

CALC. NO.: C-0031 REVISION: 7

CALC. TITLE: PIPING CODE COMPLIANCE

# SHTS. (CALC): 107 ATTACHMENTS: #/TOTAL SHTS.: 10/398 TOTAL SHTS.: 505

CHECK ONE:

[ ] INTERIM (Proposed Plant Change) [ ] VOID

[X] FINAL (Supports Installed Condition)

DESCRIPTION OF CALCULATION REVISION (IF APPL.):

SEE SHT 2 OF 2

REASON FOR CALCULATION REVISION (IF APPL.):

SEE SHT 2 OF 2

HOPE CREEK [X] Q [ ] Qs [ ] Qsh [ ] F [ ] R [ ] N/A

Q - LIST (SALEM) ? [ ] YES [ ] NO

IMPORTANT TO SAFETY ? [X] YES [ ] NO

FUTURE CONFIRMATION REQUIRED ? [ ] YES [X] NO

OTHER DOCUMENTS AFFECTED? (CBDS, FSAR, etc.): NONE

ORIGINATOR/COMPANY NAME: BBatel / FPI 7/27/94  
Date

PEER REVIEWER/COMPANY NAME: \_\_\_\_\_ 1/1  
Date

VERIFIER/COMPANY NAME: Philip M. Stahel / FPI 7/29/94  
Date

REVIEWED: [Signature] / FPI 8/15/94  
Contractor Supervisor  
(as applicable) Date

APPROVED: [Signature] 9/7/94  
PSE&G Supervisor  
(Req'd) Date

If the calculation is either Q-List, Q, Qs, Qsh, F, R, or Important to Safety "YES", completion of the Certification for Design Verification (Form NC.DE-AP.ZZ-0010-1) is required.



CALCULATION COVER SHEET

TITLE: PIPING CODE COMPLIANCE  
 DOCUMENTATION SYSTEM P-201

COVER SHEET

2 OF 2

ID NUMBER:

C-0031

REFERENCE:

REVISION HISTORY

REV.	DESCRIPTION	BY	DATE	CHKD VFR	DATE
7 IRΦ	THIS CALCULATION IS DONE BY NUTECH UNDER SNUBBER REDUCTION PROGRAM. THIS REVISION INCORPORATES DCP 4EC-1021 CD# H683/0. SHT# 1A ADDED. FOR THE DESCRIPTION OF REVISION SEE SHT# 3.	BRP	8/30/93	BRG	9/1/93
CURRENT (VALID) LSP					
CURRENT (VALID) PRINTOUT RUN ID# _____ FICHE ID # _____					
REV.	DESCRIPTION	BY	DATE	CHKD VFR	DATE
7	THIS REV SUPERSEDES & INCORPORATES DCP 4EC-1021, CD# H683/0	BRP	7/27/94	DM8	7/29/94
CURRENT (VALID) LSP					
CURRENT (VALID) PRINTOUT RUN ID# _____ FICHE ID # _____					
REV.	DESCRIPTION	BY	DATE	CHKD	DATE
CURRENT (VALID) LSP					
CURRENT (VALID) PRINTOUT RUN ID# _____ FICHE ID # _____					
REV.	DESCRIPTION	BY	DATE	CHKD	DATE
CURRENT (VALID) LSP					
CURRENT (VALID) PRINTOUT RUN ID# _____ FICHE ID # _____					



**CALCULATION  
CONTINUATION SHEET**

TITLE PIPING CODE  
 COMPLIANCE DOCUMENTATION  
 SYSTEM P- 201

ID NO. C-31  
 REFERENCE NONE

SHEET  
 1  
 OF  
 106

ORIGINATOR	0217				
DATE	10-2-88				
VFR or CKR	H&H				
DATE	6/22/88				

TABLE OF CONTENTS

	<u>PAGE</u>
PREFACE.....	2
DESCRIPTION OF REVISION.....	3
INTRODUCTION.....	4
PROCEDURE OUTLINE.....	4
CHANGES TO ANALYSIS OF RECORD.....	5
ITEMS EXCLUDED FROM THE SNUBBER REDUCTION PROGRAM.....	6
POST PHASE 2 AS-BUILT CHANGES SUMMARY.....	7
<b>ADDITIONAL INPUT DATA</b>	
o Enveloped PVRC Spectra Identification.....	19
o Seismic Anchor Movement Data.....	20
o Thermal Anchor Movement Data.....	21
o Static Torus Motion Input Data.....	22
o Load Conditions.....	23
o Load Combinations.....	33
o Geometry Plot.....	35
<b>EVALUATIONS</b>	
o Pipe Stresses.....	37
o System Functional Capability Check.....	39
o Torus Penetration Loads & Evaluation.....	40
o Torus Internal Strut Loads and Evaluation.....	47
o Equipment Nozzle Loads/Evaluation.....	67
o Expansion Joints Evaluations.....	72
o Valve Accelerations Evaluation.....	77
o Flange Evaluation.....	80
o Welded Attachment Evaluation.....	86
o Small Bore Piping Interfaces.....	90
o Pipe Support Loads & Evaluation.....	100
CONCLUSIONS.....	100
REFERENCES.....	101
ATTACHMENTS.....	-

SEE SHEET 1A



CALCULATION  
CONTINUATION SHEET

TITLE <i>PIPING CODE COMPLIANCE DOCU- MENTATION SYSTEM-P201</i>		ID NO. <i>C-0031</i>		SHEET <i>1A</i> OF <i>1</i>
ORIGINATOR <i>6/16/93</i>		REFERENCE		
✓ DATE <i>8-30-93</i>	<i>7</i>			
PEER REVIEW <i>EXL</i>				
DATE <i>9/1/93</i>				

ATTACHMENTS:

<u>ATTACH #</u>	<u>DESCRIPTION</u>	<u># OF PAGES</u>
<i>1</i>	<i>COMPUTER LISTING &amp; TAPE LOG INFO.</i>	<i>68.</i>
<i>2</i>	<i>NUTECH HG CALCULATION</i>	<i>143</i>
<i>3</i>	<i>DECOUPLED BRANCH CONNECTION DISPLACEMENT EVALUATION</i>	<i>5</i>
<i>4</i>	<i>NUTECH DESIGN INPUT LOG / RECORD INDEX.</i>	<i>7</i>
<i>5</i>	<i>DOCUMENTATION AND INTERFACE REQUIREMENTS SUMMARY</i>	<i>12</i>
<i>6</i>	<i>NUTECH COVER SHEETS</i>	<i>2</i>
<i>7</i>	<i>MARK I SPECTRA AT SBP INERFACE</i>	<i>43</i>
<i>8</i>	<i>SPECTRA CURVE</i>	<i>108</i>
<i>9</i>	<i>DESIGN VERIFICATION RECORD</i>	<i>1</i>
<i>10</i>	<i>WALKDOWN RESULTS</i>	<i>4</i>



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201.

ID NO. C-31

REFERENCE NONE

SHEET  
2  
OF

ORIGINATOR	027	7				
DATE	5/31/88					
VFR or CKR	AS11					
DATE	5/31/88					

106

PREFACE

This Revision 7 of piping calculation C-31 is done by NUTECH (for PSE&G) to document the results of the snubber reduction program performed under Purchase Order No. P1-239820. The details of the description of Revision 7 are shown on the next page.

This revision consists of:

- a) this sheet,
- b) NUTECH calculation sheets
- c) Attachment I - Computer Run Listing
- d) Attachment II - Record Index
- e) Attachment III - Computer Output (Hard Copy/Microfiche)
- f) Attachment IV - Bechtel Calculation C-31-60.
- g) Attachment V - Bechtel Calc SCF-31-10.
- h) Attachment VI - Hanger Guidance Issue, dated 11-26-85.

#5,

THIS REVISION SUPERSEDES REVISION  
60 OF THIS CALCULATION C-31



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201

ID NO. C-31


REFERENCE NONE

SHEET  
3  
OF  
106

ORIGINATOR	021	7					
DATE	6-22-88						
VFR or CKR	ABY						
DATE	6/23/88						

DESCRIPTION OF REVISION NO. 7

1. Incorporation of Snubber Reduction Evaluation.
2. Incorporation of Zero Period Acceleration (ZPA) Results.
3. Incorporation of As-Built changes Documented in:
  - a) Post Phase II Calculation C-31-60
  - b) Post Phase II Calculation No. SCF-31-10
  - c) Hanger Guidance Issue # 5 , Dated 11-26-85
4. As-Built Pipe Isometric and Pipe Support Drawings.  
 (Actual drawing number and revisions are entered in the Record Index).
5. Incorporation of following revisions of the specifications listed below:
  - a) Line Index: 10855-P-501(Q), Rev. 23
  - b) Pipe Class Sheets: 10855-P-500(Q), Rev. 27
  - c) Insulation Specification: 10855-P-516(Q), Rev. 11
  - d) Branches 2 1/2" and larger Connection 10855-P-514(Q), Rev. 0 Specification
  - e) Vent/Drain Connection Specification: 10855-P-511(Q), Rev. 1
  - f) Branches 2" and Smaller Connection 10855-P-515(Q), Rev. 1 Specification.
  - g) Piping Specification: 10855-M-068(Q), Rev. 6
  - h) Seismic Specification: 10855-G-051(Q), Rev. 1

 CALCULATION CONTINUATION SHEET	TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201		ID NO. C-31		SHEET 4 OF 106
	ORIGINATOR <u>0-21</u> 7		REFERENCE NONE		
DATE <u>5-31-88</u>		_____		_____	
VFR or CKR <u>ASH</u>		_____		_____	
DATE <u>5/31/88</u>		_____		_____	

INTRODUCTION

This revision of the original piping calculation documents the results of the Snubber Reduction Program implemented by NUTECH on Hope Creek Generating Station Unit 1 System P-201.

PROCEDURE OUTLINE

THE BASIC GEOMETRY

Geometry for this system is obtained from perm files on tape (Reference 1) available at NUTECH as qualifying analysis documentation.

A benchmark run is performed to confirm the original model. After establishing a good correlation with the original model, the model is updated to incorporate changes documented in Reference 2, and the latest pipe isometric and pipe support drawings. The isometrics, pipe support drawings, and piping qualification calculations are shown on the Record Index (Reference 3) which is included with this calculation.

LOADINGS & LOAD COMBINATIONS

The loading cases and the combinations thereof used by NUTECH in this reanalysis are the same as those used in the PUA as documented in Reference 2, except for OBE & SSE response spectra. The OBE & SSE response spectra, based on PVRC damping, are taken at all appropriate attachment points from the data generated by NUTECH (Ref. 4). Snubber reduction requires that the applicable results be lower than capacities of the components. This enveloping is performed by using NUTECH's computer code PISTAR (Ref. 5.a).

ANALYSIS TECHNIQUE

The methods of analysis used for FSAR loads in this project are the same as in the original analysis documented in set of calculations (Ref. 2). Mark I loads analyses methods ~~either are same as used in the original analysis or as outlined in procedure of Reference 6.~~ The choice of method to evaluate Mark I loads is also in accordance with criteria of technical instruction PSE-TI-002 (Ref. 7). NUTECH's computer code PISTAR is used to perform the various analyses required for this system.



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201 (C-31)

ID NO. C-31

REFERENCE NONE

SHEET  
5  
OF  
106

ORIGINATOR	021	7					
DATE	5-31-88						
VFR or CKR	ASH						
DATE	5/31/88						

EVALUATIONS

The results of these analyses are documented in various pages of this calculation. The categories of evaluations performed are in accordance with the ASME B&PV Code (Ref. 8) and are listed in the Table of Contents of this calculation. The results of the evaluations are documented in various tables of this calculation. The basis of the evaluation were computer runs listed in Reference 9. The revised support load combinations are generated by the post processor OPTSUPT (Ref. 5.b). The qualification of supports for revised loads is documented in a separate calculations (Ref. 10). The details of criteria used in the snubber reduction are available in Technical Instruction PSE-TI-002.


SUMMARY

The changes to the original analysis are listed in this calculation. A list of the snubbers status, i.e. whether snubber is deleted, replaced with strut, or left as-is is provided for reference only. A field walk down shall be performed prior to any removal/replacement of snubbers to confirm the piping clearances availability so as not to inhibit piping system predicted displacement.

CHANGES TO ANALYSIS OF RECORD

1. Use of  $E_c$ ,  $E_h$ ,  $\alpha_h$  are as required by ASME Code (Ref. 8).
2. Allowable stresses are obtained from Ref. 8 at design temperature at all service levels.
3. PVRC damping is used in accordance with ASME Code Case N-411 (Ref. 11).
4. When snubbers are replaced by struts, appropriate stiffness updates are incorporated in the PISTAR model.
5. The effects of ZPA (for both OBE & SSE) are included in the piping and pipe supports evaluations.
6. Effects of long term torus heatup are included in the piping and pipe support evaluations.



 CALCULATION CONTINUATION SHEET	TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201 (C-31)		ID NO. C-31		SHEET 6 OF 106
			REFERENCE NONE		
	ORIGINATOR DATE VFR or CKR DATE	0217 5-31-88 ABH 5/31/88			

ITEMS EXCLUDED FROM THE SNUBBER REDUCTION PROGRAM

1. Since TAP systems are either moderate or low energy systems, no check for pipe break criteria is required.
2. There are no pipe whip restraints on the TAP models, per FSAR (Ref. 12) and hence, no need to check the whip restraint gaps.
3. Since there is no set pipe deflection limit criteria, the check for interferences for pipe motions was not in the scope of snubber reduction program.

Additional Items Included in this Documentation

1. Rupture disc loads evaluation, which was originally documented in calculation D-034 (Ref. 23), is included in this package. This evaluation of rupture disc load is performed for geometry finalized after snubber reduction.
2. Operating Loads (OL) analysis was performed on the finalized geometry after the snubber reduction was completed. The loads and method of analysis was identical to those used in the original analysis of Ref. 24.



CALCULATION CONTINUATION SHEET

TITLE CODE COMPLIANCE DOCUMENTATION SYSTEM P201

ID NO. C-31


REFERENCE NONE

SHEET 7 OF 106

ORIGINATOR DATE 021 7  
 DATE 1-4-88  
 VFR or CKR 151  
 DATE 5/31/88

-SYSTEM: P 201

CHANGES PER DOCUMENTS RECEIVED AFTER ABR PERFORMED UNDER PROJECT XBP-06

NO	DESCRIPTION OF CHANGE	REFERENCE/REMARKS	PISTAR GEOM. FILE UPDATE
1	All the changes listed in SECTION-1 of CALC. NO. C-31-6Q (N CALC. XBPO06.0301) ARE INCORPORATED IN THE PISTAR FILE.	REF: SECTION-1 OF CALC NO. C. 31-6Q.	YES
2	<p>FROM ABOVE FILE XBPO06.0301 Deviation item NO 1 &amp; 31 CHANGES ARE SHOWN below SHOWN BELOW.</p>  <p>20" PIPE CAP. NODE # 145CP.</p> <p>LIVE # 007-H8B 4" Sch Std.</p> <p>150# psi WNRF Wt=16.5</p> <p>150# psi Blind flg Wt=17</p> <p>NEW NODE No=147</p> <p>Boil Wt = <math>33\frac{1}{2}</math> (20%) = 67</p> <p>TOTAL WEIGHT = 40.5</p>	<p>AS ABOVE. E<sub>1</sub></p> <p>150# 1-P-FD-01 REV-196</p> <p>LADISH CATALOG# 57</p>	<p>NO</p> <p>DUE TO <math>I_r/F_B</math> RATIO <math>&gt; 40</math> OR PIPE SIZE <math>D_r/D_B &gt; 3</math> DECOUPLE CRITERIA IS APPLIED CRIT. OFF POINT 145CP IS OK.</p>

NOTES.



**CALCULATION  
CONTINUATION SHEET**

TITLE CODE COMPLIANCE  
DOCUMENTATION  
SYSTEM P-201

ID NO. C-31

REFERENCE NONE

SHEET

8  
OF

106

ORIGINATOR 031 7  
DATE 1-5-88  
VFR or CKR ASJ  
DATE 5/31/98


SYSTEM: P 201

CHANGES PER DOCUMENTS RECEIVED AFTER ABR PERFORMED UNDER

PROJECT XBP-06

NO.	DESCRIPTION OF CHANGE	REFERENCE/REMARKS	PISTAR GEOM. FILE UPDATE
3	SUPPORT # 1-P-FD-006-HDI NODE HIA CHANGE H.L. FROM 1925# TO 2158# AND C.L. FROM 2038# TO 2270#	Ref CALC. FILE # SCF-31-19 SHT 8/26, PIPE Support. DWG REV-5	YES
3A	Sup # 1-P-FD-006-H06 NET STIFFNESS K <sub>AB</sub> = 1.402 EL 6 #/IN INCLUDING SIF = 2.0 FOR LUGS	Ref SCF-31-19 SH 9/26	YES
4	Supp # 1-P-FD-006-H08 NODE H8 CHANGES H.L. FROM 2674# TO 2860# C.L. FROM 2385# TO 2560#	Ref Supp DWG REV # 4 & FILE # SCF-31-19 SHT 11/16	YES
5	Sup # 1-P-FD-006-H19 NODE H19. CHANGE TOTAL H.L. FROM 4706# TO 4940# C.L. FROM 5020 TO 5240# and SIF = 2.0 FOR LUG'S	Ref Supp DWG REV-3 and file # SCF-31-19 SHT 13/26	YES
6	ADDED NEW NODE 27BR (20 1/4" up FROM 26BR; 3" WELD CAP NEAR Sup # 1-P-FD-006-H19 and Corrected dimension accordingly on PISTAR GEOMETRY. SIF = 3.6 AT NODE 27BR.	160# 1-P-FD-01 REV-19  PER CALC. C31-69 SECTION 6 FILE # 112201 301.03 ITEM 8(a)	YES
7	CHANGE NODE NO. H1415 TO NODE 54BR FOR 1" BRANCH # 1-P-FD-211 WITH SIF = 1.0 AT 3 1/4" SOUTH OF Sup # 1-P-FD-006-H20	150# 1-P-FD-01 REV-19	YES

NOTES.


 <b>PSEG</b> CALCULATION CONTINUATION SHEET	TITLE CODE COMPLIANCE DOCUMENTATION SYSTEM P 201	ID NO. <b>C-31</b> REFERENCE <b>None</b>	SHEET 9 OF 106	
	ORIGINATOR DATE VFR or CKR DATE	10/21/7 1-5-88 ABH 5/31/88	_____ _____ _____ _____	_____ _____ _____ _____
			_____ _____ _____ _____	_____ _____ _____ _____

-SYSTEM: P-201

CHANGES PER DOCUMENTS RECEIVED AFTER ABR PERFORMED UNDER  
PROJECT XBP-06

NO	DESCRIPTION OF CHANGE	REFERENCE/REMARKS	PISTAR GEOM. FILE UPDATE
8	ADDED NEW NODE NO 91 & 92 FOR CONN PT / NOSBA & PT / NOSBA 006-HBB-1"	Ref PER No. 7 (PREVIOUS ITEM) REF NO. <u>13</u> FOR SIF.	YES.
9	ADDED NEW NODE NO. 163 FOR 1" VENT COMPARTMEN (1-PFD-204) TO TORUS @ 30' UPCTY) FROM 20" X 16" TEE ON LINE NO. 1-P-FD-014-HBB-16", SIF=1.0 @ NODE NO. 163.	180 # 1-P-FD-01 REV-19 PER Ref <u>13</u> FOR SIF.	YES
10	Sup # 1-P-FD-014-H01 NODE (H1B) PROVIDE SIF, PER CALC. NO SC-134. (E-2.0)	Ref. FILE NO. SCF-31-1Q SH 12/26	Yes.
11	Sup # 1-P-FD-014-H02 NODE (H2B) (a) LOAD Faulted reduced to 24,000 # b) ADD SIF for Lug c) Stroke adjustment to 6"	HG ISSUE #5 & Sup DWG REV. 2	a) NO b) YES c) NO.

NOTES.

 <b>PSEG</b> CALCULATION CONTINUATION SHEET	TITLE CODE COMPLIANCE DOCUMENTATION SYSTEM P201		ID NO. C-31				SHEET 10 OF 106
	ORIGINATOR DATE VFR or CKR DATE		REFERENCE NONE				
	03/7 1-5-88 VBY 5/31/88		_____ _____ _____ _____				

-SYSTEM: P 201

CHANGES PER DOCUMENTS RECEIVED AFTER ABR PERFORMED UNDER  
 PROJECT XBP-06

NO.	DESCRIPTION OF CHANGE	REFERENCE/REMARKS	PISTAR GEOM. FILE UPDATE
13	Sup # 1-P-FD-006-H04 (NODE H4A) DESIGN LOADS & DISP CHANGED	Sup DWG REV-3	NO
14	Sup # 1-P-FD-006-H05 NODE (H5A) DESIGN LOADS & DISP. CHANGED.	Sup DWG REV 2	NO.
15	Sup # 1-P-FD-006-H07 (NODE H7) loads & displ. CHANGED.	Sup DWG REV-4	NO.
16	Sup # 1-P-FD-006-H13 (NODE H13) IS balanced to 4900 #	Sup DWG REV 6 and SCF-31-19 SH 26/26	NO
17	Sup # 1-P-FD-006-H03 (NODE H3A) NEW DISPL. AND LOADS CHANGE.	HG ISSUE NO.5 AND SUPPORT DWG REV-5.	NO.
N/A	FOLLOWING PAGES SHOW DETAILS CALCULATION REQUIRED TO UPDATE PISTAR FILE FOR DEVIATION # 27 and 28 OF CALC. FILE NO. XBP006.0301	FILE NO. XBP006.0301	YES

NOTES.



CALCULATION CONTINUATION SHEET

TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201(C-31)

ID NO. C-31  
 REFERENCE NONE

SHEET 11 OF 106

ORIGINATOR D21 7  
 DATE 2-16-88  
 VFR or CKR ASM  
 DATE 5/31/88

VALVE PROPERTIES:-

DWG NO. 10855-P301(Q)-323-4-

REV. BC REF FILE NO. PSE005.0016

18" - 150# RATING GATE VALVE WITH LIMITORUE OPERATOR.

VALVE BODY PROPERTY:-

TOTAL VALVE WEIGHT  $W_T$  (lbs) = 2950#  
 OPERATOR WEIGHT  $W_{op}$  (lbs) = 310#  
 VALVE BODY WEIGHT  $W_B = W_T - W_{op} = 2950 - 310 = 2640$  #

$$W_T \times L_2 - W_{op} \times L_1 = W_B \times X$$

$$X = \frac{W_T \times L_2 - W_{op} \times L_1}{W_B}$$

$$X = \frac{2950 \times 21.5 - 310 \times 65}{2640}$$

$$\therefore X = 16.40 \text{ IN.} \quad \therefore L = 65 - 16.40 = 48.60 \text{ IN.}$$


$$D_{\text{VALVE BODY}} = D_o + 2(T) \quad \text{WHERE}$$


$$= 20 + 2(.375) = 20.75"$$

$$T_{\text{VALVE BODY}} = 2(T) = 2(.375) = 0.75"$$

$D_o$  = RUN PIPE OD (IN)  
 $T$  = RUN PIPE THICKNESS

$\therefore$  VALVE BODY PROPERTY NO. 4 IN PISTAR ANALYSIS  
 OD = 20.75"  $t$  = 0.75" Lump WEIGHT = 2640# @ NODE VBCG  
 WEIGHT LESS @ NODE 40-45, 45-VBCG. & 45-50.



 <b>PSEG</b> CALCULATION CONTINUATION SHEET	TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201(C-31)		ID NO. C-31		SHEET 12 OF 106
	ORIGINATOR DATE VFR or CKR DATE		REFERENCE NONE		
	021 7 2-16-88 ASY 5/31/88		_____ _____ _____		

X<sub>S</sub> OPERATOR

$$K_{op} = W_{op} (2\pi f)^2 \quad \& \quad K_{op} = \frac{P}{\delta}$$

f = fundamental mode of valve assembly = 36.89 Cps  
 Ref: file # 11.2201.0715

OPERATOR DEFLECTION  $\delta_{op}$  DUE TO BENDING & SHEAR

$$\delta_{op} = \delta_{bending} + \delta_{shear}$$

$$= \frac{PL^3}{3EI} + \frac{F(PL)}{AG}$$

where  $G = \frac{E}{2(1+\nu)} = \frac{E}{2.6}$   
 &  $F = 2.0$

$$\delta = \frac{PL^3}{3EI} + \frac{5.2PL}{AE} = \frac{P}{K}$$

where  $I = \pi R^3 t$  &  $A = 2\pi R t$

REF: FORMULA FOR  
 STRESS AND STRAIN  
 BY ROARK. MCGRAW  
 HILL BOOK COMPANY,  
 FOURTH EDITION.

$$K = \frac{3EI}{L^3 \left\{ 1 + \frac{3I(5.2)}{AL^2} \right\}}$$

$$K = \frac{W_0}{g} (2\pi f)^2 = \frac{310}{386.4} (2\pi \times 36.89)^2 = 43102 \text{ lb/in}$$

E = 27.9 EG. Carbon Steel @ T = 70°

I =  $\pi R^3 t$ , A =  $2\pi R t$ , L = 48.6 and t = 0.75 use  
 $I/A = R^2/2$



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201 (C-21)

ID NO. C-31

REFERENCE NONE

SHEET  
13  
OF  
106

ORIGINATOR	D21	7				
DATE	2-16-88					
VFR or CKR	ABM					
DATE	5/31/88					

$$43102 = 729.12 I$$

$$\frac{\quad}{1 + 0.0066 I/A}$$

$$0.03986R^3 - 0.0033R^2 - 1 = 0$$

$$R = 2.975 = D_o - 0.75/2$$

$$D_o = 6.70" \text{ and } t = 0.75" \text{ use}$$

(Stem) (Stem)

VALUE Stem PROPERTY # 5 IN PISTAR ANALYSIS

Stem OD = 6.70 in Stem thickness = 0.75"

WEIGHTLESS FROM NODE VBCG - CGOP

Lump WEIGHT @ NODE CGOP = 310# OPERATOR

Lump WEIGHT @ NODE H22 = 150# CLAMP WEIGHT

(Supt # 1-P-FD-044-H22)





CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-20(C-31)

ID NO. C-31  
REFERENCE NONE

SHEET  
14  
OF  
106

ORIGINATOR	021	7				
DATE	2-16-88					
VFR or CKR	ASM					
DATE	5/31/82					

INSULATION WEIGHT:-

REF. LINE INDEX DWG NO. 10855-P-0501 REF# 13(a)

INSULATION THICKNESS DWG NO. 10855-P-051/2 REF# 13(c)

INSULATION THICKNESS = 2 IN (DENSITY  $\rho_{INS} = 14 \frac{\text{lbs}}{\text{ft}^3}$ )

ALUMINIUM JACKETING = 0.032 IN (DENSITY  $\rho_{AL} = 170 \frac{\text{lbs}}{\text{ft}^3}$ )

$$\frac{\text{TOTAL WEIGHT}}{\text{LENGTH}} = \frac{\pi}{4} \left[ \underbrace{(\text{OD}_{\text{PIPE}} + 2t_{\text{INS}})^2 - \text{OD}_{\text{PIPE}}^2}_A \right] \rho_{\text{INS}} + \frac{\pi}{4} \left[ (A + 2t_{\text{AL}})^2 - (A)^2 \right] \rho_{\text{AL}}$$

... TOTAL WEIGHT / LENGTH

$$= \frac{\pi}{4} \left\{ \left[ (\text{OD}_{\text{PIPE}} + 2t_{\text{INS}})^2 - \text{OD}_{\text{PIPE}}^2 \right] \rho_{\text{INS}} + \left[ (A + 2t_{\text{AL}})^2 - (A)^2 \right] \rho_{\text{AL}} \right\}$$



CALCULATION  
CONTINUATION SHEET

TITLE CODE COMPLIANCE  
DOCUMENTATION  
SYSTEM P20

ID NO. C-31


REFERENCE NONE

ORIGINATOR  
DATE  
VFR or CKR  
DATE

DET 7  
1-5-88  
PST  
SBI/ST

SHEET  
15  
OF  
106

DESCRIPTION: PROPERTIES (CONT.)



1) Run PIPE 24"  $\phi$

$$\therefore \text{WT/length} = \frac{\pi}{4} \left\{ (28^2 - 24^2) \frac{14}{(144)(12)} + \left[ (28.064)^2 - 28^2 \right] \frac{170}{(144)(12)} \right\}$$

$$= 1.6 \text{ lbs/in}$$

2) Run PIPE 20"  $\phi$

$$\text{WT/length} = \frac{\pi}{4} \left\{ (24^2 - 20^2) \frac{14}{(144)(12)} + \left[ (24.064)^2 - 24^2 \right] \frac{170}{(144)(12)} \right\}$$

$$= 1.36 \text{ lbs/in.}$$

3) 24" X 20 RED CALCULATING BASE ON AVG O.D. 22.0"

$$\text{WT/length} = \frac{\pi}{4} \left\{ (26^2 - 22^2) \frac{14}{(144)(12)} + \left[ (26.064)^2 - (26)^2 \right] \frac{170}{(144)(12)} \right\}$$

$$= 1.48 \text{ lbs/in}$$



**CALCULATION  
 CONTINUATION SHEET**

**TITLE** CODE COMPLIANCE  
 DOCUMENTATION  
 SYSTEM P201

**ID NO.** C-31

**REFERENCE** NONE

**SHEET**

16  
 OF  
 106

**ORIGINATOR** [Signature]  
**DATE** 1-5-88  
**VFR or CKR** [Signature]  
**DATE** 5/16/88

7


**DESCRIPTION:** PROPERTIES (CONCLUDED)

4) 16"  $\phi$  RUN PIPE.


$$\text{WT/LENGTH} = \frac{\pi}{4} \left\{ (20^2 - 16^2) \frac{14}{(144)(12)} + \left[ (20.064)^2 + 20^2 \right] \frac{176}{(144)(12)} \right\}$$

$$= 1.12 \text{ lbs/in.}$$

5) 10"  $\phi$  PIPE

$$\text{WT/Length} = \frac{\pi}{4} \left\{ \left[ (14.75)^2 - (10.75)^2 \right] \frac{14}{(144)(12)} + \left[ (14.814)^2 - (14.75)^2 \right] \frac{170}{144 \times 12} \right\}$$

$$= 0.80 \text{ lbs/in}$$

 CALCULATION CONTINUATION SHEET	TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201 (C-31)		ID NO. C-31		SHEET 17 OF 106
	ORIGINATOR DATE VFR or CKR DATE		REFERENCE NONE		
	[Handwritten initials and dates: 02/17, 2-22-88, 1/27/88, 5/31/88]		[Empty reference table]		

DESCRIPTION: SUPPORT STIFFNESS TO CORRECT ERROR IN PIP

SUPPORT DWG NO. 1-P-FD-006-H14 REV-2 Node H14

REF:- BECHTEL PIPE SUPP. CALC. NO. 1-P-FD-006-C8  
 REV-2 FROM STRUT

FRAME STIFFNESS =  $\frac{P_{\text{APPLIED LOAD AT JOINT 13}}}{\delta = \text{DEFLECTION AT JOINT 13}}$

$$K_F = \frac{48.42 \times 1000}{0.004183} = 11.575 E6 \text{ \#}/\text{in}$$

SUPPORT STRUT STIFFNESS

SIZE # 7 C-C. = 2'-10 3/4"

Fig # 211.

$$\therefore K_{ST} = \frac{1000}{0.0002} = 5.0 E6 \text{ \#}/\text{in}$$

{ REF file no. XBP006-0301 Pg 24/76.

TOTAL EFFECTIVE SUPPORT H14 STIFFNESS.

$$K_{H14} = \left\{ \frac{1}{K_F} + \frac{1}{K_{ST}} \right\}^{-1}$$

$$= \left\{ \frac{1}{11.575 E6} + \frac{1}{5.0 E6} \right\}^{-1}$$

$$K_{H14} = 3.491 E6 \text{ lbs}/\text{in}$$



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201(C-31)

ID NO. C-31  
REFERENCE NONE

SHEET  
18  
OF  
106

ORIGINATOR	031	7					
DATE	2-22-88						
VFR or CKR	187						
DATE	5/31/87						

DESCRIPTION: SUPPORT STIFFNESS TO CORRECT ERROR IN PLVA  
 SUPPORT DWG # 1-P-FD-006-H17. REV.1., Node H17

REF. BECHTEL PIPE SUPP. CALC. NO. 1-P-FD-006-C8  
 REV-2. FROM STRUDL ANALYSIS.

FRAME TS 8x8x1/2 x 9'-9" LG. STIFFNESS

APPLIED LOAD = 38.4 KIP AT JOINT # 12  
 DEFLECTION AT JOINT 12 = 0.022219.

} BECHTEL CALC #  
 1-P-FD-006-C8  
 REV-2

$$\text{FRAME STIFFNESS} = \frac{38.4 \times 1000}{0.022219}$$

$$K_F = 1.728 E6 \text{ \# / IN}$$

SUPPORT STRUT STIFFNESS

Pip - Pin (C-C) = 2'-10 13/16

$$K = \frac{AE}{L} = \frac{6.62 \times 29 E6}{34 \frac{13}{16}} = 5.51 E6 \text{ \# / IN}$$

} REF  
 XBP006.0301  
 Page 26/76

TOTAL EFFECTIVE SUPPORT H17 STIFFNESS  $K_{H17}$

$$K_{H17} = \left\{ \frac{1}{1.728 E6} + \frac{1}{5.51 E6} \right\}^{-1}$$

$$\therefore K_{H17} = 1.31546 E6 \text{ \# / IN}$$



**CALCULATION  
CONTINUATION SHEET**

**TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201 (C-31)**

**ID NO. C-31**

**REFERENCE NONE**

**SHEET**

19  
OF

106

<b>ORIGINATOR</b>	DM	7				
<b>DATE</b>	2-16-88					
<b>VFR or CKR</b>	DM					
<b>DATE</b>	5/21/88					

**TABLE 1  
ENVELOPED PVRC RESPONSE SPECTRA IDENTIFICATION (1,2,3)**

SPECIFIC BUILDING ELEVATIONS (IN FEET) ENVELOPED  
ARE NOTED BELOW:

<b>REACTOR BUILDING ELV. (FT)</b>	<b>REACTOR INTERIOR STRUCTURE ELV. (FT)</b>
X 54	72.33
X 77	145
X 102	

Vertical Spectra For Both  
Wall & Slab Are Enveloped  
For Reactor Building.

- NOTES:**
- (1) Damping was per ASME Code Case N-411 (Ref. 10).
  - (2) Appendix A shows digitized listing of the spectra.
  - (3) Response spectra at El. 72'-4" for Reactor Building is used as torus penetration point.



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201(C-31)		ID NO. C-31		SHEET 20 OF 106
		REFERENCE NONE		
ORIGINATOR	OZI 7			
DATE	2-16-88			
VFR or CKR	MSH			
DATE	5/31/88			

TABLE 2

SEISMIC ANCHOR MOVEMENT DATA

Source: (Reference 2)

<input checked="" type="checkbox"/>	TORUS (EL. 72'-4" )
<input checked="" type="checkbox"/>	REACTOR BLDG. (ELS. 54'-102" )
<input type="checkbox"/>	REACTOR BLDG. (ELS. ) INTERIOR STRUCTURE
<input type="checkbox"/>	NO ANCH MOTIONS

SAM INPUT VALUES (IN) FOR VARIOUS NODES ARE LISTED IN APPENDIX A

- NOTES:
1. NET OBE/SSE SAM =  $\sqrt{DX^2 + DY^2 + DZ^2}^{1/2}$
  2. OBE/SSE SAM ARE USED IN SUPPORT LOADS BUT ONLY OBE SAM IS USED IN ASME CODE EVALUATION.



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201(C-31)

ID NO. C-31  
REFERENCE NONE

SHEET  
21  
OF  
106

ORIGINATOR 021 7  
DATE 2-16-87  
VFR or CKR ABM  
DATE 5/31/88

TABLE-3

THERMAL ANCHOR MOVEMENTS DATA

VALUES (IN) (Ref. 2)

CONDITION	NODE	Dx	Dy	Dz
THAMA*	P201	0.021195	0.015141	-0.15411
	I958N	0.0000	-0.009546	-0.14295
	I75AN	0.028850	-0.010980	-0.14510
	HPTUB	0.000500	-0.00400	-0.00690
THAM THAM1 & THAM2	- See Below.			

\* TORUS ANCHOR DISP. @ 100°F ( $\Delta T = 30^\circ$ )

$$\begin{aligned} \text{THAM} &= \text{TORUS ANCHOR DISP. @ } 177^\circ\text{F. } (\Delta T = 107) \\ &= 3.567 \left( = \frac{107}{30} \right) \text{THAMA.} \end{aligned}$$

$$\begin{aligned} \text{THAM1} &= \text{TORUS ANCHOR DISP. @ } 167^\circ\text{F. } (\Delta T = 97^\circ\text{F}) \\ &= 3.233 \left( = \frac{97}{30} \right) \text{THAMA} \end{aligned}$$

$$\begin{aligned} \text{THAM2} &= \text{TORUS ANCHOR DISP @ } 212^\circ\text{F. } (\Delta T = 142) \\ &= 4.733 \left( = \frac{142}{30} \right) \text{THAMA.} \end{aligned}$$





CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201 (C-31)

ID NO. C-31  
REFERENCE NONE

SHEET  
22  
OF  
106

ORIGINATOR	021	7					
DATE	2-16-88						
VFR or CKR	ASB						
DATE	5/31/88						

TABLE-4

STATIC TORUS MOTION INPUT DATA

VALUES (IN) (Ref. 2)

CASES	NODE	DX	DY	DZ
TD	P201	0.00500	0.002900	-0.0882
	I9SBN	0.0000	-0.007660	-0.04816
	I7SAN	0.008065	-0.00400	-0.04053
TD1*	↓	↓	↓	↓
TD2*	↓	↓	↓	↓
TD3	N/A	→		

\* TD1 & TD2 ARE SAME AS TD. CONSERVATIVELY.



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201

ID NO. C-31  
REFERENCE NONE

SHEET 23  
OF 106

ORIGINATOR	DJH	F				
DATE	5/31/88					
VFR or CKR	ASB					
DATE	5/31/88					

TABLE 5  
LOADING CONDITIONS

PISTAR LOAD CASE ID	DESCRIPTION	ANALYZED DURING ITERATIONS
DW	Dead Weight with Normal Contents	Yes
DWT	Dead Weight with Water	No/YES
OBEI	Operating Basis Earthquake (Inertia) including ZPA Effect	Yes
OBED	Operating Basis Earthquake Anchor Motions	Yes
SSEI	Safe Shutdown Earthquake (inertia) including ZPA Effects	Yes
SSED	Safe Shutdown Earthquake Anchor Motions	Yes
TE*	Normal Operating Thermal Expansion (Maximum of Different Modes.)	Yes
TE1*	Maximum Operating Thermal Expansion (Maximum of Different Modes.)	Yes
TE2*	Thermal Expansion for Long Term Torus Heatup	Yes
THAM	Normal Operating Thermal Anchor Motions	Yes
THAM1	Maximum Operating Thermal Anchor Motions	Yes
THAM2	Thermal Anchor Motions due to Long Term Torus Heatup	Yes
OL	Operating Loads	No
TD,TD1	Static Torus Displacement due to Normal Operating, and Maximum of SBA, IBA, DBA Conditions Respectively	No
TD2	Static Torus Displacement due to Deadweight of Water and Pressure of 62 psig.	Yes
QAB	SRV Hydrodynamic Load	No
QABI	SRV Torus Motion Inertia Effects (see page 32 for details)	No
CO	Condensation Oscillation Hydrodynamic Loads	No
COI	Condensation Oscillation Torus Motion Inertia Effects	No
CHUG	Post-Chugging Hydrodynamic Loads	No
CHUGI	Post-Chugging Torus Motion Inertial Effects	No
RDPD1	RUPTURE DISC EVALUATION**	YES

\* See Ref. 22 and next 3 pages for details of input  
 \*\* See pages 27 through 31 for the details of input.





CALCULATION CONTINUATION SHEET


TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201 (C-31)

ID NO. C-31  
 REFERENCE NONE

SHEET 25 OF 106


ORIGINATOR	031	5				
DATE	05-18-88					
VFR or CKR	ASG					
DATE	03/1/88					

Penetration P201




CASE - TEI.

FROM NODE.	TO NODE.	FROM THE ABOVE SKETCH OF REF-22 SECTION	THERMAL MODE = TEI. MAX OP. F.	$\Delta T$
IICAP	P201	N/A	167.0	97.0
ExNOZ	155	A plus B	283.0	213.0
160	210	C	110.0	40.0

 CALCULATION CONTINUATION SHEET	TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201 (C-31)		ID NO. C-31		SHEET 26 OF 106
	ORIGINATOR DATE 05-18-88 VFR or CKR DATE 1/20/89 DATE 5/31/89		REFERENCE NONE		
	021 5		_____ _____ _____		

Penetration P 201



FROM NODE.	TO NODE.	FROM THE ABOVE SKETCH OF REF-22 SECTION	THERMAL MODE LONG TERM TORUS HEAT-UP TE2 F.	$\Delta T$ F.
IICAP	P201	A	212.0	142.0
EXNOZ	155	A-B	283	213.0
100	210	C	AMB = 110	40.0



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201 (C-31)

ID NO. C-31

REFERENCE NONE

ORIGINATOR  
DATE  
VFR or CKR  
DATE

021 5  
05-08-88  
NBN  
5/31/89

SHEET  
27  
OF  
106

LOCA- TIME HISTORY ANALYSIS

CALCULATION DAMPING VALUES

REF. <sup>25</sup> R.W. CLOUGH, DYNAMICS OF STRUCTURE, 1976

PARAMETERS (damping for critical frequencies of loads)

$$f_1 = 5 \text{ Hz}$$

$$T_1 = \frac{1}{f_1} = 0.2$$

$$f_2 = 50 \text{ Hz}$$

$$T_2 = \frac{1}{f_2} = 0.02$$

$$\Delta t = 0.001 \text{ Sec}$$

Damping due to Time Steps (Ref. <sup>25</sup> Pg 47 & 269)

$$\frac{\Delta t}{T_1} = \frac{0.001}{0.2} = 0.005 \quad \text{---} \quad AD_1 = 0$$

$$\frac{\Delta t}{T_2} = \frac{0.001}{0.02} = 0.05 \quad \text{---} \quad AD_2 = 1.3$$

} with  $\theta = 1.4$   
(Value in plot).

$$(\xi)_{\Delta t} = \frac{V_n - V_{n+1}}{2\pi (V_{n+1})}$$

$$V_n = 1$$

$$V_{n+1} = (1 - AD)V_n$$

$$\therefore (\xi)_{\Delta t} = \frac{1.0 - [1.0 - (0.0)]1.0}{2\pi [1.0 - (0.0)]1.0} = 0.0$$



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201 (C-31)

ID NO. C-31  
REFERENCE NONE

SHEET  
28  
OF  
106

ORIGINATOR	021	5				
DATE	05-08-88					
VFR or CKR	ABY					
DATE	5/31/88					

$$(\xi_2)_{AT} = \frac{[1 - (1 - 0.013)] 1.0}{2\pi (1 - 0.013) 1.0} = 0.002$$

Damping Due to  $\alpha \frac{1}{2} \beta$  (Ref. Pg 196)

$$\xi_n = \frac{1}{2\omega_n} \sum_b a_b \omega_n^{2b}$$

Letting  $\alpha = a_0$   
 $\beta = a_1$   
 $b = 0, 1$

$$\text{Then } \xi_n = \frac{1}{2\omega_n} (\alpha + \beta \omega_n^2)$$

given  $\omega_1 = 2\pi f_1 = 2\pi(5) = 31.416 \text{ Rad/sec}$   
 $\omega_2 = 2\pi f_2 = 2\pi(50) = 314.2 \text{ Rad/sec.}$

$$\xi_1 = \frac{\alpha}{2\omega_1} + \frac{\beta\omega_1}{2}$$

$$\xi_2 = \frac{\alpha}{2\omega_2} + \frac{\beta\omega_2}{2}$$

$$D - (\xi_1)_{AT} = \frac{\alpha}{2\omega_1} + \frac{\beta\omega_1}{2}$$

$$D - (\xi_2)_{AT} = \frac{\alpha}{2\omega_2} + \frac{\beta\omega_2}{2}$$



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201 (C-31)

ID NO. C-31

REFERENCE NONE

SHEET  
29  
OF

ORIGINATOR  
DATE  
VFR or CKR  
DATE

021 5  
05-08-88  
AS1  
5/31/88


106

FOR 3% Damping ( $D=0.03$ )

$$0.03 - 0 = \frac{\alpha}{2(31.416)} + \frac{31.416 \beta}{2} \quad \text{--- Eqn 1}$$

$$0.03 - 0.002 = \frac{\alpha}{2(314.16)} + \frac{314.16 \beta}{2} \quad \text{--- Eqn 2}$$

$$0.03 = 0.0159\alpha + 15.708\beta \quad \text{--- Eqn 1}$$

$$0.028 = 0.00159\alpha + 157.08\beta \quad \text{--- Eqn 2}$$

$$(0.03) \times 10 = 10 [0.0159\alpha + 15.708\beta]$$

$$0.3 = 0.159\alpha + 157.08\beta \quad \text{--- Eqn 1a}$$

$$0.028 = 0.00159\alpha + 157.08\beta \quad \text{--- Eqn 2a}$$

∴ Solving Eqn 1a & 2a

$$\begin{aligned} 0.3 &= 0.159\alpha + 157.08\beta \\ - 0.028 &= -0.00159\alpha - 157.08\beta \end{aligned}$$

---


$$0.272 = 0.15741\alpha$$

$$\therefore \alpha = 1.727915$$

$$0.3 = 0.159(1.727915) + 157.08\beta$$

$$\beta = 16.08 \times 10^{-5}$$

PSTAR INTEGRATE CARD  $\alpha = 1.727915$  &  $\beta = 16.08 \text{E-}05$





CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201 (C-31)

ID NO. C-31  
REFERENCE NONE


SHEET  
30  
OF  
106

ORIGINATOR	021	7					
DATE	05-11-88						
VFR or CKR	BSM						
DATE	5/31/88						

DYNAMIC TIME HISTORY.

DYNAMIC ANALYSIS FOR THE HPCI STEAM EXHUST  
LINE DUE TO THE 40 MSEC RUPTURE OF THE PRESSURE  
RELIEF DISK.

REF: BECHTEL CALC. REPORT NO. S/10855/D-034 REV-1  
NUTECH FILE NO. PBE005.0024.06 (Ref. 23)



SECTION	Lg (Ft)	FORCE (LBS)	t <sub>0</sub> (MSEC)	Time (MSEC)			
				t <sub>1</sub>	t <sub>2</sub>	t <sub>3</sub>	t <sub>4</sub>
A	5.92	5756	3.56	0.0	3.56	40.00	43.56
B	19.08	18851	11.47	3.56	15.03	43.56	55.03
C	18.30	33250	11.00	15.03	55.03	steady - state	

NEXT PAGE SHOWS PISTAR INPUT CARD AMPLITUDE → TIME VERSUS  
FORCE FUNCTION FOR SECTION A, B, & C AMPLITUDE 1, 2, and 3 RESPECTIVELY.



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201 (C-31)

ID NO. C-31  
REFERENCE NONE

SHEET  
31  
OF  
106

ORIGINATOR	027	7					
DATE	5/3/88						
VFR or CKR	ASH						
DATE	5/31/88						

SECTION NO.	AMPLITUDE No.	FORCE LBS	TIME t <sub>1</sub> SEC	FORCE LBS.	TIME t <sub>2</sub> SEC.	FORCE LBS.	TIME t <sub>3</sub> SEC.	FORCE LBS	TIME t <sub>4</sub> SEC.
A	1	0.0	0.0	5756	0.004	5756	0.04	0.0	0.044
B	2	0.0	0.004	18551	0.015	18551	0.044	0.0	0.055
C	3	0.0	0.015	33250	0.055	33250	0.300	/	/



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201 (C-3) 1

ID NO. C-31

REFERENCE NONE

SHEET  
32  
OF

ORIGINATOR DATE	051 7 5-17-88					
VFR or CKR DATE	ASW 6/17/88					

106

Additional Load Cases for P201

<u>Case ID</u>	<u>Description</u>
QABIB	SRV Torus motion @ 2% Damping (case C3.1)
QABI	" " " " " " " (case A1.2, C3.2)
QABI3	" " " " 3% " " " "

(This case can be used in lieu of QABI if required)



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-20

ID NO. C-31  
REFERENCE NONE

SHEET  
33  
OF  
106

ORIGINATOR	021	7				
DATE	5/31/88					
VFR or CKR	ASD					
DATE	5/31/88					

Table 6

ASME CLASS 2 PIPING EVALUATION LOAD COMBINATIONS

DESCRIPTION	SERVICE LEVEL	ASME CODE (NC-3650) EQN	ALLOWABLE LIMIT
(WEIGHT) + (DESIGN PRESSURE)	Design	8	$1.0 S_h$
(WEIGHT) + (PEAK PRESSURE) + (OBE) OR (SRV)	B	9	$1.2 S_h$
(THERMAL RANGE) + (OBE ANCHOR MOTION + MARK 1 ANCHOR MOTIONS) OR 2 x (OBE ANCHOR MOTION) *	A & B	10	$S_A = f$ $(1.25 S_c + 0.25 S_h)$
(WEIGHT) + (DESIGN PRESSURE) + (THERMAL RANGE) + (OBE ANCHOR MOTION + MARK 1 ANCHOR MOTIONS) OR (WEIGHT) + (DESIGN PRESSURE) + 2 x (OBE ANCHOR MOTION) *	A & B	11	$S_A + S_h$
(WEIGHT) + (PEAK PRESSURE) + (SRV & LOCA OR SSE COMBINED BY SRSS)	C	9	$1.8 S_h$
(WEIGHT) + (PEAK PRESSURE) + [(SSE) + (LOCA) + (SRV) COMBINED BY SRSS] AND DW + RVP-DISC	D	9	$2.4 S_h$
(HYDRO WEIGHT) + (1.25 DESIGN PRESSURE)	TEST	8	$1.0 S_h$

- NOTES:
- 1) OBE and SSE includes ZPA effects
  - 2) See listing in Appendix A for the details of the evaluation of these load combinations.

\* Includes long Term Trans Heatup case.



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201

ID NO. C-31  
REFERENCE NONE

SHEET  
34  
OF  
106

ORIGINATOR DATE VFR or CKR DATE	021 05/31/88 KSH 5/31/88	7					
--	-----------------------------------	---	--	--	--	--	--

Table 7

ASME CLASS 2 PIPE SUPPORT LOADING COMBINATIONS

DESCRIPTION	ASME CODE SERVICE LEVEL
(WEIGHT) + (OPERATING LOADS)	A
(WEIGHT) + (MAX. THERMAL) + (OBE PLUS OBE ANCHOR MOTION) OR (WEIGHT) + (MAX. THERMAL) + (SRV PLUS SRV ANCHOR MOTION)	B
(WEIGHT) + (MAX. THERMAL) + (SSE PLUS SSE ANCHOR MOTION COMBINED WITH SRV BY SRSS) OR (WEIGHT) + (MAX. THERMAL) + (LOCA PLUS LOCA ANCHOR MOTION COMBINED WITH SRV BY SRSS)	C
[ (WEIGHT) + (MAX. THERMAL) + (SSE PLUS SSE ANCHOR MOTIONS, SRV, LOCA COMBINED BY SRSS) ] <u>OR</u> DW+RUP DISC.	D

- NOTES: 1) OBE and SSE includes ZPA effects  
 2) See listing in Appendix A for the details of the evaluation of these load combinations.



CALCULATION  
CONTINUATION SHEET


TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201 (C-31)

ID NO. C-31  
REFERENCE NONE


SHEET  
35  
OF  
106

ORIGINATOR  
DATE  
VFR or CKR  
DATE

02 7  
2-16-88  
ASB  
5/31/88



NUTECH/PISTAR PIPING MODEL  
PLOT TO ( : : : : R )




COORDINATE SYSTEM

VIEWPOINT  
X -1.00 Y 0.75 Z -1.00

TORUS PENETRATION P201 TURBINE EXHURST  
HOPE CREEK PUR

SNUBBER D = DELETED  
R = CHANGED TO STRUT.  
S = REMAINS SNUBBER.





CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-20 (C-3)

ID NO. C-31  
REFERENCE NONE

SHEET  
36  
OF  
106

ORIGINATOR DATE VFR or CKR DATE	DJI 10-9-88 NBY 6/24/04	7					
--	----------------------------------	---	--	--	--	--	--

10% Exclusion Evaluation Summary (Stress in psi)

NODE	CAPI stress	CHUGI stress	CPJ stress	(CHUGI <sup>2</sup> +CPJ <sup>2</sup> ) <sup>1/2</sup>	
}	*				Main Line 20" NPS before Tee @ 100T.
					Main 20" NPS line after Tee @ 100T
					Branch Line 16" NPS
Allowable	1800 psi	N/A	3600 psi	2700 psi	

\* REVIEWING OF STRESS SUMMARY, 10% CUT-OFF ZONE IS  
 BEYOND 20" MAIN LINE ie 16" BRANCH LINE FROM NODE NO.  
 106 - TO NODE NO. 210.



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-20

ID NO. c-31  
REFERENCE NONE

SHEET  
37  
OF  
106

ORIGINATOR DATE VFR or CKR DATE	021 06-22-88 ASD 6/24/88	7					
--	-----------------------------------	---	--	--	--	--	--

TABLE 8  
ASME CLASS 2 PIPING STRESS SUMMARY

Component: See Below Allowable Stress;  $S_h = 15,000$  psi  
 Material: SA-106, Gr. B at Temperature;  $T = 366$  °F

I. Maximum Primary Stress for Design Condition

ASME CRITERIA	Node/ Description	Stress in PSI	
		Calculated	Allowable
Equation 8 of NC-3652.1 $S_{SL} \leq 1.0 S_h$ (includes operating load)	EXNUZ / elbow	3,944	15,000

II. Maximum Primary Stress for Upset Condition

ASME CRITERIA	Node/ Description	Stress in PSI	
		Calculated	Allowable
Equation 9 of NC-3652.2 $S_{SL} \leq 1.2 S_h$	EXNUZ / elbow	11,664	18,000

III. Maximum Primary Stress for Emergency Condition

ASME CRITERIA	Node/ Description	Stress in PSI	
		Calculated	Allowable
Equation 9 of NC-3652.2 $S_{SL} \leq 1.8 S_h$	EXNUZ / elbow	19,239	27,000

IV. Maximum Primary Stress for Faulted Condition

ASME CRITERIA	Node/ Description	Stress in PSI	
		Calculated	Allowable
Equation 9 of NC-3652.2 $S_{SL} \leq 2.4 S_h$	190 / Elbow ①	20,804 ①	36,000
	EXNUZ / Elbow ②	19,458	

V. Maximum Primary Stress for Test Condition (HYDRO TEST)

ASME CRITERIA	Node/ Description	Stress in PSI	
		Calculated	Allowable
Equation 8 of NC-3652.1 * $[1.25P + DW] \leq 1.0 S_h$ + OL.	65 / ELBOW	5598 *	15,000

① FOR RUPTURE DISK ANALYSIS \*  $(1.25 \times 2067) + 2927 + 87$   
 + OL. = 18,934 + 1870 = 20,804 = 5598 psi  
 ② FOR REGULAR MARK + OL ANALYSIS.





CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201

ID NO. C-31  
REFERENCE NONE

SHEET  
38  
OF  
106

ORIGINATOR DATE VFR or CKR DATE	<u>DAI</u> <u>6-22-88</u> <u>ASB</u> <u>6/24/88</u>	<u>7</u>					
--	--	----------	--	--	--	--	--

TABLE 9

ASME CLASS 2 PIPING SECONDARY STRESS SUMMARY

Component: See Below Allowable Stress;  $S_A = 22,500$  psi  
 Material: SA-106, Gr. B at Temperature;  $T = 366$  °F

I. Maximum Secondary Stress

ASME CRITERIA	Node/ Description	Stress in PSI	
		Calculated	Allowable
Equation 10 of NG-3652.3(a) $S_E \leq S_A$	35/Elbow	12,984	22,500

II. Maximum Primary Plus Secondary Stress

ASME CRITERIA	Node/ Description	Stress in PSI	
		Calculated	Allowable
Equation 11 of NG-3652.3(c) $S_{TE} \leq S_A + S_h$	35/Elbow	16,394	37,500



CALCULATION CONTINUATION SHEET

TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201

ID NO. C-31  
 REFERENCE NONE

SHEET 39 OF 106

ORIGINATOR	081	7				
DATE	06-22-88					
VFR or CKR	AK					
DATE	6/24/88					

TABLE 10

SYSTEM FUNCTIONAL CAPABILITY CHECK (Ref 7) (1, 2)

NODE	SIZE & SCH.	COMPONENT TYPE	MAX. OF LEVEL C OR D STRESS (PSI) (3)	ALLOWABLE STRESS <math>< 1.5 S_y</math> (psi)	PASS FAIL
←		Straight Pipe	Enveloped by	Elbow value →	
		Elbow	21,989.	45,510	PASS
←		Tee	Enveloped by	Elbow value →	
N/A	N/A	Branch	N/A	N/A	N/A
←		Reducer	Enveloped by	Elbow values →	

NOTES: 1) Functionality Evaluation is not required for line 1-P-FD-014-HBB-16" per Ref. 7. And also for internal piping no evaluation is required.

2) Both 24" & 20" NPS pipes have  $D_o/H > 50$ . } and therefore  
 $24/0.375 = 64$  and  $20/0.375 = 53.33$   
 $0.75d$  should be divided by (conservatively) lowest of two  $f$  factors for functionality evaluation  
 $f_1 = (1.3 - 0.006 * 64)(1.033 - 0.00033 * 64) = 0.9461$   
 $f_2 = (1.3 - 0.006 * 53.33)(1.033 - 0.00033 * 53.33) = 1.012$  [choose  $f = 0.9461$ ]

3) stress = PIPING STRESS / 0.9461 =  $\frac{20,804}{0.9461} = 21,989$



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201 (C-3)

ID NO. C-31  
REFERENCE NONE

SHEET  
40  
OF  
106

ORIGINATOR DATE	<i>DJL</i>	<i>7</i>				
VFR or CKR DATE	<i>06-10-88</i>					
	<i>1871</i>					
	<i>6/10/88</i>					

TORUS PENETRATION LOADS EVALUATION

The revised loads for the torus penetration P-201 are shown on the next 6 pages. The qualification and acceptance of these revised loads is documented in NUTECH calculation listed as Reference 16.

The revised coupled response spectra plots and the digitized values at torus penetration P-201 are shown in Attachment III of this calculation.

Rupture disc load <sup>reactions</sup> have very small compared to other dynamic load but they are reported for use in penetration evaluation.



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-20)

ID NO. C-31  
REFERENCE NONE


SHEET  
41  
OF  
106

ORIGINATOR  
DATE  
VFR or CKR  
DATE

021 7  
060388  
1801  
6/6/88

TORUS SHELL REACTIONS FORCES AND MOMENTS AT PENETRATION P20

LOAD TYPE	FORCES ( $\frac{lbs}{kips}$ )			MOMENTS ( $\frac{lbs}{kips}$ -in.)			REMARKS
	Fx	Fy	Fz	Mx	My	Mz	
DW	+193	+5176	-5412	+1761	-589	+228	
OL	$\pm 208$	$\pm 25531$	$\pm 47638$	$\pm 12355$	$\pm 513$	$\pm 186$	
TD1	-210	-117	-440	-2010	+1490	+271	
TE1	+3022	+2026	-1057	-7487	+6556	-5872	
THAM1	-829	-168	-1821	+7053	+410	+178	
OBEI	$\pm 802$	$\pm 1160$	$\pm 1627$	$\pm 461$	$\pm 3961$	$\pm 1173$	
OBED	$\pm 262$	$\pm 322$	$\pm 229$	$\pm 140$	$\pm 2708$	$\pm 1026$	
QAB	$\pm 693$	$\pm 7522$	$\pm 1128$	$\pm 3299$	$\pm 6486$	$\pm 2441$	
QABI *	$\pm 4231$	$\pm 11691$	$\pm 10491$	$\pm 1499800$	$\pm 447010$	$\pm 284030$	Case C3-1
	$\pm 8180$	$\pm 14311$	$\pm 17868$	$\pm 1310000$	$\pm 659540$	$\pm 381150$	Case C3-2
CHUG	$\pm 3661$	$\pm 2831$	$\pm 7848$	$\pm 2913$	$\pm 12275$	$\pm 5447$	
CHUGI	+843	$\pm 3615$	$\pm 5544$	$\pm 182070$	$\pm 91013$	$\pm 82961$	
CO	← Same as CHUG →						
COI	$\pm 2701$	$\pm 9200$	$\pm 14469$	$\pm 805560$	$\pm 310490$	$\pm 226920$	



\* These values should be multiplied by a non-quencher bay reduction factor of 0.73 per Reference 26 before using in any further combinations. Case C-32 loads are reported for accident condition @ 2% while Case C3-1 is @ 2% normal condition.




CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P- 201		ID NO. C- 31	SHEET 42 OF 106
ORIGINATOR DATE VFR or CCR DATE		REFERENCE NONE	
	031 7		
	06-03-88		
	ASST		
	6/6/88		

TORUS SHELL REACTIONS FORCES AND MOMENTS AT PENETRATION P201

LOAD TYPE	FORCES ( <sup>lbs</sup> <del>kip</del> )			MOMENTS ( <sup>lbs</sup> <del>kip</del> -in.)			REMARKS
	Fx	Fy	Fz	Mx	My	Mz	
SSEI	±1225	±1866	±2692	±764	±5755	±1692	
SSED	±511	±633	±474	±267	±5334	±2015	
TD2	} Included in TEST case						
TE2							
THAM2							
TE2T	+1765	+1610	-4277	-2332	+10292	-5695	
RUPD1	±546	±957	±1539	±494	±1409	±398	Rep. Disc load





CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201

ID NO. C-31  
REFERENCE NONE


SHEET  
43  
OF  
106

ORIGINATOR DATE VFR or CKR DATE	DJI 7 06-03-88 ASD 616188						
--	------------------------------------	--	--	--	--	--	--

INTERNAL NOZZLE FORCES AND MOMENTS AT PENETRATION P201

LOAD TYPE	FORCES ( <sup>lbs</sup> <del>kips</del> )			MOMENTS ( <sup>lbs</sup> <del>kips</del> -in.)			REMARKS
	Fx	Fy	Fz	Mx	My	Mz	
DW	+4484	+5371	-74	+14754	-9162	-24544	
OL	±42777	±33457	±152	±14566	±18880	±59289	
TD 1	+171	-123	+183	-17566	+22783	+31680	
TEL	-163	+91	-246	+23548	-30553	-26859	
THAM1	+570	-343	+795	-76218	+98860	+97330	
OBEI	±1180	±1167	±639	±33106	±29967	±14688	
OBED	±46	±41	±111	±10618	±13772	±8479	
QAB	±225	±6358	±1053	±106713	±35871	±41706	
QABI *	±7396 ±9528	±13543 ±15088	±2498 ±3029	±101880 ±200000	±113160 ±315220	±1423200 ±1412600	CASE C3-1 CASE C3-2
CHUG	±7943	±4286	±3053	±236938	±60399	±46187	
CHUGI	±4476	±4140	±953	±82668	±72812	±184580	
CO	Same as CHUG →						
COI	±11696	±10744	±2321	±241950	±248070	±796110	

\* SEE NOTE PG. A1





CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201

NO. C-31

REFERENCE NONE


SHEET  
44  
OF  
106

ORIGINATOR  
DATE  
VFR or CR  
DATE

021 7  
06-03-88  
ASW  
6/6/88

INTERNAL NOZZLE FORCES AND MOMENTS AT PENETRATION P201

LOAD TYPE	FORCES ( <sup>lbs</sup> kips)			MOMENTS ( <sup>lbs</sup> ft-in.)			REMARKS
	Fx	Fy	Fz	Mx	My	Mz	
SSEI	±2010	±1942	±1012	±49313	±43991	±21040	
SSED	±91	±79	±226	±21656	±28087	±16515	
TD2	} Included in TEST Case →						
TE2							
THAM2							
TEST	+886	-609	+1034	-99192	+128648	+160689	
RUPD1	±1094	±977	±425	±15250	±15902	±14536	Pub Disc





CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201

ID NO. C-31  
REFERENCE NONE


SHEET  
45  
OF  
106

ORIGINATOR	<u>DST</u>	<u>7</u>					
DATE	<u>06-03-88</u>						
VFR or CKR	<u>BSY</u>						
DATE	<u>6/16/88</u>						

EXTERNAL NOZZLE FORCES AND MOMENTS AT PENETRATION P201

LOAD TYPE	FORCES ( $\frac{\text{lbs}}{\text{KIPS}}$ )			MOMENTS ( $\frac{\text{lbs}}{\text{KIPS}}\text{-in.}$ )			REMARKS
	Fx	Fy	Fz	Mx	My	Mz	
DW	+52	-666	+119	+14876	-8543	-22783	
OL	$\pm 295$	$\pm 43$	$\pm 57$	$\pm 14293$	$\pm 18407$	$\pm 46933$	
TD 1	-283	-85	-27	-17039	+21363	+29670	
TEL	-851	-2088	+2777	+18903	-38029	-34346	
THAM1	-1253	-793	-35	-75330	+94844	+104383	
OBEI	$\pm 643$	$\pm 414$	$\pm 517$	$\pm 32677$	$\pm 32950$	$\pm 14758$	
OBED	$\pm 170$	$\pm 307$	$\pm 244$	$\pm 10896$	$\pm 12950$	$\pm 8618$	
QAB	$\pm 30$	$\pm 1245$	$\pm 359$	$\pm 105435$	$\pm 29060$	$\pm 38406$	
QABI *	$\pm 8025$ $\pm 16993$	$\pm 889$ $\pm 1704$	$\pm 3006$ $\pm 5854$	$\pm 8309$ $\pm 4207$	$\pm 469290$ $\pm 965550$	$\pm 78543$ $\pm 194340$	CASE C3.1 CASE C3.2
CHUG	$\pm 270$	$\pm 2603$	$\pm 656$	$\pm 233499$	$\pm 47485$	$\pm 47145$	
CHUGI	$\pm 681$	$\pm 319$	$\pm 982$	$\pm 17950$	$\pm 43727$	$\pm 12920$	
CO	← Same as CHUG			→			
COI	$\pm 2337$	$\pm 1060$	$\pm 2184$	$\pm 64969$	$\pm 154290$	$\pm 45130$	

\* SEE NOTE PG. 41







CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P- 201

ID NO. C- 31

REFERENCE NONE

SHEET

46  
OF


106

ORIGINATOR  
DATE  
VFR or CCR  
DATE

QST 7  
06-03-88  
ASB  
06/15/88

EXTERNAL NOZZLE FORCES AND MOMENTS AT PENETRATION P201

LOAD TYPE	FORCES ( <sup>lbs</sup> kips)			MOMENTS ( <sup>lbs</sup> kips-in.)			REMARKS
	Fx	Fy	Fz	Mx	My	Mz	
SSEI	±952	±597	±766	±48686	±48252	±21101	
SSED	±355	±606	±476	±22183	±26668	±16781	
TD2	} Included in TE2T case						
TE2							
THAM2							
TE2T	-3047	-2936	+2799	-103014	+117524	+158357	
RDPD1	± 305	± 388	± 402	± 15125	± 15654	± 14546	Rep. Disc





CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201

ID NO. C-31

REFERENCE NONE

SHEET  
47  
OF  
106

ORIGINATOR	DJF	7				
DATE	06-22-88					
VFR or CKR	ASM					
DATE	6/24/88					

TORUS INTERNAL STRUT LOADS AND EVALUATIONS

The next 20 pages show the ~~combination of~~ loads for the torus internal struts at locations 1, 2, 3, 4. These combinations are done for worst case Level D only using three options:

- ~~a) Static direct and dynamic by SBSS~~
- ~~b) Static direct and dynamic by ABS~~
- ~~c) All loads by ABS~~

REVIEW OF LOADS WAS DONE FOR  $F_x, M_y, M_z$  @ LOCATION-2  
 Furthermore, these combinations were done only for three components,  $F_x, F_y$ , and  $F_z$ , as these are critical components per Reference 18. The revised torus internal strut loads are acceptable because of one of the following (Circle applicable):

- a) Revised loads ( $F_x, M_y, M_z$ ) are lower than PUA loads (Ref. 19),  
OR
- b) Revised load combinations are lower than the PUA combinations for ~~the same system or~~ the loads used to qualify the group in which this system falls per Reference 18. *See next page for further details.*  
OR
- c) ~~Revised loads are qualified with new calculation or revision to the calculation of Reference 18.~~



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-20 (C-31)

ID NO. C-31.  
REFERENCE NONE

SHEET  
48  
OF  
106

ORIGINATOR	07	7					
DATE	06-22-88						
VFR or CKR	ABV						
DATE	6/24/88						

TOURUS INTERNAL STRUT LOADS EVALUATION CONT.

STRUTS

a) THE REVISED LOADS  $F_x, M_y, M_z$  - THE CRITICAL COMPONENTS FOR INTERNAL STRUT 'A' AND 'B' ARE APPROXIMATELY SAME AS PUA LOADS AT ALL (1-4) LOCATION FOR WORST LEVEL-D COMBINATION,

b) BUT LEVEL-B REVISED LOADS COMBINATION AT LOCATION-② OF STRUT A & B THE CRITICAL COMPONENTS ( $F_x, M_y, M_z$ ) ARE INCREASED MAXIMUM OVERALL 5% THAN QUALIFIED PUA LOADS (REF-18). Thus strut can be qualified <sup>for new loads</sup> BY INCREASING OVERALL 5% TO INTERACTION EQUATION Pg 18/73 OF REF-18. ie  $0.926 \times 1.05 = 0.9723 < 1 \therefore O.K$   
 $\therefore$  NO FURTHER DETAILS CALCULATION IS REQUIRED.

End Plates/Clevis

a) SIMILARY FOR LEVEL-B REVISED LOADS COMBINATION AT LOCATION ① AND ③ OF STRUT A & B THE CRITICAL COMPONENTS ( $F_x, F_y, F_z$ ) ARE INCREASED MAXIMUM OVERALL 5%. Thus end plate/clevis CAN BE QUALIFIED <sup>for new loads</sup> BY INCREASING OVERALL 5% TO INTERACTION EQUATION Pg 31/73 OF REF: 18  
 ie  $0.456 \times 1.05 = 0.479 < 1.0 \therefore O.K.$   
 NO FURTHER DETAILS CALCULATION IS REQUIRED.

CONCLUSION: REVISED LOAD COMBINATION FOR LOCATION 1-4 FOR STRUT A & B ARE QUALIFIED PER REF 18.



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201 (C-31)

ID NO. C-31  
REFERENCE NONE

SHEET  
49  
OF  
106

ORIGINATOR DATE VFR or CWR DATE	PKY 6/10/88 JSM 6/22/88	7							
--	----------------------------------	---	--	--	--	--	--	--	--

[STRUT A.]

Summary of Internal Strut Reaction Loads  
penetration P201 Strut<sup>A</sup> attached to Ring Beam




Figure 1 Local Strut Coordinate System




Figure 2 Shell Coordinate System

Loads are provided at the following locations except as noted in the attached tables.

Location ①	Node ILSAP
Location ②	Node I4SA
Location ③	Node I6SAP
Location ④	Node I7SAN

Locations ①, ②, & ③ are in local strut coordinate system as shown in Figure 1. Location ④ are in shell coordinate system as shown in Figure 2.



CALCULATION CONTINUATION SHEET

TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201

ID NO. c-31  
 REFERENCE NONE

SHEET 50 OF 106

ORIGINATOR	REP	7				
DATE	6/10/88					
VFR or CCR	BSY					
DATE	6/24/88					

FORCES AND MOMENTS AT LUCA ① Node I1SAP

LOAD TYPE	FORCES (lbs)			MOMENTS (lbs-in.)			REMARKS
	Fx	Fy	Fz	Mx	My	Mz	
DW	-5027	-336	0	0	0	0	
OL	±5128	±1	0	0	0	0	
TD	-385	0	0	0	0	0	
TE1	+436	0	0	0	+4	0	
THAM1	-1463	0	0	0	-1	0	
OBEI	±1951	±83	±132	0	±1	0	
OBED	±149	0	0	0	±1	0	
QAB	±10984	±8589	±1482	±4	±1	0	
QABI *	0	0	0	0	±2	0	(Case C3-2)
	0	0	0	0	±2	0	(Case C3-1)
CHUG	±135692	±983	±6714	±3	±4	0	
CHUGI	0	0	0	0	0	0	
CO	Same as CHUG						
COI	0	0	0	0	±2	0	

\* These values should be multiplied by a non-quercher bay reduction factor of 0.73 per Ref. 26 before using in any further combinations. Case C3-1 is at 2% damping in T.H. while Case C3-2 is at 3% damping.





CALCULATION  
CONTINUATION SHEET

PIPE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201

ID NO. C-31  
REFERENCE NONE

SHEET  
52  
OF  
106

ORIGINATOR	P&P	7					
DATE	6/10/88						
VPR or CCR	ABN						
DATE	6/29/88						

FORCES AND MOMENTS AT LOCATION (2) - I4SA

LOAD TYPE	FORCES (LBS)			MOMENTS (LBS-in.)			REMARKS
	Fx	Fy	Fz	Mx	My	Mz	
DW	-5450	+88	0	0	-6	+6241	
OL	±5128	±1	0	0	±5	±13	
TDB	-385	0	0	0	0	-1	
TEL	+436	0	0	0	+1	+1	
THAM1	-1463	0	0	0	-1	-4	
OBEI	±2016	±41	±55	0	±1749	±1470	
OBED	±149	0	0	0	0	0	
QAB	±9521	±3285	±622	±2	±23215	±117069	
QABI *	±13475	±94	±32	0	±561	±13139	CASE C3.2
	±14053	±100	±32	±1	±522	±14240	CASE C3.1
CHUG	±133588	±102	±345	±13	±68554	±14593	
CHUGI	±2936	±17	±6	0	±453	±3739	
CO	Same	as	CHUG				
COI	±8554	±53	±.24	0	±1639	±9650	

\* SEE NOTE SHT. 50.







CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201

ID NO. C-31  
REFERENCE NONE

SHEET  
54  
of  
106

ORIGINATOR	RMP	7				
DATE	1/10/88					
VFR or COR	ASD					
DATE	6/24/88					

FORCES AND MOMENTS AT LOCATION (3) - I6SAP

LOAD TYPE	FORCES ( <del>lbs</del> )			MOMENTS ( <del>lbs</del> -in.)			REMARKS
	Fx	Fy	Fz	Mx	My	Mz	
DW	-5702	+339	0	0	0	0	
OL	±5128	±1	0	0	0	0	
TD1	-385	0	0	0	+1	0	
TE1	+436	0	0	0	-2	0	
THAM1	-1463	0	0	0	+1	0	
OBEI	±2035	±78	±77	0	0	0	
OBED	±149	0	0	0	0	0	
QAB	±9210	±6012	±1270	±4	0	0	
QABI*	±13967	±710	±94	0	±436	0	CASE C3.2
	±14732	±797	0	±1	±400	0	CASE C3.1
CHUG	±132355	±767	±3379	±4	±1	±0	
CHUGI	±3083	±188	0	0	±31	0	
CO	Same as	CHUG					
COI	±8942	±502	0	0	±213	0	

\* SEE NOTE SH. 50.





CALCULATION CONTINUATION SHEET

TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201

ID NO. C-31  
 REFERENCE NONE

SHEET 56 OF 106

ORIGINATOR	HP	7				
DATE	6/10/88					
VFR or CCR	287					
DATE	6/22/88					

FORCES AND MOMENTS AT LOCA. (4) - I7SAN

LOAD TYPE	FORCES (LBS)			MOMENTS (LBS-in.)			REMARKS
	Fx	Fy	Fz	Mx	My	Mz	
DW	+201	+398	+5752	+2397	+98	-90	
OL	±192	±4	±5125	±15	±6	±1	
TDE	+14	0	+384	-1	+1	0	
TEL	-16	0	-435	+2	-3	-1	
THAM1	+55	+1	+1462	-5	+3	0	
OBEI	±147	±96	±2042	±582	±549	±22	
OBED	±6	0	±149	0	0	0	
QAB	±2071	±8886	±8963	±60525	±16582	±2297	
QABI *	±265	±852	±14081	±5302	±434	±204	CARE C3.2
	±250	±985	±14887	±6119	±398	±231	CARE C3.1
CHUG	±2019	±1021	±131881	±6267	±32039	±274	
CHUGI	±19	±226	±3115	±1339	±31	±53	
CO	Same as CHUG			→			
COI	±133	±612	±9028	±2791	±217	±143	

\* SEE NOTE EXT. 50.





CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201 (C-31)		ID NO. C-31		SHEET 58 OF 106	
ORIGINATOR PHT 7		REFERENCE NONE			
DATE 6/10/88					
VFR or CKR ABN					
DATE 5/22/89					

[STRUT B]

Summary of Internal Strut Reaction Loads  
 penetration P20) Strut<sup>B</sup> attached to Ring Curder




Figure 1 Local Strut Coordinate System




Figure 2 Shell Coordinate System

Loads are provided at the following locations except as noted in the attached tables.

Location ①	Node I15BP
Location ②	Node I6SB
Location ③	Node I8SBP
Location ④	Node I9SBN

Locations ①, ②, & ③ are in local strut coordinate system as shown in Figure 1. Location ④ are in shell coordinate system as shown in Figure 2.



CALCULATION CONTINUATION SHEET

PIPING CODE  
 COMPLIANCE DOCUMENTATION  
 SYSTEM P-20)

U NO. c-31  
 REFERENCE NONE

SHEET 59 OF 106

ORIGINATOR	RAY	7				
DATE	6/10/88					
VFR or CR	1807					
DATE	6/22/88					

FORCES AND MOMENTS AT LOCATION (1) - I1SBP

LOAD TYPE	FORCES (LBS)			MOMENTS (LBS-in.)			REMARKS
	Fx	Fy	Fz	Mx	My	Mz	
DW	-1251	-579	0	+1	0	0	
OL	±1897	±1	0	0	0	0	
TD	+210	0	0	0	0	0	
TEL	-308	0	0	0	+1	0	
THAM1	+978	0	0	0	+1	0	
OBEI	±2392	±186	±182	0	0	0	
OBED	±156	0	0	0	0	0	
QAB	±15316	±14909	±13935	±39	±1	0	
QABI *	±1990	±1041	±770	±1	±1	0	CASE C3.2
	±1814	±1066	±776	±2	0	0	CASE C3.1
CHUG	±140196	±6251	±13206	±10	±1	0	
CHUGI	±418	±428	±219	0	0	0	
CO	Same as CHUG			—————→			
COI	±1240	±1004	±557	±1	±1	0	

\* SEE NOTE SH. 50.





CALCULATION  
CONTINUATION SHEET

PIPE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-20

ID NO. C-31  
REFERENCE NONE

SHEET  
61  
OF  
106

ORIGINATOR	PLP	7				
DATE	6/10/88					
VFR or CKR	DBN					
DATE	6/22/88					

FORCES AND MOMENTS AT LOCA (2) - I 6SB

LOAD TYPE	FORCES (LBS <del>in. lbs</del> )			MOMENTS (LBS <del>in. lbs</del> -in.)			REMARKS
	Fx	Fy	Fz	Mx	My	Mz	
DW	-2172	+343	0	-2	0	+13615	
OL	±1897	0	0	0	±2	±12	
TD	+210	0	0	0	0	+1	
TEL	-308	6	0	0	+1	-2	
THAM1	+978	0	0	0	-1	+6	
OBEI	±2617	±108	±104	0	±3173	±3329	
OBED	±156	0	0	0	0	±1	
QAB	±15097	±9028	±11758	±65	±490331	±343215	
QABI *	±366	±998	±801	±7	±24950	±32862	CASE C3.2
	±366	±934	±630	±5	±20395	±30574	CASE C3.1
CHUG	±134243	±2006	±4390	±18	±133081	±59477	
CHUGI	±80	±309	±193	±1	±6312	±9672	
CO	Same as CHUG →						
COI	±216	±728	±467	±3	±15183	±23321	

\* SEE NOTE SH. 50.







CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201

ID NO. c-31  
REFERENCE NONE

SHEET

63  
OF  
106

ORIGINATOR	RHR	7				
DATE	6/10/88					
VFR or CCR	1871					
DATE	6/22/88					

FORCES AND MOMENTS AT LUCA-③ - IBSBP

LOAD TYPE	FORCES ( <sup>LBS</sup> <del>lbs</del> )			MOMENTS ( <sup>LBS</sup> <del>lbs</del> -in.)			REMARKS
	Fx	Fy	Fz	Mx	My	Mz	
DW	-2424	+594	0	-1	0	0	
OL	±1897	±1	0	0	0	0	
TD	+210	0	0	0	0	0	
TEL	-308	0	0	0	0	0	
THAM1	+978	0	0	0	-1	0	
OBEI	±2649	±135	±124	0	0	0	
OBED	±156	0	0	0	0	0	
QAB	±12585	±19209	+30422	±39	±2	0	
QABI *	±261	±1416	±980	±2	±16	±1	CASE C3.2
	±304	±1347	±906	±2	±16	±1	CASE C3.1
CHUG	±13452	±2169	±5111	±9	±1	0	
CHUGI	±98	±423	±282	0	±2	0	
CO	Same as		CHUG	—————→			
COI	±246	±1006	±675	±1	±8	0	

\* SEE NOTE EXT. 50.





CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-20)

ID NO. C-3)  
REFERENCE NONE

SHEET  
65  
OF  
106

ORIGINATOR  
DATE  
VFR or CIR  
DATE

REP	7				
6/15/88					
ASST					
6/22/88					

FORCES AND MOMENTS AT LOCATION (4) - I95BN

LOAD TYPE	FORCES (LBS)			MOMENTS (LBS-in.)			REMARKS
	Fx	Fy	Fz	Mx	My	Mz	
DW	-1009	+991	+2136	+2530	-2258	+2244	
OL	±1046	±355	±1542	±12	±10	±6	
TD	+116	-39	-171	+1	+1	+1	
TEL	-170	+58	+250	-2	-2	-1	
THAM1	+539	-183	-795	+6	+5	+3	
OBEI	±1517	±541	±2132	±586	±999	±480	
OBED	±86	±29	±127	±1	±1	±1	
QAB	±15690	±33474	±1041	±180256	±87723	±102148	
QABI	±12	±1980	±131	±10085	±20	±6859	CASE C3.2
	±11	±1880	±145	±9624	±20	±6545	CASE C3.1
CHUG	±77828	±28081	±106264	±19194	±30114	±6080	
CHUGI	±1	±579	±27	±3005	±2	±2042	
CO	Same as CHUG						
COI	±7	±1389	±83	±7161	±10	±4867	

\* SEE NOTE SHT. 50.





**CALCULATION  
CONTINUATION SHEET**

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-20)

ID NO. C-3)

REFERENCE NONE

SHEET

67  
OF

106

ORIGINATOR  
DATE  
VFR or CNR  
DATE

021 7  
6-17-88  
BSN  
6/17/88

EQUIPMENT NOZZLE LOADS/EVALUATION

The revised loads for the equipment nozzle are shown on the next 4 pages. The acceptance of these loads (i.e., comparison of these loads with their appropriate allowables) is also documented in the pages that follow the nozzle loads summary sheets. If the revised equipment nozzle loads are higher than the existing nozzle loads, then equipment is listed as external interface on the interface document for this system (file number PSE008.1017).



CALCULATION  
 CONTINUATION SHEET

EQUIPMENT NOZZLE LOAD SUMMARY NODE NO. HP TUB

TITLE PIPING CODE  
 COMPLIANCE DOCUMENTATION  
 SYSTEM P-201 (C-3)

ID NO. C-3  
 REFERENCE NONE


ORIGINATOR DATE  
 VPR OR COR DATE

DATE 12-88  
 DATE 1/13/91

SHEET 68 OF 106

LOAD	LOCAL REACTIONS					
	F <sub>x</sub> Lbs.	F <sub>y</sub> Lbs.	F <sub>z</sub> Lbs.	M <sub>x</sub> in.-Lbs	M <sub>y</sub> in.-Lbs	M <sub>z</sub> in.-Lbs
DW	-14	+35	-64	+3128	-4168	-3939
OBE <sub>I</sub>	±524	±658	±1101	±63222	±28888	±41934
OBE <sub>D</sub>	±34	±14	±33	±2656	±4392	±2576
SSE <sub>I</sub>	±833	±909	±1531	±89616	±38885	±64465
SSE <sub>D</sub>	±37	±23	±36	±4056	±5197	±3773
TD 87D1,8 TD2	0	-8	-7	-268	-259	-191
TE2T	+535	-294	+486	+22288	+28985	-44829
TE	+610	-151	+603	+23835	+44116	-46173
TE1	+610	-152	+602	+23793	+44082	-46192
THAM	-68	-98	-96	-1539	-11901	+2028
THAM1	-61	-89	-87	-1395	-10787	+1838
QAB	0	±15	±22	±1020	±680	±333
*QAB <sub>I</sub>	CASE 3.2 ±375 CASE 3.1 ±269	±160 ±131	±2004 ±1700	±124290 ±105980	±45607 ±37981	±48552 ±18027
CHUG	±1	±28	±39	±1828	±1245	±644
CHUG <sub>I</sub>	±167	±73	±231	±13359	±6074	±11515
CO	±1	±28	±39	±1828	±1245	±644
CO <sub>I</sub>	±531	±285	±870	±50964	±22354	±38950
OL	0	±2	±4	±227	±118	±14
RWPD 1	±1652	±1523	±2131	±111,666	±30244	±75,727

\* THESE VALUES SHOULD BE MULTIPLIED BY A NON-QUENCHER BAY REDUCTION FACTOR  
 = 1.72 FOR BAY 1 REACTOR. VALUES IN ALL OTHER BAYS ARE UNADJUSTED.

 CALCULATION CONTINUATION SHEET	TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-20 / (C-3)		ID NO. C-31		SHEET 69 OF 106
			REFERENCE NONE		
	ORIGINATOR DATE VFR or CKR DATE	021 6-17-88 ASH 11/19/88			

HPCI Turbine Exhaust Nozzle Evaluation

Allowables are as follows (Ref. 12)

- Level A -  $F = (9930 - m) / 3.0$  No Dyn. Loads
- Level B -  $F = (20,000 - m) / 0.8$  Includes Dyn. Loads  
 but  $\leq 11,500 \#$
- Level C/D -  $F = (20,000 - m) / 0.8$  Includes SSE and  
 Rup Dis effects  
 but  $\leq 11,500 \#$

where:

$M = \text{Resultant Moment} = \sqrt{m_x^2 + m_y^2 + m_z^2}$  in FT-lbs  
 $F = \text{Force} = \sqrt{F_x^2 + F_y^2 + F_z^2}$  in lbs.

(A) Evaluation for Rupture Disc Loads From MVIC.H4 pkg  
IDWH/RISPD11


$M = \left[ (184103)^2 + (22120)^2 + (76078)^2 \right]^{1/2} \cdot \frac{1}{12} = 9,629 \text{ FT-lbs}$

$F_{\text{Allow}} = (20,000 - 9629) / 0.8 = 12964 \text{ lbs.} > 11,500$   
 $F_{\text{Allow}} = 11,500$

$F = \left[ (1645)^2 + (1818)^2 + (1593)^2 \right]^{1/2} = 2924 \text{ lbs} < 11,500 \text{ lbs}$

Thus NOZZLE INFEETS ALLOW FOR RUP. DISC  
 Load condition



 <p><b>PSEG</b></p> <p>CALCULATION CONTINUATION SHEET</p>	TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201 (C-3)		ID NO. C-3)		SHEET 70 OF 106
			REFERENCE NONE		
	ORIGINATOR DATE VFR or CKR DATE	[Signature] 6-17-88 AM 11/1/88			

Evaluation for Mark 1 loads

Level A

$$\text{Max. Moment } M = \sqrt{M_x^2 + M_y^2 + M_z^2}$$

$$F = \sqrt{F_x^2 + F_y^2 + F_z^2}$$

USING COMBINATIONS OF

$$DW, |TE + THAM + TD| \text{ OR } |TE| + |THAM| + |TD| \text{ OR } |E2T|$$

and also use individual maximum components.

By using absolute summation of cases; <sup>for forces but signed values</sup> moments, we get -

$$F_x = 14 + 610 + 68 = 692 \text{ lbs}$$

$$F_y = 35 + 294 = 329 \text{ lbs}$$

$$F_z = 64 + 603 + 96 = 763 \text{ lbs}$$

$$F = 1081 \text{ lbs}$$

$$M_x = \frac{1}{12} [3128 + 23835 - 13957] = +2131 \text{ FT-lbs}$$

$$M_y = \frac{1}{12} [-4168 + 44116 - 10787] = +2430 \text{ FT-lbs}$$

$$M = 5161 \text{ lbs}$$

$$M_z = \frac{1}{12} [-3939 + 46192 + 1838] = +4024 \text{ FT-lbs}$$

$$\therefore F_{\text{allow}} = (9930 - 5161) / 3 = 1589 \text{ lbs}$$

$$\therefore F_{\text{actual}} = 1081 < F_{\text{all.}} 1589 \therefore \text{OK}$$



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-20/(C-3/1)

ID NO. C-3/  
REFERENCE NONE

SHEET  
71  
OF  
106

ORIGINATOR	021	7					
DATE	06-17-88						
VFR or CKR	ABN						
DATE	6/17/88						

Mark 1 Loads levels B, C, D Evaluation

Since allowables for levels B, C, D are same, use  
 Max Level D forces/moments using  $[SSEI^2 + SSE_D^2]^{1/2}$

per Ref 15

$$M = \left[ (DW + TE + THAM + TD)^2 + (SSEI)^2 + (SSE_D)^2 + \{0.73(GABE + QAB)\}^2 + (CHUGI + GHUG)^2 + OL \right]^{1/2}$$

$$M = \left[ (114288)^2 + (81278)^2 + (154700)^2 \right]^{1/2}$$

$$= 17400 \text{ FT-LBS}$$

$$F_{allow} = (20,000 - 17400) / 0.8 = 3249 \#$$

but less than 11,500 #

$$F_{actual} = \left[ (1429)^2 + (1142)^2 + (2598)^2 \right]^{1/2} = 3177 \text{ lbs}$$

$\therefore F_{actual} \leq F_{allow}$ ,  $\therefore$  OK

$\therefore$  HPCI Turbine Nozzle is OK



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201

ID NO. c-31  
REFERENCE NONE

SHEET  
72  
OF  
106

ORIGINATOR  
DATE  
VFR or CKR  
DATE

0217  
06-17-88  
ASV  
6/17/88


EXPANSION JOINTS EVALUATION

Documentation of revised displacements at the expansion joints  
and their acceptance is documented on the next ~~4~~ pages.



CALCULATION CONTINUATION SHEET

TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201 (C-31)

ID NO. C-31  
 REFERENCE NONE

SHEET 73 OF 106

ORIGINATOR	021	7					
DATE	6-12-88						
VFR or CCR	0871						
DATE	6/12/88						

EVALUATION OF EXPANSION JOINT

EXPANSION JT. ID: XJQ-7      NODE ID: 95BEL


GOVERNING (4) LOAD COMP. FOR MAX. DISPL.	GLOBAL DISPL. (2)			LOCAL DISPL. (3)					
	DISPL. (in)			ACTUAL (1)			ALLOWABLE (3)		
	X <sub>G</sub>	Y <sub>G</sub>	Z <sub>G</sub>	AXIAL (in)	LATERAL (in)	ROTATION (DEG)	AXIAL (in)	LATERAL (in)	ROTATION (DEG)
Level B	X	Y	Z	0.373	0.531	362	5.2	0.70	5°
Level C				0.385	0.587	341			
Level D*				0.395	0.604	302			

NOTES: 1. GLOBAL TO LOCAL AXIS TRANSFORMATION:

$$\left. \begin{aligned} \text{AXIAL} &= Z \\ \text{LATERAL} &= \sqrt{Y^2 + X^2} \\ \text{ROTATION} &= \end{aligned} \right\} \text{Read from HG pkg. data}$$

- 2. COMPUTER ~~RESULTS/DATE~~ <sup>output per</sup>: HG pkg. (~~REF~~)
- 3. REF. 14(i)
- 4. COMBINATION AS IN REF. 7

\* Values for normal + Max 1 load reported here. Values for rupture disc are lower.  
 Conclusion: Actual displacements ≤ Allowable

 <b>PSEG</b> CALCULATION CONTINUATION SHEET	TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201		ID NO. C-31		SHEET 74 OF 106
	ORIGINATOR DATE 0-17-88 VFR or CIPR DATE 6/14/88		REFERENCE NONE		

## EVALUATION OF EXPANSION JOINT

EXPANSION JT. ID: XJQ.7      NODE ID: 958L  
 DIRECTION COSINE OF SEGMENT      0.0, 0.0, -1.0

GOVERNING (A) LOAD COMB. FOR MAX. ROTATION IN RAD.	GLOBAL (D) ROTATION (RAD)			LOCAL DISPL.				
	$\theta_x$	$\theta_y$	$\theta_z$	ACTUAL (E) $[\theta_x^2 + \theta_y^2 + \theta_z^2]^{1/2}$	ALLOWABLE (F)	AXIAL (G)	LATERAL (H)	ROTATION (I)
DW								5.5
1= TMAX								↓ 5.5 ↓
2= TMAX1								
3= TMAX2								
<del>D3 + MREQD</del>								
4= D1 + MREQD								
5= D3 + OBEI								
** DW + MAX OF 1, 2, 3 + 4 OF 5	0.0022	0.0036	0.0049	0.00647	0.371			

NOTES: 1. GLOBAL TO LOCAL AXIS TRANSFORMATION:

AXIAL = N/A  
 LATERAL = N/A  
 $ROTATION = [\theta_x^2 + \theta_y^2 + \theta_z^2]^{1/2}$

2. COMPUTER RUN ID / DATE : ACQD 6/11/88 (Ref 9)

3. REF. 14(1)

4. COMBINATION AS IN REF. 7

$$D_1 = [Q_{ABI}^2 + C_{HGI}^2 + M_{REQI}^2]^{1/2}$$

$$D_3 = [C_{OI}^2 + OBEI^2]^{1/2}$$

\*\* Using values from rare SLD (Ref 9.d)

\* DEG =  $\frac{180}{\pi} \times RAD (\theta_x, \theta_y \text{ or } \theta_z)$

CONCLUSION:      0.371 ° < 5.5      ∴ OK



CALCULATION CONTINUATION SHEET

TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201 (C-3/1)		ID NO. C-3/	SHEET 75 OF 106
ORIGINATOR <u>021</u> <u>7</u>		REFERENCE NONE	
DATE <u>6-17-88</u>			
VFR or CKR <u>ABJ</u>			
DATE <u>6/17/88</u>			

EVALUATION OF EXPANSION JOINT

EXPANSION JT. ID: X5Q-8      NODE ID: 180BL

GOVERNING (A) LOAD COMP. FOR MAX. DISPL.	GLOBAL (B) DISPL. (in)			LOCAL DISPL.					
	X <sub>G</sub>	Y <sub>G</sub>	Z <sub>G</sub>	ACTUAL (C)			ALLOWABLE (D)		
				AXIAL (in)	LATERAL (in)	ROTATION (DEG)	AXIAL (in)	LATERAL (in)	ROTATION (DEG)
Level B	X	X	X	0.255	0.192		5.2	0.80	5.5
Level C				0.271	0.223		↓	↓	↓
Level D *				0.278	0.227		↓	↓	↓

NOTES: 1. GLOBAL TO LOCAL AXIS TRANSFORMATION:

AXIAL = Z  
 LATERAL =  $\sqrt{X^2 + Y^2}$   
 ROTATION =

- 2. COMPUTER <sup>per</sup> ~~RUN DATE~~ : HLG pkg ~~(8/88)~~
- 3. REF. 14(1)
- 4. COMBINATION AS IN REF. 7

\* Values reported for normal + mod 1 loads. Rupture disc values are lower than these.

∴ Expansion Joint is acceptable.



CALCULATION CONTINUATION SHEET

TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-20)		ID NO. C-31	SHEET 76 OF 106
ORIGINATOR DATE 6-17-88 VPR or CDR DATE 6/17/91		REFERENCE NONE	

EVALUATION OF EXPANSION JOINT

EXPANSION JT. ID: XJQ-78 NOOB ID: 180BL  
 DIRECTION COSINE OF SEGMENT 0.0, 0.0, -1.0

GOVERNING (A) LOAD COMP. FOR MAX. ROTATION IN RAD.	GLOBAL (B) ROTATION (RAD)			LOCAL DISPL.		
	$\theta_x$	$\theta_y$	$\theta_z$	ACTUAL (C) $[\theta_x^2 + \theta_y^2 + \theta_z^2]^{1/2}$	STATION (D)	ALLOWABLE (E) AXIAL (F) LATERAL (G) ROTATION (H)
DW						
1= TMAX						5 ↓
2= TMAX1						
3= TMAX2						
<del>4= D14 MREQD</del>						
5= D14 OBED						
* * DW + $\frac{MREQD}{E} + \frac{OBED}{E}$	0.0003	0.0041	0.0047	0.00624	0.357	

NOTES: 1. GLOBAL TO LOCAL AXIS TRANSFORMATION:

AXIAL = N/A  
 LATERAL = N/A  
 ROTATION =  $[\theta_x^2 + \theta_y^2 + \theta_z^2]^{1/2}$

- 2. COMPUTER RUN NO / DATE : PBA (WD) 6/6/88 (REF 9)
- 3. REF. 14(1)
- 4. COMBINATION AS IN REF. 7

$D_1 = [Q_{OBI}^2 + C_{OGL}^2 + M_{XBOI}^2]^{1/2}$   
 $D_3 = [C_{OI}^2 + OBEI^2]^{1/2}$

} Location is outside 10% zone.

\* \* Core SLD for Ref 9-d  
 \* DEG =  $\frac{180}{\pi} \times \text{RAD} (\theta_x, \theta_y \text{ or } \theta_z)$

CONCLUSION:  $0.357^\circ < 5.5$  ok



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201 (C-31)

ID NO. C-31  
REFERENCE NONE

SHEET  
77  
OF  
106

ORIGINATOR	087	7				
DATE	6-17-88					
VFR or CKR	WGA					
DATE	6/17/01					

VALVE ACCELERATIONS EVALUATIONS

Valve Accelerations and their combinations as per original analysis (Ref. 2) are evaluated by hand calculations. The results are documented on the next 2 pages.





**CALCULATION  
CONTINUATION SHEET**

TITLE Piping Code  
compliance Doc.  
System: P201.

NO. C-31

REFERENCE NONE

SHEET  
78  
OF  
106


ORIGINATOR DAI  
DATE 6-17-88  
VFR or CKR 1087  
DATE 6/17/88


SYSTEM : P201

VALVE ACCELERATION SUMMARY

Valve Tag No.: V006

Node No.: 45CG0



Comb. No.	Load Case/ Combination	Acceleration (g's)(*)			Remarks
		Ax	Ay	Az	
	OBEI	0.714	0.254	0.205	
	SSEI	1.00	0.388	0.350	
	QABI	1.39	0.226	2.796	(4)
	CHUGI	0.441	0.232	1.04	
	COI	1.15	0.53	2.09	
D-1	$\sqrt{SSEI^2 + QABI^2 + CHUGI^2}$	1.768	0.505	3.004	
D-2	$\sqrt{OBEI^2 + COI^2}$	1.354	0.588	2.10	
D-1	Resultant Acceleration	3.52/3.485			PASS
D-2	$\sqrt{Ax^2 + Ay^2 + Az^2} / \sqrt{Ax^2 + Az^2}$	2.57/2.50			PASS
	Allowable Acceleration (1)	6.0/4.5			

- Notes:
- (\*) Accelerations are in global coord.: X=N-S; Y=Vert; Z=E-W
  - (1) Reference: 13i-14i
  - (2) Reference computer run ID: as Ref 9, Dt. \_\_\_\_\_
  - (3) Reference computer run ID: \_\_\_\_\_, Dt. \_\_\_\_\_
  - (4) Includes factor of 0.73 per Ref. 26



**CALCULATION  
 CONTINUATION SHEET**

TITLE Piping Code  
 compliance Doc.  
 System: P201

NO. C-31

REFERENCE NONE

SHEET  
 79  
 OF  
 106

ORIGINATOR 021 7  
 DATE 6-17-89  
 VFR or CKR ASB  
 DATE 6/19/89


SYSTEM : P201

VALVE ACCELERATION SUMMARY

Valve Tag No.: V004

Node No.:

OBEI/SSEI → Max of 55/60 .55  
 OBEI - Max of .54BR, H13



Comb. No.	Load Case/ Combination	Acceleration (g's) (*)			Remarks
		Ax	Ay	Az	
	OBEI	0.328	0.247	0.145	
	SSEI	0.443	0.375	0.297	
	QABI	0.64	0.261	0.558	(4)
	CHUGI	0.119	0.435	0.175	
	COI	0.325	0.268	0.373	
D-1	$\sqrt{SSEI^2 + QABI^2 + CHUGI^2}$	0.787	0.476	0.656	
D-2	$\sqrt{OBEI^2 + COI^2}$	Envelope by D-1			PASS
D-1	Resultant Acceleration	1.13 / 1.025			PASS
D-2	$\sqrt{Ax^2 + Ay^2 + Az^2} / \sqrt{Ax^2 + Az^2}$	Envelope by D-1			
	Allowable Acceleration (1)	6.0 / 4.5			

Notes:

(\*) Accelerations are in global coord.: X=N-S; Y=Vert; Z=E-W

(1) Reference: 13i-14i

(2) Reference computer run ID: as per Ref. 2

(3) Reference computer run ID: \_\_\_\_\_, Dt. \_\_\_\_\_

(4) Includes factor 0.73 per Ref. 26



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201		ID NO. C-31		SHEET 80 OF 106
		REFERENCE NONE		
ORIGINATOR	081 7			
DATE	6-17-88			
VFR or CKR	BSM			
DATE	6/17/88			

FLANGE EVALUATIONS

The flange load combinations for levels A, B, C, & D were evaluated in PISTAR Run of Ref 9.d, and only the resultants  $m_x, m_y, m_z$  are shown on the next 5 pages



CALCULATION  
CONTINUATION SHEET

TITLE Code Compliance  
Documentation.  
System P- 201

ISWG  
C- 31

REFERENCE  
None

SHEET  
81  
OF  
106

ORIGINATOR  
DATE  
VPR or OPR  
DATE

PKP  
6-7-08  
PBN  
6/17/08


FLANGE EVALUATION Free End

FLANGE ID: Blind Flange  
 TYPE: WNRF  
 SIZE (φ): 4 IN.  
 RATING: 150 #  
 NODE ID: 145CP  
 DESIGN TEMP. T<sub>D</sub>: 366 °F  
 DESIGN PRESS. P<sub>D</sub>: 175 PSIG  
 MAX OPERATING  
PRESS. CONCURRENT  
WITH M<sub>fd</sub> } P<sub>fd</sub>: 185 PSIG

FLANGE MATERIAL: SA-105  
 YIELD STRESS @ T<sub>D</sub>, S<sub>y</sub> = 31.17 KSI  
 DIA. OF BOLT CIRCLE, C = 7.5 IN.  
 NO. OF BOLTS 5/8" φ, n = 8  
 ROOT AREA PER BOLT, A = 0.202 IN<sup>2</sup>  
 TOTAL ROOT AREA, n x A = A<sub>b</sub> = 1.616 IN<sup>2</sup>  
 OUTSIDE DIAMETER OF  
RAISED FACE, D<sub>f</sub> = 6.1875 IN.

ALLOWABLE MOMENTS:

SERVICE LEVEL ALLOWABLE MOMENT/PRESSURE  
(CNC-365B.3 OF REF. 8)

A, B  $M_{fs} \leq 3125 \cdot (S_y/36) \cdot C \cdot A_b = \underline{32,793 \text{ in}\cdot\#}$   
 $M_{fd} \leq 6250 \cdot (S_y/36) \cdot C \cdot A_b = 2M_{fs} = \underline{65,586 \text{ in}\cdot\#}$

C, D  $M_{fd} \leq [11250 A_b - (\pi/16) D_f^2 P_{fd}] \cdot C \cdot (S_y/36) = \underline{107,095 \text{ in}\cdot\#}$   
 D  $P_{fd} \leq 2 \cdot P_D = \underline{350 \text{ PSIG}}$

SERVICE LEVEL	GOVERNING LOAD CASE (MAX. COMB. LOAD) (2)	M <sub>x</sub> <sup>(1)</sup> (TORSON) (in #)	M <sub>y</sub> <sup>(1)</sup> (in #)	M <sub>z</sub> <sup>(1)</sup> (in #)	LARGEST OF M <sub>x</sub> + $\sqrt{M_y^2 + M_z^2}$ (in #)	REMARKS
A	STATIC	0	0	0	M <sub>fs</sub> = 0	PASS
B	STATIC + DYN.	0	0	0	M <sub>fd</sub> = 0	PASS
C	STATIC + DYN.	ENVELOPED BY LEVEL D			M <sub>fd</sub>	PASS
D	STATIC + DYN.	0	0	0	M <sub>fd</sub> = 0	PASS

NOTES: (1) COMPUTER RUN ID/ DATE: ALCSD/08/06/06 (Ref. 9)  
 (2) LOAD COMBINATIONS, AS PER REF. 7.



CALCULATOR  
CONTINUATION SHEET

TITLE Code Compliance  
Documentation.  
System P-20

NO. C-31

REFERENCE None

SHEET  
82  
OF  
106

ORIGINATOR R&P 7  
DATE 6-7-88  
VFR or ODR RSM  
DATE 6/17/88

FLANGE EVALUATION Free End

FLANGE ID: STARTUP 10 IN. FLANGE MATERIAL: SA-105  
 TYPE: WN RF (BLIND) YIELD STRESS @  $T_D$ ,  $S_y = 31.17 \text{ KSI}$   
 SIZE ( $\phi$ ): 10 IN. DIA. OF BOLT CIRCLE,  $C = 14.25 \text{ IN.}$   
 RATING: 150 # NO. OF BOLTS  $\frac{7}{\phi}$ ,  $n = 12$   
 NODE ID: 155 ROOT AREA PER BOLT,  $a = 0.419 \text{ IN.}^2$   
 DESIGN TEMP.  $T_D$ : 366 °F TOTAL ROOT AREA,  $n \times a = A_b = 5.028 \text{ IN.}^2$   
 DESIGN PRESS.  $P_D$ : 175 PSIG OUTSIDE DIAMETER OF  
 MAX. OPERATING }  $P_{fd}$ : 185 PSIG. RAISED FACE,  $D_f = 12.75 \text{ IN.}$   
 PRESS. CONCURRENT WITH  $M_{fd}$

ALLOWABLE MOMENTS:

SERVICE LEVEL ALLOWABLE MOMENT/PRESSURE  
(CNC-3658.3 OF REF. 8)

A, B  $M_{fs} \leq 3125 \cdot (S_y/36) \cdot C \cdot A_b = 193,863 \text{ IN}\cdot\#$   
 $M_{fd} \leq 6250 \cdot (S_y/36) \cdot C \cdot A_b = 2 M_{fs} = 387,726 \text{ IN}\cdot\#$

C, D  $M_{fd} \leq [11250 A_b - (\frac{\pi}{16}) D_f^2 P_{fd}] \cdot C \cdot (S_y/36) = 625,049 \text{ IN}\cdot\#$   
 D  $P_{fd} \leq 2 \times P_D = 350 \text{ PSIG}$

SERVICE LEVEL	GOVERNING LOAD CASE (MAX. COMB. LOAD) (2)	$M_x$ (1) (TORSION) (in #)	$M_y$ (1) (in #)	$M_z$ (1) (in #)	LARGEST OF $M_x$ & $\sqrt{M_y^2 + M_z^2}$ (in #)	REMARKS
A	STATIC	0	0	0	$M_{fs} = 0$	PASS
B	STATIC + DYN.	0	0	0	$M_{fd} = 0$	PASS
C	STATIC + DYN.	ENVELOPED BY LEVEL D			$M_{fd}$	PASS
D	STATIC + DYN.	0	0	0	$M_{fd} = 0$	PASS

NOTES: (1) COMPUTER RUN ID/DATE: ACED/88/06/06 (REF. 9)  
 (2) LOAD COMBINATIONS, AS PER REF. 7.



**CALCULATION  
 CONTINUATION SHEET**

**TITLE** Code Compliance  
 Documentation.  
 System P-201

**ISWG.**  
 C-31

**REFERENCE** None

**SHEET**  
 83  
 OF  
 106

**ORIGINATOR** RGP 7  
**DATE** 6-7-88  
**VFR of CKR** [Signature]  
**DATE** 8/13/88

FLANGE EVALUATION

**FLANGE ID:** HPCI Tur. No. 4  
**TYPE:** WNRF  
**SIZE (φ):** 18 IN.  
**RATING:** 150 #  
**NODE ID:** HPTUB.  
**DESIGN TEMP. T<sub>D</sub>:** 366 °F  
**DESIGN PRESS. P<sub>D</sub>:** 175 PSIG  
**MAX OPERATING PRESS. CONCURRENT WITH M<sub>fd</sub>** P<sub>fd</sub>: 185 PSIG.

**FLANGE MATERIAL:** SA-105  
**YIELD STRESS @ T<sub>D</sub>,** S<sub>y</sub> = 31.17 KSI  
**DIA. OF BOLT CIRCLE, C:** 22.75 IN.  
**NO. OF BOLTS 1/8" φ, n:** 16  
**ROOT AREA PER BOLT, a:** 0.693 IN<sup>2</sup>  
**TOTAL ROOT AREA, n × a = A<sub>b</sub>:** 11.09 IN<sup>2</sup>  
**OUTSIDE DIAMETER OF RAISED FACE, D<sub>f</sub>:** 21.0 IN.

ALLOWABLE MOMENTS:

**SERVICE LEVEL** ALLOWABLE MOMENT/PRESSURE (NC-3658.3 OF REF. 8)

A, B  $M_{fs} \leq 3125 \cdot (S_y/36) \cdot C \cdot A_b = 682,649 \text{ IN}\cdot\#$   
 $M_{fd} \leq 6250 \cdot (S_y/36) \cdot C \cdot A_b = 2 M_{fs} = 1,365,298 \text{ IN}\cdot\#$

C, D  $M_{fd} \leq [11250 A_b - (\pi/16) D_f^2 P_{fd}] \cdot C \cdot (S_y/36) = 2,141,994 \text{ IN}\cdot\#$   
 D  $P_{fd} \leq 2 \times P_D = 350 \text{ PSIG}$

SERVICE LEVEL	GOVERNING LOAD CASE (MAX. COMB. LOAD) (2)	M <sub>x</sub> <sup>(1)</sup> (TORSION) (in #)	M <sub>y</sub> <sup>(1)</sup> (in #)	M <sub>z</sub> <sup>(1)</sup> (in #)	LARGEST OF M <sub>x</sub> + $\sqrt{M_y^2 + M_z^2}$ (in #)	REMARKS
A	STATIC	25643	37321	48782	M <sub>fs</sub> = 61421	PASS
B	STATIC + DYN.	104029	70601	93291	M <sub>fd</sub> = 116994	PASS
C	STATIC + DYN.	ENVELOPED BY LEVEL D			M <sub>fd</sub>	PASS
D	MAX OF STATIC + DYN. DW + RUPDI	232864	117810	118861	M <sub>fd</sub> = 232864	PASS

**NOTES:** (1) COMPUTER RUN ID/ DATE: ACQD / 88/06/06 (Ref. 9)  
 ADCE / 88-01-07 (RUP-DISK)  
 (2) LOAD COMBINATIONS, AS PER REF. 7.  
 \* INCLUDING MARK-I LOADS.



CALCULATION CONTINUATION SHEET

TITLE Code Compliance Documentation. System P-201

ISNO

C-31

REFERENCE

None

ORIGINATOR RGP  
 DATE 6-7-88  
 VFR or CKR HSN  
 DATE 11/21/88

7

SHEET 84 OF 106

FLANGE EVALUATION

FLANGE ID: PSECD3  
 TYPE: WN RF  
 SIZE (φ): 16 IN.  
 RATING: 1SD #  
 NODE ID: 160  
 DESIGN TEMP.  $T_D$ : 366 °F  
 DESIGN PRESS.  $P_D$ : 175 PSIG  
 MAX OPERATING PRESS. CONCURRENT WITH  $M_{fd}$  }  $P_{fd}$ : 185 PSIG.

FLANGE MATERIAL: SA-105  
 YIELD STRESS @  $T_D$ ,  $S_y$ : 31.17 KSI  
 DIA. OF BOLT CIRCLE,  $C$ : 21.25 IN.  
 NO. OF BOLTS  $1.0\phi$ ,  $n$ : 16  
 ROOT AREA PER BOLT,  $a$ : 0.531 IN<sup>2</sup>  
 TOTAL ROOT AREA,  $n \times a = A_b$ : 8.816 IN<sup>2</sup>  
 OUTSIDE DIAMETER OF RAISED FACE,  $D_f$ : 18.5 IN.

ALLOWABLE MOMENTS:

SERVICE LEVEL ALLOWABLE MOMENT/PRESSURE (ENC-365B.3 OF REF. 8)

A, B  $M_{fs} \leq 3125 \cdot (S_y/36) \cdot C \cdot A_b = 506,891$  IN\*  
 $M_{fd} \leq 6250 \cdot (S_y/36) \cdot C \cdot A_b = 2 M_{fs} = 1,013,782$  IN\*  
 C, D  $M_{fd} \leq [11250 A_b - (\pi/16) D_f^2 P_{fd}] \cdot C \cdot (S_y/36) = 1,596,071$  IN\*  
 D  $P_{fd} \leq 2 \times P_D = 350$  PSIG

SERVICE LEVEL	GOVERNING LOAD CASE (MAX. COMB. LOAD) (2)	$M_x$ (1) (TORSION) (in #)	$M_y$ (1) (in #)	$M_z$ (1) (in #)	LARGEST OF $M_x$ + $\sqrt{M_y^2 + M_z^2}$ (in #)	REMARKS
A	STATIC	8898	17200	107571	$M_{fs} = 108937$	PASS
B	STATIC + DYN.	31962	108752	147910	$M_{fd} = 163587$	PASS
C	STATIC + DYN.	ENVELOPED BY LEVEL D			$M_{fd}$	PASS
D	MAX OF STATIC + DYN. DW + ROPDI	23,184	33,764	316272	$M_{fd} = 318,069$	PASS

NOTES: (1) COMPUTER RUN ID/ DATE: ACQD / 98/06/06 (Ref. 9)  
 (2) LOAD COMBINATIONS, AS PER REF. 7.  
 \* INCLUDING MARKET LOADS



CALCULATION  
CONTINUATION SHEET

TITLE Code Compliance  
Documentation.  
System P-201

ISSNO. c-31

REFERENCE None

SHEET  
88  
OF  
106

ORIGINATOR  
DATE  
VPR or OKR  
DATE

PhP  
6-7-88  
10871  
6/13/89


FLANGE EVALUATION

FLANGE ID: PSE004  
 TYPE: WIN RF  
 SIZE (φ): 16 IN.  
 RATING: 150 #  
 NODE ID: 165  
 DESIGN TEMP.  $T_D$ : 366 °F  
 DESIGN PRESS.  $P_D$ : 175 PSIG  
 MAX OPERATING  
PRESS. CONCURRENT  
WITH  $M_{fd}$  }  $P_{fd}$ : 185 PSIG.

FLANGE MATERIAL: SA-105  
 YIELD STRESS @  $T_D$ ,  $S_y$ : 31.17 KSI  
 DIA. OF BOLT CIRCLE,  $C$ : 21.25 IN.  
 NO. OF BOLTS  $\frac{1}{2}$ " φ,  $n$ : 16  
 ROOT AREA PER BOLT,  $a$ : 0.55 IN<sup>2</sup>  
 TOTAL ROOT AREA,  $n \times a = A_b$ : 8.816 IN<sup>2</sup>  
 OUTSIDE DIAMETER OF  
RAISED FACE,  $D_f$ : 18.5 IN.

ALLOWABLE MOMENTS:

SERVICE LEVEL ALLOWABLE MOMENT/PRESSURE  
(ENC-365B.3 OF REF. 8)

A, B  $M_{fs} \leq 3125 \cdot (S_y/36) \cdot C \cdot A_b = 506,891$  IN\*  
 $M_{fd} \leq 6250 \cdot (S_y/36) \cdot C \cdot A_b = 2 M_{fs} = 1,013,782$  IN\*  
 C, D  $M_{fd} \leq [11250 A_b - (\pi/16) D_f^2 P_{fd}] \cdot C \cdot (S_y/36) = 1,596,071$  IN\*  
 D  $P_{fd} \leq 2 \times P_D = 350$  PSIG

SERVICE LEVEL	GOVERNING LOAD CASE (MAX. COMB. LOAD) (2)	$M_x$ (1) (TORSON) (in #)	$M_y$ (1) (in #)	$M_z$ (1) (in #)	LARGEST of $M_x$ + $\sqrt{M_y^2 + M_z^2}$ (in #)	REMARKS
A	STATIC	8898	7897	95151	$M_{fs} = 95418$	PASS
B	STATIC + DYN.	31982	60658	127753	$M_{fd} = 141422$	PASS
C	STATIC + DYN.	ENVELOPED BY LEVEL D			$M_{fd}$	PASS
D	MAX OF STATIC + DYN. + WIND + ROAD	23,184	27130	183,759	$M_{fd} = 185,751$	PASS

NOTES: (1) COMPUTER RUN ID/ DATE: ALGD. / 88/06/06 (REF. 9)  
 (2) LOAD COMBINATIONS, AS PER REF. 7. ADCE / 88/06/07 (RID-DISK).  
 \* INCLUDING MARC-I LOADS





CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201(C-31)

ID NO. c-31  
REFERENCE NONE


SHEET  
86  
OF  
106

ORIGINATOR	DST	F					
DATE	6-17-88						
VFR or CKR	MSA						
DATE	6/17/89						

WELDED ATTACHMENT EVALUATIONS

Welded attachment evaluations (i.e., pipe lugs) for 3 supports listed below are evaluated using procedures of Ref. 13. The details are shown on the next 3 pages.

- 1) 1-P-FD-006-119 (S.H.)
- 2) 1-P-FD-006-1106
- 3) 1-P-FD-014-1102

 CALCULATION CONTINUATION SHEET	TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-20)		ID NO. C-31	SHEET 87 OF 106
	ORIGINATOR DATE VFR or CCR DATE		REFERENCE NONE	
	021	7		
	6-17-88			
	NSM			
	6/17/88			

WELDED ATTACHMENT EVALUATION:-

SUPPORT NO. 1-P-FD-006-H19

TYPE: Spring Hanger NUMBER OF LUGS ON  
 ONE SIDE OF CLAMP: N = 4 (1)

NODE NO. H19 UNIT LOCAL STRESS: F = 3.27 ksi (1)

SERVICE LEVEL	LOAD J <sup>(2)</sup> LBS.	LOCAL STRESS(A) = F(J) * 2/N PSI.	MAX. PIPE STRESS(B) PSI.	TOTAL PIPE STRESS = C = A+B PSI.	ALLOWABLE STRESS PSI.
NORMAL UPSET	5378	8793	18,000	26,793	1.5 Sm = 30,000
EMERGENCY	5450	8911	27,500	36,411	2.25 Sm = 45,000
FAULTED	5521	9027	36,000	45,027	3.0 Sm = 60,000
PRIMARY + SECONDARY	5521	(1.4)(9027) 12638	37,500	50,138	3.0 Sm = 60,000

NOTE: (1) REF CALC NO. C-31-6Q AND SCF-31-1Q

(2) NUTECH SUPPORT LOAD OUTPUT

RUN ID. SUPT JSRL DATE: 6/7/88

CONTAINED IN HANGER GUIDANCE PACKAGE,  
C-31-HG, REV NO. 6



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201

ID NO. C-31  
REFERENCE NONE

SHEET  
88  
OF  
106

ORIGINATOR DATE VFR or CKR DATE	021 6-17-88 AM 6/17/88	7					
--	---------------------------------	---	--	--	--	--	--

WELDED ATTACHMENT EVALUATION:-

SUPPORT NO. 1-P-FD-006-H06

TYPE:- STRUT

NUMBER OF LUGS ON

NODE NO. #16

ONE SIDE OF CLAMP: N = 2 <sup>(1)</sup> per lug area

UNIT LOCAL STRESS: F = 5350 psi <sup>(1)</sup> min.  
 (UNIT Load = 8023 lbs) 10,710 psi secm.

SERVICE LEVEL	LOAD J <sup>(2)</sup> LBS.	LOCAL STRESS(A) F(J) * $\frac{2}{N}$ PSI.	MAX. PIPE STRESS(B) PSI.	TOTAL PIPE STRESS = C = A+B. PSI.	ALLOWABLE STRESS PSI.
NORMAL LIPSET	3506 *	2338	18,000	20,338	1.5 Sm. = 30,000
EMERGENCY	4712 †	3142	27,000	30142	2.25 Sm. = 45,000
FAULTED	FF 9624	6418	36,000	42,418	3.0 Sm. = 60,000
PRIMARY + SECONDARY.	4769 * (wire failed)	$(1.4) \left( \frac{10710}{8023} \right) = .6366$	37,500	43,866.	3.0 Sm. = 60,000

NOTE: (1) REF CALC NO. C-31-6Q AND SCF-31-1Q


(2) NUTECH SUPPORT LOAD OUTPUT

\* RUN ID. S1PTJ SRL

DATE: 6/7/88

\*\* CONTAINED IN HANGER GUIDANCE PACKAGE, (Rev. Dis.)

C-31-HG; REV NO. 6

 CALCULATION CONTINUATION SHEET	TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201	ID NO. C-31 REFERENCE NONE	SHEET 89 OF 106
	ORIGINATOR DATE VFR or CKR DATE	021 7 6-12-86 18/11 21/11/0	

WELDED ATTACHMENT EVALUATION:-

SUPPORT NO. 1-P-FD-014-H02

TYPE:- STRUTS      NUMBER OF LUGS ON ONE SIDE OF CLAMP: N = 4 (1)

NODE NO. H2B  
 UNIT LOCAL STRESS: F =  $\frac{2,220}{4340}$  (1) Prim.  
 UNIT = 2500 PSI      , 4340      Secm.

SERVICE LEVEL	LOAD F(J) <sup>(2)</sup> LBS.	LOCAL STRESS(A) F(I) * $\frac{2}{N}$ PSI.	MAX. PIPE STRESS.(B) PSI.	TOTAL PIPE STRESS = C = A+B PSI.	ALLOWABLE STRESS PSI.
NORMAL UPSET	900 *	355	18,000	18,355	1.5 Sm. = 30,000
EMERGENCY	1490 *	662	27,000	27,662	2.25 Sm. = 45,000
FAULTED	23908 **	10,615	36,000	46,615	3.0 Sm. = 60,000
PRIMARY + SECONDARY.	1490 * (unbolted)	(1.4) $\frac{(4340)}{5000}$ = 1811	37,500	39,311	3.0 Sm. = 60,000

NOTE: (1) REF CALC NO. C-31-6Q AND SCF-31-1Q

(2) NUTECH SUPPORT LOAD OUTPUT

\* RUN ID. SUPT JSRL      DATE: 6/7/81  
 \*\* CONTAINED IN HANGER GUIDANCE PACKAGE, 6/7/88 (Ref Inv.)  
 C-31-HG; REV NO. 6



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-20) (C-3)

ID NO. C-31  
REFERENCE NONE

SHEET  
90  
OF  
106

ORIGINATOR DATE VFR or CKR DATE	077 6-17-88 JSM 6/17/88	7					
--	----------------------------------	---	--	--	--	--	--

SBP INTERFACE DATA

The following 10 pages show the revised displacement/acceleration data for the small bore piping connection points. The same pages also show the resolution of these interfaces as noted in the "Remark" column. Any interfaces that require requalification are shown as external interfaces on the interface document for this system (file number PSE005: 1017).

The revised acceleration spectra plots and the digitized values are shown in Attachment III of this calculation.



CALCULATION CONTINUATION SHEET

TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201

NO. C-31  
 REFERENCE NOTE

SHEET 91 OF 106

ORIGINATOR	P6P	7				
DATE	6-8-88					
VFR or CFR	1/87					
DATE	6/17/88					

SBP INTERFACE DATA

LBP SBP system ID: P-204 LBP SBP Iso. No.: 1-P-BC-06 Node ID: 26BR

Item	LOAD CASE	PUA/ABR. (2)			Per current Analysis (1)			REMARKS
		X	Y	Z	X	Y	Z	
Displacements (in.)	DW				0.0013	0.0196	0.0023	This is ..
	TMAX				0.074	0.137	-0.264	separate
	TMAX1				0.072	0.129	-0.245	LBP system
	OBED				0.012	0.030	0.017	see calc #
	SSED				0.031	0.059	0.040	C-80;
	OBEI				0.026	0.011	0.021	for quality
	SSEI				0.032	0.016	0.030	ration
	QAS				0.012	0.006	0.007	
	QABI				0.021	0.014	0.013	
	COI				0.021	0.014	0.013	
Accelerations (g's)	CHUG				0.021	0.014	0.013	
	CHUG1				0.021	0.014	0.013	
	OBEI				0.335	0.506	0.438	
	SSEI				0.501	0.761	0.670	
	QABI							
COI								
CHUG1								

- Notes: 1) See computer run identifications listed in Reference 9 for source of the data.  
 2) See PUA/ABR computer runs of Ref. 2(a)



**CALCULATION  
CONTINUATION SHEET**

PIPE PIPING CODE  
 COMPLIANCE DOCUMENTATION  
 SYSTEM P-201

NO. C-31  
 REFERENCE NONE

SHEET  
92  
 OF  
106

ORIGINATOR DATE VFR or CCR DATE	<u>RKT</u> <u>6/8/88</u> <u>ASST</u> <u>6/17/88</u>	<u>7</u>					
--	--	----------	--	--	--	--	--

SBP INTERFACE DATA

SBP system ID: 3" Weld Cap SBP Iso. No.: N/A Node ID: 27BR

Item	LOAD CASE	PUA/ABR. (2)			Per current Analysis (1)			REMARKS
		X	Y	Z	X	Y	Z	
Displace-ments (in.)	DN							See note 3
	TMAX							
	TMAX1							
	OBEI							
	SSEI							
	OBEI							
	SSEI							
	QAB							
	QABI							
	COI							
CHUG								
CHUGI								
Accele-rations (g's)	OBEI							
	SSEI							
	QABI							
	COI							
	CHUGI							

- Notes: 1) See computer run identifications listed in Reference 9 for source of the data.  
 2) See PUA/ABR computer runs of Ref. 2(a)  
 3) Since this is welded cap connection and connection is qualified by SIF input, no additional data is required to be reported here.



CALCULATION CONTINUATION SHEET

TITLE PIPING CODE  
 COMPLIANCE DOCUMENTATION  
 SYSTEM P-201

REF. C-3)  
 REFERENCE NOTE

SHEET 93 OF 106

ORIGINATOR	RGF	7				
DATE	6-8-88					
VPR or CKR	ASJ					
DATE	6/17/88					

SBP INTERFACE DATA

SBP system ID: 1-P-FD-006-1 SBP Iso. No.: 1-P-FD-211, Rev. 9 Node ID: 54BR  
 (NUTECH (alc. No. 11-2201-3602-01) PUA NODE: MAX OF A1514/55)

Item	LOAD CASE	PUA/ABR. (2)			Per current Analysis (1)			REMARKS
		X	Y	Z	X	Y	Z	
Displacements (in.)	DW	-0.012	-0.017	0	-0.013	-0.005	-0.00	All SPP
	TMAX (3)				0.058	0.116	0.003	displacement
	TMAXI (3)	0.018	0.214	-0.002	0.059	0.113	0.003	are less than
	(PUA OBEI)							or equal to
	OBEI	0.031	0.015	0.022	0.029	0.014	0.022	PUA/ABR
	(PUA SSEI)							Values:
	SSEI	0.069	0.030	0.050	0.065	0.028	0.050	
	(PUA OBEI)							Acceptable
	OBEI	0.032	0.002	0.001	0.040	0.002	0.001	
	(PUA SSEI)							
SSEI	0.318	0.002	0.001	0.049	0.003	0.001		
QAS				0.004	0.001	0.0		
QABI								
CO				0.008	0.002	0.0	Requalification req'd	
COI								
CHUG	0	0	0	0.008	0.002	0.0		
CHUGI								
Accelerations (g's)	(PUA OBEI)	0.739	0.106	0.031	0.328	0.223	0.106	for new
	(PUA SSEI)	0.673	0.158	0.035	0.444	0.341	0.241	Acceptable
	OBEI							CASE C3.2
	OBEI				0.240	0.088	0.048	CASE C3.1
	COI				0.325	0.268	0.097	
CHUGI				0.119	0.136	0.049		

Notes: 1) See computer run identifications listed in Reference 9 for source of the data.

2) See PUA/ABR computer runs of Ref. 2(a)

4) Includes factor 0.73 per Ref. 26 and in or at 3% damping  
 +4) " " " " " " " " 2% damping

3) These are values qualified for per ISO & 1-P-FD-211, Rev. 9.





**CALCULATION  
CONTINUATION SHEET**

PIPE PIPING CODE  
 COMPLIANCE DOCUMENTATION  
 SYSTEM P-201

REV. C-31  
 REFERENCE NONE

SHEET  
 94  
 OF  
 106

ORIGINATOR	PLP	7				
DATE	6-3-88					
VFR or CCR	187					
DATE	6/17/88					

SBP INTERFACE DATA

SBP system ID: PT-N056A SBP Iso. No.: FSK-P1-FD-601 Node ID: 91

[Similitu Cantilever Type I of Ref 21] Rev. 8 PUA NODE HT

Item	LOAD CASE	PUA/ABR. (2)			Per current Analysis (1)			REMARKS
		X	Y	Z	X	Y	Z	
Displace-ments (in.)	DN							NIR
	TMAX							
	TMAX1							
	OBEI							
	SSEI							
	OBEI							
	SSEI							
	QAB							
	OABI							
	COI							
Accelerations (g's)	CHUG							
	CHUGI							
	(PUA/ABR) OBEI	0.243	1.497	0.069	0.497	0.638	0.092	OK
	(PUA/ABR) SSEI	0.325	1.028	0.074	0.678	0.990	0.209	note 3
	OABI *†	NIR			0.23	0.22	0.025	Case C3-2 Case C3-1
COI	NIR			0.259	0.224	0.048		
CHUGI				0.095	0.075	0.021		

Notes: 1) See computer run identifications listed in Reference 9 for source of the data.

2) See PUA/ABR computer runs of Ref. 2(a)

\*, \*†) Same as previous page for node 54BR

3) OABI, CHUGI, COI accelerations shown above are peak of time history response. The accelerations at 10Hz (used to qualify Type I cantilever of Ref 21) from the spectrum in attachment III are lower than Ref 21, line qualified on p. 721. OBE/SSE acceleration although individually high as SBP when combined are marked as values give lower than ref values qualified for Ref 21.



CALCULATION CONTINUATION SHEET

TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201

REF. NO. C-31 REFERENCE NOTE

SHEET 95 OF 106

ORIGINATOR	Pgt	7					
DATE	6/8/88						
VFR or CCR	1887						
DATE	6/17/88						

SBP INTERFACE DATA

(PT-NOS6E) SBP system ID: 006-HBB-1 SBP Iso. No.: FSK-P-1-FD-600 Node ID: 92  
 (Similar to Cantilever Type I of Ref 21) Rev. 6 PUA Node H7

Item	LOAD CASE	PUA/ABR. (2)			Per current Analysis (1)			REMARKS
		X	Y	Z	X	Y	Z	
Displacements (in.)	DW							NIR
	TMAX							
	TMAX1							
	OBEI							
	SSEI							
	QAS							
	QBI							
	COI							
	CHUG							
	CHUGI							
	Accelerations (g's)	(PUA EAPEN) OBEI	0.243	1.497	0.069	0.497	0.791	0.092
(PUA SSEI) SSEI		0.325	1.028	0.074	0.688	0.936	0.209	
QBI * *y		NIR			0.271	0.196	0.024	Case 13.2 Case 13.1
COI		NIR			0.285	0.226	0.047	
CHUGI					0.10	0.08	0.021	

- Notes: 1) See computer run identifications listed in Reference 9 for source of the data.  
 2) See PUA/ABR computer runs of Ref. 2(a)  
 \*, \*y) Same as for node "54 BR" page  
 3) See note 3 of previous page (node 91).





CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201

ID NO. C-31  
REFERENCE NONE

SHEET 97  
OF 106

ORIGINATOR  
DATE  
VPR or CIR  
DATE

RAY 7  
6/18/88  
VPR  
6/18/88

SBP INTERFACE DATA

SBP system ID: 1-P-FD-016-HBB-LSBP Iso. No.: 1-P-FD-234 Rev. 4 Node ID: 145CP  
 (Chart method)

Item	LOAD CASE	PUA/ABR. (2)			Per current Analysis (1)			REMARKS
		X	Y	Z	X	Y	Z	
Displace-ments (in.)	DN	0	0	0	0.0	0.0	0.0	
	THAX	/	/	/	0.002	-0.045	-0.054	OK
	THAX1	/	/	/	0.002	-0.044	-0.051	note 3
	(P/A EXP2) OBEI	0.001	0	0	0.0	0.0	0.0	
	(P/A SFE2) SSEI	0.014	0	0.009	0.015	0.0	0.01	
	(P/A EXP4) OBEI	0.001	0	0	0.001	0.0004	0.0008	
	(P/A SFE5) SSEI	0.002	0	0	0.002	0.001	0.001	
	QAS QABI	X						outside
	CO COI	X						10% zero
	CHUG CHUGI	X						
Accelerations (g's)	(P/A EXP2) OBEI	0.056	0.013	0.021	0.158	0.258	0.120	OK
	(P/A SFE5) SSEI	0.091	0.021	0.033	0.254	0.397	0.265	note 3
	QABI	X						outside
	COI	X						10% zero
	CHUGI	X						

- Notes: 1) See computer run identifications listed in Reference 9 for source of the data.  
 2) See PUA/ABR computer runs of Ref. 2(a)  
 3) Displacements are negligible ( $< 1/16$  in). SRP accelerations although higher than PUA/ABR, they are below ZPA (at 33 Hz) of the input spectra applied in ME602, Table 2



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-20)

ID NO. C-31  
REFERENCE NORZ

SHEET  
98  
OF  
106

ORIGINATOR Plp  
DATE 6/2/88  
VFR or CCR DATE 6/17/88

SBP INTERFACE DATA

SBP system ID: 1-P-FD-018-HB <sup>3/4"</sup> SBP Iso. No.: 1-P-FD-208 Rev 5 Node ID: 145CP

(Chord Method)

Item	LOAD CASE	PUA/ABR. (2)			Per current Analysis (1)			REMARKS
		X	Y	Z	X	Y	Z	
Displace-ments (in.)	DN							
	TMAX							
	TMAX1							
	OBED							
	SSED							
	OBEI							
	SSEI							
	QAS							
	QABI							
	CO							
	COI							
CHUG								
CHUGI								
Accele-rations (g's)	OBEI							
	SSEI							
	QABI							
	COI							
	CHUGI							

Notes: 1) See computer run identifications listed in Reference 9 for source of the data.

2) See PUA/ABR computer runs of Ref. 2(a)

*See data for 1-P-FD-234 for evaluation*



**CALCULATION  
 CONTINUATION SHEET**

**TITLE PIPING CODE  
 COMPLIANCE DOCUMENTATION  
 SYSTEM P-201**

**ID NO. C-3**  
**REFERENCE NONE**

**SHEET  
 99  
 OF  
 106**

<b>ORIGINATOR</b>	PHF	7					
<b>DATE</b>	6/2/88						
<b>WR or CR</b>	ABN						
<b>DATE</b>	6/17/88						

**SBP INTERFACE DATA**

SBP system ID: 1-P-FD-017-HBB-1" SBP Iso. No.: 1-P-FD-207, Rev 5 Node ID: 145CP

*(Chart Method)*

Item	LOAD CASE	PUA/ABR. (2)			Per current Analysis (1)			REMARKS
		X	Y	Z	X	Y	Z	
Displace-ments (in.)	DN	See data for 1-P-FD-234 for evaluation	See data for 1-P-FD-234 for evaluation	See data for 1-P-FD-234 for evaluation	See data for 1-P-FD-234 for evaluation	See data for 1-P-FD-234 for evaluation	See data for 1-P-FD-234 for evaluation	See data for 1-P-FD-234 for evaluation
	TMAX							
	TMAX1							
	OBEI							
	SSEI							
	OBEI							
	SSEI							
	QAS							
	QABI							
	CO							
	COI							
CHUG								
CHUGI								
Accelerations (g's)	OBEI	See data for 1-P-FD-234 for evaluation	See data for 1-P-FD-234 for evaluation	See data for 1-P-FD-234 for evaluation	See data for 1-P-FD-234 for evaluation	See data for 1-P-FD-234 for evaluation	See data for 1-P-FD-234 for evaluation	See data for 1-P-FD-234 for evaluation
	SSEI							
	QABI							
	COI							
	CHUGI							

- Notes: 1) See computer run identifications listed in Reference 9 for source of the data.  
 2) See PUA/ABR computer runs of Ref. 2(a)



**CALCULATION  
 CONTINUATION SHEET**

TITLE PIPING CODE  
 COMPLIANCE DOCUMENTATION  
 SYSTEM P-20)

REF. NO. c-3)  
 REFERENCE NOTE

SHEET  
100  
 OF  
106

ORIGINATOR DATE VPR or CDR DATE	<u>Abp</u> <u>6/8/87</u> <u>ABM</u> <u>6/19/87</u>	<u>7</u>					
--	---	----------	--	--	--	--	--

SBP INTERFACE DATA

SBP system ID: \* SBP Iso. No.: 1-P-FD-201, Rev 5 Node ID: 145CP

*(Chart method)*

Item	LOAD CASE	PUA/ABR. (2).			Per current Analysis <sup>(1)</sup>			REMARKS
		X	Y	Z	X	Y	Z	
Displace-ments (in.)	DN							<i>See 1-P-FD-234 for evaluation data</i>  <i>OK per FD-234</i>
	TMAX							
	TMAX1							
	OBED							
	SSED							
	OBEI							
	SSEI							
	QAS							
	QABI							
	CO COI							
CHUG CHUGI								
Accele-rations (g's)	OBEI							
	SSEI							
	QABI							
	COI							
	CHUGI							

Notes: 1) See computer run identifications listed in Reference 9 for source of the data.

2) See PUA/ABR computer runs of Ref. 2(a)

\*) This isometric contains following SBP lines

- a) 1-P-FD-007-HBB-1" (both going to Barometric Condenser)
- b) 1-P-FD-007-HBB-2" (both going to Barometric Condenser)



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201 (C-31)

ID NO. C-31  
REFERENCE NONE

SHEET  
101  
OF  
106

ORIGINATOR  
DATE  
VFR or CKR  
DATE

021 7  
5/31/88  
HBM  
5/31/88

PIPE SUPPORT LOADS AND EVALUATION

The pipe supports remaining after snubber reduction are qualified for the loads and load combinations listed earlier in this calculation. The details of qualification are available in the calculations listed in the Record Index which is part of this calculation. The load combinations required were performed by postprocess OPTSUPT. The output of OPTSUPT is made part of ~~the~~ <sup>pkg of this</sup> ~~the~~ HG calculation.

CONCLUSIONS

As documented in previous pages of this calculation, the piping system P-201 meets all the applicable criteria of ASME Code (Ref. 6) and the applicable specification (Ref. 13) when modifications listed are implemented. The application of snubber reduction program on this system resulted in removing 8 snubbers, replacing 0 snubbers by rigid struts and leaving 6 snubbers in place. A list of the final status of the original snubbers is provided below.

<u>SNUBBER I.D.</u>	<u>STATUS</u> <sup>(1)</sup>	<u>NODE</u>
1-P-FD-006-H18	S	H18
1-P-FD-006-H22	S	H22
1-P-FD-006-H15 (PAIR)	2S	H15
1-P-FD-006-H10	D	H10
1-P-FD-006-H09	D	H9
1-P-FD-006-H07 (PAIR)	2D	H7
1-P-FD-006-H03	D	H3A
1-P-FD-006-H02	D	H2A
1-P-FD-006-H05 (PAIR)	2D	H5A
1-P-FD-014-H02 (PAIR)	2S	H2B

NOTE: D-Deleted; R-Replaced by Rigid Strut; S-Remain As-is.





**CALCULATION  
CONTINUATION SHEET**

TITLE PIPING CODE  
 COMPLIANCE DOCUMENTATION  
 SYSTEM P-20 (C-3)

ID NO. C-3

REFERENCE NONE

SHEET  
102  
OF  
106

ORIGINATOR	021	7					
DATE	6-10-88						
VFR or CKR	1871						
DATE	6/10/88						

REFERENCES

1. PISTAR input perm file from Tape No. VSN02917, Sym. Name No.A00376, NUTECH File No. PSE005.0050 (System P-20).
2. Piping calculation for system P-201, NUTECH File No. PSE005.1016.
  - a) Calculation No. C-31-60
  - b) Calculation No. SCF-31-10
  - c) Hanger Guidance Issue # 5, Dated 11-26-85
3. As-Built Isometrics, pipe support drawings and piping and pipe support design and qualification calculations. See entries in the Record Index (which is part of this calculation) for the details.
4. "HCGS - Unit 1 OBE and SSE PVRC acceleration response spectra" NUTECH Calculation No. SC-202, Revision 0, File No. PSE005.1001.
5. a. "PISTAR Versions 3.5.<sup>1</sup> Computer Program User's Manual", NUTECH document number TR-76-002, Revisions 12, File No. QASJO.SOFT.2.036.3.5.0.2.
  - b. "OPTSUPT Version 1.0.0 Computer Program User's Manual", NUTECH document number OPT-87-005, Revision 0, File No. QASJO.SOFT.2.136.1.0.0.2.
  - c. "OPTVALV Version 1.0.0 Computer Program User's Manual", NUTECH document number ARD-00-001, Revision 0, File No. QASJO.SOFT.2.137.1.0.0.1.
  - d. "FLANGE Version 1.<sup>2</sup> Computer Program User's Manual", NUTECH document number XCE-28-023, Revision 0, File No. QASJO.SOFT.2.126.1.0.0.2.
6. "Guidelines for Evaluating Support Stiffness changes on Hope Creek Torus Attached Piping Systems", NUTECH document number BPC-01-426, Revision 0, File Number PSE005.1004.
7. "Snubber Reduction Evaluation", NUTECH Technical Instruction PSE-TI-002, Revision 1.
8. ASME B&PV Code, Section III, Div. 1, "Nuclear Power Plant Components (Subsections NA, NC, NF, APPENDICES)," 1977 Edition with Addenda up to and including Summer 1977 Addenda. (This is Code of Existing Qualifying Analysis of Record.) (1979 Summer Addenda for Flange evaluation).



**CALCULATION  
 CONTINUATION SHEET**

TITLE PIPING CODE  
 COMPLIANCE DOCUMENTATION  
 SYSTEM P-201 (C-3)

ID NO. C-3  
 REFERENCE NONE

SHEET  
103  
 OF  
106

ORIGINATOR	<u>DJ</u>	<u>7</u>				
DATE	<u>6-10-88</u>					
VFR or CKR	<u>NSJ</u>					
DATE	<u>6/10/88</u>					

REFERENCES (continued)

9. PISTAR RUNID/Date, NUTECH File No. PSE005. 1016 .
  - a. AAKD/5-16-88 Modal Extraction + Seismic
  - b. ABOA/5-18-88 Normal DN only
  - c. ACBY/5-19-88 All thermal cases
  - d. ACQD/6-6-88 Code Evaluation + Flange loading Comb.
- See last 2 pages of this calculation for additional runs.
10. "Pipe Support Design & Qualification Calculations", NUTECH File No. PSE005. 1015 . The list of calculation numbers and revisions is available in the record index for this system.
11. "Alternative Damping Values for Seismic Analysis of Class 1, 2, and 3 piping sections, Section III, Division 1", ASME B&PV Code Case N-411, Approval Date September 17, 1984.
12. HCGS 1 FSAR Sections 3.1 through 3.10, Amendments 4/84, - File No. PSE005.0046.
13. "Stress Group Procedures for Piping Stress Analysis for the HCGS-1 Job No. 10855, PSEG Company", Bechtel Document, Revision 2 dated September 16, 1985 (including stress bulletins 1 through 25, and Appendixes A through X) NUTECH File No. PSE005.0027.
14. PSEG Specifications (only Number, Revision, and File Number are listed below).
  - a) 10855-P-501(Q), Rev. 23, PSE005.0012.35
  - b) 10855-P-500(Q), Rev. 27, PSE005.0012.36
  - c) 10855-P-516(Q), Rev. 11, PSE005.0012.27
  - d) 10855-P-514(Q), Rev. 0, PSE005.0012.19
  - e) 10855-P-511(Q), Rev. 1, PSE005.0012.18
  - f) 10855-P-515(Q), Rev. 1, PSE005.0012.20
  - g) 10855-M-068(Q), Rev. 6, PSE005.0012.22
  - h) 10855-G-051(Q), Rev. 1, PSE005.0012.01



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201 (C-3/1)

ID NO. C-3/  
REFERENCE NONE

SHEET  
104  
OF  
106

ORIGINATOR DATE VFR or CKR DATE	OST 6-21-88 OST 1/21/06	7					
--	----------------------------------	---	--	--	--	--	--

REFERENCES (Continued)

- i) 10855-P-401(Q), Rev. 8, 11.2201.0501
- j) 10855-P-407(Q), REV. 19-1, 11.2201.0707
- 15. "Nozzle Loads for ~~RHR Heat Exchanger SC-205~~ <sup>HPCI Turbine Exhaust Nozzle</sup>", File No. PSE005.0023.06, Calculation Number SC-105-1, Rev. 1, ~~105-1~~
- 16. "Torus Attached Piping Penetration Analysis", Calculation No. SC-203, Rev. 0, File No. PSE005.1006.
- 17. Mark-I Torus Motion Coupled Analysis Input Tape Information, Rev. 0, File No. PSE005.1007.
- 18. "Torus Internal Supports Analysis TAP Systems P-201, 202, 207, 209, 212A, 212B, 213A, 213B, 217A, 217B, 222 (As-Built)", Calculation File No. XBP006.0323, Revision 0.
- 19. "Torus Internal Strut Loads - Results Summary", Calculation Number 11.2201.3103.03 Revision 0, File Number 11.2201.3103
- 20. "SBP Interface Spectra for QABI, COI, CHUGI for nodes 268R etc., on LBP system P-201, Calculation Number 11.2201.3104.01 Revision 0, File Number 11.2201.3104.
- 21. "Analysis of SBP attached to LBP - Cantilever Lines", Calculation File Number 11.2201.3603, Revision 0..
- 22. "Thermal Modes TAP HCGS-1", Calculation Number SC-206, Rev. 0, File No. PSE005.1003.
- 23. "HPCI Turbine Exhaust - Rupture of Pressure Relief Dick Evaluation", Calculation No. S/10855/D-034, Rev. 1, File No. PSE005.0024.06.
- 24. "Dynamic Analysis for Design of the HPCI Turbine Exhaust line Piping System Inside the Torus due to the Water Clearing Loads at maximum Water Level Height", Calculation Number S/10855/D-067, Rev. 1, File No. PSE005.0024.04.
- 25. "Dynamics of Structures", R.W. Clough, 1976 Edition.
- 26. "SRV Load Attenuation in Non-Quencher Bay", Calculation No. SC-208, Revision 0, File No. PSE005.1501.



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-20/ (C-3/ )

ID NO. C-31  
REFERENCE NONE

SHEET  
105  
OF  
106

ORIGINATOR	UJI	7				
DATE	6-10-88					
VFR or CKR	PSI					
DATE	7-22-88					

Reference 9 (continued)

- e. AALS / 5-16-88 Hydrotest DW only
- f. ADCE / 6-07-88 Rupture Disc Evaluation
- g. ABCQ / 6-03-88 Coupled modes, Psmode, modsup runs for mode 1
- h. ABMM / 6-03-88 Selection of critical freq. TFFABL2 Run (2% T.H. Damp)
- i. ABQM / 6-03-88 SRVHIST Run case C3-2 2% T.H. Damping
- j. ABCP / 6-03-88 " " " C3-1 " " "
- k. ABRG / 6-03-88 TFUNCTION2 Run QABI (C3-2, C3-1, CQI, CHUGI Resp. T.H.; TFPOST Run for same cases. PLSTAR for code evaluation (2% T.H. Damping)
- l. AAGQ / 6-09-88 Mark I Load Accel. (2% T.H. Damping) Response T.H., Peak Values etc (Case C3-2, CQI, CHUGI)
- m. AAQG / 6-09-88 RESGEN/DGTR/PLOTSC Runs for QABI (C3-2) [2% T.H. Damping] Accelerations Resp. Spectra
- n. AAQJ / 6-09-88 Same as above for CQI case
- o. AAQK / 6-09-88 " " m. " CHUGI case
- p. ACWV / 6-15-88 Carrots/CMDXF or Coupling Analysis Run (3% T.H. Damp) MODSUP, W.H. T.H. Responses etc
- q. ADPX / 6-15-88 TFUNCTION1 for 3% T.H. Damping
- r. ADRQ / 6-15-88 TFFABL2 " " " " Selection for case C3-2 SRV only
- s. AEGT / 6-16-88 SRVHIST Run for Case C3-2 - 3% Damping
- t. AESM / 6-17-88 TFUNCTION3, TFPOST, PLSTAR for Case C3-2 - 3% T.H. D.
- u. AEXB / 6-17-88 TFUNCTION2, TFPOST for Case C3-1 QAB Accel. Resp T.H.
- v. AFGZ / 6-17-88 RESGEN/DGTR/PLOTSC for Case C3-1 - 2% T.H. Damping QABI only Accel. Resp Spectra



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201 (C-31)

ID NO. C-31  
REFERENCE NONE

SHEET  
106  
OF  
106

ORIGINATOR	AM	7					
DATE	07/22/88						
VFR or CKR	ASG						
DATE	7/22/88						

Reference 9 (concluded)

- W. AALY/6-20-88 TFUNCTION1, TFUNCTION2, TFPOST runs for QABI (case C3-2 (3% T-H Damping) Accelerations
- X. AARK/6-20-88 RESGEN/DGTZR/PLOTSC Run for above case.
- Y. AECN/07-13-88 TFUNCTION1, TFUNCTION2, TFPOST runs for QABI (case C3-2, CFI, CHUGI (all for 2% T-H Damping) at node P201 only Acceleration runs
- Z. ABAY/07-15-88 RESGEN/DGTZR/PLOTSC Run for QABI (case C3-2 2% T-H Damping at node P201 only Accel-Resp Spectra
- AA. ABAY/07-15-88 Same as Z. above except for CFI case.
- BB. ABBB/07-15-88 " " Z. " " " CHUGI case.

7.201



CALCULATION  
CONTINUATION SHEET

TITLE *Piping Code Compliance  
Documentation System P201*

ID NO. *C-31*  
REFERENCE NONE

SHEET  
*I-1*  
OF  
*68*

ORIGINATOR  
DATE  
VFR or CKR  
DATE

*Val 7*  
*10-10-88*  
*ASN*  
*6/10/89*


ATTACHMENT I

COMPUTER RUN LISTINGS AND TAPE LOG INFORMATION

- 1) Computer Listings (57 Pages)
- 2) Tape Log Information (10 Pages)

```
CJM,P2.
USER(NU134WC,XNUTECH)
CHARGE,F3395JT,*311*XPS080501.
ROUTE(OUTPUT,DEF,DC=FR,FID=CJM40,ID)
SETTL,*.
SETJSL,*.
REWIND,OUTPUT.
*
*****
* RESTART, INPUT, AND OUTPUT+DAYFILE ARE SAVED *
* IN THE FOLLOWING TAPE, IN THAT ORDER. *
*****
COPYBR,INPUT,SYSLN.
REWIND,SYSLN.
GET,APPLIC/UN=LIBRARY.
BEGIN,PISTARR,APPLIC,LEVEL=351,NOTES=N,TSAVE=P201.
*****
* ATTACH PISTAR MODEL IMMEDIATELY BELOW "/EOR", *
* FOLLOWED BY LOAD MODULE-1 *
*****
/*EOR
TITLE HPCI TURBINE EXHAUST (P201)NORMAL LOADS MODEL.
COMMENT THIS MODEL REFLECT AS BUILT CHANGE PER BECHTEL CALC NO.
COMMENT C31-60 INCLUDING LATEST SUPPORT/VALVE DWG'S LINE INDEX.
COMMENT *****
COMMENT FILE: C311ST ✓
COMMENT *****
COMMENT AS BULT CHANGES WITH ALL SNUBBER REMAIN
COMMENT *****
ID CLIENT = PUBLIC SERVICE ELECTRIC AND GAS COMPANY
ID PROJECT NAME = HOPE CREEK SNUBBER REDUCTION
ID PROJECT NUMBER = XPS-08
ID FILE NUMBER = PSE005.1016
ID CALCULATION NO = C-31
ID RUN NO =
ID PREPARED BY = C. J. MEHTA
ID CHECKED BY = A. S. HERLEKAR
COMMENT *****
COMMENT PISTAR GEOMETRY DEFINITION INPUT GROUP
COMMENT *****
COMMENT
GEOMETRY HPCI TURBINE EXHAUST (006-HBB-24",20")(014-HBB-16")
START I1CAP 120.0 750.0 -682.0 70.0 386.4 Y
COMMENT *****
COMMENT REF. DWG. 1-P-FD-01 REV. 19 & PDM DWG. 51
COMMENT *****
CLASS 2
DESIGN I1CAP155 366.0 155.0
DESIGN 160 210 366.0 175.0
COMMENT *****
COMMENT PIPING AND SUPPORT DEFINITION INPUT GROUP
```

COMMENT	*****									
PIPE	I1CAP	I2SPA	0.0	15.21	-15.21				11	1
ADD WEIGHT	I1CAP		105.0	105.0	105.0					
SIF	I1CAP		2.0							
COMMENT	END CAP WEIGHT(FROM TUBE TURNS CATALOG)									
PIPE	I2SPA	I3SPA	0.0	15.21	-15.21				11	1
PIPE	I3SPA	I4SPA	0.0	15.21	-15.21				12	1
PIPE	I4SPA	I5SUP	0.0	8.485	-8.485				10	1
SIF	I5SUP		1.9							
PIPE	I5SUP	I5EA	2.093	-8.485	-8.22				16	1
PIPE	I5EA	I1SAP	1.395	-5.657	-5.48				13	1
STIFFNESS	I1SAP	I1SA2	0.1744	-0.7071	-0.685	DCOSINE				1
MATRIX	1	K11	1.0E8	K22	1.0E8	K33	1.0E8			
MATRIX	1	K44	1.0E3	K55	1.0E3	K66	1.0E2			
PIPE	I1SA2	I2SA	1.395	-5.657	-5.48				13	1
PIPE	I2SA	I3SA	3.122	-12.657	-12.27				14	1
PIPE	I3SA	I4SA	3.122	-12.657	-12.27				14	1
PIPE	I4SA	I5SA	3.663	-14.849	-14.39				15	1
PIPE	I5SA	I6SAP	1.395	-5.657	-5.48				13	1
STIFFNESS	I6SAP	I6SA2	0.1774	-0.7071	-0.685	DCOSINE				1
PIPE	I6SA2	I7SAN	1.134	-4.596	-4.45				13	1
RESTRAINT	I7SAN	TRAN	.9808	0.0	.1951	SPRING			1.0E8	
RESTRAINT	I7SAN	TRAN	-.1379	-0.707	.6935	SPRING			1.0E8	
RESTRAINT	I7SAN	TRAN	.1379	-0.707	-.6935	SPRING			1.0E8	
RESTRAINT	I7SAN	ROT	0.9808	0.0	0.1951	SPRING			1.0E10	
RESTRAINT	I7SAN	ROT	-.1379	-0.707	.6935	SPRING			1.0E10	
RESTRAINT	I7SAN	ROT	.1379	-0.707	-0.6935	SPRING			1.0E10	
SIF	I7SAN		2.1							
PIPE	I5SUP	I5EB	-6.62	-8.49	-5.31				16	1
PIPE	I5EB	I1SBP	-4.41	-5.66	-3.54				13	1
STIFFNESS	I1SBP	I1SB2	-0.5515	-0.7071	-0.442	DCOSINE				1
PIPE	I1SB2	I2SB	-4.41	-5.66	-3.54				13	1
PIPE	I2SB	I3SB	-13.53	-17.35	-10.86				14	1
PIPE	I3SB	I4SB	-11.18	-14.33	-8.97				14	1
PIPE	I4SB	I5SB	-11.18	-14.33	-8.97				14	1
PIPE	I5SB	I6SB	-14.02	-17.97	-11.25				14	1
PIPE	I6SB	I7SB	-11.58	-14.85	-9.29				15	1
PIPE	I7SB	I8SBP	-4.41	-5.66	-3.54				13	1
STIFFNESS	I8SBP	I8SB2	-0.5515	-0.7071	-0.442	DCOSINE				1
PIPE	I8SB2	I9SBN	-3.59	-4.60	-2.87				13	1
RESTRAINT	I9SBN	TRAN	1.0	0.0	0.0	SPRING			1.0E8	
RESTRAINT	I9SBN	TRAN	0.0	-0.707	0.707	SPRING			1.0E8	
RESTRAINT	I9SBN	TRAN	0.0	-0.707	-0.707	SPRING			1.0E8	
RESTRAINT	I9SBN	ROT	1.0	0.0	0.0	SPRING			1.0E10	
RESTRAINT	I9SBN	ROT	0.0	-0.707	0.707	SPRING			1.0E10	
RESTRAINT	I9SBN	ROT	0.0	-0.707	-0.707	SPRING			1.0E10	
SIF	I9SBN		2.1							
PIPE	I5SUP	I6	0.0	6.72	-6.72				10	1
PIPE	I6	I7	0.0	15.21	-15.21				10	1
PIPE	I7	I8	0.0	15.21	-15.21				10	1
PIPE	I8	I9WAT	0.0	15.21	-15.21				10	1



PIPE	I9WATI10	0.0	43.58	-43.58		17	1
ELBOW	I10 INNOZ36.0					17	1
SIF	INNOZ P201	1.9					
PIPE	INNOZP201	0.0	0.0	-28.5		17	1
COMMENT	*****						
COMMENT	P201 STIFFNESSES ARE FOR STIFNED TORUS						
COMMENT	*****						
RESTRAINT	P201 TRAN	1.0	0.0	0.0	SPRING	31.60E6	
RESTRAINT	P201 TRAN	0.0	-0.9848	-0.1736	SPRING	5.120E6	
RESTRAINT	P201 TRAN	0.0	0.1736	-0.9848	SPRING	1.470E6	
RESTRAINT	P201 ROT	1.0	0.0	0.0	SPRING	15.70E6	
RESTRAINT	P201 ROT	0.0	-0.9848	-0.1736	SPRING	15.66E6	
RESTRAINT	P201 ROT	0.0	0.1736	-0.9848	SPRING	2.970E6	
PIPE	P201 EXNOZO.0		0.0	-46.5		17	1
SIF	EXNOZ P201	1.9					
SIF	P201	2.1					
ELBOW	EXNOZ10	36.0				1	1
PIPE	10 12	-55.50	0.69	0.0		1	1
PIPE	12 15	-55.50	0.69	0.0		1	1
ELBOW	15 20	36.0				1	1
REDUCER	20 25	0.0	56.00	0.0		2	1
PIPE	25 26BR	0.0	33.375	0.0		3	1
COMMENT	*****						
COMMENT	26BR IS 3" BRANCH LINE CONT. ON 1-P-BC-06 (P-204)						
COMMENT	*****						
PIPE	26BR 27BR	0.0	20.25	0.0		3	1
PIPE	27BR H19	0.0	12	0.0		3	1
COMMENT	*****						
COMMENT	27BR IS 3" WELD CAP.						
COMMENT	*****						
SIF	27BR	3.6					
SIF	26BR	3.6					
HANGER	H19			4940.0	SPRING	1800.0	
SIF	H19	2.0					
PIPE	H19 30	0.0	43.5	0.0		3	1
ELBOW	30 35	30.0				3	1
PIPE	35 H18	-33.00	0.29975	0.0		3	1
COMMENT	*****						
COMMENT	SNUBBER NO. 1-P-FD-006-H18 AT NODE H18						
COMMENT	SNUBBER IS REMAIN						
COMMENT	*****						
RESTRAINT	H18	0.0	1.0	0.0	SPRING	2.59E5	
PIPE	H18 H17	-5.1875	0.048	0.0		3	1
RESTRAINT	H17	0.0	0.0	1.0	SPRING	1.320E6	
COMMENT	500LBS IS BEING APPLIED AS THE CONCENTRATED WEIGHT.						
COMMENT	FOR THE PSA 35 SNUBBERS AND CLAMPS.REF PSA CATALOG.						
ADD WEIGHT	H18	500.0	500.0	500.0			
PIPE	H17 40	-3.8125	0.055	0.0		3	1
SIF	40	1.9					
VALVE	40 45	-13.999	0.127	0.0		4	1
VALVE	45 VBCG	0.0	16.4	0.0		4	1

ADD WEIGHT	VBCG	2640.0	2640.0	2640.0			
VALVE	VBCG H22	0.0	34.35	0.0		5	1
COMMENT	*****						
COMMENT	SNUBBER NO. 1-P-006-H22 AT NODE H22 (WAS 45CGS)						
COMMENT	SNUBBER IS REMAIN						
COMMENT	*****						
RESTRAINT	H22	0.0	0.0	1.0	SPRING	8.700E4	
ADD WEIGHT	H22	150.0	150.0	150.0			
VALVE	H22 45CG0	0.0	14.25	0.0		5	1
ADD WEIGHT	45CG0	310.0	310.0	310.0			
VALVE	45 50	-13.999	0.127	0.0		4	1
SIF	50	1.9					
PIPE	50 H14	-3.25	0.030	0.0		3	1
PIPE	H14 H15	-5.0	0.020	0.0		3	1
COMMENT	*****						
COMMENT	SNUBBER NO. 1-P-FD-006-H15 AT NODE H15.						
COMMENT	SNUBBER IS REMAIN						
COMMENT	*****						
RESTRAINT	H15	0.0	1.0	0.0	SPRING	4.950E5	
RESTRAINT	H14	0.0	0.0	1.0	SPRING	3.491E6	
ADD WEIGHT	H15	500.0	500.0	500.0			
COMMENT	*****						
COMMENT	1" DIA LINE 1-P-FD-211 @ NODE 54BR						
COMMENT	*****						
PIPE	H15 54BR	-3.25	0.030	0.0		3	1
PIPE	54BR 55	-3.0	0.027			3	1
VALVE	55 60	-38.498	0.350	0.0		6	1
SIF	55	1.9					
SIF	54BR	1.0					
PIPE	60 H13	-6.625	0.060	0.0		3	1
SIF	60	1.9					
RESTRAINT	H13	0.0	1.0	0.0	SPRING	4.8E5	
PIPE	H13 65	-35.375	0.322	0.0		3	1
ELBOW	65 70	30.0				3	1
PIPE	70 H11	0.0	-40.0	0.0		3	1
RESTRAINT	H11	-0.7844	0.0	-0.6202	SPRING	1.750E6	
PIPE	H11 H12	0.0	-16.5	0.0		3	1
RESTRAINT	H12	0.4524	0.0	-0.8918	SPRING	3.066E6	
PIPE	H12 75	0.0	-51.0	0.0		3	1
PIPE	75 H10	0.0	-48.5	0.0		3	1
COMMENT	*****						
COMMENT	SNUBBER NO 1-P-006-H10 AT NODE H10.						
COMMENT	SNUBBER IS DELETED						
COMMENT	*****						
SNUBBER	H10	1.0	0.0	0.0	SPRING	0.00000	
PIPE	H10 H9	0.0	-14.82	0.0		3	1
COMMENT	*****						
COMMENT	SNUBBER NO 1-P-FD-006-H09 AT NODE H9						
COMMENT	SNUBBER IS DELETED						
COMMENT	*****						
SNUBBER	H9	0.2801	0.0	-0.96	SPRING	0.0000	

PIPE	H9	78	0.0	-54.0	0.0		3	1
PIPE	78	80	0.0	-54.0	0.0		3	1
ELBOW	80	85	30.0				3	1
TANGENT	TIP	85	30.00	0.0	0.0			
TANGENT	85	TIP	30.00	0.0	0.0			
ELBOW	85	90	30.0				3	1
COMMENT	*****							
COMMENT	IT IS ASSUMED THAT THE BELLOWS ARE NEXT TO THE WALL							
COMMENT	AND THE WALL IS APPROX 50 IN. FROM ELBOW WELD							
PIPE	90	95	BELO.0	-0.9	-80.0		3	1
SIF	95	BEL	2.0					
COMMENT	*****							
RESTRAINT	95	BELTRAN	0.0	0.0	-1.0	SPRING	310.0	
RESTRAINT	95	BELTRAN	0.0	1.0	0.0	SPRING	1825.0	
RESTRAINT	95	BELTRAN	1.0	0.0	0.0	SPRING	1825.0	
RESTRAINT	95	BELROT	0.0	0.0	-1.0	SPRING	6.67E4	
RESTRAINT	95	BELROT	0.0	1.0	0.0	SPRING	6.67E4	
RESTRAINT	95	BELROT	1.0	0.0	0.0	SPRING	6.67E4	
ADD WEIGHT	95	BEL	135.0	135.0	135.0			
PIPE	95	BELHB	0.0	-0.5	-50.0		3	1
HANGER	H8				2860.0	SPRING	1200.0	
PIPE	H8	91	0.0	-0.233	-21.00		3	1
SIF	91		1.0					
COMMENT	*****							
COMMENT	CONNECTION PT/N056A IS AT NODE 91							
COMMENT	*****							
COMMENT	1" DIA LINE 006-HBB-1" (PTN056E) AT NODE 92							
COMMENT	*****							
PIPE	91	H7	0.0	0.05	-3.5		3	1
COMMENT	*****							
COMMENT	SNUBBER NO. 1-P-FD-006-H07 AT NODE H7							
COMMENT	SNUBBER IS DELETED							
COMMENT	*****							
SNUBBER	H7		1.0	0.0	0.0	SPRING	0.00000	
PIPE	H7	92	0.0	0.094	-8.5		3	1
SIF	92		1.0					
COMMENT	*****							
COMMENT	1" DIA LINE							
COMMENT	*****							
PIPE	92	100T	0.0	-0.503	-36.00		3	1
PIPE	100T	105	0.0	-0.819	-66.875		3	1
PIPE	105	H6	0.0	-0.819	-66.875		3	1
SIF	100T		2.95					
RESTRAINT	H6		0.0	0.0	1.0	SPRING	1.402E6	
SIF	H6		2.0					
PIPE	H6	H5A	0.0	-0.082	-18.25		3	1
COMMENT	*****							
COMMENT	SNUBBER NO. 1-P-FD-006-H05 AT NODE H5A.							
COMMENT	SNUBBER IS DELETED							
COMMENT	*****							
SNUBBER	H5A		1.0	0.0	0.0	SPRING	0.00000	

PIPE	H5A	H4A	0.0	-0.122	-10.750		3	1
RESTRAINT	H4A		0.0	1.0	0.0	SPRING	6.160E5	
PIPE	H4A	110	0.0	-0.408	-36.00		3	1
ELBOW	110	115	30.0				3	1
PIPE	115	120	55.750	-0.578	0.0		3	1
PIPE	120	H3A	82.00	-0.891	0.0		3	1
COMMENT	*****							
COMMENT	SNUBBER NO 1-P-FD-006-H03 AT NODE H3A.							
COMMENT	SNUBBER IS DELETED							
COMMENT	*****							
SNUBBER	H3A		0.0767	0.0	-0.9965	SPRING	0.000000	
PIPE	H3A	125T	18.25	-0.156	0.0		3	1
PIPE	125T	H2A	30.00	-0.312	0.0		3	1
COMMENT	*****							
COMMENT	SNUBBER NO 1-P-FD-006-H02 AT NODE H2A.							
COMMENT	SNUBBER IS DELETED							
COMMENT	*****							
SNUBBER	H2A		0.0	1.0	0.0	SPRING	0.00000	
PIPE	H2A	H1A	6.0	-0.063	0.0		3	1
HANGER	H1A				2158.0	SPRING	900.0	
PIPE	H1A	130	36.00	-0.375	0.0		3	1
ELBOW	130	135	30.0				3	1
PIPE	135	140T	0.0	-77.313	0.0		3	1
PIPE	140T	145CP	0.0	-21.0	0.0		3	1
COMMENT	*****							
COMMENT	SMALL BRANCHES 1IN AND 2IN CLOSE TO NODE 145CP.							
COMMENT	THESE ARE SBP 1-P-FD-201, 207, 208 & 234							
COMMENT	SIF FOR BUTT WELD AT NODE 145CP							
COMMENT	*****							
SIF	145CP		1.8					
ADD WEIGHT	145CP		79.0	79.0	79.0			
COMMENT	*****							
COMMENT	END OF MODEL.007.HBB-1,"AT 4" BLIND FLANGE.							
COMMENT	*****							
PIPE	140T	HPTUB	0.0	0.0	20.75		9	1
SIF	140T		2.95					
COMMENT	HPCI TURBINE							
ADD WEIGHT	HPTUB		306.0	306.0	306.0			
RESTRAINT	HPTUBTRAN	1.0	0.0	0.0	0.0	SPRING	1.0E8	
RESTRAINT	HPTUBTRAN	0.0	1.0	0.0	0.0	SPRING	1.0E8	
RESTRAINT	HPTUBTRAN	0.0	0.0	1.0	0.0	SPRING	1.0E8	
RESTRAINT	HPTUBROT	1.0	0.0	0.0	0.0	SPRING	1.0E12	
RESTRAINT	HPTUBROT	0.0	1.0	0.0	0.0	SPRING	1.0E12	
RESTRAINT	HPTUBROT	0.0	0.0	1.0	0.0	SPRING	1.0E12	
SIF	HPTUB		2.10					
PIPE	125T	155	0.0	0.0	-17.125		8	1
SIF	125T		2.95					
ADD WEIGHT	155		112.0	112.0	112.0			
SIF	155		1.9					
COMMENT	*****							
COMMENT	1-P-FD-014-HBB-16" BR LINE							

COMMENT	*****									
PIPE	100T	160	0.0		14.0		0.0		7	1
SIF	160			1.90						
SIF	165			1.90						
PIPE	160	162	0.0		5.00		0.0		7	1
PIPE	162	163	0.0		11.0		0.0		7	1
COMMENT	*****									
COMMENT	1" VENT TO TORUS COMPARTMENT (SBP 1-P-FD-204)									
COMMENT	*****									
SIF	163			1.0						
PIPE	163	165	0.0		7.0625		0.0		7	1
ADD WEIGHT	160			282.0		282.0		282.0		
ADD WEIGHT	165			282.0		282.0		282.0		
PIPE	165	170	0.0		34.0		0.0		7	1
ELBOW	170	175	24.0						7	1
PIPE	175	H2B	0.0		0.353		34.0		7	1
COMMENT	*****									
COMMENT	SNUBBER NO 1-P-FD-014-HO2 AT NODE H2B.									
COMMENT	SNUBBER IS REMAIN (PAIR)									
COMMENT	*****									
RESTRAINT	H2B		0.0		0.0		1.0		SPRING	2.530E5
SIF	H2B			2.0						
PIPE	H2B	H1B	0.0		0.145		13.999		7	1
RESTRAINT	H1B		1.0		0.0		0.0		SPRING	3.41E6
RESTRAINT	H1B		0.0		1.0		0.0		SPRING	3.41E6
SIF	H1B			2.0						
PIPE	H1B	180BL	0.0		0.501		48.330		7	1
COMMENT	*****									
COMMENT	IT IS ASSUMED THAT THE BELLOWS ARE ABOUT 4FT FROM									
COMMENT	THE SUPPORT H-01 ON 16IN LINE.									
COMMENT	*****									
RESTRAINT	180BLTRAN		0.0		0.0		1.0		SPRING	260.0
RESTRAINT	180BLTRAN		0.0		1.0		0.0		SPRING	1250.0
RESTRAINT	180BLTRAN		1.0		0.0		0.0		SPRING	1250.0
RESTRAINT	180BLROT		0.0		0.0		1.0		SPRING	5.13E4
RESTRAINT	180BLROT		0.0		1.0		0.0		SPRING	5.13E4
RESTRAINT	180BLROT		1.0		0.0		0.0		SPRING	5.13E4
SIF	180BL			2.0						
ADD WEIGHT	180BL		130.0		130.0		130.0			
PIPE	180BL	185	0.0		0.501		48.330		7	1
PIPE	185	H3B	0.0		0.501		48.330		7	1
RESTRAINT	H3B		0.0		1.0		0.0		SPRING	8.34E5
PIPE	H3B	190	0.0		0.37		35.998		7	1
ELBOW	190	195	24.0						7	1
PIPE	195	200	0.0		70.208		0.0		7	1
PIPE	200	205	0.0		46.208		0.0		7	1
PIPE	205	H5B	0.0		46.208		0.0		7	1
PIPE	H5B	H4B	0.0		5.50		0.0		7	1
RESTRAINT	H5B		-0.5210		0.0		-0.8535		SPRING	3.85E5
RESTRAINT	H4B		0.6264		0.0		-0.7795		SPRING	5.16E5
PIPE	H4B	210	0.0		51.500		0.0		7	1

COMMENT END OF MODEL. SEE DWG. 1-P-FD-01 REV.19

COMMENT \*\*\*\*\*

COMMENT HYDROSTATIC LOAD ON INTERNAL SUBMERGED PIPING

COMMENT \*\*\*\*\*

ADD WEIGHTI1CAP	173.5	123.0	123.0
ADD WEIGHTI2SPA	346.9	245.0	245.0
ADD WEIGHTI3SPA	346.9	245.0	245.0
ADD WEIGHTI4SPA	270.0	191.0	191.0
ADD WEIGHTI5SUP	199.0	199.00	199.00
ADD WEIGHTI6	250.0	177.0	177.0
ADD WEIGHTI7	346.9	245.0	245.0
ADD WEIGHTI8	346.9	245.0	245.0
ADD WEIGHTI9WAT	173.5	123.0	123.0

COMMENT \*\*\*\*\*

COMMENT HYDRO LOAD FOR STRUT IS BEING ADDED EQUALLY IN

COMMENT ALL THREE DIRECTIONS BECAUSE IT IS SMALL.(CONSERVATIVE)

COMMENT \*\*\*\*\*

ADD WEIGHTI1SAP	25.9	25.9	25.9
ADD WEIGHTI2SA	41.9	41.9	41.9
ADD WEIGHTI3SA	57.9	57.9	57.9
ADD WEIGHTI4SA	76.7	76.7	76.7
ADD WEIGHTI5SA	60.7	60.7	60.7
ADD WEIGHTI6SAP	23.5	23.5	23.5
ADD WEIGHTI7SAN	10.5	10.5	10.5

COMMENT STRUT TWO

ADD WEIGHTI1SBP	25.9	25.9	25.9
ADD WEIGHTI2SB	52.6	52.6	52.6
ADD WEIGHTI3SB	72.5	72.5	72.5
ADD WEIGHTI4SB	65.6	65.6	65.6
ADD WEIGHTI5SB	73.9	73.9	73.9
ADD WEIGHTI6SB	88.9	88.9	88.9
ADD WEIGHTI7SB	60.7	60.7	60.7
ADD WEIGHTI8SBP	23.5	23.5	23.5
ADD WEIGHTI9SBN	10.5	10.5	10.5

COMMENT \*\*\*\*\*

COMMENT \*\*\*\*\*

COMMENT PROPERTY AND MATERIAL DEFINITION

COMMENT \*\*\*\*\*

PROPERTY 1				24.OSCH20	STEAM	1.60
PROPERTY 2	22.0	0.375	8.1	24X20RED	STEAM	1.48
PROPERTY 3				20.OSCH20	STEAM	1.36
PROPERTY 4	20.75	0.75	00.000	V006BODY	STEAM	1.36
PROPERTY 5	6.70	0.750	0.0	V006 DP		
PROPERTY 6	20.75	0.75	46.75	V004	STEAM	1.36
PROPERTY 7				16.OSCH30	STEAM	1.12
PROPERTY 8				10.OSCH40	STEAM	0.80
PROPERTY 9	18.0	0.375	5.88		STEAM	1.36
PROPERTY 10				24.OSCH80	WATER	
PROPERTY 11	24.0	0.50	10.417		WATER	
PROPERTY 12				24.OSCH40	WATER	
PROPERTY 13				10.OSCH100		

PROPERTY	14				10.OSCH160
PROPERTY	15				12.OSCH140
PROPERTY	16	24.0	1.218	0.0	WTLESS
PROPERTY	17				24.OSCH80 STEAM
MATERIAL	1				CARBON

END GEOM

COMMENT

\*\*\*\*\*

COMMENT

\* LOAD AND CODE EVALUATION MODULE - 1 \*

COMMENT

\*=====\*

COMMENT

\* THIS INCLUDES ALL NON-MARK1 DYNAMIC AND EQUIVALENT \*

COMMENT

\* STATIC LOAD CASES. HENCE ALL ACTIVE SNUBBERS ARE \*

COMMENT

\* CODED AS RIGID RESTRAINTS. \*

COMMENT

\*\*\*\*\*

COMMENT

\*\*\*\*\*

COMMENT

\* SNUBBER REMAIN : 006-H18,H22,H15, \*

COMMENT

\* 014-H02, \*

COMMENT

\*\*\*\*\*

COMMENT

\* SNUBBER CHANGE TO STRUT : NONE \*

COMMENT

\*\*\*\*\*

COMMENT

\* SNUBBER DELETED : 006-H10,H07,H05,H03,H02 \*

COMMENT

\* : 006-H9, \*

COMMENT

\*\*\*\*\*

COMMENT

\*\*\*\*\*

COMMENT

\*\*\*\*\*

COMMENT

\*\*\*\*\*

COMMENT

\* LOAD CASE DEFINITIONS \*

COMMENT

\*=====\*

COMMENT

\* OBED = OPER. BASIS EARTHQUAKE - DISPLACEMENTS \*

COMMENT

\* OBEI = OPER. BASIS EARTHQUAKE - INERTIA \*

COMMENT

\* SSED = SAFE SHUTDOWN EARTHQUAKE - DISPLACEMENTS \*

COMMENT

\* SSEI = SAFE SHUTDOWN EARTHQUAKE - INERTIA \*

COMMENT

\*\*\*\*\*

LOADING

LOAD MODULE-1

CASE

MODAL EXTRACTION

PRINT

NO NO

FREQUENCY

40 33.0

COMMENT

=====

CASE

OBEI OBE - PVRC

COMMENT

\*\*\*\*\*

COMMENT

THE FOLLOWING SETS OF OBE PVRC SPECTRA AT APPLICABLE

COMMENT

ELEVATIONS WILL BE ENVELOPED IN X, Y, AND Z.

COMMENT

\*\*\*\*\*

ENVELOPE

COMMENT

\*\*\*\* X-SPECTRA : N-S DIRECTION \*\*\*\*

SEISMIC

1	386.4	386.4	386.4	CSM	RSS	LOG
---	-------	-------	-------	-----	-----	-----

ZFA

COMMENT

- READ X-SHOCK CARDS BELOW -

COMMENT

\*\*\*\*\*

COMMENT PVRC OBE N-S (SPEC. G51, FIG. F4), SPECTRA # P1  
 COMMENT \*\*\*\*\*

	FREQ	ACCEL	.0100	.0500	.6400	.1300
X-SHOCK	FREQ	ACCEL	1.2000	.2100	2.6000	.2100
X-SHOCK	FREQ	ACCEL	3.0000	.2200	3.3000	.3100
X-SHOCK	FREQ	ACCEL	3.4000	.3700	3.6000	.4000
X-SHOCK	FREQ	ACCEL	3.8000	.4000	3.9000	.7000
X-SHOCK	FREQ	ACCEL	6.4000	.7000	7.0000	.5300
X-SHOCK	FREQ	ACCEL	7.5000	.4000	7.8000	.3000
X-SHOCK	FREQ	ACCEL	8.0000	.2800	8.5000	.2700
X-SHOCK	FREQ	ACCEL	9.0000	.2500	9.9000	.2320
X-SHOCK	FREQ	ACCEL	10.0000	.2300	11.0000	.1830
X-SHOCK	FREQ	ACCEL	12.0000	.1710	13.0000	.1250
X-SHOCK	FREQ	ACCEL	14.0000	.1250	15.0000	.1250
X-SHOCK	FREQ	ACCEL	16.0000	.1250	17.0000	.1250
X-SHOCK	FREQ	ACCEL	18.0000	.1250	19.0000	.1250
X-SHOCK	FREQ	ACCEL	20.0000	.1250	33.0000	.1250

COMMENT SEISMIC 2 386.4 386.4 386.4 CSM RSS  
 COMMENT - READ X-SHOCK CARDS BELOW -

COMMENT PVRC OBE N-S (SPEC. G51, FIG. F10), SPECTRA # P2  
 COMMENT \*\*\*\*\*

	FREQ	ACCEL	.0100	.0500	.5000	.1300
X-SHOCK	FREQ	ACCEL	1.2300	.2300	2.9000	.2300
X-SHOCK	FREQ	ACCEL	3.2000	.2400	3.5000	.4200
X-SHOCK	FREQ	ACCEL	3.8000	.7000	6.4000	.7000
X-SHOCK	FREQ	ACCEL	7.0000	.5500	7.5000	.4000
X-SHOCK	FREQ	ACCEL	7.8000	.3200	8.0000	.3100
X-SHOCK	FREQ	ACCEL	8.5000	.3000	9.0000	.2700
X-SHOCK	FREQ	ACCEL	9.9000	.2430	10.0000	.2400
X-SHOCK	FREQ	ACCEL	11.0000	.2210	12.0000	.2000
X-SHOCK	FREQ	ACCEL	13.0000	.1700	14.0000	.1400
X-SHOCK	FREQ	ACCEL	15.0000	.1400	16.0000	.1400
X-SHOCK	FREQ	ACCEL	17.0000	.1400	18.0000	.1400
X-SHOCK	FREQ	ACCEL	19.0000	.1400	20.0000	.1400
X-SHOCK	FREQ	ACCEL	33.0000	.1400		

COMMENT SEISMIC 3 386.4 386.4 386.4 CSM RSS  
 COMMENT - READ X-SHOCK CARDS BELOW -

COMMENT PVRC OBE N-S (SPEC. G51, FIG. F16), SPECTRA # P3  
 COMMENT \*\*\*\*\*

	FREQ	ACCEL	.0100	.0700	.5000	.1200
X-SHOCK	FREQ	ACCEL	.8200	.1600	1.1700	.2300
X-SHOCK	FREQ	ACCEL	3.1000	.2300	3.4000	.3000
X-SHOCK	FREQ	ACCEL	3.6000	.4000	3.9000	.5400
X-SHOCK	FREQ	ACCEL	6.4000	.5400	7.0000	.4200
X-SHOCK	FREQ	ACCEL	7.5000	.3500	7.8000	.2800
X-SHOCK	FREQ	ACCEL	8.0000	.2700	8.5000	.2500
X-SHOCK	FREQ	ACCEL	9.0000	.2300	9.9000	.2210



X-SHOCK	FREQ	ACCEL	10.0000	.2200	11.0000	.1920
X-SHOCK	FREQ	ACCEL	12.0000	.1720	13.0000	.1430
X-SHOCK	FREQ	ACCEL	14.0000	.1000	15.0000	.1000
X-SHOCK	FREQ	ACCEL	16.0000	.1000	17.0000	.1000
X-SHOCK	FREQ	ACCEL	18.0000	.1000	19.0000	.1000
X-SHOCK	FREQ	ACCEL	20.0000	.1000	33.0000	.1000

COMMENT  
 COMMENT

\*\*\*\*\* Y-SPECTRA : VERT. DIRECTION \*\*\*\*\*

4 386.4 386.4 386.4 CSM RSS  
 - READ Y-SHOCK CARDS BELOW -

\*\*\*\*\*  
 PVRC OBE VERT (SPEC. G51, FIG. G27), SPECTRA # P6

Y-SHOCK	FREQ	ACCEL	.0100	.0400	.5000	.0900
Y-SHOCK	FREQ	ACCEL	1.0000	.1400	2.8000	.2900
Y-SHOCK	FREQ	ACCEL	3.0000	.3500	9.9000	.3500
Y-SHOCK	FREQ	ACCEL	10.0000	.3500	11.0000	.3620
Y-SHOCK	FREQ	ACCEL	12.0000	.3740	13.0000	.4000
Y-SHOCK	FREQ	ACCEL	13.7000	.4291	14.0000	.4560
Y-SHOCK	FREQ	ACCEL	15.0000	.5500	16.0000	.5760
Y-SHOCK	FREQ	ACCEL	17.0000	.6020	18.0000	.6280
Y-SHOCK	FREQ	ACCEL	19.0000	.6540	20.0000	.6800
Y-SHOCK	FREQ	ACCEL	21.0000	.3600	23.0000	.2250
Y-SHOCK	FREQ	ACCEL	28.0000	.2000	33.0000	.1800

COMMENT  
 SEISMIC

5 386.4 386.4 386.4 CSM RSS  
 - READ Y-SHOCK CARDS BELOW -

\*\*\*\*\*  
 PVRC OBE VERT (SPEC. G51, FIG. G26), SPECTRA # P7

Y-SHOCK	FREQ	ACCEL	.0100	.0500	.7000	.1500
Y-SHOCK	FREQ	ACCEL	1.5000	.2800	2.5000	.3700
Y-SHOCK	FREQ	ACCEL	7.0000	.3900	7.5000	.4500
Y-SHOCK	FREQ	ACCEL	8.0000	.5000	8.5000	.5700
Y-SHOCK	FREQ	ACCEL	9.0000	.6300	9.8000	.6900
Y-SHOCK	FREQ	ACCEL	9.9000	.6900	10.0000	.6900
Y-SHOCK	FREQ	ACCEL	11.0000	.7110	12.0000	.7320
Y-SHOCK	FREQ	ACCEL	13.0000	.7530	14.0000	1.0020
Y-SHOCK	FREQ	ACCEL	14.3000	1.0942	14.5000	1.1150
Y-SHOCK	FREQ	ACCEL	15.0000	1.1500	16.0000	1.2200
Y-SHOCK	FREQ	ACCEL	17.0000	1.2900	18.0000	1.3600
Y-SHOCK	FREQ	ACCEL	19.0000	1.4300	20.0000	1.5000
Y-SHOCK	FREQ	ACCEL	21.5000	1.0000	23.5000	.3000
Y-SHOCK	FREQ	ACCEL	24.0000	.2911	28.0000	.2200
Y-SHOCK	FREQ	ACCEL	29.0000	.2200	33.0000	.2200

COMMENT  
 SEISMIC

6 386.4 386.4 386.4 CSM RSS  
 - READ Y-SHOCK CARDS BELOW -

\*\*\*\*\*

COMMENT PVRC OBE VERT (SPEC. G51, FIG. F12), SPECTRA # P8  
 COMMENT \*\*\*\*\*

Y-SHOCK	FREQ	ACCEL	.0100	.0300	.6400	.0900
Y-SHOCK	FREQ	ACCEL	1.4500	.1800	2.0000	.2600
Y-SHOCK	FREQ	ACCEL	2.3000	.3000	2.8000	.3000
Y-SHOCK	FREQ	ACCEL	3.2000	.3600	3.7000	.4200
Y-SHOCK	FREQ	ACCEL	4.2000	.4900	6.6000	.4900
Y-SHOCK	FREQ	ACCEL	7.0000	.4300	7.6000	.3200
Y-SHOCK	FREQ	ACCEL	9.0000	.3200	9.4000	.3000
Y-SHOCK	FREQ	ACCEL	9.9000	.3000	10.0000	.3000
Y-SHOCK	FREQ	ACCEL	11.0000	.3100	12.0000	.2840
Y-SHOCK	FREQ	ACCEL	13.0000	.2490	14.0000	.2460
Y-SHOCK	FREQ	ACCEL	15.0000	.2500	16.0000	.2540
Y-SHOCK	FREQ	ACCEL	17.0000	.2580	17.5000	.2600
Y-SHOCK	FREQ	ACCEL	18.0000	.2500	19.0000	.2270
Y-SHOCK	FREQ	ACCEL	20.0000	.1900	24.5000	.1400
Y-SHOCK	FREQ	ACCEL	33.0000	.1400		

COMMENT SEISMIC 7 386.4 386.4 386.4 CSM RSS  
 COMMENT - READ Y-SHOCK CARDS BELOW -

COMMENT \*\*\*\*\*  
 COMMENT PVRC OBE VERT (SPEC. G51, FIG. G33), SPECTRA # P9  
 COMMENT \*\*\*\*\*

Y-SHOCK	FREQ	ACCEL	.0100	.0300	.5000	.0800
Y-SHOCK	FREQ	ACCEL	1.0000	.1400	2.0000	.2000
Y-SHOCK	FREQ	ACCEL	2.8000	.2700	3.2000	.3700
Y-SHOCK	FREQ	ACCEL	9.9000	.3700	10.0000	.3700
Y-SHOCK	FREQ	ACCEL	11.0000	.3860	12.0000	.4020
Y-SHOCK	FREQ	ACCEL	13.0000	.4180	14.0000	.4340
Y-SHOCK	FREQ	ACCEL	15.0000	.4800	16.0000	.5020
Y-SHOCK	FREQ	ACCEL	17.0000	.5240	18.0000	.5460
Y-SHOCK	FREQ	ACCEL	19.0000	.5680	19.5000	.5790
Y-SHOCK	FREQ	ACCEL	20.0000	.5900	20.1000	.3500
Y-SHOCK	FREQ	ACCEL	21.0000	.3000	24.0000	.2300
Y-SHOCK	FREQ	ACCEL	27.0000	.1600	33.0000	.1500

COMMENT SEISMIC 8 386.4 386.4 386.4 CSM RSS  
 COMMENT - READ Y-SHOCK CARDS BELOW -

COMMENT \*\*\*\*\*  
 COMMENT PVRC OBE VERT (SPEC. G51, FIG. G34), SPECTRA # P10  
 COMMENT \*\*\*\*\*

Y-SHOCK	FREQ	ACCEL	.0100	.0300	.6800	.1000
Y-SHOCK	FREQ	ACCEL	1.0000	.1800	2.0000	.2900
Y-SHOCK	FREQ	ACCEL	3.0000	.3600	4.0000	.4200
Y-SHOCK	FREQ	ACCEL	5.0000	.4500	6.0000	.4800
Y-SHOCK	FREQ	ACCEL	7.0000	.5200	8.0000	.5400
Y-SHOCK	FREQ	ACCEL	9.0000	.5700	9.9000	.5880
Y-SHOCK	FREQ	ACCEL	10.0000	.5900	11.0000	.6370
Y-SHOCK	FREQ	ACCEL	11.5000	.6600	12.0000	.9360
Y-SHOCK	FREQ	ACCEL	13.0000	.9840	14.0000	1.0320
Y-SHOCK	FREQ	ACCEL	15.0000	1.0800	15.1000	1.1766

Y-SHOCK	FREQ	ACCEL	16.0000	1.2360	17.0000	1.3020
Y-SHOCK	FREQ	ACCEL	18.0000	1.3680	19.0000	1.4340
Y-SHOCK	FREQ	ACCEL	20.0000	1.5000	21.0000	.6400
Y-SHOCK	FREQ	ACCEL	23.0000	.5200	26.0000	.3900
Y-SHOCK	FREQ	ACCEL	29.0000	.2700	33.0000	.2600

COMMENT  
 SEISMIC 9 386.4 386.4 386.4 CSM RSS

COMMENT - READ Y-SHOCK CARDS BELOW -

COMMENT \*\*\*\*\*

COMMENT PVRC DBE VERT (SPEC. G51, FIG. F18), SPECTRA # F11

COMMENT \*\*\*\*\*

Y-SHOCK	FREQ	ACCEL	.0100	.0300	.6000	.1000
Y-SHOCK	FREQ	ACCEL	1.1500	.1400	1.6500	.2200
Y-SHOCK	FREQ	ACCEL	3.3000	.3500	3.9000	.3500
Y-SHOCK	FREQ	ACCEL	4.3000	.4900	6.8000	.4900
Y-SHOCK	FREQ	ACCEL	7.6000	.3500	9.9000	.3500
Y-SHOCK	FREQ	ACCEL	10.0000	.3500	11.0000	.3650
Y-SHOCK	FREQ	ACCEL	11.5000	.3513	12.0000	.3300
Y-SHOCK	FREQ	ACCEL	13.0000	.3000	13.5000	.2775
Y-SHOCK	FREQ	ACCEL	14.0000	.2740	15.0000	.2800
Y-SHOCK	FREQ	ACCEL	16.0000	.2860	17.0000	.2920
Y-SHOCK	FREQ	ACCEL	18.0000	.2980	19.0000	.3040
Y-SHOCK	FREQ	ACCEL	19.5000	.3058	20.0000	.2700
Y-SHOCK	FREQ	ACCEL	20.5000	.1900	25.0000	.1500
Y-SHOCK	FREQ	ACCEL	33.0000	.1500		

COMMENT  
 SEISMIC 10 386.4 386.4 386.4 CSM RSS

COMMENT - READ Y-SHOCK CARDS BELOW -

COMMENT \*\*\*\*\*

COMMENT PVRC DBE VERT (SPEC. G51, FIG. F6), SPECTRA # P12

COMMENT \*\*\*\*\*

Y-SHOCK	FREQ	ACCEL	.0100	.0300	.3500	.0600
Y-SHOCK	FREQ	ACCEL	1.0000	.1400	1.6000	.2300
Y-SHOCK	FREQ	ACCEL	2.2000	.2800	2.7000	.3200
Y-SHOCK	FREQ	ACCEL	3.1000	.3400	4.3000	.4900
Y-SHOCK	FREQ	ACCEL	7.0000	.4900	7.5000	.3900
Y-SHOCK	FREQ	ACCEL	8.0000	.3000	9.9000	.3000
Y-SHOCK	FREQ	ACCEL	10.0000	.3000	11.0000	.2760
Y-SHOCK	FREQ	ACCEL	12.0000	.2580	12.5000	.2475
Y-SHOCK	FREQ	ACCEL	13.0000	.2420	14.0000	.2460
Y-SHOCK	FREQ	ACCEL	15.0000	.2500	16.0000	.2540
Y-SHOCK	FREQ	ACCEL	17.0000	.2580	17.5000	.2600
Y-SHOCK	FREQ	ACCEL	18.0000	.2580	19.0000	.2260
Y-SHOCK	FREQ	ACCEL	20.0000	.1900	20.5000	.1500
Y-SHOCK	FREQ	ACCEL	23.0000	.1300	33.0000	.1300

COMMENT  
 COMMENT ADD MORE SHOCK CARDS IF NEEDED FOR ADDITIONAL ELEVATIONS

COMMENT -----

COMMENT \*\*\*\*\* Z-SPECTRA : E-W DIRECTION \*\*\*\*\*

SEISMIC 11 386.4 386.4 386.4 CSM RSS

COMMENT - READ Z-SHOCK CARDS BELOW -  
 COMMENT \*\*\*\*\*  
 COMMENT PVRC OBE E-W (SPEC. G51, FIG. F5), SPECTRA # P16  
 COMMENT \*\*\*\*\*  
 Z-SHOCK FREQ ACCEL .0100 .0500 .4200 .0900  
 Z-SHOCK FREQ ACCEL .6200 .1300 1.0600 .1400  
 Z-SHOCK FREQ ACCEL 1.6000 .2000 2.2000 .2850  
 Z-SHOCK FREQ ACCEL 3.2000 .2850 3.3000 .3000  
 Z-SHOCK FREQ ACCEL 3.4000 .3300 3.7000 .3400  
 Z-SHOCK FREQ ACCEL 4.4000 .3400 4.5000 .4000  
 Z-SHOCK FREQ ACCEL 7.8000 .4000 8.3000 .3300  
 Z-SHOCK FREQ ACCEL 8.8000 .2700 9.4000 .2000  
 Z-SHOCK FREQ ACCEL 9.9000 .1917 10.0000 .1900  
 Z-SHOCK FREQ ACCEL 11.0000 .1660 11.5000 .1458  
 Z-SHOCK FREQ ACCEL 12.0000 .1320 13.0000 .1230  
 Z-SHOCK FREQ ACCEL 14.0000 .1170 15.0000 .1100  
 Z-SHOCK FREQ ACCEL 16.0000 .1050 17.0000 .1000  
 Z-SHOCK FREQ ACCEL 18.0000 .1000 19.0000 .1000  
 Z-SHOCK FREQ ACCEL 20.0000 .1000 33.0000 .1000

SEISMIC 12 386.4 386.4 386.4 CSM RSS

COMMENT - READ Z-SHOCK CARDS BELOW -  
 COMMENT \*\*\*\*\*  
 COMMENT PVRC OBE E-W (SPEC. G51, FIG. F11), SPECTRA # P17  
 COMMENT \*\*\*\*\*  
 Z-SHOCK FREQ ACCEL .0100 .0500 .3800 .0700  
 Z-SHOCK FREQ ACCEL .6200 .1400 .7000 .1500  
 Z-SHOCK FREQ ACCEL 1.0000 .1750 1.2000 .1800  
 Z-SHOCK FREQ ACCEL 1.7000 .2700 2.1000 .3000  
 Z-SHOCK FREQ ACCEL 2.6000 .3400 3.1000 .3700  
 Z-SHOCK FREQ ACCEL 4.5000 .3700 4.6000 .3900  
 Z-SHOCK FREQ ACCEL 7.6000 .3900 8.6000 .2700  
 Z-SHOCK FREQ ACCEL 9.0000 .2500 9.9000 .2230  
 Z-SHOCK FREQ ACCEL 10.0000 .2200 10.5000 .1958  
 Z-SHOCK FREQ ACCEL 10.7000 .1921 11.0000 .1825  
 Z-SHOCK FREQ ACCEL 12.0000 .1320 13.0000 .1265  
 Z-SHOCK FREQ ACCEL 14.0000 .1200 15.0000 .1000  
 Z-SHOCK FREQ ACCEL 15.5000 .0800 16.0000 .0800  
 Z-SHOCK FREQ ACCEL 17.0000 .0800 18.0000 .0800  
 Z-SHOCK FREQ ACCEL 19.0000 .0800 20.0000 .0800  
 Z-SHOCK FREQ ACCEL 33.0000 .0800

SEISMIC 13 386.4 386.4 386.4 CSM RSS

COMMENT - READ Z-SHOCK CARDS BELOW -  
 COMMENT \*\*\*\*\*  
 COMMENT PVRC OBE E-W (SPEC. G51, FIG. F17), SPECTRA # P18  
 COMMENT \*\*\*\*\*  
 Z-SHOCK FREQ ACCEL .0100 .0400 .4000 .0800  
 Z-SHOCK FREQ ACCEL .6000 .1400 1.5500 .2300  
 Z-SHOCK FREQ ACCEL 1.8000 .2700 2.2000 .3200  
 Z-SHOCK FREQ ACCEL 2.9000 .3200 3.1000 .3700

Z-SHOCK	FREQ	ACCEL	3.3500	.5000	5.6000	.5000
Z-SHOCK	FREQ	ACCEL	5.9000	.3600	7.1000	.3600
Z-SHOCK	FREQ	ACCEL	7.6000	.2800	8.0000	.2700
Z-SHOCK	FREQ	ACCEL	9.9000	.2700	10.0000	.2700
Z-SHOCK	FREQ	ACCEL	10.4000	.2760	11.0000	.2190
Z-SHOCK	FREQ	ACCEL	12.0000	.1300	13.0000	.1250
Z-SHOCK	FREQ	ACCEL	14.0000	.1200	15.0000	.1150
Z-SHOCK	FREQ	ACCEL	16.0000	.1100	17.0000	.1000
Z-SHOCK	FREQ	ACCEL	18.0000	.0900	19.0000	.0850
Z-SHOCK	FREQ	ACCEL	20.0000	.0800	33.0000	.0800

COMMENT

COMMENT

CASE

=====

SSEI            SSE - PVRC

COMMENT

\*\*\*\*\*

COMMENT

THE FOLLOWING SETS OF SSE PVRC SPECTRA AT APPLICABLE

COMMENT

ELEVATIONS WILL BE ENVELOPED IN X, Y, AND Z.

COMMENT

\*\*\*\*\*

ENVELOPE

COMMENT

\*\*\*\* X-SPECTRA : N-S DIRECTION \*\*\*\*

SEISMIC

1            386.4            386.4            386.4            CSM            RSS            LOG

ZFA

COMMENT

- READ X-SHOCK CARDS BELOW -

COMMENT

\*\*\*\*\*

COMMENT

PVRC SSE N-S (SPEC. G51, FIG. F1), SPECTRA # P21

COMMENT

\*\*\*\*\*

X-SHOCK

FREQ	ACCEL	.0100	.1000	.8400	.3000	
X-SHOCK	FREQ	ACCEL	1.0600	.3700	1.8000	.3700
X-SHOCK	FREQ	ACCEL	2.2000	.5700	2.6000	.7200
X-SHOCK	FREQ	ACCEL	2.7000	.8400	4.8000	.8400
X-SHOCK	FREQ	ACCEL	5.2000	.8000	5.6000	.4900
X-SHOCK	FREQ	ACCEL	6.3000	.4000	7.0000	.3000
X-SHOCK	FREQ	ACCEL	7.5000	.2900	8.0000	.2850
X-SHOCK	FREQ	ACCEL	8.5000	.2800	9.0000	.2750
X-SHOCK	FREQ	ACCEL	9.5000	.2700	9.9000	.2740
X-SHOCK	FREQ	ACCEL	10.0000	.2750	11.0000	.2615
X-SHOCK	FREQ	ACCEL	12.0000	.2500	13.0000	.2400
X-SHOCK	FREQ	ACCEL	14.0000	.2300	15.0000	.2250
X-SHOCK	FREQ	ACCEL	16.0000	.2250	17.0000	.2250
X-SHOCK	FREQ	ACCEL	18.0000	.2250	19.0000	.2250
X-SHOCK	FREQ	ACCEL	20.0000	.2250	33.0000	.2250

X-SHOCK

X-SHOCK

X-SHOCK

X-SHOCK

X-SHOCK

X-SHOCK

X-SHOCK

X-SHOCK

X-SHOCK

X-SHOCK

X-SHOCK

X-SHOCK

X-SHOCK

X-SHOCK

X-SHOCK

COMMENT

SEISMIC

2            386.4            386.4            386.4            CSM            RSS

COMMENT

- READ X-SHOCK CARDS BELOW -

COMMENT

\*\*\*\*\*

COMMENT

PVRC SSE N-S (SPEC. G51, FIG. F7), SPECTRA # P22

COMMENT

\*\*\*\*\*

X-SHOCK

FREQ	ACCEL	.0100	.1100	.8000	.3200	
X-SHOCK	FREQ	ACCEL	1.0700	.3800	1.7000	.3800
X-SHOCK	FREQ	ACCEL	1.8000	.4000	2.2000	.5500
X-SHOCK	FREQ	ACCEL	2.6000	.6700	2.8000	.7400
X-SHOCK	FREQ	ACCEL	4.8000	.7400	5.4000	.6900

X-SHOCK

X-SHOCK

X-SHOCK

X-SHOCK

X-SHOCK

X-SHOCK	FREQ	ACCEL	5.6000	.4400	6.0000	.4000
X-SHOCK	FREQ	ACCEL	6.6000	.3500	7.2000	.2900
X-SHOCK	FREQ	ACCEL	9.9000	.2707	10.0000	.2700
X-SHOCK	FREQ	ACCEL	11.0000	.2610	12.0000	.2520
X-SHOCK	FREQ	ACCEL	13.0000	.2465	14.0000	.2400
X-SHOCK	FREQ	ACCEL	15.0000	.2300	16.0000	.2250
X-SHOCK	FREQ	ACCEL	17.0000	.2200	18.0000	.2100
X-SHOCK	FREQ	ACCEL	19.0000	.2000	20.0000	.2000
X-SHOCK	FREQ	ACCEL	33.0000	.2000		

COMMENT

SEISMIC 3 386.4 386.4 386.4 CSM RSS

COMMENT - READ X-SHOCK CARDS BELOW -

COMMENT \*\*\*\*\*

COMMENT PVRC SSE N-S (SPEC. G51, FIG. F13), SPECTRA # P23

COMMENT \*\*\*\*\*

X-SHOCK	FREQ	ACCEL	.0100	.1200	.8600	.3500
X-SHOCK	FREQ	ACCEL	1.0700	.4200	1.7000	.4200
X-SHOCK	FREQ	ACCEL	1.7500	.4300	2.1000	.5500
X-SHOCK	FREQ	ACCEL	2.4500	.6600	2.5000	.7200
X-SHOCK	FREQ	ACCEL	4.4000	.7200	4.6000	.7100
X-SHOCK	FREQ	ACCEL	5.0000	.6300	5.5000	.5500
X-SHOCK	FREQ	ACCEL	6.0000	.4300	6.5000	.3500
X-SHOCK	FREQ	ACCEL	6.8000	.3000	8.5000	.2700
X-SHOCK	FREQ	ACCEL	9.9000	.2513	10.0000	.2500
X-SHOCK	FREQ	ACCEL	10.5000	.2498	11.0000	.2480
X-SHOCK	FREQ	ACCEL	12.0000	.2440	13.0000	.2400
X-SHOCK	FREQ	ACCEL	14.0000	.2320	15.0000	.2175
X-SHOCK	FREQ	ACCEL	16.0000	.2000	17.0000	.2000
X-SHOCK	FREQ	ACCEL	18.0000	.2000	19.0000	.2000
X-SHOCK	FREQ	ACCEL	20.0000	.2000	33.0000	.2000

COMMENT

COMMENT

COMMENT

COMMENT \*\*\*\*\* Y-SPECTRA : VERT. DIRECTION \*\*\*\*\*

SEISMIC 4 386.4 386.4 386.4 CSM RSS

COMMENT - READ Y-SHOCK CARDS BELOW -

COMMENT \*\*\*\*\*

COMMENT PVRC SSE VERT (SPEC. G51, FIG. F9), SPECTRA # P26

COMMENT \*\*\*\*\*

Y-SHOCK	FREQ	ACCEL	.0100	.0700	.4500	.1300
Y-SHOCK	FREQ	ACCEL	1.1000	.3000	1.6000	.4300
Y-SHOCK	FREQ	ACCEL	1.6500	.4900	2.1000	.5800
Y-SHOCK	FREQ	ACCEL	2.4000	.6100	3.0000	.7000
Y-SHOCK	FREQ	ACCEL	4.0000	.7000	4.3000	1.0300
Y-SHOCK	FREQ	ACCEL	5.6000	1.0300	6.6000	.7000
Y-SHOCK	FREQ	ACCEL	9.9000	.7000	10.0000	.7000
Y-SHOCK	FREQ	ACCEL	11.0000	.7250	12.0000	.6480
Y-SHOCK	FREQ	ACCEL	13.0000	.5590	14.0000	.4900
Y-SHOCK	FREQ	ACCEL	14.5000	.4615	15.0000	.4450
Y-SHOCK	FREQ	ACCEL	16.0000	.4320	17.0000	.4190
Y-SHOCK	FREQ	ACCEL	18.0000	.4120	19.0000	.4040

Y-SHOCK	FREQ	ACCEL	20.0000	.3500	22.0000	.2500
Y-SHOCK	FREQ	ACCEL	23.0000	.2300	26.0000	.2000
Y-SHOCK	FREQ	ACCEL	33.0000	.2000		

COMMENT SEISMIC 5 386.4 386.4 386.4 CSM RSS

COMMENT - READ Y-SHOCK CARDS BELOW -

COMMENT \*\*\*\*\*

COMMENT PVRC SSE VERT (SPEC. G51, FIG. G23), SPECTRA # P27

COMMENT \*\*\*\*\*

Y-SHOCK	FREQ	ACCEL	.0100	.1000	.9400	.2400
Y-SHOCK	FREQ	ACCEL	3.1000	.7200	6.0000	.7200
Y-SHOCK	FREQ	ACCEL	7.8000	.7800	9.9000	.7800
Y-SHOCK	FREQ	ACCEL	10.0000	.7800	11.0000	.8150
Y-SHOCK	FREQ	ACCEL	11.7000	.8395	12.0000	.8660
Y-SHOCK	FREQ	ACCEL	13.0000	.9700	13.5000	1.0173
Y-SHOCK	FREQ	ACCEL	14.0000	1.0390	15.0000	1.0825
Y-SHOCK	FREQ	ACCEL	16.0000	1.1260	17.0000	1.1695
Y-SHOCK	FREQ	ACCEL	18.0000	1.2130	19.0000	1.2565
Y-SHOCK	FREQ	ACCEL	20.0000	1.3000	20.5000	1.3000
Y-SHOCK	FREQ	ACCEL	22.0000	1.0000	24.0000	.7500
Y-SHOCK	FREQ	ACCEL	26.0000	.4200	29.0000	.4000
Y-SHOCK	FREQ	ACCEL	32.0000	.3500	33.0000	.3700

COMMENT SEISMIC 6 386.4 386.4 386.4 CSM RSS

COMMENT - READ Y-SHOCK CARDS BELOW -

COMMENT \*\*\*\*\*

COMMENT PVRC SSE VERT (SPEC. G51, FIG. G24), SPECTRA # P28

COMMENT \*\*\*\*\*

Y-SHOCK	FREQ	ACCEL	.0100	.0700	.8600	.2300
Y-SHOCK	FREQ	ACCEL	1.6000	.4500	2.0000	.5200
Y-SHOCK	FREQ	ACCEL	2.4000	.6000	2.8000	.6600
Y-SHOCK	FREQ	ACCEL	3.1000	.7000	3.4000	.7400
Y-SHOCK	FREQ	ACCEL	9.9000	.7400	10.0000	.7400
Y-SHOCK	FREQ	ACCEL	11.0000	.7700	11.5000	.7850
Y-SHOCK	FREQ	ACCEL	11.7000	.7844	12.0000	.7800
Y-SHOCK	FREQ	ACCEL	13.0000	.7750	14.0000	.7560
Y-SHOCK	FREQ	ACCEL	15.0000	.7750	16.0000	.7940
Y-SHOCK	FREQ	ACCEL	17.0000	.8130	18.0000	.8320
Y-SHOCK	FREQ	ACCEL	18.5000	.8415	19.0000	.8500
Y-SHOCK	FREQ	ACCEL	20.0000	.8700	22.0000	.6450
Y-SHOCK	FREQ	ACCEL	24.0000	.4200	26.0000	.3000
Y-SHOCK	FREQ	ACCEL	29.0000	.2950	32.0000	.2900
Y-SHOCK	FREQ	ACCEL	33.0000	.2850		

COMMENT SEISMIC 7 386.4 386.4 386.4 CSM RSS

COMMENT - READ Y-SHOCK CARDS BELOW -

COMMENT \*\*\*\*\*

COMMENT PVRC SSE VERT (SPEC. G51, FIG. F15), SPECTRA # P29

COMMENT \*\*\*\*\*

Y-SHOCK	FREQ	ACCEL	.0100	.0600	.7000	.2100
Y-SHOCK	FREQ	ACCEL	1.5000	.3700	1.6000	.4800

Y-SHOCK	FREQ	ACCEL	2.1000	.5600	2.5000	.6000
Y-SHOCK	FREQ	ACCEL	3.0000	.7000	4.1000	.7000
Y-SHOCK	FREQ	ACCEL	4.3000	1.0300	5.8000	1.0300
Y-SHOCK	FREQ	ACCEL	6.8000	.7000	8.0000	.7000
Y-SHOCK	FREQ	ACCEL	8.4000	.7400	9.9000	.7400
Y-SHOCK	FREQ	ACCEL	10.0000	.7400	11.0000	.7740
Y-SHOCK	FREQ	ACCEL	11.7000	.7978	12.0000	.7880
Y-SHOCK	FREQ	ACCEL	13.0000	.7100	14.0000	.6080
Y-SHOCK	FREQ	ACCEL	15.0000	.4750	15.3000	.4577
Y-SHOCK	FREQ	ACCEL	16.0000	.4640	17.0000	.4730
Y-SHOCK	FREQ	ACCEL	18.0000	.4820	19.0000	.4520
Y-SHOCK	FREQ	ACCEL	20.0000	.4100	22.0000	.3000
Y-SHOCK	FREQ	ACCEL	23.0000	.2850	25.0000	.2550
Y-SHOCK	FREQ	ACCEL	28.0000	.2500	31.0000	.2450
Y-SHOCK	FREQ	ACCEL	33.0000	.2400		

COMMENT

SEISMIC            8            386.4            386.4            386.4            CSM            RSS

COMMENT            - READ Y-SHOCK CARDS BELOW -

COMMENT \*\*\*\*\*

COMMENT PVRC SSE VERT (SPEC. G51, FIG. G30), SPECTRA # P30

COMMENT \*\*\*\*\*

Y-SHOCK	FREQ	ACCEL	.0100	.0600	.8600	.2300
Y-SHOCK	FREQ	ACCEL	1.6000	.4500	2.0000	.4800
Y-SHOCK	FREQ	ACCEL	2.4000	.6000	2.8000	.6600
Y-SHOCK	FREQ	ACCEL	3.3000	.7200	6.4000	.7200
Y-SHOCK	FREQ	ACCEL	7.2000	.7300	7.7000	.7500
Y-SHOCK	FREQ	ACCEL	8.2000	.7800	8.6000	.8100
Y-SHOCK	FREQ	ACCEL	9.9000	.8100	10.0000	.8100
Y-SHOCK	FREQ	ACCEL	11.0000	.8440	12.0000	.8780
Y-SHOCK	FREQ	ACCEL	13.0000	.8380	14.0000	.7840
Y-SHOCK	FREQ	ACCEL	15.0000	.7450	15.3000	.7201
Y-SHOCK	FREQ	ACCEL	15.5000	.7125	16.0000	.7200
Y-SHOCK	FREQ	ACCEL	17.0000	.7350	18.0000	.7500
Y-SHOCK	FREQ	ACCEL	19.0000	.7650	19.5000	.7725
Y-SHOCK	FREQ	ACCEL	20.0000	.7800	22.0000	.6300
Y-SHOCK	FREQ	ACCEL	25.0000	.4500	28.0000	.3000
Y-SHOCK	FREQ	ACCEL	28.5000	.2992	31.0000	.2950
Y-SHOCK	FREQ	ACCEL	33.0000	.2900		

COMMENT

SEISMIC            9            386.4            386.4            386.4            CSM            RSS

COMMENT            - READ Y-SHOCK CARDS BELOW -

COMMENT \*\*\*\*\*

COMMENT PVRC SSE VERT (SPEC. G51, FIG. G31), SPECTRA # P31

COMMENT \*\*\*\*\*

Y-SHOCK	FREQ	ACCEL	.0100	.0500	.9000	.2400
Y-SHOCK	FREQ	ACCEL	.9600	.2500	1.6000	.4500
Y-SHOCK	FREQ	ACCEL	2.0000	.5300	2.4000	.6000
Y-SHOCK	FREQ	ACCEL	2.8000	.6500	3.2000	.7300
Y-SHOCK	FREQ	ACCEL	3.5000	.7500	4.0000	.7600
Y-SHOCK	FREQ	ACCEL	4.5000	.7900	5.0000	.8000
Y-SHOCK	FREQ	ACCEL	5.5000	.8100	6.0000	.8200



Y-SHOCK	FREQ	ACCEL	6.8000	.8300	7.3000	.8500
Y-SHOCK	FREQ	ACCEL	7.8000	.9500	8.3000	1.1000
Y-SHOCK	FREQ	ACCEL	8.8000	1.1500	9.3000	1.2000
Y-SHOCK	FREQ	ACCEL	9.6000	1.2700	9.9000	1.2700
Y-SHOCK	FREQ	ACCEL	10.0000	1.2700	11.0000	1.3260
Y-SHOCK	FREQ	ACCEL	12.0000	1.3820	13.0000	1.4380
Y-SHOCK	FREQ	ACCEL	14.0000	1.4940	15.0000	1.5500
Y-SHOCK	FREQ	ACCEL	16.0000	1.6060	17.0000	1.5070
Y-SHOCK	FREQ	ACCEL	18.0000	1.4120	19.0000	1.3120
Y-SHOCK	FREQ	ACCEL	20.0000	1.2000	22.0000	.9000
Y-SHOCK	FREQ	ACCEL	25.0000	.5000	25.5000	.4750
Y-SHOCK	FREQ	ACCEL	26.0000	.4500	28.0000	.4300
Y-SHOCK	FREQ	ACCEL	31.0000	.4100	33.0000	.4000

COMMENT SEISMIC 10 386.4 386.4 386.4 CSM RSS

COMMENT - READ Y-SHOCK CARDS BELOW -

COMMENT \*\*\*\*\*

COMMENT PVRC SSE VERT (SPEC. G51, FIG. F3), SPECTRA # P32

COMMENT \*\*\*\*\*

Y-SHOCK	FREQ	ACCEL	.0100	.0800	.5000	.1800
Y-SHOCK	FREQ	ACCEL	.7400	.2300	1.5000	.3800
Y-SHOCK	FREQ	ACCEL	2.0000	.5000	2.4000	.5700
Y-SHOCK	FREQ	ACCEL	2.8000	.6500	3.1000	.6900
Y-SHOCK	FREQ	ACCEL	3.6000	.7000	4.1000	.7200
Y-SHOCK	FREQ	ACCEL	4.3000	.9700	5.8000	.9700
Y-SHOCK	FREQ	ACCEL	6.2000	.8500	6.6000	.7500
Y-SHOCK	FREQ	ACCEL	7.0000	.6700	7.5000	.6400
Y-SHOCK	FREQ	ACCEL	8.0000	.6300	8.4000	.6200
Y-SHOCK	FREQ	ACCEL	9.0000	.6000	9.9000	.5730
Y-SHOCK	FREQ	ACCEL	10.0000	.5700	11.0000	.5520
Y-SHOCK	FREQ	ACCEL	12.0000	.5460	13.0000	.5240
Y-SHOCK	FREQ	ACCEL	14.0000	.5160	15.0000	.4900
Y-SHOCK	FREQ	ACCEL	16.0000	.4700	17.0000	.4530
Y-SHOCK	FREQ	ACCEL	18.0000	.4260	19.0000	.4130
Y-SHOCK	FREQ	ACCEL	20.0000	.3600	21.0000	.3200
Y-SHOCK	FREQ	ACCEL	21.1000	.2500	22.0000	.2300
Y-SHOCK	FREQ	ACCEL	24.0000	.2000	33.0000	.2000

COMMENT -----

COMMENT

COMMENT

COMMENT \*\*\*\*\* Z-SPECTRA : E-W DIRECTION \*\*\*\*\*

SEISMIC 11 386.4 386.4 386.4 CSM RSS

COMMENT - READ Z-SHOCK CARDS BELOW -

COMMENT \*\*\*\*\*

COMMENT PVRC SSE E-W (SPEC. G51, FIG. F2), SPECTRA # P36

COMMENT \*\*\*\*\*

Z-SHOCK	FREQ	ACCEL	.0100	.1100	.3400	.1300
Z-SHOCK	FREQ	ACCEL	.4400	.2000	.4600	.2100
Z-SHOCK	FREQ	ACCEL	.8400	.2500	2.0000	.5300
Z-SHOCK	FREQ	ACCEL	2.1000	.5400	2.8000	.5400
Z-SHOCK	FREQ	ACCEL	2.9000	.6200	3.0000	.6300

Z-SHOCK	FREQ	ACCEL	3.4000	.6300	3.6000	.7800
Z-SHOCK	FREQ	ACCEL	6.4000	.7500	6.6000	.7500
Z-SHOCK	FREQ	ACCEL	7.0000	.6800	7.5000	.5600
Z-SHOCK	FREQ	ACCEL	8.0000	.5100	8.5000	.4500
Z-SHOCK	FREQ	ACCEL	9.0000	.3800	9.6000	.3000
Z-SHOCK	FREQ	ACCEL	9.9000	.2850	10.0000	.2800
Z-SHOCK	FREQ	ACCEL	11.0000	.2630	12.0000	.2470
Z-SHOCK	FREQ	ACCEL	13.0000	.2260	14.0000	.2080
Z-SHOCK	FREQ	ACCEL	15.0000	.1900	16.0000	.1800
Z-SHOCK	FREQ	ACCEL	17.0000	.1800	18.0000	.1800
Z-SHOCK	FREQ	ACCEL	19.0000	.1800	20.0000	.1800
Z-SHOCK	FREQ	ACCEL	33.0000	.1800		

COMMENT

SEISMIC 12 386.4 386.4 386.4 CSM RSS

COMMENT - READ Z-SHOCK CARDS BELOW -

COMMENT \*\*\*\*\*

COMMENT PVRC SSE E-W (SPEC. G51, FIG. F8), SPECTRA # P37

COMMENT \*\*\*\*\*

Z-SHOCK	FREQ	ACCEL	.0100	.0800	.4400	.2000
Z-SHOCK	FREQ	ACCEL	.7400	.2300	.8000	.2400
Z-SHOCK	FREQ	ACCEL	1.9000	.5500	2.2000	.5700
Z-SHOCK	FREQ	ACCEL	2.3000	.5700	2.4000	.6000
Z-SHOCK	FREQ	ACCEL	2.6000	.6900	6.2000	.6900
Z-SHOCK	FREQ	ACCEL	6.4000	.6400	7.0000	.5100
Z-SHOCK	FREQ	ACCEL	7.5000	.4400	8.0000	.4000
Z-SHOCK	FREQ	ACCEL	8.5000	.3300	9.0000	.2800
Z-SHOCK	FREQ	ACCEL	9.4000	.2400	9.9000	.2358
Z-SHOCK	FREQ	ACCEL	10.0000	.2350	11.0000	.2350
Z-SHOCK	FREQ	ACCEL	12.0000	.2330	13.0000	.2290
Z-SHOCK	FREQ	ACCEL	14.0000	.2250	15.0000	.2175
Z-SHOCK	FREQ	ACCEL	16.0000	.2080	17.0000	.2000
Z-SHOCK	FREQ	ACCEL	18.0000	.2000	19.0000	.2000
Z-SHOCK	FREQ	ACCEL	20.0000	.2000	33.0000	.2000

COMMENT

SEISMIC 13 386.4 386.4 386.4 CSM RSS

COMMENT - READ Z-SHOCK CARDS BELOW -

COMMENT \*\*\*\*\*

COMMENT PVRC SSE E-W (SPEC. G51, FIG. F14), SPECTRA # P38

COMMENT \*\*\*\*\*

Z-SHOCK	FREQ	ACCEL	.0100	.0900	.4500	.2100
Z-SHOCK	FREQ	ACCEL	.6200	.2100	.6800	.2300
Z-SHOCK	FREQ	ACCEL	1.0700	.3400	2.1000	.6000
Z-SHOCK	FREQ	ACCEL	2.3500	.6000	2.6000	.8200
Z-SHOCK	FREQ	ACCEL	5.4000	.8200	5.7000	.8000
Z-SHOCK	FREQ	ACCEL	6.2000	.6700	6.6000	.5500
Z-SHOCK	FREQ	ACCEL	7.0000	.4800	7.5000	.4200
Z-SHOCK	FREQ	ACCEL	8.0000	.3800	8.5000	.3300
Z-SHOCK	FREQ	ACCEL	9.0000	.2700	9.9000	.2655
Z-SHOCK	FREQ	ACCEL	10.0000	.2650	10.7000	.2677
Z-SHOCK	FREQ	ACCEL	11.0000	.2670	12.0000	.2660
Z-SHOCK	FREQ	ACCEL	13.0000	.2620	14.0000	.2550

Z-SHOCK	FREQ	ACCEL	15.0000	.2450	16.0000	.2300
Z-SHOCK	FREQ	ACCEL	17.0000	.2300	18.0000	.2300
Z-SHOCK	FREQ	ACCEL	19.0000	.2300	20.0000	.2300
Z-SHOCK	FREQ	ACCEL	33.0000	.2300		

COMMENT  
 COMMENT  
 COMMENT  
 COMMENT  
 COMMENT

CASE OBEDX OBE DISPL. IN X  
 COMMENT - LIST "TRANSLATE" CARDS BELOW FOR ALL NODES  
 COMMENT DYNAMICALLY RESTRAINED IN X, WITH THEIR  
 COMMENT CORRESPONDING DISPLACEMENTS IN X.-  
 COMMENT

PRINT		NO	NO	NO	NO
TRANSLATE	P201	-0.0129			
TRANSLATE	H11	0.03			
TRANSLATE	H12	0.03			
TRANSLATE	H10	0.02			
TRANSLATE	H9	0.02			
TRANSLATE	H7	0.015			
TRANSLATE	H5A	0.015			
TRANSLATE	H1B	0.020			
TRANSLATE	H5B	0.03			
TRANSLATE	H4B	0.03			
TRANSLATE	I7SAN	-0.0129			
TRANSLATE	I9SBN	-0.0125			

COMMENT  
 COMMENT

CASE OBEDY OBE DISPL. IN Y  
 COMMENT - LIST "TRANSLATE" CARDS BELOW FOR ALL NODES  
 COMMENT DYNAMICALLY RESTRAINED IN Y, WITH THEIR  
 COMMENT CORRESPONDING DISPLACEMENTS IN Y.-  
 COMMENT

PRINT		NO	NO	NO	NO
TRANSLATE	P201		0.0012		
TRANSLATE	H18		-0.021		
TRANSLATE	H15		-0.021		
TRANSLATE	H4A		0.0067		
TRANSLATE	H2A		0.0067		
TRANSLATE	H1B		-0.0018		
TRANSLATE	H3B		-0.0020		
TRANSLATE	I7SAN		0.00129		
TRANSLATE	I9SBN		0.00129		
TRANSLATE	H13		0.00400		

COMMENT  
 COMMENT

CASE OBEDZ OBE DISPL. IN Z  
 COMMENT - LIST "TRANSLATE" CARDS BELOW FOR ALL NODES  
 COMMENT DYNAMICALLY RESTRAINED IN Z, WITH THEIR  
 COMMENT CORRESPONDING DISPLACEMENTS IN Z.-  
 COMMENT

COMMENT				
PRINT		NO	NO	NO
TRANSLATE P201				-0.01165
TRANSLATE H17				0.022
TRANSLATE H14				0.022
TRANSLATE H11				0.020
TRANSLATE H12				0.020
TRANSLATE H9				0.013
TRANSLATE H6				0.010
TRANSLATE H3A				0.015
TRANSLATE H2B				0.013
TRANSLATE H5B				0.020
TRANSLATE H4B				0.020
TRANSLATE I7SAN				-0.01165
TRANSLATE I9SBN				-0.01239

COMMENT  
 -----  
 COMMENT  
 CASE OBEDE OBE DISPL. (X+Y+Z)  
 COMBINE OBEDXRSS OBEDYRSS OBEDZRSS  
 COMMENT  
 =====

COMMENT  
 CASE SSEDX SSE DISPL. IN X  
 COMMENT - LIST "TRANSLATE" CARDS BELOW FOR ALL NODES  
 COMMENT DYNAMICALLY RESTRAINED IN X, WITH THEIR  
 COMMENT CORRESPONDING DISPLACEMENTS IN X.-

COMMENT				
PRINT		NO	NO	NO
TRANSLATE P201				-0.0167
TRANSLATE H11				0.065
TRANSLATE H12				0.065
TRANSLATE H10				0.040
TRANSLATE H9				0.040
TRANSLATE H7				0.027
TRANSLATE H5A				0.027
TRANSLATE HPTUB				0.015
TRANSLATE H1B				0.038
TRANSLATE H5B				0.065
TRANSLATE H4B				0.065
TRANSLATE I7SAN				-0.0167
TRANSLATE I9SBN				-0.0161

COMMENT  
 -----  
 COMMENT  
 CASE SSEDY SSE DISPL. IN Y  
 COMMENT - LIST "TRANSLATE" CARDS BELOW FOR ALL NODES  
 COMMENT DYNAMICALLY RESTRAINED IN Y, WITH THEIR  
 COMMENT CORRESPONDING DISPLACEMENTS IN Y.-

COMMENT				
PRINT		NO	NO	NO
TRANSLATE P201				0.002
TRANSLATE H1B				-0.0418
TRANSLATE H15				-0.0418

TRANSLATE H4A 0.01200  
 TRANSLATE H2A 0.01200  
 TRANSLATE H1B -0.0026  
 TRANSLATE H3B -0.0040  
 TRANSLATE I7SAN 0.00215  
 TRANSLATE H13 0.00670  
 TRANSLATE I9SBN 0.00214

COMMENT -----  
 COMMENT  
 CASE SSEDZ SSE DISPL. IN Z  
 COMMENT - LIST "TRANSLATE" CARDS BELOW FOR ALL NODES  
 COMMENT DYNAMICALLY RESTRAINED IN Z, WITH THEIR  
 COMMENT CORRESPONDING DISPLACEMENTS IN Z.-  
 COMMENT

PRINT	NO	NO	NO	NO
TRANSLATE P201			-0.0188	
TRANSLATE H17			0.05	
TRANSLATE H14			0.05	
TRANSLATE H11			0.045	
TRANSLATE H12			0.045	
TRANSLATE H9			0.030	
TRANSLATE H6			0.020	
TRANSLATE H3A			0.032	
TRANSLATE HPTUB			0.010	
TRANSLATE H2B			0.030	
TRANSLATE H5B			0.045	
TRANSLATE H4B			0.045	
TRANSLATE I7SAN			-0.0188	
TRANSLATE I9SBN			-0.0197	

COMMENT -----  
 COMMENT  
 CASE SSED SSE DISPL. (X+Y+Z)  
 COMBINE SSEDXRSS SSEDYRSS SSEDZRSS  
 COMMENT =====  
 COMMENT

CASE MXEQD MAX. OF OBED/SSED  
 MAXIMUM ABS OBED SSED  
 COMMENT

CASE MXEQI MAX. OF OBEI/SSEI  
 MAXIMUM ABS OBEI SSEI  
 COMMENT  
 =====  
 =====

CASE OL OPERATING LOADS  
 FORCE I6 0.0000 38424.0 -38424.0  
 COMMENT =====  
 =====

CASE QAB SRV HYDRODYNAMIC  
 COMMENT =====  
 =====  
 FORCE I1CAP 347.4 350.9 1498.0  
 FORCE I2SFA 643.3 651.7 2782.1

FORCE	I3SPA	711.7	866.7	3700.3
FORCE	I4SPA	925.30	1388.8	5929.2
FORCE	I5SUP	484.0	872.6	3725.2
FORCE	I6	312.2	888.0	3790.9
FORCE	I7	431.2	1427.1	6092.6
FORCE	I8	181.4	1747.4	7460.1
FORCE	I9WAT	26.60	509.9	2181.8
COMMENT				
FORCE	I5SUP	0.20	1.44	-2.14
FORCE	I5EA	-1.10	-7.73	10.90
FORCE	I1SAP	934.9	1687.0	-2010.7
FORCE	I2SA	770.0	1331.0	-1569.2
FORCE	I3SA	1273.4	2154.8	-2526.9
FORCE	I4SA	1387.2	2185.7	-2512.9
FORCE	I5SA	1158.8	1708.8	-1924.4
FORCE	I6SAP	1559.6	2142.2	-2355.9
FORCE	I7SAN	-213.0	-285.3	310.9
COMMENT				
FORCE	I5SUP	12.40	73.10	-73.80
FORCE	I5EB	70.80	-418.6	422.6
FORCE	I1SBP	-249.0	1467.3	-1480.0
FORCE	I2SB	-655.0	3263.0	-3225.2
FORCE	I3SB	238.4	3460.8	-4795.0
FORCE	I4SB	428.3	2410.2	-4418.6
FORCE	I5SB	1162.5	3120.9	-7515.4
FORCE	I6SB	1834.4	3040.6	-9299.3
FORCE	I7SB	4680.0	5420.0	-20175.0
FORCE	I8SBP	387.7	574.5	1865.1
FORCE	I9SBN	-81.30	-120.5	391.1
COMMENT				
CASE	CHUGO	POST CHUG	HYDRODYNAMIC	
COMMENT				
FORCE	I1CAP	.3138E+04	.1829E+03	-.4377E+03
FORCE	I2SPA	.5840E+04	.3368E+03	-.8182E+03
FORCE	I3SPA	.1022E+05	.2889E+03	-.1738E+04
FORCE	I4SPA	.1819E+05	-.9722E+01	-.3639E+04
FORCE	I5SUP	.1286E+05	-.3362E+03	-.2835E+04
FORCE	I6	.8182E+04	-.3899E+01	-.1762E+04
FORCE	I7	.1054E+05	.3188E+03	-.1438E+04
FORCE	I8	.3280E+04	.1405E+04	-.6852E+03
FORCE	I9WAT	.4203E+03	.4600E+03	-.4173E+03
COMMENT				
FORCE	I5SUP	-.6791E+02	.9325E+01	.6326E-01
FORCE	I5EA	.2794E+03	-.3836E+02	-.2602E+00
FORCE	I1SAP	-.3329E+04	.4571E+03	.3101E+01
FORCE	I2SA	-.8752E+03	.1102E+03	.1151E+02
FORCE	I3SA	-.2450E+04	.2885E+03	.5373E+02
FORCE	I4SA	-.1510E+04	.1528E+03	.5983E+02
FORCE	I5SA	-.1126E+04	.1090E+03	.4966E+02
FORCE	I6SAP	-.1244E+04	.1108E+03	.6543E+02
FORCE	I7SAN	.1571E+03	-.1345E+02	-.8868E+01

COMMENT

FORCE	I5SUP	.1603E+02	-.1812E+02	-.1658E+02
FORCE	I5EB	-.6536E+02	.7394E+02	.6748E+02
FORCE	I1SBP	.1485E+04	-.1541E+04	-.1753E+04
FORCE	I2SB	.3194E+04	-.3232E+04	-.3900E+04
FORCE	I3SB	.2966E+04	-.3016E+04	-.3598E+04
FORCE	I4SB	.1280E+04	-.1329E+04	-.1510E+04
FORCE	I5SB	.7678E+03	-.6938E+03	-.1069E+04
FORCE	I6SB	.3666E+03	-.2514E+03	-.6359E+03
FORCE	I7SB	.8828E+02	.4838E+02	-.3256E+03
FORCE	I8SBP	.1022E+03	.5122E+02	-.3697E+03
FORCE	I9SBN	-.2444E+02	-.1181E+02	.8769E+02

COMMENT

COMMENT

CASE	CHUGF	POST	CHUG	FSI
------	-------	------	------	-----

COMMENT

FORCE	I1CAP	.1153E+04	0.	0.
FORCE	I2SPA	.2140E+04	0.	0.
FORCE	I3SPA	.2356E+04	0.	0.
FORCE	I4SPA	.3440E+04	0.	0.
FORCE	I5SUP	.1977E+04	0.	0.
FORCE	I6	.1869E+04	0.	0.
FORCE	I7	.2941E+04	0.	0.
FORCE	I8	.3437E+04	0.	0.
FORCE	I9WAT	.9992E+03	0.	0.

COMMENT

FORCE	I5SUP	.2903E+01	3.0	0.75
FORCE	I5EA	-.1195E+02	12.33	3.09
FORCE	I1SAP	.1423E+03	146.9	36.85
FORCE	I2SA	.4386E+02	45.3	11.36
FORCE	I3SA	.2111E+03	217.9	54.66
FORCE	I4SA	.3887E+03	401.3	100.7
FORCE	I5SA	.3112E+03	321.2	80.6
FORCE	I6SAP	.2991E+03	308.7	77.5
FORCE	I7SAN	-.3517+02	-36.3	-9.11

COMMENT

FORCE	I5SUP	0.5	0.8	-0.6
FORCE	I5EB	-.1970E+01	-3.15	2.45
FORCE	I1SBP	.4805E+02	76.9	-59.95
FORCE	I2SB	.1053E+03	168.4	-131.4
FORCE	I3SB	.1071E+03	171.3	-133.6
FORCE	I4SB	.1534E+03	245.4	-191.4
FORCE	I5SB	.2485E+03	397.5	-310.1
FORCE	I6SB	.3419E+03	546.9	-426.6
FORCE	I7SB	.2402E+03	384.2	-299.7
FORCE	I8SBP	.1837E+03	293.9	-229.2
FORCE	I9SBN	-.4140E+02	-66.20	51.65

COMMENT

CASE	CHUG	TOTAL	CHUGO	HYD	+ FSI
------	------	-------	-------	-----	-------

COMBINE

COMMENT

CHUGOABS	CHUGFABS
----------	----------

```
=====
COMMENT
CASE      CO      CO  HYDRODYNAMIC
COMBINE   CHUG    1.0
COMMENT
COMMENT
COMMENT
=====
END LOADS
COMMENT *****
COMMENT
COMMENT                CODE EVALUATION
COMMENT
COMMENT                NOTE: INCLUDE ONE "ALLOWABLE" CARD CORRESPONDING TO
COMMENT                EVERY "MATERIAL" CARD IN THE MODEL, IN EACH OF THE
COMMENT                FOLLOWING CODE EVALUATION SEGMENTS. ALSO VERIFY AND
COMMENT                INCLUDE CORRESPONDING SH AND SC VALUES.
COMMENT
EVALUATE
COMMENT
COMMENT *****
COMMENT *****
CODE                CLASS 2  DESIGN  77ED S77
COMMENT *****
COMMENT                ***** L.C. A-1 IS EQN. 8 BELOW *****
COMMENT *****
EQUATION  8      OL
EQUATION  9                OBEI
EQUATION 10                OBED
PEAK PRES I1CAP210  185.0
ALLOWABLE 1                15000.    15000.
COMMENT *****
CODE                CLASS 2  DESIGN  77ED S77
EQUATION  9                QAB
PEAK PRES I1CAP210  185
ALLOWABLE 1                15000.    15000.
COMMENT *****
CODE                CLASS 2  LEVELC  77ED S77
EQUATION  9                CHUG
PEAK PRES I1CAP210  185
ALLOWABLE 1                15000.    15000.
COMMENT *****
CODE                CLASS 2  LEVELC  77ED S77
EQUATION  9                MXEQI
EQUATION 10                MXEQD
PEAK PRES I1CAP210  185.0
ALLOWABLE 1                15000.    15000.
COMMENT
END CODE
COMMENT *****
RESTART
SAVE      LMOD1    100  200  20  20  20  100  5
```



● END RESTRT  
/\*EOR

CJM,P3.  
USER(NU134WC,XNUTECH)  
CHARGE,F3395JT,\*311\*XPS080501.  
ROUTE(OUTPUT,DEF,DC=PR,FID=CJM40,ID)  
SETTL,\*.  
SETJSL,\*.  
REWIND,OUTPUT.

\*  
\*\*\*\*\*  
\* RESTART, INPUT, AND OUTPUT+DAYFILE ARE SAVED \*  
\* IN THE FOLLOWING TAPE, IN THAT ORDER. \*  
\*\*\*\*\*  
COPYBR,INPUT,SYNIN.  
REWIND,SYNIN.  
GET,APPLIC/UN=LIBRARY.  
BEGIN,PISTARR,APPLIC,LEVEL=351,NOTES=N,TSTORE=P201,  
TSAVE=P201,FN=1.

\*\*\*\*\*  
\* ATTACH PISTAR MODEL IMMEDIATELY BELOW "/EOR", \*  
\* FOLLOWED BY LOAD MODULE-1 \*  
\*\*\*\*\*  
/\*EOR

TITLE HOPE CREEK TAP SYSTEM:HPCI TURBINE EXHAUST P201  
ID CLIENT= PUBLIC SERVICE ELECTRIC & GAS COMPANY  
ID PROJECT NAME= HOPE CREEK TAP SNUBBER REDUCTION  
ID PROJECT NUMBER= XPS-0800  
ID JOB NUMBER= XPS-0800  
ID FILE NUMBER= PSE005.1016  
ID CALCULATION NUMBER=C-31  
ID RUN NUMBER=  
ID PREPARED BY= C. J. MEHTA  
ID CHECKED BY= A. S. HERLEKER

COMMENT \*\*\*\*\*  
COMMENT \* FILE NAME : C31DWS \*  
COMMENT \*\*\*\*\*  
COMMENT \* LOAD AND CODE EVALUATION MODULE - 2 \*  
COMMENT \* \*  
COMMENT \* THIS CONTAINS ALL NON-MARK1 STATIC LOAD CASES. \*  
COMMENT \* ALSO LOAD COMBINATIONS ARE PERFORMED WITH THE LOAD \*  
COMMENT \* CASES OF LOAD MODULE-1, FOLLOWED BY CODE EVALUATION \*  
COMMENT \* ----- \*  
COMMENT \* SINCE THE LOAD CASES EVALUATED IN THIS MODULE ARE \*  
COMMENT \* STATIC CASES, THE SNUBBERS SHALL BE CODED BACK AS \*  
COMMENT \* "SNUBBERS" IN THIS RESTART RUN. \*  
COMMENT \*\*\*\*\*  
COMMENT \*\*\*\*\*  
COMMENT \* SNUBBER REMAIN : 006-H18,H15,H22 \*  
COMMENT \* 014-H02, \*  
COMMENT \*\*\*\*\*  
COMMENT \* SNUBBER CHANGE TO STRUT : NONE \*  
COMMENT \*\*\*\*\*

```
COMMENT * SNUBBER DELETED : 006-H10,H09,H07,H05,H03 *
COMMENT * : 006-H02, *
COMMENT *****
GEOMETRY *****
COMMENT *****
COMMENT SNUBBER NO. 1-P-FD-006-H18 AT NODE H18
COMMENT *****
SNUBBER H18 0.0 1.0 0.0 SPRING 2.59E5
COMMENT *****
COMMENT SNUBBER NO. 1-P-006-H22 AT NODE H22 (WAS 45CGS)
COMMENT *****
SNUBBER H22 0.0 0.0 1.0 SPRING 8.700E4
COMMENT *****
COMMENT SNUBBER NO. 1-P-FD-006-H15 AT NODE H15.
COMMENT *****
SNUBBER H15 0.0 1.0 0.0 SPRING 4.950E5
COMMENT *****
COMMENT SNUBBER NO 1-P-FD-014-H02 AT NODE H2B.
COMMENT *****
SNUBBER H2B 0.0 0.0 1.0 SPRING 2.530E5
COMMENT *****
COMMENT *****
END GEOM *****
COMMENT LOAD MODULE - 2
COMMENT *****
CASE DW DEAD WEIGHT
DEAD LOAD
END LOADS
COMMENT *****
COMMENT IN THE FOLLOWING CODE EVALUATION SEGMENTS, USE
COMMENT AS MANY "ALLOWABLE" CARDS AS THERE ARE "MATERIAL"
COMMENT CARDS IN THE MODEL. ALSO VERIFY AND INCLUDE THE
COMMENT CORRESPONDING SH AND SC VALUES
COMMENT *****
EVALUATE *****
COMMENT *****
CODE CLASS 2 DESIGN 77ED 577
COMMENT *****
COMMENT ***** L.C. A-1 IS EQN. 8 BELOW *****
COMMENT *****
EQUATION 8 DW
PEAK PRES I1CAP 210 185.0
ALLOWABLE 1 15000. 15000.
END CODE
COMMENT *****
RESTART
RESTORE LMOD1
SAVE LMOD2
```

● END RESTRT  
/\*EOR

CJM,P3.  
USER(NU134WC,XNUTECH)  
CHARGE,F3395JT,\*311\*XPS080501.  
ROUTE(OUTPUT,DEF,DC=PR,FID=CJM40,ID)  
SETTL,\*.  
SETJSL,\*.  
REWIND,OUTPUT.

\*  
\*\*\*\*\*  
\* RESTART, INPUT, AND OUTPUT+DAYFILE ARE SAVED \*  
\* IN THE FOLLOWING TAPE, IN THAT ORDER. \*  
\*\*\*\*\*  
COPYBR,INPUT,SYNIN.  
REWIND,SYNIN.  
GET,APPLIC/UN=LIBRARY.  
BEGIN,PISTARR,APPLIC,LEVEL=351,NOTES=N,TSAVE=P201,  
TSTORE=P201,FN=2.

\*\*\*\*\*  
\* ATTACH PISTAR MODEL IMMEDIATELY BELOW "/EOR", \*  
\* FOLLOWED BY LOAD MODULE-3 \*  
\*\*\*\*\*  
/\*EOR

ID TITLE HOPE CREEK TAP SYSTEM:HPCI TURBINE EXHAUST P201  
ID CLIENT= PUBLIC SERVICE ELECTRIC & GAS COMPANY  
ID PROJECT NAME= HOPE CREEK TAP SNUBBER REDUCTION  
ID PROJECT NUMBER= XPS-0800  
ID JOB NUMBER= XPS-0800  
ID FILE NUMBER= PSE005.1016  
ID CALCULATION NUMBER=C-31  
ID RUN NUMBER=  
ID PREPARED BY= C. J. MEHTA  
ID CHECKED BY= A. S. HERLEKER

COMMENT \*\*\*\*\*  
COMMENT \* FILE NAME : C31TH \*  
COMMENT \*\*\*\*\*  
COMMENT \* LOAD MODULE - 3 \*  
COMMENT \*\*\*\*\*  
COMMENT \*\*\*\*\*  
COMMENT \* SNUBBER REMAIN : 006-H1B,H15,H22 \*  
COMMENT \* 014-H02, \*  
COMMENT \*\*\*\*\*  
COMMENT \* SNUBBER CHANGE TO STRUT : NONE \*  
COMMENT \*\*\*\*\*  
COMMENT \* SNUBBER DELETED : 006-H10,H09,H07,H05,H03 \*  
COMMENT \* : 006-H02, \*  
COMMENT \*\*\*\*\*

GEOMETRY  
COMMENT \*\*\*\*\*  
COMMENT SNUBBER NO. 1-P-FD-006-H18 AT NODE H18  
COMMENT \*\*\*\*\*  
SNUBBER H18 0.0 1.0 0.0 SPRING 2.59E5

```
*****
COMMENT SNUBBER NO. 1-P-006-H22 AT NODE H22 (WAS 45CGS)
COMMENT *****
SNUBBER H22 0.0 0.0 1.0 SPRING 8.700E4
COMMENT *****
COMMENT SNUBBER NO. 1-F-FD-006-H15 AT NODE H15.
COMMENT *****
SNUBBER H15 0.0 1.0 0.0 SPRING 4.950E5
COMMENT *****
COMMENT SNUBBER NO 1-P-FD-014-H02 AT NODE H2B.
COMMENT *****
SNUBBER H2B 0.0 0.0 1.0 SPRING 2.530E5
COMMENT *****
COMMENT *****
END GEOM
COMMENT *****
LOADING LOAD MODULE - 3
COMMENT *****
COMMENT *****
CASE TE TH. EXP.- NORM. OPER.
THERMAL I1CAP P201 107.00
THERMAL EXNOZ 155 213.00
THERMAL 160 210 40.00
COMMENT *****
COMMENT *****
CASE TE1 MAX OP. TEMP
THERMAL I1CAP P201 97.00
THERMAL EXNOZ 155 213.00
THERMAL 160 210 40.00
COMMENT *****
CASE TE2 LONG TERM TORUS HEAT UP
THERMAL I1CAP P201 142.0
THERMAL EXNOZ 155 213.0
THERMAL 160 210 40.0
COMMENT *****
CASE THAMA TORUS ANC. DISP. @ 100F
TRANSLATE P201 0.021195 0.015141 -0.15411
TRANSLATE I9SBN 0.000000 -0.009546 -0.14295
TRANSLATE I7SAN 0.028850 -0.010980 -0.14510
TRANSLATE HPTUB 0.000500 -0.004000 -0.00690
COMMENT *****
CASE THAM TORUS ANC. DIS. 177 F
COMBINE THAMA 3.567
COMMENT *****
CASE THAM1 THAM1 ANC. MOV. @ 167 F
COMBINE THAMA 3.233
COMMENT *****
```

```

CASE THAM2 TORUS AT 212 F
COMBINE THAMA 4.733
COMMENT =====
CASE TD ANCH.MVT.DUE TO DW+SBA PRESS.
TRANSLATE P201 0.005000 0.002900 -0.0882
TRANSLATE I9SBN 0.000000 -0.007660 -0.04816
TRANSLATE I7SAN 0.008060 -0.002107 -0.04053
COMMENT =====
COMMENT =====
COMMENT TD1 SAME AS TD
CASE TD1 ANCH.MVT.DUE TO DW+SBA PRESS.
COMBINE TD 1.0
COMMENT =====
COMMENT TD2 SAME AS TD1
CASE TD2 ANCH.MVT.DUE TO DW+SBA PRESS.
COMBINE TD1 1.0
COMMENT =====
CASE TE2T SUM THAM2 & TE2 & TD2
COMBINE TE2 DIR 1.0282 THAM2DIR 1.0282 TD2 DIR
COMMENT =====
CASE THTD THAM+TD
COMBINE THAM TD NO NO NO NO
PRINT
CASE TEHD TE+THAM+TD
COMBINE TE THAM TD
PRINT NO NO NO NO
CASE THTD1 THAM1+TD1
COMBINE THAM1 TD1
PRINT NO NO NO NO
CASE TEHD1 TE1+THAM1+TD1
COMBINE TE1 THAM1 TD1
PRINT NO NO NO TD1
COMMENT
CASE TMAX MAX(THAM+TD,TE+THAM+TD)
MAXIMUM ABS THTD TEHD
PRINT YES NO NO NO
COMMENT
CASE TMAX1 MAX(THAM1+TD1,TE1+THAM1+TD1)
MAXIMUM ABS THTD1 TEHD1
PRINT YES NO NO NO
COMMENT
COMMENT ***** PIPNG LOAD COMBINATIONS *****
COMMENT
COMMENT THE FOLLOWING LOAD COMBINATIONS DO NOT INCLUDE LINE
COMMENT OPERATING LOAD (OL). IF OL IS APPLICABLE, OL SHALL BE
COMMENT EVALUATED AND COMBINED WITH OTHER PRIMARY LOADS. IN
    
```

```
COMMENT COMBINATIONS WHERE DYNAMIC LOADS ARE PRESENT, OL MAY
COMMENT BE SRSS'ED WITH DYNAMIC LOADS. THE COMBINATIONS ARE
COMMENT GIVEN IN TECHNICAL INSTRUCTION NO. PSE-TI-002.
COMMENT =====
CASE A2A A2A = TMAX+OBED
COMMENT *****
COMMENT A FACTOR OF EC/EH =1.0282 IS APPLIED TO TMAX PER
COMMENT NC-3672.6 Ec=27.9E6 T=70 & Eh=27.136E6 T=366, CARBON STEEL
COMMENT *****
COMBINE TMAX ABS 1.0282 OBED ABS
CASE A-2 MAX.(TMAX+MXEQD, 2 X OBED)
MAXIMUM ABS A2A OBED 2.0
PRINT NO NO NO NO
COMMENT *****
COMMENT L.C. A-2 USES MAX OF OBED/SSED, THUS A-3 IS ENVELOPED BY A-2
COMMENT *****
CASE A3A A3A = TMAX1+MXEQD
COMMENT *****
COMMENT A FACTOR OF EC/EH = 1.0282 IS APPLIED TO TMAX1 PER
COMMENT NC-3672.6 Ec=27.9E6 T=70 & Eh=27.136E6 T=366, CARBON STEEL
COMMENT *****
COMBINE TMAX1ABS 1.0282 MXEQDABS
PRINT NO NO NO NO
CASE A-3 MAX.(TMAX1+MXEQD, 2 X MXEQD)
MAXIMUM ABS A3A MXEQD 2.0
PRINT NO NO NO NO
COMMENT *****
CASE A4A
COMBINE TE2T ABS MXEQDABS
COMMENT =====
CASE A-4
MAXIMUM ABS A4A MXEQD 2.0
PRINT NO NO NO NO
COMMENT *****
END LOADS
COMMENT *****
RESTART
RESTORE LMOD2
SAVE LMOD3
END RESTR
/*EOR
```



CJM,F2.

USER(NU134WC,XNUTECH)  
CHARGE,F3395JT,\*311\*XPS080503.  
ROUTE(OUTPUT,DEF,DC=PR,FID=CJM40,ID)  
SETTL,\*.  
SETJSL,\*.  
REWIND,OUTPUT.

\*  
\*\*\*\*\*  
\* RESTART, INPUT, AND OUTPUT+DAYFILE ARE SAVED \*  
\* IN THE FOLLOWING TAPE, IN THAT ORDER. \*  
\*\*\*\*\*

COPYBR,INPUT,SYSLN.  
REWIND,SYSLN.  
GET,APPLIC/UN=LIBRARY.  
BEGIN,PISTARR,APPLIC,LEVEL=351,NOTES=N,TSAVE=201DW.  
/\*EOR

TITLE HPCI TURBINE EXHAUST (P201)NORMAL LOADS MODEL.  
COMMENT THIS MODEL REFLECT AS BUILT CHANGE PER BECHTEL CALC NO.  
COMMENT C31-6Q INCLUDING LATEST SUPPORT/VALVE DWG'S LINE INDEX.  
COMMENT \*\*\*\*\*

COMMENT FILE: C31DWT  
COMMENT \*\*\*\*\*  
COMMENT AS BUILT CHANGES WITH ALL SNUBBER REMAIN  
COMMENT \*\*\*\*\*

ID CLIENT = PUBLIC SERVICE ELECTRIC AND GAS COMPANY  
ID PROJECT NAME = HOPE CREEK SNUBBER REDUCTION  
ID PROJECT NUMBER = XPS-08  
ID FILE NUMBER = PSE005.1016  
ID CALCULATION NO = C-31  
ID RUN NO =  
ID PREPARED BY = C. J. MEHTA  
ID CHECKED BY = A. S. HERLEKAR

COMMENT \*\*\*\*\*  
COMMENT PISTAR GEOMETRY DEFINITION INPUT GROUP  
COMMENT \*\*\*\*\*

GEOMETRY HPCI TURBINE EXHAUST (006-HBB-24",20")(014-HBB-16")  
START I1CAP 120.0 750.0 -682.0 70.0 386.4 Y  
COMMENT \*\*\*\*\*  
COMMENT REF. DWG. 1-P-FD-01 REV. 19 & PDM DWG. 51  
COMMENT \*\*\*\*\*

CLASS 2  
DESIGN I1CAP155 366.0 155.0  
DESIGN 160 210 366.0 175.0  
COMMENT \*\*\*\*\*  
COMMENT PIPING AND SUPPORT DEFINITION INPUT GROUP  
COMMENT \*\*\*\*\*

PIPE I1CAPI2SPA0.0 15.21 -15.21 11 1  
ADD WEIGHT I1CAP 105.0 105.0 105.0  
SIF I1CAP 2.0

COMMENT	END CAP WEIGHT(FROM TUBE TURNS CATALOG)							
PIPE	I2SPAI3SPA0.0		15.21		-15.21		11	1
PIPE	I3SPAI4SPA0.0		15.21		-15.21		12	1
PIPE	I4SPAI5SUP0.0		8.485		-8.485		10	1
SIF	I5SUP	1.9						
PIPE	I5SUP I5EA	2.093	-8.485		-8.22		16	1
PIPE	I5EA I1SAP	1.395	-5.657		-5.48		13	1
STIFFNESS	I1SAPI1SA2	0.1744	-0.7071		-0.685	DCOSINE		1
MATRIX	1	K11 1.0E8		K22 1.0E8		K33 1.0E8		
MATRIX	1	K44 1.0E3		K55 1.0E3		K66 1.0E2		
PIPE	I1SA2 I2SA	1.395	-5.657		-5.48		13	1
PIPE	I2SA I3SA	3.122	-12.657		-12.27		14	1
PIPE	I3SA I4SA	3.122	-12.657		-12.27		14	1
PIPE	I4SA I5SA	3.663	-14.849		-14.39		15	1
PIPE	I5SA I6SAP	1.395	-5.657		-5.48		13	1
STIFFNESS	I6SAPI6SA2	0.1774	-0.7071		-0.685	DCOSINE		1
PIPE	I6SA2I7SAN	1.134	-4.596		-4.45		13	1
RESTRAINT	I7SANTRAN	.9808	0.0		.1951	SPRING	1.0E8	
RESTRAINT	I7SANTRAN	-.1379	-0.707		.6935	SPRING	1.0E8	
RESTRAINT	I7SANTRAN	.1379	-0.707		-.6935	SPRING	1.0E8	
RESTRAINT	I7SANROT	0.9808	0.0		0.1951	SPRING	1.0E10	
RESTRAINT	I7SANROT	-.1379	-0.707		.6935	SPRING	1.0E10	
RESTRAINT	I7SANROT	.1379	-0.707		-0.6935	SPRING	1.0E10	
SIF	I7SAN	2.1						
PIPE	I5SUP I5EB	-6.62	-8.49		-5.31		16	1
PIPE	I5EB I1SBP	-4.41	-5.66		-3.54		13	1
STIFFNESS	I1SBPI1SB2	-0.5515	-0.7071		-0.442	DCOSINE		1
PIPE	I1SB2 I2SB	-4.41	-5.66		-3.54		13	1
PIPE	I2SB I3SB	-13.53	-17.35		-10.86		14	1
PIPE	I3SB I4SB	-11.18	-14.33		-8.97		14	1
PIPE	I4SB I5SB	-11.18	-14.33		-8.97		14	1
PIPE	I5SB I6SB	-14.02	-17.97		-11.25		14	1
PIPE	I6SB I7SB	-11.58	-14.85		-9.29		15	1
PIPE	I7SB I8SBP	-4.41	-5.66		-3.54		13	1
STIFFNESS	I8SBPI8SB2	-0.5515	-0.7071		-0.442	DCOSINE		1
PIPE	I8SB2I9SBN	-3.59	-4.60		-2.87		13	1
RESTRAINT	I9SBNTRAN	1.0	0.0		0.0	SPRING	1.0E8	
RESTRAINT	I9SBNTRAN	0.0	-0.707		0.707	SPRING	1.0E8	
RESTRAINT	I9SBNTRAN	0.0	-0.707		-0.707	SPRING	1.0E8	
RESTRAINT	I9SBNROT	1.0	0.0		0.0	SPRING	1.0E10	
RESTRAINT	I9SBNROT	0.0	-0.707		0.707	SPRING	1.0E10	
RESTRAINT	I9SBNROT	0.0	-0.707		-0.707	SPRING	1.0E10	
SIF	I9SBN	2.1						
PIPE	I5SUP I6	0.0	6.72		-6.72		10	1
PIPE	I6 I7	0.0	15.21		-15.21		10	1
PIPE	I7 I8	0.0	15.21		-15.21		10	1
PIPE	I8 I9WAT0.0		15.21		-15.21		10	1
PIPE	I9WATI10	0.0	43.58		-43.58		17	1
ELBOW	I10 INNOZ	36.0					17	1
SIF	INNOZ P201	1.9						
PIPE	INNOZP201	0.0	0.0		-28.5		17	1

```

COMMENT *****
COMMENT P201 STIFFNESSES ARE FOR STIFNNED TORUS
COMMENT *****
RESTRAINT P201 TRAN 1.0      0.0      0.0      SPRING      31.60E6
RESTRAINT P201 TRAN 0.0      -0.9848  -0.1736  SPRING      5.120E6
RESTRAINT P201 TRAN 0.0      0.1736   -0.9848  SPRING      1.470E6
RESTRAINT P201 ROT  1.0      0.0      0.0      SPRING      15.70E6
RESTRAINT P201 ROT  0.0      -0.9848  -0.1736  SPRING      15.66E6
RESTRAINT P201 ROT  0.0      0.1736   -0.9848  SPRING      2.970E6
PIPE      P201 EXNOZ0.0      0.0      -46.5     17      1
SIF      EXNOZ P201      1.9
SIF      P201      2.1
ELBOW    EXNOZ10      36.0      1      1
PIPE     10      12      -55.50    0.69     0.0      1      1
PIPE     12      15      -55.50    0.69     0.0      1      1
ELBOW    15      20      36.0      1      1
REDUCER  20      25      0.0      56.00    0.0      2      1
PIPE     25      26BR 0.0      33.375   0.0      3      1
COMMENT *****
COMMENT 26BR IS 3" BRANCH LINE CONT. ON 1-P-BC-06 (P-204)
COMMENT *****
PIPE     26BR 27BR 0.0      20.25    0.0      3      1
PIPE     27BR H19 0.0      12       0.0      3      1
COMMENT *****
COMMENT 27BR IS 3" WELD CAP.
COMMENT *****
SIF      27BR      3.6
SIF      26BR      3.6
HANGER   H19      4940.0    SPRING    1800.0
SIF      H19      2.0
PIPE     H19      30      0.0      43.5     0.0      3      1
ELBOW    30      35      30.0      3      1
PIPE     35      H18     -33.00    0.29975  0.0      3      1
COMMENT *****
COMMENT SNUBBER NO. 1-P-FD-006-H18 AT NODE H18
COMMENT SNUBBER IS REMAIN
COMMENT *****
RESTRAINT H18      0.0      1.0      0.0      SPRING    2.59E5
PIPE     H18      H17     -5.1875   0.048    0.0      3      1
RESTRAINT H17      0.0      0.0      1.0      SPRING    1.320E6
COMMENT 500LBS IS BEING APPLIED AS THE CONCENTRATED WEIGHT.
COMMENT FOR THE PSA 35 SNUBBERS AND CLAMPS.REF PSA CATALOG.
ADD WEIGHTH18      500.0    500.0    500.0
PIPE     H17      40      -3.8125   0.055    0.0      3      1
SIF      40      1.9
VALVE    40      45      -13.999   0.127    0.0      4      1
VALVE    45      VBCG 0.0      16.4     0.0      4      1
ADD WEIGHTVBCG     2640.0    2640.0    2640.0
VALVE    VBCG H22 0.0      34.35    0.0      5      1
COMMENT *****
COMMENT SNUBBER NO. 1-P-006-H22 AT NODE H22 (WAS 45CGS)
    
```

```

TANGENT 85 TIP 30.00 0.0 0.0
ELBOW 85 90 30.0 3 1
COMMENT *****
COMMENT IT IS ASSUMED THAT THE BELLOWS ARE NEXT TO THE WALL
COMMENT AND THE WALL IS APPROX 50 IN. FROM ELBOW WELD
PIPE 90 95BELO.0 -0.9 -80.0 3 1
SIF 95BEL 2.0
COMMENT *****
RESTRAINT 95BELTRAN 0.0 0.0 -1.0 SPRING 310.0
RESTRAINT 95BELTRAN 0.0 1.0 0.0 SPRING 1825.0
RESTRAINT 95BELTRAN 1.0 0.0 0.0 SPRING 1825.0
RESTRAINT 95BELROT 0.0 0.0 -1.0 SPRING 6.67E4
RESTRAINT 95BELROT 0.0 1.0 0.0 SPRING 6.67E4
RESTRAINT 95BELROT 1.0 0.0 0.0 SPRING 6.67E4
ADD WEIGHT 95BEL 135.0 135.0 135.0
PIPE 95BELHS 0.0 -0.5 -50.0 3 1
HANGER HB 2860.0 SPRING 1200.0
PIPE HB 91 0.0 -0.233 -21.00 3 1
SIF 91 1.0
COMMENT *****
COMMENT CONNECTION PT/N056A IS AT NODE 91
COMMENT *****
COMMENT 1" DIA LINE 006-HBB-1" (PTN056E) AT NODE 92
COMMENT *****
PIPE 91 H7 0.0 0.05 -3.5 3 1
COMMENT *****
COMMENT SNUBBER NO. 1-P-FD-006-H07 AT NODE H7
COMMENT SNUBBER IS DELETED
COMMENT *****
SNUBBER H7 1.0 0.0 0.0 SPRING 0.00000
PIPE H7 92 0.0 0.094 -8.5 3 1
SIF 92 1.0
COMMENT *****
COMMENT 1" DIA LINE
COMMENT *****
PIPE 92 100T 0.0 -0.503 -36.00 3 1
PIPE 100T 105 0.0 -0.819 -66.875 3 1
PIPE 105 H6 0.0 -0.819 -66.875 3 1
SIF 100T 2.95
RESTRAINT H6 0.0 0.0 1.0 SPRING 1.402E6
SIF H6 2.0
PIPE H6 H5A 0.0 -0.082 -18.25 3 1
COMMENT *****
COMMENT SNUBBER NO. 1-P-FD-006-H05 AT NODE H5A.
COMMENT SNUBBER IS DELETED
COMMENT *****
SNUBBER H5A 1.0 0.0 0.0 SPRING 0.00000
PIPE H5A H4A 0.0 -0.122 -10.750 3 1
RESTRAINT H4A 0.0 1.0 0.0 SPRING 6.160E5
PIPE H4A 110 0.0 -0.408 -36.00 3 1
ELBOW 110 115 30.0 3 1
    
```

```

COMMENT SNUBBER IS REMAIN
*****
RESTRAINT H22 0.0 0.0 1.0 SPRING 8.700E4
ADD WEIGHTH22 150.0 150.0 150.0
VALVE H22 45CG00.0 14.25 0.0 5 1
ADD WEIGHT45CG0 310.0 310.0 310.0
VALVE 45 50 -13.999 0.127 0.0 4 1
SIF 50 1.9
PIPE 50 H14 -3.25 0.030 0.0 3 1
PIPE H14 H15 -5.0 0.020 0.0 3 1
COMMENT *****
COMMENT SNUBBER NO. 1-P-FD-006-H15 AT NODE H15.
COMMENT SNUBBER IS REMAIN
COMMENT *****
RESTRAINT H15 0.0 1.0 0.0 SPRING 4.950E5
RESTRAINT H14 0.0 0.0 1.0 SPRING 3.491E6
ADD WEIGHTH15 500.0 500.0 500.0
COMMENT *****
COMMENT 1" DIA LINE 1-P-FD-211 @ NODE 54BR
COMMENT *****
PIPE H15 54BR -3.25 0.030 0.0 3 1
PIPE 54BR 55 -3.0 0.027 3 1
VALVE 55 60 -38.498 0.350 0.0 6 1
SIF 55 1.9
SIF 54BR 1.0
PIPE 60 H13 -6.625 0.060 0.0 3 1
SIF 60 1.9
RESTRAINT H13 0.0 1.0 0.0 SPRING 4.8E5
PIPE H13 65 -35.375 0.322 0.0 3 1
ELBOW 65 70 30.0 3 1
PIPE 70 H11 0.0 -40.0 0.0 3 1
RESTRAINT H11 -0.7844 0.0 -0.6202 SPRING 1.750E6
PIPE H11 H12 0.0 -16.5 0.0 3 1
RESTRAINT H12 0.4524 0.0 -0.8918 SPRING 3.066E6
PIPE H12 75 0.0 -51.0 0.0 3 1
PIPE 75 H10 0.0 -48.5 0.0 3 1
COMMENT *****
COMMENT SNUBBER NO 1-P-006-H10 AT NODE H10.
COMMENT SNUBBER IS DELETED
COMMENT *****
SNUBBER H10 1.0 0.0 0.0 SPRING 0.00000
PIPE H10 H9 0.0 -14.82 0.0 3 1
COMMENT *****
COMMENT SNUBBER NO 1-P-FD-006-H09 AT NODE H9
COMMENT SNUBBER IS DELETED
COMMENT *****
SNUBBER H9 0.2801 0.0 -0.96 SPRING 0.0000
PIPE H9 78 0.0 -54.0 0.0 3 1
PIPE 78 80 0.0 -54.0 0.0 3 1
ELBOW 80 85 30.0 3 1
TANGENT TIP 85 30.00 0.0 0.0
    
```

PIPE	115	120	55.750	-0.578	0.0		3	1
PIPE	120	H3A	82.00	-0.891	0.0		3	1
COMMENT	*****							
COMMENT	SNUBBER NO 1-P-FD-006-H03 AT NODE H3A.							
COMMENT	SNUBBER IS DELETED							
COMMENT	*****							
SNUBBER	H3A		0.0767	0.0	-0.9965	SPRING		0.000000
PIPE	H3A	125T	18.25	-0.156	0.0		3	1
PIPE	125T	H2A	30.00	-0.312	0.0		3	1
COMMENT	*****							
COMMENT	SNUBBER NO 1-P-FD-006-H02 AT NODE H2A.							
COMMENT	SNUBBER IS DELETED							
COMMENT	*****							
SNUBBER	H2A		0.0	1.0	0.0	SPRING		0.000000
PIPE	H2A	H1A	6.0	-0.063	0.0		3	1
HANGER	H1A				2158.0	SPRING		900.0
PIPE	H1A	130	36.00	-0.375	0.0		3	1
ELBOW	130	135	30.0				3	1
PIPE	135	140T	0.0	-77.313	0.0		3	1
PIPE	140T	145CP	0.0	-21.0	0.0		3	1
COMMENT	*****							
COMMENT	SMALL BRANCHES 1IN AND 2IN CLOSE TO NODE 145CP.							
COMMENT	THESE ARE SBP 1-P-FD-201, 207, 208 & 234							
COMMENT	SIF FOR BUTT WELD AT NODE 145CP							
COMMENT	*****							
SIF	145CP		1.8					
ADD WEIGHT	145CP		79.0	79.0	79.0			
COMMENT	*****							
COMMENT	END OF MODEL.007.HBB-1,"AT 4" BLIND FLANGE.							
COMMENT	*****							
PIPE	140T	HPTUB	0.0	0.0	20.75		9	1
SIF	140T		2.95					
COMMENT	HPCI TURBINE							
ADD WEIGHT	HPTUB		306.0	306.0	306.0			
RESTRAINT	HPTUBTRAN	1.0	0.0	0.0	0.0	SPRING		1.0E8
RESTRAINT	HPTUBTRAN	0.0	1.0	0.0	0.0	SPRING		1.0E8
RESTRAINT	HPTUBTRAN	0.0	0.0	1.0	0.0	SPRING		1.0E8
RESTRAINT	HPTUBROT	1.0	0.0	0.0	0.0	SPRING		1.0E12
RESTRAINT	HPTUBROT	0.0	1.0	0.0	0.0	SPRING		1.0E12
RESTRAINT	HPTUBROT	0.0	0.0	1.0	0.0	SPRING		1.0E12
SIF	HPTUB		2.10					
PIPE	125T	155	0.0	0.0	-17.125		8	1
SIF	125T		2.95					
ADD WEIGHT	155		112.0	112.0	112.0			
SIF	155		1.9					
COMMENT	*****							
COMMENT	1-P-FD-014-HBB-16" BR LINE							
COMMENT	*****							
PIPE	100T	160	0.0	14.0	0.0		7	1
SIF	160		1.90					
SIF	165		1.90					

PIPE	160	162	0.0	5.00	0.0	7	1
PIPE	162	163	0.0	11.0	0.0	7	1
COMMENT	*****						
COMMENT	1" VENT TO TORUS COMPARTMENT (SBP 1-F-FD-204)						
COMMENT	*****						
SIF	163		1.0				
PIPE	163	165	0.0	7.0625	0.0	7	1
ADD WEIGHT	160		282.0	282.0	282.0		
ADD WEIGHT	165		282.0	282.0	282.0		
PIPE	165	170	0.0	34.0	0.0	7	1
ELBOW	170	175	24.0			7	1
PIPE	175	H2B	0.0	0.353	34.0	7	1
COMMENT	*****						
COMMENT	SNUBBER NO 1-P-FD-014-H02 AT NODE H2B.						
COMMENT	SNUBBER IS REMAIN (PAIR)						
COMMENT	*****						
RESTRAINT	H2B		0.0	0.0	1.0	SPRING	2.530E5
SIF	H2B		2.0				
PIPE	H2B	H1B	0.0	0.145	13.999	7	1
RESTRAINT	H1B		1.0	0.0	0.0	SPRING	3.41E6
RESTRAINT	H1B		0.0	1.0	0.0	SPRING	3.41E6
SIF	H1B		2.0				
PIPE	H1B	180BL	0.0	0.501	48.330	7	1
COMMENT	*****						
COMMENT	IT IS ASSUMED THAT THE BELLOWS ARE ABOUT 4FT FROM						
COMMENT	THE SUPPORT H-01 ON 16IN LINE.						
COMMENT	*****						
RESTRAINT	180BLTRAN		0.0	0.0	1.0	SPRING	260.0
RESTRAINT	180BLTRAN		0.0	1.0	0.0	SPRING	1250.0
RESTRAINT	180BLTRAN		1.0	0.0	0.0	SPRING	1250.0
RESTRAINT	180BLROT		0.0	0.0	1.0	SPRING	5.13E4
RESTRAINT	180BLROT		0.0	1.0	0.0	SPRING	5.13E4
RESTRAINT	180BLROT		1.0	0.0	0.0	SPRING	5.13E4
SIF	180BL		2.0				
ADD WEIGHT	180BL		130.0	130.0	130.0		
PIPE	180BL	185	0.0	0.501	48.330	7	1
PIPE	185	H3B	0.0	0.501	48.330	7	1
RESTRAINT	H3B		0.0	1.0	0.0	SPRING	8.34E5
PIPE	H3B	190	0.0	0.37	35.998	7	1
ELBOW	190	195	24.0			7	1
PIPE	195	200	0.0	70.208	0.0	7	1
PIPE	200	205	0.0	46.208	0.0	7	1
PIPE	205	H5B	0.0	46.208	0.0	7	1
PIPE	H5B	H4B	0.0	5.50	0.0	7	1
RESTRAINT	H5B		-0.5210	0.0	-0.8535	SPRING	3.85E5
RESTRAINT	H4B		0.6264	0.0	-0.7795	SPRING	5.16E5
PIPE	H4B	210	0.0	51.500	0.0	7	1
COMMENT	END OF MODEL. SEE DWG. 1-F-FD-01 REV.19						
COMMENT	*****						
COMMENT	HYDROSTATIC LOAD ON INTERNAL SUBMERGED PIPING						
COMMENT	*****						

ADD WEIGHTI1CAP	173.5	123.0	123.0
ADD WEIGHTI2SPA	346.9	245.0	245.0
ADD WEIGHTI3SPA	346.9	245.0	245.0
ADD WEIGHTI4SPA	270.0	191.0	191.0
ADD WEIGHTI5SUP	199.0	199.00	199.00
ADD WEIGHTI6	250.0	177.0	177.0
ADD WEIGHTI7	346.9	245.0	245.0
ADD WEIGHTI8	346.9	245.0	245.0
ADD WEIGHTI9WAT	173.5	123.0	123.0

COMMENT \*\*\*\*\*  
 COMMENT HYDRO LOAD FOR STRUT IS BEING ADDED EQUALLY IN  
 COMMENT ALL THREE DIRECTIONS BECAUSE IT IS SMALL.(CONSERVATIVE)  
 COMMENT \*\*\*\*\*

ADD WEIGHTI1SAP	25.9	25.9	25.9
ADD WEIGHTI2SA	41.9	41.9	41.9
ADD WEIGHTI3SA	57.9	57.9	57.9
ADD WEIGHTI4SA	76.7	76.7	76.7
ADD WEIGHTI5SA	60.7	60.7	60.7
ADD WEIGHTI6SAP	23.5	23.5	23.5
ADD WEIGHTI7SAN	10.5	10.5	10.5

COMMENT STRUT TWO

ADD WEIGHTI1SBP	25.9	25.9	25.9
ADD WEIGHTI2SB	52.6	52.6	52.6
ADD WEIGHTI3SB	72.5	72.5	72.5
ADD WEIGHTI4SB	65.6	65.6	65.6
ADD WEIGHTI5SB	73.9	73.9	73.9
ADD WEIGHTI6SB	88.9	88.9	88.9
ADD WEIGHTI7SB	60.7	60.7	60.7
ADD WEIGHTI8SBP	23.5	23.5	23.5
ADD WEIGHTI9SBN	10.5	10.5	10.5

COMMENT \*\*\*\*\*

COMMENT \*\*\*\*\*

COMMENT PROPERTY AND MATERIAL DEFINITION

COMMENT \*\*\*\*\*

PROPERTY 1				24.0SCH20 WATER	1.60
PROPERTY 2	22.0	0.375	8.1	24X20RED WATER	1.48
PROPERTY 3				20.0SCH20 WATER	1.36
PROPERTY 4	20.75	0.75	00.000	V006BODY WATER	1.36
PROPERTY 5	6.70	0.750	0.0	V006 OP	
PROPERTY 6	20.75	0.75	46.75	V004 WATER	1.36
PROPERTY 7				16.0SCH30 WATER	1.12
PROPERTY 8				10.0SCH40 WATER	0.80
PROPERTY 9	18.0	0.375	5.88	WATER	1.36
PROPERTY 10				24.0SCH80 WATER	
PROPERTY 11	24.0	0.50	10.417	WATER	
PROPERTY 12				24.0SCH40 WATER	
PROPERTY 13				10.0SCH100	
PROPERTY 14				10.0SCH160	
PROPERTY 15				12.0SCH140	
PROPERTY 16	24.0	1.218	0.0	WTLESS	
PROPERTY 17				24.0SCH80 WATER	



MATERIAL 1 CARBON  
END GEOM  
COMMENT  
LOADING  
COMMENT  
CASE DWT DEAD WEIGHT HYDRO TEST  
DEAD LOAD  
END LOADS  
COMMENT \*\*\*\*\*  
EVALUATE  
COMMENT \*\*\*\*\*  
COMMENT \*\*\*\*\* LEVELS A EVALUATION \*\*\*\*\*  
COMMENT \*\*\*\*\*  
CODE CLASS 2 DESIGN 77ED S77  
COMMENT \*\*\*\*\*  
COMMENT \*\*\*\*\* L.C. A-1 IS EQN. 8 BELOW \*\*\*\*\*  
COMMENT \*\*\*\*\*  
EQUATION 8 DWT  
COMMENT \*\*\*\*\*  
COMMENT FOR HYDRO TEST DESIGN PRESSURE =1.25 X P (=155)=194. \*\*  
COMMENT FOR HYDRO TEST DESIGN PRESSURE =1.25 X P (=175)=219. \*\*  
COMMENT \*\*\*\*\*  
PEAK PRES IICAP 155 194.0  
PEAK PRES 160 210 219.0  
ALLOWABLE 1 15000. 15000.  
COMMENT \*\*\*\*\*  
D CODE  
RESTART  
SAVE 201DW  
END RESTR  
/\*EOR

CJM,P3.

USER(NU134WC,XNUTECH)  
CHARGE,F3395JT,\*311\*XPS080501.  
ROUTE(OUTPUT,DEF,DC=PR,FID=CJM40,ID)  
SETTL,\*  
SETJSL,\*  
REWIND,OUTPUT.

\*  
\*\*\*\*\*  
\* RESTART, INPUT, AND OUTPUT+DAYFILE ARE SAVED \*  
\* IN THE FOLLOWING TAPE, IN THAT ORDER. \*  
\*\*\*\*\*  
COPYBR,INPUT,SYISIN.

REWIND,SYISIN.  
GET,APPLIC/UN=LIBRARY.  
BEGIN,PISTARR,APPLIC,LEVEL=351,NOTES=N,TSAVE=201R,  
PTAPE,ROUTE=NES01.  
GOTO,1.  
EXIT.  
1,REWIND,TAPE14,TAPE16.  
TRS(LFN=TAPE,OP=W,D=PE,L=\$P201\_RPDISK\$,SYM=P201RP,CT=PU)  
COPYBF,TAPE14,TAPE.  
COPYBF,TAPE16,TAPE.

\*\*\*\*\*  
\* ATTACH PISTAR MODEL IMMEDIATELY BELOW "/EOR", \*  
\* FOLLOWED BY LOAD MODULE-1 \*  
\*\*\*\*\*

/\*EOR

TITLE HFCI TURBINE EXHAUST (P201) RUPTURE OF PRESSURE RELIEF DISK  
COMMENT THIS MODEL REFLECT AS BUILT CHANGE PER BECHTEL CALC NO.  
COMMENT C31-6Q INCLUDING LATEST SUPPORT/VALVE DWG'S LINE INDEX.  
COMMENT \*\*\*\*\*  
COMMENT \*\*\*\*\*  
COMMENT \*\*\*\*\*  
COMMENT \* FILE NAME : C31RUP \*  
COMMENT \*\*\*\*\*

ID CLIENT = PUBLIC SERVICE ELECTRIC AND GAS COMPANY  
ID PROJECT NAME = HOPE CREEK SNUBBER REDUCTION  
ID PROJECT NUMBER = XPS-08  
ID FILE NUMBER = PSE005.1016  
ID CALCULATION NO = C-31  
ID RUN NO =  
ID PREPARED BY = C. J. MEHTA  
ID CHECKED BY = A. S. HERLEKAR

COMMENT \*\*\*\*\*  
COMMENT PISTAR GEOMETRY DEFINITION INPUT GROUP  
COMMENT \*\*\*\*\*

GEOMETRY HFCI TURBINE EXHAUST (006-HBB-24",20")(014-HBB-16")  
START I1CAP 120.0 750.0 -682.0 70.0 386.4 Y  
COMMENT \*\*\*\*\*

COMMENT	REF. DWG. 1-P-FD-01 REV. 19 & PDM DWG. 51									
COMMENT	*****									
CLASS 2										
DESIGN	I1CAP155	366.0	155.0							
DESIGN	160 210	366.0	175.0							
COMMENT	*****									
COMMENT	PIPING AND SUPPORT DEFINITION INPUT GROUP									
COMMENT	*****									
PIPE	I1CAPI2SPA0.0	15.21	-15.21	11	1					
ADD WEIGHT	I1CAP	105.0	105.0	105.0						
SIF	I1CAP	2.0								
COMMENT	END CAP WEIGHT(FROM TUBE TURNS CATALOG)									
PIPE	I2SPAI3SPA0.0	15.21	-15.21	11	1					
PIPE	I3SPAI4SPA0.0	15.21	-15.21	12	1					
PIPE	I4SPAI5SUP0.0	8.485	-8.485	10	1					
SIF	I5SUP	1.9								
PIPE	I5SUP I5EA	2.093	-8.485	-8.22	16	1				
PIPE	I5EA I1SAP	1.395	-5.657	-5.48	13	1				
STIFFNESS	I1SAPI1SA2	0.1744	-0.7071	-0.685	DCOSINE	1				
MATRIX	1	K11	1.0E8	K22	1.0E8	K33	1.0E8			
MATRIX	1	K44	1.0E3	K55	1.0E3	K66	1.0E2			
PIPE	I1SA2 I2SA	1.395	-5.657	-5.48	13	1				
PIPE	I2SA I3SA	3.122	-12.657	-12.27	14	1				
PIPE	I3SA I4SA	3.122	-12.657	-12.27	14	1				
PIPE	I4SA I5SA	3.663	-14.849	-14.39	15	1				
PIPE	I5SA I6SAP	1.395	-5.657	-5.48	13	1				
STIFFNESS	I6SAPI6SA2	0.1774	-0.7071	-0.685	DCOSINE	1				
PIPE	I6SA2I7SAN	1.134	-4.596	-4.45	13	1				
RESTRAINT	I7SANTRAN	.9808	0.0	.1951	SPRING	1.0E8				
RESTRAINT	I7SANTRAN	-.1379	-0.707	.6935	SPRING	1.0E8				
RESTRAINT	I7SANTRAN	.1379	-0.707	-.6935	SPRING	1.0E8				
RESTRAINT	I7SANROT	0.9808	0.0	0.1951	SPRING	1.0E10				
RESTRAINT	I7SANROT	-.1379	-0.707	.6935	SPRING	1.0E10				
RESTRAINT	I7SANROT	.1379	-0.707	-0.6935	SPRING	1.0E10				
SIF	I7SAN	2.1								
PIPE	I5SUP I5EB	-6.62	-8.49	-5.31	16	1				
PIPE	I5EB I1SBP	-4.41	-5.66	-3.54	13	1				
STIFFNESS	I1SBPI1SB2	-0.5515	-0.7071	-0.442	DCOSINE	1				
PIPE	I1SB2 I2SB	-4.41	-5.66	-3.54	13	1				
PIPE	I2SB I3SB	-13.53	-17.35	-10.86	14	1				
PIPE	I3SB I4SB	-11.18	-14.33	-8.97	14	1				
PIPE	I4SB I5SB	-11.18	-14.33	-8.97	14	1				
PIPE	I5SB I6SB	-14.02	-17.97	-11.25	14	1				
PIPE	I6SB I7SB	-11.58	-14.85	-9.29	15	1				
PIPE	I7SB I8SBP	-4.41	-5.66	-3.54	13	1				
STIFFNESS	I8SBPI8SB2	-0.5515	-0.7071	-0.442	DCOSINE	1				
PIPE	I8SB2I9SBN	-3.59	-4.60	-2.87	13	1				
RESTRAINT	I9SBNTRAN	1.0	0.0	0.0	SPRING	1.0E8				
RESTRAINT	I9SBNTRAN	0.0	-0.707	0.707	SPRING	1.0E8				
RESTRAINT	I9SBNTRAN	0.0	-0.707	-0.707	SPRING	1.0E8				
RESTRAINT	I9SBNROT	1.0	0.0	0.0	SPRING	1.0E10				

RESTRAINT	I95BNROT	0.0		-0.707	0.707	SPRING	1.0E10	
RESTRAINT	I95BNROT	0.0		-0.707	-0.707	SPRING	1.0E10	
SIF	I95BN		2.1					
PIPE	I5SUP16	0.0		6.72	-6.72		10	1
PIPE	I6 I7	0.0		15.21	-15.21		10	1
PIPE	I7 I8	0.0		15.21	-15.21		10	1
PIPE	I8 I9WAT0	0.0		15.21	-15.21		10	1
PIPE	I9WATI10	0.0		43.58	-43.58		17	1
ELBOW	I10 INNOZ36	0.0					17	1
SIF	INNOZ P201		1.9					
PIPE	INNOZP201	0.0		0.0	-28.5		17	1
RESTRAINT	P201 TRAN	1.0		0.0	0.0	SPRING	31.60E6	
RESTRAINT	P201 TRAN	0.0		-0.9848	-0.1736	SPRING	5.120E6	
RESTRAINT	P201 TRAN	0.0		0.1736	-0.9848	SPRING	1.470E6	
RESTRAINT	P201 ROT	1.0		0.0	0.0	SPRING	15.70E6	
RESTRAINT	P201 ROT	0.0		-0.9848	-0.1736	SPRING	15.66E6	
RESTRAINT	P201 ROT	0.0		0.1736	-0.9848	SPRING	2.970E6	
PIPE	P201 EXNOZ0	0.0		0.0	-46.5		17	1
SIF	EXNOZ P201		1.9					
SIF	P201		2.1					
ELBOW	EXNOZ10	36.0					1	1
PIPE	10 12	-55.50		0.69	0.0		1	1
PIPE	12 15	-55.50		0.69	0.0		1	1
ELBOW	15 20	36.0					1	1
REDUCER	20 25	0.0		56.00	0.0		2	1
PIPE	25 26BR	0.0		33.375	0.0		3	1
COMMENT	*****							
COMMENT	26BR IS 3" BRANCH LINE CONT. ON 1-P-BC-06 (P-204)							
COMMENT	*****							
PIPE	26BR 27BR	0.0		20.25	0.0		3	1
PIPE	27BR H19	0.0		12	0.0		3	1
COMMENT	*****							
COMMENT	27BR IS 3" WELD CAP.							
COMMENT	*****							
SIF	27BR		3.6					
SIF	26BR		3.6					
HANGER	H19				4940.0	SPRING	1800.0	
SIF	H19		2.0					
PIPE	H19 30	0.0		43.5	0.0		3	1
ELBOW	30 35	30.0					3	1
PIPE	35 H18	-33.00		0.29975	0.0		3	1
COMMENT	*****							
COMMENT	SNUBBER NO. 1-P-FD-006-H18 AT NODE H18							
COMMENT	*****							
SNUBBER	H18	0.0		1.0	0.0	SPRING	2.59E5	
PIPE	H18 H17	-5.1875		0.048	0.0		3	1
RESTRAINT	H17	0.0		0.0	1.0	SPRING	1.320E6	
COMMENT	500LBS IS BEING APPLIED AS THE CONCENTRATED WEIGHT.							
COMMENT	FOR THE PSA 35 SNUBBERS AND CLAMPS.REF PSA CATALOG.							
ADD WEIGH	H18	500.0		500.0	500.0			
PIPE	H17 40	-3.8125		0.055	0.0		3	1

SIF	40		1.9					
VALVE	40	45	-13.999	0.127	0.0		4	1
VALVE	45	VBCG	0.0	16.4	0.0		4	1
ADD WEIGHT	VBCG		2640.0	2640.0	2640.0			
VALVE	VBCG	H22	0.0	34.35	0.0		5	1
COMMENT	*****							
COMMENT	SNUBBER NO. 1-P-006-H22 AT NODE H22 (WAS 45CGS)							
COMMENT	*****							
SNUBBER	H22		0.0	0.0	1.0	SPRING	8.700E4	
ADD WEIGHT	H22		150.0	150.0	150.0			
VALVE	H22	45CGO	0.0	14.25	0.0		5	1
ADD WEIGHT	45CGO		310.0	310.0	310.0			
VALVE	45	50	-13.999	0.127	0.0		4	1
SIF	50		1.9					
PIPE	50	H14	-3.25	0.030	0.0		3	1
PIPE	H14	H15	-5.0	0.020	0.0		3	1
COMMENT	*****							
COMMENT	SNUBBER NO. 1-P-FD-006-H15 AT NODE H15.							
COMMENT	*****							
SNUBBER	H15		0.0	1.0	0.0	SPRING	4.950E5	
RESTRAINT	H14		0.0	0.0	1.0	SPRING	3.491E6	
ADD WEIGHT	H15		500.0	500.0	500.0			
COMMENT	*****							
COMMENT	1" DIA LINE 1-P-FD-211 @ NODE 54BR							
COMMENT	*****							
PIPE	H15	54BR	-3.25	0.030	0.0		3	1
PIPE	54BR	55	-3.0	0.027			3	1
VALVE	55	60	-38.498	0.350	0.0		6	1
SIF	55		1.9					
SIF	54BR		1.0					
PIPE	60	H13	-6.625	0.060	0.0		3	1
SIF	60		1.9					
RESTRAINT	H13		0.0	1.0	0.0	SPRING	4.8E5	
PIPE	H13	65	-35.375	0.322	0.0		3	1
ELBOW	65	70	30.0				3	1
PIPE	70	H11	0.0	-40.0	0.0		3	1
RESTRAINT	H11		-0.7844	0.0	-0.6202	SPRING	1.750E6	
PIPE	H11	H12	0.0	-16.5	0.0		3	1
RESTRAINT	H12		0.4524	0.0	-0.8918	SPRING	3.066E6	
PIPE	H12	75	0.0	-51.0	0.0		3	1
PIPE	75	H10	0.0	-48.5	0.0		3	1
COMMENT	*****							
COMMENT	SNUBBER NO 1-P-006-H10 AT NODE H10.							
COMMENT	*****							
SNUBBER	H10		1.0	0.0	0.0	SPRING	0.00000	
PIPE	H10	H9	0.0	-14.82	0.0		3	1
COMMENT	*****							
COMMENT	SNUBBER NO 1-P-FD-006-H09 AT NODE H9							
COMMENT	*****							
SNUBBER	H9		0.2801	0.0	-0.96	SPRING	0.0000	
PIPE	H9	78	0.0	-54.0	0.0		3	1

PIPE	78	80	0.0	-54.0	0.0		3	1
ELBOW	80	85	30.0				3	1
TANGENT	TIP	85	30.00	0.0	0.0			
TANGENT	85	TIP	30.00	0.0	0.0			
ELBOW	85	90	30.0				3	1
COMMENT	*****							
COMMENT	IT IS ASSUMED THAT THE BELLOWS ARE NEXT TO THE WALL							
COMMENT	AND THE WALL IS APPROX 50 IN. FROM ELBOW WELD							
PIPE	90	95BELO.0		-0.9	-80.0		3	1
SIF	95BEL		2.0					
COMMENT	*****							
RESTRAINT	95BELTRAN	0.0		0.0	-1.0	SPRING		310.0
RESTRAINT	95BELTRAN	0.0		1.0	0.0	SPRING		1825.0
RESTRAINT	95BELTRAN	1.0		0.0	0.0	SPRING		1825.0
RESTRAINT	95BELROT	0.0		0.0	-1.0	SPRING		6.67E4
RESTRAINT	95BELROT	0.0		1.0	0.0	SPRING		6.67E4
RESTRAINT	95BELROT	1.0		0.0	0.0	SPRING		6.67E4
ADD WEIGHT	95BEL		135.0	135.0	135.0			
PIPE	95BELH8	0.0		-0.5	-50.0		3	1
HANGER	H8				2860.0	SPRING		1200.0
PIPE	H8	91	0.0	-0.233	-21.00		3	1
SIF	91		1.0					
COMMENT	*****							
COMMENT	CONNECTION PT/N056A IS AT NODE 91							
COMMENT	*****							
COMMENT	1" DIA LINE 006-HBB-1" (PTN056E) AT NODE 92							
COMMENT	*****							
PIPE	91	H7	0.0	0.05	-3.5		3	1
COMMENT	*****							
COMMENT	SNUBBER NO. 1-P-FD-006-H07 AT NODE H7							
COMMENT	*****							
SNUBBER	H7		1.0	0.0	0.0	SPRING		0.00000
PIPE	H7	92	0.0	0.094	-8.5		3	1
SIF	92		1.0					
COMMENT	*****							
COMMENT	1" DIA LINE							
COMMENT	*****							
PIPE	92	100T	0.0	-0.503	-36.00		3	1
PIPE	100T	105	0.0	-0.819	-66.875		3	1
PIPE	105	H6	0.0	-0.819	-66.875		3	1
SIF	100T		2.95					
RESTRAINT	H6		0.0	0.0	1.0	SPRING		1.402E6
SIF	H6		2.0					
PIPE	H6	H5A	0.0	-0.082	-18.25		3	1
COMMENT	*****							
COMMENT	SNUBBER NO. 1-P-FD-006-H05 AT NODE H5A.							
COMMENT	*****							
SNUBBER	H5A		1.0	0.0	0.0	SPRING		0.00000
PIPE	H5A	H4A	0.0	-0.122	-10.750		3	1
RESTRAINT	H4A		0.0	1.0	0.0	SPRING		6.160E5
PIPE	H4A	110	0.0	-0.408	-36.00		3	1

ELBOW	110	115	30.0				3	1
PIPE	115	120	55.750	-0.578	0.0		3	1
PIPE	120	H3A	82.00	-0.891	0.0		3	1
COMMENT	*****							
COMMENT	SNUBBER NO 1-P-FD-006-H03 AT NODE H3A.							
COMMENT	*****							
SNUBBER	H3A		0.0767	0.0	-0.9965	SPRING		0.000000
PIPE	H3A	125T	18.25	-0.156	0.0		3	1
PIPE	125T	H2A	30.00	-0.312	0.0		3	1
COMMENT	*****							
COMMENT	SNUBBER NO 1-P-FD-006-H02 AT NODE H2A.							
COMMENT	*****							
SNUBBER	H2A		0.0	1.0	0.0	SPRING		0.000000
PIPE	H2A	H1A	6.0	-0.063	0.0		3	1
HANGER	H1A				2158.0	SPRING		900.0
PIPE	H1A	130	36.00	-0.375	0.0		3	1
ELBOW	130	135	30.0				3	1
PIPE	135	140T	0.0	-77.313	0.0		3	1
PIPE	140T	145CP	0.0	-21.0	0.0		3	1
COMMENT	*****							
COMMENT	SMALL BRANCHES 1IN AND 2IN CLOSE TO NODE 145CP.							
COMMENT	THESE ARE SBP 1-P-FD-201, 207, 208 & 234							
COMMENT	SIF FOR BUTT WELD AT NODE 145CP							
COMMENT	*****							
SIF	145CP		1.8					
ADD WEIGHT	145CP		79.0	79.0	79.0			
COMMENT	*****							
COMMENT	END OF MODEL.007.HBB-1,"AT 4" BLIND FLANGE.							
COMMENT	*****							
PIPE	140T	HPTUB	0.0	0.0	20.75		9	1
SIF	140T		2.95					
COMMENT	HPCI TURBINE							
ADD WEIGHT	HPTUB		306.0	306.0	306.0			
RESTRAINT	HPTUBTRAN	1.0	0.0	0.0	0.0	SPRING		1.0E8
RESTRAINT	HPTUBTRAN	0.0	1.0	0.0	0.0	SPRING		1.0E8
RESTRAINT	HPTUBTRAN	0.0	0.0	1.0	0.0	SPRING		1.0E8
RESTRAINT	HPTUBROT	1.0	0.0	0.0	0.0	SPRING		1.0E12
RESTRAINT	HPTUBROT	0.0	1.0	0.0	0.0	SPRING		1.0E12
RESTRAINT	HPTUBROT	0.0	0.0	1.0	0.0	SPRING		1.0E12
SIF	HPTUB		2.10					
PIPE	125T	155	0.0	0.0	-17.125		8	1
SIF	125T		2.95					
ADD WEIGHT	155		112.0	112.0	112.0			
SIF	155		1.9					
COMMENT	*****							
COMMENT	1-P-FD-014-HBB-16" BR LINE							
COMMENT	*****							
PIPE	100T	160	0.0	14.0	0.0		7	1
SIF	160		1.90					
SIF	165		1.90					
PIPE	160	162	0.0	5.00	0.0		7	1

PIPE	162	163	0.0	11.0	0.0		7	1
COMMENT	*****							
COMMENT	1" VENT TO TORUS COMPARTMENT (SBP 1-P-FD-204)							
COMMENT	*****							
SIF	163							
PIPE	163	165	0.0	7.0625	0.0		7	1
ADD WEIGHT	160		282.0	282.0	282.0			
ADD WEIGHT	165		282.0	282.0	282.0			
PIPE	165	170	0.0	34.0	0.0		7	1
ELBOW	170	175	24.0				7	1
PIPE	175	H2B	0.0	0.353	34.0		7	1
COMMENT	*****							
COMMENT	SNUBBER NO 1-P-FD-014-H02 AT NODE H2B.							
COMMENT	*****							
SNUBBER	H2B		0.0	0.0	1.0	SPRING		2.530E5
SIF	H2B		2.0					
PIPE	H2B	H1B	0.0	0.145	13.999		7	1
RESTRAINT	H1B		1.0	0.0	0.0	SPRING		3.41E6
RESTRAINT	H1B		0.0	1.0	0.0	SPRING		3.41E6
SIF	H1B		2.0					
PIPE	H1B	180BL	0.0	0.501	48.330		7	1
COMMENT	*****							
COMMENT	IT IS ASSUMED THAT THE BELLOWS ARE ABOUT 4FT FROM							
COMMENT	THE SUPPORT H-01 ON 16IN LINE.							
COMMENT	*****							
RESTRAINT	180BL	TRAN	0.0	0.0	1.0	SPRING		260.0
RESTRAINT	180BL	TRAN	0.0	1.0	0.0	SPRING		1250.0
RESTRAINT	180BL	TRAN	1.0	0.0	0.0	SPRING		1250.0
RESTRAINT	180BL	ROT	0.0	0.0	1.0	SPRING		5.13E4
RESTRAINT	180BL	ROT	0.0	1.0	0.0	SPRING		5.13E4
RESTRAINT	180BL	ROT	1.0	0.0	0.0	SPRING		5.13E4
SIF	180BL		2.0					
ADD WEIGHT	180BL		130.0	130.0	130.0			
PIPE	180BL	185	0.0	0.501	48.330		7	1
PIPE	185	H3B	0.0	0.501	48.330		7	1
RESTRAINT	H3B		0.0	1.0	0.0	SPRING		8.34E5
PIPE	H3B	190	0.0	0.37	35.998		7	1
ELBOW	190	195	24.0				7	1
PIPE	195	200	0.0	70.208	0.0		7	1
PIPE	200	205	0.0	46.208	0.0		7	1
PIPE	205	H5B	0.0	46.208	0.0		7	1
PIPE	H5B	H4B	0.0	5.50	0.0		7	1
RESTRAINT	H5B		-0.5210	0.0	-0.8535	SPRING		3.85E5
RESTRAINT	H4B		0.6264	0.0	-0.7795	SPRING		5.16E5
PIPE	H4B	210	0.0	51.500	0.0		7	1
COMMENT	END OF MODEL. SEE DWG. 1-P-FD-01 REV.19							
COMMENT	*****							
COMMENT	HYDROSTATIC LOAD ON INTERNAL SUBMERGED PIPING							
COMMENT	*****							
ADD WEIGHT	I1CAP		173.5	123.0	123.0			
ADD WEIGHT	I2SPA		346.9	245.0	245.0			



ADD WEIGHTI3SPA	346.9	245.0	245.0
ADD WEIGHTI4SPA	270.0	191.0	191.0
ADD WEIGHTI5SUP	199.0	199.00	199.00
ADD WEIGHTI6	250.0	177.0	177.0
ADD WEIGHTI7	346.9	245.0	245.0
ADD WEIGHTI8	346.9	245.0	245.0
ADD WEIGHTI9WAT	173.5	123.0	123.0

COMMENT \*\*\*\*\*  
 COMMENT HYDRO LOAD FOR STRUT IS BEING ADDED EQUALLY IN  
 COMMENT ALL THREE DIRECTIONS BECAUSE IT IS SMALL.(CONSERVATIVE)  
 COMMENT \*\*\*\*\*

ADD WEIGHTI1SAP	25.9	25.9	25.9
ADD WEIGHTI2SA	41.9	41.9	41.9
ADD WEIGHTI3SA	57.9	57.9	57.9
ADD WEIGHTI4SA	76.7	76.7	76.7
ADD WEIGHTI5SA	60.7	60.7	60.7
ADD WEIGHTI6SAP	23.5	23.5	23.5
ADD WEIGHTI7SAN	10.5	10.5	10.5

COMMENT STRUT TWO

ADD WEIGHTI1SBP	25.9	25.9	25.9
ADD WEIGHTI2SB	52.6	52.6	52.6
ADD WEIGHTI3SB	72.5	72.5	72.5
ADD WEIGHTI4SB	65.6	65.6	65.6
ADD WEIGHTI5SB	73.9	73.9	73.9
ADD WEIGHTI6SB	88.9	88.9	88.9
ADD WEIGHTI7SB	60.7	60.7	60.7
ADD WEIGHTI8SBP	23.5	23.5	23.5
ADD WEIGHTI9SBN	10.5	10.5	10.5

COMMENT \*\*\*\*\*  
 COMMENT \*\*\*\*\*  
 COMMENT \*\*\*\*\*  
 COMMENT \*\*\*\*\*

PROPERTY AND MATERIAL DEFINITION

PROPERTY 1				24.OSCH20	STEAM	1.60
PROPERTY 2	22.0	0.375	8.1	24X20RED	STEAM	1.48
PROPERTY 3				20.OSCH20	STEAM	1.36
PROPERTY 4	20.75	0.75	00.000	V006BODY	STEAM	1.36
PROPERTY 5	6.70	0.750	0.0	V006	DP	
PROPERTY 6	20.75	0.75	46.75	V004	STEAM	1.36
PROPERTY 7				16.OSCH30	STEAM	1.12
PROPERTY 8				10.OSCH40	STEAM	0.80
PROPERTY 9	18.0	0.375	5.88		STEAM	1.36
PROPERTY 10				24.OSCH80	WATER	
PROPERTY 11	24.0	0.50	10.417		WATER	
PROPERTY 12				24.OSCH40	WATER	
PROPERTY 13				10.OSCH100		
PROPERTY 14				10.OSCH160		
PROPERTY 15				12.OSCH140		
PROPERTY 16	24.0	1.218	0.0	WTLESS		
PROPERTY 17				24.OSCH80	STEAM	
MATERIAL 1				CARBON		

END GEOM

```
COMMENT *****
COMMENT *          LOAD AND CODE EVALUATION MODULE          *
COMMENT *****
COMMENT *****
COMMENT * SNUBBER REMAIN          : 006-H1B,H22,H15,          *
COMMENT *          014-H02,          *
COMMENT *****
COMMENT * SNUBBER CHANGE TO STRUT : NONE          *
COMMENT *****
COMMENT * SNUBBER DELETED          : 006-H10,H07,H05,H03,H02 *
COMMENT *          H09          *
COMMENT *****
COMMENT *****
LOADING LOAD MODULE
COMMENT *****
CASE      DW          DEAD WEIGHT
DEAD LOAD
COMMENT *****
COMMENT *****
COMMENT DYNAMIC ANALYSIS FOR THE HPCI STEAM EXHAUST LINE DUE TO THE
COMMENT 40 MSEC RUPTURE OF THE PRESSURE RELIEF DISK
COMMENT REF: BECHTEL CALC REPORT NO. S/10855/D-034, REV-1 NUTECH
COMMENT PSE005.0024.06
COMMENT *****
COMMENT *****
COMMENT HPCI TURBINE EXHAUST (P201) RUPTURE OF PRESSURE RELIEF DISK
COMMENT *****
COMMENT *****
CASE      RUPD1  DYNAMIC TIME HISTORY
INTEGRATE          1.727915  16.08E-05
TIME-STEP          300      0.001      1
F-FUNCTION 162    Y-TRAN      1      -1.0      FOR AMPLITUDE-1 AT FG-PSE/D003
F-FUNCTION H1B    Z-TRAN      2      -1.0      FOR AMPLITUDE-2 AT SUP-014-H01
F-FUNCTION H4B    Y-TRAN      3      -1.0      FOR AMPLITUDE-3 AT SUP-014-H04
AMPLITUDE  1      0.0          0.0          5756.0      0.004      5756.0      0.04
AMPLITUDE  1      0.0          0.044
AMPLITUDE  2      0.0          0.000          0.0          0.004      18551.0      0.015
AMPLITUDE  2      18551.0      0.044          0.0          0.055
AMPLITUDE  3      0.0          0.000          0.0          0.015      33250.0      0.055
AMPLITUDE  3      33250.0      0.300
NODES      I1SAP I4SAI I6SAPI I7SANI I1SBP I6SBI I6SSBI I9SBN INNOZ EXNOZ 10 15 20
NODES      26BR 27BR 30 35 H18 H17 45 H22 H14 H15 54BR 55 60
NODES      H13 65 70 H11 H12 H10 H9 80 85 90 95BEL H8 91
NODES      H7 92 100T H6 H5A H4A 110 115 H3A 125T H2A H1A 140T
NODES      HPTUB 162 165 170 175 H2B H1B180BL H3B 190 195 H5B H4B
NODES      21045CGO P201
PRINT
END LOADS
COMMENT *****
EVALUATE
```

```
COMMENT *****
COMMENT DISK RUPTURE LOAD CONSIDERED FOR THE FAULTED CONDITION
COMMENT IN ACCORDANCE WITH THE APPROPRIATE LOAD COMBINATIONS
COMMENT GIVEN IN DESIGN SPECIFICATION 10855-M-68(Q)
COMMENT *****
CODE          CLASS 2  LEVELD   77ED S77
EQUATION  9      DW          RUPD1
PEAK PRES I1CAP 210        185.0
ALLOWABLE 1          15000.    15000.
END CODE
COMMENT *****
RESTART
SAVE      201R
END RESTR
/*EOR ...
```

COM,P3.  
USER(NU134WC,XNUTECH)  
CHARGE,F3395JT,\*311\*XPS080501.  
ROUTE(OUTPUT,DEF,DC=PR,FID=CJM40,ID)  
SETTL,\*  
SETJSL,\*.  
REWIND,OUTPUT.  
\*  
\*\*\*\*\*  
\* RESTART, INPUT, AND OUTPUT+DAYFILE ARE SAVED \*  
\* IN THE FOLLOWING TAPE, IN THAT ORDER. \*  
\*\*\*\*\*  
TRS,OP=R,VSN=A03114,LFN=RTAPE.  
COPYBF,RTAPE,RESTART.  
COPYBF,RTAPE,TAPE9.  
COPYBF,RTAPE,TAPE31.  
COPYBF,RTAPE,TAPE51.  
COPYBF,RTAPE,TAPE52.  
UNLOAD,RTAPE.  
REWIND,RESTART,TAPE9.  
REWIND,TAPE31.  
REWIND,TAPES1,TAPES2.  
COPYBR,INPUT,SYNIN.  
REWIND,SYNIN.  
GET,APPLIC/UN=LIBRARY.  
GIN,PISTAR,APPLIC,LEVEL=351,NOTES=N,TSAVE=201MK,  
APE,ROUTE=NES01.

\*\*\*\*\*  
\* ATTACH PISTAR MODEL IMMEDIATELY BELOW "/EOR", \*  
\*\*\*\*\*  
/\*EOR

TITLE HOPE CREEK TAP SYSTEM: HPCI TURBINE EXHAUST P-201  
ID CLIENT= PUBLIC SERVICE ELECTRIC & GAS COMPANY  
ID PROJECT NAME= HOPE CREEK TAP SNUBBER REDUCTION  
ID PROJECT NUMBER= XPS-0800  
ID JOB NUMBER= XPS-08  
ID FILE NUMBER= PSE005.1016  
ID CALCULATION NUMBER= C-31  
ID PREPARED BY= C. J. MEHTA  
ID CHECKED BY= A. S. HERLEKAR

COMMENT \*\*\*\*\*  
COMMENT \* LOAD MODULE - 4 \*  
COMMENT -----  
COMMENT =====  
COMMENT ===== INPUT FILE : C31EVL =====  
COMMENT -----  
COMMENT -----  
LOADING -----  
COMMENT -----  
COMMENT -----  
CASE B-2 LOAD CASE B-2

```

=====
COMBINE QABIBABS 0.73 QAB ABS
COMMENT
CASE B-MAX MAXIMUM LEVEL-B
MAXIMUM ABS OBEI B-2
COMMENT
CASE C2 LOAD CASE LEVEL C & D
COMBINE QABI ABS 0.73 QAB ABS
COMMENT
CASE C-1 LOAD CASE C-1
COMBINE C2 RSS MXEQIRSS
COMMENT
COMMENT C-2 IS ENVELOPED BY C-1
COMMENT
CASE C3A CHUGI+CHUG
COMBINE CHUGIABS CHUG ABS
CASE C-3 LOAD CASE C-3
COMBINE C3A RSS C2 RSS
COMMENT
CASE C-MAX MAIXIMUM LEVEL-C
MAXIMUM ABS C-1 C-3
COMMENT
CASE D-1 LOAD CASE D-1
COMBINE C3A RSS C-1 RSS
COMMENT
COMMENT D-2 IS ENVELOPED BY D-1
COMMENT
CASE D3A COI + CO
COMBINE COI ABS CO ABS
COMMENT
CASE D-3 LOAD CASE D-3
COMBINE D3A RSS OBEI RSS
COMMENT
CASE D-MAX MAIXIMUM LEVEL-D
MAXIMUM ABS D-1 D-3
COMMENT
CASE DWS DW + OL
COMBINE DW ABS OL ABS
COMMENT
*****
COMMENT
*****
COMMENT
* FLANGE LOAD COMBINATION MODUAL *
COMMENT
*****
CASE OBID OBEI+OBED
COMBINE OBEI ABS OBED ABS
PRINT YES NO YES NO
COMMENT
CASE SSID SSEI + SSED
COMBINE SSEI ABS SSED ABS
PRINT YES NO NO NO
COMMENT
=====
    
```

```

CASE          MXEQ          MAX SSID & OBID
MAXIMUM      ABS          SSID      OBID
PRINT
COMMENT      =====
CASE          SLA1          MAX TMAX TMAX1 TE2T
MAXIMUM      ABS          TMAX      TMAX1  TE2T
PRINT
COMMENT      =====
CASE          SLB1          MAX B-2 & OBID
MAXIMUM      ABS          B-2      OBID
PRINT
COMMENT      =====
CASE          SLD1          SRSS OF C2, C3A, MXEQ
COMBINE      C2  RSS          C3A  RSS          MXEQ RSS
PRINT
COMMENT      =====
CASE          SLD2          SRSS OF D3A & OBEID
COMBINE      D3A  RSS          OBID  RSS
PRINT
COMMENT      =====
CASE          SLD3
MAXIMUM      ABS          SLD1      SLD2
PRINT
COMMENT      =====
CASE          SLA          SLA1+DWS
COMBINE      SLA1  ABS          DWS  ABS
PRINT
COMMENT      =====
CASE          SLB          SLB1+SLA
COMBINE      SLB1  ABS          SLA  ABS
PRINT
COMMENT      =====
CASE          SLD          SLD1+SLA
COMBINE      SLD3  ABS          SLA  ABS
PRINT
COMMENT      =====
COMMENT      *****
END LOADS
COMMENT      *****
COMMENT      IN THE FOLLOWING CODE EVALUATION SEGMENTS, USE
COMMENT      AS MANY "ALLOWABLE". CARDS AS THERE ARE "MATERIAL"
COMMENT      CARDS IN THE MODEL. ALSO VERIFY AND INCLUDE THE
COMMENT      CORRESPONDING SH AND SC VALUES
COMMENT      *****
EVALUATE
CODE          CLASS 2  DESIGN  77ED S77
COMMENT      *****
COMMENT      LOAD CASE DWS = DW + OL
COMMENT      *****
EQUATION     8  DWS
EQUATION     9  DWS          B-MAX
    
```

EQUATION 10 A-2  
EQUATION 11 DWS A-2  
PEAK PRES I1CAP 210 185.0  
ALLOWABLE 1 15000. 15000.

COMMENT \*\*\*\*\*  
CODE CLASS 2 DESIGN 77ED S77

EQUATION 10 A-3  
EQUATION 11 DWS A-3  
PEAK PRES I1CAP 210 185.0  
ALLOWABLE 1 15000. 15000.

COMMENT \*\*\*\*\*  
CODE CLASS 2 DESIGN 77ED S77

EQUATION 10 A-4  
EQUATION 11 DWS A-4  
ALLOWABLE 1 15000. 15000.

COMMENT \*\*\*\*\*  
CODE CLASS 2 LEVELC 77ED S77

EQUATION 9 DWS C-MAX  
PEAK PRES I1CAP 210 185.0  
ALLOWABLE 1 15000. 15000.

COMMENT \*\*\*\*\*  
CODE CLASS 2 LEVELD 77ED S77

EQUATION 9 DWS D-MAX  
PEAK PRES I1CAP 210 185.0  
ALLOWABLE 1 15000. 15000.

END CODE  
COMMENT \*\*\*\*\*

RESTART  
RESTORE 201MK  
SAVE LOMD4  
END RESTRT  
/\*EOR







CALCULATION CONTINUATION SHEET

TITLE PIPING CODE  
 COMPLIANCE DOCUMENTATION  
 SYSTEM P-201

ORIGINATOR DATE  
 VPR or COR DATE

ID NO. C-31  
 REFERENCE NONE

SHEET 68 OF 76

TAPE STORAGE LOG

SYSTEM: P 201

TAPE DETAILS			FILE NO.	INFO./FILE SAVED	COMPUTER PROGRAM	COMPUTER OUTPUT ID / DATE	REMARKS
VSN=	D=	L=\$.....\$					
A04234	PE	PISTAR-SAVE P201	1	RESTART	PISTAR	ACBY 5/19/88	All Thermal Cases (FN=3)
			2	TAPE 9			
			3	TAPE 31			
			4	TAPE 51			No Data
			5	TAPE 52			No Data
			6	INPUT			
			7	OUTPUT			
A00431		PISTAR-SAVE 201MK	1	RESTART		ACORD 6/6/88	Code Evaluation, Flange Evaluation etc (FN=2)
			2	TAPE 9			
			3	TAPE 31			
			4	TAPE 51			
			5	TAPE 52			
			6	INPUT			None
			7	OUTPUT			None



CALCULATION  
 CONTINUATION SHEET

TAPE STORAGE LOG

SYSTEM: P 201

TAPE DETAILS			FILE NO.	INFO./FILE SAVED	COMPUTER PROGRAM	COMPUTER OUTPUT ID / DATE	REMARKS
VSN=	D=	L=\$.....\$					
A03933	PE	PISTAR-SAVE 201DW	1	RESTART	PISTAR	APLS 5/16/88	Hydroweight only (FN=1)
			2	TAPE 9			
			3	TAPE 31			
			4	TAPE 51			No Data
			5	TAPE 52			No Data
			6	INPUT			
			7	OUTPUT			
A01251		PISTAR-SAVE 201R	1	RESTART		ADCE 6/7/88	Rupture Disc Analysis
			2	TAPE 9			
			3	TAPE 31			
			4	TAPE 51			
			5	TAPE 52			
			6	INPUT			
			7	OUTPUT			
A01282		P201-RPDISK	1	TAPE-14			
			2	TAPE-16			

TITLE PIPING CODE  
 COMPLIANCE DOCUMENTATION  
 SYSTEM P-201

ORIGINATOR DATE  
 VFN or CCM DATE

027  
 6-16-88  
 1871  
 1/19/88

7

ID NO. C-37  
 REFERENCE NONE

SHEET I. 61  
 OF 68



CALCULATION CONTINUATION SHEET

TITLE PIPING CODE  
 COMPLIANCE DOCUMENTATION  
 SYSTEM P-201

ID NO. C-31  
 REFERENCE None

ORIGINATOR DATE  
 VFR OR CDR DATE

AM  
 2/22/88  
 1/21/89  
 7/12/88

[Grid of empty boxes for tracking]

SHEET I-62  
 OF 68

TAPE STORAGE LOG

SYSTEM: P201

TAPE DETAILS			FILE NO.	INFO./FILE SAVED	COMPUTER PROGRAM	COMPUTER OUTPUT ID / DATE	REMARKS
VSN=	D=	L=\$.....\$					
A0357K/ A0427F	GE	P201-MK1-ASBUILT*	1	RESTART	PISTAR	ABCO 06/03/88	Coupled Mode
			2	TAPE9			
			3	TAPE1			
			4	TAPE23			
			5	RESTART	PSMODE	"	Random modes
			6	TAPE15	CARROTS/ CMDGF	"	coupling
			7	TAPE61			
			8	TAPE63			
			9	TAPE14	MODSUP	"	Model superposition w/d response
			10	TAPE16			
			11	TAPE34			
			12	TAPE36			
			13	TAPE11	TRUNCTION1	"	Transfer functions.

NOTES:

\* Even though the label is "AS BUILT", the contents are actually for "snubber-reduced" configuration.



CALCULATION  
 CONTINUATION SHEET

TITLE PIPING CODE  
 COMPLIANCE DOCUMENTATION  
 SYSTEM P-001

ID NO. C-91  
 REFERENCE None

ORIGINATOR  
 DATE  
 VFR or CCR  
 DATE

LM  
 02/12/88  
 DSH  
 7/22/88

SHEET  
 I.63  
 OF  
 68

TAPE STORAGE LOG

SYSTEM: P201

TAPE DETAILS			FILE NO.	INFO./FILE SAVED	COMPUTER PROGRAM	COMPUTER OUTPUT ID / DATE	REMARKS
VSN=	D=	L=\$.....\$					
-	-	-	-	-	TFTABL2	ASMM 06/03/88	Selection of Critical frequencies
-	-	-	-	Tuned T.Hist. file: "C32 P201"	SRNHIST	ASPM 06/03/88	Tuning of PABE (C3.2) Time History
-	-	-	-	"C31 P201"	"	ASPP 06/03/88	Tuning of PABE (C3.1) Time History
Ap357H/ A0427H	(cont'd...)		14	TAPE13	TFUNCTION.2	ASRG 05/03/88	PABE (C3.2) Response T.Hist
			15	"	"		PABE (C3.1) " "
			16	"	"		COI (CHG OPTION - ABSSEN) RESP.T.HIST
			17	"	"		CHUGI Loop. T.Hist
			18	RESTART	TFPOST	"	PABE (C3.2) Response
			19	"	"		PABE (C3.1) " "
			20	"	"		COI " "
			21	"	"		CHUGI " "

NOTES:

PISTAR

Code Evaluation.



CALCULATION  
 CONTINUATION SHEET

TITLE PIPING CODE  
 COMPLIANCE DOCUMENTATION  
 SYSTEM P-201

ORIGINATOR DATE VFR or OPR DATE	4/1 05/24/08 ASB 7/24/08
REFERENCE	None

ID NO. C-3/

SHEET  
 5.64  
 OF  
 68

TAPE STORAGE LOG

SYSTEM: P201

TAPE DETAILS			FILE NO.	INFO./FILE SAVED	COMPUTER PROGRAM	COMPUTER OUTPUT ID / DATE	REMARKS
VSN=	D=	L=\$.....\$					
A#3574/ A#4271	GE	P201-MRI-ASSEMBLY	22	TAPE 11	TFUNCTION1	AAGP 06/09/08	Transfer Functions - Acceleration
		(Revised.....)	23	TAPE 13	TFUNCTION2	"	QASZ (G3.2) Accel. Response T. Hist
			24	"	"		COI Accel " " "
			25	"	"		CHUG " " " "
			26	"	"		CHUG2 (CO OPTION) " "
			27	RESTART	TFPOST	1	QASZ (G3.2) Accel.
			28	"	"		COI Accel.
			29	"	"		CHUG2 (CO OPTION) Accel.
			-	Accel. Resp. Spectra File P201AQB	REGEN/ OSTER/ROTSC	AAQG 06/09/08	QASZ (G3.2) Accel Resp. Spectra
			-	"Protach"	"	AAQJ 06/09/08	COI " "
			-	"Protach"	"	AAQP 06/09/08	CHUG2 (CO OPTION) " "

NOTES:



CALCULATION  
 CONTINUATION SHEET

TAPE STORAGE LOG

SYSTEM: P201

TAPE DETAILS			FILE NO.	INFO./FILE SAVED	COMPUTER PROGRAM	COMPUTER OUTPUT ID / DATE	REMARKS
VSN=	D=	L=\$.....\$					
103544/ 104271	GE	* P201-MKT-ASBUNT	30	TAP515	CARROTS/ CMDOP	ACWV 06/15/88	Coupling w/ 3% piping Damping
			31	TAP561			
			32	TAP563			
			33	TAP514	MORSE	"	Modal Superposition w. noise response T.H.
			34	TAP516			
			35	TAP534			
			36	TAP536			
			37	TAP511	TRANJON1	ADPK 06/15/88	Transfer functions 3% piping Dmpg.
			-	-	TFTAB2	ADRO 06/15/88	Selection of Critical Freq. (3% Piping Dmpg)
			-	Tuned T.History file "201CB23"	SRNHST	ASGT 06/16/88	Tuning of PISE (C3.2) T.History (3% Piping Damping)

TITLE PIPING CODE  
 COMPLIANCE DOCUMENTATION  
 SYSTEM P-201

OPERATOR  
 DATE  
 VFR or CCR  
 DATE

ATL  
 06/11/88  
 ASH  
 7/21/88

ID NO. C-31  
 REFERENCE None

SHEET  
 I-65  
 of  
 68

NOTES:

\* Even though label is "AS-KOILT" the contents are actually for "snubber-reduced" configuration.



CALCULATION SHEET  
 CONTINUATION SHEET

TAPE STORAGE LOG

SYSTEM: P201

TAPE DETAILS			FILE NO.	INFO./FILE SAVED	COMPUTER PROGRAM	COMPUTER OUTPUT ID / DATE	REMARKS
VSN=	D=	L=\$.....\$					
A03574/ A04271	GE	P201-MKT-ASSULT	38	TAPE13	TFUNCTION1	AESM 06/17/88	QABE (C3.2) Response T.Hist (3% Piping Dmpg)
(concluded)			39	RESTART	TFPOST	"	QABE (C3.2) Response (3% Piping Dmpg)
			-	-	PISTAR	"	Code Evaluation
			40	TAPE13	TFUNCTION2	AEXB 06/17/88	QABE (C3.1) Accel Resp. T.Hist (2% Dmpg)
			41	RESTART	TFPOST	"	QABE (C3.1) Accel Resp (2% Dmpg)
			-	Resp. Spectra File "P2P201A"	REGEN/DGTRK PLOTSC	AFG2 06/17/88	QABE (C3.1) Accel Resp. Spectra (20% Piping Dmpg)
			42	TAPE11	TFUNCTION1	AALY 06/20/88	QABE (C3.2) Accel. Transfer Functions. (3% Piping Dmpg)
			43	TAPE13	TFUNCTION2	"	QABE (C3.2) Accel Response T.History (3% Piping Dmpg)
			44	RESTART	TFPOST	"	QABE (C3.2) Accel Response (3% Piping Dmpg)

TITLE PIPING CODE  
 COMPLIANCE DOCUMENTATION  
 SYSTEM P-201

ORIGINATOR DATE  
 VFR or CDR DATE

AM 02/11/88  
 ASB 1/22/88

ID NO. C-31  
 REFERENCE Name

SHEET 7.66  
 of 18

NOTES:



CALCULATION  
 CONTINUATION SHEET

TAPE STORAGE LOG

SYSTEM: P201

TAPE DETAILS			FILE NO.	INFO./FILE SAVED	COMPUTER PROGRAM	COMPUTER OUTPUT ID / DATE	REMARKS
VSN=	D=	L=\$.....\$					
			-	Accel. Resp. Spectra File "QB3P201"	RESGEN/DATX/ PLOTSC	AARK 06-20-88	Accel. Resp. Spectra. QAS2 (C3.2) 3% piping Dmgpt
A03151	GE	P201ACCL-@P201	1	TAR011	TFUNCTION1	ACEN 07/13/88	Transfer function Accel. - @ P201 (2% piping Dmgpt)
			2	TAR013	TFUNCTION 2		QAS2 (C3.2) Accel Response TH @ P201 (2% piping Dmgpt)
			3	"	"	"	COI " " "
			4	"	"	"	CHNGE " " " "
			5	"	"	"	CHNGE (CO OPTIM) " "
			6	RESTART	TFPOST		QAS2 (C3.2) Accel Response (2% Piping Dmgpt)
			7	"	"	"	COI " " "
			8	"	"	"	CHNGE (CO OPTIM) " "
			-	Accel Resp. Spectra File "QBAP201"	RESGEN/DATX/ PLOTSC	ABAV 07/15/88	QAS2 (C3.2) Accel Spectra @ Mide P201 (2% Dmgpt)
			-	"COAP201"	"	ABAY 07/15/88	COI " " "
			-	"CHAP201"	"	ABBB 07/15/88	CHNGE " " " "

TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201	ID NO. C-31 REFERENCE	SHEET 267 OF 68
ORIGINATOR DATE VFR or CDR DATE	DATE	DATE
AM 07/14/88	AKH 07/14/88	7/22/88

NOTES:





CALCULATION  
 CONTINUATION SHEET

TAPE STORAGE LOG


SYSTEM: P201

TAPE DETAILS			FILE NO.	INFO./FILE SAVED	COMPUTER PROGRAM	COMPUTER OUTPUT ID / DATE	REMARKS
VSN=	D=	L=\$.....\$					
A03114	PE	PISTAR-SAVE-201M	1	RESTART	PISTAR	ABRG 06/03/88	Pistar Restart containing all MK I Tapes notation cases (26 Dmg) for use in Supp. Comb
			2	TAPES9	"		
			3	TAPES31	"		
			4	TAPES1	"		
			5	TAPES2	"		
			6	INPUT	"		
			7	OUTPUT	"		
A02386	PE	PISTAR-SAVE-P201M	1	RESTART	PISTAR	AESM 06/17/88	SAME AS ABOVE BUT INCLUDING (TAB2 (C312) CASE 1/32 PIPING Dmg)
			2	TAPES9			
			3	TAPES31			
			4	TAPES1			
			5	TAPES2			
			6	INPUT			
			7	OUTPUT			

NOTES:

6 INPUT  
7 OUTPUT

TITLE PIPING CODE	ID NO. C-31	SHEET 1-68 OF 68
COMPLIANCE DOCUMENTATION SYSTEM P-201	REFERENCE None	
ORIGINATOR DATE	AM 7	
VFR or OVR DATE	01/21/88	
	1/21/88	
	7/12/88	

 <b>CALCULATION CONTINUATION SHEET</b>	TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-24, HANGER GUIDANCE		ID NO. C-31-HG		SHEET 1 OF 3
	REFERENCE NONE				
	ORIGINATOR DATE VFR or CKR DATE	[Signature] 06-07-88 [Signature] 6/1/88			

**HOPE CREEK GENERATING STATION - UNIT 1**

**FINAL STRESS HANGER GUIDANCE**

Reactor Building

Attached herewith is the hanger guidance for the following isometrics:


STARTUP SYSTEM	CALCULATION NUMBER	GUIDANCE ISSUE NUMBER	ISOMETRIC/REVISION NUMBER*	REASON FOR REVISION
EEA BJA	C-31-HG	6	1-P-FD-01 Rev.	SNUBBER REDUCTION IMPLEMENTATION

\*Revision number to be assigned later.

**NOTES:**

- Linear footage of this calculation \_\_\_\_\_
- Number of hangers 20 (SNB 6 RAD 11 ANC - SPD 3).
- Hanger guidance accounts for hanger minimum design load as applicable per S.G. Bulletin 24 Yes  No
- Essential Safety related calc. Yes  No
- Small Bore Piping included: Yes  No
- Hanger Load Changes: Yes  No
- Calculated load may be used if minimum design load results in hardware impact.
- For torus attached piping: X = North, Y = Up, Z = East.

ATTACHMENT 2  
 PAGE 1 OF 143  
 CALC. NO. C-0031/710

 CALCULATION CONTINUATION SHEET	TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201, HANGER GUIDANCE		ID NO. C-31-HG REFERENCE NONE		SHEET 2 OF 3	
	ORIGINATOR	031	0			
	DATE	06-07-88				
VFR or CKR	ASD					
DATE	6/7/88					

HANGER GUIDANCE:

- 1) Support Loads and Maximum Displacements to be used for evaluation of the pipe supports on system P-201 are contained in OPTSUPT RUNID No. SUPTJSRU dated 06-07-88 (Attachment A).
- 2) Dead weight loads and normal operating displacements are obtained from OPTSUPT RUNID No. SUPTJYVD, dated 06-07-88 (Attachment B). For this run, Level-B load is DW reaction and Level-3B displacements are maximum normal operating values. Loads from Level-3B are purely thermal normal operating loads.
- 3) RUPTURE OF PRESSURE RELIEF DISK LOADS AND DISPLACEMENTS (LEVEL-D) ARE OBTAINED FROM OPTSUPT RUNID NO. SUPTMVIC, DATED 06-07-88 (ATTACHMENT-C)
- 4 FOR SERVICE LEVEL-D MAXIMUM OF FAULTED LOADS FROM ATTACHMENT A OR C ARE TO BE USED FOR SUPPORT EVALUATION.




CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201, HANGER GUIDANCE		ID NO. C-31-HG	SHEET 3 OF 3
		REFERENCE NONE	
ORIGINATOR	<u>PM</u>		
DATE	<u>06-07-88</u>		
VFR or CKR	<u>MSJ</u>		
DATE	<u>6/7/88</u>		

ATTACHMENTS

- A. OPTSUPT RUNID SUPTJSRL, dated 06-07-88
- B. OPTSUPT RUNID SUPTJYVD, dated 06-07-88
- C. OPTSUPT RUNID SUPTMVIC, dated 06-07-88

ATTACHMENT 2  
PAGE 3 OF 143  
CALC. NO. C-0031/TIRO

 <b>PSEG</b> CALCULATION CONTINUATION SHEET	TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201, HANGER GUIDANCE		ID NO. C-31-HG	SHEET A-1 OF  59
			REFERENCE NONE	
	ORIGINATOR DATE VFR or CKR DATE	<u>031</u> <u>6</u> <u>06-07-88</u> <u>ASB</u> <u>6/7/88</u>		

ATTACHMENT A

OPTSUPT RUNID SUPTJSRL DATED 06-07-88  
( 58 Pages)

N N U U TTTT EEEEE CCCC H H  
 NN N U U T E C H H  
 N N N U U T EEEEE C H H H  
 N NN U U T E C H H  
 N N UUUU T EEEEE CCCC H H

00000 P P P P P T T T T T S S S S S U U P P P P P T T T T T  
 O O P P T S U U P P T  
 O O P P P P T S S S S U U P P P P T  
 O O P T S U U P T  
 00000 P T S S S S S U U U U P T

REVISION 1.0.0  
 LEVEL FEB-25-1988

DPTSUPT RUN: ID = SUPTJSRL TIME = 9:38:17.58 DATE = 6/ 7/1988

CALCULATION PACKAGE FILE NUMBER = (C-31) PSE005.1016

COMPUTER RUN FILE NUMBER = AC00

COMPUTER RUN OUTPUT FILE NAME = P201SUP.S1

OPTPIPE TAPE 51 INPUT:

FILE NAME = P201SUP.T51 RUN ID = AC00 DATE = 88/06/06

OPTPIPE TAPE 52 INPUT:

FILE NAME = P201SUP.T52 RUN ID = AC00 DATE = 88/06/06

FILE CONTAINING ADDITIONAL LOAD CASE DATA:

FILE NAME =

PREPARED BY/DATE: C. J. Mehta 06-07-88  
 C. J. MEHTA

CHECKED BY/DATE: A. S. Herlekar 06/7/88  
 A. S. HERLEKAR

SUPTJSRL 9:38:17.58 6/ 7/1988 PAGE 1

NUTECH ENGINEERS  
 PIPE SUPPORT LOAD COMP. SYSTEM (P201)

ATTACHMENT 2  
 PAGE 5 OF 148  
 CASE NO. C-0531/TIRO

NUTECH ENGINEERS  
PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005 1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACOD

HPC1 TURBINE EXHAUST (P201) NORMAL LOADS MODEL

NUMBER OF POINTS = 111      NUMBER OF PIPE RUNS = 1  
 NUMBER OF SUPPORTS = 61      NUMBER OF TEES = 0  
 NUMBER OF PIPES = 106      NUMBER OF BEAMS = 0  
 NUMBER OF LOAD CASES = 69

CASE ID	LOAD CASE DESCRIPTION	CASE ID	LOAD CASE DESCRIPTION
DBEDX		OBEDY	
DBEDZ		SSEDX	
SSEDY		SSEDZ	
CL		GAB	
CHUGO		CHUGF	
DW		TE	
TE1		TE2	
THAMA		TD	
GAB1		GAB1B	
CO1		CHUG1	
OBE1		SSE1	
DBED		SSED	
MXEOD		MXEQI	
CHUO		CO	
THAM		THAM1	
THAM2		TD1	
TD2		TE2T	
TH1D		TEHD	
THTD1		TEHD1	
THAX		THAX1	
A2A		A-2	
A3A		A-3	
A4A		A-4	
B-2		B-MAX	
C2		C-1	
C3A		C-3	
C-MAX		D-1	

ATTACHMENT 2  
 PAGE 6 of 143  
 CALC. NO. C-0581/TTRD

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB SYSTEM 12:01

PROJECT: HOPE CREEK SNUGGER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CAL. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACOD

CASE ID	LOAD CASE DESCRIPTION	CASE ID	LOAD CASE DESCRIPTION
D3A		D-3	
D-MAX		DWS	
OB1D		SS1D	
MXE0		SLA1	
SLB1		SLD1	
SLD2		SLD3	
SLA		SLB	
SLD			

ECHO OF COMBINATION PROCEDURE INPUT FILE SUPP201

CAS(1)- SERVICE LEVEL B  
 CAS(2)- SERVICE LEVEL C  
 CAS(3)- SERVICE LEVEL D  
 CAS(4)- SERVICE LEVEL 3#B  
 CAS(1)- L. C. NO. A-1 DL+VE  
 LID(DW)  
 LID(OL)  
 ABS  
 ADD  
 CAS(1)- L. C. NO. A-1 DL-VE  
 LID(DW)  
 LID(OL)  
 ABS  
 SUB  
 CAS(1)- L. C. NO. B-1 ORE1 +VE  
 LID(DW)  
 LID(OL)  
 ABS  
 ADD  
 LID(OBE1)  
 ADD  
 CAS(1)- L. C. NO. B-1 OBE1-VE  
 LID(DW)  
 LID(OL)  
 ABS  
 SUB  
 LID(OBE1)  
 SUB  
 CAS(1)- L. C. NO. B-2 OAB1B+VE  
 LID(DW)  
 LID(OL)  
 ABS  
 ADD  
 LID(OAB1B)

ATTACHMENT 2  
 PAGE 7 OF 143  
 FILE NO. C-0031/TIRb

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222



NUTECH ENGINEERS  
PIPE SUPPORT LOAD COMB. SYSTEM P:01

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) P5E005 1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

ECHO OF COMBINATION PROCEDURE INPUT FILE (CONT.) :APP201

INP=0.73  
MLT  
ADD  
LID(OAB)  
ADD  
CAS(1)- L. C. NO. B-2 OABIB-VE  
LID(DW)  
LID(OL)  
ABS  
SUB  
LID(OABIB)  
INP=0.73  
MLT  
SUB  
LID(OAB)  
SUB  
CAS(1)-L. C. NO. B-3 OBE+VE (W/ TE)  
LID(DW)  
LID(TE)  
ADD  
LID(THAM)  
ADD  
LID(TD)  
ADD  
LID(OL)  
ABS  
ADD  
LID(OBEI)  
ADD  
LID(OBED)  
ADD  
CAS(1)-L. C. NO. B-3 OBE+VE (W/D TE)  
LID(DW)  
LID(THAM)  
ADD  
LID(TD)  
ADD  
LID(OL)  
ABS  
ADD  
LID(OBEI)  
ADD  
LID(OBED)  
ADD  
CAS(1)-L. C. NO. B-3 OBE+VE (W/ DW ONLY)  
LID(DW)  
LID(OL)  
ABS

SUPTJSRL

9:38:17.58

6/ 7/1988

PAGE 4

ATTACHMENT 2  
PAGE 8 OF 143  
CALC. NO. C-0031 / TIRB

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB. SYSTEM 11:01

PROJECT: HOPE CREEK SMOOTHER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC00

ECHO OF COMBINATION PROCEDURE INPUT FILE (CONT.) SUPP201

```

ADD
LID(OBEI)
ADD
LID(OBED)
ADD
CAS(1)-L.C.NO. B-3 OOE -VE (W/ TE)
LID(DW)
LID(TE)
ADD
LID(THAM)
ADD
LID(TD)
ADD
LID(OL)
ABS
SUB
LID(OBEI)
SUB
LID(OBED)
SUB
CAS(1)-L.C.NO. B-3 OOE-VE (W/O TE)
LID(DW)
LID(THAM)
ADD
LID(TD)
ADD
LID(OL)
ABS
SUB
LID(OBEI)
SUB
LID(OBED)
SUB
CAS(1)-L.C.NO. B-3 OOE-VE (W/ DW ONLY)
LID(DW)
LID(OL)
ABS
SUB
LID(OBEI)
SUB
LID(OBED)
SUB
CAS(1)-L.C.NO. B-4 OABIB+VE (W/ TE)
LID(DW)
LID(TE)
ADD
LID(THAM)
ADD

```

SUPTJSRL 9:38:17.58 6/ 7/1988 PAGE 5

ATTACHMENT 2  
PAGE 9 OF 143  
CALC. NO. C-0031 / 7TR0

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

NUTECH ENGINEERS  
PIPE SUPPORT LOAD COMB. SYSTEM #201

PROJECT: HOPE CREEK SNURDER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC00

ECHO OF COMBINATION PROCEDURE INPUT FILE (CONT.) SUPP201

LID(TD)  
ADD  
LID(OL)  
ABS  
ADD  
LID(GABIB)  
INP=0.73  
MLT  
ADD  
LID(GAB)  
ADD  
CAS(1)-L.C.NO. B-4 GABIB+VE (W/O TE)  
LID(DW)  
LID(THAM)  
ADD  
LID(TD)  
ADD  
LID(OL)  
ABS  
ADD  
LID(GABIB)  
INP=0.73  
MLT  
ADD  
LID(GAB)  
ADD  
CAS(1)-L.C.NO. B-4 GABIB+VE (W/ DW ONLY)  
LID(DW)  
LID(OL)  
ABS  
ADD  
LID(GABIB)  
INP=0.73  
MLT  
ADD  
LID(GAB)  
ADD  
CAS(1)-L.C.NO. B-4 GABIB-VE (W/ TE)  
LID(DW)  
LID(TE)  
ADD  
LID(THAM)  
ADD  
LID(TD)  
ADD  
LID(OL)  
ABS  
SUB

ATTACHMENT 2  
PAGE 10 OF 143  
CALC. NO. G-0031/7TRD

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

NUTECH ENGINEERS  
PIPE SUPPORT LOAD COMB. SYSTEM P:01

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMB. ACQD

ECHO OF COMBINATION PROCEDURE INPUT FILE (CONT.) SUPP201

LID(QABIB)  
INP=0.73  
MLT  
SUB  
LID(QAB)  
SUB  
CAS(1)-L.C.NO. B-4 QABIB-VE (H/D TE)  
LID(DW)  
LID(THAM)  
ADD  
LID(TD)  
ADD  
LID(OL)  
ABS  
SUB  
LID(QABIB)  
INP=0.73  
MLT  
SUB  
LID(QAB)  
SUB  
CAS(1)-L.C.NO. B-4 QABIB-VE (H/ DW ONLY)  
LID(DW)  
LID(OL)  
ABS  
SUB  
LID(QABIB)  
INP=0.73  
MLT  
SUB  
LID(QAB)  
SUB  
CAS(2)-L.C.NO. C-1 DYN+VE  
LID(DW)  
LID(OL)  
ABS  
ADD  
LID(MXE01)  
PW2  
LID(QABI)  
INP=0.73  
MLT  
LID(QAB)  
ADD  
PW2  
ADD  
SQR  
ADD

SUPTJSRL

9:38:17.58

6/ 7/1988

PAGE 7

ATTACHMENT 2  
PAGE 11 OF 143  
CALC. NO. 6-0031/TTRD

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

PROJECT: HOPE CREEK SNUGGER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACGD

ECHO OF COMBINATION PROCEDURE INPUT FILE (CONT.) SUPP201

```

CAS(2)-L. C. NO. C-1 DYN-VE
LID(DW)
LID(OL)
ABS
SUB
LID(MXEQI)
PW2
LID(QABI)
INP=0.73
MLT
LID(QAB)
ADD
PW2
ADD
SOR
SUB
CAS(2)-L. C. NO. C-2 DYN+VE
LID(DW)
LID(OL)
ABS
ADD
LID(QABI)
INP=0.73
MLT
LID(QAB)
ADD
PW2
LID(CHUGI)
LID(CHUG)
ADD
PW2
ADD
SOR
ADD
CAS(2)-L. C. NO. C-2 DYN-VE
LID(DW)
LID(OL)
ABS
SUB
LID(QABI)
INP=0.73
MLT
LID(QAB)
ADD
PW2
LID(CHUGI)
LID(CHUG)
ADD

```

SUPTJSRL

9:38:17.58

6/ 7/1988

PAGE 8

ATTACHMENT

PAGE 12 OF 143

2

CALC. NO. C-0031/71R0

NUTECH ENGINEERS  
PIPE SUPPORT LOAD COMB. SYSTEM P'01

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS \_\_\_\_\_  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005 1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACGO

ECHO OF COMBINATION PROCEDURE INPUT FILE (CONT.) (RPP20)

PW2  
ADD  
SGR  
SUB  
CAS(2)-L.C.NO. C-3 DYN+VE (W/ TE1)  
LID(DW)  
LID(TE1)  
ADD  
LID(THAH1)  
ADD  
LID(TD1)  
ADD  
LID(OL)  
ABS  
ADD  
LID(OABI)  
INP=0.73  
MLT  
LID(OAB)  
ADD  
PW2  
LID(CHUGI)  
LID(CHUG)  
ADD  
PW2  
ADD  
SGR  
ADD  
CAS(2)-L.C.NO. C-3 DYN-VE (W/ TE1)  
LID(DW)  
LID(TE1)  
ADD  
LID(THAH1)  
ADD  
LID(TD1)  
ADD  
LID(OL)  
ABS  
SUB  
LID(OABI)  
INP=0.73  
MLT  
LID(OAB)  
ADD  
PW2  
LID(CHUGI)  
LID(CHUG)  
ADD

SUPTJSRL

9:38:17.58

6/ 7/1988

PAGE 9

ATTACHMENT 2  
PAGE 13 OF 143  
CALC. NO. C-0031/TIRO

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP, ACQD

ECHO OF COMBINATION PROCEDURE INPUT FILE (CONT.) SUPP201

PH2  
ADD  
SOR  
SUB  
CAS(2)-L.C.NO. C-3 DYN+VE (W/D TE1)  
LID(DW)  
LID(THAM1)  
ADD  
LID(TD1)  
ADD  
LID(OL)  
ABS  
ADD  
LID(QAB1)  
INP=0.73  
MLT  
LID(QAB)  
ADD  
PH2  
LID(CHUG1)  
LID(CHUG)  
ADD  
PH2  
ADD  
SOR  
ADD  
CAS(2)-L.C.NO. C-3 DYN-VE (W/D TE1)  
LID(DW)  
LID(THAM1)  
ADD  
LID(TD1)  
ADD  
LID(OL)  
ABS  
SUB  
LID(QAB1)  
INP=0.73  
MLT  
LID(QAB)  
ADD  
PH2  
LID(CHUG1)  
LID(CHUG)  
ADD  
PH2  
ADD  
SOR  
SUB

SUPTJSRL

9:38:17.58

6/7/1988

PAGE 10

ATTACHMENT 2  
PAGE 14 OF 143  
CALC. NO. C-0031/TTRD

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

NUTECH ENGINEERS  
PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBER: \_\_\_\_\_  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005 1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC00

ECHO OF COMBINATION PROCEDURE INPUT FILE (CONT.) SUPP201

CAS(2)-L C.NO. C-4 DYN+VE (W/ TE1)  
LID(DW)  
LID(TE1)  
ADD  
LID(THAM1)  
ADD  
LID(TD1)  
ADD  
LID(DL)  
ABS  
ADD  
LID(MXEQT)  
LID(MXEQD)  
ADD  
PW2  
LID(GAB1)  
INP=0.73  
MLT  
LID(GAB)  
ADD  
PW2  
ADD  
SGR  
ADD  
CAS(2)-L C.NO. C-4 DYN-VE (W/ TE1)  
LID(DW)  
LID(TE1)  
ADD  
LID(THAM1)  
ADD  
LID(TD1)  
ADD  
LID(DL)  
ABS  
SUB  
LID(MXEQT)  
LID(MXEQD)  
ADD  
PW2  
LID(GAB1)  
INP=0.73  
MLT  
LID(GAB)  
ADD  
PW2  
ADD  
SGR  
SUB

ATTACHMENT 2  
PAGE 15 OF 143  
CALC. NO. C-0031/71R0

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222



NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUGGER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

ECHO OF COMBINATION PROCEDURE INPUT FILE (CONT.) SUPP201

```

CAS(2)-L.C.NO. C-4 DYN+VE (W/D TE1)
LID(DW)
LID(THAM1)
ADD
LID(TD1)
ADD
LID(OL)
ABS
ADD
LID(MXE01)
LID(MXE00)
ADD
PW2
LID(QAB1)
INP=0.73
MLT
LID(QAB)
ADD
PW2
ADD
SGR
ADD
CAS(2)-L.C.NO. 4 C-4 DYN-VE (W/D TE1)
LID(DW)
LID(THAM1)
ADD
LID(TD1)
ADD
LID(OL)
ABS
SUB
LID(MXE01)
LID(MXE00)
ADD
PW2
LID(QAB1)
INP=0.73
MLT
LID(QAB)
ADD
PW2
ADD
SGR
SUB
CAS(2)-L.C.NO. C-4 DYN+VE (W/ DW ONLY)
LID(DW)
LID(OL)
ABS

```

SUPTJ5RL

9:38:17.58

6/ 7/1988

PAGE 12

ATTACHMENT 2  
PAGE 16 OF 143  
CALC. NO. C-0031/TIR0

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

NUTECH ENGINEERS  
PIPE SUPPORT LOAD COMB. SYSTEM P:01

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACCD

ECHO OF COMBINATION PROCEDURE INPUT FILE (CONT.) SUPP201

ADD  
LID(MXEQI)  
LID(MXEOD)  
ADD  
PW2  
LID(GABI)  
INP=0.73  
MLT  
LID(GAB)  
ADD  
PW2  
ADD  
SOR  
ADD  
CAS(2)-L. C. NO. C-4 DYN-VE (W/ DW ONLY)  
LID(DW)  
LID(OL)  
ABS  
SUB  
LID(MXEQI)  
LID(MXEOD)  
ADD  
PW2  
LID(GABI)  
INP=0.73  
MLT  
LID(GAB)  
ADD  
PW2  
ADD  
SOR  
SUB  
CAS(3)-L. C. NO. D-3 DYN+VE  
LID(DW)  
LID(OL)  
ABS  
ADD  
LID(MXEQI)  
PW2  
LID(GABI)  
INP=0.73  
MLT  
LID(GAB)  
ADD  
PW2  
ADD  
LID(CHUQI)  
LID(CHUQ)

SUPTJBR

9:38:17.38

6/ 7/1988

PAGE 13

ATTACHMENT  
PAGE 17 OF 143  
CALC. NO. C-0031/TTD

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACGD

ECHO OF COMBINATION PROCEDURE INPUT FILE (CONT.) (SUPP20)

```

ADD
PW2
ADD
SGR
ADD
CAS(3)-L. C. NO. D-1 DYN-VE
LID(DW)
LID(DL)
ABS
SUB
LID(MXEQI)
PW2
LID(QABI)
INP=0.73
MLT
LID(QAB)
ADD
PW2
ADD
LID(CHUGI)
LID(CHUG)
ADD
PW2
ADD
SGR
SUB
CAS(3)-L. C. NO. D-2 DYN+VE (W/ TE1)
LID(DW)
LID(TE1)
ADD
LID(THAM1)
ADD
LID(TD1)
ADD
LID(DL)
ABS
ADD
LID(QABI)
INP=0.73
MLT
LID(QAB)
ADD
PW2
LID(MXEQI)
LID(MXEGD)
ADD
PW2
ADD
    
```

SUPTJSRL

9:38:17.58

6/ 7/1988

PAGE 14

ATTACHMENT 2  
 PAGE 18 OF 143  
 CALC. NO. 2-0031/TIRB

NUTECH ENGINEERS  
PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SMOOTHER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACGD

ECHO OF COMBINATION PROCEDURE INPUT FILE (CONT.) SUPP201

LID(CHUG1)  
LID(CHUG)  
ADD  
PW2  
ADD  
SGR  
ADD  
CAS(3)-L.C.NO. D-2 DYN-VE (W/ TE1)  
LID(DW)  
LID(TE1)  
ADD  
LID(THAM1)  
ADD  
LID(TD1)  
ADD  
LID(OL)  
ABS  
SUB  
LID(GAB1)  
INP=0.73  
HLT  
LID(GAB)  
ADD  
PW2  
LID(MXE01)  
LID(MXE00)  
ADD  
PW2  
ADD  
LID(CHUG1)  
LID(CHUG)  
ADD  
PW2  
ADD  
SGR  
SUB  
CAS(3)-L.C.NO. D-2 DYN+VE (W/D TE1)  
LID(DW)  
LID(THAM1)  
ADD  
LID(TD1)  
ADD  
LID(OL)  
ABS  
ADD  
LID(GAB1)  
INP=0.73  
HLT

SUPTJSRL

9:38:17.58

6/ 7/1988

PAGE 15

ATTACHMENT  
PAGE 19 OF 143  
CALC. NO. 2-0031/TIRO

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBER  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005 1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

ECHO OF COMBINATION PROCEDURE INPUT FILE (CONT.) SUPP201

LID(OAB)  
 ADD  
 PW2  
 LID(MXEQI)  
 LID(MXEOD)  
 ADD  
 PW2  
 ADD  
 LID(CHUGI)  
 LID(CHUO)  
 ADD  
 PW2  
 ADD  
 SQR  
 ADD  
 CAS(3)-L.C.NO. D-2 DYN-VE (W/O TE1)  
 LID(DW)  
 LID(THAM1)  
 ADD  
 LID(TD1)  
 ADD  
 LID(OL)  
 ABS  
 SUB  
 LID(OABI)  
 INP=0.73  
 MLT  
 LID(OAB)  
 ADD  
 PW2  
 LID(MXEQI)  
 LID(MXEOD)  
 ADD  
 PW2  
 ADD  
 LID(CHUGI)  
 LID(CHUO)  
 ADD  
 PW2  
 ADD  
 SQR  
 SUB  
 CAS(3)-L.C.NO. D-2 DYN+VE (W/ DW ONLY)  
 LID(DW)  
 LID(OL)  
 ABS  
 ADD  
 LID(OABI)

SUPTJSRL

9: 38: 17. 58

6/ 7/1988

PAGE 16

ATTACHMENT 2  
 PAGE 20 OF 143  
 CALC. NO. C-0031/71R0

NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB. SYSTEM P:01

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

ECHO OF COMBINATION PROCEDURE INPUT FILE (CONT.) SUPP201

INP=0.73  
MLT  
LID(GAB)  
ADD  
PW2  
LID(MXEQ1)  
LID(MXEQD)  
ADD  
PW2  
ADD  
LID(CHUG1)  
LID(CHU0)  
ADD  
PW2  
ADD  
SGR  
ADD  
CAS(3)-L. C. NO. D-2 DYN-VE (W/ DW ONLY)  
LID(DW)  
LID(DL)  
ABS  
SUB  
LID(GAB1)  
INP=0.73  
MLT  
LID(GAB)  
ADD  
PW2  
LID(MXEQ1)  
LID(MXEQD)  
ADD  
PW2  
ADD  
LID(CHUG1)  
LID(CHU0)  
ADD  
PW2  
ADD  
SGR  
SUB  
CAS(3)-L. C. NO. D-3 DYN+VE  
LID(DW)  
LID(DL)  
ABS  
ADD  
LID(OBE1)  
PW2  
LID(CO1)

SUPTJSRL

9:38:17.58

6/7/1988

PAGE 17

ATTACHMENT 2  
PAGE 21 OF 143  
CALC. NO. C-0031/TIRB

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

ECHO OF COMBINATION PROCEDURE INPUT FILE (CONT.) SUPP201

```

LID(CD)
ADD
PW2
ADD
SGR
ADD
CAS(3)-L.C.NO. D-3 DYN-VE
LID(DW)
LID(DL)
ABS
SUB
LID(OBE1)
PW2
LID(CO1)
LID(CO)
ADD
PW2
ADD
SGR
SUB
CAS(3)-L.C.NO. D-4 DYN+VE (W/ TE1)
LID(DW)
LID(TE1)
ADD
LID(THAM1)
ADD
LID(TD1)
ADD
LID(DL)
ABS
ADD
LID(OBE1)
LID(OBED)
ADD
PW2
LID(CO1)
LID(CO)
ADD
PW2
ADD
SGR
ADD
CAS(3)-L.C.NO. D-4 DYN-VE (W/ TE1)
LID(DW)
LID(TE1)
ADD
LID(THAM1)
ADD
    
```

SUPTJSRL

9:38:17.58

6/ 7/1988

PAGE 18

ATTACHMENT 2  
 PAGE 22 OF 143  
 CALC. NO. C-0031/71RD

NUTECH ENGINEERS  
PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SMOOTHER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005, 1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACGD

ECHO OF COMBINATION PROCEDURE INPUT FILE (CONT.) SUPP201

LID(TD1)  
ADD  
LID(OL)  
ABS  
SUB  
LID(OBEI)  
LID(OBED)  
ADD  
PW2  
LID(COI)  
LID(CO)  
ADD  
PW2  
ADD  
SGR  
SUB  
CAS(3)-L. C. NO. D-4 DYN+VE (W/O TE1)  
LID(DW)  
LID(THAM1)  
ADD  
LID(TD1)  
ADD  
LID(OL)  
ABS  
ADD  
LID(OBEI)  
LID(OBED)  
ADD  
PW2  
LID(COI)  
LID(CO)  
ADD  
PW2  
ADD  
SGR  
ADD  
CAS(3)-L. C. NO. D-4 DYN-VE (W/O TE1)  
LID(DW)  
LID(THAM1)  
ADD  
LID(TD1)  
ADD  
LID(OL)  
ABS  
SUB  
LID(OBEI)  
LID(OBED)  
ADD

SUPTJSRL

9:38:17.58

6/ 7/1988

PAGE 19

ATTACHMENT  
PAGE 23 OF 143  
CALC. NO. C-0031/TIRD

2



PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005 1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

ECHO OF COMBINATION PROCEDURE INPUT FILE (CONT.) SUPP201

PW2  
LID(CO1)  
LID(CO)  
ADD  
PW2  
ADD  
SGR  
SUB  
CAS(3)-L. C. NO. D-4 DYN+VE (W/ DW ONLY)  
LID(DW)  
LID(OL)  
ABS  
ADD  
LID(OBE1)  
LID(OBED)  
ADD  
PW2  
LID(CO1)  
LID(CO)  
ADD  
PW2  
ADD  
SGR  
ADD  
CAS(3)-L. C. NO. D-4 DYN+VE (W/ DW ONLY)  
LID(DW)  
LID(OL)  
ABS  
SUB  
LID(OBE1)  
LID(OBED)  
ADD  
PW2  
LID(CO1)  
LID(CO)  
ADD  
PW2  
ADD  
SGR  
SUB  
CAS(3)-L. C. FOR LONG TERM HEATUP DYN +VE (W/ TER ONLY)  
LID(DW)  
LID(TE2)  
ADD  
LID(TD2)  
ADD  
LID(NXE01)  
ADD

SUPTJSRL

9:38:17.58

6/ 7/1988

PAGE 20

ATTACHMENT 2  
PAGE 24 OF 143  
CALC. NO. C-0031/71R0

NUTECH ENGINEERS  
PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC00

ECHO OF COMBINATION PROCEDURE INPUT FILE (CONT.) SUPP201

```
LID(MXEQD)
ADD
CAS(3)-L. C. FOR LONG TERM HEATUP DYN -VE (W/ TE2 ONLY)
LID(DW)
LTD(TE2T)
ADD
LID(TD2)
ADD
LID(MXEQ1)
SUB
LID(MXEQD)
SUB
CAS(3)-L. C. FOR LONG TERM HEATUP DYN +VE (W/D TE2 ONLY)
LID(DW)
LID(THAM2)
ADD
LTD(TD2)
ADD
LID(MXEQ1)
ADD
LID(MXEQD)
ADD
CAS(3)-L. C. FOR LONG TERM HEATUP DYN -VE (W/D TE2 ONLY)
LID(DW)
LID(THAM2)
ADD
LID(TD2)
ADD
LID(MXEQ1)
SUB
LID(MXEQD)
SUB
```

SUPTJSRL

9:38:17.58

6/ 7/1988

PAGE 21

ATTACHMENT  
PAGE 25 OF 143  
CALL. NO. C-0031/TIR0

2

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

PIPE SUPPORT LOAD COMB. SYSTEM P:01

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQB

```

NODE = 179AN SUPPORT 1 OF 2 (Trans. only)
PIPE DIRECTION COSINES: X = .1745, Y = -.7074, Z = -.6849

SUPT: 1 RIGID | SUPT: 2 RIGID | SUPT: 3 RIGID
TRAN. STIF. = .1000E+09 | TRAN. STIF. = .1000E+09 | TRAN. STIF. = .1000E+09
(X) (Y) (Z) | (X) (Y) (Z) | (X) (Y) (Z)
DIRECTION COSINES: | DIRECTION COSINES: | DIRECTION COSINES:
.9808 .0000 .1951 | -.1379 -.7071 .6936 | .1379 -.7071 -.6936

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. 2719.753 | FORCE MAX. 8562.867 | FORCE MAX. 15064.400
FORCE MIN. -2243.923 | FORCE MIN. -7765.216 | FORCE MIN. -1562.997
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
COMP = 1.9323, .0491 | TEN. = .0353, 1.9326 | TEN. = .0341, 1.9326
TEN. = 1.9323, .5753 | TEN. = .3378, 1.9876 | COMP = .4658, 1.9616
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
1.8753 .0491 .3760 | .6231 .6235 1.9295 | .1399 .2594 .1003
-1.7843 -.0905 -.9342 | -1.0153 -1.0160 -1.9598 | -.1399 -.2594 -.1003

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. 3190.898 | FORCE MAX. 10248.100 | FORCE MAX. 149523.900
FORCE MIN. -2720.718 | FORCE MIN. -9450.559 | FORCE MIN. -136173.600
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
COMP = 2.6617, .0683 | TEN. = .0601, 2.6619 | TEN. = .0323, 2.6623
TEN. = 2.6617, .5104 | TEN. = .2808, 2.6956 | COMP = .4265, 2.6766
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
2.6144 .0653 .4998 | .8449 .8453 2.6568 | .0000 .0000 .0000
-2.5130 -.1030 -1.0096 | -1.2030 -1.2039 -2.6843 | .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 3202.260 | FORCE MAX. 10249.340 | FORCE MAX. 153649.300
FORCE MIN. -2732.080 | FORCE MIN. -9451.801 | FORCE MIN. -140299.000
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
COMP = 2.6618, .0682 | TEN. = .0599, 2.6620 | TEN. = .0326, 2.6623
TEN. = 2.6618, .5107 | TEN. = .2810, 2.6958 | COMP = .4267, 2.6766
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
2.6144 .0654 .5002 | .8452 .8458 2.6570 | .1399 .2594 .1003
-2.5131 -.1031 -1.0099 | -1.2033 -1.2041 -2.6846 | .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3+B *****
FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. .000
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

SUPTJ6RL 9:38:17.58 6/ 7/1988 PAGE 22
    
```

ATTACHMENT 2  
 PAGE 26 OF 143  
 CALC. NO. C-0031/TIRD

NUTECH ENGINEERS  
 PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

NODE = 178AN SUPPORT 2 OF 2 (Rotation only)		
PIPE DIRECTION COSINES: X = .1745, Y = -.7074, Z = -.6849		
SUPT: 4 RIGID	SUPT: 5 RIGID	SUPT: 6 RIGID
ROT. STIF. = .1000E+11	ROT. STIF. = .1000E+11	ROT. STIF. = .1000E+11
(X) (Y) (Z)	(X) (Y) (Z)	(X) (Y) (Z)
DIRECTION COSINES:	DIRECTION COSINES:	DIRECTION COSINES:
.9808 .0000 .1951	-.1379 -.7071 .6936	.1379 -.7071 -.6936
***** CAS(1)- SERVICE LEVEL B *****		
MOMT. MAX. 58440.310	MOMT. MAX. 16388.220	MOMT. MAX. 2375.940
MOMT. MIN. -33652.210	MOMT. MIN. -16187.730	MOMT. MIN. -2556.113
GLOBAL DISPL. MAX/MIN:	LOCAL DISPL. MAX/MIN:	GLOBAL ACCEL. MAX/MIN:
1.8953 .0491 .3760	.6231 .6235 1.9295	.1399 .2594 .1003
-1.7843 -.0905 -.9342	-1.0153 -1.0160 -1.9598	-.1399 -.2594 -.1003
***** CAS(2)- SERVICE LEVEL C *****		
MOMT. MAX. 68844.550	MOMT. MAX. 36400.630	MOMT. MAX. 2025.159
MOMT. MIN. -64055.990	MOMT. MIN. -36200.500	MOMT. MIN. -2205.371
GLOBAL DISPL. MAX/MIN:	LOCAL DISPL. MAX/MIN:	GLOBAL ACCEL. MAX/MIN:
2.6144 .0653 .4998	.8449 .8453 2.6568	.0000 .0000 .0000
-2.5130 -.1030 -1.0096	-1.2030 -1.2039 -2.6845	.0000 .0000 .0000
***** CAS(3)- SERVICE LEVEL D *****		
MOMT. MAX. 68851.370	MOMT. MAX. 36411.160	MOMT. MAX. 2025.469
MOMT. MIN. -64062.810	MOMT. MIN. -36211.030	MOMT. MIN. -2205.681
GLOBAL DISPL. MAX/MIN:	LOCAL DISPL. MAX/MIN:	GLOBAL ACCEL. MAX/MIN:
2.6144 .0654 .5002	.8452 .8458 2.6570	.1399 .2594 .1003
-2.5131 -.1031 -1.0099	-1.2033 -1.2041 -2.6846	.0000 .0000 .0000
***** CAS(4)- SERVICE LEVEL 3*B *****		
MOMT. MAX. .000	MOMT. MAX. .000	MOMT. MAX. .000
MOMT. MIN. .000	MOMT. MIN. .000	MOMT. MIN. .000
GLOBAL DISPL. MAX/MIN:	LOCAL DISPL. MAX/MIN:	GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000	.0000 .0000 .0000	.0000 .0000 .0000
.0000 .0000 .0000	.0000 .0000 .0000	.0000 .0000 .0000
SUPTJSRL	9:38:17.58	6/ 7/1988
PAGE 23		

ATTACHMENT 2  
 PAGE 27 OF 143  
 CALL NO. C-0031/TIRB

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) P5E005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

```

NODE = 1958N SUPPORT 1 OF 2 (Trans. only)
PIPE DIRECTION COSINES: X = -.9521, Y = -.7074, Z = -.4414

SUPT: 7 RIGID | SUPT: 8 RIGID | SUPT: 9 RIGID
TRAN STIF. = .1000E+09 | TRAN. STIF. = .1000E+09 | TRAN. STIF. = .1000E+09
(X) (Y) (Z) | (X) (Y) (Z) | (X) (Y) (Z)
DIRECTION COSINES: | DIRECTION COSINES: | DIRECTION COSINES:
1.0000 .0000 .0000 | .0000 -.7071 .7071 | .0000 -.7071 -.7071

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. 16445.800 | FORCE MAX. 32737.940 | FORCE MAX. 5936.116 |
FORCE MIN. -17752.190 | FORCE MIN. -30997.740 | FORCE MIN. -2713.413 |
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: |
COMP = .0770, .0943 | COMP = .0078, .1215 | TEN = .0940, .0774 |
TEN = .0770, .6384 | TEN = .3729, .5238 | COMP = .5181, .3808 |
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0770 .0609 .0720 | .1173 .1174 .1043 | .1398 .2606 .0998 |
-.0770 -.1026 -.6300 | -.3932 -.3934 -.5402 | -.1398 -.2606 -.0998 |

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. 80089.580 | FORCE MAX. 46778.520 | FORCE MAX. 109972.800 |
FORCE MIN. -81451.680 | FORCE MIN. -45019.420 | FORCE MIN. -106667.900 |
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: |
COMP = .0954, .1271 | COMP = .0201, .1577 | TEN = .1235, .0975 |
TEN = .0954, .6237 | TEN = .3537, .5224 | COMP = .5137, .3664 |
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0954 .0745 .1030 | .1509 .1509 .1400 | .0000 .0000 .0000 |
-.0954 -.1131 -.6133 | -.4034 -.4036 -.5386 | .0000 .0000 .0000 |

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 80132.450 | FORCE MAX. 46787.930 | FORCE MAX. 110048.200 |
FORCE MIN. -81494.550 | FORCE MIN. -45028.830 | FORCE MIN. -106743.300 |
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: |
COMP = .0961, .1274 | COMP = .0204, .1583 | TEN = .1258, .0983 |
TEN = .0961, .8195 | TEN = .4940, .6610 | COMP = .6540, .5032 |
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0961 .0746 .1033 | .1514 .1515 .1407 | .1398 .2606 .0998 |
-.0961 -.1131 -.8117 | -.4914 -.4916 -.6940 | .0000 .0000 .0000 |

***** CAS(4)- SERVICE LEVEL 3#B *****
FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. .000 |
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000 |
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: |
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000 |
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000 |
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000 |
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000 |

SUPTJSRL 9: 38: 17. 58 6/ 7/1988 PAGE 24
    
```

ATTACHMENT  
 PAGE 28 OF 143  
 CALC. NO. C-0031/T1R22

N-UT ECH ENGINEERS  
 PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1014  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC&D

```

MODE = 195BN   SUPPORT 2 OF 2                               (Rotation only)
PIPE DIRECTION COSINES: X = -.5521, Y = -.7074, Z = -.4414

SUPT: 10   RIGID | SUPT: 11   RIGID | SUPT: 12   RIGID
ROT. STIF. = .1000E+11 | ROT. STIF. = .1000E+11 | ROT. STIF. = .1000E+11
(X) (Y) (Z) | (X) (Y) (Z) | (X) (Y) (Z)
DIRECTION COSINES: | DIRECTION COSINES: | DIRECTION COSINES:
1.0000 .0000 .0000 | .0000 -.7071 .7071 | .0000 -.7071 -.7071

***** CAS(1)- SERVICE LEVEL B *****
MOMT. MAX. 175755.300 | MOMT. MAX. 85446.630 | MOMT. MAX. 109168.200
MOMT. MIN. -170687.000 | MOMT. MIN. -89936.550 | MOMT. MIN. -104677.000

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0770 .0609 .0720 | .1173 .1174 .1043 | .1398 .2606 .0998
-.0770 -.1026 -.6300 | -.3932 -.3934 -.5402 | -.1398 -.2606 -.0998

***** CAS(2)- SERVICE LEVEL C *****
MOMT. MAX. 193120.000 | MOMT. MAX. 90518.600 | MOMT. MAX. 98610.910
MOMT. MIN. -188052.400 | MOMT. MIN. -95029.020 | MOMT. MIN. -94120.030

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0954 .0745 .1030 | .1509 .1509 .1400 | .0000 .0000 .0000
-.0954 -.1131 -.6133 | -.4034 -.4036 -.5386 | .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
MOMT. MAX. 193122.800 | MOMT. MAX. 90532.820 | MOMT. MAX. 98614.140
MOMT. MIN. -188055.200 | MOMT. MIN. -95043.230 | MOMT. MIN. -94123.270

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0961 .0746 .1033 | .1514 .1515 .1407 | .1398 .2606 .0998
-.0961 -.1131 -.6117 | -.4914 -.4916 -.6940 | .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3+B *****
MOMT. MAX. .000 | MOMT. MAX. .000 | MOMT. MAX. .000
MOMT. MIN. .000 | MOMT. MIN. .000 | MOMT. MIN. .000

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

SUPTJURL          9:38:17.58      6/ 7/1988          PAGE 25
    
```

ATTACHMENT 2  
 PAGE 29 OF 143  
 CALC. NO. C-0031/TIRD

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBER  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACOD

```

NODE = P201      SUPPORT 1 OF 2                      (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = .0000, Z = -1.0000

SAPT: 13      RIGID | SAPT: 14      RIGID | SAPT: 15      RIGID
TRAN. STIF. = .3160E+08 | TRAN. STIF. = .5120E+07 | TRAN. STIF. = .1470E+07
(X) (Y) (Z) | (X) (Y) (Z) | (X) (Y) (Z)
DIRECTION COSINES: | DIRECTION COSINES: | DIRECTION COSINES:
1.0000 .0000 .0000 | .0000 -.9848 -.1736 | .0000 .1736 -.9848

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. 4594.202 | FORCE MAX. 33890.350 | FORCE MAX. 51012.880
FORCE MIN. -3410.168 | FORCE MIN. -22139.210 | FORCE MIN. -65345.130
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
COMP = .0936, .0820 | TEN = .0743, .0998 | TEN = .0347, .1195
TEN = .0129, .6766 | COMP = .1310, .6639 | COMP = .6638, .1316
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0936 .0672 .0471 | .0471 .0672 .0936 | .1400 .2381 .1258
-.0129 -.0138 -.6764 | -.6764 -.0138 -.0129 | -.1400 -.2381 -.1258

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. 10428.350 | FORCE MAX. 51538.010 | FORCE MAX. 60152.280
FORCE MIN. -9098.201 | FORCE MIN. -39729.700 | FORCE MIN. -74294.300
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
COMP = .0903, .0839 | TEN = .0721, .1000 | TEN = .0429, .1155
TEN = .0167, .6330 | COMP = .1248, .6208 | COMP = .6206, .1259
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0903 .0635 .0548 | .0548 .0635 .0903 | .0000 .0000 .0000
-.0167 -.0152 -.6328 | -.6328 -.0152 -.0167 | .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 10613.850 | FORCE MAX. 51700.960 | FORCE MAX. 64620.400
FORCE MIN. -9283.506 | FORCE MIN. -39872.630 | FORCE MIN. -78762.630
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
COMP = .1299, .0970 | TEN = .0879, .1362 | TEN = .0408, .1569
TEN = .0167, .9402 | COMP = .1783, .9233 | COMP = .9232, .1791
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.1299 .0795 .0554 | .0554 .0795 .1299 | .1400 .2381 .1258
-.0167 -.0153 -.9401 | -.9401 -.0153 -.0167 | .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. .000
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

SAPTJSRL          9:38:17.58      6/ 7/1988          PAGE 26
    
```

ATTACHMENT 2  
 PAGE 30 OF 143  
 CALC. NO. C-0031/TIRD

NUTECH ENGINEERS  
PIPE SUPPORT LOAD COMB. SYSTEM P:01

PROJECT: HOPE CREEK SMOOTHER REDUCTION  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005 1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

FILE NUMBERS

NODE = P201			SUPPORT 2 OF 2			(Rotation only)		
PIPE DIRECTION COSINES: X = .0000, Y = .0000, Z = -1.0000								
SUPT: 16 RIGID			SUPT: 17 RIGID			SUPT: 18 RIGID		
ROT. STIF. = .1570E+08			ROT. STIF. = .1566E+08			ROT. STIF. = .2970E+07		
(X) (Y) (Z)			(X) (Y) (Z)			(X) (Y) (Z)		
DIRECTION COSINES:			DIRECTION COSINES:			DIRECTION COSINES:		
1.0000 .0000 .0000			.0000 -.9848 -.1736			.0000 .1736 -.9848		
***** CAS(1)- SERVICE LEVEL B *****								
MOMT. MAX. 1111443.000			MOMT. MAX. 330415.700			MOMT. MAX. 210291.000		
MOMT. MIN. *****			MOMT. MIN. -319904.900			MOMT. MIN. -214815.600		
GLOBAL DISPL. MAX/MIN:			LOCAL DISPL. MAX/MIN:			GLOBAL ACCEL. MAX/MIN:		
.0936 .0672 .0471			.0471 .0672 .0936			.1400 .2381 .12581		
-.0129 -.0138 -.6764			-.6764 -.0138 -.0129			-.1400 -.2381 -.12581		
***** CAS(2)- SERVICE LEVEL C *****								
MOMT. MAX. 1140140.000			MOMT. MAX. 498156.800			MOMT. MAX. 290482.600		
MOMT. MIN. *****			MOMT. MIN. -487179.000			MOMT. MIN. -295001.600		
GLOBAL DISPL. MAX/MIN:			LOCAL DISPL. MAX/MIN:			GLOBAL ACCEL. MAX/MIN:		
.0903 .0635 .0548			.0548 .0635 .0903			.0000 .0000 .00001		
-.0167 -.0152 -.6328			-.6328 -.0152 -.0167			.0000 .0000 .00001		
***** CAS(3)- SERVICE LEVEL D *****								
MOMT. MAX. 1140140.000			MOMT. MAX. 498283.300			MOMT. MAX. 290506.300		
MOMT. MIN. *****			MOMT. MIN. -487305.300			MOMT. MIN. -295025.300		
GLOBAL DISPL. MAX/MIN:			LOCAL DISPL. MAX/MIN:			GLOBAL ACCEL. MAX/MIN:		
.1299 .0795 .0534			.0534 .0795 .1299			.1400 .2381 .12581		
-.0167 -.0153 -.9401			-.9401 -.0153 -.0167			.0000 .0000 .00001		
***** CAS(4)- SERVICE LEVEL 3*B *****								
MOMT. MAX. .000			MOMT. MAX. .000			MOMT. MAX. .000		
MOMT. MIN. .000			MOMT. MIN. .000			MOMT. MIN. .000		
GLOBAL DISPL. MAX/MIN:			LOCAL DISPL. MAX/MIN:			GLOBAL ACCEL. MAX/MIN:		
.0000 .0000 .0000			.0000 .0000 .0000			.0000 .0000 .00001		
.0000 .0000 .0000			.0000 .0000 .0000			.0000 .0000 .00001		
SUPTJSRL			9:38:17.58			6/ 7/1988		
						PAGE 27		

ATTACHMENT 2  
 PAGE 31 OF 143  
 CALC. NO. C-0031/TIRO

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222



NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB SYSTEM P201

PROJECT: HOPE CREEK SMOOTHER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

NODE = H19 SUPPORT 1 OF 1 (Trans. only)  
 PIPE DIRECTION COSINES: X = .0000, Y = 1.0000, Z = .0000  
 SUPT: 19 ~~21018~~ SPRING HANGER  
 TRAN STIF. = .1800E+04 Hot Load = 4940. } *02/18/88*  
 (X) (Y) (Z) *06-07-88*  
 DIRECTION COSINES:  
 .0000 1.0000 .0000  
 \*\*\*\*\* CAS(1)- SERVICE LEVEL B \*\*\*\*\*  
 FORCE MAX. 437.919  
 FORCE MIN. -37.963  
 AXIAL SWING MAX/MIN:  
 COMP = .2433, .2096  
 TEN. = .0211, .2482  
 GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:  
 .1879 .2433 .0930 .2433 .0930 .1879 .3594 .5036 .2469  
 -.0537 -.0211 -.2424 -.0211 -.2424 -.0537 -.3594 -.5036 -.2469  
 \*\*\*\*\* CAS(2)- SERVICE LEVEL C \*\*\*\*\*  
 FORCE MAX. 309.406  
 FORCE MIN. -123.140  
 AXIAL SWING MAX/MIN:  
 COMP = .2830, .3026  
 TEN. = .0684, .3484  
 GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:  
 .2297 .2830 .1970 .2830 .1970 .2297 .0000 .0000 .0000  
 -.0961 -.0684 -.3349 -.0684 -.3349 -.0961 .0000 .0000 .0000  
 \*\*\*\*\* CAS(3)- SERVICE LEVEL D \*\*\*\*\*  
 FORCE MAX. 380.731  
 FORCE MIN. -127.047  
 AXIAL SWING MAX/MIN:  
 COMP = .3226, .3038  
 TEN. = .0706, .3491  
 GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:  
 .2310 .3226 .1973 .3226 .1973 .2310 .3594 .5036 .2469  
 -.0975 -.0706 -.3352 -.0706 -.3352 -.0975 .0000 .0000 .0000  
 \*\*\*\*\* CAS(4)- SERVICE LEVEL 3\*B \*\*\*\*\*  
 FORCE MAX. .000  
 FORCE MIN. .000  
 AXIAL SWING MAX/MIN:  
 N/A = .0000, .0000  
 N/A = .0000, .0000  
 GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:  
 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000  
 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000  
 SUPTJSRL 9:38:17.58 6/ 7/1988 PAGE 28

ATTACHMENT 2  
 PAGE 32 OF 143  
 CALC. NO. C-0031/71R0

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS  
 PIPE SUPPORT LOAD COMB. SYSTEM P001

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACOD

```

MODE = H18      SUPPORT 1 OF 1      (Trans. only)

PIPE DIRECTION COSINES: X = -1.0000, Y = .0091, Z = .0000

SPT: 20 SNUBBER
TRAN STIF. = .2590E+06
(X) (Y) (Z)
DIRECTION COSINES:
.0000 1.0000 .0000

*****
CAS(1)- SERVICE LEVEL B *****
FORCE MAX. 2763.677
FORCE MIN. -2763.677
AXIAL SWING MAX/MIN:
COMP = .2575 .1868
TEN = .0248 .1033
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.1853 .2575 .0232 .1877 .2592 .0232 .3303 .3189 .0987
-.0992 -.0248 -.0288 -.0994 -.0257 -.0288 -.3303 -.3189 -.0987

*****
CAS(2)- SERVICE LEVEL C *****
FORCE MAX. 6331.530
FORCE MIN. -6331.530
AXIAL SWING MAX/MIN:
COMP = .2817 .2383
TEN = .0549 .1548
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.2325 .2817 .0520 .2351 .2838 .0520 .0000 .0000 .0000
-.1439 -.0549 -.0572 -.1444 -.0562 -.0572 .0000 .0000 .0000

*****
CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 7126.389
FORCE MIN. -7126.389
AXIAL SWING MAX/MIN:
COMP = .3227 .2387
TEN = .0561 .1588
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.2330 .3227 .0521 .2359 .3248 .0521 .3303 .3189 .0987
-.1481 -.0561 -.0575 -.1486 -.0575 -.0575 .0000 .0000 .0000

*****
CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000 .0000
N/A = .0000 .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SPTJSRL 9:38:17.58 6/ 7/1988 PAGE 29
  
```

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

ATTACHMENT 2  
 PAGE 33 of 143  
 CALC. NO. C-0031/7IRD

NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB. SYSTEM #201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACOG

```

NODE = H17      SUPPORT 1 OF 1      (Trans. only)

PIPE DIRECTION COSINES: X = -1.0000, Y = .0093, Z = .0000

SUPT: 21      RIGID
TRAN STIF. = .1320E+07
(X) (Y) (Z)
DIRECTION COSINES:
.0000 .0000 1.0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. 6267.544
FORCE MIN. -12099.760
AXIAL, SWING MAX/MIN:
COMP = .0229, .3016
TEN = .0273, .1023
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.1778 .2436 .0229 .1801 .2453 .0229 .3301 .3013 .0982
-.0993 -.0248 -.0273 -.0993 -.0257 -.0273 -.3301 -.3013 -.0982

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. 12160.950
FORCE MIN. -17352.610
AXIAL, SWING MAX/MIN:
COMP = .0516, .3488
TEN = .0556, .1534
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.2250 .2665 .0516 .2275 .2686 .0516 .0000 .0000 .0000
-.1439 -.0532 -.0556 -.1444 -.0545 -.0556 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 12291.300
FORCE MIN. -17482.960
AXIAL, SWING MAX/MIN:
COMP = .0516, .3798
TEN = .0559, .1578
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.2255 .3056 .0516 .2283 .3077 .0516 .3301 .3013 .0982
-.1481 -.0543 -.0559 -.1486 -.0557 -.0559 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL, SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTJSRL 9:38:17.58 6/ 7/1988 PAGE 30
    
```

ATTACHMENT 2  
 PAGE 34 OF 143  
 CALC. NO. C-0031/71RD

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS  
 PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACGD

```

  | NODE = H22      SUPPORT 1 OF 1      (Trans. only) |
  | PIPE DIRECTION COSINES: X = .0000, Y = 1.0000, Z = .0000 |
  | SUPT: 22  SNUBBER |
  | TRAN STIF. = .8700E+05 |
  | (X) (Y) (Z) |
  | DIRECTION COSINES: |
  | .0000 .0000 1.0000 |
  | ***** CAS(1)- SERVICE LEVEL B L ***** |
  | FORCE MAX. 3889.186 |
  | FORCE MIN. -3889.186 |
  | AXIAL, SWING MAX/MIN: |
  | COMP = .1123, .2739 |
  | TEN. = .0454, .1684 |
  | GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
  | .0533 .2687 .1123 .2687 .1123 .0533 .5351 .2537 .1743 |
  | -.1667 -.0241 -.0454 -.0241 -.0454 -.1667 -.5351 -.2537 -.1743 |
  | ***** CAS(2)- SERVICE LEVEL C L ***** |
  | FORCE MAX. 7946.756 |
  | FORCE MIN. -7946.756 |
  | AXIAL, SWING MAX/MIN: |
  | COMP = .1534, .3083 |
  | TEN. = .0920, .2256 |
  | GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
  | .1125 .2871 .1534 .2871 .1534 .1125 .0000 .0000 .0000 |
  | -.2207 -.0469 -.0920 -.0469 -.0920 -.2207 .0000 .0000 .0000 |
  | ***** CAS(3)- SERVICE LEVEL D L ***** |
  | FORCE MAX. 8022.469 |
  | FORCE MIN. -8022.469 |
  | AXIAL, SWING MAX/MIN: |
  | COMP = .1542, .3411 |
  | TEN. = .0929, .2384 |
  | GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
  | .1138 .3216 .1542 .3216 .1542 .1138 .5351 .2537 .1743 |
  | -.2336 -.0477 -.0929 -.0477 -.0929 -.2336 .0000 .0000 .0000 |
  | ***** CAS(4)- SERVICE LEVEL 3#B ***** |
  | FORCE MAX. .000 |
  | FORCE MIN. .000 |
  | AXIAL, SWING MAX/MIN: |
  | N/A = .0000, .0000 |
  | N/A = .0000, .0000 |
  | GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
  | .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
  | .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
  | SUPTJSRL 9:38:17.58 6/ 7/1988 PAGE 31 |
  
```

ATTACHMENT 1 2  
 PAGE 35 of 143  
 CALC. NO. C-0031/TIRD

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACOD

```

NODE = H14      SUPPORT 1 OF 1      (Trans. only)
PIPE DIRECTION COSINES: X = -1.0000, Y = .0092, Z = .0000

SUPT: 24      RIGID
TRAN STIF. = .3491E+07
(X) (Y) (Z)
DIRECTION COSINES:
.0000 .0000 1.0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. 7139.972
FORCE MIN. -6483.155
AXIAL SWING MAX/MIN:
COMP = .0237, .1961
TEN. = .0235, .1022
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.1267 .1496 .0237 .1281 .1508 .0237 .3289 .2273 .1022
-.0997 -.0223 -.0235 -.0999 -.0232 -.0235 -.3289 -.2273 -.1022

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. 8711.959
FORCE MIN. -8861.945
AXIAL SWING MAX/MIN:
COMP = .0515, .2390
TEN. = .0515, .1498
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.1740 .1639 .0515 .1755 .1655 .0515 .0000 .0000 .0000
-.1444 -.0401 -.0515 -.1447 -.0414 -.0515 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 9674.324
FORCE MIN. -9246.945
AXIAL SWING MAX/MIN:
COMP = .0519, .2375
TEN. = .0515, .1341
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.1745 .1694 .0519 .1762 .1910 .0519 .3289 .2273 .1022
-.1487 -.0404 -.0515 -.1490 -.0418 -.0515 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3+B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPT JSRL      9:38:17.58      6/ 7/1988      PAGE 32
    
```

ATTACHMENT 2  
 PAGE 36 OF 143  
 CALC. NO. C-0031/TIRO

NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB. SYSTEM P:01

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005, 1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACGD

```

-----
| NODE = H15      SUPPORT 1 OF 1      (Trans. only) |
| PIPE DIRECTION COSINES: X = -1.0000, Y = .0040, Z = .0000 |
| SUPT: 23 SNUDDER |
| TRAN STIF. = .4950E+06 |
| (X) (Y) (Z) |
| DIRECTION COSINES: |
| .0000 1.0000 .0000 |
| ***** CAS(1)- SERVICE LEVEL B ***** |
| FORCE MAX. 4227.485 |
| FORCE MIN. -4227.485 |
| AXIAL SWING MAX/MIN: |
| COMP= .1362, .1221 |
| TEN. = .0217, .1027 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .1195 .1362 .0248 .1201 .1367 .0248 .3286 .2243 .1044 |
| -.0997 -.0217 -.0245 -.0998 -.0221 -.0245 -.3286 -.2243 -.1044 |
| ***** CAS(2)- SERVICE LEVEL C ***** |
| FORCE MAX. 7843.962 |
| FORCE MIN. -7843.962 |
| AXIAL SWING MAX/MIN: |
| COMP= .1494, .1749 |
| TEN. = .0381, .1537 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .1668 .1494 .0526 .1674 .1501 .0526 .0000 .0000 .0000 |
| -.1444 -.0381 -.0527 -.1445 -.0387 -.0527 .0000 .0000 .0000 |
| ***** CAS(3)- SERVICE LEVEL D ***** |
| FORCE MAX. 8116.966 |
| FORCE MIN. -8116.966 |
| AXIAL SWING MAX/MIN: |
| COMP= .1728, .1753 |
| TEN. = .0383, .1577 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .1672 .1728 .0532 .1679 .1735 .0532 .3286 .2243 .1044 |
| -.1487 -.0383 -.0527 -.1488 -.0389 -.0527 .0000 .0000 .0000 |
| ***** CAS(4)- SERVICE LEVEL 3#B ***** |
| FORCE MAX. .000 |
| FORCE MIN. .000 |
| AXIAL SWING MAX/MIN: |
| N/A = .0000, .0000 |
| N/A = .0000, .0000 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| SUPTJSRL 9:38:17.58 6/ 7/1988 PAGE 33 |
-----
  
```

ATTACHMENT  
 PAGE 31 OF 143  
 CALC. NO. C-0031 / TIRD  
 2

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBER  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACOG

```

NODE = H13      SUPPORT 1 OF 1                      (Trans. only)
PIPE DIRECTION COSINES: X = -1.0000, Y = .0091, Z = .0000

SUPT: 25      RIGID
TRAN STIF. = .4800E+06
(X) (Y) (Z)
DIRECTION COSINES:
.0000 1.0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. 3362.215
FORCE MIN. -9860.547
AXIAL SWING MAX/MIN:
COMP = .0037, .0678
TEN. = .0172, .1079
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0567 .0037 .0371 .0568 .0042 .0371 .3253 .2543 .1528
-.1002 -.0172 -.0400 -.1004 -.0181 -.0400 -.3253 -.2543 -.1528

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. 7700.582
FORCE MIN. -14242.010
AXIAL SWING MAX/MIN:
COMP = .0119, .1240
TEN. = .0256, .1627
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.1028 .0119 .0693 .1029 .0129 .0693 .0000 .0000 .0000
-.1449 -.0256 -.0741 -.1451 -.0269 -.0741 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 7856.343
FORCE MIN. -14397.770
AXIAL SWING MAX/MIN:
COMP = .0124, .1244
TEN. = .0260, .1668
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.1033 .0124 .0694 .1034 .0133 .0694 .3253 .2543 .1528
-.1493 -.0260 -.0742 -.1496 -.0273 -.0742 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTJSRL          9:38:17.58      6/ 7/1988          PAGE 34
    
```

ATTACHMENT 2  
 PAGE 38 of 143  
 CALC. NO. C-0031/TIRB

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS  
PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE003.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC00

```

MODE = H11      SUPPORT 1 OF 1      (Trans. only)

PIPE DIRECTION COSINES: X = .0000, Y = -1.0000, Z = .0000

SUPT: 26      RIGID
TRAN STIF. = .1750E+07
(X) (Y) (Z)
DIRECTION COSINES:
-.7844 .0000 -.6202

*****
CAS(1)- SERVICE LEVEL B *****
FORCE MAX. 3832.994
FORCE MIN. -2288.341
AXIAL SWING MAX/MIN:
TEN. = .0503, .0053
COMP = .0513, .1673
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0409 .0047 .0294 .0047 .0294 .0409 .1208 .2716 .1109
-.0373 -.1672 -.0355 -.1672 -.0355 -.0373 -.1208 -.2716 -.1109

*****
CAS(2)- SERVICE LEVEL C *****
FORCE MAX. 6493.863
FORCE MIN. -4962.235
AXIAL SWING MAX/MIN:
TEN. = .0955, .0245
COMP = .0965, .1852
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0773 .0242 .0562 .0242 .0562 .0773 .0000 .0000 .0000
-.0734 -.1852 -.0627 -.1852 -.0627 -.0734 .0000 .0000 .0000

*****
CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 6620.108
FORCE MIN. -5088.480
AXIAL SWING MAX/MIN:
TEN. = .0959, .0253
COMP = .0969, .1898
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0774 .0251 .0568 .0251 .0568 .0774 .1208 .2716 .1109
-.0739 -.1898 -.0627 -.1898 -.0627 -.0739 .0000 .0000 .0000

*****
CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTJSRL      9:38:17.58      6/ 7/1988      PAGE 33
    
```

ATTACHMENT 2  
 PAGE 39 of 143  
 CALC. NO. C-0031/TIR0

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222



PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PBE005 1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC00

```

NODE = H12      SUPPORT 1 OF 1                      (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = -1.0000, Z = .0000

SUCT: 27      RIGID
TRAN STIF. = .3066E+07
(X) (Y) (Z)
DIRECTION COSINES:
.4524 .0000 -.8918

*****
CAS(1)- SERVICE LEVEL B *****
FORCE MAX. 2308.176
FORCE MIN. -8391.790
AXIAL SWING MAX/MIN:
TEN. = .0062, .0925
COMP = .0042, .1970
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0796 .0047 .0474 .0047 .0474 .0796 .1336 .2714 .1021
-.0416 -.1909 -.0258 -.1909 -.0258 -.0416 -.1336 -.2714 -.1021

*****
CAS(2)- SERVICE LEVEL C *****
FORCE MAX. 3253.307
FORCE MIN. -9347.229
AXIAL SWING MAX/MIN:
TEN. = .0128, .1392
COMP = .0108, .2289
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.1165 .0241 .0735 .0241 .0735 .1165 .0000 .0000 .0000
-.0786 -.2089 -.0520 -.2089 -.0520 -.0786 .0000 .0000 .0000

*****
CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 3432.731
FORCE MIN. -9326.652
AXIAL SWING MAX/MIN:
TEN = .0129, .1408
COMP = .0108, .2337
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.1178 .0251 .0742 .0251 .0742 .1178 .1336 .2714 .1021
-.0786 -.2141 -.0520 -.2141 -.0520 -.0786 .0000 .0000 .0000

*****
CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUCTJSRL          9:38:17.58      6/ 7/1988          PAGE 36
    
```

ATTACHMENT 2  
 PAGE 40 OF 143  
 CALC. NO. C-0031 / 7190

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS

PIPE SUPPORT LOAD COMD. SYSTEM P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACCO

```

MODE = H10      SUPPORT 1 OF 1      (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = -1.0000, Z = .0000

SUPT: 20 SNUBBER
TRAN STIF. = .0000E+00
(X) (Y) (Z)
DIRECTION COSINES:
1.0000 .0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
COMP = .3482, .2856
TEN = .1398, .3353
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.3482 .0045 .2856 .0045 .2856 .3482 .4085 .2700 .4524
-.1398 -.3336 -.0332 -.3336 -.0332 -.1398 -.4085 -.2700 -.4524

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
COMP = .3997, .3099
TEN = .1926, .3563
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.3997 .0241 .3089 .0241 .3089 .3997 .0000 .0000 .0000
-.1926 -.3518 -.0567 -.3518 -.0567 -.1926 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
COMP = .4118, .3152
TEN = .1930, .3653
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.4118 .0251 .3142 .0251 .3142 .4118 .4085 .2700 .4524
-.1930 -.3609 -.0568 -.3609 -.0568 -.1930 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTJ5RL      9: 38: 17.58      6/ 7/1988      PAGE 37
    
```

ATTACHMENT 41 OF 143  
 PAGE 41 OF 143  
 CALC. NO. C-00311/TIRB

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) P5E005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

```

NODE = H9      SUPPORT 1 OF 1      (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = -1.0000, Z = .0000

SUPT: 27 SNUBBER
TRAN STIF. = .0000E+00
(X) (Y) (Z)
DIRECTION COSINES:
.2801 .0000 -.9600

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL, SWING MAX/MIN:
TEN. = .2037, .4621
TEN. = .0101, .3886
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.3865 .0045 .3250 .0045 .3250 .3865 .4497 .2699 .3081
-.1548 -.3549 -.0346 -.3549 -.0346 -.1548 -.4497 -.2699 -.3081

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL, SWING MAX/MIN:
TEN. = .2101, .5203
TEN. = .0040, .4318
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.4401 .0241 .3473 .0241 .3473 .4401 .0000 .0000 .0000
-.2098 -.3730 -.0571 -.3730 -.0571 -.2098 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL, SWING MAX/MIN:
TEN. = .2133, .5354
TEN. = .0041, .4404
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.4536 .0251 .3545 .0251 .3545 .4536 .4497 .2699 .3081
-.2103 -.3827 -.0571 -.3827 -.0571 -.2103 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3#B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL, SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTJSRL          9:38:17.58      6/ 7/1988      PAGE 38
    
```

ATTACHMENT 2  
 PAGE 42 OF 143  
 CALC. NO. C-0031/7TON

NUTECH ENGINEERS  
 PIPE SUPPORT LOAD COMB. SYSTEM 1201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACGD

NODE = 95DEL SUPPORT 1 OF 2			(Trans. only)		
PIPE DIRECTION COSINES: X = .0000, Y = -.0112, Z = -.9999					
SUPT: 30	RIOID	SUPT: 31	RIOID	SUPT: 32	RIOID
TRAN. STIF. = .3100E+03		TRAN. STIF. = .1825E+04		TRAN. STIF. = .1825E+04	
(X) (Y) (Z)		(X) (Y) (Z)		(X) (Y) (Z)	
DIRECTION COSINES:		DIRECTION COSINES:		DIRECTION COSINES:	
.0000	.0000	-1.0000	.0000	1.0000	.0000
***** CAS(1)- SERVICE LEVEL B *****					
FORCE MAX.	3.507	FORCE MAX.	56.207	FORCE MAX.	967.101
FORCE MIN.	-115.645	FORCE MIN.	-472.795	FORCE MIN.	-343.467
AXIAL, SWING MAX/MIN:		AXIAL, SWING MAX/MIN:		AXIAL, SWING MAX/MIN:	
TEN. = .3730, .9309		COMP = .0319, .6481		COMP = .5299, .3744	
COMP = .0113, .3202		TEN. = .2591, .1885		TEN. = .1882, .2593	
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.5299	.0319	.3730	.3734	.0361	.5299
-.1882	-.2591	-.0113	-.0142	-.2592	-.1882
***** CAS(2)- SERVICE LEVEL C *****					
FORCE MAX.	6.909	FORCE MAX.	98.481	FORCE MAX.	1065.758
FORCE MIN.	-119.068	FORCE MIN.	-511.985	FORCE MIN.	-445.276
AXIAL, SWING MAX/MIN:		AXIAL, SWING MAX/MIN:		AXIAL, SWING MAX/MIN:	
TEN. = .3841, .5865		COMP = .0540, .6990		COMP = .5840, .3879	
COMP = .0223, .3718		TEN. = .2805, .2430		TEN. = .2440, .2814	
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.5840	.0540	.3841	.3847	.0583	.5840
-.2440	-.2805	-.0223	-.0254	-.2808	-.2440
***** CAS(3)- SERVICE LEVEL D *****					
FORCE MAX.	6.948	FORCE MAX.	98.679	FORCE MAX.	1096.497
FORCE MIN.	-122.166	FORCE MIN.	-512.184	FORCE MIN.	-446.251
AXIAL, SWING MAX/MIN:		AXIAL, SWING MAX/MIN:		AXIAL, SWING MAX/MIN:	
TEN. = .3941, .6032		COMP = .0541, .7185		COMP = .6008, .3978	
COMP = .0224, .3722		TEN. = .2806, .2455		TEN. = .2445, .2815	
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.6008	.0541	.3941	.3947	.0585	.6008
-.2445	-.2806	-.0224	-.0256	-.2809	-.2445
***** CAS(4)- SERVICE LEVEL 3*B *****					
FORCE MAX.	.000	FORCE MAX.	.000	FORCE MAX.	.000
FORCE MIN.	.000	FORCE MIN.	.000	FORCE MIN.	.000
AXIAL, SWING MAX/MIN:		AXIAL, SWING MAX/MIN:		AXIAL, SWING MAX/MIN:	
N/A = .0000, .0000		N/A = .0000, .0000		N/A = .0000, .0000	
N/A = .0000, .0000		N/A = .0000, .0000		N/A = .0000, .0000	
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.0000	.0000	.0000	.0000	.0000	.0000
.0000	.0000	.0000	.0000	.0000	.0000
SUPTJSRL	9:38:17.58	6/7/1988	PAGE 39		

ATTACHMENT 43 OF 143  
 PAGE 43 OF 143  
 CALC. NO. C-0031/71RO

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC00

```

NODE = 998EL   SUPPORT 2 OF 2                               (Rotation only)
    PIPE DIRECTION COSINES: X = .0000, Y = -.0112, Z = -.9999

SUPT: 33   RIGID | SUPT: 34   RIGID | SUPT: 35   RIGID
ROT. STIF. = .6670E+05 | ROT. STIF. = .6670E+05 | ROT. STIF. = .6670E+05
(X) (Y) (Z) | (X) (Y) (Z) | (X) (Y) (Z)
DIRECTION COSINES: | DIRECTION COSINES: | DIRECTION COSINES:
.0000 .0000 -1.0000 | .0000 1.0000 .0000 | 1.0000 .0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
MOMT. MAX.    90.674 | MOMT. MAX.    220.088 | MOMT. MAX.    136.706
MOMT. MIN.   -292.023 | MOMT. MIN.    -66.546 | MOMT. MIN.    -11.390

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.5299 .0319 .3730 | .3734 .0361 .5299 | .5463 1.0454 .0922
-.1882 -.2591 -.0113 | -.0142 -.2592 -.1882 | -.5463 -1.0454 -.0922

***** CAS(2)- SERVICE LEVEL C *****
MOMT. MAX.    114.823 | MOMT. MAX.    239.615 | MOMT. MAX.    145.628
MOMT. MIN.   -315.139 | MOMT. MIN.    -86.670 | MOMT. MIN.    -20.397

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.5840 .0540 .3841 | .3847 .0583 .5840 | .0000 .0000 .0000
-.2440 -.2805 -.0223 | -.0254 -.2808 -.2440 | .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
MOMT. MAX.    115.104 | MOMT. MAX.    242.942 | MOMT. MAX.    147.224
MOMT. MIN.   -326.171 | MOMT. MIN.    -86.998 | MOMT. MIN.    -20.695

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.6008 .0541 .3941 | .3947 .0585 .6008 | .5463 1.0454 .0922
-.2445 -.2806 -.0224 | -.0256 -.2807 -.2445 | .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3+B *****
MOMT. MAX.     .000 | MOMT. MAX.     .000 | MOMT. MAX.     .000
MOMT. MIN.     .000 | MOMT. MIN.     .000 | MOMT. MIN.     .000

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

SUPTJSRL          9:38:17.98      6/ 7/1988          PAGE 40
    
```

ATTACHMENT 2  
 PAGE 44 OF 143  
 CALC. NO. C-0031 / TIR0

NUTECH ENGINEERS  
 PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE003.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACOD

```

NODE = HB          SUPPORT 1 OF 1          (Trans. only)

PIPE DIRECTION COSINES: X = .0000, Y = -.0100, Z = -.9999

SUPT: 36          26330 | SPRING HANGER
TRAN STIF. = .1200E+04 | Hot LOAD = 2860. # } 0.0100
(X) (Y) (Z) | 06-07-88
DIRECTION COSINES:
.0000 1.0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. 29.881
FORCE MIN. -196.428
AXIAL SWING MAX/MIN:
COMP = .0249, .4762
TEN. = .1637, .1423
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.3693 .0249 .3006 .3008 .0279 .3693 .4988 .9140 .09231
-.1418 -.1637 -.0114 -.0130 -.1638 -.1418 -.4988 -.9140 -.09231

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. 48.132
FORCE MIN. -214.231
AXIAL SWING MAX/MIN:
COMP = .0401, .5177
TEN. = .1785, .1886
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.4134 .0401 .3116 .3120 .0432 .4134 .0000 .0000 .00001
-.1873 -.1785 -.0223 -.0241 -.1787 -.1873 .0000 .0000 .00001

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 48.219
FORCE MIN. -214.318
AXIAL SWING MAX/MIN:
COMP = .0402, .5320
TEN. = .1786, .1890
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.4253 .0402 .3195 .3199 .0434 .4253 .4988 .9140 .09231
-.1877 -.1786 -.0224 -.0242 -.1788 -.1877 .0000 .0000 .00001

***** CAS(4)- SERVICE LEVEL 3#B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .00001
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .00001

SUPTJSRL          9:38:17.58          6/ 7/1988          PAGE 41
  
```

ATTACHMENT:  
 PAGE 45 OF 143  
 CALC. NO. C-0031/71R0

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) P5E003.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC00

```

NODE = H7      SUPPORT 1 OF 1      (Trans. only)

PIPE DIRECTION COSINES: X = .0000, Y = .0143, Z = -.9999

SUCT: 37 SNUDDER
TRAN STIF. = .0000E+00
(X) (Y) (Z)
DIRECTION COSINES:
1.0000 .0000 .0000

*****
CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
COMP = .2921, .2660
TEN = .1208, .1255
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.2921 .0200 .2652 .2655 .0238 .2921 .4766 .8241 .0923
-.1208 -.1250 -.0114 -.0131 -.1251 -.1208 -.4766 -.8241 -.0923

*****
CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
COMP = .3314, .2781
TEN = .1612, .1386
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.3314 .0321 .2762 .2766 .0360 .3314 .0000 .0000 .0000
-.1612 -.1368 -.0223 -.0242 -.1371 -.1612 .0000 .0000 .0000

*****
CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
COMP = .3415, .2850
TEN = .1616, .1387
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.3415 .0322 .2832 .2836 .0362 .3415 .4766 .8241 .0923
-.1616 -.1369 -.0224 -.0244 -.1372 -.1616 .0000 .0000 .0000

*****
CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUCTJSRL      9:38:17.58      6/ 7/1988      PAGE 42
    
```

ATTACHMENT 2  
 PAGE 46 OF 143  
 CALC. NO. C-0031/712D

NUTECH ENGINEERS  
 PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

```

NODE = H6      SUPPORT 1 OF 1      (Trans. only)
      PIPE DIRECTION COSINES: X = .0000, Y = -.0122, Z = -.9999

SUPT: 38      RIGID
TRAN STIF. = .1402E+07
(X) (Y) (Z)
DIRECTION COSINES:
.0000 .0000 1.0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX.      748.945
FORCE MIN.     -3506.439
AXIAL SWING MAX/MIN:
COMP = .0105, .0344
TEN = .0125, .2455
GLOBAL DISPL. MAX/MIN:      LOCAL DISPL. MAX/MIN:      GLOBAL ACCEL. MAX/MIN:
.0341 .0039 .0105      .0106 .0041 .0341      .3486 .2872 .09231
-.2452 -.0130 -.0125      -.0126 -.0131 -.2452      -.3486 -.2872 -.09231

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX.      1990.683
FORCE MIN.     -4711.733
AXIAL SWING MAX/MIN:
COMP = .0213, .0751
TEN = .0232, .2872
GLOBAL DISPL. MAX/MIN:      LOCAL DISPL. MAX/MIN:      GLOBAL ACCEL. MAX/MIN:
.0746 .0088 .0213      .0214 .0090 .0746      .0000 .0000 .00001
-.2866 -.0178 -.0232      -.0234 -.0181 -.2866      .0000 .0000 .00001

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX.      2014.963
FORCE MIN.     -4769.406
AXIAL SWING MAX/MIN:
COMP = .0213, .0752
TEN = .0234, .2873
GLOBAL DISPL. MAX/MIN:      LOCAL DISPL. MAX/MIN:      GLOBAL ACCEL. MAX/MIN:
.0747 .0088 .0213      .0214 .0090 .0747      .3486 .2872 .09231
-.2867 -.0178 -.0234      -.0236 -.0181 -.2867      .0000 .0000 .00001

***** CAS(4)- SERVICE LEVEL 3#B *****
FORCE MAX.      .000
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN:      LOCAL DISPL. MAX/MIN:      GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000      .0000 .0000 .0000      .0000 .0000 .00001
.0000 .0000 .0000      .0000 .0000 .0000      .0000 .0000 .00001

SUPTJSRL      9:38:17.58      6/ 7/1988      PAGE 43
  
```

ATTACHMENT  
 PAGE 47 OF 143  
 2  
 CAL. NO. C-0031/TIR0

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222



PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC00

```

NODE = H5A      SUPPORT 1 OF 1                      (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = -.0045, Z = -1.0000

SUPT: 39 SNUBBER
TRAN STIF. = .0000E+00
      (X) (Y) (Z)
DIRECTION COSINES:
1 0000 .0000 .0000

*****
FORCE MAX.      .000
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
COMP = .0271, .0118
TEN = .2755, .0402
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0271 .0053 .0105 .0105 .0053 .0271 .3165 .2606 .0922
-.2755 -.0108 -.0387 -.0387 -.0110 -.2755 -.3165 -.2606 -.0922

*****
FORCE MAX.      .000
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
COMP = .0663, .0237
TEN = .3156, .0520
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0663 .0105 .0213 .0213 .0106 .0663 .0000 .0000 .0000
-.3156 -.0160 -.0494 -.0494 -.0162 -.3156 .0000 .0000 .0000

*****
FORCE MAX.      .000
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
COMP = .0664, .0237
TEN = .3156, .0528
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0664 .0105 .0213 .0213 .0106 .0664 .3165 .2606 .0922
-.3156 -.0160 -.0503 -.0504 -.0163 -.3156 .0000 .0000 .0000

*****
FORCE MAX.      .000
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTJSRL      9:38:17.58      6/ 7/1988      PAGE 44
    
```

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

ATTACHMENT 2  
 PAGE 48 OF 143  
 CALC. NO. C-0031/71RD

NUTECH ENGINEERS  
PIPE SUPPORT LOAD COMB. SYSTEM P701

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS \_\_\_\_\_  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACGD

```

NODE = H4A      SUPPORT 1 OF 1      (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = -.0113, Z = -.9999

SUPT: 40      RIGID
TRAN STIF. = .6160E+06
(X) (Y) (Z)
DIRECTION COSINES:
.0000 1.0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX.      350.005
FORCE MIN.     -2663.162
AXIAL SWING MAX/MIN:
COMP = .0069, .0259
TEN = .0106, .2984
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0236 .0069 .0105 .0106 .0070 .0236 .2993 .2559 .0921
-.2934 -.0106 -.0542 -.0543 -.0112 -.2934 -.2993 -.2559 -.0921

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX.      937.433
FORCE MIN.     -3249.640
AXIAL SWING MAX/MIN:
COMP = .0125, .0654
TEN = .0163, .3388
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0618 .0125 .0213 .0214 .0128 .0618 .0000 .0000 .0000
-.3325 -.0163 -.0649 -.0651 -.0170 -.3325 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX.      943.295
FORCE MIN.     -3255.499
AXIAL SWING MAX/MIN:
COMP = .0125, .0655
TEN = .0163, .3391
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0619 .0125 .0213 .0214 .0128 .0619 .2993 .2559 .0921
-.3326 -.0163 -.0662 -.0664 -.0170 -.3326 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3#B *****
FORCE MAX.      .000
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTJSRL      9:08:17.58      6/ 7/1988      PAGE 45
    
```

ATTACHMENT 2  
 PAGE 49 OF 143  
 CALC. NO. C-0031/TIRP

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBER  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) P5E005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACOD

```

NUDE = H3A      SUPPORT 1 OF 1                      (Trans. only)

PIPE DIRECTION COSINES: X = .9999, Y = -.0109, Z = .0000

SUPT: 41 SNUBBER
TRAN STIF. = .0000E+00
(X) (Y) (Z)
DIRECTION COSINES:
0767 .0000 -.9971

*****
CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
TEN. = .0114, .0892
COMP = .0960, .1486
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0183 .0871 .0128 .0192 .0873 .0128 .2675 .2749 .4880
-.1390 -.0228 -.1070 -.1393 -.0243 -.1070 -.2675 -.2749 -.4880

*****
CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
TEN. = .0241, .1122
COMP = .1072, .1825
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0494 .0997 .0280 .0504 .1002 .0280 .0000 .0000 .0000
-.1706 -.0340 -.1206 -.1709 -.0358 -.1206 .0000 .0000 .0000

*****
CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
TEN. = .0242, .1123
COMP = .1160, .1833
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0494 .0998 .0281 .0505 .1003 .0281 .2675 .2749 .4880
-.1706 -.0341 -.1295 -.1710 -.0359 -.1295 .0000 .0000 .0000

*****
CAS(4)- SERVICE LEVEL 3#B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTJSRL          9: 38: 17.58      6/ 7/1988          PAGE 46
    
```

ATTACHMENT  
 PAGE 50 OF 143  
 CALC. NO. C-0031/TIRD  
 2

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUVECH ENGINEERS

PIPE SUPPORT LOAD COMB. SYSTEM P:01

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE003.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC00

```

NODF = H2A      SUPPORT 1 OF 1      (Trans. only)
PIPE DIRECTION COSINES: X = .9999, Y = -.0104, Z = .0000

SUPT: 42 SNUBBER ;
TRAN STIF. = .0000E+00 ;
(X) (Y) (Z) ;
DIRECTION COSINES: ;
.0000 1.0000 .0000 ;

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000 ;
FORCE MIN. .000 ;
AXIAL, SWING MAX/MIN: ;
COMP = .0976, .0211 ;
TEN. = .0173, .1141 ;
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: ;
.0182 .0976 .0106 .0192 .0978 .0106 .2660 .2423 .4993 ;
-.0695 -.0173 -.0905 -.0697 -.0180 -.0905 -.2660 -.2423 -.4993 ;

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000 ;
FORCE MIN. .000 ;
AXIAL, SWING MAX/MIN: ;
COMP = .1088, .0553 ;
TEN. = .0263, .1443 ;
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: ;
.0491 .1088 .0253 .0503 .1093 .0253 .0000 .0000 .0000 ;
-.1009 -.0263 -.1032 -.1011 -.0274 -.1032 .0000 .0000 .0000 ;

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000 ;
FORCE MIN. .000 ;
AXIAL, SWING MAX/MIN: ;
COMP = .1088, .0554 ;
TEN. = .0264, .1443 ;
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: ;
.0492 .1088 .0253 .0503 .1093 .0253 .2660 .2423 .4993 ;
-.1009 -.0264 -.1143 -.1012 -.0274 -.1143 .0000 .0000 .0000 ;

***** CAS(4)- SERVICE LEVEL 3#8 *****
FORCE MAX. .000 ;
FORCE MIN. .000 ;
AXIAL, SWING MAX/MIN: ;
N/A = .0000, .0000 ;
N/A = .0000, .0000 ;
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: ;
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 ;
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 ;

SUPTJSRL          9:38:17.58      6/ 7/1988          PAGE 47
    
```

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

ATTACHMENT 2  
 PAGE 51 OF 143  
 CALC. NO. C-0031/TIRO

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACOG

MODE = HIA SUPPORT 1 OF 1 (Trans. only)

PIPE DIRECTION COSINES: X = .9999, Y = -.0105, Z = .0000

SUPT: 43 ~~R1010~~ SPRING HANGER  
 TRAN STIF. = .9000E+03 Hot Load = 2158. } *Control*  
 (X) (Y) (Z)

DIRECTION COSINES:  
 0000 1.0000 .0000

\*\*\*\*\* CAS(1)- SERVICE LEVEL B \*\*\*\*\*

FORCE MAX. 98.826  
 FORCE MIN. -15.044  
 AXIAL SWING MAX/MIN:  
 COMP = .0987, .0209  
 TEN = .0167, .1073  
 GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:  
 .0182 .0987 .0103 .0192 .0989 .0103 .2658 .2406 .4950  
 -.0608 -.0167 -.0884 -.0610 -.0174 -.0884 -.2658 -.2406 -.4950

\*\*\*\*\* CAS(2)- SERVICE LEVEL C \*\*\*\*\*

FORCE MAX. 98.580  
 FORCE MIN. -22.748  
 AXIAL SWING MAX/MIN:  
 COMP = .1095, .0551  
 TEN = .0253, .1367  
 GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:  
 .0491 .1095 .0249 .0503 .1100 .0249 .0000 .0000 .0000  
 -.0922 -.0253 -.1009 -.0925 -.0262 -.1009 .0000 .0000 .0000

\*\*\*\*\* CAS(3)- SERVICE LEVEL D \*\*\*\*\*

FORCE MAX. 98.606  
 FORCE MIN. -22.775  
 AXIAL SWING MAX/MIN:  
 COMP = .1096, .0552  
 TEN = .0253, .1452  
 GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:  
 .0492 .1096 .0250 .0503 .1101 .0250 .2658 .2406 .4950  
 .0923 -.0253 -.1122 -.0925 -.0263 -.1122 .0000 .0000 .0000

\*\*\*\*\* CAS(4)- SERVICE LEVEL 3#B \*\*\*\*\*

FORCE MAX. .000  
 FORCE MIN. .000  
 AXIAL SWING MAX/MIN:  
 N/A = .0000, .0000  
 N/A = .0000, .0000  
 GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:  
 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000  
 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTJSRL 9:38:17.58 6/7/1988 PAGE 48

ATTACHMENT 2  
 PAGE 52 OF 143  
 CALC. NO. C-0031/TIRO

NUTTECH ENGINEERS

PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC00

NODE = HPTUB SUPPORT 1 OF 2 (Trans. only)

PIPE DIRECTION COSINES: X = .0000, Y = .0000, Z = 1.0000

SUPT: 44	RIGID	SUPT: 45	RIGID	SUPT: 46	RIGID
TRAN. STIF. = .1000E+09		TRAN. STIF. = .1000E+09		TRAN. STIF. = .1000E+09	
(X) (Y) (Z)		(X) (Y) (Z)		(X) (Y) (Z)	
DIRECTION COSINES:		DIRECTION COSINES:		DIRECTION COSINES:	
1.0000	.0000 .0000	.0000	1.0000 .0000	.0000	.0000 1.0000

\*\*\*\*\* CAS(1)- SERVICE LEVEL B \*\*\*\*\*

FORCE MAX. 1703.105	FORCE MAX. 656.056	FORCE MAX. 645.566
FORCE MIN. -1433.061	FORCE MIN. -1080.999	FORCE MIN. -1092.247
AXIAL SWING MAX/MIN:	AXIAL SWING MAX/MIN:	AXIAL SWING MAX/MIN:
COMP = .0018, .0000	COMP = .0000, .0018	COMP = .0000, .0018
TEN = .0000, .0285	TEN = .0143, .0246	TEN = .0246, .0143
GLOBAL DISPL. MAX/MIN:	LOCAL DISPL. MAX/MIN:	GLOBAL ACCEL. MAX/MIN:
.0018 .0000 .0000	.0000 .0000 .0018	.1399 .2599 .0999
-.0000 -.0143 -.0246	-.0246 -.0143 -.0000	-.1399 -.2599 -.0999

\*\*\*\*\* CAS(2)- SERVICE LEVEL C \*\*\*\*\*

FORCE MAX. 3813.992	FORCE MAX. 970.428	FORCE MAX. 1042.311
FORCE MIN. -3537.023	FORCE MIN. -1403.293	FORCE MIN. -1501.642
AXIAL SWING MAX/MIN:	AXIAL SWING MAX/MIN:	AXIAL SWING MAX/MIN:
COMP = .0166, .0100	COMP = .0000, .0194	COMP = .0100, .0166
TEN = .0150, .0348	TEN = .0129, .0356	TEN = .0323, .0198
GLOBAL DISPL. MAX/MIN:	LOCAL DISPL. MAX/MIN:	GLOBAL ACCEL. MAX/MIN:
.0166 .0000 .0100	.0100 .0000 .0166	.0000 .0000 .0000
-.0150 -.0129 -.0323	-.0323 -.0129 -.0150	.0000 .0000 .0000

\*\*\*\*\* CAS(3)- SERVICE LEVEL D \*\*\*\*\*

FORCE MAX. 3824.777	FORCE MAX. 1005.350	FORCE MAX. 1056.830
FORCE MIN. -3537.808	FORCE MIN. -1408.086	FORCE MIN. -1516.161
AXIAL SWING MAX/MIN:	AXIAL SWING MAX/MIN:	AXIAL SWING MAX/MIN:
COMP = .0175, .0100	COMP = .0000, .0201	COMP = .0100, .0175
TEN = .0150, .0477	TEN = .0195, .0461	TEN = .0436, .0246
GLOBAL DISPL. MAX/MIN:	LOCAL DISPL. MAX/MIN:	GLOBAL ACCEL. MAX/MIN:
.0175 .0000 .0100	.0100 .0000 .0175	.1399 .2599 .0999
-.0150 -.0195 -.0436	-.0436 -.0195 -.0150	.0000 .0000 .0000

\*\*\*\*\* CAS(4)- SERVICE LEVEL J#B \*\*\*\*\*

FORCE MAX. .000	FORCE MAX. .000	FORCE MAX. .000
FORCE MIN. .000	FORCE MIN. .000	FORCE MIN. .000
AXIAL SWING MAX/MIN:	AXIAL SWING MAX/MIN:	AXIAL SWING MAX/MIN:
N/A = .0000, .0000	N/A = .0000, .0000	N/A = .0000, .0000
N/A = .0000, .0000	N/A = .0000, .0000	N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN:	LOCAL DISPL. MAX/MIN:	GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000	.0000 .0000 .0000	.0000 .0000 .0000
.0000 .0000 .0000	.0000 .0000 .0000	.0000 .0000 .0000

SUPTJSRL

9:38:17.58

6/7/1988

PAGE 49

ATTACHMENT 2  
 PAGE 53 OF 143  
 CALC. NO. C-0031 / TRAN

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS  
 PIPE SUPPORT LOAD COMB. SYSTEM V201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACGD

```

NODE = HPTUB   SUPPORT 2 OF 2                               (Rotation only)

PIPE DIRECTION COSINES: X = .0000, Y = .0000, Z = 1.0000

SUPT: 47   RIGID | SUPT: 48   RIGID | SUPT: 49   RIGID
ROT. STIF. = .1000E+13 | ROT. STIF. = .1000E+13 | ROT. STIF. = .1000E+13
(X) (Y) (Z) | (X) (Y) (Z) | (X) (Y) (Z)
DIRECTION COSINES: | DIRECTION COSINES: | DIRECTION COSINES:
1.0000 .0000 .0000 | .0000 1.0000 .0000 | .0000 .0000 1.0000

***** CAS(1)- SERVICE LEVEL B *****
MOMT. MAX. 42421.870 | MOMT. MAX. 49725.810 | MOMT. MAX. 76839.390
MOMT. MIN. -92798.200 | MOMT. MIN. -61184.600 | MOMT. MIN. -103314.600

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0018 .0000 .0000 | .0000 .0000 .0018 | .1399 .2599 .0999
-.0000 -.0143 -.0246 | -.0246 -.0143 -.0000 | -.1399 -.2599 -.0999

***** CAS(2)- SERVICE LEVEL C *****
MOMT. MAX. 70235.080 | MOMT. MAX. 95487.690 | MOMT. MAX. 205426.400
MOMT. MIN. -121010.700 | MOMT. MIN. -109141.900 | MOMT. MIN. -232148.400

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0166 .0000 .0100 | .0100 .0000 .0166 | .0000 .0000 .0000
-.0150 -.0129 -.0323 | -.0323 -.0129 -.0150 | .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
MOMT. MAX. 71247.480 | MOMT. MAX. 95821.190 | MOMT. MAX. 205983.700
MOMT. MIN. -122023.100 | MOMT. MIN. -109475.000 | MOMT. MIN. -232705.700

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0175 .0000 .0100 | .0100 .0000 .0175 | .1399 .2599 .0999
-.0150 -.0195 -.0436 | -.0436 -.0195 -.0150 | .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3+B *****
MOMT. MAX. .000 | MOMT. MAX. .000 | MOMT. MAX. .000
MOMT. MIN. .000 | MOMT. MIN. .000 | MOMT. MIN. .000

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

SUPTJSRL          9.38:17.58      6/ 7/1988          PAGE 50
  
```

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

ATTACHMENT 2  
 PAGE 54 OF 143  
 CALC. NO. C-0031/7TRD

NUTECH ENGINEERS  
PIPE SUPPORT LOAD COMB SYSTEM P:01

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBER: \_\_\_\_\_  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC00

```

NODE = H20      SUPPORT 1 OF 1                      (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = .0104, Z = .9999

SUPT: 50      SNUDDER
TRAN STIF. = .2530E+06
(X) (Y) (Z)
DIRECTION COSINES:
.0000 .0000 1.0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. 799.888
FORCE MIN. -799.888
AXIAL SWING MAX/MIN:
COMP = .2380, .0354
TEN = .0195, .0666
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0351 .0046 .2380 .2380 .0070 .0351 .1541 .2910 .14161
-.0648 -.0151 -.0195 -.0197 -.0153 -.0648 -.1541 -.2910 -.14161

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. 1489.455
FORCE MIN. -1489.455
AXIAL SWING MAX/MIN:
COMP = .2541, .0561
TEN = .0357, .0871
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0357 .0068 .2541 .2542 .0095 .0357 .0000 .0000 .00001
-.0854 -.0173 -.0357 -.0359 -.0177 -.0854 .0000 .0000 .00001

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 1494.598
FORCE MIN. -1494.598
AXIAL SWING MAX/MIN:
COMP = .2607, .0561
TEN = .0357, .0881
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0557 .0069 .2607 .2608 .0096 .0557 .1541 .2910 .14161
-.0864 -.0174 -.0357 -.0359 -.0177 -.0864 .0000 .0000 .00001

***** CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .00001
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .00001

SUPTJSRL          9:38:17.58      6/ 7/1988          PAGE 51
  
```

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

ATTACHMENT 2  
PAGE 55 OF 143  
CALC. NO. C-0031/7IRD



NUTECH ENGINEERS  
PIPE SUPPORT LOAD COMB. SYSTEM V1:01

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

```

NODE = H10      SUPPORT 1 OF 1      (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = .0104, Z = .9999

SUPT: 51      RIGID | SUPT: 52      RIGID |
TRAN STIF. = .3410E+07 | TRAN STIF. = .3410E+07 |
(X) (Y) (Z) | (X) (Y) (Z) |
DIRECTION COSINES: | DIRECTION COSINES: |
1.0000 .0000 .0000 | .0000 1.0000 .0000 |

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. 2702.804 | FORCE MAX. 1395.319 |
FORCE MIN. -2548.954 | FORCE MIN. -9285.413 |
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: |
COMP = .0207, .2417 | COMP = .0021, .2426 |
TEN = .0207, .0200 | TEN = .0044, .0285 |
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN: |
.0207 .0021 .2417 | .2417 .0044 .0207 | .1385 .2568 .1427 |
-.0207 -.0044 -.0195 | -.0196 -.0046 -.0207 | -.1385 -.2568 -.1427 |

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. 3298.809 | FORCE MAX. 2655.231 |
FORCE MIN. -3177.653 | FORCE MIN. -10521.610 |
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: |
COMP = .0389, .2579 | COMP = .0030, .2607 |
TEN = .0388, .0361 | TEN = .0033, .0528 |
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN: |
.0389 .0030 .2579 | .2579 .0037 .0389 | .0000 .0000 .0000 |
-.0388 -.0033 -.0357 | -.0358 -.0037 -.0388 | .0000 .0000 .0000 |

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 3309.095 | FORCE MAX. 2663.851 |
FORCE MIN. -3187.939 | FORCE MIN. -10530.230 |
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: |
COMP = .0389, .2646 | COMP = .0030, .2674 |
TEN = .0388, .0361 | TEN = .0054, .0528 |
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN: |
.0389 .0030 .2646 | .2646 .0058 .0389 | .1385 .2568 .1427 |
-.0388 -.0034 -.0357 | -.0358 -.0057 -.0388 | .0000 .0000 .0000 |

***** CAS(4)- SERVICE LEVEL J+B *****
FORCE MAX. .000 | FORCE MAX. .000 |
FORCE MIN. .000 | FORCE MIN. .000 |
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: |
N/A = .0000, .0000 | N/A = .0000, .0000 |
N/A = .0000, .0000 | N/A = .0000, .0000 |
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN: |
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000 |
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000 |

SUPT JSRL          9:38:17.58      6/7/1988          PAGE 52
  
```

ATTACHMENT 2  
 PAGE 56 OF 143  
 CALC. NO. C-0031/71RD

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB. SYSTEM P:01

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005 1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACOG

```

NODE = 1800L SUPPORT 1 OF 2 (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = .0104, Z = .9999

SUPT: 53 RIGID | SUPT: 54 RIGID | SUPT: 55 RIGID
TRAN STIF. = .2600E+03 | TRAN STIF. = .1250E+04 | TRAN STIF. = .1250E+04
(X) (Y) (Z) | (X) (Y) (Z) | (X) (Y) (Z)
DIRECTION COSINES: | DIRECTION COSINES: | DIRECTION COSINES:
.0000 .0000 1.0000 | .0000 1.0000 .0000 | 1.0000 .0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. 66.196 | FORCE MAX. 18.952 | FORCE MAX. 239.015
FORCE MIN. -5.093 | FORCE MIN. -9.187 | FORCE MIN. -111.084
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
COMP = .2546, .1918 | COMP = .0152, .3184 | COMP = .1912, .2551
TEN = .0196, .0892 | TEN = .0073, .0910 | TEN = .0889, .0209
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.1912 .0152 .2546 | .2547 .0178 .1912 | .2067 .4201 .1452
-.0889 -.0073 -.0196 | -.0197 -.0076 -.0889 | -.2067 -.4201 -.1452

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. 70.405 | FORCE MAX. 23.416 | FORCE MAX. 277.164
FORCE MIN. -9.308 | FORCE MIN. -13.710 | FORCE MIN. -149.420
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
COMP = .2708, .2225 | COMP = .0187, .3500 | COMP = .2217, .2714
TEN = .0358, .1200 | TEN = .0110, .1248 | TEN = .1195, .0374
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.2217 .0187 .2708 | .2710 .0215 .2217 | .0000 .0000 .0000
-.1195 -.0110 -.0358 | -.0359 -.0113 -.1195 | .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 72.242 | FORCE MAX. 23.441 | FORCE MAX. 282.110
FORCE MIN. -9.309 | FORCE MIN. -13.735 | FORCE MIN. -149.430
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
COMP = .2779, .2265 | COMP = .0188, .3580 | COMP = .2257, .2785
TEN = .0358, .1200 | TEN = .0110, .1248 | TEN = .1195, .0375
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.2257 .0188 .2779 | .2780 .0216 .2257 | .2067 .4201 .1452
-.1195 -.0110 -.0358 | -.0359 -.0114 -.1195 | .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. .000
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

SUPTJSRL 9:38:17.58 6/ 7/1988 PAGE 53
    
```

ATTACHMENT 2  
 PAGE 57 OF 143  
 CALC. NO. C-0031/TIRO

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC0D

```

MODE = 180BL SUPPORT 2 OF 2 (Rotation only)
PIPE DIRECTION COSINES: X = .0000, Y = .0104, Z = .9999

SUCT: 56 RIGID | SUCT: 57 RIGID | SUCT: 58 RIGID
ROT. STIF. = .5130E+05 | ROT. STIF. = .5130E+05 | ROT. STIF. = .5130E+05
(X) (Y) (Z) | (X) (Y) (Z) | (X) (Y) (Z)
DIRECTION COSINES: | DIRECTION COSINES: | DIRECTION COSINES:
.0000 .0000 1.0000 | .0000 1.0000 .0000 | 1.0000 .0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
MOMT. MAX. 214.082 | MOMT. MAX. 189.002 | MOMT. MAX. 2.763
MOMT. MIN. -88.879 | MOMT. MIN. -79.025 | MOMT. MIN. -5.179

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.1912 .0152 .2546 | .2547 .0178 .1912 | .2067 .4201 .1452
-.0889 -.0073 -.0196 | -.0197 -.0076 -.0889 | -.2067 -.4201 -.1452

***** CAS(2)- SERVICE LEVEL C *****
MOMT. MAX. 234.966 | MOMT. MAX. 204.197 | MOMT. MAX. 4.425
MOMT. MIN. -110.381 | MOMT. MIN. -94.401 | MOMT. MIN. -6.820

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.2217 .0187 .2708 | .2710 .0215 .2217 | .0000 .0000 .0000
-.1195 -.0110 -.0358 | -.0359 -.0113 -.1195 | .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
MOMT. MAX. 241.327 | MOMT. MAX. 208.552 | MOMT. MAX. 4.436
MOMT. MIN. -110.572 | MOMT. MIN. -94.416 | MOMT. MIN. -6.831

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.2257 .0188 .2779 | .2780 .0216 .2257 | .2067 .4201 .1452
-.1195 -.0110 -.0358 | -.0359 -.0114 -.1195 | .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3#B *****
MOMT. MAX. .000 | MOMT. MAX. .000 | MOMT. MAX. .000
MOMT. MIN. .000 | MOMT. MIN. .000 | MOMT. MIN. .000

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

SUCTJ3RL 9:38:17.58 6/ 7/1988 PAGE 54
    
```

ATTACHMENT 58 OF 143  
 PAGE 58 OF 143  
 CALC. NO. C-0031/TIRO

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS  
 PIPE SUPPORT LOAD COMB. SYSTEM P701

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACOD

```

NODE = H3B      SUPPORT 1 OF 1.                (Trans. only)

PIPE DIRECTION COSINES: X = .0000, Y = .0104, Z = .9999

SUPT: 59      RIGID
TRAN STIF. = .8340E+06
(X) (Y) (Z)
DIRECTION COSINES:
.0000 1.0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. -2775.906
AXIAL SWING MAX/MIN:
COMP = .0018, .6226
TEN. = .0053, .2490
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.5557 .0018 .2807 .2807 .0047 .5557 .5625 .2431 .1464
-.2482 -.0053 -.0196 -.0196 -.0055 -.2482 -.5625 -.2431 -.1464

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. 211.305
FORCE MIN. -3175.498
AXIAL SWING MAX/MIN:
COMP = .0042, .6852
TEN. = .0077, .3126
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.6175 .0042 .2969 .2969 .0072 .6175 .0000 .0000 .0000
-.3105 -.0077 -.0358 -.0358 -.0081 -.3105 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 216.096
FORCE MIN. -3180.289
AXIAL SWING MAX/MIN:
COMP = .0042, .6984
TEN. = .0077, .3127
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.6284 .0042 .3047 .3047 .0074 .6284 .5625 .2431 .1464
-.3106 -.0077 -.0358 -.0359 -.0081 -.3106 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3RB *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTJSRL          9:38:17.58      6/ 7/1988          PAGE 55
  
```

ATTACHMENT  
 PAGE 59 OF 143  
 2  
 FILE NO. C-0031/TIRO

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC00

```

-----
| NODE = H5B      SUPPORT 1 OF 1                      (Trans. only) |
| PIPE DIRECTION COSINES: X = .0000, Y = 1.0000, Z = .0000 |
| SUPT: 60      R10D |
| TRAN STIF. = .3850E+06 |
| (X) (Y) (Z) |
| DIRECTION COSINES: |
| -.5210 .0000 -.8335 |
| ***** |
| CAS(1)- SERVICE LEVEL B ***** |
| FORCE MAX. 122.807 |
| FORCE MIN. -464.223 |
| AXIAL SWING MAX/MIN: |
| TEN. = .0392, .0613 |
| COMP = .0384, .0236 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0358 .0586 .0241 .0586 .0241 .0358 .1386 .2775 .0981 |
| -.0356 -.0148 -.0232 -.0148 -.0232 -.0356 -.1386 -.2775 -.0981 |
| ***** |
| CAS(2)- SERVICE LEVEL C ***** |
| FORCE MAX. 224.480 |
| FORCE MIN. -568.905 |
| AXIAL SWING MAX/MIN: |
| TEN. = .0796, .0716 |
| COMP = .0787, .0401 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0715 .0624 .0496 .0624 .0496 .0715 .0000 .0000 .0000 |
| -.0713 -.0186 -.0486 -.0186 -.0486 -.0713 .0000 .0000 .0000 |
| ***** |
| CAS(3)- SERVICE LEVEL D ***** |
| FORCE MAX. 232.925 |
| FORCE MIN. -577.350 |
| AXIAL SWING MAX/MIN: |
| TEN. = .0796, .0729 |
| COMP = .0787, .0401 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0715 .0638 .0496 .0638 .0496 .0715 .1386 .2775 .0981 |
| -.0713 -.0186 -.0487 -.0186 -.0487 -.0713 .0000 .0000 .0000 |
| ***** |
| CAS(4)- SERVICE LEVEL J#B ***** |
| FORCE MAX. .000 |
| FORCE MIN. .000 |
| AXIAL SWING MAX/MIN: |
| N/A = .0000, .0000 |
| N/A = .0000, .0000 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| ***** |
| SUPTJSRL 9:38:17.58 6/ 7/1988 PAGE 56 |
-----
    
```

ATTACHMENT 2  
 PAGE 60 OF 143  
 CALC. NO. C-0031/TIRO

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NOUILLON LNUINLLR J  
 PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBER  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) P5E005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

```

NODE = H4B      SUPPORT 1 OF 1      (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = 1.0000, Z = .0000

SUPT: 61      RIGID
TRAN STIF. = .3160E+06
(X) (Y) (Z)
DIRECTION COSINES:
.6264 .0000 -.7795

*****
CAS(1)- SERVICE LEVEL B *****
FORCE MAX.      85.395
FORCE MIN.     -403.786
AXIAL SWING MAX/MIN:
COMP = .0029, .0729
TEN = .0035, .0591
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0340 .0600 .0236 .0600 .0236 .0340 .1455 .2776 .1019
-.0468 -.0148 -.0332 -.0148 -.0332 -.0468 -.1455 -.2776 -.1019

*****
CAS(2)- SERVICE LEVEL C *****
FORCE MAX.     171.750
FORCE MIN.    -488.398
AXIAL SWING MAX/MIN:
COMP = .0052, .1067
TEN = .0058, .1031
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0699 .0639 .0494 .0639 .0494 .0699 .0000 .0000 .0000
-.0827 -.0186 -.0590 -.0186 -.0590 -.0827 .0000 .0000 .0000

*****
CAS(3)- SERVICE LEVEL D *****
FORCE MAX.     175.813
FORCE MIN.    -494.595
AXIAL SWING MAX/MIN:
COMP = .0052, .1076
TEN = .0059, .1037
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0699 .0654 .0494 .0654 .0494 .0699 .1455 .2776 .1019
-.0832 -.0186 -.0593 -.0186 -.0593 -.0832 .0000 .0000 .0000

*****
CAS(4)- SERVICE LEVEL 3+B *****
FORCE MAX.      .000
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPT JSRL      9:38:17.58      6/ 7/1988      PAGE 57
    
```

ATTACHMENT 2  
 PAGE 61 OF 143  
 CALC. NO. C-0031/TIRO

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

OUTPUT SAVED IN FILE : P201SUP.SI

NORMAL COMPLETION AT 9:42: 5.30 6/ 7/1988

SUPTJSRL

9:38:17.58

6/ 7/1988

PAGE 58

ATTACHMENT 2  
PAGE 62 OF 143  
CALC. NO. C-0031/7IRD

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE  
COMPLIANCE DOCUMENTATION  
SYSTEM P-201, HANGER GUIDANCE

ID NO. C-31-HG  
REFERENCE NONE

SHEET  
B-1  
OF  
41

ORIGINATOR	071	6					
DATE	06-07-86						
VFR or CKR	NSH						
DATE	6/7/88						

ATTACHMENT B

OPTSUPT RUNID SUPTJYVD DATED 06-07-88  
( 40 Pages)

ATTACHMENT 2  
PAGE 63 OF 143  
CALC. NO. C-0031/TIRO



NUTECH ENGINEERS  
 PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUGGER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE003.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

```

N N U U TTTT EEEEE CCCC H H
NN N U U T E C H H
NNN U U T EEEEE C HH#H
N NN U U T E C H H
N N UUUU T EEEEE CCCC H H
    
```

```

OOOO, PPPP TTTT SSSS U U PPPP TTTT
O O P P T S U U P P T
O O PPPP T SSSS U U PPPP T
O O P T S U U P T
OOOO P T SSSS UUUU P T
    
```

REVISION 1.0.0  
 LEVEL FEB-25-1988

OPTSUPT RUN: ID = SUPTJYVD TIME = 9:44:21. 2 DATE = 6/ 7/1988

CALCULATION PACKAGE FILE NUMBER = (C-31) PSE003.1016

COMPUTER RUN FILE NUMBER = ACQD

COMPUTER RUN OUTPUT FILE NAME = P201SUP.82

OPTPIPE TAPE 51 INPUT:  
 FILE NAME = P201SUP.T51 RUN ID = ACQD DATE = 88/06/06

OPTPIPE TAPE 52 INPUT:  
 FILE NAME = P201SUP.T52 RUN ID = ACQD DATE = 88/06/06

FILE CONTAINING ADDITIONAL LOAD CASE DATA:  
 FILE NAME =

PREPARED BY/DATE: *C. J. Mehta* 06-07-88  
 C. J. MEHTA

CHECKED BY/DATE: *A. S. Herlekar* 6/7/88  
 A. S. HERLEKAR

SUPTJYVD 9:44:21. 2 6/ 7/1988 PAGE 1

ATTACHMENT  
 PAGE 64 OF 143  
 CALC. NO. C-0031/TIRO  
 2

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) P5E005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC00

HPCI TURBINE EXHAUST (P201) NORMAL LOADS MODEL

NUMBER OF POINTS = 111 NUMBER OF PIPE RUNS = 1  
 NUMBER OF SUPPORTS = 61 NUMBER OF TEES = 0  
 NUMBER OF PIPES = 106 NUMBER OF BEAMS = 0  
 NUMBER OF LOAD CASES = 69

CASE ID	LOAD CASE DESCRIPTION	CASE ID	LOAD CASE DESCRIPTION
OBEDX		OBEDY	
OBEDZ		SBEDX	
SSEDY		SSEDZ	
DL		QAB	
CHUGO		CHUGF	
FW		TE	
TE1		TE2	
THAMA		TD	
GARI		GABIB	
COJ		CHUCI	
OBEI		SSEI	
OBFD		SSED	
MXEQD		MXEQI	
CHUG		CO	
THAM		THAMI	
THAM2		TD1	
TD2		TE2T	
THTD		TEHD	
THTD1		TEHD1	
TMAX		TMAX1	
A2A		A-2	
A3A		A-3	
A4A		A-4	
B-2		B-MAX	
C2		C-1	
C3A		C-3	
C-MAX		D-1	

ATTACHMENT 2  
 PAGE 65 OF 143  
 CALC. NO. 2-0031/7IRB

NUTECH ENGINEERS  
PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUDDER REDUCTION \_\_\_\_\_ FILE NUMBERS \_\_\_\_\_  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

CASE ID	LOAD CASE DESCRIPTION	CASE ID	LOAD CASE DESCRIPTION
D3A		D-3	
D-MAX		DWS	
OB1D		SS1D	
MXEQ		SLA1	
SLD1		SLD1	
SLD2		SLD3	
SLA		SLB	
SLD			

ECHO OF COMBINATION PROCEDURE INPUT FILE SUPT1

- CAS(1) - SERVICE LEVEL B
- CAS(2) - SERVICE LEVEL C
- CAS(3) - SERVICE LEVEL D
- CAS(4) - SERVICE LEVEL 3\*B
- CAS(1) - L. C. NO. A-1 (DW ONLY)
- LID(DW)
- CAS(4) - L. C. NO. THAX (N. O. C. THERMAL ONLY)
- LID(THAX)

ATTACHMENT  
 PAGE 66 of 143  
 CALC. NO. C-0031/71RD

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB. SYSTEM 1701

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC00

```

NODE = 17SAN SUPPORT 1 OF 2 (Trans. only)
PIPE DIRECTION COSINES: X = .1745, Y = -.7074, Z = -.6849

SAPT: 1 RIGID | SUPT: 2 RIGID | SUPT: 3 RIGID
TRAN STIF. = .1000E+09 | TRAN STIF. = .1000E+09 | TRAN STIF. = .1000E+09
(X) (Y) (Z) | (X) (Y) (Z) | (X) (Y) (Z)
DIRECTION COSINES: | DIRECTION COSINES: | DIRECTION COSINES:
.9808 .0000 .1951 | -.1379 -.7071 .6936 | .1379 -.7071 -.6936

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. 200.557 | FORCE MAX. 398.108 | FORCE MAX. 5752.025
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
COMP= .0000, .0000 | TEN= .0000, .0000 | COMP= .0000, .0000
TEN= .0000, .0001 | COMP= .0000, .0001 | COMP= .0001, .0000
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 -.0000 -.0000 | .0001 .0000 .0000 | .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. .000
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. .000
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3+8 *****
FORCE MAX. 74.715 | FORCE MAX. 1.434 | FORCE MAX. 1997.349
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
COMP= .1088, .0217 | TEN= .0153, .1099 | COMP= .0153, .1099
TEN= .1089, .5489 | TEN= .3579, .4302 | COMP= .4163, .3740
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.1110 .0000 .0000 | .0194 .0194 .1075 | .0000 .0000 .0000
.0000 -.0413 -.3581 | -.4115 -.4118 -.1378 | .0000 .0000 .0000

SAPTJYVD 9:44:21.2 6/ 7/1988 PAGE 4
    
```

ATTACHMENT  
 PAGE 67 OF 143  
 CALC. NO. C-0031/TIRO

NUTTECH ENGINEERS

PIPE SUPPORT LOAD COMB. SYSTEM P:01

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005, 1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC00

NODE = 17SAN SUPPORT 2 OF 2			(Rotation only)		
PIPE DIRECTION COSINES: X = .1745, Y = -.7074, Z = -.6849					
SUPT: 4 RIGID	SUPT: 5 RIGID	SUPT: 6 RIGID			
ROT STIF. = .1000E+11	ROT. STIF. = .1000E+11	ROT STIF. = .1000E+11			
(X) (Y) (Z)	(X) (Y) (Z)	(X) (Y) (Z)			
DIRECTION COSINES:		DIRECTION COSINES:		DIRECTION COSINES:	
.9808	.0000	.1951	-.1379	-.7071	-.6936
***** CAS(1)- SERVICE LEVEL B *****					
MOMT. MAX.	2397.099	MOMT. MAX.	97.829	MOMT. MAX.	.000
MOMT. MIN.	.000	MOMT. MIN.	.000	MOMT. MIN.	-90.351
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.0000	.0000	.0000	.0000	.0000	.0000
.0000	-.0000	-.0000	.0001	.0000	.0000
***** CAS(2)- SERVICE LEVEL C *****					
MOMT. MAX.	.000	MOMT. MAX.	.000	MOMT. MAX.	.000
MOMT. MIN.	.000	MOMT. MIN.	.000	MOMT. MIN.	.000
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.0000	.0000	.0000	.0000	.0000	.0000
.0000	.0000	.0000	.0000	.0000	.0000
***** CAS(3)- SERVICE LEVEL D *****					
MOMT. MAX.	.000	MOMT. MAX.	.000	MOMT. MAX.	.000
MOMT. MIN.	.000	MOMT. MIN.	.000	MOMT. MIN.	.000
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.0000	.0000	.0000	.0000	.0000	.0000
.0000	.0000	.0000	.0000	.0000	.0000
***** CAS(4)- SERVICE LEVEL 3#B *****					
MOMT. MAX.	.000	MOMT. MAX.	4.833	MOMT. MAX.	.529
MOMT. MIN.	-6.102	MOMT. MIN.	.000	MOMT. MIN.	.000
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.1110	.0000	.0000	.0194	.0194	.1075
.0000	-.0413	-.5581	-.4115	-.4118	-.1378
SUPT JVVD		9:44:21.2		6/7/1988	
				PAGE 5	

ATTACHMENT  
 PAGE 68 of 143  
 CALC. NO. C-0031/TIRD

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACOD

NODE = 19SBN			SUPPORT 1 OF 2			(Trans. only)		
PIPE DIRECTION COSINES: X = -.5521, Y = -.7074, Z = -.4414								
SUPT: 7	RIGID	SUPT: 8	RIGID	SUPT: 9	RIGID			
TRAN STIF. = .1000E+09			TRAN STIF. = .1000E+09			TRAN STIF. = .1000E+09		
(X)	(Y)	(Z)	(X)	(Y)	(Z)	(X)	(Y)	(Z)
DIRECTION COSINES:			DIRECTION COSINES:			DIRECTION COSINES:		
1.0000	.0000	.0000	.0000	-.7071	.7071	.0000	-.7071	-.7071
***** CAS(1)- SERVICE LEVEL B *****								
FORCE MAX. .000			FORCE MAX. 990.717			FORCE MAX. 2135.455		
FORCE MIN. -1008.751			FORCE MIN. .000			FORCE MIN. .000		
AXIAL SWING MAX/MIN:			AXIAL SWING MAX/MIN:			AXIAL SWING MAX/MIN:		
N/A = .0000, .0000			N/A = .0000, .0000			N/A = .0000, .0000		
TEN. = .0000, .0000			COMP = .0000, .0000			COMP = .0000, .0000		
GLOBAL DISPL. MAX/MIN:			LOCAL DISPL. MAX/MIN:			GLOBAL ACCEL. MAX/MIN:		
.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000
-.0000	-.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000
***** CAS(2)- SERVICE LEVEL C *****								
FORCE MAX. .000			FORCE MAX. .000			FORCE MAX. .000		
FORCE MIN. .000			FORCE MIN. .000			FORCE MIN. .000		
AXIAL SWING MAX/MIN:			AXIAL SWING MAX/MIN:			AXIAL SWING MAX/MIN:		
N/A = .0000, .0000			N/A = .0000, .0000			N/A = .0000, .0000		
N/A = .0000, .0000			N/A = .0000, .0000			N/A = .0000, .0000		
GLOBAL DISPL. MAX/MIN:			LOCAL DISPL. MAX/MIN:			GLOBAL ACCEL. MAX/MIN:		
.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000
.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000
***** CAS(3)- SERVICE LEVEL D *****								
FORCE MAX. .000			FORCE MAX. .000			FORCE MAX. .000		
FORCE MIN. .000			FORCE MIN. .000			FORCE MIN. .000		
AXIAL SWING MAX/MIN:			AXIAL SWING MAX/MIN:			AXIAL SWING MAX/MIN:		
N/A = .0000, .0000			N/A = .0000, .0000			N/A = .0000, .0000		
N/A = .0000, .0000			N/A = .0000, .0000			N/A = .0000, .0000		
GLOBAL DISPL. MAX/MIN:			LOCAL DISPL. MAX/MIN:			GLOBAL ACCEL. MAX/MIN:		
.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000
.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000
***** CAS(4)- SERVICE LEVEL 3#B *****								
FORCE MAX. 711.117			FORCE MAX. .000			FORCE MAX. .000		
FORCE MIN. .000			FORCE MIN. -241.233			FORCE MIN. -1048.208		
AXIAL SWING MAX/MIN:			AXIAL SWING MAX/MIN:			AXIAL SWING MAX/MIN:		
N/A = .0000, .0000			TEN. = .0000, .0000			TEN. = .0000, .0000		
TEN. = .0000, .5596			TEN. = .3651, .4241			COMP = .4241, .3651		
GLOBAL DISPL. MAX/MIN:			LOCAL DISPL. MAX/MIN:			GLOBAL ACCEL. MAX/MIN:		
.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000
.0000	-.0417	-.5581	-.2758	-.2760	-.4359	.0000	.0000	.0000
SUPT:VVD			9: 44: 21. 2			6/ 7/1988		
						PAGE 6		

ATTACHMENT 2  
PAGE 69 OF 143  
CALC. NO. C-0531/71RD

NOVELL CONSULTING  
 PIPE SUPPORT LOAD COMP. SYSTEM P:01

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACCO

NODE = 195BN SUPPORT 2 OF 2 (Rotation only)		
PIPE DIRECTION COSINES. X = -.5921. Y = -.7074. Z = -.4414		
SUPT: 10 RIGID ROT. STIF. = .1000E+11 (X) (Y) (Z)	SUPT: 11 RIGID ROT. STIF. = .1000E+11 (X) (Y) (Z)	SUPT: 12 RIGID ROT. STIF. = .1000E+11 (X) (Y) (Z)
DIRECTION COSINES: 1.0000 .0000 .0000	DIRECTION COSINES: .0000 -.7071 .7071	DIRECTION COSINES: .0000 -.7071 -.7071
***** CAS(1)- SERVICE LEVEL B *****		
MOMT. MAX. 2530.344 MOMT. MIN. .000	MOMT. MAX. .000 MOMT. MIN. -2258.183	MOMT. MAX. 2243.646 MOMT. MIN. .000
GLOBAL DISPL. MAX/MIN: .0000 .0000 .0000 -.0000 -.0000 .0000	LOCAL DISPL. MAX/MIN: .0000 .0000 .0000 .0000 .0000 .0000	GLOBAL ACCEL. MAX/MIN: .0000 .0000 .0000 .0000 .0000 .0000
***** CAS(2)- SERVICE LEVEL C *****		
MOMT. MAX. .000 MOMT. MIN. .000	MOMT. MAX. .000 MOMT. MIN. .000	MOMT. MAX. .000 MOMT. MIN. .000
GLOBAL DISPL. MAX/MIN: .0000 .0000 .0000 .0000 .0000 .0000	LOCAL DISPL. MAX/MIN: .0000 .0000 .0000 .0000 .0000 .0000	GLOBAL ACCEL. MAX/MIN: .0000 .0000 .0000 .0000 .0000 .0000
***** CAS(3)- SERVICE LEVEL D *****		
MOMT. MAX. .000 MOMT. MIN. .000	MOMT. MAX. .000 MOMT. MIN. .000	MOMT. MAX. .000 MOMT. MIN. .000
GLOBAL DISPL. MAX/MIN: .0000 .0000 .0000 .0000 .0000 .0000	LOCAL DISPL. MAX/MIN: .0000 .0000 .0000 .0000 .0000 .0000	GLOBAL ACCEL. MAX/MIN: .0000 .0000 .0000 .0000 .0000 .0000
***** CAS(4)- SERVICE LEVEL 3*B *****		
MOMT. MAX 7.552 MOMT. MIN .000	MOMT. MAX. 6.451 MOMT. MIN. .000	MOMT. MAX. 3.875 MOMT. MIN. .000
GLOBAL DISPL. MAX/MIN: .0000 .0000 .0000 .0000 -.0417 -.5381	LOCAL DISPL. MAX/MIN: .0000 .0000 .0000 -.2758 -.2760 -.4359	GLOBAL ACCEL. MAX/MIN: .0000 .0000 .0000 .0000 .0000 .0000
SUPTJYVD	9:44:21. 2	6/ 7/1988
		PAGE 7

ATTACHMENT 2  
 PAGE 70 OF 143  
 CALC. NO. C-0031/71R00

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

```

NODE = P201      SUPPORT 1 OF 2                      (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = .0000, Z = -1.0000

SUPT: 13      RIGID | SUPT: 14      RIGID | SUPT: 15      RIGID
TRAN. STIF. = .3160E+08 | TRAN. STIF. = .5120E+07 | TRAN. STIF. = .1470E+07
(X) (Y) (Z) | (X) (Y) (Z) | (X) (Y) (Z)
DIRECTION COSINES: | DIRECTION COSINES: | DIRECTION COSINES:
1.0000 .0000 .0000 | .0000 -.9848 -.1736 | .0000 .1736 -.9848

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. 192.986 | FORCE MAX. 5175.962 | FORCE MAX. .000
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. -5412.059
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
COMP = .0000, .0035 | TEN = .0006, .0034 | TEN = .0034, .0006
TEN = .0000, .0016 | COMP = .0016, .0003 | TEN = .0003, .0016
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0035 | -.0035 .0000 .0000 | .0000 .0000 .0000
.0000 -.0016 .0000 | .0000 -.0016 .0000 | .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. .000
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. .000
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3#B *****
FORCE MAX. 1922.614 | FORCE MAX. 1701.451 | FORCE MAX. .000
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. -3508.132
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
COMP = .0807, .0567 | TEN = .0598, .0813 | COMP = .0098, .0981
TEN = .0000, .6363 | COMP = .1105, .6266 | COMP = .6266, .1105
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0807 .0567 .0000 | .0000 .0567 .0807 | .0000 .0000 .0000
.0000 .0000 -.6363 | -.6363 .0000 .0000 | .0000 .0000 .0000

SUPTJYVD          9:44:21. 2      6/ 7/1988          PAGE 8
    
```

ATTACHMENT 2  
 PAGE 71 of 143  
 CALC NO. C-0031/TIRD

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222



HUILUH LHVHLLHJ  
 PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP ACOD

```

NODE = P201      SUPPORT 2 OF 2      (Rotation only)
PIPE DIRECTION COSINES: X = .0000, Y = .0000, Z = -1.0000

SUPT: 16      RIGID      SUPT: 17      RIGID      SUPT: 18      RIGID
ROT. STIF. = .1570E+08  ROT. STIF. = .1566E+08  ROT. STIF. = .2970E+07
(X) (Y) (Z)      (X) (Y) (Z)      (X) (Y) (Z)
DIRECTION COSINES:      DIRECTION COSINES:      DIRECTION COSINES:
1.0000 .0000 .0000      .0000 -.9848 -.1736      .0000 .1736 -.9848

*****
CAS(1)- SERVICE LEVEL B      *****
MOMT. MAX.      1761.167      MOMT. MAX.      .000      MOMT. MAX.      227.921
MOMT. MIN.      .000      MOMT. MIN.      -589.058      MOMT. MIN.      .000

GLOBAL DISPL. MAX/MIN:      LOCAL DISPL. MAX/MIN:      GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0035      -.0035 .0000 .0000      .0000 .0000 .0000
.0000 -.0016 .0000      .0000 -.0016 .0000      .0000 .0000 .0000

*****
CAS(2)- SERVICE LEVEL C      *****
MOMT. MAX.      .000      MOMT. MAX.      .000      MOMT. MAX.      .000
MOMT. MIN.      .000      MOMT. MIN.      .000      MOMT. MIN.      .000

GLOBAL DISPL. MAX/MIN:      LOCAL DISPL. MAX/MIN:      GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000      .0000 .0000 .0000      .0000 .0000 .0000
.0000 .0000 .0000      .0000 .0000 .0000      .0000 .0000 .0000

*****
CAS(3)- SERVICE LEVEL D      *****
MOMT. MAX.      .000      MOMT. MAX.      .000      MOMT. MAX.      .000
MOMT. MIN.      .000      MOMT. MIN.      .000      MOMT. MIN.      .000

GLOBAL DISPL. MAX/MIN:      LOCAL DISPL. MAX/MIN:      GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000      .0000 .0000 .0000      .0000 .0000 .0000
.0000 .0000 .0000      .0000 .0000 .0000      .0000 .0000 .0000

*****
CAS(4)- SERVICE LEVEL 3*B      *****
MOMT. MAX.      5771.816      MOMT. MAX.      11688.840      MOMT. MAX.      .000
MOMT. MIN.      .000      MOMT. MIN.      .000      MOMT. MIN.      -5447.514

GLOBAL DISPL. MAX/MIN:      LOCAL DISPL. MAX/MIN:      GLOBAL ACCEL. MAX/MIN:
.0807 .0567 .0000      .0000 .0567 .0807      .0000 .0000 .0000
.0000 .0000 -.6363      -.6363 .0000 .0000      .0000 .0000 .0000

SUPTJVVD      9:44:21. 2      6/ 7/1988      PAGE 9
    
```

ATTACHMENT 1  
 PAGE 72 OF 143  
 CALC. NO. C-0031 / 7TRD

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) P5E003.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACOD

NODE = H19 SUPPORT 1 OF 1 (Trans. only)

PIPE DIRECTION COSINES: X = .0000, Y = 1.0000, Z = .0000

SUPT: 19 ~~21210~~  
TRAN STIF. = .1800E+04  
(X) (Y) (Z)

SPRING HANGER.  
Hot Load = 4940. # } *02/06/88*

DIRECTION COSINES:  
.0000 1.0000 .0000

\*\*\*\*\* CAS(1)- SERVICE LEVEL B \*\*\*\*\*  
FORCE MAX. 35.435  
FORCE MIN. .000  
AXIAL, SWING MAX/MIN:  
COMP = .0197, .0019  
TEN. = .0000, .0013  
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:  
.0000 .0197 .0019 .0197 .0019 .0000 .0000 .0000 .0000  
-.0013 .0000 .0000 .0000 .0000 -.0013 .0000 .0000 .0000

\*\*\*\*\* CAS(2)- SERVICE LEVEL C \*\*\*\*\*  
FORCE MAX. .000  
FORCE MIN. .000  
AXIAL, SWING MAX/MIN:  
N/A = .0000, .0000  
N/A = .0000, .0000  
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:  
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000  
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

\*\*\*\*\* CAS(3)- SERVICE LEVEL D \*\*\*\*\*  
FORCE MAX. .000  
FORCE MIN. .000  
AXIAL, SWING MAX/MIN:  
N/A = .0000, .0000  
N/A = .0000, .0000  
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:  
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000  
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

\*\*\*\*\* CAS(4)- SERVICE LEVEL 3\*B \*\*\*\*\*  
FORCE MAX. 329.086  
FORCE MIN. .000  
AXIAL, SWING MAX/MIN:  
COMP = .1828, .1367  
TEN. = .0000, .1532  
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:  
.1367 .1828 .0000 .1828 .0000 .1367 .0000 .0000 .0000  
.0000 .0000 -.1532 .0000 -.1532 .0000 .0000 .0000 .0000

SUPTJYVD 9:44:21.2 6/7/1988 PAGE 10

ATTACHMENT 2  
PAGE 73 OF 143  
CALC. NO. C-003171RD

NUTECH ENGINEERS  
 PIPE SUPPORT LOAD COMB. SYSTEM P'01

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) P5E005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

```

NODE = H18      SUPPORT 1 OF 1      (Trans. only)
PIPE DIRECTION COSINES: X = -1.0000, Y = .0091, Z = .0000

SUPT: 20 SNUBBER
TRAN. STIF. = .2590E+06
(X) (Y) (Z)
DIRECTION COSINES:
.0000 1.0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL, SWING MAX/MIN:
COMP = .0065, .0001
TEN = .0000, .0128
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0065 .0001 .0001 .0065 -.0001 .0000 .0000 .0000
-.0128 .0000 .0000 .0128 -.0001 .0000 .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL, SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL, SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 34B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL, SWING MAX/MIN:
COMP = .2197, .1285
TEN = .0000, .0059
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.1285 .2197 .0000 .1305 .2208 .0000 .0000 .0000 .0000
.0000 .0000 -.0059 .0000 .0000 -.0059 .0000 .0000 .0000

SUPT:JYVD          9:44:21.2      6/ 7/1988          PAGE 11
    
```

ATTACHMENT 1 2  
 PAGE 74 OF 143  
 CALC. NO. C-0031/71RD

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PIPE SUPPORT LOAD COMB. SYSTEM P701

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) P8E005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP ACGR

```

-----
: NODE = H17      SUPPORT 1 OF 1      (Trans. only)
:
:   PIPE DIRECTION COSINES: X = -1.0000, Y = .0093, Z = .0000
:
: SUPT: 21      RIGID
: TRAN STIF. = .1320E+07
: (X) (Y) (Z)
: DIRECTION COSINES:
: .0000 .0000 1.0000
:
: ***** CAS(1)- SERVICE LEVEL B *****
: FORCE MAX.      148.664
: FORCE MIN.      .000
: AXIAL SWING MAX/MIN:
: COMP = .0001, .0050
: TEN = .0000, .0128
: GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
: .0000 .0050 .0001 .0000 .0050 -.0001 .0000 .0000 .0000
: -.0128 .0000 .0000 .0128 -.0001 .0000 .0000 .0000 .0000
:
: ***** CAS(2)- SERVICE LEVEL C *****
: FORCE MAX.      .000
: FORCE MIN.      .000
: AXIAL SWING MAX/MIN:
: N/A = .0000, .0000
: N/A = .0000, .0000
: GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
: .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
: .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
:
: ***** CAS(3)- SERVICE LEVEL D *****
: FORCE MAX.      .000
: FORCE MIN.      .000
: AXIAL SWING MAX/MIN:
: N/A = .0000, .0000
: N/A = .0000, .0000
: GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
: .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
: .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
:
: ***** CAS(4)- SERVICE LEVEL 3#B *****
: FORCE MAX.      .000
: FORCE MIN.     -6129.540
: AXIAL SWING MAX/MIN:
: TEN = .0000, .2414
: TEN = .0046, .0000
: GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
: .1210 .2089 .0000 .1229 .2100 .0000 .0000 .0000 .0000
: .0000 .0000 -.0046 .0000 .0000 -.0046 .0000 .0000 .0000
:
: SUPTJYVD      9:44:21.2      6/ 7/1988      PAGE 12
-----
    
```

ATTACHMENT 2  
 PAGE 75 OF 143  
 CALC. NO. C-0031/TIR0

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS

PIPE SUPPORT LOAD COND. SYSTEM P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005, 1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC00

```

NODE = H22      SUPPORT 1 OF 1                      (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = 1.0000, Z = .0000

SUPT: 22      SNUBBER
TRAN STIF. = .8700E+05
(X) (Y) (Z)
DIRECTION COSINES:
.0000 .0000 1.0000

*****
CAS(1)- SERVICE LEVEL B *****
FORCE MAX.      .000
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
TEN. = .0000, .0002
TEN. = .0007, .0250
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0002 .0000 .0000 .0000 .0000 .0000
-.0250 .0000 -.0007 .0000 -.0007 -.0250 .0000 .0000 .0000

*****
CAS(2)- SERVICE LEVEL C *****
FORCE MAX.      .000
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

*****
CAS(3)- SERVICE LEVEL D *****
FORCE MAX.      .000
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

*****
CAS(4)- SERVICE LEVEL 3#B *****
FORCE MAX.      .000
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
COMP = .0683, .2441
TEN. = .0000, .0635
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .2441 .0683 .2441 .0683 .0000 .0000 .0000 .0000
-.0635 .0000 .0000 .0000 .0000 -.0635 .0000 .0000 .0000

SUPT:JVVD      9:44:21. 2      6/ 7/1988      PAGE 13
    
```

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

ATTACHMENT 12  
 PAGE 76 OF 143  
 CALC. NO. C-0031/7120

PIPE SUPPORT LOAD COMD. SYSTEM P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PBE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACOD

```

-----
| NODE = H14      SUPPORT 1 OF 1                      (Trans. only) |
| PIPE DIRECTION COSINES: X = -1.0000, Y = .0092, Z = .0000 |
| SUPT: 24      RIGID |
| TRAN STIF. = .3491E+07 |
| (X) (Y) (Z) |
| DIRECTION COSINES: |
| .0000 .0000 1.0000 |
| ***** CAS(1)- SERVICE LEVEL B ***** |
| FORCE MAX. .000 |
| FORCE MIN. -82.637 |
| AXIAL SWING MAX/MIN: |
| N/A = .0000, .0000 |
| TEN. = .0000, .0134 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| -.0129 -.0035 -.0000 .0129 -.0036 .0000 .0000 .0000 .0000 |
| ***** CAS(2)- SERVICE LEVEL C ***** |
| FORCE MAX. .000 |
| FORCE MIN. .000 |
| AXIAL SWING MAX/MIN: |
| N/A = .0000, .0000 |
| N/A = .0000, .0000 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| ***** CAS(3)- SERVICE LEVEL D ***** |
| FORCE MAX. .000 |
| FORCE MIN. .000 |
| AXIAL SWING MAX/MIN: |
| N/A = .0000, .0000 |
| N/A = .0000, .0000 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| ***** CAS(4)- SERVICE LEVEL 3+B ***** |
| FORCE MAX. 5067.824 |
| FORCE MIN. .000 |
| AXIAL SWING MAX/MIN: |
| COMP = .0015, .1514 |
| N/A = .0000, .0000 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0700 .1343 .0015 .0712 .1349 .0015 .0000 .0000 .0000 |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| SUPT: JVD          9:44:21. 2      6/ 7/1988          PAGE 14 |
-----
    
```

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

ATTACHMENT 2  
 PAGE 77 OF 143  
 CALC. NO. C-0031/TIRD

NUTECH ENGINEERS  
 PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

```

NODE = H15      SUPPORT 1 OF 1                      (Trans. only)
PIPE DIRECTION COSINES: X = -1.0000, Y = .0040, Z = .0000

SUPT: 23  SNUBBER
TRAN STIF. = .4950E+06
(X) (Y) (Z)
DIRECTION COSINES:
.0000 1.0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
TEN. = .0045, .0129
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
-.0129 -.0045 -.0000 .0129 -.0045 .0000 .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3#B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
COMP = .1234, .0628
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0628 .1234 .0024 .0632 .1236 .0024 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTJYVD          9: 44: 21. 2      6/ 7/1988          PAGE 15
    
```

DRAWING  
 PAGE 78 OF 143  
 CALC. NO. C-0031 TIRD  
 2

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB. SYSTEM #201

PROJECT: HOPE CREEK SMOODER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

```

NODE = H13      SUPPORT 1 OF 1      (Trans. only)
PIPE DIRECTION COSINES: X = -1.0000, Y = .0091, Z = .0000

SUPT: 25      R101D
TRAN STIF. = .4800E+06
(X) (Y) (Z)
DIRECTION COSINES:
.0000 1.0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. -6081.771
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
TEN. = .0127, .0130
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
-.0130 -.0127 -.0002 .0128 -.0128 .0002 .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX. 5665.209
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0118, .0000
TEN. = .0000, .0234
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0118 .0000 .0001 .0118 .0000 .0000 .0000 .0000
-.0176 .0000 -.0153 -.0176 -.0002 -.0153 .0000 .0000 .0000

SUPT:JVVD      9:44:21. 2      6/ 7/1988      PAGE 16
  
```

ATTACHMENT 2  
 PAGE 79 OF 143  
 CALC. NO. C-0031/TIRO

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222



NUTECH ENGINEERS  
PIPE SUPPORT LOAD COMB. SYSTEM P201

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) P5E005 1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACGD

```

NODE = H11      SUPPORT 1 OF 1      (Trans. only)
PIPE DIRECTION COSINES. X = .0000, Y = -1.0000, Z = .0000

SUPT: 26      RIGID
TRAN STIF. = .1750E+07
(X) (Y) (Z)
DIRECTION COSINES:
-.7844 .0000 -.6202

*****
CAS(1)- SERVICE LEVEL B      *****
FORCE MAX.      199.088
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
TEN = .0005, .0006
COMP = .0006, .0247
GLOBAL DISPL. MAX/MIN:      LOCAL DISPL. MAX/MIN:      GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0008      .0000 .0008 .0000      .0000 .0000 .0000
-.0008 -.0247 .0000      .0247 .0000 .0008      .0000 .0000 .0000

*****
CAS(2)- SERVICE LEVEL C      *****
FORCE MAX.      .000
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN:      LOCAL DISPL. MAX/MIN:      GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000      .0000 .0000 .0000      .0000 .0000 .0000
.0000 .0000 .0000      .0000 .0000 .0000      .0000 .0000 .0000

*****
CAS(3)- SERVICE LEVEL D      *****
FORCE MAX.      .000
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN:      LOCAL DISPL. MAX/MIN:      GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000      .0000 .0000 .0000      .0000 .0000 .0000
.0000 .0000 .0000      .0000 .0000 .0000      .0000 .0000 .0000

*****
CAS(4)- SERVICE LEVEL 3*B      *****
FORCE MAX.      1146.476
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
TEN = .0055, .0044
COMP = .0062, .1133
GLOBAL DISPL. MAX/MIN:      LOCAL DISPL. MAX/MIN:      GLOBAL ACCEL. MAX/MIN:
.0071 .0000 .0000      .0000 .0000 .0071      .0000 .0000 .0000
.0000 -.1130 -.0100      -.1130 -.0100 .0000      .0000 .0000 .0000

SUPTJYVD      9:44:21.2      6/7/1988      PAGE 17
    
```

ATTACHMENT  
 PAGE 80 OF 143  
 CALC. NO. C-0531/71RD

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACOD

```

-----
| NODE = H12      SUPPORT 1 OF 1                      (Trans. only) |
|-----|
| PIPE DIRECTION COSINES: X = .0000, Y = -1.0000, Z = .0000 |
|-----|
| SUPT: 27      R101D |
| TRAN STIF. = .3066E+07 |
| (X) (Y) (Z) |
| DIRECTION COSINES: |
| .4524 .0000 -.8918 |
|-----|
| ***** CAS(1)- SERVICE LEVEL B ***** |
| FORCE MAX. .000 |
| FORCE MIN. -180.331 |
| AXIAL SWING MAX/MIN: |
| TEN. = .0001, .0025 |
| TEN. = .0000, .0248 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0022 .0000 .0012 .0000 .0012 -.0022 .0000 .0000 .0000 |
| .0000 -.0248 .0000 .0248 .0000 .0000 .0000 .0000 .0000 |
|-----|
| ***** CAS(2)- SERVICE LEVEL C ***** |
| FORCE MAX. .000 |
| FORCE MIN. .000 |
| AXIAL SWING MAX/MIN: |
| N/A = .0000, .0000 |
| N/A = .0000, .0000 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
|-----|
| ***** CAS(3)- SERVICE LEVEL D ***** |
| FORCE MAX. .000 |
| FORCE MIN. .000 |
| AXIAL SWING MAX/MIN: |
| N/A = .0000, .0000 |
| N/A = .0000, .0000 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
|-----|
| ***** CAS(4)- SERVICE LEVEL 3*B ***** |
| FORCE MAX. .000 |
| FORCE MIN. -5849.268 |
| AXIAL SWING MAX/MIN: |
| TEN. = .0019, .0385 |
| TEN. = .0000, .1366 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0335 .0000 .0191 .0000 .0191 .0335 .0000 .0000 .0000 |
| .0000 -.1366 .0000 -.1366 .0000 .0000 .0000 .0000 .0000 |
|-----|
| SUPTJYVD          9: 44: 21. 2      6/ 7/1988          PAGE 18 |
|-----|
    
```

ATTACHMENT 2  
 PAGE 81 OF 143  
 C.C. NO. C-DD31/TIRD

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

N.UTECH ENGINEERS  
 PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) P5E005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

```

-----
NODE = H10      SUPPORT 1 OF 1      (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = -1.0000, Z = .0000

SAPT: 28 SNUBBER
TRAN. STIF. = .0000E+00
(X) (Y) (Z)
DIRECTION COSINES:
1.0000 .0000 .0000

*****
CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
COMP = .0157, .0039
TEN = .0000, .0250
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0157 .0000 .0039 .0000 .0039 -.0157 .0000 .0000 .0000
.0000 -.0250 .0000 .0250 .0000 .0000 .0000 .0000 .0000

*****
CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

*****
CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

*****
CAS(4)- SERVICE LEVEL J#B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
COMP = .1770, .2445
TEN = .0000, .2791
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.1770 .0000 .2445 .0000 .2445 .1770 .0000 .0000 .0000
.0000 -.2791 .0000 -.2791 .0000 .0000 .0000 .0000 .0000

-----
SAPTJYVD          9:44:21. 2      6/ 7/1988          PAGE 19
  
```

ATTACHMENT  
 PAGE 82 OF 143  
 CALC. NO. C-0031/TIRO

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBER  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC00

```

NODE = H9      SUPPORT 1 OF 1      (Trans. only)

PIPE DIRECTION COSINES: X = .0000, Y = -1.0000, Z = .0000

SUPT: 29      SNUBBER
TRAN STIF. = .0000E+00
(X) (Y) (Z)
DIRECTION COSINES:
.2801 .0000 -.9600

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
CDMP = .0007, .0177
TEN = .0000, .0250
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0172 .0000 .0043 .0000 .0043 -.0172 .0000 .0000 .0000
.0000 -.0250 .0000 .0250 .0000 .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3=B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
TEN = .2153, .2684
TEN = .0000, .3003
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.1973 .0000 .2819 .0000 .2819 .1973 .0000 .0000 .0000
.0000 -.3003 .0000 -.3003 .0000 .0000 .0000 .0000 .0000

SUPTJYVD      9:44:21. 2      6/ 7/1988      PAGE 20
    
```

ATTACHMENT 83 OF 143  
 PAGE 83 OF 143  
 CALC. NO. C-0031/TIRD

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

```

NODE = 95BEL   SUPPORT 1 OF 2                               (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = -.0112, Z = -.9999

SUCT: 30   RIGID | SUCT: 31   RIGID | SUCT: 32   RIGID
TRAN. STIF. = .3100E+03 | TRAN. STIF. = .1825E+04 | TRAN. STIF. = .1825E+04
(X) (Y) (Z) | (X) (Y) (Z) | (X) (Y) (Z)
DIRECTION COSINES: | DIRECTION COSINES: | DIRECTION COSINES:
.0000 .0000 -1.0000 | .0000 1.0000 .0000 | 1.0000 .0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .033 | FORCE MAX. .000 | FORCE MAX. 31.162 |
FORCE MIN. .000 | FORCE MIN. -19.508 | FORCE MIN. .000 |
AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN: |
TEN. = .0000, .0171 | TEN. = .0000, .0171 | N/A = .0171, .0000 |
COMP = .0001, .0083 | TEN. = .0083, .0001 | TEN. = .0000, .0083 |
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN: |
.0171 .0000 .0000 | .0000 .0000 .0171 | .0000 .0000 .0000 |
.0000 -.0083 -.0001 | .0002 -.0083 .0000 | .0000 .0000 .0000 |

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. .000 |
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000 |
AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN: |
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000 |
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000 |
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN: |
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000 |
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000 |

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. .000 |
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000 |
AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN: |
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000 |
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000 |
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN: |
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000 |
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000 |

***** CAS(4)- SERVICE LEVEL J+B *****
FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. 561.309 |
FORCE MIN. -112.332 | FORCE MIN. -383.572 | FORCE MIN. .000 |
AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN: |
TEN. = .3624, .3076 | TEN. = .0000, .4753 | COMP = .3076, .3624 |
TEN. = .0000, .2102 | TEN. = .2102, .0000 | TEN. = .0000, .2102 |
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN: |
.3076 .0000 .3624 | .3623 .0041 .3076 | .0000 .0000 .0000 |
.0000 -.2102 .0000 | -.0024 -.2102 .0000 | .0000 .0000 .0000 |

SUCTJYVD          9:44:21.2    6/ 7/1988          PAGE 21
    
```

ATTACHMENT 2  
 PAGE 84 OF 143  
 CALC. NO. C-0031/71RB

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PIPE SUPPORT LOAD COMB. SYSTEM PROJ

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBER  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC00

```

NODE = 95BEL SUPPORT 2 OF 2 (Rotation only)

PIPE DIRECTION COSINES: X = .0000, Y = -.0112, Z = -.9999

SUPT: 33 RIGID | SUPT: 34 RIGID | SUPT: 35 RIGID
ROT. STIF. = .6670E+05 | ROT. STIF. = .6670E+05 | ROT. STIF = .6670E+05
(X) (Y) (Z) | (X) (Y) (Z) | (X) (Y) (Z)
DIRECTION COSINES: | DIRECTION COSINES: | DIRECTION COSINES:
.0000 .0000 -1.0000 | .0000 1.0000 .0000 | 1.0000 .0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
MOMT. MAX. .000 | MOMT. MAX. 6.821 | MOMT. MAX. 9.392
MOMT. MIN. -7.335 | MOMT. MIN. .000 | MOMT. MIN. .000

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0171 .0000 .0000 | .0000 .0000 .0171 | .0000 .0000 .0000
.0000 -.0085 -.0001 | .0002 -.0085 .0000 | .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
MOMT. MAX. .000 | MOMT. MAX. .000 | MOMT. MAX. .000
MOMT. MIN. .000 | MOMT. MIN. .000 | MOMT. MIN. .000

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
MOMT. MAX. .000 | MOMT. MAX. .000 | MOMT. MAX. .000
MOMT. MIN. .000 | MOMT. MIN. .000 | MOMT. MIN. .000

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3*B *****
MOMT. MAX. .000 | MOMT. MAX. 139.899 | MOMT. MAX. 106.532
MOMT. MIN. -186.240 | MOMT. MIN. .000 | MOMT. MIN. .000

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.3076 .0000 .3624 | .3623 .0041 .3076 | .0000 .0000 .0000
.0000 -.2102 .0000 | -.0024 -.2102 .0000 | .0000 .0000 .0000

SUPTJYVD 9:44:21.2 6/ 7/1988 PAGE 22
    
```

ATTACHMENT 2  
 PAGE 85 OF 143  
 CALC. NO. C-0031/TIR0

NUTECH ENGINEERS  
 PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) P5E005, 1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACOD

```

NODE = HB      SUPPORT 1 OF 1      (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = -.0100, Z = -.9999
SUPT: 36      R1210 SPRING HANGER
TRAN STIF. = .1200E+04 } Hot LOAD = 2860. # } 071012
(X) (Y) (Z)           } 06-0788
DIRECTION COSINES:
.0000 1.0000 .0000
*****
CAS(1)-- SERVICE LEVEL B *****
FORCE MAX.      .000
FORCE MIN.     -3.493
AXIAL, SWING MAX/MIN:
TEN. = .0000, .0123
TEN. = .0029, .0002
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0123 .0000 .0000 .0000 .0000 .0123 .0000 .0000 .0000
.0000 -.0029 -.0002 .0002 -.0029 .0000 .0000 .0000 .0000
*****
CAS(2)-- SERVICE LEVEL C *****
FORCE MAX.      .000
FORCE MIN.      .000
AXIAL, SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
*****
CAS(3)-- SERVICE LEVEL D *****
FORCE MAX.      .000
FORCE MIN.      .000
AXIAL, SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
*****
CAS(4)-- SERVICE LEVEL 3*B *****
FORCE MAX.      .000
FORCE MIN.     -159.561
AXIAL, SWING MAX/MIN:
TEN. = .0000, .3539
TEN. = .1330, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.2029 .0000 .2900 .2899 .0029 .2029 .0000 .0000 .0000
.0000 -.1330 .0000 -.0013 -.1330 .0000 .0000 .0000 .0000
SUPT: JYVD      9:44:21. 2      6/ 7/1988      PAGE 23
  
```

ATTACHMENT 2  
 PAGE 86 of 143  
 FILE NO. C-0031/71R

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC00

```

+-----+
| NODE = H7          SUPPORT 1 OF 1          (Trans. only) |
| PIPE DIRECTION COSINES: X = .0000, Y = .0143, Z = -.9999 |
| SUPP: 37 SNUBBER |
| TRAN STIF. = .0000E+00 |
| (X) (Y) (Z) |
| DIRECTION COSINES: |
| 1.0000 .0000 .0000 |
| ***** CAS(1)- SERVICE LEVEL B ***** |
| FORCE MAX. .000 |
| FORCE MIN. .000 |
| AXIAL SWING MAX/MIN: |
| N/A = .0102, .0000 |
| TEN. = .0000, .0027 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0102 .0000 .0000 .0000 .0000 .0102 .0000 .0000 .0000 |
| .0000 -.0027 -.0002 .0001 -.0027 .0000 .0000 .0000 .0000 |
| ***** CAS(2)- SERVICE LEVEL C ***** |
| FORCE MAX. .000 |
| FORCE MIN. .000 |
| AXIAL SWING MAX/MIN: |
| N/A = .0000, .0000 |
| N/A = .0000, .0000 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| ***** CAS(3)- SERVICE LEVEL D ***** |
| FORCE MAX. .000 |
| FORCE MIN. .000 |
| AXIAL SWING MAX/MIN: |
| N/A = .0000, .0000 |
| N/A = .0000, .0000 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| ***** CAS(4)- SERVICE LEVEL 3+B ***** |
| FORCE MAX. .000 |
| FORCE MIN. .000 |
| AXIAL SWING MAX/MIN: |
| COMP = .1508, .2546 |
| TEN. = .0000, .0995 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .1508 .0000 .2546 .2546 .0036 .1508 .0000 .0000 .0000 |
| .0000 -.0995 .0000 -.0014 -.0995 .0000 .0000 .0000 .0000 |
| SUPP: JYVD          9:44:21.2      6/ 7/1988          PAGE 24 |
+-----+

```

ATTACHMENT 2  
PAGE 87 OF 143  
C-0031/71RN

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222



PROJECT: HOPE CREEK SNUGGER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) P5E005.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACCO

```

| NODE = H6      SUPPORT 1 OF 1      (Trans. only) |
| PIPE DIRECTION COSINES: X = .0000, Y = -.0122, Z = -.9999 |
| SUPT: 38      RIGID |
| TRAN STIF. = .1402E+07 |
| (X) (Y) (Z) |
| DIRECTION COSINES: |
| .0000 .0000 1.0000 |
| ***** CAS(1)- SERVICE LEVEL B ***** |
| FORCE MAX. .000 |
| FORCE MIN. -156.044 |
| AXIAL SWING MAX/MIN: |
| TEN. = .0000 .0023 |
| TEN. = .0001 .0039 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0023 .0000 .0000 .0000 .0000 .0023 .0000 .0000 .0000 |
| .0000 -.0039 -.0001 .0002 -.0039 .0000 .0000 .0000 .0000 |
| ***** CAS(2)- SERVICE LEVEL C ***** |
| FORCE MAX. .000 |
| FORCE MIN. .000 |
| AXIAL SWING MAX/MIN: |
| N/A = .0000 .0000 |
| N/A = .0000 .0000 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| ***** CAS(3)- SERVICE LEVEL D ***** |
| FORCE MAX. .000 |
| FORCE MIN. .000 |
| AXIAL SWING MAX/MIN: |
| N/A = .0000 .0000 |
| N/A = .0000 .0000 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| ***** CAS(4)- SERVICE LEVEL 3+B ***** |
| FORCE MAX. .000 |
| FORCE MIN. -2445.405 |
| AXIAL SWING MAX/MIN: |
| N/A = .0000 .0000 |
| TEN. = .0017 .2219 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| -.2219 -.0012 -.0017 -.0018 -.0012 -.2219 .0000 .0000 .0000 |
| SUPTJYVD 9:44:21. 2 6/ 7/1988 PAGE 25

```

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

ATTACHMENT 2  
PAGE 88 OF 143  
DATE: C-0591/71R0

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) P5E005.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC00

```

NODE = H5A      SUPPORT 1 OF 1      (Trans. only)

PIPE DIRECTION COSINES: X = .0000, Y = -.0045, Z = -1.0000

SUCT: 39 SNUBBER
TRAN. STIF. = .0000E+00
(X) (Y) (Z)
DIRECTION COSINES:
1.0000 .0000 .0000

*****
CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0022, .0000
TEN. = .0000, .0032
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0022 .0000 .0000 .0000 .0000 .0022 .0000 .0000 .0000
.0000 -.0032 -.0001 .0001 -.0032 .0000 .0000 .0000 .0000

*****
CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

*****
CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

*****
CAS(4)- SERVICE LEVEL 3#B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
TEN. = .0000, .0009
TEN. = .2578, .0280
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0009 .0000 .0000 .0009 .0000 .0000 .0000 .0000
-.2578 .0000 -.0280 -.0280 -.0001 -.2578 .0000 .0000 .0000

SUCTJYVD      9:44:21. 2      6/ 7/1988      PAGE 26

```

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

ATTACHMENT 2  
PAGE 89 OF 143  
ANSI

PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUDDER REDUCTION . FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) P5E005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACOD

```

NODE = H4A      SUPPORT 1 OF 1                      (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = -.0113, Z = -.9999

SUPT: 40      RIGID
TRAN. STIF. = .6160E+06
(X) (Y) (Z)
DIRECTION COSINES:
.0000 1.0000 .0000

*****
CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. -1743.452
AXIAL, SWING MAX/MIN:
TEN = .0000, .0020
TEN = .0028, .0001
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0020 .0000 .0000 .0000 .0000 .0020 .0000 .0000 .0000
.0000 -.0028 -.0001 .0002 -.0028 .0000 .0000 .0000 .0000

*****
CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL, SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

*****
CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL, SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

*****
CAS(4)- SERVICE LEVEL J=B *****
FORCE MAX. 1175.073
FORCE MIN. .000
AXIAL, SWING MAX/MIN:
N/A = .0019, .0000
TEN = .0000, .2818
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0019 .0000 .0000 .0019 .0000 .0000 .0000 .0000
-.2784 .0000 -.0434 -.0434 -.0005 -.2784 .0000 .0000 .0000

SUPTJYVD      9:44:21. 2      6/ 7/1988      PAGE 27
  
```

ATTACHMENT 2  
 PAGE 90 OF 143  
 4-22-81 1:27 PM

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS

PIPE SUPPORT LOAD COMP. SYSTEM P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.101&  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

```

NODE = H3A      SUPPORT 1 OF 1      (Trans. only)

PIPE DIRECTION COSINES: X = .9999, Y = -.0109, Z = .0000

SUPT: 41 SNUBBER
TRAN STIF. = .0000E+00
(X) (Y) (Z)
DIRECTION COSINES:
.0767 .0000 -.9971

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
COMP = .0001, .0015
COMP = .0013, .0026
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0015 .0000 .0000 .0015 .0000 .0000 .0000 .0000 .0000
.0000 -.0026 -.0013 .0000 -.0026 -.0013 .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3&B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
TEN = .0000, .0769
COMP = .0816, .1328
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0769 .0000 .0008 .0769 .0000 .0000 .0000 .0000
-.1262 .0000 -.0915 -.1262 -.0014 -.0915 .0000 .0000 .0000

SUPTJYVD      9: 44: 21. 2      6/ 7/1988      PAGE 28
    
```

ATTACHMENT 91 OF 143  
 PAGE 91 OF 143  
 C-0031 / TIR0  
 2

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS  
 PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACGD

```

-----
NODE = H2A      SUPPORT 1 OF 1                      (Trans. only)
      PIPE DIRECTION COSINES: X = .9999, Y = -.0104, Z = .0000

SUPT: 42 SNUBBER
TRAN STIF. = .0000E+00
(X) (Y) (Z)
DIRECTION COSINES:
.0000 1.0000 .0000

*****
CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
COMP = .0006, .0016
TEN = .0000, .0016
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0016 .0006 .0000 .0015 .0006 .0000 .0000 .0000 .0000
.0000 .0000 -.0016 .0000 .0000 -.0016 .0000 .0000 .0000

*****
CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

*****
CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

*****
CAS(4)- SERVICE LEVEL 3#B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0906, .0000
TEN = .0000, .0954
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0906 .0000 .0009 .0906 .0000 .0000 .0000 .0000
-.0568 .0000 -.0767 -.0568 -.0006 -.0767 .0000 .0000 .0000

-----
SUPT:JVVD      9:44:21. 2      6/ 7/1988      PAGE 29
  
```

ATTACHMENT 2  
 PAGE 92 OF 143  
 CALC. NO. C-0031/TIRO

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS

PIPE SUPPORT LOAD COMP. SYSTEM P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

```

NUDE = H1A      SUPPORT 1 OF 1      (Trans. only)

PIPE DIRECTION COSINES: X = .9999, Y = -.0103, Z = .0000

SUPT: 43      R1019      SPRING HANGER.
TRAN. STIF. = .9000E+03      # } 02004
(X) (Y) (Z)      HOT LOAD = 2158. # } 06-07-88
DIRECTION COSINES:
.0000 1.0000 .0000

*****
CAS(1)- SERVICE LEVEL B      *****
FORCE MAX.      .852
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
COMP = .0009, .0016
TEN = .0000, .0016
GLOBAL DISPL. MAX/MIN:      LOCAL DISPL. MAX/MIN:      GLOBAL ACCEL. MAX/MIN:
.0016 .0009 .0000      .0015 .0010 .0000      .0000 .0000 .0000
.0000 .0000 -.0016      .0000 .0000 -.0016      .0000 .0000 .0000

*****
CAS(2)- SERVICE LEVEL C      *****
FORCE MAX.      .000
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN:      LOCAL DISPL. MAX/MIN:      GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000      .0000 .0000 .0000      .0000 .0000 .0000
.0000 .0000 .0000      .0000 .0000 .0000      .0000 .0000 .0000

*****
CAS(3)- SERVICE LEVEL D      *****
FORCE MAX.      .000
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN:      LOCAL DISPL. MAX/MIN:      GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000      .0000 .0000 .0000      .0000 .0000 .0000
.0000 .0000 .0000      .0000 .0000 .0000      .0000 .0000 .0000

*****
CAS(4)- SERVICE LEVEL 3#B      *****
FORCE MAX.      82.956
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
N/A = .0922, .0000
TEN = .0000, .0890
GLOBAL DISPL. MAX/MIN:      LOCAL DISPL. MAX/MIN:      GLOBAL ACCEL. MAX/MIN:
.0000 .0922 .0000      .0010 .0922 .0000      .0000 .0000 .0000
-.0481 .0000 -.0748      -.0481 -.0005 -.0748      .0000 .0000 .0000

SUCTJVVD      9:44:21. 2      6/ 7/1988      PAGE 30
    
```

ATTACHMENT 2  
 PAGE 93 OF 143  
 CALC. NO. C-0031/TIR0

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS  
PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACOB

```

  NODE = HPTUB   SUPPORT 1 OF 2                               (Trans. only)
  PIPE DIRECTION COSINES: X = .0000, Y = .0000, Z = 1.0000

  SUPT: 44   RIGID | SUPT: 45   RIGID | SUPT: 46   RIGID
  TRAN. STIF. = .1000E+09 | TRAN. STIF. = .1000E+09 | TRAN. STIF. = .1000E+09
  (X) (Y) (Z) | (X) (Y) (Z) | (X) (Y) (Z)
  DIRECTION COSINES: | DIRECTION COSINES: | DIRECTION COSINES:
  1.0000 .0000 .0000 | .0000 1.0000 .0000 | .0000 .0000 1.0000

  ***** CAS(1)- SERVICE LEVEL B *****
  FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. 14.363
  FORCE MIN. -63.778 | FORCE MIN. -340.984 | FORCE MIN. .000
  AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
  TEN. = .0000 .0000 | TEN. = .0000 .0000 | N/A = .0000 .0000
  TEN. = .0000 .0000 | TEN. = .0000 .0000 | TEN. = .0000 .0000
  GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
  .0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
  .0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

  ***** CAS(2)- SERVICE LEVEL C *****
  FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. .000
  FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000
  AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
  N/A = .0000 .0000 | N/A = .0000 .0000 | N/A = .0000 .0000
  N/A = .0000 .0000 | N/A = .0000 .0000 | N/A = .0000 .0000
  GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
  .0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
  .0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

  ***** CAS(3)- SERVICE LEVEL D *****
  FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. .000
  FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000
  AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
  N/A = .0000 .0000 | N/A = .0000 .0000 | N/A = .0000 .0000
  N/A = .0000 .0000 | N/A = .0000 .0000 | N/A = .0000 .0000
  GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
  .0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
  .0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

  ***** CAS(4)- SERVICE LEVEL 3=B *****
  FORCE MAX. 500.120 | FORCE MAX. 256.625 | FORCE MAX. .000
  FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. -542.363
  AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
  N/A = .0018 .0000 | TEN. = .0000 .0018 | TEN. = .0000 .0018
  TEN. = .0000 .0285 | TEN. = .0143 .0246 | TEN. = .0246 .0143
  GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
  .0018 .0000 .0000 | .0000 .0000 .0018 | .0000 .0000 .0000
  .0000 -.0143 -.0246 | -.0246 -.0143 .0000 | .0000 .0000 .0000

  SUPTJYVD          9: 44: 21. 2      6/ 7/1988          PAGE 31
  
```

ATTACHMENT 2  
 PAGE 94 OF 143  
 CALC. NO. C-0031/TIR0

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PROJECT: HOPE CREEK SMUGGER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

NODE = HPTUB SUPPORT 2 OF 2			(Rotation only)		
PIPE DIRECTION COSINES: X = .0000, Y = .0000, Z = 1.0000					
SUPT: 47	RICID	SUPT: 48	RICID	SUPT: 49	RICID
ROT STIF. = .1000E+13		ROT STIF. = .1000E+13		ROT STIF. = .1000E+13	
(X) (Y) (Z)		(X) (Y) (Z)		(X) (Y) (Z)	
DIRECTION COSINES:		DIRECTION COSINES:		DIRECTION COSINES:	
1.0000	.0000 .0000	.0000	1.0000 .0000	.0000	.0000 1.0000
***** CAS(1)- SERVICE LEVEL B *****					
MOHT. MAX.	.000	MOHT. MAX.	4167.737	MOHT. MAX.	.000
MOHT. MIN.	-3938.715	MOHT. MIN.	.000	MOHT. MIN.	-3127.802
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.0000	.0000 .0000	.0000	.0000 .0000	.0000	.0000 .0000
.0000	.0000 .0000	.0000	.0000 .0000	.0000	.0000 .0000
***** CAS(2)- SERVICE LEVEL C *****					
MOHT. MAX.	.000	MOHT. MAX.	.000	MOHT. MAX.	.000
MOHT. MIN.	.000	MOHT. MIN.	.000	MOHT. MIN.	.000
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.0000	.0000 .0000	.0000	.0000 .0000	.0000	.0000 .0000
.0000	.0000 .0000	.0000	.0000 .0000	.0000	.0000 .0000
***** CAS(3)- SERVICE LEVEL D *****					
MOHT. MAX.	.000	MOHT. MAX.	.000	MOHT. MAX.	.000
MOHT. MIN.	.000	MOHT. MIN.	.000	MOHT. MIN.	.000
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.0000	.0000 .0000	.0000	.0000 .0000	.0000	.0000 .0000
.0000	.0000 .0000	.0000	.0000 .0000	.0000	.0000 .0000
***** CAS(4)- SERVICE LEVEL 3*B *****					
MOHT. MAX.	.000	MOHT. MAX.	.000	MOHT. MAX.	.000
MOHT. MIN.	-44335.700	MOHT. MIN.	-31934.930	MOHT. MIN.	-22027.230
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.0018	.0000 .0000	.0000	.0000 .0018	.0000	.0000 .0000
.0000	-.0143 -.0246	-.0246	-.0143 .0000	.0000	.0000 .0000
SUPTJYVD			9:44:21. 2		6/ 7/1988
					PAGE 32

ATTACHMENT 2  
 PAGE 95 OF 143  
 CALC. NO. C-0031/7TRD



NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC00

```

NODE = H2B      SUPPORT 1 OF 1                      (Trans. only)

PIPE DIRECTION COSINES: X = .0000, Y = .0104, Z = .9999

SUPT: 50 SNUBBER |
TRAN BTIF = .2530E+06 |
(X) (Y) (Z) |
DIRECTION COSINES: |
.0000 .0000 1.0000 |

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000 |
FORCE MIN. .000 |
AXIAL, SWING MAX/MIN: |
N/A = .0000, .0000 |
TEN. = .0030, .0012 |
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
-.0001 -.0012 -.0050 -.0050 -.0012 .0001 .0000 .0000 .0000 |

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000 |
FORCE MIN. .000 |
AXIAL, SWING MAX/MIN: |
N/A = .0000, .0000 |
N/A = .0000, .0000 |
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000 |
FORCE MIN. .000 |
AXIAL, SWING MAX/MIN: |
N/A = .0000, .0000 |
N/A = .0000, .0000 |
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |

***** CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX. .000 |
FORCE MIN. .000 |
AXIAL, SWING MAX/MIN: |
N/A = .2285, .0000 |
TEN. = .0000, .0306 |
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
.0000 .0000 .2285 .2285 .0024 .0000 .0000 .0000 .0000 |
-.0295 -.0081 .0000 -.0001 -.0081 -.0295 .0000 .0000 .0000 |

SUPTJVVD          9:44:21.2      6/ 7/1988          PAGE 33
    
```

ATTACHMENT 2  
 PAGE 96 OF 143  
 CALC. NO. C-0031 / TIR0

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACOD

```

NODE = H1B      SUPPORT 1 OF 1      (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = .0104, Z = .9999

SUPT: 51      RIGID | SUPT: 92      RIGID |
TRAN STIF. = .3410E+07 | TRAN STIF. = .3410E+07 |
(X) (Y) (Z) | (X) (Y) (Z) |
DIRECTION COSINES: | DIRECTION COSINES: |
1.0000 .0000 .0000 | .0000 1.0000 .0000 |

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. 166.040 | FORCE MAX. .000 |
FORCE MIN. .000 | FORCE MIN. -1138.333 |
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: |
N/A = .0000, .0000 | TEN. = .0000, .0000 |
TEN. = .0000, .0050 | TEN. = .0003, .0050 |
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN: |
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000 |
.0000 -.0003 -.0050 | -.0050 -.0003 .0000 | .0000 .0000 .0000 |

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000 | FORCE MAX. .000 |
FORCE MIN. .000 | FORCE MIN. .000 |
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: |
N/A = .0000, .0000 | N/A = .0000, .0000 |
N/A = .0000, .0000 | N/A = .0000, .0000 |
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN: |
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000 |
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000 |

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000 | FORCE MAX. .000 |
FORCE MIN. .000 | FORCE MIN. .000 |
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: |
N/A = .0000, .0000 | N/A = .0000, .0000 |
N/A = .0000, .0000 | N/A = .0000, .0000 |
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN: |
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000 |
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000 |

***** CAS(4)- SERVICE LEVEL 3#B *****
FORCE MAX. .000 | FORCE MAX. .000 |
FORCE MIN. -378.712 | FORCE MIN. -5613.299 |
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: |
TEN. = .0000, .2322 | TEN. = .0000, .2322 |
TEN. = .0001, .0016 | TEN. = .0016, .0001 |
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN: |
.0000 .0000 .2322 | .2322 .0024 .0000 | .0000 .0000 .0000 |
-.0001 -.0016 .0000 | -.0000 -.0016 -.0001 | .0000 .0000 .0000 |

SUPTJYVD      9:44:21.2      6/ 7/1988      PAGE 34
    
```

ATTACHMENT 2  
 PAGE 97 OF 143  
 CALC. NO. C-0031/TIRO

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTTECH ENGINEERS

PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

```

NODE = 180BL SUPPORT 1 OF 2 (Trans. only)

PIPE DIRECTION COSINES: X = .0000, Y = .0104, Z = .9999

SUPT: 53 RIGID | SUPT: 54 RIGID | SUPT: 55 RIGID
TRAN. STIF. = .2600E+03 | TRAN. STIF. = .1250E+04 | TRAN. STIF. = .1250E+04
(X) (Y) (Z) | (X) (Y) (Z) | (X) (Y) (Z)
DIRECTION COSINES: | DIRECTION COSINES: | DIRECTION COSINES:
.0000 .0000 1.0000 | .0000 1.0000 .0000 | 1.0000 .0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000 | FORCE MAX. .739 | FORCE MAX. 1.248
FORCE MIN. -1.309 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN:
TEN. = .0000, .0012 | COMP = .0006, .0010 | COMP = .0010, .0006
TEN. = .0050, .0000 | TEN. = .0000, .0050 | TEN. = .0000, .0050
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0010 .0006 .0000 | .0000 .0006 -.0010 | .0000 .0000 .0000
.0000 .0000 -.0050 | -.0050 .0001 .0000 | .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. .000
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN:
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. .000
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN:
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3=B *****
FORCE MAX. 63.720 | FORCE MAX. 8.286 | FORCE MAX. 123.434
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN:
COMP = .2451, .1006 | COMP = .0066, .2648 | COMP = .1003, .2452
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.1003 .0066 .2451 | .2451 .0092 .1003 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

SUPT/JVD 9: 44:21. 2 6/ 7/1988 PAGE 35
  
```

ATTACHMENT 2  
 PAGE 98 OF 143  
 CALC. NO. C-0031/712A

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

```

MODE = 1800L SUPPORT 2 OF 2 (Rotation only)
PIPE DIRECTION COSINES: X = .0000, Y = .0104, Z = .9999

SUPT: 56 RIGID | SUPT: 57 RIGID | SUPT: 58 RIGID
ROT. STIF. = .5130E+05 | ROT. STIF. = .5130E+05 | ROT. STIF. = .5130E+05
(X) (Y) (Z) | (X) (Y) (Z) | (X) (Y) (Z)
DIRECTION COSINES: | DIRECTION COSINES: | DIRECTION COSINES:
.0000 .0000 1.0000 | .0000 1.0000 .0000 | 1.0000 .0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
MOMT. MAX. 5.350 | MOMT. MAX. 1.253 | MOMT. MAX. .000
MOMT. MIN. .000 | MOMT. MIN. .000 | MOMT. MIN. -.199

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0010 .0006 .0000 | .0000 .0006 -.0010 | .0000 .0000 .0000
.0000 .0000 -.0050 | -.0050 .0001 .0000 | .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
MOMT. MAX. .000 | MOMT. MAX. .000 | MOMT. MAX. .000
MOMT. MIN. .000 | MOMT. MIN. .000 | MOMT. MIN. .000

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
MOMT. MAX. .000 | MOMT. MAX. .000 | MOMT. MAX. .000
MOMT. MIN. .000 | MOMT. MIN. .000 | MOMT. MIN. .000

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3*B *****
MOMT. MAX. 114.504 | MOMT. MAX. 107.471 | MOMT. MAX. .000
MOMT. MIN. .000 | MOMT. MIN. .000 | MOMT. MIN. -2.019

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.1003 .0066 .2451 | .2451 .0092 .1003 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

SUPT.JYVD 9:44:21. 2 6/ 7/1988 PAGE 36
  
```

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

ATTACHMENT 2  
 PAGE 99 OF 143  
 CALC. NO. 5-0031/TIRO

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. AC00

```

NODE = H38      SUPPORT 1 OF 1                      (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = .0104, Z = .9999

SUPT: 59      RICID |
TRAN STIF. = .8340E+06 |
(X) (Y) (Z) |
DIRECTION COSINES: |
.0000 1.0000 .0000 |

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000 |
FORCE MIN. -2154.021 |
AXIAL SWING MAX/MIN: |
TEN. = .0000, .0038 |
TEN. = .0026, .0050 |
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
.0038 .0000 .0000 .0000 .0000 .0038 .0000 .0000 .0000 |
.0000 -.0026 -.0050 -.0050 -.0025 .0000 .0000 .0000 .0000 |

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000 |
FORCE MIN. .000 |
AXIAL SWING MAX/MIN: |
N/A = .0000, .0000 |
N/A = .0000, .0000 |
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000 |
FORCE MIN. .000 |
AXIAL SWING MAX/MIN: |
N/A = .0000, .0000 |
N/A = .0000, .0000 |
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |

***** CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX. 1348.264 |
FORCE MIN. .000 |
AXIAL SWING MAX/MIN: |
CUMP = .0016, .4043 |
N/A = .0000, .0000 |
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
.2999 .0016 .2711 .2711 .0044 .2999 .0000 .0000 .0000 |
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |

SUPTJYVD      9:44:21. 2      6/ 7/1988      PAGE 37

```

ATTACHMENT 2  
PAGE 100 OF 143  
CALC. NO. C-0531/TIRCD

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

NOTECH ENGINEERS

PIPE SUPPORT LOAD COND. SYSTEM P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACQD

```

NODE = H5B      SUPPORT 1 OF 1      (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = 1.0000, Z = .0000

SUPT: 60      RIGID
TRAN. STIF. = .3850E+06
(X) (Y) (Z)
DIRECTION COSINES:
-.5210 .0000 -.8535

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. -47.775
AXIAL SWING MAX/MIN:
TEN. = .0001, .0001
TEN. = .0000, .0090
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0001 .0000 .0001 .0000 .0000 .0000 .0000!
.0000 -.0090 .0000 -.0090 .0000 .0000 .0000 .0000 .0000!

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000!
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000!

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000!
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000!

***** CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX. .000
FORCE MIN. -264.605
AXIAL SWING MAX/MIN:
TEN. = .0007, .0620
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0001 .0620 .0008 .0620 .0008 .0001 .0000 .0000 .0000!
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000!

SUPTJYVD      9:44:21.2      6/ 7/1988      PAGE 38
    
```

ATTACHMENT 2  
 PAGE 101 OF 143  
 CALC. NO. C-5031/7IRB

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS  
PIPE SUPPORT LOAD COMP. SYSTEM 1201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACCD

```

NODE = H4B      SUPPORT 1 OF 1                      (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = 1.0000, Z = .0000

SUPT: 61      RIGID
TRAN STIF. = .5160E+06
(X) (Y) (Z)
DIRECTION COSINES:
.6264 .0000 -.7795

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. -65.655
AXIAL SWING MAX/MIN:
TEN. = .0001, .0000
TEN. = .0001, .0090
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0001 .0000 .0001 .0000 .0000 .0000 .0000
-.0001 -.0090 .0000 -.0090 .0000 -.0001 .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX. .000
FORCE MIN. -187.082
AXIAL SWING MAX/MIN:
TEN. = .0000, .0634
TEN. = .0004, .0159
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0634 .0000 .0634 .0000 .0000 .0000 .0000 .0000
-.0126 .0000 -.0097 .0000 -.0097 -.0126 .0000 .0000 .0000

SUPT: JVD      9:44:21.2 6/ 7/1988      PAGE 39
  
```

ATTACHMENT 2  
 PAGE 102 OF 143  
 CALC. NO. C-0031/TIRO

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTTECH ENGINEERS  
PIPE SUPPORT LOAD COMB. SYSTEM P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS \_\_\_\_\_  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ACGD

OUTPUT SAVED IN FILE : P201SUP.S2

NORMAL COMPLETION AT 9:46:58.94 6/ 7/1988

SUPTJYVD

9:44:21.2

6/ 7/1988

PAGE 40


ATTACHMENT

PAGE 103 OF 143

CALC. NO. C-0031/TIRB

2



 <b>PSEG</b>  CALCULATION CONTINUATION SHEET	TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201, HANGER GUIDANCE		ID NO. C-31-HG		SHEET A-1 OF 40
			REFERENCE NONE		
	ORIGINATOR DATE VFR or CKR DATE	<u>081</u> <u>06-07-88</u> <u>1811</u> <u>6/7/88</u>	<u>6</u>		

ATTACHMENT - C

OPTSUPT RUNID SUPTMVIC DATED 06-07-88  
( 39 Pages )

ATTACHMENT 2  
PAGE 104 OF 143  
CALC. NO. C-0031/7IRD

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

N N U U TTTT EEEEE CCCC H H
NN N U U T E C H H
N N N U U T EEEEE C HHHH
N NN U U T E C H H
N N UUUU T EEEEE CCCC H H

```

```

OOO00 PPPPP TTTT SSSSS U U PPPPP TTTT
O O P P T S U U P P T
O O PPPPP T SSSSS U U PPPPP T
O O P T S U U P T
OOO00 P T SSSSS UUUU P T

```

REVISION 1.0.0  
LEVEL FEB-25-1988

OPTSUPT RUN: ID = SUPTMVIC TIME = 12:47: 8.22 DATE = 6/ 7/1988  
CALCULATION PACKAGE FILE NUMBER = (C-31) PSE005.1016  
COMPUTER RUN FILE NUMBER = ADCE  
COMPUTER RUN OUTPUT FILE NAME = P201RUP.SUP

OPTPIPE TAPE 51 INPUT:  
FILE NAME = P201RUP.T51 RUN ID = ADCE DATE = 88/06/07  
OPTPIPE TAPE 52 INPUT:  
FILE NAME = P201RUP.T52 RUN ID = ADCE DATE = 88/06/07  
FILE CONTAINING ADDITIONAL LOAD CASE DATA:  
FILE NAME =

PREPARED BY/DATE: *C. J. Mehta* 06-07-88  
C. J. MEHTA  
CHECKED BY/DATE: *A S Herlekar* 6/7/88  
A S HERLEKAR

SUPTMVIC 12:47: 8.22 6/ 7/1988 PAGE 1

NUTECH ENGINEERS  
PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS PRO1

ATTACHMENT 2  
PAGE 105 OF 143  
CALC. NO. C-0031/TIRO

NUTEC ENGINEERS

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005 1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

HPCI TURBINE EXHAUST (P201) RUPTURE OF PRESSURE RELIEF DISK

NUMBER OF POINTS = 111 NUMBER OF PIPE RUNS = 1  
 NUMBER OF SUPPORTS = 61 NUMBER OF TEES = 0  
 NUMBER OF PIPES = 106 NUMBER OF BEAMS = 0  
 NUMBER OF LOAD CASES = 2

CASE ID	LOAD CASE DESCRIPTION	CASE ID	LOAD CASE DESCRIPTION
DW		RUPD1	

ECHO OF COMBINATION PROCEDURE INPUT FILE SUPT2

CAS(1)- SERVICE LEVEL B  
 CAS(2)- SERVICE LEVEL C  
 CAS(3)- SERVICE LEVEL D  
 CAS(4)- SERVICE LEVEL 3\*B  
 CAS(1)- L. C. NO. A-1 (DW ONLY)  
 LID(DW)  
 CAS(3)- L. C. D FAULTED ( RUPTURE LOAD + VE )  
 LID(DW)  
 LID(RUPD1)  
 ABS  
 CAS(3)- L. C. D FAULTED ( RUPTURE LOAD - VE )  
 LID(DW)  
 LID(RUPD1)  
 SUB

ATTACHMENT 2  
 PAGE 106 OF 143  
 CALC. NO. C-0031/TIRO

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

NODE = I7SAN SUPPORT 1 OF 2 (Trans. only)

PIPE DIRECTION COSINES: X = .1745, Y = -.7074, Z = -.6849

SUPT: 1	RIGID	SUPT: 2	RIGID	SUPT: 3	RIGID
TRAN. STIF. = .1000E+09		TRAN. STIF. = .1000E+09		TRAN. STIF. = .1000E+09	
(X) (Y) (Z)		(X) (Y) (Z)		(X) (Y) (Z)	
DIRECTION COSINES:			DIRECTION COSINES:		
.9808 .0000 .1951		-.1379 -.7071 .6936		.1379 -.7071 -.6936	

\*\*\*\*\* CAS(1)- SERVICE LEVEL B \*\*\*\*\*

FORCE MAX. 200.357	FORCE MAX. 398.108	FORCE MAX. 5752.025
FORCE MIN. .000	FORCE MIN. .000	FORCE MIN. .000
AXIAL, SWING MAX/MIN:	AXIAL, SWING MAX/MIN:	AXIAL, SWING MAX/MIN:
COMP = .0000, .0000	TEN = .0000, .0000	COMP = .0000, .0000
TEN = .0000, .0001	COMP = .0000, .0001	COMP = .0001, .0000
GLOBAL DISPL. MAX/MIN:	LOCAL DISPL. MAX/MIN:	GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000	.0000 .0000 .0000	.0000 .0000 .0000
.0000 -.0000 -.0000	.0001 .0000 .0000	.0000 .0000 .0000

\*\*\*\*\* CAS(2)- SERVICE LEVEL C \*\*\*\*\*

FORCE MAX. .000	FORCE MAX. .000	FORCE MAX. .000
FORCE MIN. .000	FORCE MIN. .000	FORCE MIN. .000
AXIAL, SWING MAX/MIN:	AXIAL, SWING MAX/MIN:	AXIAL, SWING MAX/MIN:
N/A = .0000, .0000	N/A = .0000, .0000	N/A = .0000, .0000
N/A = .0000, .0000	N/A = .0000, .0000	N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN:	LOCAL DISPL. MAX/MIN:	GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000	.0000 .0000 .0000	.0000 .0000 .0000
.0000 .0000 .0000	.0000 .0000 .0000	.0000 .0000 .0000

\*\*\*\*\* CAS(3)- SERVICE LEVEL D \*\*\*\*\*

FORCE MAX. 120.715	FORCE MAX. 368.887	FORCE MAX. 4067.330
FORCE MIN. .000	FORCE MIN. .000	FORCE MIN. .000
AXIAL, SWING MAX/MIN:	AXIAL, SWING MAX/MIN:	AXIAL, SWING MAX/MIN:
COMP = .0000, .0000	TEN = .0000, .0000	TEN = .0000, .0000
TEN = .0000, .0001	COMP = .0000, .0001	COMP = .0001, .0000
GLOBAL DISPL. MAX/MIN:	LOCAL DISPL. MAX/MIN:	GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000	.0000 .0000 .0000	.0000 .0000 .0000
.0000 -.0001 -.0000	-.0001 -.0001 -.0000	.0000 .0000 .0000

\*\*\*\*\* CAS(4)- SERVICE LEVEL 3\*B \*\*\*\*\*

FORCE MAX. .000	FORCE MAX. .000	FORCE MAX. .000
FORCE MIN. .000	FORCE MIN. .000	FORCE MIN. .000
AXIAL, SWING MAX/MIN:	AXIAL, SWING MAX/MIN:	AXIAL, SWING MAX/MIN:
N/A = .0000, .0000	N/A = .0000, .0000	N/A = .0000, .0000
N/A = .0000, .0000	N/A = .0000, .0000	N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN:	LOCAL DISPL. MAX/MIN:	GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000	.0000 .0000 .0000	.0000 .0000 .0000
.0000 .0000 .0000	.0000 .0000 .0000	.0000 .0000 .0000

ATTACHMENT 2  
 PAGE 107 of 143  
 CALC. NO. C-0031/TIRB

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE003.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

NODE = 17SAN SUPPORT 2 OF 2 (Rotation only)		
PIPE DIRECTION COSINES: X = .1745, Y = -.7074, Z = -.6849		
SUPT: 4 RIGID	SUPT: 5 RIGID	SUPT: 6 RIGID
ROD. STIF. = .1000E+11	ROD. STIF. = .1000E+11	ROD. STIF. = .1000E+11
(X) (Y) (Z)	(X) (Y) (Z)	(X) (Y) (Z)
DIRECTION COSINES:	DIRECTION COSINES:	DIRECTION COSINES:
.9808 .0000 .1951	-.1379 -.7071 -.6936	.1379 -.7071 -.6936
***** CAS(1)- SERVICE LEVEL B *****		
MOHT. MAX. 2397.099	MOHT. MAX. 97.829	MOHT. MAX. .000
MOHT. MIN. .000	MOHT. MIN. .000	MOHT. MIN. -90.351
GLOBAL DISPL. MAX/MIN:	LOCAL DISPL. MAX/MIN:	GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000	.0000 .0000 .0000	.0000 .0000 .0000
.0000 -.0000 -.0000	.0001 .0000 .0000	.0000 .0000 .0000
***** CAS(2)- SERVICE LEVEL C *****		
MOHT. MAX. .000	MOHT. MAX. .000	MOHT. MAX. .000
MOHT. MIN. .000	MOHT. MIN. .000	MOHT. MIN. .000
GLOBAL DISPL. MAX/MIN:	LOCAL DISPL. MAX/MIN:	GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000	.0000 .0000 .0000	.0000 .0000 .0000
.0000 .0000 .0000	.0000 .0000 .0000	.0000 .0000 .0000
***** CAS(3)- SERVICE LEVEL D *****		
MOHT. MAX. 2205.322	MOHT. MAX. 186.629	MOHT. MAX. 7.306
MOHT. MIN. .000	MOHT. MIN. -88.800	MOHT. MIN. -97.656
GLOBAL DISPL. MAX/MIN:	LOCAL DISPL. MAX/MIN:	GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000	.0000 .0000 .0000	.0000 .0000 .0000
.0000 -.0001 -.0000	-.0001 -.0001 -.0000	.0000 .0000 .0000
***** CAS(4)- SERVICE LEVEL 3*B *****		
MOHT. MAX. .000	MOHT. MAX. .000	MOHT. MAX. .000
MOHT. MIN. .000	MOHT. MIN. .000	MOHT. MIN. .000
GLOBAL DISPL. MAX/MIN:	LOCAL DISPL. MAX/MIN:	GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000	.0000 .0000 .0000	.0000 .0000 .0000
.0000 .0000 .0000	.0000 .0000 .0000	.0000 .0000 .0000
SUPTMVIC	12:47: 8.22	6/ 7/1988
		PAGE 4

ATTACHMENT 2  
 PAGE 103 OF 143  
 CALC. NO. C-0031/7TRD

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS:  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

NODE = 1958N SUPPORT 1 OF 2 (Trans. only)
PIPE DIRECTION COSINES: X = -.5521, Y = -.7074, Z = -.4414

SUCT: 7 RIGID | SUCT: 8 RIGID | SUCT: 9 RIGID
TRAN STIF. = .1000E+09 | TRAN STIF. = .1000E+09 | TRAN STIF. = .1000E+09
(X) (Y) (Z) | (X) (Y) (Z) | (X) (Y) (Z)
DIRECTION COSINES: | DIRECTION COSINES: | DIRECTION COSINES:
1.0000 .0000 .0000 | .0000 -.7071 .7071 | .0000 -.7071 -.7071

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000 | FORCE MAX. 990.717 | FORCE MAX. 2135.455
FORCE MIN. -1008.751 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
TEN. = .0000, .0000 | COMP = .0000, .0000 | COMP = .0000, .0000
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
-.0000 -.0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. .000
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 889.259 | FORCE MAX. 754.244 | FORCE MAX. 1368.226
FORCE MIN. -1898.010 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
COMP = .0000, .0000 | TEN. = .0000, .0000 | TEN. = .0000, .0000
TEN. = .0000, .0000 | COMP = .0000, .0000 | COMP = .0000, .0000
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
-.0000 -.0000 -.0000 | -.0000 -.0000 -.0000 | .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL J+B *****
FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. .000
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

SUPTRVIC 12:47: 8.22 6/ 7/1988 PAGE 5
    
```

ATTACHMENT 2  
 PAGE 109 OF 143  
 CALC. NO. C-0031/TIRD

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SMOOTHER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

NODE = 195BN SUPPORT 2 OF 2 (Rotation only)

PIPE DIRECTION COSINES: X = -.9321, Y = -.7074, Z = -.4414

SUPT: 10 RIGID | SUPT: 11 RIGID | SUPT: 12 RIGID
ROT. STIF. = .1000E+11 | ROT. STIF. = .1000E+11 | ROT. STIF. = .1000E+11
(X) (Y) (Z) | (X) (Y) (Z) | (X) (Y) (Z)
DIRECTION COSINES: | DIRECTION COSINES: | DIRECTION COSINES:
1.0000 .0000 .0000 | .0000 -.7071 .7071 | .0000 -.7071 -.7071

***** CAS(1)- SERVICE LEVEL B *****
MOMT. MAX. 2530.344 | MOMT. MAX. .000 | MOMT. MAX. 2243.646
MOMT. MIN. .000 | MOMT. MIN. -2238.183 | MOMT. MIN. .000

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
-.0000 -.0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
MOMT. MAX. .000 | MOMT. MAX. .000 | MOMT. MAX. .000
MOMT. MIN. .000 | MOMT. MIN. .000 | MOMT. MIN. .000

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
MOMT. MAX. 1995.882 | MOMT. MAX. 720.382 | MOMT. MAX. 1968.499
MOMT. MIN. .000 | MOMT. MIN. -2978.565 | MOMT. MIN. .000

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
-.0000 -.0000 -.0000 | -.0000 -.0000 -.0000 | .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3+B *****
MOMT. MAX. .000 | MOMT. MAX. .000 | MOMT. MAX. .000
MOMT. MIN. .000 | MOMT. MIN. .000 | MOMT. MIN. .000

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

SUPTMVIC 12: 47: B.22 6/ 7/1988 PAGE 6
    
```

ATTACHMENT  
 PAGE 110 OF 143  
 CALC. NO. C-0031 TIRP

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

NODE = P201      SUPPORT 1 OF 2                      (Trans. only)

PIPE DIRECTION COSINES: X = .0000, Y = .0000, Z = -1.0000

SUP1: 13  RIGID | SUP2: 14  RIGID | SUP3: 15  RIGID
TRAN STIF. = .3160E+08 | TRAN STIF. = .5120E+07 | TRAN STIF. = .1470E+07
(X) (Y) (Z) | (X) (Y) (Z) | (X) (Y) (Z)
DIRECTION COSINES: | DIRECTION COSINES: | DIRECTION COSINES:
1.0000 .0000 .0000 | .0000 -.9848 -.1736 | .0000 .1736 -.9848

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. 192.986 | FORCE MAX. 5175.962 | FORCE MAX. .000
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. -5412.059
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
COMP = .0000, .0035 | TEN = .0006, .0034 | TEN = .0034, .0006
TEN = .0000, .0016 | COMP = .0016, .0003 | TEN = .0003, .0016
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0035 | .0035 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 -.0016 .0000 | .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. .000
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 546.104 | FORCE MAX. 4218.779 | FORCE MAX. 1532.769
FORCE MIN. -353.119 | FORCE MIN. .000 | FORCE MIN. -6944.828
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
COMP = .0000, .0025 | TEN = .0008, .0024 | TEN = .0024, .0008
TEN = .0000, .0020 | COMP = .0019, .0003 | TEN = .0003, .0019
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0003 .0025 | .0025 .0003 .0000 | .0000 .0000 .0000
-.0000 -.0020 .0000 | .0000 -.0020 -.0000 | .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL B *****
FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. .000
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

SUPPORT 12: 47: 8.22 6/ 7/1988 PAGE 7
    
```

ATTACHMENT 2  
 PAGE 111 OF 143  
 CALC. NO. C-0031/TEDR



NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBER  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

NODE = P201			SUPPORT 2 OF 2			(Rotation only)		
PIPE DIRECTION COSINES: X = .0000, Y = .0000, Z = -1.0000								
SUPT: 16 RIGID			SUPT: 17 RIGID			SUPT: 18 RIGID		
ROT. STIF. = .1570E+08			ROT. STIF. = .1566E+08			ROT. STIF. = .2970E+07		
(X)	(Y)	(Z)	(X)	(Y)	(Z)	(X)	(Y)	(Z)
DIRECTION COSINES:			DIRECTION COSINES:			DIRECTION COSINES:		
1.0000	.0000	.0000	.0000	-.9848	-.1736	.0000	.1736	-.9848
***** CAS(1)- SERVICE LEVEL B *****								
MOMT. MAX. 1761.167			MOMT. MAX. .000			MOMT. MAX. 227.921		
MOMT. MIN. .000			MOMT. MIN. -389.058			MOMT. MIN. .000		
GLOBAL DISPL. MAX/MIN:			LOCAL DISPL. MAX/MIN:			GLOBAL ACCEL. MAX/MIN:		
.0000	.0000	.0035	-.0035	.0000	.0000	.0000	.0000	.0000
.0000	-.0016	.0000	.0000	-.0016	.0000	.0000	.0000	.0000
***** CAS(2)- SERVICE LEVEL C *****								
MOMT. MAX. .000			MOMT. MAX. .000			MOMT. MAX. .000		
MOMT. MIN. .000			MOMT. MIN. .000			MOMT. MIN. .000		
GLOBAL DISPL. MAX/MIN:			LOCAL DISPL. MAX/MIN:			GLOBAL ACCEL. MAX/MIN:		
.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000
.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000
***** CAS(3)- SERVICE LEVEL D *****								
MOMT. MAX. 1266.897			MOMT. MAX. 1408.985			MOMT. MAX. 398.052		
MOMT. MIN. .000			MOMT. MIN. -1998.043			MOMT. MIN. -170.131		
GLOBAL DISPL. MAX/MIN:			LOCAL DISPL. MAX/MIN:			GLOBAL ACCEL. MAX/MIN:		
.0000	.0003	.0025	.0025	.0003	.0000	.0000	.0000	.0000
.0000	-.0020	.0000	.0000	-.0020	-.0000	.0000	.0000	.0000
***** CAS(4)- SERVICE LEVEL E *****								
MOMT. MAX. .000			MOMT. MAX. .000			MOMT. MAX. .000		
MOMT. MIN. .000			MOMT. MIN. .000			MOMT. MIN. .000		
GLOBAL DISPL. MAX/MIN:			LOCAL DISPL. MAX/MIN:			GLOBAL ACCEL. MAX/MIN:		
.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000
.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000
SUPTMVIC			12: 47: 8.22			6/ 7/1988		
						PAGE 8		

ATTACHMENT  
 PAGE 112 OF 143  
 CALC. NO. C-0031/TIR0

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTCH ENGINEERS

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005 1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

NODE = H19      SUPPORT 1 OF 1      (Trans. only)

PIPE DIRECTION COSINES. X = .0000. Y = 1.0000. Z = .0000

SUPT: 19      21010 SPRING HANGER.
TRAN STIF = .1800E+04
(X) (Y) (Z)      Hot Load = 4940. } Design
DIRECTION COSINES:      06-07-88
.0000 1.0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX.      35.435
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
COMP = .0197. .0019
TEN. = .0000. .0013
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0197 .0019 .0197 .0019 .0000 .0000 .0000 .0000
-.0013 .0000 .0000 .0000 .0000 -.0013 .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX.      .000
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
N/A = .0000. .0000
N/A = .0000. .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX.      35.435
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
COMP = .0197. .0019
TEN. = .0000. .0013
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0197 .0019 .0197 .0019 .0000 .0000 .0000 .0000
-.0013 .0000 .0000 .0000 .0000 -.0013 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3#B *****
FORCE MAX.      .000
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
N/A = .0000. .0000
N/A = .0000. .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPT#VIC      12:47: 8.22      6/ 7/1988      PAGE 9
    
```

ATTACHMENT  
 PAGE 115 of 143  
 CALC. NO. C-0031/TIRD

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

NODE = H18      SUPPORT 1 OF 1                      (Trans. only)
PIPE DIRECTION COSINES: X = -1.0000, Y = .0091, Z = .0000

SUPT: 20      SNUBBER
TRAN STIF. = .2590E+06
(X) (Y) (Z)
DIRECTION COSINES:
.0000 1.0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
COMP = .0065, .0001
TEN = .0000, .0128
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0065 .0001 .0001 .0065 -.0001 .0000 .0000 .0000
-.0128 .0000 .0000 .0128 -.0001 .0000 .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 688.094
FORCE MIN. -688.094
AXIAL SWING MAX/MIN:
COMP = .0038, .0111
TEN = .0000, .0239
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0111 .0038 .0007 .0111 .0039 .0007 .0000 .0000 .0000
-.0239 .0000 -.0006 -.0239 -.0002 -.0006 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL J+B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTMVIC 12: 47: 8.22 6/ 7/1988 PAGE 10

```

ATTACHMENT 2  
PAGE 114 OF 143  
CALC. NO. C-0031/TIRM

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBER  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

NODE = H17      SUPPORT 1 OF 1      (Trans. only)
PIPE DIRECTION COSINES: X = -1.0000, Y = .0093, Z = .0000

SUP1: 21      RICID
TRAN STIF. = .1320E+07
(X) (Y) (Z)
DIRECTION COSINES:
.0000 .0000 1.0000

*****
CAS(1)- SERVICE LEVEL B *****
FORCE MAX.      148.664
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
COMP = .0001, .0050
TEN = .0000, .0128
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0050 .0001 .0000 .0050 -.0001 .0000 .0000 .0000
-.0128 .0000 .0000 .0128 -.0001 .0000 .0000 .0000 .0000

*****
CAS(2)- SERVICE LEVEL C *****
FORCE MAX.      .000
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

*****
CAS(3)- SERVICE LEVEL D *****
FORCE MAX.      766.348
FORCE MIN.     -617.685
AXIAL SWING MAX/MIN:
COMP = .0006, .0114
TEN = .0005, .0239
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0111 .0026 .0006 .0111 .0027 .0006 .0000 .0000 .0000
-.0239 .0000 -.0005 -.0239 -.0002 -.0005 .0000 .0000 .0000

*****
CAS(4)- SERVICE LEVEL J=D *****
FORCE MAX.      .000
FORCE MIN.      .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTRVIC      12:47; 8.22      6/ 7/1988      PAGE 11
  
```

ATTACHMENT  
 PAGE 115 OF 143  
 CALC. NO. C-0031 / TIRD

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBER: \_\_\_\_\_  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1014  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

-----
| NODE = H22      SUPPORT 1 OF 1                      (Trans. only) |
| PIPE DIRECTION COSINES: X = .0000, Y = 1.0000, Z = .0000 |
| SUPT: 22      SNUDDER |
| TRAN. STIF. = .8700E+05 |
| (X) (Y) (Z) |
| DIRECTION COSINES: |
| .0000 .0000 1.0000 |
| ***** |
| CAS(1)- SERVICE LEVEL B ***** |
| FORCE MAX. .000 |
| FORCE MIN. .000 |
| AXIAL SWING MAX/MIN: |
| TEN. = .0000 .0002 |
| TEN. = .0007 .0250 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0000 .0002 .0000 .0002 .0000 .0000 .0000 .0000 .0000 |
| -.0250 .0000 -.0007 .0000 -.0007 -.0250 .0000 .0000 .0000 |
| ***** |
| CAS(2)- SERVICE LEVEL C ***** |
| FORCE MAX. .000 |
| FORCE MIN. .000 |
| AXIAL SWING MAX/MIN: |
| N/A = .0000 .0000 |
| N/A = .0000 .0000 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| ***** |
| CAS(3)- SERVICE LEVEL D ***** |
| FORCE MAX. 342.669 |
| FORCE MIN. -342.669 |
| AXIAL SWING MAX/MIN: |
| COMP = .0039 .0176 |
| TEN. = .0046 .0424 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0174 .0026 .0039 .0026 .0039 .0174 .0000 .0000 .0000 |
| -.0424 -.0023 -.0046 -.0023 -.0046 -.0424 .0000 .0000 .0000 |
| ***** |
| CAS(4)- SERVICE LEVEL 3*B ***** |
| FORCE MAX. .000 |
| FORCE MIN. .000 |
| AXIAL SWING MAX/MIN: |
| N/A = .0000 .0000 |
| N/A = .0000 .0000 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| ***** |
| SUPTHVIC 12:47: 8.22 6/ 7/1988 PAGE 12 |
-----
  
```

ATTACHMENT 2  
 PAGE 116 OF 143  
 CALC. NO. C-0031/TIRD

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. C-31) P5E005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

NODE = H14      SUPPORT 1 OF 1      (Trans. only)
PIPE DIRECTION COSINES: X = -1.0000, Y = .0092, Z = .0000

SUPT: 24      RIGID
TRAN STIF. = .3491E+07
(X) (Y) (Z)
DIRECTION COSINES:
.0000 .0000 1.0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. -82.637
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
TEN. = .0000, .0134
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
-.0129 -.0035 -.0000 .0129 -.0036 .0000 .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 1486.106
FORCE MIN. -1568.743
AXIAL SWING MAX/MIN:
COMP. .0004, .0115
TEN. = .0004, .0248
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0111 .0030 .0004 .0111 .0031 .0004 .0000 .0000 .0000
-.0240 -.0065 -.0004 -.0240 -.0068 -.0004 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3+B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTMVIC      12:47: 8.22      6/ 7/1988      PAGE 13
    
```

ATTACHMENT 2  
 PAGE 17 OF 143  
 CALC. NO. C-0031/TIPD

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP, ADCE

```

NODE = H15      SUPPORT 1 OF 1      (Trans. only)
PIPE DIRECTION COSINES: X = -1.0000, Y = .0040, Z = .0000

SUPT: 23      SNUBBER
TRAN STIF. = .4950E+06
(X) (Y) (Z)
DIRECTION COSINES:
.0000 1.0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL, SWING MAX/MIN:
N/A = .0000, .0000
TEN. = .0045, .0129
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
-.0129 -.0045 -.0000 .0129 -.0045 .0000 .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL, SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 1616.753
FORCE MIN. -1616.753
AXIAL, SWING MAX/MIN:
COMP = .0033, .0111
TEN. = .0077, .0239
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0110 .0033 .0006 .0111 .0033 .0006 .0000 .0000 .0000
-.0239 -.0077 -.0006 -.0240 -.0078 -.0006 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL, SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTMVIC 12: 47: 8.22 6/ 7/1988 PAGE 14

```

ATTACHMENT  
PAGE 118 of 143  
CALC. NO. C-0031/TIRD  
2

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

NODE = H13 SUPPORT 1 OF 1 (Trans. only)

PIPE DIRECTION COSINES: X = -1.0000, Y = .0091, Z = .0000

SUPT: 25 RIGID  
TRAN. STIF. = .4800E+06  
(X) (Y) (Z)  
DIRECTION COSINES:  
.0000 1.0000 .0000

\*\*\*\*\* CAS(1)- SERVICE LEVEL B \*\*\*\*\*  
FORCE MAX. .000  
FORCE MIN. -6081.771  
AXIAL SWING MAX/MIN:  
N/A = .0000, .0000  
TEN. = .0127, .0130  
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:  
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000  
-.0130 -.0127 -.0002 .0128 -.0128 .0002 .0000 .0000 .0000

\*\*\*\*\* CAS(2)- SERVICE LEVEL C \*\*\*\*\*  
FORCE MAX. .000  
FORCE MIN. .000  
AXIAL SWING MAX/MIN:  
N/A = .0000, .0000  
N/A = .0000, .0000  
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:  
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000  
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

\*\*\*\*\* CAS(3)- SERVICE LEVEL D \*\*\*\*\*  
FORCE MAX. 3830.846  
FORCE MIN. -9912.617  
AXIAL SWING MAX/MIN:  
COMP = .0080, .0113  
TEN. = .0207, .0241  
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:  
.0109 .0080 .0029 .0110 .0081 .0029 .0000 .0000 .0000  
-.0239 -.0207 -.0031 -.0240 -.0209 -.0031 .0000 .0000 .0000

\*\*\*\*\* CAS(4)- SERVICE LEVEL 3\*B \*\*\*\*\*  
FORCE MAX. .000  
FORCE MIN. .000  
AXIAL SWING MAX/MIN:  
N/A = .0000, .0000  
N/A = .0000, .0000  
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:  
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000  
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTRVIC 12: 47: 8.22 6/ 7/1988 PAGE 15

ATTACHMENT 2  
PAGE 119 OF 143  
CALC. NO. C-0031/TIRO

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222



PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNURDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSED05.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

NUDE = H11      SUPPORT 1 OF 1      (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = -1.0000, Z = .0000

SUPT: 26      RIGID
TRAN. STIF. = .1790E+07
(X) (Y) (Z)
DIRECTION COSINES:
-.7844 .0000 -.6202

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. 199.088
FORCE MIN. .000
AXIAL SWING MAX/MIN:
TEN = .0005, .0006
COMP = .0006, .0247
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0008 .0000 .0008 .0000 .0000 .0000 .0000
-.0008 -.0247 .0000 .0247 .0000 .0008 .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 4752.394
FORCE MIN. -4553.306
AXIAL SWING MAX/MIN:
TEN = .0043, .0161
COMP = .0044, .0408
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0042 .0160 .0016 .0160 .0016 .0042 .0000 .0000 .0000
-.0050 -.0408 -.0008 -.0408 -.0008 -.0050 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL D*B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTMVIC 12: 47: 8.22 6/ 7/1988 PAGE 16
    
```

ATTACHMENT 2  
 PAGE 120 OF 143  
 CALC. NO. C-0531/71R0

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

NODE = H12      SUPPORT 1 OF 1      (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = -1.0000, Z = .0000

SUPT: 27      RIGID
TRAN STIF. = .3066E+07
(X) (Y) (Z)
DIRECTION COSINES:
.4524 .0000 -.8918

*****
CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. -180.331
AXIAL SWING MAX/MIN:
TEN. = .0001, .0025
TEN. = .0000, .0248
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0022 .0000 .0012 .0000 .0012 -.0022 .0000 .0000 .0000
.0000 -.0248 .0000 .0248 .0000 .0000 .0000 .0000 .0000

*****
CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

*****
CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 2970.485
FORCE MIN. -3150.815
AXIAL SWING MAX/MIN:
COMP = .0005, .0169
TEN. = .0006, .0410
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0048 .0161 .0019 .0161 .0019 .0048 .0000 .0000 .0000
-.0026 -.0409 -.0007 -.0409 -.0007 -.0026 .0000 .0000 .0000

*****
CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTMVIC      12:47: 8.22      6/ 7/1988      PAGE 17
    
```

ATTACHMENT 2  
 PAGE 12 OF 143  
 CALC. NO. C-0031/TIRD

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

NODE = H10      SUPPORT 1 OF 1      (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = -1.0000, Z = .0000

SUPT: 28 SNUDDER
TRAN STIF. = .0000E+00
(X) (Y) (Z)
DIRECTION COSINES:
1.0000 .0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL, SWING MAX/MIN:
COMP = .0157, .0039
TEN = .0000, .0250
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0157 .0000 .0039 .0000 .0039 -.0157 .0000 .0000 .0000
.0000 -.0250 .0000 .0250 .0000 .0000 .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL, SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL, SWING MAX/MIN:
COMP = .0220, .0199
TEN = .0063, .0420
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0220 .0163 .0114 .0163 .0114 .0220 .0000 .0000 .0000
-.0063 -.0413 -.0074 -.0413 -.0074 -.0063 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL, SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTRVIC      12:47: 8.22      6/ 7/1988      PAGE 18
    
```

ATTACHMENT 2  
 PAGE 122 OF 143  
 CALC. NO. C-D031/T190

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBER  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

NODE = H9      SUPPORT 1 OF 1      (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = -1.0000, Z = .0000

SUPT: 29      SNUDDER
TRAN STIF. = .0000E+00
(X) (Y) (Z)
DIRECTION COSINES:
.2801 .0000 -.9600

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
COMP = .0007, .0177
TEN = .0000, .0250
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0172 .0000 .0043 .0000 .0043 -.0172 .0000 .0000 .0000
.0000 -.0250 .0000 .0250 .0000 .0000 .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
TEN = .0034, .0309
COMP = .0061, .0422
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0236 .0163 .0126 .0163 .0126 .0236 .0000 .0000 .0000
-.0064 -.0414 -.0083 -.0414 -.0083 -.0064 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTMVIC 12: 47: 8.22 6/ 7/1988 PAGE 19
    
```

ATTACHMENT 2  
 PAGE 123 OF 143  
 CALC. NO. C-0031/71RO

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

NODE = 95BEL SUPPORT 1 OF 2 (Trans. only)

PIPE DIRECTION COSINES: X = .0000, Y = -.0112, Z = -.9999

SUPT: 30	RIGID	SUPT: 31	RIGID	SUPT: 32	RIGID
TRAN. STIF. = .3100E+03		TRAN. STIF. = .1825E+04		TRAN. STIF. = .1825E+04	
(X) (Y) (Z)		(X) (Y) (Z)		(X) (Y) (Z)	
DIRECTION COSINES:		DIRECTION COSINES:		DIRECTION COSINES:	
.0000	.0000	-1.0000	.0000	1.0000	.0000

\*\*\*\*\* CAS(1)- SERVICE LEVEL B \*\*\*\*\*

FORCE MAX.	.033	FORCE MAX.	.000	FORCE MAX.	31.162
FORCE MIN.	.000	FORCE MIN.	-15.508	FORCE MIN.	.000
AXIAL, SWING MAX/MIN:		AXIAL, SWING MAX/MIN:		AXIAL, SWING MAX/MIN:	
TEN. =	.0000, .0171	TEN. =	.0000, .0171	N/A =	.0171, .0000
COMP =	.0001, .0085	TEN. =	.0085, .0001	TEN. =	.0000, .0085
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.0171	.0000	.0000	.0000	.0171	.0000
.0000	-.0085	-.0001	.0002	-.0085	.0000

\*\*\*\*\* CAS(2)- SERVICE LEVEL C \*\*\*\*\*

FORCE MAX.	.000	FORCE MAX.	.000	FORCE MAX.	.000
FORCE MIN.	.000	FORCE MIN.	.000	FORCE MIN.	.000
AXIAL, SWING MAX/MIN:		AXIAL, SWING MAX/MIN:		AXIAL, SWING MAX/MIN:	
N/A =	.0000, .0000	N/A =	.0000, .0000	N/A =	.0000, .0000
N/A =	.0000, .0000	N/A =	.0000, .0000	N/A =	.0000, .0000
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.0000	.0000	.0000	.0000	.0000	.0000
.0000	.0000	.0000	.0000	.0000	.0000

\*\*\*\*\* CAS(3)- SERVICE LEVEL D \*\*\*\*\*

FORCE MAX.	2.693	FORCE MAX.	87.032	FORCE MAX.	36.482
FORCE MIN.	-2.661	FORCE MIN.	-102.540	FORCE MIN.	-5.320
AXIAL, SWING MAX/MIN:		AXIAL, SWING MAX/MIN:		AXIAL, SWING MAX/MIN:	
TEN. =	.0087, .0517	COMP =	.0477, .0218	COMP =	.0200, .0485
COMP =	.0088, .0563	TEN. =	.0562, .0093	TEN. =	.0029, .0569
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.0200	.0477	.0087	.0092	.0478	.0200
-.0029	-.0562	-.0088	-.0094	-.0563	-.0029

\*\*\*\*\* CAS(4)- SERVICE LEVEL 3\*B \*\*\*\*\*

FORCE MAX.	.000	FORCE MAX.	.000	FORCE MAX.	.000
FORCE MIN.	.000	FORCE MIN.	.000	FORCE MIN.	.000
AXIAL, SWING MAX/MIN:		AXIAL, SWING MAX/MIN:		AXIAL, SWING MAX/MIN:	
N/A =	.0000, .0000	N/A =	.0000, .0000	N/A =	.0000, .0000
N/A =	.0000, .0000	N/A =	.0000, .0000	N/A =	.0000, .0000
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.0000	.0000	.0000	.0000	.0000	.0000
.0000	.0000	.0000	.0000	.0000	.0000

SUPTMVIC 12:47: 8.22 6/ 7/1988 PAGE 20

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

ATTACHMENT 2  
 PAGE 24 OF 148  
 CALC. NO. C-0031/TIRO

PIPE SUPPORT LOAD COMB RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) P5E005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

NODE = 95BEL SUPPORT 2 OF 2 (Rotation only)
PIPE DIRECTION COSINES: X = .0000, Y = -.0112, Z = -.9999

SUPT: 33 RIGID | SUPT: 34 RIGID | SUPT: 35 RIGID
ROT. STIF. = .6670E+05 | ROT. STIF. = .6670E+05 | ROT. STIF. = .6670E+05
(X) (Y) (Z) | (X) (Y) (Z) | (X) (Y) (Z)
DIRECTION COSINES: | DIRECTION COSINES: | DIRECTION COSINES:
.0000 .0000 -1.0000 | .0000 1.0000 .0000 | 1.0000 .0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
MOMT. MAX. .000 | MOMT. MAX. 6.821 | MOMT. MAX. 9.392
MOMT. MIN. -7.355 | MOMT. MIN. .000 | MOMT. MIN. .000

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0171 .0000 .0000 | .0000 .0000 .0171 | .0000 .0000 .0000
.0000 -.0085 -.0001 | .0002 -.0085 .0000 | .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
MOMT. MAX. .000 | MOMT. MAX. .000 | MOMT. MAX. .000
MOMT. MIN. .000 | MOMT. MIN. .000 | MOMT. MIN. .000

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
MOMT. MAX. 37.010 | MOMT. MAX. 7.997 | MOMT. MAX. 31.277
MOMT. MIN. -44.565 | MOMT. MIN. -1.176 | MOMT. MIN. -21.885

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0200 .0477 .0087 | .0092 .0478 .0200 | .0000 .0000 .0000
-.0029 -.0562 -.0088 | -.0094 -.0563 -.0029 | .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3*B *****
MOMT. MAX. .000 | MOMT. MAX. .000 | MOMT. MAX. .000
MOMT. MIN. .000 | MOMT. MIN. .000 | MOMT. MIN. .000

GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

SUPTMVIC 12: 47: 8.22 6/ 7/1988 PAGE 21
    
```

ATTACHMENT 2  
 PAGE 125 OF 143  
 CALC. NO. C-0031/T120

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUCLEON ENGINEERS

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUGGER REDUCTION FILE NUMBER  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

NODE = HB          SUPPORT 1 OF 1          (Trans. only)

PIPE DIRECTION COSINES: X = .0000, Y = -.0100, Z = -.9999

SUPT: 36          HEAD } SPRING HANGER
TRAN STIF. = .1200E+04 } HOT LOAD = 2860 # } 0.1012
(X) (Y) (Z)          } 06-07-88

DIRECTION COSINES:
.0000 1.0000 .0000

*****
CAS(1)- SERVICE LEVEL B          *****
FORCE MAX.          .000
FORCE MIN.          -3.493
AXIAL SWING MAX/MIN:
TEN. = .0000, .0123
TEN = .0029, .0002
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0123 .0000 .0000 .0000 .0000 .0123 .0000 .0000 .0000
.0000 -.0029 -.0002 .0002 -.0029 .0000 .0000 .0000 .0000

*****
CAS(2)- SERVICE LEVEL C          *****
FORCE MAX.          .000
FORCE MIN.          .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

*****
CAS(3)- SERVICE LEVEL D          *****
FORCE MAX.          76.759
FORCE MIN.          -80.252
AXIAL SWING MAX/MIN:
COMP = .0640, .0162
TEN. = .0669, .0089
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0138 .0640 .0086 .0092 .0640 .0138 .0000 .0000 .0000
-.0015 -.0669 -.0087 -.0094 -.0670 -.0015 .0000 .0000 .0000

*****
CAS(4)- SERVICE LEVEL 3*B          *****
FORCE MAX.          .000
FORCE MIN.          .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTMVC          12:47: 8.22          6/ 7/1988          PAGE 22
    
```

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

ATTACHMENT  
 PAGE 126 OF 143  
 2

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBER  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

NODE = H7          SUPPORT 1 OF 1          (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = .0143, Z = -.9999

SUPT: 37 SNUBBER
TRAN STIF. = .0000E+00
(X) (Y) (Z)
DIRECTION COSINES:
1.0000 .0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0102 .0000
TEN. = .0000 .0027
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0102 .0000 .0000 .0000 .0000 .0102 .0000 .0000 .0000
.0000 -.0027 -.0002 .0001 -.0027 .0000 .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000 .0000
N/A = .0000 .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
COMP = .0127 .0725
TEN. = .0024 .0752
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0127 .0720 .0085 .0095 .0721 .0127 .0000 .0000 .0000
-.0024 -.0747 -.0086 -.0097 -.0748 -.0024 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000 .0000
N/A = .0000 .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTRVIC          12:47: 8.22          6/ 7/1988          PAGE 23
    
```

ATTACHMENT 2  
 PAGE 127 OF 143

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222



PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) P5E005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

-----
NODE = H6          SUPPORT 1 DF 1          (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = -.0122, Z = -.9999

SUPT: 3B          RIGID
TRAN. STIF. = .1402E+07
(X) (Y) (Z)
DIRECTION COSINES:
.0000 .0000 1.0000

*****
CAS(1)-- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. -156.044
AXIAL SWING MAX/MIN:
TEN = .0000, .0025
TEN = .0001, .0039
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0025 .0000 .0000 .0000 .0000 .0025 .0000 .0000 .0000
.0000 -.0039 -.0001 .0002 -.0039 .0000 .0000 .0000 .0000

*****
CAS(2)-- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

*****
CAS(3)-- SERVICE LEVEL D *****
FORCE MAX. 9467.834
FORCE MIN. -9623.878
AXIAL SWING MAX/MIN:
COMP = .0068, .0328
TEN = .0069, .0360
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0099 .0313 .0068 .0071 .0314 .0099 .0000 .0000 .0000
.0073 -.0353 -.0069 -.0073 -.0354 -.0073 .0000 .0000 .0000

*****
CAS(4)-- SERVICE LEVEL 3*B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

-----
SUPTMVIC          12:47: 8.22          6/ 7/1988          PAGE 24
    
```

ATTACHMENT 2  
 PAGE 128 OF 143  
 CALC. NO. C-0531/TIRD

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) P5E005, 1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

NODE = H5A      SUPPORT 1 OF 1      (Trans. only)

PIPE DIRECTION COSINES: X = .0000, Y = -.0045, Z = -1.0000

SUPT: 39 SNUBBER
TRAN STIF. = .0000E+00
(X) (Y) (Z)
DIRECTION COSINES:
1.0000 .0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0022, .0000
TEN. = .0000, .0032
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0022 .0000 .0000 .0000 .0000 .0022 .0000 .0000 .0000
.0000 -.0032 -.0001 .0001 -.0032 .0000 .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
CMP = .0093, .0168
TEN. = .0071, .0198
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0093 .0154 .0068 .0069 .0154 .0093 .0000 .0000 .0000
-.0071 -.0186 -.0070 -.0070 -.0186 -.0071 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3#D *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPPORT 12: 47: 8.22 6/ 7/1988 PAGE 25
    
```

ATTACHMENT 1  
 PAGE 129 OF 143  
 CALC. NO. C-0031/TIRO

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

NODE = H4A      SUPPORT 1 OF 1      (Trans. only)

PIPE DIRECTION COSINES: X = .0000, Y = -.0113, Z = -.9999

SUPT: 40      RIGID
TRAN. STIF. = .6160E+06
(X) (Y) (Z)
DIRECTION COSINES:
.0000 1.0000 .0000

*****
CAS(1)- SERVICE LEVEL B      *****
FORCE MAX. .000
FORCE MIN. -1743.452
AXIAL SWING MAX/MIN:
TEN. = .0000 .0020
TEN. = .0028 .0001
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0020 .0000 .0000 .0000 .0000 .0020 .0000 .0000 .0000
.0000 -.0028 -.0001 .0002 -.0028 .0000 .0000 .0000 .0000

*****
CAS(2)- SERVICE LEVEL C      *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000 .0000
N/A = .0000 .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

*****
CAS(3)- SERVICE LEVEL D      *****
FORCE MAX. 3652.928
FORCE MIN. -5396.381
AXIAL SWING MAX/MIN:
COMP = .0059 .0113
TEN. = .0088 .0099
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0089 .0059 .0070 .0070 .0060 .0089 .0000 .0000 .0000
-.0069 -.0088 -.0071 -.0072 -.0088 -.0069 .0000 .0000 .0000

*****
CAS(4)- SERVICE LEVEL 3*B      *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000 .0000
N/A = .0000 .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTRVIC      12: 47: 8.22      6/ 7/1988      PAGE 26
    
```

ATTACHMENT 2  
 PAGE 130 OF 143  
 CALC. NO. C-0031/71R2

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HUPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

NODE = H3A      SUPPORT 1 OF 1      (Trans. only)
PIPE DIRECTION COSINES: X = .9999, Y = -.0109, Z = .0000

SUPT: 41 SNUBBER
TRAN. STIF. = .0000E+00
(X) (Y) (Z)
DIRECTION COSINES:
.0767 .0000 -.9971

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
COMP = .0001, .0015
COMP = .0013, .0026
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0015 .0000 .0000 .0015 .0000 .0000 .0000 .0000 .0000
.0000 -.0026 -.0013 .0000 -.0026 -.0013 .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
TEN = .0163, .0194
COMP = .0178, .0210
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0088 .0163 .0171 .0090 .0166 .0171 .0000 .0000 .0000
-.0073 -.0191 -.0184 -.0075 -.0192 -.0184 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3#B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTRWIC 12:47: 8.22 6/ 7/1988 PAGE 27
    
```

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

ATTACHMENT 2  
 PAGE 131 OF 143  
 CALC. NO. 2-0031/7TRD

NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

NODE = H2A      SUPPORT 1 OF 1      (Trans. only)

PIPE DIRECTION COSINES: X = .9999, Y = -.0104, Z = .0000

SUPT: 42 SNUBBER
TRAN STIF. = .0000E+00
(X) (Y) (Z)
DIRECTION COSINES:
.0000 1.0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL, SWING MAX/MIN:
COMP = .0006, .0016
TEN. = .0000, .0016
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0016 .0006 .0000 .0015 .0006 .0000 .0000 .0000 .0000
.0000 .0000 -.0016 .0000 .0000 -.0016 .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL, SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL, SWING MAX/MIN:
COMP = .0076, .0197
TEN. = .0070, .0206
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0088 .0076 .0177 .0089 .0077 .0177 .0000 .0000 .0000
-.0073 -.0070 -.0193 -.0073 -.0071 -.0193 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL, SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTMVIC      12: 47: 8.22      6/ 7/1988      PAGE 28
  
```

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

ATTACHMENT 1 2  
 PAGE 132 OF 143  
 CALC. NO. C-0531/TIRO

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUDDEN REDUCTION FILE NUMBER  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) P5E005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

MODE = HIA SUPPORT 1 OF 1 (Trans. only)

PIPE DIRECTION COSINES: X = .9999, Y = -.0105, Z = .0000

SUPT: 43 ~~RIGID~~ SPRING HANGER  
 TRAN STIF. = .9000E+03 Hot LOAD = 2158. # *0.2158*  
 (X) (Y) (Z) *06-07-88*

DIRECTION COSINES:  
 .0000 1.0000 .0000

\*\*\*\*\* CAS(1)- SERVICE LEVEL B \*\*\*\*\*  
 FORCE MAX. .852  
 FORCE MIN. .000  
 AXIAL SWING MAX/MIN:  
 COMP = .0009, .0016  
 TEN. = .0000, .0016  
 GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:  
 .0016 .0009 .0000 .0015 .0010 .0000 .0000 .0000 .0000  
 .0000 .0000 -.0016 .0000 .0000 -.0016 .0000 .0000 .0000

\*\*\*\*\* CAS(2)- SERVICE LEVEL C \*\*\*\*\*  
 FORCE MAX. .000  
 FORCE MIN. .000  
 AXIAL SWING MAX/MIN:  
 N/A = .0000, .0000  
 N/A = .0000, .0000  
 GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:  
 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000  
 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

\*\*\*\*\* CAS(3)- SERVICE LEVEL D \*\*\*\*\*  
 FORCE MAX. 5.680  
 FORCE MIN. -4.828  
 AXIAL SWING MAX/MIN:  
 COMP = .0063, .0197  
 TEN. = .0054, .0205  
 GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:  
 .0088 .0063 .0176 .0089 .0064 .0176 .0000 .0000 .0000  
 -.0073 -.0054 -.0192 -.0073 -.0054 -.0192 .0000 .0000 .0000

\*\*\*\*\* CAS(4)- SERVICE LEVEL 3#B \*\*\*\*\*  
 FORCE MAX. .000  
 FORCE MIN. .000  
 AXIAL SWING MAX/MIN:  
 N/A = .0000, .0000  
 N/A = .0000, .0000  
 GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:  
 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000  
 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTRVIC 12:47: B.22 6/ 7/1988 PAGE 29

ATTACHMENT 2  
 PAGE 133 OF 143  
 CALC. NO. C-0031/71RD

NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

NODE = HPTUB SUPPORT 1 OF 2 (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = .0000, Z = 1.0000

SAPT: 44 RIGID | SAPT: 45 RIGID | SAPT: 46 RIGID
TRAN. STIF. = .1000E+09 | TRAN. STIF. = .1000E+09 | TRAN. STIF. = .1000E+09
(X) (Y) (Z) | (X) (Y) (Z) | (X) (Y) (Z)
DIRECTION COSINES: | DIRECTION COSINES: | DIRECTION COSINES:
1.0000 .0000 .0000 | .0000 1.0000 .0000 | .0000 .0000 1.0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. 14.363
FORCE MIN. -63.778 | FORCE MIN. -340.584 | FORCE MIN. .000
AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN:
TEN. = .0000, .0000 | TEN. = .0000, .0000 | N/A = .0000, .0000
TEN. = .0000, .0000 | TEN. = .0000, .0000 | TEN. = .0000, .0000
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. .000
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN:
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 1580.809 | FORCE MAX. 1477.202 | FORCE MAX. 1592.908
FORCE MIN. -1644.587 | FORCE MIN. -1817.786 | FORCE MIN. -1578.545
AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN:
COMP = .0000, .0000 | COMP = .0000, .0000 | COMP = .0000, .0000
TEN. = .0000, .0000 | TEN. = .0000, .0000 | TEN. = .0000, .0000
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
-.0000 -.0000 -.0000 | -.0000 -.0000 -.0000 | .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. .000
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN: | AXIAL, SWING MAX/MIN:
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

SAPTMVIC 12: 47: 8.22 6/ 7/1988 PAGE 30
    
```

ATTACHMENT 2  
 PAGE 134 OF 143  
 CALC. NO. C-0031/HTRO

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS PROJ

PROJECT: HOPE CREEK SNOBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) P5E005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

NODE = WPTUB SUPPORT 2 OF 2			(Rotation only)		
PIPE DIRECTION COSINES: X = .0000, Y = .0000, Z = 1.0000					
SUPT: 47	RIGID	SUPT: 48	RIGID	SUPT: 49	RIGID
ROT. STIF. = .1000E+13		ROT. STIF. = .1000E+13		ROT. STIF. = .1000E+13	
(X) (Y) (Z)		(X) (Y) (Z)		(X) (Y) (Z)	
DIRECTION COSINES:		DIRECTION COSINES:		DIRECTION COSINES:	
1.0000	.0000 .0000	.0000	1.0000 .0000	.0000	.0000 1.0000
***** CAS(1)- SERVICE LEVEL B *****					
MOHT. MAX.	.000	MOHT. MAX.	4167.737	MOHT. MAX.	.000
MOHT. MIN.	-3938.715	MOHT. MIN.	.000	MOHT. MIN.	-3127.802
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.0000	.0000 .0000	.0000	.0000 .0000	.0000	.0000 .0000
.0000	.0000 .0000	.0000	.0000 .0000	.0000	.0000 .0000
***** CAS(2)- SERVICE LEVEL C *****					
MOHT. MAX.	.000	MOHT. MAX.	.000	MOHT. MAX.	.000
MOHT. MIN.	.000	MOHT. MIN.	.000	MOHT. MIN.	.000
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.0000	.0000 .0000	.0000	.0000 .0000	.0000	.0000 .0000
.0000	.0000 .0000	.0000	.0000 .0000	.0000	.0000 .0000
***** CAS(3)- SERVICE LEVEL D *****					
MOHT. MAX.	80163.800	MOHT. MAX.	22119.520	MOHT. MAX.	72950.340
MOHT. MIN.	-84102.520	MOHT. MIN.	-17951.780	MOHT. MIN.	-76078.140
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.0000	.0000 .0000	.0000	.0000 .0000	.0000	.0000 .0000
-.0000	-.0000 -.0000	-.0000	-.0000 -.0000	.0000	.0000 .0000
***** CAS(4)- SERVICE LEVEL J+B *****					
MOHT. MAX.	.000	MOHT. MAX.	.000	MOHT. MAX.	.000
MOHT. MIN.	.000	MOHT. MIN.	.000	MOHT. MIN.	.000
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.0000	.0000 .0000	.0000	.0000 .0000	.0000	.0000 .0000
.0000	.0000 .0000	.0000	.0000 .0000	.0000	.0000 .0000
SUPPORTIVE 12:47: 8.22 6/ 7/1988 PAGE 31					

ATTACHMENT 2  
 PAGE 135 OF 143  
 CALC. NO. C-0031/TIRN



NUTEC ENGINEERS  
PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS \_\_\_\_\_  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

  | NODE = H2D      SUPPORT 1 OF 1      (Trans. only) |
  | PIPE DIRECTION COSINES: X = .0000, Y = .0104, Z = .9999 |
  | SUPT: 50 SNUDDER |
  | TRAN STIF. = .2530E+06 |
  | (X) (Y) (Z) |
  | DIRECTION COSINES: |
  | .0000 .0000 1.0000 |
  | ***** CAS(1)- SERVICE LEVEL B ***** |
  | FORCE MAX. .000 |
  | FORCE MIN. .000 |
  | AXIAL SWING MAX/MIN: |
  | N/A = .0000, .0000 |
  | TEN. = .0050, .0012 |
  | GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
  | .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
  | -.0001 -.0012 -.0050 -.0050 -.0012 .0001 .0000 .0000 .0000 |
  | ***** CAS(2)- SERVICE LEVEL C ***** |
  | FORCE MAX. .000 |
  | FORCE MIN. .000 |
  | AXIAL SWING MAX/MIN: |
  | N/A = .0000, .0000 |
  | N/A = .0000, .0000 |
  | GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
  | .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
  | .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
  | ***** CAS(3)- SERVICE LEVEL D ***** |
  | FORCE MAX. 23907.820 |
  | FORCE MIN. -23907.820 |
  | AXIAL SWING MAX/MIN: |
  | COMP = .0945, .0218 |
  | TEN. = .0995, .0230 |
  | GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
  | .0049 .0212 .0945 .0947 .0222 .0049 .0000 .0000 .0000 |
  | .0050 -.0224 -.0995 -.0997 -.0235 -.0050 .0000 .0000 .0000 |
  | ***** CAS(4)- SERVICE LEVEL 3*B ***** |
  | FORCE MAX. .000 |
  | FORCE MIN. .000 |
  | AXIAL SWING MAX/MIN: |
  | N/A = .0000, .0000 |
  | N/A = .0000, .0000 |
  | GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
  | .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
  | .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
  | SUPTWIC 12: 47: 8.22 6/ 7/1988 PAGE 32 |
  
```

ATTACHMENT 2  
 PAGE 136 OF 143  
 CALC. NO. C-0031/TIRO

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUDDER REDUCTION . FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

NODE = H1B      SUPPORT 1 OF 1      (Trans. only)

PIPE DIRECTION COSINES: X = .0000, Y = .0104, Z = .9999

SUPPORT: 51      RIGID      | SUPPORT: 52      RIGID      |
TRAN. STIF. = .3410E+07      | TRAN. STIF. = .3410E+07      |
(X) (Y) (Z)      | (X) (Y) (Z)      |
DIRECTION COSINES:      | DIRECTION COSINES:      |
1.0000 .0000 .0000      | .0000 1.0000 .0000      |

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX.      166.040      | FORCE MAX.      .000      |
FORCE MIN.      .000      | FORCE MIN.     -1138.333      |
AXIAL SWING MAX/MIN:      | AXIAL SWING MAX/MIN:      |
N/A = .0000, .0000      | TEN = .0000, .0000      |
TEN = .0000, .0050      | TEN = .0003, .0050      |
GLOBAL DISPL. MAX/MIN:      | LOCAL DISPL. MAX/MIN:      | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000      | .0000 .0000 -.0000      | .0000 .0000 .0000
.0000 -.0003 -.0050      | -.0050 -.0003 .0000      | .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX.      .000      | FORCE MAX.      .000      |
FORCE MIN.      .000      | FORCE MIN.      .000      |
AXIAL SWING MAX/MIN:      | AXIAL SWING MAX/MIN:      |
N/A = .0000, .0000      | N/A = .0000, .0000      |
N/A = .0000, .0000      | N/A = .0000, .0000      |
GLOBAL DISPL. MAX/MIN:      | LOCAL DISPL. MAX/MIN:      | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000      | .0000 .0000 .0000      | .0000 .0000 .0000
.0000 .0000 .0000      | .0000 .0000 .0000      | .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX.      863.293      | FORCE MAX.     14380.260      |
FORCE MIN.     -697.253      | FORCE MIN.    -15518.590      |
AXIAL SWING MAX/MIN:      | AXIAL SWING MAX/MIN:      |
COMP = .0003, .0955      | COMP = .0042, .0934      |
TEN = .0002, .1006      | TEN = .0046, .1005      |
GLOBAL DISPL. MAX/MIN:      | LOCAL DISPL. MAX/MIN:      | GLOBAL ACCEL. MAX/MIN:
.0003 .0042 .0954      | .0955 .0052 .0003      | .0000 .0000 .0000
-.0002 -.0046 -.1005      | -.1005 -.0056 -.0002      | .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX.      .000      | FORCE MAX.      .000      |
FORCE MIN.      .000      | FORCE MIN.      .000      |
AXIAL SWING MAX/MIN:      | AXIAL SWING MAX/MIN:      |
N/A = .0000, .0000      | N/A = .0000, .0000      |
N/A = .0000, .0000      | N/A = .0000, .0000      |
GLOBAL DISPL. MAX/MIN:      | LOCAL DISPL. MAX/MIN:      | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000      | .0000 .0000 .0000      | .0000 .0000 .0000
.0000 .0000 .0000      | .0000 .0000 .0000      | .0000 .0000 .0000

SUPPORT: SUPTMVIC      12: 47: 8.22      6/ 7/1988      PAGE 33
    
```

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

ATTACHMENT 2  
 PAGE 137 OF 143  
 1 11/21/1988

NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005, 1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

MODE = 180BL SUPPORT 1 OF 2 (Trans only)
PIPE DIRECTION COSINES: X = .0000, Y = .0104, Z = .9999

SUPT: 33 RIGID | SUPT: 34 RIGID | SUPT: 35 RIGID
TRAN STIF. = .2600E+03 | TRAN STIF. = .1250E+04 | TRAN STIF. = .1250E+04
(X) (Y) (Z) | (X) (Y) (Z) | (X) (Y) (Z)
DIRECTION COSINES: | DIRECTION COSINES: | DIRECTION COSINES:
.0000 .0000 1.0000 | .0000 1.0000 .0000 | 1.0000 .0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000 | FORCE MAX. .739 | FORCE MAX. 1.248
FORCE MIN. -1.309 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
TEN. = .0000, .0012 | COMP = .0006, .0010 | COMP = .0010, .0006
TEN. = .0050, .0000 | TEN. = .0000, .0050 | TEN. = .0000, .0050
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0010 .0006 .0000 | .0000 .0006 -.0010 | .0000 .0000 .0000
.0000 .0000 -.0050 | -.0050 .0001 .0000 | .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. .000
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 25.095 | FORCE MAX. 54.223 | FORCE MAX. 18.724
FORCE MIN. -26.403 | FORCE MIN. -53.484 | FORCE MIN. -17.476
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
COMP = .0965, .0459 | COMP = .0434, .0977 | COMP = .0150, .1058
TEN. = .1016, .0450 | TEN. = .0428, .1025 | TEN. = .0140, .1102
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0150 .0434 .0965 | .0970 .0444 .0150 | .0000 .0000 .0000
-.0140 -.0428 -.1016 | -.1020 -.0438 -.0140 | .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3*B *****
FORCE MAX. .000 | FORCE MAX. .000 | FORCE MAX. .000
FORCE MIN. .000 | FORCE MIN. .000 | FORCE MIN. .000
AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN: | AXIAL SWING MAX/MIN:
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
N/A = .0000, .0000 | N/A = .0000, .0000 | N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: | LOCAL DISPL. MAX/MIN: | GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000
.0000 .0000 .0000 | .0000 .0000 .0000 | .0000 .0000 .0000

SUPTMVIC 12: 47: B 22 6/ 7/1988 PAGE 34
  
```

ATTACHMENT 21  
 PAGE 138 OF 143  
 CALC. NO. C-0031 / TRD

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005 1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

NODE = 180BL SUPPORT 2 OF 2			(Rotation only)		
PIPE DIRECTION COSINES: X = .0000, Y = .0104, Z = .9999					
SUPT: 56 RIGID	SUPT: 57 RIGID	SUPT: 58 RIGID			
ROD. STIF. = .5130E+05	ROD. STIF. = .5130E+05	ROD. STIF. = .5130E+05			
(X) (Y) (Z)	(X) (Y) (Z)	(X) (Y) (Z)			
DIRECTION COSINES:		DIRECTION COSINES:		DIRECTION COSINES:	
.0000 .0000 1.0000	.0000 1.0000 .0000	1.0000 .0000 .0000			
***** CAS(1)- SERVICE LEVEL B *****					
MOMT. MAX. 5.350	MOMT. MAX. 1.253	MOMT. MAX. .000			
MOMT. MIN. .000	MOMT. MIN. .000	MOMT. MIN. -.199			
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.0010 .0006 .0000	.0000 .0006 -.0010	.0000 .0000 .0000			
.0000 .0000 -.0050	-.0050 .0001 .0000	.0000 .0000 .0000			
***** CAS(2)- SERVICE LEVEL C *****					
MOMT. MAX. .000	MOMT. MAX. .000	MOMT. MAX. .000			
MOMT. MIN. .000	MOMT. MIN. .000	MOMT. MIN. .000			
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.0000 .0000 .0000	.0000 .0000 .0000	.0000 .0000 .0000			
.0000 .0000 .0000	.0000 .0000 .0000	.0000 .0000 .0000			
***** CAS(3)- SERVICE LEVEL D *****					
MOMT. MAX. 11.706	MOMT. MAX. 14.330	MOMT. MAX. 25.569			
MOMT. MIN. -6.356	MOMT. MIN. -13.077	MOMT. MIN. -25.768			
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.0150 .0434 .0965	.0970 .0444 .0150	.0000 .0000 .0000			
-.0140 -.0428 -.1016	-.1020 -.0438 -.0140	.0000 .0000 .0000			
***** CAS(4)- SERVICE LEVEL 3*B *****					
MOMT. MAX. .000	MOMT. MAX. .000	MOMT. MAX. .000			
MOMT. MIN. .000	MOMT. MIN. .000	MOMT. MIN. .000			
GLOBAL DISPL. MAX/MIN:		LOCAL DISPL. MAX/MIN:		GLOBAL ACCEL. MAX/MIN:	
.0000 .0000 .0000	.0000 .0000 .0000	.0000 .0000 .0000			
.0000 .0000 .0000	.0000 .0000 .0000	.0000 .0000 .0000			
SUPTMVIC	12: 47: 8.22	6/ 7/1988	PAGE 35		

ATTACHMENT 2  
 PAGE 39 OF 143  
 CALC. NO. C-0031/TIRD

NUTECH ENGINEERS

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBER  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

NODE = H30      SUPPORT 1 OF 1      (Trans. only)
PIPE DIRECTION COSINES: X = .0000, Y = .0104, Z = .9997

SUPT: 59      RIGID
TRAN STIF. = .8340E+06
(X) (Y) (Z)
DIRECTION COSINES:
.0000 1.0000 .0000

***** CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. -2154.021
AXIAL SWING MAX/MIN:
TEN. = .0000, .0038
TEN. = .0026, .0050
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0038 .0000 .0000 .0000 .0000 -.0038 .0000 .0000 .0000
.0000 -.0026 -.0050 -.0050 -.0025 .0000 .0000 .0000 .0000

***** CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

***** CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 49865.160
FORCE MIN. -32019.180
AXIAL SWING MAX/MIN:
COMP = .0598, .1031
TEN. = .0624, .1057
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0341 .0598 .0973 .0979 .0608 .0341 .0000 .0000 .0000
-.0303 -.0624 -.1023 -.1029 -.0634 -.0303 .0000 .0000 .0000

***** CAS(4)- SERVICE LEVEL 3=B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPTMVIC      12:47: 8.22      6/ 7/1988      PAGE 36
  
```

ATTACHMENT  
 PAGE 140 OF 143  
 CASE NO C-0031/TIR0

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUDDER REDUCTION FILE NUMBERS  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE009.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

NODE = H50      SUPPORT 1 OF 1      (Trans. only)

PIPE DIRECTION COSINES: X = .0000, Y = 1.0000, Z = .0000

SUPT: 60      RIGID
TRAN STIF. = .3850E+06
(X) (Y) (Z)
DIRECTION COSINES:
.5210 .0000 -.8535

*****
CAS(1)- SERVICE LEVEL B *****
FORCE MAX. .000
FORCE MIN. -47.775
AXIAL SWING MAX/MIN:
TEN = .0001, .0001
TEN = .0000, .0090
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0001 .0000 .0001 .0000 .0000 .0000 .0000
.0000 -.0090 .0000 -.0090 .0000 .0000 .0000 .0000 .0000

*****
CAS(2)- SERVICE LEVEL C *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

*****
CAS(3)- SERVICE LEVEL D *****
FORCE MAX. 2595.078
FORCE MIN. -2642.853
AXIAL SWING MAX/MIN:
TEN = .0134, .2517
CUMP = .0132, .2607
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0086 .2517 .0104 .2517 .0104 .0086 .0000 .0000 .0000
-.0086 -.2607 -.0103 -.2607 -.0103 -.0086 .0000 .0000 .0000

*****
CAS(4)- SERVICE LEVEL J+B *****
FORCE MAX. .000
FORCE MIN. .000
AXIAL SWING MAX/MIN:
N/A = .0000, .0000
N/A = .0000, .0000
GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN:
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000
.0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000

SUPPORT 12: 47: 8.22 6/ 7/1988 PAGE 37
    
```

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

ATTACHMENT  
 PAGE 14 OF 143  
 CALC. NO. C-0031 / TIRD

NUTECH ENGINEERS  
PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS \_\_\_\_\_  
 OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
 CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

```

+-----+
| NODE = H4B      SUPPORT 1 OF 1                      (Trans. only) |
| PIPE DIRECTION COSINES: X = .0000, Y = 1.0000, Z = .0000 |
| SUPT: 61      RIGID |
| TRAN. STIF. = .5160E+06 |
| (X) (Y) (Z) |
| DIRECTION COSINES: |
| .6264 .0000 -.7795 |
| ***** CAS(1)- SERVICE LEVEL B ***** |
| FORCE MAX. .000 |
| FORCE MIN. -65.655 |
| AXIAL SWING MAX/MIN: |
| TEN. = .0001, .0000 |
| TEN. = .0001, .0090 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0000 .0000 .0001 .0000 .0001 .0000 .0000 .0000 .0000 |
| -.0001 -.0090 .0000 -.0090 .0000 -.0001 .0000 .0000 .0000 |
| ***** CAS(2)- SERVICE LEVEL C ***** |
| FORCE MAX. .000 |
| FORCE MIN. .000 |
| AXIAL SWING MAX/MIN: |
| N/A = .0000, .0000 |
| N/A = .0000, .0000 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| ***** CAS(3)- SERVICE LEVEL D ***** |
| FORCE MAX. 2931.515 |
| FORCE MIN. -3017.169 |
| AXIAL SWING MAX/MIN: |
| COMP = .0012, .2523 |
| TEN. = .0013, .2613 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0083 .2521 .0051 .2521 .0051 .0083 .0000 .0000 .0000 |
| -.0084 -.2611 -.0050 -.2611 -.0050 -.0084 .0000 .0000 .0000 |
| ***** CAS(4)- SERVICE LEVEL 3*B ***** |
| FORCE MAX. .000 |
| FORCE MIN. .000 |
| AXIAL SWING MAX/MIN: |
| N/A = .0000, .0000 |
| N/A = .0000, .0000 |
| GLOBAL DISPL. MAX/MIN: LOCAL DISPL. MAX/MIN: GLOBAL ACCEL. MAX/MIN: |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 .0000 |
| SUPTMVIC 12:47: 8.22 6/ 7/1988 PAGE 38 |
+-----+
  
```

ATTACHMENT  
 PAGE 142 OF 143  
 CALC. NO. C-0081/TIRD

N-UTECH ENGINEERS

PIPE SUPPORT LOAD COMB. RUP-DISK ANALYSIS P201

PROJECT: HOPE CREEK SNUBBER REDUCTION FILE NUMBERS  
OWNER: PUBLIC SERVICE ELECTRIC AND GAS COMPANY CALC. (C-31) PSE005.1016  
CLIENT: PUBLIC SERVICE ELECTRIC AND GAS COMPANY COMP. ADCE

OUTPUT SAVED IN FILE : P201RUP.SUP  
NORMAL COMPLETION AT 12:48:17.75 6/ 7/1988

SUPTMVIC

12: 47: 8.22

6/ 7/1988

PAGE 39

ATTACHMENT 2  
PAGE 143 OF 143  
CALC. NO. C-0031/TIKO





CALCULATION  
CONTINUATION SHEET

TITLE		ID NO. <u>HG-1-P-FD-201</u>	SHEET  OF
		REFERENCE <u>C-31, REV. 7</u>	
ORIGINATOR	<u>RKS</u>		
DATE	<u>1/25/93</u>		
VFR <del>or</del> GKR	<u>Jdk</u>		
DATE	<u>2-16-'93</u>		

DECOUPLED BRANCH CONNECTION DISPLACEMENT EVALUATION(S)

The following displacements were tabulated for review of impact upon associated calculations. Assessments as to the impact are given at the bottom of this sheet.

DATA POINT 145 CP HEADER CALCULATION C-31 CURRENT REVISION 7  
 DATA POINT \_\_\_\_\_ BRANCH CALCULATION \_\_\_\_\_ CURRENT REVISION \_\_\_\_\_  
 (check calculation which is being worked)

LOADCASE <u>THERMAL</u>	NOTE: Displacements in inches , rotations in radians.					
	DX	DY	DZ	RX	RY	RZ
OLD	<u>-0.02</u>	<u>-0.012</u>	<u>0.021</u>	_____	_____	_____
NEW	<u>-0.002</u>	<u>-0.045</u>	<u>0.054</u>	_____	_____	_____

LOADCASE <u>SAMOB</u>	NOTE: Displacements in inches , rotations in radians.					
	DX	DY	DZ	RX	RY	RZ
OLD	<u>0.001</u>	<u>0.0</u>	<u>0.0</u>	_____	_____	_____
NEW	<u>0.001</u>	<u>0.0</u>	<u>0.0</u>	_____	_____	_____

LOADCASE <u>SAMSS</u>	NOTE: Displacements in inches , rotations in radians.					
	DX	DY	DZ	RX	RY	RZ
OLD	<u>0.001</u>	<u>0.0</u>	<u>0.0</u>	_____	_____	_____
NEW	<u>0.015</u>	<u>0.001</u>	<u>0.01</u>	_____	_____	_____

LOADCASE _____	NOTE: Displacements in inches , rotations in radians.					
	DX	DY	DZ	RX	RY	RZ
OLD	_____	_____	_____	_____	_____	_____
NEW	_____	_____	_____	_____	_____	_____

CONCLUSIONS:  BASED UPON MINIMAL INCREASE/ACTUAL DISPLACEMENTS , NO IMPACT TO BRANCH CALCULATIONS.

[ ]

ATTACHMENT 3  
 PAGE 1 OF 5  
 CALC. NO. C-0031/7IRQ



CALCULATION CONTINUATION SHEET

TITLE		ID NO. <u>HG-1-P-FD-204</u>	SHEET
		REFERENCE <u>C-31, REV. 7</u>	
ORIGINATOR	<u>PKS</u>		OF
DATE	<u>1/25/93</u>		
VFR or CKR	<u>HK</u>		
DATE	<u>3-16-93</u>		

DECOUPLED BRANCH CONNECTION DISPLACEMENT EVALUATION(S)

The following displacements were tabulated for review of impact upon associated calculations. Assessments as to the impact are given at the bottom of this sheet.

DATA POINT 163 HEADER CALCULATION C-31 CURRENT REVISION 7  
 DATA POINT \_\_\_\_\_ BRANCH CALCULATION \_\_\_\_\_ CURRENT REVISION \_\_\_\_\_  
 (check calculation which is being worked)

LOADCASE	<u>THERMAL</u>					
	NOTE: Displacements in inches , rotations in radians.					
	DX	DY	DZ	RX	RY	RZ
OLD	<u>0.0052</u>	<u>-0.0879</u>	<u>0.2393</u>	_____	_____	_____
NEW	<u>0.011</u>	<u>-0.035</u>	<u>-0.212</u>	_____	_____	_____

LOADCASE	<u>SAMOB</u>					
	NOTE: Displacements in inches , rotations in radians.					
	DX	DY	DZ	RX	RY	RZ
OLD	<u>0.044</u>	<u>0.039</u>	<u>0.0122</u>	_____	_____	_____
NEW	<u>0.036</u>	<u>0.015</u>	<u>0.011</u>	_____	_____	_____

LOADCASE	<u>SAMSS</u>					
	NOTE: Displacements in inches , rotations in radians.					
	DX	DY	DZ	RX	RY	RZ
OLD	<u>0.041</u>	<u>0.0281</u>	<u>0.0224</u>	_____	_____	_____
NEW	<u>0.05</u>	<u>0.018</u>	<u>0.023</u>	_____	_____	_____

LOADCASE	_____					
	NOTE: Displacements in inches , rotations in radians.					
	DX	DY	DZ	RX	RY	RZ
OLD	_____	_____	_____	_____	_____	_____
NEW	_____	_____	_____	_____	_____	_____

CONCLUSIONS:  BASED UPON MINIMAL INCREASE/ACTUAL DISPLACEMENTS , NO IMPACT TO BRANCH CALCULATIONS.

[ ]

ATTACHMENT 3  
 PAGE 2 OF 5  
 CALC. NO. C-0031/7IRP



CALCULATION  
CONTINUATION SHEET

TITLE

ID NO.

HG-1-P-FD-207

SHEET

REFERENCE

C-31, REV. 7

OF

ORIGINATOR

BKS

DATE

1/25/93

VFR or GKR

JLK

DATE

3-16-93

DECOUPLED BRANCH CONNECTION DISPLACEMENT EVALUATION(S)

The following displacements were tabulated for review of impact upon associated calculations. Assessments as to the impact are given at the bottom of this sheet.

- DATA POINT 145CP HEADER CALCULATION C-31 CURRENT REVISION 7  
 DATA POINT \_\_\_\_\_ BRANCH CALCULATION \_\_\_\_\_ CURRENT REVISION \_\_\_\_\_  
 (check calculation which is being worked)

LOADCASE THERMAL

NOTE: Displacements in inches, rotations in radians.

	DX	DY	DZ	RX	RY	RZ
OLD	-0.02	-0.012	0.021	_____	_____	_____
NEW	-0.002	-0.045	0.054	_____	_____	_____

LOADCASE SAMOB

NOTE: Displacements in inches, rotations in radians.

	DX	DY	DZ	RX	RY	RZ
OLD	0.001	0.0	0.0	_____	_____	_____
NEW	0.001	0.0	0.0	_____	_____	_____

LOADCASE SAMSS

NOTE: Displacements in inches, rotations in radians.

	DX	DY	DZ	RX	RY	RZ
OLD	0.001	0.0	0.0	_____	_____	_____
NEW	0.015	0.001	0.01	_____	_____	_____

LOADCASE \_\_\_\_\_

NOTE: Displacements in inches, rotations in radians.

	DX	DY	DZ	RX	RY	RZ
OLD	_____	_____	_____	_____	_____	_____
NEW	_____	_____	_____	_____	_____	_____

CONCLUSIONS:  BASED UPON MINIMAL INCREASE/ACTUAL DISPLACEMENTS, NO IMPACT TO BRANCH CALCULATIONS.

{ }

ATTACHMENT 3

PAGE 3 OF 5

CALC. NO. C-0031/7IRP



CALCULATION CONTINUATION SHEET

TITLE		ID NO. <u>HG-1-P-FD-208</u>				SHEET OF
		REFERENCE <u>C-31, REV.7</u>				
ORIGINATOR	<u>RWS</u>					
DATE	<u>1/25/93</u>					
VFR or EKR	<u>JJK</u>					
DATE	<u>2-16-93</u>					

DECOUPLED BRANCH CONNECTION DISPLACEMENT EVALUATION(S)

The following displacements were tabulated for review of impact upon associated calculations. Assessments as to the impact are given at the bottom of this sheet.

- DATA POINT 145CP HEADER CALCULATION C-31 CURRENT REVISION 7  
 DATA POINT \_\_\_\_\_ BRANCH CALCULATION \_\_\_\_\_ CURRENT REVISION \_\_\_\_\_  
 (check calculation which is being worked)

LOADCASE THERMAL NOTE: Displacements in inches , rotations in radians.

	DX	DY	DZ	RX	RY	RZ
OLD	<u>-0.02</u>	<u>-0.012</u>	<u>0.021</u>	_____	_____	_____
NEW	<u>-0.002</u>	<u>-0.045</u>	<u>0.054</u>	_____	_____	_____

LOADCASE SAMOB NOTE: Displacements in inches , rotations in radians.

	DX	DY	DZ	RX	RY	RZ
OLD	<u>0.001</u>	<u>0.0</u>	<u>0.0</u>	_____	_____	_____
NEW	<u>0.001</u>	<u>0.0</u>	<u>0.0</u>	_____	_____	_____

LOADCASE SAMSS NOTE: Displacements in inches , rotations in radians.

	DX	DY	DZ	RX	RY	RZ
OLD	<u>0.001</u>	<u>0.0</u>	<u>0.0</u>	_____	_____	_____
NEW	<u>0.015</u>	<u>0.001</u>	<u>0.01</u>	_____	_____	_____

LOADCASE \_\_\_\_\_ NOTE: Displacements in inches , rotations in radians.

	DX	DY	DZ	RX	RY	RZ
OLD	_____	_____	_____	_____	_____	_____
NEW	_____	_____	_____	_____	_____	_____

CONCLUSIONS:  BASED UPON MINIMAL INCREASE/ACTUAL DISPLACEMENTS , NO IMPACT TO BRANCH CALCULATIONS.

[ ]

ATTACHMENT 3  
 PAGE 4 OF 5  
 CALC. NO. C-0031/71RQ



**PSEG**

CALCULATION  
CONTINUATION SHEET

TITLE		ID NO. <u>HG-1-P-FD-234</u>	SHEET  OF
		REFERENCE <u>C-31, REV. 7</u>	
ORIGINATOR	<u>SKS</u>		
DATE	<u>1/25/93</u>		
VFR <del>SKR</del>	<u>SKS</u>		
DATE	<u>2-16-93</u>		

DECOUPLED BRANCH CONNECTION DISPLACEMENT EVALUATION(S)

The following displacements were tabulated for review of impact upon associated calculations. Assessments as to the impact are given at the bottom of this sheet.

- DATA POINT 145CP HEADER CALCULATION C-31 CURRENT REVISION 7  
 DATA POINT \_\_\_\_\_ BRANCH CALCULATION \_\_\_\_\_ CURRENT REVISION \_\_\_\_\_  
 (check calculation which is being worked)

LOADCASE	<u>THERMAL</u>					
	NOTE: Displacements in inches , rotations in radians.					
	DX	DY	DZ	RX	RY	RZ
OLD	<u>-0.02</u>	<u>-0.012</u>	<u>0.021</u>	_____	_____	_____
NEW	<u>-0.002</u>	<u>-0.045</u>	<u>0.054</u>	_____	_____	_____

LOADCASE	<u>SAMOB</u>					
	NOTE: Displacements in inches , rotations in radians.					
	DX	DY	DZ	RX	RY	RZ
OLD	<u>0.001</u>	<u>0.0</u>	<u>0.0</u>	_____	_____	_____
NEW	<u>0.001</u>	<u>0.0</u>	<u>0.0</u>	_____	_____	_____

LOADCASE	<u>SAMSS</u>					
	NOTE: Displacements in inches , rotations in radians.					
	DX	DY	DZ	RX	RY	RZ
OLD	<u>0.001</u>	<u>0.0</u>	<u>0.0</u>	_____	_____	_____
NEW	<u>0.015</u>	<u>0.001</u>	<u>0.01</u>	_____	_____	_____

LOADCASE	_____					
	NOTE: Displacements in inches , rotations in radians.					
	DX	DY	DZ	RX	RY	RZ
OLD	_____	_____	_____	_____	_____	_____
NEW	_____	_____	_____	_____	_____	_____

CONCLUSIONS:  BASED UPON MINIMAL INCREASE/ACTUAL DISPLACEMENTS , NO IMPACT TO BRANCH CALCULATIONS.

{ }

ATTACHMENT 3  
 PAGE 5 OF 5  
 CALC. NO. C-0031/7IRP

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

Project: XPS-05

System: LBP P-201 (C-31)

Hope Creek TAP Records Retention

Document Number	Title or Subject	Revision or Date	File Number	Classif. L/NP	D. I. Y/N	Outgoing		Responsible PE Approval	Date
						Tech. Doc. Y/N			
PSE005.0010	Generic Design Input Log/ Records Index	7	PSE005.0010	NP	N	Y		AM for ASH	8/28/89
<u>Bechtel Documents for LBP P-201</u>									
--	PUA Calculation Review Comments	8/16/85	XBP006.0102	NP	Y	N		ASH	1/30/88
<u>Pipe Support Drawings (On Aperture Cards)</u>									
1-P-FD-006-H01(Q)	Hanger H01 Details	5	PSE005.0020	L	Y	N		ASH	1/30/88
1-P-FD-006-H02(Q)	Hanger H02 Details	4	PSE005.0020	L	Y	N		ASH	1/30/88
1-P-FD-006-H03(Q)	Hanger H03 Details (Shts 1 & 2)	5	PSE005.0020	L	Y	N		ASH	1/30/88
1-P-FD-006-H04(Q)	Hanger H04 Details	3	PSE005.0020	L	Y	N		ASH	1/30/88
1-P-FD-006-H05(Q)	Hanger H05 Details	2	PSE005.0020	L	Y	N		ASH	1/30/88
1-P-FD-006-H06(Q)	Hanger H06 Details	5	PSE005.0020	L	Y	N		ASH	1/30/88
1-P-FD-006-H07(Q)	Hanger H07 Details	4	PSE005.0020	L	Y	N		ASH	1/30/88
1-P-FD-006-H08(Q)	Hanger H08 Details	4	PSE005.0020	L	Y	N		ASH	1/30/88
1-P-FD-006-H09(Q)	Hanger H09 Details	3	PSE005.0020	L	Y	N		ASH	1/30/88
1-P-FD-006-H10(Q)	Hanger H10 Details (Shts 1,2, & 3)	3	PSE005.0020	L	Y	N		ASH	1/30/88
1-P-FD-006-H11(Q)	Hanger H11 Details	1	PSE005.0020	L	Y	N		ASH	1/30/88
1-P-FD-006-H12(Q)	Hanger H12 Details (Shts 1 & 2)	1	PSE005.0020	L	Y	N		ASH	1/30/88
1-P-FD-006-H13(Q)	Hanger H13 Details (Shts 1 & 2)	6	PSE005.0020	L	Y	N		ASH	1/30/88

ATTACHMENT 4

PAGE 1 OF 7

CALC. NO. C-0031/TIRP

\* Asterisk Designates Preliminary Input  
P-201

Project: XPS-05

System: LBP P-201 (C-31)

Hope Creek TAP Records Retention

Document Number	Title or Subject	Revision or Date	File Number	Classif. L/NP	D. I. Y/N	Outgoing		Responsible PE Approval	Date
						Tech. Doc. Y/N			
<u>Pipe Support Drawings (On Aperture Cards)</u>									
1-P-FD-006-H14(Q)	Hanger H14 Details (Shts 1, 2 & 3)	2	PSE005,0020	L	Y	N		ASH	1/30/88
1-P-FD-006-H15(Q)	Hanger H15 Details (Shts 1 & 2)	2	PSE005,0020	L	Y	N		ASH	1/30/88
1-P-FD-006-H17(Q)	Hanger H17 Details (Shts 1 & 2)	1	PSE005,0020	L	Y	N		ASH	1/30/88
1-P-FD-006-H18(Q)	Hanger H18 Details (Shts 1 & 2)	2	PSE005,0020	L	Y	N		ASH	1/30/88
1-P-FD-006-H19(Q)	Hanger H19 Details (Shts 1 & 2)	3	PSE005,0020	L	Y	N		ASH	1/30/88
1-P-FD-006-H22(Q)	Hanger H22 Details (Shts 1 & 2)	1	PSE005,0020	L	Y	N		ASH	1/30/88
1-P-FD-014-H01(Q)	Hanger H01 Details	2	PSE005,0020	L	Y	N		ASH	1/30/88
1-P-FD-014-H02(Q)	Hanger H02 Details (Shts 1, 2 & 3)	2	PSE005,0020	L	Y	N		ASH	1/30/88
1-P-FD-014-H03(Q)	Hanger H03 Details (Shts 1,2,3&4)	2	PSE005,0020	L	Y	N		ASH	1/30/88
1-P-FD-014-H04(Q)	Hanger H04 Details	2	PSE005,0020	L	Y	N		ASH	1/30/88
1-P-FD-014-H05(Q)	Hanger H05 Details	2	PSE005,0020	L	Y	N		ASH	1/30/88

Piping Isometric (On Aperture Card)

1-P-FD-01(Q)	Pipe Isometric	21	PSE005,0019	L	Y	N		ASH	1/30/88
--------------	----------------	----	-------------	---	---	---	--	-----	---------

Valve Drawings

10855-P301(Q)-347-5	Anchor/Darling Valve Co. 20"-150 Weld Ends w/SMB-0-25 Limitorque Operator	C	PSE005,0016	L	Y	N		ASH	1/30/88
10855-P301(Q)-305-4	Anchor/Darling Valve Co. 20"-150 Swing Check Valve	C	PSE005,0016	L	Y	N		ASH	1/30/88

ATTACHMENT 4

PAGE 2 OF 7

CALC. NO. C-0031/7520

\* Asterisk Designates Preliminary Input  
P-201

Project: XPS-05

System: LBP P-201 (C-31)

Hope Creek TAP Records Retention

Document Number	Title or Subject	Revision or Date	File Number	Classif. L/NP	D. I. Y/N	Outgoing		Responsible PE Approval	Date
						Tech. Doc. Y/N			
<u>Pipe Support Calculation (On Microfiche)</u>									
1-P-FD-006-C015	Hanger H01 Design Calculation	1	PSE005.1015	L	Y	N		ASH	1/30/88
1-P-FD-006-C015	Hanger H02 Design Calculation	1	PSE005.1015	L	Y	N		ASH	1/30/88
1-P-FD-006-C016	Hanger H03 Design Calculation	0	PSE005.1015	L	Y	N		ASH	1/30/88
1-P-FD-006-C017	Hanger H04 Design Calculation	0	PSE005.1015	L	Y	N		ASH	1/30/88
1-P-FD-006-C018	Hanger H05 Design Calculation	0	PSE005.1015	L	Y	N		ASH	1/30/88
1-P-FD-006-C011	Hanger H06 Design Calculation	1	PSE005.1015	L	Y	N		ASH	1/30/88
1-P-FD-006-C019	Hanger H07 Design Calculation	0	PSE005.1015	L	Y	N		ASH	1/30/88
1-P-FD-006-C020	Hanger H08 Design Calculation	0	PSE005.1015	L	Y	N		ASH	1/30/88
1-P-FD-006-C012	Hanger H09 Design Calculation	1	PSE005.1015	L	Y	N		ASH	1/30/88
1-P-FD-006-C014	Hanger H10 Design Calculation	1	PSE005.1015	L	Y	N		ASH	1/30/88
1-P-FD-006-C002	Hanger H11 Design Calculation	2	PSE005.1015	L	Y	N		ASH	1/30/88
1-P-FD-006-C009	Hanger H12 Design Calculation	1	PSE005.1015	L	Y	N		ASH	1/30/88
1-P-FD-006-C007	Hanger H13 Design Calculation	2	PSE005.1015	L	Y	N		ASH	1/30/88
1-P-FD-006-C008	Hanger H14 Design Calculation	2	PSE005.1015	L	Y	N		ASH	1/30/88

ATTACHMENT 4  
PAGE 3 OF 7  
CALC. NO. C-0031/71RD



Project: XPS-05

System: LBP P-201 (C-31)

Hope Creek TAP Records Retention

Document Number	Title or Subject	Revision or Date	File Number	Classif. L/NP	D. I. Y/N	Outgoing		Responsible PE Approval	Date
						Tech. Doc. Y/N			
<u>Pipe Support Calculation (On Microfiche)</u>									
1-P-FD-006-C007	Hanger H15 Design Calculation	2	PSE005.1015	L	Y	N		ASH	1/30/88
1-P-FD-006-C008	Hanger H17 Design Calculation	2	PSE005.1015	L	Y	N		ASH	1/30/88
1-P-FD-006-C007	Hanger H18 Design Calculation	2	PSE005.1015	L	Y	N		ASH	1/30/88
1-P-FD-006-C006	Hanger H19 Design Calculation	2	PSE005.1015	L	Y	N		ASH	1/30/88
1-P-FD-006-C010	Hanger H22 Design Calculation	1	PSE005.1015	L	Y	N		ASH	1/30/88
1-P-FD-014-C001	Hanger H01 Design Calculation	2	PSE005.1015	L	Y	N		ASH	1/30/88
1-P-FD-014-C003	Hanger H02 Design Calculation	3	PSE005.1015	L	Y	N		ASH	1/30/88
1-P-FD-014-C004	Hanger H03 Design Calculation	1	PSE005.1015	L	Y	N		ASH	1/30/88
1-P-FD-014-C005	Hanger H04 Design Calculation	1	PSE005.1015	L	Y	N		ASH	1/30/88
1-P-FD-014-C006	Hanger H05 Design Calculation	1	PSE005.1015	L	Y	N		ASH	1/30/88
<u>Piping Calculation</u>									
C-31	LBP P-201 Piping Calculation	6	PSE005.1016	L	Y	N		ASH	1/30/88
SCF-31	Post Phase 2 Piping Calculation	1	PSE005.1016	L	Y	N		ASH	1/30/88
N/A	Hanger Guidance Issue # 5	11/26/86	PSE005.1016	L	Y	N		ASH	1/30/88

ATTACHMENT 4  
 PAGE 4 OF 7  
 CALC. NO. C-0031/7100

Project: XPS-05

System: LBP P-201 (C-31)

Hope Creek TAP Records Retention

Document Number	Title or Subject	Revision or Date	File Number	Classif. L/NP	D. I. Y/N	Outgoing		Responsible PE Approval	Date
						Tech. Doc. Y/N			
<u>SB Branch Pipe Documents</u>									
1-P-FD-201	SBP Isometric	5	PSE005.0019	L	Y	N		ASH	6/24/88
1-P-FD-204	SBP Isometric	2	PSE005.0019	L	Y	N		ASH	6/24/88
1-P-FD-207	SBP Isometric	5	PSE005.0019	L	Y	N		ASH	6/24/88
1-P-FD-208	SBP Isometric	5	PSE005.0019	L	Y	N		ASH	6/24/88
1-P-FD-211	SBP Isometric	9	PSE005.0019	L	Y	N		ASH	6/24/88
1-P-FD-234	SBP Isometric	4	PSE005.0019	L	Y	N		ASH	6/24/88
FSK-P-1-FD-600	SBP Sketch for PT-N056E	6	PSE005.0019	L	Y	N		ASH	6/24/88
FSK-P-1-FD-601	SBP Sketch for PT-N056A	8	PSE005.0019	L	Y	N		ASH	6/24/88
<u>Outgoing Documents</u>									
--	Document and Interface Requirement Summary	0	PSE005.1017	NP	N	Y		N/A	1/27/89**
1-P-FD-01	Isometric Drawing	21	PSE005.1016	NP	N	Y		N/A	1/27/89**
1-P-FD-006-H02	Hanger Drawing	4	PSE005.1016	NP	N	Y		N/A	1/27/89**
1-P-FD-006-H03	Hanger Drawing	5	PSE005.1016	NP	N	Y		N/A	1/27/89**
1-P-FD-006-H05	Hanger Drawing	2	PSE005.1016	NP	N	Y		N/A	1/27/89**

ATTACHMENT 4

PAGE 5 OF 7

CALC. NO. C-0031/7IR0

\* Asterisk Designates Preliminary Input  
\*\* Date of Document Transmittal to PSE&G  
P-201



USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

Project: XPS-05

System: LBP P-201 (C-31)

Hope Creek TAP Records Retention

Document Number	Title or Subject	Revision or Date	File Number	Classif. L/NP	D. I. Y/N	Outgoing	Responsible PE Approval	Date
						Tech. Doc. Y/N		
<u>Outgoing Documents (Continued)</u>								
1-P-FD-006-C007	Hanger H13 Design Calculation	P31	PSE005.1015	NP	N	Y	N/A	1/27/89**
1-P-FD-006-C008	Hanger H14 Design Calculation	P31	PSE005.1015	NP	N	Y	N/A	1/27/89**
1-P-FD-006-C007	Hanger H15 Design Calculation	P31	PSE005.1015	NP	N	Y	N/A	1/27/89**
1-P-FD-006-C008	Hanger H17 Design Calculation	P31	PSE005.1015	NP	N	Y	N/A	1/27/89**
1-P-FD-006-C007	Hanger H18 Design Calculation	P31	PSE005.1015	NP	N	Y	N/A	1/27/89**
1-P-FD-006-C006	Hanger H19 Design Calculation	P41	PSE005.1015	NP	N	Y	N/A	1/27/89**
1-P-FD-006-C010	Hanger H22 Design Calculation	P21-1	PSE005.1015	NP	N	Y	N/A	1/27/89**
1-P-FD-014-C001	Hanger H01 Design Calculation	P31	PSE005.1015	NP	N	Y	N/A	1/27/89**
1-P-FD-014-C003	Hanger H02 Design Calculation	P41	PSE005.1015	NP	N	Y	N/A	1/27/89**
1-P-FD-014-C004	Hanger H03 Design Calculation	P21	PSE005.1015	NP	N	Y	N/A	1/27/89**
1-P-FD-014-C005	Hanger H04 Design Calculation	P21	PSE005.1015	NP	N	Y	N/A	1/27/89**
1-P-FD-014-C006	Hanger H05 Design Calculation	P21	PSE005.1015	NP	N	Y	N/A	1/27/89**
<u>Piping Calculation Outgoing</u>								
C-31	LBP P-201 Piping Calculation	P71	PSE005.1016	NP	N	Y	N/A	1/27/89**
N/A	Hanger Guidance Issue #5	P61	PSE005.1016	NP	N	Y	N/A	1/27/89**

ATTACHMENT 4

\* Asterisk Designates Preliminary Input  
 \*\* Date of Document Transmittal to PSE&G  
 P-201

PAGE 7 OF 7  
 CALC. NO. C-0031/71R0

# FILE COPY

HOPE CREEK GENERATION STATION -  
UNIT 1  
TORUS ATTACHED PIPING SNUBBER REDUCTION PROJECT  
DCP NUMBER: 4-EC-1021

## DOCUMENTATION AND INTERFACE REQUIREMENTS SUMMARY.

SYSTEM: HPCI Turbine Exhaust TORUS PENETRATION NO.: P-201

-----  
CONTENTS:

This document contains the following information related to this system:

- Attachment 1 - Snubber Reduction Summary
  - Attachment 2 - List of Calculations
  - Attachment 3 - List of Operational Design Change Notices
  - Attachment 4 - Interface Requirements
- 

NUTECH Approvals:

PSE&G Approvals:

ROD p. ASH / 7.22.88  
Project Engineer - Piping

\_\_\_\_\_

TW Soo Hoo 6/30/88  
Project Engineer - Pipe Supports

\_\_\_\_\_

Robert J. Quinn / 7.22.88  
Project Engineer - Structures

\_\_\_\_\_

ATTACHMENT 5  
PAGE 1 OF 12  
CALC. NO. C-0031/7IRQ

SNUBBER REDUCTION SUMMARY

The following provides a summary of the results of the snubber  
reduction effort on this system:

SNUBBERS REMOVED: 8

SUPPORT NO.

1-P-FD-006-H10  
1-P-FD-006-H09  
1-P-FD-006-H07 (Pair)  
1-P-FD-006-H05 (Pair)  
1-P-FD-006-H03  
1-P-FD-006-H02

SNUBBERS REPLACED: 0

SUPPORT NO.

None

NUMBER OF SNUBBERS REMAINING: 6

PSE005.1017  
Revision 0

ATTACHMENT 5  
PAGE 2 OF 12  
CALC. NO. C-0031/7190

LIST OF CALCULATIONS

The following calculations document the snubber reduction analysis performed for this system.

**A. PIPING CALCULATIONS**

<u>CD NO.*</u>	<u>CALC. NO.</u>	<u>CALCULATION TITLE</u>	<u>REV.</u>
	C-31	Piping Code Compliance Documentation System P-201	P7I

**B. HANGER GUIDANCE PACKAGES**

<u>CD NO.*</u>	<u>CALC. NO.</u>	<u>CALCULATION TITLE</u>	<u>REV.</u>
	C-31-HG	Piping Code Compliance Documentation System P-201 - Hanger Guidance Package	P6I

**C. PIPE SUPPORT CALCULATIONS**

<u>CD NO.*</u>	<u>CALCULATION NOS.</u>	<u>REV.</u>
	1-P-FD-006-C002	P3I
	1-P-FD-006-C006	P4I
	1-P-FD-006-C007	P3I
	1-P-FD-006-C008	P3I
	1-P-FD-006-C009	P2I
	1-P-FD-006-C010	P2I
	1-P-FD-006-C011	P2I
	1-P-FD-006-C012	P2I
	1-P-FD-006-C014	P2I
	1-P-FD-006-C015	P2I
	1-P-FD-006-C016	P1I
	1-P-FD-006-C017	P1I
	1-P-FD-006-C018	P1I
	1-P-FD-006-C019	P1I
	1-P-FD-006-C020	P1I
	1-P-FD-014-C001	P3I
	1-P-FD-014-C003	P4I
	1-P-FD-014-C004	P2I
	1-P-FD-014-C005	P2I
	1-P-FD-014-C006	P2I

\* CD number to be assigned by PSE&G.

PSE005.1017  
Revision 0

ATTACHMENT 5  
PAGE 3 OF 12  
CALC. NO. C-0031/7IRO

LIST OF CALCULATIONS  
(Concluded)

D. OTHER CALCULATIONS\*\*

<u>CD</u> <u>NO.*</u>	<u>CALC.</u> <u>NO.</u>	<u>CALCULATION TITLE</u>	<u>REV.</u>
		(None)	

\* CD number to be assigned by PSE&G.

\*\* Refer to PSE005.1008 for list of calculations generic to all systems.

PSE005.1017  
Revision 0

ATTACHMENT 5  
PAGE 4 OF 12  
CALC. NO. C-0031/7IRO



LIST OF OPERATIONAL DESIGN CHANGE NOTICES

The following Operational Design Change Notices (ODCN's) implement the design changes resulting from the snubber reduction analysis.

ODCN NO.*	DOCUMENT CHANGED			
	REV.	TYPE	NUMBER	REV.
	0	Isometric Drawing	1-P-FD-01	21
	0	Hanger Drawing	1-FD-006-H02	4
	0	Hanger Drawing	1-FD-006-H03	5
	0	Hanger Drawing	1-FD-006-H05	2
	0	Hanger Drawing	1-FD-006-H07	2
	0	Hanger Drawing	1-FD-006-H09	3
	0	Hanger Drawing	1-FD-006-H10	3

\* ODCN number to be assigned by PSE&G.

PSE005.1017  
Revision 0

ATTACHMENT 5  
PAGE 5 OF 12  
CALC. NO. C-0031/71R0

INTERFACE REQUIREMENTS

The following interface requirements must be completed prior to the final issuance of the ODCN's for implementation.

**A. BUILDING STRUCTURE REEVALUATION**

1. The following pipe supports have increased reaction loads due to snubber reduction and a total reaction load over 5,000 lbs. The building structure to which they are attached require requalification for the interface loads documented in the calculation for that pipe support.

SUPPORT NOS.

None

2. The following equipment have increased reaction loads due to snubber reduction. The building evaluation to which they are attached require requalification to the nozzle load documented in the Piping Calculation C-31.

EQUIPMENT (Type and Number)

HPCI Turbine 10S211 Exhaust Nozzle

INTERFACE REQUIREMENTS  
(Continued)

**B. DECOUPLED BRANCH LINE REQUALIFICATION**

The following decoupled branch lines have increased displacements and/or accelerations due to snubber reduction as documented in the Piping Calculation C-31. These decoupled branch lines require requalification for these increased displacements and/or accelerations.

<u>BRANCH LINE DESIGNATION</u> <u>(ISO. NO/CALC.NO.)</u>	<u>PISTAR</u> <u>NODE ID</u>	<u>BRANCH</u> <u>TYPE*</u>
1-P-FD-006-1" (1-P-FD-211/11.2201.3602.01)	54BR	I-C

\* See Table 4.B-1 of description of branch types.

PSE005.1017  
Revision 0

ATTACHMENT 5  
PAGE 7 OF 12  
CALC. NO. C-0031/7IRO

TABLE 4.B-1  
DECOUPLED BRANCH LINE TYPES

BRANCH TYPE	DESCRIPTION
I-A	Cantilevered vent or drain within Mark I region.
I-B	Branch line within Mark I region qualified by simplified methods.
I-C	Branch line within Mark I region qualified by computerized analysis methods.
II-A	Cantilevered vent or drain outside Mark I region.
II-B	Branch line outside Mark I region qualified by simplified (chart) methods.
II-C	Branch line outside Mark I region qualified by computerized analysis methods.

PSE005.1017  
Revision 0

ATTACHMENT 5  
PAGE 8 OF 12  
CALC. NO. C-0031/7IRO

INTERFACE REQUIREMENTS  
(Concluded)

**C. FIELD WALKDOWNS**

Displacements of the piping have increased in some locations due to snubber reduction. Field walkdowns may need to be performed to confirm that the revised displacements of the piping during a seismic or other dynamic event would not interfere with or adversely interact with other structures or piping adjacent to the TAP system.

PSE005.1017  
Revision 0

ATTACHMENT 5  
PAGE 9 OF 12  
CALC. NO. C-0031/TIRO

1010

STRESS ANALYSIS CHECKLIST

SYSTEM: P-201

CALCULATION NO./REV.: C-31/P7I

PISTAR RUN ID/DATE: Ref. 9 of the Calc.

		<u>Yes</u>	<u>No</u>	<u>N/A</u>
1.0	<u>PISTAR MODEL GEOMETRY</u>			
1.1	Have all updates, if any, been incorporated in the PISTAR model?	✓	—	—
1.2	Have as-built deviations reconciled in XBP-06 Piping Calculation been incorporated in the PISTAR model?	✓	—	—
1.3	a. Are the revision levels of the As-Built Isometrics referenced in Piping Calculation, the latest revision of the XBP-06 isometrics?	✓	—	—
	b. If no, have the changes in the later revisions of the isometric been incorporated in the PISTAR model?	—	—	✓
1.4	Have the changes from an outstanding SCF calculations incorporated in the piping model?	✓	—	—
1.5	Has the revised support stiffness been considered?	✓	—	—
2.0	<u>LOADS AND LOAD COMBINATIONS</u>			
2.1	If the system is a branch line from another subsystem included within the scope of this project, have the revised thermal and seismic movements been used in the branch line subsystem stress analysis?	—	—	✓
2.2	Have at least 33 Hz been extracted for use in the seismic response spectra analysis?	✓	—	—

ATTACHMENT 5  
 PAGE 10 OF 12  
 CALC. NO. C-0031/7IRO

SYSTEM: P-201

		<u>Yes</u>	<u>No</u>	<u>N/A</u>
2.3	Are ZPA effects included in the analysis?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.4	Have the modal responses for a seismic response spectra analysis been combined using the grouping method for closely spaced modes specified in NRC Regulatory Guide 1.92 been used?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.0	<u>EVALUATION</u>			
3.1	Pipe Stress			
3.1.1	Have provisions of editions or addenda of the ASME Code, Section III, 1977 Edition other than the Summer 1977 Addenda for piping and the Summer 1979 Addenda for flanges been used? (If so, list the provisions and edition or addenda used in the REMARKS section of this checklist and document the PSE&G's approval for their use.)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3.1.2	Have all flanges been evaluated?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.1.3	Have all welded attachments been evaluated?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.1.4	Have all SBP interfaces been assessed for their effects on branch lines?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.1.5	Has the functionality of ASME Class 2 and 3 stainless steel elbows and bends been demonstrated?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.2	Valve Accelerations <sup>(1)</sup>			
3.2.1	Have the valve accelerations been shown to be either (1) less than the allowable values given in the system design specification; or (2) <u>less than those obtained in the existing analysis?</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

ATTACHMENT 5  
PAGE 11 OF 12  
CALC. NO. C-0031/7190

SYSTEM: P-201

		<u>Yes</u>	<u>No</u>	<u>N/A</u>
3.3	Pipe Supports			
3.3.1	Have the effects of the change in preload on a spring hanger been reconciled?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.3.2	Have the effects of uplift on one-way supports been reconciled?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
3.4	Equipment Loads/Displacements <sup>(1)</sup>			
3.4.1	Have loads on equipment (including expansion joints) been shown to be either: (1) less than the allowable values given in the subsystem design specification; or (2) <del>less than the values obtained from the existing analyses?</del>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.5	Penetration Loads <sup>(1)</sup>			
3.5.1	Are the loads on the torus penetration less than the loads obtained in the existing analysis?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Note:

(1) An answer of "No" would require requalification and documentation in the piping calculations.

Remarks

3.5.1 Penetration qualification for revised loads has been documented in calculation number SC-203.


Approved:

*A. Berdekar*  
 Project Engineer - Piping

7/22/80  
 Date

ATTACHMENT 5  
 PAGE 12 OF 12  
 CALC. NO. C-0031/7IRO



 <b>CALCULATION COVER SHEET</b>	<b>TITLE</b> Piping Code Compliance Documentation System P-201		<b>SHEET</b> 1 OF 1
	<b>ID NUMBER</b> C-31	<b>REFERENCE (IF APPL)</b> None	
<b>REVISION</b>	P/I		
<b>DCP NUMBER (if applicable)</b>	4-EC-1021		
<b>REVISION HISTORY (List calc status &amp; sheets revised)</b>	Added pages 1 thru 106 & Att I-VI. Interim Revision per 4-EC-1021, CD-MOXX "Interim"		
<b>FUTURE CONFIRMATION REQUIRED:</b>	Yes		
<b>ORIGINATOR (Initial &amp; Date)</b>	R. Packer RGP 6/1/88 DJT. D. O. A. 07/22/88 SA 07/22/88		
<b>REVIEWER (Initial &amp; Date)</b>	Asher Keller ASM 6/22/88		
<b>SUPERVISOR APPROVAL (Initial &amp; Date)</b>	Asher Keller ASM 7/22/88		
<b>NUMBER PAGES (Cover Sheet)</b>	One		
<b>NUMBER PAGES (Calculation) (Excluding Attachments)</b>	106		
<b>NUMBER OF ATTACHMENTS / TOTAL PAGES</b>	6 / 4.24		
<b>TOTAL PAGES</b>	531		
<b>IMPORTANT TO SAFETY</b> <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO			
IF YES, DESIGN VERIFICATION REQUIRED PER REFERENCE 5.3			
		ATTACHMENT <u>6</u> PAGE <u>1</u> OF <u>2</u> CALC. NO. <u>C-0031/7IRP</u>	

P-201  
 #11

CALCULATION CHANGE DOCUMENT

DC No. \_\_\_\_\_

Package No. \_\_\_\_\_

MD/CD No. \_\_\_\_\_  
 (Circle One)

Page No. 1 of 1

Rev. No. 0

AFFECTED DOCUMENT

Parent Calculation  C-31, Rev. 6

New Calculation  \_\_\_\_\_, Rev. \_\_\_\_\_

EXPEDITED DCP

YES

NO

PARENT  
CALC.

INTERIM  
REVISION

New Calculation

\_\_\_\_\_ (2)

Interim Revision

6

P7I

Eng. Assessment

\_\_\_\_\_

New Calculation

\_\_\_\_\_ (1 & 2)

Interim Revision

\_\_\_\_\_

\_\_\_\_\_ (1)

Eng. Assessment

\_\_\_\_\_

\_\_\_\_\_

- (1) To follow within 10 days
- (2) New calculation number

0	ORG. ISSUE	<u>QJ1/QJ10R2</u> <u>6/21/88</u>	<u>Asher Lella</u> <u>6/22/88</u>	<u>Asher Lella</u> <u>6/22/88</u>
REV NO	REVISION SUMMARY	ORIGINATOR (Initial & Date)	REVIEWER (Initial & Date)	APPROVAL (Initial & Date)

ATTACHMENT 6

PAGE 2 OF 2

CALC. NO. C-0031/7IRP

## ATTACHMENT VII

### MARK I SPECTRA AT SBP INTERFACE (SYSTEM P201, CALC. NO. C-31)

The acceleration response spectra were regenerated in order to obtain the spectra in magnetic media for use in the small bore piping (SBP) analysis (Project XPS-025). The QABI, CHUGI, and COI spectra were regenerated using the RESGEN and ENVELOP computer programs.

#### QABI:

Spectra were generated for the QABI (C3.2) load case. Spectra were generated for all the critical tuned frequency cases as in the large bore analysis (LBP). The spectra thus generated for each tuned frequency case were enveloped using the ENVELOP computer program. The output spectra of the ENVELOP run are in ready-to-use PISTAR computer program input format, for use in the SBP PISTAR analysis.

#### CHUGI, COI:

Spectra were regenerated for COI, and CHUGI cases also using the RESGEN computer program. Even though only one load case exists within these loads, the ENVELOP computer program was run for these loads also in order to obtain the spectra in the PISTAR input format, for use in the SBP analysis.

This attachment includes the following spectra for SBP analysis:

1. Enveloped spectra in PISTAR format for QABI (C3.2) load case, (Pg. 2-15)
2. Response spectra in PISTAR format for the CHUGI load case, (Pg. 16-29)
3. Response spectra in PISTAR format for the COI load case. (Pg. 30-43)

REVISION PZI-1 PAGE 1/43  
PREPARED BY AM 5/3/93  
CHECKED BY Angela  
6/3/93

Cover Page

QABT (C3.2)

NODE 54BR

REVISION PTI-1 PAGE 2/43  
PREPARED BY AM 6/13/93  
CHECKED BY Andersblyat  
6/13/93





```
write( 6, 6003 ) nspec, npoint
np2 = npoint*2
write(6, 6004)
do 20 i = 1, nspec
  read( 1, 1002 ) node(i), idir(i), type, icase
  write(6, 6005 ) i, node(i), idir(i), type, icase
  if ( i .gt. 50) write(6, '(a1 ///)' ) '1'
20 continue
C
C   read spectra from tape2
C
do 30 i = 1, nspec
  read( 2, 2001 ) ( a(i,j), j = 1, np2 )
  do 30 j = 1, npoint
    if ( a(i, j*2-1) .eq. a(1, j*2-1) ) go to 25
    write( 6, 6902 )
    go to 999
25  continue
30 continue
C
C   Identify Node/Direction Pairs
C
k = 1
knode(1) = node(1)
kdir(1) = idir(1)
do 40 i = 1, nspec
  do 35 kk = 1, k
    if (knode(kk) .eq. node(i) .and. kdir(kk) .eq. idir(i))
+   go to 40
35  continue
  k = k + 1
  knode(k) = node(i)
  kdir(k) = idir(i)
40 continue
kount = k
C
C   zero node/direction pair amplitudes
C
do 50 k = 1, kount
  do 45 j = 1, npoint
    amp(k,j) = 0.0
45  continue
50 continue
C
C   envelope amplitudes for node/direction pairs
C
do 70 i = 1, nspec
  do 65 k = 1, kount
    if (knode(k) .eq. node(i) .and. kdir(k) .eq. idir(i))
+   go to 55
    go to 65
55  continue
  do 60 j = 1, npoint
    if (a(i, j*2) .gt. amp(k, j)) amp(k, j)=a(i, j*2)
60  continue
  go to 70
```

```
65 continue
70 continue
c
c identify nodes
c
l = 1
lnode(1) = knode(1)
do 80 k = 1, kount
  do 75 ll = 1, 1
    if (lnode(ll) .eq. knode(k)) go to 80
75 continue
  l = l + 1
  lnode(l) = knode(k)
80 continue
  lount=l
c
c write enveloped spectra to tape03.dat in PISTAR format
c and to tape04.dat in RESGEN format
c
do 90 l = 1, lount
  write( 3, 3001 ) lnode(l)
  write( 3, 3002 )
  write( 3, 3003 )
  do 85 k = 1, kount
    if (lnode(l) .ne. knode(k)) go to 85
    write( 3, 3005 ) kdir(k), a(1, 1), amp(k, 1),
+      a(1, 3), amp(k, 2)
    write( 3, 3006 ) (a(1, j*2-1), amp(k, j)), j = 3, npoint)
    write( 4, 4001 ) (a(1, j*2-1), amp(k, j)), j = 1, npoint)
85 continue
90 continue
c
c write enveloped spectra to output tape06.dat
c
c
write(6, '(a1 /)' ) '1'
do 100 l = 1, lount
  write( 6, 6006 ) lnode(l)
  write( 6, 6007 )
  write( 6, 6008 )
  do 95 k = 1, kount
    if (lnode(l) .ne. knode(k)) go to 95
    write( 6, 6009 ) kdir(k), a(1, 1), amp(k, 1),
+      a(1, 3), amp(k, 2)
    write( 6, 6010 ) (a(1, j*2-1), amp(k, j)), j = 3, npoint)
95 continue
100 continue
  goto 999
c
c write error messages
c
801 write(6, 6904) 'tape01.dat'
  stop
802 write(6, 6904) 'tape02.dat'
  stop
```



```
803 write(6, 6905) 'tape03.dat'  
stop  
804 write(6, 6905) 'tape04.dat'  
stop  
805 write(6, 6904) 'tape05.dat'  
stop  
806 write(6, 6905) 'tape06.dat'  
stop  
807 write(6, 6904) 'qablok.dat'  
stop
```

```
c  
1000 format(i5, 5x, 2i5)  
1001 format( a72 )  
1002 format(32x, a5, 2x, a1, 1x, a4, 6x, i2)
```

```
c  
2001 format(8f10.0)
```

```
c  
6001 format('1' /// 5x, 'ENVELOPE --- VERSION 1.0.0' //  
+ 5x, 'SOURCE CODE' // )  
6002 format(5x, a72)  
6003 format(// 5x, 'NO. OF SPECTRA = ', i3 /  
+ 5x, 'NO. OF FREQUENCY POINTS = ', i3 / )  
6004 format(5x, 'SPECTRA', 25x, 'LOAD' / 4x, 'NO', 5x, 'NODE',  
+ 3x, 'DIR', 4x, 'TYPE', 4x, 'CASE')  
6005 format(1x, i5, 5x, a5, 3x, a1, 5x, a4, 5x, i2)  
6006 format(// 5x, 'COMMENT', 3x, 'NODE = ', a5, 5x,  
+ 'ACCELERATION SPECTRA')  
6007 format(5x, 'CASE', 6x, 'XXXXX')  
6008 format(5x, 'SEISMIC', 7x, '1', 10x, '386.4', 5x, '386.4',  
+ 5x, '386.4', 7x, 'CSM', 7x, 'RSS')  
6009 format(5x, a1, '-SHOCK', 9x, 'FREQ', 5x, 'ACCEL', 4F10.3)  
6010 format(5x, 16x, 'FREQ', 5x, 'ACCEL', 4F10.3)
```

```
c  
3001 format(// 'COMMENT', 3x, 'NODE = ', a5, 5x,  
+ 'ACCELERATION SPECTRA')  
3002 format('CASE', 6x, 'XXXXX')  
3003 format('SEISMIC', 7x, '1', 10x, '386.4', 5x, '386.4',  
+ 5x, '386.4', 7x, 'CSM', 7x, 'RSS')  
3005 format( a1, '-SHOCK', 9x, 'FREQ', 5x, 'ACCEL', 4F10.3)  
3006 format( 16x, 'FREQ', 5x, 'ACCEL', 4F10.3)
```

```
c  
4001 format(8f10.3)
```

```
c  
6901 format(5x, 'ERROR...NSPEC = ', i5, ' > 200 (INTERNAL LIMIT)')  
6902 format(5x, 'ERROR...NPOINT = ', i5, ' > 70 (INTERNAL LIMIT)')  
6903 format(5x, 'ERROR...FREQUENCY POINTS NOT UNIFORM')  
6904 format(5x, 'ERROR...INPUT FILE -> ', a10, 'IS MISSING.' )  
6905 format(5x, 'ERROR...UNABLE TO OPEN OUTPUT FILE -> ', a10)
```

```
c  
7001 format( a80 )  
7002 format(10x, a80 )  
999 stop  
end
```

COMMENT  
 CASE  
 SEISMIC  
 X-SHOCK

NODE = 54BR  
 XXXXX

ACCELERATION SPECTRA

*QASI*

	1	386.4	386.4	386.4	CSM	RSS
FREQ	ACCEL	1.000	0.006	2.000	0.031	
FREQ	ACCEL	3.000	0.072	4.000	0.122	
FREQ	ACCEL	4.100	0.125	4.200	0.121	
FREQ	ACCEL	4.300	0.135	4.400	0.145	
FREQ	ACCEL	4.500	0.157	4.600	0.161	
FREQ	ACCEL	4.700	0.155	4.800	0.141	
FREQ	ACCEL	4.900	0.163	5.000	0.185	
FREQ	ACCEL	5.100	0.199	5.200	0.204	
FREQ	ACCEL	5.300	0.202	5.400	0.190	
FREQ	ACCEL	5.500	0.218	5.600	0.246	
FREQ	ACCEL	5.700	0.268	5.800	0.277	
FREQ	ACCEL	5.900	0.272	6.000	0.269	
FREQ	ACCEL	6.100	0.291	6.200	0.323	
FREQ	ACCEL	6.300	0.344	6.400	0.347	
FREQ	ACCEL	6.500	0.351	6.600	0.369	
FREQ	ACCEL	6.700	0.378	6.800	0.400	
FREQ	ACCEL	6.900	0.402	7.000	0.417	
FREQ	ACCEL	7.100	0.455	7.200	0.474	
FREQ	ACCEL	7.300	0.479	7.400	0.465	
FREQ	ACCEL	7.500	0.505	7.600	0.548	
FREQ	ACCEL	7.700	0.574	7.800	0.573	
FREQ	ACCEL	7.900	0.555	8.000	0.613	
FREQ	ACCEL	8.100	0.654	8.200	0.669	
FREQ	ACCEL	8.300	0.650	8.400	0.674	
FREQ	ACCEL	8.500	0.718	8.600	0.734	
FREQ	ACCEL	8.700	0.758	8.800	0.803	
FREQ	ACCEL	8.900	0.835	9.000	0.837	
FREQ	ACCEL	9.100	0.884	9.200	0.956	
FREQ	ACCEL	9.300	0.990	9.400	1.007	
FREQ	ACCEL	9.500	1.045	9.600	1.116	
FREQ	ACCEL	9.700	1.150	9.800	1.145	
FREQ	ACCEL	9.900	1.214	10.000	1.273	
FREQ	ACCEL	10.100	1.272	10.200	1.293	
FREQ	ACCEL	10.300	1.351	10.400	1.347	
FREQ	ACCEL	10.500	1.365	10.600	1.411	
FREQ	ACCEL	10.700	1.514	10.800	1.628	
FREQ	ACCEL	10.900	1.710	11.000	1.808	
FREQ	ACCEL	11.100	1.932	11.200	2.054	
FREQ	ACCEL	11.300	2.139	11.400	2.301	
FREQ	ACCEL	11.500	2.412	11.600	2.498	
FREQ	ACCEL	11.700	2.666	11.800	2.756	
FREQ	ACCEL	11.900	2.840	12.000	2.988	
FREQ	ACCEL	12.100	3.040	12.200	3.071	
FREQ	ACCEL	12.300	3.151	12.400	3.136	
FREQ	ACCEL	12.500	3.122	12.600	3.114	
FREQ	ACCEL	12.700	3.046	12.800	2.960	
FREQ	ACCEL	12.900	2.901	13.000	2.916	
FREQ	ACCEL	13.100	3.040	13.200	3.298	
FREQ	ACCEL	13.300	3.703	13.400	4.217	
FREQ	ACCEL	13.500	4.829	13.600	5.482	
FREQ	ACCEL	13.700	6.122	13.800	6.858	

FREQ	ACCEL	13.900	7.621	14.000	8.324
FREQ	ACCEL	14.100	9.046	14.200	9.688
FREQ	ACCEL	14.300	10.370	14.400	11.020
FREQ	ACCEL	14.500	11.520	14.600	12.100
FREQ	ACCEL	14.700	12.780	14.800	13.710
FREQ	ACCEL	14.900	14.660	15.000	15.290
FREQ	ACCEL	15.100	15.810	15.200	16.060
FREQ	ACCEL	15.300	16.000	15.400	15.650
FREQ	ACCEL	15.500	15.240	15.600	14.780
FREQ	ACCEL	15.700	14.110	15.800	13.580
FREQ	ACCEL	15.900	12.930	16.000	12.270
FREQ	ACCEL	16.100	11.640	16.200	10.960
FREQ	ACCEL	16.300	10.250	16.400	9.518
FREQ	ACCEL	16.500	8.837	16.600	8.135
FREQ	ACCEL	16.700	7.487	16.800	6.818
FREQ	ACCEL	16.900	6.263	17.000	5.749
FREQ	ACCEL	17.100	5.312	17.200	4.883
FREQ	ACCEL	17.300	4.487	17.400	4.165
FREQ	ACCEL	17.500	3.886	17.600	3.681
FREQ	ACCEL	17.700	3.548	17.800	3.461
FREQ	ACCEL	17.900	3.402	18.000	3.349
FREQ	ACCEL	18.100	3.287	18.200	3.202
FREQ	ACCEL	18.300	3.133	18.400	3.074
FREQ	ACCEL	18.500	3.022	18.600	2.955
FREQ	ACCEL	18.700	2.885	18.800	2.798
FREQ	ACCEL	18.900	2.712	19.000	2.621
FREQ	ACCEL	19.100	2.526	19.200	2.433
FREQ	ACCEL	19.300	2.349	19.400	2.278
FREQ	ACCEL	19.500	2.225	19.600	2.194
FREQ	ACCEL	19.700	2.182	19.800	2.178
FREQ	ACCEL	19.900	2.177	20.000	2.173
FREQ	ACCEL	20.100	2.162	20.200	2.149
FREQ	ACCEL	20.300	2.130	20.400	2.101
FREQ	ACCEL	20.500	2.062	20.600	2.016
FREQ	ACCEL	20.700	1.966	20.800	1.916
FREQ	ACCEL	20.900	1.868	21.000	1.826
FREQ	ACCEL	21.100	1.802	21.200	1.775
FREQ	ACCEL	21.300	1.747	21.400	1.736
FREQ	ACCEL	21.500	1.730	21.600	1.727
FREQ	ACCEL	21.700	1.727	21.800	1.726
FREQ	ACCEL	21.900	1.724	22.000	1.722
FREQ	ACCEL	22.100	1.721	22.200	1.721
FREQ	ACCEL	22.300	1.722	22.400	1.726
FREQ	ACCEL	22.500	1.731	22.600	1.736
FREQ	ACCEL	22.700	1.740	22.800	1.739
FREQ	ACCEL	22.900	1.731	23.000	1.712
FREQ	ACCEL	23.100	1.680	23.200	1.668
FREQ	ACCEL	23.300	1.666	23.400	1.673
FREQ	ACCEL	23.500	1.662	23.600	1.645
FREQ	ACCEL	23.700	1.687	23.800	1.715
FREQ	ACCEL	23.900	1.760	24.000	1.788
FREQ	ACCEL	24.100	1.792	24.200	1.768
FREQ	ACCEL	24.300	1.827	24.400	1.882
FREQ	ACCEL	24.500	1.932	24.600	1.998
FREQ	ACCEL	24.700	2.041	24.800	2.060
FREQ	ACCEL	24.900	2.103	25.000	2.169

FREQ	ACCEL	25.100	2.230	25.200	2.302
FREQ	ACCEL	25.300	2.374	25.400	2.498
FREQ	ACCEL	25.500	2.585	25.600	2.632
FREQ	ACCEL	25.700	2.674	25.800	2.760
FREQ	ACCEL	25.900	2.806	26.000	2.809
FREQ	ACCEL	26.100	2.799	26.200	2.850
FREQ	ACCEL	26.300	2.873	26.400	2.893
FREQ	ACCEL	26.500	2.952	26.600	2.973
FREQ	ACCEL	26.700	3.073	26.800	3.117
FREQ	ACCEL	26.900	3.120	27.000	3.130
FREQ	ACCEL	27.100	3.154	27.200	3.141
FREQ	ACCEL	27.300	3.139	27.400	3.155
FREQ	ACCEL	27.500	3.146	27.600	3.141
FREQ	ACCEL	27.700	3.178	27.800	3.182
FREQ	ACCEL	27.900	3.172	28.000	3.205
FREQ	ACCEL	28.100	3.258	28.200	3.273
FREQ	ACCEL	28.300	3.249	28.400	3.188
FREQ	ACCEL	28.500	3.193	28.600	3.195
FREQ	ACCEL	28.700	3.160	28.800	3.090
FREQ	ACCEL	28.900	3.066	29.000	3.008
FREQ	ACCEL	29.100	2.902	29.200	2.869
FREQ	ACCEL	29.300	2.811	29.400	2.709
FREQ	ACCEL	29.500	2.569	29.600	2.462
FREQ	ACCEL	29.700	2.365	29.800	2.236
FREQ	ACCEL	29.900	2.128	30.000	2.063
FREQ	ACCEL	31.000	1.425	32.000	1.301
FREQ	ACCEL	33.000	1.159	34.000	1.158
FREQ	ACCEL	35.000	1.109	36.000	1.072
FREQ	ACCEL	37.000	1.144	38.000	1.038
FREQ	ACCEL	39.000	1.059	40.000	0.990
FREQ	ACCEL	41.000	1.063	42.000	1.039
FREQ	ACCEL	43.000	0.995	44.000	1.008
FREQ	ACCEL	45.000	1.001	46.000	0.992
FREQ	ACCEL	47.000	1.011	48.000	0.933
FREQ	ACCEL	49.000	1.008	50.000	1.016
FREQ	ACCEL	51.000	0.953	52.000	0.993
FREQ	ACCEL	53.000	0.922	54.000	1.028
FREQ	ACCEL	55.000	0.958	56.000	0.950
FREQ	ACCEL	57.000	0.992	58.000	0.928
FREQ	ACCEL	59.000	0.962	60.000	0.904
FREQ	ACCEL	1.000	0.000	2.000	0.001
FREQ	ACCEL	3.000	0.003	4.000	0.005
FREQ	ACCEL	4.100	0.005	4.200	0.005
FREQ	ACCEL	4.300	0.006	4.400	0.006
FREQ	ACCEL	4.500	0.007	4.600	0.007
FREQ	ACCEL	4.700	0.008	4.800	0.008
FREQ	ACCEL	4.900	0.009	5.000	0.010
FREQ	ACCEL	5.100	0.011	5.200	0.011
FREQ	ACCEL	5.300	0.012	5.400	0.014
FREQ	ACCEL	5.500	0.016	5.600	0.017
FREQ	ACCEL	5.700	0.019	5.800	0.022
FREQ	ACCEL	5.900	0.024	6.000	0.027
FREQ	ACCEL	6.100	0.031	6.200	0.034
FREQ	ACCEL	6.300	0.038	6.400	0.043
FREQ	ACCEL	6.500	0.048	6.600	0.051
FREQ	ACCEL	6.700	0.051	6.800	0.048

Y-SHOCK

FREQ	ACCEL	6.900	0.042	7.000	0.036
FREQ	ACCEL	7.100	0.028	7.200	0.024
FREQ	ACCEL	7.300	0.023	7.400	0.024
FREQ	ACCEL	7.500	0.025	7.600	0.025
FREQ	ACCEL	7.700	0.026	7.800	0.026
FREQ	ACCEL	7.900	0.027	8.000	0.027
FREQ	ACCEL	8.100	0.028	8.200	0.028
FREQ	ACCEL	8.300	0.028	8.400	0.028
FREQ	ACCEL	8.500	0.029	8.600	0.030
FREQ	ACCEL	8.700	0.032	8.800	0.033
FREQ	ACCEL	8.900	0.035	9.000	0.037
FREQ	ACCEL	9.100	0.038	9.200	0.040
FREQ	ACCEL	9.300	0.042	9.400	0.044
FREQ	ACCEL	9.500	0.046	9.600	0.048
FREQ	ACCEL	9.700	0.049	9.800	0.051
FREQ	ACCEL	9.900	0.053	10.000	0.056
FREQ	ACCEL	10.100	0.058	10.200	0.060
FREQ	ACCEL	10.300	0.063	10.400	0.067
FREQ	ACCEL	10.500	0.071	10.600	0.075
FREQ	ACCEL	10.700	0.080	10.800	0.084
FREQ	ACCEL	10.900	0.088	11.000	0.092
FREQ	ACCEL	11.100	0.096	11.200	0.100
FREQ	ACCEL	11.300	0.104	11.400	0.107
FREQ	ACCEL	11.500	0.113	11.600	0.121
FREQ	ACCEL	11.700	0.129	11.800	0.137
FREQ	ACCEL	11.900	0.146	12.000	0.155
FREQ	ACCEL	12.100	0.163	12.200	0.172
FREQ	ACCEL	12.300	0.181	12.400	0.189
FREQ	ACCEL	12.500	0.196	12.600	0.203
FREQ	ACCEL	12.700	0.210	12.800	0.217
FREQ	ACCEL	12.900	0.225	13.000	0.232
FREQ	ACCEL	13.100	0.240	13.200	0.248
FREQ	ACCEL	13.300	0.259	13.400	0.277
FREQ	ACCEL	13.500	0.299	13.600	0.319
FREQ	ACCEL	13.700	0.336	13.800	0.351
FREQ	ACCEL	13.900	0.367	14.000	0.383
FREQ	ACCEL	14.100	0.396	14.200	0.405
FREQ	ACCEL	14.300	0.423	14.400	0.445
FREQ	ACCEL	14.500	0.467	14.600	0.491
FREQ	ACCEL	14.700	0.516	14.800	0.541
FREQ	ACCEL	14.900	0.555	15.000	0.573
FREQ	ACCEL	15.100	0.584	15.200	0.592
FREQ	ACCEL	15.300	0.598	15.400	0.596
FREQ	ACCEL	15.500	0.586	15.600	0.572
FREQ	ACCEL	15.700	0.552	15.800	0.530
FREQ	ACCEL	15.900	0.501	16.000	0.469
FREQ	ACCEL	16.100	0.446	16.200	0.422
FREQ	ACCEL	16.300	0.407	16.400	0.404
FREQ	ACCEL	16.500	0.398	16.600	0.390
FREQ	ACCEL	16.700	0.381	16.800	0.373
FREQ	ACCEL	16.900	0.366	17.000	0.357
FREQ	ACCEL	17.100	0.347	17.200	0.336
FREQ	ACCEL	17.300	0.324	17.400	0.311
FREQ	ACCEL	17.500	0.298	17.600	0.284
FREQ	ACCEL	17.700	0.271	17.800	0.258
FREQ	ACCEL	17.900	0.248	18.000	0.246

FREQ	ACCEL	18.100	0.244	18.200	0.242
FREQ	ACCEL	18.300	0.239	18.400	0.235
FREQ	ACCEL	18.500	0.232	18.600	0.228
FREQ	ACCEL	18.700	0.224	18.800	0.219
FREQ	ACCEL	18.900	0.215	19.000	0.211
FREQ	ACCEL	19.100	0.207	19.200	0.203
FREQ	ACCEL	19.300	0.200	19.400	0.198
FREQ	ACCEL	19.500	0.196	19.600	0.199
FREQ	ACCEL	19.700	0.203	19.800	0.208
FREQ	ACCEL	19.900	0.212	20.000	0.215
FREQ	ACCEL	20.100	0.219	20.200	0.222
FREQ	ACCEL	20.300	0.225	20.400	0.227
FREQ	ACCEL	20.500	0.228	20.600	0.230
FREQ	ACCEL	20.700	0.231	20.800	0.232
FREQ	ACCEL	20.900	0.233	21.000	0.234
FREQ	ACCEL	21.100	0.237	21.200	0.241
FREQ	ACCEL	21.300	0.246	21.400	0.254
FREQ	ACCEL	21.500	0.262	21.600	0.271
FREQ	ACCEL	21.700	0.285	21.800	0.300
FREQ	ACCEL	21.900	0.317	22.000	0.336
FREQ	ACCEL	22.100	0.356	22.200	0.377
FREQ	ACCEL	22.300	0.399	22.400	0.422
FREQ	ACCEL	22.500	0.445	22.600	0.468
FREQ	ACCEL	22.700	0.491	22.800	0.513
FREQ	ACCEL	22.900	0.534	23.000	0.559
FREQ	ACCEL	23.100	0.588	23.200	0.616
FREQ	ACCEL	23.300	0.642	23.400	0.669
FREQ	ACCEL	23.500	0.716	23.600	0.761
FREQ	ACCEL	23.700	0.800	23.800	0.834
FREQ	ACCEL	23.900	0.869	24.000	0.921
FREQ	ACCEL	24.100	0.966	24.200	1.002
FREQ	ACCEL	24.300	1.033	24.400	1.086
FREQ	ACCEL	24.500	1.127	24.600	1.160
FREQ	ACCEL	24.700	1.211	24.800	1.242
FREQ	ACCEL	24.900	1.279	25.000	1.318
FREQ	ACCEL	25.100	1.343	25.200	1.371
FREQ	ACCEL	25.300	1.395	25.400	1.443
FREQ	ACCEL	25.500	1.470	25.600	1.493
FREQ	ACCEL	25.700	1.507	25.800	1.526
FREQ	ACCEL	25.900	1.542	26.000	1.539
FREQ	ACCEL	26.100	1.536	26.200	1.530
FREQ	ACCEL	26.300	1.514	26.400	1.520
FREQ	ACCEL	26.500	1.526	26.600	1.517
FREQ	ACCEL	26.700	1.495	26.800	1.460
FREQ	ACCEL	26.900	1.452	27.000	1.452
FREQ	ACCEL	27.100	1.442	27.200	1.424
FREQ	ACCEL	27.300	1.399	27.400	1.373
FREQ	ACCEL	27.500	1.362	27.600	1.346
FREQ	ACCEL	27.700	1.326	27.800	1.322
FREQ	ACCEL	27.900	1.337	28.000	1.348
FREQ	ACCEL	28.100	1.356	28.200	1.360
FREQ	ACCEL	28.300	1.359	28.400	1.353
FREQ	ACCEL	28.500	1.341	28.600	1.342
FREQ	ACCEL	28.700	1.365	28.800	1.382
FREQ	ACCEL	28.900	1.392	29.000	1.394
FREQ	ACCEL	29.100	1.386	29.200	1.369

Z-SHOCK

FREQ	ACCEL	29.300	1.349	29.400	1.364
FREQ	ACCEL	29.500	1.369	29.600	1.362
FREQ	ACCEL	29.700	1.342	29.800	1.310
FREQ	ACCEL	29.900	1.287	30.000	1.275
FREQ	ACCEL	31.000	1.024	32.000	0.731
FREQ	ACCEL	33.000	0.739	34.000	0.826
FREQ	ACCEL	35.000	0.943	36.000	1.033
FREQ	ACCEL	37.000	1.057	38.000	1.086
FREQ	ACCEL	39.000	1.101	40.000	1.104
FREQ	ACCEL	41.000	1.022	42.000	0.984
FREQ	ACCEL	43.000	0.923	44.000	0.948
FREQ	ACCEL	45.000	0.917	46.000	0.820
FREQ	ACCEL	47.000	0.766	48.000	0.730
FREQ	ACCEL	49.000	0.854	50.000	0.915
FREQ	ACCEL	51.000	0.918	52.000	0.868
FREQ	ACCEL	53.000	0.804	54.000	0.800
FREQ	ACCEL	55.000	0.740	56.000	0.721
FREQ	ACCEL	57.000	0.674	58.000	0.622
FREQ	ACCEL	59.000	0.660	60.000	0.636
FREQ	ACCEL	1.000	0.001	2.000	0.004
FREQ	ACCEL	3.000	0.009	4.000	0.016
FREQ	ACCEL	4.100	0.016	4.200	0.017
FREQ	ACCEL	4.300	0.018	4.400	0.019
FREQ	ACCEL	4.500	0.020	4.600	0.021
FREQ	ACCEL	4.700	0.021	4.800	0.019
FREQ	ACCEL	4.900	0.022	5.000	0.025
FREQ	ACCEL	5.100	0.026	5.200	0.026
FREQ	ACCEL	5.300	0.025	5.400	0.026
FREQ	ACCEL	5.500	0.028	5.600	0.031
FREQ	ACCEL	5.700	0.033	5.800	0.033
FREQ	ACCEL	5.900	0.034	6.000	0.036
FREQ	ACCEL	6.100	0.038	6.200	0.039
FREQ	ACCEL	6.300	0.041	6.400	0.043
FREQ	ACCEL	6.500	0.045	6.600	0.046
FREQ	ACCEL	6.700	0.048	6.800	0.050
FREQ	ACCEL	6.900	0.052	7.000	0.054
FREQ	ACCEL	7.100	0.056	7.200	0.058
FREQ	ACCEL	7.300	0.060	7.400	0.062
FREQ	ACCEL	7.500	0.063	7.600	0.065
FREQ	ACCEL	7.700	0.067	7.800	0.069
FREQ	ACCEL	7.900	0.071	8.000	0.073
FREQ	ACCEL	8.100	0.076	8.200	0.077
FREQ	ACCEL	8.300	0.079	8.400	0.083
FREQ	ACCEL	8.500	0.088	8.600	0.088
FREQ	ACCEL	8.700	0.091	8.800	0.095
FREQ	ACCEL	8.900	0.098	9.000	0.101
FREQ	ACCEL	9.100	0.106	9.200	0.111
FREQ	ACCEL	9.300	0.115	9.400	0.119
FREQ	ACCEL	9.500	0.123	9.600	0.127
FREQ	ACCEL	9.700	0.131	9.800	0.136
FREQ	ACCEL	9.900	0.141	10.000	0.144
FREQ	ACCEL	10.100	0.148	10.200	0.157
FREQ	ACCEL	10.300	0.160	10.400	0.166
FREQ	ACCEL	10.500	0.171	10.600	0.178
FREQ	ACCEL	10.700	0.185	10.800	0.191
FREQ	ACCEL	10.900	0.198	11.000	0.207

FREQ	ACCEL	11.100	0.213	11.200	0.226
FREQ	ACCEL	11.300	0.237	11.400	0.241
FREQ	ACCEL	11.500	0.255	11.600	0.264
FREQ	ACCEL	11.700	0.276	11.800	0.289
FREQ	ACCEL	11.900	0.300	12.000	0.313
FREQ	ACCEL	12.100	0.328	12.200	0.342
FREQ	ACCEL	12.300	0.359	12.400	0.383
FREQ	ACCEL	12.500	0.404	12.600	0.423
FREQ	ACCEL	12.700	0.444	12.800	0.471
FREQ	ACCEL	12.900	0.497	13.000	0.530
FREQ	ACCEL	13.100	0.555	13.200	0.596
FREQ	ACCEL	13.300	0.627	13.400	0.675
FREQ	ACCEL	13.500	0.719	13.600	0.766
FREQ	ACCEL	13.700	0.813	13.800	0.868
FREQ	ACCEL	13.900	0.926	14.000	0.990
FREQ	ACCEL	14.100	1.052	14.200	1.119
FREQ	ACCEL	14.300	1.193	14.400	1.275
FREQ	ACCEL	14.500	1.356	14.600	1.446
FREQ	ACCEL	14.700	1.535	14.800	1.618
FREQ	ACCEL	14.900	1.708	15.000	1.788
FREQ	ACCEL	15.100	1.842	15.200	1.903
FREQ	ACCEL	15.300	1.944	15.400	1.960
FREQ	ACCEL	15.500	1.954	15.600	1.932
FREQ	ACCEL	15.700	1.905	15.800	1.857
FREQ	ACCEL	15.900	1.805	16.000	1.739
FREQ	ACCEL	16.100	1.660	16.200	1.579
FREQ	ACCEL	16.300	1.490	16.400	1.401
FREQ	ACCEL	16.500	1.309	16.600	1.213
FREQ	ACCEL	16.700	1.127	16.800	1.041
FREQ	ACCEL	16.900	0.961	17.000	0.882
FREQ	ACCEL	17.100	0.808	17.200	0.745
FREQ	ACCEL	17.300	0.680	17.400	0.620
FREQ	ACCEL	17.500	0.567	17.600	0.521
FREQ	ACCEL	17.700	0.480	17.800	0.442
FREQ	ACCEL	17.900	0.416	18.000	0.412
FREQ	ACCEL	18.100	0.408	18.200	0.402
FREQ	ACCEL	18.300	0.395	18.400	0.389
FREQ	ACCEL	18.500	0.382	18.600	0.374
FREQ	ACCEL	18.700	0.363	18.800	0.350
FREQ	ACCEL	18.900	0.337	19.000	0.326
FREQ	ACCEL	19.100	0.317	19.200	0.310
FREQ	ACCEL	19.300	0.307	19.400	0.306
FREQ	ACCEL	19.500	0.306	19.600	0.306
FREQ	ACCEL	19.700	0.306	19.800	0.303
FREQ	ACCEL	19.900	0.299	20.000	0.295
FREQ	ACCEL	20.100	0.293	20.200	0.287
FREQ	ACCEL	20.300	0.286	20.400	0.284
FREQ	ACCEL	20.500	0.279	20.600	0.271
FREQ	ACCEL	20.700	0.266	20.800	0.259
FREQ	ACCEL	20.900	0.252	21.000	0.243
FREQ	ACCEL	21.100	0.237	21.200	0.232
FREQ	ACCEL	21.300	0.233	21.400	0.236
FREQ	ACCEL	21.500	0.236	21.600	0.233
FREQ	ACCEL	21.700	0.230	21.800	0.226
FREQ	ACCEL	21.900	0.224	22.000	0.222
FREQ	ACCEL	22.100	0.225	22.200	0.224



FREQ	ACCEL	22.300	0.221	22.400	0.215
FREQ	ACCEL	22.500	0.209	22.600	0.203
FREQ	ACCEL	22.700	0.197	22.800	0.195
FREQ	ACCEL	22.900	0.196	23.000	0.196
FREQ	ACCEL	23.100	0.202	23.200	0.207
FREQ	ACCEL	23.300	0.216	23.400	0.227
FREQ	ACCEL	23.500	0.240	23.600	0.251
FREQ	ACCEL	23.700	0.259	23.800	0.262
FREQ	ACCEL	23.900	0.267	24.000	0.276
FREQ	ACCEL	24.100	0.283	24.200	0.291
FREQ	ACCEL	24.300	0.294	24.400	0.292
FREQ	ACCEL	24.500	0.297	24.600	0.299
FREQ	ACCEL	24.700	0.304	24.800	0.313
FREQ	ACCEL	24.900	0.319	25.000	0.324
FREQ	ACCEL	25.100	0.327	25.200	0.333
FREQ	ACCEL	25.300	0.342	25.400	0.348
FREQ	ACCEL	25.500	0.351	25.600	0.351
FREQ	ACCEL	25.700	0.350	25.800	0.358
FREQ	ACCEL	25.900	0.360	26.000	0.359
FREQ	ACCEL	26.100	0.358	26.200	0.364
FREQ	ACCEL	26.300	0.381	26.400	0.399
FREQ	ACCEL	26.500	0.412	26.600	0.426
FREQ	ACCEL	26.700	0.435	26.800	0.439
FREQ	ACCEL	26.900	0.435	27.000	0.434
FREQ	ACCEL	27.100	0.429	27.200	0.416
FREQ	ACCEL	27.300	0.409	27.400	0.398
FREQ	ACCEL	27.500	0.391	27.600	0.380
FREQ	ACCEL	27.700	0.363	27.800	0.352
FREQ	ACCEL	27.900	0.338	28.000	0.318
FREQ	ACCEL	28.100	0.303	28.200	0.287
FREQ	ACCEL	28.300	0.268	28.400	0.247
FREQ	ACCEL	28.500	0.245	28.600	0.245
FREQ	ACCEL	28.700	0.244	28.800	0.243
FREQ	ACCEL	28.900	0.241	29.000	0.238
FREQ	ACCEL	29.100	0.235	29.200	0.231
FREQ	ACCEL	29.300	0.227	29.400	0.224
FREQ	ACCEL	29.500	0.223	29.600	0.222
FREQ	ACCEL	29.700	0.220	29.800	0.218
FREQ	ACCEL	29.900	0.215	30.000	0.212
FREQ	ACCEL	31.000	0.246	32.000	0.329
FREQ	ACCEL	33.000	0.331	34.000	0.384
FREQ	ACCEL	35.000	0.487	36.000	0.667
FREQ	ACCEL	37.000	1.045	38.000	1.253
FREQ	ACCEL	39.000	1.093	40.000	0.889
FREQ	ACCEL	41.000	0.656	42.000	0.496
FREQ	ACCEL	43.000	0.378	44.000	0.312
FREQ	ACCEL	45.000	0.258	46.000	0.235
FREQ	ACCEL	47.000	0.254	48.000	0.303
FREQ	ACCEL	49.000	0.350	50.000	0.393
FREQ	ACCEL	51.000	0.454	52.000	0.443
FREQ	ACCEL	53.000	0.429	54.000	0.379
FREQ	ACCEL	55.000	0.342	56.000	0.332
FREQ	ACCEL	57.000	0.318	58.000	0.301
FREQ	ACCEL	59.000	0.325	60.000	0.338

COVER PAGE

CHUG.I  
NODE 54BR

REVISION P7I-1 PAGE 16/43  
PREPARED BY AM 5/3/93  
CHECKED BY Aspenkovat  
6/3/93



c

```
character*5 node, idir, knode, kdir, lnode  
character*72 source, junk  
character*80 qablok
```

c

```
dimension node(200), idir(200), knode(200), kdir(200), lnode(200)  
dimension a(200,1000), amp(200,500)
```

c

c

c

c

Open input/output devices

```
open ( unit= 1, file= 'tape01.dat', err= 801 )  
open ( unit= 2, file= 'tape02.dat', err= 802 )  
open ( unit= 3, file= 'tape03.dat', err= 803 )  
open ( unit= 4, file= 'tape04.dat', err= 804 )  
open ( unit= 5, file= 'jvelop.for', err= 805 )  
open ( unit= 6, file= 'jvelop.out', err= 806 )  
open ( unit= 7, file= 'qablok.dat', err= 807 )
```

c

c

c

write qablok to output file

```
write(6, '(a1 /)' ) '1'  
1 read(7, 7001, end= 2 ) qablok  
write( 6, 7002 ) qablok  
go to 1
```

c

c

c

Echo program source file

```
2 write( 6, 6001 )  
num = 0  
5 read( 5, 1001, end= 10 ) source  
num = num + 1  
if ( num .eq. 50) then  
write(6, '(a1 ///)' ) '1'  
num = 0  
end if  
write( 6, 6002 ) source  
go to 5
```

c

c

c

read and check tape1 input data

```
10 read( 1, 1000 ) nspec, npoint, ntitle  
write(6, '(a1 ///)' ) '1'  
do 15 n = 1, ntitle + 5  
read( 1, 1001 ) junk  
if ( n .gt. 5) write( 6, 6002 ) junk  
15 continue  
if (nspec .gt. 200) then  
write(6, 6901) nspec  
go to 999  
endif  
if (npoint .gt. 500) then  
write(6, 6902) npoint  
go to 999  
endif
```

c

```
write( 6, 6003 ) nspec, npoint  
np2 = npoint*2  
write(6, 6004)  
do 20 i = 1, nspec  
  read( 1, 1002 ) node(i), idir(i), type, icase  
  write(6, 6005 ) i, node(i), idir(i), type, icase  
  if ( i .gt. 50) write(6, '(a1 ///)' ) '1'  
20 continue
```

```
c  
c  
c  
read spectra from tape2
```

```
do 30 i = 1, nspec  
  read( 2, 2001 ) ( a(i,j), j = 1, np2 )  
  do 30 j = 1, npoint  
    if ( a(i, j*2-1) .eq. a(1, j*2-1) ) go to 25  
    write( 6, 6902 )  
    go to 999  
25 continue  
30 continue
```

```
c  
c  
c  
Identify Node/Direction Pairs
```

```
k = 1  
knode(1) = node(1)  
kdir(1) = idir(1)  
do 40 i = 1, nspec  
  do 35 kk = 1, k  
    if (knode(kk) .eq. node(i) .and. kdir(kk) .eq. idir(i))  
  + go to 40  
35 continue  
  k = k + 1  
  knode(k) = node(i)  
  kdir(k) = idir(i)  
40 continue  
kount = k
```

```
c  
c  
c  
zero node/direction pair amplitudes
```

```
do 50 k = 1, kount  
  do 45 j = 1, npoint  
    amp(k,j) = 0.0  
45 continue  
50 continue
```

```
c  
c  
c  
envelope amplitudes for node/direction pairs
```

```
do 70 i = 1, nspec  
  do 65 k = 1, kount  
    if (knode(k) .eq. node(i) .and. kdir(k) .eq. idir(i))  
  + go to 55  
    go to 65  
55 continue  
  do 60 j = 1, npoint  
    if (a(i, j*2) .gt. amp(k, j)) amp(k, j)=a(i, j*2)  
60 continue  
  go to 70
```

65 continue  
70 continue

C  
C  
C

identify nodes

l = 1  
lnode(1) = knode(1)  
do 80 k = 1, kount  
do 75 ll = 1, 1  
if (lnode(ll) .eq. knode(k)) go to 80  
75 continue  
l = l + 1  
lnode(l) = knode(k)  
80 continue  
lount=1

C  
C  
C  
C

write enveloped spectra to tape03.dat in PISTAR format  
and to tape04.dat in RESGEN format

do 90 l = 1, lount  
write( 3, 3001 ) lnode(1)  
write( 3, 3002 )  
write( 3, 3003 )  
do 85 k = 1, kount  
if (lnode(l) .ne. knode(k)) go to 85  
write( 3, 3005 ) kdir(k), a(1, 1), amp(k, 1),  
+ a(1, 3), amp(k, 2)  
write( 3, 3006 ) (a(1, j\*2-1), amp(k, j)), j = 3, npoint)  
write( 4, 4001 ) (a(1, j\*2-1), amp(k, j)), j = 1, npoint)  
85 continue  
90 continue

C  
C  
C  
C  
C

write enveloped spectra to output tape06.dat

write(6, '(a1 /)') '1'  
do 100 l = 1, lount  
write( 6, 6006 ) lnode(1)  
write( 6, 6007 )  
write( 6, 6008 )  
do 95 k = 1, kount  
if (lnode(l) .ne. knode(k)) go to 95  
write( 6, 6009 ) kdir(k), a(1, 1), amp(k, 1),  
+ a(1, 3), amp(k, 2)  
write( 6, 6010 ) (a(1, j\*2-1), amp(k, j)), j = 3, npoint)  
95 continue  
100 continue  
goto 999

C  
C  
C

write error messages

801 write(6, 6904) 'tape01.dat'  
stop  
802 write(6, 6904) 'tape02.dat'  
stop

```
803 write(6, 6905) 'tape03.dat'
stop
804 write(6, 6905) 'tape04.dat'
stop
805 write(6, 6904) 'tape05.dat'
stop
806 write(6, 6905) 'tape06.dat'
stop
807 write(6, 6904) 'qablok.dat'
stop

c
1000 format(i5, 5x, 2i5)
1001 format( a72 )
1002 format(32x, a5, 2x, a1, 1x, a4, 6x, i2)

c
2001 format(8f10.0)

c
6001 format('1' /// 5x, 'ENVELOPE --- VERSION 1.0.0' //
+ 5x, 'SOURCE CODE' // )
6002 format(5x, a72)
6003 format(// 5x, 'NO. OF SPECTRA = ', i3 /
+ 5x, 'NO. OF FREQUENCY POINTS = ', i3 / )
6004 format(5x, 'SPECTRA', 25x, 'LOAD' / 4x, 'NO', 5x, 'NODE',
+ 3x, 'DIR', 4x, 'TYPE', 4x, 'CASE')
6005 format(1x, i5, 5x, a5, 3x, a1, 5x, a4, 5x, i2)
6006 format(// 5x, 'COMMENT', 3x, 'NODE = ', a5, 5x,
+ 'ACCELERATION SPECTRA')
6007 format(5x, 'CASE', 6x, 'XXXXX')
6008 format(5x, 'SEISMIC', 7x, '1', 10x, '386.4', 5x, '386.4',
+ 5x, '386.4', 7x, 'CSM', 7x, 'RSS')
6009 format(5x, a1, '-SHOCK', 9x, 'FREQ', 5x, 'ACCEL', 4F10.3)
6010 format(5x, 16x, 'FREQ', 5x, 'ACCEL', 4F10.3)

c
3001 format(// 'COMMENT', 3x, 'NODE = ', a5, 5x,
+ 'ACCELERATION SPECTRA')
3002 format('CASE', 6x, 'XXXXX')
3003 format('SEISMIC', 7x, '1', 10x, '386.4', 5x, '386.4',
+ 5x, '386.4', 7x, 'CSM', 7x, 'RSS')
3005 format( a1, '-SHOCK', 9x, 'FREQ', 5x, 'ACCEL', 4F10.3)
3006 format( 16x, 'FREQ', 5x, 'ACCEL', 4F10.3)

c
4001 format(8f10.3)

c
6901 format(5x, 'ERROR...NSPEC = ', i5, ' > 200 (INTERNAL LIMIT)')
6902 format(5x, 'ERROR...NPOINT = ', i5, ' > 70 (INTERNAL LIMIT)')
6903 format(5x, 'ERROR...FREQUENCY POINTS NOT UNIFORM')
6904 format(5x, 'ERROR...INPUT FILE -> ', a10, 'IS MISSING.' )
6905 format(5x, 'ERROR...UNABLE TO OPEN OUTPUT FILE -> ', a10)

c
7001 format( a80 )
7002 format(10x, a80 )
999 stop
end
```

COMMENT  
 CASE  
 SEISMIC  
 X-SHOCK

NODE = 54BR  
 XXXXX

ACCELERATION SPECTRA

CHUGI

	1	386.4	386.4	386.4	CSM	RSS
FREQ	ACCEL	1.000	0.003	2.000	0.005	
FREQ	ACCEL	3.000	0.008	4.000	0.011	
FREQ	ACCEL	4.100	0.012	4.200	0.012	
FREQ	ACCEL	4.300	0.012	4.400	0.012	
FREQ	ACCEL	4.500	0.013	4.600	0.013	
FREQ	ACCEL	4.700	0.014	4.800	0.014	
FREQ	ACCEL	4.900	0.015	5.000	0.015	
FREQ	ACCEL	5.100	0.016	5.200	0.016	
FREQ	ACCEL	5.300	0.017	5.400	0.017	
FREQ	ACCEL	5.500	0.018	5.600	0.019	
FREQ	ACCEL	5.700	0.019	5.800	0.020	
FREQ	ACCEL	5.900	0.020	6.000	0.021	
FREQ	ACCEL	6.100	0.022	6.200	0.022	
FREQ	ACCEL	6.300	0.023	6.400	0.023	
FREQ	ACCEL	6.500	0.024	6.600	0.025	
FREQ	ACCEL	6.700	0.025	6.800	0.026	
FREQ	ACCEL	6.900	0.027	7.000	0.027	
FREQ	ACCEL	7.100	0.028	7.200	0.029	
FREQ	ACCEL	7.300	0.030	7.400	0.030	
FREQ	ACCEL	7.500	0.031	7.600	0.032	
FREQ	ACCEL	7.700	0.032	7.800	0.033	
FREQ	ACCEL	7.900	0.034	8.000	0.035	
FREQ	ACCEL	8.100	0.035	8.200	0.036	
FREQ	ACCEL	8.300	0.037	8.400	0.038	
FREQ	ACCEL	8.500	0.038	8.600	0.039	
FREQ	ACCEL	8.700	0.040	8.800	0.041	
FREQ	ACCEL	8.900	0.041	9.000	0.042	
FREQ	ACCEL	9.100	0.043	9.200	0.044	
FREQ	ACCEL	9.300	0.044	9.400	0.045	
FREQ	ACCEL	9.500	0.046	9.600	0.047	
FREQ	ACCEL	9.700	0.047	9.800	0.048	
FREQ	ACCEL	9.900	0.049	10.000	0.050	
FREQ	ACCEL	10.100	0.050	10.200	0.051	
FREQ	ACCEL	10.300	0.052	10.400	0.052	
FREQ	ACCEL	10.500	0.053	10.600	0.054	
FREQ	ACCEL	10.700	0.055	10.800	0.055	
FREQ	ACCEL	10.900	0.056	11.000	0.057	
FREQ	ACCEL	11.100	0.058	11.200	0.058	
FREQ	ACCEL	11.300	0.060	11.400	0.062	
FREQ	ACCEL	11.500	0.064	11.600	0.066	
FREQ	ACCEL	11.700	0.067	11.800	0.069	
FREQ	ACCEL	11.900	0.071	12.000	0.073	
FREQ	ACCEL	12.100	0.075	12.200	0.077	
FREQ	ACCEL	12.300	0.079	12.400	0.080	
FREQ	ACCEL	12.500	0.081	12.600	0.082	
FREQ	ACCEL	12.700	0.083	12.800	0.084	
FREQ	ACCEL	12.900	0.087	13.000	0.089	
FREQ	ACCEL	13.100	0.099	13.200	0.105	
FREQ	ACCEL	13.300	0.111	13.400	0.115	
FREQ	ACCEL	13.500	0.116	13.600	0.115	
FREQ	ACCEL	13.700	0.115	13.800	0.111	



FREQ	ACCEL	13.900	0.109	14.000	0.113
FREQ	ACCEL	14.100	0.114	14.200	0.118
FREQ	ACCEL	14.300	0.120	14.400	0.124
FREQ	ACCEL	14.500	0.127	14.600	0.129
FREQ	ACCEL	14.700	0.135	14.800	0.157
FREQ	ACCEL	14.900	0.175	15.000	0.189
FREQ	ACCEL	15.100	0.200	15.200	0.223
FREQ	ACCEL	15.300	0.241	15.400	0.255
FREQ	ACCEL	15.500	0.266	15.600	0.273
FREQ	ACCEL	15.700	0.278	15.800	0.275
FREQ	ACCEL	15.900	0.273	16.000	0.311
FREQ	ACCEL	16.100	0.323	16.200	0.315
FREQ	ACCEL	16.300	0.289	16.400	0.265
FREQ	ACCEL	16.500	0.243	16.600	0.220
FREQ	ACCEL	16.700	0.202	16.800	0.191
FREQ	ACCEL	16.900	0.190	17.000	0.194
FREQ	ACCEL	17.100	0.198	17.200	0.192
FREQ	ACCEL	17.300	0.181	17.400	0.167
FREQ	ACCEL	17.500	0.159	17.600	0.153
FREQ	ACCEL	17.700	0.155	17.800	0.157
FREQ	ACCEL	17.900	0.159	18.000	0.161
FREQ	ACCEL	18.100	0.162	18.200	0.164
FREQ	ACCEL	18.300	0.166	18.400	0.167
FREQ	ACCEL	18.500	0.169	18.600	0.170
FREQ	ACCEL	18.700	0.171	18.800	0.173
FREQ	ACCEL	18.900	0.176	19.000	0.178
FREQ	ACCEL	19.100	0.180	19.200	0.183
FREQ	ACCEL	19.300	0.185	19.400	0.187
FREQ	ACCEL	19.500	0.189	19.600	0.191
FREQ	ACCEL	19.700	0.193	19.800	0.195
FREQ	ACCEL	19.900	0.197	20.000	0.200
FREQ	ACCEL	20.100	0.204	20.200	0.208
FREQ	ACCEL	20.300	0.212	20.400	0.216
FREQ	ACCEL	20.500	0.220	20.600	0.224
FREQ	ACCEL	20.700	0.227	20.800	0.231
FREQ	ACCEL	20.900	0.234	21.000	0.237
FREQ	ACCEL	21.100	0.241	21.200	0.243
FREQ	ACCEL	21.300	0.246	21.400	0.249
FREQ	ACCEL	21.500	0.252	21.600	0.254
FREQ	ACCEL	21.700	0.256	21.800	0.258
FREQ	ACCEL	21.900	0.260	22.000	0.262
FREQ	ACCEL	22.100	0.266	22.200	0.271
FREQ	ACCEL	22.300	0.274	22.400	0.278
FREQ	ACCEL	22.500	0.282	22.600	0.285
FREQ	ACCEL	22.700	0.289	22.800	0.292
FREQ	ACCEL	22.900	0.296	23.000	0.300
FREQ	ACCEL	23.100	0.304	23.200	0.307
FREQ	ACCEL	23.300	0.310	23.400	0.318
FREQ	ACCEL	23.500	0.326	23.600	0.334
FREQ	ACCEL	23.700	0.341	23.800	0.349
FREQ	ACCEL	23.900	0.361	24.000	0.373
FREQ	ACCEL	24.100	0.385	24.200	0.395
FREQ	ACCEL	24.300	0.405	24.400	0.414
FREQ	ACCEL	24.500	0.423	24.600	0.437
FREQ	ACCEL	24.700	0.451	24.800	0.464
FREQ	ACCEL	24.900	0.476	25.000	0.487

FREQ	ACCEL	25.100	0.496	25.200	0.509
FREQ	ACCEL	25.300	0.519	25.400	0.531
FREQ	ACCEL	25.500	0.531	25.600	0.545
FREQ	ACCEL	25.700	0.558	25.800	0.571
FREQ	ACCEL	25.900	0.581	26.000	0.591
FREQ	ACCEL	26.100	0.601	26.200	0.618
FREQ	ACCEL	26.300	0.676	26.400	0.714
FREQ	ACCEL	26.500	0.720	26.600	0.707
FREQ	ACCEL	26.700	0.703	26.800	0.738
FREQ	ACCEL	26.900	0.831	27.000	0.978
FREQ	ACCEL	27.100	1.153	27.200	1.308
FREQ	ACCEL	27.300	1.483	27.400	1.612
FREQ	ACCEL	27.500	1.652	27.600	1.665
FREQ	ACCEL	27.700	1.622	27.800	1.541
FREQ	ACCEL	27.900	1.410	28.000	1.288
FREQ	ACCEL	28.100	1.184	28.200	1.133
FREQ	ACCEL	28.300	1.144	28.400	1.184
FREQ	ACCEL	28.500	1.285	28.600	1.361
FREQ	ACCEL	28.700	1.379	28.800	1.351
FREQ	ACCEL	28.900	1.320	29.000	1.228
FREQ	ACCEL	29.100	1.113	29.200	1.011
FREQ	ACCEL	29.300	0.948	29.400	0.930
FREQ	ACCEL	29.500	0.944	29.600	0.986
FREQ	ACCEL	29.700	1.016	29.800	1.022
FREQ	ACCEL	29.900	1.003	30.000	0.973
FREQ	ACCEL	31.000	0.715	32.000	0.559
FREQ	ACCEL	33.000	0.510	34.000	0.467
FREQ	ACCEL	35.000	0.428	36.000	0.408
FREQ	ACCEL	37.000	0.394	38.000	0.398
FREQ	ACCEL	39.000	0.391	40.000	0.375
FREQ	ACCEL	41.000	0.356	42.000	0.350
FREQ	ACCEL	43.000	0.392	44.000	0.396
FREQ	ACCEL	45.000	0.330	46.000	0.331
FREQ	ACCEL	47.000	0.330	48.000	0.340
FREQ	ACCEL	49.000	0.374	50.000	0.404
FREQ	ACCEL	51.000	0.364	52.000	0.373
FREQ	ACCEL	53.000	0.394	54.000	0.460
FREQ	ACCEL	55.000	0.312	56.000	0.266
FREQ	ACCEL	57.000	0.262	58.000	0.257
FREQ	ACCEL	59.000	0.251	60.000	0.244
FREQ	ACCEL	1.000	0.000	2.000	0.001
FREQ	ACCEL	3.000	0.001	4.000	0.002
FREQ	ACCEL	4.100	0.002	4.200	0.003
FREQ	ACCEL	4.300	0.003	4.400	0.003
FREQ	ACCEL	4.500	0.003	4.600	0.003
FREQ	ACCEL	4.700	0.003	4.800	0.003
FREQ	ACCEL	4.900	0.004	5.000	0.004
FREQ	ACCEL	5.100	0.004	5.200	0.004
FREQ	ACCEL	5.300	0.004	5.400	0.004
FREQ	ACCEL	5.500	0.004	5.600	0.005
FREQ	ACCEL	5.700	0.005	5.800	0.005
FREQ	ACCEL	5.900	0.005	6.000	0.005
FREQ	ACCEL	6.100	0.005	6.200	0.006
FREQ	ACCEL	6.300	0.006	6.400	0.006
FREQ	ACCEL	6.500	0.006	6.600	0.006
FREQ	ACCEL	6.700	0.006	6.800	0.007

Y-SHOCK

FREQ	ACCEL	6.900	0.007	7.000	0.007
FREQ	ACCEL	7.100	0.007	7.200	0.007
FREQ	ACCEL	7.300	0.008	7.400	0.008
FREQ	ACCEL	7.500	0.008	7.600	0.008
FREQ	ACCEL	7.700	0.009	7.800	0.010
FREQ	ACCEL	7.900	0.010	8.000	0.009
FREQ	ACCEL	8.100	0.009	8.200	0.010
FREQ	ACCEL	8.300	0.010	8.400	0.010
FREQ	ACCEL	8.500	0.010	8.600	0.010
FREQ	ACCEL	8.700	0.010	8.800	0.011
FREQ	ACCEL	8.900	0.011	9.000	0.011
FREQ	ACCEL	9.100	0.012	9.200	0.012
FREQ	ACCEL	9.300	0.012	9.400	0.013
FREQ	ACCEL	9.500	0.013	9.600	0.014
FREQ	ACCEL	9.700	0.014	9.800	0.015
FREQ	ACCEL	9.900	0.015	10.000	0.015
FREQ	ACCEL	10.100	0.016	10.200	0.016
FREQ	ACCEL	10.300	0.017	10.400	0.017
FREQ	ACCEL	10.500	0.017	10.600	0.018
FREQ	ACCEL	10.700	0.018	10.800	0.019
FREQ	ACCEL	10.900	0.019	11.000	0.020
FREQ	ACCEL	11.100	0.021	11.200	0.021
FREQ	ACCEL	11.300	0.022	11.400	0.022
FREQ	ACCEL	11.500	0.023	11.600	0.023
FREQ	ACCEL	11.700	0.024	11.800	0.024
FREQ	ACCEL	11.900	0.025	12.000	0.026
FREQ	ACCEL	12.100	0.026	12.200	0.027
FREQ	ACCEL	12.300	0.028	12.400	0.028
FREQ	ACCEL	12.500	0.029	12.600	0.030
FREQ	ACCEL	12.700	0.030	12.800	0.031
FREQ	ACCEL	12.900	0.032	13.000	0.032
FREQ	ACCEL	13.100	0.033	13.200	0.034
FREQ	ACCEL	13.300	0.034	13.400	0.035
FREQ	ACCEL	13.500	0.036	13.600	0.037
FREQ	ACCEL	13.700	0.037	13.800	0.038
FREQ	ACCEL	13.900	0.039	14.000	0.040
FREQ	ACCEL	14.100	0.040	14.200	0.041
FREQ	ACCEL	14.300	0.042	14.400	0.043
FREQ	ACCEL	14.500	0.044	14.600	0.045
FREQ	ACCEL	14.700	0.045	14.800	0.046
FREQ	ACCEL	14.900	0.047	15.000	0.048
FREQ	ACCEL	15.100	0.049	15.200	0.050
FREQ	ACCEL	15.300	0.050	15.400	0.051
FREQ	ACCEL	15.500	0.052	15.600	0.053
FREQ	ACCEL	15.700	0.054	15.800	0.055
FREQ	ACCEL	15.900	0.056	16.000	0.057
FREQ	ACCEL	16.100	0.058	16.200	0.059
FREQ	ACCEL	16.300	0.060	16.400	0.061
FREQ	ACCEL	16.500	0.061	16.600	0.062
FREQ	ACCEL	16.700	0.063	16.800	0.064
FREQ	ACCEL	16.900	0.065	17.000	0.066
FREQ	ACCEL	17.100	0.067	17.200	0.068
FREQ	ACCEL	17.300	0.069	17.400	0.070
FREQ	ACCEL	17.500	0.071	17.600	0.072
FREQ	ACCEL	17.700	0.073	17.800	0.074
FREQ	ACCEL	17.900	0.075	18.000	0.076

FREQ	ACCEL	18.100	0.077	18.200	0.078
FREQ	ACCEL	18.300	0.079	18.400	0.080
FREQ	ACCEL	18.500	0.081	18.600	0.082
FREQ	ACCEL	18.700	0.083	18.800	0.084
FREQ	ACCEL	18.900	0.085	19.000	0.086
FREQ	ACCEL	19.100	0.087	19.200	0.088
FREQ	ACCEL	19.300	0.089	19.400	0.090
FREQ	ACCEL	19.500	0.091	19.600	0.092
FREQ	ACCEL	19.700	0.093	19.800	0.094
FREQ	ACCEL	19.900	0.095	20.000	0.096
FREQ	ACCEL	20.100	0.097	20.200	0.098
FREQ	ACCEL	20.300	0.099	20.400	0.100
FREQ	ACCEL	20.500	0.101	20.600	0.102
FREQ	ACCEL	20.700	0.105	20.800	0.108
FREQ	ACCEL	20.900	0.111	21.000	0.113
FREQ	ACCEL	21.100	0.116	21.200	0.118
FREQ	ACCEL	21.300	0.121	21.400	0.123
FREQ	ACCEL	21.500	0.126	21.600	0.128
FREQ	ACCEL	21.700	0.130	21.800	0.133
FREQ	ACCEL	21.900	0.135	22.000	0.137
FREQ	ACCEL	22.100	0.142	22.200	0.146
FREQ	ACCEL	22.300	0.151	22.400	0.155
FREQ	ACCEL	22.500	0.159	22.600	0.163
FREQ	ACCEL	22.700	0.167	22.800	0.171
FREQ	ACCEL	22.900	0.175	23.000	0.178
FREQ	ACCEL	23.100	0.182	23.200	0.185
FREQ	ACCEL	23.300	0.189	23.400	0.192
FREQ	ACCEL	23.500	0.196	23.600	0.202
FREQ	ACCEL	23.700	0.207	23.800	0.213
FREQ	ACCEL	23.900	0.218	24.000	0.222
FREQ	ACCEL	24.100	0.231	24.200	0.235
FREQ	ACCEL	24.300	0.237	24.400	0.244
FREQ	ACCEL	24.500	0.251	24.600	0.258
FREQ	ACCEL	24.700	0.264	24.800	0.269
FREQ	ACCEL	24.900	0.275	25.000	0.291
FREQ	ACCEL	25.100	0.320	25.200	0.333
FREQ	ACCEL	25.300	0.348	25.400	0.354
FREQ	ACCEL	25.500	0.347	25.600	0.324
FREQ	ACCEL	25.700	0.332	25.800	0.339
FREQ	ACCEL	25.900	0.349	26.000	0.358
FREQ	ACCEL	26.100	0.365	26.200	0.376
FREQ	ACCEL	26.300	0.417	26.400	0.442
FREQ	ACCEL	26.500	0.452	26.600	0.447
FREQ	ACCEL	26.700	0.442	26.800	0.449
FREQ	ACCEL	26.900	0.487	27.000	0.558
FREQ	ACCEL	27.100	0.649	27.200	0.746
FREQ	ACCEL	27.300	0.849	27.400	0.924
FREQ	ACCEL	27.500	0.962	27.600	0.969
FREQ	ACCEL	27.700	0.950	27.800	0.893
FREQ	ACCEL	27.900	0.803	28.000	0.720
FREQ	ACCEL	28.100	0.651	28.200	0.616
FREQ	ACCEL	28.300	0.621	28.400	0.655
FREQ	ACCEL	28.500	0.718	28.600	0.769
FREQ	ACCEL	28.700	0.784	28.800	0.765
FREQ	ACCEL	28.900	0.747	29.000	0.694
FREQ	ACCEL	29.100	0.631	29.200	0.578

FREQ	ACCEL	29.300	0.551	29.400	0.553
FREQ	ACCEL	29.500	0.573	29.600	0.601
FREQ	ACCEL	29.700	0.617	29.800	0.623
FREQ	ACCEL	29.900	0.614	30.000	0.581
FREQ	ACCEL	31.000	0.510	32.000	0.390
FREQ	ACCEL	33.000	0.403	34.000	0.428
FREQ	ACCEL	35.000	0.438	36.000	0.455
FREQ	ACCEL	37.000	0.486	38.000	0.503
FREQ	ACCEL	39.000	0.510	40.000	0.495
FREQ	ACCEL	41.000	0.587	42.000	0.595
FREQ	ACCEL	43.000	0.969	44.000	1.015
FREQ	ACCEL	45.000	0.842	46.000	0.731
FREQ	ACCEL	47.000	0.936	48.000	0.923
FREQ	ACCEL	49.000	1.018	50.000	1.240
FREQ	ACCEL	51.000	0.935	52.000	1.168
FREQ	ACCEL	53.000	1.088	54.000	1.191
FREQ	ACCEL	55.000	0.889	56.000	0.621
FREQ	ACCEL	57.000	0.465	58.000	0.476
FREQ	ACCEL	59.000	0.416	60.000	0.412
FREQ	ACCEL	1.000	0.000	2.000	0.000
FREQ	ACCEL	3.000	0.001	4.000	0.001
FREQ	ACCEL	4.100	0.001	4.200	0.001
FREQ	ACCEL	4.300	0.001	4.400	0.001
FREQ	ACCEL	4.500	0.001	4.600	0.001
FREQ	ACCEL	4.700	0.001	4.800	0.001
FREQ	ACCEL	4.900	0.001	5.000	0.001
FREQ	ACCEL	5.100	0.002	5.200	0.002
FREQ	ACCEL	5.300	0.002	5.400	0.002
FREQ	ACCEL	5.500	0.002	5.600	0.002
FREQ	ACCEL	5.700	0.002	5.800	0.002
FREQ	ACCEL	5.900	0.002	6.000	0.002
FREQ	ACCEL	6.100	0.002	6.200	0.002
FREQ	ACCEL	6.300	0.002	6.400	0.002
FREQ	ACCEL	6.500	0.002	6.600	0.002
FREQ	ACCEL	6.700	0.003	6.800	0.003
FREQ	ACCEL	6.900	0.003	7.000	0.003
FREQ	ACCEL	7.100	0.003	7.200	0.003
FREQ	ACCEL	7.300	0.003	7.400	0.003
FREQ	ACCEL	7.500	0.003	7.600	0.003
FREQ	ACCEL	7.700	0.003	7.800	0.003
FREQ	ACCEL	7.900	0.003	8.000	0.004
FREQ	ACCEL	8.100	0.004	8.200	0.004
FREQ	ACCEL	8.300	0.004	8.400	0.004
FREQ	ACCEL	8.500	0.004	8.600	0.004
FREQ	ACCEL	8.700	0.004	8.800	0.004
FREQ	ACCEL	8.900	0.004	9.000	0.004
FREQ	ACCEL	9.100	0.005	9.200	0.005
FREQ	ACCEL	9.300	0.005	9.400	0.005
FREQ	ACCEL	9.500	0.005	9.600	0.005
FREQ	ACCEL	9.700	0.005	9.800	0.005
FREQ	ACCEL	9.900	0.005	10.000	0.005
FREQ	ACCEL	10.100	0.006	10.200	0.006
FREQ	ACCEL	10.300	0.006	10.400	0.006
FREQ	ACCEL	10.500	0.006	10.600	0.006
FREQ	ACCEL	10.700	0.006	10.800	0.006
FREQ	ACCEL	10.900	0.006	11.000	0.006

Z-SHOCK

FREQ	ACCEL	11.100	0.007	11.200	0.007
FREQ	ACCEL	11.300	0.007	11.400	0.007
FREQ	ACCEL	11.500	0.007	11.600	0.007
FREQ	ACCEL	11.700	0.008	11.800	0.008
FREQ	ACCEL	11.900	0.008	12.000	0.008
FREQ	ACCEL	12.100	0.008	12.200	0.008
FREQ	ACCEL	12.300	0.008	12.400	0.009
FREQ	ACCEL	12.500	0.009	12.600	0.009
FREQ	ACCEL	12.700	0.009	12.800	0.010
FREQ	ACCEL	12.900	0.010	13.000	0.010
FREQ	ACCEL	13.100	0.010	13.200	0.011
FREQ	ACCEL	13.300	0.011	13.400	0.011
FREQ	ACCEL	13.500	0.011	13.600	0.012
FREQ	ACCEL	13.700	0.012	13.800	0.013
FREQ	ACCEL	13.900	0.013	14.000	0.014
FREQ	ACCEL	14.100	0.014	14.200	0.014
FREQ	ACCEL	14.300	0.014	14.400	0.014
FREQ	ACCEL	14.500	0.015	14.600	0.017
FREQ	ACCEL	14.700	0.018	14.800	0.020
FREQ	ACCEL	14.900	0.024	15.000	0.027
FREQ	ACCEL	15.100	0.029	15.200	0.028
FREQ	ACCEL	15.300	0.031	15.400	0.032
FREQ	ACCEL	15.500	0.034	15.600	0.036
FREQ	ACCEL	15.700	0.037	15.800	0.038
FREQ	ACCEL	15.900	0.038	16.000	0.042
FREQ	ACCEL	16.100	0.046	16.200	0.046
FREQ	ACCEL	16.300	0.045	16.400	0.041
FREQ	ACCEL	16.500	0.036	16.600	0.033
FREQ	ACCEL	16.700	0.029	16.800	0.026
FREQ	ACCEL	16.900	0.024	17.000	0.024
FREQ	ACCEL	17.100	0.025	17.200	0.026
FREQ	ACCEL	17.300	0.027	17.400	0.026
FREQ	ACCEL	17.500	0.024	17.600	0.025
FREQ	ACCEL	17.700	0.025	17.800	0.025
FREQ	ACCEL	17.900	0.026	18.000	0.026
FREQ	ACCEL	18.100	0.027	18.200	0.027
FREQ	ACCEL	18.300	0.027	18.400	0.028
FREQ	ACCEL	18.500	0.028	18.600	0.028
FREQ	ACCEL	18.700	0.029	18.800	0.029
FREQ	ACCEL	18.900	0.030	19.000	0.030
FREQ	ACCEL	19.100	0.030	19.200	0.031
FREQ	ACCEL	19.300	0.031	19.400	0.032
FREQ	ACCEL	19.500	0.032	19.600	0.032
FREQ	ACCEL	19.700	0.033	19.800	0.033
FREQ	ACCEL	19.900	0.033	20.000	0.034
FREQ	ACCEL	20.100	0.034	20.200	0.035
FREQ	ACCEL	20.300	0.035	20.400	0.035
FREQ	ACCEL	20.500	0.036	20.600	0.036
FREQ	ACCEL	20.700	0.036	20.800	0.037
FREQ	ACCEL	20.900	0.037	21.000	0.038
FREQ	ACCEL	21.100	0.038	21.200	0.038
FREQ	ACCEL	21.300	0.039	21.400	0.039
FREQ	ACCEL	21.500	0.039	21.600	0.040
FREQ	ACCEL	21.700	0.040	21.800	0.040
FREQ	ACCEL	21.900	0.041	22.000	0.041
FREQ	ACCEL	22.100	0.042	22.200	0.043

FREQ	ACCEL	22.300	0.043	22.400	0.044
FREQ	ACCEL	22.500	0.045	22.600	0.046
FREQ	ACCEL	22.700	0.047	22.800	0.048
FREQ	ACCEL	22.900	0.048	23.000	0.049
FREQ	ACCEL	23.100	0.050	23.200	0.051
FREQ	ACCEL	23.300	0.052	23.400	0.053
FREQ	ACCEL	23.500	0.053	23.600	0.054
FREQ	ACCEL	23.700	0.055	23.800	0.056
FREQ	ACCEL	23.900	0.057	24.000	0.058
FREQ	ACCEL	24.100	0.063	24.200	0.069
FREQ	ACCEL	24.300	0.071	24.400	0.068
FREQ	ACCEL	24.500	0.066	24.600	0.069
FREQ	ACCEL	24.700	0.071	24.800	0.073
FREQ	ACCEL	24.900	0.075	25.000	0.077
FREQ	ACCEL	25.100	0.079	25.200	0.080
FREQ	ACCEL	25.300	0.081	25.400	0.083
FREQ	ACCEL	25.500	0.084	25.600	0.085
FREQ	ACCEL	25.700	0.087	25.800	0.088
FREQ	ACCEL	25.900	0.091	26.000	0.093
FREQ	ACCEL	26.100	0.096	26.200	0.100
FREQ	ACCEL	26.300	0.104	26.400	0.109
FREQ	ACCEL	26.500	0.109	26.600	0.112
FREQ	ACCEL	26.700	0.116	26.800	0.123
FREQ	ACCEL	26.900	0.132	27.000	0.159
FREQ	ACCEL	27.100	0.187	27.200	0.211
FREQ	ACCEL	27.300	0.233	27.400	0.257
FREQ	ACCEL	27.500	0.263	27.600	0.271
FREQ	ACCEL	27.700	0.264	27.800	0.256
FREQ	ACCEL	27.900	0.234	28.000	0.204
FREQ	ACCEL	28.100	0.183	28.200	0.170
FREQ	ACCEL	28.300	0.168	28.400	0.164
FREQ	ACCEL	28.500	0.165	28.600	0.173
FREQ	ACCEL	28.700	0.172	28.800	0.172
FREQ	ACCEL	28.900	0.167	29.000	0.152
FREQ	ACCEL	29.100	0.135	29.200	0.134
FREQ	ACCEL	29.300	0.133	29.400	0.132
FREQ	ACCEL	29.500	0.129	29.600	0.128
FREQ	ACCEL	29.700	0.129	29.800	0.129
FREQ	ACCEL	29.900	0.128	30.000	0.127
FREQ	ACCEL	31.000	0.121	32.000	0.131
FREQ	ACCEL	33.000	0.140	34.000	0.153
FREQ	ACCEL	35.000	0.155	36.000	0.181
FREQ	ACCEL	37.000	0.267	38.000	0.345
FREQ	ACCEL	39.000	0.463	40.000	0.315
FREQ	ACCEL	41.000	0.263	42.000	0.218
FREQ	ACCEL	43.000	0.249	44.000	0.224
FREQ	ACCEL	45.000	0.200	46.000	0.189
FREQ	ACCEL	47.000	0.212	48.000	0.205
FREQ	ACCEL	49.000	0.304	50.000	0.371
FREQ	ACCEL	51.000	0.434	52.000	0.665
FREQ	ACCEL	53.000	0.600	54.000	0.535
FREQ	ACCEL	55.000	0.393	56.000	0.269
FREQ	ACCEL	57.000	0.196	58.000	0.197
FREQ	ACCEL	59.000	0.153	60.000	0.155

COVER PAGE

COI

INODE SABR

REVISION P71-1 PAGE 30/43  
PREPARED BY AM 6/3/93  
CHECKED BY AOS-mlwat  
6/3/93







```
write( 6, 6003 ) nspec, npoint
np2 = npoint*2
write(6, 6004)
do 20 i = 1, nspec
  read( 1, 1002 ) node(i), idir(i), type, icase
  write(6, 6005 ) i, node(i), idir(i), type, icase
  if ( i .gt. 50) write(6, '(a1 ///)' ) '1'
20 continue
c
c read spectra from tape2
c
do 30 i = 1, nspec
  read( 2, 2001 ) ( a(i,j), j = 1, np2 )
  do 30 j = 1, npoint
    if ( a(i, j*2-1) .eq. a(1, j*2-1) ) go to 25
    write( 6, 6902 )
    go to 999
25 continue
30 continue
c
c Identify Node/Direction Pairs
c
k = 1
knode(1) = node(1)
kdir(1) = idir(1)
do 40 i = 1, nspec
  do 35 kk = 1, k
    if (knode(kk) .eq. node(i) .and. kdir(kk) .eq. idir(i))
+ go to 40
35 continue
  k = k + 1
  knode(k) = node(i)
  kdir(k) = idir(i)
40 continue
kount = k
c
c zero node/direction pair amplitudes
c
do 50 k = 1, kount
  do 45 j = 1, npoint
    amp(k,j) = 0.0
45 continue
50 continue
c
c envelope amplitudes for node/direction pairs
c
do 70 i = 1, nspec
  do 65 k = 1, kount
    if (knode(k) .eq. node(i) .and. kdir(k) .eq. idir(i))
+ go to 55
  go to 65
55 continue
  do 60 j = 1, npoint
    if (a(i, j*2) .gt. amp(k, j)) amp(k, j)=a(i, j*2)
60 continue
  go to 70
```

```
65 continue
70 continue
c
c identify nodes
c
  l = 1
  lnode(1) = knode(1)
  do 80 k = 1, kount
    do 75 ll = 1, l...
      if (lnode(ll) .eq. knode(k)) go to 80
75 continue
  l = l + 1
  lnode(l) = knode(k)
80 continue
  lount=l
c
c write enveloped spectra to tape03.dat in PISTAR format
c and to tape04.dat in RESGEN format
c
  do 90 l = 1, lount
    write( 3, 3001 ) lnode(l)
    write( 3, 3002 )
    write( 3, 3003 )
    do 85 k = 1, kount
      if (lnode(l) .ne. knode(k)) go to 85
      write( 3, 3005 ) kdir(k), a(1, 1), amp(k, 1),
+         a(1, 3), amp(k, 2)
      write( 3, 3006 ) (a(1, j*2-1), amp(k, j)), j = 3, npoint)
      write( 4, 4001 ) (a(1, j*2-1), amp(k, j)), j = 1, npoint)
85 continue
90 continue
c
c write enveloped spectra to output tape06.dat
c
c
  write(6, '(a1 /)' ) '1'
  do 100 l = 1, lount
    write( 6, 6006 ) lnode(l)
    write( 6, 6007 )
    write( 6, 6008 )
    do 95 k = 1, kount
      if (lnode(l) .ne. knode(k)) go to 95
      write( 6, 6009 ) kdir(k), a(1, 1), amp(k, 1),
+         a(1, 3), amp(k, 2)
      write( 6, 6010 ) (a(1, j*2-1), amp(k, j)), j = 3, npoint)
95 continue
100 continue
  goto 999
c
c write error messages
c
801 write(6, 6904) 'tape01.dat'
  stop
802 write(6, 6904) 'tape02.dat'
  stop
```

```
803 write(6, 6905) 'tape03.dat'
stop
804 write(6, 6905) 'tape04.dat'
stop
805 write(6, 6904) 'tape05.dat'
stop
806 write(6, 6905) 'tape06.dat'
stop
807 write(6, 6904) 'qablok.dat'
stop

C
1000 format(i5, 5x, 2i5)
1001 format( a72 )
1002 format(32x, a5, 2x, a1, 1x, a4, 6x, i2)

C
2001 format(8f10.0)

C
6001 format('1' /// 5x, 'ENVELOPE --- VERSION 1.0.0' //
+ 5x, 'SOURCE CODE' // )
6002 format(5x, a72)
6003 format(// 5x, 'NO. OF SPECTRA = ', i3 /
+ 5x, 'NO. OF FREQUENCY POINTS = ', i3 / )
6004 format(5x, 'SPECTRA', 25x, 'LOAD' / 4x, 'NO', 5x, 'NODE',
+ 3x, 'DIR', 4x, 'TYPE', 4x, 'CASE')
6005 format(1x, i5, 5x, a5, 3x, a1, 5x, a4, 5x, i2)
6006 format(// 5x, 'COMMENT', 3x, 'NODE = ', a5, 5x,
+ 'ACCELERATION SPECTRA')
6007 format(5x, 'CASE', 6x, 'XXXXX')
6008 format(5x, 'SEISMIC', 7x, '1', 10x, '386.4', 5x, '386.4',
+ 5x, '386.4', 7x, 'CSM', 7x, 'RSS')
6009 format(5x, a1, '-SHOCK', 9x, 'FREQ', 5x, 'ACCEL', 4F10.3)
6010 format(5x, 16x, 'FREQ', 5x, 'ACCEL', 4F10.3)

C
3001 format(// 'COMMENT', 3x, 'NODE = ', a5, 5x,
+ 'ACCELERATION SPECTRA')
3002 format('CASE', 6x, 'XXXXX')
3003 format('SEISMIC', 7x, '1', 10x, '386.4', 5x, '386.4',
+ 5x, '386.4', 7x, 'CSM', 7x, 'RSS')
3005 format( a1, '-SHOCK', 9x, 'FREQ', 5x, 'ACCEL', 4F10.3)
3006 format( 16x, 'FREQ', 5x, 'ACCEL', 4F10.3)

C
4001 format(8f10.3)

C
6901 format(5x, 'ERROR...NSPEC = ', i5, ' > 200 (INTERNAL LIMIT)')
6902 format(5x, 'ERROR...NPOINT = ', i5, ' > 70 (INTERNAL LIMIT)')
6903 format(5x, 'ERROR...FREQUENCY POINTS NOT UNIFORM')
6904 format(5x, 'ERROR...INPUT FILE -> ', a10, 'IS MISSING.' )
6905 format(5x, 'ERROR...UNABLE TO OPEN OUTPUT FILE -> ', a10)

C
7001 format( a80 )
7002 format(10x, a80 )
999 stop
end
```

COT

COMMENT  
 CASE  
 SEISMIC  
 X-SHOCK

NODE = 54BR  
 XXXXX

ACCELERATION SPECTRA

		386.4	386.4	386.4	CSM	RSS
	1					
FREQ	ACCEL	1.000	0.009	2.000	0.019	
FREQ	ACCEL	3.000	0.031	4.000	0.046	
FREQ	ACCEL	4.100	0.047	4.200	0.053	
FREQ	ACCEL	4.300	0.053	4.400	0.050	
FREQ	ACCEL	4.500	0.061	4.600	0.066	
FREQ	ACCEL	4.700	0.072	4.800	0.082	
FREQ	ACCEL	4.900	0.092	5.000	0.110	
FREQ	ACCEL	5.100	0.125	5.200	0.132	
FREQ	ACCEL	5.300	0.122	5.400	0.117	
FREQ	ACCEL	5.500	0.123	5.600	0.134	
FREQ	ACCEL	5.700	0.130	5.800	0.118	
FREQ	ACCEL	5.900	0.111	6.000	0.100	
FREQ	ACCEL	6.100	0.091	6.200	0.086	
FREQ	ACCEL	6.300	0.082	6.400	0.084	
FREQ	ACCEL	6.500	0.086	6.600	0.088	
FREQ	ACCEL	6.700	0.090	6.800	0.092	
FREQ	ACCEL	6.900	0.095	7.000	0.097	
FREQ	ACCEL	7.100	0.099	7.200	0.101	
FREQ	ACCEL	7.300	0.104	7.400	0.106	
FREQ	ACCEL	7.500	0.109	7.600	0.112	
FREQ	ACCEL	7.700	0.114	7.800	0.116	
FREQ	ACCEL	7.900	0.118	8.000	0.121	
FREQ	ACCEL	8.100	0.123	8.200	0.126	
FREQ	ACCEL	8.300	0.128	8.400	0.131	
FREQ	ACCEL	8.500	0.133	8.600	0.135	
FREQ	ACCEL	8.700	0.138	8.800	0.140	
FREQ	ACCEL	8.900	0.143	9.000	0.145	
FREQ	ACCEL	9.100	0.148	9.200	0.150	
FREQ	ACCEL	9.300	0.153	9.400	0.155	
FREQ	ACCEL	9.500	0.157	9.600	0.160	
FREQ	ACCEL	9.700	0.162	9.800	0.165	
FREQ	ACCEL	9.900	0.167	10.000	0.169	
FREQ	ACCEL	10.100	0.172	10.200	0.174	
FREQ	ACCEL	10.300	0.176	10.400	0.178	
FREQ	ACCEL	10.500	0.182	10.600	0.190	
FREQ	ACCEL	10.700	0.197	10.800	0.204	
FREQ	ACCEL	10.900	0.211	11.000	0.217	
FREQ	ACCEL	11.100	0.225	11.200	0.242	
FREQ	ACCEL	11.300	0.254	11.400	0.264	
FREQ	ACCEL	11.500	0.264	11.600	0.262	
FREQ	ACCEL	11.700	0.275	11.800	0.267	
FREQ	ACCEL	11.900	0.284	12.000	0.292	
FREQ	ACCEL	12.100	0.284	12.200	0.288	
FREQ	ACCEL	12.300	0.292	12.400	0.296	
FREQ	ACCEL	12.500	0.298	12.600	0.313	
FREQ	ACCEL	12.700	0.368	12.800	0.416	
FREQ	ACCEL	12.900	0.438	13.000	0.479	
FREQ	ACCEL	13.100	0.489	13.200	0.482	
FREQ	ACCEL	13.300	0.496	13.400	0.506	
FREQ	ACCEL	13.500	0.507	13.600	0.500	
FREQ	ACCEL	13.700	0.478	13.800	0.445	

FREQ	ACCEL	13.900	0.441	14.000	0.456
FREQ	ACCEL	14.100	0.468	14.200	0.479
FREQ	ACCEL	14.300	0.500	14.400	0.518
FREQ	ACCEL	14.500	0.535	14.600	0.561
FREQ	ACCEL	14.700	0.632	14.800	0.751
FREQ	ACCEL	14.900	0.854	15.000	0.922
FREQ	ACCEL	15.100	0.992	15.200	1.022
FREQ	ACCEL	15.300	1.092	15.400	1.141
FREQ	ACCEL	15.500	1.185	15.600	1.195
FREQ	ACCEL	15.700	1.193	15.800	1.172
FREQ	ACCEL	15.900	1.117	16.000	1.252
FREQ	ACCEL	16.100	1.322	16.200	1.281
FREQ	ACCEL	16.300	1.167	16.400	1.058
FREQ	ACCEL	16.500	0.971	16.600	0.865
FREQ	ACCEL	16.700	0.784	16.800	0.740
FREQ	ACCEL	16.900	0.725	17.000	0.733
FREQ	ACCEL	17.100	0.744	17.200	0.723
FREQ	ACCEL	17.300	0.714	17.400	0.648
FREQ	ACCEL	17.500	0.598	17.600	0.567
FREQ	ACCEL	17.700	0.572	17.800	0.578
FREQ	ACCEL	17.900	0.584	18.000	0.590
FREQ	ACCEL	18.100	0.595	18.200	0.600
FREQ	ACCEL	18.300	0.605	18.400	0.610
FREQ	ACCEL	18.500	0.616	18.600	0.625
FREQ	ACCEL	18.700	0.633	18.800	0.641
FREQ	ACCEL	18.900	0.648	19.000	0.656
FREQ	ACCEL	19.100	0.669	19.200	0.681
FREQ	ACCEL	19.300	0.693	19.400	0.705
FREQ	ACCEL	19.500	0.716	19.600	0.726
FREQ	ACCEL	19.700	0.736	19.800	0.746
FREQ	ACCEL	19.900	0.755	20.000	0.764
FREQ	ACCEL	20.100	0.772	20.200	0.779
FREQ	ACCEL	20.300	0.786	20.400	0.793
FREQ	ACCEL	20.500	0.798	20.600	0.804
FREQ	ACCEL	20.700	0.814	20.800	0.826
FREQ	ACCEL	20.900	0.838	21.000	0.849
FREQ	ACCEL	21.100	0.860	21.200	0.870
FREQ	ACCEL	21.300	0.879	21.400	0.889
FREQ	ACCEL	21.500	0.897	21.600	0.905
FREQ	ACCEL	21.700	0.913	21.800	0.920
FREQ	ACCEL	21.900	0.927	22.000	0.933
FREQ	ACCEL	22.100	0.938	22.200	0.943
FREQ	ACCEL	22.300	0.947	22.400	0.950
FREQ	ACCEL	22.500	0.953	22.600	0.958
FREQ	ACCEL	22.700	0.969	22.800	0.979
FREQ	ACCEL	22.900	1.079	23.000	1.225
FREQ	ACCEL	23.100	1.315	23.200	1.322
FREQ	ACCEL	23.300	1.300	23.400	1.182
FREQ	ACCEL	23.500	1.111	23.600	1.150
FREQ	ACCEL	23.700	1.185	23.800	1.217
FREQ	ACCEL	23.900	1.245	24.000	1.268
FREQ	ACCEL	24.100	1.410	24.200	1.524
FREQ	ACCEL	24.300	1.606	24.400	1.606
FREQ	ACCEL	24.500	1.532	24.600	1.470
FREQ	ACCEL	24.700	1.496	24.800	1.518
FREQ	ACCEL	24.900	1.535	25.000	1.691

FREQ	ACCEL	25.100	1.857	25.200	2.024
FREQ	ACCEL	25.300	2.112	25.400	2.191
FREQ	ACCEL	25.500	2.135	25.600	1.974
FREQ	ACCEL	25.700	1.788	25.800	1.747
FREQ	ACCEL	25.900	1.759	26.000	1.936
FREQ	ACCEL	26.100	2.294	26.200	2.695
FREQ	ACCEL	26.300	3.025	26.400	3.231
FREQ	ACCEL	26.500	3.441	26.600	3.454
FREQ	ACCEL	26.700	3.335	26.800	3.177
FREQ	ACCEL	26.900	3.071	27.000	3.018
FREQ	ACCEL	27.100	3.077	27.200	3.245
FREQ	ACCEL	27.300	3.462	27.400	3.632
FREQ	ACCEL	27.500	3.696	27.600	3.781
FREQ	ACCEL	27.700	3.684	27.800	3.404
FREQ	ACCEL	27.900	3.084	28.000	2.767
FREQ	ACCEL	28.100	2.513	28.200	2.407
FREQ	ACCEL	28.300	2.455	28.400	2.594
FREQ	ACCEL	28.500	2.777	28.600	3.003
FREQ	ACCEL	28.700	3.113	28.800	3.058
FREQ	ACCEL	28.900	2.899	29.000	2.756
FREQ	ACCEL	29.100	2.520	29.200	2.273
FREQ	ACCEL	29.300	2.094	29.400	2.026
FREQ	ACCEL	29.500	2.068	29.600	2.176
FREQ	ACCEL	29.700	2.281	29.800	2.315
FREQ	ACCEL	29.900	2.256	30.000	2.208
FREQ	ACCEL	31.000	1.494	32.000	1.375
FREQ	ACCEL	33.000	1.229	34.000	1.112
FREQ	ACCEL	35.000	1.065	36.000	1.024
FREQ	ACCEL	37.000	0.956	38.000	0.939
FREQ	ACCEL	39.000	0.935	40.000	0.924
FREQ	ACCEL	41.000	0.904	42.000	0.877
FREQ	ACCEL	43.000	0.844	44.000	0.826
FREQ	ACCEL	45.000	0.823	46.000	0.815
FREQ	ACCEL	47.000	0.802	48.000	0.784
FREQ	ACCEL	49.000	0.847	50.000	0.735
FREQ	ACCEL	51.000	0.705	52.000	0.673
FREQ	ACCEL	53.000	0.706	54.000	0.779
FREQ	ACCEL	55.000	0.624	56.000	0.611
FREQ	ACCEL	57.000	0.595	58.000	0.577
FREQ	ACCEL	59.000	0.558	60.000	0.551
FREQ	ACCEL	1.000	0.003	2.000	0.007
FREQ	ACCEL	3.000	0.011	4.000	0.017
FREQ	ACCEL	4.100	0.017	4.200	0.018
FREQ	ACCEL	4.300	0.018	4.400	0.019
FREQ	ACCEL	4.500	0.019	4.600	0.019
FREQ	ACCEL	4.700	0.020	4.800	0.020
FREQ	ACCEL	4.900	0.020	5.000	0.021
FREQ	ACCEL	5.100	0.021	5.200	0.021
FREQ	ACCEL	5.300	0.022	5.400	0.023
FREQ	ACCEL	5.500	0.024	5.600	0.025
FREQ	ACCEL	5.700	0.029	5.800	0.027
FREQ	ACCEL	5.900	0.027	6.000	0.028
FREQ	ACCEL	6.100	0.029	6.200	0.030
FREQ	ACCEL	6.300	0.031	6.400	0.032
FREQ	ACCEL	6.500	0.033	6.600	0.034
FREQ	ACCEL	6.700	0.035	6.800	0.036

Y-SHOCK



FREQ	ACCEL	6.900	0.037	7.000	0.038
FREQ	ACCEL	7.100	0.039	7.200	0.040
FREQ	ACCEL	7.300	0.041	7.400	0.042
FREQ	ACCEL	7.500	0.043	7.600	0.044
FREQ	ACCEL	7.700	0.045	7.800	0.046
FREQ	ACCEL	7.900	0.047	8.000	0.048
FREQ	ACCEL	8.100	0.050	8.200	0.051
FREQ	ACCEL	8.300	0.052	8.400	0.053
FREQ	ACCEL	8.500	0.054	8.600	0.056
FREQ	ACCEL	8.700	0.057	8.800	0.058
FREQ	ACCEL	8.900	0.059	9.000	0.060
FREQ	ACCEL	9.100	0.062	9.200	0.063
FREQ	ACCEL	9.300	0.064	9.400	0.065
FREQ	ACCEL	9.500	0.067	9.600	0.068
FREQ	ACCEL	9.700	0.069	9.800	0.071
FREQ	ACCEL	9.900	0.072	10.000	0.073
FREQ	ACCEL	10.100	0.074	10.200	0.076
FREQ	ACCEL	10.300	0.077	10.400	0.078
FREQ	ACCEL	10.500	0.080	10.600	0.081
FREQ	ACCEL	10.700	0.082	10.800	0.084
FREQ	ACCEL	10.900	0.085	11.000	0.086
FREQ	ACCEL	11.100	0.088	11.200	0.089
FREQ	ACCEL	11.300	0.091	11.400	0.093
FREQ	ACCEL	11.500	0.094	11.600	0.096
FREQ	ACCEL	11.700	0.097	11.800	0.099
FREQ	ACCEL	11.900	0.100	12.000	0.102
FREQ	ACCEL	12.100	0.104	12.200	0.105
FREQ	ACCEL	12.300	0.107	12.400	0.108
FREQ	ACCEL	12.500	0.110	12.600	0.112
FREQ	ACCEL	12.700	0.113	12.800	0.115
FREQ	ACCEL	12.900	0.117	13.000	0.118
FREQ	ACCEL	13.100	0.120	13.200	0.122
FREQ	ACCEL	13.300	0.123	13.400	0.125
FREQ	ACCEL	13.500	0.127	13.600	0.129
FREQ	ACCEL	13.700	0.130	13.800	0.132
FREQ	ACCEL	13.900	0.134	14.000	0.135
FREQ	ACCEL	14.100	0.137	14.200	0.139
FREQ	ACCEL	14.300	0.141	14.400	0.142
FREQ	ACCEL	14.500	0.144	14.600	0.146
FREQ	ACCEL	14.700	0.147	14.800	0.149
FREQ	ACCEL	14.900	0.151	15.000	0.153
FREQ	ACCEL	15.100	0.154	15.200	0.156
FREQ	ACCEL	15.300	0.159	15.400	0.162
FREQ	ACCEL	15.500	0.166	15.600	0.169
FREQ	ACCEL	15.700	0.172	15.800	0.175
FREQ	ACCEL	15.900	0.178	16.000	0.182
FREQ	ACCEL	16.100	0.185	16.200	0.188
FREQ	ACCEL	16.300	0.191	16.400	0.195
FREQ	ACCEL	16.500	0.199	16.600	0.203
FREQ	ACCEL	16.700	0.207	16.800	0.211
FREQ	ACCEL	16.900	0.215	17.000	0.219
FREQ	ACCEL	17.100	0.223	17.200	0.227
FREQ	ACCEL	17.300	0.230	17.400	0.234
FREQ	ACCEL	17.500	0.238	17.600	0.242
FREQ	ACCEL	17.700	0.245	17.800	0.249
FREQ	ACCEL	17.900	0.253	18.000	0.256

FREQ	ACCEL	18.100	0.260	18.200	0.263
FREQ	ACCEL	18.300	0.267	18.400	0.270
FREQ	ACCEL	18.500	0.273	18.600	0.278
FREQ	ACCEL	18.700	0.286	18.800	0.293
FREQ	ACCEL	18.900	0.300	19.000	0.306
FREQ	ACCEL	19.100	0.313	19.200	0.320
FREQ	ACCEL	19.300	0.326	19.400	0.333
FREQ	ACCEL	19.500	0.339	19.600	0.345
FREQ	ACCEL	19.700	0.350	19.800	0.356
FREQ	ACCEL	19.900	0.361	20.000	0.367
FREQ	ACCEL	20.100	0.372	20.200	0.379
FREQ	ACCEL	20.300	0.387	20.400	0.395
FREQ	ACCEL	20.500	0.403	20.600	0.410
FREQ	ACCEL	20.700	0.418	20.800	0.425
FREQ	ACCEL	20.900	0.432	21.000	0.439
FREQ	ACCEL	21.100	0.446	21.200	0.456
FREQ	ACCEL	21.300	0.466	21.400	0.476
FREQ	ACCEL	21.500	0.486	21.600	0.496
FREQ	ACCEL	21.700	0.505	21.800	0.513
FREQ	ACCEL	21.900	0.521	22.000	0.529
FREQ	ACCEL	22.100	0.540	22.200	0.550
FREQ	ACCEL	22.300	0.563	22.400	0.580
FREQ	ACCEL	22.500	0.597	22.600	0.613
FREQ	ACCEL	22.700	0.628	22.800	0.642
FREQ	ACCEL	22.900	0.656	23.000	0.669
FREQ	ACCEL	23.100	0.706	23.200	0.706
FREQ	ACCEL	23.300	0.705	23.400	0.719
FREQ	ACCEL	23.500	0.742	23.600	0.763
FREQ	ACCEL	23.700	0.783	23.800	0.801
FREQ	ACCEL	23.900	0.818	24.000	0.833
FREQ	ACCEL	24.100	0.849	24.200	0.897
FREQ	ACCEL	24.300	0.941	24.400	0.935
FREQ	ACCEL	24.500	0.923	24.600	0.943
FREQ	ACCEL	24.700	0.961	24.800	0.976
FREQ	ACCEL	24.900	1.022	25.000	1.173
FREQ	ACCEL	25.100	1.338	25.200	1.455
FREQ	ACCEL	25.300	1.546	25.400	1.541
FREQ	ACCEL	25.500	1.497	25.600	1.374
FREQ	ACCEL	25.700	1.236	25.800	1.195
FREQ	ACCEL	25.900	1.206	26.000	1.318
FREQ	ACCEL	26.100	1.594	26.200	1.891
FREQ	ACCEL	26.300	2.154	26.400	2.346
FREQ	ACCEL	26.500	2.481	26.600	2.500
FREQ	ACCEL	26.700	2.448	26.800	2.328
FREQ	ACCEL	26.900	2.182	27.000	2.072
FREQ	ACCEL	27.100	2.026	27.200	2.056
FREQ	ACCEL	27.300	2.144	27.400	2.239
FREQ	ACCEL	27.500	2.299	27.600	2.309
FREQ	ACCEL	27.700	2.281	27.800	2.143
FREQ	ACCEL	27.900	1.936	28.000	1.722
FREQ	ACCEL	28.100	1.550	28.200	1.459
FREQ	ACCEL	28.300	1.475	28.400	1.555
FREQ	ACCEL	28.500	1.651	28.600	1.777
FREQ	ACCEL	28.700	1.838	28.800	1.803
FREQ	ACCEL	28.900	1.710	29.000	1.634
FREQ	ACCEL	29.100	1.502	29.200	1.363

FREQ	ACCEL	29.300	1.263	29.400	1.231
FREQ	ACCEL	29.500	1.268	29.600	1.349
FREQ	ACCEL	29.700	1.433	29.800	1.477
FREQ	ACCEL	29.900	1.457	30.000	1.392
FREQ	ACCEL	31.000	0.999	32.000	0.962
FREQ	ACCEL	33.000	0.919	34.000	0.903
FREQ	ACCEL	35.000	0.911	36.000	0.890
FREQ	ACCEL	37.000	0.909	38.000	0.927
FREQ	ACCEL	39.000	1.039	40.000	0.885
FREQ	ACCEL	41.000	0.883	42.000	0.898
FREQ	ACCEL	43.000	0.983	44.000	1.198
FREQ	ACCEL	45.000	1.162	46.000	0.868
FREQ	ACCEL	47.000	1.118	48.000	1.327
FREQ	ACCEL	49.000	1.628	50.000	1.751
FREQ	ACCEL	51.000	1.238	52.000	1.505
FREQ	ACCEL	53.000	1.288	54.000	1.679
FREQ	ACCEL	55.000	1.218	56.000	0.780
FREQ	ACCEL	57.000	0.728	58.000	0.720
FREQ	ACCEL	59.000	0.708	60.000	0.692
FREQ	ACCEL	1.000	0.001	2.000	0.002
FREQ	ACCEL	3.000	0.003	4.000	0.004
FREQ	ACCEL	4.100	0.004	4.200	0.004
FREQ	ACCEL	4.300	0.004	4.400	0.004
FREQ	ACCEL	4.500	0.004	4.600	0.005
FREQ	ACCEL	4.700	0.005	4.800	0.005
FREQ	ACCEL	4.900	0.005	5.000	0.005
FREQ	ACCEL	5.100	0.006	5.200	0.006
FREQ	ACCEL	5.300	0.006	5.400	0.006
FREQ	ACCEL	5.500	0.007	5.600	0.008
FREQ	ACCEL	5.700	0.008	5.800	0.008
FREQ	ACCEL	5.900	0.008	6.000	0.008
FREQ	ACCEL	6.100	0.008	6.200	0.008
FREQ	ACCEL	6.300	0.009	6.400	0.009
FREQ	ACCEL	6.500	0.009	6.600	0.010
FREQ	ACCEL	6.700	0.010	6.800	0.010
FREQ	ACCEL	6.900	0.010	7.000	0.011
FREQ	ACCEL	7.100	0.011	7.200	0.011
FREQ	ACCEL	7.300	0.012	7.400	0.012
FREQ	ACCEL	7.500	0.012	7.600	0.013
FREQ	ACCEL	7.700	0.013	7.800	0.013
FREQ	ACCEL	7.900	0.014	8.000	0.014
FREQ	ACCEL	8.100	0.014	8.200	0.015
FREQ	ACCEL	8.300	0.015	8.400	0.016
FREQ	ACCEL	8.500	0.016	8.600	0.016
FREQ	ACCEL	8.700	0.017	8.800	0.017
FREQ	ACCEL	8.900	0.017	9.000	0.018
FREQ	ACCEL	9.100	0.018	9.200	0.019
FREQ	ACCEL	9.300	0.019	9.400	0.019
FREQ	ACCEL	9.500	0.020	9.600	0.020
FREQ	ACCEL	9.700	0.021	9.800	0.021
FREQ	ACCEL	9.900	0.022	10.000	0.022
FREQ	ACCEL	10.100	0.022	10.200	0.023
FREQ	ACCEL	10.300	0.023	10.400	0.024
FREQ	ACCEL	10.500	0.024	10.600	0.025
FREQ	ACCEL	10.700	0.025	10.800	0.026
FREQ	ACCEL	10.900	0.026	11.000	0.027

Z-SHOCK

FREQ	ACCEL	11.100	0.027	11.200	0.027
FREQ	ACCEL	11.300	0.028	11.400	0.028
FREQ	ACCEL	11.500	0.029	11.600	0.029
FREQ	ACCEL	11.700	0.031	11.800	0.030
FREQ	ACCEL	11.900	0.031	12.000	0.031
FREQ	ACCEL	12.100	0.032	12.200	0.033
FREQ	ACCEL	12.300	0.033	12.400	0.034
FREQ	ACCEL	12.500	0.034	12.600	0.035
FREQ	ACCEL	12.700	0.035	12.800	0.036
FREQ	ACCEL	12.900	0.037	13.000	0.037
FREQ	ACCEL	13.100	0.038	13.200	0.038
FREQ	ACCEL	13.300	0.039	13.400	0.040
FREQ	ACCEL	13.500	0.041	13.600	0.043
FREQ	ACCEL	13.700	0.045	13.800	0.045
FREQ	ACCEL	13.900	0.048	14.000	0.049
FREQ	ACCEL	14.100	0.052	14.200	0.055
FREQ	ACCEL	14.300	0.058	14.400	0.060
FREQ	ACCEL	14.500	0.066	14.600	0.072
FREQ	ACCEL	14.700	0.081	14.800	0.095
FREQ	ACCEL	14.900	0.113	15.000	0.131
FREQ	ACCEL	15.100	0.138	15.200	0.134
FREQ	ACCEL	15.300	0.140	15.400	0.149
FREQ	ACCEL	15.500	0.155	15.600	0.159
FREQ	ACCEL	15.700	0.161	15.800	0.158
FREQ	ACCEL	15.900	0.155	16.000	0.167
FREQ	ACCEL	16.100	0.177	16.200	0.175
FREQ	ACCEL	16.300	0.164	16.400	0.152
FREQ	ACCEL	16.500	0.134	16.600	0.120
FREQ	ACCEL	16.700	0.108	16.800	0.101
FREQ	ACCEL	16.900	0.098	17.000	0.099
FREQ	ACCEL	17.100	0.100	17.200	0.098
FREQ	ACCEL	17.300	0.094	17.400	0.088
FREQ	ACCEL	17.500	0.086	17.600	0.080
FREQ	ACCEL	17.700	0.079	17.800	0.079
FREQ	ACCEL	17.900	0.081	18.000	0.079
FREQ	ACCEL	18.100	0.078	18.200	0.080
FREQ	ACCEL	18.300	0.081	18.400	0.082
FREQ	ACCEL	18.500	0.083	18.600	0.085
FREQ	ACCEL	18.700	0.086	18.800	0.087
FREQ	ACCEL	18.900	0.088	19.000	0.089
FREQ	ACCEL	19.100	0.090	19.200	0.091
FREQ	ACCEL	19.300	0.092	19.400	0.093
FREQ	ACCEL	19.500	0.095	19.600	0.098
FREQ	ACCEL	19.700	0.103	19.800	0.112
FREQ	ACCEL	19.900	0.120	20.000	0.137
FREQ	ACCEL	20.100	0.144	20.200	0.143
FREQ	ACCEL	20.300	0.140	20.400	0.135
FREQ	ACCEL	20.500	0.124	20.600	0.113
FREQ	ACCEL	20.700	0.115	20.800	0.117
FREQ	ACCEL	20.900	0.118	21.000	0.119
FREQ	ACCEL	21.100	0.126	21.200	0.131
FREQ	ACCEL	21.300	0.126	21.400	0.124
FREQ	ACCEL	21.500	0.126	21.600	0.128
FREQ	ACCEL	21.700	0.130	21.800	0.132
FREQ	ACCEL	21.900	0.133	22.000	0.134
FREQ	ACCEL	22.100	0.135	22.200	0.141

FREQ	ACCEL	22.300	0.145	22.400	0.139
FREQ	ACCEL	22.500	0.143	22.600	0.147
FREQ	ACCEL	22.700	0.150	22.800	0.153
FREQ	ACCEL	22.900	0.155	23.000	0.158
FREQ	ACCEL	23.100	0.160	23.200	0.166
FREQ	ACCEL	23.300	0.171	23.400	0.166
FREQ	ACCEL	23.500	0.170	23.600	0.173
FREQ	ACCEL	23.700	0.176	23.800	0.179
FREQ	ACCEL	23.900	0.181	24.000	0.189
FREQ	ACCEL	24.100	0.216	24.200	0.243
FREQ	ACCEL	24.300	0.267	24.400	0.273
FREQ	ACCEL	24.500	0.268	24.600	0.257
FREQ	ACCEL	24.700	0.247	24.800	0.234
FREQ	ACCEL	24.900	0.225	25.000	0.227
FREQ	ACCEL	25.100	0.239	25.200	0.256
FREQ	ACCEL	25.300	0.268	25.400	0.270
FREQ	ACCEL	25.500	0.262	25.600	0.249
FREQ	ACCEL	25.700	0.253	25.800	0.258
FREQ	ACCEL	25.900	0.261	26.000	0.266
FREQ	ACCEL	26.100	0.315	26.200	0.363
FREQ	ACCEL	26.300	0.401	26.400	0.432
FREQ	ACCEL	26.500	0.453	26.600	0.455
FREQ	ACCEL	26.700	0.438	26.800	0.418
FREQ	ACCEL	26.900	0.410	27.000	0.412
FREQ	ACCEL	27.100	0.429	27.200	0.467
FREQ	ACCEL	27.300	0.514	27.400	0.550
FREQ	ACCEL	27.500	0.561	27.600	0.571
FREQ	ACCEL	27.700	0.559	27.800	0.516
FREQ	ACCEL	27.900	0.468	28.000	0.417
FREQ	ACCEL	28.100	0.357	28.200	0.321
FREQ	ACCEL	28.300	0.318	28.400	0.313
FREQ	ACCEL	28.500	0.327	28.600	0.352
FREQ	ACCEL	28.700	0.363	28.800	0.375
FREQ	ACCEL	28.900	0.378	29.000	0.359
FREQ	ACCEL	29.100	0.325	29.200	0.285
FREQ	ACCEL	29.300	0.273	29.400	0.272
FREQ	ACCEL	29.500	0.270	29.600	0.267
FREQ	ACCEL	29.700	0.263	29.800	0.257
FREQ	ACCEL	29.900	0.257	30.000	0.259
FREQ	ACCEL	31.000	0.276	32.000	0.287
FREQ	ACCEL	33.000	0.294	34.000	0.309
FREQ	ACCEL	35.000	0.314	36.000	0.390
FREQ	ACCEL	37.000	0.575	38.000	0.705
FREQ	ACCEL	39.000	0.960	40.000	0.636
FREQ	ACCEL	41.000	0.438	42.000	0.391
FREQ	ACCEL	43.000	0.336	44.000	0.326
FREQ	ACCEL	45.000	0.309	46.000	0.308
FREQ	ACCEL	47.000	0.312	48.000	0.314
FREQ	ACCEL	49.000	0.436	50.000	0.513
FREQ	ACCEL	51.000	0.557	52.000	0.831
FREQ	ACCEL	53.000	0.708	54.000	0.752
FREQ	ACCEL	55.000	0.541	56.000	0.346
FREQ	ACCEL	57.000	0.273	58.000	0.271
FREQ	ACCEL	59.000	0.268	60.000	0.262



CALCULATION  
CONTINUATION SHEET

TITLE PIPING CODE COMPLIANCE DOCUMENTATION SYSTEM P-201		ID NO. C-31	SHEET III.1 OF 347
		REFERENCE NONE	
ORIGINATOR	027 7		
DATE	7-15-88		
VFR or CCR	ABJ		
DATE	7/15/88		

ATTACHMENT 8  
 PAGE 1 OF 108  
 CALC. NO. C-0031 / 7IRΦ

ATTACHMENT III

- 1) PISTAR OUTPUT (Under separate cover)
- 2) OPTSUPT OUTPUT (Included in <sup>HG</sup> ~~the~~ package)
- 3) FLANGE OUTPUT (~~0~~ pages)

4) Acceleration Spectra plots - Total 107 pages


RUNID/Date	Case Description	Pages
AFGZ 6/17/88	SRV Case C3-1 (2% D T.H.)	19
AAQG 6/19/88	SRV Case C3-2 (2% D T.H.)	19
AAQJ 6/19/88	CAI (2% D T.H.)	19
AAQO 6/19/88	CHUGI (2% D T.H.)	19
AARK 6/20/88	SRV Case C3-2 (3% D T.H.)	19
ABAV 7/14/88	" " " (2% D T.H. P201)	4
ABAY 7/14/88	CAI (2% D T.H. rule P201)	4
ABBB 7/14/88	CHUGI ( " " " " )	4
5) Acceleration Spectra Digitized output		Total 239 pages
File Name	Description	Pages
OAB P201 A	SRV Case C3-1 (2% D T.H.)	43
P201 AQB	SRV Case C3-2 ( " )	43
P201 ACP	CAI Acceleration ( " )	43
P201 ACH	CHUGI ( " )	43
QB3 P201	SRV Case C3-2 (3% D T.H.)	43
QBAP201	" " " (2% " " - P201 We)	8
CA P201	CAI " " " " "	8
CHA P201	CHUGI " " " " "	8

JOB NAME = AFGZ

DATE = 88/06/17

CHARGE = F3395JT

PROJECT = \*311\*XPS080502




QABIB (2% for Case C3.1)  
spectrum at 1% damping  
(Total 19 pages)

ATTACHMENT 8  
PAGE 2 of 108  
CALC. NO. C-0031/71RD

RFCZ 88/06/17 15.01.06

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.1  
ACCEL RESPONSE SPECTRUM AT NODE 26BR X-TRAN LC = 3



FREQUENCY (HZ)  
FIGURE 1


— LEGEND

ATTACHMENT 8  
PAGE 3 OF 109  
CALC. NO. Q-0031/71R0



RFCZ 88/06/17 15.01.06

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.1  
ACCEL RESPONSE SPECTRUM AT NODE 26BR Y-TRAN LC = 3



FREQUENCY (HZ)  
FIGURE 2

— LEGEND

ATTACHMENT 8  
PAGE 4 OF 108  
CALC. NO. C-0031/TIRO

AFGZ 88/06/17 15.01.06

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.1  
ACCEL RESPONSE SPECTRUM AT NODE 26BR Z-TRAN LC = 3





FIGURE 3

— LEGEND

ATTACHMENT 8  
PAGE 5 OF 108  
CALC. NO. C-0531/71RD

RFCZ 88/06/17 15.01.06

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.1  
ACCEL RESPONSE SPECTRUM AT NODE 27BR X-TRAN LC = 3



FREQUENCY (HZ)


FIGURE 4

— LEGEND

ATTACHMENT 8  
PAGE 6 OF 108  
CALC. NO. C-0031/T120

RFCZ 88/06/17 15.01.06

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.1  
ACCEL RESPONSE SPECTRUM AT NODE 27BR Y-TRAN LC = 3




FREQUENCY (HZ)  
FIGURE 5

— LEGEND

ATTACHMENT 8  
PAGE 7 OF 108  
CALC. NO. C-0031/TIRD

AFCZ 88/06/17 15.01.06

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.1  
ACCEL RESPONSE SPECTRUM AT NODE 27BR Z-TRAN LC = 3



FREQUENCY (HZ)


FIGURE 6

— LEGEND

ATTACHMENT 8  
PAGE 8 OF 108  
CALC. NO. C-0031/TIRD

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.1  
ACCEL RESPONSE SPECTRUM AT NODE 54BR X-TRAN LC = 3

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222



FREQUENCY (HZ)  
FIGURE 7


— LEGEND

ATTACHMENT 8  
PAGE 9 OF 108  
CALC. NO. C-0031/TIRD

AFCZ 88/06/17 15.01.06

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.1  
ACCEL RESPONSE SPECTRUM AT NODE 54BR Y-TRAN LC = 3

AMPLITUDE



FREQUENCY (HZ)


FIGURE 8

— LEGEND

ATTACHMENT 8  
PAGE 10 OF 108  
CALC. NO. C-0031/TIR0

RFCZ 88/06/17 15.01.06

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.1  
ACCEL RESPONSE SPECTRUM AT NODE 54BR Z-TRAN LC = 3



FREQUENCY (HZ)

FIGURE 9

— LEGEND


ATTACHMENT 8  
PAGE 11 OF 108  
CALC. NO. C-0031/TIRD



AFGZ 88/06/17 15.01.06

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.1  
ACCEL RESPONSE SPECTRUM AT NODE 91 X-TRAN LC = 3

AMPLITUDE



FREQUENCY (HZ)

FIGURE 10


— LEGEND

ATTACHMENT 8  
PAGE 12 OF 108  
CALC. NO. C-0031/71R0

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
 QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.1  
 ACCEL RESPONSE SPECTRUM AT NODE 91 Y-TRAN LC = 3

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

AMPLITUDE



FREQUENCY (HZ)


FIGURE 11

— LEGEND

ATTACHMENT 8  
 PAGE 13 OF 108  
 PWC NO. C-0031/7TRD

RFCZ 88/06/17 15.01.06

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.1  
ACCEL RESPONSE SPECTRUM AT NODE 91 Z-TRAN LC = 3




FREQUENCY (HZ)  
FIGURE 12

— LEGEND

ATTACHMENT 8  
PAGE 14 OF 108  
CALC. NO. C-0031/TIRD

AFCZ 88/06/17 15.01.06

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.1  
ACCEL RESPONSE SPECTRUM AT NODE 92 X-TRAN LC = 3



FREQUENCY (HZ)


FIGURE 13

— LEGEND

ATTACHMENT 8  
PAGE 15 OF 108  
CALC. NO. C-0031/71R0

RFCZ 88/06/17 15.01.06

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.1  
ACCEL RESPONSE SPECTRUM AT NODE 92 Y-TRAN LC = 3




FREQUENCY (HZ)  
FIGURE 14

— LEGEND

ATTACHMENT 8  
PAGE 16 OF 108  
CALC. NO. C-0031/71RD

AFGZ 88/06/17 15.01.06

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.1  
ACCEL RESPONSE SPECTRUM AT NODE 92 Z-TRAN LC = 3



FREQUENCY (HZ)


FIGURE 15

— LEGEND

ATTACHMENT 8  
PAGE 17 OF 108  
CALC. NO. C-0031/TIRD

AFCZ 88/06/17 15.01.06

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G); CASE C3.1  
ACCEL RESPONSE SPECTRUM AT NODE 145CP X-TRAN LC = 3



FREQUENCY (HZ)  
FIGURE 16


— LEGEND

ATTACHMENT 8  
PAGE 8 of 108  
CALC. NO. C-0531/71RD

AFCZ 88/06/17 15.01.06

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.1  
ACCEL RESPONSE SPECTRUM AT NODE 145CP Y-TRAN LC = 3

AMPLITUDE



FREQUENCY (HZ)

FIGURE 17


— LEGEND

ATTACHMENT 19 OF 108  
PAGE 19 OF 108  
CALC. NO. C-0031/TIRd



HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.1  
ACCEL RESPONSE SPECTRUM AT NODE 145CP Z-TRAN LC = 3

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222



FREQUENCY (HZ)

FIGURE 18

— LEGEND


ATTACHMENT 8  
PAGE 20 OF 108  
CALC. NO. 6-0031/1326

JOB NAME = AAQG

DATE = 88/06/09

CHARGE = F3395JT


PROJECT = \*311\*XPS080502



QABI (Case (3.2)  
2% Damping in Coupling Analysis  
(Total 19 pages)

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 26BR X-TRAN. LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222



FREQUENCY (HZ)


FIGURE 1

— LEGEND

ATTACHMENT 8  
PAGE 22 OF 108  
CALC. NO. C-0031/TIP0

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 26BR Y-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222



FREQUENCY (HZ)


FIGURE 2

— LEGEND

ATTACHMENT 3  
PAGE 23 OF 108  
CALC. NO. C-0031/TIRP

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 26BR Z-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222



FREQUENCY (HZ)

FIGURE 3


— LEGEND

ATTACHMENT 8  
PAGE 24 OF 108  
CALC. NO. C-0031/71R0

AAQC

88/06/09 17.27.09

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
GABI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 27BR X-TRAN LC = 1



FREQUENCY (HZ)


FIGURE 4

— LEGEND

ATTACHMENT 8  
PAGE 25 OF 108  
CALC. NO. C-0031/75RD

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 27BR Y-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222




FREQUENCY (HZ)

FIGURE 5

— LEGEND

ATTACHMENT 8  
PAGE 26 OF 108  
CALC. NO. C-0031/7TRD

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QAB1 ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 27BR Z-TRAN LC = 1



FREQUENCY (HZ)

FIGURE 6

— LEGEND


ATTACHMENT 8  
PAGE 27 of 108  
CALC. NO. C-0031/TIRD



HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 54BR X-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

AMPLITUDE




FREQUENCY (HZ)  
FIGURE 7

— LEGEND

ATTACHMENT 8  
PAGE 28 OF 108  
CALC. NO. C-0031/71R0

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 54BR Y-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222



FREQUENCY (HZ)

FIGURE 8


— LEGEND

ATTACHMENT 8  
PAGE 29 OF 108  
CALC. NO. C-0031/71RD

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 54BR Z-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

AMPLITUDE



FREQUENCY (HZ)


FIGURE 9

— LEGEND

ATTACHMENT 8  
PAGE 30 OF 108  
CALC. NO. C-0031/TJRD

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 91 X-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222



FREQUENCY (HZ)


FIGURE 10

— LEGEND

ATTACHMENT 8  
PAGE 31 OF 108  
CALC. NO. C-0031/71R0

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 91 Y-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222



FREQUENCY (HZ)


FIGURE 11

— LEGEND

ATTACHMENT 8  
PAGE 32 OF 108  
CALC. NO. C-0031/TIR0

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 91 Z-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222




FREQUENCY (HZ)

FIGURE 12

— LEGEND

ATTACHMENT 8  
PAGE 33 OF 108  
CALC. NO. 2-0081/7JRD

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 92 X-TRAN LC = 1



FREQUENCY (HZ)

FIGURE 13


— LEGEND

ATTACHMENT 8  
PAGE 34 OF 108  
CALC. NO. C-0031/TIRP

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
 QABI ACCELERATION SPECTRUM (HZ,G)  
 ACCEL RESPONSE SPECTRUM AT NODE 92 Y-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

AMPLITUDE



FREQUENCY (HZ)

FIGURE 14


— LEGEND

ATTACHMENT 8  
 PAGE 35 OF 108  
 CALC NO C-0031/7TR0



HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 92 Z-TRAN LC = 1

AMPLITUDE



FREQUENCY (HZ)

FIGURE 15


— LEGEND

ATTACHMENT 8  
PAGE 36 OF 108  
CALC. NO. C-0031/7TRD

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 145CP X-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

AMPLITUDE



FREQUENCY (HZ)

FIGURE 16

— LEGEND


ATTACHMENT 8  
PAGE 37 of 108  
CALC. NO. G-0031/TTRD

ARQC

88/06/09

17.27.09

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 145CP Y-TRAN LC = 1



FREQUENCY (HZ)

FIGURE 17


— LEGEND

ATTACHMENT 8  
PAGE 38 OF 108  
CALC. NO. C-0031 / TIR0

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 145CP Z-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

AMPLITUDE



FREQUENCY (HZ)  
FIGURE 18

— LEGEND


ATTACHMENT      B  
PAGE 39 OF 108  
CALC. NO. C-0031/71120

JOB NAME = AAQJ

DATE = 88/06/09

CHARGE = F3395JT

PROJECT = \*311\*XPS080502



*CFI*  
*(19 pages total)*


ATTACHMENT 3  
PAGE 4D OF 108  
CALC. NO. C-0031/TIRP

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
COI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 26BR X-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

AMPLITUDE

5.0



FREQUENCY (HZ)


FIGURE 1

— LEGEND

ATTACHMENT 8  
PAGE 41 OF 108  
CALC. NO. C-0031/71RO

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
COI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 26BR Y-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222




FREQUENCY (HZ)  
FIGURE 2

— LEGEND

ATTACHMENT 8  
PAGE 42 OF 108  
CALC. NO. C-0031/7TPO

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
 CO1 ACCELERATION SPECTRUM (HZ,G)  
 ACCEL RESPONSE SPECTRUM AT NODE 26BR Z-TRAN LC = 1



FREQUENCY (HZ)


FIGURE 3

— LEGEND

ATTACHMENT 8  
 PAGE 43 of 108  
 CALC. NO. C-0031/7IRB



HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
 COI ACCELERATION SPECTRUM (HZ,G)  
 ACCEL RESPONSE SPECTRUM AT NODE 27BR X-TRAN LC = 1



FREQUENCY (HZ)

FIGURE 4


— LEGEND

ATTACHMENT 8  
 PAGE 44 OF 108  
 CALC. NO. C-0031/TIRD

AA07

88/06/09 17.31.25

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
COI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 27BR Y-TRAN LC = 1



FREQUENCY (HZ)  
FIGURE 5


— LEGEND

ATTACHMENT 8  
PAGE 45 of 108  
CALC. NO. C-0031/7120

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
COI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 27BR Z-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

AMPLITUDE



FREQUENCY (HZ)

FIGURE 6


— LEGEND

ATTACHMENT 3  
PAGE 46 OF 108  
CALC. NO. C-0031/71R0

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
COI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 54BR X-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

AMPLITUDE



FREQUENCY (HZ)

FIGURE 7

— LEGEND

ATTACHMENT 8  
PAGE 47 OF 108  
CALC. NO. G-0031/7IR0

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
COI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 54BR Y-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222




FIGURE 8

— LEGEND

ATTACHMENT 8  
PAGE 48 OF 108  
CALC. NO. C-00317TRD

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
COI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 54BR Z-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222





FIGURE 9

— LEGEND

ATTACHMENT 8  
PAGE 49 OF 108  
CALC. NO. C-0031/7IRD

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
COI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 91 X-TRAN LC = 1

AMPLITUDE



FREQUENCY (HZ)


FIGURE 10

— LEGEND

ATTACHMENT 8  
PAGE 50 OF 108  
CALC. NO. C-0031/71RD

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
CO1 ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 91 Y-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222



FREQUENCY (HZ)  
FIGURE 11

— LEGEND


ATTACHMENT 8  
PAGE 51 OF 168  
CALC. NO. C-0031/7TRD



HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
 CO1 ACCELERATION SPECTRUM (HZ,G)  
 ACCEL RESPONSE SPECTRUM AT NODE 91 Z-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

AMPLITUDE



FREQUENCY (HZ)


FIGURE 12

— LEGEND

ATTACHMENT 8  
 PAGE 52 OF 108  
 CALC. NO. C-0031/75RD

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
 CO1 ACCELERATION SPECTRUM (HZ,G)  
 ACCEL RESPONSE SPECTRUM AT NODE 92 X-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222



FREQUENCY (HZ)

FIGURE 13


— LEGEND

ATTACHMENT 8  
 PAGE 53 OF 108  
 CALC. NO. C-0031/71RD

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
 COI ACCELERATION SPECTRUM (HZ,G)  
 ACCEL RESPONSE SPECTRUM AT NODE 92 Y-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

AMPLITUDE



FREQUENCY (HZ)

FIGURE 14

— LEGEND

ATTACHMENT 8  
 PAGE 54 OF 108  
 CALC. NO. 2-0031/TIRD

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
COI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 92 Z-TRAN LC = 1





FIGURE 15

— LEGEND

ATTACHMENT 8  
PAGE 55 OF 108  
CALC. NO. C-0031/7TRD

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
COI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 145CP X-TRAN LC = 1



FREQUENCY (HZ)

FIGURE 16


— LEGEND

ATTACHMENT 8  
PAGE 56 OF 108  
CALC. NO. 2-0031/TIRD

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
 CO1 ACCELERATION SPECTRUM (HZ,G)  
 ACCEL RESPONSE SPECTRUM AT NODE 145CP Y-TRAN LC = -1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
 PRINTED 20041222

AMPLITUDE



FREQUENCY (HZ)

FIGURE 17

— LEGEND

ATTACHMENT 8  
 PAGE 57 OF 108  
 CALC. NO. C-0031/TIRD

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
COI. ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 145CP Z-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222




FIGURE 18

— LEGEND


ATTACHMENT 8  
PAGE 58 OF 108  
CALC. NO. C-0031/TIRD

JOB NAME = AAQO

DATE = 88/06/09

CHARGE = F3395JT

PROJECT = \*311\*XPS080502




CHUG I  
(19 pages Total)

ATTACHMENT 8  
PAGE 59 OF 108  
CALC. NO. 2-0031/TIRD



AA00 88/06/09 17.37.00

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
CHUGI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 26BR X-TRAN LC = 1




FREQUENCY (HZ)  
FIGURE 1

— LEGEND

ATTACHMENT 8  
PAGE 60 OF 108  
CALC. NO. C-0031/7IIRD

RAQD 88/06/09 17.37.00

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
CHUGI ACCELERATION SPECTRUM (HZ,G)  
ACCEL. RESPONSE SPECTRUM AT NODE 26BR Y-TRAN LC = 1



FREQUENCY (HZ)


FIGURE 2

— LEGEND

ATTACHMENT 8  
PAGE 61 OF 108  
CALC. NO. C-0031/TIR00

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
CHUGI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 26BR Z-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222



FREQUENCY (HZ)


FIGURE 3

— LEGEND

ATTACHMENT 8  
PAGE 62 OF 108  
CALC. NO. C-0031/TIRD

RR00 88/06/09 17.37.00

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
CHUGI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 27BR X-TRAN LC = 1



FREQUENCY (HZ)

FIGURE 4

— LEGEND

ATTACHMENT 8  
PAGE 63 OF 108  
CALC. NO. C-0031/71R3

1

RR00 88/06/09 17.37.00

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
CHUGI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 27BR Y-TRAN LC = 1




FIGURE 5

— LEGEND

ATTACHMENT 8  
PAGE 64 OF 108  
CALC. NO. C-0031/TIR0

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
CHUGI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 27BR Z-TRAN LC = 1





FIGURE 6

— LEGEND

ATTACHMENT 8  
PAGE 65 OF 108  
CALC NO 4-0031/7190

RR00 88/06/09 17.37.00

HOPE CREEK NUCLEAR GEN. STATION UNIT-1; P201  
CHUGI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 548R X-TRAN LC = 1



FREQUENCY (HZ)


FIGURE 7

— LEGEND

ATTACHMENT 8  
PAGE 66 OF 108  
CALC. NO. C-0031/71R0

RA00 88/06/09 17.37.00

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
CHUGI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 54BR Y-TRAN LC = 1



FREQUENCY (HZ)  
FIGURE B


— LEGEND

ATTACHMENT 8  
PAGE 67 OF 108  
CALC. NO. C-0031/7190



HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
CHUGI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 54BR Z-TRAN LC = 1

AMPLITUDE



FREQUENCY (HZ)  
FIGURE 9


— LEGEND

ATTACHMENT 8  
PAGE 68 OF 108  
CALC. NO. C-0581/7TRD

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
CHUGI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 91 X-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

AMPLITUDE



FREQUENCY (HZ)


FIGURE 10

— LEGEND

ATTACHMENT B  
PAGE 69 OF 108  
CALC. NO. 2-0531/71RD

RR00 88/06/09 17.37.00

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
CHUGI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 91 Y-TRAN LC = 1



FREQUENCY (HZ)


FIGURE 11

— LEGEND

ATTACHMENT 8  
PAGE 70 OF 108  
CALC. NO. C-0031/1TR0

RR00 88/06/09 17.37.00


HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
CHUGI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 91 Z-TRAN LC = 1



ATTACHMENT 8  
PAGE 71 OF 108  
CALC. NO. C-0031/TIRD

RR00 88/06/09 17.37.00

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
CHUGI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 92 X-TRAN LC = 1



FREQUENCY (HZ)  
FIGURE 13

— LEGEND

ATTACHMENT 8  
PAGE 72 OF 108  
CALC. NO. C-0031/71R0

RR00 88/06/09 17.37.00

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
CHUGI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 92 Y-TRAN LC = 1





FIGURE 14

— LEGEND

ATTACHMENT 8  
PAGE 73 OF 108  
CALC. NO. C-0031/71RO

AR06 08/06/09 17.37.00

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
CHUGI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 92 Z-TRAN LC = .1



FREQUENCY (HZ)


FIGURE 15

— LEGEND

ATTACHMENT 8  
PAGE 74 OF 108  
CALC. NO. C-0031/7190

RR00 88/06/09 17.37.00

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
CHUGI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 145CP X-TRAN LC = 1



FREQUENCY (HZ)

FIGURE 16

— LEGEND

AMPLITUDE

ATTACHMENT


PAGE 75 OF 108

CALC. NO. C-0031/71RD



RAQ0 88/06/09 17.37:00

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
CHUGI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 145CP Y-TRAN LC = 1



FREQUENCY (HZ)


FIGURE 17

— LEGEND

ATTACHMENT 8  
PAGE 76 OF 108  
CALC. NO. C-9031/TIRO

RR00 88/06/09 17.37.00

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
CHUGI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE 145CP Z-TRAN LC = 1



FREQUENCY (HZ)

FIGURE 18

— LEGEND

ATTACHMENT 8  
PAGE 77 of 108  
CALC. NO. C-0031/TIRD

F

JOB NAME = AARK


DATE = 88/06/20

CHARGE = F3395JT

PROJECT = \*311\*XPS080502

OABI (w/ 3% Damping)

Spectra generated for 2%  
(Total 19 pages)




ATTACHMENT 3  
PAGE 78 of 108  
CALC. NO. 6-0031/71R0

MARK 88/06/20 14.22.20

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.2 (3%D)  
ACCEL RESPONSE SPECTRUM AT NODE 26BR X-TRAN LC = 1

AMPLITUDE



FREQUENCY (HZ)

FIGURE 1

— LEGEND

ATTACHMENT 8  
PAGE 79 OF 108  
CALC. NO. C-0531/71RO

MARK 88/06/20 14.22.20

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.2 (3% D)  
ACCEL RESPONSE SPECTRUM AT NODE 26BR Y-TRAN LC = 1





FIGURE 2

ATTACHMENT 8  
PAGE 80 OF 108  
CALC. NO. C-0531/7T10

ARRK 88/06/20 14.22.20

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.2 (3% D)  
ACCEL RESPONSE SPECTRUM AT NODE 26BR Z-TRAN LC = 1

AMPLITUDE




FREQUENCY (HZ)

FIGURE 3

— LEGEND

ATTACHMENT 8  
PAGE 81 of 108  
CALC. NO. C-0031/TIRB

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.2 (3%0)  
ACCEL RESPONSE SPECTRUM AT NODE 27BR X-TRAN LC = 1



FREQUENCY (HZ)


FIGURE 4

— LEGEND

ATTACHMENT 8  
PAGE 82 OF 108  
CALC. NO. C-0031/7IRD

ARK 88/06/20 14.22.20

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.2 (3%D)  
ACCEL RESPONSE SPECTRUM AT NODE 27BR Y-TRAN LC = 1



FREQUENCY (HZ)

FIGURE 5

— LEGEND


ATTACHMENT 8  
PAGE 83 OF 108  
CALC. NO. C-0031 TIR0



RARK 88/06/20 14.22.20

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.2 (3% D)  
ACCEL RESPONSE SPECTRUM AT NODE 27BR Z-TRAN LC = 1

AMPLITUDE



FREQUENCY (HZ)


FIGURE 6

— LEGEND

ATTACHMENT 8  
PAGE 84 OF 108  
CALC. NO. C-0031/TIRD

ARK 88/06/20 14.22.20

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.2 (3%D)  
ACCEL RESPONSE SPECTRUM AT NODE 54BR X-TRAN LC = 1



FREQUENCY (HZ)  
FIGURE 7


— LEGEND

ATTACHMENT 8  
PAGE 85 OF 108  
CALC. NO. C-00311/TIRD

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.2 (3% $\bar{D}$ )  
ACCEL RESPONSE SPECTRUM AT NODE 54BR Y-TRAN LC = .1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

AMPLITUDE



FREQUENCY (HZ)


FIGURE 8

— LEGEND

ATTACHMENT B  
PAGE 86 OF 108  
CALC. NO. C-0031/TIRO

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
 QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.2 (3% D)  
 ACCEL RESPONSE SPECTRUM AT NODE 54BR Z-TRAN LC = 1

AMPLITUDE



FREQUENCY (HZ)


FIGURE 9

— LEGEND

ATTACHMENT 8  
 PAGE 87 OF 108  
 CALC. NO. C-0031/TIAD

AARK 08/06/20 14.22.20

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.2 (3%0)  
ACCEL RESPONSE SPECTRUM AT NODE 91 X-TRAN LC = 1




FREQUENCY (HZ)

FIGURE 10

— LEGEND

ATTACHMENT 8  
PAGE 88 OF 108  
CALC. NO. C-0031/TIRO

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.2 (3% D)  
ACCEL RESPONSE SPECTRUM AT NODE 91 Y-TRAN LC = 1




FREQUENCY (HZ)  
FIGURE 11

— LEGEND

ATTACHMENT 8  
PAGE 89 OF 108  
CALC. NO. C-0031/7TRD

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.2 (3% D)  
ACCEL RESPONSE SPECTRUM AT NODE 91 Z-TRAN LC = 1



FREQUENCY (HZ)


FIGURE 12

— LEGEND

ATTACHMENT 8  
PAGE 90 OF 108  
CALC. NO. C-0031/TIR0

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.2 (3%D)  
ACCEL. RESPONSE SPECTRUM AT NODE 92 X-TRAN LC = 1

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222



FREQUENCY (HZ)

FIGURE 13


— LEGEND

ATTACHMENT 8  
PAGE 91 OF 108  
CALC. NO. C-0031/TIR0



HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.2 (3%D)  
ACCEL RESPONSE SPECTRUM AT NODE 92 Y-TRAN LC = 1.

USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222



FREQUENCY (HZ)

FIGURE 14

— LEGEND

ATTACHMENT 8  
PAGE 92 OF 108  
CALC. NO. C-0031/TIRD

AARK 88/06/20 14.22.20

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.2 (3%D)  
ACCEL RESPONSE SPECTRUM AT NODE 92 Z-TRAN LC = 1





FIGURE 15

— LEGEND

ATTACHMENT 8  
PAGE 93 OF 108  
CALC. NO. 2-0031/71RD

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.2 (3% $\theta$ )  
ACCEL RESPONSE SPECTRUM AT NODE 145CP X-TRAN LC = 1



FREQUENCY (HZ)


FIGURE 16

— LEGEND

ATTACHMENT 8  
PAGE 94 OF 108  
CALC. NO. C-0031/TIRD

RARK 88/06/20 14.22.20

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.2 (3% D)  
ACCEL RESPONSE SPECTRUM AT NODE 145CP Y-TRAN LC = 1



FREQUENCY (HZ)  
FIGURE 17


— LEGEND

ATTACHMENT 8  
PAGE 95 OF 108  
CALC. NO. C-0031/TIRD

ARK

88/06/20 14.22.20

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G), CASE C3.2 (3% D)  
ACCEL RESPONSE SPECTRUM AT NODE 145CP Z-TRAN LC = 1



FREQUENCY (HZ)

FIGURE 18

— LEGEND

ATTACHMENT 8  
PAGE 96 OF 128  
CALC. NO. C-0031/TIRO


USER RESPONSIBLE FOR VERIFYING REVISION, STATUS AND CHANGES  
PRINTED 20041222

JOB NAME = ABAV

DATE = 88/07/14

CHARGE = F3395JT

PROJECT = \*311\*XPS080502



Node P201

QABI 2% T.H. Damping Case C3-2


4 pages

ATTACHMENT 8  
PAGE 97 OF 108  
CALL NO. C-0031/TIRP

ABAV 08/07/14 19.23.04

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE P201 X-TRAN LC # 1

AMPLITUDE



FREQUENCY (HZ)

FIGURE 1

— LEGEND


ATTACHMENT 8  
PAGE 98 OF 108  
CALC. NO. C-0031/TIR0

ABRV 88/07/14 19.23.04

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE P201 Y-TRAN LC = 1

AMPLITUDE

5.0



FREQUENCY (HZ)

FIGURE 2


— LEGEND

ATTACHMENT 8  
PAGE 99 OF 108  
CALC. NO. C-0031/TIRO



ABAV 88/07/14 19.23.04

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
QABI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE P201 Z-TRAN LC = 1



FREQUENCY (HZ)

FIGURE 3

— LEGEND

ATTACHMENT 8  
PAGE 100 OF 108  
CALC. NO. G-0031/TIRD


JOB NAME = ABAY

DATE = 88/07/14

CHARGE = F3395JT


PROJECT = \*311\*XPS080502

Node P201 C&I (2% D.H. Damping)  
Total 4 Pages



ABBY 88/07/14 19.22.21

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
COI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE P201 X-TRAN LC = 1



FREQUENCY (HZ)

FIGURE 1


— LEGEND

ATTACHMENT 8  
PAGE 102 OF 108  
CALC. NO. C-0031/TIRO

ABAY 08/07/14 19.22.21

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
CO1 ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE P201 Y-TRAN LC = 1

AMPLITUDE



FREQUENCY (HZ)

FIGURE 2


— LEGEND

ATTACHMENT 8  
PAGE 103 OF 108  
CALC. NO. C-0031/71RD

ADAY 88/07/14 19.22.21

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
COI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE P201 Z-TRAN LC = 1

AMPLITUDE



FREQUENCY (HZ)

FIGURE 3

— LEGEND

ATTACHMENT 8  
PAGE 104 of 108  
CALC. NO. C-0031/TIRD


JOB NAME = ABBB

DATE = 88/07/14

CHARGE = F3395JT

PROJECT = \*311\*XPS080502


Node P201 CHUGI R/s  
(2% J.H. Damping)  
Total 4 pages



ATTACHMENT 8  
PAGE 125 of 108  
CALC. NO. C-0031/TIR0

R888 88/07/14 19.24.34

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
CHUGI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE P201 X-TRAN LC = 1



FREQUENCY (HZ)  
FIGURE 1

— LEGEND

ATTACHMENT 8  
PAGE 106 OF 108  
CALC. NO. C-0031/7TFO

ABBB 88/07/14 19.24.34

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
CHUGI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE P201 Y-TRAN LC = 1




FIGURE 2

— LEGEND

ATTACHMENT B  
PAGE 107 of 108  
CALC. NO. C-0031/TIRO



R888 88/07/14 19.24.34

HOPE CREEK NUCLEAR GEN. STATION UNIT-1, P201  
CHUGI ACCELERATION SPECTRUM (HZ,G)  
ACCEL RESPONSE SPECTRUM AT NODE P201 . Z-TRAN LC = 1




FIGURE 3

— LEGEND

ATTACHMENT 8  
PAGE 108 OF 108  
CALC. NO. C-0031/TIRO

SHT. 1 of 1

FORM NC.DE-AP.ZZ-0010-1

CERTIFICATION FOR DESIGN VERIFICATION

Reference No. C-0031/71RD

SUMMARY STATEMENT

This calculation is acceptable. Pipe Stress analysis is performed  
utilizing verified ~~xxxx~~ computer program. The verification  
process consists of reviewing support loads to assure that they  
are reasonable. The method of analysis is consistent with Hope Creek  
UFSAR. The documentation generated complies with E&PB manual  
requirements. The verifier is independant of the originators  
design.

The undersigned hereby certifies that the design verification for the subject document has been completed, the questions from the generic checklist have been reviewed and addressed as appropriate, and all comments have been adequately incorporated.

J. GOREA  
Design Verifier Assigned By

[Signature] 9/1/93  
Signature of Design Verifier / Date

J. GOREA  
Design Verifier Assigned By

Philip M. Stachel 7/29/94  
Signature of Design Verifier / Date

Design Verifier Assigned By

Signature of Design Verifier / Date

Design Verifier Assigned By

Signature of Design Verifier / Date

ATTACHMENT 9

Page 1 of 1

PAGE 1 OF 1

CALC. NO. C-0031/71RD.

Orig. Philip M. Stashak 9/2/93

CALC # C-31

ATTACHMENT 10  
PAGE 1 OF 41  
CALC. NO. 678-C-31/71Rφ

### INTERFERENCE WALKDOWN

Any potential interferences documented during construction were rewalked and reevaluated for new Snubber Reduction Program displacements. In addition, any other potential interferences were documented on Interference Resolution Forms and evaluated for the new displacements. No Interferences exist due to the piping displacements. The following pages of this Attachment document the evaluation of the potential interferences.

IRF# -NEW-


ATTACHMENT 2

INTERFERENCE RESOLUTION FORM

Pkg 8

TO: -N/A- ISOMETRIC# 1-P-FD-01 REV# 22  
FROM: -N/A- ROOM # (HPCI) REACTOR BLDG 54'  
DATE: -N/A-

SKETCH



RESOLUTION:

No interference exists. movement

F.E. SIGNATURE Philip M. Stachals DATE 5/6/23  
REWORK COMPLETED \_\_\_\_\_ DATE \_\_\_\_\_  
CONCURRENCE BY (IC) \_\_\_\_\_ DATE \_\_\_\_\_

REWORK REQUIRED:  YES  NO

IRF# -NEW-


ATTACHMENT 2

INTERFERENCE RESOLUTION FORM

Pkg. 8

TO: -N/A- ISOMETRIC# 1-P-FD-C1 REV# 22  
FROM: -N/A- ROOM # TORUS  
DATE: -N/A-

SKETCH



RESOLUTION:

OLD movements larger than new movements, 1/4" clearance is acceptable.

F.E. SIGNATURE Philip M. Sturck DATE 5/6/95  
REWORK COMPLETED \_\_\_\_\_ DATE \_\_\_\_\_  
CONCURRENCE BY (IC) \_\_\_\_\_ DATE \_\_\_\_\_

REWORK REQUIRED:  YES  NO

IRF# -NEW-


ATTACHMENT 2

INTERFERENCE RESOLUTION FORM

Plg. 8

TO: -N/A- ISOMETRIC# 1-P-FD-01 REV# 22  
 FROM: -N/A- ROOM # (HPCI) REACTOR BLDG 5A'  
 DATE: -N/A-

SKETCH



RESOLUTION:

Clearance greater than movement. OK.

F.E. SIGNATURE Philip M. Strahl DATE 5/6/93  
 REWORK COMPLETED \_\_\_\_\_ DATE \_\_\_\_\_  
 CONCURRENCE BY (IC) \_\_\_\_\_ DATE \_\_\_\_\_

REWORK REQUIRED:  YES  NO