

Rancho Seco Nuclear Generating Station
Decommissioning Technical Basis Document

DTBD-06-002


Revision No. 0

DPT 06-011

RIC 2A.900

**Use of a Survey Unit Size of 319 m² for Class One Structure Surveys
at Rancho Seco Nuclear Generating Station**

PREPARED BY:


Author

2/9/06
Date

REVIEWED BY: JM Newey
Technical Reviewer

3/6/06
Date

REVIEWED BY: Michael D. Brown
QA Reviewer

3/22/06
Date

APPROVED BY: E. T. S.
Principal Radiological Engineer

6-6-06
Date

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 1 OF 215

1.0 PURPOSE

The purpose of this Decommissioning Technical Basis Document (DTBD) is to establish the basis for the use of a survey unit size of 319 m² for Class 1 structure surveys.

2.0 DISCUSSION

NUREG-1575 provides suggested survey unit sizes in section 4.6 (100 m² for Class 1 structures). The NUREG requires that the survey units share common characteristics and be limited to a single classification. The NUREG further states that survey units be consistent with the dose model used and notes that Class 1 indoor rooms could be a single survey unit or could be split into lower and upper survey units if floor contamination is significantly greater than that on the upper walls and ceiling. The only real constraints are consistency with the dose model and controlling the size such that the sample density is not less than that described for the suggested size. This technical basis document establishes a survey unit size of 319 m² as being consistent with the dose model used in the LTP (DTBD 04-004) for structures, demonstrates that the annual dose rate of 25 mrem is achieved, and preserves the sample density of NUREG-1575. In addition, conservative area factors for use with the larger survey unit size are provided.

3.0 DEFINITIONS

Area Factors-a geometry correction factor applied to the activity in a small area which results in a value which exceeds the DCGL and yet still maintains compliance with the release criterion.

Sample Density-the number of measurements required in a survey unit per m² which provides an adequate number of values to meet the requirements of the statistical test used at the applied confidence level. Sample density is a function of survey unit size and data variability.

4.0 TECHNICAL POSITION

RESRAD-Build has been appropriately used to determine a conservative room size for the Building Occupant scenario which meets the criteria outlined in both NUREG/CR-5512 and NUREG-1575. Based on the output of RESRAD-Build and the additional evaluation performed using Microshield to evaluate the external exposure from structures, RSNGS proposes to use a maximum structure survey unit size of 319 m² total surface area for Class 1 structures. The area factors calculated for 137 m² (DTBD 05-003) will be conservatively used.

5.0 LIMITATIONS

The survey unit size is limited to Class 1 structures only.

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 2 OF 215

In order to ensure an adequate sample density, 45 direct measurements will be required in a 319 m² survey unit which preserves the sample density of 1/7 m² (the sample density for an N of 14 used with a survey surface area of 100 m²).

6.0 TECHNICAL BASES

NUREG/CR-5512 establishes the basis for the radiological parameters used in dose modeling. The dose to the building occupant is mainly external whole body dose from the gamma emitters on the building surfaces. In the section describing the Building Occupancy scenario, NUREG/CR-5512 points out that the use of an infinite plane source approximates the dose rate of a room having non-uniform contamination levels (i.e., contamination is higher on the floor than the walls and higher on the walls than the ceiling). The NUREG states that dose rates are nearly equivalent using either the infinite plane or the multiple plane source geometry for rooms in the 100 m³ to 250 m³ size and the infinite plane over estimates the dose rate for smaller rooms. NUREG-1575 "suggests" a survey unit size of 100 m² floor area for a Class 1 survey unit based on the assumption that a small office would be occupied by the receptor. Therefore the building occupant dose should be conservatively bounded by the dose equivalent from the floor surface modeled as an infinite plane Co-60 source at the screening level of 15,200 dpm/100 cm². Attachment 8.1 provides the Microshield run showing that the infinite plane dose equivalent rate for Co-60 at the screening value is approximately 49 mrem/y for 2000 hours per year.

The NUREG expands the dose model by describing the room as an 8m by 8m room with 3 m high walls and also as a 100 m² floor area. The model considers the lower wall contribution, but at a reduced contamination level. Both of these situations were considered in the survey unit sizes shown in Table 2 (the first and second entries respectively).

DTBD 04-004 describes the dose model used for the Rancho Seco Building Occupancy scenario. Using the probabilistic version of RESRAD-Build, room size was analyzed to determine whether it was a sensitive parameter. Room size was found to be a sensitive parameter in determining dose to the room occupant and, as a result, a distribution of site room sizes was evaluated to determine the most probable size with respect to dose determination. RESRAD-Build determined that a room having a floor area of 137 m² (11.7 m by 11.7 m) was the most likely and conservative size to use for dose modeling. Wall height was determined to be 3.89 m which created a room volume of 533 m³. The dose model was then used to derive the dose to the occupant located in the center of the room (i.e., the floor and 4 full-height walls having a total surface area of 319 m²) contaminated at the Total DCGL of 45,500 dpm/100 cm² with the nuclide mixture specified in DTBD 05-015 (Table 1 below). (DTBD 05-015 derived the gross beta DCGL of 43,000 dpm/100 cm² using the average of the fractions method. The gross beta DCGL is based on only the beta emitting nuclides in the mixture and correcting for the remaining non-beta emitting nuclides gives a Total DCGL by the average of the fractions method of 45,500 dpm/100 cm².) Note that Cs-137 makes up approximately

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 3 OF 215

84 percent of the total activity with Co-60 comprising just 2 percent which results in lower dose rates than the Co-60 plane source model.

Table 1 Total DCGL Converted to uCi/cm²

Source Term	45,500 dpm/100 cm ²	DCGL dpm/100 cm ²	Activity uCi/cm ²
Nuclide	nf		
Co-60	2.07E-02	943	4.24E-06
Sr-90	8.35E-02	3800	1.71E-05
Cs-134	3.29E-04	15	6.74E-08
Cs-137	8.39E-01	38200	1.72E-04
Pu-238	1.17E-03	53	2.40E-07
Pu-239	3.73E-04	17	7.64E-08
Pu-240	3.73E-04	17	7.64E-08
Pu-241	5.33E-02	2420	1.09E-05
Am-241	1.05E-03	48	2.15E-07
Sum	1.00E+00	45513	2.05E-04

RESRAD-Build was then used to calculate the dose equivalent rate 1 m from a floor at the center of a room and 4 walls of various sizes to determine the dose rate effect on room size. Floor areas ranged from 64 m² to 319 m² and wall heights ranged from 2 m high to 3.89 m high. A geometry assuming 319 m² as a plane source as well as a room geometry with a ceiling included and a total surface area of 319 m² were also evaluated as shown in Table 2. The survey unit size with the DTBD 04-004 dose model applied is shown in the next to the last row in Table 2. Assuming the Table 1 source term on all structure surfaces, the dose equivalent rates were all determined to be less than the infinite plane value and less than 25 mrem/y. Reducing the size of the room reduces the dose rates as shown in Table 1 consistent with the information provided in NUREG/CR-5512. The results of the various RESRAD-Build runs are shown in Table 2.

Table 2. TEDE Versus Survey Unit Size

SU Size, m ²	Floor Area, m ²	Wall Area, m ²	Ceiling, m ²	TEDE, mrem/y
160	64	96	-----	16.4
220	100	120	-----	17.5
231	137	93.6	-----	17.2
256	100	155.6	-----	18.8
281	137	142.8	-----	18.6
319	319	-----	-----	18.1
319	137	181.6	-----	19.8
319	100	120	100	23.1

Area Factors for direct dose were recalculated for a room surface of 319 m² as shown in Attachment 8.3. Since the Area Factors presented in chapter 6 of the LTP (DTBD 05-

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 4 OF 215

003) are just slightly less based on 137 m², the LTP factors for direct dose will be used for evaluation of elevated areas in Class 1 structures.

The evaluation demonstrates that a survey unit size of 319 m² at the structure surface Total DCGL activity level meets the 25 mrem/y release criterion under the likely geometries in which it could be employed: 1) a 319 m² plane source (e.g., a wall area), 2) a 319 m² room with a floor of 137 m² and four walls of 45.5 m², or 3) a small cubicle of 319 m² with a floor, ceiling and four walls.

7.0 REFERENCES

- 7.1 NUREG-1575, "Multi-Agency Radiation Survey and Site Investigation Manual", August 2000.
- 7.2 NUREG/CR-5512, "Residual Radioactive Contamination From Decommissioning".
- 7.3 DTBD 04-004, "DCGL for Structure Surfaces".
- 7.4 DTBD 05-003, "Soil and Surface Area Factors for Use at RNGS".
- 7.5 DTBD 05-015, "Structure Nuclide Fractions and DCGLs".

8.0 ATTACHMENTS

- 8.1 Microshield Run, Infinite Plane Source
- 8.2 RESRAD-Build Outputs
- 8.3 Microshield Runs for Area Factors

9.0 RESPONSIBLE INDIVIDUAL

George Pillsbury

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 5 OF 215

Attachment 8.1

**Microshield Run
Co-60 Infinite Plane At Screening Level**

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 6 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District

Page : 1
DOS File : Case1
Run Date : February 7, 2006
Run Time: 10:08:57 AM
Duration : 00:00:00

File Ref: _____
Date: _____
By: _____
Checked: _____

Case Title: Case 1
Description: Case 1
Geometry: 15 - Infinite Plane



Dose Points			
#	X	Y	Z
# 1	100 cm 3 ft 3.4 in	0 cm 0.0 in	0 cm 0.0 in

Shields		
Shield Name	Material	Density
Air Gap	Air	0.00122

Source Input
Grouping Method : Actual Photon Energies

Nuclide	$\mu\text{Ci}/\text{cm}^2$	Bq/cm^2
Co-60	6.8500e-005	2.5345e+000

Buildup
The material reference is : Air Gap

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Results</u>		<u>Exposure Rate</u> <u>mR/hr</u>	<u>Exposure Rate</u> <u>mR/hr</u>
			<u>No Buildup</u>	<u>With Buildup</u>		
0.6938	4.134e-04	5.910e-04	5.910e-04	5.910e-04	1.141e-06	1.141e-06
1.1732	2.535e+00	6.497e+00	6.497e+00	6.497e+00	1.161e-02	1.161e-02
1.3325	2.535e+00	7.488e+00	7.488e+00	7.488e+00	1.299e-02	1.299e-02
TOTALS:	5.069e+00	1.399e+01	1.399e+01	1.399e+01	2.460e-02	2.460e-02

Attachment 8.2

RESRAD Build Outputs

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 8 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 12:55:35 Page: 1 --
Title : 160 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site2.bld

RESRAD-BUILD Table of Contents

RESRAD-BUILD Input Parameters.....	2
Building Information.....	3
Source Information.....	4
For time = 0.00E+00 yr	
Time Specific Parameters.....	9
Receptor-Source Dose Summary.....	14
Dose by Pathway Detail.....	15
Dose by Nuclide Detail.....	16
Full Summary.....	21

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 9 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 12:55:35 Page: 2 **
Title : 160 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site2.bld

RESRAD-BUILD Input Parameters

Number of Sources : 5
Number of Receptors: 1
Total Time : 3.650000E+02 days
Fraction Inside : 2.670000E-01

Receptor Information

Receptor	Room	x [m]	y [m]	z [m]	FracTime	Inhalation [m ³ /day]	Ingestion(Dust) [m ² /hr]
1	1	4.000	4.000	1.000	1.000	3.57E+01	1.61E-04

Receptor-Source Shielding Relationship

Receptor	Source	Density [g/cm ³]	Thickness [cm]	Material
1	1	2.40E+00	0.00E+00	Concrete
1	2	2.40E+00	0.00E+00	Concrete
1	3	2.40E+00	0.00E+00	Concrete
1	4	2.40E+00	0.00E+00	Concrete
1	5	2.40E+00	0.00E+00	Concrete

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 10 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 12:55:35 Page: 3 --
Title : 160 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site2.bld

Building Information

Building Air Exchange Rate: 8.35E-01 1/hr

Height [m]	Air Exchanges [m ³ /hr]
Area [m ²]	*****
*	*
*	*
*	Q01: 1.60E+02
H1: 3.000	Room 1
*	LAMBDA: 8.35E-01
Area 64.000	*
*	*
*	*
*	Q10 : 1.60E+02
*****	*****

Deposition velocity: 4.78E-04 [m/s] Resuspension Rate: 1.33E-09 [1/s]

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 11 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 12:55:35 Page: 4 **
 Title : 160 m2 room
 Input File : C:\Program Files\RESRAD_Family\BUILD\site2.bld

Source Information

Source: 1

Location:: Room : 1 x: 4.00 y: 4.00 z: 0.00[m]
 Geometry:: Type: Area Length[m]:8.00E+00 Width[m]:8.00E+00 Direction: z
 Pathway ::
 Direct Ingestion Rate: 3.450E-07 [1/hr]
 Fraction released to air: 5.170E-01
 Removable fraction: 1.000E-01
 Time to Remove: 5.280E+04 [day]
 Radon Release Fraction: 0.000E+00

Contamination::**Nuclide Concentration****Dose Conversion Factor (Library: FGR 13 Morbidity)**

		Ingestion [mrem/dpm]	Inhalation [mrem/dpm]	Submersion [mrem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
Pa-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PR-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 12 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 12:55:35 Page: 5 --
Title : 160 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site2.bld

Source: Z

Location:: Room : 1 x: 0.00 y: 4.00 z: 0.00[m]

Geometry:: Type: Area Length[m]:8.00E+00 Width[m]:3.00E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::

Nuclide Concentration

Dose Conversion Factor (Library: FGR 13 Morbidity)

	[dpm/m ²]	Ingestion [mrem/dpm]	Inhalation [mrem/dpm]	Submersion [mrem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.600E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
ND-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 13 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 12:55:35 Page: 6 **
 Title : 160 m² room
 Input File : C:\Program Files\RESRAD_Family\BUILD\site2.bld

Source: 3

Location:: Room : 1 x: 4.00 y: 0.00 z: 0.00[m]
 Geometry:: Type: Area Length[m]:6.00E+00 Width[m]:3.00E+00 Direction: y
 Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]
 Fraction released to air: 5.170E-01
 Removable fraction: 1.000E-01
 Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::**Nuclide Concentration Dose Conversion Factor (Library: FGR 13 Morbidity)**

		Ingestion [dpm/m ²]	Inhalation [rem/dpm]	Submersion [rem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.459E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	8.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PE-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SX-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-02

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 14 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 12:55:35 Page: 7 **

Title : 160 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site2.bld

Source: 4

Location:: Room : 1 x: 8.00 y: 4.00 z: 0.00[m]

Geometry:: Type: Area Length[m]:8.00E+00 Width[m]:3.00E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::

 Nuclide Concentration

 Dose Conversion Factor (Library: FGR 13 Morbidity

		Ingestion [mrem/dpm]	Inhalation [mrem/dpm]	Submersion [mrem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
Pa-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.586E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	8.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	8.871E-03	4.663E-03
PR-210	0.000E+00	2.422E-03	6.214E-03	4.692E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	5.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 15 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 12:55:35 Page: 8 **
 Title : 160 m² room
 Input File : C:\Program Files\RESRAD_Family\BUILD\site2.bld

Source: 5

Location:: Room : 1 x: 4.00 y: 8.00 z: 0.00[m]

Geometry:: Type: Area Length[m]:3.00E+00 Width[m]:3.00E+00 Direction: y

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::

Nuclide Concentration

Dose Conversion Factor (Library: NCR 13 Morbidity)

	[dpm/m ²]	Ingestion [mrem/dpm]	Inhalation [mrem/dpm]	Submersion [mrem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 16 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 12:55:35 Page: 9 --

Title : 160 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site2.bld

Evaluation Time: 0.00000000E+00 years

Assessment for Time: 1
Time =0.00E+00 yr

Source Information

Source: 1

Location:: Room : 1 x: 4.00 y: 4.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:8.00E+00 Width[m]:8.00E+00 Direction: z

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	IH-232	0.000E+00
	IH-230	0.000E+00
	IH-229	0.000E+00
	IH-228	0.000E+00
	ZC-227	0.000E+00
	EA-226	0.000E+00
	RA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SZ-90	3.500E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 17 OF 215

** NERAD-BUILD Base Program Output, Version 3.3 02/21/06 12:55:35 Page: 10 **

Title : 160 m² room

Input File : C:\Program Files\NERAD_Family\BUILD\site2.bld

Evaluation Time: 0.0000000Z+00 years

Source: 2

Location:: Room : 1 x: 0.00 y: 4.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:8.00E+00 Width[m]:3.00E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	IH-232	0.000E+00
	IH-230	0.000E+00
	IH-229	0.000E+00
	IH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PR-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 18 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 12:55:35 Page: 11 --

Title : 160 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site2.bld

Evaluation Time: 0.0000000E+00 years

Source: 3

Location:: Room : 1 x: 4.00 y: 0.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:8.00E+00 Width[m]:3.00E+00 Direction: y

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.260E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	IH-232	0.000E+00
	IH-230	0.000E+00
	IH-229	0.000E+00
	IH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 19 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 12:55:35 Page: 12 **

Title : 160 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site2.hld

Evaluation Time: 0.0000000E+00 years

Source: 4

Location:: Room : 1 x: 8.00 y: 4.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:8.00E+00 Width[m]:3.00E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	FA-231	0.000E+00
	IH-232	0.000E+00
	IH-230	0.000E+00
	IH-229	0.000E+00
	IH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PR-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 20 OF 215

-- ESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 12:55:35 Page: 13 --

Title : 160 m² room

Input File : C:\Program Files\ESRAD_Family\BUILD\site2.bld

Evaluation Time: 0.0000000E+00 years

Source: 5

Location:: Room : 1 x: 4.00 y: 8.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:8.00E+00 Width[m]:3.00E+00 Direction: y

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination:	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	IH-232	0.000E+00
	IH-230	0.000E+00
	IH-229	0.000E+00
	IH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 21 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 12:55:35 Page: 14 **

Title : 160 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site2.bld

Evaluation Time: 0.0000000E+00 years

RESRAD-BUILD Dose Tables

Source Contributions to Receptor Doses

[mrem]

	Source 1	Source 2	Source 3	Source 4	Source 5	Total
Receptor 1	1.05E+01	1.48E+00	1.48E+00	1.48E+00	1.48E+00	1.64E+01
Total	1.05E+01	1.48E+00	1.48E+00	1.48E+00	1.48E+00	1.64E+01

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 22 OF 215

** RESEAD-BUILD Dose Program Output, Version 3.3 02/21/06 12:55:35 Page: 15 **
 Title : 160 m2 room
 Input File : C:\Program Files\RESEAD_Family\BUILD\site2.bld
 Evaluation Time: 0.00000000E+00 years

Pathway Detail of Doses

[mrem]

Source: 1

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	9.35E+00	2.66E-02	2.07E-05	1.90E-01	3.45E-24	8.97E-01
Total	9.35E+00	2.66E-02	2.07E-05	1.90E-01	3.45E-24	8.97E-01

Source: 2

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	1.06E+00	9.98E-03	7.75E-06	7.11E-02	1.29E-24	3.36E-01
Total	1.06E+00	9.98E-03	7.75E-06	7.11E-02	1.29E-24	3.36E-01

Source: 3

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	1.06E+00	9.98E-03	7.75E-06	7.11E-02	1.29E-24	3.36E-01
Total	1.06E+00	9.98E-03	7.75E-06	7.11E-02	1.29E-24	3.36E-01

Source: 4

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	1.06E+00	9.98E-03	7.75E-06	7.11E-02	1.29E-24	3.36E-01
Total	1.06E+00	9.98E-03	7.75E-06	7.11E-02	1.29E-24	3.36E-01

Source: 5

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	1.06E+00	9.98E-03	7.75E-06	7.11E-02	1.29E-24	3.36E-01
Total	1.06E+00	9.98E-03	7.75E-06	7.11E-02	1.29E-24	3.36E-01

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 23 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 12:55:35 Page: 16 **
Title : 160 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site2.bld
Evaluation Time: 0.00000000E+00 years

Nuclide Detail of Doses

[mrem]

Source: 1

Nuclide Receptor	Total
1	
PU-241	
PU-241	7.93E-02
AM-241	4.40E-03
NP-237	6.09E-10
U-233	9.95E-17
TH-229	2.99E-20
AM-241	
AM-241	1.11E-01
NP-237	2.29E-08
U-233	4.97E-15
TH-229	1.86E-18
PU-240	
PU-240	3.85E-02
U-236	1.03E-10
TH-232	2.10E-20
TH-228	1.08E-23
RA-228	9.04E-23
PU-239	
PU-239	3.85E-02
U-235	3.96E-12
PA-231	4.00E-16
AC-227	8.12E-18
PU-238	
PU-238	1.00E-01
U-234	3.25E-08
TH-230	2.29E-13
RA-226	2.76E-17
PB-210	2.28E-19
CS-137	
CS-137	9.06E+00
CS-134	
CS-134	8.08E-03
SR-90	
SR-90	1.81E-01
CO-60	
CO-60	8.40E-01

**TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station**

PAGE 24 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 12:55:35 Page: 17 **
 Title : 160 m² room
 Input File : C:\Program Files\RESRAD_Family\BUILD\site2.bld
 Evaluation Time: 0.00000000E+00 years

Source: 2

Nuclide	Receptor	Total
		1
PU-241		
PU-241	2.97E-02	2.97E-02
AM-241	1.64E-03	1.64E-03
NP-237	2.23E-10	2.23E-10
U-233	3.73E-17	3.73E-17
TH-229	1.10E-20	1.10E-20
AM-241		
AM-241	4.13E-02	4.13E-02
NP-237	8.38E-09	8.38E-09
U-233	1.86E-15	1.86E-15
TH-229	6.89E-19	6.89E-19
PU-240		
PU-240	1.44E-02	1.44E-02
U-236	3.85E-11	3.85E-11
TH-232	7.87E-21	7.87E-21
TH-228	2.83E-24	2.83E-24
RA-228	2.19E-23	2.19E-23
PU-239		
PU-239	1.44E-02	1.44E-02
U-235	1.33E-12	1.33E-12
PA-231	1.50E-16	1.50E-16
AC-227	3.03E-18	3.03E-18
PU-238		
PU-238	3.76E-02	3.76E-02
U-234	1.22E-08	1.22E-08
TH-230	8.59E-14	8.59E-14
RA-226	6.08E-18	6.08E-18
PB-210	8.56E-20	8.56E-20
CS-137		
CS-137	1.18E+00	1.18E+00
CS-134		
CS-134	9.76E-04	9.76E-04
SR-90		
SR-90	6.55E-02	6.55E-02
CO-60		
CO-60	9.71E-02	9.71E-02

Source: 3

Nuclide	Receptor	Total
		1
PU-241		
PU-241	2.97E-02	2.97E-02

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 25 OF 215

** RESEAD-BUILD Dose Program Output, Version 3.3 02/21/06 12:55:35 Page: 18 **

Title : 160 m² room

Input File : C:\Program Files\RESEAD_Family\BUILD\site2.bld

Evaluation Time: 0.00000000E+00 years

AM-241	1.64E-03	1.64E-03
NP-237	2.23E-10	2.23E-10
U-233	3.73E-17	3.73E-17
TH-229	1.10E-20	1.10E-20
AM-241		
AM-241	4.13E-02	4.13E-02
NP-237	8.38E-09	8.38E-09
U-233	1.86E-15	1.86E-15
TH-229	6.89E-19	6.89E-19
PU-240		
PU-240	1.44E-02	1.44E-02
U-236	3.85E-11	3.85E-11
TH-232	7.87E-21	7.87E-21
TH-228	2.83E-24	2.83E-24
RA-228	2.19E-23	2.19E-23
PU-239		
PU-239	1.44E-02	1.44E-02
U-235	1.33E-12	1.33E-12
PA-231	1.50E-16	1.50E-16
AC-227	3.03E-18	3.03E-18
PU-238		
PU-238	3.76E-02	3.76E-02
U-234	1.22E-08	1.22E-08
TH-230	8.59E-14	8.59E-14
RA-226	6.08E-18	6.08E-18
FB-210	8.56E-20	8.56E-20
CS-137		
CS-137	1.18E+00	1.18E+00
CS-134		
CS-134	9.76E-04	9.76E-04
SR-90		
SR-90	6.55E-02	6.55E-02
CO-60		
CO-60	9.71E-02	9.71E-02

Source: 4

Nuclide Receptor	Total
1	
PU-241	
PU-241	2.97E-02
AM-241	1.64E-03
NP-237	2.23E-10
U-233	3.73E-17
TH-229	1.10E-20
AM-241	
AM-241	4.13E-02
NP-237	8.38E-09
U-233	1.86E-15
TH-229	6.89E-19

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 26 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 12:55:35 Page: 19 **
 Title : 160 m² room
 Input File : C:\Program Files\RESRAD_Family\BUILD\site2.bld
 Evaluation Time: 0.0000000E+00 years

PU-240		
PU-240	1.44E-02	1.44E-02
U-236	3.85E-11	3.85E-11
IH-232	7.87E-21	7.87E-21
IH-228	2.83E-24	2.83E-24
RA-228	2.19E-23	2.19E-23
PU-239		
PU-239	1.44E-02	1.44E-02
U-235	1.33E-12	1.33E-12
PA-231	1.50E-16	1.50E-16
AC-227	3.03E-18	3.03E-18
PU-238		
PU-238	3.76E-02	3.76E-02
U-234	1.22E-08	1.22E-08
IH-230	8.59E-14	8.59E-14
RA-226	6.08E-18	6.08E-18
PR-210	8.56E-20	8.56E-20
CS-137		
CS-137	1.18E+00	1.18E+00
CS-134		
CS-134	9.76E-04	9.76E-04
SR-90		
SR-90	6.55E-02	6.55E-02
CO-60		
CO-60	9.71E-02	9.71E-02

Source: 5

Nuclide Receptor	Total
	1
PU-241	
PU-241	2.97E-02
AM-241	1.64E-03
NP-237	2.23E-10
U-233	3.73E-17
IH-229	1.10E-20
AM-241	
AM-241	4.13E-02
NP-237	8.38E-09
U-233	1.86E-15
IH-229	6.89E-19
PU-240	
PU-240	1.44E-02
U-236	3.85E-11
IH-232	7.87E-21
IH-228	2.83E-24
RA-228	2.19E-23
PU-239	
PU-239	1.44E-02
U-235	1.33E-12

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 27 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 12:55:35 Page: 20 --

Title : 160 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site2.bld

Evaluation Time: 0.0000000E+00 years

PA-231	1.50E-16	1.50E-16
AC-227	3.03E-18	3.03E-18
PU-238		
FU-238	3.76E-02	3.76E-02
U-234	1.22E-08	1.22E-08
TH-230	8.59E-14	8.59E-14
RA-226	6.08E-18	6.08E-18
PB-210	8.56E-20	8.56E-20
CS-137		
CS-137	1.18E+00	1.18E+00
CS-134		
CS-134	9.76E-04	9.76E-04
SR-90		
SR-90	6.55E-02	6.55E-02
CO-60		
CO-60	9.71E-02	9.71E-02

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 28 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 12:55:35 Page: 21 **

Title : 160 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site2.bld

Full Summary

RESRAD-BUILD Dose (Time) Tables

Receptor Dose Received for the Exposure Duration

(mrem)

Evaluation Time [yr]

0.00E+00

1 1.64E+01

Receptor Dose/Yr Averaged Over Exposure Duration

(mrem/yr)

Evaluation Time [yr]

0.00E+00

1 1.64E+01

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 29 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:20:42 Page: 1 **
Title : 220 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site3.bld

RESRAD-BUILD Table of Contents

RESRAD-BUILD Input Parameters.....	2
Building Information.....	3
Source Information.....	4
For time = 0.00E+00 yr	
Time Specific Parameters.....	9
Receptor-Source Dose Summary.....	14
Dose by Pathway Detail.....	15
Dose by Nuclide Detail.....	16
Full Summary.....	21

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 30 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:20:42 Page: 2 **
Title : 220 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site3.bld

RESRAD-BUILD Input Parameters

Number of Sources : 5
Number of Receptors: 1
Total Time : 3.650000E+02 days
Fraction Inside : 2.670000E-01

Receptor Information

Receptor	Room	x [m]	y [m]	z [m]	Fractime	Inhalation [m ³ /day]	Ingestion(Dust) [m ² /hr]
1	1	5.000	5.000	1.000	1.000	3.57E+01	1.61E-04

Receptor-Source Shielding Relationship

Receptor	Source	Density [g/cm ³]	Thickness [cm]	Material
1	1	2.40E+00	0.00E+00	Concrete
1	2	2.40E+00	0.00E+00	Concrete
1	3	2.40E+00	0.00E+00	Concrete
1	4	2.40E+00	0.00E+00	Concrete
1	5	2.40E+00	0.00E+00	Concrete

**TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station**

PAGE 31 OF 215

** RESRAD-BUILD Base Program Output, Version 3.3 02/21/06 13:20:42 Page: 3 **
Title : 220 m² room
Input File : C:\Program Files\RESRAD Family\BUILD\site3.bld

Building Information

Building Air Exchange Rate: 8.35E-01 1/hr

Height [m]	Air Exchanges [m³/hr]
Area [m²]	*****
	*
	*
	*
	*
	*
	<001: 2.50E+02
H1: 3.000	*
	Room 1
	*
	LANRDA: 8.35E-01
Area 100.000	*
	*
	*
	*

Deposition velocity: 4.78E-04 [m/s] Resuspension Rate: 1.33E-09 [1/s]

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 32 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:20:42 Page: 4 **
 Title : 220 m² room
 Input File : C:\Program Files\RESRAD_Family\BUILD\site3.bld

Source Information**Source: 1**

Location:: Room : 1 x: 5.00 y: 5.00 z: 0.00[m]
 Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:1.00E+01 Direction: z
 Pathway ::
 Direct Ingestion Rate: 3.450E-07 [1/hr]
 Fraction released to air: 5.170E-01
 Removable fraction: 1.000E-01
 Time to Remove: 5.280E+04 [day]
 Radon Release Fraction: 0.000E+00

Contamination::**Nuclide Concentration Dose Conversion Factor (Library: FGR 13 Morbidity)**

		Ingestion [dpm/m ²]	Inhalation [mrem/dpm]	Submersion [mrem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	8.029E+00	5.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
FE-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	5.430E+04	1.212E-05	9.865E-05	6.629E-03

**TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station**

PAGE 33 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:20:42 Page: 5 **
 Title : 220 m² room
 Input File : C:\Program Files\RESRAD_Family\BUILD\site3.bld

Source: 2

Location:: Room : 1 x: 0.00 y: 5.00 z: 0.00[m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.00E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::

Nuclide Concentration

Dose Conversion Factor (Library: FGR 13 Morbidity)

	[dpm/m ²]	Ingestion [mrem/dpm]	Inhalation [mrem/dpm]	Submersion [mrem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PR-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.620E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.283E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 34 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:20:42 Page: 6 **
 Title : 220 m² room
 Input File : C:\Program Files\RESRAD_Family\BUILD\site3.bld

Source: 3

Location:: Room : 1 x: 5.00 y: 0.00 z: 0.00[m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.00E+00 Direction: y

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::**Nuclide Concentration Dose Conversion Factor (Library: FCR 13 Morbidity)**

		Ingestion [dpm/m ²]	Inhalation [mrem/dpm]	Submersion [mrem/yx/ (dpm/m ³)]
PU-241	2.420E+05	2.081E-05	3.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.614E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	8.620E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.802E-05	2.081E-05	3.983E-03
SR-90	8.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 35 OF 215

** RESEAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:20:42, Page: 7 **
 Title : 220 m² room
 Input File : C:\Program Files\RESEAD_Family\BUILD\site3.hld

Source: 4

Location:: Room : 1 x: 10.00 y: 5.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.00E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 8.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::**Nuclide Concentration Dose Conversion Factor (Library: FGR 13 Morbidity)**

		Ingestion [dpm/m ²]	Inhalation [mrem/dpm]	Submersion [mrem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.021E-05	2.716E-03	1.151E-02
AN-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
DU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
ND-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-226	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
BB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.802E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 36 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:20:42 Page: 6 --
Title : 220 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site3.bld

Source: 5

Location:: Room : 1 x: 5.00 y: 10.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.00E+00 Direction: y

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::**Nuclide Concentration****Dose Conversion Factor (Library: FGR 13 Morbidity)**

		Ingestion [dpm/m ²]	Inhalation [mrem/dpm]	Submersion [mrem/yr/ (dpm/m ³)]
FU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
FU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
FU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
FU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PR-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
Sr-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 37 OF 215

-- REZRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:20:42 Page: 9 --

Title : 220 m2 room

Input File : C:\Program Files\REZRAD_Family\BUILD\site3.bld

Evaluation Time: 0.00000000E+00 years

Assessment for Time: 1
Time =0.00E+00 yr

Source Information

Source: 1

Location:: Room : 1 x: 5.00 y: 5.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:1.00E+01 Direction: z

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	TH-232	0.000E+00
	TH-230	0.000E+00
	TH-229	0.000E+00
	TH-228	0.000E+00
	AC-227	0.000E+00
	Ra-228	0.000E+00
	KA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	Sr-90	3.600E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 38 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:20:42 Page: 10 --

Title : 220 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site3.bld

Evaluation Time: 0.0000000E+00 years

Source: 2

Location:: Room : 1 x: 0.00 y: 5.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.00E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	EU-240	1.700E+03
	EU-239	1.700E+03
	EU-238	5.310E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	TH-232	0.000E+00
	TH-230	0.000E+00
	TH-229	0.000E+00
	TH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 39 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:20:42 Page: 11 --

Title : 220 m² room

Input File : C:\Program Files\RESRAD Family\BUILD\site3.bld

Evaluation Time: 0.00000000E+00 years

Source: 3

Location:: Room : 1 x: 5.00 y: 0.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.00E+00 Direction: y

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.840E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	IH-232	0.000E+00
	IH-230	0.000E+00
	IH-229	0.000E+00
	IH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 40 OF 215

-- RESPAD-BUILD Dose Program Output, Version 3.3 02/21/06 18:20:42 Page: 12 --

Title : 220 m² room

Input File : C:\Program Files\RESPAD_Family\BUILD\site3.bld

Evaluation Time: 0.0000000E+00 years

Source: 4

Location:: Room : 1 x: 10.00 y: 5.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.00E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	TH-232	0.000E+00
	TH-230	0.000E+00
	TH-229	0.000E+00
	TH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	Sr-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 41 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:20:42 Page: 13 **

Title : 220 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site3.bld

Evaluation Time: 0.0000000E+00 years

Source: 5

Location:: Room : 1 x: 5.00 y: 10.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.00E+00 Direction: y

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	TH-232	0.000E+00
	TH-230	0.000E+00
	TH-229	0.000E+00
	TH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 42 OF 215

-- NESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:20:42 Page: 14 --
Title : 220 m² room
Input File : C:\Program Files\NESRAD_Family\BUILD\site3.bld
Evaluation Time: 0.00000000E+00 years

NESRAD-BUILDDose Tables

Source Contributions to Receptor Doses

[rem]

Receptor	Source 1	Source 2	Source 3	Source 4	Source 5	Total
1	1.22E+01	1.33E+00	1.33E+00	1.33E+00	1.33E+00	1.75E+01
Total	1.22E+01	1.33E+00	1.33E+00	1.33E+00	1.33E+00	1.75E+01

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 43 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:20:42 Page: 15 **
 Title : 220 m² room
 Input File : C:\Program Files\RESRAD_Family\BUILD\sites3.bld
 Evaluation Time: 0.0000000E+00 years

Pathway Detail of Doses

[mrem]

Source: 1

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	1.07E+01	3.03E-02	2.07E-05	1.90E-01	3.45E-24	1.30E+00
Total	1.07E+01	3.03E-02	2.07E-05	1.90E-01	3.45E-24	1.30E+00

Source: 2

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	8.71E-01	9.10E-03	6.20E-06	5.69E-02	1.04E-24	3.91E-01
Total	8.71E-01	9.10E-03	6.20E-06	5.69E-02	1.04E-24	3.91E-01

Source: 3

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	8.71E-01	9.10E-03	6.20E-06	5.69E-02	1.04E-24	3.91E-01
Total	8.71E-01	9.10E-03	6.20E-06	5.69E-02	1.04E-24	3.91E-01

Source: 4

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	8.71E-01	9.10E-03	6.20E-06	5.69E-02	1.04E-24	3.91E-01
Total	8.71E-01	9.10E-03	6.20E-06	5.69E-02	1.04E-24	3.91E-01

Source: 5

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	8.71E-01	9.10E-03	6.20E-06	5.69E-02	1.04E-24	3.91E-01
Total	8.71E-01	9.10E-03	6.20E-06	5.69E-02	1.04E-24	3.91E-01

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 44 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:20:42 Page: 16 **
Title : 220 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site3.bld
Evaluation Time: 0.0000000E+00 years

Nuclide Detail of Doses

[unrem]

Source: 1

Nuclide	Receptor	Total
	1	
PU-241		
PU-241	1.00E-01	1.00E-01
AM-241	5.31E-03	5.31E-03
NP-237	7.31E-10	7.31E-10
U-233	1.08E-16	1.08E-16
IH-229	3.22E-20	3.22E-20
AM-241		
AM-241	1.33E-01	1.33E-01
NP-237	2.75E-06	2.75E-06
U-233	5.40E-15	5.40E-15
IH-229	2.01E-18	2.01E-18
PU-240		
PU-240	4.63E-02	4.63E-02
U-236	1.12E-10	1.12E-10
IH-232	2.24E-20	2.24E-20
IH-228	1.23E-23	1.23E-23
RA-228	1.20E-22	1.20E-22
PU-239		
PU-239	4.64E-02	4.64E-02
U-235	4.34E-12	4.34E-12
PA-231	4.81E-16	4.81E-16
AC-227	9.03E-18	9.03E-18
PU-238		
PU-238	1.23E-01	1.23E-01
U-234	3.53E-08	3.53E-08
IH-230	2.45E-18	2.45E-18
RA-226	3.41E-17	3.41E-17
PB-210	3.34E-19	3.34E-19
CS-137		
CS-137	1.05E+01	1.05E+01
CS-134		
CS-134	9.29E-03	9.29E-03
SR-90		
SR-90	2.57E-01	2.57E-01
CO-60		
CO-60	9.60E-01	9.60E-01

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 45 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:20:42 Page: 17 --
Title : 220 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site3.bld
Evaluation Time: 0.00000000E+00 years

Source: 2

Nuclide	Receptor	Total
1		
PU-241		
PU-241	3.01E-02	3.01E-02
AM-241	1.58E-03	1.58E-03
NP-237	2.14E-10	2.14E-10
U-233	3.24E-17	3.24E-17
TH-229	9.51E-21	9.51E-21
AM-241		
AM-241	3.98E-02	3.98E-02
NP-237	6.05E-09	6.05E-09
U-233	1.62E-15	1.62E-15
TH-229	5.93E-19	5.93E-19
PU-240		
PU-240	1.39E-02	1.39E-02
U-236	3.35E-11	3.35E-11
TH-232	6.73E-21	6.73E-21
TH-228	2.54E-24	2.54E-24
RA-228	2.44E-23	2.44E-23
PU-239		
PU-239	1.39E-02	1.39E-02
U-235	1.15E-12	1.15E-12
PA-231	1.44E-16	1.44E-16
AC-227	2.69E-18	2.69E-18
PU-238		
PU-238	3.67E-02	3.67E-02
U-234	1.06E-08	1.06E-08
TH-230	7.35E-14	7.35E-14
RA-226	6.17E-18	6.17E-18
PB-210	1.00E-19	1.00E-19
CS-137		
CS-137	1.04E+00	1.04E+00
CS-134		
CS-134	8.35E-04	8.35E-04
SR-90		
SR-90	7.49E-02	7.49E-02
CO-60		
CO-60	8.05E-02	8.05E-02

Source: 3

Nuclide	Receptor	Total
1		
PU-241		
PU-241	3.01E-02	3.01E-02

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 46 OF 215

** RESPAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:20:42 Page: 18 **
 Title : 220 m2 room
 Input File : C:\Program Files\RESPAD_Family\BUILD\site3.bld
 Evaluation Time: 0.0000000E+00 years

AM-241	1.58E-03	1.58E-03
NP-237	2.14E-10	2.14E-10
U-233	3.24E-17	3.24E-17
TH-229	9.51E-21	9.51E-21
AM-241		
AM-241	3.98E-02	3.98E-02
NP-237	8.05E-09	8.05E-09
U-233	1.62E-15	1.62E-15
TH-229	5.93E-19	5.93E-19
PU-240		
PU-240	1.39E-02	1.39E-02
U-236	3.35E-11	3.35E-11
TH-232	6.73E-21	6.73E-21
TH-228	2.54E-24	2.54E-24
RA-228	2.44E-23	2.44E-23
PU-239		
PU-239	1.39E-02	1.39E-02
U-235	1.15E-12	1.15E-12
PA-231	1.44E-16	1.44E-16
AC-227	2.69E-18	2.69E-18
PU-238		
PU-238	3.67E-02	3.67E-02
U-234	1.06E-08	1.06E-08
TH-230	7.35E-14	7.35E-14
RA-226	6.17E-18	6.17E-18
PB-210	1.00E-19	1.00E-19
CS-137		
CS-137	1.04E+00	1.04E+00
CS-134		
CS-134	8.35E-04	8.35E-04
SR-90		
SR-90	7.49E-02	7.49E-02
CO-60		
CO-60	8.05E-02	8.05E-02

Source: 4

Nuclide Receptor	Total
1	
PU-241	
PU-241	3.01E-02
AM-241	1.58E-03
NP-237	2.14E-10
U-233	3.24E-17
TH-229	9.51E-21
AM-241	
AM-241	3.98E-02
NP-237	8.05E-09
U-233	1.62E-15
TH-229	5.93E-19

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 47 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:20:42 Page: 19 --

Title : 220 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site3.bld

Evaluation Time: 0.00000000E+00 years

PU-240

PU-240	1.39E-02	1.39E-02
---------------	-----------------	-----------------

U-236	3.35E-11	3.35E-11
--------------	-----------------	-----------------

TH-232	6.73E-21	6.73E-21
---------------	-----------------	-----------------

TH-228	2.54E-24	2.54E-24
---------------	-----------------	-----------------

RA-228	2.44E-23	2.44E-23
---------------	-----------------	-----------------

PU-239

PU-239	1.39E-02	1.39E-02
---------------	-----------------	-----------------

U-235	1.15E-12	1.15E-12
--------------	-----------------	-----------------

RA-231	1.44E-16	1.44E-16
---------------	-----------------	-----------------

AC-227	2.69E-18	2.69E-18
---------------	-----------------	-----------------

PU-238

PU-238	3.67E-02	3.67E-02
---------------	-----------------	-----------------

U-234	1.06E-08	1.06E-08
--------------	-----------------	-----------------

TH-230	7.35E-14	7.35E-14
---------------	-----------------	-----------------

RA-226	6.17E-18	6.17E-18
---------------	-----------------	-----------------

PB-210	1.00E-19	1.00E-19
---------------	-----------------	-----------------

CS-137

CS-137	1.04E+00	1.04E+00
---------------	-----------------	-----------------

CS-134

CS-134	8.35E-04	8.35E-04
---------------	-----------------	-----------------

SR-90

SR-90	7.49E-02	7.49E-02
--------------	-----------------	-----------------

CO-60

CO-60	8.05E-02	8.05E-02
--------------	-----------------	-----------------

Source: 5

Nuclide	Receptor	Total
	1	
PU-241		
PU-241	3.01E-02	3.01E-02
AM-241	1.58E-03	1.58E-03
NP-237	2.14E-10	2.14E-10
U-233	3.24E-17	3.24E-17
TH-229	9.51E-21	9.51E-21
AM-241		
AM-241	3.98E-02	3.98E-02
NP-237	8.05E-09	8.05E-09
U-233	1.62E-15	1.62E-15
TH-229	5.93E-19	5.93E-19
PU-240		
PU-240	1.39E-02	1.39E-02
U-236	3.35E-11	3.35E-11
TH-232	6.73E-21	6.73E-21
TH-228	2.54E-24	2.54E-24
RA-228	2.44E-23	2.44E-23
PU-239		
PU-239	1.39E-02	1.39E-02
U-235	1.15E-12	1.15E-12

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 48 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:20:42 Page: 20 --

Title : 220 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site3.bld

Evaluation Time: 0.00000000E+00 years

PA-231 1.44E-16 1.44E-16

AC-227 2.69E-18 2.69E-18

DU-238

PU-238 3.67E-02 3.67E-02

U-234 1.06E-08 1.06E-08

TH-230 7.35E-14 7.35E-14

RA-226 6.17E-18 6.17E-18

PB-210 1.00E-19 1.00E-19

CS-137

CS-137 1.04E+00 1.04E+00

CS-134

CS-134 8.35E-04 8.35E-04

Sr-90

Sr-90 7.49E-02 7.49E-02

Co-60

Co-60 8.05E-02 8.05E-02

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 49 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:20:42 Page: 21 **

Title : 220 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site3.bld

Full Summary

RESRAD-BUILD Dose (Time) Tables

Receptor Dose Received for the Exposure Duration

(mrem)

Evaluation Time [yr]

0.00E+00

1 1.75E+01

Receptor Dose/Yr Averaged Over Exposure Duration

(mrem/yr)

Evaluation Time [yr]

0.00E+00

1 1.75E+01

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 50 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:42:00 Page: 1 --
Title : 231 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site4.bld

RESRAD-BUILD Table of Contents

RESRAD-BUILD Input Parameters.....	2
Building Information.....	3
Source Information.....	4
For time = 0.00E+00 yr	
Time Specific Parameters.....	9
Receptor-Source Dose Summary.....	14
Dose by Pathway Detail.....	15
Dose by Nuclide Detail.....	16
Full Summary.....	21

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 51 OF 215

-- NESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:42:00 Page: 2 --
Title : 231 m² room
Input File : C:\Program Files\NESRAD_Family\BUILD\site4.bld

NESRAD-BUILD Input Parameters

Number of Sources : 5
Number of Receptors: 1
Total Time : 3.650000E+02 days.
Fraction Inside : 2.670000E-01

Receptor Information

Receptor	Room	x [m]	y [m]	z [m]	Fractime	Inhalation	Ingestion(Dust) [m ² /hr]
1	1	5.850	5.850	1.000	1.000	3.57E+01	1.61E-04

Receptor-Source Shielding Relationship

Receptor	Source	Density [g/cm ³]	Thickness [cm]	Material
1	1	2.40E+00	0.00E+00	Concrete
1	2	2.40E+00	0.00E+00	Concrete
1	3	2.40E+00	0.00E+00	Concrete
1	4	2.40E+00	0.00E+00	Concrete
1	5	2.40E+00	0.00E+00	Concrete

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 52 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:42:00 Page: 3 **
Title : 281 m2 room
Input File : C:\Program Files\RESRAD_Family\BUILD\site4.bld

Building Information

Building Air Exchange Rate: 8.35E-01 1/hr

Height [m]	Air Exchanges [m ³ /hr]	
Area [m ²]	*****	
	*	*
	*	*
	*	
	**	<=Q01: 2.29E+02
H1: 2.000	Room 1	* Q10 : 2.29E+02
	LAMBDA: 8.35E-01	*
Area 137.000	*	*
	*	*

Deposition velocity: 4.78E-04 [m/s] Resuspension Rate: 1.33E-09 [1/s]

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 53 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:42:00 Page: 4 **
 Title : 231 m² room
 Input File : C:\Program Files\RESRAD_Family\BUILD\site4.bld

Source Information**Source: 1**

Location:: Room : 1 x: 5.85 y: 5.85 z: 0.00[m]
 Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:1.17E+01 Direction: z
 Pathway ::
 Direct Ingestion Rate: 3.450E-07 [1/hr]
 Fraction released to air: 5.170E-01
 Removable fraction: 1.000E-01
 Time to Remove: 5.280E+04 [day]
 Radon Release Fraction: 0.000E+00

Contamination::**Nuclide Concentration****Dose Conversion Factor (Library: FGR 13 Morbidity)**

		Ingestion [mrem/dpm]	Inhalation [mrem/dpm]	Submersion [mrem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

**TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station**

PAGE 54 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:42:00 Page: 5 **

Title : 231 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site4.hld

Source: 2

Location:: Room : 1 x: 0.00 y: 5.85 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:2.00E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::

Nuclide Concentration

Dose Conversion Factor (Library: FGR 13 Morbidity

		Ingestion [mrem/dpm]	Inhalation [mrem/dpm]	Submersion [mrem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.021E-05	3.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	8.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PR-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 55 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:42:00 Page: 6 **
 Title : 231 m² room
 Input File : C:\Program Files\RESRAD_Family\BUILD\site4.bld

Source: 3

Location:: Room : 1 x: 5.85 y: 0.00 z: 0.00[m]

Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:2.00E+00 Direction: y

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::

Nuclide Concentration

Dose Conversion Factor (Library: FGR 13 Morbidity)

		Ingestion [mrem/dpm]	Inhalation [mrem/dpm]	Solubration [mrem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
HP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 56 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:42:00 Page: 7 **
 Title : 231 m² room
 Input File : C:\Program Files\RESRAD_Family\BUILD\site4.bld

Source: 4

Location:: Room : 1 x: 11.70 y: 5.85 z: 0.00[m]

Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:2.00E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::**Nuclide Concentration****Dose Conversion Factor (Library: FGR 13 Morbidity)**

	[dpm/m ²]	Ingestion [mrem/dpm]	Inhalation [mrem/dpm]	Submersion [mrem/yr/ (dpm/m ³)]
EU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	5.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PB-210	0.000E+00	2.422E-03	6.214E-03	4.658E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	5.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 57 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:42:00 Page: 5 **
 Title : 231 m² room
 Input File : C:\Program Files\RESRAD_Family\BUILD\site4.bld

Source: 5

Location:: Room : 1 x: 5.85 y: 11.70 z: 0.00[m]
 Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:2.00E+00 Direction: y
 Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]
 Fraction released to air: 5.170E-01
 Removable fraction: 1.000E-01
 Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::**Nuclide Concentration****Dose Conversion Factor (Library: FGR 13 Morbidity)**

	[dpm/m ²]	Ingestion [mrem/dpm]	Inhalation [mrem/dpm]	Submersion [mrem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.281E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
ND-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.045E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
RS-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.563E-03
SP-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CD-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 58 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:42:00 Page: 9 **
Title : 231 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site4.bld
Evaluation Time: 0.0000000E+00 years

Assessment for Time: 1
Time =0.00E+00 yr

Source Information

Source: 1

Location:: Room : 1 x: 5.85 y: 5.85 z: 0.00 [m]
Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:1.17E+01 Direction: z
Pathway ::
 Direct Ingestion Rate: 3.450E-07 [1/hr]
 Fraction released to air: 5.170E-01
 Removable fraction: 1.000E-01
 Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	IH-232	0.000E+00
	IH-230	0.000E+00
	IH-229	0.000E+00
	IH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 59 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:42:00 Page: 10 **

Title : 231 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site4.bld

Evaluation Time: 0.00000000E+00 years

Source: 2

Location:: Room : 1 x: 0.00 y: 5.25 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:2.00E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	TH-232	0.000E+00
	TH-230	0.000E+00
	TH-229	0.000E+00
	TH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	Sr-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 60 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:42:00 Page: 11 --

Title : 231 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site4.bld

Evaluation Time: 0.00000000E+00 years

Source: 3

Location:: Room : 1 x: 5.85 y: 0.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:2.00E+00 Direction: y

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	TH-232	0.000E+00
	TH-230	0.000E+00
	TH-229	0.000E+00
	TH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	RB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 61 OF 215

** ESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:42:00 Page: 12 **

Title : 231 m² room

Input File : C:\Program Files\ESRAD_Family\BUILD\site4.bld

Evaluation Time: 0.0000000E+00 years

Source: 4

Location:: Room : 1 x: 11.70 y: 5.85 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:2.00E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	IH-232	0.000E+00
	IH-230	0.000E+00
	IH-229	0.000E+00
	IH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 62 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:42:00 Page: 13 --

Title : 231 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site4.bld

Evaluation Time: 0.0000000E+00 years

Source: 5

Location:: Room : 1 x: 5.85 y: 11.70 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:2.00E+00 Direction: y

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	ND-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	IH-232	0.000E+00
	IH-230	0.000E+00
	IH-229	0.000E+00
	IH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 63 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:42:00 Page: 14 **

Title : 231 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site4.bld

Evaluation Time: 0.00000000E+00 years

RESRAD-BUILD Dose Tables

Source Contributions to Receptor Doses

[mrem]

	Source	Source	Source	Source	Source	Total
	1	2	3	4	5	
Receptor 1	1.37E+01	8.73E-01	8.73E-01	8.73E-01	8.73E-01	1.72E+01
Total	1.37E+01	8.73E-01	8.73E-01	8.73E-01	8.73E-01	1.72E+01

**TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station**

PAGE 64 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:42:00 Page: 15 **
 Title : 231 m² room
 Input File : C:\Program Files\RESRAD_Family\BUILD\site4.bld
 Evaluation Time: 0.00000000E+00 years

Pathway Detail of Doses**[removal]****Source: 1**

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	1.16E+01	4.50E-02	2.80E-05	2.71E-01	4.66E-24	1.79E+00
Total	1.16E+01	4.50E-02	2.80E-05	2.71E-01	4.66E-24	1.79E+00

Source: 2

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	5.13E-01	7.70E-03	4.79E-06	4.64E-02	7.97E-25	3.06E-01
Total	5.13E-01	7.70E-03	4.79E-06	4.64E-02	7.97E-25	3.06E-01

Source: 3

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	5.13E-01	7.70E-03	4.79E-06	4.64E-02	7.97E-25	3.06E-01
Total	5.13E-01	7.70E-03	4.79E-06	4.64E-02	7.97E-25	3.06E-01

Source: 4

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	5.13E-01	7.70E-03	4.79E-06	4.64E-02	7.97E-25	3.06E-01
Total	5.13E-01	7.70E-03	4.79E-06	4.64E-02	7.97E-25	3.06E-01

Source: 5

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	5.13E-01	7.70E-03	4.79E-06	4.64E-02	7.97E-25	3.06E-01
Total	5.13E-01	7.70E-03	4.79E-06	4.64E-02	7.97E-25	3.06E-01

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 65 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:42:00 Page: 16 **
Title : 231 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site4.bld
Evaluation Time: 0.00000000E+00 years

Nuclide Detail of Doses**[mrem]**

Source: 1

Nuclide Receptor	Total
1	
PU-241	
PU-241	1.35E-01
AM-241	7.56E-03
NP-237	1.04E-09
U-233	1.59E-16
TH-229	4.71E-20
AM-241	
AM-241	1.90E-01
NP-237	3.52E-08
U-233	7.93E-15
TH-229	2.94E-18
PU-240	
PU-240	6.66E-02
U-236	1.64E-10
TH-232	3.31E-20
TH-228	1.49E-23
RA-228	1.49E-22
PU-239	
PU-239	6.67E-02
U-235	6.12E-12
PA-231	6.91E-16
AC-227	1.22E-17
PU-238	
PU-238	1.71E-01
U-234	5.18E-08
TH-230	3.62E-13
RA-226	4.20E-17
PB-210	4.57E-19
CS-137	
CS-137	1.17E+01
CS-134	
CS-134	1.02E-02
SR-90	
SR-90	3.49E-01
CO-60	
CO-60	1.05E+00

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 66 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:42:00 Page: 17 **
 Title : 231 m² room
 Input File : C:\Program Files\RESRAD_Family\BUILD\site4.bld
 Evaluation Time: 0.0000000E+00 years

Source: 2

Nuclide	Receptor	Total
	1	
PU-241		
PU-241	2.32E-02	2.32E-02
AM-241	1.29E-03	1.29E-03
NP-237	1.75E-10	1.75E-10
U-233	2.71E-17	2.71E-17
IH-229	7.96E-21	7.96E-21
AM-241		
AM-241	3.24E-02	3.24E-02
NP-237	6.58E-09	6.58E-09
U-233	1.35E-15	1.35E-15
IH-229	4.96E-19	4.96E-19
PU-240		
PU-240	1.14E-02	1.14E-02
U-236	2.80E-11	2.80E-11
IH-232	5.66E-21	5.66E-21
IH-228	1.81E-24	1.81E-24
RA-228	1.82E-23	1.82E-23
PU-239		
PU-239	1.14E-02	1.14E-02
U-235	9.52E-13	9.52E-13
PA-231	1.18E-16	1.18E-16
AC-227	2.07E-18	2.07E-18
PU-238		
PU-238	2.93E-02	2.93E-02
U-234	8.85E-09	8.85E-09
IH-230	6.18E-14	6.18E-14
RA-226	4.60E-18	4.60E-18
PB-210	7.80E-20	7.80E-20
CS-137		
CS-137	6.57E-01	6.57E-01
CS-134		
CS-134	5.12E-04	5.12E-04
SR-90		
SR-90	5.82E-02	5.82E-02
CO-60		
CO-60	4.80E-02	4.80E-02

Source: 3

Nuclide	Receptor	Total
	1	
PU-241		
PU-241	2.32E-02	2.32E-02

**TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station**

PAGE 67 OF 215

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 68 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:42:00 Page: 18
Title : 231 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site4.bld
Evaluation Time: 0.0000000E+00 years

AM-241	1.29E-03	1.29E-03
NP-237	1.75E-10	1.75E-10
U-233	2.71E-17	2.71E-17
IH-229	7.96E-21	7.96E-21
AM-241		
AM-241	3.24E-02	3.24E-02
NP-237	6.58E-09	6.58E-09
U-233	1.35E-15	1.35E-15
IH-229	4.96E-19	4.96E-19
PU-240		
PU-240	1.14E-02	1.14E-02
U-236	2.80E-11	2.80E-11
IH-232	5.66E-21	5.66E-21
IH-228	1.81E-24	1.81E-24
RA-228	1.82E-23	1.82E-23
PU-239		
PU-239	1.14E-02	1.14E-02
U-235	9.52E-13	9.52E-13
PA-231	1.18E-16	1.18E-16
AC-227	2.07E-18	2.07E-18
PU-238		
PU-238	2.93E-02	2.93E-02
U-234	8.85E-09	8.85E-09
IH-230	6.18E-14	6.18E-14
RA-226	4.60E-18	4.60E-18
PR-210	7.80E-20	7.80E-20
CS-137		
CS-137	6.57E-01	6.57E-01
CS-134		
CS-134	5.12E-04	5.12E-04
SR-90		
SR-90	5.82E-02	5.82E-02
CO-60		
CO-60	4.80E-02	4.80E-02

Source: 4

Nuclide Receptor	Total
1	
PU-241	
PU-241	2.32E-02
AM-241	1.29E-03
NP-237	1.75E-10
U-233	2.71E-17
IH-229	7.96E-21
AM-241	
AM-241	3.24E-02
NP-237	6.58E-09
U-233	1.35E-15
IH-229	4.96E-19

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 69 OF 215

**** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:42:00 Page: 19 ****

Title : 231 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site4.bld

Evaluation Time: 0.00000000E+00 years

PU-240

PU-240	1.14E-02	1.14E-02
U-236	2.80E-11	2.80E-11
TH-232	5.66E-21	5.66E-21
TH-228	1.81E-24	1.81E-24
RA-228	1.82E-23	1.82E-23

PU-239

PU-239	1.14E-02	1.14E-02
U-235	9.52E-13	9.52E-13
PA-231	1.18E-16	1.18E-16
AC-227	2.07E-18	2.07E-18

PU-238

PU-238	2.93E-02	2.93E-02
U-234	8.85E-09	8.85E-09
TH-230	6.18E-14	6.18E-14
RA-226	4.60E-18	4.60E-18
PB-210	7.80E-20	7.80E-20

CS-137

CS-137	6.57E-01	6.57E-01
---------------	-----------------	-----------------

CS-134

CS-134	5.12E-04	5.12E-04
---------------	-----------------	-----------------

SR-90

SR-90	5.82E-02	5.82E-02
--------------	-----------------	-----------------

CO-60

CO-60	4.80E-02	4.80E-02
--------------	-----------------	-----------------

Source: 5

Nuclide	Receptor	Total
	1	
PU-241		
PU-241	2.32E-02	2.32E-02
AM-241	1.29E-03	1.29E-03
NP-237	1.75E-10	1.75E-10
U-233	2.71E-17	2.71E-17
TH-229	7.96E-21	7.96E-21
AM-241		
AM-241	3.24E-02	3.24E-02
NP-237	6.58E-09	6.58E-09
U-233	1.35E-15	1.35E-15
TH-229	4.96E-19	4.96E-19
PU-240		
PU-240	1.14E-02	1.14E-02
U-236	2.80E-11	2.80E-11
TH-232	5.66E-21	5.66E-21
TH-228	1.81E-24	1.81E-24
RA-228	1.82E-23	1.82E-23
PU-239		
PU-239	1.14E-02	1.14E-02
U-235	9.52E-13	9.52E-13

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 70 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:42:00 Page: 20 --

Title : 231 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site4.bld

Evaluation Time: 0.00000000E+00 years

PA-231	1.18E-16	1.18E-16
AC-227	2.07E-18	2.07E-18
PU-238		
PU-238	2.93E-02	2.93E-02
U-234	8.85E-09	8.85E-09
TH-230	6.18E-14	6.18E-14
RA-226	4.60E-18	4.60E-18
PB-210	7.80E-20	7.80E-20
CS-137		
CS-137	6.57E-01	6.57E-01
CS-134		
CS-134	5.12E-04	5.12E-04
SR-90		
SR-90	5.82E-02	5.82E-02
CO-60		
CO-60	4.80E-02	4.80E-02

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 71 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 13:42:00 Page: 21 **

Title : 231 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site4.bld

Full Summary

RESRAD-BUILD Dose (Time) Tables

Receptor Dose Received for the Exposure Duration

(mrem)

Evaluation Time [yr]

0.00E+00

1 1.72E+01

Receptor Dose/Yr Averaged Over Exposure Duration

(mrem/yr)

Evaluation Time [yr]

0.00E+00

1 1.72E+01

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 72 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:01:54 Page: 1 --
Title : 256 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site5.bld

RESRAD-BUILD Table of Contents

RESRAD-BUILD Input Parameters.....	2
Building Information.....	3
Source Information.....	4
For time = 0.00E+00 yr	
Time Specific Parameters.....	9
Receptor-Source Dose Summary.....	14
Dose by Pathway Detail.....	15
Dose by Nuclide Detail.....	16
Full Summary.....	21

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 73 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:01:54 Page: 2 **
Title : 256 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site5.bld

RESRAD-BUILD Input Parameters

Number of Sources : 5
Number of Receptors: 1
Total Time : 3.650000E+02 days
Fraction Inside : 2.670000E-01

Receptor Information

Receptor	Room	x [m]	y [m]	z [m]	FracTime	Inhalation	Ingestion(Dust) [m ³ /day]	[m ² /hr]
1	1	5.000	5.000	1.000	1.000	3.57E+01	1.61E-04	

Receptor-Source Shielding Relationship

Receptor	Source	Density [g/cm ³]	Thickness [cm]	Material
1	1	2.40E+00	0.00E+00	Concrete
1	2	2.40E+00	0.00E+00	Concrete
1	3	2.40E+00	0.00E+00	Concrete
1	4	2.40E+00	0.00E+00	Concrete
1	5	2.40E+00	0.00E+00	Concrete

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 74 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:01:54 Page: 3 --
Title : 256 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site5.bld

Building Information

Building Air Exchange Rate: 8.35E-01 1/hr

Height [m]	Air Exchanges [m ³ /hr]	

*	*	*
*	*	*
*		<=001: 3.25E+02
H1: 3.890	Room 1	O10 : 3.25E+02
	LAMBDA: 8.35E-01	*
Area 100.000	*	*
	*	*

Deposition velocity: 4.78E-04 [m/s] Resuspension Rate: 1.33E-09 [1/s]

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 75 OF 215

** NESTRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:01:54 Page: 4 **
 Title : 256 m² room
 Input File : C:\Program Files\NESTRAD_Family\BUILD\site5.bld

Source Information

Source: 1
 Location:: Room : 1 x: 5.00 y: 5.00 z: 0.00[m]
 Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:1.00E+01 Direction: z
 Pathway ::
 Direct Ingestion Rate: 3.450E-07 [1/hr]
 Fraction released to air: 5.170E-01
 Removable fraction: 1.000E-01
 Time to Remove: 5.280E+04 [day]
 Radon Release Fraction: 0.000E+00

Contamination::**Nuclide Concentration****Dose Conversion Factor (Library: FGR 13 Morbidity)**

	[dpm/m ²]	Ingestion [rem/dpm]	Inhalation [rem/dpm]	Submersion [rem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 76 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:01:54 Page: 5 --

Title : 256 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site5.bld

Source: 2

Location:: Room : 1 x: 0.00 y: 5.00 z: 0.00[m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.89E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::

Nuclide Concentration Dose Conversion Factor (Library: FGR 13 Morbidity

	[dpm/m ²]	Ingestion [mrem/dpm]	Inhalation [mrem/dpm]	Submersion [mrem/yr/(dpm/m ³)]
PU-241	2.420E+05	8.081E-05	8.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.676E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 77 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:01:54 Page: 6 **
 Title : 256 m² room
 Input File : C:\Program Files\RESRAD_Family\BUILD\site5.bld

Source: 3

Location:: Room : 1 x: 5.00 y: 0.00 z: 0.00[m]
 Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.89E+00 Direction: y
 Pathway ::
 Direct Ingestion Rate: 3.450E-07 [1/hr]
 Fraction released to air: 5.170E-01
 Removable fraction: 1.000E-01
 Time to Remove: 5.280E+04 [day]
 Radon Release Fraction: 0.000E+00

Contamination::**Nuclide Concentration****Dose Conversion Factor (Library: FCR 13 Morbidity)**

		Ingestion [rem/dpm]	Inhalation [rem/dpm]	Submersion [rem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.802E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 78 OF 215

** KISRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:01:54 Page: 7 **
Title : 256 m² room
Input File : C:\Program Files\KISRAD_Family\BUILD\site5.bld

Source: 4

Location:: Room : 1 x: 10.00 y: 5.00 z: 0.00[m]
Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.89E+00 Direction: x
Pathway ::
 Direct Ingestion Rate: 3.450E-07 [1/hr]
 Fraction released to air: 5.170E-01
 Removable fraction: 1.000E-01
 Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::**Nuclide Concentration Dose Conversion Factor (Library: FGR 13 Morbidity)**

		Ingestion [rem/dpm]	Inhalation [rem/dpm]	Submersion [rem/yr/ (dpm/m ³)]
FU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
FU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
FU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
FU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

**TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station**

PAGE 79 OF 215

** RESPAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:01:54 Page: 8 **
 Title : 256 m² room
 Input File : C:\Program Files\RESPAD_Family\BUILD\site5.bld

Source: 5

Location:: Room : 1 x: 5.00 y: 10.00 z: 0.00[m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.89E+00 Direction: y

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::

Nuclide Concentration

Dose Conversion Factor (Library: FCR 13 Morbidity)

		Ingestion [dpm/m ²]	Inhalation [mrem/dpm]	Submersion [mrem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-02
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
IH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
IH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
IH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
IH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RB-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
FS-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 80 OF 215

-- NERAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:01:54 Page: 9 --
Title : 256 m² room
Input File : C:\Program Files\NERAD_Family\BUILD\site5.bld
Evaluation Time: 0.0000000E+00 years

Assessment for Time: 1
Time =0.00E+00 yr

Source Information

Source: 1

Location:: Room : 1 x: 5.00 y: 5.00 z: 0.00 [m]
Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:1.00E+01 Direction: z
Pathway ::
Direct Ingestion Rate: 3.450E-07 [1/hr]
Fraction released to air: 5.170E-01
Removable fraction: 1.000E-01
Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	EU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	TH-232	0.000E+00
	TH-230	0.000E+00
	TH-229	0.000E+00
	TH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PR-210	0.000E+00
	CS-137	3.620E+06
	CS-134	1.500E+03
	Sr-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 81 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:01:54 Page: 10 --

Title : 256 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site5.bld

Evaluation Time: 0.0000000E+00 years

Source: 2

Location:: Room : 1 x: 0.00 y: 5.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.89E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	EU-240	1.700E+03
	EU-239	1.700E+03
	EU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	TH-232	0.000E+00
	TH-230	0.000E+00
	TH-229	0.000E+00
	TH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 82 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:01:54 Page: 11 --

Title : 256 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site5.bld

Evaluation Time: 0.0000000E+00 years

Source: 3

Location:: Room : 1 x: 5.00 y: 0.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.89E+00 Direction: y

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	TH-232	0.000E+00
	TH-230	0.000E+00
	TH-229	0.000E+00
	TH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 83 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.8 02/21/06 14:01:54 Page: 12 **

Title : 256 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site5.hld

Evaluation Time: 0.00000000E+00 years

Source: 4

Location:: Room : 1 x: 10.00 y: 5.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.89E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	IH-232	0.000E+00
	IH-230	0.000E+00
	IH-229	0.000E+00
	IH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PR-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 84 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:01:54 Page: 13 --

Title : 256 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site5.bld

Evaluation Time: 0.0000000E+00 years

Source: 5

Location:: Room : 1 x: 5.00 y: 10.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.89E+00 Direction: y

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hz]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	IH-232	0.000E+00
	IH-230	0.000E+00
	IH-229	0.000E+00
	IH-228	0.000E+00
	ZC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 85 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:01:54 Page: 14 --

Title : 256 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site5.bld

Evaluation Time: 0.00000000E+00 years

RESRAD-BUILD Dose Tables

Source Contributions to Receptor Doses

[rem]

	Source 1	Source 2	Source 3	Source 4	Source 5	Total
Receptor 1	1.21E+01	1.68E+00	1.68E+00	1.68E+00	1.68E+00	1.88E+01
Total	1.21E+01	1.68E+00	1.68E+00	1.68E+00	1.68E+00	1.88E+01

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 86 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:01:54 Page: 15 --
Title : 256 m2 room
Input File : C:\Program Files\RESRAD_Family\BUILD\site5.bld
Evaluation Time: 0.00000000E+00 years

Pathway Detail of Doses

[mrem]

Source: 1

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	1.07E+01	2.45E-02	1.67E-05	1.50E-01	2.80E-24	1.27E+00
Total	1.07E+01	2.45E-02	1.67E-05	1.50E-01	2.80E-24	1.27E+00

Source: 2

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	1.12E+00	9.54E-03	6.51E-06	5.82E-02	1.09E-24	4.94E-01
Total	1.12E+00	9.54E-03	6.51E-06	5.82E-02	1.09E-24	4.94E-01

Source: 3

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	1.12E+00	9.54E-03	6.51E-06	5.82E-02	1.09E-24	4.94E-01
Total	1.12E+00	9.54E-03	6.51E-06	5.82E-02	1.09E-24	4.94E-01

Source: 4

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	1.12E+00	9.54E-03	6.51E-06	5.82E-02	1.09E-24	4.94E-01
Total	1.12E+00	9.54E-03	6.51E-06	5.82E-02	1.09E-24	4.94E-01

Source: 5

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	1.12E+00	9.54E-03	6.51E-06	5.82E-02	1.09E-24	4.94E-01
Total	1.12E+00	9.54E-03	6.51E-06	5.82E-02	1.09E-24	4.94E-01

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 87 OF 215

** RESPAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:01:54 Page: 16 **
 Title : 256 m² room
 Input File : C:\Program Files\RESPAD_Family\BUILD\site5.bld
 Evaluation Time: 0.00000000E+00 years

Nuclide Detail of Doses

[mrem]

Source: 1

Nuclide	Receptor	Total
	1	
PU-241		
PU-241	9.29E-02	9.29E-02
AM-241	4.69E-03	4.69E-03
NP-237	6.45E-10	6.45E-10
U-233	8.87E-17	8.87E-17
TH-229	2.64E-20	2.64E-20
AM-241		
AM-241	1.18E-01	1.18E-01
NP-237	2.42E-08	2.42E-08
U-233	4.43E-15	4.43E-15
TH-229	1.65E-18	1.65E-18
PU-240		
PU-240	4.07E-02	4.07E-02
U-236	9.18E-11	9.18E-11
TH-232	1.82E-20	1.82E-20
TH-228	1.16E-23	1.16E-23
RA-228	1.19E-22	1.19E-22
PU-239		
PU-239	4.08E-02	4.08E-02
U-235	3.68E-12	3.68E-12
PA-231	4.23E-16	4.23E-16
AC-227	7.82E-18	7.82E-18
PU-238		
PU-238	1.10E-01	1.10E-01
U-234	2.50E-08	2.50E-08
TH-230	1.99E-13	1.99E-13
RA-226	3.33E-17	3.33E-17
PB-210	3.27E-19	3.27E-19
CS-137		
CS-137	1.05E+01	1.05E+01
CS-134		
CS-134	9.29E-03	9.29E-03
SR-90		
SR-90	2.49E-01	2.49E-01
CO-60		
CO-60	9.59E-01	9.59E-01

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 88 OF 215

** RESEAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:01:54 Page: 17 **
 Title : 256 m2 room
 Input File : C:\Program Files\RESEAD_Family\BUILD\site5.bld
 Evaluation Time: 0.0000000E+00 years

Source: 2

Nuclide	Receptor	Total
	1	
PU-241		
PU-241	3.62E-02	3.62E-02
AM-241	1.81E-03	1.81E-03
NP-237	2.45E-10	2.45E-10
U-233	3.45E-17	3.45E-17
TH-229	1.01E-20	1.01E-20
AM-241		
AM-241	4.56E-02	4.56E-02
NP-237	9.19E-09	9.19E-09
U-233	1.72E-15	1.72E-15
TH-229	6.28E-19	6.28E-19
PU-240		
PU-240	1.58E-02	1.58E-02
U-236	3.56E-11	3.56E-11
TH-232	7.09E-21	7.09E-21
TH-228	3.01E-24	3.01E-24
RA-228	3.14E-23	3.14E-23
PU-239		
PU-239	1.59E-02	1.59E-02
U-235	1.24E-12	1.24E-12
PA-231	1.64E-16	1.64E-16
AC-227	3.02E-18	3.02E-18
PU-238		
PU-238	4.27E-02	4.27E-02
U-234	1.12E-08	1.12E-08
TH-230	7.75E-14	7.75E-14
RA-226	7.64E-18	7.64E-18
PB-210	1.27E-19	1.27E-19
CS-137		
CS-137	1.32E+00	1.32E+00
CS-134		
CS-134	1.07E-03	1.07E-03
SR-90		
SR-90	9.42E-02	9.42E-02
CO-60		
CO-60	1.03E-01	1.03E-01

Source: 3

Nuclide	Receptor	Total
	1	
PU-241		
PU-241	3.62E-02	3.62E-02

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 89 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:01:54 Page: 18 **

Title : 256 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site5.bld

Evaluation Time: 0.00000000E+00 years

AM-241	1.81E-03	1.81E-03
NP-237	2.45E-10	2.45E-10
U-233	3.45E-17	3.45E-17
IH-229	1.01E-20	1.01E-20
AM-241		
AM-241	4.56E-02	4.56E-02
NP-237	9.19E-09	9.19E-09
U-233	1.72E-15	1.72E-15
IH-229	6.28E-19	6.28E-19
PU-240		
PU-240	1.56E-02	1.56E-02
U-236	3.56E-11	3.56E-11
IH-232	7.09E-21	7.09E-21
IH-228	3.01E-24	3.01E-24
RA-228	3.14E-23	3.14E-23
PU-239		
PU-239	1.59E-02	1.59E-02
U-235	1.24E-12	1.24E-12
PA-231	1.64E-16	1.64E-16
AC-227	3.02E-18	3.02E-18
PU-238		
PU-238	4.27E-02	4.27E-02
U-234	1.12E-08	1.12E-08
IH-230	7.75E-14	7.75E-14
RA-226	7.64E-18	7.64E-18
PB-210	1.27E-19	1.27E-19
CS-137		
CS-137	1.32E+00	1.32E+00
CS-134		
CS-134	1.07E-03	1.07E-03
SR-90		
SR-90	9.42E-02	9.42E-02
CO-60		
CO-60	1.03E-01	1.03E-01

Source: 4

Nuclide Receptor	Total
	1
PU-241	
PU-241	3.62E-02
AM-241	1.81E-03
NP-237	2.45E-10
U-233	3.45E-17
IH-229	1.01E-20
AM-241	
AM-241	4.56E-02
NP-237	9.19E-09
U-233	1.72E-15
IH-229	6.28E-19

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 90 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:01:54 Page: 19 **
Title : 256 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site5.bld
Evaluation Time: 0.00000000E+00 years

PU-240		
PU-240	1.58E-02	1.58E-02
U-236	3.56E-11	3.56E-11
IH-232	7.09E-21	7.09E-21
IH-228	3.01E-24	3.01E-24
RA-228	3.14E-23	3.14E-23
PU-239		
PU-239	1.59E-02	1.59E-02
U-235	1.24E-12	1.24E-12
PA-231	1.64E-16	1.64E-16
AC-227	3.02E-18	3.02E-18
PU-238		
PU-238	4.27E-02	4.27E-02
U-234	1.12E-08	1.12E-08
IH-230	7.75E-14	7.75E-14
RA-226	7.64E-18	7.64E-18
PB-210	1.27E-19	1.27E-19
CS-137		
CS-137	1.32E+00	1.32E+00
CS-134		
CS-134	1.07E-03	1.07E-03
SR-90		
SR-90	9.42E-02	9.42E-02
CO-60		
CO-60	1.03E-01	1.03E-01

Source: 5

Nuclide	Receptor	Total
		1
PU-241		
PU-241	3.62E-02	3.62E-02
AM-241	1.81E-03	1.81E-03
NP-237	2.45E-10	2.45E-10
U-233	3.45E-17	3.45E-17
IH-229	1.01E-20	1.01E-20
AM-241		
AM-241	4.56E-02	4.56E-02
NP-237	9.19E-09	9.19E-09
U-233	1.72E-15	1.72E-15
IH-229	6.28E-19	6.28E-19
PU-240		
PU-240	1.58E-02	1.58E-02
U-236	3.56E-11	3.56E-11
IH-232	7.09E-21	7.09E-21
IH-228	3.01E-24	3.01E-24
RA-228	3.14E-23	3.14E-23
PU-239		
PU-239	1.59E-02	1.59E-02
U-235	1.24E-12	1.24E-12

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 91 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:01:54 Page: 20 **
Title : 256 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site5.bld
Evaluation Time: 0.0000000E+00 years

PA-231	1.64E-16	1.64E-16
AC-227	3.02E-18	3.02E-18
PU-238		
PU-238	4.27E-02	4.27E-02
U-234	1.12E-08	1.12E-08
TH-230	7.75E-14	7.75E-14
RA-226	7.64E-18	7.64E-18
PB-210	1.27E-19	1.27E-19
CS-137		
CS-137	1.32E+00	1.32E+00
CS-134		
CS-134	1.07E-03	1.07E-03
SR-90		
SR-90	9.42E-02	9.42E-02
CO-60		
CO-60	1.03E-01	1.03E-01

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 92 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:01:54 Page: 21 --

Title : 256 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site5.bld

Full Summary

RESRAD-BUILD Dose (Time) Tables

Receptor Dose Received for the Exposure Duration

(mrem)

Evaluation Time [yr]

0.00E+00

1 1.88E+01

Receptor Dose/Yr Averaged Over Exposure Duration

(mrem/yr)

Evaluation Time [yr]

0.00E+00

1 1.88E+01

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 93 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:22:09 Page: 1 **
Title : 281 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site6.bld

RESRAD-BUILD Table of Contents

RESRAD-BUILD Input Parameters.....	2
Building Information.....	3
Source Information.....	4
For time = 0.00E+00 yr	
Time Specific Parameters.....	9
Receptor-Source Dose Summary.....	14
Dose by Pathway Detail.....	15
Dose by Nuclide Detail.....	16
Full Summary.....	21

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 94 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:22:09 Page: 2 --
Title : 281 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site6.bld

RESRAD-BUILD Input Parameters

Number of Sources : 5
Number of Receptors: 1
Total Time : 3.650000E+02 days
Fraction Inside : 2.670000E-01

Receptor Information

Receptor	Room	x [m]	y [m]	z [m]	Fractime	Inhalation [m ³ /day]	Ingestion(Dust) [m ² /hr]
1	1	5.850	5.850	1.000	1.000	3.57E+01	1.61E-04

Receptor-Source Shielding Relationship

Receptor	Source	Density [g/cm ³]	Thickness [cm]	Material
1	1	2.40E+00	0.00E+00	Concrete
1	2	2.40E+00	0.00E+00	Concrete
1	3	2.40E+00	0.00E+00	Concrete
1	4	2.40E+00	0.00E+00	Concrete
1	5	2.40E+00	0.00E+00	Concrete

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 95 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:22:09 Page: 3 --
Title : 281 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site6.hld

Building Information

Building Air Exchange Rate: 8.35E-01 1/hr

Height [m]	Air Exchanges [m ³ /hr]	
Area [m ²]	*****	
	*	
	*	
	*	
	*	
H1: 3.000	Q01: 3.43E+02	
	Room 1	Q10 : 3.43E+02
	LAMBDA: 8.35E-01	
Area 137.000	*****	

Deposition velocity: 4.78E-04 [m/s] Resuspension Rate: 1.33E-09 [1/s]

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 96 OF 215

-- RIES2AD-BUILD Dose Program Output, Version 3.3 02/21/06 14:22:09 Page: 4 --
Title : 281 m² room
Input File : C:\Program Files\RIES2AD_Family\BUILD\site6.bld

Source Information

Source: 1

Location:: Room : 1 . x: 5.85 y: 5.85 z: 0.00[m]
Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:1.17E+01 Direction: z
Pathway ::
 Direct Ingestion Rate: 3.450E-07 [1/hr]
 Fraction released to air: 5.170E-01
 Removable fraction: 1.000E-01
 Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::**Nuclide Concentration****Dose Conversion Factor (Library: FGR 13 Morbidity)**

		Ingestion [dpm/m ²]	Inhalation [rem/dpm]	Submersion [rem/yr/ (dpm/m ³)]
U-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
Am-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
DU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.695E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
Pa-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
Th-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
Th-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
Th-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
Th-228	0.000E+00	8.642E-04	1.556E-01	4.222E-03
Ac-227	0.000E+00	6.665E-03	8.029E+00	9.734E-04
Ra-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
Ra-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
Pb-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.802E-05	2.081E-05	3.983E-03
Sr-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
Co-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 97 OF 215

** RESPAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:22:05 Page: 5 **
 Title : 281 m² room
 Input File : C:\Program Files\RESPAD_Family\BUILD\site6.bld

Source: 2

Location:: Room : 1 x: 0.00 y: 5.85 z: 0.00[m]
 Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:3.00E+00 Direction: x
 Pathway ::
 Direct Ingestion Rate: 3.450E-07 [1/hr]
 Fraction released to air: 5.170E-01
 Removable fraction: 1.000E-01
 Time to Remove: 5.280E+04 [day]
 Radon Release Fraction: 0.000E+00

Contamination::**Nuclide Concentration****Dose Conversion Factor (Library: FCR 13 Morbidity)**

		Ingestion [rem/dpm]	Inhalation [rem/dpm]	Submersion [rem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	8.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 98 OF 215

-- RESPAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:22:09 Page: 6 --
Title : 281 m² room
Input File : C:\Program Files\RESPAD_Family\BUILD\site6.bld

Source: 3

Location:: Room : 1 x: 5.85 y: 0.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:3.00E+00 Direction: y

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::**Nuclide Concentration****Dose Conversion Factor (Library: FGR 13 Morbidity)**

		Ingestion [rem/dpm]	Inhalation [rem/dpm]	Skin/Respiratory [rem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.031E-05	3.716E-03	1.151E-08
AM-241	4.600E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
ND-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	5.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
IH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
IH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
IH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
IH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
FB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.802E-05	2.081E-05	2.983E-03
SR-90	3.800E+05	6.883E-05	5.694E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 99 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:22:09 Page: 7 **
 Title : 281 m² room
 Input File : C:\Program Files\RESRAD_Family\BUILD\site6.bld

Source: 4

Location:: Room : 1 x: 11.70 y: 5.85 z: 0.00[m]

Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:3.00E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::**Nuclide Concentration****Dose Conversion Factor (Library: FGR 13 Morbidity)**

	[dpm/m ²]	Ingestion [mrem/dpm]	Inhalation [mrem/dpm]	Submersion [mrem/yr/ (dpm/m ³)]
DU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.804E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.459E-07
DU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
DU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
ND-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.276E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
DA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
IH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
IH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
IH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
IH-228	0.000E+00	2.642E-04	1.556E-01	4.224E-03
RC-227	0.000E+00	6.665E-03	8.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RZ-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.583E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 100 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:22:09 Page: 8 **
 Title : 281 m² room
 Input File : C:\Program Files\RESRAD_Family\BUILD\site6.bld

Source: 5

Location:: Room : 1 x: 5.85 y: 11.70 z: 0.00[m]
 Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:3.00E+00 Direction: y
 Pathway ::
 Direct Ingestion Rate: 3.450E-07 [1/hr]
 Fraction released to air: 5.170E-01
 Removable fraction: 1.000E-01
 Time to Remove: 5.280E+04 [day]
 Radon Release Fraction: 0.000E+00

Contamination::**Nuclide Concentration****Dose Conversion Factor (Library: FGR 13 Morbidity)**

	[dpm/m ²]	Ingestion [mrem/dpm]	Inhalation [mrem/dpm]	Submersion [mrem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-06
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	8.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.495E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	8.871E-03	4.663E-03
PB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.583E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 101 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:22:09 Page: 9 --
Title : 281 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site6.bld
Evaluation Time: 0.0000000E+00 years

Assessment for Time: 1
Time =0.00E+00 yr

Source Information

Source: 1

Location:: Room : 1 x: 5.85 y: 5.85 z: 0.00 [m]
Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:1.17E+01 Direction: z
Pathway ::
 Direct Ingestion Rate: 3.450E-07 [1/hr]
 Fraction released to air: 5.170E-01
 Removable fraction: 1.000E-01
 Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	TH-232	0.000E+00
	TH-230	0.000E+00
	TH-229	0.000E+00
	TH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 102 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:22:09 Page: 10 --

Title : 261 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site6.bld

Evaluation Time: 0.0000000E+00 years

Source: 2

Location:: Room : 1 x: 0.00 y: 5.85 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:3.00E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	TH-232	0.000E+00
	TH-230	0.000E+00
	TH-229	0.000E+00
	TH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	FS-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	Sr-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 103 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:22:09 Page: 11 --

Title : 281 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site6.bld

Evaluation Time: 0.0000000E+00 years

Source: 3

Location:: Room : 1 x: 5.85 y: 0.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:3.00E+00 Direction: y

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	TH-232	0.000E+00
	TH-230	0.000E+00
	TH-229	0.000E+00
	TH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	FR-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 104 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:22:09 Page: 12 **

Title : 281 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site6.bld

Evaluation Time: 0.0000000E+00 years

Source: 4

Location:: Room : 1 x: 11.70 y: 5.85 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:3.00E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	IH-232	0.000E+00
	IH-230	0.000E+00
	IH-229	0.000E+00
	IH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 105 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:22:09 Page: 13 **

Title : 281 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site6.hld

Evaluation Time: 0.0000000E+00 years

Source: 5

Location:: Room : 1 x: 5.85 y: 11.70 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:3.00E+00 Direction: y

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hx]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	IH-232	0.000E+00
	IH-230	0.000E+00
	IH-229	0.000E+00
	IH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PR-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.450E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 106 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:22:09 Page: 14 --

Title : 281 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site6.bld

Evaluation Time: 0.0000000E+00 years

RESRAD-BUILDDose Tables

Source Contributions to Receptor Doses

[mrem]

	Source 1	Source 2	Source 3	Source 4	Source 5	Total
Receptor 1	1.85E+01	1.25E+00	1.25E+00	1.25E+00	1.25E+00	1.86E+01
Total	1.85E+01	1.25E+00	1.25E+00	1.25E+00	1.25E+00	1.86E+01

**TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station**

PAGE 107 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:22:09 Page: 15 **
 Title : 281 m² room
 Input File : C:\Program Files\RESRAD_Family\BUILD\site6.bld
 Evaluation Time: 0.0000000E+00 years

Pathway Detail of Doses**[mrem]****Source: 1**

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	1.16E+01	3.30E-02	2.06E-05	1.89E-01	3.45E-24	1.72E+00
Total	1.16E+01	3.30E-02	2.06E-05	1.89E-01	3.45E-24	1.72E+00

Source: 2

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	7.54E-01	8.47E-03	5.29E-06	4.86E-02	8.84E-25	4.41E-01
Total	7.54E-01	8.47E-03	5.29E-06	4.86E-02	8.84E-25	4.41E-01

Source: 3

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	7.54E-01	8.47E-03	5.29E-06	4.86E-02	8.84E-25	4.41E-01
Total	7.54E-01	8.47E-03	5.29E-06	4.86E-02	8.84E-25	4.41E-01

Source: 4

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	7.54E-01	8.47E-03	5.29E-06	4.86E-02	8.84E-25	4.41E-01
Total	7.54E-01	8.47E-03	5.29E-06	4.86E-02	8.84E-25	4.41E-01

Source: 5

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	7.54E-01	8.47E-03	5.29E-06	4.86E-02	8.84E-25	4.41E-01
Total	7.54E-01	8.47E-03	5.29E-06	4.86E-02	8.84E-25	4.41E-01

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 108 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:22:09 Page: 16 **
Title : 281 m² room
Input File : C:\Program Files\RESRAD_Family\BUILD\site6.bld
Evaluation Time: 0.00000000E+00 years

Nuclide Detail of Doses

[nrem]

Source: 1

Nuclide	Receptor	Total
PU-241		1.
PU-241	1.22E-01	1.22E-01
AM-241	6.24E-03	6.24E-03
NP-237	8.56E-10	8.56E-10
U-233	1.17E-16	1.17E-16
IH-229	3.45E-20	3.45E-20
AM-241		
AM-241	1.57E-01	1.57E-01
NP-237	3.21E-08	3.21E-08
U-233	5.83E-15	5.83E-15
IH-229	2.15E-18	2.15E-18
PU-240		
PU-240	5.44E-02	5.44E-02
U-236	1.21E-10	1.21E-10
IH-232	2.39E-20	2.39E-20
TH-228	1.37E-23	1.37E-23
RA-228	1.48E-22	1.48E-22
PU-239		
PU-239	5.44E-02	5.44E-02
U-235	4.69E-12	4.69E-12
PA-231	5.64E-16	5.64E-16
AC-227	9.95E-18	9.95E-18
PU-238		
PU-238	1.45E-01	1.45E-01
U-234	3.81E-08	3.81E-08
IH-230	2.62E-13	2.62E-13
RA-226	4.01E-17	4.01E-17
FB-210	4.43E-19	4.43E-19
CS-137		
CS-137	1.16E+01	1.16E+01
CS-134		
CS-134	1.02E-02	1.02E-02
SR-90		
SR-90	3.34E-01	3.34E-01
CO-60		
CO-60	1.05E+00	1.05E+00

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 109 OF 215

** RESPAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:22:09 Page: 17 **
 Title : 281 m² room
 Input File : C:\Program Files\RESPAD_Family\BUILD\site6.bld
 Evaluation Time: 0.00000000E+00 years

Source: 2

Nuclide	Receptor	Total
	1	
PU-241		
PU-241	3.13E-02	3.13E-02
AM-241	1.59E-03	1.59E-03
NP-237	2.15E-10	2.15E-10
U-233	2.99E-17	2.99E-17
TH-229	8.71E-21	8.71E-21
AM-241		
AM-241	4.00E-02	4.00E-02
NP-237	8.06E-09	8.06E-09
U-233	1.49E-15	1.49E-15
TH-229	5.43E-19	5.43E-19
PU-240		
PU-240	1.39E-02	1.39E-02
U-236	3.09E-11	3.09E-11
TH-232	6.13E-21	6.13E-21
TH-228	2.40E-24	2.40E-24
RA-228	2.69E-23	2.69E-23
PU-239		
PU-239	1.39E-02	1.39E-02
U-235	1.06E-12	1.06E-12
PA-231	1.44E-16	1.44E-16
AC-227	2.53E-18	2.53E-18
PU-238		
PU-238	3.72E-02	3.72E-02
U-234	9.75E-09	9.75E-09
TH-230	6.70E-14	6.70E-14
RA-226	6.40E-18	6.40E-18
PB-210	1.13E-19	1.13E-19
CS-137		
CS-137	9.59E-01	9.59E-01
CS-134		
CS-134	7.54E-04	7.54E-04
SR-90		
SR-90	8.37E-02	8.37E-02
CO-60		
CO-60	7.05E-02	7.05E-02

Source: 3

Nuclide	Receptor	Total
	1	
PU-241		
PU-241	3.13E-02	3.13E-02

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 110 OF 215

-- KESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:22:09 Page: 18 --
 Title : 281 m² room
 Input File : C:\Program Files\KESRAD_Family\BUILD\site6.bld
 Evaluation Time: 0.00000000E+00 years

AM-241	1.59E-03	1.59E-03
NP-237	2.15E-10	2.15E-10
U-233	2.99E-17	2.99E-17
IH-229	8.71E-21	8.71E-21
AM-241		
AM-241	4.00E-02	4.00E-02
NP-237	8.06E-09	8.06E-09
U-233	1.49E-15	1.49E-15
IH-229	5.43E-19	5.43E-19
PU-240		
PU-240	1.39E-02	1.39E-02
U-236	3.09E-11	3.09E-11
IH-232	6.13E-21	6.13E-21
IH-228	2.40E-24	2.40E-24
RA-228	2.69E-23	2.69E-23
PU-239		
PU-239	1.39E-02	1.39E-02
U-235	1.06E-12	1.06E-12
PA-231	1.44E-16	1.44E-16
AC-227	2.53E-18	2.53E-18
PU-238		
PU-238	3.72E-02	3.72E-02
U-234	9.75E-09	9.75E-09
IH-230	6.70E-14	6.70E-14
RA-226	6.40E-18	6.40E-18
PE-210	1.13E-19	1.13E-19
CS-137		
CS-137	9.59E-01	9.59E-01
CS-134		
CS-134	7.54E-04	7.54E-04
SR-90		
SR-90	8.37E-02	8.37E-02
CO-60		
CO-60	7.05E-02	7.05E-02

Source: 4

Nuclide	Receptor	Total
	1	
PU-241		
PU-241	3.13E-02	3.13E-02
AM-241	1.59E-03	1.59E-03
NP-237	2.15E-10	2.15E-10
U-233	2.99E-17	2.99E-17
IH-229	8.71E-21	8.71E-21
AM-241		
AM-241	4.00E-02	4.00E-02
NP-237	8.06E-09	8.06E-09
U-233	1.49E-15	1.49E-15
IH-229	5.43E-19	5.43E-19

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 111 OF 215

** RERAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:22:09 Page: 19 **

Title : 281 m² known

Input File : C:\Program Files\RERAD_Family\BUILD\site6.bld

Evaluation Time: 0.00000000E+00 years

PU-240

EU-240	1.39E-02	1.39E-02
U-236	3.09E-11	3.09E-11
TH-232	6.13E-21	6.13E-21
TH-228	2.40E-24	2.40E-24
RA-228	2.69E-23	2.69E-23

PU-239

EU-239	1.39E-02	1.39E-02
U-235	1.06E-12	1.06E-12
PA-231	1.44E-16	1.44E-16
AC-227	2.53E-18	2.53E-18

PU-238

EU-238	3.72E-02	3.72E-02
U-234	9.75E-09	9.75E-09
TH-230	6.70E-14	6.70E-14
RA-226	6.40E-18	6.40E-18
PB-210	1.13E-19	1.13E-19

CS-137

CS-137	9.59E-01	9.59E-01
--------	----------	----------

CS-134

CS-134	7.54E-04	7.54E-04
--------	----------	----------

SR-90

SR-90	8.37E-02	8.37E-02
-------	----------	----------

CO-60

CO-60	7.05E-02	7.05E-02
-------	----------	----------

Source: 5

Nuclide	Receptor	Total
1		
PU-241		
EU-241	3.13E-02	3.13E-02
AM-241	1.59E-03	1.59E-03
NP-237	2.15E-10	2.15E-10
U-233	2.99E-17	2.99E-17
TH-229	8.71E-21	8.71E-21
AM-241		
AM-241	4.00E-02	4.00E-02
NP-237	8.06E-09	8.06E-09
U-233	1.49E-15	1.49E-15
TH-229	5.43E-19	5.43E-19
PU-240		
EU-240	1.39E-02	1.39E-02
U-236	3.09E-11	3.09E-11
TH-232	6.13E-21	6.13E-21
TH-228	2.40E-24	2.40E-24
RA-228	2.69E-23	2.69E-23
PU-239		
EU-239	1.39E-02	1.39E-02
U-235	1.06E-12	1.06E-12

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 112 OF 215

-- ESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:22:09 Page: 20 --
Title : 281 m2 room
Input File : C:\Program Files\ESRAD_Family\BUILD\site6.bld
Evaluation Time: 0.0000000E+00 years

PA-231	1.44E-16	1.44E-16
AC-227	2.53E-18	2.53E-18
PU-238		
PU-238	3.72E-02	3.72E-02
U-234	9.75E-09	9.75E-09
TH-230	6.70E-14	6.70E-14
RA-226	6.40E-18	6.40E-18
PB-210	1.13E-19	1.13E-19
CS-137		
CS-137	9.59E-01	9.59E-01
CS-134		
CS-134	7.54E-04	7.54E-04
SR-90		
SR-90	8.37E-02	8.37E-02
CO-60		
CO-60	7.05E-02	7.05E-02

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 113 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:22:09 Page: 21 **

Title : 281 m² room

Input File : C:\Program Files\RESRAD_Family\BUILD\site6.bld

Full Summary

RESRAD-BUILD Dose (Time) Tables

Receptor Dose Received for the Exposure Duration

(mrem)

Evaluation Time [yr]

0.00E+00
1. 1.86E+01

Receptor Dose/Yr Averaged Over Exposure Duration

(mrem/yr)

Evaluation Time [yr]

0.00E+00
1. 1.86E+01

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 114 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:43:02 Page: 1 --
Title : 319 m² Area
Input File : C:\Program Files\RESRAD_Family\BUILD\319m2area.bld

RESRAD-BUILD Table of Contents

RESRAD-BUILD Input Parameters.....	2
Building Information.....	3
Source Information.....	4
For time = 0.00E+00 yr	
Time Specific Parameters.....	5
Receptor-Source Dose Summary.....	6
Dose by Pathway Detail.....	7
Dose by Nuclide Detail.....	8
Full Summary.....	9

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 115 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:43:02 Page: 2 **
Title : 319 m² Area
Input File : C:\Program Files\RESRAD_Family\BUILD\319m2area.bld

RESRAD-BUILD Input Parameters

Number of Sources : 1
Number of Receptors: 1
Total Time : 3.650000E+02 days
Fraction Inside : 2.670000E-01

Receptor Information

Receptor	Room	x [m]	y [m]	z [m]	FracTime	Inhalation	Ingestion(Dust)	[m ² /hr]
1	1	8.930	8.930	1.000	1.000	3.57E+01	1.61E-04	

Receptor-Source Shielding Relationship

Receptor	Source	Density [g/cm ³]	Thickness [cm]	Material
1	1	2.40E+00	0.00E+00	Concrete

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 116 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:43:02 Page: 3 --
Title : 319 m² Area
Input File : C:\Program Files\RESRAD_Family\BUILD\319m²area.bld

Building Information

Building Air Exchange Rate: 8.35E-01 1/hr

Height [m]	Air Exchanges [m ³ /hr]
Area [m ²]	*****
	*
	*
	*
	*
	Q01: 1.04E+03
H1: 3.890	*
	Room 1
	*
	LAMBDA: 8.35E-01
Area 319.000	*
	*

Deposition velocity: 4.78E-04 [m/s] Resuspension Rate: 1.33E-09 [1/s]

**TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station**

PAGE 117 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:43:02 Page: 4 **
 Title : 319 m² Area
 Input File : C:\Program Files\RESRAD_Family\BUILD\319m2area.bld

Source Information

Source: 1

Location:: Room : 1 x: 8.93 y: 8.93 z: 0.00[m]
 Geometry:: Type: Area Length[m]:1.79E+01 Width[m]:1.79E+01 Direction: z
 Pathway ::
 Direct Ingestion Rate: 3.450E-07 [1/hr]
 Fraction released to air: 5.170E-01
 Removable fraction: 1.000E-01
 Time to Remove: 5.280E+04 [day]
 Radon Release Fraction: 0.000E+00

Contamination::

Nuclide Concentration

Dose Conversion Factor (Library: FCR 13 Morbidity)

		Ingestion [mrem/dpm]	Inhalation [mrem/dpm]	Submersion [mrem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.555E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
Pa-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SP-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 118 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:43:02 Page: 5 --
Title : 319 m2 Area
Input File : C:\Program Files\RESRAD_Family\BUILD\319m2area.bld
Evaluation Time: 0.0000000E+00 years

Assessment for Time: 1
Time =0.00E+00 yr

Source Information

Source: 1

Location:: Room : 1 x: 8.93 y: 8.93 z: 0.00 [m]
Geometry:: Type: Area Length[m]:1.79E+01 Width[m]:1.79E+01 Direction: z
Pathway ::
Direct Ingestion Rate: 3.450E-07 [1/hr]
Fraction released to air: 5.170E-01
Removable fraction: 1.000E-01
Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	DU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	ND-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	Pb-231	0.000E+00
	TH-232	0.000E+00
	TH-230	0.000E+00
	TH-229	0.000E+00
	TH-228	0.000E+00
	AC-227	0.000E+00
	Ra-228	0.000E+00
	Ra-226	0.000E+00
	Pb-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	Sr-90	3.800E+05
	Co-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 119 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:43:02 Page: 6 **

Title : 319 m² Area

Input File : C:\Program Files\RESRAD_Family\BUILD\319m2area.bld

Evaluation Time: 0.00000000E+00 years

RESRAD-BUILD Dose Tables

Source Contributions to Receptor Doses

[mrem]

	Source	Total
	1	
Receptor 1	1.81E+01	1.81E+01
Total	1.81E+01	1.81E+01

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 120 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:43:02 Page: 7 --
Title : 319 m² Area
Input File : C:\Program Files\RESRAD_Family\BUILD\319m²area.bld
Evaluation Time: 0.0000000E+00 years

Pathway Detail of Doses

[rem]

Source: 1

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	1.41E+01	3.25E-02	1.67E-05	1.50E-01	2.80E-24	3.74E+00
Total	1.41E+01	3.25E-02	1.67E-05	1.50E-01	2.80E-24	3.74E+00

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 121 OF 215

-- RESEAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:43:02 Page: 8 --
Title : 319 m² Area
Input File : C:\Program Files\RESEAD_Family\BUILD\319m2area.hld
Evaluation Time: 0.00000000E+00 years

Nuclide Detail of Doses**[in rem]**

Source: 1

Nuclide	Receptor	Total
	1	
PU-241		
PU-241	2.21E-01	2.21E-01
AM-241	1.02E-02	1.02E-02
NP-237	1.38E-09	1.38E-09
U-233	1.40E-16	1.40E-16
IH-229	4.02E-20	4.02E-20
AM-241		
AM-241	2.57E-01	2.57E-01
NP-237	5.18E-08	5.18E-08
U-233	7.01E-15	7.01E-15
IH-229	2.51E-18	2.51E-18
PU-240		
PU-240	8.85E-02	8.85E-02
U-236	1.45E-10	1.45E-10
IH-232	2.71E-20	2.71E-20
IH-228	1.86E-23	1.86E-23
RA-228	2.74E-22	2.74E-22
PU-239		
PU-239	8.85E-02	8.85E-02
U-235	5.67E-12	5.67E-12
PA-231	9.18E-16	9.18E-16
AC-227	1.33E-17	1.33E-17
PU-238		
PU-238	2.45E-01	2.45E-01
U-234	4.59E-08	4.59E-08
IH-230	2.97E-13	2.97E-13
RA-226	6.50E-17	6.50E-17
PR-210	9.70E-19	9.70E-19
CS-137		
CS-137	1.52E+01	1.52E+01
CS-134		
CS-134	1.30E-02	1.30E-02
Sr-90		
Sr-90	7.08E-01	7.08E-01
CO-60		
CO-60	1.29E+00	1.29E+00

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 122 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:43:02 Page: 9 --
Title : 319 m² Area
Input File : C:\Program Files\RESRAD_Family\BUILD\319m2area.bld
Full Summary

RESRAD-BUILD Dose (Time) Tables

Receptor Dose Received for the Exposure Duration

(mrem)

Evaluation Time [yr]

0.00E+00

1 1.81E+01

Receptor Dose/Yr Averaged Over Exposure Duration

(mrem/yr)

Evaluation Time [yr]

0.00E+00

1 1.81E+01

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 123 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:51:06 Page: 1 --
Title : 319 m² Room
Input File : C:\Program Files\RESRAD_Family\BUILD\site1.bld

RESRAD-BUILD Table of Contents

KESRAD-BUILD Input Parameters.....	2
Building Information.....	3
Source Information.....	4
For time = 0.00E+00 yr	
Time Specific Parameters.....	5
Receptor-Source Dose Summary.....	14
Dose by Pathway Detail.....	15
Dose by Nuclide Detail.....	16
Full Summary.....	21

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 124 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:51:06 Page: 2 **
Title : 319 m² Room
Input File : C:\Program Files\RESRAD_Family\BUILD\site1.bld

RESRAD-BUILD Input Parameters

Number of Sources : 5
Number of Receptors: 1
Total Time : 3.650000E+02 days
Fraction Inside : 2.670000E-01

Receptor Information

Receptor	Room	x [m]	y [m]	z [m]	FracTime	Inhalation [m ³ /day]	Ingestion(Dust) [m ² /hr]
1	1	5.850	5.250	1.000	1.000	3.57E+01	1.61E-04

Receptor-Source Shielding Relationship

Receptor	Source	Density [g/cm ³]	Thickness [cm]	Material
1	1	2.40E+00	0.00E+00	Concrete
1	2	2.40E+00	0.00E+00	Concrete
1	3	2.40E+00	0.00E+00	Concrete
1	4	2.40E+00	0.00E+00	Concrete
1	5	2.40E+00	0.00E+00	Concrete

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 125 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:51:06, Page: 3 --
Title : 319 m² Room
Input File : C:\Program Files\RESRAD_Family\BUILD\site1.bld

Building Information

Building Air Exchange Rate: 8.35E-01 1/hr

Height [m]	Air Exchanges [m ³ /hr]
Area [m ²]	*****
	*
	*
	*
	*
	Q01: 4.45E+02
H1: 3.890	Room 1
	LAMBDA: 8.35E-01
Area 137.000	Q10 : 4.45E+02
	*
	*
	*

Deposition velocity: 4.78E-04 [m/s] Resuspension Rate: 1.33E-09 [1/s]

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 126 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:51:06 Page: 4 **
 Title : 319 m² Room
 Input File : C:\Program Files\RESRAD_Family\BUILD\site1.bld

Source Information**Source: 1**

Location:: Room : 1 x: 5.85 y: 5.85 z: 0.00[m]
 Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:1.17E+01 Direction: x
 Pathway ::
 Direct Ingestion Rate: 3.450E-07 [1/hr]
 Fraction released to air: 5.170E-01
 Removable fraction: 1.000E-01
 Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::**Nuclide Concentration****Dose Conversion Factor (Library: FGR 13 Morbidity)**

		Ingestion [mrem/dpm]	Inhalation [mrem/dpm]	Submersion [mrem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.802E-04	6.081E-02	8.576E-07
RA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
IH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
IH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
IH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
IH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 127 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:51:06 Page: 5 **
 Title : 319 m² Room
 Input File : C:\Program Files\RESRAD_Family\BUILD\site1.bld

Source: 2

Location:: Room : 1 x: 0.00 y: 5.85 z: 0.00[m]

Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:3.89E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::**Nuclide Concentration****Dose Conversion Factor (Library: FGR 13 Morbidity)**

	[dpm/m ²]	Ingestion [mrem/dpm]	Inhalation [mrem/dpm]	Submersion [mrem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.061E-05	3.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
FB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 128 OF 215

** NERSCAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:51:06 Page: 6 **
 Title : 319 m2 Room
 Input File : C:\Program Files\NERSCAD_Family\BUILD\site1.bld

Source: 3

Location:: Room : 1 x: 5.85 y: 0.00 z: 0.00[m]
 Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:3.89E+00 Direction: y
 Pathway ::
 Direct Ingestion Rate: 3.450E-07 [1/hr]
 Fraction released to air: 5.170E-01
 Removable fraction: 1.000E-01
 Time to Remove: 5.280E+04 [day]
 Radon Release Fraction: 0.000E+00

Contamination::**Nuclide Concentration Dose Conversion Factor (Library: FGR 12 Morbidity)**

	[dpm/m ²]	Ingestion [mrem/dpm]	Inhalation [mrem/dpm]	Skin/Respiratory [mrem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.200E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
ND-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	8.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SR-90	3.200E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

**TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station**

PAGE 129 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:51:06 Page: 7 **
 Title : 319 m² Room
 Input File : C:\Program Files\RESRAD_Family\BUILD\site1.bld

Source: 4

Location:: Room : 1 x: 11.70 y: 5.85 z: 0.00[m]
 Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:3.89E+00 Direction: x
 Pathway ::
 Direct Ingestion Rate: 3.450E-07 [1/hr]
 Fraction released to air: 5.170E-01
 Removable fraction: 1.000E-01
 Time to Remove: 5.280E+04 [day]
 Radon Release Fraction: 0.000E+00

Contamination::**Nuclide Concentration****Dose Conversion Factor (Library: FCR 13 Morbidity)**

	[dpm/m ²]	Ingestion [mrem/dpm]	Inhalation [mrem/dpm]	Schmerson [mrem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.804E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.065E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 130 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:51:06 Page: 8 **

Title : 319 m² Room

Input File : C:\Program Files\RESRAD_Family\BUILD\site1.bld

Source: 5

Location:: Room : 1 x: 5.85 y: 11.70 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:3.89E+00 Direction: y

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::

Nuclide Concentration

Dose Conversion Factor (Library: FCR 13 Morbidity

		Ingestion [rem/dpm]	Inhalation [rem/dpm]	Submersion [rem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.800E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.840E+03	1.411E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.802E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 131 OF 215

-- RESEAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:51:06 Page: 9 --

Title : 319 m² Room

Input File : C:\Program Files\RESEAD_Family\BUILD\site1.bld

Evaluation Time: 0.0000000E+00 years

Assessment for Time: 1
Time =0.00E+00 yr

Source Information

Source: 1

Location:: Room : 1 x: 5.85 y: 5.85 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:1.17E+01 Direction: z

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	DU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	DU-239	1.700E+03
	DU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	TH-232	0.000E+00
	TH-230	0.000E+00
	TH-229	0.000E+00
	TH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	BB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 132 OF 215

-- NESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:51:06 Page: 10 --

Title : 319 m² Room

Input File : C:\Program Files\NESRAD_Family\BUILD\site1.bld

Evaluation Time: 0.0000000E+00 years

Source: 2

Location:: Room : 1 x: 0.00 y: 5.85 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:3.89E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	ND-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	Pa-231	0.000E+00
	Th-232	0.000E+00
	Th-230	0.000E+00
	Th-229	0.000E+00
	Th-228	0.000E+00
	Ac-227	0.000E+00
	Ra-228	0.000E+00
	Ra-226	0.000E+00
	Pb-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	Sr-90	3.800E+05
	Co-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 133 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:51:06 Page: 11 --

Title : 319 m² Room

Input File : C:\Program Files\RESRAD_Family\BUILD\site1.bld

Evaluation Time: 0.0000000E+00 years

Source: 3

Location:: Room : 1 x: 5.85 y: 0.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:3.89E+00 Direction: y

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	TH-232	0.000E+00
	TH-230	0.000E+00
	TH-229	0.000E+00
	TH-228	0.000E+00
	AC-227	0.000E+00
	RA-226	0.000E+00
	RA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	Sr-90	3.800E+05
	CO-60	5.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 134 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:51:06 Page: 12 **

Title : 819 m² Room

Input File : C:\Program Files\RESRAD_Family\BUILD\site1.bld

Evaluation Time: 0.0000000E+00 years

Source: 4

Location:: Room : 1 x: 11.70 y: 5.25 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:3.89E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	TH-232	0.000E+00
	TH-230	0.000E+00
	TH-229	0.000E+00
	TH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	Sr-90	3.800E+05
	CD-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 135 OF 215

-- RESTAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:51:06 Page: 13 --

Title : 319 m2 Room

Input File : C:\Program Files\RESTAD_Family\BUILD\site1.bld

Evaluation Time: 0.0000000E+00 years

Source: 5

Location:: Room : 1 x: 5.85 y: 11.70 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.17E+01 Width[m]:3.89E+00 Direction: y

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.800E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	ND-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	TH-232	0.000E+00
	TH-230	0.000E+00
	TH-229	0.000E+00
	TH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	Sr-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 136 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:51:06 Page: 14 --
Title : 319 m² Room
Input File : C:\Program Files\RESRAD_Family\BUILD\site1.bld
Evaluation Time: 0.0000000E+00 years

RESRAD-BUILDDose Tables

Source Contributions to Receptor Doses

[rem]

	Source 1	Source 2	Source 3	Source 4	Source 5	Total
Receptor 1	1.35E+01	1.59E+00	1.59E+00	1.59E+00	1.59E+00	1.59E+01
Total	1.35E+01	1.59E+00	1.59E+00	1.59E+00	1.59E+00	1.59E+01

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 137 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:51:06 Page: 15 **

Title : 319 m² Room

Input File : C:\Program Files\RESRAD_Family\BUILD\site1.bld

Evaluation Time: 0.00000000E+00 years

Pathway Detail of Doses

[rem]

Source: 1

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	1.16E+01	2.67E-02	1.67E-05	1.49E-01	2.80E-24	1.69E+00
Total	1.16E+01	2.67E-02	1.67E-05	1.49E-01	2.80E-24	1.69E+00

Source: 2

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	9.67E-01	8.87E-03	5.56E-06	4.97E-02	9.31E-25	5.61E-01
Total	9.67E-01	8.87E-03	5.56E-06	4.97E-02	9.31E-25	5.61E-01

Source: 3

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	9.67E-01	8.87E-03	5.56E-06	4.97E-02	9.31E-25	5.61E-01
Total	9.67E-01	8.87E-03	5.56E-06	4.97E-02	9.31E-25	5.61E-01

Source: 4

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	9.67E-01	8.87E-03	5.56E-06	4.97E-02	9.31E-25	5.61E-01
Total	9.67E-01	8.87E-03	5.56E-06	4.97E-02	9.31E-25	5.61E-01

Source: 5

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	9.67E-01	8.87E-03	5.56E-06	4.97E-02	9.31E-25	5.61E-01
Total	9.67E-01	8.87E-03	5.56E-06	4.97E-02	9.31E-25	5.61E-01

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 138 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:51:06 Page: 16 --
Title : 319 m² Room
Input File : C:\Program Files\RESRAD_Family\BUILD\site1.bld
Evaluation Time: 0.00000000E+00 years

Nuclide Detail of Doses

[more]

Source: 1

Nuclide Receptor	Total
PU-241	1
PU-241	1.15E-01
AM-241	5.62E-03
NP-237	7.70E-10
U-233	9.74E-17
TH-229	2.87E-20
AM-241	1.41E-01
NP-237	2.89E-08
U-233	4.87E-15
TH-229	1.79E-18
PU-240	4.88E-02
U-236	1.01E-10
TH-232	1.97E-20
TH-228	1.30E-23
RA-228	1.47E-22
PU-239	4.88E-02
U-235	4.04E-12
PA-231	5.06E-16
AC-227	8.74E-18
PU-238	1.32E-01
U-234	3.18E-08
TH-230	2.16E-13
RA-226	3.92E-17
PB-210	4.35E-19
CS-137	1.16E+01
CS-137	1.16E+01
CS-134	1.02E-02
Sr-90	3.27E-01
Sr-90	3.27E-01
CO-60	1.05E+00
CO-60	1.05E+00

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 139 OF 215

** NERAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:51:06 Page: 17 **
 Title : 319 m2 Room
 Input File : C:\Program Files\NERAD_Family\BUILD\site1.bld
 Evaluation Time: 0.00000000E+00 years

Source: 2

Nuclide Receptor	Total
1	
PU-241	
PU-241	3.81E-02
AM-241	1.86E-03
NP-237	2.50E-10
U-233	3.23E-17
TH-229	9.37E-21
AM-241	
AM-241	4.67E-02
NP-237	9.38E-09
U-233	1.62E-15
TH-229	5.84E-19
PU-240	
PU-240	1.62E-02
U-236	3.34E-11
TH-232	6.56E-21
TH-228	2.87E-24
RA-228	3.46E-23
PU-239	
PU-239	1.62E-02
U-235	1.16E-12
PA-231	1.68E-16
AC-227	2.88E-18
PU-238	
PU-238	4.40E-02
U-234	1.06E-08
TH-230	7.17E-14
RA-226	7.99E-18
PB-210	1.45E-19
CS-137	
CS-137	1.23E+00
CS-134	
CS-134	9.69E-04
SR-90	
SR-90	1.06E-01
CO-60	
CO-60	9.04E-02

Source: 3

Nuclide Receptor	Total
1	
PU-241	
PU-241	3.81E-02

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 140 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:51:06 Page: 18 **

Title : 319 m² Room

Input File : C:\Program Files\RESRAD_Family\BUILD\site1.bld

Evaluation Time: 0.00000000E+00 years

AM-241	1.86E-03	1.86E-03
NP-237	2.50E-10	2.50E-10
U-233	3.23E-17	3.23E-17
TH-229	9.37E-21	9.37E-21
AM-241		
AM-241	4.67E-02	4.67E-02
NP-237	9.38E-09	9.38E-09
U-233	1.62E-15	1.62E-15
TH-229	5.84E-19	5.84E-19
PU-240		
PU-240	1.62E-02	1.62E-02
U-236	3.34E-11	3.34E-11
TH-232	6.56E-21	6.56E-21
TH-228	2.87E-24	2.87E-24
RA-228	3.46E-23	3.46E-23
PU-239		
PU-239	1.62E-02	1.62E-02
U-235	1.16E-12	1.16E-12
PA-231	1.68E-16	1.68E-16
AC-227	2.88E-18	2.88E-18
PU-238		
PU-238	4.40E-02	4.40E-02
U-234	1.06E-08	1.06E-08
TH-230	7.17E-14	7.17E-14
RA-226	7.99E-18	7.99E-18
FB-210	1.45E-19	1.45E-19
CS-137		
CS-137	1.23E+00	1.23E+00
CS-134		
CS-134	9.69E-04	9.69E-04
SR-90		
SR-90	1.06E-01	1.06E-01
CO-60		
CO-60	9.04E-02	9.04E-02

Source: 4

Nuclide	Receptor	Total
1		
PU-241		
PU-241	3.81E-02	3.81E-02
AM-241	1.86E-03	1.86E-03
NP-237	2.50E-10	2.50E-10
U-233	3.23E-17	3.23E-17
TH-229	9.37E-21	9.37E-21
AM-241		
AM-241	4.67E-02	4.67E-02
NP-237	9.38E-09	9.38E-09
U-233	1.62E-15	1.62E-15
TH-229	5.84E-19	5.84E-19

**TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station**

PAGE 141 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:51:06 Page: 19 --

Title : 319 m² Room

Input File : C:\Program Files\RESRAD_Family\BUILD\sitel.bld

Evaluation Time: 0.00000000E+00 years

PU-240

PU-240	1.62E-02	1.62E-02
---------------	-----------------	-----------------

U-236	3.34E-11	3.34E-11
--------------	-----------------	-----------------

TH-232	6.56E-21	6.56E-21
---------------	-----------------	-----------------

TH-228	2.87E-24	2.87E-24
---------------	-----------------	-----------------

RA-228	3.46E-23	3.46E-23
---------------	-----------------	-----------------

PU-239

PU-239	1.62E-02	1.62E-02
---------------	-----------------	-----------------

U-235	1.16E-12	1.16E-12
--------------	-----------------	-----------------

PA-231	1.68E-16	1.68E-16
---------------	-----------------	-----------------

AC-227	2.88E-18	2.88E-18
---------------	-----------------	-----------------

PU-238

PU-238	4.40E-02	4.40E-02
---------------	-----------------	-----------------

U-234	1.06E-08	1.06E-08
--------------	-----------------	-----------------

TH-230	7.17E-14	7.17E-14
---------------	-----------------	-----------------

RA-226	7.99E-18	7.99E-18
---------------	-----------------	-----------------

FB-210	1.45E-19	1.45E-19
---------------	-----------------	-----------------

CS-137

CS-137	1.23E+00	1.23E+00
---------------	-----------------	-----------------

CS-134

CS-134	9.69E-04	9.69E-04
---------------	-----------------	-----------------

SR-90

SR-90	1.06E-01	1.06E-01
--------------	-----------------	-----------------

CO-60

CO-60	9.04E-02	9.04E-02
--------------	-----------------	-----------------

Source: 5

Nuclide	Receptor	Total
	1	
PU-241		
PU-241	3.81E-02	3.81E-02
AM-241	1.86E-03	1.86E-03
HP-237	2.50E-10	2.50E-10
U-233	3.23E-17	3.23E-17
TH-229	9.37E-21	9.37E-21
AM-241		
AM-241	4.67E-02	4.67E-02
HP-237	9.38E-09	9.38E-09
U-233	1.62E-15	1.62E-15
TH-229	5.84E-19	5.84E-19
PU-240		
PU-240	1.62E-02	1.62E-02
U-236	3.34E-11	3.34E-11
TH-232	6.56E-21	6.56E-21
TH-228	2.87E-24	2.87E-24
RA-228	3.46E-23	3.46E-23
PU-239		
PU-239	1.62E-02	1.62E-02
U-235	1.16E-12	1.16E-12

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 142 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:51:06 Page: 20 --
Title : 319 m² Room
Input File : C:\Program Files\RESRAD_Family\BUILD\site1.bld
Evaluation Time: 0.00000000E+00 years

PA-231	1.68E-16	1.68E-16
AC-227	2.88E-18	2.88E-18
PU-238		
FU-238	4.40E-02	4.40E-02
U-234	1.06E-02	1.06E-02
IH-230	7.17E-14	7.17E-14
RA-226	7.99E-18	7.99E-18
PB-210	1.45E-19	1.45E-19
CS-137		
CS-137	1.23E+00	1.23E+00
CS-134		
CS-134	9.69E-04	9.69E-04
SR-90		
SR-90	1.06E-01	1.06E-01
CO-60		
CO-60	9.04E-02	9.04E-02

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 143 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 14:51:06 Page: 21 **

Title : 319 m² Room

Input File : C:\Program Files\RESRAD_Family\BUILD\site1.bld

Full Summary

RESRAD-BUILD Dose (Time) Tables

Receptor Dose Received for the Exposure Duration

(mrem)

Evaluation Time [yr]

0.00E+00

1 1.58E+01

Receptor Dose/Yr Averaged Over Exposure Duration

(mrem/yr)

Evaluation Time [yr]

0.00E+00

1 1.58E+01

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 144 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 15:14:05 Page: 1 --

Title : 319 m² Room

Input File : C:\Program Files\RESRAD_Family\BUILD\room+ceiling.bld

RESRAD-BUILD Table of Contents

RESRAD-BUILD Input Parameters.....	2
Building Information.....	3
Source Information.....	4
For time = 0.00E+00 yr	
Time Specific Parameters.....	10
Receptor-Source Dose Summary.....	16
Dose by Pathway Detail.....	17
Dose by Nuclide Detail.....	18
Full Summary.....	24

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 145 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 15:14:05 Page: 2 **
Title : 319 m² Room
Input File : C:\Program Files\RESRAD_Family\BUILD\room+ceiling.bld

RESRAD-BUILD Input Parameters

Number of Sources : 6
Number of Receptors: 1
Total Time : 3.650000E+02 days
Fraction Inside : 2.670000E-01

Receptor Information

Receptor	Room	x [m]	y [m]	z [m]	FracTime	Inhalation	Ingestion(Dust) [m ² /day]	[m ² /hr]
1	1	5.000	5.000	1.000	1.000	3.57E+01	1.61E-04	

Receptor-Source Shielding Relationship

Receptor	Source	Density [g/cm ³]	Thickness [cm]	Material
1	1	2.40E+00	0.00E+00	Concrete
1	2	2.40E+00	0.00E+00	Concrete
1	3	2.40E+00	0.00E+00	Concrete
1	4	2.40E+00	0.00E+00	Concrete
1	5	2.40E+00	0.00E+00	Concrete
1	6	2.40E+00	0.00E+00	Concrete

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 146 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 15:14:05 Page: 3 **
Title : 319 m² Room
Input File : C:\Program Files\RESRAD_Family\BUILD\room4ceiling.bld

Building Information

Building Air Exchange Rate: 8.35E-01 1/hr

Height [m]	Air Exchanges [m ³ /hr]	
Area [m ²]	*****	
	*	*
	*	*
	*	
	←Q01: 2.50E+02	
H1: 3.000	Room 1	Q10 : 2.50E+02
	LAMBDA: 8.35E-01	
Area 100.000	*****	
	*	*
	*	

Deposition velocity: 4.78E-04 [m/s] Resuspension Rate: 1.33E-09 [1/s]

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 147 OF 215

** RESPAD-BUILD Dose Program Output, Version 3.3 02/21/06 15:14:05 Page: 4 **
 Title : 319 m² Room
 Input File : C:\Program Files\RESPAD_Family\BUILD\room+ceiling.bld

Source Information

Source: 1

Location:: Room : 1 x: 5.00 y: 5.00 z: 0.00[m]
 Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:1.00E+01 Direction: z
 Pathway ::
 Direct Ingestion Rate: 3.450E-07 [1/hr]
 Fraction released to air: 5.170E-01
 Removable fraction: 1.000E-01
 Time to Remove: 5.280E+04 [day]
 Radon Release Fraction: 0.000E+00

Contamination::**Nuclide Concentration****Dose Conversion Factor (Library: FGR 13 Morbidity)**

		Ingestion [mrem/dpm]	Inhalation [mrem/dpm]	Submersion [mrem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-06
AM-241	4.770E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
RB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.683E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 148 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 15:14:05 Page: 5 --

Title : 319 m2 Room

Input File : C:\Program Files\RESRAD_Family\BUILD\room+ceiling.bld

Source: 2

Location:: Room : 1 x: 0.00 y: 5.00 z: 0.00[m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.00E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::

Nuclide Concentration

Dose Conversion Factor (Library: ICRP 13 Morbidity)

	[dpm/m ²]	Ingestion [mrem/dpm]	Inhalation [mrem/dpm]	Submersion [mrem/yr/ (dpm/m ³)]
PU-241	2.420E+05	8.081E-05	8.716E-03	1.151E-08
AM-241	4.770E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.695E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	8.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.061E-05	3.983E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

**TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station**

PAGE 149 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 15:14:05 Page: 6 **

Title : 319 m² Room

Input File : C:\Program Files\RESRAD_Family\BUILD\room+ceiling.bld

Source: 3

Location:: Room : 1 x: 5.00 y: 0.00 z: 0.00[m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.00E+00 Direction: y

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::

Nuclide Concentration

Dose Conversion Factor (Library: FGR 13 Morbidity)

	[dpm/m ²]	Ingestion [rem/dpm]	Inhalation [rem/dpm]	Submersion [rem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.770E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.456E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PR-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 150 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 15:14:05 Page: 7 **

Title : 319 m2 Room

Input File : C:\Program Files\RESRAD_Family\BUILD\room+ceiling.bld

Source: 4

Location:: Room : 1 x: 10.00 y: 5.00 z: 0.00[m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.00E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::

Nuclide Concentration	Dose Conversion Factor (Library: FCR 13 Morbidity)
PU-241	2.420E+05
AM-241	4.770E+03
EU-240	1.700E+03
EU-239	1.700E+03
DU-238	5.340E+03
NP-237	0.000E+00
U-236	0.000E+00
U-235	0.000E+00
U-234	0.000E+00
U-233	0.000E+00
PA-231	0.000E+00
TH-232	0.000E+00
TH-230	0.000E+00
TH-229	0.000E+00
TH-228	0.000E+00
ZC-227	0.000E+00
RA-228	0.000E+00
RA-226	0.000E+00
PB-210	0.000E+00
CS-137	3.820E+06
CS-134	1.800E+03
SR-90	3.800E+05
CO-60	9.430E+04

	[dpm/m ²]	Ingestion [mrem/dpm]	Inhalation [mrem/dpm]	Submersion [mrem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.770E+03	1.640E-03	2.000E-01	4.304E-05
EU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
EU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
DU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
ZC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.800E+03	3.302E-05	2.081E-05	3.963E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 151 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 15:14:05 Page: 8 **

Title : 319 m² Room

Input File : C:\Program Files\RESRAD_Family\BUILD\rroom+ceiling.bld

Source: 5

Location:: Room : 1 x: 5.00 y: 10.00 z: 0.00[m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.00E+00 Direction: y

Pathway ::

 Direct Ingestion Rate: 3.450E-07 [1/hr]

 Fraction released to air: 5.170E-01

 Removable fraction: 1.000E-01

 Time to Remove: 5.280E+04 [day]

 Radon Release Fraction: 0.000E+00

Contamination::

Nuclide Concentration

Dose Conversion Factor (Library: FGR 13 Morbidity

	[dpm/m ²]	Ingestion [rem/dpm]	Inhalation [rem/dpm]	Submersion [rem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.770E+03	1.640E-03	2.000E-01	4.304E-05
PU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NE-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.734E-04
R2-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PR-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SI-90	3.600E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

**TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station**

PAGE 152 OF 215

-- RESPAD-BUILD Dose Program Output, Version 3.3 02/21/06 15:14:05 Page: 9 --

Title : 319 m² Room

Input File : C:\Program Files\RESPAD_Family\BUILD\room+ceiling.bld

Source: 6

Location:: Room : 1 x: 5.00 y: 10.00 z: 3.00[m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:1.00E+01 Direction: z

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Radon Release Fraction: 0.000E+00

Contamination::

Nuclide Concentration

Dose Conversion Factor (Library: FGR 13 Morbidity

		Ingestion [mrem/dpm]	Inhalation [mrem/dpm]	Submersion [mrem/yr/ (dpm/m ³)]
PU-241	2.420E+05	3.081E-05	3.716E-03	1.151E-08
AM-241	4.770E+03	1.640E-03	2.000E-01	4.304E-05
DU-240	1.700E+03	1.595E-03	1.932E-01	2.499E-07
PU-239	1.700E+03	1.595E-03	1.932E-01	2.231E-07
PU-238	5.340E+03	1.441E-03	1.766E-01	2.567E-07
NP-237	0.000E+00	2.002E-03	2.432E-01	5.461E-04
U-236	0.000E+00	1.212E-04	5.631E-02	2.636E-07
U-235	0.000E+00	1.204E-04	5.541E-02	4.063E-04
U-234	0.000E+00	1.275E-04	5.946E-02	4.014E-07
U-233	0.000E+00	1.302E-04	6.081E-02	8.576E-07
PA-231	0.000E+00	4.775E-03	5.766E-01	9.049E-05
TH-232	0.000E+00	1.230E-03	7.387E-01	4.588E-07
TH-230	0.000E+00	2.468E-04	1.468E-01	9.155E-07
TH-229	0.000E+00	1.814E-03	9.768E-01	7.842E-04
TH-228	0.000E+00	3.642E-04	1.556E-01	4.224E-03
AC-227	0.000E+00	6.665E-03	3.029E+00	9.784E-04
RA-228	0.000E+00	6.496E-04	2.287E-03	2.515E-03
RA-226	0.000E+00	5.950E-04	3.871E-03	4.663E-03
PB-210	0.000E+00	2.422E-03	6.214E-03	4.698E-06
CS-137	3.820E+06	2.252E-05	1.437E-05	1.434E-03
CS-134	1.500E+03	3.302E-05	2.081E-05	3.983E-03
SR-90	3.800E+05	6.883E-05	5.894E-04	1.039E-05
CO-60	9.430E+04	1.212E-05	9.865E-05	6.629E-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 153 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 15:14:05 Page: 10 --

Title : 319 m² Room

Input File : C:\Program Files\RESRAD_Family\BUILD\room+ceiling.bld

Evaluation Time: 0.0000000E+00 years

Assessment for Time: 1
Time =0.00E+00 yr

Source Information

Source: 1

Location:: Room : 1 x: 5.00 y: 5.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:1.00E+01 Direction: z

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.770E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	IH-232	0.000E+00
	IH-230	0.000E+00
	IH-229	0.000E+00
	IH-228	0.000E+00
	AC-227	0.000E+00
	RA-226	0.000E+00
	RA-226	0.000E+00
	FB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 154 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 15:14:05 Page: 11 --

Title : 319 m² Room

Input File : C:\Program Files\RESRAD_Family\BUILD\room+ceiling.bld

Evaluation Time: 0.0000000E+00 years

Source: 2

Location:: Room : 1 x: 0.00 y: 5.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.00E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.770E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	ND-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	TH-232	0.000E+00
	TH-230	0.000E+00
	TH-229	0.000E+00
	TH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 155 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 15:14:05 Page: 12 --

Title : 319 m² Room

Input File : C:\Program Files\RESRAD_Family\BUILD\room+ceiling.bld

Evaluation Time: 0.0000000E+00 years

Source: 3

Location:: Room : 1 x: 5.00 y: 0.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.00E+00 Direction: y

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.770E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	RA-231	0.000E+00
	TH-232	0.000E+00
	TH-230	0.000E+00
	TH-229	0.000E+00
	TH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 156 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 15:14:05 Page: 13 --

Title : 319 m² Room

Input File : C:\Program Files\RESRAD_Family\BUILD\room+ceiling.bld

Evaluation Time: 0.00000000E+00 years

Source: 4

Location:: Room : i x: 10.00 y: 5.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.00E+00 Direction: x

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.770E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	TH-232	0.000E+00
	TH-230	0.000E+00
	TH-229	0.000E+00
	TH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	8.820E+06
	CS-134	1.500E+03
	Sr-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 157 OF 215

-- RESPAD-BUILD Dose Program Output, Version 3.3 02/21/06 15:14:05 Page: 14 --

Title : 319 m2 Room

Input File : C:\Program Files\RESPAD_Family\BUILD\room+ceiling.bld

Evaluation Time: 0.0000000E+00 years

Source: 5

Location:: Room : 1 x: 5.00 y: 10.00 z: 0.00 [m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:3.00E+00 Direction: y

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hr]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.770E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	NP-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	IH-232	0.000E+00
	IH-230	0.000E+00
	IH-229	0.000E+00
	IH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	FB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CO-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 158 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 15:14:05 Page: 15 --

Title : 319 m² Room

Input File : C:\Program Files\RESRAD_Family\BUILD\room+ceiling.hld

Evaluation Time: 0.0000000E+00 years

Source: 6

Location:: Room : 1 x: 5.00 y: 10.00 z: 3.00 [m]

Geometry:: Type: Area Length[m]:1.00E+01 Width[m]:1.00E+01 Direction: z

Pathway ::

Direct Ingestion Rate: 3.450E-07 [1/hx]

Fraction released to air: 5.170E-01

Removable fraction: 1.000E-01

Time to Remove: 5.280E+04 [day]

Contamination::	Nuclide	Concentration [dpm/m ²]
	PU-241	2.420E+05
	AM-241	4.770E+03
	PU-240	1.700E+03
	PU-239	1.700E+03
	PU-238	5.340E+03
	ND-237	0.000E+00
	U-236	0.000E+00
	U-235	0.000E+00
	U-234	0.000E+00
	U-233	0.000E+00
	PA-231	0.000E+00
	TH-232	0.000E+00
	TH-230	0.000E+00
	TH-229	0.000E+00
	TH-228	0.000E+00
	AC-227	0.000E+00
	RA-228	0.000E+00
	RA-226	0.000E+00
	PB-210	0.000E+00
	CS-137	3.820E+06
	CS-134	1.500E+03
	SR-90	3.800E+05
	CD-60	9.430E+04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 159 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 15:14:05 Page: 16 **
Title : 319 m² Room
Input File : C:\Program Files\RESRAD_Family\BUILD\xroom+ceiling.bld
Evaluation Time: 0.00000000E+00 years

RESRAD-BUILD Dose Tables

Source Contributions to Receptor Doses

[mrem]

	Source 1	Source 2	Source 3	Source 4	Source 5	Source 6	Total
Receptor 1	1.22E+01	1.33E+00	1.33E+00	1.33E+00	1.33E+00	5.63E+00	2.31E+01
Total	1.22E+01	1.33E+00	1.33E+00	1.33E+00	1.33E+00	5.63E+00	2.31E+01

**TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station**

PAGE 160 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 15:14:05 Page: 17 --
 Title : 319 m² Room
 Input File : C:\Program Files\RESRAD_Family\BUILD\xroom+ceiling.bld
 Evaluation Time: 0.00000000E+00 years

Pathway Detail of Doses

[rem]

Source: 1

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	1.07E+01	3.03E-02	2.07E-05	1.89E-01	3.45E-24	1.30E+00
Total	1.07E+01	3.03E-02	2.07E-05	1.89E-01	3.45E-24	1.30E+00

Source: 2

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	8.71E-01	9.10E-03	6.20E-06	5.68E-02	1.04E-24	3.91E-01
Total	8.71E-01	9.10E-03	6.20E-06	5.68E-02	1.04E-24	3.91E-01

Source: 3

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	8.71E-01	9.10E-03	6.20E-06	5.68E-02	1.04E-24	3.91E-01
Total	8.71E-01	9.10E-03	6.20E-06	5.68E-02	1.04E-24	3.91E-01

Source: 4

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	8.71E-01	9.10E-03	6.20E-06	5.68E-02	1.04E-24	3.91E-01
Total	8.71E-01	9.10E-03	6.20E-06	5.68E-02	1.04E-24	3.91E-01

Source: 5

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	8.71E-01	9.10E-03	6.20E-06	5.68E-02	1.04E-24	3.91E-01
Total	8.71E-01	9.10E-03	6.20E-06	5.68E-02	1.04E-24	3.91E-01

Source: 6

Receptor	External	Deposition	Immersion	Inhalation	Radon	Ingestion
1	4.10E+00	3.03E-02	2.07E-05	1.89E-01	3.45E-24	1.30E+00
Total	4.10E+00	3.03E-02	2.07E-05	1.89E-01	3.45E-24	1.30E+00

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 161 OF 215

** RESRAD-BUILD Base Program Output, Version 3.3 02/21/06 15:14:05 Page: 18 **
Title : 319 m² Room
Input File : C:\Program Files\RESRAD_Family\BUILD\room+ceiling.bld
Evaluation Time: 0.00000000E+00 years

Nuclide Detail of Doses**[reml]****Source: 1**

Nuclide Receptor	Total
	1
PU-241	
PU-241	1.00E-01
AM-241	5.31E-03
NP-237	7.31E-10
U-233	1.08E-16
TH-229	3.22E-20
AM-241	
AM-241	1.33E-01
NP-237	2.73E-08
U-233	5.36E-15
TH-229	1.99E-18
PU-240	
PU-240	4.63E-02
U-236	1.12E-10
TH-232	2.24E-20
TH-228	1.23E-23
RA-228	1.20E-22
PU-239	
PU-239	4.64E-02
U-235	4.34E-12
PA-231	4.81E-16
AC-227	9.03E-18
PU-238	
PU-238	1.23E-01
U-234	3.53E-08
TH-230	2.45E-13
RA-226	3.41E-17
PB-210	3.34E-19
CS-137	
CS-137	1.05E+01
CS-134	
CS-134	9.29E-03
SR-90	
SR-90	2.57E-01
CO-60	
CO-60	9.60E-01

**TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station**

PAGE 162 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 15:14:05 Page: 19 --
 Title : 319 m² Room
 Input File : C:\Program Files\RESRAD_Family\BUILD\xroomceiling.hld
 Evaluation Time: 0.00000000E+00 years

Source: 2

Nuclide	Receptor	Total
1		
PU-241		
PU-241	3.01E-02	3.01E-02
AM-241	1.58E-03	1.58E-03
NP-237	2.14E-10	2.14E-10
U-233	3.24E-17	3.24E-17
TH-229	9.51E-21	9.51E-21
AM-241		
AM-241	3.96E-02	3.96E-02
NP-237	8.00E-09	8.00E-09
U-233	1.61E-15	1.61E-15
TH-229	5.89E-19	5.89E-19
PU-240		
PU-240	1.39E-02	1.39E-02
U-236	3.35E-11	3.35E-11
TH-232	6.73E-21	6.73E-21
TH-228	2.54E-24	2.54E-24
RA-228	2.44E-23	2.44E-23
PU-239		
PU-239	1.39E-02	1.39E-02
U-235	1.15E-12	1.15E-12
PA-231	1.44E-16	1.44E-16
AC-227	2.69E-18	2.69E-18
PU-238		
PU-238	3.67E-02	3.67E-02
U-234	1.06E-08	1.06E-08
TH-230	7.35E-14	7.35E-14
RA-226	6.17E-18	6.17E-18
PB-210	1.00E-19	1.00E-19
CS-137		
CS-137	1.04E+00	1.04E+00
CS-134		
CS-134	8.35E-04	8.35E-04
SR-90		
SR-90	7.49E-02	7.49E-02
CO-60		
CO-60	8.05E-02	8.05E-02

Source: 3

Nuclide	Receptor	Total
1		
PU-241		
PU-241	3.01E-02	3.01E-02

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 163 OF 215

* NESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 15:14:05 Page: 20 *

Title : 319 m² Room

Input File : C:\Program Files\NESRAD_Family\BUILD\room+ceiling.bld

Evaluation Time: 0.0000000E+00 years

AM-241	1.58E-03	1.58E-03
NP-237	2.14E-10	2.14E-10
U-233	3.24E-17	3.24E-17
TH-229	9.51E-21	9.51E-21
AM-241		
AM-241	3.96E-02	3.96E-02
NP-237	8.00E-09	8.00E-09
U-233	1.61E-15	1.61E-15
TH-229	5.89E-19	5.89E-19
PU-240		
PU-240	1.39E-02	1.39E-02
U-236	3.35E-11	3.35E-11
TH-232	6.73E-21	6.73E-21
TH-228	2.54E-24	2.54E-24
RA-228	2.44E-23	2.44E-23
PU-239		
PU-239	1.39E-02	1.39E-02
U-235	1.15E-12	1.15E-12
RA-231	1.44E-16	1.44E-16
AC-227	2.69E-18	2.69E-18
PU-238		
PU-238	3.67E-02	3.67E-02
U-234	1.06E-08	1.06E-08
TH-230	7.35E-14	7.35E-14
RA-226	6.17E-18	6.17E-18
PB-210	1.00E-19	1.00E-19
CS-137		
CS-137	1.04E+00	1.04E+00
CS-134		
CS-134	8.35E-04	8.35E-04
SR-90		
SR-90	7.49E-02	7.49E-02
CO-60		
CO-60	8.05E-02	8.05E-02

Source: 4

Nuclide Receptor	Total
1	
PU-241	
PU-241	3.01E-02
AM-241	1.58E-03
NP-237	2.14E-10
U-233	3.24E-17
TH-229	9.51E-21
AM-241	
AM-241	3.96E-02
NP-237	8.00E-09
U-233	1.61E-15
TH-229	5.89E-19

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 164 OF 215

** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 15:14:05 Page: 21 **
Title : 319 m² Room
Input File : C:\Program Files\RESRAD_Family\BUILD\room+ceiling.bld
Evaluation Time: 0.000000002+00 years

PU-240		
FU-240	1.39E-02	1.39E-02
U-236	3.35E-11	3.35E-11
IH-232	6.73E-21	6.73E-21
IH-228	2.54E-24	2.54E-24
RA-228	2.44E-23	2.44E-23
PU-239		
FU-239	1.39E-02	1.39E-02
U-235	1.15E-12	1.15E-12
RA-231	1.44E-16	1.44E-16
AC-227	2.69E-18	2.69E-18
PU-238		
FU-238	3.67E-02	3.67E-02
U-234	1.06E-08	1.06E-08
IH-230	7.35E-14	7.35E-14
RA-226	6.17E-18	6.17E-18
PB-210	1.00E-19	1.00E-19
CS-137		
CS-137	1.04E+00	1.04E+00
CS-134		
CS-134	8.35E-04	8.35E-04
SR-90		
SR-90	7.49E-02	7.49E-02
CO-60		
CO-60	8.05E-02	8.05E-02

Source: 5

Nuclide	Receptor	Total
1		
PU-241		
FU-241	3.01E-02	3.01E-02
AM-241	1.58E-03	1.58E-03
NP-237	2.14E-10	2.14E-10
U-233	3.24E-17	3.24E-17
IH-229	9.51E-21	9.51E-21
AM-241		
AM-241	3.96E-02	3.96E-02
NP-237	8.00E-09	8.00E-09
U-233	1.61E-15	1.61E-15
IH-229	5.89E-19	5.89E-19
PU-240		
FU-240	1.39E-02	1.39E-02
U-236	3.35E-11	3.35E-11
IH-232	6.73E-21	6.73E-21
IH-228	2.54E-24	2.54E-24
RA-228	2.44E-23	2.44E-23
PU-239		
FU-239	1.39E-02	1.39E-02
U-235	1.15E-12	1.15E-12

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 165 OF 215

**** RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 15:14:05 Page: 22 ****

Title : 319 m² Room

Input File : C:\Program Files\RESRAD_Family\BUILD\room+ceiling.bld

Evaluation Time: 0.00000000E+00 years

DA-231	1.44E-16	1.44E-16
AC-227	2.69E-18	2.69E-18
PU-238		
PU-238	3.67E-02	3.67E-02
U-234	1.06E-08	1.06E-08
TH-230	7.35E-14	7.35E-14
RA-226	6.17E-18	6.17E-18
PB-210	1.00E-19	1.00E-19
CS-137		
CS-137	1.04E+00	1.04E+00
CS-134		
CS-134	8.35E-04	8.35E-04
SR-90		
SR-90	7.49E-02	7.49E-02
CO-60		
CO-60	8.05E-02	8.05E-02

Source: 6

Nuclide Receptor	Total	
1		
PU-241		
PU-241	1.00E-01	1.00E-01
AM-241	5.29E-03	5.29E-03
NP-237	7.17E-10	7.17E-10
U-233	1.08E-16	1.08E-16
TH-229	3.18E-20	3.18E-20
AM-241		
AM-241	1.32E-01	1.32E-01
NP-237	2.68E-03	2.68E-03
U-233	5.36E-15	5.36E-15
TH-229	1.97E-18	1.97E-18
PU-240		
PU-240	4.63E-02	4.63E-02
U-236	1.12E-10	1.12E-10
TH-232	2.24E-20	2.24E-20
TH-228	9.05E-24	9.05E-24
RA-228	8.74E-23	8.74E-23
PU-239		
PU-239	4.64E-02	4.64E-02
U-235	3.92E-12	3.92E-12
DA-231	4.80E-16	4.80E-16
AC-227	8.97E-18	8.97E-18
PU-238		
PU-238	1.22E-01	1.22E-01
U-234	3.52E-08	3.52E-08
TH-230	2.45E-13	2.45E-13
RA-226	2.27E-17	2.27E-17
PB-210	3.34E-19	3.34E-19
CS-137		

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 166 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 15:14:05 Page: 23 --
Title : 319 m² Room
Input File : C:\Program Files\RESRAD_Family\BUILD\room+ceiling.bld
Evaluation Time: 0.00000000E+00 years

CS-137	4.54E+00	4.54E+00
CS-134		
CS-134	3.79E-03	3.79E-03
SR-90		
SR-90	2.51E-01	2.51E-01
CO-60		
CO-60	3.76E-01	3.76E-01

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 167 OF 215

-- RESRAD-BUILD Dose Program Output, Version 3.3 02/21/06 15:14:05 Page: 24 --

Title : 319 m² Room

Input File : C:\Program Files\RESRAD_Family\BUILD\roomceiling.bld

Full Summary

RESRAD-BUILD Dose (Time) Tables

Receptor Dose Received for the Exposure Duration

(mrem)

Evaluation Time [yr]

0.00E+00

1 2.31E+01

Receptor Dose/Yr Averaged Over Exposure Duration

(mrem/yr)

Evaluation Time [yr]

0.00E+00

1 2.31E+01

Attachment 8.3

Microshield Runs and Resulting Area Factors

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 169 OF 215

Structure Surface Area Factors

Area Factors for 137 m² Survey Unit

Dose Rate	Area Factor	Area m ²	Area Radius, m
6.93E-03	1.00E+00	137	6.91
6.23E-03	1.11E+00	100	5.64
5.74E-03	1.21E+00	75	4.89
5.05E-03	1.37E+00	50	3.99
3.92E-03	1.77E+00	25	2.82
3.14E-03	2.21E+00	15	2.19
2.55E-03	2.72E+00	10	1.78
1.70E-03	4.08E+00	5	1.26
4.88E-04	1.42E+01	1	0.56
2.65E-04	2.62E+01	0.5	0.40

Area Factors for 319 m² Survey Unit

Dose Rate	Area Factor	Area m ²	Area Radius, m
8.22E-03	1.00E+00	319	10.08
7.82E-03	1.05 E+00	250	8.92
7.44E-03	1.11 E+00	200	7.98
6.93E-03	1.19 E+00	150	6.91
6.23E-03	1.32 E+00	100	5.64
5.74E-03	1.43 E+00	75	4.89
5.05E-03	1.63 E+00	50	3.99
3.92E-03	2.10 E+00	25	2.82
3.14E-03	2.62E+00	15	2.19
2.55E-03	3.22E+00	10	1.78
1.70E-03	4.84E+00	5	1.26
4.88E-04	1.68 E+01	1	0.56
2.65E-04	3.10E+01	0.5	0.40

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 170 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District

Page : 1
DOS File : Case1
Run Date: February 21, 2006
Run Time: 11:53:16 AM
Duration : 00:00:00

File Ref: _____
Date: _____
By: _____
Checked: _____

Total
Case Title: 137 m² at Gross DCGL
Description: Case 1 *2/21/06*
Geometry: 3 - Disk



Source Dimensions
Radius 691.0 cm 22 ft 8.0 in

Dose Points
#1 X 100 cm Y 0 cm Z 0 cm
3 ft 3.4 in 0.0 in 0.0 in

Shields			
<u>Shield Name</u>	<u>Material</u>	<u>Density</u>	
Air Gap	Air	0.00122	

Source Input
Grouping Method : Standard Indices

Number of Groups : 25

Lower Energy Cutoff : 0.015

Photons < 0.015 : Excluded

Library : Grove

<u>Nuclide</u>	<u>curies</u>	<u>becquerels</u>	<u>µCi/cm²</u>	<u>Bq/cm²</u>
Am-241	3.2251e-007	1.1933e+004	2.1500e-007	7.9550e-003
Ba-137m	2.4408e-004	9.0308e+006	1.6271e-004	6.0203e+000
Co-60	6.3602e-006	2.3533e+005	4.2400e-006	1.5688e-001
Cs-134	1.0110e-007	3.7408e+003	6.7400e-008	2.4938e-003
Cs-137	2.5801e-004	9.5463e+006	1.7200e-004	6.3640e+000
Pu-238	3.6001e-007	1.3320e+004	2.4000e-007	8.8800e-003
Pu-239	1.1460e-007	4.2403e+003	7.6400e-008	2.8268e-003
Pu-240	1.1460e-007	4.2403e+003	7.6400e-008	2.8268e-003
Pu-241	1.6351e-005	6.0497e+005	1.0900e-005	4.0330e-001
Sr-90	3.2251e-007	1.1933e+004	2.1500e-007	7.9550e-003
Y-90	3.2251e-007	1.1933e+004	2.1500e-007	7.9550e-003

Buildup
The material reference is : Air Gap

Integration Parameters

Radial	20
Circumferential	20

Results

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
 at Rancho Seco Nuclear Generating Station

PAGE 171 OF 215

Page : 2

DOS File : Case1

Run Date: February 21, 2006

Run Time: 11:53:16 AM

Duration : 00:00:00

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Exposure Rate</u> <u>mR/hr</u>	<u>Exposure Rate</u> <u>mR/hr</u>
		<u>No Buildup</u>	<u>With Buildup</u>	<u>No Buildup</u>	<u>With Buildup</u>
0.03	5.322e+05	9.175e-03	1.051e-02	9.093e-05	1.042e-04
0.04	1.255e+05	2.986e-03	3.421e-03	1.320e-05	1.513e-05
0.05	2.225e+00	6.698e-08	7.657e-08	1.784e-10	2.040e-10
0.06	4.312e+03	1.568e-04	1.781e-04	3.114e-07	3.537e-07
0.1	2.018e+00	1.236e-07	1.361e-07	1.890e-10	2.082e-10
0.3	1.324e+00	2.473e-07	2.586e-07	4.692e-10	4.905e-10
0.5	5.462e+01	1.712e-05	1.765e-05	3.361e-08	3.465e-08
0.6	8.131e+06	3.066e+00	3.149e+00	5.985e-03	6.147e-03
0.8	3.521e+03	1.777e-03	1.816e-03	3.380e-06	3.453e-06
1.0	2.354e+05	1.489e-01	1.517e-01	2.745e-04	2.796e-04
1.5	2.354e+05	2.244e-01	2.274e-01	3.775e-04	3.827e-04
TOTALS:	9.267e+06	3.454e+00	3.544e+00	6.745e-03	6.933e-03


TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 172 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District

Page : 1
DOS File : Case1
Run Date: February 21, 2006
Run Time: 11:54:41 AM
Duration : 00:00:00

File Ref: _____
Date: _____
By: _____
Checked: _____

Case Title: 137 m² at Gross DCGL**Description: Case 1****Geometry: 3 - Disk**

Source Dimensions		
Radius	564.0 cm	18 ft 6.0 in

Dose Points			
#	X	Y	Z
1	100 cm 3 ft 3.4 in	0 cm 0.0 in	0 cm 0.0 in

Shields		
<u>Shield Name</u>	<u>Material</u>	<u>Density</u>
Air Gap	Air	0.00122

Source Input**Grouping Method : Standard Indices****Number of Groups : 25****Lower Energy Cutoff : 0.015****Photons < 0.015 : Excluded****Library : Grove**

<u>Nuclide</u>	<u>curies</u>	<u>becquerels</u>	<u>$\mu\text{Ci}/\text{cm}^2$</u>	<u>Bq/cm²</u>
Am-241	2.1486e-007	7.9497e+003	2.1500e-007	7.9550e-003
Ba-137m	1.6260e-004	6.0163e+006	1.6271e-004	6.0203e+000
Co-60	4.2372e-006	1.5677e+005	4.2400e-006	1.5688e-001
Cs-134	6.7355e-008	2.4921e+003	6.7400e-008	2.4938e-003
Cs-137	1.7188e-004	6.3597e+006	1.7200e-004	6.3640e+000
Pu-238	2.3984e-007	8.8740e+003	2.4000e-007	8.8800e-003
Pu-239	7.6349e-008	2.8249e+003	7.6400e-008	2.8268e-003
Pu-240	7.6349e-008	2.8249e+003	7.6400e-008	2.8268e-003
Pu-241	1.0893e-005	4.0303e+005	1.0900e-005	4.0330e-001
Sr-90	2.1486e-007	7.9497e+003	2.1500e-007	7.9550e-003
Y-90	2.1486e-007	7.9497e+003	2.1500e-007	7.9550e-003

Buildup**The material reference is : Air Gap****Integration Parameters**

Radial	20
Circumferential	20

Results

Page : 2

DOS File : Case1

Run Date : February 21, 2006

Run Time: 11:54:41 AM

Duration : 00:00:00

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Fluence Rate</u>	<u>Exposure Rate</u>	<u>Exposure Rate</u>
			<u>No Buildup</u>	<u>With Buildup</u>	<u>mR/hr</u>
0.03	3.546e+05	8.355e-03	9.421e-03	8.281e-05	9.336e-05
0.04	8.363e+04	2.708e-03	3.054e-03	1.198e-05	1.350e-05
0.05	1.482e+00	6.068e-08	6.826e-08	1.616e-10	1.818e-10
0.06	2.872e+03	1.419e-04	1.587e-04	2.819e-07	3.153e-07
0.1	1.344e+00	1.117e-07	1.216e-07	1.709e-10	1.861e-10
0.3	8.822e-01	2.232e-07	2.321e-07	4.233e-10	4.403e-10
0.5	3.639e+01	1.544e-05	1.586e-05	3.030e-08	3.113e-08
0.6	5.417e+06	2.764e+00	2.830e+00	5.395e-03	5.523e-03
0.8	2.346e+03	1.601e-03	1.632e-03	3.045e-06	3.103e-06
1.0	1.568e+05	1.341e-01	1.363e-01	2.472e-04	2.513e-04
1.5	1.569e+05	2.020e-01	2.044e-01	3.398e-04	3.439e-04
TOTALS:	6.174e+06	3.113e+00	3.185e+00	6.080e-03	6.229e-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 174 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District

Page : 1
DOS File : Case1
Run Date: February 21, 2006
Run Time: 11:55:04 AM
Duration : 00:00:00

File Ref: _____
Date: _____
By: _____
Checked: _____

Case Title: 137 m² at Gross DCGL
Description: Case 1
Geometry: 3 - Disk



Source Dimensions
Radius 489.0 cm 16 ft 0.5 in

Dose Points
1 X 100 cm Y 0 cm Z 0 cm
3 ft 3.4 in 0.0 in 0.0 in

Shields		
<u>Shield Name</u>	<u>Material</u>	<u>Density</u>
Air Gap	Air	0.00122

Source Input
Grouping Method : Standard Indices

Number of Groups : 25

Lower Energy Cutoff : 0.015

Photons < 0.015 : Excluded

Library : Groves

<u>Nuclide</u>	<u>curies</u>	<u>becquerels</u>	<u>µCi/cm²</u>	<u>Bq/cm²</u>
Am-241	1.6151e-007	5.9760e+003	2.1500e-007	7.9550e-003
Ba-137m	1.2223e-004	4.5226e+006	1.6271e-004	6.0203e+000
Co-60	3.1852e-006	1.1785e+005	4.2400e-006	1.5688e-001
Cs-134	5.0632e-008	1.8734e+003	6.7400e-008	2.4938e-003
Cs-137	1.2921e-004	4.7808e+006	1.7200e-004	6.3640e+000
Pu-238	1.8029e-007	6.6708e+003	2.4000e-007	8.8800e-003
Pu-239	5.7393e-008	2.1236e+003	7.6400e-008	2.8268e-003
Pu-240	5.7393e-008	2.1236e+003	7.6400e-008	2.8268e-003
Pu-241	8.1883e-006	3.0297e+005	1.0900e-005	4.0330e-001
Sr-90	1.6151e-007	5.9760e+003	2.1500e-007	7.9550e-003
Y-90	1.6151e-007	5.9760e+003	2.1500e-007	7.9550e-003

Buildup
The material reference is : Air Gap

Integration Parameters

Radial	20
Circumferential	20

Results

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 175 OF 215

Page : 2
DOS File : Case1
Run Date: February 21, 2006
Run Time: 11:55:04 AM
Duration : 00:00:00

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Exposure Rate</u> <u>mR/hr</u>	<u>Exposure Rate</u> <u>mR/hr</u>
		<u>No Buildup</u>	<u>With Buildup</u>	<u>No Buildup</u>	<u>With Buildup</u>
0.03	2.665e+05	7.762e-03	8.667e-03	7.693e-05	8.590e-05
0.04	6.287e+04	2.510e-03	2.802e-03	1.110e-05	1.239e-05
0.05	1.114e+00	5.619e-08	6.259e-08	1.497e-10	1.667e-10
0.06	2.159e+03	1.313e-04	1.456e-04	2.609e-07	2.891e-07
0.1	1.010e+00	1.033e-07	1.117e-07	1.581e-10	1.709e-10
0.3	6.632e-01	2.062e-07	2.137e-07	3.911e-10	4.054e-10
0.5	2.735e+01	1.425e-05	1.461e-05	2.798e-08	2.868e-08
0.6	4.072e+06	2.551e+00	2.607e+00	4.980e-03	5.089e-03
0.8	1.763e+03	1.478e-03	1.503e-03	2.811e-06	2.860e-06
1.0	1.179e+05	1.238e-01	1.256e-01	2.281e-04	2.315e-04
1.5	1.179e+05	1.863e-01	1.884e-01	3.135e-04	3.169e-04
TOTALS:	4.641e+06	2.873e+00	2.934e+00	5.613e-03	5.739e-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 176 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District

Page : 1
DOS File : Case1
Run Date: February 21, 2006
Run Time: 11:55:26 AM
Duration : 00:00:00

File Ref: _____
Date: _____
By: _____
Checked: _____

Case Title: 137 m² at Gross DCGL

Description: Case 1

Geometry: 3 - Disk



Source Dimensions
Radius 399.0 cm 13 ft 1.1 in

Dose Points
#1 X 100 cm Y 0 cm Z 0 cm
3 ft 3.4 in 0.0 in 0.0 in

Shield Name	Material	Density
Air Gap	Air	0.00122

Source Input**Grouping Method : Standard Indices****Number of Groups : 25****Lower Energy Cutoff : 0.015****Photons < 0.015 : Excluded****Library : Grove**

Nuclide	curies	becquerels	$\mu\text{Ci}/\text{cm}^2$	Bq/cm^2
Am-241	1.0753e-007	3.9787e+003	2.1500e-007	7.9550e-003
Ba-137m	8.1380e-005	3.0110e+006	1.6271e-004	6.0203e+000
Co-60	2.1206e-006	7.8463e+004	4.2400e-006	1.5688e-001
Cs-134	3.3710e-008	1.2473e+003	6.7400e-008	2.4938e-003
Cs-137	8.6025e-005	3.1829e+006	1.7200e-004	6.3640e+000
Pu-238	1.2003e-007	4.4413e+003	2.4000e-007	8.8800e-003
Pu-239	3.8211e-008	1.4138e+003	7.6400e-008	2.8268e-003
Pu-240	3.8211e-008	1.4138e+003	7.6400e-008	2.8268e-003
Pu-241	5.4516e-006	2.0171e+005	1.0900e-005	4.0330e-001
Sr-90	1.0753e-007	3.9787e+003	2.1500e-007	7.9550e-003
Y-90	1.0753e-007	3.9787e+003	2.1500e-007	7.9550e-003

Buildup

The material reference is : Air Gap

Integration Parameters

Radial	20
Circumferential	20

Results

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 177 OF 215

Page : 2

DOS File : Case1

Run Date: February 21, 2006

Run Time: 11:55:26 AM

Duration : 00:00:00

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Exposure Rate</u> <u>mR/hr</u>	<u>Exposure Rate</u> <u>mR/hr</u>
0.03	1.775e+05	6.902e-03	7.613e-03	6.841e-05	7.545e-05
0.04	4.186e+04	2.225e-03	2.454e-03	9.842e-06	1.085e-05
0.05	7.418e-01	4.975e-08	5.475e-08	1.325e-10	1.459e-10
0.06	1.438e+03	1.162e-04	1.273e-04	2.309e-07	2.529e-07
0.1	6.727e-01	9.135e-08	9.789e-08	1.398e-10	1.498e-10
0.3	4.415e-01	1.820e-07	1.879e-07	3.453e-10	3.565e-10
0.5	1.821e+01	1.258e-05	1.286e-05	2.469e-08	2.523e-08
0.6	2.711e+06	2.251e+00	2.294e+00	4.393e-03	4.478e-03
0.8	1.174e+03	1.303e-03	1.323e-03	2.478e-06	2.517e-06
1.0	7.850e+04	1.091e-01	1.105e-01	2.011e-04	2.038e-04
1.5	7.850e+04	1.642e-01	1.658e-01	2.762e-04	2.789e-04
TOTALS:	3.090e+06	2.534e+00	2.582e+00	4.951e-03	5.050e-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys at Rancho Seco Nuclear Generating Station

PAGE 178 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District

Page : 1
DOS File : Case1
Run Date: February 21, 2006
Run Time: 11:55:45 AM
Duration : 00:00:00

File Ref: _____
Date: _____
By: _____
Checked: _____

Case Title: 137 m² at Gross DCGL

Description: Case 1

Geometry: 3 - Disk



Source Dimensions

Dose Points			
#	X	Y	Z
1	100 cm 3 ft 3.4 in	0 cm 0.0 in	0 cm 0.0 in

<u>Shield Name</u>	<u>Shields</u>	<u>Material</u>	<u>Density</u>
Air Gap		Air	0.00122

Source Input

Grouping Method : Standard Indices

Number of Groups : 25

Lower Energy Cutoff : 0.015

Photons < 0.015 : Excluded

Library : Grove

<u>Nuclide</u>	<u>curies</u>	<u>becquerels</u>	<u>uCi/cm²</u>	<u>Bq/cm²</u>
Am-241	5.3714e-008	1.9874e+003	2.1500e-007	7.9550e-003
Ba-137m	4.0651e-005	1.5041e+006	1.6271e-004	6.0203e+000
Co-60	1.0593e-006	3.9194e+004	4.2400e-006	1.5688e-001
Cs-134	1.6839e-008	6.2303e+002	6.7400e-008	2.4938e-003
Cs-137	4.2971e-005	1.5899e+006	1.7200e-004	6.3640e+000
Pu-238	5.9960e-008	2.2185e+003	2.4000e-007	8.8800e-003
Pu-239	1.9087e-008	7.0623e+002	7.6400e-008	2.8268e-003
Pu-240	1.9087e-008	7.0623e+002	7.6400e-008	2.8268e-003
Pu-241	2.7232e-006	1.0076e+005	1.0900e-005	4.0330e-001
Sr-90	5.3714e-008	1.9874e+003	2.1500e-007	7.9550e-003
Y-90	5.3714e-008	1.9874e+003	2.1500e-007	7.9550e-003

Buildup

The material reference is : Air Gap

Integration Parameters

	Integration Parameters
Radial	20
Circumferential	20

Results

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 179 OF 215

Page : 2

DOS File : Case1

Run Date: February 21, 2006

Run Time: 11:55:45 AM

Duration : 00:00:00

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Exposure Rate</u> <u>mR/hr</u>	<u>Exposure Rate</u> <u>mR/hr</u>
		<u>No Buildup</u>	<u>With Buildup</u>	<u>No Buildup</u>	<u>With Buildup</u>
0.03	8.864e+04	5.429e-03	5.888e-03	5.380e-05	5.835e-05
0.04	2.091e+04	1.743e-03	1.889e-03	7.708e-06	8.356e-06
0.05	3.705e-01	3.891e-08	4.211e-08	1.036e-10	1.122e-10
0.06	7.181e+02	9.083e-05	9.793e-05	1.804e-07	1.945e-07
0.1	3.360e-01	7.129e-08	7.548e-08	1.091e-10	1.155e-10
0.3	2.206e-01	1.418e-07	1.455e-07	2.689e-10	2.761e-10
0.5	9.096e+00	9.786e-06	9.964e-06	1.921e-08	1.956e-08
0.6	1.354e+06	1.751e+00	1.779e+00	3.417e-03	3.472e-03
0.8	5.865e+02	1.013e-03	1.026e-03	1.927e-06	1.952e-06
1.0	3.921e+04	8.480e-02	8.573e-02	1.563e-04	1.580e-04
1.5	3.921e+04	1.275e-01	1.286e-01	2.146e-04	2.163e-04
TOTALS:	1.543e+06	1.971e+00	2.002e+00	3.852e-03	3.915e-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 180 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District

Page : 1
DOS File : Case1
Run Date: February 21, 2006
Run Time: 11:56:05 AM
Duration : 00:00:00

File Ref: _____
Date: _____
By: _____
Checked: _____

Case Title: 137 m² at Gross DCGL
Description: Case 1
Geometry: 3 - Disk



Source Dimensions
Radius 219.0 cm 7 ft 2.2 in

Dose Points
1 X 100 cm Y 0 cm Z 0 cm
3 ft 3.4 in 0.0 in 0.0 in

Shields
Shield Name Material Density
Air Gap Air 0.00122

Source Input
Grouping Method : Standard Indices

Number of Groups : 25

Lower Energy Cutoff : 0.015

Photons < 0.015 : Excluded

Library : Grove

<u>Nuclide</u>	<u>curies</u>	<u>becquerels</u>	<u>$\mu\text{Ci}/\text{cm}^2$</u>	<u>Bq/cm²</u>
Am-241	3.2395e-008	1.1986e+003	2.1500e-007	7.9550e-003
Ba-137m	2.4516e-005	9.0711e+005	1.6271e-004	6.0203e+000
Co-60	6.3886e-007	2.3638e+004	4.2400e-006	1.5688e-001
Cs-134	1.0155e-008	3.7575e+002	6.7400e-008	2.4938e-003
Cs-137	2.5916e-005	9.5889e+005	1.7200e-004	6.3640e+000
Pu-238	3.6162e-008	1.3380e+003	2.4000e-007	8.8800e-003
Pu-239	1.1511e-008	4.2593e+002	7.6400e-008	2.8268e-003
Pu-240	1.1511e-008	4.2593e+002	7.6400e-008	2.8268e-003
Pu-241	1.6423e-006	6.0767e+004	1.0900e-005	4.0330e-001
Sr-90	3.2395e-008	1.1986e+003	2.1500e-007	7.9550e-003
Y-90	3.2395e-008	1.1986e+003	2.1500e-007	7.9550e-003

Buildup
The material reference is : Air Gap

Integration Parameters

Radial	20
Circumferential	20

Results

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 181 OF 215

Page : 2

DOS File : Case1

Run Date : February 21, 2006

Run Time: 11:56:05 AM

Duration : 00:00:00

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u>		<u>Exposure Rate</u>	
		<u>MeV/cm²/sec</u> <u>No Buildup</u>	<u>MeV/cm²/sec</u> <u>With Buildup</u>	<u>mR/hr</u> <u>No Buildup</u>	<u>mR/hr</u> <u>With Buildup</u>
0.03	5.346e+04	4.389e-03	4.715e-03	4.350e-05	4.673e-05
0.04	1.261e+04	1.406e-03	1.509e-03	6.217e-06	6.676e-06
0.05	2.235e-01	3.135e-08	3.361e-08	8.352e-11	8.955e-11
0.06	4.331e+02	7.316e-05	7.818e-05	1.453e-07	1.553e-07
0.1	2.027e-01	5.737e-08	6.034e-08	8.777e-11	9.231e-11
0.3	1.330e-01	1.140e-07	1.166e-07	2.162e-10	2.212e-10
0.5	5.486e+00	7.863e-06	7.989e-06	1.543e-08	1.568e-08
0.6	8.167e+05	1.406e+00	1.426e+00	2.745e-03	2.784e-03
0.8	3.537e+02	8.137e-04	8.228e-04	1.548e-06	1.565e-06
1.0	2.365e+04	6.810e-02	6.875e-02	1.255e-04	1.267e-04
1.5	2.365e+04	1.024e-01	1.031e-01	1.723e-04	1.735e-04
TOTALS:	9.308e+05	1.584e+00	1.605e+00	3.094e-03	3.139e-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station


PAGE 182 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District

Page : 1
DOS File : Case1
Run Date: February 21, 2006
Run Time: 11:56:26 AM
Duration : 00:00:00

File Ref: _____
Date: _____
By: _____
Checked: _____

Case Title: 137 m² at Gross DCGL
Description: Case 1
Geometry: 3 - Disk



Source Dimensions
Radius 178.0 cm 5 ft 10.1 in

Dose Points			
#	X	Y	Z
1	100 cm 3 ft 3.4 in	0 cm 0.0 in	0 cm 0.0 in

Shields			
<u>Shield Name</u>	<u>Material</u>	<u>Density</u>	
Air Gap	Air	0.00122	

Source Input
Grouping Method : Standard Indices

Number of Groups : 25

Lower Energy Cutoff : 0.015

Photons < 0.015 : Excluded

Library : Grove

<u>Nuclide</u>	<u>curies</u>	<u>becquerels</u>	<u>$\mu\text{Ci}/\text{cm}^2$</u>	<u>Bq/cm^2</u>
Am-241	2.1401e-008	7.9183e+002	2.1500e-007	7.9550e-003
Ba-137m	1.6196e-005	5.9925e+005	1.6271e-004	6.0203e+000
Co-60	4.2204e-007	1.5616e+004	4.2400e-006	1.5688e-001
Cs-134	6.7089e-009	2.4823e+002	6.7400e-008	2.4938e-003
Cs-137	1.7121e-005	6.3346e+005	1.7200e-004	6.3640e+000
Pu-238	2.3889e-008	8.8390e+002	2.4000e-007	8.8800e-003
Pu-239	7.6047e-009	2.8137e+002	7.6400e-008	2.8268e-003
Pu-240	7.6047e-009	2.8137e+002	7.6400e-008	2.8268e-003
Pu-241	1.0850e-006	4.0144e+004	1.0900e-005	4.0330e-001
Sr-90	2.1401e-008	7.9183e+002	2.1500e-007	7.9550e-003
Y-90	2.1401e-008	7.9183e+002	2.1500e-007	7.9550e-003

Buildup
The material reference is : Air Gap

Integration Parameters

Radial	20
Circumferential	20

Results

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 183 OF 215

Page : 2

DOS File : Case1

Run Date: February 21, 2006

Run Time: 11:56:26 AM

Duration : 00:00:00

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Exposure Rate</u> <u>mR/hr</u>	<u>Exposure Rate</u> <u>mR/hr</u>
		<u>No Buildup</u>	<u>With Buildup</u>	<u>No Buildup</u>	<u>With Buildup</u>
0.03	3.532e+04	3.586e-03	3.828e-03	3.554e-05	3.793e-05
0.04	8.330e+03	1.147e-03	1.223e-03	5.071e-06	5.411e-06
0.05	1.476e-01	2.556e-08	2.723e-08	6.808e-11	7.254e-11
0.06	2.861e+02	5.962e-05	6.333e-05	1.184e-07	1.258e-07
0.1	1.339e-01	4.673e-08	4.893e-08	7.149e-11	7.485e-11
0.3	8.787e-02	9.275e-08	9.473e-08	1.759e-10	1.797e-10
0.5	3.624e+00	6.397e-06	6.491e-06	1.256e-08	1.274e-08
0.6	5.395e+05	1.144e+00	1.159e+00	2.233e-03	2.262e-03
0.8	2.337e+02	6.618e-04	6.686e-04	1.259e-06	1.272e-06
1.0	1.562e+04	5.538e-02	5.587e-02	1.021e-04	1.030e-04
1.5	1.562e+04	8.325e-02	8.379e-02	1.401e-04	1.410e-04
TOTALS:	6.149e+05	1.288e+00	1.304e+00	2.517e-03	2.551e-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 184 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District


Page : 1
DOS File : Case1
Run Date: February 21, 2006
Run Time: 11:56:43 AM
Duration : 00:00:00

File Ref: _____
Date: _____
By: _____
Checked: _____

Case Title: 137 m² at Gross DCGL

Description: Case 1

Geometry: 3 - Disk



Source Dimensions
Radius 126.0 cm 4 ft 1.6 in

Dose Points			
#	X	Y	Z
1	100 cm 3 ft 3.4 in	0 cm 0.0 in	0 cm 0.0 in

Shields		
<u>Shield Name</u>	<u>Material</u>	<u>Density</u>
Air Gap	Air	0.00122

Source Input

Grouping Method : Standard Indices

Number of Groups : 25

Lower Energy Cutoff : 0.015

Photons < 0.015 : Excluded

Library : Grove

<u>Nuclide</u>	<u>curies</u>	<u>becquerels</u>	<u>μCi/cm²</u>	<u>Bq/cm²</u>
Am-241	1.0723e-008	3.9676e+002	2.1500e-007	7.9550e-003
Ba-137m	8.1154e-006	3.0027e+005	1.6271e-004	6.0203e+000
Co-60	2.1147e-007	7.8245e+003	4.2400e-006	1.5688e-001
Cs-134	3.3616e-009	1.2438e+002	6.7400e-008	2.4938e-003
Cs-137	8.5787e-006	3.1741e+005	1.7200e-004	6.3640e+000
Pu-238	1.1970e-008	4.4290e+002	2.4000e-007	8.8800e-003
Pu-239	3.8105e-009	1.4099e+002	7.6400e-008	2.8268e-003
Pu-240	3.8105e-009	1.4099e+002	7.6400e-008	2.8268e-003
Pu-241	5.4365e-007	2.0115e+004	1.0900e-005	4.0330e-001
Sr-90	1.0723e-008	3.9676e+002	2.1500e-007	7.9550e-003
Y-90	1.0723e-008	3.9676e+002	2.1500e-007	7.9550e-003

Buildup

The material reference is : Air Gap

Integration Parameters

Radial	20
Circumferential	20

Results

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 185 OF 215

Page : 2

DOS File : Case1

Run Date: February 21, 2006

Run Time: 11:56:43 AM

Duration : 00:00:00

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Exposure Rate</u> <u>mR/hr</u>	<u>Exposure Rate</u> <u>mR/hr</u>
0.03	1.770e+04	2.405e-03	2.547e-03	2.383e-05	2.524e-05
0.04	4.174e+03	7.674e-04	8.124e-04	3.394e-06	3.593e-06
0.05	7.397e-02	1.709e-08	1.807e-08	4.553e-11	4.814e-11
0.06	1.434e+02	3.986e-05	4.203e-05	7.917e-08	8.348e-08
0.1	6.709e-02	3.123e-08	3.251e-08	4.777e-11	4.974e-11
0.3	4.403e-02	6.191e-08	6.307e-08	1.174e-10	1.196e-10
0.5	1.816e+00	4.269e-06	4.323e-06	8.379e-09	8.486e-09
0.6	2.703e+05	7.633e-01	7.719e-01	1.490e-03	1.507e-03
0.8	1.171e+02	4.415e-04	4.454e-04	8.397e-07	8.472e-07
1.0	7.828e+03	3.694e-02	3.722e-02	6.808e-05	6.861e-05
1.5	7.828e+03	5.551e-02	5.582e-02	9.339e-05	9.392e-05
TOTALS:	3.081e+05	8.594e-01	8.688e-01	1.680e-03	1.699e-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station


PAGE 186 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District

Page : 1
DOS File : Case1
Run Date: February 21, 2006
Run Time: 11:56:59 AM
Duration : 00:00:00

File Ref: _____
Date: _____
By: _____
Checked: _____

Case Title: 137 m² at Gross DCGL
Description: Case 1
Geometry: 3 - Disk



Source Dimensions
Radius 56.0 cm 1 ft 10.0 in

Dose Points
1 X Y Z
 100 cm 0 cm 0 cm
 3 ft 3.4 in 0.0 in 0.0 in

Shields		
<u>Shield Name</u>	<u>Material</u>	<u>Density</u>
Air Gap	Air	0.00122

Source Input
Grouping Method : Standard Indices

Number of Groups : 25

Lower Energy Cutoff : 0.015

Photons < 0.015 : Excluded

Library : Grove

<u>Nuclide</u>	<u>Curies</u>	<u>becquerels</u>	<u>µCi/cm²</u>	<u>Bq/cm²</u>
Am-241	2.1182e-009	7.8373e+001	2.1500e-007	7.9550e-003
Ba-137m	1.6030e-006	5.9313e+004	1.6271e-004	6.0203e+000
Co-60	4.1773e-008	1.5456e+003	4.2400e-006	1.5688e-001
Cs-134	6.6403e-010	2.4569e+001	6.7400e-008	2.4938e-003
Cs-137	1.6945e-006	6.2698e+004	1.7200e-004	6.3640e+000
Pu-238	2.3645e-009	8.7486e+001	2.4000e-007	8.8800e-003
Pu-239	7.5270e-010	2.7850e+001	7.6400e-008	2.8268e-003
Pu-240	7.5270e-010	2.7850e+001	7.6400e-008	2.8268e-003
Pu-241	1.0739e-007	3.9733e+003	1.0900e-005	4.0330e-001
Sr-90	2.1182e-009	7.8373e+001	2.1500e-007	7.9550e-003
Y-90	2.1182e-009	7.8373e+001	2.1500e-007	7.9550e-003

Builddup
The material reference is : Air Gap

Integration Parameters

Radial	20
Circumferential	20

Results

Page : 2
 DOS File : Case1.
 Run Date: February 21, 2006
 Run Time: 11:56:59 AM
 Duration : 00:00:00

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Exposure Rate</u> <u>mR/hr</u>	<u>Exposure Rate</u> <u>mR/hr</u>
		<u>No Buildup</u>	<u>With Buildup</u>	<u>No Buildup</u>	<u>With Buildup</u>
0.03	3.496e+03	6.957e-04	7.299e-04	6.895e-06	7.234e-06
0.04	8.245e+02	2.215e-04	2.323e-04	9.795e-07	1.027e-06
0.05	1.461e-02	4.929e-09	5.164e-09	1.313e-11	1.376e-11
0.06	2.832e+01	1.149e-05	1.201e-05	2.282e-08	2.385e-08
0.1	1.325e-02	8.993e-09	9.302e-09	1.376e-11	1.423e-11
0.3	8.697e-03	1.781e-08	1.809e-08	3.379e-11	3.432e-11
0.5	3.587e-01	1.227e-06	1.241e-06	2.409e-09	2.435e-09
0.6	5.340e+04	2.195e-01	2.215e-01	4.283e-04	4.324e-04
0.8	2.313e+01	1.269e-04	1.278e-04	2.413e-07	2.432e-07
1.0	1.546e+03	1.061e-02	1.068e-02	1.957e-05	1.969e-05
1.5	1.546e+03	1.595e-02	1.602e-02	2.683e-05	2.696e-05
TOTALS:	6.086e+04	2.471e-01	2.493e-01	4.829e-04	4.875e-04


TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 188 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District

Page : 1
 DOS File : Case1
 Run Date: February 21, 2006
 Run Time: 11:57:16 AM
 Duration : 00:00:00

File Ref: _____
 Date: _____
 By: _____
 Checked: _____

Case Title: 137 m² at Gross DCGL**Description: Case 1****Geometry: 3 - Disk**

		Source Dimensions	
	Radius	40.0 cm	1 ft 3.7 in

Dose Points

# 1	X 100 cm 3 ft 3.4 in	Y 0 cm 0.0 in	Z 0 cm 0.0 in
-----	----------------------------	---------------------	---------------------

Shields			
<u>Shield Name</u>	<u>Material</u>	<u>Density</u>	
Air Gap	Air	0.00122	

Source Input**Grouping Method : Standard Indices****Number of Groups : 25****Lower Energy Cutoff : 0.015****Photons < 0.015 : Excluded****Library : Grove**

<u>Nuclide</u>	<u>curies</u>	<u>becquerels</u>	<u>$\mu\text{Ci}/\text{cm}^2$</u>	<u>Bq/cm^2</u>
Am-241	1.0807e-009	3.9986e+001	2.1500e-007	7.9550e-003
Ba-137m	8.1788e-007	3.0262e+004	1.6271e-004	6.0203e+000
Co-60	2.1313e-008	7.8856e+002	4.2400e-006	1.5688e-001
Cs-134	3.3879e-010	1.2535e+001	6.7400e-008	2.4938e-003
Cs-137	8.6457e-007	3.1989e+004	1.7200e-004	6.3640e+000
Pu-238	1.2064e-009	4.4636e+001	2.4000e-007	8.8800e-003
Pu-239	3.8403e-010	1.4209e+001	7.6400e-008	2.8268e-003
Pu-240	3.8403e-010	1.4209e+001	7.6400e-008	2.8268e-003
Pu-241	5.4789e-008	2.0272e+003	1.0900e-005	4.0330e-001
Sr-90	1.0807e-009	3.9986e+001	2.1500e-007	7.9550e-003
Y-90	1.0807e-009	3.9986e+001	2.1500e-007	7.9550e-003

Buildup**The material reference is : Air Gap****Integration Parameters**

Radial	20
Circumferential	20

Results

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 189 OF 215

Page : 2

DOS File : Case1

Run Date: February 21, 2006

Run Time: 11:57:16 AM

Duration : 00:00:00

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Exposure Rate</u> <u>mR/hr</u>	<u>Exposure Rate</u> <u>mR/hr</u>
		<u>No Buildup</u>	<u>With Buildup</u>	<u>No Buildup</u>	<u>With Buildup</u>
0.03	1.783e+03	3.790e-04	3.971e-04	3.757e-06	3.935e-06
0.04	4.207e+02	1.206e-04	1.263e-04	5.335e-07	5.587e-07
0.05	7.455e-03	2.684e-09	2.808e-09	7.150e-12	7.480e-12
0.06	1.445e+01	6.256e-06	6.530e-06	1.243e-08	1.297e-08
0.1	6.761e-03	4.896e-09	5.059e-09	7.491e-12	7.740e-12
0.3	4.437e-03	9.696e-09	9.843e-09	1.839e-11	1.867e-11
0.5	1.830e-01	6.681e-07	6.750e-07	1.311e-09	1.325e-09
0.6	2.724e+04	1.194e-01	1.205e-01	2.331e-04	2.353e-04
0.8	1.180e+01	6.906e-05	6.956e-05	1.314e-07	1.323e-07
1.0	7.889e+02	5.777e-03	5.813e-03	1.065e-05	1.071e-05
1.5	7.889e+02	8.679e-03	8.719e-03	1.460e-05	1.467e-05
TOTALS:	3.105e+04	1.345e-01	1.357e-01	2.628e-04	2.653e-04

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 190 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District

Page : 1
DOS File : Case1
Run Date: February 21, 2006
Run Time: 11:59:58 AM
Duration : 00:00:00

File Ref: _____
Date: _____
By: _____
Checked: _____

Total
Case Title: 319 m² at Gress DCGL
Description: Case 1
Geometry: 3 - Disk



Source Dimensions		
Radius	1.0e+3 cm	32 ft 9.7 in

Dose Points			
#	X 100 cm 3 ft 3.4 in	Y 0 cm 0.0 in	Z 0 cm 0.0 in
1	100 cm 3 ft 3.4 in	0 cm 0.0 in	0 cm 0.0 in

Shields		
Shield Name	Material	Density
Air Gap	Air	0.00122

Source Input**Grouping Method : Standard Indices****Number of Groups : 25****Lower Energy Cutoff : 0.015****Photons < 0.015 : Excluded****Library : Grove**

Nuclide	curies	becquerels	$\mu\text{Ci}/\text{cm}^2$	Bg/cm^2
Am-241	6.7544e-007	2.4991e+004	2.1500e-007	7.9550e-003
Ba-137m	5.1117e-004	1.8913e+007	1.6271e-004	6.0203e+000
Co-60	1.3320e-005	4.9285e+005	4.2400e-006	1.5688e-001
Cs-134	2.1174e-007	7.8345e+003	6.7400e-008	2.4938e-003
Cs-137	5.4035e-004	1.9993e+007	1.7200e-004	6.3640e+000
Pu-238	7.5398e-007	2.7897e+004	2.4000e-007	8.8800e-003
Pu-239	2.4002e-007	8.8807e+003	7.6400e-008	2.8268e-003
Pu-240	2.4002e-007	8.8807e+003	7.6400e-008	2.8268e-003
Pu-241	3.4243e-005	1.2670e+006	1.0900e-005	4.0330e-001
Sr-90	6.7544e-007	2.4991e+004	2.1500e-007	7.9550e-003
Y-90	6.7544e-007	2.4991e+004	2.1500e-007	7.9550e-003

Buildup**The material reference is : Air Gap****Integration Parameters**

Radial	20
Circumferential	20

Results

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 191 OF 215

Page : 2

DOS File : Case1

Run Date: February 21, 2006

Run Time: 11:59:58 AM

Duration : 00:00:00

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Exposure Rate</u> <u>mR/hr</u>	<u>Exposure Rate</u> <u>mR/hr</u>
		<u>No Buildup</u>	<u>With Buildup</u>	<u>No Buildup</u>	<u>With Buildup</u>
0.03	1.115e+06	1.056e-02	1.253e-02	1.047e-04	1.242e-04
0.04	2.629e+05	3.466e-03	4.120e-03	1.533e-05	1.822e-05
0.05	4.659e+00	7.802e-08	9.249e-08	2.078e-10	2.464e-10
0.06	9.030e+03	1.829e-04	2.151e-04	3.633e-07	4.273e-07
0.1	4.226e+00	1.445e-07	1.634e-07	2.211e-10	2.500e-10
0.3	2.773e+00	2.906e-07	3.074e-07	5.512e-10	5.832e-10
0.5	1.144e+02	2.016e-05	2.095e-05	3.956e-08	4.113e-08
0.6	1.703e+07	3.612e+00	3.736e+00	7.050e-03	7.293e-03
0.8	7.375e+03	2.095e-03	2.153e-03	3.985e-06	4.095e-06
1.0	4.931e+05	1.757e-01	1.798e-01	3.239e-04	3.315e-04
1.5	4.931e+05	2.650e-01	2.696e-01	4.459e-04	4.537e-04
TOTALS:	1.941e+07	4.069e+00	4.205e+00	7.944e-03	8.225e-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 192 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District

Page : 1
DOS File : Case1
Run Date : February 21, 2006
Run Time: 12:01:07 PM
Duration : 00:00:00

File Ref: _____
Date: _____
By: _____
Checked: _____

Case Title: 319 m² at Gross DCGL
Description: Case 1
Geometry: 3 - Disk



Radius	Source Dimensions	
	892.0 cm	29 ft 3.2 in

Dose Points			
# 1	X 100 cm 3 ft 3.4 in	Y 0 cm 0.0 in	Z 0 cm 0.0 in

Shields			
<u>Shield Name</u>	<u>Material</u>	<u>Density</u>	
Air Gap	Air	0.00122	

Source Input
Grouping Method : Standard Indices
Number of Groups : 25
Lower Energy Cutoff : 0.015
Photons < 0.015 : Excluded

Library : Grove

Nuclide	curies	becquerels	$\mu\text{Ci}/\text{cm}^2$	Bq/cm^2
Am-241	5.3743e-007	1.9885e+004	2.1500e-007	7.9550e-003
Ba-137m	4.0672e-004	1.5049e+007	1.6271e-004	6.0203e+000
Co-60	1.0599e-005	3.9215e+005	4.2400e-006	1.5688e-001
Cs-134	1.6848e-007	6.2336e+003	6.7400e-008	2.4938e-003
Cs-137	4.2994e-004	1.5908e+007	1.7200e-004	6.3640e+000
Pu-238	5.9992e-007	2.2197e+004	2.4000e-007	8.8800e-003
Pu-239	1.9097e-007	7.0660e+003	7.6400e-008	2.8268e-003
Pu-240	1.9097e-007	7.0660e+003	7.6400e-008	2.8268e-003
Pu-241	2.7246e-005	1.0081e+006	1.0900e-005	4.0330e-001
Sr-90	5.3743e-007	1.9885e+004	2.1500e-007	7.9550e-003
Y-90	5.3743e-007	1.9885e+004	2.1500e-007	7.9550e-003

Bulldup
The material reference is : Air Gap

Integration Parameters

Radial	20
Circumferential	20

Results

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 193 OF 215

Page : 2

DOS File : Case1

Run Date: February 21, 2006

Run Time: 12:01:07 PM

Duration : 00:00:00

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Exposure Rate</u> <u>mR/hr</u>	<u>Exposure Rate</u> <u>mR/hr</u>
		<u>No Buildup</u>	<u>With Buildup</u>	<u>No Buildup</u>	<u>With Buildup</u>
0.03	8.869e+05	1.015e-02	1.190e-02	1.006e-04	1.180e-04
0.04	2.092e+05	3.322e-03	3.899e-03	1.469e-05	1.725e-05
0.05	3.707e+00	7.469e-08	8.745e-08	1.990e-10	2.330e-10
0.06	7.185e+03	1.750e-04	2.034e-04	3.476e-07	4.040e-07
0.1	3.362e+00	1.382e-07	1.548e-07	2.114e-10	2.369e-10
0.3	2.207e+00	2.773e-07	2.922e-07	5.261e-10	5.544e-10
0.5	9.101e+01	1.923e-05	1.993e-05	3.774e-08	3.912e-08
0.6	1.355e+07	3.444e+00	3.554e+00	6.723e-03	6.938e-03
0.8	5.868e+03	1.997e-03	2.048e-03	3.799e-06	3.896e-06
1.0	3.923e+05	1.675e-01	1.711e-01	3.087e-04	3.154e-04
1.5	3.923e+05	2.525e-01	2.566e-01	4.248e-04	4.317e-04
TOTALS:	1.544e+07	3.880e+00	4.000e+00	7.576e-03	7.824e-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 194 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District

Page : 1
DOS File : Case1
Run Date: February 21, 2006
Run Time: 12:01:24 PM
Duration : 00:00:00

File Ref: _____
Date: _____
By: _____
Checked: _____

Case Title: 319 m² at Gross DCGL

Description: Case 1
Geometry: 3 - Disk



Radius	Source Dimensions	
	798.0 cm	26 ft 2.2 in

Dose Points				
# 1	<u>X</u> 100 cm 3 ft 3.4 in	<u>Y</u> 0 cm 0.0 in	<u>Z</u> 0 cm 0.0 in	

Shields		
Shield Name	Material	Density
Air Gap	Air	0.00122

Source Input
Grouping Method : Standard Indices

Number of Groups : 25

Lower Energy Cutoff : 0.015

Photons < 0.015 : Excluded

Library : Grove

<u>Nuclide</u>	<u>curies</u>	<u>becquerels</u>	<u>$\mu\text{Ci}/\text{cm}^2$</u>	<u>Bq/cm^2</u>
Am-241	4.3012e-007	1.5915e+004	2.1500e-007	7.9550e-003
Ba-137m	3.2552e-004	1.2044e+007	1.6271e-004	6.0203e+000
Co-60	8.4825e-006	3.1385e+005	4.2400e-006	1.5688e-001
Cs-134	1.3484e-007	4.9890e+003	6.7400e-008	2.4938e-003
Cs-137	3.4410e-004	1.2732e+007	1.7200e-004	6.3640e+000
Pu-238	4.8014e-007	1.7765e+004	2.4000e-007	8.8800e-003
Pu-239	1.5284e-007	5.6552e+003	7.6400e-008	2.8268e-003
Pu-240	1.5284e-007	5.6552e+003	7.6400e-008	2.8268e-003
Pu-241	2.1806e-005	8.0683e+005	1.0900e-005	4.0330e-001
Sr-90	4.3012e-007	1.5915e+004	2.1500e-007	7.9550e-003
Y-90	4.3012e-007	1.5915e+004	2.1500e-007	7.9550e-003

Buildup
The material reference is : Air Gap

Integration Parameters

Radial	20
Circumferential	20

Results

DECOMMISSIONING TECHNICAL BASIS DOCUMENT

NUMBER: DTBD-06-002

REVISION: 0

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 195 OF 215

Page : 2

DOS File : Case1.

Run Date: February 21, 2006

Run Time: 12:01:24 PM

Duration : 00:00:00

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Exposure Rate</u> <u>mR/hr</u>	<u>Exposure Rate</u> <u>mR/hr</u>
		<u>No Buildup</u>	<u>With Buildup</u>	<u>No Buildup</u>	<u>With Buildup</u>
0.03	7.098e+05	9.734e-03	1.129e-02	9.647e-05	1.119e-04
0.04	1.674e+05	3.177e-03	3.688e-03	1.405e-05	1.631e-05
0.05	2.967e+00	7.137e-08	8.264e-08	1.901e-10	2.201e-10
0.06	5.750e+03	1.671e-04	1.922e-04	3.320e-07	3.817e-07
0.1	2.691e+00	1.318e-07	1.466e-07	2.017e-10	2.242e-10
0.3	1.766e+00	2.643e-07	2.775e-07	5.014e-10	5.264e-10
0.5	7.284e+01	1.831e-05	1.894e-05	3.594e-08	3.717e-08
0.6	1.084e+07	3.280e+00	3.377e+00	6.402e-03	6.592e-03
0.8	4.696e+03	1.902e-03	1.947e-03	3.617e-06	3.703e-06
1.0	3.140e+05	1.594e-01	1.626e-01	2.938e-04	2.998e-04
1.5	3.140e+05	2.403e-01	2.439e-01	4.042e-04	4.103e-04
TOTALS:	1.236e+07	3.695e+00	3.801e+00	7.215e-03	7.435e-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 196 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District

Page : 1
DOS File : Case1
Run Date : February 21, 2006
Run Time: 12:01:42 PM
Duration : 00:00:00

File Ref: _____
Date: _____
By: _____
Checked: _____

Case Title: 319 m² at Gross DCGL**Description: Case 1****Geometry: 3 - Disk**

Source Dimensions
Radius 691.0 cm 22 ft 8.0 in

Dose Points
#1 X 100 cm Y 0 cm Z 0 cm
 3 ft 3.4 in 0.0 in 0.0 in

Shields	
<u>Shield Name</u>	<u>Material</u>
Air Gap	Air
	0.00122

Source Input**Grouping Method : Standard Indices****Number of Groups : 25****Lower Energy Cutoff : 0.015****Photons < 0.015 : Excluded****Library : Grove**

<u>Nuclide</u>	<u>curies</u>	<u>becquerels</u>	<u>µCi/cm²</u>	<u>Bq/cm²</u>
Am-241	3.2251e-007	1.1933e+004	2.1500e-007	7.9550e-003
Ba-137m	2.4408e-004	9.0308e+006	1.6271e-004	6.0203e+000
Co-60	6.3602e-006	2.3533e+005	4.2400e-006	1.5688e-001
Cs-134	1.0110e-007	3.7408e+003	6.7400e-008	2.4938e-003
Cs-137	2.5801e-004	9.5463e+006	1.7200e-004	6.3640e+000
Pu-238	3.6001e-007	1.3320e+004	2.4000e-007	8.8800e-003
Pu-239	1.1460e-007	4.2403e+003	7.6400e-008	2.8268e-003
Pu-240	1.1460e-007	4.2403e+003	7.6400e-008	2.8268e-003
Pu-241	1.6351e-005	6.0497e+005	1.0900e-005	4.0330e-001
Sr-90	3.2251e-007	1.1933e+004	2.1500e-007	7.9550e-003
Y-90	3.2251e-007	1.1933e+004	2.1500e-007	7.9550e-003

Bulldup**The material reference Is : Air Gap****Integration Parameters**

Radial	20
Circumferential	20

Results

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 197 OF 215

Page : 2
DOS File : Case1
Run Date: February 21, 2006
Run Time: 12:01:42 PM
Duration : 00:00:00

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Exposure Rate</u> <u>mR/hr</u>	<u>Exposure Rate</u> <u>mR/hr</u>
		<u>No Buildup</u>	<u>With Buildup</u>	<u>No Buildup</u>	<u>With Buildup</u>
0.03	5.322e+05	9.175e-03	1.051e-02	9.093e-05	1.042e-04
0.04	1.255e+05	2.986e-03	3.421e-03	1.320e-05	1.513e-05
0.05	2.225e+00	6.698e-08	7.657e-08	1.784e-10	2.040e-10
0.06	4.312e+03	1.568e-04	1.781e-04	3.114e-07	3.537e-07
0.1	2.018e+00	1.236e-07	1.361e-07	1.890e-10	2.082e-10
0.3	1.324e+00	2.473e-07	2.586e-07	4.692e-10	4.905e-10
0.5	5.462e+01	1.712e-05	1.765e-05	3.361e-08	3.465e-08
0.6	8.131e+06	3.066e+00	3.149e+00	5.985e-03	6.147e-03
0.8	3.521e+03	1.777e-03	1.816e-03	3.380e-06	3.453e-06
1.0	2.354e+05	1.489e-01	1.517e-01	2.745e-04	2.796e-04
1.5	2.354e+05	2.244e-01	2.274e-01	3.775e-04	3.827e-04
TOTALS:	9.267e+06	3.454e+00	3.544e+00	6.745e-03	6.933e-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 198 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District

Page : 1
DOS File : Case1
Run Date: February 21, 2006
Run Time: 12:01:58 PM
Duration : 00:00:00

File Ref: _____
Date: _____
By: _____
Checked: _____

**Case Title: 319 m² at Gross DCGL****Description: Case 1****Geometry: 3 - Disk**

Source Dimensions
Radius 564.0 cm 18 ft 6.0 in

Dose Points
1 X Y Z
 100 cm 0 cm 0 cm
 3 ft 3.4 in 0.0 in 0.0 in

Shields	
<u>Shield Name</u>	<u>Material</u>
Air Gap	Air

Density 0.00122

Source Input**Grouping Method : Standard Indices****Number of Groups : 25****Lower Energy Cutoff : 0.015****Photons < 0.015 : Excluded****Library : Grove**

<u>Nuclide</u>	<u>curies</u>	<u>becquerels</u>	<u>µCi/cm²</u>	<u>Bq/cm²</u>
Am-241	2.1486e-007	7.9497e+003	2.1500e-007	7.9550e-003
Ba-137m	1.6260e-004	6.0163e+006	1.6271e-004	6.0203e+000
Co-60	4.2372e-006	1.5677e+005	4.2400e-006	1.5688e-001
Cs-134	6.7355e-008	2.4921e+003	6.7400e-008	2.4938e-003
Cs-137	1.7188e-004	6.3597e+006	1.7200e-004	6.3640e+000
Pu-238	2.3984e-007	8.8740e+003	2.4000e-007	8.8800e-003
Pu-239	7.6349e-008	2.8249e+003	7.6400e-008	2.8268e-003
Pu-240	7.6349e-008	2.8249e+003	7.6400e-008	2.8268e-003
Pu-241	1.0893e-005	4.0303e+005	1.0900e-005	4.0330e-001
Sr-90	2.1486e-007	7.9497e+003	2.1500e-007	7.9550e-003
Y-90	2.1486e-007	7.9497e+003	2.1500e-007	7.9550e-003

Buildup**The material reference is : Air Gap****Integration Parameters**

Radial	20
Circumferential	20

Results

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 199 OF 215

Page : 2

DOS File : Case1

Run Date: February 21, 2006

Run Time: 12:01:58 PM

Duration : 00:00:00

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Exposure Rate</u> <u>mR/hr</u>	<u>Exposure Rate</u> <u>mR/hr</u>
		<u>No Buildup</u>	<u>With Buildup</u>	<u>No Buildup</u>	<u>With Buildup</u>
0.03	3.546e+05	8.355e-03	9.421e-03	8.281e-05	9.336e-05
0.04	8.363e+04	2.708e-03	3.054e-03	1.198e-05	1.350e-05
0.05	1.482e+00	6.068e-08	6.826e-08	1.616e-10	1.818e-10
0.06	2.872e+03	1.419e-04	1.587e-04	2.819e-07	3.153e-07
0.1	1.344e+00	1.117e-07	1.216e-07	1.709e-10	1.861e-10
0.3	8.822e-01	2.232e-07	2.321e-07	4.233e-10	4.403e-10
0.5	3.639e+01	1.544e-05	1.586e-05	3.030e-08	3.113e-08
0.6	5.417e+06	2.764e+00	2.830e+00	5.395e-03	5.523e-03
0.8	2.346e+03	1.601e-03	1.632e-03	3.045e-06	3.103e-06
1.0	1.568e+05	1.341e-01	1.363e-01	2.472e-04	2.513e-04
1.5	1.569e+05	2.020e-01	2.044e-01	3.398e-04	3.439e-04
TOTALS:	6.174e+06	3.113e+00	3.185e+00	6.080e-03	6.229e-03

TITLE: Use of a Survey Unit Size of .319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 200 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District

Page : 1
DOS File : Case1
Run Date: February 21, 2006
Run Time: 12:02:16 PM
Duration : 00:00:00

File Ref: _____
Date: _____
By: _____
Checked: _____

Case Title: 319 m² at Gross DCGL
Description: Case 1
Geometry: 3 - Disk



Radius	Source Dimensions	
	489.0 cm	16 ft 0.5 in

Dose Points				
# 1	X 100 cm 3 ft 3.4 in	Y 0 cm 0.0 in	Z 0 cm 0.0 in	

Shields		
<u>Shield Name</u>	<u>Material</u>	<u>Density</u>
Air Gap	Air	0.00122

Source Input
Grouping Method : Standard Indices

Number of Groups : 25

Lower Energy Cutoff : 0.015

Photons < 0.015 : Excluded

Library : Grove

<u>Nuclide</u>	<u>curies</u>	<u>becquerels</u>	<u>µCi/cm²</u>	<u>Bq/cm²</u>
Am-241	1.6151e-007	5.9760e+003	2.1500e-007	7.9550e-003
Ba-137m	1.2223e-004	4.5226e+006	1.6271e-004	6.0203e+000
Co-60	3.1852e-006	1.1785e+005	4.2400e-006	1.5688e-001
Cs-134	5.0632e-008	1.8734e+003	6.7400e-008	2.4938e-003
Cs-137	1.2921e-004	4.7808e+006	1.7200e-004	6.3640e+000
Pu-238	1.8029e-007	6.6708e+003	2.4000e-007	8.8800e-003
Pu-239	5.7393e-008	2.1236e+003	7.6400e-008	2.8268e-003
Pu-240	5.7393e-008	2.1236e+003	7.6400e-008	2.8268e-003
Pu-241	8.1883e-006	3.0297e+005	1.0900e-005	4.0330e-001
Sr-90	1.6151e-007	5.9760e+003	2.1500e-007	7.9550e-003
Y-90	1.6151e-007	5.9760e+003	2.1500e-007	7.9550e-003

Buildup
The material reference is : Air Gap

Integration Parameters

Radial	20
Circumferential	20

Results

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 201 OF 215

Page : 2

DOS File : Case1

Run Date: February 21, 2006

Run Time: 12:02:16 PM

Duration : 00:00:00

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u>		<u>Exposure Rate</u>	
		<u>MeV/cm²/sec</u> <u>No Buildup</u>	<u>MeV/cm²/sec</u> <u>With Buildup</u>	<u>mR/hr</u> <u>No Buildup</u>	<u>mR/hr</u> <u>With Buildup</u>
0.03	2.665e+05	7.762e-03	8.667e-03	7.693e-05	8.590e-05
0.04	6.287e+04	2.510e-03	2.802e-03	1.110e-05	1.239e-05
0.05	1.114e+00	5.619e-08	6.259e-08	1.497e-10	1.667e-10
0.06	2.159e+03	1.313e-04	1.456e-04	2.609e-07	2.891e-07
0.1	1.010e+00	1.033e-07	1.117e-07	1.581e-10	1.709e-10
0.3	6.632e-01	2.062e-07	2.137e-07	3.911e-10	4.054e-10
0.5	2.735e+01	1.425e-05	1.461e-05	2.798e-08	2.868e-08
0.6	4.072e+06	2.551e+00	2.607e+00	4.980e-03	5.089e-03
0.8	1.763e+03	1.478e-03	1.503e-03	2.811e-06	2.860e-06
1.0	1.179e+05	1.238e-01	1.256e-01	2.281e-04	2.315e-04
1.5	1.179e+05	1.863e-01	1.884e-01	3.135e-04	3.169e-04
TOTALS:	4.641e+06	2.873e+00	2.934e+00	5.613e-03	5.739e-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 202 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District

Page : 1
DOS File : Case1
Run Date: February 21, 2006
Run Time: 12:02:34 PM
Duration : 00:00:00

File Ref: _____
Date: _____
By: _____
Checked: _____

Case Title: 319 m² at Gross DCGL

Description: Case 1
Geometry: 3 - Disk



Source Dimensions
Radius 399.0 cm 13 ft 1.1 in

Dose Points
1 X 100 cm Y 0 cm Z 0 cm
3 ft 3.4 in 0.0 in 0.0 in

Shields			
<u>Shield Name</u>	<u>Material</u>	<u>Density</u>	
Air Gap	Air	0.00122	

Source Input**Grouping Method : Standard Indices****Number of Groups : 25****Lower Energy Cutoff : 0.015****Photons < 0.015 : Excluded****Library : Grove**

<u>Nuclide</u>	<u>curies</u>	<u>becquerels</u>	<u>µCi/cm²</u>	<u>Bq/cm²</u>
Am-241	1.0753e-007	3.9787e+003	2.1500e-007	7.9550e-003
Ba-137m	8.1380e-005	3.0110e+006	1.6271e-004	6.0203e+000
Co-60	2.1206e-006	7.8463e+004	4.2400e-006	1.5688e-001
Cs-134	3.3710e-008	1.2473e+003	6.7400e-008	2.4938e-003
Cs-137	8.6025e-005	3.1829e+006	1.7200e-004	6.3640e+000
Pu-238	1.2003e-007	4.4413e+003	2.4000e-007	8.8800e-003
Pu-239	3.8211e-008	1.4138e+003	7.6400e-008	2.8268e-003
Pu-240	3.8211e-008	1.4138e+003	7.6400e-008	2.8268e-003
Pu-241	5.4516e-006	2.0171e+005	1.0900e-005	4.0330e-001
Sr-90	1.0753e-007	3.9787e+003	2.1500e-007	7.9550e-003
Y-90	1.0753e-007	3.9787e+003	2.1500e-007	7.9550e-003

Bulldup**The material reference is : Air Gap****Integration Parameters**

Radial	20
Circumferential	20

Results

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 203 OF 215

Page : 2

DOS File : Case1

Run Date: February 21, 2006

Run Time: 12:02:34 PM

Duration : 00:00:00

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Exposure Rate</u> <u>mR/hr</u>	<u>Exposure Rate</u> <u>mR/hr</u>
0.03	1.775e+05	6.902e-03	7.613e-03	6.841e-05	7.545e-05
0.04	4.186e+04	2.225e-03	2.454e-03	9.842e-06	1.085e-05
0.05	7.418e-01	4.975e-08	5.475e-08	1.325e-10	1.459e-10
0.06	1.438e+03	1.162e-04	1.273e-04	2.309e-07	2.529e-07
0.1	6.727e-01	9.135e-08	9.789e-08	1.398e-10	1.498e-10
0.3	4.415e-01	1.820e-07	1.879e-07	3.453e-10	3.565e-10
0.5	1.821e+01	1.258e-05	1.286e-05	2.469e-08	2.523e-08
0.6	2.711e+06	2.251e+00	2.294e+00	4.393e-03	4.478e-03
0.8	1.174e+03	1.303e-03	1.323e-03	2.478e-06	2.517e-06
1.0	7.850e+04	1.091e-01	1.105e-01	2.011e-04	2.038e-04
1.5	7.850e+04	1.642e-01	1.658e-01	2.762e-04	2.789e-04
TOTALS:	3.090e+06	2.534e+00	2.582e+00	4.951e-03	5.050e-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station


PAGE 204 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District

Page : 1
DOS File : Case1
Run Date: February 21, 2006
Run Time: 12:02:54 PM
Duration : 00:00:00

File Ref: _____
Date: _____
By: _____
Checked: _____

Case Title: 319 m² at Gross DCGL
Description: Case 1
Geometry: 3 - Disk



Source Dimensions
Radius 282.0 cm 9 ft 3.0 in

Dose Points
1 X 100 cm Y 0 cm Z 0 cm
3 ft 3.4 in 0.0 in 0.0 in

Shields			
<u>Shield Name</u>	<u>Material</u>	<u>Density</u>	
Air Gap	Air	0.00122	

Source Input
Grouping Method : Standard Indices

Number of Groups : 25

Lower Energy Cutoff : 0.015

Photons < 0.015 : Excluded

Library : Grove

<u>Nuclide</u>	<u>curies</u>	<u>becquerels</u>	<u>µCi/cm²</u>	<u>Bq/cm²</u>
Am-241	5.3714e-008	1.9874e+003	2.1500e-007	7.9550e-003
Ba-137m	4.0651e-005	1.5041e+006	1.6271e-004	6.0203e+000
Co-60	1.0593e-006	3.9194e+004	4.2400e-006	1.5688e-001
Cs-134	1.6839e-008	6.2303e+002	6.7400e-008	2.4938e-003
Cs-137	4.2971e-005	1.5899e+006	1.7200e-004	6.3640e+000
Pu-238	5.9960e-008	2.2185e+003	2.4000e-007	8.8800e-003
Pu-239	1.9087e-008	7.0623e+002	7.6400e-008	2.8268e-003
Pu-240	1.9087e-008	7.0623e+002	7.6400e-008	2.8268e-003
Pu-241	2.7232e-006	1.0076e+005	1.0900e-005	4.0330e-001
Sr-90	5.3714e-008	1.9874e+003	2.1500e-007	7.9550e-003
Y-90	5.3714e-008	1.9874e+003	2.1500e-007	7.9550e-003

Buildup
The material reference is : Air Gap

Integration Parameters

Radial	20
Circumferential	20

Results

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 205 OF 215

Page : 2

DOS File : Case1

Run Date: February 21, 2006

Run Time: 12:02:54 PM

Duration : 00:00:00

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Exposure Rate</u> <u>mR/hr</u>	<u>Exposure Rate</u> <u>mR/hr</u>
		<u>No Buildup</u>	<u>With Buildup</u>	<u>No Buildup</u>	<u>With Buildup</u>
0.03	8.864e+04	5.429e-03	5.888e-03	5.380e-05	5.835e-05
0.04	2.091e+04	1.743e-03	1.889e-03	7.708e-06	8.356e-06
0.05	3.705e-01	3.891e-08	4.211e-08	1.036e-10	1.122e-10
0.06	7.181e+02	9.083e-05	9.793e-05	1.804e-07	1.945e-07
0.1	3.360e-01	7.129e-08	7.548e-08	1.091e-10	1.155e-10
0.3	2.206e-01	1.418e-07	1.455e-07	2.689e-10	2.761e-10
0.5	9.096e+00	9.786e-06	9.964e-06	1.921e-08	1.956e-08
0.6	1.354e+06	1.751e+00	1.779e+00	3.417e-03	3.472e-03
0.8	5.865e+02	1.013e-03	1.026e-03	1.927e-06	1.952e-06
1.0	3.921e+04	8.480e-02	8.573e-02	1.563e-04	1.580e-04
1.5	3.921e+04	1.275e-01	1.286e-01	2.146e-04	2.163e-04
TOTALS:	1.543e+06	1.971e+00	2.002e+00	3.852e-03	3.915e-03


TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 206 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District

Page : 1
DOS File : Case1
Run Date: February 21, 2006
Run Time: 12:03:09 PM
Duration : 00:00:00

File Ref: _____
Date: _____
By: _____
Checked: _____

Case Title: 319 m² at Gross DCGL**Description: Case 1****Geometry: 3 - Disk**

Source Dimensions
Radius 219.0 cm 7 ft 2.2 in

Dose Points			
#	X	Y	Z
1	100 cm 3 ft 3.4 in	0 cm 0.0 in	0 cm 0.0 in

Shields		
<u>Shield Name</u>	<u>Material</u>	<u>Density</u>
Air Gap	Air	0.00122

Source Input**Grouping Method : Standard Indices****Number of Groups : 25****Lower Energy Cutoff : 0.015****Photons < 0.015 : Excluded****Library : Grove**

<u>Nuclide</u>	<u>curies</u>	<u>becquerels</u>	<u>µCi/cm²</u>	<u>Bq/cm²</u>
Am-241	3.2395e-008	1.1986e+003	2.1500e-007	7.9550e-003
Ba-137m	2.4516e-005	9.0711e+005	1.6271e-004	6.0203e+000
Co-60	6.3886e-007	2.3638e+004	4.2400e-006	1.5688e-001
Cs-134	1.0155e-008	3.7575e+002	6.7400e-008	2.4938e-003
Cs-137	2.5916e-005	9.5889e+005	1.7200e-004	6.3640e+000
Pu-238	3.6162e-008	1.3380e+003	2.4000e-007	8.8800e-003
Pu-239	1.1511e-008	4.2593e+002	7.6400e-008	2.8268e-003
Pu-240	1.1511e-008	4.2593e+002	7.6400e-008	2.8268e-003
Pu-241	1.6423e-006	6.0767e+004	1.0900e-005	4.0330e-001
Sr-90	3.2395e-008	1.1986e+003	2.1500e-007	7.9550e-003
Y-90	3.2395e-008	1.1986e+003	2.1500e-007	7.9550e-003

Bulldup**The material reference is : Air Gap****Integration Parameters**

Radial	20
Circumferential	20

Results

**TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station**

PAGE 207 OF 215

Page : 2

DOS File : Case1

Run Date: February 21, 2006

Run Time: 12:03:09 PM

Duration : 00:00:00

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Exposure Rate</u> <u>mR/hr</u>	<u>Exposure Rate</u> <u>mR/hr</u>
		<u>No Buildup</u>	<u>With Buildup</u>	<u>No Buildup</u>	<u>With Buildup</u>
0.03	5.346e+04	4.389e-03	4.715e-03	4.350e-05	4.673e-05
0.04	1.261e+04	1.406e-03	1.509e-03	6.217e-06	6.676e-06
0.05	2.235e-01	3.135e-08	3.361e-08	8.352e-11	8.955e-11
0.06	4.331e+02	7.316e-05	7.818e-05	1.453e-07	1.553e-07
0.1	2.027e-01	5.737e-08	6.034e-08	8.777e-11	9.231e-11
0.3	1.330e-01	1.140e-07	1.166e-07	2.162e-10	2.212e-10
0.5	5.486e+00	7.863e-06	7.989e-06	1.543e-08	1.568e-08
0.6	8.167e+05	1.406e+00	1.426e+00	2.745e-03	2.784e-03
0.8	3.537e+02	8.137e-04	8.228e-04	1.548e-06	1.565e-06
1.0	2.365e+04	6.810e-02	6.875e-02	1.255e-04	1.267e-04
1.5	2.365e+04	1.024e-01	1.031e-01	1.723e-04	1.735e-04
TOTALS:	9.308e+05	1.584e+00	1.605e+00	3.094e-03	3.139e-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station


PAGE 208 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District

Page : 1
DOS File : Case1
Run Date : February 21, 2006
Run Time: 12:03:26 PM
Duration : 00:00:00

File Ref: _____
Date: _____
By: _____
Checked: _____

Case Title: 319 m² at Gross DCGL
Description: Case 1
Geometry: 3 - Disk



Source Dimensions
Radius 178.0 cm 5 ft 10.1 in

		X	Y	Z
# 1	100 cm	0 cm	0 cm	
	3 ft 3.4 in	0.0 in	0.0 in	

Shields		
<u>Shield Name</u>	<u>Material</u>	<u>Density</u>
Air Gap	Air	0.00122

Source Input
Grouping Method : Standard Indices
Number of Groups : 25
Lower Energy Cutoff : 0.015
Photons < 0.015 : Excluded

Library : Grove

<u>Nuclide</u>	<u>curies</u>	<u>becquerels</u>	<u>$\mu\text{Ci}/\text{cm}^2$</u>	<u>Bq/cm^2</u>
Am-241	2.1401e-008	7.9183e+002	2.1500e-007	7.9550e-003
Ba-137m	1.6196e-005	5.9925e+005	1.6271e-004	6.0203e+000
Co-60	4.2204e-007	1.5616e+004	4.2400e-006	1.5688e-001
Cs-134	6.7089e-009	2.4823e+002	6.7400e-008	2.4938e-003
Cs-137	1.7121e-005	6.3346e+005	1.7200e-004	6.3640e+000
Pu-238	2.3889e-008	8.8390e+002	2.4000e-007	8.8800e-003
Pu-239	7.6047e-009	2.8137e+002	7.6400e-008	2.8268e-003
Pu-240	7.6047e-009	2.8137e+002	7.6400e-008	2.8268e-003
Pu-241	1.0850e-006	4.0144e+004	1.0900e-005	4.0330e-001
Sr-90	2.1401e-008	7.9183e+002	2.1500e-007	7.9550e-003
Y-90	2.1401e-008	7.9183e+002	2.1500e-007	7.9550e-003

Buildup
The material reference is : Air Gap

Integration Parameters

Radial	20
Circumferential	20

Results

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 209 OF 215

Page : 2

DOS File : Case1

Run Date: February 21, 2006

Run Time: 12:03:26 PM

Duration : 00:00:00

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Exposure Rate</u> <u>mR/hr</u>	<u>Exposure Rate</u> <u>mR/hr</u>
		<u>No Buildup</u>	<u>With Buildup</u>	<u>No Buildup</u>	<u>With Buildup</u>
0.03	3.532e+04	3.586e-03	3.828e-03	3.554e-05	3.793e-05
0.04	8.330e+03	1.147e-03	1.223e-03	5.071e-06	5.411e-06
0.05	1.476e-01	2.556e-08	2.723e-08	6.808e-11	7.254e-11
0.06	2.861e+02	5.962e-05	6.333e-05	1.184e-07	1.258e-07
0.1	1.339e-01	4.673e-08	4.893e-08	7.149e-11	7.485e-11
0.3	8.787e-02	9.275e-08	9.473e-08	1.759e-10	1.797e-10
0.5	3.624e+00	6.397e-06	6.491e-06	1.256e-08	1.274e-08
0.6	5.395e+05	1.144e+00	1.159e+00	2.233e-03	2.262e-03
0.8	2.337e+02	6.618e-04	6.686e-04	1.259e-06	1.272e-06
1.0	1.562e+04	5.538e-02	5.587e-02	1.021e-04	1.030e-04
1.5	1.562e+04	8.325e-02	8.379e-02	1.401e-04	1.410e-04
TOTALS:	6.149e+05	1.288e+00	1.304e+00	2.517e-03	2.551e-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 210 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District


Page : 1
DOS File : Case1
Run Date : February 21, 2006
Run Time: 12:03:44 PM
Duration : 00:00:00

File Ref: _____
Date: _____
By: _____
Checked: _____

Case Title: 319 m² at Gross DCGL

Description: Case 1

Geometry: 3 - Disk



Source Dimensions
Radius 126.0 cm 4 ft 1.6 in

Dose Points
1 X 100 cm Y 0 cm Z 0 cm
 3 ft 3.4 in 0.0 in 0.0 in

Shields			
<u>Shield Name</u>	<u>Material</u>	<u>Density</u>	
Air Gap	Air	0.00122	

Source Input

Grouping Method : Standard Indices

Number of Groups : 25

Lower Energy Cutoff : 0.015

Photons < 0.015 : Excluded

Library : Grove

<u>Nuclide</u>	<u>curies</u>	<u>becquerels</u>	<u>µCi/cm²</u>	<u>Bq/cm²</u>
Am-241	1.0723e-008	3.9676e+002	2.1500e-007	7.9550e-003
Ba-137m	8.1154e-006	3.0027e+005	1.6271e-004	6.0203e+000
Co-60	2.1147e-007	7.8245e+003	4.2400e-006	1.5688e-001
Cs-134	3.3616e-009	1.2438e+002	6.7400e-008	2.4938e-003
Cs-137	8.5787e-006	3.1741e+005	1.7200e-004	6.3640e+000
Pu-238	1.1970e-008	4.4290e+002	2.4000e-007	8.8800e-003
Pu-239	3.8105e-009	1.4099e+002	7.6400e-008	2.8268e-003
Pu-240	3.8105e-009	1.4099e+002	7.6400e-008	2.8268e-003
Pu-241	5.4365e-007	2.0115e+004	1.0900e-005	4.0330e-001
Sr-90	1.0723e-008	3.9676e+002	2.1500e-007	7.9550e-003
Y-90	1.0723e-008	3.9676e+002	2.1500e-007	7.9550e-003

Buildup

The material reference is : Air Gap

Integration Parameters

Radial	20
Circumferential	20

Results

DECOMMISSIONING TECHNICAL BASIS DOCUMENT

NUMBER: DTBD-06-002

REVISION: 0

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 211 OF 215

Page : 2

DOS File : Case1

Run Date : February 21, 2006

Run Time: 12:03:44 PM

Duration : 00:00:00

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Exposure Rate</u> <u>mR/hr</u>	<u>Exposure Rate</u> <u>mR/hr</u>
		<u>No Buildup</u>	<u>With Buildup</u>	<u>No Buildup</u>	<u>With Buildup</u>
0.03	1.770e+04	2.405e-03	2.547e-03	2.383e-05	2.524e-05
0.04	4.174e+03	7.674e-04	8.124e-04	3.394e-06	3.593e-06
0.05	7.397e-02	1.709e-08	1.807e-08	4.553e-11	4.814e-11
0.06	1.434e+02	3.986e-05	4.203e-05	7.917e-08	8.348e-08
0.1	6.709e-02	3.123e-08	3.251e-08	4.777e-11	4.974e-11
0.3	4.403e-02	6.191e-08	6.307e-08	1.174e-10	1.196e-10
0.5	1.816e+00	4.269e-06	4.323e-06	8.379e-09	8.486e-09
0.6	2.703e+05	7.633e-01	7.719e-01	1.490e-03	1.507e-03
0.8	1.171e+02	4.415e-04	4.454e-04	8.397e-07	8.472e-07
1.0	7.828e+03	3.694e-02	3.722e-02	6.808e-05	6.861e-05
1.5	7.828e+03	5.551e-02	5.582e-02	9.339e-05	9.392e-05
TOTALS:	3.081e+05	8.594e-01	8.688e-01	1.680e-03	1.699e-03

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 212 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District


Page : 1
DOS File : Case1
Run Date: February 21, 2006
Run Time: 12:04:01 PM
Duration : 00:00:00

File Ref: _____
Date: _____
By: _____
Checked: _____

Case Title: 319 m² at Gross DCGL

Description: Case 1

Geometry: 3 - Disk



Source Dimensions
Radius 56.0 cm 1 ft 10.0 in

Dose Points			
#	X	Y	Z
1	100 cm 3 ft 3.4 in	0 cm 0.0 in	0 cm 0.0 in

Shields		
<u>Shield Name</u>	<u>Material</u>	<u>Density</u>
Air Gap	Air	0.00122

Source Input

Grouping Method : Standard Indices

Number of Groups : 25

Lower Energy Cutoff : 0.015

Photons < 0.015 : Excluded

Library : Grove

<u>Nuclide</u>	<u>curies</u>	<u>becquerels</u>	<u>µCi/cm²</u>	<u>Bq/cm²</u>
Am-241	2.1182e-009	7.8373e+001	2.1500e-007	7.9550e-003
Ba-137m	1.6030e-006	5.9313e+004	1.6271e-004	6.0203e+000
Co-60	4.1773e-008	1.5456e+003	4.2400e-006	1.5688e-001
Cs-134	6.6403e-010	2.4569e+001	6.7400e-008	2.4938e-003
Cs-137	1.6945e-006	6.2698e+004	1.7200e-004	6.3640e+000
Pu-238	2.3645e-009	8.7486e+001	2.4000e-007	8.8800e-003
Pu-239	7.5270e-010	2.7850e+001	7.6400e-008	2.8268e-003
Pu-240	7.5270e-010	2.7850e+001	7.6400e-008	2.8268e-003
Pu-241	1.0739e-007	3.9733e+003	1.0900e-005	4.0330e-001
Sr-90	2.1182e-009	7.8373e+001	2.1500e-007	7.9550e-003
Y-90	2.1182e-009	7.8373e+001	2.1500e-007	7.9550e-003

Buildup

The material reference is : Air Gap

Integration Parameters

Radial	20
Circumferential	20

Results

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 213 OF 215

Page : 2

DOS File : Case1

Run Date: February 21, 2006

Run Time: 12:04:01 PM

Duration : 00:00:00

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u>		<u>Exposure Rate</u>	
		<u>MeV/cm²/sec</u>	<u>No Buildup</u>	<u>MeV/cm²/sec</u>	<u>With Buildup</u>
0.03	3.496e+03	6.957e-04	7.299e-04	6.895e-06	7.234e-06
0.04	8.245e+02	2.215e-04	2.323e-04	9.795e-07	1.027e-06
0.05	1.461e-02	4.929e-09	5.164e-09	1.313e-11	1.376e-11
0.06	2.832e+01	1.149e-05	1.201e-05	2.282e-08	2.385e-08
0.1	1.325e-02	8.993e-09	9.302e-09	1.376e-11	1.423e-11
0.3	8.697e-03	1.781e-08	1.809e-08	3.379e-11	3.432e-11
0.5	3.587e-01	1.227e-06	1.241e-06	2.409e-09	2.435e-09
0.6	5.340e+04	2.195e-01	2.215e-01	4.283e-04	4.324e-04
0.8	2.313e+01	1.269e-04	1.278e-04	2.413e-07	2.432e-07
1.0	1.546e+03	1.061e-02	1.068e-02	1.957e-05	1.969e-05
1.5	1.546e+03	1.595e-02	1.602e-02	2.683e-05	2.696e-05
TOTALS:	6.086e+04	2.471e-01	2.493e-01	4.829e-04	4.875e-04


TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 214 OF 215

MicroShield v5.05 (5.05-00488)
Sacramento Municipal Utility District

Page : 1
DOS File : Case1
Run Date: February 21, 2006
Run Time: 12:04:15 PM
Duration : 00:00:00

File Ref: _____
Date: _____
By: _____
Checked: _____

Case Title: 319 m² at Gross DCGL**Description: Case 1****Geometry: 3 - Disk**

Source Dimensions		
Radius	40.0 cm	1 ft 3.7 in

Dose Points			
# 1	X 100 cm 3 ft 3.4 in	Y 0 cm 0.0 in	Z 0 cm 0.0 in

Shields		
<u>Shield Name</u>	<u>Material</u>	<u>Density</u>
Air Gap	Air	0.00122

Source Input**Grouping Method : Standard Indices****Number of Groups : 25****Lower Energy Cutoff : 0.015****Photons < 0.015 : Excluded****Library : Grove**

<u>Nuclide</u>	<u>curies</u>	<u>becquerels</u>	<u>$\mu\text{Ci}/\text{cm}^2$</u>	<u>Bq/cm^2</u>
Am-241	1.0807e-009	3.9986e+001	2.1500e-007	7.9550e-003
Ba-137m	8.1788e-007	3.0262e+004	1.6271e-004	6.0203e+000
Co-60	2.1313e-008	7.8856e+002	4.2400e-006	1.5688e-001
Cs-134	3.3879e-010	1.2535e+001	6.7400e-008	2.4938e-003
Cs-137	8.6457e-007	3.1989e+004	1.7200e-004	6.3640e+000
Pu-238	1.2064e-009	4.4636e+001	2.4000e-007	8.8800e-003
Pu-239	3.8403e-010	1.4209e+001	7.6400e-008	2.8268e-003
Pu-240	3.8403e-010	1.4209e+001	7.6400e-008	2.8268e-003
Pu-241	5.4789e-008	2.0272e+003	1.0900e-005	4.0330e-001
Sr-90	1.0807e-009	3.9986e+001	2.1500e-007	7.9550e-003
Y-90	1.0807e-009	3.9986e+001	2.1500e-007	7.9550e-003

Buildup**The material reference is : Air Gap****Integration Parameters**

Radial	20
Circumferential	20

Results

TITLE: Use of a Survey Unit Size of 319 m² For Class One Structure Surveys
at Rancho Seco Nuclear Generating Station

PAGE 215 OF 215

Page : 2

DOS File : Case1

Run Date: February 21, 2006

Run Time: 12:04:15 PM

Duration : 00:00:00

<u>Energy</u> <u>MeV</u>	<u>Activity</u> <u>photons/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Fluence Rate</u> <u>MeV/cm²/sec</u>	<u>Exposure Rate</u> <u>mR/hr</u>	<u>Exposure Rate</u> <u>mR/hr</u>
		<u>No Buildup</u>	<u>With Buildup</u>	<u>No Buildup</u>	<u>With Buildup</u>
0.03	1.783e+03	3.790e-04	3.971e-04	3.757e-06	3.935e-06
0.04	4.207e+02	1.206e-04	1.263e-04	5.335e-07	5.587e-07
0.05	7.455e-03	2.684e-09	2.808e-09	7.150e-12	7.480e-12
0.06	1.445e+01	6.256e-06	6.530e-06	1.243e-08	1.297e-08
0.1	6.761e-03	4.896e-09	5.059e-09	7.491e-12	7.740e-12
0.3	4.437e-03	9.696e-09	9.843e-09	1.839e-11	1.867e-11
0.5	1.830e-01	6.681e-07	6.750e-07	1.311e-09	1.325e-09
0.6	2.724e+04	1.194e-01	1.205e-01	2.331e-04	2.353e-04
0.8	1.180e+01	6.906e-05	6.956e-05	1.314e-07	1.323e-07
1.0	7.889e+02	5.777e-03	5.813e-03	1.065e-05	1.071e-05
1.5	7.889e+02	8.679e-03	8.719e-03	1.460e-05	1.467e-05
TOTALS:	3.105e+04	1.345e-01	1.357e-01	2.628e-04	2.653e-04