

May 4, 2007

Mr. Britt T. McKinney
Sr. Vice President
and Chief Nuclear Officer
PPL Susquehanna, LLC
769 Salem Blvd., NUCSB3
Berwick, PA 18603-0467

SUBJECT: SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 2 - ADDENDUM TO
SAFETY EVALUATION REGARDING MINIMUM CRITICAL POWER RATIO
SAFETY LIMIT AND REFERENCE CHANGES (TAC NO. MD3595)

Dear Mr. McKinney:

On March 19, 2007, the Nuclear Regulatory Commission (NRC) issued Amendment No. 218 to Facility Operating License No. NPF-22 for the Susquehanna Steam Electric Station, Unit 2 (SSES 2). This amendment revised the SSES 2 Technical Specifications (TSs) by revising the SSES 2 Cycle 14 Minimum Critical Power Ratio Safety Limit in Section 2.1.1.2 for two-loop and single-loop operation and the references listed in Section 5.6.5.b.

Subsequent to the issuance of the subject amendment, Mr. Duane Filchner of your staff pointed out a number of errors in the safety evaluation (SE) supporting the amendment. We agree that editorial and technical errors had been inadvertently made, resulting in several inaccurate statements in the SE. Enclosed please find the corrected page 2 of the SE, with side bars highlighting the areas of correction. We apologize if these errors caused you any inconvenience. If there are any questions regarding this matter, please contact me at 301-415-1030.

Sincerely,

/RA/

Richard V. Guzman, Senior Project Manager
Plant Licensing Branch I-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-388

Enclosure:
As stated

cc w/encl: See next page

May 4, 2007

Mr. Britt T. McKinney
Sr. Vice President
and Chief Nuclear Officer
PPL Susquehanna, LLC
769 Salem Blvd., NUCSB3
Berwick, PA 18603-0467

SUBJECT: SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 2 - ADDENDUM TO
SAFETY EVALUATION REGARDING MINIMUM CRITICAL POWER RATIO
SAFETY LIMIT AND REFERENCE CHANGES (TAC NO. MD3595)

Dear Mr. McKinney:

On March 19, 2007, the Nuclear Regulatory Commission (NRC) issued Amendment No. 218 to Facility Operating License No. NPF-22 for the Susquehanna Steam Electric Station, Unit 2 (SSES 2). This amendment revised the SSES 2 Technical Specifications (TSs) by revising the SSES 2 Cycle 14 Minimum Critical Power Ratio Safety Limit in Section 2.1.1.2 for two-loop and single-loop operation and the references listed in Section 5.6.5.b.

Subsequent to the issuance of the subject amendment, Mr. Duane Filchner of your staff pointed out a number of errors in the safety evaluation (SE) supporting the amendment. We agree that editorial and technical errors had been inadvertently made, resulting in several inaccurate statements in the SE. Enclosed please find the corrected page 2 of the SE, with side bars highlighting the areas of correction. We apologize if these errors caused you any inconvenience. If there are any questions regarding this matter, please contact me at 301-415-1030.

Sincerely,

/RA/

Richard V. Guzman, Senior Project Manager
Plant Licensing Branch I-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-388

Enclosure:
As stated

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	RidsNrrDorlLpl1-1	RidsNrrPmRGuzman	THuang
LPLI-1 R/F	RidsNrrLASLittle	RidsOgcRp	
GHill (4)	RidsNrrDssSbwB	AcrsAcnwMailCenter	

ADAMS Accession No.: ML071200410

OFFICE	LPLI-1/PM	LPLI-1/LA	LPLI-1/BC
NAME	RGuzman	SLittle	MKowal
DATE	4/30/07	5/30/07	5/04/07

OFFICIAL RECORD COPY

2. NRC Generic Letter 88-16 (GL 88-16), "Removal of Cycle-Specific Parameter Limits from Technical Specifications," provides guidance on modifying cycle-specific parameter limits in the TSs.
3. NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants," provides guidance on the acceptability of the reactivity control systems, the reactor core, and fuel-system design. Specifically, Section 4.2, "Fuel System Design," specifies the criteria for evaluation of fuel-design limits such that there be at least 95% probability at a 95% confidence level that the hot fuel rod in the core does not experience a departure from nucleate boiling or a transition condition during normal operation or anticipated operational occurrences. Section 4.4, "Thermal and Hydraulic Design," provides guidance on the review of thermal-hydraulic design in meeting the requirement of GDC-10 and the fuel-design criteria established in Section 4.2.

3.0 TECHNICAL EVALUATION

3.1 TS 2.1.1 Reactor Core SLs

PPL proposed to change the MCPRSL value in TS 2.1.1.2 for SSES U2C14 operation from 1.09 to 1.11 for two-loop recirculation and from 1.10 to 1.14 for single-loop recirculation operation with the reactor steam dome pressure \geq 785 pounds per square-inch gauge (psig) and core flow \geq 10 million pound-mass per hour (lb_m/hr).

PPL described the approved methodologies used to calculate the MCPRSL value for the proposed TS change in the submittal. The U2C14 MCPRSL analysis was performed by AREVA using SSES 2 plant-and cycle-specific fuel, core parameters, power profiles, and NRC-approved methodologies: (1) ANF-524 (P)(A), Revision 2, "Critical Power Methodology for Boiling Water Reactors," Supplement 1, Revision 2 and Supplement 2; (2) EMF-2209 (P)(A), Revision 2, "SPCB Critical Power Correlation," and (3) EMF-2158 (P)(A), Revision 0, "Siemens Power Corporation Methodology for Boiling Water Reactors: Evaluation and Validation of CASMO-4/MICROBURN-B2." PPL provides the justification that the increase in the MCPRSL is due to: (1) cycle-to-cycle variation (± 0.01) and (2) transition from ANFB-10 to SPCB critical power correlation. PPL also provides references of system-related and fuel-related uncertainties and a general assessment of their impact on results fo the values of MCPRSL including three affecting factors as stated in the PPL supplement dated February 15, 2007.

The NRC staff has reviewed the justification contained in the application and supplement for the proposed MCPRSL value of 1.11 for two-loop recirculation operation and 1.14 for single-loop recirculation operation using the approach stated in TS 5.6.5.b. Based on the review of the proposed changes, the NRC staff concludes that PPL has provided adequate justification for the 0.02 and 0.04 increase in the MPRSL values for U2C14 two-loop and single-loop operation, respectively. Additionally, the U2C14 MCPRSL will ensure that 99.9% of the fuel rods in the core will not experience boiling transition, which satisfies the requirements of GDC-10. Therefore, the proposed MCPRSLs and its analysis for U2C14 operation using the plant- and cycle-specific calculation in conjunction with NRC-approved methods, is acceptable.

Susquehanna Steam Electric Station, Units 1 and 2

cc:

Robert A. Saccone
Vice President - Nuclear Operations
PPL Susquehanna, LLC
769 Salem Blvd., NUCSB3
Berwick, PA 18603-0467

Terry L. Harpster
General Manager - Plant Support
PPL Susquehanna, LLC
769 Salem Blvd., NUCSA4
Berwick, PA 18603-0467

Rocco R. Sgarro
Manager - Nuclear Regulatory Affairs
PPL Susquehanna, LLC
Two North Ninth Street, GENPL4
Allentown, PA 18101-1179

Walter E. Morrissey
Supervising Engineer
Nuclear Regulatory Affairs
PPL Susquehanna, LLC
769 Salem Blvd., NUCSA4
Berwick, PA 18603-0467

Michael H. Crowthers
Supervising Engineer
Nuclear Regulatory Affairs
PPL Susquehanna, LLC
Two North Ninth Street, GENPL4
Allentown, PA 18101-1179

Steven M. Cook
Manager - Quality Assurance
PPL Susquehanna, LLC
769 Salem Blvd., NUCSB2
Berwick, PA 18603-0467

Luis A. Ramos
Community Relations Manager,
Susquehanna
PPL Susquehanna, LLC
634 Salem Blvd., SSO
Berwick, PA 18603-0467

Bryan A. Snapp, Esq
Assoc. General Counsel
PPL Services Corporation
Two North Ninth Street, GENTW3
Allentown, PA 18101-1179

Supervisor - Document Control Services
PPL Susquehanna, LLC
Two North Ninth Street, GENPL4
Allentown, PA 18101-1179

Richard W. Osborne
Allegheny Electric Cooperative, Inc.
212 Locust Street
P.O. Box 1266
Harrisburg, PA 17108-1266

Director, Bureau of Radiation Protection
Pennsylvania Department of
Environmental Protection
Rachel Carson State Office Building
P.O. Box 8469
Harrisburg, PA 17105-8469

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 35, NUCSA4
Berwick, PA 18603-0035

Regional Administrator, Region 1
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Board of Supervisors
Salem Township
P.O. Box 405
Berwick, PA 18603-0035

Dr. Judith Johnsrud
National Energy Committee
Sierra Club
443 Orlando Avenue
State College, PA 16803