

**TENNESSEE VALLEY AUTHORITY'S
WATTS BAR NUCLEAR PLANT
UNIT 1**

ASME SECTION XI

INSERVICE INSPECTION

SUMMARY REPORT

SECOND REFUELING CYCLE

9907090113 990628
PDR ADOCK 05000390
G PDR







Owner: TENNESSEE VALLEY AUTHORITY
Chattanooga Office Complex
1101 Market Street
Chattanooga, TN 37402

Plant: WATTS BAR NUCLEAR PLANT
P.O. Box 2000
Spring City, TN 37381-2000

Unit: 1
Commercial Service Date: May 27, 1996

Certificate of Authorization: N/A
National Board Number for Unit: N/A

CONCURRENCE AND APPROVAL SHEET

Name	Title	Signature	Date
Prepared by:			
K. E. Casey	ISI Program Engineer		6/7/99
Concurred by:			
T. L. Hale	ISO ISI/NDE Coordinator		6/7/99
J. W. Whitaker	ISO NDE Level III	SEE ATTACHED	
G. L. Johnson	System Pressure Test Engineer		6/8/99
E. D. Camp	Steam Generator Specialist		7/5/99
R. M. Emrath	Corporate Codes & ISI Manager	SEE ATTACHED	
L. L. McCormick	Component Engineering Manager		6/15/99
Approved by:			
D. F. Helms	System Engineering Manager		6/15/99


Owner: TENNESSEE VALLEY AUTHORITY
Chattanooga Office Complex
1101 Market Street
Chattanooga, TN 37402

Plant: WATTS BAR NUCLEAR PLANT
P.O. Box 2000
Spring City, TN 37381-2000

Unit: 1
Commercial Service Date: May 27, 1996

Certificate of Authorization: N/A
National Board Number for Unit: N/A

CONCURRENCE AND APPROVAL SHEET

Name	Title	Signature	Date
Prepared by:			
K. E. Casey	ISI Program Engineer	_____	
Concurred by:			
T. L. Hale	ISO ISI/NDE Coordinator	_____	
J. W. Whitaker	ISO NDE Level III		
G. L. Johnson	System Pressure Test Engineer	_____	
E. D. Camp	Steam Generator Specialist	_____	
R. M. Emrath	Corporate Codes & ISI Manager	_____	
L. L. McCormick	Component Engineering Manager	_____	
Approved by:			
D. F. Helms	System Engineering Manager	_____	

Owner: TENNESSEE VALLEY AUTHORITY Chattanooga Office Complex 1101 Market Street Chattanooga, TN 37402	Plant: WATTS BAR NUCLEAR PLANT P.O. Box 2000 Spring City, TN 37381-2000
Unit: 1 Commercial Service Date: May 27, 1998	Certificate of Authorization: N/A National Board Number for Unit: N/A

CONCURRENCE AND APPROVAL SHEET

Name	Title	Signature	Date
Prepared by:			
K. E. Casey	ISI Program Engineer		
Concurred by:			
T. L. Hale	ISO ISI/NDE Coordinator		
J. W. Whitaker	ISO NDE Level III		
G. L. Johnson	System Pressure Test Engineer		
E. D. Camp	Steam Generator Specialist		
R. M. Emrath	Corporate Codes & ISI Manager	<i>Richard M Emrath</i>	06/15/99
L. L. McCormick	Component Engineering Manager		
Approved by:			
D. F. Helms	System Engineering Manager		

Owner: TENNESSEE VALLEY AUTHORITY Chattanooga Office Complex 1101 Market Street Chattanooga, TN 37402	Plant: WATTS BAR NUCLEAR PLANT P.O. Box 2000 Spring City, TN 37381-2000
Unit: 1 Commercial Service Date: May 27, 1996	Certificate of Authorization: N/A National Board Number for Unit: N/A

TABLE OF CONTENTS

Concurrence Sheet..... 2

Table of Contents..... 3

Cover Sheet..... 4

Form NIS-1 5

Form NIS-1 for ISI Examinations..... 5

Form NIS-1 for Steam Generator Tube Eddy Current Examinations..... 7

Form NIS-1 for Pressure Tests..... 9

Introduction and Summary of the Inspection..... 11

Summary of Requests for Relief..... 13

Appendices

Appendix I, ISI Examination Plan

Appendix II, Steam Generator Tube Eddy Current Summary

Appendix III, Pressure Test Reports Summary

Appendix IV, Report for Repairs and Replacements, Form NIS-2

Owner: TENNESSEE VALLEY AUTHORITY Chattanooga Office Complex 1101 Market Street Chattanooga, TN 37402	Plant: WATTS BAR NUCLEAR PLANT P.O. Box 2000 Spring City, TN 37381-2000
Unit: 1 Commercial Service Date: May 27, 1996	Certificate of Authorization: N/A National Board Number for Unit: N/A

Cover Sheet

Owner: Tennessee Valley Authority

Address of Corporate Office: Chattanooga Office Complex
1101 Market Street
Chattanooga, Tennessee 37402-2801

Name and Address of Nuclear Power Plant: Watts Bar Nuclear Plant
P.O. Box 2000
Spring City, Tennessee 37381-2000

Applicable Nuclear Power Units: Watts Bar Nuclear Plant, Unit 1

Commercial Operation Date: May 27, 1996

Document Completion Date: June 7, 1999

Owner: TENNESSEE VALLEY AUTHORITY Chattanooga Office Complex 1101 Market Street Chattanooga, TN 37402	Plant: WATTS BAR NUCLEAR PLANT P.O. Box 2000 Spring City, TN 37381-2000
Unit: 1 Commercial Service Date: May 27, 1996	Certificate of Authorization: N/A National Board Number for Unit: N/A

NIS-1 FOR THE ISI EXAMINATION PLAN

FORM NIS-1 OWNERS' REPORT FOR INSERVICE INSPECTIONS
As required by the Provisions of the ASME Code Rules

1. Owner Tennessee Valley Authority, 1101 Market St. Chattanooga, TN 37401-2801
(Name and Address of Owner)
2. Plant Watts Bar Nuclear Plant, P.O. Box 2000, Spring City, TN 37381-2000
(Name and Address of Plant)
3. Plant Unit One (1) 4. Owner Certificate of Authorization (if required) Not Required
5. Commercial Service Date May 27, 1996 6. National Board Number for Unit None Assigned
7. Components Inspected

Component or Appurtenance	Manufacturer or Installer	Manufacturer or Installer Serial No.	State or Province No.	National Board No.
See Appendix I, Examination Plan, for List of Components	Tennessee Valley Authority	N/A	N/A	N/A

Note: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

Owner: TENNESSEE VALLEY AUTHORITY Chattanooga Office Complex 1101 Market Street Chattanooga, TN 37402	Plant: WATTS BAR NUCLEAR PLANT P.O. Box 2000 Spring City, TN 37381-2000
Unit: 1 Commercial Service Date: May 27, 1996	Certificate of Authorization: N/A National Board Number for Unit: N/A

FORM NIS-1 (Back)

- 8. Examination Dates: October 1, 1997 to April 16, 1999
- 9. Inspection Period Identification: First
- 10. Inspection Interval Identification: First
- 11. Applicable Edition of Section XI: 1989 Addenda N/A
- 12. Date/Revision of Inspection Plan: November 17, 1998/1-TRI-0-10, Revision 3
- 13. Abstract of Examinations and Tests. Include a list of examinations and tests and a statement concerning status of work required for the Inspection Plan. See Appendix I
- 14. Abstract of Results of Examinations and Tests. See Appendix I
- 15. Abstract of Corrective Measures. See Summary of Notification of Indications (NOIs)

We certify that a) the statements made in this report are correct, b) the examinations and tests meet the Inspection Plan as required by the ASME Code, Section XI, and c) corrective measures taken conform to the rules of the ASME Code, Section XI.

Certificate of Authorization No. (if applicable) N/A Expiration Date N/A
 Date 6/7 19 99 Signed Tennessee Valley Authority By [Signature]
Owner

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I&I Co. of Hartford CT. have inspected the components described in this Owners' Data Report during the period 2/27/99 to 4/15/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and tests and taken corrective measures described in this Owner's Report in accordance with the Inspection Plan and as required by the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations, and tests, and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce M. Emigh Commissions NB 8333 TN 2534 "I" "N" "A"
Inspector's Signature National Board, State, Province and Endorsements

Date 6/15/ 19 99

Owner: TENNESSEE VALLEY AUTHORITY Chattanooga Office Complex 1101 Market Street Chattanooga, TN 37402	Plant: WATTS BAR NUCLEAR PLANT P.O. Box 2000 Spring City, TN 37381-2000
Unit: 1 Commercial Service Date: May 27, 1996	Certificate of Authorization: N/A National Board Number for Unit: N/A

NIS-1 FOR STEAM GENERATOR TUBE EDDY CURRENT EXAMINATIONS

FORM NIS-1 OWNERS' REPORT FOR INSERVICE INSPECTIONS

As required by the Provisions of the ASME Code Rules

1. Owner Tennessee Valley Authority, 1101 Market St. Chattanooga, TN 37401-2801
 (Name and Address of Owner)
2. Plant Watts Bar Nuclear Plant, P.O. Box 2000, Spring City, TN 37381-2000
 (Name and Address of Plant)
3. Plant Unit One (1) 4. Owner Certificate of Authorization (if required) Not Required
5. Commercial Service Date May 27, 1996 6. National Board Number for Unit None Assigned
7. Components Inspected

Component or Appurtenance	Manufacturer or Installer	Manufacturer or Installer Serial No.	State or Province No.	National Board No.
See Appendix II, Steam Generator Tube Examination Summary	Tennessee Valley Authority	N/A	N/A	N/A
1-SGEN-068-SG1	Westinghouse Electric Corp	1591	N/A	W10286
1-SGEN-068-SG2	Westinghouse Electric Corp	1592	N/A	W10287
1-SGEN-068-SG3	Westinghouse Electric Corp	1593	N/A	W10288
1-SGEN-068-SG4	Westinghouse Electric Corp	1594	N/A	W10289

Note: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

Owner: TENNESSEE VALLEY AUTHORITY Chattanooga Office Complex 1101 Market Street Chattanooga, TN 37402	Plant: WATTS BAR NUCLEAR PLANT P. O. Box 2000 Spring City, TN 37381-2000
Unit: 1 Commercial Service Date: May 27, 1996	Certificate of Authorization: N/A National Board Number for Unit: N/A

FORM NIS-1 (Back)

- 8. Examination Dates: March 10, 1999 to March 29, 1999
- 9. Inspection Period Identification: First
- 10. Inspection Interval Identification: First
- 11. Applicable Edition of Section XI: 1989 Addenda N/A
- 12. Date/Revision of Inspection Plan: March 8, 1999/1-SI-68-907, Revision 4
- 13. Abstract of Examinations and Tests. Include a list of examinations and tests and a statement concerning status of work required for the Inspection Plan. See Appendix II
- 14. Abstract of Results of Examinations and Tests. See Appendix II
- 15. Abstract of Corrective Measures. See Appendix II

We certify that a) the statements made in this report are correct, b) the examinations and tests meet the Inspection Plan as required by the ASME Code, Section XI, and c) corrective measures taken conform to the rules of the ASME Code, Section XI.

Certificate of Authorization No. (if applicable) N/A Expiration Date N/A
 Date June 7, 19 99 Signed Tennessee Valley Authority By Emmett Coyle
Owner

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I E I Co. of HARTFORD CT. have inspected the components described in this Owners' Data Report during the period 2/27/99 to 6/15/99, and state that to the best of my knowledge and belief, the Owner has performed examinations and tests and taken corrective measures described in this Owner's Report in accordance with the Inspection Plan and as required by the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations, and tests, and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce M. Earnigh
 Inspector's Signature

Commissions NB 8333 TN 2534 "I" "N" "A"
 National Board, State, Province and Endorsements

Date 6/15 19 99

Owner: TENNESSEE VALLEY AUTHORITY
Chattanooga Office Complex
1101 Market Street
Chattanooga, TN 37402
Unit: 1
Commercial Service Date: May 27, 1996

Plant: WATTS BAR NUCLEAR PLANT
P.O. Box 2000
Spring City, TN 37381-2000
Certificate of Authorization: N/A
National Board Number for Unit: N/A

NIS-1 FOR PRESSURE TESTS

FORM NIS-1 OWNERS' REPORT FOR INSERVICE INSPECTIONS
As required by the Provisions of the ASME Code Rules

1. Owner Tennessee Valley Authority, 1101 Market St. Chattanooga, TN 37401-2801
(Name and Address of Owner)
2. Plant Watts Bar Nuclear Plant, P.O. Box 2000, Spring City, TN 37381-2000
(Name and Address of Plant)
3. Plant Unit One (1) 4. Owner Certificate of Authorization (if required) Not Required
5. Commercial Service Date May 27, 1996 6. National Board Number for Unit None Assigned
7. Components Inspected

Component or Appurtenance	Manufacturer or Installer	Manufacturer or Installer Serial No.	State or Province No.	National Board No.
See Appendix III, Pressure Test Summary	Tennessee Valley Authority	N/A	N/A	N/A

Note: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

Owner: TENNESSEE VALLEY AUTHORITY
Chattanooga Office Complex
1101 Market Street
Chattanooga, TN 37402

Plant: WATTS BAR NUCLEAR PLANT
P.O. Box 2000
Spring City, TN 37381-2000

Unit: 1
Commercial Service Date: May 27, 1996

Certificate of Authorization: N/A
National Board Number for Unit: N/A

FORM NIS-1 (Back)

- 8. Examination Dates: October 21, 1997 to April 16, 1999
- 9. Inspection Period Identification: First
- 10. Inspection Interval Identification: First
- 11. Applicable Edition of Section XI: 1989 Addenda N/A
- 12. Date/Revision of Inspection Plan: September 29, 1997/TI-100.009, Revision 0
- 13. Abstract of Examinations and Tests. Include a list of examinations and tests and a statement concerning status of work required for the Inspection Plan. See Appendix III
- 14. Abstract of Results of Examinations and Tests. See Appendix III
- 15. Abstract of Corrective Measures. See Appendix III

We certify that a) the statements made in this report are correct, b) the examinations and tests meet the Inspection Plan as required by the ASME Code, Section XI, and c) corrective measures taken conform to the rules of the ASME Code, Section XI.

Certificate of Authorization No. (if applicable) N/A Expiration Date N/A
Date JUNE 8 19 99 Signed Tennessee Valley Authority By [Signature]
Owner

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I E I Co. of HARTFORD CT. have inspected the components described in this Owners' Data Report during the period 2/27/99 to 6/15/99, and state that to the best of my knowledge and belief, the Owner has performed examinations and tests and taken corrective measures described in this Owner's Report in accordance with the Inspection Plan and as required by the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations, and tests, and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce M. Eamigh Commissions NB 8333 "I" "N" "A"
Inspector's Signature TN 2534
National Board, State, Province and Endorsements

Date 6/15 19 99

Owner: TENNESSEE VALLEY AUTHORITY Chattanooga Office Complex 1101 Market Street Chattanooga, TN 37402	Plant: WATTS BAR NUCLEAR PLANT P.O. Box 2000 Spring City, TN 37381-2000
Unit: 1 Commercial Service Date: May 27, 1996	Certificate of Authorization: N/A National Board Number for Unit: N/A

INTRODUCTION AND SUMMARY

Introduction

As required by ASME Section XI, IWA-6200, this summary report documents the results of the ASME Section XI examinations, tests, repairs and replacements performed during the second cycle of operation of TVA's Watts Bar Nuclear Plant's Unit 1. The cycle 2 refueling outage is the second of two outages in the First Period of the First Inspection Interval. The First Period ended May 26, 1999. Examinations performed this cycle completes the ISI examinations required for the First Period. System pressure tests required for the First Period that will be completed after the cycle 2 refueling outage will be reported in the cycle 3 summary report.

Included in this cycle 2 Summary Report is: the summary of ISI examinations and results; summary of steam generator tube eddy current examinations and results; summary of pressure tests and results; and, summary of repairs and replacements as documented on ASME Form NIS-2s.

Summary

ISI examinations were performed in accordance with Technical Requirement Instruction 1-TRI-0-10, "ASME Section XI ISI/NDE Program." Table 1 provides an overview of the ISI examinations that were performed during cycle 2. The results of all the examinations met the applicable acceptance standards. Examination of 4 steam generator nozzle-to-safe end butt welds and the reactor vessel head-to-flange weld require that requests for relief be prepared as the required code coverage could not be obtained. The examination results for the ISI components are summarized in Appendix I.

As noted, these examinations complete the required examinations for the first period as documented in the ASME Section XI ISI/NDE Program, 1-TRI-0-10, Revision 3. ISI credit for two components reported in the Cycle 1 Summary Report has been revised and are not included in the first period. The examinations performed on the Containment Spray Heat Exchanger Nozzle Welds and the Centrifugal Charging Pump Integrally Welded Attachments will not be used for first period ISI credit. This includes the following ISI identifiers: CSHX-NZ-IN-1A, CSHX-NZ-OUT-1A, and CCPH-1B-B-IA.

Eddy current testing of the steam generator tubes was performed in accordance with Surveillance Instruction 1-SI-68-907, "Steam Generator Tubing Inservice Inspection and Augmented Inspection." Twenty-one tubes were plugged as a result of this inspection. The results are summarized in Appendix II.

Appendix III provides a summary of the system pressure tests performed for code credit during cycle 2. System pressure tests are implemented as defined in Technical Instruction 100.009, "ASME Section XI System Pressure Testing Program Basis Document." Individual system pressure test procedures are listed in the summary.

Appendix IV provides a summary of the repairs and replacements performed during the second cycle. Included are the ASME Form NIS-2s, "Owners Report for Repair and Replacements." Repairs and replacements are documented in accordance with Standard Programs and Processes (SPP) 9.1, Part D, "Repair/Replacement of ASME Section XI Components."

Owner: TENNESSEE VALLEY AUTHORITY
 Chattanooga Office Complex
 1101 Market Street
 Chattanooga, TN 37402

Plant: WATTS BAR NUCLEAR PLANT
 P.O. Box 2000
 Spring City, TN 37381-2000

Unit: 1
 Commercial Service Date: May 27, 1996

Certificate of Authorization: N/A
 National Board Number for Unit: N/A

TABLE 1
 SUMMARY OF CYCLE 2 ISI EXAMINATIONS

Examination Category	Item Number	Component Description	Number Examined
B-A	B1.40	Reactor Vessel Head-to-Flange Weld	1
B-B	B2.40	Steam Generator Tubesheet-to-Head Weld	2
B-D	B3.90	Reactor Vessel Nozzle-to-Vessel Weld	4
	B3.100	Reactor Vessel Nozzle Inside Radius Section	4
	B3.140	Steam Generator Primary Nozzle Inside Radius Section	4
B-F	B5.10	Reactor Vessel Nozzle-to-Safe End Dissimilar Metal Butt Weld NPS 4 or Larger	4
	B5.70	Steam Generator Nozzle-to-Safe End Dissimilar Metal Butt Weld NPS 4 or Larger	4
B-G-1	B6.10	Reactor Vessel Closure Head Nuts	18
	B6.30	Reactor Vessel Closure Studs, when removed	18
	B6.40	Reactor Vessel Threads in Flange	18
	B6.50	Reactor Vessel Closure Washers	18
B-G-2	B7.50	Pipe Pressure Retaining Bolting, 2" and less is diameter	2
	B7.70	Valve Bolts, Studs, and Nuts less than equal 2" diameter	1
B-J	Pressure Retaining Welds in Piping		
	B9.11	Circumferential Welds NPS 4 or Larger	24
	B9.21	Circumferential Welds Less than NPS 4	13
	B9.31	Branch Pipe Connection Welds NPS 4 or Larger	1
B9.32	Branch Pipe Connection Welds Less than NPS 4	3	
B-M-2	B12.50	Valve Body	1
B-K of Code Case N-509	B10.20	Piping Integrally Welded Attachment	1
F-A of Code Case N-491	Supports		
	F1.10	Piping Supports	25
	F1.40	Valve Supports	3
C-B	C2.21	RHR Heat Exchanger Nozzles without Reinforcing Plate in Vessels greater than 1/2" thickness	2
C-B	C2.22	RHR Heat Exchanger Nozzle Inside Radius Section	2
C-G	C6.20	Valve Body Welds	1
F-A of Code Case N-491	F1.40	Steam Generator Secondary Side Support	1

Owner: TENNESSEE VALLEY AUTHORITY Chattanooga Office Complex 1101 Market Street Chattanooga, TN 37402	Plant: WATTS BAR NUCLEAR PLANT P.O. Box 2000 Spring City, TN 37381-2000
Unit: 1 Commercial Service Date: May 27, 1996	Certificate of Authorization: N/A National Board Number for Unit: N/A

**SUMMARY OF
REQUESTS FOR RELIEF (RFRs)**

Two RFRs are required to be written for ISI components examined during this inspection. The RFRs summarized below are required as the result of not obtaining code coverage due to limitations. The RFRs will be submitted under separate letter to the NRC.

Proposed RFR 1-ISI-05

ISI Component Number(s): RCF-D2-2-SE, RCF-D4-2-SE, RCF-F2-1-SE, RCF-F3-1-SE

Component Description: Steam Generator Nozzle-to-Safe End Butt Weld

Examination Category/Item No.: B-F, B5.70

Report Numbers: R0385, R0401, R0384, R0393

Summary: Due to geometric configuration of the steam generator nozzles, volumetric examination of four nozzle-to-safe end butt welds during the Unit 1 Cycle 2 refueling outage resulted in less than 100% of ASME code coverage being achieved. The geometric configuration of the nozzle prevents the performance of an ultrasonic scan from the generator side of the weld, thus preventing 100% examination of the required lower one-third volume. A surface examination was performed on each of the four welds and was found acceptable. Volumetric examination of this component is required in accordance with ASME Section XI Table IWB-2500-1, Examination Category B-F, Item Number B5.70. The lower one-third volume weld examination requirement is defined by Figure IWB-2500-8(c).

Proposed RFR 1-ISI-06

ISI Component Number(s): W08-09-A

Component Description: Reactor Vessel Head-to-Flange Weld

Examination Category/Item No.: B-A, B1.40

Report Number: R0512

Summary: Due to geometric configuration of the reactor vessel head, volumetric examination of the head-to-flange weld during the Unit 1 Cycle 2 refueling outage resulted in less than 100% of ASME code coverage being achieved. The geometric configuration at the taper of the flange-to-head weld prevents the performance of an ultrasonic scan from the flange side of the weld, thus preventing 100% examination of the required full volume. The required surface examination was performed and was found acceptable. Volumetric examination of this component is required in accordance with Table IWB-2500-1, Examination Category B-A, Item Number B1.40. The full examination volume requirement is defined by Figure IWB-2500-5.

Owner: TENNESSEE VALLEY AUTHORITY Chattanooga Office Complex 1101 Market Street Chattanooga, TN 37402	Plant: WATTS BAR NUCLEAR PLANT P.O. Box 2000 Spring City, TN 37381-2000
Unit: 1 Commercial Service Date: May 27, 1996	Certificate of Authorization: N/A National Board Number for Unit: N/A

**APPENDIX I
CYCLE 2 ISI EXAMINATION PLAN**

The following examination plan provides the list and results of examinations performed during the second cycle. This plan is sorted by examination category and item number and system. The headings are defined below:

System	System Title Abbreviation																				
	<table border="0"> <tr> <td>AFWS</td> <td>Auxiliary Feedwater System</td> <td>RV</td> <td>Reactor Vessel</td> </tr> <tr> <td>CVCS</td> <td>Chemical Volume and Control System</td> <td>RHRS</td> <td>Residual Heat Removal System</td> </tr> <tr> <td>FWS</td> <td>Feedwater System</td> <td>RX</td> <td>Main Loop Reactor Coolant System</td> </tr> <tr> <td>MSS</td> <td>Main Steam System</td> <td>SG</td> <td>Steam Generator</td> </tr> <tr> <td>RCS</td> <td>Reactor Coolant System</td> <td>SIS</td> <td>Safety Injection System</td> </tr> </table>	AFWS	Auxiliary Feedwater System	RV	Reactor Vessel	CVCS	Chemical Volume and Control System	RHRS	Residual Heat Removal System	FWS	Feedwater System	RX	Main Loop Reactor Coolant System	MSS	Main Steam System	SG	Steam Generator	RCS	Reactor Coolant System	SIS	Safety Injection System
AFWS	Auxiliary Feedwater System	RV	Reactor Vessel																		
CVCS	Chemical Volume and Control System	RHRS	Residual Heat Removal System																		
FWS	Feedwater System	RX	Main Loop Reactor Coolant System																		
MSS	Main Steam System	SG	Steam Generator																		
RCS	Reactor Coolant System	SIS	Safety Injection System																		
Component Number	ISI Component Identifier																				
ISO Drawing	ISI Drawing Number																				
Category	Code Examination Category																				
Item Number	Code Item Number																				
Exam Requirement	Examination Requirement																				
	<table border="0"> <tr> <td>89E-01</td> <td>Item examined per the requirements of the 1989 Edition of ASME Section XI for first interval code credit</td> </tr> <tr> <td>P89001</td> <td>Item examined per the requirements of the 1989 Edition of ASME Section XI for preservice credit (i.e. repaired/replaced item)</td> </tr> <tr> <td>SR1-01</td> <td>Supplemental examination</td> </tr> </table>	89E-01	Item examined per the requirements of the 1989 Edition of ASME Section XI for first interval code credit	P89001	Item examined per the requirements of the 1989 Edition of ASME Section XI for preservice credit (i.e. repaired/replaced item)	SR1-01	Supplemental examination														
89E-01	Item examined per the requirements of the 1989 Edition of ASME Section XI for first interval code credit																				
P89001	Item examined per the requirements of the 1989 Edition of ASME Section XI for preservice credit (i.e. repaired/replaced item)																				
SR1-01	Supplemental examination																				
Exam Scheduled	Required Examination Method																				
NDE Procedure	TVA NDE Procedure Number																				
Calibration Standard	Calibration Standard Identifier																				
Component Diameter	Component Diameter																				
Nominal Thickness	Component Thickness																				
Exam Date	Date Examination Performed																				
Exam Report	Examination Report Number																				
Exam Results	Results of the Examination																				
	<table border="0"> <tr> <td>P</td> <td>= PASS, examination met the applicable acceptance standards</td> </tr> <tr> <td>F</td> <td>= FAIL, examination did not meet the applicable acceptance standards and was repaired or replaced</td> </tr> <tr> <td>E</td> <td>= EVALUATION, examination did not meet the applicable acceptance standards but was accepted by evaluation</td> </tr> </table>	P	= PASS, examination met the applicable acceptance standards	F	= FAIL, examination did not meet the applicable acceptance standards and was repaired or replaced	E	= EVALUATION, examination did not meet the applicable acceptance standards but was accepted by evaluation														
P	= PASS, examination met the applicable acceptance standards																				
F	= FAIL, examination did not meet the applicable acceptance standards and was repaired or replaced																				
E	= EVALUATION, examination did not meet the applicable acceptance standards but was accepted by evaluation																				
Comments	Applicable Comments																				

Owner: TENNESSEE VALLEY AUTHORITY
 Chattanooga Office Complex
 1101 Market Street
 Chattanooga, TN 37402

Plant: WATTS BAR NUCLEAR PLANT
 P.O. Box 2000
 Spring City, TN 37381-2000

Unit: 1
 Commercial Service Date: May 27, 1996

Certificate of Authorization: N/A
 National Board Number for Unit: N/A

System	Component Number	ISO Drawing	Category	Item Number	Exam Requirement	Exam Scheduled	NDE Procedure	Calibration Standard	Component Diameter	Nominal Thickness	Exam Date	Exam Report	Exam Results	Comments
RV	W08-09-A	CHM-2549-C 01	B-A	B1.40	89E-01	MT	N-MT-6			6.890	19990318	R0512	P	Limited Coverage/RFR 1-ISI-6
RV	W08-09-A	CHM-2549-C 01	B-A	B1.40	89E-01	UT	VENDOR	WB-51		6.890	19990318	R0512	P	Limited Coverage/RFR 1-ISI-6
SG	SG-1-2-2	CHM-2660-C 01	B-B	B2.40	89E-01	UT	N-UT-19	WB-57		5.000	19990303	R0435	P	
SG	SG-1-2-3	CHM-2660-C 01	B-B	B2.40	89E-01	UT	N-UT-19	WB-57		5.000	19990311	R0436	P	
RV	N15-IR	ISI-0427-C 01	B-D	B3.100	89E-01	UT	VENDOR	WB-49	28.94		19990316	R0512	P	SWRI REPORT 000600
RV	N16-IR	ISI-0427-C 01	B-D	B3.100	89E-01	UT	VENDOR	WB-49	28.94		19990316	R0512	P	SWRI REPORT 000700
RV	N17-IR	ISI-0427-C 01	B-D	B3.100	89E-01	UT	VENDOR	WB-49	28.94		19990316	R0512	P	SWRI REPORT 000800
RV	N18-IR	ISI-0427-C 01	B-D	B3.100	89E-01	UT	VENDOR	WB-49	28.94		19990316	R0512	P	SWRI REPORT 000900
SG	SG-2-C-IR	CHM-2660-C 01	B-D	B3.140	89E-01	UT	N-UT-55	SQ-59			19990306	R0389	P	
SG	SG-2-H-IR	CHM-2660-C 01	B-D	B3.140	89E-01	UT	N-UT-55	SQ-59			19990306	R0390	P	
SG	SG-3-C-IR	CHM-2660-C 01	B-D	B3.140	89E-01	UT	N-UT-55	SQ-59			19990306	R0387	P	
SG	SG-3-H-IR	CHM-2660-C 01	B-D	B3.140	89E-01	UT	N-UT-55	SQ-59			19990306	R0388	P	
RV	N15	ISI-0427-C 01	B-D	B3.90	89E-01	UT	VENDOR	SQ-53	28.94		19990316	R0512	P	SWRI REPORT 000200
RV	N16	ISI-0427-C 01	B-D	B3.90	89E-01	UT	VENDOR	SQ-53	28.94		19990316	R0512	P	SWRI REPORT 000300
RV	N17	ISI-0427-C 01	B-D	B3.90	89E-01	UT	VENDOR	SQ-53	28.94		19990316	R0512	P	SWRI REPORT 000400
RV	N18	ISI-0427-C 01	B-D	B3.90	89E-01	UT	VENDOR	SQ-53	28.94		19990316	R0512	P	SWRI REPORT 000500
RV	N15-SE	ISI-0427-C 06	B-F	B5.10	89E-01	PT	N-PT-9		29.00	2.450	19990317	R0494	P	
RV	N15-SE	ISI-0427-C 06	B-F	B5.10	89E-01	UT	VENDOR	WB-60	29.00	2.450	19990316	R0512	P	SWRI REPORT 001000
RV	N16-SE	ISI-0427-C 06	B-F	B5.10	89E-01	PT	N-PT-9		29.00	2.450	19990317	R0492	P	
RV	N16-SE	ISI-0427-C 06	B-F	B5.10	89E-01	UT	VENDOR	WB-60	29.00	2.450	19990316	R0512	P	SWRI REPORT 001100
RV	N17-SE	ISI-0427-C 06	B-F	B5.10	89E-01	PT	N-PT-9		29.00	2.450	19990317	R0499	P	
RV	N17-SE	ISI-0427-C 06	B-F	B5.10	89E-01	UT	VENDOR	WB-60	29.00	2.450	19990316	R0512	P	SWRI REPORT 001200
RV	N18-SE	ISI-0427-C 06	B-F	B5.10	89E-01	PT	N-PT-9		29.00	2.450	19990317	R0496	P	
RV	N18-SE	ISI-0427-C 06	B-F	B5.10	89E-01	UT	VENDOR	WB-60	29.00	2.450	19990316	R0512	P	SWRI REPORT 001300
SG	RCF-D2-2-SE	CHM-2547-C 01	B-F	B5.70	89E-01	PT	N-PT-9		31.00	2.600	19990303	R0381	P	
SG	RCF-D2-2-SE	CHM-2547-C 01	B-F	B5.70	89E-01	UT	N-UT-33	WB-60	31.00	2.600	19990304	R0385	P	LIMITED TO 65% COVERAGE / RFR 1-ISI-5
SG	RCF-D4-2-SE	CHM-2547-C 01	B-F	B5.70	89E-01	PT	N-PT-9		31.00	2.600	19990304	R0386	P	
SG	RCF-D4-2-SE	CHM-2547-C 01	B-F	B5.70	89E-01	UT	N-UT-33	WB-60	31.00	2.600	19990304	R0401	P	LIMITED TO 75% COVERAGE / RFR 1-ISI-5
SG	RCF-F2-1-SE	CHM-2547-C 01	B-F	B5.70	89E-01	PT	N-PT-9		31.00	2.600	19990303	R0377	P	
SG	RCF-F2-1-SE	CHM-2547-C 01	B-F	B5.70	89E-01	UT	N-UT-33	WB-60	31.00	2.600	19990304	R0384	P	LIMITED TO 75% COVERAGE / RFR 1-ISI-5
SG	RCF-F3-1-SE	CHM-2547-C 01	B-F	B5.70	89E-01	PT	N-PT-9		31.00	2.600	19990304	R0383	P	

Owner: TENNESSEE VALLEY AUTHORITY
 Chattanooga Office Complex
 1101 Market Street
 Chattanooga, TN 37402

Plant: WATTS BAR NUCLEAR PLANT
 P.O. Box 2000
 Spring City, TN 37381-2000

Unit: 1
 Commercial Service Date: May 27, 1996

Certificate of Authorization: N/A
 National Board Number for Unit: N/A

System	Component Number	ISO Drawing	Category	Item Number	Exam Requirement	Exam Scheduled	NDE Procedure	Calibration Standard	Component Diameter	Nominal Thickness	Exam Date	Exam Report	Exam Results	Comments
SG	RCF-F3-1-SE	CHM-2547-C 01	B-F	B5.70	89E-01	UT	N-UT-33	WB-60	31.00	2.600	19990304	R0393	P	LIMITED TO 75% COVERAGE / RFR 1-ISI-5
RV	RVNUT-01	ISI-0427-C 03	B-G-1	B6.10	89E-01	MT	N-MT-6		07.00	07.09	19990319	R0512	P	SWRI REPORT MT002/MT004
RV	RVNUT-02	ISI-0427-C 03	B-G-1	B6.10	89E-01	MT	N-MT-6		07.00	07.09	19990319	R0512	P	SWRI REPORT MT002/MT004
RV	RVNUT-03	ISI-0427-C 03	B-G-1	B6.10	89E-01	MT	N-MT-6		07.00	07.09	19990319	R0512	P	SWRI REPORT MT002/MT004
RV	RVNUT-04	ISI-0427-C 03	B-G-1	B6.10	89E-01	MT	N-MT-6		07.00	07.09	19990319	R0512	P	SWRI REPORT MT002/MT004
RV	RVNUT-05	ISI-0427-C 03	B-G-1	B6.10	89E-01	MT	N-MT-6		07.00	07.09	19990319	R0512	P	SWRI REPORT MT002/MT004
RV	RVNUT-06	ISI-0427-C 03	B-G-1	B6.10	89E-01	MT	N-MT-6		07.00	07.09	19990319	R0512	P	SWRI REPORT MT002/MT004
RV	RVNUT-07	ISI-0427-C 03	B-G-1	B6.10	89E-01	MT	N-MT-6		07.00	07.09	19990319	R0512	P	SWRI REPORT MT002/MT004
RV	RVNUT-08	ISI-0427-C 03	B-G-1	B6.10	89E-01	MT	N-MT-6		07.00	07.09	19990319	R0512	P	SWRI REPORT MT002/MT004
RV	RVNUT-09	ISI-0427-C 03	B-G-1	B6.10	89E-01	MT	N-MT-6		07.00	07.09	19990319	R0512	P	SWRI REPORT MT002/MT004
RV	RVNUT-10	ISI-0427-C 03	B-G-1	B6.10	89E-01	MT	N-MT-6		07.00	07.09	19990319	R0512	P	SWRI REPORT MT002/MT004
RV	RVNUT-11	ISI-0427-C 03	B-G-1	B6.10	89E-01	MT	N-MT-6		07.00	07.09	19990319	R0512	P	SWRI REPORT MT002/MT004
RV	RVNUT-12	ISI-0427-C 03	B-G-1	B6.10	89E-01	MT	N-MT-6		07.00	07.09	19990319	R0512	P	SWRI REPORT MT002/MT004
RV	RVNUT-13	ISI-0427-C 03	B-G-1	B6.10	89E-01	MT	N-MT-6		07.00	07.09	19990319	R0512	P	SWRI REPORT MT002/MT004
RV	RVNUT-14	ISI-0427-C 03	B-G-1	B6.10	89E-01	MT	N-MT-6		07.00	07.09	19990319	R0512	P	SWRI REPORT MT002/MT004
RV	RVNUT-15	ISI-0427-C 03	B-G-1	B6.10	89E-01	MT	N-MT-6		07.00	07.09	19990319	R0512	P	SWRI REPORT MT002/MT004
RV	RVNUT-16	ISI-0427-C 03	B-G-1	B6.10	89E-01	MT	N-MT-6		07.00	07.09	19990319	R0512	P	SWRI REPORT MT002/MT004
RV	RVNUT-17	ISI-0427-C 03	B-G-1	B6.10	89E-01	MT	N-MT-6		07.00	07.09	19990319	R0512	P	SWRI REPORT MT002/MT004
RV	RVNUT-18	ISI-0427-C 03	B-G-1	B6.10	89E-01	MT	N-MT-6		07.00	07.09	19990319	R0512	P	SWRI REPORT MT002/MT004
RV	RVSTUD-01	ISI-0427-C 03	B-G-1	B6.30	89E-01	MT	N-MT-6		07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT MT001/MT003
RV	RVSTUD-01	ISI-0427-C 03	B-G-1	B6.30	89E-01	UT	N-UT-37	WB-76	07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT UT0001
RV	RVSTUD-02	ISI-0427-C 03	B-G-1	B6.30	89E-01	MT	N-MT-6		07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT MT001/MT003
RV	RVSTUD-02	ISI-0427-C 03	B-G-1	B6.30	89E-01	UT	N-UT-37	WB-76	07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT UT0001
RV	RVSTUD-03	ISI-0427-C 03	B-G-1	B6.30	89E-01	MT	N-MT-6		07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT MT001/MT003
RV	RVSTUD-03	ISI-0427-C 03	B-G-1	B6.30	89E-01	UT	N-UT-37	WB-76	07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT UT0001
RV	RVSTUD-04	ISI-0427-C 03	B-G-1	B6.30	89E-01	MT	N-MT-6		07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT MT001/MT003
RV	RVSTUD-04	ISI-0427-C 03	B-G-1	B6.30	89E-01	UT	N-UT-37	WB-76	07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT UT0001
RV	RVSTUD-05	ISI-0427-C 03	B-G-1	B6.30	89E-01	MT	N-MT-6		07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT MT001/MT003
RV	RVSTUD-05	ISI-0427-C 03	B-G-1	B6.30	89E-01	UT	N-UT-37	WB-76	07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT UT0001
RV	RVSTUD-06	ISI-0427-C 03	B-G-1	B6.30	89E-01	MT	N-MT-6		07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT MT001/MT003
RV	RVSTUD-06	ISI-0427-C 03	B-G-1	B6.30	89E-01	UT	N-UT-37	WB-76	07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT UT0001

Owner: TENNESSEE VALLEY AUTHORITY
 Chattanooga Office Complex
 1101 Market Street
 Chattanooga, TN 37402

Plant: WATTS BAR NUCLEAR PLANT
 P.O. Box 2000
 Spring City, TN 37381-2000

Unit: 1
 Commercial Service Date: May 27, 1996

Certificate of Authorization: N/A
 National Board Number for Unit: N/A

System	Component Number	ISO Drawing	Category	Item Number	Exam Requirement	Exam Scheduled	NDE Procedure	Calibration Standard	Component Diameter	Nominal Thickness	Exam Date	Exam Report	Exam Results	Comments
RV	RVSTUD-07	ISI-0427-C 03	B-G-1	B6.30	89E-01	MT	N-MT-6		07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT MT001/MT003
RV	RVSTUD-07	ISI-0427-C 03	B-G-1	B6.30	89E-01	UT	N-UT-37	WB-76	07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT UT0001
RV	RVSTUD-08	ISI-0427-C 03	B-G-1	B6.30	89E-01	MT	N-MT-6		07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT MT001/MT003
RV	RVSTUD-08	ISI-0427-C 03	B-G-1	B6.30	89E-01	UT	N-UT-37	WB-76	07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT UT0001
RV	RVSTUD-09	ISI-0427-C 03	B-G-1	B6.30	89E-01	MT	N-MT-6		07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT MT001/MT003
RV	RVSTUD-09	ISI-0427-C 03	B-G-1	B6.30	89E-01	UT	N-UT-37	WB-76	07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT UT0001
RV	RVSTUD-10	ISI-0427-C 03	B-G-1	B6.30	89E-01	MT	N-MT-6		07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT MT001/MT003
RV	RVSTUD-10	ISI-0427-C 03	B-G-1	B6.30	89E-01	UT	N-UT-37	WB-76	07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT UT0001
RV	RVSTUD-11	ISI-0427-C 03	B-G-1	B6.30	89E-01	MT	N-MT-6		07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT MT001/MT003
RV	RVSTUD-11	ISI-0427-C 03	B-G-1	B6.30	89E-01	UT	N-UT-37	WB-76	07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT UT0001
RV	RVSTUD-12	ISI-0427-C 03	B-G-1	B6.30	89E-01	MT	N-MT-6		07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT MT001/MT003
RV	RVSTUD-12	ISI-0427-C 03	B-G-1	B6.30	89E-01	UT	N-UT-37	WB-76	07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT UT0001
RV	RVSTUD-13	ISI-0427-C 03	B-G-1	B6.30	89E-01	MT	N-MT-6		07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT MT001/MT003
RV	RVSTUD-13	ISI-0427-C 03	B-G-1	B6.30	89E-01	UT	N-UT-37	WB-76	07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT UT0001
RV	RVSTUD-14	ISI-0427-C 03	B-G-1	B6.30	89E-01	MT	N-MT-6		07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT MT001/MT003
RV	RVSTUD-14	ISI-0427-C 03	B-G-1	B6.30	89E-01	UT	N-UT-37	WB-76	07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT UT0001
RV	RVSTUD-15	ISI-0427-C 03	B-G-1	B6.30	89E-01	MT	N-MT-6		07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT MT001/MT003
RV	RVSTUD-15	ISI-0427-C 03	B-G-1	B6.30	89E-01	UT	N-UT-37	WB-76	07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT UT0001
RV	RVSTUD-16	ISI-0427-C 03	B-G-1	B6.30	89E-01	MT	N-MT-6		07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT MT001/MT003
RV	RVSTUD-16	ISI-0427-C 03	B-G-1	B6.30	89E-01	UT	N-UT-37	WB-76	07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT UT0001
RV	RVSTUD-17	ISI-0427-C 03	B-G-1	B6.30	89E-01	MT	N-MT-6		07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT MT001/MT003
RV	RVSTUD-17	ISI-0427-C 03	B-G-1	B6.30	89E-01	UT	N-UT-37	WB-76	07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT UT0001
RV	RVSTUD-18	ISI-0427-C 03	B-G-1	B6.30	89E-01	MT	N-MT-6		07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT MT001/MT003
RV	RVSTUD-18	ISI-0427-C 03	B-G-1	B6.30	89E-01	UT	N-UT-37	WB-76	07.00	64.57	19990319	R0512	P	SWRI EXAM REPORT UT0001
RV	RVLIG-01	ISI-0427-C 03	B-G-1	B6.40	89E-01	UT	N-UT-37	WB-76	6.00		19990304	R0402	P	
RV	RVLIG-02	ISI-0427-C 03	B-G-1	B6.40	89E-01	UT	N-UT-37	WB-76	6.00		19990304	R0402	P	
RV	RVLIG-03	ISI-0427-C 03	B-G-1	B6.40	89E-01	UT	N-UT-37	WB-76	6.00		19990304	R0402	P	
RV	RVLIG-04	ISI-0427-C 03	B-G-1	B6.40	89E-01	UT	N-UT-37	WB-76	6.00		19990304	R0402	P	
RV	RVLIG-05	ISI-0427-C 03	B-G-1	B6.40	89E-01	UT	N-UT-37	WB-76	6.00		19990304	R0402	P	
RV	RVLIG-06	ISI-0427-C 03	B-G-1	B6.40	89E-01	UT	N-UT-37	WB-76	6.00		19990304	R0402	P	
RV	RVLIG-07	ISI-0427-C 03	B-G-1	B6.40	89E-01	UT	N-UT-37	WB-76	6.00		19990304	R0402	P	

Owner: TENNESSEE VALLEY AUTHORITY
 Chattanooga Office Complex
 1101 Market Street
 Chattanooga, TN 37402

Plant: WATTS BAR NUCLEAR PLANT
 P.O. Box 2000
 Spring City, TN 37381-2000

Unit: 1
 Commercial Service Date: May 27, 1996

Certificate of Authorization: N/A
 National Board Number for Unit: N/A

System	Component Number	ISO Drawing	Category	Item Number	Exam Requirement	Exam Scheduled	NDE Procedure	Calibration Standard	Component Diameter	Nominal Thickness	Exam Date	Exam Report	Exam Results	Comments
RV	RVLIG-08	ISI-0427-C 03	B-G-1	B6.40	89E-01	UT	N-UT-37	WB-76	6.00		19990304	R0402	P	
RV	RVLIG-09	ISI-0427-C 03	B-G-1	B6.40	89E-01	UT	N-UT-37	WB-76	6.00		19990304	R0402	P	
RV	RVLIG-10	ISI-0427-C 03	B-G-1	B6.40	89E-01	UT	N-UT-37	WB-76	6.00		19990304	R0402	P	
RV	RVLIG-11	ISI-0427-C 03	B-G-1	B6.40	89E-01	UT	N-UT-37	WB-76	6.00		19990304	R0402	P	
RV	RVLIG-12	ISI-0427-C 03	B-G-1	B6.40	89E-01	UT	N-UT-37	WB-76	6.00		19990304	R0402	P	
RV	RVLIG-13	ISI-0427-C 03	B-G-1	B6.40	89E-01	UT	N-UT-37	WB-76	6.00		19990304	R0402	P	
RV	RVLIG-14	ISI-0427-C 03	B-G-1	B6.40	89E-01	UT	N-UT-37	WB-76	6.00		19990304	R0402	P	
RV	RVLIG-15	ISI-0427-C 03	B-G-1	B6.40	89E-01	UT	N-UT-37	WB-76	6.00		19990304	R0402	P	
RV	RVLIG-16	ISI-0427-C 03	B-G-1	B6.40	89E-01	UT	N-UT-37	WB-76	6.00		19990304	R0402	P	
RV	RVLIG-17	ISI-0427-C 03	B-G-1	B6.40	89E-01	UT	N-UT-37	WB-76	6.00		19990304	R0402	P	
RV	RVLIG-18	ISI-0427-C 03	B-G-1	B6.40	89E-01	UT	N-UT-37	WB-76	6.00		19990304	R0402	P	
RV	RVWASHER-01	ISI-0427-C 03	B-G-1	B6.50	89E-01	VT-1	VENDOR		07.00	01.48	19990319	R0512	P	SWRI EXAM REPORT 280001
RV	RVWASHER-02	ISI-0427-C 03	B-G-1	B6.50	89E-01	VT-1	VENDOR		07.00	01.48	19990319	R0512	P	SWRI EXAM REPORT 280001
RV	RVWASHER-03	ISI-0427-C 03	B-G-1	B6.50	89E-01	VT-1	VENDOR		07.00	01.48	19990319	R0512	P	SWRI EXAM REPORT 280001
RV	RVWASHER-04	ISI-0427-C 03	B-G-1	B6.50	89E-01	VT-1	VENDOR		07.00	01.48	19990319	R0512	P	SWRI EXAM REPORT 280001
RV	RVWASHER-05	ISI-0427-C 03	B-G-1	B6.50	89E-01	VT-1	VENDOR		07.00	01.48	19990319	R0512	P	SWRI EXAM REPORT 280001
RV	RVWASHER-06	ISI-0427-C 03	B-G-1	B6.50	89E-01	VT-1	VENDOR		07.00	01.48	19990319	R0512	P	SWRI EXAM REPORT 280001
RV	RVWASHER-07	ISI-0427-C 03	B-G-1	B6.50	89E-01	VT-1	VENDOR		07.00	01.48	19990319	R0512	P	SWRI EXAM REPORT 280001
RV	RVWASHER-08	ISI-0427-C 03	B-G-1	B6.50	89E-01	VT-1	VENDOR		07.00	01.48	19990319	R0512	P	SWRI EXAM REPORT 280001
RV	RVWASHER-09	ISI-0427-C 03	B-G-1	B6.50	89E-01	VT-1	VENDOR		07.00	01.48	19990319	R0512	P	SWRI EXAM REPORT 280001
RV	RVWASHER-10	ISI-0427-C 03	B-G-1	B6.50	89E-01	VT-1	VENDOR		07.00	01.48	19990319	R0512	P	SWRI EXAM REPORT 280001
RV	RVWASHER-11	ISI-0427-C 03	B-G-1	B6.50	89E-01	VT-1	VENDOR		07.00	01.48	19990319	R0512	P	SWRI EXAM REPORT 280001
RV	RVWASHER-12	ISI-0427-C 03	B-G-1	B6.50	89E-01	VT-1	VENDOR		07.00	01.48	19990319	R0512	P	SWRI EXAM REPORT 280001
RV	RVWASHER-13	ISI-0427-C 03	B-G-1	B6.50	89E-01	VT-1	VENDOR		07.00	01.48	19990319	R0512	P	SWRI EXAM REPORT 280001
RV	RVWASHER-14	ISI-0427-C 03	B-G-1	B6.50	89E-01	VT-1	VENDOR		07.00	01.48	19990319	R0512	P	SWRI EXAM REPORT 280001
RV	RVWASHER-15	ISI-0427-C 03	B-G-1	B6.50	89E-01	VT-1	VENDOR		07.00	01.48	19990319	R0512	P	SWRI EXAM REPORT 280001
RV	RVWASHER-16	ISI-0427-C 03	B-G-1	B6.50	89E-01	VT-1	VENDOR		07.00	01.48	19990319	R0512	P	SWRI EXAM REPORT 280001
RV	RVWASHER-17	ISI-0427-C 03	B-G-1	B6.50	89E-01	VT-1	VENDOR		07.00	01.48	19990319	R0512	P	SWRI EXAM REPORT 280001
RV	RVWASHER-18	ISI-0427-C 03	B-G-1	B6.50	89E-01	VT-1	VENDOR		07.00	01.48	19990319	R0512	P	SWRI EXAM REPORT 280001
CVCS	CVC-05-BC	ISI-0050-C 04	B-G-2	B7.50	89E-01	VT-1	N-VT-1		01.50	0.281	19990310	R0425	P	
RCS	RC-03-BC	ISI-0365-C 01	B-G-2	B7.50	P89000	VT-1	N-VT-1				19990309	R0466	P	

Owner: TENNESSEE VALLEY AUTHORITY
 Chattanooga Office Complex
 1101 Market Street
 Chattanooga, TN 37402

Plant: WATTS BAR NUCLEAR PLANT
 P.O. Box 2000
 Spring City, TN 37381-2000

Unit: 1
 Commercial Service Date: May 27, 1996

Certificate of Authorization: N/A
 National Board Number for Unit: N/A

System	Component Number	ISO Drawing	Category	Item Number	Exam Requirement	Exam Scheduled	NDE Procedure	Calibration Standard	Component Diameter	Nominal Thickness	Exam Date	Exam Report	Exam Results	Comments
RCS	RC-04-BC	ISI-0365-C 01	B-G-2	B7.50	P89000	VT-1	N-VT-1				19990309	R0468	P	
RCS	RC-05-BC	ISI-0365-C 01	B-G-2	B7.50	P89000	VT-1	N-VT-1				19990310	R0467	P	
SIS	SI-04-BC	CHM-2758-C 13	B-G-2	B7.50	89E-01	VT-1	N-VT-1				19990312	R0443	P	
RCS	68-563-BC	ISI-0365-C 01	B-G-2	B7.70	P89000	VT-1	N-VT-1				19990329	R0518	P	
RCS	68-564-BC	ISI-0365-C 01	B-G-2	B7.70	P89000	VT-1	N-VT-1				19990319	R0505	P	
RCS	68-565-BC	ISI-0365-C 01	B-G-2	B7.70	P89000	VT-1	N-VT-1				19990319	R0504	P	
RHRS	63-640-BC	CHM-2636-C 07	B-G-2	B7.70	89E-01	VT-1	N-VT-1		08.00		19990305	R0414	P	
RCS	RCF-D232-01	ISI-0365-C 01	B-J	B9.11	89E-01	PT	N-PT-9		06.00	0.718	19990313	R0470	P	
RCS	RCF-D232-01	ISI-0365-C 01	B-J	B9.11	89E-01	UT	N-UT-18	WB-01	06.00	0.718	19990313	R0469	P	
RCS	RCF-D232-01B	ISI-0365-C 01	B-J	B9.11	89E-01	PT	N-PT-9		06.00	0.718	19990312	R0458	P	
RCS	RCF-D232-01B	ISI-0365-C 01	B-J	B9.11	89E-01	UT	N-UT-18	WB-01	06.00	0.718	19990312	R0478	P	
RCS	RCF-D233-15	ISI-0365-C 02	B-J	B9.11	89E-01	PT	N-PT-9		06.00	0.719	19990312	R0456	P	
RCS	RCF-D233-15	ISI-0365-C 02	B-J	B9.11	89E-01	UT	N-UT-18	WB-01	06.00	0.719	19990312	R0461	P	
RCS	RCS-022	ISI-0365-C 01	B-J	B9.11	89E-01	PT	N-PT-9		06.00	0.718	19990312	R0457	P	
RCS	RCS-022	ISI-0365-C 01	B-J	B9.11	89E-01	UT	N-UT-18	WB-01	06.00	0.718	19990312	R0477	P	
RCS	RCS-036	ISI-0365-C 02	B-J	B9.11	89E-01	PT	N-PT-9		06.00	0.718	19990312	R0455	P	
RCS	RCS-036	ISI-0365-C 02	B-J	B9.11	89E-01	UT	N-UT-18	WB-01	06.00	0.718	19990312	R0462	P	
RCS	RCS-047	ISI-0365-C 02	B-J	B9.11	89E-01	PT	N-PT-9		04.00	0.531	19990315	R0479	P	
RCS	RCS-047	ISI-0365-C 02	B-J	B9.11	89E-01	UT	N-UT-18	WB-40	04.00	0.531	19990315	R0485	P	
RHRS	RHRF-D055-13	CHM-2636-C 08	B-J	B9.11	89E-01	PT	N-PT-9		08.00	0.906	19990305	R0416	P	
RHRS	RHRF-D055-13	CHM-2636-C 08	B-J	B9.11	89E-01	UT	N-UT-18	WB-02	08.00	0.906	19990306	R0408	P	
RHRS	RHRF-D055-15	CHM-2636-C 08	B-J	B9.11	89E-01	PT	N-PT-9		06.00	0.718	19990305	R0417	P	
RHRS	RHRF-D055-15	CHM-2636-C 08	B-J	B9.11	89E-01	UT	N-UT-18	WB-01	06.00	0.718	19990309	R0482	P	
RHRS	RHRS-152A	CHM-2636-C 08	B-J	B9.11	89E-01	PT	N-PT-9		08.00	0.906	19990305	R0415	P	
RHRS	RHRS-152A	CHM-2636-C 08	B-J	B9.11	89E-01	UT	N-UT-18	WB-02	08.00	0.906	19990306	R0407	P	
RHRS	RHRS-154	CHM-2636-C 08	B-J	B9.11	89E-01	PT	N-PT-9		06.00	0.718	19990305	R0419	P	
RHRS	RHRS-154	CHM-2636-C 08	B-J	B9.11	89E-01	UT	N-UT-18	WB-01	06.00	0.718	19990309	R0405	P	
RHRS	RHRS-155	CHM-2636-C 08	B-J	B9.11	89E-01	PT	N-PT-9		06.00	0.718	19990305	R0418	P	
RHRS	RHRS-155	CHM-2636-C 08	B-J	B9.11	89E-01	UT	N-UT-18	WB-01	06.00	0.718	19990306	R0406	P	
RX	RCF-D1-1	CHM-2547-C 01	B-J	B9.11	89E-01	PT	N-PT-9		29.00	2.450	19990317	R0493	P	
RX	RCF-D1-1	CHM-2547-C 01	B-J	B9.11	89E-01	UT	VENDOR	WB-60	29.00	2.450	19990316	R0512	P	SWRI EXAM REPORT EXAM 23 & EXAM 24
RX	RCF-D2-1	CHM-2547-C 01	B-J	B9.11	89E-01	PT	N-PT-9		29.00	2.450	19990317	R0498	P	
RX	RCF-D2-1	CHM-2547-C 01	B-J	B9.11	89E-01	UT	VENDOR	WB-60	29.00	2.450	19990316	R0512	P	SWRI EXAM REPORT EXAM 19 & EXAM 20

Owner: TENNESSEE VALLEY AUTHORITY
 Chattanooga Office Complex
 1101 Market Street
 Chattanooga, TN 37402

Plant: WATTS BAR NUCLEAR PLANT
 P.O. Box 2000
 Spring City, TN 37381-2000

Certificate of Authorization: N/A
 National Board Number for Unit: N/A

Unit: 1
 Commercial Service Date: May 27, 1996

System	Component Number	ISO Drawing	Category	Item Number	Exam Requirement	Exam Scheduled	NDE Procedure	Calibration Standard	Component Diameter	Nominal Thickness	Exam Date	Exam Report	Exam Results	Comments
RX	RCF-D4-1	CHM-2547-C 01	B-J	B9.11	89E-01	PT	N-PT-9		29.00	2.450	19990317	R0500	P	
RX	RCF-D4-1	CHM-2547-C 01	B-J	B9.11	89E-01	UT	VENDOR	WB-60	29.00	2.450	19990316	R0512	P	SWR EXAM REPORT EXAM 15 & EXAM 16
RX	RCF-D5-1	CHM-2547-C 01	B-J	B9.11	89E-01	PT	N-PT-9		29.00	2.450	19990317	R0495	P	
RX	RCF-D5-1	CHM-2547-C 01	B-J	B9.11	89E-01	UT	VENDOR	WB-60	29.00	2.450	19990316	R0512	P	SWRI EXAM REPORT EXAM 11 & EXAM 12
SIS	SIF-D089-11	CHM-2758-C 07	B-J	B9.11	89E-01	PT	N-PT-9		10.00	1.000	19990306	R0410	P	
SIS	SIF-D089-11	CHM-2758-C 07	B-J	B9.11	89E-01	UT	N-UT-18	WB-33	10.00	1.000	19990310	R0460	P	
SIS	SIF-D092-03	CHM-2758-C 10	B-J	B9.11	89E-01	PT	N-PT-9		10.00	1.000	19990318	R0488	P	
SIS	SIF-D092-03	CHM-2758-C 10	B-J	B9.11	89E-01	UT	N-UT-18	WB-33	10.00	1.000	19990319	R0503	P	
SIS	SIF-D092-07	CHM-2758-C 10	B-J	B9.11	89E-01	PT	N-PT-9		06.00	0.718	19990318	R0502	P	
SIS	SIF-D092-07	CHM-2758-C 10	B-J	B9.11	89E-01	UT	N-UT-18	WB-01	06.00	0.718	19990318	R0486	P	
SIS	SIS-089	CHM-2758-C 07	B-J	B9.11	89E-01	PT	N-PT-9		10.00	1.000	19990306	R0411	P	
SIS	SIS-089	CHM-2758-C 07	B-J	B9.11	89E-01	UT	N-UT-18	WB-33	10.00	1.000	19990306	R0403	P	
SIS	SIS-090	CHM-2758-C 07	B-J	B9.11	89E-01	PT	N-PT-9		10.00	1.000	19990306	R0409	P	
SIS	SIS-090	CHM-2758-C 07	B-J	B9.11	89E-01	UT	N-UT-18	WB-33	10.00	1.000	19990306	R0404	P	
SIS	SIS-092	CHM-2758-C 07	B-J	B9.11	89E-01	PT	N-PT-9		06.00	0.718	19990318	R0497	P	
SIS	SIS-092	CHM-2758-C 07	B-J	B9.11	89E-01	UT	N-UT-18	WB-01	06.00	0.718	19990318	R0489	P	
SIS	SIS-095	CHM-2758-C 07	B-J	B9.11	89E-01	PT	N-PT-9		06.00	0.718	19990306	R0412	P	
SIS	SIS-095	CHM-2758-C 07	B-J	B9.11	89E-01	UT	N-UT-18	WB-01	06.00	0.718	19990308	R0484	P	
SIS	SIS-120	CHM-2758-C 10	B-J	B9.11	89E-01	PT	N-PT-9		10.00	1.000	19990312	R0454	P	
SIS	SIS-120	CHM-2758-C 10	B-J	B9.11	89E-01	UT	N-UT-18	WB-33	10.00	1.000	19990316	R0490	P	
SIS	SIS-129	CHM-2758-C 10	B-J	B9.11	89E-01	PT	N-PT-9		06.00	0.718	19990318	R0501	P	
SIS	SIS-129	CHM-2758-C 10	B-J	B9.11	89E-01	UT	N-UT-18	WB-01	06.00	0.718	19990318	R0487	P	
CVCS	CVCF-B-T199-15	ISI-0005-C 02	B-J	B9.21	89E-01	PT	N-PT-9		03.00	0.438	19990315	R0475	P	
CVCS	CVCF-B-T199-16	ISI-0005-C 02	B-J	B9.21	89E-01	PT	N-PT-9		03.00	0.438	19990315	R0476	P	
CVCS	CVCF-B-T199-19	ISI-0005-C 02	B-J	B9.21	89E-01	PT	N-PT-9		03.00	0.438	19990316	R0480	P	
CVCS	CVCF-B-T199-20	ISI-0005-C 02	B-J	B9.21	89E-01	PT	N-PT-9		03.00	0.438	19990309	R0394	P	
CVCS	CVCF-D036-12	ISI-0005-C 01	B-J	B9.21	89E-01	PT	N-PT-9		03.00	0.438	19990311	R0431	P	
CVCS	CVCF-D036-37	ISI-0005-C 01	B-J	B9.21	89E-01	PT	N-PT-9		03.00	0.438	19990311	R0452	P	
CVCS	CVCF-D036-38	ISI-0005-C 01	B-J	B9.21	89E-01	PT	N-PT-9		03.00	0.438	19990311	R0453	P	
CVCS	CVCS-005	ISI-0005-C 01	B-J	B9.21	89E-01	PT	N-PT-9		03.00	0.438	19990311	R0432	P	
RCS	RCS-025	ISI-0365-C 01	B-J	B9.21	89E-01	PT	N-PT-9		03.00	0.438	19990312	R0451	P	
SIS	SIF-D086-06	CHM-2758-C 04	B-J	B9.21	89E-01	PT	N-PT-9		02.50	0.375	19990302	R0376	P	
SIS	SIF-D086-07	CHM-2758-C 04	B-J	B9.21	89E-01	PT	N-PT-9		02.50	0.375	19990302	R0380	P	

Owner: TENNESSEE VALLEY AUTHORITY
 Chattanooga Office Complex
 1101 Market Street
 Chattanooga, TN 37402

Plant: WATTS BAR NUCLEAR PLANT
 P.O. Box 2000
 Spring City, TN 37381-2000

Unit: 1
 Commercial Service Date: May 27, 1996

Certificate of Authorization: N/A
 National Board Number for Unit: N/A

System	Component Number	ISO Drawing	Category	Item Number	Exam Requirement	Exam Scheduled	NDE Procedure	Calibration Standard	Component Diameter	Nominal Thickness	Exam Date	Exam Report	Exam Results	Comments
SIS	SIS-055	CHM-2758-C 04	B-J	B9.21	89E-01	PT	N-PT-9		02.50	0.375	19990302	R0378	P	
SIS	SIS-056	CHM-2758-C 04	B-J	B9.21	89E-01	PT	N-PT-9		02.50	0.375	19990302	R0379	P	
RX	RCS-3-5	CHM-2547-C 01	B-J	B9.31	89E-01	PT	N-PT-9		10.00	2.490	19990308	R0398	P	
RX	RCS-3-5	CHM-2547-C 01	B-J	B9.31	89E-01	UT	N-UT-33	WB-59	10.00	2.490	19990316	R0491	P	
CVCS	CVCW-03	ISI-0005-C 01	B-J	B9.32	89E-01	PT	N-PT-9		03.00	1.313	19990311	R0430	P	
RX	1-TW-68-24C	CHM-2547-C 02	B-J	B9.32	89E-01	PT	N-PT-9		02.50		19990304	R0382	P	
SIS	SIW-11	CHM-2758-C 04	B-J	B9.32	89E-01	PT	N-PT-9		01.50		19990310	R0428	P	
RCS	1-68-415-1A	ISI-0364-C 01	B-K-1	B10.20	89E-01	PT	N-PT-9				19990310	R0429	P	
RCS	68-563	ISI-0365-C 01	B-M-2	B12.50	P89000	VT-1	N-VT-1		06.00		19980605	R0361	P	
RCS	68-564	ISI-0365-C 01	B-M-2	B12.50	P89000	VT-1	N-VT-1				19980604	R0360	P	
RCS	68-565	ISI-0365-C 01	B-M-2	B12.50	P89000	VT-1	N-VT-1				19980603	R0359	P	
RHRS	RHRHX-3-1A	CHM-2662-C 01	C-B	C2.21	89E-01	PT	N-PT-9		14.00	1.000	19990310	R0433	P	
RHRS	RHRHX-3-1A	CHM-2662-C 01	C-B	C2.21	89E-01	UT	N-UT-73	WB-77	14.00	1.000	19990310	R0420	P	Sup. PT Exam perf. from ID included
RHRS	RHRHX-4-1A	CHM-2662-C 01	C-B	C2.21	89E-01	PT	N-PT-9		14.00	1.000	19990310	R0434	P	
RHRS	RHRHX-4-1A	CHM-2662-C 01	C-B	C2.21	89E-01	UT	N-UT-73	WB-77	14.00	1.000	19990310	R0421	P	Sup. PT Exam perf. from ID included
RHRS	RHRHX-3-1A-IR	CHM-2662-C 01	C-B	C2.22	89E-01	UT	N-UT-73	WB-77	14.00		19990311	R0423	P	Sup. PT Exam perf. from ID included
RHRS	RHRHX-4-1A-IR	CHM-2662-C 01	C-B	C2.22	89E-01	UT	N-UT-73	WB-77	14.00		19990311	R0422	P	Sup. PT Exam perf. from ID included
FWS	FWF-D372-05	CHM-2671-C 06	C-F-2	C5.51	P89000	MT	N-MT-6		06.00	0.432	19990324	R0510	P	
FWS	FWF-D372-05	CHM-2671-C 06	C-F-2	C5.51	P89000	UT	N-UT-18	WB-37	06.00	0.432	19990324	R0514	P	
FWS	FWF-D372-28	CHM-2671-C 06	C-F-2	C5.51	P89000	MT	N-MT-6		06.00	0.432	19990324	R0511	P	
FWS	FWF-D372-28	CHM-2671-C 06	C-F-2	C5.51	P89000	UT	N-UT-18	WB-37	06.00	0.432	19990324	R0513	P	
MSS	MSVS-1-530-BS062	ISI-0081-C 01	C-G	C6.20	89E-01	MT	N-MT-6		10.00		19990309	R0399	P	
CVCS	1-68-047	ISI-0026-C 02	F-A	F1.10A	89E-01	VT-3	N-VT-1		03.00		19990308	R0397	P	
RCS	1-68-092	ISI-0364-C 01	F-A	F1.10A	89E-01	VT-3	N-VT-1		03.00		19990310	R0427	P	
RHRS	1-63-343	ISI-0020-C 08	F-A	F1.10A	89E-01	VT-3	N-VT-1		08.00		19990302	R0372	P	
SIS	1-63-005	ISI-0021-C 07	F-A	F1.10A	89E-01	VT-3	N-VT-1		10.00		19990301	R0375	P	
SIS	1-63-153	ISI-0021-C 08	F-A	F1.10A	89E-01	VT-3	N-VT-1		02.50		19990301	R0368	P	
SIS	1-63-482	ISI-0021-C 07	F-A	F1.10A	89E-01	VT-3	N-VT-1		10.00		19990311	R0440	P	
CVCS	1-62A-306	ISI-0026-C 01	F-A	F1.10B	89E-01	VT-3	N-VT-1		03.00		19990319	R0396	P	
CVCS	1-62A-383	ISI-0026-C 02	F-A	F1.10B	89E-01	VT-3	N-VT-1		03.00		19990313	R0473	P	
RCS	1-68-055	ISI-0364-C 02	F-A	F1.10B	89E-01	VT-3	N-VT-1		06.00		19990310	R0426	P	
RX	RCL-CLR-2	ISI-0438-C 01	F-A	F1.10B	89E-01	VT-3	N-VT-1				19990227	R0392	P	

Owner: TENNESSEE VALLEY AUTHORITY
 Chattanooga Office Complex
 1101 Market Street
 Chattanooga, TN 37402

Plant: WATTS BAR NUCLEAR PLANT
 P.O. Box 2000
 Spring City, TN 37381-2000

Unit: 1
 Commercial Service Date: May 27, 1996

Certificate of Authorization: N/A
 National Board Number for Unit: N/A

System	Component Number	ISO Drawing	Category	Item Number	Exam Requirement	Exam Scheduled	NDE Procedure	Calibration Standard	Component Diameter	Nominal Thickness	Exam Date	Exam Report	Exam Results	Comments
SIS	1-63-010	ISI-0021-C 07	F-A	F1.10B	89E-01	VT-3	N-VT-1		06.00		19990311	R0444	P	
SIS	1-63-192	ISI-0021-C 08	F-A	F1.10B	89E-01	VT-3	N-VT-1		02.50		19990301	R0367	P	
SIS	1-63-198	ISI-0021-C 08	F-A	F1.10B	89E-01	VT-3	N-VT-1		02.50		19990313	R0471	P	
SIS	1-63-215	ISI-0021-C 12	F-A	F1.10B	89E-01	VT-3	N-VT-1		01.50		19990311	R0446	P	
SIS	1-63-218	ISI-0021-C 12	F-A	F1.10B	89E-01	VT-3	N-VT-1		01.50		19990311	R0445	P	
RCS	1-68-025	ISI-0364-C 02	F-A	F1.10C	89E-01	VT-3	N-VT-1		04.00		19990301	R0366	P	ACC. RANGE 886 TO 978 POUNDS
SIS	1-63-444	ISI-0021-C 07	F-A	F1.10C	89E-01	VT-3	N-VT-1		10.00		19990311	R0438	P	ACC. RANGE 2377 TO 2628 POUNDS
CVCS	1-62A-006	ISI-0063-C 01	F-A	F1.10D	89E-01	VT-3	N-VT-1		02.00		19990301	R0370	P	
CVCS	1-62A-065	ISI-0063-C 02	F-A	F1.10D	89E-01	VT-3	N-VT-1		02.00		19990301	R0371	P	
RCS	1-68-415	ISI-0364-C 01	F-A	F1.10D	P89000	VT-3	N-VT-1		03.00		19990319	R0506	P	
RCS	1-68-415	ISI-0364-C 01	F-A	F1.10D	89E-01	VT-3	N-VT-1		03.00		19990310	R0424	P	
RHRS	1-63-596	ISI-0020-C 08	F-A	F1.10D	89E-01	VT-3	N-VT-1		02.00		19990305	R0413	P	
SIS	1-63-156	ISI-0021-C 13	F-A	F1.10D	89E-01	VT-3	N-VT-1		01.50		19990312	R0442	P	
SIS	1-63-196	ISI-0021-C 08	F-A	F1.10D	89E-01	VT-3	N-VT-1		02.50		19990313	R0472	P	
SIS	1-63-462	ISI-0021-C 07	F-A	F1.10D	89E-01	VT-3	N-VT-1		06.00		19990312	R0439	P	
SIS	1-63-465	ISI-0021-C 10	F-A	F1.10D	89E-01	VT-3	N-VT-1		02.00		19990312	R0441	P	
FWS	1-03A-498	ISI-0062-C 08	F-A	F1.20A	P89000	VT-3	N-VT-1		06.00		19990405	R0527	P	
FWS	1-03A-499	ISI-0062-C 08	F-A	F1.20B	P89000	VT-3	N-VT-1		06.00		19990405	R0528	P	
FWS	1-03A-500	ISI-0062-C 08	F-A	F1.20B	P89000	VT-3	N-VT-1		06.00		19990405	R0529	P	
MSS	1-01A-389	ISI-0011-C 03	F-A	F1.20C	P89000	VT-3	N-VT-1		32.00		19990405	R0526	P	
FWS	1-03A-374	ISI-0062-C 05	F-A	F1.20D	P89000	VT-3	N-VT-1		06.00		19990402	R0522	P	
CVCS	47A406-09-051	ISI-0026-C 01	F-A	F1.40A	89E-01	VT-3	N-VT-1		03.00		19990315	R0481	P	
SG	SGH-1-1	CHM-2660-C 03	F-A	F1.40B	P89000	VT-3	N-VT-1				19990325	R0515	P	
SG	SGH-1-2	CHM-2660-C 03	F-A	F1.40B	P89000	VT-3	N-VT-1				19990325	R0516	P	
SG	SGH-1-2	CHM-2660-C 03	F-A	F1.40B	89E-01	VT-3	N-VT-1				19990302	R0391	P	
SG	SGH-1-4	CHM-2660-C 03	F-A	F1.40B	P89000	VT-3	N-VT-1				19990329	R0517	P	
CVCS	47A406-09-050	ISI-0026-C 01	F-A	F1.40D	89E-01	VT-3	N-VT-1		03.00		19990308	R0395	P	
RCS	1-68-023	ISI-0364-C 02	F-A	F1.40D	89E-01	VT-3	N-VT-1		04.00		19990302	R0369	P	

Owner: TENNESSEE VALLEY AUTHORITY Chattanooga Office Complex 1101 Market Street Chattanooga, TN 37402	Plant: WATTS BAR NUCLEAR PLANT P.O. Box 2000 Spring City, TN 37381-2000
Unit: 1 Commercial Service Date: May 27, 1996	Certificate of Authorization: N/A National Board Number for Unit: N/A

APPENDIX II
STEAM GENERATOR TUBE EDDY CURRENT SUMMARY

The attached table summarizes the examinations and results of the steam generator tube eddy current examinations performed during the cycle 2 refueling outage.

Owner: TENNESSEE VALLEY AUTHORITY
 Chattanooga Office Complex
 1101 Market Street
 Chattanooga, TN 37402

Plant: WATTS BAR NUCLEAR PLANT
 P.O. Box 2000
 Spring City, TN 37381-2000

Unit: 1
 Commercial Service Date: May 27, 1996

Certificate of Authorization: N/A
 National Board Number for Unit: N/A

CLASSIFICATION OF INSPECTION RESULTS
WATTS BAR NUCLEAR PLANT UNIT 1 CYCLE 2 SG INSPECTION

<u>Initial Eddy Current Exam</u>	<u>SG1</u>	<u>SG2</u>	<u>SG3</u>	<u>SG4</u>
Full Length Bobbin Coil	4667	4674	4672	4667
U-Bend Plus Point	137	137	137	137
Top of Tubesheet RPC	4667	4674	4672	4667
Dented TSP Plus Point	0	3	2	9
Freespan Ding Plus Point	16	22	30	40
Diagnostic Plus Point	25	27	37	19

<u>Expansion</u>	<u>SG1</u>	<u>SG2</u>	<u>SG3</u>	<u>SG4</u>
Full Length Bobbin Coil	0 (1)	0 (1)	0	0 (1)
U-Bend Plus Point	0	0	0	0
Top of Tubesheet RPC	0	0 (1)	0	0
Dented TSP Plus Point	0	0	0	0
Freespan Ding Plus Point	0	0	0	0
Total Exams Completed	9508	9537	9550	9539
Total Tubes Examined	4667	4674	4672	4667

<u>Indications</u>	<u>SG1</u>	<u>SG2</u>	<u>SG3</u>	<u>SG4</u>
AVB Wear	3	4	2	13
PWSCC HTS Axial	0	1	0	0
Loose Parts Damage	11	1	0	1
Total Indications	15	6	2	14

<u>Plugging Status</u>	<u>SG1</u>	<u>SG2</u>	<u>SG3</u>	<u>SG4</u>
Previously Plugged Tubes	7	0	2	7
<u>Plugged Current Outage by Damage Mechanism</u>				
AVB Wear	0	0	0	0
PWSCC HTS Axial	0	1	0	0
Loose Parts Damage	11	1	0	1
Plugged Preventively	2	5	0	0
Total	20	7	2	8

Owner: TENNESSEE VALLEY AUTHORITY
 Chattanooga Office Complex
 1101 Market Street
 Chattanooga, TN 37402

Plant: WATTS BAR NUCLEAR PLANT
 P.O. Box 2000
 Spring City, TN 37381-2000

Unit: 1
 Commercial Service Date: May 27, 1996

Certificate of Authorization: N/A
 National Board Number for Unit: N/A

**CLASSIFICATION OF INSPECTION RESULTS
 WATTS BAR NUCLEAR PLANT UNIT 1 CYCLE 2 SG INSPECTION**

<u>Classification of Inspection Results</u>	<u>SG1</u>	<u>SG2</u>	<u>SG3</u>	<u>SG4</u>
Full Length Bobbin Coil	C-2 (1)	C-2 (1)	C-1	C-2 (1)
U-Bend Plus Point	C-1	C-1	C-1	C-1
Top of Tubesheet RPC	C-1	C-2 (1)	C-1	C-1
Dented Plus Point	C-1	C-1	C-1	C-1
Freespan Ding Plus Point	C-1	C-1	C-1	C-1

Inspection Classification Category	Inspection Results
C-1	Less than 5% of the total tubes inspected are degraded tubes and none of the inspected tubes are defective.
C-2	One or more tubes, but not more than 1% of the total tubes inspected are defective, or between 5 and 10% of the total tubes inspected are degraded tubes
C-3	More than 10% of the total tubes inspected are degraded tubes or more than 1% of the inspected tubes are defective.

Note (1): Initial sample was 100% of population; therefore, no expansion sample required.

Owner: TENNESSEE VALLEY AUTHORITY Chattanooga Office Complex 1101 Market Street Chattanooga, TN 37402	Plant: WATTS BAR NUCLEAR PLANT P.O. Box 2000 Spring City, TN 37381-2000
Unit: 1 Commercial Service Date: May 27, 1996	Certificate of Authorization: N/A National Board Number for Unit: N/A

APPENDIX III
PRESSURE TEST SUMMARY

The following summarizes the tests and results of the system pressure tests performed during the second cycle.

Owner: TENNESSEE VALLEY AUTHORITY
 Chattanooga Office Complex
 1101 Market Street
 Chattanooga, TN 37402

Plant: WATTS BAR NUCLEAR P
 P.O. Box 2000
 Spring City, TN 37381-2000

Unit: 1
 Commercial Service Date: May 27, 1996

Certificate of Authorization: N/A
 National Board Number for Unit: N/A

WBN Unit 1 Cycle 2 RFO Pressure Test Report
 [First Inspection Interval, first period]

System	Procedure No.	Test Type	Exam	Performance Date	Test Results
Auxiliary Feedwater System - Train A Auxiliary Feedwater System Code Class 2 and 3 piping and components associated with the 1A-A Auxiliary Feedwater Pump.	1-TRI-3-901-A	System Inservice	VT-2	2/27 through 4/10/99	Satisfactory
Auxiliary Feedwater System - Train A Auxiliary Feedwater System Code Class 2 and 3 piping and components associated with the 1A-S Auxiliary Feedwater Pump	1-TRI-3-902	System Inservice	VT-2	Note 3	Satisfactory
Main Feedwater System - Main feedwater system Code Class 2 piping and components located inside the reactor building, including the secondary side of the steam generators.	1-TRI-3-903	System Inservice	VT-2	4/10 through 4/14/99	Satisfactory
Auxiliary Feedwater System - Essential Raw Cooling Water System supply to the 1A-A and 1A-S Auxiliary Feedwater Pumps Code Class 3 piping and components	1-TRI-3-904-A	System Functional	VT-2	1/28/99	Satisfactory
Auxiliary Feedwater System - Essential Raw Cooling Water System supply to the 1B-B and 1A-S Auxiliary Feedwater Pumps Code Class 3 piping and components	1-TRI-3-904-B	System Functional	VT-2	1/21/99	Satisfactory
Main Feedwater System - Main feedwater system Code Class 2 piping and components located outside the reactor building.	1-TRI-3-905	System Inservice	VT-2	4/21/99 Note 1	Satisfactory
Main Control Room Chilled Water System - Train A Main Control Room Chilled Water System piping and components	0-TRI-31-902-A	System Inservice	VT-2	1/12/99 Note 2	Satisfactory
Main Control Room Chilled Water System - Train B Main Control Room Chilled Water System piping and components	0-TRI-31-902-B	System Inservice	VT-2	1/15/99 Note 2	Satisfactory
Electric Board Room Chilled Water System - Train A Electric Board Room Chilled Water System piping and components	0-TRI-31-903-A	System Inservice	VT-2	1/5/99 Note 2	Satisfactory
Electric Board Room Chilled Water System - Train B Electric Board Room Chilled Water System piping and components	0-TRI-31-903-B	System Inservice	VT-2	11/19/98 Note 2	Satisfactory
Shutdown Board Room Chilled Water System - Train A Shutdown Board Room Chilled Water System piping and components	0-TRI-31-904-A	System Inservice	VT-2	1/8/99 Note 2	Satisfactory
Shutdown Board Room Chilled Water System - Train B Shutdown Board Room Chilled Water System piping and components	0-TRI-31-904-B	System Inservice	VT-2	1/22/99 Note 2	Satisfactory
Station Drainage - Code Class 3 open ended drain lines from Accumulator Rooms 3 and 4 to inside the polar crane wall.	1-TRI-40-901	System Inservice	Un-impaired Flow	3/20/99	Satisfactory
Demineralized Water - Code Class 2 piping and components associated with the Demineralized Water System penetration through containment.	1-TRI-59-901	System Functional	VT-2	1/28/99 Note 2	Satisfactory
Ice Condenser - Code Class 3 floor drain piping and components	1-SI-61-9	System Inservice	Un-impaired Flow	4/4/99	Satisfactory
Ice Condenser - Code Class 2 piping and components associated with the Ice Condenser System penetrations through containment	1-TRI-61-901	System Inservice	VT-2	2/3/99	Satisfactory
Chemical and Volume Control System - Code Class 2 and 3 piping and components located outside containment associated with charging, letdown, seal injection, high head safety injection, and boric acid batching and storage.	1-TRI-62-902 1-TRI-62-903	System Inservice	VT-2	2/5 through 2/27/99	Satisfactory

Owner: TENNESSEE VALLEY AUTHORITY
 Chattanooga Office Complex
 1101 Market Street
 Chattanooga, TN 37402

Unit: 1
 Commercial Service Date: May 27, 1996

Plant: WATTS BAR NUCLEAR P
 P.O. Box 2000
 Spring City, TN 37381-2000

Certificate of Authorization: N/A
 National Board Number for Unit: N/A

WBN Unit 1 Cycle 2 RFO Pressure Test Report
 [First Inspection Interval, first period]

System	Procedure No.	Test Type	Exam	Performance Date	Test Results
Safety Injection - Train A and Common Code Class 2 safety injection system piping and components located outside containment	1-TRI-63-901-A	System Functional	VT-2	2/8/99 Note 2	Satisfactory
Safety Injection - Train B Code Class 2 safety injection system piping and components located outside containment	1-TRI-63-901-B	System Functional	VT-2	11/25/98 Note 2	Satisfactory
Safety Injection - Code Class 2 safety injection system piping and components located inside containment, exclusive of the high safety injection system piping.	1-TRI-63-902	System Functional	VT-2	3/20 through 4/16/99	Satisfactory
Safety injection - Code Class 2 high head safety injection piping and components from the interface with the Chemical and Volume Control System to the interface with the Code Class 1 boundary.	1-TRI-63-903	System Functional	VT-2	3/20/99	Satisfactory
Safety Injection - Code Class 2 safety and relief valve discharge header	1-TRI-63-904	System Functional	VT-2	3/31/99	Satisfactory
Essential Raw Cooling Water - Train A Code Class 3 ERCW piping and components supplying the Reactor Coolant Pump motor coolers.	1-TRI-67-901-A	System Inservice	VT-2	2/28/99	Satisfactory
Essential Raw Cooling Water - Train B Code Class 3 ERCW piping and components supplying the Reactor Coolant Pump motor coolers.	1-TRI-67-901-B	System Inservice	VT-2	2/28/99	Satisfactory
Essential Raw Cooling Water - Train A Code Class 3 buried supply piping	0-TRI-67-902-A	System Inservice	Delta Flow	4/5/99	Satisfactory
Essential Raw Cooling Water - Train B Code Class 3 buried supply piping	0-TRI-67-902-B	System Inservice	Delta Flow	4/5/99	Satisfactory
Essential Raw Cooling Water - Train A Code Class 3 buried discharge piping	0-TRI-67-902-A	System Inservice	Adequate Flow	4/5/99	Satisfactory
Essential Raw Cooling Water - Train B Code Class 3 buried discharge piping	0-TRI-67-902-B	System Inservice	Adequate Flow	4/5/99	Satisfactory
Essential Raw Cooling Water - Train A Code Class 3 piping and components located in the Intake Pumping Station	0-TRI-67-903-A	System inservice	VT-2	1/16 through 1/20/99 Note 2	Satisfactory
Essential Raw Cooling Water - Train B Code Class 3 piping and components located in the Intake Pumping Station	0-TRI-67-903-B	System inservice	VT-2	1/16 through 1/20/99 Note 2	Satisfactory
Essential Raw Cooling Water - Train A Code Class 3 piping and components located in the Auxiliary, Turbine, and Diesel Generator Buildings	0-TRI-67-904-A	System Inservice	VT-2	1/26 through 1/31/99 Note 2	Satisfactory
Essential Raw Cooling Water - Train B Code Class 3 piping and components located in the Auxiliary, Turbine, and Diesel Generator Buildings	0-TRI-67-904-B	System Inservice	VT-2	1/26 through 1/31/99 Note 2	Satisfactory
Essential Raw Cooling Water - Train A Code Class 3 supply and discharge piping to the Containment Spray heat exchanger 1A-A.	1-TRI-67-905-A	System Functional	VT-2	3/16/99	Satisfactory

Owner: TENNESSEE VALLEY AUTHORITY
 Chattanooga Office Complex
 1101 Market Street
 Chattanooga, TN 37402

Plant: WATTS BAR NUCLEAR PLANT
 P.O. Box 2000
 Spring City, TN 37381-2000

Unit: 1
 Commercial Service Date: May 27, 1996

Certificate of Authorization: N/A
 National Board Number for Unit: N/A

WBN Unit 1 Cycle 2 RFO Pressure Test Report
 [First Inspection Interval, first period]

System	Procedure No.	Test Type	Exam	Performance Date	Test Results
Essential Raw Cooling Water - Train B Code Class 3 supply and discharge piping to the Containment Spray heat exchanger 1B-B.	1-TRI-67-905-B	System Functional	VT-2	3/16/99	Satisfactory
Reactor Coolant System - Code Class 1 Reactor Coolant and interfacing system piping and components	1-TRI-68-6	System Leakage	VT-2	4/10/99	Satisfactory
Reactor Coolant System - Code Class 1 bolted joints	1-TRI-68-7	System Leakage	VT-2 N-533	3/2 through 3/16/99	Satisfactory
Component Cooling System - Train 1A Code Class 3 Component Cooling System piping and components located outside the reactor building.	1-TRI-70-902-A	System Inservice	VT-2	2/1/99 Note 2	Satisfactory
Component Cooling System - Train B Code Class 3 Component Cooling System piping and components located outside the reactor building	0-TRI-70-902-B	System Inservice	VT-2	1/27/99 Note 2	Satisfactory
Component Cooling System - Train 2A Code Class 3 Component Cooling System piping and components located outside the reactor building.	2-TRI-70-902-A	System Inservice	VT-2	1/27/99 Note 2	Satisfactory
Containment Spray - Train 1A Code Class 2 Containment Spray System piping and components	1-TRI-72-901-A	System Functional	VT-2	1/7/99 Note 2	Satisfactory
Containment Spray - Train 1B Code Class 2 Containment Spray System piping and components	1-TRI-72-901-B	System Functional	VT-2	1/7/99 Note 2	Satisfactory
Residual Heat Removal - Train 1B Code Class 2 Residual Heat Removal System piping and components located outside containment	1-TRI-74-901-B	System Functional	VT-2	4/6/99	Satisfactory
Residual Heat Removal - Train 1A and 1B Code Class 2 and 3 Sampling System piping and components from the interface with RHR to the Code Class break.	1-TRI-74-902	System Functional	VT-2	3/4/99	Satisfactory
Waste Disposal - Code Class 2 piping and components associated with the Reactor Coolant Drain Tank Pump discharge line penetration through the containment	1-SI-77-701	System Inservice	App. J N-522	3/11/99	Satisfactory
Spent Fuel Pool Cooling - Train A Code Class 3 Spent Fuel Pool Cooling System piping and components	0-TRI-78-901-A	System Inservice	VT-2	1/6/99 Note 2	Satisfactory
Spent Fuel Pool Cooling - Train B Code Class 3 Spent Fuel Pool Cooling System piping and components	0-TRI-78-901-B	System Inservice	VT-2	11/25/98 Note 2	Satisfactory
Spent Fuel Pool Cooling - Common Code Class 3 Spent Fuel Pool Cooling System piping and components	0-TRI-78-901-S	System Inservice	VT-2	12/22/98 Note 2	Satisfactory
Spent Fuel Pool Cooling - Common Code Class 2 Spent Fuel Pool Cooling System piping and components associated with the reactor cavity cleanup containment penetration	1-TRI-78-902	System Inservice	VT-2	3/6/99	Satisfactory

Owner: TENNESSEE VALLEY AUTHORITY
Chattanooga Office Complex
1101 Market Street
Chattanooga, TN 37402

Unit: 1

Commercial Service Date: May 27, 1996

Plant: WATTS BAR NUCLEAR P
P.O. Box 2000
Spring City, TN 37381-2000

Certificate of Authorization: N/A
National Board Number for Unit: N/A

Notes:

1. This test was completed during power escalation following the Cycle 2 outage.
2. This test was completed as part of the pre-outage work before removing the unit from service for the start of the Cycle 2 outage.
3. This test was completed during RFO1, but was inadvertently not included in the RFO1 report.
4. One remaining test, to be performed under 1-SI-43-901-A, will be performed on the containment penetrations associated with the Post Accident Sampling System return lines to containment prior to May 26, 1999.

Owner: TENNESSEE VALLEY AUTHORITY Chattanooga Office Complex 1101 Market Street Chattanooga, TN 37402	Plant: WATTS BAR NUCLEAR PLANT P.O. Box 2000 Spring City, TN 37381-2000
Unit: 1 Commercial Service Date: May 27, 1996	Certificate of Authorization: N/A National Board Number for Unit: N/A

APPENDIX IV
REPORT FOR REPAIRS AND REPLACEMENTS
ASME FORM NIS-2

Attached are the ASME Form NIS-2s, Report for Repairs and Replacements, for the period from September 1, 1997 to completion of the second cycle refueling outage, April 16, 1999.

The following table lists by tracking number the NIS-2s included in this report.

TRACKING NUMBER	CODE CLASS	COMPONENT	DESCRIPTION
RR-02-004	2	1-MISC-043-SPARE	Repair valve. Tackweld 3 bonnet to body welds
RR-02-009	1	1-DRV-068-0566	Revise piping class from CC2 to CC1 for 3/4" loop seal drain line from PRZ safety RFVs up to and including 1-LT-068-0320.
RR-02-013	2	1-DRV-001-0536	Repair valve
RR-02-014	2	1-ISV-001-0542	Replace valve
RR-02-015	2	1-PPG-078	Install 2" pipe w/cap over 1" coupling and plug to stop leak.
RR-02-024	2	1-CKV-063-0725	Remove/replace seal weld on bonnet
RR-02-025	1	1-PCV-068-0334	Repair valve, replace disk
RR-02-030	1	1-PMP-068-0073	Replace cartridge seal and #1 seal on RCP 4
RR-02-031	2	1-RFV-062-0649-S	Replace RFV
RR-02-033	1	1-RFV-068-0563	Remove/replace Pressurizer safety relief valves and some bolting
RR-02-035	1	1-PCV-068-334-B	Remove/replace safety relief valve
RR-02-036	2	1-RFV-062-0626-A	Remove/replace safety relief valves
RR-02-037	2	1-CKV-003-0508	Remove/replace safety relief valve
RR-02-039	1	1-PCV-068-0340-A	Remove/replace valve
RR-02-040	1	1-PMP-068-0031	Replace cartridge seal on RCP
RR-02-041	2	1-SGEN-068-SG4	Replace upper support splice bolts on SG #4
RR-02-043	2	1-SGEN-068-SG2	Replace upper support splice bolts on SG #2
RR-02-044	2	1-SGEN-068-SG1	Replace upper support splice bolts on SG #1
RR-02-045	2	1-PIPE-015	Replace piping due to FAC
RR-02-046	2	1-PIPE-015	Replace piping due to FAC
RR-02-047	2	1-PIPE-015	Replace piping due to FAC
RR-02-048	2	1-PIPE-015	Replace piping due to FAC
RR-02-049	2	1-PIPE-003	Replace piping due to FAC
RR-02-050	2	1-PIPE-003	Replace piping due to FAC
RR-02-051	2	1-PIPE-003	Replace piping due to FAC
RR-02-052	2	1-PIPE-003	Replace piping due to FAC
RR-02-059	2	ELHx	Replace head flange studs
RR-02-061	2	1-CKV-067-0580C-A	Replaced disc
RR-02-086	1	1068-1-68-415	Replace bolts and nuts on pipe clamp
RR-02-087	2	1-SGEN-068-SG4	Replaced secondary manway cover
RR-02-088	2	1-SNUB-062-62A242	Replace snubber
RR-02-089	2	1-SGEN-068-SG2	Repair secondary manway cover
RR-02-090	2	1-PIPE-015	Replace 4 x 2 reducers on LP 1 and 4

Owner: TENNESSEE VALLEY AUTHORITY
Chattanooga Office Complex
1101 Market Street
Chattanooga, TN 37402

Plant: WATTS BAR NUCLEAR PLANT
P.O. Box 2000
Spring City, TN 37381-2000

Unit: 1

Commercial Service Date: May 27, 1996

Certificate of Authorization: N/A
National Board Number for Unit: N/A

TRACKING NUMBER	CODE CLASS	COMPONENT	DESCRIPTION
RR-02-090	2	1-PIPE-015	Replace 4 x 2 reducers on LP 1 and 4
RR-02-091	2	1-PIPE-015	Replace 4 x 2 reducers on LP 2 and 3
RR-02-092	1	CRDM-13	Repair canopy seal weld
RR-02-093	2	1-PIPE-61	Add 2" tee to re-route bypass pipe around 1-FCV-061-0122
RR-02-094	2	1-PIPE-61	Add 2" tee to re-route bypass pipe around 1-FCV-061-0097
RR-02-096	2	1-SGEN-068-SG3	Replace secondary manway cover studs
RR-02-099	2	1-SNUB-003-03A482U	Replace snubber
RR-02-100	2	1-SNUB-015-4006188	Replace snubber
RR-02-101	2	1-SNUB-015-4006199	Replace snubber

Copy 6/5/88

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY
Name
 400 W. Summit Hill Drive, Knoxville, TN

Date 05-29-98

Sheet _____ of _____

2. Plant Watts Bar Nuclear Plant
Name
 P. O. Box 2000, Spring City, TN, 37381

Unit Unit 1

WGC # 97-014550-000

3. Work Performed by WATTS BAR NUCLEAR PLANT
Name
P.O. Box 2000 Spring City, TN 37381
Address

Repair Organization P. O. No., Job No., etc.
 Type Code Symbol Stamp _____

Authorization No _____

Expiration Date _____

N/A
KLL 5/29/98

4. Identification of system 043 Sampling

5. (a) Applicable Construction Code SEC. III Div 1 19 80 Edition, W-80 Addenda, N/A Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No	National Board No	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
(Fev) VALVE	TARGET ROBE CORPORATION	8	NONE	i-misc 043 STAKE VALVE	1983	REPAIRED	YES

7. Description of Work REPAIR VALVE. TACKWELD BONNET to Body. (3) TACK WELDS

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks NPV-1

Tracking # RR-02-04

Additional Manufacturers Code Reports to be Attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPAIR conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NIA

Certificate of Authorization No. NIA

Signed ASCTB - Mech. Eng'r Date 6/4/98 19 98
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENNESSEE and employed by THE HSB L.I. Co. of HARTFORD, C.T. have inspected the components described in this Owner's Report during the period 2-13-98 to 6-4-98 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

C.E. Mitcove
Inspector's Signature

Commissions NB-6260
National Board, State, Province, and Endorsements

Date JUNE 5 19 98

136

FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*
As Required by the Provisions of the ASME Code, Section III, Div. 1

1. Manufactured by Target Rock Corporation 1966E Broadhollow Rd E. Farmingdale, N.Y. 11735
(Name and Address of N Certificate Holder)
2. Manufactured for Tennessee Valley Authority Chattanooga, Tennessee
(Name and Address of Purchaser or Owner)
3. Location of Installation Watts Bar Nuclear Plant, Unit 2 Near Spring, Tennessee
(Name and Address)
4. Pump or Valve Valve Nominal Inlet Size 3/8 Outlet Size 3/8
(inch) (inch)

	(a) Model No., Series No. or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Nat'l Std. No.	(g) Year Built
(1)	82KK	4, 6, 8, 12, 14	-----	82KK-003	3	-----	1983
(2)	82KK	18, 22, 26, 28, 30	-----	82KK-003	3	-----	1983
(3)	82KK	4, 8, 12, 18, 30	-----	82KK-003-1	2	-----	1983
(4)							
(5)							
(6)							
(7)							
(8)							
(9)							
(10)							

5. POST ACCIDENT SAMPLING (CONTAINMENT AIR)
(Brief description of service for which equipment was designed)
6. Design Conditions 50 (Pressure) psi 110/337 (Temperature) °F or Valve Pressure Class 150 (1)
7. Cold Working Pressure 230 psi at 100°F.
8. Pressure Retaining Pieces

TVA
15
CMK

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
(b) Forgings			

WBN-Watts Bar Unit 2
PAGE 5 OF 38

(1) For manually operated valves only

* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2" x 11", (2) information in items 1, 2 and 5 on this Data Report is included on each sheet and (3) each sheet is numbered and number of sheets is recorded at top of first form.

Approved 6-27-05
 F. Charney, Director, TME
 Date

FORM NPV-1 (Back)

135 ✓

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting			
(d) Other Parts			
Nipple	ASME SA 213 SS 316U	Teledyne Columbin-Sumerill	
Bonnet	ASME SA 479 SS 316	Universal Cyclops	
Bonnet	ASME SA 479 SS 316	Carpenter Tech.	
Disc	ASME SA 479 SS 316	ARMCO	
Body	ASME SA 479 SS 316U	Universal Cyclops	
Body	ASME SA 479 SS 316U	Carpenter Tech.	

9. Hydrostatic test 350 psi. Disk Differential test pressure 275 psi.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. 1, Edition 1980

Addenda W-80 Code Case No. _____ Date _____

Signed Target Rock Corporation by G. Abuzzo 11-7-83
(N Certificate Holder) (Date)

Our ASME Certificate of Authorization No. 1947 to use the _____ symbol expires 12/9/83
(NI) (Date)

TVA
15
CMK

CERTIFICATION OF DESIGN

Design information on file at Target Rock Corporation

Stress analysis report (Class 1 only) on file at _____

Design specifications certified by (1) Arie F. Massey Jr.

PE State NY Reg. No. 013459

Stress analysis certified by (1) _____

PE State _____ Reg. No. _____

(1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of New York and employed by Commercial Union Insurance of Boston, Mass. have inspected the pump, or valve, described in this Data Report on 11/9 19 83 and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

William A. Delaney 11/9/83
Inspector Commission No. _____ NEW YORK STATE COMMISSION NO. 2288
ALSO COMMISSIONED IN Penn., Ohio & Conn.
Natl. Bd. State Prov. and No. _____

PAGE 1 OF 1
TVA 15 CMK

133



Target Rock Corporation, 1956E Broadhollow Rd., P.O. Box V, Farmingdale, N.Y. 11735-0917

SUBSIDIARY, CURTISS-WRIGHT CORPORATION

CERTIFICATE OF CONFORMANCE

CUSTOMER: Tennessee Valley Authority
FOR: Watts Bar Nuclear Plant
CUSTOMER P.O. #: 93NNS-75918A C/O # 4
TRC PROJECT #: 93Z-507
MODEL #: 82KK-003-1
PRODUCT: 3/8" Solenoid Valve
P.O. Item 001, QTY 5

<u>S/N</u>	<u>Taq. No.</u>
4	1-FSV-43-207
8	1-FSV-43-434
14	1-FSV-43-202
18	1-FSV-43-208
30	1-FSV-43-436

We certify that the parts noted herein meet all the requirements of the Purchase Order, Drawing and Specifications. Further we certify that the detailed fabrication, inspection and test records quoted in the order and specifications are traceable and are on file.

TRC Quality Manual, Edition 5, Revision 8, Dated 10/13/92 is applicable.

E. Champey / / Date 1/29/94
Director, Quality Assurance

WBN- [unclear] [unclear] [unclear]
PAGE 3



Target Rock Corporation, 1966E Broadhollow Rd., P.O. Box V, Farmingdale, N.Y. 11735-0917

SUBSIDIARY, CURTISS-WRIGHT CORPORATION

134

CERTIFICATE OF CONFORMANCE

CUSTOMER: Tennessee Valley Authority
FOR: Watts Bar Nuclear Plant
CUSTOMER P.O. #: 93NNS-75918A C/O # 4
TRC PROJECT #: 93Z-507
MODEL #: 82KK-003-1
PRODUCT: Current Control Unit
P.O. Item 002, QTY 5
S/N's 001-005

We certify that the parts noted herein meet all the requirements of the Purchase Order, Drawing, and Specifications. Further we certify that the detailed fabrication, inspection and test records quoted in the order and specifications are traceable and are on file.

TRC Quality Manual, Edition 5, Revision 8, Dated 10/13/92 is applicable.

E. Champey / 4/19/94
E. Champey / Date
Director, Quality Assurance

WBN. 5116 293-3800
PAGE 7 OF

Tracking No. RR-02-09

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner <u>TENNESSEE VALLEY AUTHORITY</u> <small>Name</small> 400 W. Summit Hill Drive, Knoxville, TN <small>Address</small>	Date <u>5-18-98</u> Sheet <u>1</u> of <u>2</u>
2. Plant <u>Watts Bar Nuclear Plant</u> <small>Name</small> P. O. Box 2000, Spring City, TN, 37381 <small>Address</small>	Unit <u>Unit 1</u> S-39842-A Repair Organization P.O. No., Job No., etc.
3. Work Performed by <u>Site Engineering Mechanical</u> <small>Name</small> <u>EQB-2N</u> <small>Address</small>	Type Code Symbol Stamp <u>N/A</u> Authorization No <u>N/A</u> Expiration Date <u>N/A</u>
4. Identification of system <u>Reactor Coolant System (RCS) 068</u>	
5. (a) Applicable Construction Code <u>ASME III 19 74 Edition, Winter Addenda, N/A Code Case 1974</u> (b) Applicable Edition of Section XI Utilized for Repairs or Replacements <u>1989</u>	
6. Identification of Components Repaired or Replaced and Replacement Components	

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1-DRV-068-0566	Kerotest	KZ29-8 *	N/A	TVD-D-9954(2)	1976	Replacement	N/A
1-DRV-068-0567	Kerotest	KZ28-18 *	N/A	TVD-D-9954(2)	1976	Replacement	N/A
1-DRV-068-0568	Kerotest	KZ24-3 *	N/A	TVD-D-9954(2)	1976	Replacement	N/A
1-RTV-068-0441A	Kerotest	KZ29-10 *	N/A	TVD-D-9954(2)	1976	Replacement	N/A
1-RTV-068-0569	Kerotest	KZ22-10 *	N/A	TVD-D-9954(2)	1976	Replacement	N/A

7. Description of Work Revise Piping Class from SC-2 to SC-1 for 3/4" loop seal drain line from pressurizer safety relief valves 1-RFV-068-563, -564 & -565 up to and including instrument loop to 1-LT-068-0320.
 * Associated with N5 package X68-F1

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

PAGE 9 OF 107

FORM NIS-2 (Back)

9. Remarks Tracking No. RR-02-09

Applicable Manufacturers Data Reports to be Attached

No physical work has been performed on these valves per DCN S-39842-A. This DCN documents Safety

Class reclassification for subject Valves. Requirements of NB-3513 for minimum wall thickness have been

reviewed and valves meet min. wall requirements. Hydro-test per NB-3531 (Table NB-3531-9) have been

performed per existing NPV-1 forms for valves listed on page 1.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp _____ N/A

Certificate of Authorization No. _____ N/A

Signed Robert D. Briggs Date JUNE 3 19 98
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by Hartford Steam Boiler I & I Co. of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 4-12-97 to 6-3-98 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

George Deaton
Inspector's Signature

Commissions TN 3178
National Board, State, Province, and Endorsements

Date 6-3 19 98

PAGE 1306

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
 As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY
Name
400 W. Summit Hill Drive, Knoxville, TN
Address

Date 6/17/98
 Sheet _____ of _____

2. Plant Watts Bar Nuclear Plant
Name
P. O. Box 2000, Spring City, TN, 37381
Address

Unit Unit 1
 W/O # 98-002830-001
Repair Organization P.O. No., Job No., etc.

3. Work Performed by WATTS BAR Nuclear Plant
Name
P.O. Box 2000 Spring City, TN 37381
Address

Type Code Symbol Stamp NA
 Authorization No NA
 Expiration Date NA

4. Identification of system 001 MAIN STEAM

5. (a) Applicable Construction Code SEC. III CL 2 1974 Edition, Winter 1974 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Globe Valve	YARWAY CORP.	8810	NONE	1-DRV-001-0536	1977	REPLACED	YES
GLOBE VALVE	YARWAY CORP.	6927	NONE	2-DRV-001-0537	1977	REPLACEMENT	YES

7. Description of Work REV. 1, REPLACE VALVE

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure NOP psi Test Temp NOT °F

TE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

DACP

FORM NS-2 (Back)

9. Remarks REFERENCE Code CASE N-416-1

Tracking # RR-02-13 RR 4/10/00

CERTIFICATE OF COMPLIANCE

REV. 1

REPLACE Q# 3/24/99

We certify that the statements made in the report are correct and this REPAIR conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NONE

Certificate of Authorization No. NA

Signed W H Collins Mech Engr. Date 5/29 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I & I co. of Hartford CT. have inspected the components described in this Owner's Report during the period 6/18/98 to 6/1/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce M. Earnigh
Inspector's Signature

Commissions TN. 2534 "I" "N" "A"
National Board, State, Province, and Endorsements

Date 6/1 19 99

As Required by the Provisions of the ASME Code Rules

Manufactured by Yarway Corporation, Pine Bell, Pa. Order No. 45082
(Name & Address of Manufacturer)

Manufactured for Dravo Corporation Order No. SEE MASTER IDENTIFICATION LIST
(Name and Address)

Owner Tennessee Valley Authority **W 860724K1471 (4)**

Location of Plant Spring City, Tenn.

Pump or Valve Identification Nuclear Service Line Valves, 2" Globe, Serial Nos. 6905 Thru 6329
(Brief description of service for which equipment was designed)

(a) Drawing No. 103271-07 Prepared by Yarway Corporation **FILMED FROM BEST AVAILABLE COPY**

(b) National Board No. None

Design Conditions 2665 psi 700 °F or Pressure Class 1500 PSI (1)
(Pressure) (Temperature)

Material, design, construction, and workmanship complies with ASME Code Section III, Class 2
 Edition 1974, Addenda Date Winter 1974, Case No. 7

	Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings	A6-A7	A5S 5382	Nova/Howmet	Disc
(b) Forgings	3	SA05	Pittsburgh Forging	Body
	YW 728	SA 193-B 7	Republic Steel	Backseat Bushing

(1) For manually operated valves only.

*Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 11" x 17" (2) information on this data report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

DATE
 12-21-76
INITIALS

PAGE 12 OF 197

42X

FORM NPV-1 (back)

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting	None		
(d) Other Parts	None		

8. Hydrostatic test. 5400 psi.

CERTIFICATION OF DESIGN

FILMED FROM BEST AVAILABLE COPY

Design information on file at T.V.A. Knoxville, Tenn.
 Stress analysis report on file at Not Required
 Design specifications certified by George F. Dilworth (i) Prof. Eng. State Tenn. Reg. No. 4855
 Stress analysis report certified by Not Required (i) Prof. Eng. State Reg. No.
 (1) Signature not required. List name only.

We certify that the statements made in this report are correct.

Date Nov. 22, 1976 Signed Yarway Corporation By W. A. Voiger
 (Manufacturer)

Certificate of Authorization No. N899 expires Oct. 28, 1977

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors
 and/or the State or Province of Pennsylvania and employed by Phila. Manufacturers Mutual Ins. Co.
 of Philadelphia, Pa. have inspected the equipment described in this Data


Report on November 22, 1976, and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Code, Section III.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date November 22, 1976

David L. Doolittle
 (Inspector)
 David L. Doolittle

NB 7525 Pa. 2159
 (National Board, State, Province and No.)



BACK

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 5/6/99
Name
400 W. Summit Hill Drive, Knoxville, TN Sheet of
Address

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
P. O. Box 2000, Spring City, TN, 37381 w/o # 98-02830-00
Address Repair Organization P. O. No., Job No., etc.

3. Work Performed by WATTS BAR NUCLEAR PLANT Type Code Symbol Stamp N/A
Name
P. O. Box 2000 Spring City, TN 37381 Authorization No N/A
Address Expiration Date N/A

4. Identification of system 001 MAIN STEAM

5. (a) Applicable Construction Code ASME SEC III SUB 1974 Edition, W74 Addenda NONE Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Globe Valve	YARWAY CORP	8733	NONE	1-BV-001-0542	77	REPLACED	YES
Globe Valve	YARWAY CORP	8730	NONE	2-DRV-050505	77	REPLACED	YES

7. Description of Work REPAIR REPAIR VALVE ; REPAIR REPLACED VALVE

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure NOP psi Test Temp NOT °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

REV. 1

FORM NIS-2 (Back)

9. Remarks REFERENCE CODE CASE N-416-1

Tracking # RR-02-14 6/10/98

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACE IN 3/24/98 conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp NH

Certificate of Authorization No. NIA

Signed HAS:TD - Mech Eng Date 5/6 19 98
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I & I CO. of HARTFORD CT. have inspected the components described in this Owner's Report during the period 6/13/98 to 5/10/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce M. Carrigh
Inspector's Signature

Commissions TN 2534 "I" "N" "A"
National Board, State, Province, and Endorsements

Date 5/10 19 99

FORM NO. 1 MANUFACTURERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES

As Required by the Provisions of the ASME Code Rules

CASTING U1
VL S/N 8733

U2 VLU S/N 8730

Manufactured by Yarway Corporation, Blue Bell, Pa. Order No. 45092
(Name & Address of Manufacturer)

2. Manufactured for Dravo Corporation Order No. E2S97 & E2S98
(Name and Address)

3. Owner Tennessee Valley Authority **W 860724K1554 (2)**

4. Location of Plant Spring City, Tenn.

5. Pump or Valve Identification Nuclear Service Line Valves, 2" and smaller, Serial Nos. 8728 Thru 8752
(Brief description of service for which equipment was designed)

(a) Drawing No. 103271-07 Prepared by Yarway Corporation

(b) National Board No. None

6. Design Conditions 2665 psi 700 °F or Pressure Class 100
(Pressure) (Temperature)

7. The material, design, construction, and workmanship complies with ASME Code Section III, Class 2
Edition 1974, Addenda Date Winter 1974, Case No. _____

	Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings	A7 & A8	AMS 5382	Nova/Howmet	Disc
(b) Forgings	3 & 6	SA105	Pittsburgh Forging	Body
	YW 781	SA 182 F6	Al Tech Steel	Backseat Bushing

HARD COPY RETAINED

FILMED FROM BEST AVAILABLE COPY

AUTHORIZED
1021
NUCLEAR INSPECTOR
H. S. B.

(1) For manually operated valves only.

*Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2" x 11", (2) information in items 1, 2, 5a and 5b on this data report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

Work No.	Material Spec. No.	Manufacturer	Remarks
(c) Bulking None			
ACC. # 21005			
(d) Other Parts None			

HARD COPY RETAINED

FILMED FROM BEST AVAILABLE COPY

8. Hydraulic test 5400 psi.

CERTIFICATION OF DESIGN

Design information on file at T. V. A. Knoxville, Tenn.
 Stress analysis report on file at Not Required
 Design specifications certified by George E. Drlworth
 Stress analysis report certified by Not Required
 (1) Signature not required. List name only.

We certify that the statements made in this report are correct.

Date March 25, 1977 Signed Yarway Corporation by W. A. Volz
(Manufacturer)

Certificate of Authorization No. N899 expires Oct. 28, 1977

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Province of Pennsylvania and employed by Phillips Manufacturing System of Philadelphia, Pa. have inspected the equipment described in this Data Report on March 25, 1977 and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date March 25, 1977

D. Daulton
(Inspector)
 David L. Daulton

Commission No. NB 7525 Pa. 2159
(National Board, State, Province and Reg.)

*Part of the Factory Mutual System

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 07/07/98
Name
400 W. Summit Hill Drive, Knoxville, TN Sheet _____ of _____
Address

2. Plant Watts Bar Nuclear Plant Unit Unit 0
Name
P. O. Box 2000, Spring City, TN, 37381 Work Order 98-007689-000
Address

3. Work Performed by Mech. Maint. WBN Repair Organization P.O. No., Job No., etc.
Name Type Code Symbol Stamp _____
P. O. Box 2000, Spring City, TN. 37385 Authorization No. _____
Address Expiration Date _____

4. Identification of system 078, SPENT FUEL PIT COOLING

5. (a) Applicable Construction Code SEC III, CL. 2 19 71 Edition, SUMMER 73 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPING	N/A	N/A	N/A	N/A	N/A	REPLACED	NO
N/A							
N/A							
N/A							
N/A							
N/A							
N/A							
N/A							

7. Description of Work Install 2" pipe w/cap over 1" cplg. and plug to stop leak.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp N/A °F *Static Head Pressure only*

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

DATE 7/14/98
PAGE 1 OF 1

FORM NIS-2 (Back)

9. Remarks Tracking # RR-02-15
Applicable Manufacturer's Data Reports to be Attached

CODE CASE N-416-1 WELDING

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp _____

Certificate of Authorization No. NR

Signed James D. Coulter Steamfitter Foreman Date 7.24.98 19 _____
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB ICI CO. of HARTFORD CONN. have inspected the components described in this Owner's Report during the period 7/7/98 to 7/24/98 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce M. Earnigh Commissions TN 2534
Inspector's Signature National Board, State, Province, and Endorsements

Date 7/24 19 98

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 09/20/98
Name
400 W. Summit Hill Drive, Knoxville, TN
Address

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
P. O. Box 2000, Spring City, TN, 37381
Address MMG 98-008416-001

3. Work Performed by WATTS BAR NUCLEAR PLANT Repair Organization P.O. No., Job No., etc.
Name Type Code Symbol Stamp N/A
P.O. BOX 2000, SPRING CITY, TN 37381
Address Authorization No N/A

4. Identification of system SIS, SAFETY INJECTION SYSTEM, 063
 Expiration Date N/A

5. (a) Applicable Construction Code ASME SEC. III 19 74 Edition, S'75 Addenda, NONE Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1-CKV-063-0725	ROCKWELL INTERNATIONAL	GD187-8,476-10 CD787	N/A	NONE	1987	REPAIR	YES
1-CKV-063-0725	ROCKWELL INTERNATIONAL	CD787	N/A	BONNET	1987	REPAIR	YES

7. Description of Work REMOVE/REPLACE SEAL WELD ON BONNET.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 100 psi Test Temp 400 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

PAGE 1 OF 1

FORM NIS-2 (Back)

9. Remarks

Applicable Manufacturer's Data Reports to be Attached

TRACKING # RR-02-24 JTC 4/21/98

REF. CODE CASE N416-1

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPAIR conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NONE.

Certificate of Authorization No. NONE.

Signed [Signature] Date 4-5 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TN and employed by HSAI-I Co. of Hartford, CT have inspected the components described in this Owner's Report during the period 9-21-98 to 4-5-99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions TN 2533
Inspector's Signature National Board, State, Province, and Endorsements

Date 45 19 99

1. Manufactured by Rockwell International, P.O. Box 501, Sulphur Springs, Texas 75482
(Name and Address of Manufacturer)

2. Manufactured for Tennessee Valley Authority, 111 Dupon Bldg., Chattanooga, TN 37401
(Name and Address of Purchaser or Owner)

3. Location of Installation Tennessee Valley Authority, Watts Bar Nuclear Plant, Spring City, TN 37381
(Name and Address)

4. Name of Valve Valve - Check Nominal Inlet Size 2" Outlet Size 2"
(Inches) (Inches)

	(a) Model No.	(b) M Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Mfg. Bd. No.	(g) Year Built
	(1)	B36174E316JT2	GD787-GD788	NA	BH 1607432	?	NA
(2)							
(3)							
(4)							
(5)							
(6)							
(7)							
(8)							
(9)							
(10)							

5. Rockwell International Assembly Lot No. 11, 01, 2
(Brief description of service for which equipment was designed)

ASD Drawing No. C-31607432-None

6. Design Conditions 225° per 300 of Valve Pressure Class 1500
(Temperature) (Temperature)

7. Cold Working Pressure 3000 psi at 100°F

8. Pressure Retaining Pieces

Mark No.	Material Spec No.	Manufacturer	Remarks
(a) Castings			
Diska G1308#1	A567GP	Consolidated	Heat
Diska G0823#1	A567GR1	Consolidated	Heat
(b) Forgings			
Bodies SK501 HT#2	SA182F316	Texas Forge	LTV Steel Heat 8650309
Bodies FXE	SA182F316	Trinity Forge	Carpenter Heat 66474

PAGE 03 OF 03

(1) For manually operated valves only.

* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8-1/2" x 11", (2) information in items 1, 2 and 5 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

342115230
Page 13 of 42

IVA
71
29

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Boring NA			PL 9-11-93 W0 77078750 93-003416-001
(d) Other Parts			
Covers G0290	SA479TJ16	Coulter	Slater Hent 89049
Sealheld Filler	SFAS.9ERJ08	Teledyne McKay	Hent C-7066

Hydraulic test 5400 psi Over Differential test pressure 1600 psi

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. 1, Edition 1975.

Issued Summer 1975 Code Case No. None Date 6/2/97
 Signed Rockwell International (in Certificate Holder's Name) by [Signature]
 Our ASME Certificate of Authorization No. N-1816 to use the (N) symbol expires 8/12/99

CERTIFICATION OF DESIGN

Design information on file at Rockwell International, Sulphur Springs, Texas
 Stress analysis report (Class I only) on file at Not Applicable

Design specifications certified by (I) L. Ike Ezakoye
 PE State PA Reg. No. 18179-E
 Stress analysis certified by (I) Not Applicable
 PE State _____ Reg. No. _____

(I) Signature not required. Use name only

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Texas and employed by Victoria Lloyds' Ins. Co. of Houston, Texas 77098 have inspected the pump, or valve, described in this Data Report on 6-1-97 and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 6-2-97
[Signature] (Inspector) Commission Texas 595
(Not Bd., State, Prov. and No.)

STANWISSE 20
 Page 14 of 47

30

WBN PAGE 24 OF 187

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 03/23/1999
Name
400 W. Summit Hill Drive, Knoxville, TN Sheet of
Address

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
P. O. Box 2000, Spring City, TN, 37381 Contract 1241878
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Target Rock Type Code Symbol Stamp N/A
Name
1966E Broadhollow Rd, E. Farmingdale, NY 11735 Authorization No N/A
Address Expiration Date N/A
 (note work performed at Wyle Labs)

4. Identification of system 068, Reactor Coolant System

5. (a) Applicable Construction Code ASME Sec III 19 80 Edition, W80 Addenda, n/a Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1-PCV-68-340A-A	Target Rock	5		Model 83A	83	repaired	Y
main disc	Target Rock	8		P/N 300891-1	97	replacement	Y
main seat insert	Target Rock	n/a		P/N 200783-1	85	replacement	N
pilot disc	Target Rock	n/a		P/N 202918-1	95	replacement	N
1-PCV-68-0334-B	Target Rock	4		Model 83A	83	repaired	Y

7. Description of Work serial number 5 - replaced main seat disc & insert & pilot disc; seal welded both valves

Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other x Pressure 2235 psi Test Temp ambient °F
 Wyle test procedure #1056

⚠: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Tracking Number RR-02-025

Applicable Manufacturers Data Reports to be Attached

Valve serial number 4 was installed under WO 98-012709-000.

Valve serial number 5 was installed under WO 98-013995-000.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp n/a

Certificate of Authorization No. n/a

Signed James E. Casey ISI SPECIALIST Date 6/3 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I & I Co. of Hartford CT. have inspected the components described in this Owner's Report during the period 9/30/98 to 6/7/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce M. Earnigh Commissions TN 2534 I "N" A"
Inspector's Signature National Board, State, Province, and Endorsements

Date 6/7 19 99

FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES
As Required by the Provisions of the ASME Code, Section III, Div. 1

7

1. Manufactured by Tarzer Rock Corporation 1966E Broadhollow Rd E. Farmingdale, N.Y.
(Name and Address of N Certificate Holder)

2. Manufactured for Tennessee Valley Authority Chattanooga, Tennessee
(Name and Address of Purchaser or Owner)

3. Location of Installation Sequoyah Nuclear Plant, Daisy, Tennessee
(Name and Address)

4. Pump or Valve Valve Nominal Inlet Size 3 (inch) Outlet Size 3 (inch)

(a) Model No. (b) N Certificate Holder's Serial No. (c) Canadian Registration No. (d) Drawing No. (e) Class (f) Nat'l. Bd. No. (g) Year Built

(1) 87A 5 5 8200-001 1 1983

(4) W860724K1153 (2)

FILMED FROM BEST AVAILABLE COPY

5. PRESSURIZED RELIEF POWER RELIEF VALVE
(Brief description of service for which equipment was designed)

6. Design Conditions 2485 psi 680 °F or Valve Pressure Class 1707 (1)
Cold Working Pressure 4100 psi at 100°F.

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
(b) Forgings			
Body	ASME SA 182, F316L	Carmel Forge	

TVA 15 CMK

RECEIVED
DEC 08 1983
BTL

209 No.

PAGE 27 OF 187

(1) For manually operated valves only.
* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 3-1/2" x 11", (2) information in items 1, 2 and 5 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

**FORM N-2 CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL
NUCLEAR PARTS AND APPURTENANCES***

As Required by the Provisions of the ASME Code, Section III
Not to Exceed One Day's Production

Pg. 1 of 2

- 1 Manufactured and certified by Target Rock, 1966E Broadhollow Rd, E Farmingdale, NY 11735
(name and address of NPT Certificate Holder)
- 2 Manufactured for Tennessee Valley Authority, Chattanooga, TN 37402-2801
(name and address of Purchaser)
- 3 Location of installation Watts Bar Nuclear Plant, Spring City, TN 37381
(name and address)
- 4 Type 300891-1 SA479 347 75 ksi N/A 1997
(drawing no) (mat'l spec no) (tensile strength) (CRN) (year built)
- 5 ASME Code, Section III, Division 1 1980 Winter 1980 1 None
(edition) (addenda date) (class) (Code Case no)
- 6 Fabricated in accordance with Const. Spec (Div 2 only) N/A Revision N/A Date N/A
(no)
- 7 Remarks Main Disc Assembly
Spare parts for valve Model No 82UU-001
- 8 Num. Thickness (in) N/A Min. design thickness (in) N/A Dia ID (ft & in) N/A Length overall (ft & in) N/A
- 9 When applicable Certificate Holders' Data Reports are attached for each item of this report

Part or Appurtenance Serial Number	National Board NO In Numerical Order	Part or Appurtenance Serial Number	National Board NO In Numerical Order
(1) <u>8</u>	<u>N/A</u>	(26)	
(2) <u>9</u>		(27)	
(3) <u>N/A</u>		(28)	
(4)		(29)	
(5)		(30)	
(6)		(31)	
(7)		(32)	
(8)		(33)	
(9)		(34)	
(10)		(35)	
(11)		(36)	
(12)		(37)	
(13)		(38)	
(14)		(39)	
(15)		(40)	
(16)		(41)	
(17)		(42)	
(18)		(43)	
(19)		(44)	
(20)		(45)	
(21)		(46)	
(22)		(47)	
(23)		(48)	
(24)		(49)	
(25)		(50)	

10 Design pressure N/A psi Temp N/A °F Hydro Test pressure 4510 psig at temp °F
(when applicable) Ambient

* Supplemental information in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form

(12/88) This form (E00040) may be obtained from the Order Dept., ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300 REPRINT (7/91)

WBN-TVA-F-50-1152
 PAGE 3 OF 19
 PAGE 30 OF 787

FORM N-2 (BACK - Pg. 2 of 2)

Certificate Holder's Serial Nos 8 through 9

CERTIFICATION OF DESIGN

Design specifications certified by Marvin v Miller P E State TN Reg No 013995
(when applicable)
Design report* certified by Martin Goldstone P E State NY Reg No 031940
(when applicable)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this (these) _____ Part _____ conforms to the rules for construction of the ASME Code, Section III, Division 1

NPT Certificate of Authorization No N-1948 Expires 12/12/98

Date 7/24/97 Name Target Rock Signed [Signature]
(NPT Certificate Holder) R. E. Glazier, Manager, Q E
(authorized representative)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Province of New York and employed by Commercial Union Insurance Co of Boston, MA have inspected the pump, or valve, described in this Data Report on 7/24/97 and state that to the best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section III, Division 1. Each part listed has been authorized for stamping on the date shown above.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 7/24/97 Signed [Signature] N. Y. STATE COMMISSION NO. 2288
Authorized Inspector ALSO COMMISSIONED IN PENN., OHIO & CONN.
(Nat'l Bd. (incl. endorsements) and state or prov. and no.)

WBN-IVA-R97-1292
PAGE 4 OF 19



Target Rock Corporation, 1966E Broadhollow Road, P.O. Box 379 Farmingdale N.Y. 11735-0379

CERTIFICATE OF CONFORMANCE

CUSTOMER: Tennessee Valley Authority
FOR: Watts Bar Nuclear Plant
CUSTOMER P.O. #: P87ZNR-467870-000 Release # 1181193
PROJECT #: 97S-102

PRODUCT:	P O ITEM	P/N	QTY	S/N	CURE DATE	EXP DATE
Main Disc Assembly	0001	300891-1	2	8, 9	-	-
Gasket	0002	200989-2	4	-	3Q95	3Q2015


We certify that the parts noted herein meet all the requirements of the purchase order, drawing and specifications. Further we certify that all final inspections and tests required to verify conformance of the items have been performed, and that the detailed fabrication, inspection and test records quoted in the order and specifications are traceable and are on file.

The shelf life of Silicone Rubber (Item No 002) is 20 years when the material is stored in clean dry containers, away from contaminants, sunlight and radiation, at a temperature not to exceed 120°F.

Target Rock Quality Assurance Manual, Edition 7, Revision 0, dated 05/22/97 is applicable.

We certify that the items supplied are the same in design and materials and were manufactured under the same process and quality controls as those items qualified by Target Rock Qualification Test Report Nos 3524 Rev. A and 3543 Rev. Original.

WBN-TVA-R97-1292	
PAGE 2	19


 R. E. Glazier 7/24/97
 Manager, Quality Engineering Date

PAGE 32 OF 187



Target Rock Corporation, P.O. Box V, 1966E Broadhollow Rd., East Farmingdale, N.Y. 11735 / Phone: (516) 293-3800

FORM 30 (2-1-84)

REGISTRY OF CONTRACTS AND RECORDS

TRACKING NO. 9400050258 63
PAGE 62 OF 69 593523

CUSTOMER: TENNESSEE VALLEY AUTHORITY

DATE: February 4, 1985

P.O. NO.: 84P72-342533

T.R. PROJECT: 84S-135-2

CERTIFICATE OF COMPLIANCE

TARGET ROCK CORPORATION hereby certifies that the below listed material furnished on this contract are in full compliance with all specification and contract requirements.

<u>ITEM</u>	<u>QTY.</u>	<u>DESCRIPTION</u>	<u>PART NUMBER</u>	<u>NSN</u>
✓ 2	2	Disc, Pilot	202918-1	
✓ 3	2	Rod, Disc	202819-1	
7	2	Rod	102670-17	
10	2	Core, Fixed	202551-2	
18 *	4	O-Ring	300-2034	
19 *	4	Gasket	200989-2	
20	2	Seat Insert	200783-1	

*ITEM 18 - CURE DATE: 2Q84
SHELF LIFE: 10 YEARS

*ITEM 19 - CURE DATE: 3Q84
SHELF LIFE: 10 YEARS

J. Schindler
J. Schindler
Manager, Spare Parts

PAGE 33 OF 187



Target Rock Corporation, 1966E Broadhollow Rd., P.O. Box V, Farmingdale, N.Y. 11735-0917

140

CERTIFICATE OF CONFORMANCE

CUSTOMER: Tennessee Valley Authority
FOR: Watts Bar Nuclear Plant
CUSTOMER P.O. #: P-87ZNR-467870 Release # 1038087
 Supplement 002
TRC PROJECT #: 94S-281

PRODUCT:	P.O. ITEM	P/N	QTY.	S/N
Pilot Disc	74	202918-1	1	42

We certify that the parts noted herein meet all the requirements of the Purchase Order, Drawing and Specifications. Further we certify that the detailed fabrication, inspection and test records quoted in the order and specifications are traceable and are on file.

TRC Quality Manual, Edition 5, Revision 9, Dated 9/30/94 is applicable.

We certify that the items meet the requirements applicable to the items as originally specified by TVA Contract No. 82K22-831934 (Model 82UU-001).

E. Champey 2/28/95
 for E. Champey Date
 Director, Quality Assurance

4
 9500054888
 PS 20F3

FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES
As Required by the Provisions of the ASME Code, Section III, Div. 1

Manufactured by Target Rock Corporation 1966 E. Broadhollow Rd E. Farmingdale, N.Y.
(Name and Address of N Certificate Holder)
Manufactured for Tennessee Valley Authority Chattanooga, Tennessee
(Name and Address of Purchaser or Owner)

1. Location of Installation Watts Bar Nuclear Plant, Units 1 & 2, Spring City, Tennessee
(Name and Address)

4. Pump or Valve Valve . Nominal Inlet Size 3 (inch) Outlet Size 3 (inch)

(a) Model No. or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Nat'l. Bd. No.	(g) Year Built
8200	1,2,3,4	---	8200-001	I	---	1983
(1)						
(2)						
(3)						
(4)						
(5)						
(6)						
(7)						
(8)						
(9)						
(10)						

W860724K0532 (2)

Contract No. 83-1934

R.D. or S.T. No. ---

Tag No. 83-2382

5. PRESSURIZED RELIEF POWER OPERATED RELIEF VALVE
(Brief description of service for which equipment was designed)

FILMED FROM BEST AVAILABLE COPY

Design Conditions 2485 psi 680 F or Valve Pressure Class --- (1)
(Pressure) (Temperature)
Cold Working Pressure 4100 psi at 100°F

8. Pressure Retaining Pieces

Mark No	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
(b) Forgings			
Body	ASME SA 182 SS 316L	Carmel	

CC&R
FEB 17 1983

INSPECTED
10 16 1983
WST
 NUCLEAR INSPECTOR
H. B. B.

(1) For manually operated valves only.
* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 3-1/2" x 11", (2) information in

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting			
(d) Other Parts			
Bonnet	ASME SA 479 SS 316	ARMCO	
Main Disc	ASME SA 479 SS 316	Ioslyn	
Indicator Tube	ASME SA 479 SS 316	Universal Cyclops	
Flange	ASME SA 182 SS 316	Carpenter	
Seat Insert	ASME SA 479 SS 316L	Ioslyn	

FILMED FROM BEST AVAILABLE COPY

3. Hydrostatic test 6150 psi Disk Differential test pressure 4510 psi

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. 1, Edition 1980 Addenda Winter 1980 Code Case No. _____ Date _____

Signed Target Rock Corporation by G. Abruzzo, Mgr. of Quality 2-4-83
(N Certificate Holder) to use the _____ symbol expires 12/9/83
(N) (Date)

Our ASME Certificate of Authorization No. 1947

CERTIFICATION OF DESIGN

Design information on file at Target Rock Corporation
 Stress analysis report (Class 1 only) on file at Target Rock Corporation

Design specifications certified by (1) Marvin V. Miller
 PE State TN Reg. No. 013995

Stress analysis certified by (1) Martin Goldstone
 PE State NY Reg. No. 31940

(1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of New York and employed by Commercial Union Insurance of Boston, Mass. have inspected the pump, or valve, described in this Data Report on 2/4 19 83, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 2/4 19 83 NEW YORK STATE COMMISSION NO. 2238

PAGE 3 OF 187

98002396000

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 10/19/98
Name
 400 W. Summit Hill Drive, Knoxville, TN
Address

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
 P. O. Box 2000, Spring City, TN, 37381
Address

3. Work Performed by MECH MAINT WAMP Type Code Symbol Stamp MMG 98-002396-000
Name Repair Organization P.O. No., Job No., etc.
PO BOX 2000 SPRING CITY TN 37381 Authorization No N/A
Address Expiration Date ✓

4. Identification of system REACTOR COOLANT SYSTEM 068

5. (a) Applicable Construction Code ASME SECTION 191 Edition SUMMER 1991 Addenda N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
CARTRIDGE SEAL	WASTINGHOUSE	2181 2183 CW 5/25/99	N/A	PN - 5057D2401	70	REPLACE	N

7. Description of Work REPLACE CARTRIDGE SEAL SERIAL NO. 2181, SEAL REMOVED
W.O. 96-018330-0077 W.O. 96-018330-001 TO BE INSTALLED IN 200#
 FROM REP #8 UNDER W.O. 96-018330-001

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 3500 psi Test Temp 250 °F 1-TR1-68-6

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 3 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

98002396000

FORM NIS-2 (Back)

9. Remarks

TRACKING NO. RR-02-30 MC-1-6/93

Applicable Manufacturer's Data Reports to be Attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp NONE

Certificate of Authorization No. NA

Signed D.H. Collins Mech Engr. Date 4/13 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I&I CO of Hartford CT. have inspected the components described in this Owner's Report during the period 10/20/98 to 4/15/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce M. Earned Commissions TN 2534 I N A
Inspector's Signature National Board, State, Province, and Endorsements

Date 4/15 19 99

98002396000

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
 As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 1/20/94
 Name
P.O. Box 2000 SPRING CITY, TN Address Sheet 1 of 1
2. Plant WATT BARR NUCLEAR PLANT Unit 1
 Name
P.O. Box 2000 SPRING CITY, TN Address
^{new} WORK PLAN K-203579A-3 *
 Repair Organization P.O. No., Job No., etc.
3. Work Performed by TVA Type Code Symbol Stamp N/A
 Name
P.O. Box 2000 SPRING CITY, TN Address Authorization No. N/A
 Expiration Date N/A
4. Identification of System REACTOR COOLANT SYSTEM (RCS)
5. (a) Applicable Construction Code ASME III 1971 Edition, Subsec. FC Addenda A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1970 USC
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Required, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Reactor Coolant Pump #1 Seal Housing	Westinghouse	2181	N/A	P/N 5055D24G01	1990	Replacement	No
Reactor Coolant Pump #2 Seal Housing	Westinghouse	2183	N/A	P/N 5055D24G01	1990	Replacement	No
Reactor Coolant Pump #3 Seal Housing	Westinghouse	2237	N/A	P/N 5055D24G01	1990	Replacement	No
Reactor Coolant Pump #4 Seal Housing	Westinghouse	2296	N/A	P/N 5055D24G01	1990	Replacement	No

7. Description of Work Installation of RCP cartridge seals; included new #2 seal housings.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

* This form will be added to WP-K-2035-3 after approval as a corrective action to NBP 930414. CW 1/27/94

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 3/8 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

WESTINGHOUSE ELECTRIC CORPORATION

98002396000

(E-EMO)
(N-NEED)

(P-PENSACOLA)
(T-TAMPA)

BUYER'S CUST. ORDER NO. 71052-54114-1	PROJECT P. O. N/A	PROJECT W.A.T.	WRK S. O. NO. 125	DATE 02/27/90
EQ. NO. CO-42067	DIV./PLANT S. O. NO. Q094	PARIBASEI NA	PARIPROJ NA	CHIBASEI NA
EQUIP. SPEC. NO. & REV. (BASE) NA	EQUIP. SPEC. NO. & REV. (PROJECT) NA	DRAWING NO. 114E921	REV. 11	QTY. ITEM 52
P. O. ITEM NUMBER NA	SPIN NUMBER RCPCPI	PART NAME Cartridge Seal Assembly	QTY. RELEASED 2	

See Attached PA 2217

The attributes listed below have been reviewed and approved by QC/QA as noted by an A in the status column. Non-applicable items are lined out. Records are available for review. Contingent items are identified by "C" in the status column and explained in the remarks section.

STATUS	STATUS	STATUS
<u>A</u> Material Certifications	<u>_____</u> Operating Electrical Test Records	<u>_____</u> SMC and other papers
<u>A</u> Heat Treat Records	<u>_____</u> Non-Operating Electrical Test Records	<u>_____</u> Sustaining Drawings
<u>_____</u> RT Film and Records	<u>A</u> Pressure Test Records	<u>_____</u> Technical drawings (except as noted)
<u>A</u> RT Records	<u>_____</u> Test Tightness Test Records	<u>A</u> Performance Test
<u>_____</u> IT Records	<u>A</u> Performance Test Records	<u>_____</u> Certification - Attached
<u>_____</u> JT Records	<u>A</u> Welding Personnel Qual. Cert.	<u>A</u> General Assembly Drawing -
<u>A</u> Visual Inspection Records	<u>A</u> NDE Personnel Qual. Cert.	<u>_____</u> Attached
<u>A</u> Dimensional Inspection	<u>_____</u> Painting	<u>_____</u>
<u>A</u> Cleanliness	<u>A</u> Packaging	<u>_____</u>

CUSTOMER QA DATA PACKAGE REQUIRED BY PURCHASE ORDER: YES NO DEVIATION NOTICE(S) NONE APPLICABLE (SHEETS LISTED BY QN NUMBER BELOW COPY ATTACHED TO SHIPPING PAPERS)

THE SUPPLIER CERTIFIES that for the equipment and material released, all contractual requirements have been met. Approved deviations, if any, are listed above.

SUPPLIER	P. O. NUMBER
NA	NA
SUPPLIER SIGNATURE	DATE
NA	NA

Equipment shown hereon is released by Quality Assurance. Shipment may be made subject to authorization by Purchasing. The equipment supplier has certified that the equipment above meets all requirements of the purchase order drawings and specifications. Westinghouse has reviewed evidence supporting this release and except as specified above has detected no deviations from such requirements. This release does not waive any rights Westinghouse may have under the purchase order including Westinghouse's right to reject the equipment upon discovery of any such deviations after arrival at destination.

[Signature]
Westinghouse Quality Assurance Representative

WESTINGHOUSE
CHESWICK, PA 15024

SHIP ORDER Q094	THIS SHIPMENT 1	DATE 2/23/90	UR E 945-C
GENERAL ORDER NO. C042067	TOTAL ON ORDER 107	DOMESTIC X	EXPORT
PURCHASE ORDER NO. 71C62-54114-1	TOTAL DEL'D TO DATE 104	CLAIMABLE NO	PLANNER J. Clark 2-23-90
SPIN NUMBER RCPCPI	PARTIAL X	FINAL	NUMBER OF CONTAINERS 8
CUSTOMER WITNESS REQ Yes			PACKER J. Holmquist 2-2
			PACKING INSPECTOR L. Maynard 2-24
			QA RECORDS J. M. Downing 2-24

QTY	CUSTOMER ID	PACKAGING	PARTS AND PKG INSPECTOR
1		0623	
<p>Assembly dvg. 114E921 G03, which consists of the following Seals and Ho. 2 Hous</p>			
		039	
		039	
		039	
		039	
		039	

ix - 276
Page

98002396000

Uo. 676681

98002396000

FORM NPV-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES

As Required by the Provisions of the ASME Code Rules

1. Manufactured by Westinghouse Electro-Mechanical Division
Cheswick Avenue, Cheswick, PA 15024 Order No. U-363
(Name & Address of Manufacturer)
2. Manufactured for Westinghouse--PWRSD
Monroeville, PA 15230 Order No. 546-NRC-151792-BN
(Name and Address)
3. Owner Tennessee Valley Authority W 860724K0959 7
4. Location of Plant Spring City, Tennessee
5. Pump or Valve Identification S/N 4-114E921-G01

Provide Reactor Coolant Flow in Westinghouse Pressurized Water Reactor
(Brief description of service for which equipment was designed)

(a) Drawing No. 114E921 Prepared by Westinghouse Electric Corporation

(b) National Board No. N/A

(c) Design Conditions 2500 psi 650 °F
(Pressure) (Temperature)

The material, design, construction, and workmanship complies with ASME Code Section III, Class 1

Edition 1971, Addenda Date Summer 1972, Case No. N/A
See Attachments 1 through 4 for Items (a) through (d) below

Mark No	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
(b) Forgings			

Contract No. 54117-1 WVJ # 114
CPIN #
R.D. or S.T. No. RC000A 125
209 No. 76-8974

*Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2" x 11", (2) information in items 1, 2, 3c and 5b on this data report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

FILMED FROM BEST AVAILABLE COPY


Mark No.	Material Spec. No.	Manufacturer	Remarks
Bolting			
(d) Other Parts			

8. Hydrostatic test 3750 psi. (Pump Code Parts) Contract No. 54114-1 Unit #1

CERTIFICATION OF DESIGN

Design information on file at Westinghouse Electro-Mechanical Division
 Stress analysis report on file at Westinghouse Electro-Mechanical Division
 Design specifications certified by Robert L. Sylvester (1) Prof. Eng. State PA Reg. No. 15441-E
 Stress analysis report certified by Dr. O. Hagen (1) Prof. Eng. State PA Reg. No. 09091-E
 Signature not required. List name only.

We certify that the statements made in this report are correct.
 Date October 13 19 81 Signed Westinghouse Electro-Mechanical Division
 (Manufacturer)

R.D. or S.T. No. RCEPC
 209 No 76-6174 50"125


Certificate of Authorization No. N-1385 expires May 14, 1982

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Province of PENNSYLVANIA and employed by LUMBERMEN'S MUTUAL CASUALTY CO. of LONG GROVE, ILLINOIS have inspected the equipment described in this Data Report on DEC. 4 19 74, and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Code, Section III.
 By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

CR Miller COMMISSIONS PA 1784
 (INSPECTOR) (NATIONAL BOARD, STATE, PROVINCE AND NO.)

Date OCT. 13 1981
 WITNESSED COMPLETED PUMP ASSEMBLY HYDROSTATIC TEST: 3136 psi, for 10 minutes.

Westinghouse Representative Charles J. Bice Date 10-24-81

EM Mylan 10-24-81 Commissions NB 5608 TX 692
 (Inspector) (Date) (National Board, State, Province and No.)

- QUALITY RELEASE
WESTINGHOUSE ELECTRIC CORPORATION

98002396000
OR E 15457 REV 1

(E-EMD) (P-PENSACOLA)
(N-NEED) (T-TAMPA)

J. Casella

BASE P. O.	PROJECT P. NO.	PROJECT	WFO S. O. NO.	DATE
N/A	15197	W A T	125	1013811
SERIAL ORDER NO.	DIV./PLANT S.O. NO.	PARTIMATE	PARTPROJ	CHIBASEI
0-62003-ARSAR1	U-363	N/A	N/A	N/A
IP. SPEC. NO. & REV.	EQUIP. SPEC. NO. & REV. (PROJECT)	DRAWING NO.	REV.	GROUP/TITLE
677188 Rev. 1	678874 Rev. 4 with Interim Revisions 1-5	114E921	8	601
TYPE NUMBER	SPIN NUMBER	PART NAME	QTY. BY TAGS	
N/A	NAT-RCPCI-04	Reactor Coolant Pump Internals	1	
DIAL OR IDENTIFICATION NUMBERS				
/N 4-114E921-601				

The attributes listed below have been reviewed and approved by QC/OA as noted by an A in the status column. Non-applicable items are lined out. Records are available for review. Contingent items are identified by "C" on the status column and explained in the remarks section.

STATUS	STATUS	STATUS
<u>A</u> Material Certifications	Operating Condition Test Records	<u>A</u> ASME Data Report Form(s) NPV-1 (attached)
<u>A</u> Heat Treat Records	Non-Operating Condition Test Records	<u>A</u> Certified Stress Report
<u>A</u> RT Film and Records	<u>A</u> Pressure Test Records	<u>A</u> Special Handling, Storage & Install. Instruct.
<u>A</u> PT Records	Joint Tightness Test Records	
<u>A</u> UT Records	<u>A</u> Performance Test Records	
<u>A</u> Visual Inspection Records	<u>A</u> Welding Personnel Qual. Cert.	
<u>A</u> Dimensional Inspection	<u>A</u> NDE Personnel Qual. Cert.	
<u>A</u> Cleanliness	<u>A</u> Packaging	

CUSTOMER QA DATA PACKAGE PROVIDED BY PURCHASE ORDER YES NO (SEE IDENTIFICATION NOTICE) NONE APPLICABLE (ONLY LISTED BY QM NUMBER BELOW (COPY ATTACHED TO SHIPPING PAPERS))

This quality release revision is issued to communicate that all contingencies listed on the original quality release have been cleared and authorize application of the "N" symbol stamp to the pump assembly nameplate after completion of site system cold hydro.

FILMED FROM BEST AVAILABLE COPY

THE SUPPLIER CERTIFIES that for the equipment and material ordered, all contractual requirements have been met. Approved conditions, if any, are listed above.

SUPPLIER	P.O. NUMBER
N/A	N/A
SUPPLIER SIGNATURE	DATE
N/A	N/A

Equipment shown hereon is released by (a) Quality Assurance. Shipment may be made subject to authorization by (b) Purchasing. The equipment supplier has certified that the equipment above meets all requirements of the purchase order drawings and specifications. Westinghouse has reviewed evidence supporting this release and except as specified has detected no deviations from such requirements. This release does not waive any rights Westinghouse may have under the purchase order including Westinghouse's right to reject the equipment upon the receipt of any such evidence after arrival of destination.

J. Casella
Westinghouse Quality Assurance Representative

DATE

Designed by Westinghouse Electro-Mechanical Division
Cheswick Avenue, Cheswick, Pa. 15024

Order No. U-363

Manufactured for Westinghouse--PWRSD
Monroeville, PA

Order No. 546-NRC-151972-8N

Drawing Number 114E921

Serial Number 4-114E921G01

National Board Number N/A

Component	Part Number	Material Spec. No.	Manufacturer	Serial Number(s)
1A Main Flange	929C854G 01	SA-351 Gr CFB	Esco Corp.	<u>995</u>
1B Thermowell	1306C07G 01	SA-479 Type 304 5 SA-213 Grade TP304	Ionics	<u>1588</u>
2 Main Flange Bolts (24)	913C495G01	SA-540 Grade B24	J. Dyson	<u>9077 9074 9004</u> <u>9079 9078 8387</u> <u>8391 8920 9073</u> <u>9042 8922 8928</u> <u>8926 8929 9045</u> <u>9043 8386 9044</u> <u>9041 9046 9075</u> <u>9040 9076 9072</u>
3 Lower Seal Housing Bolts (12)	4129A37H16	SA-193 Grade B7	Radform Tool	<u>2439 2440 2444</u> <u>2452 2456 2464</u> <u>2493 2495 2497</u> <u>2499 2500 2510</u>
4 Upper Seal Housing Bolts (12)	4129A36H10	SA-193 Grade B7	Safety Socket	<u>2085 2235 2621</u> <u>2098 2236 2623</u> <u>2106 2252 2659</u> <u>2233 2589 2698</u>

FILMED FROM BEST AVAILABLE COPY

Westinghouse Electro-Mechanical Division
 Manufactured by Cheswick Avenue, Cheswick, Pa. 15024

Order No. U-363

Westinghouse--PWRSD

Manufactured for Monroeville, PA

Order No. 546-NRC-151972-8N

Drawing Number 114E921

Serial Number 4-114E921G01

National Board Number N/A

Component	Part Number	Material Spec. No.	Manufacturer	Serial Number(s)
S Thermal Barrier	510F365G01	Not Applicable		
5A Flange	510F364G01	SA-182 Grade P 304	Standard Steel	917
5B Water Connection	925B950G02	Not Applicable		
5B.1 Flange	955B758H05	SA-182 Grade 316	Western Forge	2686 2661 267
5B.2 Pipe	925B950H05	SA-312 Grade Tp 305	Babcock & Wilcox	2869 2867 286
5C Pressure Tap	925B949G	Not Applicable		
5C.1 Flange	955B798H	SA-182 Grade 316		N/A
5C.2 Pipe	925B949H	SA-312 Grade Tp 304		N/A
5C.3 Reducer	955B799H	SA-182 Grade 316		N/A

FILMED FROM BEST AVAILABLE COPY

98002396000

ATTACHMENT TO FORM NPV-1

Manufactured by Westinghouse Electro-Mechanical Division
Cheswick Avenue, Cheswick, Pa. 15024

Order No. U-363

Manufactured for Westinghouse--PWRSD
Monroeville, PA

Order No. 546-NRC-151972-8N

Drawing Number 114E921

Serial Number 4-114E921G01

National Board Number N/A

Component	Part Number	Material Spec. No.	Manufacturer	Serial Number(s)
6 Lower Seal Housing (Spool)	933D313 H03	SA-182 F304	Standard Steel	952
6A Thermowell	955B797H 02	SA-479 Type 304	Simonds Steel	1580
6B No. 1 Leak Off Connection	913C741G 02	Not Applicable		
● Flange	955B758H 02	SA-182 Grade 316	Western Forge	2658
6B.2 Pipe	913C741H 05	SA-312 Grade Tp 304		2891
6C Lift Off Connection	913C533G 02	Not Applicable		
6C.1 Flange	955B756H 02	SA-182 Grade 316	Western Forge	2528
6C.2 Pipe	913C533H 05	SA-312 Grade Tp 304	Allegheny Ludlum	2896
7 Upper Seal Housing (Spool)	933D309 H04	SA-182 F304	Standard Steel	871
7A No. 2 Leak Off Connection	929C852G 04	Not Applicable		
7A.1 Flange	955B798H 02	SA-182 Grade 316	Western Forge	2756
● Pipe	929C852H 07	SA-312 Grade Tp 304	U.S. Steel	2900

FILMED FROM BEST AVAILABLE COPY

PAGE 47 OF 187

98002396000

ATTACHMENT TO FORM NPV-1

Manufactured by Westinghouse Electro-Mechanical Division
Cheswick Avenue, Cheswick, PA 15024 Shop Order U-363

Manufactured for Westinghouse--PWRSD
Monroeville, PA Purchase Order 546-NRC-151972-8N

Drawing Number 114E921

National Board No. N/A

Serial No. 4-114E921G01

The following Reactor Coolant Pump Casing is covered by its own Manufacturers' Data Report (N-2 Form).

<u>Serial Number</u>	<u>Part Number</u>	<u>Manufacturer</u>
927	114E968H01	Esco Corp.

FILMED FROM BEST AVAILABLE COPY

PAGE 4 OF 107

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
 As Required by the Provisions of the ASME Code Section XI

Owner TENNESSEE VALLEY AUTHORITY Date 10/07/98
400 W. Summit Hill Drive, Knoxville, TN Sheet of
Name
 Address
 2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
P. O. Box 2000, Spring City, TN, 37381 MMG 98-008211-004
Address
 3. Work Performed by WATTS BAR NUCLEAR PLANT Repair Organization P. O. No., Job No., etc.
Name Type Code Symbol Stamp N/A
P. O. BOX 2000, SPRING CITY, TN 37381 Authorization No N/A
Address Expiration Date N/A

4. Identification of system 062, CHEMICAL VOLUME CONTROL

5. (a) Applicable Construction Code ASME SEC. III 19 71 Edition, S72 Addenda, NONE Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1-RFV-062-0649-S	CROSBY VALVE	N56900-00-0019	180	NONE	75	REPLACEMENT	YES
1-RFV-062-0649-S	CROSBY VALVE	N56900-00-0005	180	NONE	75	REPLACED	YES

7. Description of Work REMOVE/REPLACE SAFETY RELIEF VALVE.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure X*
 Other Pressure 200 psi Test Temp 225 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

Remarks

Applicable Manufacturer's Data Reports to be Attached

TRACKING # RR-02-31 ²⁰⁰ 10/16/91

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp NONE.

Certificate of Authorization No. NONE.

Signed [Signature] Date 10-20 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSEITIG of Hartford, CT have inspected the components described in this Owner's Report during the period 10-20-99 to 4-7-99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions TN 2533
Inspector's Signature National Board, State, Province, and Endorsements

Date 47 19 99

CROSBY

CROSBY VALVE & GAGE COMPANY

WRENTHAM, MASS

\$10.220

G.C. 44B

FORM NV-1 FOR SAFETY AND SAFETY RELIEF VALVES
As required by the Provisions of the ASME Code Rules

DATA REPORT
Safety and Safety Relief Valves

NB-180

1. Manufactured By Crosby Valve & Gage Company, 41 Kendrick Street, Wrentham, Ma. 02093
Name and Address

Model No. JB-25-JD-86 Order No. 7-10360 Contract Date 3-30-73

2. Manufactured For Energy Systems, Pittsburgh, Pa. 15210
Name and Address

3. Owner Tennessee Valley Authority, Hart Bar Nuclear Power Station Unit #2
Name and Address

4. Location of Plant Near Spring City, Tennessee 37381

5. Valve Identification BV-2-2123-88T Serial No. N56300-00-0019 ASME No. 2SCA 56950 Rev. 3

Type Relief
Safety Safety Relief Pilot Proof Actuated
Outlet Size 1 Inch Pipe Size 1 Inch Inlet 2 Outlet 3 Inch
Rated Temperature 150°

6. Set Pressure (PSIG) 150

Stamped Capacity 190 GPM Water 10 % Overpressure Blowdown 10% of S.P.

Hydrostatic Test (PSIG) Inlet 425 Outlet 425

7. The material, design, construction and workmanship comply with ASME Code Section III

Class 2 Edition 1971 Addenda Date Summer 1972

Pressure Containing or Pressure Retaining Components

FILMED FROM BEST AVAILABLE COPY

	Serial No Identification	Material Specification including Type or Grade
a. Castings		ASTM-A351-72 Gr. CF8M
Body	<u>N90135-33-0002</u>	ASTM-A216-70 Gr. WCB
Bonnet	<u>N90449-31-0005</u>	ASTM-A216 Gr. WCB
b. Bar Stock and Forgings		
Support Rods		
Nozzle	<u>N90137-42-0037</u>	ASME-SA479 Type 316
Disc Insert	<u>N90449-32-0045</u>	ASTM-A-79-71 Type 316
Spring Washers Top	<u>N88635-39-0097</u>	ASME-SA479 Type 316
Spring Washers Bot Com	<u>N88635-39-0097</u>	ASTM-A193-70 Gr. B8
Adjusting Bolt	<u>N88669-39-0124</u>	ASTM-A193 Gr. B8
Spradle		ASTM-A193-70 Gr. B8
		ASME-SA193 Gr. B8

HARD COPY RETAINED

SO 220
REG. NO. 54114-1
ITEM NO. 5A
209 NO. 76-5213 A

DATE
11-12-73

W8608110082 (2)

S.O. 220

5

	Serial Number Identification	Material Specification Including Type or Grade
c. Springs	<u>XX-1235-0122</u>	<u>ASTM-A177 Type 316</u>
d. Bolting		
e. Other Parts such as Pilot Components		
Bonnet Stud	<u>89122</u>	<u>ASTM-A453-70 Gr. 90 ASME-SA193 Gr. 90</u>
Bonnet Stud Nut	<u>89122</u>	<u>ASTM-A193-70 Gr. 90 ASME-SA193 Gr. 90</u>

We certify that the statements made in this report are correct.
 Date 9-23-75 Signed Cresby Valve & Pipe Co. by [Signature]
 Manufacturer GA Manager

Certificate of Authorization No. 376 expires October 15, 1977

HARD COPY RETAINED

FILMED FROM BEST AVAILABLE COPY

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid Commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Florida, and employed by Factory [Name], have inspected the equipment described in this Report and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Sections of ASME Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty expressed or implied, concerning the equipment described in this Data Report. Further, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of time and profits caused or connected with this inspection.

Date 9/23/75 Inspected by [Signature] Inspector No. 487325

REG. NO. 541171
 ITEM NO. 5A
 209 NO. 75-2312A

*Arkwright-Boston Manufacturers Mutual Insurance Company - Boiler & Machinery Division.

glw
 9-23-75
 DATE
 INITIALS

WO # 98-008416-001 *AW* 3/8/99

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 10/07/98
Name
 400 W. Summit Hill Drive, Knoxville, TN
Address
 Sheet _____ of _____

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
 P. O. Box 2000, Spring City, TN, 37381
Address
 MMG 98-008211-008
Repair Organization P.O. No., Job No., etc.

3. Work Performed by WATTS BAR NUCLEAR PLANT Type Code Symbol Stamp N/A
Name
 P.O. BOX 2000, SPRING CITY, TN 37381
Address
 Authorization No N/A
 Expiration Date N/A

4. Identification of system 068, REACTOR COOLANT

5. (a) Applicable Construction Code ASME SEC. III 19 71 Edition, W'72 Addenda, NONE. Code Case _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)	
1-RFV-068-0563	CROSBY VALVE	<i>N56964-10-0033</i>	<i>906</i>	<i>N/A</i>	<i>1983</i>	REPLACE <i>MENT</i>	YES	
1-RFV-068-0564	CROSBY VALVE	<i>N56964-10-0029</i>	<i>905</i>		<i>1983</i>	REPLACE <i>MENT</i>	YES	
1-RFV-068-0565	CROSBY VALVE	<i>N56964-10-0034</i>	<i>907</i>		<i>1983</i>	REPLACE <i>MENT</i>	YES	
1-RFV-068-0564	CROSBY VALVE	<i>N56964-10-0029</i>	<i>N/A</i>		<i>1 STUD BOLT *</i>	<i>N/A</i>	REPLACE <i>MENT</i>	YES
1-RFV-068-0565	CROSBY VALVE	<i>N56964-10-0029</i> <i>AC 070-59</i>	<i>N/A</i>		<i>2 STUD BOLTS *</i>	<i>N/A</i>	REPLACE <i>MENT</i>	YES
* STUDS REMOVED FROM SN: <i>N56964-10-0096</i>								

DHC
4/5/99

7. Description of Work REMOVE/REPLACE PRZ. SAFETY RELIEF VALVES AND STUDS IN TWO RFV'S..

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure X*
 Other Pressure 2235 psi Test Temp 650 °F
 * TO BE PERFORMED BY 1-TRI-68-6.

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 10/07/98
Name
400 W. Summit Hill Drive, Knoxville, TN Sheet _____ of _____
Address

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
P. O. Box 2000, Spring City, TN, 37381 MMG 98-008211-008
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by WATTS BAR NUCLEAR PLANT Type Code Symbol Stamp N/A
Name
P.O. BOX 2000, SPRING CITY, TN 37381 Authorization No N/A
Address Expiration Date N/A

4. Identification of system 068, REACTOR COOLANT

5. (a) Applicable Construction Code ASME SEC. III 19 71 Edition, W'72 Addenda, N/A Code Case _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1-RFV-068-0563	CROSBY VALVE	<i>N56964-10-0095</i>		<i>NA</i>		REPLACED	YES
1-RFV-068-0564	CROSBY VALVE	<i>N56964-10-0097</i>			REPLACED	YES	
1-RFV-068-0565	CROSBY VALVE	<i>N56964-10-0096</i>			REPLACED	YES	

7. Description of Work REMOVED

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure ISLT *NA*
 Other Pressure _____ psi Test Temp _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks

Applicable Manufacturer's Data Reports to be Attached

TRACKING # RR-02-33 *LR 10/10/98*

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the repair or replacement rules of the ASME Code, Section XI.

Type Code Symbol Stamp NONE.

Certificate of Authorization No. NONE.

Signed *D.F. Willis* MAMT. SPEC. Date 4/4 19 98
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSRI & I Co. of Hartford, CT have inspected the components described in this Owner's Report during the period 10-20-98 to 4-6-99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions TN 2533
 Inspector's Signature National Board, State, Province, and Endorsements

Date 4-6 19 99

CROSBY

CROSBY VALVE & GAGE COMPANY WRENTHAM, MASS

FORM NV-1 FOR SAFETY AND SAFETY RELIEF VALVES
As required by the Provisions of the ASME Code Rules

C.C.-44C-1

DATA REPORT Safety and Safety Relief Valves

1. Manufactured By Crosby Valve & Gage Co., 43 Kendrick St., Wrentham, MA 02093
Name and Address

Model No. HB-86-8P Order No. N303153B Contract Date 1/26/83 National Board No. 907
Westinghouse Electric Corp., Nuclear Energy Systems,

2. Manufactured For P.O. Box 3700, Pittsburgh, PA 15230 Order No. 546-CCX-178353-BN.
Name and Address C/N #010

3. Owner Tennessee Valley Authority, Watts Bar Nuclear Power Station
Name and Address

4. Location of Plant Site: City, TN 37381

W860811K0101 (2)

5. Valve Identification 6RV38MSC Serial No. N56964-06-0034 Drawing No. DS-C-56964-6 Rev. E

Type Safety Orifice Size 2.154 Pipe Size -- Inlet 6 Outlet 6
Safety Safety Relief Pilot Power Actuated Inch Inch Inch Inch

6. Set Pressure (PSIG) 2485 Rated Temperature 650 F

Stamped Capacity 420,006 lbs/hr % Overpressure 5% Blowdown (PSIG) 125

Hydraulic Test (PSIG) Inlet 4575 Complete Valve --

7. The material, design, construction and workmanship comply with ASME Code, Section III.

Class 1 Edition 1971, Addenda Date Winter 1972, Case No. --

Pressure Containing or Pressure Retaining Components

FILMED FROM BEST
AVAILABLE COPY

Part	Serial No. Identification	Material Specification Including Type or Grade
Bar Stock & Forgings		
Body	<u>N90490-33-0053</u>	<u>ASME SA182 Gr. F316</u>
Bonnet	<u>N90353-36-0054</u>	<u>ASME SA105 Gr. II</u>
Body & Bonnet Forgings		
Support Rods		
Nozzle	<u>N94209-31-0003</u>	<u>ASME SA182 Gr. F316</u>
Disc Holder K57220-32-0046	<u>N90553-32-0045</u> <u>N90350-34-0145</u>	<u>ASTM A637 Gr. 718</u>
Spring Washers K56380-37-0081	<u>N90350-34-0148</u>	<u>ASME SA105 Gr. II</u>
Adjusting Bolt	<u>N90351-38-0085</u>	<u>ASME SA193 Gr. B6</u>
Spindle Point K56381-34-0022	<u>N90354-34-0022</u>	<u>ASME SA193 Gr. B6</u>
Spindle Ball	<u>N90355-0022</u>	<u>ASTM A276 Type 440C</u>
Disc Insert	<u>N94210-33-0013</u>	<u>ASME SA637 Gr. 718</u>

Tract No. 54114-1
or S.T. No. WBT-ASBALS
209 No. 83-3915

	Serial No. or Identification	Material Specification Including Type or Grade	
c. Spring	K56380-37-0081	NX2761-0068	ASTM A264 Gr. 51B60H
d. Bolting			
e. Other Parts such as Pilot Components			
Bonnet Stud	100987	ASME SA453 Gr. 660	
Bonnet Nuc	89997	ASME SA193 Gr. B6	
Inlet Stud	N90488	ASME SA453 Gr. 660	
Inlet Nuc	N90489	ASME SA193 Gr. B6	

We certify that the statements made in this report are correct.

Date 5/11/83 Signed Crosby Valve & Gage Co. By [Signature]
 Manufacturer

Certificate of Authorization No. 1873 expires September 30, 1983

FILMED FROM BEST AVAILABLE COPY

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Mass. and employed by Arkwright-Boston Manufacturers Mutual Insurance Company have inspected the equipment described in this Data Report on 5-9-1983 and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 05-11-83 Factory Mutual System
[Signature] (Inspector) Commissions NB 7883 MA 1274
 National Board, State, Province and No.)

REPAIR AND REPLACEMENT
TO NUCLEAR COMPONENTS AND SYSTEMS IN NUCLEAR POWER PLANTS

1. Work performed by Crosby Valve & Gage Company 43 Kendrick St. Wrentham, MA 02093
(Name and Address)
(Repair organization's P.O. No., Job No., etc.) NV4000329

2. Owner TENNESSEE VALLEY AUTHORITY KNOXVILLE, TN
(Name and Address)

3. Name and Identification of Nuclear Power Plant WATTS BAR NUCLEAR PLANT

4. Address of Nuclear Power Plant SPRING CITY, TN 37381

5. a. Identifying Nos. N56964-10-0034 907 --- --- 1983 6
(Mfr's Serial No.) (Nat'l Bd. No.) (Jurisdiction No.) (Other) (Year Built)
b. Identification of component repaired or replacement component SAFETY VALVE
c. Name of Manufacturer CROSBY VALVE & GAGE COMPANY

6. Tests conducted: Hydrostatic Pneumatic Design Pressure Pressure 4575.0 psi
Identification of System ---

8. Applicable Section(s) III of ASME Code, 19 71 Edition
Addenda W72 Code Case ---

9. Description of work VALVE MODIFICATION
(Use of additional sheet(s) or sketch(es) is acceptable if correctly identified)

10. Remarks: VALVE SERIAL NUMBER N56964-06-0034 WAS MODIFIED TO
VALVE SERIAL NUMBER N56964-10-0034. NOZZLE N94209 WAS
REPLACED TO N96523-33-0006. BELLOWS ASSEMBLY K57220 WAS MODIFIED TO
K83206-32-0006. DISC INSERT N94210 WAS REPLACED WITH
N96522-32-0013. THE INLET STUDS WERE REPLACED WITH
TRACE#YB2 QTY 6. THE INLET NUTS WERE REPLACED WITH
TRACE #OFG QTY 12. THE VALVE WAS TESTED FOR SET PRESSURE
AND SEAT LEAKAGE IN ACCORDANCE WITH TEST PROCEDURE T-16690

4574
3012

WBN-TVA-295-0474
PAGE 38 OF 56

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and all design, material, and workmanship on this
MOD conforms to the applicable section of the ASME Code.
(repair/replacement)

Signed Lawrence J. Pini QA Eng. Manager 23 Jan 1995
(Authorized Rep. of Repair Organization) (Title) (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Massachusetts and employed by Factory Mutual of Norwood, Massachusetts have inspected the repair or replacement described in this report on January 23, 1995 and state that to the best of my knowledge and belief, this repair or replacement has been made or constructed in accordance with the applicable section of the ASME Code.

By signing this certificate, neither the Inspector nor his employer makes any warrant, expressed or implied, concerning the repair or replacement described in this report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 1-23, 1995.

Factory Mutual Systems

Signed [Signature]
(Inspector)

Commissions NG10289 N MA-1417
(Nat'l. Bd., State, Prov. and No.)

FACTORY ORDER NUMBER: NV4000329
CUSTOMER ORDER NUMBER: 94N3F-101699-001
VALVE SERIAL NUMBER: N56964-10-0034
VALVE TAG NUMBER: N/A

REPAIR CERTIFICATION
REPORT

Description of Repair:

VALVE SERIAL NUMBER N56964-06-0034 WAS MODIFIED TO VALVE SERIAL NUMBER N56964-10-0034. NOZZLE N94209 WAS REPLACED WITH N96523-33-0006 (CMTR, LP, UT AND WT REPORT ATTACHED). BELLOWS ASSEMBLY K57220 WAS MODIFIED TO K83206-32-0006. DISC INSERT N94210 WAS REPLACED WITH N96522-32-0013 (CMTR, LP, UT AND WT REPORTS ATTACHED).THE INLET STUDS WERE REPLACED WITH TRACE#YB2 QTY 6 (CMTR,LP ATTACHED).THE INLET NUTS WERE REPLACED WITH TRACE#OFG QTY 12 (CMTR,MAG ATTACHED).THE VALVE WAS REASSEMBLED,HYDROSTATICALLY, SET PRESSURE AND SEAT LEAK TESTED IN ACCORDANCE WITH T-16690 (REPORT ATTACHED). VALVE WAS INSPECTED TO DS-C-56964-10 AND PACKAGED IN ACCORDANCE WITH P-1769. VALVE IS IN ACCORDANCE WITH SPEC.G-678838 REV.0 .

WBN-TVA-795-0474
PAGE 40 OF 56

Deborah Allsbrook
QUALITY ASSURANCE.

23 JANUARY 1995
DATE



CROSBY VALVE & GAGE COMPANY
WRENTHAM, MASS

FORM NV-1 FOR SAFETY AND SAFETY RELIEF VALVES
As required by the Provisions of the ASME Code Rules

QC-44C-1

DATA REPORT
Safety and Safety Relief Valves

W860811K0099

(2)

1. Manufactured By Crosby Valve & Gage Co., 43 Kendrick St., Wrentham, MA 02093
Name and Address

Model No. H3-86-BP Order No. N303153B Contract Date 1/26/83 National Board No. 906
Westinghouse Electric Corp., Nuclear Energy Systems,

2. Manufactured For P.O. Box 3700, Pittsburgh, PA 15230 Order No. 545-CCK-178353-BN,
Name and Address C/N #010

3. Owner Tennessee Valley Authority, Watts Bar Nuclear Power Station
Name and Address

4. Location of Plant Spring City, TN 37381

5. Valve Identification 6RVG8MSC Serial No. N56964-03-0033 Drawing No. DS-C-56964-6 Rev. E
Type Safety Orifice Size 2.154 Pipe Size --- Inlet 6 Outlet 6
Safety Safety Relief Pilot Power Actuated In. In. In. In.

6. Set Pressure (PSIG) 2485 Rated Temperature 650 F

Stamped Capacity 420,006 lbm/hr 3 % Overpressure 5% Blowdown (PSIG) 125

Hydrostatic Test (PSIG) Inlet 4575 Complete Valve ---

7. The material, design, construction and workmanship comply with ASME Code, Section III.
Class 1 Edition 1971, Addenda Date Winter 1972, Case No. ---

Pressure Containing or Pressure Retaining Components

FILMED FROM BEST AVAILABLE COPY

Bar Stock & Forgings	Serial No. Identification	Material Specification including Type or Grade
Body	<u>N90490-33-0047</u>	<u>ASME SA182 Gr. F316</u>
Bonnet	<u>N90353-36-0059</u>	<u>ASME SA105 Gr. II</u>
Disc Holder		
Support Rods		
Nozzle	<u>N94209-31-0001</u>	<u>ASME SA182 Gr. F316</u>
Disc Holder	<u>K57220-32-0047</u> <u>N90553-32-0038</u>	<u>ASTM A637 Gr. 718</u>
Spring Washers	<u>K56380-37-0065</u> <u>N90350-34-0121</u> <u>N90350-34-0137</u>	<u>ASME SA105 Gr. II</u>
Adjusting Bolt	<u>N90351-39-0091</u>	<u>ASME SA193 Gr. B6</u>
Spindle Point	<u>K56381-39-0089</u> <u>N90354-42-0106</u>	<u>ASME SA193 Gr. B6</u>
Spindle Ball	<u>N90355-0089</u>	<u>ASTM A276 Type 440C</u>
Disc Insert	<u>N94210-33-0012</u>	<u>ASME SA637 Gr. 718</u>

CO. T. No. 4167-ASBNS
209 No. 83-3915

	Serial No. or Identification	Material Specification Including Type or Grade
c. Spring	K56380-37-0065	NX2761-0073
d. Bolting		ASTM A304 Gr. 51360H
e. Other Parts such as Pilot Components		
Bonnet Stud	100987	ASME SA453 Gr. 660
Bonnet Nut	89997	ASME SA193 Gr. 36
Inlet Stud	N90488	ASME SA453 Gr. 660
Inlet Nut	N90489	ASME SA193 Gr. 36

We certify that the statements made in this report are correct.

Date 5/11/83 Signed Crosby Valve & Gage Co. By [Signature]
 Manufacturer

Certificate of Authorization No. 1878 expires September 30, 1983

FILMED FROM BEST AVAILABLE COPY

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Mass. and employed by Arkwright-Boston Manufacturers Mutual Insurance Company have inspected the equipment described in this Data Report on 5-9-1983 and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 05-11-1983 [Signature] Factory Mutual System
 (Inspector) Commissions NB # 7883 ; MA 1274
 National Board, State, Province and No.)

CROSBY

CROSBY VALVE & GAGE COMPANY
WRENTHAM, MA

Q.C.-292, REV.A
SHEET 1 OF 2

REPAIR AND REPLACEMENT
TO NUCLEAR COMPONENTS AND SYSTEMS IN NUCLEAR POWER PLANTS

1. Work performed by Crosby Valve & Gage Company 43 Kendrick St. Wrentham, MA 02093
(Name and Address)
(Repair organization's P.O. No., Job No., etc.) NV4000329

2. Owner TENNESSEE VALLEY AUTHORITY KNOXVILLE, TN
(Name and Address)

3. Name and Identification of Nuclear Power Plant WATTS BAR NUCLEAR PLANT

4. Address of Nuclear Power Plant SPRING CITY, TN 37381

5. a. Identifying Nos. N56964-10-0033 906 -- -- -- 1983
(Mfr's Serial No.) (Nat'l Bd. No.) (Jurisdiction No.) (Other) (Year Built)
b. Identification of component repaired or replacement component SAFETY VALVE
c. Name of Manufacturer CROSBY VALVE & GAGE COMPANY

Tests conducted: Hydrostatic () Pneumatic () Design Pressure () Pressure 4575.0 psi

7. Identification of System --

8. Applicable Section(s) III of ASME Code, 19 71 Edition
W72 Addenda W72 Code Case --

9. Description of work VALVE MODIFICATION
(Use of additional sheet(s) or sketch(es) is acceptable if correctly identified)

10. Remarks: VALVE SERIAL NUMBER N56964-06-0033 WAS MODIFIED TO
VALVE SERIAL NUMBER N56964-10-0033. NOZZLE N94209 WAS
REPLACED TO N96523-33-0005. BELLOWS ASSEMBLY K57220 WAS MODIFIED TO
K83206-32-0005. DISC INSERT N94210 WAS REPLACED WITH
N96522-32-0011. THE INLET NUTS WERE REPLACED WITH
TRACE# OFG QTY 12. THE VALVE WAS TESTED FOR SET PRESSURE
AND SEAT LEAKAGE IN ACCORDANCE WITH TEST PROCEDURE T-16690.

WBN-TVA-R95-0474
PAGE 31 OF 56

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and all design, material, and workmanship on this MOD _____ conforms to the applicable section of the ASME Code.
(repair/replacement)

Signed Louise A. Linn O.A. Eng. Manager 23 Jan, 1995
(Authorized Rep. of Repair Organization) (Title) (Date)

WBN 17A 295-0474
PAGE 22 OF 56

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Massachusetts and employed by Factory Mutual of Norwood, Massachusetts have inspected the repair or replacement described in this report on January 23, 1995 and state that to the best of my knowledge and belief, this repair or replacement has been made or constructed in accordance with the applicable section of the ASME Code.

By signing this certificate, neither the Inspector nor his employer makes any warrant, expressed or implied, concerning the repair or replacement described in this report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 1-23, 1995 Factory Mutual Systems
Signed Louise A. Linn Commissions NB10289 N MA1418
(Inspector) (Nat'l. Bd., State, Prov. and No.)

C R O S B Y

CROSBY VALVE & GAGE COMPANY
WRENTHAM, MA

Q.C.-257,REV.B

FACTORY ORDER NUMBER: NV4000329
CUSTOMER ORDER NUMBER: 94N3F-101699-001
VALVE SERIAL NUMBER: N56964-10-0033
VALVE TAG NUMBER: N/A

REPAIR CERTIFICATION
REPORT

Description of Repair:

VALVE SERIAL NUMBER N56964-06-0033 WAS MODIFIED TO VALVE SERIAL NUMBER N56964-10-0033. NOZZLE N94209 WAS REPLACED WITH N96523-33-0005 (CMTR, LP, UT AND WT REPORT ATTACHED). BELLOWS ASSEMBLY K57220 WAS MODIFIED TO K83206-32-0005. DISC INSERT N94210 WAS REPLACED WITH N96522-32-0011 (CMTR, LP, UT AND WT REPORTS ATTACHED).THE INLET NUTS WERE REPLACED WITH TRACE#OFG QTY 12 (CMTR,MAG ATTACHED). THE VALVE WAS REASSEMBLED, HYDROSTATICALLY, SET PRESSURE AND SEAT LEAK TESTED IN ACCORDANCE WITH T-16690 (REPORT ATTACHED). VALVE WAS INSPECTED TO DS-C-56964 -10 AND PACKAGED IN ACCORDANCE WITH P-1769. VALVE IS IN ACCORDANCE WITH SPEC.G-678838 REV.0 .

WBN-TVA-R95-0474
PAGE 23 OF 56

Deborah Allsward
QUALITY ASSURANCE

23 JANUARY 1995
DATE

PAGE 25 OF 127

CROSBY

CROSBY VALVE & GAGE COMPANY WRENTHAM, MASS

FORM NV-1 FOR SAFETY AND SAFETY RELIEF VALVES
As required by the Provisions of the ASME Code Rules

Q.C.-4C-1

DATA REPORT Safety and Safety Relief Valves

W860811K0098 (2)

1. Manufactured By Crosby Valve & Gage Co., 43 Kendrick St., Wrentham, MA 02093
Name and Address

Model No. HB-d6-BB Order No. N303153B Contract Date 1/26/83 National Board No. 905
Westinghouse Electric Corp., Nuclear Energy Systems,

2. Manufactured For P.O. Box 3700, Pittsburgh, PA 15230 Order No. 546-CCX-178353-BN,
Name and Address C/N #010

3. Owner Tennessee Valley Authority, Watts Bar Nuclear Power Station
Name and Address

4. Location of Plant SEVIOR City, TN 37381

5. Valve Identification 6RV88MSC Serial No. N56564-06-0029 Drawing No. DS-C-56964-6 Rev. E

Type Safety Orifice Size 2.154 Pipe Size -- Inlet 6 Outlet 6
Safety, Safety Relief, Pilot, Power Actuated Inch Inch Inch Inch

6. Set Pressure (PSIG) 2485 650
Rated Temperature F

Stamped Capacity 420,006 lbs/hr 3 % Overpressure 5% Blowdown (PSIG) 125

Hydrostatic Test (PSIG) Inlet 4575 Complete Valve ---

7. The material, design, construction and workmanship comply with ASME Code, Section III.
Class 1 Edition 1971, Addenda Date Winter 1972, Case No. ---

Pressure Containing or Pressure Retaining Components

FILMED FROM BEST AVAILABLE COPY

Part	Serial No. Identification	Material Specification (including Type or Grade)
Bar Stock & Forgings		
Body	<u>N90490-32-0033</u>	<u>ASME SA182 Gr. F316</u>
Bonnet	<u>N90353-36-0066</u>	<u>ASME SA105 Gr. II</u>
Support Rods		
Support Rods		
Nozzle	<u>N94209-31-0002</u>	<u>ASME SA182 Gr. F316</u>
Disc Holder	<u>K57220-32-0045</u> <u>N90553-32-0049</u>	<u>ASTM A637 Gr. 718</u>
Spring Washers	<u>K56380-40-0025</u> <u>N90350-33-0074</u> <u>N90350-33-0059</u>	<u>ASME SA105 Gr. II</u>
Adjusting Bolt	<u>N90351-36-0076</u>	<u>ASME SA193 Gr. B6</u>
Spindle Point	<u>K56381-37-0052</u> <u>N90354-36-0070</u>	<u>ASME SA193 Gr. B6</u>
Spindle Ball	<u>N90355-0052</u>	<u>ASTM A276 Type 440C</u>
Disc Insert	<u>N94210-33-0010</u>	<u>ASME SA637 Gr. 718</u>

or S.T. No. WB7-ASBNS
No. 83-3945

	Serial No. or Identification	Material Specification including Type or Grade
c. Spring	K56380-40-0025	<u>NX2761-0051</u> <u>ASTM A304 Gr. 51860H</u>
d. Bolting		
e. Other Parts such as Pilot Components		
Bonnet Stud	100987	ASME SA453 Gr. 660
Bonnet Nut	89997	ASME SA193 Gr. B6
Inlet Stud	N90488	ASME SA453 Gr. 660
Inlet Nut	N90489	ASME SA193 Gr. B6

We certify that the statements made in this report are correct.

Date 5/11/1983 Signed Crosby Valve & Gage Co. By [Signature]
 Manufacturer

Certificate of Authorization No. 1978 expires September 30, 1983

FILMED FROM BEST AVAILABLE COPY

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of MASS. and employed by Arkwright-Boston Manufacturers Mutual Insurance Company have inspected the equipment described in this Data Report on 5-9-1983 and state that to the best of my knowledge and belief, the manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Section III.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 05-11-1983 Factory Mutual System
[Signature] (Inspector) Commissions NR # 7883 ; MA-1224
 National Board, State, Province and No.)

CROSBY

CROSBY VALVE & GAGE COMPANY
WRENTHAM, MA

Q.C.-292, REV.A
SHEET 1 OF 2

REPAIR AND REPLACEMENT
TO NUCLEAR COMPONENTS AND SYSTEMS IN NUCLEAR POWER PLANTS

1. Work performed by Crosby Valve & Gage Company 43 Kendrick St. Wrentham, MA 02093
(Name and Address)
(Repair organization's P.O. No., Job No., etc.) NV4000329

2. Owner TENNESSEE VALLEY AUTHORITY KNOXVILLE, TN
(Name and Address)

3. Name and Identification of Nuclear Power Plant WATTS BAR NUCLEAR PLANT

4. Address of Nuclear Power Plant SPRING CITY, TN 37381

5. a. Identifying Nos. N56964-10-0029 905 -- ---- 1983
(Mfr's Serial No.) (Nat'l Bd. No.) (Jurisdiction No.) (Other) (Year Built)
b. Identification of component repaired or replacement component SAFETY VALVE
c. Name of Manufacturer CROSBY VALVE & GAGE COMPANY

Tests conducted: Hydrostatic (X) Pneumatic () Design Pressure () Pressure 4575.0 psi

7. Identification of System --

8. Applicable Section(s) III of ASME Code, 19 71 Edition
Addenda W72 Code Case --

9. Description of work VALVE MODIFICATION
(Use of additional sheet(s) or sketch(es) is acceptable if correctly identified)

10. Remarks: VALVE SERIAL NUMBER N56964-06-0029 WAS MODIFIED TO
VALVE SERIAL NUMBER N56964-10-0029. NOZZLE N94209 WAS
REPLACED WITH N96523-33-0004. BELLOWS ASSEMBLY K57220 WAS MODIFIED
TO K83206-32-0004. DISC INSERT N94210 WAS REPLACED WITH
N96522-32-0010. THE INLET STUDS WERE REPLACED WITH TRACE# YB2
QTY 6. THE INLET NUTS WERE REPLACED WITH TRACE# OFG QTY 12. THE
VALVE WAS TESTED FOR SET PRESSURE AND SEAT LEAKAGE IN ACCORDANCE
WITH TEST PROCEDURE T-16690.

WATTS BAR TVA TR95-01074
PAGE 2 OF 56

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and all design, material, and workmanship on this MOD conforms to the applicable section of the ASME Code.
(repair/replacement)

Signed Louise of Pavia QA Eng Manager 23 Jan, 1995
(Authorized Rep. of Repair Organization) (Title) (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Massachusetts and employed by Factory Mutual of Norwood, Massachusetts have inspected the repair or replacement described in this report on January 23, 1995 and state that to the best of my knowledge and belief, this repair or replacement has been made or constructed in accordance with the applicable section of the ASME Code.

By signing this certificate, neither the Inspector nor his employer makes any warrant, expressed or implied, concerning the repair or replacement described in this report. Furthermore, neither the Inspector nor his employ shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Factory Mutual Systems

Date 1-23, 1995

Signed [Signature]
(Inspector)

Commissions NA10289 N MA1418
(Nat'l. Bd., State, Prov. and No.)

CROSBY

CROSBY VALVE & GAGE COMPANY
WRENTHAM, MA

Q.C.-257,REV.B

FACTORY ORDER NUMBER: NV4000329
CUSTOMER ORDER NUMBER: 94N3F-101699-001
VALVE SERIAL NUMBER: N56964-10-0029
VALVE TAG NUMBER: N/A

REPAIR CERTIFICATION
REPORT

Description of Repair:

VALVE SERIAL NUMBER N56964-06-0029 WAS MODIFIED TO VALVE SERIAL NUMBER N56964-10-0029. NOZZLE N94209 WAS REPLACED WITH N96523-33-0004 (CMTR, LP, UT AND WT REPORT ATTACHED). BELLOWS ASSEMBLY K57220 WAS MODIFIED TO K83206-32-0004. DISC INSERT N94210 WAS REPLACED WITH N96522-32-0010 (CMTR, LP, UT AND WT REPORTS ATTACHED).THE INLET STUDS WERE REPLACED WITH TRACE#YB2 QTY 6(CMTR,LP ATTACHED) AND THE INLET NUTS WERE REPLACED WITH TRACE#OFG QTY12(CMTR,MAG ATTACHED). THE VALVE WAS REASSEMBLED,HYDROSTATICALLY, SET PRESSURE AND SEAT LEAK TESTED IN ACCORDANCE WITH T-16690 (REPORT ATTACHED). VALVE WAS INSPECTED TO DS-C-56964 -10 AND PACKAGED IN ACCORDANCE WITH P-1769. VALVE IS IN ACCORDANCE WITH SPEC.G-678838 REV.0 .

WEN-TVA-R95-0474

PAGE 4 OF 56

Deborah Allsbrook

QUALITY ASSURANCE

23 JANUARY 1995

DATE

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 10/18/98
Name
400 W. Summit Hill Drive, Knoxville, TN Sheet of
Address

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
P. O. Box 2000, Spring City, TN, 37381 MMG 98-012709-000
Address

3. Work Performed by WATTS BAR NUCLEAR PLANT Repair Organization P.O. No., Job No., etc. N/A
Name Type Code Symbol Stamp N/A
P.O. BOX 2000, SPRING CITY, TN 37381 Authorization No N/A
Address Expiration Date N/A

4. Identification of system 068, REACTOR COOLANT

5. (a) Applicable Construction Code ASME SEC. III 19 80 Edition, W'80 Addenda, NONE. Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1-PCV-068-0334-B	TARGET ROCK	S/N 11 (removed)	1947	B244	83	REPLACE	YES
1-PCV-068-0334-B	Target Rock	S/N 4 (installed)	1947	B244	83	Replac	yes

7. Description of Work REMOVE/REPLACE SAFETY RELIEF VALVE.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure X 1-TRI-68-6
 Other Pressure 2210-2250 psi Test Temp 750 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

PAGE 71 OF 107

FORM NIS-2 (Back)

9. Remarks

Applicable Manufacturer's Data Reports to be Attached

TRACKING # RR-02-35

N-546 CODE CASE

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the repair or replacement rules of the ASME Code, Section XI.

Type Code Symbol Stamp NONE.

Certificate of Authorization No. NONE.

Signed

HRD - Mech ENGR
Owner or Owner's Designee, Title

Date

4-6 19 99

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I & I of HARTFORD, CT have inspected the components described in this

Owner's Report during the period 10-26-98 to 4-6-99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.


Inspector's Signature

Commissions

TN 2533
National Board, State, Province, and Endorsements

Date

4-6 19 99

FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES
As Required by the Provisions of the ASME Code, Section III, Div. 1

1. Manufactured by Target Rock Corporation 1966 E. Broadhollow Rd E. Farmingdale, N.Y.
(Name and Address of N Certificate Holder)
2. Manufactured for Tennessee Valley Authority Chattanooga, Tennessee
(Name and Address of Purchaser or Owner)
3. Location of Installation Watts Bar Nuclear Plant, Units 1 & 2, Spring City, Tennessee
(Name and Address)
4. Pump or Valve Valve Nominal Inlet Size 3 (inch) Outlet Size 3 (inch)

(a) Model No. or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Nat'l. Bd. No.	(g) Year Built
821U	1,2,3,4	-----	8200-001	I	-----	1983
(1)						
(2)						
(3)						
(4)						
(5)						
(6)						
(7)						
(8)						
(9)						
(10)						

W860724K0532 (2)

Contract No. 831934
R.D. or S.T. No. _____
209 No. 83-2382

5. PRESSURIZED RELIEF POWER OPERATED RELIEF VALVE
(Brief description of service for which equipment was designed) FILMED FROM BEST AVAILABLE COPY

6. Design Conditions 2485 (Pressure) psi 680 (Temperature) F or Valve Pressure Class _____ (1)
7. Cold Working Pressure 4100 psi at 100°F.
8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
(b) Forgings			
Body	ASME-SA 182 SS 316L	Carme	

QC&R
FEB 17 1983
[Signature]

AUTHORIZED
FEB 16 1983
E.S.M.
NUCLEAR INSPECTOR
H.S.B.

(1) For manually operated valves only.
* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8-1/2" x 11", (2) information in items 1, 2 and 5 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets

PAGE 72 OF 72

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting			
(d) Other Parts			
Bonnet	ASME SA 479 SS 316	ARMCO	
Main Disc	ASME SA 479 SS 347	Joslyn	
Indicator Tube	ASME SA 479 SS 316	Universal Cyclops	
Flange	ASME SA 182 SS 316	Carpenter	
Seat Insert	ASME SA 479 SS 316L	Joslyn	

FILMED FROM BEST AVAILABLE COPY

9. Hydrostatic test 6150 psi Disk Differential test pressure 4510 psi

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. 1, Edition 1980
 Addenda Winter 1980 (Date) Code Case No. _____ Date _____
 Signed Target Rock Corporation (N Certificate Holder) by G. Abruzzo, Mgr. of Quality 2-4-83
 Our ASME Certificate of Authorization No. 1947 to use the _____ (N) symbol expires 12/9/83 (Date)

CERTIFICATION OF DESIGN

Design information on file at Target Rock Corporation
 Stress analysis report (Class 1 only) on file at Target Rock Corporation
 Design specifications certified by (1) Marvin V. Miller
 PE State TN Reg. No. 013995
 Stress analysis certified by (1) Martin Goldstone
 PE State NY Reg. No. 31940
 (1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of New York and employed by Commercial Union Insurance of Boston, Mass. have inspected the pump, or valve, described in this Data Report on 2/4 19 83, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 2/4 19 83 William A. Ireland Commissions **NEW YORK STATE COMMISSION NO. 2288** ALSO COMMISSIONED IN Penn., Ohio & Conn.

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 10/18/98
Name
400 W. Summit Hill Drive, Knoxville, TN Sheet _____ of _____
Address

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
P. O. Box 2000, Spring City, TN, 37381 MMG 98-000896-000
Address Repair Organization P. O. No., Job No., etc.

3. Work Performed by WATTS BAR NUCLEAR PLANT Type Code Symbol Stamp N/A
Name
P.O. BOX 2000, SPRING CITY, TN 37381 Authorization No N/A
Address Expiration Date N/A

4. Identification of system 063, SAFETY INJECTION

5. (a) Applicable Construction Code ASME SEC. III 19 71 Edition, S'72 Addenda, NONE. Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1-RFV-063-0626-A	CROSBY	<i>NS6702-00-0003</i>	<i>120</i>	<i>MODEL TB-35-TD-WR</i>	<i>75</i>	<i>REPLACE MENT</i>	<i>YES</i>
1-RFV-063-0627-B	CROSBY	<i>NS6702-00-0004</i>	<i>121</i>	<i>MODEL TB-35-TD-WR</i>	<i>75</i>	<i>REPLACE MENT</i>	<i>YES</i>
1-RFV-063-0627-S	CROSBY	<i>NS6881-00-0047</i>	<i>255</i>	<i>Model JRAK-BS</i>	<i>77</i>	<i>REPLACE MENT</i>	<i>YES</i>
1-RFV-063-0626-A	CROSBY	<i>NS6702-00-0009</i>	<i>187</i>	<i>MODEL TB-35-TD-WR</i>	<i>76</i>	<i>REPLACED</i>	<i>YES</i>
1-RFV-063-0627-B	CROSBY	<i>NS6702-00-0010</i>	<i>188</i>	<i>MODEL TB-35-TD-WR</i>	<i>76</i>	<i>REPLACED</i>	<i>YES</i>
1-RFV-063-0577-S	CROSBY	<i>NS6881-00-0001</i>	<i>77</i>	<i>MODEL JRAK-BS</i>	<i>74</i>	<i>REPLACED</i>	<i>YES</i>
<i>N/A</i>							

7. Description of Work REMOVE/REPLACE SAFETY RELIEF VALVE.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure X
 Other Pressure 600 psi Test Temp 400 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks

Applicable Manufacturer's Data Reports to be Attached

TRACKING # RR-02-36

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp NONE.

Certificate of Authorization No. NONE.

Signed D. Williams MAINT. SPEC. Date 4/21 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I & I of HARTFORD, CT have inspected the components described in this Owner's Report during the period 10-26-98 to 4-6-99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions TN 2533
Inspector's Signature National Board, State, Province, and Endorsements

Date 4/6 19 99

CROSBY

CROSBY VALVE & GAGE COMPANY
WRENTHAM, MASS.

FORM NV-1 FOR SAFETY AND SAFETY RELIEF VALVES
As required by the Provisions of the ASME Code Rules

Q.C. 448

DATA REPORT
Safety and Safety Relief Valves

NB-120

1. Manufactured By Crosby Valve & Gage Co., 43 Kendrick St., Wrentham, Mass., 02093
Name and Address

Model No. JB-35-TD-WR Order No. N302945 Contract Date 3/30/73
Manufactured For Westinghouse Electric Corp., Nuclear Energy Systems, Pittsburgh, Pa. Order No. 546-CC-183416-BN

2. Manufactured For Tennessee Valley Authority
Name and Address

3. Owner Spring City, Tennessee
Name and Address

W860811K0086 (2)

4. Location of Plant Spring City, Tennessee
Name and Address

5. Valve Identification Kv-1-8856AWAT Serial No. N56902-00-0003 Drawing No. DS-C-56902 Rev. A

Type Relief Orifice Size J Pipe Size 2 Inlet 2 Outlet 3
Inch Inch Inch

Set Pressure (PSIG) 600 Rated temperature 400

Stamped Capacity 400 GPM WATER Overpressure 107% of S.P. Blowdown (PSIG) 107% of S.P.

Hydrostatic Test (PSIG) Inlet 950 Outlet 425
Complete Valve

7. The material, design, construction and workmanship comply with ASME Code Section III.

Class 2 Edition 1971 Addenda Date Summer 1972

N-5

FILMED FROM BEST AVAILABLE COPY

Pressure Containing or Pressure Retaining Components

	Serial No. Identification
a. Castings	
Bonnet	N90450-31-0032
	N90451-31-0014
b. Bar Stock and Forgings	
Support Rods	N90137-31-0043
Nozzle	N90448-33-0075
Disc	N88634-38-0102
Spring Washers	N88634-38-0102
Adjusting Bolt	N88635-39-0089
Spindle	N88669-34-0045

Material Specification Including Type or Grade	
ASTM A 351 72 Gr. CF8M	
ASTM SA 351 72 Gr. CF8M	
ASTM A 216 70 Gr. WCB	
ASTM SA 216 Gr. WCB	
ASTM A 182 71 Type 316	
ASTM SA 182 Type 316	
ASTM A 479 71 Type 316	
ASTM SA 479 Type 316	
ASTM A 193 70 Gr. B6	
ASTM SA 193 Gr. B6	
ASTM A 193 70 Gr. B6	
ASTM SA 193 Gr. B6	
ASTM A 193 70 Gr. B6	
ASTM SA 193 Gr. B6	

REG. NO. 54114-1
ITEM NO. 5
209 NO. 75-7604

DATE 3-12-76
INITIALS

PAGE 77 OF 107

719 13

Serial No. or Identification

Material Specification including Type or Grade

NX 2600-0023

ASTM A 638 70 Gr. B60

c. Spring

d. Bolting

e. Other Parts, such as Pilot Components

Bonnet Stud

89289

ASTM A 453 70 Gr. B60

ASME SA 453 70 Gr. B60

Bonnet Stud Nut

89293

ASTM A 193 71 Gr. B6

ASME SA 193 71 Gr. B6

REG. NO.

ITEM NO.

209 NO.

5-4114-1
5
75-7604

We certify that the statements made in this report are correct.

Date

3-12-75

Signed

Crosby Valve & Gage Co.

By

Ch. J. ...

Manufacturer

QA Manager

Certificate of Authorization No.

926

expires October 28, 1977

FILMED FROM BEST AVAILABLE COPY

N-5

CERTIFICATE OF CHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Mass. and employed by Factory Mutual System*, Norwood, Massachusetts have inspected the equipment described in this Data Report on March 12, 1975 and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date March 12, 1975

Donald E. Chmura
(Inspector)

Commissions

N.B. 6065

National Board, State, Province and No. 1

*Arkwright-Boston Manufacturers Mutual Insurance Company - Mutual Boiler and Machinery Division

G.C. Sk...
3-12-76
DATE INITIAL

PAGE 78 OF 181

677 12

CROSBY

CROSBY VALVE & GAGE COMPANY

WRENTHAM, MASS

FORM NV-1 FOR SAFETY AND SAFETY RELIEF VALVES
As required by the Provisions of the ASME Code Rules

Q.C. 41B

DATA REPORT
Safety and Safety Relief Valves

NB-121

Manufactured By Crosby Valve & Gage Co., 43 Kendrick St., Wrentham, Mass. 02093
Name and Address

Model No. JB-35-TD-WR Order No. N302945 Contract Date 3/30/73

Manufactured For Westinghouse Electric Corp. Nuclear Energy Systems Pittsburgh, Pa. Order No. 545-CCK-183416-BN
Name and Address

Owner Tennessee Valley Authority
Name and Address

W860811K0087 (2)

Location of Plant Spring City, Tennessee

Valve Identification RV-1-9856EWAT Serial No. N56902-00-0006 Drawing No. DS-C-56902 Rev. A

Type Relief Orifice Size J Pipe Size _____ Inlet 2 Outlet 3
inch inch inch inch
Safety Safety Relief Pilot Power Actuated
Set Pressure (PSIG) 600 Rated Temperature 400 F

Stamped Capacity 400 GPM 10 Orifice Pressure _____ Blowdown (PSIG) 10 % of S.P.

Hydrostatic Test (PSIG) Inlet 950 Outlet 425
Complete Valve

7. The material, design, construction and workmanship comply with ASME Code, Section III.

Class 2 Edition 1971 Addenda Date SUMMER 1972

FILMED FROM BEST AVAILABLE COPY

N-5

Pressure Containing or Pressure Retaining Components

	Serial No. Identification
a. Castings	
Body	N90450-31-6040 N90451-31-0002
Bonnet	
b. Bar Stock and Forgings	
Support Rods	N90137-31-0006
Nozzle	
Disc	N90448-31-0003 N88634-38-0151 N88634-38-0142
Spring Washers	
Adjusting Bolt	N88635-39-0092 N88669-34-0033
Spindle	

Material Specification Including Type or Grade	
ASTM- A 351 72 GR CF8M	
ASME-SA 351 72 Gr. CF8M	
ASTM- A 216 70 Gr. WCB	
ASME-SA 216 Gr. WCB	
ASTM- A 182 71 Type 316	
ASME-SA 182 Type 316	
ASTM- A 479 71 Type 316	
ASME-SA 479 Type 316	
ASTM- A 193 70 Gr. B6	
ASME-SA 193 70 Gr. B6	
ASTM- A 193 70 Gr. B6	
ASME-SA 193 Gr. B6	
ASTM- A 193 70 Gr. B6	
ASME-SA 193 Gr. B6	

REG. NO. 54114-1
ITEM NO. 5
75-7604

Q. & S. 3-12-76 DATE INITIAL

PAGE 79 OF 187

Serial No. or Identification: NX2600-0022
 Material Specification including Type or Grade: ASTM-A 638 Gr. 660

c. Spring

d. Bolting

e. Other Parts such as Pilot Components

Bonnet Stud 89289 ASTM-A 193-70 Gr. 660
ASME-SA 453 Gr. 660
 Bonnet Stud Nut 89293 ASTM-A 193-71 Gr. 86
ASTM-SA 193 Gr. 86

REC NO 54114-1
 ITEM NO 5
 200 NO 75-7604

We certify that the statements made in this report are correct.

Date 3-12-75 Signed Crosby Valve & Gage Co. By [Signature]
 Manufacturer QA Manager

Certificate of Authorization No. 926 expires October 28, 1977

FILMED FROM BEST AVAILABLE COPY

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Mass. and employed by Factory Mutual System*, Norwood, Massachusetts have inspected the equipment described in this Data Report on March 13, 1975 and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date March 13, 1975
Donald J. Chaus (Inspector) Commission A.B. 6065
 National Board, State, Province and No. 1

*Arkwright-Boston Manufacturers Mutual Insurance Company - Mutual Boiler and Machinery Division

PAGE 80 OF 187

G.C. & S.
 3-12-76
 DATE
 INITIAL

CROSBY

CROSBY VALVE & GAGE COMPANY

WRENTHAM, MASS

S.O. 220

FORM NV-1 FOR SAFETY AND SAFETY RELIEF VALVES
As required by the Provisions of the ASME Code Rules

DATA REPORT
Safety and Safety Relief Valves

3A RV-2 SWB

1. Manufactured By Crosby Valve & Gage Co., 43 Kendrick St., Wrentham, Mass 02093
Name and Address

Model No. JRAK-BS Order No. N302949 Contract Date 3/30/73 National Board No. 255
Manufactured For Westinghouse Electric Corp., Nuclear Energy Systems
P. O. Box 355, Pittsburgh, Pa. 15230 Order No. 546-CCK-183421-BN

3. Owner Tennessee Valley Authority, Watts Bar Nuclear Power Station, Unit #2
Name and Address

4. Location of Plant Near Spring City, Tennessee 37381

W860811K0045 (2)

5. Valve Identification RV-2-8842-WBT Serial No. N56884-00-0047 Drawing No. WDS-C-A56884 Rev. A

Type Relief Orifice Size SPL Pipe Size 3/4 Inlet 1 Outlet 1
Safety Safety Relief Pilot Power Actuated

6. Set Pressure (PSIG) 600 Rated Temperature 350°

Stamped Capacity 20 GPM Water 10 % Overpressure Blowdown 10% of S.P.

Hydrostatic Test (PSIG) Inlet 950 Outlet 425

7. The material, design, construction and workmanship comply with ASME Code, Section III.

Class 2 Edition 1971, Addenda Date Winter 1972, Case No. _____

Pressure Containing or Pressure Retaining Components

FILMED FROM BEST AVAILABLE COPY

	Serial No. Identification	Material Specification including Type or Grade
a. Castings		
Body	<u>N90457-40-0074</u>	<u>ASME SA351 Gr. CF8M</u>
Bonnet	<u>N90456-37-0130</u>	<u>ASTM A216-70 Gr. WCB</u> <u>ASME SA216 Gr. WCB</u>
b. Bar Stock and Forgings		
Support Rods	<u>N90458-36-0050</u>	<u>ASME SA479 Type 316</u>
Nozzle	<u>N90455-34-0082</u>	<u>ASTM A479-71 Type 316</u> <u>ASME SA479 Type 316</u>
Disc Insert	<u>N88613-55-0990</u> <u>N88613-55-1062</u>	<u>ASTM A193-72 Gr. B8</u> <u>ASME SA193 Gr. B8</u>
Spring Washers	<u>N90254-39-0208</u>	<u>ASTM A193-71 Gr. B8</u> <u>ASME SA193 Gr. B8</u>
Adjusting Bolt	<u>N88611-40-0223</u>	<u>ASTM A193-71 Gr. B8</u> <u>ASME SA193 Gr. B8</u>
Spindle	<u>K55158-40-0223</u>	

50, 220
REC. NO. 54114-1
INDEX NO. 5A
JOB NO. 77-5059

REG. NO. 54114-1
 ITEM NO. 5A
 TAG NO. 77-5059

S.O. 22

Serial No. or
 Identification

Material Specification
 Including Type or Grade

NX2613-0060

ASTM A313-70 Type 316

c. Spring

d. Bolting

e. Other Parts such as Pilot Components

We certify that the statements made in this report are correct.

Date 1-18 19 77 Signed Crosby Valve & Gage Co. By [Signature]
 Manufacturer QA Manager

Certificate of Authorization No. 926 expires October 28, 1977

FILMED FROM BEST AVAILABLE COPY

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Mass. and employed by Factory Mutual Systems*, Norwood, Mass. have inspected the equipment described in this Data Report on January 18, 1977 and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date January 18, 1977
[Signature] (Inspector) Commissions Mass. 1090
 National Board, State, Provincial and Terr.

*Arkwright-Boston Manufacturers Mutual Insurance Company - Mutual Boiler & Machinery Division.

98000731001

WO # 98-000731-001

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 10/18/98
Name
400 W. Summit Hill Drive, Knoxville, TN Sheet of
Address

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
P. O. Box 2000, Spring City, TN, 37381 MMG 98-000731-001
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by WATTS BAR NUCLEAR PLANT Type Code Symbol Stamp N/A
Name
P. O. BOX 2000, SPRING CITY, TN 37381 Authorization No N/A
Address Expiration Date N/A

4. Identification of system 003, MAIN FEEDWATER

5. (a) Applicable Construction Code ASME SEC. III 19 74 Edition, NONE Addenda, NONE Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1-CKV-003-0508	WALWORTH	D66451	1712	Model 5353	73	REPAIR	Yes

7. Description of Work REMOVE/REPLACE SAFETY RELIEF VALVE, HINGE PIN PLUG. etc
REPAIR CHECK
11-1-73

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure X
 Other Pressure 1185 psi Test Temp 600 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

98000731001

WO # 98-000731-001

FORM NIS-2 (Back)

9. Remarks

Applicable Manufacturer's Data Reports to be Attached

TRACKING # RR-02-37

CODE CASE N46-1.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPAIR conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp NONE.

Certificate of Authorization No. NONE.

Signed DH Collins Mech Engr Date 4/14 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I & I of HARTFORD, CT

have inspected the components described in this Owner's Report during the period 11/3/98 to 4/16/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce M Earnigh Commissions TN 2534 I N A
Inspector's Signature National Board, State, Province, and Endorsements

Date 4/15 19 99

98000731001

W860808K0013

2

FORM NPV-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES

As Required by the Provisions of the ASME Code, Section III, Div. 1

1. Manufactured by Walworth Company, Greensburg Plant, Greensburg, Pa. 15601
(Name and Address of Manufacturer)

2. Manufactured for Tennessee Valley Authority, Spring City, Tennessee.
(Name and Address of Purchaser or Owner)

3. Location of Installation Watts Bar Nuclear Plant, Unit #1, Spring City, Tennessee
(Name and Address)

4. Pump or Valve Valve Nominal Inlet Size 16" Outlet Size 16"
(Inch)

(a) Model No. (b) Manufacturers' (c) Canadian (d) Drawing (f) Nat'l (g) Year
 Series No. Serial Registration No. No. Ed. No. - - - - -
 or Type No. No. No. No. No. - - - - -

(1) 5353 D-66451 N/A A-12986-M3 2 17L3 1973

FILMED FROM BEST AVAILABLE COPY

HARD COPY RETAINED

5. Feedwater
(Brief description of service for which equipment was designed)

Design Conditions 1185 psi 600 F or Valve Pressure Class (1)
(Pressure) (Temperature)

1. Cold Working Pressure 2160 psi at 100°F.
 2. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
Body 175G	SA 352, LCB	Walworth Co.	Seal Welded Seat
Bonnet G381	SA 352, LCB	Walworth Co.	CoCrA Backseat
Disc G234 P4	SA 352, LCB	Walworth Co.	CoCrA Faced
			VALVE
			D66451

(b) Forgings		SERIAL NO.

APR 28 1973
 AUTHORIZED
 APR 28 1973

REC. NO. 73015
 ITEM NO. 2
 209 NO. 78-22124

APR 28 1973
 APR 23 1973

(1) For manually operated valves only.
 * Supplemental sheets, in form of lists, sketches or drawings in items 1, 2 and 5 on this data report is included on each sheet and (3) Each sheet is numbered and number of sheets

FACE OF

98000731001

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting			
Stud 47089 (PL)	ASME SA 320, Gr. L7	REC	
Nut 9853E (OA)	ASME SA 194, Gr. 7	REC	
(d) Other Parts			
Plug - 61814	ASME SA 320, Gr. L7	McWilliams	
			VALVE
			D66451
			SERIAL NO.

HARD COPY RETAINED

FILED FROM BEST AVAILABLE COPY

3. Hydrostatic test 3150 psi

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. 1, Edition 1974

Addenda N/A Code Case No. N/A Date 1/12/75

Signed Walworth Company by G. J. Hill
(Manufacturer)

Our ASME Certificate of Authorization No. 1951 to use the N symbol expires 12/9/80
(Date)

CERTIFICATION OF DESIGN

Design information on file at Walworth Company, Greensburg, Pa. 15601

Stress analysis report (Class 1 only) on file at N/A

Design specifications certified by (1) M. N. Bressler
PE State PA Reg. No. 9411

Stress analysis certified by (1) N/A
PE State PA Reg. No.

(1) Signatures not required. List name only.

REQ NO. 83075

ITEM NO. 4

ISS NO. 3

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by The Hartford Steam Boiler I&I Co of Hartford, Conn. 06102 have inspected the pump, or valve, described in this Data Report on 1/12 1975 and state that to the best of my knowledge and belief, the Manufacturer has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 1/12 1975 Commissions NB 3554 PA 2420
(Inspector) (Name, State, Prov. and No.)

PAGE 02 OF 187

ATTACHMENT # 1
 NO. 95-000731-001

PG. 1 of 2.

Records Correction Notice
 Page 1 of 1

98000731001

Instructions

1. Complete Blocks 1-11 (if required information is known).
2. Each page shall be numbered (e.g., page 1 of 3, page 2 of 3, etc.).
3. Changes to approved records shall be reviewed, verified, and approved by the same organization that performed the original review, verification, and approval.
4. Submit the completed form and records to MS.

(If applicable)
RCN #
Page 1 of 2

1. Document Title/Subject/Identifier Form NPV-1 Manufacturers' Data Report For Nuclear Pumps Or Valves							
2. Document Number D66451	3. Revision Number 0	4. Sheet Number 2	5. Unit Number 1				
6. Document Date 1/12/78	7. Effective Date of this Change 10/29/98	8. QA Record <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO					
9. Reel/Frame Number or Archive Location of Original Record (if available) W41349 - 0027 and E07228 - 1485							
10. Correction Action (check all that apply)							
<input type="checkbox"/> Supplement Record (add additional pages to record)							
<input checked="" type="checkbox"/> Correct Record (change existing information on record)							
<input type="checkbox"/> Delete Records (list records to be deleted in the reason for change block below)							
<input type="checkbox"/> Invalidate Records (list records to be invalidated in the reason for change block below)							
11. Reason for Change/Description of Change							
<p>The "Material Specification No." section on FORM NPV-1 (Back) for Plug - 61814 listed in section 3.(d) incorrectly identified the material as ASME SA 320, Gr. LF2. The correct material specification is ASME SA 350, Gr. LF2. This was verified from the NPV-1 Data Report for Document No. D66450 and from Material Test Report No. 10614 from McWilliams Forge Company, Inc. and the Certification of Impact Testing Data WMT&R Report No. 7243 which are part of the Waiworth documentation package for valve D66451 (Reel E07228 - Frame 1482). This was an obvious typographical error which was not picked up during the initial record review and completion.</p>							
Review/Verification/Approval							
Signature	<i>Robert D Briggs</i>	Date	10-29-98	Signature		Date	
Signature	<i>[Signature]</i>	Date	10/29/98	Signature		Date	
Signature	<i>[Signature]</i>	Date	10/29/98	Signature		Date	
Signature		Date		Signature		Date	

PAGE 0001

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting			
Stud 57089 (PL)	ASME SA-320, Gr. L7	REC	
Nut 9853E (OA)	ASME SA 194, Gr. 7	REC	
(d) Other Parts			
Plug - 61814	350 ASME SA 320, Gr. LF2	McWilliams	
	RBB 10-29-98		
			VALVE
			B66451
			SERIAL NO.

3. Hydrostatic test 3150 psi.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. L, Edition 1974

Addenda N/A Code Case No. N/A Date 1/12/79
Made by Walworth Company (Manufacturer) by G. J. Hill
Our ASME Certificate of Authorization No. 1951 to use the (N) (NPV) symbol expires 12/9/80 (Date)

CERTIFICATION OF DESIGN

Design information on file at Walworth Company, Greensburg, Pa. 15601

Stress analysis report (Class 1 only) on file at N/A

Design specifications certified by (1) M. N. Bressler

PE State Tenn. Reg. No. 9411

Stress analysis certified by (1) N/A

PE State Reg. No.

(1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by The Hartford Steam Boiler I&I C of Hartford, Conn. 06102 have inspected the pump, or valve, described in this Data Report on 1/12 19 78 and state that to the best of my knowledge and belief, the Manufacturer has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any way for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 1/12 19 78
Inspector

Commissions NB 8257
(Nat'l Bd., State, Prov. and No.)

8
 WO # 97-011734-000
 SDB 4-649

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
 As Required by the Provisions of the ASME Code Section XI

1. Owner <u>TENNESSEE VALLEY AUTHORITY</u> <small>Name</small> <u>400 W. Summit Hill Drive, Knoxville, TN</u> <small>Address</small>	Date <u>10/29/98</u> Sheet _____ of _____ Unit <u>Unit 1</u> MMG <u>97-011734-000</u> <small>Repair Organization P.O. No., Job No., etc.</small> Type Code Symbol Stamp <u>N/A</u>
2. Plant <u>Watts Bar Nuclear Plant</u> <small>Name</small> <u>P. O. Box 2000, Spring City, TN, 37381</u> <small>Address</small>	Authorization No <u>N/A</u> Expiration Date <u>N/A</u>
3. Work Performed by <u>WATTS BAR NUCLEAR PLANT</u> <small>Name</small> <u>P.O. BOX 2000, SPRING CITY, TN 37381</u> <small>Address</small>	Authorization No <u>N/A</u> Expiration Date <u>N/A</u>

4. Identification of system 062, CHEMICAL VOLUME CONTROL

5. (a) Applicable Construction Code ASME SEC. III 19 80 Edition, W'80 Addenda, NONE Code Case 210 6/6/99
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989 11-3-93

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1-PCV-068-0340A-A	TARGET ROCK	5	1947	Model 83A	83	REPLACE MENT	Yes
1-PCV-68-340A-A	TARGET ROCK	6	1947	Model 83A	83	REPLACED	Yes

7. Description of Work REPLACE VALVE.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure ISLT PER 1-TRI-68-6.
 Other Pressure 2250 psi Test Temp 650 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

8
WO # 97-013995-000
500 4-6-99

FORM NIS-2 (Back)

9. Remarks

Applicable Manufacturer's Data Reports to be Attached

TRACKING # RR-02-39 8/11/98

REF. CODE CASE N416-1

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the repair or replacement rules of the ASME Code, Section XI.

Type Code Symbol Stamp NONE.

Certificate of Authorization No. N/A

Signed DH Collins Mech Engr Date 4/5 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I & I of HARTFORD, CT have inspected the components described in this

Owner's Report during the period 11-3-98 to 4-5-99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions TN2533
Inspector's Signature National Board, State, Province, and Endorsements

Date 4-5-99 1999

FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES
As Required by the Provisions of the ASME Code, Section III, Div. 1

7

1. Manufactured by Targer Rock Corporation 1966E Broadhollow Rd E. Farmingdale, N.Y.
(Name and Address of N Certificate Holder)

2. Manufactured for Tennessee Valley Authority Chattanooga, Tennessee
(Name and Address of Purchaser or Owner)

3. Location of Installation Sequoyah Nuclear Plant, Daisey, Tennessee
(Name and Address)

4. Pump or Valve Valve Nominal Inlet Size 3 (inch) Outlet Size 3 (inch)

(a) Model No. or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Nat'l. Bd. No.	(g) Year Built
83A	5 6		8200-001	1		1983

W860724K1153 (2)

FILMED FROM BEST AVAILABLE COPY

5. PRESSURIZED RELIEF POWER RELIEF VALVE
(Brief description of service for which equipment was designed)

6. Design Conditions 2485 psi 680 °F or Valve Pressure Class 1707 (1)
(Pressure) (Temperature)

7. Cold Working Pressure 4100 psi at 100°F.

8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
(b) Forgings			
Body	ASME SA 182, F316L	Carmel Forge	

TVA 15 CMK

APPROVED
DEC 08 1983
BTL

209 No. 94-0690

For manually operated valves only.

* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8-1/2" x 11", (2) information in items 1, 2 and 5 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

Mark No.	Material Spec. No.	Manufacturer	Remarks
Booting			
(d) Other Parts			
Bonnet	ASME SA479 316	Joslyn Stainless Steel	
Main Disc	ASME SA 479, SS347	Joslyn Stainless Steel	
Indicator Tube	ASME SA 479, SS316	Universal Cyclops	
Flange	ASME SA 182, 316	Carpenter Tech, & Universal Cyclops	
Seat Insert	ASME SA 479, 316L	Joslyn & Carpenter Tech.	

9. Hydrostatic test 6150 psi. Disk Differential test pressure 4510 psi.

FILMED FROM BEST AVAILABLE COPY

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. 1, Edition 1980.

Addenda Winter 1980 (Date) Code Case No. _____ Date _____

Signed Target Rock Corporation by R. Rucolani 11/13/83
(N Certificate Holder) RRG. Abruzzo, N Mgr. of Quality 12/9/83
 Our ASME Certificate of Authorization No. 1947 to use the _____ symbol expires _____
(N) (Date)

CERTIFICATION OF DESIGN

Design information on file at Target Rock Corporation
 Stress analysis report (Class 1 only) on file at Target Rock Corporation

Design specifications certified by (1) Marvin V. Miller
 PE State IN Reg. No. 013995
 Stress analysis certified by (1) Marrin Gladstone
 PE State NY Reg. No. 31940

(1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of New York and employed by Commercial Union Ins. of Boston, Mass. have inspected the pump, or valve, described in this Data Report on 11/18 19 83, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 11/18 19 83 NEW YORK STATE COMMISSION NO. 2238
William A. Heland Commissions ALSO COMMISSIONED IN Penn., Ohio & Conn.
(Inspector) (Nat'l Bd., State, Prov. and No.)

98001023000

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 11/5/98
Name
400 W. Summit Hill Drive, Knoxville, TN
Address
Sheet _____ of _____

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
P. O. Box 2000, Spring City, TN, 37381
Address
MMG 98-001023-000
Repair Organization P. O. No., Job No., etc.

3. Work Performed by MWH MAINT WBNP Type Code Symbol Stamp NONE
Name
P.O. BOX 2000, SPRING CITY, TENN. 37381 Authorization No NA
Address
Expiration Date NA

4. Identification of system REACTOR COOLANT SYSTEM, DGR

5. (a) Applicable Construction Code Sect III 1911 Edition, 872 Addenda NA Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>CARTRIDGE SEAL *</u>	<u>WESTINGHOUSE</u>	<u>2183</u>	<u>N/A</u>	<u>P/N 5055024601</u>	<u>90</u>	<u>REPLACEMENT</u>	<u>N</u>
<u>* FOR 1-RMP-06X-0031</u>							

7. Description of Work Replace cartridge seal. Seal was removed from RCP 2 during RFD1 and was inspected under WO 96-18330-003. S/N 2183. To be installed in RCP 2.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure 2500 psi Test Temp 650 °F 1-TAI-68-6

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

53

98001023000

FORM NIS-2 (Back)

9. Remarks TRACKING NO. RR-02-40 9/11/98

Applicable Manufacturer's Data Reports to be Attached

AR

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI, repair or replacement

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A

Signed D.H. Collins Mech Engr. Date 4/13 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I&I CO. of Hartford CT have inspected the components described in this Owner's Report during the period 11/5/98 to 4/15/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce M. Camigli Commissions TN 2534 "I" "N" "A"
Inspector's Signature National Board, State, Province, and Endorsements

Date 4/15 19 99

59

98001023000

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
 As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY
 Name

Date 1/20/94

P.O. BOX 2000 SPRING CITY, TN
 Address

Sheet 1 of 1

2. Plant W-3 BWR Nuclear Plant
 Name

Unit 1

P.O. BOX 2000 SPRING CITY, TN
 Address

WORK PLAN K-203579A-3
 Repair Organization P.O. No., Job No., etc.

3. Work Performed by TVA
 Name

Type Code Symbol Stamp N/A

P.O. BOX 2000 SPRING CITY, TN
 Address

Authorization No. N/A
 Expiration Date N/A

4. Identification of System Reactor Coolant System (RCS)

5. (a) Applicable Construction Code ASME B1.9.1 Edition Summer 72 Addenda 1 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1990 USC

6. Identification of Components Required or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Required, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Reactor Coolant Pump 1 Seal Housing	Westinghouse	2131	N/A	P/N 5055024G01	1990	Replacement	No
Reactor Coolant Pump 2 Seal Housing	Westinghouse	2133	N/A	P/N 5055024G01	1990	Replacement	No
Reactor Coolant Pump 3 Seal Housing	Westinghouse	2237	N/A	P/N 5055024G01	1990	Replacement	No
Reactor Coolant Pump 4 Seal Housing	Westinghouse	2276	N/A	P/N 5055024G01	1990	Replacement	No

7. Description of Work Installation of 300 cartridge seals included new seal housings

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

* This form will be added to WP-K-2035-3 after approval as a corrective action to WB PER 930414. See 1/27/94

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 3 1/2 in. x 11 in., (2) information items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is noted at the top of this form.

60

PAGE 98 OF 102

98001023000

BUY S. O. NO.	PROJECT P. O.	PROJECT	WRD S. O. NO.	DATE
71062-54114-1	IN A	W I A T	125	0 2 2 7 3
CO-42067	Q094	NA	NA	NA
EQUIP. SPEC. NO. & REV. (BASE)	EQUIP. SPEC. NO. & REV. (PROJECT)	DRAWING NO.	REV.	QTY. RELEASED
NA	NA	114E921	11	52
U. I. ITEM NUMBER	SPIN NUMBER	PART NAME	QTY. RELEASED	
NA	RCPCPI	Cartridge Seal Assembly	2	
SERIAL OR IDENTIFICATION NUMBERS				
See Attached PA 2217				

The attributes listed below have been reviewed and approved by QC/QA as noted by an A in the status column. Non-applicable items are lined out. Records are available for review. Contingent items are identified by "C" in the status column and explained in the remarks section.

STATUS	STATUS	STATUS
<u>A</u> Material Certifications	<u>_____</u> Operating Electrical Test Records	<u>_____</u> HOME Data Power Records
<u>A</u> Heat Treat Records	<u>_____</u> Non-Operating Electrical Test Records	<u>_____</u> Condition Usage Record
<u>A</u> RT Film and Records	<u>A</u> Pressure Test Records	<u>_____</u> Special Handling Material
<u>A</u> PT Records	<u>_____</u> Seal Tightness Test Records	<u>A</u> Performance Test
<u>_____</u> Records	<u>A</u> Performance Test Records	<u>_____</u> Certification - Attached
<u>A</u> UT Records	<u>A</u> Welding Personnel Qual. Cert.	<u>A</u> General Assembly Drawing
<u>A</u> Visual Inspection Records	<u>A</u> NDE Personnel Qual. Cert.	<u>_____</u> Attached
<u>A</u> Dimensional Inspection	<u>_____</u> Painting	<u>_____</u>
<u>A</u> Cleanliness	<u>A</u> Packaging	<u>_____</u>

CUSTOMER QA DATA PACKAGE REQUIRED BY PURCHASE ORDER: YES NO DEVIATION NOTICE(S): NONE APPLICABLE (NISI LISTED BY DN NUMBER BELOW COPY ATTACHED TO SHIPPING PAPERS)

WESTINGHOUSE

PAGE 96 OF 187

THE SUPPLIER CERTIFIES that for the equipment and material released, all contractual requirements have been met. Approved deviations, if any, are listed above.

SUPPLIER	P.O. NUMBER
NA	NA
SUPPLIER SIGNATURE	DATE
NA	NA

The equipment shown hereon is released by Quality Assurance. Shipment may be made subject to authorization by Purchasing.

The equipment shown hereon has been certified that the equipment shown meets all requirements of the purchase order. Westinghouse has reviewed evidence supporting the release and except as indicated above has detected no deviations from such requirements. This release does not waive any rights Westinghouse may have under the purchase order including Westinghouse's right to reject the equipment upon discovery of any such deviations after arrival at destination.

[Signature]
Westinghouse Quality Assurance Representative

WILMINGTON, PA 15026

SHOP ORDER
 1094
 GENERAL ORDER NO.
 C042067
 PURCHASE ORDER NO.
 71062-54114-1
 SPIN NUMBER
 RCPPI
 CUSTOMER WITNESS REQ
 Yes

QTY. THIS SHIPMENT
 1
 TOTAL ON ORDER
 107
 TOTAL DEL'D TO DATE
 103
 PARTIAL
 X
 FINAL

DATE
 1/8/90
 DOMESTIC
 X
 EXPORT
 FLAMMABLE
 No
 NUMBER OF CONTAINERS
 8

PAGE 05 OF 07
 OR NUMBER
 E-5458-1
 SIGNATURES
 PLANNER J. Clink
 Expeditor
 J. Clink
 PACKING INSPECTOR
 J. Clink
 QA RECORDS
 J. Clink

QTY	PURCHASE ORDER NO.	PART NUMBER/ DRAWING	REV	DESCRIPTION	QTY	CUSTOMER ID	PACKAGING	PARTS AND Pkg INSPECTOR
1	EMD	2074703 G01	6	Cart Seal Assy	1		039	GM
<p>Item 52 of General Assembly dwg. 1140921 G03, which consists of the following Seals and No. 2 Housing</p>								
1	EMD	5053066 G01	15	No. 2 Seal Ring	1		608	BIL
1	EMD	5053075 G02	15	No. 2 Seal Runner	1		608	BIL
1	EMD	1099105 G01	3	No. 3 Seal Ring	1		608	BIL
1	EMD	1741057 H02	13	No. 3 Seal Runner	1		608	BIL
1	EMD	5055024 G01	12	Seal Housing	1		608	BIL

WORKPLAN
 K-POSS79A-3
 945
 II - 277

0897270

98001023000

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting			
(d) Other Parts			

9. Hydrostatic test 3750 psi. (Pump Code Parts)

FILMED FROM BEST AVAILABLE COPY

CERTIFICATION OF DESIGN

Design information on file at Westinghouse Electro-Mechanical Division
 Stress analysis report on file at Westinghouse Electro-Mechanical Division
 Design specifications certified by Robert L. Sylvester (1) Prof. Eng. State PA Reg. No. 15441-B
 Stress analysis report certified by Dr. O. Hagen (1) Prof. Eng. State PA Reg. No. 09091-B
 (1) Signature not required. List name only.

We certify that the statements made in this report are correct.
 Date October 13 19 81 Signed Westinghouse Electro-Mechanical Division (Manufacturer)
 Certificate of Authorization No. N-1385 expires May 14, 1982

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of PENNSYLVANIA and employed by LUMBERMEN'S MUTUAL CASUALTY CO of LONG GROVE, ILLINOIS

Report on NOV. 3 19 74 have inspected the equipment described in this Data Report on NOV. 3 19 74, and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

CB Miller COMMISSIONS (INSPECTOR)

(NATIONAL BOARD, STATE, PROVINCE AND NO.)

Date OCT. 13 1981
 WITNESSED COMPLETED PUMP ASSEMBLY HYDROSTATIC TEST: 3136 psi, for 10 minutes.
 Westinghouse Representative Charles E. Rio Date 10-24-81

E. W. Madson (Inspector) 10-24-81 (Date) Commission 1105608 TA 692 (National Board, State, Province and No.)

PAGE 22 OF 187

98001023000

ATTACHMENT TO FORM NPV-1

Manufactured by Westinghouse Electro-Mechanical Division
Cheswick Avenue, Cheswick, Pa. 15024

Order No. U-363

Manufactured for Westinghouse--PWRSD
Monroeville, PA

Order No. 546-NRC-151972-3A

Drawing Number 114E921

Serial Number 2-114E921G01

National Board Number N/A

Component	Part Number	Material Spec. No.	Manufacturer	Serial Number(s)
1A Main Flange 1B Thermowell	929C354G 01 1306C07G 01	SA-351 Gr C78 SA-479 Type 304 & SA-213 Grade TP304	Esco Corp. Ionics	890 1530
2 Main Flange Bolts (24)	913C495G01	SA-540 Grade 324	J. Dyson	9005 9007 9008 8778 9083 9084 9086 9087 9088 9069 9064 9065 9070 9082 9083 9084 9086 9087 9081 9071 8779 9001 8777 9002
3 Lower Seal Housing Bolts (12)	4129A37H16	SA-194 Grade 87	Radform Tool	2473 2477 2478 2401 2399 2400 2397 2406 2407 2407 2459 2460
4 Upper Seal Housing Bolts (12)	4129A36H10	SA-193 Grade 37	Safety Socket	2111 2594 2201 2118 2597 2202 2567 2249 2100 2244 2089 2203

FILMED FROM BEST AVAILABLE COPY

65

PAGE 100

98001023000

ATTACHMENT TO FORM NPV-1

Page 2 of

Manufactured by Westinghouse Electro-Mechanical Division
Cheswick Avenue, Cheswick, Pa. 15024

Order No. U-363

Manufactured for Westinghouse--PWRSD
Monroeville, PA

Order No. 546-NRC-151972-BN

Drawing Number 114E921

Serial Number 2-114E921G01

National Board Number N/A

Component	Part Number	Material Spec. No.	Manufacturer	Serial Number(s)
5 Thermal Barrier	<u>510F365G01</u>	Not Applicable		
5A Flange	<u>510F 364G01</u>	SA-182 Grade 7 304	Standard Steel	<u>319</u>
5B Water Connection	<u>925B950G 02</u>	Not Applicable		
Flange	<u>955B758H 02</u>	SA-182 Grade 316	Western Forge	<u>2658 2656 26</u>
5B.2 Pipe	<u>925B950H 05</u>	SA-312 Grade Tp 305	Babcock & Wilcox	<u>2852 2853 28</u>
5C Pressure Tap	<u>925B949G</u>	Not Applicable		
5C.1 Flange	<u>955B798Z</u>	SA-182 Grade 316		<u>N/A</u>
5C.2 Pipe	<u>925B949H</u>	SA-312 Grade Tp 304		<u>N/A</u>
5C.3 Reducer	<u>955B799H</u>	SA-182 Grade 316		<u>N/A</u>

FILMED FROM BEST AVAILABLE COPY

6-k

98001023000

ATTACHMENT TO FORM NPV-1

Manufactured by Westinghouse Electro-Mechanical Division
Cheswick Avenue, Cheswick, Pa. 15024

Order No. U-363

Manufactured for Westinghouse--PWRSD
Monroeville, PA

Order No. 546-NRC-151972-8N

Drawing Number 114E921

Serial Number 2-114E921G01

National Board Number N/A

Component	Part Number	Material Spec. No.	Manufacturer	Serial Number
6 Lower Seal Housing (Spool)	933D313H03	SA-182 F304	Standard Steel	853
6A Thermowell	955B797H02	SA-479 Type 304	Simonds Steel	1579
6B No. 1 Leak Off Connection	913C741G02	Not Applicable	FILMED FROM BEST AVAILABLE COPY	
6B.1 Flange	955B758H02	SA-182 Grade 316	Western Forge	2562
6B.2 Pipe	913C741H05	SA-312 Grade Tp 304	Babcock & Wilcox	2893
6C Lift Off Connection	913C533G02	Not Applicable		
6C.1 Flange	955B756H02	SA-182 Grade 316	Western Forge	2815
6C.2 Pipe	913C533H05	SA-312 Grade Tp 304	Allegheny Ludlum	2754
7 Upper Seal Housing (Spool)	933D309H04	SA-182 F304	Standard Steel	374
7A No. 2 Leak Off Connection	929C852G04	Not Applicable		
7A.1 Flange	955B798H02	SA-182 Grade 316	Western Forge	2747
7A.2 Pipe	929C852H07	SA-312 Grade Tp 304	U.S. Steel	2899

67

98001023000

ATTACHMENT TO FORM NPV-1

Page 4 of 4

Manufactured by Westinghouse Electro-Mechanical Division
Cheswick Avenue, Cheswick, PA 15024 Shop Order 11-263
Manufactured for Westinghouse--PWRSD
Monroeville, PA Purchase Order 546-NRC-151972-

Drawing Number 114E921

National Board No. N/A

Serial No. 2-114E921G01

The following Reactor Coolant Pump Casing is covered by its own Manufacturers' Data Report (N-2 Form).

<u>Serial Number</u>	<u>Part Number</u>	<u>Manufacturer</u>
924	114E968H01	Esco Corp.

FILMED FROM BEST
AVAILABLE COPY

605

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 3-31-99
Name
400 W. Summit Hill Drive, Knoxville, TN
Address

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
P. O. Box 2000, Spring City, TN, 37381
Address

3. Work Performed by TVA MODIFICATIONS Type Code Symbol Stamp N/A
Name
WATTS BAR NUCLEAR PLANT
Address

Repair Organization P.O. No., Job No., etc. WORK ORDER 98-010243-003
 Authorization No. N/A
 Expiration Date N/A

4. Identification of system 06B-REACTOR COOLANT / 001 MAIN STEAM

5. (a) Applicable Construction Code ASCC 701 19 19 Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
STEAM GENERATOR BOLTS	NOVA	N/A	N/A	N/A	N/A	REPLACEMENT	NO

7. Description of Work REPLACE STEAM GENERATOR UPPER LATERAL RESTRAINT SPACE BOLTING

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Traction # 98-02-41 89 11/6/98
Applicable Manufacturer's Data Reports to be Attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp _____ N/A

Certificate of Authorization No. _____

Signed Howard A. Council CONST ENGR Date 31 MARCH 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TN and employed by HSRI & I Co. of Hartford, CT have inspected the components described in this Owner's Report during the period 11-10-98 to 4-1-99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions TN 2533
Inspector's Signature National Board, State, Province, and Endorsements

Date 4-1 19 99

DAOF 12500

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 4-1-99
Name
 400 W. Summit Hill Drive, Knoxville, TN
Address

2. Plant Watts Bar Nuclear Plant Sheet 1 of 2
Name
 P. O. Box 2000, Spring City, TN, 37381
Address

3. Work Performed by TVA MODIFICATIONS Unit Unit 1
Name
WATTS BAR NUCLEAR PLANT
Address

WORK ORDER 98-010243-001
Repair Organization P.O. No., Job No., etc.
 Type Code Symbol Stamp N/A
 Authorization No N/A
 Expiration Date N/A

4. Identification of system 068-REACTOR COOLANT / 001 MAIN STEAM

5. (a) Applicable Construction Code AISC ^{13TH} Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
STEAM GENERATOR BOLTS	NOVA	N/A	N/A	N/A	N/A	REPLACEMENT	NO

7. Description of Work REPLACED ONE BOLT FOR SG 2 UPPER LATERAL RESTRAINT SPLICE PLATE

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
 As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 3-31-99
Name
 400 W. Summit Hill Drive, Knoxville, TN
Address

2. Plant Watts Bar Nuclear Plant Sheet _____ of _____
Name
 P. O. Box 2000, Spring City, TN, 37381
Address

3. Work Performed by TVA MODIFICATIONS Unit Unit 1
Name
WATTS BAR NUCLEAR PLANT
Address

WORK ORDER 98-010243-000
 Repair Organization P.O. No., Job No., etc. _____
 Type Code Symbol Stamp N/A
 Authorization No. N/A
 Expiration Date N/A

4. Identification of system 06B-REACTOR COOLANT / 001 MAIN STEAM

5. (a) Applicable Construction Code AISC 19 70 Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>STEAM GENERATOR SUPPORT BOLTING</u>	<u>NOVA</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>REPLACEMENT</u>	<u>N</u>

7. Description of Work REPLACE UPPER STEAM GENERATOR LATERAL RESTRAINT SPACE BOLTING

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

PAGE 1 OF 187

FORM NIS-2 (Back)

9. Remarks TANKING # 22-02-44 dy 11/6/98
Applicable Manufacturer's Data Reports to be Attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/

Certificate of Authorization No. _____ A

Signed Hunt A. Cornell CONST ENGR Date 31 MARCH 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I & I CO. of HARTFORD CT. have inspected the components described in this Owner's Report during the period 11/10/98 to 4/1/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce M. Earnigh Commissions TN 2534 " I " " N " " A "
Inspector's Signature National Board, State, Province, and Endorsements

Date 4/1 19 99

172
 Page ~~47~~ F. 224
 MKS
 4.7.99

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
 As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 4-12-77
Name
400 W. Summit Hill Drive, Knoxville, TN Sheet 1 of 2
Address

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
P. O. Box 2000, Spring City, TN, 37381 WORK ORDER # 98-007950-000
Address Repair Organization P. O. No., Job No., etc.

3. Work Performed by TVA MODIFICATIONS Type Code Symbol Stamp N/A
Name WATTS BAR NUCLEAR PLANT Authorization No N/A
Address Expiration Date N/A

4. Identification of system 015, Steam Generator Blowdown

5. (a) Applicable Construction Code ASME III 19 71 Edition, S73 Addenda, N-416-1 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>1-PIPE-015-B</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>REPLACEMENT</u>	<u>No</u>

7. Description of Work Replaced piping section from 1-FCV-1-7 to 90 degree elbow upstream of 1-FE-1-152.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 1075 psi Test Temp 55.3 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

PAGE 110 OF 187

173
Page ~~168~~ 224
NKS
4-7-99

FORM NIS-2 (Back)

9. Remarks REF. CODE CASE N-416-1. TANK NO. * RA-22-45-2-710-22
Applicable Manufacturer's Data Reports to be Attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the repair or replacement rules of the ASME Code, Section XI.

Type Code Symbol Stamp NA 4-12-99

Certificate of Authorization No. NA 4-12-99

Signed George A. Wiley CONSTRUCTION ENGINEER Date 4-12 19 99
Owner, or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENNESSEE and employed by HJB I & C CO of HARTFORD CT. have inspected the components described in this Owner's Report during the period 11/10/98 to 4/12/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce M. Earnigh Commissions TN 2534 I N A
Inspector's Signature National Board, State, Province, and Endorsements

Date 4/12 19 99

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 4-12-99
Name
400 W. Summit Hill Drive, Knoxville, TN Sheet 1 of 2
Address

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
P. O. Box 2000, Spring City, TN, 37381 WORK ORDER # 98-007950-001
Address Repair Organization P. O. No., Job No., etc.

3. Work Performed by TVA MODIFICATIONS Type Code Symbol Stamp N/A
Name
WATTS BAR NUCLEAR PLANT Authorization No N/A
Address Expiration Date N/A

4. Identification of system 015, Steam Generator Blowdown

5. (a) Applicable Construction Code ASME III 19 71 Edition, 573 Addenda, N/A 288 6/18/99 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1-PIPE-015-B	N/A	N/A	N/A	N/A	N/A	REPLACEMENT	NO

7. Description of Work Replaced piping section from 1-FCV-1-1A to 90 degree elbow upstream of 1-FE-1-156

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 1074 psi Test Temp 553 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Ref. Code Case N-416-1, TRACK # F RR-02-46 Applicable Manufacturer's Data Reports to be Attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the repair or replacement rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A FRS 4-12-99

Certificate of Authorization No. N/A FRS 4-12-99

Signed [Signature] Date 4-12-1999
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HCB I&EC of Hartford CT. have inspected the components described in this Owner's Report during the period 11/10/98 to 4/12/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions TN 2534 "I" "N" "A"
Inspector's Signature National Board, State, Province, and Endorsements

Date 4/12 19 99

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 4-12-77
Name
400 W. Summit Hill Drive, Knoxville, TN Sheet 1 of 2
Address

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
P. O. Box 2000, Spring City, TN, 37381 WORK ORDER # 98-007950-002
Address Repair Organization P. O. No., Job No., etc.

3. Work Performed by TVA MODIFICATIONS Type Code Symbol Stamp N/A
Name Authorization No N/A
WATTS BAR NUCLEAR PLANT Expiration Date N/A
Address

4. Identification of system 015, Steam Generator Blowdown

5. (a) Applicable Construction Code ASME III 19 71 Edition. 573 Addenda. N/A 382 6/8/77 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989 N-416

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>1-PIPE-015-B</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>REPLACED</u>	<u>NO</u>

7. Description of Work Replaced piping section from 1-FCV-1- to 90 degree elbow upstream of 1-FE-1-16

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 1032 psi Test Temp 554 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

PAGE 118 OF 196

FORM NIS-2 (Back)

9. Remarks Ref. Code Case N-416-1. Tracking # 22-02-47
Applicable Manufacturer's Data Reports to be Attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the repair or replacement rules of the ASME Code, Section XI.

Type Code Symbol Stamp NA 28 1-12-77

Certificate of Authorization No. NA 28 1-12-77

Signed [Signature] CONSTRUCTION ENGINEER Date 4-12 19 77
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I & I CO. of HARTFORD CT. have inspected the components described in this Owner's Report during the period 4/10/93 to 4/12/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions TN 2534 "I" "N" "A"
Inspector's Signature National Board, State, Province, and Endorsements

Date 4/12 19 77

BACK

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 4-12-97
Name
 400 W. Summit Hill Drive, Knoxville, TN
Address Sheet 1 of 2

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
 P. O. Box 2000, Spring City, TN, 37381
Address **WORK ORDER # 98-007950-003**

3. Work Performed by TVA MODIFICATIONS Type Code Symbol Stamp N/A
Name Authorization No N/A
WATTS BAR NUCLEAR PLANT Expiration Date N/A
Address

4. Identification of system 015, Steam Generator Blowdown

5. (a) Applicable Construction Code ASME III 19 71 Edition, 513 Addenda, 1-2, 3, 6, 8, 9 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>1-PIPE-015-B</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>REPLACEMENT</u>	<u>NO</u>

7. Description of Work Replaced piping section from 1-FCV-1-32 to 90 degree elbow upstream of 1-FE-1-164.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 1075 psi Test Temp 553 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks

Ref. Code Case N-416-1. TRACING # PP-32-73

Applicable Manufacturer's Data Reports to be Attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp

U1/A

Certificate of Authorization No.

Signed

Harold A. Cornell CONST ENGR

Date

12 April 19 99

Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I & I CO of Hartford CT have inspected the components described in this Owner's Report during the period 11/10/98 to 4/12/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce M. Earnigh Inspector's Signature

Commissions

TN 2534

I N A

National Board, State, Province, and Endorsements

Date

4/12

19 99

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 4-4-99
Name
400 W. Summit Hill Drive, Knoxville, TN
Address
 Sheet 1 of 1

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
P. O. Box 2000, Spring City, TN, 37381
Address
WO# 98-007954-000
Repair Organization P. O. No., Job No., etc.

3. Work Performed by TVA MECH MCD 5 Type Code Symbol Stamp
Name
WATTS BAR NUCLEAR PLANT
Address
 Authorization No N/A
 Expiration Date N/A

4. Identification of system 003 - Feedwater

5. (a) Applicable Construction Code ASME III 19 71 Edition, 93 Summary Addenda, N/A Code Case
73 NRC 11-12-96 N/A 2/10/99
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>1-PIPE-003-B</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>REPLACEMENT</u>	<u>NO</u>
<u>1-C3A-498</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>REPLACEMENT</u>	<u>NO</u>
<u>1-C3A-499</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>REPLACEMENT</u>	<u>NO</u>
<u>1-C3A-500</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>REPLACEMENT</u>	<u>NO</u>

7. Description of Work Replace existing 6" φ Carbon Steel Piping with Chrome Moly.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Pressure _____ psi Test Temp _____ °F

NOTE: * SYSTEM LEAKAGE TEST DEFERRED TO 1-TRI-3-905 (WORK ORDER 98-015872-000) 4-5-99
 Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

PAGE 110 001

FORM NIS-2 (Back)

9. Remarks

CCDE CASE N-416-1

TRACKING # RR-02-49-201/16/99

Applicable Manufacturer's Data Reports to be Attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp

N/A

Certificate of Authorization No.

Signed

Kevin A. Conwell CONST ENGR

Date

5 APRIL 19 99

Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TN and employed by ASB I & C of Hartford, CT have inspected the components described in this Owner's Report during the period 11-17-98 to 4-5-99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature]
Inspector's Signature

Commissions

TN 2533

National Board, State, Province, and Endorsements

Date

4-5 19 99

BACK

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 4-5-99
Name
400 W. Summit Hill Drive, Knoxville, TN
Address

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
P. O. Box 2000, Spring City, TN, 37381
Address

3. Work Performed by TVA MODIFICATIONS Type Code Symbol Stamp
Name
WATTS BAR NUCLEAR PLANT
Address
 Repair Organization P. O. No., Job No., etc
WO# 98-007954-001
 Authorization No _____
 Expiration Date _____

4. Identification of system 003 - Feedwater

5. (a) Applicable Construction Code ASME III 19 71 Edition, ⁷³ ~~73~~ ¹¹⁻¹²⁻⁷⁶ ~~Summ.~~ Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No	National Board No	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1-PIPE-003-B	N/A	N/A	N/A	N/A	N/A	REPLACEMENT	NO
1-03A-374	N/A	N/A	N/A	N/A	N/A	REPLACEMENT	NO

7. Description of Work Replace existing 6" φ Carbon Steel Piping with Chrome Moly. REPLACED U-BOLT ON 1-03A-374 DUE TO DAMAGE DURING REMOVAL

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure *
 Other Pressure _____ psi Test Temp _____ °F
 * LEAKAGE TEST TO BE PERFORMED BY 1-TRI-3-905 (WORK ORDER 98-015872-000) ^{W/O 4-5-99}

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

W O 98-07954-01

PAGE 120 OF 125

FORM NIS-2 (Back)

9. Remarks

CODE CASE N-416-1

Applicable Manufacturer's Data Reports to be Attached

TRACKING # RR-02-44 11/4/99
50

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the repair or replacement rules of the ASME Code, Section XI.

Type Code Symbol Stamp

NII

Certificate of Authorization No.

A

Signed

Harold A. Curcell

Owner or Owner's Designee, Title

Date

5 APRIL

19 99

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TN and employed by HSBI-I Co. of Hartford, CT have inspected the components described in this Owner's Report during the period 11-17-98 to 4-5-99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature

Inspector's Signature

Commissions

TN 2533

National Board, State, Province, and Endorsements

Date

4-5

19 99

DATE OF

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 4-4-99
Name
400 W. Summit Hill Drive, Knoxville, TN
Address

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
P. O. Box 2000, Spring City, TN, 37381
Address

3. Work Performed by TVA MECH MCO'S Type Code Symbol Stamp WO# 98-007954-002
Name Repair Organization P. O. No., Job No., etc.
WATTS BAR NUCLEAR PLANT Authorization No N/A
Address EX 4-4-99
 Expiration Date _____

4. Identification of system 003 - Feedwater

5. (a) Applicable Construction Code ASME III 19 71 Edition, 73 Addenda, 73 Code Case
ASME III 73 73
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>1-PIPE-003-B</u>	<u>N/A</u>	<u>NONE</u>	<u>NONE</u>	<u>N/A</u>	<u>UNKN</u>	<u>REPLACEMENT</u>	<u>NO</u>

7. Description of Work Replace existing 6" φ Carbon Steel Piping with Chrome Moly.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure 688 psi
 Other Pressure 1185 psi Test Temp 600 °F

▲ LEAK TEST DEFERRED TO I-TRI-3-905 WO# 98-015872-000. WMS 4/5/99

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks

CODE CAGEN-416-1

TRACKING # RR-02-51

Applicable Manufacturer's Data Reports to be Attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the repair or replacement rules of the ASME Code, Section XI.

Type Code Symbol Stamp NS/A

Certificate of Authorization No. A

Signed George A. Kelly MECH FIELD ENGR Date 4-4 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TN and employed by HSEI & I Co. of Hartford, CT have inspected the components described in this Owner's Report during the period 11-17-98 to 4-5-99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions TN 2533
Inspector's Signature National Board, State, Province, and Endorsements

Date 4-5 19 99

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
 As Required by the Provisions of the ASME Code Section XI

1. Owner <u>TENNESSEE VALLEY AUTHORITY</u> <small>Name</small> 400 W. Summit Hill Drive, Knoxville, TN <small>Address</small>	Date <u>4/5/99</u> Sheet <u>1</u> of <u>2</u>
2. Plant <u>Watts Bar Nuclear Plant</u> <small>Name</small> P. O. Box 2000, Spring City, TN, 37381 <small>Address</small>	Unit <u>Unit 1</u> NO# <u>98-007954-003</u> <small>Repair Organization P. O. No., Job No., etc.</small>
3. Work Performed by <u>TVA, MODIFICATIONS</u> <small>Name</small> <u>WBNP</u> <small>Address</small>	Type Code Symbol Stamp _____ Authorization No <u>N/A</u> Expiration Date <u>N/A</u>

4. Identification of system 003 - Feedwater

5. (a) Applicable Construction Code ASME III 19 71 Edition, ^{T3 LXX 11-1276} ~~73 Summary~~ Addenda, ^{NA 270 4/5/99} ~~1-416~~ Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989 ▲ AISC 7TH EDITION FOR PIPE SUPPORTS

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>1-PIPE-003-B</u>	<u>N/A</u>	<u>NONE</u>	<u>NONE</u>	<u>N/A</u>	<u>UNKNOWN</u>	<u>REPLACEMENT</u>	<u>NO</u>
<u>47A400-11-34</u>	<u>N/A</u>	<u>NONE</u>	<u>NONE</u>	<u>DCA-M19875-06</u>	<u>UNKNOWN</u>	<u>REPAIR</u>	<u>NO</u>
<u>1-01A-339</u>	<u>N/A</u>	<u>NONE</u>	<u>NONE</u>	<u>DCA-K06011-27</u>	<u>UNKNOWN</u>	<u>REPLACEMENT</u>	<u>NO</u>

7. Description of Work Replace existing 6" φ Carbon Steel Piping with Chrome Moly. CUT SUPPORTS AND REINSTALLED TO ALLOW FOR PIPING MOVS.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure *
 Other Pressure _____ psi Test Temp _____ °F
 * SYSTEM LEAKAGE TEST DEFERRED TO TRI-3-905 (NO# 93-015872-000)

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

4/5/99

FORM NIS-2 (Back)

9. Remarks CODE CASE N-416-1 TRACKING # RR-02-52 2/11/99
Applicable Manufacturer's Data Reports to be Attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/

Certificate of Authorization No. A

Signed M. R. Dodel CONST. ENGR Date 4/5 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TN and employed by HSBI + I Co. of Hartford, CT have inspected the components described in this Owner's Report during the period 11-17-98 to 4-5-99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions TN 2533
Inspector's Signature National Board, State, Province, and Endorsements

Date 4-5 19 99

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
 As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 1-22-99
 Name
 400 W. Summit Hill Drive, Knoxville, TN

2. Plant Watts Bar Nuclear Plant Sheet _____ of _____
 Address
 Name
 P. O. Box 2000, Spring City, TN, 37381 Unit Unit 1

3. Work Performed by Mech Maint WBNP Repair Organization P.O. No., Job No., etc.
 Name
 P.O. Box 2000 Type Code Symbol Stamp 97-14576-00
 Address Authorization No. AK 7-22-99
 Expiration Date _____

4. Identification of system CVCS

5. (a) Applicable Construction Code ASME sect III 19 74 Edition, Summer Addenda, NA 288 6/2/99
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1974 1989 2 Code Case

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
EXCESS LETDOWN HEAT EXCHANGER	ATLAS MANUFACTURING COMPANY	3151	2529	ATR-62-0121	1975	Replacement	
STUDS SA 453 GR 660	NOVA	NA	NA	HT. NO. 523914	99	Replacement	NO
NUTS	CARDINAL	NA	NA	HT. NO. 8869139	94	Replacement	NO
NUTS	NOVA	NA	NA	HT. NO. 49419	99	Replacement	NO
Super bolt NUT	NOVA	NA	NA	LOT NO. 35677029	98	Replacement	NO

7. Description of Work Replace Existing Heat Exchanger Head Flange ~~Bolt~~ Studs, NUTS WITH NEW STUDS, NUTS

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure & Other Pressure NOP psi Test Temp NOT °F
2230 557

Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks

RR TRACKING # RR-02-59 2001/2/99

Applicable Manufacturer's Code Reports to be Attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NA

Certificate of Authorization No. NA

Signed D. H. Collins Mech Eng. Date 4/30 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I & I Co. of HARTFORD CT. have inspected the components described in this Owner's Report during the period 1/22/99 to 5/13/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce M. Earnigh
Inspector's Signature

Commissions TN 2534 "I" "N" "A"
National Board, State, Province, and Endorsements

ate 5/13 19 99

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
 As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 08/25/98
Name
400 W. Summit Hill Drive, Knoxville, TN
Address

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
P. O. Box 2000, Spring City, TN, 37381
Address

3. Work Performed by WATTS BAR NUCLEAR PLANT Type Code Symbol Stamp NA
Name
P.O. Box 2000, Spring City, TN, 37381
Address
 Repair Organization P. O. No., Job No., etc. NO. # 97-001929-012
 Authorization No. NA
 Expiration Date NA

4. Identification of system CB7 (ESSENTIAL RAD COOLING WATER SYSTEM)

5. (a) Applicable Construction Code sect. III, Div. I 1977 Edition, 1977 Addenda, Summary 1977 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No	National Board No	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>SWIRL CHECK VALVE</u>	<u>ALCOA</u>	<u>12-14735-02</u>	<u>N/A</u>	<u>1 CV 07 530C-A</u>	<u>81</u>		<u>YES</u>
<u>Disc</u>	<u>"</u>	<u>"</u>	<u>"</u>	<u>"</u>	<u>81</u>	<u>Replaced</u>	<u>N</u>
<u>NA</u>							

7. Description of Work Replace Disc

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure VT-2
 Other Pressure NOT psi Test Temp NOT °F EXAM

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

Handwritten initials/signature

970019,29012

FORM NIS-2 (Back)

9. Remarks

ADDRESS MANUFACTURER'S CASE RECORDS TO BE ATTACHED

TRACKING# RR-02-61 ^{2/17} 2/17

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the repair or replacement rules of the ASME Code, Section XI.

Type Code Symbol Stamp None

Certificate of Authorization No. NA

Signed D. H. Collins Mech Engr Date 3/23 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TN and employed by ASB I + I Co. of Hartford, CT have inspected the components described in this Owner's Report during the period 2-3-99 to 3-23-99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions TN/2533
Inspector's Signature National Board, State, Province, and Endorsements

Date 3-23 19 99

97001929012

1. Manufactured by Armstrong Fluid Control Co. Inc.
 (Name and Address of Manufacturer)
 2. Manufactured for Tennessee Valley Authority, Chattanooga, TN
 (Name and Address of Purchaser or Owner)
 3. Location of Installation Watts Bar Nuclear Plant, Spring City, TN
 (Name and Address)
 4. Pump or Valve Valve Nominal Inlet Size 2 Outlet Size 2
 (Inch) (Inch)

(a) Model No. (b) N Certificate Holder's (c) Canadian
 Series No. Serial Registration (d) Drawing (e) Nat'l. (f) Year
 or Type No. No. No. No. Bd. No. Built

(11) 2" Swing 1-14735-02 N/A 14735-02 2 N/A 1981
 (12) Check Valve thru Rev. 1
 (13) 8-14735-02

WJ860774K0698 (2)

(14) _____
 (15) _____
 (16) _____
 (17) _____
 (18) _____
 (19) _____
 (20) _____

Contract No. 827840-2
 R.D. or S.I. No. _____
 209 No. 81-3241

5. ERCW Containment Isolation
 (Brief description of service for which equipment was designed)

6. Design Conditions 160 psi 130 °F or Valve Pressure Class N/A (1)
 (Pressure) (Temperature)

7. Cold Working Pressure 475 psi at 100°F.
 8. Pressure Retaining Pieces

FILMED FROM BEST AVAILABLE COPY

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
Body	SA 351 CF8M	Lebanon Steel Foundry	S/N 1-14735-02
Mr. # 5576L			S/N 8-14735-02
Disc	SA 351 CF8M	Quaker Alloy Casting Co.	S/N 1-14735-02
Mr. # X2937		thru	S/N 8-14735-02
(b) Forgings			
N/A			

(1) For manually operated valves only.

* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2" x 11" (2) information on items 1, 2 and 5 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

1999-27873
Page 12 of 13

(10/77)

This form (E00037) may be obtained from the Order Dept., ASME, 345 E 47th St., New York, NY 10017

(c) Detailing			
Seeds	SA 193 Gr. 8Z		
Nuts	SA 194 Gr. 2H	3.0.0. Corp.	
(d) Other Parts			
Cover	SA 240 Gr. 316	Eastern Stainless Steel Co. (M.M.)	S/N 1-14735-02
Hc. # K03468			enru
Hc. # K07884		Industrial Service Center (M.S.)	S/N 8-14735-02

FILED FROM BEST AVAILABLE COPY

B. Hydrostatic test 740 psi. Obs. Differential test pressure 540 psi.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. 1, Edition 1977

Addenda Summer 1979 (Date), Code Case No. N/A, Addenda N/A

Signed Arwood & Moccill Co, Inc by [Signature] 8/25/81
(In Certificate required)

Our ASME Certificate of Authorization No. N-1766 to use the H symbol expires 5-20-83
(Date)

CERTIFICATION OF DESIGN

Design information on file at Tennessee Valley Authority
Stress analysis report (Class 1 only) on file at N/A

Design specifications certified by (1) Ivan Lee Baltz
PE State TN, Reg. No. 9702

Stress analysis certified by (1) N/A
PE State N/A, Reg. No. N/A

(1) Signature not required. List name only.

Contract No. 9-27840-2
R.D. or S.T. No.
209 No. 81-3241

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Massachusetts and employed by M.S.E.I. S.I. of Haverford, PA have inspected the pump, or valve, described in this Data Report on August 25 19 81, and state that, to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date August 25 19 81 1999-27873
[Signature] (Inspector) Commissions [Signature] 1986 Exp. 12.5.13
(Natl Bd. State Pro. on Reg.)

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY
Name
 400 W. Summit Hill Drive, Knoxville, TN

Date 3/23/99

Sheet 1 of 2

2. Plant Watts Bar Nuclear Plant
Address
Name
 P. O. Box 2000, Spring City, TN, 37381

Unit Unit 1

WORK ORDER # 98-002218-001

3. Work Performed by TVA, MODIFICATIONS
Address
Name
WBNP
Address

Repair Organization P.O. No., Job No., etc.
 Type Code Symbol Stamp N/A

Authorization No N/A

Expiration Date N/A

4. Identification of system 068 REACTOR COOLANT SYSTEM

5. (a) Applicable Construction Code ASME III 1971 Edition, 573 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1068-1-68-415	NONE	NONE	NONE	1-68-415 SUITS. ITWEL 6	UN KNOWN	REPLACEMENT	NO

7. Description of Work REPLACED (4) BOLTS AND (8) NUTS ON PIPE CLAMP.
HGR. 1068-1-68-415

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks

Applicable Manufacturer's Data Reports to be Attached

TRACKING # RR-02-8622C 3/11/99

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No.

Signed Wif Rogus, CONSTR. ENGR. Date 3-23 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I&I CO. of HARTFORD CT. have inspected the components described in this Owner's Report during the period 3/11/99 to 3/24/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce M. Earnigh Commissions TN 2534 "I" "N" "A"
Inspector's Signature National Board, State, Province, and Endorsements
Date 3/24 19 99

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
 As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY
 Name
 400 W. Summit Hill Drive, Knoxville, TN
 Address

Date 3-9-99

2. Plant Watts Bar Nuclear Plant
 Name
 P. O. Box 2000, Spring City, TN, 37381
 Address

Sheet _____ of _____

Unit Unit 1

3. Work Performed by Mech MAINT WBNP
 Name
 P.O. Box 2000 Spring City TN 37381
 Address

WO# 98-002441-003

Type Code Symbol Stamp N/A
Repair Organization P.O. No., Job No., etc.

Authorization No N/A

Expiration Date N/A

4. Identification of system MAin STEAM

5. (a) Applicable Construction Code ASME Section III 1971 Edition, Summer 1973 Addenda. N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
STEAM Generator Secondary Manway Cover	Westinghouse	1594	W10289	1-SGEN-068-SG4	75	Repair	NO
STEAM Generator Secondary m/w Cover	Westinghouse	1594	W10289	1-SGEN-068-SG4	75	Repair ^{see 3/18/99}	NO
SG Second. m/w COVER STUDS	WESTINGHOUSE	NONE	NA	1-SGEN-068-SG4		Replace	NO
NUTS	Westinghouse	NONE	NA	1-SGEN-068-SG4		Replace	NO

7. Description of Work Repair secondary manway cover by Maching Cover per ME-3.018
Replaced Cover with COVER FROM UNIT 2

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other Pressure NOP psi Test Temp NOT °F 1-TRI-3-903

E: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

RI

FORM NIS-2 (Back)

9. Remarks

TRACKING # RR-02-07 2/6/99

REPAIRED 1 S/A COVER, Replaced one Cover And Studs

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPAIR / REPLACEMENT conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp NONE

Certificate of Authorization No. NA

Signed DH Collins Mech Engr. Date 4/11 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I & I CO. of HARTFORD CT. have inspected the components described in this Owner's Report during the period 3/11/99 to 5/26/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bence M Earnigh
Inspector's Signature

Commissions TN 2534 "I" "N" "A"
National Board, State, Province, and Endorsements

ate 5/26/ 19 99

FORM 1 - COVER SHEET
QA RECORD

PEO PKG NO: 1999-42380
PAGE 1 OF 12

RIMS/EDMS NO: T49 990329 810		REV NO: 0
SUPERSEDED RIMS/EDMS NO:		QA LEVEL: 1
TRACKING NO: 199900042380		
REASON FOR REVISION: INITIAL ISSUE		
SUBJECT: U2-U1 TRANSFER OF SECONDARY MANWAY COVER		
REFERENCE: APPENDIX A - REQUEST FOR REMOVAL - TRK. NO. 2-068-041, ER# 03-99-011		
PREPARED BY: PEO ENGINEER: BRYAN, DARYL	<i>Daryl Bryan</i>	DATE: 3-29-99
REVIEWED BY: INDEPENDENT REVIEWER: McCORD, LARRY	<i>Larry McCord</i>	DATE: 3-29-99
APPROVED BY: PROCUREMENT ENGINEERING LEAD: BENNINGHOFF, H. N.	<i>Henry Benninghoff</i>	DATE: 3-29-99

- DISTRIBUTION:
- RIMS/EDMS
 - MATERIAL & PROCUREMENT
 - NUCLEAR PROCUREMENT
 - NUCLEAR STORES

Secondary Manway Cover

For S/A NO. 4.

FORM 2 - TECHNICAL EVALUATION

PEG PKG NO: 1999-42380

PAGE 2 OF 12

<p>If the component is uniquely addressed in ME/NE output documents (ie Design Change Package, Q-spec, EMS Q-List) or is a whole component, complete HOST EQUIPMENT/COMPONENT DATA and N/A ITEM DESCRIPTION & ITEM FUNCTION</p>	
<p>HOST EQUIPMENT/COMPONENT (WORST CASE) UNID NO: WBN-1-SGEN-068-SG4 -</p>	<p>HOST EQUIPMENT/COMPONENT TIC NO: CAN276V</p>
<p>HOST EQUIPMENT/COMPONENT (WORST CASE) DESCRIPTION: STEAM GENERATOR 4</p>	
<p>HOST SAFETY CLASSIFICATION:</p> <p> <input checked="" type="checkbox"/> SAFETY RELATED <input type="checkbox"/> NON-QUALITY RELATED <input type="checkbox"/> QUALITY RELATED <input checked="" type="checkbox"/> SEISMIC I <input type="checkbox"/> SEISMIC I(L) <input type="checkbox"/> PAM <input type="checkbox"/> CLASS 1E <input checked="" type="checkbox"/> ASME SEC III CLASS: 1 <input type="checkbox"/> 10 CFR 50.49 EQ BINDER NO: N/A REV: N/A </p>	
<p>BASIS FOR SAFETY FUNCTION CLASSIFICATION: EMPAC (MEL) VERIFIED</p>	
<p>REFERENCES: (TVA dwgs, Q-list, system criteria, etc) N/A</p>	
<p>ITEM(S) DESCRIPTION: SECONDARY MANWAY COVER</p>	
<p>ITEM DESIGN FUNCTION(S): (Including Known Safety Function) N/A</p>	

FORM 2A - TECHNICAL EVALUATION

PE: PKG NO: 1999-42380

PAGE 3 OF 12

ITEM CLASSIFICATION BASED ON FUNCTION:	
<input checked="" type="checkbox"/>	SAFETY RELATED PROVIDE BASIS IF PROCURING AS COMMERCIAL GRADE
<input type="checkbox"/>	NOT SAFETY RELATED PROVIDE BASIS ONLY IF HOST IS SR
POSTULATED FAILURE MODE(s) OF ITEM: N/A	
EFFECTS OF POSTULATED FAILURE(s) ON COMPONENT SAFETY FUNCTIONS: N/A	
CONCLUSION AND BASIS FOR ITEM CLASSIFICATION: N/A	
REFERENCES: N/A	
ITEM SEISMIC REQUIREMENT:	<input checked="" type="checkbox"/> SEISMIC I <input type="checkbox"/> SEISMIC I(L) <input type="checkbox"/> N/A
REMARKS: LIKE FOR LIKE REPLACEMENT	
ITEM IS SAFETY RELATED, AND	
<input checked="" type="checkbox"/>	WILL BE PROCURED AS SAFETY RELATED - PROCURE ITEM QA LEVEL 1
<input type="checkbox"/>	WILL BE PROCURED AS COMMERCIAL GRADE - PROCURE ITEM QA LEVEL 2
OR	
ITEM IS NOT SAFETY RELATED, AND	
<input type="checkbox"/>	IS PART OF A SAFETY RELATED COMPONENT OR IS A QUALITY RELATED ITEM WITH UNIQUE ENGINEERING OR REGULATORY REQUIREMENTS OR IS ADDRESSED IN SITE PROCEDURES OR NE OUTPUT DOCUMENTS AS QA LEVEL 3 - PROCURE ITEM QA LEVEL 3
<input type="checkbox"/>	DOES NOT MEET QA LEVEL 3 REQUIREMENTS - PROCURE AS QA LEVEL 0

1. Manufactured by Westinghouse Electric Corporation, Tampa Division, Tampa, FL
(Name and Address of Manufacturer)

2. Manufactured for Tennessee Valley Authority Watts Bar #2 Spring City
(Name and Address of Purchaser)

3. Type Vertical Kind Steam Gen Vessel No. (1617) () ()
(Horiz. or Vert.) (Tank, Jacketed, Heat Ex.) (Mfr. Serial No.) (State & State No.)
Nav'l Bd. No. W10795 Yr. Built 1973

3a. Applicable ASME Code: Section III, Edition 1973, Addenda date W71, Case No. 1493-1 146
Class 1 1355

Items 4-8 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers.

4. Shell: Material SA-533 GR A CL2 S Nominal Thickness 90000 in. Allowance 06 in. Dia. ft. in. Length ft. in.

5. Seams: Long Weld-Dbl-Butt H.T. Yes R.T. Complete Efficiency 100 %
Girth Weld-Dbl-Butt H.T. Yes R.T. Complete No. of Courses *

6. Heads (a) Material SA-533 GR A CL2 T.S. 90000 (b) Material - T.S. -

Location (Top, bottom, ends)	Thickness	Crown Radius	Kauckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (Convex or Concave)
(a) Top	3.82			2:1				CONCAVE
(b)								

If removable, bolts used _____ (Material, Spec. No., T.S., Size, Number) Other fastening _____ (Describe or attach sketch)

7. Assy Closure Girth Weld-Dbl-Butt H.T. X.R. complete
Girth Weld (Describe or give dia., etc., but give dimensions, describe or sketch)
Drop Weight Pneumatic
Charpy Impact 30 ft-lb Hydrostatic or } Test
Pressure 1482 psi

8. Design Pressure 1185 psi at 600 °F at temp. of +10 °F. Combination } Test Pressure 1482 psi

Items 9 and 10 to be completed for tube sections.

9. Tube Sheets: Stationary. Material SA-508 CL2 Dia. 125.75 in. Thickness 2.03 in. Attachment SAE Flange 12
(Kind & Spec. No.) (Subject to Part 13) (Welded, Bolted)

Floating. Material _____ Dia. _____ in. Thickness _____ in. Attachment _____

10. Tubes: Material SB-163 O.D. 750 in. Thickness .043 inches gauge _____ Number 6674 Type U
(Kind & Spec. No.) (Straight or U)

Items 11 to 14 incl. to be completed for Primary Chamber

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.

12. Seams: Long Weld-Dbl-Butt H.T. Yes R.T. Complete Efficiency 100 %
Girth Weld-Dbl-Butt H.T. Yes R.T. Complete No. of Courses 2*

13. Heads: (a) Material _____ T.S. _____ (b) Material WCC T.S. 70000 (c) Material _____ T.S. _____

Location	Thickness	Crown Radius	Kauckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (Convex or Concave)
(a) Top, bottom, ends								
(b) Channel	5.09					62.81		CONCAVE
(c) Floating								

If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____ (Describe or attach sketch)

14. Design pressure 2485 psi at 650 °F at temp. of +10 °F. Combination } Test Pressure 3106 psi

See Dwg. 1101J50

* If Postweld Heat-Treated
* List other internal or external pressures with coincident temperature when applicable.

1999-42380
Page 6 of 12

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____

16. Nozzles:

Purpose (Inlet, Outlet, Drain)	Number	Dia. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
Prim. Inlet	1	31" I.D.	(Weld)	(SA-216)	3.00"	(SA-216)	(Integrally)
Prim. Outlet	1	31" I.D.	(Weld)	(OR WCC)	3.00"	(OR WCC)	(Case)
Steam Outlet	1	29" I.D.	(Weld)	(SA-508)	1.31"	Steel	Welded
Feedwater	1	14" I.D.	(Weld)	(C-2)	0.76"	Steel	Welded

17. Inspection Manholes, No. 4 Size 16" Location (2) Chamber & (2) Upper Shell
 Openings: Manholes, No. 2 Size 6" Location South Barrel Portion of Lower Shell
 Instrumentation No. 4 Size 2" Location South Barrel Portion of Lower Shell

18. Supports: Skirt No. _____ Lugs _____ Legs _____ Other X Attached See Below
 Four Main Supports are cast integral with the chamber (Where is How)

19. Remarks: This N-1 Form is to be signed off by the authorized code inspector under certificate of shop inspection for everything listed except the hydrostatic test and subsequent inspection. Field inspector must sign off for the latter items on certificate of field assembly inspection below. All other Mfg. is specified on Manufacturers' Partial Data Forms N-2 filed at Westinghouse. See Supplement #1 & 2 for field installation of the v.v. No. 100 inspection openings

CERTIFICATION OF DESIGN

Design information on file at Westinghouse Electric Corporation, Tampa Division, Tampa, FL
 Stress analysis report on file at Westinghouse Electric Corporation, Tampa Division, Tampa, Fla.
 Design specifications certified by Nuclear Energy Systems Prof. Eng. State Fla. Reg. No. 13335-E
 Stress analysis report certified by Westinghouse - Tampa Plant Prof. Eng. State Fla. Reg. No. 18684

We certify that the statements made in this report are correct and that this nuclear vessel conforms to the rules of construction of the ASME Code, Section III.
 Date October 31, 19 75 Signed Westinghouse Elec. Corp by [Signature]
 (Manufacturer)

Certificate of authorization Expires June 16, 1978 Certificate of Authorization No. N-1154

CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY Westinghouse Electric Corporation in Tampa, Fla.
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Pennsylvania and employed by Lehigh Valley Quality Control, Inc.
 have inspected the pressure vessel described in this Manufacturer's Data Report on October 12, 1975, and state that to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with the ASME Code, Section III.
 By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date November 3, 19 75
 Inspector's Signature [Signature] Commission National Board 2592
 National Board, State, Province and No.

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____ of _____
 have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer has constructed and assembled this pressure vessel in accordance with the ASME Code, Section III. The described vessel was inspected and subjected to a hydrostatic test and/or Pneumatic Test of psig Primary Side & psig Secondary Side.
 By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date _____ 19 _____
 Inspector's Signature _____ Commission _____
 National Board, State, Province and No.

Printed in U.S.A. (7/71) This form (E38) is obtainable from the ASME, 345 E. 47th St., New York, N.Y. 10017

**Stress Report will be on file before time of Field Hydro.
 Stress Report completed: December 1977.

1999-42380
 Page 7 of 12

PAGE 136 OF 187

SUPPLEMENT NO.

Form N-1 Manufacturer's Data Report for Nuclear Vessels

- 1. Manufactured by Westinghouse Electric Corporation, Tampa Division, Tampa, Florida
- 2. Manufactured for Tennessee Valley Authority - Watts Bar #2 - Spring City, TN
- 3. Type Vertical Kind Steam Generator Series D Vessel No. 1612
 National Board No. W10795 Year Built 1975

A field change was made to the steam generator under the supervision and control of Westinghouse Tampa Division by extension of the Tampa Division Certificate of Authorization as authorized by the ASME, Jurisdictional Authority of the State of Tennessee, the owner Tennessee Valley Authority and the Authorized Inspection Agency.

The change consisted of the installation of an auxiliary feedwater nozzle through the upper shell of the steam generator and the connecting of internal piping by weldment. The change was made in accordance with Westinghouse Tampa Division procedure RE-76-13 Rev. 6 and installation drawing 1104J43 Chg. 2. Change design information and stress analysis report are on file at Westinghouse Tampa Division, Tampa, Florida.

We certify that the statements made in this report are correct and that the design and installation of the auxiliary feedwater nozzle conforms to the rules of construction of the ASME Code, Section III.

Date Sept. 12, 1978 Signed Westinghouse Electric Corp. By R.P. Wedler
 Certificate of Authorization expires June 16, 1981
 Certification of Authorization No. N-1154

This supplement is signed by the Field Authorized Nuclear Inspector indicating acceptance of the field change work with exception of the hydrostatic test and subsequent inspection. Acceptance of the latter items will be indicated by the ANI signature of the Form N-1 Certificate of Field Assembly Inspection.

CERTIFICATE OF FIELD INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Tennessee have inspected the change described in this supplement and state that to the best of my knowledge and belief, the change to this pressure vessel conforms to the rules of construction of the ASME, Section III.

By signing this Certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the alteration described in this supplement. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date Sept. 12 19 78 Signed C. E. Matcalfe Commission NB-6260, TN-2196
 Inspector C. E. Matcalfe State or National Board

1999-42380
 Pgs 8 of 12

FORM 4 - OTHER EVALUATIONS

PEG PKG NO: 1999-42380

PAGE 4 OF 12

EVALUATION FOR: This form shall not be used to document Equivalency Evaluations that conflict with Design Output Documents.		
<input type="checkbox"/>	QA LEVEL CHANGE	<input type="checkbox"/> 10CFR50.49
<input type="checkbox"/>	TIC DESCRIPTION CHANGE	<input type="checkbox"/> AFFECTS OF SPECIFICATION CHANGE
<input type="checkbox"/>	PART NO. CHANGE (ADMIN ONLY)	<input type="checkbox"/> SHELF LIFE EXTENSION
<input checked="" type="checkbox"/>	OTHER: U2-U1 TRANSFER	
PURPOSE: EVALUATE U2 TRACKING # 2-068-041, ER# 03-99-011		
ASSUMPTIONS: NONE		
ANALYSIS: THE SECONDARY MANWAY COVER FOR U2 STEAM GENERATOR NO. 3 (S/N 1612) WAS SUPPLIED BY WESTINGHOUSE ON CONTRACT 5414-1 WITH THE STEAM GENERATOR. WESTINGHOUSE HAD AN APPROVED QA PROGRAM AT THE TIME OF PROCUREMENT AND IT WAS BEFORE THE INCEPTION OF PART 21. AFTER REVIEWING THE CONTRACT, DOCUMENTATION AND RECEIVING REPORT THE COVER IS ACCEPTABLE FOR TRANSFER TO U1. TRACEABILITY IS MAINTAINED BY THE S/N OF THE STEAM GENERATOR. U2 LOCATION IS ACCEPTABLE FOR REQUIRED LEVEL C STORAGE FOR THE COVER AND S/L DOES NOT APPLY TO THIS ITEM BECAUSE IT'S METALLIC. AN NER SEARCH TURNED UP NO FINDINGS APPLYING TO THIS ITEM ON WESTINGHOUSE MODEL D GENERATORS.		
CONCLUSION: THE ITEM IS ACCEPTABLE FOR TRANSFER TO U1 LOCATION AS ORIGINALLY PROCURED.		

TVAN STD 10.5

199900042380

APPENDIX A
REQUEST FOR REMOVAL

TO: Procurement Engineering Group Manager, ME 1C-WBN FAX: 365-3233

FROM:

SUBJECT: REQUEST FOR INSTALLED UNIT 2 NON-TRANSFERRED COMPONENTS

The following components are required to support WBN U1 operation. Research has determined that it is in WBN's best interest to utilize WBN Unit 2 items. Please provide a PEG evaluation of the intended use or acceptable alternatives.

Unit 2 Request Tracking Number: ER 03-99-012 2-068-041

1. Activity being supported: WO 98-002441-003

2. Installing WID (s): WO 98-002441-003

3. Need Date: 3/28-29/99

4. Request Unit 2 Component ID's: 2-SGEN-068-SG3 SIN 1612

4A. Is requested component/part currently in the active U2 PM Program?

Yes: No: X Date the last PM was Performed: NR

5. Part Names/Numbers/Descriptions: SECONDARY MANWAY COVER

6. Contract Numbers: 5411401

7. Affected Unit 1 Component ID's: 1-SGEN-068-SG4

8. Description of work: SECONDARY MANWAY COVER FROM LOOP NO. 3

MANWAY. MANWAY COVER MUST BE FROM LOOP 3

8A. Replace parts required to be ordered: Yes: No: X

PR No. :
9. 50.49: QR: SR: X ASMS: X Non-QA:

MET/D.H. COLLINS/3-28-99/8871 [Signature] 3/28/99
Requesting Org/Name/Date/Ext Requesting Org Manager/ Date

Original: Procurement Engineering Group
cc: Modifications Superintendent, FAX 365-2058
Nuclear Engineering
Site Controller ADM 1C, Fax 365-3888

CN-1

CN-1

CN-1

*** REQUIRED FOR RFO2

1999-42380
Page 5 of 12




QUALITY RELEASE

TAMPA DIVISION

OR 25374

LOCATION OF DIVISION

DATE	ISSUE NO.	PART NO.	NO. OF COPIES	NO. RELEASED
03-29-99	423-551A	Model "B" Steam Generator Serial # 1612	1	1
REV. DATE	REV. NO.	REV. BY	REV. BY	REV. BY
ISSUE NO.	ISSUE NO.	ISSUE NO.	ISSUE NO.	ISSUE NO.
ISSUE NO.	ISSUE NO.	ISSUE NO.	ISSUE NO.	ISSUE NO.



AUDIT CHECKLIST

<input type="checkbox"/>	_____
<input type="checkbox"/>	_____
<input type="checkbox"/>	_____
<input type="checkbox"/>	_____
<input type="checkbox"/>	_____
<input type="checkbox"/>	_____
<input checked="" type="checkbox"/>	Cleanliness _____
<input checked="" type="checkbox"/>	Tagging _____
<input checked="" type="checkbox"/>	Code Form <u>See RAN 002174</u>
<input type="checkbox"/>	_____
<input type="checkbox"/>	_____

ISSUING OFFICE AND RELEASED AREA CONTAINED HEREIN APPROVED BY THE REGIONAL WESTINGHOUSE ENGINEER UNLESS A SPECIFIC EXCEPTION IS STATED.

Approved Deviations - See RAN 002174

1. See RAN 002174
2. See RAN 002174

Signature

199900042383

9900095218

Pg 10 of 12

Pg 6 of 8

It is certified that the customer's requirements have been met. Approved deviations, if any, are listed above.

Signature: [Signature] TITLE: QA Engineer DATE: 10/13/99

WESTINGHOUSE MATS BAR SITE 423 365 551A 09-22-1997 10:47 P.03

WESTINGHOUSE ELECTRIC CORP.

WBNP76-3046

WESTINGHOUSE ELECTRIC CORP.

WBNP, C.W.

CONTRACT NO.
71062-54114-1
AG. NO. AND DATE

TAMPA, FL

BARGE UNION MECHLING 4501

GROSS WEIGHT
700 TONS APP.

BARGE

ACCOUNT NO.
N030-321-39-0

COMPLETE

1108 - PARTIAL

FINAL

POINT ITEM NO.	ARTICLES OR SERVICES	CLASS, BIN OR STOCK NO.	QUAN. REQD.	UNIT	UNIT PRICE	AMOUNT
	PERMANENT MATERIAL REF. NO. KVMU-888	THE ITEMS ON THIS FORM DO NOT MEET THE TECHNICAL REQUIREMENTS OF THIS CONTRACT INsofar AS CAN BE DETERMINED AT THIS TIME AND ARE APPROVED FOR FIELD USE SIGNED: _____ TITLE _____ DATE _____				
5A	P.O. 546 GRW 121928B, S.O. WBT-120, UNIT 2, SPIN WBT-ROPSOG, FOR STEAM GENERATORS (1) MODEL "D" ONE PIECE STEAM GENERATOR #1, SERIAL #1611, DNG. 1100J81, SUB. 5, E SPEC 679059, REV. 2		1	EA		RIVER DOCK
	OCR #25373, NCR #179, I&T RELEASE #4CH (10-14-75)					
	(2) MODEL "D" ONE PIECE STEAM GENERATOR #2 SERIAL #1612, DNG. 1100J81, SUB. 5, E SPEC 679059, REV. 2,		1	EA		"
	OCR #25374, I & T RELEASE #4CH (10-14-75) NCR #180					
	CC: PARRIS MATHIESON					

Carrier's Charges 199900042380

NS P 11 OF 12

Truck	Custom Carrier	Other																	
<table border="1"> <tr> <th>Loc</th> <th>Loc</th> <th>Per</th> </tr> <tr> <td>Air</td> <td>SEA</td> <td>UPS</td> </tr> <tr> <td></td> <td></td> <td></td> </tr> </table>	Loc	Loc	Per	Air	SEA	UPS				<table border="1"> <tr> <th>Service</th> <th>Master</th> <th>Rate</th> <th>Pass</th> </tr> <tr> <td></td> <td></td> <td></td> <td></td> </tr> </table>	Service	Master	Rate	Pass					
Loc	Loc	Per																	
Air	SEA	UPS																	
Service	Master	Rate	Pass																

Estimated Cost	
Cost Percent of	
NET	
Carrier's Charges	
Other Charges	
Total Cost	

Date Material Was Received 11-13 1975

OSORD #AS7785
NCR #179, & 180

B. Hixson
BRENDA HIXSON

Raymond W. Johnson
RAYMOND W. JOHNSON

NPS

11-17-75

RECEIVING REPORT

WESTINGHOUSE ELECTRIC CORP.

WESTINGHOUSE ELECTRIC CORP.

SUPERSEDING WBNP 76-3046-A

RECEIVING POINT

WBNP, C.W.

Sheet 1 of 1

CONTRACT NO. 71C62-54114-1

NO. AND DATE

DELIVERING POINT
TAMPA, FL
DELIVERING CARRIER
BARGE

CAN. NO. AND INITIALS
BARGE UNION MECHLING 4501

GROSS WEIGHT
700 TON APPROX.

AC. QUANT. NO.
N030-321-39-0

COMPLETE PARTIAL FINAL

CONT. ITEM NO.	ARTICLES OR SERVICES	CLASS. BIN OR STOCK NO.	QUAN. REC'D.	UNIT	UNIT PRICE	AMOUNT
	PERMANENT MATERIAL					
	REF: NKU-888					
SA	P.O. 546 GRW 1219288, S.O. WBT-120, UNIT 2					
	SPIN WBT-RCPCSG - FOR STEAM GENERATORS					
	1) MODEL "D" ONE PIECE STEAM GENERATOR #1,					
	SERIAL #1611, DNG 1100J81, SUB 5, E SPEC					
	679059, REV 2	RIVER DOCK	1	EA		
	QCR #25373, NCR #179, I & T RELEASE #4CH (10-14-75)					
	2) MODEL "D" ONE PIECE STEAM GENERATOR #2					
	SERIAL #1612, DNG 1100J81, SUB 5, E SPEC					
	679059, REV 2	"	1	EA		
	QCR #25374, I & T RELEASE #4CH (10-14-75)					
	NCR #180					
	THIS CLEARS OSORD #A-87785					
	MANWAY COVERS RECEIVED					

Delivered Via: Truck
 Common Carrier: Express, Freight, Par.
 Other CC: PARTS MATTHEWSON PATTON
 Carrier's Charges: 1999000 42380
 P. 12 of 12
 Form 5 NS Collect 3

Purchase Cost
 Cash Discounts
 Date Material Was Received: 11-13-75
 I certify that the articles or services listed above have been received in quantity and quality specified except as noted
 NCR #179 & 180
 Approved as Special Agent: BRENDA HILSON
 Title: 3-23-76
 Approved as Special Agent: RAYMOND W. JOHNSON
 Title: Person Authorizing Release

Serial No. of Form TVA 1877
 (Printed in Large Letters) 18 29
 P. 01 WESTINGHOUSE MATTS BAR SITE 423 365 5514 09-22-1997 10:45

FORM N-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR VESSELS

As required by the Provisions of the ASME Code Rules

1. Manufactured by Westinghouse Electric Corporation, Tampa Division, Tampa, Florida
(Name and address of Manufacturer)

2. Manufactured for Tennessee Valley Authority Watts Bar #1 Spring City
(Name and address of Purchaser)

3. Type Vertical Kind Steam Vessel No. 1594 (Horiz. or Vert.) (Tank, Jacketed, Heat Ex.) (Mfr. Serial No.) (State & State No.) Nat'l Bd. No. W10289 Yr. Built 1975
1591-4

3a. Applicable ASME Code: Section III, Edition 1971, Addenda date S71, Case No. NB 4643
Class 1 1355, 148
1493-1

FILMED FROM BEST AVAILABLE COPY

Items 4-8 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers.

4. Shell: Material SA-533 GR A CL2 T.S. 90000 Nominal Thickness 0.6 in. Corrosion Allowance 0.06 in. Dia. 06 ft. 06 in. Length 06 ft. 06 in.
(Kind & Spec. No.) (Min. of range specified)

5. Seams: Long Weld-Dbl-Butt H.T. Yes R.T. Complete Efficiency 100 %

Girth Weld-Dbl-Butt H.T. Yes R.T. Complete No. of Courses *

6. Heads (a) Material GR A CL2 T.S. 90000 (b) Material T.S.

Location (Top, bottom, ends)	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (Convex or Concave)
(a) Top	3.			2:1				Concave
(b)								

W 860724K0649 (TS)

If removable, bolts used (Material, Spec. No., T.S., Size, Number) Other fastening (Describe or attach sketch)

7. Assy Closure *Girth Weld-Dbl-Butt; H.T.; X.R. complete
Girth Weld (Describe as ogee & weld, bur, etc. If bar give dimensions, describe or sketch)
Drop Weight 30 Pneumatic Charpy Impact 30 ft-lb Hydrostatic or Test Pressure 1481 psi
Combination

8. Design Pressure 1185 psi at 600 °F at temp. of +10 °F

Items 9 and 10 to be completed for tube sections.

9. Tube Sheets: Stationary. Material SA-508 CL2 Dia. 125.75 in. Thickness 21.03 in. Attachment See Item 12
(Kind & Spec. No.) (Subject to press.) (Welded, Bolted)

Floating. Material (Kind & Spec. No.) Dia. in. Thickness in. Attachment

10. Tubes: Material SB-163 O.D. 750 in. Thickness .045 inches Number 4674 Type U
(Kind & Spec. No.) (Straight or U)

Items 11 to 14 incl. to be completed for Primary Chamber

11. Shell: Material T.S. Nominal Thickness 0.6 in. Corrosion Allowance 0.06 in. Dia. 06 ft. 06 in. Length 06 ft. 06 in.
(Kind & Spec. No.) (Min. of range specified)

12. Seams: Long Weld-Dbl-Butt H.T. Yes R.T. Complete Efficiency 100 %
(Welded, Dbl., Single) (Yes or No)

Girth Weld-Dbl-Butt H.T. Yes R.T. Complete No. of Courses 2*
SA-216 GR.

13. Heads: (a) Material T.S. (b) Material WCC T.S. 70000 (c) Material T.S.

Location (Top, bottom, ends)	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (Convex or Concave)
(a) Top, bottom, ends	5.09					62.81		concave
(b)								

If removable, bolts used (a) (Material, Spec. No., T.S., Size, Number) (b) (c) Other fastening (Describe or attach sketch)

14. Design pressure 2485 psi at 650 °F at temp. of 0 °F
Drop weight 30 Pneumatic Charpy Impact +10 ft-lb Hydrostatic or Test Pressure 3107 psi
Combination

* If Postweld Heat-Treated
* List other internal or external pressures with coincident temperature when applicable.

AUTHORIZED
JAN 28 1975
NUCLEAR INSPECTOR
HCS Floating

PAGE 1/4 OF 187

FILMED FROM BEST AVAILABLE COPY

is below to be completed for all vessels where applicable.

5. Safety Valve Outlets: Number _____ Size _____ Location _____

16. Nozzles:

Purpose (Inlet, Outlet, Drain)	Number	Dia. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
Prim. Inlet	1	31" I.D.	(Weld)	(SA-216)	3.00"	(SA-216)	(Integrally)
Prim. Outlet	1	31" I.D.	(End)	(GR WCC)	3.00"	(GR WCC)	(Cast)
Steam Outlet	1	29" I.D.	(Weld)	(SA-508)	1.20"	Steel	Welded
Feedwater	1	14" I.D.	(End)	(CL.2)	0.76"	Steel	Welded

17. Inspection Manhole, No. 4 Size 16" Location (2) Chamber & (2) Upper Shell
Openings: Handholes, No. 2 Size 6" Location Stub Barrel Portion of Lower Shell
Instrumentation No. 4 Size 2" Location Stub Barrel Portion of Lower Shell

Auxiliary Feedwater Noz. No. 1 Size 6" Location Upper Shell Assy: Mtl SA-508 Cl 2a

18. Supports: Skirt No Lugs _____ Legs _____ Other Attached See Below
Four Main supports are cast integral with the chamber (Where & How)

19. Remarks: This N-1 Form is to be signed off by the authorized code inspector under certificate of shop inspection for everything listed except the hydrostatic test and subsequent inspection. Field inspector must sign off for the latter items on certificate of field assembly inspection below. All other Mfg. is specified on Manufacturers' Partial Data Forms N-2 filed at Westinghouse, Aux. Noz. and 2.6 inch inspection installed in the plant. See attached supplements No. 1 and 2.

CERTIFICATION OF DESIGN

Design information on file at Westinghouse Electric Corporation, Tampa Division, Tampa, FL
Stress analysis report on file at Westinghouse Electric Corporation, Tampa Division, Tampa, FL
Design specifications certified by Nuclear Energy Systems Prof. Eng. State A. Wettliader Reg. No. 13335-E
Stress analysis report certified by Tampa Division Prof. Eng. State A. Lohmeier Reg. No. 13436

We certify that the statements made in this report are correct and that this nuclear vessel conforms to the rules of construction of the ASME Code, Section III.

Date March 3 1975 Signed Westinghouse Elec. By R.P. Wedler
(Manufacturer) Corp.

Certificate of authorization Expires May 2, 1975 Certificate of Authorization No. N-438

CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY Westinghouse Electric Corporation at Tampa, Florida

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Pennsylvania and employed by Lumbermen's Mutual Gas Co of Long Grove, Illinois have inspected the pressure vessel described in this Manufacturer's Data Report on May 19 1975, and state that to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with the ASME Code, Section III.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date May 19 1975

Inspector's Signature

Commissions N.B. 2596 - Penna. WC 2231 National Board, State, Province and No.

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Ohio and employed by Lumbermen's Mutual County Co. of Long Grove, Ill have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items NONE

not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer has constructed and assembled this pressure vessel in accordance with the ASME Code, Section III. The described vessel was inspected and subjected to a hydrostatic test and/or Pneumatic Test of 3107 psig Primary Side & 1481 psig Secondary Side.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 10-24 1981

Inspector's Signature

Commissions NB 5608 TN 692 National Board, State, Province and No.

* During The Primary hydro, the Secondary side was

Westinghouse



Nuclear Steam Generator

Size Designation	Serial No.	Primary Side	Secondary Side
43000	1594	Class	Class
Instr. Book: TM-1440-C254		Chamber Design	Shell Design
		2485 psig @ 650	1185 psig @ 600
		Tube Bundle Design	Tube Bundle Design
		670 psig @ 650	670 psig @ 650
		Initial Hydrotest	Initial Hydrotest
		3100 psig @	1482 psig @
		Subsequent Hydrotest	Subsequent Hydrotest
		Differential Pressure	Differential Pressure
		SEE EQUIP	SPEC

SPIN NOW AT RCPCSG-4

Westinghouse Elec. Corp.

1232367

MADE IN U.S.A.

FILMED FROM BEST AVAILABLE COPY

HARD COPY RETAINED

NATL BOARD NO - W10289

Size Sq. Ft.	Serial	Machine	Model	Secondary Side
48000				Class E
Instr.				
Model				

NATL BOARD NO
W10289

SPIN

Mach Design
 No. 1000 F
 Mach Design
 No. 1000 F
 Hydrated
 No. 1000 F
 Heat Hydrated
 No. 1000 F
 U.S.A.

Form N-1 Manufacturer's Data Report for Nuclear Vessels

Manufactured by Westinghouse Electric Corporation, Tampa Division, Tampa, Florida

Manufactured for Tennessee Valley Authority - Watts Bar #1 - Spring City, TN

3. Type Vertical Kind Steam Generator Series D Vessel No. 1594
National Board No. W10289 Year Built 1975

A field change was made to the steam generator under the supervision and control of Westinghouse Tampa Division by extension of the Tampa Division Certificate of Authorization as authorized by the ASME, Jurisdictional Authority of the State of Tennessee, the owner Tennessee Valley Authority and the Authorized Inspection Agency.

The change consisted of the installation of an auxiliary feedwater nozzle through the upper shell of the steam generator and the connecting of internal piping by weldment. The change was made in accordance with Westinghouse Tampa Division procedure RE-76-13 Rev. 6 and installation drawing 1104J43 Chg. 2. Change design information and stress analysis report are on file at Westinghouse Tampa Division, Tampa, Florida.

We certify that the statements made in this report are correct and that the design and installation of the auxiliary feedwater nozzle conforms to the rules of construction of the ASME Code, Section III.

On Sept. 12, 1978 Signed Westinghouse Electric Corp. By R.P. Wedler
Certificate of Authorization expires June 16, 1981
Certification of Authorization No. N-1154

This supplement is signed by the Field Authorized Nuclear Inspector indicating acceptance of the field change work with exception of the hydrostatic test and subsequent inspection. Acceptance of the latter items will be indicated by the ANI signature of the Form N-1 Certificate of Field Assembly Inspection.


HARD COPY RETAINED

CERTIFICATE OF FIELD INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Pressure Vessel Inspectors and/or the State of Tennessee have inspected the change described in this supplement and state that to the best of my knowledge and belief, the change to this pressure vessel conforms to the rules of construction of the ASME, Section III.

By signing this Certificate, neither the inspector nor his employer makes any warranty expressed or implied, concerning the alteration described in this supplement. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date Sept. 12 1978 Signed C.E. Metcalf Commission NB-6260, TN-2196
Inspector State or National Board



FILMED FROM BEST AVAILABLE COPY

Form N-1 Manufacturer's Data Report for Nuclear Vessels

- 1. Manufactured by Westinghouse Electric Corporation, Tampa Division, Tampa, Florida
- 2. Manufactured for Tennessee Valley Authority - Watts Bar #1
- 3. Type Vertical Kind Steam Generator Series D Vessel No. 1594
National Board No. W10289 Year Built 1975

A field change was made to the steam generator under the supervision and control of Westinghouse Tampa Division by extension of the Tampa Division Certificate of Authorization as authorized by the ASME, Jurisdictional Authority of the State of Tennessee, the owner, Tennessee Valley Authority, and the Authorized Inspection Agency.

The change consisted of adding a 2.6 inch diameter inspection opening in the lower shell immediately above the upper tube support plate on the vessel "W" axis. Closure hardware consists of a bolted cover and gasket. Bolts are SA-193 Gr. B7, covers are SA-516 Gr. 70 carbon steel, and gaskets are spiral wound inconel with asbestos filler.

The change was made in accordance with Westinghouse Tampa Division procedure RE-79-02 and drawing 1511E20. Change design information and stress analysis report are on file at Westinghouse Tampa Division, Tampa, Florida.


I certify that the statements made in this report are correct and that the design and installation of the inspection openings conforms to the rules of construction of the ASME Code, Section III.

Date 3/23/79 Signed Westinghouse Elec. Corp. By [Signature]
Certificate of Authorization expires June 16, 1981
Certification of Authorization No. N-1154

This Supplemental Report is signed by the Field Authorized Nuclear Inspector indicating acceptance of the field change work with exception of the hydrostatic test and subsequent inspection. Acceptance of the latter items will be indicated by the ANI signature of the Final Data Report for the completed vessel.

HARD COPY RETAINED

CERTIFICATE OF FIELD INSPECTION



I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Tennessee have inspected the change described in this supplement and state that to the best of my knowledge and belief, the change to this pressure vessel conforms to the rules of construction of the ASME Code, Section III.

By signing this Certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the alteration described in this supplement. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 3/23/79 1979 Signed [Signature] Commission NE-1500, TN-1154
Inspector [Signature] State or National Board

WORK CONTROL
FOR NON-TRANSFERRED
FEATURES (UNIT 2)

CAI-1.01
Revision 10
Page 32 of 34

APPENDIX T
Component/Part Removal or Refurbishment

ER No. ER-03 99-011 Page 1 of 4

UNIT: 2 SYSTEM NO.: 068 BP-380 Number: 2-068-041

Hold Order required? [] Yes [X] No HO#: N/A Held By: N/A 24

For Removal of: ID No. 2-56EN-068-502563
Description of Item: Manway Cover 1100181 5A 10FZ

N/A

Location: Bldg. R. Bldg Elev. 735 Coord. 56 ³/₂ 3-28-99

OITL, Deficiency, and TROI lists, etc., review complete
Items identified: Name Identified

Responsible Engineer: Daniel Reed /Date: 3-6-99

Step No. Description of Work to be Performed (See Appendix U)

1 PME and TVA Task Manager to verify component is not required for Unit 1 operation in its Unit 2 location.

PME: Daniel Reed 3-6-99

TVA Task Manager: Greg Jesta 3-6-99

Manway Next to Ladder No I.D. #5

2 QC to verify prior to removal: Robert & Patsy 3-28-99
Responsible Engineer: Daniel Reed Date 3-5-99 Ext 2017

Authorizing Supervisor D. Reed for Randy Lambert Date 3-5-99

Discipline Site Engineer J. Pierce Date 3/6/99

Does not impact Unit 1 operation or ABSCE requirements

NON-OPERATIONAL BRIBO. NO IMPACT TO S.G. SEISMIC POSITION RETENTION. U#2
Civil Engineering Joe Clark Date 3-06-99

Seismic Qualification Review for Cat 1, Structure only

Operations J.P. McGinnis Date 3-28-99

Work Complete: _____ Craft Rep _____ Date _____

(Verified App T, PEG Pkg for material to be used in QA application and review of incomplete work/outstanding problems. Forward a copy of this document to the Unit 2 PM Group.

Responsible Engr _____ Date _____
RESPONSIBILITY: DCRM

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 3/12/99
Name
 400 W. Summit Hill Drive, Knoxville, TN
Address
 Sheet _____ of _____

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
 P. O. Box 2000, Spring City, TN, 37381
Address
 Repair Organization P.O. No., Job No., etc.
w/o 98-04974-01
 Type Code Symbol Stamp _____

3. Work Performed by Watts Bar Nuclear Plant
Name
P.O. Box 2000 Spring City TN 37381
Address
 Authorization No. w/12
 Expiration Date _____

4. Identification of system 62-CVCS

5. (a) Applicable Construction Code AISC 19 72 Edition, n/a Addenda, n/a Code Case
STEEL CONSTRUCTION MANUAL
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1-SNUB-062-62A242	PSA	832	NA	SIZE 1/4	NA	Replaced	NO
1-SNUB-062-62A242	PSA	3516	NA	SIZE 1/4	85	Replacement	NO

7. Description of Work Replaced Snubber

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp _____ °F
1-TRI-0-7

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks

Applicable Manufacturer's Data Reports to be Attached

TRACKING # RR-02-88 2CC 3/12/99

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI.

Type Code Symbol Stamp NONE

Certificate of Authorization No. NA

Signed D.A. Collins Mech Engr. Date 4/5 19 99
Owner or Owner's Designee, Title


CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TN and employed by HSAI & I Co. of Hartford, CT have inspected the components described in this Owner's Report during the period 3-12-99 to 4-5-99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions TN 2533
Inspector's Signature National Board, State, Province, and Endorsements

Date 4/5 19 99



BERGEN-PATERSON PIPESUPPORT CORPORATION

34 Houston St.

Laconia, N. H.

Tel. (603) 524-1900

Certificate of Compliance

Tennessee Valley Authority

Date October 20, 1985

P.O. Box 2000

Near Spring City, TN 37381

Attention Chief Engineer

Subject Watts Bar Nuclear Power Plant

Purchase Order Number 7SKA2-520163

B-PPC Job Number 3576

TRACKING NO. SANM 11017
TRACKING OF 496
PAGE 307

HANGER MARK NO./REVISION NO.

3506-2551-11 3

HANGER MARK NO./REVISION NO.

P.O. Item #

RD 095CA02

Serial #: 3516 PSA-1

This PSA unit is in accordance with

PSCo. Spec. 0DR-1319, R/E, dated

1/3/84 and B-PPC Proc. 0BP-3576-S1.

R/M

Comments

BERGEN-PATERSON hereby certifies that all fabricated and manufactured hanger material furnished on the subject contract is in accordance with the design, material, fabrication and testing requirements of the applicable code or codes and job P.I. Specification.

Reference Code ANSI B31.1, MSS-SP 33

Specifications TVA 1521 A, B, D

Rev. No. N/A

Dated 10/29/85

DL # L-9776

Sales Willey's

Assigned to

BERGEN-PATERSON PIPESUPPORT CORP.

Linda Buchanan
Quality Assurance Department

FACE 152

BERGEN-PATERSON PIPESUPPORT CORPORATION

COMPUTERIZED TEST-STAND #023

DATE: 10-18-1985
TIME: 15:29:00
OPERATOR: DONALD R FORTIN

SNUBBER INFORMATION

INSPECTION NO: PS-1-4/SERIAL 0: 316
POWER STATION: MATTS BAR
HANGER MARK: N/A
TEST PROCEDURE: EP-8506-S1

TRACK: SANM 11017
PAGE 308 OF 496

TEST RESULTS

DRAG TEST

MAX FORCE TEST = 5.7 LBS
MAX FORCE COMP = 7.0 LBS
MAX FORCE FROM OLD POSITION (COMP) = 0.0 LBS

LOST MOTION TEST

TEST ACTION = .025 IN

ACTIVATION TEST

TENSION

MAX. FORCE APPLIED = 127 LBS
MAX. ACCLN = .0124 g'S

COMPRESSION

MAX. FORCE APPLIED = 75 LBS
MAX. ACCLN = .0117 g'S

ACCEPTANCE CRITERIA

- MAX. DRAG LOAD < 7 LBS (2% OF RATED LOAD)
- DRAG LOAD MAY BE 2% BUT < 5% FOR 1.5 SECS.
- MAX. DRAG LOAD < 17.5 LBS (5% OF RATED LOAD)
- MAX. LOST MOTION = .040 IN
- MAX. ALLOWABLE ACCLN = .02g'S
- MIN. ALLOWABLE ACCLN = 5% OF .02g'S = .001g'S

SNUBBER MEETS CRITERIA

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 3/15/99
Name
 400 W. Summit Hill Drive, Knoxville, TN
Address

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
 P. O. Box 2000, Spring City, TN, 37381
Address

3. Work Performed by Mech Mounts SNA Type Code Symbol Stamp NA
Name
Repair Organization P.O. No., Job No., etc.
 Authorization No NA

Address
 4. Identification of system Main Steam Expiration Date NA

5. (a) Applicable Construction Code Sec III 19 71 Edition, Summer Addenda, NA Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	<small>see sketch</small> Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
5/8 Secondary Cover	Westinghouse	1593	W10288	1-58560N-68-562	75	Repair	Yes
Secondary MW Cover Studs	Westinghouse	1869E02	NA	NA	98	Replaced	NO
<small>one stud</small> NUTS	Westinghouse	NA	NA	HEAT 14734	86	Replaced	NO

7. Description of Work Repair 5/8 Mainway Cover by Machinings. Replace 3 Studs, 3 Nuts & Washers

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure NOP psi Test Temp NOT °F 1-TR1-3-903

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

RL
 17000
 1-TR1-3-903
 17000

FORM NIS-2 (Back)

9. Remarks

Application Manufacturer's Data Reports to be Attached

Tracking No. RR-02-99

* Repair Mainway Cover (Secondary), Replace Studs, NUTS

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this * Repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NONE

Certificate of Authorization No. NA

Signed D H Collins Mech Engr. Date 5/19 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I & I CO. of HARTFORD CT. have inspected the components described in this Owner's Report during the period 3/15/99 to 5/26/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce M. Carrigh Inspector's Signature Commissions TN 2534 I N A National Board, State, Province, and Endorsements

Date 5/26 19 99

As required by the Provisions of the ASME Code Rules

1. Manufactured by Westinghouse Electric Corporation, Tampa Division, Tampa, Florida
(Name and address of Manufacturer)

2. Manufactured for Tennessee Valley Authority Watts Bar #1 Spring City
(Name and address of Purchaser)

3. Type Vertical Kind Steam Gen Vessel No. 1593 (Mfr. Serial No.) (State & Date No.)
(Vert. or Hor.) (Tank, Jacketed, Heat Ex.)
Vess. No. W10288 V. Built 1975
1591-4

3a. Applicable ASME Code: Section III, Edition 1971, Addenda date S71, Case No. NB 4643
Class 1, 1355, 1484
1493-1

Items 4-8 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers.

4. Shell Material SA-533 Kind GR A CL2 T.S. 90000 Nominal Thickness * in. Corrosion Allowance 06 in. Dia. * in. Length * in.

5. Seams: Long Weld-Dbl-Butt H.T. Yes R.T. Complete Efficiency 100

5a. Girth Weld-Dbl-Butt H.T. Yes R.T. Complete No. of Courses 1

6. Heads (a) Material GR A CL2 T.S. 90000 (b) Material - T.S. -

Location (Top, bottom, ends)	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Profile (Concave or Convex)
(a) Top	<u>3</u>			<u>2:1</u>				<u>concave</u>
(b)								

If removable, bolts used (Material, Spec. No., T.S., Size, Number)

FILMED FROM BEST AVAILABLE COPY
W 860724K0548 (13)

7. Assy Closure *Girth Weld-Dbl-Butt; H.T.; X.R. complete
Girth Weld (Describe as open & weld, bar, etc. If bar give dimensions. Describe in detail)
Drop Weight - Pneumatic

8. Design Pressure 1185 psi at 600 F at temp. of 30 Charpy Impact +10 ft-lb Hydrostatic or Test Pressure 1481 psi
+10 Combination

Items 9 and 10 to be completed for tube sections.

9. Tube Sheets: Stationary. Material SA-533 CL2 Dia. 125.75 in. Thickness 21.03 in. Attachment See Item 12
(Kind & Spec. No.) (Subject to press.) (Welded, Bolted)

10. Tubes: Material SB-163 O.D. 750 in. Thickness .043 inches of GAGE Number 4674 Type U
(Kind & Spec. No.) (Straight or U)

HARD COPY RETAINED

Items 11 to 13 incl. to be completed for Primary Chamber

11. Shell: Material - T.S. - Nominal Thickness in. Corrosion Allowance in. Dia. in. Length in.

12. Seams: Long Weld-1-Butt H.T. Yes R.T. complete Efficiency 2*
(Welded, Dbl., Single) (Yes or No) No. of Courses 2*

12a. Girth Weld-1-Butt H.T. Yes R.T. complete No. of Courses 2*
SA-216 GR.

13. Heads (a) Material WCC T.S. 70000 (b) Material - T.S. -

Location (Top, bottom, ends)	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Profile (Concave or Convex)
(a) Top, bottom, ends	<u>5.09</u>						<u>62.81</u>	<u>concave</u>
(b)								

If removable, bolts used (a) (Material, Spec. No., T.S., Size, Number)

14. Design pressure 2485 psi at 650 F at temp. of 20 Charpy Impact +10 ft-lb Hydrostatic or Test Pressure 3197 psi
+10 Combination

*If Post-weld Heat-Treated
*List other internal or external pressures with corresponding temperature when applicable

*See Dwg. 1101J50

AUTHORIZED
WEX
10/1/75
10/1/75
10/1/75

PAGE 157 OF 167

Items below to be completed for all vessels where applicable.

FILMED FROM BEST AVAILABLE COPY

19. Safety Valve Outlets	Number	Size	Location	Reinforcement Material	How Attached		
Noneless							
Purpose (Inlet, Outlet, Drain)	Number	Dis. or Size	Type	Material (SA-216)	Thickness	Reinforcement Material (SA-216)	How Attached (Integrally)
Prim. Inlet	1	31" I.D.	(Weld)	(SA-216)	3.00"	(SA-216)	(Integrally)
Prim. Outlet	1	31" I.D.	(End)	(CR WCC)	3.00"	(CR WCC)	(Cast)
Steam Outlet	1	29" I.D.	(Weld)	(SA-508)	1.20"	Steel	Welded
Feedwater	1	14" I.D.	(End)	(CL.2)	0.76"	Steel	Welded

17. Inspection Manholes, No. 4 Size 16" Location (2) Chamber & (2) Upper Shell
 Openings Manholes, No. 2 Size 6" Location Stub Barrel Portion of Lower Shell
 Instrumentation No. 4 Size 2" Location Stub Barrel Portion of Lower Shell
 Auxiliary Feedwater No. No. 1 Size 6" Location Upper Shell Assy: Mtl SA-508 Cl 2a

18. Support Skirt No Lugs --- Legs --- (Other X) Attached See Below (Where & How)
 Four Main Supports are cast integral with the chamber

19. Remarks: This N-1 Form is to be signed off by the authorized code inspector under certificate of shop inspection for everything listed except the hydrostatic test and subsequent inspection. Field inspector must sign off for the latter items on certificate of field assembly inspection below. All other Mfg. is specified on Manufacturers' Partial Data Form N-2 filed at Westinghouse. Aux. Noz. and 2.6 inch inspection installed in the body. See attached Supplements No. 1 & 2.

CERTIFICATION OF DESIGN
 Design information on file at Westinghouse Electric Corporation, Tampa Division, Tampa, FL
 Stress analysis report on file at Westinghouse Electric Corporation, Tampa Division, Tampa, FL
 Design specifications certified by Nuclear Energy Systems Tampa Division
 Stress analysis report certified by Tampa Division
 Prof. Eng. A. Wettlaufer Reg. No. 13355-E
 Prof. Eng. J. Lohmeier Reg. No. 13436

We certify that the statements made in this report are correct and that this nuclear vessel conforms to the rules of construction of the ASME Code, Section III.
 Signed March 3 1975 Westinghouse Elec. Corp. By R.P. Wadler
 (Manufacturer)

Certificate of authorization Expires May 3, 1975 Certificate of Authorization No. N-438

CERTIFICATE OF SHOP INSPECTION
 VESSEL MADE BY Westinghouse Electric Corporation at Tampa, Florida
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and in the State or Province of Pennsylvania and employed by Lumbermens Mutual Cas. Co., Long Grove, Illinois
 have inspected the pressure vessel described in this Manufacturer's Data Report on MARCH 3 1975
 state that to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with the ASME Code, Section III.
 By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date MARCH 3 1975
 Signature [Signature]
 Commissions NB-2592 - Penna. WC 2331
 National Board, State, Province and No.

CERTIFICATE OF FIELD ASSEMBLY INSPECTION
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Ill. Pa. Ohio and employed by Lumbermen's Mutual Company, Long Grove, Ill.
 have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items NONE and included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer has constructed and assembled this pressure vessel in accordance with the ASME Code, Section III. The described vessel was inspected and subjected to a hydrostatic test and/or Pneumatic Test of 3107 psig Primary Side & 1481 psig Secondary Side.
 By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 10-24-81
 Signature E. M. [Signature]
 Commissions NB5608 TN 692
 National Board, State, Province and No.

This form (F-18) is obtainable from the ASME, 115 E. 17th St., New York, N.Y. 10003
 Printed in U.S.A. (7-75)
 During Primary hydro, Secondary Side was filled with water
 NRC 1000
 PAGE 1593 OF 107

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 11 APRIL 1999
Name
400 W. Summit Hill Drive, Knoxville, TN Sheet 1 of 2
Address

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
P. O. Box 2000, Spring City, TN, 37381 WELL ORDER 99-003107-000
Address Repair Organization P. O. No., Job No., etc.

3. Work Performed by TYA MODIFICATIONS Type Code Symbol Stamp N/A
Name Authorization No. /
WATTS BAR NUCLEAR PLANT Expiration Date /A
Address

4. Identification of system STEAM GENERATOR BLOWDOWN SYSTEM C15
 5. (a) Applicable Construction Code ASME SECT III 1971 Edition, SUMMER 73 Addenda N/A Code Case N/A
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components.

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>1-PIPE-015-B (4" X 2" REDUCER)</u>	<u>CUSTOM ALLOY</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>1999</u>	<u>REPLACED</u>	<u>NO</u>

7. Description of Work REPLACE 4" X 2" REDUCERS ON LOOP 1 & LOOP 4 SGBD PIPING

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 1073 min psi Test Temp 553 max °F
1092 MAX

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks REF CODE CASE N-416-1
Applicable Manufacturer's Data Reports to be Attached

TASCO # RA-02-90 REC 3/16/99

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. A

Signed Kurt A. Connell CONST ENGR Date 11 APRIL 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENNESSEE and employed by ASB I&E CO of HARTFORD CT. have inspected the components described in this Owner's Report during the period 3/16/99 to 4/12/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce M. Carrigh Commissions TN 2534 "I" "N" "A"
Inspector's Signature National Board, State, Province, and Endorsements

Date 4/12 19 99

PAGE 1/5 OF 107

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS

As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 11 APRIL 1999
Name
400 W. Summit Hill Drive, Knoxville, TN Sheet 1 of 2
Address

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
P. O. Box 2000, Spring City, TN, 37381 WATTS BAR NUCLEAR 99-003107-001
Address Repair Organization P. O. No., Job No., etc.

3. Work Performed by TVA MODIFICATIONS Type Code Symbol Stamp 6
Name Authorization No. 7
WATTS BAR NUCLEAR PLANT Expiration Date 11/1
Address

4. Identification of system STEAM GENERATOR BLOWDOWN / SYSTEM 015

5. (a) Applicable Construction Code ASME SET III 19 71 Edition, SUMMER 1973 Addenda 1A, 2C, 4/6/99 Code Case 1113
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>L-PIPE-015-B (4"x2" REDUCER)</u>	<u>CUSTOM ALLOY</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>1999</u>	<u>REPLACED</u>	<u>NO</u>

7. Description of Work REPLACE 4"x2" SGBD REDUCERS (LOOPS 2 & 3)

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 1068 MIN / 1091 MAX psi Test Temp 553 MIN / 538 MAX °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

PAGE 161 OF 187

FORM NIS-2 (Back)

9. Remarks CODE CASE N-416-1
Applicable Manufacturer's Data Reports to be Attached

Tracking # R2-02-71

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the repair or replacement rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Signed L. H. Currell CONST ENGR Date 11 APRIL 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I E CO of HARTFORD CT have inspected the components described in this Owner's Report during the period 3/26/99 to 4/12/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce W. Earnest Commissions TN 2534 "I" "N" "A"
Inspector's Signature National Board, State, Province, and Endorsements

Date 4/12 19 99

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner <u>TENNESSEE VALLEY AUTHORITY</u> <div style="text-align: center; font-size: small;">Name</div> <u>400 W. Summit Hill Drive, Knoxville, TN</u> <div style="text-align: center; font-size: small;">Address</div>	Date <u>03/17/99</u> Sheet _____ of _____ Unit <u>Unit 1</u> 98-002000-001 Repair Organization P O. No., Job No., etc. Type Code Symbol Stamp <u>N/A</u> Authorization No <u>N/A</u> Expiration Date <u>N/A</u>
2. Plant <u>Watts Bar Nuclear Plant</u> <div style="text-align: center; font-size: small;">Name</div> <u>P. O. Box 2000, Spring City, TN, 37381</u> <div style="text-align: center; font-size: small;">Address</div>	
3. Work Performed by <u>WSI</u> <div style="text-align: center; font-size: small;">Name</div> <u>2225 SKYLAND COURT, NORCROSS, GA, 30071</u> <div style="text-align: center; font-size: small;">Address</div>	

4. Identification of system CONTROL ROD DRIVE SYSTEM, 085

5. (a) Applicable Construction Code SEC III, CL 1 19 71 Edition, WIN. 72 Addenda, N-504 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
UNIT 1 REACTOR VESSEL	ROTTERDAM	30749	N/A	WAT.RCPCR.V	1974	REPAIR	Y

7. Description of Work REPAIR CRDM CANOPY SEAL WELDS. PENETRATION # 13.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure ISLT
 Other Pressure _____ psi Test Temp _____ °F
 *****SEE SECTION 9.

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks

Applicable Manufacturer's Data Reports to be Attached

TRACKING # RR-02-92 2823/7/99

RELIEF REQUEST 1-RR-02 (CODE CASE N-504)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPAIR conforms to the repair or replacement rules of the ASME Code, Section XI.

Type Code Symbol Stamp NR REPAIR SYMBOL

Certificate of Authorization No. NR 69 EXPIRES NOV. 7, 2001

Signed David M. Wind WSI QA/QC Date MARCH 22 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I & I of HARTFORD, CT have inspected the components described in this

Owner's Report during the period 3/12/99 to 3/22/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce M. Earnest Commissions TN 2534 I " N " A "
Inspector's Signature National Board, State, Province, and Endorsements

Date 3/22 19 99

FORM NR-1 REPORT OF REPAIR MODIFICATION OR INSTALLATION OF REPLACEMENT(S)
TO NUCLEAR COMPONENTS AND SYSTEMS IN NUCLEAR POWER PLANTS

1. performed by WELDING SERVICES INC.
(name)
2225 SKYLAND COURT (address) NORCROSS GA. 30071 (repair organization's P.O. no., co. no., etc.)

2. Owner TENNESSEE VALLEY AUTHORITY
(name)
400 W. SUMMIT HILL DRIVE (address) KNOXVILLE TN.

3. Name, address and identification of nuclear power plant WATTS BAR NUCLEAR PLANT
P.O. BOX 2000 SPRING CITY TN. 37381

4. System CONTROL ROD DRIVE SYSTEM 068

5. a: Component repaired, modified or replaced I-HEAD-068-0001 (CRDM G-5)
 b: Name of manufacturer THE ROTTERDAM DOCKYARD CO. ROTTERDAM THE NETHERLANDS
 c: Identifying nos. 30749 BUILT 1974

d: Construction Code ASME III (int'l. serial no.) 1971 (Nat'l. Bd. No.) WINTER 72 (jurisdictional no.) N/A (other) N/A (year built)

6. Section XI 1989 EDITION (edition) N/A (addenda) N/A (Code Cases) N/A (Code Class)

7. Applicable edition of ASME Code Section XI under which repairs, modifications, or replacements were made: 1989 ED. (Code Cases) N/A

8. Applicable edition of Construction Code under which repairs, modifications, or replacements were made: ASME III (edition) 71 (addenda) WINTER 72 (Code Cases)

9. Design responsibilities N/A (Code) N/A (edition) N/A (addenda) N/A (Code Cases)

10. Tests conducted: hydrostatic pneumatic design pressure pressure N/A psi
 Description of work REPAIR OF CRDM CANOPY SEAL WELD
(use of additional sheets) or sketches is acceptable if properly identified)

12. Remarks: COMPONENT I-D. 1-068A-T173-13 (CRDM G-5)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and the repair, modification or replacement of the items described above conforms to Section XI of the ASME Code and the National Board rules as defined in the publication NB-102, current edition. (Dmw)
 Certificate of Authorization no. NR 69 to use the "NR" stamp expires NOV. 7 19 2001
 Date MARCH 22 19 99 Signed WELDING SERVICES INC. (repair organization) David M. Wink (authorized representative) WSI QA/QC (title)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors, and certificate of competency issued by the state or province of TENNESSEE and employed by HSB I&I CO
Harold C. have inspected the repair, modification or replacement describe in this report on 3/22, 19 99 and state that to the best of my knowledge and belief, this repair, modification or replacement has been made in accordance with Section XI of the ASME Code and the National Board rules as defined in the publication NB-102, current edition. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair, modification or replacement described in this report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

3/22, 19 99 Signed Bruce M. Earnest (Authorized Inspector) Commissions TN 2534 NB #8333 I "N" A (Nat'l. Bd. No. (including endorsement) state or province and number)

WIC # 471-013542-007

WAT-105
RCPCRV

FORM-N-EMV-1 PURCHASER'S DATA REPORT FOR NEW VESSELS
As required by the Provisions of the ASME Code Rules

1. Manufactured by The Rotterdam Dockyard, Co., Rotterdam, The Netherlands
(Name and address of Manufacturer)

2. Manufactured for Westinghouse Electric Corp., PURSO, P.O. Box 355 Pittsburgh, PA 15230 U.S.A.
(Name and address of Purchaser)

3. Type Vert. Kind Tank Vessel No. (10749) (Name, or Vess.) (Tank, Jacket, Heat Ex.) (Mfr. Serial No. (State & State No.)) Nat'l Id. No. Yr. Built 1974

3a. Applicable ASME Code: Section III, Edition 1971, Addenda date Winter 1971, Case No.
Class 1

W860806K0126 (2)

Items 4-8 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers.

4. Shell: Material SA-508 Cl. 2 T.S. 80,000 Nominal H. 46 Corrosion Thickness in. Allowance in. Dia. 146.5 in. Length 28 ft. 6.7 in.
(Kind & Spec. No.) (Min. of range specified)

5. Seams: Long H.T. R.T. Efficiency
Girth Butt Weld H.T. Yes R.T. Yes No. of Courses 1 # Plates

6. Heads (a) Material SA-533 Gr. B Cl. 1 T.S. 80,000 (b) Material SA-533 Gr. B T.S. 80,000

Location (Top, bottom, ends)	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (Convex or Concave)
(a) Top	6.9"	7.4"					13' 11"	Concave
(b) Bottom	5.6"	7.4"					14' 5"	Concave

FILMED FROM USSS AVAILABLE COPY

If removable, bolts used SA-540 Gr. B24 130,000 psi, 6.75" Ø 54 pcs. (Material, Spec. No., T.S., Size, Number) Other fastening (Describe or attach sketch)

Jacket Closure (Describe as ogee & weld, bar, etc. If bar give dimensions, describe or sketch)

8. Design Pressure 2485 psi at 650 °F at temp. of MAX 40 °F. Drop Weight 1000 lb. Pneumatic Test Churny Impact 30 ft-lb Hydrostatic or Pressure 3107 psi Combination Min. temp. req. 100 °F

Items 9 and 10 to be completed for tube sections. Actual temp. of vessel 127.4 °F

9. Tube Sheets: Stationary. Material Dia. in. Thickness in. Attachment (Welded, Bolted)

Floating. Material Dia. in. Thickness in. Attachment

10. Tubes: Material O.D. in. Thickness inches or gage Number Type (Straight or U)


Items 11 to 14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material T.S. Nominal Thickness in. Corrosion Allowance in. Dia. ft. in. Length ft. in.
(Kind & Spec. No.) (Min. of range specified)

12. Seams: Long H.T. R.T. Efficiency
(Welded, Dbl., Single) (Yes & No)

Girth H.T. R.T. No. of Courses

13. Heads (a) Material T.S. (b) Material T.S. (c) Material T.S.



Location	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (Convex or Concave)
(a) Top, bottom, ends								
(b) Channel								
(c) Floating								

Box 10-186 HARD COPY RETAINED

If removable, bolts used (a) (b) (c) Other fastening (Describe or attach sketch)

14. Design pressure psi at °F at temp. of °F. Drop weight lb. Pneumatic Test Churny Impact ft-lb Hydrostatic or Pressure psi Combination

1 If postweld heat treated. 2 List other internal or external pressures with coincident temperature when applicable.

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 3-18-99
Name
400 W. Summit Hill Drive, Knoxville, TN
Address

2. Plant Watts Bar Nuclear Plant Sheet _____ of _____
Name
P. O. Box 2000, Spring City, TN, 37381
Address

3. Work Performed by TVA MELT MODS NO 98-007961-003
Name Repair Organization P.O. No., Job No., etc.
WATTS BAR NUCLEAR PLANT Type Code Symbol Stamp _____
Address Name Authorization No N/A
P.O. Box 2000, SPRING CITY, TN 37381 Expiration Date _____
Address

4. Identification of system ICE CONDENSER / SYS # 061

5. (a) Applicable Construction Code ASME SECT III 19 71 Edition, SUMMER Addenda, N/A Code Case 6/8/99
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>1-PIPE-061-B</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>1999</u>	<u>REPLACEMENT</u>	<u>NO</u>

7. Description of Work ADD 2" TEE TO REROUTE BYPASS LINE AROUND
1-FCV-061-012Z

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 70-80 psi Test Temp 10 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks CODE CASE N-416-1
Applicable Manufacturer's Data Reports to be Attached

TRACKING NO. PR-02-93

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the repair or replacement rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Signed Michael Bainer CONST. ENGR. Date 3/20/99 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TENNESSEE and employed by HSB I&I Co. of HARTFORD CT. have inspected the components described in this Owner's Report during the period 12/4/98 to 3/20/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce M. Ewing Commissions TN2534 "I" "N" "A"
Inspector's Signature National Board, State, Province, and Endorsements

Date 3/20 19 99

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 3/20/99
Name
400 W. Summit Hill Drive, Knoxville, TN
Address
 Sheet _____ of _____

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
P. O. Box 2000, Spring City, TN, 37381
Address
 WO# 98-007961-002
Repair Organization P.O. No., Job No., etc.
 Type Code Symbol Stamp _____

3. Work Performed by TVA NUCR MODS Authorization No N/A
Name
P.O. Box 2000 Spring City, TN 37381
Address
 Expiration Date _____

4. Identification of system FXE CONDENSER SYS# 061

5. (a) Applicable Construction Code ASME SECT III 19 71 Edition, SUMMER 1973 Addenda, N/A Code Case N-416-T
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>1-PIPE-061-B</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>1999</u>	<u>REPLACEMENT</u>	<u>No</u>

7. Description of Work ADD 2' 6" TEE TO REROUTE BYPASS PIPE AROUND 1-FCU-061-0097

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 70-80 psi Test Temp 10 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks CODE CASE N-416-1
Applicable Manufacturer's Data Reports to be Attached

TRACKING No. PR-02-94

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the repair or replacement rules of the ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A

Signed Michael Bainer CONST. TNGR. Date 3/20 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB IEE CO. of HARTFORD CT. have inspected the components described in this Owner's Report during the period 12/4/18 to 3/20/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce M. Eganigh Commissions TN 2534 "I" "N" "A"
Inspector's Signature National Board, State, Province, and Endorsements

Date 3/20 19 99

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 3/23/99
Name
400 W. Summit Hill Drive, Knoxville, TN Sheet of
Address

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
P. O. Box 2000, Spring City, TN, 37381 WO 98-002441-002
Address

3. Work Performed by Mech Maint Type Code Symbol Stamp NA
Name Repair Organization P.O. No., Job No., etc.
Box 800 SPRING CITY TN. Authorization No NA
Address Expiration Date NA

4. Identification of system FEEDWATER & R. COOLANT CCB
 5. (a) Applicable Construction Code Section III 19 71 Edition, Summer Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
STUDS	WESTINGHOUSE	NA	NA	S/G MW Secondary Cover		Replaced	No
MW Cover Machining	Westinghouse	1592	W10287	1-SGEN-060 SG3	75	Repair	Yes

7. Description of Work REPLACE STUDS ON S/G MW COVER, SG3

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure 1-TRI-3-903
 Other Pressure NOT psi Test Temp NOT °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks

APPLICABLE MANUFACTURER'S CODE REPORTS TO BE ATTACHED

TRACKING NO. RR-02-9628C 3/23/99

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this R+R conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NONE

Certificate of Authorization No. NA

Signed DH Collins Mech Engr Date 5/19 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I & I CO. of HARTFORD CT. have inspected the components described in this Owner's Report during the period 3/23/99 to 5/25/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce M. Earnigh
Inspector's Signature

Commissions TN 2534 "I" "N" "A"
National Board, State, Province, and Endorsements

Date 5/25 19 99

FORM N-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR VESSELS
As required by the Provision of the ASME Code Rules

FILMED FROM BEST AVAILABLE COPY

1. Manufactured by Hastings Electric Corporation, Tampa Division, Tampa, Florida
(Name and address of Manufacturer)

2. Manufactured for Tennessee Valley Authority Watts Bar #1 Spring City
(Name and address of Purchaser)

3. Type Vertical Kind Steam Gen Vessel No. 1592 (Mfrs. Serial No.) (State & State No.)
(Horiz. or Vert.) (Tank, Jacketed, Heat Ex.)
Natl. Id. No. W10287 Yr. Built 1975
1591-4

3a. Applicable ASME Code: Section III, Edition 1971, Addenda date S71, Case No. NB 4643
Class 1
1355, 148
1493-1

Items 4-8 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers.

4. Shell Material SA-533 T.S. 90000 Nominal Thickness 0.06 in. Corrosion Allowance 0.06 in. Dia. 6 in. Length 100 in.
(Kind & Spec. No.) (Min. of range specified)

5. Seams: Long Weld-Dbl-Butt R.T. Yes R.T. Complete Efficiency 100
Girth Weld-Dbl-Butt R.T. Yes R.T. Complete No. of Courses *

6. Heads (a) Material SA-533 T.S. 90000 (b) Material --- T.S. ---
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press.
(Top, bottom, ends) (Kind & Spec. No.) (Min. of range specified)
(a) Top 3 --- --- --- 2:1 --- --- --- CONCAVE
(b) --- --- --- --- --- --- --- --- ---

W 860724K0647 G

If removable, bolts used (Material, Spec. No., T.S., Size, Number) Other fastening (Describe or attach sketch)

7. Assy Closure *Girth Weld-Dbl-Butt; H.T.; Y.P. complete
Girth Weld (Describe as type & weld, burr, etc. If bar give dimensions, describe or sketch)
Drop Weight --- Pneumatic
Charpy Impact 30 ft-lb Hydrostatic or } Test
+10 "F. Combination } Pressure 1481 psi

8. Design Pressure 1185 psi at 600 °F at temp. of --- °F

Items 9 and 10 to be completed for tube sections.

9. Tube Sheets: Stationary. Material SA-508 CL2 Dia. 125.75 in. Thickness 21.03 in. Attachment See Item 12
(Kind & Spec. No.) (Subject to press.) (Welded, Bolted)

Floating. Material (Kind & Spec. No.) Dia. in. Thickness in. Attachment

10. Tubes: Material SB-163 (O.D.) 750 in. Thickness .043 inches of edge Number 4674 Type U
(Kind & Spec. No.) (Straight or U)

Items 11 to 14 incl. to be completed for Primary Chamber

11. Shell Material --- T.S. --- Nominal Thickness --- in. Corrosion Allowance --- in. Dia. --- in. Length --- ft. in.
(Kind & Spec. No.) (Min. of range specified)

12. Seams: Long --- R.T. --- R.T. --- Efficiency ---
(Welded, Dbl., Single) (Yes or No)


Girth Weld-Dbl-Butt R.T. Yes R.T. complete No. of Courses 2*
SA-216 GR

13. Heads: (a) Material --- T.S. --- (b) Material WCC T.S. 70000 (c) Material --- T.S. ---
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press.
(Top, bottom, ends) (Kind & Spec. No.) (Min. of range specified)
(a) Top, bottom, ends 5.09 --- --- --- --- --- --- 62.81 concave
(b) Channel --- --- --- --- --- --- --- --- ---
(c) Floating --- --- --- --- --- --- --- --- ---

If removable, bolts used (a) (Material, Spec. No., T.S., Size, Number) (b) (c) Other fastening (Describe or attach sketch)

14. Design pressure 12485 psi at 650 °F at temp. of --- °F
Drop weight --- Pneumatic
Charpy Impact 20 ft-lb Hydrostatic or } Test
+10 "F. Combination } Pressure 3107

If Post-weld Heat-Treated (Describe or attach sketch)



Items below to be completed for all vessels where applicable.

FILMED FROM BEST AVAILABLE COPY

in. Nuzzles:	Number	Size	Location	Material	Thickness	Reinforcement Material	How Attached
Purpose (Inlet, Outlet, Drain)							
Prim. Inlet	1	31" I.D.	(Weld)	(SA-216)	3.00"	(SA-216)	(Integrally)
Prim. Outlet	1	31" I.D.	(Weld)	(CR WCC)	3.00"	(CR WCC)	(Cast)
Steam Outlet	1	29" I.D.	(Weld)	(SA-508)	1.20"	Steel	Welded
Feedwater	1	14" I.D.	(Weld)	(CL.2)	0.76"	Steel	Welded

17. Inspection Manholes, No. 4 Size 16" Location (2) Chamber & (2) Upper Shell
- Openings Handholes, No. 2 Size 6" Location Stub Barrel Portion of Lower Shell
- Instrumentation No. 4 Size 2" Location Stub Barrel Portion of Lower Shell
- Auxiliary Feedwater No. 1 Size 6" Location Upper Shell Assy: Mel Sa-508 Cl 2a
18. Supports: Skirt No Legs (Other Attached See Below) (Describe) (Where & How)
- Four Main Supports are cast integral with the chamber
19. Remarks: This N-1 Form is to be signed off by the authorized code inspector under certificate of shop inspection for everything listed except the hydrostatic test and subsequent inspection. Field inspector must sign off for the latter items on Manufacturers' Partial Data Forms N-2 filed at Westinghouse, Aux. Nos. and 2.6-inch inspection installed in the field. See attached Supplements No. 1 and 2.

CERTIFICATION OF DESIGN

Design information in file at Westinghouse Electric Corporation, Tampa Division, Tampa, FL

Stress analysis report on file at Westinghouse Electric Corporation, Tampa Division, Tampa, FL

Design specifications certified by Nuclear Energy Systems Prof. Eng. Axel Wettlaufer No. 13335-E

Stress analysis report certified by Tampa Division Prof. Eng. Axel Lohmeyer No. 13436

To certify that the statements made in this report are correct and that this nuclear vessel conforms to the rules of construction of the ASME Code, Section III.

Date March 3 1975 Signed S. R. Wedler (Manufacturer)

Certificate of authorization Expires May 3, 1975 Certificate of Authorization No. N-438

CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY Westinghouse Electric Corporation at Tampa, Florida

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and of the State of Pennsylvania and employed by Lumbermen Mutual Cos Co., Long Grove, Illinois have inspected the pressure vessel described in this Manufacturer's Data Report on MARCH 3 1975 and state that to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with the ASME Code, Section III.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date MARCH 3 1975 Signature [Signature] Commission NB 7592 - Penna WC 223L National Board, State, Province and No.

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and of the State of Ohio and employed by Lumbermen's Mutual Casualty Co., Long Grove, Ill have compared the statements in this Manufacturer's Data Report with the described pressure vessel and the data that parts referred to as NONE not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer has constructed and assembled this pressure vessel in accordance with the ASME Code, Section III. The described vessel was inspected and subjected to a hydrostatic test and/or pneumatic test of 3107 psig Primary Side & 1471 psig Secondary Side.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 6-24 81 Signature [Signature] Commission NB 5608 TN 642 National Board, State, Province and No.

Printed in U.S.A. 1974

This form is available from the ASME, ONE MERCHANT PLACE, NEW YORK, N.Y. 10001

During the primary testing, the secondary side was filled with water. N.T.C. per [unclear]

HARD COPY RETAINED

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 03-25-99
Name
400 W. Summit Hill Drive, Knoxville, TN Sheet _____ of _____
Address

2. Plant Watts Bar Nuclear Plant Unit Unit 1
Name
P. O. Box 2000, Spring City, TN, 37381 W/O 99-03451-02
Address

3. Work Performed by WBNP MECH. MAINT. Repair Organization P.O. No., Job No., etc. _____
Name Type Code Symbol Stamp N/A
P.O. BOX 2000 SPRING CITY, TN 37381 Authorization No N/A
Address Expiration Date N/A

4. Identification of system 003 - AUX. FEEDWATER

5. (a) Applicable Construction Code AISC N/A STEEL CONSTRUCTION MANUAL Code Case _____
Edition, N/A Addenda, N/A
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1-SNUB-003-03A482U	BERGEN PATTERSON	15599	N/A	N/A	N/A	REPLACED	NO
1-SNUB-003-03A482U	BERGEN PATTERSON	15599	N/A	SPHERICAL BEARING	N/A	Replace-Maint	NO
<i>Replaced Spherical Bearing And Load Pin.</i>							

7. Description of Work REPLACED SPHERICAL BEARING AND LOAD PIN

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp _____ °F
 1-TRI-0-7

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks TRACKING # RR-02-095 LLC 4/6/99
Applicable Manufacturer's Data Reports to be Attached
099

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NONE

Certificate of Authorization No. NA

Signed Johnny W. Shan General Foreman Date 4-7- 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TN and employed by HSB I & I Co. of Hartford, CT have inspected the components described in this Owner's Report during the period 3-25-99 to 4-7-99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions TN 2533
Inspector's Signature National Board, State, Province, and Endorsements
Date 4-7 19 99



BERGEN-PATERSON
PIPESUPPORT CORPORATION
Moulton, AL
Tel. (205) 974-9225

41

Certificate of Compliance

TENNESSEE VALLEY AUTHORITY
400 West Summit Hill Drive
Knoxville, TN 37902

Date November 17, 1989

Attention: Accounts Payable

Subject Plant: Watts Bar Nuclear Plant

Purchase Order Number: 78KA2-824160 RD #103885

B-PPC Job Number: 8506-3671

ITEM NO.	QTY.	PART	SIZE	DESCRIPTION
2	10	1000	4	Restraint End Connection
14	10	G202-1.5	6"	Restraint Pipe Clamp
15	10	2600-7	8"	Pipe Clamp
16	5	2600-10	8"	Pipe Clamp
17	10	G202-1.5	8"	Restraint Pipe Clamp
24	6	G202-12	18"	Restraint Pipe Clamp
29	5	G202-7	24"	Restraint Pipe Clamp
48	20	6502	10"	Long Tangent U-Bolt

Gentlemen:

BERGEN-PATERSON hereby certifies that all fabricated and manufactured hanger material furnished on the subject contract is in accordance with the design, material, fabrication and testing requirements of the applicable code or codes and job P.O./Specification. The documents which support compliance to subject code requirements as identified in the Bergen-Paterson Corporate Q.A. Manual have been reviewed and are considered correct and complete as valid Q.A. records.

Reference: Codes B31.1N, MSS-SP-58, 10 CFR 50, 10 CFR 21

Specification: P.O. Rev. No.: _____

Shipment of: 11/17/89 B/L #: M-8126 Via: _____

BERGEN-PATERSON PIPESUPPORT CORP.

Michael Zille
Quality Assurance

1700 107

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY Date 3/28/99
Name
 400 W. Summit Hill Drive, Knoxville, TN
Address

2. Plant Watts Bar Nuclear Plant Sheet _____ of _____
Name
 P. O. Box 2000, Spring City, TN, 37381
Address

3. Work Performed by WATTS BAR NUCLEAR PLANT Unit Unit 1
Name
P.O. BOX 2000 SPRING CITY TN. 37371 Authorization No NONE
Address
 Repair Organization P.O. No., Job No., etc. NONE
 Type Code Symbol Stamp

4. Identification of system OIS / STEAM GENERATOR BLOWDOWN
 Expiration Date NA

5. (a) Applicable Construction Code SECT III 19 77 Edition, WB Addenda, 1644-7 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>1-SNUB-015-4006188</u>	<u>PSA</u>	<u>33070</u>	<u>NONE</u>	<u>NONE</u>	<u>83</u>	<u>REPLACED</u>	<u>No</u>

7. Description of Work REPLACE SNUBBER

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure NR
 Other Pressure _____ psi Test Temp _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks

Applicable Manufacturer's Data Reports to be Attached

TRACKING # RR-02-100 2/24/99

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NONE

Certificate of Authorization No. NA

Signed DH Collins Mech Engr. Date 4/12 19 99
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I F I CO. of HARTFORD CT. have inspected the components described in this Owner's Report during the period 3/30/99 to 4/12/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce M. Emigh Commissions TN 2534 "I" "N" "A"
Inspector's Signature National Board, State, Province, and Endorsements

Date 4/12 19 99

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50

FORM NP-1 NPT CERTIFICATE HOLDERS' DATA REPORT FOR COMPONENT SUPPORTS
As Required by the Provisions of the ASME Code Rules, Section III, Division 1

141

1. Manufactured by Pacific Scientific 1245 S. State College Blvd. Anaheim, Ca. 92803
(Name and address of NPT Certificate holder)
Manufacturer for ITT Grinnell Corporation 621 Dana Street N.E. Warren, Ohio 44481
(Name and address of purchaser or owner)
Unknown

2. Location of Installation _____

4. Identification

(a) Component Support I.D. No.	(b) Canadian Registration No.	(c) Applicable Drawings with Last Rev. & Date	(d) Stress Report or Load Capacity Data Sheet	(e) Type of Component Support	(f) Class	(g) Natl Board No.	(h) Year Built
(1) 33070	None	1801104-05-J	Drl412 Rev. 0	Linear	1	None	1983
(2) thru							
(3) 32294							
(4)							
(5)							
(6)							
(7)							
(8)							
(9)							
(10)							

W 860724K0891 (4)

HARD COPY RETAINED

5. Remarks: Inspection Test Reports, CTR's and Certificate of Conformance reviewed and meet ASME SEC III 1974 Edition, Summer '76 Addenda and Code Case 1644-6.

CERTIFICATE OF COMPLIANCE

I hereby certify that the statements made in this report are correct and that these components supports conform to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Division 1, Edition 1977, Addenda Winter 1978 (Date)
Code Case No. 1644-7
Date 1/3/83 Signed Pacific Scientific by Donato M. N...
(NPT Certificate Holder)
Our ASME Certificate of Authorization No. 1193 to use the "NPT" (NPT)
Symbol expires Aug. 4, 1984 (Date)
FILMED FROM BEST AVAILABLE COPY

CERTIFICATION OF DESIGN

Design Information on File at Pacific Scientific
Stress Report or Load Capacity Data Sheets on File at:
Pacific Scientific
Filed Per NCA 3256
Design Specifications Certified by (1) Leo E. Ay PE State California
Reg. No. 13533
Stress Analysis Report or Load Capacity Data Sheets Certified by (1) Leo E. Ay
PE State California Reg. No. 13533
(1) List name only, signature not required.
JAN 13 1983
REVIEWED BY DS

Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in., (2) information in items 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40, 41, 42, 43, 44, 45, 46, 47, 48, 49, 50, 51, 52, 53, 54, 55, 56, 57, 58, 59, 60, 61, 62, 63, 64, 65, 66, 67, 68, 69, 70, 71, 72, 73, 74, 75, 76, 77, 78, 79, 80, 81, 82, 83, 84, 85, 86, 87, 88, 89, 90, 91, 92, 93, 94, 95, 96, 97, 98, 99, 100 is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of sheet.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Province of OHIO and employed by HSB&I Co of Hartford, CT

have inspected the component supports described in this Data Report on JAN 04 1983 and state that to the best of my knowledge and belief the NPT Certificate Holder has constructed these component supports in accordance with the ASME Code for Nuclear Power Plant Components.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the component supports described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date JAN 04 1983

Signed [Signature] Commissions CA-1513 / Ohio Commission
(Nat'l Bd., State, Prov., and No.)

CERTIFICATION OF FIELD INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Province of _____ and employed by _____ of _____

have compared the statements in this Data Report with the described component supports and state that the parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and that to the best of my knowledge and belief the NPT Certificate Holder has constructed these component supports in accordance with the ASME Code for Nuclear Power Plant Components.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the component supports described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____

Signed _____ Commissions _____
(Nat'l Bd., State, Prov., and No.)

FOR THE NATIONAL BOARD OF BOILER AND PRESSURE VESSEL INSPECTORS

HARD COPY RETAINED

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
 As Required by the Provisions of the ASME Code Section XI

1. Owner TENNESSEE VALLEY AUTHORITY
Name
400 W. Summit Hill Drive, Knoxville, TN
Address

Date 3-25-99

Sheet _____ of _____

2. Plant Watts Bar Nuclear Plant
Name
P. O. Box 2000, Spring City, TN, 37381
Address

Unit Unit 1

W/C: 98-004974-003

Repair Organization P.O. No., Job No., etc.
 Type Code Symbol Stamp _____

3. Work Performed by WATTS BAR Nuclear Plant
Name
P. O. Box 2000 Spring City, TN, 37381
Address

Authorization No. _____

Expiration Date _____

~~_____~~
 N/A

4. Identification of system 015 STEAM GENERATOR Blowdown

5. (a) Applicable Construction Code AISC 19MA Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989

STEEL CONSTRUCTION MANUAL

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
i-SNUB-015-1006199	PSA	33262	NONE	Snubber	1983	Replaced	yes

7. Description of Work REPLACED SNUBBER

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp N/A °F
1-TRI-0-7

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NS-2 (Back)

9. Remarks

TRACKING # RR-02-101 200 4/12/99

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NONE

Certificate of Authorization No. NA

Signed D.H. Collins Mech Engr Date 4/12 19 99

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Tennessee and employed by HSB I & I CO of Hartford CT. have inspected the components described in this Owner's Report during the period 3/25/99 to 4/12/99 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Bruce M. Earnigh Inspector's Signature

Commissions TN 2534

"I" "N" "A"

National Board, State, Province, and Endorsements

Date 4/12 19 99

FORM NP-1 NPT CERTIFICATE IN DESIGNS DATA REPORT FOR COMPONENT SUPPORTS
 As Required by the Provisions of the ASME Code Rules, Section III, Division 1

1. Manufactured by Pacific Scientific 1245 S. State College Blvd. Anaheim, Ca. 92903
(Name and address of NPT Certificate holder)

Manufacturer for ITT Grinnell Corporation 621 Dana Street N.E. Warren, Ohio 44481
(Name and address of purchaser or owner)

2. Location of Installation Unknown

4. Identification

(1) Component Support I.D. No.	(2) Canadian Registration No.	(3) Applicable Drawings with List Rev. & Date	(4) Stress Report or Load Capacity Data Sheet	(5) Type of Component Support	(6) Class	(7) NPT Board No.	(8) Year Built
(1) 33070	None	1801104-03-J	D-1412 Rev. 0	Linear	1	None	1983
(2) thru							
(3) 33294							
(4)							
(5)							
(6)							
(7)							
(8)							
(9)							
(10)							

868-5-86
 W 860724K0891 (4)
 W 860724K1745 (4)

HARD COPY RETAINED

5. Remarks: Inspection Test Reports, CTR's and Certificate of Conformance reviewed and meet ASME SEC III 1974 Edition, Summer '75 Addenda and Code Case 1644-0.

CERTIFICATE OF COMPLIANCE

I certify that the statements made in this report are correct and that these components supports conform to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Division 1, Edition 1977, Appendix Winter 1978.

Code Case No. 1644-7

Date 1/3/83 Signed Pacific Scientific by [Signature] (Date)

Our ASME Certificate of Authorization No. 1193 to use the "NPT" (NPT)

Symbol expires Aug. 4, 1984 (Date)

FILMED FROM BEST AVAILABLE COPY

CERTIFICATION OF DESIGN

Design Information on File at Pacific Scientific

Stress Report or Load Capacity Data Sheets on File at Pacific Scientific

Filed Per NCA 3256

Design Specifications Certified by (1) Leo E. Ay PE State California

Reg. No. 13533

Stress Analysis Report or Load Capacity Data Sheets Certified by (1) Leo E. Ay PE State California Reg. No. 13533

List name only, signature not required.

JAN 13 1983

REVIEWED BY [Signature]

Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. (2) information in items 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40, 41, 42, 43, 44, 45, 46, 47, 48, 49, 50, 51, 52, 53, 54, 55, 56, 57, 58, 59, 60, 61, 62, 63, 64, 65, 66, 67, 68, 69, 70, 71, 72, 73, 74, 75, 76, 77, 78, 79, 80, 81, 82, 83, 84, 85, 86, 87, 88, 89, 90, 91, 92, 93, 94, 95, 96, 97, 98, 99, 100, 101, 102, 103, 104, 105, 106, 107, 108, 109, 110, 111, 112, 113, 114, 115, 116, 117, 118, 119, 120, 121, 122, 123, 124, 125, 126, 127, 128, 129, 130, 131, 132, 133, 134, 135, 136, 137, 138, 139, 140, 141, 142, 143, 144, 145, 146, 147, 148, 149, 150, 151, 152, 153, 154, 155, 156, 157, 158, 159, 160, 161, 162, 163, 164, 165, 166, 167, 168, 169, 170, 171, 172, 173, 174, 175, 176, 177, 178, 179, 180, 181, 182, 183, 184, 185, 186, 187, 188, 189, 190, 191, 192, 193, 194, 195, 196, 197, 198, 199, 200, 201, 202, 203, 204, 205, 206, 207, 208, 209, 210, 211, 212, 213, 214, 215, 216, 217, 218, 219, 220, 221, 222, 223, 224, 225, 226, 227, 228, 229, 230, 231, 232, 233, 234, 235, 236, 237, 238, 239, 240, 241, 242, 243, 244, 245, 246, 247, 248, 249, 250, 251, 252, 253, 254, 255, 256, 257, 258, 259, 260, 261, 262, 263, 264, 265, 266, 267, 268, 269, 270, 271, 272, 273, 274, 275, 276, 277, 278, 279, 280, 281, 282, 283, 284, 285, 286, 287, 288, 289, 290, 291, 292, 293, 294, 295, 296, 297, 298, 299, 300, 301, 302, 303, 304, 305, 306, 307, 308, 309, 310, 311, 312, 313, 314, 315, 316, 317, 318, 319, 320, 321, 322, 323, 324, 325, 326, 327, 328, 329, 330, 331, 332, 333, 334, 335, 336, 337, 338, 339, 340, 341, 342, 343, 344, 345, 346, 347, 348, 349, 350, 351, 352, 353, 354, 355, 356, 357, 358, 359, 360, 361, 362, 363, 364, 365, 366, 367, 368, 369, 370, 371, 372, 373, 374, 375, 376, 377, 378, 379, 380, 381, 382, 383, 384, 385, 386, 387, 388, 389, 390, 391, 392, 393, 394, 395, 396, 397, 398, 399, 400, 401, 402, 403, 404, 405, 406, 407, 408, 409, 410, 411, 412, 413, 414, 415, 416, 417, 418, 419, 420, 421, 422, 423, 424, 425, 426, 427, 428, 429, 430, 431, 432, 433, 434, 435, 436, 437, 438, 439, 440, 441, 442, 443, 444, 445, 446, 447, 448, 449, 450, 451, 452, 453, 454, 455, 456, 457, 458, 459, 460, 461, 462, 463, 464, 465, 466, 467, 468, 469, 470, 471, 472, 473, 474, 475, 476, 477, 478, 479, 480, 481, 482, 483, 484, 485, 486, 487, 488, 489, 490, 491, 492, 493, 494, 495, 496, 497, 498, 499, 500, 501, 502, 503, 504, 505, 506, 507, 508, 509, 510, 511, 512, 513, 514, 515, 516, 517, 518, 519, 520, 521, 522, 523, 524, 525, 526, 527, 528, 529, 530, 531, 532, 533, 534, 535, 536, 537, 538, 539, 540, 541, 542, 543, 544, 545, 546, 547, 548, 549, 550, 551, 552, 553, 554, 555, 556, 557, 558, 559, 560, 561, 562, 563, 564, 565, 566, 567, 568, 569, 570, 571, 572, 573, 574, 575, 576, 577, 578, 579, 580, 581, 582, 583, 584, 585, 586, 587, 588, 589, 590, 591, 592, 593, 594, 595, 596, 597, 598, 599, 600, 601, 602, 603, 604, 605, 606, 607, 608, 609, 610, 611, 612, 613, 614, 615, 616, 617, 618, 619, 620, 621, 622, 623, 624, 625, 626, 627, 628, 629, 630, 631, 632, 633, 634, 635, 636, 637, 638, 639, 640, 641, 642, 643, 644, 645, 646, 647, 648, 649, 650, 651, 652, 653, 654, 655, 656, 657, 658, 659, 660, 661, 662, 663, 664, 665, 666, 667, 668, 669, 670, 671, 672, 673, 674, 675, 676, 677, 678, 679, 680, 681, 682, 683, 684, 685, 686, 687, 688, 689, 690, 691, 692, 693, 694, 695, 696, 697, 698, 699, 700, 701, 702, 703, 704, 705, 706, 707, 708, 709, 710, 711, 712, 713, 714, 715, 716, 717, 718, 719, 720, 721, 722, 723, 724, 725, 726, 727, 728, 729, 730, 731, 732, 733, 734, 735, 736, 737, 738, 739, 740, 741, 742, 743, 744, 745, 746, 747, 748, 749, 750, 751, 752, 753, 754, 755, 756, 757, 758, 759, 760, 761, 762, 763, 764, 765, 766, 767, 768, 769, 770, 771, 772, 773, 774, 775, 776, 777, 778, 779, 780, 781, 782, 783, 784, 785, 786, 787, 788, 789, 790, 791, 792, 793, 794, 795, 796, 797, 798, 799, 800, 801, 802, 803, 804, 805, 806, 807, 808, 809, 810, 811, 812, 813, 814, 815, 816, 817, 818, 819, 820, 821, 822, 823, 824, 825, 826, 827, 828, 829, 830, 831, 832, 833, 834, 835, 836, 837, 838, 839, 840, 841, 842, 843, 844, 845, 846, 847, 848, 849, 850, 851, 852, 853, 854, 855, 856, 857, 858, 859, 860, 861, 862, 863, 864, 865, 866, 867, 868, 869, 870, 871, 872, 873, 874, 875, 876, 877, 878, 879, 880, 881, 882, 883, 884, 885, 886, 887, 888, 889, 890, 891, 892, 893, 894, 895, 896, 897, 898, 899, 900, 901, 902, 903, 904, 905, 906, 907, 908, 909, 910, 911, 912, 913, 914, 915, 916, 917, 918, 919, 920, 921, 922, 923, 924, 925, 926, 927, 928, 929, 930, 931, 932, 933, 934, 935, 936, 937, 938, 939, 940, 941, 942, 943, 944, 945, 946, 947, 948, 949, 950, 951, 952, 953, 954, 955, 956, 957, 958, 959, 960, 961, 962, 963, 964, 965, 966, 967, 968, 969, 970, 971, 972, 973, 974, 975, 976, 977, 978, 979, 980, 981, 982, 983, 984, 985, 986, 987, 988, 989, 990, 991, 992, 993, 994, 995, 996, 997, 998, 999, 1000.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Province of OHIO and employed by HERIOT Co of Hartford, CT

have inspected the component supports described in this Data Report on JAN 04 1982 and state that to the best of my knowledge and belief the NPT Certificate Holder has constructed these component supports in accordance with the ASME Code for Nuclear Power Plant Components.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the component supports described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date JAN 04 1982

Signed [Signature] Commissions CA-1513 / Ohio Commission
(Nat'l Bd., State, Prov., and No.)

CERTIFICATION OF FIELD INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Province of _____ and employed by _____ of _____

have compared the statements in this Data Report with the described component supports and state that the parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and that to the best of my knowledge and belief the NPT Certificate Holder has constructed these component supports in accordance with the ASME Code for Nuclear Power Plant Components.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the component supports described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____

Signed _____ Commissions _____
(Nat'l Bd., State, Prov., and No.)

PHMED FROM THE AVAILABLE COPY

HARD COPY RETAINED

ENCLOSURE 2

ASME SECTION XI
INSERVICE INSPECTION SUMMARY REPORT
2ND REFUELING OUTAGE

COMMITMENT LIST

ENCLOSURE 2

WATTS BAR NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY REPORT
2ND REFUELING OUTAGE
COMMITMENT LIST

1. Two request for relief (RFR) are required to be written for ISI components examined during this inspection. The RFRs for the steam generator nozzle-to-safe end butt weld and the reactor vessel head-to-flange weld are required as a result of not obtaining code coverage due to limitations. The RFRs will be submitted under separate letter to the NRC.
2. The First Period of the 10-year inspection interval ended May 26, 1999. System pressure tests required for the First Period that were completed after the Cycle 2 Refueling Outage (April 16, 1999), will be reported in the Cycle 3 Summary Report.