

Enclosure 1 To NL-09-129

CALCULATION IP3-CALC-ED-00207, REVISION 8

ENTERGY NUCLEAR OPERATIONS, INC.
INDIAN POINT NUCLEAR GENERATING UNIT NO. 3
DOCKET NO. 50-286

<input type="checkbox"/> ANO-1	<input type="checkbox"/> ANO-2	<input type="checkbox"/> GGNS	<input type="checkbox"/> IP-2	<input checked="" type="checkbox"/> IP-3	<input type="checkbox"/> PLP
<input type="checkbox"/> JAF	<input type="checkbox"/> PNPS	<input type="checkbox"/> RBS	<input type="checkbox"/> VY	<input type="checkbox"/> W3	
<input type="checkbox"/> NP-GGNS-3	<input type="checkbox"/> NP-RBS-3				

CALCULATION COVER PAGE	(1) EC # 16788	(2) Page 1 of 69
-------------------------------	-----------------------	-------------------------

(3) Design Basis Calc. <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	(4) <input checked="" type="checkbox"/> CALCULATION <input type="checkbox"/> EC Markup
--	--

(5) Calculation No: IP3-CALC-ED-00207	(6) Revision: 8
--	------------------------

(7) Title: 480V Buses 2A, 3A, 5A & 6A and EDG's 31, 32 and 33 Accident Loading	(8) Editorial <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
---	---

(9) System(s): 480V	(10) Review Org (Department): Electrical Design
----------------------------	--

(11) Safety Class: <input checked="" type="checkbox"/> Safety / Quality Related <input type="checkbox"/> Augmented Quality Program <input type="checkbox"/> Non-Safety Related	(12) Component/Equipment/Structure Type/Number:		
	EDG 31	EDG 32	EDG 33
	SST 2	Bus 2A	
	SST 3	Bus 3A	
	SST 5	Bus 5A	
	SST 6	Bus 6A	

(13) Document Type: CALC		
---------------------------------	--	--

(14) Keywords (Description/Topical Codes): 480V LOADING		
---	--	--

(15) Name/Signature/Date A. Zografos <i>[Signature]</i> 8/27/09 Responsible Engineer	(16) Name/Signature/Date F. Bloise <i>[Signature]</i> 8/27/09 <input checked="" type="checkbox"/> Design Verifier <input type="checkbox"/> Reviewer <input type="checkbox"/> Comments Attached	(17) Name/Signature/Date J. Raffaele <i>[Signature]</i> 8/27/09 Supervisor/Approval <input type="checkbox"/> Comments Attached
---	--	--

**CALCULATION
REFERENCE SHEET**

 CALCULATION NO: IP3-CALC-ED-00207

 REVISION: 8
I. EC Markups Incorporated (N/A to NP calculations)

II. Relationships:	Sht	Rev	Input Doc	Output Doc	Impact Y/N	Tracking No.
1. See IAS			<input type="checkbox"/>	<input type="checkbox"/>		
2.			<input type="checkbox"/>	<input type="checkbox"/>		
3.			<input type="checkbox"/>	<input type="checkbox"/>		
4.			<input type="checkbox"/>	<input type="checkbox"/>		
5.			<input type="checkbox"/>	<input type="checkbox"/>		

III. CROSS REFERENCES:

- 1.
- 2.
- 3.
- 4.
- 5.

IV. SOFTWARE USED:

Title: _____ Version/Release: _____ Disk/CD No. _____

V. DISK/CDS INCLUDED:

Title: _____ Version/Release _____ Disk/CD No. _____

VI. OTHER CHANGES:

Revision	Record of Revision
0	Initial issue. Determined bus loading with no load management.
1	Calculated the loading using maximum brake horsepower requirements and temporary load management per TOP-67, Rev. 2
2	Recalculated the maximum brake horsepower loading requirements.
3	Determined the 480V Buses and EDGs loading based on the revised Emergency Operating Procedures (EOP). The EOPs were revised to incorporate load management to prevent overcurrent tripping of the 480V buses main supply breaker and subsequent lockout of its associated EDG breaker (and for EDG 31 tie breaker 2AT 3A). This revision also calculated bus loadings with Off-Site Power available and EDG loading for loss of Off-Site Power for each of the accident scenarios. The EDG loading was included in revision 3 because the EOPs had been revised to include both EDG (kW) and 480V, 6.9 kV equivalent bus (amps) loading values in the same procedures.
4	Incorporated plant modifications, updated loading, incorporated instrument accuracies in load monitoring tables, deleted Loss of Secondary Heat Sink scenario, incorporated 480V PIP outage modifications and revised attached loading tables as per revised EOPs.
5	Incorporated latest revisions to the EOPs, plant modifications (R08), and revised load data as summarized in Appendix A.13.
6	Incorporated the latest revision to the EOPs (this was an extensive revision generated by an engineering / operations review), plant modifications (R09) and the effect of frequency variation on EDG loading. A major revision was made to all the Accident Loading Step Descriptions and a summary of the loads running at end of each scenario was added. For each of the accident scenarios, loading with total MCC and lighting load reset was calculated. This revision also consolidates the Small Break LOCA no Spray Required (RCS temperature > 350 Deg. - F) and Small Break LOCA no Spray Required (RCS temperature < 350 Deg. - F) into one Small Break LOCA accident scenario.

7	Major revision to EOPs generated by the implementation of Rev. 1C of the WOG ERGs, has resulted in a general revision of all the scenarios. E-O Accident not Identified and Steam Generator Tube Rupture (with phase B isolation) scenarios are not creditable DBAs and have been deleted from the calculation see Attachment 1. This revision has also incorporated the use of Containment Recirculation Switches RS-2, RS-4, RS-7 and plant modifications that resulted in load changes. Appendixes E, F and G have been added to the calculation.
8	Incorporated the latest revision to EOPs and the latest revisions of calculations IP-CALC-04-00809 Rev.2 "Brake Horsepower Values Related to Certain Pumps and Fans for EDG Electrical Loading" and IP-CALC-ED-00201 Rev.2 "480V Buses 2A, 3A, 5A and 6A Non-Accident Loading".

Nuclear Engineering CALCULATION SHEET

New York Power
Authority

Calculation No. IP3-CALC-ED-00207 Revision 8

Project: Electrical Load Study Page 1 of 69

Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

TABLE OF CONTENTS

<u>PAGE</u>	
1.0	OBJECTIVE 2
2.0	DESIGN BASIS/ASSUMPTIONS 2
3.0	SUMMARY/CONCLUSIONS 8
4.0	REFERENCES..... 12
5.0	AFFECTED SYSTEM/COMPONENTS/DOCUMENTS 14
6.0	LOAD DATA/CALCULATIONS 15
7.0	EFFECT OF FREQUENCY VARIATION ON EDG LOADING..... 53
8.0	POWER FACTOR CALCULATION FOR WORST CASE KVA LOADING ON EDGs 56
9.0	INDEX OF LOADING CALCULATIONS FOR EACH ACCIDENT SCENARIO 60
	(PAGE 1 THRU500 OF CALCULATIONS ATTACHED AT THE END
10.0	APPENDIX A 68
11.0	APPENDIX B 68
12.0	APPENDIX C 68
13.0	APPENDIX D 69
14.0	APPENDIX E 69
15.0	APPENDIX F 69
16.0	APPENDIX G 69
17.0	APPENDIX H 69
18.0	ATTACHMENT I 69

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8

Project: Electrical Load Study Page 2 of 69

Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

1.0 OBJECTIVE

The objective of this calculation is to determine the "worst case" loadings for 480V Safety Buses 2A, 3A, 5A, and 6A, and Emergency Diesel Generators (EDG) 31, 32 and 33, during Design Basis Accidents (DBA):

2.0 DESIGN BASIS/ASSUMPTIONS

1. The Design Basis Accidents (DBA) identified below are evaluated in this calculation for loading on the 480V Safety Buses and the Emergency Diesel Generators as per the Emergency Operating Procedures operator actions. The loading is calculated with Off-Site Power available, Off-Site Power available with loss of a Bus, loss of Off-Site Power (Loop), and Loop with loss of a Bus.

Large Break LOCA (RCS Pressure < 325 psi)

Small Break LOCA

Small Break LOCA with Phase B Isolation (Containment Spray Required)

Steam Break with Phase B Isolation (Containment Spray Required)

Steam Break

Inadvertent Safety Injection (SI) with Phase B Isolation (Containment Spray Required)

Inadvertent SI

Steam Generator Tube Rupture

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8

Project: Electrical Load Study Page 3 of 69

Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

2.0 DESIGN BASIS/ASSUMPTIONS (Continued)

2. For the Design Basis Accidents identified in this calculation, one or more of the following 480V Safety Bus alignments are postulated.
 - All 480V Safety Buses are available and powered from off-site.
 - Off-Site Power available, Station Service Transformer (SST) No. 3 is lost (i.e. loss of voltage on 480V Bus 3A), 480V Bus Tie Breaker 2AT3A auto closes and a subsequent safety injection occurs. Because of the auto closure of Bus Tie Breaker 2AT3A, this alignment produces the worst case loading when a single failure is postulated.
 - Loss of Off-Site Power (LOOP), Bus Tie Breaker 2AT3A automatically closes to power Bus 3A from EDG 31, via Bus 2A (480V Bus 2A/3A is considered one safety bus).
3. This calculation is based on the assumptions of a single active failure of an entire safeguards BUS/EDG and that one Component Cooling Water Pump (CCWP) and one Non-Essential Service Water Pump (NESWP) may be out of service. The loss of one of the station service transformers is not a bounding condition since the associated EDG would automatically assume the bus loading in the event of a station service transformer failure. Also, the station service transformers are Non-Category I, so loss of a station service transformer cannot be considered as a single failure.
4. In order to determine the worst case bus current (Amp) loadings, the current values for the accident scenarios (with Off-Site Power available) have been calculated for a minimum degraded bus voltage of 444 Volts. Below this 444 Volts level, the 480V Safeguard Bus undervoltage alarm is actuated (Ref. 2) the associated station service transformer feeder breaker will be manually tripped and the bus will be automatically fed from its respective diesel generator. This measure (via Ref. 2) ensures that the degraded voltage condition will not result in overcurrent tripping of SS XFMR feeder breakers and subsequent lockout of EDG breakers and Bus Tie Breaker 2AT3A.
5. Emergency Diesel Generator Ratings. (Ref. Sections 4.0, 3-(12) and 5-(9))

Continuous	=	1750kW
2000 Hour	=	Peak 1950kW
2 Hour	=	1950 kW
½ Hour	=	2000kW

Maximum Non Warranted 2 Hour is 2250kW
Stall Rating is 2385kW

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8

Project: Electrical Load Study Page 4 of 69

Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

2.0 DESIGN BASIS/ASSUMPTIONS (Continued)

6. All accident scenarios loadings are based on the sequential execution of Emergency Operating Procedures (EOPs) in response to the DBAs postulated in this calculation. The latest revisions of the following EOPs are utilized in the analysis.

GENERIC FOLDOUT PAGE

RO-1	BOP Operator Actions During Use of EOPs
E-0	Reactor Trip or Safety Injection
E-1	Loss of Reactor or Secondary Coolant
E-2	Faulted Steam Generator Isolation
E-3	Steam Generator Tube Rupture
ES-1.1	SI Termination
ES-1.2	Post LOCA Cooldown and Depressurization
ES-1.3	Transfer to Cold Leg Recirculation
ES-1.4	Transfer to Hot Leg Recirculation
ES-3.1	Post - SGTR Cooldown using Backfill
SOP-EL-15	Operation of Non-Safeguards Equipment During Use of EOPs
SOP-RHR-1	Residual Heat Removal System

7. In Revision 0 of this calculation, since the NYPA Emergency Operating Procedures (EOPs) for a Safety Injection (SI) did not provide any load management instructions when Off-Site Power is available, whenever a load may have been energized on a particular bus per the NYPA EOPs, it was assumed to be energized on that bus at all times. This resulted in extremely conservative Bus loading. Subsequent revisions and specifically revision 7 of this calculation recalculated the loadings actual operator actions provided by the procedures in effect at the time.

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
Project: Electrical Load Study Page 5 of 69
Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

2.0 DESIGN BASIS/ASSUMPTIONS (Continued)

8. In all accident scenarios postulated, if Buses 2A and 3A are tied together via Breaker 2AT3A when MCCs are reset it is as per SOP-EL-15. This procedure requires the operators to manually open all disconnect switches, except for required loads, prior to resetting MCC's loads. Lighting reset is not required since Control Room lighting is now relocated to MCC 36C which remains energized.
9. In all scenarios where MCC/lighting and Pressurizer Heaters resets occur, the reset is as per SOP-EL-15.
10. Motor loading data was derived using calculated brake horse powers as determined by Calculation No. IP3-CALC-ED-00293 Rev. 0 entitled "Brake Horsepower Requirements of Safety Related Pumps and Fans" and IP3-CALC-MULT-00365 Rev. 0 entitled "BHP Requirements of Pumps and Fans", except where otherwise indicated. Power factors and efficiencies for motor loads were obtained from manufacturer's motor data sheets unless otherwise noted. If manufacturer's data was unavailable, a power factor (pf) of 0.85 and an efficiency (eff) of 0.90 was assumed for motor loads for conservatism.
11. Maximum run time for Containment Spray Pump (CSP) is 30 minutes as per NSE-99-03-075 ADMIN, Rev.0. Battery Chargers 31, 32 and 34 are reset per EOP (RO-1-15).
12. 480V Safeguards Buses 2A, 3A, 5A and 6A are rated at 3200 Amps continuous. However, the bus supply breakers from the Station Service Transformers are set to trip at 4000 Amps. The breaker trip devices (Amptectors) have a 10 percent pickup tolerance band. Therefore, the supply breakers could trip at a minimum of 3600 Amps. An engineering analysis has been performed to verify that the 480V buses, supply breakers and SS XFMRs can sustain peak loadings of up to 3600 Amps (Ref. IP3-CALC-ED-00300, 301 and 302). If a bus supply breaker were to trip on overcurrent, then the associated EDG breaker would be locked out, preventing the EDG from automatically powering the de-energized safeguards bus, until the bus lockout can be manually reset.
13. In order to prevent unnecessary overloading of one 480V Bus or EDG, the operators are instructed to start a load on the lightest loaded Bus/EDG and to reduce load on the heaviest loaded Bus/EDG.
14. Inaccuracies of alarms and meters are not being justified in this calculation, since this is not a setpoint calculation. Calculation IP3-CALC-ED-00297, Rev.2 titled "480 Volt Buses 2A, 3A, 5A and 6A Degraded Voltage Relay Setpoint Calculation", addresses the adequacy of the under voltage alarm relay setpoints and voltmeters used for monitoring 480 volt bus voltages.

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8

Project: Electrical Load Study Page 6 of 69

Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

2.0 DESIGN BASIS/ASSUMPTIONS (Continued)

15. Current values for 480V bus loadings for scenarios with Off-Site Power available, are calculated as follows:

$$\text{Current (Amps)} = \frac{\text{kVA} \times 1000}{\text{Voltage} \times 1.73}$$

16. For 6.9kV ammeter amperage the following calculation is used in converting from 480V amps:

$$\text{Equiv. 6.9kV Current} = (\text{Load Current on 480V Bus}) \frac{(480V)(1.02)}{(6900V)}$$

where 1.02 is the correction factor for inaccuracies in the current monitoring loop. (See IP3-CALC-ED-00285, Rev. 1).

17. In order to account for cable losses, the voltage used in calculating current loading is the terminal voltage at the loads. This terminal voltage was determined by subtracting typical calculated voltage drops, where available (Ref. Document No. SS-4-10, Rev. 1 entitled "1991 Update of IP3 Degraded Grid Voltage Studies"), from the minimum degraded bus voltage of 444 Volts. Based on the 1997 update of the IP3 Degraded Grid Voltage Study, the voltage variations from the original study are minor and will have no impact on the conclusion of this calculation. See Appendix G for comparison between the two studies.
18. The Emergency Diesel Generators (EDGs) governor maintains a frequency of 60HZ as demonstrated by plant procedures (SOP-EL-1 and IC-PC-I-31, 32 and 33). For postulated failure of the EDGs to maintain a 60HZ frequency see Section 7 of this calculation.
19. The only motor operated valves (MOVs) actuated during the DBA are located on MCCs 36A and 36B (see Appendix F for valve list). The valves of consequence to loading are those that are SI automatically actuated. The worst case maximum stroke time for any of the automatic actuated MOVs is less than 4 minutes; therefore the load generated is transient in nature occurring during the first few minutes of an SI actuation when loading is at a minimum. For this reason MOV loads are not accounted for as part of the MCC load.
20. Only worst case peak and steady state loading scenarios are considered for cable loss calculations.
21. In this analysis, the EOP response paths postulated in the accident scenario calculations are the ones that will result in worst case loading.

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 7 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

2.0 DESIGN BASIS/ASSUMPTIONS (Continued)

22. Equipment load arrangements on the buses are as follows.

<u>Description</u>	<u>Bus 5A</u> <u>EDG 33</u>	<u>Bus 2A/3A</u> <u>EDG 31</u>	<u>Bus 6A</u> <u>EDG 32</u>
Aux. FW Pumps (AFWP)		31	33
Component Cooling Water Pumps (CCWP)	31	32	33
Charging Pumps	31	32	33
Containment Recirc. Pumps (CRP)	31		32
Containment Spray Pumps (CSP)	31		32
Essential Service Water Pumps (ESWP)*	34	35	36
Non-Essential Service Water Pumps (NESWP)*	31	32	33
Safety Injection Pumps	31	32	33
RHR Pumps		31	32
Fan Cooler Units (FCU)	31, 33	32, 34	35
Pressurizer Heater Group	33	31,32	Control
PAB Fans		31	32
MCCs (Never Stripped) (Reset During Scenarios) (Stripped during a SI with LOOP, not reset in any scenarios.)	36A, 36E, 38, 39, 311	36C, 32,33, 34,35 31, 210	36B,36D, 37

* Switch 43/SW on control room panel SB1F is used for selecting the essential header. Placing the switch in position 4, 5, 6 selects service water pumps 34, 35 and 36 as the Essential Service Water Pumps and pumps 31, 32 and 33 as Non-Essential Service Water pumps. This calculation assumes the 43/SW switch is in position 4, 5, 6.

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 8 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

3.0 SUMMARY/CONCLUSIONS

SUMMARY:

Based on the analysis of each accident and the loading shown in the Loading Summary (see Section 8.0) the following summation and conclusions are arrived at.

OFF SITE POWER AVAILABLE

Worst Case Accident Scenarios	Peak & Steady State Loading (With Degraded Grid Voltage - 444V)	Peak & Steady State Loading (With Normal Voltage - 480V)
Peak Load* Large Break LOCA Bus 2A and 3A tied. Bus 5A not available.	Bus 2A/3A 3436 amps	Bus 2A/3A $3436 \times \frac{444}{480}$ = 3178.3 amps
Steady State** Large Break LOCA Bus 2A and 3A tied. Bus 6A not available.	Bus 5A 3126 amps	Bus 5A $3126 \times \frac{444}{480}$ = 2891.6 amps

* In all the accident scenarios where Off-Site Power is available, (normal plant configuration – no degraded voltage condition), the highest load reached was 3178.3 amps on Buses 2A/3A for a Large Break LOCA accident. This load is a peak load, and at the end of the scenario the Bus loading is 2550.2 amps (2757 amps under degraded voltage conditions).

** In all the accident scenarios where Off-Site Power is available, (normal plant configuration – no degraded grid voltage condition), the highest steady state load reached 2891.6 amps (3126 amps under degraded grid voltage conditions) on Bus 5A for a Large Break LOCA accident.

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 9 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

3.0 SUMMARY/CONCLUSIONS (Continued)

LOSS OF OFF SITE POWER (LOOP)

Worst Case Accident Scenarios	Peak Loading on EDGs	Steady State Loading on EDGs
Peak Load* Large Break LOCA EDG 31 (Bus 2A/3A) not available.	EDG 32 (Bus 6A) 1895.6 kW	 <i>(At the end of this scenario the loading on EDG 32 is down to 1580 kW)</i>
Steady State** Large Break LOCA EDG 32 (Bus 6A) not available.	EDG 33 (Bus 5A) <i>(Peak loading never exceeds 1950 kW)</i>	EDG 33 (Bus 5A) 1674.7 kW

* The Worst Case Peak loading during a LOOP occurs on EDG 32 for a Large Break LOCA with loss of EDG 31 (Bus 2A/3A). This accident results in a peak load of 1895.6 kW (1873.5 kW plus cable losses of 22.1 kW, Ref. Appendix E-1). This loading on the EDG lasts for less than 30 minutes. The time is validated in NSE 99-3-075 Rev.0 section 4.2.20, which states that the duration of possible spray operation is limited by the inventory in the RWST (60,000 gallons). A single Containment Spray Pump (CSP) would deliver that inventory in less than 30 minutes. During this scenario both CSPs start about 1 minute after the LOOP. Loading on EDG 32 drops to 862 kW before the last CSP is stopped therefore EDG 32 was operating at 1895.6 kW for less than 30 minutes which is within the EDG's 2 hour 1950 kW design rating. At the end of the scenario, EDG 32 is at a steady state load of 1580 kW.

** The Worst Case Steady state loading occurs on EDG 33 during a Large Break LOCA with loss of EDG 32 (Bus 6A). This scenario results in a steady state continuous load of 1674.7 kW (1651.6 plus cable losses of 23.1 kW, Ref. Appendix E-2) on EDG 33.

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8

Project: Electrical Load Study Page 10 of 69

Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

3.0 SUMMARY/CONCLUSIONS (Continued)

CONCLUSION

- Single Failure:

Where single failure of entire Bus or EDG is assumed no overloading conditions exist during the final manual recovery phase of any accident scenario. In all the scenarios analyzed where a Bus/EDG failure is not postulated, a single failure of any piece of equipment (such as a FCU or AWFPP) will not result in an overload condition on any Bus or EDG.

- Effect of Generator Frequency Variation on EDG Loading:

For the two bounding cases identified above an analysis was performed in Section 7.0 of this calculation to determine what effect a frequency deviation on the EDGs would have on loading. In both cases, which happen to be beyond Design Basis (Double Failure), the EDG design ratings were not exceeded.

- EDG Loading:

The Worst case EDG (32) loading of kW may reach 1915.15 kW if generator frequency variation is considered. Even under this condition, EDG 32 would be within its design ratings. In none of the accidents do any of the EDGs exceed the 1750 kW continuous rating after the two hour steady state plant condition is reached.

- 480V Bus loading with Offsite power available:

Engineering calculations IP3-CALC-ED-00301, 00302 and IP3-NSE-93-3-427, Rev.0 have determined that the 480V Buses, supply breakers and station service transformer can function properly for a continuous load of 3600 amps up to 4 hours. This evaluation of bus, supply breaker and transformer overload capabilities has also shown that the buses, breakers and transformers can withstand a peak load of 4400 Amps for 5 minutes.

Worst case peak loading (3436 Amps) occurs based on the most conservative assumptions. Station Service Transformer No.3 is lost resulting in Buses 2A & 3A being tied with loss of Bus 6A (single failure) and Bus 5A is at a degraded voltage of 444 Volts (double failure). This bounding case does not exceed the Bus supply breaker minimum overcurrent trip pickup values of 3600 Amps. Therefore, this potential but highly unlikely overload condition will not result in overcurrent tripping of the 480V Bus Supply Breakers and subsequent lockout of EDG Breakers and Bus Tie Breaker 52/2AT3A.

Nuclear Engineering
CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8

Project: Electrical Load Study Page 11 of 69

Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

3.0 SUMMARY/CONCLUSIONS (Continued)

The conclusion of this calculation is that the latest revision to the EOPs and SOPs maintains loading within the 480V Electrical Distribution System design loading limits. The electrical distribution equipment will perform their required safety functions during a Design Basis Accident. Section 8.0 clearly demonstrates this conclusion.

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8

Project: Electrical Load Study Page 12 of 69

Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

4.0 REFERENCES

1. Westinghouse Diesel Generator Final Load Study, dated June 5, 1989.
2. ARP-5, Rev. 21, Panel SBF-2 Safeguards.
3. NYPA Calculations/Studies:
 - (1) IP3-CALC-MULT-00365, Rev. 0 BHP Requirements of Pumps and Fans.
 - (2) IP-CALC-04-00809, Rev. 2, Brake Horsepower Values Related to Certain Pumps and Fans for EDG Electrical Loading.
 - (3) IP3-CALC-EL-00185, Rev. 2, Component Sizing-125V DC-32 Battery, Charger, Panels and Cables.
 - (4) IP3-CALC-EL-00184, Rev. 2, 31 Battery, Charger, Associated Panels and Cables Component Sizing.
 - (5) IP3-CALC-EL-00186, Rev. 3, 33 Battery, Charger, Associated Panels and Cables Component Sizing and Voltage Drop Calculations.
 - (6) IP3-CALC-EL-00187, Rev. 1, Component Sizing -125V DC-34 Battery, Charger, Panels and Cables.
 - (7) IP3-CALC-ED-00297, Rev. 2, 480 Volt Buses 2A, 3A, 5A and 6A Degraded Voltage Relay Setpoint Calculation.
 - (8) IP3-CALC-EL-01972, Rev. 0, 1997 Update of IP3 Degraded Grid Voltage Study.
 - (9) IP3-CALC-ED-00201, Rev. 2, 480V Buses 2A, 3A, 5A and 6A Loading (Non-Accident).
 - (10) IP3-CALC-ED-00300 Rev. 1, 00301 Rev. 1 and 00302 Rev. 3, 480V SWGR and Transformer Calculation.
 - (11) UE&C Calculation 6604.346-6-PAB-001 Rev. 2, PAB Ventilation System Analysis without the Supply Fan.
 - (12) IP3-NSE-99-03-004, Rev. 0, EDGs Short-Term Capacity Rating Clarification.

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8

Project: Electrical Load Study Page 14 of 69

Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

4.0 REFERENCES (Continued)

5. Industry Standards:

- (1) ANSI/NEMA MG-1 - 1978 (Rev. 1982) "Motors and Generators"
- (2) Motor Data Sheets (Appendix A)
- (3) GNB Technologies fax dated October 22, 1997 providing battery float current value. (Appendix D)
- (4) K.J Nelson (NYPA) - C. Reichert (Exide) telecom dated 2-3-1992. "Battery Charger Efficiencies". (Appendix D)
- (5) Letter from Worthington Corporation to UE&C confirming emergency diesel ratings, dated December 24, 1968 (Appendix C)

5.0 AFFECTED SYSTEMS/COMPONENTS/DOCUMENTS

480V Buses 2A, 3A, 5A and 6A
Station Service Transformers 2, 3, 5 and 6
Emergency Diesel Generators 31, 32 and 33

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 15 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS

AUTO SI MCCs LOADS

MCC 36A LOAD SUMMARY (BUS 5A-EDG 33)

<u>Load</u>	<u>kW</u>	<u>kVA</u>	<u>hp</u>	<u>Comments</u>
31 Electrical Tunnel Exhaust Fan (EL. 34')	6.2	---	7.5	Lower Tunnel Fan; Auto Restart on High Temp; 1FB; 9321-LL-31263 sht 6
31 CCR Air Conditioner	12.4	---	15.0	2-7.5hp Compressors; Auto Restart; 6FB; 9321-LL-31263 sht 9.
31 CCR A/C Fan	4.2	---	5.0	Auto Restart when Damper "D1" opens; 6FB; 9321-LL-31263 sht 11.
31 CCR A/C Filter Booster Fan	1.25	---	1.5	Auto Start when Damper "F1" opens; 6FD; 9321-LL-31263 sht 15
33 Electrical Tunnel, Exhaust Fan (EL. 46')	6.2	---	7.5	Upper Tunnel Fan; Auto Restart on High Temp; 7FB; 9321-LL-31263, sht 6
SW Strainer 31, 33 & 35	---	---	---	0.5 hp (0.9kW) per strainer. Operates 5 minutes every 2hours when its SW pump is running. (Due to the load value and frequency operation, the load generated is transient similar to MOV operation.)

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 16 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

AUTO SIMCCs LOADS (Continued)

MCC 36A LOAD SUMMARY (BUS 5A-EDG 33) (Continued)

<u>Load</u>	<u>kW</u>	<u>kVA</u>	<u>hp</u>	<u>Comments</u>
Plant Vent Rad Monitor R-27	---	2.5	---	Auto Restart 5 kVA Transformer (Feeder); 8FKL Load: 2.5 kVA kW = 2.5 x 1.0 = 2.5
Distribution Panel POH	---	5.76	---	Auto Restart 25 kVA Transformer 4-15 Amp Ckts. Used - Assumed 80% Breaker Rating 9321-LL-30412 Sht. 165 Load: 5.76kVA kW = 5.76 x 1.0 = 5.76
CCW Booster Pump 31	4.2		5.0	Auto Starts on SI; 5RK;(9321-05- 3307 sht 58) 500B971 sht 51
Rad. Monitors A/C Panel (PAB EL. 55')	7.5		---	Auto Restart 1 Exist + 1 New Temp A/C Unit (Ref. Temp Mod. No. 90-26110-12); 8 FKR
Boric Acid Heat Tracing (Normal Feed)	14.8		---	Auto Restart (Feeder); 6RF; 9321-LL-30412 Sht. 152, Sht. 153, Sht. 154 & Sht. 155 Total Load = 14.8kW

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 17 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

AUTO SI MCCs LOADS (Continued)

MCC 36A LOAD SUMMARY (BUS 5A-EDG 33)(Continued)

<u>Load</u>	<u>kW</u>	<u>kVA</u>	<u>hp</u>	<u>Comments</u>
CCW Booster Pump 32	4.2	---	5.0	Auto Start on SI; 7RB; (9321-05-3307 R58) 500B971 sht 85.
31 Boric Acid Transfer Pump (BAST)	12.4	---	Fast-15	Manual restart required; 7RH Drawing No. 500B971 Sheet 53, Dual Speed
Control Building Exhaust Fan 33	---	9.8	10.0	Auto Start on High Temp; 9RF, 9321-LL-31293 Sht. 4 Load: $\frac{(10\text{hp})(.746)}{(.85\text{pf})(.90\text{eff})} = 9.8\text{kVA}$ $\text{kW} = 9.8 \times .85 = 8.33$

TOTALS:

<u>For Offsite Power Available</u>	<u>For Loss of Offsite Power (EDG)</u>
$\text{kVA} = (2.5 + 5.76 + 9.8) \text{ kVA} + \frac{(30.3 + 26.5 + 16.6)\text{kW}}{.85^*}$ $= 104.4$	89.9kW
$\text{Amp} = \frac{104.4 \text{ kVA}}{\sqrt{3} \times .4366 \text{ kV}} = 138.4$	

(*Assumed pf of MCC 36A Loads)

**Nuclear Engineering
CALCULATION SHEET**

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 18 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

AUTO SI MCCs LOADS(Continued)

MCC 36B LOAD SUMMARY (BUS 6A-EDG 32)

<u>Load</u>	<u>kW</u>	<u>kVA</u>	<u>hp</u>	<u>Comments</u>
32 Electrical Tunnel Exhaust Fan (EL. 34')	6.2	---	7.5	Lower Tunnel Fan Auto Restart on High Temp; 1FB; 9321-LL-31263 sht 3
32 CCR Air Conditioner	12.4	---	15.0	2-7.5hp Compressors; Auto Restart; 6FB; 9321-LL-31263 sht 10.
32 CCR A/C Fan	4.2	---	5.0	Auto Restart when Damper "D2" opens; 6FB; 9321-LL-31263, sht 13
32 CCR A/C Filter Booster Fan	1.25	---	1.5	Auto Starts when Damper "F2" opens; 6FD; 9321-LL-31263, sht 15A
SW Strainers 32, 34 & 36	---	---	---	0.5 hp (0.9kW) per strainer. Operates 5 minutes every 2hours when its SW pump is running. (Due to the load value and frequency operation, the load generated is transient similar to MOV operation.)

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 19 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

AUTO SIMCCs LOADS (Continued)

MCC 36B LOAD SUMMARY (BUS 6A-EDG 32) (Continued)

<u>Load</u>	<u>kW</u>	<u>kVA</u>	<u>hp</u>	<u>Comments</u>
34 Electrical Tunnel Exhaust Fan (EL. 46')	6.2	---	7.5	Upper Tunnel Fan; Auto Restart on High Temp; 7FB; 9321-LL-31263, sht. 7
CCW Booster Pump 33	4.2	---	5.0	Starts on SI; 5RK; (9321-05-03307 R58) 500B971 sht 51.
CCW Booster Pump 34	4.2	---	5.0	Starts on SI; 7RB; (9321-05-03307 R58) 500B971 sht 85.
H2 Recombiner 32	*75	---	---	Optional Manual Load No Auto Start (Ref. Mod. 91-03-098HR, IP3-ECCF-004, Rev 0. Sht. 16 of 40)

* H2 Recombiner 32 is energized during the manual recovery stage.
(See Section 8)

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 20 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

AUTO SI MCCs LOADS (Continued)

MCC 36B LOAD SUMMARY (BUS 6A-EDG 32) (Continued)

<u>Load</u>	<u>kW</u>	<u>kVA</u>	<u>hp</u>	<u>Comments</u>
PA System	---	9.0	---	Auto Restart 9kVA power supply; (Feeder); 6RBL Load: 9kVA $kW = 9 \times 1$ $= 9.0$
D/G Building Lighting Lighting Panel 323	---	21.26	---	Auto Restart 30 kVA transformer approximately 20.2kW load; 9321-LL-30412 Sht. 35; Feeder; 6RBR $kVA = 20.2/0.95 = 21.26$
32 Boric Acid Transfer (BAST)	12.4	---	Fast-15	Manual Restart Required; 7RH; Drawing No. 500B971 Sht. 53

TOTALS: For Offsite Power Available For Loss of Offsite Power (EDG)

$$\begin{aligned}
 \text{kVA} &= (9 + 21.26)\text{kVA} + \frac{(24.1 + 14.6 + 12.4)\text{kW}}{.85^*} && 80.25 \text{ kW} \\
 &= 90.3
 \end{aligned}$$

$$\text{Amps} = \frac{90.3 \text{ kVA}}{\sqrt{3} \times .4383 \text{ kV}} = 119.2$$

(*Assumed pf of MCC 36B Loads)

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 21 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

AUTO SI MCCs LOADS (Continued)

MCC 36C LOAD SUMMARY (BUS 2A-EDG 31)

<u>Load</u>	<u>kW</u>	<u>kVA</u>	<u>hp</u>	<u>Comments</u>
Battery Charger 33***	---	9.7	---	<p>(Feeder 1BL) Continuous load (DC AMP) =59.64 at Equalize (DC) Voltage = 139.8V (Section 4, Ref. 3.5)</p> <p>The battery is under normal equilibrium conditions at the time of loss of offsite power. Battery Charger 33 is automatically reset/energized. Therefore the battery will see only a momentary (less than 1 minute) loss of charging current and subsequent discharge. Upon reenergization of the MCC, the charger will supply the DC load current plus battery float charge current. The battery float current under these conditions is 0.25 AMP (Section 4, Ref. 5.3).</p> <p>Charger DC Amps =59.64+0.25 =59.89</p> <p>kW Load(480)=$\frac{59.89 \times (139.8 \text{ VDC})}{1000}$ (.91**) =9.2 kW</p> <p>kVA Load(480) =9.2/(.95*)=9.7kVA</p>

*** Battery Charger 35 can be used in lieu of BC33 with no change to loading on EDG 31 (Ref. IP3-ECCF-728).

*power factor 0.95 assumed
 **eff. = .91 per Section 4, Ref. 5.4

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 22 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

AUTO SI MCCs LOADS (Continued)

MCC 36C LOAD SUMMARY (BUS 2A-EDG 31) (Continued)

<u>Load</u>	<u>kW</u>	<u>kVA</u>	<u>hp</u>	<u>Comments</u>
H ₂ Recombiner 31	*75	---	---	Optional Manual Load - No Auto Start (MOD No. 91-03-098HR, IP3-ECCF-004, Rev. 0, sht. 16 of 40) - 3M
PBX Phone System	---	15	---	Load as per Drawing No. 9321-F-30063; 1FR Load: 15kVA kW = 15 x 1.0 = 15
Instrument Buses 34 and 34A	---	7.5	---	7.5kVA SOLA XFMR Backup to Load as per Drawing No. 9321-F-39893; (Feeder); 2BR. Instrument Buses on MCC 32 are reset as per SOP-EL-15. For conservatism, this load is considered on both MCCs. Load: 5.3kVA (actual load)
31 EDG Cell Exhaust Fans 314 & 315	16.6		20.0	Autostart High Temp. Runs Periodically above 95° F; 1M and 4M
31 EDG Crankcase Exhaust Fan (XMFR)	---	1.0	---	Load as per Drawing No. 9321-F-30063; (Feeder); 1BR/1D Load: 1kVA kW = 1 x 1.0 = 1.0

* H2 Recombiner 31 is energized during the manual recovery stage. (See section 8)

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 23 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

AUTO SI MCCs LOADS (Continued)

MCC 36C LOAD SUMMARY (BUS 2A-EDG 31) (Continued)

<u>Load</u>	<u>kW</u>	<u>kVA</u>	<u>hp</u>	<u>Comments</u>
Rod Position Indicating System	---	5.0	---	Load as per Drawing No. 9321-F-30063; (Feeder); 2BL Load: 5.0kVA kW = 5 x 1.0 = 5
31 EDG Fuel Oil Transfer Pump	---	2.9	3.0	Load as per Drawing No. 9321-F-30063; (Feeder); 1FL Load = $(3.0 \text{ hp})(.746) = 2.9 \text{ kVA}$ $(.85*)(.90*)$ kW = kVA x pf = (2.9) (.85) = 2.5
Control Building Exhaust Fan 34	---	9.8	10.0	Load: $(10 \text{ hp})(.746) = 9.8 \text{ kVA}$ $(.85*)(.90*)$ kW = 9.8 x .85 = 8.33

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 24 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

AUTO SI MCCs LOADS (Continued)

MCC 36C LOAD SUMMARY (BUS 2A-EDG 31) (Continued)

<u>Load</u>	<u>kW</u>	<u>kVA</u>	<u>hp</u>	<u>Comments</u>
Control Building Lighting (Panels 320 and 39)	---	33.8	---	Load; (32.12kW) per 9321-30412 Sht. 7 and Sht. 10. Load: 32.12 kW $\text{kVA} = \frac{\text{kW}}{\text{pf}} = \frac{32.12 \text{ kW}}{.95^{**}}$ $= 33.8 \text{ kVA}$

TOTALS:	<u>For Offsite Power Available</u>	<u>For Loss of Offsite Power (EDG)</u>
	$\text{kVA} = (84.7) \text{ kVA} + \frac{(16.6) \text{ kW}}{.85^*} = 104.2$	94.23 kW
	$\text{Amp} = \frac{104.2 \text{ kVA}}{\sqrt{3} \times 0.444 \text{ kV}} = 135.5$	

(*Assumed pf = .85, eff = .90; ** Assumed pf = 0.95 for lighting loads)

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 25 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

AUTO SIMCCs LOADS (Continued)

MCC 36D LOAD SUMMARY (BUS 6A-EDG32)

<u>Load</u>	<u>kW</u>	<u>kVA</u>	<u>hp</u>	<u>Comments</u>
32 EDG Cell Exhaust Fans 316 & 317	16.6	---	20	Auto Start on High Temp. Runs periodically above 95° F
32 EDG crank case Exhaust Fan (XMFR)	---	1.0	---	Load as per Drawing No. 9321-F-30063 sht. 2 Load: 1kVA kW = 1 x 1.0 = 1.0
32 EDG Fuel Oil Transfer Pump	---	2.9	3.0	Load as per Drawing No. 9321-F-30063, sht. 2 Load = $(3.0 \text{ hp})(.746) = 2.9 \text{ kVA}$ $(.85*)(.90*)$ kW = kVA x pf = (2.9) (.85) = 2.5
480 - 208/120 VAC 15 kVA Transformer	---	---	---	Load only actuated when CO2 system is actuated, 1.2kVA Actual Load (Ref. MMP 97-03-400FP)

TOTALS: For Offsite Power Available

$$\text{kVA} = (2.9 + 1.0) \text{ kVA} + \frac{(16.6) \text{ kW}}{.85 *} = 23.43$$

$$\text{Amps} = \frac{23.43 \text{ kVA}}{\sqrt{3} \times 0.4383 \text{ kV}} = 30.9$$

For Loss of Offsite Power (EDG)

20.1 kW

(*Assumed pf = .85, eff = .90)

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 26 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

AUTO SI MCCs LOADS (Continued)

MCC 36E LOAD SUMMARY (BUS 5A-EDG33)

<u>Load</u>	<u>kW</u>	<u>kVA</u>	<u>hp</u>	<u>Comments</u>
33 EDG Cell Exhaust Fans 318 & 319	16.6	---	20.0	Auto Start on High Temp. Runs periodically above 95° F
33 EDG crank case Exhaust Fan (XMFR)	---	1.0	---	Load as per Drawing No. 9321-F-30063 sht. 2 Load: 1kVA kW = 1 x 1.0 = 1.0
33 EDG Fuel Oil Transfer Pump	---	2.9	---	Load as per Drawing No. 9321-F-30063, sht. 2 Load = $(3.0 \text{ hp})(.746) = 2.9 \text{ kVA}$ $(.85*)(.90*)$ kW = kVA x pf = (2.9) (.85) = 2.5

TOTALS: For Offsite Power Available For Loss of Offsite Power (EDG)

kVA = $(2.9 + 1.0) \text{ kVA} + \frac{(16.6) \text{ kW}}{.85*} = 23.43$ 20.1 kW

Amps = $\frac{23.43 \text{ kVA}}{\sqrt{3} \times 0.4366 \text{ kV}} = 31.1$

(*Assumed pf = .85, eff = .90)

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 27 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

SOP-EL-15 MCC RESET LOADS

MCC 32 (BUS 3A-EDG 31)

* BATTERY CHARGER 34; 7BR :

Battery charger 34 is not powered from an Auto SI MCC. The charger is not automatically reset and requires a manual reset per SOP-EL-15. The time required to reset MCC 32 is estimated to be within 15 minutes. After the 15 min discharge duration the battery voltage change is considered negligible and the continuous load current on the charger would remain constant.

According to calculation IP3-CALC-EL-00187 Rev.1 (Section 4, Ref. 3.6)
 Battery in normal continuous load:

Voltage in Float Mode	= 132.0 V (Section 4, Ref. 3.6)
Efficiency	= 0.91 (Section 4, Ref. 5.4)
Power Factor	= 0.95 (Conservative Assumption)
Power Panel 34 Continuous	= 77.8 A (Section 4, Ref. 3.6)
Load Current @ 125V	
Power Panel 34 Continuous	= 77.8 A x $\frac{132.0 \text{ V}}{125.0 \text{ V}}$ = 82.2 A
Load Current @ 132.0V	
DC Load (kW)	= $\frac{82.2 \text{ A} \times 132.0 \text{ V}}{1000}$ = 10.9 kW
AC Load (kW)	= $\frac{10.9 \text{ kW}}{0.91}$ = 12.0 kW
	kVA = $\frac{12.0 \text{ kW}}{0.95}$ = 12.6
AC Load (Amps)	= $\frac{12.6 \text{ kVA} \times 1000}{1.73 \times 437.9}$ = 16.6 A

* Battery Charger 35 can be used in lieu of BC 34 with a reduction in loading on EDG-31, (Ref. IP3-ECCF-728).

**Nuclear Engineering
CALCULATION SHEET**

Calculation No. IP3-CALC-ED-00207 Revision 8

Project: Electrical Load Study Page 28 of 69

Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

SOP-EL-15 MCC RESET LOADS

MCC 32 (BUS 3A-EDG 31) (Continued)

MAIN GEN. AIR SIDE SEAL OIL PUMP; 2D :

Load = 50 hp, pf = .85, eff = .90; per Section 4, Ref. 4.3,
and Ref. 3.9 attached Load List

$$\text{kVA} = \frac{50 \text{ hp} \times .746}{(.85 \text{ pf} \times .90 \text{ eff})} = 48.8$$

$$\text{kW} = (48.8 \text{ kVA})(.85 \text{ pf}) \\ = 41.5$$

$$\text{Amps} = \frac{41.5 \text{ kW}}{1.73 \times 0.4379 \text{ kV} \times 0.85} \\ = 64.4$$

MAIN BOILER FEED PUMP, MAIN OIL PUMP 31; 7M :

Load = 57.3 kVA, pf = .85; per Section 4, Ref. 3.9 attached Load List

$$\text{kW} = (57.3 \text{ kVA})(.85 \text{ pf}) \\ = 48.7$$

$$\text{Amps} = \frac{48.7 \text{ kW}}{1.73 \times 0.4379 \text{ kV} \times 0.85} \\ = 75.6$$

**Nuclear Engineering
CALCULATION SHEET**

Calculation No. IP3-CALC-ED-00207 Revision 8
Project: Electrical Load Study Page 29 of 69
Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

SOP-EL-15 MCC RESET LOADS (Continued)

MCC 33 (BUS 2A-EDG 31)

MAIN BOILER FEED PUMP, MAIN OIL PUMP 32; 7M :

Load = 57.3 kVA, pf = .85; per Section 4, Ref. 3.9 attached Load List

kW = (57.3 kVA) (.85 pf)
= 48.7

Amps = $\frac{48.7 \text{ kW}}{\sqrt{3} \times 0.437 \text{ kV} \times 0.85}$
= 75.6

MCC 34 (BUS 2A-EDG 31)

INSTRUMENT AIR COMPRESSOR 32; 1G :

Load = 52.4 kVA, pf = .85; per Section 4, Ref. 3.9 attached Load List

kW = (52.4 kVA) (.85 pf)
= 44.5

Amps = $\frac{44.5 \text{ kW}}{1.73 \times 0.4416 \text{ kV} \times 0.85}$
= 68.5

**Nuclear Engineering
CALCULATION SHEET**

Calculation No. IP3-CALC-ED-00207 Revision 8

Project: Electrical Load Study Page 30 of 69

Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

SOP-EL-15 MCC RESET LOADS (Continued)

MCC 34 (BUS 2A-EDG 31)(Continued)

INSTRUMENT CLOSED COOLING PUMP 32; 3M :

Load = 2.4 kVA, pf = .85; per Section 4, Ref. 3.9 attached Load List

$$\text{kW} = (2.4 \text{ kVA}) (.85 \text{ pf}) = 2.0$$

$$\text{Amps} = \frac{2 \text{ kW}}{1.73 \times 0.4416 \text{ kV} \times 0.85} = 3.1$$

EDG AIR COMPRESSOR 31; 6DL:

Load = 5 hp, pf = .85, eff = .90; per Section 4, Ref. 4.3 and Ref. 3.9

$$\text{kVA} = \frac{5 \text{ hp} \times .746}{.85 \text{ pf} \times .90 \text{ eff}} = 4.88$$

$$\text{kW} = (4.88 \text{ kVA}) (.85 \text{ pf}) = 4.15$$

$$\text{AMPS} = \frac{4.15 \text{ kW}}{(\sqrt{3})(.4416 \text{ kV})(.85 \text{ pf})} = 6.38$$

EDG EXHAUST HOOD BLOWER 31; 6DL:

Load = ¾ hp, pf = .85, eff = .90; per Section 4, Ref. 4.3 and 3.9

$$\text{kVA} = \frac{.75 \text{ hp} \times .746}{.85 \text{ pf} \times .90 \text{ eff}} = .73$$

$$\text{kW} = (.73 \text{ kVA}) (.85 \text{ pf}) = .62$$

$$\text{AMPS} = \frac{.62 \text{ kW}}{(\sqrt{3})(.4416 \text{ kV})(.85 \text{ pf})} = .95$$

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
Project: Electrical Load Study Page 31 of 69
Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

SOP-EL-15 MCC RESET LOADS (Continued)

MCC 35 (BUS 3A-EDG 31)

MAIN TURBINE BEARING OIL PUMP; 4M :

Load = 75 hp, pf = .85 eff = .90; per Section 4, Ref. 4.3
and Ref. 3.9 attached Load List

$$\text{kVA} = \frac{75 \text{ hp} \times .746}{.85 \text{ pf} \times .90 \text{ eff}} = 73.1$$

$$\text{kW} = (73.1 \text{ kVA}) (.85 \text{ pf})$$
$$= 62.1$$

$$\text{Amps} = \frac{62.1 \text{ kW}}{\sqrt{3} \times 0.439 \text{ kV} \times 0.85}$$
$$= 96.0$$

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 32 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

SOP-EL-15 MCC RESET LOADS (Continued)

MCC 37 (BUS 6A-EDG32)

* BATTERY CHARGER 32: IFL

Battery charger 32 is not powered from an Auto SI MCC. The charger is not automatically reset and requires a manual reset per SOP-EL-15. The time required to reset MCC 37 is estimated to be within 15 minutes. After the 15 min discharge duration the battery voltage change is considered negligible and the continuous load current on the charger would remain constant.

According to calculation IP3-CALC-EL-00185 Rev.2 (Section 4, Ref. 3.3)
 Battery in normal continuous load:

Voltage in Float Mode	= 130.5 V (Section 4, Ref. 3.3)
Efficiency	= 0.92 (Section 4, Ref. 5.4)
Power Factor	= 0.95 (Conservative Assumption)
Power Panel 32 Continuous Load Current @ 125V	= 129.4 A (Section 4, Ref. 3.3)
Power Panel 32 Continuous Load Current @ 130.5V	= $129.4 \text{ A} \times \frac{130.5 \text{ V}}{125.0 \text{ V}} = 135.1 \text{ A}$
DC Load (kW)	= $\frac{135.1 \text{ A} \times 130.5 \text{ V}}{1000} = 18.0 \text{ kW}$
AC Load (kW)	= $\frac{18.0 \text{ kW}}{0.92} = 20.0 \text{ kW}$
	kVA = $\frac{20.0 \text{ kW}}{0.95} = 21.1 \text{ kVA}$
AC Load (Amps)	= $\frac{21.1 \text{ kVA} \times 1000}{1.73 \times 441.8} = 27.6 \text{ A}$

* Battery Charger 35 can be used in lieu of BC 32 with no affect on EDG 32 loading (Ref. IP3-ECCF-728).

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8

Project: Electrical Load Study Page 33 of 69

Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

SOP-EL-15 MCC RESET LOADS (Continued)

MCC 37 (BUS 6A-EDG 32)(Continued)

EDG AIR COMPRESSOR 32; 7FMR:

Load = 5 hp, pf = .85, eff = .90; per Section 4, Ref. 4.3 and Ref. 3.9

$$\text{kVA} = \frac{5 \text{ hp} \times .746}{.85 \text{ pf} \times .90 \text{ eff}} = 4.88$$

$$\text{kW} = (4.88 \text{ kVA})(.85 \text{ pf}) = 4.15$$

$$\text{AMPs} = \frac{4.15 \text{ kW}}{(\sqrt{3})(.4418 \text{ kV})(.85 \text{ pf})} = 6.38$$

EDG EXHAUST HOOD BLOWER 32; 7FMR:

Load = ¾ hp, pf = .85, eff = .90; per Section 4, Ref. 4.3 and 3.9

$$\text{kVA} = \frac{.75 \text{ hp} \times .746}{.85 \text{ pf} \times .90 \text{ eff}} = .73$$

$$\text{kW} = (.73 \text{ kVA})(.85 \text{ pf}) = .62$$

$$\text{AMPs} = \frac{.62 \text{ kW}}{(\sqrt{3})(.4418 \text{ kV})(.85 \text{ pf})} = .95$$

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
Project: Electrical Load Study Page 34 of 69
Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

SOP-EL-15 MCC RESET LOADS (Continued)

MCC 39 (BUS 5A-EDG 33)

IA COMPRESSOR 31; 3M :

Load = 60 hp, pf = .85, eff = .90; per Section 4, Ref. 4.4 and Ref. 3.9
attached Load List

$$\text{kVA} = \frac{60 \text{ hp} \times .746}{.85 \text{ pf} \times .90 \text{ eff}} = 58.5$$

$$\begin{aligned} \text{kW} &= (58.5 \text{ KVA}) (.85 \text{ pf}) \\ &= 49.7 \end{aligned}$$

$$\begin{aligned} \text{Amps} &= \frac{49.7 \text{ kW}}{1.73 \times 0.4434 \text{ kV} \times 0.85} \\ &= 76.2 \end{aligned}$$

IA CLOSED COOLING PUMP 31; 4K :

Load = 2.4 kVA, pf = .85, eff = .90; per Section 4, Ref. 3.9
attached Load List

$$\begin{aligned} \text{kW} &= (2.4 \text{ kVA}) (.85 \text{ pf}) \\ &= 2.0 \end{aligned}$$

$$\begin{aligned} \text{Amps} &= \frac{2 \text{ kW}}{1.73 \times 0.4434 \text{ kV} \times 0.85} \\ &= 3.1 \end{aligned}$$

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
Project: Electrical Load Study Page 35 of 69
Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

SOP-EL-15 MCC RESET LOADS (Continued)

MCC 39 (BUS 5A-EDG33)(Continued)

EDG AIR COMPRESSOR 33

Load = 5 hp, pf = .85, eff = .90; per Section 4, Ref. 4.3 and Ref. 3.9

$$\text{kVA} = \frac{5 \text{ hp} \times .746}{.85 \text{ pf} \times .90 \text{ eff}} = 4.88$$

$$\text{kW} = (4.88 \text{ kVA})(.85 \text{ pf}) = 4.15$$

$$\text{AMPs} = \frac{4.15 \text{ kW}}{(\sqrt{3})(.4434 \text{ kV})(.85 \text{ pf})} = 6.36$$

EDG EXHAUST HOOD BLOWER 33

Load = ¼ hp, pf = .85, eff = .90; per Section 4, Ref. 4.3 and 3.9

$$\text{kVA} = \frac{.75 \text{ hp} \times .746}{.85 \text{ pf} \times .90 \text{ eff}} = .73$$

$$\text{kW} = (.73 \text{ kVA})(.85 \text{ pf}) = .62$$

$$\text{AMPs} = \frac{.62 \text{ kW}}{(\sqrt{3})(.4434 \text{ kV})(.85 \text{ pf})} = .95$$

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 36 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

SOP-EL-15 MCC RESET LOADS (Continued)

MCC 39 (BUS 5A-EDG 33) (Continued)

* BATTERY CHARGER 31; 5F:

Battery charger 31 is not powered from an Auto SI MCC. The charger is not automatically reset and requires a manual reset per SOP-EL-15. The time required to reset MCC 39 is estimated to be within 15 minutes. After the 15 min discharge duration the battery voltage change is considered negligible and the continuous load current on the charger would remain constant.

According to calculation IP3-CALC-EL-00184 Rev.2 (Section 4, Ref. 3.4)
 Battery in normal continuous load:

Voltage in Float Mode	= 130.5 V (Section 4, Ref. 3.4)
Efficiency	= 0.92 (Section 4, Ref. 5.4)
Power Factor	= 0.95 (Conservative Assumption)
Power Panel 31 Continuous Load Current @ 125V	= 195.2 A (Section 4, Ref. 3.4)
Power Panel 31 Continuous Load Current @ 130.5V	= $195.2 \text{ A} \times \frac{130.5 \text{ V}}{125.0 \text{ V}} = 203.8 \text{ A}$
DC Load (kW)	= $\frac{203.8 \text{ A} \times 130.5 \text{ V}}{1000} = 27.0 \text{ kW}$
AC Load (kW)	= $\frac{27.0 \text{ kW}}{0.92} = 29.3 \text{ kW}$
	kVA = $\frac{29.3 \text{ kW}}{0.95} = 30.8$
AC Load (Amps)	= $\frac{30.8 \text{ kVA} \times 1000}{1.73 \times 443.4} = 40.2 \text{ A}$

* Battery Charger 35 can be used in lieu of BC 31 with no affect on EDG 33 loading (Ref. IP3-ECCF-728).

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 37 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

STATION AUX. TRANS. AUXILIARIES (EMERG.); 2BR:

Load = 22.4 kVA, pf = .95; per Section 4, Ref. 3.9 attached Load List

kW = (22.4 kVA) (.95 pf) = 21.3

Amps = $\frac{21.3 \text{ kW}}{1.73 \times 0.4434 \text{ kV} \times 0.95} = 29.2$

SUMMARY OF SOP-EL-15 MCC RESET LOADS WITH OFFSITE POWER AVAILABLE (Per Attachment 2 of SOP-EL-15)

<u>BUS 2A</u>	<u>Amps</u>
MCC 33 MBFP Main Oil Pump 32	75.6
MCC 34 32 Instrument Air Compressor	68.5
32 Instrument Air Closed Cooling Pump	3.1
31 EDG Air Compressor	6.4
31 EDG Exhaust Hood Blower	1.0*
<u>BUS 3A</u>	
MCC 32 Main Generator Air Side Seal Oil Pump	64.4
MBFP Main Oil Pump 31	75.6
34 Battery Charger	16.6
MCC 35 Main Turbine Bearing Oil Pump	96.0

* Not required during DBA but must be energized per design in order to reset required air compressor load.

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 38 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

SUMMARY OF SOP-EL-15 MCC RESET LOADS WITH LOSS OF OFFSITE POWER (Per Attachment 1 of SOP-EL-15)

<u>BUS 2A</u>	<u>kW</u>
MCC 34 EDG Air Compressor 31	4.15
EDG Exhaust Hood Blower 31	.62
Instrument Air Compressor 32	44.5
Instrument Closed Cooling Pump 32	2.0
<u>BUS 3A</u>	
MCC 32 Battery Charger 34	12.0
<u>BUS 5A</u>	
MCC 39 Battery Charger 31	29.3
EDG Air Compressor 33	4.15
EDG Exhaust Hood Blower 33	.62*
Instrument Air Compressor	49.7
Instrument Air Closed Cooling Pump 31	2.0
<u>BUS 6A</u>	
MCC 37 Battery Charger 32	20.0
EDG Air Compressor 32	4.15
EDG Exhaust Hood Blower 32	.62*

* Not required during DBA but must be reset per design in order to reset required air compressor load.

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
Project: Electrical Load Study Page 39 of 69
Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

SPECIFIC PROCEDURAL ACTUATED MCC LOADS

BUS 2A (EDG 31) - MCC 34

MAIN TURBINE TURNING GEAR; 1M :

Load = 50 hp, pf = .85 eff = .90; per Section 4, Ref. 4.3 and 3.9

$$\text{kVA} = \frac{50 \text{ hp} \times .746}{.85 \text{ pf} \times .90 \text{ eff}} = 48.8$$

$$\text{kW} = (48.8) (.85 \text{ pf}) \\ = 41.5$$

$$\text{Amps} = \frac{41.5 \text{ kW}}{\sqrt{3} \times 0.4416 \text{ kV} \times 0.85} \\ = 63.8$$

BUS 3A (EDG 31) - MCC 35

MAIN TURBINE TURNING GEAR OIL PUMP; 5M :

Load = 75 hp, pf = .85 eff = .90; per Section 4, Ref. 4.3 and attached Load List

$$\text{kVA} = \frac{75 \text{ hp} \times .746}{.85 \text{ pf} \times .90 \text{ eff}} = 73.1$$

$$\text{kW} = (73.1 \text{ kVA}) (.85 \text{ pf}) = 62.1$$

$$\text{Amps} = \frac{62.1 \text{ kW}}{\sqrt{3} \times .85 \times 0.439 \text{ kV}} = 96.0$$

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
Project: Electrical Load Study Page 40 of 69
Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

SPECIFIC PROCEDURAL ACTUATED MCC LOADS

BUS 5A (EDG 33) - MCC 38

CRDM FANS 31 TO 34; 2D, 2F, 2H, 2K :

Load (per Fan) = 23.6 kVA, pf = .85; per Section 4, Ref. 3.9 attached Load List

$$\text{kW} = (23.6 \text{ kVA}) (.85 \text{ pf}) = 20.1$$

$$\text{Amps} = \frac{20.1 \text{ kW}}{1.73 \times 0.85 \times 0.4373 \text{ kV}} = 31.3$$

BUS 5A (EDG 33) - MCC 39

SPENT FUEL POOL COOLING PUMP 32; 7FM :

Load = 100 hp, 82.5 kVA, pf = .85; per Section 4, Ref. 3.9 attached Load List

$$\text{kW} = (82.5 \text{ kVA}) (.85 \text{ pf}) = 70.1$$

$$\text{Amps} = \frac{70.1 \text{ kW}}{1.73 \times .85 \times 0.4418 \text{ kV}} = 107.9$$

BUS 6A (EDG 32) - MCC 37

BAST (BORIC ACID STORAGE TANK) HEATERS 31 AND 32; 5RM, 3RD :

Load (per Tank) = 15 kW, pf = 1.0 (15 kVA); per Section 4, Ref. 3.9 attached Load List

$$\text{KW} = (17.6 \text{ kVA}) (.85 \text{ pf}) = 15.0$$

$$\text{Amps} = \frac{15 \text{ kW}}{1.73 \times 0.4418 \text{ kV}} = 19.6$$

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8

Project: Electrical Load Study Page 41 of 69

Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

SPECIFIC PROCEDURAL ACTUATED MCC LOADS (Continued)

BUS 6A (EDG 32) - MCC 37 (Continued)

PRIMARY WATER MAKEUP PUMPS 31 AND 32; 5RK, 6RK :

Load (per Pump) = 25 hp, pf = .85, eff = .90; per Section 4, Ref. 4.4 and
Ref. 3.9 attached Load List

$$\text{kVA} = \frac{25 \text{ HP} \times .746}{.85 \text{ pf} \times .90 \text{ eff}} = 24.4$$

$$\text{kW} = (24.4 \text{ kVA}) (.85 \text{ pf}) = 20.7$$

$$\text{Amps} = \frac{20.7 \text{ kW}}{1.73 \times .85 \times 0.4418 \text{ kV}} = 31.9$$

SPENT FUEL POOL COOLING PUMP 31; 4FM :

Load = 100 hp, 82.5 kVA, pf = .85; per Section 4, Ref. 3.9 attached Load List

$$\text{kW} = (82.5 \text{ kVA}) (.85 \text{ pf}) = 70.1$$

$$\text{Amps} = \frac{70.1 \text{ kW}}{1.73 \times .85 \times 0.4418 \text{ kV}} = 107.9$$

HOT PIPING PENETRATION BLOWERS 31 thru 34; 7FD, 7FF, 7FH, 7FK :

Load (Blower 31&32) = 17.6 kVA, pf = .85; per Section 4, Ref. 3.9 attached Load List

$$\text{kW} = (17.6 \text{ kVA}) (.85 \text{ pf}) = 15.0$$

$$\text{Amps} = \frac{15 \text{ kW}}{1.73 \times .85 \times 0.4418 \text{ kV}} = 23.1$$

Nuclear Engineering
CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8

Project: Electrical Load Study Page 42 of 69

Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 **LOAD DATA/CALCULATIONS** (Continued)

SPECIFIC PROCEDURAL ACTUATED MCC LOADS (Continued)

HOT PIPING PENETRATION BLOWERS 31 thru 34; 7FD, 7FF, 7FH, 7FK : (Continued)

Load (Blower 33) = 13.3 kVA, pf = .85; per Section 4, Ref. 3.9 attached Load List

$$\text{kW} = (13.3 \text{ kVA}) (.85 \text{ pf}) = 11.3$$

$$\text{Amps} = \frac{11.3 \text{ kW}}{1.73 \times .85 \times 0.4418 \text{ kV}} = 17.4$$

Load (Blower 34) = 18.1 kVA, pf = .85; per Section 4, Ref. 3.9 attached Load List

$$\text{kW} = (18.1 \text{ kVA}) (.85 \text{ pf}) = 15.4$$

$$\text{Amps} = \frac{15.4 \text{ kW}}{1.73 \times .85 \times 0.4418 \text{ kV}} = 23.7$$

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8

Project: Electrical Load Study Page 43 of 69

Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

PRESSURIZER HEATERS

PRESSURIZER HEATERS GROUP 31 - BUS 3A:

Load (Full Bank) = 555 kW (kVA) (per Section 4, Ref. 3.9)

$$\text{Load (per ckt)} = \frac{555 \text{ kW (kVA)}}{8 \text{ ckt}} = 69.4 \text{ kW (kVA)/ckt}$$

Load in Amperes (Amps):

$$\begin{aligned} \text{Amps (at 444V)} &= \frac{(555 \text{ kVA} \times 1000)(444\text{V})}{(1.73 \times 480\text{V})(480\text{V})} \\ &= 618.2 \end{aligned}$$

$$\text{Amps (per ckt)} = \frac{618.2 \text{ Amps (Full Bank)}}{8 \text{ ckt}} = 77.3 \text{ Amps/ckt}$$

PRESSURIZER HEATERS GROUP 32 - BUS 2A:

Load (Full Bank) = 485 kW (kVA) (per Section 4, Ref. 3.9)

$$\text{Load (per ckt)} = \frac{485 \text{ kW (kVA)}}{7 \text{ ckt}} = 69.3 \text{ kW (kVA)/ckt}$$

Load in Amperes (Amps):

$$\begin{aligned} \text{Amps (at 444V)} &= \frac{(485 \text{ kVA} \times 1000)(444\text{V})}{(1.73 \times 480\text{V})(480\text{V})} \\ &= 540.3 \end{aligned}$$

$$\text{Amps (per ckt)} = \frac{540.3 \text{ Amps (Full Bank)}}{7 \text{ ckt}} = 77.2 \text{ Amps/ckt}$$

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
Project: Electrical Load Study Page 44 of 69
Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

PRESSURIZER HEATERS (Continued)

PRESSURIZER HEATERS GROUP 33 - BUS 5A:

Load (Full Bank) = 485 kW (kVA) (per Section 4, Ref. 3.9)

$$\text{Load (per ckt)} = \frac{485 \text{ kW (kVA)}}{7 \text{ ckts}} = 69.3 \text{ kW (kVA)/ckt}$$

Load in Amperes (Amps):

$$\text{Amps (at 444V)} = \frac{(485 \text{ kVA} \times 1000) (444\text{V})}{(1.73 \times 480\text{V}) (480\text{V})}$$

$$= 540.3$$

$$\text{Amps (per ckt)} = \frac{540.3 \text{ Amps (Full Bank)}}{7 \text{ ckts}} = 77.2 \text{ Amps/ckt}$$

PRESSURIZER HEATERS CONTROL GROUP - BUS 6A:

Load = 277 kW (kVA) (per Section 4, Ref. 3.9)

Load in Amperes (Amps):

$$\text{Amps (at 444V)} = \frac{(277 \text{ kVA} \times 1000) (444\text{V})}{(1.73 \times 480\text{V}) (480\text{V})}$$

$$= 308.6$$

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 45 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

TOTAL LIGHTING AND MCC RESET

BUS 2A:

<u>LOAD</u>	<u>kVA*</u>	<u>KW**</u>	<u>AMPERAGE***</u>
MCC-34	244.1	219.7	319.1
TRAILER LOAD CENTER (Note1)	0.0	0.0	0.0
MCC-31	292.0	262.8	382.3
MCC-210 BACKUP SUPPLY	0.0	0.0	0.0
MCC-33	315.6	284.0	417.0
480V LTG BUS 32 NORMAL SUPPLY (254.4 x 0.8; Note 2)	<u>203.5</u>	<u>183.2</u>	<u>271.8</u>
	1055.2 kVA*	949.7 kW	1390.2 Amps
Diversity Factor	<u>0.61*</u>	<u>0.61*</u>	<u>0.61*</u>
	643.7 kVA	579.3 kW	848.0 Amps

*** Amperage at Degraded Grid Voltage:

Voltage at MCC 34: $444 - (415.1 - 412.7) = 441.6V$

MCC 34 Amps = $\frac{244.1}{\sqrt{3} \times .4416} = 319.1A$

Voltage at MCC 31: $444 - (415.1 - 412.1) = 441.0V$

MCC 31 Amps = $\frac{292.0}{\sqrt{3} \times .441} = 382.3A$

Voltage at MCC 33: $444 - (415.1 - 408.1) = 437.0V$

MCC 33 Amps = $\frac{315.6}{\sqrt{3} \times .437} = 417.0A$

Voltage at 480V Ltg. Bus 32: $444 - (415.1 - 403.3) = 432.2V$

Ltg. Bus 32 Amps = $\frac{203.5}{\sqrt{3} \times .4322} = 271.8A$

** A Power Factor of 0.9 is assumed for MCC and lighting loads.

* kVA and Diversity Factor are from IP3-CALC-ED-00201, (Section 4, Ref. 3.9)

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 46 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

TOTAL LIGHTING AND MCC RESET

<u>BUS 3A:</u>	<u>kVA*</u>	<u>kW**</u>	<u>AMPERAGE***</u>
MCC-35	375.4	337.9	493.7
LTG TRANSFORMER 32 (225/2 x 0.8 Note 2 & 3)	90.0	0.0	117.8
480V LTG BUS 33 NORMAL (65.7 x 0.8 Note 2)	52.6	47.3	68.8
MCC-32 (355.4 - 18.4) (Note 4)	<u>337.0</u>	<u>303.3</u>	<u>444.3</u>
	855.0kVA*	769.5kW	<u>1124.6 Amps</u>
Diversity Factor	<u>0.42*</u>	<u>0.42*</u>	<u>0.42*</u>
	359.1 kVA	<u>323.2 kW</u>	472.3 Amps
Battery Charger 34 (Note 4)	<u>12.6 kVA</u>	<u>12.0 kW</u>	<u>16.6 Amps</u>
TOTAL	371.7 kVA	335.2 kW	488.9 Amps

*** Amperage at Degraded Grid Voltage:

$$\text{Voltage at MCC 35: } 444.0 - (409.9 - 403.9) = 439.0V$$

$$\text{MCC 35 Amps } = \frac{374}{\sqrt{3} \times 439} = 493.7A$$

$$\text{Voltage at Ltg. Transfer 32: } 444.0 - (408.9 - 406.1) = 441.2V$$

$$\text{Ltg. Transfer 32 Amps } = \frac{90}{\sqrt{3} \times 441.2} = 117.8A$$

$$\text{Voltage at 480V Ltg. Bus 33: } 444 - (415.1 - 408.1) = 437.0V$$

$$\text{Ltg. Bus 33 Amps } = \frac{52.6}{\sqrt{3} \times 441.1} = 68.8A$$

$$\text{Voltage at MCC 32: } 444.0 - (408.9 - 402.8) = 437.9V$$

$$\text{MCC 32 Amps } = \frac{337.0}{\sqrt{3} \times 437.9} = 444.3A$$

** A Power Factor of 0.9 is assumed for MCC and lighting loads.

* kVA and Diversity Factor are from IP3-CALC-ED-00201, (Section 4, Ref. 3.9)

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 47 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

TOTAL LIGHTING AND MCC RESET (Continued)

BUS 5A:

<u>LOAD</u>	<u>kVA*</u>	<u>kW**</u>	<u>AMPERAGE***</u>
MCC-38	132.4	119.2	174.8
120/208V LTG BUS 33 (225√2 x 0.8 Note 1 and 2)	90.0	81.0	117.6
480V LTG BUS 33 (EMERG)	0.0	0.0	0.0
MCC-39 (689.3 - 105.6)(Note 4)	583.7	525.3	763.0
MCC-311	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
	806.1 kVA*	725.5 kW	<u>1055.4 Amps</u>
Diversity Factor	<u>0.54*</u>	<u>0.54*</u>	<u>0.54*</u>
	435.3 kVA	391.8 kW	569.9 Amps
Battery Charger 31 (Note 4)	<u>30.8 kVA</u>	<u>29.3 kW</u>	<u>40.2 Amps</u>
TOTAL	466.1 kVA	421.1 kW	610.1 Amps

*** Amperage at Degraded Grid Voltage:

Voltage at MCC 38: $444 - (401.8 - 395.1) = 437.3V$

MCC 38 Amps = $\frac{132.4}{\sqrt{3} \times .4373} = 174.8A$

Voltage at Ltg. Bus 33: $444 - (401.8 - 399.5) = 444 - 2.3 = 441.7$

* Ltg. Bus 33 Amps = $\frac{90}{\sqrt{3} \times .4417} = 117.6A$

Voltage at MCC 39: $444 - (401.8 - 401.2) = 443.4V$

MCC 39 Amps = $\frac{583.7}{\sqrt{3} \times .4417} = 763.0A$

** A Power Factor of 0.9 is assumed for MCC and lighting loads.

* kVA and Diversity Factor are from IP3-CALC-ED-00201, (Section 4, Ref. 3.9)

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 48 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

TOTAL LIGHTING AND MCC RESET (Continued)

BUS 6A:

<u>LOAD</u>	<u>kVA*</u>	<u>kW**</u>	<u>AMPERAGE***</u>
480V LTG BUS 32 (EMERG SUPPLY)	0.0	0.0	0.0
MCC-37 (1345.2 - 105.6) (Note 4)	<u>1239.6</u>	<u>1115.6</u>	<u>1619.9</u>
	1239.6 kVA*	1115.6 kW	1619.9 Amps
Diversity Factor	<u>0.1*</u>	<u>0.1*</u>	<u>0.1*</u>
	124.0 kVA	111.6 kW	162.0 Amps
Battery Charger 32 (Note 4)	<u>21.1 kVA</u>	<u>20.0 kW</u>	<u>27.6 Amps</u>
TOTAL	145.1 kVA	131.6 kW	189.6 Amps

***AMPs at Degraded Grid Voltage:

$$\text{Voltage at MCC 37: } 444 - (3995.5 - 393.3) = 441.8\text{V}$$

$$\text{MCC 37 Amps} = \frac{1239.6}{\sqrt{3} \times 0.4418} = 1619.9\text{A}$$

* kVA and Diversity Factor are from IP3-CALC-ED-00201, Rev. 2 (Section 4, Ref. 3.9)

** A Power Factor of 0.9 is assumed for MCC and lighting loads.

Notes:

1. Trailer Load Center is not reset during the accident recovery.
2. A demand factor of 0.8 is used to calculate the lighting kVA. (Lighting panels and transformers are sized at a minimum of 125% of load).
3. Lighting Transformer 32 can feed both lighting buses 32 and 33.
4. For conservatism Batteries are assumed separately from the MCC load. No diversity factor is considered. They are added separately to the overall loading.

**Nuclear Engineering
CALCULATION SHEET**

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 49 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

MOTOR BRAKE HORSEPOWER

<u>EQUIPMENT</u>	<u>bhp</u> per motor	<u>pf</u>	<u>eff</u>	<u>LOAD</u> in kVA	<u>LOAD</u> in kW
CONTAINMENT RECIRCULATION FANS (FCU)					
Total of five (5) fans					
a) When all 5 fans are running ***	159.0	.699*	.920*	184.6	129.0
b) When 4 fans are running ***	159.0	.699*	.920*	184.6	129.0
c) When 3 fans are running ***	159.0	.699*	.920*	184.6	129.0
 COMPONENT COOLING WATER PUMPS (CCWP)					
Total of three (3) pumps					
a) When all 3 pumps are running	212.0	.890*	.936*	189.8	169.0
b) When 2 pumps are running	248.0	.891	.934	222.3	198.1
c) When 1 pump is running	275.0	.891	.934	246.5	219.6
 SAFETY INJECTION PUMPS (SI)					
Total of three (3) pumps					
Pumps 31, 32 & 33	414.0	.910	.944	359.5	327.2
 SERVICE WATER PUMPS (NESWP or ESWP)					
Total of three (3) pumps					
a) Switchover Mode 1 pump running on non-essential header	350.0	.875	.930	320.9	280.8
b) Injection Mode 2 pumps running on essential header	350.0	.875	.930	320.9	280.8

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 50 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

MOTOR BRAKE HORSEPOWER (Continued)

<u>EQUIPMENT</u>	<u>bhp</u> per motor	<u>pf</u>	<u>eff</u>	<u>LOAD</u> in kVA	<u>LOAD</u> in kW
RESIDUAL HEAT REMOVAL PUMPS (RHR)					
Total of two (2) pumps					
a) When both pumps are running	365.0	.904*	.945*	318.8	288.1
b) When 1 pump is running	400.0	.906	.944	348.9	316.1
c) Mini Flow (Ref. 1)	--	.906	--	200	182
Note that a) and b) above are based on two RHR heat exchangers in service. With two pumps running and only one heat exchanger in service, flow is limited by heat exchanger flow and bhp will be lower. Higher bhp is used for conservatism.					
CONTAINMENT SPRAY PUMPS (CS)					
Total of two (2) pumps					
a) CS Pump 31 ***	385.0	.893*	.935*	344.1	307.3
b) CS Pump 32 ***	400.0	.895	.934	357.0	319.5
AUXILIARY FEED WATER PUMPS (AFWP)					
Total of two (2) motor driven pumps					
a) AFW Pumps 31	480.0	.870	.945	435.5	378.9
b) AFW Pumps 33	480.0	.890	.953	422.2	375.7
PAB FANS 31 & 32 (Ref. 3.11)					
Each fan	137.9	.850**	.90**	134.5	114.3

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 51 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

6.0 LOAD DATA/CALCULATIONS (Continued)

MOTOR BRAKE HORSEPOWER (Continued)

<u>EQUIPMENT</u>	<u>bhp</u> per motor	<u>pf</u>	<u>eff</u>	<u>LOAD</u> in kVA	<u>LOAD</u> in kW
CHARGING PUMPS	175	.894	.931	156.8	140.2
CONTAINMENT RECIRCULATION PUMPS (CRP)					
a) Large Break LOCA (Cold Legs & Recirculation Spray, with 2 HX in service)	388.1	.874	.937	353.5	309.0
b) Large Break LOCA (Post Recirculation Spray & Hot Leg Recirculation, with 1 HX in service)	259.5	.850*	.939*	242.5	206.2
c) Small Break LOCA (High Head SI & Recirculation Spray, with 1 HX in service)	384.7	.874	.937	350.4	306.3
d) Small Break LOCA (High Head SI, Post Recirculation Spray, with 1 HX in service)	257.5	.850*	.939*	240.7	204.6

Nuclear Engineering
CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8

Project: Electrical Load Study Page 52 of 69

Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

bhp - Calculated brake horsepower from IP-CALC-04-00809, Rev.2 (Ref. Section 4, 3.2)

pf - Power Factor of Motor from MFR. Data Sheets, unless otherwise noted.

eff - Efficiency of Motor from MFR. Data Sheets, unless otherwise noted.

kVA - $(bhp \times .746)/(pf \times eff)$

* - Extrapolated from motor data sheets (Appendix A.12)

** - Assumed value(s)

*** - BHP values based on input from Design Engineering Mechanical see Appendix H-1

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 53 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

7.0 EFFECT OF FREQUENCY VARIATION ON EDG LOADING

The allowable operating range of the EDGs is $\pm 0.5\%$ (59.7Hz to 60.3 Hz) of rated frequency (Reference SOP-EL-1, "Emergency Generator Operation"). The effect of frequency variation for the operating ranges of 59.7Hz and 60.3Hz were modeled on the EPRI Electromagnetic Transient Program (EMTP) Version 2.0 by Raytheon Engineers and Constructors. AFWP 33 was chosen as an example for a typical motor response. The analysis shows that at the increased frequency of 60.3Hz from 60Hz, the motor output power increased by 4kW and at a frequency of 59.7Hz decreased by 4KW (see Appendix B output graphs). The 4KW represents a 1.06% variation in real power (kW) for the motor ($4\text{kW} * 100\% / 375.5 \text{ kW} = 1.06\%$). To demonstrate the impact on EDG loading if the units were to operate at the extreme ranges indicated in SOP-EL-1, worst case peak and steady state loading are analyzed. EDG 32 experiences the largest peak loading (1895.6 kW) during a Large Break LOCA with loss of EDG 31 and the worst case steady state loading (1674.7 kW) occurs on EDG 33 during a Large Break LOCA with loss of EDG 32 (Bus 6A). These two cases are bounding for all scenarios.

FIRST CASE - PEAK LOADING

The individual loads which result in 1895.6 kW on EDG 32 are as follows:

AFWP 33	375.7 kW
CSP 32	319.5 kW
ESWP 36	280.8 kW
FCU 35	129.0 kW
MCC 36B	80.3 kW
MCC 36D	20.1 kW
MCC 37 (MCC Reset Bus 6A)	24.8 kW
RHR PUMP 32	316.1 kW
SI PUMP 33	<u>327.2 kW</u>
	1873.5 kW
Cable Losses (Ref. Appendix E)	<u>22.1 kW</u>
	1895.6 kW

Of the loads identified above the following are static loads:

MCC 36B	
PA System	9.0 kW
D/G Bldg. Ltg	20.2 kW
Cable Losses	<u>22.1 kW</u>
	51.3 kW

$$1895.6 \text{ kW} - 51.3 \text{ kW} = 1844.3 \text{ kW}$$

1844.3 kW is the motor inductive loading in real power that will be affected by the frequency variation.

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 54 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

7.0 EFFECT OF FREQUENCY VARIATION ON LOADING (Continued)

Increase in load due to increased frequency is

$$1844.3 \times 1.06\% = 19.55 \text{ kW}$$

Total load on EDG 32 is

$$1844.3 + 19.55 + 51.3 = 1915.15 \text{ kW}$$

* 1.06% variation

SECOND CASE - STEADY STATE

The individual loads which result in 1673.1 kW on EDG 33 are as follows:

RECIRC PUMP 31	309.0 kW
SI PUMP 31	327.2 kW
FCU 31	129.0 kW
FCU 33	129.0 kW
MCC 36A	89.9 kW
MCC 36E	20.1 kW
MCCs Reset Bus 2A/3A	85.8 kW
ESWP 34	280.8 kW
NESWP 31	<u>280.8 kW</u>
	1651.6 kW
Cable Losses (Ref. Appendix E)	<u>23.1 kW</u>
	1674.7 kW

Of the loads identified above the following are static loads:

MCC 36A	
Plant Vent Rad Monitor (R-27)	5.00 kW
Distribution Panel POH	5.76 kW
Boric Acid Heat Tracing	14.80 kW
Cable Losses	23.1 kW
	48.66 kW

$$1674.7 \text{ kW} - 48.66 \text{ kW} = 1626.04 \text{ kW}$$

1626.04 kW is the motor inductive loading in real power that will be affected by the frequency variation.

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8

Project: Electrical Load Study Page 55 of 69

Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

7.0 EFFECT OF FREQUENCY VARIATION ON LOADING (Continued)

Increase in load due to increased frequency is

$$1626.04 \times 1.06\% = 17.2 \text{ kW}$$

Total load on EDG 33 is

$$1626.04 + 17.2 + 48.66 = 1691.9 \text{ kW}$$

The above calculations show that:

1. In the first case the maximum peak load is 1915.15 kW. This load is below the 1950kW 2 hr/2000 hr rating of the EDG.
2. In the second case the maximum is 1691.9 kW and this load is below the 1750kW continuous rating of the EDG.

I&C engineering have been trending the EDG performance (via IC-PC-I-E-31, 32 & 33.) from 1987 to the present. During this time period the EDGs frequency deviation has never been greater than 0.2% of the actual frequency (the model uses 0.5%).

Electrical Engineering had EDG performance testing and evaluation done during the SI Black-out test of R08 and R09 outages and in both cases no degradation in performance had occurred (see attached memo in Appendix B). The frequency response of this testing concurs with I&C trending data.

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
 Project: Electrical Load Study Page 56 of 69
 Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

8.0 POWER FACTOR CALCULATION FOR WORST CASE KVA LOADING ON EDGs

This section is for the power factor calculation for the worst case kVA loading on each EDG.

For EDG 31:

The worst case peak loading occurs during a Large Break LOCA with Bus 5A not available.

The individual loads which result in 1830.8 kW or 2137.8 kVA on EDG 31 are as follows:

	<u>kW</u>	<u>kVA</u>	
AFWP 31	378.9	435.5	
CHARGING PUMP 32	140.2	156.8	
ESWP 35	280.8	320.9	
FCU 32	129.0	184.6	
FCU 34	129.0	184.6	
MCC 36C	94.3	104.2	
MCC 32 (MCC Reset Bus 2A/3A)	12.0	12.6	from 12.0/0.95 = 12.6
MCC 34 (MCC Reset Bus 2A/3A)	51.3	60.3	from 51.3/0.85 = 60.3
RHR PUMP 31	288.1	318.8	
SI PUMP 32	<u>327.2</u>	<u>359.5</u>	
	1830.8 kW	2137.8 kVA	
Cable Losses (Ref. Appendix E-3)	<u>19.6 kW</u>		
	<u>1850.4 kW</u>		

Of the loads identified above the following are static loads:

MCC 36C	
PBX System	15.0 kW
Ctrl Bldg. Ltg	33.8 kW
Rod Pos. Indic System	5.0 kW
Cable Losses	<u>19.6 kW</u>
	<u>73.4 kW</u>

$$1850.4 \text{ kW} - 73.4 \text{ kW} = 1777 \text{ kW}$$

1777 kW is the motor inductive loading in real power that will be affected by the frequency variation.

Increase in load due to increased frequency is $1777 \times 1.06\% = 18.8 \text{ kW}$

Total load on EDG 31 is $1850.4 + 18.8 = 1868.5 \text{ kW}$.

Similarly the frequency variation is calculated to be 22.1 kVA.

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8
Project: Electrical Load Study Page 57 of 69
Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

8.0 POWER FACTOR CALCULATION FOR WORST CASE KVA LOADING ON EDGs (Continued)

The majority of the feeder cables to the loads listed above are 1/C-500MCM, with a reactance of $X = 0.0509 \Omega/1000\text{ft}$ and a resistance at 75C of $R = 0.0299 \Omega/1000\text{ft}$. This yields a power factor of $\text{p.f.} = 0.51$.

For the purpose of determining the cable losses in kVA, a conservative power factor value of 0.50 is assumed. Therefore for the loads on EDG 31, the cable losses are $19.6 \text{ kW} / 0.50 = 39.2 \text{ kVA}$.

The total kVA on EDG 31 is $2137.8 + 22.1$ (frequency variation) $+ 39.2 = 2199.1 \text{ kVA}$

The calculated power factor is: $\text{p.f.} = \text{Total kW} / \text{Total kVA} = 1868.5 / 2199.1 = 0.85$.

For EDG 32:

From Section 7.0 of this calculation the worst case peak loading occurs during a Large Break LOCA with Buses 2A/3A not available.

The total loading in kW is 1915.15 kW, including 22.1 kW for cable losses (Appendix E-1) and 19.55 kW for frequency variation.

Using section 6.0 the total kVA loading is summed for the individual loads on EDG 32 as follows:

AFWP 33	422.2 kVA	
CSP 32	357.0 kVA	
ESWP 36	320.9 kVA	
FCU 35	184.6 kVA	
MCC 36B	90.3 kVA	
MCC 36D	23.5 kVA	
MCC 37 (MCC Reset Bus 6A)	29.2 kVA	from $24.8 \text{ kW} / 0.85 = 29.2 \text{ kVA}$
RHR PUMP 32	348.9 kVA	
SI PUMP 33	<u>359.5 kVA</u>	
	2136.1 kVA	

Frequency variation is calculated in the same methodology used in Section 7.0. The total inductive loads are: $2136.1 \text{ kVA} - 29.5 \text{ kVA}$ (from MCC 36B) $= 2106.6 \text{ kVA}$

The frequency variation is: $2106.6 * 1.06\% = 22.3 \text{ kVA}$.

Nuclear Engineering CALCULATION SHEET

Calculation No. JP3-CALC-ED-00207 Revision 8
Project: Electrical Load Study Page 58 of 69
Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

8.0 POWER FACTOR CALCULATION FOR WORST CASE KVA LOADING ON EDGs (Continued)

The majority of the feeder cables to the loads listed above are 1/C-500MCM, with a reactance of $X = 0.0509 \Omega/1000\text{ft}$ and a resistance at 75C of $R = 0.0299 \Omega/1000\text{ft}$. This yields a power factor of $\text{p.f.} = 0.51$.

For the purpose of determining the cable losses in kVA, a conservative power factor value of 0.50 is assumed. Therefore for the loads on EDG 32, the cable losses are $22.1 \text{ kW} / 0.50 = 44.2 \text{ kVA}$.

Therefore the total kVA loading is: $2136.1 + 44.2 + 22.3 = 2202.6 \text{ kVA}$.

The calculated power factor is: $\text{p.f.} = \text{Total kW} / \text{Total kVA} = 1915.15 / 2202.6 = 0.87$.

For EDG 33:

From Section 7.0 of this calculation the worst case peak loading occurs during a Large Break LOCA with Buses 6A not available. (For this case the worst peak load is also the worst case steady state load for EDG 33.)

The total loading in kW is 1691.9 kW, including 23.1 kW for cable losses (Appendix E-2) and 17.2 kW for frequency variation.

Using section 6.0 the total kVA loading is summed for the individual loads on EDG 33 as follows:

RECIRC PUMP 31	353.5 kVA	
SI PUMP 31	359.5 kVA	
FCU 31	184.6 kVA	
FCU 33	184.6 kVA	
MCC 36A	104.4 kVA	
MCC 36E	23.4 kVA	
MCCs Reset Bus 2A/3A	100.9 kVA	from 85.8 kW/0.85 = 100.9 kVA
ESWP 34	320.9 kVA	
NESWP 31	<u>320.9 kVA</u>	
	1952.7 kVA	

Frequency variation is calculated in the same methodology used in Section 7.0. The total inductive loads are: $1952.7 \text{ kVA} - 25.56 \text{ kVA (from MCC 36A)} = 1927.14 \text{ kVA}$

The frequency variation is: $1927.14 * 1.06\% = 20.4 \text{ kVA}$ and the cable losses are $23.1 \text{ kW} / 0.5 = 46.2 \text{ kVA}$.

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8

Project: Electrical Load Study Page 59 of 69

Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

8.0 POWER FACTOR CALCULATION FOR WORST CASE KVA LOADING ON EDGs (Continued)

The majority of the feeder cables to the loads listed above are 1/C-350MCM with a reactance of $X = 0.0527 \Omega/1000\text{ft}$ and a resistance at 75C of $R = 0.0413 \Omega/1000\text{ft}$. This yields a power factor of 0.58.

For the purpose of determining the cable losses in kVA, a conservative power factor value of 0.55 is assumed. Therefore for the loads on EDG 33, the cable losses are $23.1 \text{ kW} / 0.55 = 42 \text{ kVA}$.

Therefore the total kVA loading is: $1952.7 + 42 + 20.4 = 2015.1 \text{ kVA}$.

The calculated power factor is: $\text{p.f.} = \text{Total kW} / \text{Total kVA} = 1691.9 / 2015.1 = 0.84$.

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8

Project: Electrical Load Study Page 60 of 69

Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

9.0 INDEX OF LOADING CALCULATIONS FOR EACH ACCIDENT SCENARIO

	<u>TITLE</u>	<u>PAGE</u>
1.	Legend	1
2.	Master Load List	
	a) Loads on all Buses	4
	b) 6.9kV Equivalent Amps	8
3.	Loading Summary During and End of Accident Scenarios	12
4.	Large Break LOCA (RCS Pressure < 325)	
	a) Total MCC and Lighting Reset All Buses available with Off-Site Power	16
	b) Buses 2A and 3A Tied Together with Off-Site Power Available	23
	c) Buses 2A and 3A Tied Together, Bus 6A Not Available, with Off-Site Power	30
	d) Buses 2A and 3A Tied Together, Bus 5A Not Available, with Off-Site Power	38
	e) Bus 2A and/or 3A Not Available with Off-Site Power	46
	f) Buses 2A and 3A Tied Together with LOOP	53
	g) Buses 2A and 3A Tied Together, Bus 6A Not Available, with LOOP	60
	h) Buses 2A and 3A Tied Together, Bus 5A Not Available, with LOOP	68
	i) Bus 2A and/or 3A Not Available with LOOP	76

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8

Project: Electrical Load Study Page 61 of 69

Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

9.0 INDEX OF LOADING CALCULATIONS FOR EACH ACCIDENT SCENARIO (Continued)

	<u>TITLE</u>	<u>PAGE</u>
6.	Small Break LOCA	
a)	Total MCC and Lighting Reset All Buses available with Off-Site Power	83
b)	Buses 2A and 3A Tied Together with Off-Site Power Available	91
c)	Buses 2A and 3A Tied Together, Bus 6A Not Available, with Off-Site Power	99
d)	Buses 2A and 3A Tied Together, Bus 5A Not Available, with Off-Site Power	106
e)	Bus 2A and/or 3A Not Available with Off-Site Power	113
f)	Buses 2A and 3A Tied Together with LOOP	120
g)	Buses 2A and 3A Tied Together, Bus 6A Not Available, with LOOP	128
h)	Bus 2A and/or 3A Tied Together, Bus 5A Not Available, with LOOP	135
i)	Bus 2A and/or 3A Not Available with LOOP	142

**Nuclear Engineering
CALCULATION SHEET**

Calculation No. IP3-CALC-ED-00207 Revision 8
Project: Electrical Load Study Page 62 of 69
Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

9.0 INDEX OF LOADING CALCULATIONS FOR EACH ACCIDENT SCENARIO (Continued)

	<u>TITLE</u>	<u>PAGE</u>
7.	Small Break LOCA (Phase B)	
a)	Total MCC and Lighting Reset All Buses available with Off-Site Power	149
b)	Buses 2A and 3A Tied Together with Off-Site Power Available	157
c)	Buses 2A and 3A Tied Together, Bus 6A Not Available, with Off-Site Power	165
d)	Buses 2A and 3A Tied Together, Bus 5A Not Available, with Off-Site Power	173
e)	Bus 2A and/or 3A Not Available with Off-Site Power	181
f)	Buses 2A and 3A Tied Together with LOOP	189
g)	Buses 2A and 3A Tied Together, Bus 6A Not Available, with LOOP	197
h)	Buses 2A and 3A Tied Together, Bus 5A Not Available, with LOOP	205
i)	Bus 2A and/or 3A Not Available with LOOP	213

**Nuclear Engineering
CALCULATION SHEET**

Calculation No. IP3-CALC-ED-00207 Revision 8

Project: Electrical Load Study Page 63 of 69

Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

9.0 INDEX OF LOADING CALCULATIONS FOR EACH ACCIDENT SCENARIO (Continued)

	<u>TITLE</u>	<u>PAGE</u>
8.	Steam Break (Phase B)	
a)	Total MCC and Lighting Reset All Buses available with Off-Site Power	221
b)	Buses 2A and 3A Tied Together with Off-Site Power	227
c)	Buses 2A and 3A Tied Together, Bus 6A Not Available, with Off-Site Power	233
d)	Buses 2A and 3A Tied Together, Bus 5A Not Available, with Off-Site Power	239
e)	Bus 2A and/or 3A Not Available with Off-Site Power	245
f)	Buses 2A and 3A tied together with LOOP	251
g)	Buses 2A and 3A Tied Together, Bus 6A Not Available, with LOOP	257
h)	Buses 2A and 3A Tied Together, Bus 5A Not Available, with LOOP	263
i)	Bus 2A and/or 3A Not Available with LOOP	269

**Nuclear Engineering
CALCULATION SHEET**

Calculation No. IP3-CALC-ED-00207 Revision 8
Project: Electrical Load Study Page 64 of 69
Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

9.0 INDEX OF LOADING CALCULATIONS FOR EACH ACCIDENT SCENARIO (Continued)

	<u>TITLE</u>	<u>PAGE</u>
9.	Steam Break	
a)	Total MCC and Lighting Reset All Buses available with Off-Site Power	276
b)	Buses 2A and 3A Tied Together with Off-Site Power	282
c)	Buses 2A and 3A Tied Together, Bus 6A Not Available, with Off-Site Power	288
d)	Buses 2A and 3A Tied Together, Bus 5A Not Available, with Off-Site Power	294
e)	Bus 2A and/or 3A Not Available with Off-Site Power	300
f)	Buses 2A and 3A Tied Together with LOOP	306
g)	Buses 2A and 3A Tied Together, Bus 6A Not Available, with LOOP	312
h)	Buses 2A and 3A Tied Together, Bus 5A Not Available, with LOOP	318
i)	Bus 2A and/or 3A Not Available with LOOP	324

**Nuclear Engineering
CALCULATION SHEET**

Calculation No. IP3-CALC-ED-00207 Revision 8
Project: Electrical Load Study Page 65 of 69
Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

9.0 INDEX OF LOADING CALCULATIONS FOR EACH ACCIDENT SCENARIO (Continued)

	<u>TITLE</u>	<u>PAGE</u>
10.	Inadvertent SI (Phase B)	
a)	Total MCC and Lighting Reset All Buses available with Off-Site Power	330
b)	Buses 2A and 3A Tied Together with Off-Site Power Available	336
c)	Buses 2A and 3A Tied Together, Bus 6A Not Available, with Off-Site Power	341
d)	Buses 2A and 3A Tied Together, Bus 5A Not Available, with Off-Site Power	348
e)	Bus 2A and/or 3A Not Available with Off-Site Power	354
f)	Buses 2A and 3A Tied Together with LOOP	360
g)	Buses 2A and 3A Tied Together, Bus 6A Not Available, with LOOP	366
h)	Buses 2A and 3A Tied Together, Bus 5A Not Available, with LOOP	372
i)	Bus 2A and/or 3A Not Available with LOOP	378

**Nuclear Engineering
CALCULATION SHEET**

Calculation No. IP3-CALC-ED-00207 Revision 8
Project: Electrical Load Study Page 66 of 69
Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

9.0 INDEX OF LOADING CALCULATIONS FOR EACH ACCIDENT SCENARIO (Continued)

	<u>TITLE</u>	<u>PAGE</u>
11.	Inadvertent SI	
a)	Total MCC and Lighting Reset All Buses available with Off-Site Power	384
b)	Buses 2A and 3A Tied Together with Off-Site Power	390
c)	Buses 2A and 3A Tied Together, Bus 6A Not Available, with Off-Site Power	396
d)	Buses 2A and 3A Tied Together, Bus 5A Not Available, with Off-Site Power	402
e)	Bus 2A and/or 3A Not Available with Off-Site Power	408
f)	Buses 2A and 3A Tied Together with LOOP	414
g)	Buses 2A and 3A Tied Together, Bus 6A Not Available, with LOOP	420
h)	Buses 2A and 3A Tied Together, Bus 5A Not Available, with LOOP	426
i)	Bus 2A and/or 3A Not Available with LOOP	432

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8

Project: Electrical Load Study Page 67 of 69

Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

9.0 INDEX OF LOADING CALCULATIONS FOR EACH ACCIDENT SCENARIO (Continued)

	<u>TITLE</u>	<u>PAGE</u>
12.	Steam Generator Tube Rupture	
a)	Total MCC and Lighting Reset All Buses available with Off-Site Power	438
b)	Buses 2A and 3A Tied Together with Off-Site Power Available	445
c)	Buses 2A and 3A Tied Together, Bus 6A Not Available, with Off-Site Power	452
d)	Buses 2A and 3A Tied Together, Bus 5A Not Available, with Off-Site Power	459
e)	Bus 2A and/or 3A Not Available with Off-Site Power	466
f)	Buses 2A and 3A Tied Together with LOOP	473
g)	Buses 2A and 3A Tied Together, Bus 6A Not Available, with LOOP	480
h)	Buses 2A and 3A tied together, Bus 5A Not Available, with LOOP	487
i)	Bus 2A and/or 3A Not Available with LOOP	494

Nuclear Engineering CALCULATION SHEET

Calculation No. IP3-CALC-ED-00207 Revision 8

Project: Electrical Load Study Page 68 of 69

Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

10.0 APPENDIX A

- Appendix A.1 Charging Pumps
- Appendix A.2 Component Cooling Water Pumps
- Appendix A.3 Containment Recirculation Fans
- Appendix A.4 Containment Recirculation Pumps
- Appendix A.5 Containment Spray Pumps
- Appendix A.6 Containment Spray Pumps (New Pump Motor)
- Appendix A.7 Motor Driven Auxiliary Feedwater Pump 31
- Appendix A.8 Motor Driven Auxiliary Feedwater Pump 33 (New Pump Motor)
- Appendix A.9 Residual Heat Removal Pumps
- Appendix A.10 Safety Injection Pumps
- Appendix A.11 Service Water Pumps
- Appendix A.12 Extrapolated Motor Power Factor and Efficiency

11.0 APPENDIX B - EFFECT OF FREQUENCY VARIATION ON LOADING

- Appendix B.1 AFWP 33 -Model Input Data
- Appendix B.2 Output Graphs
- Appendix B.3 Raytheon Engineers & Constructors Letter Dated 9/15/97

12.0 APPENDIX C - LETTER FROM WORTHINGTON CORPORATION

Letter from Worthington Corporation to UE&C confirming emergency diesel ratings,
dated December 24, 1968

**Nuclear Engineering
CALCULATION SHEET**

Calculation No. IP3-CALC-ED-00207 Revision 8
Project: Electrical Load Study Page 69 of 69
Subject: 480V Bus 2A, 3A, 5A, and 6A and EDG's 31, 32 and 33 Accident Loading

13.0 APPENDIX D

Appendix D.1 GNB Technologies fax dated October 22, 1997

Appendix D.2 K.J.Nelson - C. Reichert telecon dated February 3, 1992

14.0 APPENDIX E

Appendix E-1 Worst Case Peak Load (Large Break LOCA) – EDG 32 (Bus 6A) – Cable Losses.

Appendix E-2 Worst Case Steady State Load (Large Break LOCA) – EDG 33 (Bus 5A) – Cable losses.

Appendix E-3 Worst Case kVA Load for EDG 31 (Bus 2A/3A) – Cable losses.

15.0 APPENDIX F

Appendix F-1 Motor Operated Valve list for MCCs 36A and 36B

16.0 APPENDIX G

Appendix G-1 Comparison of 1991 Degraded Grid Voltage Study (case 31) to 1997 revised study.

17.0 APPENDIX H

Appendix H-1 BHP Input from Design Engineering Mechanical for Safety Related Pumps/Motors.

18.0 ATTACHMENT 1

Basis for deletion of Steam Generator Tube Rupture with Phase B Isolation (PH B)

DESIGN VERIFICATION COVER PAGE

<input type="checkbox"/> ANO-1	<input type="checkbox"/> ANO-2	<input type="checkbox"/> IP-2	<input checked="" type="checkbox"/> IP-3	<input type="checkbox"/> JAF	<input type="checkbox"/> PLP
<input type="checkbox"/> PNPS	<input type="checkbox"/> VY	<input type="checkbox"/> GGNS	<input type="checkbox"/> RBS	<input type="checkbox"/> W3	<input type="checkbox"/> NP
Document No. IP3-CALC-ED-00207		Revision No. 2	Page 1 of 3		
Title: 480V Buses 2A, 3A, 5A and 6A and EDG's 31, 32 and 33 Accident Loading					
DV Method: <input checked="" type="checkbox"/> Quality Related <input type="checkbox"/> Augmented Quality Related <input checked="" type="checkbox"/> Design Review <input type="checkbox"/> Alternate Calculation <input type="checkbox"/> Qualification Testing					

VERIFICATION REQUIRED	DISCIPLINE	VERIFICATION COMPLETE AND COMMENTS RESOLVED (DV print, sign, and date)
<input checked="" type="checkbox"/>	Electrical	F. A. Bloise / <i>[Signature]</i> 8/27/09
<input type="checkbox"/>	Mechanical	
<input type="checkbox"/>	Instrument and Control	
<input type="checkbox"/>	Civil/Structural	
<input type="checkbox"/>	Nuclear	
<input type="checkbox"/>		
<input type="checkbox"/>		
Originator:	Andromache Zografos / <i>[Signature]</i> 8/27/09 Print/Sign/Date After Comments Have Been Resolved	

IDENTIFICATION:		DISCIPLINE:	
Document Title: 480V Buses 2A, 3A, 5A and 6A and EDG's 31, 32 and 33 Accident Loading		<input type="checkbox"/> Civil/Structural	
Doc. No.: IP3-CALC-ED-00207		<input checked="" type="checkbox"/> Electrical	
Rev. 2		<input type="checkbox"/> I & C	
QA Cat. SR		<input type="checkbox"/> Mechanical	
Verifier:	Frank A. Bloise	<i>[Signature]</i>	8/27/09
	Print	Sign	Date
Manager authorization for supervisor performing Verification.			
X N/A			
Print		Sign Date	
METHOD OF VERIFICATION:			
Design Review <input checked="" type="checkbox"/>		Alternate Calculations <input type="checkbox"/>	
		Qualification Test <input type="checkbox"/>	

The following basic questions are addressed as applicable, during the performance of any design verification. [ANSI N45.2.11 – 1974] [NP] [QAPD, Part II, Section 3][NQA-1-1994, Part II, BR 3, Supplement 3s-1].

NOTE The reviewer can use the "Comments/Continuation sheet" at the end for entering any comment/resolution along with the appropriate question number. Additional items with new question numbers can also be entered.



- Design Inputs** – Were the inputs correctly selected and incorporated into the design?
 (Design inputs include design bases, plant operational conditions, performance requirements, regulatory requirements and commitments, codes, standards, field data, etc. All information used as design inputs should have been reviewed and approved by the responsible design organization, as applicable.
 All inputs need to be retrievable or excerpts of documents used should be attached.
 See site specific design input procedures for guidance in identifying inputs.)
 Yes No N/A
- Assumptions** – Are assumptions necessary to perform the design activity adequately described and reasonable? Where necessary, are assumptions identified for subsequent re-verification when the detailed activities are completed? *Are the latest applicable revisions of design documents utilized?*
 Yes No N/A
- Quality Assurance** – Are the appropriate quality and quality assurance requirements specified?
 Yes No N/A

4. Codes, Standards and Regulatory Requirements – Are the applicable codes, standards and regulatory requirements, including issue and addenda properly identified and are their requirements for design met?
Yes No N/A
5. Construction and Operating Experience – Have applicable construction and operating experience been considered?
Yes No N/A
6. Interfaces – Have the design interface requirements been satisfied and documented?
Yes No N/A
7. Methods – Was an appropriate design or analytical (for calculations) method used?
Yes No N/A
8. Design Outputs – Is the output reasonable compared to the inputs?
Yes No N/A
9. Parts, Equipment and Processes – Are the specified parts, equipment, and processes suitable for the required application?
Yes No N/A
10. Materials Compatibility – Are the specified materials compatible with each other and the design environmental conditions to which the material will be exposed?
Yes No N/A
11. Maintenance requirements – Have adequate maintenance features and requirements been specified?
Yes No N/A
12. Accessibility for Maintenance – Are accessibility and other design provisions adequate for performance of needed maintenance and repair?
Yes No N/A
13. Accessibility for In-service Inspection – Has adequate accessibility been provided to perform the in-service inspection expected to be required during the plant life?
Yes No N/A
14. Radiation Exposure – Has the design properly considered radiation exposure to the public and plant personnel?
Yes No N/A
15. Acceptance Criteria – Are the acceptance criteria incorporated in the design documents sufficient to allow verification that design requirements have been satisfactorily accomplished?
Yes No N/A
16. Test Requirements – Have adequate pre-operational and subsequent periodic test requirements been appropriately specified?
Yes No N/A

17. Handling, Storage, Cleaning and Shipping -- Are adequate handling, storage, cleaning and shipping requirements specified?
Yes No N/A
18. Identification Requirements -- Are adequate identification requirements specified?
Yes No N/A
19. Records and Documentation -- Are requirements for record preparation, review, approval, retention, etc., adequately specified? Are all documents prepared in a clear legible manner suitable for microfilming and/or other documentation storage method? Have all impacted documents been identified for update as necessary?
Yes No N/A
20. Software Quality Assurance- ENN sites: For a calculation that utilized software applications (e.g., GOTHIC, SYMCORD), was it properly verified and validated in accordance with EN- IT-104 or previous site SQA Program?
ENS sites: This is an EN-IT-104 task. However, per ENS-DC-126, for exempt software, was it verified in the calculation?
Yes No N/A
21. *Has adverse impact on peripheral components and systems, outside the boundary of the document being verified, been considered?*
Yes No N/A

DESIGN VERIFICATION COVER PAGE

<input type="checkbox"/> ANO-1 <input type="checkbox"/> ANO-2 <input type="checkbox"/> IP-2 <input checked="" type="checkbox"/> IP-3 <input type="checkbox"/> JAF <input type="checkbox"/> PLP <input type="checkbox"/> PNPS <input type="checkbox"/> VY <input type="checkbox"/> GGNS <input type="checkbox"/> RBS <input type="checkbox"/> W3 <input type="checkbox"/> NP
Document No. EC - 16788 Revision No. 0 Page 1 of ____
Title: BHP Input From Design Mechanical – Appendix H
DV Method: <input checked="" type="checkbox"/> Quality Related <input type="checkbox"/> Augmented Quality Related <input checked="" type="checkbox"/> Design Review <input type="checkbox"/> Alternate Calculation <input type="checkbox"/> Qualification Testing

VERIFICATION REQUIRED	DISCIPLINE	VERIFICATION COMPLETE AND COMMENTS RESOLVED (DV print, sign, and date)
<input type="checkbox"/>	Electrical	
<input checked="" type="checkbox"/>	Mechanical	Louis F. Liberatori, Jr.  8/25/09
<input type="checkbox"/>	Instrument and Control	
<input type="checkbox"/>	Civil/Structural	
<input type="checkbox"/>	Nuclear	
<input type="checkbox"/>		
<input type="checkbox"/>		
Originator:	<u>J. Bubniak/A. Zografos</u>  8/25/09 Print/Sign/Date After Comments Have Been Resolved	

IDENTIFICATION:		DISCIPLINE:	
Document Title: BHP Input From Design Mechanical – Appendix H		<input type="checkbox"/> Civil/Structural <input type="checkbox"/> Electrical <input type="checkbox"/> I & C <input checked="" type="checkbox"/> Mechanical <input type="checkbox"/> Nuclear <input type="checkbox"/> Other	
Doc. No.: EC - 16788		Rev. 0 QA Cat. SR	
Verifier: <u>Louis F. Liberatori, Jr.</u> Print <u>[Signature]</u> Sign <u>8/28/09</u> Date			
Manager authorization for supervisor performing Verification. <input checked="" type="checkbox"/> N/A N/A Print _____ Sign _____ Date _____			
METHOD OF VERIFICATION:			
Design Review <input checked="" type="checkbox"/> Alternate Calculations <input type="checkbox"/> Qualification Test <input type="checkbox"/>			

The following basic questions are addressed as applicable, during the performance of any design verification. These questions are based on the requirements of ANSI N45.2.11 – 1974.

NOTE The reviewer can use the "Comments/Continuation sheet" at the end for entering any comment/resolution along with the appropriate question number. Additional items with new question numbers can also be entered.

1. Design Inputs – Were the inputs correctly selected and incorporated into the design?
 (Design inputs include design bases, plant operational conditions, performance requirements, regulatory requirements and commitments, codes, standards, field data, etc. All information used as design inputs should have been reviewed and approved by the responsible design organization, as applicable.
 All inputs need to be retrievable or excerpts of documents used should be attached. See site specific design input procedures for guidance in identifying inputs.)
 Yes No N/A

See attached Comment Sheet.
2. Assumptions – Are assumptions necessary to perform the design activity adequately described and reasonable? Where necessary, are assumptions identified for subsequent re-verification when the detailed activities are completed? Are the latest applicable revisions of design documents utilized?
 Yes No N/A

See attached Comment Sheet.
3. Quality Assurance – Are the appropriate quality and quality assurance requirements specified?
 Yes No N/A

4. Codes, Standards and Regulatory Requirements – Are the applicable codes, standards and regulatory requirements, including issue and addenda properly identified and are their requirements for design met?
Yes No N/A
5. Construction and Operating Experience – Have applicable construction and operating experience been considered?
Yes No N/A
6. Interfaces – Have the design interface requirements been satisfied and documented?
Yes No N/A
- See attached Comment Sheet.
7. Methods – Was an appropriate design or analytical (for calculations) method used?
Yes No N/A
8. Design Outputs – Is the output reasonable compared to the inputs?
Yes No N/A
9. Parts, Equipment and Processes – Are the specified parts, equipment, and processes suitable for the required application?
Yes No N/A
10. Materials Compatibility – Are the specified materials compatible with each other and the design environmental conditions to which the material will be exposed?
Yes No N/A
11. Maintenance requirements – Have adequate maintenance features and requirements been specified?
Yes No N/A
12. Accessibility for Maintenance – Are accessibility and other design provisions adequate for performance of needed maintenance and repair?
Yes No N/A
13. Accessibility for In-service Inspection – Has adequate accessibility been provided to perform the in-service inspection expected to be required during the plant life?
Yes No N/A
14. Radiation Exposure – Has the design properly considered radiation exposure to the public and plant personnel?
Yes No N/A
15. Acceptance Criteria – Are the acceptance criteria incorporated in the design documents sufficient to allow verification that design requirements have been satisfactorily accomplished?
Yes No N/A

Sheet 3 of 3

16. Test Requirements – Have adequate pre-operational and subsequent periodic test requirements been appropriately specified?
Yes No N/A
17. Handling, Storage, Cleaning and Shipping – Are adequate handling, storage, cleaning and shipping requirements specified?
Yes No N/A
18. Identification Requirements – Are adequate identification requirements specified?
Yes No N/A
19. Records and Documentation – Are requirements for record preparation, review, approval, retention, etc., adequately specified? Are all documents prepared in a clear legible manner suitable for microfilming and/or other documentation storage method? Have all impacted documents been identified for update as necessary?
Yes No N/A
20. Software Quality Assurance- ENN sites: For a calculation that utilized software applications (e.g., GOTHIC, SYMCORD), was it properly verified and validated in accordance with EN- IT-104 or previous site SQA Program?
ENS sites: This is an EN-IT-104 task. However, per ENS-DC-126, for exempt software, was it verified in the calculation?
Yes No N/A
21. *Has adverse impact on peripheral components and systems, outside the boundary of the document being verified, been considered?*
Yes No N/A

Question #	Comments	Resolution	Initial/Date
1.	Pg. 1 of 5 (Containment Recirculation Pump Input): The four cases listed are for one (1) RHR HX cases only. This is stated to be based on the GSI-191 calc IP-CALC-07-00054, Rev 2 (West. CN-SEE-05-107, Rev. 2). This calc is not formally active at this point (pending issuance of EC-2812) and the EOP changes to implement the one RHR HX restrictions are not yet issued. The BHPs are for the flows taken from a combination of that above calc and the IP-CALC-04-0809, Rev. 2 Calc. Current plant operation could have one or two HXs available.	It is agreed that the GSI-191 related calcs are still formally in "pending" status. It is also acknowledged that the EOPs as currently written still permit 2 RHR Ht Exchanger operation. However, it has been confirmed that the flow rates for applicable pumps determined in SEE-05-107 R2 bound the max flow rates from previous analyses. Thus from an analytical perspective, the flow rates used are conservative for Bhp determination (and moreover, they will be correct going forward). The Bhp values for the two RHR Ht Exch cases have been included in the EDG Loading Input Clarification.	A.P.B. 8/25/09 LH 8/25/09
2.	Pg. 1 of 5 (Containment Recirculation Pump Input): The HHSI recirc flow for LBLOCA is listed as 1500 gpm and the HHSI recirc case for SBLOCA is listed as 1420 gpm. What are the bases of these numbers and why different?	Based on SEE-03-59 R 0 Table 2, the maximum runout flow of two HHSI Pumps is approximately 1330 gpm for a LBLOCA. When this is added to the nominal 170 gpm IR Pump recirc miniflow, the 1500 gpm flow rate is obtained that is used in the 809 calc. For a SBLOCA, where some RCS backpressure exists, verbal input from Westinghouse recommended that a 2 pump maximum flow rate of 1250 gpm would be reasonably conservative. When the 170 gpm for the IR Pump miniflow is added, the 1420 gpm value in the 809 calc is obtained.	A.P.B. 8/25/09 LH 8/25/09
3.	Pg 3 and 4 of 5 (High Head Safety Injection Pump Input): The BHPs for each pump are identified as being different based on the differences in the individual pump curves. The curves and the different values are derived from the IP-CALC-04-0809, Rev. 2 calculation. The curves used were the original plant pump curves. Based on the information contained in Calculation CN-SEE-03-59, Rev. 0, the current IP3 SI pumps all have different curves. Therefore, the BHPs derived from the original curves need to be assessed against the information contained in the current pump curves.	The performance data and curves, where available, for the actually installed HHSI Pumps were compared to the curves used in IP-CALC-04-0809 R2. It was found that within the readability of all the curves, the curves contained in the calc would be deemed acceptable for use in determining BHP. In other words, the performance of the installed HHSI Pumps 31, 32, and 33 are not sufficiently different from the performance of the Pumps analyzed in the BHP calculation to alter the BHP results obtained. The discrepancy in curve usage in the calculation will be addressed as a separate issue.	A.P.B. 8/25/09 LH 8/25/09
4.	Pg. 4 of 5 (High Head Safety Injection Pump Input): The BHPs provided for the Hot Leg Recirc cases are derived from IP-CALC-04-0809, Rev. 2. The value of 540.3 gpm seems to be based on Westinghouse references noted, but the 540 value seems to be based on a minimum SI pump performance case rather than maximum SI pump performance.	IP-CALC-04-0809 R2 may have cited an unconservative flow rate for the HL Recirc case. However, in the revised EDG Loading Input Clarification writeup, it has been decided to recommend to Electrical Engineering that they employ the conservative BHP value of 414 Hp (basically related to HHSI Pump injection phase runout flow at 60° F) for all LOCA scenarios. For HL Recirc, the fluid temperature would be higher (ie, lower fluid density), so even with a potentially slightly higher flow rate associated with boost operation, the HHSIP BHP would be no higher than 414 BHP.	A.P.B. 8/25/09 LH 8/25/09

<p>5.</p>	<p>Pg. 4 and 5 of 5 (Containment Recirculation Fan (Fan Cooler Unit) Input: The 155 BHP value for a 5 FCU case is not based on a "cold" service water temperature run from the referenced calculation CN-CRA-08-11, but rather judgment and comparison to the 3 FCU cases run in that calc. In addition, reference to a superseded calc IP3-CALC-ED-00293, Rev. 1, is made since it contained an earlier run for 5 FCUs, but at "hot" service water conditions. We shouldn't be using superseded calculations for references. The CN-CRA-08-11 calc is based on "cold" service water and only calculates a BHP for 3 FCU cases (ie: 159BHP). In addition, since there are no like cases to compare, it is not clear whether "hot" or "cold" service water yields higher BHPs for the FCUs. So it's not clear whether either of the 159 BHP or the 155 BHP values are limiting values.</p>	<p>Based on the comment, Westinghouse was contacted to discuss calc CN-CRA-08-11. This discussion and the subsequent assessment of available information pertaining to FCU BHP determination methodology concluded that 159 Hp is a bounding BHP value. The number of FCUs operating affects the per FCU air/steam flow rate and also the post-accident VC atmospheric conditions. The temperature of the Service Water being delivered to the FCUs also slightly affects the per FCU flow rate, but more significantly affects the VC conditions (temperature and pressure). A qualitative evaluation of the combination of these effects, with input from the SPU Project reconciled IP2 EDG Loading Study, has led Westinghouse and IPEC engineering to conclude that the 159 Hp value is limiting. Thus, in the revised EDG Loading Input Clarification writeup, it has been decided to recommend to Electrical Engineering that they use 159 Hp input for 3, 4, and 5 FCUs operating.</p>	<p><i>J.R.B.</i> <i>8/25/09</i></p> <p><i>LR</i> <i>8/25/09</i></p>
-----------	---	--	---

Legend (Typical for all reports)

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES

ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 5

EO - ACCIDENT NOT IDENTIFIED
RCS PRESS>275, PHASE B

This is a computer generated number.
It is not related to the technical
portion of the software.

LOAD LIST TRACKING NUMBER : 508

Report Print Date : April 16, 1997
Report Print Time : 2:01 PM

*** BUSES 2A AND 3A TIED TOGETHER ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 3018.3 Bus 2A/3A = 3189.1 Bus 6A = 3505.5 (A)

3200 Amp Overload Summary


Bus 5A is below the 3200 Amp rating
Bus 2A/3A is below the 3200 Amp rating
Bus 6A exceeds the 3200 Amp rating at EOP steps : 13

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

This is not the actual EOP Step number. It only
represents a sequential number of the loading for this
scenario. To relate this number with a particular EOP,
see the example on page 3 of this Appendix.

E0 - ACCIDENT NOT IDENTIFIED



This is a sequential number not the particular EOP step. To relate this number with a particular EOP, see the example on page 3 of Appendix A.1.

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 11 -	---	RO-1-20	-98 -100 PAB FANS 31, 32 (Only 1 Fan Required)	Manual	0.0	189.3	189.3
			+69 +70		2562.4	2734.1	3049.6
- 12 -	E-0-26	---	CHARGING PUMPs 31,32,33 (Only 1 Pump Required)	Manual	0.0	0.0	0.0
			(No Loads Started or Tripped at this step)		2562.4	2734.1	3049.6
- 13 -	---	RO-1-23	NESWP 31,32,33 (Only 1 Pump Required)	Manual	455.9	455.0	455.9
			+66 +67 +68		3018.3	3189.1	3505.5
							Over 3200

Status of load; started, tripped or not running.

This is a typical EOP step.

Sub-Total

+ Means load is started
- Means load is stopped.

Actual EOP step

Sequential numbering of loading

These numbers identify the loads being started or tripped in this step. See Master Load List (Appendix A.10) for a listing of these numbers, their description, Amp and kW values.

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

MASTER LOAD LIST
LOADS ON ALL BUSES

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : September 14, 2009
Report Print Time : 1:42 PM

MASTER LOAD LIST

Report Date : September 14, 2009 Time : 1:42 PM (55)

Load Name	Bus Connected To	All Buses Available (Amps)	W-out LOOP		All Buses Available (kW)	With LOOP		Terminal Voltage \ Load Reference
			Loss Of First Bus (Amps)	Loss Of Second Bus (Amps)		Loss Of First Bus (kW)	Loss Of Second Bus (kW)	
1:AFWP 31	3A	575.4	575.4	575.4	378.9	378.9	378.9	437.1V @ Motor
2:AFWP 33	6A	562.9	562.9	562.9	375.7	375.7	375.7	433.0 V @ Motor
3:BUS 2A/3A MCC RESETS	2A/3A	407.2	407.2	407.2	0.0	0.0	0.0	441.6V @ MCC
4:CCWP 31	5A	250.5	293.4	293.4	169.0	198.1	198.1	437.4V @ Motor
5:CCWP 31 (2 RUNNING OR 3 RUN AND 1 STOPPED)	5A	293.4	293.4	293.4	198.1	198.1	198.1	437.4V @ Motor
6:CCWP 31 (ONE RUNNING)	5A	325.4	325.4	325.4	219.6	219.6	219.6	437.4V @ Motor
7:CCWP 32	2A	251.3	294.4	294.4	169.0	198.1	198.1	436.0V @ Motor
8:CCWP 32 (2 RUNNING OR 3 RUN AND 1 STOPPED)	2A	294.4	294.4	294.4	198.1	198.1	198.1	436.0V @ Motor
9:CCWP 32 (ONE RUNNING)	2A	326.4	326.4	326.4	219.6	219.6	219.6	436.0V @ Motor
10:CCWP 33	6A	251.2	294.2	294.2	169.0	198.1	198.1	436.3V @ Motor
11:CCWP 33 (2 RUNNING OR 3 RUN AND 1 STOPPED)	6A	294.2	294.2	294.2	198.1	198.1	198.1	436.3V @ Motor
12:CCWP 33 (ONE RUNNING)	6A	326.2	326.2	326.2	219.6	219.6	219.6	436.3V @ Motor
13:CHARGING PUMP 31	5A	208.5	208.5	208.5	140.2	140.2	140.2	432.0V @ Motor
14:CHARGING PUMP 32	3A	208.9	208.9	208.9	140.2	140.2	140.2	431.1V @ Motor
15:CHARGING PUMP 33	6A	209.6	209.6	209.6	140.2	140.2	140.2	429.6V @ Motor
16:CRP 31 (LBLOCA COLD LEG & RECIRC SPRAY)	5A	472.5	472.5	472.5	309.0	309.0	309.0	432.0 V @ Motor
17:CRP 31 (LBLOCA POST RECIRC SPRAY)	5A	324.2	324.2	324.2	206.2	206.2	206.2	432.0 V @ Motor
18:CRP 31 (SBLOCA HIGH HEAD SI & RECIRC SPRAY)	5A	468.3	468.3	468.3	306.3	306.3	306.3	432.0 V @ Motor
19:CRP 31 (SBLOCA HIGH HEAD SI, POST RECIRC S)	5A	321.7	321.7	321.7	204.6	204.6	204.6	432.0 V @ Motor
20:CRP 32 (LBLOCA COLD LEGS & RECIRC SPRAY)	6A	472.5	472.5	472.5	309.0	309.0	309.0	432.0 V @ Motor
21:CRP 32 (LBLOCA HOT LEG, POST RECIRC SPRAY)	6A	324.2	324.2	324.2	206.2	206.2	206.2	432.0 V @ Motor
22:CRP 32 (SBLOCA HIGH HEAD SI, POST RECIRC S)	6A	321.7	321.7	321.7	204.6	204.6	204.6	432.0 V @ Motor
23:CRP 32 (SBLOCA HIGH HEAD SI, RECIRC SPRAY)	6A	468.3	468.3	468.3	306.3	306.3	306.3	432.0 V @ Motor
24:CSP 31	5A	453.6	453.6	453.6	307.3	307.3	307.3	437.9V @ Motor
25:CSP 32	6A	471.1	471.1	471.1	319.5	319.5	319.5	437.5V @ Motor
26:ESWP 34	5A	429.8	429.8	429.8	280.8	280.8	280.8	431.0V @ Motor
27:ESWP 35	3A	429.0	429.0	429.0	280.8	280.8	280.8	431.8V @ Motor
28:ESWP 36	6A	429.8	429.8	429.8	280.8	280.8	280.8	431.0V @ Motor
29:FCU 31	5A	245.2	245.2	245.2	129.0	129.0	129.0	434.6V @ Motor
30:FCU 31 (5 RUNNING AND 1 STOPPED)	5A	245.2	245.2	245.2	129.0	129.0	129.0	434.6V @ Motor
31:FCU 32	2A	247.2	247.2	247.2	129.0	129.0	129.0	431.1V @ Motor
32:FCU 32 (5 RUNNING AND 1 STOPPED)	2A	247.2	247.2	247.2	129.0	129.0	129.0	431.1V @ Motor
33:FCU 33	5A	246.7	246.7	246.7	129.0	129.0	129.0	432.0V @ Motor
34:FCU 33 (5 RUNNING AND 1 STOPPED)	5A	246.7	246.7	246.7	129.0	129.0	129.0	432.0V @ Motor
35:FCU 34	3A	246.0	246.0	246.0	129.0	129.0	129.0	433.2V @ Motor
36:FCU 34 (5 RUNNING AND 1 STOPPED)	3A	246.0	246.0	246.0	129.0	129.0	129.0	433.2V @ Motor
37:FCU 35	6A	248.0	248.0	248.0	129.0	129.0	129.0	429.6V @ Motor
38:FCU 35 (5 RUNNING AND 1 STOPPED)	6A	248.0	248.0	248.0	129.0	129.0	129.0	429.6V @ Motor
39:MCC 32 : BATTERY CHARGER 34	3A	16.6	16.6	16.6	12.0	12.0	12.0	437.9V @ MCC
40:MCC 32 : MAIN GEN SEAL OIL PUMP	3A	64.4	64.4	64.4	41.5	41.5	41.5	437.9V @ MCC
41:MCC 32 : MBFP MAIN OIL PUMP 31	3A	75.6	75.6	75.6	48.7	48.7	48.7	437.9V @ MCC
42:MCC 33 : MBFP MAIN OIL PUMP 32	2A	75.6	75.6	75.6	48.7	48.7	48.7	437.0V @ MCC
43:MCC 34 : EDG AIR COMPRESSOR 31	2A	6.6	6.6	6.6	4.1	4.1	4.1	441.6V @ MCC
44:MCC 34 : EDG EXHAUST HOOD BLOWER 31	2A	1.0	1.0	1.0	0.6	0.6	0.6	441.6V @ MCC

MASTER LOAD LIST

Report Date : September 14, 2009 Time : 1:42 PM [55]

Load Name	Bus Connected To	W-out LOOP		With LOOP		Terminal Voltage \ Load Reference		
		All Buses Available (Amps)	Loss Of First Bus (Amps)	Loss Of Second Bus (Amps)	All Buses Available (kw)		Loss Of First Bus (kw)	Loss Of Second Bus (kw)
45:MCC 34 : IA CLOSED COOLING PUMP 32	2A	3.1	3.1	3.1	2.0	2.0	2.0	441.6V @ MCC
46:MCC 34 : IA COMPRESSOR 32	2A	68.5	68.5	68.5	44.5	44.5	44.5	441.6V @ MCC
47:MCC 34 : MAIN TURBINE TURNING GEAR	2A	63.8	63.8	63.8	41.5	41.5	41.5	441.6V @ MCC
48:MCC 35 : MAIN TURBINE BEARING OIL PUMP	3A	96.0	96.0	96.0	62.1	62.1	62.1	439.0V @ MCC
49:MCC 35 : TURBINE TURNING GEAR OIL PUMP	3A	96.0	96.0	96.0	62.1	62.1	62.1	439.0V @ MCC
50:MCC 36A : AUTO	5A	138.4	138.4	138.4	89.9	89.9	89.9	436.6V @ MCC
51:MCC 36A : ELECTRICAL TUNNEL EXHAUST FAN 31	5A	9.6	9.6	9.6	6.2	6.2	6.2	436.6V @ MCC
52:MCC 36A : ELECTRICAL TUNNEL EXHAUST FAN 33	5A	9.6	9.6	9.6	6.2	6.2	6.2	436.6V @ MCC
53:MCC 36B : AUTO	6A	119.2	119.2	119.2	80.3	80.3	80.3	438.3V @ MCC
54:MCC 36B : ELECTRICAL TUNNEL EXHAUST FAN 32	6A	9.6	9.6	9.6	6.2	6.2	6.2	438.3V @ MCC
55:MCC 36B : ELECTRICAL TUNNEL EXHAUST FAN 34	6A	9.6	9.6	9.6	6.2	6.2	6.2	438.3V @ MCC
56:MCC 36B : H2 RECOMBINER 32	6A	115.3	115.3	115.3	75.0	75.0	75.0	438.3V @ MCC
57:MCC 36C : AUTO	2A	135.5	135.5	135.5	94.3	94.3	94.3	444.0V @ MCC
58:MCC 36C : H2 RECOMBINER 31	2A	115.3	115.3	115.3	75.0	75.0	75.0	444.0V @ MCC
59:MCC 36D : AUTO	6A	30.9	30.9	30.9	20.1	20.1	20.1	438.3V @ MCC
60:MCC 36E : AUTO	5A	31.1	31.1	31.1	20.1	20.1	20.1	436.6V @ MCC
61:MCC 37 : BAST HEATER (TANK 31)	6A	19.6	19.6	19.6	15.0	15.0	15.0	441.8V @ MCC
62:MCC 37 : BAST HEATER (TANK 32)	6A	19.6	19.6	19.6	15.0	15.0	15.0	441.8V @ MCC
63:MCC 37 : BATTERY CHARGER 32	6A	27.6	27.6	27.6	20.0	20.0	20.0	441.8V @ MCC
64:MCC 37 : EDG AIR COMPRESSOR 32	6A	6.6	6.6	6.6	4.1	4.1	4.1	441.8V @ MCC
65:MCC 37 : EDG EXHAUST HOOD BLOWER 32	6A	1.0	1.0	1.0	0.6	0.6	0.6	441.8V @ MCC
66:MCC 37 : PENETRATION BLOWER (# 1)	6A	23.1	23.1	23.1	15.0	15.0	15.0	441.8V @ MCC
67:MCC 37 : PENETRATION BLOWER (# 2)	6A	23.1	23.1	23.1	15.0	15.0	15.0	441.8V @ MCC
68:MCC 37 : PW NU PUMP (31 OR 34)	6A	31.9	31.9	31.9	20.7	20.7	20.7	441.8V @ MCC
69:MCC 37 : SPENT FUEL POOL CLG PUMP 31	6A	107.9	107.9	107.9	70.1	70.1	70.1	441.8V @ MCC
70:MCC 38 : CRDM FAN 31	5A	31.3	31.3	31.3	20.1	20.1	20.1	437.3V @ MCC
71:MCC 38 : CRDM FAN 32	5A	31.3	31.3	31.3	20.1	20.1	20.1	437.3V @ MCC
72:MCC 38 : CRDM FAN 33	5A	31.3	31.3	31.3	20.1	20.1	20.1	437.3V @ MCC
73:MCC 38 : CRDM FAN 34	5A	31.3	31.3	31.3	20.1	20.1	20.1	437.3V @ MCC
74:MCC 39 : BATTERY CHARGER 31	5A	40.2	40.2	40.2	29.3	29.3	29.3	443.4V @ MCC
75:MCC 39 : EDG AIR COMPRESSOR 33	5A	6.6	6.6	6.6	4.1	4.1	4.1	443.4V @ MCC
76:MCC 39 : EDG EXHAUST HOOD BLOWER 33	5A	1.0	1.0	1.0	0.6	0.6	0.6	443.4V @ MCC
77:MCC 39 : IA CLOSED COOLING PUMP 31	5A	3.1	3.1	3.1	2.0	2.0	2.0	443.4V @ MCC
78:MCC 39 : IA COMPRESSOR 31	5A	76.2	76.2	76.2	49.7	49.7	49.7	443.4V @ MCC
79:MCC 39 : SAT AUX (E)	5A	29.2	29.2	29.2	21.3	21.3	21.3	443.4V @ MCC
80:MCC 39 : SPENT FUEL POOL CLG PUMP 32	5A	107.9	107.9	107.9	70.1	70.1	70.1	443.4V @ MCC
81:MCCS RESET (2A/3A) AS PER SOP-EL-15	2A/3A	95.6	95.6	95.6	63.3	63.3	63.3	441.6V @ MCC
82:MCCS RESET (5A) AS PER SOP-EL-15	5A	126.9	126.9	126.9	85.8	85.8	85.8	443.4V @ MCC
83:MCCS RESET (6A) AS PER SOP-EL-15	6A	35.0	35.0	35.0	24.8	24.8	24.8	441.8V @ MCC
84:NESWP 31	5A	429.8	429.8	429.8	280.8	280.8	280.8	431.0V @ Motor
85:NESWP 32	2A	429.0	429.0	429.0	280.8	280.8	280.8	431.8V @ Motor
86:NESWP 33	6A	429.8	429.8	429.8	280.8	280.8	280.8	431.0V @ Motor
87:PAB FAN 31	3A	177.0	177.0	177.0	114.3	114.3	114.3	438.7V @ Motor
88:PAB FAN 32	6A	177.0	177.0	177.0	114.3	114.3	114.3	438.7V @ Motor

MASTER LOAD LIST

Report Date : September 14, 2009 Time : 1:42 PM (55)

Load Name	Bus Connected To	All Buses Available (Amps)	W-out LOOP		All Buses Available (kW)	With LOOP		Terminal Voltage Load Reference
			Loss Of First Bus (Amps)	Loss Of Second Bus (Amps)		Loss Of First Bus (kW)	Loss Of Second Bus (kW)	
89: PRESSURIZER HEATER 31	3A	618.2	618.2	618.2	555.0	555.0	555.0	444.0V @ Heater
90: PRESSURIZER HEATER 31 (1 CIRCUIT)	3A	77.3	77.3	77.3	69.4	69.4	69.4	444.0V @ Heater
91: PRESSURIZER HEATER 31 (2 CIRCUITS)	3A	154.6	154.6	154.6	138.8	138.8	138.8	444.0V @ Heater
92: PRESSURIZER HEATER 31 (3 CIRCUITS)	3A	231.9	231.9	231.9	208.2	208.2	208.2	444.0V @ Heater
93: PRESSURIZER HEATER 31 (4 CIRCUITS)	3A	309.2	309.2	309.2	277.6	277.6	277.6	444.0V @ Heater
94: PRESSURIZER HEATER 31 (5 CIRCUITS)	3A	386.5	386.5	386.5	347.0	347.0	347.0	444.0V @ Heater
95: PRESSURIZER HEATER 31 (6 CIRCUITS)	3A	463.8	463.8	463.8	416.4	416.4	416.4	444.0V @ Heater
96: PRESSURIZER HEATER 31 (7 CIRCUITS)	3A	541.1	541.1	541.1	485.8	485.8	485.8	444.0V @ Heater
97: PRESSURIZER HEATER 31 (8 CIRCUITS)	3A	618.2	618.2	618.2	555.0	555.0	555.0	444.0V @ Heater
98: PRESSURIZER HEATER 32	2A	540.3	540.3	540.3	485.0	485.0	485.0	444.0V @ Heater
99: PRESSURIZER HEATER 32 (1 CIRCUIT)	2A	77.2	77.2	77.2	69.3	69.3	69.3	444.0V @ Heater
100: PRESSURIZER HEATER 32 (2 CIRCUITS)	2A	154.4	154.4	154.4	138.6	138.6	138.6	444.0V @ Heater
101: PRESSURIZER HEATER 32 (3 CIRCUITS)	2A	231.6	231.6	231.6	207.9	207.9	207.9	444.0V @ Heater
102: PRESSURIZER HEATER 32 (4 CIRCUITS)	2A	308.8	308.8	308.8	277.2	277.2	277.2	444.0V @ Heater
103: PRESSURIZER HEATER 32 (5 CIRCUITS)	2A	386.5	386.5	386.5	346.5	346.5	346.5	444.0V @ Heater
104: PRESSURIZER HEATER 32 (6 CIRCUITS)	2A	463.2	463.2	463.2	415.8	415.8	415.8	444.0V @ Heater
105: PRESSURIZER HEATER 32 (7 CIRCUITS)	2A	540.3	540.3	540.3	485.0	485.0	485.0	444.0V @ Heater
106: PRESSURIZER HEATER 33	5A	540.3	540.3	540.3	485.0	485.0	485.0	444.0V @ Heater
107: PRESSURIZER HEATER 33 (1 CIRCUIT)	5A	77.2	77.2	77.2	69.3	69.3	69.3	444.0V @ Heater
108: PRESSURIZER HEATER 33 (2 CIRCUITS)	5A	154.4	154.4	154.4	138.6	138.6	138.6	444.0V @ Heater
109: PRESSURIZER HEATER 33 (3 CIRCUITS)	5A	231.6	231.6	231.6	207.9	207.9	207.9	444.0V @ Heater
110: PRESSURIZER HEATER 33 (4 CIRCUITS)	5A	308.8	308.8	308.8	277.2	277.2	277.2	444.0V @ Heater
111: PRESSURIZER HEATER 33 (5 CIRCUITS)	5A	386.0	386.0	386.0	346.5	346.5	346.5	444.0V @ Heater
112: PRESSURIZER HEATER 33 (6 CIRCUITS)	5A	463.2	463.2	463.2	415.8	415.8	415.8	444.0V @ Heater
113: PRESSURIZER HEATER 33 (7 CIRCUITS)	5A	540.3	540.3	540.3	485.0	485.0	485.0	444.0V @ Heater
114: PRESSURIZER HEATER CONTROL GROUP	6A	308.6	308.6	308.6	277.0	277.0	277.0	444.0V @ Heater
115: RHR PUMP 31 (FULL FLOW - 1 OF 2 RUNNING)	3A	459.4	459.4	459.4	316.1	316.1	316.1	438.5V @ Motor
116: RHR PUMP 31 (FULL FLOW)	3A	419.7	419.7	459.4	288.1	288.1	316.1	438.5V @ Motor
117: RHR PUMP 31 (MINI FLOW)	3A	264.5	264.5	264.5	182.0	182.0	182.0	438.5V @ Motor
118: RHR PUMP 32 (FULL FLOW - 1 OF 2 RUNNING)	6A	459.9	459.9	459.9	316.1	316.1	316.1	438.0V @ Motor
119: RHR PUMP 32 (FULL FLOW)	6A	420.2	459.9	420.2	288.1	316.1	288.1	438.0V @ Motor
120: RHR PUMP 32 (MINI FLOW)	6A	264.8	264.8	264.8	182.0	182.0	182.0	438.0V @ Motor
121: SI PUMP 31	5A	472.4	472.4	472.4	327.2	327.2	327.2	439.4V @ Motor
122: SI PUMP 32	2A	472.4	472.4	472.4	327.2	327.2	327.2	438.6V @ Motor
123: SI PUMP 33	6A	473.7	473.7	473.7	327.2	327.2	327.2	438.2V @ Motor
124: TOTAL MCCS & LIGHTING RESET (2A)	2A	848.0	848.0	848.0	0.0	0.0	0.0	444.0V @ MCC
125: TOTAL MCCS & LIGHTING RESET (3A)	3A	507.6	507.6	507.6	0.0	0.0	0.0	444.0V @ MCC
126: TOTAL MCCS & LIGHTING RESET (5A)	5A	659.8	659.8	659.8	0.0	0.0	0.0	444.0V @ MCC
127: TOTAL MCCS & LIGHTING RESET (6A)	6A	252.2	252.2	252.2	0.0	0.0	0.0	444.0V @ MCC

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

MASTER LOAD LIST (6.9KV EQUIVALENT AMPS)
LOADS ON ALL BUSES

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : September 14, 2009
Report Print Time : 1:42 PM

MASTER LOAD LIST (6.9kV EQUIVALENT AMPS)

Report Date : September 14, 2009 Time : 1:42 PM (55)

Load Name	Bus Connected To	430V		6.9kV Eqvt		Terminal Voltage \ Load Reference		
		All Buses Available (Amps)	Loss Of First Bus (Amps)	Loss Of Second Bus (Amps)	All Buses Available (Amps)		Loss Of First Bus (Amps)	Loss Of Second Bus (Amps)
1:AFWP 31	3A	575.4	575.4	575.4	40.8	40.8	40.8	437.1V @ Motor
2:AFWP 33	6A	562.9	562.9	562.9	39.9	39.9	39.9	433.0 V @ Motor
3:BUS 2A/3A MCC RESETS	2A/3A	407.2	407.2	407.2	28.9	28.9	28.9	441.6V @ MCC
4:CCWP 31	5A	250.5	293.4	293.4	17.8	20.8	20.8	437.4V @ Motor
5:CCWP 31 (2 RUNNING OR 3 RUN AND 1 STOPPED)	5A	293.4	293.4	293.4	20.8	20.8	20.8	437.4V @ Motor
6:CCWP 31 (ONE RUNNING)	5A	325.4	325.4	325.4	23.1	23.1	23.1	437.4V @ Motor
7:CCWP 32	2A	251.3	294.4	294.4	17.8	20.9	20.9	436.0V @ Motor
8:CCWP 32 (2 RUNNING OR 3 RUN AND 1 STOPPED)	2A	294.4	294.4	294.4	20.9	20.9	20.9	436.0V @ Motor
9:CCWP 32 (ONE RUNNING)	2A	326.4	326.4	326.4	23.2	23.2	23.2	436.0V @ Motor
10:CCWP 33	6A	251.2	294.2	294.2	17.8	20.9	20.9	436.3V @ Motor
11:CCWP 33 (2 RUNNING OR 3 RUN AND 1 STOPPED)	6A	294.2	294.2	294.2	20.9	20.9	20.9	436.3V @ Motor
12:CCWP 33 (ONE RUNNING)	6A	326.2	326.2	326.2	23.1	23.1	23.1	436.3V @ Motor
13:CHARGING PUMP 31	5A	208.5	208.5	208.5	14.8	14.8	14.8	432.0V @ Motor
14:CHARGING PUMP 32	3A	208.9	208.9	208.9	14.8	14.8	14.8	431.1V @ Motor
15:CHARGING PUMP 33	6A	209.6	209.6	209.6	14.9	14.9	14.9	429.6V @ Motor
16:CRP 31 (LBLOCA COLD LEG & RECIRC SPRAY)	5A	472.5	472.5	472.5	33.5	33.5	33.5	432.0 V @ Motor
17:CRP 31 (LBLOCA POST RECIRC SPRAY)	5A	324.2	324.2	324.2	23.0	23.0	23.0	432.0 V @ Motor
18:CRP 31 (SBLOCA HIGH HEAD SI & RECIRC SPRAY)	5A	468.3	468.3	468.3	33.2	33.2	33.2	432.0 V @ Motor
19:CRP 31 (SBLOCA HIGH HEAD SI, POST RECIRC S)	5A	321.7	321.7	321.7	22.8	22.8	22.8	432.0 V @ Motor
20:CRP 32 (LBLOCA COLD LEGS & RECIRC SPRAY)	6A	472.5	472.5	472.5	33.5	33.5	33.5	432.0 V @ Motor
21:CRP 32 (LBLOCA HOT LEG, POST RECIRC SPRAY)	6A	324.2	324.2	324.2	23.0	23.0	23.0	432.0 V @ Motor
22:CRP 32 (SBLOCA HIGH HEAD SI, POST RECIRC S)	6A	321.7	321.7	321.7	22.8	22.8	22.8	432.0 V @ Motor
23:CRP 32 (SBLOCA HIGH HEAD SI, RECIRC SPRAY)	6A	468.3	468.3	468.3	33.2	33.2	33.2	432.0 V @ Motor
24:CSP 31	5A	453.6	453.6	453.6	32.2	32.2	32.2	437.9V @ Motor
25:CSP 32	6A	471.1	471.1	471.1	33.4	33.4	33.4	437.5V @ Motor
26:ESWP 34	5A	429.8	429.8	429.8	30.5	30.5	30.5	431.0V @ Motor
27:ESWP 35	3A	429.0	429.0	429.0	30.4	30.4	30.4	431.8V @ Motor
28:ESWP 36	6A	429.8	429.8	429.8	30.5	30.5	30.5	431.0V @ Motor
29:FCU 31	5A	245.2	245.2	245.2	17.4	17.4	17.4	434.6V @ Motor
30:FCU 31 (5 RUNNING AND 1 STOPPED)	5A	245.2	245.2	245.2	17.4	17.4	17.4	434.6V @ Motor
31:FCU 32	2A	247.2	247.2	247.2	17.5	17.5	17.5	431.1V @ Motor
32:FCU 32 (5 RUNNING AND 1 STOPPED)	2A	247.2	247.2	247.2	17.5	17.5	17.5	431.1V @ Motor
33:FCU 33	5A	246.7	246.7	246.7	17.5	17.5	17.5	432.0V @ Motor
34:FCU 33 (5 RUNNING AND 1 STOPPED)	5A	246.7	246.7	246.7	17.5	17.5	17.5	432.0V @ Motor
35:FCU 34	3A	246.0	246.0	246.0	17.5	17.5	17.5	433.2V @ Motor
36:FCU 34 (5 RUNNING AND 1 STOPPED)	3A	246.0	246.0	246.0	17.5	17.5	17.5	433.2V @ Motor
37:FCU 35	6A	248.0	248.0	248.0	17.6	17.6	17.6	429.6V @ Motor
38:FCU 35 (5 RUNNING AND 1 STOPPED)	6A	248.0	248.0	248.0	17.6	17.6	17.6	429.6V @ Motor
39:MCC 32 : BATTERY CHARGER 34	3A	16.6	16.6	16.6	1.2	1.2	1.2	437.9V @ MCC
40:MCC 32 : MAIN GEN SEAL OIL PUMP	3A	64.4	64.4	64.4	4.6	4.6	4.6	437.9V @ MCC
41:MCC 32 : MBFP MAIN OIL PUMP 31	3A	75.6	75.6	75.6	5.4	5.4	5.4	437.9V @ MCC
42:MCC 33 : MBFP MAIN OIL PUMP 32	2A	75.6	75.6	75.6	5.4	5.4	5.4	437.0V @ MCC
43:MCC 34 : EDG AIR COMPRESSOR 31	6A	6.6	6.6	6.6	0.5	0.5	0.5	441.6V @ MCC
44:MCC 34 : EDG EXHAUST HOOD BLOWER 31	2A	1.0	1.0	1.0	0.1	0.1	0.1	441.6V @ MCC

MASTER LOAD LIST (6.9KV EQUIVALENT AMPS)

Report Date : September 14, 2009 Time : 1:42 PM [55]

Load Name	Bus Connected To	480V			6.9kV Eqvt			Terminal Voltage \ Load Reference
		All Buses Available (Amps)	Loss Of First Bus (Amps)	Loss Of Second Bus (Amps)	All Buses Available (Amps)	Loss Of First Bus (Amps)	Loss Of Second Bus (Amps)	
45:MCC 34 : IA CLOSED COOLING PUMP 32	2A	3.1	3.1	3.1	0.2	0.2	0.2	441.6V @ MCC
46:MCC 34 : IA COMPRESSOR 32	2A	68.5	68.5	68.5	4.9	4.9	4.9	441.6V @ MCC
47:MCC 34 : MAIN TURBINE TURNING GEAR	2A	63.8	63.8	63.8	4.5	4.5	4.5	441.6V @ MCC
48:MCC 35 : MAIN TURBINE BEARING OIL PUMP	3A	96.0	96.0	96.0	6.8	6.8	6.8	439.0V @ MCC
49:MCC 35 : TURBINE TURNING GEAR OIL PUMP	3A	96.0	96.0	96.0	6.8	6.8	6.8	439.0V @ MCC
50:MCC 36A : AUTO	5A	138.4	138.4	138.4	9.8	9.8	9.8	436.6V @ MCC
51:MCC 36A : ELECTRICAL TUNNEL EXHAUST FAN 31	5A	9.6	9.6	9.6	0.7	0.7	0.7	436.6V @ MCC
52:MCC 36A : ELECTRICAL TUNNEL EXHAUST FAN 33	5A	9.6	9.6	9.6	0.7	0.7	0.7	436.6V @ MCC
53:MCC 36B : AUTO	6A	119.2	119.2	119.2	8.5	8.5	8.5	438.3V @ MCC
54:MCC 36B : ELECTRICAL TUNNEL EXHAUST FAN 32	6A	9.6	9.6	9.6	0.7	0.7	0.7	438.3V @ MCC
55:MCC 36B : ELECTRICAL TUNNEL EXHAUST FAN 34	6A	9.6	9.6	9.6	0.7	0.7	0.7	438.3V @ MCC
56:MCC 36B : H2 RECOMBINER 32	6A	115.3	115.3	115.3	8.2	8.2	8.2	438.3V @ MCC
57:MCC 36C : AUTO	2A	135.5	135.5	135.5	9.6	9.6	9.6	444.0V @ MCC
58:MCC 36C : H2 RECOMBINER 31	2A	115.3	115.3	115.3	8.2	8.2	8.2	444.0V @ MCC
59:MCC 36D : AUTO	6A	30.9	30.9	30.9	2.2	2.2	2.2	438.3V @ MCC
60:MCC 36E : AUTO	5A	31.1	31.1	31.1	2.2	2.2	2.2	436.6V @ MCC
61:MCC 37 : BAST HEATER (TANK 31)	6A	19.6	19.6	19.6	1.4	1.4	1.4	441.8V @ MCC
62:MCC 37 : BAST HEATER (TANK 32)	6A	19.6	19.6	19.6	1.4	1.4	1.4	441.8V @ MCC
63:MCC 37 : BATTERY CHARGER 32	6A	27.6	27.6	27.6	2.0	2.0	2.0	441.8V @ MCC
64:MCC 37 : EDG AIR COMPRESSOR 32	6A	6.6	6.6	6.6	0.5	0.5	0.5	441.8V @ MCC
65:MCC 37 : EDG EXHAUST HOOD BLOWER 32	6A	1.0	1.0	1.0	0.1	0.1	0.1	441.8V @ MCC
66:MCC 37 : PENETRATION BLOWER (# 1)	6A	23.1	23.1	23.1	1.6	1.6	1.6	441.8V @ MCC
67:MCC 37 : PENETRATION BLOWER (# 2)	6A	23.1	23.1	23.1	1.6	1.6	1.6	441.8V @ MCC
68:MCC 37 : PW MU PUMP (31 OR 34)	6A	31.9	31.9	31.9	2.3	2.3	2.3	441.8V @ MCC
69:MCC 37 : SPENT FUEL POOL CLG PUMP 31	6A	107.9	107.9	107.9	7.7	7.7	7.7	441.8V @ MCC
70:MCC 38 : CRDM FAN 31	5A	31.3	31.3	31.3	2.2	2.2	2.2	437.3V @ MCC
71:MCC 38 : CRDM FAN 32	5A	31.3	31.3	31.3	2.2	2.2	2.2	437.3V @ MCC
72:MCC 38 : CRDM FAN 33	5A	31.3	31.3	31.3	2.2	2.2	2.2	437.3V @ MCC
73:MCC 38 : CRDM FAN 34	5A	31.3	31.3	31.3	2.2	2.2	2.2	437.3V @ MCC
74:MCC 39 : BATTERY CHARGER 31	5A	40.2	40.2	40.2	2.9	2.9	2.9	443.4V @ MCC
75:MCC 39 : EDG AIR COMPRESSOR 33	5A	6.6	6.6	6.6	0.5	0.5	0.5	443.4V @ MCC
76:MCC 39 : EDG EXHAUST HOOD BLOWER 33	5A	1.0	1.0	1.0	0.1	0.1	0.1	443.4V @ MCC
77:MCC 39 : IA CLOSED COOLING PUMP 31	5A	3.1	3.1	3.1	0.2	0.2	0.2	443.4V @ MCC
78:MCC 39 : IA COMPRESSOR 31	5A	76.2	76.2	76.2	5.4	5.4	5.4	443.4V @ MCC
79:MCC 39 : SAT AUX (E)	5A	29.2	29.2	29.2	2.1	2.1	2.1	443.4V @ MCC
80:MCC 39 : SPENT FUEL POOL CLG PUMP 32	5A	107.9	107.9	107.9	7.7	7.7	7.7	443.4V @ MCC
81:MCCS RESET (2A/3A) AS PER SOP-EL-15	2A/3A	95.6	95.6	95.6	6.8	6.8	6.8	441.6V @ MCC
82:MCCS RESET (5A) AS PER SOP-EL-15	5A	126.9	126.9	126.9	9.0	9.0	9.0	443.4V @ MCC
83:MCCS RESET (6A) AS PER SOP-EL-15	6A	35.0	35.0	35.0	2.5	2.5	2.5	441.8V @ MCC
84:NESWP 31	5A	429.8	429.8	429.8	30.5	30.5	30.5	431.0V @ Motor
85:NESWP 32	2A	429.0	429.0	429.0	30.4	30.4	30.4	431.8V @ Motor
86:NESWP 33	6A	429.8	429.8	429.8	30.5	30.5	30.5	431.0V @ Motor
87:PAB FAN 31	3A	177.0	177.0	177.0	12.6	12.6	12.6	438.7V @ Motor
88:PAB FAN 32	6A	177.0	177.0	177.0	12.6	12.6	12.6	438.7V @ Motor

MASTER LOAD LIST (6.9kV EQUIVALENT AMPS)

Report Date : September 14, 2009 Time : 1:42 PM [55]

Load Name	Bus Connected To	480V			6.9kV Eqvt			Terminal Voltage \ Load Reference
		All Buses Available (Amps)	Loss Of First Bus (Amps)	Loss Of Second Bus (Amps)	All Buses Available (Amps)	Loss Of First Bus (Amps)	Loss Of Second Bus (Amps)	
89:PRESSURIZER HEATER 31	3A	618.2	618.2	618.2	43.9	43.9	43.9	444.0V @ Heater
90:PRESSURIZER HEATER 31 (1 CIRCUIT)	3A	77.3	77.3	77.3	5.5	5.5	5.5	444.0V @ Heater
91:PRESSURIZER HEATER 31 (2 CIRCUITS)	3A	154.6	154.6	154.6	11.0	11.0	11.0	444.0V @ Heater
92:PRESSURIZER HEATER 31 (3 CIRCUITS)	3A	231.9	231.9	231.9	16.5	16.5	16.5	444.0V @ Heater
93:PRESSURIZER HEATER 31 (4 CIRCUITS)	3A	309.2	309.2	309.2	21.9	21.9	21.9	444.0V @ Heater
94:PRESSURIZER HEATER 31 (5 CIRCUITS)	3A	386.5	386.5	386.5	27.4	27.4	27.4	444.0V @ Heater
95:PRESSURIZER HEATER 31 (6 CIRCUITS)	3A	463.8	463.8	463.8	32.9	32.9	32.9	444.0V @ Heater
96:PRESSURIZER HEATER 31 (7 CIRCUITS)	3A	541.1	541.1	541.1	38.4	38.4	38.4	444.0V @ Heater
97:PRESSURIZER HEATER 31 (8 CIRCUITS)	3A	618.2	618.2	618.2	43.9	43.9	43.9	444.0V @ Heater
98:PRESSURIZER HEATER 32	2A	540.3	540.3	540.3	38.3	38.3	38.3	444.0V @ Heater
99:PRESSURIZER HEATER 32 (1 CIRCUIT)	2A	77.2	77.2	77.2	5.5	5.5	5.5	444.0V @ Heater
100:PRESSURIZER HEATER 32 (2 CIRCUITS)	2A	154.4	154.4	154.4	11.0	11.0	11.0	444.0V @ Heater
101:PRESSURIZER HEATER 32 (3 CIRCUITS)	2A	231.6	231.6	231.6	16.4	16.4	16.4	444.0V @ Heater
102:PRESSURIZER HEATER 32 (4 CIRCUITS)	2A	308.8	308.8	308.8	21.9	21.9	21.9	444.0V @ Heater
103:PRESSURIZER HEATER 32 (5 CIRCUITS)	2A	386.5	386.5	386.5	27.4	27.4	27.4	444.0V @ Heater
104:PRESSURIZER HEATER 32 (6 CIRCUITS)	2A	463.2	463.2	463.2	32.9	32.9	32.9	444.0V @ Heater
105:PRESSURIZER HEATER 32 (7 CIRCUITS)	2A	540.3	540.3	540.3	38.3	38.3	38.3	444.0V @ Heater
106:PRESSURIZER HEATER 33	5A	540.3	540.3	540.3	38.3	38.3	38.3	444.0V @ Heater
107:PRESSURIZER HEATER 33 (1 CIRCUIT)	5A	77.2	77.2	77.2	5.5	5.5	5.5	444.0V @ Heater
108:PRESSURIZER HEATER 33 (2 CIRCUITS)	5A	154.4	154.4	154.4	11.0	11.0	11.0	444.0V @ Heater
109:PRESSURIZER HEATER 33 (3 CIRCUITS)	5A	231.6	231.6	231.6	16.4	16.4	16.4	444.0V @ Heater
110:PRESSURIZER HEATER 33 (4 CIRCUITS)	5A	308.8	308.8	308.8	21.9	21.9	21.9	444.0V @ Heater
111:PRESSURIZER HEATER 33 (5 CIRCUITS)	5A	386.0	386.0	386.0	27.4	27.4	27.4	444.0V @ Heater
112:PRESSURIZER HEATER 33 (6 CIRCUITS)	5A	463.2	463.2	463.2	32.9	32.9	32.9	444.0V @ Heater
113:PRESSURIZER HEATER 33 (7 CIRCUITS)	5A	540.3	540.3	540.3	38.3	38.3	38.3	444.0V @ Heater
114:PRESSURIZER HEATER CONTROL GROUP	6A	308.6	308.6	308.6	21.9	21.9	21.9	444.0V @ Heater
115:RHR PUMP 31 (FULL FLOW - 1 OF 2 RUNNING)	3A	459.4	459.4	459.4	32.6	32.6	32.6	438.5V @ Motor
116:RHR PUMP 31 (FULL FLOW)	3A	419.7	419.7	459.4	29.8	29.8	32.6	438.5V @ Motor
117:RHR PUMP 31 (MINI FLOW)	3A	264.5	264.5	264.5	18.8	18.8	18.8	438.5V @ Motor
118:RHR PUMP 32 (FULL FLOW - 1 OF 2 RUNNING)	6A	459.9	459.9	459.9	32.6	32.6	32.6	438.0V @ Motor
119:RHR PUMP 32 (FULL FLOW)	6A	420.2	459.9	420.2	29.8	32.6	29.8	438.0V @ Motor
120:RHR PUMP 32 (MINI FLOW)	6A	264.8	264.8	264.8	18.8	18.8	18.8	438.0V @ Motor
121:SI PUMP 31	5A	472.4	472.4	472.4	33.5	33.5	33.5	439.4V @ Motor
122:SI PUMP 32	2A	472.4	472.4	472.4	33.5	33.5	33.5	438.6V @ Motor
123:SI PUMP 33	6A	473.7	473.7	473.7	33.6	33.6	33.6	438.2V @ Motor
124:TOTAL MCCS & LIGHTING RESET (2A)	2A	848.0	848.0	848.0	60.2	60.2	60.2	444.0V @ MCC
125:TOTAL MCCS & LIGHTING RESET (3A)	3A	507.6	507.6	507.6	36.0	36.0	36.0	444.0V @ MCC
126:TOTAL MCCS & LIGHTING RESET (5A)	5A	659.8	659.8	659.8	46.8	46.8	46.8	444.0V @ MCC
127:TOTAL MCCS & LIGHTING RESET (6A)	6A	252.2	252.2	252.2	17.9	17.9	17.9	444.0V @ MCC

LOADING SUMMARY DURING AND END OF ACCIDENT SCENARIOS

Note: The values below do not incorporate cable losses and load increase due to frequency variation

Number	Accident Scenario	Single Failure	Peak Loading During Accident Scenario					Loading at End of Accident Scenario						
			Bus 5A (Amps)	EDG 33 (kW)	Bus 2A/3A (Amps)	EDG 31 (kW)	Bus 6A (Amps)	EDG 32 (kW)	Bus 5A (Amps)	EDG 33 (kW)	Bus 2A/3A (Amps)	EDG 31 (kW)	Bus 6A (Amps)	EDG 32 (kW)
Large Break LOCA														
1	Offsite Power Available	Total MCC and Lighting Reset- All buses Available	2928	-	1975/2387	-	3259	-	2696	-	1975/1360	-	2393	-
2	Offsite Power Available	All Buses Available - Bus 2A and 3A Tied	3136	-	3184	-	3259	-	2696	-	2252	-	2613	-
3	Offsite Power Available	Bus 6A Not Available - Bus 2A and 3A Tied	3419	-	3267	-	-	-	3126	-	3017	-	-	-
4	Offsite Power Available	Bus 5A Not Available - Bus 2A and 3A Tied	-	-	3436	-	3312	-	-	-	2757	-	2748	-
5	Offsite Power Available	Bus 2A and/or 3A Not Available	3179	-	-	-	3342	-	2653	-	-	-	3043	-
6	Loss of Offsite Power	All Buses Available - Bus 2A and 3A Tied	-	1509	-	1691	-	1846	-	1371	-	1217	-	1559
7	Loss of Offsite Power	Bus 6A Not Available - Bus 2A and 3A Tied	-	1652	-	1719	-	-	-	1652	-	1474	-	-
8	Loss of Offsite Power	Bus 5A Not Available - Bus 2A and 3A Tied	-	-	-	1831	-	1846	-	-	-	1460	-	1466
9	Loss of Offsite Power	Bus 2A and/or 3A Not Available	-	1509	-	-	-	1874	-	1343	-	-	-	1580
Small Break LOCA														
1	Offsite Power Available	Total MCC and Lighting Reset- All buses	2542	-	2490/2585	-	2633	-	1751	-	2018/2174	-	1937	-
2	Offsite Power Available	All Buses Available - Bus 2A and 3A Tied	2683	-	3029	-	2677	-	2683	-	2104	-	2144	-
3	Offsite Power Available	Bus 6A Not Available - Bus 2A and 3A Tied	2914	-	3072	-	-	-	2683	-	3035	-	-	-
4	Offsite Power Available	Bus 5A Not Available - Bus 2A and 3A Tied	-	-	3072	-	3037	-	-	-	2576	-	3037	-
5	Offsite Power Available	Bus 2A and/or 3A Not Available	2725	-	-	-	2897	-	2683	-	-	-	2574	-
6	Loss of Offsite Power	All Buses Available - Bus 2A and 3A Tied	-	1410	-	1585	-	1433	-	1211	-	1398	-	1422
7	Loss of Offsite Power	Bus 6A Not Available - Bus 2A and 3A Tied	-	1480	-	1828	-	-	-	1445	-	1547	-	-
8	Loss of Offsite Power	Bus 5A Not Available - Bus 2A and 3A Tied	-	-	-	1617	-	1643	-	-	-	1617	-	1632
9	Loss of Offsite Power	Bus 2A and/or 3A Not Available	-	1375	-	-	-	1773	-	1375	-	-	-	1492

LOADING SUMMARY DURING AND END OF ACCIDENT SCENARIOS

* Note: The values below do not incorporate cable losses and load increase due to frequency variation

Number	Accident Scenario	Single Failure	Peak Loading During Accident Scenario						Loading at End of Accident Scenario					
			Bus 5A (Amps)	EDG 33 (KW)	Bus 2A/3A (Amps)	EDG 31 (KW)	Bus 6A (Amps)	EDG 32 (KW)	Bus 5A (Amps)	EDG 33 (KW)	Bus 2A/3A (Amps)	EDG 31 (KW)	Bus 6A (Amps)	EDG 32 (KW)
	Small Break LOCA (PH B)													
1	Offsite Power Available	Total MCC and Lighting Reset- All buses Available	2928	-	2018/2231	-	3104	-	2545	-	2018/1360	-	2170	-
2	Offsite Power Available	All Buses Available - Bus 2A and 3A Tied	3136	-	3029	-	3104	-	2692	-	2252	-	2493	-
3	Offsite Power Available	Bus 6A Not Available - Bus 2A and 3A Tied	3415	-	3236	-	-	-	2692	-	2902	-	-	-
4	Offsite Power Available	Bus 5A Not Available - Bus 2A and 3A Tied	-	-	3281	-	3312	-	-	-	2757	-	2629	-
5	Offsite Power Available	Bus 2A and/or 3A Not Available	3179	-	-	-	3147	-	2653	-	-	-	2525	-
6	Loss of Offsite Power	All Buses Available - Bus 2A and 3A Tied	-	1509	-	1585	-	1739	-	1368	-	1217	-	1481
7	Loss of Offsite Power	Bus 6A Not Available - Bus 2A and 3A Tied	-	1649	-	1585	-	-	-	1649	-	1399	-	-
8	Loss of Offsite Power	Bus 5A Not Available - Bus 2A and 3A Tied	-	-	-	1725	-	1739	-	-	-	1460	-	1388
9	Loss of Offsite Power	Bus 2A and/or 3A Not Available	-	1509	-	-	-	1739	-	1343	-	-	-	1502
	Steam Break (PH B)													
1	Offsite Power Available	Total MCC and Lighting Reset- All buses Available	2928	-	2129/2231	-	3104	-	2181	-	2129/1715	-	2367	-
2	Offsite Power Available	All Buses Available - Bus 2A and 3A Tied	3136	-	3029	-	3104	-	2253	-	2533	-	2423	-
3	Offsite Power Available	Bus 6A Not Available - Bus 2A and 3A Tied	3179	-	3072	-	-	-	2914	-	3005	-	-	-
4	Offsite Power Available	Bus 5A Not Available - Bus 2A and 3A Tied	-	-	3281	-	3147	-	-	-	3036	-	2853	-
5	Offsite Power Available	Bus 2A and/or 3A Not Available	3179	-	-	-	3147	-	2683	-	-	-	2853	-
6	Loss of Offsite Power	All Buses Available - Bus 2A and 3A Tied	-	1509	-	1585	-	1739	-	1163	-	1231	-	1222
7	Loss of Offsite Power	Bus 6A Not Available - Bus 2A and 3A Tied	-	1509	-	1585	-	-	-	1444	-	1512	-	-
8	Loss of Offsite Power	Bus 5A Not Available - Bus 2A and 3A Tied	-	-	-	1725	-	1739	-	-	-	1538	-	1613
9	Loss of Offsite Power	Bus 2A and/or 3A Not Available	-	1509	-	-	-	1739	-	1444	-	-	-	1336

LOADING SUMMARY DURING AND END OF ACCIDENT SCENARIOS

* Note: The values below do not incorporate cable losses and load increase due to frequency variation

Number	Accident Scenario	Single Failure	Peak Loading During Accident Scenario					Loading at End of Accident Scenario						
			Bus 5A (Amps)	EDG 33 (kW)	Bus 2A/3A (Amps)	EDG 31 (kW)	Bus 6A (Amps)	EDG 32 (kW)	Bus 5A (Amps)	EDG 33 (kW)	Bus 2A/3A (Amps)	EDG 31 (kW)	Bus 6A (Amps)	EDG 32 (kW)
Steam Break														
1	Offsite Power Available	Total MCC and Lighting Reset- All buses Available	2474	-	2129/2231	-	2633	-	2181	-	2129/1715	-	2367	-
2	Offsite Power Available	All Buses Available - Bus 2A and 3A Tied	2682	-	3029	-	2633	-	2253	-	2533	-	2423	-
3	Offsite Power Available	Bus 6A Not Available - Bus 2A and 3A Tied	2914	-	3072	-	-	-	2914	-	3005	-	-	-
4	Offsite Power Available	Bus 5A Not Available - Bus 2A and 3A Tied	-	-	3072	-	3062	-	-	-	2828	-	3062	-
5	Offsite Power Available	Bus 2A and/or 3A Not Available	2725	-	-	-	2853	-	2683	-	-	-	2853	-
6	Loss of Offsite Power	All Buses Available - Bus 2A and 3A Tied	-	1202	-	1585	-	1420	-	1163	-	1231	-	1222
7	Loss of Offsite Power	Bus 6A Not Available - Bus 2A and 3A Tied	-	1444	-	1585	-	-	-	1444	-	1512	-	-
8	Loss of Offsite Power	Bus 5A Not Available - Bus 2A and 3A Tied	-	-	-	1585	-	1639	-	-	-	1512	-	1639
9	Loss of Offsite Power	Bus 2A and/or 3A Not Available	-	1444	-	-	-	1420	-	1444	-	-	-	1336
Inadvertent SI (PH B)														
1	Offsite Power Available	Total MCC and Lighting Reset- All buses Available	2928	-	2129/2231	-	3104	-	2181	-	2129/1715	-	2367	-
2	Offsite Power Available	All Buses Available - Bus 2A and 3A Tied	3136	-	3029	-	3104	-	2253	-	2533	-	2423	-
3	Offsite Power Available	Bus 6A Not Available - Bus 2A and 3A Tied	3179	-	3072	-	-	-	2914	-	3005	-	-	-
4	Offsite Power Available	Bus 5A Not Available - Bus 2A and 3A Tied	-	-	3281	-	3147	-	-	-	3036	-	2853	-
5	Offsite Power Available	Bus 2A and/or 3A Not Available	3179	-	-	-	3147	-	2683	-	-	-	2853	-
6	Loss of Offsite Power	All Buses Available - Bus 2A and 3A Tied	-	1509	-	1585	-	1739	-	1163	-	1231	-	1222
7	Loss of Offsite Power	Bus 6A Not Available - Bus 2A and 3A Tied	-	1509	-	1585	-	-	-	1444	-	1512	-	-
8	Loss of Offsite Power	Bus 5A Not Available - Bus 2A and 3A Tied	-	-	-	1725	-	1739	-	-	-	1538	-	1613
9	Loss of Offsite Power	Bus 2A and/or 3A Not Available	-	1509	-	-	-	1739	-	1444	-	-	-	1336

LOADING SUMMARY DURING AND END OF ACCIDENT SCENARIOS

* Note: The values below do not incorporate cable losses and load increase due to frequency variation

Number	Accident Scenario	Single Failure	Peak Loading During Accident Scenario						Loading at End of Accident Scenario					
			Bus 5A (Amps)	EDG 33 (kW)	Bus 2A/3A (Amps)	EDG 31 (kW)	Bus 6A (Amps)	EDG 32 (kW)	Bus 5A (Amps)	EDG 33 (kW)	Bus 2A/3A (Amps)	EDG 31 (kW)	Bus 6A (Amps)	EDG 32 (kW)
	Inadvertent SI													
1	Offsite Power Available	Total MCC and Lighting Reset- All buses Available	2474	-	2129/2231	-	2633	-	2181	-	2129/1715	-	2367	-
2	Offsite Power Available	All Buses Available - Bus 2A and 3A Tied	2682	-	3029	-	2633	-	2253	-	2533	-	2423	-
3	Offsite Power Available	Bus 6A Not Available - Bus 2A and 3A Tied	2914	-	3072	-	-	-	2914	-	3905	-	-	-
4	Offsite Power Available	Bus 5A Not Available - Bus 2A and 3A Tied	-	-	3072	-	2885	-	-	-	3905	-	2885	-
5	Offsite Power Available	Bus 2A and/or 3A Not Available	2725	-	-	-	2853	-	2683	-	-	-	2853	-
6	Loss of Offsite Power	All Buses Available - Bus 2A and 3A Tied	-	1202	-	1585	-	1420	-	1163	-	1231	-	1222
7	Loss of Offsite Power	Bus 6A Not Available - Bus 2A and 3A Tied	-	1444	-	1585	-	-	-	1444	-	1512	-	-
8	Loss of Offsite Power	Bus 5A Not Available - Bus 2A and 3A Tied	-	-	-	1585	-	1639	-	-	-	1512	-	1639
9	Loss of Offsite Power	Bus 2A and/or 3A Not Available	-	1444	-	-	-	1420	-	1444	-	-	-	1336
	Steam Generator Tube Rupture													
1	Offsite Power Available	Total MCC and Lighting Reset- All buses Available	2474	-	2515/2231	-	2633	-	2044	-	2264/1997	-	1937	-
2	Offsite Power Available	All Buses Available - Bus 2A and 3A Tied	2682	-	3029	-	2633	-	2191	-	2606	-	2367	-
3	Offsite Power Available	Bus 6A Not Available - Bus 2A and 3A Tied	2914	-	3267	-	-	-	2914	-	3035	-	-	-
4	Offsite Power Available	Bus 5A Not Available - Bus 2A and 3A Tied	-	-	3072	-	2885	-	-	-	3050	-	2754	-
5	Offsite Power Available	Bus 2A and/or 3A Not Available	2725	-	-	-	3004	-	2485	-	-	-	3004	-
6	Loss of Offsite Power	All Buses Available - Bus 2A and 3A Tied	-	1562	-	1585	-	1549	-	1562	-	1266	-	1549
7	Loss of Offsite Power	Bus 6A Not Available - Bus 2A and 3A Tied	-	1583	-	1585	-	-	-	1583	-	1547	-	-
8	Loss of Offsite Power	Bus 5A Not Available - Bus 2A and 3A Tied	-	-	-	1825	-	1632	-	-	-	1446	-	1632
9	Loss of Offsite Power	Bus 2A and/or 3A Not Available	-	1583	-	-	-	1492	-	1583	-	-	-	1492

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES

ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00267 REV 8

LARGE BREAK LOCA - RCS PRESSURE < 325
ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:54 PM

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2695.9 Bus 2A = 1974.8 Bus 3A = 1359.6 Bus 6A = 2392.8 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A/3A is below the 3200 Amp rating
Bus 6A exceeds the 3200 Amp rating at EOP steps : 11, 12, 13

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

LARGE BREAK LOCA - RCS PRESSURE < 325 - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 1:54 PM [48]

Step Number	SRD Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCCs 36A, 36B, 36C, 36D and 36E	Auto	169.5	135.5	0.0	150.1
					169.5	135.5	0.0	150.1
- 2 -	---	RO-1-2	+57 +58 +59 +60 SI pumps 31, 32 and 33 RHR pumps 31 and 32 {RO verifies that pumps are running.}	Auto	472.4	472.4	419.7	893.9
					641.9	607.9	419.7	1044.0
- 3 -	E-0-9	---	+116 +119 +121 +122 +123 CSPs 31 and 32 {E-0-9 verifies that pumps are running.}	Auto	453.6	0.0	0.0	471.1
					1095.5	607.9	419.7	1515.1
- 4 -	---	RO-1-3	+24 +25 FCUs 31, 32, 33, 34 and 35 {RO verifies that fans are running.}	Auto	491.9	247.2	246.0	248.0
					1587.4	855.1	665.7	1763.1
- 5 -	---	RO-1-6	+29 +31 +33 +35 +37 AFWPs 31 and 33 {RO verifies that pumps are running.}	Auto	0.0	0.0	575.4	562.9
					1587.4	855.1	1241.1	2326.0
- 6 -	---	RO-1-7	+1 +2 CCWPs 31, 32 and 33 {RO verifies that pumps are running.}	Auto	250.5	251.3	0.0	251.2
					1837.9	1106.4	1241.1	2577.2
- 7 -	---	RO-1-8	+4 +7 +10 ESWPs (34, 35, and 36) {RO verifies that pumps are running.}	Auto	429.8	0.0	429.0	429.8
					2267.7	1106.4	1670.1	3007.0
- 8 -	E-0-11	---	+26 +27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {RCS pressure is < 325 psig.}	Manual	0.0	0.0	0.0	0.0
					2267.7	1106.4	1670.1	3007.0
- 9 -	< 17 >	---	{No Loads Started or Tripped at this step}	Manual	0.0	0.0	0.0	0.0
			*** LARGE BREAK LOCA EVENT IDENTIFIED *** *** EXIT TO E-1 ***		2267.7	1106.4	1670.1	3007.0
			{No Loads Started or Tripped at this step}					

LARGE BREAK LOCA - RCS PRESSURE < 325 - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:54 PM (48)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	E-1-4	---	Reset SI (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0	0.0	0.0	0.0
					2267.7	1106.4	1670.1	3007.0
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset.)	Manual	659.8	848.0	507.6	252.2
					2927.5	1954.4	2177.7	3259.2 Over 3200
- 12 -	E-1-8	---	+126 +124 +125 +127 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	0.0	0.0	0.0
					2927.5	1954.4	2177.7	3259.2 Over 3200
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one Charging pump. (Charging pump 32 started on lightest loaded Bus.)	Manual	0.0	0.0	208.5	0.0
					2927.5	1954.4	2386.6	3259.2 Over 3200
- 14 -	E-1-13	---	+14 Stop CSPs if 5 FCUs are running or Containment pressure is < 15 psig. (5 FCUs are running, CSPs stopped.)	Manual	-453.6	0.0	0.0	-471.1
					2473.9	1954.4	2386.6	2788.1
- 15 -	E-1-14	---	-24 -25 Stop RHR pumps if pressure is > 325 psig and pressure is stable or increasing. (Pressure < 325 psig)	Manual	0.0	0.0	0.0	0.0
					2473.9	1954.4	2386.6	2788.1
- 16 -	< 13 >	---	(No Loads Started or Tripped at this step) *** TRANSFER TO COLD LEG RECIRC. *** *** EXIT TO EG-1.3 ***	Manual	0.0	0.0	0.0	0.0
					2473.9	1954.4	2386.6	2788.1
- 17 -	ES-1.3-5	---	(No Loads Started or Tripped at this step) CHECK SI Recirc SW 1 Function Complete Light - LIT. (YES) (SI pump 32 - Auto stopped. CSPs stopped at E-1-13.)	Manual	0.0	-472.4	0.0	0.0
					2473.9	1482.0	2386.6	2788.1
- 18 -	ES-1.3-6	---	-122 CHECK SI Recirc SW 3 Function Complete Light - LIT. (YES) (RHR pumps 31 and 32 - Auto stopped.)	Manual	0.0	0.0	-419.7	-420.2
					2473.9	1482.0	1966.9	2367.9
			-116 -119					

LARGE BREAK LOCA - RCS PRESSURE < 325 - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 30, 2009 Time : 3:54 PM (48)


Step Number	SKO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	---	RO-1-20	CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (NESWP 32 started on lightest loaded Bus.)	Manual	0.0 2473.9	429.0 1911.0	0.0 1966.9	0.0 2367.9
- 20 -	ES-1.3-7	---	+85 STOP Motor Driven Auxiliary Feed Pumps: (RCS pressure is less than SG pressures.) b. PLACE both Motor Driven AFWPs in TPO. (AFWPs 31 and 33 stopped.)	Manual	0.0 2473.9	0.0 1911.0	-573.4 1391.5	-562.9 1805.0
- 21 -	ES-1.3-8	---	-1 -2 INITIATE Performance of ATTACHMENT 1. Stop Any Running Charging Pumps. Place ALL PRZR HTRs to OFF. (Charging pump 32 stopped. No PRZR HTRs are on.)	Manual	0.0 2473.9	0.0 1911.0	-208.9 1182.6	0.0 1805.0
- 22 -	NSE 99-3-075	NSE 99-3-075	-14 AS PER SECTION 4.2.20 of NSE One CSP run time is less than 30 minutes. (No CSPs are running.)	Manual	0.0 2473.9	0.0 1911.0	0.0 1182.6	0.0 1805.0
- 23 -	ES-1.3-9	---	(No Loads Started or Tripped at this step) ALIGN SI Recirc SW 2 as follows: b. PLACE SI Recirc SW 2 to ON (NESWP 31- Auto started. CCWP 33 is running.)	Manual	429.8 2903.7	0.0 1911.0	0.0 1182.6	0.0 1805.0
- 24 -	ES-1.3-10	---	+84 ALIGN SI Recirc SW 4 Lo Head as follows: c. Manually START 32 Recirc Pump. (CRP 32 started.)	Manual	0.0 2903.7	0.0 1911.0	0.0 1182.6	472.5 2277.5
- 25 -	ES-1.3-14	---	+20 ALIGN SI Recirc SW 6 Lo Head as follows: (SI SW 6 Lo Head function Light is LIT. All running SI pumps [31 and 33] auto stopped.)	Manual	-472.4 2431.3	0.0 1911.0	0.0 1182.6	-473.7 1803.8
- 26 -	ES-1.3-15	---	-121 -123 ALIGN SI Recirc SW 7 as follows: b. PLACE SI Recirc SW 7 to ON. (NESWP 32 and CCWP 32 are running. CRP 31 Auto started.)	Manual	472.5 2903.8	0.0 1911.0	0.0 1182.6	0.0 1803.8
- 27 -	ES-1.3-24	---	+16 Reset MCCs. (MCCs are already reset.)	Manual	0.0 2903.8	0.0 1911.0	0.0 1182.6	0.0 1803.8
			(No Loads Started or Tripped at this step)					

LARGE BREAK LOCA - RCS PRESSURE < 325 - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:54 PM [48]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 28 -	ES-1.3-35	---	CHECK PAB Exhaust Fan Status: (No PAB fan is running.) a. START one PAB Exhaust Fan. (PAB fan 31 started on lightest loaded Bus.) +87	Manual	0.0 2903.8	0.0 1911.0	177.0 1359.6	0.0 1803.8
- 29 -	ES-1.3-36	---	Shutdown Unnecessary Plant Equipment: a. CHECK CCWPs. IF 3 are running then stop one. b. CHECK ESWPs. IF 3 are running then stop one. (CCWP 31, ESWP 34 stopped on heaviest loaded Bus.) -4 -26	Manual	-680.3 2223.5	0.0 1911.0	0.0 1359.6	0.0 1803.8
- 30 -	---	RO-1-27c	START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning gear. (Gear started) +47	Manual	0.0 2223.5	63.6 1974.8	0.0 1359.6	0.0 1803.8
- 31 -	ES-1.3-36	---	CHECK Containment Hydrogen Concentration: (Hydrogen concentration great than 0.5% by volume. Recombiner 32 started on lightest loaded Bus.) +56	Manual	0.0 2223.5	0.0 1974.8	0.0 1359.6	115.3 1919.1
- 32 -	ES-1.3-36	---	*** EXIT TO ES-1.4 *** << 6.5 HOURS ELAPSE PRIOR TO ENTERING ES-1.4-1 >>	Manual	0.0 2223.5	0.0 1974.8	0.0 1359.6	0.0 1919.1
- 33 -	ES-1.4-7	---	(No Loads Started or Tripped at this step) *** START HIGH-HEAD RECIRCULATION *** Start SI pumps 31. (SI pumps 31 started.) -121	Manual	472.4 2695.9	0.0 1974.8	0.0 1359.6	0.0 1919.1
- 34 -	ES-1.4-8	---	Start SI pump 33. (SI pump 33 started.) +123	Manual	0.0 2695.9	0.0 1974.8	0.0 1359.6	473.7 2392.8
- 35 -	ES-1.4-11	---	*** RETURN TO ES-1.3 Step 37 ***	Manual	0.0 2695.9	0.0 1974.8	0.0 1359.6	0.0 2392.8
- 36 -	ES-1.3-37	---	(No Loads Started or Tripped at this step) Evaluate long term plant status. (No Loads Started or Tripped at this step)	Manual	0.0 2695.9	0.0 1974.8	0.0 1359.6	0.0 2392.8

LARGE BREAK LOCA - RCS PRESSURE < 325



Large Break LOCA
 Total MCC and Lighting Reset
 Offsite Power Available
 Operating Loads at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

CCWP 33	2A
CCWP 32	2A
CRP 31	5A
CRP 32	6A
ESWP 35	3A
ESWP 36	6A
FCU 31	5A
FCU 32	2A
FCU 33	5A
FCU 34	3A
FCU 35	6A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36A: AUTO	5A
MCC 36B: AUTO	6A
MCC 36C: AUTO	2A
MCC 36C: H2 RECOMBINER 32	6A
MCC 36D: AUTO	6A
MCC 36E: AUTO	5A
NESWP 31	5A
NESWP 32	2A
PAB FAN 31	3A
SI PUMP 31	5A
SI PUMP 33	6A
TOTAL MCC & LIGHTING RESET (2A)	
TOTAL MCC & LIGHTING RESET (3A)	
TOTAL MCC & LIGHTING RESET (5A)	
TOTAL MCC & LIGHTING RESET (6A)	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

LARGE BREAK LOCA - RCS PRESSURE < 325

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:51 PM

*** BUSES 2A AND 3A TIED TOGETHER ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2695.9 Bus 2A/3A = 2252.1 Bus 6A = 2612.8 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A/3A is below the 3200 Amp rating
Bus 6A exceeds the 3200 Amp rating at EOP steps : 11, 12, 13

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

LARGE BREAK LOCA - RCS PRESSURE < 325

Report Date : August 25, 2009 Time : 3:51 PM [1]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCCs 36A, 36B, 36C, 36D and 36E	Auto	169.5	135.5	150.1
- 2 -	---	RO-1-2	+57 +58 +53 +59 +60 SI pumps 31, 32 and 33 RHR pumps 31 and 32 {RO verifies that pumps are running.}	Auto	472.4	892.1	893.9
- 3 -	E-0-9	---	+116 +119 +121 +122 +123 CSFs 31 and 32 {E-0-9 verifies that pumps are running.}	Auto	453.6	0.0	471.1
- 4 -	---	RO-1-3	+24 +25 FCUs 31, 32, 33, 34 and 35 {RO verifies that fans are running.}	Auto	491.9	493.2	248.0
- 5 -	---	RO-1-5	+29 +31 +33 +35 +37 AFWPs 31 and 33 {RO verifies that pumps are running.}	Auto	0.0	575.4	562.9
- 6 -	---	RO-1-7	+1 +2 CCWPs 31, 32 and 33 {RO verifies that pumps are running.}	Auto	250.5	251.3	251.2
- 7 -	---	RO-1-8	+4 +7 +10 ESWPs (34, 35, and 36) {RO verifies that pumps are running.}	Auto	429.8	429.0	429.8
- 8 -	E-0-11	---	+26 +27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {RCS pressure is < 325 psig.}	Manual	0.0	0.0	0.0
- 9 -	< 17 >	---	{No Loads Started or Tripped at this step} *** LARGE BREAK LOCA EVENT IDENTIFIED *** *** EXIT TO E-1 *** {No Loads Started or Tripped at this step}	Manual	0.0	0.0	0.0
					2287.7	2776.5	3007.0

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	E-1-4	---	Reset SI (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0 2267.7	0.0 2776.5	0.0 3007.0
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset for MCCs powered from Buses 5A and 6A.)	Manual	659.8 2927.5	407.2 3183.7	252.2 3259.2 Over 3200
- 12 -	E-1-8	---	+124 +127 +3 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0 2927.5	0.0 3183.7	0.0 3259.2 Over 3200
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (Charging pump 31 started on lightest loaded Bus.)	Manual	208.5 3136.0	0.0 3183.7	0.0 3259.2 Over 3200
- 14 -	E-1-13	---	+13 Stop CSPs if 5 FCUs are running or Containment pressure is < 16 psig (5 FCUs are running. CSPs stopped.)	Manual	-453.6 2682.4	0.0 3183.7	-471.1 2788.1
- 15 -	E-1-14	---	-24 -25 Stop RHR pumps if pressure is > 325 and pressure is stable or increasing. (Pressure < 325 psig)	Manual	0.0 2682.4	0.0 3183.7	0.0 2788.1
- 16 -	< 19 >	---	(No Loads Started or Tripped at this step) *** TRANSFER TO COLD LEG RECIRC. *** *** EXIT TO ES-1.3 ***	Manual	0.0 2682.4	0.0 3183.7	0.0 2788.1
- 17 -	ES-1.3-5	---	(No Loads Started or Tripped at this step) Stop SI pump 32, if three are running. (SI pump 32 stopped.) Stop CSP 32 if two running. (CSPs not running.)	Manual	0.0 2682.4	-472.4 2711.3	0.0 2788.1
- 18 -	ES-1.3-6	---	-122 CHECK SI Recirc SW 3 Function Complete Light - Lit. (YES) (RHR pumps 31 and 32 - Auto stopped.)	Manual	0.0 2682.4	-419.7 2291.6	-420.2 2367.9
-116 -		-119					

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	---	RO-1-20	CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (NESWP 32 started on lightest loaded Bus.)	Manual	0.0 2682.4	429.6 2720.6	9.0 2367.9
- 20 -	ES-1.3-7	---	+85 STOP Motor Driven Auxiliary Feed Pumps: (AFWPs stopped.)	Manual	0.0 2682.4	-575.4 2145.2	-563.9 1805.0
- 21 -	ES-1.3-8	---	-1 -2 INITIATE Performance of ATTACHMENT 1. STOP Any Running Charging Pumps. PLACE All PRZR HTRs to OFF. (Charging pump 31 stopped. No PRZR HTRs are on.)	Manual	-208.5 2473.9	0.0 2145.2	0.0 1805.0
- 22 -	NSE 99-3-075	NSE 99-3-075	-13 AS PER SECTION 4.2.29 of NSE, One CSP run time is less than 30 minutes. (No CSPs are running.)	Manual	0.0 2473.9	0.0 2145.2	0.0 1805.0
- 23 -	ES-1.3-9	---	(No Loads Started or Tripped at this step) ALIGN SI Recirc SW 2 (NESWP 31 auto started, CCWP 33 is running.)	Manual	429.8 2903.7	0.0 2145.2	0.0 1805.0
- 24 -	ES-1.3-10	---	+84 Align SI Recirc SW 4. (CRP 32 started.)	Manual	0.0 2903.7	0.0 2145.2	472.5 2277.5
- 25 -	ES-1.3-14	---	+20 Align SI Recirc SW 6. (All running SI pumps [31 and 33] auto stopped.)	Manual	-472.4 2431.3	0.0 2145.2	-473.7 1803.8
- 26 -	ES-1.3-16	---	-121 -123 Align SI Recirc SW 7. (NESWP 32 and CCWP 32 are running. CRP 31 auto started.)	Manual	472.5 2903.8	0.0 2145.2	0.0 1803.8
- 27 -	ES-1.3-24	---	+16 Reset MCCs. (MCCs are already reset.)	Manual	0.0 2903.8	0.0 2145.2	0.0 1803.8
			(No Loads Started or Tripped at this step)				

Step Number	SFO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 28 -	ES-1.3-35	---	Start one PAB fan. (PAB fan 32 started on lightest loaded Bus.)	Manual	0.0	0.0	177.0
					2993.6	2145.2	1980.8
- 29 -	ES-1.3-36	---	+82 Shutdown unnecessary Plant Equipment. a. CHECK CCWPs. If 3 are running then stop one b. CHECK ESWPs. If 3 are running then stop one. (CCWP 31, ESWP 34 stopped on heaviest loaded Bus.)	Manual	-680.3	43.1	43.0
					2223.5	2188.3	2023.8
- 30 -	---	RO-1-27c	+6 +11 -4 -7 -10 -26 START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. (Start Turb Turning Gear. (Gear started.)	Manual	0.0	63.8	0.0
					2223.5	2252.1	2023.8
- 31 -	ES-1.3-35	---	+47 Start one H2 Recombiner. (Recombiner 32 started on lightest loaded Bus.)	Manual	0.0	0.0	115.3
					2223.5	2252.1	2139.1
- 32 -	ES-1.3-36	---	+56 *** EXIT TO ES-1.4 *** << 6.5 HOURS ELAPSE PRIOR TO ENTERING ES-1.4-1 >>	Manual	0.0	0.0	0.0
					2223.5	2252.1	2139.1
- 33 -	ES-1.4-7	---	(No Loads Started or Tripped at this step) *** START HIGH-HEAD RECIRCULATION *** Start SI pump 31. (SI pump 31 started.)	Manual	472.4	0.0	0.0
					2695.9	2252.1	2139.1
- 34 -	ES-1.4-8	---	+121 Start SI pump 33. (SI pump 33 started.)	Manual	0.0	0.0	473.7
					2695.9	2252.1	2612.8
- 35 -	ES-1.4-11	---	+123 *** RETURN TO ES-1.3 Step 37 ***	Manual	0.0	0.0	0.0
					2695.9	2252.1	2612.8
- 36 -	ES-1.4-37	---	(No Loads Started or Tripped at this step) Evaluate long term plant status.	Manual	0.0	0.0	0.0
					2695.9	2252.1	2612.8
			(No Loads Started or Tripped at this step)				

LARGE BREAK LOCA - RCS PRESSURE < 325



Large Break LOCA
 Buses 2A/3A Tied Together, All Buses Available
 Offsite Power Available
 Operating Loads at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

CCWP 32	2A
CCWP 33	6A
CRP 31	5A
CRP 32	6A
ESWP 35	3A
ESWP 36	6A
FCU 31	5A
FCU 32	2A
FCU 33	5A
FCU 34	3A
FCU 35	6A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36A: AUTO	5A
MCC 36B: AUTO	6A
MCC 36C: AUTO	2A
MCC 36C: H2 RECOMBINER 31	2A
MCC 36D: AUTO	6A
MCC 36E: AUTO	5A
NESWP 31	5A
NESWP 32	2A
PAB FAN 32	6A
SI PUMP 31	5A
SI PUMP 33	6A
TOTAL MCCS & LIGHTING RESET BUS 5A	
TOTAL MCCS & LIGHTING RESET BUS 6A	
MCCS RESET (2A/3A) AS PER SOP-EL-15	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-06207 REV 8

LARGE BREAK LOCA - RCS PRESSURE < 325

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:51 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 6A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 3125.7 Bus 2A/3A = 3016.8 Bus 6A = * N/A * (A)

3200 Amp Overload Summary

Bus 5A exceeds the 3200 Amp rating at EOP steps : 24
Bus 2A/3A exceeds the 3200 Amp rating at EOP steps : 11, 12, 13, 14, 15, 16, 17, 19
Bus 6A Not Available

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A Not Available

LARGE BREAK LOCA - RCS PRESSURE < 325

Report Date : August 28, 2009 Time : 3:51 PM [2]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total load (A)
- 1 -	---	---	MCCs 36A, 36C and 36E	Auto	169.5	135.5	* N/A *
					169.5	135.5	* N/A *
- 2 -	---	RO-1-2	+57 +50 +60 SI Pumps 31 and 32 RRK Pump 31 {RO verifies that pumps are running.}	Auto	472.4	931.8	* N/A *
					641.9	1067.3	* N/A *
- 3 -	E-0-9	---	+116 +121 +122 CSP 31 {E-0-9 verifies that pump is running.}	Auto	453.6	0.0	* N/A *
					1095.5	1067.3	* N/A *
- 4 -	---	RO-1-3	+24 FCUs 31, 32, 33 and 34 {RO verifies that fans are running.}	Auto	491.9	493.2	* N/A *
					1587.4	1560.5	* N/A *
- 5 -	---	RO-1-5	+29 +31 +33 +35 AFWP 31 {RO verifies that pump is running.}	Auto	0.0	575.4	* N/A *
					1587.4	2135.9	* N/A *
- 6 -	---	RO-1-7	+1 CCWPs 31 and 32 {RO verifies that pumps are running.}	Auto	293.4	294.4	* N/A *
					1880.8	2430.3	* N/A *
- 7 -	---	RO-1-8	+4 +7 ESWPs (34 and 35) {RO verifies that pumps are running.}	Auto	429.8	421.0	* N/A *
					2310.6	2859.3	* N/A *
- 8 -	E-0-11	---	+26 +27 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {RCS pressure is < 325 psig.}	Manual	0.0	0.0	* N/A *
					2310.6	2859.3	* N/A *
- 9 -	< 17 >	---	{No Loads Started or Tripped at this step}	Manual	0.0	0.0	* N/A *
			*** LARGE BREAK LOCA EVENT IDENTIFIED *** *** EXIT TO E-1 ***		2310.6	2859.3	* N/A *
			{No Loads Started or Tripped at this step}				


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	E-1-4	---	Reset SI (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0 2310.6	0.0 2859.1	* N/A * * N/A *
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Full MCC and lighting reset on Bus 5A.)	Manual	659.8 2970.4	487.2 3266.5 Over 3200	* N/A * * N/A *
- 12 -	E-1-8	---	+126 +3 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0 2970.4	0.0 3266.5 Over 3200	* N/A * * N/A *
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (Charging pump 31 started on lightest loaded Bus.)	Manual	208.5 3178.9	0.0 3266.5 Over 3200	* N/A * * N/A *
- 14 -	E-1-13	---	+13 Stop CSPs if 5 FCUs are running or Containment pressure is < 16 psig. (4 FCUs are running and pressure > 16 psig. CSPs remain running.)	Manual	0.0 3178.9	0.0 3266.5 Over 3200	* N/A * * N/A *
- 15 -	E-1-14	---	(No Loads Started or Tripped at this step) Stop RHR pump if pressure is > 325 and pressure is stable or increasing. (Pressure < 325 psig.)	Manual	0.0 3178.9	0.0 3266.5 Over 3200	* N/A * * N/A *
- 16 -	< 19 >	---	(No Loads Started or Tripped at this step) *** TRANSFER TO COLD LEG RECIRC. *** *** EXIT TO ES-1.3 ***	Manual	0.0 3178.9	0.0 3266.5 Over 3200	* N/A * * N/A *
- 17 -	ES-1.3-5	---	(No Loads Started or Tripped at this step) Stop SI pump 32, if three are running. (Three SI pumps are not running, no pump stopped.) If CSP 31 or 32 is running then stop one. (Only CSP 31 running.)	Manual	0.0 3178.9	0.0 3266.5 Over 3200	* N/A * * N/A *
- 18 -	ES-1.3-5	---	(No Loads Started or Tripped at this step) CHECK SI Recirc SW 3 Function Complete Light - Lit. (YES) (RHR pumps [only 31 is running] - Auto stopped.)	Manual	0.0 3178.9	-459.4 2807.1	* N/A * * N/A *

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	-1-	RO-1-20	CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (NESWP 32 started on lightest loaded Bus.)	Manual	0.0 3178.9	429.0 3236.1 Over 3200	* N/A * * N/A *
- 20 -	ES-1.3-7	---	+85 STOP Motor Driven Auxiliary Feed Pumps. (AFWPs [only 31 is running] stopped.)	Manual	0.0 3178.9	-575.4 2660.7	* N/A * * N/A *
- 21 -	ES-1.3-8	---	-1 INITIATE Performance of ATTACHMENT 1. (Stop Any Running Charging Pumps. Place ALL PRZR HTRs to OFF. (Charging pump 31 stopped. No PRZR HTRs are on.)	Manual	-208.5 2970.4	0.0 2660.7	* N/A * * N/A *
- 22 -	NSE 99-3-075	NSE 99-3-075	-13 AS PER SECTION 4.2.29 of NSE. One CSP run time is less than 30 minutes. (CSP 31 stopped.)	Manual	-453.6 2516.8	0.0 2660.7	* N/A * * N/A *
- 23 -	ES-1.3-9	---	-24 ALIGN SI Recirc SW 2 (NESWP 31 auto started, CCWP 32 is running.)	Manual	429.8 2946.6	0.0 2660.7	* N/A * * N/A *
- 24 -	ES-1.3-10	---	+84 Align SI Recirc SW 4 (Bus 6A unavailable to start CRP 32. CRP 31 started.)	Manual	472.5 3419.1 Over 3200	0.0 2660.7	* N/A * * N/A *
- 25 -	ES-1.3-14	---	+15 ALIGN SI Recirc SW 6 (All running SI pumps auto stopped.)	Manual	-472.4 2946.7	-472.4 2188.3	* N/A * * N/A *
- 26 -	ES-1.3-15	---	-121 -122 Can not ALIGN SI Recirc SW 7. Bus 6A is not available. (CCWP 31 stopped.)	Manual	-293.4 2653.3	0.0 2188.3	* N/A * * N/A *
- 27 -	ES-1.3-24	---	-4 Reset MCCs. (MCCs are already reset.)	Manual	0.0 2653.3	0.0 2188.3	* N/A * * N/A *
(No Loads Started or Tripped at this step)							

Step Number	SFO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 28 -	ES-1.3-25	---	Start one PAB fan. (PAB fan 31 started.)	Manual	0.0 2653.3	177.0 2365.3	* N/A * * N/A *
- 29 -	ES-1.3-28	---	+87 Shutdown unnecessary equipment. a. CHECK CCWPs. IF 3 are running then stop one. b. CHECK ESWPs. IF 3 are running then stop one. (One CCWP and two ESWPs are running.) (No Loads Started or Tripped at this step)	Manual	0.0 2653.3	0.0 2365.3	* N/A * * N/A *
- 30 -	---	RO-1-27c	START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.)	Manual	0.0 2653.3	63.8 2429.1	* N/A * * N/A *
- 31 -	ES-1.3-19	---	+47 Start one H2 Recombiner. (Recombiner 31 started)	Manual	0.0 2653.3	115.3 2544.4	* N/A * * N/A *
- 32 -	ES-1.3-36	---	+58 *** EXIT TO ES-1.4 *** << 6.5 HOURS ELAPSE PRIOR TO ENTERING ES-1.4-1 >>	Manual	0.0 2653.3	0.0 2544.4	* N/A * * N/A *
- 33 -	ES-1.4-7	---	(No Loads Started or Tripped at this step) *** START HIGH-HEAD RECIRCULATION *** Start SI pump 31. (SI pump 31 started.)	Manual	472.4 3125.7	0.0 2544.4	* N/A * * N/A *
- 34 -	ES-1.4-8	---	+121 Start SI pump 33. (Bus 6A unavailable to start SI pump 33.)	Manual	0.0 3125.7	0.0 2544.4	* N/A * * N/A *
- 35 -	ES-1.4-9	---	(No Loads Started or Tripped at this step) Start SI pump 32 (SI pump 32 started.)	Manual	0.0 3125.7	472.4 3016.8	* N/A * * N/A *
- 36 -	ES-1.4-11	---	+122 *** RETURN TO ES-1.3 Step 37 *** (No Loads Started or Tripped at this step)	Manual	0.0 3125.7	0.0 3016.8	* N/A * * N/A *

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 37 -	ES-1.3-37	---	Evaluate long term plant status.	Manual	0.0	0.0	* N/A *
			(No Loads Started or Tripped at this step)		3125.7	3016.8	* N/A *

LARGE BREAK LOCA - RCS PRESSURE < 325



Large Break LOCA
 Buses 2A/3A Tied Together, Bus 6A Not Available
 Offsite Power Available
 Operating Loads at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

CCWP 32	2A
CRP 31	5A
ESWP 34	5A
ESWP 35	3A
FCU 31	5A
FCU 32	2A
FCU 33	5A
FCU 34	3A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36A: AUTO	5A
MCC 36C: AUTO	2A
MCC 36C: H2 RECOMBINER 31	2A
MCC 36E: AUTO	5A
NESWP 31	5A
NESWP 32	2A
PAB FAN 31	3A
SI PUMP 31	5A
SI PUMP 32	2A
TOTAL MCCS & LIGHTING RESET BUS 5A	
MCCS RESET (2A/3A) AS PER SOP-EL-15	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

LARGE BREAK LOCA - RCS PRESSURE < 325

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:51 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 5A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = * N/A * Bus 2A/3A = 2756.5 Bus 6A = 2748.4 (A)

3200 Amp Overload Summary

Bus 5A Not Available

Bus 2A/3A exceeds the 3200 Amp rating at EOP steps : 11, 12, 13, 14, 15, 16, 17
Bus 6A exceeds the 3200 Amp rating at EOP steps : 11, 12, 13, 14, 15, 16, 17, 19

3600 Amp Overload Summary

Bus 5A Not Available

Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCCs 36B, 36C and 36D	Auto	* N/A *	135.5	150.1
					* N/A *	135.5	150.1
- 2 -	---	RO-1-2	+57 +53 +59 S1 Pumps 32 and 33 RHR Pumps 31 and 32 (RO verifies that pumps are running.)	Auto	* N/A *	892.1	893.9
					* N/A *	1027.6	1044.0
- 3 -	E-0-9	---	+115 +119 +122 +123 CSP 32 (E-0-9 verifies that pump is running.)	Auto	* N/A *	0.0	471.1
					* N/A *	1027.6	1515.1
- 4 -	---	RO-1-3	+25 FCUs 32, 34 and 35 (RO verifies that fans are running.)	Auto	* N/A *	493.2	248.0
					* N/A *	1520.8	1753.1
- 5 -	---	RO-1-5	+31 +35 +37 AFWPs 31 and 33 (RO verifies that pumps are running.)	Auto	* N/A *	575.4	552.9
					* N/A *	2096.2	2326.0
- 6 -	---	RO-1-7	+1 +2 CCWPs 32 and 33 (RO verifies that pumps are running.)	Auto	* N/A *	294.4	294.2
					* N/A *	2390.6	2620.2
- 7 -	---	RO-1-8	+8 +11 ESWPs (35 and 36) (RO verifies that pumps are started.)	Auto	* N/A *	429.0	429.0
					* N/A *	2819.6	3050.0
- 8 -	E-0-11	--	+27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (RCS pressure is < 325 psig.)	Manual	* N/A *	0.0	0.0
					* N/A *	2819.6	3050.0
- 9 -	< 17 >	---	(No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
			*** LARGE BREAK LOCA EVENT IDENTIFIED ***				
			*** EXIT TO E-1 ***				
			(No Loads Started or Tripped at this step)				
					* N/A *	2819.6	3050.0

Step Number	SNO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	E-1-4	---	Reset SI (Steps 2 through 12 of RO-1 are completed.)	Manual	* N/A *	0.0	0.0
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15 (Full MCC and lighting reset on Bus 6A)	Manual	* N/A *	2819.6	3050.0
- 12 -	E-1-8	---	+127 +3 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	* N/A *	407.2	252.2
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (Charging pump 32 started on lightest loaded Bus.)	Manual	* N/A *	3226.8 Over 3200	3302.2 Over 3200
- 14 -	E-1-12	---	+14 Stop CSPs if 5 FCUs are running or Containment pressure psig < 16. (3 FCUs are running and psig > 16. CSPs remain running.)	Manual	* N/A *	0.0	0.0
- 15 -	E-1-14	---	(No Loads Started or Tripped at this step) Stop RHR pumps if pressure is > 325 and pressure is stable or increasing. (Pressure < 325 psig.)	Manual	* N/A *	3226.8 Over 3200	3302.2 Over 3200
- 16 -	< 19 >	---	(No Loads Started or Tripped at this step) *** TRANSFER TO COLD LEG RECIRC. *** *** EXIT TO ES-1.3 ***	Manual	* N/A *	208.9	0.0
- 17 -	ES-1.3-5	---	(No Loads Started or Tripped at this step) Stop SI pump 32, if three are running. (Three SI pump are not running, no pump stopped.) if both CSPs are running then stop one. (Only CSP 32 is running.)	Manual	* N/A *	3435.7 Over 3200	3302.2 Over 3200
- 18 -	ES-1.3-6	---	(No Loads Started or Tripped at this step) CHECK SI Recirc SW 3 Function Complete Light - Lit (YES) (RHR pumps - Auto stopped.)	Manual	* N/A *	0.0	0.0
- 116 -	-119	---			* N/A *	3435.7 Over 3200	3302.2 Over 3200
					* N/A *	-419.7	-420.2
					* N/A *	3016.0	2882.0

LARGE BREAK LOCA - RCS PRESSURE < 325

Report Date : August 25, 2009 Time : 3:51 PM (3)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	---	RO-1-20	CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (NESWP 33 started on lightest loaded Bus.)	Manual	* N/A *	0.0	429.8
			+86		* N/A *	3616.0	3311.8
- 20 -	ES-1.3-7	---	Stop Motor Driven Auxillary Feed pumps. (RFWPs stopped.)	Manual	* N/A *	-575.4	-562.9
					* N/A *	2440.6	2748.9
- 21 -	ES-1.3-8	---	-1 -2 INITIATE Performance of Attachment 1. STOP Any Running Charging Pumps. PLACE All PRZR HTRs to OFF. (Charging pump 32 stopped. No PRZR HTRs are on.)	Manual	* N/A *	-208.9	0.0
					* N/A *	2231.7	2748.9
- 22 -	NSE 99-4-075	NSE 99-3-075	-14 AS PER SECTION 4.2.29 of NSE, One CSP run time is less than 30 minutes. (CSP 32 stopped.)	Manual	* N/A *	0.0	-471.1
					* N/A *	2231.7	2277.8
- 23 -	ES-1.3-9	---	-25 ALIGN SI Recirc SW 2. (NESWP 32 auto started, CCWP 32 is running.)	Manual	* N/A *	429.0	0.0
					* N/A *	2660.7	2277.8
- 24 -	ES-1.3-10	---	+85 ALIGN SI Recirc SW 4 (CRP 32 started.)	Manual	* N/A *	0.0	472.5
					* N/A *	2660.7	2750.3
- 25 -	ES-1.3-14	---	+20 ALIGN SI Recirc SW 6 (All running SI pumps auto stopped.)	Manual	* N/A *	-472.4	-473.7
					* N/A *	2188.3	2276.6
- 26 -	ES-1.3-15	---	-122 -123 Can not ALIGN SI Recirc SW 7. Bus 5A is not available. CCWP 33 stopped.)	Manual	* N/A *	32.0	-294.2
					* N/A *	2220.3	1982.4
- 27 -	ES-1.3-24	---	+9 -8 -11 Reset MCCs. (MCCs are already reset.)	Manual	* N/A *	0.0	0.0
					* N/A *	2220.3	1982.4
			(No Loads Started or Tripped at this step)				


Step Number	SRD Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 28 -	ES-1.3-25	---	Start one PAB fan. (PAB fan 32 started on lightest loaded Bus.)	Manual	* N/A *	0.0	177.0
					* N/A *	2220.3	2159.4
- 29 -	ES-1.3-26	---	+88 Shutdown unnecessary equipment. a. CHECK CCWPs. If 3 are running then stop one. b. CHECK ESWPs. If 3 are running then stop one. (One CCWP and two ESWPs are running.) (No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
					* N/A *	2220.3	2159.4
- 30 -	---	RO-1-27c	START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.)	Manual	* N/A *	63.8	0.0
					* N/A *	2284.1	2159.4
- 31 -	ES-1.3-35	---	+47 Start a H2 Recombiner. (Recombiner 32 started on lightest loaded Bus.)	Manual	* N/A *	0.0	115.3
					* N/A *	2284.1	2274.7
- 32 -	ES-1.3-36	---	+56 *** EXIT TO ES-1.4 *** << 6.5 HOURS ELAPSE PRIOR TO ENTERING ES-1.4-1 >>	Manual	* N/A *	0.0	0.0
					* N/A *	2284.1	2274.7
- 33 -	ES-1.4-7	---	(No Loads Started or Tripped at this step) *** START HIGH-HEAD RECIRCULATION *** Start SI pump 31. (Bus 5A unavailable to started SI pump 31.)	Manual	* N/A *	0.0	0.0
					* N/A *	2284.1	2274.7
- 34 -	ES-1.4-8	---	(No Loads Started or Tripped at this step) Start SI pump 33 (SI pump 33 started.)	Manual	* N/A *	0.0	473.7
					* N/A *	2284.1	2748.4
- 35 -	ES-1.4-9	---	+123 Start SI pump 32 if both pumps 31 and 33 are not running. (SI pump 32 started.)	Manual	* N/A *	472.4	0.0
					* N/A *	2756.5	2748.4
- 36 -	ES-1.4-11	---	+123 *** RETURN TO ES-1.3 Step 37 ***	Manual	* N/A *	0.0	0.0
					* N/A *	2756.5	2748.4
			(No Loads Started or Tripped at this step)				

LARGE BREAK LOCA - RCS PRESSURE < 325

Report Date : August 25, 2009 Time : 3:51 PM [3]

Step Number	SRC Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 37 -	ES-1.3-37	---	Evaluate long term plant status. (No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
					* N/A *	2756.5	2748.4

LARGE BREAK LOCA - RCS PRESSURE < 325



Large Break LOCA
 Buses 2A/3A Tied Together, Bus 5A Not Available
 Offsite Power Available
 Operating Loads at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

CCWP 32	2A
CRP 32	6A
ESWP 35	3A
ESWP 36	6A
FCU 32	2A
FCU 34	3A
FCU 35	6A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36B: AUTO	6A
MCC 36B: H2 RECOMBINER 32	6A
MCC 36C: AUTO	2A
MCC 36D: AUTO	6A
MCC 37: BATTERY CHARGER 32	6A
NESWP 32	2A
NESWP 33	6A
PAB FAN 32	6A
SI PUMP 32	2A
SI PUMP 33	6A
MCCS RESET (2A/3A) AS PER SOP-EL-15	
TOTAL MCCS & LIGHTING RESET BUS 6A	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 6

LARGE BREAK LOCA - RCS PRESSURE < 325

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:51 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 2A AND/OR 3A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2653.2 Bus 2A/3A = * N/A * Bus 6A = 3042.6 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A and/or 3A Not Available
Bus 6A exceeds the 3200 Amp rating at EOP steps : 11, 12, 13, 14, 15, 16

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A and/or 3A Not Available
Bus 6A is below the 3600 Amp rating

Step Number	SRG Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCCs 36A, 36B, 36D and 36E	Auto	169.5	* N/A *	169.5
					169.5	* N/A *	169.5
- 2 -	---	RO-1-2	+50 +53 +59 +60 SI Pumps 31 and 33 RHR Pump 32 (RO verifies that pumps are running.)	Auto	472.4	* N/A *	933.6
					641.9	* N/A *	1083.7
- 3 -	E-0-9	---	+119 +121 +123 CSPs 31 and 32 (E-0-9 verifies that pumps are running.)	Auto	453.6	* N/A *	471.1
					1095.5	* N/A *	1554.8
- 4 -	---	RO-1-3	-24 +25 FCUs 31, 33 and 35 (RO verifies that fans are running.)	Auto	491.9	* N/A *	248.0
					1587.4	* N/A *	1802.8
- 5 -	---	RO-1-5	+29 +33 +37 AFWPs 33 (RO verifies that pump is running.)	Auto	0.0	* N/A *	562.9
					1587.4	* N/A *	2365.7
- 6 -	---	RO-1-7	+2 CCWPs 31 and 33 (RO verifies that pumps are running.)	Auto	293.4	* N/A *	294.2
					1880.8	* N/A *	2650.9
- 7 -	---	RO-1-9	+5 +11 ESWPs (34 and 36) (RO verifies that pumps are running.)	Auto	429.8	* N/A *	429.8
					2310.6	* N/A *	3089.7
- 8 -	E-0-11	---	+26 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (RCS pressure is < 325 psig.)	Manual	0.0	* N/A *	0.0
					2310.6	* N/A *	3089.7
- 9 -	< 17 >	---	(No Loads Started or Tripped at this step) *** LARGE BREAK LOCA EVENT IDENTIFIED *** *** EXIT TO E-1 ***	Manual	0.0	* N/A *	0.0
					2310.6	* N/A *	3089.7
			(No Loads Started or Tripped at this step)				

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	E-1-4	---	Reset SI (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0 2310.6	* N/A * * N/A *	0.0 3089.7
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Full MCC and lighting reset.)	Manual	659.8 2970.4	* N/A * * N/A *	252.2 3341.9 Over 3200
- 12 -	E-1-8	---	+126 -127 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0 2970.4	* N/A * * N/A *	0.0 3341.9 Over 3200
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (Charging pump 31 started on lightest loaded Bus.)	Manual	208.5 3178.9	* N/A * * N/A *	0.0 3341.9 Over 3200
- 14 -	E-1-13	---	+13 Stop CSPs if 5 FCUs are running or Containment pressure is < 16 psig. (3 FCUs are running and psig > 16. CSPs remain running.)	Manual	0.0 3178.9	* N/A * * N/A *	0.0 3341.9 Over 3200
- 15 -	E-1-14	---	(No Loads Started or Tripped at this step) Stop RHR pump if pressure is > 325 and pressure is stable or increasing. (Pressure < 325 psig.)	Manual	0.0 3178.9	* N/A * * N/A *	0.0 3341.9 Over 3200
- 16 -	< 19 >	---	(No Loads Started or Tripped at this step) *** TRANSFER TO COLD LEG RECIRC. *** *** EXIT TO ES-1.3 ***	Manual	0.0 3178.9	* N/A * * N/A *	0.0 3341.9 Over 3200
- 17 -	ES-1.3-5	---	(No Loads Started or Tripped at this step) Stop SI pump 32, if three are running. (Three SI pump are not running, no pump stopped.) If CSP 31 or 32 is running then stop one. (CSP 32 stopped on heaviest loaded Bus.)	Manual	0.0 3178.9	* N/A * * N/A *	-471.1 2870.8
- 18 -	ES-1.3-6	---	-25 CHECK SI Recirc SW 3 Function Complete light - Lit. (YES) (RHR pumps [only 32 is running] - Auto stopped.)	Manual	0.0 3178.9	* N/A * * N/A *	-459.9 2410.9


LARGE BREAK LOCA - RCS PRESSURE < 325

Report Date : August 25, 2009 Time : 3:51 PM [4]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 5A Step/Total Load (A)
- 19 -	---	RO-1-20	CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (NESWP 33 started on lightest loaded Bus.)	Manual	0.0 3178.9	* N/A * * N/A *	429.8 2840.7
- 20 -	ES-1.3-7	---	+86 STOP Motor Driven Auxiliary Feed Pumps: (AFWPs (only 33 is running) stopped.)	Manual	0.0 3178.9	* N/A * * N/A *	-562.9 2277.8
- 21 -	ES-1.3-8	---	-2 INITIATE Performance of ATTACHMENT 1. STOP Any Running Charging Pumps. PLACE All PRZR HTRs to OFF. (Charging pump 31 stopped. No PRZR HTRs are on.)	Manual	-208.5 2970.4	* N/A * * N/A *	0.0 2277.8
- 22 -	NSE 99-3-075	NSE 99-3-075	-13 AS PER SECTION 4.2.29 of NSE, One CSP run time is less than 30 minutes. (CSP 31 stopped.)	Manual	-453.6 2516.8	* N/A * * N/A *	0.0 2277.8
- 23 -	ES-1.3-9	---	-24 ALIGN SI Recirc SW 2 (NESWP 31 auto started, CCWP 33 is running.)	Manual	429.8 2946.6	* N/A * * N/A *	0.0 2277.8
- 24 -	ES-1.3-10	---	+24 Align SI Recirc SW 4 (CRP 32 started.)	Manual	0.0 2946.6	* N/A * * N/A *	472.5 2750.3
- 25 -	ES-1.3-14	---	+26 ALIGN SI Recirc SW 6. (All running SI pumps auto stopped.)	Manual	-472.4 2474.2	* N/A * * N/A *	-473.7 2276.6
- 26 -	ES-1.3-15	---	-123 -123 Can not ALIGN SI Recirc SW 7. Bus 2A/3A is not available. (CCWP 31 stopped.)	Manual	-293.4 2180.8	* N/A * * N/A *	0.0 2276.6
- 27 -	ES-1.3-24	---	-5 Reset MCCs (MCCs are already reset.)	Manual	0.0 2180.8	* N/A * * N/A *	0.0 2276.6
(No Loads Started or Tripped at this step)							

Step Number	SRG Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 28 -	ES-1.3-25	---	Start one PAB fan. (PAB fan 32 started.)	Manual	0.0 2180.8	* N/A * * N/A *	177.0 2453.6
- 29 -	ES-1.3-28	---	+88 Shutdown unnecessary Plant Equipment. a. CHECK CCWPs. If 3 are running then stop one. b. CHECK ESWPs. If 3 are running then stop one. (Only one CCWP and two ESWPs are running.) (No Loads Started or Tripped at this step)	Manual	0.0 2180.8	* N/A * * N/A *	0.0 2453.6
- 30 -	---	RO-1-27c	START AC and STOP DC OIL Pumps IF 480V Buses are powered from Offsite and tie-brackers are open. Start Turbine Turning Gear. (Bus 2A/3A unavailable to start Gear) (No Loads Started or Tripped at this step)	Manual	0.0 2180.8	* N/A * * N/A *	0.0 2453.6
- 31 -	ES-1.3-35	---	Start a H2 Recombiner. (Recombiner 32 started.)	Manual	0.0 2180.8	* N/A * * N/A *	115.3 2568.9
- 32 -	ES-1.3-36	---	+56 *** EXIT TO ES-1.4 *** << 5.5 HOURS ELAPSE PRIOR TO ENTERING ES-1.4-1 >>	Manual	0.0 2180.8	* N/A * * N/A *	0.0 2568.9
- 33 -	ES-1.4-7	---	(No Loads Started or Tripped at this step) *** START HIGH-HEAD RECIRCULATION *** Start SI pump 31. (SI pump 31 started.)	Manual	472.4 2653.2	* N/A * * N/A *	0.0 2568.9
- 34 -	ES-1.4-8	---	+121 Start SI pump 33. (SI pump 33 started.)	Manual	0.0 2653.2	* N/A * * N/A *	473.7 3042.6
- 35 -	ES-1.4-11	---	+123 *** RETURN TO ES-1.3 Step 37 ***	Manual	0.0 2653.2	* N/A * * N/A *	0.0 3042.6
- 36 -	ES-1.3-37	---	(No Loads Started or Tripped at this step) Evaluate long term plant status.	Manual	0.0 2653.2	* N/A * * N/A *	0.0 3042.6
			(No Loads Started or Tripped at this step)				

LARGE BREAK LOCA - RCS PRESSURE < 325



Large Break LOCA
 Buses 2A/3A Tied Together, Buses 2A and/or 3A Not Available
 Offsite Power Available
 Operating Loads at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

CCWP 33	6A
CRP 32	6A
ESWP 34	5A
ESWP 36	6A
FCU 31	5A
FCU 33	5A
FCU 35	6A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36A: AUTO	5A
MCC 36B: AUTO	6A
MCC 36B: H2 RECOMBINER 32	6A
MCC 36D: AUTO	6A
MCC 36E: AUTO	5A
NESWP 31	5A
NESWP 33	6A
PAB FAN 32	6A
SI PUMP 31	5A
SI PUMP 33	6A
TOTAL MCCS & LIGHTING RESET BUS 5A	
TOTAL MCCS & LIGHTING RESET BUS 6A	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

LARGE BREAK LOCA - RCS PRESSURE < 325

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:55 PM

*** BUSES 2A AND 3A TIED TOGETHER ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = 1370.8 Bus 2A/3A = 1216.8 Bus 6A = 1558.6 (kW)

1750 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1750 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1750 kW rating
Emergency Diesel Generator 32 on Bus 6A exceeds the 1750 kW rating at EOP steps : 7, 8, 9, 10, 11, 12, 13

1950 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1950 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1950 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCCs 36A, 36B, 36C, 36D and 36E	Auto	110.0 110.0	94.3 94.3	100.4 100.4
- 2 -	---	RO-1-2	+57 +50 +53 +59 +60 SI Pumps 31, 32 and 33 RHR Pumps 31 and 32 (RO verifies that pumps are running.)	Auto	327.2 437.2	615.3 709.6	615.3 715.7
- 3 -	E-0-9	---	+116 +119 +121 +122 +123 CSPs 31 and 32 (E-0-9 verifies that pumps are running.)	Auto	307.3 744.5	0.0 709.6	319.5 1035.2
- 4 -	---	RO-1-3	+24 +25 FCUs 31, 32, 33, 34 and 35 (RO verifies that fans are running.)	Auto	258.0 1002.5	258.0 967.6	129.0 1164.2
- 5 -	---	RO-1-5	+29 +31 +33 +35 +37 AFWPs 31 and 33 (RO verifies that pumps are running.)	Auto	0.0 1002.5	378.9 1346.5	375.7 1539.9
- 6 -	---	RO-1-7	+1 +2 CHECK if Offsite power is available to a 480V Bus to start at least one OCWP. (All Buses are powered from EDGs.)	Manual	0.0 1002.5	0.0 1346.5	0.0 1539.9
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESWPs (34, 35, and 36) (RO verifies that pumps are running.)	Auto	280.8 1283.3	280.8 1627.3	280.8 1820.7 Over 1750
- 8 -	E-0-11	---	+26 +27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (RCS pressure is < 325 psig.)	Manual	0.0 1283.3	0.0 1627.3	0.0 1820.7 Over 1750
- 9 -	< 17 >	---	(No Loads Started or Tripped at this step) *** LARGE BREAK LOCA EVENT IDENTIFIED *** *** EXIT TO E-1 *** (No Loads Started or Tripped at this step)	Manual	0.0 1283.3	0.0 1627.3	0.0 1820.7 Over 1750

LARGE BREAK LOCA - RCS PRESSURE < 325


Report Date : August 25, 2009 Time : 1:55 PM [56]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	E-1-4	---	Reset SI (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0	0.0	0.0
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15.	Manual	1283.3	1627.3	1820.7 Over 1750
- 12 -	E-1-8	---	+82 +21 +83 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	85.8	63.3	24.8
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (Charging pump 31 started on lightest loaded Bus.)	Manual	1369.1	1690.6	1845.5 Over 1750
- 14 -	E-1-13	---	-13 Stop CSPs if 5 FCUs are running or Containment pressure is < 16 psig. (5 FCUs are running, CSPs stopped.)	Manual	0.0	0.0	0.0
- 15 -	E-1-14	---	-24 -25 Stop RHR pumps if pressure is > 325 and pressure is stable or increasing. (Pressure < 325 psig.)	Manual	1369.1	1690.6	1845.5 Over 1750
- 16 -	< 19 >	---	(No Loads Started or Tripped at this step) *** TRANSFER TO COLD LEG RECIRC. *** *** EXIT TO ES-1.3 ***	Manual	140.2	0.0	0.0
- 17 -	ES-1.3-3	---	(No Loads Started or Tripped at this step) CHECK SI Recirc SW 1 Function Complete Light - LIT. (YES) (Three SI pumps running, SI pump 32 stopped.) Stop CSP 32 if two running. (CSPs not running.)	Manual	1509.3	1690.6	1845.5 Over 1750
- 18 -	ES-1.3-5	---	-122 CHECK SI Recirc SW 3 Function Complete Light - LIT. (YES) (RHR pumps - Auto stopped.)	Manual	-307.3	0.0	-319.5
-116 -119					1202.0	1690.6	1526.0
					0.0	-327.2	0.0
					1202.0	1363.4	1526.0
					0.0	-288.1	-288.1
					1202.0	1075.3	1237.9

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	---	RO-1-20	CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (All Buses are powered from EDGs.)	Manual	0.0 1202.0	0.0 1075.3	0.0 1237.9
- 20 -	ES-1.3-7	---	(No Loads Started or Tripped at this step) STOP Motor Driven Auxiliary Feed Pumps: (RCS pressure is less than SG pressures.) b. PLACE both Motor Driven AFWPs in TPO. (AFWPs stopped.) -1 -2	Manual	0.0 1202.0	-378.9 696.4	-375.7 862.2
- 21 -	ES-1.3-8	---	INITIATE Performance of ATTACHMENT 1. STOP Any Running Charging Pumps. PLACE All PRZR HTRs to OFF (Charging pump 31 stopped. No PRZR HTRs are on.) -13	Manual	-140.2 1061.8	0.0 696.4	0.0 862.2
- 22 -	NSE 99-3-075	NSE 99-3-075	AS PER SECTION 4.2.20 of NSE One CSP run time is less than 30 minutes. (No CSPs are running.)	Manual	0.0 1061.8	0.0 696.4	0.0 862.2
- 23 -	ES-1.3-9	---	(No Loads Started or Tripped at this step) ALIGN SI Recirc SW 2 as follows: b. PLACE SI Recirc SW 2 to ON. (NESWP 31 and CCWP 33 Auto started.)	Manual	280.8 1342.6	0.0 696.4	219.5 1081.8
- 24 -	ES-1.3-10	---	-84 +12 ALIGN SI Recirc SW 4 Lo Head as follows: b. Manually START 32 Recirc Pump. (CRP 32 started.)	Manual	0.0 1342.6	0.0 696.4	309.0 1390.8
- 25 -	ES-1.3-14	---	+20 ALIGN SI Recirc SW 6 Lo Head as follows: (SI SW 6 Lo Head function Light is LIT. All running SI pumps [31 and 33] auto stopped.)	Manual	-327.2 1015.4	0.0 696.4	-327.2 1063.6
- 26 -	ES-1.3-15	---	-121 -123 ALIGN SI Recirc SW 7 as follows: b. PLACE SI Recirc SW 7 to ON. (NESWP 32, CCWP 32 and CRP 31 Auto started.)	Manual	309.0 1324.4	478.9 1175.3	-21.5 1042.1
- 27 -	ES-1.3-24	---	+85 +8 +11 +16 -12 Reset MCCs. (MCCs are already reset.) (No Loads Started or Tripped at this step)	Manual	0.0 1324.4	0.0 1175.3	0.0 1042.1

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 9A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 28 -	ES-1.3-25	---	CHECK PAB Exhaust Fan Status: (No PAB fan is running) a. START one PAB Exhaust Fan. (PAB fan 32 started on lightest loaded Bus.) +68	Manual	0.0 1324.4	0.0 1175.3	114.3 1156.4
- 29 -	ES-1.3-28	---	Shutdown Unnecessary Plant Equipment: a. Check CCWPs. if 3 are running then stop one b. Check ESNPs. if 3 are running then stop one (ESWP 34 stopped on heaviest loaded Bus.) -26	Manual	-280.8 1043.6	0.0 1175.3	0.0 1156.4
- 30 -	---	RO-1-27c	START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite Power. (All Buses are powered from EDGs.) Start Turning Gear. (Turning Gear started.) +47	Manual	0.0 1043.6	41.5 1216.8	0.0 1156.4
- 31 -	ES-1.3-35	---	CHECK Containment Hydrogen Concentration: (Hydrogen concentration > than 0.5% by volume. Recombiner 32 started on lightest loaded Bus.) +56	Manual	0.0 1043.6	0.0 1216.8	75.0 1231.4
- 32 -	ES-1.3-36	---	*** EXIT TO ES-1.4 *** << 6.5 HOURS ELAPSE PRIOR TO ENTERING ES-1.4-1 >>	Manual	0.0 1043.6	0.0 1216.8	0.0 1231.4
- 33 -	ES-1.4-7	---	(No Loads Started or Tripped at this step) *** START HIGH-HEAD RECIRCULATION *** Start SI pump 31. (SI pump 31 started.) +121	Manual	327.2 1370.8	0.0 1216.8	0.0 1231.4
- 34 -	ES-1.4-8	---	Start SI pump 33. (SI pump 33 started.) +123	Manual	0.0 1370.8	0.0 1216.8	327.2 1558.6
- 35 -	ES-1.4-11	---	*** RETURN TO ES-1.3 Step 37 ***	Manual	0.0 1370.8	0.0 1216.8	0.0 1558.6
- 36 -	ES-1.3-37	---	(No Loads Started or Tripped at this step) Evaluate long term plant status. (No Loads Started or Tripped at this step)	Manual	0.0 1370.8	0.0 1216.8	0.0 1558.6

LARGE BREAK LOCA - RCS PRESSURE < 325



Large Break LOCA
 Buses 2A/3A Tied Together, All buses Available
 Loss of Offsite Power
 Operating Loads at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

CCWP 32	EDG 31
CCWP 33	EDG 32
CRP 31	EDG 33
CRP 32	EDG 32
ESWP 35	EDG 31
ESWP 36	EDG 32
FCU 31	EDG 33
FCU 32	EDG 31
FCU 33	EDG 33
FCU 34	EDG 31
FCU 35	EDG 32
MCC 34: TURBINE TURNING GEAR	EDG 31
MCC 36A: AUTO	EDG 33
MCC 36B: AUTO	EDG 32
MCC 36B: H2 RECOMBINER 32	EDG 32
MCC 36C: AUTO	EDG 31
MCC 36D: AUTO	EDG 32
MCC 36E: AUTO	EDG 33
MCCS RESET (2A/3A) AS PER SOP-EL-15	EDG 31
MCCS RESET (5A) AS PER SOP-EL-15	EDG 33
MCCS RESET (6A) AS PER SOP-EL-15	EDG 32
NESWP 31	EDG 33
NESWP 32	EDG 31
PAB FAN 32	EDG 32
SI PUMP 31	EDG 33
SI PUMP 33	EDG 32

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES

ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

LARGE BREAK LOCA - RCS PRESSURE < 325

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:51 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 6A NOT AVAILABLE ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = 1651.6 Bus 2A/3A = 1474.0 Bus 6A = * N/A * (kW)

1750 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1750 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1750 kW rating
Bus 6A Not Available

1950 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1950 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1950 kW rating
Bus 6A Not Available

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCCs 36A, 36C and 36E	Auto	110.0 110.0	94.3 94.3	* N/A *
- 2 -	---	RO-1-2	+57 +50 +50 SI pumps 31 and 32 RHR pump 31 (RO verifies that pumps are running.)	Auto	327.2 437.2	643.3 737.6	* N/A *
- 3 -	E-0-9	---	+116 +121 +122 CSP 31 (E-0-9 verifies that pump is running.)	Auto	307.3 744.5	0.0 737.6	* N/A *
- 4 -	---	RO-1-3	+24 FCUs 31, 32, 33 and 34 (RO verifies that fans are running.)	Auto	258.0 1002.5	258.0 995.6	* N/A *
- 5 -	---	RO-1-5	+29 +31 +33 +35 AFWP 31 (RO verifies that pump is running.)	Auto	0.0 1002.5	378.9 1374.5	* N/A *
- 6 -	---	RO-1-7	+1 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. (All Buses are powered from EDGs.)	Auto	0.0 1002.5	0.0 1374.5	* N/A *
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESWPs (34 and 35) (RO verifies that pumps are running.)	Auto	280.8 1283.3	280.8 1655.3	* N/A *
- 8 -	E-0-11	---	+26 +27 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (RCS pressure is < 325 psig.)	Manual	0.0 1283.3	0.0 1655.3	* N/A *
- 9 -	< 17 >	---	(No Loads Started or Tripped at this step) *** LARGE BREAK LOCA EVENT IDENTIFIED *** *** EXIT TO E-1 *** (No Loads Started or Tripped at this step)	Manual	0.0 1283.3	0.0 1655.3	* N/A *

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	E-1-4	---	Reset SI (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0	0.0	* N/A *
					1293.3	1655.3	* N/A *
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15.	Manual	85.8	63.3	* N/A *
					1369.1	1718.6	* N/A *
- 12 -	E-1-8	---	+82 +81 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	0.0	* N/A *
					1369.1	1718.6	* N/A *
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one Charging pump. (Charging pump 31 started on lightest loaded Bus.)	Manual	140.2	0.0	* N/A *
					1509.3	1718.6	* N/A *
- 14 -	E-1-13	---	+13 Stop CSPs if 5 FCUs are running or Containment pressure is < 16 psig. (4 FCUs are running and psig > 16. CSPs remain running.)	Manual	0.0	0.0	* N/A *
					1509.3	1718.6	* N/A *
- 15 -	E-1-14	---	(No Loads Started or Tripped at this step) Stop RHR pump if pressure is > 325 and pressure is stable or increasing. (Pressure < 325 psig.)	Manual	0.0	0.0	* N/A *
					1509.3	1718.6	* N/A *
- 16 -	< 19 >	---	(No Loads Started or Tripped at this step) *** TRANSFER TO COLD LEG RECIRC. *** *** EXIT TO ES-1.3 ***	Manual	0.0	0.0	* N/A *
					1509.3	1718.6	* N/A *
- 17 -	ES-1.3-5	---	(No Loads Started or Tripped at this step) CHECK SI Recirc SW 1 Function Complete Light - LIT. (YES) (Only two SI pumps running, none stopped.) If two CSPs are running then stop one. (1 running)	Manual	0.0	0.0	* N/A *
					1509.3	1718.6	* N/A *
- 18 -	ES-1.3-6	---	(No Loads Started or Tripped at this step) CHECK SI Recirc SW 3 Function Complete Light - LIT (YES) (RHR pumps - Auto stopped.)	Manual	0.0	-316.1	* N/A *
					1509.3	1402.5	* N/A *


-116

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	---	RO-1-20	CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (All Buses are powered from EDGs.)	Manual	0.0 1509.3	0.0 1402.5	* N/A * * N/A *
- 20 -	ES-1.3-7	---	(No Loads Started or Tripped at this step) STOP Motor Driven Auxiliary Feed Pumps. (AFWPs [only 31 is running] stopped.)	Manual	0.0 1509.3	-378.9 1023.6	* N/A * * N/A *
- 21 -	ES-1.3-8	---	-1 INITIATE Performance of ATTACHMENT 1. STOP Any Running Charging Pumps. PLACE All PRZR HTRs to OFF. (Charging pump 31 stopped. No PRZR HTRs are on.)	Manual	-140.2 1369.1	0.0 1023.6	* N/A * * N/A *
- 22 -	NSE 99-3-075	NSE 99-3-075	-13 AS PER SECTION 4.2.20 of NSE, One CSP run time is less than 30 minutes. (CSP 31 stopped.)	Manual	-307.3 1061.8	0.0 1023.6	* N/A * * N/A *
- 23 -	ES-1.3-9	---	-24 ALIGN SI Recirc SW 2 (NESWP 31 and CCWP 32 auto started.)	Manual	280.8 1342.6	219.6 1243.2	* N/A * * N/A *
- 24 -	ES-1.3-10	---	+84 +9 ALIGN SI Recirc SW 4 (Bus 6A unavailable to start CRP 32.)	Manual	0.0 1342.6	0.0 1243.2	* N/A * * N/A *
- 25 -	ES-1.3-14	---	(No Loads Started or Tripped at this step) ALIGN SI Recirc SW 6 (All running SI pumps auto stopped.)	Manual	-327.2 1015.4	-327.2 916.0	* N/A * * N/A *
- 26 -	ES-1.3-15	---	-121 -122 Can not ALIGN SI Recirc SW 7. Bus 6A is not available. (Only available CRP [31] started.)	Manual	309.0 1324.4	0.0 916.0	* N/A * * N/A *
- 27 -	ES-1.3-24	---	+16 Reset MCCs. (MCCs are already reset.)	Manual	0.0 1324.4	0.0 916.0	* N/A * * N/A *
			(No Loads Started or Tripped at this step)				

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 28 -	ES-1.3-25	---	Start one PAB fan. (PAB fan 31 started.) (PAB fan 31 started.)	Manual	0.0	114.3	* N/A *
					1324.4	1030.3	* N/A *
- 29 -	ES-1.3-28	---	+57 Shutdown unnecessary equipment. a. Check CCWPs. If 3 are running then stop one. b. Check ESWPs. If 3 are running then stop one. (One CCWP and two ESWPs are running.) (No Loads Started or Tripped at this step)	Manual	0.0	0.0	* N/A *
					1324.4	1030.3	* N/A *
- 30 -	---	RO-1-37c	START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite Power. (All Buses are powered from EDGs.) Start Turb Turning Gear. (Gear started).	Manual	0.0	41.5	* N/A *
					1324.4	1071.8	* N/A *
- 31 -	ES-1.3-35	---	+47 CHECK Containment Hydrogen Concentration: Hydrogen concentration > than 0.5% by volume. (Recombiner 31 started.)	Manual	0.0	75.0	* N/A *
					1324.4	1146.8	* N/A *
- 32 -	ES-1.3-36	---	+58 *** EXIT TO ES-1.4 *** << 6.5 HOURS ELAPSE PRIOR TO ENTERING ES-1.4-1 >>	Manual	0.0	0.0	* N/A *
					1324.4	1146.8	* N/A *
- 33 -	ES-1.4-7	---	(No Loads Started or Tripped at this step) *** START HIGH-HEAD RECIRCULATION *** Start SI pump 31. (SI pump 31 started.)	Manual	327.2	0.0	* N/A *
					1651.6	1146.8	* N/A *
- 34 -	ES-1.4-8	---	+121 Start SI pump 33. (Bus 6A unavailable to start SI pump 33.)	Manual	0.0	0.0	* N/A *
					1651.6	1146.8	* N/A *
- 35 -	ES-1.4-9	---	(No Loads Started or Tripped at this step) Start SI pump 32. (SI pump 32 started.)	Manual	0.0	327.2	* N/A *
					1651.6	1474.0	* N/A *
- 36 -	ES-1.4-11	---	+122 *** RETURN TO ES-1.3 Step 37 ***	Manual	0.0	0.0	* N/A *
					1651.6	1474.0	* N/A *
			(No Loads Started or Tripped at this step)				

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A	Bus 2A/3A	Bus 6A
					Step Load/Load (kW)	Step/Total Load (kW)	Step/Total Load (kW)
- 37 -	ES-1.3-37	---	Evaluate long term plant status.	Manual	0.0	0.0	* N/A *
			(No Loads Started or Tripped at this step)		1651.6	1474.0	* N/A *

LARGE BREAK LOCA - RCS PRESSURE < 325



Large Break LOCA
 Buses 2A/3A Tied Together, Bus 6A Not Available
 Loss of Offsite Power
 Operating Loads at the End of Scenario

EQUIPMENT RUNNING

POWER FROM EDG

1 CCWP 32	EDG 31
2 CRP 31	EDG 33
3 ESWP 34	EDG 33
4 ESWP 35	EDG 31
5 FCU 31	EDG 33
6 FCU 32	EDG 31
7 FCU 33	EDG 33
8 FCU 34	EDG 31
14 MCC 34: TURBINE TURNING GEAR	EDG 31
15 MCC 36C: AUTO	EDG 31
16 MCC 36C: H2 RECOMBINER 31	EDG 31
17 MCC 36E: AUTO	EDG 33
19 MCCS RESET (2A/3A) AS PER SOP-EL-15	EDG 31
20 MCCS RESET (5A) AS PER SOP-EL-15	EDG 33
21 NESWP 31	EDG 33
22 PAB FAN 31	EDG 31
23 SI PUMP 31	EDG 33
24 SI PUMP 32	EDG 31
25 MCC 36A: AUTO	EDG 33

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

LARGE BREAK LOCA - RCS PRESSURE < 325

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:51 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 5A NOT AVAILABLE ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = * N/A * Bus 2A/3A = 1460.2 Bus 6A = 1465.8 (kW)

1750 kW Overload Summary

Bus 5A Not Available

Emergency Diesel Generator 31 on Bus 2A/3A exceeds the 1750 kW rating at EOP steps : 13, 14, 15, 16, 17
Emergency Diesel Generator 32 on Bus 6A exceeds the 1750 kW rating at EOP steps : 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17

1950 kW Overload Summary

Bus 5A Not Available

Emergency Diesel Generator 31 on Bus 2A/3A is below the 1950 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating

LARGE BREAK LOCA - RCS PRESSURE < 325

Report Date : August 23, 2009 Time : 3:51 PM [6]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCCs 36B, 36C and 36D	Auto	* N/A *	94.3	100.4
					* N/A *	94.3	100.4
- 2 -	---	RO-1-2	+57 +53 +59 SI pumps 32 and 33 RHP pumps 31 and 32 (RO verifies that pumps are running.)	Auto	* N/A *	615.3	615.3
					* N/A *	709.6	715.7
- 3 -	E-G-9	---	+116 +119 +122 +123 CSP 32 (E-G-9 verifies that pump is running.)	Auto	* N/A *	0.0	319.5
					* N/A *	709.6	1035.2
- 4 -	---	RO-1-2	+25 FCUs 22, 34 and 35 (RO verifies that fans are running.)	Auto	* N/A *	258.0	129.0
					* N/A *	967.6	1164.2
- 5 -	---	RO-1-5	+31 +35 +37 AFWPs 31 and 32 (RO verifies that pumps are running.)	Auto	* N/A *	378.9	375.7
					* N/A *	1346.5	1539.9
- 6 -	---	RO-1-7	+1 +2 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. (All Buses are powered from EDGs.)	Auto	* N/A *	0.0	0.0
					* N/A *	1346.5	1539.9
- 7 -	---	RO-1-5	(No Loads Started or Tripped at this step) ESWPs (35 and 36) (RO verifies that pumps are running.)	Auto	* N/A *	280.8	280.8
					* N/A *	1627.3	1820.7
							Over 1750
- 8 -	E-G-11	---	+27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (RCS pressure is < 325 psig.)	Manual	* N/A *	0.0	0.0
					* N/A *	1627.3	1820.7
							Over 1750
- 9 -	< 17 >	---	(No Loads Started or Tripped at this step) *** LARGE BREAK LOCA EVENT IDENTIFIED *** *** EXIT TO E-1 ***	Manual	* N/A *	0.0	0.0
					* N/A *	1627.3	1820.7
							Over 1750
			(No Loads Started or Tripped at this step)				


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	E-1-4	---	Reset SI (Steps 2 through 12 of RO-1 are completed.)	Manual	* N/A *	0.0	0.0
					* N/A *	1827.3	1820.7 Over 1750
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15.	Manual	* N/A *	63.3	24.8
					* N/A *	1890.6	1845.5 Over 1750
- 12 -	E-1-8	---	+81 +83 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	* N/A *	0.0	0.0
					* N/A *	1890.6	1845.5 Over 1750
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one Charging pump. (Charging pump 32 started on lightest loaded Bus.)	Manual	* N/A *	140.2	0.0
					* N/A *	1830.8	1845.5 Over 1750
- 14 -	E-1-13	---	+14 Stop CSPs if 5 FCUs are running or Containment pressure is < 16 psig. (3 FCUs are running and psig > 16. CSPs remain running.)	Manual	* N/A *	0.0	0.0
					* N/A *	1830.8	1845.5 Over 1750
- 15 -	E-1-14	---	(No Loads Started or Tripped at this step) Stop RHR pumps if pressure is > 325 and pressure is stable or increasing. (Pressure < 325 psig.)	Manual	* N/A *	0.0	0.0
					* N/A *	1830.8	1845.5 Over 1750
- 16 -	< 19 >	---	(No Loads Started or Tripped at this step) *** TRANSFER TO COLD LEG RECIRC. *** *** EXIT TO ES-1.3 ***	Manual	* N/A *	0.0	0.0
					* N/A *	1830.8	1845.5 Over 1750
- 17 -	ES-1.3-5	---	(No Loads Started or Tripped at this step) CHECK SI Recirc SW 1 Function Complete Light - LIT. (YES) (Only two SI pumps running, none stopped.) If two CSPs are running then stop one. (1 running)	Manual	* N/A *	0.0	0.0
					* N/A *	1830.8	1845.5 Over 1750
- 18 -	ES-1.3-6	---	(No Loads Started or Tripped at this step) CHECK SI Recirc SW 3 Function Complete Light - LIT. (YES) (RHR pumps - Auto stopped.)	Manual	* N/A *	-288.1	-288.1
					* N/A *	1542.7	1557.4
			-116 -119				

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	---	RO-1-20	CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (All Buses are powered from EDGs.)	Manual	* N/A *	0.0	0.0
					* N/A *	1542.7	1537.4
- 20 -	ES-1.3-7	---	(No Loads Started or Tripped at this step) Stop Motor Driven Auxiliary Feed Pumps. (AFWPs stopped.)	Manual	* N/A *	-378.9	-375.7
					* N/A *	1163.8	1181.7
- 21 -	ES-1.3-8	---	-1 -2 INITIATE Performance of ATTACHMENT 1. STOP Any Running Charging Pumps. PLACE All PRZR HTRs to OFF. (Charging pump 32 stopped. No PRZR HTRs are on.)	Manual	* N/A *	-140.2	0.0
					* N/A *	1023.6	1181.7
- 22 -	NSE 99-3-075	MSE 99-3-075	-14 AS PER SECTION 4.2.20 of NSE, One CSP run time is less than 30 minutes. (CSP 32 stopped.)	Manual	* N/A *	0.0	-319.5
					* N/A *	1023.6	862.2
- 23 -	ES-1.3-9	---	-25 ALIGN SI Recirc SW 2 (NESWP 32 and CCWP 33 auto started.)	Manual	* N/A *	280.8	219.6
					* N/A *	1304.4	1081.8
- 24 -	ES-1.3-10	---	+25 -12 ALIGN SI Recirc SW 4 (CRP 32 started.)	Manual	* N/A *	0.0	309.0
					* N/A *	1304.4	1390.8
- 25 -	ES-1.3-14	---	+20 Align SI Recirc SW 6 (All running SI pumps auto stopped.)	Manual	* N/A *	-327.2	-327.2
					* N/A *	977.2	1063.6
- 26 -	ES-1.3-15	---	-122 -123 Can not ALIGN SI Recirc SW 7. (Bus 5A not available to start second CRP.)	Manual	* N/A *	0.0	0.0
					* N/A *	977.2	1063.6
- 27 -	ES-1.3-24	---	(No Loads Started or Tripped at this step) Reset MCCs. (MCCs are already reset.)	Manual	* N/A *	0.0	0.0
					* N/A *	977.2	1063.6
			(No Loads Started or Tripped at this step)				

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 28 -	ES-1.3-25	---	Start a PAB fan. (PAB fan 31 started lightest loaded Bus.)	Manual	* N/A *	114.3	0.0
					* N/A *	1091.5	1063.6
- 29 -	ES-1.3-28	---	+87 Shutdown unnecessary equipment. a. CHECK CCWPs. If 3 are running then stop one. b. CHECK ESWPs. If 3 are running then stop one. (One CCWP and two ESWPs are running.) (No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
					* N/A *	1091.5	1063.6
- 30 -	---	RO-1-27c	START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite Power. (All Buses are powered from EDGs.) Start Turb Turning Gear. (Gear started.)	Manual	* N/A *	41.5	0.0
					* N/A *	1133.0	1063.6
- 31 -	ES-1.3-35	---	+47 CHECK Containment Hydrogen Concentration: (Hydrogen concentration > than 0.5% by volume. Recombiner 32 started on lightest loaded Bus.)	Manual	* N/A *	0.0	75.0
					* N/A *	1133.0	1138.6
- 32 -	ES-1.3-36	---	+56 *** EXIT TO ES-1.4 *** << 6.5 HOURS ELAPSE PRIOR TO ENTERING ES-1.4-1 >>	Manual	* N/A *	0.0	0.0
					* N/A *	1133.0	1138.6
- 33 -	ES-1.4-7	---	(No Loads Started or Tripped at this step) *** START HIGH-HEAD RECIRCULATION *** Start SI pump 31. (Bus 5A unavailable to start SI pump 31.)	Manual	* N/A *	0.0	0.0
					* N/A *	1133.0	1138.6
- 34 -	ES-1.4-8	---	(No Loads Started or Tripped at this step) Start SI pump 33. (SI pump 33 started.)	Manual	* N/A *	0.0	327.2
					* N/A *	1133.0	1465.8
- 35 -	ES-1.4-9	---	+123 Start SI pump 32. (SI pump 32 started.)	Manual	* N/A *	327.2	0.0
					* N/A *	1460.2	1465.8
- 36 -	ES-1.4-11	---	+122 *** RETURN TO ES-1.3 Step 37 ***	Manual	* N/A *	0.0	0.0
					* N/A *	1460.2	1465.8
			(No Loads Started or Tripped at this step)				

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 37 -	ES-1.3-37	---	Evaluate long term plant status.	Manual	* N/A *	0.0	0.0
			(No Loads Started or Tripped at this step)		* N/A *	1460.2	1465.8

LARGE BREAK LOCA - RCS PRESSURE < 325



Large Break LOCA
 Buses 2A/3A Tied Together, Bus 5A Not Available
 Loss of Offsite Power
 Operating Loads at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

CCWP 33	EDG 32
CRP 32	EDG 32
ESWP 35	EDG 31
ESWP 36	EDG 32
MCC 34: TURBINE TURNING GEAR	EDG 31
MCC 36B: AUTO	EDG 31
MCC 36B: H2 RECOMBINER 32	EDG 32
MCC 36C: AUTO	EDG 32
MCC 36D: AUTO	EDG 31
MCCS RESET (2A/3A) AS PER SOP-EL-15	EDG 32
MCCS RESET (6A) AS PER SOP-EL-15	EDG 31
NESWP 32	EDG 32
PAB FAN 31	EDG 31
SI PUMP 32	EDG 31
SI PUMP 33	EDG 31

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1
IP3-CALC-ED-00207 REV 8

LARGE BREAK LOCA - RCS PRESSURE < 325

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:51 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 2A AND/OR 3A NOT AVAILABLE ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = 1342.6 Bus 2A/3A = * N/A * Bus 6A = 1580.1 (kW)

1750 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1750 kW rating
Bus 2A and/or 3A Not Available
Emergency Diesel Generator 32 on Bus 6A exceeds the 1750 kW rating at EOP steps : 7, 8, 9, 10, 11, 12, 13, 14, 15, 16

1950 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1950 kW rating
Bus 2A and/or 3A Not Available
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCCs 36A, 36B, 36D and 36E	Auto	110.0 110.0	* N/A * * N/A *	100.4 100.4
- 2 -	---	RO-1-2	+58 +52 +59 +60 SI Pumps 31 and 33 RHR Pump 32 (RO verifies that pumps are running.)	Auto	327.2 437.2	* N/A * * N/A *	643.3 743.7
- 3 -	E-0-9	---	+119 +121 +123 CSPs 31 and 32 (E-0-9 verifies that pumps are running.)	Auto	307.3 744.5	* N/A * * N/A *	319.5 1063.2
- 4 -	---	RO-1-3	+24 +25 FCUs 31, 33 and 35 (RO verifies that fans are running.)	Auto	258.0 1002.5	* N/A * * N/A *	129.0 1192.2
- 5 -	---	RO-1-5	+29 +33 +37 AFWP 33 (RO verifies that pump is running.)	Auto	0.0 1002.5	* N/A * * N/A *	375.7 1567.9
- 6 -	---	RO-1-7	+2 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. (All Buses are powered from EDGs.) (No Loads Started or Tripped at this step)	Auto	0.0 1002.5	* N/A * * N/A *	0.0 1567.9
- 7 -	---	RO-1-8	ESWPs (34 and 36) (RO-1-8 verifies that pumps are running.)	Auto	280.8 1283.3	* N/A * * N/A *	280.8 1848.7 Over 1750
- 8 -	E-0-11	---	+26 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (RCS pressure is < 325 psig.) (No Loads Started or Tripped at this step)	Manual	0.0 1283.3	* N/A * * N/A *	0.0 1848.7 Over 1750
- 9 -	< 17 >	---	*** LARGE BREAK LOCA EVENT IDENTIFIED *** *** EXIT TO E-1 *** (No Loads Started or Tripped at this step)	Manual	0.0 1283.3	* N/A * * N/A *	0.0 1848.7 Over 1750

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	E-1-4	---	Reset SI (Steps 2 through 12 of RO-iare completed.)	Manual	0.0	* N/A *	0.0
					1283.3	* N/A *	1848.7 Over 1750
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (MCCs reset.)	Manual	85.8	* N/A *	24.8
					1369.1	* N/A *	1873.5 Over 1750
- 12 -	E-1-8	---	+62 +83 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	* N/A *	0.0
					1369.1	* N/A *	1873.5 Over 1750
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one Charging pump. (Charging pump 31 started on lightest loaded Bus.)	Manual	140.2	* N/A *	0.0
					1509.3	* N/A *	1873.5 Over 1750
- 14 -	E-1-13	---	+13 Stop CSPs if 5 FCUs are running or Containment pressure is < 16 psig. (3 FCUs are running and psig > 16 CSPs remain running.)	Manual	0.0	* N/A *	0.0
					1509.3	* N/A *	1873.5 Over 1750
- 15 -	E-1-14	---	(No Loads Started or Tripped at this step) Stop RHR pump if pressure is > 325 and pressure is stable or increasing. (Pressure < 325 psig.)	Manual	0.0	* N/A *	0.0
					1509.3	* N/A *	1873.5 Over 1750
- 16 -	< 19 >	---	(No Loads Started or Tripped at this step) *** TRANSFER TO COLD LEG RECIRC. *** *** EXIT TO ES-1.3 ***	Manual	0.0	* N/A *	0.0
					1509.3	* N/A *	1873.5 Over 1750
- 17 -	ES-1.3-5	---	(No Loads Started or Tripped at this step) CHECK SI Recirc SW 1 Function Complete light - LIT. (YES) (Only two SI pumps running, none stopped.) If two CSPs running; stop CSP 32. (CSP 32 stopped)	Manual	0.0	* N/A *	-319.5
					1509.3	* N/A *	1554.0
- 18 -	ES-1.3-6	---	-25 CHECK SI Recirc SW 3 Function Complete Light - LIT. (YES) (RHR pumps [only 32 is running] - Auto stopped.)	Manual	0.0	* N/A *	-316.1
					1509.3	* N/A *	1237.9
			-119				

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	---	RO-1-20	CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (All Buses are powered from EDGs.)	Manual	0.0 1509.3	* N/A * * N/A *	0.0 1237.9
- 20 -	ES-1.3-7	---	(No Loads Started or Tripped at this step) STOP Motor Driven Auxiliary Feed Pumps (AFWPs [only 33 is running] stopped.)	Manual	0.0 1509.3	* N/A * * N/A *	-375.7 862.2
- 21 -	ES-1.3-8	---	-2 INITIATE Performance of ATTACHMENT 1. STOP Any Running Charging Pumps. PLACE All PRZR HTRs to OFF. (Charging pump 31 stopped. No PRZR HTRs are on.)	Manual	-140.2 1369.1	* N/A * * N/A *	0.0 862.2
- 22 -	NSE 99-3-075	NSE 99-3-075	-13 AS PER SECTION 4.2.20 of NSE, One CSP run time is less than 30 minutes. (CSP 31 stopped.)	Manual	-307.3 1061.8	* N/A * * N/A *	0.0 862.2
- 23 -	ES-1.3-9	---	-24 ALIGN SI Recirc SW 2 (NESWP 31 and CCWP 33 auto started.)	Manual	280.8 1342.6	* N/A * * N/A *	219.6 1081.8
- 24 -	ES-1.3-10	---	+84 -12 ALIGN SI Recirc SW 4 (CRP 32 started.)	Manual	0.0 1342.6	* N/A * * N/A *	309.0 1390.8
- 25 -	ES-1.3-14	---	+20 ALIGN SI Recirc SW 6 (ALL running SI pumps auto stopped.)	Manual	-327.2 1015.4	* N/A * * N/A *	-327.2 1063.6
- 26 -	ES-1.3-15	---	-121 -123 Can not ALIGN SI Recirc SW 7. Bus 2A/3A is not available.	Manual	0.0 1015.4	* N/A * * N/A *	0.0 1063.6
- 27 -	ES-1.3-24	---	(No Loads Started or Tripped at this step) Reset MCCs. (MCCs are already reset.)	Manual	0.0 1015.4	* N/A * * N/A *	0.0 1063.6
			(No Loads Started or Tripped at this step)				

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 28 -	ES-1.3-25	---	Start a PAB fan. (PAB fan 32 started.)	Manual	0.0	* N/A *	114.3
					1015.4	* N/A *	1177.9
- 29 -	ES-1.3-28	---	+88 Shutdown unnecessary equipment. a. Check CCWPs. If 3 are running then stop one. b. Check ESWPs. If 3 are running then stop one. (One CCWP and two ESWPs are running.) (No Loads Started or Tripped at this step)	Manual	0.0	* N/A *	0.0
					1015.4	* N/A *	1177.9
- 30 -	---	RO-1-27c	START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite Power. (All Buses are powered from EDGs) Start Turning Gear. (Bus 2A/3A unavailable.) (No Loads Started or Tripped at this step)	Manual	0.0	* N/A *	0.0
					1015.4	* N/A *	1177.9
- 31 -	ES-1.3-35	---	Start a H2 Recombiner. (Recombiner 32 started)	Manual	0.0	* N/A *	75.0
					1015.4	* N/A *	1252.9
- 32 -	ES-1.3-36	---	+56 *** EXIT TO ES-1.4 *** << 6.5 HOURS ELAPSE PRIOR TO ENTERING ES-1.4-1 >>	Manual	0.0	* N/A *	0.0
					1015.4	* N/A *	1252.9
- 33 -	ES-1.4-7	---	(No Loads Started or Tripped at this step) *** START HIGH-HEAD RECIRCULATION *** Start SI pump 31. (SI pump 31 started.)	Manual	327.2	* N/A *	0.0
					1342.6	* N/A *	1252.9
- 34 -	ES-1.4-8	---	+121 Start SI pump 33. (SI pump 33 started.)	Manual	0.0	* N/A *	327.2
					1342.6	* N/A *	1580.1
- 35 -	ES-1.4-11	---	+123 *** RETURN TO ES-1.3 Step 37 ***	Manual	0.0	* N/A *	0.0
					1342.6	* N/A *	1580.1
- 36 -	ES-1.3-37	---	(No Loads Started or Tripped at this step) Evaluate long term plant status.	Manual	0.0	* N/A *	0.0
					1342.6	* N/A *	1580.1
			(No Loads Started or Tripped at this step)				

LARGE BREAK LOCA - RCS PRESSURE < 325



Large Break LOCA
 Buses 2A/3A Tied Together, Bus 2A and/or 3A Not Available
 Loss of Offsite Power
 Operating Loads at the End of Scenario

EQUIPMENT RUNNING

CCWP 33
 CRP 32
 ESWP 34
 ESWP 36
 FCU 31
 FCU 33
 FCU 35
 MCC 36A: AUTO
 MCC 36B: AUTO
 MCC 36B: H2 RECOMBINER 32
 MCC 36D: AUTO
 MCC 36E: AUTO
 MCCS RESET (5A) AS PER SOP-EL-15
 MCCS RESET (6A) AS PER SOP-EL-15
 NESWP 31
 PAB FAN 32
 SI PUMP 31
 SI PUMP 33

POWER FROM EDG

EDG 32
 EDG 32
 EDG 33
 EDG 32
 EDG 33
 EDG 33
 EDG 31
 EDG 33
 EDG 32
 EDG 32
 EDG 32
 EDG 33
 EDG 33
 EDG 33
 EDG 32
 EDG 33
 EDG 32
 EDG 32

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1
IP3-CALC-ED-00207 REV B

SMALL BREAK LOCA
ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:51 PM

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 1751.0 Bus 2A = 2017.9 Bus 3A = 2174.3 Bus 6A = 1997.2 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A/3A is below the 3200 Amp rating
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

SMALL BREAK LOCA - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:51 PM [8]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 3A Step Load/Load (A)	Bus 2A Step/Total Load (A)	Bus 1A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36A, 36B, 36C, 36D and 36E	Auto	169.5	135.5	0.0	150.1
					169.5	135.5	0.0	150.1
- 2 -	---	RO-1-2	+57 +50 +53 +59 +60 SI pumps 31, 32 and 33 RHR pumps 31 and 32 (mini flow, RCS press > 325) {RO verifies that pumps are running.}	Auto	472.4	472.4	264.5	738.5
					641.9	607.9	264.5	888.6
- 3 -	E-0-9	---	+117 +120 +121 +122 +123 CSPs 31 and 32 (Spray not running.) {E-0-9 verifies that spray is not required.}	Manual	0.0	0.0	0.0	0.0
					641.9	607.9	264.5	888.6
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCUs 31, 32, 33, 34 and 35 {RO verifies that fans are running.}	Auto	491.9	347.2	246.0	248.0
					1133.8	855.1	510.5	1136.6
- 5 -	---	RO-1-5	+29 +31 +33 +35 +37 AFWPs 31 and 33 {RO verifies that pumps are running.}	Auto	0.0	0.0	575.4	562.9
					1133.8	855.1	1085.9	1699.5
- 6 -	---	RO-1-7	+1 +2 CCWPs 31, 32 and 33 {RO verifies that pumps are running.}	Auto	250.5	251.3	0.0	251.2
					1384.3	1106.4	1085.9	1950.7
- 7 -	---	RO-1-8	+4 +7 +10 ESWPs (34, 35 and 36) {RO verifies that pumps are running.}	Auto	429.8	0.0	429.0	429.8
					1814.1	1106.4	1514.9	2380.5
- 8 -	E-0-11	---	+26 +27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {CHARGING pump 32 started on lightest loaded Bus.}	Manual	0.0	0.0	208.9	0.0
					1814.1	1106.4	1723.8	2380.5
- 9 -	< 17 >	---	+14 *** SMALL BREAK LOCA EVENT IDENTIFIED *** ***EXIT TO E-1***	Manual	0.0	0.0	0.0	0.0
					1814.1	1106.4	1723.8	2380.5
			(No Loads Started or Tripped at this step)					

SMALL BREAK LOCA - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:51 PM (B)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	E-1-4	---	Reset SI (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0	0.0	0.0	0.0
					1814.1	1106.4	1723.8	2380.5
- 11 -	---	RO-1-10	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset.)	Manual	659.8	848.0	507.6	252.2
					2473.9	1954.4	2231.4	2632.7
- 12 -	E-1-8	---	+126 +124 +125 +127 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	0.0	0.0	0.0
					2473.9	1954.4	2231.4	2632.7
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (CHARGING pump 32 is running.)	Manual	0.0	0.0	0.0	0.0
					2473.9	1954.4	2231.4	2632.7
- 14 -	E-1-11	---	(No Loads Started or Tripped at this step) Check if CSPs can be stopped. (Spray not actuated. No pumps are running.)	Manual	0.0	0.0	0.0	0.0
					2473.9	1954.4	2231.4	2632.7
- 15 -	E-1-14	---	(No Loads Started or Tripped at this step) Stop RHR pumps if pressure is > 325 and pressure is stable or increasing. (All pumps stopped.)	Manual	0.0	0.0	-264.5	-264.5
					2473.9	1954.4	1966.9	2367.9
- 16 -	< 18 >	---	-117 -120 *** EXIT TO ES-1-2 ***	Manual	0.0	0.0	0.0	0.0
					2473.9	1954.4	1966.9	2367.9
- 17 -	ES-1.2-1	---	(No Loads Started or Tripped at this step) Reset MCCs (MCCs are already reset.)	Manual	0.0	0.0	0.0	0.0
					2473.9	1954.4	1966.9	2367.9
- 18 -	ES-1.2-2	---	(No Loads Started or Tripped at this step) Stop RHR pumps if RCS pressure > 325. (RHR pumps are already stopped.)	Manual	0.0	0.0	0.0	0.0
					2473.9	1954.4	1966.9	2367.9
			(No Loads Started or Tripped at this step)					

SMALL BREAK LOCA - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:51 PM [3]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	ES-1.2-7	---	Stop Pressurizer Heaters. (Load never started.)	Manual	0.0	0.0	0.0	0.0
					2473.9	1954.4	1966.9	2367.9
			(No Loads Started or Tripped at this step)					
- 20 -	< 11 >	---	*** FIRST PASS THROUGH PROCEDURE LOOP ***	Manual	0.0	0.0	0.0	0.0
					2473.9	1954.4	1966.9	2367.9
			(No Loads Started or Tripped at this step)					
- 21 -	ES-1.2-13	---	Stop one SI pump. (SI pump 31 stopped from heaviest loaded Bus. CHARGING pump 32 is running.)	Manual	-472.4	0.0	0.0	0.0
					2001.5	1954.4	1966.9	2367.9
			-121					
- 22 -	---	RO-1-20	CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (NESWP 32 started on lightest loaded Bus.)	Manual	0.0	429.0	0.0	0.0
					2001.5	2383.4	1966.9	2367.9
			+85					
- 23 -	ES-1.2-16	---	Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Energized Pressurizer Heater Group 31 and 33 on lightest loaded Buses.)	Manual	549.3	0.0	618.2	0.0
					2541.8	2383.4	2585.1	2367.9
			+89 +106					
- 24 -	ES-1.2-23	---	Stop 1 of 3 CCWPs. Stop 1 of 3 ESWPs and Shutdown Motor-Driven APWPs if desired. (First CCWP 31 and then ESWP 35 stopped on heaviest loaded Bus. APWPs remain running.)	Manual	-259.5	43.1	-429.0	43.0
					2291.3	2426.5	2156.1	2410.9
			+8 +11 -4 -7 -10 -27					
- 25 -	ES-1.2-26	---	DETERMINE if RHR System Can Be Place In Service. a. RCS hot leg temperatures are > 350 Deg. a. RCS pressure > 400 psig (RHR not started.)	Manual	0.0	0.0	0.0	0.0
					2291.3	2426.5	2156.1	2410.9
			(No Loads Started or Tripped at this step)					
- 26 -	ES-1.2-27	---	Check Containment Hydrogen concentration. (Less than 0.5% by vol.)	Manual	0.0	0.0	0.0	0.0
					2291.3	2426.5	2156.1	2410.9
			(No Loads Started or Tripped at this step)					
- 27 -	ES-1.2-28a	---	Check if FAN fans are running. No (FAN Fan 31 started on lightest loaded Bus.)	Manual	0.0	0.0	177.0	0.0
					2291.3	2426.5	2333.1	2410.9
			-87					

SMALL BREAK LOCA - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:51 PM [8]


Step Number	SNO Step	RO Stop	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 28 -	ES-1.2-28c	---	Start: BAST Htrs, Hot Pent Blower, PWMU, SFP pump and Elec Tunnel Fans. (All loads accounted for in total MCC resets.)	Manual	0.0 2291.3	0.0 2426.5	0.0 2333.1	0.0 2410.9
- 29 -	< 29 >	---	(No Loads Started or Tripped at this step) *** RETURN TO ES-1.2-2 AND LOOP THROUGH PROCEDURE UNTIL RCS TEMP. IS < 200 DEG. ***	Manual	0.0 2291.3	0.0 2426.5	0.0 2333.1	0.0 2410.9
- 30 -	---	RO-1-27c	(No Loads Started or Tripped at this step) START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.) +47	Manual	0.0 2291.3	63.6 2490.3	0.0 2333.1	0.0 2410.9
- 31 -	ES-1.2-11	---	Stop second SI pump. (SI pump 32 stopped from heaviest loaded Bus.)	Manual	0.0 2291.3	-472.4 2017.9	0.0 2333.1	0.0 2410.9
- 32 -	ES-1.2-23	---	-122 Reduce load on 480V Buses by Shutting down unnecessary equipment.	Manual	0.0 2291.3	0.0 2017.9	0.0 2333.1	0.0 2410.9
- 33 -	< 29 >	---	(No Loads Started or Tripped at this step) *** RETURN TO ES-1.2-2 ***	Manual	0.0 2291.3	0.0 2017.9	0.0 2333.1	0.0 2410.9
- 34 -	ES-1.2-13	---	(No Loads Started or Tripped at this step) Stop last SI pump. (Pump 33 stopped.)	Manual	0.0 2291.3	0.0 2017.9	0.0 2333.1	-473.7 1937.2
- 35 -	< 29 >	---	-123 *** RETURN TO ES-1.2-2 ***	Manual	0.0 2291.3	0.0 2017.9	0.0 2333.1	0.0 1937.2
- 36 -	ES-1.2-7	---	(No Loads Started or Tripped at this step) Shutdown Pressurizer Heaters. (Heaters - deenergized.)	Manual	-540.3 1751.0	0.0 2017.9	-618.2 1714.9	0.0 1937.2
- 89 -	-166							

SMALL BREAK LOCA - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:51 PM [8]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A	Bus 2A	Bus 3A	Bus 6A
					Step Load/Load (A)	Step/Total Load (A)	Step/Total Load (A)	Step/Total Load (A)
- 17 -	ES-1.2-26	---	DETERMINE if RHR System Can Be Placed in Service. (RHR 32 started on lightest loaded Bus.)	Manual	0.0	0.0	459.4	0.0
					1751.0	2017.9	2174.3	1937.2
- 18 -	ES-1.2-27	---	+115 Start one H2 Recombiner if necessary.	Manual	0.0	0.0	0.0	0.0
					1751.0	2017.9	2174.3	1937.2
- 19 -	ES-1.2-30	---	(No Loads Started or Tripped at this step) Evaluate long term plant status.	Manual	0.0	0.0	0.0	0.0
			(No Loads Started or Tripped at this step)		1751.0	2017.9	2174.3	1937.2

SMALL BREAK LOCA



Small Break LOCA
 Total MCC and Lighting Reset
 Offsite Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 31	3A
AFWP 33	6A
CCWP 32	2A
CCWP 33	6A
CHARGING PUMP 32	3A
ESWP 34	5A
ESWP 36	6A
FCU 31	5A
FCU 32	2A
FCU 33	5A
FCU 34	3A
FCU 35	6A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36A: AUTO	5A
MCC 36B: AUTO	6A
MCC 36C: AUTO	2A
MCC 36D: AUTO	6A
MCC 36E: AUTO	5A
NESWP 32	2A
PAB FAN 31	3A
RHR PUMP 31	3A
TOTAL MCC & LIGHTING RESET (2A)	
TOTAL MCC & LIGHTING RESET (3A)	
TOTAL MCC & LIGHTING RESET (5A)	
TOTAL MCC & LIGHTING RESET (6A)	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1
IP3-CALC-ED-00207 REV 8

SMALL BREAK LOCA

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:51 PM

*** BUSES 2A AND 3A TIED TOGETHER ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2682.7 Bus 2A/3A = 2104.1 Bus 6A = 2144.3 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A/3A is below the 3200 Amp rating
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:51 PM [9]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 26A, 36B, 36C, 36D and 36E	Auto	169.5	135.5	150.1
					169.5	135.5	150.1
- 2 -	---	RO-1-2	+57 +50 +53 +59 +60 SI pumps 31, 32 and 33 RHR Pumps 31 and 32 (mini flow, RCS press > 325) {RO verifies that pumps are running.}	Auto	472.4	736.9	738.5
					641.9	872.4	888.6
- 3 -	E-0-9	---	+117 +120 +121 +122 +123 OSPs 31 and 32 (Spray not running.) {E-0-9 verifies that spray is not required.}	Auto	0.0	0.0	0.0
					641.9	872.4	888.6
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCUs 31, 32, 33, 34 and 35 {RO verifies that fans are running.}	Auto	491.9	493.2	248.0
					1133.8	1365.6	1136.6
- 5 -	---	RO-1-5	+29 +31 +33 +35 +37 AFWPs 31 and 33 {RO verifies that pumps are running.}	Auto	0.0	575.4	562.9
					1133.8	1941.0	1699.5
- 6 -	---	RO-1-7	+1 +2 CCWPs 31, 32 and 33 {RO verifies that pumps are running.}	Auto	250.5	251.3	251.2
					1384.3	2192.3	1950.7
- 7 -	---	RO-1-8	+4 +7 +10 ESWPs (34, 35 and 36) {RO verifies that pumps are running.}	Auto	429.8	429.0	429.8
					1814.1	2621.3	2380.5
- 8 -	E-0-11	---	+26 +27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {CHARGING pump 31 started on lightest loaded Bus.}	Manual	208.5	0.0	0.0
					2022.6	2621.3	2380.5
- 9 -	< 17 >	---	+13 *** SMALL BREAK LOCA EVENT IDENTIFIED *** ***EXIT TO E-1 ***	Manual	0.0	0.0	0.0
					2022.6	2621.3	2380.5
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:51 PM [9]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	E-1-4	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0	0.0	0.0
					2022.6	2621.3	2380.5
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset.)	Manual	659.8	407.2	252.2
					2682.4	3028.5	2632.7
- 12 -	E-1-8	---	+126 +127 +3 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	0.0	0.0
					2682.4	3028.5	2632.7
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	0.0	0.0
					2682.4	3028.5	2632.7
- 14 -	E-1-13	---	(No Loads Started or Tripped at this step) Check if CSPs can be stopped. (Spray not actuated. No pumps are running.)	Manual	0.0	0.0	0.0
					2682.4	3028.5	2632.7
- 15 -	E-1-14	---	(No Loads Started or Tripped at this step) Stop RHR pumps if pressure is > 325. and pressure is stable or increasing. (All pumps stopped.)	Manual	0.0	-264.5	-264.8
					2682.4	2764.0	2367.9
- 16 -	< 16 >	---	-117 -120 *** EXIT TO ES-1-2 ***	Manual	0.0	0.0	0.0
					2682.4	2764.0	2367.9
- 17 -	ES-1.2-1	---	(No Loads Started or Tripped at this step) Reset MCCs. (MCCs are already reset.)	Manual	0.0	0.0	0.0
					2682.4	2764.0	2367.9
- 18 -	ES-1.2-2	---	(No Loads Started or Tripped at this step) Stop RHR pumps if pressure is > 325. (RHR pumps are already stopped.)	Manual	0.0	0.0	0.0
					2682.4	2764.0	2367.9
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:51 PM [9]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	ES-1.2-7	---	Stop Pressurizer Heaters. (Load never started.)	Manual	0.0	0.0	0.0
					2682.4	2764.0	2367.9
- 20 -	< 11 >	---	(No Loads Started or Tripped at this step) *** FIRST PASS THROUGH PROCEDURE LOOP ***	Manual	0.0	0.0	0.0
					2682.4	2764.0	2367.9
- 21 -	ES-1.2-13	---	(No Loads Started or Tripped at this step) Stop one SI pump. (SI pump 31 stopped from heaviest loaded Bus.) (CHARGING pump 31 is running.)	Manual	-472.4	0.0	0.0
					2210.0	2764.0	2367.9
- 22 -	---	RO-1-20	-121 CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (NESWP 31 started on lightest loaded Bus.)	Manual	429.8	0.0	0.0
					2639.8	2764.0	2367.9
- 23 -	ES-1.2-16	---	+84 Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Energized Prssurizer Heater Control Group on lightest loaded Bus.)	Manual	0.0	0.0	308.6
					2639.8	2764.0	2676.5
- 24 -	ES-1.2-23	---	+114 Stop 1 of 3 CCWPs. Stop 1 of 3 ESWPs and Shutdown Motor-Driven AFWPs if desired. (First CCWP 32 and then ESWP 36 stopped from heaviest loaded Bus. AFWPs remain running.)	Manual	42.9	-251.3	-386.8
					2682.7	2512.7	2289.7
- 25 -	ES-1.2-26	---	+5 +11 -4 -7 -16 -28 DETERMINE if RHR System Can Be Place In Service. a. RCS hot leg temperature are > 350 Deg. a. RCS pressure > 400 psig. (RHR not started.)	Manual	0.0	0.0	0.0
					2682.7	2512.7	2289.7
- 26 -	ES-1.2-27	---	(No Loads Started or Tripped at this step) Check Containment Hydrogen concentration. (Less than 0.5% by vol.)	Manual	0.0	0.0	0.0
					2682.7	2512.7	2289.7
- 27 -	ES-1.2-28a	---	(No Loads Started or Tripped at this step) Check if PAB fans are running. No (PAB Fan 32 started on lightest loaded Bus.)	Manual	0.0	0.0	177.0
					2682.7	2512.7	2466.7
			+88				

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:51 PM (9)


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 28 -	ES-1.2-28c	---	Start: BAST Htrs, Hot Pent Blower, PWMU, SFP pump and Elec Tunnel Fans. (All loads accounted for in MCC resets.)	Manual	0.0 2682.7	0.0 2512.7	0.0 2466.7
- 29 -	< 29 >	---	(No Loads Started or Tripped at this step) *** RETURN TO ES-1.2-2 AND LOOP THROUGH PROCEDURE UNTIL RCS TEMP. IS < 200 DEG. ***	Manual	0.0 2682.7	0.0 2512.7	0.0 2466.7
- 30 -	---	RO-1-27c	(No Loads Started or Tripped at this step) START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.) +47	Manual	0.0 2682.7	63.8 2576.5	0.0 2466.7
- 31 -	ES-1.2-13	---	Stop second SI pump. (SI pump 32 stopped from heaviest loaded Bus.)	Manual	0.0 2682.7	-472.4 2104.1	0.0 2466.7
- 32 -	ES-1.2-23	---	-122 Reduce load on 480V Buses by shutting down unnecessary equipment.	Manual	0.0 2682.7	0.0 2104.1	0.0 2466.7
- 33 -	< 29 >	---	(No Loads Started or Tripped at this step) *** RETURN TO ES-1.2-2 ***	Manual	0.0 2682.7	0.0 2104.1	0.0 2466.7
- 34 -	ES-1.2-13	---	(No Loads Started or Tripped at this step) Stop last SI pump (Pump 33 stopped.)	Manual	0.0 2682.7	0.0 2104.1	-473.7 1993.0
- 35 -	< 29 >	---	-123 *** RETURN TO ES-1.2-2 ***	Manual	0.0 2682.7	0.0 2104.1	0.0 1993.0
- 36 -	ES-1.2-7	---	(No Loads Started or Tripped at this step) Shutdown Pressurizer Heaters. (Heaters - deenergized.)	Manual	0.0 2682.7	0.0 2104.1	-308.6 1684.4
			-114				

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:51 PM [9]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 37 -	ES-1.2-26	---	DETERMINE If RHR Sysyem Can Be Placed In Service. (RHR 32 started on lightest loaded Bus.)	Manual	0.0 2682.7	0.0 2104.1	459.9 2144.3
- 38 -	ES-1.2-27	---	118 Start one H2 Recombiner if necessary.	Manual	0.0 2682.7	0.0 2104.1	0.0 2144.3
- 39 -	ES-1.2-30	---	(No Loads Started or Tripped at this step) Evaluate long term plant status.	Manual	0.0 2682.7	0.0 2104.1	0.0 2144.3
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA



Small Break LOCA
 Buses 2A/3A Tied Together, All Buses Available
 Offsite Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 31	3A
AFWP 33	6A
CCWP 31	5A
CCWP 33	6A
CHARGING PUMP 31	5A
ESWP 34	5A
ESWP 35	3A
FCU 31	5A
FCU 32	2A
FCU 33	5A
FCU 34	3A
FCU 35	6A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36A: AUTO	5A
MCC 36B: AUTO	6A
MCC 36C: AUTO	2A
MCC 36D: AUTO	6A
MCC 36E: AUTO	5A
NESWP 31	5A
NESWP 33	6A
PAB FAN 32	6A
RHR PUMP 32	6A
TOTAL MCCS & LIGHTING RESET BUS 5A	
TOTAL MCCS & LIGHTING RESET BUS 6A	
MCCS RESET (2A/3A) AS PER SOP-EL-15	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

SMALL BREAK LOCA

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:51 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 6A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2682.7 Bus 2A/3A = 3034.9 Bus 6A = * N/A * (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A/3A is below the 3200 Amp rating
Bus 6A Not Available

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A Not Available

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:51 PM (10)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36A, 36C and 36E	Auto	169.5 169.5	135.5 135.5	* N/A *
- 2 -	---	RO-1-2	+57 +50 +60 SI pumps 31 and 32 RHR pump 31 (mini flow, RCS press > 325) {RO verifies that pumps are running.}	Auto	472.4 641.9	736.9 872.4	* N/A *
- 3 -	E-0-9	---	+117 +121 +122 CSPs 31 and 32 (Spray not running.) {E-0-9 verifies that spray is not required.}	Auto	0.0 641.9	0.0 872.4	* N/A *
- 4 -	---	RO-1-3	{No Loads Started or Tripped at this step} FCUs 31, 32, 33 and 34 {RO verifies that fans are running.}	Auto	491.9 1133.8	493.2 1365.6	* N/A *
- 5 -	---	RO-1-5	+29 +31 +33 +35 AFWP 31 {RO verifies that pumps are running.}	Auto	0.0 1133.8	575.4 1941.0	* N/A *
- 6 -	---	RO-1-7	+1 CCWPs 31 and 32 {RO verifies that pumps are running.}	Auto	293.4 1427.2	294.4 2235.4	* N/A *
- 7 -	---	RO-1-8	+4 +7 ESWPs (34 and 35) {RO verifies that pumps are running.}	Auto	429.8 1857.0	429.0 2664.4	* N/A *
- 8 -	E-0-11	---	+26 +27 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {CHARGING pump 31 started on lightest loaded Bus.}	Manual	206.5 2065.5	0.0 2664.4	* N/A *
- 9 -	< 17 >	---	+13 *** SMALL BREAK LOCA EVENT IDENTIFIED *** ***EXIT TO E-1 ***	Manual	0.0 2065.5	0.0 2664.4	* N/A *
			{No Loads Started or Tripped at this step}				

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:51 PM (10)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	E-1-4	---	Reset S1. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0 2865.5	0.0 2664.4	* N/A * * N/A *
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset.)	Manual	659.8 2725.3	407.2 3071.6	* N/A * * N/A *
- 12 -	E-1-8	---	+126 +3 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0 2725.3	0.0 3071.6	* N/A * * N/A *
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (Charging pump 31 is running.)	Manual	0.0 2725.3	0.0 3071.6	* N/A * * N/A *
- 14 -	E-1-13	---	(No Loads Started or Tripped at this step) Check if CSPs can be stopped. (Spray not actuated. No pumps are running.)	Manual	0.0 2725.3	0.0 3071.6	* N/A * * N/A *
- 15 -	E-1-14	---	(No Loads Started or Tripped at this step) Stop RHR pump if pressure is > 325 and pressure is stable or increasing. (Only pump 31 running - stopped.)	Manual	0.0 2725.3	-264.5 2807.1	* N/A * * N/A *
- 16 -	< 16 >	---	-117 *** EXIT TO ES-1-2 ***	Manual	0.0 2725.3	0.0 2807.1	* N/A * * N/A *
- 17 -	ES-1.2-1	---	(No Loads Started or Tripped at this step) Reset MCCs. (MCCs are already reset.)	Manual	0.0 2725.3	0.0 2807.1	* N/A * * N/A *
- 18 -	ES-1.2-2	---	(No Loads Started or Tripped at this step) Stop RHR pump if pressure is > 325. (RHR pump already stopped.)	Manual	0.0 2725.3	0.0 2807.1	* N/A * * N/A *
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:51 PM [10]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	ES-1.2-7	---	Stop Pressurizer Heaters. (Load never started.)	Manual	0.0	0.0	* N/A *
					2725.3	2807.1	* N/A *
- 20 -	< 11 >	---	(No Loads Started or Tripped at this step)	Manual	0.0	0.0	* N/A *
			*** FIRST PASS THROUGH PROCEDURE LOOP ***		2725.3	2807.1	* N/A *
- 21 -	ES-1.2-13	---	(No Loads Started or Tripped at this step) Stop one SI pump. (SI pump 31 stopped from heaviest loaded Bus. CHARGING pump 31 is running.)	Manual	-472.4	0.0	* N/A *
					2252.9	2807.1	* N/A *
- 22 -	---	RO-1-20	-121 CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (NESWP 31 started on lightest loaded Bus.)	Manual	429.8	0.0	* N/A *
					2682.7	2807.1	* N/A *
- 23 -	ES-1.2-16	---	+84 Energize at least one Pressurizer Heater Group. as per SOP-EL-15. (Energized Pressurizer Heater 33.)	Manual	231.6	0.0	* N/A *
					2914.3	2807.1	* N/A *
- 24 -	ES-1.2-23	---	+109 Stop 1 of 3 CCWPs. (CCWPs 31 and 32 are running.) Stop 1 of 3 ESWPs. (ESWPs 34 and 35 are running.) Shutdown Motor-Driven AFWPs if desired. (Bus 6A not available. AFWP 31 remains running.)	Manual	0.0	0.0	* N/A *
					2914.3	2807.1	* N/A *
- 25 -	ES-1.2-26	---	(No Loads Started or Tripped at this step) DETERMINE If RHR System Can Be Place In Service. a. RCS hot leg temperature are > 350 Deg. a. RCS pressure > 400 psig (RHR not started.)	Manual	0.0	0.0	* N/A *
					2914.3	2807.1	* N/A *
- 26 -	ES-1.2-27	---	(No Loads Started or Tripped at this step) Check Containment Hydrogen concentration. (Less than 0.5% by vol.)	Manual	0.0	0.0	* N/A *
					2914.3	2807.1	* N/A *
- 27 -	ES-1.2-28a	---	(No Loads Started or Tripped at this step) Check if PAB fans are running. (PAB Fan 21 started.)	Manual	0.0	177.0	* N/A *
					2914.3	2984.1	* N/A *
			+87				

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:51 PM [10]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 28 -	ES-1.1-28c	---	Start: BAST Htrs, Hot Pent Blower, PWMU, SFP pump. (Bus 6A unavailable to start loads) Start Elec Tunnel Fans. (Fans are running.)	Manual	0.0 2914.3	0.0 2984.1	* N/A * * N/A *
- 29 -	< 29 >	---	(No Loads Started or Tripped at this step) *** RETURN TO ES-1.2-2 AND LOOP THROUGH PROCEDURE UNTIL RCS TEMP. IS < 200 DEG. ***	Manual	0.0 2914.3	0.0 2984.1	* N/A * * N/A *
- 30 -	---	RO-1-27c	(No Loads Started or Tripped at this step) START AC and STOP DC Oil Pumps if 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.) +47	Manual	0.0 2914.3	63.8 3047.9	* N/A * * N/A *
- 31 -	ES-1.2-13	---	Stop last SI pump. (Pump 32 stopped.)	Manual	0.0 2914.3	-472.4 2575.5	* N/A * * N/A *
- 32 -	< 29 >	---	-122 *** RETURN TO ES-1.2-2 ***	Manual	0.0 2914.3	0.0 2575.5	* N/A * * N/A *
- 33 -	ES-1.2-7	---	(No Loads Started or Tripped at this step) Shutdown Pressurizer Heaters (Heaters - deenergized.)	Manual	-231.6 2682.7	0.0 2575.5	* N/A * * N/A *
- 34 -	ES-1.2-26	---	-109 DETERMINE If RHR System Can Be Placed In Service. (RHR 31 started on only available Bus.)	Manual	0.0 2682.7	459.4 3034.9	* N/A * * N/A *
- 35 -	ES-1.2-27	---	+115 Start one H2 Recombiner if necessary.	Manual	0.0 2682.7	0.0 3034.9	* N/A * * N/A *
- 36 -	ES-1.2-30	---	(No Loads Started or Tripped at this step) Evaluate long term plant status.	Manual	0.0 2682.7	0.0 3034.9	* N/A * * N/A *
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA



Small Break LOCA
 Buses 2A/3A Tied Together, Bus 6A Not Available
 Offsite Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING

POWER FROM BUS

AFWP 31	3A
CCWP 32	2A
CHARGING PUMP 31	5A
ESWP 34	5A
ESWP 35	3A
FCU 31	5A
FCU 32	2A
FCU 33	5A
FCU 34	3A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36A: AUTO	5A
MCC 36C: AUTO	2A
MCC 36E: AUTO	5A
NESWP 31	5A
PAB FAN 31	3A
RHR PUMP 31	3A
MCCS RESET (2A/3A) AS PER SOP-EL-15	
TOTAL MCCS & LIGHTING RESET BUS 6A	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

SMALL BREAK LOCA

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:51 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 5A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = * N/A * Bus 2A/3A = 2575.5 Bus 6A = 3036.5 (A)

3200 Amp Overload Summary

Bus 5A Not Available
Bus 2A/3A is below the 3200 Amp rating
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A Not Available
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:51 PM [11]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36B, 36C and 36D	Auto	* N/A *	135.5	150.1
					* N/A *	135.5	150.1
- 2 -	---	RO-1-2	-57 +53 +59 SI Pumps 32 and 33 RHR Pumps 31 and 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	* N/A *	736.9	738.5
					* N/A *	872.4	888.6
- 3 -	E-0-9	---	+117 +120 +122 +123 CSFs 31 and 32 (Spray not running.) (E-0-9 verifies that spray is not required.)	Auto	* N/A *	0.0	0.0
					* N/A *	872.4	888.6
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCUs 32, 34 and 35 (RO verifies that fans are running.)	Auto	* N/A *	493.2	248.0
					* N/A *	1365.6	1136.6
- 5 -	---	RO-1-5	+31 +35 +37 AFWPs 31 and 33 (RO verifies that pumps are running.)	Auto	* N/A *	575.4	562.9
					* N/A *	1941.0	1699.5
- 6 -	---	RO-1-7	+1 +2 CCWPs 32 and 33 (RO verifies that pumps are running.)	Auto	* N/A *	294.4	294.2
					* N/A *	2235.4	1993.7
- 7 -	---	RO-1-8	+7 +10 ESWPs (35 and 36) (RO verifies that pumps are running.)	Auto	* N/A *	429.0	429.8
					* N/A *	2654.4	2423.5
- 8 -	E-0-11	---	+27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 33 started on lightest loaded Bus.)	Manual	* N/A *	0.0	209.6
					* N/A *	2654.4	2633.1
- 9 -	< 17 >	---	+15 *** SMALL BREAK LOCA EVENT IDENTIFIED *** *** EXIT TO E-1 ***	Manual	* N/A *	0.0	0.0
					* N/A *	2654.4	2633.1
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:51 PM [11]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	E-1-4	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	* N/A *	0.0	0.0
					* N/A *	2664.4	2633.1
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset.)	Manual	* N/A *	407.2	252.2
					* N/A *	3071.6	2885.3
- 12 -	E-1-8	---	+127 +3 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	* N/A *	0.0	0.0
					* N/A *	3071.6	2885.3
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (CHARGING pump 33 is running.)	Manual	* N/A *	0.0	0.0
					* N/A *	3071.6	2885.3
- 14 -	E-1-13	---	(No Loads Started or Tripped at this step) Check if CSPs can be stopped. (Spray not actuated. No pumps are running.)	Manual	* N/A *	0.0	0.0
					* N/A *	3071.6	2885.3
- 15 -	E-1-14	---	(No Loads Started or Tripped at this step) Stop RHR pumps if pressure is > 325 and pressure is stable or increasing. (All pumps stopped.)	Manual	* N/A *	-264.5	-264.8
					* N/A *	2807.1	2620.5
- 16 -	< 18 >	---	-117 -120 *** EXIT TO ES-1-2 ***	Manual	* N/A *	0.0	0.0
					* N/A *	2807.1	2620.5
- 17 -	ES-1.2-1	---	(No Loads Started or Tripped at this step) Reset MCCs. (MCC are already reset.)	Manual	* N/A *	0.0	0.0
					* N/A *	2807.1	2620.5
- 18 -	ES-1.2-2	---	(No Loads Started or Tripped at this step) Stop RHR pumps if pressure is > 325. (RHR pumps are already stopped.)	Manual	* N/A *	0.0	0.0
					* N/A *	2807.1	2620.5
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:51 PM [11]


Step Number	SRO Step	FO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/2A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	ES-1.2-7	---	Stop Pressurizer Heaters. (Load never started.)	Manual	* N/A *	0.0	0.0
					* N/A *	2807.1	2620.5
- 20 -	< 11 >	---	(No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
			*** FIRST PASS THROUGH PROCEDURE LOOP ***		* N/A *	2807.1	2620.5
- 21 -	ES-1.2-13	---	(No Loads Started or Tripped at this step) Stop one SI pump. (SI pump 33 stopped from heaviest loaded Bus. CHARGING pump 33 is running.)	Manual	* N/A *	0.0	-473.7
					* N/A *	2807.1	2146.8
- 22 -	---	RO-1-20	-123 CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (NESWP 33 started on lightest loaded Bus.)	Manual	* N/A *	0.0	429.8
					* N/A *	2807.1	2576.6
- 23 -	ES-1.2-16	---	+86 Energize at least one Pressurizer Heater Group. as per SOP-EL-15. (Energized Pressurizer Heater Control Group.)	Manual	* N/A *	0.0	308.6
					* N/A *	2807.1	2885.2
- 24 -	ES-1.2-23	---	+114 Stop 1 of 3 CCWPs. (CCWPs 32 and 33 are running.) Stop 1 of 3 ESWPs. (ESWPs 35 and 36 are running.) Shutdown Motor-driven AFWPs if desired. (AFWPs remain running.)	Manual	* N/A *	0.0	0.0
					* N/A *	2807.1	2885.2
- 25 -	ES-1.2-26	---	(No Loads Started or Tripped at this step) DETERMINE IF RHR System Can Be Placed IN Service a. RCS hot leg temperature are > 350 Deg. a. RCS pressure > 400 psig (RHR not started.)	Manual	* N/A *	0.0	0.0
					* N/A *	2807.1	2885.2
- 26 -	ES-1.2-28a	---	(No Loads Started or Tripped at this step) Check if PAB Fans are running. (PAB Fan 31 started on lightest loaded Bus.)	Manual	* N/A *	177.0	0.0
					* N/A *	2984.1	2885.2
- 27 -	ES-1.2-28c	---	-87 Start: BAST Htrs, Hot Pent Blowers, PWMU. SFP pump and Elec Tunnel Fans. (All loads accounted for in MCC resets.)	Manual	* N/A *	0.0	0.0
					* N/A *	2984.1	2885.2
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:51 PM [11]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 28 -	< 29 >	---	*** RETURN TO ES-1.2-2 AND LOOP THROUGH PROCEDURE UNFIL RCS TEMP. IS < 200 DEG. *** (No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
- 29 -	---	RO-1-27c	START AC and STOP DC Oil Pumps If 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.) +47	Manual	* N/A *	2984.1	2885.2
- 30 -	ES-1.2-13	---	Stop last SI pump. (Pump 33 stopped.) -122	Manual	* N/A *	3047.9	2885.2
- 31 -	< 29 >	---	*** RETURN TO ES-1.2-2 *** (No Loads Started or Tripped at this step)	Manual	* N/A *	-472.4	0.0
- 32 -	ES-1.2-7	---	Shutdown Pressurizer Heaters (Heaters - deenergized.) -114	Manual	* N/A *	2575.5	2885.2
- 33 -	ES-1.2-26	---	DETERMINE IF RHR System Can Be Place In Service. (RHR 32 started on lightest loaded Bus.) +110	Manual	* N/A *	0.0	0.0
- 34 -	ES-1.2-27	---	Start one H2 Recombiner if necessary.	Manual	* N/A *	2575.5	2885.2
- 35 -	ES-1.2-30	---	(No Loads Started or Tripped at this step) Evaluate long term plant status. (No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
					* N/A *	2575.5	3036.5

SMALL BREAK LOCA



Small Break LOCA
 Buses 2A/3A Tied Together, Bus 5A Not Available
 Offsite Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 31	3A
AFWP 33	6A
CCWP 32	2A
CCWP 33	6A
CHARGING PUMP 33	6A
ESWP 35	3A
ESWP 36	6A
FCU 32	2A
FCU 34	3A
FCU 35	6A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36B: AUTO	6A
MCC 36C: AUTO	2A
MCC 36D: AUTO	6A
NESWP 33	6A
PAB FAN 31	3A
RHR PUMP 32	6A
MCCS RESET (2A/3A) AS PER SOP-EL-15	
TOTAL MCCS & LIGHTING RESET BUS 6A	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

SMALL BREAK LOCA

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:52 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 2A AND/OR 3A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2602.7 Bus 3A/3A = * N/A * Bus 6A = 2574.1 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A and/or 3A Not Available
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A and/or 3A Not Available
Bus 6A is below the 3600 Amp rating

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:52 PM [12]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	NCC 36A, 36B, 36D and 36E	Auto	169.5	* N/A *	150.1
					169.5	* N/A *	150.1
- 2 -	---	RO-1-2	+50 +53 +59 +60 SI pumps 31 and 33 RHR Pumps 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	472.4	* N/A *	738.5
					641.9	* N/A *	888.6
- 3 -	E-0-9	---	+120 +121 +123 CSPs 31 and 32 (Spray not running.) (E-0-9 verifies that spray is not required.)	Auto	0.0	* N/A *	0.0
					641.9	* N/A *	888.6
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCUs 31, 33 and 35 (RO verifies that fans are running.)	Auto	491.9	* N/A *	248.0
					1133.8	* N/A *	1136.6
- 5 -	---	RO-1-5	+29 +33 +37 APWP 33 (RO verifies that pump is running.)	Auto	0.0	* N/A *	562.9
					1133.8	* N/A *	1699.5
- 6 -	---	RO-1-7	+2 CCWPs 31 and 33 (RO verifies that pumps are running.)	Auto	293.4	* N/A *	294.2
					1427.2	* N/A *	1993.7
- 7 -	---	RO-1-8	+4 +10 ESWPs (34 and 36) (RO verifies that pumps are running.)	Auto	429.8	* N/A *	429.8
					1857.0	* N/A *	2423.5
- 8 -	E-0-11	---	+26 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	208.5	* N/A *	0.0
					2065.5	* N/A *	2423.5
- 9 -	< 17 >	---	+13 *** SMALL BREAK LOCA EVENT IDENTIFIED *** *** EXIT TO E-1 ***	Manual	0.0	* N/A *	0.0
					2065.5	* N/A *	2423.5
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:52 PM [12]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load / Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	E-1-4	---	Reset S1 (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0 2065.5	* N/A * * N/A *	0.0 2423.5
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15 (Total MCC and Lighting reset.)	Manual	659.8 2725.3	* N/A * * N/A *	252.2 2675.7
- 12 -	E-1-8	---	+126 +127 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0 2725.3	* N/A * * N/A *	0.0 2675.7
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0 2725.3	* N/A * * N/A *	0.0 2675.7
- 14 -	E-1-13	---	(No Loads Started or Tripped at this step) Check if CSPs can be stopped. (Spray not actuated. No pumps are running.)	Manual	0.0 2725.3	* N/A * * N/A *	0.0 2675.7
- 15 -	E-1-14	---	(No Loads Started or Tripped at this step) Stop RHR pump if pressure is > 325 and pressure is stable or increasing. (Only pump 32 running - stopped.)	Manual	0.0 2725.3	* N/A * * N/A *	-264.8 2410.9
- 16 -	< 18 >	---	-120 *** EXIT TO ES-1-2 ***	Manual	0.0 2725.3	* N/A * * N/A *	0.0 2410.9
- 17 -	ES-1.2-1	---	(No Loads Started or Tripped at this step) Reset MCCs. (MCCs are already reset.)	Manual	0.0 2725.3	* N/A * * N/A *	0.0 2410.9
- 18 -	ES-1.2-2	---	(No Loads Started or Tripped at this step) Stop RHR pump if pressure is > 325. (RHR pump is already stopped.)	Manual	0.0 2725.3	* N/A * * N/A *	0.0 2410.9
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:52 PM [12]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	ES-1.2-7	---	Stop Pressurizer Heaters. (Load never started.)	Manual	0.0	* N/A *	0.0
					2725.3	* N/A *	2410.9
- 20 -	< 11 >	---	(No Loads Started or Tripped at this step) *** FIRST PASS THROUGH PROCEDURE LOOP ***	Manual	0.0	* N/A *	0.0
					2725.3	* N/A *	2410.9
- 21 -	ES-1.2-13	---	(No Loads Started or Tripped at this step) Stop one SF pump. (SI pump 31 stopped from heaviest loaded Bus. CHARGING pump 31 is running.)	Manual	-472.4	* N/A *	0.0
					2252.9	* N/A *	2410.9
- 22 -	---	RO-1-20	-121 CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (NESWP 31 started on lightest loaded Bus.)	Manual	429.8	* N/A *	0.0
					2682.7	* N/A *	2410.9
- 23 -	ES-1.2-16	---	+84 Energize at least one Pressurizer Heater Group. as per SOP-EL-15. (Energized Pressurizer Heater Control Group.)	Manual	0.0	* N/A *	308.6
					2682.7	* N/A *	2719.5
- 24 -	ES-1.2-23	---	+114 Stop 1 of 3 CCWPs. (CCWPs 31 and 33 are running) Stop 1 of 3 ESWPs. (ESWPs 34 and 35 are running) Shutdown Motor-driven AFWPs if desired. (Bus2A/3A not available. AFWP 33 remains running.)	Manual	0.0	* N/A *	0.0
					2682.7	* N/A *	2719.5
- 25 -	ES-1.2-26	---	(No Loads Started or Tripped at this step) DETERMINE If RHR System Can Be Place In Service. a. RCS hot leg temperatures are > 350 Deg. a. RCS pressure > 400 psig (RHR not started.)	Manual	0.0	* N/A *	0.0
					2682.7	* N/A *	2719.5
- 26 -	ES-1.2-27	---	(No Loads Started or Tripped at this step) Check Containment Hydrogen concentration. (Less than 0.5% by vol.)	Manual	0.0	* N/A *	0.0
					2682.7	* N/A *	2719.5
- 27 -	ES-1.2-28a	---	(No Loads Started or Tripped at this step) Check if PAB fans are running. No (PAB Fan 32 started.)	Manual	0.0	* N/A *	177.0
					2682.7	* N/A *	2896.5
			+88				

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:52 PM (12)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 28 -	ES-1.2-28c	---	Start: BAST Htrs. Hot Pent Blowers, PWMU, SFP pump and Tunnel Fans. (All loads accounted for in MCC resets.)	Manual	0.0	* N/A *	0.0
					2682.7	* N/A *	2896.5
- 29 -	< 29 >	---	(No Loads Started or Tripped at this step)	Manual	0.0	* N/A *	0.0
			*** RETURN TO ES-1.2-2 AND LOOP THROUGH PROCEDURE UNTIL RCS TEMP. IS < 200 DEG. ***		2682.7	* N/A *	2896.5
- 30 -	---	RG-1-27c	(No Loads Started or Tripped at this step) START AC and STOP DC Oil Pumps If 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Bus 2A/3A unavailable.)	Manual	0.0	* N/A *	0.0
			(No Loads Started or Tripped at this step)		2682.7	* N/A *	2896.5
- 31 -	ES-1.2-13	---	Stop last SI pump. (SI pump 32 stopped.)	Manual	0.0	* N/A *	-473.7
					2682.7	* N/A *	2422.8
- 32 -	< 29 >	---	-123	Manual	0.0	* N/A *	0.0
			*** RETURN TO ES-1.2-2 ***		2682.7	* N/A *	2422.8
- 33 -	ES-1.2-7	---	(No Loads Started or Tripped at this step) Shutdown Pressurizer Heaters. (Heaters - deenergized.)	Manual	0.0	* N/A *	-308.5
					2682.7	* N/A *	2114.2
- 34 -	ES-1.2-26	---	-114 DETERMINE If RHR System Can Be Place In Service. (RHR 32 started on only available Bus.)	Manual	0.0	* N/A *	453.9
					2682.7	* N/A *	2574.1
- 35 -	ES-1.2-27	---	+118 Start one NE Recombiner if necessary.	Manual	0.0	* N/A *	0.0
					2682.7	* N/A *	2574.1
- 36 -	ES-1.2-30	---	(No Loads Started or Tripped at this step) Evaluate long term plant status.	Manual	0.0	* N/A *	0.0
					2682.7	* N/A *	2574.1
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA



Small Break LOCA
 Buses 2A and / or 3A Not Available
 Offsite Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 33	6A
CCWP 31	5A
CCWP 33	6A
CHARGING PUMP 31	5A
ESWP 34	5A
ESWP 36	6A
FCU 31	5A
FCU 33	5A
FCU 35	6A
MCC 36A: AUTO	5A
MCC 36B: AUTO	6A
MCC 36D: AUTO	6A
MCC 36E: AUTO	5A
NESWP 31	5A
PAB FAN 32	6A
RHR PUMP 32	6A
TOTAL MCCS & LIGHTING RESET BUS 5A	
TOTAL MCCS & LIGHTING RESET BUS 6A	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

TP3-CALC-ED-00207 REV 8

SMALL BREAK LOCA

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:52 PM

*** BUSES 2A AND 3A TIED TOGETHER ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = 1210.9 Bus 2A/3A = 1397.6 Bus 6A = 1421.8 (kW)

1750 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1750 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1750 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1750 kW rating

1950 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1950 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1950 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:52 PM [13]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36A, 36B, 36C, 36D and 36E	Auto	110.0 110.0	94.3 94.3	100.4 100.4
- 2 -	---	RO-1-2	+57 +50 +53 +59 +60 SI Pumps 31, 32 and 33 RHR Pumps 31 and 32 (mini flow, RCS press > 325) {RO verifies that pumps are running.}	Auto	327.2 437.2	509.2 603.5	509.2 609.6
- 3 -	E-0-9	---	+117 +120 +121 +122 +123 CSPs 31 and 32 (Spray not running.) {E-0-9 verifies that spray is not required.}	Auto	0.0 437.2	0.0 603.5	0.0 609.6
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCUs 31, 32, 33, 34 and 35 {RO verifies that fans are running.}	Auto	258.0 695.2	258.0 861.5	129.0 738.6
- 5 -	---	RO-1-5	+29 +31 +33 +35 +37 AFWPs 31 and 33 {RO verifies that pumps are running.}	Auto	0.0 695.2	378.9 1240.4	378.7 1114.3
- 6 -	---	RO-1-7	+1 +2 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP {All Buses are powered from EDGs.}	Auto	0.0 695.2	0.0 1240.4	0.0 1114.3
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESWPs (34, 35 and 36) {RO verifies that pumps are running.}	Auto	280.8 976.0	280.8 1521.2	280.8 1395.1
- 8 -	E-0-11	---	+26 +27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {CHARGING pump 31 started on lightest loaded Bus.}	Manual	140.2 1116.2	0.0 1521.2	0.0 1395.1
- 9 -	< 17 >	---	+13 *** SMALL BREAK LOCA EVENT IDENTIFIED *** *** EXIT TO E-1 *** (No Loads Started or Tripped at this step)	Manual	0.0 1116.2	0.0 1521.2	0.0 1395.1

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:52 PM [13]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	E-1-4	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0 1116.2	0.0 1521.2	0.0 1395.1
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (MCCs are reset.)	Manual	85.8 1202.0	63.3 1584.5	24.8 1419.9
- 12 -	E-1-8	---	+82 +81 +83 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0 1202.0	0.0 1584.5	0.0 1419.9
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0 1202.0	0.0 1584.5	0.0 1419.9
- 14 -	E-1-13	---	(No Loads Started or Tripped at this step) Check if CSPs can be stopped. (Spray not actuated. No pumps are running.)	Manual	0.0 1202.0	0.0 1584.5	0.0 1419.9
- 15 -	E-1-14	---	(No Loads Started or Tripped at this step) Stop RHR pumps if pressure is > 325 and pressure is stable or increasing. (All pumps stopped.)	Manual	0.0 1202.0	-182.0 1402.5	-182.0 1237.9
- 16 -	< 18 >	---	-117 -120 *** EXIT TO ES-1-2 ***	Manual	0.0 1202.0	0.0 1402.5	0.0 1237.9
- 17 -	ES-1.2-1	---	(No Loads Started or Tripped at this step) Reset MCCs. (MCCs are already reset.)	Manual	0.0 1202.0	0.0 1402.5	0.0 1237.9
- 18 -	ES-1.2-2	---	(No Loads Started or Tripped at this step) Stop RHR pumps if pressure is > 325. (RHR pumps are already stopped.)	Manual	0.0 1202.0	0.0 1402.5	0.0 1237.9
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:52 PM [13]

Step Number	S#0 Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	ES-1.2-7	---	Stop Pressurizer Heaters. (Load never started.)	Manual	0.0	0.0	0.0
					1202.0	1402.5	1237.9
- 20 -	< 11 >	---	(No Loads Started or Tripped at this step) *** FIRST PASS THROUGH PROCEDURE LOOP ***	Manual	0.0	0.0	0.0
					1202.0	1402.5	1237.9
- 21 -	ES-1.2-13	---	(No Loads Started or Tripped at this step) Stop one SI pump. (SI pump 32 stopped from heaviest loaded Bus. CHARGING pump 31 is running.)	Manual	0.0	-327.2	0.0
					1202.0	1075.3	1237.9
- 22 -	---	RO-1-20	-122 CHECK if Offsite power is available to a 480V Bus. to start at least one NESWP. (NESWP 32 started on lightest loaded Bus.)	Manual	0.0	280.8	0.0
					1202.0	1356.1	1237.9
- 23 -	ES-1.2-16	---	+85 Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Energized Pressurizer Heater Group 33 on lightest loaded Bus.)	Manual	207.9	0.0	0.0
					1409.9	1356.1	1237.9
- 24 -	ES-1.2-23	---	+109 Stop 1 of 3 running ESWPs and CCWPs. (ESWP 34 stopped from heaviest loaded Bus.) Shutdown Motor-driven AFWPs if desired. (AFWPs remain running.)	Manual	-280.8	0.0	0.0
					1129.1	1356.1	1237.9
- 25 -	ES-1.2-26	---	-26 Determine if RHR System Can Be Place In Service. a. RCS hot leg temperature are > 350 Deg. a. RCS pressure > 400 psig (RHR not started.)	Manual	0.0	0.0	0.0
					1129.1	1356.1	1237.9
- 26 -	ES-1.2-27	---	(No Loads Started or Tripped at this step) Check Containment Hydrogen concentration. (Less than 0.5% by vol.)	Manual	0.0	0.0	0.0
					1129.1	1356.1	1237.9
- 27 -	ES-1.2-26a	---	(No Loads Started or Tripped at this step) Check if PAB fans are running. No (PAB Fan 32 started on lightest loaded Bus.)	Manual	0.0	0.0	114.3
					1129.1	1356.1	1352.2
			+88				

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:52 PM [13]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/2A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 28 -	ES-1.2-28c	---	Start: BAST Htrs, Hot Pent Blower, PWMU, SFP pump (All loads started MCC 37 and 39.) Start Elec Tunnel Fans. (Fans are running.) +68 +61 +66 +67 +62 +80	Manual	70.1 1199.2	0.0 1356.1	80.7 1432.9
- 29 -	< 29 >	---	*** RETURN TO ES-1.2-2 AND LOOP THROUGH PROCEDURE UNTIL RCS TEMP. IS < 200 DEG. ***	Manual	0.0 1199.2	0.0 1356.1	0.0 1432.9
- 30 -	---	RO-1-27c	(No Loads Started or Tripped at this step) START AC and STOP DC Oil Pumps If 480V Buses are powered from Gifsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.) +47	Manual	0.0 1199.2	41.5 1397.6	0.0 1432.9
- 31 -	ES-1.2-11	---	Stop second SI pump. (Pump 33 stopped from heaviest loaded Bus.) -123	Manual	0.0 1199.2	0.0 1397.6	-327.2 1105.7
- 32 -	ES-1.2-23	---	Reduce load on 480V Buses by Shutting Down unnecessary equipment.	Manual	0.0 1199.2	0.0 1397.6	0.0 1105.7
- 33 -	< 29 >	---	(No Loads Started or Tripped at this step) *** RETURN TO ES-1.2-2 ***	Manual	0.0 1199.2	0.0 1397.6	0.0 1105.7
- 34 -	ES-1.2-13	---	(No Loads Started or Tripped at this step) Stop last SI pump. (Pump 32 stopped.)	Manual	0.0 1199.2	0.0 1397.6	0.0 1105.7
- 35 -	< 29 >	---	(No Loads Started or Tripped at this step) *** RETURN TO ES-1.2-2 ***	Manual	0.0 1199.2	0.0 1397.6	0.0 1105.7
- 36 -	ES-1.2-7	---	(No Loads Started or Tripped at this step) Shutdown Pressurizer Heaters. (Heaters - deenergized.) -109	Manual	-207.9 991.3	0.0 1397.6	0.0 1105.7

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:52 PM (13)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A	Bus 2A/3A	Bus 6A
					Step Load/Load (kW)	Step/Total Load (kW)	Step/Total Load (kW)
- 17 -	ES-1.2-26	---	DETERMINE If RHR System Can Be Placed In Service. (CCWP 31 and RHR 32 started on Highest loaded Buses.)	Manual	219.6	0.0	316.1
					1210.9	1397.6	1421.8
- 18 -	ES-1.2-27	---	+118 +6 Start one H2 Recombiner if necessary.	Manual	0.0	0.0	0.0
					1210.9	1397.6	1421.8
- 19 -	ES-1.2-30	---	(No Loads Started or Tripped at this step) Evaluate long term plant status.	Manual	0.0	0.0	0.0
					1210.9	1397.6	1421.8
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA



Small Break LOCA
 Buses 2A/3A Tied Together, All Buses Available
 Loss of off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

AFWP 31	EDG 31
AFWP 33	EDG 32
CHARGING PUMP 31	EDG 33
ESWP 34	EDG 33
ESWP 36	EDG 32
FCU 31	EDG 33
FCU 32	EDG 31
FCU 33	EDG 33
FCU 34	EDG 31
FCU 35	EDG 32
MCC 34: TURBINE TURNING GEAR	EDG 31
MCC 36A: AUTO	EDG 33
MCC 36B: AUTO	EDG 32
MCC 36C: AUTO	EDG 31
MCC 36D: AUTO	EDG 32
MCC 36E: AUTO	EDG 33
MCC 37: BAST HEATER (TANK #1)	EDG 32
MCC 37: BAST HEATER (TANK #2)	EDG 32
MCC 37: PENT. BLOWERS (#1)	EDG 32
MCC 37: PENT. BLOWERS (#2)	EDG 32
MCC 37: PW MU PUMP	EDG 32
MCC 37: SPENT FUEL COOLING PUMP 31	EDG 32
MCCS RESET (2A/3A) AS PER SOP-EL-15	EDG 31
MCCS RESET (5A) AS PER SOP-EL-15	EDG 33
MCCS RESET (6A) AS PER SOP-EL-15	EDG 32
NESWP 32	EDG 31
PAB FAN 32	EDG 32
RHR PUMP 32	EDG 32

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00007 REV 8

SMALL BREAK LOCA

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:52 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 6A NOT AVAILABLE ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = 1445.3 Bus 2A/3A = 1547.2 Bus 6A = * N/A * (kW)

1750 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1750 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A exceeds the 1750 kW rating at EOP steps : 34, 35
Bus 6A Not Available

1950 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1950 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1950 kW rating
Bus 6A Not Available

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:52 PM (14)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36A, 36C and 36E	Auto	110.0	94.3	* N/A *
					110.0	94.3	* N/A *
- 2 -	---	RO-1-2	+57 +58 +60 SI Pumps 31 and 32 RHR Pumps 31 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	327.2	509.2	* N/A *
					437.2	603.5	* N/A *
- 3 -	E-0-9	---	+117 +121 +122 CSPs 31 and 32 (Spray not running.) (E-0-9 verifies that spray is not required.)	Auto	0.0	0.0	* N/A *
					437.2	603.5	* N/A *
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCUs 31, 32, 33 and 34 (RO verifies that fans are running.)	Auto	258.0	258.0	* N/A *
					695.2	861.5	* N/A *
- 5 -	---	RO-1-5	+29 +31 +33 +35 AFWP 31 (RO verifies that pump is running.)	Auto	0.0	378.9	* N/A *
					695.2	1240.4	* N/A *
- 6 -	---	RO-1-7	+1 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. (All Buses are powered from EDGs.)	Auto	0.0	0.0	* N/A *
					695.2	1240.4	* N/A *
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESWPs (34 and 35) (RO verifies that pumps are running.)	Auto	280.8	280.8	* N/A *
					976.0	1521.2	* N/A *
- 8 -	E-0-11	---	+26 +27 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	140.2	0.0	* N/A *
					1116.2	1521.2	* N/A *
- 9 -	< 17 >	---	+13 *** SMALL BREAK LOCA EVENT IDENTIFIED *** *** EXIT TO E-1 ***	Manual	0.0	0.0	* N/A *
					1116.2	1521.2	* N/A *
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:52 PM [14]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	E-1-4	---	Reset SI. (Step 2 through 12 of RO-1 are completed.)	Manual	0.0	0.0	* N/A *
					1116.2	1521.2	* N/A *
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15 (MCCs are reset.)	Manual	85.8	63.3	* N/A *
					1202.0	1584.5	* N/A *
- 12 -	E-1-8	---	+82 +81 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	0.0	* N/A *
					1202.0	1584.5	* N/A *
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	0.0	* N/A *
					1202.0	1584.5	* N/A *
- 14 -	E-1-13	---	(No Loads Started or Tripped at this step) Check if CSPs can be stopped. (Spray not actuated. No pumps are running.)	Manual	0.0	0.0	* N/A *
					1202.0	1584.5	* N/A *
- 15 -	E-1-14	---	(No Loads Started or Tripped at this step) Stop RHR pumps if pressure is > 325 and pressure is stable or increasing. (Only pump 31 running - stopped.)	Manual	0.0	-182.0	* N/A *
					1202.0	1402.5	* N/A *
- 16 -	< 18 >	---	-117 *** EXIT TO ES-1-2 ***	Manual	0.0	0.0	* N/A *
					1202.0	1402.5	* N/A *
- 17 -	ES-1.2-1	---	(No Loads Started or Tripped at this step) Reset MCCs. (MCCs are already reset.)	Manual	0.0	0.0	* N/A *
					1202.0	1402.5	* N/A *
- 18 -	ES-1.2-2	---	(No Loads Started or Tripped at this step) Stop RHR pumps if pressure is > 325. (RHR pumps are already stopped.)	Manual	0.0	0.0	* N/A *
					1202.0	1402.5	* N/A *
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:52 PM [14]


Step Number	SRG Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	ES-1.2-7	---	Stop Pressurizer Heaters. (Load never started.)	Manual	0.0	0.0	* N/A *
					1202.0	1402.5	* N/A *
- 20 -	< 11 >	---	(No Loads Started or Tripped at this step)	Manual	0.0	0.0	* N/A *
			*** FIRST PASS THROUGH PROCEDURE LOOP ***		1202.0	1402.5	* N/A *
- 21 -	ES-1.2-13	---	(No Loads Started or Tripped at this step) Stop one SI pump. (SI pump 32 stopped from heaviest loaded Bus. CHARGING pump 31 is running.)	Manual	0.0	-327.2	* N/A *
					1202.0	1075.3	* N/A *
- 22 -	---	RO-1-20	-122 CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (NESWP 32 started on lightest loaded Bus.)	Manual	0.0	280.8	* N/A *
					1202.0	1356.1	* N/A *
- 23 -	ES-1.2-16	---	+85 Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Energized Pressurizer Heater Group 33 on lightest loaded Bus.)	Manual	207.9	0.0	* N/A *
					1409.9	1356.1	* N/A *
- 24 -	ES-1.2-23	---	+109 Stop 1 of 3 running ESWPs and CCWPs. (Two ESWPs and two CCWPs are running.) Shutdown Motor-driven AFWPs if desired. (Bus 6A not available. AFWP 31 remains running.)	Manual	0.0	0.0	* N/A *
					1409.9	1356.1	* N/A *
- 25 -	ES-1.2-20	---	(No Loads Started or Tripped at this step) DETERMINE if RHR System Can Be Place in Service. a. RCS hot leg temperature are > 350 deg. (RHR not started.)	Manual	0.0	0.0	* N/A *
					1409.9	1356.1	* N/A *
- 26 -	ES-1.2-27	---	(No Loads Started or Tripped at this step) Check Containment Hydrogen concentration. (Less than 0.5% by vol.)	Manual	0.0	0.0	* N/A *
					1409.9	1356.1	* N/A *
- 27 -	ES-1.2-28a	---	(No Loads Started or Tripped at this step) Check if PAB fans are running. No (PAB Fan 31 started.)	Manual	0.0	114.3	* N/A *
					1409.9	1470.4	* N/A *
			+87				

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:52 PM [14]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 9A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 26 -	ES-1.2-28c	---	Start: BAST Htrs, Hot Pent Blowers, PNMU, (Bus 6A unavailable). SFPF 32 started. Start Elec Tunnel Fans. (Fans are running.)	Manual	70.1	0.0	* N/A *
			+80		1480.0	1470.4	* N/A *
- 29 -	< 29 >	---	*** RETURN TO ES-1.2-2 AND LOOP THROUGH PROCEDURE UNTIL RCS TEMP. IS < 200 DEG. ***	Manual	0.0	0.0	* N/A *
			(No Loads Started or Tripped at this step)		1480.0	1470.4	* N/A *
- 30 -	---	RO-1-27c	START AC and STOP DC Oil Pumps If 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.)	Manual	0.0	41.5	* N/A *
			+47		1480.0	1511.9	* N/A *
- 31 -	ES-1.2-11	---	Stop last SI pump. (Pump 31 stopped.)	Manual	-327.2	0.0	* N/A *
					1152.8	1511.9	* N/A *
- 32 -	< 29 >	---	-121	Manual	0.0	0.0	* N/A *
			*** RETURN TO ES-1.2-2 ***		1152.8	1511.9	* N/A *
- 33 -	ES-1.2-7	---	(No Loads Started or Tripped at this step) Shutdown Pressurizer Heaters. (Heaters - deenergized.)	Manual	-207.9	0.0	* N/A *
					944.9	1511.9	* N/A *
- 34 -	ES-1.2-26	---	-109 DETERMINE If RHR System Can Be Placed In Service. (CCWP 31 started on lightest loaded Bus. RHR 31 started on only available Bus.)	Manual	219.6	316.1	* N/A *
					1164.5	1828.0	* N/A *
- 35 -	ES-1.2-27	---	+116 +6 Start one H2 Recominer if necessary.	Manual	0.0	0.0	* N/A *
					1164.5	1828.0	* N/A *
						Over 1750	
- 36 -	ES-1.2-30	---	(No Loads Started or Tripped at this step) Evaluate long term plant status. (For balancing of loads on EDGs. NESWP 32 is stopped and NESWP 31 started as per FOLDOUT page.)	Manual	280.8	-280.8	* N/A *
			+84 -85		1445.3	1547.2	* N/A *

SMALL BREAK LOCA



Small Break LOCA
 Buses 2A/3A Tied Together, Bus 6A Not Available
 Loss of off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING

AFWP 31
 CCWP 31
 CHARGING PUMP 31
 ESWP 34
 ESWP 35
 FCU 31
 FCU 32
 FCU 33
 FCU 34
 MCC 34: TURBINE TURNING GEAR
 MCC 36A: AUTO
 MCC 36C: AUTO
 MCC 36E: AUTO
 MCC 39: SPENT FUEL COOLING PUMP 31
 MCC RESET (5A) AS PER SOP-EL-15
 MCCS RESET (2A/3A) AS PER SOP-EL-15
 NESWP 31
 PAB FAN 31
 RHR PUMP 31

POWER FROM EDG

EDG 31
 EDG 33
 EDG 33
 EDG 33
 EDG 31
 EDG 33
 EDG 31
 EDG 33
 EDG 33
 EDG 31
 EDG 31
 EDG 33
 EDG 31
 EDG 33
 EDG 32
 EDG 33
 EDG 31
 EDG 33
 EDG 31
 EDG 31
 EDG 31

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

1P3-CALC-ED-00207 REV 8

SMALL BREAK LOCA

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:52 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 5A NOT AVAILABLE ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = * N/A * Bus 2A/3A = 1617.2 Bus 6A = 1632.1 (kW)

1750 kW Overload Summary

Bus 5A Not Available
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1750 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1750 kW rating

1950 kW Overload Summary

Bus 5A Not Available
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1950 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:52 PM (15)

Step Number	SPO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36B, 36C and 36D	Auto	* N/A *	94.3	100.4
					* N/A *	94.3	100.4
- 2 -	---	RO-1-2	+57 +61 +59 SF pumps 32 and 33 RHR pumps 31 and 32 (mini flow, RCS press > 325) {RO verifies that pumps are running.}	Auto	* N/A *	509.2	509.2
					* N/A *	603.5	609.6
- 3 -	E-0-9	---	+117 +120 +122 +123 CSP 32 (Spray not running.) {E-0-9 verifies that spray is not required.}	Auto	* N/A *	0.0	0.0
					* N/A *	603.5	609.6
- 4 -	---	RO-1-3	{No Loads Started or Tripped at this step} FCUs 32, 34 and 35 {RO verifies that fans are running.}	Auto	* N/A *	258.0	129.0
					* N/A *	861.5	732.6
- 5 -	---	RO-1-5	+31 +35 +37 AFWPs 31 and 33 {RO verifies that pumps are running.}	Auto	* N/A *	378.9	375.7
					* N/A *	1240.4	1114.3
- 6 -	---	RO-1-7	+1 +2 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. {All Buses are powered from EDGs.}	Auto	* N/A *	0.0	0.0
					* N/A *	1240.4	1114.3
- 7 -	---	RO-1-8	{No Loads Started or Tripped at this step} ESWPs (35 and 36) {RO verifies that pumps are running.}	Auto	* N/A *	280.8	280.8
					* N/A *	1521.2	1395.1
- 8 -	E-0-11	---	+27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {CHARGING pump 33 started on lightest loaded Bus.}	Manual	* N/A *	0.0	140.2
					* N/A *	1521.2	1535.3
- 9 -	< 17 >	---	+15 *** SMALL BREAK LOCA EVENT IDENTIFIED *** *** EXIT TO E-1 *** {No Loads Started or Tripped at this step}	Manual	* N/A *	0.0	0.0
					* N/A *	1521.2	1535.3

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:52 PM [15]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	E-1-4	---	Reset S1. (Steps 2 through 12 of RO-1 are completed.)	Manual	* N/A *	0.0	0.0
					* N/A *	1521.2	1535.3
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (MCCs are reset.)	Manual	* N/A *	63.3	24.8
					* N/A *	1584.5	1560.1
- 12 -	E-1-8	---	+S1 +S2 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	* N/A *	0.0	0.0
					* N/A *	1584.5	1560.1
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (CHARGING pump 33 is running.)	Manual	* N/A *	0.0	0.0
					* N/A *	1584.5	1560.1
- 14 -	E-1-13	---	(No Loads Started or Tripped at this step) Check if CSPs can be stopped. (Spray not actuated. No pumps are running.)	Manual	* N/A *	0.0	0.0
					* N/A *	1584.5	1560.1
- 15 -	E-1-14	---	(No Loads Started or Tripped at this step) Stop RHR pumps if pressure is > 325 and pressure is stable or increasing. (All pumps stopped.)	Manual	* N/A *	-182.0	-182.0
					* N/A *	1402.5	1378.1
- 16 -	< 18 >	---	-117 -126 *** EXIT TO ES-1-2 ***	Manual	* N/A *	0.0	0.0
					* N/A *	1402.5	1378.1
- 17 -	ES-1.2-1	---	(No Loads Started or Tripped at this step) Reset MCCs. (MCCs are already reset.)	Manual	* N/A *	0.0	0.0
					* N/A *	1402.5	1378.1
- 18 -	ES-1.2-2	---	(No Loads Started or Tripped at this step) Stop RHR pumps if pressure is > 325. (RHR pumps are already stopped.)	Manual	* N/A *	0.0	0.0
					* N/A *	1402.5	1378.1
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:52 PM [15]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	ES-1.2-7	---	Stop Pressurizer Heaters. (Load never started.)	Manual	* N/A *	0.0	0.0
					* N/A *	1402.5	1378.1
- 20 -	< 11 >	---	(No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
			*** FIRST PASS THROUGH PROCEDURE LOOP ***		* N/A *	1402.5	1378.1
- 21 -	ES-1.2-13	---	(No Loads Started or Tripped at this step) Stop one SI pump. (SI pump 32 stopped from heaviest loaded Bus. CHARGING pump 33 is running.)	Manual	* N/A *	-327.2	0.0
					* N/A *	1075.3	1378.1
- 22 -	---	RO-1-20	-122 CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (NESWP 32 started on lightest loaded Bus.)	Manual	* N/A *	280.8	0.0
					* N/A *	1356.1	1378.1
- 23 -	ES -1.2-16	---	+85 Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Energized Pressurizer Heater Group 32 on lightest loaded Bus.)	Manual	* N/A *	207.9	0.0
					* N/A *	1564.0	1378.1
- 24 -	ES-1.2-23	---	+101 Stop 1 of 3 ESWPs. (ESWPs 35 and 36 are running.) Shutdown Motor-Driven AFWPs if desired. (AFWPs remains running.)	Manual	* N/A *	0.0	0.0
					* N/A *	1564.0	1378.1
- 25 -	ES-1.2-26	---	(No Loads Started or Tripped at this step) DETERMINE If RHR System Can Be Place In Service. a. RCS hot leg temperature are > 350 Deg. a. RCS pressure > 400 psig. (RHR not started.)	Manual	* N/A *	0.0	0.0
					* N/A *	1564.0	1378.1
- 26 -	ES-1.2-27	---	(No Loads Started or Tripped at this step) Check Containment Hydrogen concentration. (Less than 0.5% by vol.)	Manual	* N/A *	0.0	0.0
					* N/A *	1564.0	1378.1
- 27 -	ES-1.2-28a	---	(No Loads Started or Tripped at this step) Check if PAB fans are running. No (PAB Fan 32 started on lightest loaded Bus.)	Manual	* N/A *	0.0	114.3
					* N/A *	1564.0	1492.4
			+88				

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:52 PM (15)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 28 -	ES-1.2-28c	---	Start: BAST Htrs, Hot Pent Blowers, PWMU, SFP pump (All loads started on MCC 37.). Start Elec Tunnel Fans. (Fans are running.) +68 +61 +66 +67 +62 +69	Manual	* N/A *	0.0	150.8
- 29 -	< 29 >	---	*** RETURN TO ES-1.2-2 AND LOOP THROUGH PROCEDURE UNTIL RCS TEMP. IS < 200 DEG. *** (No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
- 30 -	---	RO-1-27c	START AC and STOP DC Oil Pumps If 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.) +47	Manual	* N/A *	41.5	0.0
- 31 -	ES-1.2-13	---	Stop last SI pump. (Pump 33 stopped.) -123	Manual	* N/A *	0.0	-327.2
- 32 -	< 29 >	---	*** RETURN TO ES-1.2-2 *** (No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
- 33 -	ES-1.2-7	---	Shutdown Pressurizer Heaters. (Heaters - deenergized) -101	Manual	* N/A *	-207.9	0.0
- 34 -	ES-1.2-26	---	DETERMINE if RHR System Can Be Place In Service. (CCWP 32 and RHR 32 started on lightest loaded Buses.) +118 +9	Manual	* N/A *	219.6	316.1
- 35 -	ES-1.2-27	---	Start one H2 Recombiner if necessary.	Manual	* N/A *	0.0	0.0
- 36 -	ES-1.2-30	---	(No Loads Started or Tripped at this step) Evaluate long term plant status. (No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0

SMALL BREAK LOCA



Small Break LOCA
 Buses 2A/3A Tied Together, Bus 5A Not Available
 Loss of off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

AFWP 31	EDG 31
AFWP 33	EDG 32
CHARGING PUMP 33	EDG 32
CCWP 32	EDG 31
ESWP 35	EDG 31
ESWP 36	EDG 32
FCU 32	EDG 31
FCU 34	EDG 31
FCU 35	EDG 32
MCC 34: TURBINE TURNING GEAR	EDG 31
MCC 36B: AUTO	EDG 32
MCC 36C: AUTO	EDG 31
MCC 36D: AUTO	EDG 32
MCC 37: BAST HEATER (TANK #1)	EDG 32
MCC 37: BAST HEATER (TANK #2)	EDG 32
MCC 37: PENT. BLOWER (#1)	EDG 32
MCC 37: PENT. BLOWER (#2)	EDG 32
MCC 37: PW MU PUMP	EDG 32
MCC 37: SPENT FUEL COOLING PUMP 31	EDG 32
MCCS RESET (2A/3A) AS PER SOP-EL-15	EDG 31
MCCS RESET (6A) AS PER SOP-EL-15	EDG 32
NESWP 32	EDG 31
PAB FAN 32	EDG 32
RHR PUMP 32	EDG 32

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

SMALL BREAK LOCA

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:52 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 2A AND/OR 3A NOT AVAILABLE ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = 1275.2 Bus 2A/3A = * N/A * Bus 6A = 1491.9 (kW)

1750 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1750 kW rating
Bus 2A and/or 3A Not Available
Emergency Diesel Generator 32 on Bus 6A exceeds the 1750 kW rating at EOP steps : 33, 34

1950 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1950 kW rating
Bus 2A and/or 3A Not Available
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:52 PM [16]

Step Number	SRD Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36A, 36B, 36D and 36E	Auto	110.0	* N/A *	100.4
					110.0	* N/A *	100.4
- 2 -	---	RO-1-2	+50 +53 +59 +60 SI pumps 31 and 33 RHR pump 32 (mini flow, RCS press > 325) {RO verifies that pumps are running.}	Auto	327.2	* N/A *	509.2
					437.2	* N/A *	609.6
- 3 -	E-0-9	---	+120 +121 +123 CSPs 31 and 32 (Spray not running.) {E-0-9 verifies that spray is not required.}	Manual	0.0	* N/A *	0.0
					437.2	* N/A *	609.6
- 4 -	---	RO-1-3	{No Loads Started or Tripped at this step} FCUs 31, 33 and 35 {RO verifies that fans are running.}	Auto	258.0	* N/A *	129.0
					695.2	* N/A *	738.6
- 5 -	---	RO-1-5	+29 +33 +37 AFWP 33 {RO verifies that pump is running.}	Auto	0.0	* N/A *	375.7
					695.2	* N/A *	1114.3
- 6 -	---	RO-1-7	+2 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. {All Buses are powered from EDGs.}	Auto	0.0	* N/A *	0.0
					695.2	* N/A *	1114.3
- 7 -	---	RO-1-8	{No Loads Started or Tripped at this step} ESWPs (34 and 36) {RO verifies that pumps are running.}	Auto	280.8	* N/A *	280.8
					976.0	* N/A *	1395.1
- 8 -	E-0-11	---	+26 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {CHARGING pump 31 started on lightest loaded Bus.}	Manual	140.2	* N/A *	0.0
					1116.2	* N/A *	1395.1
- 9 -	< 17 >	---	+13 *** SMALL BREAK LOCA EVENT IDENTIFIED *** *** EXIT TO E-1 ***	Manual	0.0	* N/A *	0.0
					1116.2	* N/A *	1395.1
			{No Loads Started or Tripped at this step}				

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:52 PM [16]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	E-1-4	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0	* N/A *	0.0
					1116.2	* N/A *	1395.1
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (MCCs are reset.)	Manual	85.9	* N/A *	24.8
					1202.0	* N/A *	1419.9
- 12 -	E-1-8	---	+82 +83 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	* N/A *	0.0
					1202.0	* N/A *	1419.9
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	* N/A *	0.0
					1202.0	* N/A *	1419.9
- 14 -	E-1-13	---	(No Loads Started or Tripped at this step) Check if CSPs can be stopped. (Spray not actuated. No pumps are running.)	Manual	0.0	* N/A *	0.0
					1202.0	* N/A *	1419.9
- 15 -	E-1-14	---	(No Loads Started or Tripped at this step) Stop RHR pumps if pressure is > 325 and pressure is stable or increasing. (Only pump 23 running - stopped.)	Manual	0.0	* N/A *	-182.0
					1202.0	* N/A *	1237.9
- 16 -	< 18 >	---	-120 *** EXIT TO ES-1-2 ***	Manual	0.0	* N/A *	0.0
					1202.0	* N/A *	1237.9
- 17 -	ES-1.2-1	---	(No Loads Started or Tripped at this step) Reset MCCs. (MCCs are already reset.)	Manual	0.0	* N/A *	0.0
					1202.0	* N/A *	1237.9
- 18 -	ES-1.2-2	---	(No Loads Started or Tripped at this step) Stop RHR pumps if pressure is > 325. (RHR pumps are already stopped.)	Manual	0.0	* N/A *	0.0
					1202.0	* N/A *	1237.9
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:52 PM [16]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	ES-1.2-7	---	Stop Pressurizer Heaters. (Load never started.)	Manual	0.0	* N/A *	0.0
					1202.0	* N/A *	1237.9
- 20 -	< 11 >	---	(No Loads Started or Tripped at this step)	Manual	0.0	* N/A *	0.0
			*** FIRST PASS THROUGH PROCEDURE LOOP ***		1202.0	* N/A *	1237.9
- 21 -	ES-1.2-13	---	(No Loads Started or Tripped at this step) Stop one SI pump. (SI pump 33 stopped from heaviest loaded Bus.)	Manual	0.0	* N/A *	-327.2
					1202.0	* N/A *	910.7
- 22 -	---	RO-1-20	-123 CHECK if Offsite power is available to a 480V Bus. to start at least one NESWP. (NESWP 33 started on lightest loaded Bus.)	Manual	0.0	* N/A *	280.8
					1202.0	* N/A *	1191.5
- 23 -	ES-1.2-16	---	+86 Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Energized Pressurizer Heater Control Group energized on lightest loaded Bus.)	Manual	0.0	* N/A *	277.0
					1202.0	* N/A *	1468.5
- 24 -	ES-1.2-23	---	+114 Stop 1 of 3 ESWPs. (ESWPs 34 and 35 are running.) Shutdown Motor-driven AFWPs if desired. (Bus 2A/3A not available. AFWP 33 remains running)	Manual	0.0	* N/A *	0.0
					1202.0	* N/A *	1468.5
- 25 -	ES-1.2-25	---	(No Loads Started or Tripped at this step) DETERMINE if RHR System Can Be Placed In Service. a. RCS hot leg temperature are > 350 Deg. a. RCS pressure > 400 psig. (RHR not started.)	Manual	0.0	* N/A *	0.0
					1202.0	* N/A *	1468.5
- 26 -	ES-1.2-28a	---	(No Loads Started or Tripped at this step) Check if PAB fans are running. No (PAB Fan 31 started.)	Manual	0.0	* N/A *	114.3
					1202.0	* N/A *	1582.8
- 27 -	ES-1.2-28c	---	+88 Start: BAST Htrs, Hot Pent Blowers, PWMU, SFP pump (All loads started on MCC 37.). Start Elec Tunnel Fans. Fans are running.	Manual	0.0	* N/A *	150.8
					1202.0	* N/A *	1733.6
			-68 +61 +66 +67 +62 +69				

SMALL BREAK LOCA

Report Date : August 25, 2009 Time : 3:52 PM [16]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 28 -	< 29 >	---	*** RETURN TO ES-1.2-2 AND LOOP THROUGH PROCEDURE UNTIL RCS TEMP. IS < 200 DEG. ***	Manual	0.0 1202.0	* N/A * * N/A *	0.0 1733.6
- 29 -	---	RO-1-27c	(No Loads Started or Tripped at this step) START AC and STOP DC Oil Pumps If 480V Buses are powered from Offsite and tie-breakers are open. Start Turb. Turning gear. (Bus 2A/3A unavailable.)	Manual	0.0 1202.0	* N/A * * N/A *	0.0 1733.6
- 30 -	ES-1.2-13	---	(No Loads Started or Tripped at this step) Stop last SI pump. (Pump 31 stopped.)	Manual	-327.2 874.8	* N/A * * N/A *	0.0 1733.6
- 31 -	< 29 >	---	-121 *** RETURN TO ES-1.2-2 ***	Manual	0.0 874.8	* N/A * * N/A *	0.0 1733.6
- 32 -	ES-1.2-7	---	(No Loads Started or Tripped at this step) Shutdown Pressurizer Heaters. (Heaters - deenergized.)	Manual	0.0 874.8	* N/A * * N/A *	-277.0 1456.6
- 33 -	ES-1.2-26	---	-114 DETERMINE If RHR System Can Be Placed In Service. (CCWP 31 started on lightest loaded Bus. RHR 32 started on only available Bus.)	Manual	219.6 1094.4	* N/A * * N/A *	316.1 1772.7 Over 1750
- 34 -	ES-1.2-27	---	+118 +6 Start one H2 Recombiner if necessary.	Manual	0.0 1094.4	* N/A * * N/A *	0.0 1772.7 Over 1750
- 35 -	ES-1.2-30	---	(No Loads Started or Tripped at this step) Evaluate long term plant status. (For balancing of loads on EDGs, NESWP 33 is stopped and NESWP 31 started as per FOLDOUT page.) +34 -36	Manual	280.8 1375.2	* N/A * * N/A *	-280.8 1491.9

SMALL BREAK LOCA



Small Break LOCA
 Buses 2A and / or 3A Not Available
 Loss of off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

AFWP 33	EDG 32
CHARGING PUMP 31	EDG 33
CCWP 31	EDG 33
ESWP 34	EDG 33
ESWP 36	EDG 32
FCU 31	EDG 33
FCU 33	EDG 33
FCU 35	EDG 32
MCC 36A: AUTO	EDG 33
MCC 36B: AUTO	EDG 32
MCC 36D: AUTO	EDG 32
MCC 36E: AUTO	EDG 33
MCC 37: BAST HEATER (TANK #1)	EDG 32
MCC 37: BAST HEATER (TANK #2)	EDG 32
MCC 37: PENT. BLOWER (#1)	EDG 32
MCC 37: PENT. BLOWER (#2)	EDG 32
MCC 37: PW MU PUMP	EDG 32
MCC 37: SPENT FUEL COOLING PUMP 31	EDG 32
MCCS RESET (5A) AS PER SOP-EL-15	EDG 33
MCCS RESET (6A) AS PER SOP-EL-15	EDG 32
NESWP 31	EDG 33
PAB FAN 32	EDG 32
RHR PUMP 32	EDG 32

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES

ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

1P3-CALC-ED-00207 REV 8

SMALL BREAK LOCA (PH B)
ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:55 PM

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2545.1 Bus 2A = 2017.9 Bus 3A = 1359.6 Bus 6A = 2169.7 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A/3A is below the 3200 Amp rating
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

SMALL BREAK LOCA (PH B) - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:55 PM (49)

Step Number	S&O Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A Step/Total Load (A)	Bus 1A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCCs 36A, 36B, 36C, 36D and 36E	Auto	169.5 169.5	135.5 135.5	0.0 0.0	150.1 150.1
- 2 -	---	RO-1-2	+57 +58 +53 +59 +60 SI pumps 31, 32 and 33 RHR pumps 31 and 32 (mini flow, RCS press > 325) {RO verifies that pumps are running.}	Auto	472.4 641.9	472.4 607.9	264.5 264.5	738.5 988.6
- 3 -	E-0-9	---	+117 +120 +121 +122 +123 CSPs 31 and 32 {E-0-9 verifies that pumps are running.}	Auto	453.6 1095.5	0.0 607.9	0.0 264.5	471.1 1359.7
- 4 -	---	RO-1-3	+24 +25 FCUs 31, 32, 33, 34 and 35 {RO verifies that fans are running.}	Auto	491.9 1587.4	247.2 855.1	246.0 510.5	248.0 1607.7
- 5 -	---	RO-1-5	+29 +31 +33 +35 +37 AFWPs 31 and 33 {RO verifies that pumps are running.}	Auto	0.0 1587.4	0.0 855.1	575.4 1085.9	562.9 2170.6
- 6 -	---	RO-1-7	+1 +2 CCWPs 31, 32 and 33 {RO verifies that pumps are running.}	Auto	250.5 1837.9	251.3 1106.4	0.0 1085.9	251.2 3421.8
- 7 -	---	RO-1-8	+4 +7 +10 ESWPs (34, 35 and 36) {RO verifies that pumps are running.}	Auto	429.8 2267.7	0.0 1106.4	429.6 1514.9	429.8 2951.6
- 8 -	E-0-11	---	+26 +27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {CHARGING pump 32 started on lightest loaded Bus.}	Manual	0.0 2267.7	0.0 1106.4	208.9 1723.8	0.0 2951.6
- 9 -	< 17 >	---	+14 *** SMALL BREAK WITH SPRAY LOCA *** ___** EVENT IDENTIFIED, EXIT TO E-1 ***___ {No Loads Started or Tripped at this step}	Manual	0.0 2267.7	0.0 1106.4	0.0 1723.8	0.0 2951.6

SMALL BREAK LOCA (PH B) - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:55 PM [49]

Step Number	SNO Step	RO Step	Loading Step Description	Initiation	Bus 2A Step Load/Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	E-1-4	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0	0.0	0.0	0.0
					2267.7	1106.4	1723.8	2851.6
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15 (Total MCC and Lighting reset.)	Manual	659.8	848.0	507.6	252.2
					2927.5	1954.4	2231.4	3103.8
- 12 -	E-1-8	---	+126 +124 +125 +127 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	0.0	0.0	0.0
					2927.5	1954.4	2231.4	3103.8
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (CHARGING pump 32 is running.)	Manual	0.0	0.0	0.0	0.0
					2927.5	1954.4	2231.4	3103.8
- 14 -	E-1-13	---	(No Loads Started or Tripped at this step) Stop CSPs if 5 FCUs are running or Containment pressure is < 16 psig. (5 FCUs are running, CSPs stopped.)	Manual	-453.6	0.0	0.0	-471.1
					2473.9	1954.4	2231.4	2632.7
- 15 -	E-1-14	---	-24 -25 Stop RHR pumps if pressure is > 325 and pressure is stable or increasing. (Pressure > 325 psig.)	Manual	0.0	0.0	-264.5	-264.8
					2473.9	1954.4	1966.9	2367.9
- 16 -	< 19 >	---	-117 -120 *** ENTER ES-1.3 *** TRANSFER TO COLD LEG RECIRCULATION	Manual	0.0	0.0	0.0	0.0
					2473.9	1954.4	1966.9	2367.9
- 17 -	ES-1.3-5	---	(No Loads Started or Tripped at this step) Stop SI pump 32, if three are running. (SI pump 32 stopped.) Stop CSP 32 if two running. (CSPs not running.)	Manual	0.0	-472.4	0.0	0.0
					2473.9	1482.0	1966.9	2367.9
- 18 -	ES-1.3-6	---	-122 CHECK SI Recirc SW 3 Function Complete light -- LIT. (YES) (RHR pumps 31 and 32 - Auto stopped. Pumps already stopped in E-1.) (No Loads Started or Tripped at this step)	Manual	0.0	0.0	0.0	0.0
					2473.9	1482.0	1966.9	2367.9

SMALL BREAK LOCA (PH B) - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 7:55 PM (49)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	---	RO-1-20	CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (NESWP 32 started on lightest loaded Bus.)	Manual	0.0 2473.9	429.0 1911.0	0.0 1968.9	0.0 2367.9
- 20 -	ES-1.3-7	---	+85 STOP Motor Driven Auxiliary Feed Pumps: a. RCS pressure is less than SG pressure. (APNPs - stopped.)	Manual	0.0 2473.9	0.0 1911.0	-575.4 1391.5	-562.9 1805.0
- 21 -	ES-1.3-8	---	-1 -2 INITIATE Performance of ATTACHMENT 1. Stop Any Running Charging Pumps. Place all PRZR HTRs to OFF. (Charging pump 32 stopped. No HTRs are on.)	Manual	0.0 2473.9	0.0 1911.0	-208.9 1182.6	0.0 1805.0
- 22 -	NSE 99-3-075	NSE 99-3-075	-14 As PFR SECTION 4.2.20 of NSE One CSP run time is less than 30 minutes. (No CSPs are running.)	Manual	0.0 2473.9	0.0 1911.0	0.0 1182.6	0.0 1805.0
- 23 -	ES-1.3-9	---	(No Loads Started or Tripped at this step) Align SI Recirc SW 2 as follows: b. PLACE SI Recirc SW 2 to ON (NESWP 31 Auto started. CCWP 33 is running.)	Manual	429.8 2903.7	0.0 1911.0	0.0 1182.6	0.0 1805.0
- 24 -	ES-1.3-10	---	+04 ALIGN SI Recirc SW 4 Lo Head as follows: b. Manually START 32 Recirc Pump. (CRP 32 started.)	Manual	0.0 2903.7	0.0 1911.0	0.0 1182.6	468.3 2273.3
- 25 -	ES-1.3-14	---	+23 ALIGN SI Recirc SW 6 Lo Head as follows: (SI SW 6 Lo Head function Light is LIT. All running SI pumps [31 and 33] auto stopped.)	Manual	-472.4 2431.3	0.0 1911.0	0.0 1182.6	-473.7 1799.6
- 26 -	ES-1.3-19	---	-121 -123 ALIGN SI Recirc SW 7 as follows: b. PLACE SI Recirc SW 7 to ON. (NESWP 32 and CCWP 32 are already running. CRP 31 auto started.)	Manual	468.3 2899.6	0.0 1911.0	0.0 1182.6	0.0 1799.6
- 27 -	ES-1.3-24	---	+18 Reset MCCs. (MCCs are already reset.)	Manual	0.0 2899.6	0.0 1911.0	0.0 1182.6	0.0 1799.6
			(No Loads Started or Tripped at this step)					

SMALL BREAK LOCA (PH B) - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:55 PM (49)


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 28 -	ES-1.3-25	---	CHECK PAB Exhaust Fan Status: (PAB fan 31 started on lightest loaded Bus.)	Manual	0.0	0.0	177.0	0.0
					2899.6	1911.0	1359.6	1799.6
- 29 -	ES-1.3-28	---	+87 Shutdown Unnecessary Plant Equipment: a. Check CCWPs. If 3 are running then stop one. b. Check ESWPs. If 3 are running then stop one. (CCWP 31, ESWP 34 stopped on heaviest loaded Bus)	Manual	-680.3	43.1	0.0	43.0
					2219.3	1954.1	1359.6	1842.6
- 30 -	---	RO-1-27c	+8 +11 -4 -7 -10 -26 START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open Start Turb Turning Gear. (Gear started.)	Manual	0.0	63.8	0.0	0.0
					2219.3	2017.9	1359.6	1842.6
- 31 -	ES-1.3-35	---	+47 CHECK Containment Hydrogen Concentration: (Hydrogen concentration less than 0.5% by Volume.)	Manual	0.0	0.0	0.0	0.0
					2219.3	2017.9	1359.6	1842.6
- 32 -	ES-1.3-36	---	(No Loads Started or Tripped at this step) *** EXIT TO ES-1.4 *** << 6.5 HOURS ELAPSE PRIOR TO ENTERING ES-1.4-1 >>	Manual	0.0	0.0	0.0	0.0
					2219.3	2017.9	1359.6	1842.6
- 33 -	ES-1.4-7	---	(No Loads Started or Tripped at this step) *** START HIGH-HEAD RECIRCULATION *** Start SI pump 31. (SI pump 31 started.)	Manual	325.8	0.0	0.0	-146.6
					2545.1	2017.9	1359.6	1696.0
- 34 -	ES-1.4-8	---	+121 +19 +22 -18 -23 Start SI pump 33. (SI pump 33 started.)	Manual	0.0	0.0	0.0	473.7
					2545.1	2017.9	1359.6	2169.7
- 35 -	ES-1.4-11	---	+123 *** RETURN TO ES-1.3 Step 37 ***	Manual	0.0	0.0	0.0	0.0
					2545.1	2017.9	1359.6	2169.7
- 36 -	ES-1.3-34	---	(No Loads Started or Tripped at this step) Determine if intact SGs should be depressurized to RCS pressure.	Manual	0.0	0.0	0.0	0.0
					2545.1	2017.9	1359.6	2169.7
			(No Loads Started or Tripped at this step)					

SMALL BREAK LOCA (PH B) - ALL BUSES AVAILABLE - TOTAL RCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:55 PM [49]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 37 -	ES-1.3-37	---	Evaluate long term plant status.	Manual	0.0	0.0	0.0	0.0
			(No Loads Started or Tripped at this step)		2545.1	2017.9	1359.6	2169.7

SMALL BREAK LOCA (PH B)



Small Break LOCA (PH B)
 Total MCC and Lighting Reset
 Offsite Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

CCWP 32	2A
CCWP 33	6A
CRP 31	5A
CRP 32	6A
ESWP 35	3A
ESWP 36	6A
FCU 31	5A
FCU 32	2A
FCU 33	5A
FCU 34	3A
FCU 35	6A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36A: AUTO	5A
MCC 36B: AUTO	6A
MCC 36C: AUTO	2A
MCC 36D: AUTO	6A
MCC 36E: AUTO	5A
NESWP 31	5A
NESWP 32	2A
PAB FAN 31	3A
SI PUMP 31	5A
SI PUMP 33	6A
TOTAL MCC & LIGHTING RESET (2A)	
TOTAL MCC & LIGHTING RESET (3A)	
TOTAL MCC & LIGHTING RESET (5A)	
TOTAL MCC & LIGHTING RESET (6A)	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES

ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

TP3-CALC-ED-00267 REV 8

SMALL BREAK LOCA (PH B)

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:54 PM

*** BUSES 2A AND 3A TIED TOGETHER ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2691.7 Bus 2A/3A = 2252.1 Bus 6A = 2493.3 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A/3A is below the 3200 Amp rating
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:54 PM [44]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCCs 36A, 36B, 36C, 36D and 36E	Auto	169.5	135.5	150.1
- 2 -	---	RO-1-2	+57 +50 +53 +59 +60 SF pumps 31, 32 and 33 RHR pumps 31 and 32 (mini flow, RCS press > 325) {RO verifies that pumps are running.}	Auto	472.4	736.9	738.9
- 3 -	E-0-9	---	+117 +120 +121 +122 +123 CSPs 31 and 32 {E-0-9 verifies that pumps are running.}	Auto	453.6	0.0	471.1
- 4 -	---	RO-1-3	+24 +25 FCUs 31, 32, 33, 34 and 35 {RO verifies that fans are running.}	Auto	491.9	493.2	248.0
- 5 -	---	RO-1-5	+29 +31 +33 +35 +37 AFWPs 31 and 33 {RO verifies that pumps are running.}	Auto	0.0	575.4	562.9
- 6 -	---	RO-1-7	-1 +2 CCWPs 31, 32 and 33 {RO verifies that pumps are running.}	Auto	250.5	251.3	251.2
- 7 -	---	RO-1-8	+4 +7 +10 ESWPs (34, 35 and 36) {RO verifies that pumps are running.}	Auto	429.8	429.0	429.8
- 8 -	E-0-11	---	+26 +27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {CHARGING pump 31 started on lightest loaded Bus.}	Manual	208.5	0.0	0.0
- 9 -	< 17 >	---	+13 *** SMALL BREAK LOCA WITH SPRAY*** *** EVENT IDENTIFIED, EXIT TO E-1 *** {No Loads Started or Tripped at this step}	Manual	0.0	0.0	0.0
					2476.2	2621.3	2851.6

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:54 PM [44]

Step Number	SKO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	E-1-4	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0	0.0	0.0
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset for MCCs powered from Buses 5A and 6A.)	Manual	659.8	407.2	252.2
- 12 -	E-1-8	---	-126 +127 +3 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	0.0	0.0
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	0.0	0.0
- 14 -	E-1-13	---	(No Loads Started or Tripped at this step) Stop CSPs if 5 FCUs are running or Containment pressure is < 16 psig. (5 FCU are running, CSPs stopped.)	Manual	-453.6	0.0	-471.1
- 15 -	E-1-14	---	-24 -25 Stop RHR pumps if pressure is > 325 and pressure is stable or increasing. (Pressure > 325 psig.)	Manual	0.0	-264.5	-264.8
- 16 -	< 19 >	---	-117 -120 *** ENTER ES-1.3 *** TRANSFER TO COLD LRG RECIRCULATION	Manual	0.0	0.0	0.0
- 17 -	ES-1.3-5	---	(No Loads Started or Tripped at this step) Stop SI pump 32, if three are running. (SI pump 32 stopped.) Stop CSP 32 if two running. (CSPs not running.)	Manual	0.0	-472.4	0.0
- 18 -	ES-1.3-6	---	-122 CHECK SI Recirc SW 3 Function Complet Light - LIT. (YES) (RHR pumps 31 and 32 - AUTO stopped. Pumps already stopped in E-1.) (No Loads Started or Tripped at this step)	Manual	0.0	0.0	0.0

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:54 PM [44]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	---	RO-1-20	CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (NESWP 32 started on lightest loaded Bus.)	Manual	0.0	429.6	0.0
			+85		2682.4	2720.6	2367.9
- 20 -	ES-1.3-7	---	STOP Motor Driven Auxiliary Feed Pumps: a. RCS pressure is less than SG pressure. (AFWPs - stopped.)	Manual	0.0	-575.4	-562.9
					2682.4	2145.2	1805.0
- 21 -	ES-1.3-8	---	-1 -2 INITIATE Performance of ATTACHMENT 1. Stop any running Charging pumps and PRZR HTRs. (Only pump 31 is running - stopped.)	Manual	-208.5	0.0	0.0
					2473.9	2145.2	1805.0
- 22 -	NSE 99-3-075	NSE 99-3-075	-13 AS PER SECTION 4.2.29 of NSE, One CSP run time is less than 30 minutes. (No CSPs are running.)	Manual	0.0	0.0	0.0
					2473.9	2145.2	1805.0
- 23 -	ES-1.3-9	---	(No Loads Started or Tripped at this step) Align SI Recirc SW 2 . b. PLACE SI Recirc SW 2 to ON (NESWP 31 auto started. CCWP 33 is running.)	Manual	429.8	0.0	0.0
					2903.7	2145.2	1805.0
- 24 -	ES-1.3-10	---	+84 ALIGN SI Recirc SW 4 Lo Head. b. Manually START 32 Recirc Pump. (CRP 32 started.)	Manual	0.0	0.0	468.3
					2903.7	2145.2	2273.3
- 25 -	ES-1.3-14	---	+23 ALIGN SI Recirc SW 6 Lo Head. (SI SW 6 Lo Head function Light is LIT. All running SI pumps [31 and 33] auto stopped.)	Manual	-472.4	0.0	-473.7
					2431.3	2145.2	1799.6
- 26 -	ES-1.3-15	---	-121 -123 ALIGN SI Recirc SW 7. b. PLACE SI Recirc SW 7 to ON. (NESWP 32 and CCWP 32 are running. CRP 31 auto started.)	Manual	468.3	0.0	0.0
					2899.6	2145.2	1799.6
- 27 -	ES-1.3-24	---	+18 Reset MCCs. (MCCs are already reset.)	Manual	0.0	0.0	0.0
					2899.6	2145.2	1799.6
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA (PH B)

Report Date : August 28, 2009 Time : 3:54 PM [44]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 26 -	ES-1.3-25	---	Start one PAB fan. (PAB fan 32 started on lightest loaded Bus.)	Manual	0.0	0.0	177.0
					2899.6	2145.2	1976.6
- 29 -	ES-1.3-28	---	+88 Shutdown unnecessary equipment. a. Check CCWPs. If 3 are running then stop one. b. Check ESWPs. If 3 are running then stop one. (CCWP 31, ESWP 34 stopped on heaviest loaded Bus.)	Manual	-680.3	43.1	43.0
					3219.3	2188.3	2019.6
- 30 -	---	RO-1-27c	+8 +11 -4 -7 -10 -26 STARTR AC and STOP BC Oil Pumps 1F 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear Started.)	Manual	0.0	63.8	0.0
					2319.3	2252.1	2019.6
- 31 -	ES-1.3-35	---	+47 CHECK Containment Hydrogen Concentration: (Hydrogen concentration less than 0.5% by volume.)	Manual	0.0	0.0	0.0
					2219.3	2252.1	2019.6
- 32 -	ES-1.3-36	---	(No Loads Started or Tripped at this step) *** EXIT TO ES-1.4 *** << 6.5 HOURS ELAPSE PRIOR TO ENTERING ES-1.4-1 >>	Manual	0.0	0.0	0.0
					2219.3	2252.1	2019.6
- 33 -	ES-1.4-7	---	(No Loads Started or Tripped at this step) *** START HIGH-HEAD RECIRCULATION *** Start SI pump 31. (SI pump 31 started.)	Manual	472.4	0.0	0.0
					2691.7	2252.1	2019.6
- 34 -	ES-1.4-8	---	+121 Start SI pump 33. (SI pump 33 started.)	Manual	0.0	0.0	473.7
					2691.7	2252.1	2493.3
- 35 -	ES-1.4-11	---	+123 *** RETURN TO ES-1.3 Step 37 ***	Manual	0.0	0.0	0.0
					2691.7	2252.1	2493.3
- 36 -	ES-1.3-34	---	(No Loads Started or Tripped at this step) Determine if intact SCs should be depressurized to RCS pressure.	Manual	0.0	0.0	0.0
					2691.7	2252.1	2493.3
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:54 PM [44]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A	Bus 2A/3A	Bus 6A
					Step Load/ Load (A)	Step/Total Load (A)	Step/Total Load (A)
- 27 -	SS-1.3-37	---	Evaluate long term plant status.	Manual	0.0	0.0	0.0
			(No Loads Started or Tripped at this step)		2691.7	2252.1	2494.3

SMALL BREAK LOCA (PH B)



Small Break LOCA (PH B)
 Buses 2A/3A Tied Together, All Buses Available
 Offsite Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

CCWP 32	2A
CCWP 33	6A
CRP 31	5A
CRP 32	6A
ESWP 35	3A
ESWP 36	6A
FCU 31	5A
FCU 32	2A
FCU 33	5A
FCU 34	3A
FCU 35	6A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36A: AUTO	5A
MCC 36B: AUTO	6A
MCC 36C: AUTO	2A
MCC 36D: AUTO	6A
MCC 36E: AUTO	5A
NESWP 31	5A
NESWP 32	2A
PAB FAN 32	6A
SI PUMP 31	5A
SI PUMP 33	6A
TOTAL MCCS & LIGHTING RESET BUS 5A	
TOTAL MCCS & LIGHTING RESET BUS 6A	
MCCS RESET (2A/3A) AS PER SOP-EL-15	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES

ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

SMALL BREAK LOCA (PH B)

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:52 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 6A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2691.7 Bus 2A/3A = 2901.5 Bus 6A = * N/A * (A)

3200 Amp Overload Summary

Bus 5A exceeds the 3200 Amp rating at EOP steps : 24
Bus 2A/3A exceeds the 3200 Amp rating at EOP steps : 19
Bus 6A Not Available

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A Not Available

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:52 PM [17]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCCs 36A, 36C and 36E	Auto	169.5	135.5	* N/A *
					169.5	135.5	* N/A *
- 2 -	---	RO-1-2	+57 +50 +60 SI pumps 31 and 32 RHR pump 31 (Pumps are in mini flow due to RCS pressure > 325.) (RO verifies that pumps are running.)	Auto	472.4	736.9	* N/A *
			+117 +121 +122		641.9	872.4	* N/A *
- 3 -	E-0-9	---	GSP 31 (E-0-9 verifies that pump is running.)	Auto	453.6	0.0	* N/A *
					1095.5	872.4	* N/A *
- 4 -	---	RO-1-3	+24 FCUs 31, 32, 33 and 34 (RO verifies that fans are running.)	Auto	491.9	492.2	* N/A *
					1587.4	1365.6	* N/A *
- 5 -	---	RO-1-5	+29 +31 +33 +35 AFWP 31 (RO verifies that pump is running.)	Auto	0.0	575.4	* N/A *
					1587.4	1941.0	* N/A *
- 6 -	---	RO-1-7	+1 CCWPs 31 and 32 (RO verifies that pumps are running.)	Auto	293.4	294.4	* N/A *
					1880.8	2235.4	* N/A *
- 7 -	---	RO-1-8	+4 +7 ESWPs (24 and 35) (RO verifies that pumps are running.)	Auto	429.8	429.0	* N/A *
					2310.6	2664.4	* N/A *
- 8 -	E-0-11	---	+26 +27 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	208.5	0.0	* N/A *
					2519.1	2664.4	* N/A *
- 9 -	< 17 >	---	+13 *** SMALL BREAK LOCA WITH SPRAY *** *** EVENT IDENTIFIED. EXIT TO E-1 *** (No Loads Started or Tripped at this step)	Manual	0.0	0.0	* N/A *
					2519.1	2664.4	* N/A *

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:52 PM [17]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	E-1-4	---	Reset S1. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0 2519.1	0.0 2664.4	* N/A * * N/A *
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Full MCC and lighting reset on Bus 5A.)	Manual	659.8 3178.9	407.2 3071.6	* N/A * * N/A *
- 12 -	E-1-8	---	+126 +3 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0 3178.9	0.0 3071.6	* N/A * * N/A *
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start CHARGING one pump. (CHARGING pump 31 is running.)	Manual	0.0 3178.9	0.0 3071.6	* N/A * * N/A *
- 14 -	E-1-13	---	(No Loads Started or Tripped at this step) Stop CSPs if 5 FCUs are running or Containment pressure is < 16 psig. (4 FCUs are running and psig >16. CSP [31] remains running.)	Manual	0.0 3178.9	0.0 3071.6	* N/A * * N/A *
- 15 -	E-1-14	---	(No Loads Started or Tripped at this step) Stop RHR pump, if RCS pressure is > 325 and pressure is stable or increasing. (Pressure > 325 psig.)	Manual	0.0 3178.9	-264.5 2807.1	* N/A * * N/A *
- 16 -	< 19 >	---	-117 *** ENTER ES-1.3 *** TRANSFER TO COLD LSG RECIRCULATION	Manual	0.0 3178.9	0.0 2807.1	* N/A * * N/A *
- 17 -	ES-1.3-5	---	(No Loads Started or Tripped at this step) Stop SI pump 32, if three pumps are running. (Only two SI pumps are running.) If two CSPs are running then stop one. (Only CSP 31 is running.)	Manual	0.0 3178.9	0.0 2807.1	* N/A * * N/A *
- 18 -	ES-1.3-6	---	(No Loads Started or Tripped at this step) Check SI Recirc SW 3 Function complete Light - LIT (YES) (RHR pumps [only 31is running] - Auto stopped. Pump already stoppped in E-1.) (No Loads Started or Tripped at this step)	Manual	0.0 3178.9	0.0 2807.1	* N/A * * N/A *

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:52 PM [17]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	---	RO-1-20	CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (NESWP 32 started on lightest loaded Bus.)	Manual	0.0 1178.9	429.0 3236.1 Over 3200	* N/A * * N/A *
- 20 -	ES-1.3-7	---	+35 STOP Motor Driven Auxiliary Feed Pumps: a. RCS pressure is less than SG pressure. (AFWPS - stopped.)	Manual	0.0 3178.9	-575.4 2660.7	* N/A * * N/A *
- 21 -	ES-1.3-8	---	-1 INITIATE Performance of ATTACHMENT 1. Stop any running Charging pumps and PRZR HTRs. (Only pump 31 is running - stopped.)	Manual	-208.5 2970.4	0.0 2660.7	* N/A * * N/A *
- 22 -	WSR 99-3-075	NSE 99-3-075	-13 AS per SECTION 4.2.29 of NSE, One CSP run time is less than 30 minutes. (CSP 31 stopped.)	Manual	-453.6 2516.8	0.0 2660.7	* N/A * * N/A *
- 23 -	ES-1.3-9	---	-24 Align SI Recirc SW 2. b. PLACE SI Recirc SW 2 to ON. (NESWP 31 auto started, CCWP 32 is running.)	Manual	-429.8 2946.6	0.0 2660.7	* N/A * * N/A *
- 24 -	ES-1.3-10	---	+84 Align SI Recirc SW 4 Lo Head as follows: b. Manually start Recirc pump 32. (Bus 6A unavailable to start CRP 32. CRP 31 started.)	Manual	468.3 3414.9 Over 3200	0.0 2660.7	* N/A * * N/A *
- 25 -	ES-1.3-14	---	+18 ALIGN SI Recirc SW 6 Lo Head. (SI SW 6 Lo Head function Light is LIT. All running SI pumps [31 and 33] auto stopped.)	Manual	-472.4 2942.5	-472.4 2188.3	* N/A * * N/A *
- 26 -	ES-1.3-15	---	-121 -122 Can not ALIGN SI Recirc SW 7. Bus 6A is not available. (NESWP 31 and CCWP 31 stopped on heaviest loaded Bus.)	Manual	-723.2 2219.3	0.0 2188.3	* N/A * * N/A *
- 27 -	ES-1.3-24	---	-4 -24 Reset MCCs. (MCCs are already reset.)	Manual	0.0 2219.3	0.0 2188.3	* N/A * * N/A *
(No Loads Started or Tripped at this step)							

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:52 PM [17]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 28 -	ES-1.3-25	---	Start one PAB fan. (PAB fan 31 started.)	Manual	0.0 2219.3	177.0 2365.3	* N/A * * N/A *
- 29 -	ES-1.3-28	---	+87 Shutdown unnecessary equipment. a. Check CCWPs. If 3 are running then stop one b. Check ESWPs. If 3 are running then stop one (One CCWP and two ESWPs are running.) (No Loads Started or Tripped at this step)	Manual	0.0 2219.3	0.0 2365.3	* N/A * * N/A *
- 30 -	---	80-1-27c	START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.)	Manual	0.0 2219.3	63.8 2429.1	* N/A * * N/A *
- 31 -	ES-1.3-35	---	-47 CHECK Containment Hydrogen Concentration: (Hydrogen concentration less than 0.5% by volume.)	Manual	0.0 2219.3	0.0 2429.1	* N/A * * N/A *
- 32 -	ES-1.3-36	---	(No Loads Started or Tripped at this step) *** EXIT TO ES-1.4 *** << 6.5 HOURS ELAPSE PRIOR TO ENTERING ES-1.4-1 >>	Manual	0.0 2219.3	0.0 2429.1	* N/A * * N/A *
- 33 -	ES-1.4-7	---	(No Loads Started or Tripped at this step) *** START HIGH-HEAD RECIRCULATION *** Start SI pump 31. (SI pump 31 started.)	Manual	472.4 2691.7	0.0 2429.1	* N/A * * N/A *
- 34 -	ES-1.4-8	---	+121 Start SI pump 33. (Bus 6A unavailable to start SI pump 33.)	Manual	0.0 2691.7	0.0 2429.1	* N/A * * N/A *
- 35 -	ES-1.4-9	---	(No Loads Started or Tripped at this step) Start SI pump 32 (SI pump 32 started.)	Manual	0.0 2691.7	472.4 2901.5	* N/A * * N/A *
- 36 -	ES-1.4-11	---	+122 *** RETURN TO ES-1.3 Step 37 *** (No Loads Started or Tripped at this step)	Manual	0.0 2691.7	0.0 2901.5	* N/A * * N/A *

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:52 PM [17]

Step Number	SRD Step	RD Step	Loading Step Description	Initiation	Bus 5A	Bus 2A/3A	Bus 6A
					Step Load/Load (A)	Step/Total Load (A)	Step/Total Load (A)
- 37 -	ES-1.3-34	---	Determine if intact SGs should be depressurized to RCS pressure.	Manual	0.0	0.0	* N/A *
			(No Loads Started or Tripped at this step)		2691.7	2901.5	* N/A *
- 38 -	ES-1.3-37	---	Evaluate long term plant status.	Manual	0.0	0.0	* N/A *
			(No Loads Started or Tripped at this step)		2691.7	2901.5	* N/A *

SMALL BREAK LOCA (PH B)



Small Break LOCA (PH B)
 Buses 2A/3A Tied Together, Bus 6A Not Available
 Offsite Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

CCWP 32	2A
CRP 31	5A
ESWP 34	5A
ESWP 35	3A
FCU 31	5A
FCU 32	2A
FCU 33	5A
FCU 34	3A
MCC 34: TURBINE TURNING GEAR	3A
MCC 36A: AUTO	5A
MCC 36C: AUTO	2A
MCC 36E: AUTO	5A
NESWP 32	2A
PAB FAN 31	3A
SI PUMP 31	5A
SI PUMP 32	2A
TOTAL MCCS & LIGHTING RESET BUS 5A	
MCCS RESET (2A/3A) AS PER SOP-EL-15	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

SMALL BREAK LOCA (PH B)

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:52 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 5A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = * N/A * Bus 2A/3A = 2756.5 Bus 6A = 2628.9 (A)

3200 Amp Overload Summary

Bus 5A Not Available
Bus 2A/3A exceeds the 3200 Amp rating at EOP steps : 11, 12, 13, 14
Bus 6A exceeds the 3200 Amp rating at EOP steps : 19

3600 Amp Overload Summary

Bus 5A Not Available
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

SMALL BREAK LOCA (SH B)

Report Date : August 25, 2009 Time : 3:52 PM [18]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/1A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36B, 36C and 36D	Auto	* N/A *	135.5	150.1
					* N/A *	135.5	150.1
- 2 -	---	RO-1-2	+57 +53 +59 SI pumps 32 and 33 RHR pumps 31 and 32 (Pumps are in mini flow due to RCS pressure > 325.) {RO verifies that pumps are running.}	Auto	* N/A *	736.9	738.5
					* N/A *	873.4	888.6
- 3 -	E-0-9	---	+117 +120 +122 +123 CSP 32 {E-0-9 verifies that pump is running.}	Auto	* N/A *	6.0	471.1
					* N/A *	873.4	1359.7
- 4 -	---	RO-1-3	+25 FCUs 32, 34 and 35 {RO verifies that fans are running.}	Auto	* N/A *	493.2	248.0
					* N/A *	1365.6	1607.7
- 5 -	---	RO-1-5	+31 +35 +37 AFWPs 31 and 33 {RO verifies that pumps are running.}	Auto	* N/A *	575.4	562.9
					* N/A *	1941.0	2170.6
- 6 -	---	RO-1-7	+1 +2 CCWPs 32 and 33 {RO verifies that pumps are running.}	Auto	* N/A *	294.4	294.2
					* N/A *	2335.4	2464.8
- 7 -	---	RO-1-8	+7 +10 ESWPs (35 and 36) {RO verifies that pumps are running.}	Auto	* N/A *	429.0	429.8
					* N/A *	2664.4	2894.6
- 8 -	E-0-11	---	+27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {CHARGING pump 32 started on lightest loaded Bus.}	Manual	* N/A *	208.9	0.0
					* N/A *	2873.3	2894.6
- 9 -	< 17 >	---	+14 *** SMALL BREAK LOCA WITH SPRAY *** *** EVENT IDENTIFIED, EXIT TO E-1 *** {No Loads Started or Tripped at this step}	Manual	* N/A *	0.0	0.0
					* N/A *	2873.3	2894.6

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:52 PM [18]

Step Number	SPO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	E-1-4	---	Reset SI (Steps 2 through 12 of RO-1 are completed.)	Manual	* N/A *	0.0	0.0
					* N/A *	2873.3	2894.6
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Full MCC and lighting reset on Bus 6A.)	Manual	* N/A *	407.2	252.3
					* N/A *	3280.5 Over 3200	3146.6
- 12 -	E-1-8	---	-127 -3 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	* N/A *	0.0	0.0
					* N/A *	3280.5 Over 3200	3146.8
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (CHARGING pump 32 is running.)	Manual	* N/A *	0.0	0.0
					* N/A *	3280.5 Over 3200	3146.8
- 14 -	E-1-13	---	(No Loads Started or Tripped at this step) Stop CSPs if 5 FCUs are running or Containment pressure is < 16 psig. (3 FCUs are running and psig > 16. CSPs remain running.)	Manual	* N/A *	0.0	0.0
					* N/A *	3280.5 Over 3200	3146.8
- 15 -	E-1-14	---	(No Loads Started or Tripped at this step) Stop RHR pumps, if RCS pressure is > 325 and pressure is stable or increasing. (Pressure > 325 psig.)	Manual	* N/A *	-264.5	-254.8
					* N/A *	3016.0	2882.0
- 16 -	< 19 >	---	-117 -120 *** ENTER ES-1.3 *** TRANSFER TO COLD LEG RECIRCULATION	Manual	* N/A *	0.0	0.0
					* N/A *	3016.0	2882.0
- 17 -	ES-1.3-5	---	(No Loads Started or Tripped at this step) Stop SI pump 32, if three are running. (Three SI pumps are not running, no pump stopped.) If both CSPs are running then stop one. (Only CSP 32 is running.)	Manual	* N/A *	0.0	0.0
					* N/A *	3016.0	2882.0
- 18 -	ES-1.3-6	---	(No Loads Started or Tripped at this step) CHECK SI Recirc SW 3 Function Complete Light - LIT (YES) (RHR pumps - Auto stopped. Pumps already stopped in E-1) (No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
					* N/A *	3016.0	2882.0

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:52 PM [18]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Scep Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	---	RO-1-20	CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (NESWP 33 started on lightest loaded Bus.)	Manual	* N/A *	0.0	429.8
			+86		* N/A *	3016.0	3311.8
			STOP Motor Driven Auxiliary Feed pumps: a. RCS pressure is less than SG pressure. (AFWPs stopped.)	Manual	* N/A *	-575.4	-562.9
- 20 -	ES-1.3-7	---			* N/A *	2440.6	2748.9
			-1 -2		* N/A *	-208.9	0.0
- 21 -	ES-1.3-8	---	INITIATE Performance of ATTACHMENT 1. Stop any running Charging pumps and PRZR HTRs. (Only pump 32 is running - stopped.)	Manual	* N/A *	2231.7	2748.9
			-14		* N/A *	0.0	-471.1
- 22 -	NSE 99-3-075	NSE 99-3-075	AS PER SECTION 4.2.29 of NSE, One CSP run time is less than 30 minutes. (CSP 32 stopped.)	Manual	* N/A *	2231.7	2277.8
			-25		* N/A *	429.0	0.0
- 23 -	ES-1.3-9	---	Align SI Recirc SW 2. b. PLACE SI Recirc SW 2 to ON (NESWP 32 auto started. CCWP 33 is running.)	Manual	* N/A *	2660.7	2277.8
			+85		* N/A *	0.0	458.3
- 24 -	ES-1.3-10	---	Align SI Recirc SW 4 Lo Head. b. Manually Start 32 Recirc Pump. (CRP 32 started.)	Manual	* N/A *	2660.7	2746.1
			+23		* N/A *	-472.4	-473.7
- 25 -	ES-1.3-14	---	Align SI Recirc SW 6 Lo Head. (SI SW 6 Lo Head function Light is Lit. All running SI pumps [31 and 33] auto stopped)	Manual	* N/A *	2188.3	2272.4
			-122 -123		* N/A *	32.0	-294.2
- 26 -	ES-1.3-15	---	Can not Align SI Recirc SW 7. Bus 5A is not available. (Second CRP can not be started. CCWP 33 stopped.)	Manual	* N/A *	2220.3	1978.2
			+9 -7 -10		* N/A *	0.0	0.0
- 27 -	ES-1.3-24	---	Reset MCCs. (MCCs are already reset.)	Manual	* N/A *	2220.3	1978.2
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA (PH B)

Report Date : August 29, 2009 Time : 3:52 PM [18]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 28 -	ES-1.3-25	---	Start one PAB fan. (PAB fan 32 started on lightest loaded Bus.)	Manual	* N/A *	0.0	177.0
					* N/A *	2220.3	2155.2
- 29 -	ES-1.3-28	---	+88 Shutdown unnecessary equipment. a. Check CCWPs. If 3 are running then stop one. b. Check ESWPs. If 3 are running then stop one. (Only one CCWPs and ESWPs are running.) (No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
					* N/A *	2220.3	2155.2
- 30 -	---	RO-1-27c	START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.)	Manual	* N/A *	63.8	0.0
					* N/A *	2284.1	2155.2
- 31 -	ES-1.3-35	---	+47 CHECK Containment Hydrogen Concentration: (Hydrogen concentration less than 0.5% by volume.)	Manual	* N/A *	0.0	0.0
					* N/A *	2284.1	2155.2
- 32 -	ES-1.3-36	---	(No Loads Started or Tripped at this step) *** EXIT TO ES-1.4 *** << 6.5 HOURS ELAPSE PRIOR TO ENTERING ES-1.4-1 >>	Manual	* N/A *	0.0	0.0
					* N/A *	2284.1	2155.2
- 33 -	ES-1.4-7	---	(No Loads Started or Tripped at this step) *** START HIGH-HEAD RECIRCULATION *** Start SI pump 31. (Bus 5A unavailable to start pump 31.)	Manual	* N/A *	0.0	0.0
					* N/A *	2284.1	2155.2
- 34 -	ES-1.4-8	---	(No Loads Started or Tripped at this step) Start SI pump 33. (SI pump 33 started.)	Manual	* N/A *	0.0	473.7
					* N/A *	2284.1	2628.9
- 35 -	ES-1.4-9	---	+123 Start SI pump 32 if both 31 and 33 are not running. (SI pump 32 started.)	Manual	* N/A *	472.4	0.0
					* N/A *	2756.5	2628.9
- 36 -	ES-1.4-11	---	+122 *** RETURN TO ES-1.3 Step 37 ***	Manual	* N/A *	0.0	0.0
					* N/A *	2756.5	2628.9
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:52 PM (18)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 37 -	ES-1.3-34	---	Determine if intact SGs should be depressurized to RCS pressure.	Manual	* N/A *	0.0	0.0
			(No Loads Started or Tripped at this step)		* N/A *	2756.5	2628.9
- 38 -	ES-1.3-37	---	Evaluate long term plant status.	Manual	* N/A *	0.0	0.0
			(No Loads Started or Tripped at this step)		* N/A *	2756.5	2628.9

SMALL BREAK LOCA (PH B)



Small Break LOCA (PH B)
 Buses 2A/3A Tied Together, Bus 5A Not Available
 Offsite Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

CCWP 32	2A
CRP 32	6A
ESWP 35	3A
ESWP 36	6A
FCU 32	2A
FCU 34	3A
FCU 35	6A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36B: AUTO	6A
MCC 36C: AUTO	2A
MCC 36D: AUTO	6A
NESWP 32	2A
NESWP 33	6A
PAB FAN 32	6A
SI PUMP 32	2A
SI PUMP 33	6A
MCCS RESET (2A/3A) AS PER SOP-EL-15	
TOTAL MCCS & LIGHTING RESET BUS 6A	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES

ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version: 1.1

IP3-CALC-ED-00207 REV 8

SMALL BREAK LOCA (PH B)

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:52 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 2A AND/OR 3A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2653.2 Bus 2A/3A = * N/A * Bus 6A = 2525.3 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A and/or 3A Not Available
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A and/or 3A Not Available
Bus 6A is below the 3600 Amp rating

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:52 PM [19]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36A, 36B, 36D and 36E	Auto	169.5	* N/A *	150.1
					169.5	* N/A *	150.1
- 2 -	---	RO-1-2	+50 +53 +59 +60 SI Pumps 31 and 33 RHR Pump 32 (Pump is in mini flow due to RCS pressure > 325.) {RO verifies that pumps are running.}	Auto	472.4	* N/A *	738.5
					641.9	* N/A *	888.6
- 3 -	E-0-9	---	+120 +121 +123 CSPs 31 and 32 {E-0-9 verifies that pumps are running.}	Auto	453.6	* N/A *	471.1
					1095.5	* N/A *	1359.7
- 4 -	---	RO-1-3	+24 +25 FCUs 31, 33 and 35 {RO verifies that fans are running.}	Auto	491.9	* N/A *	248.0
					1587.4	* N/A *	1607.7
- 5 -	---	RO-1-5	+29 +33 +37 AFWP 33 {RO verifies that pump is running.}	Auto	0.0	* N/A *	562.9
					1587.4	* N/A *	2170.6
- 6 -	---	RO-1-7	+2 CCWPs 31 and 33 {RO verifies that pumps are running.}	Auto	293.4	* N/A *	294.3
					1880.8	* N/A *	2464.8
- 7 -	---	RO-1-8	+5 +11 ESWPs (34 and 36) {RO verifies that pump is running.}	Auto	429.8	* N/A *	429.8
					2310.6	* N/A *	2894.6
- 8 -	E-0-11	---	-26 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {CHARGING pump 31 started on lightest loaded Bus.}	Manual	208.5	* N/A *	0.0
					2519.1	* N/A *	2894.6
- 9 -	< 17 >	---	+13 *** SMALL BREAK LOCA WITH SPRAY *** ___*** EVENT IDENTIFIED, EXIT TO E-1 ***___	Manual	0.0	* N/A *	0.0
					2519.1	* N/A *	2894.6
			{No Loads Started or Tripped at this step}				

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:52 PM 1191

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	E-1-4	---	Reset SI (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0	* N/A *	0.0
					2519.1	* N/A *	2894.6
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Full MCC and lighting reset.)	Manual	659.8	* N/A *	252.2
					3178.9	* N/A *	3146.8
- 12 -	E-1-8	---	+126 +127 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	* N/A *	0.0
					3178.9	* N/A *	3146.8
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	* N/A *	0.0
					3178.9	* N/A *	3146.8
- 14 -	E-1-13	---	(No Loads Started or Tripped at this step) Stop CSPs if 5 FCUs are running or Containment pressure is < 16 psig. (3 FCUs are running, CSPs remain running.)	Manual	0.0	* N/A *	0.0
					3178.9	* N/A *	3146.8
- 15 -	E-1-14	---	(No Loads Started or Tripped at this step) Stop RHR pumps, if RCS pressure is > 325 and pressure is stable or increasing. (Pressure > 325 psig.)	Manual	0.0	* N/A *	-264.6
					3178.9	* N/A *	2882.0
- 16 -	< 19 >	---	-120 *** ENTER ES-1.3 *** TRANSFER TO COLD LEG RECIRCULATION	Manual	0.0	* N/A *	0.0
					3178.9	* N/A *	2882.0
- 17 -	ES-1.3-5	---	(No Loads Started or Tripped at this step) CHECK SI Recirc SW 1 Function Complete Light - LIT (YES) (Two SI pumps are running, CSP 32 stopped.)	Manual	0.0	* N/A *	-471.1
					3178.9	* N/A *	2410.9
- 18 -	ES-1.3-6	---	-2E CHECK SI Recirc SW 1 Function Complete Light - LIT (YES) (RHR pumps - Auto stopped. Pumps [32] stopped in E-1.) (No Loads Started or Tripped at this step)	Manual	0.0	* N/A *	0.0
					3178.9	* N/A *	2410.9

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:52 PM [19]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	---	RG-1-20	CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (NESWP 33 started on lightest loaded Bus.)	Manual	0.0 3178.9	* N/A * * N/A *	429.8 2840.7
- 20 -	ES-1.3-7	---	+86 STOP Motor Driven Auxiliary Feed Pumps: a. RCS pressure is less than SG pressure. (AFWPs - stopped.)	Manual	0.0 3178.9	* N/A * * N/A *	-562.9 2277.8
- 21 -	ES-1.3-8	---	-2 Initiate Performance of ATTACHMENT 1 Stop any running Charging pumps and PRZR HTRs. (Only pump 31 is running - stopped.)	Manual	-208.5 2970.4	* N/A * * N/A *	0.0 2277.8
- 22 -	NSE 99-3-075	NSE 99-3-075	-13. AS PER SECTION 4.2.29 of NSE, One CSP run time is less than 30 minutes. (CSP 31 stopped.)	Manual	-453.6 2516.8	* N/A * * N/A *	0.0 2277.8
- 23 -	ES-1.3-9	---	-24 Align SI Recirc SW 2. b. PLACE SI Recirc SW to ON (NESWP 31 auto started, CCWP 33 is running.)	Manual	429.8 2946.6	* N/A * * N/A *	0.0 2277.8
- 24 -	ES-1.3-10	---	+84 ALIGN SI Recirc SW 4 Lo Head. b. Manually START 32 Recirc Pump. (CRP 32 started.)	Manual	0.0 2946.6	* N/A * * N/A *	468.3 2746.1
- 25 -	ES-1.3-14	---	+23 ALIGN SI Recirc SW 6 Lo Head. (SI SW 6 Lo Head function Light is Lit. All running SI pumps auto stopped.)	Manual	-472.4 2474.2	* N/A * * N/A *	-473.7 2272.4
- 26 -	ES-1.3-15	---	-121 -123 Can not ALIGN SI Recirc SW 7. Bus 2A/3A is not available. (CCWP 31 and NESWP 33 stopped.)	Manual	-293.4 2180.8	* N/A * * N/A *	-397.8 1874.6
- 27 -	ES-1.3-24	---	+12 -86 -5 -11 Reset MCCs. (MCCs are already stopped.)	Manual	0.0 2180.8	* N/A * * N/A *	0.0 1874.6
(No Loads Started or Tripped at this step)							

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 2:52 PM [19]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 28 -	ES-1.3-25	---	Start one PAB fan. (PAB fan 32 started.)	Manual	0.0	* N/A *	177.0
					2180.8	* N/A *	2051.6
- 29 -	ES-1.3-26	---	+86 Shutdown unnecessary equipment. a. Check CCWPs. If 3 are running then stop one. b. Check ESWPs. If 3 are running then stop one. (Only one CCWP and two ESSPs are running.) (No Loads Started or Tripped at this step)	Manual	0.0	* N/A *	0.0
					2180.8	* N/A *	2051.6
- 30 -	---	RO-1-27c	START AC and STOP DC Oil Pumps IF 480V Buses powered from Offsite and tie-breakers are open. Start Turbine turning gear (Bus 2A/3A unavailable to start gear) (No Loads Started or Tripped at this step)	Manual	0.0	* N/A *	0.0
					2180.8	* N/A *	2051.6
- 31 -	ES-1.3-35	---	CHECK Containment Hydrogen Concentration: (Hydrogen concentration less than 0.5% by volume.)	Manual	0.0	* N/A *	0.0
					2180.8	* N/A *	2051.6
- 32 -	ES-1.3-36	---	(No Loads Started or Tripped at this step) *** EXIT TO ES-1.4 *** << 6.5 HOURS ELAPSE PRIOR TO ENTERING ES-1.4-1 >>	Manual	0.0	* N/A *	0.0
					2180.8	* N/A *	2051.6
- 33 -	ES-1.4-7	---	(No Loads Started or Tripped at this step) *** START HIGH-HEAD RECIRCULATION *** Start SI pump 31. (SI pump 31 started.)	Manual	472.4	* N/A *	0.0
					2653.2	* N/A *	2051.6
- 34 -	ES-1.4-8	---	+121 Start SI pump 33. (SI pump 33 started.)	Manual	0.0	* N/A *	473.7
					2653.2	* N/A *	2525.3
- 35 -	ES-1.4-11	---	+123 *** RETURN TO ES-1.3 Step 37 ***	Manual	0.0	* N/A *	0.0
					2653.2	* N/A *	2525.3
- 36 -	ES-1.3-34	---	(No Loads Started or Tripped at this step) Determine if intact SGs should be depressurized to RCS pressure.	Manual	0.0	* N/A *	0.0
					2653.2	* N/A *	2525.3
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:52 PM [19]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A	Bus 2A/3A	Bus 6A
					Step Load/ Load (A)	Step/Total Load (A)	Step/Total Load (A)
- 37 -	ES-1.3-37	---	Evaluate long term plant status..	Manual	0.0	* N/A *	0.0
			(No Loads Started or Tripped at this step)		2653.2	* N/A *	2625.3

SMALL BREAK LOCA (PH B)



Small Break LOCA (PH B)
 Buses 2A and / or 3A Not Available
 Offsite Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

CCWP 33	6A
CRP 32	6A
ESWP 34	5A
ESWP 36	6A
FCU 31	5A
FCU 33	5A
FCU 35	6A
MCC 36A: AUTO	5A
MCC 36B: AUTO	6A
MCC 36D: AUTO	6A
MCC 36E: AUTO	5A
NESWP 31	5A
PAB FAN 32	6A
SI PUMP 31	5A
SI PUMP 33	6A
TOTAL MCCS & LIGHTING RESET BUS 5A	5A
TOTAL MCCS & LIGHTING RESET BUS 6A	6A

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

SMALL BREAK LOCA (PH B)

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:55 PM

*** BUSES 2A AND 3A TIED TOGETHER ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = 1368.1 Bus 2A/3A = 1216.8 Bus 6A = 1480.9 (kW)

1750 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1750 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1750 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1750 kW rating

1950 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1950 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1950 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:35 PM [51]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36A, 36B, 36C, 36D and 36E	Auto	110.0 110.0	94.3 94.3	100.4 100.4
- 2 -	---	RO-1-2	-57 +50 +53 +59 +60 SI pumps 31, 32 and 33 RHR Pumps 31 and 32 (Pumps are in mini flow due to RCS pressure > 325.) (RO verifies that pumps are running.)	Auto	327.2 437.2	509.2 603.5	509.2 609.6
- 3 -	E-0-9	---	+117 +120 +121 +122 +123 CSPs 31 and 32 (E-0-9 verifies that pumps are running.)	Auto	307.3 744.5	0.0 603.5	319.5 929.1
- 4 -	---	RO-1-3	+24 +25 FCUs 31, 32, 33, 34 and 35 (RO verifies that fans are running.)	Auto	258.0 1002.5	258.0 861.5	129.0 1058.1
- 5 -	---	RO-1-5	+29 +31 +33 +35 +37 APWPs 31 and 33 (RO verifies that pumps are running.)	Auto	0.0 1002.5	378.9 1240.4	375.7 1433.8
- 6 -	---	RO-1-7	+1 +2 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. (All Buses are powered from EDGs.)	Auto	0.0 1002.5	0.0 1240.4	0.0 1433.8
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESWPs (34, 35 and 36) (RO verifies that pumps are running.)	Auto	280.8 1283.3	280.8 1521.2	280.8 1714.6
- 8 -	E-0-11	---	+26 +27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	140.2 1423.5	0.0 1521.2	0.0 1714.6
- 9 -	< 17 >	---	+13 *** SMALL BREAK LOCA WITH SPRAY *** *** EVENT IDENTIFIED. EXIT TO E-1 *** (No Loads Started or Tripped at this step)	Manual	0.0 1423.5	0.0 1521.2	0.0 1714.6

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:55 PM [51]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	E-1-4	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0 1423.5	0.0 1521.2	0.0 1714.6
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15 (MCCs are reset.)	Manual	85.8 1509.3	63.3 1584.5	24.8 1739.4
- 12 -	E-1-8	---	+82 +81 +83 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0 1509.3	0.0 1584.5	0.0 1739.4
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start CHARGING one pump (CHARGING pump 31 is running.)	Manual	0.0 1509.3	0.0 1584.5	0.0 1739.4
- 14 -	E-1-13	---	(No Loads Started or Tripped at this step) Stop CSPs if 5 FCUs are running or Containment pressure is < 16 psig. (5 FCUs are running, CSPs stopped.)	Manual	-307.3 1202.0	0.0 1584.5	-319.5 1419.9
- 15 -	E-1-14	---	-24 -25 Stop RHR pumps if pressure is > 325 and pressure is stable or increasing. (Pressure > 325 psig)	Manual	0.0 1202.0	-182.0 1402.5	-182.0 1237.9
- 16 -	< 19 >	---	-117 -120 *** ENTER ES-1.3 *** TRANSFER TO COLD LEG RECIRCULATION	Manual	0.0 1202.0	0.0 1402.5	0.0 1337.9
- 17 -	ES-1.3-5	---	(No Loads Started or Tripped at this step) CHECK SI Recirc SW 1 Function Complete Light - LIT. (YES) (SI pump 32 - Auto stopped. CSPs stopped in E-1.)	Manual	0.0 1202.0	-227.2 1075.3	0.0 1237.9
- 18 -	ES-1.3-6	---	-122 CHECK SI Recirc SW 3 Function Complete Light - LIT. (YES) (RHR pumps 31 and 32 - Auto stopped.) (No Loads Started or Tripped at this step)	Manual	0.0 1202.0	0.0 1075.3	0.0 1237.9

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:55 PM (51)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A	Bus 2A/3A	Bus 6A
					Step Load/ Load (kW)	Step/Total Load (kW)	Step/Total Load (kW)
- 19 -	---	RO-1-20	CHECK if OFFsite power is available to a 480V Bus to start at least one NESWP. (All Buses are powered from EDGs.)	Manual	0.0	0.0	0.0
					1202.0	1075.3	1237.9
- 20 -	ES-1.3-7	---	(No Loads Started or Tripped at this step) STOP Motor Driven Auxiliary Feed Pumps: a. RCS pressure is less than SG pressures. (AFWPs - stopped.)	Manual	0.0	-378.9	-375.7
					1202.0	696.4	862.2
- 21 -	ES-1.3-8	---	-1 -2 INITIATE Performance of ATTACHMENT 1. Stop Any Running Charging Pumps. (Only Charging pump 31 is running - stopped.) Place all PRZR HTRs to off. (No HTRs are on.)	Manual	-140.2	0.0	0.0
					1061.8	696.4	862.2
- 22 -	NSE 99-3-075	NSE 99-3-075	-13 AS PER section 4.2.20 of NSE One CSP run time is less than 30 minutes. (No CSPs are running.)	Manual	0.0	0.0	0.0
					1061.8	696.4	862.2
- 23 -	ES-1.3-9	---	(No Loads Started or Tripped at this step) Align SI Recirc SW 2. b. PLACE SI Recirc SW 2 to ON. (NESWP 31 and CCWP 33 Auto started.)	Manual	280.8	0.0	219.6
					1342.6	696.4	1081.8
- 24 -	ES-1.3-10	---	+34 +12 ALIGN SI Recirc SW 4 Lo Head. b. Manually START 32 Recirc Pump. (CRP 32 started.)	Manual	0.0	0.0	306.3
					1342.6	696.4	1388.1
- 25 -	ES-1.3-14	---	+23 ALIGN SI Recirc SW 6 Lo Head. (SI SW 6 Lo Head function Light is LIT. All running SI pumps (31 and 33) auto stopped.)	Manual	-327.2	0.0	-327.2
					1015.4	696.4	1060.9
- 26 -	ES-1.3-15	---	-121 -123 ALIGN SI Recirc SW 7. d. PLACE SI Recirc SW 7 to ON. (CCWP 32, NESWP 32 and CRP 31 Auto started.)	Manual	306.3	478.9	-21.5
					1321.7	1175.3	1039.4
- 27 -	ES-1.3-24	---	+85 +8 +11 +18 -12 Reset MCCs via SOP-EL-15. (MCCs are already reset.)	Manual	0.0	0.0	0.0
					1321.7	1175.3	1039.4
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:55 PM (51)


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 28 -	ES-1.3-25	---	CHECK PAB Exhaust Fan Status: (No PAB fan is running.) (PAB fan 32 started on lightest loaded Bus.)	Manual	0.0 1321.7	0.0 1175.3	114.3 1153.7
- 29 -	ES-1.3-29	---	-38 Shutdown Unnecessary Plant Equipment: a. Check CCWPs, if 3 are running then stop one b. Check ESWPs, if 3 are running then stop one (ESWP 34 stopped on heaviest loaded Bus.)	Manual	-388.8 1040.9	0.0 1175.3	0.0 1153.7
- 30 -	---	RO-1-27c	-36 START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite Power. (All Buses are powered from EDGs.) Start Turb Turning Gear. (Turning Gear started.)	Manual	0.0 1040.9	41.5 1216.8	0.0 1153.7
- 31 -	ES-1.3-35	---	+47 CHECK Containment Hydrogen Concentration: (Hydrogen concentration less than 0.5% by volume.)	Manual	0.0 1040.9	0.0 1216.8	0.0 1153.7
- 32 -	ES-1.3-36	---	(No Loads Started or Tripped at this step) *** EXIT TO ES-1.4 *** << 6.5 HOURS ELAPSE PRIOR TO ENTERING ES-1.4-1 >>	Manual	0.0 1040.9	0.0 1216.8	0.0 1153.7
- 33 -	ES-1.4-7	---	(No Loads Started or Tripped at this step) *** START HIGH-HEAD RECIRCULATION *** Start SI pump 31. (SI pump 31 started.)	Manual	327.2 1368.1	0.0 1216.8	0.0 1153.7
- 34 -	ES-1.4-8	---	-121 Start SI pump 33. (SI pump 33 started.)	Manual	0.0 1368.1	0.0 1216.8	327.2 1480.9
- 35 -	ES-1.4-11	---	-123 *** RETURN TO ES-1.3 Step 37 ***	Manual	0.0 1368.1	0.0 1216.8	0.0 1480.9
- 36 -	ES-1.3-34	---	(No Loads Started or Tripped at this step) Determine if intact SGs should be depressurized to RCS pressure.	Manual	0.0 1368.1	0.0 1216.8	0.0 1480.9
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:55 PM [51]

Step Number	SPO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 37 -	ES-1.3-37	---	Evaluate long term plant status.	Manual	0.0	0.0	0.0
			(No Loads Started or Tripped at this step)		1368.1	1216.8	1486.9

SMALL BREAK LOCA (PH B)



Small Break LOCA (PH B)
 Buses 2A/3A Tied Together, All Busses Available
 Loss of Off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

CCWP 32	EDG 31
CCWP 33	EDG 32
CRP 32	EDG 32
ESWP 35	EDG 31
ESWP 36	EDG 32
FCU 31	EDG 33
FCU 32	EDG 31
FCU 33	EDG 33
FCU 34	EDG 31
FCU 35	EDG 32
MCC 34: TURBINE TURNING GEAR	EDG 31
MCC 36A: AUTO	EDG 33
MCC 36B: AUTO	EDG 32
MCC 36C: AUTO	EDG 31
MCC 36D: AUTO	EDG 32
MCC 36E: AUTO	EDG 33
MCCS RESET (2A/3A) AS PER SOP-EL-15	EDG 31
MCCS RESET (5A) AS PER SOP-EL-15	EDG 33
MCCS RESET (6A) AS PER SOP-EL-15	EDG 32
NESWP 31	EDG 33
NESWP 32	EDG 31
PAB FAN 32	EDG 32
SI PUMP 31	EDG 33
SI PUMP 33	EDG 32

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES

ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

SMALL BREAK LOCA (PH B)

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:55 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 6A NOT AVAILABLE ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = 1648.9 Bus 2A/3A = 1399.0 Bus 6A = * N/A * (kW)

1750 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1750 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1750 kW rating
Bus 6A Not Available

1950 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1950 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1950 kW rating
Bus 6A Not Available

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:55 PM [92]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36A, 36C, and 36E	Auto	110.0	94.3	* N/A *
					110.0	94.3	* N/A *
- 2 -	---	RO-1-2	+57 +50 +60 SI pumps 31, and 32 RHR Pump 31 (Pumps are in mini flow due to RCS pressure > 325.) (RO verifies that pumps are running.)	Auto	327.2	509.2	* N/A *
					437.2	603.5	* N/A *
- 3 -	E-0-9	---	+117 +121 +122 CSPs 31 (E-0-9 verifies that pumps are running.)	Auto	307.3	0.0	* N/A *
					744.5	603.5	* N/A *
- 4 -	---	RO-1-3	-24 FCUs 31, 32, 33, and 34 (RO verifies that fans are running.)	Auto	258.0	258.0	* N/A *
					1002.5	861.5	* N/A *
- 5 -	---	RO-1-5	+29 +31 +33 +35 AFWPs 31 (RO verifies that pumps are running.)	Auto	0.0	378.9	* N/A *
					1002.5	1240.4	* N/A *
- 6 -	---	RO-1-7	+1 CHECK if Offsite power is available to a 480V Bus. to start at least one CCWP. (All Buses are powered from EDGs.)	Manual	0.0	0.0	* N/A *
					1002.5	1240.4	* N/A *
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESWPs (34 and 35) (RO verifies that pumps are running.)	Auto	280.8	280.8	* N/A *
					1283.3	1521.2	* N/A *
- 8 -	E-0-11	---	+26 +27 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	140.2	0.0	* N/A *
					1423.5	1521.2	* N/A *
- 9 -	< 17 >	---	+13 *** SMALL BREAK LOCA WITH SPRAY *** *** EVENT IDENTIFIED, EXIT TO E-1 ***	Manual	0.0	0.0	* N/A *
					1423.5	1521.2	* N/A *
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:55 PM [52]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	E-1-4	---	Reset S1. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0 1423.5	0.0 1521.2	* N/A * * N/A *
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15 (MCCs are reset.)	Manual	85.8 1509.3	63.3 1584.5	* N/A * * N/A *
- 12 -	E-1-8	---	+82 +81 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0 1509.3	0.0 1584.5	* N/A * * N/A *
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start CHARGING one pump. (CHARGING pump 31 is running.)	Manual	0.0 1509.3	0.0 1584.5	* N/A * * N/A *
- 14 -	E-1-13	---	(No Loads Started or Tripped at this step) Stop CSPs if 5 FCUs are running or Containment pressure is < 16 psig. (4 FCUs are running and psig > 16 CSP 31 remains running.)	Manual	0.0 1509.3	0.0 1584.5	* N/A * * N/A *
- 15 -	E-1-14	---	(No Loads Started or Tripped at this step) Stop RHR pumps if pressure is > 325 and pressure is stable or increasing. (Pressure > 325 psig)	Manual	0.0 1509.3	-182.0 1402.5	* N/A * * N/A *
- 16 -	< 19 >	---	-117 *** ENTER ES-1.3 *** TRANSFER TO COLD LEG RECIRCULATION	Manual	0.0 1509.3	0.0 1402.5	* N/A * * N/A *
- 17 -	ES-1.3-5	---	(No Loads Started or Tripped at this step) CHECK SI Recirc SW 1 Function Complete Light - LIT. (YES) (Only two SI pumps and one CSP are running. CSP 31 remains running.)	Manual	0.0 1509.3	0.0 1402.5	* N/A * * N/A *
- 18 -	ES-1.3-6	---	(No Loads Started or Tripped at this step) CHECK SI Recirc SW 3 Function Complete Light - LIT. (YES) (RHR pumps 31 and 32 - Auto stopped.) (No Loads Started or Tripped at this step)	Manual	0.0 1509.3	0.0 1402.5	* N/A * * N/A *

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:55 PM [52]

Step Number	SFO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	---	RO-1-20	CHECK if Offsite power is available to a 480V Bus to start at least one NERSWP. (All Buses are powered from EDCs.)	Manual	0.0	0.0	* N/A *
					1509.3	1402.5	* N/A *
- 20 -	ES-1.3-7	---	(No Loads Started or Tripped at this step) STOP Motor Driven Auxiliary Feed Pumps: a. RCS pressure is less than SG pressures. (AFWPs - stopped.)	Manual	0.0	-378.9	* N/A *
					1509.3	1023.6	* N/A *
- 21 -	ES-1.3-8	---	-1 INITIATE Performance of ATTACHMENT 1. Stop Any Running Charging Pumps. (Only Charging pump 31 is running - stopped.) Place all PRZR HTRs to off. (No HTRs are on.)	Manual	-140.2	0.0	* N/A *
					1369.1	1023.6	* N/A *
- 22 -	NSE 99-3-075	NSE-99-3-075	-13 AS PER SECTION 4.2.20 of MSE One CSP run time is less than 30 minutes. (CSP 31 stopped.)	Manual	-307.3	0.0	* N/A *
					1061.8	1023.6	* N/A *
- 23 -	ES-1.3-9	---	-24 Align SI Recirc SW 2. b. PLACE SI Recirc SW 2 to ON. (NERSWP 31 and CCWP 32 Auto started.)	Manual	280.8	219.6	* N/A *
					1342.6	1243.2	* N/A *
- 24 -	ES-1.3-10	---	+84 +9 ALIGN SI Recirc SW 4 Lo Head. b. Manually START 32 Recirc Pump. (Bus 6A unavailable to start CRP 32. CRP 31 started.)	Manual	306.3	0.0	* N/A *
					1648.9	1243.2	* N/A *
- 25 -	ES-1.3-14	---	+18 ALIGN SI Recirc SW 6 Lo Head. (SI SW 5 Lo Head function Light is LIT. All running SI pumps [31 and 32] auto stopped.)	Manual	-327.2	-327.2	* N/A *
					1321.7	916.0	* N/A *
- 26 -	ES-1.3-16	---	-121 -122 Can not ALIGN SI Recirc sw 7. Bus 6A is not available. (CRP 31 is running.)	Manual	0.0	0.0	* N/A *
					1321.7	916.0	* N/A *
- 27 -	ES-1.3-24	---	(No Loads Started or Tripped at this step) Reset MCCs via SOP-EL-15. (MCCs are already reset.)	Manual	0.0	0.0	* N/A *
					1321.7	916.0	* N/A *
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:55 PM [52]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 28 -	ES-1.3-25	---	CHECK PAB Exhaust Fan Status: (No PAB fan is running.) (PAB fan 31 started.)	Manual	0.0 1321.7	114.3 1030.3	* N/A * * N/A *
- 29 -	ES-1.3-28	---	+87 Shutdown Unnecessary Plant Equipment: a. Check CCWPs. if 3 are running then stop one b. Check ESWPs. if 3 are running then stop one (Only CCWP 32 and two ESWPs are running.) (No Loads Started or Tripped at this step)	Manual	0.0 1321.7	0.0 1030.3	* N/A * * N/A *
- 30 -	---	RO-1-27c	START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite Power. (All Buses are powered from EDGs.) Start Turb Turning Gear. (Gear started.) +4)	Manual	0.0 1321.7	41.5 1071.8	* N/A * * N/A *
- 31 -	ES-1.3-35	---	CHECK Containment Hydrogen Concentration: (Hydrogen concentration less than 0.5% by volume.)	Manual	0.0 1321.7	0.0 1071.8	* N/A * * N/A *
- 32 -	ES-1.3-36	---	(No Loads Started or Tripped at this step) *** EXIT TO ES-1.4 *** << 6.5 HOURS ELAPSE PRIOR TO ENTERING ES-1.4-1 >>	Manual	0.0 1321.7	0.0 1071.8	* N/A * * N/A *
- 33 -	ES-1.4-7	---	(No Loads Started or Tripped at this step) *** START HIGH-HEAD RECIRCULATION *** Start SI pump 31. (SI pump 31 started.)	Manual	327.2 1648.9	0.0 1071.9	* N/A * * N/A *
- 34 -	ES-1.4-8	---	+121 Start SI pump 33. (Bus 6A unavailable to start SI pump 33.)	Manual	0.0 1648.9	0.0 1071.8	* N/A * * N/A *
- 35 -	ES-1.4-9	---	(No Loads Started or Tripped at this step) Start SI pump 32. (SI pump 32 started.)	Manual	0.0 1648.9	327.2 1399.0	* N/A * * N/A *
- 36 -	ES-1.4-11	---	+122 *** RETURN TO ES-1.3 Step 37 *** (No Loads Started or Tripped at this step)	Manual	0.0 1648.9	0.0 1399.0	* N/A * * N/A *

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:55 PM [52]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A	Bus 2A/3A	Bus 6A
					Step Load/ Load (kW)	Step/Total Load (kW)	Step/Total Load (kW)
- 37 -	ES-1.3-34	---	Determine if intact SGs should be depressurized to RCS pressure.	Manual	0.0	0.0	* N/A *
					1648.9	1399.0	* N/A *
- 38 -	ES-1.3-37	---	(No Loads Started or Tripped at this step) Evaluate long term plant status.	Manual	0.0	0.0	* N/A *
					1648.9	1399.0	* N/A *
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA (PH B)



Small Break LOCA (PH B)
 Buses 2A/3A Tied Together, Bus 6A Not Available
 Loss of Off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING

CCWP 32
 CRP 31
 ESWP 34
 ESWP 35
 FCU 31
 FCU 32
 FCU 33
 FCU 34
 MCC 34: TURBINE TURNING GEAR
 MCC 36A: AUTO
 MCC 36C: AUTO
 MCC 36E: AUTO
 MCCS RESET (2A/3A) AS PER SOP-EL-15
 MCCS RESET (5A) AS PER SOP-EL-15
 NESWP 31
 PAB FAN 31
 SI PUMP 31
 SI PUMP 32

POWER FROM EDG

EDG 31
 EDG 33
 EDG 33
 EDG 31
 EDG 33
 EDG 31
 EDG 33
 EDG 33
 EDG 31
 EDG 31
 EDG 33
 EDG 31
 EDG 33
 EDG 31
 EDG 33
 EDG 31
 EDG 33
 EDG 31
 EDG 33
 EDG 31



NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES

ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00267 REV B

SMALL BREAK LOCA (PH B)

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:55 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 5A NOT AVAILABLE ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = * N/A * Bus 2A/3A = 1460.2 Bus 6A = 1388.1 (kW)

1750 kW Overload Summary

Bus 5A Not Available

Emergency Diesel Generator 31 on Bus 2A/3A is below the 1750 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1750 kW rating

1950 kW Overload Summary

Bus 5A Not Available

Emergency Diesel Generator 31 on Bus 2A/3A is below the 1950 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating

SMALL BREAK LOCA (PH B)

Report Date : August 28, 2009 Time : 3:55 PM [53]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36B, 36C and 36D	Auto	* N/A *	94.3	100.4
					* N/A *	94.3	100.4
- 2 -	---	RO-1-2	+57 +58 +59 SI pumps 32 and 33 RHR Pumps 31 and 32 (Pumps are in mini Flow due to RCS pressure > 325.) {RO verifies that pumps are running.}	Auto	* N/A *	509.2	509.2
					* N/A *	603.5	609.6
- 3 -	E-0-9	---	-117 +120 +122 +123 CSP 32 {E-0-9 verifies that pumps are running.}	Auto	* N/A *	0.0	319.5
					* N/A *	603.5	929.1
- 4 -	---	RO-1-3	+25 FCUs 32, 34 and 35 {RO verifies that fans are running.}	Auto	* N/A *	258.0	129.0
					* N/A *	861.5	1058.1
- 5 -	---	RO-1-5	+31 +35 +37 AFWPs 31 and 33 {RO verifies that pumps are running.}	Auto	* N/A *	378.9	375.7
					* N/A *	1240.4	1433.8
- 6 -	---	RO-1-7	+1 +2 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. {All Buses are powered from EDGs.}	Manual	* N/A *	0.0	0.0
					* N/A *	1240.4	1433.8
- 7 -	---	RO-1-8	{No Loads Started or Tripped at this step} ESWPs (35 and 36) {RO verifies that pumps are running.}	Auto	* N/A *	280.8	280.8
					* N/A *	1521.2	1714.6
- 8 -	E-0-11	---	+27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {CHARGING pump 32 started on lightest loaded Bus.}	Manual	* N/A *	140.2	0.0
					* N/A *	1661.4	1714.6
- 9 -	< 17 >	---	+14 *** SMALL BREAK LOCA WITH SPRAY *** *** EVENT IDENTIFIED, EXIT TO E-1 *** {No Loads Started or Tripped at this step}	Manual	* N/A *	0.0	0.0
					* N/A *	1661.4	1714.6

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:55 PM [53]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	E-1-4	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	* N/A *	0.0	0.0
					* N/A *	1661.4	1714.6
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (MCC are reset.)	Manual	* N/A *	63.3	24.8
					* N/A *	1724.7	1739.4
- 12 -	E-1-8	---	+81 -83 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	* N/A *	0.0	0.0
					* N/A *	1724.7	1739.4
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start CHARGING one pump. (CHARGING pump 32 is running.)	Manual	* N/A *	0.0	0.0
					* N/A *	1724.7	1739.4
- 14 -	E-1-13	---	(No Loads Started or Tripped at this step) Stop CSPs if 5 FCUs are running or Containment pressure is < 16 psig. (3 FCUs are running and psig > 16. CSP remains running.)	Manual	* N/A *	0.0	0.0
					* N/A *	1724.7	1739.4
- 15 -	E-1-14	---	(No Loads Started or Tripped at this step) Stop RHR pumps if pressure is > 325 and pressure is stable or increasing. (Pressure > 325 psig)	Manual	* N/A *	-182.0	-182.0
					* N/A *	1542.7	1557.4
- 16 -	< 19 >	---	-117 -120 *** ENTER ES-1.3 *** TRANSFER TO COLD LEG RECIRCULATION	Manual	* N/A *	0.0	0.0
					* N/A *	1542.7	1557.4
- 17 -	ES-1.3-5	---	(No Loads Started or Tripped at this step) CHECK SI Recirc SW 1 Function Complete Light - LIT. (YES) (Only two SI pumps and one CSP are running. CSP 32 remains running.)	Manual	* N/A *	0.0	0.0
					* N/A *	1542.7	1557.4
- 18 -	ES-1.3-6	---	(No Loads Started or Tripped at this step) CHECK SI Recirc SW 3 Function Complete Light - LIT. (YES) (RHR pumps 31 and 32 - Auto stopped.)	Manual	* N/A *	0.0	0.0
					* N/A *	1542.7	1557.4
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:55 PM [53]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	---	RO-1-20	CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (All Buses are powered from EDGs.)	Manual	* N/A *	0.0	0.0
- 20 -	ES-1.3-7	---	(No Loads Started or Tripped at this step) STOP Motor Driven Auxilliary Feed Pumps: a. RCS pressure is less than SG pressures. (AFWPs - stopped.)	Manual	* N/A *	1542.7	1557.4
- 21 -	ES-1.3-8	---	-1 -2 INITIATE Performance of ATTACHMENT 1. Stop Any Running Charging Pumps. (Only Charging pump 32 is running - stopped.) Place all PRZR NTRs to off. (No NTRs are on.)	Manual	* N/A *	-378.9	-375.7
- 22 -	NSE 99-3-075	NSE 99-3-075	-14 AS PER SECTION 4.2.20 of NSE, One CSP run time is less than 30 minutes. (CSP 32 stopped.)	Manual	* N/A *	1163.8	1181.7
- 23 -	ES-1.3-9	---	-25 Align SI Recirc SW 2. b. PLACE SI Recirc SW 2 to ON. (NESWP 32 and CCWP 33 Auto started.)	Manual	* N/A *	-140.2	0.0
- 24 -	ES-1.3-10	---	-35 +12 ALIGN SI Recirc SW 4 Lo Head. b. Manually START 32 Recirc Pump. (CRP 32 started.)	Manual	* N/A *	1023.6	1181.7
- 25 -	ES-1.3-14	---	-23 ALIGN SI Recirc SW 6 Lo Head. (SI SW 6 Lo Head function Light is LIT. All running SI pumps (32 and 33) auto stopped.)	Manual	* N/A *	0.0	-319.5
- 26 -	ES-1.3-15	---	-122 -123 Can not Align Recirc SW 7. Bus 5A is not available. (Second CRP can not be started.)	Manual	* N/A *	1023.6	862.2
- 27 -	ES-1.3-24	---	(No Loads Started or Tripped at this step) Reset MCCs. (MCC already reset.)	Manual	* N/A *	280.8	219.6
			(No Loads Started or Tripped at this step)		* N/A *	1304.4	1081.6
					* N/A *	0.0	306.3
					* N/A *	1304.4	1388.1
					* N/A *	-327.2	-327.2
					* N/A *	977.2	1060.9
					* N/A *	0.0	0.0
					* N/A *	977.2	1060.9
					* N/A *	0.0	0.0
					* N/A *	977.2	1060.9

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:55 PM [53]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 28 -	ES-1.3-25	---	CHECK PAB Exhaust Fan Status: (No PAB fan is running.) (PAB fan 31 started on lightest loaded Bus.)	Manual	* N/A *	114.3	0.0
- 29 -	ES-1.3-28	---	+87 Shutdown Unnecessary Plant Equipment: a. Check CCWPs. if 3 are running then stop one b. Check ESWPs. if 3 are running then stop one (Only one CCWP [33] and two ESWPs are running.) (No Loads Started or Tripped at this step)	Manual	* N/A *	1091.5	1060.9
- 30 -	---	RO-1-27c	START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite Power. (All Buses are powered from EDGs.) Start Turb Turning Gear. (Gear started.)	Manual	* N/A *	41.5	0.0
- 31 -	ES-1.3-35	---	+47 CHECK Containment Hydrogen Concentration: (Hydrogen concentration less than 0.5% by volume.)	Manual	* N/A *	1133.0	1060.9
- 32 -	ES-1.3-36	---	(No Loads Started or Tripped at this step) *** EXIT TO ES-1.4 *** << 6.5 HOURS ELAPSE PRIOR TO ENTERING ES-1.4-1 >>	Manual	* N/A *	1133.0	1060.9
- 33 -	ES-1.4-7	---	(No Loads Started or Tripped at this step) *** START HIGH-HEAD RECIRCULATION *** Start SI pump 31. (Bus 5A unavailable to start pump 31.)	Manual	* N/A *	1133.0	1060.9
- 34 -	ES-1.4-8	---	(No Loads Started or Tripped at this step) Start SI pump 33. (SI pump 33 started.)	Manual	* N/A *	1133.0	327.2
- 35 -	ES-1.4-9	---	+123 Start SI pump 32 (SI pump 32 started.)	Manual	* N/A *	1460.2	1388.1
- 36 -	ES-1.4-11	---	+122 *** RETURN TO ES-1.3 Step 37 *** (No Loads Started or Tripped at this step)	Manual	* N/A *	1460.2	1388.1

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:55 PM [53]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A	Bus 2A/3A	Bus 6A
					Step Load/ Load (kW)	Step/Total Load (kW)	Step/Total Load (kW)
- 37 -	RS-1.3-14	---	Determine if intact SGs should be depressurized to RCS pressure.	Manual	* N/A *	0.0	0.0
			(No Loads Started or Tripped at this step)		* N/A *	1460.2	1388.1
- 38 -	RS-1.3-17	---	Evaluate long term plant status.	Manual	* N/A *	0.0	0.0
			(No Loads Started or Tripped at this step)		* N/A *	1460.2	1388.1

SMALL BREAK LOCA (PH B)



Small Break LOCA (PH B)
 Buses 2A/3A Tied Together, Bus 5A Not Available
 Loss of Off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

CCWP 33	EDG 32
CRP 32	EDG 32
ESWP 35	EDG 31
ESWP 36	EDG 32
FCU 32	EDG 31
FCU 34	EDG 31
FCU 35	EDG 32
MCC 34: TURBINE TURNING GEAR	EDG 31
MCC 36B: AUTO	EDG 32
MCC 36C: AUTO	EDG 31
MCC 36D: AUTO	EDG 32
MCCS RESET (2A/3A) AS PER SOP-EL-15	EDG 31
MCCS RESET (6A) AS PER SOP-EL-15	EDG 32
NESWP 32	EDG 31
PAB FAN 31	EDG 31
SI PUMP 32	EDG 31
SI PUMP 33	EDG 32

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES

ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

SMALL BREAK LOCA (PH B)

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:55 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 2A AND/OR 3A NOT AVAILABLE ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = 1342.6 Bus 2A/3A = * N/A * Bus 6A = 1502.4 (kW)

1750 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1750 kW rating
Bus 2A and/or 3A Not Available
Emergency Diesel Generator 32 on Bus 6A is Below the 1750 kW rating

1950 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1950 kW rating
Bus 2A and/or 3A Not Available
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:55 PM [54]

Step Number	SRU Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36A, 36B, 36D and 36E	Auto	110.0	* N/A *	100.4
					110.0	* N/A *	100.4
- 2 -	---	RO-1-2	+50 +51 +59 +60 SI pumps 31, and 33 RHR Pumps 32 (Pumps are in mini flow due to RCS pressure > 325.) (RO verifies that pumps are running.)	Auto	327.2	* N/A *	509.2
					437.2	* N/A *	609.5
- 3 -	E-0-9	---	+120 +121 +123 CSsPs 31 and 32 (E-0-9 verifies that pumps are running.)	Auto	307.3	* N/A *	319.5
					744.5	* N/A *	929.1
- 4 -	---	RO-1-3	+24 +25 FCUs 31, 33, and 35 (RO verifies that fans are running.)	Auto	258.0	* N/A *	129.0
					1002.5	* N/A *	1058.1
- 5 -	---	RO-1-5	+29 +33 +37 APWPs 33 (RO verifies that pumps are running.)	Auto	0.0	* N/A *	375.7
					1002.5	* N/A *	1433.8
- 6 -	---	RO-1-7	+2 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. (All Buses are powered from EDGs.)	Manual	0.0	* N/A *	0.0
					1002.5	* N/A *	1433.8
- 7 -	---	RO-1-2	(No Loads Started or Tripped at this step) ESWPs (34 and 36) (RO verifies that pumps are running.)	Auto	280.8	* N/A *	280.6
					1283.3	* N/A *	1714.6
- 8 -	E-0-11	---	+26 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	140.2	* N/A *	0.0
					1423.5	* N/A *	1714.6
- 9 -	< 17 >	---	+13 *** SMALL BREAK LOCA WITH SPRAY *** *** EVENT IDENTIFIED, EXIT TO E-1 *** (No Loads Started or Tripped at this step)	Manual	0.0	* N/A *	0.0
					1423.5	* N/A *	1714.6

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:55 PM [54]

Step number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	E-1-4	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0 1423.5	* N/A * * N/A *	0.0 1714.6
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (MCCs are reset.)	Manual	65.8 1509.3	* N/A * * N/A *	24.8 1739.4
- 12 -	ES-1-8	---	+82 +83 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0 1509.3	* N/A * * N/A *	0.0 1739.4
- 13 -	E-1-11	---	(No Loads Started or Tripped at this step) Start CHARGING one pump (CHARGING pump 31 is running.)	Manual	0.0 1509.3	* N/A * * N/A *	0.0 1739.4
- 14 -	E-1-13	---	(No Loads Started or Tripped at this step) Stop CSPs if 5 FCUs are running or Containment pressure is < 16 psig. (3 FCUs are running, CSPs remain running.)	Manual	0.0 1509.3	* N/A * * N/A *	0.0 1739.4
- 15 -	E-1-14	---	(No Loads Started or Tripped at this step) Stop RHR pumps if pressure is > 325 and pressure is stable or increasing. (Pressure > 325 psig)	Manual	0.0 1509.3	* N/A * * N/A *	-182.0 1557.4
- 16 -	< 19 >	---	-120 *** ENTER ES-1.3 *** TRANSFER TO COLD LEG RECIRCULATION	Manual	0.0 1509.3	* N/A * * N/A *	0.0 1557.4
- 17 -	ES-1.3-5	---	(No Loads Started or Tripped at this step) CHECK SI Recirc SW 1 Function Complete Light - LIT (YES) (9 SI pumps and two CSPs are running. CSP 32 is stopped and 31 remain running.)	Manual	0.0 1509.3	* N/A * * N/A *	-319.5 1237.9
- 18 -	ES-1.3-6	---	CHECK SI Recirc SW 2 Function Complete Light - LIT (YES) (9 SI pumps and two CSPs are running.)	Manual	0.0 1509.3	* N/A * * N/A *	0.0 1237.9
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:55 PM [54]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	---	RO-1-20	CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (All Buses are powered from EDGs.)	Manual	0.0	* N/A *	0.0
			(No Loads Started or Tripped at this step)		1509.3	* N/A *	1237.9
- 20 -	ES-1.3-7	---	STOP Motor Driven Auxiliary Feed Pumps: a. RCS pressure is less than SG pressures. (AFWPs - stopped.)	Manual	0.0	* N/A *	-375.7
			-2		1509.3	* N/A *	862.2
- 21 -	ES-1.3-8	---	INITIATE Performance of ATTACHMENT 1. Stop Any Running Charging Pumps. (Only Charging pump 31 is running - stopped.) Place all PRZR HTRs to off. (No HTRs are on.)	Manual	-140.2	* N/A *	0.0
			-13		1369.1	* N/A *	862.2
- 22 -	NSE 99-3-075	NSE 99-3-075	AS PER SECTION 4.2.20 of NSE. One CSP run time is less than 30 minutes. (CSP 31 stopped.)	Manual	-307.3	* N/A *	0.0
			-24		1061.8	* N/A *	862.2
- 23 -	ES-1.3-9	---	Align SI Recirc SW 2. b. PLACE SI Recirc SW 2 to ON. (NESWP 31 and CCWP 33 Auto started.)	Manual	280.8	* N/A *	219.6
			+84 +12		1342.6	* N/A *	1081.8
- 24 -	ES-1.3-10	---	ALIGN SI Recirc SW 4 Lo Head. b. Manually START 32 Recirc Pump. (CRP 32 started.)	Manual	0.0	* N/A *	306.3
			+23		1342.6	* N/A *	1388.1
- 25 -	ES-1.3-14	---	ALIGN SI Recirc SW 6 Lo Head. (SI SW 5 Lo Head function Light is LIT. All running SI pumps [31 and 33] auto stopped.)	Manual	-327.2	* N/A *	-327.2
			-121 -123		1015.4	* N/A *	1060.9
- 26 -	ES-1.3-15	---	Can not ALIGN SI Recirc SW 7. Bus 2A/3A is not available	Manual	0.0	* N/A *	0.0
			(No Loads Started or Tripped at this step)		1015.4	* N/A *	1060.9
- 27 -	ES-1.3-24	---	Reset MCCs. (MCCs are already reset.)	Manual	0.0	* N/A *	0.0
			(No Loads Started or Tripped at this step)		1015.4	* N/A *	1060.9

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:55 PM [54]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 28 -	ES-1.3-25	---	CHECK PAB Exhaust Fan Status: No PAB fan is running. (PAB fan 32 started.)	Manual	0.0	* N/A *	114.3
					1015.4	* N/A *	1175.2
- 29 -	ES-1.3-28	---	+88 Shutdown Unnecessary Plant Equipment: a. Check CCWPs. If 3 are running then stop one b. Check ESWPs. If 3 are running then stop one (Only one CCWP (33) and two ESWPs are running.) (No Loads Started or Tripped at this step)	Manual	0.0	* N/A *	0.0
					1015.4	* N/A *	1175.2
- 30 -	---	RO-1-27c	START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite Power. Start Turbine Turning Gear. (Bus 2A/3A unavailable to start Turning Gear) (No Loads Started or Tripped at this step)	Manual	0.0	* N/A *	0.0
					1015.4	* N/A *	1175.2
- 31 -	ES-1.3-35	---	CHECK Containment Hydrogen Concentration: (Hydrogen concentration less than 0.5% by volume.)	Manual	0.0	* N/A *	0.0
					1015.4	* N/A *	1175.2
- 32 -	ES-1.3-36	---	(No Loads Started or Tripped at this step) *** EXIT TO ES-1.4 *** << 6.5 HOURS ELAPSE PRIOR TO ENTERING ES-1.4-1 >>	Manual	0.0	* N/A *	0.0
					1015.4	* N/A *	1175.2
- 33 -	ES-1.4-7	---	(No Loads Started or Tripped at this step) *** START HIGH-HEAD RECIRCULATION *** Start SI pump 31. (SI pump 31 started.)	Manual	327.2	* N/A *	0.0
					1342.6	* N/A *	1175.2
- 34 -	ES-1.4-8	---	+121 Start SI pump 33. (SI pump 33 started.)	Manual	0.0	* N/A *	327.2
					1342.6	* N/A *	1502.4
- 35 -	ES-1.4-11	---	+123 *** RETURN TO ES-1.3 Step 37 ***	Manual	0.0	* N/A *	0.0
					1342.6	* N/A *	1502.4
- 36 -	ES-1.3-34	---	(No Loads Started or Tripped at this step) Determine if intact SGs should be depressurized to RCS pressure.	Manual	0.0	* N/A *	0.0
					1342.6	* N/A *	1502.4
			(No Loads Started or Tripped at this step)				

SMALL BREAK LOCA (PH B)

Report Date : August 25, 2009 Time : 3:55 PM [54]

Step Label	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 37 -	EG-1.3-37	---	Evaluate long term plant status.	Manual	0.0	* N/A *	0.0
			(No Loads Started or Tripped at this step)		1342.6	* N/A *	1502.4

SMALL BREAK LOCA (PH B)



Small Break LOCA (PH B)
 Buses 2A and / or 3A Not Available
 Loss of Off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING

CCWP 33
 CRP 32
 ESWP 34
 ESWP 36
 FCU 31
 FCU 33
 FCU 35
 MCC 36A: AUTO
 MCC 36B: AUTO
 MCC 36D: AUTO
 MCC 36E: AUTO
 MCCS RESET (5A) AS PER SOP-EL-15
 MCCS RESET (6A) AS PER SOP-EL-15
 NESWP 31
 PAB FAN 32
 SI PUMP 31
 SI PUMP 33

POWER FROM EDG

EDG 32
 EDG 32
 EDG 33
 EDG 32
 EDG 33
 EDG 33
 EDG 32
 EDG 33
 EDG 32
 EDG 32
 EDG 32
 EDG 33
 EDG 33
 EDG 32
 EDG 33
 EDG 32
 EDG 33
 EDG 32

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES

ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV B

STREAM BREAK (OH B)
ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:54 PM

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2180.8 Bus 2A = 2129.2 Bus 3A = 1714.9 Bus 6A = 2167.0 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A/3A is below the 3200 Amp rating
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

STEAM BREAK (PH B) - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:54 PM (46)

Step Number	SNO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36A, 36B, 36C, 36D and 36E	Auto	169.5	135.5	0.0	150.1
					169.5	135.5	0.0	150.1
- 2 -	---	RO-1-2	+57 +58 +53 +59 +60 SI pumps 31, 32 and 33 RHR pumps 31 and 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	472.4	472.4	264.5	738.5
					641.9	607.9	264.5	888.6
- 3 -	E-0-9	---	+117 +120 +121 +122 +123 CSPs 31 and 32 (E-0-9 verifies that pumps are running.)	Auto	453.6	0.0	0.0	471.1
					1095.5	607.9	264.5	1359.7
- 4 -	---	RO-1-3	+24 +25 FCUs 31, 32, 33, 34 and 35 (RO verifies that fans are running.)	Auto	491.9	247.2	246.0	248.0
					1587.4	855.1	510.5	1607.7
- 5 -	---	RO-1-5	+29 +31 +33 +35 +37 AFWPs 31 and 33 (RO verifies that pumps are running.)	Auto	0.0	0.0	575.4	562.9
					1587.4	855.1	1085.9	2170.6
- 6 -	---	RO-1-7	+1 +2 CCWPs 31, 32 and 33 (RO verifies that pumps are running.)	Auto	250.5	251.3	0.0	251.2
					1837.9	1106.4	1085.9	2421.8
- 7 -	---	RO-1-8	+4 +7 +10 ESWPs (34, 35 and 36) (RO verifies that pumps are running.)	Auto	429.9	0.0	429.0	429.8
					2267.7	1106.4	1514.9	2851.6
- 8 -	E-0-11	---	+26 +27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 32 started on lightest loaded Bus.)	Manual	0.0	0.0	208.3	0.0
					2267.7	1106.4	1723.8	2851.6
- 9 -	< 15 >	---	+14 *** FAULTED STEAM GENERATOR *** *** EVENT IDENTIFIED - EXIT TO E-2 *** (No Loads Started or Tripped at this step)	Manual	0.0	0.0	0.0	0.0
					2267.7	1106.4	1723.8	2851.6

STEAM BREAK (PH B) - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:54 PM [46]


Step Number	SPO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	< 6 >	---	*** GO TO E-1 AT THE COMPLETION OF E-2 *** (No Loads Started or Tripped at this step)	Manual	0.0 2267.7	0.0 1106.4	0.0 1723.8	0.0 2851.6
- 11 -	E-1-4	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0 2267.7	0.0 1106.4	0.0 1723.8	0.0 2851.6
- 12 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset.)	Manual	659.8 2927.5	848.0 1954.4	907.6 2231.4	252.2 3103.8
- 13 -	E-1-8	---	+126 +124 +125 +127 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0 2927.5	0.0 1954.4	0.0 2231.4	0.0 3103.8
- 14 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (CHARGING pump 32 is running.)	Manual	0.0 2927.5	0.0 1954.4	0.0 2231.4	0.0 3103.8
- 15 -	< 12 >	---	(No Loads Started or Tripped at this step) *** GO TO ES-1.1, SI TERMINATION ***	Manual	0.0 2927.5	0.0 1954.4	0.0 2231.4	0.0 3103.8
- 16 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (All RHR pumps stopped.) Stop SI pumps. (All SI pumps stopped.)	Manual	-472.4 2455.1	-472.4 1482.0	-264.5 1966.9	-738.5 2265.3
- 17 -	ES-1.1-8	---	-117 -120 -121 -122 -123 Start one CHARGING pump. (CHARGING pump 32 is running.)	Manual	0.0 2455.1	0.0 1482.0	0.0 1966.9	0.0 2265.3
- 18 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs if 5 FCUs are running or Containment pressure is < 16 PSIG. (5 FCUs are running and PSIG < 16. CSPs are stopped.) -24 -25	Manual	-453.6 2001.5	0.0 1482.0	0.0 1966.9	-471.1 1894.2

STEAM BREAK (PH B) - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:54 PM [46]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	ES-1.1-13	---	Check BAST transfer pumps are running. (MCC 36A-E never striped.)	Manual	0.0 2001.5	0.0 1482.0	0.0 1966.9	0.0 1894.2
- 20 -	NSE 99-3-075	NSE 99-3-075	(No Loads Started or Tripped at this step) AS PER SECTION 4.2.20 of NSE One CSP run time is less than 30 minutes. (No CSPs are running.)	Manual	0.0 2001.5	0.0 1482.0	0.0 1966.9	0.0 1894.2
- 21 -	ES-1.1-17	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group, as per SOP-EL-15. (Energized Pressurizer Heater Group 32 on lightest loaded Bus.)	Manual	0.0 2001.5	540.3 2022.3	0.0 1966.9	0.0 1894.2
- 22 -	ES-1.1-19	---	Reset MCCs. Start CRDM Fans. (MCC are already reset. CRDM Fan loads accounted for in MCC resets.)	Manual	0.0 2001.5	0.0 2022.3	0.0 1966.9	0.0 1894.2
- 23 -	---	RO-1-27c	(No Loads Started or Tripped at this step) START AC and STOP DC Oil Pumps IF 480V buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.)	Manual	0.0 2001.5	63.8 2086.1	0.0 1966.9	0.0 1894.2
- 24 -	ES-1.1-20	---	+47 Stop 1 of 3 CCWPs. Stop 1 of 3 ESWPs and Shutdown Motor-driven AFWPs if desired. (CCWP 31 and ESWP 35 stopped on heaviest loaded Bus. AFWPs remain running.)	Manual	-259.5 1751.0	43.1 2129.2	-429.0 1537.9	43.0 1937.2
- 25 -	ES-1.1-26	---	+8 +11 -4 -7 -10 -27 Check that at least two NESWPs are running. (NESWP 31 and 33 started on lightest loaded Bus.)	Manual	429.8 2180.8	0.0 2129.2	0.0 1537.9	429.8 2367.0
- 26 -	ES-1.1-27	---	+84 +85 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 31 started on lightest loaded Bus. Blowers and CCR ventilation started at MCC reset.)	Manual	0.0 2180.8	0.0 2129.2	177.0 1714.9	0.0 2367.0
- 27 -	ES-1.1-32	---	+87 Go to appropriate plant operating procedure as directed by the CRS or SM. (No Loads Started or Tripped at this step)	Manual	0.0 2180.8	0.0 2129.2	0.0 1714.9	0.0 2367.0

STEAM BREAK (PH B)



Steam Break (PH B)
 Total MCC and Lighting Reset
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 31	3A
AFWP 33	6A
CCWP 32	2A
CCWP 33	6A
CHARGING PUMP 32	3A
ESWP 34	5A
ESWP 36	6A
FCU 32	2A
FCU 33	5A
FCU 34	3A
FCU 35	6A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36A: AUTO	5A
MCC 36B: AUTO	6A
MCC 36C: AUTO	2A
MCC 36D: AUTO	6A
MCC 36E: AUTO	5A
NESWP 31	5A
NESWP 33	6A
PAB FAN 31	3A
PRESSURIZER HEATER 32	2A
TOTAL MCC & LIGHTING RESET (2A)	
TOTAL MCC & LIGHTING RESET (3A)	
TOTAL MCC & LIGHTING RESET (5A)	
TOTAL MCC & LIGHTING RESET (6A)	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES

ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00297 REV 9

STEAM BREAK (PH B)

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:52 PM

*** BUSES 2A AND 3A TIED TOGETHER ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2252.9 Bus 2A/3A = 2533.1 Bus 6A = 2422.8 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A/3A is below the 3200 Amp rating
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

STEAM BREAK (PH B)

Report Date : August 25, 2009 Time : 3:52 PM [20]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 7A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
1	---	---	MCC 36A, 36B, 36C, 36D and 36E	Auto	169.5	135.5	150.1
2	---	RO-1-2	+57 +58 +59 +60 SI pumps 31, 32 and 33 BHR pumps 31 and 32 (Infl flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	472.4	736.9	738.5
3	E-0-9	---	+117 +120 +121 +122 +123 CSPs 31 and 32 (E-0-9 verifies that pumps are running.)	Auto	453.6	0.0	471.1
4	---	RO-1-3	+24 +25 FCUs 31, 32, 33, 34 and 35 (RO verifies that fans are running.)	Auto	491.9	493.2	248.0
5	---	RO-1-5	+29 +31 +33 +35 +37 ARWPs 31 and 33 (RO verifies that pumps are running.)	Auto	0.0	575.4	562.9
6	---	RO-1-7	+1 +2 CCWPs 31, 32 and 33 (RO verifies that pumps are running.)	Auto	250.5	251.3	251.2
7	---	RO-1-8	+4 +7 +10 ESWPs (34, 35 and 36) (RO verifies that pumps are running.)	Auto	429.8	429.0	429.8
8	E-0-11	---	+26 +27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	208.5	0.0	0.0
9	E-15	---	+13 *** FAULT STEAM GENERATOR *** *** EVENT IDENTIFIED - EXIT TO E-2 *** (No Loads Started or Tripped at this step)	Manual	0.0	0.0	0.0
					2476.2	2621.3	2851.6

STEAM BREAK (PR B)

Report Date : August 25, 2009 Time : 3:52 PM (20)


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	< 6 >	---	*** GO TO E-1 AT THE COMPLETION OF E-2 *** (No Loads Started or Tripped at this step)	Manual	0.0	0.0	0.0
			Reset SI. (Steps 2 through 12 of RO-1 are completed.)		2476.2	2621.3	2851.6
- 11 -	E-1-4	---	(No Loads Started or Tripped at this step)	Manual	0.0	0.0	0.0
			RESET MCCs as per SOP-EL-15 (Total MCC and Lighting reset.)		2476.2	2621.3	2851.6
- 12 -	---	RO-1-15	(No Loads Started or Tripped at this step)	Manual	659.8	407.2	252.2
			+124 +127 +3 ESTABLISHISH Instrument Air to Containment. (Load accounted for in MCC reset.)		3136.0	3028.5	3103.8
- 13 -	E-1-8	---	(No Loads Started or Tripped at this step)	Manual	0.0	0.0	0.0
			Start one CHARGING pump. (CHARGING pump 31 is running.)		3136.0	3028.5	3103.8
- 14 -	E-1-11	---	(No Loads Started or Tripped at this step)	Manual	0.0	0.0	0.0
			*** GO TO ES-1.1, SI TERMINATION ***		3136.0	3028.5	3103.8
- 15 -	< 12 >	---	(No Loads Started or Tripped at this step)	Manual	0.0	0.0	0.0
			Stop RHR pumps. (All RHR pumps stopped.) Stop SI pumps. (All SI pumps stopped.)		-472.4	-736.9	-738.5
- 16 -	ES-1.1-4	---	-117 -120 -121 -122 -123 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	0.0	0.0
			(No Loads Started or Tripped at this step)		2663.6	2291.6	2365.3
- 17 -	ES-1.1-8	---	Stop CSPs if 5 FCUs are running or Containment pressure is < 16 PSIG. (5 FCUs are running and PSIG < 16. CSPs are stopped.)	Manual	-453.0	0.0	-471.1
			-24 -25		2210.0	2291.6	1894.2

STEAM BREAK (PH B)

Report Date : August 25, 2009 Time : 3:52 PM (20)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	ES-1.1-13	---	Check BAST transfer pumps are running. (MCC 35A-E never striped.)	Manual	0.0 2210.0	0.0 2291.6	0.0 1894.2
- 20 -	NSE 99-3-075	NSE 99-3-075	(No Loads Started or Tripped at this step) AS PER SECTION 4.2.20 of NSE One CSP run time is less than 30 minutes. (No CSPs are running.)	Manual	0.0 2210.0	0.0 2291.6	0.0 1894.2
- 21 -	ES-1.1-17	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group, as per SOP-EL-15. (Energized Pressurizer Heater Control Group on lightest loaded Bus.)	Manual	0.0 2210.0	0.0 2291.6	308.6 2202.8
- 22 -	ES-1.1-19	---	+114 Reset MCCs. Start CRDM Fans. (MCCs are already reset. CRDM Fan loads accounted for in MCC resets.)	Manual	0.0 2210.0	0.0 2291.6	0.0 2202.8
- 23 -	---	RO-1-27c	(No Loads Started or Tripped at this step) START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning gear. (Gear started.)	Manual	0.0 2210.0	63.8 2355.4	0.0 2202.8
- 24 -	ES-1.1-20	---	+47 Stop 1 of 3 CCWPs. Stop 1 of 3 ESWPs and Shutdown Motor-driven AFWPs if desired. (First CCWP 32 and then ESWP 34 stopped on heaviest loaded Buses. AFWPs remain running.)	Manual	-386.9 1823.1	-251.3 2104.1	43.0 2245.8
- 25 -	ES-1.1-26	---	+5 +11 -4 -7 -10 -26 Check that at least two NESWPs are running. (NESWP 31 and 32 started on lightest loaded Bus.)	Manual	429.8 2252.9	429.0 2533.1	0.0 2245.8
- 26 -	ES-1.1-27	---	+84 +85 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 32 started on lightest loaded Bus. Blowers and CCR vent. started at MCC reset.)	Manual	0.0 2252.9	0.0 2533.1	177.0 2422.8
- 27 -	ES-1.1-32	---	+88 Go to appropriate plant operating procedure as directed by the CRS or SM.	Manual	0.0 2252.9	0.0 2533.1	0.0 2422.8
			(No Loads Started or Tripped at this step)				

STEAM BREAK (PH B)



Steam Break (PH B)
 Buses 2A/3A Tied Together, All Buses Available
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 31	3A
AFWP 33	6A
CCWP 31	5A
CCWP 33	6A
CHARGING PUMP 31	5A
ESWP 35	3A
ESWP 36	6A
FCU 31	5A
FCU 32	2A
FCU 33	5A
FCU 34	3A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36A: AUTO	5A
MCC 36B: AUTO	6A
MCC 36C: AUTO	2A
MCC 36D: AUTO	6A
MCC 36E: AUTO	5A
NESWP 31	5A
NESWP 32	2A
PAB FAN 32	6A
PRESSURIZER HEATER CONTROL GROUP	6A
TOTAL MCCS & LIGHTING RESET BUS 5A	
TOTAL MCCS & LIGHTING RESET BUS 6A	
MCCS RESET (2A/3A) AS PER SOP-EL-15	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP2-CALC-ED-00297 REV 8

STEAM BREAK (PH B)

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:52 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 6A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2914.3 Bus 2A/3A = 3004.5 Bus 6A = * N/A * (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A/3A is below the 3200 Amp rating
Bus 6A Not Available

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A Not Available

STEAM BREAK (EH B)

Report Date : August 25, 2009 Time : 3:52 PM [21]

Step Number	SR Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36A, 36C and 36E	Auto	169.5	135.5	* N/A *
					169.5	135.5	* N/A *
- 2 -	---	RO-1-2	+57 +50 +60 SI pumps 31 and 32 RHR pumps 31 (mini flow, RCS press > 325) {RO verifies that pumps are running.}	Auto	472.4	736.9	* N/A *
					641.9	872.4	* N/A *
- 3 -	E-0-9	---	+117 +121 +122 CSPS 31 {E-0-9 verifies that pump is running.}	Auto	453.6	0.0	* N/A *
					1095.5	872.4	* N/A *
- 4 -	---	RO-1-3	+24 FCUs 31, 32, 33 and 34 {RO verifies that fans are running.}	Auto	491.9	493.2	* N/A *
					1587.4	1365.6	* N/A *
- 5 -	---	RO-1-5	+29 +31 +33 +35 APWPs 31 {RO verifies that pump is running.}	Auto	0.0	575.4	* N/A *
					1587.4	1941.0	* N/A *
- 6 -	---	RO-1-7	+1 CCWPs 31 and 32 {RO verifies that pumps are running.}	Auto	293.4	294.4	* N/A *
					1880.8	2235.4	* N/A *
- 7 -	---	RO-1-8	+4 +7 ESWPs (34 and 35) {RO verifies that pumps are running.}	Auto	429.8	429.0	* N/A *
					2310.6	2664.4	* N/A *
- 8 -	E-0-11	---	+26 +27 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {CHARGING pump 31 started on lightest loaded Bus.}	Manual	208.5	0.0	* N/A *
					2519.1	2664.4	* N/A *
- 9 -	< 15 >	---	+13 *** FAULT STEAM GENERATOR *** *** EVENT IDENTIFIED - EXIT TO E-2 *** {No Loads Started or Tripped at this step}	Manual	0.0	0.0	* N/A *
					2519.1	2664.4	* N/A *

STEAM BREAK (PH B)

Report Date : August 25, 2009 Time : 3:52 PM [21]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	< 6 >	---	*** GO TO E-1 AT THE COMPLETION OF E-2 ***	Manual	0.0	0.0	* N/A *
					2519.1	2664.4	* N/A *
- 11 -	E-1-4	---	(No Loads Started or Tripped at this step). Reset SI. (Steps 7 through 12 of RO-1 are completed.)	Manual	0.0	0.0	* N/A *
					2519.1	2664.4	* N/A *
- 12 -	---	RO-1-15	(No Loads Started or Tripped at this step). RESET MCCs as per SOP-EL-15 (Total MCC and Lighting reset.)	Manual	659.8	407.2	* N/A *
					3178.9	3071.6	* N/A *
- 13 -	E-1-8	---	+125 +3 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	0.0	* N/A *
					3178.9	3071.6	* N/A *
- 14 -	E-1-11	---	(No Loads Started or Tripped at this step). Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	0.0	* N/A *
					3178.9	3071.6	* N/A *
- 15 -	< 12 >	---	(No Loads Started or Tripped at this step). *** GO TO ES-1.1, SI TERMINATION ***	Manual	0.0	0.0	* N/A *
					3178.9	3071.6	* N/A *
- 16 -	ES-1.1-4	---	(No Loads Started or Tripped at this step). Stop RHR pump. (Only pump 31 running - stopped.) Stop SI pumps. (Only pumps 31 and 32 running - stopped.)	Manual	-472.4	-736.9	* N/A *
					2706.5	2334.7	* N/A *
- 17 -	ES-1.1-8	---	-117 -121 -122 Start a CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	0.0	* N/A *
					2706.5	2334.7	* N/A *
- 18 -	ES-1.1-10	---	(No Loads Started or Tripped at this step). Stop CSPs if 5 PCUs are running or Containment pressure is < 16 PSIG.	Manual	0.0	0.0	* N/A *
					2706.5	2334.7	* N/A *
			(No Loads Started or Tripped at this step)				

STEAM BREAK (PH B)

Report Date : August 25, 2009 Time : 3:52 PM (21)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	ES-1.1-13	---	Check BAST transfer pumps are running. (MCC 36A-E never striped.)	Manual	0.0	0.0	* N/A *
					2706.5	2334.7	* N/A *
- 20 -	NSE 99-1-075	NSE 99-1-075	(No Loads Started or Tripped at this step) AS PER SECTION 4.2.20 of NSE One CSP run time is less than 30 minutes. (CSP 31 stopped.)	Manual	-453.6	0.0	* N/A *
					2252.9	2334.7	* N/A *
- 21 -	ES-1.1-17	---	+34 Energize at least one Pressurizer Heater Group, as per SOP-EL-15. (Energized Pressurizer Heater Group 33 on lightest loaded Bus.)	Manual	231.6	0.0	* N/A *
					2484.5	2334.7	* N/A *
- 22 -	ES-1.1-19	---	+109 Reset MCCs. Start CRDM Fans. (MCCs are already reset. CRDM Fan loads accounted for in MCC resets.)	Manual	0.0	0.0	* N/A *
					2484.5	2334.7	* N/A *
- 23 -	---	RO-1-27c	(No Loads Started or Tripped at this step) START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.)	Manual	0.0	63.8	* N/A *
					2484.5	2398.5	* N/A *
- 24 -	ES-1.1-20	---	+47 Stop 1 of 3 CCWPs. (CCWPs 31 and 32 running.) Stop 1 of 3 ESWPs. (ESWPs 34 and 35 running.) Shutdown Motor-driven AFWPs if desired. (Bus 6A not available. AFWP 31 remains running)	Manual	0.0	0.0	* N/A *
					2484.5	2398.5	* N/A *
- 25 -	ES-1.1-26	---	(No Loads Started or Tripped at this step) Check that at least two NESWPs are running. (NESWPs 31 and 32 started.)	Manual	429.8	429.0	* N/A *
					2914.3	2827.5	* N/A *
- 26 -	ES-1.1-27	---	+84 +85 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 31 started. Blowers unavailable, powered from Bus 6A/MCC 37. CCR vent. started.)	Manual	0.0	177.0	* N/A *
					2914.3	3004.5	* N/A *
- 27 -	ES-1.1-32	---	+87 Go to appropriate plant operating procedure as directed by the CRS or SM.	Manual	0.0	0.0	* N/A *
					2914.3	3004.5	* N/A *
			(No Loads Started or Tripped at this step)				

STEAM BREAK (PH B)



Steam Break (PH B)
 Buses 2A/3A Tied Together, Bus 6A Not Available
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 31	3A
CCWP 31	5A
CCWP 32	2A
CHARGING PUMP 31	5A
ESWP 34	5A
ESWP 35	3A
FCU 31	5A
FCU 32	2A
FCU 33	5A
FCU 34	3A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36A: AUTO	5A
MCC 36C: AUTO	2A
MCC 36E: AUTO	5A
NESWP 31	5A
NESWP 32	2A
PAB FAN 31	3A
PRESSURIZER HEATER 32	2A
TOTAL MCCS & LIGHTING RESET BUS 5A	
MCCS RESET (2A/3A) AS PER SOP-EL-15	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IPJ-CALC-ED-00207 REV 8

STEAM BREAK (PH B)

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:53 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 5A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = * N/A * Bus 2A/3A = 3036.4 Bus 6A = 2852.6 (A)

3200 Amp Overload Summary

Bus 5A Not Available
Bus 2A/3A exceeds the 3200 Amp rating at EOP steps : 12, 13, 14, 15
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A Not Available
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

STEAM BREAK (PH B)

Report Date : August 25, 2009 Time : 3:53 PM [22]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36B, 36C and 36D	Auto	* N/A *	135.5	150.1
					* N/A *	135.5	150.1
- 2 -	---	RO-1-2	+57 +53 +59 SI pumps 32 and 33 RHR pumps 31 and 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	* N/A *	736.9	738.5
					* N/A *	872.4	888.6
- 3 -	E-0-9	---	+117 +120 +122 +123 CSP 32 (E-0-9 verifies that pump is running.)	Auto	* N/A *	0.0	471.1
					* N/A *	872.4	1359.7
- 4 -	---	RO-1-3	+25 FCUs 32, 34 and 35 (RO verifies that fans are running.)	Auto	* N/A *	493.2	248.0
					* N/A *	1365.6	1607.7
- 5 -	---	RO-1-5	+31 +35 +37 AFWPs 31 and 33 (RO verifies that pumps are running.)	Auto	* N/A *	575.4	562.9
					* N/A *	1941.0	2170.6
- 6 -	---	RO-1-7	+1 +2 CCWPs 32 and 33 (RO verifies that pumps are running.)	Auto	* N/A *	294.4	294.2
					* N/A *	2235.4	2464.8
- 7 -	---	RO-1-8	+7 +10 ESWPs (35 and 36) (RO verifies that pumps are running.)	Auto	* N/A *	429.0	429.8
					* N/A *	2664.4	2894.6
- 8 -	E-0-11	---	+27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 32 started on lightest loaded Bus.)	Manual	* N/A *	208.9	0.0
					* N/A *	2873.3	2894.6
- 9 -	< 15 >	---	+14 *** FAULT STEAM GENERATOR *** *** EVENT IDENTIFIED - EXIT TO E-2 *** (No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
					* N/A *	2873.3	2894.6

STEAM BREAK (PH B)

Report Date : August 25, 2009 Time : 3:53 PM [22]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	< 6 >	---	*** GO TO E-1 AT THE COMPLETION OF E-2 *** (No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
			Reset SI. (Steps 2 through 12 of RO-1 are completed.)		* N/A *	2873.3	2894.6
- 11 -	E-1-4	---	(No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
			RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset.)		* N/A *	2873.3	2894.6
- 12 -	---	RO-1-15	(No Loads Started or Tripped at this step)	Manual	* N/A *	467.2	252.2
			+127 +3 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)		* N/A *	3280.5 Over 3200	3146.8
- 13 -	E-1-8	---	(No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
			Start one CHARGING pump. (CHARGING pump 32 is running.)		* N/A *	3280.5 Over 3200	3146.8
- 14 -	E-1-11	---	(No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
			*** GO TO ES-1.1, SI TERMINATION ***		* N/A *	3280.5 Over 3200	3146.8
- 15 -	< 12 >	---	(No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
			Stop RHR pumps. (All RHR pumps stopped.) Stop SI pumps. (Only pumps 32 and 33 running - stopped.)		* N/A *	-736.9	-738.5
- 16 -	ES-1.1-4	---	-117 -120 -122 -123 Start a CHARGING pump. (CHARGING pump 32 is running.)	Manual	* N/A *	0.0	0.0
			(No Loads Started or Tripped at this step)		* N/A *	2543.6	2408.3
- 17 -	ES-1.1-8	---	Stop CSPs if 5 FCUs are running or Containment pressure is < 16 PSIG.	Manual	* N/A *	0.0	0.0
			(No Loads Started or Tripped at this step)		* N/A *	2543.6	2408.3
- 18 -	ES-1.1-10	---	(No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
					* N/A *	2543.6	2408.3

STEAM BREAK (PH B)

Report Date : August 25, 2009 Time : 3:53 PM [22]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	ES-1.1-13	---	Check BAST transfer pumps are running. (MCC 36A-E never striped.)	Manual	* N/A *	0.0	0.0
					* N/A *	2543.6	2408.3
- 20 -	NSE 99-3-075	NSE 99-3-075	(No Loads Started or Tripped at this step) AS PER SECTION 4.2.20 of NSE One CSP run time is less than 30 minutes. (CSP 32 stopped.)	Manual	* N/A *	0.0	-471.1
					* N/A *	2543.6	1937.2
- 21 -	ES-1.1-17	---	-25 Energize at least one Pressurizer Heater Group. as per SOP-EL-15. (Energized Pressurizer Heater Control Group on lightest loaded Bus.)	Manual	* N/A *	0.0	308.6
					* N/A *	2543.6	2245.8
- 22 -	ES-1.1-19	---	+114 Reset MCCs. Start CRDM Fans. (MCC are already reset. Bus 5A unavailable to start CRDM Fans.)	Manual	* N/A *	0.0	0.0
					* N/A *	2543.6	2245.8
- 23 -	---	RO-1-27c	(No Loads Started or Tripped at this step) START AC and DC Oil Pumps IF 180V buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.)	Manual	* N/A *	63.8	0.0
					* N/A *	2607.4	2245.8
- 24 -	ES-1.1-20	---	+47 Stop 1 of 3 CCWPs. (CCWPs 32 and 33 running.) Stop 1 of 3 ESWPs (ESWPs 35 and 36 running.) Shutdown Motor-driven AFWPs if desired. (AFWPs remain running.)	Manual	* N/A *	0.0	0.0
					* N/A *	2607.4	2245.8
- 25 -	ES-1.1-26	---	(No Loads Started or Tripped at this step) Check that at least two NESWPs are running. (NESWP 32 and 33 started.)	Manual	* N/A *	429.0	429.8
					* N/A *	3036.4	2675.6
- 26 -	ES-1.1-27	---	+85 +86 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 32 started on lightest loaded Bus. Blowers and CCR vent. started at MCC resets.)	Manual	* N/A *	0.0	177.0
					* N/A *	3036.4	2852.6
- 27 -	ES-1.1-32	---	+88 Go to appropriate plant operating procedure as directed by the CRS or SM.	Manual	* N/A *	0.0	0.0
					* N/A *	3036.4	2852.6
			(No Loads Started or Tripped at this step)				

STEAM BREAK (PH B)



Steam Break (PH B)
 Buses 2A/3A Tied Together, Bus 5A Not Available
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 31	3A
AFWP 33	6A
CCWP 32	2A
CCWP 33	6A
CHARGING PUMP 32	3A
ESWP 35	3A
ESWP 36	6A
FCU 32	2A
FCU 34	3A
FCU 35	6A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36B: AUTO	6A
MCC 36C: AUTO	2A
MCC 36D: AUTO	6A
NESWP 32	2A
NESWP 33	6A
PAB FAN 32	6A
PRESSURIZER HEATER CONTROL GROUP	6A
MCCS RESET (2A/3A) AS PER SOP-EL-15	
TOTAL MCCS & LIGHTING RESET BUS 6A	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

TP2-CALC-ED-00207 REV 8

STEAM BREAK (PH B)

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:53 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 2A AND/OR 3A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2682.7 Bus 2A/3A = * N/A * Bus 6A = 2852.6 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A and/or 3A Not Available
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A and/or 3A Not Available
Bus 6A is below the 3600 Amp rating

STEAM BREAK (PH B)

Report Date : August 25, 2009 Time : 3:53 PM [23]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36A, 36B, 36D and 36E	Auto	169.5	* N/A *	150.1
					169.5	* N/A *	150.1
- 2 -	---	RO-1-2	+55 +53 +59 +60 SI Pumps 31 and 33 RHR Pumps 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	472.4	* N/A *	738.5
					641.9	* N/A *	888.6
- 3 -	E-0-9	---	+120 +121 +123 CSFPs 31 and 32 (E-0-9 verifies that pumps are running.)	Auto	453.6	* N/A *	471.1
					1095.5	* N/A *	1359.7
- 4 -	---	RO-1-3	+24 +25 FCUs 31, 33 and 35 (RO verifies that fans are running.)	Auto	491.9	* N/A *	248.0
					1587.4	* N/A *	1607.7
- 5 -	---	RO-1-5	+29 +33 +37 AFWP 33 (RO verifies that pump is running.)	Auto	0.0	* N/A *	562.9
					1587.4	* N/A *	2170.6
- 6 -	---	RO-1-7	+2 CCMPs 31 and 33 (RO verifies that pumps are running.)	Auto	293.4	* N/A *	294.2
					1880.8	* N/A *	2464.8
- 7 -	---	RO-1-8	+4 +10 ESWPs (34 and 36) (RO verifies that pumps are running.)	Auto	429.8	* N/A *	429.8
					2310.6	* N/A *	2894.6
- 8 -	E-0-11	---	+26 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCN is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	208.5	* N/A *	0.0
					2519.1	* N/A *	2894.6
- 9 -	< 15 >	---	+13 *** FAULT STEAM GENERATOR *** *** EVENT IDENTIFIED - EXIT TO E-2 *** (No Loads Started or Tripped at this step)	Manual	0.0	* N/A *	0.0
					2519.1	* N/A *	2894.6

STEAM BREAK (PH B)

Report Date : August 25, 2009 Time : 3:53 PM [23]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	< E >	---	*** GO TO E-1 AT THE COMPLETION OF E-2 ***	Manual	0.0	* N/A *	0.0
					2519.1	* N/A *	2894.6
- 11 -	E-1-4	---	(No Loads Started or Tripped at this step) Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0	* N/A *	0.0
					2519.1	* N/A *	2894.6
- 12 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset.)	Manual	659.8	* N/A *	252.2
					3178.9	* N/A *	3146.8
- 13 -	E-1-8	---	+126 +127 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	* N/A *	0.0
					3178.9	* N/A *	3146.8
- 14 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	* N/A *	0.0
					3178.9	* N/A *	3146.8
- 15 -	< 12 >	---	(No Loads Started or Tripped at this step) *** GO TO ES-1.1, SI TERMINATION ***	Manual	0.0	* N/A *	0.0
					3178.9	* N/A *	3146.8
- 16 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (Only pump 32 running - stopped.) Stop SI pumps. (Only pumps 31 and 33 running - stopped.)	Manual	-472.4	* N/A *	-738.5
					2706.5	* N/A *	2408.3
- 17 -	ES-1.1-8	---	-120 -121 -123 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	* N/A *	0.0
					2706.5	* N/A *	2408.3
- 18 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs if 5 FCUs are running Containment pressure is < 16 PSIG.	Manual	0.0	* N/A *	0.0
					2706.5	* N/A *	2408.3
			(No Loads Started or Tripped at this step)				

STEAM BREAK (PH B)

Report Date : August 25, 2009 Time : 3:53 PM [23]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	ES-1.1-13	---	Check BAST transfer pumps are running. (MCC 36A-E never stripped.)	Manual	0.0	* N/A *	0.0
					2706.9	* N/A *	2408.3
- 20 -	NSE 99-3-075	NSE 99-3-075	(No Loads Started or Tripped at this step) AS PER SECTION 4.2.20 of NSE One CSP run time is less than 30 minutes. (CSPs stopped.)	Manual	-457.6	* N/A *	-471.1
					2252.9	* N/A *	1937.2
- 21 -	ES-1.1-17	---	-24 -25 Energize at least one Pressurizer Heater Group. as per SOP-EL-15. (Energized Pressurizer Heater Control Group on lightest loaded Bus.)	Manual	0.0	* N/A *	308.6
					2252.9	* N/A *	2245.8
- 22 -	ES-1.1-19	---	+114 Reset MCCs. Start CRDM Fans. (MCC are already reset. CRDM Fan loads accounted for in MCC resets.)	Manual	0.0	* N/A *	0.0
					2252.9	* N/A *	2345.8
- 23 -	---	RO-1-27c	(No Loads Started or Tripped at this step) START AC and STOP DC Oil Pumps LP 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Bus 2A/3A unavailable.)	Manual	0.0	* N/A *	0.0
					2252.9	* N/A *	2345.8
- 24 -	ES-1.1-20	---	(No Loads Started or Tripped at this step) Stop 1 of 3 CCWPs. (CCWPs 31 and 33 running.) Stop 1 of 3 ESWPs. (ESWPs 34 and 36 running.) Shutdown Motor-driven APWPs if desired. (Bus 2A/3A not available. APWP 33 remains running)	Manual	0.0	* N/A *	0.0
					2252.9	* N/A *	2245.8
- 25 -	ES-1.1-26	---	(No Loads Started or Tripped at this step) Check that at least two NESWPs are running. (NESWP 31 and 33 started.)	Manual	429.8	* N/A *	429.8
					2682.7	* N/A *	2675.6
- 26 -	ES-1.1-27	---	+84 +86 Start a PAB Fan. Penetration Blowers and CCR ventilation. (PAB Fan 32 started. Blowers and CCR ventilation started at MCC reset.)	Manual	0.0	* N/A *	177.0
					2682.7	* N/A *	2852.6
- 27 -	ES-1.1-32	---	+88 Go to appropriate plant operating procedure as directed by the CRS or SM.	Manual	0.0	* N/A *	0.0
					2682.7	* N/A *	2852.6
			(No Loads Started or Tripped at this step)				

STEAM BREAK (PH B)



Steam Break (PH B)
 Buses 2A and / or 3A Not Available
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING

POWER FROM BUS

AFWP 33	6A
CCWP 31	5A
CCWP 33	6A
CHARGING PUMP 31	5A
ESWP 34	5A
ESWP 36	6A
FCU 31	5A
FCU 33	5A
FCU 35	6A
MCC 36A: AUTO	5A
MCC 36B: AUTO	6A
MCC 36D: AUTO	6A
MCC 36E: AUTO	5A
NESWP 31	5A
NESWP 33	6A
PAB FAN 32	6A
PRESSURIZER HEATER CONTROL GROUP	6A
TOTAL MCCS & LIGHTING RESET BUS 5A	
TOTAL MCCS & LIGHTING RESET BUS 6A	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

STEAM BREAK (PH B)

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:53 PM

*** BUSES 2A AND 3A TIED TOGETHER ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = 1163.1 Bus 2A/3A = 1231.1 Bus 6A = 1221.5 (kW)

1750 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1750 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1750 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1750 kW rating

1950 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1950 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1950 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating

STEAM BREAK (PH B)

Report Date : August 25, 2009 Time : 3:53 PM [24]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36A, 36B, 36C, 36D and 36E	Auto	110.0	94.3	100.4
					110.0	94.3	100.4
- 2 -	---	RO-1-2	+57 +50 +53 +59 +60 SI pumps 31, 32 and 33 RHR pumps 31 and 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	327.2	509.2	509.2
					437.2	603.5	609.6
- 3 -	E-0-9	---	+117 +120 +121 +122 +123 CSPs 31 and 32 (E-0-9 verifies that pumps are running.)	Auto	307.3	0.0	319.5
					744.3	603.5	929.1
- 4 -	---	RO-1-3	+24 +25 FCUs 31, 32, 33, 34 and 35 (RO verifies that fans are running.)	Auto	258.0	258.0	129.0
					1002.5	861.5	1058.1
- 5 -	---	RO-1-5	+29 +31 +33 +35 +37 AEWPs 31 and 33 (RO verifies that pumps are running.)	Auto	0.0	378.9	375.7
					1002.5	1240.4	1433.8
- 6 -	---	RO-1-7	+1 +2 CHECK if Gifsite power is available to a 480V Bus to start at least one CCWP. (All Buses are powered from EDGs.)	Manual	0.0	0.0	0.0
					1002.5	1240.4	1433.8
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESWPs (34, 35 and 36) (RO verifies that pumps are running.)	Auto	280.8	280.8	230.8
					1283.3	1521.2	1714.6
- 8 -	E-0-11	---	+26 +27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	140.2	0.0	0.0
					1423.5	1521.2	1714.6
- 9 -	< 15 >	---	+13 *** FAULTED STEAM GENERATOR *** *** EVENT IDENTIFIED - EXIT TO E-2 *** (No Loads Started or Tripped at this step)	Manual	0.0	0.0	0.0
					1423.5	1521.2	1714.6

STEAM BREAK (PH B)

Report Date : August 25, 2009 Time : 3:53 PM [24]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	< 6 >	---	*** GO TO E-1 AT THE COMPLETION OF E-2 *** (No Loads Started or Tripped at this step)	Manual	0.0 1423.5	0.0 1521.2	0.0 1714.6
- 11 -	E-1-4	---	Reset SI. (Steps 3 through 12 of RO-1 are completed.)	Manual	0.0 1423.5	0.0 1521.2	0.0 1714.6
- 12 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (MCCs are reset.)	Manual	85.8 1509.3	63.3 1584.5	24.8 1739.4
- 13 -	E-1-8	---	+82 +81 +83 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0 1509.3	0.0 1584.5	0.0 1739.4
- 14 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0 1509.3	0.0 1584.5	0.0 1739.4
- 15 -	< 12 >	---	(No Loads Started or Tripped at this step) *** GO TO ES-1.1, SI TERMINATION ***	Manual	0.0 1509.3	0.0 1584.5	0.0 1739.4
- 16 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (All RHR pumps stopped.) Stop SI pumps. (All SI pumps stopped.)	Manual	-327.2 1182.1	-509.3 1075.3	-509.2 1230.2
- 17 -	ES-1.1-8	---	-117 -120 -121 -122 -123 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0 1182.1	0.0 1075.3	0.0 1230.2
- 18 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs if 5 FCUs are running or Containment pressure is < 15 PSIG. (5 FCUs are running. CSPs stopped.) -24 -25	Manual	-307.3 874.8	0.0 1075.3	-319.5 910.7

STEAM BREAK (PH B)

Report Date : August 29, 2009 Time : 3:53 PM (24)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	ES-1.1-13	---	Check BAST transfer pumps are running. (MCC 16A-E never striped.)	Manual	0.0 874.8	0.0 1075.3	0.0 910.7
- 20 -	NSE 99-3-075	NSE 99-3-075	(No Loads Started or Tripped at this step) AS PER SECTION 4.2.20 of NSE One CSP run time is less than 30 minutes. (No CSPs are running.)	Manual	0.0 874.8	0.0 1075.3	0.0 910.7
- 21 -	ES-1.1-17	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Pressurizer Heater Group 33 energized on lightest loaded Bus. +109	Manual	207.9 1082.7	0.0 1075.3	0.0 910.7
- 23 -	ES-1.1-19	---	Reset MCCs. Start CRDM Fans. (MCC are already reset. CRDM Fans started on MCC 38.)	Manual	80.4 1163.1	0.0 1075.3	0.0 910.7
- 23 -	---	RO-1-27c	+70 +71 +72 +73 START AC and STOP DC oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.) +47	Manual	0.0 1163.1	41.5 1116.8	0.0 910.7
- 24 -	ES-1.1-20	---	Stop 1 of 3 ESWPs. (ESWP 34 stopped on heaviest loaded Bus.) Shutdown Motor-driven AFWPs if desired. (AFWPs remain running.) -26	Manual	-280.8 882.3	0.0 1116.8	0.0 910.7
- 25 -	ES-1.1-26	---	Check that at least two NESWPs are running. (NESWP 31 and 33 started on lightest loaded Bus.)	Manual	280.8 1163.1	0.0 1116.8	280.8 1191.5
- 26 -	ES-1.1-27	---	+84 +85 Start a PAB Fan. Penetration Blowers and CCR ventilation. (PAB Fan 31 started on lightest loaded Bus. Blowers started, CCR ventilation is running.) +87 +66 +67	Manual	0.0 1163.1	114.3 1231.1	30.0 1221.5
- 27 -	ES-1.1-32	---	Go to appropriate plant operating procedure as directed by the CRS or SM. (No Loads Started or Tripped at this step)	Manual	0.0 1163.1	0.0 1231.1	0.0 1221.5

STEAM BREAK (PH B)



Steam Break (PH B)
 Buses 2A/3A Tied Together, All Buses Available
 Loss of Off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

AFWP 31	EDG 31
AFWP 33	EDG 32
CHARGING PUMP 31	EDG 33
ESWP 35	EDG 31
ESWP 36	EDG 32
FCU 31	EDG 33
FCU 32	EDG 31
FCU 33	EDG 33
FCU 34	EDG 31
FCU 35	EDG 32
MCC 34: TURBINE TURNING GEAR	EDG 31
MCC 36A: AUTO	EDG 33
MCC 36B: AUTO	EDG 32
MCC 36C: AUTO	EDG 31
MCC 36D: AUTO	EDG 32
MCC 36E: AUTO	EDG 33
MCC 37: PENT. BLOWER (#1)	EDG 32
MCC 37: PENT. BLOWER (#2)	EDG 32
MCC 38: CRDM FAN 31 (FAN#1)	EDG 33
MCC 38: CRDM FAN 32 (FAN#2)	EDG 33
MCC 38: CRDM FAN 33 (FAN#3)	EDG 33
MCC 38: CRDM FAN 34 (FAN#4)	EDG 33
MCCS RESET (2A/3A) AS PER SOP-EL-15	EDG 31
MCCS RESET (5A) AS PER SOP-EL-15	EDG 33
MCCS RESET (6A) AS PER SOP-EL-15	EDG 32
NESWP 31	EDG 33
NESWP 33	EDG 31
PAB FAN 31	EDG 31
PRESSURIZER HEATER 33	EDG 33

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

STEAM BREAK (PH B)

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:53 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 6A NOT AVAILABLE ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = 1443.9 Bus 2A/3A = 1511.9 Bus 6A = * N/A * (kW)

1750 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1750 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1750 kW rating
Bus 6A Not Available

1950 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1950 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1950 kW rating
Bus 6A Not Available

STEAM BREAK (PH B)

Report Date : August 25, 2009 Time : 3:53 PM [25]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (KW)	Bus 2A/3A Step/Total Load (KW)	Bus 6A Step/Total Load (KW)
- 1 -	---	---	MCC 36A, 36C and 36E	Auto	110.0	94.3	* N/A *
					110.0	94.3	* N/A *
- 2 -	---	RO-1-2	+57 +50 +60 SI pumps 31 and 32 RHR pumps 31 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	327.2	509.2	* N/A *
					437.2	603.5	* N/A *
- 3 -	E-0-9	---	+117 +121 +122 CSP 31 (E-0-9 verifies that pump is running.)	Auto	307.3	0.0	* N/A *
					744.5	603.5	* N/A *
- 4 -	---	RO-1-3	+24 FCGs 31, 32, 33 and 34 (RO verifies that fans are running.)	Auto	258.0	258.0	* N/A *
					1002.5	861.5	* N/A *
- 5 -	---	RO-1-5	+29 +31 +33 +35 AFWP 31 (RO verifies that pump is running.)	Auto	0.0	378.9	* N/A *
					1002.5	1240.4	* N/A *
- 6 -	---	RO-1-7	+1 CHECK if offsite power is available to a 480V Bus to start at least one CCWP. (All Buses are powered from EDGs.)	Manual	0.0	0.0	* N/A *
					1002.5	1240.4	* N/A *
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESWPs (1 + 1) (RO verifies that pumps are running.)	Auto	280.8	280.8	* N/A *
					1283.3	1521.2	* N/A *
- 8 -	E-0-11	---	+26 +27 Start one CHARGING pump if RCS pressure is > than 325 psig & CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	140.2	0.0	* N/A *
					1423.5	1521.2	* N/A *
- 9 -	< 15 >	---	+13 *** FAULTED STEAM GENERATOR *** *** EVENT IDENTIFIED - EXIT TO E-2 *** (No Loads Started or Tripped at this step)	Manual	0.0	0.0	* N/A *
					1423.5	1521.2	* N/A *

STEAM BREAK (PH B)

Report Date : August 25, 2009 Time : 3:53 PM [25]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	< 6 >	---	*** GO TO E-1 AT THE COMPLETION OF E-2 ***	Manual	0.0	0.0	* N/A *
					1423.5	1521.3	* N/A *
- 11 -	E-1-4	---	(No Loads Started or Tripped at this step) Reset SI. (Steps 3 through 12 of RO-1 are completed.)	Manual	0.0	0.0	* N/A *
					1423.5	1521.2	* N/A *
- 12 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-ED-15. (MCCs are reset.)	Manual	85.9	63.3	* N/A *
					1509.3	1584.5	* N/A *
- 13 -	E-1-8	---	+82 +81 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	0.0	* N/A *
					1509.3	1584.5	* N/A *
- 14 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	0.0	* N/A *
					1509.3	1584.5	* N/A *
- 15 -	< 12 >	---	(No Loads Started or Tripped at this step) *** GO TO ES-1.1, SI TERMINATION ***	Manual	0.0	0.0	* N/A *
					1509.3	1584.5	* N/A *
- 16 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (Only pump 31 running - stopped.) Stop SI pumps. (Only pumps 31 and 32 running - stopped.)	Manual	-327.2	-509.2	* N/A *
					1182.1	1075.3	* N/A *
- 17 -	ES-1.1-8	---	-117 -121 -122 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	0.0	* N/A *
					1183.1	1075.3	* N/A *
- 18 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs if 5 FCUs are running or Containment pressure is < 16 PSIG.	Manual	0.0	0.0	* N/A *
					1182.1	1075.3	* N/A *
			(No Loads Started or Tripped at this step)				

STEAM BREAK (PH B)

Report Date : August 25, 2009 Time : 3:53 PM (25)

Step Number	SRG Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	ES-1.1-13	---	Check BAST transfer pumps are running (MCC 36A-E never stripped.)	Manual	0.0	0.0	* N/A *
- 20 -	NSE 99-3-075	NSE 99-3-075	(No Loads Started or Tripped at this step) AS PER SECTION 4.2.20 of NSE One CSP run time is less than 30 minutes. (CSP 31 stopped.)	Manual	1182.1	1075.3	* N/A *
- 21 -	ES-1.1-17	---	-24 Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Pressurizer Heater Group 33 energized on lightest loaded Bus.)	Manual	874.8	1075.3	* N/A *
- 22 -	ES-1.1-19	---	+109 Reset MCCs. Start CRDM Fans (MCC are already reset. CRDM Fans started on MCC 38.)	Manual	207.9	0.0	* N/A *
- 23 -	---	RO-1-27c	+70 +71 +72 +73 START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.)	Manual	1082.7	1075.3	* N/A *
- 24 -	ES-1.1-20	---	+47 Stop 1 of 3 ESOWPs. (ESOWPs 34 and 35 are running.) Shutdown Motor-driven APWPs if desired. (Bus 6A not available. APWP 31 remains running)	Manual	80.4	0.0	* N/A *
- 25 -	ES-1.1-25	---	(No Loads Started or Tripped at this step) Check that at least two NESOWPs are running. (Two NESOWPs started.)	Manual	1163.1	1075.3	* N/A *
- 26 -	ES-1.1-27	---	+84 +85 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 31 started. Blowers unavailable, powered from Bus 6A/MCC 37. CCR vent. is on.)	Manual	0.0	41.5	* N/A *
- 27 -	ES-1.1-32	---	+87 Go to appropriate plant operating procedure as directed by the CRS or SM.	Manual	1163.1	1116.8	* N/A *
			(No Loads Started or Tripped at this step)		1443.9	1397.6	* N/A *
					0.0	114.3	* N/A *
					1443.9	1511.9	* N/A *
					0.0	0.0	* N/A *
					1443.9	1511.9	* N/A *

STEAM BREAK (PH B)



Steam Break (PH B)
 Buses 2A/3A Tied Together, Bus 6A Not Available
 Loss of Off-site power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

AFWP 31	EDG 31
CHARGING PUMP 31	EDG 33
ESWP 34	EDG 33
ESWP 35	EDG 31
FCU 31	EDG 33
FCU 32	EDG 31
FCU 33	EDG 33
FCU 34	EDG 31
MCC 34: TURBINE TURNING GEAR	EDG 31
MCC 36A: AUTO	EDG 33
MCC 36C: AUTO	EDG 31
MCC 36E: AUTO	EDG 33
MCC 38: CRDM FAN 31 (FAN#1)	EDG 33
MCC 38: CRDM FAN 32 (FAN#2)	EDG 33
MCC 38: CRDM FAN 33 (FAN#3)	EDG 33
MCC 38: CRDM FAN 34 (FAN#4)	EDG 33
MCCS RESET (2A/3A) AS PER SOP-EL-15	EDG 31
MCCS RESET (5A) AS PER SOP-EL-15	EDG 33
NESWP 31	EDG 33
NESWP 32	EDG 31
PAB FAN 31	EDG 31
PRESSURIZER HEATER 33	EDG 33

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

STEAM BREAK (PH B)

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:53 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 5A NOT AVAILABLE ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = * N/A * Bus 2A/3A = 1537.8 Bus 6A = 1612.8 (kW)

1750 kW Overload Summary

Bus 5A Not Available
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1750 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1750 kW rating

1950 kW Overload Summary

Bus 5A Not Available
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1950 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating

STEAM BREAK (PH B)

Report Date : August 25, 2009 Time : 3:53 PM [26]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36B, 36C and 36D	Auto	* N/A *	94.3	100.4
					* N/A *	94.3	100.4
- 2 -	---	RO-1-2	+57 +53 +59 SI pumps 31 and 32 RHR pumps 31 and 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	* N/A *	509.2	509.2
					* N/A *	603.5	609.6
- 3 -	E-0-9	---	+117 +120 +122 +123 CSP 32 (E-0-9 verifies that pump is running.)	Auto	* N/A *	0.0	319.5
					* N/A *	603.5	929.1
- 4 -	---	RO-1-3	+35 FCUs 32, 34 and 35 (RO verifies that fans are running.)	Auto	* N/A *	258.0	129.0
					* N/A *	861.5	1058.1
- 5 -	---	RO-1-5	+31 +25 +37 APNPs 31 and 33 (RO verifies that pumps are running.)	Auto	* N/A *	378.9	375.7
					* N/A *	1240.4	1433.8
- 6 -	---	RO-1-7	+1 +2 CHECK if Offsite power is available to a 480V Bus to start at least one CCMP. (All Buses are powered from EDGs.)	Manual	* N/A *	0.0	0.0
					* N/A *	1240.4	1433.8
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESWPs (35 and 36) (RO verifies that pumps are running.)	Auto	* N/A *	280.8	280.8
					* N/A *	1521.2	1714.6
- 8 -	E-0-11	---	+27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 32 started on lightest loaded Bus.)	Manual	* N/A *	140.2	0.0
					* N/A *	1661.4	1714.6
- 9 -	< 15 >	---	+14 *** FAULTED STEAM GENERATOR *** *** EVENT IDENTIFIED - EXIT TO E-2 *** (No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
					* N/A *	1661.4	1714.6

STEAM BREAK (PH B)

Report Date : August 25, 2009 Time : 3:53 PM [26]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	< 6 >	---	*** GO TO E-1 AT THE COMPLETION OF E-2 ***	Manual	* N/A *	0.0	0.0
					* N/A *	1661.4	1714.6
- 11 -	E-1-4	---	(No Loads Started or Tripped at this step) Reset SI (Steps 2 through 12 of RO-1 are completed.)	Manual	* N/A *	0.0	0.0
					* N/A *	1661.4	1714.6
- 12 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15 (MCCs are reset.)	Manual	* N/A *	63.3	24.8
					* N/A *	1724.7	1739.4
- 13 -	E-1-8	---	+81 +81 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	* N/A *	0.0	0.0
					* N/A *	1724.7	1739.4
- 14 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (CHARGING pump 32 is running.)	Manual	* N/A *	0.0	0.0
					* N/A *	1724.7	1739.4
- 15 -	< 12 >	---	(No Loads Started or Tripped at this step) *** GO TO ES-1.1, SI TERMINATION ***	Manual	* N/A *	0.0	0.0
					* N/A *	1724.7	1739.4
- 16 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (All RHR pumps stopped.) Stop SI pumps. (Only pumps 32 and 33 running - stopped.)	Manual	* N/A *	-509.2	-509.2
					* N/A *	1215.5	1230.2
- 17 -	ES-1.1-8	---	-117 -120 -122 -123 Start one CHARGING pump. (CHARGING pump 32 is running.)	Manual	* N/A *	0.0	0.0
					* N/A *	1215.5	1230.2
- 18 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs if 5 FCUs are running or Containment pressure is < 15 PSIG.	Manual	* N/A *	0.0	0.0
					* N/A *	1215.5	1230.2
			(No Loads Started or Tripped at this step)				

STEAM BREAK (PH B)

Report Date : August 25, 2009 Time : 3:53 PM [26]

Step Number	S&O Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	ES-1.1-13	---	Check BAST transfer pumps are running (MCC 36A-E never striped.)	Manual	* N/A *	0.0	0.0
					* N/A *	1215.5	1230.2
- 20 -	NSE 99-1-075	NSE 99-1-075	(No Loads Started or Tripped at this step) ASA PER SECTION 4.2.20 of NSE One CSP run time is less than 30 minutes. (CSP 32 stopped.)	Manual	* N/A *	0.0	-319.5
					* N/A *	1215.5	910.7
- 21 -	ES-1.1-17	---	-25 Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Pressurizer Heater Control Group energized on lightest loaded Bus.)	Manual	* N/A *	0.0	277.0
					* N/A *	1215.5	1187.7
- 22 -	ES-1.1-19	---	-114 Reset MCCs. Start CRDM Fans. (MCC are already reset. Bus 5A unavailable to power CRDM Fans.)	Manual	* N/A *	0.0	0.0
					* N/A *	1215.5	1187.7
- 23 -	---	RO-1-27c	(No Loads Started or Tripped at this step) START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.)	Manual	* N/A *	41.5	0.0
					* N/A *	1257.0	1187.7
- 24 -	ES-1.1-20	---	+47 Stop 1 of 3 ESWPs. (ESWPs 35 and 36 are running.) Shutdown Motor-driven APWPs if desired. (APWPs remain running.)	Manual	* N/A *	0.0	0.0
					* N/A *	1257.0	1187.7
- 25 -	ES-1.1-26	---	(No Loads Started or Tripped at this step) Check that at least two NESWPs are running. (NESWPs 32 and 33 are started.)	Manual	* N/A *	280.8	280.8
					* N/A *	1537.8	1468.5
- 26 -	ES-1.1-27	---	+85 +86 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 32 started on lightest loaded Bus. Blowers started. CCR ventilation is running.)	Manual	* N/A *	0.0	144.3
					* N/A *	1537.8	1612.8
- 27 -	ES-1.1-32	---	+83 +65 +67 Go to appropriate plant operating procedure as directed by the CRS or SM.	Manual	* N/A *	0.0	0.0
					* N/A *	1537.8	1612.8
			(No Loads Started or Tripped at this step)				

STEAM BREAK (PH B)



Steam Break (PH B)
 Buses 2A/3A Tied Together, Bus 5A Not Available
 Loss of Off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

AFWP 31	EDG 31
AFWP 33	EDG 32
CHARGING PUMP 32	EDG 31
ESWP 35	EDG 31
ESWP 36	EDG 32
FCU 32	EDG 31
FCU 34	EDG 31
FCU 35	EDG 32
MCC 34: TURBINE TURNING GEAR	EDG 31
MCC 36B: AUTO	EDG 32
MCC 36C: AUTO	EDG 31
MCC 36D: AUTO	EDG 32
MCC 37: PENT. BLOWER (#1)	EDG 32
MCC 37: PENT. BLOWER (#2)	EDG 32
MCCS RESET (2A/3A) AS PER SOP-EL-15	EDG 31
MCCS RESET (6A) AS PER SOP-EL-15	EDG 32
NESWP 32	EDG 31
NESWP 33	EDG 32
PAB FAN 32	EDG 32
PRESSURIZER HEATER CONTROL GROUP	EDG 32

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES

ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00297 REV 8

STEAM BREAK (PH B)

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:53 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 2A AND/OR 3A NOT AVAILABLE ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = 1443.9 Bus 2A/3A = * N/A * Bus 6A = 1335.8 (kW)

1750 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1750 kW rating
Bus 2A and/or 3A Not Available
Emergency Diesel Generator 32 on Bus 6A is below the 1750 kW rating

1950 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1950 kW rating
Bus 2A and/or 3A Not Available
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating

STEAM BREAK (PH B)

Report Date : August 25, 2009 Time : 3:53 PM [27]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36A, 36B, 36D and 36E	Auto	110.0	* N/A *	100.4
					110.0	* N/A *	100.4
- 2 -	---	RO-1-2	+50 +53 +59 +60 SI pumps 31 and 33 RHP pump 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	327.2	* N/A *	509.2
					437.2	* N/A *	609.6
- 3 -	E-0-9	---	+120 +121 +123 CSFs 31 and 32 (E-0-9 verifies that pump is running.)	Auto	307.3	* N/A *	319.5
					744.5	* N/A *	929.1
- 4 -	---	RO-1-3	+24 +25 FCUs 31, 33 and 35 (RO verifies that fans are running.)	Auto	293.0	* N/A *	129.0
					1002.5	* N/A *	1058.1
- 5 -	---	RO-1-5	+29 +33 +37 AFWPs 33 (RO verifies that pump is running.)	Auto	0.0	* N/A *	375.7
					1002.5	* N/A *	1433.8
- 6 -	---	RO-1-7	+2 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. (All Buses are powered from EDCs.)	Manual	0.0	* N/A *	0.0
					1002.5	* N/A *	1433.8
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESKPs (34 and 35) (RO verifies that pump is running.)	Auto	280.8	* N/A *	280.8
					1283.3	* N/A *	1714.6
- 8 -	E-0-11	---	+25 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	140.2	* N/A *	0.0
					1423.5	* N/A *	1714.6
- 9 -	< 15 >	---	+13 *** FAULTED STEAM GENERATOR *** *** EVENT IDENTIFIED - EXIT TO E-2 *** (No Loads Started or Tripped at this step)	Manual	0.0	* N/A *	0.0
					1423.5	* N/A *	1714.6

STEAM BREAK (PH B)

Report Date : August 25, 2009 Time : 3:53 PM [27]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 5A Step/Total Load (kW)
- 10 -	---	RO-1-20	Start one PAB fan. (While in this step procedure , a PAB fan can not be started if 2A/3A Tie Breaker is closed.) (No Loads Started or Tripped at this step)	Manual	0.0 1423.5	* N/A * * N/A *	0.0 1714.6
- 11 -	< 6 >	---	*** GO TO E-1 AT THE COMPLETION OF E-2 *** (No Loads Started or Tripped at this step)	Manual	0.0 1423.5	* N/A * * N/A *	0.0 1714.6
- 12 -	E-1-4	---	Reset SI (Steps 2 through 12 of RO-1 are completed.) (No Loads Started or Tripped at this step)	Manual	0.0 1423.5	* N/A * * N/A *	0.0 1714.6
- 13 -	---	RO-1-15	RESET MCCs as per SOP-EL-15. (MCCs are reset.) -82 +83	Manual	85.8 1509.3	* N/A * * N/A *	24.8 1739.4
- 14 -	E-1-8	---	ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.) (No Loads Started or Tripped at this step)	Manual	0.0 1509.3	* N/A * * N/A *	0.0 1739.4
- 15 -	E-1-11	---	Start one CHARGING pump. (CHARGING pump 31 is running.) (No Loads Started or Tripped at this step)	Manual	0.0 1509.3	* N/A * * N/A *	0.0 1739.4
- 16 -	< 12 >	---	*** GO TO ES-1.1, SI TERMINATION *** (No Loads Started or Tripped at this step)	Manual	0.0 1509.3	* N/A * * N/A *	0.0 1739.4
- 17 -	ES-1.1-4	---	Stop RHR pump. (Only pump 22 running - stopped.) Stop SI pumps. (Only pumps 31 and 33 running - stopped.) -120 -121 -123	Manual	-327.2 1182.1	* N/A * * N/A *	-509.2 1230.2
- 18 -	ES-1.1-8	---	Start one CHARGING pump. (CHARGING pump 31 is running.) (No Loads Started or Tripped at this step)	Manual	0.0 1182.1	* N/A * * N/A *	0.0 1230.2

STEAM BREAK (FH B)

Report Date : August 25, 2009 Time : 3:53 PM (27)


Step Number	Sk0 Scop	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	ES-1.1-10	---	Stop CSPs if 5 FCUs are running or Containment pressure is < 16 PSIG. (No Loads Started or Tripped at this step)	Manual	0.0 1182.1	* N/A * * N/A *	0.0 1239.2
- 20 -	ES-1.1-10	---	Check BAST transfer pumps are running (MCC 36A-E never striped.) (No Loads Started or Tripped at this step)	Manual	0.0 1182.1	* N/A * * N/A *	0.0 1239.2
- 21 -	NSE 99-3-075	NSE 99-3-075	AS PER SECTION 4.2.20 of NSB One CSP run time is less than 30 minutes. (CSPs stopped.) -24 -25	Manual	-307.3 874.8	* N/A * * N/A *	-319.5 910.7
- 22 -	ES-1.1-17	---	Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Pressurizer Heater Control Group energized on lightest loaded Bus.) +109	Manual	207.9 1082.7	* N/A * * N/A *	0.0 910.7
- 23 -	ES-1.1-19	---	Reset MCCs. Start CRDM Fans (MCC are already reset. CRDM Fans started on MCC 3R.) +70 +71 +72 +73	Manual	80.4 1163.1	* N/A * * N/A *	0.0 910.7
- 24 -	---	RO-1-27c	START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Bus 2A/3A unavailable.) (No Loads Started or Tripped at this step)	Manual	0.0 1163.1	* N/A * * N/A *	0.0 910.7
- 25 -	ES-1.1-20	---	Stop 1 of 3 ESOWPs. (ESOWPs 34 and 35 are running.) Shutdown Motor-driven APWPs if desired. (Bus 2A/3A not available. APWP 33 remains running.) (No Loads Started or Tripped at this step)	Manual	0.0 1163.1	* N/A * * N/A *	0.0 910.7
- 26 -	ES-1.1-26	---	Check that at least two NESOWPs are running. (NESOWP 31 and 33 started.) +84 +86	Manual	280.8 1443.9	* N/A * * N/A *	280.8 1191.5
- 27 -	ES-1.1-27	---	Start a PAB Fan, Penetration Blowers and CCR ventilation. (Bus 2A/3A unavailable. PAB Fan 22 started. Blowers started, CCR ventilation is running.) +88 +86 +87	Manual	0.0 1443.9	* N/A * * N/A *	144.3 1335.8

STEAM BREAK (PH B)

Report Date : August 25, 2009 Time : 3:53 PM [27]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A	Bus 2A/3A	Bus 6A
					Step Load/Load (kW)	Step/Total Load (kW)	Step/Total Load (kW)
28	ES-1.1-32	---	Go to appropriate plant operating procedure as directed by the CRS or SM.	Manual	0.0	* N/A *	0.0
			(No Loads Started or Tripped at this step)		1443.9	* N/A *	1335.8

STEAM BREAK (PH B)



Steam Break (PH B)
 Buses 2A and / or 3A Not Available
 Loss of Off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

AFWP 33	EDG 32
CHARGING PUMP 31	EDG 33
ESWP 34	EDG 33
ESWP 36	EDG 32
FCU 31	EDG 33
FCU 33	EDG 33
FCU 35	EDG 32
MCC 36A: AUTO	EDG 33
MCC 36B: AUTO	EDG 32
MCC 36D: AUTO	EDG 32
MCC 36E: AUTO	EDG 33
MCC 37: PENT. BLOWER (#1)	EDG 32
MCC 37: PENT. BLOWER (#2)	EDG 32
MCC 38: CRDM FAN 31 (FAN#1)	EDG 33
MCC 38: CRDM FAN 32 (FAN#2)	EDG 33
MCC 38: CRDM FAN 33 (FAN#3)	EDG 33
MCC 38: CRDM FAN 34 (FAN#4)	EDG 33
MCCS RESET (5A) AS PER SOP-EL-15	EDG 33
MCCS RESET (6A) AS PER SOP-EL-15	EDG 32
NESWP 31	EDG 33
NESWP 33	EDG 32
PAB FAN 32	EDG 32
PRESSURIZER HEATER 33	EDG 33

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

STEAM BREAK
ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:54 PM

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2180.8 Bus 2A = 2129.2 Bus 3A = 1714.9 Bus 6A = 2367.0 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A/3A is below the 3200 Amp rating
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

STEAM BREAK - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 30, 2009 Time : 3:54 PM [45]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36A, 36B, 36C, 36D and 36E	Auto	169.5	135.5	0.0	150.1
					169.5	135.5	0.0	150.1
- 2 -	---	RO-1-2	+57 +50 +53 +59 +60 SI pumps 31, 32 and 33 RHR pumps 31 and 32 (mini flow, RCS press > 325) {RO verifies that pumps are running.}	Auto	472.4	472.4	264.5	738.5
					641.9	607.9	264.5	888.6
- 3 -	E-0-9	---	+117 +120 +121 +122 +123 CSPs 31 and 32 {CSPs started during Phase B only.} {E-0-9 verifies that spray is not required.}	Manual	0.0	0.0	0.0	0.0
			{No Loads Started or Tripped at this step}		641.9	607.9	264.5	888.6
- 4 -	---	RO-1-3	FCUs 31, 32, 33, 34 and 35 {RO verifies that fans are running.}	Auto	491.9	247.2	246.0	248.0
					1133.8	855.1	510.5	1136.6
- 5 -	---	RO-1-5	+29 +31 +33 +35 +37 AFWPs 31 and 33 {RO verifies that pumps are running.}	Auto	0.0	0.0	575.4	562.9
					1133.8	855.1	1085.9	1699.5
- 6 -	---	RO-1-7	+1 +2 CCWPs 31, 32 and 33 {RO verifies that pumps are running.}	Auto	250.5	251.3	0.0	251.2
					1384.3	1106.4	1085.9	1950.7
- 7 -	---	RO-1-8	+4 +7 +10 ESWPs (34, 35 and 35) {RO verifies that pumps are running.}	Auto	429.8	0.0	429.0	429.8
					1814.1	1106.4	1514.9	2380.5
- 8 -	E-0-11	---	+26 +27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {CHARGING pump 32 started on lightest loaded Bus.}	Manual	0.0	0.0	208.9	0.0
					1814.1	1106.4	1723.8	2380.5
- 9 -	< 35 >	---	+14 *** FAULTED STEAM GENERATOR *** *** EVENT IDENTIFIED - EXIT TO E-2 ***	Manual	0.0	0.0	0.0	0.0
			{No Loads Started or Tripped at this step}		1814.1	1106.4	1723.8	2380.5

STEAM BREAK - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:54 PM [45]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	< 6 >	---	*** GO TO E-1 AT THE COMPLETION OF E-2 ***	Manual	0.0	0.0	0.0	0.0
			(No Loads Started or Tripped at this step)		1814.1	1106.4	1723.8	2380.5
- 11 -	E-1-4	---	Reset SI (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0	0.0	0.0	0.0
			(No Loads Started or Tripped at this step)		1814.1	1106.4	1723.8	2380.5
- 12 -	---	RO-1-15	RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset.)	Manual	659.8	843.0	507.6	252.2
					2473.9	1954.4	2231.4	2633.7
- 13 -	E-1-8	---	+126 +124 +125 +127 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	0.0	0.0	0.0
					2473.9	1954.4	2231.4	2632.7
- 14 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (CHARGING pump 32 is running.)	Manual	0.0	0.0	0.0	0.0
					2473.9	1954.4	2231.4	2632.7
- 15 -	< 12 >	---	(No Loads Started or Tripped at this step) *** GO TO ES-1.1, SI TERMINATION ***	Manual	0.0	0.0	0.0	0.0
					2473.9	1954.4	2231.4	2632.7
- 16 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (All RHR pumps stopped.) Stop SI pumps. (All SI pumps stopped.)	Manual	-472.4	-472.4	-264.5	-728.5
					2001.5	1482.0	1966.9	1894.2
- 17 -	ES-1.1-8	---	-117 -120 -121 -122 -123 Start one CHARGING pump. (CHARGING pump 32 is running.)	Manual	0.0	0.0	0.0	0.0
					2001.5	1482.0	1966.9	1894.2
- 18 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs. (Spray not actuated. No pumps are running.)	Manual	0.0	0.0	0.0	0.0
					2001.5	1482.0	1966.9	1894.2
			(No Loads Started or Tripped at this step)					

STEAM BREAK - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:54 PM (45)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
19	ES-1.1-13	---	Check BAST transfer pumps are running. (MCC 36A-E never striped.)	Manual	0.0	0.0	0.0	0.0
					2001.5	1482.0	1966.9	1894.2
20	ES-1.1-17	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group. as per SOP-EL-15. (Energized Pressurizer Heater Group 32 on lightest loaded Bus.)	Manual	0.0	540.3	0.0	0.0
					2001.5	2022.3	1966.9	1894.2
21	ES-1.1-19	---	+98 Reset MCCs. Start CRDM Fans (MCCs are already reset. CRDM Fan loads accounted for in MCC resets.)	Manual	0.0	0.0	0.0	0.0
					2001.5	2022.3	1966.9	1894.2
22	---	RO-1-27c	(No Loads Started or Tripped at this step) START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.)	Manual	0.0	63.8	0.0	0.0
					2001.5	2086.1	1966.9	1894.2
23	ES-1.1-20	---	+47 Stop 1 of 3 CCWPs. Stop 1 of 3 ESWPs and Shutdown Motor-driven AFWPs if desired. (First CCWP 31 and then ESWP 35 stopped on heaviest loaded Buses. AFWPs remain running.)	Manual	-250.5	43.1	-429.0	43.0
					1751.0	2129.2	1537.9	1937.2
24	ES-1.1-26	---	+8 +11 -4 -7 -10 -27 Check that at least two NESWPs are running. (NESWP 31 and 33 started on lightest loaded Bus.)	Manual	429.8	0.0	0.0	429.8
					2180.8	2129.2	1537.9	2367.0
25	ES-1.1-27	---	+84 +86 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 31 started on lightest loaded Bus. Blowers and CCR ventilation started at MCC reset.)	Manual	0.0	0.0	177.0	0.0
					2180.8	2129.2	1714.9	2367.0
26	ES-1.1-32	---	+87 Go to appropriate plant operating procedure as directed by the CRS or SM.	Manual	0.0	0.0	0.0	0.0
					2180.8	2129.2	1714.9	2367.0
			(No Loads Started or Tripped at this step)					

STEAM BREAK



Steam Break
 Total MCC and Lighting Reset
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 31	3A
AFWP 33	6A
CCWP 32	2A
CCWP 33	6A
CHARGING PUMP 32	3A
ESWP 35	31
ESWP 36	6A
FCU 32	2A
FCU 33	5A
FCU 34	3A
FCU 35	6A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36A: AUTO	5A
MCC 36B: AUTO	6A
MCC 36C: AUTO	2A
MCC 36D: AUTO	6A
MCC 36E: AUTO	5A
NESWP 31	5A
NESWP 33	6A
PAB FAN 31	3A
PRESSURIZER HEATER 32	2A
TOTAL MCC & LIGHTING RESET (2A)	
TOTAL MCC & LIGHTING RESET (3A)	
TOTAL MCC & LIGHTING RESET (5A)	
TOTAL MCC & LIGHTING RESET (6A)	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1
IP3-CALC-ED-00207 REV 8

STEAM BREAK

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:53 PM

*** BUSES 2A AND 3A TIED TOGETHER ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2252.9 Bus 2A/3A = 2533.1 Bus 6A = 2422.8 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A/3A is below the 3200 Amp rating
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

STEAM BREAK

Report Date : August 25, 2009 Time : 3:53 PM [28]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36A, 36B, 36C, 36D and 36E	Auto	169.5	135.5	150.1
					169.5	135.5	150.1
- 2 -	---	RO-1-2	+57 +50 +53 +59 +60 SI pumps 31, 32 and 33 RHR pumps 31 and 32 (mini flow, RCS press > 325) {RO verifies that pumps are running.}	Auto	472.4	736.9	736.5
					641.9	872.4	888.6
- 3 -	E-0-9	---	+117 +120 +121 +122 +123 CSPs 31 and 32 (Spray not required. CSPs started during Phase B only.) {E-0-9 verifies that pumps are not running.}	Manual	0.0	0.0	0.0
					641.9	872.4	888.6
- 4 -	---	RO-1-3	{No Loads Started or Tripped at this step} FCUs 31, 32, 33, 34 and 35 {RO verifies that fans are running.}	Auto	491.9	423.2	248.0
					1133.8	1365.6	1136.6
- 5 -	---	RO-1-5	-29 -31 +33 +35 +37 AFWPs 31 and 33 {RO verifies that pumps are running.}	Auto	0.0	575.4	562.9
					1133.8	1941.0	1699.5
- 6 -	---	RO-1-7	+1 +2 CCWPs 31, 32 and 33 {RO verifies that pumps are running.}	Auto	250.5	251.3	251.2
					1384.3	2192.3	1950.7
- 7 -	---	RO-1-8	+4 +7 +10 ESWPs (34, 35 and 36) {RO verifies that pumps are running.}	Auto	429.8	429.0	423.8
					1814.1	2621.3	2380.5
- 8 -	E-0-11	---	+26 +27 +28 Start one CHARGING pump if RCS pressure is > than 325 psia and CCW is available. {CHARGING pump 31 started on lightest loaded Bus.}	Manual	208.5	0.0	0.0
					2022.6	2621.3	2380.5
- 9 -	< 15 >	---	-13 *** FAULTED STEAM GENERATOR *** *** EVENT IDENTIFIED - EXIT TO E-2 *** {No Loads Started or Tripped at this step}	Manual	0.0	0.0	0.0
					2022.6	2621.3	2380.5

STEAM BREAK

Report Date : August 25, 2009 Time : 3:53 PM (28)


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	< 6 >	---	*** GO TO E-1 AT THE COMPLETION OF E-2 ***	Manual	0.0	0.0	0.0
			(No Loads Started or Tripped at this step)		2022.6	2621.3	2380.5
- 11 -	E-1-4	---	Reset SI (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0	0.0	0.0
			(No Loads Started or Tripped at this step)		2022.6	2621.3	2380.5
- 12 -	---	RO-1-15	RESET MCCs as per SGP-EL-15. (Total MCC and Lighting reset.)	Manual	659.8	407.2	252.2
			(No Loads Started or Tripped at this step)		2682.4	3028.5	2632.7
- 13 -	E-1-8	---	+126 +127 +3 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	0.0	0.0
			(No Loads Started or Tripped at this step)		2682.4	3028.5	2632.7
- 14 -	E-1-11	---	Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	0.0	0.0
			(No Loads Started or Tripped at this step)		2682.4	3028.5	2632.7
- 15 -	< 12 >	---	*** GO TO ES-1.1, SI TERMINATION ***	Manual	0.0	0.0	0.0
			(No Loads Started or Tripped at this step)		2682.4	3028.5	2632.7
- 16 -	ES-1.1-4	---	Stop RHR pumps. (All RHR pumps stopped.) Stop SI pumps. (All SI pumps stopped.)	Manual	-472.4	-736.9	-738.5
			(No Loads Started or Tripped at this step)		2210.0	2291.6	1894.2
- 17 -	ES-1.1-8	---	-117 -120 -121 -122 -123 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	0.0	0.0
			(No Loads Started or Tripped at this step)		2210.0	2291.6	1894.2
- 18 -	ES-1.1-10	---	Stop CSPs. (Spray not actuated. No pumps are running.)	Manual	0.0	0.0	0.0
			(No Loads Started or Tripped at this step)		2210.0	2291.6	1894.2

STEAM BREAK

Report Date : August 25, 2009 Time : 3:53 PM (28)

Step Number	SKO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	ES-1.1-13	---	Check BAST transfer pumps are running. (MCC 36A-E never striped.)	Manual	0.0	0.0	0.0
					2210.0	2291.6	1894.2
- 20 -	ES-1.1-17	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group. as per SOP-EL-15. (Energized Pressurizer Heater Control Group on lightest loaded Bus.)	Manual	0.0	0.0	308.6
					2210.0	2291.6	2202.8
- 21 -	ES-1.1-19	---	+114 Reset MCCs. Start CRDM fans. (MCCs are already reset. CRDM Fan loads accounted for in MCC resets.)	Manual	0.0	0.0	0.0
					2210.0	2291.6	2202.8
- 22 -	---	RO-1-27c	(No Loads Started or Tripped at this step) START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.)	Manual	0.0	63.8	0.0
					2210.0	2355.4	2202.8
- 23 -	ES-1.1-20	---	+47 Stop 1 of 3 CCWPs. Stop 1 of 3 ESWPs and Shutdown Motor-driven AFWPs if desired. (First CCWP 32 and then ESWP 34 stopped on heaviest loaded Buses. AFWPs remain running.)	Manual	-386.9	-251.3	43.0
					1823.1	2104.1	2245.8
- 24 -	ES-1.1-26	---	+5 +11 -4 -7 -10 -26 Check that at least two NESWPs are running. (NESWP 31 and 32 started on lightest loaded Bus.)	Manual	429.8	429.0	0.0
					2252.9	2533.1	2245.8
- 25 -	ES-1.1-27	---	+84 +85 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 32 started on lightest loaded Bus. Blowers and CCR vent. started at MCC reset.)	Manual	0.0	0.0	177.0
					2252.9	2533.1	2422.8
- 26 -	ES-1.1-32	---	+88 Go to appropriate plant operating procedure as directed by the CRS or SM.	Manual	0.0	0.0	0.0
					2252.9	2533.1	2422.8
			(No Loads Started or Tripped at this step)				

STEAM BREAK



Steam Break
 Buses 2A/3A Tied Together, All Buses Available
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 31	3A
AFWP 33	6A
CCWP 31	5A
CCWP 33	6A
CHARGING PUMP 31	5A
ESWP 35	3A
ESWP 36	6A
FCU 31	5A
FCU 32	2A
FCU 33	5A
FCU 34	3A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36A: AUTO	5A
MCC 36B: AUTO	6A
MCC 36C: AUTO	2A
MCC 36D: AUTO	6A
MCC 36E: AUTO	5A
NESWP 31	5A
NESWP 32	2A
PAB FAN 32	6A
PRESSURIZER HEATER CONTROL GROUP	6A
TOTAL MCCS & LIGHTING RESET BUS 5A	
TOTAL MCCS & LIGHTING RESET BUS 6A	
MCCS RESET (2A/3A) AS PER SOP-EL-15	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

1P3-CALC-ED-00207 REV 8

STEAM BREAK

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:53 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 6A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2914.3 Bus 2A/3A = 3004.5 Bus 6A = * N/A * (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A/3A is below the 3200 Amp rating
Bus 6A Not Available

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A Not Available

STEAM BREAK

Report Date : August 25, 2009 Time : 3:53 PM (29)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36A, 36C and 36E	Auto	169.5	135.5	* N/A *
					169.5	135.5	* N/A *
- 2 -	---	RO-1-2	+57 +50 +60 SI pumps 31 and 32 RHR pump 31 (mini flow, RCS press > 325) {RO verifies that pumps are running.}	Auto	472.4	736.9	* N/A *
					641.9	872.4	* N/A *
- 3 -	E-0-9	---	+117 +121 +122 CSP 31 (Spray not required. CSPs started during Phase B only.) {E-0-9 verifies that pumps are not running.}	Manual	0.0	0.0	* N/A *
					641.9	872.4	* N/A *
- 4 -	---	RO-1-3	{No Loads Started or Tripped at this step} FCUs 31, 32, 33 and 34 {RO verifies that fans are running.}	Auto	491.9	493.2	* N/A *
					1133.8	1365.6	* N/A *
- 5 -	---	RO-1-5	+29 +31 +33 +35 AFWP 31 {RO verifies that pump is running.}	Auto	0.0	575.4	* N/A *
					1133.8	1941.0	* N/A *
- 6 -	---	RO-1-7	+1 CCWPs 31 and 32 {RO verifies that pumps are running.}	Auto	293.4	294.4	* N/A *
					1427.2	2235.4	* N/A *
- 7 -	---	RO-1-8	+4 +7 ESWPs (34 and 35) {RO verifies that pumps are running.}	Auto	429.8	429.0	* N/A *
					1857.0	2664.4	* N/A *
- 8 -	E-0-11	---	+26 +27 Start one CHARGER pump if RCS pressure is > than 325 psig and CCW is available. {CHARGING pump 31 started on lightest loaded Bus.}	Manual	208.5	0.0	* N/A *
					2065.5	2664.4	* N/A *
- 9 -	< 15 >	---	+13 *** FAULTED STEAM GENERATOR *** *** EVENT IDENTIFIED - EXIT TO E-2 *** {No Loads Started or Tripped at this step}	Manual	0.0	0.0	* N/A *
					2065.5	2664.4	* N/A *

STEAM BREAK

Report Date : August 25, 2009 Time : 3:53 PM [29]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	< 6 >	---	*** GO TO E-1 AT THE COMPLETION OF E-2 ***	Manual	0.0	0.0	* N/A *
			(No Loads Started or Tripped at this step)		2065.5	2664.4	* N/A *
- 11 -	E-1-4	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0	0.0	* N/A *
					2065.5	2664.4	* N/A *
- 12 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset.)	Manual	659.8	407.2	* N/A *
					2725.3	3071.6	* N/A *
- 13 -	E-1-8	---	+126 +3 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	0.0	* N/A *
					2725.3	3071.6	* N/A *
- 14 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	0.0	* N/A *
					2725.3	3071.6	* N/A *
- 15 -	< 12 >	---	(No Loads Started or Tripped at this step) *** GO TO ES-1.1, SI TERMINATION ***	Manual	0.0	0.0	* N/A *
					2725.3	3071.6	* N/A *
- 16 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (Only pump 31 running-stopped.) Stop SI pumps. (Only pumps 31 and 32 running - stopped.)	Manual	-472.4	-736.9	* N/A *
					2352.9	2334.7	* N/A *
- 17 -	ES-1.1-8	---	-117 -121 -122 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	0.0	* N/A *
					2352.9	2334.7	* N/A *
- 18 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs. (Spray not actuated. No pumps are running.)	Manual	0.0	0.0	* N/A *
					2352.9	2334.7	* N/A *
			(No Loads Started or Tripped at this step)				

STEAM BREAK

Report Date : August 25, 2009 Time : 3:53 PM [29]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	ES-1.1-13	---	Check BAST transfer pumps are running. (MCC 36A-E never stripped.)	Manual	0.0 2252.9	0.0 2334.7	* N/A * * N/A *
- 20 -	ES-1.1-17	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group. as per SOP-EL-15. (Energized Pressurizer Heater Group 33 on lightest loaded Bus.)	Manual	231.6 2484.5	0.0 2334.7	* N/A * * N/A *
- 21 -	ES-1.1-19	---	+109 Reset MCCs. Start CRDM Fans. (MCCs are already reset. CRDM Fan loads accounted for in MCC resets.)	Manual	0.0 2484.5	0.0 2334.7	* N/A * * N/A *
- 22 -	---	RO-1-27c	(No Loads Started or Tripped at this step) START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.)	Manual	0.0 2484.5	63.8 2398.5	* N/A * * N/A *
- 23 -	ES-1.1-20	---	+47 Stop 1 of 3 CCWPs. (CCWPs 31 and 32 running.) Stop 1 of 3 ESWPs. (ESWPs 34 and 35 running.) Shutdown Motor-driven AFWPs if desired. (Bus 6A not available. AFWP 31 remains running.)	Manual	0.0 2484.5	0.0 2398.5	* N/A * * N/A *
- 24 -	ES-1.1-26	---	(No Loads Started or Tripped at this step) Check that at least two NESWPs are running. (NESWP 31 and 32 started)	Manual	429.8 2914.3	429.0 2827.5	* N/A * * N/A *
- 25 -	ES-1.1-27	---	+84 +85 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 31 started. Blowers unavailable, powered from Bus 6A/MCC27, CCR vent. started.)	Manual	0.0 2914.3	177.0 3004.5	* N/A * * N/A *
- 26 -	ES-1.1-32	---	+87 Go to appropriate plant operating procedure as directed by the CRS or SM.	Manual	0.0 2914.3	0.0 3004.5	* N/A * * N/A *
			(No Loads Started or Tripped at this step)				

STEAM BREAK



Steam Break
 Buses 2A/3A Tied Together, Bus 6A Not Available
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 31	3A
CCWP 31	5A
CCWP 32	2A
CHARGING PUMP 31	5A
ESWP 34	5A
ESWP 35	3A
FCU 31	5A
FCU 32	2A
FCU 33	5A
FCU 34	3A
MCC 34: TURBINE TURNING GEAR	3A
MCC 36A: AUTO	5A
MCC 36C: AUTO	2A
MCC 36E: AUTO	5A
NESWP 31	5A
NESWP 32	2A
PAB FAN 31	3A
PRESSURIZER HEATER 33	5A
TOTAL MCCS & LIGHTING RESET BUS 5A	
MCCS RESET (2A/3A) AS PER SOP-EL-15	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1
EP3-CALC-ED-00207 REV B

STEAM BREAK

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:53 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 5A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = * N/A * Bus 2A/3A = 2827.5 Bus 6A = 3062.2 (A)

3200 Amp Overload Summary

Bus 5A Not Available
Bus 2A/3A is below the 3200 Amp rating
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A Not Available
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

STEAM BREAK

Report Date : August 25, 2009 Time : 3:53 PM (39)

Step Number	SRO Step	RO Step	Leading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36B, 36C and 36D	Auto	* N/A *	135.5	159.1
					* N/A *	135.5	150.1
- 2 -	---	RO-1-2	-57 +53 +59 SI pumps 32 and 33 RHR pumps 31 and 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	* N/A *	736.9	738.5
					* N/A *	872.4	888.6
- 3 -	E-0-9	---	+117 +120 +122 +123 CSP 32 (Spray not required. CSPs started during Phase B only.) (E-0-9 verifies that pump is not running.)	Manual	* N/A *	0.0	0.0
					* N/A *	872.4	888.6
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCUs 32, 34 and 35 (RO verifies that fans are running.)	Auto	* N/A *	493.2	248.0
					* N/A *	1365.6	1136.6
- 5 -	---	RO-1-5	+31 +35 +37 AFWPs 31 and 33 (RO verifies that pumps are running.)	Auto	* N/A *	575.4	562.9
					* N/A *	1941.0	1699.5
- 6 -	---	RO-1-7	+1 +2 CCWPs 32 and 33 (RO verifies that pumps are running.)	Auto	* N/A *	294.4	294.2
					* N/A *	2235.4	1993.7
- 7 -	---	RO-1-8	+7 +10 ESWPs (35 and 36) (RO verifies that pumps are running.)	Auto	* N/A *	429.0	429.8
					* N/A *	2664.4	2423.5
- 8 -	E-0-11	---	+27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 33 started on lightest loaded Bus.)	Manual	* N/A *	0.0	209.6
					* N/A *	2664.4	2633.1
- 9 -	< 15 >	---	+15 *** FAULTED STEAM GENERATOR *** *** EVENT IDENTIFIED - EXIT TO E-2 *** (No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
					* N/A *	2664.4	2633.1

STEAM BREAK

Report Date : August 25, 2009 Time : 3:53 PM [30]


Step Number	SPO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	< 6 >	---	*** GO TO E-1 AT THE COMPLETION OF E-2 *** (No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
			Reset SI (Steps 2 through 12 of RO-1 are completed.)		* N/A *	2664.4	2633.1
- 11 -	E-1-4	---	(No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
			Reset SI (Steps 2 through 12 of RO-1 are completed.)		* N/A *	2664.4	2633.1
- 12 -	---	RO-1-15	(No Loads Started or Tripped at this step)	Manual	* N/A *	407.2	252.2
			RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset.)		* N/A *	3071.6	2835.3
- 13 -	E-1-8	---	+127 +3 ESTABLISH Instrument Air to Containment. (load accounted for in MCC reset.)	Manual	* N/A *	0.0	0.0
					* N/A *	3071.6	2885.3
- 14 -	E-1-11	---	(No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
			Start one CHARGING pump. (Charging pump 33 is running.)		* N/A *	3071.6	2885.3
- 15 -	< 12 >	---	(No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
			*** GO TO ES-1.1, SI TERMINATION ***		* N/A *	3071.6	2885.3
- 16 -	ES-1.1-4	---	(No Loads Started or Tripped at this step)	Manual	* N/A *	-736.9	-738.5
			Stop RHR pumps. (All RHR pumps stopped.) Stop SI pumps. (Only pumps 32 and 33 running-stopped.)		* N/A *	2334.7	2146.8
- 17 -	ES-1.1-8	---	-117 -120 -122 -123 Start one CHARGING pump. (CHARGING pump 33 is running.)	Manual	* N/A *	0.0	0.0
					* N/A *	2334.7	2146.8
- 18 -	ES-1.1-10	---	(No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
			Stop CSPs. (Spray not actuated. No pumps are running.)		* N/A *	2334.7	2146.8
			(No Loads Started or Tripped at this step)				

STEAM BREAK

Report Date : August 25, 2009 Time : 3:53 PM (30)

Step Number	SRG Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	ES-1.1-13	---	Check BAST transfer pumps are running. (MCC 36A-E never striped.)	Manual	* N/A *	0.0	0.0
					* N/A *	2334.7	2146.8
- 20 -	ES-1.1-17	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group. as per SOP-6L-15. (Energized Pressurizer Heater Control Group on lightest loaded Bus.)	Manual	* N/A *	0.0	308.6
					* N/A *	2334.7	2455.4
- 21 -	ES-1.1-19	---	+114 Reset MCCs. Start CRDM Fans (MCCs are already reset. CRDM Fans unavailable, power from Bus 5A/MCC 35.)	Manual	* N/A *	0.0	0.0
					* N/A *	2334.7	2455.4
- 22 -	---	RO-1-27c	(No Loads Started or Tripped at this step) START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.) +47	Manual	* N/A *	63.8	0.0
					* N/A *	2398.5	2455.4
- 23 -	ES-1.1-20	---	Stop 1 of 3 CCWPs. (CCWPs 32 and 33 running.) Stop 1 of 3 ESWPs. (ESWPs 35 and 36 running.) Shutdown Motor-driven APWPs if desired. (APWPs remain running.)	Manual	* N/A *	0.0	0.0
					* N/A *	2398.5	2455.4
- 24 -	ES-1.1-26	---	(No Loads Started or Tripped at this step) Check that at least two NESWPs are running. (NESWP 32 and 33 started.)	Manual	* N/A *	429.0	429.8
					* N/A *	2827.5	2885.2
- 25 -	ES-1.1-27	---	+85 +56 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 32 started on lightest loaded Bus. Blowers and CCR vent. at MCC reset.) +88	Manual	* N/A *	0.0	177.0
					* N/A *	2827.5	3062.2
- 26 -	ES-1.1-32	---	Go to appropriate plant operating procedure as directed by the CRS or SM.	Manual	* N/A *	0.0	0.0
					* N/A *	2827.5	3062.2
			(No Loads Started or Tripped at this step)				

STEAM BREAK



Steam Break
 Buses 2A/3A Tied Together, Bus 5A Not Available
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 31	3A
AFWP 33	6A
CCWP 32	2A
CCWP 33	6A
CHARGING PUMP 33	6A
ESWP 35	3A
ESWP 36	6A
FCU 32	2A
FCU 34	3A
FCU 35	6A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36B: AUTO	6A
MCC 36C: AUTO	2A
MCC 36D: AUTO	6A
NESWP 32	2A
NESWP 33	6A
PAB FAN 32	6A
PRESSURIZER HEATER CONTROL GROUP	6A
MCCS RESET (2A/3A) AS PER SOP-EL-15	
TOTAL MCCS & LIGHTING RESET BUS 6A	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

STEAM BREAK

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:53 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 2A AND/OR 3A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2632.7 Bus 2A/3A = * N/A * Bus 6A = 2952.6 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A and/or 3A Not Available
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A and/or 3A Not Available
Bus 6A is below the 3600 Amp rating

STEAM BREAK

Report Date : August 25, 2009 Time : 3:53 PM [31]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36A, 36B, 36D and 36E	Auto	169.5	* N/A *	150.1
					169.5	* N/A *	150.1
- 2 -	---	RO-1-2	+50 +53 +59 +60 SI pumps 31 and 33 RHR pump 32 (mini flow, RCS press > 325) {RO verifies that pumps are running.}	Auto	472.4	* N/A *	738.5
					641.9	* N/A *	888.6
- 3 -	E-0-9	---	+120 +121 +123 CSPs 31 and 32 (Spray not required. CSPs started during phase B only.) {E-0-9 verifies that pumps are not running.}	Manual	0.0	* N/A *	0.0
					641.9	* N/A *	888.6
- 4 -	---	RO-1-3	{No Loads Started or Tripped at this step} FCUs 31, 33 and 35 {RO verifies that fans are running.}	Auto	491.9	* N/A *	248.0
					1133.8	* N/A *	1136.6
- 5 -	---	RO-1-5	+29 +33 +37 AFWP 33 {RO verifies that pump is running.}	Auto	0.0	* N/A *	562.9
					1133.8	* N/A *	1699.5
- 6 -	---	RO-1-7	+2 CCWPs 31 and 33 {RO verifies that pumps are running.}	Auto	293.4	* N/A *	294.2
					1427.2	* N/A *	1993.7
- 7 -	---	RO-1-8	+4 +10 ESWPs (34 and 36) {RO verifies that pumps are running.}	Auto	429.8	* N/A *	429.8
					1857.0	* N/A *	2423.5
- 8 -	E-0-11	---	+25 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {CHARGING pump 31 started on lightest loaded Bus.}	Manual	208.5	* N/A *	0.0
					2065.5	* N/A *	2423.5
- 9 -	< 15 >	---	+13 *** FAULTED STEAM GENERATOR *** *** EVENT IDENTIFIED - EXIT TO E-2 *** {No Loads Started or Tripped at this step}	Manual	0.0	* N/A *	0.0
					2065.5	* N/A *	2423.5

STEAM BREAK

Report Date : August 25, 2009 Time : 3:53 PM [31]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	< 8 >	---	*** GO TO E-1 AT THE COMPLETION OF E-2 ***	Manual	0.0	* N/A *	0.0
					2065.5	* N/A *	2423.5
- 11 -	E-1-4	---	(No Loads Started or Tripped at this step) Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0	* N/A *	0.0
					2065.5	* N/A *	2423.5
- 12 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset.)	Manual	659.8	* N/A *	252.2
					2725.3	* N/A *	2675.7
- 13 -	E-1-8	---	+126 +127 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	* N/A *	0.0
					2725.3	* N/A *	2675.7
- 14 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	* N/A *	0.0
					2725.3	* N/A *	2675.7
- 15 -	< 12 >	---	(No Loads Started or Tripped at this step) *** GO TO ES-1.1, SI TERMINATION ***	Manual	0.0	* N/A *	0.0
					2725.3	* N/A *	2675.7
- 16 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (Only pump 32 running - stopped.) Stop SI pumps. (Only pumps 31 and 33 running - stopped.)	Manual	-472.4	* N/A *	-738.5
					2252.9	* N/A *	1937.2
- 17 -	ES-1.1-8	---	-120 -121 -123 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	* N/A *	0.0
					2252.9	* N/A *	1937.2
- 18 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs. (Spray not actuated. No pumps are running.)	Manual	0.0	* N/A *	0.0
					2252.9	* N/A *	1937.2
			(No Loads Started or Tripped at this step)				

STEAM BREAK

Report Date : August 25, 2009 Time : 3:53 PM [31]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	ES-1.1-13	---	Check BAST transfer pumps are running. (NCC 36A-E never striped.)	Manual	0.0 2252.9	* N/A * * N/A *	0.0 1937.2
- 20 -	ES-1.1-17	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group. (Energized Pressurizer Heater Control Group on lightest loaded Bus.)	Manual	0.0 2252.9	* N/A * * N/A *	308.6 2245.8
- 21 -	ES-1.1-19	---	+114 Reset NCCs. Start CRDM Fans. (MCC are already reset. CRDM Fan Loads accounted for in MCC resets.)	Manual	0.0 2252.9	* N/A * * N/A *	0.0 2245.8
- 22 -	---	RO-1-27c	(No Loads Started or Tripped at this step) START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Bus 2A/3A unavailable.)	Manual	0.0 2252.9	* N/A * * N/A *	0.0 2245.8
- 23 -	ES-1.1-20	---	(No Loads Started or Tripped at this step) Step 1 of 3 CCWPs. (CCWPs 31 and 33 running.) Step 1 of 3 ESWPs. (ESWPs 34 and 36 running.) Shutdown Motor-driven AFWPs if desired. (Bus 2A/3A not available. AFWP 33 remains running.)	Manual	0.0 2252.9	* N/A * * N/A *	0.0 2245.8
- 24 -	ES-1.1-26	---	(No Loads Started or Tripped at this step) Check that at least two NESWPs are running. (NESWP 31 and 33 started.)	Manual	429.8 2682.7	* N/A * * N/A *	429.8 2675.6
- 25 -	ES-1.1-27	---	+84 +86 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 32 started. Blowers and CCR ventilation started at MCC reset.)	Manual	0.0 2682.7	* N/A * * N/A *	177.0 2852.6
- 26 -	ES-1.1-32	---	+88 Go to appropriate plant operating procedure as directed by the CRS or SM. (No Loads Started or Tripped at this step)	Manual	0.0 2682.7	* N/A * * N/A *	0.0 2852.6

STEAM BREAK



Steam Break
 Buses 2A and / or 3A Not Available
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 33	6A
CCWP 31	5A
CCWP 33	6A
CHARGING PUMP 31	5A
ESWP 34	5A
ESWP 36	6A
FCU 31	5A
FCU 33	5A
FCU 35	6A
MCC 36A: AUTO	5A
MCC 36B: AUTO	6A
MCC 36D: AUTO	6A
MCC 36E: AUTO	5A
NESWP 31	5A
NESWP 33	6A
PAB FAN 32	6A
PRESSURIZER HEATER CONTROL GROUP	6A
TOTAL MCCS & LIGHTING RESET BUS 5A	
TOTAL MCCS & LIGHTING RESET BUS 6A	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

STEAM BREAK

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:53 PM

*** BUSES 2A AND 3A TIED TOGETHER ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = 1163.1 Bus 2A/3A = 1231.1 Bus 6A = 1221.5 (kW)

1750 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1750 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1750 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1750 kW rating

1950 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1950 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1950 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating

STEAM BREAK

Report Date : August 25, 2009 Time : 3:53 PM (32)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MOC 36A, 36B, 36C, 36D and 36E	Auto	110.0 110.0	94.3 94.3	100.4 100.4
- 2 -	---	RO-1-2	+57 +50 +53 +59 +60 SI pumps 31, 32 and 33 RHR pumps 31 and 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	327.2 437.2	509.2 603.5	509.2 609.6
- 3 -	E-0-9	---	+117 +120 +121 +122 +123 CSPs 31 and 32 (Spray not required. CSPs started during Phase B only.) (E-0-9 verifies that pumps are not running.)	Manual	0.0 437.2	0.0 603.5	0.0 609.6
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCUs 31, 32, 33, 34 and 35 (RO verifies that fans are running.)	Auto	258.0 695.2	258.0 861.5	129.0 738.6
- 5 -	---	RO-1-5	+29 +31 +33 +35 +37 AFWPs 31 and 33 (RO verifies that pumps are running.)	Auto	0.0 695.2	378.9 1240.4	375.7 1114.3
- 6 -	---	RO-1-7	+1 +2 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. (All Buses are powered from EDGs.)	Manual	0.0 695.2	0.0 1240.4	0.0 1114.3
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESWPs (34, 35 and 36) (RO verifies that pumps are running.)	Auto	280.8 976.0	280.8 1521.2	280.8 1395.1
- 8 -	E-0-11	---	+26 +27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	140.2 1116.2	0.0 1521.2	0.0 1395.1
- 9 -	< 15 >	---	+13 *** FAULTED STEAM GENERATOR *** *** EVENT IDENTIFIED - EXIT TO E-2 *** (No Loads Started or Tripped at this step)	Manual	0.0 1116.2	0.0 1521.2	0.0 1395.1

STEAM BRL

Ref: 001001 25.2009 Time: 3:53 PM [32]


Step Number	SRO Step	RO Step	Loading Step Description	11	1c	AS W/ Load (kW)	A/3A Total (kW)	Bus 6A Step/Total Load (kW)
- 10 -	< 6 >	---	*** GO TO E-1 AT THE COMPLETION OF			0.0	0.0	0.0
- 11 -	E-1-4	---	(No Loads Started or Tripped at this step) Reset SI (Steps 2 through 12 of RO-1 a			119.1	2	1395.1
- 12 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SI (MCC are reset.)			85.8		24.8
- 13 -	E-1-8	---	+82 +81 +83 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual		0.0	0.0	0.0
- 14 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual		1202.0	1584.5	1419.9
- 15 -	< 12 >	---	(No Loads Started or Tripped at this step) *** GO TO ES-1.1, SI TERMINATION ***	Manual		0.0	0.0	0.0
- 16 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (RHR pumps stopped.) Stop SI pumps. (All SI pumps stopped.)	Manual		-327.2	-509.2	-509.2
- 17 -	ES-1.1-8	---	-117 -125 -121 -111 -123 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual		874.8	1075.3	910.7
- 18 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop SI pumps. (SI pumps are running.)	Manual		0.0	0.0	0.0
			(No Loads Started or Tripped at this step)			874.8	1075.3	910.7

STEAM BREAK

Report Date : August 25, 2009 Time : 3:53 PM [32]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	ES-1.1-13	---	Check BAST transfer pumps are running. (MCC 36A-E never striped.)	- Manual	0.0	0.0	0.0
					274.3	1075.3	910.7
- 20 -	ES-1.1-17	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Pressurizer Heater 33 energized on lightest loaded Bus.)	Manual	207.9	0.0	0.0
					1082.7	1075.3	910.7
- 21 -	ES-1.1-19	---	+109 Reset MCCs. Start CRDM Fans. (MCC are already reset. CRDM Fans started on MCC 38.)	Manual	80.4	0.0	0.0
					1163.1	1075.3	910.7
- 22 -	---	RO-1-27c	-70 +71 +72 +73 START AC and STOP DC Oil Pumps IF (480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.)	Manual	0.0	41.5	0.0
					1163.1	1116.8	910.7
- 23 -	ES-1.1-20	---	+47 Stop 1 of 3 ESOWPs. (ESWP 34 stopped on heaviest loaded Bus.) Shutdown Motor-driven AFWPs if desired. (AFWPs remain running.)	Manual	-280.8	0.0	0.0
					882.3	1116.8	910.7
- 24 -	ES-1.1-26	---	-26 Check that at least two RESOWPs are running. (RESOWPs 31 and 32 started on lightest loaded Buses.)	Manual	280.8	0.0	280.8
					1163.1	1116.8	1191.5
- 25 -	ES-1.1-27	---	+84 +86 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 31 started on lightest loaded Bus. Blowers started, CCR ventilation is running.)	Manual	0.0	114.3	30.0
					1163.1	1231.1	1221.5
- 26 -	ES-1.1-32	---	+87 +88 +87 Go to appropriate plant procedure as directed by the CRS or SM.	Manual	0.0	0.0	0.0
					1163.1	1231.1	1221.5
			(No Loads Started or Tripped at this step)				

STEAM BREAK



Steam Break
 Buses 2A/3A Tied Together, All Buses Available
 Loss of Off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

AFWP 31	EDG 31
AFWP 33	EDG 32
CHARGING PUMP 31	EDG 33
ESWP 35	EDG 31
ESWP 36	EDG 32
FCU 31	EDG 33
FCU 32	EDG 31
FCU 33	EDG 33
FCU 34	EDG 31
MCC 34: TURBINE TURNING GEAR	EDG 31
MCC 36A: AUTO	EDG 33
MCC 36B: AUTO	EDG 32
MCC 36C: AUTO	EDG 31
MCC 36D: AUTO	EDG 32
MCC 36E: AUTO	EDG 33
MCC 37: PENT. BLOWER (#1)	EDG 32
MCC 37: PENT. BLOWER (#2)	EDG 32
MCC 38: CRDM FAN 31 (FAN#1)	EDG 33
MCC 38: CRDM FAN 32 (FAN#2)	EDG 33
MCC 38: CRDM FAN 33 (FAN#3)	EDG 33
MCC 38: CRDM FAN 34 (FAN#4)	EDG 33
MCCS RESET (2A/3A) AS PER SOP-EL-15	EDG 31
MCCS RESET (5A) AS PER SOP-EL-15	EDG 33
MCCS RESET (6A) AS PER SOP-EL-15	EDG 32
NESWP 31	EDG 32
NESWP 33	EDG 32
PAB FAN 31	EDG 31
PRESSURIZER HEATER 33	EDG 33

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1
IP3-CALC-ED-00207 REV 8

STEAM BREAK

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:53 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 6A NOT AVAILABLE ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = 1443.9 Bus 2A/3A = 1511.9 Bus 6A = * N/A * (kW)

1750 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1750 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1750 kW rating
Bus 6A Not Available

1950 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1950 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1950 kW rating
Bus 6A Not Available

STEAM BREAK

Report Date : August 25, 2009 Time : 3:53 PM [33]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 9A Step Load/ Load (KW)	Bus 2A/3A Step/Total Load (KW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36A, 36C and 36E	Auto	110.0	94.3	* N/A *
					110.0	94.3	* N/A *
- 2 -	---	RO-1-2	+57 +50 +60 S1 pumps 31 and 32 RHR pump 31 (mini flow, RCS press > 325) {RO verifies that pumps are running.}	Auto	327.2	509.2	* N/A *
					437.2	603.5	* N/A *
- 3 -	E-0-9	---	+117 +121 +122 CSP 31 (Spray not required. CSPs started during phase B only.) {E-0-9 verifies that pump is not running.}	Manual	0.0	0.0	* N/A *
					437.2	603.5	* N/A *
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCUs 31, 32, 33 and 34 {RO verifies that fans are running.}	Auto	258.0	258.0	* N/A *
					695.2	861.5	* N/A *
- 5 -	---	RO-1-5	+29 +31 +33 +35 AEWP 31 {RO verifies that pump is running.}	Auto	0.0	378.9	* N/A *
					695.2	1240.4	* N/A *
- 6 -	---	RO-1-7	+1 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. {All Buses are powered from EDCs.}	Manual	0.0	0.0	* N/A *
					695.2	1240.4	* N/A *
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESWPs (34 and 35) {RO verifies that pumps are running.}	Auto	260.8	260.8	* N/A *
					976.0	1521.2	* N/A *
- 8 -	E-0-11	---	+26 +27 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {CHARGING pump 31 started on lightest loaded Bus.}	Manual	140.2	0.0	* N/A *
					1116.2	1521.2	* N/A *
- 9 -	< 15 >	---	+13 *** FAULTED STEAM GENERATOR *** *** EVENT IDENTIFIED - EXIT TO E-2 ***	Manual	0.0	0.0	* N/A *
					1116.2	1521.2	* N/A *
			(No Loads Started or Tripped at this step)				

STEAM BREAK

Report Date : August 25,2009 Time : 3:53 PM [33]


Step Number	SR0 Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	< 8 >	---	*** GO TO E-1 AT THE COMPLETION OF E-2 ***	Manual	0.0	0.0	* N/A *
					1116.2	1521.2	* N/A *
- 11 -	E-1-4	---	(No Loads Started or Tripped at this step) Reset SI (Step 2 through 12 of RO-1 are completed.)	Manual	0.0	0.0	* N/A *
					1116.2	1521.2	* N/A *
- 12 -	---	RO-1-13	(No Loads Started or Tripped at this step) RESET MCC as per SOP-EL-15. (MCCs are reset.)	Manual	85.8	63.3	* N/A *
					1202.0	1584.5	* N/A *
- 13 -	E-1-8	---	-82 -81 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	0.0	* N/A *
					1202.0	1584.5	* N/A *
- 14 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	0.0	* N/A *
					1202.0	1584.5	* N/A *
- 15 -	< 12 >	---	(No Loads Started or Tripped at this step) *** GO TO ES-1.1, SI TERMINATION ***	Manual	0.0	0.0	* N/A *
					1202.0	1584.5	* N/A *
- 16 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (Only pump 31 running-stopped.) Stop SI pumps. (Only pumps 31 and 32 running-stopped.)	Manual	-327.2	-509.2	* N/A *
					874.8	1075.3	* N/A *
- 17 -	ES-1.1-8	---	-117 -121 -122 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	0.0	* N/A *
					874.8	1075.3	* N/A *
- 18 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs. (Spray not actuated. No pumps are running.)	Manual	0.0	0.0	* N/A *
					874.8	1075.3	* N/A *
			(No Loads Started or Tripped at this step)				

STEAM BREAK

Report Date : August 25, 2009 Time : 3:53 PM [33]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	ES-1.1-13	---	Check BAST transfer pumps are running. (MCC 36A-E never striped.)	Manual	0.0	0.0	* N/A *
					874.8	1075.3	* N/A *
- 20 -	ES-1.1-17	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Pressurizer Heater 33 energized on lightest loaded Bus.)	Manual	207.9	0.0	* N/A *
			+109		1082.7	1075.3	* N/A *
- 21 -	ES-1.1-19	---	Reset MCCs. Start CRDM Fans. (MCC are already reset. CRDM Fans started on MCC 38.)	Manual	80.4	0.0	* N/A *
					1163.1	1075.3	* N/A *
- 22 -	---	RO-1-27c	+70 +71 +72 +73 START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear Started.)	Manual	0.0	41.5	* N/A *
			+47		1163.1	1116.8	* N/A *
- 23 -	ES-1.1-20	---	Stop 1 of 3 ESWPs (ESWPs 34 and 35 are running.) Shutdown Motor-driven AFWPs if desired. (Bus 6A not available. AFWP 31 remains running.)	Manual	0.0	0.0	* N/A *
					1163.1	1116.8	* N/A *
- 24 -	ES-1.1-26	---	(No Loads Started or Tripped at this step) Check that at least two NESWPs are running. (NESWPs 31 and 32 started.)	Manual	280.8	280.8	* N/A *
					1443.9	1397.6	* N/A *
- 25 -	ES-1.1-27	---	+84 +85 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 31 started, Blowers unavailable, powered from Bus 6A/MCC 37. CCR vent. is on.)	Manual	0.0	114.3	* N/A *
			+87		1443.9	1511.9	* N/A *
- 26 -	ES-1.1-32	---	Go to appropriate plant operating procedure as directed by the CRS or SM	Manual	0.0	0.0	* N/A *
					1443.9	1511.9	* N/A *
			(No Loads Started or Tripped at this step)				

STEAM BREAK



Steam Break
 Buses 2A/3A Tied Together, Bus 6A Not Available
 Loss of Off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

AFWP 31	EDG 31
CHARGING PUMP 31	EDG 33
ESWP 34	EDG 33
ESWP 35	EDG 31
FCU 31	EDG 33
FCU 32	EDG 31
FCU 33	EDG 33
FCU 34	EDG 31
MCC 34: TURBINE TURNING GEAR	EDG 31
MCC 36A: AUTO	EDG 33
MCC 36C: AUTO	EDG 31
MCC 36E: AUTO	EDG 33
MCC 38: CRDM FAN 31 (FAN#1)	EDG 33
MCC 38: CRDM FAN 32 (FAN#2)	EDG 33
MCC 38: CRDM FAN 33 (FAN#3)	EDG 33
MCC 38: CRDM FAN 34 (FAN#4)	EDG 33
MCCS RESET (2A/3A) AS PER SOP-EL-15	EDG 31
MCCS RESET (5A) AS PER SOP-EL-15	EDG 33
NESWP 31	EDG 33
NESWP 32	EDG 31
PAB FAN 31	EDG 31
PRESSURIZER HEATER 33	EDG 33

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

STEAM BREAK

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:53 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 5A NOT AVAILABLE ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = * N/A * Bus 2A/3A = 1511.9 Bus 6A = 1638.7 (kW)

1750 kW Overload Summary

Bus 5A Not Available
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1750 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1750 kW rating

1950 kW Overload Summary

Bus 5A Not Available
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1950 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating

STEAM BREAK

Report Date : August 25, 2009 Time : 3:53 PM [34]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36B, 36C and 36D	Auto	* N/A *	94.3	100.4
- 2 -	---	RO-1-2	+57 +53 +59 SI pumps 32 and 33 RHR pumps 31 and 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	* N/A *	509.2	509.2
- 3 -	E-8-9	---	+117 +120 +122 +123 CSP 32 (Spray not required.) CSPs started during phase B only.) (E-0-9 verifies that pump is not running.)	Manual	* N/A *	0.0	0.0
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCUs 32, 34 and 35 (RO verifies that fans are running.)	Auto	* N/A *	258.0	129.0
- 5 -	---	RO-1-5	+31 +35 +37 AFWPs 31 and 33 (RO verifies that pumps are running.)	Auto	* N/A *	378.9	375.7
- 6 -	---	RO-1-7	+1 +2 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. (All Buses are powered from EDCs.)	Manual	* N/A *	0.0	0.0
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESWPs (35 and 36) (RO verifies that pumps are running.)	Auto	* N/A *	280.8	280.8
- 8 -	E-0-11	---	+27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 33 started on lightest loaded Bus.)	Manual	* N/A *	0.0	140.2
- 9 -	< 15 >	---	+15 *** FAULTED STEAM GENERATOR *** *** EVENT IDENTIFIED - EXIT TO E-2 *** (No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
					* N/A *	1521.2	1535.3

STEAM BREAK

Report Date : August 28, 2009 Time : 3:53 PM [34]


Step Number	SRO Step	FO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	< 6 >	---	*** GO TO E-1 AT THE COMPLETION OF E-2 ***	Manual	* N/A *	0.0	0.0
			(No Loads Started or Tripped at this step)		* N/A *	1521.2	1535.3
- 11 -	E-1-4	---	Reset SI (Step 2 through 12 of RO-1 are completed.)	Manual	* N/A *	0.0	0.0
			(No Loads Started or Tripped at this step)		* N/A *	1521.2	1535.3
- 12 -	---	RO-1-15	RESET MCC as per SOP-EL-15. (MCCs are reset.)	Manual	* N/A *	63.3	24.8
					* N/A *	1584.5	1560.1
- 13 -	E-1-8	---	+S1 +S3 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	* N/A *	0.0	0.0
					* N/A *	1584.5	1560.1
- 14 -	E-1-11	---	(No Loads Started or Tripped at this step) Start one CHARGING pump. (CHARGING pump 33 is running.)	Manual	* N/A *	0.0	0.0
					* N/A *	1584.5	1560.1
- 15 -	< 12 >	---	(No Loads Started or Tripped at this step) *** GO TO ES-1.1, SI TERMINATION ***	Manual	* N/A *	0.0	0.0
					* N/A *	1584.5	1560.1
- 16 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (All RHR pumps stopped.) Stop SI pumps. (Only pumps 32 and 33 running - stopped.)	Manual	* N/A *	-509.2	-509.2
					* N/A *	1075.3	1050.9
- 17 -	ES-1.1-8	---	-117 -120 -122 -123 Start one CHARGING pump. (CHARGING pump 33 is running.)	Manual	* N/A *	0.0	0.0
					* N/A *	1075.3	1050.9
- 18 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs. (Spray not actuated. No pumps are running.)	Manual	* N/A *	0.0	0.0
					* N/A *	1075.3	1050.9
			(No Loads Started or Tripped at this step)				

STGAM BREAK

Report Date : August 25, 2009 Time : 3:53 PM [34]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	ES-1.1-13	---	Check BAST transfer pumps are running. (MCC 36A-E never striped.)	Manual	* N/A *	0.0	0.0
					* N/A *	1075.3	1080.9
- 20 -	ES-1.1-17	---	(No Loads Started or Tripped at this step) Energize at least one pressurizer Heater Group as per SOP-EL-15. (Pressurizer Heater Control Group energized on lightest loaded Bus. +114	Manual	* N/A *	0.0	277.0
					* N/A *	1075.3	1327.9
- 21 -	ES-1.1-19	---	Reset MCCs. Start CRDM Fans. (MCC are already reset. CRDM Fans unavailable, powered from Bus 5A/MCC 38.)	Manual	* N/A *	0.0	0.0
					* N/A *	1075.3	1327.9
- 22 -	---	RO-1-27c	(No Loads Started or Tripped at this step) START AC and STOP DC Oil Pumps IF 480v Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.) +47	Manual	* N/A *	41.5	0.0
					* N/A *	1116.8	1327.9
- 33 -	ES-1.1-20	---	Stop 1 of 3 ESOWPs. (ESOWPs 25 and 26 are running.) Shutdown Motor-driven AFWPs if desired. (AFWPs remain running.)	Manual	* N/A *	0.0	0.0
					* N/A *	1116.8	1327.9
- 34 -	ES-1.1-26	---	(No Loads Started or Tripped at this step) Check that at least two NESOWPs are running. (NESOWPs 32 and 33 started.)	Manual	* N/A *	280.8	280.8
					* N/A *	1397.6	1608.7
- 25 -	ES-1.1-27	---	+85 +86 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 31 started on lightest loaded Bus. Blowers started. CCR ventilation is running.) +87 +66 +67	Manual	* N/A *	114.3	30.0
					* N/A *	1511.9	1638.7
- 26 -	ES-1.1-32	---	Go to appropriate plant operating procedure as directed by the CRS or SM	Manual	* N/A *	0.0	0.0
					* N/A *	1511.9	1638.7
			(No Loads Started or Tripped at this step)				

STEAM BREAK



Steam Break
 Buses 2A/3A Tied Together, Bus 5A Not Available
 Loss of Off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

AFWP 31	EDG 31
AFWP 33	EDG 32
CHARGING PUMP 33	EDG 32
ESWP 35	EDG 31
ESWP 36	EDG 32
FCU 32	EDG 31
FCU 34	EDG 31
FCU 35	EDG 32
MCC 34: TURBINE TURNING GEAR	EDG 31
MCC 36B: AUTO	EDG 32
MCC 36C: AUTO	EDG 31
MCC 36D: AUTO	EDG 32
MCC 37: PENT. BLOWER (#1)	EDG 32
MCC 37: PENT. BLOWER (#2)	EDG 32
MCCS RESET (2A/3A) AS PER SOP-EL-15	EDG 31
MCCS RESET (6A) AS PER SOP-EL-15	EDG 32
NESWP 32	EDG 31
NESWP 33	EDG 32
PAB FAN 31	EDG 31
PRESSURIZER HEATER CONTROL GROUP	EDG 32

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

STEAK BREAK

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:53 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 2A AND/OR 3A NOT AVAILABLE ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = 1443.9 Bus 2A/3A = * N/A * Bus 6A = 1335.8 (kW)

1750 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1750 kW rating
Bus 2A and/or 3A Not Available
Emergency Diesel Generator 32 on Bus 6A is below the 1750 kW rating

1950 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1950 kW rating
Bus 2A and/or 3A Not Available
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating

STEAM BREAK

Report Date : August 25, 2009 Time : 3:53 PM [38]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36A, 36B, 36D and 36E	Auto	110.0	* N/A *	100.4
					110.0	* N/A *	100.4
- 2 -	---	RO-1-2	+50 +51 +59 +60 SI pumps 31 and 33 RNR pump 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	327.2	* N/A *	509.2
					437.2	* N/A *	609.6
- 3 -	E-0-9	---	+120 +121 +123 CSPs 31 and 32 (Spray not required. CSPs started during phase B only.) (E-0-9 verifies that pumps are not running.)	Manual	0.0	* N/A *	0.0
					437.2	* N/A *	609.6
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCUs 31, 33 and 35 (RO verifies that fans are running.)	Auto	258.0	* N/A *	139.0
					695.2	* N/A *	738.6
- 5 -	---	RO-1-5	+29 +33 +37 AFWP 33 (RO verifies that pump is running.)	Auto	0.0	* N/A *	375.7
					695.2	* N/A *	1114.3
- 6 -	---	RO-1-7	+2 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. (All Buses are powered from EDGs.)	Manual	0.0	* N/A *	0.0
					695.2	* N/A *	1114.3
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESWPs (34 and 36) (RO verifies that pumps are running.)	Auto	280.8	* N/A *	280.8
					976.0	* N/A *	1395.1
- 8 -	E-0-11	---	+26 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	140.2	* N/A *	0.0
					1116.2	* N/A *	1395.1
- 9 -	< 15 >	---	+13 *** FAULT STEAM GENERATOR *** *** EVENT IDENTIFIED - EXIT TO E-2 *** (No Loads Started or Tripped at this step)	Manual	0.0	* N/A *	0.0
					1116.2	* N/A *	1395.1

STEAM BREAK

Report Date : August 25, 2009 Time : 3:53 PM [35]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A	Bus 2A/3A	Bus 6A
					Step Load/ Load (kW)	Step/Total Load (kW)	Step/Total Load (kW)
- 10 -	< 9 >	---	*** GO TO E-1 AT THE COMPLETION OF E-2 ***	Manual	0.0	* N/A *	0.0
			(No Loads Started or Tripped at this step)		1116.2	* N/A *	1395.1
- 11 -	E-1-4	---	Reset SI (Step 2 through 12 of RO-1 are completed.)	Manual	0.0	* N/A *	0.0
			(No Loads Started or Tripped at this step)		1116.2	* N/A *	1395.1
- 12 -	---	RO-1-15	RESET MCCs as per SOP-EL-15. (MCC are reset.)	Manual	85.8	* N/A *	24.8
			(No Loads Started or Tripped at this step)		1202.0	* N/A *	1419.9
- 13 -	E-1-8	---	+82 +83 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	* N/A *	0.0
			(No Loads Started or Tripped at this step)		1202.0	* N/A *	1419.9
- 14 -	E-1-11	---	Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	* N/A *	0.0
			(No Loads Started or Tripped at this step)		1202.0	* N/A *	1419.9
- 15 -	< 12 >	---	*** GO TO ES-1.1, SI TERMINATION ***	Manual	0.0	* N/A *	0.0
			(No Loads Started or Tripped at this step)		1202.0	* N/A *	1419.9
- 16 -	ES-1.1-4	---	Stop RHR pumps. (Only pump 32 running - stopped.) Stop SI pumps. (Only pumps 31 and 33 running - stopped.)	Manual	-327.2	* N/A *	-509.2
			(No Loads Started or Tripped at this step)		874.8	* N/A *	910.7
- 17 -	ES-1.1-8	---	-120 -121 -123 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	* N/A *	0.0
			(No Loads Started or Tripped at this step)		874.8	* N/A *	910.7
- 18 -	ES-1.1-10	---	Stop CSPs. (Spray not actuated. No pumps are running.)	Manual	0.0	* N/A *	0.0
			(No Loads Started or Tripped at this step)		874.8	* N/A *	910.7

STEAM BREAK

Report Date : August 25, 2009 Time : 3:53 PM [35]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	ES-1.1-13	---	Check BAST transfer pumps are running. (MCC 36A-E never striped.)	Manual	0.0 874.8	* N/A * * N/A *	0.0 910.7
- 20 -	ES-1.1-17	---	(No Loads Started or Tripped at this step) Energize at least one pressurizer Heater Group as per SOP-EL-15. (Pressurizer Heater Group 33 energized on lightest loaded Bus.)	Manual	207.9 1082.7	* N/A * * N/A *	0.0 910.7
- 21 -	ES-1.1-19	---	Reset MCCs. Start CRDM Fans. (MCC are already reset. CRDM Fans started on MCC 30.)	Manual	80.4 1163.1	* N/A * * N/A *	0.0 910.7
- 22 -	---	RO-1-27c	+70 +71 +72 +73 START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Bus 2A/3A unavailable.)	Manual	0.0 1163.1	* N/A * * N/A *	0.0 910.7
- 23 -	ES-1.1-20	---	(No Loads Started or Tripped at this step) Stop 1 of 3 ESWPs. (ESWPs 34 and 36 running.) Shutdown Motor-driven AFWPs if desired. (Bus2A/3A not available. AFWP 23 remains running)	Manual	0.0 1163.1	* N/A * * N/A *	0.0 910.7
- 24 -	ES-1.1-26	---	(No Loads Started or Tripped at this step) Check that at least two NESWPs are running. (NESWPs 31 and 33 started.)	Manual	280.8 1443.9	* N/A * * N/A *	280.8 1191.5
- 25 -	ES-1.1-27	---	+84 +86 Start a PAB Fan, Penetration Blowers and CCR ventilation. (Bus 2A/3A unavailable, PAB Fan 32 started. Blowers started, CCR ventilation is running.)	Manual	0.0 1443.9	* N/A * * N/A *	144.3 1335.8
- 26 -	ES-1.1-32	---	+88 +66 +67 Go to appropriate plant operating procedure as directed by the CRS or SM. (No Loads Started or Tripped at this step)	Manual	0.0 1443.9	* N/A * * N/A *	0.0 1335.8

STEAM BREAK



Steam Break
 Buses 2A and / or 3A Not Available
 Loss of Off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING

AFWP 33
 CHARGING PUMP 31
 ESWP 34
 ESWP 36
 FCU 31
 FCU 33
 FCU 35
 MCC 36A: AUTO
 MCC 36B: AUTO
 MCC 36D: AUTO
 MCC 36E: AUTO
 MCC 37: PENT. BLOWER (#1)
 MCC 37: PENT. BLOWER (#2)
 MCC 38: CRDM FAN 31 (FAN#1)
 MCC 38: CRDM FAN 32 (FAN#2)
 MCC 38: CRDM FAN 33 (FAN#3)
 MCC 38: CRDM FAN 34 (FAN#4)
 MCCS RESET (5A) AS PER SOP-EL-15
 MCCS RESET (6A) AS PER SOP-EL-15
 NESWP 31
 NESWP 33
 PAB FAN 32
 PRESSURIZER HEATER 33

POWER FROM EDG

EDG 32
 EDG 33
 EDG 33
 EDG 32
 EDG 33
 EDG 33
 EDG 32
 EDG 33
 EDG 32
 EDG 32
 EDG 32
 EDG 33
 EDG 32
 EDG 32
 EDG 33
 EDG 33
 EDG 32
 EDG 32
 EDG 32
 EDG 32
 EDG 33

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

LEP-CALC-ED-00207 REV 8

INADVERTENT SI (PH B)
ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:55 PM

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2180.8 Bus 2A = 2129.2 Bus 3A = 1714.9 Bus 6A = 2367.0 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A/3A is below the 3200 Amp rating
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

INADVERTENT SI (PH B) - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:55 PM (55)

Step Number	SRQ Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36A, 36B, 36C, 36D and 36E	Auto	169.5 169.5	135.5 135.5	0.0 0.0	150.1 150.1
- 2 -	---	RO-1-2	+57 +58 +53 +59 +60 SI pumps 31, 32 and 33 RRR pumps 31 and 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	472.4 641.9	472.4 607.9	264.5 264.5	738.3 888.6
- 3 -	E-0-9	---	+117 +120 +121 +122 +123 CSPs 31 and 32 (E-0-9 verifies that pumps are running.)	Auto	453.6 1095.5	0.0 607.9	0.0 264.5	471.1 1359.7
- 4 -	---	RO-1-3	+24 +25 PCUs 31, 32, 33, 34 and 35 (RO verifies that fans are running.)	Auto	491.9 1587.4	247.2 855.1	246.0 510.5	246.0 1607.7
- 5 -	---	RO-1-5	+29 +31 +33 +35 +37 APWPs 31 and 33 (RO verifies that pumps are running.)	Auto	0.0 1587.4	0.0 855.1	575.4 1085.9	552.9 2170.6
- 6 -	---	RO-1-7	+1 +2 CCWPs 31, 32 and 33 (RO verifies that pumps are running.)	Auto	250.5 1837.9	251.3 1106.4	0.0 1085.9	251.2 2421.6
- 7 -	---	RO-1-8	+4 +7 -10 ESWPs (34, 35 and 36) (RO verifies that pumps are running.)	Auto	429.8 2267.7	0.0 1106.4	429.0 1514.9	429.8 2851.6
- 8 -	E-0-11	---	+26 +27 -28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 32 started on lightest loaded Bus.)	Manual	0.0 2267.7	0.0 1106.4	200.9 1723.8	0.0 2851.6
- 9 -	< 10 >	---	+14 *** INADVERTENT SI *** *** EVENT IDENTIFIED - EXIT TO ES-1.1 *** (No Loads Started or Tripped at this step)	Manual	0.0 2267.7	0.0 1106.4	0.0 1723.8	0.0 2851.6

INADVERTENT SI (PH B) - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:55 PM (95)


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 1A Step Load/ Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	ES-1.1-1	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0 2247.7	0.0 1106.4	0.0 1723.8	0.0 2851.6
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset.)	Manual	659.8 2927.5	848.0 1954.4	597.6 2231.4	252.2 3103.8
- 12 -	ES-1.1-3	---	+125 +124 +125 +127 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0 2927.5	0.0 1954.4	0.0 2231.4	0.0 3103.8
- 13 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (All RHR pumps stopped.) Stop SI pumps. (All SI pumps stopped.)	Manual	-472.4 2459.1	-472.4 1482.0	-264.5 1966.9	-738.5 2365.3
- 14 -	ES-1.1-8	---	-117 -120 -121 -122 -123 Start one CHARGING pump. (CHARGING pump 32 is running.)	Manual	0.0 2455.1	0.0 1482.0	0.0 1966.9	0.0 2365.3
- 15 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs if 5 FCUs are running or Containment pressure is < 16 PSIG. (5 FCUs are running and PSIG < 16. CSPs are stopped.)	Manual	-453.6 2001.5	0.0 1482.0	0.0 1966.9	-471.1 1894.2
- 16 -	ES-1.1-13	---	+24 -25 Check BAST transfer pumps are running. (MCC 36A-E never stripped.)	Manual	0.0 2001.5	0.0 1482.0	0.0 1966.9	0.0 1894.2
- 17 -	NSE 99-3-075	NSE 99-3-075	(No Loads Started or Tripped at this step) AS PER SECTION 4.2.20 of NSE One CSP run time is less than 30 minutes. (No CSPs are running.)	Manual	0.0 2001.5	0.0 1482.0	0.0 1966.9	0.0 1894.2
- 18 -	ES-1.1-17	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group, as per SOP-EL-15. (Energized Pressurizer Heater Group 32 on lightest loaded Bus.) +98	Manual	0.0 2001.5	540.3 2022.3	0.0 1966.9	0.0 1894.2

INADVERTENT (PH B) - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:55 PM [55]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	ES-1.1-19	---	Reset MCCs. Start CRDM Fans. (MCC are already reset. CRDM Fan loads accounted for in previous resets.)	Manual	0.0 2001.5	0.0 2022.3	0.0 1966.9	0.0 1894.2
- 20 -	---	RO-1-27c	(No Loads Started or Tripped at this step) START AC and Slow DC Oil Pumps IF 480V buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.) +47	Manual	0.0 2001.5	63.8 2086.1	0.0 1966.9	0.0 1894.2
- 21 -	ES-1.1-20	---	Stop 1 of 3 CCWPs. Stop 1 of 3 ESWPs and Shutdown Motor-Driven AFWPs if desired. (CCWP 31 and ESWP 35 stopped on heaviest loaded Bus. AFWPs remain running.) +8 -11 -4 -7 -10 -27	Manual	-280.5 1761.0	43.1 2129.2	-429.0 1537.9	43.0 1937.2
- 22 -	ES-1.1-25	---	Check that at least two NESWPs are running. (NESWP 31 and 33 started on lightest loaded Bus.) +84 +86	Manual	429.8 2180.8	0.0 2129.2	0.0 1537.9	429.8 2367.0
- 23 -	ES-1.1-27	---	Start a PAB Fan. Penetration Blowers and CCR ventilation. (PAB Fan 31 started on lightest loaded Bus. Blowers and CCR ventilation started at MCC reset.) +87	Manual	0.0 2180.8	0.0 2129.2	177.0 1714.9	0.0 2367.0
- 24 -	ES-1.1-12	---	Go to appropriate plant operating procedure as directed by the CRS or SM. (No Loads Started or Tripped at this step)	Manual	0.0 2180.8	0.0 2129.2	0.0 1714.9	0.0 2367.0

INADVERTENT SI (PH B)



Inadvertent SI (PH B)
 Total MCC and Lighting Reset
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 31	3A
AFWP 33	6A
CCWP 32	2A
CCWP 33	6A
CHARGING PUMP 32	3A
ESWP 34	5A
ESWP 36	6A
FCU 31	5A
FCU 32	2A
FCU 33	5A
FCU 34	3A
FCU 35	6A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36A: AUTO	5A
MCC 36B: AUTO	6A
MCC 36C: AUTO	2A
MCC 36D: AUTO	6A
MCC 36E: AUTO	5A
NESWP 31	5A
NESWP 33	6A
PAB FAN 31	3A
PRESSURIZER HEATER 32	2A
TOTAL MCC & LIGHTING RESET (2A)	
TOTAL MCC & LIGHTING RESET (3A)	
TOTAL MCC & LIGHTING RESET (5A)	
TOTAL MCC & LIGHTING RESET (6A)	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

INADVERTENT SI (PH B)

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:55 PM

*** BUSES 2A AND 3A TIED TOGETHER ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2252.9 Bus 2A/3A = 2533.1 Bus 6A = 2422.8 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A/3A is below the 3200 Amp rating
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

INADVERTENT SI (PH B)

Report Date : August 25, 2009 Time : 3:55 PM [56]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36A, 36B, 36C, 36D and 36E	Auto	169.5	135.5	150.1
					169.5	135.5	150.1
- 2 -	---	RO-1-2	+57 +58 +53 +59 +60 SI pumps 31, 32 and 33 RHR pumps 31 and 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	472.4	736.9	738.5
					641.9	872.4	888.6
- 3 -	E-0-9	---	+117 +120 +121 +122 +123 CSPs 31 and 32 (E-0-9 verifies that pumps are running.)	Auto	453.6	0.0	471.1
					1095.5	872.4	1359.7
- 4 -	---	RO-1-3	+24 +25 FCUs 31, 32, 33, 34 and 35 (RO verifies that fans are running.)	Auto	491.9	493.2	248.0
					1587.4	1365.6	1607.7
- 5 -	---	RO-1-5	+29 +31 +33 +35 +37 AFWPs 31 and 33 (RO verifies that pumps are running.)	Auto	0.0	575.4	562.9
					1587.4	1941.0	2170.6
- 6 -	---	RO-1-7	+1 +2 CCWPs 31, 32 and 33 (RO verifies that pumps are running.)	Auto	250.5	251.3	251.2
					1837.9	2192.3	2421.8
- 7 -	---	RO-1-8	+4 +7 +10 ESWPs (34, 35 and 36) (RO verifies that pumps are running.)	Auto	429.8	429.0	429.8
					2267.7	2621.3	2851.6
- 8 -	E-0-11	---	+26 +27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	208.5	0.0	0.0
					2476.2	2621.3	2851.6
- 9 -	< 19 >	---	+13 *** INADVERTENT SI *** *** EVENT IDENTIFIED - EXIT TO ES-1.1 *** (No Loads Started or Tripped at this step)	Manual	0.0	0.0	0.0
					2476.2	2621.3	2851.6


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	ES-1.1-1	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0	0.0	0.0
					2474.2	2621.3	2851.6
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15 (Total MCC and Lighting reset.)	Manual	659.8	407.2	252.2
					3136.0	3028.5	3103.8
- 12 -	ES-1.1-3	---	+126 +127 +3 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	0.0	0.0
					3136.0	3028.5	3103.8
- 13 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (All RHR pumps stopped.) Stop SI pumps. (All SI pumps stopped.)	Manual	-472.4	-738.9	-738.5
					2662.6	2291.6	2365.3
- 14 -	ES-1.1-5	---	-117 -120 -121 -122 -123 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	0.0	0.0
					2662.6	2291.6	2365.3
- 15 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs if 5 FCUs are running or Containment pressure is < 16 PSIG. (5 FCUs are running and PSIG < 16. CSPs are stopped.)	Manual	-453.6	0.0	-471.1
					2210.0	2291.6	1894.2
- 16 -	ES-1.1-13	---	-24 -25 Check BAST transfer pumps are running. (MCC 36A-E never striped.)	Manual	0.0	0.0	0.0
					2210.0	2291.6	1894.2
- 17 -	NSE 99-3-075	NSE 99-3-075	(No Loads Started or Tripped at this step) AS PER SECTION 4.2.20 of NSE One CSP run time is less than 30 minutes. (No CSPs are running.)	Manual	0.0	0.0	0.0
					2210.0	2291.6	1894.2
- 18 -	ES-1.1-17	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group. as per SOP-EL-15. (Energized Pressurizer Heater Control Group on lightest loaded Bus.) +114	Manual	0.0	0.0	308.6
					2210.0	2291.6	2202.8

INADVERTENT SI (PH B)

Report Date : August 25, 2009 Time : 3:56 PM [56]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	ES-1.1-19	---	Reser MCCs. Start CRDM Fans. (MCCs are already reset. CRDM Fan loads accounted for in MCC resets.)	Manual	0.0 2210.0	0.0 2291.6	0.0 2202.8
- 20 -	---	RO-1-27c	(No Loads Started or Tripped at this step) START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning gear. (Gear started.) +47	Manual	0.0 2210.0	63.8 2355.4	0.0 2202.8
- 21 -	ES-1.1-20	---	Stop 1 of 3 CCWPs. Stop 1 of 3 ESWPs and Shutdown Motor-driven AFWPs if desired. (First CCWP 32 and then ESWP 34 stopped on heaviest loaded Buses. AFWPs remain running.) +5 +11 -4 -7 -10 -25	Manual	-386.9 1823.1	-251.3 2104.1	43.0 2245.8
- 22 -	ES-1.1-26	---	Check that at least two NESWPs are running. (NESWP 31 and 32 started on lightest loaded Bus.) +64 +65	Manual	429.8 2252.9	429.0 2533.1	0.0 2245.8
- 23 -	ES-1.1-27	---	Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 32 started on lightest loaded Bus. Blowers and CCR vent. started at MCC reset.) +88	Manual	0.0 2252.9	0.0 2533.1	177.0 2422.8
- 24 -	ES-1.1-32	---	Go to appropriate plant operating procedure as directed by the CRS or SM. (No Loads Started or Tripped at this step)	Manual	0.0 2252.9	0.0 2533.1	0.0 2422.8

INADVERTENT SI (PH B)



Inadvertent SI (PH B)
 Buses 2A/3A Tied Together, All Buses Available
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 31	3A
AFWP 33	6A
CCWP 32	2A
CCWP 33	6A
CHARGING PUMP 31	5A
ESWP 35	3A
ESWP 38	6A
FCU 31	5A
FCU 32	2A
FCU 33	5A
FCU 34	3A
FCU 35	6A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36A: AUTO	5A
MCC 36B: AUTO	6A
MCC 36C: AUTO	2A
MCC 36D: AUTO	6A
MCC 36E: AUTO	5A
NESWP 31	5A
NESWP 32	2A
PAB FAN 31	3A
PRESSURIZER HEATER CONTROL GROUP	6A
TOTAL MCC & LIGHTING RESET (5A)	
TOTAL MCC & LIGHTING RESET (6A)	
MCCS RESET (2A/3A) AS PER SOP-EL-15	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IPJ-CALC-ED-00207 REV 2

INADVERTENT SI (PH B)

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:55 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 6A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2914.3 Bus 2A/3A = 3004.5 Bus 6A = * N/A * (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A/3A is below the 3200 Amp rating
Bus 6A Not Available

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A Not Available

INADVERTENT SI (PH B)

Report Date : August 25, 2009 Time : 3:55 PM [57]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 5A Step/Total Load (A)
- 1 -	---	---	MCC 26A, 36C and 36E	Auto	169.5	135.5	* N/A *
- 2 -	---	RO-1-2	+57 +50 +60 SI pumps 31 and 32 RHR pumps 31 (mini flow, RCS press > 325) {RO verifies that pumps are running.}	Auto	472.4	736.9	* N/A *
- 3 -	E-0-9	---	+117 +121 +122 CSPs 31 {E-0-9 verifies that pump is running.}	Auto	641.9	872.4	* N/A *
- 4 -	---	RO-1-3	+24 FCUs 31, 32, 33 and 34 {RO verifies that fans are running.}	Auto	453.6	0.0	* N/A *
- 5 -	---	RO-1-5	+29 +31 +33 +35 AFWPs 31 {RO verifies that pump is running.}	Auto	1095.5	872.4	* N/A *
- 6 -	---	RO-1-7	+1 CCWPs 31 and 32 {RO verifies that pumps are running.}	Auto	491.9	493.2	* N/A *
- 7 -	---	RO-1-8	+4 +7 ESWPs (34 and 35) {RO verifies that pumps are running.}	Auto	1587.4	1365.6	* N/A *
- 8 -	E-0-11	---	+26 +27 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {CHARGING pump 31 started on lightest loaded Bus.}	Manual	0.0	575.4	* N/A *
- 9 -	< 19 >	---	+13 *** INADVERTENT SI *** *** EVENT IDENTIFIED - EXIT TO ES-1.1 *** {No Loads Started or Tripped at this step}	Manual	1587.4	1941.0	* N/A *
					208.5	0.0	* N/A *
					2519.1	2664.4	* N/A *
					0.0	0.0	* N/A *
					2519.1	2664.4	* N/A *


INADVERTENT SI (PH B)

Report Date : August 25, 2009 Time : 3:55 PM [E7]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	ES-1.1-1	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0 2519.1	0.0 2664.4	* N/A * * N/A *
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15 (Total MCC and Lighting reset.)	Manual	659.8 3178.9	407.2 3071.6	* N/A * * N/A *
- 12 -	ES-1.1-3	---	+126 #3 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0 3178.9	0.0 3071.6	* N/A * * N/A *
- 13 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pump. (Only pump 31 running - stopped.) Stop SI pumps. (Only pumps 31 and 32 running - stopped.)	Manual	-472.4 3706.5	-736.9 2334.7	* N/A * * N/A *
- 14 -	ES-1.1-8	---	-117 -121 -122 Start a CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0 2706.5	0.0 2334.7	* N/A * * N/A *
- 15 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs if 5 FCUs are running or Containment pressure is < 16 PSIG.	Manual	0.0 2706.5	0.0 2334.7	* N/A * * N/A *
- 16 -	ES-1.1-11	---	(No Loads Started or Tripped at this step) Check BAST transfer pumps are running. (MCC 36A-E never stripped.)	Manual	0.0 2706.5	0.0 2334.7	* N/A * * N/A *
- 17 -	NSE 99-3-075	NSE 99-3-075	(No Loads Started or Tripped at this step) AS PER SECTION 4.2.20 of NSE ONE CSP run time is less than 30 minutes. (CSP 31 stopped.)	Manual	-453.6 2252.9	0.0 2334.7	* N/A * * N/A *
- 18 -	ES-1.1-17	---	-24 Energize at least one Pressurizer Heater Group. as per SOP-EL-15. (Energized Pressurizer Heater Group 33 on lightest loaded Bus.) -109	Manual	231.6 2484.5	0.0 2334.7	* N/A * * N/A *

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/1A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	ES-1.1-19	---	Reset MCCs. Start CRDM Fans. (MCCs are already reset. CRDM Fan loads accounted for in MCC resets.)	Manual	0.0 2484.5	0.0 2334.7	* N/A * * N/A *
- 20 -	---	RO-1-27c	(No Loads Started or Tripped at this step) START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.) +47	Manual	0.0 2484.5	63.8 2398.5	* N/A * * N/A *
- 21 -	ES-1.1-20	---	Stop 1 of 3 CCWPs. (CCWPs 31 and 32 running.) Stop 1 of 3 ESWPs. (ESWPs 34 and 35 running.) Shutdown Motor-driven AFWPs if desired. (Bus 6A not available. AFWP 31 remains running)	Manual	0.0 2484.5	0.0 2398.5	* N/A * * N/A *
- 22 -	ES-1.1-26	---	(No Loads Started or Tripped at this step) Check that at least two NESWPs are running. (NESWPs 31 and 32 started.)	Manual	429.8 2914.3	429.0 2827.5	* N/A * * N/A *
- 23 -	ES-1.1-27	---	+84 +85 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 31 started. Blowers unavailable, powered from Bus 6A/MCC 37. CCR vent. started.) +87	Manual	0.0 2914.3	177.0 3004.5	* N/A * * N/A *
- 24 -	ES-1.1-32	---	Go to appropriate plant operating procedure as directed by the CRS or SM.	Manual	0.0 2914.3	0.0 3004.5	* N/A * * N/A *
			(No Loads Started or Tripped at this step)				

INADVERTENT SI (PH B)



Inadvertent SI (PH B)
 Buses 2A/3A Tied Together, Bus 6A Not Available
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 31	3A
CCWP 31	5A
CCWP 32	2A
CHARGING PUMP 31	5A
ESWP 34	5A
ESWP 35	3A
FCU 31	5A
FCU 32	2A
FCU 33	5A
FCU 34	3A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36A: AUTO	5A
MCC 36C: AUTO	2A
MCC 36E: AUTO	5A
NESWP 31	5A
NESWP 32	2A
PAB FAN 31	3A
PRESSURIZER HEATER 33	5A
TOTAL MCCS & LIGHTING RESET BUS 5A	
MCCS RESET (2A/3A) AS PER SOP-EL-15	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

INADVERTENT SI (PH B)

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:55 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 5A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = * N/A * Bus 2A/3A = 3036.4 Bus 6A = 2852.6 (A)

3200 Amp Overload Summary

Bus 5A Not Available
Bus 2A/3A exceeds the 3200 Amp rating at EOP steps : 11, 12
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A Not Available
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

INADVERTENT SI (PH B)

Report Date : August 25, 2009 Time : 3:55 PM [58]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36B, 36C and 36D	Auto	* N/A *	135.5	150.1
					* N/A *	135.5	150.1
- 2 -	---	RO-1-2	+57 +58 +59 SI pumps 32 and 33 RHR pumps 31 and 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	* N/A *	736.9	738.5
					* N/A *	872.4	888.6
- 3 -	E-0-9	---	+117 +120 +122 +123 CSP 32 (E-0-9 verifies that pump is running.)	Auto	* N/A *	0.0	471.1
					* N/A *	872.4	1359.7
- 4 -	---	RO-1-3	+25 FCUs 32, 34 and 35 (RO verifies that fans are running.)	Auto	* N/A *	491.2	248.0
					* N/A *	1365.6	1607.7
- 5 -	---	RO-1-5	+31 +35 +37 AFWPs 31 and 33 (RO verifies that pumps are running.)	Auto	* N/A *	575.4	562.9
					* N/A *	1941.0	2170.6
- 6 -	---	RO-1-7	+1 +2 CCWPs 32 and 33 (RO verifies that pumps are running.)	Auto	* N/A *	294.4	294.2
					* N/A *	2235.4	2464.8
- 7 -	---	RO-1-8	+7 +10 ESRPs (35 and 36) (RO verifies that pumps are running.)	Auto	* N/A *	429.0	429.8
					* N/A *	2664.4	2894.6
- 8 -	E-0-11	---	+27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 32 started on lightest loaded Bus.)	Manual	* N/A *	208.9	0.0
					* N/A *	2873.3	2894.6
- 9 -	< 19 >	---	+14 *** INADVERTENT SI *** *** EVENT IDENTIFIED - EXIT TO ES-1.1 *** (No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
					* N/A *	2873.3	2894.6


Step Number	SRG Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	ES-1.1-1	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	* N/A *	0.0	0.0
					* N/A *	2873.3	2894.6
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset.)	Manual	* N/A *	407.2	252.2
					* N/A *	3280.5 Over 3200	3146.8
- 12 -	ES-1.1-3	---	+127 +3 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	* N/A *	0.0	0.0
					* N/A *	3280.5 Over 3200	3146.8
- 13 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (All RHR pumps stopped.) Stop SI pumps. (Only pumps 32 and 33 running - stopped.)	Manual	* N/A *	-736.9	-738.5
					* N/A *	2543.6	2408.3
- 14 -	ES-1.1-2	---	-117 -120 -122 -123 Start a CHARGING pump. (CHARGING pump 32 is running.)	Manual	* N/A *	0.0	0.0
					* N/A *	2543.6	2408.3
- 15 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs if 5 FCUs are running or Containment pressure is < 16 PSIG.	Manual	* N/A *	0.0	0.0
					* N/A *	2543.6	2408.3
- 16 -	ES-1.1-13	---	(No Loads Started or Tripped at this step) Check BAST transfer pumps are running. (MCC 36A-E never striped.)	Manual	* N/A *	0.0	0.0
					* N/A *	2543.6	2408.3
- 17 -	NSE 99-3-075	NSE 99-3-075	(No Loads Started or Tripped at this step) AS PER SECTION 4.2.20 of NSE One CSP run time is less than 30 minutes. (CSP 32 stopped.)	Manual	* N/A *	0.0	-471.1
					* N/A *	2543.6	1937.2
- 18 -	ES-1.1-17	---	-25 Energize at least one Pressurizer Heater Group. as per SOP-EL-15. (Energized Pressurizer Heater Control Group on lightest loaded Bus.) +114	Manual	* N/A *	0.0	308.6
					* N/A *	2543.6	2245.8

INADVERTENT SI (PH 3)

Report Date : August 25, 2009 Time : 3:55 PM [58]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	ES-1.1-19	---	Reset MCCs. Start CRDM Fans. (MCC are already reset. Bus 5A unavailable to start CRDM Fans.)	Manual	* N/A *	0.0	0.0
- 20 -	---	RO-1-27c	(No Loads Started or Tripped at this step) START AC and DC Oil Pumps IF 480V buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.) +47	Manual	* N/A *	2543.6	2245.8
- 21 -	ES-1.1-20	---	Step 1 of 3 CCWPs. (CCWPs 32 and 33 running.) Step 1 of 3 ESWPs (ESWPs 35 and 36 running.) Shutdown Motor-driven AFWPs if desired. (AFWPs remain running.)	Manual	* N/A *	2607.4	2245.8
- 22 -	ES-1.1-24	---	(No Loads Started or Tripped at this step) Check that at least two NESWPs are running. (NESWP 32 and 33 started.)	Manual	* N/A *	429.0	439.8
- 23 -	ES-1.1-27	---	+85 +86 Start a PAB Fan, Penetration Blowers and CCF ventilation. (PAB Fan 32 started on lightest loaded Bus. Blowers and CCF vent. started at MCC resets.)	Manual	* N/A *	3036.4	2852.6
- 24 -	ES-1.1-32	---	+88 Go to appropriate plant operating procedure as directed by the CRS or SM.	Manual	* N/A *	0.0	0.0
			(No Loads Started or Tripped at this step)		* N/A *	3036.4	2852.6

INADVERTENT SI (PH B)



Inadvertent SI (PH B)
 Buses 2A/3A Tied Together, Bus 5A Not Available
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 31	3A
AFWP 33	6A
CCWP 32	2A
CCWP 33	6A
CHARGING PUMP 32	3A
ESWP 35	3A
ESWP 36	6A
FCU 32	2A
FCU 34	3A
FCU 35	6A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36B: AUTO	6A
MCC 36C: AUTO	2A
MCC 36D: AUTO	6A
NESWP 32	2A
NESWP 33	6A
PAB FAN 32	6A
PRESSURIZER HEATER CONTROL GROUP	6A
MCCS RESET (2A/3A) AS PER SOP-EL-15	
TOTAL MCCS & LIGHTING RESET BUS 6A	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IPI-CALC-ED-00207 REV 8

INADVERTENT SI (PH B)

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:55 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 2A AND/OR 3A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2682.7 Bus 2A/3A = * N/A * Bus 6A = 2852.6 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A and/or 3A Not Available
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A and/or 3A Not Available
Bus 6A is below the 3600 Amp rating

INADVERTENT SI (PH B)

Report Date : August 25, 2009 Time : 3:55 PM (59)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36A, 36B, 36D and 36E	Auto	169.5	* N/A *	150.1
					169.5	* N/A *	150.1
- 2 -	---	RO-1-2	+50 +53 +59 +60 SI Pumps 31 and 33 RHR Pumps 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	472.4	* N/A *	738.5
					641.9	* N/A *	888.6
- 3 -	E-0-9	---	+120 +121 +123 CSPs 31 and 32 (E-0-9 verifies that pumps are running.)	Auto	453.6	* N/A *	471.1
					1095.5	* N/A *	1359.7
- 4 -	---	RO-1-3	+24 +25 FCUs 31, 33 and 35 (RO verifies that fans are running.)	Auto	491.9	* N/A *	248.5
					1587.4	* N/A *	1607.7
- 5 -	---	RO-1-5	+29 +33 +37 AFWP 33 (RO verifies that pump is running.)	Auto	0.0	* N/A *	562.9
					1587.4	* N/A *	2170.6
- 6 -	---	RO-1-7	+2 CCWPs 31 and 33 (RO verifies that pumps are running.)	Auto	293.4	* N/A *	294.2
					1880.8	* N/A *	2464.8
- 7 -	---	RO-1-8	+4 +10 ESWPs (34 and 36) (RO verifies that pumps are running.)	Auto	429.8	* N/A *	429.8
					2310.6	* N/A *	2894.6
- 8 -	E-0-11	---	+26 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	208.5	* N/A *	0.0
					2519.1	* N/A *	2894.6
- 9 -	< 19 >	---	+13 *** INADVERTENT SI *** *** EVENT IDENTIFIED - EXIT TO ES-1.1 *** (No Loads Started or Tripped at this step)	Manual	0.0	* N/A *	0.0
					2519.1	* N/A *	2894.6

INADVERTENT SI (PH B)

Report Date : August 25, 2009 Time : 3:55 PM [59]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	ES-1.1-1	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0 2519.1	* N/A * * N/A *	0.0 2394.6
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset.)	Manual	659.8 3178.9	* N/A * * N/A *	252.2 3146.8
- 12 -	ES-1.1-3	---	+126 +127 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0 3178.9	* N/A * * N/A *	0.0 3146.8
- 13 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (Only pump 32 running - stopped.) Stop SI pumps. (Only pumps 31 and 33 running - stopped.)	Manual	-472.4 2706.5	* N/A * * N/A *	-738.5 2408.3
- 14 -	ES-1.1-8	---	-120 -121 -123 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0 2706.5	* N/A * * N/A *	0.0 2408.3
- 15 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs if 5 FCUs are running Containment pressure is < 16 PSIG.	Manual	0.0 2706.5	* N/A * * N/A *	0.0 2408.3
- 16 -	ES-1.1-13	---	(No Loads Started or Tripped at this step) Check BAST transfer pumps are running. (MCC 36A-E never striped.)	Manual	0.0 2706.5	* N/A * * N/A *	0.0 2408.3
- 17 -	NSE 99-3-075	MSE 99-3-075	(No Loads Started or Tripped at this step) AS PER SECTION 4.2.20 of NSE One CSP run time is less than 30 minutes. (CSPs stopped.)	Manual	-453.6 2252.9	* N/A * * N/A *	-471.1 1937.2
- 18 -	ES-1.1-17	---	-24 -25 Energize at least one Pressurizer Heater Group. as per SOP-EL-15. (Energized Pressurizer Heater Control Group on lightest loaded Bus.) +114	Manual	0.0 2252.9	* N/A * * N/A *	308.6 2245.8

INADVERTENT SI (PH B)

Report Date : August 25, 2009 Time : 3:55 PM [59]

Step Number	NRO Step	RO Str.	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total/Load (A)	Bus 6A Step/Total/Load (A)
- 19 -	ES-1.1-19	---	Reset MCCs. Start CRDM Fans. (MCC are already reset. CRDM Fan loads accounted for in MCC resets.)	Manual	0.0 2252.9	* N/A * * N/A *	0.0 2245.8
- 20 -	---	HO-1-27c	(No Loads Started or Tripped at this step) START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Bus 2A/3A unavailable.)	Manual	0.0 2252.9	* N/A * * N/A *	0.0 2245.8
- 21 -	ES-1.1-20	---	(No Loads Started or Tripped at this step) Stop 1 of 3 CCWPs. (CCWPs 31 and 33 running.) Step 1 of 3 ESWPs. (ESWPs 34 and 36 running.) Shutdown Motor-driven AFWPs if desired. (Bus 2A/3A not available. AFWP 33 remains running)	Manual	0.0 2252.9	* N/A * * N/A *	0.0 2245.8
- 22 -	ES-1.1-25	---	(No Loads Started or Tripped at this step) Check that at least two NESWPs are running. (NESWP 31 and 22 started.)	Manual	429.8 2682.7	* N/A * * N/A *	429.8 2675.6
- 23 -	ES-1.1-27	---	+84 ,86 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 32 started. Blowers and CCR ventilation started at MCC reset.)	Manual	0.0 2682.7	* N/A * * N/A *	177.0 2852.6
- 24 -	ES-1.1-32	---	+88 Go to appropriate plant operating procedure as directed by the CRS or SM.	Manual	0.0 2682.7	* N/A * * N/A *	0.0 2852.6
			(No Loads Started or Tripped at this step)				

INADVERTENT SI (PH B)



Inadvertent SI (PH B)
 Buses 2A and / or 3A Not Available
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 33	6A
CCWP 31	5A
CCWP 33	6A
CHARGING PUMP 31	5A
ESWP 34	5A
ESWP 36	6A
FCU 31	5A
FCU 33	5A
FCU 35	6A
MCC 36A: AUTO	5A
MCC 36B: AUTO	6A
MCC 36D: AUTO	6A
MCC 36E: AUTO	5A
NESWP 31	5A
NESWP 33	6A
PAB FAN 31	3A
PRESSURIZER HEATER CONTROL GROUP	6A
TOTAL MCC & LIGHTING RESET (5A)	
TOTAL MCC & LIGHTING RESET (6A)	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES

ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

INADVERTENT SI (PH B)

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:55 PM

*** BUSES 2A AND 3A TIED TOGETHER ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = 1163.1 Bus 2A/3A = 1231.1 Bus 6A = 1221.5 (KW)

1750 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1750 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1750 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1750 kW rating

1950 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1950 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1950 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating

INADVERTENT SI (PR B)

Report Date : August 29, 2009 Time : 3:55 PM [60]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36A, 36B, 36C, 36D and 36E	Auto	110.0	94.3	100.4
- 2 -	---	RO-1-2	+57 +58 +59 +60 SI pumps 31, 32 and 33 RHR pumps 31 and 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	327.2	509.2	509.2
- 3 -	E-0-9	---	+117 +120 +121 +122 +123 CSPs 31 and 32 (E-0-9 verifies that pumps are running.)	Auto	387.3	0.0	319.5
- 4 -	---	RO-1-3	+24 +25 FCCs 31, 32, 33, 34 and 35 (RO verifies that fans are running.)	Auto	258.0	258.0	129.0
- 5 -	---	RO-1-5	+29 +31 +33 +35 +37 AFWPs 31 and 33 (RO verifies that pumps are running.)	Auto	0.0	378.9	375.7
- 6 -	---	RO-1-7	+1 +2 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. (All Buses are powered from EDGs.)	Manual	0.0	0.0	0.0
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESWPs (34, 35 and 36) (RO verifies that pumps are running.)	Auto	280.8	280.8	280.8
- 8 -	E-0-11	---	+26 +27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	140.2	0.0	0.0
- 9 -	< 19 >	---	+13 *** INADVERTENT SI *** *** EVENT IDENTIFIED - EXIT TO ES-1.1 *** (No Loads Started or Tripped at this step)	Manual	0.0	0.0	0.0

INADVERTENT SI (PH B)

Report Date : August 25, 2009 Time : 3:55 PM [60]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 5A Step/Total Load (kW)
- 10 -	ES-1.1-1	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0 1423.5	0.0 1521.2	0.0 1714.6
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (MCCs are reset.)	Manual	85.9 1509.3	63.3 1584.5	24.8 1739.4
- 12 -	ES-1.1-3	---	+82 +81 +83 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0 1509.3	0.0 1584.5	0.0 1739.4
- 13 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (All RHR pumps stopped.) Stop SI pumps. (All SI pumps stopped.)	Manual	-327.2 1182.1	-509.2 1075.3	-509.2 1230.2
- 14 -	ES-1.1-6	---	-117 -120 -121 -122 -123 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0 1182.1	0.0 1075.3	0.0 1230.2
- 15 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs if 5 FCUs are running or Containment pressure is < 16 PSIG. (5 FCUs are running. CSPs stopped.)	Manual	-307.3 874.8	0.0 1075.3	-319.5 910.7
- 16 -	ES-1.1-13	---	-24 -25 Check BAST transfer pumps are running. (MCC 36A-E never stripped.)	Manual	0.0 874.8	0.0 1075.3	0.0 910.7
- 17 -	NSE 99-3-075	NSE 99-3-075	(No Loads Started or Tripped at this step) AS PER SECTION 4.2.20 of NSE One CSP run time is less than 30 minutes. (No CSPs are running.)	Manual	0.0 874.8	0.0 1075.3	0.0 910.7
- 18 -	ES-1.1-17	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Pressurizer Heater Group 33 energized on lightest loaded Bus. +109	Manual	287.9 1082.7	0.0 1075.3	0.0 910.7

INADVERTENT SI (PH B)

Report Date : August 25, 2008 Time : 3:55 PM [50]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	ES-1.1-19	---	Reset MCCs. Start CRDM Fans. (MCC are already reset. CRDM Fans started on MCC 38.)	Manual	80.4 1153.1	0.0 1075.3	0.0 910.7
- 20 -	---	RC-1-27c	+70 +71 +72 +73 START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.) +47	Manual	0.0 1153.1	41.5 1116.8	0.0 910.7
- 21 -	ES-1.1-20	---	Stop 1 of 3 ESWPs. (ESWP 34 stopped on heaviest loaded Bus.) Shutdown Motor-driven APWPs if desired. (APWPs remain running.) -26	Manual	-280.8 882.3	0.0 1116.8	0.0 910.7
- 22 -	ES-1.1-24	---	Check that at least two NESWPs are running. (NESWP 31 and 33 started on lightest loaded Bus.)	Manual	280.8 1153.1	0.0 1116.8	280.8 1191.5
- 23 -	ES-1.1-27	---	+84 +86 Start a PAR Fan, Penetration Blowers and CCR ventilation. (PAB Fan 31 started on lightest loaded Bus. Blowers started, CCR ventilation is running.) +87 +88 +67	Manual	0.0 1153.1	114.3 1231.1	30.0 1221.5
- 24 -	ES-1.1-32	---	Go to appropriate plant operating procedure as directed by the CRS or SM.	Manual	0.0 1153.1	0.0 1231.1	0.0 1221.5
			(No Loads Started or Tripped at this step)				

INADVERTENT SI (PH B)



Inadvertent SI (PH B)
 Buses 2A/3A Tied Together, All Buses Available
 Loss of Off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

AFWP 31	EDG 31
AFWP 33	EDG 32
CHARGING PUMP 31	EDG 33
ESWP 35	EDG 31
ESWP 36	EDG 32
FCU 31	EDG 33
FCU 32	EDG 31
FCU 33	EDG 33
FCU 34	EDG 31
FCU 35	EDG 32
MCC 34: TURBINE TURNING GEAR	EDG 31
MCC 36A: AUTO	EDG 33
MCC 36B: AUTO	EDG 32
MCC 36C: AUTO	EDG 31
MCC 36D: AUTO	EDG 32
MCC 36E: AUTO	EDG 33
MCC 37: PENT. BLOWER (#1)	EDG 32
MCC 37: PENT. BLOWER (#2)	EDG 32
MCC 38: CRDM FAN 31 (FAN#1)	EDG 33
MCC 38: CRDM FAN 32 (FAN#2)	EDG 33
MCC 38: CRDM FAN 33 (FAN#3)	EDG 33
MCC 38: CRDM FAN 34 (FAN#4)	EDG 33
MCCS RESET (2A/3A) AS PER SOP-EL-15	EDG 31
MCCS RESET (5A) AS PER SOP-EL-15	EDG 33
MCCS RESET (6A) AS PER SOP-EL-15	EDG 32
NESWP 31	EDG 33
NESWP 33	EDG 32
PAB FAN 31	EDG 31
PRESSURIZER HEATER 33	EDG 33

INADVERTENT SI (PH B)

Report Date : August 25, 2009 Time : 3:56 PM [61]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (KW)	Bus 6A Step/Total Load (KW)
- 1 -	---	---	MCC 36A, 36C and 36E	Auto	110.0	94.3	* N/A *
					110.0	94.3	* N/A *
- 2 -	---	RO-1-2	+57 +58 +60 SI pumps 31 and 32 RHR pumps 31 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	327.2	509.2	* N/A *
					437.2	603.5	* N/A *
- 3 -	E-0-9	---	+117 +121 +122 CSP 31 (E-0-9 verifies that pump is running.)	Auto	307.3	0.0	* N/A *
					744.5	603.5	* N/A *
- 4 -	---	RO-1-3	+24 FCUs 31, 32, 33 and 34 (RO verifies that fans are running.)	Auto	258.0	258.0	* N/A *
					1002.5	861.5	* N/A *
- 5 -	---	RO-1-5	+29 +31 +33 +35 APWP 31 (RO verifies that pump is running.)	Auto	0.0	378.9	* N/A *
					1002.5	1240.4	* N/A *
- 6 -	---	RO-1-7	+1 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. (All Buses are powered from EDGs.)	Manual	0.0	0.0	* N/A *
					1002.5	1240.4	* N/A *
- 7 -	---	RO-1-8	(NO Loads Started or Tripped at this step) ESWPs (24 and 35) (RO verifies that pumps are running.)	Auto	280.8	300.8	* N/A *
					1283.3	1521.2	* N/A *
- 8 -	E-0-11	---	+26 +27 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	140.2	0.0	* N/A *
					1423.5	1521.2	* N/A *
- 9 -	E-19 >	---	+13 *** INADVERTENT SI *** *** EVENT IDENTIFIED - EXIT TO ES-1.1 ***	Manual	0.0	0.0	* N/A *
					1423.5	1521.2	* N/A *
			(No Loads Started or Tripped at this step)				


INADVERTENT SI (PH B)

Report Date : August 25, 2009 Time : 3:56 PM [61]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 1A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	ES-1.1-1	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0	0.0	* N/A *
					1423.5	1521.2	* N/A *
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (MCCs are reset.)	Manual	85.8	63.3	* N/A *
					1509.3	1584.5	* N/A *
- 12 -	ES-1.1-3	---	*82 -21 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	0.0	* N/A *
					1509.3	1584.5	* N/A *
- 13 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (Only pump 31 running - stopped.) Stop SI pumps. (Only pumps 31 and 32 running - stopped.)	Manual	-327.2	-509.2	* N/A *
					1182.1	1075.3	* N/A *
- 14 -	ES-1.1-8	---	-117 -121 -122 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	0.0	* N/A *
					1182.1	1075.3	* N/A *
- 15 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs if 5 FCUs are running or Containment pressure is < 16 PSIG.	Manual	0.0	0.0	* N/A *
					1182.1	1075.3	* N/A *
- 16 -	ES-1.1-13	---	(No Loads Started or Tripped at this step) Check BAST transfer pumps are running (MCC 36A-E never striped.)	Manual	0.0	0.0	* N/A *
					1182.1	1075.3	* N/A *
- 17 -	NSE 99-3-075	NSE 99-3-075	(No Loads Started or Tripped at this step) AS PER SECTION 4.2.20 of NSE One CSP run time is less than 30 minutes. (CSP 31 stopped.)	Manual	-307.3	0.0	* N/A *
					874.8	1075.3	* N/A *
- 18 -	ES-1.1-17	---	-24 Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Pressurizer Heater Group 33 energized on lightest loaded Bus.) -109	Manual	207.9	0.0	* N/A *
					1082.7	1075.3	* N/A *

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	ES-1.1-19	---	Reset MCCs. Start CRDM Fans (MCC are already reset. CRDM Fans started on MCC 38.)	Manual	80.4 1163.1	0.0 1075.3	* N/A * * N/A *
- 20 -	---	RO-1-27c	+70 +71 +72 +73 START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.)	Manual	0.0 1163.1	41.5 1116.8	* N/A * * N/A *
- 21 -	ES-1.1-20	---	+47 Stop 1 of 3 ESOWPs. (ESOWPs 34 and 35 are running.) Shutdown Motor-Driven APWPs if desired. (Bus 6A not available. APWP 31 remains running)	Manual	0.0 1163.1	0.0 1116.8	* N/A * * N/A *
- 22 -	ES-1.1-26	---	(No Loads Started or Tripped at this step) Check that at least two NESOWPs are running. (Two NESOWPs started.)	Manual	280.8 1443.9	280.8 1397.6	* N/A * * N/A *
- 23 -	ES-1.1-27	---	+84 +85 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 31 started. Blowers unavailable, powered from Bus 6A/MCC 37. CCR vent. is on.)	Manual	0.0 1443.9	124.3 1511.9	* N/A * * N/A *
- 24 -	ES-1.1-32	---	+87 Go to appropriate plant operating procedure as directed by the CRS or SM.	Manual	0.0 1443.9	0.0 1511.9	* N/A * * N/A *
			(No Loads Started or Tripped at this step)				

INADVERTENT SI (PH B)



Inadvertent SI (PH B)
 Buses 2A/3A Tied Together, Bus 6A Not Available
 Loss of Off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

AFWP 31	EDG 31
CHARGING PUMP 31	EDG 33
ESWP 34	EDG 33
ESWP 35	EDG 31
FCU 31	EDG 33
FCU 32	EDG 31
FCU 33	EDG 33
FCU 34	EDG 31
MCC 34: TURBINE TURNING GEAR	EDG 31
MCC 36A: AUTO	EDG 33
MCC 36C: AUTO	EDG 31
MCC 36E: AUTO	EDG 33
MCC 38: CRDM FAN 31 (FAN#1)	EDG 33
MCC 38: CRDM FAN 32 (FAN#2)	EDG 33
MCC 38: CRDM FAN 33 (FAN#3)	EDG 33
MCC 38: CRDM FAN 34 (FAN#4)	EDG 33
MCCS RESET (2A/3A) AS PER SOP-EL-15	EDG 31
MCCS RESET (5A) AS PER SOP-EL-15	EDG 33
NESWP 31	EDG 33
NESWP 32	EDG 31
PAB FAN 31	EDG 31
PRESSURIZER HEATER 33	EDG 33

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES

ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 3

INADVERTENT SI (PH B)

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:56 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 5A NOT AVAILABLE ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = * N/A * Bus 2A/3A = 1537.8 Bus 6A = 1612.8 (KW)

1750 kW Overload Summary

Bus 5A Not Available
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1750 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1750 kW rating

1950 kW Overload Summary

Bus 5A Not Available
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1950 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating

INADVERTENT SI (PR B)

Report Date : August 25, 2009 Time : 3:56 PM [62]

Step Number	SAO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36B, 36C and 36D	Auto	* N/A *	94.3	100.4
- 2 -	---	RO-1-2	+57 +31 +59 SI pumps 31 and 32 RHR pumps 31 and 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	* N/A *	509.2	509.2
- 3 -	E-0-9	---	+117 +120 +122 +123 CSP 32 (E-0-9 verifies that pump is running.)	Auto	* N/A *	0.0	319.5
- 4 -	---	RO-1-3	+33 FCUs 32, 34 and 35 (RO verifies that fans are running.)	Auto	* N/A *	258.0	129.0
- 5 -	---	RO-1-5	+21 +35 +37 AFWPs 31 and 33 (RO verifies that pumps are running.)	Auto	* N/A *	378.9	375.7
- 6 -	---	RO-1-7	+1 +2 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. (All Buses are powered from EDGs.)	Manual	* N/A *	0.0	0.0
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESWPs (35 and 36) (RO verifies that pumps are running.)	Auto	* N/A *	280.8	280.8
- 8 -	E-0-11	---	+27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 32 started on lightest loaded Bus.)	Manual	* N/A *	140.2	0.0
- 9 -	< 19 >	---	+14 *** INADVERTENT SI *** *** EVENT IDENTIFIED - EXIT TO ES-1.1 ***	Manual	* N/A *	0.0	0.0
			(No Loads Started or Tripped at this step)		* N/A *	1661.4	1714.6


INADVERTENT SI (PH B)

Report Date : August 25, 2009 Time : 3:56 PM [62]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	ES-1.1-1	---	Reset SI (Steps 2 through 12 of RO-1 are completed.)	Manual	* N/A *	0.0	0.0
					* N/A *	1661.4	1714.6
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15 (MCCs are reset.)	Manual	* N/A *	63.3	24.3
					* N/A *	1724.7	1739.4
- 12 -	ES-1.1-3	---	-S1 -83 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	* N/A *	0.0	0.0
					* N/A *	1724.7	1739.4
- 13 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (All RHR pumps stopped.) Stop SI pumps. (Only pumps 32 and 33 running - stopped.)	Manual	* N/A *	-509.2	-509.2
					* N/A *	1215.5	1230.2
- 14 -	ES-1.1-2	---	-117 -120 -122 -123 Start one CHARGING pump. (CHARGING pump 32 is running.)	Manual	* N/A *	0.0	0.0
					* N/A *	1215.5	1230.2
- 15 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs if 5 FCUs are running or Containment pressure is < 16 PSIG.	Manual	* N/A *	0.0	0.0
					* N/A *	1215.5	1230.2
- 16 -	ES-1.1-13	---	(No Loads Started or Tripped at this step) Check BAST transfer pumps are running (MCC 36A-E never striped.)	Manual	* N/A *	0.0	0.0
					* N/A *	1215.5	1230.2
- 17 -	NSE 99-3-075	NSE 99-3-075	(No Loads Started or Tripped at this step) ASA PER SECTION 4.2.20 of NSE One CSP run time is less than 30 minutes. (CSP 32 stopped.)	Manual	* N/A *	0.0	-319.5
					* N/A *	1215.5	910.7
- 18 -	ES-1.1-17	---	-35 Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Pressurizer Heater Control Group energized on lightest loaded Bus.) +114	Manual	* N/A *	0.0	277.0
					* N/A *	1215.5	1187.7

Step Number	SRO Step	RU Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	ES-1.1-19	---	Reset MCCs. Start CRDM Fans. (MCC are already reset. Bus 5A unavailable to power CRDM Fans.)	Manual	* N/A *	0.0	0.0
- 20 -	---	RO-1-27c	(No Loads Started or Tripped at this step) START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.) +47	Manual	* N/A *	41.5	0.0
- 21 -	ES-1.1-20	---	Stop 1 of 3 ESWPs. (ESWPs 35 and 36 are running.) Shutdown Motor-driven AFWPs if desired. (AFWPs remain running.)	Manual	* N/A *	1257.0	1187.7
- 22 -	ES-1.1-36	---	(No Loads Started or Tripped at this step) Check that at least two NESWPs are running. (NESWPs 32 and 33 are started.)	Manual	* N/A *	280.8	280.8
- 23 -	ES-1.1-27	---	+85 +86 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 32 started on lightest loaded Bus. Blowers started. CCR ventilation is running.) +88 +66 +67	Manual	* N/A *	1537.8	144.3
- 24 -	ES-1.1-33	---	Go to appropriate plant operating procedure as directed by the CRS or SW.	Manual	* N/A *	0.0	0.0
			(No Loads Started or Tripped at this step)		* N/A *	1537.8	1612.8

INADVERTENT SI (PH B)



Inadvertent SI (PH B)
 Buses 2A/3A Tied Together, Bus 5A Not Available
 Loss of Off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

1 AFWP 31	EDG 31
2 AFWP 33	EDG 32
3 CHARGING PUMP 32	EDG 31
4 ESWP 35	EDG 31
5 ESWP 36	EDG 32
6 FCU 32	EDG 31
7 FCU 34	EDG 31
8 FCU 35	EDG 32
14 MCC 34: TURBINE TURNING GEAR	EDG 31
15 MCC 36B: AUTO	EDG 32
16 MCC 36C: AUTO	EDG 31
17 MCC 36D: AUTO	EDG 32
18 MCC 37: PENT. BLOWER (#1)	EDG 32
19 MCC 37: PENT. BLOWER (#2)	EDG 32
20 MCCS RESET (2A/3A) AS PER SOP-EL-15	EDG 31
21 MCCS RESET (6A) AS PER SOP-EL-15	EDG 32
22 NESWP 32	EDG 31
23 NESWP 33	EDG 32
24 PAB FAN 32	EDG 32
25 PRESSURIZER HEATER CONTROL GROUP	EDG 32

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

193-CALC-ED-00267 REV 0

INADVERTENT SI (PH B)

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 1:56 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 2A AND/OR 3A NOT AVAILABLE ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = 1443.9 Bus 2A/3A = * N/A * Bus 6A = 1335.8 (kW)

1750 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1750 kW rating
Bus 2A and/or 3A Not Available
Emergency Diesel Generator 32 on Bus 6A is below the 1750 kW rating

1950 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1950 kW rating
Bus 2A and/or 3A Not Available
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating

INADVERTENT SI (PH B)


Report Date : August 25, 2009 Time : 3:56 PM [63]

Step Number	RO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36A, 36B, 36D and 36E	Auto	110.0	* N/A *	100.4
					110.0	* N/A *	100.4
- 2 -	---	RO-1-2	+50 +53 +59 +60 SI pumps 31 and 33 RHR pump 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	327.2	* N/A *	509.2
					437.2	* N/A *	609.6
- 3 -	E-0-9	---	+120 +121 +123 CSPs 31 and 32 (E-0-9 verifies that pump is running.)	Auto	307.3	* N/A *	319.5
					744.5	* N/A *	929.1
- 4 -	---	RO-1-3	+24 +25 FCUs 31, 33 and 35 (RO verifies that fans are running.)	Auto	258.0	* N/A *	129.0
					1002.5	* N/A *	1058.1
- 5 -	---	RO-1-5	+29 +33 +37 AFWps 33 (RO verifies that pump is running.)	Auto	0.0	* N/A *	375.7
					1002.5	* N/A *	1433.8
- 6 -	---	RO-1-7	+2 CHECK if Offsite power is available to a 480V Bus to start at least one OCWP. (All Buses are powered from SDGs.)	Manual	0.0	* N/A *	0.0
					1002.5	* N/A *	1433.8
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESWPs (34 and 36) (RO verifies that pump is running.)	Auto	280.8	* N/A *	280.8
					1283.3	* N/A *	1714.6
- 8 -	E-4-11	---	+26 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	140.2	* N/A *	0.0
					1423.5	* N/A *	1714.6
- 9 -	< 19 >	---	+13 *** INADVERTENT SI *** *** EVRNT IDENTIFIED - EXIT TO ES-1.1 ***	Manual	0.0	* N/A *	0.0
					1423.5	* N/A *	1714.6
			(No Loads Started or Tripped at this step)				

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step-Total Load (kW)	Bus 6A Step-Total Load (kW)
- 10 -	ES-1.1-1	---	Reset SI (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0	* N/A *	0.0
					1423.5	* N/A *	1714.6
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (MCCs are reset.)	Manual	89.8	* N/A *	24.8
					1509.3	* N/A *	1739.4
- 12 -	ES-1.1-3	---	+82 +83 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	* N/A *	0.0
					1509.3	* N/A *	1739.4
- 13 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pump. (Only pump 32 running - stopped.) Stop SI pumps. (Only pumps 31 and 33 running - stopped.)	Manual	-327.2	* N/A *	-509.2
					1182.1	* N/A *	1230.2
- 14 -	ES-1.1-8	---	-129 -131 -123 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	* N/A *	0.0
					1182.1	* N/A *	1230.2
- 15 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs if 5 FCUs are running or Containment pressure is < 15 PSIG.	Manual	0.0	* N/A *	0.0
					1182.1	* N/A *	1230.2
- 16 -	ES-1.1-13	---	(No Loads Started or Tripped at this step) Check BAST transfer pumps are running (MCC 36A-E never striped.)	Manual	0.0	* N/A *	0.0
					1182.1	* N/A *	1230.2
- 17 -	NSE 99-3-075	NSE 99-3-075	(No Loads Started or Tripped at this step) AS PER SECTION 4.2.20 of NSE One CSP run time is less than 30 minutes. (CSPs stopped.)	Manual	-307.7	* N/A *	-319.5
					874.8	* N/A *	910.7
- 18 -	ES-1.1-17	---	-24 -25 Energize at Least one Pressurizer Heater Group as per SOP-EL-15. (Pressurizer Heater Control Group energized on lightest loaded Bus.) +109	Manual	207.9	* N/A *	0.0
					1082.7	* N/A *	910.7

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	ES-1.1-19	---	Reset MCCs. Start CRDM Fans (MCC are already reset. CRDM Fans started on MCC 28.)	Manual	80.4 1163.1	* N/A * * N/A *	0.0 910.7
- 20 -	---	RO-1-27c	+70 +71 +72 +73 START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open.	Manual	0.0 1163.1	* N/A * * N/A *	0.0 910.7
- 21 -	ES-1.1-20	---	Start Turb Turning Gear. (Bus 2A/3A unavailable.) (No Loads Started or Tripped at this step) Stop 1 of 3 ESOWs. (ESOWs 34 and 35 are running.) Shutdown Motor-driven AFWs if desired. (Bus 2A/3A not available. AFWP 33 remains running)	Manual	0.0 1163.1	* N/A * * N/A *	0.0 910.7
- 22 -	ES-1.1-26	---	(No Loads Started or Tripped at this step) Check that at least two NESOWs are running. (NESOW 31 and 33 started.)	Manual	280.8 1443.9	* N/A * * N/A *	380.8 1191.5
- 23 -	ES-1.1-27	---	+84 +86 Start a PAB Fan, Penetration Blowers and CCR ventilation. (Bus 2A/3A unavailable, PAB Fan 32 started. Blowers started, CCR ventilation is running.)	Manual	0.0 1443.9	* N/A * * N/A *	144.3 1335.8
- 24 -	ES-1.1-32	---	+88 +66 +67 Go to appropriate plant operating procedure as directed by the CRS or SM.	Manual	0.0 1443.9	* N/A * * N/A *	0.0 1335.8
			(No Loads Started or Tripped at this step)				

INADVERTENT SI (PH B)



Inadvertent SI (PH B)
 Buses 2A and / or 3A Not Available
 Loss of Off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING

POWER FROM EDG

AFWP 33	EDG 32
CHARGING PUMP 31	EDG 33
ESWP 34	EDG 33
ESWP 36	EDG 32
FCU 31	EDG 33
FCU 33	EDG 33
FCU 35	EDG 32
MCC 36A: AUTO	EDG 33
MCC 36B: AUTO	EDG 32
MCC 36D: AUTO	EDG 32
MCC 36E: AUTO	EDG 33
MCC 37: PENT. BLOWER (#1)	EDG 32
MCC 37: PENT. BLOWER (#2)	EDG 32
MCC 38: CRDM FAN 31 (FAN#1)	EDG 33
MCC 38: CRDM FAN 32 (FAN#2)	EDG 33
MCC 38: CRDM FAN 33 (FAN#3)	EDG 33
MCC 38: CRDM FAN 34 (FAN#4)	EDG 33
MCCS RESET (5A) AS PER SOP-EL-15	EDG 33
MCCS RESET (6A) AS PER SOP-EL-15	EDG 32
NESWP 31	EDG 33
NESWP 33	EDG 32
PAB FAN 32	EDG 32
PRESSURIZER HEATER 33	EDG 33

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00267 REV 8

INADVERTENT SI
ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:56 PM

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2180.8 Bus 2A = 2129.2 Bus 3A = 1714.9 Bus 6A = 2367.0 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A/3A is below the 3200 Amp rating
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

INADVERTENT SI - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:56 PM [64]

Step Number	SRU Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36A, 36B, 36C, 36D and 36E	Auto	169.5	135.5	0.0	150.1
					169.5	135.5	0.0	150.1
- 2 -	---	RO-1-2	+57 +58 +53 +59 +60 SI pumps 31, 32 and 33 RRR pumps 31 and 32 (mini flow, RCS press > 325) {RO verifies that pumps are running.}	Auto	472.4	472.4	264.5	738.5
					641.9	607.9	264.5	888.6
- 3 -	W-0-9	---	+117 +120 +121 +122 +123 CSPs 31 and 32 {CSPs started during Phase B only.} {E-0-9 verifies that spray is not required.}	Manual	0.0	0.0	0.0	0.0
					641.9	607.9	264.5	888.6
- 4 -	---	RO-1-3	{No Loads Started or Tripped at this step} FCUs 31, 32, 33, 34 and 35 {RO verifies that fans are running.}	Auto	491.9	247.2	246.0	248.0
					1133.8	855.1	510.5	1136.6
- 5 -	---	RO-1-5	+29 +31 +33 +35 +37 AFWPs 31 and 33 {RO verifies that pumps are running.}	Auto	0.0	0.0	575.4	562.9
					1133.8	855.1	1085.9	1699.5
- 6 -	---	RO-1-7	+1 +2 CCWPs 31, 32 and 33 {RO verifies that pumps are running.}	Auto	250.5	251.3	0.0	251.2
					1384.3	1106.4	1085.9	1950.7
- 7 -	---	RO-1-8	+4 +7 +10 ESWPs (34, 35 and 36) {RO verifies that pumps are running.}	Auto	429.8	0.0	429.0	429.8
					1814.1	1106.4	1514.9	2380.5
- 8 -	E-0-11	---	+25 +27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {CHARGING pump 32 started on lightest loaded Bus.}	Manual	0.0	0.0	208.9	0.0
					1814.1	1106.4	1723.8	2380.5
- 9 -	< 10 >	---	+14 *** INADVERTENT SI *** *** EVENT IDENTIFIED - EXIT TO ES-1.1 ***	Manual	0.0	0.0	0.0	0.0
					1814.1	1106.4	1723.8	2380.5
			{No Loads Started or Tripped at this step}					

INADVERTENT SI - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:56 PM [64]


Step Number	SKO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	ES-1.1-1	---	Reset SI (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0	0.0	0.0	0.0
					1814.1	1106.4	1723.8	2380.5
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset.)	Manual	659.0	848.0	507.6	252.2
					3473.9	1954.4	2231.4	2632.7
- 12 -	ES-1.1-3	---	+126 +124 +125 +127 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	0.0	0.0	0.0
					2473.9	1954.4	2231.4	2632.7
- 13 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (All RHR pumps stopped.) Stop SI pumps. (All SI pumps stopped.)	Manual	-472.4	-472.4	-264.5	-738.5
					2001.5	1482.0	1966.9	1894.2
- 14 -	ES-1.1-8	---	-117 -120 -121 -122 -123 Start one CHARGING pump. (CHARGING pump 32 is running.)	Manual	0.0	0.0	0.0	0.0
					2001.5	1482.0	1966.9	1894.2
- 15 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs. (Spray not actuated. No pumps are running.)	Manual	0.0	0.0	0.0	0.0
					2001.5	1482.0	1966.9	1894.2
- 16 -	ES-1.1-13	---	(No Loads Started or Tripped at this step) Check BAST transfer pumps are running. (MCC 16A-B never striped.)	Manual	0.0	0.0	0.0	0.0
					2001.5	1482.0	1966.9	1894.2
- 17 -	ES-1.1-16	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group. as per SOP-EL-15. (Energized Pressurizer Heater Group 32 on lightest loaded Bus.)	Manual	0.0	540.3	0.0	0.0
					2001.5	2022.3	1966.9	1894.2
- 18 -	ES-1.1-18	---	+95 Reset MCCs. Start CRDM Fans (MCCs are already reset. CRDM Fan loads accounted for in MCC resets.)	Manual	0.0	0.0	0.0	0.0
					2001.5	2022.3	1966.9	1894.2
			(No Loads Started or Tripped at this step)					

INADVERTENT SI - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:56 PM [64]

Step Number	Seq Step	FO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	---	RO-1-27c	START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.) +47	Manual	0.0 2001.5	63.8 2086.1	0.0 1956.9	0.0 1894.2
- 20 -	ES-1.1-20	---	Stop 1 of 3 CCWPs. Stop 1 of 3 ESWPs and Shutdown Motor-driven AFWPs if desired. (First CCWP 31 and then ESWP 35 stopped on heaviest loaded Buses. AFWPs remain running.) +8 +11 +4 +7 +10 +27	Manual	-250.5 1751.0	-43.1 2129.2	-429.0 1537.9	43.0 1937.2
- 21 -	ES-1.1-24	---	Check that at least two NESWPs are running. (NESWP 31 and 33 started on lightest loaded Bus.) +24 +26	Manual	429.8 2180.8	0.0 2129.2	0.0 1537.9	429.8 2367.0
- 22 -	ES-1.1-27	---	Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 31 started on lightest loaded Bus. Blowers and CCR ventilation started at MCC reset.) +87	Manual	0.0 2180.8	0.0 2129.2	177.0 1714.9	0.0 2367.0
- 23 -	ES-1.1-12	---	Go to appropriate plant operating procedure as directed by the CRS or SM. (No Loads Started or Tripped at this step)	Manual	0.0 2180.8	0.0 2129.2	0.0 1714.9	0.0 2367.0

INADVERTENT SI



Inadvertent SI
 Total MCC and Lighting Reset
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 31	3A
AFWP 33	6A
CCWP 32	2A
CCWP 33	6A
CHARGING PUMP 32	3A
ESWP 34	5A
ESWP 36	6A
FCU 31	5A
FCU 32	2A
FCU 33	5A
FCU 34	3A
FCU 35	6A
MCC 34: TURBINE TURNING GEAR	3A
MCC 36A: AUTO	5A
MCC 36B: AUTO	6A
MCC 36C: AUTO	2A
MCC 36D: AUTO	6A
MCC 36E: AUTO	5A
NESWP 31	5A
NESWP 33	6A
PAB FAN 31	3A
PRESSURIZER HEATER 32	2A
TOTAL MCC & LIGHTING RESET (2A)	
TOTAL MCC & LIGHTING RESET (3A)	
TOTAL MCC & LIGHTING RESET (5A)	
TOTAL MCC & LIGHTING RESET (6A)	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

INADVERTENT SI

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:55 PM

*** BUSES 2A AND 3A TIED TOGETHER ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2252.9 Bus 2A/3A = 2533.1 Bus 6A = 2422.8 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A/3A is below the 3200 Amp rating
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

INADVERTENT SI

Report Date : August 25, 2009 Time : 3:56 PM [65]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	RCC 36A, 36B, 36C, 36D and 36E	Auto	169.5	135.5	150.1
					169.5	135.5	150.1
- 2 -	---	RO-1-2	+57 +58 +59 +60 SI pumps 31, 32 and 33 RHR pumps 31 and 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	472.4	736.9	738.5
					641.9	872.4	888.6
- 3 -	E-0-9	---	+117 +120 +121 +122 +123 CSPs 31 and 32 (Spray not required. CSPs started during Phase B only.) (E-0-9 verifies that pumps are not running.)	Manual	0.0	0.0	0.0
					641.9	872.4	888.6
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCUs 31, 32, 33, 34 and 35 (RO verifies that fans are running.)	Auto	491.9	493.2	248.0
					1133.8	1365.6	1136.6
- 5 -	---	RO-1-5	+29 +31 +33 +35 +37 AFWPs 31 and 33 (RO verifies that pumps are running.)	Auto	0.0	578.4	562.9
					1133.8	1941.0	1699.5
- 6 -	---	RO-1-7	+1 +2 CCHPs 31, 32 and 33 (RO verifies that pumps are running.)	Auto	250.5	251.3	251.2
					1364.3	2192.3	1950.7
- 7 -	---	RO-1-8	+4 +7 +10 ESWPs (34, 35 and 36) (RO verifies that pumps are running.)	Auto	429.8	429.0	429.3
					1214.1	2621.3	2380.5
- 8 -	E-0-11	---	+26 +27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	208.5	0.0	0.0
					2022.6	2621.3	2380.5
- 9 -	< 10 >	---	+13 *** INADVERTENT SI *** *** EVENT IDENTIFIED - EXIT TO ES-1.1 *** (No Loads Started or Tripped at this step)	Manual	0.0	0.0	0.0
					2022.6	2621.3	2380.5

INADVERTENT SI

Report Date : August 25, 2009 Time : 3:56 PM [65]


Step Number	SKO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	ES-1.1-1	---	Reset SI (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0 2022.6	0.0 2621.3	0.0 2380.5
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset.)	Manual	659.8 2682.4	407.2 3028.5	252.2 2632.7
- 12 -	ES-1.1-3	---	+126 +127 +3 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0 2682.4	0.0 3028.5	0.0 2632.7
- 13 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (All RHR pumps stopped.) Stop SI pumps. (All SI pumps stopped.)	Manual	-472.4 2210.0	-736.9 2291.6	-738.5 1894.2
- 14 -	ES-1.1-8	---	-117 -120 -121 -122 -123 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0 2210.0	0.0 2291.6	0.0 1894.2
- 15 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs. (Spray not actuated. No pumps are running.)	Manual	0.0 2210.0	0.0 2291.6	0.0 1894.2
- 16 -	ES-1.1-12	---	(No Loads Started or Tripped at this step) Check BAST transfer pumps are running. (MCC 36A-R never stripped.)	Manual	0.0 2210.0	0.0 2291.6	0.0 1894.2
- 17 -	ES-1.1-17	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group. as per SOP-EL-15. (Energized Pressurizer Heater Control Group on lightest loaded Bus.)	Manual	0.0 2210.0	0.0 2291.6	308.6 2102.8
- 18 -	ES-1.1-19	---	+114 Reset MCCs. Start CRDM Fans. (MCCs are already reset. CRDM Fan loads accounted for in MCC resets.)	Manual	0.0 2210.0	0.0 2291.6	0.0 2202.8
			(No Loads Started or Tripped at this step)				

INADVERTENT SI

Report Date : August 25, 2009 Time : 3:56 PM [65]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	---	RO-1-27c	START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.) +47	Manual	0.0 2310.0	62.8 2355.4	0.0 2202.8
- 20 -	ES-1.1-26	---	Stop 1 of 3 CCWPs. Stop 1 of 3 ESWPs and Shutdown Motor-driven AFWPs if desired. (First CCWP 32 and then ESWP 34 stopped on heaviest loaded Buses. AFWPs remain running.) +5 +11 -4 -7 -10 -26	Manual	-386.9 1823.1	-251.3 2104.1	43.0 2245.8
- 21 -	ES-1.1-26	---	Check that at least two NESWPs are running. (NESWP 31 and 32 started on lightest loaded Bus.)	Manual	429.8 2252.9	429.0 2533.1	0.0 2245.8
- 22 -	ES-1.1-27	---	+84 -85 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 32 started on lightest loaded Bus. Blowers and CCR vent. started at MCC reset.) +88	Manual	0.0 2252.9	0.0 2533.1	177.0 2422.8
- 23 -	ES-1.1-32	---	Go to appropriate plant operating procedure as directed by the CRS or SM. (No Loads Started or Tripped at this step)	Manual	0.0 2252.9	0.0 2533.1	0.0 2422.8

INADVERTENT SI



Inadvertent SI
 Buses 2A/3A Tied Together, All Buses Available
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 31	3A
AFWP 33	6A
CCWP 31	5A
CCWP 33	6A
CHARGING PUMP 31	5A
ESWP 35	3A
ESWP 36	6A
FCU 31	5A
FCU 32	2A
FCU 33	5A
FCU 34	3A
FCU 35	6A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36A: AUTO	5A
MCC 36B: AUTO	6A
MCC 36C: AUTO	2A
MCC 36D: AUTO	6A
MCC 36E: AUTO	5A
NESWP 31	5A
NESWP 32	2A
PAB FAN 32	6A
PRESSURIZER HEATER CONTROL GROUP	6A
TOTAL MCC & LIGHTING RESET (5A)	
TOTAL MCC & LIGHTING RESET (6A)	
MCCS RESET (2A/3A) AS PER SOP-EL-15	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

INADVERTENT 51

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:56 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 6A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2914.3 Bus 2A/3A = 3004.5 Bus 6A = * N/A * (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A/3A is below the 3200 Amp rating
Bus 6A Not Available

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A Not Available

INADVERTENT SI

Report Date : August 25, 2009 Time : 3:56 PM [66]

Step Number	SRG Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36A, 36C and 36E	Auto	169.5	135.5	* N/A *
- 2 -	---	RO-1-2	+57 +50 +60 SI pumps 31 and 32 RHR pump 31 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	472.4	736.9	* N/A *
- 3 -	E-0-9	---	+117 +121 +122 CSP 31 (Spray not required. CSPs started during Phase B only.) (E-0-9 verifies that pumps are not running.)	Manual	0.0	0.0	* N/A *
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCUs 31, 32, 33 and 34 (RO verifies that fans are running.)	Auto	491.9	493.2	* N/A *
- 5 -	---	RO-1-5	+29 +31 +33 +35 AFWP 31 (RO verifies that pump is running.)	Auto	0.0	575.4	* N/A *
- 6 -	---	RO-1-7	+1 CCWPs 31 and 32 (RO verifies that pumps are running.)	Auto	292.4	294.4	* N/A *
- 7 -	---	RO-1-8	+4 +7 ESWPs (34 and 35) (RO verifies that pumps are running.)	Auto	429.0	429.0	* N/A *
- 8 -	E-0-11	---	+26 +27 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	268.5	0.0	* N/A *
- 9 -	< 19 >	---	+13 *** INADVERTENT SI *** *** EVENT IDENTIFIED - EXIT TO ES-1.1 *** (No Loads Started or Tripped at this step)	Manual	0.0	0.0	* N/A *
					2065.5	2664.4	* N/A *

INADVERTENT SI

Report Date : August 25, 2009 Time : 3:56 PM [66]


Step Number	S20 Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/2A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	ES-1.1-1	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0 2065.5	0.0 2664.4	* N/A * * N/A *
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset.)	Manual	659.8 2725.3	407.2 3071.6	* N/A * * N/A *
- 12 -	ES-1.1-2	---	+120 +3 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0 2725.3	0.0 3071.6	* N/A * * N/A *
- 13 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (Only pump 31 running-stopped.) Stop SI pumps. (Only pumps 31 and 32 running - stopped.)	Manual	-472.4 2252.9	-736.9 2334.7	* N/A * * N/A *
- 14 -	ES-1.1-5	---	-117 -121 -122 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0 2252.9	0.0 2334.7	* N/A * * N/A *
- 15 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs. (Spray not actuated. No pumps are running.)	Manual	0.0 2252.9	0.0 2334.7	* N/A * * N/A *
- 16 -	ES-1.1-13	---	(No Loads Started or Tripped at this step) Check BAST transfer pumps are running. (MCC 36A-E never striped.)	Manual	0.0 2252.9	0.0 2334.7	* N/A * * N/A *
- 17 -	ES-1.1-17	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group. as per SOP-EL-15. (Energized Pressurizer Heater Group 23 on lightest loaded Bus.)	Manual	231.6 2484.5	0.0 2334.7	* N/A * * N/A *
- 18 -	ES-1.1-19	---	+109 Reset MCCs. Start CRDM Fans. (MCCs are already reset. CRDM Fan loads accounted for in MCC resets.) (No Loads Started or Tripped at this step)	Manual	0.0 2484.5	0.0 2334.7	* N/A * * N/A *

UNADVERTENT SI

Report Date : August 25, 2009 Time : 3:56 PM [66]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	---	RO-1-27c	START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.) +47	Manual	0.0 2484.5	63.0 2398.5	* N/A * * N/A *
- 20 -	ES-1.1-30	---	Stop 1 of 3 CCWPs. (CCWPs 31 and 32 running.) Stop 1 of 3 ESWPs. (ESWPs 34 and 35 running.) Shutdown Motor-Driven APNPs if desired. (Bus 6A not available. APWP 31 remains running.) (No Loads Started or Tripped at this step)	Manual	0.0 2484.5	0.0 2398.5	* N/A * * N/A *
- 21 -	ES-1.1-35	---	Check that at least two NESWPs are running. (NESWP 31 and 32 started)	Manual	429.8 2914.3	429.0 2827.5	* N/A * * N/A *
- 22 -	ES-1.1-37	---	+84 +85 Start a PAB Fan. Penetration Blowers and CCR ventilation. (PAB Fan 31 started. Blowers unavailable, powered from Bus 6A/MCC37, CCR vent. is running) +87	Manual	0.0 2914.3	177.0 3004.5	* N/A * * N/A *
- 23 -	ES-1.1-32	---	Go to appropriate plant operating procedure as directed by the CRS or SM. (No Loads Started or Tripped at this step)	Manual	0.0 2914.3	0.0 3004.5	* N/A * * N/A *

INADVERTENT SI



Inadvertent SI
 Buses 2A/3A Tied Together, Bus 6A Not Available
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 31	3A
CCWP 31	5A
CCWP 32	2A
CHARGING PUMP 31	5A
ESWP 34	5A
ESWP 35	3A
FCU 31	5A
FCU 32	2A
FCU 33	5A
FCU 34	3A
MCC 35: TURBINE TURNING GEAR	2A
MCC 36A: AUTO	5A
MCC 36C: AUTO	2A
MCC 36E: AUTO	5A
NESWP 31	5A
NESWP 32	2A
PAB FAN 31	3A
PRESSURIZER HEATER 33	5A
TOTAL MCC & LIGHTING RESET (5A)	
MCCS RESET (2A/3A) AS PER SOP-EL-15	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1
IP3-CALC-ED-00207 REV 8

INADVERTENT ST

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:56 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 5A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = * N/A * Bus 2A/3A = 3004.5 Bus 6A = 2885.2 (A)

3200 Amp Overload Summary

Bus 5A Not Available
Bus 2A/3A is below the 3200 Amp rating
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A Not Available
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

INADVERTENT SI

Report Date : August 30, 2009 Time : 3:56 PM [57]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 3A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36B, 36C and 36D	Auto	* N/A *	135.5	150.1
- 2 -	---	RO-1-2	+57 +53 +59 SI pumps 32 and 33 RHR pumps 31 and 32 (mini flow, RCS press > 325) {RO verifies that pumps are running.}	Auto	* N/A *	736.9	738.5
- 3 -	E-0-9	---	+117 +120 +122 +123 CSP 32 (Spray not required.) {CSPs started during Phase B only.} {E-0-9 verifies that pump is not running.}	Manual	* N/A *	0.0	0.0
- 4 -	---	RO-1-3	{No Loads Started or Tripped at this step} FCUs 32, 34 and 35 {RO verifies that fans are running.}	Auto	* N/A *	493.2	248.0
- 5 -	---	RO-1-5	+31 +35 +37 APWPs 31 and 33 {RO verifies that pumps are running.}	Auto	* N/A *	575.4	562.9
- 6 -	---	RO-1-7	+1 +2 CCWPs 32 and 33 {RO verifies that pumps are running.}	Auto	* N/A *	294.4	294.2
- 7 -	---	RO-1-8	+7 +10 ESNPs (35 and 36) {RO verifies that pumps are running.}	Auto	* N/A *	429.0	429.8
- 8 -	E-0-11	---	+27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {CHARGING pump 33 started on lightest loaded Bus.}	Manual	* N/A *	0.0	209.6
- 9 -	< 19 >	---	+15 *** INADVERTENT SI *** *** EVENT IDENTIFIED - EXIT TO ES-1.1 *** {No Loads Started or Tripped at this step}	Manual	* N/A *	0.0	0.0
					* N/A *	2664.4	2633.1

INADVERTENT SI

Report Date : August 25, 2009 Time : 3:56 PM [67]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	ES-1.1-1	---	Reset SI (Steps 2 through 12 of RO-1 are completed.)	Manual	* N/A *	0.0	0.0
					* N/A *	2664.4	2633.1
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset.)	Manual	* N/A *	407.2	252.2
					* N/A *	3071.6	2885.3
- 12 -	ES-1.1-3	---	+127 +3 ESTABLISH Instrument Air to Containment. (load accounted for in MCC reset.)	Manual	* N/A *	0.0	0.0
					* N/A *	3071.6	2885.3
- 13 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (All RHR pumps stopped.) Stop SI pumps. (Only pumps 32 and 33 running-stopped.)	Manual	* N/A *	-736.9	-738.5
					* N/A *	2334.7	2146.8
- 14 -	ES-1.1-8	---	-117 -120 -122 -123 Start one CHARGING pump. (CHARGING pump 33 is running.)	Manual	* N/A *	0.0	0.0
					* N/A *	2334.7	2146.8
- 15 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs. (Spray not actuated. No pumps are running.)	Manual	* N/A *	0.0	0.0
					* N/A *	2334.7	2146.8
- 16 -	ES-1.1-13	---	(No Loads Started or Tripped at this step) Check BAST transfer pumps are running. (MCC 36A-E never stripped.)	Manual	* N/A *	0.0	0.0
					* N/A *	2334.7	2146.8
- 17 -	ES-1.1-17	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group. as per SOP-EL-15. (Energized Pressurizer Heater Control Group start on lightest loaded Bus.)	Manual	* N/A *	0.0	308.6
					* N/A *	2334.7	2455.4
- 18 -	ES-1.1-19	---	+114 Reset MCCs. Start CRDM Fans (MCCs are already reset. CRDM Fans unavailable, power from Bus 5A/MCC 38.)	Manual	* N/A *	0.0	0.0
					* N/A *	2334.7	2455.4
			(No Loads Started or Tripped at this step)				

INADVERTENT SI

Report Date : August 25, 2009 Time : 3:56 PM [67]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	---	RO-1-27c	START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.) +47	Manual	* N/A *	63.8	0.0
- 20 -	ES-1.1-20	---	Stop 1 of 3 COWPs. (COWPs 32 and 33 running.) Stop 1 of 3 ESOWPs. (ESOWPs 35 and 36 running.) Shutdown Motor-driven AFWPs if desired. (AFWPs remain running.) (No Loads Started or Tripped at this step)	Manual	* N/A *	2398.5	2455.4
- 21 -	ES-1.1-26	---	Check that at least two NESOWPs are running. (NESOWP 32 and 33 started.)	Manual	* N/A *	429.0	429.8
- 22 -	ES-1.1-27	---	+85 +86 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 31 started on lightest loaded Bus. Blowers and CCR vent. at MCC reset.)	Manual	* N/A *	3827.5	2885.2
- 23 -	ES-1.1-32	---	-87 Go to appropriate plant operating procedure as directed by the CRS or SM. (No Loads Started or Tripped at this step)	Manual	* N/A *	177.0	0.0
					* N/A *	3004.5	2885.2
					* N/A *	0.0	0.0
					* N/A *	3004.5	2885.2

INADVERTENT SI



Inadvertent SI
 Buses 2A/3A Tied Together, Bus 5A Not Available
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 31	3A
AFWP 33	6A
CCWP 32	2A
CCWP 33	6A
CHARGING PUMP 33	6A
ESWP 35	3A
ESWP 36	6A
FCU 32	2A
FCU 34	3A
FCU 35	6A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36B: AUTO	6A
MCC 36C: AUTO	2A
MCC 36D: AUTO	6A
NESWP 32	2A
NESWP 33	6A
PAB FAN 32	6A
PRESSURIZER HEATER 31	3A
MCCS RESET (2A/3A) AS PER SOP-EL-15	
TOTAL MCC & LIGHTING RESET (6A)	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1
IP3-CALC-ED-00207 REV B

INADVERTENT SI

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:56 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 2A AND/OR 3A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2682.7 Bus 2A/3A = * N/A * Bus 6A = 2852.6 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A and/or 3A Not Available
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A and/or 3A Not Available
Bus 6A is below the 3600 Amp rating

INADVERTENT SI

Report Date : August 25, 2009 Time : 3:56 PM [68]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 35A, 35B, 36D and 36E	Auto	169.5	* N/A *	150.1
					169.5	* N/A *	150.1
- 2 -	---	RO-1-2	+50 +53 +55 +60 SI pumps 31 and 33 RHR pump 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	472.4	* N/A *	738.5
					641.9	* N/A *	888.6
- 3 -	E-0-9	---	+120 +121 +123 CSPs 31 and 32 (Spray not required. CSPs started during phase B only.) (E-0-9 verifies that pumps are not running.)	Manual	0.0	* N/A *	0.0
					641.9	* N/A *	888.6
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCUs 31, 33 and 35 (RO verifies that fans are running.)	Auto	491.9	* N/A *	248.0
					1133.8	* N/A *	1136.6
- 5 -	---	RO-1-5	+29 +33 +37 APWP 33 (RO verifies that pump is running.)	Auto	0.0	* N/A *	562.9
					1133.8	* N/A *	1699.5
- 6 -	---	RO-1-7	+2 CCWPs 31 and 33 (RO verifies that pumps are running.)	Auto	293.4	* N/A *	294.2
					1427.2	* N/A *	1993.7
- 7 -	---	RO-1-8	+4 +10 ESWPs (34 and 36) (PO verifies that pumps are running.)	Auto	429.8	* N/A *	429.8
					1857.0	* N/A *	2423.5
- 8 -	E-0-11	---	+26 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	306.5	* N/A *	0.0
					2065.5	* N/A *	2423.5
- 9 -	< 19 >	---	+13 *** INADVERTENT SI *** *** EVENT IDENTIFIED - EXIT TO ES-1.1 *** (No Loads Started or Tripped at this step)	Manual	0.0	* N/A *	0.0
					2065.5	* N/A *	2423.5

INADVERTENT SI

Report Date : August 25, 2009 Time : 3:56 PM [68]


Step Number	ERO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	ES-1.1-1	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0	* N/A *	0.0
					2065.5	* N/A *	2423.5
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset.)	Manual	659.8	* N/A *	252.2
					2725.3	* N/A *	2675.7
- 12 -	ES-1.1-3	---	+126 +127 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	* N/A *	0.0
					2725.3	* N/A *	2675.7
- 13 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (Only pump 32 running - stopped.) Stop SI pumps. (Only pumps 31 and 33 running - stopped.)	Manual	-472.4	* N/A *	-738.5
					2252.9	* N/A *	1937.2
- 14 -	ES-1.1-8	---	-120 -121 -123 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	* N/A *	0.0
					2252.9	* N/A *	1937.2
- 15 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs. (Spray not actuated. No pumps are running.)	Manual	0.0	* N/A *	0.0
					2252.9	* N/A *	1937.2
- 16 -	ES-1.1-13	---	(No Loads Started or Tripped at this step) Check BAST transfer pumps are running. (MCC 16A-B never stripped.)	Manual	0.0	* N/A *	0.0
					2252.9	* N/A *	1937.2
- 17 -	ES-1.1-17	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group. (Energized Pressurizer Heater Control Group on lightest loaded Bus.)	Manual	0.0	* N/A *	309.6
					2252.9	* N/A *	2245.8
- 18 -	ES-1.1-19	---	+114 Reset MCCs. Start CRDM Fans. (MCC are already reset. CRDM Fan Loads accounted for in MCC resets.)	Manual	0.0	* N/A *	0.0
					2252.9	* N/A *	2245.8
			(No Loads Started or Tripped at this step)				

INADVERTENT SI

Report Date : August 25, 2009 Time : 3:56 PM (68)

Step Number	SNO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 4A Step/Total Load (A)
- 19 -	---	RO-1-27c	START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Bus 2A/3A unavailable.) (No Loads Started or Tripped at this step)	Manual	0.0 2252.9	* N/A * * N/A *	0.0 2245.8
- 20 -	ES-1.1-26	---	Stop 1 of 3 CCWPs. (CCWPs 31 and 33 running.) Stop 1 of 3 ESWPs. (ESWPs 34 and 36 running.) Shutdown Motor-driven AFWPs if desired. (Bus 2A/3A not available. APWP 33 remains running) (No Loads Started or Tripped at this step)	Manual	0.0 2252.9	* N/A * * N/A *	0.0 2245.8
- 21 -	ES-1.1-28	---	Check that at least two NESWPs are running. (NESWP 31 and 33 started.)	Manual	429.8 2682.7	* N/A * * N/A *	429.8 2675.6
- 22 -	ES-1.1-27	---	+B4 -B6 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 32 started. Blowers and CCR ventilation started at MCC reset.)	Manual	0.0 2682.7	* N/A * * N/A *	177.0 2652.6
- 23 -	ES-1.1-32	---	+B8 Go to appropriate plant operating procedure as directed by the CRS or SM. (No Loads Started or Tripped at this step)	Manual	0.0 2682.7	* N/A * * N/A *	0.0 2652.6

INADVERTENT SI



Inadvertent SI
 Buses 2A and / or 3A Not Available
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 33	6A
CCWP 31	5A
CCWP 33	6A
CHARGING PUMP 31	5A
ESWP 34	5A
ESWP 36	6A
FCU 31	5A
FCU 33	5A
FCU 35	6A
MCC 36A: AUTO	5A
MCC 36E: AUTO	5A
MCC 36B: AUTO	6A
MCC 36D: AUTO	6A
NESWP 31	5A
NESWP 33	6A
PAB FAN 32	6A
PRESSURIZER HEATER CONTROL GROUP	6A
TOTAL MCC & LIGHTING RESET (5A)	
TOTAL MCC & LIGHTING RESET (6A)	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES

ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 2

INADVERTENT SI

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:56 PM

*** BUSES 2A AND 3A TIED TOGETHER ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = 1163.1 Bus 2A/3A = 1231.1 Bus 6A = 1221.5 (kW)

1750 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1750 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1750 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1750 kW rating

1950 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1950 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1950 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating

INADVERTENT SI

Report Date : August 25, 2009 Time : 3:56 PM (62)

Step Number	SRU Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36A, 36B, 36C, 36D and 36E	Auto	110.0 110.0	94.3 94.1	100.4 100.4
- 2 -	---	RO-1-2	+57 +58 +53 +59 +60 SI pumps 31, 32 and 33 RHR pumps 31 and 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	327.2 437.2	509.2 603.5	509.2 609.6
- 3 -	E-0-9	---	+117 +120 +121 +122 +123 CSPs 31 and 32 (Spray not required. CSPs started during Phase B only.) (E-0-9 verifies that pumps are not running.)	Manual	0.0 437.2	0.0 603.5	0.0 609.6
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCUs 31, 32, 33, 34 and 35 (RO verifies that fans are running.)	Auto	258.0 695.2	258.0 861.5	129.0 738.6
- 5 -	---	RO-1-5	+29 +31 +33 +35 +37 AFWPs 31 and 33 (RO verifies that pumps are running.)	Auto	0.0 695.2	378.9 1240.4	375.7 1114.3
- 6 -	---	RO-1-7	+1 +2 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. (All Buses are powered from EDGs.)	Manual	0.0 695.2	0.0 1240.4	0.0 1114.3
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESWPs (34, 35 and 36) (RO verifies that pumps are running.)	Auto	280.8 976.0	280.8 1521.2	280.8 1395.1
- 8 -	E-0-11	---	+26 +27 -28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	140.2 1116.2	0.0 1521.2	0.0 1395.1
- 9 -	< 19 >	---	+13 *** INADVERTENT SI *** *** EVENT IDENTIFIED - EXIT TO ES-1.1 *** (No Loads Started or Tripped at this step)	Manual	0.0 1116.2	0.0 1521.2	0.0 1395.1

INADVERTENT SI

Report Date : August 25, 2009 Time : 3:56 PM [69]


Step Number	ERO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	ES-1.1-1	---	Reset SI (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0 1116.2	0.0 1521.2	0.0 1396.1
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15 (MCC are reset.)	Manual	85.8 1202.0	61.3 1584.5	24.8 1419.9
- 12 -	ES-1.1-3	---	+82 +81 +83 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0 1202.0	0.0 1584.5	0.0 1419.9
- 13 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (All RHR pumps stopped.) Stop SI pumps. (All SI pumps stopped.)	Manual	-327.2 874.8	-509.2 1075.3	-509.2 910.7
- 14 -	ES-1.1-8	---	-117 -120 -121 -122 -123 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0 874.8	0.0 1075.3	0.0 910.7
- 15 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs. (Spray not actuated. No pumps are running.)	Manual	0.0 874.8	0.0 1075.3	0.0 910.7
- 16 -	ES-1.1-13	---	(No Loads Started or Tripped at this step) Check BAST transfer pumps are running. (MCC 26A-E never stripped.)	Manual	0.0 874.8	0.0 1075.3	0.0 910.7
- 17 -	ES-1.1-17	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Pressurizer Heater 33 energized on lightest loaded Bus.)	Manual	207.9 1082.7	0.0 1075.3	0.0 910.7
- 18 -	ES-1.1-19	---	-109 Reset MCCs. Start CRDM Fans. (MCC are already reset. CRDM Fans started on MCC 38.)	Manual	80.4 1163.1	0.0 1075.3	0.0 910.7
			+70 +71 +72 +73				

INADVERTENT ST

Report Date : August 25, 2009 Time : 3:56 PM (69)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	---	RO-1-27c	START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.) +47	Manual	0.0 1163.1	41.5 1116.8	0.0 910.7
- 20 -	ES-1.1-20	---	Stop 1 of 3 ESWPs. (ESWP 34 stopped on heaviest loaded Bus.) Shutdown Motor-driven AFWPs if desired, (AFWPs remain running.) -26	Manual	-280.8 882.3	0.0 1116.8	0.0 910.7
- 21 -	ES-1.1-26	---	Check that at least two NESWPs are running. (NESWPs 31 and 33 started on lightest loaded Buses.)	Manual	280.8 1163.1	0.0 1116.8	280.8 1191.5
- 22 -	ES-1.1-27	---	+84 +86 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 31 started on lightest loaded Bus. Blowers started, CCR ventilation is running.)	Manual	0.0 1163.1	114.3 1231.1	30.0 1221.5
- 23 -	ES-1.1-32	---	+87 +88 +87 Go to appropriate plant procedure as directed by the CRS or SM.	Manual	0.0 1163.1	0.0 1231.1	0.0 1221.5
(No Loads Started or Tripped at this step)							

INADVERTENT SI



Inadvertent SI
 Buses 2A/3A Tied Together, All Buses Available
 Loss of Off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

AFWP 31	EDG 31
AFWP 33	EDG 32
CHARGING PUMP 31	EDG 33
ESWP 35	EDG 31
ESWP 36	EDG 32
FCU 31	EDG 33
FCU 32	EDG 31
FCU 33	EDG 33
FCU 34	EDG 31
FCU 35	EDG 32
MCC 34: TURBINE TURNING GEAR	EDG 31
MCC 36A: AUTO	EDG 33
MCC 36B: AUTO	EDG 32
MCC 36C: AUTO	EDG 31
MCC 36D: AUTO	EDG 32
MCC 36E: AUTO	EDG 33
MCC 37: PENT. BLOWER (#1)	EDG 32
MCC 37: PENT. BLOWER (#2)	EDG 32
MCC 38: CRDM FAN 31 (FAN#1)	EDG 33
MCC 38: CRDM FAN 32 (FAN#2)	EDG 33
MCC 38: CRDM FAN 33 (FAN#3)	EDG 33
MCC 38: CRDM FAN 34 (FAN#4)	EDG 33
MCCS RESET (2A/3A) AS PER SOP-EL-15	EDG 31
MCCS RESET (5A) AS PER SOP-EL-15	EDG 33
MCCS RESET (6A) AS PER SOP-EL-15	EDG 32
NESWP 31	EDG 33
NESWP 33	EDG 32
PAB FAN 31	EDG 31
PRESSURIZER HEATER 33	EDG 33

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

EP3-CALC-ED-00307 REV 3

INADVERTENT S1

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:55 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 6A NOT AVAILABLE ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = 1443.9 Bus 2A/3A = 1911.9 Bus 6A = * N/A * (kW)

1750 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1750 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1750 kW rating
Bus 6A Not Available

1950 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1950 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1950 kW rating
Bus 6A Not Available

INADVERTENT SI

Report Date : August 25, 2009 Time : 3:56 PM [70]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36A, 36C and 36E	Auto	110.0	94.3	* N/A *
					110.0	94.3	* N/A *
- 2 -	---	RO-1-2	+57 +58 +60 SI pumps 31 and 32 RHR pump 31 (mini flow, RCS press > 225) {RO verifies that pumps are running.}	Auto	327.2	509.2	* N/A *
					437.2	603.5	* N/A *
- 3 -	E-0-9	---	+117 +121 +122 CSP 31 (Spray not required. {CSPs started during phase B only.} {E-0-9 verifies that pump is not running.}	Manual	0.0	0.0	* N/A *
					437.2	603.5	* N/A *
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCUs 31, 32, 33 and 34 {RO verifies that fans are running.}	Auto	258.0	258.0	* N/A *
					695.2	861.5	* N/A *
- 5 -	---	RO-1-5	+29 +31 +33 +35 APNP 31 {RO verifies that pump is running.}	Auto	0.0	378.9	* N/A *
					695.2	1240.4	* N/A *
- 6 -	---	RO-1-7	+1 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. {All Buses are powered from EDGs.}	Manual	0.0	0.0	* N/A *
					695.2	1240.4	* N/A *
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESWPs (34 and 35) {RO verifies that pumps are running.}	Auto	280.8	280.8	* N/A *
					976.0	1521.2	* N/A *
- 8 -	E-0-11	---	+26 +27 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {CHARGING pump 31 started on lightest loaded Bus.}	Manual	140.2	0.0	* N/A *
					1116.2	1521.2	* N/A *
- 9 -	< 19 >	---	+13 *** INADVERTENT SI *** *** EVENT IDENTIFIED - EXIT TO ES-1.1 ***	Manual	0.0	0.0	* N/A *
					1116.2	1521.2	* N/A *
			(No Loads Started or Tripped at this step)				

INADVERTENT SI

Report Date : August 25, 2009 Time : 3:56 PM (70)


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	ES-1.1-1	---	Reset SI (Step 2 through 12 of RO-1 are completed.)	Manual	0.0 1116.2	0.0 1521.2	* N/A * * N/A *
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCC as per SOP-EL-15. (MCCs are reset.)	Manual	85.8 1202.0	53.3 1584.5	* N/A * * N/A *
- 12 -	ES-1.1-3	---	+82 +81 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0 1202.0	0.0 1584.5	* N/A * * N/A *
- 13 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (Only pump 31 running-stopped.) Stop SI pumps. (Only pumps 31 and 32 running-stopped.)	Manual	-327.2 874.8	-509.2 1075.3	* N/A * * N/A *
- 14 -	ES-1.1-8	---	-117 -121 -122 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0 874.8	0.0 1075.3	* N/A * * N/A *
- 15 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs. (Spray not actuated. No pumps are running.)	Manual	0.0 874.8	0.0 1075.3	* N/A * * N/A *
- 16 -	ES-1.1-13	---	(No Loads Started or Tripped at this step) Check BAST transfer pumps are running. (MCC 36A-E never stripped.)	Manual	0.0 874.8	0.0 1075.3	* N/A * * N/A *
- 17 -	ES-1.1-17	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Pressurizer Heater 33 energized on lightest loaded Bus.)	Manual	207.9 1082.7	0.0 1075.3	* N/A * * N/A *
- 18 -	ES-1.1-19	---	+109 Reset MCCs. Start CRDM Fans. (MCC are already reset. CRDM Fans started on MCC 38.)	Manual	86.4 1163.1	0.0 1075.3	* N/A * * N/A *
			+70 +71 +72 +73				

INADVERTENT SI

Report Date : August 26, 2009 Time : 3:56 PM [70]

Step Number	SPO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	---	RO-1-27c	START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear Started.) +47	Manual	0.0 1163.1	41.9 1116.8	* N/A * * N/A *
- 20 -	ES-1.1-26	---	Stop 1 of 3 ESOWPs (ESOWPs 34 and 35 are running.) Shutdown Motor-driven AFOWPs if desired. (Bus 6A not available. AFOWP 31 remains running.)	Manual	0.0 1163.1	0.0 1116.8	* N/A * * N/A *
- 21 -	ES-1.1-26	---	(No Loads Started or Tripped at this step) Check that at least two NESOWPs are running. (NESOWPs 31 and 32 started.)	Manual	280.8 1443.9	280.8 1397.6	* N/A * * N/A *
- 22 -	ES-1.1-27	---	+84 +85 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 31 started, Blowers unavailable, powered from Bus 6A/MCC 37. CCR vent. is on.) +87	Manual	0.0 1443.9	114.3 1511.9	* N/A * * N/A *
- 23 -	ES-1.1-27	---	Go to appropriate plant operating procedure as directed by the CRS or SM (No Loads Started or Tripped at this step)	Manual	0.0 1443.9	0.0 1511.9	* N/A * * N/A *

INADVERTENT SI



Inadvertent SI
 Buses 2A/3A Tied Together, Bus 6A Not Available
 Loss of Off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

AFWP 31	EDG 31
CHARGING PUMP 31	EDG 33
ESWP 34	EDG 33
ESWP 35	EDG 31
FCU 31	EDG 33
FCU 32	EDG 31
FCU 33	EDG 33
FCU 34	EDG 31
MCC 34: TURBINE TURNING GEAR	EDG 31
MCC 36A: AUTO	EDG 33
MCC 36C: AUTO	EDG 31
MCC 36E: AUTO	EDG 33
MCC 38: CRDM FAN 31 (FAN#1)	EDG 33
MCC 38: CRDM FAN 32 (FAN#2)	EDG 33
MCC 38: CRDM FAN 33 (FAN#3)	EDG 33
MCC 38: CRDM FAN 34 (FAN#4)	EDG 33
MCCS RESET (2A/3A) AS PER SOP-EL-15	EDG 31
MCCS RESET (5A) AS PER SOP-EL-15	EDG 33
NESWP 31	EDG 33
NESWP 32	EDG 31
PAB FAN 31	EDG 31
PRESSURIZER HEATER 33	EDG 33

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IEE-CALC-ED-00297 REV 8

INADVERTENT SI

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:56 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 5A NOT AVAILABLE ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = * N/A * Bus 2A/3A = 1511.9 Bus 6A = 1638.7 (kW)

1750 kW Overload Summary

Bus 5A Not Available
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1750 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1750 kW rating

1950 kW Overload Summary

Bus 5A Not Available
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1950 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating

INADVERTENT SI

Report Date : August 25, 2009 Time : 3:56 PM (71)

Step Number	SRC Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 34B, 34C and 34D	Auto	* N/A *	94.3	100.4
					* N/A *	94.3	100.4
- 2 -	---	RO-1-2	+57 +53 +59 SI pumps 32 and 33 RHR pumps 31 and 33 (mini flow, RCS press > 125) (RO verifies that pumps are running.)	Auto	* N/A *	509.2	509.2
					* N/A *	603.5	609.6
- 3 -	E-0-9	---	+117 +120 +122 +123 CSP 32 (Spray not required. CSPs started during phase B only.) (E-0-9 verifies that pump is not running.)	Manual	* N/A *	0.0	0.0
					* N/A *	603.5	609.6
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCUs 32, 34 and 35 (RO verifies that fans are running.)	Auto	* N/A *	298.0	129.0
					* N/A *	861.5	736.6
- 5 -	---	RO-1-5	+31 +35 +37 AFWPs 31 and 33 (RO verifies that pumps are running.)	Auto	* N/A *	378.9	379.7
					* N/A *	1240.4	1114.3
- 6 -	---	RO-1-7	+1 +2 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. (All Buses are powered from EDGs.)	Manual	* N/A *	0.0	0.0
					* N/A *	1240.4	1114.3
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESWPs (35 and 36) (RO verifies that pumps are running.)	Auto	* N/A *	280.8	280.8
					* N/A *	1521.2	1395.1
- 8 -	E-0-11	---	+27 +28 Start one CHARGING pump if RCS pressure is > than 125 psig and CCW is available. (CHARGING pump 33 started on lightest loaded Bus.)	Manual	* N/A *	0.0	140.2
					* N/A *	1521.2	1535.3
- 9 -	< 13 >	---	+15 *** INADVERTENT SI *** *** EVENT IDENTIFIED - EXIT TO ES-1.1 ***	Manual	* N/A *	0.0	0.0
					* N/A *	1521.2	1535.3
			(No Loads Started or Tripped at this step)				

INADVERTENT SI

Report Date : August 25, 2009 Time : 3:56 PM [71]


Step Number	SGO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	ES-1.1-1	---	Reset SI (Step 2 through 12 of RO-1 are completed.)	Manual	* N/A *	0.0	0.0
					* N/A *	1521.2	1535.3
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCC as per SOP-EL-15. (MCCs are reset.)	Manual	* N/A *	63.3	24.8
					* N/A *	1584.5	1560.1
- 12 -	ES-1.1-3	---	+21 -23 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	* N/A *	0.0	0.0
					* N/A *	1584.5	1560.1
- 13 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (All RHR pumps stopped.) Stop SI pumps. (Only pumps 32 and 33 running stopped.)	Manual	* N/A *	-509.2	-509.2
					* N/A *	1075.3	1050.9
- 14 -	ES-1.1-8	---	-117 -120 -122 -123 Start one CHARGING pump. (CHARGING pump 33 is running.)	Manual	* N/A *	0.0	0.0
					* N/A *	1075.3	1050.9
- 15 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs. (Spray not actuated. No pumps are running.)	Manual	* N/A *	0.0	0.0
					* N/A *	1075.3	1050.9
- 16 -	ES-1.1-11	---	(No Loads Started or Tripped at this step) Check BAST transfer pumps are running. (MCC 36A-E never stripped.)	Manual	* N/A *	0.0	0.0
					* N/A *	1075.3	1050.9
- 17 -	ES-1.1-17	---	(No Loads Started or Tripped at this step) Energize at least one pressurizer Heater Group as per SOP-EL-15. (Pressurizer Heater Control Group energized on lightest loaded Bus. -114	Manual	* N/A *	0.0	277.0
					* N/A *	1075.3	1327.9
- 18 -	ES-1.1-19	---	Reset MCCs. Start CRDM Fans. (MCC are already reset. CRDM Fans unavailable, powered from Bus 5A/MCC 38.)	Manual	* N/A *	0.0	0.0
					* N/A *	1075.3	1327.9
			(No Loads Started or Tripped at this step)				

INADVERTENT SI

Report Date : August 25, 2009 Time : 3:56 PM (71)

Step Number	SEO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 5A Step/Total Load (kW)
- 19 -	---	RO-1-27c	START AC and STOP DC Oil Pumps IF 480v Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.) +47	Manual	* N/A *	41.5	0.0
- 20 -	ES-1.1-20	---	Stop 1 of 3 ESWPs. (ESWPs 35 and 36 are running.) Shutdown Motor-driven AFWPs if desired. (AFWPs remain running.)	Manual	* N/A *	1116.8	1327.9
- 21 -	ES-1.1-26	---	(No Loads Started or Tripped at this step) Check that at least two NESWPs are running. (NESWPs 32 and 33 started.)	Manual	* N/A *	280.8	280.8
- 22 -	ES-1.1-27	---	+35 +86 Start a PAB Fan, Penetration Blowers and CCR ventilation. (PAB Fan 31 started on lightest loaded Bus. Blowers started. CCR ventilation is running.)	Manual	* N/A *	1397.6	1608.7
- 23 -	ES-1.1-32	---	+87 +66 +67 Go to appropriate plant operating procedure as directed by the CRS or SM	Manual	* N/A *	114.3	30.0
			(No Loads Started or Tripped at this step)		* N/A *	1511.9	1638.7

INADVERTENT SI



Inadvertent SI
 Buses 2A/3A Tied Together, Bus 5A Not Available
 Loss of Off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

AFWP 31	EDG 31
AFWP 33	EDG 32
CHARGING PUMP 33	EDG 32
ESWP 35	EDG 31
ESWP 36	EDG 32
FCU 32	EDG 31
FCU 34	EDG 31
FCU 35	EDG 32
MCC 34: TURBINE TURNING GEAR	EDG 31
MCC 36B: AUTO	EDG 32
MCC 36C: AUTO	EDG 31
MCC 36D: AUTO	EDG 32
MCC 37: BAST HEATER (TANK #1)	EDG 32
MCC 37: BAST HEATER (TANK #2)	EDG 32
MCC 37: PENT. BLOWER (#1)	EDG 32
MCC 37: PENT. BLOWER (#2)	EDG 32
MCCS RESET (2A/3A) AS PER SOP-EL-15	EDG 31
MCCS RESET (6A) AS PER SOP-EL-15	EDG 32
NESWP 32	EDG 31
NESWP 33	EDG 32
PAB FAN 31	EDG 31
PRESSURIZER HEATER CONTROL GROUP	EDG 32

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00267 REV 8

INADVERTENT SI

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:56 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 2A AND/OR 3A NOT AVAILABLE ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = 1443.9 Bus 2A/3A = * N/A * Bus 6A = 1335.8 (kW)

1750 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1750 kW rating
Bus 2A and/or 3A Not Available
Emergency Diesel Generator 32 on Bus 6A is below the 1750 kW rating

1950 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1950 kW rating
Bus 2A and/or 3A Not Available
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating

INADVERTENT SI

Report Date : August 25, 2009 Time : 3:56 PM [72]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36A, 36B, 36D and 36E	Auto	110.0	* N/A *	100.4
					110.0	* N/A *	100.4
- 2 -	---	RO-1-2	+50 +53 +59 +60 SI pumps 31 and 33 RHR pump 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	327.2	* N/A *	509.2
					437.2	* N/A *	609.6
- 3 -	E-0-9	---	+120 +121 +123 CSPs 31 and 32 (Spray not required. CSPs started during phase B only.) (E-0-9 verifies that pumps are not running.)	Manual	0.0	* N/A *	0.0
					437.2	* N/A *	609.6
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCUs 31, 33 and 35 (RO verifies that fans are running.)	Auto	256.0	* N/A *	129.0
					695.2	* N/A *	738.6
- 5 -	---	RO-1-5	+29 +33 +37 AFWP 33 (RO verifies that pump is running.)	Auto	0.0	* N/A *	375.7
					695.2	* N/A *	1114.3
- 6 -	---	RO-1-7	+2 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. (All Buses are powered from EDGs.)	Manual	0.0	* N/A *	0.0
					695.2	* N/A *	1114.3
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESWPs (34 and 36) (RO verifies that pumps are running.)	Auto	280.8	* N/A *	280.8
					976.0	* N/A *	1395.1
- 8 -	E-0-11	---	+26 +28 Start one CHARGING pump if RCS pressure is > than 225 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	140.2	* N/A *	0.0
					1116.2	* N/A *	1395.1
- 9 -	E-10 >	---	+13 *** INADVERTENT SI *** *** EVENT IDENTIFIED - EXIT TO ES-1.1 ***	Manual	0.0	* N/A *	0.0
					1116.2	* N/A *	1395.1
			(No Loads Started or Tripped at this step)				

INADVERTENT SI

Report Date : August 25, 2009 Time : 3:56 PM [72]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 5A Step/Total Load (kW)
- 10 -	ES-1.1-1	---	Reset SI (Step 2 through 12 of RO-1 are completed.)	Manual	0.0	* N/A *	0.0
					1116.2	* N/A *	1395.1
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (MCC are reset.)	Manual	85.8	* N/A *	24.8
					1202.0	* N/A *	1419.9
- 12 -	ES-1.1-3	---	+82 +83 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	* N/A *	0.0
					1202.0	* N/A *	1419.9
- 13 -	ES-1.1-4	---	(No Loads Started or Tripped at this step) Stop BHR pumps. (Only pump 32 running - stopped.) Stop SI pumps. (Only pumps 31 and 32 running - stopped.)	Manual	-327.2	* N/A *	-509.2
					874.8	* N/A *	910.7
- 14 -	ES-1.1-2	---	-120 -121 -123 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	* N/A *	0.0
					874.8	* N/A *	910.7
- 15 -	ES-1.1-10	---	(No Loads Started or Tripped at this step) Stop CSPs. (Spray not actuated. No pumps are running.)	Manual	0.0	* N/A *	0.0
					874.8	* N/A *	910.7
- 16 -	ES-1.1-13	---	(No Loads Started or Tripped at this step) Check BAST transfer pumps are running. (MCC 36A-E never striped.)	Manual	0.0	* N/A *	0.0
					874.8	* N/A *	910.7
- 17 -	ES-1.1-17	---	(No Loads Started or Tripped at this step) Energize at least one pressurizer Heater Group as per SOP-EL-15. (Pressurizer Heater Group 33 energized on lightest loaded Bus.)	Manual	207.9	* N/A *	0.0
					1082.7	* N/A *	910.7
- 18 -	ES-1.1-19	---	+109 Reset MCCs. Start CRDM Fans. (MCC are already reset. CRDM Fans started on MCC 38.)	Manual	80.4	* N/A *	0.0
					1163.1	* N/A *	910.7
			+70 -71 +72 +73				

INADVERTENT ST

Report Date : August 25, 2009 Time : 1:56 PM [72]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	---	RO-1-27c	START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Bus 2A/3A unavailable.) (No Loads Started or Tripped at this step)	Manual	0.0	* N/A *	0.0
					1163.1	* N/A *	910.7
- 20 -	ES-1.1-20	---	Step 1 of 3 ESWPs. (ESWPs 34 and 35 running.) Shutdown Motor-driven AFWPs if desired. (Bus2A/3A not available. AFWP 33 remains running)	Manual	0.0	* N/A *	0.0
					1163.1	* N/A *	910.7
- 21 -	ES-1.1-26	---	(No Loads Started or Tripped at this step) Check that at least two NESWPs are running. (NESWPs 31 and 32 started.)	Manual	280.8	* N/A *	280.8
					1443.9	* N/A *	1191.5
- 22 -	ES-1.1-27	---	+04 +86 Start a PAB Fan, Penetration Blowers and CCR ventilation. (Bus 2A/3A unavailable, PAB Fan 32 started. Blowers started, CCR ventilation is running.)	Manual	0.0	* N/A *	144.3
					1443.9	* N/A *	1335.6
- 23 -	ES-1.1-32	---	+88 +66 +67 Go to appropriate plant operating procedure as directed by the CRS or SM.	Manual	0.0	* N/A *	0.0
					1443.9	* N/A *	1335.8
			(No Loads Started or Tripped at this step)				

INADVERTENT SI



Inadvertent SI
 Buses 2A and / or 3A Not Available
 Loss of Off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

AFWP 33	EDG 32
CHARGING PUMP 31	EDG 33
ESWP 34	EDG 33
ESWP 36	EDG 32
FCU 31	EDG 33
FCU 33	EDG 33
FCU 35	EDG 32
MCC 36A: AUTO	EDG 33
MCC 36B: AUTO	EDG 32
MCC 36D: AUTO	EDG 32
MCC 36E: AUTO	EDG 33
MCC 37: PENT. BLOWER (#1)	EDG 32
MCC 37: PENT. BLOWER (#2)	EDG 32
MCC 38: CRDM FAN 31 (FAN#1)	EDG 33
MCC 38: CRDM FAN 32 (FAN#2)	EDG 33
MCC 38: CRDM FAN 33 (FAN#3)	EDG 33
MCC 38: CRDM FAN 34 (FAN#4)	EDG 33
MCCS RESET (5A) AS PER SOP-EL-15	EDG 33
MCCS RESET (6A) AS PER SOP-EL-15	EDG 32
NESWP 31	EDG 33
NESWP 33	EDG 32
PAB FAN 32	EDG 32
PRESSURIZER HEATER 33	EDG 33

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES

ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

TP3-CALC-ED-00207 REV 8

STEAM GENERATOR TUBE RUPTURE
ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:54 PM

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2044.4 Bus 2A = 2263.8 Bus 3A = 1997.3 Bus 6A = 1937.2 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A/3A is below the 3200 Amp rating
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

STEAM GENERATOR TUBE RUPTURE - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:54 PM [47]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step load/Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36A, 36B, 36C, 36D and 36E	Auto	169.5	135.5	0.0	150.1
					169.5	135.5	0.0	150.1
- 2 -	---	RO-1-2	+57 +50 +53 +59 +60 SI pumps 31, 32 and 33 RHR pumps 31 and 32 (mini flow, RCS press > 325) {RO verifies that pumps are running.}	Auto	472.4	472.4	264.5	738.5
					641.9	607.9	264.5	888.6
- 3 -	E-0-9	---	+117 +120 +121 +122 +123 CSPs 31 and 32 {CSPs started during Phase B only.} {E-0-9 verifies that spray is not required.}	Manual	0.0	0.0	0.0	0.0
					641.9	607.9	264.5	888.6
- 4 -	---	RO-1-3	{No Loads Started or Tripped at this step} RCUs 31, 32, 33, 34 and 35 {RO verifies that fans are running.}	Auto	491.9	247.2	246.0	246.0
					1133.8	855.1	516.5	1136.6
- 5 -	---	RO-1-5	+29 +31 +33 +35 +37 AFWPs 31 and 33 {RO verifies that pumps are running.}	Auto	0.0	0.0	575.4	562.9
					1133.8	855.1	1085.9	1699.5
- 6 -	---	RO-1-7	+1 +2 CCWPs 31, 32 and 33 {RO verifies that pumps are running.}	Auto	250.5	251.3	0.0	251.2
					1384.3	1106.4	1085.9	1950.7
- 7 -	---	RO-1-8	+4 +7 +10 ESWPs (34, 35 and 36) {RO verifies that pumps are running.}	Auto	429.6	0.0	429.0	429.0
					1814.1	1106.4	1514.9	2380.5
- 8 -	E-0-11	---	+26 +27 +8 Start of CHARGE pump if RCS pressure is > the setpoint and CCW is available. {CHARGE pump 3. started on light loaded Bus}	Manual	0.0	0.0	208.9	0.0
					1814.1	1106.4	1723.8	2380.5
- 9 -	< 16 >	---	+14 *** STEAM GENERATOR TUBE RUPTURE *** *** EVENT INITIATED - TO E-3 ***	Manual	0.0	0.0	0.0	0.0
					1814.1	1106.4	1723.8	2380.5
			{No Loads Started or Tripped at this step}					

STEAM GENERATOR TUBE RUPTURE - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:54 PM [47]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	E-3-9	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0	0.0	0.0	0.0
					1814.1	1106.4	1733.8	2380.5
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset.)	Manual	659.8	848.0	507.6	252.2
					2473.9	1954.4	2231.4	2632.7
- 12 -	E-3-11	---	+126 +124 +125 +127 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	0.0	0.0	0.0
					2473.9	1954.4	2231.4	2632.7
- 13 -	E-3-12	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (RHR pumps stopped.)	Manual	0.0	0.0	-264.5	-264.8
					2473.9	1954.4	1966.9	2367.9
- 14 -	E-3-14	---	-117 -120 Start one CHARGING pump. (CHARGING pump 32 is running.)	Manual	0.0	0.0	0.0	0.0
					2473.9	1954.4	1966.9	2367.9
- 15 -	E-3-24	---	(No Loads Started or Tripped at this step) Stop SI pumps. (All SI pumps stopped.)	Manual	-472.4	-472.4	0.0	-473.7
					2001.5	1482.0	1966.9	1894.2
- 16 -	E-3-25	---	-121 -122 -123 Start one CHARGING pump. (CHARGING pump 32 is running.)	Manual	0.0	0.0	0.0	0.0
					2001.5	1482.0	1966.9	1894.2
- 17 -	---	RO-1-20	(No Loads Started or Tripped at this step) CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (NESWP 32 started on lightest loaded Bus.)	Manual	0.0	429.0	0.0	0.0
					2001.5	1911.0	1966.9	1894.2
- 18 -	E-3-26	---	+85 Start SI pumps if subcooling is < 40-deg F.	Manual	0.0	0.0	0.0	0.0
					2001.5	1911.0	1966.9	1894.2
			(No Loads Started or Tripped at this step)					


Step Number	SRO Step	RO Step	Loading Step Description	Mode	Bus 1A Step/Total Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	E-3-28	---	Start BAST pumps and Primary Water pump. (Loads accounted for in MCC resets.)	Auto		0.0	0.0	0.0
					1911.0	1966.9	1894.2	
- 20 -	E-3-32	---	(No Loads Started or Tripped at this step) Stop CSPs. (Spray not actuated. No pumps are running.)			0.0	0.0	0.0
					1911.0	1966.9	1894.2	
- 21 -	E-3-36	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group. (Energized Pressurizer Heater Group 32 on lightest loaded Bus.)			548.3	0.0	0.0
					2601.5	2451.3	1966.9	1894.2
- 22 -	---	RO-1-27c	+33 START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.)	Manual	0.0	63.8	0.0	0.0
					2601.5	2515.1	1966.9	1894.2
- 23 -	E-3-40	---	+47 Stop 1 of 3 CCWPs. Stop 1 of 3 ESWPs and Shutdown Motor-driven AFWPs if desired. (CCWP 32 and ESWP 35 stoppped on heaviest loaded Buses. AFWPs remain running.)	Manual	42.9	-251.3	-429.0	43.0
					2644.4	2263.8	1537.9	1937.2
- 24 -	< 42 >	---	+5 +11 -4 -7 -10 -27 *** GO TO POST-SGTR COOLDOWN *** *** EXIT TO ES-3.1 ***	Manual	0.0	0.0	0.0	0.0
					2644.4	2263.8	1537.9	1937.2
- 25 -	ES-3.1-1	---	(No Loads Started or Tripped at this step) Operate Pressurizer Heaters as necessary. (Pressurizer Heater Group 32 is energized on lightest loaded Bus.)	Manual	0.0	0.0	0.0	0.0
					2644.4	2263.8	1537.9	1937.2
- 26 -	ES-3.1-3	---	(No Loads Started or Tripped at this step) Start: BAST Htrs, Hot Pen Blowers, PMMU, SFP pump [Loads started with MCC resets], Electrical Tunnel Fans [Started at SI Auto of MCC 36A and B] and one PAB fan [Fan 31 is running].	Manual	0.0	0.0	0.0	0.0
					2644.4	2263.8	1537.9	1937.2
- 27 -	ES-3.1-13	---	(No Loads Started or Tripped at this step) Start one RHR pump as per SOP-RHR-1. (RHR pump 31 started on lightest loaded Bus.)	Manual	0.0	0.0	459.4	0.0
					2644.4	2263.8	1997.3	1937.2
			+115					

STEAM GENERATOR TUBE RUPTURE - ALL BUSES AVAILABLE - TOTAL MCC AND LIGHTING RESET

Report Date : August 25, 2009 Time : 3:54 PM [47]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A Step/Total Load (A)	Bus 3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 28 -	ES-3.1-16	---	Evaluate long term plant status. (No Loads Started or Tripped at this step)	Manual	0.0 2044.4	0.0 2253.8	0.0 1997.3	0.0 1937.2

STEAM GENERATOR TUBE RUPTURE



Steam Generator Tube Rupture
 Total MCC and Lighting Reset
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 31	3A
AFWP 33	6A
CCWP 31	5A
CCWP 33	6A
CHARGING PUMP 32	3A
ESWP 34	5A
ESWP 36	6A
FCU 31	5A
FCU 32	2A
FCU 33	5A
FCU 34	3A
FCU 35	6A
MCC 36A: AUTO	5A
MCC 36B: AUTO	6A
MCC 36C: AUTO	2A
MCC 36D: AUTO	6A
MCC 36E: AUTO	5A
NESWP 32	2A
PAB FAN 31	3A
PRESSURIZER HEATER 32	2A
RHR PUMP 31	3A
TOTAL MCC & LIGHTING RESET (2A)	2A
TOTAL MCC & LIGHTING RESET (3A)	3A
TOTAL MCC & LIGHTING RESET (5A)	5A
TOTAL MCC & LIGHTING RESET (6A)	6A

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

STEAM GENERATOR TUBE RUPTURE

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:53 PM

*** BUSES 2A AND 3A TIED TOGETHER ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2191.1 Bus 2A/3A = 2605.9 Bus 6A = 2367.0 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A/3A is below the 3200 Amp rating
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:53 PM [36]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36A, 36B, 36C, 36D and 36E	Auto	169.5	135.5	150.1
					169.5	135.5	150.1
- 2 -	---	RO-1-2	+57 +58 +53 +59 +60 S1 pumps 31, 32 and 33 RHR pumps 31 and 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	472.4	736.9	736.5
					641.9	872.4	888.6
- 3 -	E-0-9	---	+117 +120 +121 +122 +123 CSPs 31 and 32 (CSPs started during Phase B only.) (E-0-9 verifies that spray is not required.)	Manual	0.0	0.0	0.0
					641.9	872.4	888.6
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCUS 31, 32, 33, 34 and 35 (RO verifies that fans are running.)	Auto	491.9	493.2	248.0
					1133.8	1365.6	1136.6
- 5 -	---	RO-1-5	+29 +31 +33 +35 +37 AFWPs 31 and 33 (RO verifies that pumps are running.)	Auto	0.0	575.4	562.9
					1133.8	1941.0	1699.5
- 6 -	---	RO-1-7	+1 +2 CCNPs 31, 32 and 33 (RO verifies that pumps are running.)	Auto	250.5	251.3	251.2
					1384.3	2192.3	1950.7
- 7 -	---	RO-1-8	+4 +7 +10 ESWPs (34, 35 and 36) (RO verifies that pumps are running.)	Auto	429.8	429.0	429.8
					1814.1	2621.3	2380.5
- 8 -	E-0-11	---	+25 +27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	208.5	0.0	0.0
					2022.6	2621.3	2380.5
- 9 -	< 16 >	---	+13 *** STEAM GENERATOR TUBE RUPTURE *** *** EVENT IDENTIFIED - EXIT TO E-3 *** (No Loads Started or Tripped at this step)	Manual	0.0	0.0	0.0
					2022.6	2621.3	2380.5

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:53 PM [16]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	E-3-9	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0	0.0	0.0
					2022.6	2621.3	2380.5
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-SI-15. (Total MCC and Lighting reset.)	Manual	659.8	407.2	252.2
					2682.4	3028.5	2632.7
- 12 -	E-3-11	---	+126 +127 +3 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	0.0	0.0
					2682.4	3028.5	2632.7
- 13 -	E-3-12	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (RHR pumps stopped.)	Manual	0.0	-264.5	-264.8
					2682.4	2764.0	2367.9
- 14 -	E-3-14	---	-117 -120 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	0.0	0.0
					2682.4	2764.0	2367.9
- 15 -	E-3-24	---	(No Loads Started or Tripped at this step) Stop SI pumps. (All SI pumps stopped.)	Manual	-472.4	-472.4	-473.7
					2210.0	2291.6	1894.2
- 16 -	E-3-25	---	-121 -122 -123 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	0.0	0.0
					2210.0	2291.6	1894.2
- 17 -	---	RO-1-20	(No Loads Started or Tripped at this step) CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (NESWP 13 started on lightest loaded Bus.)	Manual	0.0	0.0	429.8
					2210.0	2291.6	2324.0
- 18 -	E-3-26	---	+86 Start SI pumps if subcooling is < 40-deg F.	Manual	0.0	0.0	0.0
					2210.0	2291.6	2324.0
			(No Loads Started or Tripped at this step)				

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:53 PM (36)


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	E-3-28	---	Start BAST pumps and Primary Water pumps. (Loads accounted for in MCC resets.)	Manual	0.0 2210.0	0.0 2291.6	0.0 2324.0
- 20 -	E-3-32	---	(No Loads Started or Tripped at this step) Stop CSPs. (Spray not actuated. No pumps are running.)	Manual	0.0 2210.0	0.0 2291.6	0.0 2324.0
- 21 -	E-3-36	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group, as per SOP-EL-15. (Energized Pressurizer Heater Group 33 on lightest loaded Bus.)	Manual	231.6 2441.6	0.0 2291.6	0.0 2324.0
- 22 -	---	RO-1-27c	+109 START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.)	Manual	0.0 2441.6	63.8 2355.4	0.0 2324.0
- 23 -	E-3-40	---	+47 Stop 1 of 3 CCWPs. Stop 1 of 3 ESWPs and Shutdown Motor-driven APWPs if desired. (CCWP 31 and ESWP 34 stopped on heaviest loaded Buses. APWPs remain running.)	Manual	-250.5 2191.1	-385.9 1969.5	43.0 2367.0
- 24 -	< 42 >	---	+8 +11 -4 -7 -10 -27 *** GO TO POST-SGTR COOLDOWN *** *** EXIT TO ES-3.1 ***	Manual	0.0 2191.1	0.0 1969.5	0.0 2367.0
- 25 -	ES-3.1-1	---	(No Loads Started or Tripped at this step) Operate Pressurizer Heaters as necessary. (Pressurizer Heater Group 33 is energized.)	Manual	0.0 2191.1	0.0 1969.5	0.0 2367.0
- 26 -	ES-3.1-3	---	(No Loads Started or Tripped at this step) Start: BAST Htrs. Hot Fan Blowers, PWMU and SFPP (Loads started at MCC reset). Electrical Tunnel Fans (Started at SI Auto of MCC 36A and B) and one PAB fan (Fan 31 started on lightest loaded Bus).	Manual	0.0 2191.1	177.0 2146.5	0.0 2367.0
- 27 -	ES-3.1-13	---	+87 Start one RHR pump as per SOP-RHR-1. (RHR pump 31 started on lightest loaded Bus.)	Manual	0.0 2191.1	459.4 2605.9	0.0 2367.0
			+115				

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:53 PM [36]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 28 -	ES-3.1-16	---	Evaluate long term plant status.	Manual	0.0	0.0	0.0
			(No Loads Started or Tripped at this step)		2191.1	2605.9	2367.0

STEAM GENERATOR TUBE RUPTURE



Steam Generator Tube Rupture
 Buses 2A/3A Tied Together, All Buses Available
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 31	3A
AFWP 33	6A
CCWP 32	2A
CCWP 33	6A
CHARGING PUMP 31	5A
ESWP 34	5A
ESWP 36	6A
FCU 31	5A
FCU 32	2A
FCU 33	5A
FCU 34	3A
FCU 35	6A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36A: AUTO	5A
MCC 36B: AUTO	6A
MCC 36C: AUTO	2A
MCC 36D: AUTO	6A
MCC 36E: AUTO	5A
NESWP 33	6A
PAB FAN 31	3A
PRESSURIZER HEATER 33	5A
RHR PUMP 31	3A
TOTAL MCC & LIGHTING RESET (5A)	
TOTAL MCC & LIGHTING RESET (6A)	
MCCS RESET (2A/3A) AS PER SOP-EL-15	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES

ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00297 REV 3

STEAM GENERATOR TUBE RUPTURE

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:54 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 6A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2914.3 Bus 2A/3A = 3034.9 Bus 6A = * N/A * (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A/3A exceeds the 3200 Amp rating at EOP steps : 27
Bus 6A Not Available

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A/3A is below the 3600 Amp rating
Bus 6A Not Available

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM [37]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36A, 36C and 36E	Auto	169.5	135.5	* N/A *
- 2 -	---	RO-1-2	+57 +50 +60 SI pumps 31 and 32 RHR pump 31 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	472.4	736.9	* N/A *
- 3 -	E-0-9	---	+117 +121 +122 CSP 31 (CSPs started during Phase B only.) (E-0-9 verifies that spray is not required.)	Manual	0.0	0.0	* N/A *
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCUE 31, 32, 33 and 34 (RO verifies that fans are running.)	Auto	491.9	493.2	* N/A *
- 5 -	---	RO-1-5	+29 +31 +33 +35 AFWP 31 (RO verifies that pump is running.)	Auto	0.0	575.4	* N/A *
- 6 -	---	RO-1-7	-1 CCWPs 31 and 32 (RO verifies that pumps are running.)	Auto	293.4	294.4	* N/A *
- 7 -	---	RO-1-8	+4 -7 ESWPs (34 and 35) (RO verifies that pumps are running.)	Auto	429.8	429.8	* N/A *
- 8 -	E-0-11	---	+26 +27 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	208.5	0.0	* N/A *
- 9 -	< 16 >	---	+13 *** STEAM GENERATOR TUBE RUPTURE *** *** EVENT IDENTIFIED - EXIT TO E-3 *** (No Loads Started or Tripped at this step)	Manual	0.0	0.0	* N/A *

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM [37]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	E-3-9	---	Reset SI (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0	0.0	* N/A *
					2065.5	2664.4	* N/A *
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset.)	Manual	659.8	407.2	* N/A *
					2725.3	3071.6	* N/A *
- 12 -	E-3-11	---	+126 +3 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	0.0	* N/A *
					2725.3	3071.6	* N/A *
- 13 -	E-3-12	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (Only pump 31 running - stopped.)	Manual	0.0	-264.5	* N/A *
					2725.3	2807.1	* N/A *
- 14 -	E-3-14	---	-117 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	0.0	* N/A *
					2725.3	2807.1	* N/A *
- 15 -	E-3-14	---	(No Loads Started or Tripped at this step) Stop SI pumps. (Only pumps 31 and 32 running - stopped.)	Manual	-472.4	-472.4	* N/A *
					2252.9	2334.7	* N/A *
- 16 -	E-3-25	---	-121 -122 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	0.0	* N/A *
					2252.9	2334.7	* N/A *
- 17 -	---	RO-1-20	(No Loads Started or Tripped at this step) CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (NESWP 31 started on lightest loaded Bus.)	Manual	429.8	0.0	* N/A *
					2682.7	2334.7	* N/A *
- 18 -	E-3-26	---	+84 Start SI pumps if subcooling is < 40-deg F.	Manual	0.0	0.0	* N/A *
					2682.7	2334.7	* N/A *
			(No Loads Started or Tripped at this step)				

STEAM GENERATOR TUBE RUPTURE

Report Date : August 29, 2009 Time : 3:54 PM [37]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	E-3-28	---	Start BAST pumps and Primary Water pumps. (BAST pumps accounted for in MCC resets. MCC37/Bus 6A unavailable, Primary Water pumps not started.) (No Loads Started or Tripped at this step)	Manual	0.0 2682.7	0.0 2334.7	* N/A * * N/A *
- 20 -	E-3-32	---	Stop CSPs. (Spray not actuated. No pumps are running.)	Manual	0.0 2682.7	0.0 2334.7	* N/A * * N/A *
- 21 -	E-3-36	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Energized Pressurizer Heater Group 32 on lightest loaded Bus.)	Manual	0.0 2682.7	231.6 2566.3	* N/A * * N/A *
- 22 -	---	RO-1-27c	+101 START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.)	Manual	0.0 2682.7	62.8 2630.1	* N/A * * N/A *
- 23 -	E-3-40	---	+47 Stop 1 of 3 CCWPs. (CCWPs 31 and 32 running.) Stop 1 of 3 ESWPs. (ESWPs 34 and 35 running.) Shutdown Motor-driven APWPs if desired. (Bus 6A not available. APWP 31 remains running) (No Loads Started or Tripped at this step)	Manual	0.0 2682.7	0.0 2630.1	* N/A * * N/A *
- 24 -	< 42 >	---	*** GO TO POST-SCTR COOLDOWN *** *** EXIT TO ES-3.1 ***	Manual	0.0 2682.7	0.0 2630.1	* N/A * * N/A *
- 25 -	ES-3.1-1	---	(No Loads Started or Tripped at this step) Operate Pressurizer Heaters as necessary. (Pressurizer Heater Group 33 is energized.)	Manual	0.0 2682.7	0.0 2630.1	* N/A * * N/A *
- 26 -	ES-3.1-3	---	(No Loads Started or Tripped at this step) Start: Bast Htrs, Hot Pen Blowers, PWNU, SFP pump [Bus 6A not available.], Electrical Tunnel Fans (Started at SI Auto of MCC 36A.) add one PAB fan (PAB fan 31 started.)	Manual	0.0 2682.7	177.0 2807.1	* N/A * * N/A *
- 27 -	ES-3.1-13	---	+87 Start one RHR pump as per SOP-RHR-1. (RHR pump 31 started.)	Manual	0.0 2682.7	459.4 3266.5	* N/A * * N/A *
			-116			Over 3200	

STEAM GENERATOR TUBE RUPTURE

Report Date : August 29, 2009 Time : 3:54 PM (37)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 38 -	ES-3.1-16	---	Evaluate long term plant status. (If Degraded Grid voltage is still resulting in 444V at Buses. Transfer from PRZER 32 to 33 or shut down APWP 31 as per FOLDOUT PAGE.) +109 -101	Manual	231.6	-231.6	* N/A *
					2914.3	3034.9	* N/A *

STEAM GENERATOR TUBE RUPTURE



Steam Generator Tube Rupture
 Buses 2A/3A Tied Together, Bus 6A Not Available
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 31	3A
AFWP 33	6A
CCWP 32	2A
CCWP 33	6A
CHARGING PUMP 31	5A
ESWP 34	5A
ESWP 36	6A
FCU 31	5A
FCU 32	2A
FCU 33	5A
FCU 34	3A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36A: AUTO	5A
MCC 36C: AUTO	2A
MCC 36E: AUTO	5A
NESWP 33	6A
PAB FAN 31	3A
PRESSURIZER HEATER 33	5A
RHR PUMP 31	3A
TOTAL MCC & LIGHTING RESET (5A)	
MCCS RESET (2A/3A) AS PER SOP-EL-15	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00267 REV 8

STEAM GENERATOR TUBE RUPTURE

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:54 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 5A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = * N/A * Bus 2A/3A = 3049.8 Bus 6A = 2753.6 (A)

3200 Amp Overload Summary

Bus 5A Not Available
Bus 2A/3A is below the 3200 Amp rating
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A Not Available
Bus 2A/3A is below the 3600 Amp rating
Bus 6A is below the 3600 Amp rating

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM (38)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36B, 36C and 36D	Auto	* N/A *	135.5	150.1
					* N/A *	135.5	150.1
- 2 -	---	RO-1-2	+87 +93 +99 SI pumps 32 and 33 RHR pumps 31 and 32 (mini flow, RCS press > 325) {RO verifies that pumps are running.}	Auto	* N/A *	736.9	738.5
					* N/A *	872.4	888.6
- 3 -	E-0-9	---	+117 +120 +122 +123 CSP 32 {CSPs started during Phase B only.} {E-0-9 verifies that spray is not required.}	Manual	* N/A *	0.0	0.0
					* N/A *	872.4	888.6
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCOs 32, 34 and 35 {RO verifies that fans are running.}	Auto	* N/A *	493.2	248.0
					* N/A *	1365.6	1136.6
- 5 -	---	RO-1-5	+31 +35 +37 APWPs 31 and 33 {RO verifies that pumps are running.}	Auto	* N/A *	575.4	562.9
					* N/A *	1941.0	1699.5
- 6 -	---	RO-1-7	+1 +2 CCWPs 32 and 33 {RO verifies that pumps are running.}	Auto	* N/A *	294.4	294.2
					* N/A *	2235.4	1993.7
- 7 -	---	RO-1-8	+7 +10 ESWPs (35 and 36) {RO verifies that pumps are running.}	Auto	* N/A *	429.0	429.8
					* N/A *	2664.4	2422.5
- 8 -	E-0-11	---	+27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {CHARGING pump 33 started on lightest loaded Bus.}	Manual	* N/A *	0.0	209.6
					* N/A *	2664.4	2633.1
- 9 -	< 16 >	---	-15 *** STEAM GENERATOR TUBE RUPTURE *** *** EVENT IDENTIFIED - EXIT TO E-3 ***	Manual	* N/A *	0.0	0.0
					* N/A *	2664.4	2633.1
			(No Loads Started or Tripped at this step)				

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM [38]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	E-3-9	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	* N/A *	0.0	0.0
					* N/A *	2654.4	2633.1
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15 (Total MCC and Lighting reset.)	Manual	* N/A *	407.2	252.2
					* N/A *	3071.6	2885.3
- 12 -	E-3-11	---	+127 +3 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	* N/A *	0.0	0.0
					* N/A *	3071.6	2885.3
- 13 -	E-3-12	---	(No Loads Started or Tripped at this step) Stop RHR pumps (RHR pumps stopped.)	Manual	* N/A *	-264.5	-264.8
					* N/A *	2807.1	2420.5
- 14 -	E-3-14	---	-117 -120 START one CHARGING pump. (CHARGING pump 33 is running.)	Manual	* N/A *	0.0	0.0
					* N/A *	2807.1	2620.5
- 15 -	E-3-24	---	(No Loads Started or Tripped at this step) Stop SI pumps. (Only pumps 32 and 33 running - stopped.)	Manual	* N/A *	-472.4	-473.7
					* N/A *	2334.7	2146.6
- 16 -	E-3-25	---	-122 -123 Start one CHARGING pump. (CHARGING pump 33 is running.)	Manual	* N/A *	0.0	0.0
					* N/A *	2334.7	2146.6
- 17 -	---	RO-1-20	(No Loads Started or Tripped at this step) CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (NESWP 33 started on lightest loaded Bus.)	Manual	* N/A *	0.0	429.8
					* N/A *	2334.7	2576.6
- 18 -	E-3-26	---	+86 Start SI pumps if subcooling is < 40-deg F.	Manual	* N/A *	0.0	0.0
					* N/A *	2334.7	2576.6
			(No Loads Started or Tripped at this step)				

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM [38]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 5A Step/Total Load (A)
- 19 -	E-3-28	---	Start EAST pumps and Primary Water pumps. (Loads accounted for in MCC resets.)	Manual	* N/A *	0.0	0.0
					* N/A *	2334.7	2576.6
- 20 -	E-3-32	---	(No Loads Started or Tripped at this step) Stop CSPs (Spray not actuated. No pumps are running.)	Manual	* N/A *	0.0	0.0
					* N/A *	2334.7	2576.6
- 21 -	E-3-34	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Energized Pressurizer Heater Group 32 energized on lightest loaded Bus.)	Manual	* N/A *	231.6	0.0
					* N/A *	2566.3	2576.6
- 22 -	---	RO-1-27c	+101 START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.)	Manual	* N/A *	63.8	0.0
					* N/A *	2630.1	2576.6
- 23 -	E-3-40	---	+47 Stop 1 of 3 CCWPs. (CCWPs 32 and 33 running.) Stop 1 of 3 ESWPs. (ESWPs 35 and 36 running.) Shutdown Motor-driven AFWPs if desired. (AFWPs remain running.)	Manual	* N/A *	0.0	0.0
					* N/A *	2630.1	2576.6
- 24 -	< 42 >	---	(No Loads Started or Tripped at this step) *** GO TO POST-SGTR COOLDOWN *** *** EXIT TO ES-3-1 ***	Manual	* N/A *	0.0	0.0
					* N/A *	2630.1	2576.6
- 25 -	ES-3.1-1	---	(No Loads Started or Tripped at this step) Operate Pressurizer Heaters as necessary. (Pressurizer Heater Group 32 is energized.)	Manual	* N/A *	0.0	0.0
					* N/A *	2630.1	2576.6
- 26 -	ES-3.1-3	---	(No Loads Started or Tripped at this step) Start: BAST Htrs, Hot Pen Blowers, FWMU and SFPP [Loads accounted for at MCC reset.], Elec Tunnel Fans [Started at SI Auto of MCC 36B] and one PAB fan [Fan 32 started on lightest loaded Bus].	Manual	* N/A *	0.0	177.0
					* N/A *	2630.1	2753.6
- 27 -	ES-3.1-13	---	+88 Start one RHR pump as per SOP-RHR-1 (RHR pump 31 started on lightest loaded Bus.)	Manual	* N/A *	419.7	0.0
					* N/A *	3049.8	2753.6
			+116				

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 1:54 PM [38]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 28 -	ES-1.1-16	---	Evaluate long term plant status.	Manual	* N/A *	0.0	0.0
			(No Loads Started or Tripped at this step)		* N/A *	3049.8	2753.6

STEAM GENERATOR TUBE RUPTURE



Steam Generator Tube Rupture
 Buses 2A/3A Tied Together, Bus 5A Not Available
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 31	3A
AFWP 33	6A
CCWP 32	2A
CCWP 33	6A
CHARGING PUMP 33	6A
ESWP 35	3A
ESWP 36	6A
FCU 32	2A
FCU 34	3A
FCU 35	6A
MCC 34: TURBINE TURNING GEAR	2A
MCC 36B: AUTO	6A
MCC 36C: AUTO	2A
MCC 36D: AUTO	6A
NESWP 33	6A
PAB FAN 32	6A
PRESSURIZER HEATER GROUP 32	2A
RHR PUMP 31	3A
TOTAL MCC & LIGHTING RESET (5A)	
MCCS RESET (2A/3A) AS PER SOP-EL-15	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

STEAM GENERATOR TUBE RUPTURE

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:54 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 2A AND/OR 3A NOT AVAILABLE ***

*** OFF-SITE POWER AVAILABLE ***

End of Emergency Operating Procedure Loading

Bus 5A = 2484.5 Bus 2A/3A = * N/A * Bus 6A = 3003.9 (A)

3200 Amp Overload Summary

Bus 5A is below the 3200 Amp rating
Bus 2A and/or 3A Not Available
Bus 6A is below the 3200 Amp rating

3600 Amp Overload Summary

Bus 5A is below the 3600 Amp rating
Bus 2A and/or 3A Not Available
Bus 6A is below the 3600 Amp rating

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM [39]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (A)	Bus 2A/2A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 1 -	---	---	MCC 36A, 36B, 36D and 36E	Auto	169.5	* N/A *	150.1
					169.5	* N/A *	150.1
- 2 -	---	RO-1-2	+50 +53 +59 +60 SI pumps 31 and 33 RHR pump 32 (mini flow, RCS press > 325) {RO verifies that pumps are running.}	Auto	472.4	* N/A *	738.5
					641.9	* N/A *	888.6
- 3 -	E-0-9	---	+120 +121 +123 CSPs 31 and 32 {CSPs started during Phase B only.} {E-0-9 verifies that spray is not required.}	Manual	0.0	* N/A *	0.0
					641.9	* N/A *	888.6
- 4 -	---	RO-1-3	{No Loads Started or Tripped at this step} FCUs 31, 33 and 35 {RO verifies that fans are running.}	Auto	491.9	* N/A *	248.0
					1133.8	* N/A *	1136.6
- 5 -	---	RO-1-5	+29 +33 +37 AFWP 33 {RO verifies that pump is running.}	Auto	0.0	* N/A *	562.0
					1133.8	* N/A *	1699.5
- 6 -	---	RO-1-7	+2 CCWPs 31 and 33 {RO verifies that pumps are running.}	Auto	293.4	* N/A *	294.2
					1427.2	* N/A *	1993.7
- 7 -	---	RO-1-8	+4 +10 ESWPs (34 and 36) {RO verifies that pumps are running.}	Auto	429.8	* N/A *	429.8
					1857.0	* N/A *	2423.5
- 8 -	E-0-11	---	+26 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {CHARGING pump 31 started on lightest loaded Bus.}	Manual	208.5	* N/A *	0.0
					2065.5	* N/A *	2423.5
- 9 -	< 16 >	---	+13 *** STEAM GENERATOR TUBE RUPTURE *** *** EVENT IDENTIFIED - EXIT TO E-3 *** {No Loads Started or Tripped at this step}	Manual	0.0	* N/A *	0.0
					2065.5	* N/A *	2423.5

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM (39)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 3A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 10 -	E-3-9	---	Reset SI. (Steps 3 through 12 of RO-1 are completed.)	Manual	0.0	* N/A *	0.0
					2065.5	* N/A *	2423.5
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (Total MCC and Lighting reset.)	Manual	659.8	* N/A *	252.2
					2725.3	* N/A *	2675.7
- 12 -	E-3-11	---	+126 +127 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	* N/A *	0.0
					2725.3	* N/A *	2675.7
- 13 -	E-3-12	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (Only RHR pump 32 running - stopped.)	Manual	0.0	* N/A *	-264.8
					2725.3	* N/A *	2410.9
- 14 -	E-3-14	---	-120 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	* N/A *	0.0
					2725.3	* N/A *	2410.9
- 15 -	E-3-24	---	(No Loads Started or Tripped at this step) Stop SI pumps. (Only pumps 31 and 33 running - stopped.)	Manual	-472.4	* N/A *	-473.7
					2352.9	* N/A *	1937.2
- 16 -	E-3-25	---	-121 -133 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	* N/A *	0.0
					2252.9	* N/A *	1937.2
- 17 -	---	RO-1-20	(No Loads Started or Tripped at this step) CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (NESWP 33 started on lightest loaded Bus.)	Manual	0.0	* N/A *	429.8
					2252.9	* N/A *	2367.0
- 18 -	E-3-26	---	+86 Start SI pumps if subcooling is < 46-deg F. (No Loads Started or Tripped at this step)	Manual	0.0	* N/A *	0.0
					2252.9	* N/A *	2367.0

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM [39]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (A)	Bus 2A/3A Step/Total Load (A)	Bus 6A Step/Total Load (A)
- 19 -	E-3-28	---	Start BAST pumps and Primary Water pumps. (Loads accounted for in MCC resets.)	Manual	0.0	* N/A *	0.0
					2252.9	* N/A *	2367.0
- 20 -	E-3-32	---	(No Loads Started or Tripped at this step) Stop CSPs. (Spray not actuated. No pumps are running.)	Manual	0.0	* N/A *	0.0
					2252.9	* N/A *	2367.0
- 21 -	E-3-36	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Energized Pressurizer Heater Group 33 on lightest loaded Bus.)	Manual	231.6	* N/A *	0.0
					2484.5	* N/A *	2367.0
- 22 -	---	RO-1-27c	+109 START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Bus 2A/3A unavailable.)	Manual	0.0	* N/A *	0.0
					2484.5	* N/A *	2367.0
- 23 -	E-3-40	---	(No Loads Started or Tripped at this step) Stop 1 of 3 CCWPs. (CCWPs 31 and 33 running.) Stop 1 of 3 ESWPs. (ESWPs 34 and 36 running.) Shutdown Motor-driven APWPs if desired. (Bus 2A/3A not available. APWP 33 remains running) (No Loads Started or Tripped at this step)	Manual	0.0	* N/A *	0.0
					2484.5	* N/A *	2367.0
- 24 -	< 42 >	---	*** GO TO POST-SGTR COOLDOWN *** *** EXIT TO ES-3.1 ***	Manual	0.0	* N/A *	0.0
					2484.5	* N/A *	2367.0
- 25 -	ES-3.1-1	---	(No Loads Started or Tripped at this step) Operate Pressurizer Heaters as necessary. (Pressurizer Heater Group 33 is energized.)	Manual	0.0	* N/A *	0.0
					2484.5	* N/A *	2367.0
- 26 -	ES-3.1-3	---	(No Loads Started or Tripped at this step) Start: BAST Htrs, Hot Pen Blowers, PMMU and SFPP [Loads accounted for at MCC reset]. Electrical Tunnel Fans [Started at SI Auto of MCC 36A and B] and one P4B fan [Fan 32 started].	Manual	0.0	* N/A *	177.0
					2484.5	* N/A *	2544.0
- 27 -	ES-3.1-13	---	+88 Start one RHR pump as per SOP-RHR-1. (RHR pump 32 started.)	Manual	0.0	* N/A *	459.9
					2484.5	* N/A *	3003.9

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM [39]

Step Number	SRD Step	RO Step	Loading Step Description	Initiation	Bus 5A	Bus 2A/3A	Bus 6A
					Step Load/ Load (A)	Step/Total Load (A)	Step/Total Load (A)
- 28 -	ES-3.1-16	---	Evaluate long term plant status.	Manual	0.0	* N/A *	0.0
			(No Loads Started or Tripped at this step)		2484.5	* N/A *	3003.9

STEAM GENERATOR TUBE RUPTURE



Steam Generator Tube Rupture
 Buses 2A and / or 3A Not Available
 Off-site Power Available
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM BUS**

AFWP 33	6A
CCWP 31	5A
CCWP 33	6A
CHARGING PUMP 31	5A
ESWP 34	5A
ESWP 36	6A
FCU 32	2A
FCU 33	5A
FCU 35	6A
MCC 36A: AUTO	5A
MCC 36B: AUTO	6A
MCC 36D: AUTO	6A
MCC 36E: AUTO	5A
NESWP 33	6A
PAB FAN 32	6A
PRESSURIZER HEATER 33	5A
RHR PUMP 32	6A
TOTAL MCC & LIGHTING RESET (5A)	
TOTAL MCC & LIGHTING RESET (6A)	

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

STEAM GENERATOR TUBE RUPTURE

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:54 PM

*** BUSES 2A AND 3A TIED TOGETHER ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = 1561.6 Bus 2A/3A = 1266.4 Bus 6A = 1540.4 (kW)

1750 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1750 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1750 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1750 kW rating

1950 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1950 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1950 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM [40]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36A, 36B, 36C, 36D and 36E	Auto	110.0 110.0	94.3 94.3	100.4 100.4
- 2 -	---	RO-1-2	+57 +50 +53 +59 +60 SI pumps 31, 32 and 33 RHR pumps 31 and 32 (mini flow, RCS press > 325) {RO verifies that pumps are running.}	Auto	327.2 437.2	509.2 603.5	509.2 609.6
- 3 -	E-4-9	---	+117 +120 +121 +122 +123 CSPs 31 and 32 {CSPs started during Phase B only.} {E-4-9 verifies that spray is not required.}	Manual	0.0 437.2	0.0 603.5	0.0 609.6
- 4 -	---	RO-1-3	{No Loads Started or Tripped at this step} FCUs 31, 32, 33, 34 and 35 {RO verifies that fans are running.}	Auto	258.0 695.2	258.0 861.5	129.0 739.6
- 5 -	---	RO-1-5	+29 +31 +33 +35 +37 AFWPs 31 and 33 {RO verifies that pumps are running.}	Auto	0.0 695.2	378.9 1240.4	375.7 1114.3
- 6 -	---	RO-1-7	+1 +2 CHECK if Offsite power is available to a 480V Bus to start at least one CCNP {All Buses are powered from EDGs.}	Manual	0.0 695.2	0.0 1240.4	0.0 1114.3
- 7 -	---	RO-1-8	{No Loads Started or Tripped at this step} ESWPs (34, 35 and 36) {RO verifies that pumps are running.}	Auto	280.8 976.0	280.8 1521.2	280.8 1395.1
- 8 -	E-4-11	---	+36 +27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. {CHARGING pump 31 started on lightest loaded Bus.}	Manual	140.2 1116.2	0.0 1521.2	0.0 1395.1
- 9 -	< 16 >	---	+13 *** STEAM GENERATOR TUBE RUPTURE *** *** EVENT IDENTIFIED - EXIT TO E-3 *** {No Loads Started or Tripped at this step}	Manual	0.0 1116.2	0.0 1521.2	0.0 1395.1

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM [40]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	E-3-9	---	Reset SI (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0	0.0	0.0
					1116.2	1521.2	1395.1
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (MCCs are reset.)	Manual	85.6	63.3	24.8
					1202.0	1584.5	1419.9
- 12 -	E-3-11	---	+02 +01 +03 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	0.0	0.0
					1202.0	1584.5	1419.9
- 13 -	E-3-12	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (RHR pumps stopped.)	Manual	0.0	-182.0	-182.0
					1202.0	1402.5	1237.9
- 14 -	E-3-14	---	-117 -120 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	0.0	0.0
					1202.0	1402.5	1237.9
- 15 -	E-3-24	---	(No Loads Started or Tripped at this step) Stop SI pumps. (All SI pumps stopped.)	Manual	-327.2	-327.2	-327.2
					874.8	1075.3	910.7
- 16 -	E-3-25	---	-121 -122 -123 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	0.0	0.0
					874.8	1075.3	910.7
- 17 -	---	RO-1-20	(No Loads Started or Tripped at this step) CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (All Buses are powered from EDGs.)	Manual	0.0	0.0	0.0
					874.8	1075.3	910.7
- 18 -	E-3-26	---	(No Loads Started or Tripped at this step) Start SI pumps if subcooling is < 40-deg F.	Manual	0.0	0.0	0.0
					874.8	1075.3	910.7
			(No Loads Started or Tripped at this step)				

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM 1401


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	E-3-23	---	Start BAST pumps and Primary Water pumps. (BAST pumps are running. MCC 36A-E never stripped. Primary Water pumps started.)	Manual	0.0 874.8	0.0 1075.3	20.7 931.4
- 20 -	E-3-12	---	+68 Stop CSPs. (Spray not actuated. No pumps are running.)	Manual	0.0 874.8	0.0 1075.3	0.0 931.4
- 21 -	E-3-36	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Pressurizer Heater Group 33 energized on lightest loaded Bus.)	Manual	207.9 1082.7	0.0 1075.3	0.0 931.4
- 22 -	---	RO-1-27c	+109 START AC and STOP DC Oil Pumps IF 480V Buses are power from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.)	Manual	0.0 1082.7	41.5 1116.8	0.0 931.4
- 23 -	E-3-40	---	+47 Stop 1 of 3 CCWPs. Stop 1 of 3 ESWPs and Shutdown Motor-driven AFWPs if desired. (No CCWPs are running. ESWP 35 stopped on heaviest loaded Bus. AFWPs remain running.)	Manual	0.0 1082.7	-280.8 836.0	0.0 931.4
- 24 -	< 42 >	---	-27 *** GO TO POST SGTR COOLDOWN *** *** EXIT TO ES-3.1 ***	Manual	0.0 1082.7	0.0 836.0	0.0 931.4
- 25 -	ES-3.1-1	---	(No Loads Started or Tripped at this step) Operate Pressurizer Heaters as necessary. (Pressurizer Group 33 is energized.)	Manual	0.0 1082.7	0.0 836.0	0.0 931.4
- 26 -	ES-3.1-3	---	(No Loads Started or Tripped at this step) Start: BAST Htrs, Hot Pen Blowers, PVMU, SFP pump [Loads started on MCC 37], Elect Tunnel Fans [Started at SI Auto of MCC 36A and B] and one PAB fan [Fan 31 started on lightest loaded Bus].	Manual	0.0 1082.7	114.3 950.3	130.1 1061.5
- 27 -	ES-3.1-13	---	+87 +61 +66 +67 +62 +68 Start one RHR pump as per SOP-RHR-1. (CCWPs 31, 33, NESWPs 31, 33 and RHR pump 31 started.)	Manual	478.9 1561.6	316.1 1266.4	478.9 1540.4
			+84 +86 +5 +11 +115				

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM [40]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A	Bus 2A/3A	Bus 6A
					Step Load/Load (kW)	Step/Total Load (kW)	Step/Total Load (kW)
- 28 -	EB-3.1-16	---	Evaluate long term plant status.	Manual	0.0	0.0	0.0
			(No Loads Started or Tripped at this step)		1561.6	1266.4	1540.4

STEAM GENERATOR TUBE RUPTURE



Steam Generator Tube Rupture
 Buses 2A/3A Tied Together, All Buses Available
 Loss of Off-set Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

AFWP 31	EDG 31
AFWP 33	EDG 32
CCWP 31	EDG 33
CCWP 33	EDG 32
CHARGING PUMP 31	EDG 33
ESWP 34	EDG 33
ESWP 36	EDG 32
FCU 31	EDG 33
FCU 32	EDG 31
FCU 33	EDG 33
FCU 34	EDG 31
FCU 35	EDG 32
MCC 34: TURBINE TURNING GEAR	EDG 31
MCC 36A: AUTO	EDG 33
MCC 36B: AUTO	EDG 32
MCC 36C: AUTO	EDG 31
MCC 36D: AUTO	EDG 32
MCC 36E: AUTO	EDG 33
MCC 37: BAST HEATER (TANK #1)	EDG 32
MCC 37: BAST HEATER (TANK #2)	EDG 32
MCC 37: PENT. BLOWER (#1)	EDG 32
MCC 37: PENT. BLOWER (#2)	EDG 32
MCC 37: PW MU PUMP	EDG 32
MCC 37: SPENT FUEL COOLING PUMP 31	EDG 32
MCCS RESET (2A/3A) AS PER SOP-EL-15	EDG 31
MCCS RESET (5A) AS PER SOP-EL-15	EDG 33
MCCS RESET (6A) AS PER SOP-EL-15	EDG 32
NESWP 31	EDG 33
NESWP 33	EDG 32
PAB FAN 31	EDG 31
PRESSURIZER HEATER 33	EDG 33
RHR PUMP 31	EDG 31

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES

ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

STEAM GENERATOR TUBE RUPTURE

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:54 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 6A NOT AVAILABLE ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = 1583.1 Bus 2A/3A = 1547.2 Bus 6A = * N/A * (kW)

1750 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1750 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1750 kW rating
Bus 6A Not Available

1950 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1950 kW rating
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1950 kW rating
Bus 6A Not Available

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM [41]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36A, 36C and 36E	Auto	110.0 110.0	94.3 94.3	* N/A *
- 2 -	---	RO-1-2	+57 +50 +60 SI pumps 31 and 32 RHR pump 31 (mini flow, RCS press > 335) (RO verifies that pumps are running.)	Auto	327.2 437.2	509.2 603.5	* N/A *
- 3 -	E-0-9	---	+117 +121 +122 CSP 31 (CSPs started during Phase B only.) (E-0-9 verifies that spray is not required.)	Manual	0.0 437.2	0.0 603.5	* N/A *
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCUs 31, 32, 33 and 34 (RO verifies that fans are running.)	Auto	258.0 695.2	258.0 861.5	* N/A *
- 5 -	---	RO-1-5	+29 +31 +33 +35 AFWP 31 (RO verifies that pump is running.)	Auto	0.0 695.2	378.9 1240.4	* N/A *
- 6 -	---	RO-1-7	+1 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. (All Buses are powered from EDGs.)	Auto	0.0 695.2	0.0 1240.4	* N/A *
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESWPs (34 and 35) (RO verifies that pumps are running.)	Auto	280.8 976.0	280.8 1521.2	* N/A *
- 8 -	E-0-11	---	+26 +27 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	140.2 1116.2	0.0 1521.2	* N/A *
- 9 -	< 16 >	---	+13 *** STEAM GENERATOR TUBE RUPTURE *** *** EVENT IDENTIFIED - EXIT TO E-3 *** (No Loads Started or Tripped at this step)	Manual	0.0 1116.2	0.0 1521.2	* N/A *

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM (41)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	E-3-9	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	0.0 1116.2	0.0 1521.2	* N/A *
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (MCCs are reset.)	Manual	85.8 1202.0	53.3 1584.5	* N/A *
- 12 -	E-3-11	---	+82 +81 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0 1202.0	0.0 1584.5	* N/A *
- 13 -	E-3-17	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (Only pump 31 running - stopped.)	Manual	0.0 1202.0	-152.0 1402.5	* N/A *
- 14 -	E-3-14	---	-117 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0 1202.0	0.0 1402.5	* N/A *
- 15 -	E-3-24	---	(No Loads Started or Tripped at this step) Stop SI pumps. (Only pumps 31 and 32 running - stopped.)	Manual	-327.2 874.8	-327.2 1075.3	* N/A *
- 16 -	E-3-28	---	-121 -122 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0 874.8	0.0 1075.3	* N/A *
- 17 -	---	RO-1-20	(No Loads Started or Tripped at this step) CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (All Buses are powered from EDGs.)	Manual	0.0 874.8	0.0 1075.3	* N/A *
- 18 -	E-3-26	---	(No Loads Started or Tripped at this step) Start SI pumps if subcooling is < 40-deg F. (No Loads Started or Tripped at this step)	Manual	0.0 874.8	0.0 1075.3	* N/A *

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM (41)


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	E-3-28	---	Start BAST pumps and Primary Water pumps. (BAST pumps are running. MCC 36A-E never stripped. MCC37/Bus 6A unavailable . Primary Water pumps not started.) (No Loads Started or Tripped at this step)	Manual	0.0 874.8	0.0 1075.3	* N/A * * N/A *
- 20 -	E-3-32	---	Stop CSPs. (Spray not actuated. No pumps are running.)	Manual	0.0 874.8	0.0 1075.3	* N/A * * N/A *
- 21 -	E-3-35	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Pressurizer Heater Group 33 energized on lightest loaded Bus.)	Manual	207.9 1082.7	5.0 1075.3	* N/A * * N/A *
- 22 -	---	RO-1-27c	+109 START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.)	Manual	0.0 1082.7	41.5 1116.8	* N/A * * N/A *
- 23 -	E-3-40	---	+47 Stop 1 of 3 CCWPs. (No CCWPs are running.) Stop 1 of 3 ESWPs. (ESWPs 34 and 35 are running.) Shutdown Motor-driven AFWPs if desired. (Bus 6A not available. AFWP 31 remains running.) (No Loads Started or Tripped at this step)	Manual	0.0 1082.7	0.0 1116.8	* N/A * * N/A *
- 24 -	< 42 >	---	*** GO TO POST SGTR COOLDOWN *** *** EXIT TO ES-3.1 ***	Manual	0.0 1082.7	0.0 1116.8	* N/A * * N/A *
- 25 -	ES-3.1-1	---	(No Loads Started or Tripped at this step) Operate Pressurizer Heaters as necessary. (Pressurizer Heater Group 33 is energized.)	Manual	0.0 1082.7	0.0 1116.8	* N/A * * N/A *
- 26 -	ES-3.1-3	---	(No Loads Started or Tripped at this step) Start: BAST Htrs, Hot Pen Blowers, DWMU, SFP pump (Bus 6A not available.), Electrical Tunnel Fans [Started at SI Auto of MCC 36A.] and one PAB fan (PAB fan 31 started.).	Manual	0.0 1082.7	114.3 1231.1	* N/A * * N/A *
- 27 -	ES-3.1-11	---	+87 Start one RHR pump as per SOP-RHR-1. (CCWP 31 and NESWP 31 started on lightest loaded Bus. RHR pump 31 started on only available Bus.)	Manual	500.4 1583.1	316.1 1547.2	* N/A * * N/A *
			+116 +84 +6				

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM [41]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A	Bus 2A/3A	Bus 6A
					Step Load/Load (kW)	Step/Total Load (kW)	Step/Total Load (kW)
- 28 -	ES-3.1-16	---	Evaluate long term plant status.	Manual	0.0	0.0	* N/A *
					1583.1	1547.2	* N/A *
			(No Loads Started or Tripped at this step)				

STEAM GENERATOR TUBE RUPTURE



Steam Generator Tube Rupture
Buses 2A/3A Tied Together, Bus 6A Not Available
Loss of Off-site Power
Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

1 AFWP 31	EDG 31
2 CCWP 31	EDG 33
3 CHARGING PUMP 31	EDG 33
4 ESWP 34	EDG 33
5 ESWP 35	EDG 31
6 FCU 31	EDG 33
7 FCU 32	EDG 31
8 FCU 33	EDG 33
9 FCU 34	EDG 31
15 MCC 34: TURBINE TURNING GEAR	EDG 31
16 MCC 36A: AUTO	EDG 33
17 MCC 36C: AUTO	EDG 31
18 MCC 36E: AUTO	EDG 33
19 MCCS RESET (2A/3A) AS PER SOP-EL-15	EDG 31
20 MCCS RESET (5A) AS PER SOP-EL-15	EDG 33
21 NESWP 31	EDG 33
22 PAB FAN 31	EDG 31
23 PRESSURIZER HEATER 33	EDG 33
24 RHR PUMP 31	EDG 31

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES

ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

STEAM GENERATOR TUBE RUPTURE

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:54 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 5A NOT AVAILABLE ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = * N/A * Bus 2A/3A = 1446.2 Bus 6A = 1632.1 (KW)

1750 kW Overload Summary

Bus 5A Not Available
Emergency Diesel Generator 31 on Bus 2A/3A exceeds the 1750 kW rating at EOP steps : 27
Emergency Diesel Generator 32 on Bus 6A is below the 1750 kW rating

1950 kW Overload Summary

Bus 5A Not Available
Emergency Diesel Generator 31 on Bus 2A/3A is below the 1950 kW rating
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM (42)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36B, 36C and 36D	Auto	* N/A *	94.3	100.4
					* N/A *	94.3	100.4
- 2 -	---	RO-1-2	+57 +52 +59 SI pumps 32 and 33 RRR pumps 31 and 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	* N/A *	509.2	509.2
					* N/A *	603.5	609.6
- 3 -	E-0-9	---	+117 +120 +123 +123 CSP 32 (CSPs started during Phase 9 only.) (E-0-9 verifies that spray is not required.)	Manual	* N/A *	0.0	0.0
					* N/A *	603.5	609.6
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCUs 32, 34 and 35 (RO verifies that fans are running.)	Auto	* N/A *	298.0	129.0
					* N/A *	861.5	738.6
- 5 -	---	RO-1-5	+31 +35 +37 AFWPs 31 and 33 (RO verifies that pumps are running.)	Auto	* N/A *	378.9	375.7
					* N/A *	1240.4	1114.3
- 6 -	---	RO-1-7	+1 +2 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. (All Buses are powered from EDGs.)	Auto	* N/A *	0.0	0.0
					* N/A *	1240.4	1114.3
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESWPs (35 and 36) (RO verifies that pumps are running.)	Auto	* N/A *	280.8	280.8
					* N/A *	1521.2	1395.1
- 8 -	E-0-11	---	+27 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCM is available. (CHARGING pump 33 started on lightest loaded Bus.)	Manual	* N/A *	0.0	140.2
					* N/A *	1521.2	1535.3
- 9 -	< 16 >	---	+15 *** STEAM GENERATOR TUBE RUPTURE *** *** EVENT IDENTIFIED - EXIT TO E-3 ***	Manual	* N/A *	0.0	0.0
					* N/A *	1521.2	1535.3
			(No Loads Started or Tripped at this step)				

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM [42]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	E-1-9	---	Reset SI. (Steps 2 through 12 of RO-1 are completed.)	Manual	* N/A *	0.0	0.0
					* N/A *	1521.2	1535.3
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (MCC are reset.)	Manual	* N/A *	63.3	24.8
					* N/A *	1584.5	1560.1
- 12 -	E-3-11	---	+61 +63 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	* N/A *	0.0	0.0
					* N/A *	1584.5	1560.1
- 13 -	E-3-13	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (RHR pumps stopped.)	Manual	* N/A *	-182.0	-182.0
					* N/A *	1402.5	1378.1
- 14 -	E-3-14	---	-117 -120 Start one CHARGING pump. (CHARGING pump 33 is running.)	Manual	* N/A *	0.0	0.0
					* N/A *	1402.5	1378.1
- 15 -	E-3-14	---	(No Loads Started or Tripped at this step) Stop SI pumps. (Only pumps 32 and 33 running - stopped.)	Manual	* N/A *	-327.2	-327.2
					* N/A *	1075.3	1050.9
- 16 -	E-3-28	---	-122 -123 Start one CHARGING pump. (CHARGING pump 33 is running.)	Manual	* N/A *	0.0	0.0
					* N/A *	1075.3	1050.9
- 17 -	---	RO-1-20	(No Loads Started or Tripped at this step) CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (All Buses are powered from EDGs.)	Manual	* N/A *	0.0	0.0
					* N/A *	1075.3	1050.9
- 18 -	E-3-26	---	(No Loads Started or Tripped at this step) Start SI pumps if subcooling is < 40-deg F.	Manual	* N/A *	0.0	0.0
					* N/A *	1075.3	1050.9
			(No Loads Started or Tripped at this step)				

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM [42]


Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	E-3-38	---	Start BAST pumps and Primary Water pumps. (BAST pumps are running-MCC 36A-E never stripped. Primary Water pumps started.)	Manual	* N/A *	0.0	20.7
					* N/A *	1075.3	1071.6
- 20 -	E-3-32	---	+68 Stop CSPs. (Spray not actuated. No pumps are running.)	Manual	* N/A *	0.0	0.0
					* N/A *	1075.3	1071.6
- 21 -	E-3-36	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Pressurizer Heater Group 32 energized on lightest loaded Bus.)	Manual	* N/A *	207.9	0.0
					* N/A *	1283.2	1071.6
- 22 -	---	RO-1-27c	+101 START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Gear started.)	Manual	* N/A *	41.5	0.0
					* N/A *	1324.7	1071.6
- 23 -	E-3-40	---	+47 Stop 1 of 3 CCWPs. (No CCWPs are running.) Stop 1 of 3 ESWPs. (ESWPs 35 and 36 running.) Shutdown Motor-driven APWPs if desired. (APWPs remain running.)	Manual	* N/A *	0.0	0.0
					* N/A *	1324.7	1071.6
- 24 -	< 42 >	---	(No Loads Started or Tripped at this step)	Manual	* N/A *	0.0	0.0
			*** GO TO POST SGTR COOLDOWN *** *** EXIT TO ES-3.1 ***		* N/A *	1324.7	1071.6
- 25 -	ES-3.1-1	---	(No Loads Started or Tripped at this step) Operate Pressurizer Heaters as necessary. (Pressurizer Heater Group 32 is energized.)	Manual	* N/A *	0.0	0.0
					* N/A *	1324.7	1071.6
- 26 -	ES-3.1-3	---	(No Loads Started or Tripped at this step) Start: BAST Htrs. Hot Pen Blowers, PWMU. SFP pump [Loads started on MCC 37], Elect Tunnel Fans [Started at S1 Auto of MCC 36B] and one PAB fan [Fan 32 started on lightest loaded Bus].	Manual	* N/A *	0.0	244.4
					* N/A *	1324.7	1316.0
- 27 -	ES-3.1-13	---	+88 +61 +66 +67 +62 +69 Start one RHR pump as per SOP-RHR-1. (CCWP 32, NESWP 32 and RHR pump 32 started on lightest loaded Bus.)	Manual	* N/A *	500.4	316.1
					* N/A *	1825.1	1632.1
			+85 +118 +9			Over 1750	

STEAM GENERATOR TUBE RUPTURE

Report Date : August 29, 2009 Time : 3:54 PM [42]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A	Bus 2A/3A	Bus 6A
					Step Load/ Load (kW)	Step/Total Load (kW)	Step/Total Load (kW)
- 28 -	ES-3.1-16	---	Evaluate long term plant status. (Two AFWPs are running. As per FOLDBOUT page, AFWP 31 is stopped on highest loaded Bus.) -1	Manual	* N/A *	-378.9	0.0
					* N/A *	1446.2	1632.1

STEAM GENERATOR TUBE RUPTURE



Steam Generator Tube Rupture
 Buses 2A/3A Tied Together, Bus 5A Not Available
 Loss of Off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

AFWP 33	EDG 32
CCWP 32	EDG 31
CCWP 33	EDG 32
CHARGING PUMP 33	EDG 32
ESWP 35	EDG 31
ESWP 36	EDG 32
FCU 32	EDG 31
FCU 34	EDG 31
FCU 35	EDG 32
MCC 34: TURBINE TURNING GEAR	EDG 31
MCC 36B: AUTO	EDG 32
MCC 36C: AUTO	EDG 31
MCC 36D: AUTO	EDG 32
MCC 37: BAST HEATER (TANK #1)	EDG 32
MCC 37: BAST HEATER (TANK #2)	EDG 32
MCC 37: PENT. BLOWERS (#1)	EDG 32
MCC 37: PENT. BLOWERS (#2)	EDG 32
MCC 37: PW MU PUMP	EDG 32
MCC 37: SPENT FUEL COOLING PUMP 31	EDG 32
MCCS RESET (2A/3A) AS PER SOP-EL-15	EDG 31
MCCS RESET (6A) AS PER SOP-EL-15	EDG 32
NESWP 32	EDG 31
PAB FAN 32	EDG 32
PRESSURIZER HEATER 32	EDG 31
RHR PUMP 32	EDG 32

NEW YORK POWER AUTHORITY
EMERGENCY OPERATING PROCEDURES
ELECTRICAL LOADING SCENARIO MANAGEMENT SYSTEM
Version 1.1

IP3-CALC-ED-00207 REV 8

STEAM GENERATOR TUBE RUPTURE

LOAD LIST TRACKING NUMBER : 1015

Report Print Date : August 25, 2009
Report Print Time : 3:54 PM

*** BUSES 2A AND 3A TIED TOGETHER ***
*** BUS 2A AND/OR 3A NOT AVAILABLE ***

*** LOSS OF OFF-SITE POWER ***

End of Emergency Operating Procedure Loading

Bus 5A = 1583.1 Bus 2A/3A = * N/A * Bus 6A = 1491.9 (kW)

1750 kW Overload Summary

Emergency Diesel Generator 33 on Bus 5A is below the 1750 kW rating
Bus 2A and/or 3A Not Available
Emergency Diesel Generator 32 on Bus 6A is below the 1750 kW rating

1950 kW Overload Summary

Emergency Diesel Generator 23 on Bus 5A is below the 1950 kW rating
Bus 2A and/or 3A Not Available
Emergency Diesel Generator 32 on Bus 6A is below the 1950 kW rating

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM [43]

Step Number	SR0 Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 1 -	---	---	MCC 36A, 36B, 36D and 36E	Auto	110.0	* N/A *	100.4
					110.0	* N/A *	100.4
- 2 -	---	RO-1-2	+50 +53 +59 +60 SI pumps Bland 33 RHR pump 32 (mini flow, RCS press > 325) (RO verifies that pumps are running.)	Auto	327.2	* N/A *	509.2
					437.2	* N/A *	609.6
- 3 -	E-0-9	---	+120 +121 +123 CSPs 31 and 32 (CSPs started during Phase B only.) (E-0-9 verifies that spray is not required.)	Manual	0.0	* N/A *	0.0
					437.2	* N/A *	609.6
- 4 -	---	RO-1-3	(No Loads Started or Tripped at this step) FCUs 31, 33 and 35 (RO verifies that fans are running.)	Auto	258.0	* N/A *	129.0
					695.2	* N/A *	738.6
- 5 -	---	RO-1-5	+29 +33 +37 AFWP 33 (RO verifies that pump is running.)	Auto	0.0	* N/A *	375.7
					695.2	* N/A *	1114.3
- 6 -	---	RO-1-7	+2 CHECK if Offsite power is available to a 480V Bus to start at least one CCWP. (All Buses are powered from EDGs.)	Auto	0.0	* N/A *	0.0
					695.2	* N/A *	1114.3
- 7 -	---	RO-1-8	(No Loads Started or Tripped at this step) ESWPs (34 and 36) (RO verifies that pumps are running.)	Auto	280.8	* N/A *	280.8
					976.0	* N/A *	1395.1
- 8 -	E-0-11	---	+26 +28 Start one CHARGING pump if RCS pressure is > than 325 psig and CCW is available. (CHARGING pump 31 started on lightest loaded Bus.)	Manual	140.2	* N/A *	0.0
					1116.2	* N/A *	1395.1
- 9 -	< 16 >	---	+13 *** STEAM GENERATOR TUBE RUPTURE *** *** EVENT IDENTIFIED - EXIT TO E-3 *** (No Loads Started or Tripped at this step)	Manual	0.0	* N/A *	0.0
					1116.2	* N/A *	1395.1

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM [43]

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 10 -	E-3-9	---	Reser SI. (Step 2 through 12 of RO-1 are completed.)	Manual	0.0	* N/A *	0.0
					1116.2	* N/A *	1395.1
- 11 -	---	RO-1-15	(No Loads Started or Tripped at this step) RESET MCCs as per SOP-EL-15. (MCCs are reset.)	Manual	85.8	* N/A *	24.8
					1202.0	* N/A *	1419.9
- 12 -	E-3-11	---	+S2 +B1 ESTABLISH Instrument Air to Containment. (Load accounted for in MCC reset.)	Manual	0.0	* N/A *	0.0
					1202.0	* N/A *	1419.9
- 13 -	E-3-12	---	(No Loads Started or Tripped at this step) Stop RHR pumps. (Only RHR pump 32 running - stopped.)	Manual	0.0	* N/A *	-182.0
					1202.0	* N/A *	1237.9
- 14 -	E-3-14	---	-130 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	* N/A *	0.0
					1202.0	* N/A *	1237.9
- 15 -	E-3-24	---	(No Loads Started or Tripped at this step) Stop SI pumps. (Only pumps 31 and 33 running - stopped.)	Manual	-327.2	* N/A *	-327.2
					874.8	* N/A *	910.7
- 16 -	E-3-25	---	-121 -123 Start one CHARGING pump. (CHARGING pump 31 is running.)	Manual	0.0	* N/A *	0.0
					874.8	* N/A *	910.7
- 17 -	---	RO-1-20	(No Loads Started or Tripped at this step) CHECK if Offsite power is available to a 480V Bus to start at least one NESWP. (All Buses are powered from EDGs.)	Manual	0.0	* N/A *	0.0
					874.8	* N/A *	910.7
- 18 -	E-3-26	---	(No Loads Started or Tripped at this step) Start SI pumps if subcooling is < 40-deg F.	Manual	0.0	* N/A *	0.0
					874.8	* N/A *	910.7
			(No Loads Started or Tripped at this step)				

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM [43]


Step Number	SPO Step	RO Step	Loading Step Description	Initiation	Bus 5A Step Load/ Load (kW)	Bus 2A/3A Step/Total Load (kW)	Bus 6A Step/Total Load (kW)
- 19 -	E-3-28	---	Start BAST pumps and Primary Water pumps. (BAST pumps are running-MCC 36A-E never stripped. Primary Water pump started.)	Manual	0.0	* N/A *	20.7
					874.8	* N/A *	931.4
- 20 -	E-3-32	---	+68 Stop CSPs. (Spray not actuated. No pumps are running.)	Manual	0.0	* N/A *	0.0
					874.8	* N/A *	931.4
- 21 -	E-3-36	---	(No Loads Started or Tripped at this step) Energize at least one Pressurizer Heater Group as per SOP-EL-15. (Pressurizer Heater Group 33 energized on lightest loaded Bus.)	Manual	207.9	* N/A *	0.0
					1082.7	* N/A *	931.4
- 22 -	---	RO-1-27c	+109 START AC and STOP DC Oil Pumps IF 480V Buses are powered from Offsite and tie-breakers are open. Start Turb Turning Gear. (Bus 2A/3A unavailable.)	Manual	0.0	* N/A *	0.0
					1082.7	* N/A *	931.4
- 23 -	E-3-40	---	(No Loads Started or Tripped at this step) Stop 1 of 3 CCWPs (No CCWPs are running.) Stop 1 of 3 ESWPs (ESWPs 34 and 36 running.) Shutdown Motor-driven AFWPs if desired. (Bus 2A/3A not available. AFWP 33 remains running)	Manual	0.0	* N/A *	0.0
					1082.7	* N/A *	931.4
- 24 -	< 42 >	---	(No Loads Started or Tripped at this step)	Manual	0.0	* N/A *	0.0
			*** GO TO POST SGTB COOLDOWN *** *** EXIT TO ES-3.1 ***		1082.7	* N/A *	931.4
- 25 -	ES-3.1-1	---	(No Loads Started or Tripped at this step) Operate Pressurizer Heaters as necessary. (Pressurizer Heater Group 33 is energized.)	Manual	0.0	* N/A *	0.0
					1082.7	* N/A *	931.4
- 26 -	ES-3.1-3	---	(No Loads Started or Tripped at this step) Start: BAST Htrs, Hot Pen. Blowers, PNMU, SFP pump [Loads started on MCC 37], Electrical Tunnel Fans [Started at SI Auto of MCC 36A and B] and one PAB Fan [Fan 32 started].	Manual	0.0	* N/A *	244.4
					1082.7	* N/A *	1175.8
- 27 -	ES-3.1-13	---	+88 +61 +66 +67 +62 +69 Start one RHR pump as per SOP-RHR-1. (CCWP 31 and NESWP 31 started on lightest loaded Bus. RHR 32 started on only available Bus.)	Manual	500.4	* N/A *	316.1
					1583.1	* N/A *	1491.9
			-119 +84 +6				

STEAM GENERATOR TUBE RUPTURE

Report Date : August 25, 2009 Time : 3:54 PM (43)

Step Number	SRO Step	RO Step	Loading Step Description	Initiation	Bus 5A	Bus 2A/3A	Bus 6A
					Step Load/Load (kW)	Step/Total Load (kW)	Step/Total Load (kW)
- 38 -	ES-1.1-15	---	Evaluate long term plant status.	Manual	0.0	* N/A *	0.0
			(No Loads Started or Tripped at this step)		1582.1	* N/A *	1491.9

STEAM GENERATOR TUBE RUPTURE



Steam Generator Tube Rupture
 Buses 2A and / or 3A Not Available
 Loss of Off-site Power
 Operating Load at the End of Scenario

EQUIPMENT RUNNING**POWER FROM EDG**

1 AFWP 33	EDG 32
2 CCWP 31	EDG 33
3 CHARGING PUMP 31	EDG 33
4 ESWP 34	EDG 33
5 ESWP 36	EDG 32
6 FCU 31	EDG 33
7 FCU 33	EDG 33
8 FCU 35	EDG 32
15 MCC 36A: AUTO	EDG 33
16 MCC 36B: AUTO	EDG 32
17 MCC 36D: AUTO	EDG 32
18 MCC 36E: AUTO	EDG 33
19 MCC 37: BAST HEATER (TANK #1)	EDG 32
20 MCC 37: BAST HEATER (TANK #2)	EDG 32
21 MCC 37: PENT. BLOWER (#1)	EDG 32
22 MCC 37: PENT. BLOWER (#2)	EDG 32
23 MCC 37: PW MU PUMP	EDG 32
24 MCC 37: SPENT FUEL COOLING PUMP 31	EDG 32
26 MCCS RESET (5A) AS PER SOP-EL-15	EDG 33
27 MCCS RESET (6A) AS PER SOP-EL-15	EDG 32
28 NESWP 31	EDG 33
29 PAB FAN 32	EDG 32
30 PRESSURIZER HEATER 33	EDG 33
31 RHR PUMP 32	EDG 32

APPENDIX A

Viewing my 'ump'

1 PROJECT INT-CSAPCH 1/2/3 S.O. NO. 67C69216
 2 FURNISHED BY WESTINGHOUSE ELECTRIC DATE 10/26/67 BY

3 MARK OR ITEM NO. PURCHASER'S REQUIREMENTS DATA FURNISHED BY SELLER

MARK OR ITEM NO.	PURCHASER'S REQUIREMENTS	DATA FURNISHED BY SELLER
1	PRICE	MAKE Westinghouse
2	TYPE	FRAME NO. 445TS
3	NO. OF UNITS 3/Plant	HORSEPOWER 200
4	MOUNTING	SERVICE FACTOR 1.15
5	ELEC. CHARACTERISTICS 460 V. 3 PH 60 CY	FULL LOAD RPM 1775
6	SYNCH. SPEED RPM 1800	FULL LOAD AMP 221
7	HORSEPOWER 200	LOCKED ROTOR AMP 1293
8	SERVICE FACTOR 1.15	STARTING TORQUE, % F.L. 125
9	ENCLOSURE	PULL-OUT TORQUE, % F.L. 230
10	INSULATION CLASS B	EFF.-FULL LOAD, % 93.1
11	INSULATION TREATMENT PMR	EFF.-3/4 LOAD, % 93.1
12	AMBIENT TEMP-C 40°	EFF.-1/2 LOAD, % 92.3
13	STATOR TEMP RISE-C 90°C at 1.15 S.F.	P.F.-FULL LOAD, % 90.4
14	BEARING TYPE	P.F.-3/4 LOAD, % 89.4
15	BEARING TEMP RELAY	P.F.-1/2 LOAD, % 85.1
16	BEARING THERMOCOUPLE	P.F.-LOCKED ROTOR 29.8
17	HALF COUPL. OR SHEAVE MTD. BY	SPACE HTRS., TOTAL WATTS -
18	ROTATION*	RADIAL BEARING-TYPE -
19	WKT OF DRIVEN EQUIP.	THRUST BEARING-TYPE -
20	BRKVY. TORQ. OF M. EQUIP.	BEARING SERVICE-HR. -
21	OVERSIZE COND. BOX	NORMAL BRG. OPER. TEMP-C -
22	COND. BOX LOCATION*	NET WEIGHT-LB. -
23	SPACE HEATERS, VOLTAGE, PHASE	OIL COOL. SYS. REQ'D -
24	SPLIT END PFLLS	BRG. OIL PRESS. RANGE, PSI -
25	TERMINAL LUGS, TYPE	BRG. OIL REQ'D EA. BRG. GPM -
26	STATOR HIGH TEMP DEVICE	NAME PLATE CODE LETTER G
27	ADJUSTABLE SLIDE RAILS	PERMISSIBLE STARTS PER HR: -
28	SOLEPLATES	MOTOR AT AMBIENT TEMP -
29	PROJECT ELEV., FT. -	MOTOR AT RATED TOTAL TEMP -
30	SHAFT (HOLLOW, SOLID)	TYPE SEALED INSUL. SYS. -
31	COUPLING (SELF-RELEASE)	DESCRIPTION OF INSUL. SYS. Class B
32	SOLID, NONREVERSING	P.M.R.
33	ADJUSTABLE, FLEXIBLE	
34	VERT. MAX DOWNTHRUST	
35	VERT. MAX UP THRUST	
36	VERT. MIN UP THRUST	
37	VERT. MIN DOWNTHRUST	
38	(WITH MOTOR RUNNING)	
39	SIDE THRUST	
40	MAX REVERSE SPEED	
41	DRAIN PLUG AND VENT	
42	AIR INTAKE SCREENS	
43		
44		
45		
46		
47		
48		
49		
50		
51		
52	REMARKS:	REMARKS:
53	ALL PERFORMANCE DATA BASED ON NORMAL RATED	ALL PERFORMANCE DATA BASED ON NORMAL RATED
54	VOLTAGE AND FREQUENCY	VOLTAGE AND FREQUENCY
55	ITEMS 34-44 APPLY TO VERTICAL MOTORS ONLY	INDICATE IF DATA IS ESTIMATED
56		
57		
58		
59		
60	* VIEWED FROM END OPPOSITE COUPLING END	

Calc. No. IP3-CALC-ED-00207
 Rev. 8
 Appendix A.1 Sheet 1 of 1

INDUCTION MOTOR DATA SHEET
 WESTINGHOUSE FORM 54082

1	PROJECT WESTINGHOUSE ELECTRIC CORP.	S.O. NO. 54E-70491-B
2	FURNISHED BY INGERSOLL-RAND CO.	DATE 7-27-63 BY E. CAMPBELL
3	MARK OR ITEM NO. INT - ACC ROOM	
4	PURCHASER'S REQUIREMENTS	DATA FURNISHED BY SELLER
5	SERVICE COMPONENT COOLING	MAX WESTINGHOUSE ELECTRIC CORPORATION
6	TYPE 8X18SE	FRAME NO. 504US
7	NO. OF UNITS SIX (6)	HORSEPOWER 250
8	MOUNTING	SERVICE FACTOR 1.15
9	ELEC. CHARACTERISTICS V. PH CT	FULL LOAD RPM 1768
10	SYNCH. SPEED, RPM	FULL LOAD AMP 282
11	HORSEPOWER	LOCKED ROTOR AMP 1407
12	SERVICE FACTOR	STARTING TORQUE, % F.L. 120%
13	ENCLOSURE	PULL-OUT TORQUE, % F.L. 200%
14	INSULATION CLASS	EFF.-FULL LOAD, % 93.4%
15	INSULATION TREATMENT	EFF.-3/4 LOAD, % 93.7%
16	AMBIENT TEMP - C	EFF.-1/2 LOAD, % 93.2%
17	STATOR TEMP RISE - C	P.F.-FULL LOAD, % 89.1%
18	BEARING TYPE	P.F.-3/4 LOAD, % 89.0%
19	BEARING TEMP RELAY	P.F.-1/2 LOAD, % 85.7%
20	BEARING THERMOCOUPLE	P.F.-LOCKED ROTOR 28.2
21	HALF COUPL. OR SHEAVE MTD. BY	SPACE MTRS., TOTAL WATTS ---
22	ROTATION*	RADIAL BEARING - TYPE ---
23	NR 2 OF DRIVEN EQUIP.	THRUST BEARING - TYPE ---
24	BRKDY. TORQ. DRVN. EQUIP.	BEARING SERVICE - NR. ---
25	OVERSIZE COND. BOX	NORMAL BRG. OPER. TEMP - C 60 DEGREES C TOT
26	COND. BOX LOCATION	NET WEIGHT - LB. 1475
27	SPACE HEATERS, VOLTAGE, PHASE	OIL COOL. SYS. REQ'D ---
28	SPLIT END BELLS	BRG. OIL PRESS. RANGE, PSI ---
29	TERMINAL LUGS, TYPE	BRG. OIL REQ'D EA. BRG. GPM ---
30	STATOR HIGH TEMP DEVICE	NAME PLATE CODE LETTER D
31	ADJUSTABLE SLIDE RAILS	PERMISSIBLE STARTS PER HR.*
32	SOLEPLATES	*MOTOR AT AMBIENT TEMP 2 (T40)
33	PROJECT ELEV., FT.	*MOTOR AT RATED TOTAL TEMP 1 (ONE)
34	SHAFT (HOLLOW, SOLID)	TYPE SEALED INSUL. SYS. CLASS B
35	COUPLING (SELF-RELEASE)	DESCRIPTION OF INSUL. SYS. PREMIUM SHIELDED
36	SOLID, NONREVERSING	CALCULATIONS ON 460 VOLTS
37	ADJUSTABLE, FLEXIBLE	
38	VERT. MAX DOWNTHRUST	
39	VERT. MAX UP THRUST	*SUBSEQUENT STARTS
40	VERT. MIN UP THRUST	MOTOR RUNNING - 15 MIN. APART
41	VERT. MIN DOWNTHRUST	" STANDING - 45 " APART
42	(WITH MOTOR RUNNING)	
43	SIDE THRUST	
44	MAX REVERSE SPEED	
45	DRAIN PLUG AND VENT	
46	AIR INTAKE SCREENS	
47		
48		
49		
50		
51		
52	REMARKS:	REMARKS:
53	ALL PERFORMANCE DATA BASED ON NORMAL RATED	ALL PERFORMANCE DATA BASED ON NORMAL RATED
54	VOLTAGE AND FREQUENCY	VOLTAGE AND FREQUENCY
55	ITEMS 24-44 APPLY TO VERTICAL MOTORS ONLY	INDICATE IF DATA IS ESTIMATED CALCULATED DATA
56	I-R FACTORY ORDER NO. -037-30650	
57	ITEMS 1 & 2	INGERSOLL-RAND ORDER NO. 6592453
58		WESTINGHOUSE FACTORY NO. NY-35520
59		
60	* VIEWED FROM END OPPOSITE COUPLING END	

Calc No. IP3-CALC-ED-00207
 Rev. 8
 Appendix A.2 Sheet 1 of 1

Cont. Recirc Fan

CONT RECIRC FAN

WESTINGHOUSE ELECTRIC CORPORATION

Calc No. IP3-CALC-ED-00207, Rev. 8 MOTOR DIVISION, BUFFALO, N.Y.

Appendix A.3 Sheet 1 of 4

225 HP, 440V, 30



REPORT OF COMMERCIAL TESTS - INDUCTION MOTOR

DATE 11/5/70	STYLE NO.	S.O. NO. 69F97009	S.O. NO. NY-78526-AR6-L7-1	PURCHASER'S ORDER NO.
-----------------	-----------	----------------------	-------------------------------	-----------------------

PURCHASER

Westinghouse Nuclear Energy Systems-Indian Point #3 Spin # Int. RCMOCF1-5

NAME PLATE DATA

H.P.	SPEED	PHASE	FREQ.	VOLTS	AMPS.	TYPE	FRAME	TEMP. RISE	TIME RATING	DESIGN (LETTER)	LOCKED Rotor CODE LETTER
225	699 ⁵	3	60	440	312	LSM	D88.53	10°C	Cont.	B	E

TEST CHARACTERISTICS

4.75X

SERIAL NO.	NO LOAD					LOCKED ROTOR				OPEN CIRCUIT VOLTAGE (BOUND ROTOR)	DIELECTRIC TEST
	VOLTS	FREQ.	SPEED	AMPS.	Watts	VOLTS	FREQ.	AMPS.	Vibration		
1	440	60	720	148.5	5200				F-.0019		2500
				145.5					R-.0008		
				148.5					A-.0004		
Water	120			2.01		Rot. per NP55853					1300
						Submerged in water - -					500
2	440	60	720	147	4800				F-.0003		2500
				148					R-.0003		
				147					A-.0002		
Heater	120			2.1		Rot. per NP55853					1300
						Submerged in Water - -					500
3	440	60	720	143.6	5280				F-.00013		2500
				142					R-.00021		
				145.4					A-.00012		
Heater	120			2.04		Rot. per NP55853					1300
						Submerged in Water					500

TESTS ON THIS MOTOR DUPLICATE

APPROVED BY

ENGINEER

DATE

24000

Calc. No. - IP3-CALC-ED-00207, Rev. 8, Appendix A.3 sheet 2 of 4

WESTINGHOUSE ELECTRIC CORPORATION
MOTOR DIVISION, BUFFALO, N.Y.



REPORT OF COMMERCIAL TESTS - INDUCTION MOTOR Page 2 of 2

DATE	STYLE NO.	S.O. NO. 69F97009	S.O. NO.	PURCHASER'S ORDER NO.
PURCHASER				


NAME PLATE DATA

H.P.	SPEED	PHASE	FREQ.	VOLTS	AMPS.	TYPE	FRAME	TEMP. RISE	TIME RATING	DESIGN (LETTER)	LOCKED ROTOR

TEST CHARACTERISTICS

SERIAL NO.	NO LOAD					LOCKED ROTOR				OPEN CIRCUIT VOLTAGE (UNLOADED MOTOR)	DIELECTR TEST
	VOLTS	FREQ.	SPEED	AMPS.	Watts	VOLTS	FREQ.	AMPS.	Vibration		
4	440	60	720	143.8	5120				F-.00041		.2500
				144.2					R-.00024		
				144.6					A-.00016		
Heater	120			2.02				Rot. per NP 55853			1300
									Submerged in Water -		500
5	440	60	720	141.6	5200				F-.00026		2500
				146.6					R-.00031		
				141.4					A-.00011		
Heater	120			2.02				Rot. per NP 55853			1300
									Submerged in Water -		500

WESTINGHOUSE ELECTRIC CORPORATION
 STURTEVANT DIVISION
 ORDER NO. PHY 2027-5



8560D S.W.S. FAN
 712 R.P.M. - DENSITY 0.0750 LBS/CU.FT.
 OUTLET AREA 20.71 SQ.FT.

FOR
 WESTINGHOUSE NUCLEAR
 ENERGY SYSTEMS INT

LABORATORY TEST PERFORMANCE

Calc. No. IP3-CAL-ED-00207
 Rev. B
 Appendix 4.3
 Sheet 3 of 4

VOLUME (C.F.M. X 1000)

DATE 11/70

INDUCTION MOTOR DATA SHEET
WESTINGHOUSE FORM 34082

Recirculation Pumps

1	PROJECT WESTINGHOUSE ELECTRIC CORP.	S.O. NO.	67F63897
2	FURNISHED BY INGERSOLL-RAND CO.	DATE	2-12-68 BY F. CAMPBELL
3	MARK OR ITEM NO. INT PLANT		
4	PURCHASER'S REQUIREMENTS		DATA FURNISHED BY SELLER
5	SERVICE VERTICAL SAFETY INJECTION RECIRCULATION	WESTINGHOUSE ELEC. CORP.	
6	TYPE 24 AP-3	FRAME NO.	538.5 PH
7	NO. OF UNITS FOUR (4) (2 ea. PLANT)	HORSEPOWER	350
8	MOUNTING	SERVICE FACTOR	1.15
9	ELEC. CHARACTERISTICS V. PH CT	FULL LOAD RPM	1183
10	SYNCH. SPEED, RPM	FULL LOAD AMP	418
11	HORSEPOWER	LOCKED ROTOR AMP	2425
12	SERVICE FACTOR	STARTING TORQUE, % F.L.	125%
13	ENCLOSURE	FULL-OUT TORQUE, % F.L.	220%
14	INSULATION CLASS	EFF.-FULL LOAD, %	93.7%
15	INSULATION TREATMENT	EFF.-3/4 LOAD, %	93.9%
16	AMBIENT TEMP -C	EFF.-1/2 LOAD, %	93.4%
17	STATOR TEMP RISE -C	P.F.-FULL LOAD, %	87.4%
18	BEARING TYPE	P.F.-3/4 LOAD, %	85.0%
19	BEARING TEMP RELAY	P.F.-1/2 LOAD, %	77.9%
20	BEARING THERMOCOUPLE	P.F.-LOCKED ROTOR	32.8%
21	HALF COUPL. OR SHEAVE MTD. BY	SPACE MTRS., TOTAL WATTS	---
22	ROTATION*	RADIAL BEARING-TYPE	BALL
23	WE ? OF DRIVEN EQUIP.	THRUST BEARING-TYPE	BALL
24	BRKDY. TORQ. DRYN. EQUIP.	BEARING SERVICE-HR. B-10 LIFE	1000 HR.
25	OVERSIZE COND. BOX	NORMAL BRG. OPER. TEMP-C	40 DEGREES C
26	COND. BOX LOCATION*	NET WEIGHT-LB.	4200 LBS
27	SPACE HEATERS, VOLTAGE, PHASE	OIL COOL. SYS. REQ'D	YES
28	SPLIT END BELLS	BRG. OIL PRESS. RANGE, PSI	----
29	TERMINAL LUGS, TYPE	BRG. OIL REQ'D EA. BRG. GPM	STAMPED ON NAMEPLATE
30	STATOR HIGH TEMP DEVICE	NAME PLATE CODE LETTER	F
31	ADJUSTABLE SLIDE RAILS	PERMISSIBLE STARTS PER HR:	---
32	SOLE PLATES	MOTOR AT AMBIENT TEMP	3
33	PROJECT ELEV., FT.	MOTOR AT RATED TOTAL TEMP	2
34	SHAFT HOLLOW, SOLID	TYPE SEALED INSUL. SYS.	
35	COUPLING (SELF-RELEASE)	DESCRIPTION OF INSUL. SYS.	THERMALASTIC EPOXY
36	SOLID, NONREVERSING		WITH HAND LAID MICA FOR 2300
37	ADJUSTABLE, FLEXIBLE		VOLT CLASS
38	VERT. MAX DOWNTHRUST		
39	VERT. MAX UPTHURST		
40	VERT. MIN UPTHURST		
41	VERT. MIN DOWNTHRUST		
42	(WITH MOTOR RUNNING)		
43	SIDE THRUST		
44	MAX REVERSE SPEED		
45	DRAIN PLUG AND VENT		
46	AIR INTAKE SCREENS		
47			
48			
49			
50			
51			
52	REMARKS:	REMARKS:	
53	ALL PERFORMANCE DATA BASED ON NORMAL RATED	ALL PERFORMANCE DATA BASED ON NORMAL RATED	
54	VOLTAGE AND FREQUENCY	VOLTAGE AND FREQUENCY	
55	ITEMS 34-44 APPLY TO VERTICAL MOTORS ONLY	INDICATE IF DATA IS ESTIMATED	ALL INFO CALCULATED
56	I-R FACTORY ORDER NO. 037-30600	INGERSOLL-RAND ORDER NO. C592270	
57		WESTINGHOUSE FACTORY NO. NY 35513-67	
58			
59			
60	* VIEWED FROM END OPPOSITE COUPLING END		

Calc. No. IP3-CALC-ED-00207
Rev. B
Appendix A.4
Sheet 1 of 3

MOTOR DATA

Calc. No. IP3-CALC-ED-00207

Pa. B

Appendix A.4

Sheet 2 of 3

UNIT: Indian Point Unit Nos. 2 and 3

COMPONENT: Recirculation Pumps

MOTOR MANUFACTURER: Westinghouse Large Motor Division, Buffalo, New York

MOTOR SHOP ORDER NUMBER AND/OR SERIAL NUMBER: 67F63897-1S through 4S-67

MOTOR H.P. RATING: 350 @ 1181 RPM

MOTOR FRAME SIZE: 588.5

MOTOR WRR = 313 LB-FT²

LINE VOLTAGE: 440 (100%)



SLIP (PERCENT)	MOTOR SPEED (RPM)	MOTOR TORQUE (LB-FT)
100.00	0	2067.47
95.00	60	2092.84
90.00	120	2120.03
85.00	180	2149.27
80.00	240	2180.79
75.00	300	2201.22
70.00	360	2219.39
65.00	420	2242.09
60.00	480	2270.12
55.00	540	2304.55
50.00	600	2346.76
45.00	660	2315.83
40.00	720	2386.40
35.00	780	2473.89
30.00	840	2583.64
25.00	900	2723.22
20.00	960	2903.66
15.00	1020	3157.02
10.00	1080	3517.62
9.50	1086	3555.48
9.00	1092	3592.23
8.50	1098	3610.73
8.00	1104	3658.74
7.50	1110	3698.61
7.00	1116	3727.61
6.50	1122	3742.37
6.00	1128	3738.79
5.50	1134	3711.89
5.00	1140	3655.77
4.50	1146	3563.58
4.00	1152	3427.60
3.50	1158	3239.44
3.00	1164	2999.32
2.50	1170	2690.21
2.00	1176	2301.36
1.50	1182	1828.88
1.24	1185	1551.96

Nuclear Engineering CALCULATION SHEET

New York Power Authority Calculation No. IP3-ANAL-SI-02802 Revision 0

Project: Internal Recirculation Issue Page 4 of 4

Subject: Single Pump Recirculation - Amptector Impact Computed by: MA Date: 7/30/98
Reviewed by: EJG Date: 7/27/98

CALC. No. IP3-CALC-ED-00207 REV 8
APPENDIX A.4
SHEET 3 OF 3

of using motor efficiency and power factor.

5.0 EVALUATION (continued)

The matrix of values for FLOW, BHP, CURRENT (MOTOR RATING) AND CURRENT (DEGRADED GRID) is the following:

FLOW(GPM)	BHP	CURRENT (AMPS)	
		MOTOR RATING 440 VAC (BUS NOMINAL VOLTAGE 480 VAC)	DEG GRID 422 VAC
3000	335	440	458
3250	348	457	476
3500	352	462	482
3530*	354	465	484
3750	365	479	499
4000	368	483	503

* flow limit based on mechanical / hydraulic restrictions

6.0 SUMMARY:

Considering the nominal amptector setting of 540 amps and a maximum realistic amptector variance on the low side to 486 amps, it can be seen that even under DEGRADED GRID conditions, the pump would not be expected to trip below 3530 gpm. This expectation is conservative given the method of calculating ampere loading via the BPH conversion formula being used in Section 5.0. Additionally, operator remedial action for re-establishing normal bus voltage will be annunciated prior to voltage falling to the motor's rated voltage of 440 Vac. It can therefore be concluded that the Recirculation Pumps can be expected to run without a motor overcurrent trip for all flow values covered by the Recirc Pump curve as long as the pump rated voltage of 440 volts is being supplied to its terminals. Additionally, it can be concluded that a single Recirc pump will be capable of supplying the NPSH limited flow of 3530 gpm even under degraded grid conditions.

1 PROJECT WESTINGHOUSE ELECTRIC CORPORATION S.O. No. 54E70491-B
 2 FURNISHED BY INGERSOLL-RAND CO. DATE 2/23/68 BY F. CAMPBELL
 3 MARK OR ITEM NO INT - SIAPCS4

PURCHASER'S REQUIREMENTS				DATA FURNISHED BY SELLER	
5	SERVICE CONTAINMENT SPRAY			MAKE WESTINGHOUSE ELECTRIC CORP.	
6	TYPE BX21A			FRAME NO. 5090	
7	NO. OF UNITS FOUR (4) (TWO EA. PLANT)			HORSEPOWER 400	
8	MOUNTING			SERVICE FACTOR 1.15	
9	ELEC. CHARACTERISTICS	V.	PH	CY	FULL LOAD RPM 1776
10	SYNCH. SPEED. RPM			FULL LOAD AMP 438	
11	HORSEPOWER			LOCKED ROTOR AMP 2487	
12	SERVICE FACTOR			STARTING TORQUE, % F.L. 130%	
13	ENCLOSURE			PULL-OUT TORQUE, % F.L. 240%	
14	INSULATION CLASS			EFF.-FULL LOAD, % 94.4%	
15	INSULATION TREATMENT			EFF.-3/4 LOAD, % 94.7%	
16	AMBIENT TEMP - C			EFF.-1/2 LOAD, % 94.4%	
17	STATOR TEMP RISE - C			P.F.-FULL LOAD, % 90.6%	
18	BEARING TYPE			P.F.-3/4 LOAD, % 90.0%	
19	BEARING TEMP RELAY			P.F.-1/2 LOAD, % 86.3%	
20	BEARING THERMOCOUPLE			P.F.-LOCKED ROTOR 29.7	
21	HALF COUPL. OR SHEAVE MTD. BY			SPACE HTRS., TOTAL WATTS ---	
22	ROTATION*			RADIAL BEARING TYPE ----	
23	WK 2 OF DRIVEN EQUIP. 35 LB. - FT. ²			THRUST BEARING TYPE ---	
24	BRKWY. TORQ. DRVN. EQUIP. 11.0 LB. - FT.			BEARING SERVICE - HR. ---	
25	OVERSIZE COND. BOX			NORMAL BRG. OPER. TEMP - C 60 DEGREES TOTAL	
26	COND. BOX LOCATION.			NET WEIGHT - LB. 2860 LBS.	
27	SPACE HEATERS, VOLTAGE, PHASE			OIL COOL. SYS. REQ'D ---	
28	SPLIT END BELLS			BRG. OIL PRESS. RANGE, PSI ---	
29	TERMINAL LUGS, TYPE			BRG. OIL REQ'D EA. BRG. GPM ---	
30	STATOR HIGH TEMP DEVICE			NAME PLATE CODE LETTER E	
31	ADJUSTABLE SLIDE RAILS			PERMISSIBLE STARTS PER HR: *	
32	SOLEPLATES			*MOTOR AT AMBIENT TEMP 2 (TWO)	
33	PROJECT ELEV., FT.			*MOTOR AT RATED TOTAL TEMP 1 (ONE)	
34	SHAFT (HOLLOW, SOLID)			TYPE SEALED INSUL. SYS. CLASS 8	
35	COUPLING (SELF-RELEASE)			DESCRIPTION OF INSUL. SYS. THERMALASTIC EPOXY	
36	SOLID, NONREVERSING			CALCULATIONS BASED ON 460V	
37	ADJUSTABLE, FLEXIBLE				
38	VERT. MAX DOWNTHRUST			*SUBSEQUENT STARTS MOTOR RUNNING - 15 MIN. APART MOTOR STANDING - 45 MIN. APART	
39	VERT. MAX UP THRUST				
40	VERT. MIN UP THRUST				
41	VERT. MIN DOWNTHRUST				
42	(WITH MOTOR RUNNING)				
43	SIDE THRUST				
44	MAX REVERSE SPEED				
45	DRAIN PLUG AND VENT				
46	AIR INTAKE SCREENS				
47					
48					
49					
50					
51					
52	REMARKS:			REMARKS:	
53	ALL PERFORMANCE DATA BASED ON NORMAL RATED			ALL PERFORMANCE DATA BASED ON NORMAL RATED	
54	VOLTAGE AND FREQUENCY			VOLTAGE AND FREQUENCY	
55	ITEMS 34-44 APPLY TO VERTICAL MOTORS ONLY			INDICATE IF DATA IS ESTIMATED	
56	I-R FACTORY ORDER NO. 037-30650				
57	ITEMS 9 & 8			INGERSOLL-RAND ORDER NO. C-592453	
58				WESTINGHOUSE FACTORY N. N.Y. 35820	
59					
60	* VIEWED FROM END OPPOSITE COUPLING END				

Calc. No IP3-CALC-ED-00207
 Rev. 8
 Appendix A.5
 Sheet 1 of 1

Cont Spray Pump

BUFFALO, N.Y.

Date 11/2/81

POWER AUTHORITY STATE OF NEW YORK

Stock Order No. 81F32506

NY 30084

H.P. 400

Volts 460

Phase 3

Class B

Insulation

5009SZ HSDP

Poles 4

R.P.M.

1761

Cycles 60

	1	2	3	COMMENTS
Stator Res. @ 24°C				
Volts Per Terminal at no load 460 Volts	112			T ₁ T ₂ - .01416
Watts input at no load	6400			T ₁ T ₃ - .01416
Stator Res. (T-T) at 75° C - ohms	.017			T ₂ T ₃ - .01430
Working Winding Res. at 75° C - ohms				
Stator Res. (hot rings) at 75° C - ohms				Phase Rotation per NP55853
LOSSES IN WATTS AT FULL LOAD				
Stator Load Loss				
Stator I ² R Loss				Vibration with 1/2 Key
Stator I ² R Loss				Front Rear
Core Loss				Horz. .00024 .0002
Friction and Windage Loss				Vert. .00011 .0001
Efficiency - Full Load	93.4			Axial .00055 .00011
- 1/2 Load	93.9			
- 1/4 Load	93.7			
Power Factor Full Load	89.5			
- 1/2 Load	88.2			
- 1/4 Load	83.3			
Full Load	1764			
Per Term. at full load	448.5			
Watts at full load	319.6			
Watts per Term-Rotor locked 460 V	2327			
W Input-Rotor locked	584			
Sec. Volts between rings				
Amps per ring at full load				
Full Load Torque (F.L.T.) in lb. ft.	1190.5			
Sec. Torque in % of F.L.T.	239			
Working Torque in % of F.L.T.	139			
End Play Tested	OK			
Balance Tested	OK			
Stator Ins Tested 2000 V 60 Sec.	OK			
Stator Ins Tested V Sec.				
TEMPERATURE TESTS				
Length of Test in hours	4.50			
Volts	460			
Normal Full Load Amp.	115			
Temp. Rise - Stator Copper by RES.	59			
degrees C - Stator Iron	63.5			
Total - Rotor Copper Bearing Front	29	Total		
Temp. - Rotor Iron Rear	33	Temp.		
Room temperature in °C	26			

Calc. No IP3-CALC-ED-00207
 Rev 8
 Appendix A.6
 sheet 1 of 3

The above is a true and correct record of data obtained from tests made at the works of Westinghouse Electric Corporation.

P2* 80-IP-1985 REQ# 50621

PASNY PART#

(W) MOTOR 400 H.P. (WAREHOUSE) LIFELINE A MOTOR
RPM 1776, FRAME 5006S
PREVIOUS S.O. 68F/5104

01-09-250

(W) MOTOR 400 H.P. LIFELINE A MOTOR
3559 RPM FRAME 509-LLS

01-44-585

(W) MOTOR 400 H.P.
RPM 1761, FRAME 5009S2 HSDP
S.O. 81F32506

NYPA MEMOS

REQUISITION # 50621

MEMO - CONTAINMENT SPRAY PUMP MOTOR
ORIGINAL FRAME # 509US
REPLACE WITH FRAME # 5006-S

REQUISITION # 50603

AUX BOILER FEED PUMP MOTOR

REQUISITION # 50621

CONTAINMENT SPRAY PUMP MOTOR

REQUISITION # 50029

COMPONENT COOLING PUMP MOTOR

(W) MEMOS MARCH 5, 1970

P.O. 78-IP-3536

(W) MOTOR 438 HP

MEMO JULY 15, 1981

P.O. 80-IP-1985

CALLS FOR 400 H.P. FRAME 5006S MOTOR
WILL FURNISH A 5009S2 FRAME MOTOR
IN PLACE OF 509US FRAME MOTOR
THE 5009S2 WILL BE FURNISHED WITH SPECIAL SHAFT
EXTENSION TO MATCH THE 509US FRAME SHAFT

MEMO NO DATE (SOMETIME IN 1979)

PREVIOUS S.O. 68F/5104

FRAME 5006S (W) MOTOR

COMMENT IN SHIPPING INFO

Calc. No. IP3-CALC-ED-00207

Rev. 8

Appendix A-6

Sheet 2 of 3

P.O. 80-IP-1985 FEB. 26, 1982
RPM PROBLEM (W) RESPONSE
IS NOT A CONCERN

NYPA Q.C. ACCEPTANCE OF P.O. # 80-IP-1985
CONT. SPRAY PUMP

(W) MOTOR

400 HP, 460V, 50098Z FRAME

STYLE 81-F32506

1761 RPM MODEL HSDP 35R # 15-81

S.O. NO. 81F32506

DRAWING 2400003 REV 1 - SHOULD BE FOR 50098Z

DRAWING 8933D45 SUB 1 - FOR 50098 - 50065

(W)
MEMO

AD INT 5245 REQ 50621 S.O. 68F15104

QUESTIONS SHAFT LENGTH - SPECIAL SHAFT EXT.

STATES FRAME^{50098Z} MOUNTING WOULD MATCH 50985

NOTE: WOULD HAVE MATCHED MOUNTING DIM.

Calc. No. IP3-CALC-ED-00207

Rev. 8

Appendix A.6

Sheet 3 of 3

AFWP 31

AC MOTOR PERFORMANCE DATA
(AS TESTED VALUES)

Rel SO	Frame	Hp	Type	Ph/Hz	RPM	Volts
FNA 7704	E5008S	400	PB	3/60	3574	440
Amps	Duty	Amb/Insul.	S.F.	KVA/HP	Encl.	Stator Res.
460	Continuous	40° C / F	1.15	F	PROT	0.01064

TYPICAL PERFORMANCE

Load	Hp	Amperes	RPM	% P. F.	% Efficiency
NO LOAD		120	3600	6.1 %	
1/4	100	165	3593	64.4 %	92.3 %
1/2	200	251	3585	82.1 %	94.9 %
3/4	300	355	3577	87.0 %	95.4 %
FULL LOAD	400	468	3568	88.1 %	95.1 %
S. F.	460	542	3562	87.8 %	94.8 %

SPEED TORQUE

	RPM	Torque (% FLT)	Torque (ft.-lb.)	Torque (N-m)	Amperes
Locked Rotor	0	110 %	644	873	2512
Breakdown	3408	235 %	1382	1874	1645
Full Load	3568	100 %	588	797	468

RELIANCE ELECTRIC	DR. BY: <u>Phil Bamba</u>	DATE _____
	APP. BY: <u>Dolan</u>	DATE <u>3-19-97</u>
DOCUMENT NUMBER: <u>7704.009</u>	REVISION #: <u>0</u>	

CALC. NO IP3-CALC-ED-00207 REV. 8
APPENDIX A.7 SHEET 1 OF 2

AFWP 31

Facsimile
Reliance Electric
Motors Group
678 Erie Street
Stratford, Ontario N5A 6W1

 **Rockwell Automation**
Reliance Electric

To : Joe Raffaele

Date: May 5, 1997

Company: NYPA

Fax No.: 1 914 681 6482

Subject: Rotor WK square

Copy:

Total Pages: 1
(including cover)

From: R. W. (BOB) DALLY Phone: 519-271-3630 Fax: 519-271-1643

Internet: rwdally@re.ra.rockwell.com

Joe engineering informs me that the WK sq. is 61 lb./ft/sq. on this unit
FNA-7704 .

REGARDS:
506/97

CALC. No. IP3-CALC-ED-00207 REV. 8
APPENDIX A.7 SHEET 2 OF 2



AFWP 33

RELIANCE ELECTRIC

84999

24701 Euclid Avenue, Cleveland, Ohio 44117

Calc. No. IP3-CALC-ED-00207

Rev. 8

REPORT OF TEST

Appendix A.8 sheet 1 of 2 For Induction Motor

Purchaser: CONSOLIDATED EDISON CO.
P.O. BOX 799 COOPER STATION
NEW YORK, NEW YORK 10276-0799

Date of Test: 6/16/89
Purchase Order No.: 8-696017
Serial No.: YH883732 A2

P.O. # 646017
SERIAL # YH883732 A1/A2
STATION: FICKELL

APPLICATION: "STARTER INDUCTION FAN MOTOR" Nameplate Rating
"MOTOR-LIST FREQUENCIES FOR MOTOR"

Rated HP	Service Factor	Rated Speed r/min	Phase	Frequency Hz	Volts	Ampere	Type	Frame
400	1.15	3874	3	60	440	480	P	E50083

Temperature Rise

Conditions of Test				Temperature Rise °C			
Hours Run	Line Volts	Line Amperes	Cooling Air, °C	Stator		Rotor	
				Windings		Windings	
				*By RES. Method	*By --- Method	*By --- Method	*By --- Method
3.5	440	468	28.6	75.0	-----	-----	1.155F

Characteristics

Rated Slip, Percent	No-Load Line Current, amperes	Secondary Volts at Standstill	Secondary Amperes per Amp at Rated Load	Resistance at 25°C (between lines) ohms
.78	126	-----	-----	Prim. .01100 Sec. -----

Torque and Starting Current

Break-Down Torque in LB.-FT. with 50% volts applied	Locked-Rotor Torque in LB.-FT. with 50% volts applied	Starting Current Amperes (locked rotor) with 50% volts applied
341	228	1509.1

High Potential Tests

Volts rms for 60 Sec	
Stator	Rotor
2000	---

Efficiencies and Power Factor

Efficiency, Percent			Power Factor, Percent		
Rated Load	75 Percent Load	50 Percent Load	Rated Load	75 Percent Load	50 Percent Load
94.72	94.88	94.40	87.3	88.5	79.8

Notes: DATA BY J. W. ACKOBS... CHECKED BY P. M. Canty...
Data from test on THIS (tests or duplicates) motor.

*Indicate method as:
Thermometer
Thermocouple
Resistance
Embedded Detector

Approved by

Paul Reeves

Date: 6-21-89

AFWP 33

Calc. No. IP3-CALC-ED-00207

RCV. BY XEROX TELECOPIER 7811 4-19-89 18:29PM 1281 575 8388

Rev. 8

9147385383: 9

APR 19 '89 18:29 FROM RNY-PINEBROOK

Appendix A 8

PAGE. 889


Sheet 2 of 2

REL S.O. YH-863732
FRAME E50088
HP 400
TYPE P
PMASE/HERTZ 3/60

RPM 3674
VOLTS 440
AMPS 480
DUTY CONT
AMB-C/180R 40/F

S.P. 1.15
NEMA DESIGN B
CODE LETTER F
ENCLOSURE PROT
S/S --

NOTES --
TEST S.O. YH-863732 - A1
TEST DATE 3-28-89
STATOR RES. @ 20°C .01089
0.006 (BETWEEN LINES)



AMPERES SHOWN FOR 440 VOLT CONNECTION, IF OTHER VOLTAGE CONNECTIONS ARE AVAILABLE, THE AMPERES WILL VARY INVERSELY WITH THE RATED VOLTAGE.

RELIANCE ELECTRIC
CLEVELAND, OHIO 44117 U.S.A.

DR. BY *[Signature]* 3/29/89
CR. BY *[Signature]*
APP. BY *[Signature]* 3-29-89
DATE

A-C MOTOR PERFORMANCE CURVES
754999.T5T1
ISSUE DATE 3-29-89

1	PROJECT	Westinghouse Electric Corp.	S.O. NO.	54-E-70491-B
2	FURNISHED BY	Ingersoll-Rand Company	DATE	2-22-68 BY E. Campbell
3	MARK OR ITEM NO.	INT. ACA PR11-4		
4	PURCHASER'S REQUIREMENTS		DATA FURNISHED BY SELLER	
5	SERVICE	Residual Heat Removal	MAKE	Westinghouse Electric Corporation
6	TYPE	8X20d	FRAME NO.	509 11PZ
7	NO. OF UNITS	Four (4) (two each plant)	HORSEPOWER	400
8	MOUNTING		SERVICE FACTOR	1.15
9	ELEC. CHARACTERISTICS	V. PH CY	FULL LOAD RPM	1776
10	SYNCH. SPEED, RPM		FULL LOAD AMP	438
11	HORSEPOWER		LOCKED ROTOR AMP	2487
12	SERVICE FACTOR		STARTING TORQUE, % P.L.	130%
13	ENCLOSURE		PULL-OUT TORQUE, % P.L.	240%
14	INSULATION CLASS		EFF. FULL LOAD, %	94.4%
15	INSULATION TREATMENT		EFF. 3/4 LOAD, %	94.7%
16	AMBIENT TEMP. °C		EFF. 1/2 LOAD, %	94.4%
17	STATOR TEMP RISE °C		P.F. FULL LOAD, %	90.6%
18	BEARING TYPE		P.F. 3/4 LOAD, %	90.0%
19	BEARING TEMP RELAY		P.F. 1/2 LOAD, %	86.3%
20	BEARING THERMOCOUPLE		P.F. LOCKED ROTOR	29.7
21	HALF COUPL. OR SHEAVE MTD. BY		SPACE MTRS., TOTAL WATTS	
22	ROTATION*		RADIAL BEARING TYPE	
23	WK? OF DRIVEN EQUIP.	48 lb - ft. 2	THRUST BEARING TYPE	
24	PRQTY. TORQ. OR VM. EQUIP.	10.6 lb ft	BEARING SERVICE - MR.	
25	OVERSIZE COND. BOX		NORMAL BRG. OPER. TEMP. °C	60°C
26	COND. BOX LOCATION*		NET WEIGHT - LB.	3400
27	SPACE HEATERS, VOLTAGE, PHASE		OIL COOL. SYS. REQ'D	
28	SPLIT END BELLS		BRG. OIL PRESS. RANGE, PSI	
29	TERMINAL LUGS, TYPE		BRG. OIL REQ'D EA. BRG. GPM	
30	STATOR HIGH TEMP DEVICE		NAME PLATE CODE LETTER	E
31	ADJUSTABLE SLIDE RAILS		PERMISSIBLE STARTS PER HR: *	
32	SOLEPLATES		* MOTOR AT AMBIENT TEMP	2 (two)
33	PROJECT ELEV., FT.		* MOTOR AT RATED TOTAL TEMP	1 (one)
34	SHAFT (HOLLOW, SOLID)		TYPE SEALED INSUL. SYS.	WPI
35	COUPLING (SELF-RELEASE)		DESCRIPTION OF INSUL. SYS.	Class B Thermalast
36	SOLID, NONREVERSING			Epoxy
37	ADJUSTABLE, FLEXIBLE			
38	VERT. MAX DOWNTHRUST			
39	VERT. MAX UP THRUST		* Subsequent Starts:	
40	VERT. MIN UP THRUST		Motor running - 15 minute apart	
41	VERT. MIN DOWNTHRUST		Motor standing - 45 minute apart	
42	(WITH MOTOR RUNNING)			
43	SIDE THRUST			
44	MAX REVERSE SPEED			Calculations based on 400V
45	DRAIN PLUG AND VENT			
46	AIR INTAKE SCREENS			
47				
48				
49				
50				
51				
52	REMARKS:		REMARKS:	
53	ALL PERFORMANCE DATA BASED ON NORMAL RATED		ALL PERFORMANCE DATA BASED ON NORMAL RATED	
54	VOLTAGE AND FREQUENCY		VOLTAGE AND FREQUENCY	
55	ITEMS 24-24 APPLY TO VERTICAL MOTORS ONLY		INDICATE IF DATA IS ESTIMATED	calculated data
56	I-R Factory order No. 037-30650			
57	Items 10 & 11			
58				Ingersoll-Rand order No. C-592453
59				Westinghouse Factory No. NY-35820
60	* VIEWED FROM END OPPOSITE COUPLING END			

Calc. No. IP3-CALC-ED-00207

Rev. 8

Appendix A.9

Sheet 1 of 1

Calc. No. IP3-CALC-ED-00207

Rev. 8

Appendix A.10 sheet 1 of 1

INDUCTION MOTOR DATA SHEET
WESTINGHOUSE FORM 3400Z

PURCHASER'S REQUIREMENTS		DATA FURNISHED BY SELLER	
1 PROJECT	WESTINGHOUSE ELECTRIC	S.O. NO.	205
2 FURNISHED BY	Pacific Pump	DATE	4/5/63 BY R. A. Spier
3 MARK OR ITEM NO.	INT STAPSI 1, 2, 3		
4 SERVICE	Safety Injection	MAKE	Westinghouse
5 TYPE	Squirrel Cage	FRAME NO.	509 DS
6 NO. OF PHASES	3	HORSEPOWER	400 HP
7 MOUNTING		EFFICIENCY FACTOR	1.15
8 ELEC. CHARACTERISTICS	440 V. 3 PH 60 CY	FULL LOAD RPM	3570
9 SYNCH. SPEED, RPM		FULL LOAD AMP	458
10 HORSEPOWER		LOCKED ROTOR AMP	2530
11 SERVICE FACTOR		STARTING TORQUE, % P.L.	108%
12 ENCLOSURE	IP-1	PULL-OUT TORQUE, % P.L.	219% MAX. TORQUE
13 INSULATION CLASS		EFF.-FULL LOAD, %	94.4
14 INSULATION TREATMENT		EFF.-1/2 LOAD, %	94.3
15 AMBIENT TEMP. °C		EFF.-1/3 LOAD, %	93.5
16 STATOR TEMP RISE °C	60°C	P.F.-FULL LOAD, %	91.0
17 BEARING TYPE		P.F.-1/2 LOAD, %	90.8
18 BEARING TEMP RELAY		P.F.-1/3 LOAD, %	88.0
19 BEARING THERMOCOUPLE		P.F.-LOCKED ROTOR	2.37
20 HALF COUPL. OR SNEAVE MTD. BY		SPACE HTES., TOTAL WATTS	200
21 ROTATION °	CCW	RADIAL BEARING TYPE	
22 WK 3 OF DRIVEN EQUIP.	13.0 0/8cc ²	THRUST BEARING TYPE	
23 SHFTY. TORQ. DRIVEN EQUIP.	59 0/8cc ²	BEARING SERVICE - HR.	
24 OVERSIZE COND. BOX		NORMAL DRG. OPER. TEMP. °C	
25 COND. BOX LOCATION		NET WEIGHT - LB.	
26 SPACE HEATERS, VOLTAGE, PHASE	440V	DR. COOL. STYL REQ'D	
27 SPLIT END PULLS		DRG. OR PRES. RANGE, PH	
28 TERMINAL LUGS, TYPE		DRG. OR REQ'D EA. DRG. QPN	
29 STATOR HIGH TEMP DEVICE		NAME PLATE CODE LETTER	
30 ADJUSTABLE SLIDE RAILS		PERMISSIBLE STARTS PER HR.	
31 BOLTPlates		MOTOR AT AMBIENT TEMP	
32 PROJECT ELEV. - FT.		MOTOR AT RATED TOTAL TEMP	
33 SHAFT HOLLOW, SOLID		TYPE SEALED INHA. STL	
34 COIL-LEGS SELF-RELEASE		DESCRIPTION OF INHA. STL	Thermobaric Epoxy
35 SOLID, NONREVERSING		Full Load Torque:	588 0/8cc ²
36 ADJUSTABLE, FLEXIBLE		Motor Shaft Inertia:	315 0/8cc ²
37 VERT. MAX DOWNTHRUST			
38 VERT. MAX UP THRUST		Cold Motor:	Two consecutive starts
39 VERT. MIN UP THRUST			
40 VERT. MIN DOWNTHRUST			
41 (WITH MOTOR RUNNING)		Motor at operating temp:	one consecutive start
42 SIDE THRUST			
43 MAX REVERSE SPEED			
44 DRAIN PLUG AND VENT		Time between starts for normal slowdown and motor running:	15 min.
45 AIR INTAKE SCREENS			
46			
47			
48			
49			
50			
51			
52			
53			
54			
55			
56			
57			
58			
59			
60			
61			
62			
63			
64			
65			
66			
67			
68			
69			
70			
71			
72			
73			
74			
75			
76			
77			
78			
79			
80			
81			
82			
83			
84			
85			
86			
87			
88			
89			
90			
91			
92			
93			
94			
95			
96			
97			
98			
99			
100			

* VIEWED FROM END OPPOSITE COUPLING END

UNITED ENGINEERS & CONSTRUCTORS INC

SPECIFICATION FOR PUMPS
SERVICE WATER PUMPS

CLIENT <i>WESTINGHOUSE - CON ED</i>			JOB NO. <i>9321.05</i>		
PLANT LOCATION <i>INDIAN POINT - UNIT No. 3</i>			DATE <i>1 MARCH 68</i>		
INQUIRY NO. <i>WEC 46-9321-05-238-8</i>			EQUIP. NO. <i>31 to 36</i>		
TYPE	ITEM NO.	NO. REQ'D.	SERVICE		CATALOG NO.
<i>VERTICAL TURBINE</i>	<i>1</i>	<i>6</i>	<i>INTERMITTENT</i>	<i>CONTINUOUS</i>	<i>LAYNE-BOWLER</i> <i>350 5N20K2</i>
NO. STAGES <i>2</i>	RPM <i>1770</i>	TYPE IMPELLER <i>ENCLOSED</i>			
HP <i>350 (MAX)</i>	BHP <i>335</i>	EFFICIENCY % <i>87</i>			
SUCTION SIZE <i>20-7/8</i> INCHES	FLANGE FACING <i>BELL MOUTH</i>	NOZZLE SERIES <i>--</i>	LBS		
DISCHARGE SIZE <i>14</i> INCHES	FLANGE FACING <i>FLAT FACE</i>	NOZZLE SERIES <i>150</i>	LBS		
TYPE MOTOR <i>V55</i>	MOTOR MFG. <i>WESTINGHOUSE</i>		MOTOR FRAME <i>509 UPH</i>		
OPERATING CONDITIONS					
FLUID PUMPED <i>RIVER WATER</i>	PUMPING TEMP. <i>35 to 85</i>		°F		
SP. GR. @ 60°F. <i>--</i>	SP. GR. @ P.T. °F. <i>--</i>		<i>6.6 to 7.6</i>		
VISCOSITY @ P.T. <i>--</i>	PERCENT SOLIDS <i>--</i>				
VAPOR PRESSURE <i>--</i>	ROTATION (FACING COUPLING END)				
NORMAL CAPACITY <i>--</i> GPM	MAXIMUM CAPACITY <i>--</i> GPM	DESIGN CAPACITY <i>5000</i>	GPM		
DISCHARGE HEAD <i>--</i> FT.	SUCTION HEAD <i>16 FT. MIN. SUBMERGENCE</i>		FT.		
TOTAL DYNAMIC HEAD - NORMAL <i>--</i> FT.	TOTAL DYNAMIC HEAD - DESIGN <i>220</i> FT.				
NET POSITIVE SUCTION HEAD AVAILABLE <i>REQUIRED 28 in H₂O MIN. SUBMERGENCE</i>	FT.				
MOTOR HP <i>350</i>	VOLTS <i>440</i>	PHASE <i>3</i>	CYCLES <i>60</i>		
MATERIALS & CONSTRUCTION					
CASING MATERIAL <i>A 48-60, CLASS BOWLS</i>	CASING SPLIT <i>--</i>				
IMPELLER MATERIAL <i>BRONZE B145-61-4A</i>	IMPELLER SIZE <i>12-15/16 in.</i>				
SHAFT MATERIAL <i>A 276-67 TYPE 41055 (LINE)</i> <i>A 276-63 TYPE 41635 (PUMP)</i>	SHAFT SIZE <i>PUMP-2-7/16 in, LINE 1-15/16 in</i>				
TYPE PACKING <i>JOHN CRANE 5811</i>	NO. PACKING RINGS <i>--</i>				
TYPE COUPLING <i>--</i>	COUPLING GUARD <i>--</i>				
BASEPLATE MATERIAL <i>STEEL-ASTM A9</i>					
TOTAL WEIGHT (PUMP, BASE & MOTOR) <i>9400 lbs</i>	Calc. No. <i>IP3-CALC-ED-00207</i>				
MECHANICAL SEALS <i>--</i>	Rev. <i>8</i>				
<i>COLUMN PIPE A 53 GRB SEAMLESS</i>	Appendix <i>A.11</i>				
	Sheet <i>2 of 2</i>				
<i>PUMP DWG. D-21369 (FP-9321-05-2070)</i>					

NEW YORK POWER AUTHORITY
INDIAN POINT 3 NUCLEAR POWER PLANT
REPORT NO. : IP3-ANAL-ED-01636

<u>REVISION</u>	<u>DATE</u>
1	9-24-99

ADJUSTING ADEQUATE AUXILIARY FEEDWATER FLOW
WITHOUT AUX FEED PUMP TRIP ON
OVERLOAD

FI-1200, - 1201, - 1202, - 1203

FCV-406A, - 406B, - 406C, -406D

PREPARED BY:

S. D'Auria 9/23/99
S. D'AURIA / Date

REVIEWED BY:

A. VAI 9/23/99
A. VAI / Date

APPROVED BY:

S. Petrosi 9/24/99
S. PETROSI / Date

CALC No. IP3-CALC-ED-00207 REV 8
APPENDIX A.7 1 of 1

IP3-ANAL-01636, Rev.1
Adjusting Adequate Auxiliary Feedwater Flow
Without Aux Feedpump Trip on Overload

TABLE OF CONTENTS

I	PREFACE / INTRODUCTION	Page 3
II	DISCUSSION	Page 3
III	EVALUATION	Page 5
IV	CONCLUSIONS	Page 9
V	REFERENCES	Page 11
VI	ATTACHMENTS	Page 11

IP3-ANAL-01636, Rev.1
Adjusting Adequate Auxiliary Feedwater Flow
Without Aux Feedpump Trip on Overload

I. PREFACE / INTRODUCTION

Revision 0 of this analysis evaluated the Auxiliary Feedwater Flow Indication loop accuracy to ensure adequate flow without pump runout motor trip during the EOP postulated scenarios. These scenarios required a minimum of 365 gpm flow rate from 1 Aux Feedwater pump to 2 Steam Generators (to support an analytical limit of not less than 340 gpm).

Revision 1, presented herein, re-evaluates the #31 and #33 Aux Boiler Feed Pump (ABFP) motor characteristics. This is necessary to confirm that the new minimum AFW flow analytical limit requirement of 345 gpm (see reference 4.) can be supported while at the same time maintaining the existing 10 gpm wide acceptance band in Surveillance Test 3PT-R007A (reference 5.) which sets the cutback controllers PC-406A and PC-406B. Additionally, this revision will re-confirm that the EOP Setpoint SP1-S.02 (minimum of 365 gpm as read on Control Room Aux Feedwater flow indicators) provides confirmation of delivering not less than the new Aux Feed flow analytical limit of 345 gpm.

This re-evaluation specifically addresses the fact that ABFP #31 has been fitted with a Reliance motor as replacement for the previous Westinghouse motor.

The equipment and components within the scope of this evaluation are QA Category I.

II. DISCUSSION

In support of performing 3PT-R007A during R09, Calculation IP3-CALC-AFW-01805 Rev 0 was prepared and calculation IP3-CALC-AFW-1801 was revised to Rev 1 to estimate loop uncertainties for the AFW cutback control loops and the AFW flow indicator loops respectively. AFW flow requirements are dictated by the Loss of Normal Feedwater (LONF) event which requires sufficient secondary side heat sink availability. That heat sink is provided by the AFW pumps drawing water from the Condensate Storage Tank (CST). The Westinghouse analyses of record prior to R09 dictated the need for a minimum of 340 gpm AFW flow from one ABFP to two Steam Generators. AFW indication uncertainty was estimated at +/-20 gpm per AFW pump and thus the EOP setpoint for operator confirmation of minimum AFW flow of 365 gpm was determined to be sufficient with available margin.

IP3-ANAL-01636, Rev.1
Adjusting Adequate Auxiliary Feedwater Flow
Without Aux Feedpump Trip on Overload

In addition to the concern for delivering sufficient secondary side cooling, a second issue required analysis, that being the confirmation of adequate pump runout protection thereby not challenging the ABFP motor amptectors. In this regard loop uncertainty for the runout protection control loops was estimated at +/- 30 gpm. This uncertainty required that the lower limit for setting the cutback controllers be equal to or greater than 370 gpm thereby protecting the analytical limit of 340 gpm and maximizing the probability that upon initiation of pumping the indicated flow would be at least the required 365 gpm. However, the cutback controller setting could not be allowed to be arbitrarily high due to the concern surrounding challenge to the motor's overcurrent protection (amptectors). It is unacceptable to allow a condition whereby a significant probability exists that the pump motor may be tripped, in this case by overcurrent.

To ensure that this significant probability did not exist, this analysis (revision 0 version) was prepared to determine the value of ABFP flow that represented the lowest value that could conceivably cause an amptector trip of the ABFP motors. A flow of 410 gpm was calculated as the maximum flow that could be allowed while maintaining the condition of insignificant probability of pump/motor trip on amptector sensed overcurrent. (Note: The 410 gpm value was based on the ABFP #31 motor, which was the original Westinghouse supplied motor. ABFP #33 motor had been replaced with a Reliance motor which has better capacity characteristics, but since this motor was not the limiting case, the #31 motor was used for the analysis.)

With an upper limit of 410 gpm having been established for acceptable maximum pump flow, we were then able to establish the upper end of the cutback controller setting band which became 380 gpm ($410 \text{ gpm} - 30 \text{ gpm} = 380 \text{ gpm}$). The combination of this maximum flow and the previously described minimum flow yielded the present 10 gpm wide controller setting acceptance band. This test window of 10 gpm is considered the narrowest target that can be practically pursued in executing the 3PT - R007A surveillance procedure

For plant restart from R10, however, a number of conditions have changed relative to the requirements for AFW and the configuration of the AFW system:

- 1) the minimum required AFW flow rate for the LONF event has changed from the original 340 gpm to 343 gpm. Accounting for an additional 1 gpm of Blowdown Sampling flow per steam generator, we have a total required minimum makeup rate of 345 gpm (see NSE 96-3-224-AFW Rev. 3 for establishment of this new analytical limit).

IP3-ANAL-01636, Rev.1
Adjusting Adequate Auxiliary Feedwater Flow
Without Aux Feedpump Trip on Overload

- 2) the #31 ABFP has had its motor changed out during R10; the replacement motor (also Reliance) is almost identical in characteristics to the existing motor on ABFP #33.
- 3) the long term amptector settings for the 2 pump motors are now set at the same 660 amp nominal value.
- 4) EDG bus loading calculations have continued to evolve from R09 to the present. It is required that any new estimated load conditions (e.g. increases in pump flows) be confirmed as acceptable relative to diesel loading margins.

Given that the analytical limit for minimum AFW delivery has changed from 340 to 345 gpm as described in 1) above, it becomes necessary to investigate the possibility of increasing the allowable ABFP flow by 5 gpm to maintain the existing 10 gpm setting window in 3PT-R007A (i.e. confirm that a cutback controller setting window of between 375 and 385 gpm is acceptable).

The evaluation of motor loading and amptector action will therefore be focused on the potential for a new upper flow limit for each ABFP of 415 gpm (i.e. 385 gpm + 30 gpm cutback uncertainty = 415 gpm). Also, AFW flow indication uncertainties will also be investigated to confirm that we can still utilize the existing EOP minimum AFW flow of 365 gpm from one AFW pump and subsequently 730 gpm from two AFW pumps.

III EVALUATION

This evaluation is performed by investigating the following technical conditions:

- 1) AFW Pump Motor maximum electrical loading / current draw given worst case conditions of pump flow and motor terminal voltage (bus voltage corrected for cable voltage drop)
- 2) Amptector trip characteristics at nominal settings
- 3) Cutback Controller system uncertainty
- 4) EDG bus loading conditions and existing margin
- 5) Analytical Limit for AFW Flow in LONF event
- 6) AFW flow indication system uncertainty

IP3-ANAL-01636, Rev.1
Adjusting Adequate Auxiliary Feedwater Flow
Without Aux Feedpump Trip on Overload

Items 1) thru 5) above will be evaluated to establish the new Cutback Controller acceptable setting band. Items 5) and 6) will be evaluated to assess the continued acceptability of the existing EOP setpoints relative to AFW requirements.

1) AFW Pump Motor

In this application, the pump is considered driven at constant speed for the purposes of flow determination versus horsepower, the motor slip speed is considered negligible. Therefore, from the vendor pump curve, the required horsepower is: 400 gpm - 466 HP (rated), 410 gpm - 470 HP (intermediary), 415 gpm - 472 HP (final). An increase of 6.23 HP X 0.746 kW/HP / 0.953 eff. puts an additional 4.87 kW load on associated EDG.

The motor efficiencies, power factors @ 472 HP output are as follows:

Motor	31	33
eff	0.945	0.953
pf	0.87	0.89

Using the formula for kva = ((HP X 0.746) / (pf X eff))

31 AFWP kva @ 472 HP = 426 kva or 563.2 amps @ 440 volts

33 AFWP kva @ 472 HP = 414 kva or 545.9 amps @ 440 volts

31 AFWP kva @ 472 HP = 426 kva or 567.0 amps @ 437 volts

33 AFWP kva @ 472 HP = 414 kva or 554.7 amps @ 433 volts

From the current EDS model calculations, the calculated lowest 480V bus voltages on BUS 3A (31ABFP) and BUS 6A (33ABFP) with offsite power available and the 138kV grid @ 136kV during an accident scenario that has the AFWP's running are: BUS 3A @ 473 volts and Bus 6A @ 458 volts. With the voltage drop from the 480V buses to their respected ABFP motors, the motor terminal voltages are above their nameplate rating of 440 V. Thus the calculated amperage draws listed above are greater than the anticipated current draw for this scenario. For scenarios that involve loss of offsite power, the 480 V buses are powered from their respected EDG's that will also maintain voltage at the ABFP motors above their nameplate ratings.

IP3-ANAL-01636, Rev.1
Adjusting Adequate Auxiliary Feedwater Flow
Without Aux Feedpump Trip on Overload

Using the design basis minimum 480V bus degraded grid voltage of 414 volts and subtract the voltage drops from the bus to the motors of (31 ABFP – 7 volts, 33 AFWP – 11 volts) yields motor terminal voltages of 407 volts @ 31 ABFP and 403 volts @ 33 ABFP. These motor terminal voltages are not probable based on the EDS model results. At these extreme low motor terminal voltages the motor currents would be 608.9 amps for 31 ABFP and 596 amps for 33 ABFP. At these extreme conditions, the amptectors may trip. This is not considered a feasible voltage scenario. It is addressed here since the 480V bus degraded grid design low voltage is 414 volts. The DGV relays will trip the 480V bus supply breakers at this point and start the EDG's.

Each of the 480V buses is equipped with a low voltage alarm. These alarms actuate at 448.8 volts decreasing. ARP-5 directs the operators to manual trip the 480V bus supply breakers if there is a SI and voltage cannot be maintained above 446 volts. Starting with 446 volts at the bus, allowing 2 volts for alarm relay tolerance and subtracting the voltage drops from the bus to the motors yields motor terminal voltages of 437 volts at 31 ABFP and 433 volts at 33 ABFP. At these voltages the motor current is 567.0 amps for 31 ABFP and 554.7 amps for 33 ABFP. Both of these values are below the minimum amptector trip point (See 2) below).

Environmental Consideration:

The motor has a design life of 40 years +4 year margin at 460 HP. The only challenge that needs to be considered in this evaluation is thermal degradation of winding insulation due to increased temperature rise during operation above 460 HP. Seismic, radiation and aging effects were not applicable to this evaluation. Operation at elevated temperatures is comparable to operating at overload. After review of the Con Edison records of an essentially identical Reliance motor as installed at IP3, it is judged that any possible short run time at 472 HP will have an immeasurable effect on the qualification of these Reliance motors. Considered in this review were the credit taken for periods at full load, periods at elevated temperature, and design life versus remaining license duration. The service time margin for this motor is in the order of 25 years.

It is concluded that the effect of any short term operation of this motor at 472 HP can be neglected.

IP3-ANAL-01636, Rev.1
Adjusting Adequate Auxiliary Feedwater Flow
Without Aux Feedpump Trip on Overload

2) Amptector

The AFWP 480V supply breakers are equipped with amptector trip units. Each breaker has a long time trip set at 1.1 times sensor or 660 amps. These amptectors have a manufacturers specified tolerance of +/- 10%. Thus the trip unit could trip as low as $660 - (0.1 \times 660) = 594$ amps. Thus the two ABFP motors will not trip on overload at a pump output of 415 gpm. Additionally, at the minimum amptector trip of 594 amps, the amptector will not trip until the current is (slightly) greater than 594 amps for greater than 600 seconds.

3) Cutback Controller

NYPA calculation IP3-CALC-AFW-1805 Rev 0 established the uncertainty in the action of the ABFP Cutback Control system which limits AFW flow to ensure prevention of pump runout while at the same time ensuring that the ABFP accident mitigation flow rates are achieved. This runout protection is necessary to a) ensure that the ABFP does not assume an operating point on the pump curve that could overload the EDGs in the event of a loss of offsite power and to b) prevent the ABFP motor from tripping on overcurrent (amptector action). The estimated uncertainty in this calculation is documented as +/- 30 gpm. This uncertainty magnitude imposes the condition that the controller Proportional Band (PB) setting be not less than 33% due to the amplifying effects of this setting (Gain goes up as PB goes down) on pump discharge pressure uncertainties (this pressure being used as the controlling parameter for the cutback protection). An additional high side PB limit of not greater than 50% will now also be imposed to limit the effect of Proportional Offset which is inherent in the controller action and increases with increasing PB percentage.

4) EDG Bus Loading

NYPA calculation IP3-CALC-ED-207, Rev 6 establishes and maintains the sequence of loading and the magnitudes of the safeguards loads that the EDGs must carry during conditions of Loss of Offsite Power (LOOP). The loading margins that exist on these emergency busses are configuration controlled by this calculation. Based on 1) above, it has been determined that the ABFP electrical loading condition results in an increase as follows. The increase kW load for pump 31 motor bus is 4.87 kW. For pump 33, this load increase is offset by the more efficient motor, Westinghouse, efficiency 0.939, replaced by Reliance, efficiency 0.953 – a decrease of 3.52 kW. This is a net increase kW load for pump 33 motor bus of 1.35 kW. Calculation IP3-CALC-ED-207, Rev 6 shows that there is adequate margin for the EDGs to carry the ABFPs at the higher flow rate of 415 gpm.

*IP3-ANAL-01636, Rev.1
Adjusting Adequate Auxiliary Feedwater Flow
Without Aux Feedpump Trip on Overload*

5) Analytical Limit for AFW Flow

NSE 96-3-224-AFW addresses the NYPA accepted re-analysis of minimum required AFW flow for the LONF event performed by Westinghouse. A new total flow from one ABFP of 343 gpm is documented in this NSE. Additionally, the continuous flow through the Steam Generator Blowdown system is identified and conservatively estimated at 1 gpm per SG thereby increasing the required AFW flow from 343 to 345 gpm. This 345 gpm value represents the lower flow limit to which instrument and control system uncertainties are added for setting the lower end of the cutback controller range and establishing required minimum indicated flow values for EOP support.

6) AFW Flow Indication

NYPA calculation IP3-CALC-AFW-1801 Rev 1 established the uncertainty inherent in reading 2 AFW flow indicators to estimate a total flow from one AFW pump. The total uncertainty in the combined reading is documented as a worst case variation of +/- 20 gpm. This value was the result of analyzing uncertainty in differential pressure as it translates to uncertainty in gpm using the previous 340 gpm analytical limit and 410 gpm pump flow limit. This condition of the uncertainty analysis is important to consider because uncertainty in terms of gpm becomes less as the flowing conditions of interest increase (given the same percentage error in DP). This occurs due to the square root relationship between the delta-p generated across the orifice plate by the system flow. This being the case, the use of the +/- 20 gpm flow uncertainty at the 5 gpm higher conditions is conservative. Even without considering this conservatism, the existing EOP setpoints of 365 gpm (setpoint ID# SP1-S.02) and 730 gpm (setpoint ID# SP1-S.06) remain valid.

IV CONCLUSIONS

As stated in the EVALUATION section of this analysis, evaluation items 1 thru 5 will be considered together in order to arrive at a new acceptable setting band for the ABFP Cutback Controller settings:

If the ABFPs operate at a flow of 415 gpm, evaluations from 1) and 4) show that with Reliance motors driving both pumps, the conditions impose an increase of 4.87 kW on Bus 2A/3A and an increase of 1.35 kW on Bus 6A. This yields predicted bus loadings for the new 415 gpm flow of 1558.1 kW on Bus 2A/3A (ABFP#31) and 1481.1 kW on Bus 6A (ABFP#33). Diesel maximum capacity is documented as 1750 kW.

IP3-ANAL-01636, Rev.1
Adjusting Adequate Auxiliary Feedwater Flow
Without Aux Feedpump Trip on Overload

Therefore 415 gpm is an acceptable flow for the ABFPs relative to their additional electrical load imposed on the safeguards busses.

From the evaluation in item 2) we see that given an amptector nominal setting of 660 amps (i.e. 1.1 X Sensor) we have a minimum possible amptector trip current of 594 amps. Given that evaluation item 1) established that ABFP #31 motor draws 567 amps at 415 gpm which is the higher current of the 2 motors at the lowest expected voltage; we have no credible condition for amptector trip of either pump motor. Therefore 415 gpm is an acceptable flow for the ABFPs relative to the potential for loss of a pump due to electrical overload (motor amptector trip).

From the item 3) evaluation we get a cutback control system uncertainty of +/- 30 gpm. To maximize the probability that this control system will protect the 415 gpm ABFP flow limit from being exceeded, we must establish an upper limit for the cutback controller setting band of 385 gpm (i.e. 415 gpm - 30 gpm = 385 gpm).

From the item 5) evaluation we get an Analytical Limit condition for minimum AFW flow of 345 gpm. To maximize the probability that the cutback control system will ensure the 345 gpm AFW flow minimum, we must establish a lower limit for the control system setting band of 375 gpm (345 gpm + 30 gpm = 375 gpm).

Given the above, the new Cutback Controller setting band is herein defined as:

$$\geq 375 \text{ gpm to } \leq 385 \text{ gpm}$$

As stated in the EVALUATION section of this analysis, evaluation items 5) and 6) will be considered together in order to assess the continued acceptability of the existing EOP setpoints relative to AFW requirements:

As stated above, the item 5) evaluation establishes an Analytical Limit condition for minimum AFW flow of 345 gpm. From the item 6) evaluation we get an AFW flow indication uncertainty for delivery of AFW to 2 Steam Generators (from 1 ABFP) of +/- 20 gpm. Therefore to maximize the probability that the minimum AFW flow of 345 gpm is correctly being confirmed (by operator observation of the AFW flow indicators), we must establish a minimum observed flow of 365 gpm (i.e. 345 gpm + 20 gpm = 365 gpm).

IP3-ANAL-01636, Rev.1
Adjusting Adequate Auxiliary Feedwater Flow
Without Aux Feedpump Trip on Overload

Given the above, we therefore have confirmed that the existing EOP setpoint SP1-S.02 of not less than 365 gpm is still acceptable. It then follows directly the the EOP setpoint SP1-S.06 of not less than 730 gpm is also still acceptable.

Note: All resulting GPM values in this analysis are converted to equivalent mVDC values for test and calibration via the conversion method presented in calculation "-AFW-1801" (reference 1.), Section 9.0.

V REFERENCES

1. NYPA Calculation # IP3-CALC-AFW-1801 Rev 1 : " Flow/Pressure Uncertainty for AFW Pump Cut-Back Control (F-1200, F-1201, F-1202 & F-1203) Indication"
2. NYPA Calculation # IP3-CALC-AFW-1805 Rev 0 : "AFW Pump Cutback – Pressure Instrument Loop Uncertainty for PC-406A & PC-406B"
3. NYPA Calculation # IP3-CALC-ED-207 Rev 6 : "480V Bus 2A, 3A, 5A & 6A and EDGs 31, 32, 33 Accident Loading"
4. NSE 96-3-224-AFW Rev 3 : "Auxiliary Feedwater System Purge Volume and Temperature Effects"
5. Surveillance Procedure 3PT-R007A : "31 & 33 Auxiliary Boiler Feed Water Pumps Full Flow Test"
6. NYPA Calculation # IP3-CALC-EL-01969, Rev 2: Load Flow Study
7. NYPA Calculation # IP3-CALC-EL-01967, Cable Impedance Calculation
8. Reliance Electric Report of Test, S.N. VH883732 A2 (33 Motor)
9. Reliance Electric Report of Test, S.O. FNA 7704 (31 Motor)
10. IP3-ECAF-Bus3A-6 (31 Motor, old)
11. IP3-ECAF-Bus6A-11D (33 Motor)
12. IP3-ECAF-584 (31 Motor, new)

VI ATTACHMENTS


1. Aux Motor Driven Feed Pump Curve
2. Voltage Conversion Table – Flow (gpm) to Transmitter (mVdc)
3. Graph of Acceptable DVM Millivolt Values for Cutback Controllers PC-406A & B

INDIAN Point Unit 3

REV. 0

ATTACHMENT 1

Attachment 1 of Analysis
IP3-ANAL-ED-01636, Rev. 1



Attachment 1 of Analysis
IP3-ANAL-ED-01636, Rev. 1

Page 23 of 27
Section 9
REV. 0


Reviewed By: H. D. Conner
Approved By: [Signature]

Attachment 2 of Analysis
IP3-ANAL-ED-01636, Rev.1

AUXILIARY FEEDWATER FLOW (GPM) TO TRANSMITTER OUTPUT (mVdC)	
SCR S1-99-0008 ATTACHMENT 4.3 SHEET 3 of 4	
VOLTAGE CONVERSION TABLE	
GPM (VALUE)	MVDC (VALUE)
180	164.00
181	164.71
182	165.43
182.5	165.79
183	166.15
184	166.88
185	167.60
186	168.34
187	169.07
188	169.82
189	170.56
190	171.31
191	172.06
192	172.82
192.5	173.20
193	173.58
194	174.34
195	175.11
196	175.88
197	176.66
198	177.44
199	178.22
200	179.01
201	179.80
202	180.60
202.5	181.00
203	181.40
204	182.20
205	183.01

Graph of Acceptable DVM Millivolt Values for Cutback Controllers PC-406A & PC-406B (Limiting Value of 375 to 385 GPM)

SCR:51-99-0008 ATT. 4.3 SHY 4 of 4



Appendix A.12

Extrapolated Motor Power Factor and Efficiency

1. Objective

To extrapolate motor power factor and efficiency values based on motor data sheets and to determine the corresponding motor kW and Ampere values.

2. Solution Outline

- 2.1 Obtain brake horsepowers for selected 480V motor loads and the corresponding motor terminal voltage.
- 2.2 Obtain a minimum of two motor power factors at various motor loads (in horsepower) and a minimum of two motor efficiency values at various motor loads.
- 2.3 Use the following equations to determine the slopes (M) for the motor power factor and efficiency.

$$M\{PF\} = (PF2 - PF1) / (HP2 - HP1) \quad (1)$$

$$M\{EFF\} = (EFF2 - EFF1) / (HP2 - HP1) \quad (2)$$

Where:

M{PF} = Slope for motor power factor

M{EFF} = Slope for motor efficiency

PF = Power factor

EFF = Efficiency

HP = Horsepower

- 2.4 Use the following equations to extrapolate power factor and efficiency (See Note 1 below).

$$[CALC PF] = M\{PF\} * (BHP - HP1) + PF1 \quad (3)$$

$$[CALC EFF] = M\{EFF\} * (BHP - HP1) + EFF1 \quad (4)$$

Where:

[CALC PF] = Calculated motor power factor (extrapolated)

[CALC EFF] = Calculated motor efficiency (extrapolated)

M{PF} = Slope for motor power factor

M{EFF} = Slope for motor efficiency

PF = Power factor

EFF = Efficiency

HP = Horsepower

BHP = Brake Horsepower

Note 1. Where no manufacturer's data was obtained above motor rated load, power factor and efficiency are assumed the same as at 100% load. Calculating these parameters by extrapolation using data below 100% load would assume the same trend above 100% load (i.e., parameter values are increasing or decreasing with load). This may not be the case. Assuming the same values as at 100% load is considered reasonable as the difference in the results between the two methods is insignificant.

2.5 Use the following equations to determine the motor kW and Ampere values.

$$[\text{CALC KW}] = \text{BHP} * 0.746 / [\text{CALC EFF}] \quad (5)$$

$$[\text{CALC KVA}] = [\text{CALC KW}] / [\text{CALC PF}] \quad (6)$$

$$[\text{CALC AMP}] = [\text{CALC KVA}] * 1000 / ([\text{MTR VOLT}] * \text{SQRT}(3)) \quad (7)$$

Where:

[CALC KW] = Calculated KW

[CALC KVA] = Calculated kVA

[CALC AMP] = Calculated Ampere value

[CALC PF] = Calculated motor power factor (extrapolated)

[CALC EFF] = Calculated motor efficiency (extrapolated)

[MTR VOLT] = Motor terminal voltage in volts
SQRT(3) = Square root of 3

BHP = Brake Horsepower

3. Computation

The computation is shown in sheets 3 to 10 of this Appendix.

GENERAL EQUATIONS:

$$M\{PF\} = (PF2 - PF1) / (HP2 - HP1)$$

$$M\{EFF\} = (EFF2 - EFF1) / (HP2 - HP1)$$

$$[CALC PF] = M\{PF\} * (BHP - HP1) + PF1$$

$$[CALC EFF] = M\{EFF\} * (BHP - HP1) + EFF1$$

$$[CALC KW] = BHP * 0.746 / [CALC EFF]$$

$$[CALC KVA] = KW / [CALC PF]$$

$$[CALC AMP] = KVA * 1000 / ([MTR VOLT] * SQRT(3))$$

CONTAINMENT RECIRCULATING FAN

MOTOR DATA

BASE HP = 207.93 HP RATED VOLTAGE = 440 V

LOAD	HP	PF	EFF
100.00%	207.93	0.760	0.916
75.00%	156.03	0.695	0.920
50%	104.03	0.571	0.914

BETWEEN	M(PF)	M(EFF)
100% & 75%	0.00125241	-7.71E-05
75% & 50%	0.00238462	1.154E-04

CONTAINMENT RECIRCULATING FAN 31

BHP	CALC PF	CALC EFF	CALC KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
159.0	0.699	0.920	129.0	184.6	434.6	245.2	All 5 fans are running
159.0	0.699	0.920	129.0	184.6	434.6	245.2	4 fans are running
159.0	0.699	0.920	129.0	184.6	434.6	245.2	3 fans are running

CONTAINMENT RECIRCULATING FAN 32

BHP	CALC PF	CALC EFF	CALC KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
159.0	0.699	0.920	129.0	184.6	431.1	247.2	All 5 fans are running
159.0	0.699	0.920	129.0	184.6	431.1	247.2	4 fans are running
159.0	0.699	0.920	129.0	184.6	431.1	247.2	3 fans are running

CONTAINMENT RECIRCULATING FAN 33

BHP	CALC PF	CALC EFF	CALC KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
159.0	0.699	0.920	129.0	184.6	432.0	246.7	All 5 fans are running
159.0	0.699	0.920	129.0	184.6	432.0	246.7	4 fans are running
159.0	0.699	0.920	129.0	184.6	432.0	246.7	3 fans are running

CONTAINMENT RECIRCULATING FAN 34

BHP	CALC PF	CALC EFF	CALC KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
159.0	0.699	0.920	129.0	184.6	433.2	246.0	All 5 fans are running
159.0	0.699	0.920	129.0	184.6	433.2	246.0	4 fans are running
159.0	0.699	0.920	129.0	184.6	433.2	246.0	3 fans are running

CONTAINMENT RECIRCULATING FAN 35

BHP	CALC PF	CALC EFF	CALC KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
159.0	0.699	0.920	129.0	184.6	429.6	248.0	All 5 fans are running
159.0	0.699	0.920	129.0	184.6	429.6	248.0	4 fans are running
159.0	0.699	0.920	129.0	184.6	429.6	248.0	3 fans are running

COMPONENT COOLING WATER PUMP

MOTOR DATA

BASE HP = 250 HP RATED VOLTAGE = 460 V

LOAD	HP	PF	EFF
100.00%	250.0	0.891	0.934
75.00%	187.5	0.890	0.937
50%	125.0	0.857	0.933

BETWEEN	M(PF)	M(EFF)
100% & 75%	1.600E-05	-4.80E-05
75% & 50%	5.280E-04	6.400E-05

COMPONENT COOLING WATER PUMP 31

BHP	CALC PF	CALC EFF	CALC KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
212	0.890	0.936	169.0	189.8	437.4	250.5	
248	0.891	0.934	198.1	222.3	437.4	293.4	USED FULL LOAD PF & EFF
275	0.891	0.934	219.6	246.5	437.4	325.4	USED FULL LOAD PF & EFF

COMPONENT COOLING WATER PUMP 32

BHP	CALC PF	CALC EFF	CALC KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
212	0.890	0.936	169.0	189.8	436.0	251.3	
248	0.891	0.934	198.1	222.3	436.0	294.4	USED FULL LOAD PF & EFF
275	0.891	0.934	219.6	246.5	436.0	326.4	USED FULL LOAD PF & EFF

COMPONENT COOLING WATER PUMP 33

BHP	CALC PF	CALC EFF	CALC KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
212	0.890	0.936	169.0	189.8	436.3	251.2	
248	0.891	0.934	198.1	222.3	436.3	294.2	USED FULL LOAD PF & EFF
275	0.891	0.934	219.6	246.5	436.3	326.2	USED FULL LOAD PF & EFF

SAFETY INJECTION PUMP

MOTOR DATA

BASE HP = 400 HP RATED VOLTAGE = 440 V

LOAD	HP	PF	EFF
100.00%	400	0.910	0.944
75.00%	300	0.908	0.943
50%	200	0.880	0.935

BETWEEN	M(PF)	M(EFF)
100% & 75%	2.000E-05	1.000E-05
75% & 50%	2.800E-04	8.000E-05

SAFETY INJECTION PUMP 31

BHP	CALC PF	CALC EFF	CALC KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
403	0.910	0.944	318.5	350.0	439.4	459.8	USED FULL LOAD PF & EFF
414	0.910	0.944	327.2	359.5	439.4	472.4	USED FULL LOAD PF & EFF

SAFETY INJECTION PUMP 32

BHP	CALC PF	CALC EFF	CALC KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
403	0.910	0.944	318.5	350.0	438.6	460.7	USED FULL LOAD PF & EFF
414	0.910	0.944	327.1	359.4	438.6	473.0	USED FULL LOAD PF & EFF

SAFETY INJECTION PUMP 33

BHP	CALC PF	CALC EFF	CALC KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
403	0.910	0.944	318.5	350.0	438.2	461.1	USED FULL LOAD PF & EFF
414	0.910	0.944	327.2	359.5	438.2	473.7	USED FULL LOAD PF & EFF

SERVICE WATER PUMP

MOTOR DATA

BASE HP = 350 HP RATED VOLTAGE = 440 V

LOAD	HP	PF	EFF	BETWEEN	M(PF)	M(EFF)
100.00%	350	0.875	0.930			
75.00%	262.5	0.860	0.928	100% & 75%	1.714E-04	2.286E-05

SERVICE WATER PUMP 31

BHP	CALC PF	CALC EFF	CALC KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
350	0.875	0.930	280.8	320.9	431.0	429.8	PF BASED ON EDG STUDY

SERVICE WATER PUMP 32

BHP	CALC PF	CALC EFF	CALC KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
350	0.875	0.930	280.8	320.9	431.8	429.0	PF BASED ON EDG STUDY

SERVICE WATER PUMP 33

BHP	CALC PF	CALC EFF	CALC KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
350	0.875	0.930	280.8	320.9	431.0	429.8	PF BASED ON EDG STUDY

SERVICE WATER PUMP 34

BHP	CALC PF	CALC EFF	CALC KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
350	0.875	0.930	280.8	320.9	431.0	429.8	PF BASED ON EDG STUDY

SERVICE WATER PUMP 35

BHP	CALC PF	CALC EFF	CALC KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
350	0.875	0.930	280.8	320.9	431.8	429.0	PF BASED ON EDG STUDY

SERVICE WATER PUMP 36

BHP	CALC PF	CALC EFF	CALC KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
350	0.875	0.930	280.8	320.9	431.0	429.8	PF BASED ON EDG STUDY

RESIDUAL HEAT REMOVAL PUMP

MOTOR DATA

BASE HP = 400 HP RATED VOLTAGE = 460 V

LOAD	HP	PF	EFF
100.00%	400	0.906	0.944
75.00%	300	0.900	0.947
50%	200	0.863	0.944

BETWEEN	M(PF)	M(EFF)
100% & 75%	6.000E-05	-3.00E-05
75% & 50%	3.700E-04	3.000E-05

RESIDUAL HEAT REMOVAL PUMP 31

BHP	CALC PF	CALC EFF	CALC KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
365	0.904	0.945	288.1	318.8	438.5	419.7	
400	0.906	0.944	316.1	348.9	438.5	459.4	USED FULL LOAD PF & EFF

RESIDUAL HEAT REMOVAL PUMP 32

BHP	CALC PF	CALC EFF	CALC KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
365	0.904	0.945	288.1	318.8	438.0	420.2	
400	0.906	0.944	316.1	348.9	438.0	459.9	USED FULL LOAD PF & EFF

CONTAINMENT SPRAY PUMP (NEW MOTOR)

MOTOR DATA

BASE HP = 400 HP RATED VOLTAGE = 460 V

LOAD	HP	PF	EFF
100.00%	400	0.895	0.934
75.00%	300	0.882	0.939
50%	200	0.833	0.937

BETWEEN	M(PF)	M(EFF)
100% & 75%	1.300E-04	-5.00E-05
75% & 50%	4.900E-04	2.000E-05

CONTAINMENT SPRAY PUMP 31

BHP	CALC PF	CALC EFF	CALC KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
385	0.893	0.935	307.3	344.1	437.9	453.6	USED FULL LOAD PF & EFF

CONTAINMENT SPRAY PUMP 32

BHP	CALC PF	CALC EFF	CALC KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
400	0.895	0.934	319.5	357.0	437.5	471.1	USED FULL LOAD PF & EFF

AUXILIARY FEED WATER PUMP (BASED ON MOTOR DATA SHEETS)

MOTOR DATA

BASE HP = 400 HP RATED VOLTAGE = 440 V

LOAD	HP	PF	EFF	
120.00%	480	0.870	0.945	(AFWP 31 - BASED ON IP3-ANAL-ED-01636, REV.2)
120.00%	480	0.890	0.953	(AFWP 33 - BASED ON IP3-ANAL-ED-01636, REV.2)

AUXILIARY FEED WATER PUMP 31 (BASED ON RELIANCE MOTOR CURVE)

BHP	CALC PF	CALC EFF	CALC KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
480	0.870	0.945	378.9	435.5	437.0	575.4	

AUXILIARY FEED WATER PUMP 33 (BASED ON RELIANCE MOTOR CURVE)

BHP	CALC PF	CALC EFF	CALC KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
480	0.890	0.953	375.7	422.2	433.0	562.9	

CHARGING PUMP

MOTOR DATA

BASE HP = 200 HP RATED VOLTAGE = 460 V

LOAD	HP	PF	EFF
100.00%	200	0.904	0.931
87.50%	175	0.899	0.931
75.00%	150	0.894	0.931
50%	100	0.851	0.923

CHARGING PUMP 31

BHP	CALC PF	CALC EFF	KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
175	0.899	0.931	140.2	156.0	432.0	208.5	IP3-CALC-MULT-00365, Rev. 0

CHARGING PUMP 32

BHP	CALC PF	CALC EFF	KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
175	0.899	0.931	140.2	156.0	431.1	208.9	IP3-CALC-MULT-00365, Rev. 0

CHARGING PUMP 33

BHP	CALC PF	CALC EFF	KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
175	0.899	0.931	140.2	156.0	429.6	209.6	IP3-CALC-MULT-00365, Rev. 0

CONTAINMENT RECIRCULATION PUMP

MOTOR DATA

BASE HP = 350 HP RATED VOLTAGE = 440 V

LOAD	HP	PF	EFF
100.00%	350.0	0.874	0.937
75.00%	262.5	0.850	0.939
50%	175.0	0.779	0.934

CONTAINMENT RECIRCULATION PUMP 31

BHP	CALC PF	CALC EFF	KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
388.1	0.874	0.937	309.0	353.5	432.0	472.5	LBLOCA Cold Legs&Rec. Spray
259.5	0.850	0.939	206.2	242.5	432.0	324.2	LBLOCA post recirc spray
384.7	0.874	0.937	306.3	350.4	432.0	468.3	SBLOCA recirc spray
257.5	0.850	0.939	204.6	240.7	432.0	321.7	SBLOCA post recirc spray

CONTAINMENT RECIRCULATION PUMP 32

BHP	CALC PF	CALC EFF	KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
388.1	0.874	0.937	309.0	353.5	432.0	472.5	LBLOCA Cold Legs&Rec. Spray
259.5	0.850	0.939	206.2	242.5	432.0	324.2	LBLOCA post recirc spray
384.7	0.874	0.937	306.3	350.4	432.0	468.3	SBLOCA recirc spray
257.5	0.850	0.939	204.6	240.7	432.0	321.7	SBLOCA post recirc spray

PAB EXHAUST FAN

PAB EXHAUST FAN 31

BHP	CALC PF	CALC EFF	KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
137.9	0.850	0.900	114.3	134.5	438.7	177.0	ASSUMED PF & EFF

PAB EXHAUST FAN 32

BHP	CALC PF	CALC EFF	KW	CALC KVA	MTR VOLT	CALC AMP	NOTE
137.9	0.850	0.900	114.3	134.5	438.7	177.0	ASSUMED PF & EFF

APPENDIX B


```

BBVTA 66+BUS2          60.
C
C Convert the parameter to pu
C
C I full load = 468 A
C Volgate PU for line to gnd = 440/sqrt(3) = 254.03
C
SBLMBASE = 254.03
SBN_VPU = VTA / LMBASE
SBNTR_V = VTA * 1.73205
SBNTR_I = IPHA/468.0
C
C POWER METER CALCULATIONS
C
C Generator Power Meter Calculation, Reference to EPRI Workbook IV page 2-10
C
C Instantaneous Power in MW
C
SPPINSTA = (BUS2 * SWTCA) / 1.E+3
C
C S_block
IPB      +PINSTA          120.
      1.
      0.      1.
C
C Trans_Delay
C
C OUCH|XB<n1-|XB<n2-|XB<n3-|XB<n4-|XB<n5-|XC<n|<FLOW|<PHI-|<NLOW|<HM|-|
DEL 53+PB          .00833
C
C Avg Power
C
PA      +PB      -PDEL
C
C -- MOTOR VOLT-AMPERE FOR 3 PHASES IN KVA
C
SBVA    = 3.0 * IPHA * VTA / 1.E+3
C
C -- MOTOR AVERAGE POWER FOR 3 PHASES
C
SBPAVG  = 3.0 * PA
C
C
C -- MOTOR VAR CALCULATION
C
C VAR CALCULATION STARTS WHEN THE SYSTEM HAS LOAD
C
C If VARPO < 0 then VARPI = 0 Else VARPI = VARPO
C
SBVARPO = (VA*VA) - (PAVG*PAVG)
SBVARPI = ((VARPO .LE. 0) * 0.0) + ((VARPO .GT. 0) * VARPO)
SBVAR   = SORT(VARPI)
C

```

Calc. No. IP3-CALC-ED-00267

Rev. 8

Appendix B.1 Sheet 2 of 12

TACS Output

C Type (col 1-2) = 01 (all var), 33 (some var)

C	<Name	<Name	<Name	<Name	<Name	<Name	<Name	<Name	<Name	<Name	<Name	<Name	<Name
C	A6	A6	A6	A6	A6	A6	A6	A6	A6	A6	A6	A6	A6

33PAVB VAR VA 1PNA VTA NTR_V M_VPU NTR_I

C 33M_A1 BUS_V M_AV BF_A1

77LOAD 8.0

BLANK Card Ending TACS Data Component

C NETWORK

SVINTAGE, 1

C 345678901234567890123456789012345678901234567890123456789

C Cable Impedance

C	00SWTCHABUSAS0	0.0001	0.0001	0.	0
C	00SWTCH8BUS80SWTCHABUSAS0				
C	00SWTCHCBUSC90SWTCHABUSAS0				

C Motor Entries

C	00BUS2 SWAR	1.E-6	0.	0.	0
C	00BUS2 SWBR BUSA2 SWAR				
C	00BUS2 SWCR BUSA2 SWAR				
C	00BUS2 BUSAG	1.E5	0.	0.	0
C	00BUS2 BUSBG	1.E5	0.	0.	0
C	00BUS2 BUSCG	1.E5	0.	0.	0
C	00BUS2 BUSDG	1.E-6	0.	0.	0
C	00BUS2 BUSDG	23.815	0.	0.	0
C	00SWAR SWGFLA	1.E-6	0.	0.	0
C	00SWBR SWGFLBSWAR SWGFLA				
C	00SWCR SWGFLCSWAR SWGFLA				
C	00SWGFA	1.E-6	0.	0.	0
C	00SWGFB	1.E-6	0.	0.	0
C	00SWGFC	1.E-6	0.	0.	0

SVINTAGE, 0

BLANK Card Ending Branch Data Component

C Switch

C	00SWTCHASWAR	0.0	10000.	0.	1
C	00SWTCHBSWAR	0.0	10000.	0.	0
C	00SWTCHCSWAR	0.0	10000.	0.	0
C	00SWGFLASWGFA	999.0	9999.	0.	1
C	00SWGFLBSWGFB	999.0	9999.	0.	0
C	00SWGFLCSWGFC	999.0	9999.	0.	0

BLANK Card Ending Switch Data Component

C Source: Motor @ 440 V

C 440 / SQR(3) * SQR(2) = 359.258

Calc. No. FP3-CALC-ED-C0207

Rev. 8

Appendix B.1 Sheet 3 of 12

14BUSAS0	1	359.258	60.	0.0	0.	-1.	9999.
14BUSBS0	1	359.258	60.	-120.	0.	-1.	9999.
14BUSCS0	1	359.258	60.	120.	0.	-1.	9999.
C							
14BUSAS0	1	1.0	60.	0.0	0.	-1.	9999.
14BUSBS0	1	1.0	60.	-120.	0.	-1.	9999.
14BUSCS0	1	1.0	60.	120.	0.	-1.	9999.
60LOAD	-1						

C

C ---- Induction Machine

C

C line 1: HP, Voltage, Power factor, Efficiency, Operating Slip

C 2: Istart, Tqstart, Vreduced, Istart@Vreduced

C 3: Istature, Tqmax

C 4: No. of poles, Moment Inertia, Mechanical Mode Name

C 5: Output Request, see rule book for detail

C

19

1

BLANK Card Ending Class 1 UN Data

C

C APP - Aux Feed Water Pump (Reliance FMA 7704)

C

C 400 HP, 2 poles, full load current = 468 amp, 440 V,

C running speed = 3568 rpm

C Motor Running @ name plate rating: load = 400 * 0.746 = 298.4 kW

C

C $WK^2 = (61 \cdot 14.3) / 23.73 = 3.173 \text{ kg-m}^2$

C

40BUSAZ 100. 60.

40BUSBZ

40BUSCZ

DESIGN RATIO

0.55

-400. 440. 0.881 0.951 0.009

3.368 1.09 0.75 3.918

2.0 2.35

2 3.173@60

0 0 0 1 1 0 1

1.0

BLANK Card Ending Universal Machine Data

BLANK Card Ending Source Data Component

ZSMTCMA 359.258 0. 60.

BLANK Card Ending Initial Conditions Component

BLANK Card Ending Output Specifications Component

BLANK Card Ending Plot Specifications Component

BEGIN NEW DATA CASE

BLANK Card to End EMTF Input

Calc. No. IP3-CALC-ED-00207

Rev. 8

Appendix B-1 Sheet 4 of 12

BEGIN NEW DATA CASE

8/5/97

C FILE NAME : REL_603N.DAT = REL_57.DAT = MTR_57.DAT CSCP.DAT (A7)

C Reliance Electric Serial No. FA7704 Frame E50088 Type P8
C Use as Aux Feed Pump WK^2 = 14.3 lb-ft^2
C different source frequency = 60.3 HZ for IP3 Use

C Use LM Type 40

C Aux Feed Pump 400 HP, 2 poles, full load current = 468 amp, 440 V,
C running speed = 3368 rpm
C Motor running @ name plate ratings: load = 400 * 0.746 = 298.4 kW

C ... Miscellaneous data for time step, duration, print & plotting frequency...

C DeltaT<---TMax<---XOpt<---COpt<Epsfin<FolMat<TStart
C .25E-3 10.0 0. 0. 0. 0. 0. 0.
C .50E-3 7.5 0. 0. 0. 0. 0. 0.

C Second Miscellaneous Data Card

C -Iprint<--Iplot<Idoubl<KeeOut<MaxOut<---Ipur<Nameav<---Icat<Nenerg<Ipsup
C 18 18 18 18 18 18 18 18 18 18
C 1 10 1 1 1 -1 0 2 0 0
C 1 20 0 0 0 0 0 0 0 0

TACS HYBRID 1

C
C
C 90BUSAZ 0.
C 90BUSNG 0.
C 90SWAR 0.
C 91SWTCH 0.
C 91SWGFLA 0.
C 88M_A10 = SWTCH - SWGFLA

C
C 88LOAD = -0.00572*BUSNG*BUSNG

C
C 88GF_A1 66*SWGFLA 60.3
C 88M_A1 66*M_A10 60.3
C 88M_AV 66*BUSA2 60.3
C 88BUS_V266*SWAR 60.3

C
C PHASE A MOTOR TERMINAL RMS CURRENT

C
C 88IPHA 66*SWTCH 60.3

C
C PHASE A MOTOR RMS VOLTAGE

C
C 88VTA 66*BUSA2 60.3

Calc. No. IP3 - CALC-ED-00207
Rev. 8
Appendix B.1 Sheet 5 of 12

```

C
C Convert the parameter to pu
E
C I full load = 468 A
C Voltage PU for line to grd = 440/sqrt(3) = 254.03
C
BBLMBASE = 254.03
BBN_VPU = VTA / LMBASE
BSNTR_V = VTA * 1.73205
BSNTR_I = IPHA/468.0
C
C POWER METER CALCULATIONS
C
C Generator Power Meter Calculation, Reference to EPRI Workbook IV page 2-10
C
C Instantaneous Power in MW
C
BBPINSTA = (BUSAZ * SUTCHA) / 1.E+3
C
C S_block
IPB      +PINSTA      120.6
      1.
      0.      1.
C
C Trans_Delay
C
C <OutB|xS<In1-|xS<In2-|xS<In3-|xS<In4-|xS<In5-|x<Gain|<PLow|<PHI-|<MLow|<NH1-|
+PDEL 33+PB      .00829
C
Avg Power
C
PA      +PB      -PDEL
C
C -- MOTOR VOLT-AMPERE FOR 3 PHASES IN KVA
C
BBVA = 3.0 * IPHA * VTA / 1.E+3
C
C -- MOTOR AVERAGE POWER FOR 3 PHASES
C
BBPAVG = 3.0 * PA
C
C
C -- MOTOR VAR CALCULATION
C
C VAR CALCULATION STARTS WHEN THE SYSTEM HAS LOAD
C
C If VARPO < 0 then VARP1 = 0 Else VARP1 = VARPO
C
BBVARPO = (VA*VA) - (PAVG*PAVG)
BBVARP1 = ((VARPO .LE. 0) * 0.0) + ((VARPO .GT. 0) * VARPO)
BBVAR = SQR(BBVARP1)
C
C TACS Output
C Type (col 1-2) = 01 (nil var), 33 (Some var)

```

Calc. No. IP3-CALC-ED-00207

Rev. 8

Appendix B.1 Sheet 6 of 12


```

14BUSCB 1 359.258 60.3 120. 0. -1. 9999.
C
14BUSAB 1 1.0 60.3 0.0 0. -1. 9999.
14BUSBB 1 1.0 60.3 -120. 0. -1. 9999.
14BUSCB 1 1.0 60.3 120. 0. -1. 9999.
60LOAD -1

```

C

C ---- Induction Machine

C

C line 1: HP, Voltage, Power factor, Efficiency, Operating Slip

C 2: Istart, Tqstart, Vreduced, Istart@Vreduced

C 3: Isaturated, Tqmax

C 4: No. of poles, Moment Inertia, Mechanical Node Name

C 5: Output request, see rule book for detail

C

19

1

BLANK Card Ending Class 1 UM Data

C

C AFP - Aux Feed Water Pump (Reference FNA 7704)

E

C 400 HP, 2 poles, full load current = 468 amp, 440 V,

C running speed = 3568 rpm

C Motor running @ name plate ratings: load = 400 * 0.748 = 298.6 kw

C

C $WK^2 = (61 \cdot 14.3) / 23.73 = 3.173 \text{ kg-m}^2$

C

40BUSB2 100. 60.3

40BUSB2

40BUSC2

```

DESIGN RATIO 0.55
-400. 640. 0.881 0.951 0.009
5.368 1.09 0.75 3.518
2.0 2.35

```

2 3.173BUSMG

0 0 0 1 1 0 1

1.0

BLANK Card Ending Universal Machine Data

BLANK Card Ending Source Data Component

28VTCMA 359.258 0. 60.3

BLANK Card Ending Initial Conditions Component

BLANK Card Ending Output Specifications Component

BLANK Card Ending Plot Specifications Component

BEGIN NEW DATA CASE

BLANK Card to End ENTP Input

Calc No. FP3-CALC-ED-00207

Rev. 8

Appendix B.1 Sheet 8 of 12

Begin NEW DATA CASE

8/5/97

FILE NAME : REL_597N.DAT = REL_605.DAT = MTR_57.DAT = CSCP.DAT (A7)

Reliance Electric Serial No. FA7704 Frame E3008S Type P8
Use as Aux Feed Pump WK^2 = 14.3 lb-ft^2
different source frequency = 59.7 HZ for 1P3 use

Use UM Type 40

Aux Feed Pump 400 HP, 2 poles, full load current = 468 amp, 440 V,
running speed = 3568 rpm
Motor running @ name plate rating: load = 400 * 0.746 = 298.4 kW

Calc No. FP3-CALC-ED-00207

Rev. 8

Appendix B.1 Sheet 9 of 12

Miscellaneous data for time step, duration, print & plotting frequency...

DeltaT---TMax---KOpt---COpt---Epsiln---TolMat---TStart
.25E-3 10.0 0. 0. 0. 0. 0.
.50E-3 7.5 0. 0. 0. 0. 0.

Second Miscellaneous Data Card

-Iprnt--Iplot--Idoubl--KasOut--MaxOut---Iprnt--Memov---Icat--Memorg--Iprnt
18 18 18 18 18 18 18 18 18 18
1 10 1 1 1 -1 0 2 0 0
1 20 0 0 0 0 0 0 0 0

ACS HYBRID 1

POBUSAZ 0.
POBUSMG 0.
POBUSAR 0.
91SWTCHM 0.
91SWGFLA 0.
SSM_A10 = SWTCHM - SWGFLA

SSLOAD = 0.00572*BUSMG*BUSMG

SSAF_A1 66+SWGFLA 59.7
SSM_A1 66+M_A10 59.7
SSM_AV 66+BUSAZ 59.7
SSBUS_V266+SWAR 59.7

PHASE A MOTOR TERMINAL RMS CURRENT

SSIPHA 66+SWTCHM 59.7

PHASE A MOTOR RMS VOLTAGE

Post-It® Fax Note	7871	Date	10/16/97
To	✓ Raffaele	From	K SWR
Co./Dept	RS	Co.	Raytheon E&C
Phone #		Phone #	201-460-6078
Fax #	914-788-2344	Fax #	201-460-6357

BBVTA 66+BUS2 59.7

C
 C Convert the parameter to pu
 C
 C I full load = 468 A
 C Voltage PU for line to gnd = 440/sqrt(3) = 254.03
 E
 BBLMBASE = 254.03
 BBLVPU = VTA / LMBASE
 BBLNTR_V = VTA * 1.73205
 BBLNTR_I = IPHA/468.0

C
 C POWER METER CALCULATIONS
 C
 C Generator Power Meter Calculation, Reference to EPRI Workbook IV page 2-10
 C
 C Instantaneous Power (in MW)

C
 BOPINSTA = (BUS2 + BUTCHA) / 1.E+3
 E
 C 8_block
 IPB +PINSTA 119.4
 1.
 0. 1.

*Calc. No IP3-CALC-ED-00207
 Rev. 8
 Appendix B 1 sheet 10 of 12*

C
 C Trans_Delay
 C
 C <OVER|<x8<ln1-|<x8<ln2-|<x8<ln3-|<x8<ln4-|<x8<ln5-|<x<Gn1n|<FLOW|<FMI-|<NLOW|<NMI-|
 POEL 53+PB .00838

C Avg Power
 C
 PA +PB -POEL
 C
 C -- MOTOR VOLT-AMPERE FOR 3 PHASES IN KVA
 C
 B8VA = 3.0 * IPHA * VTA / 1.E+3
 C
 C -- MOTOR AVERAGE POWER FOR 3 PHASES
 C
 B8PAVG = 3.0 * PA
 C
 C
 C -- MOTOR VAR CALCULATION
 C
 C VAR CALCULATION STARTS WHEN THE SYSTEM HAS LOAD
 C
 C IF VARPO < 0 then VARP1 = 0 Else VARP1 = VARPO
 C
 B8VARPO = (VA*VA) - (PAVG*PAVG)
 B8VARP1 = ((VARPO .LE. 0) * 0.0) + ((VARPO .GT. 0) * VARPO)
 B8VAR = B8RT(VARP1)
 C
 C TACS Output

C Type (col 1-2) = 01 (all var), 33 (some var)

C <Name|<Name|<Name|<Name|<Name|<Name|<Name|<Name|<Name|<Name|<Name|<Name|<Name|
C A6 A6 A6 A6 A6 A6 A6 A6 A6 A6 A6 A6 A6 A6

33PAV0 VAR VA IPHA VTA MTR_V M_VPU MTR_1

C 33M_A1 BUS_V M_AV GF_A1

77LOAD 0.0

BLANK Card Ending TACS Data Component

C NETWORK

C SVINTAGE, 1

C 3456789012345678901234567890123456789012345678901234567890123456789

C Cable impedance

C
00SWTCHABUSAB0 0.0001 0.0001 0. 0
00SWTCHBUSBSS0SWTCHABUSAB0
00SWTCHCBUSFC0SWTCHABUSAB0

C Motor Entries

C
00BUSA2 SWAR 1.E-6 0. 0. 0
00BUSB2 SWBR BUSA2 SWAR
00BUSC2 SWCR BUSA2 SWAR
00BUSA2 BUSAG 1.E5 0. 0. 0
00BUSB2 BUSBG 1.E5 0. 0. 0
00BUSC2 BUSCG 1.E5 0. 0. 0
00D BUSDG 1.E-6 0. 0. 0
00SWAR SWGFLA 1.E-6 0. 0. 0
00SWBR SWGFLBSWAR SWGFLA
00SWCR SWGFLCSWAR SWGFLA
00SWGFA 1.E-6 0. 0. 0
00SWGFB 1.E-6 0. 0. 0
00SWGFC 1.E-6 0. 0. 0

SVINTAGE, 0

BLANK Card Ending Branch Data Component

C Switch

C
00SWTCHASWAR 0.0 10000. 0. 1
00SWTCHBSWAR 0.0 10000. 0. 0
00SWTCHCSWAR 0.0 10000. 0. 0
00SWGFLASWGFA 999.0 9999. 0. 1
00SWGFLBSWGFB 999.0 9999. 0. 0
00SWGFLCSWGFC 999.0 9999. 0. 0

BLANK Card Ending Switch Data Component

C Sources Motor @ 440 V

C 440 / SQRT(3) * SQRT(2) = 359.258

C
14BUSA0 1 359.258 59.7 0.0 0. -1. 9999.

Calc. No IP3-CALC-ED-00207
Rev. 8
Appendix B 1 Sheet 11 of 12

```

14BUSB80 1 359.258 59.7 -120. 0. -1. 9999.
14BUSCP0 1 359.258 59.7 120. 0. -1. 9999.
C
14BUSAG 1 1.0 59.7 0.0 0. -1. 9999.
14BUSB0 1 1.0 59.7 -120. 0. -1. 9999.
14BUSCO 1 1.0 59.7 120. 0. -1. 9999.
60LOAD -1

```

```

C
C ---- Induction Machine
C
C line 1: HP, Voltage, Power factor, Efficiency, Operating Slip
C 2: Istart, Tqstart, Vreduced, Istart@Vreduced
C 3: Istature, Tqmax
C 4: No. of poles, Moment Inertia, Mechanical Mode Name
C 5: Output request, see rule book for detail
C
19

```

Calc. No IP3-CALC-ED-00207
 Rev. 8
 Appendix B.1 Sheet 12 of 12

BLANK Card Ending Class 1 UM Data

```

C
C AFP - Aux Feed Water Pump (Reliance FMA 7704)
C
C 400 HP, 2 poles, full load current = 468 amp, 440 V,
C running speed = 3568 rpm
C Motor running @ name plate rating: load = 400 * 0.746 = 298.4 kW
C
C  $WK^2 = (61 \times 14.3) / 23.73 = 3.173 \text{ kg-m}^2$ 

```

```

C JRAZ 100. 59.7
C JBB2
40BUSC2
DESIGN RATIO 0.55
-400. 440. 0.881 0.951 0.009
5.368 1.09 0.75 3.918
2.0 2.35
2 3.173BUSMG
0 0 0 1 1 0 1
1.0


```

BLANK Card Ending Universal Machine Data

```

BLANK Card Ending Source Data Component
25WTCIA 359.258 0. 59.7
BLANK Card Ending Initial Conditions Component
BLANK Card Ending Output Specifications Component
BLANK Card Ending Plot Specifications Component
BEGIN NEW DATA CASE
BLANK Card to End EHTP Input


```



Calc. No. IP3-CALC-ED-00207

Rev. 8


Appendix B.2 Sheet 1 of 3



Calc.No. IP3-CALC-ED-00207

Rev. 8

Appendix B.2 sheet 2 of 3



Calc. No. IP3-CALC-ED-00207
Rev. 8
Appendix B.2 Sheet 3 of 3

Raytheon Nuclear Inc
160 Chubb Avenue
Lindhurst, NJ 07033-3502
Tel: (201) 460-1900
Fax: (201) 460-6355

Raytheon Engineers &
Constructors

September 15, 1997

Mr. Fred Weinert
New York Power Authority
Indian Point No. 3 Nuclear Power Plant
Con-Edison Broadway Bleakly Gate
Buchanan, NY 10511

*Calc. No. IP3-CALC-ED-00207
Rev. 8
Appendix B.3 Sheet 1 of 2*

Subject: EDGs Performance Testing and Evaluation

Dear Mr. Weinert:

Attached for your review is one copy of the preliminary report on Indian Point 3 EDGs performance testing and evaluation. Based on the test results and evaluation, it is concluded that the EDGs have sufficient capability to support the loads required during an accident condition. Also, the EDGs capabilities have not degraded beyond the capabilities verified in Report 9780.001, Rev 3 dated August 1995.

If you have any questions on the attached report, please contact Ibrahim Hassan at (201)460-5980.

Very truly yours,

John Simon/JS
John Simon
Project Manager

Attach

bcc: I Hassan
G Pan w/o attach
R Weronick w/o attach
K Swe

Calc. No. IP3-CALC-ED-00207
Rev. 8
Appendix B.3 sheet 2 of 2

APPENDIX C



WORTHINGTON
CORPORATION

11 Union Avenue, Bala Cynwyd, Pennsylvania 19004 Tel: 839-6900 Area 215

December 24, 1968
\$ 100,000

United Engineers & Constructors, Inc.
2401 Arch Street
Philadelphia, Pa. 19105

Attention: Mr. W. P. Robinson

Subject: Your P.O. #9321-01-102-1
Phila. 13-70850; DE-35211
Alco Diesel Engine Generators

Controller:

This will confirm our conversation on 12/24/68. The following ratings apply to the (3) three engine generators previously shipped and the proposed modified units:

	<u>PRESENT</u>	<u>PROPOSED</u>
Continuous rating	1750 KW	2000 KW
2000 KW rating	1950 KW	2250 KW
1/2 KW rating	2000 KW	None

Also also advises that the stall rating of the V-16 engine would be about 2395 KW and this would be due to the end of the fuel rack.

If you have any questions, please contact me.

Sincerely yours,

WORTHINGTON CORPORATION

R E Murphy

R. E. Murphy
Sales Representative
Philadelphia Sales Office

RE: Mr. W. P. Robinson

CC: Mr. E. M. Halligan

Calc. No. IP3-CALC-ED-00207
Rev. 8
Appendix C

APPENDIX D

CNB
TECHNOLOGIES

FAX TO: OSMAN AHMED
New York Power Authority

Page 1 of 1


FROM: Jed Reinhard
Manager of Process Engineering and Quality Assurance
Fort Smith Plant

DATE: October 22, 1997

SUBJECT: Normal Float Current for MCX-11 Cells in 60 cell configuration at 131.10 string voltage.

Upon review of the Tafel curves for the MCX product, the ideal float current for MCX-11 cells at 2.18 volts per cell, 1.215 specific gravity electrolyte, and 25 °C is 0.136 amps. Under normal equilibrium conditions, and taking into consideration variations in temperature and specific gravity, currents as high as 0.25 amps may be seen.

The original data I sent you was for cells that were not fully charged and not at equilibrium conditions. Equilibrium conditions are typically seen after 72 hours on float, after an equalizing charge per the instructions listed in the installation and operation manual provided with the product.



Calc. No. IP3-CALC-ED-00207
Rev. 8
Appendix D.1

CNB Technologies
4115 South Zero Street
Fort Smith, AR 72903
U.S.A.
Telephone: 1.501.644.8341
Facsimile: 1.501.644.6797

A Pacific Dunlop Company

NEW YORK POWER AUTHORITY
NUCLEAR ENGINEERING & DESIGN SECTION
TELEPHONE DISCUSSION DOCUMENTATION FORM

CALL DATE 2/3/92 TIME 1135 OUTGOING X
INCOMING _____

BETWEEN K.J. Nessel OF THE AUTHORITY

AND CHARLIE RECHERT OF EVIDE

AND _____ OF _____

REFERENCE (215) 378-0328

SUBJECT BATTERY CHARGER EFFICIENCIES

DISCUSSION/ACTION:

I REQUESTED THE EFFICIENCIES OF IP3 BATTERY CHARGERS 31-34, 2-MODELS SCRF 130-3-400, 1-SCRF 130-3-200 AND 1-SCRF 130-3-150, RESPECTIVELY. HE QUOTED ME THE EFFICIENCIES THAT APPLY FOR ANY LOADING (NOT JUST AT FULL LOAD) AS FOLLOWS:

130-3-400 : 92%
130-3-200 : 91%
130-3-150 : 91%

Calc. No. IP3-CALC-ED-00207
Rev 8
Appendix D.2

DISTRIBUTION:
B. Sergi

NUC GEN FILES NO. _____
MOD FILE NO. _____
[Signature] 2/3/92
SIGNATURE DATE

APPENDIX E

WORST CASE PEAK LOAD – EDG 32 (BUS 6A) – CABLE LOSSES
(LARGE BREAK LOCA – EDG 31 – BUS 2A/3A NOT AVAILABLE)

<u>EQUIPMENT</u>	<u>LENGTH (ft)</u>	<u>CABLE</u> (Per Phase)	<u>RESISTANCE (Ω)/1000 (ft)</u> (Per Cable)
SI PUMP 33	299	2/C-500MCM	.0299
ESWP 36	530	2/C-350MCM	.0413
RHR 32	318	2/C-500MCM	.0299
CSP 32	327	2/C-500MCM	.0299
FCU 35	335	1/C-500MCM	.0299
(PEN H32 → FCU 35)	201	1/C-350MCM	.0413
MCC 36B	238	1/C-350MCM	.0413
MCC 36D	76	1/C-350MCM	.0214
AFWP 33	451	2/C-500MCM	.0299
MCC 37	241	3/C-750MCM	.0214

SUMMARY

<u>EQUIPMENT</u>	<u>CABLE LOSSES (Watts)</u>
SI PUMP 33	2486.5
ESWP 36	5192.9
RHR 32	2669.3
CSP 32	2892.1
FCU 35	2884.3
MCC 36B	376.3
MCC 36D	7.6
MCC 37	6.7
AFWP 33	5555.9
TOTAL:	22071.6

WORST CASE PEAK LOAD CABLE LOSSES

FCU 35

KVA = 184.6

335ft @ 3-1/C - 500 MCM
201ft @ 3-1/C - 350 MCM

$$I = \frac{(184.6) 1000}{(466) (1.73)} = 229.0 \text{ A}$$

$$R_{500} = (335) (3)^* \frac{(.0299)}{1000} = .03\Omega$$

$$R_{350} = (201) (3)^* \frac{(.0413)}{1000} = .025\Omega$$

$$W_{500} = (229.0)^2 (.03) = 1573.23$$

$$W_{350} = (229.0)^2 (.025) = 1311.03$$

$$W_{TOTAL} = W_{500} + W_{350} = 2884.26$$

SI PUMP 33

KVA = 359.5

2- 1/C - 500 MCM Per Phase

$$I = \frac{(359.5) (1000)}{(466) (1.73)} = 445.9 \text{ A}$$

$$\frac{445.9}{2 \text{ (Cable per Phase)}} = 223 \text{ A}$$

299 ft

$$R = (299) \frac{(.0299) (6)^*}{1000} = .05\Omega$$

$$W = (223)^2 (.05) = 2486.5$$

WORST CASE PEAK LOAD CABLE LOSSES

CSP 32

KVA = 357.0

2- 1/C - 500 MCM Per Phase

$$I = \frac{(357.0)(1000)}{(466)(1.73)} = 442.8 \text{ A}$$

$$\frac{442.8}{2 \text{ (Cable per Phase)}} = 221.4 \text{ A}$$

327 ft

$$R = \frac{(327)(.0299)(6)^*}{1000} = .059\Omega$$

$$W = (221.4)^2 (.059) = 2892.1$$

RHR 32

KVA = 348.9

2- 1/C - 500 MCM Per Phase

$$I = \frac{(348.9)(1000)}{(466)(1.73)} = 432.8 \text{ A}$$

$$\frac{432.8}{2 \text{ (Cable per Phase)}} = 216.4 \text{ A}$$

318 ft

$$R = \frac{(318)(.0299)(6)^*}{1000} = .057\Omega$$

$$W = (216.4)^2 (.057) = 2669.3$$

AFWP 33

KVA = 422.2

2- 1/C - 500 MCM Per Phase

WORST CASE PEAK LOAD CABLE LOSSES

$$I = \frac{(422.2)(1000)}{(466)(1.73)} = 523.7 \text{ A} \quad \frac{523.7}{2 \text{ (Cable per Phase)}} = 261.9 \text{ A}$$

451 ft

$$R = \frac{(451)(.0299)(6)^*}{1000} = .081\Omega$$

$$W = (261.9)^2 (.081) = 5555.9$$

ESWP 36

KVA = 320.9

2- 1/C - 350 MCM Per Phase

$$I = \frac{(320.9)(1000)}{(466)(1.73)} = 398.1 \text{ A} \quad \frac{398.1}{2 \text{ (Cable per Phase)}} = 199.1 \text{ A}$$

530 ft

$$R = \frac{(530)(.0413)(6)^*}{1000} = .131\Omega$$

$$W = (199.1)^2 (.131) = 5192.9$$

MCC 36B

KVA = 90.3

3- 1/C - 350 MCM

$$I = \frac{(90.3)(1000)}{(466)(1.73)} = 112.0 \text{ A}$$

WORST CASE PEAK LOAD CABLE LOSSES

238 ft

$$R = \frac{(238) (.0413) (3)^*}{1000} = .030\Omega$$

$$W = (112.0)^2 (.030) = 376.3$$

MCC 36D

KVA = 23.43

3- 1/C - 350 MCM

$$I = \frac{(23.43)(1000)}{(466)(1.73)} = 29.1A$$

76 ft

$$R = \frac{(76) (.0413) (3)^*}{1000} = .009\Omega$$

$$W = (29.1)^2 (.009) = 7.62$$

WORST CASE PEAK LOAD CABLE LOSSES

MCC 37

Total kW from section 6.0 (pg.38) of this calculation = 24.77 kW.

Assuming a power factor of 0.85, the total kVA = kW / p.f = 24.77 / 0.85 = 29.2 kVA

*KVA = 29.2 3- 1/C - 350 MCM Per Phase

$$I = \frac{(29.2)(1000)}{(466)(1.73)} = 36.2 \text{ A} \qquad \frac{36.2}{3 \text{ (Cable per Phase)}} = 12.1 \text{ A}$$

241 ft

$$R = \frac{(241)(.0214)(9)^*}{1000} = .046\Omega$$

$$W = (12.1)^2 (.046) = 6.7$$

NOTES

KVA = Data from Section 6.0 of this Calculation

Cable Size and Length = Data from Calculation IP3-CALC-EL-01967, Rev. 0

I = Amps
(Based on Voltage Drop and Load Flow Analysis from Calculation IP3-CALC-EL-01967, Rev. 0, a conservative voltage drop of 3% is assumed for all cases.)

R = Circuit Resistance

* = Total number of conductors used in Circuit Resistance Tabulation

ft

 = Circuit Length

W = Watts

WORST CASE STEADY STATE LOAD CABLE LOSSES

WORST CASE STEADY STATE LOAD -- EDG 33 (BUS 5A) -- CABLE LOSSES
(LARGE BREAK LOCA -- EDG 32/BUS 6A NOT AVAILABLE)

<u>EQUIPMENT</u>	<u>LENGTH (ft)</u>	<u>CABLE</u> (Per Phase)	<u>RESISTANCE (Ω)/1000 (ft)</u> (Per Cable)
RECIRC. PUMP 31	334	2/C-350MCM	.0413
(PEN H50 → RP 31)	152	2/C-350MCM	.0413
SI PUMP 31	242	2/C-500MCM	.0299
ESWP 34	540	2/C-350MCM	.0413
NESWP 31	500	2/C-350MCM	.0413
FCU 31	329	1/C-500MCM	.0299
(PEN H37(1) → FCU 31)	47	1/C-350MCM	.0413
FCU 33	333	1/C-500MCM	.0299
(PEN H37(2) → FCU 33)	127	1/C-350MCM	.0413
MCC 36A	233	1/C-350MCM	.0413
MCC 36E	32	1/C-350MCM	.0413

SUMMARY

<u>EQUIPMENT</u>	<u>CABLE LOSSES (Watts)</u>
RECIRC. PUMP 31	5771.1
SI PUMP 31	2138.3
ESWP 34	5311.9
NESWP 31	4915.5
FCU 31	1861.6
FCU 33	2622.2
MCC 36A	486.3
MCC 36E	3.4
TOTAL:	23110.3

WORST CASE STEADY STATE LOAD CABLE LOSSES

RECIRCULATION PUMP 31

KVA = 353.5

2- 1/C - 350 MCM Per Phase

$$I = \frac{(353.5)(1000)}{(466)(1.73)} = 438.5 \text{ A} = \frac{438.5}{2 \text{ (Cables per Phase)}} = 219.3 \text{ A}$$

334 ft

$$R = \frac{(334 + 152)(.0413)(6)}{1000} = .12 \Omega$$

$$W = (219.3)^2 (.12) = 5771.1$$

MCC 36A

KVA = 104.4

3- 1/C - 350 MCM

$$I = \frac{(104.4)(1000)}{(466)(1.73)} = 129.5 \text{ A}$$

233 ft

$$R = \frac{(233)(.0413)(3)}{1000} = .029 \Omega$$

$$W = (129.5)^2 (.029) = 486.3$$

WORST CASE STEADY STATE LOAD CABLE LOSSES

MCC 36E

KVA = 23.43

3- 1/C -- 350 MCM

$$I = \frac{(23.43)(1000)}{(466)(1.73)} = 29.1A$$

32 ft

$$R = \frac{(32)(.0413)(3)}{1000} = .004\Omega$$

$$W = (29.1)^2 (.004) = 3.4$$

FCU 33

KVA = 184.6

333 ft @ 3-1/C -- 500 MCM
127 ft @ 3-1/C -- 350 MCM

$$I = \frac{(184.6)(1000)}{(466)(1.73)} = 229.0 A$$

$$R_{500} = \frac{(333)(3)(.0299)}{1000} = .03\Omega$$

$$R_{350} = \frac{(127)(3)(.0413)}{1000} = .02\Omega$$

$$W_{500} = (229.0)^2 (.03) = 1573.2$$

$$W_{350} = (229.0)^2 (.02) = 1049.0$$

$$W_{TOTAL} = W_{500} + W_{350} = 2622.2$$

WORST CASE STEADY STATE LOAD CABLE LOSSES

FCU 31

KVA = 184.6

329ft @ 3-1/C - 500 MCM
47ft @ 3-1/C - 350 MCM

$$I = \frac{(184.6) 1000}{(466) (1.73)} = 229.0 \text{ A}$$

$$R_{500} = \frac{(329) (3) (.0299)}{1000} = .0295 \Omega$$

$$R_{350} = \frac{(47) (3) (.0413)}{1000} = .006 \Omega$$

$$W_{500} = (229.0)^2 (.0295) = 1547.0$$

$$W_{350} = (229.0)^2 (.006) = 314.6$$

$$W_{TOTAL} = W_{500} + W_{350} = 1861.6$$

SI PUMP 31

KVA = 359.5 2 - 1/C - 500 MCM Per Phase

$$I = \frac{(359.5) (1000)}{(466) (1.73)} = 445.9 \text{ A} \qquad \frac{445.9}{2 \text{ (Cable per Phase)}} = 223.0 \text{ A}$$

242 ft

$$R = \frac{(242) (.0299) (6)}{1000} = .043 \Omega$$

$$W = (223.0)^2 (.043) = 2138.3$$

WORST CASE STEADY STATE LOAD CABLE LOSSES

ESWP 34

KVA = 320.9

2- 1/C - 350 MCM Per Phase

$$I = \frac{(320.9)(1000)}{(466)(1.73)} = 398.1 \text{ A} \qquad \frac{398.1}{2 \text{ (Cable per Phase)}} = 199.1 \text{ A}$$

540 ft

$$R = \frac{(540)(.0413)(6)}{1000} = .134\Omega$$

$$W = (199.1)^2 (.134) = 5311.9$$

NESWP 31

KVA = 320.9

2- 1/C - 350 MCM Per Phase

$$I = \frac{(320.9)(1000)}{(466)(1.73)} = 398.1 \text{ A} \qquad \frac{398.1}{2 \text{ (Cable per Phase)}} = 199.1 \text{ A}$$

500 ft

$$R = \frac{(500)(.0413)(6)}{1000} = .124\Omega$$

$$W = (199.1)^2 (.124) = 4915.5$$

WORST CASE STEADY STATE LOAD CABLE LOSSES

NOTES

KVA = Data from Section 6.0 of this Calculation

Cable Size and Length = Data from Calculation IP3-CALC-EL-01967, Rev. 0 except for MCC 36E, where ECRIS was used to determine the cable length and size.

I = Amps
(Based on Voltage Drop and Load Flow Analysis from Calculation IP3-CALC-EL-01967, Rev. 0, a conservative voltage drop of 3% is assumed for all cases.)

R = Circuit Resistance

* = Total number of conductors used in Circuit Resistance Tabulation

ft = Circuit Length

W = Watts

WORST CASE PEAK LOAD FOR EDG 31 (BUS 2A/3A) – CABLE LOSSES
(LARGE BREAK EDG 33/BUS 5A NOT AVAILABLE)

<u>EQUIPMENT</u>	<u>LENG</u> <u>TH (ft)</u>	<u>CABLE</u> (Per Phase)	<u>RESISTANCE (Ω)/1000 (ft)</u> (Per Cable)
AFWP 31	31	2/C-500MCM	.0299
(JBXDS→AFWP 31)	250	2/C-500MCM	.0299
ESWP 35	520	2/C-350MCM	.0413
FCU 32	321	1/C-500MCM	.0299
(PEN H57→FCU 32)	182	1/C-350MCM	.0413
FCU 34	311	1/C-500MCM	.0299
(PEN H53→FCU 34)	116	1/C-350MCM	.0413
MCC 36C	48	1/C-350MCM	.0413
MCC 32	373	1/C-750MCM	.0214
MCC 34	244	2/C-750MCM	.0214
RHR 31	304	2/C-500MCM	.0299
SI 32	291	2/C-500MCM	.0299
CHARGING PUMP 32	324	1/C-500MCM	.0299
(TRSW K1B1→SPLCBX W1E)	5	1/C-500MCM	.0299
(SPLCBX W1E→CHRG PP 32)	10	1/C-500MCM	.0299

SUMMARY

<u>EQUIPMENT</u>	<u>CABLE LOSSES (Watts)</u>
AFWP 31	3647.7
ESWP 35	5108.5
CHARGING PUMP 32	1134.9
SI PUMP 32	2585.9
RHR PUMP 31	2151.9
FCU 32	2726.9
FCU 34	2097.6
MCC 36C	100.3
MCC 32	5.8
MCC 34	44.8
TOTAL	19604.3

WORST CASE PEAK LOAD FOR EDG 31 (BUS 2A/3A) – CABLE LOSSES
(LARGE BREAK EDG 33/BUS 5A NOT AVAILABLE)

AFWP 31

KVA = 435.5

2- 1/C – 500 MCM Per Phase

$$I = \frac{(435.5)(1000)}{(466)(1.73)} = 540.2A \qquad \frac{540.2}{2 \text{ (Cable per Phase)}} = 270.1A$$

281 ft

$$R = \frac{(251+30)(.0299)(6)^*}{1000} = .050 \Omega$$

$$W = (270.1)^2 (.05) = 3647.7$$

ESWP 35

KVA = 320.9

2- 1/C – 350 MCM Per Phase

$$I = \frac{(320.9)(1000)}{(466)(1.73)} = 398.0 A \qquad \frac{398.0}{2 \text{ (Cable per Phase)}} = 199.0 A$$

520 ft

$$R = \frac{(520)(.0413)(6)}{1000} = .129\Omega$$

$$W = (199)^2 (.129) = 5108.5$$

WORST CASE PEAK LOAD FOR EDG 31 (BUS 2A/3A) – CABLE LOSSES
(LARGE BREAK EDG 33/BUS 5A NOT AVAILABLE)

RHR PUMP 31

KVA = 318.8

2- 1/C – 500 MCM Per Phase

$$I = \frac{(318.8)(1000)}{(466)(1.73)} = 395.5A$$

$$\frac{395.5}{2 \text{ (Cable per Phase)}} = 197.8A$$

304 ft

$$R = \frac{(304)(.0299)(6)^*}{1000} = .055 \Omega$$

$$W = (197.8)^2 (.055) = 2151.9$$

SI PUMP 32

KVA = 359.5

2- 1/C – 500 MCM Per Phase

$$I = \frac{(359.5)(1000)}{(466)(1.73)} = 445.9 A$$

$$\frac{445.9}{2 \text{ (Cable per Phase)}} = 223.0 A$$

291 ft

$$R = \frac{(291)(.0299)(6)}{1000} = .052 \Omega$$

$$W = (223)^2 (.052) = 2585.9$$

WORST CASE PEAK LOAD FOR EDG 31 (BUS 2A/3A) – CABLE LOSSES
(LARGE BREAK EDG 33/BUS 5A NOT AVAILABLE)

FCU 32

KVA = 184.6

321ft @ 1/C – 500 MCM 182ft @ 1/C – 350 MCM
--

$$I = \frac{(184.6) 1000}{(466) (1.73)} = 229.0 \text{ A}$$

$$R_{500} = \frac{(321) (3)^* (.0299)}{1000} = .029\Omega$$

$$R_{350} = \frac{(182) (3) (.0413)}{1000} = .023\Omega$$

$$W_{500} = (229.0)^2 (.029) = 1520.8$$

$$W_{350} = (229.0)^2 (.023) = 1206.1$$

$$W_{TOTAL} = W_{500} + W_{350} = 2726.9$$

FCU 34

KVA = 184.6

311 ft @ 1/C – 500 MCM 116 ft @ 1/C – 350 MCM
--

$$I = \frac{(184.6) 1000}{(466) (1.73)} = 229.0 \text{ A}$$

$$R_{500} = \frac{(311) (3)^* (.0299)}{1000} = .03\Omega$$

$$R_{350} = \frac{(116) (3)^* (.0413)}{1000} = .01\Omega$$

$$W_{500} = (229.0)^2 (.03) = 1573.2$$

$$W_{350} = (229.0)^2 (.01) = 524.4$$

$$W_{TOTAL} = W_{500} + W_{350} = 2097.6$$

WORST CASE PEAK LOAD FOR EDG 31 (BUS 2A/3A) – CABLE LOSSES
(LARGE BREAK EDG 33/BUS 5A NOT AVAILABLE)

MCC 34

2- 1/C – 750 MCM Per Phase

$$\text{KVA} = 51.3 \text{ kW}/0.85 = 60.3$$

$$I = \frac{(60.3)(1000)}{(466)(1.73)} = 74.8 \quad \frac{74.8}{2 \text{ (cables per phase)}} = 37.4$$

244 ft

$$R = \frac{(244)(.0214)(6)^*}{1000} = .031\Omega$$

$$W = (37.4)^2 (.031) = 44.8$$

MCC 32

(Battery Charger 34)

$$\text{KVA} = 12\text{kW}/0.95 = 12.6$$

1/C – 750 MCM

$$I = \frac{(12.6)(1000)}{(466)(1.73)} = 15.6\text{A}$$

373 ft

$$R = \frac{(373)(.0214)(3)^*}{1000} = .024\Omega$$

$$W = (15.6)^2 (.024) = 5.8$$

WORST CASE PEAK LOAD FOR EDG 31 (BUS 2A/3A) – CABLE LOSSES
(LARGE BREAK EDG 33/BUS 5A NOT AVAILABLE)

MCC 36C

KVA = 104.2

1/C – 350 MCM

$$I = \frac{(104.2)(1000)}{(466)(1.73)} = 129.3A$$

48 ft

$$R = \frac{(48)(.0413)(3)^*}{1000} = .006\Omega$$

$$W = (129.3)^2 (.006) = 100.5$$

CHARGING PUMP 32

KVA = 156.8

1/C – 500 MCM

$$I = \frac{(156.8)(1000)}{(466)(1.73)} = 194.5 A$$

339 ft

$$R = \frac{(339)(.0299)(3)}{1000} = .030\Omega$$

$$W = (194.5)^2 (.030) = 1134.9$$

WORST CASE PEAK LOAD FOR EDG 31 (BUS 2A/3A) – CABLE LOSSES
(LARGE BREAK EDG 33/BUS 5A NOT AVAILABLE)

NOTES

KVA = Data from Section 6.0 of this Calculation

Cable Size and Length = Data from Calculation IP3-CALC-EL-01967, Rev. 0

I = Amps
(Based on Voltage Drop and Load Flow Analysis from Calculation IP3-CALC-EL-01967, Rev. 0, a conservative voltage drop of 3% is assumed for all cases.)

R = Circuit Resistance

* = Total number of conductors used in Circuit Resistance Tabulation

ft

 = Circuit Length

W = Watts

APPENDIX F

APPENDIX F

COMPARTMENT	VALVE	DESCRIPTION	HP	KW**
	536	PRZR PWR RELIEF BLK	0.7	1.72
* MCC-36A-1FH	822A	RESID HT XCH CCW SHUTOFF	1.6	2.99
MCC-36A-1FM	745B	RHR ISO	1.9	2.62
MCC-36A-2FD	746	RHR DISCH STOP	20.7	22.12
MCC-36A-2FH	730	RHR INLET STOP	2.6	4.63
* MCC-36A-2FM	797	RCP CCW SUP ISO	0.3	.62
* MCC-36A-3FD	784	RCP BEAR CCW ISO	1.3	1.79
* MCC-36A-3FH	625	RCP THERM BARR ISO	1.6	2.54
* MCC-36A-3FM	744	RHR LOOP ISO	3.3	3.89
MCC-36A-4FD	866A	CS PP DISCH STOP	1.9	2.62
* MCC-36A-4FH	856G	HIGH HEAD INJ STOP	1.6	2.99
MCC-36A-4FM	880A	FILTER DOUSING	1.6	2.99
MCC-36A-5FD	880C	FILTER DOUSING	1.6	2.99
MCC-36A-5FH	880E	FILTER DOUSING	1.6	2.99
MCC-36A-5FM	887A	SI PP 32 SUCTION ISO	0.3	.75
MCC-36A-6FM	1869A	HI HEAD RECIRC STOP	1.0	2.10
MCC-36A-7FH	842	MIN FLOW ISO	1.0	2.10
MCC-36A-7FM	1810	REFUELING WTR STOR TK DISCH	1.0	2.10
MCC-36A-8FD	1835	BORON INJECTION TK ISO	1.6	2.99
MCC-36A-8FH	226	CHARGING LINE CONTAINMENT ISO	0.7	1.72
MCC-36A-8FM	990A	RECIRC P SAMPLE CONTAINMENT ISO	0.1	.34
MCC-36A-9FJ	441	31 RCP SEAL INJ CONTAINMENT ISO	0.7	1.72
MCC-35A-9FM	442	32 RCP SEAL INJ CONTAINMENT ISO	0.7	1.72
MCC-36A-10FC	443	33 RCP SEAL INJ CONTAINMENT ISO	0.7	1.72
MCC-36A-10FF	444	34 RCP SEAL INJ CONTAINMENT ISO	0.7	1.72
MCC-36A-10FJ	850C	31 SI P DISCHARGE ISO	1.0	2.10
MCC-36A-11FF	1852A	BORON INJ TK ISO	1.6	2.99
MCC-36A-11FJ	LCV-112C	VOLUME CONT TK DISCH	0.3	.75
* MCC-36A-1RD	222	SEAL WTR RTN ISO	1.3	1.79
MCC-36A-1RH	894C	ACCUM DISCH STOP	7.9	8.52
* MCC-36A-1RM	222	SEAL WTR RTN ISO	1.3	1.79
MCC-36A-2RD	894C	ACCUM DISCH STOP	7.9	8.52
MCC-36A-1RM	856C	HIGH HEAD INJ STOP	1.6	2.99
MCC-36A-2RD	1802A	RECIRC SUMP STOP	1.6	2.99
MCC-36A-2RM	885A	VC SUMP	3.2	3.89
MCC-36A-3RD	894A	ACCUMULATOR DISCH STOP	7.9	8.52
MCC-36A-3RH	851A	HIGH HEAD SI PP 32 STOP	1.0	2.10
MCC-36A-3RM	888A	HIGH HEAD RECIRC STOP	0.7	1.72
MCC-36A-4RD	889A	SPRAY RECIRC STOP	1.9	2.62
MCC-36A-4RH	880G	FILTER DOUSING	1.6	2.99
MCC-36A-4RM	880J	FILTER DOUSING	1.6	2.99
MCC-35A-5RD	747	RHR LOOP DISCH STOP	10.5	10.31
MCC-36A-5RH	743	RHR LOOP OUTLET	1.0	2.10
MCC-36A-6RM	BFD-2-31	BFP 31 DISCHARGE VALVE	5.3	6.73
* MCC-36A-8RD	856E	HIGH HEAD INJ STOP	1.6	2.99
MCC-36A-8RG	640	RHR LOOP FLOW CTL	0.7	1.72
MCC-36A-8RM				

* MOV's that operate automatically upon initiation of an SI signal. Ref 4-3-(8)

** Ref. IP3-CALC-EDG-02897 Rev.0

APPENDIX F

COMPARTMENT	VALVE	DESCRIPTION	HP	KW**
MCC-36B-1FH	535	PRESSURIZER PWR RELIEF	0.7	1.72
* MCC-36B-1FM	822B	RHR HX CCW SHUTOFF	1.6	2.99
MCC-36B-2FD	745A	RHR LOOP ISO	1.9	2.62
MCC-36B-2FH	899A	RHR LOOP DISCHARGE STOP	10.3	15.1
MCC-36B-2FM	731	RHR LOOP INLET STOP	2.6	4.63
* MCC-36B-3FD	769	RCP CCW SUPPLY ISO	0.3	.62
* MCC-36B-3FH	786	RCP BEARING CCW ISO	1.3	1.79
* MCC-36B-3FM	789	RCP THERM BARRIER CCW RTN	1.6	2.62
MCC-36B-4FD	882	RHR PUMP SUCTION STOP	1.9	2.62
* MCC-36B-4FH	866B	SPRAY PUMP DISCHARGE	1.9	2.62
MCC-36B-4FM	856H	HIGH HEAD INJ LINE STOP	1.6	2.99
MCC-36B-5FD	880B	FILTER DOUSING	1.6	2.99
MCC-36B-5FH	880D	FILTER DOUSING	1.6	2.99
MCC-36B-5FM	880F	FILTER DOUSING	1.6	2.99
MCC-36B-6FM	887B	S.I. PUMP SUCTION ISO	0.3	.75
MCC-36B-7FH	1869B	HIGH HEAD RECIRC STOP	1.0	2.10
MCC-36B-7FM	843	MIN FLOW ISO	1.6	2.99
MCC-36B-8FD	883	RHR PP RECIRC TO REFUEL TK	2.6	4.30
MCC-36B-8FH	1835B	BORON INJ TK ISO	1.6	2.99
MCC-36B-8FM	856J	HIGH HEAD INJ STOP	1.6	2.99
MCC-36B-9FJ	205	CHARGING LINE CONTAINMENT ISO	0.7	1.72
MCC-36B-9FM	250C	33 RCP SEAL INJ CONTAINMENT ISO	0.7	1.72
MCC-36B-10FC	990B	RECIRC P SAMPLE CONTAINMENT ISO	0.1	.34
MCC-36B-10FJ	250B	32 RCP SEAL INJ CONTAINMENT ISO	0.7	1.72
MCC-36B-11FC	250A	31 RCP SEAL INJ CONTAINMENT ISO	0.7	1.72
MCC-36B-11FF	250D	34 RCP SEAL INJ CONTAINMENT ISO	0.7	1.72
MCC-36B-11FJ	850A	31 SI P DISCHARGE ISO	1.0	2.10
MCC-36B-1RD	1852B	BORON INJ TK ISO	1.6	2.99
MCC-36B-1RH	LCV-112B	REACTOR MAKEUP WTR	0.3	.75
MCC-36B-1RM	333	EMERGENCY BORATION	0.3	.75
MCC-36B-2RD	894D	ACCUMULATOR DISCHARGE	7.9	8.52
MCC-36B-2RH	856B	HIGH HEAD INJ STOP	1.6	2.99
MCC-36B-3RD	1802B	RECIRC SUMP STOP	1.6	2.99
MCC-36B-3RH	885B	CONTAINMENT SUMP STOP	3.2	3.89
MCC-36B-3RM	894B	ACCUMULATOR DISCH STOP	7.9	8.52
MCC-36B-4RD	851B	HIGH HEAD SI PUMP 32 STOP	1.0	2.10
MCC-36B-4RH	888B	HIGH HEAD RECIRC STOP	0.7	1.72
MCC-36B-4RM	889B	SPRAY RECIRC STOP	1.9	2.62
MCC-36B-5RD	880H	FILTER DOUSING	1.6	2.99
MCC-36B-5RH	880K	FILTER DOUSING	1.6	2.99
MCC-36B-6RM	899B	RHR LOOP DISCH STOP	20.7	22.12
MCC-36B-7RM	1870	RHR LOOP OUTLET	1.6	2.99
* MCC-36B-8RD	BFD-2-32	DISCHARGE	5.3	6.73
MCC-36B-8RM	638	RHR LOOP FLOW CTL	0.7	1.72
MCC-36B-10RJ	994A	BFP 32	0.7	1.72

* MOV's that operate automatically upon initiation of an SI signal. Ref. 4-3-(8)

APPENDIX G

COMPARISON OF 1991 DGV STUDY TO 1997 STUDY

BUS/MCC	Case 31 Data of 1991 DGV Study			Case 31SK Data of 1997 DGV Study			Delta kV (1)	% Delta kV (2)
	VOLTS	VD	kV (3)	VOLTS	VD	kV (3)		
BUS 2A	415.10	--	0.4440	415.00	--	0.4440	0	0.00%
MCC 31	412.10	3.00	0.4410	411.00	4.00	0.4400	0.001	0.23%
MCC 33	408.10	7.00	0.4370	406.00	9.00	0.4350	0.002	0.46%
MCC 34	412.70	2.40	0.4416	412.00	3.00	0.4410	0.0008	0.14%
MCC 36C	415.00	0.10	0.4439	414.00	1.00	0.4430	0.0009	0.20%
BUS 3A	408.90	--	0.4440	404.00	--	0.4440	0	0.00%
MCC 32	402.80	6.10	0.4379	397.00	7.00	0.4370	0.0009	0.21%
MCC 35	403.90	5.00	0.4390	398.00	6.00	0.4380	0.001	0.23%
BUS 5A	401.80	--	0.4440	398.00	--	0.4440	0	0.00%
MCC 36A	494.40	7.40	0.4366	389.00	9.00	0.4350	0.0016	0.37%
MCC 38	395.10	6.70	0.4373	389.00	9.00	0.4350	0.0023	0.53% <--Max
MCC 39	401.20	0.60	0.4434	398.00	0.00	0.4440	0.0006	0.14%
BUS 6A	395.50	--	0.4440	392.00	--	0.4440	0	0.00%
MCC 36B	389.80	5.70	0.4383	385.00	7.00	0.4370	0.0013	0.30%
MCC 37	393.30	2.20	0.4418	389.00	3.00	0.4410	0.0008	0.18%
Largest Deviation (Max Delta kV) =							0.0023	0.53%

Notes:

1 - Delta kV = ABS((New 207 kV) - (Existing 207 kV))

2 - %Delta kV = (Delta kV) / (New 207 kV)

3 - kV = 444.0 - VD / 1000

APPENDIX H

IP3-CALC-ED-00207 REV.8 APPENDIX H-1
IP3 EDG Loading Input Clarification

Background / Purpose

The current IP3 EDG loading calculation IP3-CALC-ED-00207 Rev 7, "Electrical Load Study – 480V Bus 2A, 3A, 5A and 6A and EDG's 31, 32 and 33 Accident Loading", is to be revised to include load changes that have accumulated over the past several years. The purpose of this document is to clarify the use of certain brake horsepower (BHp) values for specific components in this forthcoming revision. The components within its scope are the Containment Recirculation Pumps (CRPs), the Containment Spray Pumps (CSPs), the High Head Safety Injection Pumps (HHSIPs), and the Fan Cooler Units (FCUs).

IPEC Design Engineering Mechanical Group issued IP-CALC-04-00809 Revision 2, "Brake Horsepower Values Related to Certain Pumps and Fans for EDG Electrical Loading", on 2/17/09 in which some BHp values were changed from the Revision 1 version of the calculation. Furthermore, in response to IP3 NRC Component Design Basis Inspection (CDBI) questions, Fan Cooler Unit post-LOCA loads were also re-evaluated and resulted in modified FCU BHp's. Westinghouse calculation CN-CRA-08-11 Rev 0, "IP3 Fan Cooler Unit (FCU) Horsepower Under LOCA Conditions", containing this evaluation was issued on 5/7/08.

Containment Recirculation Pump Input

One of the mechanical loads (BHp's) that have been changed in Rev 2 of IP-CALC-04-00809 is that of the Containment Recirculation Pumps. The ongoing GSI-191 (Generic Letter 2004-02) effort has affected certain analytical flow configurations of the CRPs and hence their associated BHp's. Calculation IP-CALC-07-00054 Rev 2 (Westinghouse CN-SEE-05-107 Rev 2) has presented GSI-191 cases that have resulted in new CRP flow rates (and BHp's). The following scenarios and BHPs involving the CRPs are now found in IP-CALC-04-00809 Rev 2 [See Note 3] that should be included in the updated IP3 EDG loading study:

1. **LB LOCA – Cold Legs & Recirculation Spray, 2 RHR HX: 388.1 Hp**
2. **LBLOCA - Cold Legs & Recirculation Spray, 1 RHR HX: 385.2 Hp**
3. **LB LOCA – Post Recirc Spray, Hot Leg Recirc, 1 RHR HX: 259.5 Hp**
4. **SB LOCA – High Head SI & Recirculation Spray, 1 RHR HX: 384.7 Hp**
5. **SB LOCA – High Head SI, post Recirc Spray, 1 RHR HX: 257.5 Hp**

Note 1: The operating configurations of Items 1 and 4 will not be permitted by a future revision of the EOPs to meet GSI-191 requirements. However, from an analytical perspective, these configurations and the associated BHp values are valid and should be included in the revised IP3-CALC-ED-00207.

Note 2: For conservatism, calculation IP-CALC-04-00809 Rev 2 did not ascertain a CRP BHp for the LB LOCA case where one CRP is supplying only the cold legs through one or two RHR HXs. This situation can exist for anywhere between about 10 and 30 minutes in the LB LOCA scenario depending upon actual RWST level at switchover and safeguard equipment availability. The CRP flow rate here would be lower and the Sump fluid temperature higher (ie, less dense water) than when Recirc Spray is in service; thus the BHp would be less than the 388.1 Hp cited above. To include this case in the updated

IP3-CALC-ED-00207 REV.8 APPENDIX H-1
IP3 EDG Loading Input Clarification

IP3-CALC-ED-00207 would require both a revision to IP-CALC-04-00809 and a general change of methodology in determining IP3 EDG loading to somewhat mimic the IP2 analytical approach.

Note 3: Item 5 above includes the Hot Leg Recirculation mode. The flow rates for High Head SI cold leg only recirculation and High Head SI cold leg / hot leg combined recirculation are essentially identical for the purposes of EDG loading. Therefore, the CRP BHp during SB LOCA Hot Leg Recirculation can be taken to be 257.5 Hp.

Containment Spray Pump Input

The Containment Spray Pump BHp values currently stated in IP3-CALC-ED-00207 Rev 7 are 400 Hp when both pumps are running and 410 Hp when only one pump is operating. The evaluation in IP-CALC-04-00809 Rev 2 provides alternate results. Because of the separate and parallel arrangement of the CS Pump discharge headers, and the minimal difference in suction losses whether one or two pumps are in operation, the 00809 calculation justified not considering the number of running CS Pumps in determining BHPs. What the calculation did utilize was RWST temperature, relative performance of each CS Pump, and Containment (VC) back pressure. All the necessary information comes from Westinghouse calculation SEE-03-128 Rev 1, "IP3 Containment Spray RWST Alignment Minimum and Maximum Flow Calculation". BHp results were obtained for three VC back pressures, 0 psig, 42.07 psig, and 47 psig, at a RWST temperature of 70°F. (Note: The BHp curves were developed at a Specific Gravity of 1.0 for water at 60°F. The difference in water density between 70°F and 60°F is 0.1% [(62.371 - 62.305) / 62.371], which is regarded as insignificant to BHp determination.)

Containment Pressure (psig)	CS Pump 31 (BHp)	CS Pump 32 (BHp)
0	410	420
42.07	377	387
47	375	385

The difficulty with these results for EDG loading is that they are either overly conservative or not conservative enough depending on the chosen VC back pressure. What needs to be ascertained with respect to CS Pump BHp for EDG loading purposes is what VC pressure is most appropriate and justifiable to use to obtain applicable pump flow rates.

According to Westinghouse calculation CRA-02-50 R1 "IP3 Long Term LOCA Mass & Energy and VC Integrity", and WCAP-16212 "IP3 SPU NSSS and BOP Licensing Report" Table 6.5-31, during a LB LOCA with Minimum Safeguards VC pressure would climb to a value of ~42 psig within about 18 minutes. This pressure would then slowly decline to ~19.5 psig at about 5 hours into the accident. During a LB LOCA with Maximum Safeguards, according to WCAP-16212 Table 6.5-32, VC pressure peaks at ~38 psig at about 3 minutes and slowly decreases to ~20 psig at about 3 hours into the event. The nominal Containment Spray actuation setpoint is 22 psig [from IP3-CALC-ESS-00244 Rev 1]. Containment Spray duration for a LB LOCA at IP3 is one hour at

IP3-CALC-ED-00207 REV.8 APPENDIX H-1
IP3 EDG Loading Input Clarification

most based on maximum RWST volume and minimum components taking suction on it. Therefore, it is obvious that VC pressure remains above 20 psig essentially throughout the entire Containment Spray period, and hence 20 psig can be safely used for EDG loading evaluation.

BHp values at 20 psig VC pressure can be obtained. This action is deemed to be a clarification to and not a revision of the -00809 calc since CS Pump flow rates at this back pressure come directly from SEE-03-128 Rev 1 Table 2 (conservatively applicable to maximum enhanced pumps) and BHp's corresponding to these flows are read directly from the pump curves (Curve #46511 for CSP 31, Curve #46510 for CSP 32). For CS Pump 31, maximum flow at 20 psig VC pressure is taken to be 2858 gpm, which is the average of the 70°F and 110°F values found in Table 2 of SEE-03-128 R1. The BHp at this flow rate is conservatively read as 385 Hp off of Curve #46511. For CS Pump 32, maximum flow at 20 psig VC pressure is taken to be 2989 gpm, again the average of the 70°F and 110°F values found in Table 2 of SEE-03-128 R1. The BHp at this flow rate is conservatively read as 400 Hp off of Curve #46510.

For a LB LOCA, it is concluded that based on the fact that VC pressure during the time that Containment Spray is occurring remains above 20 psig, the following BHp values can be used in EDG loading analysis:

LB LOCA CS Pump 31 – 385 Hp
LB LOCA CS Pump 32 – 400 Hp

Westinghouse does not perform official Containment integrity analyses for SB LOCA scenarios since the SB LOCA is bounded by the LB LOCA in terms of mass and energy release. In other words, VC pressure and temperature profiles versus time are not formally available from Westinghouse for SB LOCA. For the smallest SB LOCA in which Containment Spray is actuated (approximately 3" break size according to Westinghouse calculations LIS-03-190 Rev 1 "IP3 SB LOCA Analysis" and CRA-04-83 Rev 1 "IP3 SB LOCA Evaluation of VC Spray Flow") the VC pressure would generally not stay elevated for as long as in a LB LOCA nor would the peak pressure be as high. Basically, for RCS breaks of 3" or larger VC ambient pressures remain above 15 psig for all of injection phase [Ref: Westinghouse verbal input]. The enhanced CS Pump flow rates at this pressure, according SEE-03-128 R1 Table 2, would be approximately 1.4% greater than at 20 psig. The BHp change due to this incremental increase in flow cannot be ascertained from the certified curves. In fact, since the LB LOCA CS Pump 31 and 32 BHp values at 20 psig of 385 Hp and 400 Hp, respectively, were conservatively read from these curves, it is deemed valid to consider them also applicable for the SB LOCA.

SB LOCA CS Pump 31 – 385 Hp
SB LOCA CS Pump 32 – 400 Hp

High Head Safety Injection Pump Input

After reviewing the analyzed configurations involving the HHSI Pumps, it is deemed that the BHp values currently cited in IP3-CALC-ED-00207 Rev 7 (**414 Hp**) are

IP3-CALC-ED-00207 REV.8 APPENDIX H-1
IP3 EDG Loading Input Clarification

conservative and acceptable for use in all LOCA scenarios. Additional formal analysis of HHSI System operation would be required to obtain BHp's corresponding to specific aspects of these scenarios.

Containment Recirculation Fan (Fan Cooler Unit) Input

In the current revision of IP3-CALC-ED-00207, the FCU BHp values are provided based on whether 3, 4, or 5 FCUs are running: for 5 FCUs the load per FCU is 149.0 Hp, for 4 FCUs the load per FCU is 172.4 Hp, and for 3 FCUs the load per FCU is 193.4 Hp. These values were changed by calculation IP-CALC-ED-00293 Rev 1 on 2/7/2002 to 155 Hp, 170 Hp, and 201 Hp, respectively.

In 2008, due to findings of the IP3 NRC CDBI, FCU brake horsepower was re-visited. For normal plant operation (non-accident), the results of IP-CALC-04-00809 continued to be germane to EDG loading evaluation. However, for the post-accident case, Westinghouse analysis (documented in calculation CN-CRA-08-11, Rev 0, "IP3 Fan Cooler Unit (FCU) Horsepower Under LOCA Conditions") concluded that the BHp quantities differed from those in IP3-CALC-ED-00293 Rev 1. At the worst conditions for FCU motor power draw and for the case of 3 FCUs operating, Westinghouse determined that the BHp per FCU was 159 Hp. Westinghouse did not evaluate the loading situations of 4 and 5 operating FCUs in CN-CRA-08-11.

Due to recent conversations with the Westinghouse author of CN-CRA-08-11 and a re-assessment of information pertaining to post-LOCA FCU function (including data from Table 2 of Westinghouse Letter IPP-03-187, "IP2 SPU Project EDG Loading Study Reconciliation"), it has been concluded that 159 Hp is an appropriate input to EDG loading for 3, 4, and 5 operating FCUs. The Westinghouse analyst's expert opinion and IPEC engineering's concurring judgment are that 159 Hp would be the highest load obtained no matter what combination of FCU air flows and VC post-accident atmospheric conditions exist. In other words, whether the air flow per Unit is related to 3 (maximum flow rate), 4 (medium flow rate), or 5 (minimum flow rate) FCUs running or whether the Service Water temperature to the FCUs is as low as 28° F or as high as 95° F, the maximum BHp of a FCU would not exceed 159 Hp.

Based on the above, the following FCU loading values should hence be employed in the revision of IP3-CALC-ED-00207:

- a) When all 5 FCUs are running: 159 Hp
- b) When 4 FCUs are running: 159 Hp
- c) When 3 FCUs are running: 159 Hp

Conclusion

The Design Engineering Electrical Group requested clarification of some of the mechanical loads to use in a forthcoming revision to the IP3 EDG Loading Study calculation IP3-CALC-ED-00207. The loads pertained to the Containment Recirculation

IP3-CALC-ED-00207 REV.8 APPENDIX H-1
IP3 EDG Loading Input Clarification

Pumps, the Containment Spray Pumps, the High Head Safety Injection Pumps, and the Fan Cooler Units. The Design Engineering Mechanical Group has reviewed applicable BHp documents (IP-CALC-04-00809 Rev 2, CN-CRA-08-11 Rev 0, and IP3-CALC-ED-00293 Rev 1) and has provided the necessary input.

ATTACHMENT 1

Raffaele, Joseph
From: Vehstedt, Ken
Sent: Saturday, June 10, 2000 9:45 AM
To: Raffaele, Joseph
Subject: Design Basis SGTR Assumptions

Joe,

Sorry for the delay.

The design basis SGTR is described in SAR section 14.2.4 and AABD module 13.0. The SGTR event does not involve adverse containment conditions as there would be no mass/energy release to the VC. Therefore, consideration of a SGTR with Phase B actuation is not within the scope of the plant design basis.

The design basis MSLB is described in SAR section 14.2.5 and AABD module 17.0 (current being revised). By design, a MSLB would not result in a SGTR (as the static and dynamic differential pressures across the tubes following a large MSLB are factored into the tube design). Refer to the discussion beginning on SAR page 4.3-13 for details.

Based on the above, there is no need to consider simultaneous SGTR and CS actuation in any analysis of design basis events.

Ken V

CALC. No. IP3-CALC-ED-00207 Rev. 8
ATTACHMENT 1 1 of 1