

7

OSC 1522

Design Report #7

Thermal Mechanical Stress Analysis

of

High Pressure Injection Nozzle

B&W Contract No. 620-0003-50
Customer: Duke Power Company

FOR INFORMATION ONLY

Prepared By: W.L. Tanksley and Associates, Inc.

Reviewed By: *Robert Tarnow*

Approved By: *James P. Butte*

Report #7 - "Thermal Mechanical Stress Analysis of High Pressure Injection Nozzle"

Replace entire report with the "Thermal Mechanical Analysis of 2-1/2 Sch 160 make-up and High Pressure Injection Nozzle" for 620-0009-50 as modified in FCA 04-3601-00 (Reference #4), B&W Document 32-1128224-02 (Reference #1), and the changes to the 620-0009-50 report described below:

1. Page iii - Reference A.1 - 150156E-6 should be 131924E-9.
2. Page iii - Reference B.1 - Add "As modified by FCA 04-3599-00.

REV.	DATE
0	12-69
1	5-72

9712110086 971210
PDR ADOCK 05000270
P PDR

0006190284

REVISION PAGE

REV. NO.	PAGE	DESCRIPTION	DATE	BY / APP.
	ALL	<p style="text-align: center;">INITIAL RELEASE</p> <p>The changes below indicate the modifications required to update the 620-0008-50 analysis to the requirements of 620-0009-50.</p>		
	i	<p>Added last sentence in <u>Scope</u>.</p> <p>Changed 70°-90°F to 70°-95°F in 4th line of <u>Discussion</u>.</p> <p>Eliminate all but 1st sentence in <u>Conclusion</u>.</p>		
0	ii	Omitted primary stress results in <u>Results Section</u> .	6-73	FLB/
	iii	<p>Reference A.1 revised for NSS-9 contract.</p> <p>Reference B.1 revised for NSS-9 contract.</p>		
	1.0	Added explanation for a dimensional change on nozzle.		
	1.1	Added NSS-9 dimensions (asteriked) to nozzle sketch.		
	3-56	Add statement at bottom of page.		
	3-65	Omitted Case-2 earthquake loading.		
	3-66	Omitted all reference to piping reaction stresses.		
	5-21	Omitted all references to earthquake loadings.		
	5-22 to 5-31	Omitted all reference to piping reaction stresses.		
1.	ii 5-21 5-24 5-25 5-28 5-29 5-30 5-31	Added note referencing fatigue analysis with pipe loads contained in Section "F".	10/29/73	DMcK/2/3

0006190283

Revisions For E&W Report # 5

Date	Page	Revision Comments	By	A
0				

0006190285

INDEX

	<u>Page</u>
Scope, Discussion, Conclusions	i
Results	ii
References	iii
 <u>Section I</u>	
Geometry	1-1
Stress Concentration Factors	1-2
 <u>Section 2</u>	
Temperature Distribution of Make-up Nozzle	2-1 to 2-29
 <u>Section 3</u>	
Stress Analysis of Make-up Nozzle	3-1
 <u>Section 4</u>	
Temperature Distribution of HPI	4-1
 <u>Section 5</u>	
Stress Analysis of HPI Nozzle	5-1

000619 287

SCOPE:

This report contains the Thermal/Mechanical Analysis of the make-up nozzle and high pressure injection nozzle. These nozzles have the same geometry but are used for different purposes. They are located in the cold legs on the discharge side of the pumps. This report contains the justification of primary plus secondary stress limits and the fatigue analysis as defined in B31.7 "Nuclear Piping Code". Satisfaction of basic pressure sizing criteria and reinforcement calculations are found in Report 1 "Code Sizing Calculation". Piping reaction loads and stresses can be found in Report #4, "Piping Reactions".

DISCUSSION:

The make-up nozzle and high pressure injection nozzles have the same pressure, branch moment loading and run moment loading, but have different temperature distributions. The make-up nozzle is predominately cold in that it has a fairly constant flow and is at a temperature of 70°-95°F. The HPI is only used for a sudden pressure drop condition, and thus is at a temperature consistent with the cold leg temperature, 550°-575°F, when it is shocked with 60°F water. The critical stress location in the make-up nozzle occurs near the nozzle to run pipe intersection whereas the critical stress in the high pressure injection nozzle occurs outside the thermal sleeve in the upper part of the nozzle.

The analysis has essentially the same format for both nozzles. First, the temperature distribution is evaluated for various transient conditions and time-temperature plots for selected nodes are made to select critical times. These times are then used to calculate stresses, and thus stress ranges can be determined for thermal stresses. Secondly, stresses are calculated for pressure loading, and the stresses are then combined to obtain the total stress picture. Finally a fatigue analysis is performed to demonstrate acceptable performance during the design duration.

CONCLUSION:

The make-up nozzle and high pressure injection nozzle meet all the requirements of B31.7 1968 Draft.

RESULTSPrimary + Secondary StressesBranch Intersection Make-Up Nozzle

$$S = 21.1 \text{ ksi} < 3 S_m = 53.4 \text{ ksi}$$

End of HPI Nozzle

$$S = 107 \text{ ksi} > 3 S_m = 51.3 \text{ ksi}$$

An elastic plastic analysis was performed. Range of primary + secondary stresses occurring more than 250 cycles.

$$S = 9.85 \text{ ksi} < 3 S_m = 51.3 \text{ ksi}$$

Fatigue Usage Factors

Branch Intersection make-up nozzle

$$U = .045 < 1.0$$

End of HPI Nozzle

$$U = .953 < 1.0$$

NOTE: This fatigue analysis includes thermal and mechanical discontinuity stresses only. For inclusion of stresses due to run and branch pipe motions, see Section "F".

0006190289

REFERENCES

A. Drawings

1. Babcock and Wilcox Drawing 150156E-6 "Assembly and Detail for 2-1/2" Pressure Injection Nozzle"

B. Codes and Specs.

1. General Functional Specifications for Reactor Coolant System Components, CS(F)-3-92/NSS-9/0372.
2. Nuclear Power Piping, USAS B31.7, 1968 Draft.

C. Computer Programs

1. 91167 - "Temperature Distribution"
2. 91032 - "Temperature Interpolation"
3. 169 - "Ring Thermal Stresses"
4. 91079 - "Thermal Stresses and Motions from a Radial Temperature Gradient In a Long Cylinder, Short Cylinder, or Spherical Segment"
5. 91191 - "Annular Plate Thermal Motions"
6. 91060 - "Interaction Analysis"

D. General

1. Tentative Structural Design Basis for Reactor Pressure Vessels, U.S. Department of Commerce, Office of Technical Service.
2. Stress Concentration Design Factors, By R.E. Peterson, John Wiley and Sons, 1966.

0006190290

T.B
6-73


SECTION 1

This section contains a sketch of the make-up nozzle (identical to high pressure injection nozzle) demonstrating dimensions used in the analysis. This sketch appears on Page 1-1. The dimensions with asteriks are those for the NSS-9 nozzle, which are different from those analyzed. The change will have little effect on the final stress results. This reasoning is justified by a review of similar geometry nozzles, using the dimensions with asteriks, which were analyzed for similar thermal transients. The results indicate that a small change in piping dimensions have a negligible effect on the stress levels. The ratio of actual stress to allowable stress for the nozzle to pipe intersection is 0.395 which allows for a reasonable increase in stresses due to a change in geometry.

Stress concentration factors are also determined in this section.

0006190291

J.B.
6-73



STRESS CONCENTRATION FACTO

0006190293

BAECCOCK & WILCOX
DEPARTMENT

BY C. W. ZINN

DATE 11-19-20


STRESS CONCENTRATION FACTORS

JOB NO. 620-0000

PAGE 12

SEGMENT 5
(OUTSIDE)

REF: SEE PAGE 1-10



$t = .375$ $T = .4375$
 $h = .0625$ $\beta = 72^\circ$

$d = 2t = .75$ $D = 2T = .875$

$D/d = 1.167$ $r/d = .167$ $K_o = 1.53$ (TENSION) $K_o = 1$ (BEND)

$\frac{K'-1}{K_o-1} = 1 - \left[\frac{\beta-\alpha}{70-\alpha} \right]^{1+2.4\sqrt{r/h}}$

$\alpha = \sin^{-1} \left[1 - \frac{h}{r} \right] = \sin^{-1} [1 - .5] = 30^\circ$

$K'-1/K_o-1 = 1 - \left[\frac{72}{60} \right]^{1+2.4\sqrt{2}} = .79$


$K'_{TEN} = 1 + 1.53(.79) = 1.42$ OUTSIDE

$K'_{BEN} = 1 + .48(.79) = 1.38$ OUTSIDE

000619291

SEGMENT 15

(INSIDE)



USE SAME REFERENCES AS ON PREVIOUS PAGE

$$h = .119''$$

$$r/d = .3$$

$$T = .869''$$

$$D/d = 1.16$$

$$t = .75''$$

$$r = .5$$

FROM FIG. 57 & 60 OF REF.

$$\beta \approx 72^\circ$$

$$K_o^T = 1.39$$

$$K_o^B = 1.34$$

FROM REF. 1 A.7.2.4-2

$$\left[\frac{K'-1}{K_o-1} \right] = 1 - \left[\frac{\beta-\alpha}{90-\alpha} \right]^{1+2.47\sqrt{r/h}}$$

$$\alpha = \sin^{-1} \left[1 - \frac{h}{r} \right]$$

$$\alpha \approx 49.7^\circ$$

$$\left[\frac{K'-1}{K_o-1} \right] = 1 - [.5533]^{5.92}$$


$$K' = 1 + .97$$

$$\therefore K_o^T = 1.38$$

$$K_o^B = 1.33$$

SEGMENT 26

(OUTSIDE)



$$T = 2.1875''$$

$$t = .75''$$

FROM FIG. A.7-1 OF REF. 1

$$h = 1.438''$$

$$K_o^T = 1.52$$

$$K_o^B = 1.29$$

$$r = .75''$$

$$\beta \approx 70^\circ$$

FROM FIG. A.7-2 OF REF. 1

$$\beta_{90} = .78$$

$$\left[\frac{K'-1}{K_o-1} \right] = .48 \quad K' = 1 + .48(K_o-1)$$

$$r/d = .5 \quad r/t = 1.0$$

$$\therefore K_o^T = 1.25$$

$$K_o^B = 1.14$$

$$D/d = 2.92 \quad r/h = .522$$

BABCOCK & WILCOX

DEPARTMENT

BY C. W. ZIMM

DATE 11-20-7

STRESS CONCENTRATION FACTORS


JOB NO. 620-50

QUEST 1-5

0006190295

SEGMENT, 337

(OUTSIDE)



$t = 2.1875''$
 $r = 1.625''$
 $D = 2T$
 $d = 2t$

$r/t = .74$

FROM FIG. A.7-1 OF REFERENCE 1

$K_o^T = 1.63$

$K_o^B = 1.37$

0006190295

BABCOCK & WILCOX

DEPARTMENT

BY C. W. ZINN


DATE 11-17-57

STRESS CONCENTRATION FACTORS

JOB NO. 20000

SEGMENT 8

(OUTSIDE)



REF: 1. "TENTATIVE STRUCTURAL DESIGN BA FOR REACTOR PRESSURE VESSELS", U.S. DEPT. OF COMMERCE, OFFICE OF TECHNICAL SERVICE.

2. "STRESS CONCENTRATION DESIGN FAC BY R. E. PETERSON


$t = .4375''$ $d = 2t = .875''$
 $T = .75''$ $D = 2T = 1.5''$
 $r = .25''$ $r/d = .286$
 $h = .25''$ $D/d = 1.71$
 $\beta \approx 72^\circ$ $r/h = .8$
 $r/h = 1.0$

FROM REF. 2 FIGURES 57 & 60
 $K_o^T = 1.6$ $K_o^B = 1.36$

FROM REF. 1 FIGURE A.7-2
 $\left[\frac{K'-1}{K_o-1} \right] = .53$ $K' = 1 + .53(K_o-1)$

$\therefore K'_T = 1.32$ $K'_B = 1.19$

(INSIDE)



$t = .4375''$
 $T = .5565''$
 $h = .119''$
 $r = .25''$
 $\beta \approx 72^\circ$

FROM REF. 2 FIGURES 57 & 60
 $K_o^T = 1.48$ $K_o^B = 1.35$

FROM REF. 1 ARTICLE A.7.2.1

FOR $r > h$ $\left[\frac{K'-1}{K_o-1} \right] = 1 - \left[\frac{\theta - \alpha}{90 - \alpha} \right]^{1 + 2.4\sqrt{r/h}}$ where $\alpha = \sin^{-1} \dots$

$r/d = r/2t = .286$
 $D/d = 2T/2t = 1.27$
 $r/h = 2.1$
 $r/h = .8$

$\alpha = 31.5^\circ$ $\left[\frac{K'-1}{K_o-1} \right] = 1 - \left[\frac{72^\circ - 31.5^\circ}{90^\circ - 31.5^\circ} \right]^{4.98}$ $K' = 1 + \dots$

$\therefore K'_T = 1.39$ $K'_B = 1.28$

BABCOCK & WILCOX DEPARTMENT

BY C. W. ZINN

DATE 11-15-57

STRESS CONCENTRATION FACTOR

JOB NO. 620-17

0006190297

SATISFICATION OF PRIMARY STRESS LIMITS

— AT NOZZLE END —

LONGITUDINAL PRESSURE MEMBRANE STRESS

$$= \frac{PR}{2t} = \frac{2500(2.275)}{4(.375)} = 4.8 \text{ KSI} < 1.5S_m @ 650^\circ\text{F} \quad 376 \text{ TR}$$

$$= 1.5(16.6) = 24.9 \text{ KSI}$$

— AT BRANCH INTERSECTION —

CIRCUMFERENTIAL PRESSURE MEMBRANE STRESS IN

$$\text{RUN PIPE} = \frac{PR}{t} = \frac{2500(16.5625)}{2.25} = 18.4 \text{ KSI}$$

$$\text{ALLOWABLE STRESS} = 1.5S_m = 1.5(17.4) = 26.1 \text{ KSI} \quad A-105-$$

$$18.4 \text{ KSI} < 26.1 \text{ KSI}$$

000619 298

BABCOCK & WILCOX DEPARTMENT	DATE 8-29-72	BY <i>ford</i>	REVISION
	CHECKED DATE	BY	
			SHEET 1.7

SECTION 2


This section contains temperature transient analysis of the make-up nozzle. A survey of the functional specification was made and a composite transient curve developed for the cold leg fluid and the make-up fluid. Of primary importance was to select transients which would reflect maximum temperature differentials in the nozzle. This differential is dependent upon temperatures of the corresponding fluid, rates of change of the fluids, and flow rates.

The make-up nozzle has two predominant temperatures 95°F (normal operation and essentially constant for all transients) and 70°F (For the feed and bleed operation). It has a predominant flow rate of 13 GPM but can go as high as 100 GPM or as low as 1.5 GPM. In particular it has a flow rate of 40 GPM during feed and bleed when the fluid temperature is 70°F.

The cold leg fluid goes through several changes in temperature but the most predominant temperatures are 555°F for 8% and 100% power levels and 575°F for 15% power. The temperature does go as high as 590 for the reactor trip.

Consequently the temperature transient curve was made to reflect these variations in fluid temperature and flow rates. The pictorial diagram is shown on the following page.

CUSTOMER:
 SUBJECT: MAKE-UP NOZZLE FLOW TRANSDUCER
 JOB NO.
 DATE
 BY




FILM COEFFICIENTS

OSC. 1522

The film coefficients will be calculated assuming turbulent flow in the cold leg and nozzle. They are calculated for three different cases: 1.) in the cold leg 2.) in the branch pipe and 3.) within the thermal sleeve because of the smaller diameter. In addition the small area of contact of the fluid with the nozzle on the inside of the thermal sleeve ring (see figure on Page 2³ marked Section 3) was assumed to have a film coefficient of 200 BTU/HR-°F-Ft.² when there was a flow in the cold leg run pipe and 100 when there was no flow in the run pipe. The 100 BTU/HR-°F-Ft.² value was also used as a natural convection value for the run pipe (Cold Leg) when there was no flow during cool-down when decay removal starts.

The film coefficient for no flow in the nozzle was assumed to be 35 BTU/HR-°F-Ft.² This smaller value was chosen because of the smaller diameter and that the water would be closer to stagnant within the nozzle. The thermal model of the nozzle includes water blocks behind the sleeve. It is felt that there will be little or no flow behind the sleeve because of the very small gap between the sleeve and nozzle at the top of the nozzle plus the "Vena Contracta" effect of the flow going from a larger diameter to a smaller diameter at the transition from the branch pipe to the nozzle. Thus only conduction is assumed between the sleeve and the inside of nozzle. At Section 4 metal to metal conduction is assumed but a contact resistance coefficient of 100 BTU/HR-°F-Ft.². This value results in essentially metal to metal conduction. The rolled-in portion of sleeve is assumed to have metal to metal conduction even though a small gap may exist at certain times within the transient.

0006190302



THERMAL SLEEVE GEOMETRY

BABCOCK & WILCOX

DEPARTMENT

BY C.W. ZIMM

DATE 3/21/51

GEOMETRY FOR FILM COEFFICIENTS

JOB NO. 600-1

FILM COEFFICIENTS

NOZZLE OUTSIDE SLEEVE

FLOW (GPM)	AD^2	$D^2 = .71$	h BTU / HR-FT ² -°F
	FROM GRAPH (FOLLOWING FRSE)		
20	290		410
1.5	35		50
13	210		300
40	520		730
100	1100		1550

0 BECAUSE OF LOW TEMPERATURE OF WATER AND THE SMALL DIAMETER A SMALL VALVE FOR NATURAL CONVECTION WILL BE USED 35

NOZZLE INSIDE SLEEVE

		$D^2 = .66$	h
1.5	65		100
13	350		530
40	880		1330
100	1800		2730
0	-		35
20	520		790

INLET PIPE

		$D^2 = 1.18$	
43,750	3500		3000
82,000	7000		5900
40,000	3800		3200
0			100

BECAUSE OF LARGER DIAMETER NATURAL CONVECTION VALVE OF 100 WILL BE USED

BABCOCK & WILCOX

DEPARTMENT _____

BY _____

DATE _____

TABULATION OF FILM COEFFICIENTS

JOB NO. _____

0006190303

FILM COEFFICIENTS

CONVERSION FROM GAL/MIN TO LBS/FT²-HR.

$$\text{LBS/FT}^2\text{-HR} = (\text{GAL./MIN}) \times (60 \text{ MIN/HR}) \times (8.347 \text{ LBS/GAL}) / \text{AREA}$$

SECTION 5 AREA INLET = $\pi(14)^2 = 615.75 \text{ IN}^2$ OR 4.28 FT²
 SECTION 1 (WITHOUT SLEEVE) AREA H.P.I. = $\pi(1.0625)^2 = 3.547 \text{ IN}^2$ OR .025 FT²
 SECTION 2 (WITH SLEEVE) AREA H.P.I. = $\pi(.75)^2 = 1.767 \text{ IN}^2$ OR .0123 FT²

SECTION 1 OUTSIDE SLEEVE H.P.I. NOZZLE FLOW SECTION 2 INSIDE SLEEVE

259090 @ x 13 GPM x 40,510⁺ = 526,630 LBS/FT²-HR
 777200 @ x 40 GPM x 40,510⁺ = 1,620,400 LBS/FT²-HR
 1973000 @ x 100 GPM x 40,510⁺ = 4,051,000 LBS/FT²-HR
 29895 @ x 1.5 GPM x 40,510⁺ = 60,770 LBS/FT²-HR
 378,600 @ x 20 GPM x 40,510 = 310,200 "

INLET PIPE FLOW SECTION 5

310°F 43,750 GPM x 107.0^{*} = 4,681,250 LBS/FT²-HR
 575°F 68,000 GPM x 83.4 = 7,339,755 LBS/FT²-HR
 400°F 40,000 GPM x 99.7 = 3,988,000 LBS/FT²-HR

CONVERSION COEFFICIENTS

@ 95°F † (60 MIN/HR)(8.304 LBS/GAL) / (.0123 FT²) = 40,510 LBS-MIN/HR-GAL
 @ 95°F @ (60 MIN/HR)(8.304 LBS/GAL) / (.025 FT²) = 19,930 LB-MIN/HR-GAL
 AT 310 ° * (60 MIN/HR)(7.618 LBS/GAL) / (4.28 FT²) = 107 LBS-MIN/HR-GAL


REYNOLD'S NUMBER FOR 29895 LBS/FT²HR FLOW

$$Re = \frac{GD}{12\mu} = \frac{(29895)(10.13)}{(2)(1.25)} = 2862 > 2100 \text{ THEREFORE}$$

GRAPH ON THE FOLLOWING PAGE IS ACCEPTABLE FOR ALL THE FLOW CONDITIONS

BABCOCK & WILCOX	BY C. W. ZINN	DATE 11-18-70
DEPARTMENT		JOB NO. 620-000
FILM COEFFICIENTS		SHEET 2-5 OF

0006190304



$$G = \frac{\text{LB.}}{\text{FT.}^2 \cdot \text{HR.}}$$

WATER FILM COEFFICIENT FOR REYNOLDS NUMBERS ABOVE 2100 FROM H.T. 41-1

Job No. DD-2
MANUAL-2A35

TEMPERATURE DISTRIBUTION

The temperature distribution of the nozzle was obtained using B&W Thermal Program 91167 which performs a transient temperature distribution by solving internally generated heat balance equations as a function of time.

The grid for this program is shown on Page 2-8 and the computer output which follows depicts the input items. A heat balance equation sample is shown on pages 2-15, 2-17.

Pages 2-20, 2-22 show a graphical representation, temperatures vs. time, of selected nodes and this is finally followed by the computer print-out giving the actual temperatures at the selected critical times for stress analysis.


0006190305

0006190307

200



199



Column	MEAN RADIUS	WIDTH
1	.8125	.125
2	.9375	.125
3	1.0625	.125
4	1.203125	.15625
5	1.359375	.15625
6	1.59375	.3125
7	1.9297	.3594
8	2.2891	.3594
9	2.6485	.2594
10	3.0079	.2594
11	3.4376	.5
12	4.0626	.75
13	4.9376	1.0
14	6.6376	2.5

EDGE	HEIGHT	EDGE	HEIGHT	EDGE
1	1.5	10	.977	19
2	1.0	11	.977	20
3	.5	12	.977	21
4	.25	13	.977	22
5	.675	14	.9675	23
6	.675	15	.625	24
7	.675	16	.625	25
8	.675	17	.625	26
9	.675	18	.625	

Segment 33 of 91206 model

1	6	3	6	6	2	1	3	4	4	5	1	5	1	6	4	1	7	2	1	7	7	182	187	192
18	153	62	381																					
198	19	7	0	1	6	1	2	2	4	7	1	5	1	6	1	7	1	8				186	191	196

197

BABCOCK & WILCOX

DEPARTMENT

BY

DATE

HPI NOZZLE THERMAL GRID

JOB NO.

SHEET 2-8

NO SOLID BLOCKS
196

NO FLUID BLOCKS
4

NO OF EDGES
26

NO OF LINES
14

NO OF CYCLES
8

BASE TEMP
300.0

STARTING TEMP
70.0

STARTING TIME
0.00000

STARTING ITER
0

PUNCH CARD TIME
0.00000

TIME IS IN HOURS

GEOMETRY OF THE COLUMNS

ROW NO	BLOCK NO.			RADIAL DIMS	MEAN RADIUS	LOW EDGE NO	ROW NO	BLOCK NO.			RADIAL DIMS	MEAN RADIUS	LOW EDGE NO
	LOW	HI	ADJ					LOW	HI	ADJ			
1	1	18	16	.12500	.81250	7	2	19	38	36	.12500	.93750	5
3	39	64	60	.12500	1.06250	1	4	65	90	86	.15625	1.20313	1
5	91	116	112	.15625	1.35938	1	5	117	138	134	.31250	1.59375	5
7	139	149	145	.35940	1.92970	16	8	150	159	155	.35940	2.28910	17
9	150	168	164	.35940	2.64850	18	10	169	176	172	.35940	3.00790	19
11	177	181	177	.50000	3.43760	22	12	182	186	182	.75000	4.06260	22
13	187	191	187	1.00000	4.93760	22	14	192	196	192	2.50000	6.08760	22

SERIES NO.	BLOCK NO. FLUID FIRST LAST	SIDE NO.	SERIES NO.	BLOCK NO. FLUID FIRST LAST	SIDE NO.	SERIES NO.	BLOCK NO. FLUID FIRST LAST	SIDE NO.
1	197 66 68	2	2	197 90	2	3	197 116 118	2
4	197 135 138	2	5	197 149 149	2	6	197 159 159	2
7	197 168 168	2	8	197 176 176	2	9	197 181 181	2
10	197 186 186	2	11	197 191 191	2	12	197 196 196	2
13	198 63 64	1	14	198 18 18	2	15	198 38 38	2
16	199 1 18	1	17	200 19 20	1	18	200 1 1	4
19	200 19 19	4	20	200 39 42	1			

AXIAL DIMENSION PER EDGE


EDGE	DIMENSION	EDGE	DIMENSION	EDGE	DIMENSION	EDGE	DIMENSION	EDGE	DIMENSION	EDGE	DIMENSION
1	1.50000	2	1.00000	3	.50000	4	.25000	5	.67500	6	.67500
7	.67500	8	.67500	9	.67500	10	.47900	11	.47900	12	.47900
13	.96875	14	.96875	15	.62500	16	.62500	17	.62500	18	.62500
19	1.25000	20	1.25000	21	1.25000	22	.37500	23	.37500	24	.50000
25	.50000	26	.50000								

CONDUCTANCE OF TWO ADJACENT BLOCKS WITHOUT COMPLETE BOND - NO OF SUBDIVISIONS 2

FIRST BLOCK NO.	LAST BLOCK NO.	ADDED CONDUCT H	BLOCK SIDE	FIRST BLOCK NO.	LAST BLOCK NO.	ADDED CONDUCT H	BL S)
38	38	100.000	3	62	62	100.000	

MATERIAL NO	LAST BLOCK	MATERIAL NO	LAST BLOCK	MATERIAL NO	LAST BLOCK	MATERIAL NO	LAST BLOCK	MATERIAL NO	LAST BLOCK
4	10	4	76	1	102	1	110	4	10
1	196								

FLUID BLOCK	FILM COEF.							
197	3000.00	5900.00	5900.00	5900.00	5900.00	5900.00	3200.00	100.00
198	200.00	200.00	200.00	200.00	200.00	200.00	200.00	100.00
199	790.00	100.00	530.00	1330.00	530.00	100.00	2730.00	35.00
200	410.00	50.00	300.00	730.00	300.00	50.00	1550.00	35.00
	↑ to 3.2 based on make-up flow of 20 gpm	↑ to 4.95 based on 1.5 gpm	↑ to 10.0 based on 13. gpm	↑ to 14.0 based on 40 gpm	↑ to 16.0 based on 13 gpm	↑ to 16.2 based on 1.5 gpm	↑ to 19.15 based on 100. gpm	↑ to 22.4



3.8
22.40

4.95000

10.00000

14.00000

18.00000

19.20000

22.40000

0 0 0 6 1 9 0 3 1 1

TIMES FOR PRINTOUT	
TIME LIMIT	TIME MULTIPLE
3.50000	.50000
4.00000	.05000
5.00000	.25000
5.20000	.00833
7.50000	.46000
7.70000	.00833
10.00000	.46000
10.20000	.00278
14.00000	.38000
14.20000	.00278
16.00000	1.10000
16.40000	.00278
18.00000	.16000
19.15000	.57500
19.35000	.00278
22.40000	.31500

TIME	0.0000	10.10000	10.10000	13.90000	13.90000	19.20000	19.20000	22.40000	-99.99000
TEMP	95.00000	95.00000	70.00000	70.00000	95.00000	95.00000	280.00000	150.00000	150.00000

POINT NO. 200

TYPE 1

TIME	0.00000	10.10000	10.10000	13.90000	13.90000	19.20000	19.20000	22.40000	-99.99000
TEMP	95.00000	95.00000	70.00000	70.00000	95.00000	95.00000	280.00000	150.00000	150.00000

PI 6

0	1	1.0	.143	199	.009	2	.282	21	.010	200	.557	1
0	2	1.0	.143	199	.009	3	.282	22	.009	1	.557	2
0	3	1.0	.143	199	.010	4	.282	23	.009	2	.556	3
0	4	1.0	.143	199	.018	5	.022	24	.015	3	.802	4
0	5	1.0	.143	199	.018	6	.022	25	.018	4	.799	5
0	6	1.0	.143	199	.012	7	.022	26	.018	5	.865	6
0	7	1.0	.143	199	.004	8	.022	27	.005	6	.825	7
0	8	1.0	.143	199	.005	9	.022	28	.004	7	.825	8
0	9	1.0	.143	199	.010	10	.022	29	.005	8	.816	9
0	10	1.0	.143	199	.010	11	.022	30	.010	9	.814	10
0	11	1.0	.143	199	.010	12	.022	31	.010	10	.814	11
0	12	1.0	.143	199	.007	13	.022	32	.010	11	.817	12
0	13	1.0	.143	199	.003	14	.022	33	.003	12	.829	13
0	14	1.0	.143	199	.003	15	.022	34	.003	13	.829	14
0	15	1.0	.143	199	.004	16	.022	35	.003	14	.828	15
0	16	1.0	.143	199	.029	17	.022	36	.013	15	.792	16
0	17	1.0	.143	199	.025	18	.022	37	.029	16	.781	17
0	18	1.0	.143	199	.010	19	.282	38	.019	17	.547	18
0	19	1.0	.088	200	.009	20	.279	43	.010	200	.615	19
0	20	1.0	.088	200	.009	21	.279	44	.009	19	.616	20
0	21	1.0	.244	1	.009	22	.279	45	.009	20	.459	21
0	22	1.0	.244	2	.009	23	.279	46	.009	21	.459	22
0	23	1.0	.244	3	.001	24	.279	47	.009	22	.467	23
0	24	1.0	.019	4	.001	25	.022	48	.001	23	.956	24
0	25	1.0	.019	5	.001	26	.022	49	.001	24	.957	25
0	26	1.0	.019	6	.000	27	.022	50	.001	25	.957	26
0	27	1.0	.019	7	.000	28	.022	51	.000	26	.958	27
0	28	1.0	.019	8	.000	29	.022	52	.000	27	.958	28
0	29	1.0	.019	9	.000	30	.022	53	.000	28	.958	29
0	30	1.0	.019	10	.000	31	.022	54	.000	29	.957	30
0	31	1.0	.019	11	.000	32	.022	55	.000	30	.957	31
0	32	1.0	.019	12	.000	33	.022	56	.000	31	.958	32
0	33	1.0	.019	13	.000	34	.022	57	.000	32	.958	33
0	34	1.0	.019	14	.000	35	.022	58	.000	33	.958	34
0	35	1.0	.019	15	.000	36	.022	59	.000	34	.958	35
0	36	1.0	.019	16	.001	37	.022	60	.001	35	.957	36
0	37	1.0	.019	17	.002	38	.022	61	.001	36	.955	37
0	38	1.0	.244	18	.010	39	.027	62	.002	37	.718	38
0	39	1.0	.088	200	.002	40	.246	65	.663	39		39
0	40	1.0	.088	200	.005	41	.246	66	.003	39	.657	40

0	41	1.0
0	42	1.0
0	43	1.0
0	44	1.0
0	45	1.0
0	46	1.0
0	47	1.0
0	48	1.0
0	49	1.0
0	50	1.0
0	51	1.0
0	52	1.0
0	53	1.0
0	54	1.0
0	55	1.0
0	56	1.0
0	57	1.0
0	58	1.0
0	59	1.0
0	60	1.0
0	61	1.0
0	62	1.0
0	63	1.0
0	64	1.0
0	65	1.0
1	66	1.0
0	67	1.0
0	68	1.0
0	69	1.0
0	70	1.0
0	71	1.0
1	72	1.0
0	73	1.0
0	74	1.0
0	75	1.0
0	76	1.0
0	77	1.0
0	78	1.0
0	79	1.0
0	80	1.0
0	81	1.0

.088	290	.022	42	.246	67	.011	70	.555	42
.088	200	.035	43	.246	68	.044	41	.587	42
.246	19	.009	44	.246	69	.013	42	.486	4
.246	20	.009	45	.246	70	.009	43	.490	44
.246	21	.009	46	.246	71	.009	44	.490	45
.246	22	.009	47	.246	72	.009	45	.490	46
.246	23	.010	48	.246	73	.009	46	.488	47
.019	24	.018	49	.246	74	.015	47	.702	48
.019	25	.018	50	.246	75	.018	48	.699	49
.019	26	.012	51	.246	76	.018	49	.705	50
.019	27	.004	52	.390	77	.006	50	.580	51
.019	28	.005	53	.390	78	.004	51	.581	52
.019	29	.010	54	.390	79	.008	52	.572	53
.019	30	.010	55	.390	80	.010	53	.570	54
.019	31	.010	56	.390	81	.010	54	.570	55
.019	32	.007	57	.390	82	.010	55	.573	56
.019	33	.003	58	.390	83	.003	56	.584	57
.019	34	.003	59	.390	84	.003	57	.585	58
.019	35	.004	60	.390	85	.003	58	.584	59
.019	36	.029	61	.390	86	.013	59	.548	60
.019	37	.025	62	.390	87	.029	60	.536	61
.024	38	.016	63	.390	88	.019	61	.551	62
.047	198	.016	64	.390	89	.016	62	.530	63
.047	198	.026	197	.390	90	.016	63	.518	64
.174	39	.002	66	.178	91	.646	65		66
.174	40	.005	67	.178	92	.003	65	.639	66
.174	41	.022	68	.178	93	.011	66	.615	67
.174	42	.035	69	.178	94	.044	67	.569	68
.174	43	.009	70	.178	95	.013	68	.626	69
.174	44	.009	71	.178	96	.009	69	.630	70
.174	45	.009	72	.178	97	.009	70	.630	71
.174	46	.009	73	.178	98	.009	71	.630	72
.174	47	.010	74	.178	99	.009	72	.629	73
.174	48	.018	75	.178	100	.015	73	.615	74
.174	49	.018	76	.178	101	.018	74	.612	75
.174	50	.021	77	.178	102	.018	75	.609	76
.280	51	.013	78	.541	103	.011	76	.155	77
.280	52	.016	79	.541	104	.013	77	.150	78
.280	53	.032	80	.541	105	.025	78	.123	79
.280	54	.032	81	.541	106	.032	79	.116	80
.280	55	.032	82	.541	107	.032	80	.116	81

0	82	1.0	.280	56	.021	83	.541	108	.052	81	.160	82
0	83	1.0	.280	57	.018	84	.541	109	.011	82	.161	83
0	84	1.0	.280	58	.008	85	.541	110	.008	83	.163	84
0	85	1.0	.280	59	.012	86	.541	111	.008	84	.159	85
0	86	1.0	.280	60	.088	87	.541	112	.041	85	.050	86
0	87	1.0	.280	61	.076	88	.541	113	.088	86	.015	87
0	88	1.0	.280	62	.050	89	.541	114	.057	87	.073	88
0	89	1.0	.280	63	.050	90	.541	115	.050	88	.080	89
0	90	1.0	.280	64	.068	91	.541	116	.050	89	.062	90
0	91	1.0	.158	65	.002	92	.840	91				
0	92	1.0	.158	66	.005	93	.003	91	.834	92		
0	93	1.0	.158	67	.022	94	.011	92	.810	93		
0	94	1.0	.158	68	.035	95	.044	93	.753	94		
0	95	1.0	.158	69	.009	96	.118	117	.013	94	.702	95
0	96	1.0	.158	70	.009	97	.118	118	.009	95	.706	96
0	97	1.0	.158	71	.009	98	.118	119	.009	96	.706	97
0	98	1.0	.158	72	.009	99	.118	120	.009	97	.706	98
0	99	1.0	.158	73	.010	100	.118	121	.009	98	.705	99
0	100	1.0	.158	74	.018	101	.118	122	.015	99	.692	100
0	101	1.0	.158	75	.018	102	.118	123	.018	100	.689	101
1	102	1.0	.158	76	.021	103	.118	124	.018	101	.685	102
0	103	1.0	.478	77	.013	104	.358	125	.011	102	.140	103
0	104	1.0	.478	78	.016	105	.358	126	.013	103	.134	104
0	105	1.0	.478	79	.032	106	.358	127	.025	104	.107	105
1	106	1.0	.478	80	.032	107	.358	128	.032	105	.100	106
0	107	1.0	.478	81	.032	108	.358	129	.032	106	.100	107
0	108	1.0	.478	82	.021	109	.358	130	.032	107	.111	108
0	109	1.0	.478	83	.008	110	.358	131	.011	108	.145	109
0	110	1.0	.478	84	.008	111	.358	132	.008	109	.148	110
0	111	1.0	.478	85	.012	112	.358	133	.008	110	.144	111
0	112	1.0	.478	86	.088	113	.358	134	.041	111	.035	112
0	113	1.0	.478	87	.076	114	.358	135	.088	112	.000	113
0	114	1.0	.478	88	.050	115	.358	136	.057	113	.057	114
0	115	1.0	.478	89	.050	116	.358	137	.050	114	.065	115
0	116	1.0	.478	90	.068	117	.358	138	.050	115	.046	116
0	117	1.0	.050	95	.009	118	.941	117				
0	118	1.0	.050	96	.009	119	.009	117	.932	118		
0	119	1.0	.050	97	.009	120	.009	118	.932	119		
0	120	1.0	.050	98	.009	121	.009	119	.932	120		
0	121	1.0	.050	99	.010	122	.009	120	.930	121		
0	122	1.0	.050	100	.018	123	.015	121	.917	122		

0 123 1.0
 0 124 1.0
 0 125 1.0
 0 126 1.0
 0 127 1.0
 0 128 1.0
 0 129 1.0
 0 130 1.0
 0 131 1.0
 0 132 1.0
 0 133 1.0
 0 134 1.0
 0 135 1.0
 0 136 1.0
 0 137 1.0
 0 138 1.0
 0 139 1.0
 0 140 1.0
 0 141 1.0
 0 142 1.0
 1 143 1.0
 0 144 1.0
 0 145 1.0
 0 146 1.0
 0 147 1.0
 0 148 1.0
 0 149 1.0
 0 150 1.0
 0 151 1.0
 0 152 1.0
 0 153 1.0
 0 154 1.0
 0 155 1.0
 1 156 1.0
 0 157 1.0
 0 158 1.0
 0 159 1.0
 0 160 1.0
 0 161 1.0
 0 162 1.0
 0 163 1.0

.050 101
 .050 102
 .153 103
 .153 104
 .153 105
 .153 106
 .153 107
 .153 108
 .153 109
 .153 110
 .153 111
 .153 112
 .153 113
 .153 114
 .153 115
 .153 116
 .093 128
 .093 129
 .093 130
 .093 131
 .093 132
 .093 133
 .093 134
 .093 135
 .093 136
 .093 137
 .093 138
 .088 140
 .088 141
 .088 142
 .088 143
 .088 144
 .088 145
 .088 146
 .088 147
 .088 148
 .088 149
 .089 151
 .089 152
 .089 153
 .089 154

.010 121
 .821 122
 .013 123
 .016 124
 .032 128
 .032 129
 .032 130
 .021 131
 .008 132
 .008 133
 .012 134
 .088 135
 .076 136
 .050 137
 .050 138
 .068 139
 .032 140
 .032 141
 .021 142
 .008 143
 .008 144
 .012 145
 .088 146
 .076 147
 .050 148
 .050 149
 .068 197
 .032 151
 .021 152
 .008 153
 .008 154
 .012 155
 .088 156
 .076 157
 .050 158
 .050 159
 .068 197
 .021 161
 .008 162
 .008 163
 .012 164

.018 123
 .031 124
 .013 125
 .025 126
 .130 139
 .130 140
 .130 141
 .130 142
 .130 143
 .130 144
 .130 145
 .130 146
 .130 147
 .130 148
 .130 149
 .875 139
 .165 150
 .105 151
 .105 152
 .105 153
 .105 154
 .105 155
 .105 156
 .105 157
 .105 158
 .105 159
 .880 150
 .103 160
 .103 161
 .103 162
 .103 163
 .103 164
 .103 165
 .103 166
 .103 167
 .103 168
 .889 160
 .102 169
 .102 170
 .102 171

.911 124
 .824 125
 .818 126
 .791 127
 .032 127
 .032 128
 .032 129
 .011 130
 .008 131
 .008 132
 .041 133
 .088 134
 .057 135
 .050 136
 .050 137
 .032 139
 .032 140
 .011 141
 .008 142
 .008 143
 .041 144
 .088 145
 .057 146
 .050 147
 .050 148
 .032 150
 .011 151
 .008 152
 .008 153
 .041 154
 .088 155
 .057 156
 .050 157
 .050 158
 .011 160
 .008 161
 .008 162


.654 128
 .654 129
 .665 130
 .699 131
 .702 132
 .698 133
 .589 134
 .554 135
 .612 136
 .619 137
 .601 138
 .739 140
 .749 141
 .784 142
 .766 143
 .782 144
 .673 145
 .638 146
 .696 147
 .703 148
 .685 149
 .755 151
 .790 152
 .792 153
 .788 154
 .679 155
 .644 156
 .702 157
 .709 158
 .691 159
 .790 161
 .792 162
 .788 163

0	164	0	.089	155	0	.088	165	.102	172	.041	163	.679	164
0	165	0	.089	156	0	.076	166	.302	173	.088	164	.644	165
0	166	0	.089	157	0	.050	167	.102	174	.057	165	.702	166
0	167	1.0	.089	158	0	.050	168	.102	175	.050	166	.709	167
0	168	1.0	.089	159	0	.068	169	.102	176	.050	167	.691	168
0	169	1.0	.090	161	0	.008	170	.902	169				
0	170	1.0	.090	162	0	.008	171	.008	169	.894	170		
0	171	1.0	.090	163	0	.012	172	.008	170	.890	171		
0	172	1.0	.090	164	0	.088	173	.085	177	.041	171	.696	172
0	173	1.0	.090	165	0	.076	174	.085	178	.088	172	.661	173
0	174	1.0	.090	166	0	.050	175	.085	179	.057	173	.719	174
0	175	1.0	.090	167	0	.050	176	.085	180	.050	174	.726	175
0	176	1.0	.090	168	0	.068	177	.085	181	.050	175	.708	176
0	177	1.0	.053	172	0	.088	178	.043	182	.816	177		
0	178	1.0	.053	173	0	.076	179	.043	183	.088	177	.740	178
0	179	1.0	.053	174	0	.050	180	.043	184	.057	178	.798	179
0	180	1.0	.053	175	0	.050	181	.043	185	.050	179	.805	180
0	181	1.0	.053	176	0	.068	177	.043	186	.050	180	.787	181
0	182	1.0	.024	177	0	.088	183	.021	187	.867	182		
0	183	1.0	.024	178	0	.076	184	.021	188	.088	182	.792	183
0	184	1.0	.024	179	0	.050	185	.021	189	.057	183	.849	184
0	185	1.0	.024	180	0	.050	186	.021	190	.050	184	.856	185
0	186	1.0	.024	181	0	.068	177	.021	191	.050	185	.838	186
0	187	1.0	.013	182	0	.088	183	.008	192	.891	187		
0	188	1.0	.013	183	0	.076	189	.008	193	.088	187	.816	188
1	189	1.0	.013	184	0	.050	190	.008	194	.057	188	.873	189
0	190	1.0	.013	185	0	.050	191	.008	195	.050	189	.880	190
0	191	1.0	.013	186	0	.068	197	.008	196	.050	190	.862	191
0	192	1.0	.002	187	0	.088	193	.910	192				
0	193	1.0	.002	188	0	.076	194	.088	192	.834	193		
0	194	1.0	.002	189	0	.050	195	.057	193	.891	194		
0	195	1.0	.002	190	0	.050	196	.050	194	.899	195		
0	196	1.0	.002	191	0	.058	197	.050	195	.880	196		
0	197	1.0	1.000	197									
0	198	1.0	1.000	198									
0	199	1.0	1.000	199									
0	200	1.0	1.000	200									

DELTA THETA = 1.738E-04HRS/ITER

BLOCK 113



0006190319



CUSTOMER	JOB No.
SUBJECT	BY
DATE	

0 0 0 6 1 9 0 3 2 0

OSC 1522



CUSTOMER

SUBJECT

JOB NO.

BY

DATE

5-21 KBJ

CUSTOMER

JOB NO.


SUBJECT *TEST OF RIG FIVE TWIN*

TO MAKE UP TRANSDUCERS

BY

DATE

600 550 500 450 400 350 300 250 200 100 70



182	62
182	60

0006190321

TIME (SCALE CHANGED) 11.5

19.5
20 21 22 23

SELECTION OF CRITICAL TIMES

After a study of the preceding graphs the following times were chosen for stress analysis:

<u>ITERATION (TIME, HRS.)</u>	<u>EXPLANATION</u>
28169 (4.95)	This reflects a time near the end of heat-up to 15% power and is essentially equivalent to one of the worst axial gradient cases at 15% power.
41428 (7.5)	Steady state at 15% power. This reflects hottest cold leg temperature for a prolonged time.
52659 (9.66)	Reflects steady state distribution at 8% or 100% power.
75168 (13.9)	Reflects axial gradient at end of feed and bleed.
86960 (16.099)	Reflects maximum temperature of cold leg when trip initiates.
103154 (19.2)	Reflects short time after decay heat removal initiates and a reversal in axial gradient.

The stress analysis of these cases should define an assurance of stress levels in the nozzle and ranges in stress levels such that fatigue criteria can be justified. This will be discussed further in the stress computations portion.

000619322

28169	109	116	120	0	0	0	119	0	3	2	137	147	157	166	
28169	176	180	189	200	214	236	214	236	266	362	362	362	103	106	4.95009
28169	21	110	118	129	139	157	157	167	186	206	206	206	228	247	4.95009
28169	31	263	276	293	315	343	343	369	389	385	385	385	96	97	4.95009
28169	41	99	101	103	107	111	111	126	132	157	157	157	178	201	4.95009
28169	51	229	258	290	319	341	341	368	384	417	417	417	456	485	4.95009
28169	61	499	514	550	566	566	566	566	566	566	566	566	566	566	4.95009
28169	71	112	121	135	158	180	180	204	232	261	261	261	293	322	4.95009
28169	81	345	364	389	422	461	461	491	505	521	521	521	548	565	4.95009
28169	91	96	97	99	101	104	104	104	113	122	122	122	137	160	4.95009
28169	101	181	207	233	261	294	294	325	348	366	366	366	391	424	4.95009
28169	111	464	494	508	524	547	547	555	105	108	108	108	114	123	4.95009
28169	121	139	161	183	208	233	233	257	296	328	328	328	351	370	4.95009
28169	131	394	427	468	498	512	512	528	548	565	565	565	335	356	4.95009
28169	141	374	398	431	472	503	503	517	532	549	549	549	565	362	4.95009
28169	151	379	401	434	476	508	508	522	536	551	551	551	566	384	4.95009
28169	161	404	436	478	514	527	527	540	554	567	567	567	407	437	4.95009
28169	171	480	522	534	545	557	557	568	540	544	544	544	551	560	4.95009
28169	181	569	552	554	558	564	564	570	561	562	562	562	564	567	4.95009
28169	191	572	567	568	569	571	571	573	575	575	575	575	95	95	4.95009

40700	1	100	105	0	100	100	103	106	109	113	116	7.36006
40700	11	118	109	102	120	120	124	146	220	96	97	7.36006
40700	21	99	109	102	120	120	144	160	177	196	214	7.36006
40700	31	228	254	239	274	274	316	324	258	95	95	7.36006
40700	41	95	96	96	97	97	104	113	138	157	179	7.36006
40700	51	206	269	235	299	299	343	369	404	444	474	7.36006
40700	61	487	546	498	566	566	95	95	96	96	98	7.36006
40700	71	100	116	105	139	139	183	209	238	272	303	7.36006
40700	81	328	375	348	410	410	481	495	510	544	565	7.36006
40700	91	95	95	95	96	96	98	101	107	119	140	7.36006
40700	101	161	210	185	239	239	306	331	351	378	413	7.36006
40700	111	455	499	485	516	516	564	57	98	101	108	7.36006
40700	121	121	162	141	187	187	240	275	310	335	355	7.36006
40700	131	582	460	418	491	491	522	545	564	318	341	7.36006
40700	141	361	422	387	466	466	513	529	548	565	348	7.36006
40700	151	366	426	391	471	471	519	535	551	566	372	7.36006
40700	161	394	474	428	512	512	540	554	567	397	430	7.36006
40700	171	476	534	522	546	546	568	541	546	553	561	7.36006
40700	181	570	557	555	561	561	571	565	566	567	570	7.36006
40700	191	573	572	572	573	573	574	575	575	95	95	7.36006

41428	1	98	105	100	100	100	103	106	109	113	116	7.50007
41428	11	118	123	120	126	126	134	146	220	96	97	7.50007
41428	21	99	109	102	120	120	144	160	177	196	214	7.50007
41428	31	228	254	239	274	274	316	324	258	95	95	7.50007
41428	41	95	96	95	97	97	104	113	138	157	179	7.50007
41428	51	206	269	235	299	299	343	369	404	444	474	7.50007
41428	61	487	546	498	566	566	95	95	96	96	98	7.50007
41428	71	100	116	105	139	139	183	209	238	272	303	7.50007
41428	81	328	375	348	410	410	481	495	510	544	565	7.50007
41428	91	95	95	95	96	96	98	101	107	119	140	7.50007
41428	101	161	210	185	239	239	306	331	351	378	413	7.50007
41428	111	455	499	485	516	516	564	57	98	101	108	7.50007
41428	121	121	162	141	187	187	240	275	310	335	355	7.50007
41428	131	382	460	418	491	491	522	545	564	318	341	7.50007
41428	141	361	422	387	466	466	513	529	548	565	368	7.50007
41428	151	366	426	391	471	471	519	535	551	566	372	7.50007
41428	161	394	474	428	512	512	540	554	567	397	430	7.50007
41428	171	476	534	522	546	546	568	541	546	553	561	7.50007
41428	181	570	557	555	561	561	571	565	566	567	570	7.50007
41428	191	573	572	572	573	573	574	575	575	95	95	7.50007

50268	11	117	119	101	100	101	103	106	109	112	115	9.20019
50268	21	98	102	109	109	109	142	143	214	96	97	9.20019
50268	31	222	233	248	267	290	307	315	173	192	209	9.20019
50268	41	95	96	96	97	99	104	112	251	95	95	9.20019
50268	51	202	229	261	291	314	333	358	136	155	176	9.20019
50268	61	471	481	527	546	95	95	95	391	430	458	9.20019
50268	71	100	105	115	137	156	179	204	96	96	98	9.20019
50268	81	318	338	363	397	436	465	478	232	265	295	9.20019
50268	91	95	95	95	96	96	98	101	493	525	545	9.20019
50268	101	158	181	205	233	266	297	321	106	118	138	9.20019
50268	111	440	469	482	498	525	545	97	340	366	400	9.20019
50268	121	120	140	159	183	206	234	268	98	101	107	9.20019
50268	131	370	404	445	475	488	505	526	301	325	344	9.20019
50268	141	350	375	409	451	481	495	511	545	309	331	9.20019
50268	151	355	379	412	455	488	502	516	529	545	337	9.20019
50268	161	382	414	458	495	508	521	532	532	546	360	9.20019
50268	171	460	504	516	527	538	549	535	548	385	416	9.20019
50268	181	550	536	538	541	546	552	522	527	533	542	9.20019
50268	191	553	552	552	553	554	554	545	546	548	550	9.20019
								555	555	95	95	

52659	1	97	100	104	100	101	103	106	109	112	115	9.66003
52659	11	117	119	121	125	128	133	143	214	96	97	9.66003
52659	21	98	102	109	119	130	142	157	173	192	209	9.66003
52659	31	222	233	248	267	290	307	315	173	192	209	9.66003
52659	41	95	96	96	97	99	104	112	251	95	95	9.66003
52659	51	202	229	261	291	314	333	358	136	155	176	9.66003
52659	61	471	481	527	546	95	95	95	391	430	458	9.66003
52659	71	100	105	115	137	156	179	204	96	96	98	9.66003
52659	81	318	338	363	397	436	465	478	232	265	295	9.66003
52659	91	95	95	95	96	96	98	101	493	525	545	9.66003
52659	101	158	181	205	233	266	297	321	106	118	138	9.66003
52659	111	440	469	482	498	525	545	97	340	366	400	9.66003
52659	121	120	140	159	183	206	234	268	98	101	107	9.66003
52659	131	370	404	445	475	488	505	526	301	325	344	9.66003
52659	141	350	375	409	451	481	495	511	545	309	331	9.66003
52659	151	355	379	412	455	488	502	516	529	545	337	9.66003
52659	161	382	414	458	495	508	521	532	532	546	360	9.66003
52659	171	460	504	516	527	538	549	535	548	385	416	9.66003
52659	181	550	536	538	541	546	552	522	527	533	542	9.66003
52659	191	553	552	552	553	554	554	545	546	548	550	9.66003
								555	555	95	95	

75168		83	84	86	88	90	92	94	96	98	100	102	104	106	108	110	112	114	116	118	120	122	124	126	128	130	132	134	136	138	140	142	144	146	148	150	152	154	156	158	160	162	164	166	168	170	172	174	176	178	180	182	184	186	188	190	192	194	196	198	200	202	204	206	208	210	212	214	216	218	220	222	224	226	228	230	232	234	236	238	240	242	244	246	248	250	252	254	256	258	260	262	264	266	268	270	272	274	276	278	280	282	284	286	288	290	292	294	296	298	300	302	304	306	308	310	312	314	316	318	320	322	324	326	328	330	332	334	336	338	340	342	344	346	348	350	352	354	356	358	360	362	364	366	368	370	372	374	376	378	380	382	384	386	388	390	392	394	396	398	400	402	404	406	408	410	412	414	416	418	420	422	424	426	428	430	432	434	436	438	440	442	444	446	448	450	452	454	456	458	460	462	464	466	468	470	472	474	476	478	480	482	484	486	488	490	492	494	496	498	500	502	504	506	508	510	512	514	516	518	520	522	524	526	528	530	532	534	536	538	540	542	544	546	548	550	552	554	556	558	560	562	564	566	568	570	572	574	576	578	580	582	584	586	588	590	592	594	596	598	600	602	604	606	608	610	612	614	616	618	620	622	624	626	628	630	632	634	636	638	640	642	644	646	648	650	652	654	656	658	660	662	664	666	668	670	672	674	676	678	680	682	684	686	688	690	692	694	696	698	700	702	704	706	708	710	712	714	716	718	720	722	724	726	728	730	732	734	736	738	740	742	744	746	748	750	752	754	756	758	760	762	764	766	768	770	772	774	776	778	780	782	784	786	788	790	792	794	796	798	800	802	804	806	808	810	812	814	816	818	820	822	824	826	828	830	832	834	836	838	840	842	844	846	848	850	852	854	856	858	860	862	864	866	868	870	872	874	876	878	880	882	884	886	888	890	892	894	896	898	900	902	904	906	908	910	912	914	916	918	920	922	924	926	928	930	932	934	936	938	940	942	944	946	948	950	952	954	956	958	960	962	964	966	968	970	972	974	976	978	980	982	984	986	988	990	992	994	996	998	1000	1002	1004	1006	1008	1010	1012	1014	1016	1018	1020	1022	1024	1026	1028	1030	1032	1034	1036	1038	1040	1042	1044	1046	1048	1050	1052	1054	1056	1058	1060	1062	1064	1066	1068	1070	1072	1074	1076	1078	1080	1082	1084	1086	1088	1090	1092	1094	1096	1098	1100	1102	1104	1106	1108	1110	1112	1114	1116	1118	1120	1122	1124	1126	1128	1130	1132	1134	1136	1138	1140	1142	1144	1146	1148	1150	1152	1154	1156	1158	1160	1162	1164	1166	1168	1170	1172	1174	1176	1178	1180	1182	1184	1186	1188	1190	1192	1194	1196	1198	1200	1202	1204	1206	1208	1210	1212	1214	1216	1218	1220	1222	1224	1226	1228	1230	1232	1234	1236	1238	1240	1242	1244	1246	1248	1250	1252	1254	1256	1258	1260	1262	1264	1266	1268	1270	1272	1274	1276	1278	1280	1282	1284	1286	1288	1290	1292	1294	1296	1298	1300	1302	1304	1306	1308	1310	1312	1314	1316	1318	1320	1322	1324	1326	1328	1330	1332	1334	1336	1338	1340	1342	1344	1346	1348	1350	1352	1354	1356	1358	1360	1362	1364	1366	1368	1370	1372	1374	1376	1378	1380	1382	1384	1386	1388	1390	1392	1394	1396	1398	1400	1402	1404	1406	1408	1410	1412	1414	1416	1418	1420	1422	1424	1426	1428	1430	1432	1434	1436	1438	1440	1442	1444	1446	1448	1450	1452	1454	1456	1458	1460	1462	1464	1466	1468	1470	1472	1474	1476	1478	1480	1482	1484	1486	1488	1490	1492	1494	1496	1498	1500	1502	1504	1506	1508	1510	1512	1514	1516	1518	1520	1522	1524	1526	1528	1530	1532	1534	1536	1538	1540	1542	1544	1546	1548	1550	1552	1554	1556	1558	1560	1562	1564	1566	1568	1570	1572	1574	1576	1578	1580	1582	1584	1586	1588	1590	1592	1594	1596	1598	1600	1602	1604	1606	1608	1610	1612	1614	1616	1618	1620	1622	1624	1626	1628	1630	1632	1634	1636	1638	1640	1642	1644	1646	1648	1650	1652	1654	1656	1658	1660	1662	1664	1666	1668	1670	1672	1674	1676	1678	1680	1682	1684	1686	1688	1690	1692	1694	1696	1698	1700	1702	1704	1706	1708	1710	1712	1714	1716	1718	1720	1722	1724	1726	1728	1730	1732	1734	1736	1738	1740	1742	1744	1746	1748	1750	1752	1754	1756	1758	1760	1762	1764	1766	1768	1770	1772	1774	1776	1778	1780	1782	1784	1786	1788	1790	1792	1794	1796	1798	1800	1802	1804	1806	1808	1810	1812	1814	1816	1818	1820	1822	1824	1826	1828	1830	1832	1834	1836	1838	1840	1842	1844	1846	1848	1850	1852	1854	1856	1858	1860	1862	1864	1866	1868	1870	1872	1874	1876	1878	1880	1882	1884	1886	1888	1890	1892	1894	1896	1898	1900	1902	1904	1906	1908	1910	1912	1914	1916	1918	1920	1922	1924	1926	1928	1930	1932	1934	1936	1938	1940	1942	1944	1946	1948	1950	1952	1954	1956	1958	1960	1962	1964	1966	1968	1970	1972	1974	1976	1978	1980	1982	1984	1986	1988	1990	1992	1994	1996	1998	2000	2002	2004	2006	2008	2010	2012	2014	2016	2018	2020	2022	2024	2026	2028	2030	2032	2034	2036	2038	2040	2042	2044	2046	2048	2050	2052	2054	2056	2058	2060	2062	2064	2066	2068	2070	2072	2074	2076	2078	2080	2082	2084	2086	2088	2090	2092	2094	2096	2098	2100	2102	2104	2106	2108	2110	2112	2114	2116	2118	2120	2122	2124	2126	2128	2130	2132	2134	2136	2138	2140	2142	2144	2146	2148	2150	2152	2154	2156	2158	2160	2162	2164	2166	2168	2170	2172	2174	2176	2178	2180	2182	2184	2186	2188	2190	2192	2194	2196	2198	2200	2202	2204	2206	2208	2210	2212	2214	2216	2218	2220	2222	2224	2226	2228	2230	2232	2234	2236	2238	2240	2242	2244	2246	2248	2250	2252	2254	2256	2258	2260	2262	2264	2266	2268	2270	2272	2274	2276	2278	2280	2282	2284	2286	2288	2290	2292	2294	2296	2298	2300	2302	2304	2306	2308	2310	2312	2314	2316	2318	2320	2322	2324	2326	2328	2330	2332	2334	2336	2338	2340	2342	2344	2346	2348	2350	2352	2354	2356	2358	2360	2362	2364	2366	2368	2370	2372	2374	2376	2378	2380	2382	2384	2386	2388	2390	2392	2394	2396	2398	2400	2402	2404	2406	2408	2410	2412	2414	2416	2418	2420	2422	2424	2426	2428	2430	2432	2434	2436	2438	2440	2442	2444	2446	2448	2450	2452	2454	2456	2458	2460	2462	2464	2466	2468	2470	2472	2474	2476	2478	2480	2482	2484	2486	2488	2490	2492	2494	2496	2498	2500	2502	2504	2506	2508	2510	2512	2514	2516	2518	2520	2522	2524	2526	2528	2530	2532	2534	2536	2538	2540	2542	2544	2546	2548	2550	2552	2554	2556	2558	2560	2562	2564	2566	2568	2570	2572	2574	2576	2578	2580	2582	2584	2586	2588	2590	2592	2594	2596	2598	2600	2602	2604	2606	2608	2610	2612	2614	2616	2618	2620	2622	2624	2626	2628	2630	2632	2634	2636	2638	2640	2642	2644	2646	2648	2650	2652	2654	2656	2658	2660	2662	2664	2666	2668	2670	2672	2674	2676	2678	2680	2682	2684	2686	2688	2690	2692	2694	2696	2698	2700	2702	2704	2706	2708	2710	2712	2714	2716	2718	2720	2722	2724	2726	2728	2730	2732	2734	2736	2738	2740	2742	2744	2746	2748	2750	2752	2754	2756	2758	2760	2762	2764	2766	2768	2770	2772	2774	2776	2778	2780	2782	2784	2786	2788	2790	2792	2794	2796	2798	2800	2802	2804	2806	2808	2810	2812	2814	2816	2818	2820	2822	2824	2826	2828	2830	2832	2834	2836	2838	2840	2842	2844	2846	2848	2850	2852	2854	2856	2858	2860	2862	2864	2866	2868	2870	2872	2874	2876	2878	2880	2882	2884	2886	2888	2890	2892	2894	2896	2898	2900	2902	2904	2906	2908	2910	2912	2914	2916	2918	2920	2922	2924	
-------	--	----	----	----	----	----	----	----	----	----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	--

105	111	120	115	118	134	144	155	164	16.09634	
172	179	188	200	216	240	271	370	99	102	16.09634
106	113	123	132	144	159	178	199	221	242	16.09634
259	272	291	317	348	376	398	394	95	96	16.09634
97	98	100	102	106	114	125	148	167	190	16.09634
218	247	280	311	335	355	381	418	462	495	16.09634
511	527	564	581	95	96	97	98	100	103	16.09634
107	115	127	149	169	193	220	249	283	314	16.09634
339	359	386	423	468	501	516	534	562	580	16.09634
95	96	97	98	100	103	108	116	129	150	16.09634
170	195	220	250	284	316	341	361	388	426	16.09634
471	504	519	537	562	580	100	103	108	116	16.09634
131	151	172	196	221	251	286	320	345	365	16.09634
392	429	475	508	524	541	562	580	328	350	16.09634
369	396	433	480	514	529	546	564	580	356	16.09634
374	399	436	484	520	534	550	566	581	380	16.09634
403	438	487	526	541	555	569	582	405	439	16.09634
488	535	548	560	572	583	555	560	567	576	16.09634
585	570	572	575	589	586	579	580	582	585	16.09634
588	587	587	587	588	589	590	590	95	95	

105	111	120	115	119	125	134	144	155	164	16.09898
172	179	188	200	216	240	271	370	100	102	16.09898
106	113	123	132	144	159	178	199	222	242	16.09898
259	273	291	317	348	377	398	394	95	96	16.09898
97	98	100	102	107	114	125	148	168	190	16.09898
218	247	281	311	335	355	382	419	463	495	16.09898
511	527	564	581	95	96	97	98	100	103	16.09898
107	115	128	149	169	193	220	250	284	315	16.09898
339	359	386	424	468	501	516	534	562	580	16.09898
95	96	97	98	100	103	108	116	129	150	16.09898
171	195	221	251	285	317	341	361	389	426	16.09898
471	504	519	537	562	580	101	103	108	117	16.09898
131	151	172	197	222	251	286	321	345	365	16.09898
392	430	475	508	524	541	562	560	328	350	16.09898
370	396	434	480	514	529	546	564	580	357	16.09898
375	400	436	484	520	535	550	565	581	380	16.09898
403	438	487	526	541	555	569	582	406	439	16.09898
489	536	549	560	572	583	555	560	567	576	16.09898
585	570	572	575	589	586	579	580	582	585	16.09898
588	587	587	587	588	589	590	590	95	95	

103154	11	150	155	161	169	177	185	193	201	209	217	225	233	241	249	257	265	273	281
103154	21	99	103	107	111	115	119	123	127	131	135	139	143	147	151	155	159	163	167
103154	31	174	181	189	199	211	221	228	228	228	228	228	228	228	228	228	228	228	228
103154	41	95	96	96	97	99	103	108	117	125	136	146	157	167	177	187	197	207	217
103154	51	148	161	175	187	197	204	214	227	241	250	259	268	277	286	295	304	313	322
103154	61	254	258	266	269	275	284	295	306	317	328	339	350	361	372	383	394	405	416
103154	71	99	103	109	117	126	137	149	161	176	188	200	213	227	241	255	269	283	297
103154	81	196	205	216	228	242	251	255	259	265	271	277	283	289	295	301	307	313	319
103154	91	95	95	95	96	96	97	100	103	109	118	127	136	145	154	163	172	181	190
103154	101	126	137	149	162	176	189	198	206	216	229	243	257	271	285	299	313	327	341
103154	111	243	252	256	260	265	268	276	286	297	309	323	337	351	365	379	393	407	421
103154	121	109	118	127	138	149	162	176	190	200	207	216	225	234	243	252	261	270	279
103154	131	217	230	244	253	257	261	265	268	270	271	272	273	274	275	276	277	278	279
103154	141	209	218	231	245	255	258	262	266	269	271	272	273	274	275	276	277	278	279
103154	151	210	210	232	246	256	260	264	267	269	270	271	272	273	274	275	276	277	278
103154	161	220	232	247	258	262	265	268	270	271	272	273	274	275	276	277	278	279	280
103154	171	248	261	265	267	270	271	272	273	274	275	276	277	278	279	280	281	282	283
103154	181	273	272	273	273	274	275	276	277	278	279	280	281	282	283	284	285	286	287
103154	191	277	280	280	280	280	280	280	280	280	280	280	280	280	280	280	280	280	280

103163	1	109	111	115	122	126	130	137	144	152	159	166	173	180	187	194	201	208	215
103163	11	164	169	175	182	191	202	212	222	232	242	252	262	272	282	292	302	312	322
103163	21	104	106	111	113	120	127	137	147	158	168	178	188	198	208	218	228	238	248
103163	31	176	182	190	200	212	222	229	233	241	250	259	268	277	286	295	304	313	322
103163	41	104	104	101	101	101	104	110	117	126	136	146	157	167	177	187	197	207	217
103163	51	165	161	175	187	197	204	214	227	241	250	259	268	277	286	295	304	313	322
103163	61	255	258	266	269	275	284	295	306	317	328	339	350	361	372	383	394	405	416
103163	71	100	104	109	117	126	137	149	162	176	188	200	213	227	241	255	269	283	297
103163	81	198	206	216	228	242	251	255	259	265	271	277	283	289	295	301	307	313	319
103163	91	96	96	97	97	97	98	100	103	109	118	127	136	145	154	163	172	181	190
103163	101	127	138	149	162	176	189	198	206	216	229	243	257	271	285	299	313	327	341
103163	111	243	252	256	260	265	268	276	286	297	309	323	337	351	365	379	393	407	421
103163	121	110	118	127	138	149	162	176	190	200	207	216	225	234	243	252	261	270	279
103163	131	217	230	244	253	257	261	265	268	270	271	272	273	274	275	276	277	278	279
103163	141	209	218	231	245	255	258	262	266	269	271	272	273	274	275	276	277	278	279
103163	151	211	229	232	246	256	260	264	267	269	270	271	272	273	274	275	276	277	278
103163	161	221	232	247	258	262	265	268	270	271	272	273	274	275	276	277	278	279	280
103163	171	248	261	265	267	270	271	272	273	274	275	276	277	278	279	280	281	282	283
103163	181	272	272	273	273	274	275	276	277	278	279	280	281	282	283	284	285	286	287
103163	191	277	280	280	280	280	280	280	280	280	280	280	280	280	280	280	280	280	280

SECTION III
STRESS COMPUTATIONS


OSC 1522

This section deals with the actual stress computations and comparison to allowables. The stress calculations are performed by first justifying the nozzle for pressure conditions. This was done on Page 1-7. Secondly, a combination of stress indices from B31.7 and various other literature were obtained and moment loading is defined. Thus, giving the several intensities which is associated with applied loads, i.e. dead weight, earthquake, and thermal expansion. Thirdly, the bulk of this section deals with the calculation of thermal stresses.

The thermal stress calculations are performed using B&W Computer Programs 91206 and 91032. Program 91206 uses the virtual work method to solve axisymmetric shells of revolution (See model on Page 3-1). Program 91032 is a general thermal motion and stress program solving for various shapes using appropriate classical theory. The portion which is used in this analysis is the opening in a cylinder using flat plate theory modified to account for curvature in the circumferential direction.

The stresses were generated by inputting appropriate temperatures and geometry into the programs assuming no reactions at the nozzle to shell intersection. A two element discontinuity analysis was then performed and forces and moments generated were then superimposed on the thermal stresses to give a total thermal stress picture.


Stress concentration factors are obtained by using indices of B31.7 and other sources, and finally a fatigue analysis is performed on the branch.



000619330

CUSTOMER	JOB No.
SUBJECT <i>1006 MODEL OF NOZZLE</i>	
	BY
	DATE

OSC 1522



0006190331

CUSTOMER	JOB No.
SUBJECT 91206 GRID TO SCALE	
LONG. SCALE 4 BLOCKS = 1"	BY
RADIAL SCALE 16 BLOCKS = 1"	DATE

0006190339

MID-SURFACE GEOMETRY

AT TOP BOUNDARY, MEAN RADIUS = 1.2813 Z COORDINATE = 20.0000

SEGMENTAL GEOMETRY DATA BY GROUPS

SEGMENT DATA			CENTER OF CURVATURE DATA		
BOTTOM	MEAN	Z	RADIUS	Z	CURVATURE
SEG. NO.	RADIUS	COORD.	TO CENTER	COORD.	IDENTIFIER
5.0	1.281	15.000	-0.000	-0.000	-0.0
6.0	1.281	14.750	-0.000	-0.000	-0.0
7.0	1.281	14.500	-0.000	-0.000	-0.0
8.0	1.281	14.250	-0.000	-0.000	-0.0
10.0	1.316	13.250	-0.000	-0.000	-0.0
11.0	1.316	13.000	-0.000	-0.000	-0.0
14.0	1.316	10.712	-0.000	-0.000	-0.0
15.0	1.316	10.500	-0.000	-0.000	-0.0
16.0	1.375	10.500	-0.000	-0.000	-0.0
17.0	1.375	10.469	-0.000	-0.000	-0.0
18.0	1.375	10.260	-0.000	-0.000	-0.0
20.0	1.375	9.702	-0.000	-0.000	-0.0
21.0	1.375	9.062	-0.000	-0.000	-0.0
22.0	1.469	9.062	-0.000	-0.000	-0.0
23.0	1.469	8.842	-0.000	-0.000	-0.0
24.0	1.469	8.553	-0.000	-0.000	-0.0
25.0	1.469	7.584	-0.000	-0.000	-0.0
26.0	1.469	7.124	-0.000	-0.000	-0.0
30.0	2.188	4.312	-0.000	-0.000	-0.0
33.0	2.188	3.999	-0.000	-0.000	-0.0

0 0 0 6 1 9 0 3 3 3

SEGMENTAL GEOMETRY BY SEGMENTS (K= SEGMENT NO.)

MEAN RADIUS										
K	R(K-1)	R(K)	R(K+1)	R(K+2)	R(K+3)	R(K+4)	R(K+5)	R(K+6)	R(K+7)	R(K+8)
1	1.24	1.28	1.28	1.24	1.28	1.28	1.28	1.28	1.28	1.30
11	1.32	1.32	1.32	1.32	1.32	1.32	1.38	1.38	1.38	1.38
21	1.78	1.38	1.47	1.47	1.47	1.47	1.47	1.65	1.83	2.01
31	2.19	2.19	2.19	2.19						

Z COORDINATE										
K	Z(K-1)	Z(K)	Z(K+1)	Z(K+2)	Z(K+3)	Z(K+4)	Z(K+5)	Z(K+6)	Z(K+7)	Z(K+8)
1	20.00	19.00	18.00	17.00	16.00	15.00	14.75	14.50	14.35	13.80
11	13.25	13.00	12.24	11.47	10.71	10.50	10.50	10.46	10.26	9.78
21	9.30	9.06	9.06	9.04	8.55	7.58	7.12	6.42	5.72	5.01
31	4.31	3.21	2.10	1.00						

SEGMENT THICKNESS DATA BY GROUPS

TOP SEG. NO.	BOTTOM SEG. NO.	TOP THICK. OF TOP SEG.	BOTTOM THICK. OF BOTTOM SEG.
1.00	5.00	.38	.38
6.00	8.00	.44	.44
9.00	10.00	.44	.87
11.00	15.00	.87	.87
16.00	16.00	-0.00	-0.00
17.00	21.00	.75	.75
22.00	22.00	-0.00	-0.00
23.00	26.00	.56	.56
27.00	30.00	.56	2.00
31.00	33.00	2.00	2.00

OSC 1522

MENTAL THICKNESS BY SEGMENTS

THICKNESS AT TOP OF SEGMENT (HA)

K	HA(K)	HA(K+1)	HA(K+2)	HA(K+3)	HA(K+4)	HA(K+5)	HA(K+6)	HA(K+7)	HA(K+8)	HA(K+9)
1	.38	.38	.38	.38	.38	.44	.44	.44	.44	.65
11	.87	.87	.87	.87	.87	0.00	.75	.75	.75	.75
21	.75	0.00	.56	.56	.56	.56	.56	.92	1.28	1.64
31	2.00	2.00	2.00							

THICKNESS AT BOTTOM OF SEGMENT (HB)

K	HB(K)	HB(K+1)	HB(K+2)	HB(K+3)	HB(K+4)	HB(K+5)	HB(K+6)	HB(K+7)	HB(K+8)	HB(K+9)
1	.38	.38	.38	.38	.38	.44	.44	.44	.65	.87
11	.87	.87	.87	.87	.87	0.00	.75	.75	.75	.75
21	.75	0.00	.56	.56	.56	.56	.92	1.28	1.64	2.00
31	2.00	2.00	2.00							

FLEXIBILITY MATRIX OF ASSEMBLY AS IN PROGRAM 91060
 (THIS MATRIX ONLY IS ON A PER RADIAN BASIS)

	M(O)	Q(O)	M(N)	Q(N)
ROTATION(O)	3.138385E-06	8.041817E-07	-4.768053E-19	1.402074E-18
DEFLECTION(O)	8.041817E-07	5.054773E-07	7.682228E-20	6.538333E-19
ROTATION(N)	-4.768053E-19	7.682228E-20	4.137258E-08	2.476880E-08
DEFLECTION(N)	1.402074E-18	6.538333E-19	2.476880E-08	5.410359E-08

NOTE: THE +1 SIGN CONVENTION IS USED IN THE MATRIX PRINTED HERE.
 IF IT IS DESIRED TO USE THE -1 SIGN CONVENTION THEN THE
 SIGNS MUST BE CHANGED ON ALL OF THE OFF-DIAGONAL ELEMENTS.

OSC 1522

	97	97	97					
	99	99	99					
	101	101	101					
	103	103	104	104	105			
	106	107	107	108	108			
	110	111	112	113	114			
	118	120	121	122	123			
	127	132	135	137	139			
	157	158	160	161				
	178	180	181	183				
	201	204	207	208				
		232	233	233				
		261	261	262				
		293	294	296				
		322	325	328	335			
		345	348	351	356	362		
		364	366	370	374	379	384	
		389	391	394	398	401	404	407
		422	424	427	431	434	436	437
		461	464	468	472	476	478	486
		491	494	498	503	508	514	522

0006190335

ITER 28169 TEMPERATURE DIST.

CUSTOMER		JOB NO.	
SUBJECT	91167 GRID TO SCALE	BY	
	LONGITUDINAL SCALE 4 BLOCKS = 1"	DATE	3-7
	RADIAL SCALE 16 BLOCKS = 1"		

TEMPERATURES PER SEGMENT USED IN PEAK PRINCIPLE ANALYSIS

SEGMENT	OUTSIDE				INSIDE						
	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5
1	27	27	27	27	27	17	80	77	77	76	75
2	27	27	27	27	27	18	122	120	115	112	110
3	27	27	27	27	27	19	131	129	125	122	120
4	27	27	27	27	27	20	140	137	135	132	130
5	27	27	27	27	27	21	150	147	145	142	140
6	27	27	27	27	27	22	150	150	150	150	150
7	28	28	28	28	28	23	150	150	150	150	150
8	29	29	29	29	29	24	165	163	162	161	160
9	33	33	32	31	31	25	195	194	193	192	190
10	36	36	35	34	34	26	213	211	210	207	205
11	38	38	37	36	36	27	245	242	241	238	236
12	49	48	46	45	44	28	276	274	272	269	267
13	59	57	56	53	52	29	308	305	304	301	299
14	70	67	65	62	60	30	340	337	335	332	330
15	80	77	75	72	70	31	375	368	353	360	357
16	80	77	77	76	75	32	407	399	392	387	383
						33	440	430	420	415	410

PEAK FORCES AND MOTIONS

POSITIVE DIRECTIONS (+) ARE AS FOLLOWS

TOP OF SEGMENT NO.1 BOTTOM OF REMAINING SEGMENTS
RADIAL----- TO THE LEFT RADIAL----- TO THE RIGHT
ROTATIONAL-- CLOCKWISE ROTATIONAL-- COUNTERCLOCKWISE
AXIAL----- UPWARD AXIAL----- DOWNWARD

OSC 1500

** SIGN CONVENTIONS ARE FOR A RIGHT HAND VIEW **

SEG. NO.	LOC.	RADIAL FORCE	MOMENT	AXIAL FORCE	LOC.	RADIAL MOTION	ROTATION	AXIAL MOTION
1	TOP	0.	-2.9212E-03	0.	TOP	-3.1832E-04	6.6174E-24	0.
1	BOT.	-7.4229E-03	-8.6319E-03	0.	BOT.	3.1831E-04	-5.7149E-09	2.4844E-04
2	BOT.	-2.8156E-01	1.4224E-01	0.	BOT.	3.1831E-04	3.5028E-08	4.9688E-04
3	BOT.	2.3696E+00	-4.7788E-01	0.	BOT.	3.1844E-04	6.4591E-08	7.4531E-04
4	BOT.	-9.8380E-01	-4.4384E+00	0.	BOT.	3.1767E-04	-2.3428E-06	9.9375E-04
5	BOT.	-1.2180E+02	5.6382E+01	0.	BOT.	3.1573E-04	1.2573E-05	1.2429E-03
6	BOT.	-1.3178E+02	8.9514E+01	0.	BOT.	3.1912E-04	2.3508E-05	1.3052E-03
7	BOT.	-1.5387E+02	1.2402E+02	0.	BOT.	3.2573E+04	3.9537E-05	1.3087E-03
8	BOT.	-2.1354E+02	1.5104E+02	0.	BOT.	3.3168E-04	5.2172E-05	1.4085E-03
9	BOT.	-6.6127E+02	3.9588E+02	0.	BOT.	3.6995E-04	8.7224E-05	1.5641E-03
0	BOT.	-9.0937E+02	8.8518E+02	0.	BOT.	4.2138E-04	1.0664E-04	1.7341E-03
1	BOT.	-8.4535E+02	1.1071E+03	0.	BOT.	4.4550E-04	1.1500E-04	1.8177E-03
2	BOT.	-1.7556E+03	2.0739E+03	0.	BOT.	5.3352E-04	1.6263E-04	2.1160E-03
3	BOT.	-2.6500E+03	4.0869E+03	0.	BOT.	6.6758E-04	2.7263E-04	2.4834E-03
4	BOT.	4.7045E+03	4.2631E+03	0.	BOT.	9.5034E-04	4.2818E-04	2.9026E-03
5	BOT.	9.1787E+03	2.7727E+03	0.	BOT.	1.0669E-03	4.4408E-04	3.0324E-03
6	BOT.	9.1787E+03	2.7727E+03	0.	BOT.	1.1088E-03	4.4408E-04	3.0060E-03
7	BOT.	9.7746E+03	2.3938E+03	0.	BOT.	1.1334E-03	4.5153E-04	3.0333E-03
8	BOT.	9.2970E+03	3.5340E+02	0.	BOT.	1.2588E-03	4.5547E-04	3.2142E-03
9	BOT.	2.1891E+03	-2.2878E+03	0.	BOT.	1.4962E-03	3.0934E-04	3.7668E-03
0	BOT.	-3.0965E+03	-2.1127E+03	0.	BOT.	1.5917E-03	1.1027E-04	4.3557E-03
1	BOT.	-7.7989E+03	-8.5530E+02	0.	BOT.	1.5861E-03	4.3983E-05	4.6787E-03
2	BOT.	-7.7989E+03	-8.5530E+02	0.	BOT.	1.6752E-03	4.3983E-05	4.6746E-03
3	BOT.	-7.4426E+03	-7.0288E+02	0.	BOT.	1.6728E-03	3.8979E-05	4.6928E-03
4	BOT.	-1.3819E+03	1.3255E+03	0.	BOT.	1.6444E-03	6.2437E-05	5.1687E-03
5	BOT.	-2.9337E+02	1.5327E+03	0.	BOT.	1.8140E-03	3.3124E-04	6.2904E-03
6	BOT.	-1.2941E+03	1.9368E+03	0.	BOT.	1.9913E-03	4.7541E-04	6.9033E-03
7	BOT.	-1.6020E+03	3.4759E+03	0.	BOT.	2.6266E-03	5.8482E-04	7.8586E-03
8	BOT.	8.1339E+02	4.7784E+03	0.	BOT.	3.3500E-03	5.9876E-04	8.9549E-03
9	BOT.	4.8234E+03	4.1337E+03	0.	BOT.	4.1241E-03	5.7607E-04	1.0208E-02

51
5

30	BOT.	3.8895E+03	2.2815E+03	0.	BOT.	4.9221E-03	5.4106E-04	1.1634E-02
31	BOT.	-1.4549E+03	3.5190E+03	0.	BOT.	5.5010E-03	4.5891E-04	1.4294E-02
32	BOT.	3.8147E+03	3.4049E+03	0.	BOT.	6.0012E-03	3.9970E-04	1.7191E-02
33	BOT.	-0.	-0.	-0.	BOT.	6.3834E-03	2.6999E-04	2.0346E-02

(FORCE AND MOTION OUTPUT IS IN GLOBAL DIRECTIONS: R AND Z)

OSC 1522

000619340

	95		95				
	95.		95				
	76		76				
96	96		97	97			
97	97		98	98			
99	99		101	101			
102	104		107	108			
109	113	116	119	121			
	138	139	140	141			
	157	159	161	162			
	179	183	185	187			
	209	210	211				
	238	239	240				
	272	274	275				
	303	306	310	318			
	329	331	335	341	348		
	398	351	355	361	366	372	
	375	378	382	387	391	394	397
	410	413	418	422	426	428	430
	451	455	460	466	471	474	476
	481	485	491	498	505	512	522

ITER 41428 TEMP. DIST.

CUSTOMER	JOB NO.
SUBJECT 91167 GRID TO SCALE	
CONVERSION SCALE 1" = 1000'	BY
PLANNING SCALE 1" = 1000'	DATE 3-11

TEMPERATURES PER SEGMENT USED IN PEAK PRINCIPLE ANALYSIS

OUTSIDE					INSIDE					OUTSIDE					INSIDE				
SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5		
1	25	25	25	25	25	17	63	60	60	59	58	18	72	71	70	68	67		
2	25	25	25	25	25	19	96	93	90	88	86	19	96	93	90	88	86		
3	25	25	25	25	25	20	120	115	110	107	105	20	120	115	110	107	105		
4	25	25	25	25	25	21	125	120	115	112	110	21	125	120	115	112	110		
5	25	25	25	25	25	22	125	120	115	115	115	22	125	120	115	115	115		
6	25	25	25	25	25	23	125	120	115	115	115	23	125	120	115	115	115		
7	25	25	25	25	25	24	142	141	140	139	138	24	142	141	140	139	138		
8	26	26	26	26	26	25	171	171	170	169	168	25	171	171	170	169	168		
9	26	26	26	26	26	26	189	189	187	186	186	26	189	189	187	186	186		
10	27	27	27	27	27	27	218	217	215	213	212	27	218	217	215	213	212		
11	28	29	28	29	29	28	248	246	243	240	233	28	248	246	243	240	233		
12	36	35	34	32	30	29	277	276	272	268	264	29	277	276	272	268	264		
13	45	43	39	36	33	30	307	305	300	295	290	30	307	305	300	295	290		
14	53	50	45	40	35	31	355	350	343	337	330	31	355	350	343	337	330		
15	63	60	55	50	45	32	402	395	387	378	370	32	402	395	387	378	370		
16	63	60	60	59	58	33	450	440	430	420	410	33	450	440	430	420	410		

PEAK FORCES AND MOTIONS

POSITIVE DIRECTIONS (+) ARE AS FOLLOWS

TOP OF SEGMENT NO.1 BOTTOM OF REMAINING SEGMENTS
 RADIAL----- TO THE LEFT RADIAL----- TO THE RIGHT
 ROTATIONAL-- CLOCKWISE ROTATIONAL-- COUNTERCLOCKWISE
 AXIAL----- UPWARD AXIAL----- DOWNWARD

** SIGN CONVENTIONS ARE FOR A RIGHT HAND VIEW **

SEG. NO.	LOC.	RADIAL FORCE	MOMENT	AXIAL FORCE	LOC.	RADIAL MOTION	ROTATION	AXIAL MOTION
1	TOP	0.	-6.3159E-04	0.	TOP	-2.9465E-04	1.6544E-24	0.
1	BOT.	-3.0941E-03	-6.9566E-04	0.	BOT.	2.9465E-04	-7.9682E-10	2.2997E-04
2	BOT.	-3.5253E-02	2.2260E-02	0.	BOT.	2.9465E-04	6.6059E-09	4.5995E-04
3	BOT.	4.1391E-01	-1.1213E-01	0.	BOT.	2.9467E-04	-3.0283E-09	6.8992E-04
4	BOT.	-9.2703E-01	-4.3826E-01	0.	BOT.	2.9452E-04	-3.3750E-07	9.1990E-04
5	BOT.	-1.6094E+01	9.090JE+00	0.	BOT.	2.9452E-04	2.4A02E-06	1.1500E-03
6	BOT.	-1.2384E+01	1.2911E+01	0.	BOT.	2.9522E-04	4.1137E-06	1.2075E-03
7	BOT.	-3.9001E+01	1.7910E+01	0.	BOT.	2.9632E-04	6.4956E-06	1.2657E-03
8	BOT.	-9.8800E+01	2.7717E+01	0.	BOT.	2.9712E-04	8.8375E-06	1.3015E-03
9	BOT.	-5.0376E+02	1.9253E+02	0.	BOT.	3.0593E-04	2.4595E-05	1.4356E-03
10	BOT.	-8.7152E+02	6.0744E+02	0.	BOT.	3.2335E-04	4.8673E-05	1.5724E-03
11	BOT.	-9.4586E+02	8.3657E+02	0.	BOT.	3.3357E-04	6.2669E-05	1.6365E-03
12	BOT.	-1.9954E+03	1.9956E+03	0.	BOT.	3.8211E-04	1.1129E-04	1.8584E-03
13	BOT.	-2.6554E+03	4.0894E+03	0.	BOT.	4.6567E-04	1.8892E-04	2.1231E-03
14	BOT.	2.9129E+03	4.7240E+03	0.	BOT.	6.5148E-04	2.8482E-04	2.4182E-03
15	BOT.	5.6630E+03	3.7838E+03	0.	BOT.	7.2738E-04	2.9142E-04	2.5128E-03
16	BOT.	5.6630E+03	3.7838E+03	0.	BOT.	7.5900E-04	2.9142E-04	2.4954E-03
17	BOT.	5.7446E+03	3.5588E+03	0.	BOT.	7.7497E-04	3.0546E-04	2.5179E-03
18	BOT.	5.8862E+03	2.3730E+03	0.	BOT.	8.6229E-04	3.5753E-04	2.6393E-03
19	BOT.	4.1295E+03	-1.9811E+02	0.	BOT.	1.0823E-03	3.5631E-04	2.9995E-03
20	BOT.	-1.1902E+03	-1.1333E+03	0.	BOT.	1.2367E-03	2.2406E-04	3.4590E-03
1	BOT.	-5.6943E+03	-3.1463E+02	0.	BOT.	1.2672E-03	1.5544E-04	3.7826E-03
2	BOT.	-5.6943E+03	-3.1463E+02	0.	BOT.	1.3350E-03	1.5544E-04	3.7080E-03
3	BOT.	-5.3533E+03	-2.0435E+02	0.	BOT.	1.3360E-03	1.4984E-04	3.7220E-03
4	BOT.	-3.1249E+02	9.7231E+02	0.	BOT.	1.3721E-03	1.4477E-04	4.1108E-03
5	BOT.	-4.0547E+02	9.3992E+02	0.	BOT.	1.5810E-03	3.0178E-04	5.0844E-03
6	BOT.	-1.9807E+03	1.4871E+03	0.	BOT.	1.7304E-03	4.0744E-04	5.6258E-03
7	BOT.	-5.3764E+03	4.4528E+03	0.	BOT.	2.2741E-03	5.4323E-04	6.4851E-03
8	BOT.	-7.6851E+03	1.0221E+04	0.	BOT.	2.9182E-03	6.1452E-04	7.4645E-03
9	BOT.	-6.1871E+03	1.7358E+04	0.	BOT.	3.6438E-03	6.4647E-04	8.5706E-03

BOT.	-2.1524E+02	2.3130E+04	0.	BOT.	4.4350E-03	6.4504E-04	9.8107E-03
BOT.	6.7521E+03	2.0795E+04	0.	BOT.	5.1583E-03	6.2906E-04	1.2237E-02
BOT.	1.3098E+04	9.8460E+03	0.	BOT.	5.8613E-03	5.4850E-04	1.5024E-02
BOT.	-0.	-0.	-0.	BOT.	6.4164E-03	3.9259E-04	1.8195E-02

(FORCE AND MOTION OUTPUT IS IN GLOBAL DIRECTIONS R AND Z)

13-14

OSC 1522

000619

	95		95				
96				97			
97				98			
98				101			
102				107			
109	112			120			
				140			
				159			
176	179	181		183			
	204	205		206			
	232	233		234			
	265	266		268			
	295	297	301	309			
	318	321	325	331	337		
	338	340	344	350	355	360	
	363	366	370	375	379	382	385
	397	400	404	409	412	414	416
	438	440	445	451	455	458	460
	465	469	475	481	488	495	504

↑ SAME AS ITER 41428

ITER 52659 TEMP. DIST.

CUSTOMER	JOB No.
SUBJECT	BY
DATE	3-15

TEMPERATURES PER SEGMENT USED IN PEAK PRINCIPLE ANALYSIS

OUTSIDE											
SEGMENT	T1	T2	T3	T4	INSIDE T5	SEGMENT	OUTSIDE T1	T2	T3	INSIDE T4	T5
1	25	25	25	25	25	17	63	60	60	59	58
2	25	25	25	25	25	18	72	71	70	68	67
3	25	25	25	25	25	19	93	91	90	88	86
4	25	25	25	25	25	20	115	112	110	107	105
5	25	25	25	25	25	21	120	117	115	112	110
6	25	25	25	25	25	22	20	117	115	112	110
7	25	25	25	25	25	23	20	117	115	112	110
8	26	26	26	26	26	24	38	137	136	135	133
9	26	26	26	26	26	25	65	164	163	162	160
10	27	27	27	27	27	26	60	179	176	176	175
11	28	28	28	28	28	27	210	209	208	206	205
12	36	35	34	32	30	28	240	239	238	236	235
13	45	43	39	36	33	29	270	269	268	266	265
14	53	50	45	40	35	30	300	299	298	296	295
15	63	60	55	50	45	31	343	339	335	331	327
16	63	60	60	59	58	32	387	380	373	365	358
						33	430	420	410	400	390

PEAK FORCES AND MOTIONS

POSITIVE DIRECTIONS (+) ARE AS FOLLOWS

TOP OF SEGMENT NO.1 BOTTOM OF REMAINING SEGMENTS

RADIAL----- TO THE LEFT RADIAL----- TO THE RIGHT
 ROTATIONAL-- CLOCKWISE ROTATIONAL-- COUNTERCLOCKWISE
 AXIAL----- UPWARD AXIAL----- DOWNWARD

** SIGN CONVENTIONS ARE FOR A RIGHT HAND VIEW **

SEG. NO.	LOC.	RADIAL FORCE	MOMENT	AXIAL FORCE	LOC.	RADIAL MOTION	ROTATION	AXIAL MOTION
1	TOP	0.	-6.1883E-04	0.	TOP	-2.9465E-04	1.6544E-24	0.
1	BOT.	-2.9468E-03	-7.1802E-04	0.	BOT.	2.9465E-04	-7.9385E-10	2.2997E-04
2	BOT.	-3.5313E-02	2.2054E-02	0.	BOT.	2.9465E-04	6.5012E-09	4.5995E-04
3	BOT.	4.0849E-01	-1.0959E-01	0.	BOT.	2.9467E-04	-2.4574E-09	6.8992E-04
4	BOT.	-8.8584E-01	-4.4503E-01	0.	BOT.	2.9453E-04	-3.3574E-07	9.1950E-04
5	BOT.	-1.6075E+01	8.9993E+00	0.	BOT.	2.9451E-04	2.4372E-05	1.1500E-03
6	BOT.	-1.2617E+01	1.2643E+01	0.	BOT.	2.9520E-04	4.0595E-06	1.2075E-03
7	BOT.	-3.9711E+01	1.7955E+01	0.	BOT.	2.9628E-04	6.4412E-06	1.2657E-03
8	BOT.	-9.9924E+01	2.7899E+01	0.	BOT.	2.9705E-04	8.7954E-06	1.3015E-03
9	BOT.	-5.0762E+02	1.9406E+02	0.	BOT.	3.0585E-04	2.4679E-05	1.4358E-03
10	BOT.	-8.7852E+02	6.1224E+02	0.	BOT.	3.2332E-04	4.6944E-05	1.5725E-03
11	BOT.	-9.5578E+02	8.4312E+02	0.	BOT.	3.3354E-04	6.3047E-05	1.6366E-03
12	BOT.	-1.9805E+03	2.0018E+03	0.	BOT.	3.8261E-04	1.1205E-04	1.8584E-03
13	BOT.	-2.5471E+03	4.0505E+03	0.	BOT.	4.6734E-04	1.8886E-04	2.1226E-03
14	BOT.	3.1773E+03	4.5282E+03	0.	BOT.	6.5331E-04	2.7800E-04	2.4173E-03
15	BOT.	5.9471E+03	3.5289E+03	0.	BOT.	7.2931E-04	2.8082E-04	2.5117E-03
16	BOT.	5.8-71E+03	3.5289E+03	0.	BOT.	7.5992E-04	2.8029E-04	2.4956E-03
17	BOT.	6.2288E+03	3.2893E+03	0.	BOT.	7.7588E-04	2.9374E-04	2.5174E-03
18	BOT.	6.1471E+03	2.0511E+03	0.	BOT.	8.6090E-04	3.3925E-04	2.6388E-03
19	BOT.	4.2351E+03	-6.1622E+02	0.	BOT.	1.0710E-03	3.2947E-04	2.9975E-03
20	BOT.	-1.4235E+03	-1.5274E+03	0.	BOT.	1.2140E-03	2.0953E-04	3.4520E-03
21	BOT.	-6.1747E+03	-6.2402E+02	0.	BOT.	1.2410E-03	1.5470E-04	3.7129E-03
22	BOT.	-5.1747E+03	-6.2402E+02	0.	BOT.	1.3077E-03	1.4784E-04	3.7119E-03
23	BOT.	-5.8344E+03	-5.0392E+02	0.	BOT.	1.3343E-03	1.2211E-04	4.0891E-03
24	BOT.	-7.3729E+02	9.0174E+02	0.	BOT.	1.5174E-03	2.9581E-04	5.0260E-03
25	BOT.	-6.0431E+02	1.2203E+03	0.	BOT.	1.6733E-03	4.1981E-04	5.5397E-03
26	BOT.	-1.4772E+03	1.7309E+03	0.	BOT.	2.2242E-03	5.4265E-04	6.3469E-03
27	BOT.	-2.4678E+03	3.5085E+03	0.	BOT.	2.8746E-03	5.8679E-04	7.2842E-03
28	BOT.	-1.9796E+03	5.9797E+03	0.	BOT.	3.5923E-03	5.9942E-04	8.3628E-03
29	BOT.	4.7655E+02	7.9132E+03	0.				

BOT.	2.0307E+03	8.7653E+03	0.	BOT.	4.3593E-03	5.9597E-04	9.5934E-03
HOT.	1.1882E+03	9.1053E+03	0.	BOT.	5.0222E-03	5.7956E-04	1.1978E-02
BCT.	6.8736E+03	5.5491E+03	0.	HOT.	5.6422E-03	5.9691E-04	1.4665E-02
BOT.	-0.	-0.	-0.	BOT.	6.1266E-03	3.4069E-04	1.7653E-02

(FORCE AND MOTION OUTPUT IS IN GLOBAL DIRECTIONS R AND Z)

0006190343

70							
		70					
70				71			
71				72			
72	73	74		75			
75	77	78		81			
81	85	88		93			
	110	111		114			
	130	132		135			
	152	155		160			
		182		184			
		211		213			
		245	247	248			
		277	279	284	292		
	301	304	308	315	321		
	322	325	329	334	340	345	
	348	352	356	361	365	369	372
	384	388	392	397	401	403	404
	426	430	436	442	447	450	452
	456	461	467	475	482	489	499

ITER 75168

TEMP. DIST.

CUSTOMER	JOB No.
SUBJECT	
REPT. OF	
DATE	2-19

TEMPERATURES PER SEGMENT USED IN PEAK PRINCIPLE ANALYSIS

OUTSIDE					INSIDE					OUTSIDE					INSIDE																																																																																												
SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5																																																																																				
1	0	0	0	0	0	17	30	30	30	30	30	18	45	44	42	41	40	19	70	65	64	62	60	20	95	89	87	83	80	21	103	97	95	91	88	22	103	97	95	95	95	23	103	97	95	95	95	24	115	114	113	112	112	25	145	144	143	142	142	26	165	164	163	162	162	27	195	191	187	183	180	28	225	218	211	204	198	29	256	245	235	225	216	30	287	272	259	246	234	31	335	320	308	295	283	32	332	309	356	343	331	33	430	417	405	392	380

PEAK FORCES AND MOTIONS

POSITIVE DIRECTIONS (+) ARE AS FOLLOWS

TOP OF SEGMENT NO.1	BOTTOM OF REMAINING SEGMENTS
RADIAL----- TO THE LEFT	RADIAL----- TO THE RIGHT
ROTATIONAL-- CLOCKWISE	ROTATIONAL-- COUNTERCLOCKWISE
AXIAL----- UPWARD	AXIAL----- DOWNWARD

** SIGN CONVENTIONS ARE FOR A RIGHT HAND VIEW **

EG. NO.	LOC.	RADIAL FORCE	MOMENT	AXIAL FORCE	LOC.	RADIAL MOTION	ROTATION	AXIAL MOTION
1	TOP	0.	1.8231E-03	0.	TOP	4.5540E-11	-3.3087E-24	0.
1	BOT.	1.5596E-02	-3.4145E-03	0.	BOT.	8.0507E-10	3.4311E-10	-6.9289E-11
2	BOT.	-1.2536E-02	-2.6397E-02	0.	BOT.	-4.3707E-09	-1.4746E-08	-7.6657E-11
3	BOT.	-7.5671E-01	3.6342E-01	0.	BOT.	-1.4331E-08	8.4481E-08	4.2869E-09
4	BOT.	5.8706E+00	-1.0623E+00	0.	BOT.	3.3550E-07	2.2026E-07	-2.5249E-08
5	BOT.	7.5753E-01	-1.2426E+01	0.	BOT.	-1.5252E-06	-6.0946E-06	-5.9308E-03
6	BOT.	-3.6160E+01	-8.5334E+00	0.	BOT.	-3.3806E-06	-7.5493E-06	6.9576E-08
7	BOT.	-1.0493E+02	8.5318E+00	0.	BOT.	-5.8767E-06	-7.3474E-06	3.4582E-07
8	BOT.	-1.6400E+02	2.8604E+01	0.	BOT.	-7.5070E-06	-5.3941E-06	6.0528E-07
9	BOT.	-5.4282E+02	2.2031E+02	0.	BOT.	-1.0860E-05	1.2625E-05	2.2458E-06
0	BOT.	-9.3325E+02	6.6347E+02	0.	BOT.	-3.9967E-06	3.9281E-05	3.8895E-06
1	BOT.	-8.7300E+02	8.9713E+02	0.	BOT.	4.0180E-06	5.4004E-05	4.4731E-06
2	BOT.	-1.5294E+03	1.7703E+03	0.	BOT.	5.0521E-05	1.0655E-04	3.0592E-05
3	BOT.	-2.4617E+03	3.5502E+03	0.	BOT.	1.3550E-04	1.8730E-04	1.0325E-04
4	BOT.	2.2532E+03	4.3393E+03	0.	BOT.	3.2132E-04	2.9319E-04	2.1074E-04
5	BOT.	4.6130E+03	3.5791E+03	0.	BOT.	3.9908E-04	3.2771E-04	2.5438E-04
6	BOT.	4.6130E+03	3.5791E+03	0.	BOT.	4.1552E-04	3.2771E-04	2.3488E-04
7	BOT.	4.8301E+03	3.3904E+03	0.	BOT.	4.3225E-04	3.4266E-04	2.4593E-04
8	BOT.	5.4104E+03	2.3390E+03	0.	BOT.	5.2481E-04	3.9650E-04	3.1332E-04
9	BOT.	4.1601E+03	-1.1874E+02	0.	BOT.	7.6198E-04	3.9983E-04	5.5422E-04
0	BOT.	-3.5281E+02	-1.2485E+03	0.	BOT.	9.4381E-04	2.7950E-04	8.9748E-04
1	BOT.	-4.5520E+03	-6.7954E+02	0.	BOT.	9.9209E-04	2.1281E-04	1.1077E-03
2	BOT.	-4.5520E+03	-6.7954E+02	0.	BOT.	1.0489E-03	2.1281E-04	1.0872E-03
3	BOT.	-4.3320E+03	-5.9069E+02	0.	BOT.	1.0505E-03	2.0720E-04	1.0993E-03
4	BOT.	-6.3867E+02	5.2851E+02	0.	BOT.	1.1121E-03	1.7112E-04	1.4134E-03
5	BOT.	-6.2493E+02	6.9907E+02	0.	BOT.	1.3031E-03	2.5593E-04	2.2097E-03
6	BOT.	-3.4445E+03	1.5709E+03	0.	BOT.	1.4197E-03	3.5210E-04	2.6745E-03
7	BOT.	-1.1430E+04	7.2218E+03	0.	BOT.	1.8730E-03	5.3118E-04	3.4310E-03
8	BOT.	-1.8861E+04	1.9721E+04	0.	BOT.	2.4367E-03	6.4437E-04	4.2803E-03
9	BOT.	-1.8905E+04	3.7102E+04	0.	BOT.	3.0979E-03	6.9342E-04	5.2236E-03

20	ROT.	-5.5366E+03	5.2801E+04	0.	ROT.	3.8381E-03	5.7312E-04	6.2647E-03
21	ROT.	1.6633E+04	4.6601E+04	0.	ROT.	4.5790E-03	6.2078E-04	8.3769E-03
22	ROT.	2.6822E+04	2.0414E+04	0.	ROT.	5.3680E-03	5.0739E-04	1.0890E-02
33	ROT.	-0.	-0.	-0.	ROT.	5.8242E-03	3.1641E-04	1.3833E-02

(FORCE AND MOTION OUTPUT IS IN GLOBAL DIRECTIONS R AND Z)

OSC 1522

96
97
98

100	100	100	101				
102	102	103	103				
106	107	108	108				
113	114	116	117				
123	125	129	131				
	148	150	151				
	168	171	172				
	190	193	195	197			
	220	221	222				
	250	251	251				
	284	285	286				
	315	317	321	328			
	339	341	345	350	357		
	359	361	365	370	375	380	
	386	389	392	396	400	403	406
	429	426	430	434	436	438	439
	468	471	475	480	484	487	487
	501	504	508	514	520	526	536

00061900352

ITER 86960

TEMP. DIST.

CUSTOMER	JOB No.
SUBJECT 91167	
BY	
DATE	2-23

TEMPERATURES PER SEGMENT USED IN PEAK PRINCIPLE ANALYSIS

OUTSIDE						INSIDE					
SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5
1	26	26	26	26	26	17	73	70	67	65	65
2	26	26	26	26	26	18	85	83	82	81	80
3	26	26	26	26	26	19	107	104	102	99	98
4	26	26	26	26	26	20	130	126	122	118	115
5	26	26	26	26	26	21	135	131	127	123	120
6	26	26	26	26	26	22	135	131	127	123	120
7	28	28	28	28	28	23	135	131	127	123	120
8	30	30	30	30	30	24	155	154	153	151	150
9	30	30	30	30	30	25	180	180	180	180	180
10	30	30	30	30	30	26	199	198	197	197	196
11	33	32	32	31	31	27	229	228	225	223	221
12	43	41	40	39	37	28	260	258	253	248	245
13	53	51	49	46	44	29	290	288	282	274	270
14	63	60	57	54	50	30	321	318	310	300	295
15	73	70	67	63	60	31	365	360	350	340	333
16	73	70	67	65	62	32	410	403	390	380	372
						33	455	445	430	420	410

PEAK FORCES AND MOTIONS

POSITIVE DIRECTIONS (+) ARE AS FOLLOWS

TOP OF SEGMENT NO.1 BOTTOM OF REMAINING SEGMENTS
RADIAL----- TO THE LEFT RADIAL----- TO THE RIGHT
ROTATIONAL-- CLOCKWISE ROTATIONAL-- COUNTERCLOCKWISE
AXIAL----- UPWARD AXIAL----- DOWNWARD

** SIGN CONVENTIONS ARE FOR A RIGHT HAND VIEW **

SEG. NO.	LOC.	RADIAL FORCE	MOMENT	AXIAL FORCE	LOC.	RADIAL MOTION	ROTATION	AXIAL MOTION
1	TOP	0.	-5.2727E-03	0.	TOP	-3.0648E-04	1.3235E-23	0.
1	BOT.	-4.3647E-02	8.6691E-03	0.	BOT.	3.0648E-04	-1.4223E-09	2.3921E-04
2	BOT.	1.1257E-02	8.4621E-02	0.	BOT.	3.0649E-04	4.3678E-08	4.7841E-04
3	BOT.	2.2843E+00	-1.0423E+00	0.	BOT.	3.0653E-04	-2.2825E-07	7.1761E-04
4	BOT.	-1.6280E+01	2.5633E+00	0.	BOT.	3.0550E-04	-8.0318E-07	9.5689E-04
5	BOT.	-1.2211E+01	3.8958E+01	0.	BOT.	3.1049E-04	1.7895E-05	1.1963E-03
6	BOT.	8.8652E+01	3.0963E+01	0.	BOT.	3.1592E-04	2.2823E-05	1.2557E-03
7	BOT.	1.0476E+02	1.2414E+00	0.	BOT.	3.2277E-04	2.5184E-05	1.3178E-03
8	BOT.	-4.9294E+01	-5.1441E+00	0.	BOT.	3.2672E-04	2.5770E-05	1.3584E-03
9	BOT.	-8.8815E+02	2.7157E+02	0.	BOT.	3.4271E-04	4.2174E-05	1.5130E-03
0	BOT.	-1.0805E+03	9.0504E+02	0.	BOT.	3.7030E-04	7.7311E-05	1.6660E-03
1	BOT.	-8.1203E+02	1.1437E+03	0.	BOT.	3.8785E-04	9.2725E-05	1.7372E-03
2	BOT.	-1.2676E+03	1.8820E+03	0.	BOT.	4.6386E-04	1.4109E-04	1.9928E-03
3	BOT.	-2.0833E+03	3.3883E+03	0.	BOT.	5.7789E-04	2.1837E-04	2.3134E-03
4	BOT.	2.4276E+03	3.9115E+03	0.	BOT.	7.8813E-04	3.2253E-04	2.6846E-03
5	BOT.	4.8652E+03	3.1143E+03	0.	BOT.	8.7059E-04	3.3533E-04	2.8030E-03
6	BOT.	4.8652E+03	3.1143E+03	0.	BOT.	9.0748E-04	3.3533E-04	2.7831E-03
7	BOT.	5.1332E+03	2.9144E+03	0.	BOT.	9.2458E-04	3.4204E-04	2.6079E-03
8	BOT.	5.6653E+03	1.7949E+03	0.	BOT.	1.0153E-03	3.7136E-04	2.9469E-03
9	BOT.	3.6421E+03	-5.8395E+02	0.	BOT.	1.2337E-03	3.5019E-04	3.3619E-03
0	BOT.	-1.7682E+03	-1.2550E+03	0.	BOT.	1.3777E-03	2.0749E-04	3.8721E-03
1	BOT.	-6.4033E+03	-2.8373E+02	0.	BOT.	1.4013E-03	1.3894E-04	4.1611E-03
2	ROT.	-6.4033E+03	-2.8373E+02	0.	BOT.	1.4775E-03	1.3894E-04	4.1481E-03
3	BOT.	-5.9933E+03	-1.5976E+02	0.	BOT.	1.4777E-03	1.3173E-04	4.1631E-03
4	BOT.	-1.0447E+02	1.0587E+03	0.	BOT.	1.4966E-03	1.1070E-04	4.5859E-03
5	BOT.	-4.5793E+02	9.0048E+02	0.	BOT.	1.6783E-03	2.8366E-04	5.6352E-03
6	BOT.	-2.3818E+03	1.5438E+03	0.	BOT.	1.8213E-03	4.0614E-04	6.2103E-03
7	BOT.	-6.7335E+03	5.1616E+03	0.	BOT.	2.3757E-03	5.5920E-04	7.1226E-03
8	BOT.	-9.8523E+03	1.2389E+04	0.	BOT.	3.0355E-03	6.3430E-04	8.1528E-03
9	BOT.	-8.3648E+03	2.1563E+04	0.	BOT.	3.7760E-03	6.5776E-04	9.3084E-03

30	BOT.	-1.6853E+03	2.9474E+04	0.	BOT.	4.5757E-03	6.3727E-04	1.0599E-02
31	BOT.	8.0562E+03	2.7328E+04	0.	BOT.	5.2713E-03	5.8938E-04	1.3092E-02
32	SOT.	1.6715E+04	1.3090E+04	0.	BOT.	5.9250E-03	4.7736E-04	1.5926E-02
33	BOT.	-0.	-0.	-0.	BOT.	6.3890E-03	2.6523E-04	1.9127E-02

(FORCE AND MOTION OUTPUT IS IN GLOBAL DIRECTIONS R AND Z)

OSC 1522

95	95
96	96

96		96	96				
97			97				
99	99	100	100				
103		103	103				
107	108	107	107				
117		118	118				
125		126	127				
136		137	138				
	149	149	149				
	161	162	162				
	176	176	176				
	188	189	190	193			
	198	198	200	201	204		
	205	206	207	209	210	212	
	216	216	217	218	219	220	221
	228	229	230	231	232	232	233
	242	243	244	245	246	247	248
	251	252	253	255	256	258	261

000619355

103154

TEMP. DIST.

3-27

CUSTOMER	JOB No.
SUBJECT	BY
CONSTRUCTIONAL SCALE 1/4" = 1"	DATE
METRIC SCALE 1:1000 = 1"	

TEMPERATURES PER SEGMENT USED IN PEAK PRINCIPLE ANALYSIS

OUTSIDE					INSIDE					OUTSIDE					INSIDE														
SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5						
1	25	25	25	25	25	17	43	43	43	43	43	18	43	48	48	48	48	19	58	58	58	58	58	20	68	68	68	68	68
2	25	25	25	25	25	21	73	73	73	73	73	22	73	73	73	73	73	23	73	73	73	73	73	24	80	80	80	80	80
3	25	25	25	25	25	25	90	90	90	90	90	26	97	97	97	97	97	27	107	107	107	107	107	28	113	117	117	116	116
4	25	25	25	25	25	26	97	97	97	97	97	29	120	128	127	126	125	30	140	138	137	136	135	31	157	154	153	151	150
5	25	25	25	25	25	27	163	163	163	163	163	32	173	171	169	167	165	33	190	187	185	182	180						
6	25	25	25	25	25	28	113	117	117	116	116																		
7	25	25	25	25	25	29	120	128	127	126	125																		
8	25	25	25	25	25	30	140	138	137	136	135																		
9	25	25	25	25	25	31	157	154	153	151	150																		
10	26	26	26	26	26	32	173	171	169	167	165																		
11	27	27	27	27	27	33	190	187	185	182	180																		

PEAK FORCES AND MOTIONS

 POSITIVE DIRECTIONS (+) ARE AS FOLLOWS

TOP OF SEGMENT NO.1 BOTTOM OF REMAINING SEGMENTS

RADIAL----- TO THE LEFT RADIAL----- TO THE RIGHT
 ROTATIONAL-- CLOCKWISE ROTATIONAL-- COUNTERCLOCKWISE
 AXIAL----- UPWARD AXIAL----- DOWNWARD

** SIGN CONVENTIONS ARE FOR A RIGHT HAND VIEW **

SEG. NO.	LOC.	RADIAL FORCE	MOMENT	AXIAL FORCE	LOC.	RADIAL MOTION	ROTATION	AXIAL MOTION
1	TOP	0.	7.0211E-04	0.	TOP	-2.9465E-04	-3.3087E-24	0.
1	BOT.	9.8449E-03	-4.4392E-03	0.	BOT.	2.9465E-04	-9.9498E-10	2.2997E-04
2	BOT.	-7.0700E-02	1.1654E-02	0.	BOT.	2.9465E-04	-3.2160E-09	4.5995E-04
3	BOT.	-3.8875E-02	1.6283E-01	0.	BOT.	2.9467E-04	7.6341E-08	6.8992E-04
4	BOT.	4.1011E+00	-1.7502E+00	0.	BOT.	2.9476E-04	-3.4924E-07	9.1987E-04
5	BOT.	-2.6034E+01	3.1766E+00	0.	BOT.	2.9297E-04	-1.7450E-06	1.1500E-03
6	BOT.	-5.5360E+01	1.3273E+01	0.	BOT.	2.9233E-04	-4.2915E-07	1.2076E-03
7	BOT.	-9.1150E+01	3.1703E+01	0.	BOT.	2.9201E-04	3.0378E-06	1.2653E-03
8	BOT.	-1.1205E+02	4.7033E+01	0.	BOT.	2.9223E-04	6.6725E-06	1.2999E-03
9	BOT.	-2.2515E+02	1.4254E+02	0.	BOT.	3.0179E-04	2.1855E-05	1.4281E-03
0	BOT.	-1.4311E+02	2.7304E+02	0.	BOT.	3.1971E-04	3.4593E-05	1.5583E-03
1	BOT.	-1.9517E+01	2.9152E+02	0.	BOT.	3.2866E-04	3.9668E-05	1.6192E-03
2	BOT.	-2.7930E+02	3.6209E+02	0.	BOT.	3.6390E-04	5.8442E-05	1.8230E-03
3	BOT.	-7.2318E+02	8.2201E+02	0.	BOT.	4.1382E-04	9.2482E-05	2.0537E-03
4	BOT.	1.0901E+03	9.6386E+02	0.	BOT.	5.0695E-04	1.4568E-04	2.3067E-03
5	BOT.	2.0218E+03	6.1958E+02	0.	BOT.	5.4432E-04	1.5605E-04	2.3847E-03
6	BOT.	2.0218E+03	6.1958E+02	0.	BOT.	5.6791E-04	1.5605E-04	2.3754E-03
7	BOT.	2.1327E+03	5.3637E+02	0.	BOT.	5.7567E-04	1.5829E-04	2.3911E-03
8	BOT.	2.5149E+03	6.1080E+01	0.	BOT.	6.1622E-04	1.6390E-04	2.4743E-03
9	BOT.	2.0222E+03	-1.1323E+03	0.	BOT.	7.0937E-04	1.3559E-04	2.7089E-03
0	BOT.	-1.0098E+03	-1.5244E+03	0.	BOT.	7.6266E-04	6.7378E-05	2.9928E-03
1	BOT.	-4.1973E+03	-9.2257E+02	0.	BOT.	7.6447E-04	4.3047E-05	3.1560E-03
2	BOT.	-4.1973E+03	-9.2257E+02	0.	BOT.	8.0745E-04	4.3047E-05	3.1520E-03
3	BOT.	-4.0093E+03	-8.4050E+02	0.	BOT.	8.0655E-04	3.8284E-05	3.1605E-03
4	BOT.	-6.7363E+02	2.7369E+02	0.	BOT.	7.8832E-04	8.8333E-06	3.3861E-03
5	BOT.	1.2102E+02	3.8477E+02	0.	BOT.	8.2881E-04	9.4462E-05	3.9041E-03
6	BOT.	-3.2613E+02	4.1673E+02	0.	BOT.	8.8034E-04	1.3676E-04	4.1782E-03
7	BOT.	-1.4507E+03	1.1312E+03	0.	BOT.	1.1029E-03	1.7756E-04	4.6094E-03
8	BOT.	-2.1806E+03	2.7202E+03	0.	BOT.	1.3527E-03	1.9849E-04	5.0813E-03
9	BOT.	-1.7324E+03	4.7157E+03	0.	BOT.	1.6283E-03	2.0837E-04	5.5952E-03

30	BOT.	1.2423E+02	6.2600E-03	0.	BOT.	1.9247E-03	2.0452E-04	6.1528E-03
31	BOT.	1.8142E+03	5.3611E+03	0.	BOT.	2.1591E-03	2.0618E-04	7.1346E-03
32	BOT.	3.1971E+03	2.4920E+03	0.	BOT.	2.3893E-03	1.8782E-04	8.3342E-03
33	BOT.	-0.	-0.	-0.	BOT.	2.5646E-03	1.5159E-04	9.6060E-03

(FORCE AND MOTION OUTPUT IS IN GLOBAL DIRECTIONS R AND Z)

30

30

PLATE THICKNESS = 2.125
OUTSIDE RADIUS = 1.250
INSIDE RADIUS = 1.000
RADIAL INCREMENT = .246
RADIAL INCREMENT = .693
NO. OF ROWS = 5
NO. OF COLUMNS = 11
POISSON'S VALUE = .300

2-31

E AND ALPHA ARE CALCULATED IN PROGRAM

OSC 1522

THE CURV. IS PLATE - DEFLECTION IS CALCULATED IN PROGRAM

	COLUMNS										
	1	2	3	4	5	6	7	8	9	10	11
C	-	-	-	-	-	-	-	-	-	-	11
F	A	5									5
S	I										
T	I										
E	I										
R	I										
L	I										
I	F										
S	G										
E	G	1									3
P	S										
P	I										
A	I										
I	V										
N	-	1									
G											

.....CENTER LINE OF THE VESSEL.....

-----NOTE: FACE ONE IS ON THE BOTTOM OF THE PLATE ON INSIDE OF THE VESSEL FOR TEMPERATURES, MOTIONS AND STRESSES-----

DEFLECTION ON UO = 2.5/1005E-02 BASED ON TEMP. OF 573

TEMPERATURE OF HOLES PER EDGE FOR ITERATION 18169

COLUMNS

	1	2	3	4	5	6	7	8	9	10	11
5	515	516	517	518	519	520	521	522	523	524	525
6	525	526	527	528	529	530	531	532	533	534	535
7	535	536	537	538	539	540	541	542	543	544	545
8	545	546	547	548	549	550	551	552	553	554	555
9	555	556	557	558	559	560	561	562	563	564	565

OSC 1522

3-32

ITERATION = 24157 SIGNIFICS ROTIONS

EDGE ID	STRESS X	STRESS Y	MAXIAL DEF	MAXIAL DEF	ROTATION
1 1	174.8	2924.	-1.08449E-03	3.62732E-03	-7.95332E-05
3 1	201.64242	1.0577.29517	-1.00490E-03	3.77623E-03	-7.95332E-05
5 1	-1415.93717	2.199.53700	-1.00460E-03	3.06100E-03	-7.95332E-05
3 2	2720.17211	0.001.17302	-1.00708E-03	6.00071E-03	1.10875E-04
3 3	3512.00222	0.000.35242	-9.01057E-04	8.40595E-03	2.16251E-04
3 4	2321.30050	2.922.00102	-7.00557E-04	1.00414E-02	2.01207E-04
3 5	450.00000	2100.00574	-5.00000E-04	1.00000E-02	2.00000E-04
3 6	221.00000	1.000.00000	-4.00000E-04	1.00000E-02	2.00000E-04
3 7	100.00000	1000.00000	-2.00000E-04	1.00000E-02	1.00000E-04
3 8	100.00000	1100.00000	-1.00000E-04	2.00000E-02	1.00000E-04
3 9	100.00000	1100.00000	-0.00000E-05	2.00000E-02	9.00000E-05
3 10	100.00000	1000.00000	-1.00000E-05	2.00000E-02	4.00000E-05
1 11	501.00000	35.00000	7.21045E-10	2.01004E-02	1.20035E-10
1 11	2370.45242	0.000.23132	7.21045E-10	2.01004E-02	1.20035E-10
3 11	501.00000	35.00000	7.21045E-10	2.01004E-02	1.20035E-10

DEFLECTION ON U1 = 2.00000E-02 BASED ON TEMP. OF 576

TEMPERATURE OF HOLES PER HOLE FOR ITERATION 1424

COLUMNS

	1	2	3	4	5	6	7	8	9	10	11
5	463	465	500	519	550	501	500	571	572	575	578
4	463	507	520	535	553	502	508	571	572	574	576
3	464	520	534	549	554	505	504	571	573	575	577
2	500	501	500	501	500	504	571	573	573	574	575
1	500	570	571	572	574	573	574	575	575	575	575

3-34

DEFLECTION ON UO = 2.900945E-02 BASED ON TEMP. OF 576

ITERATION = 41920

STRESSES

MILLIONS

EDGE	COR	STRESS X	STRESS Y	AXIAL DEF	RAJIAL DEF	ROTATION
1	1	-13.70030	4500.0/455	-1.29371E-03	3.74939E-03	-6.67773E-05
3	1	-237.21324	1920.7/201	-1.29371E-03	3.82231E-03	-6.67773E-05
5	1	-247.73309	2001.7/207	-1.29371E-03	3.79523E-03	-6.67773E-05
3	2	511.91311	1170.1/125	-1.25237E-03	6.03788E-03	1.55590E-04
3	3	170.02316	4160.1/4200	-1.12000E-03	6.41873E-03	2.04206E-04
3	4	430.21327	3009.0/150	-9.13499E-04	1.08694E-02	3.29179E-04
3	5	571.12602	2010.0/125	-9.89291E-04	1.34003E-02	3.25065E-04
3	6	572.11319	1370.5/147	-9.89291E-04	1.29800E-02	2.79588E-04
3	7	407.12602	1202.1/121	-3.10255E-04	1.05700E-02	2.25599E-04
3	8	520.21327	1140.4/120	-1.74059E-04	2.11800E-02	1.67687E-04
3	9	1571.02309	1001.0/100	-7.74956E-05	2.17937E-02	1.11508E-04
3	10	1223.51302	910.4/100	-1.95237E-05	2.05991E-02	5.71165E-05
1	11	11.70170	572.4/15	-0.00423E-10	2.90094E-02	1.26128E-16
3	11	24-1.52309	0/4.0/170	-8.00423E-16	2.90094E-02	3.26128E-16
5	11	5193.3/100	1245.1/312	-8.00423E-16	2.90094E-02	3.26128E-16

DEFLECTION ON UO = 2.169791E-02 BASED ON TEMP. OF 576

3-35

3-35

Percentage of HOURS per LINE FOR JERALL 20659

COLUMNS

		1	2	3	4	5	6	7	8	9	10	11
C:	5	446	466	477	500	530	541	547	551	552	555	558
L:	4	457	462	497	517	534	543	547	551	552	554	556
U:	3	467	503	516	530	538	545	550	552	553	555	557
P:	2	536	531	535	542	546	549	551	553	554	555	556
F:	1	505	501	501	553	553	555	554	554	554	554	553

3-36

.....750 1.]

W

DEFLECTION ON UO = 2.76971E-02 BASED ON TEMP. OF 556

ITERATION = 52059 STRESSES MOTIONS

EDGE COI STRESS SIGMA H AXIAL DEF RADIAL DEF ROTATION

1	1	231.21327	4219.94207	-1.31220E-03	3.57785E-03	-6.95026E-05
3	1	2152.20913	17042.21250	-1.31298E-03	3.65375E-03	-6.95026E-05
2	1	-3202.61102	20196.90444	-1.31298E-03	3.72964E-03	-6.95026E-05
3	2	4233.60002	2759.04070	-1.20975E-03	5.75092E-03	1.61186E-04
3	3	42-2.47004	5217.80607	-1.13084E-03	0.00655E-03	2.76439E-04
3	4	452.20907	2452.10534	-9.11254E-04	1.05204E-02	1.36450E-04
3	5	365.20909	2119.70207	-6.26233E-04	1.27731E-02	1.26667E-04
3	6	477.10211	1315.22323	-4.76444E-04	1.52426E-02	2.78504E-04
3	7	412.20909	1003.49107	-3.44055E-04	1.7208E-02	2.23025E-04
3	8	377.10211	804.97003	-1.70358E-04	2.02191E-02	1.64535E-04
3	9	332.20909	600.47007	-7.62334E-05	2.21100E-02	1.08699E-04
3	10	312.20909	400.10503	-1.07035E-05	2.52017E-02	5.53594E-05
1	11	1004.97315	1112.94109	1.30770E-16	2.76970E-02	3.13985E-16
3	11	3172.20909	200.20003	1.30770E-16	2.76970E-02	3.13985E-16
5	11	5441.60237	1911.70773	1.30770E-16	2.76970E-02	3.13985E-16

DEFLECTION ON UO = 2.170936E-02 BASED ON TEMP. OF 556

ITERATION = 75157 STRESSES MILLIONS

EDGE	CON	STRESS X	STRESS Y	AXIAL DEF	RADIAL DEF	ROTATION
1	1	300.47093	5227.93003	-1.30457E-03	3.59000E-03	-7.01372E-05
3	1	230.10000	2150.14203	-1.30457E-03	3.66662E-03	-7.01372E-05
5	1	-230.10000	2012.94015	-1.30457E-03	3.74325E-03	-7.01372E-05
3	2	345.57000	4031.32400	-1.30457E-03	3.75200E-03	1.63550E-04
1	3	-202.20109	2100.51100	-1.19703E-03	5.01603E-03	2.77110E-04
3	4	470.97000	3370.70400	-2.03737E-04	1.03479E-02	1.47209E-04
3	5	2102.20109	2100.51100	-1.19703E-04	1.27053E-02	3.42205E-04
3	6	497.70000	1000.57300	-2.13010E-04	1.52330E-02	2.91816E-04
3	7	500.20000	1000.37100	-1.92030E-04	1.77201E-02	2.36057E-04
3	8	412.27117	1000.20073	-1.67700E-04	2.02111E-02	1.70010E-04
3	9	370.20000	1100.07700	-1.55500E-04	2.27134E-02	1.20760E-04
3	10	1000.00000	1000.00000	-2.13010E-04	2.52000E-02	6.24511E-05
1	11	1000.00000	500.00000	2.44000E-16	2.77094E-02	2.23779E-16
3	11	1000.00000	500.00000	2.44000E-16	2.77094E-02	2.23779E-16
5	11	1000.00000	500.00000	2.44000E-16	2.77094E-02	2.23779E-16

OSC 15%

922

ITERATION ON UO = 2.400010E-02 MASED ON TEMP. OF 551

W

TEMPERATURE OF NODES PER HOUR FOR ITERATION 00960

COLUMNS

	1	2	3	4	5	6	7	8	9	10	11	
C:	5	583	581	513	531	564	576	581	585	587	590	593
L:	4	588	575	516	550	567	577	581	585	587	589	592
U:	3	536	540	574	563	573	579	584	586	587	589	590
F:	2	572	587	571	576	580	584	587	588	588	589	590
N:	1	581	580	580	587	584	584	584	589	589	589	590

.....2820 11.....

3-40

34

DEFLECTION ON OP = 2.794719E-02 BASED ON TEMP. OF 591

DEFLECTION = FORCE DEFLECTIONS MILLIONS

EDGE NO	SIGMA X	SIGMA Y	AXIAL DEF	RAJIAL DEF	ROTATION
1 1	135.16998	5104.29767	-1.26072E-03	3.86929E-03	-6.86047E-05
3 1	-102.00007	15204.40315	-1.20072E-03	3.24420E-03	-6.86047E-05
5 1	-102.00001	25157.00071	-1.20072E-03	4.01912E-03	-6.86047E-05
3 2	002.00011	1331.00075	-1.22005E-03	5.26700E-03	1.43232E-04
3 3	002.00020	4700.50031	-1.10917E-03	8.73221E-03	2.52190E-04
3 4	037.00003	13220.07000	-9.02900E-04	1.12020E-02	3.20501E-04
7 5	2017.74442	2201.00020	-6.07233E-04	1.30730E-02	3.19136E-04
3 6	070.00001	1504.00015	-5.52319E-04	1.65347E-02	2.72896E-04
3 7	020.00002	1100.00010	-3.12743E-04	1.92161E-02	2.20986E-04
3 8	060.00004	1007.00032	-1.77093E-04	2.19000E-02	1.67736E-04
3 9	070.00007	1207.00000	-5.01163E-05	2.45997E-02	1.13739E-04
3 10	070.00010	1200.00032	-2.01503E-05	2.72900E-02	5.89579E-05
1 11	000.00000	011.00000	2.00107E-16	2.22072E-02	3.19189E-16
3 11	000.00002	1150.00017	2.00167E-16	2.45072E-02	3.19189E-16
5 11	000.00007	1200.00010	2.00167E-16	2.45072E-02	3.19189E-16

DEFLECTION ON OP = 1.105943E-02 BASED ON TEMP. OF 283

3-41

3-41

TEMPERATURE OF NODES PER EDGE FOR ITERATION 103154

COLUMNS

	1	2	3	4	5	6	7	8	9	10	11
D	247	251	254	259	270	274	277	279	280	281	283
H	253	257	260	265	271	275	277	278	280	281	283
E	254	262	265	268	272	275	277	278	280	281	283
G	256	264	268	271	273	276	278	279	280	281	282
S	269	269	270	271	275	276	277	278	280	281	282

3-42

W
2

000619 DE 0372

DEFLECTION ON UD = 1.10943E-02 BASED ON TEMP. OF 283

ITERATION = 103156 STRESSES MOTIONS

EDGE	COL	SIGMA X	SIGMA Y	AXIAL DEF	RAIAL DEF	ROTATION
1	1	496.96572	4635.23582	-2.64524E-04	1.96801E-03	-1.22271E-05
2	1	-94.05759	6700.70621	-2.04524E-04	1.48130E-03	-1.22271E-05
3	1	-331.10704	2230.10777	-2.64524E-04	1.49871E-03	-1.22271E-05
3	2	1000.10700	3011.10797	-2.55021E-04	2.33803E-03	3.01739E-05
3	3	2057.10710	2710.57704	-2.62905E-04	3.24502E-03	5.20101E-05
3	4	275.00000	2261.00000	-1.02670E-04	4.17592E-03	6.76738E-05
3	5	254.70101	1012.0170	-1.37524E-04	5.13403E-03	6.08275E-05
3	6	247.00000	1320.00000	-9.64733E-05	6.11108E-03	5.04332E-05
3	7	220.00622	1110.62222	-6.10011E-05	7.09442E-03	4.49430E-05
3	8	213.00000	930.77930	-3.42035E-05	8.09353E-03	3.32368E-05
3	9	190.00000	810.00000	-1.54247E-05	9.09161E-03	2.20189E-05
3	10	140.00000	657.61311	-3.04117E-06	1.00930E-02	1.12263E-05
1	11	12-7.65001	435.92202	2.42001E-17	1.10990E-02	3.29597E-17
3	11	172.00000	570.00000	2.42001E-17	1.10990E-02	3.29597E-17
5	11	227.00000	625.00000	2.42001E-17	1.10990E-02	3.29597E-17

3-4B


DEFLECTION ON UD = 2.12403E-02 BASED ON TEMP. OF 550

OSC 1522

CU

E @ 550°

OSC 1522



INFLUENCE COEFFICIENTS

* RING

* OPENING IN A CYLINDER

$$\theta/M_1 = \frac{12}{t^3 E \ln \frac{R_o}{R_i}} = .065 \times 10^{-6}$$

$$\theta/M_2 = \frac{15.6}{Et^3} = .0516 \times 10^{-6}$$

$$S/Q_1 = \frac{R_m}{Et(R_o - R_i)} = .02827 \times 10^{-6}$$

$$S/Q_2 = \frac{1.3}{Et^2} = .00968 \times 10^{-6}$$

$$\theta/Q_1 = S/M_1 = 0.0$$

$$\theta/Q_2 = S/M_2 = 0.0$$

* THESE VALUES BASED ON E @ 550°F

000619 373

BABCOCK & WILCOX		DATE _____
DEPARTMENT _____	BY _____	JOB NO. _____
		SHEET 3-44 0

$$\theta_{RING} = \theta_{CYL}$$

$$M_1 \left(\frac{\theta}{M_1} \right) = M_2 \left(\frac{\theta}{M_2} \right)$$

$$M_1 = \frac{M_2 \left(\frac{\theta}{M_2} \right)}{\frac{\theta}{M_1}}$$

$$\text{say: } \frac{\theta/M_2}{\theta/M_1} = K$$

$$M_1 = M_2 K$$

$$M = M_1 + M_2$$

$$M_2 = M - M_1$$

$$M_1 = (M - M_1) K$$

$$M_1 = \frac{MK}{1+K}$$

$$\theta = M_1 \left(\frac{\theta}{M_1} \right) = \frac{MK}{1+K} \left(\frac{\theta}{M_1} \right) \sim \frac{\theta}{M} = \frac{K}{1+K} \left(\frac{\theta}{M_1} \right)$$

WHERE: $E = E$ FOR CARBON STEEL @ $550^\circ = 26.53 \times 10^6$

$$t = 2.25''$$

$$R_0 = 2.1875''$$

$$R_1 = 1.1875''$$

$$\therefore \frac{\theta}{M} = .0288 \times 10^{-6}$$

BABCOCK & WILCOX
DEPARTMENT _____

BY _____

DATE _____

JOB NO. _____

SHEET 3-45 OF _____

$$S_{RING} = S_{CTRL}$$

$$Q_1 \left(\frac{S}{Q_1} \right) = Q_2 \left(\frac{S}{Q_2} \right)$$

$$Q_1 = (Q_2) \left(\frac{S/Q_2}{S/Q_1} \right)$$

SAY $\frac{S/Q_2}{S/Q_1} = N$

$$Q_1 = Q_2 (N)$$

$$Q = Q_1 + Q_2$$

$$Q_2 = Q - Q_1$$

$$Q_1 = (Q - Q_1) N$$

$$Q_1 = \frac{Q N}{1 + N}$$

$$S_1 = Q_1 \left(\frac{S}{Q_1} \right) = \frac{Q N}{1 + N} \left(\frac{S}{Q_1} \right)$$

$$\frac{S_1}{Q} = \frac{N}{1 + N} \left(\frac{S}{Q_1} \right)$$

WHERE: $R_M = 1.6875''$

$R_0 = 2.1875$

$t = 2.25''$

$E = 26.53 \times 10^{-6} \text{ PSI}$

$$\therefore \frac{S_1}{Q} = .0072 \times 10^{-6}$$

BABCOCK & WILCOX
DEPARTMENT _____

BY _____

DATE _____

JOB NO. _____

SHEET 3-46

$$s = r\theta \quad t/2 = r$$

$$\frac{s}{r} = \left(\frac{t}{2}\right) \left(\frac{\theta}{r}\right)$$

$$\frac{s}{r} = \left(\frac{2.25}{2}\right) (.0288 \times 10^{-6}) = .0324 \times 10^{-6}$$

$$\frac{\theta}{Q} s = \left(\frac{s}{r}\right) \frac{t}{2} = .0324 \times 10^{-6}$$

ADDITIONAL $\frac{s}{Q} = \left(\frac{\theta}{Q}\right) \left(\frac{t}{2}\right) = .03645 \times 10^{-6}$

TOTAL $\frac{s}{Q} = .0072 \times 10^{-6} + .03645 \times 10^{-6} = .04365 \times 10^{-6}$

0006190375

BABCOCK & WILCOX DEPARTMENT _____ BY _____	DATE _____ JOB NO. _____ SHEET <u>3-47</u> OF _____
---	---

INFLUENCE COEFFICIENTS FOR NOZZLE (91206)

$$\theta_N/M = +4.137258 \times 10^{-8}$$

$$\theta_N/Q = -2.47688 \times 10^{-8}$$

$$S_N/M = +2.47688 \times 10^{-8}$$

$$S_N/Q = -5.410859 \times 10^{-8}$$

INFLUENCE COEFFICIENTS FOR SHELL

$$\theta_S/M = -2.88 \times 10^{-8}$$

$$\theta_S/Q = -3.24 \times 10^{-8}$$

$$S_S/M = +3.24 \times 10^{-8}$$

$$S_S/Q = +4.365 \times 10^{-8}$$

0006190371

BABCOCK & WILCOX

DEPARTMENT _____

BY _____

DATE _____


JOB NO. _____

SHEET 3-48 0

MOTIONS @ NOZZLE TO SHELL JUNCTURE
AT THE SHELL (SECONDARY)

+ RADIALS	+ ROTATION	ITERATION
7.5128×10^{-3}	1.8779×10^{-4}	28169
7.4745×10^{-3}	2.3309×10^{-4}	41428
7.0866×10^{-3}	2.4343×10^{-4}	52659
7.0926×10^{-3}	2.4459×10^{-4}	75168
7.7775×10^{-3}	2.2093×10^{-4}	86960
2.9333×10^{-3}	4.6183×10^{-5}	103154

SIGN
CONVENTION



COLUMN BETWEEN
2 & 3

MOTION RATIO PROCEDURE (PROGRAM 91032)


$$\text{MOTION @ JUNCTURE} = \left(\frac{2.1875 - 1.693}{2.386 - 1.693} \right) \times (\text{MOTIONS @ } 2.386 - \text{MOTIONS @ } 1.693) + \text{MOTIONS @ } 1.693$$

000619 373

BABCOCK & WILCOX	BY _____	DATE _____
DEPARTMENT _____		JOB NO. _____
		SHEET <u>3-49</u> 0

MOTIONS @ NOZZLE TO SHELL JUNCTURE
AT THE NOZZLE (SECONDARY)

ITERATION	+ RADIAL S	+ ROTATION
28169	6.3834×10^{-3}	2.6999×10^{-4}
41428	6.4164×10^{-3}	3.9259×10^{-4}
52659	6.1266×10^{-3}	3.4069×10^{-4}
75168	5.8242×10^{-3}	3.1041×10^{-4}
86960	6.3896×10^{-3}	2.8523×10^{-4}
103154	2.5848×10^{-3}	1.5159×10^{-4}



000619379

BABCOCK & WILCOX
DEPARTMENT

BY

DATE

JOB NO.

SHEET

3-50

01

COMPATIBILITY EQUATIONS

$$\Theta_{TOT}^S = -2.88 \times 10^{-8} M - 3.24 \times 10^{-8} Q + \Theta_T^S$$

$$\Theta_{TOT}^N = 4.137258 \times 10^{-8} M - 2.47688 \times 10^{-8} Q + \Theta_T^N$$

$$\Theta_{TOT}^S = \Theta_{TOT}^N$$

$$(-2.88 - 4.137258)(10^{-8})(M) + (-3.24 + 2.47688)(10^{-8})(Q) = \Theta_T^N - \Theta_T^S$$

$$1) -(7.017)(M) - .763Q = (\Theta_T^N - \Theta_T^S)(10^8)$$

$$S_{TOT}^S = 3.24 \times 10^{-8} M + 4.365 \times 10^{-8} Q + S_T^S$$

$$S_{TOT}^N = 2.47688 \times 10^{-8} M - 5.410859 \times 10^{-8} Q + S_T^N$$

$$S_{TOT}^S = S_{TOT}^N$$

$$(3.24 - 2.47688)(10^{-8})(M) + (4.365 + 5.410859)(10^{-8})(Q) = S_T^N - S_T^S$$

$$2) (.763)(M) + (9.776)(Q) = (S_T^N - S_T^S)(10^8)$$



000619

BABCOCK & WILCOX

DEPARTMENT _____

BY _____

DATE _____

JOB NO. _____

SHEET 3-57 OF _____

SOLVING SIMO

$$\begin{aligned} 1) & -7.017M - .763Q = (\theta_T^N - \theta_T^S)(10^8) \\ 2) & .763M + 9.776Q = (\delta_T^N - \delta_T^S)(10^8) \end{aligned}$$

$$\begin{aligned} 1) & -7.017M - .763Q = (\theta_T^N - \theta_T^S)(10^8) \\ 2 \times 9.1966) & 7.017M + 89.906Q = 9.1966(10^8)(\delta_T^N - \delta_T^S) \end{aligned}$$

$$-90.669Q = (\theta_T^N - \theta_T^S)(10^8) - (9.1966)(10^8)(\delta_T^N - \delta_T^S)$$

ITERATION 28169

$$-90.669Q = (2.6999 - 1.8774)(10^4) - (9.1966)(+6.3834 - 7.51)$$

$$-90.669Q = 1046613$$

$$Q = -11534 \text{ \# / RAD}$$

$$1) M = \frac{(2.6999 - 1.8774)10^4 + .763(-11534)}{-7.017} = + 82 \frac{\text{IN-LBS}}{\text{RAD}}$$

ITERATION 41428

$$-90.669Q = (3.9259 - 2.3309)(10^4) - 9.1966(6.4164 - 7.4745)$$

$$= 989042$$

$$Q = -10908 \text{ \# / RAD}$$

$$1) M = \frac{(3.9259 - 2.3309)(10^4) + .763(-10908)}{-7.017}$$

$$M = -1087 \frac{\text{IN-LBS.}}{\text{RAD}}$$

000619381

BABCOCK & WILCOX		DATE _____
DEPARTMENT _____	BY _____	JOB NO. _____
		SHEET <u>3-52</u> OF _____

ITERATION 52659

OSC 1522

$$\begin{aligned} -90.669Q &= (3.4069 - 2.4343)(10^4) - (9.1966)(6.1266 - 7.086) \\ &= 892599.6 \\ Q &= -9845 \text{ #/RAD.} \end{aligned}$$

$$1) M = \frac{(3.4069 - 2.4343)(10^4) + .763(-9845)}{-7.017}$$

$$M = -316 \frac{\text{IN-LBS}}{\text{RAD.}}$$

ITERATION 75168

$$\begin{aligned} -90.669Q &= (3.1041 - 2.4459)(10^4) - (9.1966)(5.8242 - 7.0926) \\ &= 1173078 \\ Q &= -12,938 \text{ #/RAD} \end{aligned}$$

$$1) M = \frac{(3.1041 - 2.4459)(10^4) + (.763)(-12938)}{-7.017}$$

$$M = +469 \frac{\text{IN-LBS}}{\text{RAD}}$$

ITERATION 86960

$$\begin{aligned} -90.669Q &= (2.8523 - 2.2098)(10^4) - 9.1966(6.3896 - 7.7775) \\ &= 1282821 \\ Q &= -14148 \text{ #/RAD} \end{aligned}$$

$$1) M = \frac{(2.8523 - 2.2098)(10^4) + (.763)(-14148)}{-7.017}$$

$$M = 622 \frac{\text{IN-LBS}}{\text{RAD}}$$

BASCOCK & WILCOX
DEPARTMENT _____

BY _____

DATE _____

JOB NO. _____

SHEET 3-53 OF _____

ITERATION 103154

$$-90.669Q = (1.5159 - .46183)(10^4) - (9.1966)(2.5848 - 2.933)$$
$$= 331042$$

$$Q = -3651 \text{ #/RAD}$$


$$1) M = \frac{(1.5159 - .46183)(10^4) + (.763)(-3651)}{-7.017}$$

$$M = -1105 \frac{\text{IN. LBS.}}{\text{RAD}}$$

000619
383

BABCOCK & WILCOX	BY _____	DATE _____
DEPARTMENT _____		JOB NO. _____
		SHEET <u>3-54</u> C

CALCULATE DISCONTINUITY HOOP STRESS IN RING



$$M_1 = .49265 \left[\text{in} \frac{\text{qt}}{2} \right]$$

$$Q_1 = .25506 Q$$

$$S_A = Q_1 \left[\frac{S}{Q_1} \right] + M_1 \left[\frac{S}{M_1} \right]$$

$$S_B = Q_1 \left[\frac{S}{Q_1} \right] - M_1 \left[\frac{S}{M_1} \right]$$

WHERE: $\frac{S}{Q_1} = .02827 \times 10^{-6}$

$$\begin{aligned} \frac{S}{M_1} &= \left(\frac{g}{m_1} \right) \frac{t}{12} \\ &= .065 \times 10^{-6} \left[\frac{\text{in}}{\text{in}} \right] \\ &= .07513 \times 10^{-6} \frac{\text{in}}{\text{in}} \end{aligned}$$

$$\sigma_H^A = \frac{E S_A}{R_i}$$

$$\sigma_H^B = \frac{E S_B}{R_i}$$

$$R_i = 1.1875''$$

ITER	Q_1	M_1	$S_A \times 10^6$	$S_B \times 10^6$	$E \times 10^{-6}$	σ_H^A (PSI)	σ_H^B (PSI)
28169	-2942	-5707	-500.5	+334.2	27.	-11380	7598
41428	-1272	-5913	-468.4	396.5	27.	-10649	9015
52659	-1148	-5043	-401.2	336.3	27.	-9122	7646
75168	-1509	-6235	-498.6	413.3	27.2	-11421	9461
86960	-1650	-6970	-591.7	448.4	26.7	-12180	10081
103154	-426	-2307	-180.8	156.7	28.7	-4370	379

0006190384

BABCOCK & WILCOX

DEPARTMENT _____

BY _____

DATE _____

JOB NO. _____

SHEET _____

3-55

TABULATION OF THERMAL STRESSES
FROM PROGRAM 91032.

OSC 1522

ITER	PSI			
	σ_H IN	σ_H OUT	σ_{T2} IN	σ_{T2} OUT
28169	2830	24200	180	-1905
41428	4566	26508	-13	-3827
52657	4576	26167	231	-3267.
75168	5222	28113	309	-4371
86960	4184	26137	135.	-1698
103154	4695	9236	499	-341

TOTAL THERMAL STRESS INTENSITY

COMBINING FREE THERMAL STRESSES WITH DISCONTINUITY STRESS
STRESS INTENSITY IN KSI

ITER	$S_{IN} = \sigma_H - \sigma_{T2}$ $S_{OUT} = \sigma_H$ $S_{IN} = \sigma_H - \sigma_{T2}$ $S_{OUT} = \sigma_H$			
	$S_1 = \sigma_H - \sigma_{T2}$	$S_2 = \sigma_H$	$S_1 = \sigma_H - \sigma_{T2}$	$S_2 = \sigma_H$
28169	10.2	10.4	14.7	12.8
41428	13.6	13.6	19.7	15.9
52657	12.0	12.2	20.3	17.1
75168	14.4	14.7	21.1	16.7
86960	14.2	14.3	15.9	14.0
103154	7.9	8.4	5.2	4.9

$$S_{MAX} = 21.1 \text{ KSI} < 1.5 S_m = 1.5(17.9) = 26.7 \text{ KSI}$$

NOTE: THE FREE BODY THERMAL STRESSES CALCULATED BY PROGRAM 9103 ARE THE RESULT OF NON-LINEAR THERMAL RADIAL GRADIENTS. THE B31.7 PIPING CODE REQUIRES THAT THE PRIMARY + SECONDARY STRESS VALUE BE DETERMINED USING THE LINEAR PORT OF THE THERMAL RADIAL GRADIENT. THE NON-LINEAR GRADIENT WAS USED IN THIS ANALYSIS, AND SINCE IT IS LARGER MAGNITUDE THAN THE LINEAR PORTION, THE RESULTS ARE CONSERVATIVE.

BABCOCK & WILCOX

DEPARTMENT

BY JMS

DATE 8-72

JOB NO.


SHEET 3-56

00061900385

THERMAL SECONDARY STRESS SUMMARY
OF CRITICAL JUNCTURES

$$S_1 = \sigma_L - \sigma_H \quad S_2 = \sigma_H - \sigma_R \quad S_3 = \sigma_R - \sigma_L$$

INTENSITIES IN KSI



SEGMENT 14 (STAINLESS)

ITER	time	INSIDE			OUTSIDE		
		S ₁	S ₂	S ₃	S ₁	S ₂	S ₃
28169	4.95	-3.6	8.7	-5.1	-4.1	0	4.1
41428	7.50	-3.2	8.9	-5.8	-2.8	-1.1	3.9
52659	9.16	-3.3	8.9	-5.6	-2.7	-1.0	3.7
75168	13.70	-2.4	7.7	-5.3	-2.9	-1.9	3.8
86960	16.099	-2.3	7.2	-4.9	-2.7	-1.8	3.5
103154	17.2	-1.8	2.0	-1.2	-1.4	.4	.9

SEGMENT 21 (STAINLESS)

	S ₁	S ₂	S ₃	S ₁	S ₂	S ₃
28169	5.4	-6.5	1.2	5.4	-4.7	-1.8
41428	3.5	-4.5	1.0	5.0	-5.0	0
52659	4.3	-5.2	.9	4.6	-4.2	-1.4
75168	3.4	-4.4	1.0	4.9	-4.9	0
86960	3.7	-4.3	.5	4.9	-4.8	0
103154	3.9	-5.1	1.2	3.0	-2.1	-1.9

SEGMENT 23 (CARBON)

	S ₁	S ₂	S ₃	S ₁	S ₂	S ₃
28169	-7.7	5.9	1.7	-2.8	4.4	-1.6
41428	-7.7	6.4	1.4	-2.4	2.5	0
52659	-8.1	6.7	1.4	-2.0	3.2	-1.1
75168 13.70	-5.6	3.7	1.9	-1.0	1.4	-1.4
86960	-9.4	8.6	.7	-2.8	3.3	-1.5
103154	-4.8	2.8	2.0	-1.8	2.6	-1.7

385
000619

BABCOCK & WILCOX

DEPARTMENT _____

BY _____

DATE _____

JOB NO. _____

SHEET 3-57 OF _____

STRESS SUMMARY (CONTINUED)

OSC 1522

SEGMENT 26 (CARBON)

ITER	IN SIDE			OUTSIDE		
	S ₁	S ₂	S ₃	S ₁	S ₂	S ₃
28169	2.4	1.8	-4.2	-1.6	-1.9	3.5
41428	3.1	-.1	-2.9	-.8	-1.9	2.7
52659	2.3	1.3	-3.6	-1.6	-1.5	3.1
75168	4.7	-1.7	-3.0	.1	-2.9	2.8
86960	3.5	-.3	-3.2	-.7	-2.1	2.8
103154	1.1	.2	-.9	-.2	-.5	1.8

SEGMENT 33 (CARBON)

	S ₁	S ₂	S ₃	S ₁	S ₂	S ₃
28169	-14.3	14.0	.3	-1.0	.6	.4
41428	-12.2	11.7	.5	1.4	-.6	-.8
52659	-12.6	12.8	-.2	.8	-.5	-.4
75168	-11.8	12.7	-.8	1.6	-1.8	.2
86960	-15.5	16.1	-.6	.2	0	-.1
103154	-3.8	2.9	1.0	.6	0	-.6

MAX. THERMAL STRESS RANGE FOR STAINLESS
OCCURS AT JUNCTURE 14 ON INSIDE

$S_{MAX.} = 8.9 \text{ KSI} < 1.5 S_m = 1.5(17.1) = 25.7$

MAX. THERMAL STRESS RANGE FOR CARBON
IN THE NOZZLE OCCURS AT JUNCTURE 33

$S_{MAX} = 15.5 \text{ KSI} < 1.5 S_m = 26.7 \text{ KSI}$

000619

BABCOCK & WILCOX
DEPARTMENT

BY

DATE

JOB NO.

SHEET 3-58 OF

PEAK PRINCIPAL STRESSES

OSC 1522

SEG. NO.	OUTSIDE			MIDPLANE			INSIDE		
	LONG	HOOP	RAD.	LONG	HOOP	RAD.	LONG	HOOP	RAD.
1	.0	-.0	-.0	-.0	-.0	-.0	-.1	-.1	-.0
2	-.6	-.2	.0	.0	-.0	.0	.7	.2	.0
3	1.1	2.1	-.0	-.1	2.2	.1	-1.3	2.2	.0
4	24.3	-4.4	-.1	-1.4	-14.5	-.6	-27.5	-26.2	-.1
5	-227.9	-41.4	.3	13.7	-17.6	1.0	258.7	59.8	.3
6	-320.8	-65.9	2.0	21.6	38.9	13.7	371.9	163.4	2.0
7	-459.7	-100.1	2.9	31.6	-65.9	19.4	517.6	73.8	2.9
8	-543.4	-122.3	3.1	38.2	-142.0	20.1	633.3	-49.2	3.1
9	-544.8	-136.1	5.4	54.8	-161.1	54.0	634.4	161.2	5.4
10	-544.2	-114.7	15.4	108.8	109.7	170.4	796.8	813.9	15.4
11	-778.2	-173.2	23.2	174.0	102.8	252.6	1045.6	768.8	23.2
12	-1710.9	-1173.6	33.4	225.7	-252.6	294.4	2107.4	1007.2	33.4
13	-3572.5	-1546.8	72.0	404.1	393.2	505.3	4386.7	3239.9	72.0
14	-4101.3	34.2	157.8	500.5	3499.2	1059.5	5080.2	8694.2	157.8
15	-2333.0	491.7	149.5	477.0	3460.4	1350.9	2884.3	7479.4	149.5
17	-1067.4	466.7	117.5	299.3	3246.9	686.5	3164.0	6153.4	117.5
18	-301.2	-458.3	53.3	547.4	-4209.4	373.3	291.3	-5019.2	53.3
19	2910.8	-2290.7	-16.1	-168.9	-2520.2	-9.5	-3702.1	-3405.9	-16.1
20	2403.8	-2420.7	-21.8	-393.9	-2817.1	-134.6	-3220.4	-3534.9	-21.8
21	646.7	-4727.2	-38.1	-266.3	-5364.4	-318.6	-1164.4	-6511.7	-38.1
23	1540.9	-402.2	25.2	-59.8	5052.0	708.9	-1743.5	5925.7	25.2
24	-3083.3	604.1	43.2	272.0	2630.1	308.6	3318.6	4781.2	43.2
25	-2421.4	-1404.2	41.5	247.0	-328.2	761.2	3590.6	1230.5	41.5
26	-3544.9	-1424.0	40.5	48.7	-505.2	255.4	4149.0	1769.7	40.5
27	-1945.5	-2014.2	85.7	9.4	16.5	558.8	2441.2	3478.6	85.7
28	-1544.6	-2014.9	130.1	113.9	264.5	819.3	2099.8	4383.4	130.1
29	-1154.8	-2191.5	166.3	183.1	-49.7	1001.0	1711.9	4191.7	166.3
30	-1184.4	-3013.4	172.5	190.7	-1051.5	964.9	1632.9	2718.0	172.5
31	-2812.8	-1604.8	46.3	541.9	886.6	569.3	3358.7	4845.7	46.3
32	-4031.8	-1557.7	268.7	1239.4	3437.5	1693.6	4832.6	9919.6	268.7
33	-405.8	550.2	441.0	1213.0	6896.0	2875.0	-306.1	13998.7	441.0

2-59

LONGITUDINAL DIRECTION IS ALONG SHELL MIDSURFACE. RADIAL DIRECTION IS NORMAL TO SHELL MIDSURFACE.

3-59

000519 0389
 PEAK PRINCIPAL STRESSES

SEG. NO.	OUTSIDE			MIDPLANE			INSIDE		
	LONG	HOOP	RAD.	LONG	HOOP	RAD.	LONG	HOOP	RAD.
1	.0	-.0	-.0	-.0	-.0	-.0	-.0	-.0	-.0
2	-.1	-.0	.0	.0	.0	.0	.1	.0	.0
3	.3	.3	.0	-.0	.3	.0	-.4	.2	.0
4	2.9	-1.4	-.0	-.2	-2.7	-.1	-3.3	-4.3	-.0
5	-38.9	-9.3	.1	2.3	2.5	.4	44.1	16.9	.1
6	-47.6	-2.0	.4	3.2	15.0	2.4	53.8	35.3	.4
7	-67.1	-49.7	.2	4.7	-86.2	1.1	74.9	-86.2	.2
8	-107.2	-198.2	-.2	6.1	-194.6	-2.5	118.9	-207.4	-.2
9	-325.7	+218.0	.2	23.9	-166.6	-.9	378.4	-101.0	.2
10	-554.5	-146.1	4.4	59.5	27.6	26.4	692.2	308.0	4.4
	-740.4	-234.6	8.9	99.8	-26.9	56.4	933.0	252.3	8.9
12	-1505.3	-1140.4	30.7	192.3	-205.4	208.5	2228.7	1455.0	30.7
13	-3245.8	-1792.4	90.8	462.4	403.8	629.7	4655.3	4171.1	90.8
14	-7847.9	-1059.6	184.6	665.5	2648.2	1295.2	5782.9	8921.4	184.6
15	-2738.4	-1654.4	219.1	720.0	1751.7	1554.1	4388.6	6618.7	219.1
17	-4576.2	-1744.8	91.3	398.5	406.3	474.2	4915.5	2759.6	91.3
18	-2626.0	-1672.0	73.1	229.3	-561.6	435.1	3285.1	1060.6	73.1
19	111.7	-2473.2	38.4	187.4	-1535.8	285.8	-645.3	-1449.2	38.4
20	1014.2	-4349.6	10.0	299.7	-3271.6	90.7	-2361.6	-4292.3	10.0
21	-129.1	-5011.0	-2.2	359.8	-3762.0	-5.3	-992.3	-4444.7	-2.2
23	26.5	2659.4	57.1	732.3	5546.0	443.9	-1336.0	6339.2	57.1
24	-2105.7	144.2	49.9	254.2	1508.8	370.7	2524.0	3011.4	49.9
25	-1502.8	-987.4	24.0	140.0	-465.2	174.8	1975.6	378.2	24.0
26	-2734.6	-1809.4	10.1	228.8	-941.2	138.9	2895.0	-120.4	18.1
27	-2755.6	-2562.9	60.9	145.1	-630.1	428.2	3114.0	2264.4	60.9
28	-1021.9	-2772.8	125.0	290.2	-126.2	846.1	3993.0	4595.8	125.0
29	-2845.3	-2798.8	209.2	463.3	341.2	1367.5	4447.9	6780.2	209.2
30	-2351.2	-2528.0	297.4	616.2	605.4	1880.8	4513.3	8408.7	297.4
31	-3642.6	-2052.4	225.9	853.7	1231.1	1471.9	5889.2	7537.6	225.9
32	-3457.2	-1451.4	340.0	969.6	2597.1	2147.1	5508.3	10498.3	340.0
33	815.9	-565.0	440.3	469.3	4257.4	2769.5	-494.8	11679.9	440.3

3-60

LONGITUDINAL DIRECTION IS ALONG SHELL MIDSURFACE. RADIAL DIRECTION IS NORMAL TO SHELL MIDSURFACE.)

3-60

0006190390

PEAK PRINCIPAL STRESSES

SEG. NO.	OUTSIDE			MIDPLANE			INSIDE		
	LONG	HOOP	RAD.	LONG	HOOP	RAD.	LONG	HOOP	RAD.
1	.0	-.0	-.0	-.0	-.0	-.0	-.0	-.0	-.0
2	-.1	-.0	.0	.0	.0	.0	.1	.0	.0
3	.3	.3	.0	-.0	.3	.0	-.4	.2	.0
4	2.9	-1.3	-.0	-.2	-2.6	-.1	-3.3	-4.2	-.0
5	-38.4	-9.4	.1	2.3	2.2	.4	43.6	16.4	.1
6	-47.4	-2.3	.3	3.2	14.5	2.4	53.5	34.6	.3
7	-67.3	-90.5	.2	4.7	-87.1	1.1	75.1	-87.2	.2
8	-107.9	-189.3	-.2	6.2	-195.7	-2.6	119.7	-208.5	-.2
9	-328.3	-219.7	.2	24.1	-167.9	-.9	381.4	-101.6	.2
10	-558.8	-147.4	4.4	59.9	27.6	26.6	697.6	310.0	4.4
	-746.2	-235.6	9.0	100.6	-25.9	56.9	940.3	256.2	9.0
	-1571.5	-1135.3	30.9	193.2	-195.1	210.1	2236.9	1473.9	30.9
13	-3215.7	-1747.2	91.2	459.5	428.8	632.5	4617.0	4196.1	91.2
14	-3580.9	-1019.9	183.9	647.0	2652.9	1291.6	5572.4	8853.4	183.9
15	-2513.6	-1402.1	216.3	696.0	1746.9	1536.4	4104.9	6520.5	216.3
17	-4271.5	-1660.9	87.4	362.8	454.4	448.5	4545.9	2638.4	87.4
18	-2260.1	-1565.1	68.3	187.4	-619.6	403.3	2840.3	840.2	68.3
19	703.4	-1463.8	26.3	-128.4	-1897.6	186.5	-961.6	-1935.9	26.3
20	1649.8	-3458.8	-15.0	-303.7	-3958.8	-131.2	-2383.9	-4980.2	-15.0
21	433.5	-4177.0	-32.8	-258.7	-4530.7	-283.4	-886.1	-5169.7	-32.8
23	1104.4	3174.5	52.7	-88.7	4762.3	391.9	-1378.4	6706.4	52.7
24	-1997.1	236.0	49.1	213.4	1546.9	343.2	2562.0	3286.3	49.1
25	-2227.0	-1231.4	31.9	179.5	-279.4	193.2	2795.9	1073.0	31.9
26	-7122.4	-1533.0	32.5	136.5	-366.8	214.9	3629.1	1319.1	32.5
27	-2006.7	-1847.9	67.8	65.4	-182.3	469.0	2428.6	2630.0	67.8
28	-1811.3	-1844.0	106.7	137.6	49.8	702.4	2437.7	3697.4	106.7
29	-1565.7	-1491.5	148.5	202.7	29.6	930.1	2358.6	4265.0	148.5
30	-1436.5	-2298.7	178.0	233.1	-372.6	1051.9	2330.1	4087.8	178.0
31	-2686.4	-1593.3	107.3	362.7	758.7	657.0	3914.4	5372.9	107.3
32	-7172.7	-1605.8	277.0	718.8	2550.8	1709.2	4797.0	9982.8	277.0
33	359.5	-470.2	434.2	475.7	4591.8	2718.4	152.0	12755.9	434.2

3-61

(LONGITUDINAL DIRECTION IS ALONG SHELL MIDSURFACE. RADIAL DIRECTION IS NORMAL TO SHELL MIDSURFACE.)

000619 391

PEAK PRINCIPAL STRESSES

SEG. NO.	OUTSIDE			MIDPLANE			INSIDE		
	LONG	HOOP	RAD.	LONG	HOOP	RAD.	LONG	HOOP	RAD.
1	.0	.0	.0	-.0	.0	.0	-.0	.0	.0
2	.1	-.0	-.0	-.0	-.1	-.0	-.2	-.2	-.0
3	-1.5	-.5	.0	.1	-.1	.0	1.7	.4	.0
4	2.1	5.4	.0	-.1	5.7	.1	-2.5	6.2	.0
5	65.9	-10.0	-.2	-3.9	-35.3	-1.6	-74.5	-66.3	-.2
6	31.8	-48.4	-.6	-2.9	-72.7	-4.8	-36.6	-101.8	-.6
7	-30.8	-105.0	-.6	.6	-120.0	-5.0	33.4	-138.9	-.6
8	-109.1	-154.1	-.4	5.4	-152.5	-3.3	121.2	-152.4	-.4
9	-377.4	-228.6	.6	28.8	-163.0	1.9	439.4	-80.4	.6
10	-674.7	-151.0	4.8	65.6	24.2	28.9	754.3	319.1	4.8
11	-740.4	-109.7	12.1	105.4	175.9	78.8	991.3	594.9	12.1
12	-1500.1	-1045.3	28.6	241.6	-163.4	182.2	1993.7	1061.5	28.6
13	-2945.4	-1676.4	73.3	504.0	370.1	472.1	4021.4	3224.4	73.3
14	-3825.7	-903.6	155.3	749.7	2608.6	1030.1	5279.0	7713.1	155.3
15	-2557.1	-176.0	177.7	186.4	983.5	1038.1	5759.2	5695.0	177.7
17	-3691.5	-224.7	69.7	483.9	1299.3	477.0	4646.3	3227.8	69.7
18	-2615.9	-1514.1	63.6	537.7	-29.3	455.0	3156.0	1293.6	63.6
19	-163.5	-2350.6	44.0	45.8	-1416.6	286.7	-288.6	-959.5	44.0
20	812.4	-4059.2	21.6	-348.2	-3448.6	21.0	-1961.0	-3495.8	21.6
21	-37.0	-4426.3	6.6	-333.4	-4371.0	-151.3	-955.7	-4375.8	6.6
23	353.2	1349.9	36.4	401.0	3512.3	184.5	-1894.1	3752.9	36.4
24	-1254.3	418.3	33.5	153.9	1473.0	215.1	1245.2	2445.8	33.5
25	-1239.4	-1213.4	16.9	143.4	-610.0	138.8	1192.1	-257.8	16.9
26	-2811.2	-2914.1	9.8	223.7	-2211.3	77.3	2963.8	-1733.6	9.8
27	-4777.9	-4755.2	72.5	166.2	-1683.9	475.5	5041.3	2243.5	72.5
28	-4473.8	-5775.6	200.9	521.8	-596.2	1266.6	7164.2	6789.9	200.9
29	-6442.3	-6327.1	382.6	964.2	757.9	2348.4	8257.2	11633.3	382.6
30	-4143.8	-6556.8	594.2	1400.8	2089.4	3556.5	8213.8	15977.6	594.2
31	-7462.7	-5317.1	550.4	1922.7	2045.0	3283.1	10227.0	12532.1	550.4
32	-4113.3	-4375.5	573.2	1716.1	2762.8	3448.0	8631.5	13237.5	573.2
33	-238.8	-1805.4	579.9	805.9	4135.2	3564.2	839.6	12674.6	579.9

22-3

(LONGITUDINAL DIRECTION IS ALONG SHELL MIDSURFACE. RADIAL DIRECTION IS NORMAL TO SHELL MIDSURFACE.)

PEAK PRINCIPAL STRESSES

SEG. NO.	OUTSIDE			MIDPLANE			INSIDE		
	LONG	HOOP	RAD.	LONG	HOOP	RAD.	LONG	HOOP	RAD.
1	-0.0	-0.0	-0.0	0.0	-0.0	-0.0	0.0	-0.0	-0.0
2	-0.5	.1	.0	0.0	.3	.0	.5	.5	.0
3	4.2	1.5	-0.0	-0.3	.4	-0.0	-4.8	-1.0	-0.0
4	-3.9	-15.2	-0.1	.3	-16.9	-0.4	4.5	-19.2	-0.1
5	-200.8	21.0	.7	11.8	95.9	4.6	227.1	187.8	.7
6	-115.1	129.3	2.0	9.7	203.9	14.3	131.8	294.5	2.0
7	-10.1	-137.2	.6	4.2	-162.7	4.3	10.5	-207.3	.6
8	4.2	-449.3	-2.4	-2.1	-584.0	-18.5	-10.2	-736.7	-2.4
9	-471.2	-316.9	-1.7	27.3	-247.8	-15.5	545.0	-142.4	-1.7
10	-424.6	-49.6	9.4	88.4	290.9	60.3	1041.0	865.5	9.4
11	-1117.5	-487.6	25.3	17.2	97.0	162.1	1140.8	918.1	25.3
12	-1711.8	-1257.8	42.2	140.0	-261.0	252.2	2093.3	1214.0	42.2
13	-2931.4	-1654.4	78.3	349.5	210.7	467.9	3897.3	3116.3	78.3
14	-3524.2	-797.5	149.2	536.0	2310.3	934.9	4925.9	7228.3	149.2
15	-2517.7	-1124.6	176.6	451.6	1497.0	1170.8	3420.6	5265.5	176.6
16	-744.4	-1145.4	102.9	737.3	1856.0	802.2	3259.7	4021.5	102.9
17	-2326.2	-1418.7	74.7	618.5	-480.1	531.9	2492.7	362.4	74.7
18	545.7	-2297.0	31.8	18.1	-1657.3	177.2	-996.5	-1507.9	31.8
19	1444.7	-3486.4	6.9	-98.7	-3651.6	35.2	-2125.3	-3961.9	6.9
20	135.3	-4790.0	-3.9	-10.1	-4284.5	-38.7	-534.4	-4268.8	-3.9
21	539.7	3370.5	77.9	114.8	5871.5	597.1	-736.6	8649.5	77.9
22	-2249.7	61.2	62.6	190.7	1454.1	473.2	2735.7	3228.8	62.6
23	-1540.0	-416.4	20.9	160.5	-552.1	151.9	1756.6	-240.1	20.9
24	-2526.6	-2097.4	13.4	306.2	-1138.4	72.0	3173.9	-336.1	13.4
25	-3175.5	-3004.2	65.5	155.9	-886.7	437.3	3653.4	2416.5	65.5
26	-7566.9	-3351.2	142.5	283.9	-343.8	1006.3	4680.7	5201.3	142.5
27	-3439.8	-3742.1	243.7	457.7	134.7	1725.8	5181.9	7796.4	243.7
28	-2464.0	-3714.2	349.2	614.4	349.9	2447.4	5212.2	9679.7	349.2
29	-4442.5	-2555.0	296.4	1334.4	1557.9	2212.4	7599.3	9472.7	296.4
30	-5043.4	-2519.0	432.1	1815.0	3682.4	3033.3	7816.9	13333.5	432.1
31	117.7	-76.5	567.9	1580.7	6845.8	3914.2	577.9	16082.1	567.9

3-6B

LONGITUDINAL DIRECTION IS ALONG SHELL MIDSURFACE. RADIAL DIRECTION IS NORMAL TO SHELL MIDSURFACE.

0006190393

PEAK PRINCIPAL STRESSES

SEG. NO.	OUTSIDE			MIDPLANE			INSIDE		
	LONG	HOOP	RAD.	LONG	HOOP	RAD.	LONG	HOOP	RAD.
1	.0	.0	-.0	-.0	-.0	-.0	-.0	-.0	-.0
2	-.0	-.1	-.0	.0	-.1	-.0	.0	-.1	-.0
3	-.8	-.1	.0	.0	.4	.0	1.0	.8	.0
4	6.9	2.9	-.0	-.4	1.0	-.0	-7.8	-1.2	-.0
5	-1.3	-25.2	-.1	.2	-29.8	-.0	1.7	-35.7	-.1
6	-48.6	-50.3	-.0	2.6	-45.0	-.5	54.3	-39.2	-.0
7	-116.5	-71.9	.3	7.0	-47.0	1.8	130.8	-18.0	.3
8	-174.7	-94.8	.8	11.2	-41.4	5.3	196.4	8.5	.8
9	-233.2	-86.2	1.6	20.3	-23.6	10.2	274.7	61.3	1.6
10	-235.7	14.8	4.5	29.4	139.9	30.0	305.8	339.6	4.5
11	-254.7	-34.2	6.1	41.6	66.0	41.3	324.7	192.7	6.1
12	-314.2	-167.0	3.0	44.1	-111.1	17.8	342.8	-56.6	3.0
13	-708.2	-156.4	5.5	84.7	64.2	33.3	646.0	415.0	5.5
14	-907.9	401.6	24.2	122.7	989.0	164.7	1183.3	1957.1	24.2
15	-521.0	161.0	29.8	128.2	515.1	207.9	684.3	915.0	29.8
17	-574.0	288.2	17.7	84.9	652.5	125.0	713.3	1136.3	17.7
18	-70.5	29.6	10.8	38.9	47.3	77.4	92.9	113.5	10.8
19	1263.7	-196.7	-11.6	-117.5	-780.7	-80.0	-1570.5	-1674.2	-11.6
20	1767.7	-1029.2	-42.3	-215.7	-2176.6	-294.1	-2197.0	-3830.2	-42.3
21	917.4	-2052.0	-62.8	-188.4	-3324.8	-455.7	-1205.6	-5078.2	-62.8
23	1747.6	2598.6	5.2	-105.8	2665.8	55.3	-1965.5	2814.2	5.2
24	-704.6	747.8	11.2	66.7	1230.5	89.6	824.3	1824.9	11.2
25	-831.4	-268.1	9.0	75.4	-16.2	63.4	955.3	252.7	9.0
26	-763.6	-526.5	4.1	58.5	-380.9	26.0	869.3	-229.0	4.1
27	-767.4	-740.7	15.8	32.6	-236.9	96.1	793.1	507.1	15.8
28	-972.0	-422.4	36.5	83.7	-53.6	214.4	1063.6	1227.4	36.5
29	-1015.5	-1024.3	64.6	144.9	109.5	368.1	1174.2	1882.9	64.6
30	-945.0	-1123.8	94.8	200.2	215.4	522.2	1148.5	2373.4	94.8
31	-1149.0	-744.0	65.7	209.6	305.2	354.3	1445.2	1804.7	65.7
32	-944.5	-550.1	93.5	178.7	693.5	543.1	1180.2	2648.0	93.5
33	625.2	42.4	117.5	-44.5	1162.2	720.3	-906.4	2922.0	117.5

364

(LONGITUDINAL DIRECTION IS ALONG SHELL MIDSURFACE. RADIAL DIRECTION IS NORMAL TO SHELL MIDSURFACE.)

FATIGUE ANALYSIS

IT CAN BE SEEN THAT THE HIGHEST STRESSED LOCATION IS AT THE INSIDE OF THE NOZZLE NEAR THE NOZZLE TO RUN PIPE INTERSECTION. THIS IS CARBON STEEL WHICH HAS THE WORST FATIGUE PROPERTIES. THEREFORE, JUSTIFICATION OF THIS POINT WILL JUSTIFY THE ENTIRE VICINITY OF THE BRANCH.

S_{MAX} THERMAL STRESS RANGE = 21.1 KSI (PAGE 3-56)

S_{MAX} PRESSURE STRESS INTENSITY = $\frac{3.3 P R_p}{t_p} = 29.55 P$

WHERE: $R_p = 14.3125 + \frac{2.0625}{2} = 15.344"$ $t_p = 2.0625"$

$S_{PEAK} = 21.1 + 2500(29.55) = 82.5$ KSI

$S_{ACT} = 41.3$ KSI FOR 240 CYCLES [HEAT-UP & COOL-DOWN]

$N_{ALLOW} = 6000$ CYCLES

$U_1 = \frac{240}{6000} = 0.04$

0006190391

BABCOCK & WILCOX DEPARTMENT	DATE 8-72	BY <i>JML</i>	REVISION
	CHECKED DATE	BY	
	JOB NO.		SHEET 3-65 OF

CASE 3

MAX. FLUCTUATION OF THERMAL STRESS EXCLUDING HEAT-UP AND COOL-DOWN VALUES
= 21.1 - 14.7 = 6.4 KSI (SEE PAGE 3-56)

MAX. FLUCTUATION OF PRESSURE EXCLUDING HEAT-UP AND COOL-DOWN = 2500 - 1700 (REACTOR TRIP 8B) = 800 PSI

$S_{PEAK} = 6.4 + .8(29.55) = 26.0 \text{ KSI}$

$S_{ALT} = 13.0 \text{ KSI} \quad N_{ALLOW} = 30,000 \text{ CYCLES}$

ACTUAL CYCLES = 160 (TRIP 8B) $U_3 = \frac{160}{30000} = 0.005$

CASE 4

NEXT MAX. PRESSURE RANGE IS LESS THAN 300 PSI FOR ALL OTHER TRANSIENT CONDITIONS

\therefore NEXT LARGEST $S_{PEAK} = 6.4 + .3(29.55) = 13.8 \text{ KSI}$

$S_{ALT} = 6.9 \text{ KSI} \quad N_{ALLOW} = \infty \quad \therefore U = 0.0$

CUMULATIVE NOZZLE USAGE FACTOR, $U_{TOT} = U_1 + U_3 = 0.09 + 0.005 = 0.095$

$0.095 < 1.0$

O.K.

BABCOCK & WILCOX
DEPARTMENT

DATE 2-72

BY *[Signature]*

REVISION

CHECKED DATE

BY

JOB NO.

SHEET 366 OF

SECTION 4

Temperature Distribution of High Pressure Injection Nozzle

The high pressure injection nozzle only has flow through it for two conditions. One is a test condition when 60°F water is injected at 100 gallons per minute for 10 seconds. The second condition is during rapid depressurization when the reactor pressure goes below 1500 psi. This condition is defined as 60°F water injection for 45 sec. with a continuation for 15 minutes at 40°F water. The flow rate is 425 gpm. All other times the nozzle essentially follows the cold leg fluid temperature.

The same thermal model and B&W Program 91167 were used in the analysis of the RPI (See Section 2). The figures showing the transients run are on Pages 4344 These pages are followed by time-temperatures plots of selected nodes and a discussion of selection of critical times. Finally the actual temperature distribution is shown for the selected times for stress calculation.

FILM COEFFICIENTS

THE COLD LEG FLUID COEFFICIENTS ARE THE SAME AS IDENTIFIED IN SECTION 2. THE HIGH PRESSURE INJECTION FLUID FILM COEFFICIENTS ARE CALCULATED IN THE SAME MANNER FOR TURBULENT FLOW. A FILM COEFFICIENT OF 35 BTU/°F-HR-FT² IS USED FOR THE NO FLOW CONDITION.

FILM COEFFICIENT FOR TEST CONDITION

$$hD^{.2} = .023 \left(\frac{G}{\mu}\right)^{.8} \left(\frac{C_p \mu}{K}\right)^{.4}$$

WHERE: FOR 60°F WATER AT 100 gpm

$$C_p = 1 \quad \mu = 2.71 \quad K = .344 \quad 62.34 \text{ lbs} = 1 \text{ Cu. FT. OF WATER}$$

1 IN BRANCH

$$D_i = 2.125'' = .177' \quad \text{AREA} = .0246 \text{ FT}^2 \quad D^{.2} = .707$$

$$G = \frac{\text{lb}}{\text{FT}^2 \cdot \text{HR}} = 100 \frac{\text{GAL}}{\text{MIN}} \cdot \frac{60 \text{ MIN}}{\text{HR}} \cdot \frac{1 \text{ Cu. FT.}}{7.48 \text{ GAL}} \times \frac{62.34 \text{ lb}}{1 \text{ Cu. FT.}} \times \frac{1}{.0246}$$

$$= 2032466 \text{ lb/FT}^2 \cdot \text{HR}$$

$$hD^{.2} = .023 (.344) (50124) (2.289) = 906$$

$$h = \frac{906}{.707} = 1281 \quad \text{USE } \underline{1300} \text{ BTU/HR-°F-FT}^2$$

INSIDE SLEEVE

$$D_i = 1.5'' = .125' \quad \text{AREA} = .01227 \quad D^{.2} = .66$$

$$G = 4074871$$

$$hD^{.2} = .023 (.344) (87441) (2.289) = 1580$$

$$h = \frac{1580}{.66} = 2394 \quad \text{USE } \underline{2400} \text{ BTU/HR-°F-FT}^2$$

FILM COEFFICIENTS (CONTINUED)

RAPID DEPRESSURIZATION

FOR 60°F WATER: $C_p = 1$ $\rho = 62.34 \text{ lb/CO FT}$ $\mu = 2.71$
 $K = .344$

IN BRANCH

$$G = 2032466 \left(\frac{425}{100} \right) = 8637981$$

$$h D^{.2} = .01907 [3187447]^{.8} = 2882$$

$$h = 2882 / .707 = 4076 \quad \text{USE } \underline{4100} \text{ BTU/HR-°F-FT}^2$$

INSIDE SLEEVE

$$G = 4074871 (4.25) = 17318201$$

$$h D^{.2} = .01807 [6390780]^{.8} = 5028$$

$$h = 5028 / .66 = 7618 \quad \text{USE } \underline{8000} \text{ BTU/HR-°F-FT}^2$$

FOR 40°F WATER: $C_p = 1.005$ $\rho = 62.42$ $\mu = 3.75$ $K = .332$

IN BRANCH

$$G = 8637981 \left[\frac{62.42}{62.34} \right] = 8649066$$

$$h D^{.2} = .023 (.332) [2306418]^{.8} [2.64] = 2482$$

$$h = 2482 / .707 = 3510 \quad \text{USE } \underline{3600} \text{ BTU/HR-°F-FT}^2$$


INSIDE SLEEVE

$$h = 4330 / .66 = 6561 \quad \text{USE } \underline{6600} \text{ BTU/HR-°F-FT}^2$$

0006190390

OSC 1522

0006120399




TEMPERATURE °F

TIME (HRS)

OPER	JOB No.
SUBJECT FLUID TRANSIENT FOR NO FLOW IN HIGH PRESSURE INJECTION NOZZLE	BY
	DATE 4-3

0006190400





OWNER _____
 SUBJECT TEMPERATURE TRANSIENT FOR
 TEST TRANSIENT AND RAPID DEPRES-
 SURIZATION

JOB No. _____
 BY _____
 DATE 4-4

0 0 0 6 1 9 3 4 0 1

CUSTOMER	
SUBJECT	WASH. REGIONAL WATER TREATMENT PLANT
HEAT-UP AND LEVEL MANAGER	
DATE	4-5
BY	
JOB NO.	

600
550
500
450
400
350
300
250
200
150
100
70



+ MEANS FIRST NODE HOTTEST
TIME 0 → 7.5 HRS

MAX ΔT BETWEEN 66 + 72 = +16°F	5.25 HRS,
MAX ΔT BETWEEN 72 + [102, 106] = +7°F	4.95 HRS,
MAX ΔT BETWEEN 106 + 143 = -8°F	4.95 HRS.
MAX ΔT BETWEEN 143 + 189 = -24°F	4.95 HRS.

TIME 7.5 → 10.5 HRS.

ΔT 66 + 72 = -6°F	7.6 HRS
ΔT 72 + (102, 106) = -4	7.6 HRS.
ΔT 106 + 143 = +4	7.6 HRS
ΔT 143 + 189 = 12°F	7.55 HRS,
	11°F
	7.6 HRS.

TIME 10.5 HRS. → 10.81 HRS

ΔT 66 + 72 = 10°F	10.59 HRS,
ΔT 72 + (102, 106) = 6	10.59
ΔT 106 + 143 = -7	10.63
ΔT 143 + 189 = -23	10.57

TIME 10.81 → 11.5

ΔT 66 + 72 = -7	10.94 HRS.
ΔT 72 + (102, 106) = -5	10.93
ΔT 106 + 143 = +4	10.93
ΔT 143 + 189 = 116	10.91




HOURS AFTER HEAT-UP STARTS

115-2032

000619 0402

STOWER
SUBJECT TEST TRANSIENT
TIME-TEMPERATURE PLOT

ON BUR
BY
DATE 4-6




2 4 6 8 10 20 30 40 50 60 1.2 3.75 1.0

TIME (HR x 10⁴)

TIME (HRS)

000819 403



TIME AFTER RAPID DEPRESSURIZATION STARTS HR. (x10⁴)

TIME IN HOURS CORRESPONDING TO 9/167.

CUSTOMER: ALCOA FERTILIZER DIVISION


SUBJECT: TEMPERATURE LOG

JOB NO.:

BY:

DATE: 4-7

0006192404





1.25 1.35 1.40 1.45 1.5 1.55 1.6 1.65 1.7 1.75 1.8 1.85 1.9 2.0 2.05 2.1 2.15 2.2 2.25 2.3 2.35

TIME CORRESPONDS TO 91167 IN ABOVE

CUSTOMER	JOB No.
SUBJECT INITIATION OF 2306-DRAIN AFTER HIGH PRESSURE INJECTION	BY
	DATE 9-8

000619405



15 MIN

10 SEC 20 SEC 2 MIN

KAPPA DEPRESSURIZATION

10 SEC 20 SEC




TEST TRANSIENT

CUSTOMER	JOB No.
SUBJECT TEST OF SHELL TEMPERATURE RESPONSES (FOR NET TEST AND KAPPA DEPRESSURIZATION)	BY
	DATE 4-7

HPI STRESS CASES

<u>ITERATION</u>	<u>TIME</u>	<u>EXPLANATION</u>
27967	4.95 Hrs.	End of Heat-Up - No flow condition See Page 4-5
41491	7.5 Hrs.	Steady State Temperature at 575 Hottest temperature in vicinity of Bi-metal weld.
42021	7.6 Hrs.	Reversal in Axial gradient from 27967. See Page 4-5
3, 6, 8	0 - 10 Secs.	Maximum radial gradient stress during test transient. See Page 8-6
15	10.7 Sec. from start of test	Maximum axial gradient in upper part of nozzle
30	21.4 Sec. after test	Reversal of radial gradient
1211	14.8 min. after test	Reversal of axial gradient in upper part of nozzle
5060, 5063, 5072	0-10 Secs. after start of rapid depress- urization	Maximum radial gradient stress in radid depressurization. See Page 4-7
5124	1.015 Hrs. .9 min. after start of rapid depressurization	One location of possible maximum axial gradient stress. See Page 4-7.
5237	1.0384 Hrs.	Possible maximum axial gradient stress
6059	1.2 hrs.	Possible maximum axial gradient stress.
6307	1.248 hrs.	End of 40°F water injection
6338	1.254 hrs.	Reversal of radial gradient and reversal of axial gradient. See Page 4-8
6850	1.35 hrs.	Reversal of axial gradient.

0 0 0 6 1 9 0 4 0 7



1.24877 HRS. 1.27877 1.30877

TIME (EACH BLOCK = .0002 HRS.) 1.00000 HRS.

TIME (EACH BLOCK = .002 HRS.)

CUSTOMER		JOB NO.	
SUBJECT PLANT OF RADIAL GENERATOR THROUGH		BY	
UNITED STATES AND CANADIAN DIVISION		DATE	
		4-10	

52 528 527


000519 D400

	550	550	550			
	551	551	551			
	552	552	552			
542	542	542	541	550		
541	540	540	540	548		
548	548	547	547	546		
546	545	545	544	544		
545	544	543	542	542		
	541	540	540	540		
	539	539	539	538		
	538	538	538	537		
	537	537		537		
	537	537		537		
	537	537		537		
	538	538	538	538		
	539	539	539	539	540	
	540	540	540	540	540	540
542	542	542	542	542	542	542
547	546	546	546	546	546	546
553	553	553	553	553	554	554
559	559	559	559	560	560	562

TEMP. FOR ITER 27967

CUSTOMER	JOB NO.
SUBJECT 91167 GND TO SCALE	
CONSTITUTIONAL SCALE 4 BLOCKS = 1"	BY
RADIAL SCALE 16 BLOCKS = 1"	DATE 4-12

000619409



CONSTANT TEMP. 575° F

TEMP. FOR ITER 41491

CUSTOMER	JOB No.
SUBJECT 91167 GRID TO SCALE	
CONSTRUCTIONAL SCALE 1" = 1"	BY
DRAWING SCALE 1" = 1"	DATE 4-13

OSC 1522

0006190410

S66	S66	S66	S66	S66	
S67	S67	S67	S67	S67	
S68	S68	S68	S68	S68	
S69	S69	S69	S69	S69	
S70	S70	S70	S70	S70	
S71	S71	S71	S71	S71	
S72	S72	S72	S72	S72	
S72	S72	S72	S72	S72	S72
S71	S71	S71	S71	S71	S71
S70	S70	S70	S70	S70	S70
S69	S69	S69	S69	S69	S69
S68	S68	S68	S68	S68	S68
S67	S67	S67	S67	S67	S67
S66	S66	S66	S66	S66	S66

TEMP. FOR ITER 42021

CUSTOMER	JOH No.
SUBJECT 71167 GRID TO ...	BY
CONSTRUCTION SCALE 1/4" = 1"	DATE 4-14
REVISION SCALE 1/4" = 1"	

TEMPERATURES PER SEGMENT USED IN PEAK PRINCIPLE ANALYSIS
 IYEE 3

OUTSIDE					INSIDE						
SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5
1	468	458	420	330	169	17	480	480	480	480	480
2	468	458	420	330	169	18	480	480	480	480	480
3	468	458	420	330	169	19	480	480	480	480	480
4	468	458	420	330	169	20	480	480	480	480	480
5	475	468	437	350	168	21	480	480	480	480	480
6	475	468	437	350	168	22	480	480	480	480	480
7	475	468	437	350	168	23	480	480	480	480	480
8	475	468	437	350	168	24	480	480	480	480	480
9	477	474	456	394	178	25	480	480	480	480	480
10	480	480	476	438	188	26	480	480	480	480	480
11	480	480	476	438	188	27	480	480	480	480	480
12	480	480	477	470	305	28	480	480	480	480	480
13	480	480	477	470	307	29	480	480	480	480	480
14	480	480	477	470	308	30	480	480	480	480	480
15	480	480	477	470	310	31	480	480	480	480	480
16	480	480	480	480	480	32	480	480	480	480	480
						33	480	480	480	480	480

THESE TEMP. ARE T-70°

TEMPERATURES PER SEGMENT USED IN LEAK PRINCIPLE ANALYSIS

OUTSIDE					INSIDE					OUTSIDE					INSIDE				
SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5		
1	422	405	353	260	127	17	480	480	480	480	480	18	480	480	480	480	480		
2	422	405	353	260	127	18	480	480	480	480	480	19	480	480	480	480	480		
3	422	405	353	260	127	19	480	480	480	480	480	20	480	480	480	480	480		
4	422	405	353	260	127	20	480	480	480	480	480	21	480	480	480	480	480		
5	447	432	380	280	127	21	480	480	480	480	480	22	480	480	480	480	480		
6	447	432	380	280	127	22	480	480	480	480	480	23	480	480	480	480	480		
7	447	432	380	280	127	23	480	480	480	480	480	24	480	480	480	480	480		
8	447	432	380	280	127	24	480	480	480	480	480	25	480	480	480	480	480		
9	463	454	421	332	127	25	480	480	480	480	480	26	480	480	480	480	480		
10	479	477	462	385	127	26	480	480	480	480	480	27	480	480	480	480	480		
11	479	477	462	385	127	27	480	480	480	480	480	28	480	480	480	480	480		
12	480	480	480	440	235	28	480	480	480	480	480	29	480	480	480	480	480		
13	480	480	480	442	237	29	480	480	480	480	480	30	480	480	480	480	480		
14	480	480	480	443	238	30	480	480	480	480	480	31	480	480	480	480	480		
15	480	480	480	445	240	31	480	480	480	480	480	32	480	480	480	480	480		
16	480	480	480	480	480	32	480	480	480	480	480	33	480	480	480	480	480		

THESE TEMP. ARE T-70

000519

3

1113

TEMPERATURES PER SEGMENT USED IN PEAK EFFICIENCY ANALYSIS

Tree 8

SEGMENT	OUTSIDE				INSIDE				SEGMENT	OUTSIDE				INSIDE
	T1	T2	T3	T4	T5	T6	T7	T8		T9	T10	T11	T12	
1	385	369	317	231	111	17	680	480	480	480	480	480	480	480
2	385	369	317	231	111	18	480	480	480	480	480	480	480	480
3	385	369	317	231	111	19	480	480	480	480	480	480	480	480
4	385	369	317	231	111	20	480	480	480	480	480	480	480	480
5	421	403	349	252	112	21	480	480	480	480	480	480	480	480
6	421	403	349	252	112	22	480	480	480	480	480	480	480	480
7	421	403	349	252	112	23	480	480	480	480	480	480	480	480
8	421	403	349	252	112	24	480	480	480	480	480	480	480	480
9	449	438	399	305	112	25	480	480	480	480	480	480	480	480
10	478	474	450	358	112	26	480	480	480	480	480	480	480	480
11	478	474	450	358	112	27	480	480	480	480	480	480	480	480
12	480	480	465	410	210	28	480	480	480	480	480	480	480	480
13	480	480	465	412	212	29	480	480	480	480	480	480	480	480
14	480	480	467	413	215	30	480	480	480	480	480	480	480	480
15	480	480	468	415	217	31	480	480	480	480	480	480	480	480
16	480	480	480	480	480	32	480	480	480	480	480	480	480	480
						33	480	480	480	480	480	480	480	480

THESE TEMP ARE T70

T_{FLUID} = 550

n = 35

000619

	357	353	352			
	360	352	361			
	357	357	357			
412	417	422	451	492		
424	431	402	471	501		
413	430	452	480	511		
416	434	452	485	514		
420	441	467	492	519		
	519	526	544	541		
	534	540	540	547		
	537	542	545	548		
	544	543		547		
	544	546		547		
	544	546	547	547		
	544	548	547	549		
	544	546	548	549	550	
	544	546	547	549	550	
	544	546	549	549		550
	544	545	549	549		
	544	543	549	549		
	543	540	549	549	550	550

TEMP. FOR ITER 30

CUSTOMER	JOB NO.
SUBJECT 71167 GRID TO SCALE	
CONSTRUCTION SCALE 1" = 100'	BY
MINIMUM SCALE 1" = 100'	DATE 4-19

S40 S39 S38

TFLUID = 550
h = 35

S38	S38	S37					
S35	S35	S35					
S32	S31	S31	S30	S30			
S30	S29	S29	S29	S29	S29		
S30	S29	S29	S29	S28			
S30	S29	S29	S29	S28			
S30	S30	S29	S29	S29			
S30	S29	S30	S30				
S32	S30	S31	S31				
S33	S32	S33	S33				
S33	S32	S35	S35				
S35	S38	S38	S38				
S37	S40	S40	S40				
S40	S41	S42	S42	S42			
S41	S43	S43	S43	S43	S43		
S43	S44	S44	S44	S44	S44	S44	
S44	S45	S45	S45	S45	S45	S45	S45
S45	S46	S46	S46	S46	S46	S46	S46
S46	S47	S47	S47	S47	S47	S47	S47
S47	S48	S48	S48	S48	S48	S48	S48

TEMP. FOR ITER 1211

CUSTOMER	JOHNSON	JOB No.	
SUBJECT	91167 GRID TO ...	BY	
CONSTRUCTION	SCALE 1" = 1'	DATE	4-20
REVISION	SCALE 1" = 1'		

000619

ITERATION 5000

TEMPERATURES PER SEGMENT USED IN PEAK PRINCIPLE ANALYSIS

OUTSIDE					INSIDE						
SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5
1	478	473	445	340	76	17	480	480	480	480	480
2	478	473	445	340	76	18	480	480	480	480	480
3	478	473	445	340	76	19	480	480	480	480	480
4	478	473	445	340	76	20	480	480	480	480	480
5	479	477	458	367	74	21	480	480	480	480	480
6	479	477	458	367	74	22	480	480	480	480	480
7	479	477	458	367	74	23	480	480	480	480	480
8	479	477	458	367	74	24	480	480	480	480	480
9	479	478	468	408	81	25	480	480	480	480	480
10	479	479	478	450	91	26	480	480	480	480	480
11	479	479	478	450	91	27	480	480	480	480	480
12	480	480	480	480	370	28	480	480	480	480	480
13	480	480	480	480	372	29	480	480	480	480	480
14	480	480	480	480	373	30	480	480	480	480	480
15	480	480	480	480	375	31	480	480	480	480	480
16	480	480	480	480	480	32	480	480	480	480	480
						33	480	480	480	480	480

THESE TEMP. ARE T-70

ITERATION 5063

TEMPERATURES PER SEGMENT USED IN PEAK PRINCIPLE ANALYSIS

OUTSIDE					INSIDE					OUTSIDE					INSIDE				
SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5		
1	407	386	317	200	38	17	480	480	480	480	480	17	480	480	480	480	480		
2	407	386	317	200	38	18	480	480	480	480	480	18	480	480	480	480	480		
3	407	386	317	200	38	19	480	480	480	480	480	19	480	480	480	480	480		
4	407	386	317	200	38	20	480	480	480	480	480	20	480	480	480	480	480		
5	439	419	352	225	38	21	480	480	480	480	480	21	480	480	480	480	480		
6	439	419	352	225	38	22	480	480	480	480	480	22	480	480	480	480	480		
7	439	419	352	225	38	23	480	480	480	480	480	23	480	480	480	480	480		
8	439	419	352	225	38	24	480	480	480	480	480	24	480	480	480	480	480		
9	458	448	407	298	37	25	480	480	480	480	480	25	480	480	480	480	480		
10	478	477	462	372	37	26	480	480	480	480	480	26	480	480	480	480	480		
11	478	477	462	372	37	27	480	480	480	480	480	27	480	480	480	480	480		
12	480	480	478	440	255	28	480	480	480	480	480	28	480	480	480	480	480		
13	480	480	479	442	271	29	480	480	480	480	480	29	480	480	480	480	480		
14	480	480	479	443	286	30	480	480	480	480	480	30	480	480	480	480	480		
15	480	480	480	445	302	31	480	480	480	480	480	31	480	480	480	480	480		
16	480	480	480	480	480	32	480	480	480	480	480	32	480	480	480	480	480		
						33	480	480	480	480	480	33	480	480	480	480	480		

THESE TEMP. ARE T-70

STRESS ANALYSIS OF HIGH PRESSURE INJECTION NOZ HEAD/KC

ITERATION 5072

TEMPERATURES PER SEGMENT USED IN PEAK PRINCIPLE ANALYSIS

OUTSIDE					INSIDE					OUTSIDE					INSIDE								
SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5
1	245	230	184	112	18	17	480	480	480	480	480	18	480	480	480	480	480	19	480	480	480	480	480
2	245	230	184	112	18	18	480	480	480	480	480	19	480	480	480	480	480	20	480	480	480	480	480
3	245	230	184	112	18	19	480	480	480	480	480	20	480	480	480	480	480	21	480	480	480	480	480
4	245	230	184	112	18	20	480	480	480	480	480	21	480	480	480	480	480	22	480	480	480	480	480
5	307	289	232	141	21	21	480	480	480	480	480	22	480	480	480	480	480	23	480	480	480	480	480
6	307	289	232	141	21	22	480	480	480	480	480	23	480	480	480	480	480	24	480	480	480	480	480
7	307	289	232	141	21	23	480	480	480	480	480	24	480	480	480	480	480	25	480	480	480	480	480
8	307	289	232	141	21	24	480	480	480	480	480	25	480	480	480	480	480	26	480	480	480	480	480
9	386	370	314	202	22	25	480	480	480	480	480	26	480	480	480	480	480	27	480	480	480	480	480
10	465	452	397	264	23	26	480	480	480	480	480	27	480	480	480	480	480	28	480	480	480	480	480
11	465	452	397	264	23	27	480	480	480	480	480	28	480	480	480	480	480	29	480	480	480	480	480
12	480	467	437	340	190	28	480	480	480	480	480	29	480	480	480	480	480	30	480	480	480	480	480
13	480	469	441	346	194	29	480	480	480	480	480	30	480	480	480	480	480	31	480	480	480	480	480
14	480	470	446	351	197	30	480	480	480	480	480	31	480	480	480	480	480	32	480	480	480	480	480
15	480	472	450	357	201	31	480	480	480	480	480	32	480	480	480	480	480	33	480	480	480	480	480
16	480	480	480	480	480	32	480	480	480	480	480	33	480	480	480	480	480						

THESE TEMP. ARE T-70

OSG 1522

FLUID 40°F
h = 4100

40	41	42
49	48	51
52	62	69

57	76	95	111	131			
65	92	116	135	159			
96	123	147	166	185			
112	145	174	197	219			
133	185	223	250	275			
	334	374	354	364			
	339	403	411	418			
	428	438	446	453			
		463	466	470			
		473	477	480			
		483	487	491			
	494	497	505	511			
	502	507	513	519	524		
	506	511	518	524	529	532	
	510	515	522	529	533	536	538
	511	516	523	530	535	538	539
	516	516	523	530	535	538	540
	511	517	524	531	536	540	543

00061800420

TEMP. FOR ITER 5237

CUSTOMER	JOB No.
SUBJECT 71167 GRID TO ...	
BY	
DATE	4-24

OSC 1522

40	40	40
40	40	40
40	40	40

40	41	42	42			
41	42	43	44	44		
44	46	47	49	50		
49	52	56	59	61		
58	67	74	80	84		
114	116	119	112			
146	149	151	154			
178	182	185	188			
219	220	222				
258	260	262				
299	302	304				
330	340	345	355			
362	366	372	380	387		
381	386	391	398	404	410	
403	407	413	419	424	428	431
424	428	434	440	444	447	449
443	448	454	460	465	469	470
455	460	467	474	481	485	492

00061900421

TEMP. FOR 6059

CUSTOMER	JOB NO.
SUBJECT <i>71157 GRID TO ...</i>	
<i>CONSTRUCTION SCALE 4" = 1"</i>	BY
<i>GRIDING SCALE 1" = 1"</i>	DATE <i>4-25</i>

OSC 1522

40		40	
40			42
		43	43
43	45	47	48
47	50	53	55
55	62	68	73
102	109	106	107
127	132	134	136
158	162	165	167



SAME AS ITER 6338

	195	197	198

0006100422

ITER 6307

CUSTOMER	JOB No.
SUBJECT 7167 GRID TO SCALE LONGITUDINAL SCALE 1" = 100' 1"	BY
TRANSVERSE SCALE 1" = 100' 1"	DATE 4-26

88	75	68
87	74	67
84	71	64

70	76	63	55	47		
84	71	61	54	48		
79	68	60	55	51		
81	72	66	62	59		
94	87	82	79	78		
105	105	106	107			
130	132	133	135			
160	163	165	167			
	196	197	198			
	233	234	236			
	274	275	277			
310	313	318	327			
337	340	345	352	359		
357	360	365	371	377	382	
380	383	388	393	398	402	405
404	407	412	417	421	424	425
427	431	436	442	446	450	451
442	446	452	459	465	470	476

00061 423

ITER 6338

CUSTOMER	JOB No.
SUBJECT 91167 GRID TO SCALE	
CONTINUING SCALE 1/16" = 1"	BY
MINIMUM SCALE 1/16" = 1"	DATE 4-27

FLUID: 490
 No. 35

365	361	359
339	339	332
311	314	311

277	261	279	272	270			
272	271	264	259	254			
269	258	252	247	243			
258	252	249	242	238			
262	255	249	245	241			
	252	251	249	247			
	265	263	261	259			
	282	281	280	279			
	301	301	301				
	325	324	324				
	349	348	347				
	367	368	368	372			
	382	382	383	384	387		
	394	394	394	395	397	399	
	410	410	410	410	411	412	413
	431	431	430	430	430	430	431
	453	452	452	453	453	453	454
	466	466	466	466	467	469	473

0006120421

TEMP FOR ITER 6850

CUSTOMER	JOH No.
SUBJECT 9167 GRID TO	
CONDENSER SECTION 4 TUBES = 1"	BY
HEATER SECTION 11 TUBES = 1"	DATE 4-28

SELECTION OF CRITICAL SEGMENTS

The following pages contain a sample temperature input and stress output for iterations 27976, 6, 5060, 6307. The reader can discern from this sample that the stainless segments 5 and 8 and carbon segment 23 (Bi-Metal Weld) are representative of the highest stress area in the nozzle.

Pages 5-16 to 5-20 contain a stress intensity summary of thermal stress iterations runs. Iteration I on this summary was run of pressure only on the nozzle at a pressure of 1000 psi. This summary is for Segments 5, 8, 21, 23, 33. It can be seen that segment 33 has stresses less than or in the vicinity of those shown for the make-up nozzle. Therefore, this point is not re-analyzed for the high pressure injection nozzle.

A complete analysis will be performed on Segments 5, 8, 23 therefore justifying the acceptability of this nozzle under the design criteria. This will be discussed further later.

0006100425

STRESS ANALYSIS OF HIGH PRESSURE INJECTION NOZ REFURKE

ITERATION 27976

TEMPERATURES PER SEGMENT USED IN PRIMARY + SECONDARY ANALYSIS

OUTSIDE					INSIDE					OUTSIDE					INSIDE				
SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5		
1	492	492	492	492	492	17	472	472	472	472	472	18	470	470	471	471	472		
2	492	492	492	492	492	19	468	469	469	470	470	20	466	467	467	468	468		
3	492	492	492	492	492	21	467	467	467	467	467	21	467	467	467	467	467		
4	492	492	492	492	492	22	467	467	467	467	467	22	467	467	467	467	467		
5	490	490	490	491	491	23	467	467	467	467	467	23	467	467	467	467	467		
6	488	488	489	489	490	24	467	467	467	467	467	24	467	467	467	467	467		
7	485	486	487	488	489	25	467	467	467	467	467	25	467	467	467	467	467		
8	485	486	487	488	489	26	467	467	467	467	467	26	467	467	467	467	467		
9	479	480	481	482	483	27	468	468	468	468	468	27	468	468	468	468	468		
10	480	480	480	480	480	28	469	469	469	469	469	28	469	469	469	469	469		
11	480	480	480	480	480	29	470	470	470	470	470	29	470	470	470	470	470		
12	475	476	477	478	479	30	471	471	471	471	471	30	471	471	471	471	471		
13	473	474	475	476	477	31	476	476	475	475	475	31	476	476	475	475	475		
14	471	472	473	474	475	32	481	480	480	480	479	32	481	480	480	480	479		
15	472	472	472	472	472	33	485	485	484	484	483	33	485	485	484	484	483		
16	472	472	472	472	472														

STRESS ANALYSIS OF HIGH PRESSURE INJECTION NOZ REHNKE

ITERATION 27976

PRIMARY + SECONDARY STRESSES

SFG. NO.	OUTSIDE			MIDPLANE			INSIDE		
	LONG	HOOP	RAD.	LONG	HOOP	RAD.	LONG	HOOP	RAD.
1	.3	.1	-.0	-.0	-.0	-.0	-.3	-.1	-.0
2	-1.1	-1.1	-.0	.1	-.4	-.0	1.2	-.7	-.0
3	-4.9	4.2	.0	.5	8.2	.3	10.1	13.1	.0
4	118.9	28.7	-.2	-7.1	-7.4	-1.3	-134.9	-51.3	-.2
5	741.8	191.2	-4.1	-41.9	-195.3	-28.2	-833.4	-656.1	-4.1
	625.2	365.2	-10.8	-50.8	-117.8	-74.5	-711.0	-675.7	-10.8
	616.9	500.6	-14.4	-55.8	-118.1	-90.5	-705.0	-828.3	-14.4
8	559.7	273.3	-16.9	-58.0	-382.7	-117.1	-643.7	-1135.6	-16.9
9	-55.4	629.5	-15.6	-26.1	310.9	-105.3	54.1	-17.1	-15.6
10	73.7	129.6	-7.3	-23.7	60.7	-45.0	-98.6	-6.7	-7.3
11	122.3	10.7	-4.7	-15.9	-116.6	-30.3	-160.7	-316.6	-4.7
12	290.6	565.8	-17.2	-43.3	69.9	-111.0	-375.8	-608.9	-17.2
13	699.0	781.5	-25.8	-119.2	242.7	-161.4	-846.3	-430.6	-25.8
14	2248.5	1215.9	-32.2	-293.5	282.9	-196.2	-2848.5	-1021.5	-32.2
15	3072.7	1238.7	-38.8	-430.8	498.2	-236.3	-3864.2	-403.7	-38.8
17	6169.9	1597.3	-43.6	-472.5	494.7	-280.0	-5040.7	-823.4	-43.6
18	5170.5	1877.1	-57.9	-571.6	189.2	-376.2	-6262.2	-1963.5	-57.9
19	7563.5	556.9	-105.7	-835.5	-2626.8	-709.5	-9233.9	-7015.9	-105.7
20	6563.4	-4004.8	-192.3	-872.6	-8694.4	-1348.8	-8190.4	-15302.8	-192.3
21	1548.8	-9151.3	-247.4	-567.8	-13741.1	-1803.9	-2336.1	-20116.0	-247.4
23	3566.6	14126.9	100.6	-54.7	16799.1	811.3	-3862.1	20272.4	100.6
24	-8397.8	3083.2	117.7	779.0	7221.9	884.1	9719.8	12106.5	117.7
	-3317.8	-1831.8	62.3	361.3	-959.7	434.8	3776.6	-288.3	62.3
26	-743.5	-949.0	8.8	75.8	-895.3	53.5	898.2	-908.7	8.8
27	183.4	-246.7	-2.0	-23.3	-343.9	-18.5	-228.8	-469.8	-2.0
28	-153.6	-152.9	1.2	-9.7	-73.6	3.3	163.1	106.4	1.2
29	-229.5	-80.8	10.0	18.6	109.0	60.7	300.5	513.0	10.0
30	-152.6	36.0	22.3	47.6	315.6	137.9	280.2	934.8	22.3
31	28.7	34.5	13.4	21.8	143.8	87.7	-20.9	282.3	13.4
32	485.9	-7.6	3.2	-63.9	-64.8	22.3	-666.5	-259.8	3.2
33	802.4	-304.5	-19.8	-138.5	-645.6	-127.1	-1150.0	-1436.3	-19.8

15-2

STRESS ANALYSIS OF HIGH PRESSURE INJECTION NOZ HEAD

ITERATION 27976

TEMPERATURES PER SEGMENT USED IN PEAK PRINCIPLE ANALYSIS

OUTSIDE						INSIDE					
SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5
1	492	492	492	492	492	17	472	472	472	472	472
2	492	492	492	492	492	18	470	470	471	471	472
3	492	492	492	492	492	19	468	468	469	469	470
4	492	492	492	492	492	20	467	467	467	468	469
5	490	490	490	491	491	21	467	467	467	467	467
6	488	488	489	489	490	22	467	467	467	467	467
7	486	486	487	488	489	23	467	467	467	467	467
8	486	486	487	488	489	24	467	467	467	467	467
9	480	480	481	482	483	25	467	467	467	467	467
10	480	480	480	480	481	26	467	467	467	467	467
11	480	480	480	480	481	27	468	468	468	468	468
12	475	476	477	478	479	28	469	469	469	469	469
13	473	474	475	476	477	29	470	470	470	470	470
14	472	472	473	474	475	30	471	471	471	471	471
15	472	472	472	472	472	31	476	476	475	475	475
16	472	472	472	472	472	32	480	480	480	480	479
						33	485	485	484	484	483

5-3

5-3

STRESS ANALYSIS OF HIGH PRESSURE INJECTION NOZ BEHNKE

ITERATION 27976

PEAK PRINCIPAL STRESSES

SFG. NO.	OUTSIDE			MIDPLANE			INSIDE		
	LONG	HOOP	RAD.	LONG	HOOP	RAD.	LONG	HOOP	RAD.
1	.3	.1	-.0	-.0	-.0	-.0	-.3	-.1	-.0
2	-1.1	-1.1	-.0	.1	-.9	-.0	1.2	-.7	-.0
3	-8.9	4.2	.0	.5	6.2	.3	10.1	13.1	.0
4	119.0	28.7	-.2	-7.1	-7.3	-1.3	-134.9	-51.3	-.2
5	810.0	63.2	-3.7	-33.0	-186.4	-29.6	-1020.6	-724.7	-3.7
	465.1	203.7	-.5	-33.8	-100.9	-79.3	-752.1	-718.5	-9.5
	375.6	258.0	-12.3	-30.6	-92.1	-107.4	-765.0	-892.1	-12.3
8	467.2	-20.5	-14.3	-33.4	-358.7	-126.5	-829.1	-1233.1	-14.3
9	-298.4	386.3	-12.3	-2.0	334.8	-116.7	-3.4	-81.0	-12.3
10	21.9	76.7	-7.6	3.2	90.9	-40.4	-349.4	-236.3	-7.6
11	67.2	-45.1	-9.4	19.4	-74.1	-6.6	-411.9	-549.2	-9.4
12	281.5	560.9	-19.5	-37.1	72.3	-99.0	-366.3	-610.3	-19.5
13	580.3	660.5	-24.5	-106.5	255.9	-165.4	-929.0	-464.6	-24.5
14	2014.4	976.0	-28.4	-270.4	308.3	-208.7	-2916.9	-1088.2	-28.4
15	3068.3	1238.8	-36.2	-433.9	495.1	-244.3	-5151.2	-742.0	-36.2
17	4162.2	1585.3	-43.5	-471.5	495.2	-279.3	-5011.4	-820.0	-43.5
18	5037.7	1752.2	-57.7	-698.7	66.7	-377.6	-6381.3	-2079.2	-57.7
19	7415.2	408.3	-105.4	-808.3	-2597.2	-709.9	-9388.8	-7164.0	-105.4
20	6402.9	-4176.8	-192.4	-689.2	-8511.7	-1343.2	-8385.4	-15486.8	-192.4
21	1593.5	-9153.1	-247.6	-565.5	-13740.1	-1799.4	-2329.6	-20114.5	-247.6
23	3557.9	14124.0	100.7	-54.0	16798.6	811.8	-3852.2	20274.7	100.7
24	-9401.0	3080.5	117.8	779.3	7219.8	884.3	9723.5	12104.8	117.8
	-3336.8	-1432.1	62.3	361.2	-960.4	434.8	3775.5	-289.5	62.3
26	-898.4	-913.4	8.8	75.8	-895.4	53.5	897.7	-908.9	8.8
27	206.7	-255.2	-2.0	-23.3	-345.7	-18.4	-228.9	-469.5	-2.0
28	-153.2	-152.7	1.2	-9.7	-73.3	3.3	162.7	106.7	1.2
29	-228.9	-80.5	10.0	18.6	109.3	60.7	299.9	513.2	10.0
30	-151.8	36.3	22.3	47.5	315.8	137.9	279.3	934.6	22.3
31	60.7	65.7	13.2	54.1	174.9	89.1	9.5	309.3	13.2
32	549.2	54.5	2.7	1.5	-2.1	26.6	-604.7	-206.1	2.7
33	1148.0	-319.9	-20.6	-39.9	-550.9	-119.8	-1056.1	-1355.0	-20.6

TEMPERATURES PER SEGMENT USED IN PRIMARY + SECONDARY ANALYSIS
 ***** ITER 6

OUTSIDE					INSIDE					OUTSIDE					INSIDE				
SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5		
1	472	399	326	253	180	17	480	480	480	480	480	17	480	480	480	480	480		
2	472	399	326	253	180	18	480	480	480	480	480	18	480	480	480	480	480		
3	472	399	326	253	180	19	480	480	480	480	480	19	480	480	480	480	480		
4	472	399	326	253	180	20	480	480	480	480	480	20	480	480	480	480	480		
5	504	426	348	270	192	21	480	480	480	480	480	21	480	480	480	480	480		
6	504	426	348	270	192	22	480	480	480	480	480	22	480	480	480	480	480		
7	504	426	348	270	192	23	480	480	480	480	480	23	480	480	480	480	480		
8	504	426	348	270	192	24	480	480	480	480	480	24	480	480	480	480	480		
9	527	454	382	309	237	25	480	480	480	480	480	25	480	480	480	480	480		
10	549	482	415	348	281	26	480	480	480	480	480	26	480	480	480	480	480		
11	549	482	415	348	281	27	480	480	480	480	480	27	480	480	480	480	480		
12	527	487	446	406	365	28	480	480	480	480	480	28	480	480	480	480	480		
13	527	487	447	407	367	29	480	480	480	480	480	29	480	480	480	480	480		
14	526	487	448	408	369	30	480	480	480	480	480	30	480	480	480	480	480		
15	526	487	448	410	371	31	480	480	480	480	480	31	480	480	480	480	480		
16	480	480	480	480	480	32	480	480	480	480	480	32	480	480	480	480	480		
						33	480	480	480	480	480	33	480	480	480	480	480		

PRIMARY + SECONDARY STRESSES

ITER 6

FG. NO.	OUTSIDE			MIDPLANE			INSIDE		
	LONG	HOOP	RAD.	LONG	HOOP	RAD.	LONG	HOOP	RAD.
1	-49756.9	-49747.3	1105.1	4195.4	365.5	7609.1	55866.3	55881.4	1105.1
2	-49744.0	-49745.1	1105.1	4194.6	363.5	7608.9	55851.7	55874.5	1105.1
3	-49794.9	-49790.8	1105.0	4197.8	326.4	7608.3	55909.6	55847.6	1105.0
4	-50148.2	-49592.8	1106.9	4217.9	688.8	7622.0	56307.7	56413.1	1106.9
5	-50698.5	-57613.8	1143.7	4766.9	-2952.6	7863.2	67062.9	58116.0	1143.7
6	-52880.4	-54992.0	1322.8	5088.5	-2668.8	9028.9	60490.7	56520.9	1322.8
7	-62580.4	-56901.5	1394.7	5765.6	-1432.6	9526.8	71427.3	61353.0	1394.7
8	-60285.5	-57986.5	1466.6	6293.2	-248.5	10026.2	79003.4	65046.7	1466.6
9	-39747.3	-42979.9	1687.3	5752.1	3125.2	11392.4	48477.6	59394.2	1687.3
10	-27896.5	-35766.0	2014.4	6081.3	3649.0	13220.0	36850.2	54778.9	2014.4
11	-29596.2	-34858.2	2166.1	6607.5	5629.2	14007.5	39221.6	57834.2	2166.1
12	-27636.1	-26944.1	1807.0	6651.6	-122.5	11664.8	36297.2	30947.4	1807.0
13	-23617.6	-23629.1	1386.1	4846.0	1798.5	8922.6	30946.7	34223.0	1386.1
14	-13782.4	-19366.8	1356.8	3769.7	3647.4	8809.3	18524.5	32303.3	1356.8
15	-7909.5	-16795.2	1229.1	2839.9	4435.0	8010.7	11155.9	31116.8	1229.1
17	-10084.4	-6895.7	52.0	1074.4	-5514.4	266.9	12082.2	-4216.6	52.0
18	-4029.8	-5647.4	1.4	459.7	-6233.9	-68.8	4747.5	-7633.2	1.4
19	6200.4	-3416.3	-110.5	-672.1	-7318.9	-811.4	-7684.6	-13089.5	-110.5
20	7597.6	-5509.4	-225.8	-1032.9	-10963.1	-1610.3	-9495.8	-18627.7	-225.8
21	2586.7	-9810.7	-281.0	-721.6	-15110.3	-2049.3	-3568.9	-22409.9	-281.0
23	5272.0	14127.9	80.1	-203.4	16142.3	666.6	-5822.8	18849.4	80.1
24	-7331.9	3523.0	103.7	676.6	7360.2	787.0	8499.8	11946.1	103.7
25	-3356.7	-1646.6	59.9	359.1	-722.4	420.4	3810.3	40.9	59.9
26	-685.3	-845.0	9.1	70.1	-801.5	56.6	775.8	-828.4	9.1
27	391.9	-94.7	-3.5	-27.4	-258.1	-27.2	-451.5	-485.2	-3.5
28	139.1	-2.0	-3.5	-24.6	-51.2	-24.9	-166.9	-101.3	-3.5
29	54.2	13.6	-1.6	-14.3	-2.5	-10.8	-74.7	-9.9	-1.6
30	23.3	13.6	-.6	-6.8	7.3	-3.2	-32.3	11.1	-.6
31	10.8	13.5	-.3	-1.8	10.0	-.6	-11.8	14.8	-.3
32	2.7	8.9	-.1	.4	6.7	.8	-.7	10.3	-.1
33	.5	7.0	-.1	.9	4.5	1.0	2.1	6.6	-.1

(LONGITUDINAL DIRECTION IS ALONG SHELL MIDSURFACE. RADIAL DIRECTION IS NORMAL TO SHELL MIDSURFACE.)

TEMPERATURES PER SEGMENT UNIT FOR PRINCIPLE ANALYSIS

OUTSIDE						INSIDE					
SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5
1	422	405	353	260	127	17	480	480	480	480	480
2	422	405	353	260	127	18	480	480	480	480	480
3	422	405	353	260	127	19	480	480	480	480	480
4	422	405	353	260	127	20	480	480	480	480	480
5	447	432	380	280	127	21	480	480	480	480	480
6	447	432	380	280	127	22	480	480	480	480	480
7	447	432	380	280	127	23	480	480	480	480	480
8	447	432	380	280	127	24	480	480	480	480	480
9	463	454	421	332	127	25	480	480	480	480	480
10	479	477	462	385	127	26	480	480	480	480	480
11	479	477	462	385	127	27	480	480	480	480	480
12	480	480	480	440	235	28	480	480	480	480	480
13	480	480	480	442	237	29	480	480	480	480	480
14	480	480	480	443	238	30	480	480	480	480	480
15	480	480	480	445	240	31	480	480	480	480	480
16	480	480	480	480	480	32	480	480	480	480	480
						33	480	480	480	480	480

SEG. NO.	OUTSIDE			MIDPLANE			INSIDE		
	LONG	HOOP	RAD.	LONG	HOOP	RAD.	LONG	HOOP	RAD.
1	-31531.0	-31516.3	1115.3	-5549.7	-9323.5	7388.8	74996.8	75020.7	1115.3
2	-31517.6	-31513.7	1115.3	-5550.5	-9325.0	7388.6	74981.6	75014.1	1115.3
3	-31563.9	-31561.6	1115.2	-5547.5	-9366.3	7387.8	75034.5	74980.5	1115.2
4	-31978.7	-31378.0	1117.2	-5523.8	-8999.6	7402.2	75502.3	75573.1	1117.2
5	-50961.3	-32896.2	1167.5	-6700.2	-13910.1	7588.2	104192.5	85987.6	1167.5
6	-32204.5	-33793.1	1368.1	-6422.1	-13476.2	8620.6	84198.5	80912.9	1368.1
7	-41056.7	-35254.2	1436.8	-5797.5	-12009.1	9098.1	94192.5	85767.7	1436.8
8	-65828.7	-29758.9	1503.5	-5324.4	-10692.6	9563.4	116512.6	93594.1	1503.5
	-16469.7	-19767.5	1871.9	-8730.6	-10722.4	10100.0	87873.7	99071.9	1871.9
10	-4414.6	-11562.8	2593.8	-11598.5	-16031.0	9739.4	94786.3	109508.6	2593.8
11	-5496.6	-10340.7	2982.7	-11716.2	-12429.4	9165.1	96443.8	112611.9	2982.7
12	-0758.1	-0685.9	2601.0	-7000.7	-13615.7	6969.9	82689.2	76969.9	2601.0
13	-6431.4	-6633.6	2171.1	-8410.0	-10670.8	4429.8	77968.6	80662.6	2171.1
14	1698.6	-3022.5	2159.2	-9057.7	-8587.8	4359.0	67644.5	79498.9	2159.2
15	6587.7	-044.4	2058.5	-9592.1	-7630.7	3668.5	65144.2	79477.4	2058.5
17	-7596.0	-5550.8	31.9	798.4	-4672.0	146.0	9087.2	-3916.7	31.9
18	-2350.3	-4467.9	-11.5	266.7	-5280.6	-142.0	2732.9	-6856.8	-11.5
19	6572.7	-2759.2	-110.9	-717.1	-6556.3	-803.1	-8118.0	-12104.0	-110.9
20	7520.5	-5278.9	-220.3	-1016.4	-10601.2	-1567.8	-9392.8	-18083.7	-220.3
21	2481.9	-9710.3	-276.1	-702.0	-14919.7	-2013.6	-3436.4	-22105.8	-276.1
23	5088.5	14201.0	83.1	-186.0	16307.1	688.0	-5610.6	19123.0	83.1
24	-7503.0	3487.5	106.0	692.9	7382.5	803.2	8696.3	12030.1	106.0
25	-3365.9	-1672.4	60.5	360.8	-750.4	424.5	3819.2	4.9	60.5
26	-769.4	-821.3	9.0	69.5	-813.0	56.0	767.8	-845.8	9.0
27	448.6	-112.8	-3.6	-28.0	-260.4	-27.8	-457.6	-489.6	-3.6
28	131.7	-1.7	-3.6	-25.0	-51.3	-25.2	-169.0	-101.7	-3.6
29	54.8	13.8	-1.7	-14.5	-2.4	-10.9	-75.5	-9.6	-1.7
30	23.5	13.7	-.6	-6.8	7.5	-3.2	-32.6	11.3	-.6
31	10.9	13.6	-.3	-1.8	10.1	-.6	-11.9	15.0	-.3
32	2.6	9.0	-.1	.4	6.7	.8	-.7	10.4	-.1
33	1.0	7.1	-.1	.9	4.5	1.0	2.2	6.6	-.1

(LONGITUDINAL DIRECTION IS ALONG SHELL MIDSURFACE. RADIAL DIRECTION IS NORMAL TO SHELL MIDSURFACE.)

TEMPERATURES PER SEGMENT USED IN PRIMARY + SECONDARY ANALYSIS

OUTSIDE					INSIDE					OUTSIDE					INSIDE				
SEGMNT	T1	T2	T3	T4	T5	SEGMNT	T1	T2	T3	T4	T5	SEGMNT	T1	T2	T3	T4	T5		
1	558	475	391	308	224	17	480	480	480	480	480	17	480	480	480	480	480		
2	558	475	391	308	224	18	480	480	480	480	480	18	480	480	480	480	480		
3	558	475	391	308	224	19	480	480	480	480	480	19	480	480	480	480	480		
4	558	475	391	308	224	20	480	480	480	480	480	20	480	480	480	480	480		
5	560	482	404	326	247	21	480	480	480	480	480	21	480	480	480	480	480		
6	560	482	404	326	247	22	480	480	480	480	480	22	480	480	480	480	480		
7	560	482	404	326	247	23	480	480	480	480	480	23	480	480	480	480	480		
8	560	482	404	326	247	24	480	480	480	480	480	24	480	480	480	480	480		
9	554	487	421	354	283	25	480	480	480	480	480	25	480	480	480	480	480		
10	547	492	437	383	328	26	480	480	480	480	480	26	480	480	480	480	480		
11	547	492	437	383	328	27	480	480	480	480	480	27	480	480	480	480	480		
12	498	485	471	457	443	28	480	480	480	480	480	28	480	480	480	480	480		
13	498	485	471	457	444	29	480	480	480	480	480	29	480	480	480	480	480		
14	498	484	471	458	444	30	480	480	480	480	480	30	480	480	480	480	480		
15	497	484	471	458	445	31	480	480	480	480	480	31	480	480	480	480	480		
16	480	480	480	480	480	32	480	480	480	480	480	32	480	480	480	480	480		
						33	480	480	480	480	480	33	480	480	480	480	480		

PRIMARY + SECONDARY STRESSES

SEG. NO.	OUTSIDE			MIDPLANE			INSIDE		
	LONG	HOOP	RAD.	LONG	HOOP	RAD.	LONG	HOOP	RAD.
1	-56571.9	-56563.4	1256.5	4770.1	415.0	8651.7	63518.0	63536.9	1256.5
2	-56572.3	-56572.2	1256.5	4770.2	404.6	8651.4	63518.6	63524.5	1256.5
3	-56700.0	-56566.2	1256.9	4777.7	456.8	8654.1	63663.0	63633.3	1256.9
4	-55798.1	-56129.0	1256.3	4722.8	665.0	8651.6	62638.3	63564.6	1256.3
5	-60614.9	-57521.0	1219.8	5058.8	-2350.8	8388.6	68193.0	58692.1	1219.8
	-51951.5	-54244.5	1323.0	5043.4	-2163.6	9034.2	59439.5	56677.2	1323.0
	-59818.5	-55870.2	1381.0	5592.9	-1269.8	9435.6	68316.7	60481.5	1381.0
8	-65323.1	-56880.6	1438.8	6023.6	-448.0	9836.2	74534.6	63327.5	1438.8
9	-35787.6	-38514.3	1595.1	5384.1	3745.0	10777.3	43760.2	55049.4	1595.1
10	-23077.5	-27950.0	1773.0	5343.9	5172.4	11667.2	30683.2	47809.5	1773.0
11	-22830.3	-26971.6	1818.7	5359.4	6419.9	11805.4	30431.8	49393.6	1818.7
12	-13865.9	-12966.9	1160.0	4522.3	-2689.1	7492.1	18381.0	5154.8	1160.0
13	-7378.9	-8930.3	449.0	1550.4	-1074.5	2851.0	9595.8	8639.1	449.0
14	-2749.4	-6064.7	434.6	1007.4	1123.7	2818.1	3843.1	10008.7	434.6
15	-430.2	-4949.9	387.8	653.9	1619.1	2534.1	945.4	9838.9	387.8
17	-369.1	-989.8	-10.6	24.3	-1245.3	-86.3	416.5	-1658.1	-10.6
18	2236.0	-627.4	-33.7	-238.2	-1791.4	-241.2	-2744.8	-3478.5	-33.7
19	7186.0	-838.8	-100.0	-777.1	-4107.2	-693.9	-8801.8	-8768.6	-100.0
20	7013.9	-4723.0	-198.6	-926.5	-9582.6	-1404.2	-8750.3	-16464.8	-198.6
21	1989.5	-9533.2	-259.7	-621.6	-14445.4	-1895.9	-2824.1	-21273.6	-259.7
23	4250.4	14269.0	93.8	-111.8	16719.1	764.4	-4645.9	19935.0	93.8
24	-8084.2	3284.5	113.6	748.4	7353.6	856.5	9362.0	12178.4	113.6
	-3349.0	-1751.0	62.1	362.2	-853.2	434.5	3793.5	-143.5	62.1
26	-639.0	-866.9	8.6	66.2	-847.2	52.6	722.3	-903.4	8.6
27	411.5	-95.1	-3.9	-30.2	-265.5	-30.1	-475.4	-499.6	-3.9
28	136.0	-.4	-3.7	-26.1	-51.0	-26.1	-174.9	-101.8	-3.7
29	56.2	14.7	-1.7	-14.9	-1.7	-11.1	-77.6	-8.6	-1.7
30	23.9	14.1	-.6	-7.0	8.0	-3.2	-33.3	12.2	-.6
31	10.9	13.8	-.3	-1.8	10.4	-.6	-11.9	15.5	-.3
32	3.5	9.0	-.1	.4	6.8	.9	-.6	10.6	-.1
33	.3	6.9	-.0	1.0	4.5	1.0	2.3	6.7	-.0

STRESS VALUES ARE IN TENSILE UNITS. RADIAL DIRECTION IS NORMAL TO S-ELL MID-SURFACE.

TEMPERATURES PER SEGMENT USED IN PEAK PRINCIPLE ANALYSIS

OUTSIDE						INSIDE					OUTSIDE						INSIDE						
SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5
1	478	473	445	340	76	17	480	480	480	480	480	17	480	480	480	480	480	18	480	480	480	480	480
2	478	473	445	340	76	18	480	480	480	480	480	19	480	480	480	480	480	20	480	480	480	480	480
3	478	473	445	340	76	19	480	480	480	480	480	21	480	480	480	480	480	21	480	480	480	480	480
4	478	473	445	340	76	20	480	480	480	480	480	22	480	480	480	480	480	22	480	480	480	480	480
5	479	477	458	367	74	21	480	480	480	480	480	23	480	480	480	480	480	23	480	480	480	480	480
6	479	477	458	367	74	22	480	480	480	480	480	24	480	480	480	480	480	24	480	480	480	480	480
7	479	477	458	367	74	23	480	480	480	480	480	25	480	480	480	480	480	25	480	480	480	480	480
8	479	477	458	367	74	24	480	480	480	480	480	26	480	480	480	480	480	26	480	480	480	480	480
9	479	478	468	408	86	25	480	480	480	480	480	27	480	480	480	480	480	27	480	480	480	480	480
10	479	479	478	450	98	26	480	480	480	480	480	28	480	480	480	480	480	28	480	480	480	480	480
11	479	479	478	450	98	27	480	480	480	480	480	29	480	480	480	480	480	29	480	480	480	480	480
12	480	480	480	480	370	28	480	480	480	480	480	30	480	480	480	480	480	30	480	480	480	480	480
13	480	480	480	480	372	29	480	480	480	480	480	31	480	480	480	480	480	31	480	480	480	480	480
14	480	480	480	480	373	30	480	480	480	480	480	32	480	480	480	480	480	32	480	480	480	480	480
15	480	480	480	480	375	31	480	480	480	480	480	33	480	480	480	480	480	33	480	480	480	480	480
16	480	480	480	480	480																		

PEAK PRINCIPAL STRESSFS

SEG. NO.	OUTSIDE			MIDPLANE			INSIDE		
	LONG	HOOP	RAD.	LONG	HOOP	RAD.	LONG	HOOP	RAD.
1	-27543.0	-27531.5	1554.3	-15022.3	-18992.1	7070.8	116998.3	117022.5	1554.3
2	-27540.7	-27539.2	1554.3	-15022.4	-19002.2	7070.5	116995.8	117009.4	1554.3
3	-27670.4	-27543.5	1554.6	-15014.7	-18961.6	7072.8	117142.7	117104.9	1554.6
4	-26906.9	-27093.9	1554.5	-15061.5	-18689.8	7073.5	116274.4	117162.6	1554.5
5	-43079.7	-23849.0	1572.6	-14925.9	-21386.5	6593.0	144089.4	125578.1	1572.6
6	-22647.9	-24317.9	1801.7	-15130.5	-21049.4	6654.2	122157.7	120199.8	1801.7
7	-29215.0	-25329.8	1853.6	-14664.7	-19864.6	7015.7	129573.0	123913.3	1853.6
8	-51361.5	-20006.5	1903.2	-14314.2	-18900.2	7361.7	149265.6	130543.4	1903.2
9	-8671.6	-11506.1	2300.6	-12467.8	-13271.0	7077.4	116882.6	127442.8	2300.6
10	-539.3	-4678.0	3021.6	-10500.4	-10790.6	5249.1	117164.4	128921.4	3021.6
11	93.7	-3446.9	3365.0	-11173.5	-10063.2	3885.7	116628.8	130656.9	3365.0
12	-5298.3	-5127.8	2185.7	-819.6	-6634.8	2194.1	43320.9	32004.4	2185.7
13	-528.6	-1967.7	964.8	-2403.5	-4147.0	286.3	35753.9	35082.0	964.8
14	3105.1	286.6	948.9	-2769.0	-2264.2	325.6	30707.9	35818.6	948.9
15	4972.5	1120.8	901.2	-3007.5	-1824.8	122.8	28163.4	35265.3	901.2
17	755.3	-309.2	-17.8	-97.4	-754.8	-127.5	-933.8	-1365.6	-17.8
18	2962.0	-47.5	-37.8	-319.1	-1274.1	-261.5	-3613.0	-3000.6	-37.8
19	7301.3	-540.5	-98.8	-789.5	-3736.0	-680.5	-8932.7	-8269.7	-98.8
20	6947.1	-4631.7	-195.5	-914.3	-9422.8	-1380.4	-8664.9	-16214.6	-195.5
21	1919.7	-9500.8	-257.3	-610.0	-14369.3	-1878.2	-2738.5	-21142.0	-257.3
23	4133.0	14285.7	95.4	-101.2	16784.9	775.7	-4510.6	20060.6	95.4
24	-8171.0	3257.1	114.8	756.7	7353.1	864.5	9461.6	12205.6	114.8
25	-3348.2	-1763.1	62.3	362.5	-868.3	436.2	3791.7	-164.8	62.3
26	-718.6	-840.9	8.5	65.8	-852.5	52.1	716.1	-912.1	8.5
27	467.9	-113.8	-3.9	-30.6	-266.4	-30.5	-478.1	-501.3	-3.9
28	136.7	-.2	-3.7	-26.3	-51.0	-26.2	-175.8	-101.9	-3.7
29	56.4	14.8	-1.7	-15.0	-1.6	-11.2	-77.4	-8.4	-1.7
30	24.0	14.2	-.6	-7.0	8.1	-3.2	-33.4	12.3	-.6
31	11.0	13.8	-.3	-1.8	10.4	-.6	-11.9	15.6	-.3
32	2.5	9.0	-.1	.4	6.8	.9	-.5	10.6	-.1
33	.8	7.0	-.0	1.0	4.5	1.0	2.4	6.7	-.0

(LONGITUDINAL DIRECTION IS ALONG SHELL MIDSURFACE. RADIAL DIRECTION IS NORMAL TO SHELL MIDSURFACE.)

TEMPERATURES PER SEGMENT USED IN PRIMARY + SECONDARY ANALYSIS

OSC 1522

21-5

OUTSIDE						INSIDE					OUTSIDE						INSIDE						
SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5
1	0	0	0	0	0	17	69	68	66	65	64	17	69	68	66	65	64	18	69	68	66	65	64
2	0	0	0	0	0	18	69	68	66	65	64	19	99	97	96	94	92	20	129	127	125	123	120
3	0	0	0	0	0	19	99	97	96	94	92	21	139	139	138	137	136	21	139	139	138	137	136
4	0	0	0	0	0	20	129	127	125	123	120	22	139	139	138	137	136	22	139	139	138	137	136
5	0	0	0	0	0	21	139	139	138	137	136	23	139	139	138	137	136	23	139	139	138	137	136
6	0	0	0	0	0	22	139	139	138	137	136	24	159	158	157	156	155	24	159	158	157	156	155
7	0	0	0	0	0	23	139	139	138	137	136	25	200	197	195	192	190	25	200	197	195	192	190
8	0	0	0	0	0	24	159	158	157	156	155	26	230	227	224	221	218	26	230	227	224	221	218
9	1	1	1	0	-0	25	200	197	195	192	190	27	260	257	254	250	247	27	260	257	254	250	247
10	3	2	1	0	-1	26	230	227	224	221	218	28	290	285	281	277	272	28	290	285	281	277	272
11	3	2	1	0	-1	27	260	257	254	250	247	29	319	314	308	303	293	29	319	314	308	303	293
12	16	13	10	7	4	28	290	285	281	277	272	30	348	342	336	330	323	30	348	342	336	330	323
13	29	24	19	13	8	29	319	314	308	303	293	31	377	370	363	356	349	31	377	370	363	356	349
14	42	35	27	20	12	30	348	342	336	330	323	32	407	399	391	383	374	32	407	399	391	383	374
15	69	68	66	65	64	31	377	370	363	356	349	33	436	427	418	409	400	33	436	427	418	409	400
16	69	68	66	65	64	32	407	399	391	383	374												
						33	436	427	418	409	400												

0 0 0 6 1 9 0 4 3 9

PRIMARY + SECONDARY STRESSES

5-13

SFG. NO.	OUTSIDE			MIDPLANE			INSIDE		
	LONG	HOOP	RAD.	LONG	HOOP	RAD.	LONG	HOOP	RAD.
1	.0	.0	.0	-.0	.0	.0	-.0	.0	.0
2	.2	-.1	-.0	-.0	-.2	-.0	-.2	-.4	-.0
3	-3.3	-.7	.0	.2	.4	.0	3.8	1.6	.0
4	11.4	11.8	.0	-.7	16.2	.2	-13.0	8.3	.0
5	102.4	-45.0	-.5	-5.9	-90.2	-3.5	-115.5	-145.9	-.5
6	-6.4	-135.3	-1.1	-1.5	-166.9	-8.1	5.4	-205.9	-1.1
7	-183.9	-248.9	-.7	9.0	-243.6	-5.8	204.5	-239.8	-.7
8	-376.8	-341.4	.4	21.6	-288.4	1.0	419.2	-230.2	.4
9	-849.0	-669.1	6.5	67.2	-308.8	40.4	994.4	155.9	6.5
10	-1272.2	-775.4	24.9	153.1	-31.2	157.6	1599.4	1048.4	24.9
11	-1668.9	-732.2	44.0	251.9	212.3	282.8	2134.1	1506.3	44.0
12	-3323.5	-2404.5	81.6	455.2	-151.7	520.5	4234.4	2980.3	81.6
13	-5822.0	-3371.7	172.9	843.6	935.5	1111.6	7481.4	7027.0	172.9
14	-5632.3	-1880.4	312.3	1016.1	4625.1	2061.4	7439.1	13877.5	312.3
15	-3848.8	-3758.9	200.0	1075.6	-2766.8	1308.0	4879.8	-3292.4	200.0
17	-4455.4	-3552.8	39.6	487.2	-2449.5	223.6	5356.4	-1223.1	39.6
18	-2533.0	-1385.2	48.2	305.8	-194.5	301.4	3090.3	1321.3	48.2
19	1279.0	-1836.3	23.8	-36.1	-1962.0	147.3	-1559.6	-2535.6	23.8
20	2986.1	-3546.1	-38.8	-311.8	-4768.8	-299.0	-3699.4	-6811.5	-38.8
21	1485.2	-4658.9	-93.7	-275.3	-6747.5	-703.7	-1961.9	-9809.9	-93.7
23	2870.7	3934.4	15.0	-165.4	4287.7	133.8	-3223.0	4807.2	15.0
24	-1979.1	898.9	32.2	174.4	2397.7	242.3	2306.2	4244.4	32.2
25	-3265.7	-1383.8	47.6	280.9	581.0	328.9	3766.7	2905.8	47.6
26	-3019.4	-2939.8	48.5	279.4	-1277.4	325.0	3466.9	565.5	48.5
27	-2289.7	-2773.8	92.2	184.2	-154.0	603.7	2695.4	3613.2	92.2
28	-2145.0	-2633.2	163.6	338.0	684.5	1048.5	2881.4	5973.4	163.6
29	-1502.4	-2753.7	239.1	476.2	834.3	1487.7	2439.1	6867.2	239.1
30	-912.2	-3242.6	283.6	520.6	191.3	1693.8	1838.4	6063.5	283.6
31	-467.7	-1867.4	205.7	294.9	884.5	1237.4	909.2	5205.6	205.7
32	1123.3	-2133.8	219.8	144.3	259.2	1333.0	-1313.0	3284.4	219.8
33	2604.2	-4118.0	105.7	-155.8	-3345.3	584.1	-3643.2	-4040.5	105.7

(LONGITUDINAL DIRECTION IS ALONG SHELL MIDSURFACE. RADIAL DIRECTION IS NORMAL TO SHELL MIDSURFACE.)

5-1

0 0 0 6 1 9 0 4 4 0

TEMPERATURES PER SEGMENT USED IN PFAK PRINCIPLE ANALYSIS

OSC 1522

7/10

OUTSIDE					INSIDE					OUTSIDE					INSIDE				
SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5	SEGMENT	T1	T2	T3	T4	T5		
1	0	0	0	0	0	17	68	68	66	65	65	18	68	68	66	65	65		
2	0	0	0	0	0	19	99	98	95	94	93	20	130	127	125	123	120		
3	0	0	0	0	0	21	145	137	136	138	137	21	145	137	136	138	137		
4	0	0	0	0	0	22	145	137	136	138	137	22	145	137	136	138	137		
5	0	0	0	0	0	23	145	137	136	138	137	23	145	137	136	138	137		
6	0	0	0	0	0	24	160	158	157	156	155	24	160	158	157	156	155		
7	0	0	0	0	0	25	200	197	195	192	190	25	200	197	195	192	190		
8	0	0	0	0	0	26	230	227	225	221	218	26	230	227	225	221	218		
9	2	1	1	0	0	27	260	257	255	250	247	27	260	257	255	250	247		
10	3	2	1	0	0	28	289	285	282	276	272	28	289	285	282	276	272		
11	3	2	1	0	0	29	319	314	309	303	298	29	319	314	309	303	298		
12	15	13	11	7	3	30	348	342	336	329	323	30	348	342	336	329	323		
13	28	24	20	13	7	31	377	370	364	356	349	31	377	370	364	356	349		
14	40	35	30	20	10	32	407	399	391	382	374	32	407	399	391	382	374		
15	68	68	66	65	65	33	436	427	418	409	400	33	436	427	418	409	400		
16	68	68	66	65	65														

5-14

0 0 0 6 1 9 0 0 4 4 1

PEAK PRINCIPAL STRESSES

SEG. NO.	OUTSIDE			MIDPLANE			INSIDE		
	LONG	HOOP	RAD.	LONG	HOOP	RAD.	LONG	HOOP	RAD.
1	.0	.0	.0	-.0	.0	.0	-.0	.0	.0
2	.2	-.1	-.0	-.0	-.2	-.0	-.2	-.4	-.0
3	-3.4	-.7	.0	.2	.4	.0	3.8	1.7	.0
4	11.6	11.9	.0	-.7	10.3	.2	-13.2	8.3	.0
5	123.4	-52.4	-.5	-5.9	-91.4	-3.6	-139.1	-154.0	-.5
6	-7.6	-137.2	-1.1	-1.4	-168.8	-8.2	6.7	-207.9	-1.1
7	-187.6	-251.9	-.7	9.2	-246.0	-5.8	208.7	-241.5	-.7
8	-483.5	-311.9	.4	22.0	-290.8	1.1	508.6	-208.6	.4
9	-879.4	-697.3	5.7	82.3	-292.1	44.7	873.0	40.5	5.7
10	-1316.8	-825.6	21.6	184.2	6.6	173.7	1336.2	817.1	21.6
11	-1709.6	-781.7	39.2	285.5	253.1	306.0	1864.6	1272.5	39.2
12	-3070.8	-2154.7	77.8	173.0	-437.6	528.1	4366.2	3109.9	77.8
13	-5276.4	-2821.5	170.9	238.2	318.3	1087.5	8016.0	7524.3	170.9
14	-4842.5	-1027.0	312.7	92.8	3700.3	2009.2	8439.9	14803.6	312.7
15	-3549.2	-3489.5	193.2	1220.9	-2613.2	1309.8	6149.8	-3155.8	193.2
17	-4155.9	-3287.6	26.4	656.5	-2278.4	275.8	4988.6	-1531.0	26.4
18	-2247.1	-1117.9	35.2	476.5	-14.9	355.0	2739.0	1031.1	35.2
19	1313.3	-1793.6	16.4	54.9	-1857.2	181.2	-1624.8	-2574.8	16.4
20	2790.7	-3722.4	-35.5	-312.1	-4751.1	-307.6	-3500.3	-6608.7	-35.5
21	-486.9	-6692.4	-69.4	358.5	-6092.9	-785.1	-2277.2	-10102.0	-69.4
23	1393.2	2425.8	36.1	297.1	4750.0	59.5	-3417.2	4604.3	36.1
24	-2151.2	728.3	43.9	177.7	2406.5	201.2	2262.7	4208.2	43.9
25	-3360.4	-1475.6	48.7	184.0	487.5	324.4	3672.8	2816.4	48.7
26	-3402.1	-2784.6	48.1	56.7	-1495.5	324.1	3410.5	518.1	48.1
27	-2469.7	-2544.1	90.4	-164.7	-500.3	602.3	2690.3	3611.6	90.4
28	-2046.8	-2530.9	161.1	45.7	392.6	1043.1	2879.2	5972.6	161.1
29	-1424.7	-2672.6	236.8	240.6	598.7	1478.8	2440.2	6870.1	236.8
30	-854.6	-3182.2	281.8	342.4	13.9	1683.4	1841.4	6069.9	281.8
31	-426.8	-1825.6	204.4	174.4	766.2	1227.7	908.0	5212.2	204.4
32	1145.9	-2111.3	219.0	83.1	201.4	1327.3	-1316.6	3290.2	219.0
33	3438.5	-4462.2	105.4	-157.6	-3344.1	582.2	-3651.4	-4039.7	105.4

(LONGITUDINAL DIRECTION IS ALONG SHELL MIDSURFACE. RADIAL DIRECTION IS NORMAL TO SHELL MIDSURFACE.)

5-15

5-1

ITER	PRIMARY + SECONDARY STRESS INTENSITIES						PEAK STRESS INTENSITIES					
	L - P		R - H		H - L (S)		L - R		R - H		H - L	
	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
3	58.1	-53.6	-50.2	50.9	-7.9	2.7	104.1	-42.6	-88.1	25.8	-16.0	16.8
6	65.0	-60.8	-57.0	58.8	-8.0	2.1	103.0	-52.1	-84.8	34.0	-18.2	18.7
8	64.1	-50.2	-55.2	57.8	-8.0	1.4	97.5	-51.9	-79.6	34.8	-18.0	17.8
15	49.7	-45.8	-40.0	44.1	-0.7	1.7	72.7	-50.7	-56.0	37.1	-16.7	13.8
20	1.4	-1.1	1.1	-0.5	-2.4	1.7	1.1	-1.5	1.6	-0.4	-2.6	1.8
1211	.1	-0.1	-0.2	-0.1	.1	.2	.2	-0.1	-0.3	-0.1	.1	.1
291	-0.0	.0	.0	-0.0	.0	-0.0	-0.0	.0	.0	.0	.0	-0.1
1	1.7	1.4	-4.0	-2.3	2.3	.0	1.8	1.6	-4.0	-2.3	2.2	.1
27976	-0.8	.7	.7	-0.2	.2	-0.5	-1.0	.8	.7	.0	.3	-0.1
42021	.0	.0	.0	.0	.0	.0	-0.1	.1	.1	.0	.0	-0.1

STRESS OUTPUT ANALYSIS

5072	60.1	-55.4	-50.2	56.3	-9.9	-0.8	87.9	-49.1	-69.5	35.3	-18.3	13.8
5060	67.0	-61.8	-57.5	58.7	-9.5	3.1	142.5	-44.7	-124.0	25.4	-18.5	19.8
5063	83.9	-77.5	-72.4	74.4	-11.5	3.1	129.2	-67.0	-105.9	43.5	-23.3	23.8
5124	11.6	-10.6	-4.9	10.1	-6.7	.5	13.7	-12.2	-5.3	8.8	-8.4	3.8
5237	2.2	-1.9	.3	1.9	-2.5	.0	2.8	-2.4	.0	1.8	-2.8	.1
6059	-0.1	.1	.2	.0	-0.0	-0.2	-0.2	.1	.2	.1	-0.0	-0.1
6307	-0.1	.1	.1	.0	-0.0	-0.1	-0.1	.1	.2	.1	-0.0	-0.1
338	-5.7	5.3	4.5	-4.8	1.2	-0.4	-7.2	6.3	5.1	-4.4	2.0	-1.8
0850	-6.7	6.2	6.8	-4.0	-0.1	-2.2	-8.4	6.3	7.5	-2.4	.9	-3.8
1	1.7	1.4	-4.0	-2.3	2.3	1.0	1.8	1.6	-4.0	-2.3	2.2	.1

STRESS OUTPUT ANALYSIS

ITER.	PRIMARY + SECONDARY STRESS INTENSITIES							PEAK STRESS INTENSITIES				
	L - R		R - H		H - I		(8)	L - R		R - H		H - L
	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
3	63.7	-59.2	-54.7	50.2	-0.0	7.9	109.0	-50.7	-92.9	22.5	-16.0	28
6	77.5	-70.8	-63.6	54.5	-14.0	11.3	115.0	-67.3	-92.1	31.3	-22.9	36
8	78.8	-71.9	-62.9	59.2	-16.0	12.6	113.3	-70.6	-88.0	32.7	-25.3	37
15	69.3	-63.0	-47.3	48.2	-22.0	14.9	95.0	-75.0	-64.2	38.0	-30.9	37
30	7.7	-6.9	-1.2	1.1	-6.5	5.8	8.7	-9.4	-1.0	1.2	-7.7	8
1211	-.4	.3	.1	-.1	.3	-.2	-.4	.4	.1	-.1	.4	-
1491	.0	-.0	.0	.0	-.0	-.0	.0	-.0	1.0	.0	-.0	-
1	2.2	.6	-3.5	-1.6	1.3	1.0	2.5	.9	-3.5	-1.6	1.0	-
42021	.0	.0	.0	.0	.0	.0	.0	.0	.0	.0	.0	-
2979	-.7	-.6	1.1	-.3	-.5	-.3	-.8	.5	1.2	.0	-.4	-

STRESS OUTPUT ANALYSIS

5072	86.0	-78.3	-62.4	60.0	-23.6	18.3	117.3	-80.5	-83.1	34.7	-34.2	45
5060	73.1	-66.8	-61.9	58.3	-11.2	8.4	147.4	-53.3	-128.6	21.9	-18.7	31
5063	97.9	-89.3	-81.4	74.5	-16.4	14.8	143.3	-85.3	-115.7	39.3	-27.6	46
5124	33.0	-29.7	-13.1	15.1	-19.8	14.7	39.9	-36.7	-15.8	11.4	-24.1	25
5237	11.5	-10.4	-7.8	5.5	-7.7	4.9	14.2	-13.4	-5.1	4.8	-9.2	8
6059	.4	-.4	.3	.4	-.7	-.0	.5	-.5	.3	.3	-.8	-

6307	.4	-.4	.2	.3	-.6	.0	.5	-.5	.2	.3	-.7	.2
6338	-7.7	7.0	5.6	-5.1	2.1	-1.9	-9.6	8.7	6.6	-4.3	3.1	-4.4
350	-3.5	3.1	-1.0	-.5	4.5	-2.6	-1.3	4.1	-3.4	-.4	4.7	-3.7
1	2.2	.6	-3.5	-1.6	1.3	1.0	2.5	.9	-3.5	-1.6	1.0	-

STRESS OUTPUT ANALYSIS

ITER	PRIMARY + SECONDARY STRESS INTENSITIES						PEAK STRESS INTENSITIES					
	L - R		R - H		H - L		L - R		R - H		H - L	
	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
3	-2.8	2.5	21.5	9.4	-18.7	-11.9	-2.7	2.4	21.3	9.3	-18.6	-11.9
6	-3.3	2.9	22.1	9.5	-18.8	-12.4	-3.2	2.8	21.8	9.4	-18.7	-12.7
8	-3.7	3.3	22.5	9.6	-18.8	-12.8	-3.6	3.2	22.3	9.5	-18.6	-12.7
15	-4.1	3.6	24.0	10.1	-19.9	-13.7	-4.1	3.5	23.8	10.0	-19.7	-13.9
30	-3.3	2.8	21.0	10.3	-17.7	-13.1	-4.1	2.5	21.7	10.6	-17.6	-13.9
1211	-2.1	1.8	19.9	9.1	-17.8	-10.9	-2.2	1.4	20.0	9.6	-17.8	-10.9
91	-2.4	2.1	21.3	9.5	-18.9	-11.6	-2.4	2.1	21.3	9.5	-18.9	-11.7
1	1.1	.6	-3.3	-1.2	2.2	.7	1.1	.6	-3.3	-1.2	2.2	.7

STRESS OUTPUT ANALYSTS

5072	-4.7	4.0	23.0	9.4	-18.4	-13.5	-4.6	4.0	22.8	9.3	-18.2	-13.5
5060	-2.6	2.2	21.0	9.3	-18.4	-11.5	-2.5	2.2	20.9	9.2	-18.4	-11.5
5063	-3.2	2.8	21.8	9.4	-18.6	-12.2	-3.1	2.7	21.6	9.3	-18.5	-12.2
5124	-5.6	4.7	21.6	13.3	-16.0	-13.0	-2.7	5.6	18.7	12.3	-16.0	-17.0
5237	-5.4	4.5	15.5	11.5	-10.2	-15.9	-4.0	4.7	14.2	11.2	-10.2	-15.9
6059	-2.6	2.2	9.7	5.9	-7.1	-3.1	.1	1.8	7.1	6.3	-7.3	-8.0
6307	-1.9	1.6	9.7	4.6	-7.8	-6.1	-2.2	.4	10.0	6.6	-7.8	-6.1
6338	-1.4	1.2	9.4	4.6	-8.0	-5.8	-1.8	.8	9.7	6.6	-8.0	-5.8
850	-1.2	1.1	12.2	5.5	-11.0	-6.6	-1.2	1.1	12.2	5.5	-11.0	-6.6
1	1.1	.6	-3.3	-1.2	2.2	.7	1.1	.6	-3.3	-1.2	2.2	.7

STRESS OUTPUT ANALYSTS

STRESS INTENSITIES INSIDE OUTSIDE INSIDE OUTSIDE INSIDE OUTSIDE INSIDE OUTSIDE INSIDE OUTSIDE INSIDE OUTSIDE

ITER	PRIMARY + SECONDARY STRESS INTENSITIES						PEAK STRESS INTENSITIES					
	L - R		R - H		H - L		L - R		R - H		H - L	
	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
3	-5.2	4.6	-19.4	-14.1	24.6	9.5	-5.0	4.4	-19.6	-14.1	24.6	9.5
6	-5.9	5.2	-18.8	-14.0	24.7	8.9	-5.7	5.0	-19.0	-14.1	24.7	9.5
8	-6.6	5.8	-18.3	-14.1	24.9	8.3	-6.4	5.7	-18.6	-14.2	25.0	8.5
15	-7.2	6.4	-17.1	-13.6	24.4	7.3	-7.2	6.3	-17.3	-13.7	24.4	7.5
30	-5.8	5.1	-19.2	-13.3	25.0	8.2	-6.2	4.8	-18.9	-13.1	25.1	8.5
1211	-3.9	3.4	-20.0	-13.8	23.9	10.8	-4.0	3.1	-19.9	-13.4	23.9	10.5
191	-4.4	3.9	-21.0	-14.7	25.4	10.8	-4.4	3.9	-21.0	-14.7	25.4	10.5
1	1.9	.4	-3.3	-1.4	1.4	.4	1.9	.4	-3.3	-1.4	1.4	.5
27976	-4.0	3.5	-20.3	-14.0	24.1	10.6	-4.0	3.5	-20.1	-14.0	24.1	10.5
42321	-4.5	3.9	-20.7	-14.6	25.2	10.7	-4.5	3.1	-20.7	-14.6	24.2	10.5

STRESS OUTPUT ANALYSIS

5072	-8.1	7.1	-17.7	-14.4	25.8	7.3	-8.0	7.0	-17.9	-14.4	25.9	7.5
5060	-4.7	4.2	-19.8	-14.2	24.6	10.0	-4.6	4.0	-20.0	-14.2	24.6	10.5
5063	-5.8	5.1	-19.0	-14.1	24.8	9.1	-5.6	4.9	-19.2	-14.2	24.8	9.5
5124	-9.5	8.4	-16.4	-12.3	25.9	3.9	-9.3	8.2	-16.8	-12.1	26.1	4.5
5237	-8.9	7.8	-18.9	-10.6	27.8	2.7	-8.0	8.1	-19.9	-10.9	28.0	3.5
6059	-4.5	3.9	-5.4	-4.4	9.8	.5	-5.0	3.3	-5.0	-3.7	10.0	.5
6307	-3.2	2.9	-4.8	-3.9	8.0	1.1	-3.5	1.4	-4.6	-2.4	8.0	1.5
6338	-2.6	2.2	-5.2	-3.8	7.7	1.6	-2.8	.8	-4.9	-2.3	7.7	1.5
6850	-2.4	2.1	-11.6	-8.1	14.0	6.0	-2.4	2.1	-11.5	-8.1	13.9	6.5
1	1.9	.4	-3.3	-1.4	1.4	.9	1.9	.4	-3.3	-1.4	1.4	.5

STRESS OUTPUT ANALYSIS

ITER	PRIMARY + SECONDARY STRESS INTENSITIES						PEAK STRESS INTENSITIES					
	L - R		R - H		H - L		L - R		R - H		H - L	
	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
3	.0	.0	-.0	-.0	.0	.0	.0	.0	-.0	-.0	.0	.0
6	.0	.0	-.0	-.0	.0	.0	.0	.0	-.0	-.0	.0	.0
8	.0	.0	-.0	-.0	.0	.0	.0	.0	-.0	-.0	.0	.0
15	.0	.0	-.0	-.0	.0	.0	.0	.0	-.0	-.0	.0	.0
30	.6	-.5	-.6	.5	-.0	.0	1.5	-.3	-1.4	.1	-.0	-.0
211	-.3	.3	.3	-.0	.0	-.2	-.3	.3	.3	.0	.0	-.0
91	.0	.0	-.0	-.0	.0	.0	.0	.0	-.0	-.0	.0	.0
1	1.1	.1	-2.2	-.3	1.2	.2	1.1	.2	-2.2	-.3	1.2	.0

5072	.0	.0	-.0	-.0	.0	.0	.0	.0	-.0	-.0	.0	.0
5060	.0	.0	-.0	-.0	.0	.0	.0	.0	-.0	-.0	.0	.0
5063	.0	.0	-.0	-.0	.0	.0	.0	.0	-.0	-.0	.0	.0
5124	2.3	-1.8	-2.3	1.8	.1	.0	4.5	-1.4	-4.5	.6	-.1	-.1
5237	1.8	-1.5	-2.0	3.2	.2	-1.7	3.2	-1.0	-3.3	2.0	.1	-.1
6059	-1.7	1.1	2.1	3.3	-.3	-4.4	.1	2.6	.4	2.3	-.5	-.5
6307	-3.7	2.5	4.1	4.2	-.4	-6.7	-3.8	3.3	4.1	4.6	-.4	-7.0
6338	-3.7	2.5	4.1	4.2	-.4	-6.7	-3.8	3.3	4.1	4.6	-.4	-7.0
6P50	-5.6	4.1	6.4	.1	-.8	-1.2	-5.6	5.4	6.4	.6	-.8	-6.0
1	1.1	.1	-2.2	-.3	1.2	.2	1.1	.2	-2.2	-.3	1.2	.0

STRESS OUTPUT ANALYSIS

DETERMINATION OF MAXIMUM STRESS
INTENSITIES RANGES AND FATIGUE ANALYSIS

OSC 1522

Segment 5: Page 5-16 gives a summary of thermal stress intensities plus a stress intensity for a 1000 psi pressure. The worst stress intensity range for segment 5 would be full range of thermal stress from rapid depressurization plus pressure variation of 1500 psi (pressure at start of rapid depressurization) to 800 psi (pressure at time of reversal in thermal stress). The smaller pressure range is chosen since the pressure stresses are small and even the range of 2500 psi is less than the reversal in thermal stress. This will be assumed to occur 40 times.

The next maximum range comes from maximum thermal stress in the test transient plus range in pressure of 2200-0 psi (2200 psi is pressure at time of test).

The third range can be found using all the miscellaneous transients excluding the rapid depressurization and test transient. This last range will be shown to be acceptable for infinite number of cycles.

Segment 8 is analyzed for essentially same conditions as segment 5.

Segment 23, the carbon steel segment, is analyzed differently since it has less radial gradient thermal effects and its stress picture is more dependent on the temperature of the segment because of the bimetal weld.

Thus its highest stress intensity is derived from the range of its highest thermal stress to 0 stress plus the range of pressure from 2500 psi to 0. It is shown that all other ranges are essentially insignificant.

NOTE: This fatigue analysis includes thermal and mechanical discontinuity stresses only. For inclusion of stresses due to run and branch pipe motions, see Section "F".

D.MCK
10/29/73
REV. 1

0006190447

CRITICAL STRESS JUNCTURE 5 (STAINLESS)PRIMARY + SECONDARY STRESS

MAX. THERMAL STRESS RANGE = $83.9 - (-6.7) = 90.6$ KSI

ITER. 5863 ITER. 6850

MAX. PRESSURE RANGE = $1500 - 800 = 0.7(1.7) = 1.2$ KSI

$$S_N = 90.6 + 1.2 = 91.8 \text{ KSI} > 3S_m = 51.3 \text{ KSI}$$

ELASTIC - PLASTIC ANALYSIS WILL BE PERFORMED

1.) EQUATION 9 IS SATISFIED

2.) IT WILL BE SHOWN THAT PRIMARY PLUS SECONDARY STRESS RANGES DO NOT EXCEED $3S_m$ MORE THAN 250 CYCLES.

THE ABOVE RANGE WAS REPRESENTATIVE OF THE RAPID DEPRESSURIZATION CYCLE. THEREFORE IT OCCURRED 40 CYCLES.

- NEXT MAXIMUM RANGE WILL BE FROM THE TEST TRANSIENT -

RANGE IN THERMAL STRESS = 65.9 KSI

ITER. 6

RANGE IN PRESSURE $2200 \text{ PSI} - 0 = 2.2(1.7) = 3.74$ KSI

$$S_N = 65.9 + 3.74 = 69.64 \text{ KSI} > 3S_m = 51.3 \text{ KSI}$$

ACTUAL CYCLES = 40

BABCOCK & WILCOX
DEPARTMENT

DATE 8-72

BY

CHECKED DATE

BY

REVISION

5-22

CRITICAL STRESS JUNCTURE 5

NEXT MAX. RANGE OF PRIMARY + SECONDARY STRESSES

RANGE OF THERMAL STRESS DISREGARDING RAPID DEPRESSURIZATION AND TEST TRANSIENT = LESS THAN 5 KSI.

RANGE OF PRESSURE = $2.5(4) = 10$ KSI

$S_N = 5 + 10 = 15$ KSI $< 3S_m = 51.3$ KSI

THEREFORE, PRIMARY + SECONDARY STRESSES EXCEED $3S_m$ ONLY 80 CYCLES.

0006100449

BABCOCK & WILCOX
DEPARTMENT

DATE 8-72

BY

fwl

CHECKED DATE

BY

REVISION

5-23

FATIGUE ANALYSIS OF JUNCTURE 5CASE 1 RAPID DEPRESSURIZATION CYCLES = 90PEAK THERMAL STRESS RANGE (Pg. 5-16) = $142.5 + 8.4 = 151$ KSIPEAK PRESSURE STRESS RANGE (Pg. 5-16) = $.7(1.8) = 1.3$ KSI

$$S_p = 151 + 1.3 = 152.3 \text{ KSI} \quad K_e = \frac{1}{3} = \frac{1}{n} \quad S_n = 1.7(3S_m)$$

$$S_{ALT} = .5\left(\frac{1}{3}\right)(152.3) = 259 \text{ KSI}$$

$$\text{ALLOWABLE CYCLES} = 55 \quad U_1 = \frac{90}{55} = 0.727$$

CASE 2 TEST TRANSIENT TO ZERO STRESS STATE CYCLES = 90

PEAK THERMAL STRESS ITER. 3 = 109.1 KSI

PEAK PRESSURE STRESS AT 2200 PSI = $2.2(1.8) = 3.96$ KSI

$$S_p = 109.1 + 3.96 = 109 \text{ KSI}$$

$$K_e = 1 + \frac{(1+n)}{n(n-1)} \left[\frac{S_n}{3S_m} - 1 \right] = 1 + \frac{.7}{3(.7)} \left[\frac{79.74}{51.3} - 1 \right] = 2.523$$

$$S_{ALT} = 0.5(2.523)(109) = 136 \text{ KSI}$$

$$\text{ALLOWABLE CYCLES} = 360 \quad U_2 = \frac{90}{360} = 0.111$$

NOTE: THIS FATIGUE ANALYSIS INCLUDES THERMAL AND MECHANICAL DISCONTINUITY STRESSES ONLY. FOR INCLUSION OF STRESSES DUE TO RUN AND BRANCH PIPE STRESSES, SEE SECTION "F"

BABCOCK & WILCOX
DEPARTMENT

DATE 10-29-73 BY D.MCK.

CHECKED DATE BY

REVISION
REV. 1
5-24

0006100450

OSC 1522

CASE 3 ALL OTHER CONDITIONS

THERMAL STRESS RANGE LESS THAN 10 KSI

PEAK PRESSURE STRESSES = $2.5(4) = 10$ KSI

$$S_p = 10 + 10 = 20 \text{ KSI}$$

SALT = 10 KSI ALLOWABLE CYCLES = ∞

THEREFORE,

$$U_{\text{TOTAL}} = U_1 + U_2 = 0.727 + .111 = 0.838 < 1.0$$

NOTE: THIS FATIGUE ANALYSIS INCLUDES THERMAL AND MECHANICAL DISCONTINUITY STRESSES ONLY. FOR INCLUSION OF STRESSES DUE TO RUN AND BRANCH PIPE MOTIONS, SEE SECTION "F".

BABCOCK & WILCOX
DEPARTMENT

DATE 10-29-73 BY D.MCK.

CHECKED DATE BY

REVISION
REV. 1

5-25

0006100451

CRITICAL STRESS JUNCTURE B

PRIMARY + SECONDARY RANGE

THERMAL STRESS RANGE = $97.9 - (-7.7) = 105.6$ KSI

ITER. 5063 ITER. 6338

PRESSURE STRESS RANGE

PRESSURE AT ITER. 5063 = 1500 PSI S = 3.3 KSI

PRESSURE AT ITER. 6338 = 800 PSI S = 1.76 KSI

TOTAL S = $105.6 + 3.3 - 1.76 = 107$ KSI $> 3S_m = 51.7$ KSI

AN ELASTIC-PLASTIC ANALYSIS PER THE USAS B31.7 CODE, PARA. I-705.9 WILL BE PERFORMED.

DETERMINE NUMBER OF CYCLES $3S_m$ CAN BE EXCEEDED.

1.) THE ABOVE CASE COMES FROM TIMES WITHIN THE RAPID DEPRESSURIZATION TRANSIENT. THEREFORE, THE NUMBER OF CYCLES = 40

2.) DETERMINE NEXT THE MAXIMUM RANGE OF STRESSES

0006100452

BABCOCK & WILCOX
DEPARTMENT

DATE 8-72

BY

JML

CHECKED DATE

BY

REVISION

5-26

050 1522

STRESS JUNCTURE 8

NEXT MAXIMUM RANGE COMES FROM THE TEST TRANSIENT
AND A NO FLOW CONDITION. CYCLES = 40

$$\text{THERMAL RANGE} = 78.8 - (-.7) = 79.5 \text{ KSI}$$

ITER. 8 ITER. 2776

$$\text{PRESSURE RANGE} = 2500 - 2200 = 300 \text{ PSI}$$

MAX. TEST

A WORST CASE IS DISREGARDING THERMAL STRESS REVER
AL AND USING RANGE OF 2200

$$S_{\text{MAX}} = 78.8 + 2.2 \text{ (L-R)} (2.2) = 83.6 \text{ KSI} > 3S_m = 51.3 \text{ KSI}$$

3.) NEXT MAXIMUM RANGE EXCLUDING RAPID DEPRES. |
TEST TRANSIENT

$$\text{THERMAL RANGE} = 1.1 \text{ KSI ITER. 2776}$$

$$\text{PRESSURE RANGE} = 2500 \text{ PSI}; S = 2.5 \text{ (3.5)} = 8.75 \text{ KSI}$$

(R-H)

$$S_{\text{MAX}} = 1.1 + 8.75 = 9.85 \text{ KSI} < 3S_m = 51.3 \text{ KSI}$$

$$\text{NUMBER OF CYCLES OVER } 3S_m = 40 + 40 = 80 < 250$$

THEREFORE $3S_m$ IS NOT EXCEEDED MORE THAN 250 CYCLE
AND ALL ELASTIC-PLASTIC REQUIREMENTS ARE MET.

BABCOCK & WILCOX

DEPARTMENT

DATE 8-72

BY

b.w.s.

REVISION

CHECKED DATE

BY

5-27

FATIGUE ANALYSIS OF JUNCTURE B

CASE-1 RAPID DEPRESSURIZATION TRANSIENT 90 CYCLES

PEAK THERMAL RANGE (Pg. 5-17) = $197.9 - (-9.6) = 157$ KSI

PEAK PRESSURE RANGE (Pg. 5-17) = $0.7(2.5) = 1.75$ KSI

$S_{PEAK} = 157 + 1.75 = 158.7$ KSI

CALCULATE K_c FACTOR FOR ELASTIC-PLASTIC FACTOR. THE 1971 SECTION III EQUATION WILL BE USED SINCE IT IS MORE CONSERVATIVE THAN THE B31.7 1968 DRAFT VERSION.

$K_c = \frac{1}{K_1} = \frac{1}{.3} = 3.33$ SINCE S_N EXCEEDS $1.7(3S_m) = 87.2$ KSI

$\therefore S_{ACT} = \frac{1}{2}(3.33)(158.7) = 267$ KSI \therefore ALLOWABLE CYCLES =

$U_1 = \frac{90}{60} = 0.667$

CASE-2 TEST TRANSIENT COMBINED WITH A NO FLOW CONDITION - 90 CYCLES

PEAK THERMAL RANGE (Pg. 5-17) = 115 KSI

PEAK PRESSURE RANGE (Pg. 5-17) = $2.2(2.5) = 5.5$ KSI

$S_p = 115 + 5.5 = 120.5$ KSI

NOTE: THIS FATIGUE ANALYSIS INCLUDES THERMAL AND MECHANICAL DISCONTINUITY STRESSES ONLY. FOR INCLUSION OF STRESSES DUE TO RUN AND BRANCH PIPE MOTIONS, SEE SECTION "F".

BABCOCK & WILCOX
DEPARTMENT

DATE 10-29-73

BY D.MCK

CHECKED DATE

BY

REVISION
REV. 1

5-28

0005100451

O.S.C 1522

JUNCTURE 8 (CONTINUED)

$K_e = 1/n = 3.33$ $SALT = 1/2(3.33)(120.5) = 201.0 \text{ KSI}$

ALLOWABLE CYCLES = 190

$U_2 = \frac{90}{190} = 0.286,$

CASE - 3 MAXIMUM RANGE EXCLUDING RAPID DEPR. + TEST

PEAK THERMAL RANGE (PAGE 5-17) = 1.2 KSI

PEAK PRESSURE RANGE (PAGE 5-17) = 2.5(3.5) = 8.75 KSI

$S_p = 1.2 + 8.75 = 9.95 \text{ KSI}$ $SALT = 5 \text{ KSI}$

ALLOWABLE CYCLES = ∞ $U_3 = 0.0$

$\therefore U_{TOTAL} = U_1 + U_2 = 0.667 + 0.286 = 0.953 < 1.0$

NOTE: THIS FATIGUE ANALYSIS INCLUDES THERMAL AND MECHANICAL DISCONTINUITY STRESSES ONLY. FOR INCLUSION OF STRESSES DUE TO RUN AND BRANCH PIPE MOTIONS, SEE SECTION "F".

BABCOCK & WILCOX
DEPARTMENT

DATE 10-29-73

BY D.MCK²

CHECKED DATE

BY

REVISION
REV. 1

5-29

0006100455

CRITICAL STRESS JUNCTURE 23 CARBON STEEL
PRIMARY + SECONDARY STRESS

MAX. RANGE OF THERMAL STRESS = 27.8 KSI [H-L INSIDE]
(PGS-17)

MAX. RANGE OF PRESSURE = 2500 PSI

$S_{PRESS} = 2.5(3.3) = 8.25 \text{ KSI}$

$S_N = 27.8 + 8.25 = 36.05 \text{ KSI} < 3S_m = 53.4 \text{ KSI}$

THEREFORE, THIS JUNCTURE DOES NOT EXCEED THE
3S_m LIMIT.

FATIGUE ANALYSIS OF JUNCTURE 23

CASE - 1 MAXIMUM STRESS IN CONJUNCTION WITH ZERO
STRESS STATE CYCLES = 290

MAX. PEAK THERMAL STRESS = 28 KSI ITER. 5237 (H-L INSIDE)

MAX. PEAK PRESSURE STRESS = 3.3(2.5) = 8.25 (R-H INSIDE)

$S_p = 28 + 8.25 = 36.25 \text{ KSI}$ $S_{ALT} = 18 \text{ KSI}$

ALLOWABLE CYCLES = 35000

$U_1 = \frac{290}{35000} = 0.007$

NOTE: THIS FATIGUE ANALYSIS INCLUDES THERMAL AND
MECHANICAL DISCONTINUITY STRESSES ONLY. FOR
INCLUSION OF STRESSES DUE TO RUN AND BRANCH
PIPE MOTIONS, SEE SECTION "F".

BABCOCK & WILCOX
DEPARTMENT

DATE: 10-29-73

BY: D. MCK.

CHECKED DATE

BY

REVISION
REV. 1

5-30

0006100455

OSC 1522

CASE - 2 MAXIMUM STRESS RANGE DISREGARDING
HEAT-UP & COOL-DOWN

PEAK THERMAL STRESS RANGE = 26.1 - 10 = 16.1 KSI
ITER. STR 9 ITER. 6059

PEAK PRESSURE RANGE = (2.5 - 1.7) 3.3 = 2.64 KSI
THIS MAX. PRESSURE - MIN. PRESSURE (REACTOR TRIP + B) DISREGARDING
ZERO STRESS STATE.

$S_p = 16.1 + 2.64 = 18.74 \text{ KSI}$

$S_{ACT} = 9.4 \text{ KSI}$ ALLOWABLE CYCLES = ∞

$U_{TOTAL} = U_1 = 0.007 < 1.0$

O.K.

NOTE: THIS FATIGUE ANALYSIS INCLUDES MECHANICAL AND
THERMAL DISCONTINUITY STRESSES ONLY. FOR
INCLUSION OF STRESSES DUE TO RUN AND BRANCH
PIPE MOTIONS, SEE SECTION "F"

BABCOCK & WILCOX DEPARTMENT	DATE 10-29-73	BY D.MCK.	REVISION
	CHECKED DATE	BY	REV. 1 5-31

interim analysis

Oconee Nuclear Station Problem Investigation Process - PIP Problem Investigation Form

Scott
copy to
HPI, Ed
Girard

PIP Serial No: 0-097-1368	LER Serial No:
MSE Serial No:	Other Report:

I. Problem ID

Discovered Time/Date: 16:06 04/27/97 Occurred Time/Date: 16:06 04/27/97

Unit(s): 0

<u>Status at Time Discovered</u>	<u>Unit 1</u>	<u>Unit 2</u>	<u>Unit 3</u>
Mode	N/A	N/A	N/A
% Power			

Unit Status Remarks:

System(s) Affected: HPI Other High Pressure Injection Equip.
RC Reactor Coolant

Affected Equipment

<u>WMS Equipment ID No.</u>	<u>Comp. Code</u>	<u>Manufacturer</u>

Location of Problem - Bldg: R Column Line: Elev:

Location Remarks:

High Pressure Normal Injection nozzles

Method Used to Discover Problem:

Engineering review

Brief Problem Description:

Possible inadequate evaluation of thermally induced stresses at HPI normal injection nozzles.

Detailed Problem Description:

It appears that the data from letter dated 5/15/91, from David Whitaker to Bob Morgan, Jr (subject: "Data transfer for ONS Unit 1 Start up at end of EOC 12 Outage in response to NRC Bulletins 88-08 and 88-11 dealing with Thermal stratification") has not been incorporated into existing ONS calculations for the HPI system.

Originated By: CCT8276: TOMPKINS, CRAIG C Team: CCT8276 Group: MCE Date: 04/27/97

This data should be specifically reviewed for impact on calcs performed for NRC Bul 88-08 (includes Calcs OSC - 3681 and OSC-1323-06.)

Last Updated By: RPT7314: TODD, RANDALL P Team: RTB7310 Group: SRG Date: 05/13/97

Oconee Nuclear Station

Problem Investigation Process - PIP

Problem Investigation Form

PIP Serial No:	0-097-1368	LER Serial No:	
MSE Serial No:		Other Report:	

Last Updated By: RSM7315: MATHESON, RICKIE S Team: RTB7310 Group: SRG Date: 05/28/97

Responsible Group for Proposed Resolution(s):	MCE	Mech/Civil Eq. Eng.
Responsible Group for Problem Evaluation:	MCE	Mech/Civil Eq. Eng.
Responsible Group for Overall PIP approval:	MCE	Mech/Civil Eq. Eng.

	<u>Indiv</u>	<u>Team</u>	<u>Group</u>	<u>Date</u>
Screened By:	RSM7315	RTB7310	SRG	05/28/97

This PIP has been downgraded from an MSE to an LSE status

III. Operability

Present Operability:

Responsible Group: MCE Status: Closed

Sys/Comp Operable?(Y,N,C,E): Y

Required Mode: N/A

Comments:

STATEMENT OF PROBLEM

Thermocouple data was collected on the HPI Normal Make-up and Emergency Injection piping during heatup of Oconee Unit 1 in early June 1990 (after EOC 12). The results of this data indicated significant thermal stratification was occurring in the normal make-up line. A maximum top to bottom temperature differential of 327°F was experienced during periods when one "A" Reactor Coolant Pump was not operating, with reduced Letdown, and with reduced and oscillating make-up. This indicated that backleakage was occurring through valve IHP-127. This information was transmitted to Robert Morgan, Jr. (ONS Pipe Stress Engineer) from David Whitaker (Nuclear Production Engineer) via letter on May 15, 1991. David's summary letter indicated that significant thermal stratification was experienced on the normal makeup line.

However, this thermocouple data on the HPI normal make-up piping was not analyzed to determine if the piping was acceptable for the thermal stratification loadings.

RELATION TO QA CONDITION

The HPI Normal Make-up Piping in question is QA Condition 1

APPLICABLE CODES AND STANDARDS

1. 1968 B31.7 Power Piping Code

Oconee Nuclear Station

Problem Investigation Process - PIP

Problem Investigation Form

PIP Serial No: 0-O97-1368
MSE Serial No:

LER Serial No:
Other Report:

2. 1983 ASME Code, Section III

EVALUATION INPUTS / METHODS USED

Structural Integrity Associates (SIA) performed a limited cycle Class I fatigue analysis per the 1983 ASME Code using the applicable design basis transients listed in UFSAR Table 5-2 and the thermocouple data taken in June 1990. Loads and moments applied on the makeup nozzle by the piping were supplied to SIA by ONS. These loads and moments came from OSC-1304-06.

To perform the analyses, SIA needed the actual number of applicable transients experienced on Unit 1 to date. This information was provided to them from the AOTC Logbook. The total number of occurrences to date for each transient considered in the analysis follows:

Heatup on ONS Unit 1 -	94
Cooldowns on ONS Unit 1 -	95
ONS Unit 1 Trip (Transient 8A) -	5
ONS Unit 1 Trip (Transient 8B) -	27
ONS Unit 1 Trip (Transient 8C) -	29

Also used in SIA's analysis was a previous analysis on the HPI Make-up nozzle performed by B&W. This analysis is contained in B&W Document No. 32-1128224-02, "Revised HPI Nozzle Usage Factor".

APPLICABLE LICENSING REFERENCES

1. UFSAR Sections 3.2.2.1, 5.2 (including subsections), and 5.4.7.2
2. UFSAR Table 5-2
3. Letter from NRC to Duke Power Dated July 10, 1995, "Reactor Coolant System (RCS) Auxillary Piping Fatigue Analysis Schedule".

ASSUMPTIONS

1. From observance of the thermocouple data, the thermal stratification on the make-up line occurred 5 times during the June 1990 heatup. In order to estimate the number of cycles for the thermal stratification, SIA assumed that the thermal stratification occurred 5 times during each heatup, and plant trip.
2. From previous calculations, it has been demonstrated that the nozzle safe-end to piping weld is the most limiting thermal fatigue location (ie has the highest Cumulative Usage Factor). Therefore, the thermal fatigue effects of the thermal stratification were analyzed at this weld. If demonstrated to be acceptable, then it is assumed all other locations (nozzle and piping) will be acceptable as well.
3. The thermal stratification observed on the make-up piping was due to backflow through valve 1HP-127. In order for this transient to occur, make-up valves HP-126 and HP-127 must leak. New check valves have been installed on Units 2 & 3. It is assumed that these new valves will not allow

Oconee Nuclear Station

Problem Investigation Process - PIP

Problem Investigation Form

PIP Serial No:	0-O97-1368	LER Serial No:	
MSE Serial No:		Other Report:	

backleakage, thus eliminating the thermal stratification observed from the backflow transient. New check valves are also planned to be installed in Unit 1 during the next refueling outage. These new valves should eliminate the thermal stratification resulting from backleakage.

Thermocouples are being installed on the HPI make-up lines on Units 1, 2, and 3. The data collected by the thermocouples will allow ONS Engineering to validate this assumption.

Therefore, the analysis performed by SIA only evaluates the actual number of occurrences of each transients to date plus an estimate of transients that will occur between now and replacement of the check valves on the make-up line. A cumulative usage factor was calculated for a limited number of transient cycles. The omission of the balance of UFSAR Table 5-2 transients is discussed below.

The additional number of cycles assumed in the analysis between now and the next refueling outage are:

Hcatups -	2
Cooldowns -	2
Trips -	1
OBE	1
HPI Manual Actuation -	1

REFERENCES

1. AOTC Logbook
2. Calculation performed by SIA
3. Thermocouple data taken from June 1990 Heatup of Unit 1
4. B&W Document No. 32-1128224-02, "Revised HPI Nozzle Usage Factor"
5. OSC-1522, RCS Piping Stress Report

CALCULATION / EVALUATION

SIA calculated a fatigue usage factor on the makeup nozzle safe-end to piping weld for a limited number of cycles. The transients considered and their associated cycles were:

Normal Operation (154 cycles)
Normal Operation with Stratification Initiation (515 cycles)
Normal Operation with Stratification Decay (510 cycles)
Trip with RCS Pressure reduction (57 cycles)
Trip with Stratification Initiation (285 cycles)
Trip with Stratification Decay (285 cycles)
HPI Manual Actuation Up (1 cycle)
OBE (1 cycle)
Zero Load (97 cycles)

The change in moments applied to the nozzle from thermal stratification were estimated as twice the thermal stratification moments on the emergency injection piping. The thermal stratification moments on the emergency injection nozzle was obtained from reference 4.

Oconee Nuclear Station

Problem Investigation Process - PIP

Problem Investigation Form

PIP Serial No: 0-097-1368
MSE Serial No:

LER Serial No:
Other Report:

The result of the analysis was a cumulative usage factor of 0.04 which is much less than 1.0.

The analysis performed was based on the 1983 ASME Code. Reconciliation between 1983 ASME Code and B31.7 is addressed in the SIA calculation. As discussed in the calculation, the techniques used in evaluating the usage factor were more conservative than those in B31.7.

The original B&W analysis determined that the application of all Design events upon this nozzle would result in a CUF of 0.045. Due to the low predicted CUF in both evaluations, it is not necessary to merge the two to conclude CUF will not exceed 1.0 before the next refueling outage.

SIA's calculation assumed a number of future cycles between now and replacement of the HPI make-up valves. Two additional heatup and cooldown transients were assumed. The HPI make-up valves (1HP-126, -127) are going to be replaced by NSM ON-12975 during the next refueling outage which is scheduled to begin late August 1997. Given the low usage factor (0.04) on this nozzle, an engineering judgement is made that no mechanism needs to be put into place to count and limit the number of heatup and cooldown cycles that can occur before the HPI valves are replaced. Even if the number of assumed heatup, cooldown, trip, and HPI actuation cycles were exceeded, it will not result in the usage factor being greater than 1.0.

However, a corrective action to this PIP will be established to verify that valves 1HP-126, -127 were replaced by NSM ON-12975 and that the assumption of no backleakage through the new valves is valid.

SIA's calculation will be incorporated into piping analysis calculation OSC-1304-06.

Since the usage factor calculated is less than 1.0, the HPI Make-up piping is determined to be OPERABLE.

Compensatory Actions Required for Operability

None

Conclusions

The HPI Make-up piping is OPERABLE for the occurrence of the thermal stratification during back flow through valves 1HP-126, -127.

Originated By: PAW4981: WELLS, PHILLIP A Team: RAH8344 Group: MCE Date: 05/16/97

Operability evaluation was revised on 5/19/97 to incorporate editorial corrections such that the evaluation correctly corresponds with calculation performed by Structural Integrity Associates. The conclusion of OPERABLE was not changed.

Last Updated By: PAW4981: WELLS, PHILLIP A Team: RAH8344 Group: MCE Date: 05/19/97

Oconee Nuclear Station

Problem Investigation Process - PIP

Problem Investigation Form

PIP Serial No: 0-097-1368 MSE Serial No:	LER Serial No: Other Report:
---	---

Last Updated By: PAW4981: WELLS, PHILLIP A Team: RAH8344 Group: MCE Date: 05/19/97

	<u>Indiv</u>	<u>Team</u>	<u>Group</u>	<u>Date</u>
Accepted By:	KWG7360	TKR7315	MCE	05/08/97
Due Date:	05/22/97			
Ready for Checked By:	KWG7360	TKR7315	MCE	05/22/97
Assigned To:	TDB2719	RAH8344	MCE	05/22/97
Checked By Assigned To:	TDB2719	RAH8344	MCE	05/22/97
Checked By:	TDB2719	RAH8344	MCE	05/27/97
Ready For Approval:	TDB2719	RAH8344	MCE	05/27/97
Approval Assigned To:	RAH8344	RAH8344	MCE	05/27/97
Approved By:	RAH8344	RAH8344	MCE	05/27/97
Evaluated By:	RSM7315	RTB7310	SRG	05/28/97

Past Operability:

Responsible Group: MCE Status: Closed

Sys/Comp Operable?(Y,N,C,E): Y

Required Mode: N/A

Comments:

The calculation performed by Structural Integrity Associates that was used to demonstrate that this piping is Operable in its present condition is sufficient to demonstrate that the piping has been PAST OPERABLE. No additional analyses are required to determine the past operability condition of the HPI Normal Make-up piping on Unit 1.

Originated By: PAW4981: WELLS, PHILLIP A Team: RAH8344 Group: MCE Date: 05/22/97

	<u>Indiv</u>	<u>Team</u>	<u>Group</u>	<u>Date</u>
Due Date:	06/06/97			
Accepted By:	KWG7360	TKR7315	MCE	05/08/97
Assigned To:	PAW4981	RAH8344	MCE	05/19/97
Ready for Checked By:	PAW4981	RAH8344	MCE	05/22/97
Checked By Assigned To:	TDB2719	RAH8344	MCE	05/27/97
Checked By:	TDB2719	RAH8344	MCE	05/27/97
Ready For Approval:	TDB2719	RAH8344	MCE	05/27/97
Approval Assigned To:	RAH8344	RAH8344	MCE	05/27/97
Approved By:	RAH8344	RAH8344	MCE	05/27/97
Evaluated By:	RSM7315	RTB7310	SRG	05/28/97

IV. Reportability/Investigation

Responsible Group: SRG Status: Closed

Oconee Nuclear Station

Problem Investigation Process - PIP

Problem Investigation Form

PIP Serial No: 0-097-1368	LER Serial No:
MSE Serial No:	Other Report:

Problem Reportable(Y,N,E):

Reportable Pcr:

Comments:

This event is not reportable.

Originated By: RSM7315: MATHESON, RICKIE S Team: RTB7310 Group: SRG Date: 05/28/97

	<u>Indiv</u>	<u>Team</u>	<u>Group</u>	<u>Date</u>
Assigned To:			SRG	05/08/97
Ready For Approval:	RSM7315	RTB7310	SRG	05/28/97
Approval Assigned To:	RSM7315	RTB7310	SRG	05/28/97
Approved By:	RSM7315	RTB7310	SRG	05/28/97
Concurrence By:	MEB2307	JEB8371	RGC	05/28/97

Investigation Report:

Responsible Group:

Act Date:

Investigator:

Due Date:

Date Due to VP or Sta. Mgr:

Date Regulatory or Agency Rpt Due:

Date Investigation Report Approved:

NRC Cause Codes:

V. Problem Evaluation

Responsible Group: MCE

Status: Closed

System(s) Affected: HPI
RC

Other High Pressure Injection Equip.
Reactor Coolant

Affected Equipment

<u>WMS Equipment ID No.</u>	<u>Comp.</u>	<u>Code</u>	<u>Manufacturer</u>

<u>Event</u>	<u>Cause Cd</u>	<u>Cause Description</u>	<u>Primary</u>	<u>Causing Group(s)</u>
D6	YYY	Incomplete Problem Evaluation	No	

Primary Causing Group(s)
No

Oconee Nuclear Station

Problem Investigation Process - PIP

Problem Investigation Form

PIP Serial No: 0-097-1368 MSE Serial No:	LER Serial No: Other Report:
---	---

Problem Evaluation:

The causes of not incorporating the thermo-couple data into the appropriate Oconee stress analysis calculations is covered in PIP O-97-01324. This PIP documents the efforts and reports the results of the Failure Investigation Process (FIP) team report concerning the weld failure of the 2A1 HPI/MU safe-end to pipe weld. A full detailed report of the human performance error associated with not incorporating the data is included in the FIP report.

Originated By: TDB2719: BROWN, TIMOTHY D Team: RAH8344 Group: MCE Date: 05/30/97

Last Updated By: TDB2719: BROWN, TIMOTHY D Team: RAH8344 Group: MCE Date: 05/30/97

	<u>Indiv</u>	<u>Team</u>	<u>Group</u>	<u>Date</u>
Due Date:	05/27/97			
Accepted By:	KWG7360	TKR7315	MCE	04/28/97
Assigned To:	TDB2719	RAH8344	MCE	05/28/97
Ready For Approval:	TDB2719	RAH8344	MCE	05/30/97
Approval Assigned To:	TDB2719	RAH8344	MCE	05/30/97
Approved By:	RAH8344	RAH8344	MCE	06/01/97

VI. Proposed Resolution

Proposed Resolution From: Resp. Group: MCE Status: Closed OEDB Checked: Yes

The thermal stratification noted as a result of the thermo-couple data taken in 1990 and transmitted via David Whitaker's letter to Robert Morgan in 1991 will be fully evaluated within the Reactor Coolant Class 1 Branch Line project currently in progress. Duke Power has contracted with Structural Integrity Associates of San Jose California to complete Class 1 evaluations on all of the Reactor Coolant branch lines that were previously evaluated to Class 2 rules. The HPI & HPI/MU lines are included within the scope of the project. The expectation of the project is that all loading including the noted thermal stratification will be included in the determination of the fatigue life of the various components. The schedule for completion of the project, including all plant modifications is August of 1999.

Originated By: TDB2719: BROWN, TIMOTHY D Team: RAH8344 Group: MCE Date: 05/30/97

	<u>Indiv</u>	<u>Team</u>	<u>Group</u>	<u>Date</u>
Due Date:	05/27/97			
Accepted By:	KWG7360	TKR7315	MCE	04/28/97
Assigned To:	TDB2719	RAH8344	MCE	05/28/97
Ready For Approval:	TDB2719	RAH8344	MCE	05/30/97
Approval Assigned To:	TDB2719	RAH8344	MCE	05/30/97
Approved By:	RAH8344	RAH8344	MCE	06/01/97

Oconee Nuclear Station

Problem Investigation Process - PIP

Problem Investigation Form

PIP Serial No: 0-097-1368	LER Serial No:
MSE Serial No:	Other Report:

VII. Corrective Actions

Seq. No: 1

Resp Group: MCE	Status: Closed
Orig Group: MCE	Event Code: D6
Prop CAC: B	Cause Code: YYY

Proposed Corrective Action:

Civil Engineering should verify that the HPI Make-up valves (IHP-126 & IHP-127), Class I HPI Make-up piping, and make-up piping to nozzle welds were replaced by NSM ON-12975.

Originated By: PAW4981: WELLS, PHILLIP A Team: RAH8344 Group: MCE Date: 05/16/97

	<u>Indiv</u>	<u>Team</u>	<u>Group</u>	<u>Date</u>
Assigned To:	PAW4981	RAH8344	MCE	05/19/97
Ready For Approval:	KWG7360	TKR7315	MCE	05/19/97
Approval Assigned To:	RAH8344	RAH8344	MCE	05/19/97
Approved By:	RAH8344	RAH8344	MCE	05/22/97

General:

Outage: Mode:

<u>Other Tracking Processes</u>		
<u>Type</u>	<u>Number</u>	<u>Text</u>

Actual Corrective Action:

Actual CAC: Status: Open
Due Date: 10/24/97

	<u>Indiv</u>	<u>Team</u>	<u>Group</u>	<u>Date</u>
Due Date:	10/24/97			
Accepted By:	RAH8344	RAH8344	MCE	05/22/97
Assigned To:	TDB2719	RAH8344	MCE	05/22/97

Seq. No: 2

Resp Group: MCE	Status: Closed
Orig Group: MCE	Event Code: D6
Prop CAC: B3a	Cause Code: YYY

Proposed Corrective Action:

Civil Engineering needs to evaluate the thermocouple data taken on the HPI Normal Make-up System after replacement of valves IHP-126, -127 to verify backleakage through the new check valves is not occurring. If backleakage is still

**Oconee Nuclear Station
Problem Investigation Process - PIP
Problem Investigation Form**

PIP Serial No: 0-097-1368	LER Serial No:
MSE Serial No:	Other Report:

Indiv _____ Team _____ Group _____ Date _____
Concurred By:

IX. Attachments

Generic Applicability

Generic Applicability Review Not Required for this PIP.

Environmental

No Environmental for this PIP.

Failure Prevention Investigation:

No FPI for this PIP.

Remarks

No Remarks for this PIP

Maintenance Rule

Responsible Group: SES Status: Closed

Maintenance Rule SSC:	<u>SSC</u>	<u>Description</u>	<u>Risk Significant</u>
	HPI	High Pressure Injection System	Yes

Equipment Group: P01
Applicable Unit: Unit 1
 Unit 2
 Unit 3

Functional Failure: No MPFF: None Repetitive MPFF: None

Functional Failure Comments:

No functional failure is attributed to the documentation deficiency described within this PIP. PIP 97-1324, as identified in the Cause Evaluation section of this PIP, directly addresses the Unit 2 HPI nozzle failure and accordingly all MR implications.

Originated By: RSL7360: LEATHERWOOD, ROBERT S Team: SLN8374 Group: SES Date: 06/05/97

Oconee Nuclear Station

Problem Investigation Process - PIP

Problem Investigation Form

PIP Serial No: 0-097-1368 MSE Serial No:	LER Serial No: Other Report:
---	---

MPFF Comments:

Repetitive MPFF Comments:

Reactor Trip: No Safety System Actuation: No Loss of Heat Decay Removal: No
 Contrib. Force Outage Rate: No

Comments:

	<u>Indiv</u>	<u>Team</u>	<u>Group</u>	<u>Date</u>
Assigned To:	RSL7360	SLN8374	SES	05/08/97
Due Date:	07/01/97			
Ready For Approval:	RSL7360	SLN8374	SES	06/05/97
Approval Assigned To:	SLN8374	SLN8374	SES	06/09/97
Approved By:	SLN8374	DBC7309	SES	06/16/97

End of the Document for PIP No: 0-097-1368
 The status of this PIP is: Screened
 The duration of this PIP was: 31 days