

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

As required by the Provisions of the ASME Code Rules

1. Owner Duke Power Company, 422 S. Church St., Charlotte, NC 28201
(Name and Address of Owner)

2. Plant Oconee Nuclear Station, Highway 130/183, Seneca, SC 29679
(Name and Address of Plant)

3. Plant Unit 1 4. Owner Certificate of Authorization (if required) N/A

5. Commercial Service Date 7-15-73 6. National Board Number for Unit N/A

7. Components Inspected

Component or Appurtenance	Manufacturer or Installer	Manufacturer or Installer Serial No.	State or Province No.	National Board No.
SEE SECTION 1 PARAGRAPH 1.5 IN THE ATTACHED REPORT.				
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

9008210015 900815
PDR ADOCK 05000269
Q PDC

FORM NIS-1 (back)

8. Examination Dates 02-13-89 to 06-04-90 9. Inspection Interval from 03-01-84 to 03-01-94

10. Abstract of Examinations. Include a list of examinations and a statement concerning status of work required for current interval. See Attached Report

11. Abstract of Conditions Noted. See Attached Report

12. Abstract of Corrective Measures Recommended and Taken See Attached Report

We certify that the statements made in this report are correct and the examinations and corrective measures taken conform to the rules of the ASME Code, Section XI.

Date 8-9 19 90 Signed Duke Power Co. By A. R. Davison
Owner

Certificate of Authorization No. (if applicable) N/A Expiration Date N/A

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of NORTH CAROLINA and employed by *The HSBI&I Co. of HARTFORD CT. have inspected the components described in this Owners' Data Report during the period 02-13-89 to 06-04-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners' Data Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners' Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date Aug. 9 19 90

Rayford F. Elgin
Inspector's Signature

Commissions

NC 828

National Board, State, Province and No.

*The Hartford Steam Boiler Inspection & Insurance Co.
1117 Perimeter Center W.
Suite E-301
Atlanta, Ga 30338

INSERVICE INSPECTION REPORT
UNIT 1 OCONEE 1990 REFUELING
OUTAGE 12

Location: Oconee County, South Carolina
NRC Docket No. 50-287
Commercial Service Date: July 15, 1973

Owner: Duke Power Company
422 S. Church St.
Charlotte, N. C. 28201

Revision 0

Prepared By: A. J. Hogg, Jr. Date 7-30-90
Reviewed By: T. L. Tucker Date 8-7-90
Approved By: A. B. [Signature] Date 8/9/90

Copy No. 5

Assigned To NRC Document Control

Controlled X

Uncontrolled _____

CONTROLLED DISTRIBUTION

<u>Copy No.</u>	<u>Assigned To</u>
Original	C. B. Cheezem
1	T. L. Tucker
2	R. A. Morgan
3	T. E. Smith (B&W Lynchburg)
4	P. F. Guill (to Licensing File)
5	NRC Document Control

UNCONTROLLED DISTRIBUTION

6	C. A. Ireland (AIA, Atlanta, GA)
---	-------------------------------------

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Revision</u>
1.	Summary of Inservice Inspection	0
2.	Status of Required Inspections	0
3.	Final Inservice Inspection Plan for Outage 12	0
4.	Results of Inspections Performed During Outage 12	0
5.	Class 1 Inspection Results	0
6.	Class 2 Inspection Results	0
7.	Augmented Inspection Results	0
8.	Personnel, Equipment, and Material Certifications	0
9.	Problem Investigation Reports	0
10.	Reference Documents	0
11.	Class 1 and 2 Repairs and Replacements	0

1.0 Summary of Inservice Inspection

This report describes the Inservice Inspection of Duke Power Company's Oconee Nuclear Station Unit 1 during the 1990 Refueling Outage (also referred to as Outage 12).

Included in this report are the final Inservice Inspection Plan, the inspection results for each item, a summary for each category of examination and corrective action taken when unacceptable conditions were found. In addition, there is a section included for repairs and replacements required since February 13, 1989.

1.1 Class 1 Inspection

The Class 1 Inservice Inspection included examinations on the Reactor Vessel Closure Head Circumferential Weld, Reactor Vessel Head to Flange Weld, Reactor Vessel Closure Head CRDM Housing Welds. Also, Steam Generator 1B Upper and Lower Head to Tubesheet Welds, Steam Generator 1A Support Skirt to Head Weld, Letdown Cooler 1A Outlet Channel Body to End Plate Weld, and Letdown Cooler 1A Tubeside Outlet Nozzle Weld and Inside Radius Section received examinations. Dissimilar Metal Butt Welds in Reactor Coolant System were examined. Reactor Coolant Pump 1A2 Main Flange Bolts, Lower Seal Housing Bolts, and Decay Heat Emergency Dump Valves Bolting also received examinations. Pressurizer Support Lug to Shell Welds were examined. In addition, Piping Welds in Reactor Coolant, High Pressure Injection and Low Pressure Injection Systems were examined. Piping integrally-welded attachment weld of the Low Pressure Injection System was also examined.

Visual examinations were performed on the Class 1 Pressure Boundary during System Leakage Tests. Also, visual examinations were performed on Class 1 Component Supports of the High Pressure Injection and Low Pressure Injection Systems.

The Inconel 600 tubing in Steam Generators 1A and 1B was inspected by eddy current during Outage 12. The results of the inspections are shown in Section 5 of this report.

Reportable indications were found on the Class 1 Inspections shown in this section. Inspection and evaluation data for each reportable indication found on Class 1 Inspections is included in Section 5 of this report.

A detailed description of each inspection is found in the final Inservice Inspection Plan in Section 3 of this report. Results of each examination are found in Section 4.

1.2 Class 2 Inspection

The Class 2 Inspections included examinations on Steam Generator 1B Shell to Shell Weld, piping integrally-welded attachments of Main Steam, Main Feedwater, Low Pressure Injection and Reactor Building Spray Systems, and on Main Steam Stop Valve Bolting. Also included were examinations on

circumferential butt welds of the Low Pressure Injection, Reactor Building Spray and High Pressure Injection Systems. Also, Longitudinal Welds of the Reactor Building Spray and Low Pressure Injection Systems were examined.

Visual examinations were performed on the Class 2 Pressure Boundary during system functional tests. Also, visual examinations were performed on Class 2 Components of the Main Steam, Main Feedwater, Auxiliary Feedwater, High Pressure Injection, Low Pressure Injection and Reactor Building Spray Systems.

A detailed description of each inspection is found in the final Inservice Inspection Plan in Section 3 of this report. Results of each examination are found in Section 4.

1.3 Augmented Inspection

There were no augmented inspections performed at Oconee 1 during Outage 12.

1.4 Alternate Examination

Alternate examination at Oconee 1 was performed on integrally-welded piping attachment for Support No. 03-0-480A-H9B (Item No. C03.040.038). A detailed description of the examination is found in the final Inservice Inspection Plan in Section 3 of this report. Results are found in Section 4.

1.5 Identification Numbers

Owner: Duke Power Company, 422 S Church St., Charlotte, NC 28201
Plant: Oconee Nuclear Station, Highway 130/183, Seneca, SC 29679
Plant Unit: 1
Owner Certificate of Authorization: N/A
Commercial Service Date: 7-15-73

<u>Item</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
Reactor Vessel	Babcock & Wilcox	620-0003-51-52	N/A	N-101
Steam Generator A	Babcock & Wilcox	620-0003-55-1	N/A	N-103
Steam Generator B	Babcock & Wilcox	620-0003-55-2	N/A	N-104
Pressurizer	Babcock & Wilcox	620-0003-59	N/A	N-102

1.6 Authorized Nuclear Inservice Inspector(s)

Name: R. F. Elgin *R. F. Elgin*
Employer: The Hartford Steam Boiler Inspection & Insurance Company
Business Address: The Hartford Steam Boiler Inspection & Insurance Company
1117 Perimeter Center W., Suite E-301
Atlanta, GA 30338

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B02

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 CLASS 1 REPORTABLE ITEMS OUTAGE 12

PAGE 2
 DATE 08/07/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP. REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
B02.011.000	***PRESSURIZER	SHELL TO HEAD WELDS CIRCUMFERENTIAL*****	_____	***	*****	*****	____.	*****	***** *****
B02.012.000	***PRESSURIZER	WELDS***** LONGITUDINAL*****	_____	***	*****	*****	____.	*****	***** *****
B02.040.000	*****STEAM	GENERATORS TUBESHEET TO HEAD WELDS*****	_____	***	*****	*****	____.	*****	***** *****
B02.040.003	1SGB-WG58-1	OM-201-1873 ISI-OCNI-004	_____	UT	ISI-130	CS	08.500	40305	STEAM GEN 1B UPPER HEAD TO TUBESHEET PC 8 TO 51 INSP.RF#14 PER IWB-2420(B) PIR# 1-090-0052
B02.051.000	HEAT EXCHANGER	SHELL / HEAD WELDS CIRCUMFERENTIAL ****	*****	***	*****	*****	____.	_____	**** INSPECTOR TO RECORD **** ** COOLER S\N ON INSP. DATA **
B02.060.000	HEAT EXCHANGER	TUBESHEET TO SHELL** WELDS*****	_____	***	*****	*****	____.	*****	**** INSPECTOR TO RECORD **** ** COOLER S\N ON INSP. DATA **

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B16

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 CLASS 1 REPORTABLE ITEMS OUTAGE 12

PAGE 16
 DATE 08/07/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
B16.011.000	**** STEAM GENERATOR	TUBING *****		***	*****				***** STRIGHT TUBE DESIGN ***** *****
B16.011.001	1SGA-TUBES	B&W 129309E7		ET	ISI-418	INCØ	00.62 00.040	*****	* SELECT CAL. STANDARD PER VOL.1, SECT. 10.2
B16.011.002	1SGB-TUBES	B&W 129309E7		ET	ISI-418	INCØ	00.62 00.040	*****	* SELECT CAL. STANDARD PER VOL.1, SECT. 10.2

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER F1.

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 CLASS 1 REPORTABLE ITEMS OUTAGE 12

PAGE 28
 DATE 08/07/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP. REG.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./THICK	CALIB BLOCK	COMMENTS
F1.01.000	***** CLASS 1	SUPPORTS***** *****	_____	***	*****	*****	____	*****	***** *****
F1.01.083	1-51A-H7A	0-479A -----	_____	VT	QCL-14	_____	02.50	_____	HIGH PRESS INJ. - RIGID 51A-0-479A-H7A INSP.RF0#14 PER IWF-2420(B) PIR# 1-090-0046
F1.02.000	***** CLASS 2	SUPPORTS***** *****	_____	***	*****	*****	____	*****	***** *****
F1.03.000	***** CLASS 3	SUPPORTS ***** *****	_____	***	*****	_____	____	_____	***** *****

2.0 Status of Required Inspections

The completion status of inspections required by the 1980 ASME Code Section XI, including addenda through Winter 1980, is summarized in this section. The requirements are listed by the ASME Section XI examination category as defined in Table IWB-2500-1 for Class 1 Inspections, in IWC-2500-1 for Class 2 Inspections. Augmented and alternate inspections are also included.

Class 1 Inspections

<u>Section XI Category</u>	<u>Description</u>	<u>Inspections Required</u>	<u>Inspections Completed</u>	<u>Percentage Completed</u>	<u>Deferral Allowed</u>
B-A	Pressure Retaining Welds in Reactor Vessel	15 Welds	2.333 Welds	15.55%	Yes
B-B	Pressure Retaining Welds in Vessels Other than Reactor Vessel	15 Welds	9 Welds	60%	No
B-D	Full Penetration Welds of Nozzles in Vessels	60 Inspections	31 Inspections	51.66%	Partial
B-E	Pressure Retaining Partial Penetration Welds in Vessels	31 Welds	31 Welds	67% Credited	No
B-F	Pressure Retaining Dissimilar Metal Welds	38 Welds	21 Welds	55.26%	No
B-G-1	Pressure Retaining Bolting Greater than 2 Inch Diameter	425 Items	231 Items	54.35%	Yes
B-G-2	Pressure Retaining Bolting 2 Inches and Less in Diameter	*38 Connections	25 Connections	65.78%	No
B-H	Integral Attachment for Vessels	12 Attachments	7 Attachments	58.33%	No
B-J	Pressure Retaining Welds in Piping	115 Welds	72 Welds	62.60%	No

*Total connections include CRDMs that are disassembled

Class 1 Inspections (Continued)

<u>Section XI Category</u>	<u>Description</u>	<u>Inspections Required</u>	<u>Inspections Completed</u>	<u>Percentage Completed</u>	<u>Deferral Allowed</u>
B-K-1	Integral Attachments for Piping, Pumps and Valves	3 Attachments	2 Attachments	66.66%	No
B-L-1	Pressure Retaining Welds in Pump Casings	1 Weld	None	0%	Yes
B-L-2	Pump Casings	1 Casing	None	0%	Yes
B-M-1	Pressure Retaining Welds in Valve Bodies	None	N/A	N/A	N/A
B-M-2	Valve Body > 4 in. Nominal Pipe Size	2 Valves	1 Valve	50%	Yes
B-N-1	Interior of Reactor Vessel	3 Items	2 Items	66.66%	No
B-N-2	Integrally Welded Core Support Structures and Interior Attachments to Reactor Vessels	None	N/A	N/A	N/A
B-N-3	Removable Core Support Structures	1 Item	None	0%	Yes
B-O	Pressure Retaining Welds in Control Rod Housings	3 Housings	2 Housings	66.66%	Yes
B-P	All Pressure Retaining Components				No
	System Leakage Test	112 Components	93 Components	73.03%	
	System Hydrostatic Test	19 Components	0 Components	0%	
B-Q	Steam Generator Tubing	100% Station Technical Specifications Met			N/A
F1.01	Class 1 Component Supports	92 Supports	58 Supports	63.04%	No

Class 2 Inspections

<u>Section XI Category</u>	<u>Description</u>	<u>Inspections Required</u>	<u>Inspections Completed</u>	<u>Percentage Completed</u>	<u>Deferral Allowed</u>
C-A	Pressure Retaining Welds in Pressure Vessels	10 Welds	6 Welds	60%	No
C-B	Pressure Retaining Nozzle Welds in Vessels	5 Welds	3 Welds	60%	No
C-C	Integral Attachments for Vessels, Piping, Pumps and Valves	57 Attachments	37 Attachments	64.91%	No
C-D	Pressure Retaining Bolting Exceeding 2 Inches in Diameter	1 Item	1 Item	100% Credited	No
C-F	Pressure Retaining Welds in Piping	250 Welds	164 Welds	65.60%	No
C-G	Pressure Retaining Welds in Pumps and Valves	None	N/A	N/A	N/A
C-H	All Pressure Retaining Components				No
	System or Component Functional Test	34 Components	34 Components	100%	
	System Hydrostatic Test	54 Components	3 Components	5.55%	
F1.02	Class 2 Component Supports	317 Supports	210 Supports	66.24%	No

Augmented Inspections

<u>Description</u>	<u>Percentage Complete</u>
Reactor Coolant Pump Flywheels:	100% of Technical Specifications met
High Pressure Injection Nozzle Safe-ends	100% of requirements
Pressurizer Surge Piping Drain Nozzle	100% of requirements
Thermal Stress Piping	100% of requirements for Outages 11 & 12
Pressurizer Spray Piping Thermal Transient	100% of requirements

Alternate Inspections

<u>Description</u>	<u>Percentage Complete</u>
Main Feedwater Integrally- Welded Attachment (Item Number C03.040.038)	100% of requirements

3.0 Final Inservice Inspection Plan For Outage 12

The final ISI plan presented in this section lists all examinations credited for Outage 12 at Oconee Unit 1. This includes ASME Section XI Class 1 and 2, augmented and alternate inspections required by the plant technical specifications, NRC Bulletins and Problem Investigation Reports.

The information shown below is a field description for the reporting format included in this section of the report:

Item Number	=	ASME Section XI Tables IWB-2500-1 (Class 1), IWC-2500 (Class 2), IWD-2500-1 (Class 3), Augmented and Alternate Requirements
ID Number	=	Unique Identification Number
Drawing Number	=	Location and/or Detail Drawing
Locs.	=	Location
Insp. Req.	=	Examination Technique - Magnetic Particle, Dye Penetrant, etc.
Proc. Numbers	=	Examination Procedures
Material Type/Grade	=	General Description of Material
Diam./Thick	=	Diameter/Thickness
Calib. Block	=	Calibration Block
Comments	=	General and/or Detail Description

PROGRAM: NISIRUNB-QAISIO2
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B01

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 1
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP. REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./THICK	CALIB BLOCK	COMMENTS
B01.011.000	REACTOR VESSEL	CIRCUMFERENTIAL***** SHELL WELDS*****	_____	***	*****	*****	____.	****	***** *****
B01.012.000	REACTOR VESSEL	LONGITUDINAL***** SHELL WELDS*****	_____	***	*****	*****	____.	****	***** *****
B01.021.000	REACTOR VESSEL	HEAD WELDS***** CIRCUMFERENTIAL*****	_____	***	*****	*****	____.	****	***** *****
B01.021.001B	IRPV-WH5	OM-201-1122 ISI-OCN1-001	_____	UT	ISI-130	CS	07.500	40387	CLOSURE HEAD PC 23 TO 24 240 TO 0 DEGREES
B01.030.000	REACTOR VESSEL	SHELL TO FLANGE WELD *****	_____	***	*****	*****	____.	****	***** *****
B01.040.000	REACTOR VESSEL	HEAD TO FLANGE WELDS *****	_____	***	*****	*****	____.	****	***** *****
B01.040.001B	IRPV-WH7	OM-201-1122 ISI-OCN1-001	_____	UT	ISI-130	CS	07.500	40387	PC 22 TO 23 240 TO 0 DEGREES
B01.040.002B	IRPV-WH7	OM-201-1122 ISI-OCN1-001	_____	MT	NDE-25	CS	07.500	-----	PC 22 TO 23 240 TO 0 DEGREES

PROGRAM: NISIRUMB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B02

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 2
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP. REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
B02.011.000	***PRESSURIZER	SHELL TO HEAD WELDS CIRCUMFERENTIAL****	_____	***	*****	*****	_____	****	***** *****
B02.012.000	***PRESSURIZER	WELDS***** LONGITUDINAL*****	_____	***	*****	*****	_____	****	***** *****
B02.040.000	*****STEAM	GENERATORS TUBESHEET TO HEAD WELDS*****	_____	***	*****	*****	_____	****	***** *****
B02.040.003	1SGB-WG58-1	OM-201-1873 ISI-OCN1-004	_____	UT	ISI-130	CS	08.500	40305	STEAM GEN 1B UPPER HEAD TO TUBESHEET PC 8 TO 51 INSP.RF#14 PER INB-2420(B) PIR# 1-090-0052
B02.040.004	1SGB-WG58-2	OM-201-1873 ISI-OCN1-004	_____	UT	ISI-130	CS	08.500	40305	STEAM GEN 1B LOWER HEAD TO TUBESHEET PC 7 TO 50 INSP.RF#12 PER INB-2430(A)
B02.051.000	HEAT EXCHANGER	SHELL / HEAD WELDS CIRCUMFERENTIAL ****	*****	***	*****	*****	_____	_____	**** INSPECTOR TO RECORD **** ** COOLER S\N ON INSP. DATA **
B02.051.002	1-LDCA-OUT-V6	OM-201-2933	_____	UT	ISI-120	SS	08.62 00.875	40411	LDC-A OUT.CHNL.BODY TO END PLT PC.3 TO 4,INSPECTOR RECORD S\N
B02.060.000	HEAT EXCHANGER	TUBESHEET TO SHELL** WELDS*****	_____	***	*****	*****	_____	****	**** INSPECTOR TO RECORD **** ** COOLER S\N ON INSP. DATA **

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B03

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 3
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP. REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./THICK	CALIB BLOCK	COMMENTS
B03.090.000	REACTOR VESSEL	NØZZLE TØ VESSEL**** WELDS*****	_____	***	*****	_____	____.	_____	***** *****
B03.100.000	REACTOR VESSEL	*****NØZZLE INSIDE RADIUS SECTION*****	_____	***	*****	*****	____.	*****	***** *****
B03.110.000	***PRESSURIZER	NØZZLE TØ VESSEL**** WELDS*****	_____	***	*****	*****	____.	*****	***** *****
B03.120.000	***PRESSURIZER	NØZZLE INSIDE RADIUS SECTION*****	_____	***	*****	*****	____.	*****	***** *****
B03.130.000	*****STEAM	GENERATOR NØZZLE TØ VESSEL WELDS*****	_____	***	*****	*****	____.	*****	***** *****
B03.140.000	*****STEAM	GENERATOR NØZZLE INSIDE RADIUS*****	_____	***	*****	*****	____.	*****	***** *****
B03.150.000	HEAT EXCHANGER	NØZZLE TØ VESSEL WELDS*****	_____	***	*****	*****	____.	*****	*** INSPECTØR TØ RECORD *** ** COØLER S\N ØN INSP. DATA **
B03.150.002	1-LDCA-ØUT-V2	ØM-201-2933	_____	UT	ISI-120	SS	Ø3.00 ØØ.875	4Ø411	LDC-A TUBESIDE ØUT.NØZ. PC.5 TØ 3, INSPECTØR RECORD S\N

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B03

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 4
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP. REQ. NUMBERS	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./THICK	CALIB BLOCK	COMMENTS
B03.160.000	HEAT EXCHANGER	NOZZLE INSIDE RADIUS SECTION*****	_____	***	*****	*****	____	*****	**** INSPECTOR TO RECORD **** ** COOLER S\N ON INSP. DATA **
B03.160.002	1-LDCA-OUT-V2	OM-201-2933	_____	UT	ISI-120	SS	03.00 00.875	40411	LDC-A OUT.NOZ. INSIDE RADIUS PC.5 TO 3,INSPECTOR RECORD S\N

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: O'CONNOR UNIT 1
 KEY: ITEM NUMBER B04

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 O'CONNOR 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 5
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP. REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./THICK	CALIB. BLOCK	COMMENTS
B04.012.000	*****PARTIAL	PENETRATION***** CRD NOZZLES*****	_____	***	*****	*****	_____	*****	INSPECT AND DOCUMENT 100 % OF NOZZLE WELDS ON NPD PROCEDURE
B04.013.000	*****PARTIAL	PENETRATION***** INSTRUMENTATION*****	_____	***	*****	*****	_____	*****	INSPECT AND DOCUMENT 100 % OF NOZZLE WELDS ON NPD PROCEDURE

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B05

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 6
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
B05.010.000	REACTOR VESSEL	NOZZLE TO SAFE END** BUTT WELDS*****	=====	***	*****	*****	---. ---	*****	NOMINAL PIPE SIZE > 4 INCH**** *****
B05.020.000	***PRESSURIZER	NOZZLE TO SAFE END** BUTT WELDS*****	=====	***	*****	*****	---. ---	*****	NOMINAL PIPE SIZE > 4 INCH**** *****
B05.021.000	***** PRESSURIZER	NOZZLE-TO-SAFE END BUTT WELDS *****	=====	***	*****	-----	---. ---	-----	NOMINAL PIPE SIZE < 4 INCHES *****
B05.050.000	CLASS 1 PIPING	DISSIMILAR METAL**** BUTT WELDS*****	=====	***	*****	*****	---. ---	*****	NOMINAL PIPE SIZE 4 IN. & OVER *****
B05.050.003	1PIA2-7	OM-201-1845 ISI-OCN1-008	=====	UT	ISI-119 ISI-120	CS/SS	33.50 03.000	40350	A2 SUCT PUMP SAFE END TO PIPE UT FROM PIPE SIDE
B05.050.003A	1PIA2-7	OM-201-1845 ISI-OCN1-008	=====	UT	ISI-119	CS/SS	33.50 03.000	40397	A2 SUCT PUMP SAFE END TO PIPE UT FROM SAFE END SIDE
B05.050.003B	1PIA2-7	OM-201-1845 ISI-OCN1-008	=====	PT	NDE-35	CS/SS	33.50 03.000	-----	A2 SUCTION PUMP SAFE END TO PIPE PC 210 TO 215
B05.050.004	1PDA2-2	OM-201-1844 ISI-OCN1-012	=====	UT	ISI-119 ISI-120	CS/SS	33.50 03.000	40350	A2 DISCH. PUMP SAFE END TO ELBOW UT FROM ELBOW SIDE

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B05

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 7
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
B05.050.004A	1PDA2-2	OM-201-1844 ISI-OCN1-012	_____	UT	ISI-119	CS/SS	33.50 03.000	40397	A2 DISCH. PUMP SAFE END TO ELBOW UT FROM SAFE END SIDE
B05.050.004B	1PDA2-2	ISI-OCN1-012 OM-201-1844	_____	PT	NDE-35	SS/CS	33.50 03.000	-----	A2 DISCHARGE PUMP SE TO ELBOW PC 212 TO 213
B05.050.012	1PHA-17	ISI-OCN1-005	_____	UT	ISI-119	CS/IN	10.00 01.000	40399	SURGE NOZ. SE, UT NOZ. SIDE INSP. WITH B05.050.009
B05.050.012A	1PHA-17	ISI-OCN1-005	_____	UT	ISI-119	CS/IN	10.00 01.000	40399	SURGE NOZ. SE, UT PIPE SIDE INSP. WITH B05.050.009A
B05.050.012B	1PHA-17	ISI-OCN1-005	_____	PT	NDE-35	CS/IN	10.00 01.000	_____	SURGE NOZ. SAFE END INSP. WITH B05.050.009B
B05.051.000	CLASS 1 PIPING	DISSIMILAR METAL**** BUTT WELDS*****	_____	***	*****	*****	_____ _____	*****	NOMINAL PIPE SIZE < 4 INCH**** *****

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B06

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 8
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP. REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./THICK	CALIB BLOCK	COMMENTS
B06.010.000	REACTOR VESSEL	CLOSURE HEAD NUTS*** *****	_____	***	*****	*****	____.	****	*****
B06.030.000	REACTOR VESSEL	CLOSURE STUDS***** *****	_____	***	*****	*****	____.	****	WHEN REMOVED*****
B06.040.000	REACTOR VESSEL	THREADS IN FLANGE*** *****	_____	***	*****	*****	____.	****	*****
B06.050.000	REACTOR VESSEL	CLOSURE WASHERS AND* BUSHINGS*****	_____	***	*****	*****	____.	****	*****
B06.060.000	***PRESSURIZER	BOLTING***** *****	_____	***	*****	*****	____.	****	*****
B06.070.000	***PRESSURIZER	FLANGE SURFACES***** *****	_____	***	*****	*****	____.	****	INSPECT WHEN CONNECTION DISASSEMBLED
B06.080.000	***PRESSURIZER	NUTS, BUSHINGS, AND WASHERS*****	_____	***	*****	*****	____.	****	*****
B06.180.000	*CLASS 1 PUMPS	BOLTS AND STUDS***** *****	_____	***	*****	*****	____.	****	GREATER THAN 2 INCH*****

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B06

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 9
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
B06.180.002	1RCP-1A2-F	OM-201D-34		UT	NDE-44	CS	04.32 28.000	40363	A2 RC PUMP MN FLG BOLTS PC. 19 TOTAL 24 BOLTS
B06.190.000	*CLASS 1 PUMPS	FLANGE SURFACE***** *****		***	*****	*****		*****	WHEN CONNECTION DISASSEMBLED** *****
B06.200.000	*CLASS 1 PUMPS	NUTS, BUSHINGS, AND WASHERS*****		***	*****	*****		*****	***** *****

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B07

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 10
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	INSP LOCS.	PROC. REQ.	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
B07.020.000	***PRESSURIZER	BOLTS,STUDS,AND NUTS *****	___	***	*****	___	****	*****
B07.030.000	*****STEAM	GENERATOR***** BOLTS,STUDS,AND NUTS	___	***	*****	___	****	*****
B07.060.000	*CLASS 1 PUMPS	BOLTS,STUDS,AND NUTS *****	___	***	*****	___	****	*****
B07.060.002	1RCP-1A2-S	OM-201D-34 -----	___	VT1	QCL-13	02.00 08.000	----	PC. 26 LWR SEAL HOUSING BOLTS 12 CAP SCREWS
B07.070.000	CLASS 1 VALVES	BOLTS,STUDS,AND NUTS *****	___	***	*****	___	****	*****
B07.070.017	1-53A-LP104	OM-245-1255 -----	___	VT1	QCL-13	03.00	----	DECAY HEAT EMERGENCY DUMP , VLV. LP-104 BOLTING
B07.070.018	1-53A-LP103	OM-245-755 -----	___	VT1	QCL-13	03.00	----	DECAY HEAT EMERGENCY DUMP , VLV. LP-103 BOLTING
B07.080.000	**CRD HOUSINGS	BOLTS,STUDS,AND NUTS *****	___	***	*****	___	****	INSPECT ONLY IF HOUSING IS**** DISASSEMBLED*****

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B08

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 11
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
B08.020.000	***PRESSURIZER	INTEGRALLY WELDED*** ATTACHMENTS*****	_____	***	*****	*****	_____ _____	****	***** *****
B08.020.005	1PZR-WP82-Z	OM-201-637 ISI-OCN1-002	_____	MT	NDE-25	CS	03.500	----	PZR SUPPORT LUG Z-AXIS
B08.020.006	1PZR-WP82-ZW	OM-201-637 ISI-OCN1-002	_____	MT	NDE-25	CS	03.500	----	PZR SUPPORT LUG Z-W AXIS
B08.030.000	STEAM GEN.	***INTEGRALLY WELDED ATTACHMENTS*****	_____	***	*****	*****	_____ _____	****	***** *****
B08.030.001	1SGA-WG57	OM-201-1876 ISI-OCN1-003	_____	MT	NDE-25	CS	09.000	----	1A SG SUPPORT SKIRT TO HEAD PC 95 TO 07

PROGRAM: NISIRLNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B09

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 12
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
B09.011.000	*****	PIPING CIRCUMFERENTIAL***** WELDS*****		***	*****	*****	. . .	*****	NOMINAL PIPE SIZE 4 IN. & OVER *****
B09.011.093	1-53A-2.2-63L	SYS 53A ISØ 2 P2		UT	ISI-120	SS	10.00 01.000	40399	CORE FLOOD A, PIPE TO ELBOW
B09.011.093A	1-53A-2.2-63L	SYS 53A ISØ 2 P2		PT	NDE-35	SS	10.00 01.000	-----	CORE FLOOD A, PIPE TO ELBOW
B09.011.098	1-53A-1.2-8L	SYS 53A ISØ 1 P2		UT	ISI-120	SS	14.00 01.250	40389	10 B SIDE CORE FLOOD (Y-AXIS) VALVE TO ELBOW
B09.011.098A	1-53A-1.2-8L	SYS 53A ISØ 1 P2		PT	NDE-35	SS	14.00 01.250	-----	10 B SIDE CORE FLOOD (Y-AXIS) VALVE TO ELBOW
B09.011.099	1-53A-1.2-6L	SYS 53A ISØ 1 P2		UT	ISI-120	SS	14.00 01.250	40389	B SIDE CORE FLOOD (Y-AXIS) PIPE TO ELBOW
B09.011.099A	1-53A-1.2-6L	SYS 53A ISØ 1 P2		PT	NDE-35	SS	14.00 01.250	-----	B SIDE CORE FLOOD (Y-AXIS) PIPE TO ELBOW
B09.011.102	1-53A-1.2-28L	SYS 53A ISØ 1 P2		UT	ISI-120	SS	10.75 01.000	40399	B SIDE CORE FLOOD

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B09

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 13
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
B09.011.102A	1-53A-1.2-28L	SYS 53A ISO 1 P2		PT	NDE-35	SS	10.75 01.000	----	B SIDE CORE FLOOD
B09.011.103	1-53A-1.2-21L	SYS 53A ISO 1 P2		UT	ISI-120	SS	10.75 01.000	40399	B SIDE CORE FLOOD
B09.011.103A	1-53A-1.2-21L	SYS 53A ISO 1 P2		PT	NDE-35	SS	10.75 01.000	----	B SIDE CORE FLOOD
B09.011.113	1-51A-05-52C	SYS 51A ISO 5		UT	ISI-120	SS	04.00 00.531	40406	1B1 HIGH PRESSURE INJECTION
B09.011.113A	1-51A-05-52C	SYS 51A ISO 5		PT	NDE-35	SS	04.00 00.531	----	1B1 HIGH PRESSURE INJECTION
B09.012.000	***** PIPING	LONGITUDINAL***** WELDS*****		***	*****	*****	---	*****	NOMINAL PIPE SIZE 4 IN. & OVER *****
B09.012.017	1PDA2-212LI	B&W 131914E6 ISI-0CN1-012		UT	ISI-182	CS	34.75 03.000	40350	A2 LONG SEAM PC 212R TO 212L SEE REQUEST FOR RELIEF ONS-003
B09.012.017A	1PDA2-212LI	OM-201-1844 ISI-0CN1-012		MT	NDE-25	CS	34.75 03.000	----	A2 DISCHARGE INSIDE LONG SEAM PC 212R TO 212L

PROGRAM: NISIRUNB-QAISIO2
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B09

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 14
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM. THICK	CALIB BLOCK	COMMENTS
B09.012.018	1PDA2-212LØ	B&W 131914E6 ISI-ØCN1-012	_____	UT	ISI-182	CS	34.75 03.000	40350	A2 LONG SEAM PC 212L TO 212R SEE REQUEST FOR RELIEF ONS-003
B09.012.018A	1PDA2-212LØ	ØM-201-1844 ISI-ØCN1-012	_____	MT	NDE-25	CS	34.75 03.000	-----	A2 DISCHARGE OUTSIDE LONG SEAM PC 212L TO 212R
B09.021.000	***** PIPING	CIRCUMFERENTIAL***** WELDS*****	_____	***	*****	*****	_____	*****	NOMINAL PIPE SIZE ***** 4 IN. & SMALLER *****
B09.021.008	1-51A-11-87	SYS 51A ISØ 11.3	_____	PT	NDE-35	SS	02.50 00.375	-----	SELECTION CRITERIA 4.2.1
B09.021.009A	1-51A-11-89	SYS 51A ISØ 11.3	_____	PT	NDE-35	SS	02.50 00.375	-----	SELECTION CRITERIA 4.2.1
B09.021.051	1-51A-05-71C	SYS 51A ISØ 5 PØ-101B-1	_____	PT	NDE-35	SS	02.50 00.375	-----	1B1 HIGH PRESSURE INJECTION
B09.021.052	1-51A-05-65C	SYS 51A ISØ 5 PØ-101B-1	_____	PT	NDE-35	SS	02.50 00.375	-----	1B1 HIGH PRESSURE INJECTION
B09.021.053	1-51A-05-62C	SYS 51A ISØ 5 PØ-101B-1	_____	PT	NDE-35	SS	02.50 00.375	-----	1B1 HIGH PRESSURE INJECTION

PROGRAM: NISIRUMB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B09

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 15
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
B09.021.054	1-51A-05-59C	SYS 51A ISØ 5 PØ-101B-1	_____	PT	NDE-35	SS	02.50 00.375	----	1B1 HIGH PRESSURE INJECTION
B09.021.055	1-51A-05-56C	SYS 51A ISØ 5 PØ-101B-1	_____	PT	NDE-35	SS	02.50 00.375	----	1B1 HIGH PRESSURE INJECTION
B09.021.072	1-51A-136-01A	SYS 51A ISØ 136	_____	PT	NDE-35	SS	03.00 00.438	----	
B09.021.074	1-51A-136-03	SYS 51A ISØ 136	_____	PT	NDE-35	SS	03.00 00.438	----	
B09.031.000	***** BRANCH PIPE	CONNECTION WELDS *** *****	_____	***	*****	*****	____	****	NOMINAL PIPE SIZE ***** 4 INCHES & OVER *****
B09.032.000	***** BRANCH PIPE	CONNECTION WELDS *** *****	_____	***	*****	*****	____	****	NOMINAL PIPE SIZE ***** LESS THAN 4 INCHES *****
B09.040.000	***** SOCKET WELDS	***** *****	_____	***	*****	*****	____	****	***** *****

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B10

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 16
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
B10.010.002	1-53A-H1B	0-479A		PT	NDE35	SS	01.500		C.F.T.1B-SPRING 53A-0-479A-H1B D.E. STRESS CALC. OSC-1299-06

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: O'CONNOR UNIT 1
 KEY: ITEM NUMBER B12

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 O'CONNOR 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 17
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
B12.010.000	CLASS 1 PUMPS	CASING WELDS***** *****	_____	***	*****	*****	____.	****	***** *****
B12.020.000	CLASS 1 PUMP	CASINGS***** *****	_____	***	*****	*****	____.	****	***** *****
B12.040.000	CLASS 1 VALVE	BODIES EXCEEDING*** 4 INCH NPS*****	_____	***	*****	*****	____.	****	INSPECT IF DISASSEMBLED *****

PROGRAM: NISIRUMB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B13

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 18
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
B13.010.000	REACTOR VESSEL	VESEL INTERIOR**** *****	_____	***	*****	*****	_____	*****	***** *****

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B14

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 19
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
B14.010.000	REACTOR VESSEL	CRD HOUSING WELDS*** *****		***	*****	*****		****	INSPECT IF DISASSEMBLED *****
B14.010.002	IRPV-CRD-66WH9	B&W 128720E14 OM-201-2186		PT	NDE-35	SS/IN	04.06 00.650	----	CRDM HOUSING BODY TO ADAPTER MK-67 TO MK-55
B14.010.005	IRPV-CRD-66W60	B&W 128720E14 DPS 706599-1056		PT	NDE-35	CS/SS	05.00 00.500	----	CRDM BASE TO MOTOR TUBE
B14.010.008	IRPV-CRD-66	B&W 128720E14 DPS 706599-1056		PT	NDE-35	CS/SS	04.30 00.400	----	CRDM MOTOR TUBE TO EXTENSION
B14.010.011	IRPV-CRD-66W61	B&W 128720E14 DPS 706605-1058		PT	NDE-35	SS	04.19 00.380	----	PERIPHERAL CRDM EXTENSION TO CAP

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B15

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 20
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
B15.010.000	REACTOR VESSEL	PRESSURE RETAINING** BOUNDARY*****	_____	***	*****	*****	___	*****	***** *****
B15.010.001	1RPV-LK TEST	ØFD-100A-1.1 -----	_____	VIS	ISI-350	-----	___	-----	RX VESSEL SYS. LEAK TEST ALT. EXAM QCL-15 VT2 MAY BE USED
B15.011.000	REACTOR VESSEL	PRESSURE RETAINING** BOUNDARY*****	_____	***	*****	*****	___	*****	***** *****
B15.020.000	***PRESSURIZER	PRESSURE RETAINING** BOUNDARY*****	_____	***	*****	*****	___	*****	***** *****
B15.020.001	1PZR-LK TEST	ØFD-100A-1.2 -----	_____	VIS	ISI-350	-----	___	-----	PRESS. SYSTEM LEAK TEST ALT. EXAM QCL-15 VT2 MAY BE USED
B15.021.000	***PRESSURIZER	PRESSURE RETAINING** BOUNDARY*****	_____	***	*****	*****	___	*****	***** *****
B15.030.000	*****STEAM	GENERATORS PRESSURE* RETAINING BOUNDARY**	_____	***	*****	*****	___	*****	***** *****
B15.030.001	1SGA-LK TEST	ØFD-100A-1.1 -----	_____	VIS	ISI-350	-----	___	-----	STEAM GEN. A SYS LEAK TEST ALT. EXAM QCL-15 VT2 MAY BE USED

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B15

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 21
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP. REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./THICK	CALIB BLOCK	COMMENTS
B15.030.002	1SGB-LK TEST	ØFD-100A-1.1		VIS	ISI-350	----	..	----	STEAM GEN.B SYS LEAK TEST ALT. EXAM QCL-15 VT2 MAY BE USED
B15.031.000	*****STEAM	GENERATORS PRESSURE* RETAINING BOUNDARY**		***	*****	*****	..	*****	***** *****
B15.040.000	HEAT EXCHANGER	PRESSURE RETAINING BOUNDARY					..		***** *****
B15.040.001	1LDC1A-LK TEST	ØFD-101A-1.1		VIS	ISI-350	----	..	----	COOLER 1A SYS LEAK TEST ALT. EXAM QCL-15 VT2 MAY BE USED
B15.040.002	1LDC1B-LK TEST	ØFD-101A-1.1		VIS	ISI-350	----	..	----	COOLER 1B SYS LEAK TEST ALT. EXAM QCL-15 VT2 MAY BE USED
B15.041.000	HEAT EXCHANGER	PRESSURE RETAINING BOUNDARY					..		***** *****
B15.050.000	CLASS 1 PIPING	PRESSURE RETAINING** BOUNDARY*****		***	*****	*****	..	*****	***** *****
B15.050.001	1-ØFD-100A-1.1	ØFD-100A-1.1		VIS	ISI-350 QCL-15	----	..	----	CLASS A SYS LEAK TEST-INCLUDES DWG.NOS.0-422BB1A,1B,2,3,5,86

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B15

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 22
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
B15.050.001A	1-0FD-100A-1.2	0FD-100A-1.2	_____	VIS	ISI-350 QCL-15	_____	____.	_____	CLASS A SYS LEAK TEST-INCLUDES DWG. NO. 0-422BB-4
B15.050.002	1-0FD-101A-1.1	0FD-101A-1.1	_____	VIS	ISI-350	-----	____.	-----	CLASS A SYSTEM LEAK TEST ALT. EXAM QCL-15 VT2 MAY BE USED
B15.050.003	1-0FD-101A-1.4	0FD-101A-1.4	_____	VT2	ISI-350 QCL-15	-----	____.	-----	CLASS A SYS LEAK TEST-INCLUDES DWG NO. 0-422X-51
B15.050.004	1-0FD-102A-1.1	0FD-102A-1.1	_____	VIS	ISI-350	-----	____.	-----	CLASS A SYSTEM LEAK TEST ALT. EXAM QCL-15 VT2 MAY BE USED
B15.050.005	1-0FD-102A-1.2	0FD-102A-1.2	_____	VIS	ISI-350	-----	____.	-----	CLASS A SYSTEM LEAK TEST ALT. EXAM QCL-15 VT2 MAY BE USED
B15.050.006	1-0FD-102A-1.3	0FD-102A-1.3	_____	VIS	ISI-350	-----	____.	-----	CLASS A SYSTEM LEAK TEST ALT. EXAM QCL-15 VT2 MAY BE USED
B15.050.007	1-0FD-110A-1.1	0FD-110A-1.1	_____	VIS	ISI-350	-----	____.	-----	CLASS A SYSTEM LEAK TEST ALT. EXAM QCL-15 VT2 MAY BE USED
B15.050.009	1-0FD-110A-1.4	0FD-110A-1.4	_____	VIS	ISI-350	_____	____.	_____	CL. A SYSTEM LEAKAGE TEST ALT EXAM QCL-15 VT2 MAY BE USED

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCOONEE UNIT 1
 KEY: ITEM NUMBER B15

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCOONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 23
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./THICK	CALIB BLOCK	COMMENTS
B15.060.000	*CLASS 1 PUMPS	PRESSURE RETAINING** BOUNDARY*****		***	*****	*****	..	*****	***** *****
B15.060.001	1-RCP-1A1	OFD-100A-1.1		VIS	ISI-350	----	..	----	RCP 1A1 SYS LEAK TEST ALT. EXAM QCL-15 VT2 MAY BE USED
B15.060.002	1-RCP-1A2	OFD-100A-1.1		VIS	ISI-350	----	..	----	RCP 1A2 SYS LEAK TEST ALT. EXAM QCL-15 VT2 MAY BE USED
B15.060.003	1-RCP-1B1	OFD-100A-1.1		VIS	ISI-350	----	..	----	RCP 1B1 SYS LEAK TEST ALT. EXAM QCL-15 VT2 MAY BE USED
B15.060.004	1-RCP-1B2	OFD-100A-1.1		VIS	ISI-350	----	..	----	RCP 1B2 SYS LEAK TEST ALT. EXAM QCL-15 VT2 MAY BE USED
B15.061.000	*CLASS 1 PUMPS	PRESSURE RETAINING** BOUNDARY*****		***	*****	*****	..	*****	***** *****
B15.070.000	CLASS 1 VALVES	PRESSURE RETAINING** BOUNDARY*****		***	*****	*****	..	*****	COVERED IN B15.050.000 *****

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B16

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 24
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP. REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./THICK	CALIB BLOCK	COMMENTS
B16.011.000	**** STEAM GENERATOR	TUBING *****		***	*****				**** STRIGHT TUBE DESIGN **** *****
B16.011.001	1SGA-TUBES	B&W 129309E7		ET	ISI-418	INCO	00.62 00.040	****	* SELECT CAL. STANDARD PER VOL.1, SECT. 10.2
B16.011.002	1SGB-TUBES	B&W 129309E7		ET	ISI-418	INCO	00.62 00.040	****	* SELECT CAL. STANDARD PER VOL.1, SECT. 10.2

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER C01

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 25
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP. REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
C01.010.000	*****SHELL	CIRCUMFERENTIAL***** WELDS*****	_____	***	*****	*****	_____	*****	***** PRESSURE VESSELS ***** *****
C01.010.005	ISGB-MG8-1	OM-201-1873 ISI-OCN1-004	_____	UT	ISI-130	CS	04.188	40339	GEN B SHELL TO SHELL PC 1 TO 2
C01.020.000	*****HEAD	CIRCUMFERENTIAL***** WELDS*****	_____	***	*****	*****	_____	*****	***** PRESSURE VESSELS ***** *****
C01.030.000	*****CLASS 2	TUBESHEET TO SHELL WELDS*****	_____	***	*****	*****	_____	*****	***** PRESSURE VESSELS ***** *****

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: CCONEE UNIT 1
 KEY: ITEM NUMBER C02

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 CCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 26
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK.	CALIB BLOCK	COMMENTS
C02.010.000	***** NOZZLES	IN VESSELS ***** *****	_____	***	*****	*****	-. _	****	1/2" NOMINAL THICKNESS AND**** LESS*****
C02.021.000	*****NOZZLE	TO SHELL OR HEAD**** WELDS*****	_____	***	*****	*****	-. _	****	***** *****
C02.022.000	*****NOZZLE	INSIDE RADIUS***** SECTION*****	_____	***	*****	*****	-. _	****	***** *****

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER C03

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 27
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	INSP LOCS.	PROC. REQ. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
C03.010.000	***** PRESSURE	VESSELS INTEGRALLY** WELDED ATTACHMENTS**	_____	*** *****	*****	_____	*****	***** *****
C03.040.000	*** CLASS 2 PIPING	INTEGRALLY WELDED ** ATTACHMENTS *****	_____	*** *****	_____	_____	_____	***** *****
C03.040.017	1-01A-H9B	0-480A	_____	MT NDE-25	CS	01.750	_____	M.S.-SPRING 1-01A-0-480A-H9B D.E. STRESS CALC. OSC-1296-06
C03.040.018	1-01A-H9A	0-480A	_____	MT NDE-25	CS	01.750	_____	M.S.-SPRING 1-01A-0-480A-H9A D.E. STRESS CALC. OSC-1296-06
C03.040.037	1-03-H15B	0-481A	_____	MT NDE-25	CS	01.500	_____	M. FDWTR-SPRING 03-0-481A-H15B D.E. STRESS CALC. OSC-1297-06
C03.040.038	1-03-H9B	0-480A	_____	VT3 QCL-14	CS	01.000	_____	MAIN FDWTR-RIGID 03-0-480A-H9B REQUEST FOR RELIEF ONS-013 REQUEST FOR RELIEF ONS-0013
C03.040.050	1-53B-H17	0-436D	_____	PT NDE-35	SS	01.250	_____	LPI-SPRING 1-53B-5-0-436D-H17
C03.040.053	1-53B-R29	0-439B	_____	PT NDE-35	SS	01.000	-----	LPI - RIGID 1-53B-5-0-439B-R29

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER C03

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 28
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP PROC. REQ. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
C03.040.059	1-53B-DE062	0-435B		PT NDE-35	SS	01.000	----	LPI - RESTRAINT 1-53B-0-435B-DE062
C03.040.062	1-54A-H5	0-439C		PT NDE-35	SS	01.000	----	REACTOR BLDG. SPRAY - RIGID 1-54A-3-0-439C-H5
C03.040.065	1-54A-R6	0-436D		PT NDE-35	SS	00.750	----	R.B. SPRAY - RIGID 1-54A-3-0-436D-R6

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER C04

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 29
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
C04.040.000	***** PRESSURE	RETAINING BOLTING ** *****	*****	***	*****	*****	___	___	**** VALVE BOLTING > 2" **** *****
C04.040.001	1-01A-SV1-STUD	SYS. 01A ISO. 1.5 OM-200-195	___	UT	NDE-44	CS	02.25	40417	MAIN STEAM STOP VALVE SV1 REQUEST FOR RELIEF ONS-009

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER C05

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 30
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
C05.011.000	*** CLASS 2 PIPING	CIRCUMFERENTIAL WELD *****		***	*****	*****	--- ---	*****	NOMINAL WALL THICKNESS ***** 1/2 IN. OR LESS *****
C05.011.027	1-53B-3.1-42E	SYS 53B ISØ 3.1		PT	NDE-35	SS	06.00 00.134	----	
C05.011.034	1-53B-16-4	SYS 53B ISØ 16		PT	NDE-35	SS	08.00 00.148	----	
C05.011.035	1-53B-7.2-20KA	SYS 53B ISØ 7.2		PT	NDE-35	SS	10.00 00.165	----	TERMINAL END
C05.011.036	1-53B-7.2-11K	SYS 53B ISØ 7.2		PT	NDE-35	SS	10.00 00.165	----	
C05.011.038	1-53B-7.1-30A	SYS 53B ISØ 7.1		PT	NDE-35	SS	06.00 00.134	----	
C05.011.039	1-53B-7.1-26	SYS 53B ISØ 7.1		PT	NDE-35	SS	06.00 00.134	----	
C05.011.044	1-53B-3.4-32F	SYS 53B ISØ 3.4		PT	NDE-35	SS	10.00 00.250	----	

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER C05

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 31
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
C05.011.085B	1-53B-14-1C	SYS 53B ISØ 14	_____	PT	NDE-35	SS	12.00 00.180	-----	SELECTION CRITERIA 5.2
C05.011.086	1-53B-14-1D	SYS 53B ISØ 14	_____	PT	NDE-35	SS	08.00 00.250	-----	SELECTION CRITERIA 5.2
C05.011.087	1-53B-14-1E	SYS 53B ISØ 14	_____	PT	NDE-35	SS	12.00 00.250	-----	SELECTION CRITERIA 5.2
C05.011.093	1-53B-10-B64	SYS 53B ISØ 10	_____	PT	NDE-35	SS	12.00 00.180	-----	
C05.011.151	1-53A-2.4-78LA	SYS 53A ISØ 2.4	_____	PT	NDE-35	CS/SS	14.00 00.375	-----	TERMINAL END
C05.011.205	1-54A-1.3-15A	SYS 54A ISØ 1.3	_____	PT	NDE-35	SS	08.00 00.250	-----	TERMINAL END
C05.011.206	1-54A-3.1-2C	SYS 54A ISØ 3.1	_____	PT	NDE-35	SS	08.00 00.250	-----	
C05.011.207	1-54A-3.1-6CC	SYS 54A ISØ 3.1	_____	PT	NDE-35	SS	08.00 00.250	-----	

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER C05

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 32
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
C05.011.220	1-54A-1.1-19A	SYS 54A ISØ 1.1		PT	NDE-35	SS	10.00 00.250		
C05.011.264	1-51A-1.1-39A	SYS 51A ISØ 1.1		PT	NDE-35	SS	06.00 00.280		
C05.011.268	1-51A-1.2-43A	SYS 51A ISØ 1.2		PT	NDE-35	SS	06.00 00.280		
C05.011.271	1-51A-1.2-48A	SYS 51A ISØ 1.2		PT	NDE-35	SS	06.00 00.280		
C05.012.000	***** CLASS 2 PIPING	LONGITUDINAL WELDS * *****		***	*****	*****	..	*****	NOMINAL WALL THICKNESS ***** 1/2 IN. OR LESS *****
C05.012.021	1-54A-3.1-2CL	SYS 54A ISØ 3.1		PT	NDE-35	SS	08.00 00.250		LONG. SEAM FOR C05.011.206
C05.012.026	1-53B-10-B77L	SYS 53B ISØ 10		PT	NDE35	SS	12.00 00.180		ELL SEAM FOR C05.011.110, INSP ENTIRE LENGTH, SELECT. CRIT. 5.2
C05.021.000	***** CLASS 2 PIPING	CIRCUMFERENTIAL***** WELDS*****		***	*****	*****	..	*****	GREATER THAN 1/2 IN. ***** NOMINAL WALL THICKNESS *****

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER C05

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 33
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP. REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
C05.022.000	**** CLASS 2 PIPING	LONGITUDINAL WELDS * *****	_____	***	***** *****	_____	____	_____	GREATER THAN 1/2 IN. ***** NOMINAL WALL THICKNESS *****
C05.031.000	CLASS 2 PIPING	BRANCH CONNECTION WELDS*****	_____	***	***** *****	*****	____	*****	***** *****
C05.031.008	1-53B-6.2-26KC	SYS 53B ISO 6.2 -----	_____	PT	NDE-35	SS	06.00 00.134	-----	SELECTION CRITERIA 5.2 -----

PROGRAM: NISIRUMB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER C07

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 34
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
C07.010.000	***** PRESSURE	VESELS***** *****	_____	***	*****	*****	____	****	PRESSURE RETAINING COMPONENTS* *****
C07.020.000	*****PIPING	***** *****	_____	***	*****	*****	____	****	PRESSURE RETAINING COMPONENTS* *****
C07.020.006	1-OFD-101A-1.4	OFD-101A-1.4	_____	VT2	QCL-15 ISI-350	_____	____	_____	CLASS B HPI SYSTEM FUNCTIONAL TEST ALSO INSP. 110187 STATUS - CLR
C07.020.007	1-OFD-101A-1.3	OFD-101A-1.3	_____	VT2	QCL-15 ISI-350	_____	____	_____	CLASS B HPI SYSTEM FUNCTIONAL TEST ALSO INSP. 110187 STATUS - CLR
C07.030.000	*****PUMPS	***** *****	_____	***	*****	*****	____	****	PRESSURE RETAINING COMPONENTS* SYSTEM PRESSURE TEST*****
C07.030.004	1HPI-PUMP-1C	OFD-101A-1.3	_____	VT2	QCL-15 ISI-350	-----	____	-----	HPI PUMP 1C FUNCTIONAL TEST ALSO INSP. 110187 STATUS - CLR
C07.040.000	*****VALVES	***** *****	_____	***	*****	*****	____	****	PRESSURE RETAINING COMPONENTS COVERED IN C07.020.000 SAME AS C07.020.000 SAME AS C07.020.000

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER 001

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 35
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
D01.011.000	*****SYSTEM	INSERVICE TEST***** *****	_____	***	*****	*****	_____ _____	*****	***** *****
D01.011.015	1-0FD-135A-1.2	0FD-135A-1.2	_____	VT2	ISI-350 QCL-15	_____	_____ _____	_____	CL. C SYSTEM LEAK TEST

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER D02

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 36
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
D02.011.000	*****SYSTEM	FUNCTIONAL***** TEST*****	_____	***	*****	*****	_____ _____ _____	*****	***** ***** *****
D02.011.003	1-OFD-121A-1.7	OFD-121A-1.7 -----	_____	VT2	ISI-350 QCL-15	_____ _____ _____	_____ _____ _____	-----	CL. C SYSTEM LEAK TEST _____ _____
D02.011.004	1-OFD-121A-1.8	OFD-121A-1.8 -----	_____	VT2	ISI-350 QCL-15	_____ _____ _____	_____ _____ _____	-----	CL. C SYSTEM LEAK TEST _____ _____
D02.011.005	1-OFD-121B-1.3	OFD-121B-1.3 -----	_____	VT2	ISI-350 QCL-15	_____ _____ _____	_____ _____ _____	-----	CL. C SYSTEM LEAK TEST _____ _____
D02.011.006	1-OFD-121B-1.5	OFD-121B-1.5 -----	_____	VT2	ISI-350 QCL-15	_____ _____ _____	_____ _____ _____	-----	CL. C SYSTEM LEAK TEST _____ _____
D02.011.021	1-OFD-133A-2.5	OFD-133A-2.5 -----	_____	VT2	ISI-350 QCL-15	_____ _____ _____	_____ _____ _____	-----	CL. C SYSTEM LEAK TEST _____ _____
D02.011.023	1-OFD-133A-1.2	OFD-133A-1.2 -----	_____	VT2	ISI-350 QCL-15	_____ _____ _____	_____ _____ _____	-----	CL. C SYSTEM LEAK TEST _____ _____
D02.011.025	1-OFD-133A-1.5	OFD-133A-1.5 -----	_____	VT2	ISI-350 QCL-15	_____ _____ _____	_____ _____ _____	-----	CL. C SYSTEM LEAK TEST _____ _____

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER D02

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 37
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
D02.011.026	1-0FD-133A-2.1	0FD-133A-2.1	_____	VT2	ISI-350 QCL-15	_____	____.	-----	CL. C SYSTEM LEAK TEST
D02.011.027	1-0FD-133A-2.2	0FD-133A-2.2	_____	VT2	ISI-350 QCL-15	_____	____.	-----	CL. C SYSTEM LEAK TEST
D02.011.028	1-0FD-133A-3.2	0FD-133A-3.2	_____	VT2	ISI-350 QCL-15	_____	____.	-----	CL. C SYSTEM LEAK TEST
D02.011.029	1-0FD-133A-3.4	0FD-133A-3.4	_____	VT2	ISI-350 QCL-15	_____	____.	-----	CL. C SYSTEM LEAK TEST
D02.011.032	1-0FD-124A-1.3	0FD-124A-1.3	_____	VT2	ISI-350 QCL-15	--	____.	-----	CL. C SYSTEM LEAK TEST
D02.011.034	1-0FD-124B-1.1	0FD-124B-1.1	_____	VT2	ISI-350 QCL-15	--	____.	-----	CL. C SYSTEM LEAK TEST
D02.011.035	1-0FD-124B-2.1	0FD-124B-2.1	_____	VT2	ISI-350 QCL-15	--	____.	-----	CL. C SYSTEM LEAK TEST
D02.011.041	1-0FD-121C-1.1	0FD-121C-1.1	_____	VT2	ISI-350 QCL-15	_____	____.	-----	CL. C SYSTEM LEAK TEST

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER D02

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 38
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./THICK	CALIB BLOCK	COMMENTS
D02.011.042	1-ØFD-124C-1.2	ØFD-124C-1.2	_____	VT2	QCL-15 ISI-350	_____	____.	_____	CL. C SYSTEM LEAK TEST
D02.011.043	1-ØFD-133A-3.1	ØFD-133A-3.1	_____	VT2	QCL-15 ISI-350	_____	____.	_____	CL. C SYSTEM LEAK TEST
D02.020.000	***** CLASS 3 PIPING	INTEGRAL ATTACHMENT WELDS *****	_____	***	*****	*****	____.	*****	COMPONENT SUPPORTS ***** AND RESTRAINTS *****
D02.020.020	1-03A-SR39	0-439A	_____	VT3	QCL-14	-----	____.	-----	EMER. FDWTR - RIGID 1-03A-1-0-439A-SR39
D02.020.021	1-03A-H24	0-439A	_____	VT3	QCL-14	-----	____.	-----	EMER. FDWTR - RIGID 1-03A-1-0-439A-H24
D02.020.032	1-03A-SR75	0-401A	_____	VT3	QCL-14	-----	____.	-----	EMER. FDWTR - RIGID 1-03A-1-0-401A-SR75
D02.020.034	1-03A-H47	0-400A	_____	VT3	QCL-14	-----	____.	-----	EMER. FDWTR - RIGID 1-03A-1-0-400A-H47
D02.020.035	1-03A-SR79	0-400A	_____	VT3	QCL-14	-----	____.	-----	EMER. FDWTR - RIGID 1-03A-1-0-400A-SR79

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER D02

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 39
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ. NUMBERS	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
D02.020.036	1-03A-H48	0-400A	_____	VT3	QCL-14	-----	____	-----	EMER. FDWTR - RIGID 1-03A-1-0-400A-H48
D02.020.037	1-03A-SR80	0-400A	_____	VT3	QCL-14	-----	____	-----	EMER. FDWTR - RIGID 1-03A-1-0-400A-SR80
D02.020.062	1-03A-SR87	0-400B	_____	VT3	QCL-14	-----	____	-----	EMER. FDWTR - RIGID 1-03A-1-0-400B-SR87
D02.020.077	1-03A-H11	0-439C	_____	VT3	QCL-14	-----	____	-----	EMER. FDWTR - RIGID 1-03A-1-0-439C-H11
D02.020.082	1-03A-SR47	0-439B	_____	VT3	QCL-14	-----	____	-----	EMER. FDWTR-RIGID 1-03A-1-0-439B-SR47
D02.020.087	1-03A-H72(A)	0-439A	_____	VT3	QCL-14	-----	____	-----	EMER. FDWTR. - SPRING 1-03A-1-0-439A-H72
D02.020.096	1-03A-SR86	0-400B	_____	VT3	QCL-14	-----	____	-----	EMER. FDWTR-RIGID 1-03A-1-0-400B-SR86
D02.020.101	1-03A-H46	0-400A	_____	VT3	QCL-14	-----	____	-----	EMER. FDWTR - SPRING 1-03A-1-0-400A-H46

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER D02

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 40
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
D02.020.102	1-03A-H12	0-439C		VT3	QCL-14				EMER. FDWTR. - RIGID 1-03A-1-0-439C-H12
D02.020.107	1-03A-SR17	0-401A		VT3	QCL-14				EMER. FDWTR. - RIGID 1-03A-1-0-401A-SR17
D02.020.135	1-03A-SR18	0-401A		VT3	QCL-14				EMER. FDWTR - RIGID 1-03A-1-0-401A-SR18
D02.030.000	*****INTEGRAL	ATTACHMENT***** *****		***	*****	*****		*****	MECHANICAL&HYDRAULIC SNUBBERS *****
D02.030.001	1-01A-R6	0-403C		VT3	QCL-14	-----		-----	STEAM SUPPLY - SNUBBER 1-01A-4-1-0-403C-R6
D02.040.000	*****INTEGRAL	ATTACHMENT***** *****		***	*****	*****		*****	SPRING TYPE SUPPORTS***** *****
D02.060.000	*****INTEGRAL	ATTACHMENT***** *****		***	*****	*****		*****	SHOCK ABSORBERS***** *****

PROGRAM: NISIRUNB-QAISIO2
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER D03

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 41
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
D03.011.000	*****SYSTEM	INSERVICE TEST***** *****	_____	***	*****	*****	_____	*****	***** *****
D03.011.001	1-0FD-104A-1.1	0FD-104A-1.1	_____	VT2	ISI-350 QCL-15	_____	_____	-----	CL. C SYSTEM LEAK TEST

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER E01

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 42
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	INSP LOCS.	PROC. REQ.	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
E01.001.000	REACTOR COOL. PUMP	FLYWHEEL INSPECTION *****	___	*** *****	*****	___	*****	***** *****
E01.001.004	1RCP-1B2	OM-201D-38	___	UT ISI-117	CS	72.00 09.500	----	RC PUMP 1B2 FLYWHEEL ----- BASELINE RFO # 12
E01.001.004A	1RCP-1B2	OM-201D-38	___	MT NDE-25	CS	72.00 09.500	----	RC PUMP 1B2 FLYWHEEL MT INSP. WHEN FLYWHEEL REMOVED ----- BASELINE RFO # 12

PROGRAM: NISIRUNB-QAISIO2
FILE: C007133
PLANT: OCONEE UNIT 1
KEY: ITEM NUMBER E04

DUKE POWER COMPANY
QUALITY ASSURANCE DEPARTMENT
PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 43
DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
E04.001.000	**HPI SAFE END	EXAMINATIONS***** *****	_____	***	*****	*****	_____	_____	***** ***** *****

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER F1.

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 44
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
F1.01.000	***** CLASS 1	SUPPORTS***** *****		***	*****	*****	. . .	*****	***** *****
F1.01.069	1-51A-H8C	0-478A		VT	QCL-14		02.50		HIGH PRESS INJ. - RIGID 51-0-478A-H8C INSP.RF0#12 PER IWF-2430(A)
F1.01.074	1-51A-H5C	0-478A		VT	QCL-14		02.50		HIGH PRESS INJ. - RIGID 51A-0-478A-H5C INSP.RF0#12 PER IWF-2430(A)
F1.01.076	1-51A-H7C	0-478A		VT	QCL-14		02.50		HIGH PRESS INJ. - RIGID 51A-0-478A-H7C INSP.RF0#12 PER IWF-2430(A)
F1.01.078	1-51A-H2A	0-479A		VT	QCL-14		02.50		HIGH PRESS INJ. - RIGID 51A-0-479A-H2A INSP.RF0#12 PER IWF-2430(A)
F1.01.079	1-51A-H3A	0-479A		VT	QCL-14		02.50		HIGH PRESS INJ. - RIGID 51A-0-479A-H3A
F1.01.080	1-51A-H4A	0-479A		VT	QCL-14		02.50		HIGH PRESS INJ. - RIGID 51A-0-479A-H4A
F1.01.081	1-51A-H5A	0-479A		VT	QCL-14		02.50		HIGH PRESS INJ. - RIGID 51A-0-479A-H5A

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER F1.

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 45
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
F1.01.082	1-51A-H6A	0-479A		VT	QCL-14		02.50		HIGH PRESS INJ. - RIGID 51A-0-479A-H6A
F1.01.083	1-51A-H7A	0-479A		VT	QCL-14		02.50		HIGH PRESS INJ. - RIGID 51A-0-479A-H7A INSP.RF0#14 PER IWF-2420(B) PIR# 1-090-0046
F1.01.084	1-51A-H8A	0-479A		VT	QCL-14		02.50		HIGH PRESS INJ. - RIGID 51A-0-479A-H8A INSP.RF0#12 PER IWF-2430(A)
F1.01.085	1-51A-H9A	0-479A		VT	QCL-14		02.50		HIGH PRESS INJ. - RIGID 51A-0-479A-H9A INSP.RF0#12 PER IWF-2430(A)
F1.01.087	1-51A-H12A	0-479A		VT	QCL-14		02.50		HIGH PRESS INJ. - RIGID 51A-0-479A-H12A
F1.01.088	1-51A-H13A	0-479A		VT	QCL-14		02.50		HIGH PRESS INJ. - RIGID 51A-0-479A-H13A
F1.01.091	1-51A-H16A	0-479A		VT	QCL-14		02.50		HIGH PRESS INJ. - RIGID 51A-0-479A-H16A INSP.RF0#12 PER IWF-2430(A)
F1.01.092	1-51A-H10A	0-479A		VT	QCL-14		02.50		HIGH PRESS INJ. - RIGID 51A-0-479A-H10A INSP.RF0#12 PER IWF-2430(A)

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER F1.

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 46
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
F1.01.150	1-53A-H8A	0-478A	_____	VT	QCL-14	-----	14.00	-----	LOW PRESS INJ. - SPRING 53A-0-478A-H8A
F1.01.164	1-53A-H35C	0-481A	_____	VT	QCL-14	_____	01.50	_____	LOW PRESS INJ. - RIGID 53A-0-481A-H35C
F1.01.165	1-53A-H36C	0-481A	_____	VT	QCL-14	_____	01.50	_____	LOW PRESS INJ. - RIGID 53A-0-481A-H36C
F1.01.166	1-53A-H37C	0-481A	_____	VT	QCL-14	_____	01.50	_____	LOW PRESS INJ. - RIGID 53A-0-481A-H37C
F1.01.171	1-53A-H4A	0-478A	_____	VT	QCL-14	_____	10.00	_____	LOW PRESS INJ. -RIGID 53A-0-478A-H4A
F1.02.000	***** CLASS 2 SUPPORTS*****		_____	***	*****	*****	_____	*****	*****
F1.02.017	1-01A-DE006	0-550	_____	VT	QCL-14	_____	36.00	-----	MAIN STEAM A - SNUBBER I-01A-0-550-DE006 (N.R.REQ.)
F1.02.018	1-01A-R2	0-550	_____	VT	QCL-14	_____	36.50	-----	MAIN STEAM A - HYD SNUBBER I-01A-0-550-R2

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER F1.

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 47
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
F1.02.037	1-01A-H2B	0-481A		VT	QCL-14	-----	26.18	-----	MAIN STEAM B - RIGID 01A-0-481A-H2B
F1.02.070	1-01A-H22(A)	0-401A		VT	QCL-14	-----	12.00	-----	MAIN STEAM B - SPRING 1-01A-401A-EM0-H22
F1.02.117	1-03-H62	0-439B		VT	QCL-14	-----	24.00	-----	MAIN FDWTR A-RIGID 1-03-0-439B-H62
F1.02.136	1-03-H5B	0-479A		VT	QCL-14	-----	24.00	-----	MAIN FDWTR B - RIGID 03-0-479A-H5B
F1.02.140	1-03-H9B	0-480A		VT	QCL-14	-----	24.00	-----	MAIN FDWTR B - RIGID 03-0-480A-H9B
F1.02.142	1-03-H5A	0-480A		VT	QCL-14	-----	20.00 04.000	-----	MAIN FDWTR A-RIGID 03-0-480A-H5A
F1.02.209	1-03A-H71	0-437A		VT	QCL-14	-----	06.00	-----	EMER. FDWTR B - SPRING 1-03A-1-0-437A-H71
F1.02.251	1-51A-DE064	0-435C		VT	QCL-14	-----	06.00	-----	HPI - SWAY STRUT 1-51A-0-435C-DE064

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER F1.

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 48
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
F1.02.285	1-53B-DE050	0-438B		VT	QCL-14	-----	12.00	-----	DECAY HEAT - RIGID 1-53B-0-438B-DE050
F1.02.286	1-53B-H25	0-437B		VT	QCL-14	-----	12.00	-----	DECAY HEAT - RIGID 1-53B-3-0-437B-H25
F1.02.287	1-53B-0279	0-437B		VT	QCL-14	-----	12.00	-----	DECAY HEAT - SWAY STRUT 1-53B-0-437B-ARM-0279
F1.02.288	1-53B-DE052	0-437B		VT	QCL-14	-----	12.00	-----	DECAY HEAT - SWAY STRUT 1-53B-0-437B-DE052
F1.02.291	1-53B-R3	0-444		VT	QCL-14	-----	12.00	-----	DECAY HEAT - ANCHOR 1-53B-3-0-444-R3
F1.02.305	1-53A-DE078	0-436D		VT	QCL-14	-----	10.00	-----	DECAY HEAT - RIGID 1-53A-436D-DE078
F1.02.306	1-53B-R2401	0-436D		VT	QCL-14	-----	10.00	-----	DECAY HEAT-RIGID 1-53B-0-436D-DJB-R2401
F1.02.307	1-53B-H23	0-436D		VT	QCL-14	-----	10.00	-----	DECAY HEAT - SPRING 1-53B-5-0-436D-H23

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER F1.

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 49
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
F1.02.308	1-53B-R5	0-436B	_____	VT	QCL-14	-----	10.00	-----	DECAY HEAT - SMAY STRUT 1-53B-5-0-436B-R5
F1.02.343	1-53B-2601	0-439B	_____	VT	QCL-14	-----	10.00	-----	DECAY HEAT - RIGID 1-53B-439B-RTB-2601
F1.02.344	1-53B-2602	0-439B	_____	VT	QCL-14	-----	10.00	-----	DECAY HEAT - RIGID 1-53B-439B-RTB-2602
F1.02.345	1-53B-R29	0-439B	_____	VT	QCL-14	-----	10.00	-----	DECAY HEAT - RIGID 1-53B-5-0-439B-R29
F1.02.346	1-53B-H57	0-439B	_____	VT	QCL-14	-----	10.00	-----	DECAY HEAT - SPRING 1-53B-5-0-439B-H57
F1.02.347	1-53B-H58A	0-439A	_____	VT	QCL-14	-----	10.00	-----	DECAY HEAT - SPRING 1-53B-0-439A-H58A
F1.02.348	1-53B-H17	0-436D	_____	VT	QCL-14	-----	10.00	-----	DECAY HEAT - SPRING 1-53B-5-0-436D-H17
F1.02.392	1-53B-H3	0-436E	_____	VT	QCL-14	-----	14.00	-----	DECAY HEAT - RIGID 1-53B-2-0-436E-H3 INSP.RF0#10 PER IMF-2430(A)

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER F1.

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 50
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
F1.02.393	1-53B-H1	0-436E	_____	VT	QCL-14	-----	14.00	-----	DECAY HEAT - RIGID 1-53B-2-0-436E-H1
F1.02.394	1-53B-DE068	0-435B	_____	VT	QCL-14	-----	08.00	-----	DECAY HEAT - RIGID 1-53B-0-435B-DE068 INSP.RFO#10 PER IWF-2430(A)
F1.02.396	1-53B-DE069	0-435B	_____	VT	QCL-14	-----	08.00	-----	DECAY HEAT - RIGID 1-53B-0-435B-DE069 INSP.RFO#10 PER IWF-2430(A)
F1.02.404	1-53B-H12	0-435B	_____	VT	QCL-14	-----	14.00	-----	DECAY HEAT - SPRING 1-53B-4-0-435B-H12 INSP.RFO#10 PER IWF-2430(A)
F1.02.405	1-53A-H3B	0-478A	_____	VT	QCL-14	-----	14.00	-----	CORE FLOOD-RIGID 53A-0-478A-H3B
F1.02.406	1-53A-H5A	0-479A	_____	VT	QCL-14	-----	12.00	-----	DECAY HEAT-SNUBBER 53A-0-479A-H5A
F1.02.453	1-54A-H35	0-435B	_____	VT	QCL-14	-----	10.00	-----	REACTOR BLDG. SPRAY-RIGID 1-54A-1-0-435B-H35
F1.02.460	1-54A-DE014	0-435B	_____	VT	QCL-14	-----	08.00	-----	REACTOR BLDG. SPRAY - RIGID 1-54A-0-435B-DE014

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER F1.

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 51
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
F1.02.461	1-54A-DE015	0-435B		VT	QCL-14		08.00		REACT. BLDG. SPRAY-MECH. SNUBB 1-54A-0-435B-DE015
F1.02.463	1-54A-DE016	0-435B		VT	QCL-14		08.00		REACTOR BLDG. SPRAY-SWAY STRUT 1-54A-0-435B-DE016
F1.02.472	1-54A-R6	0-436D		VT	QCL-14		08.00		REACTOR BUILDING SPRAY-RIGID 1-54A-3-0-436D-R6
F1.02.475	1-54A-R19	9-439A		VT	QCL-14		08.00		REACTOR BUILDING SPRAY-ANCHOR 1-54A-0-439A-R19
F1.02.500	1-54A-R21	0-439A		VT	QCL-14		08.00		R.B. SPRAY - RIGID 1-54A-0-439A-R21
F1.02.502	1-54A-R22	0-444		VT	QCL-14		08.00		REACTOR BLDG. SPRAY - ANCHOR 1-54A-3-0-444-R22
F1.02.503	1-54A-H5	0-439C		VT	QCL-14		08.00		REACTOR BLDG. SPRAY - RIGID 1-54A-3-0-439C-H5
F1.03.000	***** CLASS 3	SUPPORTS *****		***	*****				***** *****

PROGRAM: NISIRUNB-QAISIO2
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER F1.

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 52
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
F1.03.001	1-01A-H1	0-401A	_____	VT	QCL-14	-----	06.00	-----	STEAM SUPPLY - SPRING 1-01A-4-1-0-401A-H1
F1.03.002	1-01A-H2	0-401A	_____	VT	QCL-14	-----	06.00	-----	STEAM SUPPLY - SPRING 1-01A-4-1-0-401A-H2
F1.03.003	1-01A-R6	0-403C	_____	VT	QCL-14	-----	06.00	-----	STEAM SUPPLY - MECH. SNUBBER 1-01A-4-1-0-403C-R6
F1.03.058	1-03-H54	0-439B	_____	VT	QCL-14	-----	24.00	-----	MAIN FDWTR - RIGID 1-03-0-439B-H54
F1.03.064	1-03-H60	0-551	_____	VT	QCL-14	-----	24.00	-----	MAIN FDWTR - RIGID 1-03-0-551-H60
F1.03.118	1-03A-SR47	0-439B	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR. - RIGID 1-03A-1-0-439B-SR47
F1.03.120	1-03A-SR39	0-439A	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR. - SHAY STRUT 1-03A-1-0-439A-SR39
F1.03.121	1-03A-H24	0-439A	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR. - RIGID 1-03A-1-0-439A-H24

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER F1.

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 53
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	INSP LOCS.	PROC. REQ.	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
F1.03.122	1-03A-H25	0-439A	VT	QCL-14	-----	06.00	-----	EMER. FDWTR. - RIGID 1-03A-1-0-439A-H25
F1.03.150	1-03A-H72 (A)	0-439A	VT	QCL-14	-----	06.00	-----	EMER. FDWTR. - SPRING 1-03A-1-0-439A-H72
F1.03.151	1-03A-H70	0-439A	VT	QCL-14	-----	06.00	-----	EMER. FDWTR. - SHAY STRUT 1-03A-1-0-437A-H70
F1.03.152	1-03A-SR62	0-437A	VT	QCL-14	-----	06.00	-----	EMER. FDWTR. - H.S.S SUPP. 1-03A-1-0-437A-SR62
F1.03.175	1-03A-H78	0-439B	VT	QCL-14	-----	06.00	-----	EMER. FDWTR - SPRING 1-03A-1-0-439B-H78
F1.03.176	1-03A-SR64	0-439B	VT	QCL-14	-----	06.00	-----	EMER. FDWTR - H.S.S SUPP. 1-03A-1-0-439B-SR64
F1.03.207	1-03A-SR86	0-400B	VT	QCL-14	-----	06.00	-----	EMER. FDWTR. - RIGID 1-03A-1-0-400B-SR86
F1.03.231	1-03A-SR75	0-401A	VT	QCL-14	-----	06.00	-----	EMER. FDWTR - RIGID 1-03A-1-0-401A-SR75

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER F1.

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 54
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM. THICK	CALIB BLOCK	COMMENTS
F1.03.237	1-03A-H46	0-400A	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR. - SPRING 1-03A-1-0-400A-H46
F1.03.238	1-03A-SR52	0-400A	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR - HYD. S.S. SUPP. 1-03A-1-0-400A-SR52
F1.03.239	1-03A-H47	0-400A	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR - RIGID 1-03A-1-0-400A-H47
F1.03.240	1-03A-SR79	0-400A	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR - RIGID 1-03A-1-0-400A-SR79
F1.03.241	1-03A-H48	0-400A	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR - RIGID 1-03A-1-0-400A-H48
F1.03.242	1-03A-SR80	0-400A	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR - RIGID 1-03A-1-0-400A-SR80
F1.03.314	1-03A-DE031	0-401A	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR - RIGID 1-03A-401A-DE031
F1.03.323	1-03A-SR17	0-401A	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR - RIGID 1-03A-1-0-401A-SR17

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER F1.

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 55
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
F1.03.324	1-03A-SR18	0-401A	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR. - RIGID 1-03A-1-0-401A-SR18
F1.03.358	1-03A-SR87	0-400B	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR - RIGID 1-03A-1-0-400B-SR87
F1.03.367	1-03A-H144	0-400A	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR - RIGID 1-03A-1-0-400A-H144
F1.03.371	1-03A-H149	0-400B	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR - RIGID 1-03A-1-0-400B-H149
F1.03.372	1-03A-H131	0-400B	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR - SWAY STRUT 1-03A-1-0-400B-H131
F1.03.388	1-03A-H189	0-400A	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR - RIGID 1-03A-1-0-400A-H189
F1.03.389	1-03A-H188	0-400A	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR - SWAY STRUT 1-03A-1-0-400A-H188
F1.03.390	1-03A-SR36	0-400A	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR - RIGID 1-03A-1-0-400A-SR36

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER F1.

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 56
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
F1.03.391	1-03A-H5231	0-439G	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR - SWAY STRUT 1-03A-439G-H5231
F1.03.392	1-03A-H4	0-439C	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR - SWAY STRUT 1-03A-1-0-439C-H4
F1.03.393	1-03A-H5230	0-439G	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR - SWAY STRUT 1-03A-439G-H5230
F1.03.394	1-03A-H5229	0-439G	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR - SPRING 1-03A-439G-H5229
F1.03.405	1-03A-H11	0-439C	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR - RIGID 1-03A-1-0-439C-H11
F1.03.406	1-03A-H12	0-439C	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR - RIGID 1-03A-1-0-439C-H12
F1.03.418	1-03A-H2B	0-480A	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR. - SPRING 1-03A-480A-H2B
F1.03.419	1-03-H6068	0-479F	_____	VT	QCL-14	-----	06.00	-----	EMER. FDWTR. - SNUBBER 1-03-479F-H6068

PROGRAM: NISIRUNB-QAISI02
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER F1.

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION LISTING OUTAGE 12

PAGE 57
 DATE 08/06/90

ITEM NUMBER	ID. NUMBER	DRAWING NUMBERS	LOCS.	INSP REQ.	PROC. NUMBERS	MATERIAL TYPE/GRADE	DIAM./ THICK	CALIB BLOCK	COMMENTS
F1.03.420	1-03A-DE003	0-401A	_____	VT	QCL-14	_____	06.00	_____	MAIN FDMTR. - RIGID 1-03A-401A-DE003
F1.03.450	1-07A-H8	0-402A	_____	VT	QCL-14	-----	08.00	-----	LP & HP CONDENSATE - SPRING 1-07A-6-0-402A-H8

4.0 Results Of Inspections Performed During Outage 12

The results of each inspection shown in the final ISI Plan (Section 3 of this report) are included in this section. The completion date and status for each inspection are shown. All inspections revealing reportable indications are described in further detail in Section 5, 6, or 7 as applicable.

The information shown below is a field description for the reporting format included in this section of the report:

Item Number = ASME Section XI Tables IWB-2500-1 (Class 1),
IWC-2500-1 (Class 2), IWD-2500-1 (Class 3),
Augmented and Alternate Requirements

ID Number = Unique Identification Number

Inspection Date = Date of Examination

Inspection Status
CLR = Clear
REC = Recordable
REP = Reportable

Inspection Limited
L = Limited
- = No

Geo. Ref. = Geometric Reflector
N = No
Y = Yes

Comments = General and/or Detail Description

PROGRAM: NISIRUND-QAISI04
FILE: C007133
PLANT: OCONEE UNIT 1
KEY: ITEM NUMBER B01

DUKE POWER COMPANY
QUALITY ASSURANCE DEPARTMENT
PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 1
DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEQ. REF. =====	COMMENTS =====
B01.021.001B	1RPV-WH5	05/10/90	CLR	L	N	_____
B01.040.001B	1RPV-WH7	05/10/90	CLR	L	N	_____
B01.040.002B	1RPV-WH7	05/08/90	CLR	-	N	_____

PROGRAM: NISIRUND-QAISI04
FILE: C007133
PLANT: OCONEE UNIT 1
KEY: ITEM NUMBER B02

DUKE POWER COMPANY
QUALITY ASSURANCE DEPARTMENT
PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 2
DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEØ. REF. =====	COMMENTS =====
B02.040.003	1SGB-WG58-1	05/06/90	REP	L	N	PIR# 1-090-0052
B02.040.004	1SGB-WG58-2	05/18/90	CLR	L	Y	_____
B02.051.002	1-LDCA-ØUT-V6	05/04/90	CLR	L	N	_____

PROGRAM: NISIRUND-QAISI04
FILE: C007133
PLANT: OCONEE UNIT 1
KEY: ITEM NUMBER B03

DUKE POWER COMPANY
QUALITY ASSURANCE DEPARTMENT
PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 3
DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEØ. REF. =====	COMMENTS =====
B03.150.002	1-LDCA-ØUT-V2	05/04/90	CLR	L	Y	_____
B03.160.002	1-LDCA-ØUT-V2	05/04/90	CLR	L	N	_____

PROGRAM: NISIRUND-QAISI04
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B05

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 4
 DATE 08/07/90

ITEM NUMBER	ID NUMBER	INSPECTION DATE	INSPECTION STATUS	INSPECTION LIMITED	GEQ. REF.	COMMENTS
B05.050.003	1PIA2-7	05/05/90	CLR	-	N	
B05.050.003A	1PIA2-7	05/15/90	CLR	-	N	
B05.050.003B	1PIA2-7	05/16/90	CLR	-	N	
B05.050.004	1PDA2-2	05/05/90	CLR	L	N	
B05.050.004A	1PDA2-2	05/15/90	CLR	L	N	
B05.050.004B	1PDA2-2	05/07/90	CLR	-	N	
B05.050.012	1PHA-17	05/18/90	CLR	L	N	
B05.050.012A	1PHA-17	05/18/90	CLR	-	N	
B05.050.012B	1PHA-17	05/22/90	CLR	-	N	

PROGRAM: NISIRUND-QAISI04
FILE: C007133
PLANT: OCONEE UNIT 1
KEY: ITEM NUMBER B06

DUKE POWER COMPANY
QUALITY ASSURANCE DEPARTMENT
PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 5
DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEØ. REF. =====	COMMENTS =====
B06.180.002	1RCP-1A2-F	05/05/90	CLR	-	N	_____

PROGRAM: NISIRUND-QAISI04
FILE: C007133
PLANT: OCONEE UNIT 1
KEY: ITEM NUMBER B07

DUKE POWER COMPANY
QUALITY ASSURANCE DEPARTMENT
PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 6
DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEØ. REF. =====	COMMENTS =====
B07.060.002	1RCP-1A2-S	05/18/90	CLR	-	N	_____
B07.070.017	1-53A-LP104	05/21/90	CLR	-	N	_____
B07.070.018	1-53A-LP103	05/18/90	CLR	-	N	_____

PROGRAM: NISIRUND-QAISI04
FILE: C007133
PLANT: OCONEE UNIT 1
KEY: ITEM NUMBER B08

DUKE POWER COMPANY
QUALITY ASSURANCE DEPARTMENT
PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 7
DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEØ. REF. =====	COMMENTS =====
B08.020.005	1PZR-WP82-Z	05/07/90	CLR	-	N	_____
B08.020.006	1PZR-WP82-ZW	05/07/90	CLR	-	N	_____
B08.030.001	1SGA-WG57	05/10/90	CLR	-	N	_____

PROGRAM: NISIRUND-QAISI04
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B09

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 8
 DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEQ. REF. =====	COMMENTS =====
B09.011.093	1-53A-2.2-63L	05/14/90	CLR	L	Y	_____
B09.011.093A	1-53A-2.2-63L	05/07/90	CLR	-	N	_____
B09.011.098	1-53A-1.2-8L	05/14/90	CLR	L	Y	_____
B09.011.098A	1-53A-1.2-8L	05/08/90	CLR	-	N	_____
B09.011.099	1-53A-1.2-6L	05/14/90	CLR	-	Y	_____
B09.011.099A	1-53A-1.2-6L	05/03/90	CLR	-	N	_____
B09.011.102	1-53A-1.2-28L	05/14/90	CLR	-	Y	_____
B09.011.102A	1-53A-1.2-28L	05/08/90	CLR	-	N	_____
B09.011.103	1-53A-1.2-21L	05/14/90	CLR	-	Y	_____
B09.011.103A	1-53A-1.2-21L	05/08/90	CLR	-	N	_____
B09.011.113	1-51A-05-52C	05/03/90	CLR	-	N	_____
B09.011.113A	1-51A-05-52C	05/02/90	CLR	-	N	_____
B09.012.017	1PDA2-212LI	05/05/90	CLR	-	N	_____
B09.012.017A	1PDA2-212LI	05/04/90	CLR	-	N	_____
B09.012.018	1PDA2-212LØ	05/05/90	CLR	-	N	_____

PROGRAM: NISIRUND-QAISI04
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B09

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 9
 DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEQ. REF. =====	COMMENTS =====
B09.012.018A	1PDA2-212L0	05/04/90	CLR	-	N	_____
B09.021.008	1-51A-11-87	05/03/90	CLR	-	N	_____
B09.021.009A	1-51A-11-89	05/03/90	CLR	-	N	_____
B09.021.051	1-51A-05-71C	05/02/90	CLR	-	N	_____
B09.021.052	1-51A-05-65C	05/04/90	CLR	-	N	_____
B09.021.053	1-51A-05-62C	05/04/90	CLR	-	N	_____
B09.021.054	1-51A-05-59C	05/04/90	CLR	-	N	_____
B09.021.055	1-51A-05-56C	05/02/90	CLR	-	N	_____
B09.021.072	1-51A-136-01A	05/04/90	CLR	-	N	_____
B09.021.074	1-51A-136-03	05/04/90	CLR	-	N	_____

PROGRAM: NISIRUND-QAISI04
FILE: C007133
PLANT: OCONEE UNIT 1
KEY: ITEM NUMBER B10

DUKE POWER COMPANY
QUALITY ASSURANCE DEPARTMENT
PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 10
DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEN. REF. =====	COMMENTS =====
B10.010.002	1-53A-H1B	05/11/90	CLR	-	N	_____

PROGRAM: NISIRUND-QAISIO4
FILE: C007133
PLANT: OCONEE UNIT 1
KEY: ITEM NUMBER B14

DUKE POWER COMPANY
QUALITY ASSURANCE DEPARTMENT
PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 11
DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEN. REF. =====	COMMENTS =====
B14.010.002	IRPV-CRD-66WH9	05/08/90	CLR	-	N	_____
B14.010.005	IRPV-CRD-66W60	05/08/90	CLR	-	N	_____
B14.010.008	IRPV-CRD-66	05/08/90	CLR	-	N	_____
B14.010.011	IRPV-CRD-66W61	05/08/90	CLR	-	N	_____

PROGRAM: NISIRUND-QAISI04
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER B15

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 12
 DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEØ. REF. =====	COMMENTS =====
B15.010.001	1RPV-LK TEST	06/04/90	CLR	-	N	_____
B15.020.001	1PZR-LK TEST	06/04/90	CLR	-	N	_____
B15.030.001	1SGA-LK TEST	06/04/90	CLR	-	N	_____
B15.030.002	1SGB-LK TEST	06/04/90	CLR	-	N	_____
B15.040.001	1LDC1A-LK TEST	06/04/90	CLR	-	N	_____
B15.040.002	1LDC1B-LK TEST	06/04/90	CLR	-	N	_____
B15.050.001	1-ØFD-100A-1.1	06/04/90	CLR	-	N	_____
B15.050.001A	1-ØFD-100A-1.2	06/04/90	CLR	-	N	_____
B15.050.002	1-ØFD-101A-1.1	06/04/90	REC	-	N	_____
B15.050.003	1-ØFD-101A-1.4	06/04/90	CLR	-	N	_____
B15.050.004	1-ØFD-102A-1.1	06/04/90	REC	-	N	_____
B15.050.005	1-ØFD-102A-1.2	06/04/90	CLR	-	N	_____
B15.050.006	1-ØFD-102A-1.3	06/04/90	CLR	-	N	_____
B15.050.007	1-ØFD-110A-1.1	06/04/90	REC	-	N	_____
B15.050.009	1-ØFD-110A-1.4	06/04/90	CLR	-	N	_____

PROGRAM: NISIRUND-QAISI04
FILE: C007133
PLANT: OCONEE UNIT 1
KEY: ITEM NUMBER B15

DUKE POWER COMPANY
QUALITY ASSURANCE DEPARTMENT
PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 13
DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEN. REF. =====	COMMENTS =====
B15.060.001	1-RCP-1A1	06/04/90	CLR	-	N	_____
B15.060.002	1-RCP-1A2	06/04/90	CLR	-	N	_____
B15.060.003	1-RCP-1B1	06/04/90	CLR	-	N	_____
B15.060.004	1-RCP-1B2	06/04/90	CLR	-	N	_____

PROGRAM: NISIRUND-QAISI04
FILE: C007133
PLANT: OCONEE UNIT 1
KEY: ITEM NUMBER B16

DUKE POWER COMPANY
QUALITY ASSURANCE DEPARTMENT
PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 14
DATE 08/07/90

ITEM NUMBER	ID NUMBER	INSPECTION DATE	INSPECTION STATUS	INSPECTION LIMITED	GEN. REF.	COMMENTS
B16.011.001	1SGA-TUBES	05/17/90	REP	-	N	_____
B16.011.002	1SGB-TUBES	05/18/90	REP	-	N	_____

PROGRAM: NISIRUND-QAISI04
FILE: C007133
PLANT: OCONEE UNIT 1
KEY: ITEM NUMBER C01

DUKE POWER COMPANY
QUALITY ASSURANCE DEPARTMENT
PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 15
DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEQ. REF. =====	COMMENTS =====
C01.010.005	ISGB-WG8-1	05/09/90	CLR	L	N	_____

PROGRAM: NISIRUND-QAISI04
FILE: C007133
PLANT: OCONEE UNIT 1
KEY: ITEM NUMBER C03

DUKE POWER COMPANY
QUALITY ASSURANCE DEPARTMENT
PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 16
DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEØ. REF. =====	COMMENTS =====
C03.040.017	1-01A-H9B	05/21/90	CLR	-	N	_____
C03.040.018	1-01A-H9A	05/22/90	CLR	-	N	_____
C03.040.037	1-03-H15B	05/11/90	CLR	-	N	_____
C03.040.038	1-03-H9B	05/23/90	REC	-	N	REQUEST FOR RELIEF ONS-0013
C03.040.050	1-53B-H17	04/05/90	CLR	-	N	_____
C03.040.053	1-53B-R29	05/14/90	CLR	-	N	_____
C03.040.059	1-53B-DE062	04/04/90	CLR	-	N	_____
C03.040.062	1-54A-H5	04/23/90	CLR	-	N	_____
C03.040.065	1-54A-R6	04/05/90	CLR	-	N	_____

PROGRAM: NISIRUND-QAISI04
FILE: C007133
PLANT: OCONEE UNIT 1
KEY: ITEM NUMBER C04

DUKE POWER COMPANY
QUALITY ASSURANCE DEPARTMENT
PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 17
DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEØ. REF. =====	COMMENTS =====
C04.040.001	1-01A-SV1-STUD	05/05/90	CLR	-	N	_____

PROGRAM: NISIRUND-QAIS104
FILE: C007133
PLANT: OCONEE UNIT 1
KEY: ITEM NUMBER C05

DUKE POWER COMPANY
QUALITY ASSURANCE DEPARTMENT
PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 18
DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEQ. REF. =====	COMMENTS =====
C05.011.027	1-53B-3.1-42E	04/04/90	CLR	-	N	_____
C05.011.034	1-53B-16-4	05/01/90	CLR	-	N	_____
C05.011.035	1-53B-7.2-20KA	04/05/90	CLR	-	N	_____
C05.011.036	1-53B-7.2-11K	04/11/90	CLR	-	N	_____
C05.011.038	1-53B-7.1-30A	04/05/90	CLR	-	N	_____
C05.011.039	1-53B-7.1-26	04/05/90	CLR	-	N	_____
C05.011.044	1-53B-3.4-32F	04/04/90	CLR	-	N	_____
C05.011.085B	1-53B-14-1C	05/02/90	CLR	-	N	_____
C05.011.086	1-53B-14-1D	05/02/90	CLR	-	N	_____
C05.011.087	1-53B-14-1E	05/02/90	CLR	-	N	_____
C05.011.093	1-53B-10-B64	04/30/90	CLR	-	N	_____
C05.011.151	1-53A-2.4-78LA	05/03/90	CLR	-	N	_____
C05.011.205	1-54A-1.3-15A	04/04/90	CLR	-	N	_____
C05.011.206	1-54A-3.1-2C	04/11/90	CLR	-	N	_____
C05.011.207	1-54A-3.1-6CC	04/04/90	CLR	-	N	_____

PROGRAM: NISIRUND-QAISI04
FILE: C007133
PLANT: OCONEE UNIT 1
KEY: ITEM NUMBER C05

DUKE POWER COMPANY
QUALITY ASSURANCE DEPARTMENT
PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 19
DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEO. REF. =====	COMMENTS =====
C05.011.220	1-54A-1.1-19A	04/04/90	CLR	-	N	_____
C05.011.264	1-51A-1.1-39A	05/21/90	CLR	-	N	_____
C05.011.268	1-51A-1.2-43A	05/21/90	CLR	-	N	_____
C05.011.271	1-51A-1.2-48A	05/16/90	CLR	-	N	_____
C05.012.021	1-54A-3.1-2CL	04/11/90	CLR	-	N	_____
C05.012.026	1-53B-10-B77L	04/23/90	CLR	-	N	_____
C05.031.008	1-53B-6.2-26KC	04/05/90	CLR	-	N	_____

PROGRAM: NISIRUND-QAISI04
FILE: C007133
PLANT: OCONEE UNIT 1
KEY: ITEM NUMBER C07

DUKE POWER COMPANY
QUALITY ASSURANCE DEPARTMENT
PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 20
DATE 08/07/90

ITEM NUMBER	ID NUMBER	INSPECTION DATE	INSPECTION STATUS	INSPECTION LIMITED	GEØ. REF.	COMMENTS
C07.020.006	1-ØFD-101A-1.4	04/17/90	CLR	-	N	ALSØ INSP. 110187 STATUS - CLR
C07.020.007	1-ØFD-101A-1.3	04/17/90	CLR	-	N	ALSØ INSP. 110187 STATUS - CLR
C07.030.004	1HPI-PUMP-1C	04/17/90	CLR	-	N	ALSØ INSP. 110187 STATUS - CLR

PROGRAM: NISIRUND-QAISI04
FILE: C007133
PLANT: OCONEE UNIT 1
KEY: ITEM NUMBER D01

DUKE POWER COMPANY
QUALITY ASSURANCE DEPARTMENT
PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 21
DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEØ. REF. =====	COMMENTS =====
D01.011.015	1-ØFD-135A-1.2	05/09/89	CLR	-	N	_____

PROGRAM: NISIRUND-QAISI04
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER D02

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 22
 DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEØ. REF. =====	COMMENTS =====
D02.011.003	1-ØFD-121A-1.7	06/21/90	CLR	-	N	_____
D02.011.004	1-ØFD-121A-1.8	06/21/90	REC	-	N	_____
D02.011.005	1-ØFD-121B-1.3	02/12/90	CLR	-	N	_____
D02.011.006	1-ØFD-121B-1.5	02/14/90	CLR	-	N	_____
D02.011.021	1-ØFD-133A-2.5	02/13/90	CLR	-	N	_____
D02.011.023	1-ØFD-133A-1.2	05/29/90	CLR	-	N	_____
D02.011.025	1-ØFD-133A-1.5	05/29/90	CLR	-	N	_____
D02.011.026	1-ØFD-133A-2.1	05/29/90	CLR	-	N	_____
D02.011.027	1-ØFD-133A-2.2	05/29/90	CLR	-	N	_____
D02.011.028	1-ØFD-133A-3.2	05/29/90	CLR	-	N	_____
D02.011.029	1-ØFD-133A-3.4	05/29/90	CLR	-	N	_____
D02.011.032	1-ØFD-124A-1.3	02/09/90	CLR	-	N	_____
D02.011.034	1-ØFD-124B-1.1	06/19/90	CLR	-	N	_____
D02.011.035	1-ØFD-124B-2.1	06/19/90	CLR	-	N	_____
D02.011.041	1-ØFD-121C-1.1	06/19/90	CLR	-	N	_____

PROGRAM: NISIRUND-QAISI04
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER D02

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 23
 DATE 08/07/90

ITEM NUMBER	ID NUMBER	INSPECTION DATE	INSPECTION STATUS	INSPECTION LIMITED	GEQ. REF.	COMMENTS
D02.011.042	1-0FD-124C-1.2	06/19/90	CLR	-	N	
D02.011.043	1-0FD-133A-3.1	05/29/90	CLR	-	N	
D02.020.020	1-03A-SR39	03/20/90	CLR	-	N	
D02.020.021	1-03A-H24	03/20/90	CLR	-	N	
D02.020.032	1-03A-SR75	03/21/90	CLR	-	N	
D02.020.034	1-03A-H47	03/06/90	CLR	-	N	
D02.020.035	1-03A-SR79	03/06/90	CLR	-	N	
D02.020.036	1-03A-H48	03/06/90	CLR	-	N	
D02.020.037	1-03A-SR80	03/06/90	CLR	-	N	
D02.020.062	1-03A-SR87	03/08/90	CLR	-	N	
D02.020.077	1-03A-H11	05/01/90	CLR	-	N	
D02.020.082	1-03A-SR47	04/19/90	CLR	-	N	
D02.020.087	1-03A-H72(A)	04/09/90	CLR	-	N	
D02.020.096	1-03A-SR86	03/08/90	CLR	-	N	
D02.020.101	1-03A-H46	03/08/90	CLR	-	N	

PROGRAM: NISIRUND-QAISI04
FILE: C007133
PLANT: OCONEE UNIT 1
KEY: ITEM NUMBER D02

DUKE POWER COMPANY
QUALITY ASSURANCE DEPARTMENT
PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 24
DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEØ. REF. =====	COMMENTS =====
D02.020.102	1-03A-H12	05/01/90	CLR	-	N	_____
D02.020.107	1-03A-SR17	03/14/90	CLR	-	N	_____
D02.020.135	1-03A-SR18	03/14/90	CLR	-	N	_____
D02.030.001	1-01A-R6	03/21/90	CLR	-	N	_____

PROGRAM: NISIRUND-QAISI04
FILE: C007133
PLANT: OCONEE UNIT 1
KEY: ITEM NUMBER D03

DUKE POWER COMPANY
QUALITY ASSURANCE DEPARTMENT
PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 25
DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEO. REF. =====	COMMENTS =====
D03.011.001	1-0FD-104A-1.1	05/14/90	CLR	-	N	_____

PROGRAM: NISIRUND-QAISI04
FILE: C007133
PLANT: OCONEE UNIT 1
KEY: ITEM NUMBER E01

DUKE POWER COMPANY
QUALITY ASSURANCE DEPARTMENT
PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 26
DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEØ. REF. =====	COMMENTS =====
E01.001.004	1RCP-1B2	03/01/90	CLR	L	N	BASELINE RFØ # 12
E01.001.004A	1RCP-1B2	02/28/90	CLR	-	N	BASELINE RFØ # 12

PROGRAM: NISIRUND-QAISI04
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER F1.

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 27
 DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEO. REF. =====	COMMENTS =====
F1.01.069	1-51A-H8C	05/17/90	REC	-	N	INSP.RF0#12 PER IWF-2430(A)
F1.01.074	1-51A-H5C	05/19/90	REC	-	N	INSP.RF0#12 PER IWF-2430(A)
F1.01.076	1-51A-H7C	05/17/90	REC	-	N	INSP.RF0#12 PER IWF-2430(A)
F1.01.078	1-51A-H2A	05/17/90	CLR	-	N	INSP.RF0#12 PER IWF-2430(A)
F1.01.079	1-51A-H3A	05/03/90	REC	-	N	_____
F1.01.080	1-51A-H4A	05/03/90	REC	-	N	_____
F1.01.081	1-51A-H5A	05/03/90	REC	-	N	_____
F1.01.082	1-51A-H6A	05/10/90	CLR	-	N	_____
F1.01.083	1-51A-H7A	05/03/90	REP	-	N	PIR# 1-090-0046
F1.01.084	1-51A-H8A	05/17/90	REC	-	N	INSP.RF0#12 PER IWF-2430(A)
F1.01.085	1-51A-H9A	06/01/90	CLR	-	N	INSP.RF0#12 PER IWF-2430(A)
F1.01.087	1-51A-H12A	05/03/90	CLR	-	N	_____
F1.01.088	1-51A-H13A	05/03/90	CLR	-	N	_____
F1.01.091	1-51A-H16A	05/17/90	REC	-	N	INSP.RF0#12 PER IWF-2430(A)
F1.01.092	1-51A-H10A	05/17/90	REC	-	N	INSP.RF0#12 PER IWF-2430(A)

PROGRAM: NISIRUND-QAISI04
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER F1.

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 28
 DATE 08/07/90

ITEM NUMBER	ID NUMBER	INSPECTION DATE	INSPECTION STATUS	INSPECTION LIMITED	GEOR. REF.	COMMENTS
F1.01.150	1-53A-H8A	05/03/90	CLR	-	N	
F1.01.164	1-53A-H35C	05/03/90	REC	-	N	
F1.01.165	1-53A-H36C	05/03/90	REC	-	N	
F1.01.166	1-53A-H37C	05/03/90	REC	-	N	
F1.01.171	1-53A-H4A	05/10/90	REC	-	N	
F1.02.017	1-01A-DE006	05/21/90	CLR	-	N	
F1.02.018	1-01A-R2	05/01/90	CLR	-	N	
F1.02.037	1-01A-H2B	05/03/90	CLR	-	N	
F1.02.070	1-01A-H22(A)	05/01/90	REC	-	N	
F1.02.117	1-03-H62	02/26/90	CLR	-	N	
F1.02.136	1-03-H5B	05/03/90	REC	-	N	
F1.02.140	1-03-H9B	05/11/90	CLR	-	N	
F1.02.142	1-03-H5A	05/11/90	CLR	-	N	
F1.02.209	1-03A-H71	02/26/90	CLR	-	N	
F1.02.251	1-51A-DE064	05/01/90	CLR	-	N	

PROGRAM: NISIRUND-QAISI04
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER F1.

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 29
 DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEØ. REF. =====	COMMENTS =====
F1.02.285	1-53B-DE050	05/22/90	CLR	-	N	_____
F1.02.286	1-53B-H25	04/25/90	CLR	-	N	_____
F1.02.287	1-53B-0279	04/25/90	CLR	-	N	_____
F1.02.288	1-53B-DE052	04/25/90	CLR	-	N	_____
F1.02.291	1-53B-R3	04/09/90	CLR	-	N	_____
F1.02.305	1-53A-DE078	03/07/90	CLR	-	N	_____
F1.02.306	1-53B-R2401	03/07/90	CLR	-	N	_____
F1.02.307	1-53B-H23	03/07/90	CLR	-	N	_____
F1.02.308	1-53B-R5	03/07/90	REC	-	N	_____
F1.02.343	1-53B-2601	04/09/90	CLR	-	N	_____
F1.02.344	1-53B-2602	04/09/90	REC	-	N	_____
F1.02.345	1-53B-R29	04/09/90	CLR	-	N	_____
F1.02.346	1-53B-H57	02/26/90	CLR	-	N	_____
F1.02.347	1-53B-H58A	02/26/90	CLR	-	N	_____
F1.02.348	1-53B-H17	05/03/90	REC	-	N	_____

PROGRAM: NISIRUND-QAISI04
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER F1.

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 30
 DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEØ. REF. =====	COMMENTS =====
F1.02.392	1-53B-H3	03/20/90	CLR	-	N	_____
F1.02.393	1-53B-H1	03/20/90	CLR	-	N	_____
F1.02.394	1-53B-DE068	03/22/90	CLR	-	N	_____
F1.02.396	1-53B-DE069	05/01/90	CLR	-	N	_____
F1.02.404	1-53B-H12	03/22/90	CLR	-	N	_____
F1.02.405	1-53A-H3B	05/10/90	REC	-	N	_____
F1.02.406	1-53A-H5A	05/03/90	REC	-	N	_____
F1.02.453	1-54A-H35	03/20/90	CLR	-	N	_____
F1.02.460	1-54A-DE014	03/22/90	CLR	-	N	_____
F1.02.461	1-54A-DE015	03/22/90	CLR	-	N	_____
F1.02.463	1-54A-DE016	03/22/90	CLR	-	N	_____
F1.02.472	1-54A-R6	03/07/90	CLR	-	N	_____
F1.02.475	1-54A-R19	03/28/90	REC	-	N	_____
F1.02.500	1-54A-R21	04/09/90	CLR	-	N	_____
F1.02.502	1-54A-R22	04/09/90	CLR	-	N	_____

PROGRAM: NISIRUND-QAISI04
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER F1.

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 31
 DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEO. REF. =====	COMMENTS =====
F1.02.503	1-54A-H5	03/20/90	REC	-	N	
F1.03.001	1-01A-H1	03/07/90	CLR	-	N	
F1.03.002	1-01A-H2	04/18/90	CLR	-	N	
F1.03.003	1-01A-R6	03/21/90	CLR	-	N	
F1.03.058	1-03-H54	03/20/90	CLR	-	N	
F1.03.064	1-03-H60	03/07/90	CLR	-	N	
F1.03.118	1-03A-SR47	04/19/90	CLR	-	N	
F1.03.120	1-03A-SR39	03/20/90	CLR	-	N	
F1.03.121	1-03A-H24	03/20/90	CLR	-	N	
F1.03.122	1-03A-H25	05/04/90	CLR	-	N	
F1.03.150	1-03A-H72 (A)	04/09/90	CLR	-	N	
F1.03.151	1-03A-H70	03/20/90	CLR	-	N	
F1.03.152	1-03A-SR62	03/20/90	CLR	-	N	
F1.03.175	1-03A-H78	02/26/90	CLR	-	N	
F1.03.176	1-03A-SR64	02/26/90	CLR	-	N	

PROGRAM: NISIRUND-QAISI04
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER F1.

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 32
 DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEØ. REF. =====	COMMENTS =====
F1.03.207	1-03A-SR86	03/08/90	CLR	-	N	_____
F1.03.231	1-03A-SR75	03/21/90	CLR	-	N	_____
F1.03.237	1-03A-H46	03/08/90	CLR	-	N	_____
F1.03.238	1-03A-SR52	01/31/90	CLR	-	N	_____
F1.03.239	1-03A-H47	03/06/90	CLR	-	N	_____
F1.03.240	1-03A-SR79	03/06/90	CLR	-	N	_____
F1.03.241	1-03A-H48	03/06/90	CLR	-	N	_____
F1.03.242	1-03A-SR80	03/06/90	CLR	-	N	_____
F1.03.314	1-03A-DE031	02/16/90	CLR	-	N	_____
F1.03.323	1-03A-SR17	03/14/90	CLR	-	N	_____
F1.03.324	1-03A-SR18	03/14/90	CLR	-	N	_____
F1.03.358	1-03A-SR87	03/08/90	CLR	-	N	_____
F1.03.367	1-03A-H144	01/31/90	CLR	-	N	_____
F1.03.371	1-03A-H149	01/31/90	CLR	-	N	_____
F1.03.372	1-03A-H131	01/31/90	CLR	-	N	_____

PROGRAM: NISIRUND-QAISI04
 FILE: C007133
 PLANT: OCONEE UNIT 1
 KEY: ITEM NUMBER F1.

DUKE POWER COMPANY
 QUALITY ASSURANCE DEPARTMENT
 PRE-SERVICE AND IN-SERVICE INSPECTION SYSTEM
 OCONEE 1 INSERVICE INSPECTION RESULTS OUTAGE 12

PAGE 33
 DATE 08/07/90

ITEM NUMBER =====	ID NUMBER =====	INSPECTION DATE =====	INSPECTION STATUS =====	INSPECTION LIMITED =====	GEO. REF. =====	COMMENTS =====
F1.03.388	1-03A-H189	01/31/90	CLR	-	N	_____
F1.03.389	1-03A-H188	01/31/90	CLR	-	N	_____
F1.03.390	1-03A-SR36	01/31/90	CLR	-	N	_____
F1.03.391	1-03A-H5231	02/27/90	CLR	-	N	_____
F1.03.392	1-03A-H4	03/20/90	CLR	-	N	_____
F1.03.393	1-03A-H5230	02/27/90	CLR	-	N	_____
F1.03.394	1-03A-H5229	03/20/90	CLR	-	N	_____
F1.03.405	1-03A-H11	05/01/90	CLR	-	N	_____
F1.03.406	1-03A-H12	05/01/90	CLR	-	N	_____
F1.03.418	1-03A-H2B	05/03/90	CLR	-	N	_____
F1.03.419	1-03-H6068	05/03/90	CLR	-	N	_____
F1.03.420	1-03A-DE003	03/07/90	REC	-	N	_____
F1.03.450	1-07A-H8	03/07/90	CLR	-	N	_____

5.0 Class 1 Inspection Results

Examinations were performed during Outage 12 on the Reactor Vessel, Pressurizer, Steam Generators 1A and 1B, Letdown Cooler 1A, Class 1 Piping of the Reactor Coolant, Low Pressure Injection and High Pressure Injection Systems, Reactor Coolant Pump Bolting, Valve Bolting and Supports.

5.1 Reactor Vessel

Reactor Vessel Upper Head Weld (Upper Head Ring to Upper Head Cap) from 240 degrees to 0 degrees received an ultrasonic inspection. Reactor Vessel Upper Head Flange to Upper Head Ring Weld from 240 degrees to 0 degrees received an ultrasonic and a magnetic particle examination. Four (4) welds in one (1) CRDM Housing received a dye penetrant examination. No reportable indications were found.

5.2 Pressurizer

Pressurizer Support Lug Welds located at Z-axis and between Z-W axis received a magnetic particle examination. No reportable indications were found.

5.3 Steam Generators

Steam Generator 1B Upper Head to Tubesheet Weld received an ultrasonic inspection. Reportable indications were found (Weld 1SGB-WG-58-1, Item Number B02.040.003). Indications were evaluated and found acceptable. (Refer to Babcock and Wilcox Volumetric Examination Evaluation Report 901-002, dated May 8, 1990, and Babcock and Wilcox Fracture Mechanics Analysis Report Number 32-1179753-00, included in Section 10 of this report.) The scope of the inspection was expanded per ASME Section XI, Paragraph IWB-2430(a) to include Steam Generator 1B Lower Head to Tubesheet Weld, Item Number B02.040.004 (refer to Problem Investigation Report No. 1-090-0052), included in Section 9 of this report. A copy of the inspection data sheets is included in this section of the report. No other reportable indications were found.

Steam Generator 1A Support Skirt to Head Weld received a magnetic particle examination. No reportable indications were found.

5.4 Letdown Coolers

Letdown Cooler 1A Outlet Channel Body to End Plate Weld and Tubeside Outlet Nozzle to Channel Body Weld received ultrasonic examinations. No reportable indications were found.

5.5 Piping

Dissimilar Metal Butt Welds:

Two (2) Reactor Coolant Pump 1A2 Safe End to Pipe Welds and one (1) Surge Nozzle Safe End Weld, nominal pipe size four inches and greater,

received ultrasonic and dye penetrant examinations. No reportable indications were found.

Similar Metal Butt Welds:

Six (6) circumferential butt welds, nominal pipe size four inches and greater, received ultrasonic and dye penetrant examinations. Two (2) longitudinal welds, nominal pipe size four inches and greater, received ultrasonic and magnetic particle examinations. Nine (9) circumferential butt welds, nominal pipe size less than four inches, received a dye penetrant examination. No reportable indications were found.

Piping Integrally-Welded Attachments:

One (1) integrally-welded attachment on the Low Pressure Injection System received a dye penetrant examination. No reportable indications were found.

Piping Supports:

Twelve (12) Class 1 component Supports received a visual examination as required by ASME Section XI, Article IWF-2000. A reportable condition was detected on Component Support 1-51A-0-479A-H7A (Item No. F1.01.083). Duke Power Company Design Engineering evaluated the reportable condition and determined that the pipe will remain within code tolerances as found (refer to Problem Investigation Report 1-090-0046 included in Section 9 of this report). The scope of the inspection was extended per ASME Section XI, Paragraph IWF-2430(a) to include eight (8) additional supports in the High Pressure Injection System. A copy of the inspection data sheet is included in this section of the report. No other reportable conditions were found.

5.6 Pumps

Reactor Coolant Pump 1A2 Main Flange Bolts received an ultrasonic examination. No reportable indications were found.

Reactor Coolant Pump 1A2 Lower Seal Housing Bolts (twelve (12) Cap Screws) received a visual examination. No reportable conditions were found.

5.7 Valves

Two (2) Decay Heat Emergency Dump Valves (LP-103 and LP-104) received a visual examination. No reportable conditions were found.

5.8 Steam Generator Tubing

The tubing in Once-Through Steam Generators (OTSGs) "A" and "B" at Oconee Unit 1 was inspected using eddy current bobbin coil multi-frequency techniques and B&W's Eddy-360 rotating pancake coil probe. The sleeves in both OTSGs were also inspected with bobbin coil and crosswound probes. The eddy current examinations began on May 2, 1990

and were completed on May 18, 1990. A brief summary of the eddy current examination follows:

OTSG "A"

Tubing Examination:

9332 tubes were examined using the standard bobbin coil technique.

9 tubes exhibited degradation of 40% TW or greater.

12 tubes exhibited degradation of 20% to 39% TW.

Ten (10) tubes were removed from service in OTSG "A" due to indications exceeding the plugging limit or from good engineering practices. A list of these tubes for OTSG "A" is attached.

Sleeve Examination:

262 sleeves were examined using both standard bobbin coil and crosswound probes.

There was no degradation reported in any of the sleeves examined and no sleeves were removed from service.

OTSG "B"

Tubing Examination:

9328 tubes were examined using the standard bobbin coil and crosswound probes.

49 tubes exhibited degradation of 40% TW or greater. Three of the tubes (102-9, 108-111, & 108-114) contained wear indications sized as less than 40% TW using B&W's Eddy-360 and were not removed from service.

168 tubes exhibited degradation of 20 to 39% TW.

Forty-nine (49) tubes were removed from service in OTSG "B" due to indications exceeding the plugging limit or from good engineering practices. A list of these tubes for OTSG "B" is attached.

Sleeve Examination:

209 sleeves were examined using both standard bobbin coil and crosswound probes.

There was no degradation reported in any of the sleeves examined and no sleeves were removed from service.

5.9 System Leakage Tests

The Class 1 Pressure Boundary was subjected to a system leakage test as required by ASME Section XI, Article IWB-5000. No reportable conditions were found.

5.10 Class 1 Repairs and Replacements

Repairs and replacements for work performed from February 14, 1989 to June 4, 1990 are itemized in Section 11 of this report.

EC FIELD SYSTEM (TM) (VER. 3.1) **** Thursday June 7, 1990

6:20 AM **** BABCOCK & WILCOX CO. **** Page

Plant: Oconee Unit 1
 Outage: 05/90 RPO

Steam Generator: A

QUERY: INDICATIONS 40-100% TMD

TEST	ROW	COL	IND	XTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
FINAL DATA	6	13	ODI	40	1.85	M 1	92	14TH TSP+	0.61	FL	6	B0690
FINAL DATA	20	42	ODI	56	2.27	3	82	14TH TSP+	0.38	FL	20	W6871
FINAL DATA	40	116	ODI	43	1.06	3	99	1ST TSP +	0.68	FL	70	H8259
FINAL DATA	61	17	ODI	40	1.00	M 1	92	14TH TSP+	0.49	FL	48	N0942
FINAL DATA	64	116	ODI	49	1.42	M 1	85	8TH TSP +	0.00	FL	54	N0942
FINAL DATA	72	126	ODI	46	1.33	M 1	90	11TH TSP+	0.77	FL	129	T4004
FINAL DATA	85	5	ODI	61	1.15	M 1	72	14TH TSP+	0.60	14TH TSP	3	N0942
FINAL DATA	86	6	ODI	40	2.43	M 1	92	14TH TSP+	0.18	FL	123	S6373
FINAL DATA	86	131	ODI	45	0.68	M 1	95	10TH TSP-	0.59	FL	140	N0942

TOTAL TUBES FOUND = 9
 TOTAL INDICATIONS FOUND = 9
 TOTAL TUBES IN INPUT FILE = 15531

EC FIELD SYSTEM (TM) (VER. 3.1) **** Thursday June 7, 1990

6:22 AM **** BABCOCK & WILCOX CO. ****: Page

Plant: Oconee Unit 1
Outage: 05/90 RFO

Steam Generator: A

QUERY: INDICATIONS 20-39% TWD

TEST	ROW	COL	IND	XTH	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
FINAL DATA	7	14	001	22	0.94	M	1	110 6TH TSP +	0.30	FL	7	T4004
FINAL DATA	18	43	001	26	0.83	M	3	105 14TH TSP+	0.34	FL	19	W6871
FINAL DATA	56	6	001	32	1.13	M	1	98 14TH TSP+	0.19	FL	45	N0942
FINAL DATA	60	2	001	20	1.83	M	1	98 14TH TSP-	0.11	FL	48	T4004
FINAL DATA	61	1	001	38	0.56	M	1	89 9TH TSP -	0.46	FL	48	T4004
FINAL DATA	62	115	001	39	1.25	M	1	91 9TH TSP +	0.00	FL	54	N0942
FINAL DATA	65	128	001	39	1.03	M	3	96 14TH TSP+	1.09	FL	54	B0690
FINAL DATA	66	3	001	32	0.90	M	3	100 14TH TSP+	0.50	14TH TSP	1	N0942
FINAL DATA	116	113	001	38	2.81	M	1	92 14TH TSP+	0.80	FL	112	S4373
FINAL DATA	134	30	001	36	0.64	M	1	96 8TH TSP -	0.34	FL	95	T4004
FINAL DATA	137	3	001	21	0.87	M	1	104 14TH TSP+	0.57	FL	90	H8259
FINAL DATA	147	39	001	33	0.47	M	3	99 4TH TSP +	0.79	FL	77	N0942
FINAL DATA			001	28	0.61	M	1	95 4TH TSP +	0.21	FL	77	N0942

TOTAL TUBES FOUND = 12
 TOTAL INDICATIONS FOUND = 13
 TOTAL TUBES IN INPUT FILE = 15531

17517

***** B&W TUBAN(TM) (VER. 3.1)***** Thursday June 7, 1990 01:02 PM **

Plant: OCONEE UNIT 1

Steam Generator: A

Order: Sort by ROW, TUBE

Title: TUBES PLUGGED - 5/90 RFO

NO.	ROW	TUBE
1.	6-	13
2.	20-	42
3.	40-	116
4.	61-	17
5.	64-	116
6.	65-	128
7.	72-	126
8.	85-	5
9.	86-	6
10.	86-	131

EC FIELD SYSTEM (TH) (VER. 3.1) **** Thursday June 7, 1990

1:21 PM **** BABCOCK & WILCOX CO. **** Page 1

Pl. : Oconee Unit 1 Steam Generator: B
Outage: 05/90 RFO

Y: INDICATIONS 40-100% TWD

TEST	ROW	COL	IND	XTV	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
FINAL DATA	9	36	001	41	0.95	M	1	94 9TH TSP -	1.44	FL	59	T4004
FINAL DATA	11	47	001	50	2.70	M	1	86 14TH TSP+	0.15	FL	61	T4004
FINAL DATA	19	15	001	40	1.08	M	1	97 14TH TSP+	0.55	FL	72	T4004
FINAL DATA	20	54	001	43	0.98	M	3	95 3RD TSP +	9.01	FL	74	B0690
FINAL DATA	22	93	001	44	0.60	M	1	91 11TH TSP-	0.03	FL	77	W6871
FINAL DATA	24	86	001	48	0.65	M	1	91 14TH TSP+	0.67	FL	80	T4004
FINAL DATA	25	88	001	43	0.79	M	3	94 14TH TSP+	0.54	FL	80	N0942
FINAL DATA	26	88	001	45	1.01	M	1	82 14TH TSP+	0.06	FL	82	H3921
FINAL DATA	27	9	001	41	1.07	M	1	94 9TH TSP -	1.38	FL	84	S4373
FINAL DATA	29	88	001	53	1.18	M	1	83 14TH TSP+	0.39	FL	87	H8259
FINAL DATA	30	105	001	43	1.15	M	1	84 10TH TSP-	0.47	FL	88	N0942
FINAL DATA	32	72	001	44	1.02	M	1	94 12TH TSP+	0.00	FL	89	B0690
FINAL DATA	35	73	001	41	0.73	M	1	87 12TH TSP-	0.14	FL	94	B0690
FINAL DATA	43	116	001	40	1.22	M	1	87 11TH TSP+	0.05	FL	103	S4373
FINAL DATA	44	118	001	42	1.19	M	1	89 10TH TSP-	0.06	FL	104	H8259
FINAL DATA	44	119	001	41	1.06	M	1	84 10TH TSP-	0.22	FL	104	H8259
FINAL DATA	50	119	001	40	1.19	M	1	85 14TH TSP+	0.00	FL	109	L7871
FINAL DATA	52	3	001	48	3.12	M	1	78 14TH TSP+	0.00	FL	124	B0690
FINAL DATA	52	4	001	83	6.88	M	1	46 14TH TSP+	0.00	FL	124	B0690
FINAL DATA	61	125	001	47	0.70	M	3	87 12TH TSP+	0.95	FL	135	N0942
FINAL DATA	68	119	001	48	1.22	M	3	87 14TH TSP+	1.00	FL	134	H3921
FINAL DATA	69	4	001	43	3.06	M	1	114 13TH TSP+	0.00	14TH TSP	3	M7006
FINAL DATA	86	16	001	46	1.95	M	1	90 12TH TSP+	0.08	FL	46	W6871
FINAL DATA	93	7	001	48	0.87	M	1	89 14TH TSP+	0.06	FL	5	W6871
FINAL DATA	94	2	001	55	3.51	M	1	83 13TH TSP+	0.29	FL	5	W6871
FINAL DATA	94	12	001	43	3.01	M	1	93 14TH TSP+	0.40	FL	5	W6871
FINAL DATA	94	119	001	40	0.93	M	1	82 8TH TSP +	0.00	FL	86	N0942
FINAL DATA	95	128	001	44	0.90	M	1	89 11TH TSP-	0.16	FL	83	N0942
FINAL DATA	102	9	WAR	49	1.45	M	1	88 11TH TSP+	0.00	FL	8	N0942
FINAL DATA	103	54	001	44	1.11	M	3	92 7TH TSP +	0.70	FL	9	M7006
FINAL DATA	108	111	WAR	45	1.23	M	1	82 13TH TSP+	0.00	FL	73	N0942
FINAL DATA	108	114	WAR	45	4.93	M	1	83 13TH TSP+	0.00	FL	53	L7871
FINAL DATA			WAR	59	2.76	M	1	71 12TH TSP+	0.00	FL	53	L7871
FINAL DATA	116	6	001	40	2.35	M	1	93 12TH TSP+	0.20	FL	15	W6871
FINAL DATA	116	105	WAR	80	1.41	M	1	69 13TH TSP+	0.00	FL	50	B0690
FINAL DATA			001	43	1.66	M	1	92 9TH TSP +	0.00	FL	50	B0690
FINAL DATA	118	20	001	40	1.81	M	1	94 14TH TSP+	0.00	FL	16	W6871
FINAL DATA	125	93	001	41	1.32	M	1	94 9TH TSP -	1.39	FL	48	W6871
FINAL DATA	128	20	001	42	1.79	M	1	89 9TH TSP -	0.03	FL	22	H3921
FINAL DATA	128	35	001	42	1.13	M	3	95 LTSF +	20.54	FL	22	H3921
FINAL DATA	130	84	001	42	1.22	M	1	96 9TH TSP -	0.18	FL	25	T4004
FINAL DATA	131	82	001	48	1.09	M	1	91 9TH TSP -	0.21	FL	25	T4004
FINAL DATA	132	8	001	52	1.20	M	1	78 14TH TSP-	0.11	FL	26	N0942
FINAL DATA	135	3	001	58	4.92	M	1	81 14TH TSP+	0.00	FL	30	N0942
FINAL DATA	136	3	001	52	1.19	M	1	88 14TH TSP-	0.03	FL	31	N0942
FINAL DATA	137	18	001	55	9.31	M	1	85 10TH TSP+	0.10	FL	32	S4373
FINAL DATA	139	65	001	41	0.95	M	1	92 9TH TSP -	0.11	FL	34	M7006
FINAL DATA	140	3	001	44	0.64	M	1	91 14TH TSP-	1.52	FL	35	W6871
FINAL DATA	140	9	001	40	0.86	M	1	94 9TH TSP -	1.48	FL	35	W6871
FINAL DATA	140	17	001	43	1.45	M	1	92 9TH TSP -	1.37	FL	35	W6871
FINAL DATA	145	52	001	44	1.01	M	3	93 7TH TSP +	0.44	FL	39	W6871

TOTAL TUBES FOUND = 49
TOTAL INDICATIONS FOUND = 51
TOTAL TUBES IN INPUT FILE = 15531

EC FIELD SYSTEM (TM) (VER. 3.1) **** Thursday June 7, 1990

1:16 PM **** BABCOCK & WILCOX CO. **** Page 1

Plant: Oconee Unit 1
Outage: 05/90 RFO

Steam Generator: B

Y: INDICATIONS 20-39% TWO

TEST	ROW	COL	IND	XTM	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
FINAL DATA	1	8	001	24	0.82	M	1	110 10TH TSP+	0.52	FL	55	N0942
FINAL DATA	3	1	001	20	1.56	M	3	114 14TH TSP+	0.75	FL	55	H8259
FINAL DATA	3	30	001	29	1.24	M	1	95 10TH TSP-	1.22	FL	55	H8259
FINAL DATA	4	4	001	24	1.22	M	1	99 14TH TSP+	0.46	FL	56	S4373
FINAL DATA	4	17	001	37	1.38	M	1	89 14TH TSP+	0.27	FL	56	S4373
FINAL DATA	4	39	001	33	1.25	M	1	92 10TH TSP-	0.08	FL	55	H8259
FINAL DATA	5	8	001	22	1.76	M	1	100 14TH TSP+	0.22	FL	56	S4373
FINAL DATA	6	9	001	29	0.98	M	1	103 14TH TSP+	0.00	FL	57	T4004
FINAL DATA	6	19	001	25	0.88	M	1	106 14TH TSP+	0.11	FL	57	T4004
FINAL DATA	6	45	001	29	0.61	M	1	103 14TH TSP+	0.11	FL	57	T4004
FINAL DATA	6	49	001	32	0.98	M	1	101 10TH TSP-	1.41	FL	57	T4004
FINAL DATA	7	11	001	37	0.99	M	1	97 14TH TSP+	0.24	FL	57	T4004
FINAL DATA	7	47	001	20	0.92	M	3	115 14TH TSP+	0.65	FL	58	H3921
FINAL DATA	9	2	001	30	0.85	M	3	106 14TH TSP+	2.04	FL	59	N0942
FINAL DATA	9	3	001	22	0.73	M	1	108 10TH TSP+	0.03	FL	59	T4004
FINAL DATA	9	19	001	21	1.18	M	1	109 10TH TSP-	1.49	FL	59	T4004
FINAL DATA	10	21	001	37	0.78	M	1	97 14TH TSP+	0.03	FL	59	T4004
FINAL DATA	10	56	001	30	1.09	M	1	102 10TH TSP-	1.39	FL	61	T4004
FINAL DATA	12	19	001	37	1.04	M	1	96 10TH TSP-	1.43	FL	62	W6871
FINAL DATA	12	69	001	33	0.85	M	3	104 13TH TSP+	0.21	FL	62	W6871
FINAL DATA	13	17	001	33	1.32	M	1	100 10TH TSP-	1.43	FL	63	S4373
FINAL DATA	14	73	001	39	1.38	M	1	88 14TH TSP+	0.54	FL	64	B0690
FINAL DATA	17	80	001	29	1.61	M	1	99 14TH TSP+	0.26	FL	67	B0690
FINAL DATA	18	2	001	20	1.10	M	1	102 8TH TSP +	0.00	FL	123	B0690
FINAL DATA	19	2	001	20	0.75	M	1	102 8TH TSP +	0.00	FL	123	B0690
FINAL DATA	19	3	001	35	1.39	M	1	95 8TH TSP +	0.18	FL	123	B0690
FINAL DATA	20	47	001	25	0.89	M	1	107 10TH TSP+	1.30	FL	74	B0690
FINAL DATA	20	48	001	34	1.65	M	1	93 10TH TSP+	0.00	FL	74	B0690
FINAL DATA	20	81	001	20	0.61	M	3	116 13TH TSP+	0.50	FL	75	N0942
FINAL DATA	21	39	001	31	0.91	M	1	95 14TH TSP+	0.18	FL	75	N0942
FINAL DATA	21	85	001	24	0.93	M	1	100 14TH TSP+	0.00	FL	75	N0942
FINAL DATA	22	87	001	24	0.79	M	1	108 14TH TSP+	0.03	FL	77	W6871
FINAL DATA	22	91	001	31	1.10	M	1	102 14TH TSP+	0.28	FL	77	W6871
FINAL DATA	23	10	001	38	1.13	M	1	96 9TH TSP -	1.38	FL	79	W6871
FINAL DATA	23	13	001	33	1.22	M	1	100 4TH TSP -	0.03	FL	79	W6871
FINAL DATA	24	91	001	33	0.77	M	1	103 14TH TSP-	0.03	FL	80	T4004
FINAL DATA	25	35	001	22	0.95	M	3	111 7TH TSP -	0.98	FL	80	N0942
FINAL DATA	26	34	001	32	0.85	M	1	90 7TH TSP -	0.30	FL	82	N0942
FINAL DATA	26	88	001	37	0.82	M	3	99 14TH TSP+	0.71	FL	82	H3921
FINAL DATA	26	98	001	27	0.67	M	3	106 14TH TSP+	0.62	FL	84	N0942
FINAL DATA	27	89	001	21	0.75	M	1	109 14TH TSP+	0.37	FL	84	T4004
FINAL DATA	32	73	001	36	0.96	M	3	101 12TH TSP+	0.96	FL	89	S4373
FINAL DATA	33	7	001	29	1.11	M	1	104 14TH TSP+	0.08	FL	122	B0690
FINAL DATA	33	100	001	33	0.81	M	1	103 14TH TSP-	0.14	FL	89	T4004
FINAL DATA	33	102	001	27	0.66	M	1	108 9TH TSP -	1.51	FL	89	T4004
FINAL DATA	34	71	001	27	1.47	M	3	106 12TH TSP+	0.45	FL	92	B0690
FINAL DATA	34	101	001	33	2.35	M	3	102 14TH TSP+	0.62	FL	92	L7871
FINAL DATA	37	7	001	21	1.02	M	1	94 10TH TSP-	0.67	FL	122	B0690
FINAL DATA	40	15	001	26	0.92	M	1	100 11TH TSP+	0.00	FL	100	L7871
FINAL DATA	41	113	001	27	1.25	M	3	110 14TH TSP+	0.82	FL	100	L7871
FINAL DATA	42	99	001	36	1.41	M	3	100 14TH TSP+	1.10	FL	103	B0690
FINAL DATA	43	115	001	31	1.20	M	1	94 14TH TSP+	0.71	FL	103	B0690
FINAL DATA			001	38	1.51	M	1	81 14TH TSP+	0.25	FL	103	B0690
FINAL DATA	45	1	001	33	2.16	M	3	96 2ND TSP +	0.53	FL	119	N0942
FINAL DATA	45	120	001	36	1.30	M	1	88 10TH TSP-	0.03	FL	104	H8259
FINAL DATA	46	1	001	23	1.33	M	1	86 2ND TSP +	0.00	FL	117	L7871
FINAL DATA	46	11	001	26	1.52	M	1	84 14TH TSP+	0.46	FL	117	L7871
FINAL DATA	47	24	001	39	2.09	M	1	76 11TH TSP+	0.00	FL	115	N0942
FINAL DATA	48	120	001	31	1.27	M	1	92 9TH TSP +	0.03	FL	107	H8259
FINAL DATA	48	121	001	22	1.12	M	1	99 10TH TSP-	1.37	FL	107	H8259
FINAL DATA	49	2	001	28	1.43	M	3	101 13TH TSP+	0.32	FL	115	L7871
FINAL DATA	49	120	001	30	1.20	M	1	93 9TH TSP +	0.00	FL	107	B0690
FINAL DATA	49	123	001	34	0.92	M	3	101 14TH TSP+	20.54	FL	107	H8259
FINAL DATA	50	5	001	25	1.04	M	3	103 13TH TSP+	1.47	FL	114	N0942
FINAL DATA	50	6	001	23	1.29	M	1	102 13TH TSP+	1.30	FL	114	N0942
FINAL DATA	51	121	001	22	1.09	M	1	98 14TH TSP+	0.45	FL	109	L7871
FINAL DATA	58	126	001	26	1.94	M	3	108 14TH TSP+	0.61	FL	118	B0690
FINAL DATA	59	116	001	37	1.51	M	1	84 14TH TSP+	0.59	FL	118	L7871
FINAL DATA	59	118	001	22	1.67	M	1	95 10TH TSP-	1.50	FL	118	L7871
FINAL DATA	61	1	001	36	1.04	M	1	97 13TH TSP+	1.04	FL	131	B0690

EC FIELD SYSTEM (TM) (VER. 3.1) **** Thursday June 7, 1990

1:17 PM **** BABCOCK & WILCOX CO. **** Page

2

Unit: Oconee Unit 1
Outage: 05/90 RFO

Steam Generator: B

INDICATIONS 20-39X TWD

TEST	ROW	COL	IND	XTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
FINAL DATA	63	28	001	21	1.65	3	105	UTSF -	1.39	FL	126	B0690
FINAL DATA	66	122	001	24	0.66	3	104	14TH TSP+	1.02	FL	132	W6871
FINAL DATA	67	3	001	37	0.39	M	1	120 14TH TSP+	0.00	14TH TSP	3	M7006
FINAL DATA	67	6	001	26	0.31	M	1	130 13TH TSP+	0.20	14TH TSP	3	M7006
FINAL DATA	67	10	001	24	0.87	M	1	101 13TH TSP-	0.05	FL	129	B0690
FINAL DATA	67	125	001	31	1.10	3	100	14TH TSP+	0.35	FL	134	N0942
FINAL DATA	69	3	001	30	0.31	M	1	126 14TH TSP+	0.30	14TH TSP	3	N0942
FINAL DATA	69	5	001	27	0.53	M	1	129 13TH TSP+	0.30	14TH TSP	3	M7006
FINAL DATA	70	118	001	36	0.89	M	1	93 14TH TSP-	0.09	FL	114	T4004
FINAL DATA	71	3	001	31	0.54	M	1	125 14TH TSP+	0.40	14TH TSP	3	B0690
FINAL DATA	76	118	001	30	1.30	3	100	12TH TSP+	0.45	FL	108	W6871
FINAL DATA	76	120	001	23	0.67	M	1	100 12TH TSP-	1.50	FL	108	W6871
FINAL DATA	77	121	001	31	0.79	M	1	96 8TH TSP +	0.05	FL	99	T4004
FINAL DATA	80	125	001	28	0.77	M	1	98 14TH TSP+	0.05	FL	99	T4004
FINAL DATA	82	129	001	25	1.91	M	1	98 10TH TSP-	0.11	FL	98	T4004
FINAL DATA			001	26	1.10	M	1	97 13TH TSP+	0.69	FL	98	T4004
FINAL DATA	83	119	001	25	0.88	M	1	98 14TH TSP+	0.23	FL	98	T4004
FINAL DATA	84	124	001	28	1.42	M	1	97 14TH TSP-	0.08	FL	96	B0690
FINAL DATA	84	129	001	23	1.40	M	1	100 14TH TSP+	0.27	FL	96	B0690
FINAL DATA	86	125	001	23	1.89	M	1	100 14TH TSP+	0.00	FL	96	B0690
FINAL DATA	86	128	001	36	3.85	3	96	13TH TSP+	0.70	FL	96	B0690
FINAL DATA	88	3	001	30	0.76	1	104	14TH TSP+	0.60	14TH TSP	1	B0690
FINAL DATA	88	124	001	33	1.70	M	1	95 14TH TSP+	0.03	FL	93	T4004
FINAL DATA	89	4	001	35	4.13	3	101	14TH TSP+	0.90	FL	4	H3921
FINAL DATA	89	123	001	20	1.99	M	1	118 14TH TSP+	0.08	FL	91	B0690
FINAL DATA	91	13	001	34	1.63	M	1	96 14TH TSP+	0.10	FL	4	H3921
FINAL DATA	91	41	001	25	0.84	M	1	99 15TH TSP+	0.06	FL	47	W6871
FINAL DATA	91	125	001	27	2.13	3	102	13TH TSP+	1.13	FL	90	S4373
FINAL DATA	92	117	001	22	2.35	3	106	9TH TSP -	6.20	FL	86	N0942
FINAL DATA	93	2	001	38	2.22	M	1	97 13TH TSP+	0.09	FL	5	W6871
FINAL DATA	95	116	001	28	2.07	M	1	105 14TH TSP+	0.50	FL	86	S4373
FINAL DATA	95	11	001	37	1.86	M	1	98 14TH TSP+	0.14	FL	5	W6871
FINAL DATA	95	13	001	34	2.78	3	101	14TH TSP+	0.65	FL	5	W6871
FINAL DATA			001	33	1.44	M	1	101 14TH TSP+	0.06	FL	5	W6871
FINAL DATA	95	117	001	38	1.33	M	1	93 8TH TSP -	1.37	FL	83	W6871
FINAL DATA	95	123	001	23	0.97	M	1	102 12TH TSP+	0.23	FL	83	W6871
FINAL DATA	99	123	001	25	0.64	M	1	100 14TH TSP+	0.21	FL	81	N0942
FINAL DATA	102	9	WAR	36	1.12	M	1	98 13TH TSP+	0.00	FL	8	N0942
FINAL DATA	102	13	001	31	0.75	M	1	102 14TH TSP+	0.40	FL	8	N0942
FINAL DATA	102	94	001	26	1.28	3	104	15TH TSP+	40.80	FL	105	B0690
FINAL DATA	103	8	WAR	39	1.34	M	1	94 12TH TSP+	0.00	FL	9	M7006
FINAL DATA	103	53	001	26	1.70	M	1	104 7TH TSP +	0.00	FL	9	M7006
FINAL DATA	103	116	001	26	0.75	M	1	98 14TH TSP+	0.30	FL	78	T4004
FINAL DATA	104	120	001	26	1.30	M	1	106 10TH TSP-	1.50	FL	53	B0690
FINAL DATA	108	57	001	36	1.03	M	1	98 7TH TSP +	0.10	FL	11	M7006
FINAL DATA	108	111	WAR	34	1.33	M	1	93 11TH TSP+	0.00	FL	73	N0942
FINAL DATA	108	112	001	22	1.68	M	1	99 10TH TSP-	1.29	FL	73	B0690
FINAL DATA	110	5	001	36	0.91	M	1	100 9TH TSP -	1.30	FL	12	B0690
FINAL DATA	111	1	001	24	1.50	M	1	105 12TH TSP+	0.10	FL	13	W6871
FINAL DATA			001	35	0.72	3	100	4TH TSP +	0.70	FL	13	W6871
FINAL DATA	111	3	001	37	1.09	M	1	95 14TH TSP+	0.10	FL	13	B0690
FINAL DATA	111	110	001	26	1.43	M	1	105 10TH TSP-	0.60	FL	52	B0690
FINAL DATA	112	5	001	28	1.60	M	1	102 9TH TSP -	1.40	FL	13	W6871
FINAL DATA	112	117	001	34	1.19	M	1	98 7TH TSP +	0.14	FL	52	S4373
FINAL DATA	113	6	001	29	1.03	M	1	99 9TH TSP -	1.30	FL	14	B0690
FINAL DATA	114	6	001	29	1.06	M	1	99 9TH TSP -	1.30	FL	14	B0690
FINAL DATA	116	1	001	33	1.31	3	100	14TH TSP+	7.40	FL	15	N0942
FINAL DATA	116	5	001	32	2.58	3	101	5TH TSP +	0.50	FL	15	W6871
FINAL DATA	116	22	001	37	1.59	M	1	95 10TH TSP+	0.00	FL	15	W6871
FINAL DATA	117	106	001	24	1.00	3	111	13TH TSP+	0.43	FL	50	B0690
FINAL DATA	118	97	001	35	0.97	M	1	97 8TH TSP +	0.00	FL	50	B0690
FINAL DATA	120	4	001	38	1.46	M	1	95 14TH TSP+	0.39	FL	17	T4004
FINAL DATA	121	104	001	35	1.38	M	1	98 10TH TSP+	0.00	FL	49	B0690
FINAL DATA	122	4	001	35	0.67	3	100	13TH TSP+	0.51	FL	18	M7006
FINAL DATA	123	4	001	34	1.30	M	1	97 3RD TSP +	0.05	FL	19	M7006
FINAL DATA	123	49	001	24	0.91	3	108	LTSP +	10.68	FL	18	M7006 MBM
FINAL DATA	123	89	001	34	1.21	3	102	8TH TSP +	0.53	FL	48	W6871
FINAL DATA	124	6	001	20	0.94	M	1	106 4TH TSP +	0.05	FL	19	M7006
FINAL DATA	124	11	001	22	1.90	M	1	105 14TH TSP+	0.00	FL	19	M7006
FINAL DATA	124	95	001	36	1.35	M	1	98 9TH TSP -	1.33	FL	48	W6871

EC FIELD SYSTEM (TM) (VER. 3.1) **** Thursday June 7, 1990

1:17 PM **** BABCOCK & WILCOX CO. **** Page 3

Unit: Oconee Unit 1
 Outage: 05/90 RFO

Steam Generator: B

INDICATIONS 20-39% TMD

TEST	ROW	COL	IND	XTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
FINAL DATA 128	92	001	28	0.57	M 1	105	9TH	TSP -	0.16	FL	23	T4004
FINAL DATA		001	31	0.67	M 1	103	9TH	TSP -	1.31	FL	23	T4004
FINAL DATA 129	54	001	36	0.84	3	101	7TH	TSP +	0.75	FL	24	H3921
FINAL DATA 130	93	001	28	0.95	M 1	107	14TH	TSP+	0.08	FL	25	T4004
FINAL DATA 131	5	001	34	1.01	M 1	93	13TH	TSP+	0.08	FL	26	N0942
FINAL DATA 131	9	001	21	0.94	3	113	14TH	TSP+	0.59	FL	26	H3921
FINAL DATA 134	11	001	26	0.76	M 1	105	9TH	TSP -	1.49	FL	28	M7006
FINAL DATA 136	4	001	36	0.63	M 1	100	14TH	TSP+	0.41	FL	31	N0942
FINAL DATA 136	8	001	26	1.15	M 1	107	10TH	TSP-	1.43	FL	31	M7006
FINAL DATA 138	5	001	25	2.42	M 1	110	14TH	TSP+	0.64	FL	33	T4004
FINAL DATA 138	16	001	34	0.99	M 1	103	10TH	TSP+	0.18	FL	33	T4004
FINAL DATA 138	58	001	31	0.64	M 1	105	9TH	TSP -	0.29	FL	33	T4004
FINAL DATA 139	19	001	36	1.14	M 1	96	9TH	TSP -	1.52	FL	34	M7006
FINAL DATA 139	56	001	21	0.80	M 1	107	10TH	TSP-	1.61	FL	34	M7006
FINAL DATA 139	74	001	39	1.88	M 1	94	12TH	TSP+	0.24	FL	34	M7006
FINAL DATA 141	34	001	24	0.75	3	108	UTSF	-	0.70	FL	36	B0690
FINAL DATA 141	64	001	28	0.91	3	105	14TH	TSP+	0.54	FL	36	B0690
FINAL DATA 142	14	001	33	1.67	M 1	99	9TH	TSP -	1.39	FL	37	W6871
FINAL DATA 142	49	001	38	0.95	M 1	88	10TH	TSP-	1.45	FL	37	B0690
FINAL DATA 143	14	001	37	1.53	M 1	94	9TH	TSP -	1.47	FL	38	T4004
FINAL DATA 143	17	001	36	0.78	M 1	95	9TH	TSP -	1.45	FL	38	T4004
FINAL DATA 143	56	001	30	1.84	3	105	7TH	TSP +	0.44	FL	37	W6871
FINAL DATA 144	54	001	20	0.70	3	113	10TH	TSP-	6.72	FL	39	W6871
FINAL DATA 145	3	001	27	0.51	3	108	14TH	TSP+	0.41	FL	40	W6871
FINAL DATA 145	52	001	24	0.95	M 1	105	7TH	TSP -	0.05	FL	39	W6871
FINAL DATA 146	5	001	33	2.40	3	103	UTSF	-	1.10	FL	40	W6871
FINAL DATA 146	50	001	34	0.92	3	102	7TH	TSP +	0.92	FL	40	W6871
FINAL DATA 148	13	001	21	1.04	M 1	107	9TH	TSP +	0.00	FL	41	S4373
FINAL DATA 148	34	001	37	0.80	M 1	90	14TH	TSP+	0.87	FL	41	B0690
FINAL DATA 149	10	001	21	0.76	3	113	6TH	TSP +	1.50	FL	42	B0690
FINAL DATA 149	29	001	25	1.11	M 1	108	10TH	TSP+	0.00	FL	42	B0690
FINAL DATA 149	32	001	29	1.01	3	105	14TH	TSP+	0.44	FL	42	S4373
FINAL DATA 150	13	001	25	1.22	M 1	105	8TH	TSP +	0.10	FL	42	B0690

TOTAL TUBES FOUND = 168
 TOTAL INDICATIONS FOUND = 173
 TOTAL TUBES IN INPUT FILE = 15531

** B&W TUBAN(TM) (VER. 3.1)***** Thursday June 7, 1990 02:28 PM **

Plant: OCONEE UNIT 1

Steam Generator: B

Order: Sort by ROW, TUBE

Title: TUBES PLUGGED 5/90 RFO

NO.	ROW	TUBE
1.	9-	36
2.	11-	47
3.	19-	15
4.	20-	54
5.	22-	93
6.	24-	86
7.	25-	88
8.	26-	88
9.	27-	9
10.	29-	88
11.	30-	105
12.	32-	72
13.	35-	73
14.	43-	115
15.	43-	116
16.	44-	118
17.	44-	119
18.	45-	1
19.	50-	119
20.	52-	3
21.	52-	4
22.	61-	125
23.	63-	28
24.	68-	119
25.	69-	4
26.	86-	16
27.	93-	7
28.	94-	2
29.	94-	12
30.	94-	119
31.	95-	128
32.	103-	54
33.	116-	6
34.	116-	105
35.	118-	20
36.	125-	93
37.	128-	20
38.	128-	35
39.	130-	84
40.	131-	82
41.	132-	8
42.	135-	3
43.	136-	3
44.	137-	18
45.	139-	65
46.	140-	3
47.	140-	9
48.	140-	17
49.	145-	52



Cock & Wilcox
a McDermott company

VOLUMETRIC TEST DATA

CUSTOMER: Duke Power Co. Oconee Unit I CONTRACT NO.: 702-2034 COMPONENT: STEAM GEN. 1B (VESSEL)

DESCRIPTION: STEAM GEN. 1B (UPPER HEAD TO TUBE SHEET. Pg 8 To 51) THERMOMETER: OCQA-223

I.D. NO.: ISGB-WG58-1 PROCEDURE: ISI-130 REV. 24 MATERIAL: C/S THICKNESS: 8.5" TEST SURF.: OD

NO. POSITIONS: 36 DISTANCE: 12.0" NO. REFERENCE: 20 CAL. SHEET: 901023 CAL. SHEET: 901010 CAL. SHEET: 901011 CAL. SHEET:

BEAM DIRECTION: LONG SHEAR LIMITED EXAM: NO YES? ANGLE: 0 ANGLE: 45 ANGLE: 60 ANGLE:

EXAMINER: DJ Moss / D.L. Robison ID NO.: M-8280 LEVEL: II TIME START: 1242 HR. TIME START: 1830 HR. TIME START: 1230 HR. TIME START: A HR.

EXAMINER: J.W. Sizer / J. Bill ID NO.: 8949 LEVEL: II TIME STOP: 1457 HR. TIME STOP: 2020 HR. TIME STOP: 1830 HR. TIME STOP:

NOTES: INDICATION #200 MEAS. TAKEN FROM TUBE SHEET TAP PART TEMP: 88 °F PART TEMP: 88 °F PART TEMP: 88 °F PART TEMP: °F

#1 REF. STARTS AT X-AXIS DATE: 5-6-90 DATE: 5-6-90 DATE: 5-6-90 DATE:

old data states W-AXIS CAL. BLK.: 40305 WELD INFORMATION & 0° THICKNESS

No MAX TWD DIMENSION WAS OBTAINABLE DUE TO THE GEOMETRY WHERE THE HEAD RADIUS STARTS (40Z) ONLY. DWG. NO.: OM-201-1878 SURFACE NO.2 HTH: FLUSH SURFACE NO.1

1ST SCAN N/A 60° REQUIRED CAT. 89.006 Tube Sheet 8.44 UPPER HEAD

2ND SCAN N/A 60° NOT REQUIRED BM: N/A MIN: 8.3 BM: 9.045

HAZ: N/A MAX: 8.6 HAZ: 8.743

INDICATION NO(S)	POSITION OR PART ITEM		ANGLE (DEGREES)	SURFACE	BEAM DIRECTION	STATUS	L.A.M.			CRystal DISTANCE FROM (INCHES)				THROUGH WALL DIMENSION				DAMPS	REMARKS				
	A	B					MAX. AMP. %DAC	DEPTH (INS)	20%	50% / HMA	100%	MINIMUM		MAXIMUM		DEPTH	POSITION (INCHES)			DEPTH	POSITION (INCHES)		
												A	B	A	B		I				2	I	2
	LENGTH							A	B	I	2	DEPTH	A	B	A	B							
	360°		0°			No	RECORDABLE INDICATIONS																
200	27 to 28		45°	1	2	SEP.	282	7.437		6.1		5.4	10.75	7.135		10.15	7.638	11.2	No				
							50	7.437				1.6	10.5							50% EP			
							50	7.337				7.7	10.5							50% EP			
							224	7.235				4.5	10.3	7.135		10.0	7.738	11.0	No				
							224	7.537				3.6	10.6	7.135		9.9	7.737	10.8	No				
							125	7.235				2.7	10.5	7.235		10.2	7.738	11.0	No				
							50	7.235				1.8	10.5	7.135		10.0	7.638	11.0	No				
							125	7.538				6.3	10.5	7.135		10.0	7.537	10.9	No				
							50	7.336				7.2	10.5	7.135		10.2	7.537	11.0	No				
	360°		45°			No	OTHER RECORDABLE INDICATIONS																

REVIEWED BY: Howard Stojilman LEVEL: II DATE: 8 MAY '90 FIGURE NO.: B02.040.003

ANGLE: 0 DEG. 45 DEG. 60 DEG. OTHER E.R. REQUIRED: YES NO E.R. NUMBER: 901-002

IND. NOS. 1 TO 199 200 TO 399 400 TO 599 600 TO 799 PAGE 1 OF 8

VOLUMETRIC TEST DATA FORM 101

BWNP-20531-3 (10-84)

CUSTOMER: DUKE POWER CO. O'CONNOR I						CONTRACT NO: 702-2034				COMPONENT: VESSEL SGB											
EXAMINER: J.W. Setzer			ID# S-5643			LEVEL II			DATE(S): 5-6-90												
EXAMINER: J. Bill			ID# B-9449			LEVEL II															
IND. NO.	POSITION OR PART ITEM	ANGLE (DEG)	SURFACE	BEAM DIRECTION	STATUS	LAM.			(INCHES)				THROUGH WALL DIMENSION				DAMPS	REMARKS			
						MAX AMP % DAC	DEPTH (IN.)	20%	50% OR HMA	100%	CRYSTAL		DISTANCE FROM		MINIMUM				MAXIMUM		
											A	B	I	2	POSITION IN.				DEPTH	POSITION IN.	
															A	B				A	B
400	25 to 27	60	1	2	SEP	125	7.3		1.0		12.0		12.6	7.1		12.0	7.5		13.1	NO	
						50	7.4				11.6										
						50	7.3				12.6										
401	20 to 21	60	1	2	SEP	80	7.1		1.5		2.5		12.0	6.9		11.5	7.2		12.1	NO	
						50	7.1				2.0										
						50	7.1				3.5										
402	27 to 28	60	1	2	SEP	251	6.8		4.4		5.1		13.2	6.6		12.9					NO
						50	6.8				2.8		13.2								
						50	6.8				7.2		13.2								
						251	6.8				3.7		13.2	6.6		12.9					
						251	6.8				4.6		13.2	6.6		12.9					
						200	6.8				5.5		13.2	6.6		12.9					
						159	6.8				6.4		13.2	6.6		12.9					
	360°	60				NO OTHER RECORDABLE INDICATIONS															

} SEE NOTES

REVIEWED BY: Harold Stoppelman LEVEL: II DATE REVIEWED: 8 MAY '90 FIGURE NO.: B02-040.003



Babcock & Wilcox
 a McDermott company
 SPECIAL PRODUCTS
 AND
 INTEGRATED FIELD SERVICE

ISI, LIMITED EXAMINATIONS

CUSTOMER: DUKE POWER COMPANY, SITE: OCONEE, UNIT: I
 CONTRACT NO.: 702-2034
 COMPONENT: STEAM GENERATOR, I.D. NO.: ISGB-WG58-1

TEST METHOD: U.T.

BWNP

(7-87)

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 3 AND 5 8.5 INCHES FROM POINT 3 TO 8.5
 INCHES FROM POINT 5 10 INCHES FROM WELD ξ TO beyond INCHES FROM
 WELD ξ
 ANGLE(S) 0° 45° 60° ___° ___° ___° N/A
 DUE TO: Scub in Shipping Tie Down Removal AREA


NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS ___ AND ___ INCHES FROM POINT ___ TO ___
 INCHES FROM POINT ___ INCHES FROM WELD ξ TO ___ INCHES FROM
 WELD ξ
 ANGLE(S) 0° 45° 60° ___° ___° ___° N/A
 DUE TO: _____

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
360 DEGREES. 3.5 INCHES FROM WELD ξ TO beyond INCHES FROM WELD ξ
 ANGLE(S) 0° 45° 60° ___° ___° ___° N/A
 DUE TO: Tape on Tube sheet AREA

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 ___ DEGREES. ___ INCHES FROM WELD ξ TO ___ INCHES FROM WELD ξ
 ANGLE(S) 0° 45° 60° ___° ___° ___° N/A
 DUE TO: _____

NOTES: _____

SKETCH:



SEE ATTACHMENT NO(S): _____

REVIEWED BY: Howard Stappelman LEVEL: II DATE: 8 MAY '90
 REVIEWED BY: _____ DATE: _____

FIGURE NO.: B02.040.003



Babcock & Wilcox
 a McDermott company
 SPECIAL PRODUCTS
 AND
 INTEGRATED FIELD SERVICE

ISI, LIMITED EXAMINATIONS

CUSTOMER: DUKE POWER COMPANY, SITE: OCONEE, UNIT: I
 CONTRACT NO.: 702-2034
 COMPONENT: STEAM Generator, I.D. NO.: ISGB-WG58-1

TEST METHOD: U.T.

BWNP

(7-87)

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 33 AND 34 . 0.0 INCHES FROM POINT 33 TO 2.0
 INCHES FROM POINT 34 . 10 INCHES FROM WELD ξ TO beyond INCHES FROM
 WELD ξ
 ANGLE(S) 0° 45° 60° ° ° ° N/A
 DUE TO: Scrub in shipping tie Down Removal Area

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 35 AND 3 . 5.0 INCHES FROM POINT 35 TO 5.0
 INCHES FROM POINT 3 . 19.5 INCHES FROM WELD ξ TO beyond INCHES FROM
 WELD ξ
 ANGLE(S) 0° 45° 60° ° ° ° N/A
 DUE TO: MANWAY

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ
 ANGLE(S) 0° 45° 60° ° ° ° N/A
 DUE TO: _____

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ
 ANGLE(S) 0° 45° 60° ° ° ° N/A
 DUE TO: _____

NOTES: _____

SKETCH: _____

 SEE ATTACHMENT NO(S): _____

REVIEWED BY: Houred Stogelma LEVEL: II DATE: 8 MAY '90
 REVIEWED BY: _____ TITLE: _____ DATE: _____

FIGURE NO.: B02.040.003



Babcock & Wilcox
 a McDermott company
 SPECIAL PRODUCTS
 AND
 INTEGRATED FIELD SERVICE

ISI, LIMITED EXAMINATIONS

CUSTOMER: DUKE POWER COMPANY, SITE: OCONEE, UNIT: I
 CONTRACT NO.: 702-2034
 COMPONENT: STEAM GEN B, I.D. NO.: ISGB-VG 58-1

TEST METHOD: UT

BWNP

(7-87)

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 26 AND 30 6 INCHES FROM POINT 26 TO 6
 INCHES FROM POINT 30 15 INCHES FROM WELD ξ TO _____ INCHES FROM
 WELD ξ AND BEYOND
 ANGLE(S) 0° 45° 60° ° ° ° N/A
 DUE TO: SUPPORT PAD

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 4 AND 5 3.5 INCHES FROM POINT 4 TO 6.5
 INCHES FROM POINT 5 8.5 INCHES FROM WELD ξ TO 11.5 INCHES FROM
 WELD ξ
 ANGLE(S) 0° 45° 60° ° ° ° N/A
 DUE TO: 1 1/2" Ø VENT CONN.

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ

 ANGLE(S) 0° 45° 60° ° ° ° N/A
 DUE TO: _____

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ

 ANGLE(S) 0° 45° 60° ° ° ° N/A
 DUE TO: _____

NOTES: _____

SKETCH: _____

 SEE ATTACHMENT NO(S): _____

REVIEWED BY: Howard Stogdeman LEVEL: II DATE: 8 MAY '90
 REVIEWED BY: _____ TITLE: _____ DATE: _____

FIGURE NO.: B02.040.003



Babcock & Wilcox
 a McDermott company
 SPECIAL PRODUCTS
 AND
 INTEGRATED FIELD SERVICE

ISI, LIMITED EXAMINATIONS

CUSTOMER: DUKE POWER COMPANY, SITE: OCONEE, UNIT: I
 CONTRACT NO.: 702-2034
 COMPONENT: STEAM GEN B, I.D. NO.: ISGB-WG 5B-1

BWNP (7-87)

TEST METHOD: UT

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 12 AND 16 6 INCHES FROM POINT 12 TO 6
 INCHES FROM POINT 16 15 INCHES FROM WELD ξ TO _____ INCHES FROM
 WELD ξ AND BEYOND
 ANGLE(S) 0° 45° 60° _____° _____° N/A
 DUE TO: SUPPORT PAD

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 19 AND 23 6 INCHES FROM POINT 19 TO 6
 INCHES FROM POINT 23 15 INCHES FROM WELD ξ TO _____ INCHES FROM
 WELD ξ AND BEYOND
 ANGLE(S) 0° 45° 60° _____° _____° N/A
 DUE TO: SUPPORT PAD

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ
N/A
 ANGLE(S) 0° 45° 60° _____° _____° N/A
 DUE TO: _____

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ
N/A
 ANGLE(S) 0° 45° 60° _____° _____° N/A
 DUE TO: _____

NOTES: _____

SKETCH: _____

 SEE ATTACHMENT NO(S): _____

REVIEWED BY: Howard Stapp LEVEL: II DATE: 8 MAY '90
 RE VIEWED BY: _____ TITLE: _____ DATE: _____

FIGURE NO.: B02.040.003



Babcock & Wilcox
 a McDermott company
 SPECIAL PRODUCTS
 AND
 INTEGRATED FIELD SERVICE

ISI, LIMITED EXAMINATIONS

CUSTOMER: DUKE POWER COMPANY, SITE: OCONEE, UNIT: I
 CONTRACT NO.: 702-2034
 COMPONENT: SG B, I.D. NO.: 1 SGB-VG58-1

BWNP

(7-87)

TEST METHOD: UT

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 33 AND 2 7 INCHES FROM POINT 33 TO 6
 INCHES FROM POINT 2 15 INCHES FROM WELD ξ TO _____ INCHES FROM
 WELD ξ AND BEYOND.
 ANGLE(S) 0° 45° 60° _____° _____° N/A
 DUE TO: SUPPORT PAD

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 5 AND 9 6 INCHES FROM POINT 5 TO 6
 INCHES FROM POINT 9 15 INCHES FROM WELD ξ TO _____ INCHES FROM
 WELD ξ AND BEYOND.
 ANGLE(S) 0° 45° 60° _____° _____° N/A
 DUE TO: SUPPORT PAD

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ
 n/a
 ANGLE(S) 0° 45° 60° _____° _____° N/A
 DUE TO: _____

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ
 n/a
 ANGLE(S) 0° 45° 60° _____° _____° N/A
 DUE TO: _____


NOTES: _____

SKETCH: _____

 SEE ATTACHMENT NO(S): _____

REVIEWED BY: Howard Higgins LEVEL: II DATE: 8 MAY '90
 REVIEWED BY: _____ TITLE: _____ DATE: _____

FIGURE NO.: B02-040.003




COMMENTS:

GEOMETRIC

REPORTABLE

CUSTOMER:	DURE POWER CO OGONEE 1
PROJECT NO:	702-2034
WELD NO:	1SG3-WG 58-1
ANALYST:	
SNT LEVEL:	
DATE:	
FIGURE NO:	B02.040.003

ATTACHMENT TO B02.040.003



D.L. Robinson
5-7-90

DUKE POWER COMPANY

PROJECT O CONEE UNIT 1

ISI VISUAL EXAMINATION VT-3 AND VT-4 HANGERS

SN/012

W.R. # / NSM <u>N/A</u>		<input type="checkbox"/> PSI <input checked="" type="checkbox"/> ISI	
INSPECTOR	LEVEL	DATE	PROCEDURE
<u>P. S. Eberhart</u>	<u>II</u>	<u>5-3-90</u>	<u>QCL-14</u>
<u>W.C. Lund</u>	<u>II</u>	ACTUAL SYSTEM TEMPERATURE	REV. <u>9</u>
		<u>N/A</u>	VISUAL METHOD:
		SYSTEM STATUS	<input checked="" type="checkbox"/> DIRECT <input type="checkbox"/> REMOTE
		HOT <input type="checkbox"/> COLD <input checked="" type="checkbox"/> OTHER <input type="checkbox"/>	VISUAL AIDS/M&TE SN:
		(EXPLAIN IN COMMENTS)	FLASHLIGHT
			MIRROR
			TAPE

S/R NUMBER	REV.	I.D. NUMBER	ITEM NUMBER
<u>1-51A-0-479A-H7A</u>	<u>D2</u>	<u>1-51A-H7A</u>	<u>F1.01.083</u>

RESULTS: ACCEPTABLE UNACCEPTABLE, (REQUIRES NDE, EVALUATION OR REPAIR)


IND. NO.	INDICATION TYPE	LENGTH	WIDTH	REMARKS
<u>1</u>			<u>"</u>	<u>U-BOLT IS MISSING FROM HANGER</u>

MECHANICAL SHOCK SUPPRESSOR			MECHANICAL SHOCK SUPPRESSOR		
	A	B		C	D
HOT SETTING			HOT SETTING		
COLD SETTING	<u>N/A</u>	<u>N/A</u>	COLD SETTING	<u>N/A</u>	<u>N/A</u>
ACTUAL PISTON SETTING			ACTUAL PISTON SETTING		


VARIABLE SPRING SUPPORTS			HYDRAULIC SHOCK SUPPRESSOR		
	A	B		A	B
HOT LOAD			FLUID LEVEL		
COLD LOAD	<u>N/A</u>	<u>N/A</u>	HOT SETTING	<u>N/A</u>	<u>N/A</u>
LOAD IND. READING			COLD SETTING		

CONSTANT SUPPORT			ACTUAL PISTON SETTING		
	A	B	COMMENTS DISPOSITION		
HOT LOAD					
COLD LOAD	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>		
POSITION IND. READING					


TOTAL NO. OF DIV. SCALE	PIR: <input checked="" type="checkbox"/> YES <input checked="" type="checkbox"/> NO	SERIAL NO. <u>N/A 1-040-0046</u>
QA REVIEW <u>T. J. Coleman</u>	DATE <u>5-29-90</u>	ANII REVIEW <u>R. P. Elgin</u> ANII/ANII DATE <u>5-29-90</u>



Pg 20 of 3



NOTE
 WORK THIS DWG
 W/HANGER NO'S:
 14-O-480A-H211A
 14-O-480A-H211B
 14-O-480A-H211C
 14-O-480A-H211D
 14-O-480A-H211E
 14-O-480A-H211F
 51A-O-479A-H19C
 51A-O-479A-H19E



S/R Calc. # OSC-13004.07

FOR INFORMATION ONLY

ELEVATION A FOR INSERVICE INSPECTION USE ONLY

FL 01.083 1-51A-H7A


D2	As Built Per IEB 79-14 Impl. Date: 3-29-89		RH	5-17-89	PCG	6-16-89	SAC	6-24-89
Δ	REVISED PER IEB 79-14		SR	9-10-81	ME	9-10-81	DIR	9-22-81
REV	DESCRIPTION		BY	DATE	CHK	DATE	APPR	DATE
Δ	3/30/81	REVISED & REDRAWN PER IEB 79-14	SBM	3/30/81	PCG	3/30/81	PCG	3/30/81
REV. DATE	REVISIONS		INSP	CHK	CHK	DATE	APPR	DATE
DUKE POWER CO. Oconee Nuclear Station						STRESS ISO 0-492B-2(5)		
Isa. Drawing No.	Item No.	Unit No.				REP. DWG.	COMPOSITE 0-479A	
-1RB-15115-01	9	1	JOB NO.			HANGER NO.		REV.
PIPESUPPORTS			13312-002			51A-O-479A-H7A		D2
H.P. INJECTION SYS. EAST COOLANT LOOP-NORTH LEG						SHT. 1 OF 2		

ITEM NO.	NO. REQ'D	SIZE	DESCRIPTION	ASTM	LOT NUMBER	BY
1		1/2" x 2 1/2" FIG. 137 U-BOLT			294-1017F	H.C.


Dwg 3013

SUPPORT DATA		
	"X" RIGID	"Y" RIGID
T (THERMAL LOAD)	5	-5
D (DEAD LOAD)	0	-98
DE (OBE)	61	16
MHE (SSE) (OBE)	122	32
DE+T+D	+78/-61	+0/-119
MHE+T+D	+138/-122	+0/-135

MOVTS."	X	Y	Z
THERMAL	—	—	.219
DBE SEISMIC	.001	—	.150



PROBLEM NO. 1-51-15 SYSTEM NO. 51A
 ISSUE 0
 DATA PT. 345 NUCLEAR CLASS



This Drawing Supersedes Bechtel
 Dwg. No. N/A Rev. Date



DUKE POWER COMPANY

PROJECT OCONEE NUCLEAR STA. UNIT 1

QA CONDITION 1

SHEET NO. 2 OF 2 REV. D2
 MARK NO. 51A-0-479A-H7A

Attachment to Form QCL-14A

SERIAL NO. SN/012

SUPPORT NO. 1-51A-0-479A-H7A

QA ITEM NO. FL01.083

Design Engineering Comments/Disposition:

Design Engineering Review has found this support to be unacceptable for service as a lateral pipe restraint. However, further evaluation has verified that the pipe system is acceptable for service as found. A PIR will be written and additional samples will be performed as required by Q.A. per ASME Code (Winter 1980), Sect. 11, Subsection IWF2430(A). The support sketch will be revised to reflect the existing condition.

Approved by: S J Crews

Date: 5/15/90

6.0 Class 2 Inspection Results

Inspections were performed during Outage 12 on Steam Generator 1B, piping integrally-welded attachments, piping welds of Low Pressure Injection, Reactor Building Spray and High Pressure Injection Systems, Main Steam Valve, and supports.

6.1 Steam Generators

Steam Generator 1B Shell to Shell Weld received an ultrasonic examination. No reportable indications were found.

6.2 Piping

Welds one-half inch and less nominal wall thickness:

Nineteen (19) circumferential welds and two (2) longitudinal welds received a dye penetrant examination. No reportable indications were found.

One (1) pipe branch circumferential weld received a dye penetrant examination. No reportable indications were found.

Piping integrally-welded attachments:

Two (2) attachments of the Main Steam System and one (1) attachment of the Main Feedwater System received a magnetic particle examination. An alternate examination was performed on one (1) attachment of the Main Feedwater System (see Section 7 of this report). Three (3) attachments of the Low Pressure Injection System and two (2) attachments of the Reactor Building Spray System received a dye penetrant examination. No reportable indications were found.

6.3 Valves

Main Steam Turbine Stop Valve SV1 Head-to-Body Studs received an ultrasonic examination in place. The examination was performed from the top of the studs to the last two (2) threads engaged in the valve body (refer to Request for Relief ONS-009, NPD Licensing Serial No. 89-04, included in Section 10 of this report). No reportable indications were found.

6.4 Component Supports

Forty-one (41) Class 2 Component Supports received a visual examination as required by ASME Section XI, Article IWF-2000. No reportable conditions were found.

6.5 System or Component Functional Test

A Class 2 Functional Test was performed as required by ASME Section XI, Article IWC-5000. No reportable conditions were found.

6.6 Class 2 Repairs and Replacements

Repairs and replacements for work performed from February 14, 1989 to June 4, 1990 are itemized in Section 11 of this report.

7.0 Augmented Inspection and Alternate Examination Results

Augmented inspections were performed on Reactor Coolant Pump 1B2 Flywheel.

An alternate examination was performed on a Main Feedwater Integrally-Welded Attachment.

7.1 Reactor Coolant Pump Flywheel

Reactor Coolant Pump 1B2 Flywheel received an ultrasonic and a magnetic particle baseline examination. No reportable indications were found.

7.2 Alternate Examination

Main Feedwater Integrally-Welded Attachment (for Support No. 03-0-480A-H9B), Item No. C03.040.038, received a visual examination in lieu of the applicable surface examination specified in ASME Section XI Table IWC-2500-1 Category C-C, due to the physical location of the attachment. In compliance with the Inservice Inspection Program, Request for Relief ONS-013 was submitted to the NRC. A copy of the relief is included in Section 10, and a copy of the inspection data sheet is included in this section of the report.

No reportable conditions were found during the visual examination.

RECEIVED

DUKE POWER COMPANY

MAY 24 1990

PROJECT DOWNER UNIT 1

DIVISION/CENTRAL RECORDS

ISI VISUAL EXAMINATION VT-3 AND VT-4 HANGERS

SN/028

File No.: _____

WR # / NSM <u>N/A</u>		= PSI = ASI	
INSPECTOR	LEVEL	DATE	PROCEDURE
<u>P.S. Eberhart/TAK</u>	<u>II</u>	<u>5-23-90</u>	<u>QAL-14</u>
ACTUAL SYSTEM TEMPERATURE		REV. <u>10</u>	
<u>N/A</u>		VISUAL METHOD	
		<input checked="" type="checkbox"/> DIRECT <input type="checkbox"/> REMOTE	
SYSTEM STATUS		VISUAL AIDS/M&T E SN.	
HOT <input type="checkbox"/> COLD <input checked="" type="checkbox"/> OTHER <input type="checkbox"/>			
(EXPLAIN IN COMMENTS)		<u>Flashlight - Mirror</u>	
S/R NUMBER	REV.	I.D. NUMBER	ITEM NUMBER
<u>1-03-0-480A-149B</u>	<u>D1</u>	<u>1-03-149B</u>	<u>1-03-040-038-VT</u>

RESULTS: ACCEPTABLE UNACCEPTABLE. (REQUIRES NDE, EVALUATION OR REPAIR)


IND. NO	INDICATION TYPE	LENGTH	WIDTH	REMARKS
<u>1</u>	<u>under cut</u>		<u>1/32 to 3/32</u>	<u>some welds have undercut the entire length others vary from 1/4" to 1" long</u> <u>520 Attached.</u>

MECHANICAL SHOCK SUPPRESSOR		MECHANICAL SHOCK SUPPRESSOR	
A B		C D	
HOT SETTING		HOT SETTING	
COLD SETTING	<u>N/A</u>	COLD SETTING	<u>N/A</u>
ACTUAL PISTON SETTING		ACTUAL PISTON SETTING	
VARIABLE SPRING SUPPORTS		HYDRAULIC SHOCK SUPPRESSOR	
A B		A B	
HOT LOAD		FLUID LEVEL	
COLD LOAD	<u>N/A</u>	HOT SETTING	<u>N/A</u>
LOAD IND. READING		COLD SETTING	
CONSTANT SUPPORT		ACTUAL PISTON SETTING	
A B			
HOT LOAD		COMMENTS/DISPOSITION	
COLD LOAD	<u>N/A</u>	<u>undercut present on Attachments 1 thru 12</u> <u>as noted above TPL 5-23-90</u>	
POSITION IND. READING			
TOTAL NO. OF DIV. SCALE		PIR: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	SERIAL NO: <u>N/A</u>
QA REVIEW	<u>T.J. Coleman</u>	DATE	ANII REVIEW
		<u>5-30-90</u>	<u>R.F. Elgin ANII</u>
			DATE
			<u>5-30-90</u>

- #1 THRU #5 - 1/4" FILLET WELD BOTH SIDES
- #6 - 3/16" FILLET WELD BOTH SIDES
- #7 - 1/8" to 3/16" FILLET WELD BOTH SIDES
- #8 - (A) 1/8" (B) NO WELD *
- #9 THRU #11 - WELD IS PRESENT
- #12 - (A) 1/8" (B) 1/4" *

* A - 1st SIDE OF LUG ENCOUNTERED GOING CCW FROM #1
 B - 2ND SIDE "

1-03-0-480A-H9B
 REV. D1




LKG. SOUTH

DIMENSIONS GIVEN ARE NOT MEASUREMENTS - THEY ARE THE RESULTS OF A VISUAL INSPECTION USING A MIRROR AND A FLASHLIGHT. THIS INSPECTION WAS DONE WHILE WEARING A PARTICULATE MASK, MAKING IT VIRTUALLY IMPOSSIBLE TO SEE #'S 9-11.


PSE 5-22-90

- #9 Top weld has $\frac{1}{4}$ " partial Penetration weld with $\frac{1}{32}$ " undercut 1" in and $\frac{1}{32}$ " undercut $\frac{3}{4}$ " Long in Center of the weld. Bottom weld is $\frac{3}{8}$ " P.P. entire length with no undercut
- #10 Top weld is $\frac{5}{16}$ " P.P. $\frac{3}{4}$ " in on weld there is $\frac{1}{32}$ " undercut $\frac{1}{4}$ " long. Bottom weld is $\frac{3}{8}$ " P.P. entire length with no undercut
- #11. Top weld is $\frac{5}{16}$ " P.P. entire length of Bottom weld is $\frac{5}{16}$ " P.P. entire length $\frac{1}{16}$ " low entire length.




LKG North

SHIM IS REQUIRED PER SECTION 7.70 OF
 OS-002.00-05-0002 EXCEPT
 SHIMS ARE TO EXTEND TO A MINIMUM
 16 IN. ALL LENGTH OF THE SADDLE
 AND HAVE A MINIMUM WIDTH OF 5 IN.
 MAY EXTEND 4" PAST EDGES OF SLEAVE
 TO ALLOW WELDING OUTSIDE OF SLEAVE.
 SHIM THICKNESS SHALL BE SELECTED
 BASED ON THE MINIMUM TAP SIZE
 OVER THE SHIM AREA.




CLIP (IF BOTH
 ENDS & PLACES)
 [WHERE ACCESSIBLE]

SECTION 'A-A'



PLAN

* LOADS WITH FEEDWATER
 HEADER SUPPORTS
FOR INSERVICE INSPECTION USE ONLY



LOCATION PLAN

COS. 040.058
 WEST Side 2nd Level F102.140 1-03-1978

ITEM NO.	MATERIALS AND OPERATIONS	ITEM NO.																
01	PIPE GUIDE CONSISTING OF:																	
1	1. Saddle/sk. As Drawn A TV-2467																	
2	2. Plate A Top																	
3	3. MHE 03-0-480A-49B																	
	NOTE: SEE DRAWING ATTACHED TO ABOVE MAT'L.																	
FOR INFORMATION ONLY																		
SIB CALC. NO. 196-1297-07																		
X RIGID																		
<table border="1"> <tr> <td></td> <td>X</td> <td>Y</td> <td>Z</td> </tr> <tr> <td>THERMAL</td> <td>.000</td> <td>.000</td> <td>-.814</td> </tr> <tr> <td>558</td> <td></td> <td></td> <td></td> </tr> <tr> <td>250000</td> <td>.000</td> <td>.000</td> <td>.621</td> </tr> </table>		X	Y	Z	THERMAL	.000	.000	-.814	558				250000	.000	.000	.621		
	X	Y	Z															
THERMAL	.000	.000	-.814															
558																		
250000	.000	.000	.621															
PROJECT NO.	1-03-03	SYSTEM NO.	03															
ISSUE	0																	
DATA PT.	370	NUCLEAR CLASS																
FOR INSERVICE INSPECTION USE ONLY																		
NOTE: THIS DRAWING SUPERSEDES BECHTEL SKETCH 04905-17.REV. 0 D, DATED 7-17-70																		
F102.140 1-03-1978																		
QA CONDITION 1																		
DUKE POWER CO.																		
DORCHESTER NUCLEAR POWER STATION - UNITS 1, 2, & 3																		
PIPING SUPPORT DETAIL																		
03-0-480A-49B																		
DRN.	HLU	4/15/81	CHKD. DP	4-28-81														
INSP.	WSP	5/14/81	APPR. OLP	5/11/81														
SCALE: NONE			SHT. 1 OF 9	REV. DI														


SECTION DATA	LOADS	REACTOR
DESIGN	T (THERMAL LOAD)	-7672
OPERATING	D (DEAD LOAD)	-1039
TEMPERATURE	DE (DEAD)	16381
OR TEMPERATURE	MHE (558)	57682
OR	DE + T + D	+15366 / -23118
OR	MHE + T + D	+51709 / -41459




BY: [Signature] DATE: [Date]
 2. BASED ON 16A T-14 BY [Signature]

CUSTOMER DUKE POWER CO.
 ORDER OR CONT. No. 57-HDW-1678
 JOB NAME OCONEE NUC. STA. UNIT # 1

* This drawing supersedes Grinnell Sketch
 No. O-4908-17A Rev. 0 Dated 6/19/70



DETAIL "A"



SECTION A-A
FOUR (4) REQ'D.

MATERIALS AND OPERATIONS		QUAN.	SHIP
Plate assembly as detailed above, TW-236 #		4	
FOR INFORMATION ONLY			
FOR INSERVICE INSPECTION USE ONLY			

F. DRW'G. Nos. PIPE _____
 STEEL _____

MARK No. 03-0-480A-H9B

SHT. 2 OF 3

REV. DI


ITEM NO.	QTY REQD	PART NO.	SIZE	DESCRIPTION	MATERIAL

"Y" RIGID

FOR INFORMATION ONLY

FOR INSERVICE INSPECTION USE ONLY

SUPPORT DATA	
T (THERMAL LOAD)	21699
D (DEAD LOAD)	-6874
DE (OBE)	* 11949
MHE (SSE)	* 23897
DE+T+D	+27148/-19197
MHE+T+D	+39096/-31145



MOVES. "	X	Y	Z
THERMAL	.000	.000	-.814
SSE SELECT	.000	.000	.639

PROBLEM NO. 1-03-05 SYSTEM NO. 03
 ISSUE 0
 DATA FT. 370 NUCLEAR CLASS

M 0 3
MASTER FILE
 ON CONDITION 1

* LOADS WITH FEEDWATER HEADER SUPPORTS
 ** LOADS WITHOUT FEEDWATER HEADER SUPPORTS

△															
USA	-	SEE SH. 1 OF 3													
▲	11/20	REVISED PER IEB 79-14													
REV. DATE															

DUKE POWER CO. Oconee Nuclear Station				STRESS ISO 0-490B-3(3)		
Iss. Drawing No.	Item No.	Unit No.		REP. COND.	COMPOSITE	
0-490B-3	2	1	CIVIL			
PIPE SUPPORTS			JOB NO.	HANGER NO.	RE	
MAIN FEEDWATER SYS. WEST GENERATOR			13312-002	03-0-480A-H9B SHEET 3 OF 3	DI	

Attachment to Form QCL-14A

SERIAL NO. SN/028

SUPPORT NO. 1-03-0-480A-H9B

QA ITEM NO. C.03.040.038-VT

Design Engineering Comments/Disposition:

Design Engineering review has found
this support to be acceptable for service.
The support sketch will be revised to
reflect the existing conditions. Also, reference
QA Item Number F1.02.140

Approved by: S J Cawt

Date: 5/24/90

8.0 Personnel, Equipment and Material Certifications

All personnel who performed or evaluated the results of inservice inspections from February 13, 1990 to June 4, 1990 at Oconee 1 were certified in accordance with the requirements of 1980 Edition of ASME Section XI with Addenda through Winter 1980. The appropriate certification records for each Duke Power Company inspector is on file at Oconee Nuclear Station or in the Corporate Offices in Charlotte, North Carolina. The certification records for the Babcock & Wilcox inspectors are on file at the Babcock & Wilcox Offices in Lynchburg, Virginia.

Records of periodic calibration of Babcock & Wilcox inspection equipment are on file at the Babcock and Wilcox Offices in Lynchburg, Virginia. Records of periodic calibration of Duke Power Company inspection equipment are on file at Oconee Nuclear Station or in the Corporate Offices in Charlotte, North Carolina.

9.0 Problem Investigation Reports

A copy of each Problem Investigation Report resulting from reportable items, originated against scheduled inservice inspections performed during Outage 12, is included in this section. All were resolved and found acceptable by Duke Power's Quality Assurance Department before returning Unit 1 to service. The following Problem Investigation Reports were issued:

<u>P.I.R. NO.</u>	<u>DESCRIPTION</u>	<u>DATE ISSUED</u>
1-090-0046	Class 1 Component Support 1-51A-0-479A-H7A	05-15-90
1-090-0052	Steam Generator 1B Upper Head to Tubesheet Weld (Item No. B02.04.003)	05-22-90

INFORMATION ONLY

COMPLETE FORM BY PRINTING WITH BLACK BALL POINT PEN OR TYPE

DUKE POWER COMPANY NUCLEAR STATION

Problem Investigation Report Serial No. 1-090-0046

Station Crowle

Licensee Event Report No. _____

I. Problem Occurred-Time/Date: UNKNOWN Discovered-Time/Date: 5-15-90

Unit(s): 2 Unit Status At Time Problem Occurred/Discovered: Rebuckling Outage

Description and Cause of Problem: During EST visual examination of Hanger 1-51A-C-479A-H7ARW.02 (Item # F101083) it was discovered that the U-Bolt (Item ID) was missing from Hanger. This discrepancy was determined by Design Engineering to be unacceptable for service.

Other Duke Stations Affected Yes No Determined By/Date: T.J. Coleman 5-15-90

Comments: _____

Location of Problem: Rt. Bldg.

Method Used to Discover Problem: This Report

Immediate Corrective Actions Taken/To Be Taken: _____

Work Stoppage Notification (Form QCK-2A) Serial No.: N/A

Information Sources/References (Work Requests, Documents Violated, etc.): QA514, QAL-14

Originated By: T.J. Coleman Date: 5-15-90 Dept./Group/Section: QA

II. Compliance Evaluation-Item/System Operable Yes No Not Applicable

Evaluated By/Date: Rick Matheson 5/23/90 Comments: Determined by Design

Reportable Yes No Reportable Per: 50.73 Section 50.72 Section

73.71 Section T.S./Lic Cond Section Part 21 Other: Part 50.9

Evaluated By/Date: Rick Matheson 5/22/90 Comments: * Determined after Operability

III. Telecon/ENS Report to NRC Time/Date: _____

NRC Contactee(s): _____ DPC Contactor(s): _____

Telegraph/Mailgram/Facsimile Transmission to NRC-Date: _____

Date Notified: NRC Res. Inspector: _____ Station Manager: _____

General Office: _____ Comments: _____

IV. Investigation Assigned To: _____ NRC Report Due Date: _____

Date Due to Compliance after Evaluation: _____

PIR Review (Compliance): _____ Date: _____

PIR Station Manager Approval: _____ Date: _____

V. Further Action/Evaluation Required Yes No (Explain Below):

Page 2 Assigned To: Design

Comments: _____

Compliance Review: Rick Matheson Date: 5/23/90 QA Review: T.J. Coleman Date: 5-22-90

Distribution

Initial	Originator	<u>Supt (4)</u>	<u>J.M. McClure</u>	<u>B. Barrow</u>	<u>Russ Childs</u>	<u>J. Tucker</u>	<u>R. Henderson</u>
5-15-90	<u>T.J. Coleman</u>	<u>J. Lowery</u>	<u>P. Skinner</u>	<u>O. Delstrap</u>	<u>M. Carter</u>	<u>R. Elgin</u>	<u>P. Guille</u>
Final	Originator	<u>Supt (4)</u>	<u>J.M. McClure</u>	<u>B. Barrow</u>	<u>M. Carter</u>	<u>J. Tucker</u>	<u>R. Henderson</u>
5-24-90	<u>T.J. Coleman</u>	<u>J. Lowery</u>	<u>P. Skinner</u>	<u>O. Delstrap</u>	<u>Russ Childs</u>	<u>R. Elgin</u>	<u>P. Guille</u>
					<u>P. Deraban</u>	<u>QA 3rd Serv.</u>	<u>L. Strubough</u>

PROBLEM INVESTIGATION REPORT

Page 2
PIR No. 1-090-0046

VI. Proposed Resolution of Problem

Design Engineering review of the piping system has determined that the pipe will remain within code allowables with the U-bolt removed. It is therefore proposed that the missing U-bolt for support # 1-51A-0-479A HTA not be replaced.

Other Approved *[Signature]* 5-21-90
Other Approved *[Signature]* 5/21/90

Approved *[Signature]* 5-22-90
Determined By/Date *[Signature]* 5-22-90

SCAE Required Yes No

SCAE Assigned To: _____ Serial No. _____
Remarks *Design Engineering Evaluation & the additional sample inspected per ASME Sect XI is sufficient*

VII. QA Verification Requirements *NO further QA Verification Required.*
[Signature] 5-22-90

Assigned To _____ Date _____

VIII. Corrective Action Completed _____
Information forwarded to Maintenance (Milton Addis) about resolution. No further corrective action necessary as stated in section VI.
[Signature] 5/22/90
Approved _____ Date _____

IX. QA Verification Results *NA*

Completed By _____ Date _____ QA Approval _____ Date _____

Remarks *[Signature]* 5.22.90

DESIGN ENGINEERING DEPARTMENT
OPERABILITY EVALUATION

Station: OCONEE Unit: 1 PIR Number: 1-090-0046

Structure, system, or component (SSC) in question: S/R # 1-51A-0-479A-H7A Rev. D2
(ISI Item # FI.01.093) Prob. No. 1-51-15

Design basis references applicable: N/A

Technical Specification sections applicable: N/A

The SSC in question is recommended to be:

OPERABLE

CONDITIONALLY OPERABLE

INOPERABLE

Operability Evaluation expiration date: _____

FSAR change required

Yes No

10 CFR 50.59 Evaluation required

Yes No

Summary/Comments:

Design Engineering review of support # 1-51A-0-479A-H7A during ISI EOC-12 for Unit 1 determined that this support was inoperable as a lateral restraint. However, further review revealed that the piping system was operable with the lateral portion of this support removed.

Originated by: Russell [Signature] Date: 5-21-90

Reviewed by: BR Christoph Date: 5-21-90

Approved by: SJ Crews Date: 5/21/90

COMPLETE FORM BY PRINTING WITH BLACK BALL POINT PEN OR TYPE

ONLY

DUKE POWER COMPANY NUCLEAR STATION

Problem Investigation Report Serial No. 1-090-0052
Station Crown
Licensee Event Report No.

I. Problem Occurred-Time/Date: UNKNOWN Discovered-Time/Date: 5-22-90
Unit(s): 1 Unit Status At Time Problem Occurred/Discovered: Refueling Outage
Description and Cause of Problem: During IST inspection (ultrasonic examination) of steam generator 1B upper head to tube sheet weld (IST TRM # B02040003 ID# 1566-N658-1) a reportable indication was revealed.

Other Duke Stations Affected Yes No Determined By/Date: T. J. Coleman 5-22-90
Comments: This PTR to be resolved prior to Unit 1 start up.

Location of Problem: OTSG 1B
Method Used to Discover Problem: This Report
Immediate Corrective Actions Taken/To Be Taken: None

Work Stoppage Notification (Form QCK-2A) Serial No.: N/A
Information Sources/References (Work Requests, Documents Violated, etc.): ASME XI

Originated By: T. J. Coleman Date: 5-22-90 Dept./Group/Section: QA Tech Support

II. Compliance Evaluation-Item/System Operable Yes No Not Applicable
Evaluated By/Date: Rich Matheson 5/22/90 Comments:
Reportable Yes No Reportable Per: 50.73 Section 50.72 Section
73.71 Section I.S./Lic Cond Section Part 21 Other: Part 50.9
Evaluated By/Date: Rich Matheson 5/22/90 Comments:

III. Telecon/ENS Report to NRC Time/Date:
NRC Contactee(s): DPC Contactor(s):
Telegraph/Mailgram/Facsimile Transmission to NRC-Date:
Date Notified: NRC Res. Inspector: Station Manager:
General Office: Comments:

IV. Investigation Assigned To: NRC Report Due Date:
Date Due to Compliance after Evaluation:
PIR Review (Compliance): Date:
PIR Station Manager Approval: Date:

V. Further Action/Evaluation Required Yes No (Explain Below):
Page 2 Assigned To: QA
Comments:

Compliance Review: Date: QA Review: Date:

Distribution table with columns for Initial, Originator, and Final, Originator, listing names like Andy Hodge, J. McClure, B. Barron, etc.

COMPLETE FORM BY PRINTING WITH BLACK BALL POINT PEN OR TYPE

INFORMATION ONLY

DUKE POWER COMPANY NUCLEAR STATION

Problem Investigation Report Serial No. 1-090-0052
Station Croomer
Licensee Event Report No.

I. Problem Occurred-Time/Date: UNKNOWN Discovered-Time/Date: 5-22-90
Unit(s): 1 Unit Status At Time Problem Occurred/Discovered: Roducing Outside
Description and Cause of Problem: During I.S.T. inspection (ultrasonic examination) of 5" diam generator IB was found to tubeshet with I.S.T. form # B02-040003 ID# 156B-4658-1. A reportable event on unit 2 revealed.

Other Duke Stations Affected [] Yes [X] No Determined By/Date: T. J. Coleman / 5-22-90
Comments: This PIR to be resolved prior to Unit 1 start up.

Location of Problem: CTSC IB
Method Used to Discover Problem: This Report
Immediate Corrective Actions Taken/To Be Taken: None

Work Stoppage Notification (Form QCK-2A) Serial No.: N/A
Information Sources/References (Work Requests, Documents Violated, etc.): PSME XI

Originated By: T. J. Coleman Date: 5-22-90 Dept./Group/Section: DA Tech Support

II. Compliance Evaluation-Item/System Operable [X] Yes [] No [] Not Applicable
Evaluated By/Date: Rick Matheson 5/22/90 Comments:
Reportable [] Yes [X] No Reportable Per: [] 50.73 Section [] 50.72 Section
[] 73.71 Section [] T.S./Lic Cond Section [] Part 21 [] Other: [] Part 50.9
Evaluated By/Date: Rick Matheson 5/22/90 Comments:

III. Telecon/ENS Report to NRC Time/Date:
NRC Contactee(s): DPC Contactor(s):
Telegraph/Mailgram/Facsimile Transmission to NRC-Date:
Date Notified: NRC Res. Inspector: Station Manager:
General Office: Comments:

IV. Investigation Assigned To: NRC Report Due Date:
Date Due to Compliance after Evaluation:
PIR Review (Compliance): Date:
PIR Station Manager Approval: Date:

V. Further Action/Evaluation Required [X] Yes [] No (Explain Below):
Page 2 Assigned To: SA Mech Maint.
Comments:

Compliance Review: Rick Matheson Date: 6/12/90 QA Review: T. J. Coleman Date: 5-31-90

Distribution

Table with columns: Initial, Originator, and a grid of names. Includes handwritten notes like 'RSM 5/22/90' and '60'.

PROBLEM INVESTIGATION REPORT

Page 2

PIR No. MO90-0052

VI. Proposed Resolution of Problem QA to attach a copy of the ISI Report identifying details of the defect identified during the inspection. QA to attach a copy of the Fracture Mechanics Analysis allowing for continued operation with defect.

This is considered to be a KNOWN generic item applicable to pressure vessels at all Nuclear Power plants. MAA 5-28-90

Other Approved _____ Date _____ Approved [Signature] 5/29/90

Other Approved _____ Date _____ Approved T.J. Coleman 5-31-90

Significant Corrective Action Evaluation Assigned To: N/A Due to the evaluation performed and the monitoring of the indication by the ISI program NO SCAE required

VII. QA Verification Requirements Ensure an Evaluation Report and the associated Fracture Mechanics Analysis are attached to this report. Ensure an ISI Plan Addendum is initiated for additional Examination

Assigned To Tech Support Date 5-31-90

VIII. Corrective Action Completed N/A additional Examination will be performed to monitor the indication Date 5-31-90

Approved _____ Date _____

IX. QA Verification Results Verified Evaluation Report #901-002 and the associated Fracture Mechanics were attached and ISI Plan Addendum 1-CR-0289 issued

Completed By T.J. Coleman 6-4-90 Date _____ QA Approval [Signature] 6.4.90 Date _____

Remarks _____

Final QA Review T.J. Coleman Date 6-4-90

BABCOCK & WILCOX
NUCLEAR POWER GENERATION DIVISION
VOLUMETRIC EXAMINATION EVALUATION REPORT

BWNP-20525-1(11-81)

EVALUATION NUMBER

901-002

METHOD: UT X RT _____

FILE NO. OR REFERENCE

WELD NO. OR IDENTIFICATION: STM. GEN. 1B HEAD TO TUBESHEET, ID# 1SGR-UIG-58-1

APPLICABLE CODE YEAR AND ADDENDA: ASME SEC XI 1980 THRU UNL 1980 ADDENDA

DATE OF INITIAL EXAMINATION: 6 MAY '90

RE-EXAMINATION: _____

REPORTABLE INDICATION NUMBER(S): 200, 400, 401 & 402

COMMENTS: _____

ORIGINATOR: Howard Stojaschmann

LEVEL: II

DATE: 8 MAY '90

PRELIMINARY DISPOSITION

ACCEPTANCE STANDARD: TWB-3511-1

COMMENTS: Indications #200/#402 are from the same reflector which is an unacceptable subsurface planar flaw. Indications #400 and #401 are acceptable separate subsurface planar flaws. See attachment 1 for calculations.

ACCEPTABLE INDICATION NUMBER(S) 400, 401

REJECTABLE INDICATION NUMBER(S) 200 & 402

LEVEL III: M. G. Hoehen

DATE: 5-11-90

FRACTURE MECHANICS ANALYSIS

YES NO

DOCUMENT NUMBER 32-1179753-00

FINAL DISPOSITION

COMMENTS: Indications 400 and 401 are acceptable separate subsurface planar flaws. See attachment 1. Indications 200 and 402 are from the same reflector which has been evaluated as acceptable per the attached referenced fracture mechanics analysis.

ACCEPTABLE INDICATION NUMBER(S) 400, 401, 200, 402

REJECTABLE INDICATION NUMBER(S) _____

LEVEL III: Kenj Hacken

DATE: 6-1-90

FIGURE NO.

B02.040.003

RFE 12-81
X11B
ASIB
6-4-90



CALCULATIONAL SUMMARY SHEET (CSS)

DOCUMENT IDENTIFIER 32-1179753-00

TITLE OC-1 OTSG FLAW EVALUATION

PREPARED BY:

REVIEWED BY:

NAME ASHOK NANA

NAME K.K Yoon

SIGNATURE [Signature]

SIGNATURE [Signature]

TITLE ENGR. IV DATE 5/31/90

TITLE Adv. Engn DATE 5/31/90

COST CENTER 308 REF. PAGE(S) 12

TM STATEMENT: REVIEWER INDEPENDENCE ADM

This document including the information contained herein and any associated drawings, is the property of B&W Nuclear Technologies. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of B&W Nuclear Technologies nor may any use be made of it that is or may be injurious to B&W Nuclear Technologies. This document and any associated drawings and any copies that may have been made must be returned upon request.

PURPOSE AND SUMMARY OF RESULTS:

Purpose

The purpose of this calculation is to evaluate a flaw indication, found in Oconee Unit 1 Steam Generator 1B, according to the ASME Code Section XI procedure.

Results

The flaw indication is found to be acceptable by evaluation according to the ASME Section XI, IWB-3612 for 120 future heatup/cooldown cycles.

THE FOLLOWING COMPUTER CODES HAVE BEEN USED IN THIS DOCUMENT:

CODE / VERSION / REV

CODE / VERSION / REV

NONE

THIS DOCUMENT CONTAINS ASSUMPTIONS THAT MUST BE VERIFIED PRIOR TO USE ON SAFETY-RELATED WORK

YES () NO (X)

BW B&W NUCLEAR
SERVICE COMPANY

GENERAL CALCULATIONS

DOC. I.D. _____

32 - 1179753 - 00

RECORD OF REVISIONS

<u>Revision</u>	<u>Description of Revision</u>	<u>Date</u>
00	Original Release	5/90

PREPARED BY A.D. Nana DATE 5/21/90
 REVIEWED BY K.K. Yoon DATE _____

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company nor may any use be made of it that is or may be injurious to the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request.

PAGE NO.
2



GENERAL CALCULATIONS

DOC. I.D. 32-1179753-00

TABLE OF CONTENTS

	Page
1.0 Introduction.....	4
2.0 Stresses and FM Evaluation.....	5
3.0 Fracture Toughness Determination.....	10
4.0 Conclusion.....	11
5.0 References.....	12
6.0 Appendix A - Volumetric Examination Report	13

PREPARED BY A.D. Nana DATE 5/21/90
 REVIEWED BY K.K. Yoon DATE _____

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company nor may any use be made of it that is or may be injurious to the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request



GENERAL CALCULATIONS

DOC. I.D. _____

32-1179753-00

1.0 INTRODUCTION

During the May 1990 inspection, there were a number of flaw indications detected in the tubesheet to head weld regions of the Ocone-1 Steam Generator 1B. The indications are reported in Appendix A. The flaw indications were located in ^{the} circumferential weld between the upper head and the tubesheet of the steam generator. The weld is identified in Reference 3 as WG-58 with details given in the enlarged view "X" of Reference 2. The purpose of this analysis is to determine the acceptability of the reported indication that exceeds the IWB-3500 acceptance standards of Reference 4. The flaw indication that requires an evaluation is the combined indications of #200 and #402 as described in Appendix A. Using the stresses from Reference 7, the above indication is evaluated in accordance with the ASME Boiler and Pressure Vessel Code, Section XI (Ref. 4).

PREPARED BY A.D. Nana DATE 5/21/90
 REVIEWED BY K.K. Yoon DATE _____

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company nor may any use be made of it that is or may be injurious to the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request.

PAGE NO. 4



GENERAL CALCULATIONS

DOC. I.D. 32-1179753-00

2.0 STRESSES

This section summarizes the stresses in the vicinity of the flaw. Per Appendix A, the flaw was detected in the circumferential weld region of the upper head to tubesheet juncture of OTSG-1B.

2.1 Normal/Upset Condition Stresses

The thermal and pressure stresses of the upper tubesheet region is contained in Reference [7]. Since the results are total stresses obtained from the NASTRAN finite element analysis, they have to be linearized. The linearized stresses are shown schematically on Page 3 of Reference 8 and reported below:

Transient	Linearized Stresses in ksi		
	Inside Surface	Outside Surface	Membrane
Heatup	-20.1	28.1	4.0
Cooldown	49.2	-33.6	7.8

Note that the maximum tensile stress occurs at the inside surface during normal cooldown. Since the flaw is located 0.31 inches from the inside surface, the bending stress at the crack tip is 38.2 ksi. This stress value is used in the computation of the acceptable number of heatup/cooldown cycles on the following two pages.

PREPARED BY A.D. Nana DATE 5/21/90
 REVIEWED BY K.K. Yoon DATE _____

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company nor may any use be made of it that is or may be injurious to the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request

Flaw Location : OTSG 1B Head to Tubesheet, ID# 1SGB-WG 58-1
 Indication # : 200 & 402

**** Using Stresses from NASTRAN Model & Linearizing ****

A. Stress Intensity Factor Calculation for an
 Elliptical Subsurface Flaw

Flaw Geometry Input :
 Wall Thick., (t) - 8.05 in.
 Distance, S - 0.31 in.
 Flaw depth, a - 0.57 in.
 Flaw length, l - 6.1 in.
 Eccentricity, e - 3.145 in.

For Normal and Upset Condition :

Maximum Stress State :- Decay Heat Trans.
 Membrane Stress, SIGm - 7.8 ksi
 Bending Stress, SIGb - 38.2 ksi
 Yield Strength, SIGys - 50 ksi

a/l - 0.09 2a/t - 0.14
 (SIGm + SIGb)/SIGys - 0.92 2e/t - 0.78

From Appendix A, Section XI, ASME B&PV Code :

Q - 0.9 (Fig. A-3300-1)
 Mm - 1.1 (Fig. A-3300-2)
 Mb - 0.89 (Fig. A-3300-4)

KI(ai) - 60.1 ksi sqrt.in

B. Fatigue Flaw Growth Analysis:

For delta KI determination :

Normal and Upset Condition : From Fig. A-4300-1
 No. of Cycles (N) - 120 (assumed) For Subsurface Flaws
 Membrane Stress, SIGm ; (air environment) ;

Due to Heatup - 4 ksi C - 2.7E-11
 Due to Cooldown - 7.8 ksi n - 3.726
 Delta SIGm - 7.8 ksi da/dN = c(Delta KI)^n

Bending Stress, SIGb ;

	Inside	Outside
Due to Heatup	- 22.2 ksi	22.2 ksi
Due to Cooldown	- 38.2 ksi	-38.2 ksi
Delta SIGb	- 60.4 ksi	

PREPARED BY A.D. Nana DATE 5/21/90
 REVIEWED BY K.K. Yoon DATE _____

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request.

$$\Delta KI = (D1 + D2) * \text{Sqrt.}(a_i)$$

where ;

$$D1 = 16.0 \text{ (Delta SIGm * Mm * Sqrt.(pi/Q))}$$

$$D2 = 100.4 \text{ (Delta SIGb * Mb * Sqrt.(pi/Q))}$$

$$D1 + D2 = 116.5$$

$$\Delta KI = 87.9 \text{ ksi sqrt.in}$$

$$da/dN = C * (\Delta KI)^n$$

$$da/dN = 0.000468 \text{ in/cycle; } C = 2.7E-11 ; n = 3.726$$

The final crack size, a_f , in terms of initial crack size, a_i , and above constants ;

$$a_f = [a_i^B + B * C * (D1 + D2)^n * N]^{(1/B)}$$

where ;

$$a_i = 0.57 \text{ in.}$$

$$B = -0.863 \quad (1 - n/2)$$

$$a_f = 0.632 \text{ in.}$$

Calculating KI based on final flaw size ;

$$KI(a_f) = 63.2 \text{ ksi sqrt.in.}$$

C. Safety Factor Assessment :

Material Fracture Toughness:

Per Fig. 3.0-2 of Ref.[6], since oper. temp. > 250 F

(Worst Case HU/CD Transient - CD Trans. 1B2 @ 3.125 hrs.)

$$K_{Ia}(250) = 200 \text{ ksi sqrt. in. (See Section 3.0)}$$

For Normal/Upset Condition, per IWB-3612,

$$K_{Ia}/KI > \text{sqrt.}10 = 3.16$$

$$K_{Ia}/KI(a_f) = 3.16$$

Therefore, this flaw is acceptable for 120 future cycles.

PREPARED BY A.D. Nana DATE 5/21/90

REVIEWED BY K.K. Yoon DATE _____

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company nor may any use be made of it that is or may be injurious to the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request

PAGE NO.

7

2.2 Emergency and Faulted Loading Condition Stresses

The stresses due to the emergency/faulted condition, for the upper head to tubesheet weld region are reported in Section 2.4 of Reference 5. The stresses for this loading category are obtained by superimposing the stresses due to LOCA (loss of coolant accident) with the maximum primary pressure stresses of 2566 psi to include the effects of MSLB (main steam line break) and FWLB (feedwater line break) events. The linearized stresses are summarized below:

Transient	Longitudinal stress (ksi)			
	Inside	Outside	Membrane	Bending
LOCA	52.0	-30	11.0	+/-11.0
Pressure (2566psi)	29.2	-11.3	9.0	+/-20.2

The membrane plus bending stress at the crack tip corresponds to 28 ksi due to pressure(2566 psi) and 49 ksi due to LOCA. Therefore, conservatively assume the membrane stress to be 20 ksi and the rest of the stress at the crack tip as bending i.e. $77 - 20 = 57$ ksi. These stresses will be used in the KI calculation on the following page.

PREPARED BY A.D. Nana DATE 5/21/90
 REVIEWED BY K.K. Yoon DATE _____

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company nor may any use be made of it that is or may be injurious to the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request.

Flaw Location : OTSG 1B Head to Tubesheet, ID# 1SGB-WG 58-1
 Indication # : 200 & 402
 **** Using Stresses from NASTRAN Model & Linearizing ****
 A. Stress Intensity Factor Calculation for an
 Elliptical Subsurface Flaw

Flaw Geometry Input :

Wall Thick., (t) - 8.05 in.
 Distance, S - 0.31 in.
 Flaw depth, a - 0.57 in.
 Flaw length, l - 6.1 in.
 Eccentricity, e - 3.145 in.

For Emergency and Faulted Condition :

Maximum Stress State :-
 Membrane Stress, SIGm - 20 ksi
 Bending Stress, SIGb - 57 ksi
 Yield Strength, SIGys - 50 ksi

$\frac{a}{l}$ - 0.09 $\frac{2a}{t}$ - 0.14
 $\frac{(SIGm + SIGb)}{SIGys}$ - 1.54 $\frac{2e}{t}$ - 0.78

From Appendix A, Section XI, ASME B&PV Code :

Q - 0.8 (Fig. A-3300-1)
 Mm - 1.1 (Fig. A-3300-2)
 Mb - 0.89 (Fig. A-3300-4)

KI(af) - 108.8 ksi sqrt.in

As indicated previously in this Section
 KIc - 200 ksi sqrt.in (See Section 3.0)

For Emergency and Faulted Condition, per IWB-3612,

$KIc/KI > \text{sqrt. } 2$ - 1.414

$KIc/KI(af)$ - 1.838

Therefore, this flaw is acceptable for Emergency & Faulted Cond

PREPARED BY A.D. Nana DATE 5/21/90
 REVIEWED BY K.K. Yoon DATE _____

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company nor may any use be made of it that is or may be injurious to the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request

3.0 Fracture Toughness Determination

The maximum tensile stress at the upper head to tubesheet juncture occurs during the cooldown at 15% power (3.125 hrs into the transient) when the RCS temperature is 250 F. Note that it is the stresses due to this cooldown transient that is evaluated in Section 2.0. This transient is illustrated in Figure 3.0-2 on Page 3-11 of Reference 6.

For the SG shell there is no appreciable fluence cummulation, hence,

$$\begin{aligned} RT_{NDT} &= \text{initial } RT_{NDT} \\ &= 60^{\circ}F \text{ (assumed)} \end{aligned}$$

$$T - RT_{NDT} = 250 - 60 = 190^{\circ}F$$

From Fig. A-4200-1 of Ref. 4, $K_{Ia} = 200 \text{ ksi } \sqrt{\text{in.}}$

For the Emergency and Faulted Condition, the RCS temperature when the pressure is at 2566 psi is significantly greater than 250 F and the minimum RCS temperature during the emergency and faulted condition events is greater than 250 F. Therefore, K_{Ic} is also 200 ksi $\sqrt{\text{in}}$ per Fig. A-4200-1.

PREPARED BY A.D. Nana DATE 5/21/90
REVIEWED BY K.K. Yoon DATE _____

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company nor may any use be made of it that is or may be injurious to the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request

PAGE NO.

10



GENERAL CALCULATIONS

DOC. I.D. _____

32-1179753-00

4.0 Conclusion

The combined indication (200 & 402) evaluated in this document is found to be acceptable for 120 future heatup/cooldown cycles (since May 1990) per the IWB-3612 criteria.

PREPARED BY	<u> A.D. Nana </u>	DATE	<u> 5/21/90 </u>
REVIEWED BY	<u> K.K. Yoon </u>	DATE	<u> </u>

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company nor may any use be made of it that is or may be injurious to the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request.

PAGE NO.
 11

5.0 References

1. Not used.
2. B&W Drawing 02-129316E-9, "Assy. and Detail of Upper Head". (NSS-3).
3. B&W Drawing 02-129312E-13, "Shell and Tubesheet Attachment Assembly". (NSS-3).
4. ASME Boiler and Pressure Vessel Code, Section XI, 1980 Edition through Winter 1980 Addenda.
5. B&W Document 32-1173627-00, "ANO-1 OTSG Flaw Evaluation", Nov. '88. (For Owners Group OTSG Emergency and Faulted Condition Stresses @ Upper Head to Tubesheet Junction).
6. B&W Document 32-9811-01, "177 OTSG Minimum Tube Wall Thickness", Nov, 1979.
7. B&W Document 32-1134568-00, "OTSG Stresses - Heatup, Cooldown, Loca", July 1982.
8. B&W Document 32-1153946-00, "ISI Flaw Evaluation, Steam Generator Upper Head to Tubesheet", Nov. 1984.

PREPARED BY A. D. Nana DATE 5/21/90
 REVIEWED BY K. K. Yoon DATE _____

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company nor may any use be made of it that is or may be injurious to the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request.

PAGE NO.

12



GENERAL CALCULATIONS

DOC. I.D. 32-1179753-00

6.0 Appendix A

The following is the Volumetric Examination Evaluation Report that contains flaw indications, in the upper head to tubesheet region of Ocone Unit-1 OTSG-1B, found during the May 1990 inspection.

PREPARED BY A.D. Nana DATE 5/21/90
REVIEWED BY K.K. Yoon DATE

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company nor may any use be made of it that is or may be injurious to the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request.



Stock & Wilcox
a McDermott company

VOLUMETRIC TEST DATA

CUSTOMER: Duke Power Co. Oconee Unit CONTRACT NO: 702-2034 COMPONENT: STEAM GEN. 1B (VESSEL)
 DESCRIPTION: STEAM GEN. 1B (UPPER HEAD TO TUBE SHEET. PG 8 TO 51) THERMOMETER: OCQA-223
 I.D. NO.: 15GB-WG58-1 PROCEDURE: ISI-130 REV. 24 MATERIAL: 9/5 THICKNESS: 8.5" TEST SURF.: OD

NO. POSITIONS: 36 DISTANCE: 12.0" NO. REFERENCE: 20 CAL SHEET: 901023 CAL SHEET: 901010 CAL SHEET: 901011 CAL SHEET:
 BEAM DIRECTION: LONG SHEAR LIMITED EXAM: NO YES ? ANGLE: 0 ANGLE: 45 ANGLE: 60 ANGLE:
 EXAMINER: DJ Moss/O.L. Robison ID NO.: M-8250 LEVEL: II TIME START: 1242 HR. TIME START: 1830 HR. TIME START: 1230 HR. TIME START: A HR.
 EXAMINER: J.W. Sitzer/Ed Hill ID NO.: 89449 LEVEL: II TIME STOP: 1457 HR. TIME STOP: 2020 HR. TIME STOP: 1830 HR. TIME STOP: HR.
 EXAMINER: J.W. Sitzer/Ed Hill ID NO.: 55043 LEVEL: II PART TEMP: 88 °F PART TEMP: 88 °F PART TEMP: 88 °F PART TEMP: °F

NOTES: INDICATION 200 MEAS. TAKEN FROM TUBE SHEET TOP
 #1 REF. STARTS AT X-AXIS
 old data states W-axis
 NO MAX TWD DIMENSION WAS OBTAINABLE DUE TO THE GEOMETRY WHERE THE HEAD RADIUS STARTS (402) ONLY

DATE: 5-6-90 DATE: 5-6-90 DATE: 5-6-90 DATE:
 CAL BLK: 40305 WELD INFORMATION @ 0° THICKNESS
 DWG NO: OM-201-1878 SURFACE NO2 HTH: FLUSH SURFACE NO.1
ISI-OCQA-004 WD: 4.0"
 FCA(S): TUBE SHEET E: 8.44 UPPER HEAD
 CAT. 89.006 BM: N/A MIN: 8.3 BM: 9.045
 HAZ: N/A MAX: 8.6 HAZ: 8.743

1ST SCAN 60° REQUIRED
 2ND SCAN 60° NOT REQUIRED

INDICATION NO(S)	POSITION OR PART ITEM		ANGLE (DEGREES)	SURFACE	BEAM DIRECTION	STATUS	L.A.M.			DEPTH (INS)	LGTH WOTH			CRYSTAL DISTANCE FROM (INCHES)				THROUGH WALL DIMENSION				DAMPS	REMARKS
	A	B					MAX. AMP. % DAC	20%	50% / HMA		100%	MINIMUM		MAXIMUM		DEPTH	POSITION (INCHES)		DEPTH	POSITION (INCHES)			
												A	B	A	B		A	B		A	B		
	LENGTH						A	B	I		2	A	B	A	B								
	360°		0°			No	RECORDABLE INDICATIONS																
200	27 TO 28		45°	1	2	SEP.	282	7.437		6.1			5.4	10.75	7.135		10.15	7.638		11.2	No		
							50	7.437					1.6	10.5									50% EP
							50	7.337					7.7	10.5									50% EP
							224	7.235					4.5	10.3	7.135		10.0	7.738		11.0	No		
							224	7.537					3.6	10.6	7.135		9.9	7.737		10.8	No		
							125	7.235					2.7	10.5	7.235		10.2	7.738		11.0	No		
							50	7.235					1.8	10.5	7.135		10.0	7.638		11.0	No		
							125	7.538					6.3	10.5	7.135		10.0	7.537		10.9	No		
							50	7.336					7.2	10.5	7.135		10.2	7.537		11.0	No		
	360°		45°			No	OTHER RECORDABLE INDICATIONS																

REVIEWED BY: Howard Stojilman LEVEL: II DATE: 8 MAY '90 FIGURE NO: B02.040.003

ANGLE: 0 DEG. 45 DEG. 60 DEG. OTHER E.R. REQUIRED: YES NO E.R. NUMBER: 901-002

IND. NOS. 1 TO 199 200 TO 399 400 TO 599 600 TO 799 PAGE 1 OF 8

VOLUMETRIC TEST DATA FORM 101

BWNP-20531-3 (10-84)

CUSTOMER: DUKE POWER CO. OCOONEE I	CONTRACT NO: 702-2034	COMPONENT: VESSEL SGB
EXAMINER: J.W. Setzer	ID: S-5643	LEVEL II
EXAMINER: J. Abill	ID: B-9449	LEVEL II
DATE(S): 5-6-90		

IND. NO.	POSITION OR PART ITEM	ANGLE (DEG)	SURFACE	BEAM DIRECTION	STATUS	LAM.		LNPTH	WDTH	(INCHES)				THROUGH WALL DIMENSION				DAMPS	REMARKS					
						MAX AMP % DAC	DEPTH (IN.)			20%	50% OR HMA	100%	CRYSTAL		DISTANCE		MINIMUM			MAXIMUM				
													A	B	1	2	DEPTH			POSITION IN.		DEPTH	POSITION IN.	
																				I	2		I	2
																				A	B		A	B
LENGTH				A	B	I	2	DEPTH	A	B	A	B												
400	25 to 27	60	1	2	SEP	125	7.3		1.0		12.0		12.6	7.1		12.0	7.5		13.1	NO				
						50	7.4				11.6													
						50	7.3				12.6													
401	20 to 21	60	1	2	SEP	80	7.1		1.5		2.5		12.0	6.9		11.5	7.2		12.1	NO				
						50	7.1				2.0													
						50	7.1				3.5													
402	27 to 28	60	1	2	SEP	251	6.8		4.4		5.1		13.2	6.6		12.9					NO			
						50	6.8				2.8		13.2											
						50	6.8				7.2		13.2											
						251	6.8				3.7		13.2	6.6		12.9								
						251	6.8				4.6		13.2	6.6		12.9								
						200	6.8				5.5		13.2	6.6		12.9								
						159	6.8				6.4		13.2	6.6		12.9								
	360°	60		No	OTHER	RECORDABLE INDICATIONS																		

}

SEE NOTES

REVIEWED BY: Harold Stoppelman	LEVEL: II	DATE REVIEWED: 8 MAY '90	FIGURE NO.: B02-040.003
---------------------------------------	------------------	---------------------------------	--------------------------------



Babcock & Wilcox
 a McDermott company
 SPECIAL PRODUCTS
 AND
 INTEGRATED FIELD SERVICE

ISI, LIMITED EXAMINATIONS

CUSTOMER: DUKE POWER COMPANY, SITE: OCONEE, UNIT: I
 CONTRACT NO.: 702-2034
 COMPONENT: STEAM GENERATOR, I.D. NO.: ISGB-WG58-1

BWNP

(7-87)

TEST METHOD: U.T.


NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 3 AND 5 8.5 INCHES FROM POINT 3 TO 8.5
 INCHES FROM POINT 5 10 INCHES FROM WELD ξ TO beyond INCHES FROM
 WELD ξ
 ANGLE(S) 0° 45° 60° ___° ___° ___° N/A
 DUE TO: Scub in shipping Tie Down Removal AREA

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS ___ AND ___ INCHES FROM POINT ___ TO ___
 INCHES FROM POINT ___ INCHES FROM WELD ξ TO ___ INCHES FROM
 WELD ξ
 ANGLE(S) 0° 45° 60° ___° ___° ___° N/A
 DUE TO: ___

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
360 DEGREES. 3.5 INCHES FROM WELD ξ TO beyond INCHES FROM WELD ξ
 ANGLE(S) 0° 45° 60° ___° ___° ___° N/A
 DUE TO: Taper on Tube sheet AREA

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 ___ DEGREES. ___ INCHES FROM WELD ξ TO ___ INCHES FROM WELD ξ
 ANGLE(S) 0° 45° 60° ___° ___° ___° N/A
 DUE TO: ___

NOTES: _____



SEE ATTACHMENT NO(S): _____

VIEWED BY: Howard Hornsman LEVEL: II DATE: 8 MAY '90

FIGURE NO.: B02.040.003



Babcock & Wilcox

a McDermott company
SPECIAL PRODUCTS
AND

INTEGRATED FIELD SERVICE

ISI, LIMITED EXAMINATIONS

CUSTOMER: DUKE POWER COMPANY

SITE: OCONEE

UNIT: I

CONTRACT NO.: 702-2034

COMPONENT: STEAM Generator, I.D. NO.: 15GB-WG58-1

BWNP

(7-87)

TEST METHOD: U.T.

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 33 AND 34 . 0.0 INCHES FROM POINT 33 TO 2.0
 INCHES FROM POINT 34 . 10 INCHES FROM WELD ξ TO beyond INCHES FROM
 WELD ξ
 ANGLE(S) 0° 45° 60° ___° ___° ___° N/A
 DUE TO: Scub in shipping tie Down Removal Area

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 35 AND 3 . 5.0 INCHES FROM POINT 35 TO 5.0
 INCHES FROM POINT 3 . 19.5 INCHES FROM WELD ξ TO beyond INCHES FROM
 WELD ξ
 ANGLE(S) 0° 45° 60° ___° ___° ___° N/A
 DUE TO: MANWAY

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ
 ANGLE(S) 0° 45° 60° ___° ___° ___° N/A
 DUE TO: _____

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ
 ANGLE(S) 0° 45° 60° ___° ___° ___° N/A
 DUE TO: _____

NOTES: _____

SKETCH: _____

 SEE ATTACHMENT NO(S): _____

REVIEWED BY: Howard Stogdole LEVEL: II DATE: 8 MAY '90

FIGURE NO.: B02.040.003



Babcock & Wilcox
 a McDermott company
 SPECIAL PRODUCTS
 AND
 INTEGRATED FIELD SERVICE

ISI, LIMITED EXAMINATIONS

CUSTOMER: DUKE POWER COMPANY, SITE: OCONEE, UNIT: I
 CONTRACT NO.: 702-2034
 COMPONENT: STEAM GEN B, I.D. NO.: ISGB-WG 58-1

BWNP (7-87)

TEST METHOD: UT

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 26 AND 30 6 INCHES FROM POINT 26 TO 6
15 INCHES FROM POINT 30 15 INCHES FROM WELD ξ TO _____ INCHES FROM
 WELD ξ AND BEYOND
 ANGLE(S) 0° 45° 60° _____° _____° _____° N/A
 DUE TO: SUPPORT PAD

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 4 AND 5 3.5 INCHES FROM POINT 4 TO 6.5
8.5 INCHES FROM POINT 5 8.5 INCHES FROM WELD ξ TO 11.5 INCHES FROM
 WELD ξ
 ANGLE(S) 0° 45° 60° _____° _____° _____° N/A
 DUE TO: 1 1/2" ϕ VENT CONN.

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ

 ANGLE(S) 0° 45° 60° _____° _____° _____° N/A
 DUE TO: _____

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ

 ANGLE(S) 0° 45° 60° _____° _____° _____° N/A
 DUE TO: _____

NOTES: _____

SKETCH: _____

 SEE ATTACHMENT NO(S): _____

REVIEWED BY: Howard H. [Signature] LEVEL: II DATE: 8 MAY 90
 REVIEWED BY: _____ TITLE: _____ DATE: _____

FIGURE NO.: B02.040.003



Babcock & Wilcox
 a McDermott company
 SPECIAL PRODUCTS
 AND
 INTEGRATED FIELD SERVICE

ISI, LIMITED EXAMINATIONS

CUSTOMER: DUKE POWER COMPANY, SITE: OCONEE, UNIT: I
 CONTRACT NO.: 702-2034
 COMPONENT: STEAM GEN B, I.D. NO.: 15GB-WG 5B-1

BWNP

(7-87)

TEST METHOD: UT

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 12 AND 16 6 INCHES FROM POINT 12 TO 6
 INCHES FROM POINT 16 15 INCHES FROM WELD ξ TO _____ INCHES FROM
 WELD ξ AND BEYOND
 ANGLE(S) 0° 45° 60° _____° _____° _____° N/A
 DUE TO: SUPPORT PAD

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 19 AND 23 6 INCHES FROM POINT 19 TO 6
 INCHES FROM POINT 23 15 INCHES FROM WELD ξ TO _____ INCHES FROM
 WELD ξ AND BEYOND
 ANGLE(S) 0° 45° 60° _____° _____° _____° N/A
 DUE TO: SUPPORT PAD

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ
N/A
 ANGLE(S) 0° 45° 60° _____° _____° _____° N/A
 DUE TO: _____

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ
N/A
 ANGLE(S) 0° 45° 60° _____° _____° _____° N/A
 DUE TO: _____

NOTES: _____

SKETCH: _____

SEE ATTACHMENT NO(S): _____

REVIEWED BY: Homer Stephens LEVEL: II DATE: 8 MAY '90

FIGURE NO.: B02.040.003



Babcock & Wilcox

a McDermott company
SPECIAL PRODUCTS
AND

INTEGRATED FIELD SERVICE

ISI, LIMITED EXAMINATIONS

CUSTOMER: DUKE POWER COMPANY

SITE: OCONEE

UNIT: I

CONTRACT NO.: 702-2034

COMPONENT: SG B

I.D. NO.: 1 SGB-WG58-1

BWNP

(7-87)

TEST METHOD: UT

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 33 AND 2 . . . 7 INCHES FROM POINT 33 TO 6
 INCHES FROM POINT 2 . . . 15 INCHES FROM WELD ξ TO _____ INCHES FROM
 WELD ξ AND BEYOND.
 ANGLE(S) 0° 45° 60° _____° _____° _____° N/A
 DUE TO: SUPPORT PAD

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 5 AND 9 . . . 6 INCHES FROM POINT 5 TO 6
 INCHES FROM POINT 9 . . . 15 INCHES FROM WELD ξ TO _____ INCHES FROM
 WELD ξ AND BEYOND.
 ANGLE(S) 0° 45° 60° _____° _____° _____° N/A
 DUE TO: SUPPORT PAD

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ

 ANGLE(S) 0° 45° 60° _____° _____° _____° N/A
 DUE TO: _____

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ

 ANGLE(S) 0° 45° 60° _____° _____° _____° N/A
 DUE TO: _____

NOTES: _____

SKETCH: _____

 SEE ATTACHMENT NO(S): _____

REVIEWED BY: Howard Hoggins LEVEL: II DATE: 8 MAY '90
 REVIEWED BY: _____ TITLE: _____ DATE: _____


FIGURE NO.: B02-040.003

INDICATION PLOT SHEET

EXAMINATION SURFACE 1
HEAD

WELD
⊕

EXAMINATION SURFACE 2
TUBESHEET



COMMENTS:

GEOMETRIC

REPORTABLE

CUSTOMER: DUKE POWER CO OGONEE 1

PROJECT NO: 702-2034

WELD NO: 1SG-B-WG-58-1


ANALYST:

SNT LEVEL:

DATE:

FIGURE NO: 802-040-003

ATTACHMENT TO B02.040.003



D. L. Robinson

5-7-90



DOCUMENT RELEASE NOTICE (DRN)

Release Date _____
 Records Mgmt. Initials _____

CONTRACT NO. 702-2034		PLANT Ocone Unit 1	CHARGE NO.			Page 1 of 1	
3-DIGIT TASK NO., PART NO., OR TASK-GROUP-SEQ.	B&W DOCUMENT NO.	DOCUMENT TITLE (30 Characters Maximum)			SAFETY CLASS (OMIT FOR NSS-15, 16 & 23)	PUL STAT (Y/N)	COM ATT? (Y/N)
140	32-1179753-00	OC-1 OTSG Flaw Evaluation			S	N	N
		Keywords : Fracture Mechanics, Flaw Evaluation, OTSG, LEFM.					

REQUIRED DISTRIBUTION (ORGANIZATION OR TE)	NO. COPIES			INFORMATION COPIES (INDIVIDUAL'S NAME)	NO. COPIES		
	DRN	DOC	COM		DRN	DOC	COM
MG HACKER	1	1		KK YOON	1	1	
WD MINTON	1	1		AD NANA (Originals)	1	1	
TP SURRETT	2	1					

PROJECT ENGINEER/PM APPROVAL:
 (SIGNATURE) _____
 (PRINTED NAME) _____ DATE _____

RELEASED BY (PREPARER):
 (SIGNATURE) Ashok Nana 5/31/90
 (PRINTED NAME) ASHOK NANA DATE

REVIEWED BY:
 (SIGNATURE) KK Yoon 5/31/90
 (PRINTED NAME) K. K. YOON DATE

DUKE POWER CO.
OCONEE - UNIT #1
STEAM GENERATOR 1B
UPPER HEAD TO TUBESHEET: 1SGB-WG58-1

EVALUATION OF INDICATIONS:

FIG. NO. B02.040.003

EVALUATION REPORT NO.: 901-002

INDICATION #200/#402

$$t = 8.3" - .25" = 8.05"$$

$$S = 8.05" - 7.738" = .31"$$

$$2d = 7.738" - 6.6" = 1.14"$$

$$d = 1.14"/2 = .57"$$

$$.4d = .4 \times .57 = .23"$$

$S > .4d$ = SUBSURFACE FLAW

$$a = d = .57"$$

$$l = 6.1"$$

$$a/l = .57/6.1 = .09$$

$$a/t = .57/8.05" = 7.17.$$

IWB-3511-1 ALLOWABLE FOR .09 ASPECT RATIO IS 2.88Y

$$Y = S/a = .31/.57 = .544$$

$$2.88 \times .544 = 1.577. a/t$$

7.17. $a/t > 1.577. a/t$ = UNACCEPTABLE

INDICATION # 400

$$t = 8.3 - .25 = 8.05''$$

$$S = 8.05 - 7.5 = .45''$$

$$2d = 7.5 - 7.1 = .4''$$

$$d = .4/2 = .2''$$

$$.4d = .4 \times .2 = .08''$$

$S > .4d =$ SUBSURFACE FLAW

$$a = d = .2''$$

$$l = 1.0''$$

$$a/l = .2/1 = .2$$

$$a/t = .2/8.05 = 2.59.$$

IWB-3511-1 ALLOWABLE FOR .2 ASPECT RATIO IS 3.6Y a,

$$Y = S/a = .45/.2 = 2.25, \text{ IF } Y > 1, Y = 1$$

2.59. $a/t < 3.69. a/t =$ ACCEPTABLE

INDICATION # 401

$$t = 8.3 - .25 = 8.05$$

$$S = 8.05 - 7.2 = .805$$

$$2d = 7.2 - 6.9 = .3$$

$$d = .3/2 = .15$$

$$.4d = .4 \times .15 = .06$$

$S > .4d =$ SUBSURFACE FLAW

$$a = d = .15$$

$$l = 1.5$$

$$a/l = .15/1.5 = .10$$

$$a/t = .15/8.05 = 1.97$$

IWB-3511-1 ALLOWABLE FOR .10 ASPECT RATIO IS 2.97 a/l

$$Y = S/a = .805/.15 = 5.37, \text{ IF } Y \neq 1, Y = 1$$

1.97 $a/t < 2.97$ $a/t =$ ACCEPTABLE

M. G. Hoehen Level III 5-11-90

10.0 Reference Documents

The following reference documents apply to the inservice inspection performed during Outage 12 at Oconee 1.

Babcock and Wilcox Volumetric Examination Evaluation Report 901-002, dated May 8, 1990.

Babcock and Wilcox Fracture Mechanics Analysis Report No. 32-1179753-00.

Duke Power Company Request for Relief ONS-009.

Duke Power Company Request for Relief ONS-013.

BABCOCK & WILCOX
NUCLEAR POWER GENERATION DIVISION
VOLUMETRIC EXAMINATION EVALUATION REPORT

BWNP-20525-1(11-81)

EVALUATION NUMBER

901-002

METHOD: UT X RT _____

FILE NO. OR REFERENCE

WELD NO. OR IDENTIFICATION: STM. GEN. 1B HEAD TO TUBESHEET, ID# 1SGB-WG 58-1
APPLICABLE CODE YEAR AND ADDENDA: ASME SEC II 1980 THRU WIN. 1980 ADDENDA
DATE OF INITIAL EXAMINATION: 6 MAY '90 RE-EXAMINATION: _____
REPORTABLE INDICATION NUMBER(S): 200, 400, 401 & 402

COMMENTS: _____

ORIGINATOR: Howard Stoppelmann LEVEL: II DATE: 8 MAY '90

PRELIMINARY DISPOSITION

ACCEPTANCE STANDARD: IWB-3511-1

COMMENTS: Indications #200/#402 are from the same reflector which is an unacceptable subsurface planar flaw. Indications #400 and #401 are acceptable separate subsurface planar flaws. See attachment 1 for calculations.

ACCEPTABLE INDICATION NUMBER(S) 400, 401

REJECTABLE INDICATION NUMBER(S) 200 & 402

LEVEL III: M. G. Hoeker DATE: 5-11-90

FRACTURE MECHANICS ANALYSIS

YES NO

DOCUMENT NUMBER 32-1179753-00

FINAL DISPOSITION

COMMENTS: Indications 400 and 401 are acceptable separate subsurface planar flaws. See attachment 1. Indications 200 and 402 are from the same reflector which has been evaluated as acceptable per the referenced fracture mechanics analysis.

ACCEPTABLE INDICATION NUMBER(S) 400, 401, 200, 402

REJECTABLE INDICATION NUMBER(S) _____

LEVEL III: Kevin Hoeker DATE: 6-1-90

FIGURE NO.

B02.040.003

APPEAL
ASB
6-4-90

DUKE POWER CO.
OCONEE - UNIT #1
STEAM GENERATOR 1B
UPPER HEAD TO TUBESHEET: 1SGB-WG58-1

EVALUATION OF INDICATIONS:

FIG. NO. B02.040.003

EVALUATION REPORT NO.: 901-002

INDICATION #200/#402

$$t = 8.3" - .25" = 8.05"$$

$$S = 8.05" - 7.738" = .31"$$

$$2d = 7.738" - 6.6" = 1.14"$$

$$d = 1.14"/2 = .57"$$

$$.4d = .4 \times .57 = .23"$$

$S > .4d$ = SUBSURFACE FLAW

$$a = d = .57"$$

$$l = 6.1"$$

$$a/l = .57/6.1 = .09$$

$$a/t = .57/8.05" = 7.17.$$

IWB-3511-1 ALLOWABLE FOR .09 ASPECT RATIO IS 2.88Y a

$$Y = S/a = .31/.57 = .544$$

$$2.88 \times .544 = 1.577. a/t$$

7.17. a/t > 1.577. a/t = UNACCEPTABLE

INDICATION # 400

$$t = 8.3 - .25 = 8.05''$$

$$S = 8.05 - 7.5 = .45''$$

$$2d = 7.5 - 7.1 = .4''$$

$$d = .4/2 = .2''$$

$$.4d = .4 \times .2 = .08''$$

$S > .4d =$ SUBSURFACE FLAW

$$a = d = .2''$$

$$l = 1.0''$$

$$a/l = .2/1 = .2$$

$$a/t = .2/8.05 = 2.5\%$$

IWB-3511-1 ALLOWABLE FOR .2 ASPECT RATIO IS 3.6% a/l

$$Y = S/a = .45/.2 = 2.25, \text{ IF } Y > 1, Y = 1$$

2.5% $a/t < 3.6\%$ $a/t =$ ACCEPTABLE

INDICATION # 401

$$t = 8.3 - .25 = 8.05"$$

$$S = 8.05 - 7.2 = .805"$$

$$2d = 7.2 - 6.9 = .3"$$

$$d = .3/2 = .15"$$

$$.4d = .4 \times .15 = .06$$

$S > .4d =$ SUBSURFACE FLAW

$$a = d = .15"$$

$$l = 1.5"$$

$$a/l = .15/1.5 = .10$$

$$a/t = .15/8.05 = 1.9\%$$

IWB-3511-1 ALLOWABLE FOR .10 ASPECT RATIO IS 2.9% a/t

$$Y = S/a = .805/.15 = 5.37, \text{ IF } Y > 1, Y = 1$$

1.9% $a/t < 2.9\% a/t =$ ACCEPTABLE

M. G. Hoehen Level III 5-11-90

PAGE 3 OF 3

32-1179753-00



CALCULATIONAL SUMMARY SHEET (CSS)

DOCUMENT IDENTIFIER 32-1179753-00

TITLE OC-1 OTSG FLAW EVALUATION

PREPARED BY:

REVIEWED BY:

NAME ASHOK NANA

NAME K.K Yoon

SIGNATURE [Signature]

SIGNATURE [Signature]

TITLE ENGR. IV DATE 5/31/90

TITLE Adv. Eng. DATE 5/31/90

COST CENTER 308 REF. PAGE(S) 12

TM STATEMENT: REVIEWER INDEPENDENCE ADM

This document including the information contained herein and any associated drawings, is the property of B&W Nuclear Technologies. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of B&W Nuclear Technologies nor may any use be made of it that is or may be injurious to B&W Nuclear Technologies. This document and any associated drawings and any copies that may have been made must be returned upon request.

PURPOSE AND SUMMARY OF RESULTS:

Purpose

The purpose of this calculation is to evaluate a flaw indication, found in Oconee Unit 1 Steam Generator 1B, according to the ASME Code Section XI procedure.

Results

The flaw indication is found to be acceptable by evaluation according to the ASME Section XI, IWB-3612 for 120 future heatup/coldown cycles.

THE FOLLOWING COMPUTER CODES HAVE BEEN USED IN THIS DOCUMENT:

CODE / VERSION / REV

CODE / VERSION / REV

NONE

THIS DOCUMENT CONTAINS ASSUMPTIONS THAT MUST BE VERIFIED PRIOR TO USE ON SAFETY-RELATED WORK

YES () NO (X)

BW B&W NUCLEAR
SERVICE COMPANY

GENERAL CALCULATIONS

DOC. I.D. _____

32 - 1179753 - 00

RECORD OF REVISIONS

<u>Revision</u>	<u>Description of Revision</u>	<u>Date</u>
00	Original Release	5/90

PREPARED BY A.D. Nana DATE 5/21/90

REVIEWED BY K.K. Yoon DATE _____

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company nor may any use be made of it that is or may be injurious to the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request.

PAGE NO.
2

TABLE OF CONTENTS

	Page
1.0 Introduction.....	4
2.0 Stresses and FM Evaluation.....	5
3.0 Fracture Toughness Determination.....	10
4.0 Conclusion.....	11
5.0 References.....	12
6.0 Appendix A - Volumetric Examination Report	13

PREPARED BY A.D. Nana DATE 5/21/90

REVIEWED BY K.K. Yoon DATE

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company nor may any use be made of it that is or may be injurious to the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request.



GENERAL CALCULATIONS

DOC. I.D. 32-1179753-00

1.0 INTRODUCTION

During the May 1990 inspection, there were a number of flaw indications detected in the tubesheet to head weld regions of the Ocone-1 Steam Generator 1B. The indications are reported in Appendix A. The flaw indications were located in ^{the} circumferential weld between the upper head and the tubesheet of the steam generator. The weld is identified in Reference 3 as WG-58 with details given in the enlarged view "X" of Reference 2. The purpose of this analysis is to determine the acceptability of the reported indication that exceeds the IWB-3500 acceptance standards of Reference 4. The flaw indication that requires an evaluation is the combined indications of #200 and #402 as described in Appendix A. Using the stresses from Reference 7, the above indication is evaluated in accordance with the ASME Boiler and Pressure Vessel Code, Section XI (Ref. 4).

PREPARED BY A.D. Nana DATE 5/21/90
REVIEWED BY K.K. Yoon DATE

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company nor may any use be made of it that is or may be injurious to the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request

PAGE NO. 4

2.0 STRESSES

This section summarizes the stresses in the vicinity of the flaw. Per Appendix A, the flaw was detected in the circumferential weld region of the upper head to tubesheet juncture of OTSG-1B.

2.1 Normal/Upset Condition Stresses

The thermal and pressure stresses of the upper tubesheet region is contained in Reference [7]. Since the results are total stresses obtained from the NASTRAN finite element analysis, they have to be linearized. The linearized stresses are shown schematically on Page 3 of Reference 8 and reported below:

Transient	Linearized Stresses in ksi		
	Inside Surface	Outside Surface	Membrane
Heatup	-20.1	28.1	4.0
Cooldown	49.2	-33.6	7.8

Note that the maximum tensile stress occurs at the inside surface during normal cooldown. Since the flaw is located 0.31 inches from the inside surface, the bending stress at the crack tip is 38.2 ksi. This stress value is used in the computation of the acceptable number of heatup/cooldown cycles on the following two pages.

PREPARED BY A.D. Nana DATE 5/21/90
 REVIEWED BY K.K. Yoon DATE _____

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company nor may any use be made of it that is or may be injurious to the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request.

Flaw Location : OTSG 1B Head to Tubesheet, ID# 1SGB-WG 58-1
 Indication # : 200 & 402

**** Using Stresses from NASTRAN Model & Linearizing ****

A. Stress Intensity Factor Calculation for an Elliptical Subsurface Flaw

Flaw Geometry Input :
 Wall Thick., (t) = 8.05 in.
 Distance, S = 0.31 in.
 Flaw depth, a = 0.57 in.
 Flaw length, l = 6.1 in.
 Eccentricity, e = 3.145 in.

For Normal and Upset Condition :

Maximum Stress State :- Decay Heat Trans.
 Membrane Stress, SIGm = 7.8 ksi
 Bending Stress, SIGb = 38.2 ksi
 Yield Strength, SIGys = 50 ksi

$a/l = 0.09$ $2a/t = 0.14$
 $(SIGm + SIGb)/SIGys = 0.92$ $2e/t = 0.78$

From Appendix A, Section XI, ASME B&PV Code :

Q = 0.9 (Fig. A-3300-1)
 Mm = 1.1 (Fig. A-3300-2)
 Mb = 0.89 (Fig. A-3300-4)

KI(ai) = 60.1 ksi sqrt.in

B. Fatigue Flaw Growth Analysis:
 For delta KI determination :

Normal and Upset Condition : From Fig. A-4300-1
 No. of Cycles (N) = 120 (assumed) For Subsurface Flaws
 Membrane Stress, SIGm ; (air environment) ;

Due to Heatup = 4 ksi C = 2.7E-11
 Due to Cooldown = 7.8 ksi n = 3.726
 Delta SIGm = 7.8 ksi $da/dN = c(\Delta KI)^n$

Bending Stress, SIGb ;

	Inside	Outside
Due to Heatup	= -22.2 ksi	22.2 ksi
Due to Cooldown	= 38.2 ksi	-38.2 ksi
Delta SIGb	= 60.4 ksi	

PREPARED BY A.D. Nana DATE 5/21/90

REVIEWED BY K.K. Yoon DATE _____

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company nor may any use be made of it that is or may be injurious to the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request.

$$\Delta KI = (D1 + D2) * \text{Sqrt.}(a_i)$$

where ;

$$D1 = 16.0 \text{ (Delta SIGm * Mm * Sqrt.(pi/Q))}$$

$$D2 = 100.4 \text{ (Delta SIGb * Mb * Sqrt.(pi/Q))}$$

$$D1 + D2 = 116.5$$

$$\Delta KI = 87.9 \text{ ksi sqrt.in}$$

$$da/dN = C * (\Delta KI)^n$$

$$da/dN = 0.000468 \text{ in/cycle; } C = 2.7E-11 ; n = 3.726$$

The final crack size, a_f , in terms of initial crack size, a_i , and above constants ;

$$a_f = [a_i^B + B * C * (D1 + D2)^n * N]^{(1/B)}$$

where ;

$$a_i = 0.57 \text{ in.}$$

$$B = -0.863 \quad (1 - n/2)$$

$$a_f = 0.632 \text{ in.}$$

Calculating KI based on final flaw size ;

$$KI(a_f) = 63.2 \text{ ksi sqrt.in.}$$

C. Safety Factor Assesment :

Material Fracture Toughness:

Per Fig. 3.0-2 of Ref. [6], since oper. temp. > 250 F

(Worst Case HU/CD Transient = CD Trans. 1B2 @ 3.125 hrs.)

$KI_a(250) = 200 \text{ ksi sqrt. in. (See Section 3.0)}$

For Normal/Upset Condition, per IWB-3612,

$$KI_a/KI > \text{sqrt.}10 = 3.16$$

$$KI_a/KI(a_f) = 3.16$$

Therefore, this flaw is acceptable for 120 future cycles.

PREPARED BY A.D. Nana DATE 5/21/90

REVIEWED BY K.K. Yoon DATE _____

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company nor may any use be made of it that is or may be injurious to the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request.

PAGE NO.

7

2.2 Emergency and Faulted Loading Condition Stresses

The stresses due to the emergency/faulted condition, for the upper head to tubesheet weld region are reported in Section 2.4 of Reference 5. The stresses for this loading category are obtained by superimposing the stresses due to LOCA (loss of coolant accident) with the maximum primary pressure stresses of 2566 psi to include the effects of MSLB (main steam line break) and FWLB (feedwater line break) events. The linearized stresses are summarized below:

Transient	Longitudinal stress (ksi)			
	Inside	Outside	Membrane	Bending
LOCA	52.0	-30	11.0	+/-11.0
Pressure (2566psi)	29.2	-11.3	9.0	+/-20.2

The membrane plus bending stress at the crack tip corresponds to 28 ksi due to pressure(2566 psi) and 49 ksi due to LOCA. Therefore, conservatively assume the membrane stress to be 20 ksi and the rest of the stress at the crack tip as bending i.e. $77 - 20 = 57$ ksi. These stresses will be used in the KI calculation on the following page.

PREPARED BY A.D. Nana DATE 5/21/90
 REVIEWED BY K.K. Yoon DATE _____

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company nor may any use be made of it that is or may be injurious to the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request.

Flaw Location : OTSG 1B Head to Tubesheet, ID# 1SGB-WG 58-1
 Indication # : 200 & 402
 **** Using Stresses from NASTRAN Model & Linearizing ****
 A. Stress Intensity Factor Calculation for an
 Elliptical Subsurface Flaw

Flaw Geometry Input :

Wall Thick., (t) - 8.05 in.
 Distance, S - 0.31 in.
 Flaw depth, a - 0.57 in.
 Flaw length, l - 6.1 in.
 Eccentricity, e - 3.145 in.

For Emergency and Faulted Condition :

Maximum Stress State :-
 Membrane Stress, SIGm - 20 ksi
 Bending Stress, SIGb - 57 ksi
 Yield Strength, SIGys - 50 ksi

$\frac{a}{l}$ - 0.09 $\frac{2a}{t}$ - 0.14
 $\frac{(SIGm + SIGb)}{SIGys}$ - 1.54 $\frac{2e}{t}$ - 0.78

From Appendix A, Section XI, ASME B&PV Code :

Q - 0.8 (Fig. A-3300-1)
 Mm - 1.1 (Fig. A-3300-2)
 Mb - 0.89 (Fig. A-3300-4)

KI(af) - 108.8 ksi sqrt.in

As indicated previously in this Section
 KIc - 200 ksi sqrt.in (See Section 3.0)

For Emergency and Faulted Condition, per IWB-3612,

$KIc/KI > \text{sqrt. } 2$ - 1.414

$KIc/KI(af)$ - 1.838

Therefore, this flaw is acceptable for Emergency & Faulted Cond

PREPARED BY A.D. Nana DATE 5/21/90
 REVIEWED BY K.K. Yoon DATE _____

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company nor may any use be made of it that is or may be injurious to the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request.

3.0 Fracture Toughness Determination

The maximum tensile stress at the upper head to tubesheet juncture occurs during the cooldown at 15% power (3.125 hrs into the transient) when the RCS temperature is 250 F. Note that it is the stresses due to this cooldown transient that is evaluated in Section 2.0. This transient is illustrated in Figure 3.0-2 on Page 3-11 of Reference 6.

For the SG shell there is no appreciable fluence cummulation, hence,

$$\begin{aligned} RT_{NDT} &= \text{initial } RT_{NDT} \\ &= 60^{\circ}\text{F (assumed)} \end{aligned}$$

$$T - RT_{NDT} = 250 - 60 = 190^{\circ}\text{F}$$

From Fig. A-4200-1 of Ref. 4, $K_{Ia} = 200 \text{ ksi } \sqrt{\text{in.}}$

For the Emergency and Faulted Condition, the RCS temperature when the pressure is at 2566 psi is significantly greater than 250 F and the minimum RCS temperature during the emergency and faulted condition events is greater than 250 F. Therefore, K_{Ic} is also $200 \text{ ksi } \sqrt{\text{in}}$ per Fig. A-4200-1.

PREPARED BY A. D. Nana DATE 5/21/90
REVIEWED BY K. K. Yoon DATE _____

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company nor may any use be made of it that is or may be injurious to the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request

PAGE NO.

10



GENERAL CALCULATIONS

DOC. I.D. _____

32-1179753-00

4.0 Conclusion

The combined indication (200 & 402) evaluated in this document is found to be acceptable for 120 future heatup/cooldown cycles (since May 1990) per the IWB-3612 criteria.

PREPARED BY	<u> A.D. Nana </u>	DATE	<u> 5/21/90 </u>
REVIEWED BY	<u> K.K. Yoon </u>	DATE	<u> </u>

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company nor may any use be made of it that is or may be injurious to the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request.

PAGE NO.

 11

5.0 References

1. Not used.
2. B&W Drawing 02-129316E-9, "Assy. and Detail of Upper Head". (NSS-3).
3. B&W Drawing 02-129312E-13, "Shell and Tubesheet Attachment Assembly". (NSS-3).
4. ASME Boiler and Pressure Vessel Code, Section XI, 1980 Edition through Winter 1980 Addenda.
5. B&W Document 32-1173627-00, "ANO-1 OTSG Flaw Evaluation", Nov. '88. (For Owners Group OTSG Emergency and Faulted Condition Stresses @ Upper Head to Tubesheet Juncture).
6. B&W Document 32-9811-01, "177 OTSG Minimum Tube Wall Thickness", Nov, 1979.
7. B&W Document 32-1134568-00, "OTSG Stresses - Heatup, Cooldown, Loca", July 1982.
8. B&W Document 32-1153946-00, "ISI Flaw Evaluation, Steam Generator Upper Head to Tubesheet", Nov. 1984.

PREPARED BY A. D. Nana DATE 5/21/90
 REVIEWED BY K. K. Yoon DATE _____

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company nor may any use be made of it that is or may be injurious to the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request.

PAGE NO.

12

6.0 Appendix A

The following is the Volumetric Examination Evaluation Report that contains flaw indications, in the upper head to tubesheet region of Ocone Unit-1 OTSG-1B, found during the May 1990 inspection.

PREPARED BY _____	A. D. Nana	DATE	5/21/90
REVIEWED BY _____	K. K. Yoon	DATE	_____

This sheet including the information contained herein and any associated drawings, is the property of the B&W Nuclear Service Company. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of the B&W Nuclear Service Company nor may any use be made of it that is or may be injurious to the B&W Nuclear Service Company. This sheet and any associated drawings and any copies that may have been made must be returned upon request



Cock & Wilcox
a McDermott company

VOLUMETRIC TEST DATA

CUSTOMER: Duke Power Co. Oconee Unit CONTRACT NO.: 702-2034 COMPONENT: STEAM GEN. 1B (VESSEL)
 DESCRIPTION: STEAM GEN. 1B (UPPER HEAD TO TUBE SHEET. Pg 8 To 51) THERMOMETER: OCQA-223
 I.D. NO.: 1SG8-WG58-1 PROCEDURE: ISI-130 REV. 24 MATERIAL: 9/5 THICKNESS: 8.5" TEST SURF.: OD

NO. POSITIONS: 36 DISTANCE: 12.0" NO. REFERENCE: 20 CAL SHEET: 901023 CAL SHEET: 901010 CAL SHEET: 901011 CAL SHEET:
 BEAM DIRECTION: LONG SHEAR LIMITED EXAM: NO YES? ANGLE: 0 ANGLE: 45 ANGLE: 60 ANGLE:
 EXAMINER: DJ Moss / O.L. Bob ID NO.: M. 8150 LEVEL: II TIME START: 1242 HR. TIME START: 1830 HR. TIME START: 1230 HR. TIME START: A HR.
 EXAMINER: J.W. Stry / J. Bill ID NO.: 89448 LEVEL: II TIME STOP: 1457 HR. TIME STOP: 2020 HR. TIME STOP: 1830 HR. TIME STOP: HR.
 EXAMINER: J.W. Stry / J. Bill ID NO.: 5-5043 LEVEL: II PART TEMP.: 88 °F PART TEMP.: 88 °F PART TEMP.: 88 °F PART TEMP.: °F
 NOTES: INDICATION 200 MBAS. TAKEN FROM TUBE SHEET TOP DATE: 5-6-90 DATE: 5-6-90 DATE: 5-6-90 DATE:
#1 REF. STARTS AT X-AXIS CAL BLK: 40305 WELD INFORMATION 8.0° THICKNESS

old data states W-axis
 No MAX TWD DIMENSION WAS OBTAINABLE DUE TO
 THE GEOMETRY WHERE THE HEAD RADIUS STARTS
 (402) ONLY

DWG NO: OM-201-1878 SURFACE NO2 HTH: FLUSH SURFACE NO.1
ISI-OCQA-004 WD: 4.0"
 FCA(S): TUBE SHEET E: 8.44 UPPER HEAD
 CAT. 89.006 BM: N/A MN: 8.3 BM: 9.045
 HAZ: N/A MAX: 8.6 HAZ: 8.743

1ST SCAN 60° REQUIRED
 2ND SCAN 60° NOT REQUIRED

INDICATION NO(S)	POSITION OR PART ITEM		ANGLE (DEGREES)	SURFACE	BEAM DIRECTION	STATUS	LAM.			CRYSTAL DISTANCE FROM (INCHES)				THROUGH WALL DIMENSION				DAMPS	REMARKS
							MAX. AMP. % DAC	DEPTH (INS)	LGTH	WTH	MINIMUM		MAXIMUM						
	20%	50% / HMA									100%	DEPTH	POSITION (INCHES)	DEPTH	POSITION (INCHES)				
	A	B					A	B	A	B	A	B							
	360°		0°			No	RECORDABLE INDICATIONS												
200	27 To 28		45°	1	2	SEP.	282	7.437	6.1		5.4	10.75	7.135	10.15	7.638	11.2	No		
							50	7.437			1.6	10.5						50% EP	
							50	7.337			7.7	10.5						50% EP	
							224	7.235			4.5	10.3	7.135	10.0	7.738	11.0	No		
							224	7.537			3.6	10.6	7.135	9.9	7.737	10.8	No		
							125	7.235			2.7	10.5	7.235	10.2	7.738	11.0	No		
							50	7.235			1.8	10.5	7.135	10.0	7.638	11.0	No		
							125	7.538			6.3	10.5	7.135	10.0	7.537	10.9	No		
							50	7.336			7.2	10.5	7.135	10.2	7.537	11.0	No		
	360°		45°			No	OTHER RECORDABLE INDICATIONS												

REVIEWED BY: Howard Stojilman LEVEL: II DATE: 8 MAY '90 FIGURE NO.: B02.040.003
 ANGLE: 0 DEG. 45 DEG. 60 DEG. OTHER: E.R. REQUIRED: YES NO E.R. NUMBER: 901-002
 IND. NOS. 1 TO 199 200 TO 399 400 TO 599 600 TO 799 PAGE 1 OF 8

VOLUMETRIC TEST DATA FORM 101

BWNP-20531-3 (10-84)

CUSTOMER: DUKE POWER CO. OCOONEE I										CONTRACT NO: 702-2034					COMPONENT: VESSEL SGB						
EXAMINER: J.W. Setzer					ID: S-5643			LEVEL II		DATE(S): 5-6-90											
EXAMINER: J. Bill					ID: B-9449			LEVEL II													
IND. NO.	POSITION OR PART ITEM	ANGLE (DEG)	SURFACE	BEAM DIRECTION	STATUS	LAM.		LNPTH	WDTH	(INCHES)				THROUGH WALL DIMENSION				DAMPS	REMARKS		
						MAX AMP % DAC	DEPTH (IN.)			20%	50% OR HMA	100%	CRYSTAL DISTANCE		MINIMUM		MAXIMUM				
								A	B				1	2	DEPTH	POSITION IN.				DEPTH	POSITION IN.
						A	B			A	B	A				B					
400	25 to 27	60	1	2	SEP	125	7.3		1.0		12.0		12.6	7.1		12.0	7.5		13.1	NO	
						50	7.4				11.6										
						50	7.3				12.6										
401	20 to 21	60	1	2	SEP	80	7.1		1.5		2.5		12.0	6.9		11.5	7.2		12.1	NO	
						50	7.1				2.0										
						50	7.1				3.5										
402	27 to 28	60	1	2	SEP	251	6.8		4.4		5.1		13.2	6.6		12.9					NO
						50	6.8				2.8		13.2								
						50	6.8				7.2		13.2								
						251	6.8				3.7		13.2	6.6		12.9					
						251	6.8				4.6		13.2	6.6		12.9					
						200	6.8				5.5		13.2	6.6		12.9					
						159	6.8				6.4		13.2	6.6		12.9					
	360°	60				NO OTHER RECORDABLE INDICATIONS															

SEE NOTES

REVIEWED BY: Howard Stoppelman LEVEL: II DATE REVIEWED: 8 MAY '90 FIGURE NO.: B02-040.003



Babcock & Wilcox
 a McDermott company
 SPECIAL PRODUCTS
 AND
 INTEGRATED FIELD SERVICE

ISI, LIMITED EXAMINATIONS

CUSTOMER: DUKE POWER COMPANY, SITE: OCONEE, UNIT: I
 CONTRACT NO.: 702-2034
 COMPONENT: Steam Generator, I.D. NO.: ISGB-WG58-1

TEST METHOD: U.T.

BWNP

(7-87)

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 3 AND 5 8.5 INCHES FROM POINT 3 TO 8.5
 INCHES FROM POINT 5 10 INCHES FROM WELD ξ TO beyond INCHES FROM
 WELD ξ
 ANGLE(S) 0° 45° 60° ___° ___° ___° N/A
 DUE TO: Scub in Shipping Tie Down Removal AREA

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS ___ AND ___ INCHES FROM POINT ___ TO ___
 INCHES FROM POINT ___ INCHES FROM WELD ξ TO ___ INCHES FROM
 WELD ξ
 ANGLE(S) 0° 45° 60° ___° ___° ___° N/A
 DUE TO: ___


NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
360 DEGREES. 3.5 INCHES FROM WELD ξ TO beyond INCHES FROM WELD ξ
 ANGLE(S) 0° 45° 60° ___° ___° ___° N/A
 DUE TO: TAPER on Tube sheet AREA

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 ___ DEGREES. ___ INCHES FROM WELD ξ TO ___ INCHES FROM WELD ξ

ANGLE(S) 0° 45° 60° ___° ___° ___° N/A
 DUE TO: ___

NOTES: _____

SKETCH:



SEE ATTACHMENT NO(S): _____

REVIEWED BY: Howard Hornsman LEVEL: II DATE: 8 MAY '90

FIGURE NO.: B02.040.003



Babcock & Wilcox
 a McDermott company
 SPECIAL PRODUCTS
 AND
 INTEGRATED FIELD SERVICE

ISI, LIMITED EXAMINATIONS

CUSTOMER: DUKE POWER COMPANY, SITE: OCONEE, UNIT: I
 CONTRACT NO.: 702-2034
 COMPONENT: STEAM Generator, I.D. NO.: ISGB-WG58-1

TEST METHOD: U.T.

BWNP (7-87)

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 33 AND 34 . 0.0 INCHES FROM POINT 33 TO 2.0
 INCHES FROM POINT 34 . 10 INCHES FROM WELD ξ TO beyond INCHES FROM
 WELD ξ
 ANGLE(S) 0° 45° 60° ___° ___° ___° N/A
 DUE TO: Scrub in shipping tie Down Removal Area

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 35 AND 3 . 5.0 INCHES FROM POINT 35 TO 5.0
 INCHES FROM POINT 3 . 19.5 INCHES FROM WELD ξ TO beyond INCHES FROM
 WELD ξ
 ANGLE(S) 0° 45° 60° ___° ___° ___° N/A
 DUE TO: MANWAY

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ
 ANGLE(S) 0° 45° 60° ___° ___° ___° N/A
 DUE TO: _____

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ
 ANGLE(S) 0° 45° 60° ___° ___° ___° N/A
 DUE TO: _____

NOTES: _____

SKETCH: _____

SEE ATTACHMENT NO(S): _____

REVIEWED BY: Howard Stogdins LEVEL: II, DATE: 8 MAY '90

FIGURE NO.: BOZ.040.003



Babcock & Wilcox
 a McDermott company
 SPECIAL PRODUCTS
 AND
 INTEGRATED FIELD SERVICE

ISI, LIMITED EXAMINATIONS

CUSTOMER: DUKE POWER COMPANY, SITE: OCONEE, UNIT: I
 CONTRACT NO.: 702-2034
 COMPONENT: STEAM GEN B, I.D. NO.: ISGB-VG 58-1

TEST METHOD: UT

BWNP

(7-87)

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 26 AND 30 6 INCHES FROM POINT 26 TO 6
 INCHES FROM POINT 30 15 INCHES FROM WELD ξ TO _____ INCHES FROM
 WELD ξ AND BEYOND
 ANGLE(S) 0° 45° 60° ° ° ° N/A
 DUE TO: SUPPORT PAD

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 4 AND 5 3.5 INCHES FROM POINT 4 TO 6.5
 INCHES FROM POINT 5 8.5 INCHES FROM WELD ξ TO 11.5 INCHES FROM
 WELD ξ
 ANGLE(S) 0° 45° 60° ° ° ° N/A
 DUE TO: 1 1/2" ϕ VENT CONN.

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ

 ANGLE(S) 0° 45° 60° ° ° ° N/A
 DUE TO: _____

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ

 ANGLE(S) 0° 45° 60° ° ° ° N/A
 DUE TO: _____

NOTES: _____

SKETCH: _____

 SEE ATTACHMENT NO(S): _____

REVIEWED BY: Howard H. [Signature] LEVEL: II DATE: 8 MAY '90
 REVIEWED BY: _____ TITLE: _____ DATE: _____

FIGURE NO.: B02.040.003



Babcock & Wilcox
 a McDermott company
 SPECIAL PRODUCTS
 AND
 INTEGRATED FIELD SERVICE

ISI, LIMITED EXAMINATIONS

CUSTOMER: DUKE POWER COMPANY, SITE: OCONEE, UNIT: I
 CONTRACT NO.: 702-2034
 COMPONENT: STEAM GEN B, I.D. NO.: 15GB-WG 5B-1

TEST METHOD: UT

BWNP

(7-87)

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 12 AND 16 6 INCHES FROM POINT 12 TO 6
 INCHES FROM POINT 16 15 INCHES FROM WELD ξ TO _____ INCHES FROM
 WELD ξ AND BEYOND
 ANGLE(S) 0° 45° 60° ° ° ° N/A
 DUE TO: SUPPORT PAD

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 19 AND 23 6 INCHES FROM POINT 19 TO 6
 INCHES FROM POINT 23 15 INCHES FROM WELD ξ TO _____ INCHES FROM
 WELD ξ AND BEYOND
 ANGLE(S) 0° 45° 60° ° ° ° N/A
 DUE TO: SUPPORT PAD

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ
N/A
 ANGLE(S) 0° 45° 60° ° ° ° N/A
 DUE TO: _____

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ
N/A
 ANGLE(S) 0° 45° 60° ° ° ° N/A
 DUE TO: _____

NOTES: _____

SKETCH:

SEE ATTACHMENT NO(S): _____

REVIEWED BY: Herman H. Huppelmann LEVEL: II, DATE: 8 MAY '90

FIGURE NO.: B02.040.003



Babcock & Wilcox
 a McDermott company
 SPECIAL PRODUCTS
 AND
 INTEGRATED FIELD SERVICE

ISI, LIMITED EXAMINATIONS

CUSTOMER: DUKE POWER COMPANY, SITE: OCONEE, UNIT: I
 CONTRACT NO.: 702-2034
 COMPONENT: SG B, I.D. NO.: 1 SGB-WG58-1

BWNP

(7-87)

TEST METHOD: UT

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 33 AND 2 7 INCHES FROM POINT 33 TO 6
 INCHES FROM POINT 2 15 INCHES FROM WELD ξ TO _____ INCHES FROM
 WELD ξ AND BEYOND.
 ANGLE(S) 0° 45° 60° _____° _____° _____° N/A
 DUE TO: SUPPORT PAD

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 BETWEEN POINTS 5 AND 9 6 INCHES FROM POINT 5 TO 6
 INCHES FROM POINT 9 15 INCHES FROM WELD ξ TO _____ INCHES FROM
 WELD ξ AND BEYOND.
 ANGLE(S) 0° 45° 60° _____° _____° _____° N/A
 DUE TO: SUPPORT PAD

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ

 ANGLE(S) 0° 45° 60° _____° _____° _____° N/A
 DUE TO: _____

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 A B
 _____ DEGREES. _____ INCHES FROM WELD ξ TO _____ INCHES FROM WELD ξ

 ANGLE(S) 0° 45° 60° _____° _____° _____° N/A
 DUE TO: _____


NOTES: _____

SKETCH: _____

 SEE ATTACHMENT NO(S): _____

REVIEWED BY: Howard Hoggins LEVEL: II DATE: 8 MAY '90
 REVIEWED BY: _____ TITLE: _____ DATE: _____

FIGURE NO.: B02-040.003




COMMENTS:

GEOMETRIC

REPORTABLE

CUSTOMER:	DURE POWER CO OGONEE 1
PROJECT NO:	702-2034
WELD NO:	1SG-B-WG-58-1
ANALYST:	
SNT LEVEL:	
DATE:	
FIGURE NO:	B02-040-003



D. L. Robinson

5-7-90



DOCUMENT RELEASE NOTICE (DRN)

Release Date _____
 Records Mgmt. Initials _____

CONTRACT NO. 702-2034 PLANT Oconee Unit 1 CHARGE NO. _____ Page 1 of 1

3-DIGIT TASK NO., PART NO., OR TASK-GROUP-SEQ.	B&W DOCUMENT NO.	DOCUMENT TITLE (30 Characters Maximum)	SAFETY CLASS (OMIT FOR NSS-15, 16 & 23)	PUL STAT (Y/N)	COM ATT? (Y/N)
140	32-1179753-00	OC-1 OTSG Flaw Evaluation	S	N	N

Keywords : Fracture Mechanics,
 Flaw Evaluation,
 OTSG, LEFM.

REQUIRED DISTRIBUTION (ORGANIZATION OR TE)	NO. COPIES			INFORMATION COPIES (INDIVIDUAL'S NAME)	NO. COPIES		
	DRN	DOC	COM		DRN	DOC	COM
MG HACKER	1	1		KK YOON	1	1	
WD MINTON	1	1		AD NANA(Originals)	1	1	
TP SURRATT	2	1					

PROJECT ENGINEER/PM APPROVAL:
 (SIGNATURE) _____
 (PRINTED NAME) _____ DATE _____

RELEASED BY (PREPARER):
 (SIGNATURE) Ad Nana 5/31/90
 (PRINTED NAME) ASHOK NANA
 DATE

REVIEWED BY:
 (SIGNATURE) KK Yoon 5/31/90
 (PRINTED NAME) K. K. YOON
 DATE

DUKE POWER CO.
OCONEE - UNIT #1
STEAM GENERATOR 1B
UPPER HEAD TO TUBESHEET: 1SGB-WG58-1

EVALUATION OF INDICATIONS:

FIG. NO. B02.040.003

EVALUATION REPORT NO.: 901-002

INDICATION #200/#402

$$t = 8.3" - .25" = 8.05"$$

$$S = 8.05" - 7.738" = .31"$$

$$2d = 7.738" - 6.6" = 1.14"$$

$$d = 1.14/2 = .57"$$

$$.4d = .4 \times .57 = .23"$$

$S > .4d$ = SUBSURFACE FLAW

$$a = d = .57"$$

$$l = 6.1"$$

$$a/l = .57/6.1 = .09$$

$$a/t = .57/8.05" = 7.17.$$

IWB-3511-1 ALLOWABLE FOR .09 ASPECT RATIO IS 2.88Y

$$Y = S/a = .31/.57 = .544$$

$$2.88 \times .544 = 1.577. a/t$$

7.17. $a/t > 1.577. a/t$ = UNACCEPTABLE

INDICATION # 400

$$t = 8.3 - .25 = 8.05''$$

$$S = 8.05 - 7.5 = .45''$$

$$2d = 7.5 - 7.1 = .4''$$

$$d = .4/2 = .2''$$

$$.4d = .4 \times .2 = .08''$$

$S > .4d =$ SUBSURFACE FLAW

$$a = d = .2''$$

$$l = 1.0''$$

$$a/l = .2/1 = .2$$

$$a/t = .2/8.05 = 2.59.$$

IWB-3511-1 ALLOWABLE FOR .2 ASPECT RATIO IS 3.6Y a ,
 $Y = S/a = .45/.2 = 2.25$, IF $Y > 1$, $Y = 1$

2.59. $a/t < 3.69. a/t =$ ACCEPTABLE

PAGE 2 OF 3

32-1179753-00

INDICATION # 401

$$t = 8.3 - .25 = 8.05$$

$$S = 8.05 - 7.2 = .805$$

$$2d = 7.2 - 6.9 = .3$$

$$d = .3/2 = .15$$

$$.4d = .4 \times .15 = .06$$

$S > .4d =$ SUBSURFACE FLAW

$$a = d = .15$$

$$l = 1.5$$

$$a/l = .15/1.5 = .10$$

$$a/t = .15/8.05 = 1.97$$

IWB-3511-1 ALLOWABLE FOR .10 ASPECT RATIO IS 2.97 a/l

$$Y = S/a = .805/.15 = 5.37, \text{ IF } Y \neq 1, Y = 1$$

1.97 $a/t < 2.97$ $a/t =$ ACCEPTABLE

M. G. Hoehen Level III 5-11-90

PAGE 3 OF 3

32-1179753-00

DUKE POWER COMPANY

Request For Relief From
Inservice Inspection Requirement

Station: Oconee

Unit: 1,2 and 3

Requesting Department: Quality Assurance, Inservice Inspection

Reference Code: ASME Boiler and Pressure Vessel Code, Section XI 1980
Edition through Winter 1980 Addenda

I. Component for which exemption is requested:

a. Name and Identification Number:

Main Steam Turbin Stop Valve Upper Head to Valve Body Studs.
Valve Manual OM-200-195

b. Function: Pressure retaining bolting of upper head to valve body

c. ASME Section XI Code Class: Class 2

d. Construction Code and Class: ANSI (USAS) B31.1, Class F

e. Valve Category: Category A

II. Reference Code Requirement that has been determined to be impractical:

Table IWC-2500-1; Category C-D; Item C4.40
Volumetric Examination requirements of figure number IWC-2500-6

III. Basis for Requesting Relief:

ASME Section XI, IWC2500-6 requires that the full volume of the thread portion of the stud be examined. This request for relief is on the premise that even though the code requires a volumetric examination of the entire length of the stud, the actual areas of concern would be the thread run-out points, where the threads meet the body of the stud; the first three to four threads that engage the nut.

The Design Engineering Department of Duke Power Co. performed an evaluation to support this request. It was concluded that the last 2.9" of the stud that is engaged in the valve body would not have any significant load that would lead to the stud's failure (see Certification of Engineering Calculation No. OSC-3369 attached to this request.)

The stud manufacturer, General Electric (GE), in their document "Valve Studs-Tighting, Inspection & Replacement Recommendations (TIL-891)", states; "The results obtained to date indicate that crack indications will appear at the first or second thread, 0-1/4 inch below the valve joint surface..." (See page 16 of Certification of Engineering Calculation No. OSC-3369 for this statement).

IV. Alternate Examination:

Article 5 of ASME Section V, Paragraph T-541.5 specifies the ultrasonic examination be performed from the end of the bolt. Calibration shall be established from a 3/8" diameter, 3" long, flat bottom hole drilled in the end of the calibration standard(s) with dimensions as identified in Table 541.5.2. Configuration of the Main Steam Upper Head Studs on the Turbine Stop Valve prevents this technique from being properly utilized.

The Main Steam Turbine Stop Valve Upper Head Stud is configured with a .620" diameter heater hole that runs 11.13" of the length of the stud. An in-place examination using an ultrasonic angle beam transducer can be performed from the heater hole.

ASME Section XI 1983 winter addenda specifies that a procedure qualification be performed in accordance with Paragraph VI-2430. The sensitivity of the examination shall be established using a qualification specimen with notches of dimensions that are specified in Table VI-2430-1. The ultrasonic examination specified in Article 5 of ASME Section V, Paragraph T-541.5 can not be performed using that calibration block design. However, an angle beam examination has been established using the qualification specimen design identified in the

Serial No. ONS-009

Page 3 of 3

ASME Section XI 1983 winter addenda, Paragraph VI-2430. This technique is an in-place examination that employs a 45 degree angle beam transducer through the heater hole. It is capable of detecting cracks from the top of the stud to the last two threads engaged in the valve body. This is approximately 1.5" beyond the critical area identified in the Certification of Engineering Calculation No. OSC-3369.

V. Implementation Schedule:

This examination is scheduled to be performed during the current (10th) refueling outage for Oconee Unit 2 during the period from May 19, 1989 to July 2, 1989. For Oconee Units 1 and 3 these examinations are scheduled to be performed during upcoming outages 12 and 11 respectively.

February 3, 1989

MOEE-89-052

G. W. Grier, Manager
Quality Assurance

Attention: A. C. Gladney

Re: ISI of Turbine Stop Valve
Request for Relief
File: OS-27-M

This is in response to your letter of November 30, 1988 on the above subject.

Based on our evaluation which is documented in our calculation OSC-3369, we support your request for relief. It is our judgement that as long as your proposed UT procedure cover the threads between points B and C on our sketch OSC-3369, we will have inspected the critical threads on the valve end of the stud.

For your records, attached is a copy of our calculation OSC-3369. Please advise if we may be of further help.

B. L. Peele, Jr., Division Project Manager
Oconee Engineering Division



By: R. L. Williams
Engineering Consultant

RLW/acb

Attachment

cc w/o att: Central Records

Dev./Station Oconee Unit 1-3 File No. OSC - 3369
 Subject Main Steam Turbine Stop
Valve Upper Head Stud By R.L. Williams Date 1/10/89
 Sheet No. 1 of 3 Problem No. _____ Checked By G.D. Robison Date 1/16/89

PROBLEM

The Q.A. Department is in the process of developing a procedure to do the ISI of the Main Steam Stop Valve Upper Head Studs in place. This valve is Q.A. Condition 1 and the requirements of ASME SECTION XI, 1980 Edition through W'80 Addenda apply.

Q.A. has evaluated the situation and plans to seek relief from the 100% UT requirement imposed by ASME Section XI. They are asking for Design Engineering review and concurrence with their plan of action. For further detail, see A.C. Gladney's letter of Nov. 30, 1988 and its attachments (Attachment No. 1 to this Calculation).

ASSUMPTIONS

Sketch OSC-3369 (Attachment No. 2 to this Calculation) shows the general dimensions and configuration of the upper head stud. This sketch is based on field measurements furnished by Q.A. (Attachment No. 3 to this Calculation). For the purpose of this evaluation, we are assuming that:

- The portion of the stud between points B and D are screwed into the valve body.
- UT will be performed by inserting a 45° transducer into the stud through the .620" hole at end A.
- The transducer will traverse the I.D. of the stud from point A to C.
- This will give UT coverage from point A through C.
- Q.A. will be seeking relief from the UT of the portion of the stud from approximately point C to D.
- The material is ferritic and stamped "L" per GE TIL.

Dev./Station Oconee

Unit 1-3 File No OSC-3369

Subject: Main Steam Turbine Stop Valve

Upper Head Stud

By R.L. Willin 1/10/89

Sheet 2 of 3 Problem No.

Checked By G.D. Robison 1/16/89

REFERENCES

1. ASME SECTION XI, 1980 Edition through W'80 Addenda Rules for Inservice Inspection of Nuclear Power Plant Components.
2. "An Introduction to the Design and Behavior of Bolted Joints" © 1981, 5th Printing by John H. Bickford.

EVALUATION

No specific information such as material properties is available for a numerical analysis of the stud. Our evaluation will therefore be based on the past history of similar studs and the normally expected behavior of threaded fasteners.

From the UT procedure included in TIL-891, we find that the cracking found to date in similar studs, occurs in the vicinity of the 1st or 2nd thread. This is 0" to .250" from point B on sketch OSC-3369. This is expected since the juncture of a fastener pair is subject to the highest loads and moments.

From reference No. 2 we find that:

- The first 3 threads carry most of the load.
- The tensile stress in the bolt falls off rapidly as it gets further into the internally threaded part. At a distance into the part equal to about half of the bolt diameter, the tensile stress is less than $\frac{1}{2}$ of the tensile stress ~~is less than $\frac{1}{2}$ the~~ in the unthreaded shank of the bolt. In this case, the half diameter insertion depth is

$$\frac{2.230''}{2} = 1.115''$$

Dev. System

Oconee

Unit 1-3

File No.

OSC-3369

Subject

Main Steam Turbine Stop Valve
Upper Head Stud

R. L. Williams

1/10/89

Sheet No.

3 of 3

Problem No.

Checked By

G. D. Robison

1/16/89

CONCLUSIONS

The proposed UT should cover the area that has contained any cracks found in similar studs. It should also cover the area over which the stud will have any significant loading. The area in which Q.A. seeks relief from the UT requirement is a relatively low stress area and any indications which might exist should not propagate.

∴ Design Engineering can support Q.As. request for relief.

Att. No. 1
Calc. OSC-3369
Pg. 1 of 21

November 30, 1988

R L Williams

- Re: Request For Design Engineering Support in the Examination of the
Main Steam Turbine Stop Valve Upper Head Stud at Oconee Unit #1

This memorandum is a follow-up on our discussion, November 28, on the ultrasonic examination of the main steam turbine stop valve upper head studs. In that discussion I identified that QA would need the support of Design Engineering in two areas:

- 1) Support documentation for a request for relief
- 2) A design approved drawing of the upper head stud

The request for relief is on the premise that even though it is a code requires a volumetric examination of the entire length of the stud, the actual areas of concern would be the thread run-out points, where the threads meet the body of the stud; the first three to four threads that engage the body of the valve; and the first three to four threads that engage the nut. The stud manufacturer, General Electric (GE), in their document "Valve Studs-Tighting, Inspection & Replacement Recommendations (TIL-891), states; " The results obtained to date indicate that crack indications will appear at the 1st or 2nd thread, 0-1/4 inch below the valve joint surface..."


I am attaching a copy of this document for your information:

The drawing is for support documentation of the calibration standard. GE will not provide a drawing that specifies the dimensions of the stud. This type of information proprietary. Jack Packard, my contact at GE, feels he may be allowed to approve a Duke Power drawing of the stud as a courtesy. For your information, a copy of this phone conversation is also attached.

Request For Design Engineering Support
November 30, 1988
Page 2 of 2

Att. No. 1
Calc. 056-3369
Pg. 2 of 21

I am requesting that the support documentation and drawing be provided by December 7, 1988. If I can be of any assistance in expediting the matter, please contact me at your convenience at 373-4842. An alternative contact will be Carl Freeman at Oconee. His number is 882-2406.



A C Gladney
NDE Level III
QA Technical Services

ACG
Attachments

cc w/o attachments
E B Miller
C B Cheezem

cc w/attachments
T L Tucker
Carl Freeman-ONS

[- A.J. Grunsky letter of Feb. 29, 1980
- G.E. TIL - 891-3 dated Dec. 20, 1979
- Telephone Conversation Record
File No. UT-88-8

DUKE POWER COMPANY
STEAM PRODUCTION DEPT.
GENERAL OFFICES
422 SOUTH CHURCH STREET
CHARLOTTE, N. C. 28242

P. O. BOX 33169

Att. No. 1
Calc. OSC-3369
Pg. 3 of 21
TELEPHONE: AREA 708
373-4011

February 29, 1980

ALL STATION MANAGERS

Attention: Superintendents of Maintenance

Subject: General Electric Company
TIL 891-3
"Valve Studs-Tightening, Inspection and
Replacement Recommendations"
GS-200.24

Re-securing

*GPK / SPP / TIL put in TIL file
& in outage book*

Gentlemen:

The subject GE TIL is attached for your information and outage planning usage.

In reference to the TIL, the following comments are made:

- a) Stud Lubricants--Almost exclusively on our system, we use "Never-Seez Compound" bolt lubricant. Reference GE TIL 824 and C. W. Hendrix's letter of July 12, 1977, on TIL 824.
- B) Many fossil units on our system with stop-valve studs in service before 1965 have already had the studs replaced due mainly to creep rupture crackage or plastic deformation (useful life of the stud has been used up).
- C) There have been no major problems with the Austenitic studs on the few 1050°F valves on our system.
- D) Since all valve studs are ultrasonically tested during each major outage, this means that on an average of every five years all valve studs are checked for cracks and the cracked studs are replaced. Each station should have an adequate number of spare studs as spares (based on past experience) on hand for each outage. In the event a station might experience a shortage of studs during an outage, I would suggest using the system turbine/generator parts interchangeability listing to possibly locate the required studs at another plant on the system.
- E) With our present inspection schedule, all fossil valve studs will probably be replaced in the time interval specified in the TIL.
- F) The GE TIL 176 procedure is used to U.T. the studs which are identical to the recommendations in TIL 891.

ALL STATION MANAGERS
Page 2
February 29, 1980

Att. No. 1
Calc. OSC-3369
Pg. 4 of 21

If you have any questions concerning this TIL, please call me.

Very truly yours,



Alan J. Grunsky
Associate Engineer

AJG/dw

cc: Oscar Lashmit - SMS

GENERAL ELECTRIC

GENERAL ELECTRIC COMPANY, 141 PROVIDENCE ROAD, P.O. BOX 30897
CHARLOTTE, NORTH CAROLINA 28230. Phone (704) 371-3300

December 20, 1979

SUBJECT: ALLEN #1, #2, #3, #4, #5
TURBINES #108848, #115013, #115034-#118363, #118391-#118392,
#128974-#128925

BUCK #3, #5, #6
TURBINES #34663, #93386, #99611

CLIFFSIDE #4, #5
TURBINES #83611, X533

DAN RIVER #1, #2, #3
TURBINES #83656, #87400, #101670

LEE #1, #2, #3
TURBINES #87460, #87461, #115033

MARSHALL #1, #2, #3, #4
TURBINES #X142-X143, X249-X250, X297, X357

OCONEE #1, #2, #3
TURBINES #X392, X393, X449

RIVERBEND #6, #7
TURBINES #99688, #101603

VALVE STUDS - TIGHTENING, INSPECTION & REPLACEMENT RECOMMENDATIONS

TIL - 891-3

Duke Power Company
P. O. Box 33189
Charlotte, N. C. 28242

Attn: Paul H. Barton, Manager
System Operations & Maintenance Nuclear & Fossil

Gentlemen:

The purpose of this TIL is to recommend tightening levels for turbine steam valve studs used to secure the upper heads on main stop valve and reheat valve casings and the stands on control valve casings. Recommendations are also provided for

Att. No. 1

INSTALLATION AND
Calc. 056-33-69
SERVICE ENGINEERING
Pg. 5 of 21
BUSINESS DIVISION

GENERAL  ELECTRIC

Att. #1

Page.... 2


Calc. OSC-3369

pg. 6 of 21

inspection and replacement of valve studs to minimize the probability of in-service failure.

If you have any questions, please give me a call.

Very truly yours,



J. M. Corriher
Service Supervisor
Steam Turbines

pdm
Attachment/s

cc: Alan Grunsky

V
10

VALVE STUDS - TIGHTENING, INSPECTION
&
REPLACEMENT RECOMMENDATIONS
(TIL-891)

Att. #1
Calc. 05C-3369
Pg. 7 of 21

INTRODUCTION

The purpose of this Technical Information Letter is to recommend tightening levels for turbine steam valve studs used to secure the upper heads on main stop valve and reheat valve casings and the stands on control valve casings.

Recommendations are also provided for inspection and replacement of valve studs to minimize the probability of in-service failure.

BACKGROUND

Last year an operating fossil unit experienced sudden failure of 10 out of 14 main stop valve upper head studs. The upper head lifted partially, permitting steam to escape and resulting in a forced outage. It appears likely that the head would have come off altogether if the centering rabbet had not become wedged in the cylindrical casing fit. A similar incident occurred 13 years earlier when 9 out of 16 upper head studs failed suddenly on another fossil main stop valve.

Studies were made of the variables affecting valve stud life following the 1st incident. Some of the variables are: length of time in service, number of retightenings, tightening stress level, thermal cycling and differential expansion. It was determined that the major factors are tightening stress level and number of tightenings to that stress level. As a result, a reduced tightening stress, called the "1970 level", was implemented for the valve stud materials used on most fossil units. Also, recognizing that valve studs may have limited service life regardless of the stress level, it was recommended that they be inspected for cracks at least every 6 years.

This Technical Information Letter will repeat and re-emphasize the tightening and inspection recommendations made earlier for fossil valve studs. In addition, the recommendations are being expanded in two respects. First, the useful life is predicted and replacement is recommended for certain studs regardless of whether cracks are found at inspection. Second, the recommended frequency of inspection is related to number of tightenings as well as to number of years in service.

Factors affecting the life of nuclear valve studs (operating at temperatures below 800°F) differ from those affecting fossil valve studs. Nuclear valve studs are not operating in the material creep range. Therefore, stud life is not related to tightening stress or number of tightenings in the same manner as for fossil valve studs. Stud life can be affected by excessive overtightening, corrosion and other factors, however, making it advisable to establish a regular inspection program. Recommendations for fossil and nuclear valve studs, being somewhat different, are covered separately in this Technical Information Letter.

Att. # 1
Calc. OSC-3369
Pg. 8 of 21

STUD MATERIALS

Table I lists the materials and identification stampings that have been used for valve upper head and stand studs.

B5F4C and B5F5B will be found on nuclear valves (below 800°F).

B5F5B and B50A125E are by far the most commonly used stud materials on fossil valves (800°F and higher). If any studs of B50A125B or C remain in service, the recommendations for B50A125E apply.

Austenitic stud materials have been used on a limited number of fossil valves at 1050°F and higher. Austenitic studs are non-magnetic.

It is expected that most owners can identify their stud materials from previous inspection and tightening records. If not, the material should be determined from the stamping at the next inspection. In those cases where the material is not known, and needs to be known as an input for scheduling maintenance (for example, on pre-1966 units), the necessary information can be obtained through your G.E. Service Engineer.

STUD LUBRICANTS

FEL-PRO N1000 and CRANE COMPOUND JC 60 are approved thread lubricants See TIL 824 for more detail.

TIGHTENING RECOMMENDATIONS

A. Fossil Valve Studs (800°F and higher)

The recommended elongation ranges for B5F5B and B50A125E studs are given on attached drawing 223A3906. This is the "1970 Level" which is approximately 70% of the pre-1970 stress level. Drawing 223A3906 takes precedence over instructions on valve assembly drawings issued before the "1970 Level" was implemented.

Tightening of austenitic studs (see Table I) should be continued per the original valve assembly drawing instructions.

B. Nuclear Valve Studs (below 800°F)

The elongation range for B5F4C and B5F5B, operating below 800°F, is also given on drawing 223A3906. This is essentially the pre-1970 stress level before it was reduced for those valve studs operating in the material creep range.

REPLACEMENT RECOMMENDATIONS

A. Fossil Valve Studs (800°F and higher)

Most valve studs operating at 800°F and higher are in the creep range of the stud material. After the studs are tightened, and the valve brought up to operating temperature, the material will

REPLACEMENT RECOMMENDATIONS - (Cont'd.)

be accounted for in determining the initial tightening stress level in order to prevent leakage from developing in service. Each time a stud is tightened to the initial stress level some of the stress creeps out in service and the stud suffers some plastic strain damage. The plastic strain accumulates with each tightening cycle until finally, after some number of cycles the rupture ductility of the material is used up and a crack will develop.

A bending stress is also imposed on valve studs due to the difference in expansion of the valve casing and upper head during heating and cooling cycles. Low cycle fatigue due to bending is a contributing cause of valve stud failure but is not the primary damage mechanism when recommended rates of temperature change are observed. Creep rupture damage, as described in the preceding paragraph, is considered to be the primary damage mechanism for fossil valve studs and the number of tightenings is the primary measure of the amount of stud life expended.

Using analytical methods calibrated by laboratory and field data we now believe that the useful life of fossil valve studs can be predicted based on number of tightenings with sufficient accuracy to be helpful in maintenance planning. The end of useful life is considered to have been reached after that number of tightenings which corresponds to a 50% probability of stud cracking. At this point it is recommended that all studs that have experienced that number of tightening cycles be replaced regardless of whether cracks are detected. The rupture ductility will have been nearly used up and the probability of cracking before the next inspection will be high.

The following recommendations assume the valve studs were tightened to the recommended stress levels in effect at the time of the tightening, and that recommended rates of temperature change were observed at the valves. Higher stress levels or temperature rates can be expected to cause earlier stud failures:

B5F5B Stud Material:

All valve upper head and stand studs in service before 1966 have seen at least 14 years of service, and for at least 5 of those years were stressed to the pre-1970 level. Assuming one tightening every 2 years on the average, they have been tightened at least 7 times and are near the end of useful life as defined above. It is recommended that all B5F5B fossil valve studs in service before 1966 be replaced by the end of 1981.

Newer B5F5B studs (in service in 1966 and later) should be replaced after 11 tightenings or if cracks are found during periodic inspections. This is discussed in more detail under "INSPECTION RECOMMENDATIONS".

Att. #1
Calc. OSC-3369
Pg. 10 of 21

B5F5B Stud Material - (Cont'd.)

Replacements for B5F5B studs will also be made of B5F5B. It is true that B50A125E has a longer life expectancy and is used on all new fossil valves. The problem is that the two materials have different coefficients of expansion and different tightening stress levels, making it unacceptable to mix them on the same valve. It is also undesirable to mix the materials on similar valves on the same unit, or in the same station, because of the bookkeeping problems created. The life expectancy of replacement B5F5B studs is 11 tightenings (estimated to correspond to about 22 years). This is felt to be an acceptable life expectancy on most units requiring replacements.

B50A125E Stud Material:

All valve upper head and stand studs in service before 1966 have seen at least 14 years of service, and for at least 5 of those years were stressed to the pre-1970 level. Assuming one tightening every two years on the average, they would have been tightened at least 7 times and are near the end of useful life as defined above. It is recommended that all B50A125E fossil valve studs in service before 1966 be replaced by the end of 1983. (This also applies to studs of B50A125B&C if any remain in service).

Newer B50A125E studs (in service in 1966 and later) have a useful life expectancy of about 25 tightenings because of the reduced tightening stress level. Assuming one tightening every 2 years on the average, these studs have a high probability of lasting as long as the turbine. However, tightening records should be kept and the studs should be replaced after 25 tightenings if this number is reached. Inspection and replacement, if cracks are found, should be as discussed under "INSPECTION RECOMMENDATIONS".

Austenitic Stud Material:

Austenitic studs have not shown a tendency to crack due to loss of rupture ductility, and so there are no replacement recommendations related to number of tightenings. Inspection and replacement, if cracks are found, should be as discussed under "INSPECTION RECOMMENDATIONS".

B. Nuclear Valve Studs (below 800°F)

Nuclear valve studs operating below 800°F are not in the material creep range and do not suffer plastic strain and loss of rupture ductility in service. Therefore, there are no replacement recommendations related to number of tightenings. Inspection and replacement, if cracks are found, should be as discussed under "INSPECTION RECOMMENDATIONS".

Att. #1
Calc. OSC-3369
Pg. 11 of 21

INSPECTION RECOMMENDATIONS

The previous recommendation has been to inspect studs for cracks at least every 6 years, regardless of material or application. The new recommendation relates inspection frequency to number of tightenings, as well as to years in service, for fossil valve studs of B5F5B and B50A125E material.

Any studs that are found cracked must be replaced immediately. It is desirable to also replace all the other studs of the same age in that valve if new studs are available. If less than 30% of the studs in a valve are cracked, however, it is generally satisfactory to replace only the cracked studs, provided that the other studs of the same age are replaced within one year. If more than 30% of the studs are cracked, all studs of that age in that valve and mating valves should be replaced immediately.

At a minimum, the number of spare studs recommended in the parts catalog should be kept on hand. This may vary from 10% to 50%, depending on the type of valve. If the studs are B5F5B or B50A125E, and in fossil service before 1966, the spares on hand should be increased to 100% in preparation for complete replacement.

A. Fossil Valve Studs (800°F and higher)

B5F5B Stud Material:

It is recommended that B5F5B studs for valve upper heads and stands be tested for cracks at least after every 3 tightenings or every 6 years, whichever comes first. The studs should be replaced at the next valve inspection following 11 tightenings (for studs in service after January 1, 1966). This is shown in tabular form below:

Stud Insp. No.	1	2	3	4
Tightening No.	3	6	9	*
(or) Years Service	6	12	18	24

* Replace after 11 tightenings.

As was discussed under "REPLACEMENT RECOMMENDATIONS" the stud replacement recommendation in the above table is based only on number of tightenings, not on years in service. The years in service are shown in the above table only to help establish the minimum inspection frequency.

Att. #1
Calc. OSC-3369
Pg. 12 of 21

INSPECTION RECOMMENDATIONS - (Cont'd.)

B50A125E Stud Material:

It is recommended that B50A125E studs for valve upper heads and stands be tested for cracks at least after every 3 tightenings up to 18 and after every 2 tightenings thereafter, or every 6 years, whichever comes first. This is shown in tabular form below. If the number of tightenings reaches 25, the studs should be replaced at the next valve inspection (studs in service after January 1, 1966):

Stud Insp. No.	1	2	3	4	5	6	7	8	9	-
Tightening No.	3	6	9	12	15	18	20	22	24	*
(or) Years Service	6	12	18	24	30	36	42	48	54	-

* Replace after 25 tightenings.

Austenitic Stud Material:

It is recommended that austenitic studs for valve upper heads and stands be tested for cracks at least every 6 years.

B. Nuclear Valve Studs (below 800°F)

It is recommended that studs for nuclear valve upper heads and stands be tested for cracks at least every 6 years.

Because they are operating below the material creep range, any cracks found in nuclear valve studs should be reported to the G.E. Service Engineer immediately for assistance in diagnosing the cause.

INSPECTION PROCEDURE

Magnetic particle testing of magnetic materials and red dye testing of non-magnetic materials are satisfactory methods of checking for cracks, but both methods require removal of the studs from the casing. An ultrasonic test procedure has been developed which has proven to be a dependable method of locating cracks. The ultrasonic test method is recommended because it does not require removal of the studs. In some instances the grain size in austenitic materials may prevent ultrasonic inspection, but this must be determined by trial.

To assist in the inspection of valve studs we have prepared the attached detailed test procedure TG-19A entitled "Ultrasonic Testing Of Steam Valve Studs After Periods Of Service", and report form TG-19AU entitled "Ultrasonic Examination Of Valve Studs".

STUD REMOVAL

When a stud is removed from a casing, care should be taken to avoid damage to the casing threads. A generous application of penetrating oil will often help. Other techniques which have been used with some success include cooling the stud with nitrogen and/or heating

Att. #1
Calc. 056-3369
Pg. 13 of 21

STUD REMOVAL - (Cont'd.)

the casing locally to about 300°F. It should be expected that some percent of the studs to be removed will not yield to the above techniques, and equipment should be available to drill out these studs.

SUMMARY OF RECOMMENDATIONS

Fossil Units (800°F and Higher):

1. Tighten B5F5B and B50A125E valve studs per 223A3906. Drawing 223A3906 takes precedence over instructions on valve assembly drawings issued before the "1970 Level" was implemented.
2. Tighten austenitic valve studs per the original valve assembly drawing.
3. Replace all B5F5B valve studs in service before 1966 by the end of 1981.
4. Replace all B50A125E valve studs in service before 1966 by the end of 1983.
5. Inspect all B5F5B studs for cracks at least every 3 tightenings or 6 years, whichever comes first. Replace after 11 tightenings (for studs in service after January 1, 1966).
6. Inspect all B50A125E studs for cracks at least after 3 tightenings up to 18 and every 2 tightenings thereafter, or every 6 years, whichever comes first. If the number of tightenings reaches 25, the studs should be replaced at the next valve inspection (for studs in service after January 1, 1966).
7. Inspect all austenitic studs for cracks at least every 6 years.

Nuclear Units:

1. Tighten studs per the valve assembly drawing or drawing 223A (they should be in agreement).
2. Inspect studs for cracks at least every 6 years.

THE INFORMATION FURNISHED IN THIS TECHNICAL INFORMATION LETTER IS OFFERED BY GENERAL ELECTRIC AS A SERVICE TO YOUR ORGANIZATION. IN VIEW OF THIS AND SINCE OPERATION OF YOUR PLANT INVOLVES MANY FACTORS NOT WITHIN OUR KNOWLEDGE, AND SINCE OPERATION IS WITHIN YOUR CONTROL AND RESPONSIBILITY, IT SHOULD BE UNDERSTOOD THAT GENERAL ELECTRIC ACCEPTS NO LIABILITY IN NEGLIGENCE OR OTHERWISE AS A RESULT OF YOUR APPLICATION OF THIS INFORMATION.

TABLE I
VALVE STUD MATERIALS

Att. #1
 Calc. OSC-3369
 Pg. 14 of 21

G.E. Material Spec.		Identification Stamping	
		NEW	OLD *
B5F4C	Ferritic	N	F4
B5F5B	Ferritic	L	F5
B50A125B	Ferritic	P	--
B50A125C	Ferritic	W	--
B50A125E	Ferritic	XD	F25
B50A146A	Austenitic	S	A6A
B50A199B	Austenitic	XA	--
B50A199D	Austenitic	XB	--

* In use from about 1960 to 1967.

GENERAL ELECTRIC

223A3906

CONT ON SHEET - SHEET NO. 1

TITLE

ELONGATION FOR PRESTRESSING VALVE UPPER HEAD AND STAND STUDS - 1970 LEVE

FIRST MADE FOR

223A3906

CONT ON SHEET - SHEET NO. 1

Calc. OSC-3369
P. 1-15 of 21

ELONGATION (MILS)


0 2 4 6 8 10 12 14 16 18 20 22 24 26 28 30 32

NOTE:
WHERE DIFFERENCES EXIST, THIS DWG.
TAKES PRECEDENCE OVER INSTRUCTIONS
ON VALVE ASSEMBLY DRAWINGS ISSUED
BEFORE THE 1970 STRESS LEVEL
WAS IMPLEMENTED.

ELONGATION RANGE FOR B5F58 & B5F4C
STUD MATERIALS (STAMPED L OR F5) (N OR F4)
AT STEAM TEMP. BELOW 800° F.

ELONGATION RANGE FOR B5F58
STUD MATERIAL (STAMPED L OR F5)
AT STEAM TEMP. OF 800° F THRU 1050° F.

ELONGATION RANGE FOR B50A125E STUD
MATERIAL (STAMPED X0 OR F25) USED AT
STEAM TEMP OF 900° F THRU 1050° F.



EFFECTIVE STUD LENGTH (INCHES)

APPROVALS
3 R. Muir - F.P. No. F4
Muir 2.1.79
273-
PRINTS

223A3906
TURBINE DIV OR DEPT.
SCHEENECTADY LOCATION
APPROVALS
Issued March 24, 1970
Th 226.1779 P/M

Att. #1
Calc. OSC-3369
(TIL 891 ATTA)
Pg. 16 of 21

ULTRASONIC TESTING OF STEAM VALVE STUDS AFTER PERIODS OF SERVICE

1. Introduction

These instructions outline the procedure to be followed when performing ultrasonic longitudinal wave tests on valve studs, in place, after periods of service.

2. General

Tests shall be performed by well trained and properly qualified personnel.

Tests shall be performed while the studs are in place and generally after the cover has been removed. However, where the end of the stud protrudes above the nut, the studs may be tested without disassembly.

A Sperry Reflectoscope, Type UR or equivalent, shall be used. The ultrasonic instrument vertical presentation shall be linear within $\pm 5\%$ of the full scale deflection.

The exposed end of each stud shall be free of all scale and oxide. Caution should be exercised to maintain a flat surface for search unit contact.

A suitable couplant such as SAE 20 oil shall be used.

The distance calibration markers shall be adjusted on a calibration bar of material similar to that of the studs, for accurate distance measurements.

3. Method of Test

Tests shall be performed using a 5.0 Mc 1/2 or 1 inch diameter type ZR search unit. Experience has shown that these search units give the best results. However, due to variations in type of material and geometry it may be necessary to use other frequencies and diameter search units.

The sweep length shall be adjusted until the 1st back reflection of the stud is visible on the right hand side of the oscilloscope screen as shown in Figure 1.

The distance from the top of the stud to the valve joint surface shall be measured and recorded.

The oscilloscope screen shall be marked at the measured distance determined in the previous paragraph. The results obtained to date indicate that crack indications will appear at the 1st or 2nd thread, 0 - 1/4 inch below the valve joint surface as shown in Figures 1 and 2.

The sensitivity shall be adjusted until the amplitude of the indications from the valve end threads is 5% of 1 1/2 inches sweep to peak.

The studs shall be tested completely from the exposed end by scanning 360 degrees in a see-saw manner as shown in Figure 3.

Each stud shall be assigned a number indexed with respect to the dowel pin as shown in Figure 4.

The scanning procedure shall be repeated on all studs.

Att. #1
Calc. OSC-3369
Pg. 17 of 21

All indications shall be marked on the test surface as they occur. The circumferential distribution of indications shall be indicated with respect to a clock system. The 12 o'clock position on each stud is toward the OD of the valve and in radial line with the center of the valve bore.

RECORD OF TEST RESULTS:

The ultrasonic test report shall contain all pertinent information regarding the test as outlined in this instruction. A sample test report is shown in Figure 5.

ACCEPTANCE AND REJECTION

Copies of the ultrasonic test report should be made available to General Electric Company personnel at the earliest possible time following completion of the tests in order that acceptance or rejection can be made of the studs that were tested.







Figure 2

Att. #1
Calc. OSC-3369
Pg. 18 of 21



SCANNING IN A SEESAW MANNER-360°

Figure 3



STUD NUMBERING SYSTEM

Figure 4

In addition to customers' requirements for copies of the test reports, two copies should be forwarded to:

STGMD, Product Service - Mgr. Maintenance Su
Bldg. 269 - Rm. 200, North Ave.
Schenectady, NY (12345)

RETURNING STUDS FOR LABORATORY EXAMINATION

LST-G Product Service should be contacted for instructions before returning cracked studs to the factory for metallurgical examination. There is not a sufficient number of Laboratory Technicians to perform routine testing of cracked studs and arrangements to make such tests, if desired by the purchaser, should be made with local testing organizations.

ULTRASONIC EXAMINATION OF VALVE STUDS


Att. #1
Calc 056-3369
Pg. 19 of 21

Owner Niagara Mohawk Corp.
Location Albany
Machine No. 00000 Unit No. 100

Valve Type Stop
Stud Length 26 1/2" Diam. 1/2"
Frequency 2.0 mc. Size 3" Type ZR
Tested By A. B. Fish
Company General Electric Co.
Address Schenectady, N.Y.
Date of Test Nov. 30, 1966

Stud No.	Mag. %	Circum. Distr. (Time)	Dist. Top
1	25	9:00 - 12:00	19"
2	OK		
3	OK		
4	100	9:00 - 3:00	19"
5	OK		
6	OK		
7	OK		
8	20	12:00 - 3:00	19"
9	OK		
10	OK		
11	OK		
12	OK		
13	OK		
14	OK		
15	OK		
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			
32			
33			
34			
35			
36			
37			
38			
39			
40			

SAMPLE



Stud bolt hour service 61,000
Times studs were tightened 5
Number of cold starts 25
Number of studs questioned sonically 3
Number of studs replaced 15
GE-I&SE Representative D. Hutchinson

Additional Information

Indications in the studs were verified using a 2.25 mc. 1/2" diam. ZR search unit.

Att. No. 1
Calc. OSC-3369

Pg. 21 of 21

TELEPHONE CONVERSATION RECORD

DATE: 11-28-88

FILE NO: UT-88-8

FROM: A. C. Gladney

ROUTE

TO: Jack Packard of General Electric

CARL FREEMAN-ONS

TIM TUCKER

ROYCE WILLIAMS


SUBJECT: Main Steam Turbine Stop Valve Upper Head

Stud Examination For Oconee Nuclear Station


Jack was called to see if GE was going to support our efforts by providing a drawing of the upper head stud on the main steam turbine stop valve. GE will not send us a drawing of the stud, but they may approve the drawing I am having prepared by Design Engineering.

In the GE Recommendation TIL-891, it specifies that B5F5B stud material shall be the type of studs used in our valves. None of the numbers stamped on the studs correlate. I asked Jack if the numbers stamped on the studs were coded in anyway that needed information could be obtained if you knew the key. He said yes, and that Dave Smith of NPD should have this key.

Pursuing this a little further, the following was obtained:



ATTACHMENT # 2
CALC. OSC-3369



- NOTES:
- (1) STUDS WILL BE MARKED WITH A G.E. TURBINE NUMBER AS FOLLOWS : 170392 170393 170449
 - (2) DIMENSIONS ON THIS DWG. ARE AS MEASURED FROM A SPARE UNIT "I" STUD.
 - (3) THESE STUDS ARE A FERRITIC MATERIAL TO G.E. MATERIAL SPEC. B5F5B. STUDS WILL BE STAMPED WITH "L" FOR IDENTIFICATION OF THIS MATERIAL.
 - (4) PER TIL-891, ANY INDICATION FOUND TO DATE OCCURRED HERE IN THE FIRST 0-1/4".
 - (5) BASED ON LOAD DISTRIBUTION IN THREADED FASTENERS, THE STRESSES IN THIS AREA WOULD BE LOW ENOUGH THAT ANY INDICATION WHICH MIGHT EXIST SHOULD NOT PROPAGATE. (SEE O'CONNOR CALCULATION OSC-3369).
 - (6) THIS IS THE DISTANCE FROM THE FIRST THREAD TO THE SHOULDER ON THE I.D. AND ALSO EQUALS APPROX. ONE HALF THE THREAD DIAMETER.

SECTION A-A

Q A CONDITION 1
NUCLEAR SAFETY RELATED

IDENTIFICATION LEGEND

TYPE OF BOLT → BOLT LENGTH (14.125") → MATERIAL SPEC. CODE

606 - 217 - 1412 - L - 170392

MATERIAL PROPERTIES CODE → G.E. TURBINE NUMBER

- REFERENCES:
1. G.E. TECHNICAL INFORMATION LETTER (TIL-891) TRANSMITTED TO DUKE POWER BY LETTER OF 12-20-79.
 2. G.E. TURBINE GENERATOR MANUAL OM-200-195.

DUKE POWER COMPANY O'CONNOR UNITS 1, 2 & 3										
MAIN STEAM TURBINE STOP VALVE UPPER HEAD STUD										
ORG. RELEASED FOR USE WITH CALC. OSC-3369										
NO.	REVISIONS	DRW	DATE	CHKD	DATE	APPR	DATE	CIVIL	ELC	MECH
SKETCH OSC-3369										

DUKE POWER COMPANY

Request For Relief From
Inservice Inspection Requirement

Station: Oconee

Unit: 1

Reference Code: 1980 ASME Section XI, including addenda through Winter
1980

1. Component for which exemption is requested:

a. Name and Identification Number:

Integrally welded Piping Attachments for Support No.
03-0-480A-H9B on the Feedwater system (Duke System No. 03),
ISI Item No. C03.040.038

b. Function:

To support the weight of and provide structural stability to
the Feedwater Piping System

c. ISI Class/Duke Class: ISI Class II/Duke Class F

d. Valve Category: N/A

II. Reference Code Requirement that has been determined to be impractical:

ASME Boiler and Pressure Vessel Code Section XI, 1980 Edition,
including 1980 Winter Addenda, Surface Examination (PT/MT)
specified in table IWC-2500-1, Category C-C, Item No. C3.40

III. Basis for Requesting Relief:

The integral attachments are inaccessible for a Surface Examination because of their physical location inside a wall penetration. The integral attachments are welded to a 24" Feedwater pipe that runs through a 36" pipe sleeve penetrating the wall at an approximate 45° angle. Due to the angle, the integral attachments are inside the sleeve at a depth of approximately 12" from the near side and 36" from far side with a maximum clearance of 5" as shown on attached piping support detail No. 03-0-480A-H9B (pages 1-3).

IV. Alternate Examination:

A Visual Examination will be performed on the integrally welded attachments for Support No. 03-0-480A-H9B (ISI Item No. C03.040.038) meeting the requirements of 1980 ASME Section XI, IWA-2211, VT-1 Visual Examination. This inspection will provide assurance of the structural integrity of this support.

V. Implementation Schedule:


This examination will be performed in the month of May, 1990, during the current (12th) refueling outage.

SHIM IF REQUIRED PER SECTION 7.70 OF 03-0021-00-00-0002 EXCEPT SHIMS ARE TO EXTEND AS A MINIMUM TO FULL ARC LENGTH OF THE SADDLE AND HAVE A MINIMUM WIDTH OF 3". SHIM MAY EXTEND 4" PAST EDGE OF SLEEVE TO ALLOW WELDING OUTSIDE OF SLEEVE. SHIM THICKNESS SHALL BE SELECTED BASED ON THE MINIMUM GAP SIZE OVER THE SHIM AREA.




Note: This Plate On All Four Saddles To Have No Less Than 220 Sply. For Civil Bearing

CL. (F.Y. BOTH ENDS - 4 PLACES) [WHERE ACCESSIBLE] SECTION 'A-A'



PLAN

* LOADS WITH FRESHWATER HEADER SUPPORTS



LOCATION PLAN

QTY	MATERIALS AND OPERATIONS	UNIT
001	FT. GUIDE CONSISTING OF:	
4	Saddle/sk. See Detail 'A' TV-2368	1
1	Plate & Tag	
	NO: 03-0-480A-498	
	COMP. OF THIS DRAWING IS SUBJECT TO ABOVE MAT'L.	

FOR INFORMATION ONLY

SIZ. CALL. NO. DSC-1297-07

	X	Y	Z
358	.000	.000	-.814
	.000	.000	.639

PROJECT NO. 1-03-03 SYSTEM NO. 03
 ISSUE 0
 DATA PT. 370 NUCLEAR CLASS

FOR INSERVICE INSPECTION USE ONLY

NOTE: THIS DRAWING SUPERSEDES BECHTEL SKETCH 04908-17 REV. 1 D, DATED 7-17-70

QA CONDITION 1



SYSTEM DATA		LOADS		STRESS		DUKE POWER CO.	
DESIGN PRESSURE	1050 PSIG	T (THERMAL LOAD)	-7672	15512-002		SCORCE NUCLEAR POWER STATION - UNITS 1, 2, & 3	
DESIGN TEMPERATURE	600° F	D (DEAD LOAD)	-1039			PIPING SUPPORT DETAIL	
OPERATING TEMPERATURE	410° F	DE (DR)	16241			J3-0-480A-498	
PIPE	25" Sch. 80, 106-G.B	MNE (SSE)	37682			DRN. HLU	4/15/81
ORIENTATION	3'	DE + T + D	+15368/25118			INSP. HLU	5/1/81
		MNE + T + D	+31709/-41459			CHKD. D3P	4-24-81
						APPR. OJA	5/1/81
						SCALE: NONE	SHT. 1 OF 9
							REV. DI

Request For Relief Ser. No. ONS-013
 Attachment (pages 1-3)

GRINNELL

CUSTOMER DUKE POWER CO.
 ORDER OR CONT. NO. 57-HDW-1678
 NAME OCONEE NUC. STA. UNIT # 1

note This drawing supersedes Grinnell Sketch
 No. O-490B-17A Rev. 0 Dated 6/19/70



SECTION A-A
FOUR (4) REQ'D.


EM No.	MATERIALS AND OPERATIONS	QUAN.	SHIP.
	Plate assembly as detailed above, TW-236 #	4	

ITEM NO	NO REQ'D	PART NO	SIZE	DESCRIPTION	MATERIAL


"Y" RIGID

SUPPORT DATA	
T (THERMAL LOAD)	21699
D (DEAD LOAD)	-6874
DE (OBE)	** 11949
MHE (SSE)	** 23897
DE+T+D	+27148/-19197
MHE+T+D	+39096/-3145

MOVES. "	X	Y	Z
THERMAL	.000	.000	-.814
SSE	.000	.000	.639
SELSUBC			



PROBLEM NO. 1-03-05 SYSTEM NO. 03
 ISSUE 0
 DATA FT. 370 NUCLEAR CLASS



* LOADS WITH FEEDWATER HEADER SUPPORTS
 ** LOADS WITHOUT FEEDWATER HEADER SUPPORTS

Δ										
WA	-	SEE SHT. 1 OF 3				-	-	-	-	-
▲	11-5-80	REVISED PER IEB 79-14						N/A	N/A	N/A
REV. DATE	REVISIONS				BY	CHK	DESIGN SUPER	ENG'N	PROJ. ENG'N	APPR

DUKE POWER CO.
 Oconee Nuclear Station

Iso. Drawing No.	Item No.	Unit No.
0-4908-3	2	1

PIPE SUPPORTS
MAIN FEEDWATER SYS.
WEST GENERATOR

GAIHERSBURG

STRESS ISO 0-490B-3(5)
 REF. DWGS. COMPOSITE
 CIVIL

JOB. NO.	HANGER NO.	REV.
13312-002	03-0-480A-H9B	DI
	SHEET 3 OF 3	

11.0 Class 1 and 2 Repairs and Replacements

As required by ASME Section XI 1980 Edition, a record of the Class 1 and 2 Repairs and Replacements for work performed from February 14, 1989 through June 4, 1990 is provided and is included in this section of the report. The individual work request documents are on file at the Oconee Nuclear Station.

REPAIRS/REPLACEMENT LOG

ASME SECTION XI - 1980

OCONEE NUCLEAR STATION

Interval covered: From: 02-14-89 To: 06-04-90

NOTE: (1) Unit #1 Refueling outage #12 Start-up
Leak Test *Indeterminate from Work
Request Review

Prepared By: QA Technical Support Date: 6-04-90

Reviewed By: T. J. Coleman Date: 6-25-90

Transmitted to
ISI Supervisor By: T. J. Coleman Date: 6-25-90

TJC/jah

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
57981A	1	A	PREPPED AND INSPECTED 1-51A-11-87 & 88
57095E	1	B	PT VALVE 1M5-84 AND MT INSPECTED
57074D	1	B	PT INSPECTED 1M5-102
57071D	1	B	PT INSPECTED VALVE 1M5-105
57072D	1	B	PT AND MT INSPECTED VALVE 1M5-104
17810C	1	B	VT INSPECTED VALVE 1M5-24
57073D	1	B	PT AND MT INSPECTED 1M5-103
52942H	1	B	AUXILIARY FWD NOZZLE #5 HEADER FLANGE PT & RT INSPECTED WELD REPAIR
21382C	1	B	TACK WELD ON VALVE 1-5F-23
24141C	1	A	WELD REPAIR TO SEAL WELD ON UPPER HEATER BUNDLE OF PRESSURIZER
51801J	1	B	REPLACE 1C511 WITH 09J-341
51802J	1	B	REPLACED 1C512 WITH 9J-341
51793J	1	B	MADE SEAL WELD ON SEAT RING ON 1LPSW-321
51805J	1	B	REPLACED 150 418 WITH DMV-849
050205I	1	2	REPLACED BOLTING VALVE 1-85-16
0502375H	1	2	REPLACED BOLTING VALVE 1-85-14
57996A	1	1	REPLACED BOLTING OT5C B LPM
57995A	1	1	REPLACED BOLTING OT5C A UPPER PRIMARY MANWAY
17796C	1	2	REPLACED BOLTING LPI A COOLER
052945H	1	2	REPLACED GAMMA PLUG WELD # 1-01A-2-5BZ

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
62794C	1	2	REPLACED GAMMA PLUG WELD # 1-03-3-43BZ
57832C	1	1	REPLACED 1RC-68 AND 1/2 NUTS ON LEAK OFF FLANGE
57469D	1	1	REPLACED 1RC-66
15685C	1	2	REPLACED B/B BOLTING 1LP-22
57831C	1	1	REPLACED 1RC-67 AND LEAK OFF FLANGE NUTS
57095E	1	2	REPLACED DISC IN 1MS-84
57071D	1	2	REPLACED PRESSURE SEAL HEAT BOLTING 1MS-105
57072D	1	2	REPLACED PRESSURE SEAL HEAD BOLTING 1MS-104
17810C	1	2	REPLACED B/B BOLTING 1MS-24
052544H	1	1	REPLACED BOLTING CRDM FLANGE #38
57011E	1	2	REPLACED BOLTING RBCU B
052940H	1	1	REPLACED BOLTING LPH "B" OTSG
15653H	1	1	REPLACED BOLTING IRV FLANGE "A1" RCP
19876C	1	2	REPLACED "1C" HPI PUMP
57005E	1	2	REPLACED BOLTING RBCU 'A'
052942	1	2	REPLACED BOLTING AUXILIARY FWD NOZZLE #5
052949H	1	2	REPLACED BOLTING "B" OTSG L 5 MANWAY
11699C	1	2	REPLACED B/B BOLTING 1MS-135
24141C	1	1	REPLACED BOLTING ON UPPER HTR BUNDLE PZR

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
51035I	1	2	REPLACED B/B BOLTING 1HP-188
51799J	1	2	REPLACED B/B BOLTING 1-FW-64
51676J	1	1	REMOVED, STABILIZED, PLUGGED TUBES 1A DT5G B & W FCA 04-4596
51677J	1	1	REMOVED, STABILIZED, PLUGGED TUBES 1B075G B & W FCA 04-4597
54114I	1	2	REPLACED DISC 1M5-2
57977A	1	2	REPLACED BWST MANWAY BOLTING
98615C	1		REMOVED HANGER 1-08-400A-H4044
98615C	1		REMOVED HANGER 1-08-401A-H4045
98615C	1		REMOVED HANGER 1-08-1-0-401A-H6
98615C	1		REMOVED HANGER 1-08-1-0-401A-H7
98615C	1		REMOVED HANGER 1-08-1-0-400A-H5
98615C	1		REMOVED HANGER 1-08-400A-DE001
98445C	1		REMOVED HANGER 1-67-4408-H5319
98808C	1		INSTALL NEW HANGER 1-64-479D-H6415
98808C	1		MODIFIED HANGER 1-64-479D-H6347
98808C	1		INSTALLED NEW HANGER 1-64-479D-H6417
98808C	1		INSTALLED NEW HANGER 1-64-479D-H6416
51717J	1		INSTALLED NEW HANGER 1-51A-479A-H6418

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
51718J	1		INSTALLED NEW HANGER 1-51A-479A-H6419
51808J	1		INSTALLED NEW HANGER 1-61-429A-H5624
51809J	1		INSTALLED NEW HANGER 1-61-439A-H5625
95338B	1		MODIFIED HANGER 1-GH-R5-7273-01
95338B	1		MODIFIED HANGER 1-GH-R5-7172-01
95338B	1		MODIFIED HANGER 1-GH-R5-7172-02
95338B	1		MODIFIED HANGER 1-GH-QR-6970-02
95338B	1		MODIFIED HANGER 1-GH-ST-7172-02
95338B	1		MODIFIED HANGER 1-GH-R5-7071-04
95338B	1		MODIFIED HANGER 1-GH-RBU-7071-04
95338B	1		REMOVED HANGER 1-GH-UV-7071-07
95338B	1		MODIFIED HANGER 1-04A-2-0-439B-R3
98794C	1		REMOVED HANGER 1-01A-0-550-R1
97357C	1		MODIFIED HANGER 1-54A-3-0-435B-R5
98460C	1		MODIFIED HANGER 1-51A-0-479A-EKK-H1701
98460C	1		MODIFIED HANGER 0-1-55-479F-H6419
98460C	1		MODIFIED HANGER 1-50-0-66A-RCPM-510

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFD-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
984600	1		MODIFIED HANGER 1-51A-0-479A-H6167
984600	1		MODIFIED HANGER 1-50-0-66A-RCPM-512
984600	1		MODIFIED HANGER 1-50-0-66A-RCPM-511
987030	1		MODIFIED HANGER 1-07A-400B-SR20
986150	1		REMOVED HANGER 1-08-401A-H4047
986150	1		REMOVED HANGER 1-08-401A-H4046
953388	1		MODIFIED HANGER 1-GH-HJ-2223-01
953388	1		MODIFIED HANGER 1-GH-HJ-2223-02
953388	1		MODIFIED HANGER 1-GH-HJ-2324-03
953388	1		MODIFIED HANGER 1-GH-RBU-7071-01
953388	1		INSTALLED HANGER 1-GH-RS-7071-02
953388	1		MODIFIED HANGER 1-GH-ST-7273-03
953388	1		INSTALLED HANGER 1-GH-UV-7071-02
953388	1		INSTALLED HANGER 1-GH-ST-7071-01
953388	1		INSTALLED HANGER 1-GH-VW-7071-02
953388	1		MODIFIED HANGER 1-GH-VW-7071-03
953388	1		MODIFIED HANGER 1-GH-VW-7071-06

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFD-12
ASME SECTION XI - 1980
DODDNER NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
953388	1		INSTALLED HANGER 1-GH-WX-6970-01
953388	1		MODIFIED HANGER 1-GH-TRB-7071-02
953388	1		MODIFIED HANGER 1-GH-R5-7071-03
953388	1		MODIFIED HANGER 1-GH-ST-7172-01
953388	1		MODIFIED HANGER 1-GH-UV-7071-04
953388	1		REMOVED HANGER 1-GH-QR-7071-04
953388	1		MODIFIED HANGER 1-GH-R5-6970-01
953388	1		MODIFIED HANGER 1-GH-QR-6667-02
953388	1		MODIFIED HANGER 1-GH-QR-7071-01
953388	1		INSTALLED HANGER 1-GH-LM-2324-02
953388	1		INSTALLED HANGER 1-GH-WX-7071-06
953388	1		MODIFIED HANGER 1-GH-VW-7071-01
953388	1		MODIFIED HANGER 1-GH-WX-7071-03
953388	1		MODIFIED HANGER 1-GH-VW-7071-07
953388	1		INSTALLED HANGER 1-GH-UV-7071-01
953388	1		MODIFIED HANGER 1-GH-RBU-7071-03
953388	1		MODIFIED HANGER 1-GH-ST-7273-04

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFD-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
953388	1		INSTALLED HANGER 1-GH-QR-6970-01
953388	1		INSTALLED HANGER 1-GH-QR-6970-03
953388	1		MODIFIED HANGER 1-GH-RBU-7071-02
953388	1		MODIFIED HANGER 1-GH-VW-7071-04
953388	1		MODIFIED HANGER 1-GH-PQ-6667-02
953388	1		MODIFIED HANGER 1-GH-R5-7071-06
953388	1		REMOVED U-BOLT ON HANGER 1-GH-ST-7071-05
953388	1		MODIFIED HANGER 1-GH-CD-1718-01
953388	1		ADDED MISSING CLEVIS TO HANGER 1-GH-CD-2223-02
953388	1		MODIFIED HANGER 1-GH-FG-2324-01
953388	1		MODIFIED HANGER 1-GH-F6-2324-02
953388	1		MODIFIED HANGER 1-GH-GH-2324-01
951208	1		REMOVED HANGER 1-538-2-0-439B-H54
951208	1		MODIFIED HANGER 1-538-5-0-435B-R25
951208	1		REMOVED HANGER 1-538-5-0-439C-H32
951208	1		REMOVED HANGER 1-54A-0-435B-H14

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCOONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951208	1		REMOVED HANGER 1-54A-1-0-435B-H11
951208	1		MODIFIED HANGER 1-53B-4-0-435B-H13
951208	1		INSTALLED HANGER 1-53B-435B-DE079
951208	1		MODIFIED HANGER 1-53B-4-0-444-H64
951208	1		INSTALLED HANGER 1-53B-0-435B-DE059
951208	1		MODIFIED HANGER 1-53B-0-436D-DE060
951208	1		INSTALLED HANGER 1-53B-0-435B-DE058
951208	1		INSTALLED HANGER 1-53B-5-0-439C-R21
951208	1		MODIFIED HANGER 1-53B-435B-DE023
953388	1		MODIFIED HANGER 1-GH-ST-7172-05
953388	1		MODIFIED HANGER 1-GH-WX-7071-02
953388	1		MODIFIED HANGER 1-GH-ST-7071-02
953388	1		MODIFIED HANGER 1-GH-BC-2122-01
953388	1		MODIFIED HANGER 1-GH-KL-2223-01
953388	1		MODIFIED HANGER 1-GH-KL-2324-01
953388	1		INSTALLED HANGER 1-GH-LM-2324-01

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFU-12
ASME SECTION XI - 1980
UCONNEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951208	1		MODIFIED HANGER 1-538-438C-H5586
951208	1		INSTALLED HANGER 1-538-438C-H5587
951208	1		INSTALLED HANGER 1-538-439C-H5603
951208	1		MODIFIED HANGER 1-538-5-0-438A-H55
951208	1		MODIFIED HANGER 1-538-5-0-439B-H57
951208	1		MODIFIED HANGER 1-538-5-0-439B-R31
951208	1		MODIFIED HANGER 1-538-5-0-436F-R34
951208	1		INSTALLED HANGER 1-538-439B-RTB-2601
951208	1		INSTALLED HANGER 1-538-439B-RTB-2602
951208	1		REMOVED HANGER 1-538-0-439A-H58
951208	1		MODIFIED HANGER 1-538-5-0-439C-H38
951208	1		MODIFIED HANGER 1-538-5-0-439C-H39
951208	1		MODIFIED HANGER 1-538-5-0-439C-H40
951208	1		MODIFIED HANGER 1-538-5-0-439C-H42
951208	1		MODIFIED HANGER 1-538-5-0-439C-H43
951208	1		MODIFIED HANGER 1-538-5-0-439C-H44

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951208	1		MODIFIED HANGER 1-538-5-0-439C-H45
951208	1		MODIFIED HANGER 1-538-5-0-439C-H46
951208	1		REMOVED HANGER 1-538-2-0-439B-H52
951208	1		MODIFIED HANGER 1-538-439C-DE097
951208	1		INSTALLED HANGER 1-538-0-435B-DE056
951208	1		MODIFIED HANGER 1-538-5-0-436-H8
951208	1		MODIFIED HANGER 1-538-5-0-436D-H17
951208	1		MODIFIED HANGER 1-538-3-0-444-H65
951208	1		MODIFIED HANGER 1-538-5-0-436D-R22
951208	1		MODIFIED HANGER 1-538-5-0-444-DE099
951208	1		MODIFIED HANGER 1-538-5-0-435B-R24
951208	1		REMOVED HANGER 1-538-435B-DE038
951208	1		INSTALLED HANGER 1-538-0-438B-DE050
951208	1		INSTALLED HANGER 1-538-0-437B-DE051
951208	1		INSTALLED HANGER 1-538-0-437B-DE052
951208	1		INSTALLED HANGER 1-538-0-438C-DE055

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
DUNEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951208	1		MODIFIED HANGER 1-538-3-0-437B-H25
951208	1		INSTALLED HANGER 1-538-3-0-438C-H26
951208	1		MODIFIED HANGER 1-538-0-437B-ARM-0279
951208	1		REMOVED HANGER 1-538-0-438C-DE011
951208	1		REMOVED HANGER 1-538-3-0-439C-H27
951208	1		REMOVED HANGER 1-538-0-438C-DE014
951208	1		REMOVED HANGER 1-538-3-0-439C-H28
951208	1		REMOVED HANGER 1-538-0-438C-DE004
951208	1		INSTALLED HANGER 1-538-5-0-435-R7
951208	1		INSTALLED HANGER 1-538-5-0-435-R8
951208	1		ADDED SHIMS TO HANGER 1-538-5-0-444-R10
951208	1		ADDED SHIMS TO HANGER 1-538-5-0-444-R11
951208	1		MODIFIED HANGER 1-538-3-0-444-R3
951208	1		INSTALLED HANGER 1-538-5-0-444-R12
951208	1		INSTALLED HANGER 1-538-5-0-439-R14
951208	1		INSTALLED HANGER 1-538-5-0-439C-R15

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFD-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951208	1		MODIFIED HANGER 1-538-5-0-436D-R16
951208	1		MODIFIED HANGER 1-538-0-435B-R26
951208	1		INSTALLED HANGER 1-538-0-436D-DJB-R2401
951208	1		INSTALLED HANGER 1-538-438C-TLN-0701
951208	1		INSTALLED HANGER 1-538-438C-TLN-0702
951208	1		INSTALLED HANGER 1-11-0-438C-DE004
951208	1		REMOVED HANGER 1-538-438C-DE098
951208	1		REMOVED HANGER 1-538-439C-RPP-2901
951208	1		REMOVED HANGER 1-538-5-0-436D-R32
951208	1		REMOVED HANGER 1-538-438C-DE002
951208	1		REMOVED HANGER 1-538-5-0-444-R23
951208	1		INSTALLED HANGER 1-538-435B-DE044
951208	1		INSTALLED HANGER 1-538-438C-DE005
951208	1		INSTALLED HANGER 1-538-438C-DE007
951208	1		INSTALLED HANGER 1-538-435B-DE025
951208	1		INSTALLED HANGER 1-538-0-438C-DE057

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951208	1		MODIFY HANGER 1-538-5-0-435B-H1
951208	1		ADJUSTED CLAMP STEERING HANGER 1-538-5-0-444-H2
951208	1		MODIFIED HANGER 1-538-5-0-444-H6
951208	1		MODIFIED HANGER 1-538-5-0-436D-H13
951208	1		INSTALLED HANGER 1-538-6-0-439C-H13
951208	1		INSTALLED HANGER 1-538-6-0-439C-H14
951208	1		MODIFIED HANGER 1-538-5-0-436D-H16
951208	1		MODIFIED HANGER 1-538-5-0-436D-H19
951208	1		MODIFIED HANGER 1-538-5-0-436D-H23
951208	1		REPLACED SPRING CAN HANGER 1-538-0-436D-EMD-H30
951208	1		MODIFIED HANGER 1-538-5-0-439C-H33
951208	1		INSTALLED HANGER 1-538-5-0-439B-H50
951208	1		INSTALLED HANGER 1-538-0-439A-H59
951208	1		INSTALLED HANGER 1-538-5-0-435B-H67
951208	1		INSTALLED HANGER 1-538-5-0-436B-R5
951208	1		MODIFIED HANGER 1-538-5-0-435-R6

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCOONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951208	1		INSTALLED HANGER 1-538-4-0-435B-H28
951208	1		MODIFIED HANGER 1-538-4-0-435B-H29
951208	1		MODIFIED HANGER 1-538-4-0-435B-H30
951208	1		MODIFIED HANGER 1-54A-1-0-435B-H34
951208	1		MODIFIED HANGER 1-54A-1-0-435B-H35
951208	1		INSTALLED HANGER 1-54A-1-0-435B-H36
951208	1		INSTALLED SHIM 1-538-2-0-435B-H38
951208	1		MODIFIED HANGER 1-538-4-0-444-H62
951208	1		MODIFIED HANGER 1-538-4-0-436-H63
951208	1		MODIFIED HANGER 1-538-4-0-444-R1
951208	1		MODIFIED HANGER 1-538-3-0-444-R4
951208	1		MODIFIED HANGER 1-538-0-435B-R35
951208	1		INSTALLED HANGER 1-53-438C-TWE-2879
951208	1		REMOVED HANGER 1-538-438C-DE077
951208	1		REMOVED HANGER 1-51A-438C-CWO-2801
951208	1		REMOVED HANGER 1-538-438C-TWE-2769

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFD-12
ASME SECTION XI - 1980
OCOONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
95120B	1		REMOVED HANGER 1-53B-438C-DE076
95120B	1		REMOVED HANGER 1-53B-438C-TWE-2779
95120B	1		REMOVED HANGER 1-53B-3-0-436-R2
95120B	1		REMOVED HANGER 1-53B-0-435B-DE080
96224B	1		MODIFIED HANGER 1-51A-439A-RD-2500
98556C	1		MODIFIED HANGER 1-56-0-443-5R25
25770C	1		REPAIRED SNUBBER HANGER 1-54A-0-439A-R16
95120B	1		INSTALLED HANGER 1-53B-438C-DE070
95120B	1		INSTALLED HANGER 1-53B-5-0-436D-H9
95120B	1		INSTALLED HANGER 1-54A-435B-DE09
95120B	1		INSTALLED HANGER 1-53B-435B-DE024
95120B	1		INSTALLED HANGER 1-53B-0-435B-DE061
95120B	1		INSTALLED HANGER 1-53B-0-435B-DE062
95120B	1		INSTALLED HANGER 1-53B-0-535B-DE063
95120B	1		INSTALLED HANGER 1-53B-0-435B-DE064
95120B	1		INSTALLED HANGER 1-53B-0-435B-DE065

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951208	1		INSTALLED HANGER 1-538-0-4358-DE066
951208	1		INSTALLED HANGER 1-538-0-4358-DE067
951208	1		INSTALLED HANGER 1-538-0-4358-DE068
951208	1		INSTALLED HANGER 1-538-0-4358-DE069
951208	1		MODIFIED HANGER 1-538-2-0-436E-H1
951208	1		MODIFIED HANGER 1-538-2-0-436E-H3
951208	1		INSTALLED HANGER 1-538-7-0-436E-H11
951208	1		MODIFIED HANGER 1-538-4-0-4358-H12
951098	1		MODIFIED HANGER 1-148-0-444-ASR11
951098	1		REMOVED HANGER 1-148-439A-RB-0702
951098	1		MODIFIED HANGER 1-148-437A-5R39
951098	1		REMOVED HANGER 1-148-439A-DE115
951098	1		MODIFIED HANGER 1-148-400B-DE076
951098	1		MODIFIED HANGER 1-148-0-436E-ASR16
951098	1		MODIFIED HANGER 1-148-439A-5R57
951098	1		MODIFIED HANGER 1-148-0-436L-ASR13

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFD-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
95107B	1		MODIFIED HANGER 1-14B-0-436L-ASR14
95107B	1		MODIFIED HANGER 1-14B-400I-LRM-0601
96224B	1		MODIFIED HANGER 1-51-0-439A-DE098
96224B	1		MODIFIED HANGER 1-51-0-439C-DE095
96224B	1		INSTALLED HANGER 1-53B-0-439C-DE053
96224B	1		INSTALLED HANGER 1-14B-0-1444-ASR19
96224B	1		MODIFIED HANGER 1-14B-0-439C-ASR9
96224B	1		MODIFIED HANGER 1-53B-438C-DE075
96224B	1		MODIFIED HANGER 1-14B-0-439A-ASR10
96224B	1		MODIFIED HANGER 1-07A-4008-TLM-2116
96224B	1		MODIFIED HANGER 1-14B-0-2436D-ASR-24
96224B	1		MODIFIED HANGER 1-14B-0-1436C-ASR21
95337B	1		MODIFIED HANGER 1-56-2-0-437B-H35
95337B	1		REPLACED HANGER 1-56-2-0-437B-H34
95337B	1		REPLACED HANGER 1-56-2-0-437B-H33
95337B	1		MODIFIED HANGER 1-51A-438C-DE094

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
95337B	1		MODIFIED HANGER 1-56-5-0-4378-H47
95109B	1		MODIFIED HANGER 1-14B-437A-5R61
95109B	1		MODIFIED HANGER 1-14B-436D-DE063
95109B	1		MODIFIED HANGER 1-14B-436L-WJB-1002
95109B	1		MODIFIED HANGER 1-14B-0-400G-RWC-1303
95109B	1		MODIFIED HANGER 1-14B-0-400G-RWC-1302
95109B	1		INSTALLED HANGER 1-14B-439B-RB-0501
95109B	1		ADDED LOCK NUT HANGER 1-14B-0-436E-MKP-0506
95109B	1		REMOVED HANGER 1-14B-0-436E-MKP-0504
95109B	1		REMOVED HANGER 1-14B-0-400I-LRM-0602
95109B	1		MODIFIED HANGER 1-14B-0-1436D-ASR-23
95109B	1		MODIFIED HANGER 1-14B-0-1436D-ASR-22
95109B	1		REMOVED HANGER 1-14B-0-444-ASR12
95109B	1		MODIFIED HANGER 1-14B-0-444-ASR7
95109B	1		MODIFIED HANGER 1-14B-0-436L-ASR15
95109B	1		MODIFIED HANGER 1-14B-437A-DE055

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
UCUNEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
97521	1		REPLACED HANGER 1-01A-0-401B-JWC-1701
97521	1		MODIFIED HANGER 1-01A-0-401B-JWC-1702
97521	1		INSTALLED HANGER 1-01A-0-401B-DE035
97521	1		REPLACED HANGER 1-01A-0-401B-DE034
97521	1		REPLACED HANGER 1-01A-0-401A-DE019
97521	1		READJUSTED SNUBBER SETTING 1-01A-2-1-0-401A-5R1
97521	1		MODIFIED HANGER 1-01A-0-550-R12
97521	1		INSTALLED HANGER 1-01A-0-401B-DE033
97521	1		MODIFIED HANGER 1-01A-0-401A-DE032
97521	1	I	INSTALLED HANGER 1-GH-BC-2223-02
95066B	1		INSTALLED HANGER 1-54A-3-0-439C-H7
053582I	1		READJUSTED HANGER 1-03A-1-0-400B-H165
54246H	1		DISCONNECTED/RECONNECTED U-BOLT HANGER 1-15-437F-H5189
95109B	1		OLD REMOVED/WITH NEW REPLACED HANGER 1-14B-437B-DE020
95109B	1		MODIFIED HANGER 1-14B-437A-5R52
95109B	1		INSTALLED HANGER 1-14B-437A-5R49

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFD-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951098	1		MODIFIED HANGER 1-14B-437A-5R40
951098	1		OLD REMOVED/WITH NEW REPLACED HANGER 1-14B-437A-5R38
951098	1		INSTALLED SHIM HANGER 1-14B-0-4008-5R33
951098	1		OLD REMOVED/WITH NEW REPLACED HANGER 1-14B-437B-DE021
950928	1		MODIFIED HANGER 1-55-1-0-437B-H12
950928	1		MODIFIED HANGER 1-55-1-0-444-H49
951098	1		REMOVED HANGER 1-14B-439B-RMC-0504
951098	1		INSTALLED 1-14B-1-0-439B-H20
951098	1		REMOVED/REPLACED HANGER 1-14B-439B-RB-0901
951098	1		REMOVED/REPLACED HANGER 1-14B-439B-DE004
951098	1		MODIFIED HANGER 1-14B-436D-5R41
951098	1		INSTALLED HANGER 1-14B-439B-RJC-0601
951098	1		REMOVED/REPLACED HANGER 1-14B-439B-DE005
951098	1		INSTALLED HANGER 1-14B-1-0-439B-DE140
951098	1		REMOVED HANGER 1-14B-439B-DE006
951098	1		INSTALLED HANGER 1-14B-0-439B-RMC-0503
951098	1		REMOVED/REPLACED HANGER 1-14B-5-0-1444-H15

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
95109B	1		INSTALLED HANGER 1-14B-0-439B-DE138
95109B	1		REMOVED HANGER 1-14B-439B-JEJ-0803
95109B	1		MODIFIED HANGER 1-14B-439B-SR42
95109B	1		REMOVED/REPLACED HANGER 1-14B-0-400B-SR34
95109B	1		INSTALLED HANGER 1-14B-0-439B-DE136
95109B	1		INSTALLED HANGER 1-14B-400B-DE096
95109B	1		INSTALLED HANGER 1-14B-437B-SR25
97521	1		MODIFIED HANGER 1-01A-1-1-0-401A-H3
97521	1		MODIFIED HANGER 1-01A-1-4-0-401B-H27
97521	1		INSTALLED HANGER 1-01A-1-4-0-401B-H28
97521	1		INSTALLED HANGER 1-01A-1-4-0-401A-H18
95109B	1		REMOVED/REPLACED HANGER 1-14B-1-0-439B-SR43
95109B	1		INSTALLED HANGER 1-14B-0-439B-H7
95109B	1		MODIFIED HANGER 1-14B-437A-DE042
95109B	1		MODIFIED HANGER 1-14B-437A-DE041
95109B	1		MODIFIED HANGER 1-14B-437A-DE039

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCOONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951098	1		MODIFIED HANGER 1-148-437A-DE036
951098	1		REPLACED HANGER 1-148-0-437B-DE024
951098	1		REMOVED HANGER 1-148-436D-WJB-1201
951098	1		MODIFIED HANGER 1-148-437B-DE023
951098	1		MODIFIED HANGER 1-148-0-1444-A5R18
951098	1		REMOVED HANGER 1-148-0-437A-5R53
951098	1		MODIFIED HANGER 1-148-0-439B-5R52
951098	1		REMOVED/REPLACED HANGER 1-148-439B-RJC-0602
951098	1		REMOVED HANGER 1-148-439B-JEJ-0801
951098	1		REMOVED HANGER 1-148-439B-JEJ-0802
951098	1		INSTALLED HANGER 1-148-0-439B-5R55
951098	1		INSTALLED HANGER 1-148-1-0-439B-DE139
951098	1		MODIFIED HANGER 1-148-0-436F-H25
951098	1		REMOVED HANGER 1-148-0-437B-H18
951098	1		REMOVED HANGER 1-148-0-437B-H17
951098	1		REMOVED HANGER 1-148-1-0-444-H6

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
95109B	1		REPLACED HANGER 1-14B-1-0-439B-H10
95109B	1		MODIFIED HANGER 1-14B-1-0-439B-H5
95109B	1		MODIFIED HANGER 1-14B-1-0-439B-H4
95109B	1		INSTALLED HANGER 1-14B-1-0-437A-H1
95109B	1		INSTALLED HANGER 1-14B-0-437B-SR27
95109B	1		MODIFIED HANGER 1-14B-400B-DE095
95109B	1		INSTALLED HANGER 1-14B-400B-DE075
95109B	1		ADJUSTED HANGER 1-14B-400B-DE070
95109B	1		MODIFIED HANGER 1-14B-400B-DE074
95109B	1		MODIFIED HANGER 1-14B-400B-DE068
95109B	1		INSTALLED HANGER 1-14B-4360-DE065
95109B	1		MODIFIED HANGER 1-14B-437A-DE061
95109B	1		MODIFIED HANGER 1-14B-437A-DE058
95109B	1		ADDED SHIM, HANGER 1-14B-0-439B-SR46
95109B	1		INSTALLED HANGER 1-14B-1-0-439B-DE141
95121B	1		INSTALLED HANGER 1-51A-1-0-438A-H71

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFD-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951218	1		INSTALLED HANGER 1-51-0-439A-5R39
951218	1		MODIFY HANGER 1-51-0-439A-5R40
951218	1		INSTALL HANGER 1-51-0-437B-ARM-2102
951218	1		INSTALL HANGER 1-51-0-435C-DE064
951218	1		INSTALL HANGER 1-51-0-439C-LC-2504
951218	1		INSTALL HANGER 1-51-0-438A-DE054
951218	1		INSTALL HANGER 1-51-0-435C-DE065
951218	1		INSTALL HANGER 1-51-0-437B-DE042
951218	1		INSTALL HANGER 1-51-0-436D-JTC-0401
951218	1		INSTALL HANGER 1-51-435E-DE101
951218	1		MODIFIED HANGER 1-51-0-444-5R48
951218	1		MODIFIED HANGER 1-51-4-0-437A-H52
951218	1		MODIFIED HANGER 1-51-0-439C-5R45
951218	1		INSTALL HANGER 1-51-1-0-438C-DE038
951218	1		INSTALL HANGER 1-51-1-0-437B-DE037
951218	1		INSTALL HANGER 1-51-0-438C-5R30
951218	1		MODIFIED HANGER 1-51-0-437B-5R24

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951218	1		MODIFIED HANGER 1-51-0-437B-SR23
951218	1		MODIFIED HANGER 1-51-0-436H-SR17
951218	1		MODIFY HANGER 1-51-0-444-SR52
951218	1		MODIFY HANGER 1-51-0-436H-SR3
951218	1		INSTALLED HANGER 1-51-0-436H-SR18
951218	1		INSTALLED HANGER 1-51-0-436H-H61
951218	1		MODIFY HANGER 1-51-0-436D-SR11
951218	1		MODIFY HANGER 1-51-0-436H-SR19
951218	1		REMOVED 1-51-0-439C-DE072
951218	1		INSTALLED HANGER 1-51-0-438A-SR26
951218	1		INSTALLED HANGER 1-51-0-438A-SR28
951218	1		INSTALLED HANGER 1-51-0-437B-ARM-2004
951218	1		INSTALLED HANGER 1-51-0-437A-SR31
951218	1		INSTALLED HANGER 1-51-0-439A-SR38
951218	1		INSTALLED HANGER 1-51-1-0-435B-DE093
951218	1		INSTALLED HANGER 1-51-437B-ARM-2003
951218	1		INSTALLED HANGER 1-51-0-439C-SR43
951218	1		MODIFY HANGER 1-51-0-439C-SR46

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951218	1		MODIFY HANGER 1-51-0-444-SR51
951218	1		INSTALLED HANGER 1-51-0-444-SR56
951218	1		INSTALLED HANGER 1-51-0-436D-JTC-0402
951218	1		MODIFY HANGER 1-51-0-439C-SR47
951218	1		MODIFY HANGER 1-51-0-439B-RHG-2806
951218	1		MODIFY HANGER 1-51-0-435C-SR4
951218	1		MODIFY HANGER 1-51-0-435C-SR5
951218	1		REMOVED HANGER 1-51-0-439B-RHG-2808
951218	1		INSTALLED HANGER 1-51-437B-ARM-2002
951218	1		REMOVED HANGER 1-51-0-438C-SR31
951218	1		MODIFY HANGER 1-51A-0-435C-DE001
951218	1		MODIFY HANGER 1-51A-0-439B-DE012
951218	1		MODIFY HANGER 1-51A-0-439C-H87
951218	1		MODIFY HANGER 1-51A-1-0-439B-H67
951218	1		MODIFY HANGER 1-51A-1-0-439B-H66
951218	1		INSTALLED HANGER 1-51A-40-437A-H49
951218	1		MODIFY HANGER 1-51A-1-0-439A-H27
951218	1		INSTALLED HANGER 1-51A-1-0-439C-H17

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OGDNEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951218	1		INSTALLED HANGER 1-51A-1-0-439C-H13
951218	1		MODIFIED HANGER 1-51A-1-0-437B-H5
951218	1		MODIFY HANGER 1-51A-1-0-444-H2
951218	1		MODIFY HANGER 1-51A-439C-DM-2003
951218	1		INSTALLED HANGER 1-51A-1-0-439B-DE079
951218	1		1-51A-439C-DE073
951218	1		INSTALLED HANGER 1-51A-1-0-439B-DE057
951218	1		INSTALLED HANGER 1-51A-0-438A-DE056
951218	1		INSTALLED HANGER 1-51A-0-438A-DE053
951218	1		INSTALLED HANGER 1-51A-0-438A-DE052
951218	1		INSTALLED HANGER 1-51A-0-438A-DE050
951218	1		INSTALLED HANGER 1-51A-438A-DE048
951218	1		INSTALLED HANGER 1-51A-437A-DE044
951218	1		INSTALLED HANGER 1-51A-437A-DE043
951218	1		INSTALLED HANGER 1-51A-437A-DE041
951218	1		INSTALLED HANGER 1-51A-437A-DE040
951218	1		INSTALLED HANGER 1-51A-444-DE039

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951218	1		INSTALLED HANGER 1-51A-439C-DE030
951218	1		MODIFY HANGER 1-51A-439C-DE022
951218	1		INSTALLED HANGER 1-51A-439C-DE029
951218	1		MODIFY HANGER 1-51A-439C-DE021
951218	1		MODIFY HANGER 1-51A-439B-DE013
951218	1		INSTALLED HANGER 1-51A-439C-DE012
951218	1		INSTALLED HANGER 1-51A-439C-DE011
951218	1		INSTALLED HANGER 1-51A-439B-DE011
951218	1		INSTALLED HANGER 1-51A-439B-DE010
951218	1		MODIFY HANGER 1-51A-439B-DE007
951218	1		INSTALL HANGER 1-51A-439C-DE005
951218	1		MODIFY HANGER 1-51A-439C-DE004
951218	1		INSTALL HANGER 1-51A-439C-DE003
951218	1		INSTALL HANGER 1-51A-437A-DE003
951218	1		INSTALL HANGER 1-51A-435B-DE002
951218	1		INSTALL HANGER 1-51A-437A-DE002
951218	1		MODIFY HANGER 1-51A-0-435C-DE001A
951218	1		MODIFY HANGER 1-51A-438C-85M-2001

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFD-12
ASME SECTION XI - 1980
OCOONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951218	1		INSTALL HANGER 1-51A-1-0-439A-RD-2501
951218	1		MODIFY HANGER 1-51A-0-437B-ARM-2006
951218	1		REMOVED HANGER 1-51A-0-439C-DE036
951218	1		REMOVED HANGER 1-51A-0-439C-DH-2001
951218	1		REMOVED HANGER 1-51A-435C-DE090
951218	1		REMOVED HANGER 1-51A-439A-LME-2003
951218	1		REMOVED HANGER 1-51A-0-439B-RHG-2803
951218	1		REMOVED HANGER 1-51A-0-439B-RHG-2804
951218	1		REMOVED HANGER 1-51A-439C-DE032
951218	1		REMOVED HANGER 1-51A-439C-DE033
951218	1		REMOVED HANGER 1-51A-0-439C-DE034
951218	1		REMOVED HANGER 1-51A-439C-DE031
951218	1		REMOVED HANGER 1-51A-439C-DE001
951218	1		REMOVED HANGER 1-51A-439C-DE009
951218	1		REMOVED HANGER 1-51A-0-439B-RHG-2802
951218	1		REMOVED HANGER 1-51A-439B-DE008

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951218	1		REMOVED HANGER 1-51A-0-439B-RHG-2801
951218	1		REMOVED HANGER 1-51A-LME-2006
951218	1		REMOVED HANGER 1-51A-0-439A-LME-2005
951218	1		REMOVED HANGER 1-51A-LME-2004
951218	1		REMOVED HANGER 1-51A-0-439E-LC-2402
951218	1		REMOVED HANGER 1-51A-435C-DE089
951218	1		REMOVED HANGER 1-51A-439A-JWC-1901
951218	1		REMOVED HANGER 1-51A-0-437B-ARM-2103
951218	1		MODIFY HANGER 1-51A-439B-DE006
951218	1		INSTALL HANGER 1-51A-1-0-438C-H9
951218	1		INSTALL HANGER 1-51A-439C-DE006
951218	1		INSTALL HANGER 1-51A-1-0-439B-DE055
951218	1		INSTALL HANGER 1-51B-436H-DE019
951218	1		INSTALL HANGER 1-51B-436H-DE020
951218	1		INSTALL HANGER 1-51B-436H-DE021
951218	1		INSTALL HANGER 1-51B-436H-DE014
951218	1		MODIFY HANGER 1-51B-436H-DE002
951218	1		INSTALL HANGER 1-51B-436H-DE069

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFD-12
ASME SECTION XI - 1980
OCOONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951218	1		INSTALL HANGER 1-51B-436H-DE010
951218	1		INSTALL HANGER 1-51B-2-0-436G-DE002
951218	1		MODIFY HANGER 1-51B-2-0-436G-DE045
951218	1		INSTALL HANGER 1-51B-2-0-437A-DE051
951218	1		MODIFY HANGER 1-51B-436H-DE001
951218	1		REMOVE HANGER 1-51A-435C-DE002
951218	1		REMOVE HANGER 1-51B-2-0-437A-H35
951218	1		REMOVE HANGER 1-51B-2-0-436D-H43A
951218	1		REMOVE HANGER 1-51-439E-LC-2401
951218	1		REMOVE HANGER 1-51B-2-0-436D-H43
951218	1		MODIFY HANGER 1-51B-2-0-436D-H42
951218	1		MODIFY HANGER 1-51B-436E-SR66
951218	1		INSTALL HANGER 1-51B-2-0-436E-SR65
951218	1		INSTALL HANGER 1-51-0-437B-ARM-2101
951218	1		REMOVE HANGER 1-51B-2-0-437A-H36
951218	1		INSTALL HANGER 1-51B-436H-DE003
951218	1		MODIFY HANGER 1-51-0-437B-SR22
951218	1		MODIFY HANGER 1-51-0-438A-SR27

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFD-12
ASME SECTION XI - 1980
UCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951218	1		MODIFY HANGER 1-51-0-436H-H60
951218	1		INSTALL HANGER 1-51B-436H-DE016
951218	1		MODIFY HANGER 1-51B-436H-DE017
951218	1		INSTALL HANGER 1-51B-436H-DE018
951218	1		MODIFY HANGER 1-51B-436H-DE015
951218	1		INSTALL HANGER 1-51B-436H-DE009
951218	1		INSTALL HANGER 1-51B-2-0-437A-DE091
951218	1		REMOVE HANGER 1-53A-1-436D-DJB-2701
951218	1		INSTALL HANGER 1-54A-435B-DE13
951218	1		INSTALL HANGER 1-53B-0-435C-DE087
951218	1		MODIFY HANGER 1-53B-5-0-436D-H20
951218	1		INSTALL HANGER 1-53B-5-0-436D-H24A
951218	1		REMOVE HANGER 1-53B-2-0-436E-H8
951218	1		REMOVE HANGER 1-53B-2-0-436E-H9
951218	1		MODIFY HANGER 1-53B-2-0-436E-H10
951218	1		MODIFY HANGER 1-53B-5-0-436D-H10
951218	1		INSTALL HANGER 1-53B-5-0-444-H5
951218	1		MODIFY HANGER 1-53B-2-0-436E-H7

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951218	1		MODIFIED HANGER 1-53B-2-0-436E-DE083
951218	1		MODIFIED HANGER 1-53B-435C-DE063
951218	1		MODIFIED HANGER 1-53B-435C-DE060
951218	1		INSTALL HANGER 1-53B-435C-DE058
951218	1		INSTALL HANGER 1-53B-435B-DE032
951218	1		INSTALL HANGER 1-53B-435B-DE034
951218	1		INSTALL HANGER 1-53B-435B-DE035
951218	1		MODIFIED HANGER 1-53B-435C-DE020
951218	1		REMOVED HANGER 1-51-436H-TLM-0601
951218	1		REMOVED HANGER 1-51A-437A-RDJ-2101
951218	1		REMOVED HANGER 1-51-0-437B-JW-2106
951218	1		REMOVED HANGER 1-51-436H-JWC-1901
951218	1		REMOVED HANGER 1-51B-436K-TLM-0401
951218	1		REMOVED HANGER 1-51B-436G-DE003
951218	1		MODIFIED HANGER 1-51-0-444-SR49
951218	1		MODIFIED HANGER 1-51A-439C-DE025

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCDNEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951218	1		MODIFIED HANGER 1-51A-439C-DE026
951218	1		MODIFIED HANGER 1-54A-435B-DE03
951218	1		MODIFIED HANGER 1-53B-0-5-0-4360-H12
950928	1		MODIFIED HANGER PER SKETCH 1-55-1-0-437B-H16
950928	1		INSTALLED HANGER 1-55-1-0-437B-H17
950928	1		MODIFIED HANGER 1-55-1-0-439C-H32
950928	1		MODIFIED HANGER 1-55-1-0-439C-H34
950928	1		MODIFIED HANGER 1-55-1-0-439B-H39A
950928	1		MODIFIED HANGER 1-55-1-0-439B-H40
950928	1		INSTALLED HANGER 1-55-1-0-439B-H42
950928	1		MODIFIED HANGER 1-55-1-0-437B-SR4
950928	1		INSTALLED HANGER 1-55-1-0-437B-SR5
950928	1		INSTALLED HANGER 1-55-1-0-439C-SR10
950928	1		MODIFIED HANGER 1-55-1-0-439C-SR12
950928	1		REMOVED HANGER 1-55-RJC-0-439C-2701
950928	1		MODIFIED HANGER 1-55-1-0-437B-SR3

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFQ-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
95092B	1		MODIFIED HANGER 1-55-1-0-439B-H43
95092B	1		ADJUSTED SPRING HANGER 1-55-1-0-439B-H44
95092B	1		MODIFIED HANGER 1-55-1-0-444-H50
95092B	1		INSTALLED HANGER 1-55-1-0-444-SR22
95092B	1		INSTALLED HANGER 1-55-1-0-439B-SR14
95092B	1		REPLACED HANGER 1-55-437B-JL5-2901
95092B	1		REMOVED HANGER 1-55-1-0-439A-H39
97521	1		MODIFIED HANGER 1-01A-400A-JEJ-1401
97521	1		MODIFIED HANGER 1-02A-1-0-403A-H12
97521	1		INSTALLED HANGER 1-01A-0-403A-DE066
97521	1		INSTALLED HANGER 1-01A-0-403A-JGM-1704
97521	1		INSTALLED HANGER 1-01A-0-403A-JGM-1703
97521	1		MODIFIED HANGER 1-01A-0-403A-JGM-1702
97521	1		MODIFIED HANGER 1-01A-0-403A-DE065
97521	1		MODIFIED HANGER 1-01A-0-550-R1
97521	1		MODIFIED HANGER 1-01A-4-2-0-400A-R11
97521	1		MODIFIED HANGER 1-01A-4-0-401A-H4

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCDNEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
97521	1		MODIFIED HANGER 1-01A-4-2-0-403C-R2
97521	1		INSTALLED HANGER 1-01A-401A-DE008
97521	1		INSTALLED HANGER 1-01A-403C-DE002
97521	1		INSTALLED HANGER 1-01A-403C-DE003
97521	1		MODIFIED HANGER 1-01A-4-1-0-401A-H1
97521	1		REMOVED HANGER 1-01A-401B-JWC-2801
97521	1		REMOVED HANGER 1-01A-401B-JWC-1703
97521	1		MODIFIED HANGER 1-01A-401A-JGM-1002
97521	1		MODIFIED HANGER 1-01A-401A-JGM-1001
97521	1		REMOVED HANGER 1-01A-0-401A-TWE-1379
97521	1		MODIFY HANGER 1-01A-0-550-H15
97521	1		MODIFY HANGER 1-01A-0-550-R7
97521	1		MODIFY HANGER 1-01A-0-550-H14
97521	1		MODIFY HANGER 1-01A-0-550-H13
97521	1		INSTALLED HANGER 1-01A-0-550-DE006
97521	1		REMOVED HANGER 1-01A-0-403C-JH-1603
97521	1		REMOVED HANGER 1-01A-0-403C-JH-1602
97521	1		REMOVED HANGER 1-01A-0-403C-JH-1303

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFD-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
97521	1		REMOVED HANGER 1-01A-0-403C-JH-1302
97521	1		REMOVED HANGER 1-01A-0-403C-JH-1301
97521	1		REMOVED HANGER 1-01A-4-2-0-403C-R4
97521	1		REMOVED HANGER 1-01A-0-403A-JCM-1707
97521	1		REMOVED HANGER 1-01A-4-2-0-403C-R5
97521	1		REMOVED HANGER 1-01A-0-403A-JCM-1708
97521	1		REMOVED HANGER 1-01A-0-403D-DE049
97521	1		REMOVED HANGER 1-01A-0-403D-DE043
97521	1		REMOVED HANGER 1-01A-4-2-0-403D-R14
97521	1		INSTALLED HANGER 1-01A-0-403C-JH-1601
97521	1		MODIFY HANGER 1-01A-0-403A-FAC-1705
97521	1		INSTALLED HANGER 1-01A-400K-KWW-0300
97521	1		MODIFY HANGER 1-01A-0-550-M5-2
97521	1		MODIFY HANGER 1-01A-0-550-R16
97521	1		INSTALLED HANGER 1-01A-0-550-H10
97521	1		REPLACED HANGER 1-01A-0-550-H24
97521	1		MODIFIED HANGER 1-01A-0-550-R13

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFD-12
ASME SECTION XI - 1980
OCOONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
97521	1		INSTALLED HANGER 1-01A-0-550-R6
97521	1		REPLACED HANGER 1-01A-0-550-H9
97521	1		INSTALLED HANGER 1-01A-0-550-R5
97521	1		ADJUSTED COLD SET HANGER 1-01A-0-550-H21
97521	1		MODIFIED HANGER 1-01A-0-550-H7
97521	1		OFFSET PIPE CLAMP HANGER 1-01A-0-550-H8
97521	1		MODIFIED HANGER 1-01A-0-550-H20
97521	1		ADJUSTED SPRING CAN HANGER 1-01A-0-550-H19
97521	1		INSTALLED HANGER 1-01A-0-550-H6
97521	1		REPLACED HANGER 1-01A-0-550-R4
97521	1		ADJUSTED SPRING CAN HANGER 1-01A-0-550-H18
97521	1		INSTALLED HANGER 1-01A-0-550-DE005
97521	1		MODIFIED HANGER 1-01A-0-550-H17
97521	1		MODIFIED HANGER 1-01A-0-550-R9
97521	1		REPLACED HANGER 1-01A-0-550-R8
97521	1		REPLACED SPRING CAN HANGER 1-01A-0-401A-EMO-H14
97521	1		MODIFIED HANGER 1-01A-1-1-0-401A-H41
97521	1		ADJUSTED SPRING CAN HANGER 1-01A-1-1-0-401A-H2

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
97521	1		MODIFIED HANGER 1-01A-1-1-0-401A-H5
97521	1		REPLACED HANGER 1-01A-1-4-0-401A-H25
97521	1		INSTALLED HANGER 1-01A-1-4-0-401A-H24
97521	1		MODIFIED HANGER 1-01A-1-4-0-401A-H23
97521	1		MODIFIED HANGER 1-01A-1-4-0-401A-H22
97521	1		INSTALLED HANGER 1-01A-0-401A-DE071
97521	1		MODIFIED HANGER 1-01A-1-4-0-401A-H21
97521	1		MODIFIED HANGER 1-01A-1-2-0-401A-H39
97521	1		REPLACED HANGER 1-01A-1-2-401A-H50
97521	1		MODIFIED HANGER 1-01A-1-4-0-401B-H29
97521	1		REPLACED SPRING CANS HANGER 1-01A-1-4-0-401B-H30
97521	1		INSTALLED HANGER 1-01A-402B-DE073
97521	1		REPLACED HANGER 1-01A-1-4-0-401B-H31
97521	1		INSTALLED HANGER 1-01A-0-550-R11
97521	1		MODIFIED HANGER 1-01A-0-550-H23
97521	1		REMOVED HANGER 1-01A-0-441-R18
97521	1		REMOVED HANGER 1-01A-0-441-R17

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
95337B	1		MODIFIED HANGER PER SKETCH 1-56-4-0-437B-H1
95337B	1		MODIFIED HANGER PER SKETCH 1-53B-438C-DE001
95337B	1		MODIFIED HANGER PER SKETCH 1-56-5-0-437B-H50
95337B	1		MODIFIED HANGER PER SKETCH 1-56-0-438C-DE024
95337B	1		INSTALLED HANGER 1-56-437B-JGM-0801
95337B	1		INSTALLED HANGER 1-56-438B-DE004
95337B	1		REMOVED HANGER 1-56-4-0-437B-H15
95337B	1		MODIFIED HANGER PER SKETCH 1-56-2-0-437B-H58
95337B	1		MODIFIED HANGER PER SKETCH 1-56-4-0-437B-DE037
95337B	1		MODIFIED HANGER PER SKETCH 1-56-4-0-437B-DE038
95337B	1		MODIFIED HANGER PER SKETCH 1-56-5-0-437B-H37
95337B	1		MODIFIED HANGER PER SKETCH 1-53B-438C-DE092
95337B	1		REALIGNED U-BOLT FOR LOOSE FIT 1-56-0-437B-RTB-1005
95337B	1		REPLACED HANGER 1-53B-438C-DE093
95337B	1		REALIGNED U-BOLT FOR LOOSE FIT 1-56-0-437B-RTB-1004
95337B	1		MODIFIED HANGER 1-56-4-0-437B-DE036

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFD-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
953378	1		MODIFIED HANGER 1-56-5-0-437B-TLM-1079
953378	1		REPLACED HANGER 1-56-0-437B-SR20
953378	1		INSTALLED HANGER 1-56-437B-DE017
953378	1		MODIFIED HANGER 1-56-0-437B-SR17
973378	1		MODIFIED HANGER 1-56-0-437B-SR9
953378	1		MODIFIED HANGER 1-56-2-0-438C-H62
953378	1		MODIFIED HANGER 1-56-438C-DE011
953378	1		REPLACED HANGER 1-56-437D-DE014
953378	1		MODIFIED HANGER 1-56-437B-DE020
953378	1		MODIFIED HANGER 1-538-438D-W55-2002
953378	1		MODIFIED HANGER 1-538-438D-W55-2001
953378	1		MODIFIED HANGER 1-538-438D-W55-2003
953378	1		REMOVED HANGER 1-56-5-0-437B-H54
953378	1		REMOVED HANGER 1-56-5-0-437B-H52
953378	1		REALIGNED U-BOLT FOR LOOSE FIT 1-56-0-437B-SR8
953378	1		REPLACED HANGER 1-56-5-0-437B-H39

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCOONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
95337B	1		MODIFIED HANGER 1-56-5-0-437B-H36
95337B	1		MODIFIED HANGER 1-56-4-0-443-H65
95337B	1		REMOVED HANGER 1-JGM-56-0-437B-3001
95337B	1		MODIFIED HANGER 1-56-437B-REB-0701
95337B	1		MODIFIED HANGER 1-56-437B-JWC-1201
95337B	1		MODIFIED HANGER 1-53B-438C-LCC-1501
95337B	1		1-56-0-437B-RTB-1001
95337B	1		REPLACED HANGER 1-56-437B-JGM-0802
95065B	1		REPAIR HANGER 1-55-0-479A-H31C
97509	1		REPAIR HANGER 1-03-0-480A-H5A
97509	1		REPAIR HANGER 1-03-0-479A-H4A
97509	1		REPAIR HANGER 1-03-0-479A-H3B
97509	1		REPAIR HANGER 1-03-0-479A-H4B
97509	1		REPAIR HANGER 1-03-0-479A-H5B
97509	1		REPAIR HANGER 1-03-0-480A-H9B
97509	1		REPAIR HANGER 1-03-0-481A-H11B
97509	1		REPAIR HANGER 1-03-0-481A-H14B
97509	1		REPAIR HANGER 1-03-0-481A-H5B
97509	1		REPAIR HANGER 1-03-0-481A-H16B
97502	1		REPAIR HANGER 1-31-0-479D-DE001

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCDNEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
97502	1		REPAIR HANGER 1-31-0-439C-DE002
97502	1		REMOVE HANGER 1-31-0-439C-JRL-3001
97508	1		REPLACE HANGER 1-53A-0-479A-H7A
97508	1		REPAIR HANGER 1-53A-0-478A-H6A
97508	1		REPAIR HANGER 1-53A-0-478A-H4A
97503	1		REPAIR HANGER 1-69-0-439C-DE004
97503	1		REMOVE HANGER 1-69-0-438C-DE001
95111B	1		REMOVE HANGER 1-07A-400B-GC-2610
95111B	1		REMOVED HANGER 1-07A-400B-GC-2607
95111B	1		REMOVED HANGER 1-07A-400B-GC-2605
95111B	1		REMOVED HANGER 1-07A-400B-GC-2603
95111B	1		REPAIR HANGER 2-07A-1400AA-JWC-1607
95111B	1		REPAIR HANGER 2-07A-1400B-JWC-0901
95111B	1		REPAIR HANGER 2-07A-1400B-JWC-0201
95111B	1		REPAIR HANGER 2-07A-1400A-JEJ-1604
95111B	1		REPAIR HANGER 1-07A-400B-GC-2613
92794C	1		REPLACED A325 BOLTING 1-64-439C-H5594

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
95111B	1		REPAIR HANGER 1-07A-400B-GC-2611
95111B	1		REPAIR HANGER 1-07A-400B-GC-2604
95111B	1		REPAIR HANGER 1-07A-400B-GC-2601
95111B	1		REPAIR HANGER 1-07A-400B-DE068
95111B	1		REPAIR HANGER
95111B	1		INSTALLED HANGER 1-07A-400B-DE048
95111B	1		REMOVED HANGER 1-07A-400B-SR-64
95111B	1		REMOVED HANGER 1-07A-400B-TLM-2114
95111B	1		REMOVED HANGER 1-07A-400B-JME-2304
95111B	1		REMOVED HANGER 1-07A-402A-DE028
95111B	1		REMOVED HANGER 1-07A-402A-DE026
95111B	1		REMOVED HANGER 1-07A-400B-JME-2303
95111B	1		REMOVED HANGER 1-07A-400A-GTE-2101
95111B	1		REMOVED HANGER 1-07A-400B-DE063A
95111B	1		REMOVED HANGER 1-07A-400B-GTE-2001
95111B	1		REPLACED HANGER 1-07A-400A-GTE-2102
95111B	1		REPAIR HANGER 1-07A-400B-SR-11

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFD-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
95111B	1		REPAIR HANGER 1-07A-400B-5R-9
95111B	1		REPAIR HANGER 1-07A-400B-5R-7
95111B	1		REPAIR HANGER 1-07A-400B-5R-5
95111B	1		REPAIR HANGER 1-07A-400A-5R-1
95111B	1		REPAIR HANGER 1-07A-402A-HB
95111B	1		REPAIR HANGER 1-07A-400B-DE058
95111B	1		INSTALLED HANGER 1-07A-400B-DE056
95111B	1		REPAIR HANGER 1-07A-400B-DE055
95111B	1		INSTALL HANGER 1-07A-400B-DE054
95111B	1		INSTALL HANGER 1-07A-402A-DE029
95111B	1		REPAIR HANGER 1-07A-402A-DE027
95111B	1		REPAIR HANGER 1-07A-400B-DE022
95111B	1		REPAIR HANGER 1-07A-400B-DE018
95111B	1		REPLACED HANGER 1-07A-400B-DE017
95111B	1		MODIFIED HANGER 1-07A-6-0-400A-H41
95111B	1		INSTALLED HANGER 1-07A-400B-DE047
95111B	1		INSTALLED HANGER 1-07A-400B-DE046
95111B	1		INSTALLED HANGER 1-07A-400B-DE049
95111B	1		MODIFY HANGER 1-07A-401A-RNF-2305
95111B	1		INSTALLED HANGER 1-07A-400A-RNF-2304

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFD-12
ASME SECTION XI - 1980
OCOONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951118	1		MODIFY HANGER 1-07A-400A-RNF-2303
951118	1		INSTALLED 1-07A-400A-RNF-2302
951118	1		INSTALLED HANGER 1-07A-400A-RNF-2301
951118	1		REPLACED HANGER 1-07A-400B-PN-2302
951118	1		MODIFY HANGER 1-07A-400B-PN-2301
051118	1		INSTALL HANGER 1-07A-400B-SR22
951118	1		INSTALL HANGER 1-07A-400B-SR20
951118	1		MODIFY HANGER 1-07A-400B-SR19
951118	1		MODIFY HANGER 1-07A-5-0-402A-H12
951118	1		INSTALL HANGER 1-07A-0-400B-SR18
951118	1		INSTALL HANGER 1-07A-6-0-402A-H10
951118	1		REPLACED HANGER 1-07A-400B-DE039
951118	1		REPLACED HANGER 1-07A-400A-DE035
951118	1		REPLACED HANGER 1-07A-400A-DE034
951118	1		MODIFY HANGER 1-07A-400A-DE033
951118	1		MODIFY HANGER 1-07A-400A-DE032
951118	1		INSTALL HANGER 1-07A-400A-DE031
951118	1		MODIFY HANGER 1-07A-400B-DE009
951118	1		INSTALL HANGER 1-07A-400B-DE008

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFG-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951118	1		INSTALL HANGER 1-07A-400B-H4135
951118	1		REMOVED HANGER 1-07A-0-400B-JME-2301
951118	1		REMOVED HANGER 1-07A-0-400B-PN-2304
951118	1		REMOVED HANGER 1-07A-0-400B-SR14
951118	1		MODIFY HANGER 1-07A-400B-DE064
951118	1		REPLACED HANGER 1-07A-400A-DE063
951118	1		MODIFY HANGER 1-11-400A-DE003
951118	1		MODIFY HANGER 1-07A-400B-SR17
951118	1		MODIFY HANGER 1-07A-400B-SR16
951118	1		INSTALL HANGER 1-07A-6-0-400B-H48
951118	1		MODIFY HANGER 1-07A-6-0-400B-H47
951118	1		MODIFY HANGER 2-07A-1400B-JWC-0203
951118	1		REPLACED HANGER 1-07A-400B-TLM-2111
951118	1		MODIFY HANGER 2-07A-1400A-JWC-1606
951118	1		MODIFY HANGER 1-07A-400B-DE006
951118	1		MODIFY HANGER 1-07A-400B-DE010
051165	1		ADJUSTED SPRING SETTING HANGER 1-02A-1-0-403A-H12
97265C	1		MODIFY HANGER 0-14C-447A-H7038
97847C	1		ADJUSTED CAN SPRING HANGER 1-08-1-0-401A-H6

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
950988	1		INSTALLED SHIM-HANGER 1-04A-0-479A-H20A
950988	1		MODIFIED PER SKETCH-HANGER 1-04A-0-479A-MSM-H1701
950988	1		ADJUSTED CLEARANCE-HANGER 1-04A-0-479A-H22A
950988	1		MODIFIED PER SKETCH-HANGER 1-04A-0-478A-NPS-H36
950988	1		MODIFIED PER SKETCH-HANGER 1-04A-0-478A-NPS-H37
950988	1		MODIFIED PER SKETCH-HANGER 1-04A-0-478A-H25A
950988	1		MODIFIED PER SKETCH-HANGER 1-04A-0-478A-H26A
950988	1		MODIFIED PER SKETCH-HANGER 1-04A-0-479A-JEB-0401
950988	1		MODIFIED PER SKETCH-HANGER 1-04A-0-479A-H27A
950988	1		ADJUSTED CLEARANCE-HANGER 1-04A-0-479A-H29A
950988	1		REMOVED HANGER 1-04A-0-480A-H30A
950988	1		MODIFIED PER SKETCH-HANGER 1-04A-0-478A-H24B
950988	1		MODIFIED PER SKETCH-HANGER 1-04A-0-478A-H1A
950988	1		MODIFIED PER SKETCH-HANGER 1-04A-0-479A-EWD-H0101
950988	1		INSTALLED HANGER 1-04A-0-479A-GPD-H0052
950988	1		ADJUSTED U-BOLT AND TACK WELDED NUT HANGER 04A-0-479A-CMP-HC215

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
950988	1		INSTALLED SHIM-HANGER 1-04A-0-478A-H9A
950988	1		ADJUSTED FOR PROPER CLEARANCE HANGER 1-04A-0-478A-H10A
950988	1		INSTALLED HANGER 1-04A-0-478A-H11A
950988	1		REWELDED LUGS-HANGER 1-04A-0-478A-H13A
950988	1		REWELDED LUGS-HANGER 1-04A-0-478A-H14A
950988	1		ADJUSTED FOR PROPER CLEARANCE HANGER 1-04A-0-478A-H17A
950988	1		INSTALLED HANGER 1-04A-0-478A-GPD-H0053
950988	1		INSTALLED HANGER 1-04A-0-478A-GPD-H0054
950988	1		INSTALLED HANGER 1-59-0-478A-H15
950988	1		MODIFIED PER SKETCH HANGER 1-04A-0-478A-H18A
950988	1		MODIFIED PER SKETCH HANGER 1-04A-0-479A-H20B
950988	1		ADJUSTED FOR PROPER CLEARANCE HANGER 1-04A-0-478A-H22B
950988	1		REMOVED HANGER 1-04A-0-479A-H28A
950988	1		MODIFIED PER SKETCH HANGER 1-04A-0-478A-NPS-H26
950988	1		MODIFIED PER SKETCH HANGER 1-04A-0-479A-H25B
950988	1		INSTALLED SHIM HANGER 1-04A-0-478A-H1B

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
950988	1		INSTALLED HANGER 1-04A-0-478A-H2B
950988	1		REPLACED PIPE CLAMP BOLT 1-04A-0-478A-H3B
950988	1		INSTALLED HANGER 1-04A-0-478A-H7B
950988	1		MODIFIED PER SKETCH HANGER 1-04A-0-478A-H9B
950988	1		ADJUSTED FOR PROPER CLEARANCE HANGER 1-04A-0-478A-H10B
950988	1		MODIFIED PER SKETCH HANGER 1-04A-0-478A-H11B
950988	1		MODIFIED PER SKETCH HANGER 1-04A-0-478A-H13B
950988	1		ADJUSTED FOR PROPER CLEARANCE HANGER 1-04A-0-478A-H17B
950988	1		MODIFIED PER SKETCH HANGER 1-04A-0-478A-H18B
950988	1		MODIFIED PER SKETCH HANGER 1-04A-0-478A-CB-H0130
950988	1		ADJUSTED U-BOLT FOR PROPER CLEARANCE HANGER 1-04A-0-478A-DR5-H1801
950988	1		ADJUSTED SHOCK SUPPRESSOR HANGER 1-04A-0-478A-NP5-H35
950988	1		MODIFIED PER SKETCH HANGER 1-04A-478A-NP5-H10
950988	1		MODIFIED PER SKETCH HANGER 1-04A-478A-NP5-H35A
950988	1		MODIFIED PER SKETCH HANGER 1-04A-478A-NP5-H9
950988	1		MODIFIED PER SKETCH HANGER 1-04A-0-478A-NP5-H34

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCOONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
950988	1		MODIFIED PER SKETCH HANGER 1-04A-0-478A-NP5-H22
950988	1		MODIFIED PER SKETCH HANGER 1-04A-0-478A-NP5-H59
950988	1		MODIFIED PER SKETCH HANGER 1-04A-0-478A-NP5-H19
950988	1		REMOVED HANGER 1-04A-0-478-H53
950988	1		REMOVED HANGER 1-04A-0-479A-NP5-H41
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-438B-SR63
951198	1		REMOVED/REPLACED LUGS HANGER 1-03A-1-0-401A-SR19
951198	1		REPLACED SNUBBERS HANGER 1-03A-1-0-400B-SR58
951198	1		INSTALLED NEW HANGER 1-03A-1-0-439A-DE060
951198	1		MODIFIED PER SKETCH 1-03A-1-0-439A-H24
951198	1		INSTALLED NEW HANGER 1-03A-1-0-401A-H44
951198	1		INSTALLED NEW HANGER 1-03A-1-0-401B-DE057
951198	1		INSTALLED NEW HANGER 1-03A-1-0-401B-SR24
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-438B-H76
951198	1		INSTALLED NEW HANGER 1-03A-1-0-401B-SR23
951198	1		INSTALLED NEW HANGER 1-03A-1-0-400A-SR52
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-437A-SR61

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCDNEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-439B-H15
951198	1		WELDED EXISTING WASHER PLATE INTACT HANGER 1-03A-1-0-400A-SR34
951198	1		REMOVED HANGER 1-03A-1-0-439B-SR96
951198	1		REMOVED LUGS 1-03A-1-0-438B-SR99
951198	1		MODIFIED PER SKETCH-HANGER 1-03A-1-0-401A-SR72
951198	1		REMOVED SADDLE HANGER 1-03A-1-0-400A-SR81
951198	1		REMOVED HANGER 1-03A-1-0-400B-H60
951198	1		REMOVED/REPLACED HANGER 1-03A-1-0-401A-H41
951198	1		MODIFIED PER SKETCH HANGER 1-03A-401B-DE039
951198	1		MODIFIED PER SKETCH HANGER 1-03A-401A-DE001
951198	1		MODIFIED PER SKETCH HANGER 1-03A-401A-DE003
951198	1		MODIFIED PER SKETCH HANGER 1-03A-401A-DE004
951198	1		MODIFIED PER SKETCH HANGER 1-03A-401A-DE005
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-437A-H66
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-437A-H68
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-437A-H71

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCDNEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-439A-H103
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-401A-SR2
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-401A-SR3
951198	1		REMOVED/REPLACE EXISTING HANGER 1-03A-1-0-401A-SR5
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-401A-SR6
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-401A-SR4
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-439B-SR47
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-439B-SR49
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-401A-SR50
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-437A-SR95
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-437A-SR96
951198	1		REMOVED HANGER 1-03A-401A-DE006
951198	1		REMOVED HANGER 1-03A-401A-DE007
951198	1		REMOVED HANGER 1-03A-401A-DE008
951198	1		REMOVED HANGER 1-03A-401A-DE009
951198	1		REMOVED HANGER 1-03A-401A-DE014

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCOONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951198	1		REMOVED HANGER 1-03A-1-0-439B-H16
951198	1		REMOVED HANGER 1-03A-1-0-401A-H40
951198	1		REMOVED HANGER 1-03A-1-0-437A-H69
951198	1		REMOVED HANGER 1-03A-1-0-439B-ALD-1010
951198	1		REMOVED/REPLACED EXISTING HANGER 1-03A-1-0-437A-H70
951198	1		REMOVED HANGER 1-03A-401A-WCN-0501
951198	1		REMOVED HANGER 1-03A-401A-WCN-0502
951198	1		MODIFIED PER SKETCH HANGER 1-03A-401B-DE040
951198	1		TIGHTENED LOOSE NUTS HANGER 1-03A-401B-DE041
951198	1		MODIFIED PER SKETCH HANGER 1-03A-401B-DE042
951198	1		MODIFIED PER SKETCH HANGER 1-03A-401B-DE048
951198	1		INSTALLED HANGER 1-03A-401B-DE059
951198	1		ADJUSTED SPRING CAN HANGER 1-03A-1-0-401B-H1
951198	1		INSTALLED HANGER 1-03A-1-0-439A-H22
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-439A-H23
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-439A-H25

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951198	1		REMOVED/REPLACED EXISTING HANGER 1-03A-1-0-4398-H27
951198	1		REMOVED/REPLACED EXISTING HANGER 1-03A-1-0-401B-5R30
951198	1		INSTALLED HANGER 1-03A-401B-5R32
951198	1		INSTALLED HANGER 1-03A-1-0-439A-5R39
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-4398-5R41
951198	1		MODIFIED PER SKETCH HANGER 1-03A-401B-AM-0501
951198	1		REMOVED HANGER 1-03A-1-0-401B-5R33
951198	1		REMOVED HANGER 1-03A-439C-RB-0401
951198	1		INSTALLED HANGER 1-03A-1-0-437B-DE065
951198	1		REMOVED HANGER 1-03A-1-0-401A-5R75
951198	1		INSTALLED HANGER 1-03A-1-0-400A-5R79
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-400B-5R85
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-437A-5R88
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-437A-5R89
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-437A-5R90
951198	1		MODIFIED PER SKETCH HANGER 1-03A-401B-MB-0701

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-437A-SR91
951198	1		INSTALLED HANGER 1-03A-401A-ADM-0100
951198	1		MODIFIED PER SKETCH HANGER 1-03A-400A-ADM-0200
951198	1		REMOVED/REPLACED HANGER 1-03A-439C-BFB-0301
951198	1		REMOVED/REPLACED HANGER 1-03A-0-437B-JWC-0301
951198	1		REMOVED HANGER 1-03A-1-0-437B-H73
951198	1		REMOVED HANGER 1-03A-1-0-437B-H74
951198	1		REMOVED HANGER 1-03A-439C-H82
951198	1		REMOVED HANGER 1-03A-1-0-439C-H100
951198	1		REMOVED HANGER 1-03A-400B-WDB-0101
951198	1		REMOVED/REPLACED HANGER 1-03A-401A-DE024
951198	1		MODIFIED PER SKETCH HANGER 1-03A-401B-DE051
951198	1		INSTALLED HANGER 1-03A-1-0-401A-SR9
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-401A-SR10
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-401A-SR11
951198	1		MODIFIED PER SKETCH HANGER 1-NSR-401A-DE061
951198	1		REMOVED/REPLACED HANGER 1-03A-1-0-401A-SR12

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-401A-5R13
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-401A-5R14
951198	1		REMOVED/REPLACED HANGER 1-03A-1-0-401A-5R17
951198	1		REMOVED/REPLACED HANGER 1-03A-1-0-401A-5R18
951198	1		REMOVED/REPLACED HANGER 1-03A-1-0-401A-5R20
951198	1		REMOVED/REPLACED HANGER 1-03A-1-0-401B-5R22
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-401B-5R25
951198	1		REMOVED/REPLACED HANGER 1-03A-1-0-401B-5R26
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-401B-5R28
951198	1		MODIFIED PER SKETCH HANGER 1-03A-401A-TLN-0502
951198	1		MODIFIED PER SKETCH HANGER 1-03A-401A-TLN-0503
951198	1		REMOVED HANGER 1-03A-401A-DE017
951198	1		REMOVED HANGER 1-03A-401A-DE020
951198	1		REMOVED HANGER 1-03A-401A-DE026
951198	1		REMOVED HANGER 1-03A-401A-DE030
951198	1		REMOVED HANGER 1-03A-401B-DE052

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951198	1		REMOVED HANGER 1-03A-401B-AM-1001
951198	1		REMOVED HANGER 1-03A-401B-AM-1102
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-400B-SR59
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-401A-H45
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-400A-H46
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-400A-H47
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-400A-H49
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-400B-H55
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-400B-H59
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-437A-H64
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-437B-H72
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-438B-H77
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-439B-H78
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-439B-H79
95337B	1		MODIFIED FOR SKETCH HANGER 1-56-0-437B-RTB-1002
95337B	1		INSTALLED HANGER 1-56-0-437B-SR19

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
95337B	1		INSTALLED HANGER 1-56-0-437B-DE019
95337B	1		REPLACED HANGER 1-56-0-437E-GMT-1401
95337B	1		INSTALLED HANGER 1-56-0-438B-SR10
95337B	1		MODIFIED PER SKETCH HANGER 1-56-0-438C-SR12
95337B	1		MODIFIED PER SKETCH HANGER 1-56-0-437B-SR21
95337B	1		INSTALLED HANGER 1-56-0-437B-SR18
95337B	1		MODIFIED HANGER 1-56-4-0-437B-H2
95337B	1		MODIFIED HANGER 1-56-0-438C-SR13
95337B	1		MODIFIED HANGER 1-53B-4380-DE088
95337B	1		MODIFIED HANGER 1-56-437B-TLM-1019
95337B	1		INSTALLED HANGER 1-56-0-439A-SR22
95337B	1		REMOVED AND REPLACED/REALIGNED U-BOLT 1-56-0-437B-RTB-1003
95337B	1		REMOVED HANGER 1-56-5-0-437B-H55
95337B	1		MODIFIED PER SKETCH 1-53B-4380-LCC-1503
95337B	1		REMOVED HANGER 1-56-438C-DE006
95337B	1		MODIFIED PER SKETCH 1-56-4-0-437B-H3
95337B	1		INSTALLED HANGER 1-56-0-437B-DE018

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-439C-H102
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-400A-5R51
951198	1		REPLACED/REALIGNED PIPE CLAMP HANGER 1-03A-1-0-400A-5R53
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-400B-5R55
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-439B-5R64
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-400A-5R71
951198	1		INSTALLED HANGER 1-03A-1-0-400B-DE062
951198	1		INSTALLED HANGER 1-03A-1-0-400B-H54
951198	1		MODIFIED PER SKETCH HANGER 1-03A-1-0-400A-H38
951198	1		REPLACED HANGER 1-53B-435B-EMO-H43
950668	1		INSTALLED HANGER 1-54A-0-435B-DE014
950668	1		INSTALLED HANGER 1-54A-0-435B-DE015
950668	1		INSTALLED HANGER 1-54A-0-435B-DE016
950668	1		MODIFIED PER SKETCH HANGER 1-54A-3-0-444-H1
950668	1		MODIFIED PER SKETCH HANGER 1-54A-3-0-435B-H21
950668	1		REPLACED HANGER 1-54A-3-0-435B-H22

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFD-12
ASME SECTION XI - 1980
OCOONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
950668	1		MODIFIED PER SKETCH HANGER 1-54A-3-0-436D-R6
950668	1		MODIFIED PER SKETCH HANGER 1-54A-3-0-435B-R9
950668	1		MODIFIED PER SKETCH HANGER 1-54A-3-0-436D-R27
950668	1		REMOVED HANGER 1-54A-0-435B-DE12
950668	1		REMOVED HANGER 1-54A-3-0-435B-R10
950668	1		REPLACED HANGER 1-54A-0-435B-DE06
950668	1		MODIFIED PER SKETCH HANGER 1-54A-0-435B-DE10
950668	1		INSTALLED HANGER 1-54A-435B-DE020
950668	1		INSTALLED HANGER 1-54A-435B-DE021
950668	1		MODIFIED HANGER PER SKETCH 1-54A-3-0-435B-R1
950668	1		REPLACED HANGER 1-54A-3-0-435B-R3
950668	1		MODIFIED PER SKETCH HANGER 1-54A-3-0-435B-R4
950668	1		REMOVED HANGER 1-54A-3-0-435B-H37
950668	1		REMOVED HANGER 1-54A-0-435B-DE08
950668	1		INSTALLED HANGER 1-54A-3-0-439A-H21
950668	1		INSTALLED HANGER 1-54A-3-0-435B-R8

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCDONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
950668	1		MODIFIED PER SKETCH HANGER 1-54A-3-0-439A-H23
950668	1		MODIFIED PER SKETCH HANGER 1-54A-3-0-439A-H24
950668	1		MODIFIED PER SKETCH HANGER 1-54A-3-0-439A-H25
950668	1		REPLACED HANGER 1-54A-3-0-439A-R11
950668	1		REPLACED HANGER 1-54A-0-439A-R12
950668	1		REPLACED HANGER 1-54A-0-439A-R13
950668	1		MODIFIED PER SKETCH HANGER 1-54A-0-444-R14
950668	1		MODIFIED PER SKETCH HANGER 1-54A-0-444-R15
950668	1		MODIFIED HANGER 1-54A-0-439A-R17
950668	1		MODIFIED HANGER 1-54A-0-439A-R21
950668	1		MODIFIED HANGER 1-54A-3-0-444-R22
950668	1		REMOVED HANGER 1-54A-3-0-439A-H18
950668	1		REMOVED HANGER 1-54A-3-0-439A-H22
950668	1		REMOVED HANGER 1-54A-3-0-439A-H26
950668	1		REMOVED HANGER 1-54A-3-0-444B-RHG-0301
950668	1		INSTALLED HANGER 1-54A-A-439A-DE023

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
95066B	1		REMOVED HANGER 1-54A-0-439D-RAB-2601
95066B	1		MODIFIED HANGER 1-54A-3-0-439C-H5
95066B	1		MODIFIED HANGER 1-54A-3-0-439C-H6
95066B	1		MODIFIED HANGER 1-54A-3-0-439C-H11
95066B	1		MODIFIED HANGER 1-54A-3-0-439C-H13
95066B	1		MODIFIED HANGER 1-54A-0-439C-DE022
95066B	1		REMOVED HANGER 1-54A-0-3-439C-R23
95066B	1		REMOVED HANGER 1-54A-0-3-439C-R24
95066B	1		REMOVED HANGER 1-54A-0-3-439C-R25
97521	1		MODIFIED/SKETCH HANGER 1-01A-0-401A-DE030
97521	1		MODIFIED/SKETCH HANGER 1-01A-0-401A-TWE-1279
97521	1		MODIFIED/SKETCH HANGER 1-01A-401A-DE011
97521	1	*	MODIFIED HANGER 1-01A-2-1-0-401A-5R2204
97521	1		MODIFIED HANGER 1-01A-0-401A-DE053
97521	1		MODIFIED HANGER 1-01A-2-1-0-401A-5R2202
97521	1		MODIFIED HANGER 1-01A-0-401A-JGM-1201

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCDNEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
97521	1		MODIFIED HANGER 1-01A-0-401A-JGM-1202
97521	1		MODIFIED HANGER 1-01A-2-1-0-401A-SR7
97521	1		REMOVED HANGER 1-01A-0-401A-DE013
97521	1		INSTALLED HANGER 1-01A-0-401A-DE018
97521	1		INSTALLED HANGER 1-01A-0-401A-DE017
97521	1		MODIFIED HANGER 1-01A-0-400E-JWC-2401
97521	1		MODIFIED HANGER 1-01A-0-401B-JWC-1801
97521	1		MODIFIED HANGER 1-01A-0-401A-DE008A
97521	1		MODIFIED HANGER 1-01A-0-401A-DE012
97521	1		INSTALLED HANGER 1-01A-401A-DE052
97521	1		REPLACED HANGER 1-01A-401A-DE014
97521	1		MODIFIED HANGER 1-01A-2-1-0-401A-SR2205
97521	1		INSTALLED HANGER 1-01A-0-401A-DE015
97521	1		MODIFIED HANGER 1-01A-0-401A-GLJ-2503
97521	1		REMOVED HANGER 1-01A-3-0-401A-HTT-2301
97521	1		REMOVED HANGER 1-01A-3-0-401A-HTT-2401

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFD-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
97521	1		REMOVED HANGER 1-01A-3-0-401A-H10
97521	1		REMOVED HANGER 1-01A-3-0-401A-H12
97521	1		INSTALLED HANGER 1-01A-0-403C-JH-1516B
97521	1		MODIFIED HANGER 1-01A-3-0-401A-H17
97521	1		MODIFIED HANGER 1-01A-3-0-401A-H21
97521	1		ADJUSTED SPRING CAN COLD SETTING HANGER 1-01A-3-0-401A-H22
97521	1		MODIFIED HANGER 1-01A-3-0-401A-H14
97521	1		MODIFIED HANGER 1-01A-3-0-401A-H15
97521	1		MODIFIED HANGER 1-01A-3-0-401A-H13
97521	1		MODIFIED HANGER 1-01A-3-0-401A-H11
97521	1		REMOVED HANGER 1-01A-403C-JH-1520
97521	1		INSTALLED HANGER 1-01A-403C-JH-1515
97521	1		INSTALLED HANGER 1-01A-403C-JH-1514
97521	1		INSTALLED HANGER 1-01A-403C-DE075
97521	1		MODIFIED HANGER 1-01A-0-403C-JH-1513
97521	1		INSTALLED HANGER 1-01A-403C-DE070

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFO-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
97521	1		INSTALLED HANGER 1-01A-403C-DE072
97521	1		MODIFIED HANGER 1-01A-0-403C-JH-1519
97521	1		MODIFIED HANGER 1-01A-403C-JH-1518
97521	1		MODIFIED HANGER 1-01A-0-403C-JH-1516A
97521	1		MODIFIED HANGER 1-01A-1-2-0-401A-H15
53576	1		REPOSITIONED HANGER 1-03-0-401B-EM0-H25
97521	1		MODIFIED HANGER 1-01A-1-3-0-401A-H16
97521	1		MODIFIED HANGER 1-01A-1-2-0-401A-H17
97521	1		INSTALLED HANGER 1-01A-1-4-0-401A-H19
97521	1		INSTALLED HANGER 1-01A-0-441-H42
97521	1		INSTALLED HANGER 1-01A-0-441-H43
97521	1		RESET SPRING CAN/HANGER 1-01A-1-1-0-401A-H7
97521	1		MODIFIED HANGER 1-01A-0-401A-EM0-H15
97521	1		INSTALLED HANGER 1-01A-1-1-0-401A-H8
97521	1		MODIFIED HANGER 1-01A-1-1-0-401A-H33
97521	1		REPLACED SPRING CAN HANGER 1-01A-1-1-0-401A-H34

REPAIRS AND REPLACEMENT LOG
UNIT 1, RFD-12
ASME SECTION XI - 1980
OCONEE NUCLEAR STATION

WORK REQUEST #	UNIT	ASME	DESCRIPTION
97521	1		MODIFIED HANGER 1-01A-1-1-0-401A-H9
97521	1		MODIFIED HANGER 1-01A-1-2-0-401A-H14
97521	1		MODIFIED HANGER 1-01A-1-2-0-401A-H48
97521	1		REPLACED HANGER 1-01A-1-2-0-401A-H13
97521	1		INSTALLED HANGER 1-01A-1-2-0-401A-H49
97521	1		MODIFIED HANGER 1-01A-1-1-0-401A-H35
97521	1		MODIFIED HANGER 1-01A-1-1-0-401A-H40
97521	1		REPLACED HANGER 1-01A-1-1-0-401A-H43