

VOLUME I - BOOK 9 (PART 4)  
TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

MODEL NOS. 1A & 1B

<u>SUBJECT</u>	<u>MULTIMODE RESPONSE MULTIPLIER - STUDIES</u>	<u>PAGE</u>
1. Introduction		1
2. Structural Models		5
2a. Properties		7
2b. Boundary Condition		8
2c. Tray Weight (Models 1-A/1-B)		9
2d. Models & Plots (Models 1-A/1-B)		11
3. Frequency Analysis		24
3a. Model 1-A. "2-D" & Syst Approx. Freq.		25
3b. Model 1-B. "2-D" & Syst Approx. Freq.		27
3c. Summary Table (Models 1-A/1-B)		31
4. Response Spectra & MRM for "g"		33
4a. Introduction		33
4b. MRM for RSS=6		36
4c. MRM for RSS=14, IRSSXI=1		37
4d. MRM for RSS=1		38
5. Reaction & MRM		42
5a. Missing Weight (Models 1-A/1-B)		45
5b. MRM for Reaction (Models 1-A/1-B)		58
5c. Summary Table		68
6. Time History Vs Response Spectra Approach		69
6a. 2-D Accl. Level for Best Estimate Eq		71
6b. Dynamic Responses (Models 1-A/1-B)		72
6c. MRM for Time History Approach (Models 1-A/1-B)		88
6d. Summary Table for MRM		100
7. Conclusion		101

GENERAL TABLE OF CONTENTS  
VOLUME I - BOOKS

VOLUME I - BOOK 1  
TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK UNITNO. 1 & 2  
TABLE OF CONTENTS

<u>SUBJECT</u>	<u>GENERAL INPUT DATA</u> (12/20/85) R3	<u>SECTION</u>
Organization of Documents in volume I & II (LATER) Design Criteria		i - viii
1. Seismic Design Criteria for Cable Tray Hangers for Comanche Peak Steam Electric Station No. 2	Rev <u>4</u> Date <u>12/04/85</u>	I
2. Design and Analysis Procedure of Seismic Category I Electrical Conduit System	Rev <u>4</u> Date <u>12/11/85</u>	
3. General Instructions for Cable Tray Hanger Analysis for Comanche Peak Steam Electrical Station No. 1 and No. 2	Rev <u>2</u> Date <u>12/20/85</u>	
4. Seismic Design Criteria for Cable Tray Hangers for Comanche Peak Steam Electric Station No. 1	Rev <u>1</u> Date <u>12/20/85</u>	
General Notes		II
Refined Response Spectra Curves		III
1. Refined Response Spectra Curves for Safeguards Bldg., FSB-5R, November, 1982 (GTN-62339 dated November 16, 1982)		
2. Refined Response Spectra for Containment Bldg., FRB-7R, December, 1982 (GTN-63341, dated January 18, 1983)		
3. Refined Response Spectra Curves for 4% OBE and 7% SSE of Cat. 1 Bldg. Floor (GTN-69817, dated February 8, 1985)		
4. Refined Response Spectra Curves for Fuel Building, 4% OBE and 7% SSE (GTN-70739, dated October 17, 1985)		

VOLUME I - BOOK 2  
TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

<u>SUBJECT</u>	<u>COMPUTER RELATED INFORMATION</u>	<u>SECTION</u>
P Delta Strudl Program Usage		I
1. Instruction for Ebasco IBM PC workstation		
2. P-Delta Strudl example problem No. 1 "Frequency Analysis" (later)		
3. P-Delta Strudl example problem No. 2 "Static Analysis" (later)		
4. P-Delta Strudl example problem No. 3 "Base Plate Analysis" (later)		
5. PD Strudl (frequency & static and base plate) data input forms (Base Plate later)		
6. Beta angle guide for PSDI-Strudl		
7. Input of modchano into computer		
8. Calculation of equivalent density including thermolag		
9. AISC Code checking verification of P-Delta Strudl Program (later)		
10. P-Delta Strudl/Nastran Result Comparison (later)		

VOLUME I - BOOK 2A  
 TEXAS UTILITIES GENERATING COMPANY  
 COMMANCHE PEAK UNIT NO. 2  
TABLE OF CONTENTS

<u>SUBJECT</u>	<u>COMPUTER RELATED INFORMATION</u>	<u>SECTION</u>
Member Property Tables Included In The STRUDL Subsystem		See Appendix D of PSDI STRUDL Manual

Table

1	Table STEELW (Wide Flange Shapes - 1969 AISC)	D-26
2	Table STEELWF (Wide Flange Shapes - 1963 AISC)	D-27
3	Table W1978 (Wide Flange Shapes - 1979 AISC)	D-28
4	Table STEEL-HM	*
⑤	Table STEEL-IIN	*
⑥	Table STEEL-IHW	*
7	Table STEELM (Miscellaneous Wide Flange Shapes)	D-29
8	Table STEELS (S Shapes -- I Beam 1969 AISC)	D-30
9	Table STLCOL78 (Wide Flange Column Shapes-1978 AISC)	D-31
10	Table STLS78(S Shapes - I Beam 1978 AISC)	D-32
11	Table STEELHP	*
12	Table STLHP78 HP Shapes (Piles - 1978 AISC)	D-33
13	Table STEELL (Structural Angles)	D-34
14	Table IEANGLES (Single Angle with Equal Legs)	D-35
15	Table IANGLES (Single Angle with Unequal Legs)	D-36
16	Table 2EANGLES (Double Angle with Equal Legs)	D-37
17	Table 2SANGLES (Double Angle with Short Legs Back-to-Back)	D-38
18	Table 2LANGLES (Double Angle with Long Legs Back-to Back)	D-39
19	Table STEELC (American Standard Channel Shapes)	D-40
20	Table STEELMC (Miscellaneous Channel Shapes)	D-41
21	Table STEELWFC	*
22	Table STEELMT	*
23	Table STEELST (Tees Cut from S Shapes - I Beam)	D-42

VOLUME I - BOOK 2A  
 TEXAS UTILITIES GENERATING COMPANY  
 COMMANCHE PEAK UNIT NO. 2  
TABLE OF CONTENTS

<u>SUBJECT</u>	<u>COMPUTER RELATED INFORMATION</u>	<u>SECTION</u>
Member Property Tables Included In The STRUDL Subsystem		See Appendix D of PSDI STRUDL Manual

Table

24	Table STEELWT (Tees Cut from Wide Flange Shapes)	D-43
25	Table STLMT78	*
26	Table STLST78	*
27	Table STLWT78 (Tees Cut from Wide Flange Shapes - 1978 AISC)	D-44
28	Table APISLX (American Petroleum Institute 5LX Plain End Line Pipe 18 - 42 IN.OD)	D-45
②9	Table AISCPIPE (Pipe Profiles)	D-46
30	Table CIRCTUBE	*
③1	Table TUBRECT (Rectangular Structural Tubing)	D-47
32	Table RECTUBE	*
③3	Table TUBESQR (Square Structural Tubing)	D-48
34	Table SQT8	*
35	Table HOLOTUBE	*
③6	Available Weld Properties Tables	D-49
③7	Available Tables for AIJ and DINS Codes	D-50
38	Table TUBES - Tubes (Rectangular and Square - Depth 2" to 12")	**
39	Table ANGLES - Single and Double Structural Angles (for STRUDL TOWER Application)	**
40	Table STLW78 - Wide Flange Shapes (September 1978)	**
41	Table MODCHAND - Tube Shape * This section to be provided at a later time.	
	** From MCAUTO	

○ Tables not included in this BOOK 2A.

## EBASCO SERVICES INCORPORATED

BY S. P. Lu DATE 6/28/85SHEET 1 OF 2CHKD. BY JTLTA DATE 6/28/85OFS NO. 3317.002 DEPT. NO. 549CLIENT TEXAS UTILITIES GENERATING CO.PROJECT COMANCHE PEAK UNIT 2CABLE TRAY HANGERSSUBJECT PRYING ACTION FACTORS & FORMULAS FOR EVALUATING ANCHOR BOLTSTABLE OF CONTENTSSECTION I - GENERAL

PAGE

(a) DESCRIPTION OF PROBLEM	1
(b) INVESTIGATION PURPOSE	2
(c) INVESTIGATION PROCEDURE	3
(d) ANALYSIS METHOD AND COMPUTER PROGRAM	6
(e) SPRING CONSTANTS OF R.C SUBGRADE AND ANCHOR BOLTS	7
(f) BASE ANGLES AND PLATES	12
(g) PRYING ACTION FACTORS AND HAND CALCULATION FORMULAS	15
(h) REFERENCES	19
(i) LIST OF COMPUTER OUTPUT	20

SECTION II - SUMMARY

(a) SUMMARY OF RESULTS	1
------------------------	---

BY S. P. Lu DATE 6/28/85

SHEET 2 OF 2

CHKD. BY JTLA DATE 6/28/85

DPS NO. 3317.002 DEPT. NO. 549

CLIENT TEXAS UTILITIES GENERATING CO.

COMANCHE PEAK UNIT 2

PROJECT CABLE TRAY HANGERS

SUBJECT PRying ACTION FACTORS & FORMULAS FOR EVALUATING ANCHOR BOLTS

SECTION III — CORRESPONDENCE IN/INPUT DATA

- (a) ANCHOR BOLT SHEAR AND TENSION STIFFNESS
- (b) TEST REPORT ON SHEAR AND TENSION LOADING OF RICHMOND INSERTS

SECTION IV — CALCULATIONS

- (a) DESCRIPTION OF FINITE ELEMENT MODEL 1
- (b) ANSYS FINITE ELEMENT MODELS 4
- (c) ANALYSIS INPUT 6
- (d) ANALYSIS OUTPUT 10
- (e) EVALUATION OF OUTPUT 33
- (f) VERIFICATION OF PRying ACTION FACTORS 41
- (g) PRying ACTION FACTORS FOR APPLICATION 44



VOLUME I - BOOKS 3A thru 3J  
 EBASCO SERVICES INCORPORATED

BY JTL/TM DATE 7/2/85 SHEET 1 OF 1  
 CHKD. BY JW DATE 7/2/85 TEXAS UTILITIES GENERATING CO. OFS NO. 3317.002 DEPT. NO. 549  
 CLIENT COMANCHE PEAK UNIT 2  
 PROJECT CADLE TRAY HANGERS  
 SUBJECT PRYING ACTION FACTORS & FORMULAS FOR EVALUATING ANCHOR BOLTS

VOLUME I -  
CALCULATION BOOKS 3A, 3B, 3C, 3D, 3E, 3F, 3G, 3H, 3I & 3J

BOOK NO.	CONTENTS
VOL. I - BOOK 3	CALCULATION BOOK FOR "PRYING ACTION FACTORS & FORMULAS FOR EVALUATING ANCHOR BOLTS"
-BOOK 3A	COMPUTER PRINTOUTS FOR BASE ANGLE ANAL - L 8x6x <sup>3</sup> / <sub>4</sub> & L 6x6x <sup>3</sup> / <sub>4</sub> W/2 BOLTS
-BOOK 3B	COMPUTER PRINTOUTS FOR BASE ANGLE ANAL - L 6x6x <sup>3</sup> / <sub>4</sub> W/2 BOLTS
-BOOK 3C	COMPUTER PRINTOUTS FOR BASE ANGLE ANAL - L 6x6x <sup>3</sup> / <sub>4</sub> W/2 BOLTS
-BOOK 3D	COMPUTER PRINTOUTS FOR BASE ANGLE ANAL - L 8x6x <sup>3</sup> / <sub>4</sub> & L 6x6x <sup>3</sup> / <sub>4</sub> W/1 BOLT
-BOOK 3E	COMPUTER PRINTOUTS FOR BASE ANGLE ANAL - L 8x6x <sup>3</sup> / <sub>4</sub> & L 6x6x <sup>3</sup> / <sub>4</sub> W/1 BOLT
-BOOK 3F	COMPUTER PRINTOUTS FOR BASE PLATE ANAL - P 1x24x24 W/4 BOLTS
-BOOK 3G	COMPUTER PRINTOUTS FOR BASE PLATE ANAL - P 1x24x24 W/4 BOLTS
-BOOK 3H	COMPUTER PRINTOUTS FOR BASE PLATE ANAL - P 1/2x6x2'-4 W/2 BOLTS
-BOOK 3I	COMPUTER PRINTOUTS FOR BASE ANGLE ANAL - L 8x6x <sup>3</sup> / <sub>4</sub> & L 6x6x <sup>3</sup> / <sub>4</sub> W/2 BOLTS
-BOOK 3J	COMPUTER PRINTOUTS FOR BASE PLATE ANAL - P 1x14x14, P 1x24x24 W/4 BOLTS; P 1/2x6x2'-4 W/2 BOLTS

VOLUME I - BOOK 4  
 TEXAS UTILITIES GENERATING COMPANY  
 COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

CABLE TRAY HANGER GEOMETRY GROUPING - (12/20/85)

R2

- I Cable Tray Hanger Geometry Classification Code
- II Procedure for Grouping Cable Tray Hangers
- III Groups

<u>Geometry Code</u>	<u>Volume I Book</u>	<u>Group Numbers</u>
U1	4	U1-1, U1-2, U1-3, U1-4, U1-5, U1-6, U1-7, U1-8, U1-9, U1-10, U1-11, U1-12, U1-13, U1-14, U1-15, U1-16, U1-17, U1-18, U1-19, U1-20, U1-21, U1-22, U1-23
U1T1	4	U1T1-1, U1T1-2, U1T1-3, U1T1-4, U1T1-5, U1T1-6, U1T1-7, U1T1-8, U1T1-9, U1T1-10, U1T1-11
U1T2	4	U1T2-1
U1B1	4	U1B1-1, U1B1-2, U1B1-3, U1B1-4, U1B1-5, U1B1-6, U1B1-7, U1B1-8, U1B1-9, U1B1-10
U1B2	4	U1B2-1, U1B2-2, U1B2-3
U1B3	4	U1B3-1, U1B3-2
U1T1B1	4	U1T1B1-1, U1T1B1-2
U2	4	U2-1, U2-2, U2-3, U2-4, U2-5, U2-6, U2-7, U2-8, U2-9, U2-10
U2T1	4	U2T1-1, U2T1-2, U2T1-3, U2T1-4 U2T1-5, U2T1-6, U2T1-7, U2T1-8
U2T2	4	U2T2-1, U2T2-2
U2B1	4	U2B1-1, U2B1-2, U2B1-3, U2B1-4, U2B1-5, U2B1-7, U2B1-8, U2B1-9, U2B1-10, U2B1-11, U2B1-12, U2B1-13, U2B1-14, U2B1-15, U2B1-16

VOLUME I - BOOK 4A  
 TEXAS UTILITIES GENERATING COMPANY  
 COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

CABLE TRAY HANGER GEOMETRY GROUPING - (12/20/85)

R2

III Groups

<u>Geometry Code</u>	<u>Volume I Book</u>	<u>Group Numbers</u>
U2B2	4A	U2B2-1, U2B2-2, U2B2-3, U2B2-4, U2B2-5, U2B2-6, U2B2-7, U2B2-8, U2B2-9, U2B2-10, U2B2-11, U2B-12, U2B2-13, U2B2-14
U2B3	4A	U2B3-1, U2B3-2
U2T1B1	4A	U2T1B1-1
U2T2B1	4A	U2T2B1-1
U3	4A	U3-1, U3-2, U3-3
U3B1	4A	U3B1-1, U3B1-2, U3B1-3, U3B1-4, U3B1-5, U3B1-6
U3B2	4A	U3B2-1
U3T1B1	4A	U3T1B1-1, U3T1B1-2
U4B1	4A	U4B1-1, U4B1-2, U4B1-3
U4B2	4A	U4B2-1, U2B2-2
U4B3	4A	U4B3-1
U5B2	4A	U5B2-1

VOLUME I - BOOK 4B  
 TEXAS UTILITIES GENERATING COMPANY  
 COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

CABLE TRAY HANGER GEOMETRY GROUPING - (12/20/85)

R2

III Groups

<u>Geometry Code</u>	<u>Volume I Book</u>	<u>Group Numbers</u>
UW	4B	UW-1, UW-2, UW-3, UW-4, UW-5, UW-6, UW-7, UW-8, UW-9, UW-10, UW-11, UW-12, UW-13, UW-14, UW-15
UBW	4B	UBW-1, UBW-2, UBW-3, UBW-4, UBW-5, UBW-6, UBW-7, UBW-8, UBW-9, UBW-10, UBW-11, UBW-12, UBW-13, UBW-15, UBW-17, UBW-18, UBW-19, UBW-20, UBW-21
U2W	4B	U2W-1
SPEC	4B	SP-1, SP-2, SP-3, SP-4, SP-5, SP-6, SP-7, SP-8, SP-9, SP-10 SP-11, SP-12, SP-13, SP-14, SP-15, SP-16
L3W	4B	LW3-1, LW3-2
U1Z2B1	4B	U1Z2B1-1
U1BL	4B	U1BL-1, U1BL-2

IV Memos to Design

VOLUME I - BOOK 4C  
TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

CABLE TRAY HANGER GEOMETRY GROUPING - (12/20/85)

R2

V Additional Groups

<u>Geometry Code</u>	<u>Volume I Book</u>	<u>Group Numbers</u>
CANT	4C	CANT-1, CANT-3, CANT-4, CANT-5 CANT-6, CANT-7, CANT-8, CANT-9 CANT-10, CANT-11, CANT-12, CANT-13, CANT-14, CANT-15, CANT-16, CANT-17, CANT-18, CANT-19, CANT-20, CANT-21, CANT-22, CANT-23, CANT-24, CANT-25, CANT-26, CANT-27, CANT-28, CANT-29, CANT-30, CANT-31, CANT-32, CANT-33, CANT-34, CANT-35, CANT-36, CANT-37, CANT-38, CANT-39, CANT-40, CANT-41, CANT-42, CANT-43, CANT-44, CANT-45, CANT-46, CANT-47, CANT-48, CANT-49, CANT-50, CANT-51, CANT-52, CANT-53, CANT-54, CANT-55, CANT-57, CANT-59, CANT-60, CANT-61, CANT-62, CANT-66, CANT-67, CANT-68, CANT-69, CANT-70, CANT-73, CANT-75, CANT-76, CANT-77, CANT-78, CANT-79, CANT-80, CANT-81, CANT-82, CANT-83, CANT-84, CANT-85, CANT-86, CANT-87, CANT-88, CANT-89, CANT-90, CANT-91, CANT-92

VOLUME I - BOOK 4D  
TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

CABLE TRAY HANGER GEOMETRY GROUPING - (12/20/85)

R2

V Additional Groups

<u>Geometry Code</u>	<u>Volume I Book</u>	<u>Group Numbers</u>
BEAM	4D	BEAM-1, BEAM-2, BEAM-3, BEAM-4 BEAM-5, BEAM-6, BEAM-7, BEAM-8 BEAM-9, BEAM-10, BEAM-11, BEAM-12,
WALL	4D	WALL-1, WALL-2, WALL-3, WALL-4 WALL-5, WALL-6, WALL-7, WALL-8 WALL-9, WALL-10
L	4D	L-1, L-2, L-3, L-4, L-5, L-6, L-7, L-8, L-9, L-10, L-11, L-12, L-13, L-14, L-15, L-16, L-17, L-18, L-19 L-20, L-21, L-22
L2	4D	L2-1, L2-2, L2-3, L2-4, L2-5
LW	4D	LW-1, LW-2, LW-3
L2W	4D	LW2-2, LW2-3, LW2-4

VOLUME I - BOOK 4E  
TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

CABLE TRAY HANGER GEOMETRY GROUPING - (12/20/85)

R2

V Additional Groups

<u>Geometry Code</u>	<u>Volume I Book</u>	<u>Group Numbers</u>
TRIA	4E	TRIA-1, TRIA-2, TRIA-3, TRIA-4 TRIA-5, TRIA-6, TRIA-7, TRIA-8 TRIA-9, TRIA-10, TRIA-11, TRIA-12, TRIA-13, TRIA-14, TRIA-15, TRIA-16, TRIA-17, TRIA-18, TRIA-19, TRIA-20, TRIA-21, TRIA-22, TRIA-23, TRIA-24, TRIA-25, TRIA-26, TRIA-27, TRIA-28, TRIA-29, TRIA-30, TRIA-31, TRIA-32, TRIA-33, TRIA-34, TRIA-35, TRIA-36, TRIA-37, TRIA-40, TRIA-41, TRIA-43,
U1L	4E	U1L-1, U1L-2
U1B1BL	4E	U1B1BL-1
U1T1BL	4E	U1T1BL-1
U2L	4E	U2L-1
U2T1BL	4E	U2T1BL-1
U2Z1	4E	U2Z1-1

VOLUME I - BOOK 5  
TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK UNIT NO. 2  
TABLE OF CONTENTS

<u>SUBJECT</u>	<u>TORSION AND RELATED STUDIES</u>	<u>SECTION</u>
Composite Channel Shear Center		I
Warping Stresses for Single Channels		II
Warping Stresses for Composite Channels		III



VOLUME I - BOOK 6  
TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

<u>SUBJECT</u>	<u>BUCKLING STUDY</u>	<u>PAGE</u>
1. Introduction		3
2. References		5
3. Conclusions		6
4. Methodology		8
5. Summary of Results		12
6. Calculations		14
7. Computer Run Summary		43

VOLUME I - BOOK 6A  
 TEXAS UTILITIES GENERATING COMPANY  
 COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

BUCKLING STUDY COMPUTER PRINTOUT

RUN No.	DATE	CTH DESCRIPTION				LOADING	COMMENTS
		TRAPEZEE TYPE	LENGTH, FT.	WIDTH, FT.			
DOLSCZJ	6/11/85	U1	5.0	3.0	I-OBE		
DOLTA67	6/12/85				II-OBE		
DOLTBBZ	6/12/85				I-SSE		
DOLTCVR	6/12/85		5.0		II-SSE		
DOLVABY	6/27/85		5.5		I		
DOLUBON	6/27/85			3.0	II		
DOL3B7Z	6/7/85			4.0	I		
DOL3C5F	6/7/85				II		
DOLRDXZ	6/11/85				II		
DOLRCKR	6/10/85	U1	5.5	4.0	II	LOAD RATIO EFFECT "	
DOLUCC3	6/13/85	U2	5.0	3.0	I-OBE		
DOLUCQ7	6/13/85		5.0		II-OBE		
DOLRDA3	6/24/85		6.2		I-OBE		
DOLSAQV	6/25/85			3.0	II-OBE		
DOLRDEB	6/24/85			4.0	I-OBE		
DOLRDOB	6/24/85	U2	6.2	4.0	II-OBE		
DOL2L4B	6/20/85	U1Z1	5.0	3.0	I-SSE		
DOL2DJZ	6/20/85				II-SSE		
DOLZCEV	6/17/85				I-OBE		
DOLZC9F	6/17/85				II-OBE		
DOLZCIF	6/17/85	U1Z1	5.0		I-OBE		
DOLSCFF	6/25/85	U1B1	6.2		I-OBE		
DOLTA3V	6/26/85			3.0	II-OBE		
DOLSCFV	6/25/85			4.0	I-OBE		
DOLSDIJ	6/25/85	U1B1			II-OBE		
DOLTCZZ	6/26/85	U2B1			I-OBE		
DOLTDPR	6/26/85	U2B1	6.2	4.0	II-OBE		

VOLUME I - BOOK 7  
TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

CABLE TRAY HANGER LOAD LOCATION STUDIES

	<u>SUBJECT</u>	<u>PAGE</u>
1.0	Introduction	3
2.0	References	4
3.0	Conclusions	
3.1	Vertical Load Study	5
3.2	Longitudinal Load Study	5
4.0	Calculations	
4.1	Vertical Load Study	6
4.2	Longitudinal Load Study	13

VOLUME I - BOOK 8  
TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK UNIT NO. 1

TABLE OF CONTENTS

CABLE TRAY HANGER GEOMETRY GROUPING

- I Cable Tray Hanger Geometry Classification Code
- II Procedure for Grouping Cable Tray Hangers
- III Groups

<u>Geometry Code</u>	<u>Volume I Book</u>	<u>Group Numbers</u>
BEAM	8	BEAM-300
CANT	8	CANT-300, CANT-301, CANT-302, CANT-303, CANT-304, CANT-305, CANT-306, CANT-307, CANT-308, CANT-309, CANT-310, CANT-311, CANT-313, CANT-314, CANT-315, CANT-316, CANT-317, CANT-318, CANT-319, CANT-320, CANT-321, CANT-322, CANT-323, CANT-324, CANT-325, CANT-326, CANT-327, CANT-328, CANT-329, CANT-330

VOLUME I - BOOK 8A  
TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK UNIT NO. 1

TABLE OF CONTENTS

CABLE TRAY HANGER GEOMETRY GROUPING

III Groups

<u>Geometry Code</u>	<u>Volume I Book</u>	<u>Group Numbers</u>
L	8A	L-300, L-301, L-302, L-304, L-305, L-306, L-307, L-308, L-309
SPEC	8A	SPEC-300, SPEC-301, SPEC-302, SPEC-303, SPEC-304
TRIA	8A	TRIA-300, TRIA-301, TRIA-302, TRIA-303, TRIA-304, TRIA-305
U1	8A	U1-300, U1-301, U1-302, U1-303, U1-304, U1-305, U1-306, U1-307, U1-308, U1-309, U1-310, U1-311, U1-312, U1-313, U1-314

VOLUME I - BOOK 8B  
TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK UNIT NO. 1

TABLE OF CONTENTS

CABLE TRAY HANGER GEOMETRY GROUPING

III Groups

<u>Geometry Code</u>	<u>Volume I Book</u>	<u>Group Numbers</u>
ULB1	8B	ULB1-300, ULB1-301, ULB1-302
ULB2	8B	ULB2-300
ULT1	8B	ULT1-300, ULT1-301, ULT1-302, ULT1-303, ULT1-304
ULZ1B2	8B	ULZ1B2-300
U2	8B	U2-300, U2-301, U2-302
U2B1	8B	U2B1-300
U2T1	8B	U2T1-300, U2T1-301
U2T1B1	8B	U2T1B1-300, U2T1B1-301
U3	8B	U3-300, U3-301, U3-302
U3B2	8B	U3B2-300, U3B2-301
U3B3	8B	U3B3-300
U3Z1B1	8B	U3Z1B1-300

VOLUME I - BOOK 8C  
TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK UNIT NO. 1

TABLE OF CONTENTS

CABLE TRAY HANGER GEOMETRY GROUPING

III Groups

<u>Geometry Code</u>	<u>Volume I Book</u>	<u>Group Numbers</u>
UW	8C	UW-300, UW-301
WALL	8C	WALL-300, WALL-301
Z1	8C	Z1-300

VOLUME I - BOOK  
TEXAS UTILITIES GENERATL.  
COMANCHE PEAK UNIT NO.

TABLE OF CONTENTS

CABLE TRAY HANGER GEOMETRY GROUPING

IV Memos to Design



VOLUME I - BOOK 9  
TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

MODEL NOS. 1, 2, & 3

<u>SUBJECT</u>	<u>MULTIMODE RESPONSE MULTIPLIER - SUMMARY REPORT 3-D RESPONSE SPECTRUM ANALYSIS AND VERIFICATION OF A MULTIMODE RESPONSE MULTIPLIER EQUAL TO 1.25</u>	<u>PAGE</u>
I.	INTRODUCTION	1
II.	THE SELECTION OF 3-D STUDY MODELS	3
III.	STUDY CONCLUSION	11
IV.	STUDY SUMMARY	
	1.0 Modelling Assumptions	14
	2.0 Seismic Input Requirements	15
	3.0 Analysis Approach	16
	4.0 Study Results	18
	5.0 Discussions	22

VOLUME I - BOOK 9 (PART 1)  
TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

MODEL NOS. 1 & 2

<u>SUBJECT</u>	<u>MULTIMODE RESPONSE MULTIPLIER - STUDIES</u>	<u>PAGE</u>
1. Summary of Results		1
2. Structural Drawings and Finite Element Model		7
2a. Model #1		8
2b. Model #2		20
3. Response Spectra Input		31
4. Boundary Conditions		58
5. Frequency Results		60
5a. Model #1		61
5b. Model #2		65
6. MRM Results		69
6a. Model #1		70
6b. Model #2		131
7. Summary Tables		192

VOLUME I - BOOK 9 (PART 2)  
TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

MODEL NOS. 1 & 2

<u>SUBJECT</u>	<u>MULTIMODE RESPONSE MULTIPLIER - STUDIES</u>	<u>PAGE</u>
1. Introduction		1
2. Spring Constants		2
2a Model No. 1		3
2b Model No. 2		13
3. Response Spectra Input		27
4. Boundary Conditions		28
5. Frequency Results		29
5a Model No. 1		30
5b Model No. 2		34
6. MRM Results		38
6a Model No. 1		39
6b Model No. 2		101
7. Summary		104

VOLUME I - BOOK 9 (PART 3)  
TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

MODEL NOS. 1 & 2

<u>SUBJECT</u>	<u>MULTIMODE RESPONSE MULTIPLIER - STUDIES</u>	<u>PAGE</u>
1.	Introduction	1
2.	Earthquake Input	2
2a.	Time History Plots	3
2b.	Response Spectra Plots & Values	8
3.	Time History Approach vs Response Spectra Approach	15
3a.	Model #1 Fixed End Boundary	16
3b.	Model #1 Spring Boundary	23
3c.	Model #2 Fixed End Boundary	30
3d.	Model #2 Spring Boundary	37
4.	MRM Computation	44
4a.	Fixed Boundary Models 1 & 2 R.S.	45
4b.	Fixed Boundary Models 1 & 2 T.H.	52
4c.	Spring Boundary Models 1 & 2 R.S.	65
4d.	Spring Boundary Models 1 & 2 T.H.	74
5.	Summary of MRM	87

VOLUME I - BOOK 9 (PART 4)  
TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

MODEL NOS. 1A & 1B

<u>SUBJECT</u>	<u>MULTIMODE RESPONSE MULTIPLIER - STUDIES</u>	<u>PAGE</u>
1. Introduction		1
2. Structural Models		5
2a. Properties		7
2b. Boundary Condition		8
2c. Tray Weight (Models 1-A/1-B)		9
2d. Models & Plots (Models 1-A/1-B)		11
3. Frequency Analysis		24
3a. Model 1-A. "2-D" & Syst Approx. Freq.		25
3b. Model 1-B. "2-D" & Syst Approx. Freq.		27
3c. Summary Table (Models 1-A/1-B)		31
4. Response Spectra & MRM for "g"		33
4a. Introduction		33
4b. MRM for RSS=6		36
4c. MRM for RSS=14, IRSSXI=1		37
4d. MRM for RSS=1		38
5. Reaction & MRM		42
5a. Missing Weight (Models 1-A/1-B)		45
5b. MRM for Reaction (Models 1-A/1-B)		58
5c. Summary Table		68
6. Time History Vs Response Spectra Approach		69
6a. 2-D Accl. Level for Best Estimate Eq		71
6b. Dynamic Responses (Models 1-A/1-B)		72
6c. MRM for Time History Approach (Models 1-A/1-B)		88
6d. Summary Table for MRM		100
7. Conclusion		101

VOLUME I - BOOK 9A  
 TEXAS UTILITIES GENERATING COMPANY  
 COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

Multimode response multiplier study - computer runs for base angle flexibility and seismic analysis of Model No. 1

COMPUTER RUN ID.	DATE OF RUN	TITLE
DOLVCNR	8/16/85	BASEANGLE FLEXIBILITY ANALYSIS FOR MODEL 1
DOLVCNZ	8/16/85	BASEANGLE FLEXIBILITY ANALYSIS FOR MODEL 1
DOLVCN7	8/16/85	BASEANGLE FLEXIBILITY ANALYSIS FOR MODEL 1
DOLVCOJ	8/16/85	BASEANGLE FLEXIBILITY ANALYSIS FOR MODEL 1
DOLVCQZ	8/16/85	BASEANGLE FLEXIBILITY ANALYSIS FOR MODEL 1
DOLVC07	8/16/85	BASEANGLE FLEXIBILITY ANALYSIS FOR MODEL 1
DOLVBK3	8/16/85	BASEANGLE FLEXIBILITY ANALYSIS FOR MODEL 1
DOLVCL7	8/16/85	BASEANGLE FLEXIBILITY ANALYSIS FOR MODEL 1
DOLVCMJ	8/16/85	BASEANGLE FLEXIBILITY ANALYSIS FOR MODEL 1
DOLVCMV	8/16/85	BASEANGLE FLEXIBILITY ANALYSIS FOR MODEL 1
DOLVCM3	8/16/85	BASEANGLE FLEXIBILITY ANALYSIS FOR MODEL 1
DOLVCNJ	8/16/85	BASEANGLE FLEXIBILITY ANALYSIS FOR MODEL 1
DOLWA03	8/17/85	BASEANGLE FLEXIBILITY ANALYSIS FOR MODEL 1
DOLWAPF	8/17/85	BASEANGLE FLEXIBILITY ANALYSIS FOR MODEL 1
DOLWAPN	8/17/85	BASEANGLE FLEXIBILITY ANALYSIS FOR MODEL 1
DOLWAPZ	8/17/85	BASEANGLE FLEXIBILITY ANALYSIS FOR MODEL 1
DOLWAP7	8/17/85	BASEANGLE FLEXIBILITY ANALYSIS FOR MODEL 1
DOLWAQF	8/17/85	BASEANGLE FLEXIBILITY ANALYSIS FOR MODEL 1
DOLZAZJ	8/14/85	BASEANGLE STIFFNESS MATRIX.
DOLVDD7	8/31/85	SYSTEM FREQUENCIES, MODEL 1 FIXED BASE
DOLTC4Z	9/10/85	HANGER FREQUENCIES, MODEL 1 FIXED BASE
DOLRDE7	8/28/85	SYSTEM FREQUENCIES, MODEL 1 SPRING BASE
DOLTECJ	8/28/86	HANGER FREQUENCIES, MODEL 1 SPRING BASE
DOLRBNJ	9/16/86	HANGER FREQUENCIES, MODEL 1 HINGED BASE
DOLSCGZ	8/27/86	SP 7 FREQUENCIES, MODEL 1 FIXED BASE
DOLTC3V	9/11/86	SP 7 FREQUENCIES, MODEL 1 SPRING BASE
DOLTBCN	8/28/86	SP 7 FREQUENCIES, MODEL 1 HINGED BASE

TABLE OF CONTENTS

Multimode response multiplier study - computer runs for seismic analysis of Model No. 1 for fixed base

COMPUTER RUN ID.	DATE OF RUN	TITLE	9B-1
DOLWATJ	8/31/85	MODEL 1 FIXED BASE INTERNAL BLDG. OBE 4%	RSS = 6
DOLWA3Z	9/14/85	MODEL 1 FIXED BASE INTERNAL BLDG. OBE 4%	RSS = 1
DOLTBKZ	9/11/85	MODEL 1 FIXED BASE INTERNAL BLDG. SSE 7%	RSS = 6
DOLWA4V	9/14/85	MODEL 1 FIXED BASE INTERNAL BLDG. SSE 7%	RSS = 1
DOLSD3J	9/10/85	MODEL 1 FIXED BASE R/B BLDG. OBE 4%	RSS = 6
DOLWA4N	9/14/85	MODEL 1 FIXED BASE R/B BLDG. OBE 4%	RSS = 1
DOLSDKB	9/10/85	MODEL 1 FIXED BASE R/B BLDG. SSE 7%	RSS = 6
DOLWA47	9/14/85	MODEL 1 FIXED BASE R/B BLDG. SSE 7%	RSS = 1
DOLTAYV	9/11/85	MODEL 1 FIXED BASE AUXI. BLDG. OBE 4%	RSS = 6
DOLWA53	9/14/85	MODEL 1 FIXED BASE AUXI. BLDG. OBE 4%	RSS = 1
DOLSDKV	9/10/85	MODEL 1 FIXED BASE AUXI. BLDG. SSE 7%	RSS = 6
DOLWA5F	9/14/85	MODEL 1 FIXED BASE AUXI. BLDG. SSE 7%	RSS = 1
DOLSD07	9/10/85	MODEL 1 FIXED BASE ELEC. BLDG. OBE 4%	RSS = 6
DOLWAXB	9/14/85	MODEL 1 FIXED BASE ELEC. BLDG. OBE 4%	RSS = 1
DOLSA37	9/10/85	MODEL 1 FIXED BASE ELEC. BLDG. OBE 4%	RSS = 6
DOLVB7R	9/13/85	MODEL 1 FIXED BASE ELEC. BLDG. SSE 7%	RSS = 1
DOLSDPB	9/10/85	MODEL 1 FIXED BASE SAFEG. BLDG. OBE 4%	RSS = 6
DOLWA4Z	9/14/85	MODEL 1 FIXED BASE SAFEG. BLDG. OBE 4%	RSS = 1
DOLSD03	9/10/85	MODEL 1 FIXED BASE SAFEG. BLDG. SSE 7%	RSS = 6
DOLWA5V	9/14/85	MODEL 1 FIXED BASE SAFEG. BLDG. SSE 7%	RSS = 1
DOLVAZZ	9/20/85	MODEL 1 SPRING BASE REACT. BLDG. OBE 4%	RSS = 1
DOLVCDZ	9/20/85	MODEL 1 SPRING BASE REACT. BLDG. SSE 7%	RSS = 1
DOLUASR	9/19/85	MODEL 1 SPRING BASE REACT. BLDG. OBE 4%	RSS = 1
DOLVAZ3	9/20/85	MODEL 1 SPRING BASE REACT. BLDG. SSE 7%	RSS = 1
DOLVA0N	9/20/85	MODEL 1 SPRING BASE AUXI. BLDG. OBE 4%	RSS = 1
DOLVA07	9/20/85	MODEL 1 SPRING BASE AUXI. BLDG. SSE 7%	RSS = 1
DOLVA1N	9/20/85	MODEL 1 SPRING BASE ELEC. BLDG. OBE 4%	RSS = 1





TABLE OF CONTENTS

Multimode response multiplier study - computer runs for base angle flexibility and seismic analysis of Model No. 2

COMPUTER RUN ID.	DATE OF RUN	TITLE	
DOL 2C8N	9/5/85	MODEL 2 SPRING BASE, BASE ANGLE FLEXIBILITY	$F_x=1.0^k$
DOL 2D1B	9/6/85	MODEL 2 SPRING BASE, BASE ANGLE FLEXIBILITY	$F_y=1.0^k$
DOL 2D1V	9/6/85	MODEL 2 SPRING BASE, BASE ANGLE FLEXIBILITY	$F_z=1.0^k$
DOL 2D13	9/6/85	MODEL 2 SPRING BASE, BASE ANGLE FLEXIBILITY	$M_x=1.0^k$
DOL 2D2V	9/6/85	MODEL 2 SPRING BASE, BASE ANGLE FLEXIBILITY	$M_y=1.0^k$
DOL 2D3F	9/6/85	MODEL 2 SPRING BASE, BASE ANGLE FLEXIBILITY	$M_z=1.0^k$
DOL 2DXB	9/6/85	MODEL 2 SPRING BASE, BASE ANGLE FLEXIBILITY	$F_x=1.0^k$
DOL 2DYB	9/6/85	MODEL 2 SPRING BASE, BASE ANGLE FLEXIBILITY	$F_y=1.0^k$
DOL 2D2N	9/6/85	MODEL 2 SPRING BASE, BASE ANGLE FLEXIBILITY	$F_z=1.0^k$
DOL 2D27	9/6/85	MODEL 2 SPRING BASE, BASE ANGLE FLEXIBILITY	$M_x=1.0^k$
DOL 2D0N	9/6/85	MODEL 2 SPRING BASE, BASE ANGLE FLEXIBILITY	$M_y=1.0^k$
DOL 2DV3	9/6/85	MODEL 2 SPRING BASE, BASE ANGLE FLEXIBILITY	$M_z=1.0^k$
DOL 2C8F	9/5/85	MODEL 2 SPRING BASE, BASE ANGLE FLEXIBILITY	$F_x=1.0^k$
DOL 3DLN	9/6/85	MODEL 2 SPRING BASE, BASE ANGLE FLEXIBILITY	$F_y=1.0^k$
DOL SA03	9/10/85	MODEL 2 SPRING BASE, BASE ANGLE FLEXIBILITY	$F_z=1.0^k$
DOL 3DL7	9/6/85	MODEL 2 SPRING BASE, BASE ANGLE FLEXIBILITY	$M_x=1.0^k$
DOL 2DXJ	9/6/85	MODEL 2 SPRING BASE, BASE ANGLE FLEXIBILITY	$M_y=1.0^k$
DOL 2D2F	9/6/85	MODEL 2 SPRING BASE, BASE ANGLE FLEXIBILITY	$M_z=1.0^k$
DOL 2D2Z	9/6/85	MODEL 2 SPRING BASE, BASE ANGLE FLEXIBILITY	$F_x=1.0^k$
DOL 2D0F	9/6/85	MODEL 2 SPRING BASE, BASE ANGLE FLEXIBILITY	$F_y=1.0^k$
DOL 2D0Z	9/6/85	MODEL 2 SPRING BASE, BASE ANGLE FLEXIBILITY	$F_z=1.0^k$
DOL 2D1J	9/6/85	MODEL 2 SPRING BASE, BASE ANGLE FLEXIBILITY	$M_x=1.0^k$
DOL TA2R	9/11/85	MODEL 2 SPRING BASE, STIFFNESS MATRIX	
DOL 5BL7	9/10/85	MODEL 2 SPRING BASE, STIFFNESS MATRIX	
DOL VBF3	9/20/85	MODEL 2 SPRING BASE, SEISMIC RESPONSE ANALYSIS	
DOL SF0F	9/17/85	MODEL 2 SPRING BASE, SEISMIC RESPONSE ANALYSIS	
DOL SGXJ	9/17/85	MODEL 2 SPRING BASE, SEISMIC RESPONSE ANALYSIS	



VOLUME I - BOOK 9D  
 TEXAS UTILITIES GENERATING COMPANY  
 COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

Multimode response multiplier study - computer runs for seismic analysis of Model No. 2, fixed base.

COMPUTER RUN	DATE OF RUN	TITLE	
DOLLIARN	9/12/85	MODEL 2 SYSTEM FREQUENCIES ANALYSIS, FIXED BASE	
DOLSCM7	9/10/85	MODEL 2 HANGER FREQUENCIES ANALYSIS, FIXED BASE	
DOLUBFJ	9/12/85	MODEL 2 HANGER FREQUENCIES ANALYSIS, FIXED BASE	
DOLLDMJ	9/12/85	INTER BLDG, OBE RSS=6	
DOLLDMN	9/12/85	INTER BLDG, SSE RSS=6	
DOLWBA7	9/14/85	AUXILIARY BLDG, OBE RSS=6 @ EL. 810.5'	
DOLWBA2	9/14/85	AUXILIARY BLDG, SSE RSS=6 @ EL. 810.5'	
DOLUDUB	9/12/85	AUXILIARY BLDG OBE RSS=6	
DOLLDT3	9/12/85	AUXILIARY BLDG SSE RSS=6	
DOLLDMG	9/12/85	ELETC. BLDG. OBE RSS=6	
DOLLDMF	9/12/85	ELETC. BLDG. SSE RSS=6	
DOLVDZ7	9/13/85	SAFEQ. BLDG. OBE RSS=6	
DOLVDXJ	9/13/85	SAFEQ. BLDG. SSE RSS=6	
DOLSB BZ	9/17/85	INTER, BLDG. OBE RSS=1	
DOLSB CF	9/17/85	INTER, BLDG. SSE RSS=1	
DOLSB AZ	9/17/85	AUXILIARY BLDG, OBE RSS=1 @ EL. 810.5'	
DOLSB BN	9/17/85	AUXILIARY BLDG, SSE RSS=1 @ EL. 810.5'	
DOLSB CV	9/17/85	AUXILIARY BLDG. OBE RSS=1	
DOL RHON	9/16/85	AUXILIARY BLDG. SSE RSS=1	
DOLSB CJ	9/17/85	ELETC. BLDG. OBE RSS=1	
DOLSB CR	9/17/85	ELETC. BLDG. SSE RSS=1	
DOLSA VB	9/17/85	SAFEQ. BLDG OBE RSS=1	
DOLSB C3	9/17/85	SAFEQ. BLDG. SSE RSS=1	

TABLE OF CONTENTS

Multimode response multiplier study - computer runs for seismic analysis of Model No. 1 & 2 for spring base.

COMPUTER RUN ID.	DATE OF RUN	TITLE	9E
DOLVCP3	10/11/85	VERTICAL SPECTRUM, OBE, DYNRE 5	
DOLVCS7	10/11/85	HORIZONTAL SPECTRUM, OBE, DYNRE 5	
DOLVCOB	10/11/85	VERTICAL SPECTRUM, SSE, DYNRE 5	
DOLVCL3	10/11/85	HORIZONTAL SPECTRUM, SSE, DYNRE 5	
DOLTFIN	10/16/85	MODEL 1, SPRING BASE, OBE, DYNRE 4	
DOLSHFV	10/16/85	MODEL 1, SPRING BASE, OBE, DYNRE 1, VERTI.	
DOLTGAZ	10/17/85	MODEL 1, SPRING BASE, OBE, DYNRE 1, VERTI.	
DOLSHIE3	10/16/85	MODEL 1, SPRING BASE, OBE, DYNRE 1, TRANS.	
DOLTGCV	10/17/85	MODEL 1, SPRING BASE, OBE, DYNRE 1, TRANS.	
DOLSHFN	10/16/85	MODEL 1, SPRING BASE, OBE, DYNRE 1, LONGI.	
DOLTGEB	10/17/85	MODEL 1, SPRING BASE, OBE, DYNRE 1, LONGI.	
DOLIENF	10/17/85	MODEL 1, SPRING BASE, SSE, DYNRE 4	
DOLSHBN	10/16/85	MODEL 1, SPRING BASE, SSE, DYNRE 1, VERTI.	
DOLTGGR	10/17/85	MODEL 1, SPRING BASE, SSE, DYNRE 1, VERTI.	
DOLSHDR	10/16/85	MODEL 1, SPRING BASE, SSE, DYNRE 1, TRANS.	
DOLTGF7	10/17/85	MODEL 1, SPRING BASE, SSE, DYNRE 1, TRANS.	
DOLSHC3	10/16/85	MODEL 1, SPRING BASE, SSE, DYNRE 1, LONGI.	
DOLTGFN	10/17/85	MODEL 1, SPRING BASE, SSE, DYNRE 1, LONGI.	
DOLTB9B	10/16/85	MODEL 2, SPRING BASE, OBE, DYNRE 4	
DOLUFKN	10/18/85	MODEL 2, SPRING BASE, OBE, DYNRE 1, VERTI.	
DOLUFLB	10/18/85	MODEL 2, SPRING BASE, OBE, DYNRE 1, TRANS.	
DOLUFL7	10/18/85	MODEL 2, SPRING BASE, OBE, DYNRE 1, LONGI.	
DOLUFN7	10/16/85	MODEL 2, SPRING BASE, SSE, DYNRE 4	
DOLUFIJ	10/18/85	MODEL 2, SPRING BASE, SSE, DYNRE 1, VERTI.	
DOLUFGF	10/18/85	MODEL 2, SPRING BASE, SSE, DYNRE 1, TRANS.	
DOLUFGN	10/18/85	MODEL 2, SPRING BASE, SSE, DYNRE 1, LONGI.	

VOLUME I - BOOK 9F  
TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

Multimode response multiplier study - computer runs for base angle flexibility analysis for Model No. 3.

COMPUTER RUN ID.	DATE OF RUN	TITLE							
DOLSC6B	9/10/85	FLEXIBILITY MATRIX							
DOLSC6J	9/10/85	FLEXIBILITY MATRIX							
DOLRDNF	9/10/85	BASE ANGLE ANALYSIS	2.6 x 6 x 3/4	x	37.33	NODE 13			
DOLRDM3	9/10/85	BASE ANGLE ANALYSIS	2.6 x 6 x 3/4	x	37.33	MX = 1.0 k			
DOLRDMR	9/10/85	BASE ANGLE ANALYSIS	2.6 x 6 x 3/4	x	37.33	MY = 1.0 k			
DOLRDMB	9/10/85	BASE ANGLE ANALYSIS	2.6 x 6 x 3/4	x	37.33	MX = 1.0 k			
DOLRDLZ	9/10/85	BASE ANGLE ANALYSIS	2.6 x 6 x 3/4	x	37.33	FZ = 1.0 k			
DOLRDLB	9/10/85	BASE ANGLE ANALYSIS	2.6 x 6 x 3/4	x	37.33	FY = 1.0 k			
DOLRDKN	9/10/85	BASE ANGLE ANALYSIS	2.6 x 6 x 3/4	x	37.33	NODE 13			
DOLRDG7	9/10/85	BASE ANGLE ANALYSIS	2.6 x 6 x 3/4	x	37.33	MX = 1.0 k			
DOLRDHV	9/10/85	BASE ANGLE ANALYSIS	2.6 x 6 x 3/4	x	37.33	MY = 1.0 k			
DOLRDIR	9/10/85	BASE ANGLE ANALYSIS	2.6 x 6 x 3/4	x	37.33	FZ = 1.0 k			
DOLRDJV	9/10/85	BASE ANGLE ANALYSIS	2.6 x 6 x 3/4	x	37.33	FY = 1.0 k			
DOLRDA7	9/10/85	BASE ANGLE ANALYSIS	2.6 x 6 x 3/4	x	37.33	NODE 13			

VOLUME I - BOOK 9G  
 TEXAS UTILITIES GENERATING COMPANY  
 COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

Multimode Response Multiplier Study - Computer Analysis for Cable Tray System  
 Runs with a Bend, Model Nos. 1A & 1B

LIST OF COMPUTER RUNS				
RUN I.D.	DATE	TYPE OF RUN (✓)		DESCRIPTION
		FREQUENT	STATIC	
DOLZCVR	11-11-85			FORTRAN - SUBROUTINE PICK
DOLZDC7	11-11-85			DYNRE4 - MODEL 1, OBE, FIXED
DOLOAXN	11-12-85			DYNRE4 - MODEL 1, SSE, FIXED
DOLZDNJ	11-11-85			DYNRE4 - MODEL 1, OBE, SPRING
DOLOAXB	11-12-85			DYNRE4 - MODEL 1, SSE, SPRING
DOLOAAZ	11-12-85			DYNRE4 - MODEL 2, OBE, FIXED
DOLOA2J	11-12-85			DYNRE4 - MODEL 2, SSE, FIXED
DOL6A2Z	11-12-85			DYNRE4 - MODEL 2, OBE, SPRING
DOL6A3Z	11-12-85			DYNRE4 - MODEL 2, SSE, SPRING

VOLUME I - BOOK 9H  
 TEXAS UTILITIES GENERATING COMPANY  
 COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

Multimode Response Multiplier Study - Computer Analysis for Cable Tray System Runs with a Bend, Model Nos. 1A & 1B

LIST OF COMPUTER RUNS				
RUN I.D.	DATE	TYPE OF RUN (✓)		DESCRIPTION
		FREQUENCY	STATIC	
DRY RA 53	12-30-85	✓		MODEL "1-A" - 3-D-FREQ.
DRY TB NZ	1-8-86	✓		MODEL "1-B" - 3-D-FREQ
DRY SA 2F	12-31-85	✓		MODEL "1-A" - 2-D-FREQ
DRY UB QV	1-10-86	✓		MODEL "1-B" - 2-D-FREQ
DRY TC DB	1-15-86		✓	MODEL "1-A" - 2-D-STATIC
DRY VC QJ	1-31-86		✓	MODEL "1-B" - 2-D-STATIC (FACTOR MOMENT)
DRY SC TR	1-23-86		✓	MODEL "1-B" - 2-D-STATIC-REF
DRY TD E7	1-29-86		✓	MODEL "1-B" - 2-D-STATIC (UNBAL. MOMENT)-REF

VOLUME I - BOOK 91  
 TEXAS UTILITIES GENERATING COMPANY  
 COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

Multimode Response Multiplier Study - Computer Analysis for Cable Tray System. Runs with a Bend, Model Nos. 1A & 1B

LIST OF COMPUTER RUNS				
RUN I.D.	DATE	TYPE OF RUN		DESCRIPTION
		FREQ.	STATIC	
DRY UD QF	1-16-86			"1A"-MRM-860.00'-OBE (RSS=6)
DRY UD V7	1-16-86			"1A"-MRM-860.00'-SSE (RSS=6)
DRY UD WH	1-16-86			"1A"-MRM-905.75'-OBE (RSS=6)
DRY UD W7	1-16-86			"1A"-MRM-905.75'-SSE (RSS=6)
DRY UD XJ	1-16-86			"1A"-MRM-899.50'-OBE (RSS=6)
DRY UD XB	1-16-86			"1A"-MRM-899.50'-SSE (RSS=6)
DRY UD YB	1-16-86			"1A"-MRM-873.33'-OBE (RSS=6)
DRY UD YN	1-16-86			"1A"-MRM-873.33'-SSE (RSS=6)
DRY UD ZB	1-16-86			"1A"-MRM-896.5'-OBE (RSS=6)
DRY UD ZF	1-16-86			"1A"-MRM-896.5'-SSE (RSS=6)
DRY VB PR	1-17-86			"1B"-MRM-860.5'-OBE (RSS=6)
DRY VB P3	1-17-86			"1B"-MRM-860.0'-SSI (RSS=6)
DRY VB QH	1-17-86			"1B"-MRM-905.75'-OBE (RSS=6)
DRY VB RB	1-17-86			"1B"-MRM-905.75'-SSE (RSS=6)
DRY VB RJ	1-17-86			"1B"-MRM-899.5'-OBE (RSS=6)
DRY VB RZ	1-17-86			"1B"-MRM-899.5'-SSE (RSS=6)
DRY VB SB	1-17-86			"1B"-MRM-873.33'-OBE (RSS=6)
DRY VB SR	1-17-86			"1B"-MRM-873.33'-SSE (RSS=6)
DRY VB SV	1-17-86			"1B"-MRM-896.5'-OBE (RSS=6)
DRY VB S7	1-17-86			"1B"-MRM-896.5'-SSE (RSS=6)



VOLUME I - BOOK 9J  
 TEXAS UTILITIES GENERATING COMPANY  
 COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

Multimode Response Multiplier Study - Computer Analysis for Cable Tray  
 System Runs with a Bend, Model Nos. 1A & 1B

LIST OF COMPUTER RUNS				
ROW I. D.	DATE	TYPE OF RUN (V)		DESCRIPTION
		FREQ.	STATIC	
DRY UD 2F	1-16-86			"1-A"-MRM-860.00' OBE (RSS=14) IRSSXI=1
DRY UE GR	1-17-86			"1-A"-MRM-860.00'SSE (RSS=14) IRSSXI=1
DRY UE GB	1-17-86			"1-A"-MRM-905.75' OBE (RSS=14) IRSSXI=1
DRY UE HJ	1-17-86			"1-A"-MRM-905.75'SSE (RSS=14) IRSSXI=1
DRY UE IB	1-17-86			"1-A"-MRM-899.50' OBE (RSS=14) IRSSXI=1
DRY UE IJ	1-17-86			"1-A"-MRM-899.50'SSE (RSS=14) IRSSXI=1
DRY UE IV	1-17-86			"1-A"-MRM-873.33' OBE (RSS=14) IRSSXI=1
DRY UE JJ	1-17-86			"1-A"-MRM-873.33'SSE (RSS=14) IRSSXI=1
DRY UE JR	1-17-86			"1-A"-MRM-896.50' OBE (RSS=14) IRSSXI=1
DRY UE JV	1-17-86			"1-A"-MRM-896.50'SSE (RSS=14) IRSSXI=1
DRY VB GF	1-17-86			"1-B"-MRM-860.00' OBE (RSS=14) IRSSXI=1
DRY VB JN	1-17-86			"1-B"-MRM-860.00'SSE (RSS=14) IRSSXI=1
DRY VB J3	1-17-86			"1-B"-MRM-905.75' OBE (RSS=14) IRSSXI=1
DRY VB KN	1-17-86			"1-B"-MRM-905.75'SSE (RSS=14) IRSSXI=1
DRY VB KV	1-17-86			"1-B"-MRM-899.5' OBE (RSS=14) IRSSXI=1
DRY VB LN	1-17-86			"1-B"-MRM-899.5'SSE (RSS=14) IRSSXI=1
DRY VB MN	1-17-86			"1-B"-MRM-873.33 OBE (RSS=14) IRSSXI=1
DRY VB NB	1-17-86			"1-B"-MRM-873.33 SSE (RSS=14) IRSSXI=1
DRY VB NR	1-17-86			"1-B"-MRM-896.5 OBE (RSS=14) IRSSXI=1
DRY DA 5R	1-21-86			"1-B"-MRM-896.5 SSE (RSS=14) IRSSXI=1

VOLUME I - BOOK 9K  
 TEXAS UTILITIES GENERATING COMPANY  
 COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

Multimode Response Multiplier Study - Computer Analysis for Cable Tray System Runs with a Bend, Model Nos. 1A & 1B

LIST OF COMPUTER RUNS				
RDN I.D.	DATE	TYPE OF RUN (V)		DESCRIPTION
		FREQ.	STATIC	
DRY SB P3	1-7-86			EL 860-R.I BLDG-OBE
DRY SD YZ	1-7-86			EL 860-R.I. BLDG-SSE
DRY SD 47	1-7-86			EL 905.75 R.I. BLDG-OBE
DRY SD 6Z	1-7-86			EL 905.75 R.I BLDG SSE
DRY VC ?N	1-15-86			EL 899.5-R.A.B. OBE-M.1A.
DRY SD 9F	1-7-86			EL 899.5-R.A.B. SSE-1A
DRY SE AF	1-7-86			EL 873.33-ELECT BLDG-OBE
DRY SE AV	1-7-86			EL 873.33-ELECT BLDG-SSE
DRY VC 23	1-15-86			EL 896.5-SAFEGUARD BLDG-OBE-M.1A
DRY SE BJ	1-15-86			EL 896.5-SAFEGUARD BLDG-SSE-M.1A
DRY VC RR	1-17-86			EL 860.0-MRM-1B-OBE-RSS=1
DRY VC RZ	1-17-86			EL 860.0-MRM-1B-SSE-RSS=1
DRY VC R3	1-17-86			EL 905.75-MRM-1B-OBE-RSS=1
DRY VC 3B	1-17-86			EL 905.75-MRM-1B-SSE-RSS=1
DRY VC KN	1-10-86			EL 899.5-R.A.B-OBE-M.1B
DRY VC SH	1-17-86			EL 899.5-MRM-1B-SSE-RSS=1
DRY VC SR	1-17-86			EL 873.33-MRM-1B-OBE-RSS=1
DRY YU QZ	1-10-86			EL 873.33-ELECT BLDG-SSE <sup>M.1B</sup> RSS=1
DRY VC S7	1-17-86			EL 896.5-MRM-1B-OBE-RSS=1
DRY VC TF	1-17-86			EL 896.5-MRM-1B-SSE-RSS=1

VOLUME I - BOOK 9L  
 TEXAS UTILITIES GENERATING COMPANY  
 COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

Multimode Response Multiplier Study - Computer Analysis for Cable Tray System Runs with a Bend, Model Nos. 1A & 1B

LIST OF COMPUTER RUNS				
RUN ID.	DATE	TYPE OF RUN (✓)		DESCRIPTION
		FREQUENCY	STATIC	
DRY TD WV	1-22-86		✓	MODEL "1-A" - MISSING WT. RATIO (3-D)
DLIC 9E	1-22-86		✓	MODEL "1-B" - MISSING WT. RATIO (3-D)
DRY TE JB	1-30-86		✓	MODEL "1-A" - RIGID MOTION (3-D)
DRY TE HV	1-29-86		✓	MODEL "1-B" - RIGID MOTION (3-D)
DRY SA UH	12-31-85		✓	MODEL "1-A" - 3-D MISSING WT. RATIO RAT. BLDG. 560.0' O.B.E. (REF)
DRY UD 2J	1-16-86		✓	MODEL "1-A" - MRM (RSS 714, IRSS XI 10) RAT BLDG. 560.0' O.B.E. (REF)
DRY 2B 9J	1-27-86		✓	MODEL "1-B" - 3-D STATIC INERTIA FORCE
DRY 3DVH	2-21-86		✓	MODEL "1-A" 3-D STATIC INERTIA FORCE

VOLUME I - BOOK 9M  
 TEXAS UTILITIES GENERATING COMPANY  
 COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

Multimode Response Multiplier Study - Computer Analysis for Cable Tray  
 System Runs with a Bend, Model Nos. 1A & 1B

LIST OF COMPUTER RUNS				
RUN I.D.	DATE	TYPE OF RUN (✓)		DESCRIPTION
		FREQUENCY	STATIC	
DRYED MN	2-3-86			MODEL "1-A" OBE "BEST ESTIMATE EQ."
DRYED GJ	2-4-86			MODEL "1-A" SSE "BEST ESTIMATE EQ" 1/2
DRY OD AB	2-4-86			MODEL "1A" SSE "BEST ESTIMATE EQ" 2/2
DRYED XF	2-4-86			MODEL "1-B" OBE "BEST ESTIMATE EQ" 1/2
DRY OD OJ	2-5-86			MODEL "1B" OBE "BEST ESTIMATE EQ" 2/2
DRYED XJ	2-4-86			MODEL "1-B" SSE "BEST ESTIMATE EQ" 1/2
DRY OD TR	2-5-86			MODEL "1-B" SSE "BEST ESTIMATE EQ" 2/2
DRY ZC L3	2-3-86			MODEL "1A" OBE "RESPONCE SPECTRA"
DRY ZA 4B	2-3-86			MODEL "1A" SSE "RESPONCE SPECTRA"
DRY ZC 67	2-3-86			MODEL "1-B" OBE "RESPONCE SPECTRA"
DRY ZD F7	2-3-86			MODEL "1-B" SSE "RESPONCE SPECTRA"

VOLUME I - BOOK 10  
TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

MODEL NO. 3

<u>SUBJECT</u>	<u>MULTIMODE RESPONSE MULTIPLIER - STUDIES</u>	<u>PAGE</u>
Introduction		1
Procedure		4
Reference		6
Reference Drawings		7
Response Spectra Curves		15
Model		
Boundary Conditions		27
Support Sketches		29
Grid and Element Numbering		37
Plots		45
Properties		49
Flexible Boundary Stiffness Matrix		58
Tray Frequencies		60
Fixed Boundary Condition Case Support 11099		
List of Computer Runs		61
Equivalent Static Method		62
Design "G" Value Computation		63
Input to Response Spectra		66
Modal Plots		69
Summary of MRM Factors		72
Flexible Boundary Condition Case, Support 11012		
List of Computer Runs		74
Equivalent Static Method		75
Flexible Boundary Condition Case, Support 11012		
Design "G" Value Computation		76
Input to Response Spectra		79
Modal Plots		82
Summary of MRM Factors		85
Appendices		
Computer Runs	Volume I Book 10A	
	Volume I Book 10B	
	Volume I Book 10C	

VOLUME I - BOOK 10A  
TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

COMPUTER RUNS - MULTIMODE RESPONSE MULTIPLIER - STUDIES

<u>RUN I.D.</u>	<u>DATE</u>	<u>DESCRIPTION</u>
DOL UD JB	9/12/85	Frequency Anal. 2-D Fixed B.C. CTH-2-11099
DOL RF 67	10/25/85	Frequency Anal. 3-D Fixed B.C. Tape 23495
DOL SI MF	10/29/85	Response Spectra - Fixed B.C. - OBE Safeguard Bldg EL 852.5
DOL SI M3	10/29/85	Response Spectra - Fixed B.C. - OBE Safeguard Bldg EL 896.5
CLØ RD I3	11/4/85	Response Spectra - Fixed B.C. - OBE Safeguard Bldg EL 896.5
DOL SI NN	10/29/85	Response Spectra - Fixed B.C. - OBE Auxiliary Bldg EL 899.5
CLØ RD I7	11/4/85	Response Spectra - Fixed B.C. - OBE Auxiliary Bldg EL 899.5
DOL SI NV	10/29/85	Response Spectra - Fixed B.C. - OBE Electric Bldg EL 873.33
DOL SI N7	10/29/85	Response Spectra - Fixed B.C. - OBE R.B. Internals EL 905.75
DOL SI QJ	10/29/85	Response Spectra - Fixed B.C. - SSE Safeguard Bldg EL 852.5
CLØ RD ØV	11/4/85	Response Spectra - Fixed B.C. - SSE Safeguard Bldg EL 896.5
DOL SI ØR	10/29/85	Response Spectra - Fixed B.C. - SSE Auxiliary Bldg EL 899.5
CLØ RD L7	11/4/85	Response Spectra - Fixed B.C. - SSE Auxiliary Bldg EL 899.5
DOL SI PF	10/29/85	Response Spectra - Fixed B.C. - SSE Electric BLDG EL 873.33
DOL SI QN	10/29/85	Response Spectra - Fixed B.C. - SSE R.B. Internals EL 905.75

VOLUME I - BOOK 10B  
TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

COMPUTER RUNS - MULTIMODE RESPONSE MULTIPLIER - STUDIES

<u>RUN I.D.</u>	<u>DATE</u>	<u>DESCRIPTION</u>
DOL WB CJ	10/26/85	2-D Flexible B.C. CTH-2-11012
DOL VC F3	10/25/85	3-D Flexible B.C. Tape 13720
DOL TB 1B	10/30/85	Response Spectra Anal. Flexible B.C. - OBE Safeguard Bldg EL 852.5
DOL VI 9J	11/1/85	Response Spectra Anal. Flexible B.C. - OBE Safeguard Bldg EL 896.5
DOL VJ FJ	11/1/85	Response Spectra Anal. Flexible B.C. - OBE Auxiliary Bldg EL 899.5
DOL TB 23	10/30/85	Response Spectra Anal. Flexible B.C. - OBE Electric Bldg EL 873.33
DOL TB 3B	10/30/85	Response Spectra Anal. Flexible B.C. - OBE R.B. Internals EL 905.75
DOL TB 3V	10/30/85	Response Spectra Anal. Flexible B.C. - SSE Safeguard Bldg EL 852.5
DOL VI 7N	11/1/85	Response Spectra Anal. Flexible B.C. - SSE Safeguard Bldg EL 896.5
DOL VJ CZ	11/1/85	Response Spectra Anal. Flexible B.C. - SSE Auxiliary Bldg EL 899.5
DOL TB 5V	10/30/85	Response Spectra Anal. Flexible B.C. - SSE Electric Bldg EL 873.33
DOL TB 0J	10/30/85	Response Spectra Anal. Flexible B.C. - SSE R.B. Internals EL 905.75

VOLUME I - BOOK 10C  
TEXAS UTILITIES GENERATING COMPANY  
COMANCHE PEAK UNIT NO. 2

TABLE OF CONTENTS

Computer Runs - Multimode Response Multiplier - Studies

<u>RUN I.D.</u>	<u>DATE</u>	<u>DESCRIPTION</u>
DOL RB IB	9/23/85	Q/A Dump of DYNRE 4 Run's Tape 80
DOL NB RF	9/26/85	Q/A of Post Processor From P.F.X3 = Longitudinal
DOL UB 47	9/26/85	Q/A of Post Processor From Deck X3 = Longitude
DOL UC N7	9/26/85	Q/A of Post Processor Form Deck X1 = Longitude
DOL UC XR	9/26/85	Q/A Created P.F. of Post Processor
DOL RE MB	9/30/85	Q/A of Actual Case Using P.F.



EBASCO SERVICES INCORPORATED  
CALCULATION COVER SHEET

CLIENT TEXAS UTILITIES GENERATING CO  
COMANCHE PEAK UNIT 2  
CABLE TRAY HANGERS

OFS NO. TU4C3306.221  
DEPT NO. 550

SUBJECT MULTIPLE RESPONSE MULTIPLIER - STUDY FOR CABLE TRAY SYSTEM RUNS  
WITH A BEND MODELS 1A & 1B

CALCULATION NO. VOLUME I - BOOK 9 (PART 4) NUMBER OF SHEETS 102

PROBLEM

The verification of a Multiple Response Multiplier (MRM) was extended to cover the cable tray-hanger system with a bend.

It was found that the previous finding for the straight run system is valid also for the cable tray-hanger system with bend, namely an MRM of 1.25 is adequate to cover the multiple modes and system effect, by Equivalent Static Analysis (ESA) method.

CONTAINS ASSUMPTIONS WHICH REQUIRE CONFIRMATION YES \_\_\_\_\_ NO   
ASSUMPTIONS CONFIRMED ON \_\_\_\_\_ BY \_\_\_\_\_

						OPTIONAL		
0	102	I H CHOU	2/11/80	C.H. Yeh / K.W. Yu	2/11/80			
REV. NO.	SHEET NOS.	NAME	DATE	NAME	DATE		NAME	DATE
		CALCULATION BY		CHECKED BY			REVIEWED OR APPROVED BY	

PRELIMINARY  FINAL  SUPERSEDES CALC NO. \_\_\_\_\_

EBASCO SERVICES INCORPORATED

BY Z H CHU DATE 2/10/86

SHEET 1 OF 2

CHKD. BY YEL DATE 2/10/86

OFS NO. 3306 221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

TABLE OF CONTENTS

SECTIONS	PAGE
1. <u>INTRODUCTION</u>	<u>1.</u>
2. <u>STRUCTURAL MODELS</u>	<u>5.</u>
2a. <u>PROPERTIES</u>	<u>7.</u>
2b. <u>BOUNDARY CONDITION</u>	<u>8.</u>
2c. <u>TRAY WEIGHT (MODELS 1-A/1-B)</u>	<u>9.</u>
2d. <u>MODELS &amp; PLOTS (MODELS 1-A/1-B)</u>	<u>11.</u>
3. <u>FREQUENCY ANALYSIS</u>	<u>24.</u>
3a. <u>MODEL 1-A. "2-D" &amp; SYST. APPROX. FREQ.</u>	<u>25.</u>
3b. <u>MODEL 1-B. "2-D" &amp; SYST. APPROX. FREQ.</u>	<u>27.</u>
3c. <u>SUMMARY TABLE (MODELS 1-A/1-B)</u>	<u>31.</u>
4. <u>RESPONSE SPECTRA &amp; MRM FOR "g"</u>	<u>33</u>
4a. <u>INTRODUCTION</u>	<u>33.</u>
4b. <u>MRM FOR <math>RSS = 6</math>,</u>	<u>36</u>
4c. <u>MRM FOR <math>RSS = 14</math>, <math>IRSSXI = 1</math>,</u>	<u>37.</u>
4d. <u>MRM FOR <math>RSS = 1</math>,</u>	<u>38.</u>

EBASCO SERVICES INCORPORATED

BY Z H ctlo DATE 2/10/86

SHEET 2 OF 2

CHKD. BY TEP DATE 2/10/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEL. UTILITIES GENERAL CO.

PROJECT COMANCHE PEAK UNIT 2  
CABLE TRAY HANGERS

SUBJECT \_\_\_\_\_

TABLE OF CONTENTS (CONT'D)

<u>SECTIONS</u>	<u>PAGE</u>
<u>5. REACTION &amp; MRM.</u>	<u>42</u>
<u>5a. MISSING WEIGHT (MODELS 1-A/1-B)</u>	<u>45</u>
<u>5b MRM FOR REACTION (MODELS 1-A/1-B)</u>	<u>58.</u>
<u>5c. SUMMARY TABLE</u>	<u>63</u>
<u>6. TIME HISTRY Vs. RESPONSE SPECTRA APPROACH</u>	<u>69</u>
<u>6a. 2-D ACCL. LEVEL FOR BEST ESTIMATE EQ.</u>	<u>71.</u>
<u>6b. DYNAMIC RESPONSES (MODELS 1-A/1-B)</u>	<u>72</u>
<u>6c. MRM FOR TIME HISTRY APPROACH</u>	<u>88</u>
<u>(MODELS 1-A/1-B)</u>	
<u>6d. SUMMARY TABLE FOR MRM</u>	<u>100</u>
<u>7. CONCLUSION</u>	<u>101</u>

EBASCO SERVICES INCORPORATED

BY Z H CHU DATE 1/22/86

SHEET 1 OF 102

CHKD. BY YBL DATE 1/25/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

1 Introduction

The verification of a Multimode Response Multiplier<sup>(MRM)</sup> was extended to investigate a cable tray-hanger system with bent. The study followed the same procedures as in the straight run cases, namely:

A). 2-D hanger study:

- i) frequency analysis for hanger with tray weight added at the tier locations,
- ii) system frequency computation through Dunkerley's formula to combine the frame and cable frequencies
- iii) acceleration level in three directions from the corresponding floor response spectrum curves for the three fundamental system frequencies obtained in step ii of (A).

EBASCO SERVICES INCORPORATED

BY Z H CHW DATE 1/20/86

SHEET 2 OF 102

CHKD. BY YSL DATE 1/20/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

iv) static analysis to find the reactions at the supports of the hanger using acceleration level obtained from (iii) of (A)

B) 3-D cable hanger - tray system

Two systems were investigated, one with a symmetrical setting (model 1-A), and the other with tray terminating at one end (model 1-B). Both systems used the longitudinal and transverse hangers as those of model 1 in previous straight run study, with the same cable tray arrangement.

i) Frequency analysis :

cut off frequency of 33 Hz is used

ii) Modal response analysis :

STAR DYNE system, DYNRE 4 code was used in the study with three

EBASCO SERVICES INCORPORATED

BY Z H CHU DATE 1/22/86

SHEET 3 OF 102

CHKD. BY YEH DATE 1/23/86

OFS NO. 3306.221 DEPT. STD  
NO. 570

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

distinctive options

a)  $RSS = 1$ , purely SRSS for modal  
superposition

b)  $RSS = 14$  and  $IRSS \times I = 1$

C&C

c)  $RSS = 6$ , SRSS with 10% close mode  
provision

The responses obtained were <sup>nodal</sup> accelerations  
as well as reactions at the support.

iii) static analysis to find the support reactions  
due to missing weight.

c) The comparison of results from A & B  
was then performed on both the  
acceleration level as well as hanger  
support reactions.

It should be noted that in the modal  
analysis ~~the~~ structural responses up to 33 Hz

## EBASCO SERVICES INCORPORATED

BY I H CHW DATE 1/22/86

NEW YORK

SHEET 4 OF 102CHKD. BY 1/24 DATE 1/25/86OFS NO. 2306 231 DEPT. NO. 530CLIENT TEXAS UTILITIES OPERATING CO.PROJECT COMANCHE PEAK UNIT 2SUBJECT CABLE TRAY HANGERS

were combined. To account for the contributions due to the higher modes, a residual-load-method was used. It was obvious from this study, that the contribution is substantial, especially at the panel points of the hanger.

The results of this study further support and substantiate the simplification factor of 1.25 is adequate and conservative, both for the acceleration and hanger reaction considerations.

## EBASCO SERVICES INCORPORATED

NEW YORK

BY I H cited DATE 1/22/86SHEET 5 OF 102CHKD. BY YBH DATE 1/25/86OFS NO. 2206 221 DEPT. 530 NO. 530CLIENT TEXAS UTILITIES GENERATING CO.  
PROJECT COMANCHE PEAK UNIT 2  
SUBJECT CABLE TRAY HANGERS2 STRUCTURAL MODELS

Two cable tray-hanger systems with bend were constructed, designated as models 1-A and 1-B. Both the transverse / longitudinal hanger and cable tray used the same configuration as those of model 1 in the previous straight run study. Model 1-A had symmetrical setting with longitudinal supports at both ends, whereas model 1-B has trays terminated at one end.

The support hangers were assumed fixed at the support points. An additional cable tray weight was added at the tray nodal points at the end support hanger, to account for the tray load beyond the end support hanger.

The cross-sectional properties were



EBASCO SERVICES INCORPORATED

NEW YORK

BY I HCH DATE 4/22/86

SHEET 6 OF 102

CHKD. BY YGH DATE 1/25/85

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.  
PROJECT COMANCHE PEAK UNIT 2  
SUBJECT CABLE TRAY HANGERS

identical to the previous study. However, it is included for easy reference. The tray weight assumed a maximum of  $35 \text{ \#/ft}^2$  as in <sup>the</sup> previous study.

**EBASCO SERVICES INCORPORATED**

BY C.H. HICK DATE 12-17-85

SHEET 7 OF 102

CHKD. BY C.Wu DATE 12-17-85

OFS N. =306221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2


SUBJECT CABLE TRAY HANGERS

2a. BEAM PROPERTY

BEAM I.D.	PROP I.D	A	J	I <sub>3</sub>	I <sub>2</sub>	S <sub>2</sub>	S <sub>3</sub>
C6x8.2	1	2.4	.075	13.1	.692	.5	.5
C4x7.25	2	2.13	.082	4.59	.432	.61	.39
L3x3x3/8	3	2.11	—	—	—	—	—
COMPOSIT MC6x12/C6x8.2	4	5.83	0.22	19.719	4.985	0.5	0.5
MC6x12	5	3.53	.155	18.7	1.87	.53	.47
12x4 TRAY	6	1.102	.099	1.465	5.793	0.5	0.5
RIGID BAR	7	50.0	200.0	2000.0	2000.0	1.0	1.0

NOTES:

1. UNIT IN INCH-KIP,
2. ELASTIC PROPERTIES  $E = 29 \times 10^3$ ,
3. POISSON RATIO  $\nu = 0.3$
4. CRITICAL DAMPING RATIO : OBE 4% , SSE 7%



EBASCO SERVICES INCORPORATED

BY H-H-U DATE 2/10/86

SHEET 8 OF 102

CHKD. BY YEH DATE 2/12/86

OFS NO. 3306221 DEPT. 533  
NO. 533

CLIENT TEXAS UTILITIES GENERATING CO.  
PROJECT COMANCHE PEAK UNIT 2  
SUBJECT CABLE TRAY HANGERS

2b. Boundary Condition

The support hangers were assumed fixed at the support points. An additional cable tray weight was added at the tray support points at the end support hanger to account for the tray load beyond the end support hanger.

EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 12/31/85

SHEET 9 OF 102

CHKD. BY C.W.J. DATE 12/31/85

OFS NO. 3306 221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS  
MODEL "1-A"

2C. TRAY WEIGHT

I. TRAY LOAD FOR FREQUENCY ANALYSIS INPUT (MODEL 1-A)

1. EXTRA - LOAD FOR SUPT # 1, PT ①, ③①, ③② (3-D INPUT)

LONG.  $35 \times 20' = 700 \#$  ( $W_1 = .7^k$ )

VERT.  $35 \times 4.5' = 158 \#$  ( $W_2 = .158^k$ )

TRAN.  $35 \times 4.5' = 158 \#$  ( $W_3 = .158^k$ )

2. EXTRA - LOAD FOR SUPT # 6 PT ②③, ⑤③, ⑤④ (3-D. INPUT)

LONG  $W_3 = .7^k$

VERT  $W_2 = .158^k$

TRAN  $W_1 = .158^k$

3. NODAL LOAD FOR 2-D (SINGLE FRAME) FREQUENCY ANALYSIS

SUPT # 3, PT ③⑤, ③⑥, ③⑦

LONG.  $W_1 = 0$

VERT.  $W_2 = 35 \times \left( \frac{108}{2} + 24 + \frac{1}{4} \times \pi \times 30 \right) / 2 = 296 \# = .296^k$

TRANS.  $W_3 = 35 \times \left( 108 \times 3 + 24 \times 2 + \frac{1}{2} \times \pi \times 30 \right) / 2 \times 2 = 611 \# = .611^k$

EBASCO SERVICES INCORPORATED

BY C.H. yeh DATE 01/08/86  
 CHKD. BY C.Wu DATE 1/15/86  
 CLIENT TEXAS UTILITIES GENERATING CO.  
COMANCHE PEAK UNIT 2  
 PROJECT CABLE TRAY HANGERS  
 SUBJECT MODEL. 1-B

SHEET 10 OF 102  
 OFS NO. 3306.221 DEPT. NO. 550

II. TRAY LOAD FOR FREQ. ANAL. (MODEL. 1-B)

1. EXTRA-LOAD FOR EXTERIA SUPT (3-D FREQ. ANAL.)

FOR SUPT 1, PT ①, ③①, ⑥①

LONG =  $35 \times 9' = 315 \#$  ( $W_1 = .315$ )

VERT =  $35 \times 9' / 2 = 158 \#$  ( $W_2 = .158$ )

TRAN =  $158 \#$  ( $W_3 = .158$ )

$\star L = 40 - 9 \times 3 = 45 = 8.5'$

FOR SUPT 6, PT ②③, ⑤③, ⑧③

LONG. =  $0$  ( $W_3 = 0$ )

VERT =  $35 \times 9 / 2 = 158 \#$  ( $W_2 = .158$ )

TRAN =  $158 \#$  ( $W_1 = .158$ )

2. NODAL LOAD FOR Z-D SINGLE FRAME FREQUENCY ANALYSIS

SUPT 4, NODAL. 405, 406, 407

LONG.  $W_1 = 0.$

VERT  $W_2 = 35 \times \left( \frac{108}{2} + 24 + \frac{1}{4} \pi \times 30 \right) / 2 = 296 \# = .296 \#$

TRAN.  $W_3 = W_2 \times 2 + 35 \times 4.5 = 750 \#$

EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 12-24-85

SHEET 11 OF 102

CHKD. BY C.Wu DATE 1-16-86


OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

CABLE TRAY HANGERS

SUBJECT MODEL 1-A





EBASCO SERVICES INCORPORATED

BY C.H. yeh DATE 12-16-85  
 CHKD. BY C.Wu DATE 1-16-86  
 CLIENT TEXAS UTILITIES GENERATING CO.  
 PROJECT COMANCHE PEAK UNIT 2  
 SUBJECT CABLE TRAY HANGERS  
MODEL "1-A"

SHEET 12 OF 102  
 OFS NO. 3306-221 DEPT. NO. 550

MODEL OF SPT 1

(X1 = 0.0)



# EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 12-16-85

SHEET 13 OF 102

CHKD. BY C.Wu DATE 1-16-86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2  
CABLE TRAY HANGERS





SUBJECT MODEL 1-A

MODEL OF SUPT 2. (X1=108)

MODEL OF SUPT 5 (X3=108)

MODEL OF SUPT 3 (X1=216)

MODEL OF SUPT 4 (X3=216)



$X_1$	108.0	→ 216.0		
$X_3$	282.0	270.	240.75	
$X_2'$	4.0	20.875	28.875	
$X_2$	0.0	16.875	34.875	51.125

	282.0	270	240.75	$X_1$
	108.0	~ 216.0		$X_3$
	4.0	20.875	28.875	$X_2'$
	0.0	16.875	34.875	51.125 $X_2$



EBASCO SERVICES INCORPORATED

BY C.H. yeh DATE 12-16-85

SHEET 14 OF 102

CHKD. BY C.Wu DATE 1-16-86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.


PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGING


MODEL 1-D

MODEL OF SPT 6

(X3=0.0)




ELV. OF MODEL




UPPER FRAME

$x_2 = 36.0$

$x_1' = 38.875$




MID LOW FRAME  $x_2 = 18.0$   $x_1' = 20.875$   
 $0.0$   $4.0$



TEXAS UTILITIES GENERATING CO.  
COMANCHE PEAK UNIT 2  
CABLE TRAY HANGERS


BY C. H. Yeh DATE 01/16/85  
CHKD. BY C. Wu DATE 1/16/86



TEXAS UTILITIES GENERATING CO.  
COMANCHE PEAK UNIT 2  
CABLE TRAY HANGERS


BY C. H. Yeh DATE 01/16/86

CHKD. BY C. Wu DATE 1/16/86



TEXAS UTILITIES GENERATING CO.  
COMANCHE PEAK UNIT 2  
CABLE TRAY HANGERS

BY C.H. Yeh DATE 01/16/85  
CHKD. BY C.Wu DATE 1/16/86



EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 01/06/85

SHEET 19 OF 102


CHKD. BY C.Wu DATE 1-16-86

OFS NO. 3306.221 DEPT. 550  
NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2  
CABLE TRAY HANGERS

SUBJECT MODEL 1-B



EBASCO SERVICES INCORPORATED

BY C.H. yeh DATE 01/06/86

SHEET 19 OF 102

CHKD. BY C.Wu DATE 1-16-86

OFS NO. 3306 221 DEPT. 550

CLIENT TEXAS UTILITIES GENERATING CO.


PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS


MODEL 1-B

MODEL OF SUPT 1

$(x_1 = -108.0)$




$x_3 = 2790 \quad 266.0 \quad 231.0$



UPPER FRAME

$x_2 = 36.0$   
 $x_3' = 33.875$



MID. FRAME (LOW)

$(x_2 = 18.0 \quad x_3' = 20.875)$   
 $(x_2 = 0.0 \quad x_3' = 4.0)$

EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 01/06/86

SHEET 20 OF 102

CHKD. BY C.Wu DATE 1-16-86

OFS NO. 2206 221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.


PROJECT COMANCHE PEAK UNIT 2

CABLE TRAY HANGERS

SUBJECT MODEL 1-B


MODEL OF SUP'T 2, 3, 4 }  $x_1 = \begin{matrix} 0.0 \\ 108.0 \\ 216.0 \end{matrix}$

MODEL OF SUP'T 5, 6 }  $x_3 = \begin{matrix} 216.0 \\ 108.0 \end{matrix}$



TEXAS UTILITIES GENERATING CO.  
COMANCHE PEAK UNIT 2  
CABLE TRAY HANGERS


BY C.H. Yeh DATE 01/16/86  
CHKD. BY C.Wu DATE 1/16/86






TEXAS UTILITIES GENERATING CO.  
COMANCHE PEAK UNIT 2  
CABLE TRAY HANGERS

BY C.H. Yeh DATE 01/16/86  
CHKD. BY C.Wu DATE 1/16/86



TEXAS UTILITIES GENERATING CO.  
COMANCHE PEAK UNIT 2  
CABLE TRAY HANGERS

BY C.H. Yeh DATE 01/16/86  
CHKD. BY C.W.J. DATE 1/16/86



BY Z HCHOV DATE 1/22/86SHEET 24 OF 102CHKD. BY YEH DATE 1/31/86OFS NO. 3306.721 DEPT. NO. 550CLIENT TEXAS UTILITIES GENERATING CO.  
PROJECT COMANCHE PEAK UNIT 2  
SUBJECT CABLE TRAY HANGERS3 FREQUENCY ANALYSIS

The eigen vector characteristics were extracted, using the Lanczos procedure in the STARDYNE computer code. Both models 1-A & 1-B plus corresponding 2-D single frame models with corresponding cable tray weights were studied.

The Dunkerley formula was utilized to calculate the approximate system frequency which was subsequently used to find the acceleration level in the corresponding direction.

EBASCO SERVICES INCORPORATED

BY C. H. YEH DATE 12.31.85

SHEET 25 OF 102

CHKD. BY C. W. WU DATE 1-3-86

OFS NO. 3306221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.  
COMANCHE PEAK UNIT 2

PROJECT CABLE TRAY HANGERS

SUBJECT SYSTEM FREQ. FOR "2-D" MODEL "1-A"

3a. SYSTEM FREQ. FOR "2-D" MODE 1-A

FROM: MODEL NO. 1 w/ 90° BEND  
FRAME NO. 3.

$$AV. SPAN = (108 + 95.1) / 2 / 12 = 101.55 / 12 = 8.4625'$$

FROM: ATT. C2 / GENERAL INSTRUCTION FOR CTH ANALYSIS  
PAGE 26. (DATE 6/4/85)

$$I_V = 1.465, \quad I_H = 5.795, \quad f = \frac{\pi}{2} \left[ \frac{EI}{W \cdot L^3} \right]^{1/2}$$

$$\Rightarrow f_V = 11.42 \quad f_H = 22.72$$

$$f_L = 67.76 \quad (\text{PAGE 27. ATT. C2 / GENERAL INSTRUCTION})$$

FROM COMPUTER RUN "DRYSAZF"  
FREQUENCY OF FRAME NO. 3

$$f_V = 79.93, \quad f_H = 23.06, \quad f_L = 11.44$$

DIRECTION	TRAY FREQ. $f_T$	FRAME FREQ. $f_F$	SYSTEM FREQ. $f_S$
LONG.	67.76	11.44	11.28
TRAN.	22.72	23.06	16.18
VERT.	11.42	79.93	11.31

$$\star f_S = \left[ \frac{1}{\left\{ \left( \frac{1}{f_T} \right)^2 + \left( \frac{1}{f_F} \right)^2 \right\}} \right]^{1/2}$$

EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 01/06/86

SHEET 26 OF 102

CHKD. BY C.Wu DATE 1/7/86

OFS NO. 3306.021 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT DOMINION PEAK UNIT 2  
CABLE TRAY REVISIONS

SUBJECT ACCEL. LEVEL FOR MODEL "1-A"

BLDGT. ID.	ELV.	DIRECT	1ST. FREQ. f <sub>s</sub>	DBE			SSE						
				f <sub>1</sub>	f <sub>2</sub>	A <sub>1</sub>	A <sub>2</sub>	A <sub>ORE</sub>	f <sub>2</sub>	f <sub>4</sub>	A <sub>3</sub>	A <sub>4</sub>	2 <sup>nd</sup> ASSE
REACTOR (INT.)	860'	L	11.28	11.2	11.9	.61	.61	.61	8.0	11.39	1.34	.84	.854
		V	11.31	7.92	15.72	.92	.92	.92	8.3	15.16	1.18	1.18	1.18
		T	16.18	13.96	40.0	.47	.32	.449	14.83	27.5	.68	.47	.65
REACTOR (INT.)	905.75'	L	11.28	10.64	13.75	1.088	.7	1.0	9.167	13.75	1.807	1.050	1.42
		V	11.31	7.18	15.03	1.328	1.328	1.328	8.076	15.03	1.712	1.712	1.712
		T	16.18	13.75	7.5	.5	.653	13.75	27.5	1.05	.737	.917	
REACTOR (AUX.)	899.5'	L	11.28	10.444	13.212	.968	.89	.944	11.0	12.104	1.184	1.141	1.173
		V	11.31	5.774	12.447	1.631	1.713	1.713	7.601	12.32	1.851	1.851	1.851
		T	16.18	16.148	16.742	.89	.865	.89	16.148	16.742	1.141	1.111	1.139
ELECT.	873.3'	L	11.28	10.49	11.86	.68	.40	.514	10.19	12.32	.93	.60	.781
		V	11.31	9.27	13.7	1.12	1.15	1.15	10.49	13.21	1.5	1.56	1.56
		T	16.18	16.15	16.74	.40	.39	.399	14.91	18.55	.51	.51	.51
SAFGD.	896.5'	L	11.28	11.0	11.65	1.4	1.1	1.27	10.53	11.65	2.01	1.46	1.636
		V	11.31	10.05	13.44	1.31	1.5	1.50	9.24	14.19	1.83	2.01	2.01
		T	16.18	14.66	16.42	.73	.71	.713	14.66	16.42	1.11	1.05	1.058

\*\*  $A_{SSE} = A_2 + (A_4 - A_3) \frac{ln f_3 - ln f_2}{ln f_0 - ln f_2}$

\*  $A_{OBE} = A_1 + (A_2 - A_1) \frac{ln f_3 - ln f_1}{ln f_2 - ln f_1}$

EBASCO SERVICES INCORPORATED

BY C. Li Yeh DATE 1/16/86

SHEET 27 OF 102

CHKD. BY C. Wu DATE 1/16/86  
 TEXAS UTILITIES GENERATING CO.

OFS NO. 3306221 DEPT. NO. 550

CLIENT COMANCHE PEAK UNIT 2

PROJECT CABLE TRAY HANGERS

SUBJECT SYSTEM, FREQ. FOR "2-D" MODEL "1-B"

3b. SYSTEM FREQ. FOR "2-D" MODEL "1-B"

FROM: MODEL "1-B" FRAME NO. 4

$$AV. SPAN = (108 + 95.1) / 2 = 101.55' / 12 = 8.4625'$$

FROM: ATT. C2 / GENERAL INSTRUCTION FOR CTH ANALYSIS  
 PAGE 26. (DATE: 6/14/85)

$$I_V = 1.465, \quad I_H = 5.795, \quad f = \frac{\pi}{2} \left[ \frac{EI}{\frac{W}{g} \times L^4} \right]^{1/2}$$

$$\Rightarrow f_V = 11.42 \quad f_H = 10.43^*$$

$$f_L = 67.76 \quad (\text{PAGE 27. ATT. C2 / GENERAL INSTRUCTION})$$

FROM COMPUTER RUN "DRYUBQV"

FREQUENCY OF FRAME NO. 4:

$$f_V = 87.44, \quad f_H = 20.93, \quad f_L = 11.44$$

DIRECTION	FREQUENCY		
	TRAY ( $f_T$ )	FRAME ( $f_F$ )	** SYSTEM ( $f_S$ )
LONGT.	67.76	11.44	11.28
VERT.	11.42	87.44	11.32
TRAN.	10.43 <sup>+</sup>	20.93	9.34

NOTES:

\* SEE NEXT SHEET.

$$** f_S = \left[ (f_T)^2 + (f_F)^2 \right]^{-0.5}$$

EBASCO SERVICES INCORPORATED

BY C. Wu DATE 1-28-86

SHEET 23 OF 102

CHKD. BY YEH DATE 1-28-86

OFS NO. 3306-221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

SUBJECT 2-D MODEL 1-B Tray frequency in trans. direction

$$L = 24 + 30 \times \sin 45^\circ$$

$$= 45.21''$$

$$M = \frac{45.21}{12} \times 35 = 131.83 \# g$$


$$M = \frac{108 + 24 \times 2 + \pi \times 60 / 4 - 45.21}{12} \times 35$$

$$= 460.51 \# g$$

$$k = \frac{3EI}{L^3} = \frac{3 \times 29 \times 10^6 \times 5.795}{(45.21)^3} = 5455.94 \# / ''$$

$$\omega_n = \sqrt{\frac{k}{M + 0.2311}} = \sqrt{\frac{5455.94 \times 386.4}{460.51 + 0.23 \times 131.83}} = 65.54 \text{ rps}$$

$$f_n = \frac{\omega_n}{2\pi} = \frac{65.54}{2\pi} = 10.43 \text{ Hz}$$



ADDITIONAL MOMENT (APPLIED AT PT ③)

$$M_2 = 460.51 \times 45.21 + \frac{1}{2} \times 131.83 \times 45.21 = 23803 \text{ ''} = 23,803 \text{ ''}$$

FACTOR OF UNEQUAL MOMENT APPLIED EN FRAME NO. 4

$$R = \frac{0.0715 \times 41.75}{23,803 \times 3} = .042$$

$$\therefore M_2 = 23,803 \times .042 = 1.0$$

NOTE: REF. TO COMPUTER RUN I.D. DRYZB9J, THE  $X_1$ -REACTION

DUE TO  $X_3$ -INERTIA FORCE = 0.0715\*

\*\* SEE NEXT PAGE.

EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 01/31/86

SHEET 29 OF 102

CHKD. BY C.Wu DATE 1/31/86


OFS NO. 3306 221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.  
 PROJECT COMANCHE PEAK UNIT 2  
 SUBJECT CABLE TRAY HANGERS

(1.08)  
REACTION COMPARISON FOR 3-D/2-D INERTIA FORCE INPUT

MODEL : 1-B COMPUTER RUN ID \_\_\_\_\_  
 BLDG : ELECT. 3-D: DRYZB9J  
 ELEV : 873.33' 2-D: DRYSCTR

INPUT FORCE	MODEL TYPE	X <sub>1</sub>		X <sub>2</sub>		X <sub>3</sub>	
		401	408	401	408	401	408
X <sub>1</sub>	3-D	-0.0741	-0.0674	-0.0060	.0176	.0141	.0096
	2-D	-0.0730	-0.0685	—	—	—	—
X <sub>2</sub>	3-D	-0.0017	.0017	-0.3119	-0.7033	.0425	-0.0490
	2-D	—	—	-0.3198	-0.7098	.0473	-0.0473
X <sub>3</sub>	3-D	-0.0715	.0715	.9437	-0.9515	-1.629	-1.0066
	2-D	—	—	1.0795	-1.0795	-1.4984	-0.3921



PLAN OF MODEL 1-B



EBASCO SERVICES INCORPORATED

BY C.H. York DATE 01/16/86

SHEET 30 OF 102

CHKD. BY S.O. J... DATE 1/16/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2  
CABLE TRAY HANGERS

SUBJECT ACCL. LEVEL FOR MODEL "1-B"

BLDG. ID.	ELEV.	DIR.	SYS. FREQ. $f_s$	OBE			AORE			SSE			A <sub>4</sub>	A <sub>4</sub> S <sub>SE</sub>
				$f_1$	$f_2$	$A_1$	$A_2$	$A_3$	$f_3$	$f_4$	$A_3$	$A_3$		
REACTOR (INT.)	8600'	L	11.28	11.2	11.9	.61	.61	.61	.61	1.34	1.34	1.34	.84	.854
		V	11.32	7.92	15.22	.92	.92	.92	.92	1.18	1.18	1.18	1.18	1.18
		T	9.34	9.2	11.2	.95	.924	.924	.924	1.34	1.34	1.34	.84	1.121
REACTOR (INT.)	9057.5'	L	11.28	10.64	13.75	1.088	.7	1.0	1.0	1.807	1.807	1.807	1.050	1.42
		V	11.32	7.18	15.03	1.328	1.328	1.328	1.328	1.712	1.712	1.712	1.712	1.712
		T	9.34	8.48	10.64	1.717	1.449	1.449	1.449	1.807	1.807	1.807	1.050	1.772
REACTOR (AUX)	8995'	L	11.28	10.494	13.212	.968	.89	.944	.944	1.184	1.184	1.184	1.141	1.173
		V	11.32	5.724	12.447	1.631	1.713	1.713	1.713	1.851	1.851	1.851	1.851	1.851
		T	9.34	9.273	10.494	1.209	.968	1.195	1.195	1.591	1.591	1.591	1.346	1.577
ELEC.	8733'	L	11.28	10.49	11.86	.68	.40	.514	.514	.93	.93	.93	.60	.781
		V	11.32	9.27	13.7	1.12	1.15	1.15	1.15	1.5	1.5	1.5	1.56	1.56
		T	9.34	9.27	10.49	.83	.68	.821	.821	1.14	1.14	1.14	.93	1.127
SFGD	3965'	L	11.28	11.0	11.65	1.4	1.1	1.27	1.27	2.01	2.01	2.01	1.46	1.636
		V	11.32	10.05	13.44	1.31	1.50	1.50	1.50	1.83	1.83	1.83	2.01	2.01
		T	9.34	8.24	10.08	2.19	2.19	2.19	2.19	2.42	2.42	2.42	2.12	2.357

$$A_{SSE} = A_3 + (A_4 - A_2) \frac{f_{inf5} - f_{inf3}}{f_{inf4} - f_{inf3}}$$

$$A_{OBE} = A_1 + (A_2 - A_1) \frac{f_{inf5} - f_{inf1}}{f_{inf2} - f_{inf1}}$$

NOTES:

EBASCO SERVICES INCORPORATED

BY C. Wu DATE 1-8-86

SHEET 31 OF 102

CHKD. BY C. H. YEH DATE 1-10-86

OFS NO. 3306-221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

COMANCHE PEAK UNIT 2

PROJECT CABLE TRAY HANGERS

SUBJECT MISSING WT. RATIO MODEL 1-A

3C. FREQ. SUMMARY TABLE

1. FREQ. FOR MODEL "1-A" FIXED BOUNDARY

COMPUTER RUN ID: DRYRA53

12-30-85

MODE NO.	FREQUENCY <sub>HZ</sub>	DIRECTION	MODE NO.	FREQUENCY <sub>HZ</sub>	DIRECTION
1	8.28	V	20	21.41	T
2	8.30	V	21	22.09	T
3	8.31	V	22	23.44	T
4	10.36	V	23	24.19	T
5	10.60	V	24	24.86	T
6	10.64	V	25	25.20	T
7	11.80	L	26	26.58	T
8	11.80	L	27	27.79	T
9	11.81	L	28	28.34	T
10	11.81	L	29	28.67	T
11	12.12	V	30	29.44	T
12	12.39	V	31	29.76	V
13	12.44	V	32	29.83	V
14	15.59	V	33	30.03	T
15	15.92	V	34	30.24	V
16	15.97	V	35	31.14	V
17	19.25	V	36	31.48	T
18	19.53	V	37	32.79	V
19	19.57	V	38	32.95	V

Note: L - longitudinal, V - Vertical, T - Transverse

DIRECTION	L	V	T
MODEL WT. TO 33HZ.	5.52356	4.276	5.52356
MISSING WT. RATIO	* 0.328	† 0.352	* 0.328

\*  $1 - \frac{5.52356}{8.2213} = 0.328$ ,      †  $1 - \frac{4.276}{6.5953} = 0.352$

EBASCO SERVICES INCORPORATED

BY C. H. Yeh DATE 01/10/86

SHEET 32 OF 102

CHKD. BY C. Wu DATE 1/13/86

OFS NO. 3306221 DEPT. NO. 550

CLIENT TELEPHONE COMPANY GENERATING CO

PROJECT CABLE TRAY HANGERS

SUBJECT MISSING WT. RATIO MODEL. 1-B

2. FREQUENCY FOR MODEL 1B, FIXED BOUNDARY

COMPUTER RUN ID: DRYTBNZ  
DATE = 01/03/85

MODE NO.	FREQUENCY Hz	DIRECTION	MODE NO.	FREQUENCY Hz	DIRECTION
1	8.07	V	21	19.48	V
2	8.08	V	22	19.70	V
3	8.08	V	23	19.74	V
4	8.63	L	24	20.72	T
5	9.96	V	25	21.10	T
6	10.15	V	26	23.02	T
7	10.54	V	27	23.57	T
8	10.96	V	28	25.13	T
9	11.06	V	29	25.34	T
10	11.80	L	30	26.15	T
11	11.80	L	31	26.77	T
12	11.81	L	32	28.13	T
13	11.81	L	33	29.23	T
14	11.81	L	34	29.79	V
15	12.78	V	35	29.81	V
16	12.90	V	36	29.84	V
17	12.93	V	37	30.07	T
18	15.99	V	38	31.53	T
19	16.17	V	39	32.72	V
20	16.20	V	40	32.85	V

ITEM NO.		WEIGHT		
		LONG.	VERT.	TRAN.
①	MODEL. WT. TO 33 Hz	5.3055	3.73555	4.17533
②	TOTAL. MODEL. WT	6.9724	6.5014	6.0274
③	MISSING WT. RATIO	23.9%	42.54%	30.68%

MISSING WT. RATIO =  $1 - \frac{\text{① WT.}}{\text{② WT.}}$

EBASCO SERVICES INCORPORATED

BY Z. H. ... DATE 1/12/86

NEW YORK

SHEET 33 OF 102

CHKD. BY YEH DATE 1/31/86

OFS NO. 3306221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.  
 PROJECT COMANCHE PEAK UNIT 2  
 SUBJECT CABLE TRAY HANGERS

4 RESPONSE SPECTRA ANALYSIS and MRM for "g"

The frequency response analyses were performed through STADYNE'S DYNRE4 computer code. The directional effects of seismic excitation in three orthogonal directions were combined by SRSS approach. However, the <sup>modal</sup> combinations were carried out through several options available in the DYNRE4 program.

The model 1-A under seismic OBE at the reactor building elevation 860' was studied first. The results for various modal combination options were summarized on Table. The results confirmed ~~through~~ the complete quadratic combination (CQC) method ( $RSS=14$ ) that the previous study of the straight run used the appropriate option ( $RSS=1$ ), and the 10% correction ( $RSS=6$ ) overestimated

EBASCO SERVICES INCORPORATED

BY I H CHOU DATE 1/17/86

SHEET 34 OF 102

CHKD. BY YSH DATE 1/31/86

OFS NO. 3306.221 DEPT. NO. 530

CLIENT TEXAS UTILITIES GENERATING CO.  
 PROJECT COMANCHE PEAK UNIT 2  
 SUBJECT CABLE TRAY HANGERS

DYNRE4 OPTION	VERT.	TRANS.	LONG.	RUN ID	
RSS = 6	0.879	1.129	1.384	DRYUD QF	RSS WITH 10%.
RSS = 14 IRSSX1 = 1	0.731	0.704	0.935	DRYUD ZF	CRC WITH RSS ON DIRE
RSS = 1	0.721	0.793	0.890	DRYSB P3	RSS WITHOUT 10%.
RSS = 14 IRSSX1 = 10	0.527	0.801	0.831	DRYUD ZJ	CRC WITH ALG ON DIRE

MRM COMPARISON BETWEEN OPTIONS IN DYNRE 4

MODEL 1-A  
 SEISMIC OBE, REACTOR INTERNAL 860' EL

## EBASCO SERVICES INCORPORATED

NEW YORK

BY Z H CHOU DATE 1/17/86SHEET 35 OF 102CHKD. BY YELI DATE 1/31/86OFS NO. 3306.221 DEPT. NO. 530

CLIENT TEXAS UTILITIES GENERATING CO.  
 PROJECT COMANCHE PEAK UNIT 2  
 SUBJECT CABLE TRAY HANGERS

The structural response by a large margin.  
~~However~~, further confirmation of the usage  
 of option (RSS = 1) by the time history  
 approach as performed in the previous ~~straight~~  
 run study was ~~not presented~~ presented in section 6.

However, for illustrative purposes, all  
 three options (RSS = 6, RSS = 14 with 1RSSX1 = 1,  
 and RSS = 1) were performed for all the  
 cases. In addition, RSS = 14 with 1RSSX1 = 10  
 was also performed for the pilot case -  
 Model 1-A, OBE REACTOR INTERNAL 830' EL. as  
 shown on ~~Page~~ page 34. It was found that  
 the algebraic summation for directional effect  
 might yield erroneous results.

EBASCO SERVICES INCORPORATED

BY C. Wu DATE 1-17-86

SHEET 36 OF 102

CHKD. BY CH. 1/21 DATE 1-21-86  
 TEXAS UTILITIES GENERATING CO.

OFS NO. 3306-221 DEPT. 550  
 NO. 550

CLIENT COMANCHE PEAK UNIT 2

PROJECT CABLE TRAY HANGERS

SUBJECT MULTIPLE RESPONSE MULTIPLIER FOR C.T.H. SYSTEM W/90° BENT (RSS=6)

MODEL	BUILDING	ELEVATION (FT)	RANGE OF AMPLIFICATION FACTOR							
			OBE (4%)				SSE (7%)			
			VERT.	TRANS.	LONG.	RUN ID	VERT.	TRANS.	LONG.	RUN ID
1A	REACTOR INTERNAL	860.00*	0.88	1.13	1.38	DRYUDRF	0.92	1.05	1.33	DRYUDV7
	REACTOR INTERNAL	905.75	0.93	1.11	1.26	DRYUDWN	0.98	1.09	1.26	DRYUDW7
	REACTOR AUXILIARY	899.50	0.64	0.69	1.33	DRYUDXJ	0.80	0.82	1.36	DRYUDX3
	ELECTRICAL	873.33	0.86	1.10	1.17	DRYUDYB	0.85	1.23	1.23	DRYUDYN
	SAFE GUARD	896.50	0.90	1.05	1.13	DRYUDZB	0.90	0.98	1.19	DRYUDZF
1B	REACTOR INTERNAL	860.00*	0.88	0.60	1.21	DRYVBPR	0.92	0.65	1.16	DRYVBP3
	REACTOR INTERNAL	905.75	0.94	0.58	1.11	DRYVBQW	0.98	0.65	1.10	DRYVBRB
	REACTOR AUXILIARY	899.50	0.66	0.61	1.15	DRYVBRJ	0.79	0.65	1.19	DRYVBR3
	ELECTRICAL	873.33	0.86	0.62	1.04	DRYVBSE	0.85	0.63	1.08	DRYVBSR
	SAFE GUARD	896.50	0.89	0.46	1.00	DRYVESV	0.88	0.53	1.04	DRYVBS7

\* THE FLOOR ELEVATION WHERE THE HANGER FOR STRUCTURAL MODEL IS LOCATED.

\*\* M.R.M. RESULTS FOR CABLE TRAY HANGER SYSTEM WITH 90° BENT

\*\*\* MRM SUMMARY FOR "RSS=6"

EBASCO SERVICES INCORPORATED

BY C.Wu DATE 1-17-86

SHEET 37 OF 102

CHKD. BY C.W. VEH DATE 1-21-86  
 CLIENT TEXAS UTILITIES GENERATING CO.  
COMANCHE PEAK UNIT 2

OFS NO. 3306-221 DEPT. NO. 550

PROJECT CABLE TRAY HANGERS  
 SUBJECT MULTIPLE RESPONSE MULTIPLIER FOR C.T.H. SYSTEM W/90° BENT (RSS=14)

MODEL	BUILDING	ELEVATION (FT)	RANGE OF AMPLIFICATION FACTOR							
			OBE (4%)				SSE (7%)			
			VERT.	TRANS.	LONG.	RUN ID	VERT.	TRANS.	LONG.	RUN ID
1A	REACTOR	860.00*	0.73	0.70	0.94	DRYUDZF	0.77	0.66	0.91	DRYUEGF
	INTERNAL	905.75	0.78	0.70	0.85	DRYUEG3	0.82	0.68	0.86	DRYUEHT
	REACTOR	899.50	0.53	0.43	0.88	DRYUEIB	0.66	0.52	0.92	DRYUEIT
	AUXILIARY	873.33	0.71	0.68	0.72	DRYUEIV	0.70	0.76	0.79	DRYUEJ
	ELECTRICAL	896.50	0.74	0.64	0.76	DRYUEJF	0.74	0.60	0.81	DRYUEJV
1B	REACTOR	860.00*	0.70	0.45	0.68	DRYVBGF	0.74	0.49	0.65	DRYVBJ
	INTERNAL	905.75	0.75	0.44	0.63	DRYVB33	0.79	0.49	0.62	DRYVBKN
	REACTOR	899.50	0.52	0.46	0.63	DRYVBKV	0.63	0.49	0.66	DRYVB311
	AUXILIARY	873.33	0.68	0.46	0.63	DRYVBMM	0.68	0.46	0.62	DRYVBNB
	ELECTRICAL	896.50	0.70	0.35	0.56	DRYVBNR	0.70	0.40	0.58	DRYOA5R

\* THE FLOOR ELEVATION WHERE THE HANGER FOR STRUCTURAL MODEL IS LOCATED.  
 RSS = 14

IRSSX1 = 1

\*\* M.R.M. RESULTS FOR CABLE TRAY HANGER SYSTEM WITH 90° BENT

\*\*\* MRM SUMMARY FOR "RSS=14", IRSSX1=1



EBASCO SERVICES INCORPORATED

BY C.Wu DATE 1-9-86

SHEET 33 OF 102

CHKD. BY YEH DATE 1-13-86

OFS NO. 3306-221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2  
CABLE TRAY HANGERS

SUBJECT MULTIPLE RESPONSE MULTIPLIER FOR C.T.H. SYSTEM W/90° BENT (RSS=1)

TABLE 4-3 MRM FOR RSS=1

MODEL	BUILDING	FLOOR ELEVATION (FT)	RANGE OF AMPLIFICATION FACTOR							
			OBE (4%)				SSE (7%)			
			VERT.	TRANS.	LONG.	RUN ID	VERT.	TRANS.	LONG.	RUN ID
1A	REACTOR INTERNAL	860.00	0.72*	0.79*	0.90*	DRYSBP3	0.76	0.75	0.87	DRYSDYZ
		905.75	0.77	0.79	0.82	DRYSD47	0.81	0.77	0.82	DRYSD6Z
	REACTOR AUXILIARY	899.50	0.52	0.49	0.85	DRYVC2N	0.65	0.58	0.89	DRYSD9F
	ELECTRICAL	873.33	0.70	0.78	0.77	DRYSEAF	0.70	0.88	0.80	DRYSEAV
	SAFE GUARD	896.50	0.73	0.73	0.71	DRYVC23	0.73	0.69	0.76	DRYSEBJ
1B	REACTOR INTERNAL	860.00	0.69	0.47	0.95	DRYVCRR	0.73	0.51	0.91	DRYVCRZ
		905.75	0.74	0.47	0.87	DRYVCR3	0.78	0.51	0.86	DRYVCSB
	REACTOR AUXILIARY	899.50	0.51	0.48	0.90	DRYVCKN	0.62	0.51	0.93	DRYVCSN
	ELECTRICAL	873.33	0.67	0.49	0.83	DRYVCSR	0.67	0.49	0.85	DRYUDQZ
	SAFE GUARD	896.50	0.69	0.37	0.79	DRYVCST	0.69	0.42	0.81	DRYVCTF

NOTES:

- ① MRM SUMMARY FOR RSS=1
- ② FL. ELEV. WHERE THE HANGER STRUCTURAL MODEL IS LOCATED
- ③ MRM RESULTS FOR CABLE TRAY HANGER SYST. W/ 90° BENT
- \*. SEE ALSO NEXT 3 PAGES.

BLDG: REACTOR (INTER)

ELE 660-0

DIRECTION: VERT. OPE 4%, FIXED BOUNDARY,

COMPUTER RUN ID = DRYSAUN

WEIGHT	TRAY												SUPPORT				
	UPPER				MIDDLE				LOWER				WEIGHT	NODE	a	FM*	a <sub>T</sub>
	NODE	a	FM*	a <sub>T</sub>	NODE	a	FM*	a <sub>T</sub>	NODE	a	FM*	a <sub>T</sub>					
0.039	7	.762	0.0	.762	37	1.095	0.0	1.095	67	1.219	0.0	1.219	0.021	302	.002	.999	.39
0.079	8	.428	.231	.437	38	.60	.347	.615	68	.693	.321	.704	0.021	303	.004	.998	.389
0.074	9	.019	.968	.378	39	.026	.971	.38	69	.031	.962	.376	0.015	304	.004	.997	.389
0.052	10	.543	.379	.563	40	.696	.390	.712	70	.792	.382	.806	0.013	305	.019	.968	.378
0.034	11	.826	0.0	.826	41	1.103	0.0	1.103	71	1.282	0.0	1.282	0.013	306	.026	.971	.38
0.017	12	.923	0.0	.923	42	1.261	0.0	1.261	72	1.496	0.0	1.496	0.013	307	.031	.962	.376
													0.014	309	.003	.995	.388
													0.014	310	.006	.991	.387
													0.009	311	.007	.989	.386

\* FM - MISSING WEIGHT RATIO

TOTAL ACC.  $a_T = \sqrt{a^2 + (FM \cdot ZPA)^2}$ ,

ZPA = 0.39

TRAY  $\sum W_i = .885$   $\sum W_i a_{Ti} = .623$   
 SUPPORT  $\sum W_i = .133$   $\sum W_i a_{Ti} = .051$   
 $\sum W = 1.018$   $\sum W a_T = .614$   
 $\left. \begin{array}{l} \sum W_i a_{Ti} \\ \sum W_i \end{array} \right\} \text{ave } g = \frac{\sum W_i a_{Ti}}{\sum W_i} = .662$

PREVIOUS DESIGN PROCEDURE SYSTEM FREQ. = 11.31 ACC. LEVEL = .92

MULTIPLE-MODE RESPONSE MULTIPLIER  $M R M = \frac{\text{ave } g}{\text{ACC. LEVEL}} = \frac{.662}{.92} = .72$

BY C. W. J. U. DATE 12-31-85  
 CHKD. BY Yell DATE 12/31/85  
 CLIENT \_\_\_\_\_  
 PROJECT \_\_\_\_\_  
 SUBJECT \_\_\_\_\_  
 COMMANDER PEAK UNIT 2  
 CABLE TRAY HANGERS  
 P55 = L  
 SHEET 39 OF 102  
 DEPT. 550  
 OFS NO. TUGC 3306.221

EBASCO SERVICES INCORPORATED

BLDG: INTER STRUCTURE ELE 860'-0  
 DIRECTION: TRNS. OBE 4%, FIXED BOUNDARY,

COMPUTER RUN ID = DRYSAUN

WEIGHT	TRAY												SUPPORT				
	UPPER				MIDDLE				LOWER				WEIGHT	NODE	a	FM*	aT
	NODE	a	FM*	aT	NODE	a	FM*	aT	NODE	a	FM*	aT					
0.039	7	.54	.577	.57	37	.564	.047	.564	67	.854	0.0	.854	0.021	302	.053	.82	.268
0.079	8	.354	.736	.425	38	.407	.233	.414	68	.634	0.0	.634	0.021	303	.151	.508	.222
0.074	9	.058	.804	.264	39	.156	.488	.221	69	.24	.244	.252	0.015	304	.232	.266	.247
0.052	10	.164	.473	.223	40	.262	.333	.283	70	.227	.154	.232	0.013	305	.054	.816	.267
0.034	11	.209	.289	.229	41	.314	.22	.322	71	.269	.046	.269	0.013	306	.153	.502	.222
0.017	12	.228	.167	.234	42	.334	.144	.337	72	.289	0.0	.289	0.013	307	.234	.261	.248
													0.014	309	.054	.817	.267
													0.014	310	.153	.502	.222
													0.009	311	.233	.264	.248

\* FM - MISSING WEIGHT RATIO

TOTAL ACC.  $a_T = \sqrt{a^2 + (FM \cdot ZPA)^2}$ ,  $ZPA = 0.32$

TRAY  $\sum W_i = 0.895$   $\sum W_i a_{Ti} = .329$   
 SUPPORT  $\sum W_i = 0.133$   $\sum W_i a_{Ti} = .033$  }  $ave g = \frac{\sum W_i a_{Ti}}{\sum W_i} = .356$

PREVIOUS DESIGN PROCEDURE SYSTEM FREQ. = 16.18 ACC. LEVEL = .449

MULTIPLE-MODE RESPONSE MULTIPLIER  $M R M = \frac{ave g}{ACC. LEVEL} = \frac{.356}{.449} = .793$

BY C. W. U. DATE 12-31-85  
 CHKD. BY Y. L. DATE 12/31/85  
 CLIENT LEWIS & CLARK ENGINEERING CO.  
 PROJECT COMANCHE PEAK UNIT 2  
 SUBJECT CABLE TRAY HANGERS  
 ESI = 4  
 SHEET 40 OF 102  
 DEPT. 550  
 OFS NO. TUG 6306.221 NO. 550

EBASCO SERVICES INCORPORATED

BY C. W. H. DATE 12-31-85  
 CHKD. BY YEH DATE 12-31-85  
 OFS NO. TUGC 3306.221 DEPT. 550

CLIENT TEXAS UTILITIES GENERATING CO.  
 PROJECT COMANCHE PEAK UNIT 2  
 SUBJECT CABLE TRAY HANGERS

RSS = 1

COMPUTER RUN ID = DRYSALUN

BLDG : INTER STRUCTURE EL 860'-0  
 DIRECTION: LONG. OBE 4 %, FIXED BOUNDARY

WEIGHT	TRAY												SUPPORT				
	UPPER				MIDDLE				LOWER				WEIGHT	NODE	a	FM*	AT
	NODE	a	FM*	AT	NODE	a	FM*	AT	NODE	a	FM*	AT					
	7				37				67				0.021	302	.136	.776	.283
	8				38				68				0.021	303	.495	.212	.50
	9				39				69				0.015	304	.912	0.0	.912
	10				40				70				0.013	305	.146	.777	.288
	11				41				71				0.013	306	.503	.271	.51
	12				42				72				0.013	307	.928	0.0	.928
													0.014	309	.145	.838	.305
													0.014	310	.519	.34	.53
													0.009	311	.95	0.0	.95

\* FM - MISSING WEIGHT RATIO

TOTAL ACC.  $a_T = \sqrt{a^2 + (FM \cdot ZPA)^2}$ , ZPA = 0.32

TRAY  $\sum W_i = 0$   $\sum W_i a_{Ti} = 0$   
 SUPPORT  $\sum W_i = 0.133$   $\sum W_i a_{Ti} = 0.73$  }  $ave g = \frac{\sum W_i a_{Ti}}{\sum W_i} = \frac{0.73}{0.133} = .547$

PREVIOUS DESIGN PROCEDURE SYSTEM FREQ. = 11.78 ACC. LEVEL = .61

MULTIPLE-MODE RESPONSE MULTIPLIER  $M R M = \frac{ave g}{ACC. LEVEL} = \frac{.547}{.61} = .897$

201/8-1

## EBASCO SERVICES INCORPORATED

NEW YORK

BY Z H CHOU DATE 1/23/86SHEET 42 OF 102CHKD. BY YEH DATE 1/31/85OFS NO. 3306.221 DEPT. 550CLIENT TEXAS UTILITIES GENERATING CO.PROJECT COMANCHE PEAK UNIT 2SUBJECT CABLE TRAY HANGERS5. REACTIONS & MRM

The comparison between the cable tray-hanger system and the one frame hanger with concentrated cable weight at the tier was performed.

The static analysis for the one frame hanger was straight forward, with the acceleration levels obtained through system frequency and corresponding <sup>floor</sup> response spectrum. However, the analysis for the cable tray-hanger system needs further consideration.

Since the STARDYNE'S "DYNET4" codes combined the structural responses up to the frequency defined (in our study,  $33^{Hz}$ ), the remaining contribution due to higher modes was obtained through the calculation of missing weight with a rigid mode.

## EBASCO SERVICES INCORPORATED

NEW YORK

BY Z H CHOU DATE 1/23/56SHEET 43 OF 102CHKD. BY Y E I DATE 1/31/56OFS NO. 3306.221 DEPT. NO. 550CLIENT TEXAS UTILITIES GENERATING CO.PROJECT COMANCHE PEAK UNIT 2SUBJECT CABLE TRAY HANGERS

The tabulation of the missing weight for models 1-A & 1-B was first completed from the computer run for the missing weight ratio through the residual load method.

The reactions were then obtained through "POST" code in STARDYNE system to perform SRSS in three directions. These results were added to DYNRE4 reactions ~~and~~ to complete the dynamic analysis.

The MRMS for the reactions ~~were~~ summarized in ~~Table~~ on page 68.

It was noted that the <sup>MRM</sup> values for the reactions were relatively smaller <sup>than</sup> ~~than~~ those for the "j"s, because the conservative assumption in the latter case that all modes were acting in the same phase.

EBASCO SERVICES INCORPORATED

BY I H CHEW DATE 1/23/86  
 CHKD. BY YEH DATE 1/31/86

SHEET 44 OF 102  
 OFS NO. 3306-221 DEPT. NO. 550

CLIENT \_\_\_\_\_  
 PROJECT \_\_\_\_\_ TEXAS UTILITIES GENERATING CO.  
 \_\_\_\_\_ COMANCHE PEAK UNIT 2  
 SUBJECT \_\_\_\_\_ CABLE TRAY HANGERS

It was found that the contribution due to missing weight is less than 10% for the support reactions. In some cases, almost no contribution at all. This is due to the fact that the support weight is relatively small compared to the tray weight.

EBASCO SERVICES INCORPORATED

BY C.H. York DATE 01/23/86

SHEET 45 OF 102

CHKD. BY C.W.V. DATE 1/23/86

OFFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

SUBJECT MODEL '1-A'

MISSING WT OF MODEL "1-A" COMPUTER RUN I.D  
 NODAL WT: DRY RA53  
 MISS. RATIO: DRY IDWV

NODE ID	NODAL WEIGHTS	X <sub>1</sub>		X <sub>2</sub>		X <sub>3</sub>	
		MISSING RATIO	MISS. WT.	MISSING RATIO	MISS. WT.	MISSING RATIO	MISS. WT.
1	.7394 (V1) .1974 (V2.3)	.324	.2396	.619	.1222	.978	.1931
2	.0788	.283	.0223	—	—	.905	.0713
3	=	.247	.0195	—	—	.868	.0684
4	=	.214	.0169	.318	.0251	.847	.0667
5	=	.185	.0146	.969	.0764	.783	.0617
6	=	.162	.0128	.245	.0193	.610	.0481
7	=	.142	.0112	—	—	.577	.0455
8	=	.127	.0100	.231	.0182	.736	.0580
9	.0744	.117	.0087	.968	.0720	.804	.0598
10	.0521	.113	.0059	.379	.0197	.473	.0246
11	.0341	.118	.0040	—	—	.289	.0099
12	.0342	.167	.0057	—	—	.167	.0057
13	.0341	.289	.0099	—	—	.118	.0040
14	.0521	.473	.0246	.379	.0197	.113	.0059
15	.0744	.804	.0598	.968	.072	.117	.0087
16	.0788	.736	.0580	.231	.0182	.127	.010
17	=	.577	.0455	—	—	.142	.0112
18	=	.610	.0481	.245	.0193	.162	.0128
19	=	.783	.0617	.969	.0764	.185	.0146
20	=	.847	.0667	.318	.0251	.214	.0169



**EBASCO SERVICES INCORPORATED**

BY C H yek DATE 01/23/86

SHEET 46 OF 102

CHKD. BY C.Wu DATE 1/23/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO

PROJECT COMANCHE PEAK UNIT 2  
CABLE TRAY HANGERS

SUBJECT MODEL "1-A"

MISSING WT OF MODEL 1-A				COMPUTER RUN I.D			
				NODAL WT: DRY RA53			
				MISS. RATIO: DRY IDWV			
NODE ID	NODAL WEIGHTS	X <sub>1</sub>		X <sub>2</sub>		X <sub>3</sub>	
		MISSING RATIO	MISS. WT.	MISSING RATIO	MISS. WT.	MISSING RATIO	MISS. WT.
21	.0788	.868	.0684	—	—	.247	.0195
22	=	.905	.0713	—	—	.283	.0223
23	.1474 (X1,2) .7394 (X2)	.978	.1931	.619	.1222	.324	.2396
31	.7394 (X1) .1272 (X2)	.323	.2388	.183	.0361	.964	.1903
32	.0788	.284	.0224	—	—	.361	.0234
33	=	.248	.0195	—	—	—	—
34	=	.215	.0169	.631	.0497	.116	.0091
35	=	.187	.0147	.976	.0769	.389	.0307
36	=	.163	.0128	.192	.0151	.195	.0154
37	=	.143	.0113	—	—	.047	.0037
38	=	.128	.0101	.347	.0273	.233	.0184
39	.0744	.117	.0087	.971	.0722	.483	.0363
40	.0521	.112	.0058	.390	.0203	.333	.0173
41	.0341	.114	.0039	—	—	.270	.0075
42	.0342	.144	.0049	—	—	.144	.0049
43	.0341	.220	.0075	—	—	.114	.0039
44	.0521	.333	.0173	.390	.0203	.112	.0058
45	.0744	.488	.0363	.971	.0722	.117	.0087
46	.0788	.233	.0184	.347	.0273	.128	.0101
47	=	.047	.0037	—	—	.143	.0113
			.796		.510		.683

EBASCO SERVICES INCORPORATED

BY C.H. Gier DATE 01/23/86

SHEET 47 OF 102

CHKD. BY C. Wu DATE 1/23/86

OFFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO

PROJECT COMANCHE PEAK UNIT 2  
CABLE TRAY HANGERS

SUBJECT MODEL. 1-A

MISSING WT OF MODEL "1-A"		COMPUTER RUN I.D					
		X1		X2		X3	
NODE ID	NODAL WEIGHTS	MISSING RATIO	MISS. WT.	MISSING RATIO	MISS. WT.	MISSING RATIO	MISS. WT.
48	.0788	.195	.0154	.192	.0151	.163	.0128
49	=	.389	.0307	.976	.0769	.187	.0147
50	=	.116	.0091	.631	.0497	.215	.0169
51	=	—	—	—	—	.248	.0195
52	=	.361	.0284	—	—	.234	.0224
53	.1974 (X1,2) .7394 (X3)	.964	.1903	.183	.0361	.323	.2388
61	.7394 (X1) .1974 (X2,2)	.153	.1131	.164	.0324	.978	.1931
62	.0788	.117	.0092	—	—	.050	.0039
63	=	.084	.0066	—	—	—	—
64	=	.054	.0043	.552	.0435	—	—
65	=	.029	.0023	.963	.0759	.084	.0066
66	=	.008	.0006	.195	.0154	—	—
67	=	—	—	—	—	—	—
68	=	—	—	.321	.0253	—	—
69	.0744	—	—	.962	.0716	.244	.0182
70	.0521	—	—	.382	.0199	.154	.0080
71	.0341	—	—	—	—	.046	.0016
72	.0342	—	—	—	—	—	—
73	.0341	.046	.0016	—	—	—	—
74	.0521	.154	.0080	.382	.0199	—	—
		.420		.4812		.557	

**EBASCO SERVICES INCORPORATED**

BY C.H. Yeh DATE 01/23/86

SHEET 08 OF 102

CHKD. BY C.W.M DATE 1/23/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO

PROJECT COMANCHE PEAK UNIT 2  
CABLE TRAY HANGERS

SUBJECT MODEL. 1-A

		COMPUTER RUN I.D					
<u>MISSING WT OF MODEL. 1-A</u>		NODAL WT: <u>DRYRA53</u>					
		MISS. RATIO: <u>DRYIDWV</u>					
NODE ID	NODAL WEIGHTS	X1		X2		X3	
		MISSING RATIO	MISS. WT.	MISSING RATIO	MISS. WT.	MISSING RATIO	MISS. WT.
75	.0744	.244	.0182	.962	.0716	—	—
76	.0788	—	—	.321	.0253	—	—
77	=	—	—	—	—	—	—
78	=	—	—	.195	.0154	.008	.0006
79	=	.034	.0066	.963	.0759	.029	.0023
80	=	—	—	.552	.0435	.054	.0043
81	=	—	—	—	—	.084	.0066
82	=	.050	.0039	—	—	.117	.0092
83	.1474 (X1.2) .7394 (X3)	.978	.1931	.164	.0324	.153	.113
104	.0490	.854	.0418	.751	.0368	.998	.0489
105	.0344	.822	.0283	.305	.0105	.998	.0343
106	.0344	.834	.0287	.289	.0099	.999	.0244
107	.0078	.677	.0053	.619	.0048	.993	.0078
108	.0020	.665	.0013	.183	.0004	.998	.0020
109	.0020	.725	.0015	.164	.0003	.999	.0020
202	.0207	.866	.0179	.999	.0207	.795	.0165
203	.0209	.485	.0101	.998	.0209	.415	.0087
204	.0145	.021	.0003	.998	.0143	.112	.0017
205	.0126	.760	.0096	.969	.0122	.792	.010
206	=	.139	.0018	.976	.0123	.407	.0051

**EBASCO SERVICES INCORPORATED**

BY C.H. Yeh DATE 01/23/86

SHEET 49 OF 102

CHKD. BY C.Wu DATE 1/24/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO

PROJECT COMANCHE PEAK UNIT 2  
CABLE TRAY HANGERS

SUBJECT MODEL. 1-A

		COMPUTER RUN I.D					
<u>MISSING WT OF MODEL. 1-A</u>		NODAL WT: DRY RASS					
		MISS. RATIO: DRY IDWV					
NODE ID	NODAL WEIGHTS	X <sub>1</sub>		X <sub>2</sub>		X <sub>3</sub>	
		MISSING RATIO	MISS. WT.	MISSING RATIO	MISS. WT.	MISSING RATIO	MISS. WT.
207	.0126	—	—	.963	.0121	.106	.0013
209	.0140	.758	.0106	.994	.0139	.792	.0111
210	.0142	.118	.0017	.991	.0141	.407	.0058
211	.0087	—	—	.939	.0086	.110	.0010
302	.0207	.776	.0161	.999	.0207	.820	.017
303	.0209	.212	.0044	.998	.0209	.503	.0106
304	.0148	—	—	.997	.0148	.265	.0039
305	.0126	.777	.0098	.968	.0122	.816	.0103
306	=	.271	.0034	.971	.0122	.502	.0063
307	=	—	—	.962	.0121	.261	.0033
309	.0140	.838	.0117	.995	.0139	.817	.0114
310	.0142	.340	.0048	.991	.0141	.502	.0071
311	.0087	—	—	.989	.0086	.264	.0023
402	.0207	.820	.0170	.999	.0207	.776	.0161
403	.0209	.503	.0106	.998	.0209	.212	.0044
404	.0148	.265	.0039	.997	.0148	—	—
405	.0126	.816	.0103	.968	.0122	.777	.0098
406	=	.502	.0063	.971	.0122	.271	.0034
407	=	.261	.0033	.962	.0121	—	—
409	.0140	.817	.0114	.995	.0139	.838	.0117

EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 01/23/86

SHEET 50 OF 102

CHKD. BY C.W.U DATE 1/24/86

OFS NO. 3306.221 DEPT. NO. 55C

CLIENT TEXAS UTILITIES GENERATING CO

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

MODEL. 1-A

MISSING WT OF MODEL. 1-A								COMPUTER RUN ID	
								NODAL WT: DRY RAS3	
								MISS. RATIO: DRY IDWV	
NODE ID	NODAL WEIGHTS	X <sub>1</sub>		X <sub>2</sub>		X <sub>3</sub>			
		MISSING RATIO	MISS. WT.	MISSING RATIO	MISS. WT.	MISSING RATIO	MISS. WT.		
410	.0142	.502	.0071	.991	.041	.340	.0048		
411	.0087	.264	.0023	.989	.0086	—	—		
502	.0207	.795	.0165	.999	.0207	.866	.0179		
503	.0209	.415	.0087	.998	.0209	.485	.0101		
504	.0148	.112	.0017	.998	.0148	.021	.0003		
505	.0126	.792	.010	.969	.0122	.760	.0296		
506	=	.407	.0051	.976	.0123	.139	.0013		
507	=	.106	.0013	.963	.0121	—	—		
509	.0140	.792	.0111	.994	.0139	.758	.0106		
510	.0142	.407	.0058	.991	.0141	.118	.0017		
511	.0087	.110	.0010	.989	.0086	—	—		
604	.0490	.998	.0489	.751	.0368	.854	.0418		
605	.0344	.998	.0343	.305	.0105	.822	.0283		
606	=	.999	.0344	.289	.0099	.834	.0287		
607	.0078	.998	.0078	.619	.0048	.677	.0053		
608	.0020	.998	.0020	.183	.0004	.665	.0013		
609	=	.999	.0020	.164	.0003	.725	.0015		

**EBASCO SERVICES INCORPORATED**

BY C.H. Yeh DATE 01/22/86

SHEET 51 OF 102

CHKD. BY C.W.H. DATE 1/22/86

CFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO

PROJECT COMANCHE PEAK UNIT 2  
CABLE TRAY HANGERS

SUBJECT MODEL "1-B"

MISSING WT OF MODEL "1-B"				COMPUTER RUN ID			
				NODAL WT: DRYTBNZ (01/86)			
				MISS. RATIO: DCLIC9Z (01/86)			
NODE ID	NODAL WEIGHTS	X1		Y2		X3	
		MISSING RATIO	MISS. WT.	MISSING RATIO	MISS. WT.	MISSING RATIO	MISS. WT.
1	.35438 (X1) .19733 (X2,3)	.3721	.1319	.6865	.1355	.9940	.1962
2	.078759	.3155	.0249	—	—	.8332	.0657
3	=	.2624	.0207	—	—	.6815	.0537
4	=	.2129	.0168	.3525	.0278	.6833	.0539
5	=	.1673	.0132	.9633	.0763	.7821	.0616
6	=	.1260	.0099	.2145	.0169	.7902	.0622
7	=	.0890	.0070	—	—	.7903	.0622
8	=	.0568	.0045	.2636	.0208	.8120	.0640
9	=	.0293	.0023	.9607	.0757	.7352	.0618
10	=	.0067	.0005	.2360	.0186	.6175	.0486
11	=	—	—	—	—	.5779	.0455
12	=	—	—	.2600	.0205	.7413	.0584
13	.074333	—	—	.9651	.0718	.3160	.0607
14	.052074	—	—	.3112	.0162	.4494	.0234
15	.034145	—	—	—	—	.2326	.0079
16	.034149	.0148	.0005	—	—	.0869	.0030
17	.034145	.1729	.0059	—	—	.0301	.0010
18	.052074	.4224	.022	.4595	.0239	.0240	.0013
19	.074333	.772	.0574	.9786	.0728	.0206	.0015
20	.078759	.2463	.0194	.4276	.0337	.0177	.0014

EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 01/22/86

SHEET 52 OF 102

CHKD. BY C.Wu DATE 1/22/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO  
COMANCHE PEAK UNIT 2

PROJECT CABLE TRAY HANGERS

SUBJECT MODEL. 1-B

MISSING WT OF MODEL. 1-B		COMPUTER RUN I.D					
		NODAL WT: DRYTBHZ (01/86)					
		MISS. RATIO:					
NODE ID	NODAL WEIGHTS	X <sub>1</sub>		X <sub>2</sub>		X <sub>3</sub>	
		MISSING RATIO	MISS. WT.	MISSING RATIO	MISS. WT.	MISSING RATIO	MISS. WT.
21	.078759	—	—	—	—	.0155	.0012
22	=	.0126	.0010	—	—	.0142	.0011
23	.19738 (X1,2) .039379 (X3)	.9143	.1805	.9927	.1959	.0138	.0005
31	.35438 (X1) .19758 (X2,3)	.3579	.1268	.2038	.0402	.9380	.1950
32	.078759	.2971	.0234	—	—	.3487	.0275
33	=	.2395	.0189	—	—	—	—
34	=	.1856	.0146	.6595	.0520	.0995	.0078
35	=	.1355	.0107	.9741	.0767	.3356	.0304
36	=	.0977	.0071	.1551	.0122	.1717	.0135
37	=	.0433	.0038	—	—	.0558	.0005
38	=	.0116	.0009	.3807	.030	.1864	.0147
39	=	—	—	.9674	.0758	.4013	.0316
40	=	—	—	.2315	.0182	.0991	.0077
41	=	—	—	—	—	—	—
42	=	—	—	.2937	.0231	.1748	.0138
43	.074383	—	—	.9656	.0718	.5246	.0390
44	.052074	—	—	.3574	.0186	.3258	.017
45	.034145	—	—	—	—	.1543	.0053
46	.034149	—	—	—	—	.0286	.0010
47	.034145	.0574	.0020	—	—	—	—

**EBASCO SERVICES INCORPORATED**

BY C.H. Yell DATE 01/22/86

SHEET 53 OF 102

CHKD. BY C.W.U DATE 1/22/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO

PROJECT COMANCHE PEAK UNIT 2  
CABLE TRAY HANGERS

SUBJECT MODEL. 1-B

		COMPUTER RUN I.D					
<u>MISSING WT OF MODEL. 1-B</u>		<u>NODAL WT: DRYTBNZ (01/22/86)</u>					
		<u>X1</u>		<u>X2</u>		<u>X3</u>	
<u>NODE ID</u>	<u>NODAL WEIGHTS</u>	<u>MISSING RATIO</u>	<u>MISS. WT.</u>	<u>MISSING RATIO</u>	<u>MISS. WT.</u>	<u>MISSING RATIO</u>	<u>MISS. WT.</u>
48	.052074	.2311	.0120	.4143	.0216	—	—
49	.074383	.4635	.0345	.9761	.0726	—	—
50	.078759	.0364	.0029	.4421	.0348	—	—
51	=	—	—	—	—	—	—
52	=	—	—	—	—	—	—
53	.19738 (X1.2) .039379 (X3)	.7985	.1576	.9919	.1958	—	—
61	.35438 (X1) .19738 (X2.5)	.2803	.0993	.1952	.0385	.9906	.1955
62	.078759	.2370	.0183	—	—	.0802	.0063
63	=	.1864	.0147	—	—	—	—
64	=	.1438	.0113	.6150	.0484	—	—
65	=	.1043	.0082	.9644	.0760	.0795	.0063
66	=	.0681	.0054	.1540	.0121	—	—
67	=	.0354	.0028	—	—	—	—
68	=	.0063	.0005	.3660	.0288	—	—
69	=	—	—	.9542	.0752	.1050	.0083
70	=	—	—	.2261	.0178	—	—
71	=	—	—	—	—	—	—
72	=	—	—	.2862	.0225	—	—
73	.074383	—	—	.9581	.0713	.3102	.0231
74	.052074	—	—	.3503	.0182	.2332	.0121
			.368		.734		.252



**EBASCO SERVICES INCORPORATED**

BY C.H. Yeh DATE 01/22/86

SHEET 54 OF 102

CHKD. BY C.A.W. DATE 1/22/86

OFFS. NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO

PROJECT COMANCHE PEAK UNIT 2

SUBJECT MODEL. 1-B

CABLE TRAY HANGERS

MISSING WT OF MODEL. 1-B		COMPUTER RUN I.D					
		NODAL WT: DRYTB NZ (01/05)					
		MISS. RATIO:					
NODE ID	NODAL WEIGHTS	X1		X2		X3	
		MISSING RATIO	MISS. WT.	MISSING RATIO	MISS. WT.	MISSING RATIO	MISS. WT.
75	.034145	—	—	—	—	.0931	.0032
76	.034149	—	—	—	—	—	—
77	.034145	.0041	.0001	—	—	—	—
78	.052074	.1093	.0057	.4115	.0214	—	—
79	.074383	.2551	.0190	.9699	.0721	—	—
80	.078759	—	—	.4361	.0344	—	—
81	=	—	—	—	—	—	—
82	=	—	—	—	—	—	—
83	.19738 (X1,2) .039379 (X3)	.7210	.1423	.9903	.1955	—	—
104	.048967	.8603	.0421	.7951	.0390	.9983	.0489
105	.03438	.8184	.0281	.3231	.0111	.9974	.0343
106	=	.8554	.0294	.3159	.0109	.9979	.0343
107	.00778	.6899	.0054	.6865	.0053	.9982	.0078
108	.00201	.681	.0014	.2039	.0004	.9972	.0020
109	.00201	.7534	.0015	.1953	.0004	.9975	.0020
202	.02067	.8526	.0176	.9989	.0210	.7941	.0164
203	.02088	.4505	.0094	.1981	.0208	.4111	.0086
204	.01475	—	—	.9976	.0147	.1071	.0016
205	.01263	.7380	.0093	.9684	.0122	.7916	.010
206	.01263	.1787	.0023	.9741	.0123	.4028	.0051
			.214		.477		.174

EBASCO SERVICES INCORPORATED

BY C.H. Wick DATE 01/23/86

SHEET 15 OF 102

CHKD. BY C.Wu DATE 1/23/86

OFFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO

PROJECT COMANCHE PEAK UNIT 2  
CABLE TRAY HANGERS

SUBJECT MODEL. 1-B

		COMPUTER RUN I.D					
<u>MISSING WT OF MODEL. 1-B</u>		NODAL WT: DRY TBINZ (01/86)					
		X1		X2		X3	
NODE ID	NODAL WEIGHTS	MISSING RATIO	MISS. WT.	MISSING RATIO	MISS. WT.	MISSING RATIO	MISS. WT.
207	.01263	—	—	.9644	.0122	.1013	.0013
209	.01399	.7691	.0108	.9946	.0139	.7915	.0111
210	.01418	.1433	.0020	.9911	.0141	.4032	.0057
211	.00873	—	—	.9895	.0086	.1049	.0009
302	.02067	.8078	.0167	.9979	.0206	.7931	.0165
303	.02088	.3058	.0064	.9964	.0208	.2259	.0089
304	.01475	—	—	.9957	.0147	.1314	.0019
305	.01263	.7637	.0096	.9607	.0121	.7953	.010
306	.01263	.2542	.0032	.9674	.0122	.4179	.0053
307	.01263	—	—	.9542	.0121	.1257	.0016
309	.01399	.8059	.0113	.9941	.0139	.7954	.0111
310	.01418	.2556	.0036	.9899	.0140	.4184	.0059
311	.00873	—	—	.9880	.0086	.1291	.0011
402	.02067	.7695	.0163	.9982	.0206	.8320	.0172
403	.02088	.2456	.0051	.9969	.0208	.5451	.0114
404	.01475	—	—	.9962	.0147	.3286	.0048
405	.01263	.7355	.0099	.9652	.0122	.8276	.0125
406	=	.2565	.0032	.9657	.0122	.5384	.0068
407	=	—	—	.9581	.0121	.3248	.0041
409	.01399	.8250	.0115	.9946	.0140	.8283	.0116

**EBASCO SERVICES INCORPORATED**

BY C.H. York DATE 01/23/86

SHEET 56 OF 102

CHKD. BY C.W.H. DATE 1/24/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO

PROJECT COMANCHE PEAK UNIT 2

SUBJECT MODEL. 1-B

CABLE TRAY HANGERS

MISSING WT OF MODEL. 1-B COMPUTER RUN I.D  
NODAL WT: DRY TBN 2 (1.1%)  
MISS. RATIO:

NODE ID	NODAL WEIGHTS	X <sub>1</sub>		X <sub>2</sub>		X <sub>3</sub>	
		MISSING RATIO	MISS. WT.	MISSING RATIO	MISS. WT.	MISSING RATIO	MISS. WT.
410	.01418	.3129	.0044	.9907	.0140	.5390	.0076
411	.00873	—	—	.9889	.0086	.3273	.0029
502	.02067	.7984	.0165	.9990	.0206	.7874	.0163
503	.02088	.4874	.0102	.9982	.0208	.2278	.0048
504	.01475	.2710	.0040	.9978	.0147	—	—
505	.01263	.7903	.010	.9786	.0124	.7886	.0100
506	=	.4795	.0061	.9762	.0123	.2823	.0036
507	=	.2631	.0034	.9699	.0122	—	—
509	.01398	.7919	.0111	.9959	.0139	.8260	.0115
510	.01418	.4804	.0068	.9929	.0141	.3269	.0046
511	.00873	.2704	.0024	.9916	.0087	—	—
602	.02067	.9242	.0191	.9996	.0207	.8194	.0170
603	.02088	.8076	.0169	.9993	.0209	.3013	.0067
604	.01475	.7269	.0107	.9991	.0147	—	—
605	.01263	.9212	.0116	.9927	.0125	.8040	.0102
606	=	.8045	.0102	.9919	.0125	.2475	.0031
607	=	.7258	.0092	.9903	.0125	—	—
609	.01398	.9218	.0129	.9938	.0140	.7912	.0111
610	.01418	.6019	.0114	.9979	.0142	.2370	.0034
611	.00873	.7266	.0063	.9975	.0087	—	—

EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 01/23/86

SHEET 57 OF 102

CHKD. BY C.Wu DATE 2/10/86

OFS NO. 3306 221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

SUMMARY OF MISSING WT.

MISS. WT. FOR MODEL 1-A				MISS WT FOR MODEL 1-B			
PAGE	X1	X2	X3	PAGE	X1	X2	X3
1	.746	.584	.797	1	.337	.611	.934
2	.786	.540	.683	2	.390	.615	.408
3	.420	.482	.557	3	.368	.734	.252
4	.368	.408	.306	4	.314	.472	.174
5	.125	.285	.137	5	.110	.284	.148
6	.200	.215	.164	6	.183	.283	.113
Σ	2.645	2.514	2.644	Σ	1.702	2.999	2.029
TOTAL WT.	8.221	6.595	8.221	TOTAL WT.	6.9724	6.5014	6.0274
MISS. RATIO	.322	.381	.322	MISS RATIO	.244	.461	.337

EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 01/27/86

SHEET 58 OF 102

CHKD. BY C.Wu DATE 1/30/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

REACTION RATIO OF 3-D SYSTEM TO 2-D SINGLE HANGER. (MRM)

MODEL. 1-A

COMP. RUN ID.

BLDG. REACTOR (INT.)

3-D DYNAMIC: OBE, DRYSBP3  
(DYNRE4, RSS=1) SSE, DRYSDYZ

ELEV. 860.0'

3-D RIGID MODE: DRYTFJB (CASE 1/6)  
2-D STATIC: DRYTCDB (CASE 1/6)

SEISMIC EVENTS	NODE ID	COMPONENT ID.		X <sub>1</sub>		X <sub>2</sub>		X <sub>3</sub>	
		3-D SYST.	REACT		SRSS		SRSS		SRSS
OBE	301	3-D SYST.	DYNAM.	.037	SRSS	.169	SRSS	.165	SRSS
			RIGID MODE	.008	.038	.068	.182	.072	.180
		2-D SINGLE HANGER			.045		.496		.557
		MRM			.84		.37		.32
	308	3-D SYST.	DYNAM.	.026	SRSS	.268	SRSS	.101	SRSS
			RIGID MODE	.008	.027	.120	.294	.045	.111
		2-D SINGLE HANGER			.042		.766		.334
		MRM			.65		.38		.33
SSE	301	3-D SYST.	DYNAM.	.050	SRSS	.225	SRSS	.219	SRSS
			RIGID MODE	.012	.051	.097	.245	.105	.243
		2-D SINGLE HANGER			.062		.691		.806
		MRM			.83		.35		.30
	308	3-D SYST.	DYNAM.	.035	SRSS	.359	SRSS	.134	SRSS
			RIGID MODE	.012	.037	.170	.397	.066	.149
		2-D SINGLE HANGER			.059		1.018		.483
		MRM			.63		.39		.31

EBASCO SERVICES INCORPORATED

BY C. H. Yeh DATE 1/27/86

SHEET 59 OF 102

CHKD. BY C. Wu DATE 1/30/86

OFFS. NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

REACTION RATIO OF 3-D SYSTEM TO 2-D SINGLE HANGER. (MRM)

MODEL. 1-A

COMP. RUN ID.

BLDG. REACTOR (INT.)

3-D DYNAMIC: OBE DRYSD47

(DYNRE4, RSS=1) SSE DRYSD6Z

ELEV. 905.75'

3-D RIGID MODE: DRYTFJB (CASE 217)

2-D STATIC: DRYTCDB (CASE 217)

SEISMIC EVENTS	NODE ID.	COMPONENT ID.		X <sub>1</sub>		X <sub>2</sub>		X <sub>3</sub>	
		REACT	REACT						
OBE	301	3-D SYST.	DYNAM.	.055	SRSS	.247	SRSS	.235	SRSS
			RIGID MODE	.012	.056	.113	.272	.110	.259
		2-D SINGLE HANGER		.073		.720		.810	
		MRM		.77		.38		.32	
	308	3-D SYST.	DYNAM.	.039	SRSS	.397	SRSS	.143	SRSS
			RIGID MODE	.012	.041	.201	.445	.069	.159
		2-D SINGLE HANGER		.069		1.107		.486	
		MRM		.59		.40		.33	
SSE	301	3-D SYST.	DYNAM.	.078	SRSS	.345	SRSS	.338	SRSS
			RIGID MODE	.018	.080	.162	.381	.161	.374
		2-D SINGLE HANGER		.104		1.027		1.211	
		MRM		.77		.37		.31	
	308	3-D SYST.	DYNAM.	.055	SRSS	.544	SRSS	.206	SRSS
			RIGID MODE	.018	.058	.288	.616	.101	.229
		2-D SINGLE HANGER		.097		1.494		.725	
		MRM		.60		.41		.32	

EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 01/27/86

SHEET 60 OF 102

CHKD. BY C.Wu DATE 1/30/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

REACTION RATIO OF 3-D SYSTEM TO 2-D SINGLE HANGER. (MRM)

MODEL. 1-A

COMP. RUN ID.

BLDG. REACTOR (AUX.)

3-D DYNAMIC: OBE DRYVC2N

(DYNRE4. RSS=1) SSE DRYSD9F

ELEV. 899.5'

3-D RIGID MODE: DRYTFJB (CASE 3/8)

2-D STATIC: DRYTCDB (CASE 3/8)

SEISMIC EVENTS	NODE ID	COMPONENT ID.		X <sub>1</sub>		X <sub>2</sub>		X <sub>3</sub>		
		REACT	REACT							
OBE	301	3-D SYST.	DYNAM.	.056	SRSS	.225	SRSS	.211	SRSS	
			RIGID MODE	.010	.057	.067	.235	.089	.229	
		2-D SINGLE HANGER				.069			.963	1.104
		MRM				.82			.24	.21
	308	3-D SYST.	DYNAM.	.040	SRSS	.383	SRSS	.131	SRSS	
			RIGID MODE	.010	.041	.115	.400	.056	.142	
		2-D SINGLE HANGER				.065			1.451	.661
		MRM				.63			.28	.22
SSE	301	3-D SYST.	DYNAM.	.07	SRSS	.318	SRSS	.309	SRSS	
			RIGID MODE	.016	.072	.103	.334	.139	.339	
		2-D SINGLE HANGER				.086			1.174	1.412
		MRM				.83			.28	.24
	308	3-D SYST.	DYNAM.	.050	SRSS	.511	SRSS	.189	SRSS	
			RIGID MODE	.015	.052	.176	.54	.087	.208	
		2-D SINGLE HANGER				.080			1.659	.845
		MRM				.65			.33	.25

EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 01/27/86

SHEET 61 OF 102

CHKD. BY C.Wu DATE 1/30/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

REACTION RATIO OF 3-D SYSTEM TO 2-D SINGLE HANGER. (MRM)

MODEL. 1-A

COMP. RUN ID.

BLDG. ELECT.

3-D DYNAMIC: OBE DRYSEAF

(DYNRE 4. RSS=1) SSE DRYSEAV

ELEV. 873.33'

3-D RIGID MODE: DRYTFJB (CASE 4/9)

2-D STATIC: DRYTCDB (CASE 4/9)

SEISMIC EVENTS	NODE ID	COMPONENT ID.		X <sub>1</sub>		X <sub>2</sub>		X <sub>3</sub>	
		3-D	REACT						
OBE	301	3-D	DYNAM.	.026	SRSS	.194	SRSS	.154	SRSS
			RIGID MODE	.006	.027	.054	.201	.056	.164
		2-D SINGLE HANGER				.038	.511	.497	
		MRM				.70	.39	.33	
	308	3-D	DYNAM.	.019	SRSS	.332	SRSS	.094	SRSS
			RIGID MODE	.006	.020	.096	.346	.035	.100
		2-D SINGLE HANGER				.035	.89	.299	
		MRM				.57	.39	.34	
SSE	301	3-D	DYNAM.	.042	SRSS	.262	SRSS	.218	SRSS
			RIGID MODE	.010	.043	.087	.276	.085	.234
		2-D SINGLE HANGER				.057	.674	.635	
		MRM				.76	.41	.37	
	308	3-D	DYNAM.	.030	SRSS	.441	SRSS	.133	SRSS
			RIGID MODE	.009	.031	.154	.467	.054	.144
		2-D SINGLE HANGER				.054	1.197	.383	
		MRM				.58	.39	.37	



**EBASCO SERVICES INCORPORATED**

BY C.H. Yet DATE 01/27/86

SHEET 62 OF 102

CHKD. BY C.Wu DATE 1/30/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

REACTION RATIO OF 3-D SYSTEM TO 2-D SINGLE HANGER. (MRM)

MODEL. 1-A

COMP. RUN ID.

BLDG. SFGD.

3-D DYNAMIC: OBE DRY VC23

(DYNRE4, RSS=1) SSE DRY SEBT

ELEV. 896.5'

3-D RIGID MODE: DRY TFJB (CASE 5/10)

2-D STATIC: DRY TCDB (CASE 5/10)

SEISMIC EVENTS	NODE ID	COMPONENT ID.		X <sub>1</sub>		X <sub>2</sub>		X <sub>3</sub>	
		REACT	REACT						
OBE	301	3-D SYST.	DYNAM.	.065	SRSS	.297	SRSS	.267	SRSS
			RIGID MODE	.009	.066	.069	.305	.083	.280
		2-D SINGLE HANGER		.093		.795		.885	
		MRM		.71		.38		.32	
	308	3-D SYST.	DYNAM.	.046	SRSS	.476	SRSS	.162	SRSS
			RIGID MODE	.069	.047	.121	.491	.052	.170
		2-D SINGLE HANGER		.087		1.240		.531	
		MRM		.54		.40		.32	
SSE	301	3-D SYST.	DYNAM.	.086	SRSS	.379	SRSS	.344	SRSS
			RIGID MODE	.016	.087	.118	.397	.141	.372
		2-D SINGLE HANGER		.119		1.14		1.312	
		MRM		.74		.35		.28	
	308	3-D SYST.	DYNAM.	.061	SRSS	.615	SRSS	.209	SRSS
			RIGID MODE	.016	.063	.205	.648	.089	.227
		2-D SINGLE HANGER		.112		1.709		.786	
		MRM		.56		.38		.29	

**EBASCO SERVICES INCORPORATED**

BY C.H. Yeh DATE 01/29/86

SHEET 63 OF 102

CHKD. BY C.W.M DATE 1/30/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS "1-B" (FACTOR. UNBALANCE MOMENT)

REACTION RATIO OF 3-D SYSTEM TO 2-D SINGLE HANGER (MRM)

MODEL. 1-B

COMP. RUN ID.

BLDG. REACTOR (INT)

3-D DYNAMIC: OBE: DRYVCRR

(DYNREA.RSS=1) SSE: DRYVCRZ

ELEV. 860.0'

3-D RIGID MODE: DRYTEHV (CASE 1/6)

2-D STATIC: DRYVCQJ (CASE 1/6)

SEISMIC EVENTS	NODE ID	COMPONENT ID.		X <sub>1</sub>		X <sub>2</sub>		X <sub>3</sub>	
		REACT	REACT						
OBE	401	3-D DYNAM. SYST.	DYNAM.	.050	SRSS	.654	SRSS	.813	SRSS
			RIGID MODE	.008	.051	.067	.657	.073	.816
		2-D SINGLE HANGER		.079		1.040		1.385	
		MRM		.65		.63		.59	
	408	3-D DYNAM. SYST.	DYNAM.	.049	SRSS	.729	SRSS	.491	SRSS
			RIGID MODE	.008	.050	.121	.739	.046	.493
		2-D SINGLE HANGER		.077		1.192		.826	
		MRM		.65		.62		.60	
SSE	401	3-D DYNAM. SYST.	DYNAM.	.066	SRSS	.817	SRSS	1.014	SRSS
			RIGID MODE	.012	.067	.095	.823	.107	1.020
		2-D SINGLE HANGER		.100		1.268		1.681	
		MRM		.67		.65		.61	
	408	3-D DYNAM. SYST.	DYNAM.	.063	SRSS	.913	SRSS	.613	SRSS
			RIGID MODE	.012	.064	.171	.929	.068	.617
		2-D SINGLE HANGER		.098		1.472		1.003	
		MRM		.65		.63		.62	

EBASCO SERVICES INCORPORATED

BY C. H. Yeh DATE 01/29/86

SHEET 64 OF 102

CHKD. BY C. Wu DATE 1/30/86

OFFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS "1-B"

REACTION RATIO OF 3-D SYSTEM TO 2-D SINGLE HANGER (MRM)

MODEL. 1-B

COMP. RUN ID.

BLDG. REACTOR (INT)

3-D DYNAMIC: OBE DRY VCR3  
(DYNREA, RSS=1) SSE DRY VCSB

ELEV. 905.75'

3-D RIGID MODE: DRYTEHV (CASE 2/7)

2-D STATIC: DRYVCQT (CASE 2/7)

SEISMIC EVENTS	NODE ID	COMPONENT ID.		X <sub>1</sub>		X <sub>2</sub>		X <sub>3</sub>	
		REACT	REACT						
OBE	401	3-D SYST.	DYNAM.	.078	SRSS	1.104	SRSS	1.374	SRSS
			RIGID MODE	.013	.079	.111	1.110	.111	1.378
		2-D SINGLE HANGER		.125		1.621		2.172	
		MRM		.63		.68		.63	
	408	3-D SYST.	DYNAM.	.080	SRSS	1.226	SRSS	.830	SRSS
			RIGID MODE	.012	.081	.202	1.243	.070	.833
		2-D SINGLE HANGER		.123		1.826		1.296	
		MRM		.66		.68		.64	
SSE	401	3-D SYST.	DYNAM.	.105	SRSS	1.339	SRSS	1.665	SRSS
			RIGID MODE	.018	.106	.160	1.349	.163	1.673
		2-D SINGLE HANGER		.162		1.99		2.656	
		MRM		.65		.68		.63	
	408	3-D SYST.	DYNAM.	.102	SRSS	1.491	SRSS	1.006	SRSS
			RIGID MODE	.018	.104	.289	1.519	.104	1.011
		2-D SINGLE HANGER		.158		2.266		1.585	
		MRM		.66		.67		.64	

EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 01/29/86

SHEET 65 OF 102

CHKD. BY C.Wu DATE 1/30/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS "1-B"

REACTION RATIO OF 3-D SYSTEM TO 2-D SINGLE HANGER (MRM)

MODEL. 1-B

COMP. RUN ID.

BLDG. REACTOR (AUX.)

3-D DYNAMIC: OBE: DRYVCKN  
(DYNRE4, RSS=1) SSE: DRYVCSN

ELEV. 899.5'

3-D RIGID MODE: DRYTEHV (CASE 3/8)

2-D STATIC: DRYVCQT (CASE 3/8)

SEISMIC EVENTS	NODE ID	COMPONENT ID.		X <sub>1</sub>		X <sub>2</sub>		X <sub>3</sub>	
		REACT							
OBE	401	3-D SYST.	DYNAM.	.074	SRSS	.956	SRSS	1.187	SRSS
			RIGID MODE	.010	.075	.067	.958	.091	1.19
		2-D SINGLE HANGER		.109		1.401		1.792	
		MRM		.69		.68		.66	
	408	3-D SYST.	DYNAM.	.072	SRSS	1.065	SRSS	.717	SRSS
			RIGID MODE	.010	.073	.116	1.07	.057	.719
		2-D SINGLE HANGER		.106		1.773		1.070	
		MRM		.69		.60		.67	
SSE	401	3-D SYST.	DYNAM.	.093	SRSS	1.190	SRSS	1.477	SRSS
			RIGID MODE	.016	.094	.103	1.194	.141	1.484
		2-D SINGLE HANGER		.140		1.802		2.365	
		MRM		.67		.66		.63	
	408	3-D SYST.	DYNAM.	.091	SRSS	1.327	SRSS	.893	SRSS
			RIGID MODE	.016	.092	.178	1.339	.089	.897
		2-D SINGLE HANGER		.137		2.15		1.411	
		MRM		.67		.62		.64	

EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 01/29/86

SHEET 66 OF 102

CHKD. BY C.Wu DATE 1/30/86

OFFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS "1-B"

REACTION RATIO OF 3-D SYSTEM TO 2-D SINGLE HANGER (MRM)

MODEL. 1-B

COMP. RUN ID.

BLDG. ELECT.

3-D DYNAMIC: OBE DRYVCSR  
(DYNREA, RSS=1) SSE DRYVD&Z

ELEV. 873.33'

3-D RIGID MODE: DRYTEHV (CASE 4/9)

2-D STATIC: DRYVC&J (CASE 4/9)

SEISMIC EVENTS	NODE ID	COMPONENT ID.		X <sub>1</sub>		X <sub>2</sub>		X <sub>3</sub>	
		REACT							
OBE	401	3-D DYNAM. SYST.	DYNAM.	.042	SRSS	.672	SRSS	.828	SRSS
			RIGID MODE	.006	.042	.053	.674	.057	.830
		2-D SINGLE HANGER			.069		.96		1.231
		MRM			.61		.70		.67
	408	3-D DYNAM. SYST.	DYNAM.	.046	SRSS	.766	SRSS	.500	SRSS
			RIGID MODE	.006	.046	.096	.772	.036	.501
		2-D SINGLE HANGER			.068		1.205		.735
		MRM			.68		.64		.68
SSE	401	3-D DYNAM. SYST.	DYNAM.	.060	SRSS	.865	SRSS	1.067	SRSS
			RIGID MODE	.010	.061	.085	.869	.086	1.070
		2-D SINGLE HANGER			.098		1.315		1.69
		MRM			.62		.66		.63
	408	3-D DYNAM. SYST.	DYNAM.	.062	SRSS	.987	SRSS	.645	SRSS
			RIGID MODE	.009	.063	.155	.999	.055	.647
		2-D SINGLE HANGER			.095		1.645		1.009
		MRM			.66		.61		.64

EBASCO SERVICES INCORPORATED

5

BY C.H. yeh DATE 01/29/86

SHEET 67 OF 102

CHKD. BY C.Wu DATE 1/30/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS "1-B"

REACTION RATIO OF 3-D SYSTEM TO 2-D SINGLE HANGER (MRM)

MODEL. 1-B

COMP. RUN ID.

BLDG. SFGD

3-D DYNAMIC: OBE DRYVCS7

(DYNREA, RSS=1) SSE DRYVCTF

ELEV. 896.5'

3-D RIGID MODE: DRYTEHV (CASE 5/10)

2-D STATIC: DRYVC&T (CASE 5/10)

SEISMIC EVENTS	NODE ID	COMPONENT ID.		X <sub>1</sub>		X <sub>2</sub>		X <sub>3</sub>		
		REACT								
OBE	401	3-D SYST.	DYNAM.	.105	SRSS	1.458	SRSS	1.820	SRSS	
			RIGID MODE	.009	.105	.069	1.46	.084	1.822	
		2-D SINGLE HANGER			.179		2.412		3.282	
		MRM			.59		.61		.56	
	408	3-D SYST.	DYNAM.	.109	SRSS	1.608	SRSS	1.100	SRSS	
			RIGID MODE	.009	.109	.122	1.613	.053	1.101	
		2-D SINGLE HANGER			.177		2.593		1.957	
		MRM			.62		.62		.56	
SSE	401	3-D SYST.	DYNAM.	.124	SRSS	1.635	SRSS	2.036	SRSS	
			RIGID MODE	.016	.125	.117	1.639	.143	2.041	
		2-D SINGLE HANGER			.204		2.624		3.533	
		MRM			.61		.62		.58	
	408	3-D SYST.	DYNAM.	.124	SRSS	1.818	SRSS	1.230	SRSS	
			RIGID MODE	.016	.125	.207	1.822	.090	1.233	
		2-D SINGLE HANGER			.200		2.917		2.107	
		MRM			.63		.63		.59	

**EBASCO SERVICES INCORPORATED**

BY C.H. Yeh DATE 2/7/86

SHEET 68 OF 102

CHKD. BY C.W. H 2/10/86  
 TEXAS UTILITIES GENERATING CO.

OFS NO. 3306 221 DEPT. NO. 550

CLIENT COMANCHE PEAK UNIT 2  
 PROJECT CABLE TRAY HANGERS

MRM FOR REACTION.

SUBJECT MULTIPLE RESPONSE MULTIPLIER FOR C.T.H. SYSTEM W/90° BENT (RSS=1)

MODEL	BUILDING	ELEVATION (FT)	RANGE OF AMPLIFICATION FACTOR							
			OBE (4%)				SSE (7%)			
			VERT.	TRANS.	LONG.	RUN ID	VERT.	TRANS.	LONG.	RUN ID
1A	REACTOR	860.00*	.38	.33	.84	SBP3 DRY TFJB TCDB	.39	.31	.83	SDPZ DRY TFJB TCDB
	INTERNAL	905.75	.40	.33	.77	SD47 DRY TFJB TCDB	.41	.32	.77	SD6Z DRY TFJB TCDB
	REACTOR AUXILIARY	899.50	.28	.22	.82	VC2N DRY TFJB TCDB	.33	.25	.83	SD9F DRY TFJB TCDB
	ELECTRICAL	873.33	.39	.34	.70	SEAF DRY TFJB TCDB	.41	.37	.76	SEAV DRY TFJB TCDB
	SAFE GUARD	896.50	.40	.32	.71	VC23 DRY TFJB TCDB	.38	.29	.74	SEBT DRY TFJB TCDB
** 1B	REACTOR	860.00*	.63	.60	.65	VCR2 DRY TEHV VCQT	.65	.62	.67	VCR2 DRY TEHV VCQT
	INTERNAL	905.75	.68	.64	.66	VCR3 DRY TEHV VCQT	.68	.64	.66	VCSB DRY TEHV VCQT
	REACTOR AUXILIARY	899.50	.68	.67	.69	VCKN DRY TEHV VCQT	.66	.64	.67	VCSN DRY TEHV VCQT
	ELECTRICAL	873.33	.70	.68	.68	VCSR DRY TEHV VCQT	.66	.64	.66	VD&Z DRY TEHV VCQT
	SAFE GUARD	896.50	.62	.56	.62	VCST DRY TEHV VCQT	.63	.59	.63	VCTE DRY TEHV VCQT

\* THE FLOOR ELEVATION WHERE THE HANGER FOR STRUCTURAL MODEL IS LOCATED.

\*\* USE FACTOR UNBALANCE MOMENT IN "2-D" STATIC ANALYSIS

M.R.M. RESULTS FOR CABLE TRAY HANGER SYSTEM WITH 90° BENT

(FOR SUPPORT REACTION ENVELOP)

## EBASCO SERVICES INCORPORATED

NEW YORK

BY I H CHOU DATE 2/7/86SHEET 69 OF 102CHKD. BY YEH DATE 2/8/86OFS NO. 3306.221 DEPT. NO. 550CLIENT TEXAS UTILITIES GENERATING CO.PROJECT COMANCHE PEAK UNIT 2SUBJECT CABLE TRAY HANGERS6 The time History vs Response Spectra Approach

In order to verify the validity of selecting option  $RSS=1$  in the dynamic analysis using modal response (DYNRE4), a comparison between the MRM's through both the time history analysis (DYNRE1) and the response spectra approach (DYNRE4 with  $RSS=1$ ) was performed.

The floor response spectra were obtained through DYNRE5 <sup>at</sup> ~~for~~ selected frequencies ~~for~~ the time histories. Four sets of time histories were used, horizontal and vertical earthquakes for both OBE and SSE. Damping values were assumed 4% and 7% for OBE and SSE respectively.

In the time history approach (DYNRE1),



## EBASCO SERVICES INCORPORATED

BY Z H CHU DATE 2/7/86

NEW YORK

SHEET 70 OF 102CHKD. BY YCH DATE 2/8/86OFS NO. 3306.221 DEPT. NO. 50CLIENT TEXAS UTILITIES GENERATING CO.PROJECT COMANCHE PEAK UNIT 2SUBJECT CABLE TRAY HANGERS

structural responses were obtained by SRSS of the peak values corresponding to three individual, separate seismic excitations.

Since the rigid-mode response is included in the program formulation, the missing mass adjustment is not necessary.

~~For the response~~

For the response spectra approach, (DYNRE4 with  $RSS = 1$ ), however, the rigid-mode responses were obtained through the missing mass computation. The MRM's were listed on ~~the~~ page 100 for both approaches and both models.

BY E.W.J. DATE 1-31-86

CHKD. BY YEH DATE 2-03-86

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

Calculation of Acceleration level from Time History

SHEET 71 OF 102

DEPT. NO. 550

OFS NO. 3306-221

MODEL	DIRECT.	SYSTEM FREQUENCY $f_s$	OBE (4% DAMPING)					SSE (7% DAMPING)				
			$f_1$	$f_2$	$A_1$	$A_2$	* $A_{OBE}$	$f_3$	$f_4$	$A_3$	$A_4$	** $A_{SSE}$
I-A	L	11.28	11.211	11.307	0.427	0.417	0.420	11.211	11.307	0.679	0.671	0.673
	V	11.31	11.307	11.397	0.974	0.954	0.973	11.307	11.397	1.374	1.358	1.373
	T	16.18	14.870	16.966	0.328	0.306	0.314	14.870	16.966	0.541	0.483	0.504
I-B	L	11.28	11.211	11.307	0.427	0.417	0.420	11.211	11.307	0.679	0.671	0.673
	V	11.32	11.307	11.397	0.974	0.954	0.971	11.307	11.397	1.374	1.358	1.372
	T	9.34	8.251	9.659	0.951	0.664	0.725	8.251	9.659	1.369	1.006	1.083

2-D MODEL ACCELERATION LEVEL FOR BEST ESTIMATE TIME HISTORY

$$* A_{OBE} = A_1 + (A_2 - A_1) \frac{\ln f_s - \ln f_1}{\ln f_2 - \ln f_1}$$

$$** A_{SSE} = A_3 + (A_4 - A_3) \frac{\ln f_s - \ln f_3}{\ln f_4 - \ln f_3}$$

**EBASCO SERVICES INCORPORATED**

BY C.H. yeh DATE 02/04/86

SHEET 72 OF 162

CHKD. BY e.w'u DATE 2/4/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

CABLE TRAY HANGERS

SUBJECT \_\_\_\_\_

COMPARISON OF TIME HISTORY (DYNRE 1) / RESPONSE SPECTRA (DYNRE 4)

MODEL: 1-A

SEISMIC: OBE

COMPUTER RUN ID.

DYNRE 1: DRYZDMN

DYNRE 4: DRYZCL3

RESPONSE @		DYNRE 1				DYNRE 4	
NODE	DIRECT.	X <sub>1</sub>	X <sub>2</sub>	X <sub>3</sub>	SRSS (AT)	RSS = 1	
7	2	.163	.399	.123	.448	.375	
	3	.188	.018	.221	.291	.595	
8	2	.126	.304	.080	.339	.235	✓
	3	.118	.014	.218	.248	.466	
9	2	.004	.180	.008	.180	.191	
	3	.019	.004	.218	.219	.336	
10	2	.125	.234	.121	.292	.418	
	3	.050	.026	.227	.234	.248	
11	2	.136	.318	.169	.385	.536	
	3	.055	.034	.231	.240	.227	✓
12	2	.154	.367	.154	.427	.519	
	3	.057	.036	.241	.250	.225	✓
37	2	.156	.402	.118	.447	.517	
	3	.170	.034	.362	.401	.525	
38	2	.130	.305	.083	.342	.320	✓
	3	.126	.025	.310	.336	.386	
39	2	.004	.180	.005	.180	.192	
	3	.056	.012	.229	.236	.247	

EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 02/04/86

SHEET 73 OF 102

CHKD. BY C.Wu DATE 2/4/86

OFS NO. 7306221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

COMPARISON OF TIME-HISTORY (DYNRE1) / RESPONSE-SPECTRA (DYNRE4)

MODEL: 1-A  
SEISMIC: OBE

COMPUTER RUN ID.  
DYNRE 1: DRYZDMN  
DYNRE 4: DRYZCL3

RESPONSE @		DYNRE 1				DYNRE 4	
NODE	DIRECT.	X <sub>1</sub>	X <sub>2</sub>	X <sub>3</sub>	SRSS(A <sub>T</sub> )	RSS = 1	
40	2	.103	.230	.106	.273	.494	
	3	.072	.029	.228	.241	.286	
41	2	.124	.313	.159	.372	.658	
	3	.076	.036	.231	.246	.313	
42	2	.156	.364	.156	.426	.662	
	3	.075	.039	.233	.248	.326	
67	2	.207	.401	.169	.482	.613	
	3	.363	.054	.522	.638	.772	
68	2	.154	.301	.124	.360	.395	
	3	.262	.039	.431	.506	.570	
69	2	.007	.180	.004	.180	.190	
	3	.089	.018	.270	.285	.241	✓
70	2	.150	.218	.176	.318	.505	
	3	.058	.044	.247	.258	.202	✓
71	2	.221	.339	.222	.462	.757	
	3	.063	.056	.258	.271	.221	✓
72	2	.217	.394	.217	.499	.855	
	3	.069	.059	.267	.282	.236	✓

EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 02/04/86

SHEET 74 OF 102

CHKD. BY C.Wu DATE 2/4/86

OFS NO. 3306 221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

COMPARISON OF TIME-HISTORY (DYNRE1) / RESPONSE - SPECTRA (DYNRE4)

MODEL: 1-A

SEISMIC OBE

COMPUTER RUN ID.

DYNRE 1: DRYZDMN

DYNRE 4: DRYZCL3

RESPONSE @		DYNRE 1				DYNRE 4	
NODE	DIRECT.	X <sub>1</sub>	X <sub>2</sub>	X <sub>3</sub>	SRSS	RSS = 1	
302	1	.244	.007	.022	.245	.334	
	2	.001	.180	.001	.180	.197	
	3	.018	.004	.217	.218	.342	
303	1	.327	.025	.078	.337	.343	
	2	.001	.180	.002	.180	.197	
	3	.054	.011	.229	.236	.251	
304	1	.425	.043	.136	.448	.607	
	2	.001	.180	.003	.180	.197	
	3	.086	.018	.265	.279	.238	
305	1	.247	.007	.019	.248	.337	
	2	.004	.180	.008	.180	.191	
	3	.018	.004	.217	.218	.341	
306	1	.333	.022	.028	.335	.343	
	2	.004	.180	.005	.180	.192	
	3	.055	.012	.229	.236	.250	
307	1	.436	.040	.060	.442	.594	
	2	.007	.180	.004	.180	.190	
	3	.086	.018	.266	.280	.239	✓

EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 02/04/86

SHEET 75 OF 102

CHKD. BY C.Wu DATE 2/4/86

OFS NO. 3306 221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.  
 PROJECT COMANCHE PEAK UNIT 2  
 SUBJECT CABLE TRAY HANGERS

COMPARISON OF TIME-HISTORY (DYNRE 1) / RESPONSE-SPECTRA (DYNRE 4)

MODEL: 1-A  
 SEISMIC: OBE

COMPUTER RUN ID.  
 DYNRE 1: DRYZDMN  
 DYNRE 4: DRYZCL3

RESPONSE @		DYNRE 1				DYNRE 4	
NODE	DIRECT.	X <sub>1</sub>	X <sub>2</sub>	X <sub>3</sub>	SRSS	RSS = 1	
309	1	.244	.008	.019	.245	.360	
	2	.001	.180	.002	.180	.196	
	3	.018	.004	.217	.218	.341	
310	1	.331	.028	.066	.339	.369	
	2	.002	.180	.003	.180	.195	
	3	.055	.012	.229	.236	.250	
311	1	.434	.051	.109	.450	.619	
	2	.002	.180	.004	.180	.195	
	3	.086	.018	.266	.280	.239	✓

**EBASCO SERVICES INCORPORATED**

BY C.H. Yeh DATE 02/05/86

SHEET 76 OF 102

CHKD. BY C.W. W DATE 2/6/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT \_\_\_\_\_  
 PROJECT TEXAS UTILITIES GENERATING CO.  
COMANCHE PEAK UNIT 2  
 SUBJECT CABLE TRAY HANGERS

**COMPARISON OF TIME-HISTORY (DYNRE 1) / RESPONSE SPECTRA (DYNRE 4)**

MODEL: 1-A  
SEISMIC: SSE

COMPUTER RUN ID.  
DYNRE 1: DRYZDGJ/DRYODAB  
DYNRE 4: DRYZAAB

RESPONSE @		DYNRE 1				DYNRE 4	
NODE	DIRECT.	X <sub>1</sub>	X <sub>2</sub>	X <sub>3</sub>	SRSS	RSS = 1	
7	2	.18	.678	.137	.715	.608	✓
	3	.033	.021	.356	.358	.617	
8	2	.116	.562	.105	.583	.375	✓
	3	.021	.017	.356	.357	.464	
9	2	.002	.345	.002	.345	.361	
	3	.005	.006	.357	.357	.299	✓
10	2	.112	.391	.118	.423	.565	
	3	.011	.038	.366	.368	.242	✓
11	2	.161	.503	.165	.553	.794	
	3	.013	.050	.374	.378	.240	✓
12	2	.172	.576	.172	.625	.86	
	3	.014	.053	.378	.382	.244	✓
37	2	.189	.680	.146	.721	.853	
	3	.045	.027	.406	.409	.584	
38	2	.124	.564	.112	.588	.511	✓
	3	.033	.019	.393	.395	.430	
39	2	.002	.345	.002	.345	.362	
	3	.014	.015	.369	.370	.241	✓

EBASCO SERVICES INCORPORATED

BY C.H. yeh DATE 02/05/86

SHEET 77 OF 102

CHKD. BY C.Wu DATE 2/6/86

OFS NO. 3306221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.  
 PROJECT COMANCHE PEAK UNIT 2  
 SUBJECT CABLE TRAY HANGERS

COMPARISON OF TIME-HISTORY (DYNRE 1) / RESPONSE SPECTRA (DYNRE 4)  
 MODEL: 1-A  
 SEISMIC: SSE  
 COMPUTER RUN ID.  
 DYNRE 1: DRYZD6J/DRYODAB  
 DYNRE 4: DRYZA4B

RESPONSE @		DYNRE 1				DYNRE 4	
NODE	DIREKT.	X <sub>1</sub>	X <sub>2</sub>	X <sub>3</sub>	SKSS	RSS = 1	
40	2	.119	.390	.125	.426	.682	
	3	.014	.042	.370	.373	.295	✓
41	2	.170	.497	.175	.554	.997	
	3	.017	.052	.375	.379	.332	✓
42	2	.182	.569	.182	.625	1.103	
	3	.019	.055	.379	.383	.347	✓
67	2	.271	.672	.217	.756	1.002	
	3	.073	.040	.438	.447	.887	
68	2	.188	.568	.163	.620	.626	
	3	.058	.029	.416	.421	.657	
69	2	.002	.345	.002	.345	.359	
	3	.022	.023	.383	.384	.265	✓
70	2	.174	.380	.169	.451	.786	
	3	.018	.063	.393	.398	.237	✓
71	2	.242	.471	.238	.581	1.200	
	3	.025	.078	.404	.412	.272	✓
72	2	.258	.542	.258	.653	1.376	
	3	.031	.082	.412	.421	.293	✓



EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 02/05/86

SHEET 78 OF 102

CHKD. BY C.W. Yeh DATE 2/6/86

OFS NO. 3306 221 DEPT. NO. 550

CLIENT \_\_\_\_\_  
 PROJECT TEXAS UTILITIES GENERATING CO.  
COMANCHE PEAK UNIT 2  
 SUBJECT CABLE TRAY HANGERS

COMPARISON OF TIME-HISTORY (DYNRE 1) / RESPONSE SPECTRA (DYNRE 4)

MODEL: 1-A  
 SEISMIC: SSE

COMPUTER RUN ID.  
 DYNRE 1: DRYZDGJ/DRYODAB  
 DYNRE 4: DRYZA4B

RESPONSE @		DYNRE 1				DYNRE 4	
NODE	DIRECT.	X <sub>1</sub>	X <sub>2</sub>	X <sub>3</sub>	SKSS	RSS = 1	
302	1	.401	.008	.008	.401	.316	✓
	2	.0002	.343	.0004	.343	.372	
	3	.005	.006	.357	.357	.304	✓
303	1	.538	.025	.027	.539	.516	✓
	2	.0003	.343	.001	.343	.371	
	3	.014	.015	.368	.369	.243	✓
304	1	.699	.043	.049	.702	.939	
	2	.0004	.344	.001	.344	.371	
	3	.021	.022	.382	.383	.260	✓
305	1	.406	.007	.005	.406	.321	✓
	2	.002	.345	.002	.345	.361	
	3	.005	.006	.357	.357	.302	✓
306	1	.551	.025	.014	.552	.527	✓
	2	.002	.345	.002	.345	.362	
	3	.014	.015	.368	.369	.242	✓
307	1	.722	.043	.023	.724	.955	
	2	.002	.345	.002	.345	.359	
	3	.022	.022	.382	.383	.261	✓

EBASCO SERVICES INCORPORATED

BY C.H. yeh DATE 02/05/86

SHEET 79 OF 102

CHKD. BY e. Wu DATE 2/6/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

COMPARISON OF TIME-HISTORY (DYNRE 1) / RESPONSE SPECTRA (DYNRE 4)

MODEL: 1-A

SEISMIC: SSE

COMPUTER RUN ID.

DYNRE 1: DRYZDGJ/DRYODAB

DYNRE 4: DRYZAAB

RESPONSE @		DYNRE 1				DYNRE 4	
NODE	DIRECT.	X <sub>1</sub>	X <sub>2</sub>	X <sub>3</sub>	SKSS	RSS = 1	
309	1	.403	.010	.008	.403	.339	✓
	2	.0003	.343	.0005	.343	.370	
	3	.005	.006	.357	.357	.303	✓
310	1	.549	.033	.027	.551	.547	✓
	2	.0005	.344	.001	.344	.369	
	3	.014	.015	.368	.369	.242	✓
311	1	.720	.060	.047	.724	.975	
	2	.001	.344	.001	.344	.368	
	3	.021	.022	.382	.383	.261	✓

**EBASCO SERVICES INCORPORATED**

BY C.H. Yeh DATE 02/05/86

SHEET 80 OF 102

CHKD. BY C.Wy DATE 2/6/86

OFS NO. 3306 221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

COMPARISON OF TIME-HISTORY (DYNRE 1) / RESPONSE SPECTRA (DYNRE 4)

MODEL: 1-B

SEISMIC: OBE

COMPUTER RUN ID.

DYNRE 1: DRYZDXF/DRYODUJ

DYNRE 4: DRYZC67

RESPONSE @		DYNRE 1				DYNRE 4	
NODE	DIRECT.	X <sub>1</sub>	X <sub>2</sub>	X <sub>3</sub>	SRSS (AT)	RSS = 1	
11	2	.104	.321	.056	.342	.470	
	3	.131	.031	.300	.329	.504	
12	2	.080	.245	.035	.260	.321	
	3	.073	.026	.249	.261	.405	
13	2	.003	.180	.007	.180	.191	
	3	.014	.005	.241	.241	.341	
14	2	.063	.397	.039	.404	.380	✓
	3	.076	.049	.395	.405	.256	✓
15	2	.082	.454	.056	.465	.419	✓
	3	.092	.070	.466	.480	.259	✓
16	2	.095	.394	.072	.412	.310	✓
	3	.081	.081	.512	.525	.282	✓
41	2	.102	.339	.051	.358	.629	
	3	.151	.030	.453	.478	.563	
42	2	.077	.256	.039	.270	.435	
	3	.106	.023	.368	.384	.391	
43	2	.003	.180	.005	.180	.191	
	3	.033	.013	.283	.285	.259	✓

EBASCO SERVICES INCORPORATED

BY C.H. yeh DATE 02/05/86

SHEET 81 OF 102

CHKD. BY C.Wu DATE 2/7/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT \_\_\_\_\_  
PROJECT TEXAS UTILITIES GENERATING CO.  
SUBJECT COMANCHE PEAK UNIT 2  
CABLE TRAY HANGERS

COMPARISON OF TIME-HISTORY (DYNRE 1) / RESPONSE SPECTRA (DYNRE 4)

MODEL: 1-B  
SEISMIC: OBE

COMPUTER RUN ID.  
DYNRE 1: DRY2DXF/DRYODUJ  
DYNRE 4: DRY2C67

RESPONSE @		DYNRE 1				DYNRE 4	
NODE	DIRECT.	X <sub>1</sub>	X <sub>2</sub>	X <sub>3</sub>	SRSS (A <sub>r</sub> )	RSS = 1	
44	2	.070	.399	.052	.408	.337	✓
	3	.060	.030	.531	.535	.406	✓
45	2	.085	.459	.073	.472	.419	✓
	3	.063	.038	.645	.649	.519	✓
46	2	.098	.393	.088	.414	.438	
	3	.070	.041	.717	.722	.597	✓
71	2	.143	.357	.078	.392	.772	
	3	.179	.054	.586	.615	.691	
72	2	.092	.266	.060	.288	.537	
	3	.129	.041	.472	.491	.501	
73	2	.003	.180	.001	.180	.189	
	3	.044	.019	.317	.321	.247	✓
74	2	.092	.391	.088	.411	.47	
	3	.077	.052	.646	.653	.618	✓
75	2	.120	.446	.133	.481	.607	
	3	.103	.067	.795	.804	.825	
76	2	.151	.386	.157	.443	.635	
	3	.118	.074	.891	.902	.961	

EBASCO SERVICES INCORPORATED

BY C.H. yeh DATE 02/05/86

SHEET 82 OF 102

CHKD. BY C.Wu DATE 2/7/86

OFFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.  
PROJECT COMANCHE PEAK UNIT 2  
SUBJECT CABLE TRAY HANGERS

COMPARISON OF TIME-HISTORY (DYNRE 1) / RESPONSE SPECTRA (DYNRE 4)  
MODEL: 1-B  
SEISMIC: OBE  
COMPUTER RUN ID.  
DYNRE 1: DRYEDXF/DRYODUJ  
DYNRE 4: DRYEC67

RESPONSE @		DYNRE 1				DYNRE 4	
NODE	DIRECT.	X <sub>1</sub>	X <sub>2</sub>	X <sub>3</sub>	SRSS (a <sub>r</sub> )	RSS = 1	
402	1	.239	.006	.043	.243	.339	
	2	.0003	.180	.001	.180	.197	
	3	.012	.004	.239	.239	.347	
403	1	.313	.016	.144	.345	.356	
	2	.001	.180	.002	.180	.196	
	3	.031	.012	.280	.282	.263	✓
404	1	.401	.025	.249	.473	.626	
	2	.001	.180	.002	.180	.196	
	3	.044	.019	.314	.318	.246	✓
405	1	.246	.011	.028	.248	.341	
	2	.003	.180	.007	.180	.191	
	3	.013	.004	.240	.240	.345	
406	1	.340	.023	.109	.358	.369	
	2	.003	.180	.005	.180	.191	
	3	.032	.013	.281	.283	.261	✓
407	1	.450	.041	.202	.495	.652	
	2	.003	.180	.001	.180	.189	
	3	.044	.019	.315	.319	.246	✓

EBASCO SERVICES INCORPORATED

BY C. H. Yeh DATE 02/05/86

SHEET 83 OF 102

CHKD. BY C. Wu DATE 2/7/86

OFS NO. 3306221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

COMPARISON OF TIME-HISTORY (DYNRE 1) / RESPONSE SPECTRA (DYNRE 4)

MODEL: 1-B

SEISMIC: OBE

COMPUTER RUN ID.

DYNRE 1: DRY2DXF/DRYODUJ

DYNRE 4: DRY2C67

RESPONSE @		DYNRE 1				DYNRE 4	
NODE	DIRECT.	X <sub>1</sub>	X <sub>2</sub>	X <sub>3</sub>	SRSS (at)	RSS = 1	
409	1	.249	.009	.059	.256	.360	
	2	.001	.180	.001	.180	.196	
	3	.013	.004	.240	.240	.346	
410	1	.348	.032	.195	.400	.441	
	2	.001	.180	.002	.180	.195	
	3	.032	.013	.280	.282	.262	✓
411	1	.461	.059	.351	.582	.769	
	2	.001	.180	.003	.180	.195	
	3	.043	.019	.314	.317	.246	✓

**EBASCO SERVICES INCORPORATED**

BY C.H. Yek DATE 02/05/86

SHEET 84 OF 102

CHKD. BY C.Wu DATE 2/6/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

**COMPARISON OF TIME-HISTORY (DYNRE 1) / RESPONSE SPECTRA (DYNRE 4)**

MODEL: 1-B  
SEISMIC: SSE

COMPUTER RUN ID.  
DYNRE 1: DRYZDXJ/DRYODIR  
DYNRE 4: DRYZDF7

RESPONSE @		DYNRE 1				DYNRE 4	
NODE	DIRECT.	X <sub>1</sub>	X <sub>2</sub>	X <sub>3</sub>	SRSS (RT)	RSS = 1	
11	2	.097	.55	.066	.562	.772	
	3	.038	.036	.346	.350	.551	
12	2	.062	.431	.044	.438	.532	
	3	.026	.030	.350	.352	.410	
13	2	.002	.345	.006	.345	.360	
	3	.007	.007	.387	.387	.305	✓
14	2	.077	.686	.047	.692	.465	✓
	3	.046	.066	.616	.621	.304	✓
15	2	.112	.798	.067	.809	.543	✓
	3	.068	.093	.723	.732	.363	✓
16	2	.125	.739	.079	.754	.519	✓
	3	.083	.109	.790	.802	.415	✓
41	2	.102	.563	.058	.575	1.048	
	3	.033	.026	.382	.384	.637	
42	2	.068	.439	.040	.446	.721	
	3	.023	.020	.369	.370	.446	
43	2	.002	.345	.005	.345	.360	
	3	.020	.017	.443	.444	.265	✓

EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 02/05/86

SHEET 85 OF 102

CHKD. BY C.Wu DATE 2/6/86

OFFS NO. 3306221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

COMPARISON OF TIME-HISTORY (DYNRE 1) / RESPONSE SPECTRA (DYNRE 4)

MODEL: 1-B

SEISMIC: SSE

COMPUTER RUN ID.

DYNRE 1: DRYZDXJ/DRYODIR

DYNRE 4: DRYZDF7

RESPONSE @		DYNRE 1				DYNRE 4	
NODE	DIRELT.	X <sub>1</sub>	X <sub>2</sub>	X <sub>3</sub>	SRSS (QT)	RSS = 1	
44	2	.079	.685	.050	.691	.500	✓
	3	.063	.048	.789	.793	.570	✓
45	2	.115	.795	.075	.807	.640	✓
	3	.082	.061	.951	.956	.754	✓
46	2	.128	.737	.090	.753	.726	✓
	3	.093	.066	1.055	1.061	.874	✓
71	2	.143	.572	.096	.597	1.268	
	3	.060	.048	.445	.452	.833	
72	2	.093	.443	.066	.457	.877	
	3	.044	.036	.424	.428	.606	
73	2	.002	.345	.001	.345	.357	
	3	.030	.025	.484	.486	.298	✓
74	2	.109	.668	.084	.682	.705	
	3	.103	.074	.948	.956	.894	✓
75	2	.159	.775	.127	.801	.925	
	3	.138	.094	1.159	1.171	1.203	
76	2	.186	.720	.151	.759	1.005	
	3	.163	.104	1.294	1.308	1.403	



EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 02/05/86

SHEET 86 OF 102

CHKD. BY C.Wu DATE 2/6/86

OFS NO. 3306 221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.  
 PROJECT COMANCHE PEAK UNIT 2  
 SUBJECT CABLE TRAY HANGERS

COMPARISON OF TIME-HISTORY (DYNRE 1) / RESPONSE SPECTRA (DYNRE 4)

MODEL: 1-B

SEISMIC: SSE

COMPUTER RUN ID.

DYNRE 1: DRYZDXJ/DRYODIR

DYNRE 4: DRYZDF7

RESPONSE @		DYNRE 1				DYNRE 4	
NODE	DIRECT.	X <sub>1</sub>	X <sub>2</sub>	X <sub>3</sub>	SRSS (A <sub>r</sub> )	RSS = 1	
402	1	.397	.008	.050	.400	.321	✓
	2	.0002	.343	.001	.343	.371	
	3	.007	.006	.384	.384	.309	✓
403	1	.526	.022	.149	.547	.532	✓
	2	.0004	.343	.002	.343	.371	
	3	.019	.016	.439	.440	.265	✓
404	1	.679	.034	.239	.721	.967	
	2	.0004	.344	.002	.344	.371	
	3	.029	.024	.480	.481	.293	✓
405	1	.403	.014	.039	.405	.327	✓
	2	.002	.345	.006	.345	.360	
	3	.007	.006	.385	.385	.308	✓
406	1	.556	.027	.148	.576	.568	✓
	2	.002	.345	.005	.345	.360	
	3	.019	.017	.441	.442	.265	✓
407	1	.732	.051	.285	.787	1.034	
	2	.002	.345	.001	.345	.357	
	3	.029	.024	.481	.482	.294	✓

EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 02/05/86

CHKD. BY C.Wu DATE 2/6/86

SHEET 87 OF 102  
 OFS NO. 3306221 DEPT. NO. 550

CLIENT \_\_\_\_\_  
 PROJECT TEXAS UTILITIES GENERATING CO.  
COMANCHE PEAK UNIT 2  
 SUBJECT CABLE TRAY HANGERS

COMPARISON OF TIME-HISTORY (DYNRE 1) / RESPONSE SPECTRA (DYNRE 4)

MODEL: 1-B  
 SEISMIC: SSE

COMPUTER RUN ID.  
 DYNRE 1: DRYZDXJ/DRYODIR  
 DYNRE 4: DRYZDF7

RESPONSE @		DYNRE 1				DYNRE 4	
NODE	DIRECT.	X <sub>1</sub>	X <sub>2</sub>	X <sub>3</sub>	SRSS (or)	RSS = 1	
409	1	.408	.011	.088	.418	.349	✓
	2	.0003	.343	.001	.343	.370	
	3	.007	.006	.384	.384	.308	✓
410	1	.563	.040	.277	.629	.656	
	2	.001	.344	.002	.344	.369	
	3	.019	.017	.440	.441	.265	✓
411	1	.741	.075	.474	.883	1.181	
	2	.001	.344	.003	.344	.368	
	3	.029	.024	.480	.481	.293	✓

EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 02/05/86

SHEET 88 OF 102

CHKD. BY C.Wu DATE 2/7/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

MRM FOR TIME HISTRY

MODEL : 1-A

COMPUTER RUN I.D

SEISMIC : OBE

DYNRE 1: DRYZDMN

BOUNDARY : FIXED

DYNRE 4, DRYZCL3

DIRECTION : LONG.

NODE ID.	R <sub>ti</sub> @ TRAY			Σ aT <sub>i</sub> (UP+MID+LOW)	W <sub>T</sub> @ EACH NODE	Σ aT <sub>i</sub> · W <sub>T</sub>
	UP. (1) ~ (2)	MID. (3) ~ (4)	LOW (5) ~ (6)			
7/37/67				NIL	.039	
8/38/68					.079	
9/39/69					.074	
10/40/70					.052	
11/41/71					.034	
12/42/72					.017	

NODE ID.	SUPPORT		
	aT	W <sub>T</sub>	aT · W <sub>T</sub>
302	.245	.021	
303	.337	.021	
304	.448	.015	
305	.248	.013	
306	.335	.013	
307	.442	.013	
309	.245	.014	
310	.339	.014	
311	.450	.009	
Σ		.133	.0445

	TRAY	SUP'T	Σ
aT · W <sub>T</sub>	—	.0445	.0445
W <sub>T</sub>	—	.133	.133
avg = $\frac{\Sigma aT \cdot W_T}{\Sigma W_T}$			.335
A (2-D MODEL ACCL. LEVEL)			.420
MRM = $\frac{avg}{A}$			.80

**EBASCO SERVICES INCORPORATED**

BY C.H. York DATE 02/05/86

SHEET 89 OF 102

CHKD. BY C.Wu DATE 2/7/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.  
 PROJECT COMANCHE PEAK UNIT 2  
 SUBJECT CABLE TRAY HANGERS

**MRM FOR TIME HISTRY**

MODEL : 1-A  
 SEISMIC : OBE  
 BOUNDARY : FIXED  
 DIRECTION : VERT.

COMPUTER RUN I.D  
 DYNRE 1: DRYZDMN  
 DYNRE 4: DRYZCL3

NODE ID.	A <sub>Ti</sub> @ TRAY			Σ A <sub>Ti</sub> (UP+MID+LOW)	W <sub>T</sub> @ EACH NODE	Σ A <sub>Ti</sub> · W <sub>T</sub>
	UP. (7) ~ (12)	MID. (27) ~ (42)	LOW (7) ~ (12)			
7 / 37 / 67	.448	.447	.482		.039	
8 / 38 / 68	.339	.342	.360		.071	
9 / 39 / 69	.180	.180	.180		.074	
10 / 40 / 70	.292	.273	.318		.052	
11 / 41 / 71	.385	.372	.462		.034	
12 / 42 / 72	.427	.426	.499		.017	

NODE ID.	SUPPORT		
	A <sub>T</sub>	W <sub>T</sub>	A <sub>T</sub> W <sub>T</sub>
302	.180	.021	
303	.180	.021	
304	.180	.015	
305	.180	.013	
306	.180	.013	
307	.180	.013	
309	.180	.014	
310	.180	.014	
311	.180	.009	
Σ		.133	.024

Σ = .295 × 3 = .885      .286

	TRAY	SUP'T	Σ
A <sub>T</sub> W <sub>T</sub>	.286	.024	.310
W <sub>T</sub>	.885	.133	1.018
Avg = $\frac{\Sigma A_T W_T}{\Sigma W_T}$			.305
A (2-D MODEL) (ACCL. LEVEL)			.973
MRM = $\frac{avg}{A}$			.313

EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 02/05/86

SHEET 90 OF 102

CHKD. BY C.Wu DATE 2/17/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.  
 PROJECT COMANCHE PEAK UNIT 2  
 SUBJECT CABLE TRAY HANGERS

MRM FOR TIME HISTRY

MODEL : I-A  
 SEISMIC : OBE  
 BOUNDARY : FIXED  
 DIRECTION : TRANS.

COMPUTER RUN I.D  
 DYNRE 1: DRYZDMN  
 DYNRE 4: DRYZCL3

NODE ID.	a <sub>Ti</sub> @ TRAY			Σ a <sub>Ti</sub> (UP+MID+LOW)	W <sub>T</sub> @ EACH NODE	Σ a <sub>Ti</sub> · W <sub>T</sub>
	UP. (7) ~ (12)	MID. (27) ~ (42)	LOW (7) ~ (12)			
7 / 37 / 67	.291	.401	.638		.039	
8 / 38 / 68	.248	.336	.506		.071	
9 / 39 / 69	.219	.236	.285		.074	
10 / 40 / 70	.234	.241	.258		.052	
11 / 41 / 71	.240	.246	.271		.034	
12 / 42 / 72	.250	.248	.282		.017	

NODE ID.	SUPPORT		Σ
	a <sub>T</sub>	W <sub>T</sub>	
302	.218	.021	
303	.236	.021	
304	.279	.015	
305	.218	.013	
306	.236	.013	
307	.280	.013	
309	.218	.014	
310	.236	.014	
311	.280	.009	
	Σ	.133	.032

Σ .295 X 3 = .885 .270

	TRAY	SUP'T	Σ
a <sub>T</sub> W <sub>T</sub>	.270	.032	.302
W <sub>T</sub>	.885	.133	1.018
avg = $\frac{\Sigma a_i W_i}{\Sigma W_i}$			.297
A (2-D MODEL ACC. LEVEL)			.314
MRM = $\frac{avg}{A}$			.945

**EBASCO SERVICES INCORPORATED**

BY C.H. Yeh DATE 02/05/86

SHEET 91 OF 102

CHKD. BY C.Wu DATE 2/7/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

**MRM FOR TIME HISTRY**

MODEL : I-A  
 SEISMIC : SSE  
 BOUNDARY : FIXED  
 DIRECTION : LONG

COMPUTER RUN I.D

DYNRE 1: DRYZDGI/DRYODAB  
 DYNRE 4: DRYZA4B

NODE ID.	RTi @ TRAY			ΣRTi (UP+MID+LOW)	WT @ EACH NODE	ΣRTi · WT
	UP. (1) ~ (12)	MID. (37) ~ (42)	LOW (17) ~ (22)			
7/37/67				-NIL-	.039	
8/38/68					.071	
9/39/69					.074	
10/40/70					.052	
11/41/71					.034	
12/42/72					.017	

NODE ID.	SUPPORT		
	AT	WT	AT · WT
302	.401	.021	
303	.539	.021	
304	.702	.015	
305	.406	.013	
306	.552	.013	
307	.724	.013	
309	.403	.014	
310	.551	.014	
311	.724	.009	
	Σ	.133	.072

Σ — NIL —

	TRAY	SUP'T	Σ
AT · WT	—	.072	.072
WT	—	.133	.133
Avg = $\frac{\Sigma AT \cdot WT}{\Sigma WT}$			.541
A (2-D MODEL ACC'L. LEVEL)			.673
MRM = $\frac{Avg}{A}$			.804

**EBASCO SERVICES INCORPORATED**

BY C.H. yeh DATE 02/06/86  
 CHKD. BY C.Wu DATE 2/7/86

SHEET 92 OF 102  
 OFS NO. 3306.221 DEPT. 550  
 NO. 550

CLIENT \_\_\_\_\_  
 PROJECT TEXAS UTILITIES GENERATING CO.  
COMANCHE PEAK UNIT 2  
 SUBJECT CABLE TRAY HANGERS

**MRM FOR TIME HISTRY**

MODEL : 1-A  
SEISMIC : SSE  
BOUNDARY : FIXED  
DIRECTION : VERT

COMPUTER RUN I.D  
DYNRE 1: DRYZDGJ/DRYODA3  
DYNRE 4: DRYZ44B

NODE ID.	a <sub>Ti</sub> @ TRAY			Σ a <sub>Ti</sub> (UP+MID+LOW)	W <sub>T</sub> EX:11 NODE	Σ a <sub>Ti</sub> · W <sub>T</sub>
	UP. (7) ~ (12)	MID. (37) ~ (42)	LOW (57) ~ (72)			
7 / 37 / 67	.715	.721	.756		.039	
8 / 38 / 68	.583	.588	.620		.071	
9 / 39 / 69	.345	.345	.345		.074	
10 / 40 / 70	.423	.426	.451		.052	
11 / 41 / 71	.553	.554	.581		.034	
12 / 42 / 72	.625	.625	.653		.017	

NODE ID.	SUPPORT		
	a <sub>T</sub>	W <sub>T</sub>	a <sub>T</sub> W <sub>T</sub>
302	.343	.021	
303	.343	.021	
304	.344	.015	
305	.345	.013	
306	.345	.013	
307	.345	.013	
309	.343	.014	
310	.344	.014	
311	.344	.009	
	Σ	.133	.046

Σ .295 × 3  
 = .885      .461

	TRAY	SUP'T	Σ
a <sub>T</sub> W <sub>T</sub>	.461	.046	.507
W <sub>T</sub>	.885	.133	1.018
avg = $\frac{\Sigma a_T W_T}{\Sigma W_T}$			.498
A (2-D MODEL ACCL. LEVEL)			1.373
MRM = $\frac{avg}{A}$			.36

**EBASCO SERVICES INCORPORATED**

BY C.H. Yeh DATE 02/06/86

SHEET 93 OF 102

CHKD. BY C.Wu DATE 2/7/86

OFS NO. 3306.221 DEPT. 550  
NO. 550

CLIENT \_\_\_\_\_  
PROJECT TEXAS UTILITIES GENERATING CO.  
COMANCHE PEAK UNIT 2  
SUBJECT CABLE TRAY HANGERS

**MRM FOR TIME HISTORY**

MODEL : 1-A  
SEISMIC : SSE  
BOUNDARY : FIXED  
DIRECTION : TRANS.

COMPUTER RUN I.D  
DYNRE 1: DRYZDQJ/DRYODAB  
DYNRE 4: DRYZ44B

NODE ID.	RTi @ TRAY			Σ RTi (UP+MID+LOW)	WT @ EACH NODE	Σ RTi · WT
	UP. (7) ~ (12)	MID. (37) ~ (42)	LOW (67) ~ (72)			
7 / 37 / 67	.358	.409	.447		.039	
8 / 38 / 68	.357	.395	.421		.071	
9 / 39 / 69	.357	.370	.384		.074	
10 / 40 / 70	.368	.373	.398		.052	
11 / 41 / 71	.378	.379	.412		.034	
12 / 42 / 72	.382	.383	.421		.017	

NODE ID.	SUPPORT		
	RT	WT	RT · WT
302	.357	.021	
303	.369	.021	
304	.383	.015	
305	.357	.013	
306	.369	.013	
307	.383	.013	
309	.357	.014	
310	.369	.014	
311	.383	.009	
Σ		.133	.049

Σ .295x3  
= .885      .341

	TRAY	SUP'T	Σ
RT · WT	.341	.049	.390
WT	.885	.133	1.018
avg = $\frac{\Sigma RT \cdot WT}{\Sigma WT}$			.383
A (2-D MODEL ACCL. LEVEL)			.504
MRM = $\frac{avg}{A}$			.760



EBASCO SERVICES INCORPORATED

BY C.H. Yeh DATE 02/06/86

SHEET 94 OF 102

CHKD. BY C.Wu DATE 2/7/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT \_\_\_\_\_  
 PROJECT TEXAS UTILITIES GENERATING CO.  
COMANCHE PEAK UNIT 2  
 SUBJECT CABLE TRAY HANGERS

MRM FOR TIME HISTORY (DYNRE 1)

MODEL : I-B COMPUTER RUN ID \_\_\_\_\_  
 SEISMIC : OBE DYNRE 1: DRYZDXF/DRYODUJ  
 BOUNDARY : FIXED DYNRE 4: NIL  
 DIRECTION : LONG.

NODE ID.	RT @ TRAY			ΣATI (UP+MID+LOW)	WT @ EACH NODE	ΣATI·WT
	UP. (1) ~ (16)	MID. (4) ~ (46)	LOW. (7) ~ (76)			
11/41/71					.039	
12/42/72					.079	
13/43/73					.074	
14/44/74					.052	
15/45/75					.034	
16/46/76					.017	

NODE ID.	SUPPORT		
	RT	WT	RT·WT
402	.243	.021	.005
403	.345	.021	.007
404	.473	.015	.007
405	.248	.013	.003
406	.358	.013	.005
407	.495	.013	.006
409	.256	.014	.004
410	.40	.014	.006
411	.583	.009	.005
	Σ	.133	.048

	TRAY	SUP'T	Σ
RT·WT		.048	.048
WT		.133	.133
avg = $\frac{\Sigma RT \cdot WT}{\Sigma WT}$			.361
A (2-D MODEL ACCL. LEVEL)			.420
MRM = $\frac{avg}{A}$			.86

**EBASCO SERVICES INCORPORATED**

BY C.H. yeh DATE 02/06/86

SHEET 95 OF 102

CHKD. BY C.W.Y DATE 2/17/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.  
 PROJECT COMANCHE PEAK UNIT 2  
 SUBJECT CABLE TRAY HANGERS

**MRM FOR TIME HISTORY**

MODEL : I-B  
 SEISMIC : OBE  
 BOUNDARY : FIXED  
 DIRECTION : VERT.

COMPUTER RUN I.D  
DYNRE 1: DRYZDXF/DRYODUJ  
DYNRE 4: DRYZC67

NODE ID.	RT @ TRAY			Σ RTz (UP+MID+Low)	WT @ EACH NODE	Σ RTz · WT
	UP. (1) ~ (6)	MID. (7) ~ (12)	LOW (13) ~ (18)			
11/41/71	.342	.358	.392		.039	
12/42/72	.260	.270	.288		.079	
13/43/73	.180	.180	.180		.074	
14/44/74	.404	.408	.411		.052	
15/45/75	.465	.472	.481		.034	
16/46/76	.412	.414	.443		.017	

Σ  $.295 \times 3$   
 $= .885$        $.281$

NODE ID.	SUPPORT		
	RT	WT	
402	.180	.021	
403	.180	.021	
404	.180	.015	
405	.180	.013	
406	.180	.013	
407	.180	.013	
409	.180	.014	
410	.180	.014	
411	.180	.009	
Σ	.133	.024	

	TRAY	SUP'T	Σ.
RT · WT	.281	.024	.305
WT	.885	.133	1.018
avg = $\frac{\Sigma RT \cdot WT}{\Sigma WT}$		.300	
A (2-D MODEL) (ACCL. LEVEL)		.971	
MRM = $\frac{avg}{A}$		.309	

**EBASCO SERVICES INCORPORATED**

BY C.H. Giel DATE 02/06/86

SHEET 96 OF 102

CHKD. BY C.Wu DATE 2/7/86

OFS NO. 3306.221 DEPT. 550  
NO. 550

CLIENT \_\_\_\_\_  
PROJECT TEXAS UTILITIES GENERATING CO.  
CONDUIT PEAK UNIT 2  
SUBJECT CABLE TRAY HANGERS

**MRM FOR TIME HISTORY**

MODEL : I-B  
SEISMIC : OBE  
BOUNDARY : FIXED  
DIRECTION : TRANS.

COMPUTER RUN ID  
DYNRE 1: DRYZDXF/DRYODUJ  
DYNRE 4: DRYZC67

NODE ID.	RT @ TRAY			ΣRT <sub>T</sub> (UP+MID+LOW)	WT @ EACH NODE	ΣRT <sub>T</sub> · WT
	UP. (1) ~ (16)	MID. (4) ~ (46)	LOW (7) ~ (76)			
11/41/71	.329	.478	.615		.039	
12/42/72	.261	.584	.491		.079	
13/43/73	.241	.285	.321		.074	
14/44/74	.405	.535	.653		.052	
15/45/75	.430	.649	.504		.034	
16/46/76	.525	.722	.902		.017	

NODE ID.	SUPPORT		
	RT	WT	RT · WT
402	.239	.021	
403	.282	.021	
404	.318	.015	
405	.240	.013	
406	.283	.013	
407	.319	.013	
409	.240	.014	
410	.282	.014	
411	.317	.009	
		.133	.037

Σ  
= .295 × 3  
= .885      .393

	TRAY	SUP'T	Σ
RT · WT	.393	.037	.430
WT	.885	.133	1.018
AVG = $\frac{\Sigma RT \cdot WT}{\Sigma WT}$			.422
A (2-D MODEL ACCL. LEVEL)			.725
MRM = $\frac{AVG}{A}$			.582

**EBASCO SERVICES INCORPORATED**

BY C.H. Yeh DATE 02/06/86

SHEET 97 OF 102

CHKD. BY C.Wu DATE 2/7/86

OFS NO. 3306.221 DEPT. 550  
NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.  
PROJECT COMANCHE PEAK UNIT 2  
SUBJECT CABLE TRAY HANGERS

**MRM FOR TIME HISTRY**

MODEL : I-B  
SEISMIC : SSE  
BOUNDARY : FIXED  
DIRECTION : LONG

COMPUTER RUN I.D

DYNRE 1: DRYEDXJ/DRYODTR  
DYNRE 4: DRYEDF7

NODE ID.	RT @ TRAY			EAT (UP+MID+LOW)	WT @ EACH NODE	EAT · WT
	UP. (1) ~ (6)	MID. (7) ~ (12)	LOW (13) ~ (16)			
11/41/71				/	.039	
12/42/72					.079	
13/43/73					.074	
14/44/74					.052	
15/45/75					.034	
16/46/76					.017	

NODE ID.	SUPPORT		
	RT	WT	RT+WT
402	.40	.021	
403	.547	.021	
404	.721	.015	
405	.405	.013	
406	.576	.013	
407	.787	.013	
409	.418	.014	
410	.629	.014	
411	.883	.059	
$\Sigma$		.133	.076

$\Sigma$  — Nil —

	TRAY	SUP'T	$\Sigma$
RT · WT	—	.076	.076
WT	—	.133	.133
avg = $\frac{\Sigma RT \cdot WT}{\Sigma WT}$			.574
A (2-D MODEL ACCL. LEVEL)			.673
MRM = $\frac{avg}{A}$			.853

**EBASCO SERVICES INCORPORATED**

BY C.H. Yeh DATE 02/06/86

SHEET 98 OF 102

CHKD. BY C.Wu DATE 2/7/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT \_\_\_\_\_  
 PROJECT TEXAS UTILITIES GENERATING CO.  
COMANCHE PLANT UNIT 2  
 SUBJECT CABLE TRAY HANGERS

**MRM FOR TIME HISTRY**

MODEL : I-B  
SEISMIC : SSE  
BOUNDARY : FIXED  
DIRECTION : VERT.

COMPUTER RUN I.D  
DYNRE 1. DRYZDXJ/DRYODTR  
DYNRE 4. DRYZDF7

NODE ID.	RTi @ TRAY			ΣATI (UP+MID+LOW)	WT @ EACH NODE	ΣATI·WT
	UP. (1) ~ (16)	MID. (4) ~ (46)	LOW. (7) ~ (76)			
11/41/71	.562	.575	.597		.039	
12/42/72	.438	.446	.457		.079	
13/43/73	.345	.345	.345		.074	
14/44/74	.692	.691	.682		.052	
15/45/75	.809	.807	.801		.034	
16/46/76	.754	.753	.759		.017	

NODE ID.	SUPPORT		
	AT	WT	ATWT
402	.343	.021	
403	.343	.021	
404	.344	.015	
405	.345	.013	
406	.345	.013	
407	.345	.013	
409	.343	.014	
410	.344	.014	
411	.344	.009	
		.133	.046

Σ .295x3 = .885      .478

	TRAY	SUP'T	Σ.
ATWT	.478	.046	.524
WT	.885	.133	1.018
Avg = $\frac{\Sigma ATWT}{\Sigma WT}$		.515	
A (2-D MODEL ACCL. LEVEL)		1.372	
MRM = $\frac{AVG}{A}$		.375	

EBASCO SERVICES INCORPORATED

BY C.H. Uel DATE 02/06/86

SHEET 99 OF 102

CHKD. BY C.Wu DATE 2/7/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

MRM FOR TIME HISTY

MODEL : I-B  
 SEISMIC : SSE  
 BOUNDARY : FIXED  
 DIRECTION : TRANS

COMPUTER RUN ID  
 DYNRE 1: DRYZDXJ / DRYODTR  
 DYNRE 4: DRYEDF7

NODE ID.	RTi @ TRAY			ΣRTi (UP+MID+LOW)	WT @ EACH NODE	ΣRTi · WT
	UP. (1) ~ (16)	MID. (2) ~ (4)	LOW. (7) ~ (7)			
11/41/71	.350	.384	.452		.039	
12/42/72	.352	.370	.428		.079	
13/43/73	.387	.444	.486		.074	
14/44/74	.621	.793	.956		.052	
15/45/75	.732	.956	1.171		.034	
16/46/76	.802	1.061	1.308		.017	

NODE ID.	SUPPORT	
	RT	WT
402	.384	.021
403	.440	.021
404	.481	.015
405	.385	.013
406	.442	.013
407	.482	.013
409	.384	.014
410	.441	.014
411	.481	.009
		.133
		.057

Σ .295x3  
 = .885      .509

	TRAY	SUPT	Σ
RT · WT	.509	.057	.566
WT	.885	.133	1.018
Avg = $\frac{\Sigma RT \cdot WT}{\Sigma WT}$			.556
A (2-D MODEL ACCL. LEVEL)			1.083
MRM = $\frac{AVG}{A}$			.514

EBASCO SERVICES INCORPORATED

BY S.W.V. DATE 2-5-86

SHEET 100 OF 102

CHKD. BY YEH DATE 2-5-86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

CABLE TRAY HANGERS

SUBJECT Multiple Response Multiplier for C.T.H Systems W/90° Bent (Time History)

MODEL	APPROACH	RANGE OF AMPLIFICATION FACTOR							
		OBE (4%)				SSE (7%)			
		VERT.	TRANS.	LONG.	RUN ID	VERT.	TRANS.	LONG.	RUN ID
1-A	RESPONSE SPECTRA (DYNRE4, RSS=1)	0.38	1.13	1.00	DRYZCL3	0.44	0.75	0.85	DRYZAAB
	TIME HISTORY (DYNRE 1)	0.31	0.95	0.80	DRYZDMN	0.36	0.76	0.80	DRYZD4J DRYODA3
1-B	RESPONSE SPECTRA (DYNRE4, RSS=1)	0.38	0.57	1.07	DRYZC67	0.44	0.47	0.92	DRYZDF7
	TIME HISTORY (DYNRE 1)	.31	.58	.86	DRYZDXF DRYODUJ	.38	.51	.85	DRYZDXJ DRYODTR

## EBASCO SERVICES INCORPORATED

NEW YORK

BY Z H Zhou DATE 2/10/86SHEET 101 OF 102CHKD. BY YEH DATE 2/10/86OFS NO. 3306.221 DEPT. NO. 550CLIENT TEXAS UTILITIES GENERATING CO.PROJECT COMANCHE PEAK UNIT 2SUBJECT CABLE TRAY HANGERSCONCLUSIONS

The study of a Multi-mode Response Multiplier (MRM) was extended to investigate a cable tray-hanger system with bend. Two models <sup>(1-A and 1-B)</sup> were constructed for this purpose.

one with symmetrical settings. The other with cable tray terminated at one end. Hangers as well as cable tray used the identical configuration as those of ~~the~~ Mode 1 in previous straight run MRM study.

A residual load method was used to account for the ~~missing~~ contribution due to the higher mode beyond the cut-off frequency in the modal response analysis. Both nodal accelerations and support reactions were investigated in this study. The results of MRMs were summarized on Tables 1 and 2.



EBASCO SERVICES INCORPORATED

NEW YORK

BY I HZ10U DATE 2/10/86

SHEET 102 OF 102

CHKD. BY YEH DATE 2/10/86

OFS NO. 3306.221 DEPT. NO. 550

CLIENT TEXAS UTILITIES GENERATING CO.

PROJECT COMANCHE PEAK UNIT 2

SUBJECT CABLE TRAY HANGERS

The results of this study further support and substantiate the amplification factor of 1.25 is adequate and conservative to use ~~to~~ in the equivalent static analysis (ESA) method, regarding the nodal acceleration as well as support reaction.