



Westinghouse
Electric Corporation

Energy Systems

Box 355
Pittsburgh Pennsylvania 15230-0355

DCP/NRC1057
NSD-NRC-97-5348
Docket No.: 52-003

September 26, 1997

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: T. R. QUAY

SUBJECT: DRAFT AP600 PRA ATTACHMENT 54B - SURGE LINE FLOODING EFFECT ON SHUTDOWN PRA

Dear Mr. Quay:

A telecon was held between the NRC and Westinghouse on September 5, 1997, to discuss the AP600 shutdown PRA. Westinghouse agreed to an NRC-requested action during the telecon to provide four additional shutdown PRA sensitivity studies and to provide a justification for not requantifying the PRA given the recent change to the surge line flooding success criteria. A description of the additional sensitivity studies is provided as Attachment 6 to NRC's September 18, 1997, letter which summarized the telecon.

Enclosure 1 of this letter is a draft of Attachment 54B which will be placed at the end of AP600 PRA Chapter 54 in the next revision to the PRA report. Attachment 54B provides the four requested shutdown PRA sensitivity studies.

Enclosure 2 provides a page change correction to Section 54A.1 of Attachment 54A of the AP600 PRA. The changes presented in Enclosure 2 will be incorporated into the next revision of the PRA report.

Westinghouse believes Enclosure 1 satisfies the NRC-requested additional sensitivity studies. The telecon open item is represented by item #5751 in the OITS. Westinghouse will change the Westinghouse status column to "Action N" for the sensitivity study request, but will keep "Action W" for the requested justification for not requantifying the PRA to address the change to surge line flooding success criteria. The justification will be provided by separate letter. The staff is requested to review the enclosures and to provide Westinghouse with the action to be placed in the NRC status column of item #5751.

204

3407A.WPF

971001039B 970926
PDR ADDCK 05200003
A PDR




DCP/NRC1057
NSD-NRC-97-5348

-2-

September 26, 1997

Please contact Cynthia L. Haag on (412) 374-4277 if you have any questions concerning this transmittal.



Brian A. McIntyre, Manager
Advanced Plant Safety and Licensing

jml

Enclosures

cc: J. M. Sebrosky, NRC (Enclosures)
N. J. Liparulo, Westinghouse (w/o Enclosures)

**Enclosure 1 to Westinghouse
Letter DCP/NRC1057**

September 26, 1997

ATTACHMENT 54B

SURGE LINE FLOODING EFFECT ON LOW-POWER AND SHUTDOWN RISK ASSESSMENT

54B.1 Effect on Shutdown PRA, Revision 6

An examination of the surge line flooding concerns was conducted on the AP600 design to determine the capability of the IRWST gravity injection function during reduced inventory conditions if normal residual heat removal (RNS) cooling is lost.

The results of that examination indicated that, if RNS cooling is lost during reduced inventory conditions with the reactor coolant system open, a vent path through the ADS 4th stage is required to preclude the occurrence of surge line flooding and thereby not affect gravity injection.

Therefore, to address surge line flooding, Westinghouse has included the requirement for 1-out-of-4 ADS stage 4 valves to be opened, in the success criteria for events during reduced inventory conditions. This success criterion for 1-out-of-4 ADS stage 4 valves to be opened is determined by analyses documented in Section 4.8 of the AP600 Shutdown Evaluation Report, WCAP-14837, (Reference 54B-1). Technical Specification 3.4.14 allows for 2 of the 4 ADS stage 4 valves to be out of service during reduced inventory conditions. This technical specification provision is to allow for unscheduled repairs of as many as two ADS stage 4 valves during drained conditions.

Sensitivity studies are conducted to determine the effect of the additional ADS success criteria for surge line flooding on the shutdown PRA and basic insights obtained from Revision 6 of the shutdown PRA. All shutdown drained cases are affected by the surge line flooding issue. These cases are as follows:

IEV-RCSOD	RCS overdraining when entering mid-loop condition
IEV-LISPED	Loss of offsite power during mid-loop operation
IEV-RNSD	Loss of RNS during mid-loop operation
IEV-CCWD	Loss of CCS/SWS during mid-loop operation
IEV-LOCA24D	LOCA through RNS-V024 during mid-loop operation

The method of evaluating the effect of this success criterion on the shutdown PRA involves the following process:

- Include ADS stage 4 in the shutdown event trees for drained conditions. The revised event trees are provided in Figures 54B-1 through 54B-5.
- Construct two ADS fault trees: ADASD for cases with loss of offsite power available, and ADASDP for the station blackout case. The success criteria summary tables for these fault trees are provided in Tables 54B-1 and 54B-2.
- Evaluate the impact of these changes on the baseline and focused shutdown core damage frequencies.

Note, the shutdown PRA, Revision 6, reflects the conservative modeling of RNS trees in sequences associated with the loss of offsite power (LOSP) initiating event. This conservatism

consists of using an OR gate instead of an AND at the second level of the RNS fault tree files RNP2, RNT2, RNP2D and RNT2D. By correcting of these fault tree files, the baseline core damage frequency changes from 5.5E-08 to 4.7E-08 events per year; the dominant core damage sequences with single RNS train failure from LOSP events are eliminated by these corrections. The corrected RNS fault tree files are used in this evaluation to resolve the surge line issue.

54B.1.1 Baseline PRA Shutdown Core Damage Frequency Sensitivity Results

By incorporating the changes discussed above into the shutdown PRA model, the baseline core damage frequency (CDF) changes from 4.7E-08 to 6.7E-08 events per year; an increase of 43 percent. However, a CDF of 6.7E-08 is still very low.

54B.1.2 Focused PRA Shutdown Core Damage Frequency Sensitivity Results

By incorporating the changes discussed above into the model from the shutdown PRA, Revision 6, the focused PRA sensitivity study core damage frequency changes from 4.1E-07 to 5.1E-07 events per year; an increase of 24 percent. However, a CDF of 5.1E-07 is still very low.

54B.2 Design Change Effect on Surge Line Sensitivity Studies

This section documents the effect of design changes on the baseline and focused PRA results from the surge line sensitivity studies addressed in the previous section (54B.1) of this attachment. The cutset output files for the results in subsections 54B.1.1 and 54B.1.2 form the starting point of these additional sensitivity studies.

These particular design changes, made subsequent to preparing the design reported in the shutdown PRA, Revision 6, are as follows:

1. IRWST injection check valves maintaining the RCS pressure boundary changed to squib valves; (i.e., check valves 123A/B and 125A/B are changed to squib valves 123A/B and 125A/B, respectively)
2. IRWST recirculation paths changed from 10-inch and 4-inch lines to 6-inch lines in all paths
3. IRWST motor-operated valves 118A & B and check valves 120A & B maintaining the IRWST water level changed to squib valves
4. CCS valves to the RNS heat exchanger changed from manual to air-operated
5. The capacity of the service water basin reduced; its duration changed from 24 hours to 12 hours
6. Service water system valves V037A & B changed from air-operated to motor-operated
7. The number of PRHR heat exchangers changed from two to one
8. RNS check valves V015A & B on the DVI lines changed to stop check valves.

This evaluation is an extension of the studies documented in Attachment 54A. The same basic event changes, shown in Attachment 54A, are made in these studies for the base cases. Additional

basic event changes related to the 4th stage ADS components and human error probabilities (HEPs) are made to perform sensitivity studies in addition to those in Attachment 54A.

In these studies, the effect of the design changes are evaluated together by performing the steps in Section 54A.9, but on the surge line-related cutset files. In other words, the sensitivity studies that assess the effect of each design change (as documented in Sections 54A.1 through 54A.8) are not performed in this exercise.

The sensitivity studies for this evaluation, consisting of the following cases, are documented in the subsections that follow:

- Case 1 - Effect of design changes on the baseline surge line core damage frequency
- Case 2 - Effect of design changes on the focused PRA sensitivity study surge line core damage frequency
- Case 3 - Effect on case 1 core damage frequency with single IRWST train and 2 ADS 4th stage valves operation
- Case 4 - Effect on case 1 core damage frequency when all HEPs are set to 0.5
- Case 5 - Effect on case 3 core damage frequency when all HEPs are set to 0.5.

54B.2.1 Case 1 Sensitivity Study - Effect on Baseline (Surge Line) Results

The Case 1 sensitivity study estimates the effect of the design changes on the baseline shutdown core damage frequency of 6.7E-08, discussed above in subsection 54B.1.1.

This estimation is conducted by making changes to the basic events in the quantification output file from the surge line Level 1 baseline case. The following steps were done:

- a) Revise basic event probabilities associated with the new IRWST configuration and unscheduled maintenance unavailability discussed in subsection 54A.1; IWX-MV-GO1 is set to 2.6E-05, IWX-CV-AO set to 3.0E-05, IRWMOD05S set to 3.0E-03, and IRWMOD06S is set to 0.
- b) Revise the basic event frequencies for CCS initiating events to reflect the changes discussed in subsection 54A.4; IEV-CCWD is set to 6.02E-04, and IEV-CCWND set to 3.75E-03.
- c) Revise the basic event frequencies for the loss of offsite power initiating events to reflect the changes discussed in subsection 54A.5; IEV-LISPED is set to 4.44E-03, and IEV-LOSPND is set to 1.71E-02.

Having modified the basic events to incorporate these design changes into the shutdown PRA, the baseline quantification output file is recalculated to estimate the shutdown core damage frequency. The resulting shutdown core damage frequency changes from 6.7E-08 events per year to 7.0E-08 events per year. The top 200 cutsets from this quantification output file are shown in Table 54B-3. The associated component importance file is shown in Table 54B-4.

54B.2.2 Case 2 Sensitivity Study - Effect on Focused PRA (Surge Line) Results

The Case 2 sensitivity study estimates the effect of the design changes on the focused PRA sensitivity study core damage frequency of 5.1E-07, discussed above in subsection 54B.1.2.

This estimation is conducted by making changes to the basic events in quantification output file from the surge line Level 1 focused PRA case. The following steps were done:

- a) Revise basic event probabilities associated with the new IRWST configuration and unscheduled maintenance unavailability discussed in subsection 54A.1; IWX-MV-GO1 is set to 2.6E-05, IWX-CV-AO set to 3.0E-05, IRWMOD05S set to 3.0E-03, and IRWMOD06S set to 0.
- b) Revise the basic event frequencies for CCS initiating events to reflect the changes discussed in subsection 54A.4; IEV-CCWD is set to 6.02E-04, and IEV-CCWND set to 3.75E-03.

Note, the service water system basin capacity design change is not included in the focused PRA sensitivity study because this failure does not affect the SWS-related initiating events, and the focused PRA does not credit nonsafety-related systems in the event trees.

Having modified the basic events to incorporate these design changes into the shutdown PRA, the focused PRA quantification output file is recalculated to estimate the shutdown core damage frequency. The resulting shutdown core damage frequency changes from 5.1E-07 events per year to 4.8E-07 events per year. The top 200 cutsets from this quantification output file are shown in Table 54B-5. The associated component importance file is shown in Table 54B-6.

54B.2.3 Case 3 Sensitivity Study - Single IRWST Train & 2 ADS 4th Stage Operation

AP600 Technical Specifications 3.5.8 and 3.4.14 allow one of the IRWST injection trains and two ADS 4th stage valves to be out of service during reduced inventory conditions. These technical specification provisions are to allow for unscheduled repairs of components in any one of the IRWST injection trains and any two ADS 4th stage valves during drained conditions. These provisions are not intended to allow plant personnel to schedule or plan maintenance activities to be conducted during reduced inventory conditions, and, therefore, should not be misconstrued as such.

However, a sensitivity study is performed to estimate the core damage frequency if one train of IRWST and two ADS 4th stage valves are failed at the same time. For this conservative estimate of the design configuration, one IRWST train and two ADS 4th stage valves are assumed to fail during filled and drained shutdown conditions. That is, it is assumed that (a) the IRWST has only one injection line by essentially setting the other train failure probability equal to 1.0; and (b) the ADS 4th stage has only two valves by propagating the common cause failure of two 4th stage valves through the shutdown model.

Note, the ADS 4th stage operation with only 2 valves is reflected in the model by changing only the common cause of the 4 ADS 4th stage squib valves to common cause of 2 ADS 4th stage squib valves. Changes to the squib valves random failure probabilities were not attempted since these changes would not change the result of this sensitivity study.

This sensitivity is performed by modifying basic events in the quantification output file from Case 1, discussed above in subsection 54B.2.1. The following basic events are modified as shown:

ADX-EV-SA = 3.8E-05; IWACV122AO = 1.0; IWACV123AO = 5.8E-04; IWACV124AO = 1.0; IWACV125AO = 5.8E-04; IWBCV122AO = 1.75E-03; IWBCV123AO = 5.8E-04; IWBCV124AO = 1.75E-03; IWBCV125AO = 5.8E-04; IWX-CV-AO = 3.1E-05; IWX-MV-

GO1 = 3.8E-05; IRWMOD05S = 0; IRWMOD06S = 0; RNSMOD05S = 1

Requantification of the cutset file with these changes provides a core damage frequency of 1.2E-06 events per year. However, a core damage frequency of 1.2E-06 is still quite low. The top 200 cutsets from this quantification output file is shown in Table 54B-7. The associated component importance file is shown in Table 54B-8.

This estimate of the core damage frequency at shutdown is believed to be conservative for the following reasons:

- One train of IRWST is assumed to fail during both drained and non-drained conditions
- Two ADS 4th stage valves are assumed to fail during both drained and non-drained conditions
- The IRWST water is considered to be clean water, suitable for injection into the RCS
- The IRWST is covered to preclude material that could clog the strainer from entering the tank
- The IRWST strainer is assigned a conservative failure probability of 2.4E-04 in the PRA. The plugging of the IRWST strainer is expected to be a much less probable event than reflected in a failure probability of 2.4E-04.

54B.2.4 Case 4 Sensitivity Study - Setting HEPs to 0.5 in Case 1 Cutsets

The Case 4 sensitivity study estimates the effect of the setting the human error probabilities to 0.5 in the quantification output file from Case 1, discussed above in subsection 54B.2.1. The following basic events are set to 0.5:

ADN-MAN01, CCB-MAN01, IWN-MAN01, IWN-MAN01C, LPM-MAN05, REC-MANDAS, REC-MANDASC, RHN-MAN03, RHN-MAN04, RHN-MAN04-SUCC; RHN-MAN05, RHN-MAN05C, PRN-MAN01, SWB-MAN02, and ZON-MAN01.

Requantification of the cutset file with these changes provides a core damage frequency of 2.4E-06 events per year. However, a core damage frequency of 2.4E-06 is still quite low. The top 200 cutsets from this quantification output file is shown in Table 54B-9. The associated component importance file is shown in Table 54B-10.

54B.2.5 Case 5 Sensitivity Study - Setting HEPs to 0.5 in Case 3 Cutsets

The Case 5 sensitivity study estimates the effect of the setting the human error probabilities to 0.5 in the quantification output file from Case 3, discussed above in subsection 54B.2.3. The following basic events are set to 0.5:

ADN-MAN01, CCB-MAN01, IWN-MAN01, IWN-MAN01C, LPM-MAN05, REC-MANDAS, REC-MANDASC, RHN-MAN03, RHN-MAN04, RHN-MAN04-SUCC; RHN-MAN05, RHN-MAN05C, PRN-MAN01, SWB-MAN02, and ZON-MAN01.

Requantification of the cutset file with these changes provides a core damage frequency of 6.2E-

06 events per year. However, a core damage frequency of 6.2E-06 is still quite low. The top 200 cutsets from this quantification output file is shown in Table 54B-11. The associated component importance file is shown in Table 54B-12.

54B.3 Conclusion

The design changes were evaluated to determine their effect on the PRA results and insights from the surge line sensitivity study. The previous subsections provide details on the five quantitative sensitivity studies that basically assess the effects of these design changes on the shutdown (surge line) baseline and focused PRA core damage frequencies. The results of this evaluation are as follows:

- a) When the design changes are incorporated together, the baseline (surge line) shutdown PRA core damage frequency changes from 6.7E-08 to 7.0E-08 events per year; an increase of only 4 percent.
- b) When the design changes are incorporated together, the focused (surge line) shutdown PRA core damage frequency changes from 5.1E-07 to 4.8E-07 events per year; a decrease of 6 percent.
- c) Although some top cutsets are reordered, the top 50 to 100 cutsets are more or less the same. This can be seen when the cutsets for the baseline and focused shutdown studies in Section 54B.1 are compared with the results from Cases 1 and 2 in Section 54B.2.
- d) Although basic events importance are changed and reordered in some cases, the most important events are relatively the same, as shown by their "importance % decrease" values in the related component importance tables.
- e) When the HEPs are set to 0.5 in the surge line baseline case, the core damage frequency becomes 2.4E-06 events per year, which is about 34 times greater than the base case core damage frequency of 7.0E-08 events per year. This increase in the base case core damage frequency is somewhat significant even though a core damage frequency of 2.4E-06 is still quite low. The result indicates that the operator actions are important in maintaining a very low core damage frequency for internal events at shutdown.
- f) Although the functions of the IRWST and the RNS and its support systems (CCS and SWS) are still important to maintaining plant safety during shutdown, the function of ADS becomes more important than reflected in Revision 6 of the PRA, since the ADS 4th stage is now required to preclude the effects of surge line flooding and thereby maintain plant safety. The importance of these functions are due mainly because of their required operability during reduced inventory conditions, where initiating events dominate the plant shutdown risk.

54B.4 References

- 54B-1 "AP600 Shutdown Evaluation Report," WCAP-14837, Revision 0, March 1997.

Table 54B-1

FAULT TREE "ADASD"
SUCCESS CRITERIA SUMMARY

Event description:	Automatic depressurization system, automatically actuated, fails to provide RCS vent path following a loss of the residual heat removal capability during reduced inventory shutdown conditions with the vessel head intact. For this scenario, offsite power is available
Success configuration:	1 out of 4 lines of stage 4
System initial status:	All squib valves of stage 4 closed
Mission time:	24 hours
Components required to change status:	Squib valve of stage 4 is required to open
Initiating signals:	PMS: automatic actuation on low hot leg water level signal
Operator actions:	Manual actuation from the main control room when automatic actuation fails - basic events: LPM-MAN05 and ADN-MAN01 performed through PMS - basic event: REC-MANDAS performed through DAS

Table 54B-2

FAULT TREE "ADASDP"
SUCCESS CRITERIA SUMMARY

Event description:	Automatic depressurization system, automatically actuated, fails to provide RCS vent path following a loss of the residual heat removal capability during reduced inventory shutdown conditions with the vessel head intact. For this scenario, station blackout has occurred
Success configuration:	1 out of 4 lines of stage 4
System initial status:	All squib valves of stage 4 closed
Mission time:	24 hours
Components required to change status:	Squib valve of stage 4 is required to open
Initiating signals:	PMS: automatic actuation on low hot leg water level signal
Operator actions:	Manual actuation from the main control room when automatic actuation fails - basic events: LPM-MAN05 and ADN-MAN01 performed through PMS - basic event: REC-MANDAS performed through DAS

Table 54B-3
CASE 1 LIST OF TOP 200 DOMINANT CUTSETS

Reduced Sum of Cutsets: 7.0490E-08

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	EVENT PROB	IDENTIFIER			
1	1.81E-08	25.68	LOSS OF CCS/SWS DUE TO CCF OF THE SQUIB VALVES TO OPERATE	6.02E-04 3.00E-05	IEV-COWD ADX-EV-SA			
2	1.57E-08	22.27	LOSS OF CCS/SWS CCF OF IRWST INJ MOVs 121A, 121B, & RNS V023	6.02E-04 2.60E-05	IEV-COWD IWX-MV-G01			
3	7.22E-09	10.24	LOSS OF CCS/SWS CCF OF STRAINERS IN IRWST TANK	6.02E-04 1.20E-05	IEV-COWD IWX-FL-GP			
4	3.09E-09	4.38	LOSS OF OFFSITE SOFTWARE CCF POWER INITIATING EVENT OCCURS AC POWER RECOVERED IN 1 HOUR OF ALL CARDS	4.44E-03 5.80E-01 1.20E-06	IEV-LOSPD SUC-RIS CCX-SPTW			
5	2.45E-09	3.48	LOSS OF RNS WITH RCS DRAINED DUE TO CCF OF THE SQUIB VALVES TO OPERATE	8.15E-05 3.00E-05	IEV-RNSD ADX-EV-SA			
6	2.24E-09	3.18	LOSS OF OFFSITE FAILURE TO SOFTWARE CCF POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ALL CARDS	4.44E-03 4.20E-01 1.20E-06	IEV-LOSPD OTH-R1 CCX-SPTW			
7	2.19E-09	3.11	LOSS OF CCS/SWS CCF OF ORIFICES	6.02E-04 3.63E-06	IEV-COWD CCX-DRY-SPX			
8	2.12E-09	3.01	LOSS OF RNS WITH RCS DRAINED CCF OF IRWST INJ MOVs 121A, 121B, & RNS V023	8.15E-05 2.60E-05	IEV-RNSD IWX-MV-G01			
9	1.83E-09	2.60	OVERDRAINING OF RHN-MAN00C COND. PROB. OF RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT TO ISOLATE RNS PIPE RUPTURE	4.44E-06 5.50E-02 5.00E-02 1.50E-01	IEV-RCSOD RHN-MAN04 IWN-MAN00C RHN-MAN05C			
10	1.58E-09	2.24	LOSS OF CCS/SWS CCF OF PRESSURE TRANSMITTERS	6.02E-04 2.63E-06	IEV-COWD CCX-XMTRX			
11	9.78E-10	1.39	LOSS OF RNS WITH RCS DRAINED CCF OF STRAINERS IN IRWST TANK	8.15E-05 1.20E-05	IEV-RNSD IWX-FL-GP			
12	7.24E-10	1.03	OVERDRAINING OF RHN-MAN04-SUCC COND. PROB. OF RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT TO OPEN TWO IRWST MOVs	4.44E-06 9.45E-01 1.15E-03 1.50E-01	IEV-RCSOD RHN-MAN04-SUCC IWN-MAN00 RHN-MAN05C			
13	7.22E-10	1.02	LOSS OF CCS/SWS SOFTWARE CCF WITH RCS DRAINED INITIATING EVENT OCCURS OF ALL CARDS	6.02E-04 1.20E-06	IEV-CCW IWX-S/TW			
14	5.04E-10	.71	LOCA/RNS-V024 CCF OF GRAVITY	OPENS INITIATING EVENT OCCURS INJECTION CHECK VALVES TO OPEN	WITH RCS FILLED	1.68E-05 3.00E-05	IEV-LOCA24ND IWX-CV-A0	
15	4.33E-10	.61	LOSS OF CCS/SWS MECHANICAL IRWST DISCHARGE	FAILURE CAUSES LINE "B"	MOV 121A TO STRAINER	FAIL-TO-OPEN PLUGGED	6.02E-04 3.00E-03 2.40E-04	IEV-COWD IRWMOD05S IWB-PLUG

Table 54B-3

CASE 1 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME			EVENT PROB	IDENTIFIER
16	3.75E-10	.53	LOSS OF CCS/SWS FAILURE OF CCF OF THE POWER	WITH RCS FILLED MANUAL DAS INTERFACE OUTPUT BOARDS IN PMS	INITIATING EVENT OCCURS ACTUATION	3.75E-03 1.16E-02 8.62E-06	IEV-CWND REC-MANDAS CCX-EP-SAM
17	3.59E-10	.51	LOSS OF CCS/SWS COND. PROB. OF CCF OF ORIFICES OPERATOR FAILS	WITH RCS FILLED REC-MANDAS	(FAILURE OF MANUAL DAS ACT TO RECOGNIZE THE NEED FOR RCS)	3.75E-03 5.06E-01 2.77E-04 6.83E-04	IEV-CWND REC-MANDASC CCX-ORY-SP LPM-MAN05
18	3.39E-10	.48	LOCA/RNS-V024 DUE TO CCF OF	OPENS INITIATING THE SQUIB VALVES TO OPERATE	EVENT OCCURS WITH RCS DRAINED	1.13E-05 3.20E-05	IEV-LOCA24D ADX-EV-SA
19	3.23E-10	.46	LOSS OF CCS/SWS FAILURE OF CCF OF THE POWER	WITH RCS FILLED MANUAL DAS INTERFACE OUTPUT BOARDS IN PMS	INITIATING EVENT OCCURS REACTOR TRIP HARDWARE	3.75E-03 1.00E-02 8.62E-06	IEV-CWND MDAS CCX-EP-SAM
20	2.96E-10	.42	LOSS OF RNS WITH CCF OF ORIFICES	WITH RCS DRAINED	INITIATING EVENT OCCURS	8.15E-05 3.63E-06	IEV-RNSD CCX-ORY-SPX
21	2.94E-10	.42	LOCA/RNS-V024 CCF OF IRWST INJ	OPENS INITIATING MOVS 121A, 121B, & RNS V023	EVENT OCCURS WITH RCS DRAINED	1.13E-05 2.60E-05	IEV-LOCA24D IWX-MV-G01
22	2.60E-10	.37	LOSS OF CCS/SWS COND. PROB. OF CCF OF PRESSURE OPERATOR FAILS	WITH RCS FILLED REC-MANDAS TRANSMITTERS TO RECOGNIZE THE NEED FOR RCS	INITIATING EVENT OCCURS (FAILURE OF MANUAL DAS ACT DEPRESSURIZATION	3.75E-03 5.06E-01 2.01E-04 6.83E-04	IEV-CWND REC-MANDASC CCX-XMTR195 LPM-MAN05
23	2.14E-10	.30	LOSS OF RNS WITH CCF OF PRESSURE	WITH RCS DRAINED TRANSMITTERS	INITIATING EVENT OCCURS	8.15E-05 2.63E-06	IEV-RNSD CCX-XMTRX
24	2.02E-10	.29	LOCA/RNS-V024 CCF OF STRAINERS	OPENS INITIATING IN IRWST TANK	EVENT OCCURS WITH RCS FILLED	1.68E-05 1.20E-05	IEV-LOCA24D IWX-FL-GP
25	1.81E-10	.26	LOSS OF OFFSITE OFFSITE SOFTWARE CCF FAILURE OF	POWER INITIATING AC POWER RECOVERED IN OF ALL CARDS MANUAL DAS	EVENT OCCURS RECOVERED IN 2 HOURS ACTUATION	1.71E-02 7.60E-01 1.20E-06 1.16E-02	IEV-LOSPND SUC-R2S CCX-SPTW REC-MANDAS
26	1.75E-10	.25	LOSS OF OFFSITE FAILURE TO CCF TO START COMMON CAUSE	POWER INITIATING RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS FAILURE OF THE BATTERIES	EVENT OCCURS WITH RCS DRAINED IDSA-DB-1A/1B	4.44E-03 4.20E-01 2.00E-03 4.70E-05	IEV-LOSPD OTR-R1 Z0X-PD-ES CCX-BY-PN
27	1.56E-10	.22	LOSS OF OFFSITE OFFSITE SOFTWARE CCF FAILURE OF	POWER INITIATING AC POWER RECOVERED IN OF ALL CARDS MANUAL DAS	EVENT OCCURS REACTOR TRIP HARDWARE	1.71E-02 7.60E-01 1.20E-06 1.00E-02	IEV-LOSPND SUC-R2S CCX-SPTW MDAS
28	1.36E-10	.19	LOCA/RNS-V024 CCF OF STRAINERS	OPENS INITIATING IN IRWST TANK	EVENT OCCURS WITH RCS DRAINED	1.13E-05 1.20E-05	IEV-LOCA24D IWX-FL-GP
29	1.33E-10	.19	LOSS OF CCS/SWS COND. PROB. OF COMMON MODE OPERATOR FAILS	WITH RCS FILLED REC-MANDAS (FAILURE OF FAILURE OF INPUT LOGIC GROUPS TO RECOGNIZE THE NEED FOR RCS)	INITIATING EVENT OCCURS MANUAL DAS ACT DEPRESSURIZATION	3.75E-03 5.06E-01 1.03E-04 6.83E-04	IEV-CWND REC-MANDASC CCX-INPUT-LOGIC LPM-MAN05

Table 54B-3

CASE 1 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER
30	1.26E-10	.18	OVERDRAINING OF RHN-MAN04-SUCC DUE TO CCF OF	RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT THE SQUIB VALVES TO OPERATE	4.44E-06 9.45E-01 3.00E-05	IEV-RCS0D RHN-MAN04-SUCC ADX-EV-SA
31	1.23E-10	.17	LOSS OF OFFSITE FAILURE TO BATTERY DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR DB1 UNAVAILABLE THE SQUIB VALVES TO OPERATE	4.44E-03 4.20E-01 2.20E-03 3.00E-05	IEV-LOSPD OTH-R1 ED1MOD03 ADX-EV-SA
32	1.17E-10	.17	LOSS OF OFFSITE FAILURE TO FAILURE OF DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR PLS OUTPUT LOGIC I/Os THE SQUIB VALVES TO OPERATE	4.44E-03 4.20E-01 2.09E-03 3.00E-05	IEV-LOSPD OTH-R1 PLSMOD11 ADX-EV-SA
33	1.12E-10	.16	LOSS OF OFFSITE FAILURE TO CCF TO START DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS THE SQUIB VALVES TO OPERATE	4.44E-03 4.20E-01 2.00E-03 3.00E-05	IEV-LOSPD OTH-R1 Z0X-PD-ES ADX-EV-SA
34	1.09E-10	.15	OVERDRAINING OF RHN-MAN04-SUCC CCF OF IRWST INJ MOVs 121A, 121B, & RNS V023	RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT	4.44E-06 9.45E-01 2.60E-05	IEV-RCS0D RHN-MAN04-SUCC IWX-MV-G01
35	1.07E-10	.15	LOSS OF OFFSITE FAILURE TO BATTERY DB1 CCF OF IRWST INJ MOVs 121A, 121B, & RNS V023	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR UNAVAILABLE	4.44E-03 4.20E-01 2.20E-03 2.60E-05	IEV-LOSPD OTH-R1 ED1MOD03 IWX-MV-G01
36	1.05E-10	.15	LOSS OF OFFSITE FAILURE TO COMMON CAUSE COMMON CAUSE	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR 4KV BREAKERS TO OPEN FAILURE OF THE BATTERIES	4.44E-03 4.20E-01 1.20E-03 4.70E-05	IEV-LOSPD OTH-R1 ECX-CB-G0 CCX-BY-PN
37	1.01E-10	.14	LOSS OF OFFSITE FAILURE OF CCF OF IRWST INJ MOVs 121A, 121B, & RNS V023	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR PLS OUTPUT LOGIC I/Os	4.44E-03 4.20E-01 2.09E-03 2.60E-05	IEV-LOSPD OTH-R1 PLSMOD11 IWX-MV-G01
38	9.78E-11	.14	LOSS OF RNS WITH RCS DRAINED SOFTWARE CCF OF ALL CARDS	INITIATING EVENT OCCURS	8.15E-05 1.20E-06	IEV-RNSD CCX-SFTW
39	9.70E-11	.14	LOSS OF OFFSITE FAILURE TO CCF TO START CCF OF IRWST INJ MOVs 121A, 121B, & RNS V023	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS	4.44E-03 4.20E-01 2.00E-03 2.60E-05	IEV-LOSPD OTH-R1 Z0X-PD-ES IWX-MV-G01
40	9.61E-11	.14	LOSS OF RNS WITH RCS FILLED FAILURE OF CCF OF THE POWER INTERFACE OUTPUT BOARDS IN PMS	INITIATING EVENT OCCURS MANUAL DAS ACTUATION	9.61E-04 1.16E-02 8.62E-06	IEV-RNSND REC-MANDAS CCX-EP-SAM
41	9.20E-11	.13	LOSS OF RNS WITH RCS FILLED COND PROB OF REC-MANDAS CCF OF ORIFICES OPERATOR FAILS	INITIATING EVENT OCCURS (FAILURE OF MANUAL DAS ACT.)	9.61E-04 5.06E-01 2.77E-04 6.83E-04	IEV-RNSND REC-MANDASC CCX-DRY-SP LPM-MAN05
42	8.28E-11	.12	LOSS OF RNS WITH RCS FILLED FAILURE OF CCF OF THE POWER INTERFACE OUTPUT BOARDS IN PMS	INITIATING EVENT OCCURS MANUAL DAS REACTOR TRIP HARDWARE	9.61E-04 1.00E-02 8.62E-06	IEV-RNSND MDAS CCX-EP-SAM

Table 54B-3

CASE 1 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS	DEMAND	EVENT PROB	IDENTIFIER
43	6.71E-11	.10	LOSS OF OFFSITE FAILURE TO COMMON CAUSE DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR 4KV BREAKERS TO OPEN THE SQUIB VALVES TO OPERATE	WITH RCS DRAINED	4.44E-03 4.20E-01 1.20E-03 3.00E-05	IEV-LOSPD OTH-R1 CCX-CB-GO ADX-EV-SA
44	6.68E-11	.09	LOSS OF RNS WITH COND. PROB. OF CCF OF PRESSURE OPERATOR FAILS	POWER INITIATING EVENT OCCURS (FAILURE OF REC-MANDAS TRANSMITTERS TO RECOGNIZE THE NEED FOR RCS)	MANUAL DAS ACT.	9.61E-04 5.06E-01 2.01E-04 6.83E-04	IEV-RNSND REC-MANDASC CCX-XNTR195 LPM-MAN05
45	6.49E-11	.09	LOSS OF OFFSITE FAILURE TO PLS LOGIC GROUP DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR PROCESSING FAILURE UPON THE SQUIB VALVES TO OPERATE	DEMAND	4.44E-03 4.20E-01 1.16E-03 3.00E-05	IEV-LOSPD OTH-R1 PLS0301ASA ADX-EV-SA
46	6.49E-11	.09	LOSS OF OFFSITE FAILURE TO PLS LOGIC GROUP DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR PROCESSING FAILURE UPON THE SQUIB VALVES TO OPERATE	DEMAND	4.44E-03 4.20E-01 1.16E-03 3.00E-05	IEV-LOSPD OTH-R1 PLS0301BSA ADX-EV-SA
47	6.40E-11	.09	LOSS OF OFFSITE FAILURE TO COMMON CAUSE COMMON CAUSE	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR 4KV BREAKER TO CLOSE FAILURE OF THE BATTERIES	WITH RCS DRAINED IDSA-DB-1A/1B	4.44E-03 4.20E-01 7.30E-04 4.70E-05	IEV-LOSPD OTH-R1 CCX-CB-GC CCX-BY-PN
48	6.16E-11	.09	LOSS OF CCS/SWS CCF OF ACTUATION MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS LOGIC GROUPS FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN		6.02E-04 4.63E-05 2.21E-03	IEV-CCWD CCX-PMAN05X RN23MOD55
49	6.02E-11	.09	LOSS OF CCS/SWS CCF OF THE POWER	WITH RCS DRAINED FAILURE OF MANUAL DAS INTERFACE OUTPUT BOARDS IN PMS	INITIATING EVENT OCCURS ACTUATION	6.02E-04 1.16E-02 8.62E-06	IEV-CCWD REC-MANDAS CCX-EP-SAM
50	5.95E-11	.08	LOSS OF OFFSITE CCF TO START DUE TO CCF OF	POWER INITIATING EVENT OCCURS AC POWER RECOVERED IN 1 HOUR OF THE PUMPS THE SQUIB VALVES TO OPERATE	WITH RCS DRAINED	4.44E-03 5.80E-01 7.70E-04 3.00E-05	IEV-LOSPD SUC-RIS RNX-PM-FS ADX-EV-SA
51	5.87E-11	.08	LOSS OF RNS WITH MECHANICAL IRWST DISCHARGE	POWER INITIATING EVENT OCCURS FAILURE CAUSES MOV 121A TO FAIL-TO-OPEN LINE "B" STRAINER PLUGGED		8.15E-05 3.00E-03 2.40E-04	IEV-RNSD IRWMOD05J INB-PLUG
52	5.82E-11	.08	LOSS OF OFFSITE COMMON CAUSE CCF OF IRWST INJ	POWER INITIATING EVENT OCCURS FAILURE TO RECOVER AC POWER IN 1 HOUR 4KV BREAKERS TO OPEN MOVs 121A, 121B, & RNS V023	WITH RCS DRAINED	4.44E-03 4.20E-01 1.20E-03 2.60E-05	IEV-LOSPD OTH-R1 CCX-CB-GO INX-MV-G01
53	5.71E-11	.08	LOSS OF OFFSITE SOFTWARE CCF FAILURE OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 2 HOURS OF ALL CARDS MANUAL DAS ACTUATION	WITH RCS FILLED	1.71E-02 2.40E-01 1.20E-06 1.16E-02	IEV-LOSPND OTH-R2 CCX-SPTW REC-MANDAS
54	5.62E-11	.08	LOSS OF OFFSITE FAILURE TO PLS LOGIC GROUP CCF OF IRWST INJ	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR PROCESSING FAILURE UPON MOVs 121A, 121B, & RNS V023	WITH RCS DRAINED DEMAND	4.44E-03 4.20E-01 1.16E-03 2.60E-05	IEV-LOSPD OTH-R1 PLS0301BSA INX-MV-G01

Table 54B-3

CASE 1 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER
55	5.62E-11	.08	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS FAILURE TO RECOVER AC POWER IN 1 HOUR PLS LOGIC GROUP PROCESSING FAILURE UPON DEMAND CCF OF IRWST INJ MOVS 121A, 121B, & RNS V023	WITH RCS DRAINED	4.44E-03 4.20E-01 1.16E-03 2.60E-05	IEV-LOSPD OTH-R1 PLS6301ASA INX-MV-G01
56	5.22E-11	.07	LOSS OF CCS/SWS WITH RCS FILLED INITIATING EVENT OCCURS SOFTWARE CCF OF ALL CARDS FAILURE OF MANUAL DAS ACTUATION		3.75E-03 1.20E-06 1.16E-02	IEV-CCWND CCX-SFTW REC-MANDAS
57	5.19E-11	.07	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS FAILURE OF MANUAL DAS REACTOR TRIP/HARDWARE CCF OF THE POWER INTERFACE OUTPUT BOARDS IN PMS		6.02E-04 1.00E-02 8.62E-06	IEV-CCWD MDAS CCX-EP-SAM
58	5.16E-11	.07	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS OFFSITE AC POWER RECOVERED IN 1 HOUR CCF TO START OF THE PUMPS CCF OF IRWST INJ MOVS 121A, 121B, & RNS V023	WITH RCS DRAINED	4.44E-03 5.80E-01 7.70E-04 2.60E-05	IEV-LOSPD SUC-R1S RNX-PM-FS INX-MV-G01
59	5.03E-11	.07	OVERDRAINING OF RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT RHN-MAN04-SUCC CCF OF STRAINERS IN IRWST TANK		4.44E-06 9.45E-01 1.20E-02	IEV-RCSOD RHN-MAN04-SUCC INX-FL-GP
60	4.93E-11	.07	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS FAILURE TO RECOVER AC POWER IN 1 HOUR BATTERY DB1 UNAVAILABLE CCF OF STRAINERS IN IRWST TANK	WITH RCS DRAINED	4.44E-03 4.20E-01 2.20E-03 1.20E-05	IEV-LOSPD OTH-R1 ED1MOD03 INX-FL-GP
61	4.92E-11	.07	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS FAILURE TO RECOVER AC POWER IN 2 HOURS SOFTWARE CCF OF ALL CARDS FAILURE OF MANUAL DAS REACTOR TRIP/HARDWARE	WITH RCS FILLED	1.71E-02 2.40E-01 1.20E-06 1.00E-02	IEV-LOSPND OTH-R2 CCX-SFTW MDAS
62	4.71E-11	.07	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS OFFSITE AC POWER RECOVERED IN 1 HOUR CCF TO OPEN OF THE STOP CHECK VALVES DUE TO CCF OF THE SQUIB VALVES TO OPERATE	WITH RCS DRAINED	4.44E-03 5.80E-01 6.10E-04 3.00E-05	IEV-LOSPD SUC-R1S RNX-KV-G0 ADX-EV-SA
63	4.68E-11	.07	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS FAILURE TO RECOVER AC POWER IN 1 HOUR FAILURE OF PLS OUTPUT LOGIC I/Os CCF OF STRAINERS IN IRWST TANK	WITH RCS DRAINED	4.44E-03 4.20E-01 2.09E-03 1.20E-05	IEV-LOSPD OTH-R1 PLSMOD11 INX-FL-GP
64	4.50E-11	.06	LOSS OF CCS/SWS WITH RCS FILLED INITIATING EVENT OCCURS SOFTWARE CCF OF ALL CARDS FAILURE OF MANUAL DAS REACTOR TRIP/HARDWARE		3.75E-03 1.20E-06 1.00E-02	IEV-CCWND CCX-SFTW MDAS
65	4.48E-11	.06	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS FAILURE TO RECOVER AC POWER IN 1 HOUR CCF TO START OF ENGINE-DRIVEN FUEL PUMPS CCF OF STRAINERS IN IRWST TANK	WITH RCS DRAINED	4.44E-03 4.20E-01 2.00E-03 1.20E-05	IEV-LOSPD OTH-R1 Z0X-PD-ES INX-FL-GP
66	4.46E-11	.06	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS CCF OF ACTUATION LOGIC GROUPS OPERATOR FAILS TO RECOGNIZE NEED AND TO OPEN RNS MOV V023		6.02E-04 4.63E-05 1.60E-03	IEV-CCWD CCX-PMAMOD1X RHN-MAN05
67	4.33E-11	.06	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS IRWST DISCHARGE LINE "B" STRAINER PLUGGED BUS UNAVAILABLE DUE TO TEST OR CORRECTIVE MAINTENANCE		6.02E-04 2.40E-04 3.00E-04	IEV-CCWD IWB-PLUG IDBBSD01TM

Table 54B-3

CASE 1 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB.	PERCENT	BASIC EVENT NAME		EVENT PROB.	IDENTIFIER	
68	4.33E-11	.06	LOSS OF CCS/SWS IRWST DISCHARGE BUS UNAVAILABLE	WITH RCS DRAINED LINE "B" DUE TO TEST OR	INITIATING EVENT OCCURS STRAINER PLUGGED CORRECTIVE MAINTENANCE	6.02E-04 2.40E-04 3.00E-04	IEV-CCWD IWB-PLUG IDBBSDKITM
69	4.33E-11	.06	LOSS OF CCS/SWS IRWST DISCHARGE BUS UNAVAILABLE	WITH RCS DRAINED LINE "B" DUE TO TEST OR	INITIATING EVENT OCCURS STRAINER PLUGGED CORRECTIVE MAINTENANCE	6.02E-04 2.40E-04 3.00E-04	IEV-CCWD IWB-PLUG IDBBSDSITM
70	4.31E-11	.06	LOSS OF OFFSITE FAILURE TO CCF TO START DUE TO CCF OF	POWER INITIATING RECOVER AC POWER IN 1 HOUR OF THE PUMPS THE SQUIB VALVES TO OPERATE	EVENT OCCURS WITH RCS DRAINED	4.44E-03 4.20E-01 7.70E-04 3.00E-05	IEV-LOSPD OTH-R1 RNX-PM-FS ADX-EV-SA
71	4.10E-11	.06	LOCA/RNS-V024 CCF OF ORIFICES	OPENS	INITIATING EVENT OCCURS WITH RCS DRAINED	1.13E-05 3.63E-06	IEV-LOCA24D CCX-ORY-SPK
72	4.08E-11	.06	LOSS OF OFFSITE OFFSITE CCF TO OPEN CCF OF IRWST INJ	POWER INITIATING AC POWER RECOVERED IN OF THE STOP MOVs 121A, 121B, & RNS V023	EVENT OCCURS WITH RCS DRAINED 1 HOUR CHECK VALVES	4.44E-03 5.80E-01 6.10E-04 2.60E-05	IEV-LOSPD SUC-R1S RNX-KV-GO IWX-MV-GO1
73	4.08E-11	.06	LOSS OF OFFSITE FAILURE TO COMMON CAUSE DUE TO CCF OF	POWER INITIATING RECOVER AC POWER IN 1 HOUR 4KV BREAKER TO THE SQUIB VALVES TO OPERATE	EVENT OCCURS WITH RCS DRAINED CLOSE	4.44E-03 4.20E-01 7.30E-04 3.00E-05	IEV-LOSPD OTH-R1 ECX-CB-GC ADX-EV-SA
74	3.99E-11	.06	LOSS OF CCS/SWS CCF OF GRAVITY MECHANICAL	WITH RCS DRAINED INJECTION CHECK FAILURE CAUSES	INITIATING EVENT OCCURS VALVES TO OPEN MOV 023 TO FAIL-TO-OPEN	6.02E-04 3.00E-05 2.21E-03	IEV-CCWD IWX-CV-A0 RN23MODSS
75	3.86E-11	.05	LOSS OF OFFSITE FAILURE TO COMMON CAUSE COMMON CAUSE	POWER INITIATING RECOVER AC POWER IN 1 HOUR FAILURE STANDBY DG TO FAILURE OF THE	EVENT OCCURS WITH RCS DRAINED RUN IDSA-DB-1A/1B	4.44E-03 4.20E-01 4.40E-04 4.70E-05	IEV-LOSPD OTH-R1 ZOX-DG-DR CCX-BY-PN
76	3. . . 11	.05	LOSS OF OFFSITE FAILURE TO CCF TO START CCF OF IRWST INJ	POWER INITIATING RECOVER AC POWER IN 1 HOUR OF THE PUMPS MOVs 121A, 121B, & RNS V023	EVENT OCCURS WITH RCS DRAINED	4.44E-03 4.20E-01 7.70E-04 2.60E-05	IEV-LOSPD OTH-R1 RNX-PM-FS IWX-MV-GO1
77	3.58E-11	.05	LOSS OF OFFSITE FAILURE TO D/G FAILS TO D/G FAILS TO COMMON CAUSE	POWER INITIATING RECOVER AC POWER IN 1 HOUR START & RUN OR BKR 102 FAILS TO CLOSE START & RUN OR BKR 202 FAILS TO CLOSE FAILURE OF THE	EVENT OCCURS WITH RCS DRAINED 4KV BREAKER TO IDSA-DB-1A/1B	4.44E-03 4.20E-01 2.02E-02 2.02E-02 4.70E-05	IEV-LOSPD OTH-R1 Z01MOD01 Z02MOD01 CCX-BY-PN
78	3.54E-11	.05	LOSS OF OFFSITE FAILURE TO BATTERY CCF OF THE POWER	POWER INITIATING RECOVER AC POWER IN 1 HOUR UNAVAILABLE INTERFACE OUTPUT BOARDS IN PMS	EVENT OCCURS WITH RCS DRAINED	4.44E-03 4.20E-01 2.20E-03 8.62E-06	IEV-LOSPD OTH-R1 ED1MOD03 CCX-EP-SAM
79	3.54E-11	.05	LOSS OF OFFSITE FAILURE TO COMMON CAUSE CCF OF IRWST INJ	POWER INITIATING RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKER TO MOVs 121A, 121B, & RNS V023	EVENT OCCURS WITH RCS DRAINED CLOSE	4.44E-03 4.20E-01 7.30E-04 2.60E-05	IEV-LOSPD OTH-R1 ECX-CB-GC IWX-MV-GO1

Table 54B-3

CASE 1 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER
80	3.47E-11	.05	LOSS OF CCS/SWS IRWST DISCHARGE IRWST DISCHARGE	WITH RCS DRAINED INITIATING EVENT OCCURS LINE "A" STRAINER PLUGGED LINE "B" STRAINER PLUGGED	6.02E-04 2.40E-04 2.40E-04	IEV-CWMD IWA-PLUG IWB-PLUG
81	3.42E-11	.05	LOSS OF RNS WITH RCS FILLED COND. PROB. OF REC-MANDAS COMMON MODE OPERATOR FAILS	INITIATING EVENT OCCURS (FAILURE OF LOGIC GROUPS FAILURE OF INPUT TO RECOGNIZE THE NEED FOR RCS	9.61E-04 5.06E-01 1.03E-04 6.83E-04	IEV-RNSND REC-MANDASC CCX-INPUT-LOGIC LPM-MAN05
82	3.41E-11	.05	LOSS OF OFFSITE FAILURE TO CCF TO OPEN DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF THE STOP CHECK VALVES THE SQUIB VALVES TO OPERATE	4.44E-03 4.20E-01 6.10E-04 3.00E-05	IEV-LOSPD OTH-R1 RNX-KV-GO ADX-EV-SA
83	3.36E-11	.05	LOSS OF OFFSITE FAILURE TO PLS OUTPUT CCP OF THE POWER	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR LOGIC I/Os INTERFACE OUTPUT BOARDS IN PIS	4.44E-03 4.20E-01 2.09E-03 8.62E-06	IEV-LOSPD OTH-R1 PLSMOD11 CCX-EP-SAM
84	3.21E-11	.05	LOSS OF OFFSITE FAILURE TO CCF TO START CCF OF THE POWER	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS INTERFACE OUTPUT BOARDS IN PMS	4.44E-03 4.20E-01 2.00E-03 8.62E-06	IEV-LOSPD OTH-R1 Z0X-PD-ES CCX-EP-SAM
85	2.97E-11	.04	LOCA/RNS-V024 CCF OF PRESSURE	OPENS INITIATING EVENT OCCURS TRANSMITTERS	1.13E-05 2.63E-06	IEV-LOCA24D CCX-XMTRX
86	2.96E-11	.04	LOSS OF OFFSITE FAILURE TO CCF TO OPEN CCF OF IRWST INJ	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF THE STOP CHECK VALVES MOVES 121A, 121B, & RNS V023	4.44E-03 4.20E-01 6.10E-04 2.60E-05	IEV-LOSPD OTH-R1 RNX-KV-GO INX-MV-G01
87	2.89E-11	.04	LOSS OF CCS/SWS CCF OF GRAVITY OPERATOR FAILS	WITH RCS DRAINED INITIATING EVENT OCCURS INJECTION CHECK VALVES TO OPEN TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	6.02E-04 3.00E-05 1.60E-03	IEV-CWMD IWX-CV-A0 RHN-MAN05
88	2.82E-11	.04	LOSS OF OFFSITE FAILURE TO FIXED COMPONENT DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURES THE SQUIB VALVES TO OPERATE	4.44E-03 4.20E-01 5.04E-04 3.00E-05	IEV-LOSPD OTH-R1 EDIMOD01 ADX-EV-SA
89	2.76E-11	.04	LOSS OF OFFSITE FAILURE TO PUMP MP 01B D/G FAILS TO	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR START & RUN OR BKR 102 FAILS TO CLOSE	4.44E-03 4.20E-01 2.44E-02 2.02E-02 3.00E-05	IEV-LOSPD OTH-R1 SWBMOD02 Z0IMOD01 ADX-EV-SA
90	2.70E-11	.04	OVERDRAINING OF IWN-MAN00C MECHANICAL	RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT TO ISOLATE RNS PIPE RUPTURE FAILURE CAUSES MOV 023 TG FAIL-TO-OPEN	4.44E-06 5.50E-02 5.00E-02 2.21E-03	IEV-RCS0D RHN-MAN04 IWN-MAN00C RN23MOD55
92	2.69E-11	.04	LOSS OF OFFSITE FAILURE TO COMMON CAUSE CCF OF STRAINERS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKERS TO OPEN IN IRWST TANK	4.44E-03 4.20E-01 1.20E-03 1.20E-05	IEV-LOSPD OTH-R1 CCX-CB-GO INX-FL-GP

Table 54B-3

CASE I LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER
93	2.60E-11	.04	LOSS OF OFFSITE FAILURE TO PLS LOGIC GROUP CCF OF STRAINERS IN IRWST TANK	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR PROCESSING FAILURE UPON DEMAND	4.44E-03 4.20E-07 1.16E-03 1.20E-05	IEV-LOSPD OTH-R1 PL50301BSA IWX-FL-GP
94	2.60E-11	.04	LOSS OF OFFSITE FAILURE TO PLS LOGIC GROUP CCF OF STRAINERS IN IRWST TANK	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR PROCESSING FAILURE UPON DEMAND	4.44E-03 4.20E-01 1.16E-03 1.20E-05	IEV-LOSPD OTH-R1 PL50301ASA IWX-FL-GP
95	2.49E-11	.04	LOCA/RNS PIPE OPERATOR FAILS CCF OF GRAVITY	RUPTURE WITH RCS FILLED INIT. TO ISOLATE RNS PIPE RUPTURE INJECTION CHECK VALVES TO OPEN	1.51E-05 5.50E-02 3.00E-05	IEV-LOCAPRND RHN-MAN04 IWX-CV-AO
96	2.46E-11	.03	LOSS OF OFFSITE FAILURE TO COMMON CAUSE DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR STANDBY DG TO THE SQUIB VALVES TO OPERATE	4.44E-03 4.20E-01 4.40E-04 3.00E-05	IEV-LOSPD OTH-R1 ZOK-DG-DR ADK-EV-SA
97	2.45E-11	.03	LOSS OF OFFSITE FAILURE TO COMMON CAUSE COMMON CAUSE	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR STANDBY DG TO FAILURE OF THE BATTERIES	4.44E-03 4.20E-01 2.80E-04 4.70E-05	IEV-LOSPD OTH-R1 ZOK-DG-DS CCK-BY-PN
98	2.44E-11	.03	LOSS OF OFFSITE FAILURE TO FIXED COMPONENT CCF OF IRWST INJ	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURES MOVS 121A, 121B, & RNS V023	4.44E-03 4.20E-01 5.04E-04 2.60E-05	IEV-LOSPD OTH-R1 EDIMOD01 IWX-MV-G01
99	2.39E-11	.03	LOSS OF OFFSITE FAILURE TO PUMP MP 01B D/G FAILS TO CCF OF IRWST INJ	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR START & RUN OR BKR 102 FAILS TO CLOSE MOVS 121A, 121B, & RNS V023	4.44E-03 4.20E-01 2.44E-02 2.02E-02 2.60E-05	IEV-LOSPD OTH-R1 SWBMOD02 Z01MOD01 IWX-MV-G01
100	2.38E-11	.03	LOSS OF OFFSITE CCF TO START CCF OF STRAINERS IN IRWST TANK	POWER INITIATING EVENT OCCURS AC POWER RECOVERED IN 1 HOUR OF THE PUMPS	4.44E-03 5.80E-01 7.70E-04 1.20E-05	IEV-LOSPD SUC-RIS RNX-PF-FS IWA-FL-GP
101	2.28E-11	.03	LOSS OF OFFSITE FAILURE TO D/G FAILS TO D/G FAILS TO DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR START & RUN OR BKR 102 FAILS TO CLOSE START & RUN OR BKR 202 FAILS TO CLOSE THE SQUIB VALVES TO OPERATE	4.44E-03 4.20E-01 2.02E-02 2.02E-02 3.00E-05	IEV-LOSPD OTH-R1 Z01MOD01 Z02MOD01 ADK-EV-SA
102	2.18E-11	.03	LOSS OF OFFSITE FAILURE TO BREAKER 100 D/G FAILS TO COMMON CAUSE	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILS TO OPEN (#3.5) START & RUN OR BKR 202 FAILS TO CLOSE FAILURE OF THE BATTERIES	4.44E-03 4.20E-01 1.23E-02 2.02E-02 4.70E-05	IEV-LOSPD OTH-R1 EC1CB100V0 Z02MOD01 CCK-BY-PN
103	2.18E-11	.03	LOSS OF OFFSITE FAILURE TO D/G FAILS TO BREAKER 200 COMMON CAUSE	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILS TO OPEN (#5.3) START & RUN OR BKR 102 FAILS TO CLOSE FAILURE OF THE BATTERIES	4.44E-03 4.20E-01 2.02E-02 1.23E-02 4.70E-05	IEV-LOSPD OTH-R1 Z01MOD01 EC2CB2COV0 CCK-BY-PN

Table 54B-3

CASE 1 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER	
104	2.13E-11	.03	LOSS OF OFFSITE FAILURE TO COMMON CAUSE CCF OF IRWST INJ	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE STANDBY DG TO MOVs 121A, 121B, & RNS V023	WITH RCS DRAINED RUN	4.44E-03 4.20E-01 4.40E-04 2.60E-05	IEV-LOSPD OTH-R1 Z0X-DG-DR IWX-MV-G01
105	1.98E-11	.03	LOSS OF OFFSITE FAILURE TO D/G FAILS TO D/G FAILS TO CCF OF IRWST INJ	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR START & RUN OR BKR 102 FAILS TO CLOSE START & RUN OR BKR 202 FAILS TO CLOSE MOVs 121A, 121B, & RNS V023	WITH RCS DRAINED	4.44E-03 4.20E-01 2.02E-02 2.02E-02 2.60E-05	IEV-LOSPD OTH-R1 Z01MOD01 Z02MOD01 IWX-MV-G01
106	1.93E-11	.03	LOSS OF OFFSITE FAILURE TO COMMON CAUSE CCF OF THE POWER	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKERS TO INTERFACE OUTPUT BOARDS IN PMS	WITH RCS DRAINED OPEN	4.44E-03 4.20E-01 1.20E-03 8.62E-06	IEV-LOSPD OTH-R1 CCX-CB-G0 CCX-EP-SAM
107	1.90E-11	.03	LOSS OF OFFSITE FAILURE TO BATTERY FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR DB1 UNAVAILABLE PMS OUTPUT LOGIC I/Os FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED FAIL-TO-OPEN	4.44E-03 4.20E-01 2.20E-03 2.09E-03 2.21E-03	IEV-LOSPD OTH-R1 ED1MOD03 PMAMOD11 RN23MOD55
108	1.89E-11	.03	LOSS OF OFFSITE OFFSITE CCP TO OPEN CCF OF STRAINERS	POWER INITIATING EVENT OCCURS AC POWER RECOVERED IN OF THE STOP CHECK VALVES IN IRWST TANK	WITH RCS DRAINED	4.44E-03 5.80E-01 6.10E-04 1.20E-05	IEV-LOSPD SUC-R1S RNX-XV-G0 IWX-FL-GP
109	1.86E-11	.03	LOSS OF OFFSITE FAILURE TO PLS LOGIC GROUP CCF OF THE POWER	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR PROCESSING FAILURE UPON INTERFACE OUTPUT BOARDS IN PMS	WITH RCS DRAINED DEMAND	4.44E-03 4.20E-01 1.16E-03 8.62E-06	IEV-LOSPD OTH-R1 PL50301ASA CCX-EP-SAM
110	1.86E-11	.03	LOSS OF OFFSITE FAILURE TO PLS LOGIC GROUP CCF OF THE POWER	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR PROCESSING FAILURE UPON INTERFACE OUTPUT BOARDS IN PMS	WITH RCS DRAINED DEMAND	4.44E-03 4.20E-01 1.16E-03 8.62E-06	IEV-LOSPD OTH-R1 PL50301BSA CCX-EP-SAM
111	1.84E-11	.03	LOSS OF CCS/SWS CCF OF LOGIC MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS GROUP PROCESSING FAILURE CAUSES MOV 023 TO	FAIL-TO-OPEN	6.02E-04 1.38E-05 2.21E-03	IEV-CCWD CCX-PMA030X RN23MOD55
112	1.81E-11	.03	LOSS OF OFFSITE FAILURE TO PUMP GIA FAILS; PUMP 01B FAILS & DUE TO CCF OF	POWER INITIATING EVENT OCCURS AC POWER RECOVERED IN STOP CK V007A, CB & RELAY FTC; CB ECS122 SPO PUMP 01B FAILS & ST CK V007B & C B FTC & RE FTC & CB ECS221 SPO DUE TO CCF OF THE SQUIB VALVES TO OPERATE	WITH RCS DRAINED	4.44E-03 5.80E-01 1.53E-02 1.53E-02 3.00E-05	IEV-LOSPD SUC-R1S RNAMOD06S RNBMOD07S ADX-EV-SA
113	1.77E-11	.03	LOSS OF OFFSITE FAILURE TO FIXED DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR COMPONENTS FAILURE DUE TO CCF OF THE SQUIB VALVES TO OPERATE	WITH RCS DRAINED	4.44E-03 4.20E-01 3.17E-04 3.00E-05	IEV-LOSPD OTH-R1 ED1MOD11 ADX-EV-SA
114	1.77E-11	.03	LOSS OF OFFSITE FAILURE TO FIXED DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR COMPONENTS FAILURE DUE TO CCF OF THE SQUIB VALVES TO OPERATE	WITH RCS DRAINED	4.44E-03 4.20E-01 3.17E-04 3.00E-05	IEV-LOSPD OTH-R1 ED1MOD13 ADX-EV-SA

Table 54B-3

CASE 1 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER	
115	1.77E-11	.03	LOSS OF OFFSITE FAILURE TO FIXED COMPONENTS DUE TO CCF OF THE SQUIB VALVES TO OPERATE	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE	WITH RCS DRAINED	4.44E-03 4.20E-01 3.17E-04 3.00E-05	IEV-LOSPD OTH-R1 ED1MOD113 ADX-EV-SA
116	1.73E-11	.02	LOSS OF OFFSITE FAILURE TO PUMP 01B FAILS & D/G FAILS TO DUE TO CCF OF THE SQUIB VALVES TO OPERATE	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR ST CK V007B & C B FTC & RE FTC & CB ECS221 SPO START & RUN OP BKR 102 FAILS TO CLOSE	WITH RCS DRAINED	4.44E-03 4.20E-01 1.53E-02 2.02E-02 3.00E-05	IEV-LOSPD OTH-R1 RNBMOD07S Z01MOD01 ADX-EV-SA
117	1.73E-11	.02	LOSS OF OFFSITE FAILURE TO PUMP 01A FAILS; D/G FAILS TO DUE TO CCF OF THE SQUIB VALVES TO OPERATE	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR STOP CK V007A, CB & RELAY FTC; CB ECS122 SPO START & RUN OP BKR 202 FAILS TO CLOSE	WITH RCS DRAINED	4.44E-03 4.20E-01 1.53E-02 2.02E-02 3.00E-05	IEV-LOSPD OTH-R1 RNAMOD06S Z02MOD01 ADX-EV-SA
118	1.72E-11	.02	LOSS OF OFFSITE FAILURE TO CCF TO START CCF OF STRAINERS IN IRWST TANK	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF THE PUMPS	WITH RCS DRAINED	4.44E-03 4.20E-01 7.70E-04 1.20E-05	IEV-LOSPD OTH-R1 RNX-PM-FS IWX-FL-GP
119	1.72E-11	.02	LOSS OF OFFSITE FAILURE TO CCF TO START FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS PMS OUTPUT LOGIC I/Os FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED	4.44E-03 4.20E-01 2.00E-03 2.09E-03 2.21E-03	IEV-LOSPD OTH-R1 Z0X-PD-ES PMAMOD11 RN23MOD5S
120	1.71E-11	.02	LOSS OF OFFSITE FAILURE TO EDS1 EA 1 DISTR. DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR PNL FAILURE OR T&M THE SQUIB VALVES TO OPERATE	WITH RCS DRAINED	4.44E-03 4.20E-01 3.05E-04 3.07E-05	IEV-LOSPD OTH-R1 ED1MOD07 ADX-EV-SA
121	1.68E-11	.02	LOSS OF OFFSITE FAILURE TO PUMP MP 01B BREAKER 100 DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR FAILS TO OPEN THE SQUIB VALVES TO OPERATE	WITH RCS DRAINED DIVERTED FLOW [#3,5]	4.44E-03 4.20E-01 2.44E-02 1.23E-02 3.00E-05	IEV-LOSPD OTH-R1 SWBMOD02 EC1CB100VO ADX-EV-SA
122	1.63E-11	.02	LOSS OF OFFSITE FAILURE TO COMMON CAUSE DUE TO CCF OF STRAINERS IN IRWST TANK	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKER TO CLOSE	WITH RCS DRAINED	4.44E-03 4.20E-01 7.30E-04 1.20E-05	IEV-LOSPD OTH-R1 ECX-CB-GC IWX-FL-GP
123	1.57E-11	.02	LOSS OF OFFSITE FAILURE TO PUMP 01A FAILS; PUMP 01B FAILS & CCF OF IPWST INJ	POWER INITIATING EVENT OCCURS AC POWER RECOVERED IN 1 HOUR ST CK V007A, CB & RELAY FTC; CB ECS122 SPO ST CK V007B & C B FTC & RE FTC & CB ECS221 SPO MOVs 121A, 121B, & RNS V023	WITH RCS DRAINED	4.44E-03 5.80E-01 1.53E-02 1.53E-02 2.60E-05	IEV-LOSPD SUC-R1S RNAMOD06S RNBMOD07S IWX-MV-GC1
124	1.57E-11	.02	LOSS OF OFFSITE FAILURE TO COMMON CUSE DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE STANDEY DG TO START THE SQUIB VALVES TO OPERATE	WITH RCS DRAINED	4.44E-03 4.20E-01 2.80E-04 3.00E-05	IEV-LOSPD OTH-R1 Z0X-DG-DS ADX-EV-SA

Table 54B-3

CASE 1 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS	WITH RCS DRAINED	EVENT PROB	IDENTIFIER
125	1.55E-11	.02	LOSS OF CCS/SWS COND. PROB. OF COMMON MODE OPERATOR FAILS	WITH RCS DRAINED (FAILURE OF REC-MANDAS FAILURE OF INPUT LOGIC GROUPS TO ACTUATE ADS BEFORE CORE	INITIATING EVENT OCCURS MANUAL DAS ACT. DAMAGE	6.02E-04 5.06E-01 1.03E-04 4.93E-04	IEV-CWMD REC-MANDASC CCX-INPUT-LOGIC ADN-MAN01
126	1.54E-11	.02	LOSS OF OFFSITE FAILURE TO RECOVER AC POWER IN 1 HOUR FIXED COMPONENTS CCF OF IRWST INJ	POWER INITIATING FAILURE TO RECOVER AC POWER IN 1 HOUR FAILURE MOVES 121A, 121B, & RNS V023	INITIATING EVENT OCCURS WITH RCS DRAINED	4.44E-03 4.20E-01 3.17E-04 2.60E-05	IEV-LOSPD OTH-R1 ED1MOD13 IWX-MV-G01
127	1.54E-11	.02	LOSS OF OFFSITE FAILURE TO RECOVER AC POWER IN 1 HOUR FIXED COMPONENTS CCF OF IRWST INJ	POWER INITIATING FAILURE TO RECOVER AC POWER IN 1 HOUR FAILURE MOVES 121A, 121B, & RNS V023	INITIATING EVENT OCCURS WITH RCS DRAINED	4.44E-03 4.20E-01 3.17E-04 2.60E-05	IEV-LOSPD OTH-R1 ED1MOD113 IWX-MV-G01
128	1.54E-11	.02	LOSS OF OFFSITE FAILURE TO RECOVER AC POWER IN 1 HOUR FIXED COMPONENTS CCF OF IRWST INJ	POWER INITIATING FAILURE TO RECOVER AC POWER IN 1 HOUR FAILURE MOVES 121A, 121B, & RNS V023	INITIATING EVENT OCCURS WITH RCS DRAINED	4.44E-03 4.20E-01 3.17E-04 2.60E-05	IEV-LOSPD OTH-R1 ED1MOD11 IWX-MV-G01
129	1.52E-11	.02	OVERDRAINING OF RHN-MAN04-SUCC CCF OF ORIFICES	RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT	INITIATING EVENT OCCURS	4.44E-06 9.45E-01 3.63E-06	IEV-RCSOD RHN-MAN04-SUCC CCX-ORY-SPX
130	1.50E-11	.02	LOSS OF OFFSITE FAILURE TO PUMP 01A FAILS; STOP CK V007A, CB & RELAY PTC; D/G FAILS TO START & RUN OR CCF OF IRWST INJ	POWER INITIATING FAILURE TO RECOVER AC POWER IN 1 HOUR PUMP 01A FAILS; STOP CK V007A, CB & RELAY PTC; D/G FAILS TO START & RUN OR MOVES 121A, 121B, & RNS V023	INITIATING EVENT OCCURS WITH RCS DRAINED	4.44E-03 4.20E-01 1.53E-02 2.02E-02 2.60E-05	IEV-LOSPD OTH-R1 RNAMOD06S Z02MOD01 IWX-MV-G01
131	1.50E-11	.02	LOSS OF OFFSITE FAILURE TO PUMP 01B FAILS & ST CK V007B & C B PTC & RE PTC & CB ECS221 SPO D/G FAILS TO START & RUN OR CCF OF IRWST INJ	POWER INITIATING FAILURE TO RECOVER AC POWER IN 1 HOUR PUMP 01B FAILS & ST CK V007B & C B PTC & RE PTC & CB ECS221 SPO D/G FAILS TO START & RUN OR MOVES 121A, 121B, & RNS V023	INITIATING EVENT OCCURS WITH RCS DRAINED	4.44E-03 4.20E-01 1.53E-02 2.02E-02 2.60E-05	IEV-LOSPD OTH-R1 RNBMOD07S Z01MOD01 IWX-MV-G01
132	1.49E-11	.02	LOSS OF OFFSITE FAILURE TO BATTERY CCF OF ORIFICES	POWER INITIATING FAILURE TO RECOVER AC POWER IN 1 HOUR DB1 UNAVAILABLE	INITIATING EVENT OCCURS WITH RCS DRAINED	4.44E-03 4.20E-01 2.20E-03 3.63E-06	IEV-LOSPD OTH-R1 ED1MOD03 CCX-ORY-SPX
133	1.48E-11	.02	LOSS OF OFFSITE FAILURE TO EDS1 EA 1 DISTR PML FAILURE OR T&M CCF OF IRWST INJ	POWER INITIATING FAILURE TO RECOVER AC POWER IN 1 HOUR EDS1 EA 1 DISTR PML FAILURE OR T&M MOVES 121A, 121B, & RNS V023	INITIATING EVENT OCCURS WITH RCS DRAINED	4.44E-03 4.20E-01 3.05E-04 2.60E-05	IEV-LOSPD OTH-R1 ED1MOD07 IWX-MV-G01
134	1.46E-11	.02	LOSS OF CCS/SWS SOFTWARE CCF OF MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS OUTPUT LOGIC I/Os FAILURE CAUSES MOV 023 TO	INITIATING EVENT OCCURS FAIL-TO-OPEN	4.07E-04 1.11E-05 2.21E-03	IEV-CWMD CCX-PMAMOD1-SW RN23MOD5S
135	1.46E-11	.02	LOSS OF OFFSITE FAILURE TO PUMP MP 01B BREAKER 100 CCF OF IRWST INJ	POWER INITIATING FAILURE TO RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR FAILS TO OPEN MOVES 121A, 121B, & RNS V023	INITIATING EVENT OCCURS WITH RCS DRAINED DIVERTED PLOW	4.44E-03 4.20E-01 2.44E-02 1.23E-02 2.60E-05	IEV-LOSPD OTH-R1 SWBMOD02 EC1CB100V0 IWX-MV-G01

Table 54B-3

CASE 1 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME			EVENT PROB	IDENTIFIER
136	1.42E-11	.02	LOSS OF CCS/SWS COND. PROB. OF ORIFICE FAILURE OPERATOR FAILS	WITH RCS DRAINED REC-MANDAS DUE TO PLUGGING TO ACTUATE ADS	INITIATING EVENT OCCURS (FAILURE OF MANUAL DAS ACT. BEFORE CORE)	6.02E-04 5.06E-01 9.46E-05 4.93E-04	IEV-CCWD REC-MANDASC IW10R170SPX ADN-MAN01
137	1.42E-11	.02	LOSS OF CCS/SWS COND. PROB. OF ORIFICE FAILURE OPERATOR FAILS	WITH RCS DRAINED REC-MANDAS DUE TO PLUGGING TO ACTUATE ADS	INITIATING EVENT OCCURS (FAILURE OF MANUAL DAS ACT. BEFORE CORE)	6.02E-04 5.06E-01 9.46E-05 1.93E-04	IEV-CCWD REC-MANDASC IW20R160SPX ADN-MAN01
138	1.41E-11	.02	LOSS OF OFFSITE FAILURE TO FAILURE OF CCF OF ORIFICES	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR PLS OUTPUT	WITH RCS DRAINED LOGIC I/Os	4.44E-03 4.20E-01 2.09E-03 3.63E-06	IEV-LOSPD OTH-R1 PL5MOD11 CCX-ORY-SPX
139	1.39E-11	.02	LOSS OF OFFSITE FAILURE TO BREAKER 105 D/G FAILS TO DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILS TO OPEN START & RUN OR THE SQUIB VALVES TO OPERATE	WITH RCS DRAINED [#3.5]	4.44E-03 4.20E-01 1.23E-02 2.02E-02 3.00E-05	IEV-LOSPD OTH-R1 EC1CB100VO Z02MOD01 ADN-EV-SA
140	1.39E-11	.02	LOSS OF OFFSITE FAILURE TO D/G FAILS TO BREAKER 200 DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR START & RUN OR FAILS TO OPEN THE SQUIB VALVES TO OPERATE	WITH RCS DRAINED [#5.3]	4.44E-03 4.20E-01 2.02E-02 1.23E-02 3.00E-05	IEV-LOSPD OTH-R1 Z01MOD01 EC2CB209VO ADN-EV-SA
141	1.37E-11	.02	LOSS OF OFFSITE FAILURE TO BATTERY FAILURE OF OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR DBI UNAVAILABLE PMS OUTPUT TO RECOGNIZE	WITH RCS DRAINED LOGIC I/Os NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 2.20E-03 2.09E-03 1.60E-03	IEV-LOSPD OTH-R1 ED1MOD03 PMAMOD11 RHN-MAN05
142	1.37E-11	.02	LOSS OF OFFSITE FAILURE TO CCF TO OPEN CCF OF STRAINERS IN IRWST TANK	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF THE STOP CHECK VALVES	WITH RCS DRAINED	4.44E-03 4.20E-01 6.10E-04 1.20E-05	IEV-LOSPD OTH-R1 RNX-KV-GO IWX-FL-GP
143	1.36E-11	.02	LOSS OF OFFSITE FAILURE TO COMMON CAUSE CCF OF IRWST INJ	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE STANDBY DG TO MOVs 121A, 121B, & RNS V023	WITH RCS DRAINED START	4.44E-03 4.20E-01 2.80E-04 2.60E-05	IEV-LOSPD OTH-R1 Z0X-DG-DS IWX-MV-GO1
144	1.36E-11	.02	LOCA/RNS-V024 SOFTWARE CCF	OPENS INITIATING EVENT OCCURS OF ALL CARDS	WITH RCS DRAINED	1.13E-05 1.20E-06	IEV-LOCA24D CCX-SFTW
145	1.35E-11	.02	LOSS OF OFFSITE FAILURE TO CCF TO START CCF OF ORIFICES	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS	WITH RCS DRAINED	4.44E-03 4.20E-01 2.00E-03 3.63E-06	IEV-LOSPD OTH-R1 Z0X-PD-ES CCX-ORY-SPX
146	1.34E-11	.02	LOSS OF RNS WITH SOFTWARE CCF FAILURE OF	WITH RCS FILLED OF ALL CARDS MANUAL DAS	INITIATING EVENT OCCURS ACTUATION	9.61E-04 1.20E-06 1.16E-02	IEV-RNSND CCX-SFTW REC-MANDAS
147	1.33E-11	.02	LOSS OF CCS/SWS CCF OF LOGIC OPERATOR FAILS	WITH RCS DRAINED GROUP PROCESSING TO RECOGNIZE	INITIATING EVENT OCCURS NEED AND TO OPEN RNS MOV V023	6.02E-04 1.38E-05 1.60E-03	IEV-CCWD CCX-PMA030X RHN-MAN05

Table 54B-3

CASE 1 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT_PJS	ISE	FIRE
148	1.33E-11	.02	LOSS OF OFFSITE FAILURE TO BREAKER 100 BREAKER 200 COMMON CAUSE	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILS TO OPEN FAILS TO OPEN FAILURE OF THE BATTERIES	WITH RCS DRAINED (#3.5) (#5.31) IDSA-DB-1A/1B	4.44E-03 4.20E-01 1.23E-02 1.23E-02 4.70E-05	IEN-LOSPOD OTH-R1 RC1CB100V0 RC2CB200V0 CCX-BY-PN
149	1.31E-11	.02	LOSS OF OFFSITE FAILURE TO PUMP GIA FAILS; PUMP DIB FAILS & DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR STOP CK V007A, CB & RELAY FTC & ST CK V007B & C B FTC & RE FTC & CB ECS221 SPO THE SQUIB VALVES TO OPERATE	WITH RCS DRAINED CB ECS122 SPO	4.44E-03 4.20E-01 1.53E-02 1.53E-02 3.30E-05	IEN-LOSPOD OTH-R1 RNMAM0004S RNMAM0007S ADX-EV-SA
150	1.25E-11	.02	LOSS OF OFFSITE FAILURE TO CCF TO START FAILURE OF OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS PMS OUTPUT LOGIC I/Os TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 2.00E-03 2.09E-03 1.60E-03	IEN-LOSPOD OTH-R1 ZOK-PD-ES RNMAM011 RNMAM015
151	1.24E-11	.02	LOSS OF OFFSITE FAILURE TO CCF TO START CCF OF THE POWER	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF THE PUMPS INTERFACE OUTPUT BOARDS IN PMS	WITH RCS DRAINED	4.44E-03 4.20E-01 7.70E-04 8.62E-06	IEN-LOSPOD OTH-R1 RNM-PM-FS CCX-EP-SAM
152	1.20E-11	.02	LOSS OF OFFSITE FAILURE TO BREAKER 100 D/G FAILS TO CCF OF IRWST INJ	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILS TO OPEN START & RUN OR BKR 202 FAILS TO CLOSE MOVs 121A, 121B, & RMS V023	WITH RCS DRAINED (#3.5)	4.44E-03 4.20E-01 1.23E-02 2.02E-02 2.60E-05	IEN-LOSPOD OTH-R1 Z02M0001 IWX-MV-G01
153	1.20E-11	.02	LOSS OF OFFSITE D/G FAILS TO BREAKER 200 CCF OF IRWST INJ	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR START & RUN OR BKR 102 FAILS TO CLOSE FAILS TO OPEN MOVs 121A, 121B, & RMS V023	WITH RCS DRAINED (#5.31)	4.44E-03 4.20E-01 2.02E-02 1.23E-02 1.60E-05	IEN-LOSPOD Z01M0001 BC2CR250V0 IWX-MV-G01
154	1.18E-11	.02	LOSS OF OFFSITE PUMP SUBLOOP B D/G FAILS TO DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR HARDWARE FAILURE OR DIVERTED FLOW START & RUN OR BKR 102 FAILS TO CLOSE THE SQUIB VALVES TO OPERATE	WITH RCS DRAINED	4.44E-03 4.20E-01 1.0E-02 2.0E-02 3.00E-05	IEN-LOSPOD OTH-R1 Z01M0001 Z01M0001 ADX-EV-SA
155	1.17E-11	.02	LOSS OF OFFSITE COMMON CAUSE CCF OF THE POWER	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKER TO CLOSE INTERFACE OUTPUT BOARDS IN PMS	WITH RCS DRAINED	4.44E-03 4.20E-01 7.30E-04 8.62E-06	IEN-LOSPOD OTH-R1 CCX-CB-GC CCX-EP-SAM
156	1.15E-11	.02	LOSS OF RNS WITH RCS FILLED SOFTWARE CCF FAILURE OF	INITIATING EVENT OCCURS OF ALL CARDS MANUAL DAS REACTOR TRIP	HARDWARE	9.61E-04 1.20E-06 1.00E-02	IEN-RNSMD CCX-SPTW MDAS
157	1.14E-11	.02	LOSS OF OFFSITE FAILURE TO CCF TO RUN OF COMMON CAUSE	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR ENGINE-DRIVEN FUEL PUMPS FAILURE OF THE BATTERIES	WITH RCS DRAINED IDSA-DB-1A/1B	4.44E-03 4.20E-01 1.30E-04 4.70E-05	IEN-LOSPOD OTH-R1 ZOK-PD-EP CCX-BY-PN

Table 54B-3

CASE 1 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER
158	1.12E-11	.02	LOSS OF OFFSITE FAILURE TO PUMP 01A FAILS: PUMP 01B FAILS & CCF OF IRWST INT MOVs	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR STOP CK V007A, CB & RELAY PTC, CR ECS122 SPO STOP CK V007B & C B PTC & RE PTC & CR ECS221 SPO 121A, 121B, & RNS V023	WITH RCS DRAINED 4.44E-03 4.20E-01 1.53E-02 1.53E-02 2.60E-05	IEV-LOSPO OTH-R1 RNAMOD02S RNBMOD02S IMX-MV-G01
159	1.13E-11	.02	LOSS OF OFFSITE FAILURE TO FIXED COMPONENT FAILURES CCF OF STRAINERS IN IRWST TANK	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURES CCF OF STRAINERS IN IRWST TANK	WITH RCS DRAINED 4.44E-03 4.20E-01 5.04E-04 1.20E-05	IEV-LOSPO OTH-R1 EDIMOD01 IMX-FL-GP
160	1.11E-11	.02	LOSS OF CCS/SWS CHECK VALVE CHECK VALVE IRWST DISCHARGE	WITH RCS DRAINED 123A 124A LINE "B" INITIATING EVENT OCCURS FAILS TO OPEN FAILS TO OPEN STRAINER PLUGGED	6.02E-04 8.76E-03 8.76E-03 2.40E-04	IEV-COND IWACV123AO IWACV124AO IWB-PLUG
161	1.11E-11	.02	LOSS OF CCS/SWS CHECK VALVE CHECK VALVE IRWST DISCHARGE	WITH RCS DRAINED 123A 125A LINE "B" INITIATING EVENT OCCURS FAILS TO OPEN FAILS TO OPEN STRAINER PLUGGED	6.02E-04 8.76E-03 8.76E-03 2.40E-04	IEV-COND IWACV123AO IWACV125AO IWB-PLUG
162	1.11E-11	.02	LOSS OF CCS/SWS CHECK VALVE CHECK VALVE IRWST DISCHARGE	WITH RCS DRAINED 122A 124A LINE "B" INITIATING EVENT OCCURS FAILS TO OPEN FAILS TO OPEN STRAINER PLUGGED	6.02E-04 8.76E-03 8.76E-03 2.40E-04	IEV-COND IWACV122AO IWACV124AO IWB-PLUG
163	1.11E-11	.02	LOSS OF CCS/SWS CHECK VALVE CHECK VALVE IRWST DISCHARGE	WITH RCS DRAINED 122A 125A LINE "B" INITIATING EVENT OCCURS FAILS TO OPEN FAILS TO OPEN STRAINER PLUGGED	6.02E-04 8.76E-03 8.76E-03 2.40E-04	IEV-COND IWACV122AO IWACV125AO IWB-PLUG
164	1.10E-11	.02	OVERDRAINING OF RHN-MAN04-SUCC CCF OF PRESSURE TRANSMITTERS	RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT	4.44E-06 9.45E-01 2.63E-06	IEV-RCSD0 RHN-MAN04-SUCC CX-XMTRX
165	1.10E-11	.02	LOSS OF OFFSITE FAILURE TO PUMP MP 01B DIG FAILS TO CCF OF STRAINERS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR STA'1 & RUN OR "VER 102 FAILS TO CLOSE IN IRWST TANK	WITH RCS DRAINED 4.44E-03 4.20E-01 2.44E-02 2.02E-02 1.20E-05	IEV-LOSPO OTH-R1 EDIMOD02 EDIMOD03 IMX-FL-GP
166	1.09E-11	.02	LOSS OF OFFSITE OFFSITE CCF OF OUTPUT DUE TO CCF OF	POWER INITIATING EVENT OCCURS AC POWER RECOVERED IN LOGIC I/Os THE SQUIB VALVES TO OPERATE	WITH RCS DRAINED 4.44E-03 5.80E-01 1.41E-04 3.00E-05	IEV-LOSPO SNC-K15 CX-PL4MOD1 ADK-EV-SA
167	1.08E-11	.02	LOSS OF OFFSITE FAILURE TO BATTERY CCF OF PRESSURE TRANSMITTERS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR DB1 UNAVAILABLE	WITH RCS DRAINED 4.44E-03 4.20E-01 2.10E-03 2.63E-06	IEV-LOSPO - OTH-R1 EDIMOD03 CX-XMTRX
168	1.07E-11	.02	OVERDRAINING OF RHN-MAN04-SUCC OPERATOR FAILS MECHANICAL	RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT TO OPEN TWO IRWST MOVs FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-06 9.45E-01 1.15E-03 2.21E-03	IEV-RCSD0 RHN-MAN04-SUCC RHN-MAN02 RHN23MOD02S

Table 54B-3

CASE 1 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER
169	1.06E-11	.02	LOSS OF CCS/SWS SOFTWARE CCF OF OPERATOR FAILS	WITH RCS DRAINED INITIATING EVENT OCCURS OUTPUT LOGIC I/Os TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	6.02E-04 1.10E-05 1.60E-03	IEV-COND CCX-PHAMOD1-SW RHN-MAN05
170	1.05E-11	.01	LOSS OF OFFSITE FAILURE TO PUMP 01B FAILS & BREAKER 100 DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR ST OR V007B & C B FTC & RE FTC & CB ECS221 SPO FAILS TO OPEN [#3.5] THE SQUIB VALVES TO OPERATE	4.44E-03 4.20E-01 1.53E-02 1.23E-02 3.00E-05	IEV-LOSPD OTH-R1 RHNMOD07S FCICB100VO ADK-EV-SA
171	1.05E-11	.01	LOSS OF OFFSITE FAILURE TO PUMP 01A FAILS, BREAKER 200 DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR STOP C: V007A, CB & RELAY FTC: CB ECS122 SPO FAILS 1J OPEN [#5.3] THE SQUIB VALVES TO OPERATE	4.44E-03 4.20E-01 1.53E-02 1.23E-02 3.00E-05	IEV-LOSPD OTH-R1 RHNMOD06S EC2CB200VO ADK-EV-SA
172	1.05E-11	.01	LOSS OF OFFSITE FAILURE TO BATTERY FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR DB1 UNAVAILABLE DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.20E-03 1.16E-03 2.21E-03	IEV-LOSPD OTH-R1 EDIMOD093 PMA0301ASA RNC3MOD55
173	1.05E-11	.01	LOSS OF OFFSITE FAILURE TO BATTERY FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR DB1 UNAVAILABLE DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.20E-03 1.16E-03 2.21E-03	IEV-LOSPD OTH-R1 EDIMOD093 PMA0301BSA RN23MOD55
174	1.03E-11	.01	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR 4KV BREAKERS TO OPEN PMS OUTPUT LOGIC I/Os FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 1.20E-03 2.09E-03 2.21E-03	IEV-LOSPD OTH-R1 ECX-CB-G0 PHAMOD11 RN23MOD55
175	1.03E-11	.01	LOSS OF CCS/SWS COND. PROB. OF LEVEL OPERATOR FAILS	WITH RCS DRAINED INITIATING EVENT OCCURS REC-MANDAS (FAILURE OF MANUAL DAS ACT. TRANSMITTER FAILURE BEFORE CORE DAMAGE TO ACTUATE ADS	6.02E-04 5.06E-01 6.84E-05 4.93E-04	IEV-COND REC-MANDAS IW2TL1600FX ADN-MAN01
176	1.03E-11	.01	LOSS OF CCS/SWS COND. PROB. OF LEVEL OPERATOR FAILS	WITH RCS DRAINED INITIATING EVENT OCCURS REC-MANDAS (FAILURE OF MANUAL DAS ACT. TRANSMITTER FAILURE BEFORE CORE DAMAGE TO ACTUATE ADS	6.02E-04 5.06E-01 6.84E-05 4.93E-04	IEV-COND REC-MANDAS IW1TL1700FX ADN-MAN01
177	1.03E-11	.01	LOSS OF OFFSITE FAILURE TO FAILURE OF CCF OF PRESSURE TRANSMITTERS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FLS OUTPUT LOGIC I/Os TRANSMITTERS	4.44E-03 4.20E-01 2.09E-03 2.63E-06	IEV-LOSPD OTH-R1 PLSMOD011 CCX-XMTRX
178	1.02E-11	.01	LOSS OF OFFSITE FAILURE TO PUMP SURLOOP B D/G FAILS TO CCF OF IRWST INU	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR HARDWARE FAILURE OR DIVERTED FLOW START & RUN OR BKR 102 FAILS TO CLOSE MOVs 121A, 121B, & RNS V023	4.44E-03 4.20E-01 1.04E-02 2.02E-02 2.60E-05	IEV-LOSPD OTH-R1 CCBMOD0915 Z01M0061 INX-MV-G01
179	9.97E-12	.01	LOCA/RNS PIPE OPERATOR FAILS CCF OF STRAINERS	RUPTURE WITH RCS FILLED INIT. EVENT OCCURS TO ISOLATE RNS PIPE RUPTURE IN IRWST TANK	1.51E-05 5.50E-02 1.20E-05	IEV-LOCAPRND RHN-MAN04 INX-FL-GP

Table 54B-3

CASE 1 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIL EVENT NAME		EVENT PROB.	IDENTIFIER
180	9.86E-12	.01	LOSS OF CCS/SWS WITH RCS FILLED CCF OF THE POWER INTERFACE OUTPUT BOARDS IN PMS EDS3 MA 1 DISTR. PNL FAILURE OR T&M	INITIATING EVENT OCCURS	3.75E-03 8.62E-06 3.05E-04	IEV-COMND CCX-EP-SAM ED3MOD07
181	9.85E-12	.01	LOSS OF OFFSITE FAILURE TO COMMON CAUSE CCF OF STRAINERS IN IRWST TANK	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR STANDBY DG TO RBN	4.44E-03 4.20E-01 4.40E-04 1.20E-05	IEV-LOSPD OTH-R1 ZOK-DG-DR IRW-FL-GP
182	9.82E-12	.01	LOSS OF CCS/SWS ORIFICE FAILURE OPERATOR FAILS COND. PROB. OF RHN-MANO5 IOP.	WITH RCS DRAINED DUE TO PLUGGING TO OPEN TWO IRWST MOVs FAILS TO OPEN RNS MOV V023)	6.02E-04 .46E-05 1.15E-03 1.50E-01	IEV-COMND IRW20R160SPX IRN-MANO5 RHN-MANO5C
183	9.82E-12	.01	LOSS OF CCS/SWS ORIFICE FAILURE OPERATOR FAILS COND. PROB. OF RHN-MANO5 IOP.	WITH RCS DRAINED DUE TO PLUGGING TO OPEN TWO IRWST MOVs FAILS TO OPEN RNS MOV V023)	6.02E-04 9.46E-05 1.15E-03 1.50E-01	IEV-COMND IRW20R170SPX IRN-MANO5 RHN-MANO5C
184	9.81E-12	.01	LOSS OF OFFSITE FAILURE TO CCF TO START CCF OF PRESSURE TRANSMITTERS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS	4.44E-03 4.20E-01 2.00E-03 2.63E-06	IEV-LOSPD OTH-R1 ZOK-PD-ES CCX-KMTRX
185	9.81E-12	.01	LOSS OF OFFSITE FAILURE TO CCF TO OPEN CCF OF THE POWER	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF THE STOP CHECK VALVES INTERFACE OUTPUT BOARDS IN PMS	4.44E-03 4.20E-01 6.10E-04 8.62E-06	IEV-LOSPD OTH-R1 RBN-KV-GC CCX-EP-SAM
186	9.72E-12	.01	LOSS OF OFFSITE FAILURE TO PUMP MP 01A PUMP MP 01A DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE DIVERTED FLOW	4.44E-03 4.20E-01 7.12E-03 2.44E-02 3.00E-05	IEV-LOSPD OTH-R1 SWAM0007 SWBM0002 ADK-EV-SA
187	9.57E-12	.01	LOSS OF OFFSITE FAILURE TO FAILURE OF DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OUTPUT DRIVER THE SQUIB VALVES TO OPERATE	4.44E-03 4.20E-01 1.71E-04 3.00E-05	IEV-LOSPD OTH-R1 ECSEPM001SA ADK-EV-SA
188	9.56E-12	.01	LOSS OF OFFSITE FAILURE TO CCF TO START FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 .1E-03 .8E-03 2.21E-03	IEV-LOSPD OTH-R1 ZOK-PD-ES PMA0301ASA RN23M005S
189	9.56E-12	.01	LOSS OF OFFSITE FAILURE TO CCF TO START FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 1.00E-03 .16E-03 2.21E-03	IEV-LOSPD OTH-R1 ZOK-PD-ES PMA0301BSA RN23M005S
190	9.44E-12	.01	LOSS OF OFFSITE OFFSITE CMF OF OUTPUT CCF OF IRWST INJ	POWER INITIATING EVENT OCCURS AC POWER RECOVERED IN 1 HOUR MOVs 121A, 121B, & RNS V023	4.44E-03 5.80E-01 1.41E-04 2.60E-05	IEV-LOSPD SUC-RIS CCX-PL4MOD1 IRW-MV-G01

Table 54B-3

CASE 1 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS	WITH RCS DRAINED	EVENT PROB.	IDENTIFIER
191	9.13E-12	.01	LOSS OF OFFSITE FAILURE TO D/G FAILS TO D/G FAILS TO CCF OF STRAINERS IN IRWST TANK	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR START & RUN OR BBR 182 FAILS TO CLOSE START & RUN OR BBR 282 FAILS TO CLOSE	WITH RCS DRAINED	4.44E-03 4.20E-01 2.02E-02 2.02E-02 1.20E-05	IEV-LOSPO OTH-R1 Z01M0001 Z02M0001 INX-PL-GP
192	9.12E-12	.01	LOSS OF OFFSITE FAILURE TO PUMP 01A FAILS BREAKER 200 CCF OF IRWST INJ	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR STOP CK V007A, CB & RELAY PTC, CB ECR122 SPO FAILS TO OPEN [#5.3] MOVs 121A, 121B, & RNS V023	WITH RCS DRAINED	4.44E-03 4.20E-01 1.53E-02 1.23E-02 2.60E-05	IEV-LOSPO OTH-R1 RNAMOD06S EC2CB200V0 INX-MV-G01
193	9.12E-12	.01	LOSS OF OFFSITE FAILURE TO PUMP 01B FAILS & BREAKER 100 CCF OF IRWST INJ	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR ST CK V007B & C B PTC & RE PTC A' CR ECR221 SPO FAILS TO OPEN [#3.5] MOVs 121A, 121B, & RNS V023	WITH RCS DRAINED	4.44E-03 4.20E-01 1.53E-02 1.23E-02 2.60E-05	IEV-LOSPO OTH-R1 RNBMOD07S EC1CB100V0 INX-MV-G01
194	8.91E-12	.01	LOSS OF CCS/SWS CCF OF ACTUATION LOGIC GROUPS OPERATOR FAILS COMD. PROB. OF RHN-MAN05 (OP.)	WITH RCS DRAINED INITIATING EVENT OCCURS TO OPEN TWO IRWST MOVs FAILS TO OPEN RNS MOV V023)		6.02E-04 8.58E-05 1.15E-03 1.50E-01	IEV-COMD CCX-PMAN002X INN-MAN05 RHN-MAN05C
195	8.88E-12	.01	LOSS OF OFFSITE FAILURE TO BATTERY COMMON CAUSE STANDBY DG	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR DB1 UNAVAILABLE FAILURE OF THE BATTERIES UNAVAILABLE DUE TO TEST AND MAINTENANCE	WITH RCS DRAINED	4.44E-03 4.20E-01 2.20E-03 6.70E-05 4.60E-02	IEV-LOSPO OTH-R1 EDIMOD03 CCX-BV-PB Z02DG002TM
196	8.46E-12	.01	LOSS OF OFFSITE FAILURE TO BREAKER 100 BREAKER 200 DUE TO CCF OF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILS TO OPEN [#3.5] FAILS TO OPEN [#5.3] THE SQUIB VALVES TO OP..ATE	WITH RCS DRAINED	4.44E-03 4.20E-01 1.23E-02 1.23E-02 3.90E-05	IEV-LOSPO OTH-R1 EC1CB100V0 EC2CB200V0 ADK-EV-SA
197	8.42E-12	.01	LOSS OF CCS/SWS IRWST DISCHARGE LINE "B" FAILURE OF POWER	WITH RCS DRAINED INITIATING EVENT OCCURS STRAINER PLUGGED INTERFACE OUTPUT BOARD		6.02E-04 2.40E-04 5.83E-05	IEV-COMD INB-PLUG IRAEPI21ASAX
198	8.42E-12	.01	LOSS OF OFFSITE FAILURE TO PUMP MP 01A PUMP MP 01B CCF OF IRWST INJ	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR DIVERTED FLOW	WITH RCS DRAINED	4.44E-03 4.20E-01 7.12E-03 2.44E-02 2.60E-05	IEV-LOSPO OTH-R1 SMAMOD07 SMBMOD02 INX-MV-G01
199	8.36E-12	.01	LOSS OF CCS/SWS CCF OF ACTUATION LOGIC GROUPS BUS UNAVAILABLE	WITH RCS DRAINED INITIATING EVENT OCCURS CORRECTIVE MAINTENANCE		6.02E-04 4.63E-05 3.90E-04	IEV-COMD CCX-PMAN001X IDDBSD01TM
200	8.36E-12	.01	LOSS OF CCS/SWS CCF OF ACTUATION LOGIC GROUPS BUS UNAVAILABLE	WITH RCS DRAINED INITIATING EVENT OCCURS CORRECTIVE MAINTENANCE		6.02E-04 4.63E-05 3.90E-04	IEV-COMD CCX-PMAN001X IDDBSD01TM

Table 54B-4

BASIC EVENT IMPORTANCE - CASE 1

	SYSTEM UNAVAILABILITY (Q) = 7.058E-08	NUMBER OF BASIC EVENTS = 295	NUMBER OF CUTSETS = 6e34	IMPORTANCE (%DECREASE)	NUMBER OF CUTSETS	DECREASE IN SYSTEM UNAVAILABILITY	BASIC EVENT PROBABILITY
1	IEV-CWWD	66.35	2122	4.6836E-08	6.0200E-04		
2	ADX-EV-SA	31.73	290	2.2397E-08	3.0000E-05		
3	IWX-MV-GO1	27.50	266	1.9414E-08	2.6000E-05		
4	IEV-LOSPD	14.63	2450	1.0326E-08	4.4400E-03		
5	IWX-PL-GP	12.96	168	9.1450E-09	1.2000E-05		
6	OTH-R1	9.69	2292	6.8425E-09	4.2000E-01		
7	CCX-SFTW	9.55	26	6.7434E-09	1.2000E-06		
8	IEV-RNSD	8.97	1015	6.3345E-09	8.1500E-05		
9	SUC-R1S	4.94	158	3.4836E-09	5.8000E-01		
10	IEV-RCBOD	4.21	484	2.9731E-09	4.4400E-06		
11	CCX-ORY-SPX	3.83	112	2.7053E-09	3.6300E-06		
12	RHN-MAN05C	3.70	27	2.6101E-09	1.5000E-01		
13	CCX-XMTRX	2.77	97	1.9519E-09	2.6300E-06		
14	RHN-MAN04	2.74	123	1.9325E-09	5.5000E-02		
15	IWN-MAN00C	2.66	23	1.8777E-09	5.0000E-02		
16	IEV-CCWND	2.25	69	1.5863E-09	3.7500E-03		
17	CCX-EP-SAM	1.97	218	1.3927E-09	8.6200E-06		
18	RHN-MAN04-SUCC	1.52	399	1.0743E-09	9.4500E-01		
19	REC-MANDASC	1.46	46	1.0312E-09	5.0600E-01		
20	LPM-MAN05	1.38	37	9.7191E-10	6.8300E-04		
21	IEV-LJCA24D	1.24	428	8.7778E-10	1.1300E-05		
22	REC-MANDAS	1.22	36	8.5761E-10	1.1600E-02		
23	IWB-PLUG	1.21	443	8.5150E-10	2.4000E-04		
24	IWN-MAN00	1.13	189	8.0059E-10	1.1500E-03		
25	MDAS	1.08	79	7.5911E-10	1.0000E-02		
26	IEV-LOCA24ND	1.04	121	7.3323E-10	1.6800E-05		
27	IWX-CV-AO	.94	395	6.6008E-10	3.0000E-05		
28	ZOX-PD-ES	.87	113	6.1060E-10	2.0000E-03		
29	CCX-BY-PN	.83	237	5.8284E-10	4.7000E-05		
30	IRWMOD05S	.78	380	5.4779E-10	3.0000E-03		
31	Z01MOD01	.76	524	5.3414E-10	2.0200E-02		
32	RN22MOD5S	.75	917	5.2999E-10	2.2100E-03		
33	ED1MOD03	.71	131	4.9867E-10	2.2020E-03		
34	IEV-LOSPND	.67	40	4.7026E-10	1.7100E-02		
35	CCX-ORY-SP	.66	18	4.6569E-10	2.7700E-04		
36	IEV-RNSD	.58	46	4.0677E-10	9.6100E-04		
37	ECX-CB-GO	.52	92	3.6510E-10	1.2000E-03		
38	RHN-MAN05	.50	785	3.5328E-10	1.6000E-03		
39	SUC-R2S	.49	9	3.4566E-10	7.6000E-01		
40	PLSMOD11	.48	73	3.4195E-10	2.0900E-03		
41	CCX-XMTR195	.48	16	3.3742E-10	2.0100E-04		
42	Z02MOD01	.46	187	3.2753E-10	2.0200E-02		
43	EC1CB100VO	.45	380	3.1668E-10	1.2300E-02		
44	RNX-PM-FS	.39	50	2.7618E-10	7.7000E-04		
45	PMAMOD11	.34	296	2.4119E-10	2.0900E-03		
46	ECX-CB-GC	.31	74	2.2118E-10	7.3000E-04		
47	RNX-KV-GO	.31	44	2.1853E-10	6.1000E-04		
48	SWBMOD02	.29	150	2.0748E-10	2.4400E-02		
49	RNBMOD07S	.29	146	2.0625E-10	1.5300E-02		
50	EC2CB200VO	.28	144	1.9692E-10	1.2300E-02		
51	CCX-INPUT-LOGIC	.27	29	1.9140E-10	1.0300E-04		
52	PL50301ASA	.27	47	1.8850E-10	1.1600E-03		
53	PL50301BSA	.27	47	1.8850E-10	1.1600E-03		
54	RNAMOD01S	.26	90	1.8655E-10	1.5300E-02		
55	CCX-PMAMDDIX	.26	195	1.8036E-10	4.6300E-05		
56	ZOX-DG-DR	.19	57	1.3222E-10	4.4000E-04		
57	PMA0301ASA	.18	218	1.2936E-10	1.1600E-03		
58	PMA0301BSA	.18	218	1.2936E-10	1.1600E-03		
59	OTH-R2	.18	29	1.2447E-10	2.4000E-01		
60	CCBMOD01S	.12	91	8.5340E-11	1.0400E-02		
61	ZOX-DG-DS	.12	50	8.3609E-11	2.8000E-04		
62	ED1MOD01	.11	23	8.0589E-11	5.0400E-04		
63	ADN-MAN01	.11	58	7.9719E-11	4.9300E-04		
64	ED1MOD11	.10	55	6.9890E-11	3.1700E-04		
65	ED1MOD113	.10	55	6.9890E-11	3.1700E-04		
66	SWAMOD07	.10	42	6.9016E-11	7.1200E-03		

67	IDAMOD05	.10	354	6.8742E-11	5.1600E-04
68	IDDBSDD1TM	.09	310	6.4586E-11	3.0000E-04
69	IDDBSDK1TM	.09	370	6.4586E-11	3.0000E-04
70	IDBBSDS1TM	.09	370	6.4586E-11	3.0000E-04
71	CCX-PMA030X	.08	130	5.3568E-11	1.3800E-05
72	IDBBSDD1TM	.08	125	5.3536E-11	3.0000E-04
73	IDBBSDK1TM	.08	125	5.3536E-11	3.0000E-04
74	IDBBSDS1TM	.08	125	5.3536E-11	3.0000E-04
75	CCAMOD02	.08	40	5.3178E-11	7.1000E-03
76	ED1MOD13	.07	17	5.0329E-11	3.1700E-04
77	CCX-PL4MOD1	.07	17	4.9372E-11	1.4100E-04
78	ED1MOD07	.07	17	4.8478E-11	3.0500E-04
79	IWA-PLUG	.06	136	4.5067E-11	2.4000E-04
80	CCX-PMAMOD1-SW	.06	128	4.2992E-11	1.1000E-05
81	EC1REDG2GA	.06	57	4.2477E-11	4.3600E-03
82	IEV-LOCAPRND	.06	59	4.2065E-11	1.5100E-05
83	ED2MOD03	.06	68	4.1838E-11	2.7000E-03
84	IDAMOD04	.06	340	4.0934E-11	3.1700E-04
85	EC1REDG1GA	.05	39	3.8556E-11	4.3600E-03
86	ZOX-PD-ER	.05	32	3.7998E-11	1.3000E-04
87	IDABSDS1TM	.05	255	3.7163E-11	3.0000E-04
88	RNDEP023SA	.05	291	3.4971E-11	1.7100E-04
89	CCX-PL403	.05	16	3.3840E-11	9.6900E-05
90	IW1OR170SPX	.04	34	2.8797E-11	9.4600E-05
91	IW2OR160SPX	.04	34	2.8797E-11	9.4600E-05
92	CCX-PMDMOD1	.04	270	2.8108E-11	1.4100E-04
93	IWACV122AO	.04	126	2.8029E-11	8.7600E-03
94	IWACV123AO	.04	126	2.8029E-11	8.7600E-03
95	IWACV124AO	.04	126	2.8029E-11	8.7600E-03
96	IWACV125AO	.04	126	2.8029E-11	8.7600E-03
97	EC5EPMB1SA	.04	9	2.6790E-11	1.7100E-04
98	ZO1MOD04	.04	82	2.5979E-11	1.2500E-03
99	ZO1D0001TM	.04	95	2.5243E-11	4.6000E-02
100	EC1BS001TM	.04	442	2.5138E-11	2.7000E-03
101	EC1BS012TM	.04	442	2.5138E-11	2.7000E-03
102	EC1BS121TM	.04	442	2.5138E-11	2.7000E-03
103	ED3MOD07	.03	26	2.4418E-11	3.0500E-04
104	PMAMOD11X	.03	369	2.4116E-11	6.5300E-04
105	ZO2DG002TM	.03	42	2.2865E-11	4.6000E-02
106	CCX-PL1MOD1	.03	9	2.2094E-11	1.4100E-04
107	CCX-PL7MGD1	.03	9	2.2094E-11	1.4100E-04
108	CCX-PMAMOD1	.03	87	2.1346E-11	1.4100E-04
109	IW1TL170UFX	.03	33	2.0855E-11	6.8400E-05
110	IW2TL160UFX	.03	33	2.0855E-11	6.8400E-05
111	ED3MOD03	.03	35	2.0850E-11	2.2020E-03
112	CCX-BY-PN1	.03	17	1.8431E-11	5.7000E-05
113	CCX-PMD030	.03	184	1.8183E-11	9.6900E-05
114	RNX-CV-GO	.03	12	1.7721E-11	5.1000E-05
115	ZO2MOD04	.03	44	1.7694E-11	1.2500E-03
116	ZOX-BL-ES	.02	16	1.6716E-11	6.0000E-05
117	PL4MOD11	.02	43	1.5793E-11	2.0900E-03
118	CCX-PL103	.02	7	1.5111E-11	9.6900E-05
119	CCX-PL703	.02	7	1.5111E-11	9.6900E-05
120	PL1MOD11	.02	36	1.4332E-11	2.0900E-03
121	PL7MOD11	.02	36	1.4332E-11	2.0900E-03
122	CCX-PMA030	.02	59	1.2905E-11	9.6900E-05
123	PXX-AV-LA	.02	57	1.2491E-11	6.1000E-05
124	PL5XS00ASA	.02	7	1.2481E-11	8.0000E-05
125	CCX-IV-XR	.02	132	1.2178E-11	2.4000E-05
126	SWBMOD09P	.02	31	1.2089E-11	1.8500E-03
127	CCX-EP-SAMX	.02	87	1.1380E-11	2.9400E-06
128	SWAMOD09P	.02	22	1.0838E-11	1.8500E-03
129	CCX-PMAMOD2X	.01	22	1.0555E-11	8.5800E-05
130	IRAEPI21ASAX	.01	42	1.0003E-11	5.8300E-05
131	CCX-PMDMOD4	.01	133	8.2095E-12	4.9800E-05
132	PL40301ASA	.01	29	7.8139E-12	1.1600E-03
133	PL40301BSA	.01	26	7.5545E-12	1.1600E-03
134	ALL-IND-FAIL	.01	27	7.3433E-12	1.0000E-06
135	PL10301ASA	.01	25	7.2707E-12	1.4500E-03
136	PL70301ASA	.01	25	7.2707E-12	1.1600E-03
137	PL10301BSA	.01	24	7.2056E-12	1.1600E-03
138	PL70301BSA	.01	24	7.2056E-12	1.1600E-03
139	PMA0301ASAX	.01	176	5.8789E-12	1.6500E-04
140	PMA0301BSAX	.01	157	5.7396E-12	1.6500E-04
141	PMAXS00ASA	.01	28	5.5586E-12	8.0000E-05
142	RNX-PM-ER	.01	10	5.4562E-12	1.6000E-05
143	AD2MOD01	.01	21	5.0340E-12	5.5400E-02
144	AD2MOD02	.01	21	5.0340E-12	5.5400E-02
145	AD3MOD03	.01	21	5.0340E-12	5.5400E-02
146	AD3MOD04	.01	21	5.0340E-12	5.5400E-02
147	RHN-MAND3	.01	36	5.0231E-12	2.2600E-03

148	IDCBSDD1TM	.01	176	4.9447E-12	3.0000E-04
149	IDCBSDK1TM	.01	176	4.9447E-12	3.0000E-04
150	IDCBSDS1TM	.01	176	4.9447E-12	3.0000E-04
151	CCX-PM-ER	.01	10	4.7707E-12	1.4000E-05
152	SWX-PM-ER	.01	10	4.7707E-12	1.4000E-05
153	ED2MOD11	.01	20	4.3133E-12	3.1700E-04
154	EC2BS002TM	.01	187	3.9581E-12	2.7000E-03
155	EC2BS022TM	.01	187	3.9581E-12	2.7000E-03
156	EC2BS221TM	.01	187	3.9581E-12	2.7000E-03
157	IWBCV122AO	.01	184	3.8876E-12	8.7600E-03
158	IWBCV123AO	.01	184	3.8876E-12	8.7600E-03
159	IWBCV124AO	.01	184	3.8876E-12	8.7600E-03
160	IWBCV125AO	.01	184	3.8876E-12	8.7600E-03
161	CCX-IV-XR1	.01	6	3.7030E-12	2.4000E-05
162	CCX-PL4MOD1-SW	.01	8	3.6009E-12	1.1000E-05
163	PMAMOD12X	.00	123	3.4291E-12	6.5300E-04
164	ED3MOD01	.00	10	3.2503E-12	5.0400E-04
165	CCX-INPUT-LOGICK	.00	12	3.1284E-12	2.5900E-05
166	PMAX500ASAX	.00	158	3.1161E-12	8.0000E-05
167	CCX-EP-SA	.00	8	2.8215E-12	8.6200E-06
168	EC1MOD01	.00	16	2.6423E-12	2.0200E-04
169	PMDDMOD11	.00	206	2.6317E-12	2.0900E-03
170	PL4MOD12	.00	16	2.6108E-12	2.0900E-03
171	IDBFD013RQ	.00	10	2.0343E-12	1.2000E-05
172	IDBFD014RQ	.00	10	2.0343E-12	1.2000E-05
173	EC2MOD01	.00	14	2.0179E-12	2.0200E-04
174	CCX-LS-FA	.00	32	1.7374E-12	5.3700E-06
175	IDAMOD08	.00	96	1.6454E-12	3.1700E-04
176	CCX-PL1MOD1-SW	.00	4	1.5710E-12	1.1000E-05
177	CCX-PL7MOD1-SW	.00	4	1.5710E-12	1.1000E-05
178	IDDFD019RQ	.00	58	1.4450E-12	1.2000E-05
179	IDDFD020RQ	.00	58	1.4450E-12	1.2000E-05
180	ZON-MAN01	.00	7	1.3393E-12	2.6700E-03
181	CCX-IN-LOGIC-SW	.00	8	1.3228E-12	1.1000E-05
182	CCX-PMAMOD2-SW	.00	8	1.3228E-12	1.1000E-05
183	CCX-PMDMOD1-SW	.00	56	1.3217E-12	1.1000E-05
184	CCX-PMDMOD4-SW	.00	56	1.3217E-12	1.1000E-05
185	RNAEPRNPSA	.00	9	1.3107E-12	1.7100E-04
186	RNBEPRNPSA	.00	9	1.3107E-12	1.7100E-04
187	CCX-PMAMOD4	.00	41	1.2623E-12	4.9800E-05
188	SWNTP001RI	.00	5	1.2469E-12	5.2300E-03
189	SWB-MAN02	.00	4	1.1959E-12	1.6000E-03
190	PMD0301ASA	.00	134	1.1637E-12	1.1600E-03
191	PMAMOD21X	.00	14	1.1450E-12	1.1600E-03
192	SW7EPSBPASA	.00	7	1.1083E-12	1.7100E-04
193	CCB-MAN01	.00	6	1.1010E-12	1.0700E-03
194	PL1MOD12	.00	7	1.0618E-12	2.0900E-03
195	PL7MOD12	.00	7	1.0618E-12	2.0900E-03
196	PMD0301BSA	.00	117	1.0526E-12	1.1600E-03
197	DG2-LOGIC	.00	1	9.6501E-13	5.0000E-03
198	PMDMOD12	.00	86	9.0394E-13	2.0900E-03
199	IRAEPI21BSAX	.00	66	8.9639E-13	5.8300E-05
200	PL40302ASA	.00	7	8.6231E-13	1.1600E-03
201	CCNTF101RI	.00	5	8.4999E-13	5.2300E-03
202	IDBBSDD1LF	.00	7	8.1146E-13	4.8000E-06
203	IDBBSOK1LF	.00	7	8.1146E-13	4.8000E-06
204	IDBBSDS1LF	.00	7	8.1146E-13	4.8000E-06
205	CC1EPSBPASA	.00	6	7.6561E-13	1.7100E-04
206	PMA0302ASAX	.00	59	7.3963E-13	1.6500E-04
207	DAS	.00	4	7.3730E-13	1.0000E-02
208	ZO1MOD03	.00	8	7.3574E-13	1.0000E-04
209	CC1EPSBPBSA	.00	5	6.3893E-13	1.7100E-04
210	SW7EPSBPBSA	.00	5	6.3893E-13	1.7100E-04
211	CCX-AV-LA	.00	5	6.2306E-13	6.1000E-05
212	ED1BSDS1LF	.00	3	6.0907E-13	4.8000E-06
213	PL40302BSA	.00	4	6.0296E-13	1.1600E-03
214	PMA0302BSAX	.00	40	6.0041E-13	1.6500E-04
215	ADX-MV-GO	.00	4	5.9086E-13	1.1000E-03
216	SW7EPCTFASA	.00	4	5.7998E-13	1.7100E-04
217	SW7EPCTFBPA	.00	4	5.7998E-13	1.7100E-04
218	CMX-VS-FA	.00	7	5.2991E-13	3.8400E-05
219	CMX-CV-GO	.00	4	5.2014E-13	5.1000E-05
220	ED3BSDS1TM	.00	1	4.8805E-13	3.0000E-04
221	IDDBSDD1LF	.00	31	4.7840E-13	4.8000E-06
222	IDBBSOK1LF	.00	31	4.7840E-13	4.8000E-06
223	IDBBSDS1LF	.00	31	4.7840E-13	4.8000E-06
224	IWNTRK001AF	.00	5	4.7595E-13	2.4000E-06
225	PMDMOD41	.00	67	4.6219E-13	6.3500E-04
226	RC1OR195SP	.00	4	4.5386E-13	7.2200E-03
227	ZO2MOD03	.00	5	4.3032E-13	1.0000E-04
228	EC1MOD12	.00	66	4.2799E-13	4.8000E-05

229	CCX-PMDEH0	.00	29	4.0001E-13	4.0300E-06
230	PRAAV108LA	.00	11	3.4428E-13	1.0900E-03
231	PRBAV108LA	.00	11	3.4428E-13	1.0900E-03
232	PMD0302ASA	.00	46	3.4162E-13	1.1600E-03
233	IDDMOD33	.00	45	3.3173E-13	5.1600E-04
234	RC1TTL195UF	.00	3	3.2829E-13	5.2300E-03
235	PL10302ASA	.00	3	3.1919E-13	1.1600E-03
236	PL70302ASA	.00	3	3.1919E-13	1.1600E-03
237	IDAMOD06	.00	48	3.1330E-13	4.3200E-05
238	IDDMOD32	.00	58	3.0864E-13	3.1700E-04
239	CCX-BC-SA	.00	5	2.8300E-13	8.4000E-06
240	IDAMOD02	.00	31	2.7167E-13	2.7000E-03
241	IDAMOD03	.00	31	2.7167E-13	2.7000E-03
242	CCX-PMAMOD4-SW	.00	120	2.5979E-13	1.1000E-05
243	PL10302BSA	.00	20	2.5402E-13	1.1600E-03
244	PL70302BSA	.00	20	2.5402E-13	1.1600E-03
245	PL1MOD51	.00	20	2.4403E-13	8.7400E-04
246	CCX-HE-AF	.00	3	2.3115E-13	1.2000E-06
247	PMD0302BSA	.00	29	2.3048E-13	1.1600E-03
248	PL1XS00ASA	.00	3	2.1649E-13	8.0000E-05
249	PL4XS00ASA	.00	3	2.1649E-13	8.0000E-05
250	PL7XS00ASA	.00	3	2.1649E-13	8.0000E-05
251	PRx-MAN01	.00	4	1.8641E-13	4.0800E-04
252	PLMMOD41	.00	2	1.7897E-13	6.3500E-04
253	EC2MOD22	.00	17	1.5954E-13	4.8000E-05
254	PRAAV108TM	.00	9	1.5754E-13	5.0000E-04
255	PRBAV108TM	.00	9	1.5754E-13	5.0000E-04
256	IDCFD007RQ	.00	18	1.5343E-13	1.2000E-05
257	IDCFD008RQ	.00	18	1.5343E-13	1.2000E-05
258	PMAMOD22X	.00	2	1.4211E-13	1.1600E-03
259	CCX-XMTR	.00	3	1.3822E-13	2.0100E-04
260	PMAMOD41	.00	34	1.3656E-13	6.3500E-04
261	IDABSDS1LF	.00	24	1.2790E-13	4.8000E-06
262	IDDMOD38	.00	31	1.1813E-13	3.1700E-04
263	CCX-TRNSM	.00	2	1.0192E-13	2.0100E-04
264	EC1MOD121	.00	24	1.0159E-13	1.6800E-05
265	EC1MOD13	.00	2	9.6145E-14	4.8000E-05
266	EC2MOD23	.00	2	9.6145E-14	4.8000E-05
267	CCX-PMAEH0X	.00	14	9.4591E-14	4.0300E-06
268	DG1-LOGIC	.00	1	9.0039E-14	5.0000E-03
269	PMDXS00ASA	.00	32	6.9944E-14	8.0000E-05
270	ZOX-BL-ER	.00	1	6.5947E-14	1.3600E-06
271	ED2MOD01	.00	1	6.5170E-14	5.0400E-04
272	ZOX-FL-GP	.00	1	6.2950E-14	1.3000E-06
273	PMDEH0A1SA	.00	28	6.1395E-14	8.0000E-05
274	IDCBSDD1LF	.00	12	5.3346E-14	4.8000E-06
275	IDCBSDK1LF	.00	12	5.3846E-14	4.8000E-06
276	IDCBSDS1LF	.00	12	5.3846E-14	4.8000E-06
277	IDAMOD07	.00	15	5.2292E-14	2.1900E-02
278	IDDMOD21	.00	6	4.9960E-14	1.9200E-04
279	PMDMOD42	.00	11	4.0523E-14	6.3500E-04
280	IDABSDD1TM	.00	3	2.4980E-14	3.0000E-04
281	IDABSDK1TM	.00	3	2.4980E-14	3.0000E-04
282	PRX-HR-ML	.00	4	2.3759E-14	1.2000E-07
283	ZANMOD01	.00	8	1.9984E-14	8.4000E-05
284	EC1BS001LF	.00	7	1.8319E-14	4.8000E-06
285	PMDEH0A2SA	.00	10	1.7431E-14	8.0000E-05
286	IDOMOD34	.00	10	1.2101E-14	4.3200E-05
287	PMAEH0A1SAX	.00	6	1.0325E-14	8.0000E-05
288	PMAMOD42	.00	4	9.6589E-15	6.3500E-04
289	IDDMOD35	.00	4	5.7732E-15	2.1900E-02
290	EC2MOD221	.00	3	1.3323E-15	1.6800E-05
291	IWX-XMTRLW	.00	2	1.2212E-15	9.2000E-09
292	IDDMOD22	.00	3	9.9920E-16	2.7000E-03
293	IDDMOD23	.00	3	9.9920E-16	2.7000E-03
294	PRCEP108SA	.00	1	2.2204E-16	1.7100E-04
295	PRDEP108SA	.00	1	2.2204E-16	1.7100E-04

SYSTEM UNAVAILABILITY (Q) = 7.058E-08
 NUMBER OF BASIC EVENTS = 295
 NUMBER OF CUTSETS = 6834

BASIC EVENT	IMPORTANCE (%INCREASE)	NUMBER OF CUTSETS	INCREASE IN SYSTEM UNAVAILABILITY	BASIC EVENT PROBABILITY
1 CCX-SFTW	7.961444E+06	26	5.6195E-03	1.2000E-06
2 IWX-FL-GF	1.079667E+06	168	7.6208E-04	1.2000E-05
3 IWX-MV-Q01	1.057835E+06	266	7.4666E-04	2.6000E-05
4 ADX-EV-SA	1.057684E+06	290	7.4656E-04	3.0000E-05
5 CCX-ORY-SPX	1.055829E+06	112	7.4525E-04	3.6300E-06
6 CCX-XMTRX	1.051485E+06	97	7.4218E-04	2.6300E-06
7 IEV-RCSOD	948041.	484	6.6917E-04	4.4400E-06
8 CCX-EP-SAM	228896.	218	1.6156E-04	8.6200E-06
9 IEV-CWCD	110158.	2122	7.7754E-05	6.0200E-04
10 IEV-RNSD	110106.	1015	7.7718E-05	8.1500E-05
11 IEV-LOCA24D	110051.	428	7.7679E-05	1.1300E-05
12 IEV-LOCA24ND	61832.6	121	4.3644E-05	1.6800E-05
13 IWX-CV-AO	31171.5	395	2.2002E-05	3.0000E-05
14 CCX-BY-PN	17.68.0	237	1.2400E-05	4.7000E-05
15 ALL-IND-FAIL	10403.6	27	7.3433E-06	1.0000E-06
16 CCX-PMAMOD1-SW	5537.16	128	3.9084E-06	1.1000E-05
17 CCX-PMAMOD1X	5518.75	195	3.3954E-06	4.6300E-05
18 CCX-PMA030X	5499.37	130	3.8817E-06	1.3800E-05
19 CCX-EP-SAMX	5484.01	87	3.8709E-06	2.9400E-06
20 IWB-PLUG	5025.32	443	3.5471E-06	2.4000E-04
21 IEV-LOCAPRND	3946.65	59	2.7857E-06	1.5100E-05
22 IEV-LOSPD	3280.31	2450	2.3154E-06	4.4400E-03
23 CCX-INPUT-LOGIC	2632.46	29	1.8581E-06	1.0300E-04
24 CCX-ORY-SP	2381.19	18	1.6801E-06	2.7700E-04
25 CCX-XMTR195	2377.85	16	1.6784E-06	2.0100E-04
26 LPM-MAN05	2014.66	37	1.4220E-06	6.8300E-04
27 IWN-MAN00	985.152	189	6.9536E-07	1.1500E-03
28 CCX-IV-XR	718.885	132	5.0742E-07	2.4000E-05
29 IEV-RNSND	599.100	46	4.2287E-07	9.6100E-04
30 IEV-CWND	597.050	69	4.2142E-07	3.7500E-03
31 RNX-PM-FS	507.769	50	3.5841E-07	7.7000E-04
32 RNX-KV-GO	507.244	44	3.5803E-07	6.1000E-04
33 CCX-PL4MOD1	496.011	17	3.5011E-07	1.4100E-04
34 CCX-PL403	496.712	14	3.4919E-07	9.6900E-05
35 RNX-CV-GO	492.266	12	3.4746E-07	5.1000E-05
36 RNX-PM-ER	483.120	10	3.4101E-07	1.6000E-05
37 CCX-PM-ER	482.774	10	3.4076E-07	1.4000E-05
38 SWX-PM-ER	482.774	10	3.4076E-07	1.4000E-05
39 CCX-PL4MOD1-SW	463.773	8	3.2735E-07	1.1000E-05
40 CCX-EP-SA	463.729	8	3.2732E-07	8.6200E-06
41 CCX-LS-FA	458.366	32	3.2353E-07	5.3700E-06
42 CCX-BY-PN1	458.089	17	3.2334E-07	5.7000E-05
43 IW1TL170UFX	431.933	33	3.0488E-07	6.8400E-05
44 IW2TL160UFX	431.933	33	3.0488E-07	6.8400E-05
45 ZOX-PD-ES	431.667	113	3.0469E-07	2.0000E-03
46 IW1OR170SPX	431.229	34	3.0438E-07	9.4600E-05
47 IW2OR160SPX	431.229	34	3.0438E-07	9.4600E-05
48 ECX-CB-GO	430.529	92	3.0389E-07	1.2000E-03
49 ECX-CB-GC	428.942	74	3.0277E-07	7.3000E-04
50 ZOX-DG-DR	425.533	57	3.0036E-07	4.4000E-04
51 ZOX-DG-DS	422.929	50	2.9852E-07	2.8000E-04
52 ZOX-PD-ER	413.730	32	2.9203E-07	1.3000E-04
53 ZOX-BL-ES	394.681	16	2.7858E-07	6.0000E-05
54 RN23MOD55	339.003	917	2.3928E-07	2.2100E-03
55 ED1MOD03	320.131	131	2.2596E-07	2.2020E-03
56 RHN-MAN05	312.316	785	2.2045E-07	1.6000E-03
57 ED1MOD11	312.255	55	2.2040E-07	3.1700E-04
58 ED1MOD113	312.255	55	2.2040E-07	3.1700E-04
59 IDDBSDD1TM	304.915	370	2.1522E-07	3.0000E-04
60 IDDBSDK1TM	304.915	370	2.1522E-07	3.0000E-04
61 IDDBSDS1TM	304.915	370	2.1522E-07	3.0000E-04
62 PXX-AV-LA	290.101	57	2.0477E-07	6.1000E-05
63 RNDEP023SA	289.685	291	2.0447E-07	1.7100E-04
64 CCX-PMDMOD1	282.383	270	1.9932E-07	1.4100E-04
65 IWNNTK001AF	280.959	5	1.9831E-07	2.4000E-06
66 PRX-HR-ML	280.501	4	1.9799E-07	1.2000E-07
67 CCX-HE-AF	272.898	3	1.9262E-07	1.2000E-06
68 IWA-PLUG	265.973	136	1.8773E-07	2.4000E-04
69 CCX-PMD030	265.821	184	1.8763E-07	9.6900E-05
70 IRWMOD055	257.915	380	1.8205E-07	3.0000E-03
71 IDDBSDD1TM	252.749	125	1.7840E-07	3.0000E-04

72	IDBBSDK1TM	252.749	125	1.7840E-07	3.0000E-04
73	IDBBSDS1TM	252.749	125	1.7840E-07	3.0000E-04
74	IRAEPI21ASAX	243.079	62	1.7158E-07	5.8300E-05
75	IDBFDO13RQ	240.166	10	1.6952E-07	1.2000E-05
76	IDBFDO14RQ	240.166	10	1.6952E-07	1.2000E-05
77	IDBBSDD1LF	239.506	7	1.6905E-07	4.8000E-06
78	IDBBSDK1LF	239.506	7	1.6905E-07	4.8000E-06
79	IDBBSDS1LF	239.506	7	1.6905E-07	4.8000E-06
80	CCX-PMDMOD4	233.539	133	1.6484E-07	4.9800E-06
81	PL5MOD11	231.311	73	1.6327E-07	2.0900E-03
82	PL50301ASA	229.951	47	1.6231E-07	1.1600E-03
83	PL50301BSA	229.951	47	1.6231E-07	1.1600E-03
84	ADN-MAN01	228.977	58	1.6162E-07	4.9300E-04
85	ED1MOD01	226.422	23	1.5982E-07	5.0400E-04
86	ED1MOD07	225.113	17	1.5889E-07	3.0500E-04
87	ED1MOD13	224.858	17	1.5873E-07	3.1700E-04
88	CCX-PL1MOD1	221.969	9	1.5668E-07	1.4100E-04
89	CCX-PL7MOD1	221.969	9	1.5668E-07	1.4100E-04
90	EC5EPMBG1SA	221.915	9	1.5664E-07	1.7100E-04
91	PL5XSD0ASA	221.013	7	1.5600E-07	8.0000E-05
92	CCX-PL103	220.912	7	1.5594E-07	9.6900E-05
93	CCX-PL703	220.912	7	1.5593E-07	9.6900E-05
94	CCX-IV-XR1	218.589	6	1.5429E-07	2.4000E-05
95	CCX-PMAMOD1	214.447	87	1.5137E-07	1.4100E-04
96	CCX-PL1MOD1-SW	202.330	4	1.4281E-07	1.1000E-05
97	CCX-PL7MOD1-SW	202.330	4	1.4281E-07	1.1000E-05
98	CCX-PMAD030	188.668	59	1.3317E-07	9.3900E-05
99	IDAMOD05	188.642	354	1.3315E-07	5.1600E-04
100	IWX-XMTRLW	188.065	2	1.3274E-07	9.2000E-09
101	IDAMOD04	182.887	340	1.2909E-07	3.1700E-04
102	IDBBSDD1LF	179.769	3	1.2689E-07	4.8000E-06
103	IDABSDS1TM	175.449	255	1.2384E-07	3.0000E-04
104	CCX-PMAMOD2X	174.264	22	1.2300E-07	8.5800E-05
105	CCX-INPUT-LOGICX	171.120	12	1.2078E-07	2.5900E-05
106	IDDFD019RQ	170.592	58	1.2041E-07	1.2000E-05
107	IDDFD020RQ	170.592	58	1.2041E-07	1.2000E-05
108	CCX-IN-LOJIC-SW	170.372	8	1.2026E-07	1.1000E-05
109	CCX-PMAMOD2-SW	170.372	8	1.2026E-07	1.1000E-05
110	CCX-PMDMOD1-SW	170.229	56	1.2016E-07	1.1000E-05
111	CCX-PMDMOD4-SW	170.229	56	1.2016E-07	1.1000E-05
112	PMAMOD11	163.156	296	1.1516E-07	2.0900E-03
113	PMAD0301ASA	157.806	218	1.1139E-07	1.1600E-03
114	PMAD0301BSA	157.806	218	1.1139E-07	1.1600E-03
115	IDDBSDD1LF	141.200	31	9.9656E-08	4.8000E-06
116	IDDBSDK1LF	141.200	31	9.9656E-08	4.8000E-06
117	IDBBSDD1LF	141.200	31	9.9656E-08	4.8000E-06
118	CCX-PMDEH0	140.624	29	9.9258E-08	4.0300E-06
119	ED3MOD07	113.390	26	8.0035E-08	3.0500E-04
120	MDAS	106.471	79	7.5152E-08	1.0000E-02
121	REC-MANDAS	103.528	36	7.3074E-08	1.1600E-02
122	PMAX500ASA	98.4303	28	6.9476E-08	8.0000E-05
123	ZOX-BL-ER	68.6988	1	4.8491E-08	1.3600E-06
124	ZOX-FL-GP	68.6027	1	4.8423E-08	1.3000E-06
125	PMAX500ASAX	55.1790	158	3.8948E-08	8.0000E-05
126	PMAMOD11X	52.2884	369	3.6907E-08	6.5300E-04
127	IWN-MAN00C	50.5432	23	3.5676E-08	5.0000E-02
128	PMAD0301ASAX	50.4695	176	3.5624E-08	1.6500E-04
129	PMAD0301BSAX	49.2743	157	3.4780E-08	1.6500E-04
130	CCX-BC-SA	47.7297	5	3.3690E-08	8.4000E-06
131	RHN-MAN04	47.0422	123	3.3204E-08	5.5000E-02
132	IEV-LOSPND	38.2953	40	2.7030E-08	1.7100E-02
133	IDABSDS1LF	37.7495	24	2.6645E-08	4.8000E-06
134	ZO1MOD01	36.7058	524	2.5909E-08	2.0200E-02
135	EC1CB100VO	36.0271	380	2.5429E-08	1.2300E-02
136	CCX-PMAMOD4	35.9097	41	2.5347E-08	4.9800E-05
137	CCX-PMAMOD4-SW	33.4596	12	2.3617E-08	1.1000E-05
138	CCX-PMAEH0X	33.2533	11	2.3472E-08	4.0300E-06
139	ZO1MOD04	29.4080	82	2.0757E-08	1.2500E-03
140	IDCBSDD1TM	23.3443	170	1.6477E-08	3.0000E-04
141	IDCBSDK1TM	23.3443	176	1.6477E-08	3.0000E-04
142	IDCBSDS1TM	23.3443	176	1.6477E-08	3.0000E-04
143	ZO2MOD01	22.5074	187	1.5887E-08	2.0200E-02
144	EC2CB200VO	22.4030	144	1.5813E-08	1.2300E-02
145	ED2MOD03	21.8941	68	1.5454E-08	2.7000E-03
146	IRAEPI21BSAX	21.7820	66	1.5375E-08	5.8300E-05
147	RHN-MAN05C	20.9545	27	1.4791E-08	1.5000E-01
148	ZO2MOD04	20.0297	44	1.4138E-08	1.2500E-03
149	CMX-VS-FA	19.5500	7	1.3799E-08	3.8400E-05
150	ED2MOD11	19.2711	20	1.3602E-08	3.1700E-04
151	RNBMOD07S	18.8062	146	1.3274E-08	1.5300E-02
152	EC1MOD01	18.5285	16	1.3078E-08	2.0200E-04

153	IDCFD007RQ	18.1144	18	1.2786E-08	1.2000E-05
154	IDCFD008RQ	18.1144	18	1.2786E-08	1.2000E-05
155	RNAMOD06S	17.0102	90	1.2007E-08	1.5300E-02
156	IDCBSD01LF	15.8928	12	1.1218E-08	4.8000E-06
157	IDCBSDK1LF	15.8928	12	1.1218E-08	4.8000E-06
158	IDCBSDS1LF	15.8928	12	1.1218E-08	4.8000E-06
159	CCX-AV-LA	14.4698	5	1.0213E-08	6.1000E-05
160	CMX-CV-GO	14.9484	4	1.0198E-08	5.1000E-05
161	EC2MOD01	14.1502	14	9.9878E-09	2.0200E-04
162	EC1REDG2GA	13.7424	57	9.7000E-09	4.3600E-03
163	SWAMOD07	13.6352	42	9.6243E-09	7.1200E-03
164	OTH-R1	13.3871	2292	9.4492E-09	4.2000E-01
165	ED3MOD03	13.3849	35	9.4476E-09	2.2020E-03
166	EC1BS001TM	13.1546	442	9.2851E-09	2.7000E-03
167	EC1BS012TM	13.1546	442	9.2851E-09	2.7000E-03
168	EC1BS121TM	13.1546	442	9.2851E-09	2.7000E-03
169	EC1MOD12	12.6318	66	8.9161E-09	4.8000E-05
170	EC1REDG1GA	12.4780	39	8.8075E-09	4.3600E-03
171	SWBMOD02	11.7533	150	8.2960E-09	2.4400E-02
172	CCBMOD01S	11.5046	91	8.1204E-09	1.0400E-02
173	RNAEPRNPSA	10.8576	9	7.6638E-09	1.7100E-04
174	RNBEPRNPSA	10.8576	9	7.6638E-09	1.7100E-04
175	PL4MOD11	10.6835	43	7.5409E-09	2.0900E-03
176	CCAMOD02	10.5359	40	7.4367E-09	7.1000E-03
177	ZO1MOD03	10.4226	8	7.3567E-09	1.0000E-04
178	IDAMOD06	10.2744	48	7.2521E-09	4.3200E-05
179	PL1MOD11	9.69467	36	6.8429E-09	2.0900E-03
180	PL7MOD11	9.69467	36	6.8429E-09	2.0900E-03
181	PL40301ASA	9.53225	29	6.7283E-09	1.1600E-03
182	SWBMOD09P	9.24056	31	6.5224E-09	1.8500E-03
183	PL40301BSA	9.21587	26	6.5050E-09	1.1600E-03
184	SW7EPSPBPASA	9.18106	7	6.4804E-09	1.7100E-04
185	ED3MOD01	9.13197	10	6.4457E-09	5.0400E-04
186	PL10301ASA	8.86969	25	6.2606E-09	1.1600E-03
187	PL70301ASA	8.86969	25	6.2606E-09	1.1600E-03
188	PL10301BSA	8.79019	24	6.2045E-09	1.1600E-03
189	PL70301BSA	8.79019	24	6.2045E-09	1.1600E-03
190	EC1MOD121	8.56656	24	6.0466E-09	1.6800E-05
191	SWAMOD09P	8.28448	22	5.8475E-09	1.8500E-03
192	PMAMOD12X	7.43500	123	5.2479E-09	6.5300E-04
193	IDAMOD08	7.35112	96	5.1887E-09	3.1700E-04
194	PMA0302ASAX	6.34967	59	4.4819E-09	1.6500E-04
195	CU1EPSPBPASA	6.34204	6	4.4765E-09	1.7100E-04
196	ZO2MOD03	6.09597	5	4.3028E-09	1.0000E-04
197	EC1BS001LF	5.40683	7	3.8164E-09	4.8000E-06
198	CC1EPSPBPBSA	5.29270	5	3.7358E-09	1.7100E-04
199	SW7EPSPBPBSA	5.29270	5	3.7358E-09	1.7100E-04
200	PMA0302BSAX	5.15446	40	3.12E-09	1.6500E-04
201	SW7EPCTFASA	4.80435	4	3.12E-09	1.7100E-04
202	SW7EPCTFBASA	4.80435	4	3.3911E-09	1.7100E-04
203	EC2MOD22	4.70865	17	3.3236E-09	4.8000E-05
204	IWACV122AO	4.49334	126	3.1716E-09	8.7600E-03
205	IWACV123AO	4.49334	126	3.1716E-09	8.7600E-03
206	IWACV124AO	4.49334	126	3.1716E-09	8.7600E-03
207	IWACV125AO	4.49334	126	3.1716E-09	8.7600E-03
208	PL1XS000ASA	3.83365	3	2.7060E-09	8.0000E-05
209	PL4XS000ASA	3.83365	3	2.7060E-09	8.0000E-05
210	PL7XS000ASA	3.83365	3	2.7060E-09	8.0000E-05
211	SUC-R1S	3.57392	158	2.5226E-09	5.8000E-01
212	RHN-MAN03	3.14175	36	2.2176E-09	2.2600E-03
213	EC1MOD13	2.83764	2	2.0029E-09	4.8000E-05
214	EC2MOD23	2.83764	2	2.0029E-09	4.8000E-05
215	ED3BSDS11M	2.30414	1	1.6264E-09	3.0000E-04
216	EC2BS002TM	2.07127	187	1.4620E-09	2.7000E-03
217	EC2BS022TM	2.07127	187	1.4620E-09	2.7000E-03
218	EC2BS221TM	2.07127	187	1.4620E-09	2.7000E-03
219	PMDDMOD11	1.78020	206	1.2565E-09	2.0900E-03
220	PL4MOD12	1.76608	16	1.2466E-09	2.0900E-03
221	CCB-MAN01	1.45624	6	1.0279E-09	1.0700E-03
222	REC-MANDASC	1.42628	46	1.0067E-09	5.0600E-01
223	PMD0301ASA	1.41966	134	1.0021E-09	1.1600E-03
224	PMAMOD21X	1.39677	14	9.8590E-10	1.1600E-03
225	IDDMOD32	1.37895	58	9.7333E-10	3.1700E-04
226	PMD0301BSA	1.28409	117	9.0636E-10	1.1600E-03
227	PMDXS00ASA	1.23856	32	8.7423E-10	8.0000E-05
228	PMDEHOA1FA	1.08718	28	7.6738E-10	8.0000E-05
229	SWB-MAN02	1.05726	4	7.4626E-10	1.6000E-03
230	PL40302ASA	1.05195	7	7.4251E-10	1.6000E-03
231	PMDDMOD41	1.03053	67	7.2739E-10	6.3500E-04
232	CCX-KMTR	9.74065	3	6.8754E-10	2.0100E-04
233	IDDMOD33	9.10351	45	6.4256E-10	5.1600E-04

234	ADX-MV-00	760162	4	5.3656E-10	1.1000E+03
235	Z01DG001TM	.741683	95	5.2351E-10	4.6000E-02
236	PL40302BSA	.735563	4	5.1919E-10	1.1600E-03
237	PL1MOD12	.718268	7	5.0698E-10	2.0900E-03
238	PL7MOD12	.718268	7	5.0698E-10	2.0900E-03
239	CCX-TRNSM	.728227	2	5.0698E-10	2.0100E-04
240	ZON-MAN01	.708737	7	5.0026E-10	2.6700E-03
241	Z02DG002TM	.671832	42	4.7421E-10	4.6000E-02
242	PRN-MAN01	.647017	4	4.5669E-10	4.0800E-04
243	IWBCV122AO	.623223	184	4.3990E-10	8.7600E-03
244	IWBCV123AO	.623223	184	4.3990E-10	8.7600E-03
245	IWBCV124AO	.623223	184	4.3990E-10	8.7600E-03
246	IWBCV125AO	.623223	184	4.3990E-10	8.7600E-03
247	PMDMOD12	.611475	86	4.3160E-10	2.0900E-03
248	OTH-R2	.558414	29	3.9415E-10	2.4000E-01
249	IDDMOD38	.527773	31	3.7252E-10	3.1700E-04
250	PRAAV108LA	.446996	11	3.1551E-10	1.0900E-03
251	PRBAV108LA	.446996	11	3.1551E-10	1.0900E-03
252	PRAVV108TM	.446167	9	3.1492E-10	5.0000E-04
253	PRBAV108TM	.446167	9	3.1492E-10	5.0000E-04
254	PMD0302ASA	.416742	46	2.9415E-10	1.1600E-03
255	PLMMOD41	.399041	2	2.8166E-10	6.3500E-04
256	IDDMOD34	.396850	10	2.8011E-10	4.3200E-05
257	PL1MOD51	.395220	2	2.7896E-10	8.7400E-04
258	PL10302ASA	.389384	3	2.7484E-10	1.1600E-03
259	PL70302ASA	.389384	3	2.7484E-10	1.1600E-03
260	IDDMOD21	.368579	6	2.6016E-10	1.9200E-04
261	ZANMOD01	.337023	8	2.3788E-10	8.4000E-05
262	SWNTP001RI	.336002	5	2.3716E-10	5.2300E-03
263	PL10302BSA	.309882	2	2.1873E-10	1.1600E-03
264	PL70302BSA	.309882	2	2.1873E-10	1.1600E-03
265	PMDEH0A2SA	.308658	10	2.1786E-10	8.0000E-05
266	PMAMOD41	.304679	34	2.1491E-10	6.3500E-04
267	PMD0302BSA	.281169	29	1.9846E-10	1.1600E-03
268	DG2-LOGIC	.272066	1	1.9204E-10	5.0000E-03
269	CCNTF101RI	.229047	5	1.6167E-10	5.2300E-03
270	ED2MOD01	.183101	1	1.2924E-10	5.0400E-04
271	PMAEH0A1SAX	.182835	6	1.2905E-10	8.0000E-05
272	PMAMOD22X	.173360	2	1.2237E-10	1.1600E-03
273	SUC-R2S	.154648	9	1.0916E-10	7.6000E-01
274	IDAMOD02	.142167	31	1.0035E-10	2.7000E-03
275	IDAMOD03	.142167	31	1.0035E-10	2.7000E-03
276	AD2MOD01	.121602	21	8.5832E-11	5.5400E-02
277	AD2MOD02	.121602	21	8.5832E-11	5.5400E-02
278	AD3MOD03	.121602	21	8.5832E-11	5.5400E-02
279	AD3MOD04	.121602	21	8.5832E-11	5.5400E-02
280	IDABSSD1TM	.117932	3	8.3242E-11	3.0000E-04
281	IDABSDK1TM	.117932	3	8.3242E-11	3.0000E-04
282	EC2MOD221	.112348	3	7.9300E-11	1.6800E-05
283	DAS	.103412	4	7.2993E-11	1.0000E-02
284	PMDMOD42	9.035359E-02	11	6.3775E-11	6.3500E-04
285	RHN-MAN04-SUCC	8.857936E-02	399	6.2522E-11	9.4500E-01
286	RC1TL195UF	8.846562E-02	3	6.2443E-11	5.2300E-03
287	RC1OR195SP	8.841559E-02	4	6.2408E-11	7.2200E-03
288	DG1-LOGIC	2.538494E-02	1	1.7918E-11	5.0000E-03
289	PMAMOD42	2.153634E-02	4	1.5201E-11	6.3500E-04
290	IDAMOD07	3.308737E-03	15	2.3354E-12	2.1900E-02
291	PRCEP108SA	1.839339E-03	1	1.2983E-12	1.7100E-04
292	PRDEP108SA	1.839339E-03	1	1.2983E-12	1.7100E-04
293	IDDMOD22	5.228856E-04	3	3.6908E-13	2.7000E-03
294	IDDMOD23	5.228856E-04	3	3.6908E-13	2.7000E-03
295	IDDMOD35	3.652958E-04	4	2.5784E-13	2.1900E-02

Table 54B-5

CASE 2 LIST OF TOP 200 DOMINANT CUTSETS

Reduced Sum of Cutsets: 4.8040E-07

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB.	IDENTIFIER	
1	6.96E-08	14.49	LOSS OF OFFSITE COMMON CAUSE	POWER INITIATING EVENT OCCURS FAILURE OF THE BATTERIES	WITH RCS DRAINED IDSA-DB-1A/1B	1.48E-03 4.70E-05	IEV-LOSPD CCX-BY-PN
2	4.44E-08	9.24	LOSS OF OFFSITE DUE TO CCF OF	POWER INITIATING EVENT OCCURS THE SQUIB VALVES TO OPERATE	WITH RCS DRAINED	1.48E-03 3.00E-05	IEV-LOSPD ADX-EV-SA
3	3.85E-08	8.01	LOSS OF OFFSITE CCF OF IRWST INJ	POWER INITIATING EVENT OCCURS MOVs 121A, 121B, & RNS V023	WITH RCS DRAINED	1.48E-03 2.60E-05	IEV-LOSPD IWX-MV-G01
4	3.55E-08	7.39	LOSS OF OFFSITE COMMON CAUSE	POWER INITIATING EVENT OCCURS FAILURE OF HE INVERTER	WITH RCS DRAINED	1.48E-03 2.40E-05	IEV-LOSPD CCX-IV-XR
5	2.83E-08	5.89	LOSS OF CCS/SWS COMMON CAUSE	WITH RCS DRAINED INITIATING EVENT OCCURS FAILURE OF THE BATTERIES	IDSA-DB-1A/1B	6.02E-04 4.70E-05	IEV-COMD CCX-BY-PN
6	1.81E-08	3.77	LOSS OF CCS/SWS DUE TO CCF OF	WITH RCS DRAINED INITIATING EVENT OCCURS THE SQUIB VALVES TO OPERATE		6.02E-04 3.00E-05	IEV-COMD ADX-EV-SA
7	1.78E-08	3.71	LOSS OF OFFSITE CCF OF STRAINERS	POWER INITIATING EVENT OCCURS IN IRWST TANK	WITH RCS DRAINED	1.48E-03 1.20E-05	IEV-LOSPD IWX-FL-GP
8	1.57E-08	3.27	LOSS OF CCS/SWS CCF OF IRWST INJ	WITH RCS DRAINED INITIATING EVENT OCCURS MOVs 121A, 121B, & RNS V023		6.02E-04 2.60E-05	IEV-COMD IWX-MV-G01
9	1.44E-08	3.00	LOSS OF CCS/SWS COMMON CAUSE	WITH RCS DRAINED INITIATING EVENT OCCURS FAILURE OF THE INVERTER		6.02E-04 2.40E-05	IEV-COMD CCX-IV-XR
10	1.28E-08	2.66	LOSS OF OFFSITE CCF OF THE POWER	POWER INITIATING EVENT OCCURS INTERFACE OUTPUT BOARDS IN PMS	WITH RCS DRAINED	1.48E-03 8.62E-06	IEV-LOSPD CCX-EP-SAM
11	7.22E-09	1.50	LOSS OF CCS/SWS CCF OF STRAINERS	WITH RCS DRAINED INITIATING EVENT OCCURS IN IRWST TANK		6.02E-04 1.20E-05	IEV-COMD IWX-FL-GP
12	6.84E-09	1.42	LOSS OF OFFSITE FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS PMS OUTPUT LOGIC I/Os FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED	1.48E-03 2.09E-03 2.21E-03	IEV-LOSPD PMAMOD11 RN23MOD55
13	6.46E-09	1.34	LOSS OF OFFSITE FAILURE OF PMODMOD11	POWER INITIATING EVENT OCCURS PMS OUTPUT LOGIC I/Os	WITH RCS DRAINED	1.48E-03 2.09E-03 2.09E-03	IEV-LOSPD PMAMOD11 PMEMOD11
14	6.02E-09	1.25	LOSS OF OFFSITE FAILURE OF INDICATION	POWER INITIATING EVENT OCCURS PMS OUTPUT LOGIC I/Os FAILURE	WITH RCS DRAINED	1.48E-03 4.07E-03 1.00E-03	IEV-LOSPD PMAMOD21 ALL-IND-FAIL
15	5.37E-09	1.12	LOSS OF OFFSITE CCF OF ORIFICES	POWER INITIATING EVENT OCCURS	WITH RCS DRAINED	1.48E-03 3.63E-06	IEV-LOSPD CCX-BY-SPX
16	5.19E-09	1.08	LOSS OF CCS/SWS CCF OF THE POWER	WITH RCS DRAINED INITIATING EVENT OCCURS INTERFACE OUTPUT BOARDS IN PMS		6.02E-04 8.62E-06	IEV-COMD CCX-EP-SAM
17	4.95E-09	1.03	LOSS OF OFFSITE FAILURE OF OPERATOR FAILS	POWER INITIATING EVENT OCCURS PMS OUTPUT LOGIC I/Os TO RECOGNIZE NEED AND TO OPEN RNG MOV V023	WITH RCS DRAINED	1.48E-03 2.09E-03 1.60E-03	IEV-LOSPD PMAMOD11 RRN-MAN05

Table 54B-5

CASE 2 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER
18	4.20E-09	.87	OVERDRAINING OF RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT RHN-MAND4-SUCC INDICATION FAILURE		4.44E-06 9.45E-01 1.00E-03	IEV-RCS0D RHN-MAND4-SUCC ALL-IND-FAIL
19	3.79E-09	.81	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED CCF OF PRESSURE TRANSMITTERS		1.48E-03 2.63E-06	IEV-LOSPD CCK-KMTRA
20	3.83E-09	.80	LOSS OF RNS WITH RCS DRAINED INITIATING EVENT OCCURS COMMON CAUSE FAILURE OF THE BATTERIES IDSA-DB-1A/1B		8.15E-05 4.70E-05	IEV-RNSD CCK-BY-PN
21	3.79E-09	.79	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN		1.48E-03 1.16E-03 2.21E-03	IEV-LOSPD PMA0301ASA RN23M005S
22	3.79E-09	.79	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN		1.48E-03 1.16E-03 2.21E-03	IEV-LOSPD PMA0301BSA RN23M005S
23	3.59E-09	.75	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING PMDMOD11		1.48E-03 1.16E-03 2.09E-03	IEV-LOSPD PMA0301BSA PMDMOD11
24	3.59E-09	.75	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED FAILURE OF PMS OUTPUT LOGIC I/Os PMD0301ASA		1.48E-03 2.09E-03 1.16E-03	IEV-LOSPD PMAMOD11 PMD0301ASA
25	3.59E-09	.75	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED FAILURE OF PMS OUTPUT LOGIC I/Os PMD0301BSA		1.48E-03 2.09E-03 1.16E-03	IEV-LOSPD PMAMOD11 PMD0301BSA
26	3.59E-09	.75	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING PMDMOD11		1.48E-03 1.16E-03 2.09E-03	IEV-LOSPD PMA0301ASA PMDMOD11
27	3.09E-09	.64	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED FAILURE OF PMS OUTPUT LOGIC I/Os INDICATION FAILURE		1.48E-03 2.09E-03 1.00E-03	IEV-LOSPD PMAMOD11 ALL-IND-FAIL
28	2.75E-09	.57	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING OPERATOR FAILS TO RECOGNIZE NEED AND TO OPEN RNS MOV V023		1.48E-03 1.16E-03 1.60E-03	IEV-LOSPD PMA0301BSA RHN-MAN05
29	2.75E-09	.57	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING OPERATOR FAILS TO RECOGNIZE NEED AND TO OPEN RNS MOV V023		1.48E-03 1.16E-03 1.60E-03	IEV-LOSPD PMA0301ASA RHN-MAN05
30	2.45E-09	.51	LOSS OF RNS WITH RCS DRAINED INITIATING EVENT OCCURS DUE TO CCF OF THE SQUIB VALVES TO OPERATE		8.15E-05 3.00E-05	IEV-RNSD ADX-EV-SA
31	2.19E-09	.46	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS CCF OF ORIFICES		6.02E-04 3.63E-06	IEV-COMD CCK-ORY-SPX
32	2.12E-09	.44	LOSS OF RNS WITH RCS DRAINED INITIATING EVENT OCCURS CCF OF IEWST INJ MOVs 121A, 121B, & RNS V023		8.15E-05 2.60E-05	IEV-RNSD IWX-MV-G01
33	1.99E-09	.41	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING PMD0301ASA		1.48E-03 1.16E-03 1.16E-03	IEV-LOSPD PMA0301ASA PMD0301ASA

Table 54B-5

CASE 2 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET_PROB	PERCENT	BASIC EVENT NAME		EVENT_PROB	IDENTIFIER
34	1.99E-09	.41	LOSS OF OFFSITE FAILURE UPON PMD0301BSA	POWER INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING	WITH RCS DRAINED	1.48E-03 1.16E-03 1.16E-03
35	1.99E-09	.41	LOSS OF OFFSITE FAILURE UPON PMD0301ASA	POWER INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING	WITH RCS DRAINED	1.48E-03 1.16E-03 1.16E-03
36	1.99E-09	.41	LOSS OF OFFSITE FAILURE UPON PMD0301BSA	POWER INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING	WITH RCS DRAINED	1.48E-03 1.16E-03 1.16E-03
37	1.96E-09	.41	LOSS OF OFFSITE FAILURE OF PMS OUTPUT PMDMOD41	POWER INITIATING EVENT OCCURS LOGIC I/Os	WITH RCS DRAINED	1.48E-03 2.09E-03 6.35E-04
38	1.96E-09	.41	LOSS OF RNS WITH RCS DRAINED COMMON CAUSE	INITIATING EVENT OCCURS FAILURE OF THE INVERTER		8.15E-05 2.40E-05
39	1.83E-09	.38	OVERDRAINING OF OPERATOR FAILS INN-MAN00C COND. PROB. OF	RCS DURING DRAIN DOWN TO MID-LOOP TO ISOLATE PNS PIPE RUPTURE	INITIATING EVENT	4.44E-06 5.50E-02 5.00E-02 1.50E-01
40	1.78E-09	.37	LOSS OF OFFSITE SOFTWARE CCF	POWER INITIATING EVENT OCCURS OF ALL CARDS	WITH RCS DRAINED	1.48E-03 1.20E-06
41	1.72E-09	.36	LOSS OF OFFSITE FAILURE UPON INDICATION	POWER INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING FAILURE	WITH RCS DRAINED	1.48E-03 1.16E-03 1.00E-03
42	1.72E-09	.36	LOSS OF OFFSITE FAILURE UPON INDICATION	POWER INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING FAILURE	WITH RCS DRAINED	1.48E-03 1.16E-03 1.00E-03
43	1.692E-09	.35	LOSS OF OFFSITE FAILURE OF INV. MECHANICAL	POWER INITIATING EVENT OCCURS STATIC SWITCH AND ASSOC. FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED BREAKERS FAIL-TO-OPEN	1.48E-03 5.16E-04 2.21E-03
44	1.60E-09	.33	LOSS OF OFFSITE FAILURE OF PMS OUTPUT FAILURE OF INV.	POWER INITIATING EVENT OCCURS LOGIC I/Os STATIC SWITCH AND ASSOC.	WITH RCS DRAINED BREAKERS	1.48E-03 2.09E-03 5.16E-04
45	1.60E-09	.33	LOSS OF OFFSITE FAILURE OF INV. PMDMOD11	POWER INITIATING EVENT OCCURS STATIC SWITCH AND ASSOC.	WITH RCS DRAINED BREAKERS	1.48E-03 5.16E-04 2.09E-03
46	1.58E-09	.33	LOSS OF CCS/SWS OCF OF PRESSURE	WITH RCS DRAINED INITIATING EVENT OCCURS TRANSMITTERS		6.02E-04 2.63E-06
47	1.22E-09	.25	LOSS OF OFFSITE FAILURE OF INV. OPERATOR FAILS	POWER INITIATING EVENT OCCURS STATIC SWITCH AND ASSOC. TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED BREAKERS	1.48E-03 5.16E-04 1.60E-03
48	1.09E-09	.23	LOSS OF OFFSITE FAILURE UPON PMDMOD41	POWER INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING	WITH RCS DRAINED	1.48E-03 1.16E-03 6.35E-04

Table 54B-5

CASE 2 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB.	IDENTIFIER
49	1.09E-09	.23	LOSS OF OFFSITE FAILURE UPON PMDMOD41	POWER INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING	WITH RCS DRAINED 1.48E-03 1.16E-03 6.35E-04	IEV-LOSPD PMA0301ASA PMODMOD41
50	1.07E-09	.22	LOSS OF OFFSITE MECHANICAL IRWST DISCHARGE	POWER INITIATING EVENT OCCURS FAILURE CAUSES MOV 121A TO LINE "B" STRAINER	WITH RCS DRAINED FAIL-TO-OPEN PLUGGED 1.48E-03 3.00E-03 2.40E-04	IEV-LOSPD IRWMOD05S TMB-PLUG
51	1.04E-09	.22	LOSS OF OFFSITE FAILURE OF OPERATOR FAILS COND. PROB. OF RHN-MAN05 (OP)	POWER INITIATING EVENT OCCURS PMS OUTPUT LOGIC I/Os TO OPEN TWO IRWST MOVs FAILS TO OPEN	WITH RCS DRAINED 1.48E-03 4.07E-03 1.15E-03 1.50E-03	IEV-LOSPD PMAMOD21 IRN-MAN00 RHN-MAN05C
52	1.04E-09	.22	LOSS OF OFFSITE LOSS OF DIST. MECHANICAL	POWER INITIATING EVENT OCCURS PANEL OR BREAKER A07 SPURIOUSLY FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED OPENS FAIL-TO-OPEN 1.48E-03 3.17E-04 2.21E-03	IEV-LOSPD IDAMOD04 RN23MOD5S
53	9.81E-10	.20	LOSS OF OFFSITE BUS UNAVAILABLE MECHANICAL	POWER INITIATING EVENT OCCURS DUE TO TEST OR CORRECTIVE FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED MAINTENANCE FAIL-TO-OPEN 1.48E-03 3.00E-04 2.21E-03	IEV-LOSPD IDABSDS1TM RN23MOD5S
54	9.81E-10	.20	LOSS OF OFFSITE LOSS OF DIST. PMDMOD11	POWER INITIATING EVENT OCCURS PANEL OR BREAKER A07 SPURIOUSLY	WITH RCS DRAINED OPENS 1.48E-03 3.17E-04 2.09E-03	IEV-LOSPD IDAMOD04 PMODMOD11
55	9.81E-10	.20	LOSS OF OFFSITE FAILURE OF LOSS OF DIST.	POWER INITIATING EVENT OCCURS PMS OUTPUT LOGIC I/Os PANEL OR BREAKER A28 SPURIOUSLY	WITH RCS DRAINED 1.48E-03 2.09E-03 3.17E-04	IEV-LOSPD PMAMOD11 IDOMOD032
56	9.78E-10	.20	LOSS OF RNS WITH RCS DRAINED CCF OF STRAINERS IN IRWST TANK	INITIATING EVNT OCCURS	8.15E-05 1.20E-05	IEV-RNSD INX-FL-GP
57	9.28E-10	.19	LOSS OF OFFSITE BUS UNAVAILABLE PMDMOD11	POWER INITIATING EVENT OCCURS DUE TO TEST OR CORRECTIVE	WITH RCS DRAINED MAINTENANCE 1.48E-03 3.00E-04 2.09E-03	IEV-LOSPD IDABSDS1TM PMODMOD11
58	9.28E-10	.19	LOSS OF OFFSITE FAILURE OF BUS UNAVAILABLE	POWER INITIATING EVENT OCCURS PMS OUTPUT LOGIC I/Os DUE TO TEST OR CORRECTIVE	WITH RCS DRAINED MAINTENANCE 1.48E-03 2.09E-03 3.00E-04	IEV-LOSPD PMAMOD11 IDDBSDS1TM
59	9.28E-10	.19	LOSS OF OFFSITE FAILURE OF BUS UNAVAILABLE	POWER INITIATING EVENT OCCURS PMS OUTPUT LOGIC I/Os DUE TO TEST OR CORRECTIVE	WITH RCS DRAINED MAINTENANCE 1.48E-03 2.09E-03 3.00E-04	IEV-LOSPD PMAMOD11 IDDBSDS1TM
60	9.28E-10	.19	LOSS OF OFFSITE FAILURE OF BUS UNAVAILABLE	POWER INITIATING EVENT OCCURS PMS OUTPUT LOGIC I/Os DUE TO TEST OR CORRECTIVE	WITH RCS DRAINED MAINTENANCE 1.48E-03 2.09E-03 3.00E-04	IEV-LOSPD PMAMOD11 IDDBSDS1TM
61	8.86E-10	.18	LOSS OF OFFSITE FAILURE OF INV. PMD0301BSA	POWER INITIATING EVENT OCCURS STATIC SWITCH AND ASSOC.	WITH RCS DRAINED BREAKERS 1.48E-03 5.16E-04 1.16E-03	IEV-LOSPD IDAMOD05 PMD0301BSA
62	8.86E-10	.18	LOSS OF OFFSITE FAILURE UPON FAILURE OF INV.	POWER INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING STATIC SWITCH AND ASSOC.	WITH RCS DRAINED BREAKERS 1.48E-03 1.16E-03 5.16E-04	IEV-LOSPD PMA0301ASA IDDMOD033

63
43

Table 54B-5

CASE 2 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	EVENT PROB.	IDENTIFIER
63	8.86E-10	.18	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING AND ASSOC.	1.48E-03	IEV-LOSPD PRM0301RGA TRN003033
64	8.86E-10	.18	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED FAILURE OF INV. STATIC SWITCH AND ASSOC.	1.48E-03	IEV-LOSPD IDM0005 PRM0321USA
65	8.69E-10	.18	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS FAILURE OF PCS OUTPUT LOGIC 1/0s MECHANICAL FAILURE CAUSES NOV 023 TO FAIL-TO-OPEN	6.02E-04 6.53E-04 2.21E-03	IEV-COCD PRM0011X TRN2300055
66	8.22E-10	.17	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS FAILURE OF PCS OUTPUT LOGIC 1/0s PHM00011	6.02E-04 6.53E-04 2.09E-03	IEV-COCD PRM0011X PHM0011
67	7.90E-10	.16	LOCAL RNS-V024 COMMON CAUSE OPENS "B" AND EVENT OCCURS FAILURE "C" HE BATTERIES WITH RCS FILLED TSEA DB-1A/1B	1.68E-05 4.70E-05	IEV-LCDC4AND CCK-BY-EP
68	7.64E-10	.16	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED FAILURE OF INV. STATIC SWITCH AND ASSOC. INDICATION FAILURE	1.48E-03	IEV-LOSPD IDM0005 ALL-IND-FAIL
69	7.51E-10	.16	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED LOSS OF DIST. PANEL OR BREAKER ACT SPURIOUSLY OPERATOR FAILS TO RECOGNIZE NEED AND TO OPEN RNS NOV V023	1.48E-03 3.17E-04 1.60E-03	IEV-LOSPD TRN0004 RBN-MAN05
70	7.42E-10	.15	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED FAILURE OF PCS OUTPUT LINE "B" INERT DISCHARGE PLUGGED	1.48E-03 2.09E-03 2.40E-04	IEV-LOSPD PRM0011X INB-PLUG
71	7.24E-10	.15	OVERTRAINING OF RBN-MAND4 STCC OPERATOR FAILS TO OPEN TWO INERT MOTS COND. PRIOR OF RBN-MAND5 TOP FAILS TO OPEN RNS NOV V023	4.44E-06 9.45E-01 1.15E-03 1.50E-01	IEV-COCD CCK-SPPW RBN-MAND4-STCC RBN-MAND5
72	7.22E-10	.15	LOSS OF CCS/SWS SOFTWARE CCF WITH RCS DRAINED INITIATING EVENT OCCURS OF ALL CARDS	6.02E-04 1.20E-06	IEV-COCD CCK-SPPW
73	7.10E-10	.15	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED BUS UNAVAILABLE DUE TO TEST OR CORRECTIVE OPERATOR FAILS TO RECOGNIZE NEED AND TO OPEN RNS NOV V023	1.48E-03 3.01E-04 1.60E-01	IEV-LOSPD TRN0017W RBN-MAN05
74	7.03E-10	.15	LOSS OF RNS WITH RCS DRAINED INITIATING EVENT OCCURS OCF OF THE POWER INTERFACE OUTPUT BOARDS IN PCS	8.15E-05 8.62E-06	IEV-RNSD CCK-EP-SAM
75	6.98E-10	.15	LOSS OF CCS/SWS PHM0011X INDICATION FAILURE WITH RCS DRAINED INITIATING EVENT OCCURS	6.02E-04 1.14E-03 1.00E-03	IEV-COCD PRM0011X ALL-IND-FAIL
76	6.86E-10	.14	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS FAILURE OF INV. STATIC SWITCH AND ASSOC. MECHANICAL FAILURE CAUSES NOV 023 TO FAIL-TO-OPEN	6.02E-04 5.16E-04 2.21E-03	IEV-COCD IDM0005 TRN2300055
77	6.49E-10	.14	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS FAILURE OF INV. STATIC SWITCH AND ASSOC. PHM00011	6.02E-04 5.16E-04 2.09E-03	IEV-COCD IDM0005 PHM0011

Table 54B-5

CASE 2 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET FROM	PERCENT	BASIC EVENT NAME	EVENT	PERCENT	IDENTIFIER
78	6.29E-10	.13	LOSS OF CCS/SWS WITH RCS TRAINED INITIATING EVENT OCCURS PMS OUTPUT DUE TO RECOGNIZE NEED AND TO OPEN RBS NOV 2023	6.02E-04	1EV-COVID	PMA0301BSA
79	5.44E-10	.11	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS PANEL OR BREAKER A07 SPORADICALLY	6.53E-04	1EV-COVID	PMA0301BSA
80	5.44E-10	.11	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS PANEL OR BREAKER A07 SPORADICALLY	1.69E-03	BUS-MARSH	PMA0301BSA
81	5.44E-10	.11	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING PANEL OR BREAKER A28 SPORADICALLY	1.48E-03	1EV-LOSPO	PMA0301BSA
82	5.44E-10	.11	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING PANEL OR BREAKER A28 SPORADICALLY	3.17E-03	1DDBSDS17W	PMA0301BSA
83	5.31E-10	.11	LOSS OF RBS-2024 COMMON CAUSE	1.48E-03	1EV-LOSPO	PMA0301BSA
84	5.29E-10	.11	LOSS OF OFFSITE FAILURE UPON FAILURE OF PMS OUTPUT LOGIC I/Os	3.17E-04	1EV-LOSPO	PMA0301BSA
85	5.15E-10	.11	LOSS OF OFFSITE FAILURE UPON BUS UNAVAILABLE	1.48E-03	1EV-LOSPO	PMA0301BSA
86	5.15E-10	.11	LOSS OF OFFSITE FAILURE UPON BUS UNAVAILABLE	3.00E-04	1DDBSDS17W	PMA0301BSA
87	5.15E-10	.11	LOSS OF OFFSITE FAILURE UPON BUS UNAVAILABLE	1.48E-03	1EV-LOSPO	PMA0301BSA
88	5.15E-10	.11	LOSS OF OFFSITE FAILURE UPON BUS UNAVAILABLE	3.00E-04	1DDBSDS17W	PMA0301BSA
89	5.15E-10	.11	LOSS OF OFFSITE FAILURE UPON BUS UNAVAILABLE	1.48E-03	1EV-LOSPO	PMA0301BSA
90	5.15E-10	.11	LOSS OF OFFSITE FAILURE UPON BUS UNAVAILABLE	3.00E-04	1DDBSDS17W	PMA0301BSA
91	5.15E-10	.11	LOSS OF OFFSITE FAILURE UPON BUS UNAVAILABLE	1.48E-03	1EV-LOSPO	PMA0301BSA
92	5.15E-10	.11	LOSS OF OFFSITE FAILURE UPON BUS UNAVAILABLE	3.00E-04	1DDBSDS17W	PMA0301BSA

Table 54B-5

CASE 2 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER	
93	5.04E-10	.10	LOCA/RNS-V024 CCF OF GRAVITY	OPENS INITIATING EVENT OCCURS INJECTION CHECK VALVES TO OPEN	WITH RCS FILLED 3.00E-05	IEV-LOCA24ND TWS-CV-AO	
94	4.97E-10	.10	LOSS OF CCS/SWS FAILURE OF INV. OPERATOR FAILS	WITH RCS DRAINED FAILURE OF INV. STATIC SWITCH AND ASSOC.	INITIATING EVENT OCCURS AND ASSOC. BREAKERS	6.02E-04 5.16E-04 1.60E-03	IEV-COND IDAMOD05 RBN-MAN05
95	4.85E-10	.10	LOSS OF OFFSITE FAILURE OF INV. PMDMOD41	POWER INITIATING EVENT OCCURS STATIC SWITCH AND ASSOC.	WITH RCS DRAINED BREAKERS	1.48E-03 5.16E-04 6.35E-04	IEV-LOSPO IDAMOD05 PMDMOD41
96	4.69E-10	.10	LOSS OF OFFSITE LOSS OF DIST INDICATION	POWER INITIATING EVENT OCCURS PANEL OR BREAKER A07 SPURIOUSLY FAILURE	WITH RCS DRAINED OPENS	1.48E-03 3.17E-04 1.00E-03	IEV-LOSPO IDAMOD04 ALL-IND-FAIL
97	4.56E-10	.09	LOSS OF CCS/SWS FAILURE OF PMD0301ASA	WITH RCS DRAINED PMS OUTPUT	INITIATING EVENT OCCURS LOGIC I/Os	6.02E-04 6.53E-04 1.16E-03	IEV-COND PMAMOD11X PMD0301ASA
98	4.56E-10	.09	LOSS OF CCS/SWS FAILURE OF PMD0301BSA	WITH RCS DRAINED PMS OUTPUT	INITIATING EVENT OCCURS LOGIC I/Os	6.02E-04 6.53E-04 1.16E-03	IEV-COND PMAMOD11X PMD0301BSA
99	4.44E-10	.09	LOSS OF OFFSITE BUS UNAVAILABLE INDICATION	POWER INITIATING EVENT OCCURS DUE TO TEST OR CORRECTIVE FAILURE	WITH RCS DRAINED MAINTENANCE	1.48E-03 3.00E-04 1.00E-03	IEV-LOSPO IDABSDSTM ALL-IND-FAIL
100	4.33E-10	.09	LOSS OF CCS/SWS MECHANICAL IRWST DISCHARGE	WITH RCS DRAINED FAILURE CAUSES MOV 121A TO LINE "B"	INITIATING EVENT OCCURS FAIL-TO-OPEN STRAINER	6.02E-04 3.00E-03 2.40E-04	IEV-COND IDMMOD05S TWS-PLUG
101	4.22E-10	.09	LOSS OF CCS/SWS LOSS OF DIST MECHANICAL	WITH RCS DRAINED PANEL OR BREAKER A07 SPURIOUSLY FAILURE CAUSES	INITIATING EVENT OCCURS OPENS MOV 023 TO	6.02E-04 3.17E-04 2.21E-03	IEV-COND IDAMOD04 RN23MOD05S
102	4.12E-10	.09	LOSS OF OFFSITE FAILURE UPON IRWST DISCHARGE	POWER INITIATING EVENT OCCURS DEMAND OF LOGIC LINE "B"	WITH RCS DRAINED GROUP PROCESSING STRAINER	1.48E-03 1.16E-03 2.40E-04	IEV-LOSPO PMAMOD11A TWS-PLUG
103	4.12E-10	.09	LOSS OF OFFSITE FAILURE UPON IRWST DISCHARGE	POWER INITIATING EVENT OCCURS DEMAND OF LOGIC LINE "B"	WITH RCS DRAINED GROUP PROCESSING STRAINER	1.48E-03 1.16E-03 2.40E-04	IEV-LOSPO PMAMOD11A TWS-PLUG
104	4.03E-10	.08	LOCA/RNS-V024 COMMON CAUSE	OPENS INITIATING EVENT OCCURS FAILURE OF THE INVERTER	WITH RCS FILLED	1.68E-05 2.40E-05	IEV-LOCA24ND CX-IV-XR
105	3.99E-10	.08	LOSS OF CCS/SWS BUS UNAVAILABLE MECHANICAL	WITH RCS DRAINED INIT. "T" AS EVENT DUE TO TEST OR CORRECTIVE FAILURE CAUSES	OCCURS MAINTENANCE MOV 023 TO	6.02E-04 3.00E-04 2.21E-03	IEV-COND IDABSDSTM RN23MOD05S
106	3.99E-10	.08	LOSS OF CCS/SWS LOSS OF DIST PMDMOD11	WITH RCS DRAINED INITIATING EVENT OCCURS PANEL OR BREAKER A07 SPURIOUSLY	OPENS	6.02E-04 3.17E-04 2.09E-03	IEV-COND IDAMOD04 PMDMOD11
107	3.94E-10	.08	LOSS OF OFFSITE FAILURE OF INV. FAILURE OF INV.	POWER INITIATING EVENT OCCURS STATIC SWITCH AND ASSOC. STATIC SWITCH AND ASSOC.	WITH RCS DRAINED BREAKERS BREAKERS	1.48E-03 5.16E-04 5.16E-04	IEV-LOSPO IDAMOD05 IDOMOD13

Table 54B-5

CASE 2 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER
108	3.93E-10	.08	1 OF CCS/SWS FAILURE OF INDICATION	WITH RCS DRAINED INITIATING EVENT OCCURS PMS OUTPUT LOGIC 1/08 FAILURE	6.02E-04 6.53E-04 1.00E-03	IEV-COMD PMAMOD11X ALL-IND-FAIL
109	3.77E-10	.08	LOSS OF CCS/SWS BUS UNAVAILABLE PMEMOD11	WITH RCS DRAINED INITIATING EVENT OCCURS DUE TO TEST OR CORRECTIVE MAINTENANCE	6.02E-04 3.00E-04 2.09E-03	IEV-COMD IDABSDS1TM PMEMOD11
110	3.60E-10	.07	LOSS OF CCS/SWS FAILURE OF INV., STATIC SWITCH PMDD0301BSA	WITH RCS DRAINED INITIATING EVENT OCCURS STATIC SWITCH AND ASSOC. BREAKERS	6.02E-04 5.16E-04 1.16E-03	IEV-COMD IDAMOD05 PMDD0301BSA
111	3.60E-10	.07	LOSS OF CCS/SWS FAILURE OF INV., STATIC SWITCH PMDD0301ASA	WITH RCS DRAINED INITIATING EVENT OCCURS STATIC SWITCH AND ASSOC. BREAKERS	6.02E-04 5.16E-04 1.16E-03	IEV-COMD IDAMOD05 PMDD0301ASA
112	3.39E-10	.07	LOCA/RNS-V024 DUE TO CCF OF	OPENS INITIATING EVENT OCCURS THE SQUIB VALVES TO OPERATE	1.13E-05 3.00E-05	IEV-LOCA24D ADK-BV-SA
113	3.11E-10	.06	LOSS OF CCS/SWS FAILURE OF INV., STATIC SWITCH INDICATION	WITH RCS DRAINED INITIATING EVENT OCCURS STATIC SWITCH AND ASSOC. BREAKERS FAILURE	6.02E-04 5.16E-04 1.00E-03	IEV-COMD IDAMOD05 ALL-IND-FAIL
114	3.05E-10	.06	LOSS OF CCS/SWS LOSS OF DIST. OPERATOR FAILS	WITH RCS DRAINED INITIATING EVENT OCCURS LOSS OF DIST. PANEL OR BREAKER A07 SPURIOUSLY OPENS TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	6.02E-04 3.17E-04 1.60E-03	IEV-COMD IDAMOD04 RBN-MAN05
115	2.98E-10	.06	LOSS OF OFFSITE LOSS OF DIST. PMEMOD41	POWER INITIATING EVENT OCCURS PANEL OR BREAKER A07 SPURIOUSLY OPENS	1.48E-03 3.17E-04 6.35E-04	IEV-LOSED IDAMOD04 PMEMOD41
116	2.96E-10	.06	LOSS OF RNS WITH RCS DRAINED CCF OF ORIFICES	INITIATING EVENT OCCURS	8.15E-05 3.63E-06	IEV-RNSD CCX-ORY-SPK
117	2.94E-10	.06	LOCA/RNS-V024 CCF OF IRWST INJ MOVs 121A, 121B, & RNS V023	OPENS INITIATING EVENT OCCURS WITH RCS DRAINED	1.13E-05 2.60E-05	IEV-LOCA24D IDK-MV-G01
118	2.94E-10	.06	LOSS OF OFFSITE FAILURE UPON FAILURE OF	POWER INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING OUTPUT DRIVER	1.48E-03 3.16E-03 1.71E-04	IEV-LOSPO PMA0301ASA RNDEP023SA
119	2.94E-10	.06	LOSS OF OFFSITE FAILURE UPON FAILURE OF	POWER INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING OUTPUT DRIVER	1.48E-03 3.16E-03 1.71E-04	IEV-LOSPO PMA0301BSA RNDEP023SA
120	2.89E-10	.06	LOSS OF CCS/SWS BUS UNAVAILABLE OPERATOR FAILS	WITH RCS DRAINED INITIATING EVENT OCCURS DUE TO TEST OR CORRECTIVE MAINTENANCE TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	6.02E-04 3.00E-04 1.60E-03	IEV-COMD IDABSDS1TM RBN-MAN05
121	2.82E-10	.06	LOSS OF OFFSITE BUS UNAVAILABLE PMEMOD41	POWER INITIATING EVENT OCCURS DUE TO TEST OR CORRECTIVE MAINTENANCE	1.48E-03 3.00E-04 6.35E-04	IEV-LOSPO IDABSDS1TM PMEMOD41
122	2.71E-10	.06	LOCA/RNS-V024 COMMON CAUSE	OPENS INITIATING EVENT OCCURS FAILURE OF THE INVERTER	1.13E-05 2.40E-05	IEV-LOCA24D CCR-IV-XR

Table 54B-5

CASE 2 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME			EVENT PROB	IDENTIFIER
123	2.62E-10	.05	LOSS OF OFFSITE FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS MIMIC BUS FAILURE CAUS. J MOV 023 TO	WITH RCS DRAINED SELECTOR BOARD FAIL-TO-OPEN	1.48E-03 8.00E-05 2.21E-03	IEV-LOSPD PMAKS00ASA RN23M00SS
124	2.50E-10	.05	LOSS OF CCS/SWS FAILURE OF PMDMOD41	WITH RCS DRAINED PMS OUTPUT	INITIATING EVENT OCCURS LOGIC I/Os	6.02E-04 6.53E-04 6.35E-04	IEV-CWCD PMA0011X PMOD041
125	2.47E-10	.05	LOSS OF OFFSITE FAILURE OF PMDMOD11	POWER INITIATING EVENT OCCURS MIMIC BUS	WITH RCS DRAINED SELECTOR BOARD	1.48E-03 8.00E-05 2.09E-03	IEV-LOSPD PMAKS00ASA PMOD011
126	2.47E-10	.05	LOSS OF OFFSITE FAILURE OF PMDKS00ASA	POWER INITIATING EVENT OCCURS PMS OUTPUT	WITH RCS DRAINED LOGIC I/Os	1.48E-03 2.09E-03 8.00E-05	IEV-LOSPD PMA0011X PMOKS00ASA
127	2.44E-10	.05	OVERDRAINING OF OPERATOR FAILS INDICATION	RCS DURING DRAIN DOWN TO MID-LOOP TO ISOLATE FAILURE	INITIATING EVENT RNS PIPE RUPTURE	4.44E-06 5.50E-02 1.00E-03	IEV-RCSGD RNIN-MAND4 ALL-IND-FAIL
128	2.42E-10	.05	LOSS OF OFFSITE FAILURE OF INV., LOSS OF DIST.	POWER INITIATING EVENT OCCURS STATIC SWITCH AND ASSOC. PANEL OR BREAKER A28 SPURIOUSLY	WITH RCS DRAINED BREAKERS OPENS	1.48E-03 5.16E-04 3.17E-04	IEV-LOSPD IDAM0005 IDDM0032
129	2.42E-10	.05	LOSS OF OFFSITE LOSS OF DIST. FAILURE OF INV.,	POWER INITIATING EVENT OCCURS PANEL OR BREAKER A07 SPURIOUSLY STATIC SWITCH AND ASSOC.	WITH RCS DRAINED OPENS BREAKERS	1.48E-03 -.7E-04 5.16E-04	IEV-LOSPD IDAM0004 IDDM0033
130	2.29E-10	.05	LOSS OF OFFSITE BUS UNAVAILABLE FAILURE OF INV.,	POWER INITIATING EVENT OCCURS DUE TO TEST OR STATIC SWITCH AND ASSOC.	WITH RCS DRAINED MAINTENANCE BREAKERS	1.48E-03 3.00E-04 5.16E-04	IEV-LOSPD IDABSD1TM IDDM0033
131	2.29E-10	.05	LOSS OF OFFSITE FAILURE OF INV., BUS UNAVAILABLE	POWER INITIATING EVENT OCCURS STATIC SWITCH AND ASSOC. DUE TO TEST OR CORRECTIVE	WITH RCS DRAINED BREAKERS MAINTENANCE	1.48E-03 5.16E-04 3.00E-04	IEV-LOSPD IDAM0005 IDDBSD1TM
132	2.29E-10	.05	LOSS OF OFFSITE FAILURE OF INV., BUS UNAVAILABLE	POWER INITIATING EVENT OCCURS STATIC SWITCH AND ASSOC. DUE TO TEST OR CORRECTIVE	WITH RCS DRAINED BREAKERS MAINTENANCE	1.48E-03 5.16E-04 3.00E-04	IEV-LOSPD IDAM0005 IDDBSD1TM
133	2.29E-10	.05	LOSS OF OFFSITE FAILURE OF INV., BUT UNAVAILABLE	POWER INITIATING EVENT OCCURS STATIC SWITCH AND ASSOC. DUE TO TEST OR CORRECTIVE	WITH RCS DRAINED BREAKERS MAINTENANCE	1.48E-03 5.16E-04 3.00E-04	IEV-LOSPD IDAM0005 IDDBSD1TM
134	2.21E-10	.05	LOSS OF CCS/SWS LOSS OF DIST. PMD0301ASA	WITH RCS DRAINED INITIATING EVENT OCCURS PANEL OR BREAKER A07 SPURIOUSLY	OPEN	6.02E-04 3.17E-04 1.16E-03	IEV-CWCD IDAM0004 PMOD0301ASA
135	2.21E-10	.05	LOSS OF CCT/SWS LOSS OF DIST. PMD0301BSA	WITH RCS DRAINED INITIATING EVENT OCCURS PANEL OR BREAKER A07 SPURIOUSLY	OPEN	6.02E-04 3.17E-04 1.16E-03	IEV-CWCD IDAM0004 PMOD0301BSA
136	2.20E-10	.05	LOSS OF CCS/SWS FAILURE UPON MECHANICAL	WITH RCS DRAINED DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO	INITIATING EVENT OCCURS FAIL-TO-OPEN	6.02E-04 1.65E-04 2.21E-03	IEV-CWCD PMA0301ASAX RN23M00SS

Table 54B-5

CASE 2 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS	WITH RCS DRAINED	EVENT PROB	IDENTIFIER	
137	2.20E-10	.05	LOSS OF CCS/SWS FAILURE UPON MECHANICAL	DEMAND OF LOGIC FAILURE CAUSES MOV 023 TO	GROUP PROCESSING FAIL-TO-OPEN	6.02E-04 1.65E-04 2.21E-03	IEV-COMD PMA0301BSAX RN23MUD55	
138	2.14E-10	.04	LOSS OF RNS WITH RCS DRAINED CCF OF PRESSURE TRANSMITTERS		INITIATING EVENT OCCURS	8.15E-05 2.63E-06	IEV-RNSD CCX-XMTRX	
139	2.09E-10	.04	LOSS OF CCS/SWS BUS UNAVAILABLE PMOD0301ASA	WITH RCS DRAINED DUE TO TEST OR	INITIATING EVENT OCCURS CORRECTIVE MAINTENANCE	6.02E-04 3.00E-04 1.16E-03	IEV-COMD IDABSDS1TM PMOD0301ASA	
140	2.09E-10	.04	LOSS OF CCS/SWS BUS UNAVAILABLE PMOD0301BSA	DUE TO TEST OR	INITIATING EVENT OCCURS CORRECTIVE MAINTENANCE	6.02E-04 3.00E-04 1.16E-03	IEV-COMD IDABSDS1TM PMOD0301BSA	
141	2.08E-10	.04	LOSS OF CCS/SWS FAILURE UPON PMODMOD11	WITH RCS DRAINED DEMAND OF LOGIC	INITIATING EVENT OCCURS GROUP PROCESSING	3.47E-04 1.65E-04 2.09E-03	IEV-COMD PMA0301BSAX PMODMOD11	
142	2.08E-10	.04	LOSS OF CCS/SWS FAILURE UPON PMODMOD11	WITH RCS DRAINED DEMAND OF LOGIC	INITIATING EVENT OCCURS GROUP PROCESSING	6.02E-04 1.65E-04 2.09E-03	IEV-COMD PMA0301ASAX PMODMOD11	
143	2.03E-10	.04	LOSS OF CCS/SWS FAILURE OF PMS OUTPUT FAILURE OF INV.,	WITH RCS DRAINED LOGIC 1/0s STATIC SWITCH AND ASSOC.	INITIATING EVENT OCCURS BREAKERS	6.02E-04 5.53E-04 5.16E-04	IEV-COMD PMAMOD11X IDDMOD33	
144	2.02E-10	.04	LOCA/RNS-V024 CCF OF STRAINERS	OPENS IN RNST TANK	INITIATING EVENT OCCURS	WITH RCS FILLED	1.68E-05 1.20E-05	IEV-LOCA24ND INX-FL-GP
145	1.97E-10	.04	LOSS OF CCS/SWS FAILURE OF INV.,	WITH RCS DRAINED STATIC SWITCH AND ASSOC.	INITIATING EVENT OCCURS BREAKERS	6.02E-04 5.16E-04 6.35E-04	IEV-COMD IDAMOD05 PMODMOD41	
146	1.97E-10	.04	OVERDRAINING OF RHN-MAN04-SUCC COMMON CAUSE	RCS DURING DRAIN DOWN TO MID-LOOP FAILURE OF THE	INITIATING EVENT BATTERIES	4.44E-06 9.45E-01 4.71E-04	IEV-RCS0D RHN-MAN04-SUCC INX-WW-PN	
147	1.91E-10	.04	LOSS OF CCS/SWS LOSS OF DIST. INDICATION	WITH RCS DRAINED MANEL OR BREAKER A07 FAILURE	INITIATING EVENT OCCURS SPURIOUSLY OPENS	6.02E-04 3.17E-04 1.00E-03	IEV-COMD IDAMOD04 ALL-IND-FAIL	
148	1.89E-10	.04	LOSS OF OFFSITE FAILURE OF OPERATOR FAILS	POWER INITIATING MIN'C BUS SELECTOR BOARD TO & RECOGNIZE	EVENT OCCURS NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	1.48E-03 8.00E-05 1.60E-03	IEV-LOSPO PMAKS0GASA RHN-MAN05
149	1.83E-10	.04	LOSS OF OFFSITE FAILURE OF INV., IRWST DISCHARGE	POWER INITIATING STATIC SWITCH LINE "B"	EVENT OCCURS AND ASSOC. SHOWERER	WITH RCS DRAINED BREAKERS PLUGGED	1.48E-03 5.16E-04 2.40E-04	IEV-LOSPO IDAMOD05 INB-PLUG
150	1.81E-10	.04	LOSS OF CCS/SWS BUS UNAVAILABLE INDICATION	WITH RCS DRAINED DUE TO TEST OR	INITIATING EVENT OCCURS CORRECTIVE FAILURE	MAINTENANCE BREAKERS	6.02E-04 3.00E-04 1.00E-03	IEV-COMD IDABSDS1TM ALL-IND-FAIL
151	1.60E-10	.03	LOSS OF CCS/SWS FAILURE OF INV.,	WITH RCS DRAINED STATIC SWITCH AND ASSOC.	INITIATING EVENT OCCURS FAILURE OF INV.,	WITH RCS DRAINED STATIC SWITCH AND ASSOC.	6.02E-04 5.16E-04 5.16E-04	IEV-COMD IDAMOD05 IDDMOD33

Table 54B-5

CASE 2 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET_PRB	PERCENT	BASIC_EVENT_NAME		EVENT_PRB	IDENTIFIER	
152	1.59E-10	.03	LOSS OF CCS/SWS FAILURE UPON OPERATOR FAILS	WITH RCS DRAINED INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	6.02E-04 1.65E-04 1.60E-03	IEV-COMD PMA0301ASA RHN-MAN05	
153	1.59E-10	.03	LOSS OF CCS/SWS FAILURE UPON OPERATOR FAILS	WITH RCS DRAINED INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	6.02E-04 1.65E-04 1.60E-03	IEV-COMD PMA0301BSA RHN-MAN05	
154	1.52E-10	.03	LOSS OF OFFSITE COMMON MODE INDICATION	POWER INITIATING EVENT OCCURS FAILURE OF INPUT LOGIC GROUPS	1.48E-03 1.03E-04 1.00E-03	IEV-LOSPD CCX-INPUT-LOGIC ALL-IND-FAIL	
155	1.49E-10	.03	LOSS OF OFFSITE LOSS OF DIST. LOSS OF DIST.	POWER INITIATING EVENT OCCURS PANEL OR BREAKER A07 SPURIOUSLY PANEL OR BREAKER A28 SPURIOUSLY	WITH RCS DRAINED OPENS OPENS	1.48E-03 3.17E-04 3.17E-04	IEV-LOSPD IDAMOD04 IDMOD32
156	1.45E-10	.03	LOCA/RNS-V024 CCF OF THE POWER	OPENS INITIATING EVENT OCCURS INTERFACE OUTPUT BOARDS IN PMS	WITH RCS FILLED OPENED	1.68E-05 8.62E-06	IEV-LOCA24ND CCX-EP-SAM
157	1.41E-10	.03	LOSS OF OFFSITE BUS UNAVAILABLE LOSS OF DIST.	POWER INITIATING EVENT OCCURS DUE TO TEST OR CORRECTIVE PANEL OR BREAKER A28 SPURIOUSLY	WITH RCS DRAINED MAINTENANCE OPENS	1.48E-03 3.00E-04 3.17E-04	IEV-LOSPD IDABSDS1TM IDMOD32
158	1.41E-10	.03	LOSS OF OFFSITE LOSS OF DIST. BUS UNAVAILABLE	POWER INITIATING EV. OCCURS PANEL OR BREAKER A07 SPURIOUSLY DUE TO TEST OR CORRECTIVE	WITH RCS DRAINED OPENS MAINTENANCE	1.48E-03 3.17E-04 3.00E-04	IEV-LOSPD IDAMOD04 IDBGSDD1TM
159	1.41E-10	.03	LOSS OF OFFSITE LOSS OF DIST. BUS UNAVAILABLE	POWER INITIATING EVENT OCCURS PANEL OR BREAKER A07 SPURIOUSLY DUE TO TEST OR CORRECTIVE	WITH RCS DRAINED OPENS MAINTENANCE	1.48E-03 3.17E-04 3.00E-04	IEV-LOSPD IDAMOD04 IDDBSDS1TM
160	1.41E-10	.03	LOSS OF OFFSITE LOSS OF DIST. BUS UNAVAILABLE	POWER INITIATING EVENT OCCURS PANEL OR BREAKER A07 SPURIOUSLY DUE TO TEST OR CORRECTIVE	WITH RCS DRAINED OPENS MAINTENANCE	1.48E-03 3.17E-04 3.00E-04	IEV-LOSPD IDAMOD04 IDDBSDS1TM
161	1.40E-10	.03	LOSS OF OFFSITE ORIFICE FAILURE INDICATION	POWER INITIATING EVENT OCCURS DUE TO PLUGGING FAILURE	WITH RCS DRAINED OPENED MAINTENANCE	1.48E-03 9.46E-05 1.00E-03	IEV-LOSPD IW10R170SPK ALL-IND-FAIL
162	1.40E-10	.03	LOSS OF OFFSITE ORIFICE FAILURE INDICATION	POWER INITIATING EVENT OCCURS DUE TO PLUGGING FAILURE	WITH RCS DRAINED OPENED MAINTENANCE	1.48E-03 9.46E-05 1.00E-03	IEV-LOSPD IW20R160SPK ALL-IND-FAIL
163	1.37E-10	.03	LOSS OF OFFSITE FAILURE UPON PMDKS00ASA	POWER INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING	WITH RCS DRAINED OPENED MAINTENANCE	1.48E-03 1.16E-03 8.00E-05	IEV-LOSPD PMA0301BSA PMDKS00ASA
164	1.37E-10	.03	LOSS OF OFFSITE FAILURE UPON PMDKS00ASA	POWER INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING	WITH RCS DRAINED OPENED MAINTENANCE	1.48E-03 1.16E-03 8.00E-05	IEV-LOSPD PMA0301ASA PMDKS00ASA
165	1.37E-10	.03	LOSS OF OFFSITE FAILURE OF PMD0301BSA	POWER INITIATING EVENT OCCURS MIMIC BUS SELECTOR BOARD	WITH RCS DRAINED OPENED MAINTENANCE	1.48E-03 8.00E-05 1.16E-03	IEV-LOSPD PMAKS00ASA PMD0301BSA
166	1.37E-10	.03	LOSS OF OFFSITE FAILURE OF PMD0301ASA	POWER INITIATING EVENT OCCURS MIMIC BUS SELECTOR BOARD	WITH RCS DRAINED OPENED MAINTENANCE	1.48E-03 8.00E-05 1.16E-03	IEV-LOSPD PMAKS00ASA PMD0301ASA

Table 54B-5

CASE 2 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER
167	1.36E-10	.03	LOCA/RNS-V024 CCF OF STRAINERS IN IRWST TANK	OPENS INITIATING EVENT OCCURS WITH RCS DRAINED	1.13E-05 1.20E-05	IEV-LOCA24D IRX-FL-GP
168	1.33E-10	.03	LOSS OF OFFSITE BUS UNAVAILABLE BUS UNAVAILABLE	POWER INITIATING EVENT OCCURS DUE TO TEST OR CORRECTIVE MAINTENANCE	1.48E-03 3.00E-04 3.00E-04	IEV-LOSPD IDABSDS1TM IDDBSDK1TM
169	1.33E-10	.03	LOSS OF OFFSITE BUS UNAVAILABLE BUS UNAVAILABLE	POWER INITIATING EVENT OCCURS DUE TO TEST OR CORRECTIVE MAINTENANCE	1.48E-03 3.00E-04 3.00E-04	IEV-LOSPD IDABSDS1TM IDDBSDS1TM
170	1.33E-10	.03	LOSS OF OFFSITE BUS UNAVAILABLE BUS UNAVAILABLE	POWER INITIATING EVENT OCCURS DUE TO TEST OR CORRECTIVE MAINTENANCE	1.48E-03 3.00E-04 3.00E-04	IEV-LOSPD IDABSDS1TM IDDBSDS1TM
171	1.31E-10	.03	LOSS OF OFFSITE FAILURE OF INV. FAILURE OF	POWER INITIATING EVENT OCCURS STATIC SWITCH AND ASSOC. OUTPUT DRIVER	1.48E-03 5.18E-04 1.73E-04	IEV-LOSPD IDAMOD05 PMDEP023SA
172	1.26E-10	.03	OVERDRAINING OF RHN-MANO4-SUCC DUE TO CCF OF	RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT THE SQUIB VALVES TO OPERATE	4.44E-06 9.45E-01 3.00E-05	IEV-RCS0D RHN-MANO4-SUCC P IX-EV-SA
173	1.25E-10	.03	LOSS OF CCS/SWS FAILURE OF LOSS OF DIST.	WITH RCS DRAINED INITIATING EVENT OCCURS PMS OUTPUT LOGIC I/Os PANEL OR BREAKER A28 SPURIOUSLY OPENS	6.02E-04 6.53E-04 3.17E-04	IEV-CWMD PMAMOD11X IDDMOD32
174	1.21E-10	.03	LOSS OF CCS/SWS LOSS OF DIST. +m.WOD41	WITH RCS DRAINED INITIATING EVENT OCCURS PANEL OR BREAKER A07 SPURIOUSLY OPENS	6.02E-04 3.17E-04 6.35E-04	IEV-CWMD IDAMOD04 PMDDMOD41
175	1.20E-10	.02	LOSS OF CCS/SWS PM.MOD21X OP.RATOR FAILS CUD. PROB. OF	WITH RCS DRAINED INITIATING EVENT OCCURS TO OPEN TWO IRWST MOVs RHN-MANO5 (OP. FAILS TO OPEN RNS MOV V023)	6.02E-04 1.16E-03 1.15E-03 1.50E-03	IEV-CWMD PMAMOD21X RHN-MANO5 RHN-MAN05C
176	1.18E-10	.02	LOSS OF OFFSITE FAILURE OF INDICATION	POWER INITIATING EVENT OCCURS MIMIC BUS SELECTOR BOARD FAILURE	1.48E-03 8.00E-05 1.00E-03	IEV-LOSPD PMAXSD0ASA ALL-IND-FAIL
177	1.18E-10	.02	LOSS OF CCS/SWS FAILURE OF BUS UNAVAILABLE	WITH RCS DRAINED INITIATING EVENT OCCURS PMS OUTPUT LOGIC I/Os DUE TO TEST OR CORRECTIVE MAINTENANCE	6.02E-04 6.53E-04 3.00E-04	IEV-CWMD PMAMOD11X IDDBSDS1TM
178	1.18E-10	.02	LOSS OF CCS/SWS FAILURE OF BUS UNAVAILABLE	WITH RCS DRAINED INITIATING EVENT OCCURS PMS OUTPUT LOGIC I/Os DUE TO TEST OR CORRECTIVE MAINTENANCE	6.02E-04 6.53E-04 3.00E-04	IEV-CWMD PMAMOD11X IDDBSDS1TM
179	1.18E-10	.02	LOSS OF CCS/SWS FAILURE OF BUS UNAVAILABLE	WITH RCS DRAINED INITIATING EVENT OCCURS PMS OUTPUT LOGIC I/Os DUE TO TEST OR CORRECTIVE MAINTENANCE	6.02E-04 6.53E-04 3.00E-04	IEV-CWMD PMAMOD11X IDDBSDK1TM
180	1.18E-10	.02	LOSS OF RNS WITH RCS DRAINED FAILURE OF PMS OUTPUT MECHANICAL	INITIATING EVENT OCCURS LOGIC I/Os FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	8.15E-05 6.53E-04 2.21E-03	IEV-RNSD PMAMOD11X RN23MOD5S

Table 54B-5

CASE 2 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER	
181	1.15E-10	.02	LOSS OF CCS/SWS FAILURE UPON PMD0301ASA	WITH RCS DRAINED INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING	6.62E-04 1.65E-04 1.16E-03	IEV-COND PMA0301BSAX PMD0301ASA	
182	1.15E-10	.02	LOSS OF CCS/SWS FAILURE UPON PMD0301BSA	WITH RCS DRAINED INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING	6.62E-04 1.65E-04 1.16E-03	IEV-COND PMA0301BSAX PMD0301BSA	
183	1.15E-10	.02	LOSS OF CCS/SWS FAILURE UPON PMD0301ASA	WITH RCS DRAINED INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING	6.62E-04 1.65E-04 1.16E-03	IEV-COND PMA0301ASAX PMD0301ASA	
184	1.15E-10	.02	LOSS OF CCS/SWS FAILURE UPON PMD0301BSA	WITH RCS DRAINED INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING	6.62E-04 1.65E-04 1.16E-03	IEV-COND PMA0301ASAX PMD0301BSA	
185	1.15E-10	.02	LOSS OF CCS/SWS BUS UNAVAILABLE PMDMOD41	WITH RCS DRAINED INITIATING EVENT OCCURS DUE TO TEST OR CORRECTIVE MAINTENANCE	6.62E-04 3.00E-04 6.35E-04	IEV-COND TDABSDSITM PMDMOD41	
186	1.13E-10	.02	LOSS OF OFFSITE IRWST DISCHARGE	POWER INITIATING EVENT OCCURS LOSS OF DIST. PANEL OR BREAKER A07 SPURIOUSLY LINE "B" STRAINER	WITH RCS DRAINED OPENS PLUGGED	1.48E-03 3.17E-04 2.40E-04	IEV-LOSPD IDAMOD04 IWB-PLUG
187	1.11E-10	.02	LOSS OF RNS WITH PMD0301L1	RCS DRAINED FAILURE OF PMS OUTPUT	INITIATING EVENT OCCURS LOGIC I/Os	8.15E-05 6.53E-04 2.09E-03	IEV-RNSD PMA0301LX PMD0301L1
188	1.09E-10	.02	OVERDRAINING OF RHN-MAN04-SUCC CCF OF IRWST INJ	RCS DURING DRAIN DOWN TO MID-LOOP MOVs 121A, 121B, & RNS V023	INITIATING EVENT	4.44E-06 9.45E-01 2.60E-05	IEV-RCS0D RHN-MAN04-SUCC IWB-MV-G01
189	1.07E-10	.02	LOSS OF OFFSITE IRWST DISCHARGE	POWER INITIATING EVENT OCCURS BUS UNAVAILABLE DUE TO TEST OR CORRECTIVE LINE "B" STRAINER	WITH RCS DRAINED MAINTENANCE PLUGGED	1.48E-03 3.00E-04 2.40E-04	IEV-LOSPD TDABSDSITM IWB-PLUG
190	1.07E-10	.02	LOSS OF OFFSITE IRWST DISCHARGE	POWER INITIATING EVENT OCCURS BUS UNAVAILABLE DUE TO TEST OR CORRECTIVE LINE "B" STRAINER	WITH RCS DRAINED PLUGGED MAINTENANCE	1.48E-03 2.40E-04 3.00E-04	IEV-LOSPD IWB-PLUG TDABSDSITM
191	1.07E-10	.02	LOSS OF OFFSITE IRWST DISCHARGE	POWER INITIATING EVENT OCCURS BUS UNAVAILABLE DUE TO TEST OR CORRECTIVE LINE "B" STRAINER	WITH RCS DRAINED PLUGGED MAINTENANCE	1.48E-03 2.40E-04 3.00E-04	IEV-LOSPD IWB-PLUG TDABSDSITM
192	1.07E-10	.02	LOSS OF OFFSITE IRWST DISCHARGE	POWER INITIATING EVENT OCCURS BUS UNAVAILABLE DUE TO TEST OR CORRECTIVE LINE "B" STRAINER	WITH RCS DRAINED PLUGGED MAINTENANCE	1.48E-03 2.40E-04 3.00E-04	IEV-LOSPD IWB-PLUG TDABSDSITM
193	1.06E-10	.02	LOSS OF CCS/SWS MECHANICAL	WITH RCS DRAINED FAILURE OF MIMIC BUS FAILURE CAUSES NOV 023 TO	INITIATING EVENT OCCURS SELECTOR BOARD FAIL-TO-OPEN	6.02E-04 8.00E-05 2.21E-03	IEV-COND PMAKS00ASAX RM23MOD55
194	1.01E-10	.02	LOSS OF OFFSITE LEVEL INDICATION	POWER INITIATING EVENT OCCURS TRANSMITTER FAILURE FAILURE	WITH RCS DRAINED	1.48E-03 6.84E-05 1.00E-03	IEV-LOSPD IWB-PLUG ALL-IND-FAIL

Table 54B-6

BASIC EVENT IMPORTANCE - CASE 2

		SYSTEM UNAVAILABILITY (Q) = 4.806E-07	NUMBER OF BASIC EVENTS = 156	NUMBER OF CUTSETS = 6982	
BASIC EVENT	IMPORTANCE (*DECREASE)	NUMBER OF CUTSETS	DECREASE IN SYSTEM UNAVAILABILITY	BASIC EVENT PROBABILITY	
1 IEV-LOSPD	71.02	2488	3.4131E-07	1.4800E-03	
2 IEV-CCWD	23.25	1723	1.1174E-07	6.0200E-04	
3 CCX-BY-PN	21.50	33	1.0334E-07	4.7000E-05	
4 ADX-EV-SA	13.62	357	6.5440E-08	3.0000E-05	
5 IWX-MV-GO1	11.80	6	5.6729E-08	2.6000E-05	
6 CCX-IV-XR	10.96	31	5.2681E-08	2.4000E-05	
7 PMAMOD11	7.80	32	3.7505E-08	2.0900E-03	
8 IWX-FL-GP	5.50	30	2.6409E-08	1.2000E-05	
9 ALL-IND-FAIL	4.62	485	2.2208E-08	1.0000E-03	
10 RN23MOD5S	4.60	560	2.2100E-08	2.2100E-03	
11 PMDMOD11	4.35	560	2.0901E-08	2.0900E-03	
12 PMA0301ASA	4.33	29	2.0817E-08	1.1400E-03	
13 PMA0301BSA	4.33	29	2.0817E-08	1.1600E-03	
14 CCX-EP-SAM	3.95	29	1.8988E-08	8.6200E-06	
15 RHN-MAN05	3.32	465	1.5961E-08	1.6000E-03	
16 IEV-RNSD	3.15	1020	1.5132E-08	8.1500E-05	
17 IDAMOD05	2.84	126	1.3635E-08	5.1600E-04	
18 PMD0301ASA	2.41	475	1.1596E-08	1.1600E-03	
19 PMD0301BSA	2.41	475	1.1596E-08	1.1600E-03	
20 IDAMOD04	1.74	123	8.3789E-09	3.1700E-04	
21 IEV-RCSOD	1.67	581	8.0065E-09	4.4400E-06	
22 IDABSDS1TM	1.65	123	7.9242E-09	3.0000E-04	
23 CCX-ORY-SPX	1.65	6	7.9131E-09	3.6300E-06	
24 PMAMOD21	1.49	79	7.1743E-09	4.0700E-03	
25 PMDMOD41	1.32	396	6.3453E-09	6.3500E-04	
26 RHN-MAN04-SUCC	1.20	368	5.7646E-09	3.4500E-01	
27 CCX-XMTRX	1.19	6	5.7253E-09	2.6300E-06	
28 PMAMOD11X	1.15	100	5.5352E-09	6.5300E-04	
29 IDDMOD33	1.07	379	5.1635E-09	5.1600E-04	
30 IWB-PLUG	1.00	231	4.7847E-09	2.4000E-04	
31 RHN-MAN05C	.81	28	3.8885E-09	1.5000E-01	
32 IDDMOD32	.66	321	3.1706E-09	3.1700E-04	
33 IDDBSDS1TM	.62	322	2.9997E-09	3.0000E-04	
34 IDDBSDD1TM	.62	313	2.9996E-09	3.0000E-04	
35 IDDBSDK1TM	.62	313	2.9996E-09	3.0000E-04	
36 CCX-SFTW	.55	24	2.6409E-09	1.2000E-06	
37 RHN-MAN04	.49	335	2.3454E-09	5.5000E-02	
38 IWN-MAN00	.46	366	2.1893E-09	1.1500E-03	
39 IEV-LOCA24D	.44	465	2.0966E-09	1.1300E-05	
40 IEV-LOCA24ND	.44	178	2.0950E-09	1.6800E-05	
41 IWN-MAN00C	.40	20	1.9464E-09	5.0000E-02	
42 RNDEP023SA	.36	281	1.7109E-09	1.7100E-04	
43 IRWMOD05S	.35	756	1.6747E-09	3.0000E-03	
44 PMAXS00ASA	.30	25	1.4338E-09	8.0000E-05	
45 PMA0301ASAX	.29	97	1.3986E-09	1.6500E-04	
46 PMA0301BSAX	.29	97	1.3986E-09	1.6500E-04	
47 IWX-CV-AO	.28	149	1.3468E-09	3.0000E-05	
48 PMAMOD21X	.20	141	9.5942E-10	1.1600E-03	
49 PMDXS00ASA	.17	189	7.9861E-10	8.0000E-05	
50 PMAXS00ASAX	.14	97	6.7789E-10	8.0000E-05	
51 ADN-MAN01	.10	61	4.7514E-10	4.9300E-04	
52 CCX-INPUT-LOGIC	.08	78	3.7004E-10	1.0300E-04	
53 IW1OR170SPX	.07	132	3.4896E-10	9.4600E-05	
54 IW2OR160SPX	.07	132	3.4896E-10	9.4600E-05	
55 IW1TL170UFX	.05	124	2.5211E-10	6.8400E-05	
56 IW2TL160UFX	.05	124	2.5213E-10	6.8400E-05	
57 IDAMOD02	.04	99	1.9251E-10	2.7000E-03	
58 IDAMOD03	.04	99	1.9251E-10	2.7000E-03	
59 IDDBSDS1TM	.03	410	1.6752E-10	3.0000E-04	
60 IDDBSDD1TM	.03	411	1.6735E-10	3.0000E-04	
61 IDBBSDK1TM	.03	411	1.6735E-10	3.0000E-04	
62 IWA-PLUG	.03	409	1.3592E-10	2.4000E-04	
63 IDABSDS1LF	.03	98	1.2676E-10	4.8000E-06	
64 IDDFD019RQ	.02	99	1.1991E-10	1.2000E-05	
65 IDDFD020RQ	.02	99	1.1991E-10	1.2000E-05	
66 IEV-LOCAPRND	.02	133	1.0356E-10	1.5100E-05	

67	PXX-AV-LA	.02	218	9.7794E-11	6.1000E-05
68	IWACV122AO	.02	524	8.6846E-11	8.7600E-03
69	IWACV123AO	.02	524	8.6846E-11	8.7600E-03
70	IWACV124AO	.02	524	8.6846E-11	8.7600E-03
71	IWACV125AO	.02	524	8.6846E-11	8.7600E-03
72	PMAMOD41	.02	342	8.6000E-11	6.3500E-04
73	IDDMOD22	.02	76	7.2763E-11	2.7000E-03
74	IDDMOD23	.02	76	7.2763E-11	2.7000E-03
75	IEV-LOSPND	.01	185	6.6901E-11	8.1300E-03
76	IDDBSDD1LF	.01	68	4.7908E-11	4.8000E-06
77	IDDBSDK1LF	.01	68	4.7908E-11	4.8000E-06
78	IDDBBSD1LF	.01	68	4.7908E-11	4.8000E-06
79	CCX-IN-LOGIC-SW	.01	80	4.0856E-11	1.1000E-05
80	IDCBSDS1TM	.01	532	3.5232E-11	3.0000E-04
81	IDCBSDK1TM	.01	529	3.5198E-11	3.0000E-04
82	IDCBSDK1TM	.01	529	3.5198E-11	3.0000E-04
83	IRAEPI21ASAX	.01	218	3.2327E-11	5.8300E-05
84	IEV-CCWND	.01	125	3.0895E-11	3.7500E-03
85	CCX-EF-SAMX	.01	73	2.4896E-11	2.9400E-06
86	CCX-INPUT-LOGICK	.00	47	2.1376E-11	2.5900E-05
87	IWBCV122AO	.00	704	1.9302E-11	8.7600E-03
88	IWBCV123AO	.00	704	1.9302E-11	8.7600E-03
89	IWBCV124AO	.00	704	1.9302E-11	8.7600E-03
90	IWBCV125AO	.00	704	1.9302E-11	8.7600E-03
91	IEV-RNSND	.00	84	7.9011E-12	9.6100E-04
92	IRAEPI21BSAX	.00	304	6.7177E-12	5.8300E-05
93	IDBFDO13RQ	.00	92	6.5755E-12	1.2000E-05
94	IDBFDO14RQ	.00	92	6.5755E-12	1.2000E-05
95	PMAEHO1SA	.00	93	5.9349E-12	8.0000E-05
96	CCK-LS-FA	.00	67	5.6773E-12	5.3700E-06
97	ADN-MAN01C	.00	6	5.3839E-12	5.0000E-02
98	AD3MOD03	.00	79	5.2154E-12	5.5400E-02
99	AD3MOD04	.00	79	5.2154E-12	5.5400E-02
100	AD2MOD01	.00	76	5.2064E-12	5.5400E-02
101	AD2MOD02	.00	75	5.2062E-12	5.5400E-02
102	PMAEHO1SAX	.00	105	4.8270E-12	8.0000E-05
103	IDBMOD10	.00	63	3.9737E-12	2.7000E-03
104	IDBMOD11	.00	63	3.9737E-12	2.7000E-03
105	IWNTK001AF	.00	58	3.8181E-12	2.4000E-06
106	LPM-MAN05	.00	33	3.3402E-12	6.8300E-04
107	PRAAV108LA	.00	66	2.7486E-12	1.0900E-03
108	PRBAV108LA	.00	66	2.7486E-12	1.0900E-03
109	IDDBBSDS1LF	.00	44	2.5945E-12	4.8000E-06
110	IDBBSSDD1LF	.00	43	2.5920E-12	4.8000E-06
111	IDBBSDK1LF	.00	43	2.5920E-12	4.8000E-06
112	CCK-AV-LA	.00	16	2.4406E-12	6.1000E-05
113	CMX-CV-GO	.00	15	2.0431E-12	5.1000E-05
114	CMX-VS-FA	.00	19	1.6807E-12	3.8400E-05
115	IDCFD007RQ	.00	141	1.2889E-12	1.2000E-05
116	IDCFD008RQ	.00	141	1.2889E-12	1.2000E-05
117	PMAMOD31	.00	58	1.2555E-12	5.0200E-03
118	PRAAV108TM	.00	42	1.2552E-12	5.0000E-04
119	PRBAV108TM	.00	42	1.2552E-12	5.0000E-04
120	PMBMOD32	.00	49	1.1652E-12	5.0200E-03
121	PMCMOD33	.00	49	1.1652E-12	5.0200E-03
122	PMBMOD11	.00	11	1.1545E-12	2.0900E-03
123	PMDMOD34	.00	34	1.0091E-12	5.0200E-03
124	IDCMOD16	.00	102	7.4885E-13	2.7000E-03
125	IDCMOD17	.00	102	7.4885E-13	2.7000E-03
126	PMB0301ASA	.00	8	6.4249E-13	1.1600E-03
127	PMB0301BSA	.00	8	6.4249E-13	1.1600E-03
128	ADX-MV-GO	.00	8	6.0862E-13	1.1000E-03
129	IDCBSDS1LF	.00	80	4.7107E-13	4.8000E-06
130	IDCBSDK1LF	.00	80	4.7107E-13	4.8000E-06
131	IDCBSDS1LF	.00	80	4.7107E-13	4.8000E-06
132	IDBMOD25	.00	15	3.5538E-13	5.1600E-04
133	IDBMOD24	.00	8	2.1072E-13	3.1700E-04
134	PRX-HR-ML	.00	15	1.8774E-13	1.2000E-07
135	CCX-XKTR	.00	4	1.4200E-13	2.0100E-04
136	IDCMOD29	.00	9	7.0055E-14	5.1600E-04
137	PMBX500ASA	.00	4	4.4076E-14	8.0000E-05
138	IDCMOD28	.00	3	3.5305E-14	3.1700E-04
139	IDABSDS1TM	.00	9	2.6978E-14	3.0000E-04
140	IDABSDK1TM	.00	9	2.6978E-14	3.0000E-04
141	CMA-PLUG	.00	3	1.9318E-14	7.2700E-04
142	CMB-PLUG	.00	3	1.9318E-14	7.2700E-04
143	ADAEPO02ASA	.00	6	1.4988E-14	1.7100E-04
144	ADAEPO03ASA	.00	6	1.4988E-14	1.7100E-04
145	ADAEPO12ASA	.00	6	1.4988E-14	1.7100E-04
146	ADAEPO13ASA	.00	6	1.4988E-14	1.7100E-04
147	ADBEPO02BSA	.00	6	1.4988E-14	1.7100E-04

148	ADBEPO03BSA	.00	6	1.4988E-14	1.7100E-04
149	ADBEPO12BSA	.00	6	1.4988E-14	1.7100E-04
150	ADBEPO13BSA	.00	6	1.4988E-14	1.7100E-04
151	IWX-XMTRLW	.00	6	1.0436E-14	9.2000E-09
152	PMBMOD21	.00	4	5.7732E-15	4.0700E-03
153	CMX-TK-AF	.00	2	3.3307E-15	1.2000E-07
154	PMBMOD41	.00	1	1.3323E-15	6.3500E-04
155	IDAFD003RQ	.00	3	9.9920E-16	1.2000E-05
156	IDAFD004RQ	.00	3	9.9920E-16	1.2000E-05

SYSTEM UNAVAILABILITY (Q) = 4.806E-07
 NUMBER OF BASIC EVENTS = 156
 NUMBER OF CUTSETS = 6982

BASIC EVENT	IMPORTANCE (% INCREASE)	NUMBER OF CUTSETS	INCREASE IN SYSTEM UNAVAILABILITY	BASIC EVENT PROBABILITY
1 CCX-EP-SAM	458350.	29	2.4028E-03	8.6200E-06
2 CCX-SPTW	457931.	24	2.2008E-03	1.2000E-06
3 IWX-FL-OF	457927.	30	2.2008E-03	1.2000E-05
4 CCX-BY-PN	457476.	33	2.1986E-03	4.7000E-05
5 CCX-IV-XR	456728.	31	2.1950E-03	2.4000E-05
6 IWX-MV-OO1	453992.	6	2.1818E-03	2.6000E-05
7 ADX-EV-SA	453871.	357	2.1813E-03	3.0000E-05
8 CCX-ORY-SPX	453589.	6	2.1799E-03	3.6300E-06
9 CCX-XMTRX	452970.	6	2.1769E-03	2.6300E-06
10 IEV-RCSOD	375218.	581	1.8033E-03	4.4400E-06
11 IEV-LOSPD	47914.3	2488	2.3027E-04	1.4800E-03
12 IEV-RNSD	38629.8	1020	1.8565E-04	8.1500E-05
13 IEV-LOCA24D	38607.1	465	1.8554E-04	1.1300E-05
14 IEV-CCWD	38600.3	1723	1.8551E-04	6.0200E-04
15 IEV-LOCA24ND	25946.9	178	1.2470E-04	1.6800E-05
16 IWX-CV-AO	9341.02	149	4.4892E-05	3.0000E-05
17 IDAMOD04	5498.14	123	2.6424E-05	3.1700E-04
18 IDAMOD05	5495.58	126	2.6411E-05	5.1600E-04
19 IDABSDS1LF	5495.11	98	2.6409E-05	4.8000E-06
20 IDABSDS1TM	5494.50	123	2.6406E-05	3.0000E-04
21 ALL-IND-FAIL	4616.35	485	2.2186E-05	1.0000E-03
22 IWB-PLUG	4147.29	231	1.9931E-05	2.4000E-04
23 PMA0301ASA	3729.77	29	1.7925E-05	1.1600E-03
24 PMA0301BSA	3729.77	29	1.7925E-05	1.1600E-03
25 PMAXS00ASA	3729.02	25	1.7921E-05	8.0000E-05
26 PMAMOD11	3726.16	32	1.7908E-05	2.0900E-03
27 RNDEP023SA	2081.55	281	1.0004E-05	1.7100E-04
28 IDDMOD33	2081.10	379	1.0002E-05	5.1600E-04
29 IDDMOD32	2080.52	321	9.9988E-06	3.1700E-04
30 IDDBSDS1TM	2079.93	322	9.9959E-06	3.0000E-04
31 IDDRSDD1TM	2079.86	313	9.9956E-06	3.0000E-04
32 IDDBSDK1TM	2079.86	313	9.9956E-06	3.0000E-04
33 IDDFD019RQ	2075.16	99	9.9922E-06	1.2000E-05
34 IDDFD020RQ	2079.16	99	9.9922E-06	1.2000E-05
35 PMDMOD41	2077.90	396	9.9862E-06	6.3500E-04
36 PMD0301ASA	2077.57	475	9.9846E-06	1.1600E-03
37 PMD0301BSA	2077.57	475	9.9846E-06	1.1600E-03
38 PMDXS00ASA	2076.99	189	9.9818E-06	8.0000E-05
39 IDDBSDS1LF	2076.77	68	9.9808E-06	4.8000E-06
40 IDDBSDK1LF	2076.77	68	9.9808E-06	4.8000E-06
41 IDDBSDS1LF	2076.77	68	9.9808E-06	4.8000E-06
42 PMDMOD11	2076.57	560	9.9798E-06	2.0900E-03
43 RN23MOD5S	2076.14	560	9.9777E-06	2.2100E-03
44 RHN-MAN05	2072.43	465	9.9599E-06	1.6000E-03
45 PMA0301ASAX	1763.42	97	8.4749E-06	1.6500E-04
46 PMA0301BSAX	1763.42	97	8.4749E-06	1.6500E-04
47 PMAXS00ASAX	1763.03	97	8.4729E-06	8.0000E-05
48 PMAMOD11X	1762.62	100	8.4710E-06	5.5300E-04
49 CCX-EP-SAMX	1761.97	73	8.4679E-06	2.9400E-06
50 IEV-LOCAPRND	1427.06	133	6.8583E-06	1.5100E-05
51 CCX-IN-LOGIC-SW	772.834	80	3.7142E-06	1.1000E-05
52 IW1OR170SPX	767.488	132	3.6885E-06	9.4600E-05
53 IW2OR160SPX	767.488	132	3.6885E-06	9.4600E-05
54 IW1TL170UFX	766.937	124	3.6858E-06	6.8400E-05
55 IW2TL160UFX	766.937	124	3.6858E-06	6.8400E-05
56 CCX-INPUT-LOGIC	747.474	78	3.5923E-06	1.0300E-04
57 IWN-MAN00	395.672	366	1.9016E-06	1.1500E-03
58 PMAMOD21	365.290	79	1.7555E-06	4.0700E-03
59 PXX-AV-LA	333.566	218	1.6031E-06	6.1000E-05
60 IWNTK001AF	331.020	58	1.5909E-06	2.4000E-06
61 PRX-HR-ML	325.535	15	1.5645E-06	1.2000E-07
62 IWX-XMTRLW	236.034	6	1.1344E-06	9.2000E-09
63 CCX-LS-FA	219.985	67	1.0572E-06	5.3700E-06
64 ADN-MAN01	200.441	61	9.6330E-07	4.9300E-04
65 PMAMOD21X	171.898	141	8.2613E-07	1.1600E-03
66 CCX-INPUT-LOGICK	171.726	47	8.2530E-07	2.5900E-05
67 IWA-PLUG	117.811	409	5.6619E-07	2.4000E-04
68 IDBBSDD1TM	116.158	410	5.5824E-07	3.0000E-04
69 IDBBSDK1TM	116.038	411	5.5767E-07	3.0000E-04
70 IRWMMOD05S	116.038	411	5.5767E-07	3.0000E-04
71 IRAEP021ASAX	115.810	756	5.5657E-07	3.0000E-03
72 IRAEP121ASAX	115.372	218	5.5447E-07	5.8300E-05

73	IDBFDO13RQ	114.017	92	5.4795E-07	1.2000E-05
74	IDBFDO14RQ	114.017	92	5.4795E-07	1.2000E-05
75	IDBBSDS1LF	112.469	44	5.4051E-07	4.8000E-06
76	IDBBSDD1LF	112.363	43	5.4001E-07	4.8000E-06
77	IDBBSDK1LF	112.363	43	5.4001E-07	4.8000E-06
78	PMAMOD41	28.1626	342	1.3535E-07	6.3500E-04
79	IDCBSDS1TM	24.4293	532	1.1740E-07	3.0000E-04
80	IDCBSDD1TM	24.4060	529	1.1729E-07	3.0000E-04
81	IDCBSDK1TM	24.4060	529	1.1729E-07	3.0000E-04
82	IRAEPI21BSAX	23.9747	304	1.1522E-07	5.8300E-05
83	IDCFD007RQ	22.3482	141	1.0740E-07	1.2000E-05
84	IDCFD008RQ	22.3482	141	1.0740E-07	1.2000E-05
85	IDCBSDD1LF	20.4204	80	9.8139E-08	4.8000E-06
86	IDCBSDK1LF	20.4204	80	9.8139E-08	4.8000E-06
87	IDCBSDS1LF	20.4204	80	9.8139E-08	4.8000E-06
88	PMAEHOA1SA	15.4353	93	7.4181E-08	8.0000E-05
89	IDAMOD02	14.7958	99	7.1107E-08	2.7000E-03
90	IDAMOD03	14.7958	99	7.1107E-08	2.7000E-03
91	PMAFH0A1SAX	12.5539	105	6.0333E-08	8.0000E-05
92	CMY-S-FA	9.10658	19	4.3765E-08	3.8400E-05
93	RHL-LN04	8.38500	335	4.0298E-08	5.5000E-02
94	CMX-CV-GO	8.33549	15	4.0060E-08	5.1000E-05
95	CCX-AV-LA	8.32464	16	4.0007E-08	6.1000E-05
96	IWN-MAN00C	7.69485	20	3.6981E-08	5.0000E-02
97	CMX-TK-AF	5.77530	2	2.7756E-08	1.2000E-07
98	IDDMOD22	5.59241	76	2.6877E-08	2.7000E-03
99	IDDMOD23	5.59241	76	2.6877E-08	2.7000E-03
100	RHN-MAN05C	4.58492	28	2.2559E-08	1.5000E-01
101	IWACV122AO	2.04478	524	9.1271E-09	8.7600E-03
102	IWACV123AO	2.04478	524	9.1271E-09	8.7600E-03
103	IWACV124AO	2.04478	524	9.8270E-09	8.7600E-03
104	IWACV125AO	2.04478	524	9.8270E-09	8.7600E-03
105	IEV-RNSND	1.70912	84	8.2139E-09	9.6100E-04
106	IEV-CCWND	1.70784	125	8.2077E-09	3.7500E-03
107	IEV-LOSPND	1.69834	185	8.1620E-09	8.1300E-03
108	LPM-MAN05	1.01691	33	4.8872E-09	6.8300E-04
109	PRAAV108LA	.524122	66	2.5189E-09	1.0900E-03
110	PRBAV108LA	.524122	66	2.5189E-09	1.0900E-03
111	PRAAV108TM	.522103	42	2.5092E-09	5.0000E-04
112	PRBAV108TM	.522103	42	2.5092E-09	5.0000E-04
113	IWBCV122AO	.454469	704	2.1841E-09	8.7600E-03
114	IWBCV123AO	.454469	704	2.1841E-09	8.7600E-03
115	IWBCV124AO	.454469	704	2.1841E-09	8.7600E-03
116	IWBCV125AO	.454469	704	2.1841E-09	8.7600E-03
117	IDBMOD10	.305410	63	1.4678E-09	2.7000E-03
118	IDBMOD11	.305410	63	1.4678E-09	2.7000E-03
119	CCX-XMTR	.146968	4	7.0631E-10	2.0100E-04
120	IDBMOD25	.143234	15	6.8837E-10	5.1600E-04
121	IDBMOD24	.138272	8	6.6452E-10	3.1700E-04
122	PMB0301ASA	.115113	8	5.5322E-10	1.1600E-03
123	PMB0301BSA	.115113	8	5.5322E-10	1.1600E-03
124	ADX-MV-GO	.115001	8	5.5269E-10	1.1000E-03
125	PMBMOD11	.114702	11	5.5125E-10	2.0900E-03
126	PMBX500ASA	.114631	4	5.5090E-10	8.0000E-05
127	RHN-MAN04-SUCC	6.981131E-02	368	3.3551E-10	9.4500E-01
128	IDCMOD16	5.755443E-02	102	2.7660E-10	2.7000E-03
129	IDCMOD17	5.755443E-02	102	2.7660E-10	2.7000E-03
130	PMAMOD31	5.179007E-02	58	2.4890E-10	5.0200E-03
131	PMBMOD32	4.805382E-02	49	2.3094E-10	5.0200E-03
132	PMCMOD33	4.805382E-02	49	2.3094E-10	5.0200E-03
133	PMDDMOD34	4.161612E-02	34	2.0000E-10	5.0200E-03
134	IDCMOD29	2.823517E-02	9	1.3570E-10	5.1600E-04
135	IDCMOD28	2.316674E-02	3	1.1134E-10	3.1700E-04
136	ADN-MAN01C	2.128514E-02	6	1.0229E-10	5.0000E-02
137	IDABSDD1TM	1.870637E-02	9	8.9901E-11	3.0000E-04
138	IDABSDK1TM	1.870637E-02	9	8.9901E-11	3.0000E-04
139	AD3MOD03	1.850329E-02	79	8.8925E-11	5.5400E-02
140	AD3MOD04	1.850329E-02	79	8.8925E-11	5.5400E-02
141	AD2MOD01	1.847139E-02	76	8.8772E-11	5.5400E-02
142	AD2MOD02	1.847060E-02	75	8.8768E-11	5.5400E-02
143	ADAEP002ASA	1.823468E-02	6	8.7634E-11	1.7100E-04
144	ADAEP003ASA	1.823468E-02	5	8.7634E-11	1.7100E-04
145	ADAEP012ASA	1.823468E-02	6	8.7634E-11	1.7100E-04
146	ADAEP013ASA	1.823468E-02	6	8.7634E-11	1.7100E-04
147	ADBEPO02BSA	1.823468E-02	6	8.7634E-11	1.7100E-04
148	ADBEPO03BSA	1.823468E-02	6	8.7634E-11	1.7100E-04
149	ADBEPO12BSA	1.823468E-02	6	8.7634E-11	1.7100E-04
150	ADBEPO13BSA	1.823468E-02	6	8.7634E-11	1.7100E-04
151	TDAFD003RQ	1.732570E-02	3	8.3266E-11	1.2000E-05
152	TDAFD004RQ	1.732570E-02	3	8.3266E-11	1.2000E-05
153	CMA-PLUG	5.525019E-03	3	2.6553E-11	7.2700E-04

154	CMB-PLUG	5.525019E-03	3	2.65553E-11	7.2700E-04
155	PMBMOD41	4.362811E-04	1	2.0967E-12	6.3500E-04
156	PMBMOD21	2.939494E-04	4	1.4127E-12	4.0700E-03

Table 54B-7

CASE 3 LIST OF TOP 200 DOMINANT CUTSETS

Reduced Sum of Cutsets: 1.15E-06

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIERS
1	1.81E-07	15.73	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS CHECK VALVE 122A FAILS TO OPEN CHECK VALVE 124A FAILS TO OPEN BUS UNAVAILABLE DUE TO TEST OR CORRECTIVE MAINTENANCE MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN		6.02E-04 1.00E+00 1.00E+00 3.00E-04 1.00E+00	IEV-CCWD IWACV122AO IWACV124AO IDCBSDS1TM RN23MOD5S
2	1.81E-07	15.73	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS CHECK VALVE 122A FAILS TO OPEN CHECK VALVE 124A FAILS TO OPEN BUS UNAVAILABLE DUE TO TEST OR CORRECTIVE MAINTENANCE MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN		6.02E-04 1.00E+00 1.00E+00 3.00E-04 1.00E+00	IEV-CCWD IWACV122AO IWACV124AO IDCBSDS1TM RN23MOD5S
3	1.81E-07	15.73	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS CHECK VALVE 122A FAILS TO OPEN CHECK VALVE 124A FAILS TO OPEN BUS UNAVAILABLE DUE TO TEST OR CORRECTIVE MAINTENANCE MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN		6.02E-04 1.00E+00 1.00E+00 3.00E-04 1.00E+00	IEV-CCWD IWACV122AO IWACV124AO IDCBSDS1TM RN23MOD5S
4	1.44E-07	12.51	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS CHECK VALVE 122A FAILS TO OPEN CHECK VALVE 124A FAILS TO OPEN IRWST DISCHARGE LINE "B" STRAINER PLUGGED		6.02E-04 1.00E+00 1.00E+00 2.40E-04	IEV-CCWD IWACV122AO IWACV124AO INB-PLUG
5	3.51E-08	3.05	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS CHECK VALVE 122A FAILS TO OPEN CHECK VALVE 124A FAILS TO OPEN FAILURE OF POWER INTERFACE OUTPUT BOARD MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN		6.02E-04 1.00E+00 1.00E+00 5.83E-05 1.00E+00	IEV-CCWD IWACV122AO IWACV124AO TRAEP121BSAX RN23MOD5S
6	2.79E-08	2.42	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS CCF OF ACTUATION LOGIC GROUPS MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN		6.02E-04 4.63E-05 1.00E+00	IEV-CCWD CX-PMA MOD1X RN23MOD5S
7	2.45E-08	2.13	LOSS OF RNS WITH RCS DRAINED INITIATING EVENT OCCURS CHECK VALVE 122A FAILS TO OPEN CHECK VALVE 124A FAILS TO OPEN BUS UNAVAILABLE DUE TO TEST OR CORRECTIVE MAINTENANCE MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN		8.15E-05 1.00E+00 1.00E+00 3.00E-04 1.00E+00	IEV-RNSD IWACV122AO IWACV124AO IDCBSDS1TM RN23MOD5S
8	2.45E-08	2.13	LOSS OF RNS WITH RCS DRAINED INITIATING EVENT OCCURS CHECK VALVE 122A FAILS TO OPEN CHECK VALVE 124A FAILS TO OPEN BUS UNAVAILABLE DUE TO TEST OR CORRECTIVE MAINTENANCE MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN		8.15E-05 1.00E+00 1.00E+00 3.00E-04 1.00E+00	IEV-RNSD IWACV122AO IWACV124AO IDCBSDS1TM RN23MOD5S
9	2.45E-08	2.13	LOSS OF RNS WITH RCS DRAINED INITIATING EVENT OCCURS CHECK VALVE 122A FAILS TO OPEN CHECK VALVE 124A FAILS TO OPEN BUS UNAVAILABLE DUE TO TEST OR CORRECTIVE MAINTENANCE MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN		8.15E-05 1.00E+00 1.00E+00 3.00E-04 1.00E+00	IEV-RNSD IWACV122AO IWACV124AO IDCBSDS1TM RN23MOD5S
10	2.29E-08	1.99	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS CCF OF IRWST INJ MOVs 121A, 121B, & RNS V023		6.02E-04 3.80E-05	IEV-CCWD INX-MV-G01
11	2.29E-08	1.99	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS DUE TO CCF OF THE SQUIB VALVES TO OPERATE		6.02E-04 3.80E-05	IEV-CCWD ADX-EV-SA

Table 54B-7

CASE 3 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER
12	1.96E-08	1.70	LOSS OF RNS WITH RCS DRAINED CHECK VALVE 122A CHECK VALVE 124A IRWST DISCHARGE LINE "B" STRAINER PLUGGED	INITIATING EVENT OCCURS FAILS TO OPEN FAILS TO OPN MOV 023 TO FAIL-TO-OPEN	8.15E-05 1.00E+00 1.00E+00 2.40E-04	IEV-RNSD IWACV122AO IWACV124AO IMB-PLUG
13	1.87E-08	1.62	LOSS OF CCS/SWS WITH RCS DRAINED CCF OF GRAVITY MECHANICAL	INITIATING EVENT OCCURS INJECTION CHECK VALVES TO OPEN FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	6.02E-04 3.10E-05 1.00E+00	IEV-CWMD INX-CV-AO RN23MOD5S
14	1.22E-08	1.06	OVERDRAINING OF RCS DURING DRAIN DOWN TO MID-LOOP OPERATOR FAILS TO ISOLATE IWN-MAN00C MECHANICAL	INITIATING EVENT OCCURS RNS PIPE RUPTURE MOV 023 TO FAIL-TO-OPEN	4.44E-06 5.50E-02 5.00E-02 1.00E+00	IEV-RCS0D RHN-MAN04 IWN-MAN00C RN23MOD5S
15	8.58E-09	.75	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS FAILURE TO RECOVER AC POWER IN 1 HOUR BATTERY DB1 FAILURE OF PMS OUTPUT MECHANICAL	WITH RCS DRAINED UNAVAILABLE LOGIC I/Os MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.20E-03 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 ED1MOD03 PMAMOD11 RN23MOD5S
16	8.31E-09	.72	LOSS OF CCS/SWS WITH RCS DRAINED CCF OF LOGIC GROUP PROCESSING MECHANICAL	INITIATING EVENT OCCURS MOV 023 TO FAIL-TO-OPEN	6.02E-04 1.38E-05 1.00E+00	IEV-CWMD CCK-PMA030X RN23MOD5S
17	7.79E-09	.68	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS FAILURE TO RECOVER AC POWER IN 1 HOUR CCF TO START OF ENGINE-DRIVEN FUEL PUMPS FAILURE OF PMS OUTPUT MECHANICAL	WITH RCS DRAINED UNAVAILABLE LOGIC I/Os MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.00E-03 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 ZOK-PD-ES PMAMOD11 RN23MOD5S
18	7.22E-09	.63	LOSS OF CCS/SWS WITH RCS DRAINED CCF OF STRAINERS IN IRWST TANK	INITIATING EVENT OCCURS	6.02E-04 1.20E-05	IEV-CWMD INX-FL-GP
19	6.62E-09	.58	LOSS OF CCS/SWS WITH RCS DRAINED SOFTWARE CCF OF OUTPUT LOGIC I/Os MECHANICAL	INITIATING EVENT OCCURS MOV 023 TO FAIL-TO-OPEN	6.02E-04 1.10E-05 1.00E+00	IEV-CWMD CCK-PMAMOD1-SW RN23MOD5S
20	4.83E-09	.42	OVERDRAINING OF RCS DURING DRAIN DOWN TO MID-LOOP RHN-MAN04-SUCC OPERATOR FAILS TO OPEN TWO IRWST MOVs MECHANICAL	INITIATING EVENT OCCURS MOV 023 TO FAIL-TO-OPEN	4.44E-06 9.45E-01 1.15E-03 1.00E+00	IEV-RCS0D RHN-MAN04-SUCC IWN-MAN00 RN23MOD5S
21	4.76E-09	.41	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS FAILURE TO RECOVER AC POWER IN 1 HOUR BATTERY DB1 FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING MECHANICAL	WITH RCS DRAINED UNAVAILABLE MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.20E-03 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 ED1MOD03 PMA0301BSA RN23MOD5S
22	4.76E-09	.41	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS FAILURE TO RECOVER AC POWER IN 1 HOUR BATTERY DB1 FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING MECHANICAL	WITH RCS DRAINED UNAVAILABLE MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.20E-03 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 ED1MOD03 PMA0301ASA RN23MOD5S

Table 54B-7

CASE 3 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME			EVENT PROB	IDENTIFIER
23	4.68E-09	.41	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR 4KV BREAKERS TO OPEN LOGIC I/Os FAIL-TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 1.20E-03 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 ECX-CB-GO PMAMOD11 RN23MOD5S
24	4.33E-09	.38	LOSS OF OFFSITE FAILURE TO CCF TO START FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED	4.44E-03 4.20E-01 2.00E-03 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 ZOK-PD-ES PMA0301BSA RN23MOD5S
25	4.33E-09	.38	LOSS OF OFFSITE FAILURE TO CCF TO START FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED	4.44E-03 4.20E-01 2.00E-03 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 ZOK-PD-ES PMA0301ASA RN23MOD5S
26	4.03E-09	.35	LOCA/RNS-V024 CHECK VALVE CHECK VALVE IRWST DISCHARGE	OPENS INITIATING EVENT OCCURS 122A FAILS TO OPEN 124A FAILS TO OPEN LINE "B" STRAINER	WITH RCS FILLED	1.68E-05 1.00E+00 1.00E+00 2.40E-04	IEV-LOCA24ND IWACV122AO IWACV124AO IWB-PLUG
27	3.77E-09	.33	LOSS OF RNS WITH RCS DRAINED CCF OF ACTUATION MECHANICAL	INITIATING EVENT OCCURS LOGIC GROUPS FAILURE CAUSES MOV 023 TO	FAIL-TO-OPEN	8.15E-05 4.63E-05 1.00E+00	IEV-RNSD CCX-PMAMODIX RN23MOD5S
28	3.10E-09	.27	LOSS OF RNS WITH RCS DRAINED CCF OF IRWST INJ MOVs 121A, 121B, & RNS V023	INITIATING EVENT OCCURS		8.15E-05 3.80E-05	IEV-RNSD IWK-MV-G01
29	3.10E-09	.27	LOSS OF RNS WITH RCS DRAINED DUE TO CCF OF THE SQUIB VALVES TO OPERATE	INITIATING EVENT OCCURS		8.15E-05 3.80E-05	IEV-RNSD ADK-EV-SA
30	3.09E-09	.27	LOSS OF OFFSITE OFFSITE SOFTWARE CCF	POWER INITIATING EVENT OCCURS AC POWER RECOVERED IN OF ALL CARDS	WITH RCS DRAINED	4.44E-03 5.80E-01 1.20E-06	IEV-LOSPD SUC-RIS CCX-SFTW
31	2.85E-09	.25	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR 4KV BREAKER TO CLOSE LOGIC I/Os FAIL-TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 7.30E-04 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 ECX-CB-GC PMAMOD11 RN23MOD5S
32	2.71E-09	.24	LOCA/RNS-V024 CHECK VALVE CHECK VALVE IRWST DISCHARGE	OPENS INITIATING EVENT OCCURS 122A FAILS TO OPEN 124A FAILS TO OPEN LINE "B" STRAINER	WITH RCS DRAINED	1.13E-05 1.00E+00 1.00E+00 2.40E-04	IEV-LOCA24D IWACV122AO IWACV124AO IWB-PLUG
33	2.60E-09	.23	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR 4KV BREAKERS TO OPEN DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED	4.44E-03 4.20E-01 1.20E-03 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 ECX-CB-GO PMA0301ASA RN23MOD5S

Table 54B-7

CASE 3 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS	WITH RCS DRAINED	EVENT PROB.	IDENTIFIER
34	2.60E-09	.23	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE UPON MECHANICAL	POWER INITIATING RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKERS TO OPEN DEMAND OF LOGIC GROUP PROCESSING MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 1.20E-03 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 ECX-CB-GO PMA0301BSA RN23MOD5S	
35	2.53E-09	.22	LOSS OF RNS WITH CCF OF GRAVITY MECHANICAL	RCS DRAINED INITIATING EVENT OCCURS INJECTION CHECK VALVES TO OPEN FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	8.15E-05 3.10E-05 1.00E+00	IEV-RNSD IWX-CV-AO RN23MOD5S	
36	2.24E-09	.19	LOSS OF OFFSITE FAILURE TO SOFTWARE CCF	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ALL CARDS	4.44E-03 4.20E-01 1.20E-06	IEV-LOSPD OTH-R1 CCX-SFTW	
37	2.19E-09	.19	LOSS OF CCS/SWS CCF OF ORIFICES	WITH RCS DRAINED INITIATING EVENT OCCURS	6.02E-04 3.63E-06	IEV-CCWD CCX-ORY-SPX	
38	2.12E-09	.18	LOSS OF OFFSITE FAILURE TO BATTERY	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR DB1 UNAVAILABLE	4.44E-03 4.20E-01 2.20E-03	IEV-LOSPD OTH-R1 ED1MOD03	
			FAILURE OF INV.	STATIC SWITCH AND ASSOC.	5.16E-04	IDAMOD05	
			MECHANICAL	FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	1.00E+00	RN23MOD5S	
39	1.92E-09	.17	LOSS OF OFFSITE FAILURE TO CCF TO START	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS	4.44E-03 4.20E-01 2.00E-03	IEV-LOSPD OTH-R1 ZOX-PD-EU	
			FAILURE OF INV.	STATIC SWITCH AND ASSOC.	5.16E-04	IDAMOD05	
			MECHANICAL	FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	1.00E+00	RN23MOD5S	
40	1.92E-09	.17	LOSS OF OFFSITE FAILURE TO PUMP MP 01B	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR DIVERTED FLOW	4.44E-03 4.20E-01 2.44E-02	IEV-LOSPD OTH-R1 SWRBMOD02	
			D/G FAILS TO START & RUN OR	BKR 102 FAILS TO CLOSE	2.02E-02	Z01MOD01	
			FAILURE OF PMS OUTPUT	LOGIC I/Os	2.09E-03	PMAMOD11	
			MECHANICAL	FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	1.00E+00	RN23MOD5S	
41	1.84E-09	.16	LOSS OF CCS/SWS CHECK VALVE	WITH RCS DRAINED INITIATING EVENT OCCURS 122A FAILS TO OPEN	6.02E-04 1.00E+00	IEV-CCWD IWACV122AO	
			CHECK VALVE	124A FAILS TO OPEN	1.00E+00	IWACV124AO	
			CHECK VALVE	122B FAILS TO OPEN	1.75E-03	IWBCV122AO	
			CHECK VALVE	124B FAILS TO OPEN	1.75E-03	IWBBCV124AO	
			MECHANICAL	FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	1.00E+00	RN23MOD5S	
42	1.83E-09	.16	OVERDRAINING OF OPERATOR FAILS	RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT TO ISOLATE RNS PIPE RUPTURE	4.44E-06 5.50E-02 5.00E-02	IEV-RCSOD RHN-MAN04 IWN-MAN0C	
			IWN-MAN0C COND. PROB. OF	RHN-MAN05 (OP. FAILS TO OPEN RNS MOV V023)	1.50E-01	RHN-MAN05C	
43	1.77E-09	.15	LOSS OF CCS/SWS CCF OF THE POWER MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS INTERFACE OUTPUT BOARDS IN PMS FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	6.02E-04 2.94E-06 1.00E+00	IEV-CCWD CCX-EP-SAMX RN23MOD5S	
44	1.71E-09	.15	LOSS OF OFFSITE FAILURE TO COMMON CAUSE	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE STANDBY DG TO RUN	4.44E-03 4.20E-01 4.40E-04	IEV-LOSPD OTH-R1 ZOX-DG-DR	
			FAILURE OF PMS OUTPUT	LOGIC I/Os	2.09E-03	PMAMOD11	
			MECHANICAL	FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	1.00E+00	RN23MOD5S	

Table 54B-7

CASE 3 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER
45	1.59E-09	14	LOSS OF OFFSITE FAILURE TO D/G FAILS TO FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR START & RUN OR BKR 102 FAILS TO CLOSE START & RUN OR BKR 202 FAILS TO CLOSE PMS OUTPUT LOGIC I/Os FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.02E-02 2.02E-02 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 Z01MOD01 Z02MOD01 PMAMOD11 RN23MOD55
46	1.58E-09	14	LOSS OF CCS/SWS CCF OF PRESSURE	WITH RCS DRAINED INITIATING EVENT OCCURS TRANSMITTERS	6.02E-04 2.63E-06	IEV-CCWD CCX-XMTRX
47	1.58E-09	14	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR 4KV BREAKER TO CLOSE DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 7.30E-04 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 ECX-CB-GC PMA0301ASA RN23MOD55
48	1.58E-09	14	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR 4KV BREAKER TO CLOSE DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 7.30E-04 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 ECX-CB-GC PMA0301gSA RN23MOD55
49	1.30E-09	11	LOSS OF OFFSITE FAILURE TO BATTERY LOSS OF DIST. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR DB1 UNAVAILABLE PANEL OR BREAKER A07 SPURIOUSLY FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.25E-03 3.17E-04 1.00E+00	IEV-LOSPD OTH-R1 EDIMOD03 IDAMOD04 RN23MOD55
50	1.24E-09	11	LOSS OF OFFSITE FAILURE TO FIXED FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR COMPONENTS FAILURE PMS OUTPUT LOGIC I/Os FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 3.17E-04 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 EDIMOD113 PMAMOD11 RN23MOD55
51	1.24E-09	11	LOSS OF OFFSITE FAILURE TO FIXED FAILURE OF MECHANICAL	POWER INITIAT ~ EVENT OCCURS RECOVER AC POWER IN 1 HOUR COMPONENTS FAILURE PMS OUTPUT LOGIC I/Os FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 3.17E-04 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 EDIMOD11 PMAMOD11 RN23MOD55
52	1.23E-09	11	LOSS OF OFFSITE FAILURE TO BATTERY BUS UNAVAILABLE MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR DB1 UNAVAILABLE DUE TO TEST OR CORRECTIVE FAILURE CAUSES MOV 023 TO MAINTENANCE FAIL-TO-OPEN	4.44E-03 4.20E-01 2.20E-03 3.00E-04 1.00E+00	IEV-LOSPD OTH-R1 EDIMOD03 IDABSDSDTWN RN23MOD55
53	1.20E-09	10	LOSS OF OFFSITE FAILURE TO PUMP 01B FAILS & D/G FAILS TO FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR ST CK V007B & C B FTC & RE FTC & CB EBS221 SPO START & RUN OR BKR 102 FAILS TO CLOSE PMS OUTPUT LOGIC I/Os FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 1.53E-02 2.02E-02 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 RNBMOD07S Z01MOD01 PMAMOD11 RN23MOD55
54	1.18E-09	10	LOSS OF OFFSITE FAILURE TO CCF TO START LOSS OF DIST. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS PANEL OR BREAKER A07 SPURIOUSLY FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.00E-03 3.17E-04 1.00E+00	IEV-LOSPD OTH-R1 Z0X-PD-ES IDAMOD04 RN23MOD55

50

Table 54B-7

CASE 3 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME			EVENT PROB.	IDENTIFIER
55	1.17E-09	.10	LOSS OF OFFSITE FAILURE TO PUMP MP 01B BREAKER 100 FAILURE OF PMS OUTPUT MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR FAILS TO OPEN LOGIC I/Os MOV 023 TO	WITH RCS DRAINED DIVERTED FLOW [#3,5] FAIL-TO-OPEN	4.44E-03 4.20E-01 2.44E-02 1.23E-02 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 SWBMOD02 EC1CB100VO PMA MOD11 RN23MOD55
56	1.15E-09	.10	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE OF INV. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR 4KV BREAKERS TO STATIC SWITCH AND ASSOC. FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED OPEN BREAKERS FAIL-TO-OPEN	4.44E-03 4.20E-01 1.20E-03 5.16E-04 1.00E+00	IEV-LOSPD OTH-R1 ECX-CB-00 IDAMOD65 RN23MOD55
57	1.12E-09	.10	LOSS OF RNS WITH CCF OF LOGIC MECHANICAL	RCS DRAINED GROUP PROCESSING FAILURE CAUSES MOV 023 TO	INITIATING EVENT OCCURS FAIL-TO-OPEN	8.15E-05 1.38E-05 1.00E+00	IEV-RNSD CCK-PMA030X RN23MOD55
58	1.12E-09	.10	LOSS OF OFFSITE FAILURE TO CCF TO START BUS UNAVAILABLE MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS DUE TO TEST OR CORRECTIVE FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED MAINTENANCE FAIL-TO-OPEN	4.44E-03 4.20E-01 2.00E-03 3.00E-04 1.00E+00	IEV-LOSPD OTH-R1 ZOM-PD-ES IDABSD1TM RN23MOD55
59	1.09E-09	.09	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE OF PMS OUTPUT MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE STANDBY DG TO START LOGIC I/Os MOV 023 TO	WITH RCS DRAINED START FAIL-TO-OPEN	4.44E-03 4.20E-01 2.80E-04 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 ZOK-DG-DS PMA MOD11 RN23MOD55
60	1.07E-09	.09	LOSS OF OFFSITE FAILURE TO PUMP MP 01B D/G FAILS TO FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR START & RUN OR DEMAND OF LOGIC FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED DIVERTED FLOW BKR 102 FAILS TO CLOSE GROUP PROCESSING FAIL-TO-OPEN	4.44E-03 4.20E-01 2.44E-02 2.02E-02 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 SWBMOD02 Z01MOD01 PMA0301ASA RN23MOD55
61	1.07E-09	.09	LOSS OF OFFSITE FAILURE TO PUMP MP 01B D/G FAILS TO FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR START & RUN OR DEMAND OF LOGIC FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED DIVERTED FLOW BKR 102 FAILS TO CLOSE GROUP PROCESSING FAIL-TO-OPEN	4.44E-03 4.20E-01 2.44E-02 2.02E-02 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 SWBMOD02 Z01MOD01 PMA0301BSA RN23MOD55
62	1.06E-09	.09	LOSS OF CCS/SWS FAILURE OF UNAVAILABILITY MECHANICAL	WITH RCS DRAINED PMS OUTPUT OF BUS ECS ES 1 FAILURE CAUSES	INITIATING EVENT OCCURS LOGIC I/Os L/E TO UNSCHEDUL MAINTENANCE MOV 023 TO	6.02E-04 6.53E-04 2.70E-03 1.00E+00	IEV-CCWD PMA MOD11X EC1BS001TM RN23MOD55
63	1.06E-09	.09	LOSS OF CCS/SWS FAILURE OF BUS UNAVAILABLE MECHANICAL	WITH RCS DRAINED PMS OUTPUT DUE TO FAILURE CAUSES	INITIATING EVENT OCCURS LOGIC I/Os UNSCHEDULED MAINTENANCE MOV 023 TO	6.02E-04 6.53E-04 2.70E-03 1.00E+00	IEV-CCWD PMA MOD11X EC1BS012TM RN23MOD55
64	1.06E-09	.09	LOSS OF CCS/SWS FAILURE OF BUS UNAVAILABLE MECHANICAL	WITH RCS DRAINED PMS OUTPUT DUE TO FAILURE CAUSES	INITIATING EVENT OCCURS LOGIC I/Os UNSCHEDULED MAINTENANCE MOV 023 TO	6.02E-04 6.53E-04 2.70E-03 1.00E+00	IEV-CCWD PMA MOD11X EC1BS121TM RN23MOD55

Table 54B-7

CASE 3 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME			EVENT PROB	IDENTIFIER
65	1.01E-09	.09	OVERDRAINING OF RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT	RHN-MAN04-SUCC		4.44E-06	IEV-RCS0D
			CHECK VALVE 122A	FAILS TO OPEN		9.45E-01	RHN-MAN04-SUCC
			CHECK VALVE 124A	FAILS TO OPEN		1.00E+00	IWACV122AO
			IRWST DISCHARGE LINE "B"	STRAINER PLUGGED		1.00E+00	IWACV124AO
						2.40E-04	IWB-PLUG
66	9.86E-10	.09	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS	WITH RCS DRAINED		4.44E-03	IEV-LOSPD
			FAILURE TO RECOVER AC POWER IN 1 HOUR			4.20E-01	OTH-R1
			BATTERY DB1 UNAVAILABLE			2.20E-03	EDIMOD03
			CHECK VALVE 122A FAILS TO OPEN			1.00E+00	IWACV122AO
			CHECK VALVE 124A FAILS TO OPEN			1.00E+00	IWACV124AO
			IRWST DISCHARGE LINE "B"	STRAINER PLUGGED		2.40E-04	IWB-PLUG
67	9.78E-10	.08	LOSS OF RNS WITH RCS DRAINED	INITIATING EVENT OCCURS		8.15E-05	IEV-RNSD
			CCF OF STRAINERS IN IRWST TANK			1.20E-05	IWX-FL-GP
68	9.68E-10	.08	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS	WITH RCS DRAINED		4.44E-03	IEV-LOSPD
			FAILURE TO RECOVER AC POWER IN 1 HOUR			4.20E-01	OTH-R1
			BREAKER 100 FAILS TO OPEN		[#3.5]	1.23E-02	EC1CB100VO
			D/G FAILS TO START & RUN OR BKR 202 FAILS TO CLOSE			2.02E-02	Z02MOD01
			FAILURE OF PMS OUTPUT LOGIC I/Os			2.09E-03	PMA0D11
			MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN			1.00E+00	RN23MOD5S
69	9.68E-10	.08	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS	WITH RCS DRAINED		4.44E-03	IEV-LOSPD
			FAILURE TO RECOVER AC POWER IN 1 HOUR			4.20E-01	OTH-R1
			D/G FAILS TO START & RUN OR BKR 102 FAILS TO CLOSE		[#5.3]	2.02E-02	Z01MOD01
			BREAKER 200 FAILS TO OPEN			1.23E-02	EC2CB200VO
			PMS OUTPUT LOGIC I/Os			2.09E-03	PMA0D11
			MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN			1.00E+00	RN23MOD5S
70	9.52E-10	.08	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS	WITH RCS DRAINED		4.44E-03	IEV-LOSPD
			FAILURE TO RECOVER AC POWER IN 1 HOUR			4.20E-01	OTH-R1
			COMMON CAUSE FAILURE STANDBY DG TO RUN			4.40E-04	ZCX-ING-DR
			FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING			1.16E-03	PMA0301BSA
			MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN			1.00E+00	RN23MOD5S
71	9.52E-10	.08	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS	WITH RCS DRAINED		4.44E-03	IEV-LOSPD
			FAILURE TO RECOVER AC POWER IN 1 HOUR			4.20E-01	OTH-R1
			COMMON CAUSE FAILURE STANDBY DG TO RUN			4.40E-04	ZCX-DG-DR
			FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING			1.16E-03	PMA0301ASA
			MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN			1.00E+00	RN23MOD5S
72	8.97E-10	.08	LOSS OF RNS WITH RCS DRAINED	INITIATING EVENT OCCURS		8.15E-05	IEV-RNSE
			SOFTWARE CCF OF OUTPUT LOGIC I/Os			1.10E-05	CCX-PMA0D1-SW
			MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN			1.00E+00	RN23MOD5S
73	8.83E-10	.08	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS	WITH RCS DRAINED		4.44E-03	IEV-LOSPD
			FAILURE TO RECOVER AC POWER IN 1 HOUR			4.20E-01	OTH-R1
			D/G FAILS TO START & RUN OR BKR 102 FAILS TO CLOSE			2.02E-02	Z01MOD01
			D/G FAILS TO START & RUN OR BKR 202 FAILS TO CLOSE			2.02E-02	Z02MOD01
			FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING			1.16E-03	PMA0301ASA
			MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN			1.00E+00	RN23MOD5S
74	8.83E-10	.08	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS	WITH RCS DRAINED		4.44E-03	IEV-LOSPD
			FAILURE TO RECOVER AC POWER IN 1 HOUR			4.20E-01	OTH-R1
			D/G FAILS TO START & RUN OR BKR 102 FAILS TO CLOSE			2.02E-02	Z01MOD01
			D/G FAILS TO START & RUN OR BKR 202 FAILS TO CLOSE			2.02E-02	Z02MOD01
			FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING			1.16E-03	PMA0301BSA
			MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN			1.00E+00	RN23MOD5S

Table 54B-7

CASE 3 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS	EVENT PROB	IDENTIFIER
75	8.39E-10	.07	LOSS OF CCS/SWS WITH RCS DRAINED FAILURE OF INV.. STATIC SWITCH AND ASSOC. BUS UNAVAILABLE DUE TO UNSCHEDULED MAINTENANCE MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	INITIATING EVENT OCCURS BREAKERS MAINTENANCE FAIL-TO-OPEN	6.02E-04 5.16E-04 2.70E-03 1.00E+00	IEV-COWD IDAMOD05 EC1BS121TM RN23MOD55
76	8.39E-10	.07	LOSS OF CCS/SWS WITH RCS DRAINED FAILURE OF INV.. STATIC SWITCH AND ASSOC. BUS UNAVAILABLE DUE TO UNSCHEDULED MAINTENANCE MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	INITIATING EVENT OCCURS BREAKERS MAINTENANCE FAIL-TO-OPEN	6.02E-04 5.16E-04 2.70E-03 1.00E+00	IEV-COWD IDAMOD05 EC1BS012TM RN23MOD55
77	8.39E-10	.07	LOSS OF CCS/SWS WITH RCS DRAINED FAILURE OF INV.. STATIC SWITCH AND ASSOC. UNAVAILABILITY OF BUS ECS ES 1 DUE TO UNSCHEDUL MAINTENANCE MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	INITIATING EVENT OCCURS BREAKERS MAINTENANCE FAIL-TO-OPEN	6.02E-04 5.16E-04 2.70E-03 1.00E+00	IEV-COWD IDAMOD05 EC1BS001TM RN23MOD55
78	8.19E-10	.07	LOSS OF OFFSITE FAILURE TO PUMP SUBLOOP B D/G FAILS TO FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR HARDWARE FAILURE OR DIVERTED FLOW START & RUN OR BKR 102 FAILS TO CLOSE PMS OUTPUT LOGIC I/Os FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED 4.44E-03 4.20E-01 1.04E-02 2.02E-02 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 CCBMOD01S Z01MOD01 PMAMOD11 RN23MOD55
79	7.33E-10	.06	LOSS OF OFFSITE FAILURE TO PUMP DIB FAILS & BREAKER 100 FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR ST CK V007B & C B FTC & RE FTC & CB ECS221 SPO FAILS TO OPEN [#3.5] PMS OUTPUT LOGIC I/Os FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED 4.44E-03 4.20E-01 1.53E-02 1.23E-02 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 RNBMOD07S EC1CB100VO PMAMOD11 RN23MOD55
80	7.24E-10	.06	OVERDRAINING OF RHN-MAN04-SUCC OPERATOR FAILS COND. PROB. OF	RCS DURING DRAIN DOWN TO MID-LOOP TO OPEN TWO IRNST MOVs FAILS TO OPEN RNS MOV VC231	INITIATING EVENT 4.44E-06 9.45E-01 1.15E-03 1.50E-01	IEV-RCS00D RHN-MAN04-SUCC IWN-MAN00 RHN-MAN05C
81	7.22E-10	.06	LOSS OF CCS/SWS SOFTWARE CCF	WITH RCS DRAINED OF ALL CARDS	INITIATING EVENT OCCURS 4.02E-04 1.20E-06	IEV-COWD CCX-SFTW
82	7.09E-10	.06	LOSS OF OFFSITE FAILURE TO COMMON CAUSE LOSS OF DIST. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKERS TO OPEN PANEL OR BREAKER A07 SPURIOUSLY OPENS FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED 4.44E-03 4.20E-01 1.20E-03 3.17E-04 1.00E+00	IEV-LOSPD OTH-R1 ECX-CB-G0 IDAMOD04 RN23MOD55
83	7.02E-10	.06	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE OF INV.. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKER TO CLOSE STATIC SWITCH AND ASSOC. FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED 4.44E-03 4.20E-01 7.30E-04 5.16E-04 1.00E+00	IEV-LOSPD OTH-R1 ECX-CB-GC IDAMOD05 RN23MOD55
84	6.86E-10	.06	LOSS OF OFFSITE FAILURE TO FIXED FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR COMPONENTS FAILURE DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED 4.44E-03 4.20E-01 3.17E-04 1.76E-03 4.00E+00	IEV-LOSPD OTH-R1 ED1MOD11 PMA0301ASA RN23MOD55
85	6.86E-10	.06	LOSS OF OFFSITE FAILURE TO FIXED	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR COMPONENTS FAILURE	WITH RCS DRAINED 4.44E-03 4.20E-01 3.17E-04	IEV-LOSPD OTH-R1 ED1MOD113

Table 54B-7

CASE 3 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	FAILURE UPON	DEMAND OF LOGIC	GROUP PROCESSING		EVENT PROB	IDENTIFIER
			MECHANICAL	FAILURE CAUSES	MOV 023 TO	FAIL-TO-OPEN		1.15E-03	PMA0301ASA
								1.00E+00	RN23MOD5S
86	6.86E-10	.06	LOSS OF OFFSITE FAILURE TO FIXED	POWER INITIATING RECOVER AC POWER IN 1 HOUR	EVENT OCCURS	WITH RCS DRAINED	4.44E-03	IEV-LOSPD	
			FAILURE UPON MECHANICAL	COMPONENTS	FAILURE		4.20E-01	OTH-R1	
				DEMAND OF LOGIC	GROUP PROCESSING		3.17E-04	ED1MOD11	
				FAILURE CAUSES	MOV 023 TO	FAIL-TO-OPEN	1.16E-03	PMA0301BSA	
							1.00E+00	RN23MOD5S	
87	6.86E-10	.06	LOSS OF OFFSITE FAILURE TO FIXED	POWER INITIATING RECOVER AC POWER IN 1 HOUR	EVENT OCCURS	WITH RCS DRAINED	4.44E-03	IEV-LOSPD	
			FAILURE UPON MECHANICAL	COMPONENTS	FAILURE		4.20E-01	OTH-R1	
				DEMAND OF LOGIC	GROUP PROCESSING		3.17E-04	ED1MOD113	
				FAILURE CAUSES	MOV 023 TO	FAIL-TO-OPEN	1.16E-03	PMA0301BSA	
							1.00E+00	RN23MOD5S	
88	6.71E-10	.06	LOSS 2 OFFSITE FAILURE TO COMMON CAUSE	POWER INITIATING RECOVER AC POWER IN 1 HOUR	EVENT OCCURS	WITH RCS DRAINED	4.44E-03	IEV-LOSPD	
			BUS UNAVAILABLE	FAILURE	4KV BREAKERS TO OPEN		4.20E-01	OTH-R1	
			MECHANICAL	DUE TO TEST OR	CORRECTIVE MAINTENANCE		1.20E-03	ECX-CB-GO	
				FAILURE CAUSES	MOV 023 TO	FAIL-TO-OPEN	3.00E-04	IDABSDS1TM	
							1.00E+00	RN23MOD5S	
89	6.69E-10	.06	LOSS OF OFFSITE FAILURE TO PUMP 01B FAILS & D/G FAILS TO	POWER INITIATING RECOVER AC POWER IN 1 HOUR	EVENT OCCURS	WITH RCS DRAINED	4.44E-03	IEV-LOSPD	
			FAILURE UPON MECHANICAL	ST CK V007B & C B FTC & RE FTC & CB ECS221 SPO			4.20E-01	OTH-R1	
				START & RUN OR	BKR 102 FAILS TO CLOSE		1.53E-02	RNBMOD07S	
				DEMAND OF LOGIC	GROUP PROCESSING		2.02E-02	Z01MOD01	
				FAILURE CAUSES	MOV 023 TO	FAIL-TO-OPEN	1.16E-03	PMA0301BSA	
							1.00E+00	RN23MOD5S	
90	6.69E-10	.06	LOSS OF OFFSITE FAILURE TO PUMP 01B FAILS & D/G FAILS TO	POWER INITIATING RECOVER AC POWER IN 1 HOUR	EVENT OCCURS	WITH RCS DRAINED	4.44E-03	IEV-LOSPD	
			FAILURE UPON MECHANICAL	ST CK V007B & C B FTC & RE FTC & CB ECS221 SPO			4.20E-01	OTH-R1	
				START & RUN OR	BKR 102 FAILS TO CLOSE		1.53E-02	RNBMOD07S	
				DEMAND OF LOGIC	GROUP PROCESSING		2.02E-02	Z01MOD01	
				FAILURE CAUSES	MOV 023 TO	FAIL-TO-OPEN	1.16E-03	PMA0301ASA	
							1.00E+00	RN23MOD5S	
91	6.49E-10	.06	LOSS OF OFFSITE FAILURE TO PUMP MP 01B BREAKER 100	POWER INITIATING RECOVER AC POWER IN 1 HOUR	EVENT OCCURS	WITH RCS DRAINED	4.44E-03	IEV-LOSPD	
			FAILURE UPON MECHANICAL	SEGMENT HARDWARE FAILURE OR FAILS TO OPEN		DIVERTED FLOW	4.20E-01	OTH-R1	
				DEMAND OF LOGIC	GROUP PROCESSING	[#3.5]	2.44E-02	SWRMOD02	
				FAILURE CAUSES	MOV 023 TO	FAIL-TO-OPEN	1.23E-02	EC1CB100V0	
							1.16E-03	PMA0301ASA	
							1.00E+00	RN23MOD5S	
92	6.49E-10	.06	LOSS OF OFFSITE FAILURE TO PUMP MP 01B BREAKER 100	POWER INITIATING RECOVER AC POWER IN 1 HOUR	EVENT OCCURS	WITH RCS DRAINED	4.44E-03	IEV-LOSPD	
			FAILURE UPON MECHANICAL	SEGMENT HARDWARE FAILURE OR FAILS TO OPEN		DIVERTED FLOW	4.20E-01	OTH-R1	
				DEMAND OF LOGIC	GROUP PROCESSING	[#3.5]	2.44E-02	SWRMOD02	
				FAILURE CAUSES	MOV 023 TO	FAIL-TO-OPEN	1.23E-02	EC1CB100V0	
							1.16E-03	PMA0301BSA	
							1.00E+00	RN23MOD5S	
93	6.11E-10	.05	LOSS OF CCS/SWS CHECK VALVE	WITH RCS DRAINED	INITIATING EVENT OCCURS		6.02E-04	IEV-CWCD	
			122A	FAILS TO OPEN			1.00E+00	IWACV122AO	
			124A	FAILS TO OPEN			1.00E+00	IWACV124AO	
			122B	FAILS TO OPEN			1.75E-03	IWBKV122AO	
			125B	FAILS TO OPEN			5.80E-04	IWBKV125AO	
			MECHANICAL	FAILURE CAUSES	MOV 023 TO	FAIL-TO-OPEN	1.00E+00	RN23MOD5S	
94	6.11E-10	.05	LOSS OF CCS/SWS CHECK VALVE	WITH RCS DRAINED	INITIATING EVENT OCCURS		6.02E-04	IEV-CWCD	
			122A	FAILS TO OPEN			1.00E+00	IWACV122AO	
			124A	FAILS TO OPEN			1.00E+00	IWACV124AO	

Table 54B-7

CASE 3 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME			EVENT PROB.	IDENTIFIER
			CHECK VALVE 123B	FAILS TO OPEN		5.80E-04	IWBCV123AO
			CHECK VALVE 124B	FAILS TO OPEN		1.75E-03	IWBCV124AO
			MECHANICAL FAILURE CAUSES	MOV 023 TO FAIL-TO-OPEN		1.00E+00	RN23MOD5S
95	6.06E-10	.05	LOSS OF OFFSITE FAILURE TO RECOVER AC POWER IN 1 HOUR	POWER INITIATING EVENT OCCURS WITH RCS DRAINED	4.44E-03	IEV-LOSPD	
			COMMON CAUSE FAILURE	STANDBY DG TO START	4.20E-01	OTH-R1	
			FAILURE UPON MECHANICAL	DEMAND OF LOGIC GROUP PROCESSING	2.80E-04	Z0X-DG-DS	
			FAILURE CAUSES	MOV 023 TO FAIL-TO-OPEN	1.16E-03	PMA0301ASA	
					1.00E+00	RN23MOD5S	
96	6.06E-10	.05	LOSS OF OFFSITE FAILURE TO RECOVER AC POWER IN 1 HOUR	POWER INITIATING EVENT OCCURS WITH RCS DRAINED	4.44E-03	IEV-LOSPD	
			COMMON CAUSE FAILURE	STANDBY DG TO START	4.20E-01	OTH-R1	
			FAILURE UPON MECHANICAL	DEMAND OF LOGIC GROUP PROCESSING	2.80E-04	Z0X-DG-DS	
			FAILURE CAUSES	MOV 023 TO FAIL-TO-OPEN	1.16E-03	PMA0301BSA	
					1.00E+00	RN23MOD5S	
97	5.90E-10	.05	LOSS OF OFFSITE FAILURE TO RECOVER AC POWER IN 1 HOUR	POWER INITIATING EVENT OCCURS WITH RCS DRAINED	4.44E-03	IEV-LOSPD	
			BREAKER 100 FAILS TO OPEN	[#3.5]	4.20E-01	OTH-R1	
			BREAKER 200 FAILS TO OPEN	[#5.3]	1.23E-02	EC1CB100VO	
			FAILURE OF PMS OUTPUT	LOGIC I/Os	1.23E-02	EC2CB200VO	
			MECHANICAL FAILURE CAUSES	MOV 023 TO FAIL-TO-OPEN	2.09E-03	PMAMOD11	
					1.00E+00	RN23MOD5S	
98	5.79E-10	.05	LOSS OF OFFSITE FAILURE TO RECOVER AC POWER IN 1 HOUR	POWER INITIATING EVENT OCCURS WITH RCS DRAINED	4.44E-03	IEV-LOSPD	
			BATTERY DB1 UNAVAILABLE		4.20E-01	OTH-R1	
			CCF OF OUTPUT LOGIC I/O BOARDS		2.20E-03	ED1MOD03	
			MECHANICAL FAILURE CAUSES	MOV 023 TO FAIL-TO-OPEN	1.41E-04	CCX-PMAMOD1	
					1.00E+00	RN23MOD5S	
99	5.50E-10	.05	LOSS OF OFFSITE FAILURE TO RECOVER AC POWER IN 1 HOUR	POWER INITIATING EVENT OCCURS WITH RCS DRAINED	4.44E-03	IEV-LOSPD	
			FAILURE OF PLS OUTPUT		4.20E-01	OTH-R1	
			CCF OF OUTPUT LOGIC I/O Boards		2.09E-03	PLSMOD11	
			MECHANICAL FAILURE CAUSES	MOV 023 TO FAIL-TO-OPEN	1.41E-04	CCX-PMAMOD1	
					1.00E+00	RN23MOD5S	
100	5.37E-10	.05	LOSS OF OFFSITE FAILURE TO RECOVER AC POWER IN 1 HOUR	POWER INITIATING EVENT OCCURS WITH RCS DRAINED	4.44E-03	IEV-LOSPD	
			D/G FAILS TO START & RUN OR BKR 102 FAILS TO CLOSE		4.20E-01	OTH-R1	
			BREAKER 200 FAILS TO OPEN	[#5.3]	2.02E-02	Z01MOD01	
			FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING		1.23E-02	EC2CB200VO	
			MECHANICAL FAILURE CAUSES	MOV 023 TO FAIL-TO-OPEN	1.16E-03	PMA0301ASA	
					1.00E+00	RN23MOD5S	
101	5.37E-10	.05	LOSS OF OFFSITE FAILURE TO RECOVER AC POWER IN 1 HOUR	POWER INITIATING EVENT OCCURS WITH RCS DRAINED	4.44E-03	IEV-LOSPD	
			BREAKER 100 FAILS TO OPEN	[#3.5]	4.20E-01	OTH-R1	
			D/G FAILS TO START & RUN OR BKR 202 FAILS TO CLOSE		1.23E-02	EC1CB100VO	
			FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING		2.02E-02	Z02MOD01	
			MECHANICAL FAILURE CAUSES	MOV 023 TO FAIL-TO-OPEN	1.16E-03	PMA0301BSA	
					1.00E+00	RN23MOD5S	
102	5.37E-10	.05	LOSS OF OFFSITE FAILURE TO RECOVER AC POWER IN 1 HOUR	POWER INITIATING EVENT OCCURS WITH RCS DRAINED	4.44E-03	IEV-LOSPD	
			D/G FAILS TO START & RUN OR BKR 102 FAILS TO CLOSE		4.20E-01	OTH-R1	
			BREAKER 200 FAILS TO OPEN	[#5.3]	2.02E-02	Z01MOD01	
			FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING		1.23E-02	EC2CB200VO	
			MECHANICAL FAILURE CAUSES	MOV 023 TO FAIL-TO-OPEN	1.16E-03	PMA0301BSA	
					1.00E+00	RN23MOD5S	

Table 54B-7

CASE 3 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME			EVENT PROB	IDENTIFI...3
103	5.37E-10	.05	LOSS OF OFFSITE FAILURE TO RECOVER AC POWER IN 1 HOUR BREAKER 100 FAILS TO OPEN D/G FAILS TO START & RUN OR FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR BKR 202 FAILS TO CLOSE GROUP PROCESSING DEMAND OF LOGIC FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED [#3.5] FAIL-TO-OPEN	4.44E-03 4.20E-01 1.23E-02 2.02E-02 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 EC1CB100V0 Z02MOD01 PMA0301ASA RN23MOD5S
104	5.26E-10	.05	LOSS OF OFFSITE CCF TO START CCF OF OUTPUT MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS LOGIC I/O BOARDS FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED FAIL-TO-OPEN	4.44E-03 4.20E-01 2.00E-03 1.41E-04 1.00E+00	IEV-LOSPD OTH-R1 Z0X-PD-ES CCX-PMANOD1 RN23MOD5S
105	5.23E-10	.05	LOCA/RNS-V024 CCF OF ACTUATION MECHANICAL	OPENS INITIATING EVENT OCCURS LOGIC GROUPS FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED FAIL-TO-OPEN	1.13E-05 4.63E-05 1.00E+00	IEV-LOCA24D CCX-PMANOD1X RN23MOD5S
106	5.21E-10	.05	LOCA/RNS-V024 CCF OF GRAVITY	OPENS INITIATING EVENT OCCURS INJECTION CHECK VALVES TO OPEN	WITH RCS FILLED	1.68E-05 3.10E-05	IEV-LOCA24ND INX-CV-AO
107	5.15E-10	.04	LOSS OF CCS/SWS LOSS OF DIST. UNAVAILABILITY MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS PANEL OR BREAKER A07 SPURIOUSLY OF BUS ECS ES 1 DUE TO UNSCHEDUL FAILURE CAUSES MOV 023 TO	FAIL-TO-OPEN	6.02E-04 3.17E-04 2.70E-03 1.00E+00	IEV-CCWD IDAMOD04 EC1BS001TM RN23MOD5S
108	5.15E-10	.04	LOSS OF CCS/SWS LOSS OF DIST. BUS UNAVAILABLE MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS PANEL OR BREAKER A07 SPURIOUSLY DUE TO UNSCHEDULED FAILURE CAUSES MOV 023 TO	FAIL-TO-OPEN	6.02E-04 3.17E-04 2.70E-03 1.00E+00	IEV-CCWD IDAMOD04 EC1BS121TM RN23MOD5S
109	5.15E-10	.04	LOSS OF CCS/SWS LOSS OF DIST. BUS UNAVAILABLE MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS PANEL OR BREAKER A07 SPURIOUSLY DUE TO UNSCHEDULED FAILURE CAUSES MOV 023 TO	FAIL-TO-OPEN	6.02E-04 3.17E-04 2.70E-03 1.00E+00	IEV-CCWD IDAMOD04 EC1BS012TM RN23MOD5S
110	5.07E-10	.04	LOSS OF OFFSITE FAILURE TO CCF TO RUN OF FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR ENGINE-DRIVEN FUEL PUMPS PMS OUTPUT LOGIC I/Os FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED FAIL-TO-OPEN	4.44E-03 4.20E-01 1.30E-04 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 Z0X-PD-ER PMANOD11 RN23MOD5S
111	4.99E-10	.04	LOSS OF OFFSITE FAILURE TO PUMP SUBLOOP B BREAKER 100 FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR HARDWARE FAILURE OR DIVERTED FLOW FAILS TO OPEN PMS OUTPUT LOGIC I/Os FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED [#3.5] FAIL-TO-OPEN	4.44E-03 4.20E-01 1.04E-02 1.23E-02 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 CCBMOD001S EC1CB100V0 PMANOD11 RN23MOD5S
112	4.88E-10	.04	LOSS OF CCS/SWS BUS UNAVAILABLE BUS UNAVAILABLE MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS DUE TO TEST OR CORRECTIVE MAINTENANCE DUE TO UNSCHEDULED MAINTENANCE FAILURE CAUSES MOV 023 TO	FAIL-TO-OPEN	6.02E-04 3.00E-04 2.70E-03 1.00E+00	IEV-CCWD IDABSDS1TM EC1BS121TM RN23MOD5S
113	4.88E-10	.04	LOSS OF CCS/SWS BUS UNAVAILABLE BUS UNAVAILABLE MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS DUE TO TEST OR CORRECTIVE MAINTENANCE DUE TO UNSCHEDULED MAINTENANCE FAILURE CAUSES MOV 023 TO	FAIL-TO-OPEN	6.02E-04 3.00E-04 2.70E-03 1.00E+00	IEV-CCWD IDABSDS1TM EC1BS012TM RN23MOD5S

Table 54B-7

CASE 3 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER
114	4.88E-10	.04	LOSS OF CCS/SWS BUS UNAVAILABLE UNAVAILABILITY MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS DUE TO TEST OR CORRECTIVE MAINTENANCE OF BUS 2CS ES 1 DUE TO UNSCHEDUL MAINTENANCE FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	6.02E-04 3.00E-04 2.70E-03 1.00E+00	IEV-CCWD IDABSDS1TM EC1RS001TM RN23MOD5S
115	4.74E-10	.04	LOSS OF OFFSITE FAILURE TO PUMP MP 01B D/G FAILS TO FAILURE OF INV. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR DIVERTED FLOW START & RUN OR BKR 102 FAILS TO CLOSE STATIC SWITCH AND ASSOC FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.44E-02 2.02E-02 5.16E-04 1.00E+00	IEV-LOSPD OTH-R1 SMBMOD02 Z0IMOD01 IDAMOD05 RN23MOD5S
116	4.54E-10	.04	LOSS OF OFFSITE FAILURE TO PUMP SUBLOOP B D/G FAILS TO FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR HARDWARE FAILURE OR DIVERTED FLOW START & RUN OR BKR 102 FAILS TO CLOSE DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 1.04E-02 2.02E-02 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 CCBMOD01S Z0IMOD01 PMA0301ASA RN23MOD5S
117	4.54E-10	.04	LOSS OF OFFSITE FAILURE TO PUMP SUBLOOP B D/G FAILS TO FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR HARDWARE FAILURE OR DIVERTED FLOW START & RUN OR BKR 102 FAILS TO CLOSE DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 1.04E-02 2.02E-02 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 CCBMOD01S Z0IMOD01 PMA0301BSA RN23MOD5S
118	4.32E-10	.04	LOSS OF OFFSITE FAILURE TO COMMON CAUSE LOSS OF DIST. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKER TO CLOSE PANEL OR BREAKER A07 SPURIOUSLY OPENS FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 7.30E-04 3.17E-04 1.00E+00	IEV-LOSPD OTH-R1 ECX-CB-GC IDAMOD04 RN23MOD5S
119	4.29E-10	.04	LOCA/RNS-V024 DUE TO CCF OF	OPENS INITIATING EVENT OCCURS THE SQUIB VALVES TO OPERATE	1.13E-05 3.80E-05	IEV-LOCA24D ADX-EV-SA
120	4.29E-10	.04	LOCA/RNS-V024 CCF OF IRWST 1KJ	OPENS INITIATING EVENT OCCURS MOVES 121A, 121B, & RNS V023	1.13E-05 3.80E-05	IEV-LOCA24D IWX-MV-G01
121	4.23E-10	.04	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE OF INV. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE STANDBY DG TO RUN STATIC SWITCH AND ASSOC FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 4.40E-04 5.16E-04 1.00E+00	IEV-LOSPD OTH-H1 Z0X-DG-DR IDAMOD05 RN23MOD5S
122	4.08E-10	.04	LOSS OF OFFSITE FAILURE TO COMMON CAUSE BUS UNAVAILABLE MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKER TO CLOSE DUE TO TEST OR CORRECTIVE MAINTENANCE FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 7.30E-04 3.00E-04 1.00E+00	IEV-LOSPD OTH-R1 ECX-CB-GC IDABSDS1TM RN23MOD5S
123	4.07E-10	.04	LOSS OF OFFSITE FAILURE TO PUMP 01B FAILS & BREAKER 100 FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR ST CK V007B & C B FTC & RE FTC & CB BCS221 SPO FAILS TO OPEN (#3, 5) DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 1.53E-02 1.23E-02 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 RNBMOD07S EC1CB100VO PMA0301ASA RN23MOD5S

Table 54B-7

CASE 3 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER
124	4.07E-10	.04	LOSS OF OFFSITE FAILURE TO RECOVER AC POWER IN 1 HOUR PUMP 01B FAILS & ST CK V007B & C B PTC & RE PTC & CB ECS221 SPO BREAKER 100 FAILS TO OPEN [#3.5] FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 1.53E-02 1.23E-02 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 RNBMOD07S EC1CB100V0 PMA030*BSA RN23MOD55
125	3.98E-10	.03	LOSS OF OFFSITE FAILURE TO RECOVER AC POWER IN 1 HOUR BATTERY DB1 UNAVAILABLE CCF OF LOGIC GROUP PROCESSING MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 1.20E-03 9.69E-05 1.00E+00	IEV-LOSPD OTH-R1 ED1MOD03 CCX-PMA030 RN23MOD55
126	3.93E-10	.03	LOSS OF OFFSITE FAILURE TO RECOVER AC POWER IN 1 HOUR D/G FAILS TO START & RUN OR BKR 102 FAILS TO CLOSE D/G FAILS TO START & RUN OR BKR 207 FAILS TO CLOSE FAILURE OF INV. STATIC SWITCH AND ASS.C. MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 2.02E-02 2.02E-02 5.16E-04 1.00E+00	IEV-LOSPD OTH-R1 Z01MOD01 Z02MOD01 IDAMOD05 RN23MOD55
127	3.78E-10	.03	LOSS OF OFFSITE FAILURE TO RECOVER AC POWER IN 1 HOUR CCF OF LOGIC PLS OUTPUT LOGIC I/Os GROUP PROCESSING MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 2.09E-03 9.69E-05 1.00E+00	IEV-LOSPD OTH-R1 PLSMOD11 CCX-PMA030 RN23MOD55
128	3.75E-10	.03	LOSS OF CCS/SWS FAILURE OF MANUAL DAS CCF OF THE POWER INTERFACE OUTPUT	WITH RCS FILLED INITIATING EVENT OCCURS ACTUATION BOARDS IN PMS	3.75E-03 1.16E-02 8.62E-06	IEV-CWND REC-MANDAS CCX-EP-SAM
129	3.75E-10	.03	LOSS OF OFFSITE FAILURE TO RECOVER AC POWER IN 1 HOUR FAILURE OF PLS OUTPUT LOGIC I/Os FAILURE OF PMS OUTPUT LOGIC I/Os STANDBY DG UNAVAILABLE DUE TO TEST AND MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 2.09E-03 2.09E-03 4.60E-02 1.00E+00	IEV-LOSPD OTH-R1 PLSMOD11 PMAMOD11 Z01DG001TM RN23MOD55
130	3.61E-10	.03	LOSS OF OFFSITE FAILURE TO RECOVER AC POWER IN 1 HOUR CCF TO START OF ENGINE-DRIVEN FUEL PUMPS CCF OF LOGIC GROUP PROCESSING MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 2.00E-03 9.69E-05 1.00E+00	IEV-LOSPD OTH-R1 Z0X-PD-ES CCX-PMA030 RN23MOD55
131	3.59E-10	.03	LOSS OF CCS/SWS COND. PROB. OF CCF OF ORIFICES OPERATOR FAILS	WITH RCS FILLED INITIATING EVENT OCCURS (FAILURE OF REC-MANDAS MANUAL DAS ACT.) TO RECOGNIZE THE NEED FOR RCS DEPRESSURIZATION	3.75E-03 5.06E-01 2.77E-04 6.83E-04	IEV-CWND REC-MANDASC CCX-DRY-SP LPM-MAN05
132	3.50E-10	.03	LOCA/RNS-V024 CCF OF GRAVITY MECHANICAL	OPENS INITIATING EVENT OCCURS INJECTION CHECK VALVES TO OPEN FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	1.13E-05 3.10E-05 1.00E+00	IEV-LOCA24D INX-CV-AO RN23MOD55
133	3.43E-10	.03	LOSS OF OFFSITE FAILURE TO RECOVER AC POWER IN 1 HOUR D/G FAILS TO START & RUN OR BKR 102 FAILS TO CLOSE FAILURE OF UNDERVOLTAGE RELAY PMS OUTPUT LOGIC I/Os MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 2.02E-02 4.36E-03 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 Z01MOD01 EC1REDG2GA PMAMOD11 RN23MOD55

Table 54B-7

CASE 3 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME			EVENT PROB	IDENTIFIER
134	3.29E-10	.03	LOSS OF OFFSITE FAILURE TO BATTERY FAILURE OF MECHANICAL	POWER INITIATING RECOVER AC POWER IN 1 HOUR DB1 UNAVAILABLE MIMIC BUS SELECTOR BOARD FAILURE CAUSES MOV 023 TO	EVENT OCCURS FAIL-TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 2.20E-03 8.00E-05 1.00E+00
135	3.27E-10	.03	LOSS OF OFFSITE FAILURE TO BREAKER 100 BREAKER 200 FAILURE UPON MECHANICAL	POWER INITIATING RECOVER AC POWER IN 1 HOUR FAILS TO OPEN FAILS TO OPEN DEMAND OF LOGIC FAILURE CAUSES	EVENT OCCURS [#3.5] [#5.3] GROUP PROCESSING MOV 023 TO	WITH RCS DRAINED	4.44E-03 4.20E-01 1.23E-02 1.23E-02 1.16E-03 1.00E+00
136	3.27E-10	.03	LOSS OF OFFSITE FAILURE TO BREAKER 100 BREAKER 200 FAILURE UPON MECHANICAL	POWER INITIATING RECOVER AC POWER IN 1 HOUR FAILS TO OPEN FAILS TO OPEN DEMAND OF LOGIC FAILURE CAUSES	EVENT OCCURS [#3.5] [#5.3] GROUP PROCESSING MOV 023 TO	WITH RCS DRAINED	4.44E-03 4.20E-01 1.23E-02 1.23E-02 1.16E-03 1.00E+00
137	3.23E-10	.03	LOSS OF CCS/SWS FAILURE OF CCF OF THE POWER	WITH RCS FILLED MANUAL DAS INTERFACE OUTPUT	INITIATING EVENT OCCURS REACTOR TRIP HARDWARE		3.75E-03 1.00E-02 8.62E-06
138	3.16E-10	.03	LOSS OF OFFSITE FAILURE TO COMMON CAUSE CCF OF OUTPUT MECHANICAL	POWER INITIATING RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKERS TO LOGIC I/O BOARDS	EVENT OCCURS OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 1.20E-02 1.41E-04 1.00E+00
139	3.05E-10	.03	LOSS OF OFFSITE FAILURE TO FIXED FAILURE OF INV.. MECHANICAL	POWER INITIATING RECOVER AC POWER IN 1 HOUR COMPONENTS FAILURE STATIC SWITCH AND ASSOC.	EVENT OCCURS FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED	4.44E-03 4.20E-01 3.17E-04 5.16E-04 1.00E+00
140	3.05E-10	.03	LOSS OF OFFSITE FAILURE TO FIXED FAILURE OF INV.. MECHANICAL	POWER INITIATING RECOVER AC POWER IN 1 HOUR COMPONENTS FAILURE STATIC SWITCH AND ASSOC.	EVENT OCCURS FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED	4.44E-03 4.20E-01 3.17E-04 5.16E-04 1.00E+00
141	3.05E-10	.03	LOSS OF OFFSITE FAILURE TO PLS LOGIC GROUP CCF OF OUTPUT MECHANICAL	POWER INITIATING RECOVER AC POWER IN 1 HOUR PROCESSING FAILURE UPON LOGIC I/O BOARDS	EVENT OCCURS FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED	4.44E-03 4.20E-01 1.16E-03 1.41E-04 1.00E+00
142	3.05E-10	.03	LOSS OF OFFSITE FAILURE TO PLS LOGIC GROUP CCF OF OUTPUT MECHANICAL	POWER INITIATING RECOVER AC POWER IN 1 HOUR PROCESSING FAILURE UPON LOGIC I/O BOARDS	EVENT OCCURS FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED	4.44E-03 4.20E-01 1.16E-03 1.41E-04 1.00E+00

Table 54B-7

CASE 3 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS	WITH RCS DRAINED	EVENT PROB.	IDENTIFIER
143	2.98E-10	.03	LOSS OF OFFSITE FAILURE TO CCF TO START FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS MIMIC BUS SELECTOR BOARD FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 2.00E-03 8.00E-05 1.00E+00	IEV-LOSPD OTH-R1 ZOK-PD-ES PMAKS00ASA RN23MOD55
144	2.97E-10	.03	LOSS OF OFFSITE FAILURE TO PUMP 01B FAILS & D/G FAILS TO FAILURE OF INV. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR ST CK V007B & C S PTC & RE PTC & CB ECS221 SPO START & RUN OR BKR 102 FAILS TO CLOSE STATIC SWITCH AND ASSOC. FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 1.53E-02 2.02E-02 5.16E-04 1.00E+00	IEV-LOSPD OTH-R1 RNBBMOD07S Z01MOD01 IDAMOD05 RN23MOD55
145	2.96E-10	.03	LOSS OF RNS WITH CCF OF ORIFICES	RCS DRAINED	INITIATING EVENT OCCURS	8.15E-05 3.63E-06	IEV-RNSD CCX-ORY-SPX
146	2.91E-10	.03	LOSS F OFFSITE FAILURE TO PUMP M. '1B D/G FAIL TO LOSS OF D.G. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR START & RUN OR BKR 102 FAILS TO CLOSE PANEL OR BREAKER A07 SPURIOUSLY OPENS FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 2.44E-02 2.02E-02 3.17E-04 1.00E+00	IEV-LOSPD OTH-R1 SWBMOD02 Z01MOD01 IDAMOD04 RN23MOD55
147	2.89E-10	.03	LOSS OF CCS/SWS CHECK VALVE 122A CHECK VALVE 124A BUS UNAVAILABLE OPERATOR FAILS	WITH RCS DRAINED	INITIATING EVENT OCCURS FAILS TO OPEN FAILS TO OPEN DUE TO TEST OR CORRECTIVE MAINTENANCE TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	6.02E-04 1.00E+00 1.00E+00 3.00E-04 1.60E-03	IEV-CCWD IWACV122AO IWACV124AO IDCBSDS1TM RHN-MAN05
148	2.89E-10	.03	LOSS OF CCS/SWS CHECK VALVE 122A CHECK VALVE 124A BUS UNAVAILABLE OPERATOR FAILS	WITH RCS DRAINED	INITIATING EVENT OCCURS FAILS TO OPEN FAILS TO OPEN DUE TO TEST OR CORRECTIVE MAINTENANCE TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	6.02E-04 1.00E+00 1.00E+00 3.00E-04 1.60E-03	IEV-CCWD IWACV122AO IWACV124AO IDCBSDK1TM RHN-MAN05
149	2.89E-10	.03	LOSS OF CCS/SWS CHECK VALVE 122A CHECK VALVE 124A BUS UNAVAILABLE OPERATOR FAILS	WITH RCS DRAINED	INITIATING EVENT OCCURS FAILS TO OPEN FAILS TO OPEN DUE TO TEST OR CORRECTIVE MAINTENANCE TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	6.02E-04 1.00E+00 1.00E+00 3.00E-04 1.60E-03	IEV-CCWD IWACV122AO IWACV124AO IDCBSDS1TM RHN-MAN05
150	2.89E-10	.03	LOSS OF OFFSITE FAILURE TO PUMP MP 01B BREAKER 100 FAILURE OF INV. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR FAILS TO OPEN STATIC SWITCH AND ASSOC. FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 2.44E-02 [03.5] 5.16E-04 1.00E+00	IEV-LOSPD OTH-R1 SWBMOD02 EC1CB100VO IDAMOD05 RN23MOD55
151	2.81E-10	.02	LOSS OF OFFSITE FAILURE TO CCF TO RUN OF FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR ENGINE-DRIVEN FUEL PUMPS DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 1.30E-04 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 ZOK-PD-ER PMA0301ASA RN23MOD55
152	2.81E-10	.02	LOSS OF OFFSITE FAILURE TO CCF TO RUN OF FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR ENGINE-DRIVEN FUEL PUMPS DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 1.30E-04 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 ZOK-PD-ER PMA0301BSA RN23MOD55

Table 54B-7

CASE 3 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER
153	2.77E-10	.02	LOSS OF OFFSITE FAILURE TO PUMP SUBLOOP B BREAKER 100 FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR HARDWARE FAILURE OR DIVERTED FLOW FAILS TO OPEN DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 1.04E-02 1.23E-02 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 CCBMOD01S EC1CB100V0 PMA0301ASA RN23MOD5S
154	2.77E-10	.02	LOSS OF OFFSITE FAILURE TO PUMP SUBLOOP B BREAKER 100 FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR HARDWARE FAILURE OR DIVERTED FLOW FAILS TO OPEN DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 1.04E-02 1.23E-02 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 CCBMOD01S EC1CB100V0 PMA0301BSA RN23MOD5S
155	2.76E-10	.02	LOSS OF OFFSITE FAILURE TO PUMP MP 01B D/G FAILS TO BUS UNAVAILABLE MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR START & RUN OR BKR 102 FAILS TO CLOSE DUE TO TEST OR CORRECTIVE MAINTENANCE FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.44E-02 2.02E-02 3.00E-04 1.00E+00	IEV-LOSPD OTH-R1 SWBMOD02 Z01MOD01 IDABSDS1TM RN23MOD5S
156	2.69E-10	.02	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE OF INV. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR STANDBY DG TO START STATIC SWITCH AND ASSOC. BREAKERS FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.80E-04 5.16E-04 1.00E+00	IEV-LOSPD OTH-R1 ZGX-DG-DS IDAMOD05 RN23MOD5S
157	2.68E-10	.02	LOSS OF CCS/SWS FAILURE UPON UNAVAILABILITY MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING OF BUS ECS ES 1 DUE TO UNSCHEDUL MAINTENANCE FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	6.02E-04 1.65E-04 2.70E-03 1.00E+00	IEV-CWMD PMA0301ASAX EC1BS001TM RN23MOD5S
158	2.68E-10	.02	LOSS OF CCS/SWS FAILURE UPON UNAVAILABILITY MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING OF BUS ECS ES 1 DUE TO UNSCHEDUL MAINTENANCE FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	6.02E-04 1.65E-04 2.70E-03 1.00E+00	IEV-CWMD PMA0301BSAX EC1BS001TM RN23MOD5S
159	2.68E-10	.02	LOSS OF CCS/SWS FAILURE UPON BUS UNAVAILABLE MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING DUE TO UNSCHEDULED MAINTENANCE FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	6.02E-04 1.65E-04 2.70E-03 1.00E+00	IEV-CWMD PMA0301ASAX EC1BS121TM RN23MOD5S
160	2.68E-10	.02	LOSS OF CCS/SWS FAILURE UPON BUS UNAVAILABLE MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING DUE TO UNSCHEDULED MAINTENANCE FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	6.02E-04 1.65E-04 2.70E-03 1.00E+00	IEV-CWMD PMA0301ASAX EC1BS012TM RN23MOD5S
161	2.68E-10	.02	LOSS OF CCS/SWS FAILURE UPON BUS UNAVAILABLE MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING DUE TO UNSCHEDULED MAINTENANCE FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	6.02E-04 1.65E-04 2.70E-03 1.00E+00	IEV-CWMD PMA0301BSA EC1BS017TM RN23MOD5S
162	2.68E-10	.02	LOSS OF CCS/SWS FAILURE UPON BUS UNAVAILABLE MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS DEMAND OF LOGIC GROUP PROCESSING DUE TO UNSCHEDULED MAINTENANCE FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	6.02E-04 1.65E-04 2.70E-03 1.00E+00	IEV-CWMD PMA0301BSAX EC1BS121TM RN23MOD5S

Table 54B-7

CASE 3 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS	EVENT PROB	IDENTIFIER	
163	2.60E-10	.02	LOSS OF CCS/SWS COND. PROB. OF REC-MANDAS CCF OF PRESSURE OPERATOR FAILS	WITH RCS FILLED TRANSMITTERS TO RECOGNIZE THE NEED FOR RCS	[FAILURE OF MANUAL DAS ACT. DEPRESSURIZATION]	3.75E-03 5.06E-01 2.01E-04 6.83E-04	IEV-CCMDND REC-MANDASC CCX-XMTR195 LPM-MAN05
164	2.60E-10	.02	LOSS OF OFFSITE FAILURE TO COMMON CAUSE LOSS OF DIST. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE STANDBY DG TO PANEL OR BREAKER A07 SPURIOUSLY FAILURE CAUSES	WITH RCS DRAINED RUN OPENS MOV 023 TO	4.44E-03 4.20E-01 4.40E-04 3.17E-04 1.00E+00	IEV-LOSPD OTH-R1 ZOK-DG-DR IDAMOD04 RN23MOD55
165	2.57E-10	.02	LOSS OF CCS/SWS FAILURE OF PMS OUTPUT FAILURE OF PMS OUTPUT MECHANICAL	WITH RCS DRAINED LOGIC I/Os LOGIC I/Os FAILURE CAUSES	INITIATING EVENT OCCURS FAIL-T0-OPEN	6.02E-04 6.53E-04 6.53E-04 1.00E+00	IEV-CCMD PMAMOD11X PMAMOD12X RN23MOD55
166	2.50E-10	.02	LOSS OF RNS WITH RCS DRAINED CHECK VALVE 122A CHECK VALVE 124A CHECK VALVE 122B CHECK VALVE 124B MECHANICAL	INITIATING EVENT OCCURS FAILS TO OPEN FAILS TO OPEN FAILS TO OPEN FAILS TO OPEN FAILURE CAUSES	WITH RCS DRAINED FAIL-T0-OPEN	8.15E-05 1.00E+00 1.00E+00 1.75E-03 1.75E-03 1.00E+00	IEV-RNSD IWACV122AO IWACV124AO IWBCV122AO IWBCV124AO RN23MOD55
167	2.46E-10	.02	LOSS OF OFFSITE FAILURE TO COMMON CAUSE BUS UNAVAILABLE MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE STANDBY DG TO DUE TO TEST OR CORRECTIVE FAILURE CAUSES	WITH RCS DRAINED RUN MAINTENANCE FAIL-T0-OPEN	4.44E-03 4.20E-01 4.40E-04 3.00E-04 1.00E+00	IEV-LOSPD OTH-R1 ZOK-DG-DR IDABSDSITM RN23MOD55
168	2.41E-10	.02	LOSS OF OFFSITE FAILURE TO D/G FAILS TO D/G FAILS TO LOSS OF DIST. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR START & RUN OR BKR 102 FAILS TO CLOSE START & RUN OR BKR 202 FAILS TO CLOSE PANEL OR BREAKER A07 SPURIOUSLY FAILURE CAUSES	WITH RCS DRAINED FAIL-T0-OPEN	4.44E-03 4.20E-01 2.02E-02 2.02E-02 3.17E-04 1.00E+00	IEV-LOSPD OTH-R1 Z01MOD01 Z02MOD01 IDAMOD04 RN23MOD55
169	2.40E-10	.02	LOSS OF RNS WITH RCS DRAINED CCF OF THE POWER INTERFACE MECHANICAL	INITIATING EVENT OCCURS OUTPUT BOARDS IN PMS FAILURE CAUSES	MOV 023 TO	8.15E-05 2.94E-06 1.00E+00	IEV-RNSD CCX-EP-SAMX RN23MOD55
170	2.39E-10	.02	LOSS OF OFFSITE FAILURE TO D/G FAILS TO BREAKER 200 FAILURE OF INV. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR START & RUN OR BKR 102 FAILS TO CLOSE FAILS TO OPEN STATIC SWITCH AND ASSOC. FAILURE CAUSES	WITH RCS DRAINED FAIL-T0-OPEN	4.44E-03 4.20E-01 2.02E-02 1.23E-02 5.16E-04 1.00E+00	IEV-LOSPD OTH-R1 Z01MOD01 EC2CB200V0 IDAMOD05 RN23MOD55
171	2.39E-10	.02	LOSS OF OFFSITE FAILURE TO BREAKER 100 D/G FAILS TO FAILURE OF INV. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILS TO OPEN START & RUN OR BKR 202 FAILS TO CLOSE STATIC SWITCH AND ASSOC. FAILURE CAUSES	WITH RCS DRAINED FAIL-T0-OPEN	4.44E-03 4.20E-01 1.23E-02 2.02E-02 5.16E-04 1.00E+00	IEV-LOSPD OTH-R1 EC1CB100V0 Z02MOD01 IDAMOD05 RN23MOD55
172	2.34E-10	.02	LOSS OF OFFSITE FAILURE TO CCF TO START FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR DG ROOM VENT FANS PMS OUTPUT LOGIC I/Os FAILURE CAUSES	WITH RCS DRAINED FAIL-T0-OPEN	4.44E-03 4.20E-01 6.00E-05 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 ZOK-BL-ES PMAMOD11 RN23MOD55

Table 54B-7

CASE 3 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS	WITH RCS DRAINED	EVENT PROB	IDENTIFIER
173	2.28E-10	.02	LOSS OF OFFSITE FAILURE TO D/G FAILS TO D/G FAILS TO BUS UNAVAILABLE MECHANICAL	POWER INITIATING RECOVER AC POWER IN 1 HOUR START & RUN OR BKR 102 FAILS TO CLOSE START & RUN OR BKR 202 FAILS TO CLOSE DUE TO TEST OR CORRECTIVE MAINTENANCE FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 2.02E-02 2.02E-02 3.00E-04 1.00E+00	IEV-LOSPD OTH-R1 Z01MOD01 Z02MOD01 IDAB-DS1TM RN23MOD5S
174	2.22E-10	.02	LOSS OF OFFSITE COMMON CAUSE FAILURE OF MECHANICAL	POWER INITIATING RECOVER AC POWER IN 1 HOUR FAILURE OF THE BATTERY PMS OUTPUT FAILURE CAUSES	WITH RCS DRAINED	4.44E-03 4.20E-01 5.70E-05 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 CCX-BY-PN1 PMAMOD11 RN23MOD5S
175	2.17E-10	.02	LOSS OF OFFSITE FAILURE TO COMMON CAUSE CCF OF LOGIC MECHANICAL	POWER INITIATING RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKERS TO OPEN GROUP PROCESSING FAILURE CAUSES	WITH RCS DRAINED	4.44E-03 4.20E-01 1.20E-03 9.69E-05 1.00E+00	IEV-LOSPD OTH-R1 ECX-CB-GO CCX-PMA030 RN23MOD5S
176	2.14E-10	.02	LOSS OF RNS WITH CCF OF PRESSURE	RCS DRAINED TRANSMITTERS	INITIATING EVENT OCCURS	8.15E-05 2.63E-06	IEV-RNSD CCX-XMTRX
177	2.13E-10	.02	LOSS OF OFFSITE FAILURE TO BATTERY DB1 D/G FAILS TO FAILURE OF MECHANICAL	POWER INITIATING RECOVER AC POWER IN 1 HOUR UNAVAILABLE START & RUN OR BKR 102 FAILS TO CLOSE PMS OUTPUT LOGIC I/Os FAILURE CAUSES	WITH RCS DRAINED	4.44E-03 4.20E-01 2.70E-03 2.02E-02 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 ED2MOD03 Z01MOD01 PMAMOD11 RN23MOD5S
178	2.10E-10	.02	LOSS OF OFFSITE FAILURE TO PLS LOGIC GROUP CCF OF LOGIC MECHANICAL	POWER INITIATING RECOVER AC POWER IN 1 HOUR PROCESSING FAILURE UPON GROUP PROCESSING FAILURE CAUSES	WITH RCS DRAINED	4.44E-03 4.20E-01 1.16E-03 9.69E-05 1.00E+00	IEV-LOSPD OTH-R1 PL50301BSA CCX-PMA030 RN23MOD5S
179	2.10E-10	.02	LOSS OF OFFSITE FAILURE TO PLS LOGIC GROUP CCF OF LOGIC MECHANICAL	POWER INITIATING RECOVER AC POWER IN 1 HOUR PROCESSING FAILURE UPON GROUP PROCESSING FAILURE CAUSES	WITH RCS DRAINED	4.44E-03 4.20E-01 1.16E-03 9.69E-05 1.00E+00	IEV-LOSPD OTH-R1 PL50301ASA CCX-PMA030 RN23MOD5S
180	2.09E-10	.02	LOSS OF OFFSITE FAILURE TO BREAKER 100 FAILURE OF UNDERVOLTAGE FAILURE OF PMS OUTPUT MECHANICAL	POWER INITIATING RECOVER AC POWER IN 1 HOUR FAILS TO OPEN RELAY LOGIC I/Os FAILURE CAUSES	WITH RCS DRAINED	4.44E-03 4.20E-01 1.23E-02 4.36E-03 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 EC1CB190V0 EC1REDG2GA PMAMOD11 RN23MOD5S
181	2.09E-10	.02	OVERDRAINING OF RHN-MAN04-SUCC CCF OF MUX MECHANICAL	RCS DURING DRAIN DOWN TO MID-LOOP LOGIC GROUPS FAILURE CAUSES	INITIATING EVENT	4.44E-06 9.45E-01 4.98E-05 1.00E+00	IEV-RCS0D RHN-MAN04-SUCC CCX-PMAMOD4 RN23MOD5S
182	2.08E-10	.02	LOSS OF OFFSITE FAILURE TO PLS OUTPUT FAILURE UPON STANDBY DG MECHANICAL	POWER INITIATING RECOVER AC POWER IN 1 HOUR LOGIC I/Os DEMAND OF LOGIC GROUP PROCESSING UNAVAILABLE DUE TO TEST AND MAINTENANCE FAILURE CAUSES	WITH RCS DRAINED	4.44E-03 4.20E-01 2.09E-03 1.16E-03 4.60E-02 1.00E+00	IEV-LOSPD OTH-R1 PL50301ASA Z01DG001TM RN23MOD5S

Table 54B-7

CASE 3 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS	WITH RCS DRAINED	EVENT PROB	IDENTIFIER
183	2.08E-10	.02	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS FAILURE TO RECOVER AC POWER IN 1 HOUR FAILURE OF PLS OUTPUT LOGIC I/Os FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING STANDBY DG UNAVAILABLE DUE TO TEST AND MAINTENANCE MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN			4.44E-03 4.20E-01 2.09E-03 1.16E-03 4.60E-02 1.00E+00	IEV-LOSPD OTH-R1 PLSMOD11 PMA0301BSA Z01DG001TM RN23MOD55
184	2.08E-10	.02	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS FAILURE TO RECOVER AC POWER IN 1 HOUR PLS LOGIC GROUP PROCESSING FAILURE UPON DEMAND FAILURE OF PMS OUTPUT LOGIC I/Os STANDBY DG UNAVAILABLE DUE TO TEST AND MAINTENANCE MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN			4.44E-03 4.20E-01 1.16E-03 2.09E-03 4.60E-02 1.00E+00	IEV-LOSPD OTH-R1 PLS0301BSA PMAMOD11 Z01DG001TM RN23MOD55
185	2.08E-10	.02	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS FAILURE TO RECOVER AC POWER IN 1 HOUR PLS LOGIC GROUP PROCESSING FAILURE UPON DEMAND FAILURE OF PMS OUTPUT LOGIC I/Os STANDBY DG UNAVAILABLE DUE TO TEST AND MAINTENANCE MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN			4.44E-03 4.20E-01 1.16E-03 2.09E-03 4.60E-02 1.00E+00	IEV-LOSPD OTH-R1 PLS0301ASA PMAMOD11 Z01DG001TM RN23MOD55
186	2.03E-10	.02	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS CHECK VALVE 122A FAILS TO OPEN CHECK VALVE 124A FAILS TO OPEN CHECK VALVE 123B FAILS TO OPEN CHECK VALVE 125B FAILS TO OPEN MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN			6.02E-04 1.00E+00 1.00E+00 5.80E-04 5.80E-04 1.00E+00	IEV-CCWD IWACV122AO IWACV124AO IWBCV123AO IWBCV125AO RN23MOD55
187	2.02E-10	.02	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS FAILURE TO RECOVER AC POWER IN 1 HOUR CCF TO START OF THE PUMPS CCF OF OUTPUT LOGIC I/O BOARDS MECHANICAL FAILURE CAUSES MOV C23 TO FAIL-TO-OPEN			4.44E-03 4.20E-01 7.70E-04 1.41E-04 1.00E+00	IEV-LOSPD OTH-R1 RNX-PM-FS CX-PMAMOD1 RN23MOD55
188	2.02E-10	.02	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS FAILURE TO RECOVER AC POWER IN 1 HOUR PUMP SUBLOOP B HARDWARE FAILURE OR DIVERTED FLOW D/G FAILS TO START & RUN OR BKR 102 FAILS TO CLOSE FAILURE OF INV. STATIC SWITCH AND ASSOC. MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN			4.44E-03 4.20E-01 1.04E-02 1.02E-02 5.16E-04 1.00E+00	IEV-LOSPD OTH-R1 CCBMOD001S Z01MOD01 IDAMOD05 RN23MOD55
189	2.02E-10	.02	LOCA/RNS-V024 OPENS INITIATING EVENT OCCURS CCF OF STRAINERS IN IRWST TANK	WITH RCS FILLED		1.58E-05 1.20E-05	IEV-LOCA24ND IWX-FL-GP
190	1.99E-10	.02	LOCA/RNS PIPE RUPTURE WITH RCS FILLED INIT. EVENT OCCURS OPERATOR FAILS TO ISOLATE RNS PIPE RUPTURE CHECK VALVE 122A FAILS TO OPEN CHECK VALVE 124A FAILS TO OPEN IRWST DISCHARGE LINE "B" STRAINER PLUGGED			1.51E-05 5.50E-02 1.00E+00 1.00E+00 2.40E-04	IEV-LOCAPRND RHN-MAN04 IWACV122AO IWACV124AO IWBB-PLUG
191	1.94E-10	.02	OVERDRAINING OF RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT RHN-MAN04-SUCC CCF OF ACTUATION LOGIC GROUPS MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN			4.44E-06 9.45E-01 4.63E-05 1.00E+00	IEV-RCS0D RHN-MAN04-SUCC CX-PMAMOD1X RN23MOD55

Table 54B-7

CASE 3 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME			EVENT PROB	IDENTIFIER
192	1.93E-10	.02	LOSS OF OFFSITE FAILURE TO BATTERY COMMON CAUSE MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR DS1 UNAVAILABLE FAILURE OF THE BATTERIES FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED IDSA-DB-1A/1B FAIL-TO-OPEN	4.44E-03 4.20E-01 2.20E-03 4.70E-05 1.00E+00	IEV-LOSPD OTH-R1 EDIMOD03 CCX-BY-PN RN23MOD5S
193	1.92E-10	.02	LOSS OF OFFSITE FAILURE TO COMMON CAUSE CCF OF OUTPUT MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKER TO LOGIC I/O BOARDS FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED CLOSE FAIL-TO-OPEN	4.44E-03 4.20E-01 7.30E-04 1.41E-04 1.00E+00	IEV-LOSPD OTH-R1 ECX-CB-GC CCX-PMAMOD1 RN23MOD5S
194	1.91E-10	.02	LOSS OF OFFSITE FAILURE TO D/G FAILS TO FAILURE OF FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR START & RUN OR BKR 102 FAILS TO CLOSE UNDERTOLVAGE RELAY DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED FAIL-TO-OPEN	4.44E-03 4.20E-01 2.02E-02 4.36E-03 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 Z01MGD01 ZC1REDG2GA PMA0301ASA RN23MOD5S
195	1.91E-10	.02	LOSS OF OFFSITE FAILURE TO D/G FAILS TO FAILURE OF FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR START & RUN OR BKR 102 FAILS TO CLOSE UNDERTOLVAGE RELAY DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED FAIL-TO-OPEN	4.44E-03 4.20E-01 2.02E-02 4.36E-03 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 Z01MOD01 EC1REDG2GA PMA0301BSA RN23MOD5S
196	1.87E-10	.02	LOSS OF OFFSITE FAILURE TO FIXED LOSS OF DIST. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR COMPONENTS FAILURE PANEL OR BREAKER A07 SPURIOUSLY FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED OPENS FAIL-TO-OPEN	4.44E-03 4.20E-01 3.17E-04 3.17E-04 1.00E+00	IEV-LOSPD OTH-R1 EDIMOD11 IDAMOD04 RN23MOD5S
197	1.87E-10	.02	LOSS OF OFFSITE FAILURE TO FIXED LOSS OF DIST. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR COMPONENTS FAILURE PANEL OR BREAKER A07 SPURIOUSLY FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED OPENS FAIL-TO-OPEN	4.44E-03 4.20E-01 3.17E-04 3.17E-04 1.00E+00	IEV-LOSPD OTH-R1 EDIMOD113 IDAMOD04 RN23MOD5S
198	1.83E-10	.02	LOSS OF OFFSITE FAILURE TO PUMP 01B FAILS & D/G FAILS TO LOSS OF DIST. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR ST CK V007B & C B FTC & RE FTC & CB ECS221 SPO START & RUN OR BKR 102 FAILS TO CLOSE PANEL OR BREAKER A07 SPURIOUSLY FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED FAIL-TO-OPEN	4.44E-03 4.20E-01 1.53E-02 2.02E-02 3.17E-04 1.00E+00	IEV-LOSPD OTH-R1 RNBMOD07S Z01MOD01 IDAMOD04 RN23MOD5S
199	1.81E-10	.02	LOSS OF OFFSITE FAILURE TO PUMP 01B FAILS & BREAKER 100 FAILURE OF INV. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR ST CK V007B & C B FTC & RE FTC & CB ECS221 SPO FAILS TO OPEN STATIC SWITCH AND ASSOC. FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED (#3.5) BREAKERS FAIL-TO-OPEN	4.44E-03 4.20E-01 1.53E-02 1.23E-02 5.16E-04 1.00E+00	IEV-LOSPD OTH-R1 RNBMOD07S EC1CB100VO IDAMOD05 RN23MOD5S
200	1.81E-10	.02	LOSS OF OFFSITE SOFTWARE CCF FAILURE OF	POWER INITIATING EVENT OCCURS AC POWER RECOVERED IN 2 HOURS OF ALL CARDS MANUAL DAS ACTUATION	WITH RCS FILLED	1.71E-02 7.60E-01 1.20E-05 1.16E-02	IEV-LOSPND SUC-R2S CCX-SFTW REC-MANDAS

Table 54B-8

BASIC EVENT IMPORTANCE - CASE 3

SYSTEM UNAVAILABILITY (Q.) = 1.152E-06
 NUMBER OF BASIC EVENTS = 294
 NUMBER OF CUTSETS = 6454

BASIC EVENT	IMPORTANCE (%DECREASE)	NUMBER OF CUTSETS	DECREASE IN SYSTEM UNAVAILABILITY	BASIC EVENT PROBABILITY
1 RN23MOD5S	77.53	875	8.9344E-07	1.0000E+00
2 IEV-CWCD	74.86	1942	8.6271E-07	6.0200E-04
3 IWACV122AO	72.04	126	8.3025E-07	1.0000E+00
4 IWACV124AO	72.04	126	8.3025E-07	1.0000E+00
5 IDCBSDD1TM	17.92	126	2.0654E-07	3.0000E-04
6 IDCBSDK1TM	17.92	126	2.0654E-07	3.0000E-04
7 IDCBSDS1TM	17.92	126	2.0654E-07	3.0000E-04
8 IW8-PLUG	15.02	382	1.7311E-07	2.4000E-04
9 IEV-LOSPD	12.39	2394	1.4283E-07	4.4400E-03
10 OTH-R1	12.06	2242	1.3893E-07	4.2000E-01
11 IEV-RNSD	9.72	933	1.1201E-07	8.1500E-05
12 PMAMOL1	4.04	296	4.6545E-08	2.0900E-03
13 IRAEP121BSAX	3.06	45	3.5245E-08	5.8300E-05
14 CCX-PMAMOD1X	2.83	195	3.2671E-08	4.6300E-05
15 ADX-EV-SA	2.46	290	2.8339E-08	3.8000E-05
16 IWX-MV-GO1	2.46	266	2.8329E-08	3.8000E-05
17 ED1MOD03	2.26	130	2.6060E-08	2.2020E-03
18 PMA0301ASA	2.19	218	2.5235E-08	1.1600E-03
19 PMA0301BSA	2.19	218	2.5235E-08	1.1600E-03
20 Z01MOD01	2.13	518	2.4563E-08	2.0200E-02
21 IWX-CV-AO	2.05	395	2.3596E-08	3.1000E-05
22 Z0X-PD-ES	1.97	112	2.2736E-08	2.0000E-03
23 IEV-RCSOD	1.91	457	2.2001E-08	4.4400E-06
24 RHN-MAN04	1.25	122	1.4416E-08	5.5000E-02
25 IWN-MAN00C	1.22	23	1.4051E-08	5.0000E-02
26 EC1CB100VO	1.20	375	1.3871E-08	1.2300E-02
27 IDAMOD05	1.18	354	1.3652E-08	5.1600E-04
28 ECX-CB-GO	1.18	91	1.3624E-08	1.2000E-03
29 CCX-PMA030X	.84	130	9.6795E-09	1.3800E-05
30 SWBMOD02	.81	147	9.2930E-09	2.4400E-02
31 IWX-FL-GP	.79	168	9.1450E-09	1.2000E-05
32 IDAMOD04	.72	340	8.3399E-09	3.1700E-04
33 ECX-CB-GC	.72	73	8.2570E-09	7.3000E-04
34 Z02MOD01	.70	181	8.0840E-09	2.0200E-02
35 CCX-PMAMOD1-SW	.68	128	7.8447E-09	1.1000E-05
36 RHN-MAN04-SUCC	.68	373	7.8249E-09	9.4500E-01
37 IDABSDS1TM	.66	255	7.6125E-09	3.0000E-04
38 CCX-SFTW	.59	26	6.7434E-09	1.2000E-06
39 IWN-MAN00	.52	189	5.9933E-09	1.1500E-03
40 RNBMOD07S	.52	141	5.9674E-09	1.5300E-02
41 IEV-LOCA24D	.45	393	5.2331E-09	1.1300E-05
42 Z0X-DG-DR	.43	56	4.9670E-09	4.4000E-04
43 CCX-PMAMOD1	.43	87	4.9407E-09	1.4100E-04
44 IEV-LOCA24ND	.42	121	4.8750E-09	1.6800E-05
45 EC2CB200VO	.41	139	4.6799E-09	1.2300E-02
46 PMAMOD11X	.38	369	4.3902E-09	6.5300E-04
47 EC1BS001TM	.38	442	4.3268E-09	2.7000E-03
48 EC1BS012TM	.38	442	4.3268E-09	2.7000E-03
49 EC1BS121TM	.38	442	4.3268E-09	2.7000E-03
50 SUC-RIS	.34	152	3.8968E-09	5.8000E-01
51 CCBMOD01S	.33	88	3.7503E-09	1.0400E-02
52 ED1MOD11	.31	54	3.5611E-09	3.1700E-04
53 ED1MOD113	.31	54	3.5612E-09	3.1700E-04
54 Z0X-DG-DS	.27	49	3.1630E-09	2.8000E-04
55 PL5MOP11	.27	72	3.1375E-09	2.0900E-03
56 CCX-PMA030	.27	59	3.1080E-09	9.6900E-05
57 Z01DG001TM	.25	95	2.9170E-09	4.6000E-02
58 IWBCV122AO	.25	132	2.8672E-09	1.7500E-03
59 IWBCV124AO	.25	132	2.8672E-09	1.7500E-03
60 CCX-ORY-SPX	.23	112	2.7053E-09	3.6300E-06
61 RHN-MAN05C	.23	27	2.6101E-09	1.5000E-01
62 CCX-EP-SAMX	.18	87	2.0631E-09	2.9400E-06
63 CCX-XMTRX	.17	97	1.9519E-09	2.6300E-06
64 IEV-CCWND	.14	69	1.6427E-09	3.7500E-03
65 PL50301ASA	.13	46	1.5472E-09	1.1600E-03
66 PL50301BSA	.13	46	1.5472E-09	1.1600E-03

67	EC1REDG2GA	.13	55	1.4516E-09	4.3600E-03
68	PMAX300ASA	.12	28	1.4189E-09	8.0000E-05
69	RHN-MAN05	.12	743	1.3963E-09	1.6000E-03
70	CCX-EP-SAM	.12	215	1.3927E-09	8.6200E-06
71	ZOX-PD-ER	.12	31	1.3907E-09	1.3000E-04
72	RNX-PM-FS	.11	48	1.2677E-09	7.7000E-04
73	PMA0301ASAX	.09	176	1.0879E-09	1.6500E-04
74	CCX-BY-PN	.09	237	1.0853E-09	4.7000E-05
75	PMA0301BSAX	.09	157	1.0602E-09	1.6500E-04
76	REC-MANDASC	.09	46	1.0312E-09	5.0600E-01
77	RNX-KV-GO	.08	42	9.7434E-10	6.1000E-04
78	LPM-MAN05	.08	37	9.7191E-10	6.8300E-04
79	IWBCV123AO	.08	132	9.5179E-10	5.8000E-04
80	IWBCV125AO	.08	132	9.5179E-10	5.8000E-04
81	REC-MANDAS	.07	36	8.5761E-10	1.1600E-02
82	ED2MOD03	.07	68	8.2166E-10	2.7000E-03
83	MDAS	.07	79	7.5911E-10	1.0000E-02
84	Z01MOD04	.07	82	7.5593E-10	1.2500E-03
85	RNAMOD06S	.06	85	6.7790E-10	1.5300E-02
86	ED3MOD03	.06	35	6.5362E-10	2.2020E-03
87	PMAMOD12X	.06	123	6.3921E-10	6.5300E-04
88	PL4MOD11	.05	43	6.1730E-10	2.0900E-03
89	PL1MOD11	.05	36	6.1537E-10	2.0900E-03
90	PL7MOD11	.05	36	6.1537E-10	2.0900E-03
91	PMAX500CASAX	.05	158	5.0517E-10	8.0000E-05
92	ED1MOD01	.05	22	5.8141E-10	5.0400E-04
93	ZOX-BL-ES	.05	15	5.6935E-10	6.0000E-05
94	SWBMOD09P	.05	31	5.4408E-10	1.8500E-03
95	CCX-BW-PN1	.05	16	5.4213E-10	5.7000E-05
96	IWACV123AO	.04	126	4.8183E-10	5.8000E-04
97	IWACV125AO	.04	126	4.8183E-10	5.8000E-04
98	IEV-LOSPND	.04	40	4.7027E-10	1.7100E-02
99	CCX-ORY-SP	.04	18	4.6569E-10	2.7700E-04
100	IEV-RNSND	.04	46	4.2095E-10	9.6100E-04
101	CCX-IV-XR	.03	132	3.8887E-10	2.4000E-05
102	SUC-R2S	.03	9	3.4566E-10	7.6000E-01
103	CCX-XMTR195	.03	16	3.3742E-10	2.0100E-04
104	IDAMOD08	.03	96	3.1023E-10	3.1700E-04
105	Z02MOD04	.02	44	2.8786E-10	1.2500E-03
106	ED1MOD13	.02	16	2.7717E-10	3.1700E-04
107	ED1MOD07	.02	16	2.6655E-10	3.0500E-04
108	IDBBSDD1TM	.02	125	2.6042E-10	3.0000E-04
109	IDBBSDK1TM	.02	125	2.6042E-10	3.0000E-04
110	IDBBSDS1TM	.02	125	2.6042E-10	3.0000E-04
111	PL40301ASA	.02	29	2.5733E-10	1.1600E-03
112	PL40301BSA	.02	26	2.5698E-10	1.1600E-03
113	PL10301ASA	.02	25	2.5660E-10	1.1600E-03
114	PL70301ASA	.02	25	2.5660E-10	1.1600E-03
115	PL10301BSA	.02	24	2.5650E-10	1.1600E-03
116	PL70301BSA	.02	24	2.5650E-10	1.1600E-03
117	IEV-LOCAPRND	.02	59	2.4654E-10	1.5100E-05
118	CCX-PMAMOD4	.02	41	2.3507E-10	4.9800E-05
119	IDDBSDD1TM	.02	343	2.2667E-10	3.0000E-04
120	IDDBSDK1TM	.02	343	2.2667E-10	3.0000E-04
121	IDDBSDS1TM	.02	343	2.2667E-10	3.0000E-04
122	IWA-PLUG	.02	136	2.0911E-10	2.4000E-04
123	CCX-INPUT-LOGIC	.02	29	1.9140E-10	1.0300E-04
124	SWAMOD07	.02	39	1.8637E-10	7.1200E-03
125	PMA0302ASAX	.01	59	1.4110E-10	1.6500E-04
126	RNDEP023SA	.01	267	1.2737E-10	1.7100E-04
127	OTH-R2	.01	29	1.2447E-10	2.4000E-01
128	CCX-PL4MOD1	.01	15	1.1786E-10	1.4100E-04
129	PMA0302BSAX	.01	40	1.1338E-10	1.6500E-04
130	CCAMOD02	.01	37	1.1131E-10	7.1000E-03
131	IWIOR170SPX	.01	34	1.0706E-10	9.4600E-05
132	IW2OR160SPX	.01	34	1.0706E-10	9.4600E-05
133	CCX-PMDMOD1	.01	249	1.0436E-10	1.4100E-04
134	EC5EPMBG1SA	.01	8	8.7669E-11	1.7100E-04
135	PXX-AV-LA	.01	57	8.3091E-11	6.1000E-05
136	CCX-PMAMOD2X	.01	22	8.1518E-11	8.5800E-05
137	ADN-MAN01	.01	58	7.9719E-11	4.9300E-04
138	IW1TL170UFX	.01	33	7.7478E-11	6.8400E-05
139	IW2TL160UFX	.01	33	7.7478E-11	6.8400E-05
140	EC1MOD12	.01	66	7.4091E-11	4.8000E-05
141	CCX-PL1MOD1	.01	8	7.2306E-11	1.4100E-04
142	CCX-PL7MOD1	.01	8	7.2306E-11	1.4100E-04
143	IDAMOD02	.01	31	7.0216E-11	2.7000E-03
144	IDAMOD03	.01	31	7.0216E-11	2.7000E-03
145	IDAMOD06	.01	48	6.4733E-11	4.3200E-05
146	CCX-PL403	.00	12	4.9853E-11	9.6900E-05
147	CCX-PMAMOD4-SW	.00	12	4.9042E-11	1.1000E-05

148	IRAEPI21ASAX	.00	42	4.7909E-11	5.8300E-05
149	EC1REDG1GA	.00	37	4.7551E-11	4.3600E-03
150	ED3MOD01	.00	10	4.3471E-11	5.0400E-04
151	DG1-LOGIC	.00	1	4.0700E-11	5.0000E-03
152	PMAMOD41	.00	34	2.7780E-11	6.3500E-04
153	IDABSDS1LF	.00	24	2.6649E-11	4.8000E-06
154	CCX-LS-FA	.00	32	2.5495E-11	5.3700E-06
155	ED3MOD07	.00	26	2.4788E-11	3.0500E-04
156	CCX-INPUT-LOGICK	.00	12	2.4188E-11	2.5900E-05
157	EC1MOD121	.00	24	2.3859E-11	1.6800E-05
158	Z02DQ002TM	.00	42	2.2868E-11	4.6700E-02
159	RNX-CV-GO	.00	11	2.2157E-11	5.1000E-05
160	CCX-PL103	.00	6	1.8601E-11	9.6900E-05
161	CCX-PL703	.00	6	1.8601E-11	9.6900E-05
162	CCX-PMD030	.00	163	1.7994E-11	9.5900E-05
163	CCX-PMAEH0X	.00	11	1.7939E-11	4.0300E-06
164	PL5XS00ASA	.00	6	1.5354E-11	8.0000E-05
165	IDAMOD07	.00	15	1.4597E-11	2.1900E-02
166	SWAMOD09P	.00	22	1.3491E-11	1.8500E-03
167	PMAMOD21X	.00	14	1.2163E-11	1.1600E-03
168	CCX-IN-LOGIC-SW	.00	8	9.9537E-12	1.1000E-05
169	CCX-PMAMOD2-SW	.00	8	9.9537E-12	1.1000E-05
170	IDBFD013RQ	.00	10	8.5301E-12	1.2000E-05
171	IDBFD014RQ	.00	10	8.5301E-12	1.2000E-05
172	IDCFD007RQ	.00	8	8.2532E-12	1.2000E-05
173	IDCFD008BRQ	.00	8	8.2532E-12	1.2000E-05
174	CCX-PMDMOD4	.00	118	8.1162E-12	4.9800E-05
175	ALL-IND-AIL	.00	27	7.3440E-12	1.0000E-06
176	RNX-PM-ER	.00	10	6.8751E-12	1.6000E-05
177	RHN-MAN03	.00	36	6.6279E-12	2.2600E-03
178	AD2MOD01	.00	21	6.3662E-12	5.5400E-02
179	AD2MOD02	.00	21	6.3662E-12	5.5400E-02
180	AD3MOD03	.00	21	6.3662E-12	5.5400E-02
181	AD3MOD04	.00	21	6.3662E-12	5.5400E-02
182	CCX-PM-ER	.00	10	6.0156E-12	1.4000E-05
183	SWX-PM-ER	.00	10	6.0156E-12	1.4000E-05
184	ED2MOD11	.00	20	5.3288E-12	3.1700E-04
185	EC1BS001LF	.00	7	5.1700E-12	4.8000E-06
186	ZANMOD01	.00	8	4.8314E-12	8.4000E-05
187	CCX-IV-XR1	.00	6	4.6030E-12	2.4000E-05
188	CCX-PL4MOD1-SW	.00	8	4.5841E-12	1.1000E-05
189	EC2BS002TM	.00	178	3.9492E-12	2.7000E-03
190	EC2BS022TM	.00	178	3.9492E-12	2.7000E-03
191	EC2BS221TM	.00	178	3.9492E-12	2.7000E-03
192	CCX-EP-SA	.00	8	3.5885E-12	8.6200E-06
193	PL4MOD12	.00	16	3.4699E-12	2.0900E-03
194	IDBBSDD1LF	.00	7	3.4067E-12	4.8000E-06
195	IDBBSDK1LF	.00	7	3.4067E-12	4.8000E-06
196	IDBBSDS1LF	.00	7	3.4067E-12	4.8000E-06
197	IDCBSDD1LF	.00	4	3.2949E-12	4.8000E-06
198	IDK-BSDK1LF	.00	4	3.2949E-12	4.8000E-06
199	IDCBSDS1LF	.00	4	3.2949E-12	4.8000E-06
200	EC1MOD01	.00	16	3.2830E-12	2.0200E-04
201	PMAEHOA1SAX	.00	6	2.7225E-12	8.0000E-05
202	PMDMOD11	.00	194	2.6151E-12	2.0900E-03
203	PMAMOD42	.00	4	2.5390E-12	6.3500E-04
204	EC2MOD01	.00	14	2.5059E-12	2.0200E-04
205	CCX-PL1MOD1-SW	.00	4	1.9811E-12	1.1000E-05
206	CCX-PL7MOD1-SW	.00	4	1.9811E-12	1.1000E-05
207	RNAEPRNPSA	.00	9	1.7508E-12	1.7100E-04
208	RNBEPRNPSA	.00	9	1.7508E-12	1.7100E-04
209	ZON-MAN01	.00	7	1.7244E-12	2.6700E-03
210	SWNTP001RI	.00	5	1.5824E-12	5.2300E-03
211	SWB-MAN02	.00	4	1.5079E-12	1.6000E-03
212	SW7EPSBPASA	.00	7	1.4734E-12	1.7100E-04
213	IDDFD019RQ	.00	51	1.4267E-12	1.2000E-05
214	IDOFD020RQ	.00	51	1.4267E-12	1.2000E-05
215	CCB-MAN01	.00	6	1.4190E-12	1.0700E-03
216	PL1MOD12	.00	7	1.4055E-12	2.0900E-03
217	PL7MOD12	.00	7	1.4055E-12	2.0900E-03
218	CCX-PMDMOD1-SW	.00	49	1.3046E-12	1.1000E-05
219	CCX-PMDMOD4-SW	.00	49	1.3046E-12	1.1000E-05
220	PL40302ASA	.00	7	1.1774E-12	1.1600E-03
221	PMD0301ASA	.00	125	1.1577E-12	1.1600E-03
222	CCNTF101RI	.00	5	1.0836E-12	5.2300E-03
223	PMAMOD22X	.00	2	1.0720E-12	1.1600E-03
224	PMD0301BSA	.00	108	1.0455E-12	1.1600E-03
225	CC1EPSBPASA	.00	6	1.0401E-12	1.7100E-04
226	Z01MODO3	.00	8	1.0089E-12	1.0000E-04
227	DG2-LOGIC	.00	1	9.6501E-13	5.0000E-03
228	PMDMOD12	.00	83	9.0394E-13	2.0900E-03

229	SW7EP5BPSA	.00	5	8.7430E-13	1.7100E-04
230	CC1EP5BPSA	.00	5	8.7408E-13	1.7100E-04
231	PL40302BSA	.00	4	8.1801E-13	1.1600E-03
232	SW7EPCTFASA	.00	4	7.8104E-13	1.7100E-04
233	SW7EPCTFBSA	.00	4	7.8804E-13	1.7100E-04
234	ED1BSDS1LF	.00	3	7.8693E-13	4.8000E-06
235	ADX-MV-GO	.00	4	7.4873E-13	1.1000E-03
236	DAS	.00	4	7.3730E-13	1.3000E-02
237	CCX-AV-LA	.00	5	6.2306E-13	6.1000E-05
238	ZO2MOD03	.00	5	5.8920E-13	1.0000E-04
239	CMX-VS-FA	.00	7	5.2991E-13	3.8400E-05
240	CMX-CV-GO	.00	4	5.2014E-13	5.1000E-05
241	ED3BSDS1TM	.00	1	4.8805E-13	3.0000E-04
242	JWNTK001AF	.00	5	4.8728E-13	2.4000E-06
243	IDDBSD001LF	.00	28	4.7418E-13	4.8000E-06
244	IDDBSDK1LF	.00	28	4.7418E-13	6.8000E-06
245	IDDBSDS1LF	.00	28	4.7418E-13	4.8000E-06
246	PMDMOD41	.00	67	4.6607E-13	6.3500E-04
247	RC1OR195SP	.00	4	4.5386E-13	7.2200E-03
248	PL10302ASA	.00	3	4.3932E-13	1.1600E-03
249	PL70302ASA	.00	3	4.3932E-13	1.1600E-03
250	CCX-PMDEH0	.00	26	3.9613E-13	4.0300E-06
251	PRAAV108LA	.00	11	3.5205E-13	1.0900E-03
252	PRBAV108LA	.00	11	3.5205E-13	1.0900E-03
253	PMD0302ASA	.00	46	3.4461E-13	1.1600E-03
254	PL10302BSA	.00	2	3.4395E-13	1.1600E-03
255	PL70302BSA	.00	2	3.4395E-13	1.1600E-03
256	IDDMOD3J	.00	45	3.3440E-13	5.1600E-04
257	PL1MOD51	.00	2	3.2996E-13	8.7400E-04
258	RC1TL195UF	.00	3	3.2829E-13	5.2300E-03
259	CCX-HE-AF	.00	3	3.1908E-13	1.2000E-06
260	IDDMOD32	.00	58	3.1120E-13	3.1700E-04
261	PL1XS00ASA	.00	3	2.9976E-13	8.0000E-05
262	PL4XS00ASA	.00	3	2.9976E-13	8.0000E-05
263	PL7XS00ASA	.00	3	2.9976E-13	8.0000E-05
264	CCX-BC-SA	.00	5	2.8300E-13	8.4000E-06
265	PLMMOD41	.00	2	2.4203E-13	6.3500E-04
266	PMD0302BSA	.00	29	2.3248E-13	1.1600E-03
267	PRN-MAN01	.00	4	1.8641E-13	4.0800E-04
268	EC2MOD22	.00	17	1.8141E-13	4.8000E-05
269	PRAAV108TM	.00	9	1.6143E-13	5.0000E-04
270	PRBAV108TM	.00	9	1.6143E-13	5.0000E-04
271	CCX-TRNSM	.00	2	1.4899E-13	2.0100E-04
272	EC1MOD13	.00	2	1.4067E-13	4.8000E-05
273	EC2MOD23	.00	2	1.4067E-13	4.8000E-05
274	CCX-XMTTR	.00	3	1.3822E-13	2.0100E-04
275	IDDMOD38	.00	31	1.1935E-13	3.1700E-04
276	ZOX-BL-ER	.00	1	9.6367E-14	1.3600E-06
277	ED2MOD01	.00	1	9.5368E-14	5.0400E-04
278	ZOX-FL-CP	.00	1	9.2149E-14	1.3000E-06
279	PMDXS00ASA	.00	32	7.0721E-14	8.0000E-05
280	PMDEH0A1SA	.00	28	6.2061E-14	8.0000E-05
281	IDDMOD21	.00	6	4.9960E-14	1.9200E-04
282	PMDMOD42	.00	11	4.0967E-14	6.3500E-04
283	IDABSD001TM	.00	3	3.1641E-14	3.0000E-04
284	IDABSDK1TM	.00	3	3.1641E-14	3.0000E-04
285	PRX-HR-ML	.00	4	2.4314E-14	1.2000E-07
286	PMDEH0A2SA	.00	10	1.7764E-14	8.0000E-05
287	IDDMOD34	.00	10	1.2212E-14	4.3200E-05
288	IDDMOD35	.00	4	5.7732E-15	2.1900E-02
289	EC2MOD221	.00	3	1.3323E-15	1.6800E-05
290	IWX-XMTRLW	.00	2	1.3323E-15	9.2000E-09
291	IDDMOD22	.00	3	9.9920E-16	2.7000E-03
292	IDDMOD23	.00	3	9.9920E-16	2.7000E-03
293	PRCEP108SA	.00	1	2.2204E-16	1.7100E-04
294	PRDFP108SA	.00	1	2.2204E-16	1.7100E-04

SYSTEM UNAVAILABILITY (Q) = 1.152E-06
 NUMBER OF BASIC EVENTS = 294
 NUMBER OF CUTSETS = 6454

BASIC EVENT	IMPORTANCE (%INCREASE)	NUMBER OF CUTSETS	INCREASE IN SYSTEM UNAVAILABILITY	BASIC EVENT PROBABILITY
1 CCX-BPTW	487621.	26	5.6195E-03	1.2000E-06
2 IEV-RCSOD	429970.	457	4.9551E-03	4.4400E-06
3 IEV-CCWD	124277.	1942	1.4322E-03	6.0200E-04
4 IEV-RNSD	119245.	933	1.3742E-03	8.1500E-05
5 IWX-FL-GP	66127.2	168	7.6208E-04	1.2000E-05
6 IWX-CV-AO	66045.8	395	7.6114E-04	3.1000E-05
7 ADX-EV-SA	64709.1	290	7.4574E-04	3.8700E-05
8 IWX-MV-GO1	64685.7	266	7.4546E-04	3.8700E-05
9 CCX-ORY-SPX	64667.2	112	7.4525E-04	3.6300E-06
10 CCX-KMTRX	64401.2	97	7.4218E-04	2.6300E-06
11 IWB-PLUG	62580.0	382	7.2120E-04	2.4000E-04
12 CCX-PMAMOD1-SW	61881.9	128	7.1315E-04	3.1000E-05
13 CCX-PMAMOD1X	61227.6	195	7.0561E-04	4.6300E-05
14 CCX-EP-SAMX	60889.9	87	7.0172E-04	2.9400E-06
15 CCX-PMA030X	60862.4	130	7.0140E-04	1.3800E-05
16 IDCBSDD1TM	59723.1	126	6.8827E-04	3.0000E-04
17 IDCBSDK1TM	59723.1	126	6.8827E-04	3.0000E-04
18 IDCBSDE1TM	59723.1	126	6.8827E-04	3.0000E-04
19 IRAEP121BSAX	52454.3	45	6.0450E-04	6.8300E-05
20 IEV-LOCA24D	40184.6	393	4.6310E-04	1.1300E-05
21 IEV-LOCA24ND	25179.3	121	2.9018E-04	1.6800E-05
22 CCX-EP-SAM	14019.3	215	1.6156E-04	8.6200E-06
23 CCX-PMAMOD1	3040.10	87	3.5035E-05	1.4100E-04
24 CCX-PMA030	2782.86	59	3.2071E-05	9.6900E-05
25 IEV-LOSPD	2778.91	2394	3.2025E-05	4.4400E-03
26 IDAMOD05	2294.61	354	2.5444E-05	5.1600E-04
27 IDAMOD04	2282.16	340	2.6300E-05	3.1700E-04
28 IDABSDS1TM	2201.19	255	2.5367E-05	3.0000E-04
29 CCX-BY-PN	2003.56	237	2.3090E-05	4.7000E-05
30 PMAMOD11	1928.43	296	2.2224E-05	2.0900E-03
31 PMA0301ASA	1885.46	218	2.1729E-05	1.1600E-03
32 PMA0301BAA	1885.46	218	2.1729E-05	1.1600E-03
33 PMAXSO0ASA	1538.93	28	1.7735E-05	8.0000E-05
34 IEV-LOCAPRND	1416.72	59	1.6327E-05	1.5100E-05
35 CCX-IV-XR	1405.95	132	1.6203E-05	2.4000E-05
36 ED1HOD03	1024.68	130	1.1809E-05	2.2020E-03
37 ZOX-PD-ES	984.451	112	1.1345E-05	2.0000E-03
38 ECX-CB-GO	983.992	91	1.1340E-05	1.2000E-03
39 ECX-CS-GC	980.760	73	1.1303E-05	7.3000E-04
40 ZOX-DG-DS	979.932	49	1.1293E-05	2.8000E-04
41 ZOX-DG-DR	979.109	56	1.1284E-05	4.4000E-04
42 ED1MOD11	974.509	54	1.1231E-05	3.1700E-04
43 ED1MOD113	974.509	54	1.1231E-05	3.1700E-04
44 ZOX-PD-ER	928.132	31	1.0696E-05	1.3000E-04
45 CCX-BY-PN1	825.250	16	9.5105E-06	5.7000E-05
46 ZOX-BL-ES	823.345	15	9.4885E-06	6.0000E-05
47 ALL-IND-FAIL	637.259	27	7.3440E-06	1.0000E-06
48 PMAXSO0ASA	634.653	158	7.3140E-06	8.0000E-05
49 PMAMOD11X	583.004	369	6.7188E-06	6.5300E-04
50 PMA0301ASA	572.046	176	6.5925E-06	1.6500E-04
51 PMA0301BAA	557.466	157	6.4245E-06	1.6500E-04
52 IDABSDS1LP	481.755	24	5.5519E-06	4.8000E-06
53 IWN-MAN00	451.699	189	5.2056E-06	1.1500E-03
54 CCX-LS-FA	411.959	32	4.7476E-06	5.3700E-06
55 CCX-PMAMOD4	409.572	41	4.7201E-06	4.9800E-05
56 CCX-PMAMOD4-SW	386.858	12	4.4583E-06	1.1000E-05
57 CCX-PMAEH0X	386.255	11	4.4513E-06	4.0300E-06
58 CCX-INPUT-LOGIC	161.233	29	1.8581E-06	1.0300E-04
59 CCX-ORY-SP	145.842	18	1.6807E-06	2.7700E-04
60 CCX-KMTR195	145.638	16	1.6784E-06	2.0100E-04
61 RNX-PM-FS	142.748	48	1.6451E-06	7.7000E-04
62 IWBCV123AO	142.313	132	1.6401E-06	5.8000E-04
63 IWBCV125AO	142.313	132	1.6401E-06	5.8000E-04
64 IWBCV122AO	141.920	132	1.6355E-06	1.7500E-03
65 IWBCV124AO	141.920	132	1.6355E-06	1.7500E-03
66 EC1BS001TM	138.680	442	1.5982E-06	2.7000E-03
67 EC1BS012TM	138.680	442	1.5982E-06	2.7000E-03
68 EC1BS121TM	138.680	442	1.5982E-06	2.7000E-03
69 RNX-KV-GO	138.515	42	1.5963E-06	6.1000E-04
70 EC1MOD12	133.932	66	1.5435E-06	4.8000E-05
71 IDAMOD06	130.018	48	1.4984E-06	4.3200E-05
72 PL5MOD11	129.990	72	1.4980E-06	2.0900E-03

73	LPH-MAN05	123.393	37	1.4220E-06	6.8300E-04
74	EC1MOD121	123.231	24	1.4202E-06	1.6800E-05
75	PXX-AV-LA	118.190	57	1.3621E-06	6.1000E-05
76	PL50301ASA	115.600	46	1.3322E-06	1.1600E-03
77	PL50301BSA	115.600	46	1.3322E-06	1.1600E-03
78	ZO1MOD01	103.382	518	1.1914E-06	1.0200E-02
79	ED1MOD01	100.049	22	1.1530E-06	0.6000E-04
80	IW1TL170UFX	98.2824	33	1.1326E-06	6.8400E-05
81	IW2TL160UFX	98.2824	33	1.1326E-06	6.8400E-05
82	IW1OR170SPX	98.1956	34	1.1316E-06	9.4600E-05
83	IW2OR160SPX	98.1956	34	1.1316E-06	9.4600E-05
84	EC1CB100VO	96.6542	375	1.1139E-06	1.2300E-02
85	EC1BS001LF	93.4604	7	1.0771E-06	4.8000E-06
86	IDAMOD08	84.8922	96	9.7833E-07	3.1700E-04
87	PMAMOD12X	84.8852	123	9.7825E-07	6.5300E-06
88	CKX-PMAMOD2X	82.4348	22	9.5001E-07	6.5800E-05
89	CCX-INPUT-LOGICK	81.0340	12	9.3387E-07	6.5900E-05
90	CCX-IN-LOGIC-SW	78.5181	8	9.0487E-07	1.1000E-05
91	CCX-PMAMOD2-SW	78.5181	8	9.0487E-07	1.1000E-05
92	ED1MOD13	75.8458	16	8.7408E-07	3.1700E-04
93	ED1MOD07	75.8110	16	8.7367E-07	3.0500E-04
94	RHN-MAN05	75.6023	743	8.7127E-07	1.6000E-03
95	IWA-PLUG	75.5854	136	8.7107E-07	2.4000E-04
96	IDBBSDD1TM	75.3005	125	8.6779E-07	3.0000E-04
97	IDBBSDK1TM	75.1005	125	8.6779E-07	3.0000E-04
98	IDBBSDS1TM	75.3005	125	8.6779E-07	3.0000E-04
99	PMA0302ASAX	74.1932	59	8.5503E-07	1.6500E-04
100	CCX-PLAMOD1	72.5212	15	8.3576E-07	1.4100E-04
101	IWACV123AO	72.0439	126	8.3026E-07	5.8000E-04
102	IWACV125AO	72.0439	126	8.3026E-07	5.8000E-04
103	IRAEV121ASAX	71.3025	42	8.2172E-07	5.8300E-05
104	IDDBSDD1TM	65.5430	343	7.5534E-07	3.0000E-04
105	IDDBBSDK1TM	65.5430	343	7.5534E-07	3.0000E-04
106	IDDBBSDS1TM	65.5430	343	7.5534E-07	3.0000E-04
107	RNDEP023SA	64.6235	267	7.4475E-07	1.7100E-04
108	CCX-PMDMOD1	64.2159	249	7.4005E-07	1.4100E-04
109	IDBF0D013RQ	61.6806	10	7.1083E-07	1.2000E-05
110	IDBF0D014RQ	61.6806	10	7.1083E-07	1.2000E-05
111	IDBBSDD1LF	61.5851	7	7.0973E-07	4.8000E-06
112	IDBBSDF1LF	61.5851	7	7.0973E-07	4.8000E-06
113	IDBBSDS1LF	61.5851	7	7.0973E-07	4.8000E-06
114	IDCFD007RQ	59.6784	8	6.8776E-07	1.2000E-05
115	IDCFD008RQ	59.6784	8	6.8776E-07	1.2000E-05
116	PMA0302RSAX	59.6135	40	6.8701E-07	1.6500E-04
117	IDCBSDDD1LF	59.5640	4	6.8644E-07	4.8000E-06
118	IDCBSDK1LF	59.5640	4	6.8644E-07	4.8000E-06
119	IDCBSDS1LF	59.5640	4	6.8644E-07	4.8000E-06
120	ZO1MOD04	52.4098	82	6.0399E-07	1.2500E-03
121	CCX-PL403	44.6383	12	5.1443E-07	9.6900E-05
122	CCX-PL1MOD1	44.4915	8	5.1274E-07	1.4100E-04
123	CCX-PL7MOD1	44.4915	8	5.1274E-07	1.4100E-04
124	EC5EPMBG1SA	44.4793	8	5.1260E-07	1.7100E-04
125	IEV-RNSND	37.9729	46	4.3761E-07	9.6100E-04
126	IEV-CCWND	37.8690	69	4.3642E-07	3.7500E-03
127	RNX-CV-GO	37.6962	11	4.3443E-07	5.1000E-05
128	RNX-PM-ER	37.2848	10	4.2968E-07	1.4000E-05
129	CCK-PM-ER	37.2846	10	4.2968E-07	1.4000E-05
130	SWX-PM-ER	37.2846	10	4.2968E-07	1.4000E-05
131	CCX-PL4MOD1-SW	36.1610	8	4.1673E-07	1.1000E-05
132	CCX-EP-SA	36.1227	8	4.1629E-07	8.6200E-06
133	ZO2MOD01	34.0246	181	3.9211E-07	2.0200E-02
134	RNBMOD07S	33.3259	141	3.8406E-07	1.5300E-02
135	EC2CB200VO	32.6089	139	3.7580E-07	1.2300E-02
136	SWBMOD02	32.2417	147	3.7157E-07	2.4400E-02
137	CCBMOD018	30.9650	88	3.5685E-07	1.0400E-02
138	EC1REDG2GA	28.7635	55	3.3148E-07	4.3600E-03
139	ED2MOD03	26.3351	68	3.0350E-07	2.7000E-03
140	ED3MOD03	25.6999	35	2.9618E-07	2.2020E-03
141	PL4MOD11	25.5757	43	2.9474E-07	2.0900E-03
142	PL1MOD11	25.4954	36	2.9382E-07	2.0900E-03
143	PL7MOD11	25.4954	36	2.9382E-07	2.0900E-03
144	SWBMOD09P	25.4724	31	2.9355E-07	1.8500E-03
145	IWN-MAN00C	23.1650	23	2.6696E-07	5.0000E-02
146	CCX-HE-AF	23.0727	3	2.6590E-07	1.2000E-06
147	RHN-MAN04	21.4931	122	2.4769E-07	5.5000E-02
148	ZO2MOD04	19.9579	44	2.3000E-07	1.2500E-03
149	PL40301ASA	19.2273	29	2.2158E-07	1.1600E-03
150	PL40301BSA	19.2005	26	2.2127E-07	1.1600E-03
151	PL10301ASA	19.1722	25	2.2095E-07	1.1600E-03
152	PL70301ASA	19.1722	25	2.2095E-07	1.1600E-03
153	PL10301BSA	19.1650	24	2.2087E-07	1.1600E-03

154	PL703D1BSA	19.1650	24	2.2087E-07	1.1600E-03
155	IWNTK001AF	17.6176	5	2.0303E-07	2.4000E-06
156	PRX-HR-ML	17.5815	4	2.0262E-07	1.2000E-07
157	CCK-PL103	16.6552	6	3.9194E-07	9.6900E-05
158	CCK-PL703	16.6552	6	3.9194E-07	9.6900E-05
159	PL5X800ASA	16.6526	6	3.9194E-07	8.0000E-05
160	OTH-R1	16.6477	2242	3.9185E-07	4.2000E-01
161	CCK-IV-XR1	16.6418	5	3.9179E-07	2.4000E-05
162	CCK-PMD030	16.1118	163	1.8568E-07	9.6900E-05
163	CCK-PL1MOD1-SW	15.6274	4	1.8010E-07	1.1000E-05
164	CCK-PL7MOD1-SW	15.6274	4	1.8010E-07	1.1000E-05
165	ED1BSSD1LF	14.2257	3	1.6394E-07	4.8000E-06
166	CCK-PMDM04	14.1413	118	1.6297E-07	4.9800E-05
167	ADN-MAN01	14.0243	58	1.6162E-07	4.9300E-04
168	IWX-KMTRLW	12.5657	2	1.4481E-07	9.2000E-09
169	IDDFD019RQ	10.3168	51	1.1889E-07	1.2000E-05
170	IDDPD020RQ	10.3168	51	1.1889E-07	1.2000E-05
171	CCK-PMDM01-SW	10.2913	49	1.1860E-07	3.1000E-05
172	CCK-PMDM04-SW	10.2913	49	1.1860E-07	3.1000E-05
173	IDDBSDD1LF	8.57194	20	9.8786E-08	4.8000E-06
174	IDDBSDK1LF	8.57194	28	9.8786E-08	4.8000E-06
175	IDDBSDD1LF	8.57194	28	9.8786E-08	4.8000E-06
176	CCK-PMDEH0	8.52925	26	9.8294E-08	4.0300E-06
177	ED3MOD01	7.48046	10	8.6208E-08	5.0400E-04
178	ED3MOD07	7.05012	26	8.1244E-08	5.0500E-04
179	MDAS	6.52112	79	7.5152E-08	1.0000E-02
180	REC-MANDAS	6.34086	36	7.3074E-08	1.1600E-02
181	ZOK-FL-GP	6.15073	1	7.0883E-08	1.3000E-06
182	ZOK-BL-ER	6.14855	1	7.0858E-08	1.3600E-06
183	Z01DG001TM	5.24938	95	6.0496E-08	4.6000E-02
184	ZANMOD01	4.99041	8	5.7511E-08	8.4000E-05
185	PMAMOD41	3.79378	34	4.3721E-08	6.3500E-04
186	RNAMOD06P	3.78582	85	4.3629E-08	1.5300E-02
187	PMAEH0A1SAX	2.95273	6	3.4028E-08	8.0000E-05
188	CCK-BC-SA	2.92334	5	3.3690E-08	8.4000E-06
189	IEV-LOSPND	2.34553	40	2.7031E-08	1.7100E-02
190	SWAMOD07	2.25520	39	2.5990E-08	7.1200E-03
191	IDAMOD02	2.25052	31	2.5936E-08	2.7000E-03
192	IDAMOD03	2.25052	31	2.5936E-08	2.7000E-03
193	ED2MOD11	1.45821	20	1.6805E-08	3.1700E-04
194	EC1MOD01	1.41000	16	1.6249E-08	2.0200E-04
195	CCAMOD02	1.35077	37	1.5567E-08	7.1000E-03
196	RHN-MAN05C	1.28342	27	1.4791E-08	1.5000E-01
197	CMX-VS-FA	1.19739	7	1.3799E-08	3.8400E-05
198	EC2MOD01	1.07623	14	1.2403E-08	2.0200E-04
199	EC1REDG1GA	0.94233	37	1.0859E-08	4.3600E-03
200	PMAMOD21X	0.908772	14	1.0473E-08	1.1600E-03
201	RNAEPRNPSA	0.888289	9	1.0237E-08	1.7100E-04
202	RNBEPRNPSA	0.888289	9	1.0237E-08	1.7100E-04
203	CCK-AV-LA	0.886246	5	1.0213E-08	6.1000E-05
204	CMX-CV-GO	0.884932	4	1.0198E-08	5.1000E-05
205	Z01MOD03	0.875326	8	1.0088E-08	1.0000E-04
206	SW7EPSPBPASA	0.747526	7	8.6148E-09	1.7100E-04
207	DG1-LOGIC	0.702797	1	8.0993E-09	5.0000E-03
208	SWAMOD09P	0.631622	22	7.2791E-09	1.8500E-03
209	CC1EPSPBPASA	0.527678	6	6.0812E-09	1.7100E-04
210	Z02MOD03	0.511209	5	5.8914E-09	1.0000E-04
211	SW7EPSPBPASA	0.443581	5	5.1120E-09	1.7100E-04
212	CC1EPSPBPASA	0.443468	5	5.1107E-09	1.7100E-04
213	SW7EPCTFASA	0.399814	4	4.6076E-09	1.7100E-04
214	SW7EPCTFBSA	0.399814	4	4.6076E-09	1.7100E-04
215	PMAMOD42	0.346729	4	3.9958E-09	6.3500E-04
216	EC2MOD22	0.327931	17	3.7792E-09	4.8000E-05
217	PL1X5000ASA	0.325111	3	3.7467E-09	8.0000E-05
218	PL4X5000ASA	0.325111	3	3.7467E-09	8.0000E-05
219	PL7X5000ASA	0.325111	3	3.7467E-09	8.0000E-05
220	EC1MOD13	0.254277	2	2.9304E-09	4.8000E-05
221	EC2MOD23	0.254277	2	2.9304E-09	4.8000E-05
222	RHN-MAN03	0.253904	36	2.9261E-09	4.2600E-03
223	SUC-R1S	0.244857	152	2.8218E-09	5.8000E-01
224	PL4MOD12	0.143762	16	1.6568E-09	4.0900E-03
225	ED3BSSD1TM	0.141123	1	1.6264E-09	3.0000E-04
226	EC2BS002TM	0.126576	178	1.4587E-09	2.7000E-03
227	EC2BS022TM	0.126576	178	1.4587E-09	2.7000E-03
228	EC2BS221TM	0.126576	178	1.4587E-09	2.7000E-03
229	CCB-MAN01	0.114950	6	1.3247E-09	1.0700E-03
230	PMDMOD11	0.108348	194	1.2486E-09	2.0900E-03
231	PL4C302ASA	8.797138E-02	7	1.0138E-09	1.1600E-03
232	REC-MANDASC	8.735669E-02	46	1.0067E-09	5.0600E-01
233	PMD0301ASA	8.650312E-02	125	9.9689E-10	1.1600E-03
234	IDDMOD32	8.515672E-02	58	9.8138E-10	3.1700E-04

235	SWB-MAN02	8.164717E-02	4	9.40938E-10	1.6000E+03
236	PMA MOD22X	8.009917E-02	108	9.23098E-10	1.1600E+03
237	PMD0301BSA	7.812490E-02	108	9.00348E-10	1.1600E+03
238	PMDXS00ASA	7.670215E-02	108	8.83948E-10	8.00008E+05
239	PMDEHOA1SA	6.731004E-02	108	7.75718E-10	8.00008E+05
240	CCX-TRNSM	6.430755E-02	108	7.41108E-10	2.01000E+06
241	PMDMOD41	6.364813E-02	67	7.33508E-10	6.35000E+04
242	PL40302BSA	6.111958E-02	6	7.04378E-10	1.16000E+03
243	CCX-XMTR	5.965939E-02	3	6.87588E-10	2.01000E+04
244	ADX-MV-GO	5.898833E-02	4	6.79928E-10	1.16000E+03
245	PLIMOD12	5.823332E-02	7	6.71108E-10	2.09000E+03
246	PLT MOD12	5.823332E-02	7	6.71108E-10	2.09000E+03
247	IDAMOD07	5.657114E-02	15	6.51958E-10	2.19000E+02
248	IDDMOD33	5.620487E-02	45	6.47738E-10	2.26000E+04
249	ZON-MAN01	5.589176E-02	7	6.44128E-10	2.67000E+03
250	ZD2DG002TM	4.115226E-02	42	6.74258E-10	4.60000E+02
251	PRN-MAN01	3.962836E-02	4	6.56698E-10	4.08000E+04
252	RHN-MAN04-SUCC	3.951797E-02	373	4.55428E-10	9.45000E+01
253	PMDMOD12	3.745148E-02	83	4.31608E-10	2.09000E+03
254	OTH-R2	3.420154E-02	29	3.94158E-10	2.40000E+01
255	PLMMOD41	3.3052215E-02	2	3.80918E-10	6.35000E+04
256	PL10302ASA	3.282440E-02	3	3.78288E-10	2.16000E+03
257	PL70302ASA	3.282440E-02	3	3.78288E-10	2.16000E+03
258	PL1MOD51	3.273033E-02	2	3.77208E-10	8.74000E+04
259	IDDMOD38	3.265911E-02	31	3.76388E-10	3.17000E+04
260	PRAAV108TM	2.800077E-02	9	3.22698E-10	5.00000E+04
261	PRBAV108TM	2.800077E-02	9	3.22698E-10	5.00000E+04
262	PRAAV108LA	2.799554E-02	11	3.22638E-10	1.09000E+03
263	PRBAV108LA	2.799554E-02	11	3.22638E-10	1.09000E+03
264	SWNTP001RI	2.611681E-02	5	3.00988E-10	5.23000E+03
265	PMD0302ASA	2.574853E-02	46	2.96748E-10	1.16000E+03
266	PL10302BSA	2.569876E-02	2	2.96168E-10	1.16000E+03
267	PL70302BSA	2.569876E-02	2	2.96168E-10	1.16000E+03
268	IDDMOD34	2.452918E-02	10	2.82688E-10	4.32000E+05
269	IDDMOD21	2.257463E-02	6	2.60168E-10	1.92000E+04
270	PMDEHOA2SA	1.926585E-02	10	2.22038E-10	8.00000E+05
271	CNTF101RI	1.788396E-02	5	2.06108E-10	5.23000E+03
272	PMD0302BSA	1.737030E-02	29	2.00188E-10	1.16000E+03
273	DG2-LOGIC	1.6663488E-02	1	1.92048E-10	5.00000E+03
274	ED2MOD01	1.6411105E-02	1	1.89138E-10	5.04000E+04
275	SUC-R2S	9.471867E-03	9	1.09168E-10	7.60000E+01
276	AD2MOD01	9.4189798E-03	21	1.08558E-10	5.54000E+02
277	AD2MOD02	9.4189798E-03	21	1.08558E-10	5.54000E+02
278	AD3MOD03	9.4189798E-03	21	1.08558E-10	5.54000E+02
279	AD3MOD04	9.4189798E-03	21	1.08558E-10	5.54000E+02
280	IDABSD01TM	9.149263E-03	3	1.05448E-10	3.00000E+04
281	IDABSDK1TM	9.149263E-03	3	1.05448E-10	3.00000E+04
282	EC2MOD221	8.881094E-03	3	7.93008E-11	1.68000E+05
283	DAS	6.333758E-03	4	7.29938E-11	1.00000E+02
284	PMDMOD42	5.594607E-03	11	6.44748E-11	6.35000E+04
285	RC1TL195UF	5.4183268E-03	3	6.24438E-11	5.23000E+03
286	RC1OR195SP	5.4152638E-03	4	6.24088E-11	7.22000E+03
287	PRCEF108SA	1.126555E-04	1	1.29838E-12	1.71000E+04
288	PRDEP108SA	1.126555E-04	1	1.29838E-12	1.71000E+04
289	IDDMOD22	3.202561E-05	3	3.69088E-13	2.70000E+03
290	IDDMOD23	3.202561E-05	3	3.69088E-13	2.70000E+03
291	IDDMOD35	2.237357E-05	4	2.57848E-13	2.19000E+02
292	RN23MOD55	.000000	875	0.00000E+00	1.00000E+00
293	IWACV122AO	.000000	126	0.00000E+00	1.00000E+00
294	IWACV124AO	.000000	126	0.00000E+00	1.00000E+00

Table 54B-9

CASE 4 LIST OF TOP 200 DOMINANT CUTSETS

Reduced S-m of Cutsets 2.428E-06

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT	EVENT PROB.	IDENTIFIER
1	5.55E-07	22.86	OVERDRAINING OF RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT RHN-MAN04-SUCC OPERATOR FAILS TO OPEN TWO IRMST MOVES COND. PROB. OF RHN-MAN05 (OP. FAILS TO OPEN RNS MOV V023)	4.44E-06 5.00E-01 5.00E-01 5.00E-01	IEV-RCS00 RHN-MAN04 SUCC RHN-MAN05 RHN-MAN05C	
2	5.55E-07	22.86	OVERDRAINING OF RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT OPERATOR FAILS TO ISOLATE RNS PIPE RUPTURE RHN-MAN04C COND. PROB. OF RHN-MAN05 (OP. FAILS TO OPEN RNS MOV V023)	4.44E-06 5.00E-01 5.00E-01 5.00E-01	IEV-RCS00 RHN-MAN04 RHN-MAN04C RHN-MAN05C	
3	2.60E-07	10.71	LOSS OF CCS/SWS WITH RCS FILLED INITIATING EVENT OCCURS COND. PROB. OF REC-MANDAS (FAILURE OF MANUAL DAS ACT.) CCF OF ORIFICES OPERATOR FAILS TO RECOGNIZE THE NEED FOR RCS DEPRESSURIZATION	3.75E-03 5.00E-01 2.77E-04 5.00E-01	IEV-COMND REC-MANDASC CCX-DRY-SP LPM-MAN05	
4	1.88E-07	7.74	LOSS OF CCS/SWS WITH RCS FILLED INITIATING EVENT OCCURS COND. PROB. OF REC-MANDAS (FAILURE OF MANUAL DAS ACT.) CCF OF PRESSURE TRANSMITTERS OPERATOR FAILS TO RECOGNIZE THE NEED FOR RCS DEPRESSURIZATION	3.75E-03 5.00E-01 2.01E-04 5.00E-01	IEV-COMND REC-MANDASC CCX-XMTR195 LPM-MAN05	
5	1.30E-07	5.35	LOSS OF CCS/SWS WITH RCS FILLED INITIATING EVENT OCCURS COND. PROB. OF REC-MANDAS (FAILURE OF MANUAL DAS ACT.) CCF OF ORIFICES PRN-MAN01 OPERATOR FAILS TO ACTUATE ADS BEFORE CORE DAMAGE	3.75E-03 5.00E-01 2.77E-04 5.00E-01 5.00E-01	IEV-COMND REC-MANDASC CCX-DRY-SP PRN-MAN01 ADM-MAN01	
6	9.66E-08	3.98	LOSS OF CCS/SWS WITH RCS FILLED INITIATING EVENT OCCURS COND. PROB. OF REC-MANDAS (FAILURE OF MANUAL DAS ACT.) COMMON MODE FAILURE OF INPUT LOGIC GROUPS OPERATOR FAILS TO RECOGNIZE THE NEED FOR RCS DEPRESSURIZATION	3.75E-03 5.00E-01 1.03E-04 5.00E-01	IEV-COMND REC-MANDASC CCX-INPUT LOGIC LPM-MAN05	
7	9.42E-08	3.88	LOSS OF CCS/SWS WITH RCS FILLED INITIATING EVENT OCCURS COND. PROB. OF REC-MANDAS (FAILURE OF MANUAL DAS ACT.) CCF OF PRESSURE TRANSMITTERS PRN-MAN01 OPERATOR FAILS TO ACTUATE ADS BEFORE CORE DAMAGE	3.75E-03 5.00E-01 2.01E-04 5.00E-01 5.00E-01	IEV-COMND REC-MANDASC CCX-XMTR195 PRN-MAN01 ADM-MAN01	
8	6.65E-08	2.74	LOSS OF RNS WITH RCS FILLED INITIATING EVENT OCCURS COND. PROB. OF REC-MANDAS (FAILURE OF MANUAL DAS ACT.) CCF OF ORIFICES OPERATOR FAILS TO RECOGNIZE THE NEED FOR RCS DEPRESSURIZATION	9.61E-04 5.00E-01 2.77E-04 5.00E-01	IEV-RNSND REC-MANDASC CCX-DRY-SP LPM-MAN05	
9	4.83E-08	1.99	LOSS OF RNS WITH RCS FILLED INITIATING EVENT OCCURS COND. PROB. OF REC-MANDAS (FAILURE OF MANUAL DAS ACT.) CCF OF PRESSURE TRANSMITTERS OPERATOR FAILS TO RECOGNIZE THE NEED FOR RCS DEPRESSURIZATION	9.61E-04 5.00E-01 2.01E-04 5.00E-01	IEV-RNSND REC-MANDASC CCX-XMTR195 LPM-MAN05	
10	2.47E-08	1.02	LOSS OF RNS WITH RCS FILLED INITIATING EVENT OCCURS COND. PROB. OF REC-MANDAS (FAILURE OF MANUAL DAS ACT.) COMMON MODE FAILURE OF INPUT LOGIC GROUPS OPERATOR FAILS TO RECOGNIZE THE NEED FOR RCS DEPRESSURIZATION	9.61E-04 5.00E-01 1.03E-04 5.00E-01	IEV-RNSND REC-MANDASC CCX-INPUT LOGIC LPM-MAN05	
11	1.81E-08	.75	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS DUE TO CCF OF THE SQUIB VALVES TO OPERATE	6.02E-04 3.00E-05	IEV-COMD ADM-EV-SA	

Table 54B-9

CASE 4 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET #HUB	PLANT	BASIC EVENT NAME	EVENT SUB	IDENTIFIER
1.2	1.62E-08	67	LOSS OF CCS/SMS WITH RCS FILLED INITIATING EVENT OCCURS FAILURE OF MANUAL DAS ACTUATION CCP OF THE POWER INTERFACE OUTPUT BOARDS IN PMS	LEV-COMD REC-MANDAS CCP-EP-SAM	3.75E-03 5.00E-01 8.62E-06
1.3	1.57E-08	65	LOSS OF CCS/SMS WITH RCS DRAINED INITIATING EVENT OCCURS CCP OF INRST INU MOVs 121A, 121B, & RMS VOL3	LEV-COMD REC-MANDAS	6.02E-04 2.60E-05 EMR-KV-G011
1.4	1.55E-08	64	LOSS OF CCS/SMS WITH RCS DRAINED INITIATING EVENT OCCURS COND. PROB. OF REC-MANDAS COMMON MODE FAILURE OF INPUT LOGIC GROUPS OPERATOR FAILS TO ACTUATE ADS BEFORE CORE DAMAGE	LEV-COMD REC-MANDAS CCP-INRST-LOGC ACN-MAND1	6.02E-04 5.00E-01 3.03E-04 5.00E-01
1.5	1.42E-08	58	LOSS OF CCS/SMS WITH RCS DRAINED INITIATING EVENT OCCURS ORIFICE FAILURE DUE TO PLUGGING OPERATOR FAILS TO OPEN TWO IRNST MOVs COND. PROB. OF RBN-MANDS TOP FAILS TO OPEN RMS MOV VOL231	LEV-COMD REC-MANDAS IRNST-MOVSPK ACN-MAND1	6.02E-04 9.46E-05 5.00E-01 5.00E-01
1.6	1.42E-08	58	LOSS OF CCS/SMS WITH RCS DRAINED INITIATING EVENT OCCURS COND. PROB. OF REC-MANDAS ORIFICE FAILURE DUE TO PLUGGING OPERATOR FAILS TO ACTUATE ADS BEFORE CORE DAMAGE	LEV-COMD REC-MANDAS IRNST-MOVSPK ACN-MAND1	6.02E-04 5.00E-01 9.46E-05 5.00E-01
1.7	1.42E-08	58	LOSS OF CCS/SMS WITH RCS DRAINED INITIATING EVENT OCCURS COND. PROB. OF REC-MANDAS ORIFICE FAILURE DUE TO PLUGGING OPERATOR FAILS TO ACTUATE ADS BEFORE CORE DAMAGE	LEV-COMD REC-MANDAS IRNST-MOVSPK ACN-MAND1	6.02E-04 5.00E-01 9.46E-05 5.00E-01
1.8	1.42E-08	58	LOSS OF CCS/SMS WITH RCS DRAINED INITIATING EVENT OCCURS ORIFICE FAILURE DUE TO PLUGGING OPERATOR FAILS TO OPEN TWO IRNST MOVs COND. PROB. OF RBN-MANDS TOP FAILS TO OPEN RMS MOV VOL231	LEV-COMD REC-MANDAS IRNST-MOVSPK ACN-MAND1	6.02E-04 9.46E-05 5.00E-01 5.00E-01
1.9	1.39E-08	57	LOSS OF CCS/SMS WITH RCS DRAINED INITIATING EVENT OCCURS CCF OF ACTUATION LOGIC GROUPS OPERATOR FAILS TO RECOGNIZE NEED AND TO OPEN RMS MOV VOL231	LEV-COMD REC-MANDAS CCF-PRMADZK	6.02E-04 4.63E-05 5.00E-01
20	1.29E-08	53	LOSS OF CCS/SMS WITH RCS DRAINED INITIATING EVENT OCCURS CCF OF ACTUATION LOGIC GROUPS OPERATOR FAILS TO OPEN TWO IRNST MOVs COND. PROB. OF RBN-MANDS TOP FAILS TO OPEN RMS MOV VOL231	LEV-COMD REC-MANDAS CCF-PRMADZK IRNST-MAND10 RBN-MAND10	6.02E-04 8.58E-05 5.00E-01 5.00E-01
21	1.03E-08	42	LOSS OF CCS/SMS WITH RCS DRAINED INITIATING EVENT OCCURS LEVEL TRANSMITTER FAILURE OPERATOR FAILS TO OPEN TWO IRNST MOVs COND. PROB. OF RBN-MANDS TOP FAILS TO OPEN RMS MOV VOL231	LEV-COMD REC-MANDAS LEVEL-TRANSPK IRNST-MAND10 RBN-MAND10	6.02E-04 6.84E-05 5.00E-01 5.00E-01
22	1.03E-08	42	LOSS OF CCS/SMS WITH RCS DRAINED INITIATING EVENT OCCURS LEVEL TRANSMITTER FAILURE OPERATOR FAILS TO OPEN TWO IRNST MOVs COND. PROB. OF RBN-MANDS TOP FAILS TO OPEN RMS MOV VOL231	LEV-COMD REC-MANDAS LEVEL-TRANSPK IRNST-MAND10 RBN-MAND10	6.02E-04 6.84E-05 5.00E-01 5.00E-01
23	1.03E-08	42	LOSS OF CCS/SMS WITH RCS DRAINED INITIATING EVENT OCCURS COND. PROB. OF REC-MANDAS LEVEL TRANSMITTER FAILURE OPERATOR FAILS TO ACTUATE ADS BEFORE CORE DAMAGE	LEV-COMD REC-MANDAS LEVEL-TRANSPK ACN-MAND1	6.02E-04 5.00E-01 6.84E-05 5.00E-01

Table 54B-9

CASE 4 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS	EVENT PROB	IDENTIFIER	
24	1.03E-08	.42	LOSS OF CCS/SWS COND. PROB. OF LEVEL OPERATOR FAILS	WITH RCS DRAINED REC-MANDAS TRANSMITTER TO ACTUATE ADS	INITIATING EVENT OCCURS (FAILURE OF MANUAL DAS ACT FAILURE BEFORE CORE DAMAGE)	6.02E-04 5.00E-01 6.84E-05 5.00E-01	IEV-COMD REC-MANDAS TM2TL160UF3 ADN-MANO1
25	9.03E-09	.37	LOSS OF CCS/SWS CCF OF GRAVITY OPERATOR FAILS	WITH RCS DRAINED INJECTION CHECK TO RECOGNIZE	INITIATING EVENT OCCURS VALVES TO OPEN NEED AND TO OPEN RNS MOV V023	6.02E-04 3.00E-05 5.00E-01	IEV-COMD TMX-CV-AU RHN-MAN05
26	7.80E-09	.32	LOSS OF OFFSITE OFFSITE SOFTWARE CCF FAILURE OF	POWER INITIATING AC POWER OF ALL CARDS MANUAL DAS	EVENT OCCURS RECOVERED IN 2 HOURS ACTUATION	1.71E-02 7.60E-01 1.20E-06 5.00E-07	IEV-LOSPD SUC-R2S CCX-SFTW REC-MANDAS
27	7.22E-09	.30	LOSS OF CCS/SWS CCF OF STRAINERS	WITH RCS DRAINED IN IRMST TANK	INITIATING EVENT OCCURS	6.02E-04 1.20E-05	IEV-COMD TMX-FL-GP
28	5.19E-09	.21	LOSS OF CCS/SWS FAILURE OF CCF OF ORIFICES OPERATOR FAILS	WITH RCS FILLED MANUAL DAS	INITIATING EVENT OCCURS REACTOR TRIP HARDWARE	3.75E-03 1.00E-02 2.77E-04 5.00E-01	IEV-COMD MDAS CCX-DRY-SP LPM-MANO5
29	4.29E-09	.18	LOSS OF OFFSITE FAILURE TO BATTERY FAILURE OF OPERATOR FAILS	POWER INITIATING RECOVER AC POWER IN 1 HOUR DBI PMS OUTPUT TO RECOGNIZE	EVENT OCCURS UNAVAILABLE LOGIC I/Os NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 2.20E-03 2.09E-03 5.00E-01	IEV-LOSPD OTB-R1 EDIMOD003 PMAMOD11 RHN-MAN05
30	4.15E-09	.17	LOSS OF CCS/SWS CCF OF LOGIC OPERATOR FAILS	WITH RCS DRAINED GROUP PROCESSING	INITIATING EVENT OCCURS	6.02E-04 1.38E-05 5.00E-01	IEV-COMD CCX-PNA030X RHN-MAN05
31	4.14E-09	.17	LOSS OF RNS WITH RCS FILLED FAILURE OF CCF OF THE POWER INTERFACE	MANUAL DAS ACTUATION OUTPUT BOARDS IN PMS	INITIATING EVENT OCCURS	9.61E-04 5.00E-01 8.62E-06	IEV-RNSND REC-MANDAS CCX-EP-SAM
32	3.90E-09	.16	LOSS OF CCS/SWS CCF OF INPUT OPERATOR FAILS COND. PROB. OF	WITH RCS DRAINED LOGIC GROUPS TO OPEN TWO RHN-MAN05 (OP.)	INITIATING EVENT OCCURS IRMST MOVs FAILS TO OPEN RNS MOV V023)	6.02E-04 2.59E-05 5.00E-01 5.00E-01	IEV-COMD CCX-INPUT-LOGICK RHN-MAN05 RHN-MAN05C
33	3.90E-09	.16	LOSS OF OFFSITE FAILURE TO CCF TO START FAILURE OF OPERATOR FAILS	POWER INITIATING RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS PMS OUTPUT TO RECOGNIZE	EVENT OCCURS HARDWARE LOGIC I/Os NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 2.09E-03 2.09E-03 5.00E-01	IEV-LOSPD OTB-R1 CCX-PD-ES PMAMOD11 RHN-MAN05
34	3.77E-09	.16	LOSS OF CCS/SWS FAILURE OF CCF OF PRESSURE TRANSMITTERS OPERATOR FAILS	WITH RCS FILLED MANUAL DAS REACTOR TRIP TRANSMITTERS TO RECOGNIZE THE NEED FOR RCS	INITIATING EVENT OCCURS HARDWARE DEPRESSURIZATION	3.75E-03 1.00E-02 2.01E-04 5.00E-01	IEV-COMD MDAS CCX-XMTR195 LPM-MAN05
35	3.31E-09	.14	LOSS OF CCS/SWS SOFTWARE CCF OF OPERATOR FAILS	WITH RCS DRAINED OUTPUT LOGIC I/Os	INITIATING EVENT OCCURS NEED AND TO OPEN RNS MOV V023	6.02E-04 1.10E-05 5.00E-01	IEV-COMD CCX-PHAMOD1-SW RHN-MAN05
36	3.09E-09	.13	LOSS OF OFFSITE OFFSITE SOFTWARE CCF	POWER INITIATING AC POWER OF ALL CARDS	EVENT OCCURS RECOVERED IN 1 HOUR	4.44E-03 5.80E-01 1.70E-06	IEV-LOSPD SUC-R1S CCX-SFTW

Table 54B-9

CASE 4 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME				EVENT PROB	IDENTIFIER
37	2.60E-09	.11	LOSS OF CCS/SWS WITH RCS FILLED FAILURE OF CCF OF ORIFICES PRN-MAN01 OPERATOR FAILS	INITIATING EVENT OCCURS MANUAL DAS REACTOR TRIP	HARDWARE		3.75E-03 1.00E-02 2.77E-04 5.00E-01 5.00E-01	IEV-COMND MIDAS CCX-ORY-SP PRN-MAN01 ADN-MAN01
38	2.59E-09	.11	LOSS OF CCS/SWS WITH RCS DRAINED FAILURE OF CCF OF THE POWER	INITIATING EVENT OCCURS MANUAL DAS ACTUATION INTERFACE OUTPUT BOARDS IN PMS			6.02E-04 5.00E-01 6.62E-06	IEV-COMD REC-MANDAS CCX-EP-SAM
39	2.46E-09	.10	LOSS OF OFFSITE POWER FAILURE TO RECOVER AC POWER IN 2 HOURS SOFTWARE CCF OF ALL CARDS FAILURE OF MANUAL DAS	INITIATING EVENT OCCURS WITH RCS FILLED RECOVER AC POWER IN 2 HOURS ACTUATION			1.71E-02 2.40E-01 1.20E-06 5.00E-01	IEV-LOSPND OTH-R2 CCX-SFTW REC-MANDAS
40	2.45E-09	.10	OVERDRAINING OF RCS DURING DRAIN OPERATOR FAILS IWN-MAN00C MECHANICAL	DOWN TO MID-LOOP TO ISOLATE RNS PIPE RUPTURE FAILURE CAUSES	INITIATING EVENT FAIL-TO-OPEN	MOV 023 TO	4.44E-06 5.00E-01 5.00E-01 2.21E-03	IEV-RCS00 RHN-MAN04 IWN-MAN00C RN23M005S
41	2.45E-09	.10	OVERDRAINING OF RCS DURING DRAIN RHN-MAN04-SUCC OPERATOR FAILS MECHANICAL	DOWN TO MID-LOOP TO OPEN TWO IRWST MOVs FAILURE CAUSES	INITIATING EVENT FAIL-TO-OPEN	MOV 023 TO	4.44E-06 5.00E-01 5.00E-01 2.21E-03	IEV-RCS00 RHN-MAN04-SUCC IWN-MAN00 RN23M005S
42	2.45E-09	.10	LOSS OF RNS WITH RCS DRAINED DUE TO CCF OF THE SQUIB VALVES TO OPERATE	INITIATING EVENT OCCURS			8.15E-05 3.00E-05	IEV-RNSD ADX-EV-SA
43	2.38E-09	.10	LOSS OF OFFSITE POWER FAILURE TO RECOVER AC POWER IN 1 HOUR BATTERY DB1 FAILURE UPON DEMAND OF LOGIC OPERATOR FAILS	INITIATING EVENT OCCURS WITH RCS DRAINED RECOVER AC POWER IN 1 HOUR UNAVAILABLE GROUP PROCESSING NEED AND TO OPEN RNS MOV V023			4.44E-03 4.20E-01 2.20E-03 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 ED1M0003 PMA0301ASA RHN-MAN05
44	2.38E-09	.10	LOSS OF OFFSITE POWER FAILURE TO RECOVER AC POWER IN 1 HOUR BATTERY DB1 FAILURE UPON DEMAND OF LOGIC OPERATOR FAILS	INITIATING EVENT OCCURS WITH RCS DRAINED RECOVER AC POWER IN 1 HOUR UNAVAILABLE GROUP PROCESSING NEED AND TO OPEN RNS MOV V023			4.44E-03 4.20E-01 2.20E-03 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 ED1M0003 PMA0301BSA RHN-MAN05
45	2.34E-09	.10	LOSS OF OFFSITE POWER FAILURE TO COMMON CAUSE FAILURE OF PMS OUTPUT OPERATOR FAILS	INITIATING EVENT OCCURS WITH RCS DRAINED RECOVER AC POWER IN 1 HOUR FAILURE - 4EV BREAKERS TO OPEN LOGIC I/Os NEED AND TO OPEN RNS MOV V023			4.44E-03 4.20E-01 1.20E-03 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 CCX-CB-GO PMAMOD11 RHN-MAN05
46	2.25E-09	.09	LOSS OF CCS/SWS WITH RCS FILLED SOFTWARE CCF OF ALL CARDS FAILURE OF MANUAL DAS	INITIATING EVENT OCCURS ACTUATION			3.75E-03 1.20E-06 5.00E-01	IEV-COMND CCX-SFTW REC-MANDAS
47	2.24E-09	.09	LOSS OF OFFSITE POWER FAILURE TO SOFTWARE CCF	INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ALL CARDS		WITH RCS DRAINED	4.44E-03 4.20E-01 1.20E-06	IEV-LOSPD OTH-R1 CCX-SFTW
48	2.19E-09	.09	LOSS OF CCS/SWS WITH RCS DRAINED CCF OF ORIFICES	INITIATING EVENT OCCURS			6.02E-04 3.63E-06	IEV-COMD CCX-ORY-SP

Table 54B-9

CASE 4 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME			EVENT PROB	IDENTIFIER
49	2.16E-09	.09	LOSS OF OFFSITE FAILURE TO CCF TO START FAILURE UPON OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS DEMAND OF LOGIC GROUP PROCESSING TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 2.00E-03 1.16E-03 5.00E-01	IEV-LOSPO OTH-R1 ZOK-PD-ES PMA0301ASA RHN-MAN05
50	2.16E-09	.09	LOSS OF OFFSITE FAILURE TO CCF TO START FAILURE UPON OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS DEMAND OF LOGIC GROUP PROCESSING TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 2.00E-03 1.16E-03 5.00E-01	IEV-LOSPO OTH-R1 ZOK-PD-ES PMA0301ASA RHN-MAN05
51	2.12E-09	.09	LOSS OF RNS WITH RCS DRAINED CCF OF IRWST INJ MOVs 121A, 121B, & RNS V023		INITIATING EVENT OCCURS	8.15E-05 2.60E-05	IEV-RNSD IWN-MV-G01
52	2.10E-09	.09	LOSS OF RNS WITH RCS DRAINED COND. PROB. OF REC-MANDAS COMMON MODE OPERATOR FAILS	INITIATING EVENT OCCURS (FAILURE OF MANUAL DAS ACT. FAILURE OF INPUT LOGIC GROUPS TO ACTUATE ADS BEFORE CORE DAMAGE		8.15E-05 5.00E-01 1.03E-04 5.00E-01	IEV-RNSD REC-MANDASC CCK-INPUT-LOGIC ADN-MAN01
53	1.93E-09	.08	LOSS OF CCS/SWS FAILURE OF COMMON MODE OPERATOR FAILS	WITH RCS FILLED MANUAL DAS FAILURE OF INPUT TO RECOGNIZE THE NEED FOR RCS	INITIATING EVENT OCCURS REACTOR TRIP LOGIC GROUPS DEPRESSURIZATION	3.75E-03 1.00E-02 1.03E-04 5.00E-01	IEV-COMND MDAS CCK-INPUT-LOGIC LPM-MAN05
54	1.93E-09	.08	LOSS OF RNS WITH RCS DRAINED ORIFICE FAILURE DUE TO PLUGGING OPERATOR FAILS COND. PROB. OF RHN-MAN05 (OP.)	INITIATING EVENT OCCURS IRWST MOVs FAILS TO OPEN RNS MOV V023)		8.15E-05 9.46E-05 5.00E-01 5.00E-01	IEV-RNSD IWNOR160SPX IWN-MAN00 RHN-MAN05C
55	1.93E-09	.08	LOSS OF RNS WITH RCS DRAINED COND. PROB. OF REC-MANDAS ORIFICE FAILURE DUE TO PLUGGING OPERATOR FAILS	INITIATING EVENT OCCURS (FAILURE OF MANUAL DAS ACT. TO ACTUATE ADS BEFORE CORE DAMAGE		8.15E-05 5.00E-01 9.46E-05 5.00E-01	IEV-RNSD REC-MANDASC IWNOR160SPX ADN-MAN01
56	1.93E-09	.08	LOSS OF RNS WITH RCS DRAINED COND. PROB. OF REC-MANDAS ORIFICE FAILURE DUE TO PLUGGING OPERATOR FAILS	INITIATING EVENT OCCURS (FAILURE OF MANUAL DAS ACT. TO ACTUATE ADS BEFORE CORE DAMAGE		8.15E-05 5.00E-01 9.46E-05 5.00E-01	IEV-RNSD REC-MANDASC IWNOR170SPX ADN-MAN01
57	1.93E-09	.08	LOSS OF RNS WITH RCS DRAINED ORIFICE FAILURE DUE TO PLUGGING OPERATOR FAILS COND. PROB. OF RHN-MAN05 (OP.)	INITIATING EVENT OCCURS IRWST MOVs FAILS TO OPEN RNS MOV V023)		8.15E-05 9.46E-05 5.00E-01 5.00E-01	IEV-RNSD IWNOR170SPX IWN-MAN00 RHN-MAN05C
58	1.89E-09	.08	LOSS OF RNS WITH RCS DRAINED CCF OF ACTUATION OPERATOR FAILS	INITIATING EVENT OCCURS LOGIC GROUPS TO RECOGNIZE NEED AND TO OPEN RNS MOV V023		8.15E-05 4.63E-05 5.00E-01	IEV-RNSD CCK-PMAN001X RHN-MAN05
59	1.86E-09	.08	LOSS OF CCS/SWS FAILURE OF CCF OF PRESSURE PRN-MAN01 OPERATOR FAILS	WITH RCS FILLED MANUAL DAS TRANSMITTERS TO ACTUATE ADS BEFORE CORE DAMAGE	INITIATING EVENT OCCURS REACTOR TRIP HARDWARE	3.75E-03 1.00E-02 2.01E-04 5.00E-01 5.00E-01	IEV-COMND MDAS CCK-XMTR195 PRN-MAN01 ADN-MAN01
60	1.75E-09	.07	LOSS OF RNS WITH RCS DRAINED CCF OF ACTUATION OPERATOR FAILS COND. PROB. OF RHN-MAN05 (OP.)	INITIATING EVENT OCCURS LOGIC GROUPS TO OPEN TWO IRWST MOVs FAILS TO OPEN RNS MOV V023)		8.15E-05 8.58E-05 5.00E-01 5.00E-01	IEV-RNSD CCK-PMAN002X IWN-MAN00 RHN-MAN05C

Table 54B-9

CASE 4 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS	WITH RCS DRAINED	EVENT PROB	IDENTIFIER
61	1.66E-09	.07	LOSS OF CCS/SWS CCF OF SOFTWARE OPERATOR FAILS COND. PROB. OF	WITH RCS DRAINED INITIATING EVENT OCCURS FOR INPUT LOGIC GROUPS TO OPEN TWO IRWST MOVES FAILS TO OPEN RNS MOV V023)		6.02E-04 1.10E-05 5.00E-01 5.00E-01	IEV-COWD CCX-IN-LOGIC-SW RHN-MAN00 RHN-MAN05C
62	1.66E-09	.07	LOSS OF CCS/SWS CCF OF SOFTWARE OPERATOR FAILS COND. PROB. OF	WITH RCS DRAINED INITIATING EVENT OCCURS FOR ACTUATION LOGIC GROUPS TO OPEN TWO IRWST MOVES FAILS TO OPEN RNS MOV V023)		6.02E-04 1.10E-05 5.00E-01 5.00E-01	IEV-COWD CCX-PMAN02-SW RHN-MAN00 RHN-MAN05C
63	1.58E-09	.07	LOSS OF CCS/SWS CCF OF PRESSURE	WITH RCS DRAINED INITIATING EVENT OCCURS TRANSMITTERS		6.02E-04 2.63E-06	IEV-COWD CCX-XMTRX
64	1.42E-09	.06	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE OF OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR 4KV BREAKER TO CLOSE PMS OUTPUT LOGIC I/Os TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 7.30E-04 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 ECK-CB-GC PMAMOD11 RHN-MAN05
65	1.39E-09	.06	LOSS OF RNS WITH COND. PROB. OF LEVEL OPERATOR FAILS	RCS DRAINED REC-MANDAS TRANSMITTER TO ACTUATE ADS	INITIATING EVENT OCCURS (FAILURE OF MANUAL DAS ACT. FAILURE BEFORE CORE DAMAGE	8.15E-05 5.00E-01 6.84E-05 5.00E-01	IEV-RNSD REC-MANDASC IW1TL170UFX ADN-MAN01
66	1.39E-09	.06	LOSS OF RNS WITH COND. PROB. OF LEVEL OPERATOR FAILS	RCS DRAINED REC-MANDAS TRANSMITTER TO ACTUATE ADS	INITIATING EVENT OCCURS (FAILURE OF MANUAL DAS ACT. FAILURE BEFORE CORE DAMAGE	8.15E-05 5.00E-01 6.84E-05 5.00E-01	IEV-RNSD REC-MANDASC IW2TL160UFX ADN-MAN01
67	1.39E-09	.06	LOSS OF RNS WITH LEVEL OPERATOR FAILS COND. PROB. OF	RCS DRAINED TRANSMITTER TO OPEN TWO IRWST MOVES FAILS TO OPEN RNS MOV V023)	INITIATING EVENT OCCURS FAILURE IRWST MOVES FAILS TO OPEN RNS MOV V023)	8.15E-05 6.84E-05 5.00E-01 5.00E-01	IEV-RNSD IW2TL160UFX RHN-MAN00 RHN-MAN05C
68	1.39E-09	.06	LOSS OF RNS WITH LEVEL OPERATOR FAILS COND. PROB. OF	RCS DRAINED TRANSMITTER TO OPEN TWO IRWST MOVES FAILS TO OPEN RNS MOV V023)	INITIATING EVENT OCCURS FAILURE IRWST MOVES FAILS TO OPEN RNS MOV V023)	8.15E-05 6.84E-05 5.00E-01 5.00E-01	IEV-RNSD IW1TL170UFX RHN-MAN00 RHN-MAN05C
69	1.33E-09	.05	LOSS OF RNS WITH FAILURE OF CCF OF ORIFICES OPERATOR FAILS	RCS FILLED MANUAL DAS TO RECOGNIZE THE NEED FOR RCS	INITIATING EVENT OCCURS REACTOR TRIP HARDWARE DEPRESSURIZATION	9.61E-04 1.00E-02 2.77E-04 5.00E-01	IEV-RNSND MEAS CCX-GRY-SP LPM-MAN05
70	1.30E-09	.05	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE UPON OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR 4KV BREAKERS TO OPEN DEMAND OF LOGIC GROUP PROCESSING TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 1.20E-03 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 ECK-CB-GO PMA0301ASA RHN-MAN05
71	1.30E-09	.05	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE UPON OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR 4KV BREAKERS TO OPEN DEMAND OF LOGIC GROUP PROCESSING TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 1.20E-03 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 ECK-CB-GO PMA0301BSA RHN-MAN05
72	1.22E-09	.05	LOSS OF RNS WI'H CCF OF GRAVITY OPERATOR FAILS	RCS DRAINED INJECTION CHECK TO RECOGNIZE	INITIATING EVENT OCCURS VALVES TO OPEN NEED AND TO OPEN RNS MOV V023	8.15E-05 3.00E-05 5.00E-01	IEV-RNSD INX-CV-A0 RHN-MAN05

Table 54B-9

CASE 4 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS	WITH RCS FILLED	EVENT PROB	IDENTIFIER
73	1.16E-09	.05	LOCA/RNS-V024 CCF OF ORIFICES COND. PROB. OF OPERATOR FAILS	OPENS INITIATING EVENT OCCURS REC-MANDAS (FAILURE OF TO ACTUATE ADS BEFORE CORE)	WITH RCS FILLED MANUAL DAS ACT. DAMAGE	1.68E-05 2.77E-04 5.00E-01 5.00E-01	IEV-LOCA24ND CCX-DRY-SP REC-MANDAS: ADN-MAN01
74	1.16E-09	.05	LOCA/RNS-V024 CCF OF ORIFICES COND. PROB. OF OPERATOR FAILS	OPENS INITIATING EVENT OCCURS REC-MANDAS (FAILURE OF TO RECOGNIZE THE NEED FOR RCS)	WITH RCS FILLED MANUAL DAS ACT. DEPRESSURIZATION	1.68E-05 2.77E-04 5.00E-01 5.00E-01	IEV-LOCA24ND CCX-DRY-SP REC-MANDAS: LPM-MAN05
75	1.06E-09	.04	LOSS OF OFFSITE FAILURE TO BATTERY FAILURE OF INV. OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR DB1 UNAVAILABLE STATIC SWITCH AND ASSOC. TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED MANUAL DAS ACT. BREAKERS	4.44E-03 4.20E-01 2.20E-03 5.16E-04 5.00E-01	IEV-LOSPD OTH-R1 EDIMOD03 IDAMOD05 RHN-MAN05
76	1.05E-09	.04	LOCA/RNS PIPE COND. PROB. OF CCF OF ORIFICES OPERATOR FAILS	RUPTURE WITH RCS FILLED INIT. REC-MANDAS (FAILURE OF TO RECOGNIZE THE NEED FOR RCS)	EVENT OCCURS MANUAL DAS ACT. DEPRESSURIZATION	1.51E-05 5.00E-01 2.77E-04 5.00E-01	IEV-LOCAPRND REC-MANDAS: CCX-DRY-SP LPM-MAN05
77	9.78E-10	.04	LOSS OF RNS WITH RCS DRAINED CCF OF STRAINERS IN IRWST TANK	INITIATING EVENT OCCURS		8.15E-05 1.20E-05	IEV-RNSD IMX-FL-GP
78	9.66E-10	.04	LOSS OF RNS WITH RCS FILLED FAILURE OF CCF OF PRESSURE OPERATOR FAILS	INITIATING EVENT OCCURS MANUAL DAS REACTOR TRIP TRANSMITTERS	HARDWARE	9.61E-04 1.00E-02 2.01E-04 5.00E-01	IEV-RNSND MDAS CCX-XMTR195 LPM-MAN05
79	9.62E-10	.04	LOSS OF OFFSITE FAILURE TO CCF TO START FAILURE OF INV. OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS STATIC SWITCH AND ASSOC. TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED MANUAL DAS ACT. BREAKERS	4.44E-03 4.20E-01 2.00E-03 5.16E-04 5.00E-01	IEV-LOSPD OTH-R1 Z0X-PD-ES IDAMOD05 RHN-MAN05
80	9.60E-10	.04	LOSS OF OFFSITE FAILURE TO PUMP MP 01B D/G FAILS TO FAILURE OF OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR START & RUN OR BKR 102 FAILS TO CLOSE PMS OUTPUT LOGIC I/Os TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED DIVERTED VLOW	4.44E-03 4.20E-01 2.44E-02 2.02E-02 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 SWBMOD02 Z0IMOD01 PMAMOD11 RHN-MAN05
81	8.85E-10	.04	LOSS OF CCS/SWS CCF OF THE POWER INTERFACE OUTPUT BOARDS IN PMS OPERATOR FAILS	WITH RCS DRAINED INTERFACE OUTPUT BOARDS IN PMS TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	INITIATING EVENT OCCURS	6.02E-04 2.94E-06 5.00E-01	IEV-COVID CCX-EP-SAMX RHN-MAN05
82	8.57E-10	.04	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE OF OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE STANDBY DG TO RUN PMS OUTPUT LOGIC I/Os TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 4.40E-04 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 Z0X-DG-DR PMAMOD11 RHN-M-N05
83	8.44E-10	.03	LOCA/RNS-V024 CCF OF PRESSURE COND. PROB. OF OPERATOR FAILS	OPENS INITIATING EVENT OCCURS TRANSMITTERS REC-MANDAS (FAILURE OF TO RECOGNIZE THE NEED FOR RCS)	WITH RCS FILLED MANUAL DAS ACT. DEPRESSURIZATION	1.68E-05 2.01E-04 5.00E-01 5.00E-01	IEV-LOCA24ND CCX-XMTR195 REC-MANDAS: LPM-MAN05

Table 54B-9

CASE 4 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME			EVENT PROB	IDENTIFIER
84	8.44E-10	.03	LOCA/RNS-V024 CCF OF PRESSURE COND. PROB. OF OPERATOR FAILS	OPENS INITIATING EVENT OCCURS TRANSMITTERS REC-MANDAS TO ACTUATE ADS	WITH RCS FILLED (FAILURE OF MANUAL DAS ACT. BEFORE CORE DAMAGE)	1.68E-05 2.01E-04 5.00E-01 5.00E-01	IEV-LOCA24ND CCX-XMTR195 REC-MANDASC ADM-MAN01
85	7.95E-10	.03	LOSS OF OFFSITE FAILURE TO D/G FAILS TO D/G FAILS TO FAILURE OF OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR START & RUN OR BKR 102 FAILS TO CLOSE START & RUN OR BKR 202 FAILS TO CLOSE PMS OUTPUT LOGIC I/Os TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 2.02E-02 2.02E-02 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 Z01MOD001 Z02MOD001 PMAMOD011 RHN-MAN05
86	7.90E-10	.03	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE UPON OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKER TO CLOSE DEMAND OF LOGIC GROUP PROCESSING TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 7.30E-04 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 ECX-CB-GC PMA0301BSA RHN-MAN05
87	7.90E-10	.03	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE UPON OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKER TO CLOSE DEMAND OF LOGIC GROUP PROCESSING TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 7.30E-04 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 ECX-CB-GC PMA0301ASA RHN-MAN05
88	7.59E-10	.03	LOCA/RNS PIPE COND. PROB. OF CCF OF PRESSURE OPERATOR FAILS	RUPTURE WITH RCS FILLED INIT. REC-MANDAS TRANSMITTERS TO RECOGNIZE THE NEED FOR RCS	EVENT OCCURS (FAILURE OF MANUAL DAS ACT. DEPRESSURIZATION)	1.51E-05 5.00E-01 2.01E-04 5.00E-01	IEV-LOCA24ND REC-MANDASC CCX-XMTR195 LPM-MAN05
89	7.22E-10	.03	LOSS OF CCS/SWS SOFTWARE CCF	WITH RCS DRAINED INITIATING EVENT OCCURS OF ALL CARDS		6.02E-04 1.20E-06	IEV-COND CCX-SPTW
90	6.51E-10	.03	LOSS OF OFFSITE FAILURE TO BATTERY LOSS OF DIST.	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR DBI UNAVAILABLE PANEL OR BREAKER A07 SPURIOUSLY OPENS TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 2.20E-03 3.17E-04 5.00E-01	IEV-LOSPD OTH-R1 EDIMOD003 IDAMOD004 RHN-MAN05
91	6.18E-10	.03	LOSS OF OFFSITE FAILURE TO FIXED FAILURE OF OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR COMPONENTS FAILURE PMS OUTPUT LOGIC I/Os TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 3.17E-04 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 EDIMOD0113 PMAMOD011 RHN-MAN05
92	6.18E-10	.03	LOSS OF OFFSITE FAILURE TO FIXED FAILURE OF OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR COMPONENTS FAILURE PMS OUTPUT LOGIC I/Os TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 3.17E-04 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 EDIMOD011 PMAMOD011 RHN-MAN05
93	6.16E-10	.03	LOSS OF OFFSITE FAILURE TO BATTERY BUS UNAVAILABLE OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR DBI UNAVAILABLE DUE TO TEST OR CORRECTIVE MAINTENANCE TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 2.20E-03 3.00E-04 5.00E-01	IEV-LOSPD OTH-R1 EDIMOD003 IDABSDS1TM RHN-MAN05
94	6.02E-10	.02	LOSS OF OFFSITE FAILURE TO PUMP 01B FAILS &	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR ST CK V007B & C B FTC & RE FTC & CB ECS221 SPO	WITH RCS DRAINED	4.44E-03 4.20E-01 1.53E-02	IEV-LASPD OTH-R1 RNBMOD00/S

Table 54B-9

CASE 4 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME			EVENT PROB.	IDENTIFIER
			D/G FAILS TO FAILURE OF OPERATOR FAILS	START & RUN OR PMS OUTPUT TO RECOGNIZE	BKR 102 FAILS TO CLOSE LOGIC I/Os NEED AND TO OPEN RNS MOV V023	2.02E-02 2.09E-03 5.00E-01	Z01M0001 PMAM0011 RHN-MAN05
95	5.91E-10	.02	LOSS OF OFFSITE FAILURE TO CCF TO START LOSS OF DIST. OPERATOR FAILS	POWER INITIATING RECOVER AC POWER OF ENGINE-DRIVEN FUEL PUMPS PANEL OR BREAKER TO RECOGNIZE	EVENT OCCURS IN 1 HOUR SPURIOUSLY NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 2.00E-03 3.17E-04 5.00E-01	IEV-LOSPD OTH-R1 Z0X-PD-ES IDAM0004 RHN-MAN05
96	5.85E-10	.02	LOSS OF OFFSITE FAILURE TO PUMP MP 01B BREAKER 100 FAILURE OF OPERATOR FAILS	POWER INITIATING RECOVER AC POWER SEGMENT HARDWARE FAILS TO OPEN PMS OUTPUT TO RECOGNIZE	EVENT OCCURS IN 1 HOUR DIVERTED FLOW LOGIC I/Os NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 2.44E-02 1.23E-02 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 SWBM0002 ECICB100V0 PMAM0011 RHN-MAN05
97	5.77E-10	.02	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE OF INV. OPERATOR FAILS	POWER INITIATING RECOVER AC POWER 4KV BREAKERS TO STATIC SWITCH TO RECOGNIZE	WT OCCURS IN 1 HOUR OPEN AND ASSOC. NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 1.20E-03 5.16E-04 5.00E-01	IEV-LOSPD OTH-R1 RCK-CB-G0 IDAM0005 RHN-MAN05
98	5.77E-10	.02	LOSS OF RNS WITH SOFTWARE CCF FAILURE OF	RCS FILLED OF ALL CARDS MANUAL DAS	INITIATING EVENT OCCURS ACTUATION	9.61E-04 1.20E-06 5.00E-01	IEV-RNSND CCK-SFTW REC-MANDAS
99	5.62E-10	.02	LOSS OF RNS WITH CCF OF LOGIC OPERATOR FAILS	RCS DRAINED GROUP PROCESSING TO RECOGNIZE	INITIATING EVENT OCCURS NEED AND TO OPEN RNS MOV V023	8.15E-05 1.38E-05 5.00E-01	IEV-RNSD CCK-PMAG30X RHN-MAN05
100	5.59E-10	.02	LOSS OF OFFSITE FAILURE TO CCF TO START BUS UNAVAILABLE OPERATOR FAILS	POWER INITIATING RECOVER AC POWER OF ENGINE-DRIVEN FUEL PUMPS DUE TO TEST OR CORRECTIVE TO RECOGNIZE	EVENT OCCURS IN 1 HOUR MAINTENANCE NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 2.00E-03 3.00E-04 5.00E-01	IEV-LOSPD OTH-R1 Z0X-PD-ES IDABSDSITM RHN-MAN05
101	5.46E-10	.02	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE OF OPERATOR FAILS	POWER INITIATING RECOVER AC POWER STANDBY DG TO PMS OUTPUT TO RECOGNIZE	EVENT OCCURS IN 1 HOUR START LOGIC I/Os NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 2.44E-04 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 Z0X-DG-DS PMAM0011 RHN-MAN05
102	5.33E-10	.02	LOSS OF OFFSITE FAILURE TO PUMP MP 01B D/G FAILS TO FAILURE UPON OPERATOR FAILS	POWER INITIATING RECOVER AC POWER SEGMENT HARDWARE START & RUN OR DEMAND OF LOGIC TO RECOGNIZE	EVENT OCCURS IN 1 HOUR DIVERTED FLOW BKR 102 FAILS TO CLOSE GROUP PROCESSING NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 2.44E-02 2.02E-02 1.16E-03 5.07E-01	IEV-LOSPD OTH-R1 SWBM0002 Z01M0001 PMAD301ASA RHN-MAN05
103	5.33E-10	.02	LOSS OF OFFSITE FAILURE TO PUMP MP 01B D/G FAILS TO FAILURE UPON OPERATOR FAILS	POWER INITIATING RECOVER AC POWER SEGMENT HARDWARE START & RUN OR DEMAND OF LOGIC TO RECOGNIZE	EVENT OCCURS IN 1 HOUR DIVERTED FLOW BKR 102 FAILS TO CLOSE GROUP PROCESSING NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 2.44E-02 2.02E-02 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 SWBM0002 Z01M0001 PMAD301ASA RHN-MAN05

Table 54B-9

CASE 4 LIST OF TOP 200 DOMINANT CUTSETS

LUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER
104	5.33E-10	.02	LOSS OF CCS/SWS FAILURE OF PMS OUTPUT BUS UNAVAILABLE DUE TO OPERATOR FAILS TO RECOGNIZE	WITH RCS DRAINED INITIATING EVENT OCCURS LOGIC I/Os UNSCHEDULED MAINTENANCE NEED AND TO OPEN RNS MOV V023	6.02E-04 6.53E-04 2.70E-03 5.00E-01	IEV-COMD PMAMOD11X EC1BS121TM RHN-MAN05
105	5.31E-10	.02	LOSS OF CCS/SWS FAILURE OF PMS OUTPUT UNAVAILABILITY OF BUS ECS ES 1 OPERATOR FAILS TO RECOGNIZE	WITH RCS DRAINED INITIATING EVENT OCCURS LOGIC I/Os DUE TO UNSCHEDUL MAINTENANCE NEED AND TO OPEN RNS MOV V023	6.02E-04 6.53E-04 2.70E-03 5.00E-01	IEV-COMD PMAMOD11X EC1BS001TM RHN-MAN05
106	5.31E-10	.02	LOSS OF CCS/SWS FAILURE OF PMS OUTPUT BUS UNAVAILABLE DUE TO OPERATOR FAILS TO RECOGNIZE	WITH RCS DRAINED INITIATING EVENT OCCURS LOGIC I/Os UNSCHEDULED MAINTENANCE NEED AND TO OPEN RNS MOV V023	6.02E-04 6.53E-04 2.70E-03 5.00E-01	IEV-COMD PMAMOD11X EC1BS012TM RHN-MAN05
107	5.28E-10	.02	LOSS OF RNS: WITH CCS OF INPUT OPERATOR FAILS TO OPEN TWO COND. PROB. OF RHN-MAN05 (CP)	WITH RCS DRAINED LOGIC GROUPS TO OPEN TWO IRWST MOVs FAILS TO OPEN RNS MOV V023	8.15E-05 2.59E-05 5.00E-01 5.00E-01	IEV-RNSD CCX-INPUT-LOGICK TWN-MAN05 RHN-MAN05C
108	5.23E-10	.02	LOCA/RNS PIPE OPERATOR FAILS TO ISOLATE CCF OF ORIFICES COND. PROB. OF OPERATOR FAILS	RUPTURE WITH RCS FILLED INIT RNS PIPE RUPTURE REC-MANDAS (FAILURE OF TO ACTUATE ADS BEFORE CORE	1.51E-05 5.00E-01 2.77E-04 5.00E-01 5.00E-01	IEV-LOCAPRND RHN-MAN04 CCX-ORY-SP REC-MANDASC ADN-MAN01
109	5.04E-10	.02	LOCA/RNS-V024 CCF OF GRAVITY	OPENS INITIATING EVENT OCCURS INJECTION CHECK VALVES TO OPEN	1.68E-05 3.00E-05	IEV-LOCA24ND TWN-CV-A0
110	4.95E-10	.02	LOSS OF RNS WITH RCS FILLED FAILURE OF MANUAL DAS COMMON MODE OPERATOR FAILS TO RECOGNIZE THE NEED FOR RCS	INITIATING EVENT OCCURS REACTOR TRIP LOGIC GROUPS DEPRESSURIZATION	9.61E-04 1.03E-02 1.03E-04 5.00E-01	IEV-RNSND MDAS CCX-INPUT-LOGIC LPM-MAN05
111	4.84E-10	.02	LOSS OF OFFSITE FAILURE TO D/G FAILS TO BREAKER 200 FAILURE OF OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR START & RUN OR BKR 102 FAILS TO CLOSE FAILS TO OPEN PMS OUTPUT LOGIC I/Os TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 2.02E-02 1.23E-02 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 Z01MOD01 EC2CB200VO PMAMOD11 RHN-MAN05
112	4.84E-10	.02	LOSS OF OFFSITE FAILURE TO BREAKER 100 D/G FAILS TO FAILURE OF OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILS TO OPEN START & RUN OR BKR 202 FAILS TO CLOSE PMS OUTPUT LOGIC I/Os TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 1.23E-02 2.02E-02 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 EC1CB100VO Z02MOD01 PMAMOD11 RHN-MAN05
113	4.76E-10	.02	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE UPON OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE STANDBY DG TO RUN DEMAND OF LOGIC GROUP PROCESSING TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 4.40E-04 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 Z0X-DG-DR PMAMOD10BSA RHN-MAN05
114	4.76E-10	.02	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE UPON OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE STANDBY DG TO RUN DEMAND OF LOGIC GROUP PROCESSING TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 4.40E-04 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 Z0X-DG-DR PMAMOD10ASA RHN-MAN05

Table 54B-9

CASE 4 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT	EVENT PROB	IDENTIFIER
115	4.71E-10	.02	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS PMAMOD21X OPERATOR FAILS TO OPEN TWO IRWST MOVES UNAVAILABILITY OF BUS ECS ES 1 DUE TO UNSCHEDUL MAINTENANCE COND. PROB. OF RHN-MAN05 (OP. FAILS TO OPEN RNS MOV V023)		6.02E-04 1.16E-03 5.00E-01 2.70E-03 5.00E-01	IEV-COWD PMAMOD21X IWN-MAN00 BC1BS001TM RHN-MAN05C
116	4.71E-10	.02	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS PMAMOD21X OPERATOR FAILS TO OPEN TWO IRWST MOVES BUS UNAVAILABLE DUE TO UNSCHEDULED MAINTENANCE COND. PROB. OF RHN-MAN05 (OP. FAILS TO OPEN RNS MOV VP-1)		6.02E-04 1.16E-03 5.00E-01 2.70E-03 5.00E-01	IEV-COWD PMAMOD21X IWN-MAN00 BC1BS121TM RHN-MAN05C
117	4.71E-10	.02	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS PMAMOD21X OPERATOR FAILS TO OPEN TWO IRWST MOVES BUS UNAVAILABLE DUE TO UNSCHEDULED MAINTENANCE COND. PROB. OF RHN-MAN05 (OP. FAILS TO OPEN RNS MOV V023)		6.02E-04 1.16E-03 5.00E-01 2.70E-03 5.00E-01	IEV-COWD PMAMOD21X IWN-MAN00 BC1BS012TM RHN-MAN05C
118	4.48E-10	.02	LOSS OF RNS WITH RCS DRAINED SOFTWARE CCF OF OUTPUT LOGIC OPERATOR FAILS TO RECOGNIZE	INITIATING EVENT OCCURS I/Os NEED AND TO OPEN RNS MOV V023	9.15E-05 1.10E-05 5.00E-01	IEV-RNSD CCX-PMAMOD1-SW RHN-MAN05
119	4.41E-10	.02	LOSS OF OFFSITE FAILURE TO D/G FAILS TO START & RUN OR D/G FAILS TO START & RUN OR FAILURE UPON DEMAND OF LOGIC OPERATOR FAILS TO RECOGNIZE	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR BKR 102 FAILS TO CLOSE BKR 202 FAILS TO CLOSE GROUP PROCESSING NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 2.02E-02 2.02E-02 1.16E-03 5.00E-01	IEV-LOSPD OTB-R1 Z01MOD01 Z02MOD01 PMA0301ASA RHN-MAN05
120	4.41E-10	.02	LOSS OF OFFSITE FAILURE TO D/G FAILS TO START & RUN OR D/G FAILS TO START & RUN OR FAILURE UPON DEMAND OF LOGIC OPERATOR FAILS TO RECOGNIZE	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR BKR 102 FAILS TO CLOSE BKR 202 FAILS TO CLOSE GROUP PROCESSING NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 2.02E-02 2.02E-02 1.16E-03 5.00E-01	IEV-LOSPD OTB-R1 Z01MOD01 Z02MOD01 PMA0301ASA RHN-MAN05
121	4.33E-10	.02	LOSS OF CCS/SWS MECHANICAL IRWST DISCHARGE	WITH RCS DRAINED INITIATING EVENT OCCURS FAILURE CAUSES MOV 121A TO FAIL-TO-OPEN LINE "B" STRAINER PLUGGED	6.02E-04 3.00E-03 2.40E-04	IEV-COWD IRWMOD05S IWB-PLUG
122	4.33E-10	.02	LOCA/RNS-V024 COND. PROB. OF COMMON MODE OPERATOR FAILS	OPENS INITIATING EVENT OCCURS REC-MANDAS (FAILURE OF FAILURE OF INPUT LOGIC GROUPS TO ACTUATE ADS BEFORE CORE DAMAGE	1.68E-05 5.00E-01 1.03E-04 5.00E-01	IEV-LOCA24ND REC-MAN05C CCX-INPUT-LOGIC ADN-MAN01
123	4.33E-10	.02	LOCA/RNS-V024 COND. PROB. OF COMMON MODE OPERATOR FAILS	OPENS INITIATING EVENT OCCURS REC-MANDAS (FAILURE OF FAILURE OF INPUT LOGIC GROUPS TO RECOGNIZE THE NEED FOR RCS DEPRESSURIZATION	1.68E-05 5.00E-01 1.03E-04 5.00E-01	IEV-LOCA24ND REC-MAN05C CCX-INPUT-LOGIC LPM-MAN05
124	4.19E-10	.02	LOSS OF CCS/SWS FAILURE OF INV. UNAVAILABILITY OPERATOR FAILS	WITH RCS DRAINED INITIATING EVENT OCCURS STATIC SWITCH AND ASSOC. OF BUS ECS ES 1 DUE TO UNSCHEDUL MAINTENANCE TO RECOGNIZE NEED AND TO OPEN RNS MOV V027	6.02E-04 5.16E-04 2.70E-03 5.00E-01	IEV-COWD ISAM0005 BC1BS001TM RHN-MAN05
125	4.19E-10	.02	LOSS OF CCS/SWS FAILURE OF INV. BUS UNAVAILABLE OPERATOR FAILS	WITH RCS DRAINED INITIATING EVENT OCCURS STATIC SWITCH AND ASSOC. DUE TO UNSCHEDULED MAINTENANCE TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	6.02E-04 5.16E-04 2.70E-03 5.00E-01	IEV-COWD IDAM0005 BC1BS017TM RHN-MAN05

92

Table 54B-9

CASE 4 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER
126	4.19E-10	.02	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS FAILURE OF INV. STATIC SWITCH AND ASSOC. BUS UNAVAILABLE DUE TO UNSCHEDULED MAINTENANCE OPERATOR FAILS TO RECOGNIZE NEED AND TO OPEN RNS MOV V023		6.02E-04 5.16E-04 2.70E-03 5.00E-01	IEV-COHO IDAM0005 ECIBS121TM RHN-MAN05
127	4.09E-10	.02	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED FAILURE TO RECOVER AC POWER IN 1 HOUR PUMP SUBLOOP 8 HARDWARE FAILURE OR DIVERTED FLOW D/G FAILS TO START & RUN OR BKR 102 FAILS TO CLOSE FAILURE OF PMS OUTPUT LOGIC I/Os OPERATOR FAILS TO RECOGNIZE NEED AND TO OPEN RNS MOV V023		4.44E-03 4.20E-01 1.04E-02 2.02E-02 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 CCR00001S Z01MOD01 PMAM0011 RHN-MAN05
128	3.89E-10	.02	LOCA/RNS PIPE RUPTURE WITH RCS FILLED INIT. EVENT OCCURS COND. PROB. OF REC-MANDAS (FAILURE OF COMMON MODE FAILURE OF INPUT LOGIC GROUPS OPERATOR FAILS TO RECOGNIZE THE NEED FOR RCS DEPRESSURIZATION		1.51E-05 5.00E-01 1.03E-04 5.00E-01	IEV-LOCAPPND REC-MANDAS CCK-INPUT-LOGIC LPM-MAN05
129	3.67E-10	.02	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED FAILURE TO RECOVER AC POWER IN 1 HOUR PUMP C1B FAILS & ST CK V007B & C B PTC & RE PTC & CB ECS221 SPO BREAKER 100 FAILS TO OPEN [#3,5] FAILURE OF PMS OUTPUT LOGIC I/Os OPERATOR FAILS TO RECOGNIZE NEED AND TO OPEN RNS MOV V023		4.44E-03 4.20E-01 1.53E-02 1.23E-02 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 RNB00007S ECICB100V0 PMAM0011 RHN-MAN05
130	3.55E-10	.01	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED FAILURE TO RECOVER AC POWER IN 1 HOUR COMMON CAUSE FAILURE 4KV BREAKERS TO OPEN LOSS OF DIST. PANEL OR BREAKER A07 SPURIOUSLY OPENS OPERATOR FAILS TO RECOGNIZE NEED AND TO OPEN RNS MOV V023		4.44E-03 4.20E-01 1.20E-03 3.17E-04 5.00E-01	IEV-LOSPD OTH-R1 ECX-CB-G0 IDAM0004 RHN-MAN05
131	3.51E-10	.01	LOSS OF RNS WITH RCS DRAINED INITIATING EVENT OCCURS FAILURE OF MANUAL DAS ACTUATION CCF OF THE POWER INTERFACE OUTPUT BOARDS IN PMS		8.15E-05 5.00E-01 8.62E-06	IEV-RNSD REC-MANDAS CCK-EP-SAM
132	3.51E-10	.01	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED FAILURE TO RECOVER AC POWER IN 1 HOUR COMMON CAUSE FAILURE 4KV BREAKER TO CLOSE FAILURE OF INV. STATIC SWITCH AND ASSOC. OPERATOR FAILS TO RECOGNIZE NEED AND TO OPEN RNS MOV V023		4.44E-03 4.20E-01 7.30E-04 5.16E-04 5.00E-01	IEV-LOSPD OTH-R1 ECX-CB-GC IDAM0005 RHN-MAN05
133	3.43E-10	.01	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED FAILURE TO RECOVER AC POWER IN 1 HOUR FIXED COMPONENTS FAILURE FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING OPERATOR FAILS TO RECOGNIZE NEED AND TO OPEN RNS MOV V023		4.44E-03 4.20E-01 3.77E-04 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 EDIMOD013 PMAM0301BSA RHN-MAN05
134	3.43E-10	.01	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED FAILURE TO RECOVER AC POWER IN 1 HOUR FIXED COMPONENTS FAILURE FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING OPERATOR FAILS TO RECOGNIZE NEED AND TO OPEN RNS MOV V023		4.44E-03 4.20E-01 3.17E-04 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 EDIMOD011 PMAM0301ASA RHN-MAN05
135	3.43E-10	.01	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED FAILURE TO RECOVER AC POWER IN 1 HOUR FIXED COMPONENTS FAILURE FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING OPERATOR FAILS TO RECOGNIZE NEED AND TO OPEN RNS MOV V023		4.44E-03 4.20E-01 3.17E-04 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 EDIMOD013 PMAM0301ASA RHN-MAN05

Table 54B-9

CASE 4 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS	WITH RCS DRAINED	EVENT PROB.	IDENTIFIER
136	3.43E-10	.01	LOSS OF OFFSITE FAILURE TO FIXED FAILURE UPON OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR COMPONENTS FAILURE DEMAND OF LOGIC GROUP PROCESSING TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 3.17E-04 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 EDIMOD11 PMA0301BSA RHN-MAN05
137	3.39E-10	.01	LOCA/RNS-V024 DUE TO CCF OF	OPENS INITIATING EVENT OCCURS THE SQUIB VALVES TO OPERATE	WITH RCS DRAINED	1.13E-05 3.00E-05	IEV-LOCA24D ADX-EV-SA
138	3.36E-10	.01	LOSS OF OFFSITE FAILURE TO COMMON CAUSE BUS UNAVAILABLE OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKERS TO OPEN DUE TO TEST OR CORRECTIVE MAINTENANCE TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 1.20E-03 3.00E-04 5.00E-01	IEV-LOSPD OTH-R1 ZCX-CB-G0 IDABSDS1TM RHN-MAN05
139	3.34E-10	.01	LOSS OF OFFSITE FAILURE TO PUMP 01B FAILS & D/G FAILS TO FAILURE UPON OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR ST CK V007B & C B PTC & RE PTC & CB ECS21 SPO START & RUN OR BKR 102 FAILS TO CLOSE DEMAND OF LOGIC GROUP PROCESSING TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 1.53E-02 2.02E-02 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 RNBMOD07S Z01M0001 PMA0301ASA RHN-MAN05
140	3.34E-10	.01	LOSS OF OFFSITE FAILURE TO PUMP 01B FAILS & D/G FAILS TO FAILURE UPON OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR ST CK V007B & C B PTC & RE PTC & CB ECS21 SPO START & RUN OR BKR 102 FAILS TO CLOSE DEMAND OF LOGIC GROUP PROCESSING TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 1.53E-02 2.02E-02 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 RNBMOD07S Z01M0001 PMA0301BSA RHN-MAN05
141	3.33E-10	.01	OVERDRAIN % OF OPERATOR FAILS IWN-MAN00C BUS UNAVAILABLE	RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT TO ISOLATE RNS PIPE RUPTURE	WITH RCS DRAINED	4.44E-06 5.00E-01 5.00E-01 3.00E-04	IEV-RCS0D RHN-MAN04 IWN-MAN00C IDOBSDS1TM
142	3.33E-10	.01	OVERDRAINING OF OPERATOR FAILS IWN-MAN00C BUS UNAVAILABLE	RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT TO ISOLATE RNS PIPE RUPTURE	WITH RCS DRAINED	4.44E-06 5.00E-01 5.00E-01 3.00E-04	IEV-RCS0D RHN-MAN04 IWN-MAN00C IDOBSDK1TM
143	3.33E-10	.01	OVERDRAINING OF RHN-MAN04-SUCC OPERATOR FAILS BUS UNAVAILABLE	RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT TO OPEN TWO IRWST MOVs	WITH RCS DRAINED	4.44E-06 5.00E-01 5.00E-01 3.00E-04	IEV-RCS0D RHN-MAN04-SUCC IWN-MAN00 IDOBSDD1TM
144	3.33E-10	.01	OVERDRAINING OF OPERATOR FAILS IWN-MAN00C BUS UNAVAILABLE	RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT TO ISOLATE RNS PIPE RUPTURE	WITH RCS DRAINED	4.44E-06 5.00E-01 5.00E-01 3.00E-04	IEV-RCS0D RHN-MAN04 IWN-MAN00C IDOBSDUD1TM
145	3.33E-10	.01	OVERDRAINING OF RHN-MAN04-SUCC OPERATOR FAILS BUS UNAVAILABLE	RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT TO OPEN TWO IRWST MOVs	WITH RCS DRAINED	4.44E-06 5.00E-01 5.00E-01 3.00E-04	IEV-RCS0D RHN-MAN04-SUCC IWN-MAN00 IDOBSDS1TM
146	3.33E-10	.01	OVERDRAINING OF RHN-MAN04-SUCC OPERATOR FAILS BUS UNAVAILABLE	RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT TO OPEN TWO IRWST MOVs	WITH RCS DRAINED	4.44E-06 5.00E-01 5.00E-01 3.00E-04	IEV-RCS0D RHN-MAN04-SUCC IWN-MAN00 IDOBSDK1TM

Table 54B-9

CASE 4 LIST OF TOP 200 DOMINANT CUTSE.T'S

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS	WITH RCS DRAINED	EVENT PROB	IDENTIFIER
147	3.25E-10	.01	LOSS OF OFFSITE FAILURE TO PUMP MP 01B BREAKER 100 FAILURE UPON OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR FAILS TO OPEN DEMAND OF LOGIC GROUP PROCESSING TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED DIVERTED FLOW [#3.5] DIVERTEI FLOW [#3.5] NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 2.44E-02 1.23E-02 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 SWBMOD02 RC1CB100VO PMA0301ASA RHN-MAN05
148	3.25E-10	.01	LOSS OF OFFSITE FAILURE TO PUMP MP 01B BREAKER 100 FAILURE UPON OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR FAILS TO OPEN DEMAND OF LOGIC GROUP PROCESSING TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED DIVERTED FLOW [#3.5] DIVERTEI FLOW [#3.5] NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 2.44E-02 1.23E-02 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 SWBMOD02 RC1CB100VO PMA0301BSA RHN-MAN05
149	3.23E-10	.01	LOSS OF CCS/SWS FAILURE OF CCF OF THE POWER	WITH RCS FILLED MANUAL DAS INTERFACE OUTPUT	INITIATING EVENT OCCURS REACTOR TRIP HARDWARE BOARDS IN PMS	3.75E-03 1.00E-02 8.62E-06	IEV-COMND MDAS CCX-EP-SAM
150	3.10E-10	.01	LOSS OF CCS/SWS FAILURE OF COMMON MODE OPERATOR FAILS	WITH RCS DRAINED MANUAL DAS FAILURE OF INPUT TO ACTUATE ADS	INITIATING EVENT OCCURS REACTOR TRIP HARDWARE LOGIC GROUPS BEFORE CORE	6.02E-04 1.00E-02 1.03E-04 5.00E-01	IEV-COMND MDAS CCX-INPUT-LOGIC ADN-MAN01
151	3.03E-10	.01	LOCA/RNS-V024 DAS COND. PROB. OF RC10R195SP	OPENS INITIATING EVENT OCCURS REC-MANDAS (FAILURE OF TO RECOGNIZE THE NEED FOR RCS	WITH RCS FILLED MANUAL DAS ACT. DEPRESSURIZATION	1.68E-05 1.00E-02 5.00E-01 7.22E-03 5.00E-01	IEV-LOCA24ND DAS REC-MANDASC RC10R195SP LPM-MAN05
152	3.03E-10	.01	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE UPON OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE STANDBY DG TO START DEMAND OF LOGIC GROUP PROCESSING TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED [#3.5] STANDBY DG TO START DEMAND OF LOGIC GROUP PROCESSING NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 2.40E-04 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 Z0X-DG-DS PMA0301ASA RHN-MAN05
153	3.03E-10	.01	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE UPON OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE STANDBY DG TO START DEMAND OF LOGIC GROUP PROCESSING TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED [#3.5] STANDBY DG TO START DEMAND OF LOGIC GROUP PROCESSING NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 2.40E-04 1.17E-03 5.00E-01	IEV-LOSPD OTH-R1 Z0X-DG-DS PMA0301BSA RHN-MAN05
154	2.96E-10	.01	LOSS OF RNS WITH CCF OF ORIFICES	INITIATING EVENT OCCURS	-	8.15E-05 3.63E-06	IEV-RNSD CCX-GRY-SPX
155	2.95E-10	.01	LOSS OF OFFSITE FAILURE TO BREAKER 100 BREAKER 200 FAILURE OF OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILS TO OPEN FAILS TO OPEN PMS OUTPUT TO RECOGNIZE	WITH RCS DRAINED [#3.5] [#5.3] LOGIC I/Os NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 1.23E-02 1.23E-02 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 RC1CB100VO RC2CB200VO PNA MOD11 RHN-MAN05
156	2.94E-10	.01	LOCA/RNS-V024 CCF OF IRWST INJ	OPENS INITIATING EVENT OCCURS MOV's 121A, 121B, & RNS V023	WITH RCS DRAINED	1.13E-05 2.60E-05	IEV-LOCA24D EWX-MV-G01
157	2.91E-10	.01	LOCA/RNS-V024 COND. PROB. OF COMMON MODE OPERATOR FAILS	OPENS INITIATING EVENT OCCURS REC-MANDAS (FAILURE OF TO ACTUATE ADS	WITH RCS DRAINED MANUAL DAS ACT. DAMAGE	1.13E-05 5.00E-01 1.03E-04 5.00E-01	IEV-LOCA24D REC-MANDASC CCX-INPUT-LOGIC ADN-MAN01

Table 54B-9

CASE 4 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS	WITH RCS DRAINED	IDENTIFIER
158	2.89E-10	.01	LOSS OF OFFSITE POWER	POWER INITIATING EVENT OCCURS	WITH RCS DRAINED	IEV-LOSPD
			FAILURE TO RECOVER AC POWER IN 1 HOUR			4.44E-03
			DBI UNAVAILABLE			4.20E-01
			BATTERY			2.20E-03
			CCP OF OUTPUT			1.41E-04
			OPERATOR FAILS	NEED AND TO OPEN RNS MOV V023		CC2-PRAM001
			TO RECOGNIZE			5.00E-01
						RBN-MAN05
159	2.89E-10	.01	LOSS OF CCS/SMS	WITH RCS DRAINED INITIATING EVENT OCCURS	WITH RCS DRAINED	IEV-CCWD
			MANUAL DAS	REACTOR TRIP HARDWARE		IEV-CCWD
			ORIFICE FAILURE	DUE TO PLUGGING		IEV-CCWD
			OPERATOR FAILS	TO ACTUATE AIDS		IEV-CCWD
			TO RECOGNIZE	REPAIR CORE		IEV-CCWD
				DAMAGE		IEV-CCWD
160	2.89E-10	.01	LOSS OF CCS/SMS	WITH RCS DRAINED INITIATING EVENT OCCURS	WITH RCS DRAINED	IEV-CCWD
			MANUAL DAS	REACTOR TRIP HARDWARE		IEV-CCWD
			ORIFICE FAILURE	DUE TO PLUGGING		IEV-CCWD
			OPERATOR FAILS	TO ACTUATE AIDS		IEV-CCWD
			TO RECOGNIZE	BEFORE CORE DAMAGE		IEV-CCWD
161	2.75E-10	.02	LOSS OF OFFSITE POWER	POWER INITIATING EVENT OCCURS	WITH RCS DRAINED	IEV-LOSPD
			RECOVER AC POWER IN 1 HOUR			6.02E-04
			PLS OUTPUT	LOGIC 1/0		IEV-LOSPD
			CCP OF OUTPUT	NEED AND TO OPEN RNS MOV V023		IEV-LOSPD
			OPERATOR FAILS	TO RECOGNIZE		IEV-LOSPD
162	2.71E-10	.01	LOSS OF CCS/SMS	WITH RCS DRAINED INITIATING EVENT OCCURS	WITH RCS DRAINED	IEV-CCWD
			MECHANICAL FAILURE	MOV 121A TO FALL-TO-OPEN		IEV-CCWD
			BUS UNAVAILABLE	DOE TO TEST OR CORRECTIVE MAINTENANCE		IEV-CCWD
			OPERATOR FAILS	TO RECOGNIZE NEED AND TO OPEN RNS MOV V023		IEV-CCWD
163	2.71E-10	.01	LOSS OF CCS/SMS	WITH RCS DRAINED INITIATING EVENT OCCURS	WITH RCS DRAINED	IEV-CCWD
			MECHANICAL FAILURE	MOV 121A TO FALL-TO-OPEN		IEV-CCWD
			BUS UNAVAILABLE	DOE TO TEST OR CORRECTIVE MAINTENANCE		IEV-CCWD
			OPERATOR FAILS	TO RECOGNIZE NEED AND TO OPEN RNS MOV V023		IEV-CCWD
164	2.71E-10	.01	LOSS OF CCS/SMS	WITH RCS DRAINED INITIATING EVENT OCCURS	WITH RCS DRAINED	IEV-CCWD
			MECHANICAL FAILURE	MOV 121A TO FALL-TO-OPEN		IEV-CCWD
			BUS UNAVAILABLE	DOE TO TEST OR CORRECTIVE MAINTENANCE		IEV-CCWD
			OPERATOR FAILS	TO RECOGNIZE NEED AND TO OPEN RNS MOV V023		IEV-CCWD
165	2.69E-10	.01	LOSS OF OFFSITE POWER	POWER INITIATING EVENT OCCURS	WITH RCS DRAINED	IEV-LOSPD
			FAILURE TO RECOVER AC POWER IN 1 HOUR			4.44E-03
			DIG FAILS TO BREAKER 100	FAILS TO OPEN		4.20E-01
			BREAKER 200	START & RUN OR		4.20E-01
			DIG FAILS TO FAILURE UPON	DEMAND OF LOGIC GROUP PROCESSING		4.20E-01
			OPERATOR FAILS	TO RECOGNIZE NEED AND TO OPEN RNS MOV V023		4.20E-01
166	2.69E-10	.01	LOSS OF OFFSITE POWER	POWER INITIATING EVENT OCCURS	WITH RCS DRAINED	IEV-LOSPD
			FAILURE TO RECOVER AC POWER IN 1 HOUR			4.44E-03
			BREAKER 100	FAILS TO OPEN		4.20E-01
			DIG FAILS TO FAILURE UPON	START & RUN OR		4.20E-01
			OPERATOR FAILS	DEMAND OF LOGIC GROUP PROCESSING		4.20E-01
167	2.69E-10	.01	LOSS OF OFFSITE POWER	POWER INITIATING EVENT OCCURS	WITH RCS DRAINED	IEV-LOSPD
			FAILURE TO RECOVER AC POWER IN 1 HOUR			4.44E-03
			BREAKER 100	FAILS TO OPEN		4.20E-01
			DIG FAILS TO FAILURE UPON	START & RUN OR		4.20E-01
			OPERATOR FAILS	DEMAND OF LOGIC GROUP PROCESSING		4.20E-01

Table 54B-9

CASE 4 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME			EVENT PROB	IDENTIFIER
168	2.69E-10	.01	LOSS OF OFFSITE FAILURE TO D/G FAILS TO BREAKER 200 FAILURE UPON OPERATOR FAILS	POWER INITIATI RECOVER AC POWER IN 1 HOUR START & RUN OR FAILS TO CLOSE DEMAND OF LOGIC TO RECOGNIZE	EVENT OCCURS #5.3 GROUP PROCESSING NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 2.02E-02 1.23E-02 1.16E-03 5.00E-01
169	2.67E-10	.01	LOCA/RNS-V024 ORIFICE FAILURE OPERATOR FAILS COND. PROB. OF RHN-MAN05 (OP.)	OPENS INITIATING DUE TO PLUGGING TO OPEN TWO IRWST MOVs	EVENT OCCURS FAILS TO OPEN	WITH RCS DRAINED	1.13E-05 9.46E-05 5.00E-01 5.00E-01
170	2.67E-10	.01	LOCA/RNS-V024 ORIFICE FAILURE OPERATOR FAILS COND. PROB. OF RHN-MAN05 (OP.)	OPENS INITIATING DUE TO PLUGGING TO OPEN TWO IRWST MOVs	EVENT OCCURS FAILS TO OPEN	WITH RCS DRAINED	1.13E-05 9.46E-05 5.00E-01 5.00E-01
171	2.67E-10	.01	LOCA/RNS-V024 COND. PROB. OF ORIFICE FAILURE OPERATOR FAILS	OPENS INITIATING REC-MANDAS (FAILURE OF DUE TO PLUGGING TO ACTUATE ADS	EVENT OCCURS MANUAL DAS ACT.	WITH RCS DRAINED	1.13E-05 5.00E-01 9.46E-05 5.00E-01
172	2.67E-10	.01	LOCA/RNS-V024 COND. PROB. OF ORIFICE FAILURE OPERATOR FAILS	OPENS INITIATING REC-MANDAS (FAILURE OF DUE TO PLUGGING TO ACTUATE ADS	EVENT OCCURS MANUAL DAS ACT.	WITH RCS DRAINED	1.13E-05 5.00E-01 9.46E-05 5.00E-01
173	2.66E-10	.01	OVERDRAINING OF RHN-MAN04-SUCC OPERATOR FAILS IRWST DISCHARGE	RCS DURING DRAIN DOWN TO MID-LOOP TO OPEN TWO LINE "B"	INITIATING EVENT IRWST MOVs STRAINER	4.44E-06 5.00E-01 5.00E-01	IEV-FC030D RHN-MAN04-SUCC IWN-MAN00
174	2.66E-10	.01	OVERDRAINING OF OPERATOR FAILS IWN-MAN04C IRWST DISCHARGE	RCS DURING DRAIN DOWN TO MID-LOOP TO ISOLATE LINE "B"	INITIATING EVENT RNS PIPE RUPTURE STRAINER	4.44E-06 5.00E-01 5.00E-01 2.40E-04	IEV-RC030D RHN-MAN04 IWN-MAN00C IWB-PLUG
175	2.63E-10	.01	LOSS OF OFFSITE FAILURE TO CCF TO START CCF OF OUTPUT OPERATOR FAILS	POWER INITIATING RECOVER AC POWER IN 1 HOUR OF ENGINE DRIVEN FUEL PUMPS LOGIC I/O BOARDS	EVENT OCCURS	WITH RCS DRAINED	4.44E-03 4.20E-01 2.00E-03 1.41E-04 5.00E-01
176	2.62E-10	.01	LOCA/RNS-V024 CCF OF ACTUATION OPERATOR FAILS	OPENS INITIATING LOGIC GROUPS TO RECOGNIZE	EVENT OCCURS NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	1.13E-05 4.63E-05 5.00E-01
177	2.18E-10	.01	LOSS OF CCS/SWS LOSS OF DIST. BUS UNAVAILABLE OPERATOR FAILS	WITH RCS DRAINED PANEL OR BREAKER A07 SPURIOUSLY DUE TO TO RECOGNIZE	INITIATING EVENT OCCURS OPENS UNSCHEDULED MAINTENANCE NEED AND TO OPEN RNS MOV V023	6.02E-04 3.17E-04 2.70E-03 5.00E-01	IEV-CCWD IDAM0004 BC1BS012TM RHN-MAN05
178	2.58E-10	.01	LOSS OF CCS/SWS LOSS OF DIST. UNAVAILABILITY OPERATOR FAILS	WITH RCS DRAINED PANEL OR BREAKER A07 SPURIOUSLY OF BUS ECS ES 1 DUE TO UNSCHEDUL TO RECOGNIZE	INITIATING EVENT OCCURS OPENS MAINTENANCE NEED AND TO OPEN RNS MOV V023	6.02E-04 3.17E-04 2.70E-03 5.00E-01	IEV-CCWD IDAM0004 BC1BS001TM RHN-MAN05

Table 54B-9

CASE 4 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME			EVENT PROB	IDENTIFIER
179	2.58E-10	.01	LOSS OF CCS/SWS LOSS OF DIST. BUS UNAVAILABLE OPERATOR FAILS	WITH RCS DRAINED INITIATING EVENT OCCURS PANEL OR BREAKER A07 SPURIOUSLY OPENS DUE TO UNSCHEDULED MAINTENANCE TO RECOGNIZE NEED AND TO OPEN RNS MOV V023		6.02E-04 3.17E-04 2.70E-03 5.00E-01	IEV-COMD IDAMOD04 EC1BS121TM RHN-MAN05
180	2.56E-10	.01	LOCA/RNS-V024 COMMON CAUSE COND. PROB. OF OPERATOR FAILS	OPENS INITIATING EVENT OCCURS FAILURE OF 4 AOVs TO OPEN REC-MANDAS (FAILURE OF TO ACTUATE ADS BEFORE CORE	WITH RCS FILLED MANUAL DAS ACT. DAMAGE	1.68E-05 6.10E-05 5.00E-01 5.00E-01	IEV-LOCA24ND CCX-AV-LA REC-MANDASC ADN-MAN01
181	2.56E-10	.01	LOCA/RNS-V024 COMMON CAUSE COND. PROB. OF OPERATOR FAILS	OPENS INITIATING EVENT OCCURS FAILURE OF 4 AOVs TO OPEN REC-MANDAS (FAILURE OF TO RECOGNIZE THE NEED FOR RCS	WITH RCS FILLED MANUAL DAS ACT. DEPRESSURIZATION	1.68E-7 6.10E-01 5.00E-01 5.00E-01	IEV-LOCA24ND CCX-AV-LA REC-MANDASC LPM-MAN05
182	2.53E-10	.01	LOSS OF OFFSITE FAILURE TO CCF TO RUN OF FAILURE OF OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR ENGINE-DRIVEN FUEL PUMPS PMS OUTPUT LOGIC I/Os TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 1.30E-04 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 Z0X-PD-BR PMAMOD11 RHN-MAN05
183	2.49E-10	.01	LOSS OF OFFSITE FAILURE TO PUMP SUBLOOP B BREAKER 100 FAILURE OF OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR HARDWARE FAILURE OR DIVERTED FLOW FAILS TO OPEN [83.5] PMS OUTPUT LOGIC I/Os TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED [83.5] LOGIC I/Os NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 1.04E-02 1.23E-02 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 CCBMOD01S EC1CB100V0 PMAMOD11 RHN-MAN05
184	2.44E-10	.01	LOSS OF CCS/SWS BUS UNAVAILABLE BUS UNAVAILABLE OPERATOR FAILS	WITH RCS DRAINED INITIATING EVENT OCCURS DUE TO TEST OR CORRECTIVE MAINTENANCE DUE TO UNSCHEDULED MAINTENANCE TO RECOGNIZE NEED AND TO OPEN RNS MOV V023		6.02E-04 3.00E-04 2.70E-03 5.00E-01	IEV-COMD IDABSDS1TM EC1BS012TM RHN-MAN05
185	2.44E-10	.01	LOSS OF CCS/SWS BUS UNAVAILABLE BUS UNAVAILABLE OPERATOR FAILS	WITH RCS DRAINED INITIATING EVENT OCCURS DUE TO TEST OR CORRECTIVE MAINTENANCE DUE TO UNSCHEDULED MAINTENANCE TO RECOGNIZE NEED AND TO OPEN RNS MOV V023		6.02E-04 3.00E-04 2.70E-03 5.00E-01	IEV-COMD IDABSDS1TM EC1BS121TM RHN-MAN05
186	2.44E-10	.01	LOSS OF CCS/SWS BUS UNAVAILABLE UNAVAILABILITY OPERATOR FAILS	WITH RCS DRAINED INITIATING EVENT OCCURS DUE TO TEST OR CORRECTIVE MAINTENANCE OF BUS ECS ES 1 DUE TO UNSCHEDUL MAINTENANCE TO RECOGNIZE NEED AND TO OPEN RNS MOV V023		6.02E-04 3.00E-04 2.70E-03 5.00E-01	IEV-COMD IDABSDS1TM EC1BS001TM RHN-MAN05
187	2.42E-10	.01	LOCA/RNS-V024 CCF OF ACTUATION OPERATOR FAILS COND. PROB. OF	OPENS INITIATING EVENT OCCURS LOGIC GROUPS TO OPEN TWO IRWST MOVs RHN-MAN05 (OP. FAILS TO OPEN RNS MOV V023)	WITH RCS DRAINED	1.13E-05 8.58E-05 5.00E-01 5.00E-01	IEV-LOCA24D CCX-PMAMOD2X RHN-MAN05 RHN-MAN05C
188	2.37E-10	.01	LOSS OF OFFSITE FAILURE TO PUMP MP 01B D/G FAILS TO FAILURE OF INV. OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR START & RUN OR BRR 102 FAILS TO CLOSE STATIC SWITCH AND ASSOC. BREAKERS TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED DIVERTED FLOW BREAKERS	4.44E-03 4.20E-01 2.44E-02 2.02E-02 5.16E-04 5.00E-01	IEV-LOSPD OTH-R1 SMRMOD02 Z01MOD01 IDAMOD05 RHN-MAN05
189	2.27E-10	.01	LOSS OF OFFSITE FAILURE TO PUMP SUBLOOP B	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR HARDWARE FAILURE OR DIVERTED FLOW	WITH RCS DRAINED	4.44E-03 4.20E-01 1.04E-02	IEV-LOSPD OTH-R1 CCBMOD01S

Table 54B-9

CASE 4 LIST OF TOP 200 DOMINANT CUT SETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS	WITH RCS DRAINED	EVENT PROB	IDENTIFIER
			D/G FAILS TO FAILURE UPON OPERATOR FAILS	START & RUN OR DEMAND OF LOGIC TO RECOGNIZE	RHR 102 FAILS TO CLOSE GROUP PROCESSING NEED AND TO OPEN RNS MOV V023	2.02E-02 1.16E-03 5.00E-01	Z0IM0D01 PMA0301BSA RHN-MAN05
190	2.27E-10	.01	LOSS OF OFFSITE FAILURE TO PUMP SUBLOOP B D/G FAILS TO FAILURE UPON OPERATOR FAILS	POWER INITIATING RECOVER AC POWER IN 1 HOUR HARDWARE FAILURE OR DIVERTED FLOW START & RUN OR DEMAND OF LOGIC TO RECOGNIZE	WITH RCS DRAINED GROUP PROCESSING NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 1.04E-02 2.02E-02 1.16E-03 5.00E-01	IEV-LOSPOD OTH-R1 CCM0001S Z0IM0D01 PMA0301ASA RHN-MAN05
191	2.27E-10	.01	LOCA/RNS PIPE OPERATOR FAILS CCF OF GRAVITY	RUPTURE WITH RCS TO ISOLATE INJECTION CHECK	FILLED INIT. RNS PIPE RUPTURE VALVES TO OPEN	1.51E-05 5.00E-01 3.00E-05	IEV-LOCAPRND RHN-MAN04 INX-CV-AO
192	2.24E-10	.01	LOSS OF RNS WITH CCF OF SOFTWARE OPERATOR FAILS COND. PROB. OF	RCS DRAINED FOR ACTUATION TO OPEN TWO RHN-MAN05 (OP.)	INITIATING EVENT OCCURS LOGIC GROUPS IRWST MOVs FAILS TO OPEN	8.15E-05 1.10E-05 5.00E-01 5.00E-01	IEV-RNSD CCX-PMAN02-SW TWN-MAN00 RHN-MAN05C
193	2.24E-10	.01	LOSS OF RNS WITH CCF OF SOFTWARE OPERATOR FAILS COND. PROB. OF	RCS DRAINED FOR INPUT LOGIC TO OPEN TWO RHN-MAN05 (OP.)	INITIATING EVENT OCCURS GROUPS IRWST MOVs FAILS TO OPEN	8.15E-05 1.10E-05 5.00E-01 5.00E-01	IEV-RNSD CCX-IN-LOGIC-SW TWN-MAN00 RHN-MAN05C
194	2.20E-10	.01	LOCA/RNS-V024 DAS COND. PROB. OF RCITL195UF	OPENS INITIATING REC-MANDAS (FAILURE OF	EVENT OCCURS MANUAL DAS ACT.	1.68E-05 1.00E-02 5.00E-01 5.23E-03 5.00E-01	IEV-LOCA24ND DAS REC-MANDASC RCITL195UF LPM-MAN05
195	2.16E-10	.01	LOSS OF OFFSITE COMMON CAUSE LOSS OF DIST. OPERATOR FAILS	POWER INITIATING FAILURE TO 4KV BREAKER TO PANEL OR BREAKER A07 SPURIOUSLY TO RECOGNIZE	RECOVER AC POWER IN 1 HOUR CLOSE OPEN NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 7.30E-04 3.17E-04 5.00E-01	IEV-LOSPOD OTH-R1 ECX-CB-GC IDAM0D04 RHN-MAN05
196	2.14E-10	.01	LOSS OF RNS WITH CCF OF PRESSURE	RCS DRAINED TRANSMITTERS	INITIATING EVENT OCCURS	8.15E-05 2.63E-06	IEV-RNSD CCX-XMTRX
197	2.14E-10	.01	LOCA/RNS-V024 COMMON CAUSE COND. PROB. OF OPERATOR FAILS	OPENS INITIATING FAILURE OF 4 REC-MANDAS TO ACTUATE ADS	EVENT OCCURS CHECK VALVES TO (FAILURE OF BEFORE CORE	1.68E-05 5.10E-05 5.00E-01 5.00E-01	IEV-LOCA24ND OMX-CV-GO REC-MANDASC AEN-MAN01
198	2.14E-10	.01	LOCA/RNS-V024 COMMON CAUSE COND. PROB. OF OPERATOR FAILS	OPENS INITIATING FAILURE OF 4 REC-MANDAS TO RECOGNIZE THE NEED FOR RCS	EVENT OCCURS CHECK VALVES TO (FAILURE OF DEPRESSURIZATION	1.68E-05 5.10E-05 5.00E-01 5.00E-01	IEV-LOCA24ND OMX-CV-GO REC-MANDASC LPM-MAN05
199	2.12E-10	.01	LOSS OF OFFSITE COMMON CAUSE FAILURE OF INV. OPERATOR FAILS	POWER INITIATING FAILURE TO STANDBY DG TO STATIC SWITCH TO RECOGNIZE	EVENT OCCURS RECOVER AC POWER IN 1 HOUR RUN AND ASSOC. NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 4.40E-04 5.16E-04 5.00E-01	IEV-LOSPOD OTH-R1 Z0X-DG-DR IDAM0D05 RHN-MAN05

Table 54B-9

CASE 4 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER
200	2.06E-10	.61	LOSS OF CCS/SMS WITH RCS DRAINED FAILURE OF MANUAL DAS LEVEL TRANSMITTER OPERATOR FAILS TO ACTUATE ADS	INITIATING EVENT OCCURS REACTOR TRIP FAILURE BEFORE CORE DAMAGE	6.02E-04 1.00E-02 6.84E-05 5.00E-01	IEV-COND MDAS INITL170UFX ADN-MANO1

Table 54B-10

BASIC EVENT IMPORTANCE - CASE 4

	SYSTEM UNAVAILABILITY (Q) >	2.428E-06		
	NUMBER OF BASIC EVENTS >	295		
	NUMBER OF CUTSETS >	6834		
BASIC EVENT	IMPORTANCE (%DECREASE)	NUMBER OF CUTSETS	DECREASE IN SYSTEM UNAVAILABILITY	BASIC EVENT PROBABILITY
1 RHN-MAN05C	49.06	27	1.1913E-06	5.0000E-01
2 IEV-RCS0D	46.11	484	1.1197E-06	4.4400E-06
3 REC-MANDARC	40.87	46	9.9237E-07	5.0000E-01
4 IEV-CCWND	33.07	69	8.0301E-07	3.7500E-03
5 LPM-MAN05	28.98	37	7.0373E-07	5.0000E-01
6 IWN-MAN00	26.41	189	6.4125E-07	5.0000E-01
7 RHN-MAN04	23.08	123	5.6057E-07	5.0000E-01
8 RHN-MAN04-SUCC	23.06	399	5.6003E-07	5.0000E-01
9 IWN-MAN00C	23.03	23	5.5933E-07	5.0000E-01
10 CCX-ORY-SP	19.34	18	4.6959E-07	2.7700E-04
11 CCX-XMTR195	13.99	16	3.3961E-07	2.0100E-04
12 ADN-MAN01	12.71	58	3.0853E-07	5.0000E-01
13 PRN-MAN01	9.42	4	2.2868E-07	5.0000E-01
14 IEV-CCWD	9.28	2122	2.2541E-07	6.0200E-04
15 IEV-RNSND	6.06	46	1.4711E-07	9.6100E-04
16 CCX-INPUT-LOGIC	5.90	29	1.4331E-07	1.0300E-04
17 RHN-MAN05	4.54	785	1.1034E-07	5.0000E-01
18 IEV-LOSPD	3.18	2450	7.7138E-08	4.4400E-03
19 OTH-R1	2.98	2292	7.2384E-08	4.2000E-01
20 REC-MANDAS	1.52	36	3.6991E-08	5.0000E-01
21 IW1OR170SPX	1.37	34	3.3302E-08	9.4600E-05
22 IW2OR160SPX	1.37	34	3.3302E-08	9.4600E-05
23 IEV-RNSD	1.25	1015	3.0296E-08	8.1500E-05
24 CCX-EP-SAM	1.02	218	2.4744E-08	8.6200E-06
25 IW1TL170UFX	.99	33	2.4133E-08	6.8400E-05
26 IW2TL160UFX	.99	33	2.4133E-08	6.8400E-05
27 ADX-EV-SA	.96	290	2.3311E-08	3.0000E-05
28 PMAMOD11	.96	296	2.3247E-08	2.0900E-03
29 MDAS	.85	79	2.0583E-08	1.0000E-02
30 IWX-MV-GO1	.84	266	2.0342E-08	2.6000E-05
31 CCX-SFTW	.80	26	1.9545E-08	1.2000E-06
32 CCX-PMAMOD1X	.67	195	1.6365E-08	4.6300E-05
33 CCX-PMAMOD2X	.62	22	1.5006E-08	8.5800E-05
34 EDIMOD03	.53	131	1.2948E-08	2.2020E-03
35 PMA0301ASA	.52	218	1.2643E-08	1.1600E-03
36 PMA0301BSA	.52	218	1.2643E-08	1.1600E-03
37 Z01MOD01	.51	524	1.2300E-08	2.0200E-02
38 IWX-CV-AO	.49	395	1.1872E-08	3.0000E-05
39 Z0X-PD-ES	.49	113	1.1819E-08	2.0000E-03
40 IEV-LOSPND	.44	40	1.0762E-08	1.7100E-02
41 IWX-FL-GP	.39	168	9.5212E-09	1.2000E-05
42 SUC-R2S	.33	9	8.0530E-09	7.6000E-01
43 IEV-LOCA24ND	.31	121	7.6299E-09	1.6800E-05
44 ECX-CB-GO	.29	92	7.0988E-09	1.2000E-03
45 EC1CB100VO	.29	380	6.9747E-09	1.2300E-02
46 IDAMOD05	.28	354	6.7548E-09	5.1600E-04
47 RN23MOD5S	.24	917	5.7507E-09	2.2100E-03
48 CCX-PMA030X	.20	130	4.8587E-09	1.3800E-05
49 SUC-R1S	.20	158	4.7538E-09	5.8000E-01
50 SWBMOD02	.19	150	4.7168E-09	2.4400E-02
51 CCX-INPUT-LOGICX	.18	12	4.4596E-09	2.5900E-05
52 ECX-CB-GC	.18	74	4.2845E-09	7.3000E-04
53 IDAMOD04	.17	340	4.1872E-09	3.1700E-04
54 Z02MOD01	.17	187	4.1301E-09	2.0200E-02
55 IEV-LOCA24D	.17	428	4.0509E-09	1.1300E-05
56 CCX-PMAMOD1-SW	.16	128	3.8978E-09	1.1000E-05
57 IDABSDS1TM	.16	255	3.8177E-09	3.0000E-04
58 IEV-LOCAPRND	.13	59	3.1838E-09	1.5100E-05
59 RNBMOD07S	.12	146	2.9939E-09	1.5300E-02
60 OTH-R2	.11	29	2.7091E-09	2.4000E-01
61 CCX-ORY-SPX	.11	112	2.7053E-09	3.6300E-06
62 EC1BS001TM	.11	442	2.6382E-09	2.7000E-03
63 EC1BS012TM	.11	442	2.6382E-09	2.7000E-03
64 EC1BS121TM	.11	442	2.6382E-09	2.7000E-03
65 ZOX-DG-DR	.11	5	2.5654E-09	4.4000E-04
66 EC2CB200VO	.10	144	2.3656E-09	1.2300E-02

67	CCX-PHAMOD1	.10	87	2.3206E-09	1.4100E-04
68	PMAMOD11X	.09	369	2.2001E-09	6.5300E-04
69	CCX-XMTRX	.08	97	1.9520E-09	2.6300E-06
70	IRWMOD05S	.08	380	1.9059E-09	3.0000E-03
71	CCX-IN-LOGIC-SW	.08	8	1.8961E-09	1.1000E-05
72	CCX-PHAMOD2-SW	.08	8	1.8961E-09	1.1000E-05
73	CCBMOD01S	.08	91	1.8833E-09	1.0400E-02
74	PL5MOD11	.08	73	1.8546E-09	1.0900E-03
75	ED1MOD11	.07	55	1.7935E-09	1.1700E-04
76	ED1MOD113	.07	55	1.7935E-09	1.1700E-04
77	PMAMOD21X	.07	14	1.6249E-09	1.1600E-03
78	ZOX-DG-DS	.07	50	1.6061E-09	1.8000E-04
79	ZO1DG001TM	.06	95	1.4801E-09	4.6000E-02
80	CCX-PMAD30	.06	59	1.4742E-09	9.6900E-05
81	IWB-PLUG	.06	443	1.4174E-09	2.4000E-04
82	RHN-MAN03	.05	36	1.1106E-09	5.0000E-01
83	CCX-EP-SAMX	.04	87	1.0362E-09	2.9400E-06
84	PL50301ASA	.04	47	9.6705E-10	1.1600E-03
85	PL50301BSA	.04	47	9.6705E-10	1.1600E-03
86	CCX-BY-PN	.03	237	8.1154E-10	4.7000E-05
87	RNX-PM-FS	.03	50	7.8210E-10	7.7000E-04
88	IDDBSDD1TM	.03	370	7.7189E-10	3.0000E-04
89	IDDBSDK1TM	.03	370	7.7189E-10	3.0000E-04
90	IDDBSDS1TM	.03	370	7.7189E-10	3.0000E-04
91	ED2MOD03	.03	68	7.5987E-10	2.7000E-03
92	EC1REDG2GA	.03	57	7.4263E-10	4.3600E-03
93	ZOX-FD-ER	.03	32	7.0812E-10	1.3000E-04
94	RNX-KV-GO	.02	44	5.9576E-10	6.1000E-04
95	PMAXS00ASA	.02	28	5.6078E-10	8.0000E-05
96	PMA0301ASAX	.02	176	5.4451E-10	1.6500E-04
97	DAS	.02	4	5.3345E-10	1.0000E-02
98	PMA0301BSAX	.02	157	5.3061E-10	1.6500E-04
99	CCX-AV-LA	.02	5	5.2224E-10	6.1000E-05
100	CCB-MAN01	.02	6	5.1450E-10	5.0000E-01
101	IDCBSDD1TM	.02	176	4.7568E-10	3.0000E-04
102	IDCBSDK1TM	.02	176	4.7568E-10	3.0000E-04
103	IDDBSDS1TM	.02	176	4.7568E-10	3.0000E-04
104	RNDEP023SA	.02	291	4.3738E-10	1.7100E-04
105	CMX-CV-GO	.02	4	4.3656E-10	5.1000E-05
106	RNAMOD06S	.02	90	4.0233E-10	1.5300E-02
107	CCNTF101RI	.02	5	3.7355E-10	5.2300E-03
108	SWNTP001RI	.02	5	3.7355E-10	5.2300E-03
109	SWB-MAN02	.02	4	3.7350E-10	5.0000E-01
110	CCX-PMDMOD1	.01	270	3.5979E-10	1.4100E-04
111	ZO1MOD04	.01	82	3.4675E-10	1.2500E-03
112	ED1MOD01	.01	23	3.3742E-10	5.0400E-04
113	RC1OR195SP	.01	4	3.3587E-10	7.2200E-03
114	ED3MOD03	.01	35	3.3554E-10	2.2020E-03
115	CMX-VS-FA	.01	7	3.2865E-10	3.8400E-05
116	PMAMOD12X	.01	123	3.1897E-10	6.5300E-04
117	CCX-IV-XR	.01	132	3.0459E-10	2.4000E-05
118	PL4MOD11	.01	43	2.9430E-10	3.0900E-03
119	PL1MOD11	.01	36	2.9284E-10	2.0900E-03
120	PL7MOD11	.01	36	2.9284E-10	2.0900E-03
121	PMAXS00ASAX	.01	158	2.9216E-10	8.0000E-05
122	ZOX-BL-ES	.01	16	2.9153E-10	6.0000E-05
123	CCX-BY-PN1	.01	17	2.7939E-10	5.7000E-05
124	SWBMOD09P	.01	31	2.5840E-10	1.8500E-03
125	ZON-MAN01	.01	7	2.5070E-10	5.0000E-01
126	CCX-PMD030	.01	184	2.4527E-10	9.6900E-05
127	IWBKV122AO	.01	184	2.4081E-10	8.7600E-03
128	IWBKV123AO	.01	184	2.4081E-10	8.7600E-03
129	IWBKV124AO	.01	184	2.4081E-10	8.7600E-03
130	IWBKV125AO	.01	184	2.4081E-10	8.7600E-03
131	RC1TL195UF	.01	3	2.3779E-10	5.2300E-03
132	PMAMOD22X	.01	2	2.0389E-10	1.1600E-03
133	IDDBSDD1TM	.01	125	1.8655E-10	3.0000E-04
134	IDDBSDK1TM	.01	125	1.8655E-10	3.0000E-04
135	IDDBSDS1TM	.01	125	1.8655E-10	3.0000E-04
136	ED1MOD13	.01	17	1.6811E-10	3.1700E-04
137	ED1MOD07	.01	17	1.6183E-10	3.0500E-04
138	IDAMOD08	.01	96	1.5440E-10	3.1700E-04
139	IWA-PLUG	.01	136	1.5239E-10	2.4000E-04
140	ZG2MOD04	.01	44	1.5107E-10	1.2500E-03
141	PL40301ASA	.01	29	1.3152E-10	1.1600E-03
142	PL40301BSA	.01	26	1.3126E-10	1.1600E-03
143	PL10301ASA	.01	25	1.3097E-10	1.1600E-03
144	PL70301ASA	.01	25	1.3097E-10	1.1600E-03
145	PL10301BSA	.01	24	1.3091E-10	1.1600E-03
146	PL70301BSA	.01	24	1.3091E-10	1.1600E-03
147	CCX-PMDMOD4	.01	133	1.2412E-10	4.9800E-05

148	CCX-PMAMOD4	.00	41	1.1766E-10	4.9800E-05
149	IWACV122AO	.00	126	9.2456E-11	8.7600E-03
150	IWACV123AO	.00	126	9.2456E-11	8.7600E-03
151	IWACV124AO	.00	126	9.2456E-11	8.7600E-03
152	IWACV125AO	.00	126	9.2456E-11	8.7600E-03
153	IRAEPI21BSAX	.00	66	9.0638E-11	5.8300E-05
154	PMA0302ASAX	.00	59	7.0115E-11	1.6500E-04
155	SWAMOD07	.00	42	6.9016E-11	7.1200E-03
156	ED3MOD07	.00	26	6.4578E-11	3.0500E-04
157	PMA0302BSAX	.00	40	5.6211E-11	1.6500E-04
158	PMDDMOD11	.00	206	5.5612E-11	2.0900E-03
159	CCX-PL4MOD1	.00	17	5.4804E-11	1.4100E-04
160	CCAMOD02	.00	40	5.3178E-11	7.1000E-03
161	PL1MOD51	.00	2	4.5600E-11	8.7400E-04
162	EC1REDG1GA	.00	39	3.9569E-11	4.3600E-03
163	EC1MOD12	.00	66	3.6853E-11	4.8000E-05
164	Z02DG002TM	.00	42	3.4976E-11	4.6000E-02
165	IRAEPI21ASAX	.00	42	3.4265E-11	5.8300E-05
166	CCX-PL403	.00	14	3.3840E-11	9.6900E-05
167	IDAMOD06	.00	48	3.1916E-11	4.3200E-05
168	EC2BS002TM	.00	187	2.8167E-11	2.7000E-03
169	EC2BS022TM	.00	187	2.8167E-11	2.7000E-03
170	EC2BS221TM	.00	187	2.8167E-11	2.7000E-03
171	IDDFD019RQ	.00	58	2.7837E-11	1.2000E-05
172	IDDFD020RQ	.00	58	2.7837E-11	1.2000E-05
173	EC5EPMB1SA	.00	9	2.6790E-11	1.7100E-04
174	CCX-PMDDMOD1-SW	.00	56	2.5532E-11	1.1000E-05
175	CCX-PMDDMOD4-SW	.00	56	2.5532E-11	1.1000E-05
176	CCX-PMAMOD4-SW	.00	12	2.4547E-11	1.1000E-05
177	CCX-PL1MOD1	.00	9	2.2094E-11	1.4100E-04
178	CCX-PL7MOD1	.00	9	2.2094E-11	1.4100E-04
179	IDAMOD02	.00	31	2.0373E-11	2.7000E-03
180	IDAMOD03	.00	31	2.0373E-11	2.7000E-03
181	RNX-CV-GO	.00	12	1.7721E-11	5.1000E-05
182	PMDDMOD12	.00	86	1.6617E-11	2.0900E-03
183	IDCFD007RQ	.00	18	1.6478E-11	1.2000E-05
184	IDCFD008RQ	.00	18	1.6478E-11	1.2000E-05
185	PMDO301ASA	.00	134	1.6126E-11	1.1600E-03
186	CCX-PL103	.00	7	1.5111E-11	9.6900E-05
187	CCX-PL703	.00	7	1.5111E-11	9.6900E-05
188	PMDO301BSA	.00	117	1.4531E-11	1.1600E-03
189	CCX-LS-FA	.00	32	1.3597E-11	5.3700E-06
190	IDABSDS1LF	.00	24	1.3369E-11	4.8000E-06
191	PXX-AV-LA	.00	57	1.2491E-11	6.1000E-05
192	PL5XS00ASA	.00	7	1.2481E-11	8.0000E-05
193	ED2MOD01	.00	1	1.2200E-11	5.0400E-04
194	EC1MOD121	.00	24	1.1563E-11	1.6800E-05
195	IDDBSDD1LF	.00	31	1.1056E-11	4.8000E-06
196	IDDBSDK1LF	.00	31	1.1056E-11	4.8000E-06
197	IDDBSDS1LF	.00	31	1.1056E-11	4.8000E-06
198	SWAMOD09P	.00	22	1.0838E-11	1.8500E-03
199	CCX-PMDEH0	.00	29	9.2710E-12	4.0300E-06
200	CCX-PMAEH0X	.00	11	8.9933E-12	4.0300E-06
201	PMAMOD41	.00	34	8.2206E-12	6.3500E-04
202	ALL-IND-FAIL	.00	77	7.3394E-12	1.0000E-06
203	AD2MOD01	.00	21	6.8895E-12	5.5400E-02
204	AD2MOD02	.00	21	6.8895E-12	5.5400E-02
205	AD3MOD03	.00	21	6.8895E-12	5.5400E-02
206	AD3MOD04	.00	21	6.8895E-12	5.5400E-02
207	PMDDMOD41	.00	67	6.5833E-12	6.3500E-04
208	IDAMOD07	.00	15	6.3711E-12	2.1900E-02
209	RNX-PM-ER	.00	10	5.4562E-12	1.6000E-05
210	IDBFD013RQ	.00	10	5.2583E-12	1.2000E-05
211	IDBFD014RQ	.00	10	5.2583E-12	1.2000E-05
212	IDDMOD33	.00	45	4.9614E-12	5.1600E-04
213	IDCBSSD1LF	.00	12	4.9550E-12	4.8000E-06
214	IDCBSDK1LF	.00	12	4.9550E-12	4.8000E-06
215	IDCBSDS1LF	.00	12	4.9550E-12	4.8000E-06
216	PMDO302ASA	.00	46	4.9095E-12	1.1600E-03
217	CCX-PM-ER	.00	10	4.7707E-12	1.4000E-05
218	SWX-PM-ER	.00	10	4.7707E-12	1.4000E-05
219	IDDMOD32	.00	58	4.6906E-12	3.1700E-04
220	ED2MOD11	.00	20	4.3133E-12	3.1700E-04
221	CCX-IV-XR1	.00	6	3.7030E-12	2.4000E-05
222	CCX-PL4MOD1-SW	.00	8	3.6009E-12	1.1000E-05
223	PMDO302BSA	.00	29	3.3148E-12	1.1600E-03
224	ED3MOD01	.00	10	3.2503E-12	5.0400E-04
225	CCX-EP-SA	.00	8	2.8215E-12	8.6200E-06
226	EC1MOD01	.00	16	2.6423E-12	2.0200E-04
227	PL4MOD12	.00	16	2.6108E-12	2.0900E-03
228	EC1BS001LF	.00	7	2.1584E-12	4.8000E-06

229	EC2MOD01	.00	14	2.0179E-12	2.0200E-04
230	IDDMOD38	.00	31	1.6623E-12	1.1700E-04
231	CCX-PL1MOD1-SW	.00	4	1.5710E-12	1.1000E-05
232	CCX-PL7MOD1-SW	.00	4	1.5710E-12	1.1000E-05
233	ZANMOD01	.00	8	1.3746E-12	8.4000E-05
234	RNAEPRNPSA	.00	9	1.3107E-12	1.7100E-04
235	RNBEPRNPSA	.00	9	1.3107E-12	1.7100E-04
236	SW7EPSBPASA	.00	7	1.1083E-12	1.7100E-04
237	PLLMOD12	.00	7	1.0618E-12	6.0900E-03
238	PL7MOD12	.00	7	1.0618E-12	2.0900E-03
239	DG1-LOGIC	.00	1	9.6501E-13	5.0000E-03
240	PL40302ASA	.00	7	8.6231E-13	1.1600E-03
241	ADX-MV-GO	.00	4	8.1246E-13	1.1000E-03
242	IDBBBDD1LF	.00	7	8.0913E-13	4.8000E-06
243	IDBBBSDK1LF	.00	7	8.0913E-13	4.8000E-06
244	IDBBBSDS1LF	.00	7	8.0913E-13	4.8000E-06
245	PMDX500ASA	.00	32	7.8704E-13	8.0000E-05
246	PMDEHOA1SA	.00	28	7.7849E-13	8.0000E-05
247	CC1EPSBPASA	.00	6	7.6561E-13	1.7100E-04
248	Z01MOD03	.00	8	7.3574E-13	1.0000E-04
249	PMAEH0A1SAX	.00	6	7.2342E-13	8.0000E-05
250	PMAMOD42	.00	4	6.7402E-13	6.3500E-04
251	CC1EPSBPBSA	.00	5	6.3893E-13	1.7100E-04
252	SW7EPSBPBSA	.00	5	6.3893E-13	1.7100E-04
253	ED1BSDS1LF	.00	3	6.0907E-13	4.8000E-06
254	PL40302BSA	.00	4	6.0296E-13	1.1600E-03
255	SW7EPCTFASA	.00	4	5.7998E-13	1.7100E-04
256	SW7EPCTFBASA	.00	4	5.7998E-13	1.7100E-04
257	ED3BSDS1TM	.00	1	4.8805E-13	3.0000E-04
258	PMDMOD42	.00	11	4.8650E-13	6.3500E-04
259	IWNTK001AF	.00	5	4.7595E-13	2.4000E-06
260	Z02MOD03	.00	5	4.3032E-13	1.0000E-04
261	PRAAV108LA	.00	11	3.5461E-13	1.0900E-03
262	PRBAV108LA	.00	11	3.5461E-13	1.0900E-03
263	PLL10302ASA	.00	3	3.1919E-13	1.1600E-03
264	PLT70302ASA	.00	3	3.1919E-13	1.1600E-03
265	CCX-BC-SA	.00	5	2.8222E-13	8.4000E-06
266	PLL10302BSA	.00	2	2.5402E-13	1.1600E-03
267	PLT7G3D2BSA	.00	2	2.5402E-13	1.1600E-03
268	CCX-HE-AF	.00	3	2.3115E-13	1.2000E-06
269	PL1X500ASA	.00	3	2.1649E-13	8.0000E-05
270	PL4X500ASA	.00	3	2.1649E-13	8.0000E-05
271	PL7X500ASA	.00	3	2.1649E-13	8.0000E-05
272	CCX-XMTR	.00	3	1.9007E-13	2.0100E-04
273	PLMMOD41	.00	2	1.7897E-13	6.3500E-04
274	EC2MOD22	.00	17	1.5954E-13	4.8000E-05
275	PRAAV108TM	.00	9	1.5754E-13	5.0000E-04
276	PRBAV108TM	.00	9	1.5754E-13	5.0000E-04
277	CCX-TRNSM	.00	2	1.0192E-13	2.0100E-04
278	EC1MOD13	.00	2	9.6145E-14	4.8000E-05
279	EC2MOD23	.00	2	9.6145E-14	4.8000E-05
280	DG1-LOGIC	.00	1	9.0039E-14	5.0000E-03
281	ZOX-BL-ER	.00	1	6.5947E-14	1.3600E-06
282	ZOX-FL-GP	.00	1	6.2950E-14	1.3000E-06
283	IDDMOD21	.00	6	4.9960E-14	1.9200E-04
284	IDABSDD1TM	.00	3	2.4980E-14	3.0000E-04
285	IDABSDK1TM	.00	3	2.4980E-14	3.0000E-04
286	PRX-HR-ML	.00	4	2.3759E-14	1.2000E-07
287	PMDEHOA2SA	.00	10	2.7431E-14	8.0000E-05
288	IDDMOD34	.00	10	1.2101E-14	4.3200E-05
289	PRCEP108SA	.00	1	1.0547E-14	1.7100E-04
290	PRDEP108SA	.00	1	1.0547E-14	1.7100E-04
291	IDDMOD35	.00	4	5.7732E-15	2.1900E-02
292	EC2MOD221	.00	3	1.3323E-15	1.6800E-05
293	IWX_XMTRLW	.00	2	1.2212E-15	9.2000E-09
294	IDDMOD22	.00	3	9.9920E-16	2.7000E-03
295	IDDMOD23	.00	3	9.9920E-16	2.7000E-03

SYSTEM UNAVAILABILITY (Q) = 2.428E-06
 NUMBER OF BASIC EVENTS = 295
 NUMBER OF CUTSETS = 6834

BASIC EVENT	IMPORTANCE (%INCREASE)	NUMBER OF CUTSETS	INCREASE IN SYSTEM UNAVAILABILITY	BASIC EVENT PROBABILITY
1 IEV-RCSOD	1.038544E+07	484	2.5219E-01	4.4400E-06
2 CCX-SFTW	670744.	26	1.6288E-02	1.2000E-06
3 CCX-EP-SAM	118210.	218	2.8705E-03	8.6200E-06
4 CCX-ORY-SP	69793.3	18	1.6948E-03	2.7700E-04
5 CCX-XMTR195	69565.5	16	1.6893E-03	2.0100E-04
6 CCX-INPUT-LOGIC	57292.4	29	1.3912E-03	1.0300E-04
7 IWX-FL-GP	32680.4	168	7.9359E-04	1.2000E-05
8 IWX-MV-GO1	32218.1	406	7.8236E-04	2.6000E-05
9 ADX-EV-SA	31997.7	290	7.7701E-04	3.0000E-05
10 CCX-ORY-SPX	30690.2	112	7.4526E-04	2.6300E-06
11 CCX-XMTRX	30564.2	97	7.4220E-04	2.6300E-06
12 IEV-LOCA24ND	18702.3	121	4.5415E-04	1.6800E-05
13 IWX-CV-AO	16295.7	395	3.9571E-04	3.0000E-05
14 IEV-CCWD	15410.1	2122	3.7421E-04	6.0200E-04
15 IEV-RNSD	15306.8	1016	3.7170E-04	8.1500E-05
16 IEV-LOCA24D	14762.5	428	3.5848E-04	1.1300E-05
17 CCX-PMAMOD1-SW	14591.9	128	3.5434E-04	1.1000E-05
18 CCX-PMAMOD1X	14555.2	195	3.5345E-04	4.6300E-05
19 IW1TL170UPX	14528.4	33	3.5280E-04	6.8400E-05
20 IW2TL160UPX	14528.4	33	3.5280E-04	6.8400E-05
21 CCX-EP-SAMX	14514.1	87	3.5245E-04	2.9400E-06
22 CCX-PMA030X	14498.7	130	3.5207E-04	1.3800E-05
23 IW1OR170SPX	14495.4	34	3.5200E-04	9.4600E-05
24 IW2OR160SPX	14495.4	34	3.5200E-04	9.4600E-05
25 IEV-CWND	8785.20	69	2.1333E-04	3.7500E-03
26 IEV-LOCAPRND	8682.60	59	2.1084E-04	1.5100E-05
27 CCX-PMAMOD2X	7201.47	22	1.7488E-04	8.5800E-05
28 CCX-IN-LOGIC-SW	7098.28	8	1.7237E-04	1.1000E-05
29 CCX-PMAMOD2-SW	7098.28	8	1.7237E-04	1.1000E-05
30 CCX-INPUT-LOGICX	7090.53	12	1.7218E-04	2.5900E-05
31 IEV-RNSND	6297.81	46	1.5293E-04	9.6100E-04
32 IEV-LOSPD	712.270	2450	1.7296E-05	4.4400E-03
33 CCX-BY-PN	711.023	237	1.7266E-05	4.7000E-05
34 CCX-PMAMOD1	677.652	87	1.6456E-05	1.4100E-04
35 CCX-PMA030	626.452	59	1.5212E-05	9.6900E-05
36 IDAMOD04	543.770	340	1.3205E-05	3.1700E-04
37 IDAMOD05	538.807	354	1.3084E-05	5.1600E-04
38 IDABSDS1TM	523.898	255	1.2722E-05	3.0000E-04
39 CCX-IV-XR	522.623	132	1.2691E-05	2.4000E-05
40 PMAMOD11	457.098	296	1.1100E-05	2.0900E-03
41 PMA0301ASA	448.329	218	1.0887E-05	1.1600E-03
42 PMA0301BSA	448.329	218	1.0887E-05	1.1600E-03
43 CCX-AV-LA	152.539	5	8.5608E-06	6.1000E-05
44 CMX-CV-GO	352.488	4	8.5596E-06	5.1000E-05
45 CMX-VS-FA	352.435	7	8.5583E-06	3.8400E-05
46 ALL-IND-FAIL	372.239	27	7.3393E-06	1.0000E-06
47 PMAXSD00ASA	288.640	28	7.0091E-06	8.0000E-05
48 ECX-CB-UC	243.320	72	5.9086E-06	1.2000E-03
49 IWB-PLUG	243.147	443	5.9044E-06	2.4000E-04
50 ZOX-PD-ES	242.873	113	5.8978E-06	2.0000E-03
51 ED1MOD03	241.621	131	5.8673E-06	2.2020E-03
52 -CB-GC	241.522	74	5.8649E-06	7.3000E-04
53 -DG-DR	240.001	57	5.8280E-06	4.4000E-04
54 -G-DS	236.150	50	5.7345E-06	2.8000E-04
55 -D11	232.916	55	5.6560E-06	3.1700E-04
56 -D113	232.916	55	5.5608E-06	3.1700E-04
57 ZOX-PD-ER	224.284	32	5.4464E-06	1.3000E-04
58 CCX-BY-PN1	201.842	17	4.9014E-06	5.7000E-05
59 ZOX-BL-ES	200.080	16	4.8586E-06	6.0000E-05
60 PMAXSD00ASAX	150.379	158	3.6517E-06	8.0000E-05
61 PMAMOD11X	138.654	369	3.3670E-06	6.5300E-04
62 PMA0301ASAX	135.876	176	3.2995E-06	1.6500E-04
63 PMA0301BSAX	132.406	157	3.2153E-06	1.6500E-04
64 IDABSDS1LF	114.699	24	2.7853E-06	4.8000E-06
65 RN23MOD5S	106.921	917	2.5964E-06	2.2100E-03
66 IDDBSD001TM	105.925	370	2.5722E-06	3.0000E-04
67 IDDBSDK1TM	105.925	370	2.5722E-06	3.0000E-04
68 IDDBSDS1TM	105.925	370	2.5722E-06	3.0000E-04
69 RNDEP023SA	105.312	291	2.5573E-06	1.7100E-04
70 CCX-PMDMOD1	105.065	270	2.5513E-06	1.4100E-04
71 CCX-LS-FA	104.271	32	2.5320E-06	5.3700E-06
72 CCX-PMD030	104.225	184	2.5309E-06	9.6900E-05

73	CCX-PMDMOD4	102.635	133	2.4925E-06	4.9800E-05
74	CCX-PMAMOD4	97.2944	41	2.3676E-06	4.9800E-05
75	CCX-PMDMOD1-SW	95.5630	56	2.3211E-06	1.1000E-05
76	CCX-PMDMOD4-SW	95.5830	56	2.3211E-06	1.1000E-05
77	IDDPD019RQ	95.5274	56	2.3197E-06	1.2000E-05
78	IDDFD020RQ	95.5274	58	2.3197E-06	1.2000E-05
79	IDDBSDD1LF	94.8507	31	2.3033E-06	4.8000E-06
80	IDDBSDK1LF	94.8507	31	2.3033E-06	4.8000E-06
81	IDDBSDS1LF	94.8507	31	2.3033E-06	4.8000E-06
82	CCX-PMDEHO	94.7358	21	2.3005E-06	4.0300E-06
83	CCX-PMAEHOK	91.8973	11	2.2211E-06	4.0300E-06
84	CCX-PMAMOD4-SW	91.0956	12	2.2111E-06	1.1000E-05
85	MDAS	83.9156	79	2.0377E-06	1.0000E-02
86	IDCBSDD1TM	65.2765	176	1.5851E-06	3.0000E-04
87	IDCBSDK1TM	65.2765	176	1.5851E-06	3.0000E-04
88	IDCBSDS1TM	65.2765	176	1.5851E-06	3.0000E-04
89	IRAEPI21BSAX	64.0193	66	1.5546E-06	5.8300E-05
90	PMAMOD21X	57.6193	14	2.3992E-06	1.1600E-03
91	IDCFD17RQ	56.5473	18	1.3732E-06	1.2000E-05
92	IDCFD17BRQ	56.5473	18	1.3732E-06	1.2000E-05
93	RHN-MAN05C	49.0570	27	1.1913E-06	5.0000E-01
94	IDCBSDD1LF	42.5105	12	1.0323E-06	4.8000E-06
95	IDCBSDK1LF	42.5105	12	1.0323E-06	4.8000E-06
96	IDCBSDS1LF	42.5105	12	1.0323E-06	4.8000E-06
97	RNX-PM-FS	41.7955	50	1.0149E-06	7.7000E-04
98	REC-MANDASC	40.8664	46	9.9237E-07	5.0000E-01
99	RNX-KV-GO	40.1945	44	9.7505E-07	6.1000E-04
100	EC1BS001TM	40.1297	442	9.7448E-07	2.7000E-03
101	EC1BS012TM	40.1297	442	9.7448E-07	2.7000E-03
102	EC1BS121TM	40.1297	442	9.7448E-07	2.7000E-03
103	PL5MOD11	36.4662	73	8.8552E-07	2.0900E-03
104	PL50301ASA	34.2910	47	8.3270E-07	1.1600E-03
105	PL50301BSA	34.2910	47	8.3270E-07	1.1600E-03
106	EC1MOD12	31.6155	66	7.6773E-07	4.8000E-05
107	IDAMOD06	30.4224	48	7.3875E-07	4.3200E-05
108	LPM-MAN05	28.9799	37	7.0373E-07	5.0000E-01
109	EC1MOD121	28.3430	24	6.8826E-07	1.6800E-05
110	ED1MOD01	27.5556	23	6.6914E-07	5.0400E-04
111	IWN-MAN00	26.4069	189	6.4125E-07	5.0000E-01
112	IWA-PLUG	26.1420	136	6.3481E-07	2.4000E-04
113	IRWMOD05S	26.0833	380	6.3339E-07	3.0000E-03
114	IDBBSDD1TM	25.5997	125	6.2164E-07	3.0000E-04
115	IDBBSDK1TM	25.5997	125	6.2164E-07	3.0000E-04
116	IDBBSDS1TM	25.5997	125	6.2164E-07	3.0000E-04
117	IEV-LOSPND	25.4745	40	6.1860E-07	1.7100E-02
118	Z01MOD01	24.5691	524	5.9662E-07	2.0200E-02
119	IRAEPI21ASAX	24.2017	42	5.8770E-07	5.8300E-05
120	RHN-MAN04	23.0847	123	5.6057E-07	5.0000E-01
121	EC1CB100VO	23.0842	380	5.6007E-07	1.2300E-02
122	RHN-MAN04-SUCC	23.0625	399	5.6003E-07	5.0000E-01
123	IWN-MAN00C	23.0336	23	5.5933E-07	5.0000E-01
124	ED1MOD07	21.8434	17	5.3043E-07	3.0500E-04
125	ED1MOD13	21.8313	17	5.3014E-07	3.1700E-04
126	PMAMOD12X	20.1023	123	4.8815E-07	6.5300E-04
127	IDAMOD06	20.0513	96	4.8691E-07	3.1700E-04
128	EC1BS001LF	18.5173	7	4.4966E-07	4.8000E-06
129	IDBFD013RQ	18.0450	10	4.3819E-07	1.2000E-05
130	IDBFD014RQ	18.0450	10	4.3819E-07	1.2000E-05
131	PMA0302ASAX	17.4963	59	4.2487E-07	1.6500E-04
132	CCX-PL4MOD1	16.0040	17	3.8863E-07	1.4100E-04
133	CCX-PL403	14.3798	14	3.4919E-07	9.6900E-05
134	RNX-CV-GO	14.3087	12	3.4745E-07	5.1000E-05
135	RNX-PM-ER	14.0429	10	3.4101E-07	1.6000E-05
136	CCX-PM-ER	14.0328	10	3.4076E-07	1.4000E-05
137	SWX-PM-ER	14.0328	10	3.4076E-07	1.4000E-05
138	PMA0302BSAX	14.0269	40	3.1062E-07	1.6500E-04
139	CCX-PL4MOD1-SW	13.4805	8	3.2735E-07	1.1000E-05
140	CCX-EP-SA	13.4792	8	3.2732E-07	8.6200E-06
141	ADN MAN01	12.7054	58	3.0853E-07	5.0000E-01
142	ED2MOD03	11.5583	68	2.8067E-07	2.7000E-03
143	Z01MOD04	11.4092	82	2.7705E-07	1.2500E-03
144	PRN-MAN01	9.41718	4	2.2868E-07	5.0000E-01
145	ED3MOD07	8.71659	26	2.1167E-07	3.0500E-04
146	PXX-AV-LA	8.43237	57	2.0477E-07	6.1000E-05
147	Z02MOD01	8.24963	187	2.0333E-07	2.0200E-01
148	IWNTPK001AF	8.16666	5	1.9831E-07	2.4000E-06
149	PRX-HR-ML	8.15334	4	1.9799E-07	1.2000E-07
150	RNBMOD07S	7.93486	146	1.9268E-07	1.5300E-02
151	CCA HE-AF	7.93205	3	1.9262E-07	1.2000E-06
152	EC2CB200VO	7.82260	144	1.8996E-07	1.2300E-02
153	SWBMOD02	7.76650	150	1.8860E-07	2.4400E-03

154	CCBMOD01S	7.37986	91	1.7921E-07	1.0400E-02
155	PMAMOD22X	7.22998	2	1.7557E-07	1.1600E-03
156	EC1REDG2GA	6.98365	57	1.6959E-07	4.3600E-03
157	IDBBSDD1LF	6.94174	7	1.6857E-07	4.8000E-06
158	IDBBSDK1LF	6.94174	7	1.6857E-07	4.8000E-06
159	IDBBSDS1LF	6.94174	7	1.6857E-07	4.8000E-06
160	CCX-PL1MOD1	6.45198	9	1.5668E-07	1.4100E-04
161	CCX-PL7MOD1	6.45198	9	1.5668E-07	1.4100E-04
162	EC5EPMB1SA	6.45042	9	1.5664E-07	1.7100E-04
163	PL5KS00ASA	6.42419	7	1.5600E-07	8.0000E-05
164	CCX-PL103	6.42127	7	1.5593E-07	9.6900E-05
165	CCX-PL703	6.42127	7	1.5593E-07	9.6900E-05
166	CCX-IV-XR1	6.35374	6	1.5429E-07	2.4000E-05
167	ED3MOD03	6.26126	35	1.5204E-07	2.2020E-03
168	CCX-PL1MOD1-SW	5.88115	4	1.4281E-07	1.1000E-05
169	CCX-PL7MOD1-SW	5.88115	4	1.4281E-07	1.1000E-05
170	PL4MOD11	5.78667	43	1.4052E-07	4.0900E-03
171	PL1MOD11	5.75793	36	1.3982E-07	2.0900E-03
172	PL7MOD11	5.75793	36	1.3982E-07	2.0900E-03
173	SWBMOD09P	5.74125	31	1.3942E-07	1.8500E-03
174	IWX-KMTRLW	5.46648	2	1.3274E-07	9.2000E-09
175	ED1BSDS1LF	5.22535	3	1.2689E-07	4.8000E-06
176	ZO2MOD04	4.97060	44	1.2070E-07	1.2500E-03
177	PL40301ASA	4.66350	29	1.1324E-07	1.1600E-03
178	PL40301BSA	4.65430	26	1.1302E-07	1.1600E-03
179	PL10301ASA	4.64424	25	1.1278E-07	1.1600E-03
180	PL70301ASA	4.64424	25	1.1278E-07	1.1600E-03
181	PL10301BSA	4.64193	24	1.1272E-07	1.1600E-03
182	PL70301BSA	4.64193	24	1.1272E-07	1.1600E-03
183	RHN-MAN05	4.54369	785	1.1034E-07	5.0000E-01
184	OTH-R1	4.11637	2292	9.9959E-08	4.2000E-01
185	CCNTF101RI	2.92593	5	7.1051E-08	5.2300E-03
186	SWNTP001RI	2.92593	5	7.1051E-08	5.2300E-03
187	DAS	2.17481	4	5.2812E-08	1.0000E-02
188	PL1MOD51	2.14668	2	5.2128E-08	8.7400E-04
189	ZOX-BL-ER	1.99687	1	4.8491E-08	1.3600E-06
190	ZOX-FL-GP	1.99408	1	4.8423E-08	1.3000E-06
191	RC10R195SP	1.90187	4	4.6184E-08	7.2200E-03
192	RC1TL195UF	1.86255	3	4.5229E-08	5.2300E-03
193	REC-MANDAS	1.52332	36	3.6991E-08	5.0000E-01
194	CCX-BC-SA	1.38355	5	3.3597E-08	8.4000E-06
195	Z01DG001TM	1.26406	95	3.0696E-08	4.6000E-02
196	IWBCV122AO	1.12213	184	2.7249E-08	8.7600E-03
197	IWBCV123AO	1.12213	184	2.7249E-08	8.7600E-03
198	IWBCV124AO	1.12213	184	2.7249E-08	8.7600E-03
199	IWBCV125AO	1.12213	184	2.7249E-08	8.7600E-03
200	PMDMOD11	1.09347	206	2.6553E-08	2.0900E-03
201	RNAMOD06S	1.06633	90	2.5894E-08	1.5300E-02
202	ED2MOD01	.996332	1	2.419E-08	5.0400E-04
203	ZANMOD01	.673819	8	1.6163E-08	8.4000E-05
204	IDDMOD12	.609148	58	1.4792E-08	3.1700E-04
205	PMD0301ASA	.571805	134	1.3885E-08	1.1600E-03
206	ED2MOD11	.560155	20	1.3602E-08	3.1700E-04
207	EC1MOD01	.538568	16	1.3078E-08	2.0200E-04
208	PMAMOD41	.532782	34	1.2938E-08	6.3500E-04
209	PMD0301BSA	.515257	117	1.2512E-08	1.1600E-03
210	IWACV122AO	.430828	126	1.0462E-08	8.7600E-03
211	IWACV123AO	.430828	126	1.0462E-08	8.7600E-03
212	IWACV124AO	.430828	126	1.0462E-08	8.7600E-03
213	IWACV125AO	.430828	126	1.0462E-08	8.7600E-03
214	EC2BS002TM	.421411	187	1.0404E-08	2.7000E-03
215	EC2BS022TM	.428441	187	1.0404E-08	2.7000E-03
216	EC2BS221TM	.428441	187	1.0404E-08	2.7000E-03
217	PMDMOD41	.426664	67	1.0361E-08	6.3500E-04
218	EC2MOD01	.411303	14	9.9878E-09	2.0200E-04
219	PMDXS00ASA	.405101	32	9.8372E-09	8.0000E-05
220	PMDEHOA1SA	.400701	28	9.7303E-09	8.0000E-05
221	SWAMOD07	.396334	42	9.6243E-09	7.1200E-03
222	IDDMOD13	.395749	45	9.6101E-09	5.1600E-04
223	PMAEH0A1SAX	.372357	6	9.0420E-09	8.0000E-05
224	EC1REDG1GA	.361699	39	8.8075E-09	4.3600E-03
225	OTH-R2	.353274	29	8.5787E-09	2.4000E-01
226	PMDMOD12	.326736	86	7.9342E-09	2.0900E-03
227	RNAEPRNPSA	.315599	9	7.6638E-09	1.7100E-04
228	RNBEPRNPSA	.315599	9	7.6638E-09	1.7100E-04
229	IDAMOD02	.309896	31	7.5253E-09	2.7000E-03
230	IDAMOD03	.309896	31	7.5253E-09	2.7000E-03
231	CCAMOD02	.306247	40	7.4367E-09	7.1000E-03
232	Z01MOD03	.302954	8	7.3567E-09	1.0000E-04
233	SW7EPSBPASA	.266866	7	6.4804E-09	1.7100E-04
234	ED3MOD01	.265433	10	6.4457E-09	5.0400E-04

235	SWAMOD09P	.240805	22	5.8475E-09	1.8500E-03
236	IDDMOD3B	.215881	31	5.2423E-09	3.1700E-04
237	CC1EPSPBASA	.184344	6	4.4765E-09	1.7100E-04
238	ZO2MOD03	.177192	5	4.3028E-09	1.0000E-04
239	PMD0302ASA	.174088	46	4.2274E-09	1.1600E-03
240	CC1EPSPBBSA	.153843	5	3.7358E-09	1.7100E-04
241	SW7EPSPBBSA	.153843	5	3.7358E-09	1.7100E-04
242	SUC-R1S	.141760	158	3.4424E-09	5.8000E-01
243	SW7EPCTFASA	.139648	4	3.3911E-09	1.7100E-04
244	SW7EPCTFBSA	.139648	4	3.3911E-09	1.7100E-04
245	EC2MOD2	.136867	17	3.3236E-09	4.8000E-05
246	PMD0302BSA	.117540	29	2.8543E-09	1.1600E-03
247	PL1XSD0ASA	.111433	3	2.7060E-09	8.0000E-05
248	PL4XSD0ASA	.111433	3	2.7060E-09	8.0000E-05
249	PL7XSD0ASA	.111433	3	2.7060E-09	8.0000E-05
250	SUC-R2S	.104724	9	2.5430E-09	7.6000E-01
251	EC1MOD13	8.248194E-02	2	2.0029E-09	4.8000E-05
252	EC2MOD23	8.248194E-02	2	2.0029E-09	4.8000E-05
253	ED3BSDS1TM	6.697445E-02	1	1.6264E-09	3.0000E-04
254	PL4MOD12	5.133477E-02	16	1.2466E-09	2.0900E-03
255	RHN-MAN03	4.573561E-02	36	1.1106E-09	5.0000E-01
256	PMAMOD42	4.368313E-02	4	1.0608E-09	6.3500E-04
257	CCX-XMTR	3.893350E-02	3	9.4543E-10	2.0100E-04
258	PMDMOD42	3.153014E-02	11	7.6556E-10	6.3500E-04
259	PL40302ASA	3.057696E-02	7	7.4251E-10	1.1600E-03
260	A7X-MV-GO	3.038259E-02	4	7.3779E-10	1.1000E-03
261	ZL2DQ002TM	2.987156E-02	42	7.2538E-10	4.6000E-02
262	PL40302BSA	2.138065E-02	4	5.1919E-10	1.1600E-03
263	CCB-MAN01	2.118743E-02	6	5.1450E-10	5.0000E-01
264	PL1XDD12	2.087794E-02	7	5.0698E-10	2.0900E-03
265	PL7MD12	2.087794E-02	7	5.0698E-10	2.0900E-03
266	CCX-XNSM	2.087673E-02	2	5.0696E-10	2.0100E-04
267	SWB-MAJ02	1.538096E-02	4	3.7350E-10	5.0000E-01
268	PRAV108LA	1.338252E-02	11	3.2497E-10	1.0900E-03
269	PRAV108LA	1.338252E-02	11	3.2497E-10	1.0900E-03
270	PRAAV108TM	1.296875E-02	9	3.1492E-10	5.0000E-04
271	PRAV108TM	1.296875E-02	9	3.1492E-10	5.0000E-04
272	IDAMOD07	1.171786E-02	15	2.8455E-10	2.1900E-02
273	PLMMOD41	1.159895E-02	2	2.8166E-10	6.3500E-04
274	IDDMOD34	1.153525E-02	10	2.8011E-10	4.3200E-05
275	PL10302ASA	1.131824E-02	3	2.7484E-10	1.1600E-03
276	PL70302ASA	1.131824E-02	3	2.7484E-10	1.1600E-03
277	IDDMOD21	1.071349E-02	6	2.6016E-10	1.9200E-04
278	ZON-MAN01	1.032399E-02	7	2.5070E-10	5.0000E-01
279	PL10302BSA	9.007351E-03	2	2.1873E-10	1.1600E-03
280	PL70302BSA	9.007351E-03	2	2.1873E-10	1.1600E-03
281	PMDEH0A2SA	8.971768E-03	10	2.1786E-10	8.0000E-05
282	DG1-LOGIC	7.908168E-03	1	1.9204E-10	5.0000E-03
283	AD2MOD01	4.837467E-03	21	1.1747E-10	5.5400E-02
284	AD2MOD02	4.837467E-03	21	1.1747E-10	5.5400E-02
285	AD3MOD03	4.837467E-03	21	1.1747E-10	5.5400E-02
286	AD3MOD04	4.837467E-03	21	1.1747E-10	5.5400E-02
287	IDABSDD1TM	3.4227946E-03	3	8.3242E-11	3.0000E-04
288	IDABSDK1TM	3.4227946E-03	3	8.3242E-11	3.0000E-04
289	EC2MOD221	3.265636E-03	3	7.9300E-11	1.6800E-05
290	PRCEP108SA	2.539547E-03	1	6.1669E-11	1.7100E-04
291	PRDEP108SA	2.539547E-03	1	6.1669E-11	1.7100E-04
292	DG1-LOGIC	7.378652E-04	1	1.7918E-11	5.0000E-03
293	IDDMOD22	1.519874E-05	3	3.6908E-13	2.7000E-03
294	IDDMOD23	1.519874E-05	3	3.6908E-13	2.7000E-03
295	IDDMOD35	1.061807E-05	4	2.5784E-13	2.1900E-02

Table 54B-11

CASE 5 LIST OF TOP 200 DOMINANT CUTSETS

Reduced Sum of Cutsets: 6.196E-06

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER
1	1.11E-06	17.91	OVERDRAINING OF RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT	4.44E-06	IEV-RCSOD	
			OPERATOR FAILS TO ISOLATE SNS PIPE RUPURE	5.00E-01	RHN-MAN04	
			IWN-MANDOC MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	5.00E-01	IWN-MAN00C	
				1.00E+00	RN23MOD5S	
2	1.11E-06	17.91	OVERDRAINING OF RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT	4.44E-06	IEV-RCSOD	
			RHN-MAN04-SUCC OPERATOR FAILS TO OPEN TWO IRWST MOVs	5.00E-01	RHN-MAN04-SUCC	
			MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	5.00E-01	IWN-MAN00	
				1.00E+00	RN23MOD5S	
3	5.55E-07	8.96	OVERDRAINING OF RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT	4.44E-06	IEV-RCSOD	
			OPERATOR FAILS TO ISOLATE SNS PIPE RUPURE	5.00E-01	RHN-MAN04	
			IWN-MAN00C COND. PROB. OF RHN-MAN05 (OP. FAILS TO OPEN RNS MOV V023)	5.00E-01	IWN-MAN00C	
				5.00E-01	RHN-MAN05C	
4	5.55E-07	8.96	OVERDRAINING OF RCS DURING DRAIN DOWN TO MID-LOOP INITIATING EVENT	4.44E-06	IEV-RCSOD	
			RHN-MAN04-SUCC OPERATOR FAILS TO OPEN TWO IRWST MOVs	5.00E-01	RHN-MAN04-SUCC	
			COND. PROB. CF RHN-MAN05 (OP. FAILS TO OPEN RNS MOV V023)	5.00E-01	IWN-MAN00	
				5.00E-01	RHN-MAN05C	
5	2.60E-07	4.20	LOSS OF CCS/SWS WITH RCS FILLED INITIATING EVENT OCCURS	3.75E-03	IEV-CCWD	
			COND. PROB. OF REC-MANDAS (FAILURE OF MANUAL DAS ACT.	5.00E-01	REC-MANDASC	
			CCF OF ORIFICES TO RECOGNIZE THE NEED FOR RCS DEPRESSURIZATION	2.77E-04	CCX-DRY-SP	
			OPERATOR FAILS	5.00E-01	LPM-MAN05	
6	1.88E-07	3.03	LOSS OF CCS/SWS WITH RCS FILLED INITIATING EVENT OCCURS	3.75E-03	IEV-CCWD	
			COND. PROB. OF REC-MANDAS (FAILURE OF MANUAL DAS ACT.	5.00E-01	REC-MANDASC	
			CCF OF PRESSURE TRANSMITTERS TO RECOGNIZE THE NEED FOR RCS DEPRESSURIZATION	2.01E-04	CCX-XMTR195	
			OPERATOR FAILS	5.00E-01	LPM-MAN05	
7	1.81E-07	2.92	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS	6.02E-04	IEV-CCWD	
			CHECK VALVE 122A FAILS TO OPEN	1.00E+00	IWACV122AO	
			CHECK VALVE 124A FAILS TO OPEN	1.00E+00	IWACV124AO	
			BUS UNAVAILABLE DUE TO TEST OR CORRECTIVE MAINTENANCE	3.00E-04	IDCBSD1TM	
			MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	1.00E+00	RN23MOD5S	
8	1.81E-07	2.92	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS	6.02E-04	IEV-CCWD	
			CHEC. VALVE 122A FAILS TO OPEN	1.00E+00	IWACV122AO	
			CHEC. VALVE 124A FAILS TO OPEN	1.00E+00	IWACV124AO	
			BUS UNAVAILABLE DUE TO TEST OR CORRECTIVE MAINTENANCE	3.00E-04	IDCBSD1TM	
			MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	1.00E+00	RN23MOD5S	
9	1.81E-07	2.92	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS	6.02E-04	IEV-CCWD	
			CHECK VALVE 122A FAILS TO OPEN	1.00E+00	IWACV122AO	
			CHECK VALVE 124A FAILS TO OPEN	1.00E+00	IWACV124AO	
			BUS UNAVAILABLE DUE TO TEST OR CORRECTIVE MAINTENANCE	3.00E-04	IDCBSD1TM	
			MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	1.00E+00	RN23MOD5S	
10	1.44E-07	2.32	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS	6.02E-04	IEV-CCWD	
			CHECK VALVE 122A FAILS TO OPEN	1.00E+00	IWACV122AO	
			CHECK VALVE 124A FAILS TO OPEN	1.00E+00	IWACV124AO	
			IRWST DISCHARGE LINE "B" STRAINER PLUGGED	2.40E-04	IWB-PLUG	

Table 54B-11

CASE 5 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET	PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS	EVENT PROB	IDENTIFIER
1.1	1.30E-07	2.10	LOSS OF CCS/SWS WITH RCS FILLED	(FAILURE OF REC-MANDAS	MANUAL DAS ACT	3.75E-03	IEV-CMD
			COND. PROB. OF REC-MANDAS	CCP OF ORIFICES		5.00E-01	REC-MANDAS
			PRN-MAN01	OPERATOR FAILS	TO ACTUATE ADS	2.77E-04	CCX-ORY-SP
					BEFORE CORE	5.00E-01	PRN-MAN01
					DAMAGE	5.00E-01	ADM-MAN01
1.2	9.66E-08	1.56	LOSS OF CCS/SWS WITH RCS FILLED	INITIATING EVENT OCCURS	3.75E-03	IEV-CMD	
			COND. PROB. OF REC-MANDAS	(FAILURE OF COMMON MODE	MANUAL DAS ACT	5.00E-01	REC-MANDAS
			CCP OF ORIFICES	OPERATOR FAILS	LOGIC GROUPS	1.01E-04	CCX-INPUT-LOGIC
			PRN-MAN01	TO RECOGNIZE THE NEED FOR RCS	DEPRESSURIZATION	5.00E-01	LPM-MAN05
1.3	9.42E-08	1.52	LOSS OF CCS/SWS WITH RCS FILLED	INITIATING EVENT OCCURS	3.75E-03	IEV-CMD	
			COND. PROB. OF CCP OF PRESSURE	(FAILURE OF REC-MANDAS	MANUAL DAS ACT	5.00E-01	REC-MANDAS
			PRN-MAN01	TRANSMITTERS		2.01E-04	CCX-NMT195
			OPERATOR FAILS	TO ACTUATE ADS		5.00E-01	PRN-MAN01
					BEFORE CORE	5.00E-01	ADM-MAN01
1.4	9.03E-08	1.46	LOSS OF CCS/SWS WITH RCS DRAINED	INITIATING EVENT OCCURS	6.02E-04	IEV-CMD	
			CHECK VALVE	FAILS TO OPEN	1.00E+00	IMACV122AO	
			CHECK VALVE	FAILS TO OPEN	1.00E+00	IMACV124AO	
			BUS UNAVAILABLE	NEED TO TEST OR	3.00E-04	IDCSBD17W	
			OPERATOR FAILS	TO RECOGNIZE	5.00E-01	RBN-MAN05	
1.5	9.03E-08	1.46	LOSS OF CCS/SWS WITH RCS DRAINED	INITIATING EVENT OCCURS	6.02E-04	IEV-CMD	
			CHECK VALVE	FAILS TO OPEN	1.00E+00	IMACV122AO	
			CHECK VALVE	FAILS TO OPEN	1.00E+00	IMACV124AO	
			BUS UNAVAILABLE	NEED AND TO OPEN RNS MOV V023	3.00E-04	IDCSBD17W	
			OPERATOR FAILS		5.00E-01	RBN-MAN05	
1.6	9.03E-08	1.46	LOSS OF CCS/SWS WITH RCS DRAINED	INITIATING EVENT OCCURS	6.02E-04	IEV-CMD	
			CHECK VALVE	FAILS TO OPEN	1.00E+00	IMACV122AO	
			CHECK VALVE	FAILS TO OPEN	1.00E+00	IMACV124AO	
			BUS UNAVAILABLE	NEED AND TO OPEN RNS MOV V023	3.00E-04	IDCSBD17W	
			OPERATOR FAILS		5.00E-01	RBN-MAN05	
1.7	6.65E-08	1.07	LOSS OF RNS WITH RCS FILLED	INITIATING EVENT OCCURS	9.61E-04	IEV-RNSND	
			COND. PROB. OF CCP OF ORIFICES	(FAILURE OF REC-MANDAS	MANUAL DAS ACT	5.00E-01	REC-MANDAS
			PRN-MAN01	TO RECOGNIZE THE NEED FOR RCS	DEPRESSURIZATION	2.77E-04	CCX-ORY-SP
			OPERATOR FAILS			5.00E-01	LPM-MAN05
1.8	4.83E-08	.78	LOSS OF RNS WITH RCS FILLED	INITIATING EVENT OCCURS	9.61E-04	IEV-RNSND	
			COND. PROB. OF CCP OF ORIFICES	(FAILURE OF REC-MANDAS	MANUAL DAS ACT	5.00E-01	REC-MANDAS
			CCP OF PRESSURE	TRANSMITTERS		2.01E-04	CCX-NMT195
			PRN-MAN01	TO RECOGNIZE THE NEED FOR RCS	DEPRESSURIZATION	5.00E-01	LPM-MAN05
1.9	3.51E-08	.57	LOSS OF CCS/SWS WITH RCS DRAINED	INITIATING EVENT OCCURS	6.02E-04	IEV-CMD	
			CHECK VALVE	FAILS TO OPEN	1.00E+00	IMACV122AO	
			CHECK VALVE	FAILS TO OPEN	1.00E+00	IMACV124AO	
			FAILURE OF POWER	INTERFACE OUTPUT BOARD	5.83E-05	TRAEP12IBSAK	
			MECHANICAL	FAILURE CAUSES	1.00E+00	RNC3M0D55	
20	2.85E-08	.46	LOSS OF CCS/SWS WITH RCS DRAINED	INITIATING EVENT OCCURS	6.02E-04	IEV-CMD	
			ORIFICE FAILURE	DO TO PLUGGING	9.46E-05	INIOR170SPX	
			OPERATOR FAILS	TO OPEN TWO	5.00E-01	INR-BMAN01	
			MECHANICAL	FAILURE CAUSES	1.00E+00	RNC23M0D55	

Table 54B-11

CASE 5 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS	EVENT PROB	IDENTIFIER
21	2.85E-08	.46	LOSS OF CCS/SWS ORIFICE FAILURE OPERATOR FAILS MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS DUE TO PLUGGING TO OPEN TWO IRWST MOVs FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	6.02E-04 9.46E-05 5.00E-01 1.00E+00	IEV-COWD IW2OR160SPX IWN-MAN00 RN23MOD5S
22	2.79E-08	.45	LOSS OF CCS/SWS CCF OF ACTUATION MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS LOGIC GROUPS FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	6.02E-04 4.63E-05 1.00E+00	IEV-COWD CCX-PHAMOD1X RN23MOD5S
23	2.58E-08	.42	LOSS OF CCS/SWS CCF OF ACTUATION OPERATOR FAILS MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS LOGIC GROUPS TO OPEN TWO IRWST MOVs FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	6.02E-04 8.58E-05 5.00E-01 1.00E+00	IEV-COWD CCX-PHAMOD2X IWN-MAN00 RN23MOD5S
24	2.47E-08	.40	LOSS OF RNS WITH RCS FILLED COND. PROB. OF REC-MANDAS COMMON MODE OPERATOR FAILS	INITIATING EVENT OCCURS (FAILURE OF MANUAL DAS ACT. FAILURE OF INPUT LOGIC GROUPS TO RECOGNIZE THE NEED FOR RCS DEPRESSURIZATION	9.61E-04 5.00E-01 1.03E-04 5.00E-01	IEV-RNSND REC-MANDASC CCX-JINPUT-LOGIC LPM-MAN05
25	2.45E-08	.40	LOSS OF RNS WITH RCS DRAINED CHECK VALVE 122A CHECK VALVE 124A BUS UNAVAILABLE MECHANICAL	INITIATING EVENT OCCURS FAILS TO OPEN FAILS TO OPEN CORRECTIVE MAINTENANCE FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	8.15E-05 1.00E+00 1.00E+00 3.00E-04 1.00E+00	IEV-RNSD IWACV122AG IWACV124AO IDCBSD1TM RN23MOD5S
26	2.45E-08	.40	LOSS OF RNS WITH RCS DRAINED CHECK VALVE 122A CHECK VALVE 124A BUS UNAVAILABLE MECHANICAL	INITIATING EVENT OCCURS FAILS TO OPEN FAILS TO OPEN CORRECTIVE MAINTENANCE FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	8.15E-05 1.00E+00 1.00E+00 3.00E-04 1.00E+00	IEV-RNSD IWACV122AO IWACV124AO IDCBSD1TM RN23MOD5S
27	2.45E-08	.40	LOSS OF RNS WITH RCS DRAINED CHECK VALVE 122A CHECK VALVE 124A BUS UNAVAILABLE MECHANICAL	INITIATING EVENT OCCURS FAILS TO OPEN FAILS TO OPEN CORRECTIVE MAINTENANCE FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	8.15E-05 1.00E+00 1.00E+00 3.00E-04 1.00E+00	IEV-RNSD IWACV122AO IWACV124AO IDCBSD1TM RN23MOD5S
28	2.29E-08	.37	LOSS OF CCS/SWS DUE TO CCF OF THE SQUIB VALVES	WITH RCS DRAINED INITIATING EVENT OCCURS TO OPERATE	6.02E-04 3.80E-05	IEV-COWD ADX-EV-SA
29	2.29E-08	.37	LOSS OF CCS/SWS CCF OF IRWST INJ MOVs 121A, 121B, & RNS V023	WITH RCS DRAINED INITIATING EVENT OCCURS	6.02E-04 3.80E-05	IEV-COWD IWX-MV-G01
30	2.06E-08	.33	LOSS OF CCS/SWS LEVEL OPERATOR FAILS MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS TRANSMITTER FAILURE TO OPEN TWO IRWST MOVs FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	6.02E-04 6.84E-05 5.00E-01 1.00E+00	IEV-COWD IW2TL160UFX IWN-MAN00 RN23MOD5S
31	2.06E-08	.33	LOSS OF CCS/SWS LEVEL OPERATOR FAILS MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS TRANSMITTER FAILURE TO OPEN TWO IRWST MOVs FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	6.02E-04 6.84E-05 5.00E-01 1.00E+00	IEV-COWD IW1TL170UFX IWN-MAN00 RN23MOD5S
32	1.96E-08	.32	LOSS OF RNS WITH RCS DRAINED CHECK VALVE 122A CHECK VALVE 124A IRWST DISCHARGE LINE "B"	INITIATING EVENT OCCURS FAILS TO OPEN FAILS TO OPEN STRAINER PLUGGED	8.15E-05 1.00E+00 1.00E+00 2.40E-04	IEV-RNSD IWACV122AO IWACV124AO IWB-PLUG

Table 54B-11

CASE 5 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME			EVENT PROB	IDENTIFIER
33	1.87E-08	.30	LOSS OF CCS/SWS WITH RCS DRAINED CCF OF GRAVITY INJECTION CHECK MECHANICAL FAILURE CAUSES	INITIATING EVENT OCCURS VALVES TO OPEN MOV 023 TO FAIL-TO-OPEN		6.02E-04 3.10E-05 1.00E+00	IEV-CCMD IWACV122AO RHN-MAN05
34	1.75E-08	.28	LOSS OF CCS/SWS WITH RCS DRAINED CHECK VALVE 122A CHECK VALVE 124A FAILURE OF POWER INTERFACE OUTPUT BOARD OPERATOR FAILS	INITIATING EVENT OCCURS FAILS TO OPEN FAILS TO OPEN NEED AND TO OPEN RNS MOV V023		6.02E-04 1.00E+00 1.00E+00 5.83E-05 5.00E-01	IEV-CCMD IWACV122AO IWACV124AL TRAEPI21BSAK RHN-MAN05
35	1.62E-08	.26	LOSS OF CCS/SWS WITH RCS FILLED FAILURE OF MANUAL DAS CCF OF THE POWER INTERFACE OUTPUT BOARDS IN PHS	INITIATING EVENT OCCURS ACTUATION BOARDS IN PHS		3.75E-03 5.00E-01 8.62E-06	IEV-CCMD REC-MANDAS CCX-EP-SAM
36	1.55E-08	.25	LOSS OF CCS/SWS WITH RCS DRAINED COND. PROB. OF REC-MANDAS COMMON MODE FAILURE OPERATOR FAILS	INITIATING EVENT OCCURS (FAILURE OF MANUAL DAS ACT.) FAILURE OF INPUT LOGIC GROUPS TO ACTUATE ADS BEFORE CORE		6.02E-04 5.00E-01 1.03E-04 5.00E-01	IEV-CCMD REC-MANDASC CCX-INPUT-LOGIC ADN-MAN01
37	1.42E-08	.23	LOSS OF CCS/SWS WITH RCS DRAINED COND. PROB. OF REC-MANDAS ORIFICE FAILURE OPERATOR FAILS	INITIATING EVENT OCCURS (FAILURE OF MANUAL DAS ACT.) DUE TO PLUGGING TO ACTUATE ADS BEFORE CURE		6.02E-04 5.00E-01 9.46E-05 5.00E-01	IEV-CCMD REC-MANDASC IW1OR170SPX ADN-MAN01
38	1.42E-08	.23	LOSS OF CCS/SWS WITH RCS DRAINED COND. PROB. OF REC-MANDAS ORIFICE FAILURE OPERATOR FAILS	INITIATING EVENT OCCURS (FAILURE OF MANUAL DAS ACT.) DUE TO PLUGGING TO ACTUATE ADS BEFORE CORE		6.02E-04 5.00E-01 9.46E-05 5.00E-01	IEV-CCMD REC-MANDASC IW2OR160SPX ADN-MAN01
39	1.42E-08	.23	LOSS OF CCS/SWS WITH RCS DRAINED ORIFICE FAILURE OPERATOR FAILS COND. PROB. OF RHN-MAN05 (OP.)	INITIATING EVENT OCCURS DUE TO PLUGGING TO OPEN TWO IRWST MOVs FAILS TO OPEN RNS MOV V023)		6.02E-04 9.46E-05 5.00E-01 5.00E-01	IEV-CCMD IW2OR160SPX IWN-MAN00 RHN-MAN05
40	1.42E-08	.23	LOSS OF CCS/SWS WITH RCS DRAINED ORIFICE FAILURE OPERATOR FAILS COND. PROB. OF RHN-MAN05 (OP.)	INITIATING EVENT OCCURS DUE TO PLUGGING TO OPEN TWO IRWST MOVs FAILS TO OPEN RNS MOV V023)		6.02E-04 9.46E-05 5.00E-01 5.00E-01	IEV-CCMD IW1OR170SPX IWN-MAN00 RHN-MAN05
41	1.39E-08	.22	LOSS OF CCS/SWS WITH RCS DRAINED CCF OF ACTUATION OPERATOR FAILS	INITIATING EVENT OCCURS LOGIC GROUPS TO RECOGNIZE		6.02E-04 4.63E-05 5.00E-01	IEV-CCMD CCX-PMAMODIX RHN-MAN05
42	1.29E-08	.21	LOSS OF CCS/SWS WITH RCS DRAINED CCF OF ACTUATION OPERATOR FAILS COND. PROB. OF RHN-MAN05 (OP.)	INITIATING EVENT OCCURS LOGIC GROUPS TO OPEN TWO IRWST MOVs FAILS TO OPEN RNS MOV V023)		6.02E-04 8.58E-05 5.00E-01 5.00E-01	IEV-CCMD CCX-PMAMOD2X IWN-MAN00 RHN-MAN05C
43	1.22E-08	.20	LOSS OF RNS WITH RCS DRAINED CHECK VALVE 122A CHECK VALVE 124A BUS UNAVAILABLE OPERATOR FAILS	INITIATING EVENT OCCURS FAILS TO OPEN FAILS TO OPEN CORRECTIVE MAINTENANCE NEED AND TO OPEN RNS MOV V023		8.15E-05 1.00E+00 1.00E+00 3.00E-04 5.00E-01	IEV-RNSD IWACV122AO IWACV124AO IDCBSDK1TM RHN-MAN05
44	1.22E-08	.20	LOSS OF RNS WITH RCS DRAINED CHECK VALVE 122A CHECK VALVE 124A BUS UNAVAILABLE OPERATOR FAILS	INITIATING EVENT OCCURS FAILS TO OPEN FAILS TO OPEN CORRECTIVE MAINTENANCE NEED AND TO OPEN RNS MOV V023		8.15E-05 1.00E+00 1.00E+00 3.00E-04 5.00E-01	IEV-RNSD IWACV122AO IWACV124AO IDCBSDS1TM RHN-MAN05

112

Table 54B-11

CASE 5 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER
45	1.22E-08	20	LOSS OF RNS WITH RCS DRAINED CHECK VALVE 122A CHECK VALVE 124A BUS UNAVAILABLE DUE TO TEST OR OPERATOR FAILS TO RECOGNIZE	INITIATING EVENT OCCURS FAILS TO OPEN FAILS TO OPEN CORRECTIVE MAINTENANCE NEED AND TO OPEN RNS MOV V023	6.15E-05 1.00E+00 1.00E+00 3.00E-04 5.00E-01	IEV-RNSD IWACV122AO IWACV124AO IDCBSDDITM RHN-MAN05
46	1.03E-08	17	LOSS OF CCS/SWS LEVEL OPERATOR FAILS COND. PROB. OF RHN-MAN05 (OP)	WITH RCS DRAINED TRANSMITTER FAILURE TO OPEN TWO IRWST MOVs FAILS TO OPEN RNS MOV V023)	6.02E-04 6.84E-05 5.00E-01 5.00E-01	IEV-COWD IWITL170UFX IWN-MAN00 RHN-MAN05C
47	1.03E-08	17	LOSS OF CCS/SWS COND. PROB. OF REC-MANDAS LEVEL OPERATOR FAILS	WITH RCS DRAINED REC-MANDAS (FAILURE OF TRANSMITTER FAILURE TO ACTUATE ADS BEFORE CORE	6.02E-04 5.00E-01 6.84E-05 5.00E-01	IEV-COWD REC-MANDASC IW2TL160UFX ADN-MAN01
48	1.03E-08	17	LOSS OF CCS/SWS COND. PROB. OF REC-MANDAS LEVEL OPERATOR FAILS	WITH RCS DRAINED (FAILURE OF TRANSMITTER FAILURE TO ACTUATE ADS BEFORE CORE	6.02E-04 5.00E-01 6.84E-05 5.00E-01	IEV-COWD REC-MANDASC IWITL170UFX ADN-MAN01
49	1.03E-08	17	LOSS OF CCS/SWS LEVEL OPERATOR FAILS COND. PROB. OF RHN-MAN05 (OP)	WITH RCS DRAINED TRANSMITTER FAILURE TO OPEN TWO IRWST MOVs FAILS TO OPEN RNS MOV V023)	6.02E-04 6.84E-05 5.00E-01 5.00E-01	IEV-COWD IW2TL160UFX IWN-MAN00 RHN-MAN05C
50	9.33E-09	15	LOSS OF CCS/SWS CCF OF GRAVITY OPERATOR FAILS	WITH RCS DRAINED INJECTION CHECK VALVES TO OPEN TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	6.02E-04 3.10E-05 5.00E-01	IEV-COWD IWX-CV-AO RHN-MAN05
51	8.58E-09	14	LOSS OF OFFSITE FAILURE TO BATTERY FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR DB1 UNAVAILABLE PMS OUTPUT LOGIC I/Os FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.20E-03 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 EDIMOD03 PMAMOD11 RN23MOD5S
52	8.31E-09	13	LOSS OF CCS/SWS CCF OF LOGIC MECHANICAL	WITH RCS DRAINED GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	6.02E-04 1.38E-05 1.00E+00	IEV-COWD CCX-PMA030X RN23MOD5S
53	7.80E-09	13	LOSS OF OFFSITE OFFSITE SOFTWARE CCF FAILURE OF	POWER INITIATING EVENT OCCURS AC POWER RECOVERED IN 2 HOURS OF ALL CARDS MANUAL DAS ACTUATION	1.71E-02 7.60E-01 1.20E-06 5.00E-01	IEV-LOSPND SUC-RZS CCX-SFTW REC-MANDAS
54	7.80E-09	13	LOSS OF CCS/SWS CCF OF INPUT OPERATOR FAILS MECHANICAL	WITH RCS DRAINED LOGIC GROUPS TO OPEN TWO IRWST MOVs FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	6.02E-04 2.59E-05 5.00E-01 1.00E+00	IEV-COWD CCX-INPUT-LOGICK IWN-MAN00 RN23MOD5S
55	7.79E-09	13	LOSS OF OFFSITE FAILURE TO CCF TO START FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS PMS OUTPUT LOGIC I/Os FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.00E-03 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 ZOX-PD-ES PMAMOD11 RN23MOD5S
56	7.22E-09	12	LOSS OF CCS/SWS CCF OF STRAINERS	WITH RCS DRAINED IN IRWST TANK	6.02E-04 1.20E-05	IEV-COWD IWX-FL-GP

Table 54B-11

CASE 5 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME			EVENT PROB	IDENTIFIER
57	6.62E-09	.11	LOSS OF CCS/SWS SOFTWARE CCF OF MECHANICAL	WITH RCS DRAINED OUTPUT LOGIC FAILURE CAUSES	INITIATING EVENT OCCURS I/Os MOV 023 TO FAIL-TO-OPEN	6.02E-04 1.10E-05 1.00E+00	IEV-CCWD CCX-PMA0D1-SW RN23MOD5S
58	5.19E-09	.08	LOSS OF CCS/SWS FAILURE OF CCF OF ORIFICES OPERATOR FAILS	WITH RCS FILLED MANUAL DAS	INITIATING EVENT OCCURS REACTOR TRIP	3.75E-03 1.00E-02 2.77E-04	IEV-CCWD MDAS CCX-ORY-SP LPM-MAN05
59	4.76E-09	.08	LOSS OF OFFSITE FAILURE TO BATTERY FAILURE UPON MECHANICAL	POWER INITIATING RECOVER AC POWER IN 1 HOUR DB1 DEMAND OF LOGIC FAILURE CAUSES	EVENT OCCURS UNAVAILABLE GROUP PROCESSING MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.20E-03 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 ED1MOD03 PMA0301ASA RN23MOD5S
60	4.76E-09	.08	LOSS OF OFFSITE FAILURE TO BATTERY FAILURE UPON MECHANICAL	POWER INITIATING RECOVER AC POWER IN 1 HOUR DB1 DEMAND OF LOGIC FAILURE CAUSES	EVENT OCCURS UNAVAILABLE GROUP PROCESSING MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.20E-03 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 ED1MOD03 PMA0301BSA RN23MOD5S
61	4.68E-09	.08	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE OF MECHANICAL	POWER INITIATING RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKERS TO PMS OUTPUT FAILURE CAUSES	EVENT OCCURS OPEN LOGIC I/Os MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 1.20E-03 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 ECX-CB-GO PMANOD11 RN23MOD5S
62	4.33E-09	.07	LOSS OF OFFSITE CCF TO START FAILURE UPON MECHANICAL	POWER INITIATING RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS DEMAND OF LOGIC FAILURE CAUSES	EVENT OCCURS GROUP PROCESSING MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.00E-03 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 Z0X-PD-ES PMA0301ASA RN23MOD5S
63	4.33E-09	.07	LOSS OF OFFSITE CCF TO START FAILURE UPON MECHANICAL	POWER INITIATING RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS DEMAND OF LOGIC FAILURE CAUSES	EVENT OCCURS GROUP PROCESSING MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.00E-03 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 Z0X-PD-ES PMA0301BSA RN23MOD5S
64	4.29E-09	.07	LOSS OF OFFSITE FAILURE TO BATTERY FAILURE OF OPERATOR FAILS	POWER INITIATING RECOVER AC POWER IN 1 HOUR DB1 PMS OUTPUT TO RECOGNIZE	EVENT OCCURS UNAVAILABLE LOGIC I/Os NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 2.20E-03 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 ED1MOD03 PMAMOD11 RHN-MAN05
65	4.15E-09	.07	LOSS OF CCS/SWS CCF OF LOGIC OPERATOR FAILS	WITH RCS DRAINED GROUP PROCESSING TO RECOGNIZE	INITIATING EVENT OCCURS NEED AND TO OPEN RNS MOV V023	6.02E-04 1.38E-05 5.00E-01	IEV-CCWD CCX-PMA030X RHN-MAN05
66	4.14E-09	.07	LOSS OF RNS WITH CCF OF THE POWER INTERFACE	WITH RCS FILLED FAILURE OF MANUAL DAS	INITIATING EVENT OCCURS ACTUATION	9.61E-04 5.00E-01 8.62E-06	IEV-RNSND REC-MANDAS CCX-EP-SAM
67	4.03E-09	.07	LCA/RNS-V024 CHECK VALVE IRWST DISCHARGE	OPENS 122A 124A LINE "B"	INITIATING EVENT OCCURS FAILS TO OPEN FAILS TO OPEN STRAINER	1.58E-05 1.00E+00 1.00E+00 2.40E-04	IEV-LOCA24ND IWACV122AO IWACV124AO IW-B-PLUG

Table 54B-11

CASE 5 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER
68	3.90E-09	.06	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS CCF OF INPUT LOGIC GROUPS OPERATOR FAILS TO OPEN TWO IRWST MOVs COND. PROB. OF RHN-MAN05 (OP. FAILS TO OPEN RNS MOV V023)		6.02E-04 2.59E-05 5.00E-01 5.00E-01	IEV-COWD CCX-INPUT-LOGICK IWN-MAN00 RHN-MAN05
69	3.90E-09	.06	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED FAILURE TO RECOVER AC POWER IN 1 HOUR CCF TO START OF ENGINE-DRIVEN FUEL PUMPS FAILURE OF PMS OUTPUT LOGIC I/Os OPERATOR FAILS TO RECOGNIZE NEED AND TO OPEN RNS MOV V023		4.44E-03 4.20E-01 2.00E-03 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 ZOK-PD-ES PMAMOD11 RHN-MAN05
70	3.85E-09	.06	LOSS OF RNS WITH RCS DRAINED INITIATING EVENT OCCURS ORIFICE FAILURE DUE TO PLUGGING OPERATOR FAILS TO OPEN TWO IRWST MOVs MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN		8.15E-05 9.48E-05 5.00E-01 1.00E+00	IEV-RNSD IW10R170SPK IWN-MAN00 RN23MOD5S
71	3.85E-09	.06	LOSS OF RNS WITH RCS DRAINED INITIATING EVENT OCCURS ORIFICE FAILURE DUE TO PLUGGING OPERATOR FAILS TO OPEN TWO IRWST MOVs MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN		8.15E-05 9.48E-05 5.00E-01 1.00E+00	IEV-RNSD IW20R160SPK IWN-MAN00 RN23MOD5S
72	3.77E-09	.06	LOSS OF RNS WITH RCS DRAINED INITIATING EVENT OCCURS CCF OF ACTUATION LOGIC GROUPS MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN		8.15E-05 4.63E-05 1.00E+00	IEV-RNSD CCX-PMAMOD1X RN23MOD5S
73	3.77E-09	.06	LOSS OF CL 4S WITH RCS FILLED INITIATING EVENT OCCURS FAILURE OF MANUAL DAS REACTOR TRIP HARDWARE CCF OF PRESSURE TRANSMITTERS OPERATOR FAILS TO RECOGNIZE THE NEED FOR RCS DEPRESSURIZATION		3.75E-03 1.00E-02 2.01E-04 5.00E-01	IEV-COWD MDAS CCX-XMTR155 LPM-MAN05
74	3.50E-09	.06	LOSS OF RNS WITH RCS DRAINED INITIATING EVENT OCCURS CCF OF ACTUATION LOGIC GROUPS OPERATOR FAILS TO OPEN TWO IRWST MOVs MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN		8.15E-05 8.58E-05 5.00E-01 1.00E+00	IEV-RNSD CCX-PMAMOD2X IWN-MAN00 RN23MOD5S
75	3.31E-09	.05	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS CCF OF SOFTWARE FOR ACTUATION LOGIC GROUPS OPERATOR FAILS TO OPEN TWO IRWST MOVs MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN		6.02E-04 1.10E-05 5.00E-01 1.00E+00	IEV-COWD CCX-PMAMOD2-SW IWN-MAN00 RN23MOD5S
76	3.31E-09	.05	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS CCF OF SOFTWARE FOR INPUT LOGIC GROUPS OPERATOR FAILS TO OPEN TWO IRWST MOVs MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN		6.02E-04 1.10E-05 5.00E-01 1.00E+00	IEV-COWD CCX-IN-LOGIC-SW IWN-MAN00 RN23MOD5S
77	3.31E-09	.05	LOSS OF CCS/SWS WITH RCS DRAINED INITIATING EVENT OCCURS SOFTWARE CCF OF OUTPUT LOGIC I/Os OPERATOR FAILS TO RECOGNIZE NEED AND TO OPEN RNS MOV V023		6.02E-04 1.10E-05 5.00E-01	IEV-COWD CCX-PMAMOD1-SW RHN-MAN05
78	3.10E-09	.05	LOSS OF RNS WITH RCS DRAINED INITIATING EVENT OCCURS DUE TO CCF OF THE SQUIB VALVES TO OPERATE		8.15E-05 3.80E-05	IEV-RNSD ADX-EV-SA
79	3.10E-09	.05	LOSS OF RNS WITH RCS DRAINED INITIATING EVENT OCCURS CCF OF IRWST INJ MOVs 121A, 121B, & RNS V023		8.15E-05 3.80E-05	IEV-RNSD IMX-MV-G01
80	3.09E-09	.05	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS WITH RCS DRAINED OFFSITE AC POWER RECOVERED IN 1 HOUR SOFTWARE CCF OF ALL CARDS		4.44E-03 5.80E-01 1.20E-06	IEV-LOSPD SUC-RIS CCX-SPTW

S/1

Table 54B-11

CASE 5 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER
81	2.85E-09	.05	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS FAILURE TO RECOVER AC POWER IN 1 HOUR COMMON CAUSE FAILURE 4KV BREAKER TO CLOSE FAILURE OF PMS OUTPUT LOGIC I/Os MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 7.30E-04 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 ECX-CB-GC PMAMOD11 RN23MOD5S
82	2.79E-09	.05	LOSS OF RNS WITH RCS DRAINED LEVEL TRANSMITTER FAILURE OPERATOR FAILS TO OPEN TWO IRWST MOVs MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	INITIATING EVENT OCCURS	8.15E-05 6.84E-05 5.00E-01 1.00E+00	IEV-RNSD IW2TL160UFX IWN-MAN00 RN23MOD5S
83	2.79E-09	.05	LOSS OF RNS WITH RCS DRAINED LEVEL TRANSMITTER FAILURE OPERATOR FAILS TO OPEN TWO IRWST MOVs MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	INITIATING EVENT OCCURS	8.15E-05 6.84E-05 5.00E-01 1.00E+00	IEV-RNSD IWITL170UFX IWN-MAN00 RN23MOD5S
84	2.71E-09	.04	LOCA/RNS-V024 OPENS CHECK VALVE 122A FAILS TO OPEN CHCK VALVE 124A FAILS TO OPEN IRWST DISCHARGE LINE "B" STRAINER PLUGGED	INITIATING EVENT OCCURS WITH RCS DRAINED	1.13E-05 1.00E+00 1.00E+00 2.40E-04	IEV-LOCA24D IWACV122AO IWACV124AO IWB-PLUG
85	2.60E-09	.04	LOSS OF CCS/SWS WITH RCS FILLED FAILURE OF CCF OF ORIFICES PRN-MAN01 OPERATOR FAILS TO ACTUATE ADS	INITIATING EVENT OCCURS REACTOR TRIP HARDWARE	3.75E-03 1.00E-02 2.77E-04 5.00E-01 5.00E-01	IEV-CCWND MDAS CCX-ORY-SP PRN-MAN01 ADN-MAN01
86	2.60E-09	.04	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS FAILURE TO RECOVER AC POWER IN 1 HOUR COMMON CAUSE FAILURE 4KV BREAKERS TO OPEN FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 1.20E-03 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 ECX-CB-GO PMA0301BSA RN23MOD5S
87	2.60E-09	.04	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS FAILURE TO RECOVER AC POWER IN 1 HOUR COMMON CAUSE FAILURE 4KV BREAKERS TO OPEN FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 1.20E-03 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 ECX-CB-GO PMA0301ASA RN23MOD5S
88	2.59E-09	.04	LOSS OF CCS/SWS WITH RCS DRAINED FAILURE OF MANUAL DAS CCF OF THE POWER INTERFACE OUTPUT BOARDS IN PMS	INITIATING EVENT OCCURS ACTUATION	6.02E-04 5.00E-01 8.62E-06	IEV-CCWD REC-MANDAS CCX-EP-SAM
89	2.53E-09	.04	LOSS OF RNS WITH RCS DRAINED CCF OF GRAVITY INJECTION CHECK MECHANICAL FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	INITIATING EVENT OCCURS VALVES TO OPEN	8.15E-05 3.10E-05 1.00E+00	IEV-RNSD IWX-CV-AO RN23MOD5S
90	2.46E-09	.04	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS FAILURE TO RECOVER AC POWER IN 2 HOURS SOFTWARE CCF OF ALL CARDS FAILURE OF MANUAL DAS	WITH RCS FILLED ACTUATION	1.71E-02 2.40E-01 1.20E-06 5.00E-01	IEV-LOSPND OTH-R2 CCX-SFTW REC-MANDAS
91	2.38E-09	.04	LOSS OF OFFSITE POWER INITIATING EVENT OCCURS FAILURE TO RECOVER AC POWER IN 1 HOUR BATTERY DB1 UNAVAILABLE FAILURE UPON DEMAND OF LOGIC GROUP PROCESSING OPERATOR FAILS TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 2.20E-03 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 EDIMOD03 PMA0301ASA RHN-MAN05

Table 54B-11

CASE 5 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS	WITH RCS DRAINED	EVENT PROB	IDENTIFIER
92	2.38E-09	.04	LOSS OF OFFSITE FAILURE TO BATTERY FAILURE UPON OPERATOR FAILS	POWER INITIATING RECOVER AC POWER IN 1 HOUR DB1 UNAVAILABLE DEMAND OF LOGIC GROUP PROCESSING TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	EVENT OCCURS WITH RCS DRAINED	4.44E-03 4.20E-01 2.20E-03 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 ED1MOD03 PMA0301BSA RHN-MAN05
93	2.34E-09	.04	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE OF PMS OUTPUT OPERATOR FAILS	POWER INITIATING RECOVER AC POWER IN 1 HOUR 4KV BREAKERS TO OPEN LOGIC I/Os NEED AND TO OPEN RNS MOV V023	EVENT OCCURS WITH RCS DRAINED	4.44E-03 4.20E-01 1.20E-03 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 ECX-CB-G0 PMAMOD11 RHN-MAN05
94	2.25E-09	.04	LOSS OF CCS/SWS SOFTWARE CCF FAILURE OF	WITH RCS FILLED OF ALL CARLS MANUAL DAS	INITIATING EVENT OCCURS ACTUATION	3.75E-03 1.20E-06 5.00E-01	IEV-CCWND CCK-SFTW REC-MANDAS
95	2.24E-09	.04	LOSS OF OFFSITE FAILURE TO SOFTWARE CCF	POWER INITIATING RECOVER AC POWER IN 1 HOUR OF ALL CARDS	EVENT OCCURS WITH RCS DRAINED	4.44E-03 4.20E-01 1.20E-06	IEV-LOSPD OTH-R1 CCK-SFTW
96	2.19E-09	.04	LOSS OF CCS/SWS CCF OF ORIFICES	WITH RCS DRAINED	INITIATING EVENT OCCURS	6.02E-04 3.63E-06	IEV-CCWD CCK-ORY-SPX
97	2.16E-09	.03	LOSS OF OFFSITE FAILURE TO CCF TO START FAILURE UPON OPERATOR FAILS	POWER INITIATING RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS DEMAND OF LOGIC GROUP PROCESSING TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	EVENT OCCURS WITH RCS DRAINED	4.44E-03 4.20E-01 2.00E-03 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 ZOX-PD-ES PMA0301BSA RHN-MAN05
98	2.16E-09	.03	LOSS OF OFFSITE FAILURE TO CCF TO START FAILURE UPON OPERATOR FAILS	POWER INITIATING RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS DEMAND OF LOGIC GROUP PROCESSING TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	EVENT OCCURS WITH RCS DRAINED	4.44E-03 4.20E-01 2.00E-03 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 ZOX-PD-ES PMA0301ASA RHN-MAN05
99	2.12E-09	.03	LOSS OF OFFSITE FAILURE TO BATTERY FAILURE OF INV. MECHANICAL	POWER INITIATING RECOVER AC POWER IN 1 HOUR DB1 STATIC SWITCH AND ASSOC. FAILURE CAUSES	EVENT OCCURS WITH RCS DRAINED BREAKERS MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.20E-03 5.16E-04 1.00E+00	IEV-LOSPD OTH-R1 ED1MOD03 IDAMOD05 RN23MOD05
100	2.10E-09	.03	LOSS OF RNS WITH COND. PROB. OF COMMON MODE OPERATOR FAILS	WITH RCS DRAINED REC-MANDAS FAILURE OF INPUT LOGIC GROUPS TO ACTUATE ADS BEFORE CORE	INITIATING EVENT OCCURS (FAILURE OF LOGIC GROUPS DAMAGE)	8.15E-05 5.00E-01 1.03E-04 5.00E-01	IEV-RNSD REC-MANDASC CCK-INPUT-LOGIC ADN-MAN01
101	1.93E-09	.03	LOSS OF CCS/SWS FAILURE OF COMMON MODE OPERATOR FAILS	WITH RCS FILLED MANUAL DAS FAILURE OF INPUT LOGIC GROUPS TO RECOGNIZE THE NEED FOR RCS	INITIATING EVENT OCCURS REACTOR TRIP HARDWARE DEPRESSURIZATION	3.75E-03 1.00E-02 1.03E-04 5.00E-01	IEV-CCWND MDAS CCK-INPUT-LOGIC LPM-MAN05
102	1.93E-09	.03	LOSS OF RNS WITH ORIFICE FAILURE OPERATOR FAILS COND. PROB. OF	WITH RCS DRAINED DUE TO PLUGGING TO OPEN TWO IRWST MOVs RHN-MAN05 (OP.)	INITIATING EVENT OCCURS FAILS TO OPEN RMS MOV V023	8.15E-05 9.46E-05 5.00E-01 5.00E-01	IEV-RNSD IW10R170SPX INN-MAN00 RHN-MAN05C

Table 54B-11

CASE 5 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS	EVENT PROB	IDENTIFIER
103	1.93E-09	.03	LOSS OF RNS WITH RCS DRAINED COND. PROB. OF REC-MANDAS ORIFICE FAILURE DUE TO PLUGGING OPERATOR FAILS TO ACTUATE ADS	(FAILURE OF MANUAL DAS ACT. BEFORE CORE DAMAGE)	8.15E-05 5.00E-01 9.46E-05 5.00E-01	IEV-RNSD REC-MANDASC IW10R170SPX ADN-MAN01
104	1.93E-09	.03	LOSS OF RNS WITH RCS DRAINED COND. PROB. OF REC-MANDAS ORIFICE FAILURE DUE TO PLUGGING OPERATOR FAILS TO ACTUATE ADS	(FAILURE OF MANUAL DAS ACT. BEFORE CORE DAMAGE)	8.15E-05 5.00E-01 9.46E-05 5.00E-01	IEV-RNSD REC-MANDASC IW20R160SPX ADN-MAN01
105	1.93E-09	.03	LOSS OF RNS WITH RCS DRAINED ORIFICE FAILURE DUE TO PLUGGING OPERATOR FAILS TO OPEN TWO IRWST MOVES COND. PROB. OF RHN-MAN05 (OP.)	(INITIATING EVENT OCCURS IRWST MOVES FAILS TO OPEN RNS MOV V023)	8.15E-05 9.46E-05 5.00E-01 5.00E-01	IEV-RNSD IW20R160SPX IWN-MAN00 RHN-MAN05C
106	1.92E-09	.03	LOSS OF OFFSITE POWER INITIATING FAILURE TO RECOVER AC POWER IN 1 HOUR CCF TO START OF ENGINE-DRIVEN FUEL PUMPS FAILURE OF INV. STATIC SWITCH AND ASSOC. MECHANICAL FAILURE CAUSES	EVENT OCCURS WITH RCS DRAINED BREAKERS FAIL-TO-OPEN	4.44E-03 4.20E-01 2.00E-03 5.16E-04 1.00E+00	IEV-LOSPD OTH-R1 ZOK-PD-ES IDAMOD05 RN23MOD5S
107	1.92E-09	.03	LOSS OF OFFSITE POWER INITIATING FAILURE TO RECOVER AC POWER IN 1 HOUR PUMP MP 01B SEGMENT HARDWARE FAILURE OR DIVERTED FLOW D/G FAILS TO START & RUN OR BKR 102 FAILS TO CLOSE FAILURE OF PMS OUTPUT LOGIC I/Os MECHANICAL FAILURE CAUSES	EVENT OCCURS WITH RCS DRAINED DIVERTED FLOW MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.44E-02 2.02E-02 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 SWBMOD02 Z01MOD01 PMAMOD11 RN23MOD5S
108	1.89E-09	.03	LOSS OF RNS WITH RCS DRAINED CCF OF ACTUATION LOGIC GROUPS OPERATOR FAILS TO RECOGNIZE	INITIATING EVENT OCCURS NEED AND TO OPEN RNS MOV V023	8.15E-05 4.63E-05 5.00E-01	IEV-RNSD CCX-PMAMOD1X RHN-MAN05
109	1.88E-09	.03	LOSS OF CCS/SWS WITH RCS FILLED FAILURE OF MANUAL DAS CCF OF PRESSURE TRANSMITTERS PRN-MAN01 OPERATOR FAILS TO ACTUATE ADS	INITIATING EVENT OCCURS REACTOR TRIP HARDWARE	3.75E-03 1.00E-02 2.01E-04 5.00E-01 5.00E-01	IEV-CCWND MDAS CCX-XMTR195 PRN-MAN01 ADN-MAN01
110	1.84E-09	.03	LOSS OF CCS/SWS WITH RCS DRAINED CHECK VALVE 122A CHECK VALVE 124A CHECK VALVE 122B CHECK VALVE 124B MECHANICAL FAILURE CAUSES	INITIATING EVENT OCCURS FAILS TO OPEN FAILS TO OPEN FAILS TO OPEN FAILS TO OPEN MOV 023 TO FAIL-TO-OPEN	6.02E-04 1.00E+00 1.00E+00 1.75E-03 1.75E-03 1.00E+00	IEV-CCWD IWACV122AO IWACV124AO IWBCV122AO IWBCV124AO RN23MOD5S
111	1.81E-09	.03	LOCA/RNS PIPE RUPTURE WITH RCS FILLED INIT. OPERATOR FAILS TO ISOLATE RNS PIPE RUPTURE CHECK VALVE 122A FAILS TO OPEN CHECK VALVE 124A FAILS TO OPEN IRWST DISCHARGE LINE "B" STRAINER PLUGGED	EVENT OCCURS FAILS TO OPEN FAILS TO OPEN FAILS TO OPEN PLUGGED	1.51E-05 5.00E-01 1.00E+00 1.00E+00 2.40E-04	IEV-LOCAPRND RHN-MAN04 IWACV122AO IWACV124AO IWS-PLUG
112	1.77E-09	.03	LOSS OF CCS/SWS WITH RCS DRAINED CCF OF THE POWER INTERFACE OUTPUT BOARDS IN PMS MECHANICAL FAILURE CAUSES	INITIATING EVENT OCCURS BOARDS IN PMS MOV 023 TO FAIL-TO-OPEN	6.02E-04 2.94E-06 1.00E+00	IEV-CCWD CCX-EP-SAMX RN23MOD5S
113	1.75E-09	.03	LOSS OF RNS WITH RCS DRAINED CCF OF ACTUATION LOGIC GROUPS OPERATOR FAILS TO OPEN TWO IRWST MOVES COND. PROB. OF RHN-MAN05 (OP.)	INITIATING EVENT OCCURS IRWST MOVES FAILS TO OPEN RNS MOV V023)	8.15E-05 8.58E-05 5.00E-01 5.00E-01	IEV-RNSD CCX-PMAMOD2X IWN-MAN00 RHN-MAN05C

Table 54B-11

CASE 5 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS	WITH RCS DRAINED	EVENT PROB.	IDENTIFIER
114	1.71E-09	.03	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR STANDBY DG TO RUN LOGIC I/Os MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 4.40E-04 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 Z0X-DG-DR PMAMOD11 RN23MOD55
115	1.66E-09	.03	LOSS OF CCS/SWS CCF OF SOFTWARE OPERATOR FAILS COND. PROB. OF	WITH RCS DRAINED FOR INPUT LOGIC GROUPS TO OPEN TWO IRWST MOVs RHN-MAN05 (OP)	INITIATING EVENT OCCURS FAILS TO OPEN RNS MOV V0231	6.02E-04 1.10E-05 5.00E-01 5.00E-01	IEV-CCWD CCX-IN-LOGIC-SW IWN-MAN00 RHN-MAN05C
116	1.66E-09	.03	LOSS OF CCS/SWS CCF OF SOFTWARE OPERATOR FAILS COND. PROB. OF	WITH RCS DRAINED FOR ACTUATION LOGIC GROUPS TO OPEN TWO IRWST MOVs RHN-MAN05 (OP)	INITIATING EVENT OCCURS FAILS TO OPEN RNS MOV V0231	6.02E-04 1.10E-05 5.00E-01 5.00E-01	IEV-CCWD CCX-PMAMOD2-SW IWN-MAN00 RHN-MAN05C
117	1.59E-09	.03	LOSS OF OFFSITE FAILURE TO D/G FAILS TO D/G FAILS TO FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR START & RUN OR ECR 102 FAILS TO CLOSE START & RUN OR ECR 202 FAILS TO CLOSE PMS OUTPUT LOGIC I/Os FAILURE CAUSES MOV 023 TO FAIL TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 2.02E-02 2.02E-02 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 Z01MOD01 Z02MOD01 PMAMOD11 RN23MOD55
118	1.58E-09	.03	LOSS OF CCS/SWS CCF OF PRESSURE	WITH RCS DRAINED TRANSMITTERS	INITIATING EVENT OCCURS	6.02E-04 2.63E-06	IEV-CCWD CCX-XMTRX
119	1.58E-09	.03	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKER TO CLOSE DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 7.30E-04 1.16E-03 1.07E+00	IEV-LOSPD OTH-R1 ECX-CB-GC PMA0301BSA RN23MOD57
120	1.58E-09	.03	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKER TO CLOSE DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED	4.44E-03 4.20E-01 7.30E-04 1.16E-03 1.07E+00	IEV-1/APD OTH-1 ECX-CB-GC PMA0301BSA RN23MOD55
121	1.42E-09	.02	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE OF OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKER TO CLOSE PMS OUTPUT LOGIC I/Os TO RECOGNIZE N. 4D TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 7.30E-04 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 ECX-CB-GC PMAMOD11 RHN-MAN05
122	1.39E-09	.02	LOSS OF RNS WITH RCS DRAINED LEVEL OPERATOR FAILS COND. PROB. OF	INITIATING EVENT OCCURS FAILURE TO OPEN TWO IRWST MOVs FAILS TO OPEN RNS MOV V0231	INITIATING EVENT OCCURS	8.15E-05 6.84E-05 5.00E-01 5.00E-01	IEV-RNSD IW2TL160UFX IWN-MAN00 RHN-MAN05C
123	1.39E-09	.02	LOSS OF RNS WITH RCS DRAINED LEVEL OPERATOR FAILS COND. PROB. OF	INITIATING EVENT OCCURS FAILURE TO OPEN TWO IRWST MOVs FAILS TO OPEN RNS MOV V0231	INITIATING EVENT OCCURS	8.15E-05 6.84E-05 5.00E-01 5.00E-01	IEV-RNSD IW1TL170UFX IWN-MAN00 RHN-MAN05C
124	1.39E-09	.02	LOSS OF RNS WITH RCS DRAINED COND. PROB. OF LEVEL OPERATOR FAILS	INITIATING EVENT OCCURS (FAILURE OF REC-MANDAS TRANSMITTER TO ACTUATE ADS BEFORE CORE FAILURE DAMAGE	INITIATING EVENT OCCURS MANUAL DAS ACT.	8.15E-05 5.00E-01 6.84E-05 5.00E-01	IEV-RNSD REC-MANDASC IW2TL160UFX ADN-MAN01

Table 54B-11

CASE 5 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS	EVENT PROB	IDENTIFIER
125	1.39E-09	.02	LOSS OF RNS WITH RCS DRAINED COND. PROB. OF REC-MANDAS LEVEL TRANSITTER OPERATOR FAILS TO ACTUATE ADS	INITIATING EVENT OCCURS (FAILURE OF MANUAL DAS ACT. FAILURE BEFORE CORE DAMAGE)	8.15E-05 5.00E-01 6.84E-05 5.00E-01	IEV-RNSND REC-MANDASC TWITL170UFX ADN-MAN01
126	1.13E-09	.02	LOSS OF RNS WITH RCS FILLED FAILURE OF CCF OF ORIFICES OPERATOR FAILS TO RECOGNIZE THE NEED FOR RCS	INITIATING EVENT OCCURS MANUAL DAS REACTOR TRIP HARDWARE	9.61E-04 1.00E-02 2.77E-04 5.00E-01	IEV-RNSND MDAS CCX-GRY-SF LPM-MAN05
127	1.30E-09	.02	LOSS OF OFFSITE FAILURE TO BATTERY DB1 LOSS OF DIST. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR UNAVAILABLE PANEL OR BREAKER A07 SPURIOUSLY FAILURES CAUSES MOV 023 TO	4.44E-03 4.20E-01 2.20E-03 3.17E-04 1.00E+00	IEV-LOSPD OTH-R1 ED1MOD03 IDAMOD04 RN23MOD5S
128	1.30E-09	.02	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE UPON OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR 4KV BREAKERS TO OPEN DEMAND OF LOGIC GROUP PROCESSING TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 1.20E-03 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 ECX-CB-GO PMA0301RSA RHN-MAN05
129	1.30E-09	.02	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE UPON OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR 4KV BREAKERS TO OPEN DEMAND OF LOGIC GROUP PROCESSING TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 1.20E-03 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 ECX-CB-GO PMA0301ASA RHN-MAN05
130	1.26E-09	.02	LOSS OF RNS WITH RCS DRAINED CCF OF GRAVITY INJECTION CHECK OPERATOR FAILS TO RECOGNIZE	INITIATING EVENT OCCURS VALVES TO OPEN NEED AND TO OPEN RNS MOV V023	8.15E-05 3.10E-05 5.00E-01	IEV-RNSD INX-CV-AO RHN-MAN05
131	1.24E-09	.02	LOSS OF OFFSITE FAILURE TO FIXED FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR COMPONENTS FAILURE PMS OUTPUT LOGIC I/Os FAILURE CAUSES MOV 023 TO	4.44E-03 4.20E-01 3.17E-04 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 ED1MOD113 PMAMOD11 RN23MOD5S
132	1.24E-09	.02	LOSS OF OFFSITE FAILURE TO FIXED FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR COMPONENTS FAILURE PMS OUTPUT LOGIC I/Os FAILURE CAUSES MOV 023 TO	4.44E-03 4.20E-01 3.17E-04 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 ED1MOD11 PMAMOD11 RN23MOD5S
133	1.23E-09	.02	LOSS OF OFFSITE FAILURE TO BATTERY BUS UNAVAILABLE MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR DB1 UNAVAILABLE DUE TO TEST OR CORRECTIVE FAILURE CAUSES MOV 023 TO	4.44E-03 4.20E-01 2.20E-03 3.00E-04 1.00E+00	IEV-LOSPD OTH-R1 ED1MOD03 IDABSDS1TH RN23MOD5S
134	1.20E-09	.02	LOSS OF OFFSITE FAILURE TO PUMP 01B FAILS & D/G FAILS TO FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR ST CK V007B & C B FTC & RE FTC & CB ECS221 SPO START & RUN OR BKR 102 FAILS TO CLOSE PMS OUTPUT LOGIC I/Os FAILURE CAUSES MOV 023 TO	4.44E-03 4.20E-01 1.53E-02 2.02E-02 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 RNBMOD07S Z01MOD01 PMAMOD11 RN23MOD5S

Table 54B-11

CASE 5 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT OCCURS		EVENT PROB.	IDENTIFIER
135	1.18E-09	.02	LOSS OF OFFSITE FAILURE TO CCF TO START LOSS OF DIST MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS PANEL OR BREAKER A07 SPURIOUSLY FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED OPENS FAIL-TO-OPEN	4.44E-03 4.20E-01 2.00E-03 3.17E-04 1.00E+00	IEV-LOSPD OTH-R1 ZOX-PD-ES IDAMOD04 RN23MOD5S
136	1.17E-09	.02	LOSS OF OFFSITE FAILURE TO PUMP MP 01B BREAKER 100 FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR FAILS TO OPEN PMS OUTPUT LOGIC I/Os FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED DIVERTED FLOW [#3.5] FAIL-TO-OPEN	4.44E-03 4.20E-01 2.64E-02 1.23E-02 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 SWBMOD02 EC1CB100V0 PMAMOD11 RN23MOD5S
137	1.16E-09	.02	LOCA/RNS-V024 CCF OF ORIFICES COND. PROB. OF OPERATOR FAILS	OPENS INITIATING EVENT OCCURS REC-MANDAS (FAILURE OF TO RECOGNIZE THE NEED FOR RCS	WITH RCS FILLED MANUAL DAS ACT. DEPRESSURIZATION	1.68E-05 2.77E-04 5.00E-01 5.00E-01	IEV-LOCA24ND CCX-DRY-SP REC-MANDASC LPM-MAN05
138	1.16E-09	.02	LOCA/RNS-V024 CCF OF ORIFICES COND. PROB. OF OPERATOR FAILS	OPENS INITIATING EVENT OCCURS REC-MANDAS (FAILURE OF TO ACTUATE ADS BEFORE CORE	WITH RCS FILLED MANUAL DAS ACT. DAMAGE	1.68E-05 2.77E-04 5.00E-01 5.00E-01	IEV-LOCA24ND CCX-DRY-SP REC-MANDASC ADN-MAN01
139	1.15E-09	.02	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE OF INV. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR 4KV BREAKERS TO STATIC SWITCH AND ASSOC. FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED OPEN BREAKERS FAIL-TO-OPEN	4.44E-03 4.20E-01 1.20E-03 5.16E-04 1.00E+00	IEV-LOSPD OTH-R1 ECX-CB-G0 IDAMOD05 RN23MOD5S
140	1.12E-09	.02	LOSS OF RNS WITH CCF OF LOGIC MECHANICAL	RCS DRAINED GROUP PROCESSING FAILURE CAUSES MOV 023 TO	INITIATING EVENT OCCURS FAIL-TO-OPEN	8.15E-05 1.38E-05 1.00E+00	IEV-RNSD CCX-PMA030X RN23MOD5S
141	1.12E-09	.02	LOSS OF OFFSITE FAILURE TO CCF T' START BUS UNAVAILABLE MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS DUE TO TEST OR CORRECTIVE FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED MAINTENANCE FAIL-TO-OPEN	4.44E-03 4.20E-01 2.00E-03 3.00E-04 1.00E+00	IEV-LOSPD OTH-R1 ZOX-PD-ES IDABSDS1TM RN23MOD5S
142	1.09E-09	.02	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR STANDBY DG TO PMS OUTPUT LOGIC I/Os FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED START FAIL-TO-OPEN	4.44E-03 4.20E-01 2.80E-04 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 ZOX-DG-DS PMAMOD11 RN23MOD5S
143	1.07E-09	.02	LOSS OF OFFSITE FAILURE TO PUMP MP 01B D/G FAILS TO FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR START & RUN OR BKR 102 FAILS TO CLOSE DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED DIVERTED FLOW FAIL-TO-OPEN	4.44E-03 4.20E-01 2.44E-02 2.02E-02 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 SWBMOD02 Z01MOD01 PMA0301BSA RN23MOD5S
144	1.07E-09	.02	LOSS OF OFFSITE FAILURE TO PUMP MP 01B D/G FAILS TO FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR START & RUN OR BKR 102 FAILS TO CLOSE DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED DIVERTED FLOW FAIL-TO-OPEN	4.44E-03 4.20E-01 2.44E-02 2.02E-02 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 SWBMOD02 Z01MOD01 PMA0301ASA RN23MOD5S

Table 54B-11

CASE 5 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	INITIATING EVENT	EVENT PROB.	IDENTIFIER
145	1.06E-09	.02	LOSS OF CCS/SWS FAILURE OF PMS OUTPUT UNAVAILABILITY OF BUS ECS ES 1 MECHANICAL FAILURE CAUSES	WITH RCS DRAINED INITIATING EVENT OCCURS LOGIC I/Os DUE TO UNSCHEDUL MAINTENANCE MOV 023 TO FAIL-TO-OPEN	6.02E-04 6.53E-04 2.70E-03 1.00E+00	IEV-COWD PMAMOD11X EC1BS001TM RN23MOD5S
146	1.06E-09	.02	LOSS OF CCS/SWS FAILURE OF PMS OUTPUT BUS UNAVAILABLE MECHANICAL FAILURE CAUSES	WITH RCS DRAINED INITIATING EVENT OCCURS LOGIC I/Os DUE TO UNSCHEDULED MAINTENANCE MOV 023 TO FAIL-TO-OPEN	6.02E-04 6.53E-04 2.70E-03 1.00E+00	IEV-COWD PMAMOD11X EC1RS012TM RN23MOD5S
147	1.06E-09	.02	LOSS OF CCS/SWS FAILURE OF PMS OUTPUT BUS UNAVAILABLE MECHANICAL FAILURE CAUSES	WITH RCS DRAINED INITIATING EVENT OCCURS LOGIC I/Os DUE TO UNSCHEDULED MAINTENANCE MOV 023 TO FAIL-TO-OPEN	6.02E-04 6.53E-04 2.70E-03 1.00E+00	IEV-COWD PMAMOD11X EC1BS121TM RN23MOD5S
148	1.06E-09	.02	LOSS OF OFFSITE POWER FAILURE TO RECOVER AC POWER IN 1 HOUR BATTERY DB1 FAILURE OF INV. OPERATOR FAILS	INITIATING EVENT OCCURS POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR UNAVAILABLE STATIC SWITCH AND ASSOC BREAKERS TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 2.20E-03 5.15E-04 5.00E-01	IEV-LOSPD OTH-R1 ED1MOD03 IDAMOD05 RHN-MAN05
149	1.06E-09	.02	LOSS OF RNS WITH RCS DRAINED CCF OF INPUT LOGIC GROUPS OPERATOR FAILS MECHANICAL FAILURE CAUSES	INITIATING EVENT OCCURS LOGIC GROUPS TO OPEN TWO IRWST MOVs MOV 023 TO FAIL-TO-OPEN	8.15E-05 2.59E-05 5.00E-01 1.00E+00	IEV-RNSD CCX-INPUT-LOGICK IWN-MAN00 RN23MOD5S
150	1.05E-09	.02	LOCA/RNS PIPE COND. PROB. OF COND. PROB. OF ORIFICES OPERATOR FAILS	RUPTURE WITH RCS FILLED INIT. REC-MANDAS (FAILURE OF TO RECOGNIZE THE NEED FOR RCS	1.51E-05 5.00E-01 2.77E-04 5.00E-01	IEV-LOCAPRD REC-MANDASC CCX-ORY-SP LPM-MAN05
151	9.86E-10	.02	LOSS OF OFFSITE POWER FAILURE TO RECOVER AC POWER IN 1 HOUR BATTERY DB1 CHECK VALVE 122A CHECK VALVE 124A IRWST DISCHARGE LINE "B"	INITIATING EVENT OCCURS POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR UNAVAILABLE FAILS TO OPEN FAILS TO OPEN STRAINER PLUGGED	4.44E-03 4.20E-01 2.20E-03 1.00E+00 1.00E+00 2.40E-04	IEV-LOSPD OTH-R1 ED1MOD03 IWACV122AO IWACV124AO IWB-PLUG
152	9.78E-10	.02	LOSS OF RNS WITH RCS DRAINED CCF OF STRAINERS IN IRWST TANK	INITIATING EVENT OCCURS POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR	8.15E-05 1.20E-05	IEV-RNSD INX-FL-GP
153	9.68E-10	.02	LOSS OF OFFSITE POWER FAILURE TO RECOVER AC POWER IN 1 HOUR D/G FAILS TO START & RUN OR BREAKER 200 FAILS TO CLOSE FAILURE OF PMS OUTPUT MECHANICAL FAILURE CAUSES	INITIATING EVENT OCCURS POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR START & RUN OR BKR 102 FAILS TO CLOSE FAILS TO OPEN LOGIC I/Os MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.02E-02 1.23E-02 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 Z01MOD01 EC2CB200V0 PMAMOD11 RN23MOD5S
154	9.68E-10	.02	LOSS OF OFFSITE POWER FAILURE TO RECOVER AC POWER IN 1 HOUR BREAKER 100 FAILS TO OPEN D/G FAILS TO START & RUN OR FAILURE OF PMS OUTPUT MECHANICAL FAILURE CAUSES	INITIATING EVENT OCCURS POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILS TO OPEN START & RUN OR BKR 202 FAILS TO CLOSE LOGIC I/Os MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 1.23E-02 2.02E-02 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 EC1CB100V0 Z02MOD01 PMAMOD11 RN23MOD5S
155	9.66E-10	.02	LOSS OF RNS WITH RCS FILLED FAILURE OF MANUAL DAS CCF OF PRESSURE TRANSMITTERS OPERATOR FAILS	INITIATING EVENT OCCURS POWER INITIATING EVENT OCCURS REACTOR TRIP HARDWARE TO RECOGNIZE THE NEED FOR RCS DEPRESSURIZATION	9.61E-04 1.00E-02 2.01E-04 5.00E-01	IEV-RNSND MDAS CCX-XMTR195 LPM-MAN05

Table 54B-11

CASE 5 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB.	IDENTIFIER	
156	9.62E-10	.02	LOSS OF OFFSITE FAILURE TO CCP TO START FAILURE OF INV. OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR OF ENGINE-DRIVEN FUEL PUMPS STATIC SWITCH AND ASSOC. TO RECOGNIZE	WITH RCS DRAINED BREAKERS NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 2.00E-03 5.16E-04 5.00E-01	IEV-LOSPD OTH-R1 ZOK-PD-ES IDAMOD05 RHN-MAN05
157	9.60E-10	.02	LOSS OF OFFSITE FAILURE TO PUMP MP 01B D/G FAILS TO FAILURE OF OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR START & RUN OR PMS OUTPUT TO RECOGNIZE	WITH RCS DRAINED DIVERTED FLOW BKR 102 FAILS TO CLOSE LOGIC I/Os NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 2.44E-02 2.02E-02 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 SWBMOD02 Z01MOD01 PMAMOD11 RHN-MAN05
158	9.52E-10	.02	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR STANDBY DG TO DEMAND OF LOGIC FAILURE CAUSES	WITH RCS DRAINED RUN GROUP PROCESSING MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 4.40E-04 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 ZOK-DG-DR PMA0301ASA RN23MOD5S
159	9.52E-10	.02	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR STANDBY DG TO DEMAND OF LOGIC FAILURE CAUSES	WITH RCS DRAINED RUN GROUP PROCESSING MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 4.40E-04 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 ZOK-DG-DR PMA0301BSA RN23MOD5S
160	9.43E-10	.02	LOSS OF CCS/SWS PMAMOD21X OPERATOR FAILS UNAVAILABILITY MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS TO OPEN TWO IRWST MOVs OF BUS ECS ES 1 DUE TO UNSCHEDUL MAINTENANCE FAILURE CAUSES	FAIL-TO-OPEN	6.02E-04 1.16E-03 5.00E-01 2.70E-03 1.00E+00	IEV-COWD PMAMOD21X IWN-MAN00 EC1BS001TM RN23MOD5S
161	9.43E-10	.02	LOSS OF CCS/SWS PMAMOD21X OPERATOR FAILS BUS UNAVAILABLE MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS TO OPEN TWO IRWST MOVs DUE TO UNSCHEDULED MAINTENANCE FAILURE CAUSES	FAIL-TO-OPEN	6.02E-04 1.16E-03 5.00E-01 2.70E-03 1.00E+00	IEV-COWD PMAMOD21X IWN-MAN00 EC1BS121TM RN23MOD5S
162	9.43E-10	.02	LOSS OF CCS/SWS PMAMOD21X OPERATOR FAILS BUS UNAVAILABLE MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS TO OPEN TWO IRWST MOVs DUE TO UNSCHEDULED MAINTENANCE FAILURE CAUSES	FAIL-TO-OPEN	6.02E-04 1.16E-03 5.00E-01 2.70E-03 1.00E+00	IEV-COWD PMAMOD21X IWN-MAN00 EC1BS012TM RN23MOD5S
163	9.22E-10	.01	LOSS OF CCS/SWS CHECK VALVE 122A CHECK VALVE 124A CHECK VALVE 122B CHECK VALVE 124B OPERATOR FAILS	WITH RCS DRAINED INITIATING EVENT OCCURS FAILS TO OPEN FAILS TO OPEN FAILS TO OPEN FAILS TO OPEN NEED AND TO OPEN RNS MOV V023		6.02E-04 1.00E+00 1.00E+00 1.75E-03 1.75E-03 5.00E-01	IEV-COWD IWACV122AO IWACV124AO IWBCV122AO IWBCV124AO RHN-MAN05
164	8.97E-10	.01	LOSS OF RNS WITH SOFTWARE CCF OF MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS OUTPUT LOGIC I/Os FAILURE CAUSES	FAIL-TO-OPEN	8.15E-05 1.10E-05 1.00E+00	IEV-RNSD CCX-PMAMOD1-SW RN23MOD5S
165	8.85E-10	.01	LOSS OF CCS/SWS CCF OF THE POWER INTERFACE OUTPUT OPERATOR FAILS	WITH RCS DRAINED INITIATING EVENT OCCURS INTERFAC OUTPUT BOARDS IN PMS TO RECOGNIZE NEED AND TO OPEN RNS MOV V023		6.02E-04 2.94E-06 5.00E-01	IEV-COWD CCX-EP-SAMX RHN-MAN05

Table 54B-11

CASE 5 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER
166	8.83E-10	.01	LOSS OF OFFSITE FAILURE TO D/G FAILS TO D/G FAILS TO FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR START & RUN OR BKR 102 FAILS TO CLOSE START & RUN OR BKR 202 FAILS TO CLOSE DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.02E-02 2.02E-02 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 Z01MOD01 Z02MOD01 PMA0301BSA RN23MOD5S
167	8.83E-10	.01	LOSS OF OFFSITE FAILURE TO D/G FAILS TO D/G FAILS TO FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR START & RUN OR BKR 102 FAILS TO CLOSE START & RUN OR BKR 202 FAILS TO CLOSE DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.02E-02 2.02E-02 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 Z01MOD01 Z02MOD01 PMA0301ASA RN23MOD5S
168	8.57E-10	.01	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE OF OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE STANDBY DG TO RUN PMS OUTPUT LOGIC I/Os TO RECOGNIZE NEED AND TO OPEN RNC MOV V023	4.44E-03 4.20E-01 4.40E-04 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 Z0X-DG-DR PMAMOD11 RHN-MAN05
169	8.44E-10	.01	LOCA/RNS-V024 CCF OF PRESSURE COND. PROB. OF OPERATOR FAILS	OPENS INITIATING EVENT OCCURS TRANSMITTERS REC-MANDAS (FAILURE OF TO RECOGNIZE THE NEED FOR RCS	1.68E-05 2.01E-04 5.00E-01 5.00E-01	IEV-LOCA24ND CCX-XMTR195 REC-MANDASC LPM-MAN05
170	8.44E-10	.01	LOCA/RNS-V024 CCF OF PRESSURE COND. PROB. OF OPERATOR FAILS	OPENS INITIATING EVENT OCCURS TRANSMITTERS REC-MANDAS (FAILURE OF TO ACTIVATE ADS BEFORE CORE	1.68E-05 2.01E-04 5.00E-01 5.00E-01	IEV-LOCA24ND CCX-XMTR195 REC-MANDASC ADN-MAN01
171	8.39E-10	.01	LOSS OF CCS/SWS FAILURE OF INV. BUS UNAVAILABLE MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS STATIC SWITCH AND ASSOC. DUE TO UNSCHEDULED FAILURE CAUSES MOV 023 TO	6.02E-04 5.16E-04 2.70E-03 1.00E+00	IEV-CCWD IDAMOD05 EC1BS012TM RN23MOD5S
172	8.39E-10	.01	LOSS OF CCS/SWS FAILURE OF INV. UNAVAILABILITY MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS STATIC SWITCH AND ASSOC. DUE TO UNSCHEDUL FAILURE CAUSES MOV 023 TO	6.02E-04 5.16E-04 2.70E-03 1.00E+00	IEV-CCWD IDAMOD05 EC1BS001TM RN23MOD5S
173	8.39E-10	.01	LOSS OF CCS/SWS FAILURE OF INV. BUS UNAVAILABLE MECHANICAL	WITH RCS DRAINED INITIATING EVENT OCCURS STATIC SWITCH AND ASSOC. DUE TO UNSCHEDULED FAILURE CAUSES MOV 023 TO	6.02E-04 5.16E-04 2.70E-03 1.00E+00	IEV-CCWD IDAMOD05 EC1BS121TM RN23MOD5S
174	8.19E-10	.01	LOSS OF OFFSITE FAILURE TO PUMP SUBLOOP B D/G FAILS TO FAILURE OF MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR HARDWARE FAILURE OR DIVERTED FLOW START & RUN OR BKR 102 FAILS TO CLOSE PMS OUTPUT LOGIC I/Os FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 1.04E-02 2.02E-02 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 CCBMOD01S Z01MOD01 PMAMOD11 RN23MOD5S
175	7.95E-10	.01	LOSS OF OFFSITE FAILURE TO D/G FAILS TO D/G FAILS TO FAILURE OF OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR START & RUN OR BKR 102 FAILS TO CLOSE START & RUN OR BKR 202 FAILS TO CLOSE PMS OUTPUT LOGIC I/Os TO RECOGNIZE NEED AND TO OPEN RNC MOV V023	4.44E-03 4.20E-01 2.02E-02 2.02E-02 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 Z01MOD01 Z02MOD01 PMAMOD11 RHN-MAN05

621

Table 54B-11

CASE 5 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME		EVENT PROB	IDENTIFIER
176	7.90E-10	.01	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE UPON OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKER TO CLOSE DEMAND OF LOGIC GROUP PROCESSING NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED 4.44E-03 4.20E-01 7.30E-04 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 ECX-CB-GC PMA0301BSA RHN-MAN05
177	7.90E-10	.01	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE UPON OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKER TO CLOSE DEMAND OF LOGIC GROUP PROCESSING NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED 4.44E-03 4.20E-01 7.30E-04 1.16E-03 5.00E-01	IEV-LOSPD OTH-R1 ECX-CB-GC PMA0301ASA RHN-MAN05
178	7.59E-10	.01	LOCA/RNS PIPE COND. PROB. OF CCF OF PRESSURE OPERATOR FAILS	RUPTURE WITH RCS FILLED INIT. REC-MANDAS (FAILURE OF TRANSMITTERS TO RECOGNIZE THE NEED FOR RCS)	EVENT OCCURS MANUAL DAS ACT. DEPRESSURIZATION	1.51E-05 5.00E-01 2.01E-04 5.00E-01
179	7.33E-10	.01	LOSS OF OFFSITE FAILURE TO PUMP 01B FAILS & BREAKER 100 MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR ST CK V007B & C B PTC & RE PTC & CB ECS221 SPO FAILS TO OPEN [#3,5] PMS OUTPUT FAILURE CAUSES	WITH RCS DRAINED 4.44E-03 4.20E-01 1.53E-02 1.23E-02 2.09E-03 1.00E+00	IEV-LOSPD OTH-R1 RNBMOD07S EC1CB100V0 PMAMOD11 RN23MOD5S
180	7.22E-10	.01	LOSS OF CCS/SWS SOFTWARE CCF	WITH RCS DRAINED INITIATING EVENT OCCURS OF ALL CARDS		5.02E-04 1.20E-06
181	7.09E-10	.01	LOSS OF OFFSITE FAILURE TO COMMON CAUSE LOSS OF DIST. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKERS TO OPEN PANEL OR BREAKER A07 SPURIOUSLY OPENS FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED 4.44E-03 4.20E-01 1.20E-03 3.17E-04 1.00E+00	IEV-LOSPD OTH-R1 ECX-CB-GO IDAMOD04 RN23MOD5S
182	7.02E-10	.01	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE OF INV. MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKER TO CLOSE STATIC SWITCH AND ASSOC. FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED 4.44E-03 4.20E-01 7.30E-04 5.16E-04 1.00E+00	IEV-LOSPD OTH-R1 ECX-CB-GC IDAMOD05 RN23MOD5S
183	6.86E-10	.01	LOSS OF OFFSITE FAILURE TO FIXED FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR COMPONENTS FAILURE DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED 4.44E-03 4.20E-01 3.17E-04 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 EDIMOD11 PMA0301BSA RN23MOD5S
184	6.86E-10	.01	LOSS OF OFFSITE FAILURE TO FIXED FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR COMPONENTS FAILURE DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED 4.44E-03 4.20E-01 3.17E-04 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 EDIMOD113 PMA0301BSA RN23MOD5S
185	6.86E-10	.01	LOSS OF OFFSITE FAILURE TO FIXED FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR COMPONENTS FAILURE DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	WITH RCS DRAINED 4.44E-03 4.20E-01 3.17E-04 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 EDIMOD113 PMA0301ASA RN23MOD5S

521

Table 54B-11

CASE 5 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME	POWER INITIATING EVENT OCCURS	WITH RCS DRAINED	EVENT PROB	IDENTIFIER
186	6.86E-10	.01	LOSS OF OFFSITE FAILURE TO FIXED FAILURE UPON MECHANICAL	RECOVER AC POWER IN 1 HOUR COMPONENTS FAILURE DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 3.17E-04 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 ED1MOD11 PMA0301ASA RN23MOD5S	
187	6.71E-10	.01	LOSS OF OFFSITE FAILURE TO COMMON CAUSE BUS UNAVAILABLE MECHANICAL	RECOVER AC POWER IN 1 HOUR FAILURE 4KV BREAKERS TO OPEN DUE TO TEST OR CORRECTIVE MAINTENANCE FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 1.20E-03 3.00E-04 1.00E+00	IEV-LOSPD OTH-R1 ECX-CB-GO IDABSDS1TM RN23MOD5S	
188	6.69E-10	.01	LOSS OF OFFSITE FAILURE TO PUMP 01B FAILS & D/G FAILS TO FAILURE UPON MECHANICAL	RECOVER AC POWER IN 1 HOUR ST CK V007B & C B FTC & RE FTC & CB ECS221 SPO START & RUN OR BKR 102 FAILS TO CLOSE DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 1.53E-02 2.02E-02 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 RNBMOD07S Z01MOD01 PMA0301ASA RN23MOD5S	
189	6.69E-10	.01	LOSS OF OFFSITE FAILURE TO PUMP 01B FAILS & D/G FAILS TO FAILURE UPON MECHANICAL	RECOVER AC POWER IN 1 HOUR ST CK V007B & C B FTC & RE FTC & CB ECS221 SPO START & RUN OR BKR 102 FAILS TO CLOSE DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 1.53E-02 2.02E-02 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 RNBMOD07S Z01MOD01 PMA0301BSA RN23MOD5S	
190	6.51E-10	.01	LOSS OF OFFSITE FAILURE TO BATTERY LOSS C7 DIST. OPERATOR FAILS	RECOVER AC POWER IN 1 HOUR DB1 UNAVAILABLE PANEL OR BREAKER A07 SPURIOUSLY OPENS NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 2.20E-03 3.17E-04 5.00E-01	IEV-LOSPD OTH-R1 ED1MOD03 IDAMOD04 RHN-MAN05	
191	6.49E-10	.01	LOSS OF OFFSITE FAILURE TO PUMP MP 01B BREAKER 100 FAILURE UPON MECHANICAL	RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR FAILS TO OPEN DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.44E-02 1.23E-02 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 SWBMOD02 EC1CB100VO PMA0301BSA RN23MOD5S	
192	6.49E-10	.01	LOSS OF OFFSITE FAILURE TO PUMP MP 01B BREAKER 100 FAILURE UPON MECHANICAL	RECOVER AC POWER IN 1 HOUR SEGMENT HARDWARE FAILURE OR FAILS TO OPEN DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO FAIL-TO-OPEN	4.44E-03 4.20E-01 2.44E-02 1.23E-02 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 SWBMOD02 EC1CB100VO PMA0301ASA RN23MOD5S	
193	6.18E-10	.01	LOSS OF OFFSITE FAILURE TO FIXED FAILURE OF OPERATOR FAILS	RECOVER AC POWER IN 1 HOUR COMPONENTS FAILURE PMS OUTPUT LOGIC I/Os TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 3.17E-04 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 ED1MOD113 PMAMOD11 RHN-MAN05	
194	6.18E-10	.01	LOSS OF OFFSITE FAILURE TO FIXED FAILURE OF OPERATOR FAILS	RECOVER AC POWER IN 1 HOUR COMPONENTS FAILURE PMS OUTPUT LOGIC I/Os TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	4.44E-03 4.20E-01 3.17E-04 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 ED1MOD11 PMAMOD11 RHN-MAN05	

126

Table 54B-II

CASE 5 LIST OF TOP 200 DOMINANT CUTSETS

NUMBER	CUTSET PROB	PERCENT	BASIC EVENT NAME			EVENT PROB.	IDENTIFIER
195	6.16E-10	.01	LOSS OF OFFSITE FAILURE TO BATTERY BUS UNAVAILABLE OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR DB1 UNAVAILABLE DUE TO TEST OR CORRECTIVE MAINTENANCE TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 2.20E-03 3.00E-04 5.00E-01	IEV-LOSPD OTH-R1 ED1MOD03 IDABSDS1TM RHN-MAN05
196	6.11E-10	.01	LOSS OF CCS/SWS CHECK VALVE CHECK VALVE CHECK VALVE CHECK VALVE MECHANICAL	WITH RCS DRAINED 122A FAILS TO OPEN 124A FAILS TO OPEN 122B FAILS TO OPEN 125B FAILS TO OPEN FAILURE CAUSES MOV 023 TO	INITIATING EVENT OCCURS FAILS TO OPEN FAILS TO OPEN FAILS TO OPEN FAILS TO OPEN FAIL-TO-OPEN	6.02E-04 1.00E+00 1.00E+00 1.75E-03 5.80E-04 1.00E+00	IEV-CWMD IWACV122AO IWACV124AO IWBCV122AO IWBCV125AO RN23MOD5S
197	6.11E-10	.01	LOSS OF CCS/SWS CHECK VALVE CHECK VALVE CHECK VALVE CHECK VALVE MECHANICAL	WITH RCS DRAINED 122A FAILS TO OPEN 124A FAILS TO OPEN 123B FAILS TO OPEN 124B FAILS TO OPEN FAILURE CAUSES MOV 023 TO	INITIATING EVENT OCCURS FAILS TO OPEN FAILS TO OPEN FAILS TO OPEN FAILS TO OPEN FAIL-TO-OPEN	6.02E-04 1.00E+00 1.00E+00 5.80E-04 1.75E-03 1.00E+00	IEV-CWMD IWACV122AO IWACV124AO IWBCV123AO IWBCV124AO RN23MOD5S
198	6.06E-10	.01	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE STANDBY DG TO START DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED STANDBY DG TO START GROUP PROCESSING FAIL-TO-OPEN	4.44E-03 4.20E-01 2.80E-04 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 Z0X-DG-DS PMA030IASA RN23MOD5S
199	6.06E-10	.01	LOSS OF OFFSITE FAILURE TO COMMON CAUSE FAILURE UPON MECHANICAL	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR FAILURE STANDBY DG TO START DEMAND OF LOGIC GROUP PROCESSING FAILURE CAUSES MOV 023 TO	WITH RCS DRAINED STANDBY DG TO START GROUP PROCESSING FAIL-TO-OPEN	4.44E-03 4.20E-01 2.80E-04 1.16E-03 1.00E+00	IEV-LOSPD OTH-R1 Z0X-DG-DS PMA030IBSA RN23MOD5S
200	6.02E-10	.01	LOSS OF OFFSITE FAILURE TO PUMP 01B FAILS & D/G FAILS TO FAILURE OF OPERATOR FAILS	POWER INITIATING EVENT OCCURS RECOVER AC POWER IN 1 HOUR ST CK V007B & C B FTC & RE FTC & CB ECS221 SPO START & RUN OR BKR 102 FAILS TO CLOSE PMS OUTPUT LOGIC I/Os TO RECOGNIZE NEED AND TO OPEN RNS MOV V023	WITH RCS DRAINED	4.44E-03 4.20E-01 1.53E-02 2.02E-02 2.09E-03 5.00E-01	IEV-LOSPD OTH-R1 RNBMOD07S Z01MOD01 PMAMOD11 RHN-MAN05

Table 54B-12

BASIC EVENT IMPORTANCE - CASE 5

BASIC EVENT	IMPORTANCE (%DECREASE)	NUMBER OF CUTSETS	DECREASE IN SYSTEM UNAVAILABILITY	BASIC EVENT PROBABILITY
1 IEV-RCSOD	53.84	457	3.3368E-06	4.4400E-06
2 RN23MOD5S	52.58	875	3.2587E-06	1.0000E+00
3 IWN-MAN00	30.84	189	1.9112E-06	5.0000E-01
4 RHN-MAN04	26.96	122	1.6709E-06	5.0000E-01
5 RHN-MAN04-SUCC	26.92	373	1.6686E-06	5.0000E-01
6 IWN-MAN00C	26.90	23	1.6669E-06	5.0000E-01
7 IEV-CCWD	23.73	1942	1.4706E-06	6.0200E-04
8 RHN-MAN05C	19.22	27	1.1913E-06	5.0000E-01
9 IWACV122AO	18.68	126	1.1577E-06	1.0000E+00
10 IWACV124AO	18.68	126	1.1577E-06	1.0000E+00
11 REC-MANDASC	16.01	46	9.9237E-07	5.0000E-01
12 IEV-CCWND	12.96	69	8.0307E-07	3.7500E-03
13 LPM-MAN05	11.36	37	7.0373E-07	5.0000E-01
14 CCX-ORY-SP	7.58	18	4.6959E-07	2.7700E-04
15 RHN-MAN05	7.04	743	4.3610E-07	5.0000E-01
16 CCX-XMTR195	5.48	16	3.3961E-07	2.0100E-04
17 IDCBSDD1TM	4.99	126	3.0896E-07	3.0000E-04
18 IDCBSDK1TM	4.99	126	3.0896E-07	3.0000E-04
19 IDCBSDS1TM	4.99	126	3.0896E-07	3.0000E-04
20 ADN-MAN01	4.98	58	3.0853E-07	5.0000E-01
21 PRN-MAN01	3.69	4	2.2868E-07	5.0000E-01
22 IEV-LOSPD	3.39	2394	2.1033E-07	4.4400E-03
23 OTH-R1	3.30	2242	2.0480E-07	4.2000E-01
24 IEV-RNSD	.08	933	1.9100E-07	8.1500E-05
25 IWB-PLUG	2.83	382	1.7530E-07	2.4000E-04
26 IEV-RNSND	2.37	46	1.4712E-07	9.6100E-04
27 CCX-INPUT-LOGIC	2.31	29	1.4331E-07	1.0300E-04
28 PMAMOD11	1.12	296	6.9551E-08	2.0900E-03
29 IW10R170SPX	1.07	34	6.6116E-08	9.4600E-05
30 IW20R160SPX	1.07	34	6.6116E-08	9.4600E-05
31 IRAEP121BSAX	.85	45	5.2732E-08	5.8300E-05
32 CCX-PMAMOD1X	.79	195	4.8857E-08	4.6300E-05
33 IW1TL170UFX	.77	33	4.7858E-08	6.8400E-05
34 IW2TL160UFX	.77	33	4.7858E-08	6.8400E-05
35 CCX-PMAMOD2X	.72	22	4.4727E-08	8.5800E-05
36 ED1MOD03	.62	130	3.8569E-08	2.2020E-03
37 PMA01ASA	.61	218	3.7749E-08	1.1600E-03
38 PMA01BSA	.61	218	3.7749E-08	1.1600E-03
39 REC-MANDAS	.60	36	3.6991E-08	5.0000E-01
40 Z01MOD01	.59	518	3.6358E-08	2.0200E-02
41 IWX-CV-AO	.57	395	3.5178E-08	3.1000E-05
42 ZOX-PD-ES	.55	112	3.3998E-08	2.0000E-03
43 IWX-MV-G01	.48	266	2.9685E-08	3.8000E-05
44 ADX-EV-SA	.48	290	2.9497E-08	3.8000E-05
45 CCX-EP-SAM	.40	215	2.4744E-08	8.6200E-06
46 MDAS	.33	79	2.0583E-08	1.0000E-02
47 EC1CB100VO	.33	375	2.0539E-08	1.2300E-02
48 ECX-CB-G0	.33	91	2.0390E-08	1.2000E-03
49 IDAMOD05	.33	354	2.0330E-08	5.1600E-04
50 CCX-SFTW	.32	26	1.9545E-08	1.2000E-06
51 CCX-PMA030X	.23	130	1.4485E-08	1.3800E-05
52 SWBMOD02	.22	147	1.3820E-08	2.4400E-02
53 CCX-INPUT-LOGICX	.21	12	1.3301E-08	2.5900E-05
54 IDAMOD04	.20	340	1.2480E-08	3.1700E-04
55 ECX-CB-GC	.20	73	1.2340E-08	7.3000E-04
56 Z02MOD01	.19	181	1.1902E-08	2.0200E-02
57 IEV-LOCA24ND	.19	121	1.1772E-08	1.6800E-05
58 CCX-PMAMOD1-SW	.19	128	1.1699E-08	1.1000E-05
59 IDABSDS1TM	.18	255	1.1388E-08	3.0000E-04
60 IEV-LOSPND	.17	40	1.0762E-08	1.7100E-02
61 IEV-LOCA24D	.17	393	1.0704E-08	1.1300E-05
62 IWX-FL-GP	.15	168	9.5232E-09	1.2000E-05
63 RNBMOD07S	.14	141	8.7608E-09	1.5300E-02
64 SUC-R+S	.13	9	8.0530E-09	7.6000E-01
65 EC1BS001TM	.13	442	7.8629E-09	2.7000E-03
66 EC1BS012TM	.13	442	7.8629E-09	2.7000E-03

67	EC1BS121TM	.13	442	7.8629E-09	2.7000E-03
68	ZOX-DG-DR	.12	56	7.4074E-09	4.4000E-04
69	CCX-PMAMOD1	.12	87	7.2399E-09	1.4100E-04
70	EC2CB200VO	.11	139	6.8528E-09	1.2300E-02
71	PMAMOD11X	.11	369	6.5545E-09	6.5300E-04
72	CCX-IN-LOGIC-SW	.09	8	5.6458E-09	1.1000E-05
73	CCX-PMAMOD2-SW	.09	8	5.6458E-09	1.1000E-05
74	CCBMOD01S	.09	88	5.5465E-09	1.0400E-02
75	SUC-RIS	.09	152	5.5237E-09	5.8000E-01
76	ED1MOD11	.09	1	5.2900E-09	3.1700E-04
77	ED1MOD113	.09	54	5.2900E-09	3.1700E-04
78	IEV-LOCAPRND	.08	59	5.0432E-09	1.5100E-05
79	PMAMOD21X	.08	14	4.8554E-09	1.1600E-03
80	PL5MOD11	.08	72	4.7051E-09	2.0900E-03
81	ZOX-DG-DS	.08	49	4.6900E-09	2.8000E-04
82	CCX-PMA030	.07	59	4.5693E-09	9.6900E-05
83	ZO1DG001TM	.07	95	4.3718E-09	4.6000E-02
84	IWBCV122AO	.07	132	4.1218E-09	1.7500E-03
85	IWBCV124AO	.07	132	4.1218E-09	1.7500E-03
86	CCX-EP-SAMX	.05	87	3.0879E-09	2.9400E-06
87	OTH-R2	.04	29	2.7091E-09	2.4000E-01
88	CCX-ORY-SPX	.04	112	2.7053E-09	3.6300E-06
89	PL50301ASA	.04	46	2.3567E-09	1.1600E-03
90	PL50301BSA	.04	46	2.3567E-09	1.1600E-03
91	EC1REIDG2GA	.03	55	2.1517E-09	4.3600E-03
92	ZOX-PD-ER	.03	31	2.0608E-09	1.3000E-04
93	PMAXS00ASA	.03	28	1.9741E-09	8.0000E-05
94	CCX-XMTRX	.03	97	1.9520E-09	2.6300E-06
95	RNX-PM-FS	.03	48	1.7754E-09	7.7000E-04
96	ED2MOD03	.03	68	1.6401E-09	2.7000E-03
97	PMA0301ASAX	.03	176	1.6239E-09	1.6500E-04
98	PMA0301BSAX	.03	157	1.5824E-09	1.6500E-04
99	RHN-MAN03	.02	36	1.4668E-09	5.0000E-01
100	IWBCV123AO	.02	132	1.3676E-09	5.8000E-04
101	IWBCV125AO	.02	132	1.3676E-09	5.8000E-04
102	RNX-KV-GO	.02	42	1.3528E-09	6.1000E-04
103	CCX-BY-PN	.02	237	1.3132E-09	4.7000E-05
104	ZO1MOD04	.02	82	1.0767E-09	1.2500E-03
105	ED3MOD03	.02	35	9.6831E-10	2.2020E-03
106	PMAMOD12X	.02	123	9.5351E-10	6.5300E-04
107	IDDBSDD1TM	.02	343	9.3398E-10	3.0000E-04
108	IDDBBSDK1TM	.02	343	9.3398E-10	3.0000E-04
109	IDDBSDS1TM	.02	343	9.3398E-10	3.0000E-04
110	RNAMOD06S	.01	85	8.9943E-10	1.5300E-02
111	PL4MOD11	.01	43	8.9581E-10	2.0900E-03
112	PL1MOD11	.01	36	8.9387E-10	2.0900E-03
113	PL7MOD11	.01	36	8.9387E-10	2.0900E-03
114	PMAXS00ASAX	.01	158	8.7293E-10	8.0000E-05
115	ED1MOD01	.01	22	8.5167E-10	5.0400E-04
116	ZOX-BL-ES	.01	15	8.4416E-10	6.0000E-05
117	CCX-BY-PN1	.01	16	8.0309E-10	5.7000E-05
118	SWBMOD09P	.01	31	7.9039E-10	1.8500E-03
119	CCX-IV-XR	.01	132	6.8129E-10	2.4000E-05
120	IWACV123AO	.01	126	6.7191E-10	5.8000E-04
121	IWACV125AO	.01	126	6.7191E-10	5.8000E-04
122	CCB-MAN01	.01	6	6.6190E-10	5.0000E-01
123	PMAMOD22X	.01	2	6.0800E-10	1.1600E-03
124	DAS	.01	4	5.3345E-10	1.0000E-02
125	RNDEP023SA	.01	267	5.2978E-10	1.7100E-04
126	CCX-AV-LA	.01	5	5.2224E-10	6.1000E-05
127	CCNTF101RI	.01	5	4.7057E-10	5.2300E-03
128	SWNTP001RI	.01	5	4.7057E-10	5.2300E-03
129	SWB-MAN02	.01	4	4.7050E-10	5.0000E-01
130	IDAMC008	.01	96	4.6218E-10	3.1700E-04
131	CMX-CV-GO	.01	4	4.3656E-10	5.1000E-05
132	CCX-PMDMOD1	.01	249	4.3604E-10	1.4100E-04
133	ZO2MOD04	.01	44	4.2124E-10	1.2500E-03
134	ED1MOD13	.01	16	4.0011E-10	3.1700E-04
135	ED1MOD07	.01	16	3.8487E-10	3.0500E-04
136	PL40301ASA	.01	29	3.8104E-10	1.1600E-03
137	PL40301BSA	.01	26	3.8068E-10	1.1600E-03
138	PL10301ASA	.01	25	3.8030E-10	1.1600E-03
139	PL70301ASA	.01	25	3.8030E-10	1.1600E-03
140	PL10301BSA	.01	24	3.8020E-10	1.1600E-03
141	PL70301BSA	.01	24	3.8020E-10	1.1600E-03
142	IDDBSDD1TM	.01	125	3.6261E-10	3.0000E-04
143	IDDBBSDK1TM	.01	125	3.6261E-10	3.0000E-04
144	IDDBSDS1TM	.01	125	3.6261E-10	3.0000E-04
145	CCX-PMAMOD4	.01	41	3.5227E-10	4.9800E-05
146	RC10R195SP	.01	4	3.3587E-10	7.2200E-03
147	CMX-VS-FA	.01	7	3.2365E-10	3.8400E-05

148	ZON-MAN01	.01	7	3.2320E-10	5.0000E-01
149	IWA-PLUG	.00	136	2.9131E-10	2.4000E-04
150	CCX-PMD030	.00	163	2.4508E-10	9.6900E-05
151	RC1TL195UF	.00	3	2.3779E-10	5.2300E-03
152	PMA0302ASAX	.00	59	2.1048E-10	1.6500E-04
153	SWAMOD07	.00	39	1.8637E-10	7.1200E-03
154	PMA0302BSAX	.00	40	1.6899E-10	1.6500E-04
155	CCX-PMDMOD4	.00	118	1.2403E-10	4.9800E-05
156	CCX-PL4MOD1	.00	15	1.2347E-10	1.4100E-04
157	CCAMOD02	.00	37	1.1131E-10	7.1000E-03
158	EC1MOD12	.00	66	1.1052E-10	4.8000E-05
159	IDAMOD06	.00	48	9.6335E-11	4.3200E-05
160	IDAMOD02	.00	31	9.0318E-11	2.7000E-03
161	IDAMOD03	.00	31	9.0318E-11	2.7000E-03
162	EC5EPMB1SA	.00	8	8.7669E-11	1.7100E-04
163	PXX-AV-LA	.00	57	8.3091E-11	6.1000E-05
164	CCX-PMAMOD4-SW	.00	12	7.3239E-11	1.1000E-05
165	CCX-PL1MOD1	.00	8	7.2306E-11	1.4100E-04
166	CCX-PL7MOD1	.00	8	7.2306E-11	1.4100E-04
167	IRAEPI21ASAX	.00	42	6.6882E-11	5.8300E-05
168	ED3MOD07	.00	26	6.4948E-11	3.0500E-04
169	PL1MOD51	.00	2	6.2000E-11	8.7400E-04
170	PMDMOD11	.00	194	5.5596E-11	2.0900E-03
171	CCX-PL403	.00	12	4.9853E-11	9.6900E-05
172	EC1REDG1GA	.00	37	4.75F1E-11	4.3600E-03
173	ED3MOD01	.00	10	4.3471E-11	5.0400E-04
174	DG1-LOGIC	.00	1	4.0700E-11	5.9000E-03
175	IDABSDS1LF	.00	24	3.9891E-11	4.8000E-06
176	CCX-LS-FA	.00	32	3.7345E-11	5.3700E-06
177	EC1MOD121	.00	24	3.5320E-11	1.6800E-05
178	Z02DG002TM	.00	42	3.4979E-11	4.6000E-02
179	EC2BS002TM	.00	178	2.8158E-11	2.7000E-03
180	EC2BS022TM	.00	178	2.8158E-11	2.7000E-03
181	EC2BS221TM	.00	178	2.8158E-11	2.7000E-01
182	IDDFD019RQ	.00	51	2.7819E-11	1.2000E-05
183	IDDFD020RQ	.00	51	2.7819E-11	1.2000E-05
184	CCX-PMAEH0X	.00	11	2.6854E-11	4.0300E-06
185	CCX-PMDMOD1-SW	.00	49	2.5515E-11	1.1000E-05
186	CCX-PMDMOD4-SW	.00	49	2.5515E-11	1.1000E-05
187	PMAMOD41	.00	34	2.4556E-11	6.3500E-04
188	RNX-CV-GO	.00	11	2.2157E-11	5.1000E-05
189	IDAMOD07	.00	15	2.0916E-11	2.1900E-02
190	CCX-PL103	.00	6	1.8601E-11	9.6900E-05
191	CCX-PL703	.00	6	1.8601E-11	9.6900E-05
192	ED2MOD01	.00	1	1.7900E-11	5.0400E-04
193	PMDMOD12	.00	83	1.6617E-11	2.0900E-03
194	PMD0301ASA	.00	125	1.6120E-11	1.1600E-03
195	PL5XS00ASA	.00	6	1.5354E-11	8.0000E-05
196	PMD0301BSA	.00	108	1.4534E-11	1.1600E-03
197	SWAMOD09P	.00	22	1.3491E-11	1.8500E-03
198	IDCFD007RQ	.00	8	1.2347E-11	1.2000E-05
199	IDCFD008RQ	.00	8	1.2347E-11	1.2000E-05
200	IDBFD013RQ	.00	10	1.1754E-11	1.2000E-05
201	IDBFD014RQ	.00	10	1.1754E-11	1.2000E-05
202	IDDBBSD1LF	.00	28	1.1051E-11	4.8000E-06
203	IDDBBSDK1LF	.00	28	1.1051E-11	4.8000E-06
204	IDDBBSDS1LF	.00	28	1.1051E-11	4.8000E-06
205	CCX-PMDEH0	.00	26	9.2671E-12	4.0300E-06
206	AD2MOD01	.00	21	8.7184E-12	5.5400E-02
207	AD2MOD02	.00	21	8.7184E-12	5.5400E-02
208	AD3MOD03	.00	21	8.7184E-12	5.5400E-02
209	AD3MOD04	.00	21	8.7184E-12	5.5400E-02
210	ALI.-IND-FAIL	.00	27	7.3400E-12	1.0000E-06
211	EC1BS001LF	.00	7	7.3100E-12	4.8000E-06
212	RNX-PM-ER	.00	10	6.8751E-12	1.6000E-05
213	PMDMOD41	.00	67	6.5872E-12	6.3500E-04
214	ZANMOD01	.00	8	6.1859E-12	8.4000E-05
215	CCX-PM-ER	.00	10	6.0156E-12	1.4000E-05
216	SWX-PM-ER	.00	10	6.0156E-12	1.4000E-05
217	ED2MOD11	.00	20	5.3288E-12	3.1700E-04
218	IDDMOD13	.00	45	4.9640E-12	5.1600E-04
219	PMD0302ASA	.00	46	4.9126E-12	1.1600E-03
220	IDDMOD32	.00	58	4.6931E-12	3.1700E-04
221	CCX-IV-XR1	.00	6	4.6030E-12	2.4000E-05
222	CCX-PL4MOD1-SW	.00	8	4.5841E-12	1.1000E-05
223	CCX-EP-SA	.00	8	3.5885E-12	8.8200E-06
224	PL4MOD12	.00	16	3.4699E-12	2.0900E-03
225	IDBBBSD1LF	.00	7	3.4044E-12	4.8000E-06
226	IDBBBSDK1LF	.00	7	3.4044E-12	4.8000E-06
227	IDBBBSDS1LF	.00	7	3.4044E-12	4.8000E-06
228	PMD0302BSA	.00	29	3.3169E-12	1.1600E-03

229	IDCBSDD1LF	.00	4	3.2949E-12	4.8000E-06
230	IDCBSDK1LF	.00	4	3.2949E-12	4.8000E-06
231	IDCBSDS1LF	.00	4	3.2949E-12	4.8000E-06
232	EC1MOD01	.00	16	3.2830E-12	2.0200E-04
233	EC2MOD01	.00	14	2.5059E-12	2.0200E-04
234	PMAEHOA1SAX	.00	6	2.1599E-12	8.0000E-05
235	PMAMOD42	.00	4	2.0129E-12	6.3500E-04
236	CCX-PL1MOD1-SW	.00	4	1.9811E-12	1.1000E-05
237	CCX-PL7MOD1-SW	.00	4	1.9811E-12	1.1000E-05
238	RNAEPRNPSA	.00	9	1.7508E-12	1.7100E-04
239	RNBEPRNPSA	.00	9	1.7508E-12	1.7100E-04
240	IDDMOD38	.00	31	1.6636E-12	3.1700E-04
241	SW7EPSBPASA	.00	7	1.4734E-12	1.7100E-04
242	PL1MOD12	.00	7	1.4055E-12	2.0900E-03
243	PL7MOD12	.00	7	1.4055E-12	2.0900E-03
244	PL40302ASA	.00	7	1.1774E-12	1.1600E-03
245	CC1EPSEPBASA	.00	6	1.0401E-12	1.7100E-04
246	ADX-MV-GO	.00	4	1.0300E-12	1.1000E-03
247	Z01MOD03	.00	8	1.0089E-12	1.0000E-04
248	D22-LOGIC	.00	1	9.6501E-13	5.0000E-03
249	SW7EPSEPBASA	.00	5	8.7430E-13	1.7100E-04
250	CC1EPSEPBASA	.00	5	8.7408E-13	1.7100E-04
251	PL40302BSA	.00	4	8.1801E-13	1.1600E-03
252	SW7EPCTFASA	.00	4	7.8804E-13	1.7100E-04
253	SW7EPCTFBASA	.00	4	7.8804E-13	1.7100E-04
254	PMDXS00ASA	.00	32	7.8781E-13	8.0000E-05
255	ED1BSDS1LF	.00	3	7.8693E-13	4.8000E-06
256	PMDEHOA1SA	.00	28	7.7915E-13	8.0000E-05
257	Z02MOD03	.00	5	5.8920E-13	1.0000E-04
258	ED1BSDS1TM	.00	1	4.8805E-13	3.0000E-04
259	IWNNTK001AF	.00	5	4.8728E-13	2.4000E-06
260	PMDMOD42	.00	11	4.8694E-13	6.3500E-04
261	PL10302ASA	.00	3	4.3932E-13	1.1600E-03
262	PL70302ASA	.00	3	4.3932E-13	1.1600E-03
263	PRAAV108LA	.00	11	3.6260E-13	1.0900E-03
264	PRBAV108LA	.00	11	3.6260E-13	1.0900E-03
265	PL10302BSA	.00	2	3.4395E-13	1.1600E-03
266	PL70302BSA	.00	2	3.4395E-13	1.1600E-03
267	CCX-HE-AF	.00	3	3.1908E-13	1.2000E-06
268	PLIXS00ASA	.00	3	1.9976E-13	8.0000E-05
269	PL4XS00ASA	.00	3	2.9976E-13	8.0000E-05
270	PL7XS00ASA	.00	3	2.9976E-13	8.0000E-05
271	CCX-BC-SA	.00	5	2.8222E-13	8.4000E-06
272	PLMMOD41	.00	2	2.4203E-13	6.3500E-04
273	CCX-KMTR	.00	3	1.9007E-13	2.0100E-04
274	EC2MOD22	.00	17	1.8141E-13	4.8000E-05
275	PRAAV108TM	.00	9	1.6143E-13	5.0000E-04
276	PRBAV108TM	.00	9	1.6143E-13	5.0000E-04
277	CCX-TRNSM	.00	2	1.4899E-13	2.0100E-04
278	EC1MOD13	.00	2	1.4067E-13	4.8000E-05
279	EC2MOD23	.00	2	1.4067E-13	4.8000E-05
280	ZOX-BL-ER	.00	1	9.6367E-14	1.3600E-06
281	ZOX-FL-GP	.00	1	9.2149E-14	1.3000E-06
282	IDDMOD21	.00	6	4.9960E-14	1.9200E-04
283	IDABSDD1TM	.00	3	3.1641E-14	3.0000E-04
284	IDABSDK1TM	.00	3	3.1641E-14	3.0000E-04
285	PRX-HR-ML	.00	4	2.4314E-14	1.2000E-07
286	PMDEHOA2SA	.00	10	1.7764E-14	8.0000E-05
287	IDDMOD34	.00	10	1.2212E-14	4.3200E-05
288	PRCEP108SA	.00	1	1.0769E-14	1.7100E-04
289	PRDEP108SA	.00	1	1.0769E-14	1.7100E-04
290	IDDMOD35	.00	4	5.7732E-15	2.1900E-02
291	EC2MOD221	.00	3	1.3323E-15	1.6800E-05
292	IWX-KMTRLW	.00	2	1.3323E-15	9.2000E-09
293	IDDMOD22	.00	3	9.9920E-16	2.7000E-03
294	IDDMOD23	.00	3	9.9920E-16	2.7000E-03

SYSTEM UNAVAILABILITY (Q) = 6.197E-06
 NUMBER OF BASIC EVENTS = 294
 NUMBER OF CUTSETS = 6454

BASIC EVENT	IMPORTANCE (%INCREASE)	NUMBER OF CUTSETS	INCREASE IN SYSTEM UNAVAILABILITY	BASIC EVENT PROBABILITY
1 IEV-RCSOD	1.212687E+07	457	7.5153E-01	4.4400E-06
2 CCX-SFTW	262824	26	1.6288E-02	1.2000E-06
3 CCX-EP-SAM	46319.2	215	2.8705E-03	8.6200E-06
4 IEV-CCWD	39395.8	1942	2.4415E-03	6.0200E-04
5 IEV-RNSD	37813.5	933	2.3434E-03	8.1500E-05
6 CCX-ORY-SP	27347.7	18	1.6948E-03	2.7700E-04
7 CCX-XMTR195	27258.5	16	1.6893E-03	2.0100E-04
8 CCX-INPUT-LOGIC	22449.4	29	1.3912E-03	1.0300E-04
9 IWX-CV-AO	18310.5	395	1.1347E-03	3.1000E-05
10 CCX-PMAMOD1-SW	17162.0	128	1.0636E-03	1.1000E-05
11 CCX-PMAMOD1X	17026.5	195	1.0552E-03	4.6300E-05
12 CCX-EP-SAMX	16948.0	87	1.0503E-03	2.9400E-06
13 CCX-PMA030X	16936.4	130	1.0496E-03	1.3800E-05
14 IDCBSDD1TM	16613.2	126	1.0296E-03	3.0000E-04
15 IDCBSDK1TM	16613.2	126	1.0296E-03	3.0000E-04
16 IDCBSDS1TM	16613.2	126	1.0296E-03	3.0000E-04
17 IEV-LOCA24D	15285.5	393	9.4728E-04	1.1300E-05
18 IRAEP121BSAX	14594.3	45	9.0445E-04	5.8300E-05
19 IWX-PL-GP	12805.5	168	7.9359E-04	1.2000E-05
20 IWX-NV-GO1	12604.7	266	7.8115E-04	3.8000E-05
21 ADX-EV-SA	12525.2	290	7.7622E-04	3.8000E-05
22 CCX-ORY-SPX	12025.6	112	7.4526E-04	3.6300E-06
23 CCX-XMTRX	11976.2	97	7.4220E-04	2.6300E-06
24 IW-B-PLUG	11783.6	382	7.3026E-04	2.4000E-04
25 IEV-LOCA24ND	11306.4	121	7.0068E-04	1.6800E-05
26 IW1TL1170UFX	11289.5	33	6.9964E-04	6.8400E-05
27 IW2TL160UFX	11289.5	33	6.9964E-04	6.8400E-05
28 IW1OR170SPX	11276.5	34	6.9884E-04	9.4600E-05
29 IW2OR160SPX	11276.5	34	6.9884E-04	9.4600E-05
30 CCX-PMAMOD2X	8411.01	22	5.2125E-04	8.5800E-05
31 CCX-INPUT-LOGICX	8286.46	12	5.11353E-04	2.5900E-05
32 CCX-IN-LOGIC-SW	8281.84	8	5.11325E-04	1.1000E-05
33 CCX-PMAMOD2-SW	8281.84	8	5.11325E-04	1.1000E-05
34 IEV-LOCAPRND	5389.23	59	3.3398E-04	1.5100E-05
35 IEV-CCWND	3442.63	69	2.11335E-04	3.7500E-03
36 IEV-RNSD	2467.97	46	1.5295E-04	9.6100E-04
37 CCX-PMAMOD1	828.423	87	5.13399E-05	1.4100E-04
38 IEV-LOSPD	760.990	2394	4.7160E-05	4.4400E-03
39 CCX-PMA030	760.818	59	4.7150E-05	9.6900E-05
40 IDAMOD05	635.423	354	3.9379E-05	5.1600E-04
41 IDAMOD04	635.078	340	3.9357E-05	3.1700E-04
42 IDABSDS1TM	612.359	255	3.7949E-05	3.0000E-04
43 PMAMOD11	535.860	296	3.3209E-05	2.0900E-03
44 PMA0301ASA	524.496	218	3.2504E-05	1.1600E-03
45 PMA0301BSA	524.496	218	3.2504E-05	1.1600E-03
46 CCX-IV-XR	458.046	132	2.8386E-05	2.4000E-05
47 CCX-BY-PN	450.838	237	2.7940E-05	4.7000E-05
48 PMAXS00ASA	398.157	28	2.4675E-05	8.0000E-05
49 ED1MOD03	282.009	130	1.7477E-05	2.2020E-03
50 ECX-CB-GO	273.848	91	1.6971E-05	1.2000E-03
51 ZOX-PD-ES	273.747	112	1.6965E-05	2.0000E-03
52 ECX-CB-GC	272.563	73	1.6891E-05	7.3000E-04
53 ZOX-DG-DR	271.532	56	1.6828E-05	4.4000E-04
54 ZOX-DG-DS	270.207	49	1.6745E-05	2.8000E-04
55 ED1MOD11	269.191	54	1.6682E-05	3.1700E-04
56 ED1MOD113	269.191	54	1.6682E-05	3.1700E-04
57 ZOX-PD-ER	255.766	31	1.5850E-05	1.3000E-04
58 CCX-BY-PN1	227.335	16	1.4089E-05	5.7000E-05
59 ZOX-BL-ES	227.013	15	1.4069E-05	6.0000E-05
60 PMAXS00ASAX	176.058	158	1.0911E-05	8.0000E-05
61 PMAMOD11X	161.861	369	1.0031E-05	6.5300E-04
62 PMA0301ASAX	158.786	176	9.8404E-06	1.6500E-04
63 PMA0301BSAX	154.729	157	9.5889E-06	1.6500E-04
64 CCX-AV-LA	138.139	5	8.5608E-06	6.1000E-05
65 CMX-CV-GO	138.119	4	8.5596E-06	5.1000E-05
66 CMX-VS-FA	138.098	7	8.5583E-06	3.8400E-05
67 IDABSDS1LF	134.100	24	8.3105E-06	4.8000E-06
68 ALL-IND-FAIL	118.440	27	7.3400E-06	1.0000E-06
69 CCX-PMAMOD4	114.138	41	7.0734E-06	4.9800E-05
70 CCX-LS-FA	112.215	32	6.9543E-06	5.3700E-06
71 CCX-PMAEHOX	107.522	11	6.6634E-06	4.0300E-06
72 CCX-PMAMOD4-SW	107.435	12	6.6580E-06	1.1000E-05

73	PMAMOD21X	67.4626	14	4.1808E-06	1.1600E-03
74	IDDBSDD1TM	50.2211	343	3.1123E-06	3.0000E-04
75	IDDBSDK1TM	50.2211	343	3.1123E-06	3.0000E-04
76	IDDBSDS1TM	50.2211	343	3.1123E-06	3.0000E-04
77	RNDEPO23SA	49.9834	267	3.0976E-06	1.7100E-04
78	CCX-PMDMOD1	49.8938	249	3.0920E-06	1.4100E-04
79	EC1BS001TM	46.8647	442	2.9043E-06	2.7000E-03
80	EC1BS012TM	46.8647	442	2.9043E-06	2.7000E-03
81	EC1BS121TM	46.8647	442	2.9043E-06	2.7000E-03
82	CCX-PMD070	40.8082	163	2.5290E-06	9.6900E-05
83	CCX-PMDMOD4	40.1863	118	2.4904E-06	4.9800E-05
84	IWBCV123AO	38.0259	132	2.3566E-06	5.8000E-04
85	IWBCV125AO	38.0259	132	2.3566E-06	5.8000E-04
86	IWBCV122AO	37.9390	132	2.3512E-06	1.7500E-03
87	IWBCV124AO	37.9390	132	2.3512E-06	1.7500E-03
88	CCX-PMDMOD1-SW	37.4279	49	2.3195E-06	1.1000E-05
89	CCX-PMDMOD4-SW	37.4279	49	2.3195E-06	1.1000E-05
90	IDDFD019RQ	37.4069	51	2.3182E-06	1.2000E-05
91	IDDPD020RQ	37.4069	51	2.3182E-06	1.3000E-05
92	RNX-PM-FS	37.1768	48	2.3739E-06	7.7000E-04
93	IDDBSDD1LF	37.1517	28	2.3024E-06	4.8000E-06
94	IDDBSDK1LF	37.1517	28	2.3024E-06	4.8000E-06
95	IDDBSDS1LF	37.1517	28	2.3024E-06	4.8000E-06
96	EC1MOD12	37.1502	66	2.3023E-06	4.8000E-05
97	CCX-PMDEH0	37.1056	26	2.2995E-06	4.0300E-06
98	PL5MOD11	36.2505	72	2.2465E-06	2.0900E-03
99	IDAMOD06	35.9817	48	2.2299E-06	4.3200E-05
100	RNX-KV-GO	35.7622	42	2.2163E-06	6.1000E-04
101	EC1MOD121	33.9242	24	2.1024E-06	1.6800E-05
102	MDAS	32.8814	79	2.0377E-06	1.0000E-02
103	PL50301ASA	32.7446	46	2.0293E-06	1.1600E-03
104	PL50301BSA	32.7446	46	2.0293E-06	1.1600E-03
105	IWN-MAN00	30.8387	189	1.9112E-06	5.0000E-01
106	Z01MOD01	28.4566	518	1.7635E-06	2.0200E-02
107	ED1MOD01	27.2536	22	1.6890E-06	5.0400E-04
108	RHN-MAN04	26.9627	122	1.6709E-06	5.0000E-01
109	RHN-MAN04-SUCC	26.9249	373	1.6686E-06	5.0000E-01
110	IWN-MAN00C	26.8971	23	1.6669E-06	5.0000E-01
111	EC1CB100VO	26.6128	375	1.6493E-06	1.2300E-02
112	EC1BS001LF	24.5741	7	1.5229E-06	4.8000E-06
113	PMAMOD12X	23.5466	123	1.4592E-06	6.5300E-04
114	IDAMOD08	23.5187	96	1.4575E-06	3.1700E-04
115	PXX-AV-LA	21.9785	57	1.3621E-06	6.1000E-05
116	PMA0302ASAX	20.5803	59	1.2754E-06	1.6500E-04
117	ED1MOD13	20.3605	16	1.2618E-06	3.1700E-04
118	ED1MOD07	20.3557	16	1.2615E-06	3.0500E-04
119	IWA-PLUG	19.5813	136	1.2135E-06	2.4000E-04
120	IDDBSDD1TM	19.4981	125	1.2083E-06	3.0000E-04
121	IDBBSDK1TM	19.4981	125	1.2083E-06	3.0000E-04
122	IDDBSDS1TM	19.4981	125	1.2083E-06	3.0000E-04
123	RHN-MAN05C	19.2224	27	1.1913E-06	5.0000E-01
124	IWACV123AO	18.6823	126	1.1578E-06	5.8000E-04
125	IWACV125AO	18.6823	126	1.1578E-06	5.8000E-04
126	IRAEPI21ASAX	18.5104	42	1.1471E-06	5.8300E-05
127	IDCFD007RQ	16.6027	8	1.0289E-06	1.2000E-05
128	IDCFD008RQ	16.6027	8	1.0289E-06	1.2000E-05
129	PMA0302BSAX	16.5233	40	1.0240E-06	1.6500E-04
130	REC-MANDASC	16.0130	46	9.9237E-07	5.0000E-01
131	IDBFD013RQ	15.8054	10	9.7950E-07	1.2000E-05
132	IDBFD014RQ	15.8054	10	9.7950E-07	1.2000E-05
133	CCX-PL4MOD1	14.1282	15	8.7556E-07	1.4100E-04
134	Z01MOD04	13.8817	82	8.6029E-07	1.2500E-03
135	IDDBSDD1LF	11.4445	7	7.0924E-07	4.8000E-06
136	IDBBSDK1LF	11.4445	7	7.0924E-07	4.8000E-06
137	IDBF3DS1LF	11.4445	7	7.0924E-07	4.8000E-06
138	LPM-MAN03	11.3554	37	7.0373E-07	5.0000E-01
139	IDCBSDD1LF	11.0765	4	6.8644E-07	4.8000E-06
140	IDCBSDK1LF	11.0765	4	6.8644E-07	4.8000E-06
141	IDCBSDS1LF	11.0765	4	6.8644E-07	4.8000E-06
142	IEV-LOSPND	9.98189	40	6.1860E-07	1.7100E-02
143	ED2MOD03	9.77541	68	6.0581E-07	2.7000E-03
144	Z02MOD01	9.31575	181	5.7732E-07	2.0200E-02
145	RNBMOD07S	9.09824	141	5.6384E-07	1.5300E-02
146	SWBMOD02	8.91662	147	5.5259E-07	2.4400E-02
147	EC2CB200VO	8.87951	139	5.5029E-07	1.2300E-02
148	CCBMOD01S	8.51921	88	5.2796E-07	1.0400E-02
149	PMAMOD22X	8.44777	2	5.2353E-07	1.1600E-03
150	CCX-PL403	8.30092	12	5.1443E-07	9.6900E-05
151	CCX-PL1MOD1	8.27361	8	5.1274E-07	1.4100E-04
152	CCX-PL7MOD1	8.27361	8	5.1274E-07	1.4100E-04
153	EC5EPMGB1SA	8.27135	8	5.1260E-07	1.7100E-04

154	EC1REDG32GA	7.92880	55	4.9137E-07	4.3600E-03
155	ED3MOD03	7.08010	35	4.3877E-07	2.3030E-03
156	RHN-MAN05	7.03702	743	4.3610E-07	5.0000E-01
157	RNX-CV-OO	7.00997	11	4.1843E-07	5.1000E-05
158	RNX-PM-ER	6.93346	10	4.2968E-07	2.6000E-05
159	CCX-PM-ER	6.93343	10	4.2958E-07	1.4000E-05
160	SWX-PM-ER	6.93343	10	4.2968E-07	1.4000E-05
161	PL4MOD11	6.90180	43	4.2772E-07	2.0900E-03
162	PL1MOD11	6.84688	36	4.2680E-07	2.0900E-03
163	PL7MOD11	6.88688	36	4.2680E-07	2.0900E-03
164	SWBMOD09P	6.88124	31	4.2645E-07	1.8500E-03
165	CCX-PL4MOD1-SW	6.73447	8	4.1673E-07	1.1000E-05
166	CCX-E-/SA	6.71735	8	4.1629E-07	8.6200E-06
167	Z02MOD04	5.43591	44	3.3657E-07	1.2500E-03
168	PL40301ASA	5.29427	29	3.2810E-07	1.1600E-03
169	PL10301BSA	5.28928	26	3.2779E-07	1.1600E-03
170	PL10301ASA	5.28402	25	3.2746E-07	1.1600E-03
171	PL70301ASA	5.28402	25	3.2746E-07	1.1600E-03
172	PL10301BSA	5.28269	24	3.2738E-07	1.1600E-03
173	PL70301BSA	5.28269	24	3.2738E-07	1.1600E-03
174	ADN-MAN01	4.97846	58	3.0853E-07	5.0000E-01
175	OTH-R1	4.56368	2142	2.8262E-07	4.2000E-01
176	CCX-HE-AF	4.29058	3	2.6590E-07	1.2000E-06
177	RHN-MAN01	3.69002	4	2.2868E-07	5.0000E-01
178	ED3MOD07	3.43507	26	2.1288E-07	3.0500E-04
179	IWNTK001AF	3.27615	5	2.0303E-07	2.4000E-06
180	PRX-HR-ML	3.26944	4	2.0262E-07	1.2000E-07
181	CCX-PL103	3.09720	6	1.9194E-07	9.6900E-05
182	CCX-PL703	3.09720	6	1.9194E-07	9.6900E-05
183	PL5XS000AFA	3.09670	6	1.9191E-07	8.0000E-05
184	CCX-IV-XR1	3.09470	6	1.9179E-07	2.4000E-05
185	CCX-PL1MOD1-SW	2.90607	4	1.8010E-07	1.1000E-05
186	CCX-PL7MOD1-SW	2.90607	4	1.8010E-07	1.1000E-05
187	ED1BEDS11P	2.64540	3	1.6394E-07	4.8000E-06
188	IWX-XMTRLW	2.33671	2	1.4481E-07	9.2000E-09
189	Z01DG001TM	1.46303	95	9.0668E-08	4.6000E-02
190	CCNTF101RI	1.44428	5	8.9505E-08	5.2300E-03
191	SWNTP001RI	1.44428	5	8.9505E-08	5.2300E-03
192	ED3MOD01	1.39106	10	8.6208E-08	5.0400E-04
193	ZANMOD01	1.18820	8	7.3636E-08	8.4000E-05
194	ZOK-FL-GP	1.14379	1	7.0883E-08	1.3000E-06
195	PL1MOD51	1.14367	2	7.0877E-08	8.7400E-04
196	ZOK-BL-ER	1.14338	1	7.0858E-08	1.3600E-06
197	RNAMOD06S	.934076	85	5.7887E-08	1.5300E-02
198	DAS	.852177	4	5.2812E-08	1.0000E-02
199	RC10R195SP	.745225	4	4.6184E-08	7.2200E-03
200	RC1TL195UF	.729819	3	4.5229E-08	5.2300E-03
201	PMAMCD41	.623610	34	3.8647E-08	6.3500E-04
202	REC-MANDAS	.596897	36	3.6991E-08	5.0000E-01
203	ED2MOD01	.572802	1	3.5498E-08	5.0400E-04
204	CCX-BC-SA	.542130	5	3.3597E-08	8.4000E-06
205	IDAMOD02	.538316	31	3.3361E-08	2.7000E-03
206	IDAMOD03	.538316	31	3.3361E-08	2.7000E-03
207	PMAEH0A1SAK	.435630	6	2.6997E-08	8.0000E-05
208	PMDMOD11	.428337	194	2.6545E-08	2.0900E-03
209	SWAMOD07	.419377	39	2.5990E-08	7.1200E-03
210	ED2MOD11	.271167	20	1.6805E-08	3.1700E-04
211	EC1MOD01	.262203	16	1.6249E-08	2.0200E-04
212	CCAMOD02	.251188	37	1.5567E-08	7.1000E-03
213	IDDMOD32	.238818	58	1.4800E-08	3.1700E-04
214	PMD0301ASA	.223974	125	1.3880E-08	1.1600E-03
215	PMD0301BSA	.201802	108	1.2506E-08	1.1600E-03
216	EC2MOD01	.200135	14	1.2403E-08	2.0200E-04
217	EC1REDG1GA	.175216	37	1.0859E-08	4.3600E-03
218	EC2BS002TM	.167826	178	1.0401E-08	2.7000E-03
219	EC2BS022TM	.167826	178	1.0401E-08	2.7000E-03
220	EC2BS221TM	.167826	178	1.0401E-08	2.7000E-03
221	PMDMOD41	.167282	67	1.0367E-08	6.3500E-04
222	RNAEPRNPSA	.165186	9	1.0237E-08	1.7100E-04
223	RNBEPRNPSA	.165186	9	1.0237E-08	1.7100E-04
224	Z01MOD03	.162775	8	1.0088E-08	1.0000E-04
225	PMDXS00ASA	.158891	32	9.8469E-09	8.0000E-05
226	PMDEH0A1SA	.157145	28	9.7387E-09	8.0000E-05
227	IDDMOD33	.155153	45	9.6152E-09	5.1600E-04
228	SW7EPSBPASA	.1.9009	7	8.6148E-09	1.7100E-04
229	OTH-R2	.138427	29	8.5787E-09	2.4000E-01
230	DG1-LOGIC	.130692	1	8.0993E-09	5.0000E-03
231	PMDMOD12	.128030	83	7.9343E-09	2.0900E-03
232	SWAMOD09P	.117456	22	7.2791E-09	1.8500E-03
233	CC1EPSPBPASA	9.812675E-02	6	6.0812E-09	1.7100E-04
234	Z02MOD03	9.506411E-02	5	5.8914E-09	1.0000E-04

235	IDDMOD38	8.4652888E-02	31	8.24628E-09	3.1700E-04
236	SW7EP5BPPBSA	8.2488068E-02	5	5.11208E-09	3.7100E-04
237	CC1EP5BPPBSA	8.2467118E-02	5	5.11078E-09	3.7100E-04
238	SW7EPCTPASA	7.4349248E-02	4	4.60758E-09	3.7100E-04
239	SW7EPCTPBSA	7.4349248E-02	4	4.60758E-09	3.7100E-04
240	PMD0302ASA	6.8257808E-02	46	4.23018E-09	3.1600E-03
241	SUC-R18	6.4543598E-02	152	3.99998E-09	3.8000E-01
242	EC2MOD22	6.0981898E-02	37	3.77928E-09	4.8000E-05
243	PL1X800ASA	6.0457478E-02	3	3.74678E-09	3.0000E-05
244	PL4X800ASA	6.0457478E-02	3	3.74678E-09	3.0000E-05
245	PL7X800ASA	6.0457478E-02	3	3.74678E-09	3.0000E-05
246	PMAMOD42	5.1119098E-02	4	3.16808E-09	3.3500E-04
247	EC1MOD13	4.7285228E-02	2	2.93048E-09	4.8000E-05
248	EC2MOD23	4.7285228E-02	2	2.93048E-09	4.8000E-05
249	PMD0302NSA	4.6086248E-02	29	2.85618E-09	3.1600E-03
250	SUC-R28	4.1034998E-02	9	2.54308E-09	7.6000E-01
251	PL4MOD12	2.6733858E-02	16	65688E-09	3.0900E-03
252	ED3BSDS1TM	2.6243228E-02	1	1.62648E-09	3.0000E-04
253	R_N-MAN03	2.3668568E-02	36	1.46688E-09	3.0000E-01
254	PL40302ASA	1.6359108E-02	7	1.01388E-09	3.1600E-03
255	CXK-XMTR	1.5255678E-02	3	9.45438E-10	3.0100E-04
256	ADX-MV-GO	1.5092038E-02	4	9.35298E-10	3.1000E-03
257	IDAMOD07	1.5073778E-02	15	9.34168E-10	3.1900E-02
258	PMDDMOD42	1.2366028E-02	11	7.61358E-10	3.3500E-04
259	CXK-TRNSM	1.1958598E-02	2	7.41108E-10	3.0100E-04
260	ZO2DG002TM	1.1705598E-02	42	7.25438E-10	4.6000E-02
261	PL40302BSA	1.1365768E-02	4	7.04378E-10	3.1600E-03
262	PL1MOD12	1.0829038E-02	7	6.71108E-10	3.0900E-03
263	PL7MOD12	1.0829038E-02	7	6.71108E-10	3.0900E-03
264	CCB-MAN01	1.0680548E-02	6	6.61908E-10	3.0000E-01
265	SWB-MAN02	7.5920718E-03	4	4.70508E-10	3.0000E-01
266	PLMMOD41	6.1463578E-03	2	3.80918E-10	3.3500E-04
267	PL10302ASA	6.1040068E-03	3	3.78288E-10	3.1600E-03
268	PL70302ASA	6.1040068E-03	3	3.78288E-10	3.1600E-03
269	PRAAV108LA	5.3620028E-03	11	3.32308E-10	3.0900E-03
270	PRBAV108LA	5.3620028E-03	11	3.32308E-10	3.0900E-03
271	ZON-MAN01	5.2152118E-03	7	3.23208E-10	3.0000E-01
272	PRAAV108TM	5.2070068E-03	9	3.22698E-10	3.0000E-04
273	PRBAV1087M	5.2070068E-03	9	3.22698E-10	3.0000E-04
274	PL10302BSA	4.7789268E-03	2	2.96168E-10	3.1600E-03
275	PL70302BSA	4.7789268E-03	2	2.96168E-10	3.1600E-03
276	IDDMOD34	4.5614318E-03	10	2.82688E-10	4.3200E-05
277	IDDMOD21	4.1979658E-03	6	2.60168E-10	3.9200E-04
278	PMDBH0A2SA	3.5826658E-03	10	2.22038E-10	3.0000E-05
279	DG2-LOGIC	3.0987308E-03	1	1.92048E-10	3.0000E-03
280	A12MOD01	2.3986878E-03	21	1.48658E-10	3.5400E-02
281	AF_JODD2	2.3986878E-03	21	1.48658E-10	3.5400E-02
282	AD3MOD03	2.3986878E-03	21	1.48658E-10	3.5400E-02
283	AD3MOD04	2.3986878E-03	21	1.48658E-10	3.5400E-02
284	IDABSDD1TM	1.7013918E-03	3	1.05448E-10	3.0000E-04
285	IDABSDK1TM	1.7013918E-03	3	1.05448E-10	3.0000E-04
286	EC2MOD221	1.2796748E-03	3	7.93008E-11	3.6800E-05
287	PRCEP108SA	1.0160438E-03	1	6.29678E-11	3.7100E-04
288	PRDEP108SA	1.0160438E-03	1	6.29678E-11	3.7100E-04
289	IDDMOD22	5.9554628E-06	3	3.69088E-13	3.7000E-03
290	IDDMOD23	5.9554628E-06	3	3.69088E-13	3.7000E-03
291	IDDMOD35	4.1605758E-06	4	2.57848E-13	3.1900E-02
292	RN23MOD58	.000000	875	0.00000E+00	1.0000E+00
293	IWACV122AO	.000000	126	0.00000E+00	1.0000E+00
294	IWACV124AO	.000000	126	0.00000E+00	1.0000E+00

JDEC REQUEST FOR ADDITIONAL INFORMATION

Reactor Coolant System



SCS	SLR	ADS	CI	GEMS
SCS	SLR	ADS	CI	GEMS



Event
RCI DRYDOWN, Boeing Status-Data 10 MELD-300
MANUAL 150 ALL REL LINE
GEMs INERTION
GEMs INITIATION RELAY 1605: via SRS SOURCE LINE
4th Stage ADS Activated


Description
RCI DRYDOWN, Boeing Status-Data 10 MELD-300
MANUAL 150 ALL REL LINE
GEMs INERTION
GEMs INITIATION RELAY 1605: via SRS SOURCE LINE
4th Stage ADS Activated

Overdraining of Reactor Coolant System During Drydown to Mid-Loop

54B-1
Figure 720-303(01)-74



AP600



Law of Other Power (RCS Drafted) Event Tree

Figure 54B-2


Westinghouse

MODERNIZATIONAL REVOLUTIONS IN COGNITION

卷之三



四



565

LOSS OF ROSS OPERATIONS DURING GRAINED MAINTENANCE (WILL-LEOPOLD, 1946)

GRAVITY INJECTION

GRAVITY INJECTION FROM IRUST VIA RGS SKID LINE

WELL STAGGER AND ACTIVATION

List of DNS Leader (RCS-Directed) Event Tree

Figure 54B-3

卷之八

TRAC PROBLEMS FOR ADDITIONAL INFORMATION

Response Function -



Description:
LOSS OF CCW/ISW INITIATOR (RCS DRIVEN)
GRAVITY INJECTION
GRAVITY INJECTION FROM INLET VIA RDS SUCTION - 14C
470 STAGE RDS ACTUATION AND
ADS

Loss of CCW/ISW Initiator (RCS Driven) Event Tree

54B-4
Figure 220-202-4



-722-293(RH)-79-

HOA REQUEST FOR ADDITIONAL INFORMATION

Response Revision-4

AP600



Event:
- v024t
G1
G1BDS
ABS

Descriptor:
LOCA THROUGH RCS-V024 DURING DRAINED MAINTENANCE
GRANIT: INJECTION
GRANIT: INJECTION FROM 100%ST via RDS SECTION LINE
4TH STAGE RDS ACTUATION

LOCARNS-V024 Open (RCS Drained) Event Tree

548-5
Figure 220-203-00-00



**Enclosure 2 to Westinghouse
Letter DCP/NRC1057**

September 26, 1997

REVISION TO PRA PAGE 54A-6

This sensitivity is performed by modifying the following basic events in the quantification output file:

IWACV122AO = 1.0; IWACV123AO = 5.8E-04; IWACV124AO = 1.0;
IWACV125AO = 5.8E-04; IWBCV122AO = 1.75E-03; IWBCV123AO = 5.8E-04;
IWBCV124AO = 1.75E-03; IWBCV125AO = 5.8E-04; IWX-CV-AO = 5.4E-07 3.1E-05; IWX-MV-GO1 = 1.0E-05 3.8E-05; IRWMOD05S = 0; and IRWMOD06S = 0.

Requantification of the cutset file with these changes provides a core damage frequency of 4.8E-07 2.0E-07 events per year. Since this evaluation is a sensitivity study of the main exercise in assessing the reliability of the new IRWST design, the output file for this case is not included in this report.

This estimate of the core damage frequency at shutdown is believed to be conservative for the following reasons:

- One train of the IRWST is assumed to fail during both drained and non-drained conditions.
- Approximately 67.61 percent of the core damage frequency of 4.8E-07 2.0E-07 events per year is attributed to dominant failures that include failure of the IRWST injection line strainer; (i.e., the top two cutsets total 1.2E-07, and these cutsets include basic event IWB-PLUG).
- The IRWST water is considered to be clean water, suitable for injection into the RCS.
- The IRWST is covered to preclude material that could clog the strainer from entering the tank.
- The IRWST strainer is assigned a conservative failure probability of 2.4E-04 in Revision 6 of the PRA. The plugging of the IRWST strainer is expected to be a much less probable event than reflected in a failure probability of 2.4E-04.

Therefore, failure of the IRWST line strainer is more dominant than would be expected for failure of a strainer in a clean water system. If a more realistic failure probability is used for strainer plugging, the resulting core damage frequency of the model having a single IRWST train configuration should be much closer to the core damage frequency of 5.5E-08 events per year. This is obtained from the baseline shutdown model of PRA, Revision 6.

54A.2 IRWST Recirculation Paths Changed from 10-inch and 4-inch Lines to 6-inch Lines

This design change has no impact on the shutdown core damage frequency calculation, since the recirculation function is not credited in the Level 1 shutdown PRA. (See note in Section 54A.3 below).