


MULLION CORNER
*STANDARD



MITRE CORNER
*AVAILABLE




STANDARD CONSTRUCTION	
BLADE STYLE:	6" (152 mm) DEEP STORMPROOF BLADES
CORNER STYLE:	MULLION CORNER (BOX CORNER)
MATERIAL:	EXTRUDED ALUMINUM – 6063-T5 ALLOY
FRAME THICKNESS:	0.085" (2.16 mm)
BLADE THICKNESS:	0.081" (2.06 mm)
BLADE ANGLE:	45°
BLADE CENTRES:	7.25" (184 mm)
BIRDSCREEN:	19 GA. GALVANIZED BIRDSCREEN - 1/2" x 1/2" OPENINGS
FINISH:	MILL
ROOF INSULATION:	FACTORY APPLIED ANTI-CONDENSATE COATING

SIZE LIMITATIONS		
	MINIMUM	MAXIMUM
THROAT $T_L \times T_W$	12" x 12" (305 x 305 mm)	CONSULT VENTEX
CURB CAP ID $C_L \times C_W$	24" x 24" (610 x 610 mm)	
PENTHOUSE OD $P_L \times P_W$	24.125" x 24.125" (613 x 613 mm)	
HEIGHT	16" (406 mm)	

*PENTHOUSE WILL BE MANUFACTURED EXACT SIZE UNLESS OTHERWISE SPECIFIED
*RECOMMENDED CURB SIZE = CURB CAP ID – 1 1/2" (38 mm)

AVAILABLE ACCESSORIES	
FINISH:	SCREENS:
<ul style="list-style-type: none"> • BAKED ENAMEL FINISH • DURANAR FINISH • ANODIZED FINISH <ul style="list-style-type: none"> ○ CLEAR ANODIZED ○ LIGHT BRONZE ○ MEDIUM BRONZE ○ DARK BRONZE ○ BLACK ANODIZED 	<ul style="list-style-type: none"> • BIRDSCREEN <ul style="list-style-type: none"> ○ 1/2" x 1/2" INTER CRIMPED ALUMINUM ○ ALUMINUM BIRDSCREEN WITH FRAME • INSECT SCREEN <ul style="list-style-type: none"> ○ 18 x 14 MESH
OTHER:	BLANK-OFF PANELS (ALUMINUM): VARIOUS GAUGES
<ul style="list-style-type: none"> • MITRE CORNER • EXTENDED SILLS • SECURITY BARS • FILTER RACKS • STAINLESS STEEL FASTENERS • HINGED ROOF • HINGED ACCESS DOORS • ALL WELDED CONSTRUCTION • CONTROL DAMPERS / BACK DRAFT DAMPERS FOR THROAT 	<ul style="list-style-type: none"> • NON-INSULATED BLANK-OFF PANELS • INSULATED BLANK-OFF PANELS <ul style="list-style-type: none"> ○ 1" (25.4 mm) INSULATION ○ 2" (50.8 mm) INSULATION



TAG	QTY.	THROAT SIZE $T_L \times T_W$	CURB CAP ID $C_L \times C_W$	PENTHOUSE OD $P_L \times P_W$	HEIGHT	ACCESSORIES
		x	x	x		
		x	x	x		
		x	x	x		
		x	x	x		
		x	x	x		

THROAT SIZE + 12" (305 mm) THROAT SIZE + 12.125" (308 mm)

PROJECT NAME:		ENGINEER:	
CONTRACTOR:		SUBMITTAL DATE:	