



06/02/05

Mr. David Cline  
 Compliance Data Section (IDEM)  
 100 North Senate Avenue  
 P.O. Box 6015  
 Indianapolis, Indiana 46206-6015

RE: Emissions Test Summary  
 (Nucor Steel – PPF Baghouses)

Dear David,

Air Analysis, Inc. and Air Test Professionals, Inc. were contracted by Nucor Steel to perform air emissions sampling of their Positive Pressure Fabric Filter (PPFF) Baghouse #1 and #2, respectively. The testing was performed at the Crawfordsville, Indiana facility on April 18-19, 22, 2005. The objective of the testing was to determine compliance with 40CFR60, Subpart AAa for Particulate Matter (PM) emissions including Condensable Particulate Matter (CPM), Volatile Organic Compound (VOC) emissions, and Metals emissions.

The testing program included flow and gas analysis (US EPA Methods 1-4), particulate (US EPA Method 5/5D), condensable particulate matter (US EPA Method 202), volatile organic compound emissions (US EPA Method 25A), and metals emissions (US EPA Method 29). Listed below is a summary of the results.

Pollutant	PPFF Baghouse #1	PPFF Baghouse #2	Source Emissions
Lead	0.012 (lbs/hr)	0.002 (lbs/hr)	0.014 (lbs/hr - Pb)
Mercury	< 0.008 (lbs/hr)	< 0.016 (lbs/hr)	0.024 (lbs/hr - Hg)
Filterable (TSP)	0.0006 (gr/dscf)	0.0003 (gr/dscf)	0.0005 (gr/dscf)
+ Condensable (CPM)	0.0009 (gr/dscf)	0.0007 (gr/dscf)	0.0008 (gr/dscf)
Volatile Organic Compounds	0.00 (lbs/ton)	0.027 (lbs/ton)	0.027 (lbs/ton)

12-1-05  
SKE  
HD.

# Indiana Air Permit Compliance Testing

## NUCOR STEEL CORPORATION

EAF/Melt Shop PPF Baghouse, Crawfordsville, IN

Report on:

Particulates/PM10, Volatile Organic Compounds, Lead, Mercury

Performed by:

ΔAir Analysis, Inc.

Project Number: 302

April 18, 19, 22, 2005

(IDEM  
COPY)

ΔAir Analysis, Inc.

3904 Clarks Creek Road • Plainfield, Indiana • 46168

317.837.8514

877.683.TEST

# ΔAir Analysis, Inc.

3904 Clarks Creek Road • Plainfield, Indiana 46168  
Tel. 317 837-8514 Fax. 317 837-8518

## Certification Page

Air Analysis, Inc. represents that the information provided in this report is true and accurate. We at Air Analysis, Inc. strive to remain true to our mission, that the people involved are people of integrity, the data accurate, and the reporting timely.

Sincerely,



Michael M. Dicen, President  
Air Analysis, Inc.

Date: 6-20-05



**Executive Summary**

Air Analysis, Inc. was contracted by Nucor Steel to perform air emissions sampling of the EAF/Melt Shop Positive Pressure Fabric Filter (PPFF) Baghouse located in Crawfordsville, Indiana, on April 18,19 and 22, 2005. The objective of the test program was to determine compliance with Indiana air permit requirements and 40CFR60, Subpart AAa. Sampling was performed for Particulate Matter (PM), Lead, Mercury and Volatile Organic Compounds (VOC). Visible emissions were also read during the above listed testing. In addition the same pollutants were tested simultaneously at the new Baghouse # 2 by Air Test Professionals, Inc. The combination of the two baghouses control emissions from the EAF/Melt Shop. The following personnel were involved with the testing program:

Air Analysis	Mike Dicen
Air Analysis	Marcus Allen
Air Analysis	Ron Stappert
Air Test Professionals, Inc.	Carlos Brown
IDEM	Steve Friend
Nucor Steel	Mark Washer

The testing program was performed utilizing US EPA Methods 1-4, 5D, 202, 29, 25A and 9.

**Test Summary  
Table 1**

Pollutant	Location	Emissions Rate (Avg.) lbs/hr	Pollutant Concentration gr/dscf
Lead	PPFF Baghouse	0.0121 (Pb)	0.00000118 (Pb)
Mercury		0.008 (Hg)	0.00000079 (Hg)
VOC		0.0	0.0 ppm

Pollutant	Location	Filterable PM Concentration	PM/PM10 Filterable & Condensable Concentration
Particulate	PPFF Baghouse	0.0006 (gr/dscf)	0.0009 (gr/dscf)



**VISIBLE EMISSIONS**

**Table 1-2**

Date	Time	Source	Opacity (EPA RM 9)
04/18/05 04/19/05 4/22/05	12:47 – 13:47 8:20 -16:45 8:33-14:14	Melt Shop	0%
04/18/05 04/19/05 4/22/05	12:47 – 13:47 8:20 -16:45 8:33-14:14	East Baghouse Roof Monitors	0%
04/18/05 04/19/05 4/22/05	12:47 – 13:47 8:20 -16:45 8:33-14:14	West Baghouse Roof Monitors	0%

**Results**

**PM/PM10 Test Conditions**

**Table 2-1**

<b>Gas Conditions</b>		<b>1</b>	<b>2</b>	<b>3</b>	<b>Avg</b>
Ts	Stack Temperature	166.2	174.4	151.6	164.07
Bwo	Moisture (volume %)	1.78	2.69	1.79	2.09
O2	Oxygen (dry volume %)	21	21	21	21
CO2	Carbon Dioxide (dry volume %)	0	0	0	0
<b>Volumetric Flow Rate</b>					
Qa	Actual Conditions (acfm)	1,409.446	1,425.294	1,366.239	1,400.327
Qstd	Standard Conditions (dscfm)	1,180.006	1,166.944	1,171.136	1,172.695
<b>Pollutant Results</b>					
Ec	Emission Rate, (gr/dscf) PM	0.0008	0.0006	0.0004	0.0006
E(me)	Emission Rate, (lbs/hr) PM	8.00	5.8	4.3	6.0
Ec filter + condensible	Emissions Rate, (gr/dscf) PM10	0.0013	0.0006	0.0008	0.0009

**METALS and VOC EMISSIONS**

**Table 2-2**

<b>Gas Conditions</b>		<b>1</b>	<b>2</b>	<b>3</b>	<b>Avg</b>
Ts	Stack Temperature	166.2	141.6	174.4	160.8
Bwo	Moisture (volume %)	3.85	2.29	1.99	2.71
O2	Oxygen (dry volume %)	21	21	21	21
CO2	Carbon Dioxide (dry volume %)	0	0	0	0
<b>Volumetric Flow Rate</b>					
Qa	Actual Conditions (acfm)	1,414.994	1,401.034	1,424.305	1,413.444
Qstd	Standard Conditions (dscfm)	1,206.092	1,214.572	1,174.947	1,198.537
<b>Pollutant Results</b>					
Er	Emission Rate, (lbs/hr) Lead	0.0012	0.0126	0.0225	0.00121
Er	Emission Rate, (lbs/hr) Mercury	0.0061	0.012	0.0064	0.0082
ErVOC	Emission Rate, (lbs/hr) VOC	0	0	0	0

**NOTE:** For Particulates and Metals testing, velocity head setting for Method 5D compartment test runs were derived from Inlet volumetric flow rates. Flow rate calculations were corrected for compartment conditions: temperature, moisture and gas analysis.  
A minimum of 160 dscf at 288 minutes was sampled during each test period.

**NOTE:** Metals emissions are based on total baghouse (16 compartment) volumetric flow rates for the calculation of mass emissions (lb/hr). Two hour sample periods were taken.

**Table 3**

**EAF (PPFF) Baghouse Diagram**

1. Nucor Steel PPFF baghouse consists of 16 compartment housing with an area of 366" d x 260" w per compartment
2. Testing was conducted at 12 of the 16 compartment housings
3. Three (3) sample runs were conducted at four compartments per sample run.  
Total area of the baghouse is 366" d x 4160" w.

Compartment unsampled	Compartment unsampled	Compartment # 6 Run 2B PM Run 2 A Metals	Compartment #5 Run 2A PM Run 1D Metals	Compartment # 4 Run 1D PM Run 1C Metals	Compartment # 3 Run 1C PM Run 1B Metals	Compartment # 2 Run 1B PM Run 1A Metals	Compartment # 1 Run1 A PM Run 3D Metals
Roof monitor area							
Compartment unsampled	Compartment unsampled	Compartment # 7 Run 2C PM Run 2 B Metals	Compartment # 8 Run 2D PM Run 2C Metals	Compartment # 9 Run 3A PM Run 2 D Metals	Compartment # 10 Run 3B PM Run 3 A Metals	Compartment # 11 Run 3C PM Run 3 B Metals	Compartment # 12 Run 3D PM Run 3 C Metals

### **3-1 PROCESS DESCRIPTION**

Nucor steel operates a meltshop, which is comprised of the following process units: Two (2) EAF units, one (1) ladle metallurgy station, one (1) AOD with two (2) continuous casters. Of these, the two EAF units, the AOD, and the two caster units, each is evacuated through the meltshop positive pressure baghouse and the new baghouse.

The EAF units melt various grades of scrap metal, scrap substitute, pebbled lime, and coke into molten steel. The molten steel is refined into various grades of carbon steel at the ladle metallurgy station or refined into stainless steel at the AOD. The molten steel from the ladle metallurgy station or AOD is cast into continuous strips at the two continuous casters.

The emissions from the EAF units, AOD and casters are generated from melting, refining, charging, tapping and casting operations and are captured in a direct shell evacuation (DEC) system and overhead canopy hoods. All captured emissions are evacuated through the positive pressure fabric filter (PPFF) baghouse compartments.

The testing reported in this document was performed at 12 of the 16 EAF (PPFF) baghouse compartments.

---

**Methodology**

The sampling procedures used by Air Analysis, Inc. are as follows:

**Title 40 CFR Part 60 Appendix A**

Method 1 “Sampling of Velocity Traverses for Stationary Sources”

Method 2 “Determining of Stack Gas Velocity and Volumetric Flow Rate”

Method 3 “Gas Analysis for the Determination of Molecular Weight”

Method 4 “Determination of Moisture Content in Stack Gas”

Method 5D “Determining of Particulate Emissions from PPF Sources”

Method 29 “Determination of Metals Emissions from Stationary Sources”

Method 25A “Determination of Volatile Organic Compounds from Stationary Sources, Analyzer Method”

Method 9 “Visual Determination of the Opacity Emissions”

**Title 40 CFR Part 51 Appendix M**

Method 202 “Determination of Condensable Emissions from Stationary Sources”

**SAMPLE POINT DETERMINATION-EPA METHOD 1**

Sampling point locations were determined according to EPA Reference Method 1.

<b>Locations</b>	<b>Dimensions</b>	<b>Points / Ports</b>	<b>Total Points</b>
Inlet	14.67’W x 23.13’	4/ 8	32
Compartment (ea)	21.67’ x 30.50’	6	12

\*\* Exact measure points and distances to disturbances are listed in Appendix- Field Data

**VELOCITY AND VOLUMETRIC FLOW RATE – EPA METHOD 2**

EPA Method 2 was used to determine the gas velocity and flow rate at the stack. Figure 4-2 includes the components of the EPA Method 2 sampling apparatus. Each set of velocity determinations included the measurement of gas velocity pressure and gas temperature at each of the Method 1 determined traverse points. The velocity pressures were measured with a Type S pitot tube. Gas temperature measurements made with a Type K thermocouple and digital pyrometer.

**GAS COMPOSITION AND MOLECULAR WEIGHT – EPA METHOD 3**

In order to determine the oxygen and carbon dioxide concentrations, a sample of gas was obtained and analyzed in accordance with EPA Method 3. The gas sample was collected using a Fyrite analyzer. The results were used to determine gas molecular weight.

**MOISTURE CONTENT – EPA METHOD 4**

The flue gas moisture content at the testing locations was determined in accordance with EPA Method 4. Figure 4-2 includes the Method 4 sampling components. The gas moisture was determined by quantitatively condensing moisture in the chilled impingers and silica absorption. The amount of moisture condensed was determined gravimetrically. A dry gas meter was used to measure the volume of gas sampled. Moisture content is used to determine stack gas velocity.

### **PARTICULATE DETERMINATION – EPA METHOD 5/202**

Stack gas is withdrawn isokinetically and particulate matter is collected on the nozzle, probe and filter. The probe temperature and filter are maintained at temperatures of 248 degrees F (+/- 25 deg. F). The impinger temperature and exit gas is maintained at temperatures at or below 68 degrees F. The nozzle, probe and glass filter containers are rinsed with acetone and the rinse is captured in a sealed glass container. (Method 202 only) The impingers and connecting glassware are rinsed twice with de-ionized water and captured in a sealed container. Two rinses of methylene chloride are captured and stored in a sealed glass container

### **VOC DETERMINATION – EPA METHOD 25A**

Stack gas is withdrawn at a constant sample rate through a heated sample line and glass fiber filter to a flame ionization analyzer. Hydrogen is used as fuel as well as air is used for oxidation. Probe temperature and filter are maintained at temperatures of 248 degrees F (+/- 25 deg. F). Intensity of the flame when the organics are oxidized is directly proportional to the organic concentration. VOC is determined as volume concentration equivalents of the calibration gas or as carbon equivalents. EPA protocol gas as high concentration is introduced to the analyzer and allowed to set the high span at the concentration level. Thirty percent and fifty percent of span gases are introduced to the analyzer to check for linearity. Zero gas is used to purge and level off the analyzer when no organics are present.

### **Metals DETERMINATION – EPA METHOD 29**

Stack gas is withdrawn isokinetically and particulate matter is collected in glass/quartz nozzle, probe and filter. The probe temperature and filter are maintained at temperatures of 248 degrees F (+/- 25 deg. F). The impinger temperature and exit gas is maintained at temperatures at or below 68 degrees F. Metals are caught in the nozzle, probe, filter and glassware and backhalf impingers. The first two impingers contain 100 mls each of HNO<sub>3</sub>/ H<sub>2</sub>O<sub>2</sub>. The next impinger is empty. The next two impingers contain 100 mls each of acidic KMNO<sub>4</sub>. The nozzle, probe and glass filter containers are rinsed with water/ HNO<sub>3</sub> and the rinse is captured in a sealed glass container. The impingers and connecting glassware are rinsed twice with the absorbent solutions and water and captured in a sealed container.

### **OPACITY – EPA METHOD 9**

Stack opacity readings are taken for 60 minutes at 15 second intervals *for NSPS* and 30 minutes at 15 intervals for *state permitted, non-federal sources*, by a certified visible emissions reader. The visible emissions reading are conducted during each of the particulate test runs. The results are reported as an average opacity reading for the half an hour period. A copy of the visible reader's current certification is included in the Appendix.

ΔAir Analysis, Inc.

NUCOR

Project Number: 302

**APPENDIX I**

**SAMPLE CALCULATIONS**

---




Figure 5-1. Metals & Particulate Sampling Train



## SAMPLE CALCULATIONS

The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

### 1. Volume of water collected (wscf)

$$V_{wscf} = (0.04707)(V_{lc})$$

Where:

$V_{lc}$	total volume of liquid collected in impingers and silica gel (ml)
$V_{wscf}$	volume of water collected at standard conditions (ft <sup>3</sup> )
0.04707	conversion factor (ft <sup>3</sup> /ml)

### 2. Volume of gas metered, standard conditions (dscf)

$$V_{dscf} = \frac{(17.64)(V_m)(P_{baro} + \frac{\Delta H}{13.6})(Y_d)}{(460 + T_m)}$$

Where:

$P_{baro}$	barometric pressure (in Hg)
$T_m$	average dry gas meter temperature (°F)
$V_m$	volume of gas sample through dry gas meter at meter conditions (ft <sup>3</sup> )
$V_{dscf}$	volume of gas sample through dry gas meter at standard conditions (ft <sup>3</sup> )
$Y_d$	gas meter correction factor (dimensionless)
$\Delta H$	average pressure drop across meter box orifice (in H <sub>2</sub> O)
17.64	conversion factor (°R/in Hg)
13.6	conversion factor (in H <sub>2</sub> O/in Hg)
460	°F to °R conversion constant

### 3. Sample gas pressure (in Hg)

$$P_s = P_{baro} + \left(\frac{P_g}{13.6}\right)$$

Where:

$P_{baro}$	barometric pressure (in Hg)
$P_g$	sample gas static pressure (in H <sub>2</sub> O)
$P_s$	absolute sample gas pressure (in H <sub>2</sub> O)
13.6	conversion factor (in H <sub>2</sub> O/in Hg)

4. Actual vapor pressure (in Hg)

$$P_v = P_s$$

Where:

$P_v$  vapor pressure, actual (in Hg)  
 $P_s$  absolute sample gas pressure (in Hg)

5. Moisture Content (%)

$$B_{wo} = \frac{V_{wstd}}{V_{std} + V_{wstd}}$$

Where:

$B_{wo}$  proportion of water vapor in the gas stream by volume  
 $V_{std}$  volume of gas sample through the dry gas meter at standard conditions (ft<sup>3</sup>)  
 $V_{wstd}$  volume of water collected at standard conditions (ft<sup>3</sup>)

6. Saturated moisture content (%)

$$B_{ws} = \frac{(P_v)}{(P_s)}$$

Where:

$B_{ws}$  proportion of water vapor in gas stream by volume at saturated conditions (%)  
 $P_v$  vapor pressure, actual (in Hg)  
 $P_s$  absolute sample gas pressure (in Hg)

7. Molecular weight of dry gas stream (lb/lb-mole)

$$M_d = M_{CO_2} \frac{(CO_2)}{(100)} + M_{O_2} \frac{(O_2)}{(100)} + M_{CO+N_2} \frac{(CO+N_2)}{(100)}$$

Where:

$M_d$  dry molecular weight of sample gas (lb/lb-mole)  
 $M_{CO_2}$  molecular weight of carbon dioxide (lb/lb-mole)  
 $M_{O_2}$  molecular weight of oxygen (lb/lb-mole)  
 $M_{CO+N_2}$  molecular weight of carbon monoxide and nitrogen (lb/lb-mole)  
 $CO_2$  proportion of carbon dioxide in the gas stream by volume (%)  
 $O_2$  proportion of oxygen in the gas stream by volume (%)  
 $CO + N_2$  proportion of carbon monoxide and nitrogen in gas stream by volume (%)  
 $100$  conversion factor, %

8. Molecular weight of sample gas (lb/lb-mole)

$$M_s = (M_d)(1 - B_{wv}) + (M_{H_2O})(B_{wv})$$

Where:

Md	dry molecular weight of sample gas (lb/lb-mole)
B <sub>wv</sub>	proportion of water vapor in the gas stream by volume
M <sub>H<sub>2</sub>O</sub>	molecular weight of water (lb/lb-mole)
Ms	molecular weight of sample gas, wet basis (lb/lb-mole)

9. Velocity of sample gas (ft/sec)

$$V_s = (K_p)(C_p)(\sqrt{\Delta p}) \sqrt{\frac{t_s + 460}{(M_s)(P_s)}}$$

Where:

Kp	velocity pressure coefficient (dimensionless)
Cp	pitot tube constant
Ms	molecular weight of sample gas, wet basis (lb/lb-mole)
P <sub>s</sub>	absolute sample gas pressure (in. Hg)
t <sub>s</sub>	average sample gas temperature (°F)
V <sub>s</sub>	average sample gas velocity (ft/sec)
460	°F to °R conversion factor

10. Total flow of sample gas (acfm)

$$Q_s = (60)(A_s)(V_s)$$

Where:

A <sub>s</sub>	cross section area of sampling location (ft <sup>2</sup> )
Q <sub>s</sub>	volumetric flow rate at actual conditions (acfm)
V <sub>s</sub>	sample gas velocity (ft/sec)
60	conversion factor, seconds to minutes

11. Total flow of sample gas (dscfm)

$$Q_{std} = \frac{(Q_a \times P_s \times 17.64 \times (1 - B_{wo}))}{(t_s + 460)}$$

Where:

Bwo	proportion of water vapor in the gas stream by volume
P <sub>s</sub>	absolute sample gas pressure (in. Hg)
Q <sub>a</sub>	volumetric flow rate at actual conditions (acfm)
Q <sub>std</sub>	volumetric flow rate at standard conditions (dscfm)
t <sub>s</sub>	average sample gas temperature (°F)
17.64	conversion factor, (°R/in.Hg)
460	°F to °R conversion factor

12. Total flow of sample gas (dscfh)

$$Q_{std/hr} = \left[ \frac{(Q_a \times P_s \times 17.64 \times (1 - B_{wo}))}{(t_s + 460)} \right] (60)$$

Where:

Bwo	proportion of water vapor in the gas stream by volume
P <sub>s</sub>	absolute sample gas pressure (in. Hg)
Q <sub>a</sub>	volumetric flow rate at actual conditions (acfm)
Q <sub>std/hr</sub>	volumetric flow rate at standard conditions (dscfm x 60)
t <sub>s</sub>	average sample gas temperature (°F)
17.64	conversion factor, (°R/in.Hg)
460	°F to °R conversion factor

13. Percent Isokinetic (%)

$$I = \frac{(0.09450)(T_s)(V_{std})}{(P_s)(V_s) \left( \frac{D_n^2(\pi)}{(144)(4)} \right) (t)(1-B_w)}$$

Where:

D <sub>n</sub>	diameter of nozzle, inches
B <sub>w</sub>	proportion of water vapor in the gas stream by volume
I	percent of isokinetic sampling (%)
P <sub>s</sub>	absolute sample gas pressure (in. Hg)
T <sub>s</sub>	average sample gas temperature (°R)
V <sub>std</sub>	volume of gas sample through the dry gas meter at standard conditions (ft <sup>3</sup> )
V <sub>s</sub>	average sample gas velocity (ft/sec)
t	total sample time, minutes
0.09450	constant

14. Pollutant concentration (gr/dscf)

$$C_{gr/dscf} = \frac{(15.43)(m_p)}{V_{std}}$$

Where:

C <sub>gr/dscf</sub>	measured concentration in gas stream, gr/dscf
M <sub>p</sub>	pollutant collected, corrected for reagent blank, grams
V <sub>std</sub>	volume of gas sample through the dry gas meter at standard conditions (ft <sup>3</sup> )
15.43	conversion factor, grams to grains

15. Pollutant Emissions, Mass Emissions Rate lbs/hr

$$E_{lb/hr} = \frac{(\mu g_{HCl})(2.2046e-9)(Q_{std})(60)}{(V_{std})}$$

Where:

E <sub>lb/hr</sub>	Mass emissions rate, pounds per hour
μg pollutant	micrograms of pollutant emissions
Q <sub>std</sub>	volumetric flow rate at standard conditions, dry basis (dscfm)
V <sub>std</sub>	Volume Standard conditions
2.2046e-9	conversion factor, pounds per microgram
60	conversion factor, minutes per hour

ΔAir Analysis, Inc.

NUCOR

Project Number: 302

**APPENDIX II**

**FIELD DATA PRINTOUTS**

---

**STACK EMISSION SUMMARY**

SOURCE TESTED: PPF Baghouse  
 COMPANY NAME: Nucor Steel  
 DATE OF TEST: 04/18/05

Particulate Concentration	Run 1	Run 2	Run 3	Average
Filterable (gr/dscf)	0.0008	0.0006	0.0004	0.0006
Filterable (lbs/hr)	8.0078	5.7770	4.2822	6.0223
Condensable (lbs/hr)	4.7665	0.4311	3.3009	2.8328
Filterable + Consensible (lbs/hr)	12.7743	6.2081	7.5831	8.8552
Filterable + Consensible (gr/dscf)	0.0013	0.0006	0.0008	0.0009

2.739  
 0.093

**Avg. Stack Vol. Flow Rate**

ACFM	1409446.28	1425294.064	1366239.54	1400326.628
DSCFM	1180005.586	1166943.771	1171136.419	1172695.259

Avg. Stack Temp.	166.233	174.400	151.570	164.068
Stack Gas Velocity	2.222	2.247	2.154	2.207

Avg. Velocity Head	0.0013	0.0013	0.0013	0.0013
Avg. Sq. Rt of Delta P	0.0363	0.0364	0.0356	0.0361

**ISOKINETIC TESTING SUMMARY**

%Isokinetics:	93.43	103.30	99.83	98.85
Allowable isokinetic 90-110%				
% Moisture of Stack Gas	1.78%	2.69%	1.79%	2.09%
Sample Volume	163.732	179.021	173.644	172.132

**COMPANY NAME:** Nucor Steel  
**LOCATION:** Crawfordsville  
**SOURCE TESTED:** PPF Baghouse  
**DATE OF TEST:** 04/18/05  
**RUN NO.:** 1  
 Particulate

**FIELD DATA**

K - Factor = 990.00

**Start Time** 12:50  
**Stop Time** 19:58

**Molecular Weight of Stack Gas, Dry Basis, Md**  
 %CO2 0  
 %O2 21  
 Md 28.84

**Volume of Water Vapor Collected @ STD. COND., Vwv**  
 Vtc 53  
 Vw(std) 2.964

**Volume of Dry Gas Collected @ STD. COND., Vm(std)**  
 Tm(F) 129.865  
 Vm 167.680  
 P0(Inches Hg) 30.146  
 delta H 1.307  
 gamma 0.961  
 Vm(std) 163.732

**Moisture Content of Stack Gas, Bwo**  
 Bwo 1.78%  
 1-Bwo 98.22%

**Molecular Weight of Stack Gas, Ms**  
 Ms 28.85

**Area of Stack (enter diameter in inches), As**  
 Depth-In 365  
 Width-In 4160  
 diameter 0  
 No. of Stacks 1  
 As(L<sup>2</sup>W) 10573.33333  
 As(dia.) 0

**Static Pressure, Ps**  
 Static 0.000  
 Ps 30.14

**Stack Gas Velocity, Vs, fps**  
 Cp 0.84  
 sq(delta p) 0.036  
 Ts 166.233  
 Vs 2.222

0.00122

**Stack Gas Flowrate, Qs, acfm**  
 As 10573.33333  
 Qs 1409446

**Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd**  
 Qstd (dscfm) = 1180005.59  
 Qstd (dscf/hr) = 70800335.16

**Velocity at the Nozzle, Vn**

Dia. of Nozzle  
 Time of Run 268  
 Vn 2.08

An(nozzle): 0.005454

**% Isokinetic, %I**

%I 93.43  
 % Isokinetic measured from intermediate values  
 %I 93.79

**Pollutant Mass Emission Rate, PMR, lbs./hr.**

Mn (g) = 0.0084 0.0050 0.0134  
 PMR (lb/hr) = 8.0078 4.7865 12.7743  
 PMR (lb/MMBtu) = -0.2312 0.0000 -0.2312  
                     Filterable Condensable Total

**Grains per acf**  
 g/acf = 0.0007 0.0004

**Grains per dscf**  
 g/dscf = 0.0008 0.0005 0.0012628

**Grains per mg/dscf**  
 mg/dscf = 0.8831 0.6831

Run	Delta P	Square Delta P	Volume	Delta H	Stack Temp	DGM	DGM
1	0.00132	0.036	1.307	166.23	100		101
2	0.00132	0.036	1.307	166.233	102		102
3	0.00132	0.036	1.307	166.233	104		103
4	0.00132	0.036	1.307	166.233	104		103
5	0.00132	0.036	1.307	166.233	100		103
6	0.00132	0.036	1.307	166.233	103		99
7	0.00132	0.036	1.307	166.233	104		98
8	0.00132	0.036	1.307	166.233	107		98
9	0.00132	0.036	1.307	166.233	108		99
10	0.00132	0.036	1.307	166.233	107		100
11	0.00132	0.036	1.307	166.233	108		101
12	0.00132	0.036	1.307	166.233	108		101
13	0.00132	0.036	1.307	166.233	108		104
14	0.00132	0.036	1.307	166.233	108		103
15	0.00132	0.036	1.307	166.233	110		104
16	0.00132	0.036	1.307	166.233	110		104
17	0.00132	0.036	1.307	166.233	110		103
18	0.00132	0.036	1.307	166.233	107		103
19	0.00132	0.036	1.307	166.233	108		103
20	0.00132	0.036	1.307	166.233	109		102
21	0.00132	0.036	1.307	166.233	108		102
22	0.00132	0.036	1.307	166.233	108		102
23	0.00132	0.036	1.307	166.233	109		102
24	0.00132	0.036	1.307	166.233	110		102
25	0.00132	0.036	1.307	166.233	1111		102
26	0.00132	0.036	1.307	166.233	112		106
27	0.00132	0.036	1.307	166.233	112		107
28	0.00132	0.036	1.307	166.233	115		107
29	0.00132	0.036	1.307	166.233	115		106
30	0.00132	0.036	1.307	166.233	110		108
31	0.00132	0.036	1.307	166.233	117		109
32	0.00132	0.036	1.307	166.233	118		110
33	0.00132	0.036	1.307	166.233	118		110
34	0.00132	0.036	1.307	166.233	118		1112
35	0.00132	0.036	1.307	166.233	119		112
36	0.00132	0.036	1.307	166.233	120		112
37	0.00132	0.036	1.307	166.233	117		113
38	0.00132	0.036	1.307	166.233	121		113
39	0.00132	0.036	1.307	166.233	121		114
40	0.00132	0.036	1.307	166.233	123		114
41	0.00132	0.036	1.307	166.233	123		114
42	0.00132	0.036	1.307	166.233	121		114
43	0.00132	0.036	1.307	166.233	116		114
44	0.00132	0.036	1.307	166.233	117		114
45	0.00132	0.036	1.307	166.233	117		112
46	0.00132	0.036	952.750	1.307	166.233	117	113
47	0.00132	0.036	765.070	1.307	166.233	116	112
48	0.00132	0.036	1.307	166.233	116		112

Avg. Dp	Avg. Sq. Dp	Volume	Delta H	Avg. Ts(F)	Avg. Meter T(F)
0.001	0.036	187.680	1.307	166.233	129.665



**COMPANY NAME:** Nucor Steel  
**LOCATION:** Crawfordsville  
**SOURCE TESTED:** PPF Baghouse  
**DATE OF TEST:** 04/18/05  
**RUN NO.:** 2  
**POLLUTANT:** Particulate

**FIELD DATA**

K-Factor = 990.00

start time: 8:20  
 end time: 16:08

Enter Data

**Molecular Weight of Stack Gas, Dry Basis, Md**  
 %CO2 0  
 %O2 21  
 Md 28.84

**Volume of Water Vapor Collected @ STD. COND., Vwv**  
 Vc 105.3  
 Vw(std) 4.953

**Volume of Dry Gas Collected @ STD. COND., Vm(std)**  
 Trn(F) 101.340  
 Vm 195.278  
 Pb(inches Hg) 30.140  
 delta H 1.317  
 gamma 0.961  
 Vm(std) 179.021

**Molature Content of Stack Gas, Bwo**  
 Bwo 2.69%  
 1-Bwo 97.31%

**Molecular Weight of Stack Gas, Ms**  
 Ms 28.55

**Area of Stack (enter diameter in inches), As**  
 Depth-in 366  
 Width-in 4160  
 diameter 0  
 No. of Stacks 1  
 As(L\*W) 10573.33333  
 As(da.) 0

**Static Pressure, Ps**  
 Static 0.000  
 Ps 30.14

**Stack Gas Velocity, Va, fps**  
 Cp 0.84  
 sqrt(delta p) 0.036  
 Ts 174.400  
 Vs 2.247

**Stack Gas Flowrate, Qs, acfm**  
 As 10573.33333  
 Qs 1425294

**Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd.**  
 Qstd 1166943.77  
 Qstd (dscf/hr) = 70016626.26

**Velocity at the Nozzle, Vn**  
 Dia. of Nozzle 1  
 Time of Run 288  
 Vn 2.32  
 An(nozzle) 0.005464

% Isokinetic, %I  
 %I 103.30  
 % Isokinetic measured from intermediate values  
 %I 103.69

**Pollutant Mass Emission Rate, PMR, lbs./hr.**  
 Mn(g) = 0.0067 0.0005 0.0072  
 PMR (lb/hr) = 5.7770 0.4311 6.2081  
 PMR (lb/MMBtu) = -0.1686 0.0000 -0.1686

**Grains per acf**  
 gr/acf = 0.0005 3.606E-05

**Grains per dscf**  
 gr/dscf = 0.0006 4.30954E-05 0.000621

**Grains per mg/dscf**  
 mg/dscf = 0.4966 0.4966

Run	Depth	Width	Area	Flow	Temp	Pressure	Velocity	Flow	Flow	Flow
1	0.00133	0.036	1.317	174	96	92				
2	0.00133	0.036	1.317	174	99	92				
3	0.00133	0.036	1.317	174	100	93				
4	0.00133	0.036	1.317	174	100	94				
5	0.00133	0.036	1.317	174	99	95				
6	0.00133	0.036	1.317	174	99	96				
7	0.00133	0.036	1.317	174	98	96				
8	0.00133	0.036	1.317	174	102	96				
9	0.00133	0.036	1.317	174	105	96				
10	0.00133	0.036	1.317	174	108	98				
11	0.00133	0.036	1.317	174	109	99				
12	0.00133	0.036	1.317	174	109	100				
13	0.00133	0.036	1.317	174	107	102				
14	0.00133	0.036	1.317	174	110	98				
15	0.00133	0.036	1.317	174	108	104				
16	0.00133	0.036	1.317	174	99	98				
17	0.00133	0.036	1.317	174	100	98				
18	0.00133	0.036	1.317	174	101	98				
19	0.00133	0.036	1.317	174	102	99				
20	0.00133	0.036	1.317	174	102	99				
21	0.00133	0.036	1.317	174	100	99				
22	0.00133	0.036	1.317	174	98	98				
23	0.00133	0.036	1.317	174	98	98				
24	0.00133	0.036	1.317	174	96	98				
25	0.00133	0.036	1.317	174	98	97				
26	0.00133	0.036	1.317	174	100	97				
27	0.00133	0.036	1.317	174	102	98				
28	0.00133	0.036	1.317	174	104	99				
29	0.00133	0.036	1.317	174	103	101				
30	0.00133	0.036	1.317	174	104	101				
31	0.00133	0.036	1.317	174	103	100				
32	0.00133	0.036	1.317	174	102	101				
33	0.00133	0.036	1.317	174	100	100				
34	0.00133	0.036	1.317	174	99	100				
35	0.00133	0.036	1.317	174	100	100				
36	0.00133	0.036	1.317	174	101	100				
37	0.00133	0.036	1.317	174	101	99				
38	0.00133	0.036	1.317	174	102	100				
39	0.00133	0.036	1.317	174	102	100				
40	0.00133	0.036	1.317	174	110	101				
41	0.00133	0.036	1.317	174	110	102				
42	0.00133	0.036	1.317	174	110	102				
43	0.00133	0.036	1.317	174	111	103				
44	0.00133	0.036	1.317	174	111	103				
45	0.00133	0.036	1.317	174	111	104				
46	0.00133	0.036	1156.969	1.317	174	110	103			
47	0.00133	0.036	961.691	1.317	174	110	104			
48	0.00133	0.036		1.317	174	110				

Avg. Depth	Avg. Width	Avg. Area	Avg. Flow	Avg. Temp	Avg. Pressure	Avg. Velocity	Avg. Flow
0.001	0.036	195.278	1.317	174.400			101.340

**COMPANY NAME:** Nucor Steel  
**LOCATION:** Crawfordsville  
**SOURCE TESTED:** PPF Baghouse  
**DATE OF TEST:** 04/18/05  
**RUN NO.:** 3  
**POLLUTANT:** Particulate

**FIELD DATA**

K - Factor = 900.00

**Start Time:** 0:33  
**Stop Time:** 14:14

Enter Data

**Molecular Weight of Stack Gas, Dry Basis, Md**  
 %CO2 = 0  
 %O2 = 21  
 Md = 28.84

**Volume of Water Vapor Collected @ STD. COND., Vwv**  
 Vic = 67.2  
 Vwv(std) = 3.161

**Volume of Dry Gas Collected @ STD. COND., Vm(std)**  
 Tm(F) = 84.219  
 Vm = 183.712  
 Pb(inches Hg) = 30.140  
 delta H = 1.143  
 gamma = 0.961  
 Vm(std) = 173.644

**Moisture Content of Stack Gas, Bwo**  
 Bwo = 1.79%  
 1-Bwo = 98.21%

**Molecular Weight of Stack Gas, Ms**  
 Ms = 28.65

**Area of Stack (enter diameter in inches), As**  
 Depth-in = 366  
 Width-in = 4160  
 diameter = 0  
 No. of Stacks = 1  
 As(L\*W) = 10573.33333  
 As(dia.) = 0

**Static Pressure, Ps**  
 Static = 0.000  
 Ps = 30.14

**Stack Gas Velocity, Vs, fps**  
 Cp = 0.84  
 sq(delta p) = 0.038  
 Ts = 151.570  
 Vs = 2.154

**Stack Gas Flowrate, Qs, acfm**  
 As = 10573.33333  
 Qs = 1366240

**Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd.**  
 Qstd = 1171136.42  
 Qstd (dscf/hr) = 70268185.13

**Velocity at the Nozzle, Vn**  
 Dia. of Nozzle = 1      An(nozzle) = 0.005454  
 Time of Run = 2.88  
 Vn = 2.15

**% Isokinetic, %I**  
 %I = 89.83  
**% Isokinetic measured from Intermediate values**  
 %I = 100.22

**Pollutant Mass Emission Rate, PMR, lbs./hr.**  
 Mn (g) = 0.0048    0.0037    0.0085  
 PMR (lb/hr) = 4.2822    3.8009    7.58314  
 PMR (lb/MMBtu) = -0.12455    0.0000    -0.12455

**Grains per acf**  
 gr/acf = 0.0004    0.0003

**Grains per dscf**  
 gr/dscf = 0.0004    0.0003    0.000755

**Grains per mg/dscf**  
 mg/dscf = 0.376937824    0.376938

Run	Time	Flow Rate	Volume	Delta H	Avg. Temp	Down	DCM
1	0.00127	0.036	1.143	151.57	76	64	
2	0.00127	0.036	1.143	151.57	76	64	
3	0.00127	0.036	1.143	151.57	78	65	
4	0.00127	0.036	1.143	151.57	77	66	
5	0.00127	0.036	1.143	151.57	77	67	
6	0.00127	0.036	1.143	151.57	78	68	
7	0.00127	0.036	1.143	151.57	74	69	
8	0.00127	0.036	1.143	151.57	77	69	
9	0.00127	0.036	1.143	151.57	78	69	
10	0.00127	0.036	1.143	151.57	80	70	
11	0.00127	0.036	1.143	151.57	83	72	
12	0.00127	0.036	1.143	151.57	81	72	
13	0.00127	0.036	1.143	151.57	78	73	
14	0.00127	0.036	1.143	151.57	78	73	
15	0.00127	0.036	1.143	151.57	80	73	
16	0.00127	0.036	1.143	151.57	80	73	
17	0.00127	0.036	1.143	151.57	84	74	
18	0.00127	0.036	1.143	151.57	84	77	
19	0.00127	0.036	1.143	151.57	89	76	
20	0.00127	0.036	1.143	151.57	89	78	
21	0.00127	0.036	1.143	151.57	83	78	
22	0.00127	0.036	1.143	151.57	92	80	
23	0.00127	0.036	1.143	151.57	83	83	
24	0.00127	0.036	1.143	151.57	86	82	
25	0.00127	0.036	1.143	151.57	86	82	
26	0.00127	0.036	1.143	151.57	86	81	
27	0.00127	0.036	1.143	151.57	92	82	
28	0.00127	0.036	341.712	1.143	151.57	96	83
29	0.00127	0.036	158.000	1.143	151.57	97	85
30	0.00127	0.036	1.143	151.57	95	86	
31	0.00127	0.036	1.143	151.57	95	86	
32	0.00127	0.036	1.143	151.57	96	87	
33	0.00127	0.036	1.143	151.57	96	87	
34	0.00127	0.036	1.143	151.57	97	87	
35	0.00127	0.036	1.143	151.57	99	87	
36	0.00127	0.036	1.143	151.57	102	89	
37	0.00127	0.036	1.143	151.57	104	91	
38	0.00127	0.036	1.143	151.57	104	92	
39	0.00127	0.036	1.143	151.57	97	93	
40	0.00127	0.036	1.143	151.57	93	91	
41	0.00127	0.036	1.143	151.57	91	90	
42	0.00127	0.036	1.143	151.57	92	88	
43	0.00127	0.036	1.143	151.57	95	98	
44	0.00127	0.036	1.143	151.57	97	93	
45	0.00127	0.036	1.143	151.57	98	89	
46	0.00127	0.036	1.143	151.57	97	89	
47	0.00127	0.036	1.143	151.57	96	89	
48	0.00127	0.036	1.143	151.57	96	89	

Avg. Qs	Avg. Sp. Gr	Volume	Delta H	Avg. Temp	Avg. Rate
0.001	0.036	183.712	1.143	151.570	84.219

**STACK EMISSION SUMMARY**

SOURCE TESTED: PPF Baghouse  
COMPANY NAME: Nucor Steel  
DATE OF TEST: 04/18/05

Pollutant Emissions	Run 1	Run 2	Run 3	Average
Lead (gr/dscf)	1.1778E-07	1.2101E-06	2.2335E-06	1.1871E-06
Mercury (gr/dscf)	5.8889E-07	1.1549E-06	6.3212E-07	7.9197E-07
Lead (lbs/hr)	0.0012	0.0126	0.0225	0.0121
Mercury (lbs/hr)	0.0061	0.0120	0.0064	0.0082
VOC (ppm as propane)	0.0000	0.0000	0.0000	0.0000
VOC as carbon (lbs/hr)	0.0000	0.0000	0.0000	0.0000

**Avg. Stack Vol. Flow Rate**

ACFM	1,414,994.21	1,401,033.92	1,424,304.97	1,413,444.37
DSCFM	1,206,092.24	1,214,572.10	1,174,947.16	1,198,537.17
Avg. Stack Temp.	166.233	141.630	174.400	160.754
Stack Gas Velocity	2.230	2.208	2.245	2.228
Avg. Velocity Head	0.0013	0.0014	0.0013	0.0013
Avg. Sq. Rt of Delta P	0.0363	0.0368	0.0365	0.0365

**ISOKINETIC TESTING SUMMARY**

%Isokinetics:	91.28	96.70	100.72	96.23
Allowable isokinetic 90-110%				
% Moisture of Stack Gas	3.85%	2.29%	1.99%	2.71%
Sample Volume	65.505	72.682	73.229	70.472

374.9

**COMPANY NAME:** Nucor Steel  
**LOCATION:** Crawfordsville  
**SOURCE TESTED:** PPF Baghouse  
**DATE OF TEST:** 04/18/05  
**RUN NO.:** 1  
 Metals

**FIELD DATA**

K - Factor = 899.00

Start Time 12:50  
 Stop Time 15:50

**Molecular Weight of Stack Gas, Dry Basis, MW**  
 %CO2 0  
 %O2 21  
 Md 28.84

**Volume of Water Vapor Collected @ STD. COND., Vwv**  
 Vc 55.7  
 Vw(std) 2.620

**Volume of Dry Gas Collected @ STD. COND., Vm(std)**  
 Tm(F) 114.667  
 Vm 72.773  
 P<sub>b</sub>(inches Hg) 30.140  
 delta H 1.305  
 gamma 0.966  
 Vm(std) 65.605

**Moisture Content of Stack Gas, Bwo**  
 Bwo 3.85%  
 1-Bwo 96.15%

**Molecular Weight of Stack Gas, Ma**  
 Ma 28.42

**Area of Stack (enter diameter in inches), Aa**  
 Depth-in 366  
 Width-in 4160  
 diameter 0  
 No. of Stacks 1  
 Aa(L\*W) 10573.33333  
 Aa(dia.) 0

**Static Pressure, Pe**  
 Static 0.000  
 Pe 30.14

**Stack Gas Velocity, Vs, fps**  
 Cp 0.84  
 sqrt(delta p) 0.036  
 Ts 166.233  
 Vs 2.230

**Stack Gas Flowrate, Qs, scfm**  
 Aa 10573.33333  
 Qs 1414994

**Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd.**  
 Qstd (scfm) = 1206062.24  
 Qstd (dscf/hr) = 72363634.28

**Velocity at the Nozzle, Vn**  
 Dia. of Nozzle 1  
 Time of Run 120  
 Vn 2.04

An(nozzle): 0.005454

**% Isokinetic, %I**  
 %I 91.28  
 % Isokinetic measured from intermediate values  
 %I 91.83

**Pollutant Mass Emission Rate, PMR, lbs./hr.**  
 Mn (g) = 0.0000005 0.0000025 0  
 PMR (lb/hr) = 0.0012 0.0081 0.0000  
 PMR (lb/MMBtu) = 0.0009 0.0000  
*Lead Mercury VOC*

1	0.00132	0.036	1.305	166.233	101	104
2	0.00132	0.036	1.305	166.233	99	103
3	0.00132	0.036	1.305	166.233	99	103
4	0.00132	0.036	1.305	166.233	99	102
5	0.00132	0.036	1.305	166.233	99	101
6	0.00132	0.036	1.305	166.233	99	101
7	0.00132	0.036	1.305	166.233	98	99
8	0.00132	0.036	1.305	166.233	97	98
9	0.00132	0.036	1.305	166.233	97	97
10	0.00132	0.036	1.305	166.233	97	98
11	0.00132	0.036	1.305	166.233	102	98
12	0.00132	0.036	1.305	166.233	100	98
13	0.00132	0.036	1.305	166.233	111	96
14	0.00132	0.036	1.305	166.233	111	97
15	0.00132	0.036	1.305	166.233	111	98
16	0.00132	0.036	1.305	166.233	111	98
17	0.00132	0.036	1.305	166.233	111	98
18	0.00132	0.036	1.305	166.233	111	98
19	0.00132	0.036	1.305	166.233	111	99
20	0.00132	0.036	1.305	166.233	109	99
21	0.00132	0.036	1.305	166.233	110	99
22	0.00132	0.036	1.305	166.233	111	100
23	0.00132	0.036	1.305	166.233	111	100
24	0.00132	0.036	1.305	166.233	111	100
25	0.00132	0.036	1.305	166.233	111	103
26	0.00132	0.036	1.305	166.233	112	104
27	0.00132	0.036	1.305	166.233	111	104
28	0.00132	0.036	1.305	166.233	111	104
29	0.00132	0.036	1.305	166.233	111	104
30	0.00132	0.036	1.305	166.233	111	104
31	0.00132	0.036	1.305	166.233	111	104
32	0.00132	0.036	1.305	166.233	112	104
33	0.00132	0.036	1.305	166.233	112	104
34	0.00132	0.036	1.305	166.233	112	104
35	0.00132	0.036	1.305	166.233	112	104
36	0.00132	0.036	1.305	166.233	111	104
37	0.00132	0.036	1.305	166.233	110	102
38	0.00132	0.036	1.305	166.233	107	102
39	0.00132	0.036	1.305	166.233	107	102
40	0.00132	0.036	1.305	166.233	107	102
41	0.00132	0.036	1.305	166.233	107	102
42	0.00132	0.036	1.305	166.233	107	102
43	0.00132	0.036	1.305	166.233	107	102
44	0.00132	0.036	1.305	166.233	107	102
45	0.00132	0.036	1.305	166.233	110	102
46	0.00132	0.036	610.000	166.233	110	102
47	0.00132	0.036	537.227	166.233	110	102
48	0.00132	0.036	1.305	166.233	110	103

0.001	0.036	72.773	1.305	166.233	114.667
-------	-------	--------	-------	---------	---------

**COMPANY NAME:** Nucor Steel  
**LOCATION:** Crawfordsville  
**SOURCE TESTED:** PPF Baghouse  
**DATE OF TEST:** 04/18/05  
**RUN NO.:** 2  
**POLLUTANT:** Metals

**FIELD DATA**

K-Factor = 889.00

17:05  
19:20

Enter Data

Molecular Weight of Stack Gas, Dry Basis, Md

%CO2 0  
 %O2 21  
 Md 28.84

Volume of Water Vapor Collected @ STD. COND., Vwv

Vc 36.2  
 Vw(std) 1.703

Volume of Dry Gas Collected @ STD. COND., Vm(std)

Tm(F) 114.745  
 Vm 80.750  
 Pb(Inches Hg) 30.140  
 delta H 1.840  
 gamma 0.966  
 Vm(std) 72.882

Moisture Content of Stack Gas, Bwo

Bwo 2.29%  
 1-Bwo 97.71%

Molecular Weight of Stack Gas, Ms

Ms 28.59

Area of Stack (enter diameter in inches), As

Depth-in 366  
 Width-in 4160  
 diameter 0  
 No. of Stacks 1  
 As(L\*W) 10673.33333  
 As(dia.) 0

Static Pressure, Ps

Static 0.000  
 Ps 30.14

Stack Gas Velocity, Vs, fps

Cp 0.84  
 scf(delta p) 0.037  
 Ts 141.630  
 Vs 2.208

Stack Gas Flowrate, Qs, acfm

As 10573.33333  
 Qs 1401034

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd.

Qstd 1214572.10  
 Qstd (dsctfr) = 72874325.96

Velocity at the Nozzle, Vn

Dia. of Nozzle 1  
 Time of Run 120  
 Vn 2.14  
 An(nozzle) 0.005454

% Isokinetic, %I

%I 96.70  
 % Isokinetic measured from intermediate values  
 %I 97.87

Pollutant Mass Emission Rate, PMR, lbs./hr.

Mn (g) = 0.0000057 0.00000544 0  
 PMR (lb/hr) = 0.0126 0.0120 0.0000  
 PMR (lb/MMBtu) = -0.0004 0.0000 -0.0004  
                   Lead Mercury VOC

Grains per acf

gr/acf = 1.07E-06 1.02E-06

Grains per dsct

gr/dsct = 1.21E-06 1.15E-06

1	0.001355	0.037	1.340	142	110	104	
2	0.001355	0.037	1.340	142	111	104	
3	0.001355	0.037	1.340	142	113	104	
4	0.001355	0.037	1.340	142	113	105	
5	0.001355	0.037	1.340	142	112	106	
6	0.001355	0.037	1.340	142	111	106	
7	0.001355	0.037	1.340	142	112	107	
8	0.001355	0.037	1.340	142	113	107	
9	0.001355	0.037	1.340	142	113	107	
10	0.001355	0.037	1.340	142	114	107	
11	0.001355	0.037	1.340	142	115	107	
12	0.001355	0.037	1.340	142	115	107	
13	0.001355	0.037	1.340	142	113	108	
14	0.001355	0.037	1.340	142	114	108	
15	0.001355	0.037	1.340	142	114	108	
16	0.001355	0.037	1.340	142	117	108	
17	0.001355	0.037	1.340	142	117	108	
18	0.001355	0.037	1.340	142	117	108	
19	0.001355	0.037	1.340	142	118	109	
20	0.001355	0.037	1.340	142	120	110	
21	0.001355	0.037	1.340	142	120	110	
22	0.001355	0.037	1.340	142	120	110	
23	0.001355	0.037	1.340	142	119	109	
24	0.001355	0.037	1.340	142	116	111	
25	0.001355	0.037	1.340	142	115	111	
26	0.001355	0.037	1.340	142	120	112	
27	0.001355	0.037	1.340	142	120	112	
28	0.001355	0.037	1.340	142	122	113	
29	0.001355	0.037	1.340	142	123	114	
30	0.001355	0.037	1.340	142	124	113	
31	0.001355	0.037	1.340	142	124	114	
32	0.001355	0.037	1.340	142	124	114	
33	0.001355	0.037	1.340	142	126	114	
34	0.001355	0.037	1.340	142	126	115	
35	0.001355	0.037	1.340	142	126	115	
36	0.001355	0.037	1.340	142	126	115	
37	0.001355	0.037	1.340	142	123	115	
38	0.001355	0.037	1.340	142	123	115	
39	0.001355	0.037	1.340	142	123	116	
40	0.001355	0.037	1.340	142	123	116	
41	0.001355	0.037	1.340	142	123	116	
42	0.001355	0.037	1.340	142	121	116	
43	0.001355	0.037	1.340	142	118	115	
44	0.001355	0.037	1.340	142	118	115	
45	0.001355	0.037	1.340	142	118	115	
46	0.001355	0.037	891.000	1.340	142	118	115
47	0.001355	0.037	610.250	1.340	142	118	115
48	0.001355	0.037	1.340	142	118	114	

0.001	0.037	80.750	1.340	141.630	114.745
-------	-------	--------	-------	---------	---------

**COMPANY NAME:** Nucor Steel  
**LOCATION:** Crawfordsville  
**SOURCE TESTED:** PFFF Baghouse  
**DATE OF TEST:** 04/19/05  
**RUN NO.:** 3  
**POLLUTANT:** Metals

**FIELD DATA**

K - Factor = 990.00

8:20  
13:25

Enter Data

**Molecular Weight of Stack Gas, Dry Basis, Md**  
 %CO2 0  
 %O2 21  
 Md 28.84

**Volume of Water Vapor Collected @ STD. COND., Vwv**  
 Vw 31.6  
 Vw(std) 1.486

**Volume of Dry Gas Collected @ STD. COND., Vm(std)**  
 Tm(F) 98.073  
 Vm 78.877  
 Pb(Inches Hg) 30.150  
 delta H 1.317  
 gamma 0.966  
 Vm(std) 73.229

**Molature Content of Stack Gas, Bwo**  
 Bwo 1.99%  
 1-Bwo 98.01%

**Molecular Weight of Stack Gas, Ms**  
 Ms 28.62

**Area of Stack (enter diameter in inches), As**  
 Depth-in 366  
 Width-in 4160  
 diameter 0  
 No. of Stacks 1  
 As(L\*W) 10573.33333  
 As(dia.) 0

**Static Pressure, Ps**  
 Static 0.000  
 Ps 30.15

**Stack Gas Velocity, Vs, fps**  
 Cp 0.84  
 sqr(delta p) 0.036  
 Ts 174.400  
 Vs 2.245

**Stack Gas Flowrate, Qs, acfm**  
 As 10573.33333  
 Qs 1424305

**Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd.**  
 Qstd 1174947.16  
 Qstd (dscf/hr) = 70496829.67

**Velocity at the Nozzle, Vn**  
 Dia. of Nozzle 1  
 Time of Run 120  
 Vn 2.28  
 An(nozzle): 0.005454

**% Isokinetic, %I**  
 %I 100.72  
**% Isokinetic measured from intermediate values**  
 %I 101.46

**Pollutant Mass Emission Rate, PMR, lbs./hr**  
 Mn (g) = 0.0000106 0.000003 0  
 PMR (lb/hr) = 0.0226 0.0084 0.00000  
 PMR (lb/MMBtu) = -0.00065 0.0000 -0.00065  
 Lead Mercury VOC

**Grains per acf**  
 gr/acf = 1.87E-06 5.28E-07

**Grains per dscf**  
 gr/dscf = 2.23E-06 6.32E-07

1	0.00133	0.036	1.317	174	89	92	
2	0.00133	0.036	1.317	174	97	90	
3	0.00133	0.036	1.317	174	99	90	
4	0.00133	0.036	1.317	174	100	90	
5	0.00133	0.036	1.317	174	100	90	
6	0.00133	0.036	1.317	174	100	90	
7	0.00133	0.036	1.317	174	98	91	
8	0.00133	0.036	1.317	174	99	92	
9	0.00133	0.036	1.317	174	100	92	
10	0.00133	0.036	1.317	174	100	92	
11	0.00133	0.036	1.317	174	100	92	
12	0.00133	0.036	1.317	174	100	92	
13	0.00133	0.036	1.317	174	98	92	
14	0.00133	0.036	1.317	174	98	92	
15	0.00133	0.036	1.317	174	98	92	
16	0.00133	0.036	1.317	174	98	92	
17	0.00133	0.036	1.317	174	99	92	
18	0.00133	0.036	1.317	174	101	92	
19	0.00133	0.036	1.317	174	101	93	
20	0.00133	0.036	1.317	174	101	93	
21	0.00133	0.036	1.317	174	102	93	
22	0.00133	0.036	1.317	174	102	94	
23	0.00133	0.036	1.317	174	103	95	
24	0.00133	0.036	1.317	174	102	95	
25	0.00133	0.036	1.317	174	100	96	
26	0.00133	0.036	1.317	174	104	96	
27	0.00133	0.036	1.317	174	105	97	
28	0.00133	0.036	779.441	1.317	174	109	98
29	0.00133	0.036	700.464	1.317	174	110	98
30	0.00133	0.036	1.317	174	110	98	
31	0.00133	0.036	1.317	174	107	99	
32	0.00133	0.036	1.317	174	106	99	
33	0.00133	0.036	1.317	174	106	99	
34	0.00133	0.036	1.317	174	99	98	
35	0.00133	0.036	1.317	174	100	100	
36	0.00133	0.036	1.317	174	98	98	
37	0.00133	0.036	1.317	174	89	97	
38	0.00133	0.036	1.317	174	99	97	
39	0.00133	0.036	1.317	174	101	97	
40	0.00133	0.036	1.317	174	102	98	
41	0.00133	0.036	1.317	174	103	98	
42	0.00133	0.036	1.317	174	104	98	
43	0.00133	0.036	1.317	174	100	98	
44	0.00133	0.036	1.317	174	101	99	
45	0.00133	0.036	1.317	174	104	98	
46	0.00133	0.036	1.317	174	103	98	
47	0.00133	0.036	1.317	174	102	98	
48	0.00133	0.036	1.317	174	102	98	

0.001	0.036	78.977	1.317	174.400	98.073
-------	-------	--------	-------	---------	--------

ΔAir Analysis, Inc.

NUCOR

Project Number: 302

**APPENDIX III**

**FIELD DATA**

---

Nucor PPPBH

Chemical 2

Cal gas

response

Cal gas

response

8AM

0  
109  
38.9  
63.7

0.1  
109  
38.8  
63.2

10:30AM

0  
109  
38.9  
63.7  
63.7

109  
38.2  
63.4

AP 1.8  
ST 108  
AP 1.9  
ST 109  
AP 2.0  
ST 108  
AP 1.7  
ST 108  
AP 1.9  
ST 111  
AP 1.7  
ST 113

0  
63.7  
63.7

400

0  
63.7  
0.2  
~~63.4~~ 64.0

833 PM

0  
63.7  
0.4  
63.4

Mid Hagen Flow

AP 1.6  
ST 118  
AP 1.7  
ST 120  
AP 1.3  
ST 124  
AP 1.5  
ST 125  
AP 1.6  
ST 144  
AP 1.8  
ST 148  
AP 1.4  
ST 149  
AP 0.9  
ST 149

7 10AM

0  
63.7  
-0.6  
63.4

~~938~~ 10:00 End R3


0  
63.7  
-0.4  
63.4

AP 1.2  
ST 135  
AP 1.7  
ST 150  
AP 1.7  
ST 153  
AP 1.0  
ST 191  
AP 1.1  
ST 123  
AP 1.4  
ST 134  
AP 1.5  
ST 143  
AP 1.3  
ST 126  
AP 1.4  
ST 128  
AP 1.5  
ST 130  
AP 1.9  
ST 120  
AP 1.7  
ST 121  
AP 1.5  
ST 123



View

### Nucor Steel Positive Pressure Baghouse




— PPM on Ch 2  
Maximum Minimum Average  
5 -1 -0

ppm as Propane


View.

### Nucor Steel Positive Pressure Baghouse




ppm as Propane

### Nucor Steel Positive Pressure Baghouse



ppm as Propane

### Nucor Steel Positive Pressure Baghouse



— PPM on Ch 2    Maximum 5    Minimum -2    Average -0

ppm as Propane

**VELOCITY TRAVERSE POINT DETERMINATION**  
(EPA Method 1)

**Nucor Steel**  
**Rectangular Stack**  
Flow Determination Spacing

@

**Crawfordsville**

Depth-in : 176.04 Dia. (inches): 215.44  
Width-in : 277.56 Ports: 8

Points per port:

1	44.01	22.01	17.60	14.67	8.80	6.77
2	132.03	66.02	52.81	44.01	26.41	20.31
3		110.03	88.02	73.35	44.01	33.85
4		154.04	123.23	102.69	61.61	47.40
5			158.44	132.03	79.22	60.94
6				161.37	96.82	74.48
7					114.43	88.02
8					132.03	101.56
9					149.63	115.10
10						128.64
11						142.19
12						155.73
13						169.27

<b>Spacing</b>	88.02	44.01	35.21	29.34	17.60	13.54
----------------	-------	-------	-------	-------	-------	-------

**VELOCITY TRAVERSE POINT DETERMINATION**  
(EPA Method 1)

**Nucor Steel**  
Circular Stack  
Taverse Points on Diameter:  
Stack Dia.(inches)?

@ **Crawfordsville**

Points:

	4	8	8	10	12
0					
1	0.00	0.00	0.00	0.00	0.00
2	0.00	0.00	0.00	0.00	0.00
3	0.00	0.00	0.00	0.00	0.00
4	0.00	0.00	0.00	0.00	0.00
5		0.00	0.00	0.00	0.00
6		0.00	0.00	0.00	0.00
7			0.00	0.00	0.00
8			0.00	0.00	0.00
9				0.00	0.00
10				0.00	0.00
11					0.00
12					0.00

**VELOCITY TRAVERSE POINT DETERMINATION**  
(EPA Method 1)

**Nucor Steel**  
Rectangular Stack


@ **Crawfordsville**

Depth-in : 368 Dia. (Inches): 304.03  
Width-in : 280 Ports: 2

Points per port:

	4	8	8	10	12	
1	91.50	45.75	36.60	30.50	18.30	14.08
2	274.50	137.25	109.80	91.50	54.90	42.23
3		228.75	183.00	152.50	91.50	70.38
4		320.25	256.20	213.50	128.10	98.54
5			329.40	274.50	164.70	126.69
6				335.50	201.30	154.85
7					237.90	183.00
8					274.50	211.15
9					311.10	239.31
10						267.46
11						295.62
12						323.77
13						351.92

Spacing	183.00	91.50	73.20	61.00	36.60	28.15
---------	--------	-------	-------	-------	-------	-------




TESTING  
FIELD DATA SHEET

TEST LOCATION: Inter  
UNIT: PPFF RUN: 1

Client: Nucor Project No: \_\_\_\_\_  
 Plant: \_\_\_\_\_ Date: 4-18-05  
 Meter Operator: \_\_\_\_\_  
 Probe Operator: \_\_\_\_\_

Meter Box No: \_\_\_\_\_ Sample Box No: \_\_\_\_\_  
 Meter Yd: \_\_\_\_\_ Meter AH: \_\_\_\_\_  
 K Factor: \_\_\_\_\_ Pilot Cp: \_\_\_\_\_  
 Leak Rate Before: \_\_\_\_\_ (cm) [Lpm] (M, Hg)  
 Leak Rate After: \_\_\_\_\_ (cm) [Lpm] (M, Hg)  
 Prior Leak Check Before:  After, Good  Zr Bed

Ant. Temp. (°F) \_\_\_\_\_ Bar. Press. \_\_\_\_\_ (in. Hg) [mbar]  
 Probe I.D. No.: \_\_\_\_\_  
 Liner Material: \_\_\_\_\_  
 Filter No.: \_\_\_\_\_  
 Thimble No.: \_\_\_\_\_  
 Nozzle Diameter: \_\_\_\_\_ Nozzle I.D.: \_\_\_\_\_  
 H<sub>2</sub>O: \_\_\_\_\_ (ml) [gm] Silica Gel (gm)  
 Total V<sub>g</sub>: \_\_\_\_\_



Transverse Point Number	Mntr. (Elapsed) Time	Velocity Head ΔP <sub>h</sub> (in. H <sub>2</sub> O) (M, Hg)	Velocity (ft/min) (M, Hg)	Orifice (in.) (M, Hg)	Gas Sample Volume (ft <sup>3</sup> ) (M, Hg)	Suck Temp. T <sub>s</sub> (°F)	Probe Temp. T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Filter T <sub>h</sub> (°F)	DGM Outer Temp. T <sub>o</sub> (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T <sub>1</sub> (°F)	Notes
		1.8 (AP)	147	147	147	12.8	169	169	1.9	168	192	168	168	Use FR
		1.8	148	148	148	1.3	160	160	1.0	164	190	164	164	R1 PM/PM
		1.7	147	147	147	1.2	168	168	1.3	190	192	190	190	R1 Metals
		1.8	147	147	147	0.9	160	160	1.1	192	192	192	192	
		1.3	153	153	153	1.1	146	146	1.4	190	190	190	190	
		1.8	158	158	158	1.0	166	166	1.4	168	168	168	168	
		1.7	171	171	171	1.0	175	175	1.8	187	187	187	187	
		1.3	157	157	157	0.8	170	170	1.2	160	160	160	160	
		1.2	157	157	157	1.1	168	168	1.1	178	178	178	178	
		1.3	130	130	130	1.3	177	177	1.1	177	177	177	177	
		1.7	175	175	175	1.1	174	174	1.1	174	174	174	174	
Total														
Average														

Start Time: 12:30 Stop Time: \_\_\_\_\_

Circle correct bracketed units on data sheet.

\* 1427723 acfm  
 1202591 dscfm

U6.2 Steel Temp

TESTING  
FIELD LATA SHEET

TEST LOCATION: 1st floor PPF  
 UNIT: 1st floor RUN: Recheck midday

Ant. Temp. (°F) \_\_\_\_\_ Bar. Press. \_\_\_\_\_ (in. Hg) (mbar)  
 Probe I.D. No.: \_\_\_\_\_  
 Liner Material: \_\_\_\_\_

Filter No. \_\_\_\_\_  
 Thimble No. \_\_\_\_\_  
 Nozzle Diameter \_\_\_\_\_ Nozzle I.D. \_\_\_\_\_

H<sub>2</sub>O \_\_\_\_\_ (ml) (gm) Silica Gel (gm)  
 Total Vol \_\_\_\_\_

Start Time: ~ 2:20 Stop Time: \_\_\_\_\_

Cross-Section of Test Location  
RI check  
use to R2

[N] (UP)

Duct Dimensions (in.): Nozzle

Static Press. (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow (in) (Out)	First point all the way (in) (Out)

Client: <u>Nucor</u>	Project No: _____
Plant: _____	Date: <u>4/8/05</u>
Meter Operator: _____	
Probe Operator: _____	

Meter Box No: _____	Sample Bar No: _____
Meter Yd: _____	Meter: <u>AH</u>
K Factor: _____	Pilot Cp: _____
Leak Rate Before: _____ (cm) (Lpm) (in. Hg)	
Leak Rate After: _____ (cm) (Lpm) (in. Hg)	
Prior Leak Check Before: <input checked="" type="checkbox"/> Alter, Good, <input type="checkbox"/> Bad <input type="checkbox"/>	

Inlet Valve Number	Elapsed Time	Mach	Velocity Head $\Delta P = \frac{\rho v^2}{2}$ (in. H <sub>2</sub> O) (in. H <sub>2</sub> O)	Velocity Head $\Delta P = \frac{\rho v^2}{2}$ (in. H <sub>2</sub> O) (in. H <sub>2</sub> O)	Orifice Reading	Orifice Reading	Gas Sample Volume (ft <sup>3</sup> ) (L)	Suck Temp. (°F)	Probe Tp (°F)	Filter Tp (°F)	Cond. Temp. (°F)	DGM Inlet Temp. (°F)	DGM Outlet Temp. (°F)	Pump/Vacuum (in. Hg)	XAD Trap Temp. (°F)	Notes
			1.8	1.48			1.2	148	1.4	128						
			1.9	148			1.3	140	1.0	126						
			1.7	142			1.2	148	1.3	134						
			1.7	154			0.9	160	1.1	126						
			1.3	153			1.1	130	1.6	105						
			1.8	150			1.0	146	1.6	120						
			1.1	157			1.0	135	1.8	126						
			1.4	166			0.8	135	1.2	127						
			1.2	157			1.1	130								
			1.8	160			1.1	135								
			1.4	148			1.3	137								
			1.7	148			1.1	134								
Total																
Average																

DS 001 General  
 CHV5/7AG RO-4/8/94

• Sum of square roots.

1,399,074 Acfm  
 1.729121 d scfm

Circle correct bracketed units on data sheet

Aug 142 Stack Temp



TEST LOCATION: Inlet

UNIT: RPF RUN: 2

# TESTING FIELD DATA SHEET

METHOD: \_\_\_\_\_ PAGE \_\_\_\_\_ OF \_\_\_\_\_

Client: \_\_\_\_\_ Project No: \_\_\_\_\_  
 Plant: \_\_\_\_\_ Date: 4-19-80  
 Meter Operator: \_\_\_\_\_  
 Probe Operator: \_\_\_\_\_

Meter Box No.: \_\_\_\_\_ Sample Box No.: \_\_\_\_\_  
 Meter Yd: \_\_\_\_\_ Meter:  AH   
 K Factor: \_\_\_\_\_ Pilot Cp: \_\_\_\_\_  
 Leak Rate Before: \_\_\_\_\_ (cm) (Lpm)  (in. Hg)  
 Leak Rate After: \_\_\_\_\_ (cm) (Lpm)  (in. Hg)  
 Pilot Leak Check Before:  Alarm Good  Bad

Cross-Section of Test Location:  
Use for  
R2 PM  
R3 - Next 4  
 (IN) (UP)

Duct Dimensions (in.)  
 Static Press. (in. Hg) Port Len. (in.) Gas Flow (in) (Out) First point all the way (in) (Out)  
 of page

Antb. Temp. (°F) \_\_\_\_\_ Bar. Press. \_\_\_\_\_ (in. Hg) (mbar)  
 Probe I.D. No.: \_\_\_\_\_  
 Liner Material: \_\_\_\_\_  
 Filter No.: \_\_\_\_\_  
 Thimble No.: \_\_\_\_\_  
 Nozzle Diameter: \_\_\_\_\_ Nozzle I.D.: \_\_\_\_\_  
 H<sub>2</sub>O: \_\_\_\_\_ (ml) (gm) Silica Gel (gm)  
 Total V<sub>g</sub>: \_\_\_\_\_  
 Start Time: SAM Stop Time: \_\_\_\_\_

Min/Sec Elapsed Time	Velocity Head $\Delta P$ (in. H <sub>2</sub> O) (ft. H <sub>2</sub> O)	Velocity Head $\Delta P$ (in. H <sub>2</sub> O) (ft. H <sub>2</sub> O)	Gas Sample Volume (ft <sup>3</sup> ) Total (ft <sup>3</sup> ) (L)	Suck Temp T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond. Temp T <sub>c</sub> (°F)	DGM Inlet T <sub>in</sub> (°F)	DGM Outlet T <sub>out</sub> (°F)	Pump/ Vacuum (in. Hg)	XAD Temp T <sub>1</sub> (°F)	Notes
	1.7	147		1.1	165		1.4	170				
	1.7	147		1.2	163		0.96	192				
	1.9	146		1.3	161		1.3	190				
	1.8	142		1.7	172		1.1	186				
	1.7	169		0.91	192		1.3	146				
	1.6	179		0.94	180		1.4	198				
	1.8	180		1.2	187		1.9	181				
	1.8	166		1.0	182		1.7	196				
	1.1	181		1.0	190							
	1.3	191		0.99	193							
	1.4	200		1.5	193							
	1.7	192		1.1	193							
Total												
Average												

Speed Avg  
 174.4

05 001 General  
 CNVSTAG RD-4/8/94  
 \* Sum of square roots.  
 1436990 cfm  
 1,194835 dscfm  
 Circle correct bracketed units on data sheet.

TEST LOCATION: 1st

UNIT: RRF RUN: \_\_\_\_\_

Client: NL41R Project No: \_\_\_\_\_  
 Plant: \_\_\_\_\_ Date: 4-19-05  
 Meter Operator: \_\_\_\_\_  
 Probe Operator: \_\_\_\_\_

Meter Box No.: \_\_\_\_\_ Sample Box No.: \_\_\_\_\_  
 Meter Yd: \_\_\_\_\_ Meter: ΔH  
 K Factor: \_\_\_\_\_ Pilot Cp: \_\_\_\_\_  
 Leak Rate Before: \_\_\_\_\_ (cm) (Lpm) (M, Hg)  
 Leak Rate After: \_\_\_\_\_ (cm) (Lpm) (M, Hg)  
 Pilot Leak Check Before:  Alter, Good  Bad

METHOD: \_\_\_\_\_ PAGE \_\_\_\_\_ OF \_\_\_\_\_

Amb. Temp. (°F) \_\_\_\_\_ Bar. Press. \_\_\_\_\_ (in. Hg) (mbar)  
 Probe I.D. No.: \_\_\_\_\_  
 Liner Material: \_\_\_\_\_  
 Filter No.: \_\_\_\_\_  
 Thimble No.: \_\_\_\_\_  
 Nozzle Diameter: \_\_\_\_\_ Nozzle I.D.: \_\_\_\_\_  
 H<sub>2</sub>O: \_\_\_\_\_ (ml) (gm) Silica Gel (gm)  
 Total V<sub>g</sub>: \_\_\_\_\_  
 Start Time: \_\_\_\_\_ Stop Time: \_\_\_\_\_

Cross-Section of Test Location  
 ↑  
 (N) (UP)  
 Duct Dimensions (in.): \_\_\_\_\_  
 Sample Press. \_\_\_\_\_ Port Len. \_\_\_\_\_ Gas Flow \_\_\_\_\_ First point  
 (in. H<sub>2</sub>O) (in.) (in) (Out) at the way  
 of page (In) (Out)

Invent. Part Number	Min. Time	Velocity Head (in. H <sub>2</sub> O)	Velocity (ft/min)	Leak Rate (cm) (Lpm) (M, Hg)	Leak Rate (cm) (Lpm) (M, Hg)	Pilot Leak Check Before: <input checked="" type="checkbox"/> Alter, Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>	Gas Sample Volume (ml) (L)	Stack Temp (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond. Temp (°F)	DGM Filter T <sub>in</sub> (°F)	DGM Outer Temp (°F)	Pump Vacuum (in. Hg)	XAD Trap T <sub>i</sub> (°F)	Notes
		1.8	108	1.6	1.6		1.44	144	130	1.3	124					
		1.9	109	1.3	1.3		1.48	148	128	1.7	128					
		1.9	112	1.4	1.4		1.49	149	128	1.6	128					
		2.0	108	1.2	1.2		1.35	135	130	1.3	130					
		1.9	111	1.7	1.7		1.50	150	120	1.9	120					
		1.7	113	1.7	1.7		1.53	153	121	1.7	121					
		1.7	106	1.2	1.2		1.53	153	121	1.7	121					
		1.6	118	1.1	1.1		1.23	123	123	1.5	123					
		1.7	120	1.4	1.4		1.39	139								
		1.8	124	1.5	1.5		1.43	143								
		1.5	125	1.0	1.0		1.41	141								
	Total															
	Average															

check  
 flows  
 Post 4-19-05

TEST LOCATION: INLET

UNIT: PFF RUN: 3

# KM TESTING FIELD DATA SHEET

METHOD: PAGE OF

Client: Project No: \_\_\_\_\_  
 Plant: Date: 4-22-05  
 Meter Operator: \_\_\_\_\_  
 Probe Operator: \_\_\_\_\_

Meter Box No.: \_\_\_\_\_ Sample Box No.: \_\_\_\_\_  
 Meter: Yd Meter: AH  
 K Factor: \_\_\_\_\_ Pilot Cp: \_\_\_\_\_  
 Leak Rate Before: [cm] [Lpm] [in. Hg] (in. Hg)  
 Leak Rate After: [cm] [Lpm] [in. Hg] (in. Hg)  
 Pilot Leak Check Before:  After:  Good:  Bad:

Cross-Section of Test Location  
 [IN] [UP] Use for (R3) (PM/PM10)  
 Duct Dimensions (in.): \_\_\_\_\_  
 Stack Press. (in. Hg) Port Len. (in.) Gas Flow (In) (Out) First point alt. the way (In) (Out) of page

Amb. Temp. (°F) Bar. Press. (in. Hg) (in. Hg) (in. Hg) (in. Hg)  
 Probe I.D. No.: \_\_\_\_\_  
 Filter Material: \_\_\_\_\_  
 Filter No.: \_\_\_\_\_  
 Thimble No.: \_\_\_\_\_  
 Nozzle Diameter: \_\_\_\_\_ Nozzle I.D.: \_\_\_\_\_  
 H<sub>2</sub>O (ml) (gm) Silica Gel (gm)  
 Total Vol: \_\_\_\_\_  
 Start Time: 8 AM Stop Time: \_\_\_\_\_

Test Point Number	Meter #	Elapsed Time	Velocity Head (in. H <sub>2</sub> O)	Orifice Reading (in. H <sub>2</sub> O)	Gas Sample Volume (ft <sup>3</sup> )	Stack Temp. (°F)	Probe Temp. (°F)		Filter T <sub>1</sub> (°F)	Cond. Temp. (°F)	DGM Star. Temp. (°F)	DGM Outer Temp. (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. (°F)	Notes
							T <sub>2</sub>	T <sub>3</sub>							
1			1.2	149		1.1	151	0.9	136						
2			1.3	153		1.3	150	0.9	160						
3			1.7	170		1.3	156	1.0	140						
4			1.7	163		1.4	156	1.0	141						
5			1.3	150		1.3	136	0.76	141						
6			1.1	143		1.3	143	0.8	136						
7			1.8	163		1.4	143	1.0	153						
8			1.7	161		1.4	147	1.1	150						
9			1.1	129		0.8	151								
10			1.3	159		0.8	151								
11			1.4	168		0.8	156								
12			1.7	175		0.9	147								
Total															
Average															

DS 001 General \* Sum of square roots. Circle correct bracketed units on data sheet.


(1,335 191 acfm)  
(1,151 653 dscfm)

Temp

Aug 15 1.57

CLIENT: Nor-Sbest METER BOX ID: 80 K FACTOR: 9.87 DUCT DIMENSIONS (in.): 36 by 460  
 LOCATION: Crestwood IN METER ΔH: 1.982 PORT LENGTH (in.):  
 UNIT: Positiv Pressure - Bst PROBE LINER: 1.0 FILTER ID: SILICA ID:  
 DATE: 4-18-05 PROJECT #: 1.0 NOZZLE ID: TEDLAR BAG ID:  
 METER OPERATOR: M. Dixon BAROMETRIC: 30.19 AMBIENT TEMP (°F):  
 PROBE OPERATOR: M. Allen STATIC PRESSURE (in. H<sub>2</sub>O):  
 VISIBLE EMISSIONS READER: R. S. Stapp LEAK RATE BEFORE (cfm) @ (in. Hg): 15 H<sub>2</sub>O (mL): 23  
 CLIENT CONTACT: H. Washburn LEAK RATE AFTER (cfm) @ (in. Hg): 15 SILICA GEL (g):  
 AGENCY CONTACT: S. F. Smith START TIME: 1250 STOP TIME: 1936 TOTAL V<sub>c</sub>: (6.3)



Traverse Point Number	MiniPoint Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tp (°F)	Filter Tt (°F)	Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
1	6	0.00133	1.3	765.07	166.23	N/A	N/A	624	100	104	6	
2	12			772.4				624	102	102	6	
3	18			786.0					104	102	5	
4	24			794.4					104	101	5	
5	30			782.3					100	103	5	1437382
6	36			787.1					103	99	6	
7	42			790.6					104	98	6	
8	48			794.5					107	99	6	
9	54			796.1					101	98	6	
10	60			803.4					107	100	6	
11	66			808.6					108	101	6	
12	72			810.7				75	108	101	6	
13	78		1.08	814.4					108	104	6	
14	84			820.0					108	103	6	
15	90			823.3					110	104	6	
16	96			826.7					110	104	6	
17	102			828					110	103	6	
18	108			834					107	103	6	
19	114			837.7					108	102	6	
20	120			842.0					108	102	6	
21	126			841					108	102	6	
22	132			843					109	102	6	
23	138			851.5					110	102	6	
24	144			855.4					110	101	6	
25	150			859.7					112	102	6	
26	156			863.1					112	102	6	
27	162			868.0					112	102	6	
28	168			871.0					115	107	6	
29	174			875.0					115	107	6	
30	180			879.0					115	108	6	



Hot  
Vocative

UN NUMBER 1 POLLUTANT TESTED PM/PMD EPA METHOD 5D/202 Start Time: 2:05 End Time: 2:20

Company: Duane Sied  
 Location: Craftonville  
 Nit Tested: PPDA  
 Filter Operator: MD  
 Probe Operator: MA  
 Diluent Contact: MW  
 Gency Contact: SC  
 E. Reader: PS  
 AI Project: Date: 4-1-86  
 Ambient Pressure: 30.14  
 Ambient Temperature: 115



Point	Minutes per point	Δ P	Δ H	Meter Cu. ft.	Static Pressure			Filter Temp. (F)	Notes
					Stack Temp. (F)	Probe Temp. (F)	Temp. (F)		
31	186	0.00132	1.3	8835	166.2	NA	MA	109	
32	192	0.00132	1.3	8872	166.2			110	
33	198	0.00132	1.3	8923	166.2			110	
34	204	0.00132	1.3	895	166.2			112	
35	210	0.00132	1.3	900	166.2			112	
36	216	0.00132	1.3	9074	166.2			112	
37	222	0.00132	1.3	9085	166.2			113	
38	228	0.00132	1.3	9124	166.2			113	
39	234	0.00132	1.3	9154	166.2			114	
40	240	0.00132	1.3	9204	166.2			114	
41	246	0.00132	1.3	9218	166.2			114	
42	252	0.00132	1.3	9291	166.2			114	
43	258	0.00132	1.3	9329	166.2			114	
44	264	0.00132	1.3	9367	166.2			114	
45	270	0.00132	1.3	9412	166.2			112	
46	276	0.00132	1.3	9451	166.2			113	
47	282	0.00132	1.3	950	166.2			112	
48	288	0.00132	1.3	95275	166.2			112	
19									
20									
21									
22									
23									
24									
25									
26									
27									
28									
29									
30									

Filter Number:  
 Filter preweight: 2.9980  
 Filter postweight: 3.0028  
 Total:  
 Beaker ID:  
 Beaker preweight: 65.7916  
 Beaker postweight: 65.7952  
 Total:

DF 0.0581  
 56.0532  
0.0049

MA 0.002  
 55.8954  
 56.8953  
0.0001

DF 0.064  
 55.1330  
 56.1330  
0

MA 0.064  
 54.7901  
 54.7901  
0





dot

RUN NUMBER 2 POLLUTANT TESTED PM<sub>10</sub> EPA METHOD 50/202 Start Time:            End Time:           

AIR ANALYSIS, L.L.C.

Company: Nucor Steel  
 Location: Crawfordsville  
 Inlet Tested: PP64  
 Meter Operator: MD  
 Probe Operator: MA  
 Client Contact: MW  
 Agency Contact: SE  
 V.E. Reader: RS  
 AAI Project:            Date: 4-19-05  
 Barometric Pressure: 30.5  
 Ambient Temperature: 115



Traverse Point	Minutes per point	Δ P	Δ H	Diagram of Test Location				Static Pressure		Filter Temp. (F)	Impinger Outlet Temp. (F)	CO2		O2		Nozzle size measurement		NOTES		
				Meter Cu. ft.	Stack Temp. (F)	Probe Temp. (F)	Temp. (F)	Temp. (F)	Temp. (F)			Temp. (F)	Temp. (F)	Meter Inlet Temp. (F)	Meter Outlet Temp. (F)	Pretest Leak Ch.	Posttest Leak Ch.		Meter Y	nozzle (quartz, glass, SS)
31	186	0.00133	1.32	1036.6	NA	NA	NA	NA	74	103	102	102	102	102	102	102	102	7		
7	22	0.00133	1.32	1070.3	174.4	174.4	174.4	174.4	74	102	102	102	102	102	102	102	102	7		
33	193	0.00133	1.32	1094.8	174.4	174.4	174.4	174.4	74	102	102	102	102	102	102	102	102	7		
34	204	0.00133	1.32	1098.7	174.4	174.4	174.4	174.4	74	102	102	102	102	102	102	102	102	7		
35	210	0.00133	1.32	1101.4	174.4	174.4	174.4	174.4	74	102	102	102	102	102	102	102	102	7		
36	216	0.00133	1.32	1106.85	174.4	174.4	174.4	174.4	74	102	102	102	102	102	102	102	102	7		
37	222	0.00133	1.32	111.14	174.4	174.4	174.4	174.4	74	102	102	102	102	102	102	102	102	7		
38	228	0.00133	1.32	115.31	174.4	174.4	174.4	174.4	74	102	102	102	102	102	102	102	102	7		
39	234	0.00133	1.32	119.69	174.4	174.4	174.4	174.4	74	102	102	102	102	102	102	102	102	7		
8	40	0.00133	1.32	123.18	174.4	174.4	174.4	174.4	74	102	102	102	102	102	102	102	102	7		
41	240	0.00133	1.32	127.91	174.4	174.4	174.4	174.4	74	102	102	102	102	102	102	102	102	7		
42	252	0.00133	1.32	130.99	174.4	174.4	174.4	174.4	74	102	102	102	102	102	102	102	102	7		
43	258	0.00133	1.32	134.95	174.4	174.4	174.4	174.4	74	102	102	102	102	102	102	102	102	7		
44	264	0.00133	1.32	139.11	174.4	174.4	174.4	174.4	74	102	102	102	102	102	102	102	102	7		
45	270	0.00133	1.32	143.28	174.4	174.4	174.4	174.4	74	102	102	102	102	102	102	102	102	7		
46	276	0.00133	1.32	147.44	174.4	174.4	174.4	174.4	74	102	102	102	102	102	102	102	102	7		
47	282	0.00133	1.32	151.59	174.4	174.4	174.4	174.4	74	102	102	102	102	102	102	102	102	7		
48	288	0.00133	1.32	155.76	174.4	174.4	174.4	174.4	74	102	102	102	102	102	102	102	102	7		
19				1150.765																
20																				
21																				
22																				
23																				
24																				
25																				
26																				
27																				
28																				
29																				
30																				

Filter Number:  
 Filter preweight:  
 Filter postweight:  
 Total:  
 Beaker ID:  
 Beaker preweight:  
 Beaker postweight:  
 Total:

88  
 -22  
 ---  
 66  
 12

1. f2

Start Time: 8:33

End Time: 2:00 PM




Run Number: 3

POLLUTANT TESTED: PM<sub>10</sub>/PM<sub>2.5</sub>

EPA METHOD: 50/102

AIR ANALYSIS, INC

Traverse Point	Minutes per point	Δ P	Δ H	Diagram of Test Location				CO <sub>2</sub>		O <sub>2</sub>		Nozzle size measurement		Notes	
				Meter Cu. ft.	Static Pressure Stack Temp. (F)	Probe Temp. (F)	Filter Temp. (F)	Meter Inlet Temp. (F)	Meter Outlet Temp. (F)	Meter Inlet Temp. (F)	Meter Outlet Temp. (F)	nozzle (quartz, glass, SS, Tl)	cfm@		
1	6	0.00127	1.1	158.0	151.57	NA	NA	0	0	1	2.1	76	69	7	AP
2	12	0.00127	1.1	162.0	151.57	NA	NA	0	0	2	2.1	76	69	7	1.2 1.3
3	18	0.00127	1.1	170.0	151.57	NA	NA	0	0	3	2.1	76	69	7	1.2 1.3
4	24	0.00127	1.1	174.5	151.57	NA	NA	0	0	Avg. 2.1		76	69	7	1.2 1.3
5	30	0.00127	1.1	178.1	151.57	NA	NA	0	0	2.1		76	69	7	1.2 1.3
6	36	0.00127	1.1	182.1	151.57	NA	NA	0	0	2.1		76	69	7	1.2 1.3
7	42	0.00127	1.1	185.6	151.57	NA	NA	0	0	2.1		76	69	7	1.2 1.3
8	48	0.00127	1.1	189.6	151.57	NA	NA	0	0	2.1		76	69	7	1.2 1.3
9	54	0.00127	1.1	192.8	151.57	NA	NA	0	0	2.1		76	69	7	1.2 1.3
10	60	0.00127	1.1	196.6	151.57	NA	NA	0	0	2.1		76	69	7	1.2 1.3
11	66	0.00127	1.1	201.1	151.57	NA	NA	0	0	2.1		76	69	7	1.2 1.3
12	72	0.00127	1.1	204.9	151.57	NA	NA	0	0	2.1		76	69	7	1.2 1.3
13	78	0.00127	1.1	208.4	151.57	NA	NA	0	0	2.1		76	69	7	1.2 1.3
14	84	0.00127	1.1	212.4	151.57	NA	NA	0	0	2.1		76	69	7	1.2 1.3
15	90	0.00127	1.1	216.0	151.57	NA	NA	0	0	2.1		76	69	7	1.2 1.3
16	96	0.00127	1.1	219.1	151.57	NA	NA	0	0	2.1		76	69	7	1.2 1.3
17	102	0.00127	1.1	223.1	151.57	NA	NA	0	0	2.1		76	69	7	1.2 1.3
18	108	0.00127	1.1	227.3	151.57	NA	NA	0	0	2.1		76	69	7	1.2 1.3
19	114	0.00127	1.1	231.4	151.57	NA	NA	0	0	2.1		76	69	7	1.2 1.3
20	120	0.00127	1.1	234.6	151.57	NA	NA	0	0	2.1		76	69	7	1.2 1.3
21	126	0.00127	1.1	238.5	151.57	NA	NA	0	0	2.1		76	69	7	1.2 1.3
22	132	0.00127	1.1	242.1	151.57	NA	NA	0	0	2.1		76	69	7	1.2 1.3
23	138	0.00127	1.1	245.6	151.57	NA	NA	0	0	2.1		76	69	7	1.2 1.3
24	144	0.00127	1.1	249.7	151.57	NA	NA	0	0	2.1		76	69	7	1.2 1.3
25															
26															
27															
28															
29															
30															



Filter Number:  
 Filter preweight: 2.4885  
 Filter postweight: 2.4858  
 Total:  
 Beaker ID:  
 Beaker preweight: 66.5135  
 Beaker postweight: 66.5156  
 Total: 0.0021

DI 65.919  
 65.9153  
 M.02

R2 1658-1920

13410108  
 1,155,887

No (see) 3rd wt of May

54.6505  
 54.6505



2 + 2

Start Time: 8:33

AIR ANALYSIS, INC




POLLUTANT TESTED

RUN NUMBER 3

EPA METHOD 5D/2022

PM<sub>10</sub>

Traverse Point	Minutes per point	Δ P	ΔH	Diagram of Test Location		Static Pressure		Meter		CO2		O2		Nozzle size measurement		NOTES
				Stack Temp. (F)	Probe Temp. (F)	Filter Temp. (F)	Cu. ft.	Impinger Outlet Temp. (F)	Impinger Inlet Temp. (F)	1	2	a	b	c	Avg.	
1	150	0.00127	1.1	151.57	NA	NA	253.5	86	81	0	0	21	1.0	1.0	0.96	
2	150	0.00127	1.1	151.57	NA	NA	280.8	92	82	0	0	21	1.0	1.0	1.88	
3	162	0.00127	1.1	151.57	NA	NA	281.0	96	83	0	0	21	1.0	1.0	1.5	
4	168	0.00127	1.1	151.57	NA	NA	264.6	97	85	0	0	21	1.0	1.0	1.5	
5	174	0.00127	1.1	151.57	NA	NA	268.3	95	96	0	0	21	1.0	1.0	1.5	
6	180	0.00127	1.1	151.57	NA	NA	272.2	95	86	0	0	21	1.0	1.0	1.5	
7	186	0.00127	1.1	151.57	NA	NA	276.0	95	87	0	0	21	1.0	1.0	1.5	
8	192	0.00127	1.1	151.57	NA	NA	279.8	95	87	0	0	21	1.0	1.0	1.5	
9	198	0.00127	1.1	151.57	NA	NA	283.5	97	87	0	0	21	1.0	1.0	1.5	
10	204	0.00127	1.1	151.57	NA	NA	287.3	97	87	0	0	21	1.0	1.0	1.5	
11	210	0.00127	1.1	151.57	NA	NA	291.1	102	89	0	0	21	1.0	1.0	1.5	
12	216	0.00127	1.1	151.57	NA	NA	295.3	104	91	0	0	21	1.0	1.0	1.5	
13	222	0.00127	1.1	151.57	NA	NA	299.1	104	92	0	0	21	1.0	1.0	1.5	
14	228	0.00127	1.1	151.57	NA	NA	302.9	98	93	0	0	21	1.0	1.0	1.5	
15	234	0.00127	1.1	151.57	NA	NA	306.7	93	91	0	0	21	1.0	1.0	1.5	
16	240	0.00127	1.1	151.57	NA	NA	311.5	91	90	0	0	21	1.0	1.0	1.5	
17	246	0.00127	1.1	151.57	NA	NA	314.8	92	88	0	0	21	1.0	1.0	1.5	
18	252	0.00127	1.1	151.57	NA	NA	322.5	95	88	0	0	21	1.0	1.0	1.5	
19	258	0.00127	1.1	151.57	NA	NA	324.2	97	88	0	0	21	1.0	1.0	1.5	
20	264	0.00127	1.1	151.57	NA	NA	326.8	97	88	0	0	21	1.0	1.0	1.5	
21	270	0.00127	1.1	151.57	NA	NA	330.2	97	89	0	0	21	1.0	1.0	1.5	
22	276	0.00127	1.1	151.57	NA	NA	333.3	97	89	0	0	21	1.0	1.0	1.5	
23	282	0.00127	1.1	151.57	NA	NA	337.2	96	89	0	0	21	1.0	1.0	1.5	
24	288	0.00127	1.1	151.57	NA	NA	341.7	96	89	0	0	21	1.0	1.0	1.5	
25																
26																
27																
28																
29																
30																



Company: Alcor Steel  
 Location: C. J. L.  
 Unit Tested: PPBIX  
 Meter Operator: MD  
 Probe Operator: NA  
 Client Contact: MW  
 Agency Contact: CB  
 V.E. Reader: CB  
 AAI Project: Date: 4/22  
 Barometric Pressure: 29.73  
 Ambient Temperature: 52

Pretest Pitot Ch.  Pass  Fail  
 Posttest Pitot Ch.  Pass  Fail  
 Meter Y 0.96  
 Meter Deltah 1.88  
 Pretest Leak Ch.  cfm @ 15  
 Posttest Leak Ch.  cfm @ 15  
 Meter Outlet Temp (F) 81  
 Meter Inlet Temp (F) 86  
 Impinger Outlet Temp (F) Fully  
 Impinger Inlet Temp (F) 120  
 Filter Temp (F) NA  
 Filter Temp (F) NA  
 Filter Number: 7  
 Filter preweight: 7  
 Filter postweight: 7  
 Total: 7  
 Beaker ID: 7  
 Beaker preweight: 7  
 Beaker postweight: 7  
 Total: 7

Diagram of Test Location  
 # 77  
 6.466  
 1.88

CLIENT: Hessle Steel  
 LOCATION: Cross-Island  
 UNIT: RPPA  
 DATE: 4-18-85  
 PROJECT #:  
 METER BOX ID: 79  
 K FACTOR: 985  
 DUCT DIMENSIONS (in.): 3.6 x 4.0  
 METER Y: 0.966  
 METER ΔH@: 1.08  
 PORT LENGTH (in.):  
 PITOT C<sub>p</sub>: 0.84  
 PROBE LINER: Feb  
 FILTER ID:  
 SILICA ID: 12  
 PROBE ID:  
 NOZZLE ID:  
 TEDLAR BAG ID:  
 METER OPERATOR: H. Dick  
 BAROMETRIC: 30.14  
 AMBIENT TEMP (°F):  
 PROBE OPERATOR: H. Allen  
 STATIC PRESSURE (in. H<sub>2</sub>O): 0  
 PILOT CHECK:  PASS  FAIL   
 O<sub>2</sub>: 21  
 CO<sub>2</sub>: 0  
 VISIBLE EMISSIONS READER: R. St. Denis  
 LEAK RATE BEFORE (cfm): 0 @ (in. Hg)  
 H<sub>2</sub>O (mL): 30  
 CLIENT CONTACT: M. W. ...  
 LEAK RATE AFTER (cfm): 0 @ (in. Hg)  
 SILICA GEL (g): 25.17  
 AGENCY CONTACT: D. F. ...  
 START TIME: 12:50  
 STOP TIME: 3:50  
 TOTAL V<sub>c</sub>: 55.7

Traverse Point Number	Min/Point Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume V <sub>m</sub> (ft <sup>3</sup> )	Stack Temp. T <sub>s</sub> (°F)	Probe Temp. T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>m</sub> (°F)	DGM Outlet T <sub>m</sub> (°F)	Pump Vacuum (in. Hg)	Notes
1	35	0.00133	1.33	537.227	166.23	NA	NA	62.0	101	104	12	
2	5	0.00133		539.1				10.4	97	103	17	
3	7.5	0.00133		540					94	103	17	
4	10	0.00133		441					99	102	17	
5	12.5	0.00133		443					95	101	17	
6	15	0.00133		546.2					95	101	17	
7	17.5			548.0					98	95	17	
8	20			549.3					55	98	17	
9	22.5			551.0					98	97	17	
10	25			552.9					97	98	17	
11	27.5			553.5					97	98	17	
12	30			554.561					97	98	17	Sample clean ✓
13	32.5			557.8	166.23				102	96	8	
14	35	0.00133	1.33	555.4	166.23				108	97	8	
15	37.5	0.00133	1.33	571.7	166.2				111	98	8	
16	40	0.00133	1.33	562.6	116.2				111	58	8	
17	42.5	0.00133	1.33	564.6	166.2				111	98	8	
18	45	0.00133	1.33	566.2	166.2				111	98	8	
19	47.5	0.00133	1.33	567.9	166.2				111	99	8	
20	50	0.00133	1.33	569.1	166.2				109	99	8	
21	52.5	0.00133	1.33	570.1	166.2				110	99	8	
22	55	0.00133	1.33	572	166.2				111	100	8	
23	57.5	0.00133	1.33	573.2	166.2				111	100	8	
24	60	0.00133	1.33	576.1	166.2				111	100	8	
25	62.5	0.00133	1.33	577.1	166.2				111	101	8	
26	65	0.00133	1.33	579.5	166.2				117	101	10	
27	67.5	0.00133	1.33	580	166.2				111	101	10	11.5cm
28	70	0.00133	1.33	582.7	166.2				111	101	10	900 scm
29	72.5	0.00133	1.33	583	166.2				111	104	6	
30	75	0.00133	1.33	586.2	166.2				111	104	6	
30	30											

2


3

4

15

2

30

**Company:** Nucor     **Location:** Chardonville     **Diagrams of Test Location:** 

**Init Tested:** PP Bill     **Filter:** NA     **CO2:** 0     **O2:** 21

**Filter Operator:** MW     **Probe Operator:** NA     **Postest Pitot Ch. Temp. (F):** 111     **Meter Inlet Temp. (F):** 104

**Agency Contact:** MW     **Impingers:** Moisture Total     **Pretest Pitot Ch. Temp. (F):** 112     **Meter Outlet Temp (F):** 104

**Agency Contact:** SE     **Silica wt.:** 0     **Postest Pitot Ch. Temp. (F):** 112     **Meter Outlet Temp (F):** 104

**E. Reader:** RS     **Silica ID:** 0     **Impinger Outlet Temp. (F):** 112     **Meter Outlet Temp (F):** 104

**AI Project:** 2015     **Impingers:** Moisture Total     **Impinger Outlet Temp. (F):** 112     **Meter Outlet Temp (F):** 104

**Barometric Pressure:** 115     **Impingers:** Moisture Total     **Impinger Outlet Temp. (F):** 112     **Meter Outlet Temp (F):** 104

**Ambient Temperature:** 115     **Impingers:** Moisture Total     **Impinger Outlet Temp. (F):** 112     **Meter Outlet Temp (F):** 104

Traverse Point	Minutes per point	Δ P	Δ H	Meter		Static Pressure		Filter		CO2		O2		Notes
				Cu. ft.	cu. ft.	Stack Temp (F)	Probe Temp (F)	Temp (F)	Temp (F)	Temp (F)	Temp (F)	Temp (F)	Temp (F)	
31	775	?	0.9	5876	NA	NA	NA	NA	0	0	21	111	104	
32	80		0.9	5886							21	112	104	
33	835		0.9	5891							21	112	104	
34	85		0.9	590							Avg. 21	112	104	
35	855		0.9	5921								112	107	
36	90		0.9	5932								112	107	
37	925		0.9	594								111	107	
38	95		0.9	5957								110	102	
39	975		0.9	597								107	103	
40	100		0.9	5987								107	103	
41	1025		0.9	6019								107	103	
42	108		0.9	6025								107	103	
43	1075		0.9	6039								107	103	
44	110		0.9	6048								107	103	
45	1125		0.9	6079								107	103	
46	115		0.9	609								107	103	
47	1175		0.9	610								107	103	
48	120		0.9									107	103	
19														
20														
21														
22														
23														
24														
25														
26														
27														
28														
29														
30														

**Filter Number:** \_\_\_\_\_     **Filter preweight:** \_\_\_\_\_

**Filter postweight:** \_\_\_\_\_     **Total:** \_\_\_\_\_

**Beaker ID:** \_\_\_\_\_     **Beaker preweight:** \_\_\_\_\_

**Beaker postweight:** \_\_\_\_\_     **Total:** \_\_\_\_\_

RUN NUMBER 2

POLLUTANT TESTED

CO2

EPA METHOD

29



AIR ANALYSIS, INC

Start Time: 5:05

End Time: 7:20

1082

Company:	Mixer Steel		Diagram of Test Location	CO2		Nozzle size measurement	
	Location:	Cross-Handed		1	2	a	b
Unit Tested:	Positive Pressure BH		Roof Numbers	3	Avg.	26.2 grams	probe (quartz, glass, SS, Ti)
Meter Operator:	Mr. Dican		Impingers	Meter Inlet Temp. (F)	Meter Outlet Temp. (F)	Vacuum (inches)	NOTES
Probe Operator:	Mr. Allen		Moisture Total	Pretest Leak Ch.	Posttest Leak Ch.	Filter Number:	Filter preweight:
Client Contact:	Mr. Friend		Pretest Pitot Ch.	Impinger Outlet Temp. (F)	Filter Temp. (F)	Filter postweight:	Total:
Agency Contact:	S. Friend		Static Pressure	Stack Temp. (F)	Probe Temp. (F)	Beaker ID:	Beaker preweight:
V.E. Reader:	R. Staupert		Meter Cu. ft.	Meter Inlet Temp. (F)	Meter Outlet Temp. (F)	Beaker postweight:	Total:
AAI Project:	Date: 1-18-85		10.25	142	NA	119	120
Barometric Pressure:	30.8		11.5	142	NA	117	110
Ambient Temperature:	115		12.5	142	NA	115	109
Point	Minutes per point	Δ P	Δ H	142	NA	117	110
2	5	0.00132	1.33	142	NA	117	110
3	7.5	0.00132	1.33	142	NA	117	110
4	10	0.00132	1.3	142	NA	117	110
5	12.5	0.00132	1.3	142	NA	117	110
6	15	0.00132	1.3	142	NA	117	110
7	17.5	0.00132	1.3	142	NA	117	110
8	20	0.00132	1.3	142	NA	117	110
9	22.5	0.00132	1.3	142	NA	117	110
10	25	0.00132	1.3	142	NA	117	110
11	27.5	0.00132	1.3	142	NA	117	110
12	30	0.00132	1.3	142	NA	117	110
13	32.5	0.00132	1.3	142	NA	117	110
14	35	0.00132	1.3	142	NA	117	110
15	37.5	0.00132	1.3	142	NA	117	110
16	40	0.00132	1.3	142	NA	117	110
17	42.5	0.00132	1.3	142	NA	117	110
18	45	0.00132	1.3	142	NA	117	110
19	47.5	0.00132	1.3	142	NA	117	110
20	50	0.00132	1.3	142	NA	117	110
21	52.5	0.00132	1.3	142	NA	117	110
22	55	0.00132	1.3	142	NA	117	110
23	57.5	0.00132	1.3	142	NA	117	110
24	60	0.00132	1.3	142	NA	117	110
25	62.5	0.00132	1.3	142	NA	117	110
26	65	0.00132	1.3	142	NA	117	110
27	67.5	0.00132	1.3	142	NA	117	110
28	70	0.00132	1.3	142	NA	117	110
29	72.5	0.00132	1.3	142	NA	117	110
30	75	0.00132	1.3	142	NA	117	110



Filter Number:  
Filter preweight:  
Filter postweight:  
Total:  
Beaker ID:  
Beaker preweight:  
Beaker postweight:  
Total:

1082

ADT L

Start Time:


End Time:

Company: Medco

POLLUTANT TESTED: CO2

Diagram of Test Location

Point	Traverse	Minutes per	Barometric Pressure:	Ambient Temperature:	Δ P	Δ H	Static Pressure			Filter Temp. (F)	CO2		O2		Nozzle size measurement		NOTES
							Meter Cu. ft.	Stack Temp. (F)	Probe Temp. (F)		Meter Inlet Temp. (F)	Meter Outlet Temp. (F)	Pretest Pitot Ch. Temp. (F)	Posttest Pitot Ch. Temp. (F)	Meter Inlet Temp. (F)	Meter Outlet Temp. (F)	
31	775	0.00132	1.3	ΔH	142	NA	NA	124	114								
32	805	0.00132	1.3		142			124	114								
33	825	0.00132	1.3		142			126	114								
34	855	0.00132	1.3		142			126	114								
35	875	0.00132	1.3		142			126	115								
36	90	0.00132	1.3		142			123	115								
37	926	0.00132	1.3		142			123	115								
38	95	0.00132	1.3		142			123	115								
39	978	0.00132	1.3		142			123	115								
40	100	0.00132	1.3		142			123	115								
41	1025	0.00132	1.3		142			123	115								
42	105	0.00132	1.3		142			121	115								
43	1075	0.00132	1.3		142			118	115								
44	110	0.00132	1.3		142			118	115								
45	1125	0.00132	1.3		142			118	115								
46	115	0.00132	1.3		142			118	115								
47	1175	0.00132	1.3		142			118	115								
48	120	0.00132	1.3		142			118	115								
19																	
20																	
21																	
22																	
23																	
24																	
25																	
26																	
27																	
28																	
29																	
30																	



Filter Number:  
 Filter preweight:  
 Filter postweight:  
 Total:  
 Beaker ID:  
 Beaker preweight:  
 Beaker postweight:  
 Total:

Start Time: 820

End Time:



AIR ANALYSIS, C

POLLUTANT TESTED Metal

Run Number 3

EPA METHOD 29

Company: Alameda State  
 Location: Crowley Road  
 Unit Tested: PP3H  
 Meter Operator: MD  
 Probe Operator: MA  
 Client Contact: MW  
 Agency Contact: SE  
 V.E. Reader: RS  
 AAI Project: Date: 4-12-06  
 Barometric Pressure: 30.15



Traverse Point	Minutes per point	Δ P	Δ H	Diagram of Test Location				Meter Cu. ft.	Static Pressure		Impinger Outlet Temp. (F)	Impinger Inlet Temp. (F)	Meter Inlet Temp. (F)	Meter Outlet Temp. (F)	Vacuum (inches)	NOTES
				Stack Temp. (F)	Probe Temp. (F)	Filter Temp. (F)	Moisture Total									
1	15	0.00133	1.32	700.46	174.5	NA	NA	700.46	174.5	89	92	7				
2	5	0.00133	1.32	703.9	174.4			703.9	174.4	97	90	7				
3	15	0.00133	1.32	703.6	174.4			703.6	174.4	99	90	7				
4	10	0.00133	1.32	707.1	174.4			707.1	174.4	100	90	7				
5	12.5	0.00133	1.32	708	174.4			708	174.4	150	90	7				
6	15	0.00133	1.32	710.2	174.4			710.2	174.4	150	90	7				
7	17.5	0.00133	1.32	711.7	174.4			711.7	174.4	58	91	7				
8	20	0.00133	1.32	713.4	174.4			713.4	174.4	99	92	7				
9	22.5	0.00133	1.32	715.4	174.4			715.4	174.4	150	92	7				
10	25	0.00133	1.32	717.1	174.4			717.1	174.4	150	92	7				
11	27.5	0.00133	1.32	718.9	174.4			718.9	174.4	150	92	7				
12	30	0.00133	1.32	722	174.4			722	174.4	92	92	7				
13	32.5	0.00133	1.32	723.0	174.4			723.0	174.4	98	92	7				
14	35	0.00133	1.32	724.6	174.4			724.6	174.4	98	92	7				
15	37.5	0.00133	1.32	726.2	174.4			726.2	174.4	98	92	7				
16	40	0.00133	1.32	728.1	174.4			728.1	174.4	99	92	7				
17	42.5	0.00133	1.32	729.7	174.4			729.7	174.4	101	92	7				
18	45	0.00133	1.32	731.5	174.4			731.5	174.4	101	93	7				
19	47.5	0.00133	1.32	732.8	174.4			732.8	174.4	101	93	7				
20	50	0.00133	1.32	734.5	174.4			734.5	174.4	102	93	7				
21	52.5	0.00133	1.32	736.1	174.4			736.1	174.4	102	94	7				
22	55	0.00133	1.32	738.0	174.4			738.0	174.4	103	95	7				
23	57.5	0.00133	1.32	739.5	174.4			739.5	174.4	102	95	7				
24	60	0.00133	1.32	740.9	174.4			740.9	174.4	100	96	7				
25	62.5	0.00133	1.32	742.5	174.4			742.5	174.4	104	96	7				
26	65	0.00133	1.32	745	174.4			745	174.4	105	97	7				
27	67.5	0.00133	1.32	746.2	174.4			746.2	174.4	104	98	7				
28	70	0.00133	1.32	747.8	174.4			747.8	174.4	110	98	7				
29	72.5	0.00133	1.32	749.4	174.4			749.4	174.4	110	98	7				
30	75	0.00133	1.32									7				

Filter Number:  
 Filter preweight:  
 Filter postweight:  
 Total:  
 Beaker ID:  
 Beaker preweight:  
 Beaker postweight:  
 Total:

24

Start Time:

1:25 PM



# AIR ANALYSIS, A.C

EPA METHOD 29

POLLUTANT TESTED Metal

RUN NUMBER 3

Company:	Diagram of Test Location		Static Pressure		Meter Cu. ft.	Filter Temp. (F)	Probe Temp. (F)	Filter Temp. (F)	CO2		O2		Nozzle size measurement		NOTES
	Location:	Unit Tested:	Stack Temp. (F)	Probe Temp. (F)					Pretest Pitot Ch. Temp. (F)	Impinger Outlet Temp. (F)	Meter Inlet Temp. (F)	Meter Outlet Temp. (F)	Vacuum (inches)	Pretest Leak Ch. cfm @ 15	
Nuclear			1744	N/A	753.3	NA	NA	NA	107	106	21	21	nozzle (quartz, glass, SS)		
Location:			1744		754.4				106	106	21	21	probe (quartz, glass, SS, Ti)		
Unit Tested:			1744		755.2				106	106	21	21			
Meter Operator:			1744		758.0				98	97	21	21			
Probe Operator:			1744		759				98	98	21	21			
Client Contact:			1744		759.8				99	99	21	21			
Agency Contact:			1744		761.3				99	99	21	21			
V.E. Reader:			1744		763				99	99	21	21			
AAI Project:			1744		764.8				101	102	21	21			
Barometric Pressure:			1744		766.7				103	104	21	21			
Ambient Temperature:			1744		767.9				104	104	21	21			
Traverse Point:	Minutes per point	Δ P	Δ H		769.9				104	104	21	21			
31	77.5	0.00133	1.32		771.2				100	100	21	21			
32	80	0.00132	1.32		772.8				101	101	21	21			
33	82.5	0.00132	1.32		774.3				101	101	21	21			
34	85	0.00133	1.32		776.2				104	104	21	21			
35	87.5	0.00133	1.32		777.9				102	102	21	21			
36	90	0.00133	1.32		779.44				102	102	21	21			
37	92.5	0.00133	1.32												
38	95	0.00133	1.32												
39	97.5	0.00133	1.32												
40	100	0.00133	1.32												
41	102.5	0.00133	1.32												
42	105	0.00133	1.32												
43	107.5	0.00133	1.32												
44	110	0.00133	1.32												
45	112.5	0.00133	1.32												
46	115	0.00133	1.32												
47	117.5	0.00133	1.32												
48	120	0.00133	1.32												
19															
20															
21															
22															
23															
24															
25															
26															
27															
28															
29															
30															



Filter Number:  
 Filter preweight:  
 Filter postweight:  
 Total:  
 Beaker ID: /  
 Beaker preweight:  
 Beaker postweight:  
 Total:

STOP 9:53 AM

Baseline 12468

Date: 4-10-05

2015

Ambient Temperature: 115

ΔAir Analysis, Inc.

NUCOR

Project Number: 302

**APPENDIX IV**

**LABORATORY DATA**

---





**CONDENSIBLE DETERMINATION**

**H2O**

Beaker ID	Run #	Pre-Weight	Post-Weight	Net Gain
e	1	56.0532	56.0581	0.0049
f	2	53.7402	53.7404	0.0002
l	3	65.9153	65.9190	0.0037

**Blank Beaker (500mls H2O)                      55.133                      55.133                      0.0000**

0.0029  
0.967

**MeCl2**

Beaker ID	Run #	Pre-Weight	Post-Weight	Net Gain
c	1	65.7523	65.7524	0.0001
d	2	55.8953	55.8956	0.0003
k	3	54.6505	54.6505	0.0000

**Blank Beaker (50mls MeCl2)                      54.9354                      54.9354                      0.0000**

0.0001  
0.033

**TOTAL**

1	0.0049	0.0001	0.005
2	0.0002	0.0003	0.0005
3	0.0037	0	0.0037


**Air Analysis, Inc.**  
3904 Clarks Creek Road  
Plainfield, IN 46168

Project Number: 302-NUCOR STEEL

Lead & Mercury

EPA Method 29 Analysis


Analytical Report  
5031



Element One, Inc.  
5022-C Wrightsville Av., Wilmington, NC 28403  
910-793-0128 FAX: 910-792-6853 e1lab@e1lab.com

The following data for Analytical Report 5031  
has been reviewed for completeness, accuracy,  
adherence to method protocol,  
and compliance with quality assurance guidelines.

Quality Assurance Review by:



Melissa Lawrence, QA Officer  
May 7, 2005

Report Reviewed and Finalized By:



Ken Smith, Laboratory Director  
May 7, 2005

el<sub>1</sub>

# SUMMARY OF RESULTS

el<sub>1</sub>

## Summary of Analysis

### Summary of Mercury Analysis

Run Number		Average Total Catch, $\mu\text{g}$	Front half $\mu\text{g}$	$\text{H}_2\text{O}_2/\text{HNO}_3$ $\mu\text{g}$	Empty Imp. $\mu\text{g}$	$\text{KMnO}_4$ $\mu\text{g}$
Run 1	#1	2.54	< 0.1	1.32	0.71	0.51
	#2		< 0.1	1.32	0.72	0.51
Run 2	#1	5.48	0.11	1.19	< 0.21	4.18
	#2		0.10	1.18	< 0.21	4.18
Run 3	#1	3.40	0.17	1.38	< 0.2	1.85
	#2		0.17	1.38	< 0.2	1.83
Reagent Blank	#1	< 0.4	< 0.1	< 0.3	< 0.2	< 0.4
	#2		< 0.1	< 0.3	< 0.2	< 0.4

### Summary of Metals Analysis

Element	Run 1 Total $\mu\text{g}$	Run 2 Total $\mu\text{g}$	Run 2 Total $\mu\text{g}$	Run 3 Total $\mu\text{g}$	Reagent Blank Total $\mu\text{g}$
Lead	< 0.5	5.75	5.52	11.1	< 0.5

# **ANALYTICAL NARRATIVE**

**el<sub>1</sub>**

## Element One Analytical Narrative

Client	Air Analysis, Inc.	Element One #:	5031
Client ID:	302- Nucor Steel	Analyst:	DBW, CML, IJJ
Method:	M29	Date Received	4/22/05
Analytes	Pb, & Hg	Dates Analyzed	4/28-5/07/05

### Summary of Analysis

The Method 29 samples were digested, prepared, and analyzed according to Method 29 protocol. Samples were analyzed for mercury on a PerkinElmer FIMS-100 CVAA mercury analyzer. The other metals were analyzed on a PerkinElmer ELAN 6100 ICP-MS.

### Detection Limits

The FIMS-100 CVAA instrument reporting limit for mercury was 0.004 µg per aliquot analyzed. The ICP-MS instrument reporting limit is 2.5µg/L for lead.

### Analysis QA/QC

Duplicate analyses relative percent difference (RPD), spike sample recovery, and second source calibration verification data are summarized in the Quality Control Section. All QA/QC data was within the criteria of the method.

### Additional Comments

The reported results have not been corrected for any blank or spike recovery values. Nothing unusual was noticed with any of the samples or analyses.



# QUALITY CONTROL SUMMARY

el<sub>1</sub>

## Summary of Quality Control Data

### Mercury Duplicate Analysis RPD

Run Number	Front half	H <sub>2</sub> O <sub>2</sub> /HNO <sub>3</sub>	Empty Imp	KMnO <sub>4</sub>
Run 1	NA	0.1%	1.9%	0.3%
Run 2	6.3%	0.8%	NA	0.0%
Run 3	0.7%	0.0%	NA	1.1%
Reagent Blank	NA	NA	NA	NA

### Mercury Spike Recoveries

Run Number		Front half	H <sub>2</sub> O <sub>2</sub> /HNO <sub>3</sub>	Empty Imp	KMnO <sub>4</sub>
Run 3	# 1	103%	101%	102%	95%
	# 2	104%	101%	102%	95%

### Metals Duplicate Analysis RPD and Spike Recoveries

Element	Run 2 RPD	Run 3 Recovery
Lead	4.0%	75%

### Second Source Calibration Check Recoveries

Element	0.25 ppb	1 ppb	100 ppb	200 ppb
Lead		104%	99%	95%

# ANALYTICAL DATA

el<sub>1</sub>

Project ID/ Number:

Nucor Steel / 302

Client: <b>Air Analysis, Inc</b>	Date / Time Received: 4/22/05 / 0945
----------------------------------	--------------------------------------

HNO <sub>3</sub> Lot:	HF Lot:	HCl Lot:	Ref. Method: 29
Volume Marked Y / N	Volume Loss Y / N / ?	pH < 2.0 Y / N	

	Sample Identification		Sample Identification
1	Run 1		
2	Run 2		
3	Run 2 Duplicate		
4	Run 3		
5	Run 3 Spike		
6	Reagent Blank		

Analyses Requested: ~~Sb, As, Ba, Be, Cd, Cr, Co, Cu, Pb, Mn, Ni, P, Se, Ag, Tl, Zn & Hg~~

SAMPLE	Front Half		Back Half			HNO <sub>3</sub> (A)		KMnO <sub>4</sub> (B)		HCl (C)		
	BV, ml	FV, ml	BV, ml	Used	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml	
1	54ml	100ml	290	145	50	109	200	400	500	X		
2/3	52ml		270	135		107	210	430				
4/5	56ml		310	155		113	200	375				
6	100ml		200 H <sub>2</sub> O 100 ml HNO <sub>3</sub>	150		200ml	200	100ml KMnO <sub>4</sub> 33ml DI	Calculate as 400ml			

Comments:

# Sample/Batch Report

User Name: daphne.woodman  
Computer Name: ICPMS1  
Sample File: C:\elandata\Sample\xx.sam  
Report Date/Time: Friday, April 29, 2005 10:13:01

*Daphne Woodman*  
4-29-05

A/S Loc.	Batch ID	Sample ID	Description	Sample Type	Init. Quant.	Prep. Vol.	Aliquot Vol.	Diluted Vol.	Solids Ratio
14		5031-1	Air Analysis, Inc.						
15		5031-2	Air Analysis, Inc.						
16	d	5031-2	Air Analysis, Inc	QC Duplicate					
17		5031-4	Air Analysis, Inc.						
18	s	5031-4	Air Analysis, Inc	Spike - 1					
19		5031-6	Air Analysis, Inc.						
20	x10	5031-1	Air Analysis, Inc.						
21	x500	5031-1	Air Analysis, Inc.						
22	x10	5031-2	Air Analysis, Inc.						
23	x10d	5031-2	Air Analysis, Inc	QC Duplicate					
24	x1000	5031-2	Air Analysis, Inc.						
25	x1000d	5031-2	Air Analysis, Inc	QC Duplicate					
26	x10	5031-4	Air Analysis, Inc.						
27	x10s	5031-4	Air Analysis, Inc	Spike - 1					
28	x1000	5031-4	Air Analysis, Inc.						
29	x1000s	5031-4	Air Analysis, Inc	Spike - 1					
30		5031-6	Air Analysis, Inc.						
5		QC Std #2							
31		200 ppb Ag							
32		5031-1	Air Analysis, Inc.						
33	x1000	5031-1	Air Analysis, Inc.						
34		5031-4	Air Analysis, Inc.						
35	s	5031-4	Air Analysis, Inc	Spike - 1					
38		2.5 ppb Se							
39	x10000	5031-1	Air Analysis, Inc.						
40	x2	5031-4	Air Analysis, Inc.						
41	x2s	5031-4	Air Analysis, Inc	Spike - 1					

# Dataset Report

User Name: daphne.woodman  
 Computer Name: ICPMS1  
 Dataset File Path: c:\elandata\dataset\042805-1\  
 Report Date/Time: Friday, April 29, 2005 10:13:31

*Daphne Woodman*  
*4-29-05*

Autosampler Position: 3

## The Dataset

Time	Sample ID	Batch ID	Read Type	Description	Init. Quant	Prep. Vol.	Aliquot. Vol.	Diluted V
16:41:22 Thu 28-Apr-05	Blank		Blank					
16:44:19 Thu 28-Apr-05	Standard 1		Standard #1					
16:47:16 Thu 28-Apr-05	Standard 2		Standard #2					
16:50:14 Thu 28-Apr-05	Standard 3		Standard #3					
16:53:11 Thu 28-Apr-05	QC Std 1		QC Std #1					
16:56:08 Thu 28-Apr-05	QC Std 2		QC Std #2					
16:59:05 Thu 28-Apr-05	QC Std 3		QC Std #3					
17:02:02 Thu 28-Apr-05	QC Std 4		QC Std #4					
17:05:00 Thu 28-Apr-05	QC Std 6		QC Std #6					
17:07:58 Thu 28-Apr-05	QC Std 7		QC Std #7					
17:10:56 Thu 28-Apr-05	QC Std 8		QC Std #8					
17:13:55 Thu 28-Apr-05	QC Std 9		QC Std #9					
17:16:54 Thu 28-Apr-05	QC Std 10		QC Std #10					
17:19:52 Thu 28-Apr-05	5031-1		Sample	Air Analysis, Inc.				
17:22:48 Thu 28-Apr-05	5031-2		Sample	Air Analysis, Inc.				
17:25:44 Thu 28-Apr-05	5031-2	d	QC Duplicate	Air Analysis, Inc.				
17:28:40 Thu 28-Apr-05	5031-4		Sample	Air Analysis, Inc.				
17:31:37 Thu 28-Apr-05	5031-4	s	Spike - 1	Air Analysis, Inc.				
17:34:33 Thu 28-Apr-05	5031-6		Sample	Air Analysis, Inc.				
17:37:30 Thu 28-Apr-05	5031-1	x10	Sample	Air Analysis, Inc.				
17:40:27 Thu 28-Apr-05	5031-1	x500	Sample	Air Analysis, Inc.				
17:43:25 Thu 28-Apr-05	5031-2	x10	Sample	Air Analysis, Inc.				
17:46:23 Thu 28-Apr-05	5031-2	x10d	QC Duplicate	Air Analysis, Inc.				
17:49:20 Thu 28-Apr-05	QC Std 1		QC Std #1					
17:52:17 Thu 28-Apr-05	QC Std 4		QC Std #4					
17:55:15 Thu 28-Apr-05	5031-2	x1000	Sample	Air Analysis, Inc.				
17:58:14 Thu 28-Apr-05	5031-2	x1000d	QC Duplicate	Air Analysis, Inc.				
18:01:11 Thu 28-Apr-05	5031-4	x10	Sample	Air Analysis, Inc.				
18:04:08 Thu 28-Apr-05	5031-4	x10s	Spike - 1	Air Analysis, Inc.				
18:07:04 Thu 28-Apr-05	5031-4	x1000	Sample	Air Analysis, Inc.				
18:10:01 Thu 28-Apr-05	5031-4	x1000s	Spike - 1	Air Analysis, Inc.				
18:12:57 Thu 28-Apr-05	5031-6		Sample	Air Analysis, Inc.				
18:15:53 Thu 28-Apr-05	QC Std 1		QC Std #1					
18:18:50 Thu 28-Apr-05	QC Std 4		QC Std #4					
09:03:24 Fri 29-Apr-05	QC Std #2		QC Std #2					
09:06:22 Fri 29-Apr-05	200 ppb Ag		Sample					
09:09:19 Fri 29-Apr-05	5031-1		Sample	Air Analysis, Inc.				
09:12:16 Fri 29-Apr-05	5031-1	x1000	Sample	Air Analysis, Inc.				
09:15:14 Fri 29-Apr-05	5031-4		Sample	Air Analysis, Inc.				
09:18:12 Fri 29-Apr-05	5031-4	s	Spike - 1	Air Analysis, Inc.				
09:27:07 Fri 29-Apr-05	QC Std 1		QC Std #1					
09:30:04 Fri 29-Apr-05	QC Std 4		QC Std #4					
09:41:50 Fri 29-Apr-05	2.5 ppb Se		Sample					

09:44:47 Fri 29-Apr-05	5031-1	x10000	Sample	Air Analysis, Inc.
09:47:44 Fri 29-Apr-05	QC Std 1		QC Std #1	
09:50:40 Fri 29-Apr-05	QC Std 4		QC Std #4	
09:53:38 Fri 29-Apr-05	5031-4	x2	Sample	Air Analysis, Inc.
09:56:35 Fri 29-Apr-05	5031-4	x2s	Spike - 1	Air Analysis, Inc.
10:05:25 Fri 29-Apr-05	QC Std 1		QC Std #1	
10:08:22 Fri 29-Apr-05	QC Std 4		QC Std #4	

Analyst: DBW Date: 4-28-05 Solid Samples  / Liquid Samples

*Daphne Welch*  
4-29-05

A/S Loc	Batch # for sample sets	Sample Lab ID	Sample Description	Type Sample QC Spike QC Dup QC Reg Blank	Spike concentratio	Prep Volume (ml)	Aliquot (ml)	Diluted to Volume (ml)	Units
12			LRB	S		100X2			
13			LRB	SS	Table #1	100X2			
14			5031-1	S		100X2			
15			5031-2	S		100X2			
16			5031-2	SD		100X2			
17			5031-4	S		100X2			
18			5031-4	SS	Table #1	100X2			
19			5031-6	S		100X2			
20			5031-1	S		100X2	1.0	10	
21			5031-1	S		100X2	0.02	10	
22			5031-2	S		100X2	1.0	10	
23			5031-2	SD		100X2	1.0	10	
24			5031-2	S		100X2	0.01	10	
25			5031-2	SD		100X2	0.01	10	
26			5031-4	S		100X2	1.0	10	
27			5031-4	SS	Table #1	100X2	1.0	10	
28			5031-4	S		100X2	0.01	10	
29			5031-4	SS	Table #1	100X2	0.01	10	
30			5031-6	S		100X2			

Dilutions and Rechecks

5			QC Std #2						
---	--	--	-----------	--	--	--	--	--	--







Sample_ID	Date	Time	Mean_Sig	Mean_ST	Mean_SA	Units	Alq. Vol.	Sig 1	Std_U 1	Smp_U 1	Sig 2	Std_U 2	Smp_U 2	
Calib Blank	4/28/2005	11:51:28	0.0027957			µg		0.0027957						
STD1=.004ug	4/28/2005	11:52:31	0.00088695			µg		0.00088695						
STD2=.04ug	4/28/2005	11:53:34	0.0089693			µg		0.0089693						
STD3=.08ug	4/28/2005	11:54:40	0.01892292			µg		0.01892292						
STD4=.12ug	4/28/2005	11:55:46	0.0278251			µg		0.0278251						
STD5=.16ug	4/28/2005	11:56:53	0.03692484			µg		0.03692484						
STD6=.2ug	4/28/2005	11:58:01	0.0455182			µg		0.0455182						
Reagent Blank	4/28/2005	11:59:37	0.00006637	0.00029396	0.00029396	µg		0.00018154	0.00080407	0.00080407	-0.0000487	-0.0002161	-0.0002161	
0.004 = DL	4/28/2005	12:04:02	0.00083476	0.00369569	0.00369569	µg		0.00083476	0.00369569	0.00369569				
0.080 = QC STD 2	4/28/2005	12:05:09	0.01819567	0.07973295	0.07973295	µg		0.01819567	0.07973295	0.07973295				
0.080 = QC STD 3	4/28/2005	12:06:16	0.01918385	0.08401424	0.08401424	µg		0.01918385	0.08401424	0.08401424				
REAGENT BLANK	4/28/2005	12:07:20	0.0001008	0.0004465	0.0004465	µg		0.0001008	0.0004465	0.0004465				
0.004 = DL	4/28/2005	13:05:58	0.00091281	0.00404106	0.00404106	µg	4	320	0.00091281	0.00404106	0.00404106			
0.080 = QC STD 2	4/28/2005	13:07:05	0.018561	0.08131632	0.08131632	µg	4	320	0.018561	0.08131632	0.08131632			
REAGENT BLANK	4/28/2005	13:08:09	0.00017973	0.00079603	0.00079603	µg	4	320	0.00017973	0.00079603	0.00079603			
5031-A-1	4/28/2005	13:11:18	0.00032265	0.01426418	0.01426418	µg	4	200	0.000319531	0.01412658	0.070632926	0.00325768	0.01440179	0.7200895
5031-A-2/3	4/28/2005	13:12:54	-0.0000197	-0.0000873	-0.0000873	µg	4	210	0.00000564	0.00002499	0.00131208	-0.000045	-0.0001998	-0.0104799
5031-A-4	4/28/2005	13:14:31	0.00006509	0.00028833	0.01441653	µg	4	200	0.00005423	0.0002402	0.01201049	0.00007596	0.000033645	0.01882257
5031-A-5-SPK	4/28/2005	13:16:08	0.01865649	0.08173009	0.08173009	µg	4	200	0.01863246	0.08162594	4.08129741	0.01868053	0.08183424	4.09171243
5031-A-6	4/28/2005	13:17:45	0.0000854	0.00037826	0.01891321	µg	4	200	0.00014164	0.00062734	0.03136735	0.00002916	0.00012918	0.00645908
5031-B-1	4/28/2005	13:19:23	0.00092502	0.00409507	0.51188429	µg	4	500	0.00092631	0.00410077	0.51259666	0.00092373	0.00408937	0.51117193
5031-B-2/3	4/28/2005	13:21:01	0.0075846	0.03344455	4.18056904	µg	4	500	0.00758551	0.03344851	4.18106397	0.0075837	0.03344059	4.18007411
5031-B-4	4/28/2005	13:22:39	0.00333682	0.01475095	1.8438695	µg	4	500	0.00335493	0.01483085	1.8538563	0.00331871	0.01467106	1.83388269
5031-B-5-SPK	4/28/2005	13:24:14	0.02075617	0.09081603	11.3520047	µg	4	500	0.0207409	0.09075004	11.3437551	0.02077144	0.09088203	11.3602542
0.004 = DL	4/28/2005	13:26:27	0.00095026	0.00420676	0.00420676	µg	4	500	0.00095026	0.00420676	0.00420676			
0.080 = QC STD 2	4/28/2005	13:27:34	0.01870361	0.08193424	0.08193424	µg	4	500	0.01870361	0.08193424	0.08193424			
REAGENT BLANK	4/28/2005	13:28:38	0.00017892	0.00079246	0.00079246	µg	4	500	0.00017892	0.00079246	0.00079246			
5031-B-6	4/28/2005	13:30:10	-0.0000175	-0.0000775	-0.0000775	µg	4	400	-0.0000377	-0.0001672	-0.0167234	0.00000271	0.00001204	0.00120446
5031-BH-1	4/28/2005	13:31:42	0.00411573	0.01818582	1.31847217	µg	4	290	0.00411293	0.01817348	1.31757768	0.00411853	0.01819816	1.31936667
5031-BH-2/3	4/28/2005	13:33:15	0.00398705	0.01761861	1.1892563	µg	4	270	0.00400269	0.01768752	1.1939081	0.00397142	0.01754969	1.1846045
5031-BH-4	4/28/2005	13:34:48	0.00403354	0.01782355	1.38132522	µg	4	310	0.00403328	0.01782239	1.38123549	0.0040338	0.0178247	1.38141494
5031-BH-5-SPK	4/28/2005	13:36:21	0.02251897	0.09842692	7.62808634	µg	4	310	0.02248398	0.098276	7.61639036	0.02255396	0.09857783	7.63978232
5031-BH-6	4/28/2005	13:37:55	0.00011609	0.00051418	0.03856375	µg	4	300	0.00020353	0.00090142	0.06760673	0.00002865	0.00012694	0.00952078
0.004 = DL	4/28/2005	13:46:30	0.0008969	0.00397067	0.00397067	µg	4	200	0.0008969	0.00397067	0.00397067			
0.080 = QC STD 2	4/28/2005	13:47:37	0.01866102	0.08174971	0.08174971	µg	4	200	0.01866102	0.08174971	0.08174971			
REAGENT BLANK	4/28/2005	13:48:41	0.00018943	0.00083901	0.00083901	µg	4	200	0.00018943	0.00083901	0.00083901			
0.004 = DL	4/28/2005	14:41:32	0.00094513	0.00418408	0.00418408	µg	4	700	0.00094513	0.00418408	0.00418408			
0.080 = QC STD 3	4/28/2005	14:42:39	0.01914398	0.08384159	0.08384159	µg	4	700	0.01914398	0.08384159	0.08384159			
REAGENT BLANK	4/28/2005	14:43:44	0.00025959	0.00114968	0.00114968	µg	4	700	0.00025959	0.00114968	0.00114968			
Calib Blank	4/28/2005	15:30:36	0.00315633			µg		0.00315633						
STD1=.004ug	4/28/2005	15:31:40	0.00110689			µg		0.00110689						
STD2=.04ug	4/28/2005	15:32:44	0.01024893			µg		0.01024893						
STD3=.08ug	4/28/2005	15:33:49	0.02107251			µg		0.02107251						
STD4=.12ug	4/28/2005	15:34:55	0.03059855			µg		0.03059855						
STD5=.16ug	4/28/2005	15:36:02	0.04119103			µg		0.04119103						
STD6=.2ug	4/28/2005	15:37:10	0.05061039			µg		0.05061039						
Reagent Blank	4/28/2005	15:38:46	0.00037005	0.00137381	0.00137381	µg		0.0006621	0.00245827	0.00245827	0.00007799	0.00028936	0.00028936	
0.004 = DL	4/28/2005	15:42:25	0.00110223	0.00409474	0.00409474	µg		0.00110223	0.00409474	0.00409474				
0.080 = QC STD 2	4/28/2005	15:43:31	0.02159506	0.08245496	0.08245496	µg		0.02159506	0.08245496	0.08245496				
0.080 = QC STD 3	4/28/2005	15:44:37	0.02113913	0.08066424	0.08066424	µg		0.02113913	0.08066424	0.08066424				
REAGENT BLANK	4/28/2005	15:45:41	0.00043178	0.00160263	0.00160263	µg		0.00043178	0.00160263	0.00160263				
5025/5031-FH-BLK	4/28/2005	15:47:14	0.00018098	0.00067154	0.01678865	µg	4	100	0.00016452	0.00061044	0.01526112	0.00019745	0.00073264	0.01831618
5025/5031-FH-BLK-S	4/28/2005	15:48:47	0.01905613	0.07251101	4.53193813	µg	1.6	100	0.01898927	0.07225007	4.51562971	0.01912298	0.07277194	4.54824655
5025/5031-FH-6	4/28/2005	15:56:49	0.00067602	0.00251008	0.06275211	µg	4	100	0.00081606	0.0030305	0.0757625	0.00053598	0.00198966	0.04974172
5031-FH-2/3	4/28/2005	16:00:04	0.00115552	0.00429304	0.10732621	µg	4	100	0.001192	0.00442875	0.11071893	0.00111905	0.00415733	0.10393349
5031-FH-4	4/28/2005	16:01:37	0.00187075	0.0069568	0.17392018	µg	4	100	0.00187688	0.00697966	0.17449163	0.00186461	0.00693394	0.17334873
0.004 = DL	4/28/2005	16:02:42	0.00113023	0.00419891	0.00419891	µg	4	100	0.00113023	0.00419891	0.00419891			
0.080 = QC STD 2	4/28/2005	16:03:50	0.02169196	0.08283586	0.08283586	µg	4	100	0.02169196	0.08283586	0.08283586			
REAGENT BLANK	4/28/2005	16:04:54	0.00041923	0.00155603	0.00155603	µg	4	100	0.00041923	0.00155603	0.00155603			
Calib Blank	4/28/2005	17:17:54	0.0033103			µg	4	200	0.0033103					
STD1=.004ug	4/28/2005	17:18:57	0.00098543			µg	4	200	0.00098543					
STD2=.04ug	4/28/2005	17:20:02	0.01046968			µg	4	200	0.01046968					
STD3=.08ug	4/28/2005	17:21:07	0.02137058			µg	4	200	0.02137058					
STD4=.12ug	4/28/2005	17:22:13	0.03152574			µg	4	200	0.03152574					
STD5=.16ug	4/28/2005	17:23:20	0.04216271			µg	4	200	0.04216271					
STD6=.2ug	4/28/2005	17:24:28	0.05159739			µg	4	200	0.05159739					
Reagent Blank	4/28/2005	17:29:02	0.00047997	0.00187354	0.00187354	µg	4	200	0.00097793	0.00381736	0.00381736	-0.0000179	-0.0000702	-0.0000702
0.004 = DL	4/28/2005	17:30:07	0.00099915	0.00390014	0.00390014	µg	4	200	0.00099915	0.00390014	0.00390014			
0.080 = QC STD 2	4/28/2005	17:31:14	0.02166576	0.08354377	0.08354377	µg	4	200	0.02166576	0.08354377	0.08354377			
0.080 = QC STD 3	4/28/2005	17:32:21	0.02162116	0.08337398	0.08337398	µg	4	200	0.02162116	0.08337398	0.08337398			
REAGENT BLANK	4/28/2005	17:33:25	0.00047467	0.00185343	0.00185343	µg	4	200	0.00047467	0.00185343	0.00185343			
5031-FH-1	4/28/2005	17:36:36	0.00072609	0.00283471	0.07088785	µg	4	100	0.00075169	0.00293462	0.07336573	0.00070048	0.00273479	0.06836997
5031-FH-5-SPK	4/28/2005	17:38:13	0.02336621	0.08999521	2.24988044	µg	4	100	0.02328248	0.08969269	2.2423174	0.02344173	0.09029773	2.25744347
0.004 = DL	4/28/2005	17:50:33	0.00096775	0.00377764	0.00377764	µg	4	200	0.00096775	0.00377764	0.00377764			
0.080 = QC STD 2	4/28/2005	17:51:40	0.02139496	0.0825127	0.0825127	µg	4	200	0.02139496	0.0825127	0.0825127			
REAGENT BLANK	4/28/2005	17:52:44	0.00044525	0.0017386	0.0017386									

Method 6020 & 200.8 Metals Summary Report

Sample ID: Blank

Sample Da Thursday, April 28, 2005 16:41:22

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas Report Unit
	Li	6	301321.5	ppb
-	Sc	45	172316.1	ppb
>	Rh	103	304097.6	ppb
>	Ho	165	764832.7	ppb
-	Pb	208	4539.8	ppb
	Kr	83	85.3	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: Standard 1

Sample Da Thursday, April 28, 2005 16:44:19

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas Report Unit
	Li	6	319751.5	ppb
-	Sc	45	176723.4	ppb
>	Rh	103	314488.6	ppb
>	Ho	165	796905.2	ppb
-	Pb	208	38668.7	1.00228 ppb
	Kr	83	93.3	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: Standard 2

Sample Da Thursday, April 28, 2005 16:47:16

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas Report Unit
	Li	6	317483.4	ppb
-	Sc	45	176370.7	ppb
>	Rh	103	311507.7	ppb
>	Ho	165	810360.2	ppb
-	Pb	208	3390275	98.31932 ppb
	Kr	83	98.7	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: Standard 3

Sample Da Thursday, April 28, 2005 16:50:14

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas Report Unit
	Li	6	305887	ppb
-	Sc	45	174635.5	ppb
>	Rh	103	301683.5	ppb
>	Ho	165	787823.9	ppb
-	Pb	208	16756078	500.3361 ppb
	Kr	83	156.3	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 1

Sample Da Thursday, April 28, 2005 16:53:11

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas Report Unit
	Li	6	297494	ppb
-	Sc	45	167883.5	ppb
>	Rh	103	303691.4	ppb
>	Ho	165	766543.9	ppb
-	Pb	208	13934.3	0.28809 ppb
	Kr	83	101.7	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 2

Sample Da Thursday, April 28, 2005 16:56:08

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas Report Unit
	Li	6	305435.9	ppb
-	Sc	45	173215	ppb
>	Rh	103	311801.2	ppb
>	Ho	165	795795.3	ppb
-	Pb	208	39711.4	1.03458 ppb
	Kr	83	101.7	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 3

Sample Da Thursday, April 28, 2005 16:59:05

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas Report Unit
	Li	6	306121.3	ppb
-	Sc	45	173202.1	ppb
>	Rh	103	305183.3	ppb
>	Ho	165	784793.1	ppb
-	Pb	208	6369395	190.8724 ppb
	Kr	83	116.7	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 4

Sample Da Thursday, April 28, 2005 17:02:02

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas Report Unit
	Li	6	309125.4	ppb
-	Sc	45	174380.4	ppb
>	Rh	103	310074.6	ppb
>	Ho	165	795036.7	ppb
-	Pb	208	3338269	98.6743 ppb
	Kr	83	111	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 6

Sample Da Thursday, April 28, 2005 17:05:00

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas Report Unit
	Li	6	312453.2	ppb
-	Sc	45	158734.3	ppb
>	Rh	103	256238.9	ppb
>	Ho	165	719536.7	ppb
-	Pb	208	11479.4	0.23565 ppb
	Kr	83	114.3	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 7

Sample Da Thursday, April 28, 2005 17:07:58

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas Report Unit
	Li	6	327002.7	ppb
-	Sc	45	160274.9	ppb
>	Rh	103	261928.6	ppb
>	Ho	165	723367.1	ppb
-	Pb	208	8542.5	0.13824 ppb
	Kr	83	107.7	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 9

Sample Da Thursday, April 28, 2005 17:13:55

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas Report Unit
	Li	6	357592.8	ppb
-	Sc	45	180103.9	ppb
>	Rh	103	297508.6	ppb
>	Ho	165	800582.1	ppb
-	Pb	208	21550.4	0.49375 ppb
	Kr	83	51	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 10

Sample Da Thursday, April 28, 2005 17:16:54

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas Report Unit
	Li	6	345234.6	ppb
-	Sc	45	169546.2	ppb
>	Rh	103	283028.8	ppb
>	Ho	165	770042.5	ppb
-	Pb	208	1590206	48.45306 ppb
	Kr	83	57.7	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: 5031-1

Sample Da Thursday, April 28, 2005 17:19:52

Sample De Air Analysis, Inc.

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas Report Unit
	Li	6	237235	ppb
-	Sc	45	723105.4	ppb
>	Rh	103	212828.3	ppb
>	Ho	165	662696.9	ppb
-	Pb	208	3567.3	-0.01259 ppb
	Kr	83	2348.3	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: 5031-2

Sample Da Thursday, April 28, 2005 17:22:48

Sample De Air Analysis, Inc.

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas Report Unit
	Li	6	242987.7	ppb
-	Sc	45	537601.5	ppb
>	Rh	103	242332.8	ppb
>	Ho	165	846931.1	ppb
-	Pb	208	1039289	28.74923 ppb
	Kr	83	1485.5	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: 5031-2

Sample Da Thursday, April 28, 2005 17:25:44

Sample De Air Analysis, Inc.

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas Report Unit
	Li	6	264368.7	ppb
-	Sc	45	468424.1	ppb
>	Rh	103	270463.3	ppb
>	Ho	165	908751.7	ppb
-	Pb	208	1071745	27.61421 ppb
	Kr	83	1494.5	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: 5031-6

Sample Da Thursday, April 28, 2005 17:34:33

Sample De Air Analysis, Inc.

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas Report Unit
	Li	6	393244.1	ppb
-	Sc	45	546936.3	ppb
>	Rh	103	317327.9	ppb
>	Ho	165	846917.5	ppb
-	Pb	208	38712.8	0.93624 ppb
	Kr	83	255	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 1

Sample Da Thursday, April 28, 2005 17:49:20

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas Report Unit
	Li	6	278090.9	ppb
-	Sc	45	175091.7	ppb
>	Rh	103	306105.1	ppb
>	Ho	165	769206.5	ppb
-	Pb	208	3496.6	-0.03268 ppb
	Kr	83	78.7	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 4

Sample Da Thursday, April 28, 2005 17:52:17

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas Report Unit
	Li	6	286013.6	ppb
-	Sc	45	181138.1	ppb
>	Rh	103	315440.6	ppb
>	Ho	165	801484.9	ppb
-	Pb	208	3339358	97.91067 ppb
	Kr	83	94.3	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 1

Sample Da Friday, April 29, 2005 09:47:44

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas Report Unit
	Li	6	233671	ppb
-	Sc	45	185997	ppb
>	Rh	103	351048.4	ppb
>	Ho	165	852118.7	ppb
-	Pb	208	3723.6	-0.03685 ppb
	Kr	83	88.7	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 4

Sample Da Friday, April 29, 2005 09:50:40

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas Report Unit
	Li	6	243776.8	ppb
-	Sc	45	190097.1	ppb
>	Rh	103	359745.8	ppb
>	Ho	165	870101.9	ppb
-	Pb	208	3587950	96.9022 ppb
	Kr	83	87.7	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: 5031-4

Sample Da Friday, April 29, 2005 09:53:38

Sample De Air Analysis, Inc.

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas. Report Unit
	Li	6	193517.6	ppb
-	Sc	45	329617.2	ppb
>	Rh	103	256536.4	ppb
>	Ho	165	844853.4	ppb
-	Pb	208	1000061	27.7146 ppb
	Kr	83	1106.7	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: 5031-4

Sample Da Friday, April 29, 2005 09:56:35

Sample De Air Analysis, Inc.

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas. Report Unit
	Li	6	189413	ppb
-	Sc	45	316656.6	ppb
>	Rh	103	266233.3	ppb
>	Ho	165	877750	ppb
-	Pb	208	2443374	65.37028 ppb
	Kr	83	1146.1	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 1

Sample Da Friday, April 29, 2005 10:05:25

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas. Report Unit
	Li	6	213197.4	ppb
-	Sc	45	183149.4	ppb
>	Rh	103	355426.7	ppb
>	Ho	165	849427.2	ppb
-	Pb	208	6087.8	0.02923 ppb
	Kr	83	85	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 4

Sample Da Friday, April 29, 2005 10:08:22

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inter Conc.	Meas. Report Unit
	Li	6	215622.9	ppb
-	Sc	45	187456.9	ppb
>	Rh	103	366168.5	ppb
>	Ho	165	879440.2	ppb
-	Pb	208	3558382	95.07217 ppb
	Kr	83	84.7	ppb



ΔAir Analysis, Inc.

NUCOR

Project Number: 302

**APPENDIX V**

**CHAIN OF CUSTODY**

---

**Air Analysis, Inc**  
 3904 Clarks Creek Road  
 Plainfield, IN 46168  
 PH: 317-837-8514  
 FAX: 317-837-8518

**Chain of Custody Form**

Date: 4-21-05

Job Number: 302

Invoice to:  
 Air Analysis, Inc  
 3904 Clarks Creek Road  
 Plainfield, IN 46168

Report to:  
 Mike Dicen @ above address  
 Fax Results to 317-837-8518

Additional Notes

ATP has blanks for  
 this job  
 Nucor Steel  
 test.

Sample ID	Number of Containers	Description	Container P or G	Sample Date	Analysis to perform
R1	1	Filter	P	4-18	Method 29
R2	1	Filter	P	4-18	Full Metals
R3	1	Filter	P	4-19	Analysis
Blank	1	Filter	P		
R1	1	Probe/Nozzle/Line	P	4-18	
R2	1	Rinse	P	4-18	
R3	1	↓	P	4-19	
R1	1	Impinger 1-2	P	4-18	
R2	1	Rinse	P	4-18	
R3	1	↓	P	4-19	
R1	1	Impinger 3	P	4-18	
R2	1	Rinse	P	4-18	
R3	1	↓	P	4-19	

AIRBILL NUMBER

SHIPMENT METHOD Fed Ex

24 HR

48 HR

5 BUSINESS DAYS

10 BUSINESS DAYS

OTHER

Normal

Required Turnaround	24 HR	48 HR	5 BUSINESS DAYS	10 BUSINESS DAYS	OTHER
RELINQUISHED BY	Date	RELINQUISHED BY	Date	RELINQUISHED BY	COURIER
Company	Time	Company	Time	Company	
RECEIVED BY	Date	RECEIVED BY	Date	RECEIVED BY	
Company	Time	Company	Time	Company	







**Certificate of Analysis**  
EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

B16341B

Notice: This Cylinder is not to be used when pressure is under 150 psig.

*Manufactured and certified at:*

AGA Gas, Inc.  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

*Produced for customer:*

AGA COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

<b>Material:</b>	6647 EPA C3H8/N2 1-99 PPM	<b>Blend Tolerance:</b>	5 % Relative
<b>Production #:</b>	100061496	<b>Store/Use Temp:</b>	35 to 90 F
<b>Batch #:</b>	02499M2180MC	<b>Blend Type:</b>	EPA Protocol
<b>Cylinder #:</b>	CC41701	<b>Cyl. Pressure:</b>	2000 psig
<b>Expiration Date:</b>	12/23/2005	<b>Balance Gas:</b>	Nitrogen
<b>Shelf Life:</b>	36 months	<b>CGA:</b>	350
		<b>Analytical Accuracy:</b>	1.00 % Relative

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
74-98-6	Propane	38	38.9 +/- 0.4 ppm	12/23/2002
7727-37-9	Nitrogen		Balance	12/23/2002

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
74-98-6	Propane	CC206 , GMIS	3.113 ppm	12/31/2003
7727-37-9	Nitrogen	CC154126 , GMIS	Bal	12/19/2004

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba FIA-510	56847471	Flame Ionization	12/22/2002

*This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.*

Analytical report approved by Jim Healy



**HiQ** Analysis  
Certificate

**Certificate of Analysis**  
EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

*Manufactured and certified at:*

AGA Gas, Inc.  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

*Produced for customer:*

AGA COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

<b>Material:</b>	6647 EPA C3H8/N2 1-99 PPM	<b>Blend Tolerance:</b>	5 % Relative
<b>Production #:</b>	100077553	<b>Blend Type:</b>	EPA Protocol
<b>Lot #:</b>	02499M3020ZE	<b>Cyl. Pressure:</b>	2000 psig
<b>Cylinder #:</b>	CC13911	<b>Balance Gas:</b>	Nitrogen
<b>Expiration Date:</b>	12/15/2006	<b>CGA:</b>	350
<b>Shelf Life:</b>	36 months	<b>Analytical Accuracy:</b>	1.00 % Relative
		<b>Confidence:</b>	95 %

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
74-98-6	Propane	64	63.7 +/- 0.6 ppm	12/15/2003
7727-37-9	Nitrogen		Balance	12/15/2003

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
74-98-6	Propane	CC100454 , GMIS	10.52 ppm	06/05/2005
74-98-6	Propane	CC154126 , GMIS	101.0 ppm	06/05/2005

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba FIA-510	56847471	Flame Ionization	11/11/2003

*This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.*

B17112B

Analytical report approved by Jim Healy

*Jim R. Healy*



**Certificate of Analysis**  
EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

B16343 B

Notice: This Cylinder is not to be used when pressure is under 150 psig.

Manufactured and certified at:

AGA Gas, Inc.  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

Produced for customer:

AGA COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

<b>Material:</b>	4004 EPA PROPANE/N2 100-999 PPM	<b>Blend Tolerance:</b>	5 % Relative
<b>Production #:</b>	100061487	<b>Store/Use Temp:</b>	35 to 90 F
<b>Batch #:</b>	02499M2170GF	<b>Blend Type:</b>	EPA Protocol
<b>Cylinder #:</b>	CC42922	<b>Cyl. Pressure:</b>	2000 psig
<b>Expiration Date:</b>	12/23/2005	<b>Balance Gas:</b>	Nitrogen
<b>Shelf Life:</b>	36 months	<b>CGA:</b>	350
		<b>Analytical Accuracy:</b>	1.00 % Relative

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
74-98-6	Propane	108	109 +/- 1 ppm	12/23/2002
7727-37-9	Nitrogen		Balance	12/23/2002

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
74-98-6	Propane	CC73695, GMIS	1021 ppm	06/14/2004
7727-37-9	Nitrogen	CC154126, GMIS	Bal	12/19/2004

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba FIA-510	56847471	Flame Ionization	12/22/2002

This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

Analytical report approved by Jim Healy

**HQ** Analysis Certificate





**CALIBRATION CHECK**  
 (Post Test) per EMTC Guideline GD-26  
 04/15/05

Nucor Steel  
 Crawfordsville

Y <sub>avg</sub> =	1.030	0.943	0.956	0.978
--------------------	-------	-------	-------	-------

Average result must be within 5% of Y

(Range %): -1.51%

PASS POST CAL

ID:	79
Y:	0.998
Delta H:	1.59

NUM	Volume	Delta H	DOM (Inlet)	DOM (Outlet)
1	1,300		101	104
2	1,300		99	103
3	1,300		99	103
4	1,300		99	103
5	1,300		99	101
6	1,300		99	101
7	1,300		97	99
8	1,300		97	99
9	1,300		97	97
10	1,300		97	98
11	1,300		102	98
12	1,300		100	98
13	1,300		111	98
14	1,300		111	97
15	1,300		111	98
16	1,300		111	98
17	1,300		111	98
18	1,300		111	98
19	1,300		111	98
20	1,300		109	99
21	1,300		110	99
22	1,300		111	100
23	1,300		111	100
24	1,300		111	100
25	1,300		111	100
26	1,300		112	104
27	1,300		111	104
28	610.020		111	104
29	617.227		111	104
30	1,300		111	104

Volume	72,170	Avg. Dh	1.31	Avg. Meter (F)	103.17
--------	--------	---------	------	----------------	--------

Barometric Pressure:	30.14	Water T:	0.898
Test Time:	120	Delta H:	1.80

Y<sub>avg</sub> = 1.030

NUM	Volume	Delta H	DOM (Inlet)	DOM (Outlet)
1	1,34		99	92
2	1,34		97	90
3	1,34		99	90
4	1,34		100	90
5	1,34		100	90
6	1,34		100	90
7	1,34		99	91
8	1,34		99	92
9	1,34		100	92
10	1,34		100	92
11	1,34		100	92
12	1,34		100	92
13	1,34		98	92
14	1,34		98	92
15	1,34		98	92
16	1,34		98	92
17	1,34		99	92
18	1,34		101	92
19	1,34		101	92
20	1,34		101	92
21	1,34		102	93
22	1,34		102	94
23	1,34		101	94
24	1,34		102	94
25	1,34		100	94
26	1,34		104	94
27	610.020		104	97
28	610.290		104	98
29	1,34		110	98
30	1,34		110	98

Volume	60,750	Avg. Dh	1.34	Avg. Meter (F)	98.97
--------	--------	---------	------	----------------	-------

Barometric Pressure:	30.14	Water T:	0.898
Test Time:	120	Delta H:	1.800

Y<sub>avg</sub> = 0.943

NUM	Volume	Delta H	DOM (Inlet)	DOM (Outlet)
1	1.32		89	92
2	1.32		97	90
3	1.32		99	90
4	1.32		100	90
5	1.32		100	90
6	1.32		100	90
7	1.32		99	91
8	1.32		99	92
9	1.32		100	92
10	1.32		100	92
11	1.32		100	92
12	1.32		100	92
13	1.32		99	92
14	1.32		98	92
15	1.32		98	92
16	1.32		98	92
17	1.32		99	92
18	1.32		101	92
19	1.32		101	92
20	1.32		101	92
21	1.32		102	93
22	1.32		102	94
23	1.32		101	94
24	1.32		102	94
25	1.32		100	94
26	1.32		104	94
27	770.441		105	97
28	780.484		105	98
29	1.32		110	98
30	1.32		110	98

Volume	79,877	Avg. Dh	1.32	Avg. Meter (F)	98.97
--------	--------	---------	------	----------------	-------

Barometric Pressure:	30.14	Water T:	0.898
Test Time:	120	Delta H:	1.800

Y<sub>avg</sub> = 0.968

**GRASEBY NUTECH**  
**EPA Method 5**  
**Meter Box Calibration**  
**Post-Test Orifice Method**  
**English Meter Box Units, English K' Factor**

Filename: C:\Documents and Settings\michael dicen\My Documents\meter box#80cal.XLS\BJPTCCAL  
 Revised: 8/1/97 Version: 1.01

Model #: mst  
 Serial #: 90680.00

Date: \_\_\_\_\_  
 Barometric Pressure: \_\_\_\_\_  
 Theoretical Critical Vacuum: \_\_\_\_\_

30.05 (in. Hg)  
 14.17 (in. Hg)

!!!!!!!  
**IMPORTANT** For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.  
**IMPORTANT** The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>\*(deg R)<sup>0.5</sup>/((in.Hg)<sup>x</sup>(mm)).  
 !!!!!!!!

----- DRY GAS METER READINGS -----

Delta H (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Initial Temps.		Final Temps.		Orifice K' Orifice Serial# (number)	Coefficient (see above)	Actual - Ambient Temperature -		Average (deg F)
				Total (cu ft)	Vcr (cu ft)	Inlet (deg F)	Outlet (deg F)			Inlet (deg F)	Outlet (deg F)	
1.62	5.00	832.500	836.070	3.570	56.0	57.0	57.0	3	0.533	18.5	58.0	57.0
1.62	5.00	836.070	839.610	3.540	57.0	58.0	57.0	3	0.533	18.5	57.0	57.0
1.62	5.00	839.610	843.186	3.576	58.0	58.0	57.0	3	0.533	18.5	57.0	57.0

----- CRITICAL ORIFICE READINGS -----

\*\*\*\*\* RESULTS \*\*\*\*\*

--- DRY GAS METER ---

VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED
Vm(std) (cu ft)	Vm(std) (liters)	Vm(std) (cu ft)	Vm(std) (liters)	Vcr (cu ft)	Vcr (liters)	Vcr (cu ft)	Vcr (liters)	Y (number)	Y (number)	Y (number)	Y (number)	Y (number)
3.678	104.2	3.523	99.8	3.439	97.8	0.958	-0.004	0.958	0.968	0.968	0.958	0.961
3.642	103.1	3.525	99.8	3.438	97.8	0.968	0.006	0.968	0.968	0.968	0.958	0.961
3.677	104.1	3.525	99.8	3.438	97.8	0.958	-0.003	0.958	0.958	0.958	0.958	0.961

Average Y →

--- DRY GAS METER ---

CALIBRATION FACTOR		CALIBRATION FACTOR	
Value	Variation	Value	Variation
1.884	0.002	1.884	0.002
1.881	-0.001	1.881	-0.001
1.881	-0.001	1.881	-0.001
1.882	47.80	1.882	47.80

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.2.

For Orifice Calibration Factor dh@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/-0.2.

SIGNED: 

Date: 01/03/2005

**GRASEBY NUTECH**  
**EPA Method 5**  
**Meter Box Calibration**  
**Post-Test Orifice Method**  
**English Meter Box Units, English K' Factor**

Filename: C:\Documents and Settings\michael dicea\My Documents\meter box#79cal.XLS\3PTCCQCAL  
 Revised: 8/1/97 Version: 1.01

Model #: mst  
 Serial #: 90679.00  
 Date: \_\_\_\_\_  
 Barometric Pressure: \_\_\_\_\_  
 Theoretical Critical Vacuum: \_\_\_\_\_

30.05 (in. Hg)  
 14.17 (in. Hg)

!!!!!!!  
 IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.  
 IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>/(deg R)<sup>0.5</sup>((in.Hg)<sup>3</sup>(mm)).  
 !!!!!!!!

**-CRITICAL ORIFICE READINGS-**

Delta H (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Final Temps.		Orifice K' Orifice Serial# (number)	Coefficient (see above)	Actual - Ambient Temperature -		
					Inlet (deg F)	Outlet (deg F)			Vacuum (in Hg)	Final (deg F)	Average (deg F)
1.62	5.00	660.800	664.310	3.510	56.0	55.0	3	0.533	18.0	57.0	57.0
1.62	5.00	664.310	667.970	3.660	57.0	56.0	3	0.533	18.0	57.0	57.0
1.62	5.00	667.970	671.429	3.459	58.0	56.0	3	0.533	18.0	57.0	58.0

**--- DRY GAS METER READINGS ---**

**\*\*\*\*\* RESULTS \*\*\*\*\***

**--- DRY GAS METER ---**

VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	CALIBRATION FACTOR	
						Y	ORIFICE
Vm(std) (cu ft)	Vm(std) (liters)	Vc (cu ft)	Vc (liters)	Vc (cu ft)	Vc (liters)	Value (in H2O)	Value (mm H2O)
3.622	102.6	3.525	99.8	3.438	3.438	1.888	47.96
3.771	106.8	3.525	99.8	3.438	3.438	1.886	47.91
3.557	100.7	3.523	99.8	3.439	3.439	1.886	47.91
Average Y →						1.887	47.93

**--- DRY GAS METER ---**

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.

For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.

SIGNED: \_\_\_\_\_  
 Date: 01/03/2005

# ΔAir Analysis, Inc.

3904 Clarks Creek Road  
Plainfield, Indiana 46168  
(317) 837-8514  
(317) 837-8518 fax

## Pitot Tube Calibration

Reference: 40CFR 60, Appendix A, Method 2, Section 2.1

External Tubing Diameter: 0.95 centimeters  
Base to Opening Plane Distance (Pa): 1.2 centimeters  
Base to Opening Plane Distance (Pb): 1.2 centimeters

	Measured	Allowable
Pa/Dt	1.26cm	1.05Dt ≤ P ≤ 1.50Dt (0.9975cm - 1.42cm)
Pb/Dt	1.26cm	1.05Dt ≤ P ≤ 1.50Dt (0.9975cm - 1.42cm)
Angle α 1	1 deg	α 1 and α 2 ≤ 10.0°
Angle α 2	1 deg	α 1 and α 2 ≤ 10.0°
Angle β 1	0 deg	β 1 and β 2 ≤ 5.0°
Angle β 2	0 deg	β 1 and β 2 ≤ 5.0°
z (cm)	0.0	z is less than 0.32cm (1/8 <sup>th</sup> " )
w (cm)	0.0	w is less than 0.08cm (1/32 <sup>nd</sup> " )
If all criteria are met, Pitot Coefficient is 0.84		<b>Pitot Coefficient: 0.84</b>

Calibrated By: *Marcus Allen* Date Calibrated: January 3, 2005

## Thermocouple Test

Control factor	Mercury Thermometer F	Probe Response
ICE	41°	39°
AMBIENT	59°	58°
BOILING/ HOT H2O	140°	139°

Test performed by: *Marcus Allen* Date of test: January 3, 2005

ΔAir Analysis, Inc.

NUCOR

Project Number: 302

**APPENDIX VII**

**VISIBLE EMISSIONS DATA**

---

**CARL KOONTZ ASSOCIATES  
SMOKE SCHOOL TRAINING FORM**

NAME RONALD STAPERT RUN # 1 SUNGLASSES YES  
 COMPANY AIR ANALYTICS COURSE LOCATION IND-1 IND.  
 DATE 3-24-05 SKY S WIND S DISTANCE & DIRECTION TO STACK \_\_\_\_\_

WHITE

ERROR

1	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
2	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
3	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
4	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
5	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
6	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
7	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
8	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
9	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
10	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
11	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
12	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
13	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
14	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
15	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
16	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
17	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
18	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
19	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
20	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
21	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
22	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
23	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
24	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1
25	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1

**CARL KOONTZ ASSOCIATES**  
 of Nashville, Tennessee  
 This is to acknowledge that  
RONALD STAPERT  
 successfully participated in Visible Emissions  
 training on MAR 24 2005  
 and is qualified to evaluate Visible Emissions  
 for a period of six (6) months from the date of  
 certification.  
*Carl Koontz*  
 Instructor

DEVIATION 11

2.2

BLACK

26	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	26	0
27	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	27	0
28	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	28	0
29	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	29	0
30	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	30	1
31	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	31	1
32	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	32	0
33	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	33	1
34	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	34	1
35	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	35	0
36	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	36	0
37	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	37	1
38	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	38	1
39	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	39	1
40	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	40	1
41	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	41	0
42	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	42	2
43	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	43	1
44	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	44	1
45	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	45	1
46	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	46	1
47	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	47	1
48	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	48	1
49	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	49	0
50	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	50	0

I hereby certify that the above readings  
 are my own.

DEVIATION 15

3.0


Visible Emissions Observations Form

RUN NUMBER

1

SOURCE NAME <b>NUCOR STEEL</b>			OBSERVATION DATE <b>4-18-05</b>			START TIME PA <b>12:47</b>		STOP TIME <b>1:47</b>	
ADDRESS			sec				sec		
CITY <b>CRAWFORDSVILLE</b>			min	0	15	30	45	min	0
STATE <b>IN</b>			1	0	0	0	0	31	0
ZIP			2	0	0	0	0	32	0
PHONE			3	0	0	0	0	33	0
SOURCE ID NUMBER <b>EAF &amp; AOD</b>			4	0	0	0	0	34	0
PROCESS EQUIPMENT <b>STEEL MELT ROOF MONI</b>			5	0	0	0	0	35	0
OPERATING MODE			6	0	0	0	0	36	0
CONTROL EQUIPMENT			7	0	0	0	0	37	0
OPERATING MODE			8	0	0	0	0	38	0
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <del>XXXXXXXXXX</del> <b>ROOF MOUNT VENT</b>			9	0	0	0	0	39	0
HEIGHT ABOVE GROUND LEVEL START <b>160</b> STOP			10	0	0	0	0	40	0
HEIGHT RELATIVE TO OBSERVER START <b>120</b> STOP			11	0	0	0	0	41	0
DISTANCE FROM OBSERVER START <b>500'</b> STOP			12	0	0	0	0	42	0
DIRECTION FROM OBSERVER START <b>30°</b> STOP			13	0	0	0	0	43	0
DESCRIBE EMISSIONS START <b>CLEAR</b> STOP			14	0	0	0	0	44	0
EMISSION COLOR START <b>CLEAR</b> STOP			15	0	0	0	0	45	0
PLUME TYPE: <b>CONTINUOUS</b>			16	0	0	0	0	46	0
FUGITIVE INTERMITTENT			17	0	0	0	0	47	0
WATER DROPLETS PRESENT <b>NO</b> YES			18	0	0	0	0	48	0
IF WATER DROPLET PLUME: ATTACHED <b>DETACHED</b>			19	0	0	0	0	49	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <b>2' ALONG TOP</b> STOP			20	0	0	0	0	50	0
DESCRIBE BACKGROUND START <b>LIGHT BLUE</b> STOP			21	0	0	0	0	51	0
BACKGROUND COLOR START <b>LIGHT BLUE</b> STOP			22	0	0	0	0	52	0
SKY CONDITIONS START <b>MOSTLY SUNNY</b> STOP			23	0	0	0	0	53	0
WIND SPEED (MPH) <b>5 to 10 MPH</b>			24	0	0	0	0	54	0
WIND DIRECTION START <b>NW</b> STOP			25	0	0	0	0	55	0
AMBIENT TEMPERATURE (F) START <b>70'</b> STOP <b>74°</b>			26	0	0	0	0	56	0
WET BULB TEMP			27	0	0	0	0	57	0
RH PERCENT			28	0	0	0	0	58	0
SOURCE LAYOUT SKETCH			29	0	0	0	0	59	0
			30	0	0	0	0	60	0

AVERAGE OPACITY FOR HIGHEST PERIOD	0	NUMBER OF READINGS ABOVE WERE	0
RANGE OF OPACITY READINGS	MINIMUM 0	MAXIMUM 0	
OBSERVER'S NAME (PRINT) <b>RONALD STAPERT</b>			
OBSERVER'S SIGNATURE <i>Ronald Stapert</i>		DATE <b>4-18-05</b>	
ORGANIZATION <b>Air Test Professionals, Inc. (ATP)</b>			
CERTIFIED BY <b>Carl Koontz Associates</b>		DATE <b>4-24-05</b>	
Comments:			



- X = Emission Point
- = Observer's Position
- ☼ = Sun
- = Wind
- = Plume

MELT ROOF MONI




Visible Emissions Observations Form

RUN NUMBER

1

SOURCE NAME <b>NUCWR STEEL</b>			OBSERVATION DATE <b>4-18-05</b>			START TIME <b>12:47</b>		STOP TIME <b>2:15</b>	
ADDRESS			sec				sec		
			min	0	15	30	45	min	0
CITY <b>CRAWFORDVILLE</b>		STATE <b>IN</b>	ZIP	1	0	0	0	31	
PHONE		SOURCE ID NUMBER <b>EAF &amp; A00</b>		2	0	0	0	32	
PROCESS EQUIPMENT <b>BAG HOUSE</b>		OPERATING MODE		3	0	0	0	33	
<b>EAST BAG HOUSE</b>				4	0	0	0	34	
CONTROL EQUIPMENT <b>ROOF MON</b>		OPERATING MODE		5	0	0	0	35	
				6	0	0	0	36	
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>ROOF MOUNT VENT</b>			7	0	0	0	0	37	
			8	0	0	0	0	38	
			9	0	0	0	0	39	
			10	0	0	0	0	40	
HEIGHT ABOVE GROUND LEVEL START <b>150'</b> STOP <input checked="" type="checkbox"/>		HEIGHT RELATIVE TO OBSERVER START <b>110'</b> STOP <input checked="" type="checkbox"/>		11	0	0	0	41	
				12	0	0	0	42	
DISTANCE FROM OBSERVER START <b>800'</b> STOP <input checked="" type="checkbox"/>		DIRECTION FROM OBSERVER START <b>35°</b> STOP <input checked="" type="checkbox"/>		13	0	0	0	43	
				14	0	0	0	44	
DESCRIBE EMISSIONS START <b>CLEAR</b> STOP <input checked="" type="checkbox"/>			15	0	0	0	0	45	
			16	0	0	0	0	46	
EMISSION COLOR START <b>CLEAR</b> STOP <input checked="" type="checkbox"/>		PLUME TYPE: CONTINUOUS		17	0	0	0	47	
		FUGITIVE INTERMITTENT		18	0	0	0	48	
WATER DROPLETS PRESENT <input checked="" type="checkbox"/> NO YES		IF WATER DROPLET PLUME: ATTACHED <input checked="" type="checkbox"/> DETACHED		19	0	0	0	49	
				20	0	0	0	50	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <b>20' ALONG TOP</b> STOP <input checked="" type="checkbox"/>			21	0	0	0	0	51	
			22	0	0	0	0	52	
DESCRIBE BACKGROUND START <b>LIGHT BLUE</b> STOP <input checked="" type="checkbox"/>			23	0	0	0	0	53	
			24	0	0	0	0	54	
BACKGROUND COLOR START <b>BLUE</b> STOP <input checked="" type="checkbox"/>		SKY CONDITIONS START <b>MOSTLY SUNNY</b> STOP <input checked="" type="checkbox"/>		25	0	0	0	55	
				26	0	0	0	56	
WIND SPEED (MPH) <b>5-10 MPH</b>		WIND DIRECTION START <b>NW</b> STOP <input checked="" type="checkbox"/>		27	0	0	0	57	
				28	0	0	0	58	
AMBIENT TEMPERATURE (F) START <b>70°</b> STOP <b>72°</b>		WET BULB TEMP. RH PERCENT		29	0	0	0	59	
				30	0	0	0	60	



AVERAGE OPACITY FOR HIGHEST PERIOD		NUMBER OF READINGS ABOVE WERE	
RANGE OF OPACITY READINGS			
MINIMUM		MAXIMUM	
OBSERVER'S NAME (PRINT) <b>RONALD STAPERT</b>			
OBSERVER'S SIGNATURE <i>Ronald Stapert</i>		DATE <b>4-18-05</b>	
ORGANIZATION <b>AIR ANALYSIS</b> Air Test Professionals, Inc. (ATP)			
CERTIFIED BY <b>Carl Koontz Associates</b>		DATE <b>3-24-05</b>	
Comments:			

EAST BAG. H. ①


Visible Emissions Observations Form

RUN NUMBER 1

SOURCE NAME <b>NUCOR STEEL</b>			OBSERVATION DATE <b>4-18-05</b>				START TIME <b>12:47</b>		STOP TIME <b>2:15</b>	
ADDRESS			sec				sec			
CITY <b>CRAWFORDVILLE</b>	STATE <b>IN</b>	ZIP	min	0	15	30	45	min	0	
PHONE	SOURCE ID NUMBER <b>BAF &amp; A00</b>		1	0	0	0	0	31		
PROCESS EQUIPMENT <b>WEST BAGHOUSE ROOF MON</b>	OPERATING MODE		2	0	0	0	0	32		
CONTROL EQUIPMENT	OPERATING MODE		3	0	0	0	0	33		
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>ROOF MOUNT, VENT</b>			4	0	0	0	0	34		
HEIGHT ABOVE GROUND LEVEL START <b>150'</b> STOP	HEIGHT RELATIVE TO OBSERVER START <b>100'</b> STOP <input checked="" type="checkbox"/>		5	0	0	0	0	35		
DISTANCE FROM OBSERVER START <b>800'</b> STOP <input checked="" type="checkbox"/>	DIRECTION FROM OBSERVER START <b>30°</b> STOP <input checked="" type="checkbox"/>		6	0	0	0	0	36		
DESCRIBE EMISSIONS START <b>CLEAR</b> STOP <input checked="" type="checkbox"/>			7	0	0	0	0	37		
EMISSION COLOR START <b>CLEAR</b> STOP <input checked="" type="checkbox"/>	PLUME TYPE: CONTINUOUS FUGITIVE INTERMITTENT		8	0	0	0	0	38		
WATER DROPLETS PRESENT <input checked="" type="checkbox"/> NO YES	IF WATER DROPLET PLUME: ATTACHED <input checked="" type="checkbox"/> DETACHED		9	0	0	0	0	39		
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <b>20' Along Top</b> STOP <input checked="" type="checkbox"/>			10	0	0	0	0	40		
DESCRIBE BACKGROUND START <b>LIGHT BLUE</b> STOP <input checked="" type="checkbox"/>			11	0	0	0	0	41		
BACKGROUND COLOR START <b>BLUE</b> STOP <input checked="" type="checkbox"/>	SKY CONDITIONS START <b>MOSTLY SUNNY</b> STOP		12	0	0	0	0	42		
WIND SPEED (MPH) START <b>5-10</b> STOP <input checked="" type="checkbox"/>	WIND DIRECTION START <b>NW</b> STOP <input checked="" type="checkbox"/>		13	0	0	0	0	43		
AMBIENT TEMPERATURE (F) START <b>70</b> STOP <b>72°</b>	WET BULB TEMP	REL. HUMIDITY	14	0	0	0	0	44		
SOURCE LAYOUT SKETCH			15	0	0	0	0	45		

AVERAGE OPACITY FOR HIGHEST PERIOD	NUMBER OF READINGS ABOVE WERE
RANGE OF OPACITY READINGS	
MINIMUM	MAXIMUM
OBSERVER'S NAME (PRINT) <b>RONALD STAPERT</b>	
OBSERVER'S SIGNATURE <i>Ronald Stapert</i>	DATE <b>4-18-05</b>
ORGANIZATION <b>AIR ANALYSIS</b> <i>Air Test Professionals, Inc. (ATP)</i>	
CERTIFIED BY <b>Carl Koontz Associates</b>	DATE <b>3-24-05</b>

Comments:




West BagH (D)

Visible Emissions Observations Form

RUN NUMBER

1

SOURCE NAME <b>NUCOR STEEL</b>			OBSERVATION DATE <b>4-18-05</b>			START TIME <b>12:47</b>		STOP TIME <b>2:15</b>		
ADDRESS			sec				sec			
			min	0	15	30	45	min	0	15
CITY	STATE	ZIP	1	0	0	0	0	31		
<b>CRAW FORDSVILLE</b>	<b>IN</b>		2	0	0	0	0	32		
PHONE	SOURCE ID NUMBER		3	0	0	0	0	33		
	<b>EAR A00</b>		4	0	0	0	0	34		
PROCESS EQUIPMENT	OPERATING MODE		5	0	0	0	0	35		
<b>BAG HOUSE #2</b>			6	0	0	0	0	36		
CONTROL EQUIPMENT	OPERATING MODE		7	0	0	0	0	37		
			8	0	0	0	0	38		
DESCRIBE EMISSION POINT (Stack Exit Dimensions)			9	0	0	0	0	39		
<b>25' X 25' STACK</b>			10	0	0	0	0	40		
HEIGHT ABOVE GROUND LEVEL	HEIGHT RELATIVE TO OBSERVER		11	0	0	0	0	41		
START <b>170'</b> STOP	START <b>130'</b> STOP		12	0	0	0	0	42		
DISTANCE FROM OBSERVER	DIRECTION FROM OBSERVER		13	0	0	0	0	43		
START <b>1100</b> STOP <input checked="" type="checkbox"/>	START <b>60°</b> STOP <input checked="" type="checkbox"/>		14	0	0	0	0	44		
DESCRIBE EMISSIONS			15	0	0	0	0	45		
START <b>CLEAR</b> STOP <input checked="" type="checkbox"/>			16	0	0	0	0	46		
EMISSION COLOR	PLUME TYPE: <b>CONTINUOUS</b>		17	0	0	0	0	47		
START <b>CLEAR</b> STOP <input checked="" type="checkbox"/>	FUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>		18	0	0	0	0	48		
WATER DROPLETS PRESENT	IF WATER DROPLET PLUME:		19	0	0	0	0	49		
<b>NO</b> YES <input checked="" type="checkbox"/>	ATTACHED <input type="checkbox"/> <b>DETACHED</b> <input checked="" type="checkbox"/>		20	0	0	0	0	50		
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED			21	0	0	0	0	51		
START <b>20'</b> STOP <input checked="" type="checkbox"/>			22	0	0	0	0	52		
DESCRIBE BACKGROUND			23	0	0	0	0	53		
START <b>Light Blue</b> STOP <input checked="" type="checkbox"/>			24	0	0	0	0	54		
BACKGROUND COLOR	SKY CONDITIONS		25	0	0	0	0	55		
START <b>Light Blue</b> STOP <input checked="" type="checkbox"/>	START <b>Mostly Sunny</b> STOP		26	0	0	0	0	56		
WIND SPEED (MPH)	WIND DIRECTION		27	0	0	0	0	57		
START <b>5-10</b> STOP <input checked="" type="checkbox"/>	START <b>NW</b> STOP <input checked="" type="checkbox"/>		28	0	0	0	0	58		
AMBIENT TEMPERATURE (F)	WET BULB TEMP	RH PERCENT	29	0	0	0	0	59		
START <b>70°</b> STOP <b>72°</b>			30	0	0	0	0	60		



AVERAGE OPACITY FOR HIGHEST PERIOD	NUMBER OF READINGS ABOVE WERE
RANGE OF OPACITY READINGS	
MINIMUM	MAXIMUM
OBSERVER'S NAME (PRINT) <b>RONALD STAPERT</b>	
OBSERVER'S SIGNATURE <i>Ronald Stapert</i>	DATE <b>4-18-05</b>
ORGANIZATION <b>Air Test Professionals, Inc. (ATP)</b>	
CERTIFIED BY <b>Carl Koontz Associates</b>	DATE <b>3-24-05</b>
Comments:	


- X = Emission Point
- = Observer's Position
- ☀ = Sun
- = Wind
- = Plume

BAG HOUSE #2

Visible Emissions Observations Form

RUN NUMBER **2**

SOURCE NAME <b>NUCOR STEEL</b>			OBSERVATION DATE <b>4 18-05</b>				START TIME <b>2:15</b>		STOP TIME <b>2:45</b>	
ADDRESS			sec				sec			
			min	0	15	30	45	min	0	
CITY <b>CRAWFORDVILLE</b>			STATE <b>IN</b>	ZIP		1	0	15	30	
PHONE			SOURCE ID NUMBER <b>EAR 2 A0D</b>		2	0	15	30	45	
PROCESS EQUIPMENT <b>EAST #1 BAG HOUSE ROOM</b>			OPERATING MODE		3	0	15	30	45	
CONTROL EQUIPMENT			OPERATING MODE		4	0	15	30	45	
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>ROOF MOUNT VENT</b>					5	0	15	30	45	
HEIGHT ABOVE GROUND LEVEL START <b>150</b> STOP			HEIGHT RELATIVE TO OBSERVER START <b>110'</b> STOP <input checked="" type="checkbox"/>		6	0	15	30	45	
DISTANCE FROM OBSERVER START <b>800'</b> STOP			DIRECTION FROM OBSERVER START <b>35°</b> STOP <input checked="" type="checkbox"/>		7	0	15	30	45	
DESCRIBE EMISSIONS START <b>CLEAR</b> STOP <input checked="" type="checkbox"/>					8	0	15	30	45	
EMISSION COLOR START <b>CLEAR</b> STOP			PLUME TYPE: <b>CONTINUOUS</b>		9	0	15	30	45	
WATER DROPLETS PRESENT <input checked="" type="checkbox"/> NO YES			IF WATER DROPLET PLUME: ATTACHED <input checked="" type="checkbox"/> DETACHED		10	0	15	30	45	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <b>20' Along Top</b> STOP <input checked="" type="checkbox"/>					11	0	15	30	45	
DESCRIBE BACKGROUND START <b>LIGHT BLUE</b> STOP <input checked="" type="checkbox"/>					12	0	15	30	45	
BACKGROUND COLOR START <b>LIGHT BLUE</b> STOP			SKY CONDITIONS START <b>MOSTLY Sunny</b> STOP <input checked="" type="checkbox"/>		13	0	15	30	45	
WIND SPEED (MPH) START <b>5 to 10</b> STOP <input checked="" type="checkbox"/>			WIND DIRECTION START <b>NW</b> STOP <input checked="" type="checkbox"/>		14	0	15	30	45	
AMBIENT TEMPERATURE (F) START <b>76</b> STOP			WET BULB TEMP. RH PERCENT		15	0	15	30	45	




AVERAGE OPACITY FOR HIGHEST PERIOD <b>0</b>		NUMBER OF READINGS ABOVE WERE <b>0</b>	
RANGE OF OPACITY READINGS MINIMUM <b>0</b> MAXIMUM <b>0</b>			
OBSERVER'S NAME (PRINT) <b>RONALD STAPERT</b>			
OBSERVER'S SIGNATURE <i>Ronald Stapert</i>		DATE <b>4 18-05</b>	
ORGANIZATION <b>AIR ANALYSIS Air Test Professionals, Inc. (ATP)</b>			
CERTIFIED BY <b>Carl Koontz Associates</b>		DATE	
Comments:			

EAST BAG H<sup>01</sup> (2R)

Visible Emissions Observations Form

RUN NUMBER **1**

SOURCE NAME <b>NUCOR STEEL</b>			OBSERVATION DATE <b>4-18-05</b>			START TIME <b>2:15</b>		STOP TIME <b>2:45</b>				
ADDRESS			sec				sec					
			min	0	15	30	45	min	0	15	30	45
CITY <b>CRAWFORDSVILLE</b>	STATE <b>IN</b>	ZIP	1	0	0	0	0	31				
PHONE	SOURCE ID NUMBER <b>EAP &amp; AOD</b>		2	0	0	0	0	32				
PROCESS EQUIPMENT <b>WEST BAG House #1 ROOF MON.</b>	OPERATING MODE		3	0	0	0	0	33				
CONTROL EQUIPMENT	OPERATING MODE		4	0	0	0	0	34				
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>ROOF MOUNT VENT</b>			5	0	0	0	0	35				
HEIGHT ABOVE GROUND LEVEL START <b>150</b> STOP			6	0	0	0	0	36				
HEIGHT RELATIVE TO OBSERVER START <b>10'</b> STOP			7	0	0	0	0	37				
DISTANCE FROM OBSERVER START <b>800</b> STOP			8	0	0	0	0	38				
DIRECTION FROM OBSERVER START <b>30°</b> STOP			9	0	0	0	0	39				
DESCRIBE EMISSIONS START <b>CLEAR</b> ✓ STOP ✓			10	0	0	0	0	40				
EMISSION COLOR START <b>CLEAR</b> STOP ✓			11	0	0	0	0	41				
PLUME TYPE: <b>CONTINUOUS</b>			12	0	0	0	0	42				
FUGITIVE INTERMITTENT			13	0	0	0	0	43				
WATER DROPLETS PRESENT <b>(NO)</b> YES			14	0	0	0	0	44				
IF WATER DROPLET PLUME: ATTACHED <b>DETACHED</b>			15	0	0	0	0	45				
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <b>20' Along Top</b> STOP ✓			16	0	0	0	0	46				
DESCRIBE BACKGROUND START <b>Light Blue</b> STOP ✓			17	0	0	0	0	47				
BACKGROUND COLOR START <b>Light Blue</b> STOP ✓			18	0	0	0	0	48				
SKY CONDITIONS START <b>Mostly Sunny</b> STOP			19	0	0	0	0	49				
WIND SPEED (MPH) START <b>5-10</b> STOP ✓			20	0	0	0	0	50				
WIND DIRECTION START <b>NW</b> STOP ✓			21	0	0	0	0	51				
AMBIENT TEMPERATURE (F) START <b>76</b> STOP <b>77°</b>			22	0	0	0	0	52				
WET BULB TEMP			23	0	0	0	0	53				
RA PERCENT			24	0	0	0	0	54				



AVERAGE OPACITY FOR HIGHEST PERIOD <b>0</b>		NUMBER OF READINGS ABOVE WERE <b>0</b>	
RANGE OF OPACITY READINGS MINIMUM <b>0</b> MAXIMUM <b>0</b>			
OBSERVER'S NAME (PRINT) <b>RONALD STAPERT</b>			
OBSERVER'S SIGNATURE <i>Ronald Stapert</i>		DATE <b>4-18-05</b>	
ORGANIZATION <b>AIR ANALYSIS Air Test Professionals, Inc. (ATP)</b>			
CERTIFIED BY <b>Carl Koontz Associates</b>		DATE	
Comments:			

- X = Emission Point
- = Observer's Position
- ☀ = Sun
- = Wind
- = Plume


WEST BAG H. #1 (2) R.

Visible Emissions Observations Form

RUN NUMBER

211  
1A

SOURCE NAME <b>NUCOR STEEL</b>			OBSERVATION DATE <b>4 18-05</b>				START TIME <b>2:15</b>		STOP TIME <b>2:45</b>	
ADDRESS			sec		min		sec		min	
			0		15		0		15	
CITY <b>CRAWFORDSVILLE</b>			STATE <b>IN</b>		ZIP		1		31	
PHONE			SOURCE ID NUMBER <b>EAF &amp; AOD</b>		2		0		32	
PROCESS EQUIPMENT <b>BAG HOUSE #2</b>			OPERATING MODE		3		0		33	
CONTROL EQUIPMENT			OPERATING MODE		4		0		34	
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>25' X 25' STACK</b>			5		0		0		35	
HEIGHT ABOVE GROUND LEVEL START <b>170'</b> STOP <input checked="" type="checkbox"/>			HEIGHT RELATIVE TO OBSERVER START <b>130'</b> STOP <input checked="" type="checkbox"/>		6		0		36	
DISTANCE FROM OBSERVER START <b>1100'</b> STOP <input checked="" type="checkbox"/>			DIRECTION FROM OBSERVER START <b>60°</b> STOP <input checked="" type="checkbox"/>		7		0		37	
DESCRIBE EMISSIONS START <b>CLEAR</b> STOP <input checked="" type="checkbox"/>			EMISSION COLOR START <b>CLEAR</b> STOP <input checked="" type="checkbox"/>		8		0		38	
EMISSION COLOR START <b>CLEAR</b> STOP <input checked="" type="checkbox"/>			PLUME TYPE: <b>CONTINUOUS</b>		9		0		39	
WATER DROPLETS PRESENT <input checked="" type="checkbox"/> YES			IF WATER DROPLET PLUME: <b>DETACHED</b>		10		0		40	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <b>20'</b> STOP <input checked="" type="checkbox"/>			11		0		0		41	
DESCRIBE BACKGROUND START <b>LIGHT BLUE</b> STOP <input checked="" type="checkbox"/>			12		0		0		42	
BACKGROUND COLOR START <b>Light Blue</b> STOP <input checked="" type="checkbox"/>			SKY CONDITIONS START <b>Mostly Sunny</b> STOP <input checked="" type="checkbox"/>		13		0		43	
WIND SPEED (MPH) START <b>5-10</b> STOP <input checked="" type="checkbox"/>			WIND DIRECTION START <b>NW</b> STOP <input checked="" type="checkbox"/>		14		0		44	
AMBIENT TEMPERATURE (F) START <b>76</b> STOP <b>77</b>			WET BULB TEMP		15		0		45	
			RH PERCENT		16		0		46	



AVERAGE OPACITY FOR HIGHEST PERIOD

NUMBER OF READINGS ABOVE WERE

RANGE OF OPACITY READINGS  
MINIMUM \_\_\_\_\_ MAXIMUM \_\_\_\_\_

OBSERVER'S NAME (PRINT)  
**RONALD STAPERT**

OBSERVER'S SIGNATURE  
*Ronald Stapert*

DATE  
**4 18-05**

ORGANIZATION  
**Air Test Professionals, Inc. (ATP)**

CERTIFIED BY  
**Carl Koontz Associates**

DATE  
**3-27-05**


Comments:

BAG HOUSE #2 (21)

Visible Emissions Observations Form

RUN NUMBER

SOURCE NAME <b>NUCUR STEEL</b>			OBSERVATION DATE <b>4-18-05</b>				START TIME <b>2:45</b>		STOP TIME <b>3:15</b>			
ADDRESS			sec				sec					
			min	0	15	30	45	min	0	15	30	45
CITY <b>CARWINDSVILLE</b>		STATE <b>IN</b>	ZIP	1	0	0	0	31				
PHONE		SOURCE ID NUMBER <b>FA2A0D</b>		2	0	0	0	32				
PROCESS EQUIPMENT <b>WEST BAG HOUSE ROOF MON</b>		OPERATING MODE		3	0	0	0	33				
CONTROL EQUIPMENT		OPERATING MODE		4	0	0	0	34				
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>ROOF MOUNT. VENT</b>				5	0	0	0	35				
HEIGHT ABOVE GROUND LEVEL START <b>850'</b> STOP		HEIGHT RELATIVE TO OBSERVER START <b>130'</b> STOP		6	0	0	0	36				
DISTANCE FROM OBSERVER START <b>800'</b> STOP		DIRECTION FROM OBSERVER START <b>30°</b> STOP		7	0	0	0	37				
DESCRIBE EMISSIONS START <b>CLEAR</b> STOP				8	0	0	0	38				
EMISSION COLOR START <b>CLEAR</b> STOP		PLUME TYPE: <b>CONTINUOUS</b>		9	0	0	0	39				
WATER DROPLETS PRESENT <b>NO</b> YES		IF WATER DROPLET PLUME: <b>DETACHED</b>		10	0	0	0	40				
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <b>20' ALONG TOP</b> STOP				11	0	0	0	41				
DESCRIBE BACKGROUND START <b>20' ALONG TOP</b> STOP				12	0	0	0	42				
BACKGROUND COLOR START <b>LIGHT BLUE</b> STOP		SKY CONDITIONS START <b>MOSTLY SUNNY</b> STOP		13	0	0	0	43				
WIND SPEED (MPH) START <b>0-5</b> STOP		WIND DIRECTION START <b>NW</b> STOP		14	0	0	0	44				
AMBIENT TEMPERATURE (F) START <b>79</b> STOP		WET BULB TEMP. RH PERCENT		15	0	0	0	45				



AVERAGE OPACITY FOR HIGHEST PERIOD

NUMBER OF READINGS ABOVE WERE

RANGE OF OPACITY READINGS

MINIMUM MAXIMUM

OBSERVER'S NAME (PRINT)  
**RONALD STAPERT**

OBSERVER'S SIGNATURE  
*Ronald Stapert* DATE **3-18-04**

ORGANIZATION  
**AIR ANALYSIS**  
*Air Test Professionals, Inc. (ATP)*

CERTIFIED BY  
**Carl Koontz Associates** DATE **3-24-05**

Comments:


- X = Emission Point
- = Observer's Position
- ☀ = Sun
- = Wind
- = Plume

BAG HOUSE #1 W

Visible Emissions Observations Form

RUN NUMBER

SOURCE NAME <b>NUCOR STEEL</b>			OBSERVATION DATE <b>4 18 05</b>			START TIME <b>2 45</b>		STOP TIME <b>3 15</b>				
ADDRESS			sec				sec					
			min	0	15	30	45	min	0	15	30	45
CITY <b>CRAWFORDSVILLE</b>	STATE <b>IN</b>	ZIP	1	0	0	0	0	31				
PHONE	SOURCE ID NUMBER		2	0	0	0	0	32				
PROCESS EQUIPMENT <b>EAST BAGHOUSE I</b>		OPERATING MODE	3	0	0	0	0	33				
CONTROL EQUIPMENT		OPERATING MODE	4	0	0	0	0	34				
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>ROOF MOUNT VENT</b>			5	0	0	0	0	35				
HEIGHT ABOVE GROUND LEVEL START <b>150</b> STOP			6	0	0	0	0	36				
HEIGHT RELATIVE TO OBSERVER START <b>110</b> STOP			7	0	0	0	0	37				
DISTANCE FROM OBSERVER START <b>800</b> STOP			8	0	0	0	0	38				
DIRECTION FROM OBSERVER START <b>35°</b> STOP ✓			9	0	0	0	0	39				
DESCRIBE EMISSIONS <b>CLEAR</b>			10	0	0	0	0	40				
START <b>ROOF MOUNT VENT</b> STOP ✓			11	0	0	0	0	41				
EMISSION COLOR START <b>CLEAR</b> STOP ✓		PLUME TYPE: <u>CONTINUOUS</u>	12	0	0	0	0	42				
WATER DROPLETS PRESENT <u>NO</u> YES		FUGITIVE INTERMITTENT	13	0	0	0	0	43				
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <b>20' ALONG TOP</b> STOP ✓		IF WATER DROPLET PLUME: ATTACHED <u>DETACHED</u>	14	0	0	0	0	44				
DESCRIBE BACKGROUND START <b>LIGHT BLUE</b> STOP ✓			15	0	0	0	0	45				
BACKGROUND COLOR START <b>LIGHT BLUE</b> STOP		SKY CONDITIONS START <b>MOSTLY SUNNY</b> STOP	16	0	0	0	0	46				
WIND SPEED (MPH) START <b>5-10</b> STOP		WIND DIRECTION START <b>NW</b> STOP	17	0	0	0	0	47				
AMBIENT TEMPERATURE (F) START <b>79</b> STOP		WET BULB TEMP / RH PERCENT	18	0	0	0	0	48				



AVERAGE OPACITY FOR HIGHEST PERIOD	0	NUMBER OF READINGS ABOVE WERE	0
RANGE OF OPACITY READINGS	MINIMUM 0	MAXIMUM	0
OBSERVER'S NAME (PRINT) <b>RONALD STAPERT</b>			
OBSERVER'S SIGNATURE <i>Ronald Stapert</i>		DATE <b>4 18-05</b>	
ORGANIZATION <b>AIR ANALYSIS</b> <small>Air Test Professionals, Inc. (ATP)</small>			
CERTIFIED BY <b>Carl Koontz Associates</b>		DATE <b>3-24-05</b>	
Comments:			

BAG HOUSE I E




Visible Emissions Observations Form

RUN NUMBER

SOURCE NAME <b>NUCOR STEEL</b>			OBSERVATION DATE <b>4-18-05</b>			START TIME <b>245</b>		STOP TIME <b>315</b>	
ADDRESS			sec				sec		
CITY	STATE	ZIP	min	0	15	30	45	min	0
<b>CARWATONSVILLE</b>	<b>IN</b>		1	0	0	0	0	31	
PHONE	SOURCE ID NUMBER		2	0	0	0	0	32	
	<b>BAR E A00</b>		3	0	0	0	0	33	
PROCESS EQUIPMENT	OPERATING MODE		4	0	0	0	0	34	
<b>BAG HOUSE #2</b>			5	0	0	0	0	35	
CONTROL EQUIPMENT	OPERATING MODE		6	0	0	0	0	36	
			7	0	0	0	0	37	
DESCRIBE EMISSION POINT (Stack Exit Dimensions)			8	0	0	0	0	38	
<b>25' X 25' STACK</b>			9	0	0	0	0	39	
HEIGHT ABOVE GROUND LEVEL	HEIGHT RELATIVE TO OBSERVER		10	0	0	0	0	40	
START <b>120'</b> STOP <input checked="" type="checkbox"/>	START <b>130'</b> STOP <input checked="" type="checkbox"/>		11	0	0	0	0	41	
DISTANCE FROM OBSERVER	DIRECTION FROM OBSERVER		12	0	0	0	0	42	
START <b>110'</b> STOP <input checked="" type="checkbox"/>	START <b>300'</b> <b>30°</b> STOP <input checked="" type="checkbox"/>		13	0	0	0	0	43	
DESCRIBE EMISSIONS			14	0	0	0	0	44	
START <b>CLEAR</b> <input checked="" type="checkbox"/> STOP <input checked="" type="checkbox"/>			15	0	0	0	0	45	
EMISSION COLOR	PLUME TYPE: CONTINUOUS		16	0	0	0	0	46	
START <b>CLEAR</b> STOP <input checked="" type="checkbox"/>	FUGITIVE INTERMITTENT		17	0	0	0	0	47	
WATER DROPLETS PRESENT	IF WATER DROPLET PLUME:		18	0	0	0	0	48	
NO YES	ATTACHED DETACHED		19	0	0	0	0	49	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED			20	0	0	0	0	50	
START STOP			21	0	0	0	0	51	
DESCRIBE BACKGROUND			22	0	0	0	0	52	
START <b>LIGHT BLUE</b> STOP			23	0	0	0	0	53	
BACKGROUND COLOR	SKY CONDITIONS		24	0	0	0	0	54	
START <b>LIGHT BLUE</b> STOP <input checked="" type="checkbox"/>	START <b>MOSTLY SUNNY</b> STOP		25	0	0	0	0	55	
WIND SPEED (MPH)	WIND DIRECTION		26	0	0	0	0	56	
START <b>5-10</b> STOP <input checked="" type="checkbox"/>	START <b>NW</b> STOP		27	0	0	0	0	57	
AMBIENT TEMPERATURE (F)	WET BULB TEMP	REL PERCENT	28	0	0	0	0	58	
START <b>79</b> STOP <input checked="" type="checkbox"/>			29	0	0	0	0	59	
SOURCE LAYOUT SKETCH			30	0	0	0	0	60	

SOURCE LAYOUT SKETCH



AVERAGE OPACITY FOR HIGHEST PERIOD	0	NUMBER OF READINGS ABOVE 0 WERE 0
RANGE OF OPACITY READINGS		
MINIMUM	0	MAXIMUM 0
OBSERVER'S NAME (PRINT) <b>RONALD STAPERT</b>		
OBSERVER'S SIGNATURE <b>Ronald Stapert</b>	DATE <b>4-18-05</b>	
ORGANIZATION <b>Air Test Professionals, Inc. (ATP)</b>		
CERTIFIED BY <b>Carl Koontz Associates</b>	DATE <b>4-18-05</b>	


Comments:

- X = Emission Point
- = Observer's Position
- ☀ = Sun
- = Wind
- = Plume

BAG HOUSE #2

Visible Emissions Observations Form


RUN NUMBER

SOURCE NAME <b>NUCOR STEEL</b>			OBSERVATION DATE <b>4-18-05</b>			START TIME <b>3:45</b>		STOP TIME <b>4:45</b>				
ADDRESS			sec				sec					
CITY	STATE	ZIP	min	0	15	30	45	min	0	15	30	45
<b>CARFORDSVILLE</b>	<b>IN</b>		1	0	0	0	0	31	0	0	0	0
PHONE	SOURCE ID NUMBER <b>BAP &amp; AOD</b>		2	0	0	0	0	32	0	0	0	0
PROCESS EQUIPMENT <b>ROOF MOUNT BAG HOUSE WEST</b>	OPERATING MODE		3	0	0	0	0	33	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE		4	0	0	0	0	34	0	0	0	0
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>ROOF MOUNT VENT</b>			5	0	0	0	0	35	0	0	0	0
HEIGHT ABOVE GROUND LEVEL START <b>150'</b> STOP <b>L</b>	HEIGHT RELATIVE TO OBSERVER START <b>110'</b> STOP <b>✓</b>		6	0	0	0	0	36	0	0	0	0
DISTANCE FROM OBSERVER START <b>900'</b> STOP <b>✓</b>	DIRECTION FROM OBSERVER START <b>30'</b> STOP <b>✓</b>		7	0	0	0	0	37	0	0	0	0
DESCRIBE EMISSIONS START <b>CLEAR</b> STOP <b>✓</b>			8	0	0	0	0	38	0	0	0	0
EMISSION COLOR START <b>CLEAR</b> STOP <b>✓</b>	PLUME TYPE: <b>CONTINUOUS</b>		9	0	0	0	0	39	0	0	0	0
WATER DROPLETS PRESENT <b>NO</b> YES	IF WATER DROPLET PLUME: ATTACHED <b>DETACHED</b>		10	0	0	0	0	40	0	0	0	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <b>20' ALONG TOP</b> STOP <b>✓</b>			11	0	0	0	0	41	0	0	0	0
DESCRIBE BACKGROUND START <b>LIGHT BLUE</b> STOP <b>✓</b>			12	0	0	0	0	42	0	0	0	0
BACKGROUND COLOR START <b>LIGHT BLUE</b> STOP <b>✓</b>	SKY CONDITIONS START <b>MOSTLY Sunny</b> STOP <b>✓</b>		13	0	0	0	0	43	0	0	0	0
WIND SPEED (MPH) START <b>5-10</b> STOP <b>✓</b>	WIND DIRECTION START <b>NW</b> STOP <b>✓</b>		14	0	0	0	0	44	0	0	0	0
AMBIENT TEMPERATURE (F) START <b>80</b> STOP <b>✓</b>	WET BULB TEMP	REL. HUMIDITY	15	0	0	0	0	45	0	0	0	0
SOURCE LAYOUT SKETCH			16	0	0	0	0	46	0	0	0	0
			17	0	0	0	0	47	0	0	0	0
			18	0	0	0	0	48	0	0	0	0
			19	0	0	0	0	49	0	0	0	0
			20	0	0	0	0	50	0	0	0	0
			21	0	0	0	0	51	0	0	0	0
			22	0	0	0	0	52	0	0	0	0
			23	0	0	0	0	53	0	0	0	0
			24	0	0	0	0	54	0	0	0	0
			25	0	0	0	0	55	0	0	0	0
			26	0	0	0	0	56	0	0	0	0
			27	0	0	0	0	57	0	0	0	0
			28	0	0	0	0	58	0	0	0	0
			29	0	0	0	0	59	0	0	0	0
			30	0	0	0	0	60	0	0	0	0
SOURCE LAYOUT SKETCH			AVERAGE OPACITY FOR HIGHEST PERIOD <b>0</b>				NUMBER OF READINGS ABOVE <b>0</b> WERE <b>0</b>					
			RANGE OF OPACITY READINGS MINIMUM <b>0</b> MAXIMUM <b>0</b>									
			OBSERVER'S NAME (PRINT) <b>RONALD STAPERT</b>									
			OBSERVER'S SIGNATURE <i>Ronald Stapert</i>						DATE <b>4-18-05</b>			
			ORGANIZATION <b>AIR ANALYSIS</b> Air Test Professionals, Inc. (ATP)									
			CERTIFIED BY <b>Carl Koontz Associates</b>						DATE <b>3-24-05</b>			
			Comments:									
X = Emission Point • = Observer's Position ☼ = Sun = Wind → = Plume												

Visible Emissions Observations Form

RUN NUMBER

SOURCE NAME <b>NUCOR STEEL</b>			OBSERVATION DATE <b>4-18-05</b>				START TIME <b>345</b>		STOP TIME <b>445</b>			
ADDRESS			sec				sec					
			min	0	15	30	45	min	0	15	30	45
CITY	STATE	ZIP	1	0	0	0	0	31	0	0	0	0
<b>CRANFORDSVILLE</b>	<b>IN</b>		2	0	0	0	0	32	0	0	0	0
PHONE	SOURCE ID NUMBER		3	0	0	0	0	33	0	0	0	0
PROCESS EQUIPMENT <b>BAG HOUSE #2</b>		OPERATING MODE	4	0	0	0	0	34	0	0	0	0
CONTROL EQUIPMENT <b>25' X 25' STACK</b>		OPERATING MODE	5	0	0	0	0	35	0	0	0	0
			6	0	0	0	0	36	0	0	0	0
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>25' X 25' STACK</b>			7	0	0	0	0	37	0	0	0	0
			8	0	0	0	0	38	0	0	0	0
HEIGHT ABOVE GROUND LEVEL START <b>170'</b> STOP <input checked="" type="checkbox"/>	HEIGHT RELATIVE TO OBSERVER START <b>130'</b> STOP <input checked="" type="checkbox"/>		9	0	0	0	0	39	0	0	0	0
			10	0	0	0	0	40	0	0	0	0
DISTANCE FROM OBSERVER START <b>1100'</b> STOP <input checked="" type="checkbox"/>	DIRECTION FROM OBSERVER START <b>60°</b> STOP <input checked="" type="checkbox"/>		11	0	0	0	0	41	0	0	0	0
			12	0	0	0	0	42	0	0	0	0
DESCRIBE EMISSIONS START <b>CLEAR</b> STOP <input checked="" type="checkbox"/>			13	0	0	0	0	43	0	0	0	0
			14	0	0	0	0	44	0	0	0	0
EMISSION COLOR START <b>CLEAR</b> STOP		PLUME TYPE: <u>CONTINUOUS</u> FUGITIVE INTERMITTENT	15	0	0	0	0	45	0	0	0	0
			16	0	0	0	0	46	0	0	0	0
WATER DROPLETS PRESENT <input checked="" type="checkbox"/> YES		IF WATER DROPLET PLUME: ATTACHED <u>DETACHED</u>	17	0	0	0	0	47	0	0	0	0
			18	0	0	0	0	48	0	0	0	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <b>20'</b> STOP <input checked="" type="checkbox"/>			19	0	0	0	0	49	0	0	0	0
			20	0	0	0	0	50	0	0	0	0
DESCRIBE BACKGROUND START <b>LIGHT BLUE</b> STOP <input checked="" type="checkbox"/>			21	0	0	0	0	51	0	0	0	0
			22	0	0	0	0	52	0	0	0	0
BACKGROUND COLOR START <b>LIGHT BLUE</b> STOP <input checked="" type="checkbox"/>		SKY CONDITIONS START <b>MOSTLY SUNNY</b> STOP	23	0	0	0	0	53	0	0	0	0
			24	0	0	0	0	54	0	0	0	0
WIND SPEED (MPH) START <b>5-10</b> STOP <input checked="" type="checkbox"/>		WIND DIRECTION START <b>NW</b> STOP	25	0	0	0	0	55	0	0	0	0
			26	0	0	0	0	56	0	0	0	0
AMBIENT TEMPERATURE (F) START <b>80°</b> STOP <input checked="" type="checkbox"/>		WET BULB TEMP. RH. PERCENT	27	0	0	0	0	57	0	0	0	0
			28	0	0	0	0	58	0	0	0	0
			29	0	0	0	0	59	0	0	0	0
			30	0	0	0	0	60	0	0	0	0



AVERAGE OPACITY FOR HIGHEST PERIOD

NUMBER OF READINGS ABOVE WERE

RANGE OF OPACITY READINGS  
MINIMUM  MAXIMUM

OBSERVER'S NAME (PRINT)  
**RONALD STAPERT**

OBSERVER'S SIGNATURE  
*Ronald Stapert* DATE  
**4-18-05**

ORGANIZATION  
**Air Test Professionals, Inc. (ATP)**

CERTIFIED BY  
**Carl Koontz Associates** DATE  
**3-24-05**

Comments:


BAG HOUSE #2

Visible Emissions Observations Form

RUN NUMBER

SOURCE NAME <b>NUCOR STEEL</b>			OBSERVATION DATE <b>4-18-05</b>			START TIME <b>3:45</b>		STOP TIME <b>4:45</b>	
ADDRESS			sec				sec		
			min	0	15	30	45	min	0
CITY <b>CARWATONSVILLE</b>			STATE <b>IN</b>	ZIP				0	15
PHONE			SOURCE ID NUMBER					30	45
PROCESS EQUIPMENT <b>I FAST BAGHOUSE</b>			OPERATING MODE					31	0
CONTROL EQUIPMENT			OPERATING MODE					32	0
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>ROOF MOUNT VENT</b>								33	0
HEIGHT ABOVE GROUND LEVEL START <b>150'</b> STOP			HEIGHT RELATIVE TO OBSERVER START <b>110'</b> STOP					34	0
DISTANCE FROM OBSERVER START <b>800'</b> STOP			DIRECTION FROM OBSERVER START <b>35'</b> STOP					35	0
DESCRIBE EMISSIONS START <b>CLEAR</b> STOP								36	0
EMISSION COLOR START <b>CLEAR</b> STOP			PLUME TYPE: <b>CONTINUOUS</b>					37	0
WATER DROPLETS PRESENT <b>NO</b> YES			IF WATER DROPLET PLUME: <b>DETACHED</b>					38	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <b>20' ALONG TO STOP</b>								39	0
DESCRIBE BACKGROUND START <b>LIGHT BLUE</b> STOP								40	0
BACKGROUND COLOR START <b>LIGHT BLUE</b> STOP			SKY CONDITIONS START <b>MOSTLY SUNNY</b> STOP					41	0
WIND SPEED (MPH) START <b>5-10</b> STOP			WIND DIRECTION START STOP					42	0
AMBIENT TEMPERATURE (F) START <b>80'</b> STOP <b>80'</b>			WET BULB TEMP. RH PERCENT					43	0

AVERAGE OPACITY FOR HIGHEST PERIOD	NUMBER OF READINGS ABOVE WERE
0	0 WERE 0
RANGE OF OPACITY READINGS	
MINIMUM	MAXIMUM
0	0
OBSERVER'S NAME (PRINT) <b>RONALD STAPERT</b>	
OBSERVER'S SIGNATURE <i>Ronald Stapert</i>	DATE <b>4-18-05</b>
ORGANIZATION <b>MR ANALYSIS</b> <small>Air Test &amp; Diagnostic, Inc. (ATP)</small>	
CERTIFIED BY <b>Carl Koontz Associates</b>	DATE <b>3-24-05</b>
Comments:	



- X = Emission Point
- = Observer's Position
- ☀ = Sun
- = Wind
- = Plume

NUCOR STEEL

4-19-05

2:45 - 3:45

RUN 2

CITY CRAWFORDSVILLE	STATE IN	ZIP	1	0	0	0	0	31
PHONE	SOURCE ID NUMBER		2	0	0	0	0	32
PROCESS EQUIPMENT BAG HOUSE #2	OPERATING MODE		3	0	0	0	0	33
CONTROL EQUIPMENT	OPERATING MODE		4	0	0	0	0	34
DESCRIBE EMISSION POINT START 25' x 25' STOP STACK			5	0	0	0	0	35
HEIGHT ABOVE GROUND LEVEL START 170' STOP ✓	HEIGHT RELATIVE TO OBSERVER START 130' STOP ✓		6	0	0	0	0	36
DISTANCE FROM OBSERVER START 1000 STOP ✓	DIRECTION FROM OBSERVER START 60° STOP ✓		7	0	0	0	0	37
DESCRIBE EMISSIONS START CLEAR STOP ✓			8	0	0	0	0	38
EMISSION COLOR START CLEAR STOP	PLUME TYPE: CONTINUOUS <input checked="" type="checkbox"/>		9	0	0	0	0	39
WATER DROPLETS PRESENT <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES	IF WATER DROPLET PLUME: ATTACHED <input type="checkbox"/> DETACHED <input checked="" type="checkbox"/>		10	0	0	0	0	40
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START 20' STOP ✓			11	0	0	0	0	41
DESCRIBE BACKGROUND START BLUR STOP ✓			12	0	0	0	0	42
BACKGROUND COLOR START BLUR STOP ✓	SKY CONDITIONS START MOSTLY SUNNY STOP		13	0	0	0	0	43
WIND SPEED START 10-15 STOP 10-15	WIND DIRECTION START SE STOP		14	0	0	0	0	44
AMBIENT TEMPERATURE START 80° STOP 80°	WET BULB TEMP.	R.H. PERCENT	15	0	0	0	0	45
SOURCE LAYOUT SKETCH			16	0	0	0	0	46
			17	0	0	0	0	47
			18	0	0	0	0	48
AVERAGE OPACITY FOR HIGHEST PERIOD 0			19	0	0	0	0	49
RANGE OF OPACITY READINGS MINIMUM 0 MAXIMUM 0			20	0	0	0	0	50
OBSERVER'S NAME (PRINT) RONALD STAPERT			21	0	0	0	0	51
OBSERVER'S SIGNATURE Ronald Stapert			22	0	0	0	0	52
DATE 4 11 01			23	0	0	0	0	53
ORGANIZATION AIR TEST PROFESSIONAL INC			24	0	0	0	0	54
CERTIFIED BY CARL KOONTZ			25	0	0	0	0	55
DATE 3-24-0			26	0	0	0	0	56
Comments:			27	0	0	0	0	57
			28	0	0	0	0	58
			29	0	0	0	0	59
			30	0	0	0	0	60

BAG H #2

NUCOR STEEL


4-19-05

245-345

1000 L

CITY CRAWFORDSVILLE		STATE IN	ZIP
PHONE		SOURCE ID NUMBER	
PROCESS EQUIPMENT WEST BACK HOUSE ROOF MON.		OPERATING MODE	
CONTROL EQUIPMENT		OPERATING MODE	
DESCRIBE EMISSION POINT ROOF MOUNT VENT			
START		STOP	
HEIGHT ABOVE GROUND LEVEL START 150' STOP ✓		HEIGHT RELATIVE TO OBSERVER START 110' STOP ✓	
DISTANCE FROM OBSERVER START 800' STOP ✓		DIRECTION FROM OBSERVER START 30° STOP ✓	
DESCRIBE EMISSIONS START CLEAR ✓ STOP ✓			
EMISSION COLOR START CLEAR STOP ✓		PLUME TYPE: CONTINUOUS <input checked="" type="checkbox"/> FUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>	
WATER DROPLETS PRESENT <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES <input type="checkbox"/>		IF WATER DROPLET PLUME: ATTACHED <input type="checkbox"/> DETACHED <input checked="" type="checkbox"/>	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START 20' ALONG TOP STOP ✓			
DESCRIBE BACKGROUND START BLUE STOP ✓			
BACKGROUND COLOR START BLUE STOP ✓		SKY CONDITIONS START MOSTLY SUNNY STOP	
WIND SPEED START 10-15 STOP ✓		WIND DIRECTION START S2 STOP ✓	
AMBIENT TEMPERATURE START 80 STOP ✓		WET BULB TEMP. R.H. PERCENT	

1	0	0	0	0	31
2	0	0	0	0	32
3	0	0	0	0	33
4	0	0	0	0	34
5	0	0	0	0	35
6	0	0	0	0	36
7	0	0	0	0	37
8	0	0	0	0	38
9	0	0	0	0	39
10	0	0	0	0	40
11	0	0	0	0	41
12	0	0	0	0	42
13	0	0	0	0	43
14	0	0	0	0	44
15	0	0	0	0	45
16	0	0	0	0	46
17	0	0	0	0	47
18	0	0	0	0	48
19	0	0	0	0	49
20	0	0	0	0	50
21	0	0	0	0	51
22	0	0	0	0	52
23	0	0	0	0	53
24	0	0	0	0	54
25	0	0	0	0	55
25	0	0	0	0	56
27	0	0	0	0	57
28	0	0	0	0	58
29	0	0	0	0	59
30	0	0	0	0	60



AVERAGE OPACITY FOR HIGHEST PERIOD	0	NUMBER OF READINGS ABOVE 0 WERE	0
RANGE OF OPACITY READINGS			
MINIMUM	0	MAXIMUM	0
OBSERVER'S NAME (PRINT) RONALD STAPERT			
OBSERVER'S SIGNATURE Ronald Stapert			DATE 4 19 05
ORGANIZATION AIR ANALYSIS INC			
CERTIFIED BY CARL KOONTZ			DATE 3 24 00
Comments:			


BAG H. #1  
WEST

NUCOR STEEL

4-19-05 2:45 3:15

CITY CRAWFORDSVILLE		STATE IN	ZIP
PHONE		SOURCE ID NUMBER	
PROCESS EQUIPMENT BAG H #1 EAST BAG HOUSE ROOF MOUNT		OPERATING MODE	
CONTROL EQUIPMENT		OPERATING MODE	
DESCRIBE EMISSION POINT ROOF MOUNT VENT.			
START		STOP	
HEIGHT ABOVE GROUND LEVEL START 150' STOP ✓		HEIGHT RELATIVE TO OBSERVER START 116' STOP ✓	
DISTANCE FROM OBSERVER START 500 STOP ✓		DIRECTION FROM OBSERVER START 35° STOP ✓	
DESCRIBE EMISSIONS			
START CLEAR		STOP ✓	
EMISSION COLOR START CLEAR STOP ✓		PLUME TYPE: CONTINUOUS <input checked="" type="checkbox"/> FUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>	
WATER DROPLETS PRESENT <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES <input type="checkbox"/>		IF WATER DROPLET PLUME: ATTACHED <input type="checkbox"/> DETACHED <input checked="" type="checkbox"/>	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED			
START 20' ALONG TOP		STOP	
DESCRIBE BACKGROUND			
START BLUE ✓		STOP ✓	
BACKGROUND COLOR START BLUE STOP ✓		SKY CONDITIONS MOSTLY SUNNY START MOSTLY SUNNY STOP ✓	
WIND SPEED START 10-15 STOP ✓		WIND DIRECTION START S12 STOP ✓	
AMBIENT TEMPERATURE START 80° STOP 80°		WET BULB TEMP. — R.H. PERCENT —	

1	0	0	0	0	31
2	0	0	0	0	32
3	0	0	0	0	33
4	0	0	0	0	34
5	0	0	0	0	35
6	0	0	0	0	36
7	0	0	0	0	37
8	0	0	0	0	38
9	0	0	0	0	39
10	0	0	0	0	40
11	0	0	0	0	41
12	0	0	0	0	42
13	0	0	0	0	43
14	0	0	0	0	44
15	0	0	0	0	45
16	0	0	0	0	46
17	0	0	0	0	47
18	0	0	0	0	48
19	0	0	0	0	49
20	0	0	0	0	50
21	0	0	0	0	51
22	0	0	0	0	52
23	0	0	0	0	53
24	0	0	0	0	54
25	0	0	0	0	55
26	0	0	0	0	56
27	0	0	0	0	57
28	0	0	0	0	58
29	0	0	0	0	59
30	0	0	0	0	60



AVERAGE OPACITY FOR HIGHEST PERIOD 0

NUMBER OF READINGS ABOVE 0 WERE 0

RANGE OF OPACITY READINGS

MINIMUM 0 MAXIMUM 0

OBSERVER'S NAME (PRINT) RONALD STAPERT

OBSERVER'S SIGNATURE Ronald Stapert DATE 4-19-05

ORGANIZATION AIR ANALYSIS INC

CERTIFIED BY CARL KOONER DATE 3-24-05

Comments:

BAG H. #1  
EAST


NUCOR STEEL

(1,45 - 215) RUN 2  
 1245-1.15  
 70920 - 1400

4-19-05

TY CRAWFORDSVILLE	STATE IN	ZIP
PHONE	SOURCE ID NUMBER BAR E A00	
PROCESS EQUIPMENT EAST BAGHOUSE ROOF MON	OPERATING MODE	
CONTROL EQUIPMENT	OPERATING MODE	
DESCRIBE EMISSION POINT ROOF MOUNT UNIT		
START	STOP	
HEIGHT ABOVE GROUND LEVEL START 150' STOP	HEIGHT RELATIVE TO OBSERVER START 110' STOP	
DISTANCE FROM OBSERVER START 800' STOP	DIRECTION FROM OBSERVER START 35° STOP	
DESCRIBE EMISSIONS START CLEAR STOP		
EMISSION COLOR START CLEAR STOP	PLUME TYPE: CONTINUOUS <input type="checkbox"/> FUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>	
WATER DROPLETS PRESENT <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES	IF WATER DROPLET PLUME: ATTACHED <input type="checkbox"/> DETACHED <input checked="" type="checkbox"/>	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START 20' ALONG ZOP STOP		
DESCRIBE BACKGROUND START BLUE STOP		
BACKGROUND COLOR START BLUE STOP	SKY CONDITIONS MOSTLY SUNNY START STOP	
WIND SPEED START 10-15 STOP	WIND DIRECTION START SE STOP	
AMBIENT TEMPERATURE START 80° STOP 80°	WET BULB TEMP.	R.H. PERCENT

1	0	0	0	0	31	0	0	0	0
2	0	0	0	0	32	0	0	0	0
3	0	0	0	0	33	0	0	0	0
4	0	0	0	0	34	0	0	0	0
5	0	0	0	0	35	0	0	0	0
6	0	0	0	0	36	0	0	0	0
7	0	0	0	0	37	0	0	0	0
8	0	0	0	0	38	0	0	0	0
9	0	0	0	0	39	0	0	0	0
10	0	0	0	0	40	0	0	0	0
11	0	0	0	0	41	0	0	0	0
12	0	0	0	0	42	0	0	0	0
13	0	0	0	0	43	0	0	0	0
14	0	0	0	0	44	0	0	0	0
15	0	0	0	0	45	0	0	0	0
16	0	0	0	0	46	0	0	0	0
17	0	0	0	0	47	0	0	0	0
18	0	0	0	0	48	0	0	0	0
19	0	0	0	0	49	0	0	0	0
20	0	0	0	0	50	0	0	0	0
21	0	0	0	0	51	0	0	0	0
22	0	0	0	0	52	0	0	0	0
23	0	0	0	0	53	0	0	0	0
24	0	0	0	0	54	0	0	0	0
25	0	0	0	0	55	0	0	0	0
26	0	0	0	0	56	0	0	0	0
27	0	0	0	0	57	0	0	0	0
28	0	0	0	0	58	0	0	0	0
29	0	0	0	0	59	0	0	0	0
30	0	0	0	0	60	0	0	0	0



AVERAGE OPACITY FOR HIGHEST PERIOD 0

NUMBER OF READINGS ABOVE 0 WERE 0

RANGE OF OPACITY READINGS  
 MINIMUM 0 MAXIMUM 0

OBSERVER'S NAME (PRINT)  
RONALD STAPERT

OBSERVER'S SIGNATURE  
Ronald Stapert

DATE  
4/19/05

ORGANIZATION  
AIR ANALYSIS INC

CERTIFIED BY  
CARL KOONTZ

DATE  
3-24-0

Comments:

1  
EAST BAG 17



NUCOR STEEL


4-19-05

1.45 2.15  
12:45 1.15  
10:20 - 11:20

CITY CRAWFORDSVILLE		STATE IN	ZIP	1	0	0	0	0	31	0	0	0	0
PHONE		SOURCE ID NUMBER EAP E AOD		2	0	0	0	0	32	0	0	0	0
PROCESS EQUIPMENT WEST BAG HOUSE ROOM MON		OPERATING MODE		3	0	0	0	0	33	0	0	0	0
CONTROL EQUIPMENT		OPERATING MODE		4	0	0	0	0	34	0	0	0	0
DESCRIBE EMISSION POINT ROOF MOUNT VENT				5	0	0	0	0	35	0	0	0	0
START		STOP		6	0	0	0	0	36	0	0	0	0
HEIGHT ABOVE GROUND LEVEL START 150' STOP ✓		HEIGHT RELATIVE TO OBSERVER START 110' STOP ✓		7	0	0	0	0	37	0	0	0	0
DISTANCE FROM OBSERVER START 800' STOP ✓		DIRECTION FROM OBSERVER START 30 STOP ✓		8	0	0	0	0	38	0	0	0	0
DESCRIBE EMISSIONS START CLEAR STOP ✓				9	0	0	0	0	39	0	0	0	0
EMISSION COLOR START CLEAR STOP ✓		PLUME TYPE: CONTINUOUS <input checked="" type="checkbox"/> FUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>		10	0	0	0	0	40	0	0	0	0
WATER DROPLETS PRESENT NO <input checked="" type="checkbox"/> YES <input type="checkbox"/>		IF WATER DROPLET PLUME: ATTACHED <input type="checkbox"/> DETACHED <input checked="" type="checkbox"/>		11	0	0	0	0	41	0	0	0	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START 20' ALONG TOP STOP ✓				12	0	0	0	0	42	0	0	0	0
DESCRIBE BACKGROUND START BLUE STOP ✓				13	0	0	0	0	43	0	0	0	0
BACKGROUND COLOR START BLUE STOP ✓		SKY CONDITIONS START MOSTLY SUNNY STOP		14	0	0	0	0	44	0	0	0	0
WIND SPEED START 10-15 STOP ✓		WIND DIRECTION START SE STOP ✓		15	0	0	0	0	45	0	0	0	0
AMBIENT TEMPERATURE START 80° STOP 80°		WET BULB TEMP. R.H. PERCENT		16	0	0	0	0	46	0	0	0	0

17	0	0	0	0	47	0	0	0	0
18	0	0	0	0	48	0	0	0	0
19	0	0	0	0	49	0	0	0	0
20	0	0	0	0	50	0	0	0	0
21	0	0	0	0	51	0	0	0	0
22	0	0	0	0	52	0	0	0	0
23	0	0	0	0	53	0	0	0	0
24	0	0	0	0	54	0	0	0	0
25	0	0	0	0	55	0	0	0	0
26	0	0	0	0	56	0	0	0	0
27	0	0	0	0	57	0	0	0	0
28	0	0	0	0	58	0	0	0	0
29	0	0	0	0	59	0	0	0	0
30	0	0	0	0	60	0	0	0	0

SOURCE LAYOUT SKETCH



AVERAGE OPACITY FOR HIGHEST PERIOD 0

NUMBER OF READINGS ABOVE 0 WERE 0

RANGE OF OPACITY READINGS  
MINIMUM 0 MAXIMUM 0

OBSERVER'S NAME (PRINT)  
RONALD STAPART

OBSERVER'S SIGNATURE  
Ronald Stapart

DATE  
4/19/05

ORGANIZATION  
AIR ANALYSIS

CERTIFIED BY  
CARL KOONTZ

DATE  
3-24-06

Comments:

WEST  
BAG H, -1


# NUCOR STEEL

4-19-05

(1,75-2,15) RUN 2  
 12:45-1:15  
~~10:00-11:00~~

CITY CRAWFORDSVILLE		STATE IN	ZIP
PHONE		SOURCE ID NUMBER EAF & A00	
PROCESS EQUIPMENT BAG HOUSE #2		OPERATING MODE	
CONTROL EQUIPMENT		OPERATING MODE	
DESCRIBE EMISSION POINT START 25' X 25' STACK STOP			
HEIGHT ABOVE GROUND LEVEL START 170' STOP		HEIGHT RELATIVE TO OBSERVER START 130' STOP	
DISTANCE FROM OBSERVER START 160' STOP		DIRECTION FROM OBSERVER START 60' STOP	
DESCRIBE EMISSIONS START CLEAR STOP			
EMISSION COLOR START CLEAR STOP		PLUME TYPE: <input checked="" type="checkbox"/> CONTINUOUS <input type="checkbox"/> FUGITIVE <input type="checkbox"/> INTERMITTENT	
WATER DROPLETS PRESENT <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES		IF WATER DROPLET PLUME: <input type="checkbox"/> ATTACHED <input checked="" type="checkbox"/> DETACHED	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START 20' STOP			
DESCRIBE BACKGROUND START BLUE STOP			
BACKGROUND COLOR START BLUE STOP <input checked="" type="checkbox"/>		SKY CONDITIONS START MOSTLY SUNNY STOP	
WIND SPEED START 10-15 STOP <input checked="" type="checkbox"/>		WIND DIRECTION START SE STOP <input checked="" type="checkbox"/>	
AMBIENT TEMPERATURE START 80° STOP <input checked="" type="checkbox"/>		WET BULB TEMP. R.H. PERCENT	

1	0	0	0	0	31	0	0	0	0
2	0	0	0	0	32	0	0	0	0
3	0	0	0	0	33	0	0	0	0
4	0	0	0	0	34	0	0	0	0
5	0	0	0	0	35	0	0	0	0
6	0	0	0	0	36	0	0	0	0
7	0	0	0	0	37	0	0	0	0
8	0	0	0	0	38	0	0	0	0
9	0	0	0	0	39	0	0	0	0
10	0	0	0	0	40	0	0	0	0
11	0	0	0	0	41	0	0	0	0
12	0	0	0	0	42	0	0	0	0
13	0	0	0	0	43	0	0	0	0
14	0	0	0	0	44	0	0	0	0
15	0	0	0	0	45	0	0	0	0
16	0	0	0	0	46	0	0	0	0
17	0	0	0	0	47	0	0	0	0
18	0	0	0	0	48	0	0	0	0
19	0	0	0	0	49	0	0	0	0
20	0	0	0	0	50	0	0	0	0
21	0	0	0	0	51	0	0	0	0
22	0	0	0	0	52	0	0	0	0
23	0	0	0	0	53	0	0	0	0
24	0	0	0	0	54	0	0	0	0
25	0	0	0	0	55	0	0	0	0
26	0	0	0	0	56	0	0	0	0
27	0	0	0	0	57	0	0	0	0
28	0	0	0	0	58	0	0	0	0
29	0	0	0	0	59	0	0	0	0
30	0	0	0	0	60	0	0	0	0



AVERAGE OPACITY FOR HIGHEST PERIOD	0	NUMBER OF READINGS ABOVE 0 WERE	0
RANGE OF OPACITY READINGS			
MINIMUM	0	MAXIMUM	0
OBSERVER'S NAME (PRINT)		RONALD STAPERT	
OBSERVER'S SIGNATURE		Ronald Stapert	
ORGANIZATION		AIR TEST PROFESSIONAL INC	
CERTIFIED BY		CARL KOONTZ	
DATE		4-19-05	
Comments:			

BAG-House #2


# NUCOR STEEL

9,20-950 KUN 2

4-19-05 (8:20) - (9:50)

CITY CRAWFORDSVILLE		STATE IN	ZIP 47
PHONE		SOURCE ID NUMBER	
PROCESS EQUIPMENT BAG House #2		OPERATING MODE BAF & AOD	
CONTROL EQUIPMENT		OPERATING MODE	
DESCRIBE EMISSION POINT START 25' X 25' STOP STACK			
HEIGHT ABOVE GROUND LEVEL START 170' STOP		HEIGHT RELATIVE TO OBSERVER START 130' STOP ✓	
DISTANCE FROM OBSERVER START 100 STOP ✓		DIRECTION FROM OBSERVER START 55° STOP ✓	
DESCRIBE EMISSIONS START CLEAR STOP ✓			
EMISSION COLOR START CLEAR STOP ✓		PLUME TYPE: CONTINUOUS <input checked="" type="checkbox"/> FUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>	
WATER DROPLETS PRESENT NO <input checked="" type="checkbox"/> YES <input type="checkbox"/>		IF WATER DROPLET PLUME: ATTACHED <input type="checkbox"/> DETACHED <input checked="" type="checkbox"/>	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START 20" UP STOP ✓			
DESCRIBE BACKGROUND START BLUE STOP ✓			
BACKGROUND COLOR START BLUE STOP ✓		SKY CONDITIONS START MOSTLY Sunny STOP -	
WIND SPEED START 5 STOP ✓		WIND DIRECTION START S STOP ✓	
AMBIENT TEMPERATURE START 65° STOP 68		WET BULB TEMP. R.H. PERCENT	

1	0	0	0	0	31	0	0	0	0
2	0	0	0	0	32	0	0	0	0
3	0	0	0	0	33	0	0	0	0
4	0	0	0	0	34	0	0	0	0
5	0	0	0	0	35	0	0	0	0
6	0	0	0	0	36	0	0	0	0
7	0	0	0	0	37	0	0	0	0
8	0	0	0	0	38	0	0	0	0
9	0	0	0	0	39	0	0	0	0
10	0	0	0	0	40	0	0	0	0
11	0	0	0	0	41	0	0	0	0
12	0	0	0	0	42	0	0	0	0
13	0	0	0	0	43	0	0	0	0
14	0	0	0	0	44	0	0	0	0
15	0	0	0	0	45	0	0	0	0
16	0	0	0	0	46	0	0	0	0
17	0	0	0	0	47	0	0	0	0
18	0	0	0	0	48	0	0	0	0
19	0	0	0	0	49	0	0	0	0
20	0	0	0	0	50	0	0	0	0
21	0	0	0	0	51	0	0	0	0
22	0	0	0	0	52	0	0	0	0
23	0	0	0	0	53	0	0	0	0
24	0	0	0	0	54	0	0	0	0
25	0	0	0	0	55	0	0	0	0
26	0	0	0	0	56	0	0	0	0
27	0	0	0	0	57	0	0	0	0
28	0	0	0	0	58	0	0	0	0
29	0	0	0	0	59	0	0	0	0
30	0	0	0	0	60	0	0	0	0



AVERAGE OPACITY FOR HIGHEST PERIOD 0 NUMBER OF READINGS ABOVE 0 WERE 0

RANGE OF OPACITY READINGS MINIMUM 0 MAXIMUM 0

OBSERVER'S NAME (PRINT) RONALD STAPERT

OBSERVER'S SIGNATURE Ronald Stapert DATE 4 119 1

ORGANIZATION AIR TEST PROFESSIONALS INC

CERTIFIED BY CAR KROON TL DATE 3-24-0

Comments:

BAG H #2

NUCOR STEEL

4-19-05


9120-9150

820 850

Run 2

CITY CRAWFORDSULLY		STATE IN	ZIP
PHONE		SOURCE ID NUMBER BAF & AGD	
PROCESS EQUIPMENT		OPERATING MODE	
CONTROL EQUIPMENT BAF HOUSE MON.		OPERATING MODE	
DESCRIBE EMISSION POINT Roof Mount Vent.			
START		STOP	
HEIGHT ABOVE GROUND LEVEL START 150' STOP ✓		HEIGHT RELATIVE TO OBSERVER START 110' STOP ✓	
DISTANCE FROM OBSERVER START 800 STOP ✓		DIRECTION FROM OBSERVER START 35 STOP ✓	
DESCRIBE EMISSIONS START CLEAR STOP ✓			
EMISSION COLOR START CLEAR STOP ✓		PLUME TYPE: CONTINUOUS <input checked="" type="checkbox"/> FUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>	
WATER DROPLETS PRESENT NO <input checked="" type="checkbox"/> YES <input type="checkbox"/>		IF WATER DROPLET PLUME: ATTACHED <input type="checkbox"/> DETACHED <input checked="" type="checkbox"/>	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START 20' Above Top of Vent STOP ✓			
DESCRIBE BACKGROUND START BLUE STOP ✓			
BACKGROUND COLOR START BLUE STOP ✓		SKY CONDITIONS START Mostly Sunny STOP	
WIND SPEED START 5 STOP ✓		WIND DIRECTION START S STOP	
AMBIENT TEMPERATURE START 65° STOP 68°		WET BULB TEMP. R.H. PERCENT	

1	0	0	0	0	31	0	0	0	0
2	0	0	0	0	32	0	0	0	0
3	0	0	0	0	33	0	0	0	0
4	0	0	0	0	34	0	0	0	0
5	0	0	0	0	35	0	0	0	0
6	0	0	0	0	36	0	0	0	0
7	0	0	0	0	37	0	0	0	0
8	0	0	0	0	38	0	0	0	0
9	0	0	0	0	39	0	0	0	0
10	0	0	0	0	40	0	0	0	0
11	0	0	0	0	41	0	0	0	0
12	0	0	0	0	42	0	0	0	0
13	0	0	0	0	43	0	0	0	0
14	0	0	0	0	44	0	0	0	0
15	0	0	0	0	45	0	0	0	0
16	0	0	0	0	46	0	0	0	0
17	0	0	0	0	47	0	0	0	0
18	0	0	0	0	48	0	0	0	0
19	0	0	0	0	49	0	0	0	0
20	0	0	0	0	50	0	0	0	0
21	0	0	0	0	51	0	0	0	0
22	0	0	0	0	52	0	0	0	0
23	0	0	0	0	53	0	0	0	0
24	0	0	0	0	54	0	0	0	0
25	0	0	0	0	55	0	0	0	0
26	0	0	0	0	56	0	0	0	0
27	0	0	0	0	57	0	0	0	0
28	0	0	0	0	58	0	0	0	0
29	0	0	0	0	59	0	0	0	0
30	0	0	0	0	60	0	0	0	0



AVERAGE OPACITY FOR HIGHEST PERIOD	0	NUMBER OF READINGS ABOVE 0 WERE	0
RANGE OF OPACITY READINGS	MINIMUM 0	MAXIMUM 0	
OBSERVER'S NAME (PRINT) RONALD STAPERT		DATE 4 11 05	
OBSERVER'S SIGNATURE Ronald Stapert		DATE 4 11 05	
ORGANIZATION AIR ANALYSIS			
CERTIFIED BY CARL KOONTZ		DATE 3-24-05	
Comments:			

BAG H. #1 EAST

NUCOR STEEL

4-19-05


Run 2

8:20-8:50  
9:20-9:50

CITY CRAWFORDSVILLE		STATE IN	ZIP
PHONE		SOURCE ID NUMBER EAF & A.O.	
PROCESS EQUIPMENT WEST BAG HOUSE ROOF MOUNT		OPERATING MODE	
CONTROL EQUIPMENT		OPERATING MODE	
DESCRIBE EMISSION POINT START ROOF MOUNT VENT STOP			
HEIGHT ABOVE GROUND LEVEL START 150 STOP ✓		HEIGHT RELATIVE TO OBSERVER START 110' STOP ✓	
DISTANCE FROM OBSERVER START 800 STOP ✓		DIRECTION FROM OBSERVER START 30° STOP ✓	
DESCRIBE EMISSIONS START CLEAR STOP ✓			
EMISSION COLOR START CLEAR STOP		PLUME TYPE: CONTINUOUS <input type="checkbox"/> FUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>	
WATER DROPLETS PRESENT <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES		IF WATER DROPLET PLUME: ATTACHED <input type="checkbox"/> DETACHED <input checked="" type="checkbox"/>	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START 20' ALONG TO STOP			
DESCRIBE BACKGROUND START BLUR STOP ✓			
BACKGROUND COLOR START BLUR STOP ✓		SKY CONDITIONS START MOSTLY SUNNY STOP	
WIND SPEED START 5 STOP ✓		WIND DIRECTION START S STOP ✓	
AMBIENT TEMPERATURE START 65° STOP 68°		WET BULB TEMP. R.H. PERCENT	

1	0	0	0	0	31	0	0	0	0
2	0	0	0	0	32	0	0	0	0
3	0	0	0	0	33	0	0	0	0
4	0	0	0	0	34	0	0	0	0
5	0	0	0	0	35	0	0	0	0
6	0	0	0	0	36	0	0	0	0
7	0	0	0	0	37	0	0	0	0
8	0	0	0	0	38	0	0	0	0
9	0	0	0	0	39	0	0	0	0
10	0	0	0	0	40	0	0	0	0
11	0	0	0	0	41	0	0	0	0
12	0	0	0	0	42	0	0	0	0
13	0	0	0	0	43	0	0	0	0
14	0	0	0	0	44	0	0	0	0
15	0	0	0	0	45	0	0	0	0
16	0	0	0	0	46	0	0	0	0
17	0	0	0	0	47	0	0	0	0
18	0	0	0	0	48	0	0	0	0
19	0	0	0	0	49	0	0	0	0
20	0	0	0	0	50	0	0	0	0
21	0	0	0	0	51	0	0	0	0
22	0	0	0	0	52	0	0	0	0
23	0	0	0	0	53	0	0	0	0
24	0	0	0	0	54	0	0	0	0
25	0	0	0	0	55	0	0	0	0
26	0	0	0	0	56	0	0	0	0
27	0	0	0	0	57	0	0	0	0
28	0	0	0	0	58	0	0	0	0
29	0	0	0	0	59	0	0	0	0
30	0	0	0	0	60	0	0	0	0

SOURCE LAYOUT SKETCH



AVERAGE OPACITY FOR HIGHEST PERIOD 0 NUMBER OF READINGS ABOVE WERE 0

RANGE OF OPACITY READINGS MINIMUM 0 MAXIMUM 0

OBSERVER'S NAME (PRINT) RONALD STAPERT

OBSERVER'S SIGNATURE Ronald Stapert DATE 4-19-05

ORGANIZATION AIR ANALYSIS

CERTIFIED BY CARL KOONTZ DATE 3-24-05

Comments:

BAG #1  
WEST

# NUCOR STEEL


Run 2

4-19-05

8:20 - 9:20

CITY CRAWFORDSVILLE		STATE IN	ZIP
PHONE		SOURCE ID NUMBER BAR # <u>ADD</u>	
PROCESS EQUIPMENT STEEL MELT ROOF MOUNT		OPERATING MODE	
CONTROL EQUIPMENT		OPERATING MODE	
DESCRIBE EMISSION POINT: <u>ROOF MOUNT VENT.</u>			
START		STOP	
HEIGHT ABOVE GROUND LEVEL START <u>160'</u> STOP <input checked="" type="checkbox"/>		HEIGHT RELATIVE TO OBSERVER START <u>120'</u> STOP <input checked="" type="checkbox"/>	
DISTANCE FROM OBSERVER START <u>500'</u> STOP <input checked="" type="checkbox"/>		DIRECTION FROM OBSERVER START <u>30</u> STOP <input checked="" type="checkbox"/>	
DESCRIBE EMISSIONS START <u>CLEAR</u> STOP <input checked="" type="checkbox"/>			
EMISSION COLOR START <u>CLEAR</u> STOP <input checked="" type="checkbox"/>		PLUME TYPE: <input checked="" type="checkbox"/> CONTINUOUS <input type="checkbox"/> FUGITIVE <input type="checkbox"/> INTERMITTENT	
WATER DROPLETS PRESENT <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES		IF WATER DROPLET PLUME: <input type="checkbox"/> ATTACHED <input checked="" type="checkbox"/> DETACHED	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <u>20' ALONG TOP</u> STOP <input checked="" type="checkbox"/>			
DESCRIBE BACKGROUND START <u>BLUE</u> STOP <input checked="" type="checkbox"/>			
BACKGROUND COLOR START <u>BLUE</u> STOP <input checked="" type="checkbox"/>		SKY CONDITIONS START <u>MOSTLY SUNNY</u> STOP <input checked="" type="checkbox"/>	
WIND SPEED START <u>5</u> STOP <input checked="" type="checkbox"/>		WIND DIRECTION START <u>S</u> STOP <input checked="" type="checkbox"/>	
AMBIENT TEMPERATURE START <u>65°</u> STOP <u>68°</u>		WET BULB TEMP. _____ R.H. PERCENT _____	

1	0	0	0	0	31	0	0	0	0
2	0	0	0	0	32	0	0	0	0
3	0	0	0	0	33	0	0	0	0
4	0	0	0	0	34	0	0	0	0
5	0	0	0	0	35	0	0	0	0
6	0	0	0	0	36	0	0	0	0
7	0	0	0	0	37	0	0	0	0
8	0	0	0	0	38	0	0	0	0
9	0	0	0	0	39	0	0	0	0
10	0	0	0	0	40	0	0	0	0
11	0	0	0	0	41	0	0	0	0
12	0	0	0	0	42	0	0	0	0
13	0	0	0	0	43	0	0	0	0
14	0	0	0	0	44	0	0	0	0
15	0	0	0	0	45	0	0	0	0
16	0	0	0	0	46	0	0	0	0
17	0	0	0	0	47	0	0	0	0
18	0	0	0	0	48	0	0	0	0
19	0	0	0	0	49	0	0	0	0
20	0	0	0	0	50	0	0	0	0
21	0	0	0	0	51	0	0	0	0
22	0	0	0	0	52	0	0	0	0
23	0	0	0	0	53	0	0	0	0
24	0	0	0	0	54	0	0	0	0
25	0	0	0	0	55	0	0	0	0
26	0	0	0	0	56	0	0	0	0
27	0	0	0	0	57	0	0	0	0
28	0	0	0	0	58	0	0	0	0
29	0	0	0	0	59	0	0	0	0
30	0	0	0	0	60	0	0	0	0



AVERAGE OPACITY FOR HIGHEST PERIOD: 0

NUMBER OF READINGS ABOVE 0 WERE 0

RANGE OF OPACITY READINGS: MINIMUM 0 MAXIMUM 0

OBSERVER'S NAME (PRINT): RONALD STAPERT

OBSERVER'S SIGNATURE: Ronald Stapert DATE: 4/19/05

ORGANIZATION: AIR TEST PROFESSIONALS INC.

CERTIFIED BY: CARL KOONZ DATE: 3-24-05


Comments:

MELT HOUSE

Visible Emissions Observations Form

RUN NUMBER 3

SOURCE NAME			OBSERVATION DATE				START TIME		STOP TIME			
NICON STEEL			04-22-05				0900		1000			
ADDRESS			sec				min		sec			
			min				0		0			
CITY			STATE		ZIP		1		31		0	
CRAWFORDSVILLE			IN				2		32		0	
PHONE			SOURCE ID NUMBER				3		33		0	
4							4		34		0	
PROCESS EQUIPMENT			OPERATING MODE				5		35		0	
EAF'S & ACD (WEST)							6		36		0	
CONTROL EQUIPMENT			OPERATING MODE				7		37		0	
PPPP BASTHOUSE #1 (WEST)							8		38		0	
9							9		39		0	
DESCRIBE EMISSION POINT			START				10		40		0	
Roof Monitor EXIT			Roof Monitor EXIT				11		41		0	
HEIGHT ABOVE GROUND LEVEL			HEIGHT RELATIVE TO OBSERVER				12		42		0	
START 120' STOP 120'			START 120' STOP 120'				13		43		0	
DISTANCE FROM OBSERVER			DIRECTION FROM OBSERVER				14		44		0	
START 550' STOP 550'			START W STOP W				15		45		0	
16							16		46		0	
DESCRIBE EMISSIONS			START				17		47		0	
START N/A STOP N/A			STOP N/A				18		48		0	
EMISSION COLOR			PLUME TYPE: CONTINUOUS <input type="checkbox"/>				19		49		0	
START N/A STOP N/A			EFFLUVIAL <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>				20		50		0	
WATER DROPLETS PRESENT			IF WATER DROPLET PLUME:				21		51		0	
NO <input checked="" type="checkbox"/> YES <input type="checkbox"/>			ATTACHED <input type="checkbox"/> DETACHED <input type="checkbox"/>				22		52		0	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED			START				23		53		0	
Roof Monitor EXIT			Roof Monitor EXIT				24		54		0	
DESCRIBE BACKGROUND			START				25		55		0	
START SKY STOP SKY			STOP SKY				26		56		0	
BACKGROUND COLOR			SKY CONDITIONS				27		57		0	
START Gray STOP Gray			START Overcast STOP Overcast				28		58		0	
WIND SPEED			WIND DIRECTION				29		59		0	
START 0-5 STOP 0-5			START N STOP N				30		60		0	
AMBIENT TEMPERATURE			WET BULB TEMP.		R.H. PERCENT							
START 55° STOP 57°												



AVERAGE OPACITY FOR HIGHEST PERIOD 0

NUMBER OF READINGS ABOVE WERE 0

RANGE OF OPACITY READINGS MINIMUM 0 MAXIMUM 0

OBSERVER'S NAME (PRINT) Carlos Brown


OBSERVER'S SIGNATURE [Signature] DATE 04 122 05

ORGANIZATION ATP

CERTIFIED BY CARL KOONTZ DATE

Comments:

SOURCE NAME NUCOR STEEL			OBSERVATION DATE 04-22-05				START TIME 10:30		STOP TIME 12:00	
ADDRESS			1sec				1sec			
CITY CRAWFORDSVILLE			min	0	15	30	45	min	0	
STATE			1	0	0	0	0	31	0	
ZIP			2	0	0	0	0	32	0	
PHONE			3	0	0	0	0	33	0	
SOURCE ID NUMBER			4	0	0	0	0	34	0	
PROCESS EQUIPMENT EAP'S / AND			5	0	0	0	0	35	0	
OPERATING MODE			6	0	0	0	0	36	0	
CONTROL EQUIPMENT (WEST) OFF. BAKHOUSE #1			7	0	0	0	0	37	0	
OPERATING MODE NORMAL			8	0	0	0	0	38	0	
DESCRIBE EMISSION POINT			9	0	0	0	0	39	0	
START ROOF MONITOR STOP ROOF MONITOR			10	0	0	0	0	40	0	
HEIGHT ABOVE GROUND LEVEL		HEIGHT RELATIVE TO OBSERVER		11	0	0	0	0	41	
START 120' STOP 120'		START 120' STOP 120'		12	0	0	0	0	42	
DISTANCE FROM OBSERVER		DIRECTION FROM OBSERVER		13	0	0	0	0	43	
START 550' STOP 550'		START W STOP W		14	0	0	0	0	44	
DESCRIBE EMISSIONS			15	0	0	0	0	0	45	
START N/A STOP N/A			16	0	0	0	0	0	46	
EMISSION COLOR		PLUME TYPE CONTINUOUS <input type="checkbox"/>		17	0	0	0	0	47	
START N/A STOP N/A		FUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>		18	0	0	0	0	48	
WATER DROPLETS PRESENT		IF WATER DROPLET PLUME:		19	0	0	0	0	49	
NO <input checked="" type="checkbox"/> YES <input type="checkbox"/>		ATTACHED <input type="checkbox"/> DETACHED <input type="checkbox"/>		20	0	0	0	0	50	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED			21	0	0	0	0	0	51	
START R.M. EXIT STOP R.M. EXIT			22	0	0	0	0	0	52	
DESCRIBE BACKGROUND			23	0	0	0	0	0	53	
START SKY STOP SKY			24	0	0	0	0	0	54	
BACKGROUND COLOR		SKY CONDITIONS		25	0	0	0	0	55	
START GRAY STOP GRAY		START OVERCAST STOP OVERCAST		26	0	0	0	0	56	
WIND SPEED		WIND DIRECTION		27	0	0	0	0	57	
START 0-5 STOP 0-5		START N STOP N		28	0	0	0	0	58	
AMBIENT TEMPERATURE		WET BULB TEMP.		29	0	0	0	0	59	
START STOP		R.H. PERCENT		30	0	0	0	0	60	



AVERAGE OPACITY FOR HIGHEST PERIOD: 0

NUMBER OF READINGS ABOVE WERE: 0

RANGE OF OPACITY READINGS: MINIMUM 0 MAXIMUM 0

OBSERVER'S NAME (PRINT): CARL BROWN

OBSERVER'S SIGNATURE: [Signature]

DATE: 04-22-05

ORGANIZATION: AFP

CERTIFIED BY: CARL KOONTZ

DATE: [Blank]

Comments: [Blank]


- X = Emission Point
- = Observer's Position
- ◇ = Sun
- = Wind
- ≡ = Plume



Visible Emissions Observations Form

RUN NUMBER 3

SOURCE NAME <i>Nucor Steel</i>			OBSERVATION DATE <i>04-22-05</i>				START TIME <i>1230</i>		STOP TIME <i>1300</i>					
ADDRESS			sec					sec						
CITY <i>Crawfordsville</i>			min	0	15	30	45	min	0	15	30	45		
STATE <i>IN</i>			ZIP			1			31					
PHONE			SOURCE ID NUMBER			2			32					
PROCESS EQUIPMENT <i>RAF'S + AOD</i>			OPERATING MODE			3			33					
CONTROL EQUIPMENT <i>PPFF BARNHOUSE #1</i>			(WEST) OPERATING MODE			4			34					
DESCRIBE EMISSION POINT			START <i>R. MONITOR</i>			STOP <i>R. MONITOR</i>			5			35		
HEIGHT ABOVE GROUND LEVEL			START <i>120'</i>			STOP <i>120'</i>			6			36		
HEIGHT RELATIVE TO OBSERVER			START <i>120'</i>			STOP <i>120'</i>			7			37		
DISTANCE FROM OBSERVER			START <i>550'</i>			STOP <i>550'</i>			8			38		
DIRECTION FROM OBSERVER			START <i>W</i>			STOP <i>W</i>			9			39		
DESCRIBE EMISSIONS			START <i>N/A</i>			STOP <i>N/A</i>			10			40		
EMISSION COLOR			START <i>N/A</i>			STOP <i>N/A</i>			11			41		
PLUME TYPE: CONTINUOUS <input type="checkbox"/>			EUGITIVE <input type="checkbox"/>			INTERMITTENT <input type="checkbox"/>			12			42		
WATER DROPLETS PRESENT			NO <input checked="" type="checkbox"/>			YES <input type="checkbox"/>			13			43		
IF WATER DROPLET PLUME:			ATTACHED <input type="checkbox"/>			DETACHED <input type="checkbox"/>			14			44		
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED			START <i>X OF MONITOR EXIT</i>			STOP <i>R.M. EXIT</i>			15			45		
DESCRIBE BACKGROUND			START <i>SKY</i>			STOP <i>SKY</i>			16			46		
BACKGROUND COLOR			START <i>GRAY</i>			STOP <i>GRAY</i>			17			47		
WIND SPEED			START <i>0-5</i>			STOP <i>0-5</i>			18			48		
WIND DIRECTION			START <i>N</i>			STOP <i>N</i>			19			49		
AMBIENT TEMPERATURE			START			STOP			20			50		
WET BULB TEMP.			R.H. PERCENT			21			51					
22			52											
23			53											
24			54											
25			55											
25			56											
27			57											
28			58											
29			59											
30			60											



AVERAGE OPACITY FOR HIGHEST PERIOD

RANGE OF OPACITY READINGS

MINIMUM | MAXIMUM

OBSERVER'S NAME (PRINT)  
*CARLOS BRENN*

OBSERVER'S SIGNATURE  
*[Signature]*

DATE  
*04/22/05*

ORGANIZATION  
*ATP*

CERTIFIED BY  
*Carl Koontz*

DATE

Comments:

- X = Emission Point
- = Observer's Position
- ◇ = Sun
- = Wind
- ≡ = Plume

Visible Emissions Observations Form

RUN NUMBER

3

SOURCE NAME NUCOR STEEL

OBSERVATION DATE 04-22-05

START TIME 0900

STOP TIME 1000

ADDRESS

CITY Camden

STATE IN

ZIP

PHONE

SOURCE ID NUMBER

PROCESS EQUIPMENT EAF & Acid

OPERATING MODE

CONTROL EQUIPMENT PPPF BREATHOUSE #1 (EAST)

OPERATING MODE NORMAL

DESCRIBE EMISSION POINT  
START ROOF MONITORS STOP ROOF MONITORS

HEIGHT ABOVE GROUND LEVEL  
START 120' STOP 120'

HEIGHT RELATIVE TO OBSERVER  
START 120' STOP 120'

DISTANCE FROM OBSERVER  
START 500' STOP 500'

DIRECTION FROM OBSERVER  
START W STOP W

DESCRIBE EMISSIONS  
START N/A STOP N/A

EMISSION COLOR  
START N/A STOP N/A

PLUME TYPE: CONTINUOUS   
FUGITIVE  INTERMITTENT

WATER DROPLETS PRESENT  
NO  YES

IF WATER DROPLET PLUME:  
ATTACHED  DETACHED

POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED  
START MONITOR EXITS STOP MONITOR EXITS

DESCRIBE BACKGROUND  
START SKY STOP SKY

BACKGROUND COLOR  
START GRAY STOP GRAY


SKY CONDITIONS  
START OVERCAST STOP OVERCAST

WIND SPEED  
START 0-5 STOP 0-5

WIND DIRECTION  
START N STOP N

AMBIENT TEMPERATURE  
START 55° STOP 57°

WET BULB TEMP. R.H. PERCENT



AVERAGE OPACITY FOR HIGHEST PERIOD 0 NUMBER OF READINGS ABOVE 0 WERE 0

RANGE OF OPACITY READINGS MINIMUM 0 MAXIMUM 0

OBSERVER'S NAME (PRINT) CARLOS BROWN

OBSERVER'S SIGNATURE [Signature] DATE 04/22/05

ORGANIZATION ATP

CERTIFIED BY CARL KOONTZ DATE

Comments:

- X = Emission Point
- = Observer's Position
- ◇ = Sun
- = Wind
- ≡ = Plume

Visible Emissions Observations Form

RUN NUMBER

3

SOURCE NAME <i>NUGER STEEL</i>			OBSERVATION DATE <i>04-22-05</i>				START TIME <i>1030</i>		STOP TIME <i>1200</i>					
ADDRESS			sec	0	15	30	45	sec	0	15	30	45		
CITY <i>CRAWFORDSVILLE</i>			min	1	2	3	4	min	31	32	33	34		
STATE <i>IN</i>														
ZIP														
PHONE			SOURCE ID NUMBER											
PROCESS EQUIPMENT <i>EAF's &amp; Add</i>			OPERATING MODE											
CONTROL EQUIPMENT <i>(EAST) PPF BARRIERS # 1</i>			OPERATING MODE											
DESCRIBE EMISSION POINT														
START <i>ROOF MONITORS</i>			STOP <i>ROOF MONITORS</i>											
HEIGHT ABOVE GROUND LEVEL			HEIGHT RELATIVE TO OBSERVER											
START <i>120'</i>			STOP <i>120'</i>			START <i>120'</i>			STOP <i>120'</i>					
DISTANCE FROM OBSERVER			DIRECTION FROM OBSERVER											
START <i>570'</i>			STOP <i>570'</i>			START <i>W</i>			STOP <i>W</i>					
DESCRIBE EMISSIONS														
START <i>N/A</i>			STOP <i>N/A</i>											
EMISSION COLOR			PLUME TYPE: CONTINUOUS <input type="checkbox"/>											
START <i>N/A</i>			STOP <i>N/A</i>			FUGITIVE <input type="checkbox"/>			INTERMITTENT <input type="checkbox"/>					
WATER DROPLETS PRESENT			IF WATER DROPLET PLUME:											
NO <input checked="" type="checkbox"/> YES <input type="checkbox"/>			ATTACHED <input type="checkbox"/>			DETACHED <input type="checkbox"/>								
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED														
START <i>RAIL EXIT</i>			STOP <i>RAIL EXIT</i>											
DESCRIBE BACKGROUND														
START <i>SKY</i>			STOP <i>SKY</i>											
BACKGROUND COLOR			SKY CONDITIONS											
START <i>GRAY</i>			STOP <i>GRAY</i>			START <i>OVERCAST</i>			STOP <i>OVERCAST</i>					
WIND SPEED			WIND DIRECTION											
START <i>0-5</i>			STOP <i>0-5</i>			START <i>N</i>			STOP <i>N</i>					
AMBIENT TEMPERATURE			WET BULB TEMP.		R.H. PERCENT									
START <i>58'</i>			STOP											
SOURCE LAYOUT SKETCH			AVERAGE OPACITY FOR HIGHEST PERIOD <input type="checkbox"/>											
			NUMBER OF READINGS ABOVE WERE <input type="checkbox"/>											
			RANGE OF OPACITY READINGS: MINIMUM <input type="checkbox"/> MAXIMUM <input type="checkbox"/>											
			OBSERVER'S NAME (PRINT) <i>CARLOS BROWN</i>											
			OBSERVER'S SIGNATURE <i>[Signature]</i>							DATE <i>04 22 05</i>				
			ORGANIZATION <i>ATP</i>											
			CERTIFIED BY <i>CARL KOONTZ</i>							DATE				
			Comments:											


- X = Emission Point
- = Observer's Position
- ◇ = Sun
- = Wind
- ≡ = Plume

Visible Emissions Observations Form

RUN NUMBER

3

SOURCE NAME <i>Nucor Steel</i>			OBSERVATION DATE <i>04-22-05</i>				START TIME <i>1230</i>		STOP TIME <i>1300</i>	
ADDRESS			sec				sec			
			min	0	15	30	45	min	0	
CITY <i>Covington</i> STATE <i>IN</i> ZIP			1	0	0	0	0	31		
PHONE			2	0	0	0	0	32		
SOURCE ID NUMBER			3	0	0	0	0	33		
PROCESS EQUIPMENT			4	0	0	0	0	34		
<i>EAF'S &amp; ADD</i>			5	0	0	0	0	35		
OPERATING MODE			6	0	0	0	0	36		
CONTROL EQUIPMENT			7	0	0	0	0	37		
<i>PPFF BATHHOUSE #1 (EAST)</i>			8	0	0	0	0	38		
OPERATING MODE			9	0	0	0	0	39		
DESCRIBE EMISSION POINT			10	0	0	0	0	40		
<i>START ROOF MONITOR STOP ROOF MONITOR</i>			11	0	0	0	0	41		
HEIGHT ABOVE GROUND LEVEL		HEIGHT RELATIVE TO OBSERVER	12	0	0	0	0	42		
<i>START 120' STOP 120'</i>		<i>START 120' STOP 120'</i>	13	0	0	0	0	43		
DISTANCE FROM OBSERVER		DIRECTION FROM OBSERVER	14	0	0	0	0	44		
<i>START 500' STOP 500'</i>		<i>START W STOP W</i>	15	0	0	0	0	45		
DESCRIBE EMISSIONS			16	0	0	0	0	46		
<i>START N/A STOP N/A</i>			17	0	0	0	0	47		
EMISSION COLOR		PLUME TYPE: CONTINUOUS <input type="checkbox"/>	18	0	0	0	0	48		
<i>START N/A STOP N/A</i>		FUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>	19	0	0	0	0	49		
WATER DROPLETS PRESENT		IF WATER DROPLET PLUME:	20	0	0	0	0	50		
<i>NO <input checked="" type="checkbox"/> YES <input type="checkbox"/></i>		ATTACHED <input type="checkbox"/> DETACHED <input type="checkbox"/>	21	0	0	0	0	51		
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED			22	0	0	0	0	52		
<i>START R.M. EXIT STOP R.M. EXIT</i>			23	0	0	0	0	53		
DESCRIBE BACKGROUND			24	0	0	0	0	54		
<i>START SKY STOP SKY</i>			25	0	0	0	0	55		
BACKGROUND COLOR		SKY CONDITIONS	25	0	0	0	0	56		
<i>START GRAY STOP GRAY</i>		<i>START OVERCAST STOP OVERCAST</i>	27	0	0	0	0	57		
WIND SPEED		WIND DIRECTION	28	0	0	0	0	58		
<i>START 0-5 STOP 0-5</i>		<i>START N STOP N</i>	29	0	0	0	0	59		
AMBIENT TEMPERATURE		WET BULB TEMP. R.H. PERCENT	30	0	0	0	0	60		
<i>START STOP</i>										



AVERAGE OPACITY FOR HIGHEST PERIOD

RANGE OF OPACITY READINGS: MINIMUM  MAXIMUM

NUMBER OF READINGS ABOVE WERE

OBSERVER'S NAME (PRINT) *ARLOS BROWN*

OBSERVER'S SIGNATURE *[Signature]* DATE *04 22 05*

ORGANIZATION *ATP*

CERTIFIED BY *Carl Koontz* DATE

Comments:

ΔAir Analysis, Inc.

NUCOR

Project Number: 302

**APPENDIX VIII**

**SUBMITTED PROTOCOL**

---

**COMPLIANCE TEST PROTOCOL**  
**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT**

Date Prepared: March 7, 2005 Proposed Test Date: To Be Determined

Plant Address and Location: 4537 South Nucor Street, Crawfordsville, IN


1. Source Information  
 AFS: Id Number: 107-16823-00038  
 Company: Nucor Steel  
 Mail Address: 4537 South Nucor Street  
 City: Crawfordsville, Indiana Zip: 47933  
 Co. Contact: Mark Washer Phone: (765) 364-1323

Check program if applicable:  
 FESOP: \_\_\_\_\_  
 Title V: X  
 SSOA: \_\_\_\_\_

AGENCY USE ONLY		Date Rec'd: _____
Inspector: _____	Reviewer: _____	Date Appr: _____

2. Tester Information  
 Name: Air Test Professionals, Inc.  
 Address: 1201 N. Graham Ave.  
 Contact: Carlos M. Brown Phone: 317-345-1723  
 Pre-Test Inspection Complete? Yes

3. Process Information  
 Unit to Test: Melting EAF Baghouse #1  
 Max. Rated Capacity: 502 tons/hour  
 Proposed Operating Speed: Normal (MAX)  
 Pollution Control Equipment: 2 Pos. Pressure Baghouses  
 Process Description: EAF's & AOD & other units  
mel scrap steel for processing



4. Test Information

Methods 1-4	# Runs	Time/Run
Method 5	<u>3</u>	<u>120 MIN</u>
Method 6		
Method 29	<u>3</u>	<u>120 min</u>
Method 25A	<u>3</u>	<u>60 min</u>
Other Testing:		

5. Sampling Strategy  
 a. Describe any deviations from the standard test method.  
 Name: \_\_\_\_\_  
 b. Describe method used to determine quantity of raw materials  
 Plant personnel will keep record production  
 \_\_\_\_\_  
 \_\_\_\_\_

6. Sample Site Location  
 Does sample port location meet 40 CFR 60, Appx A, Method 1  
 Section 1.2 requirements: Yes/No: \_\_\_\_\_ If No, Explain  
Sampling performed in representative number of compartments in the  
positive pressure baghouse  
 \_\_\_\_\_  
 \_\_\_\_\_

Number of sample points for MS: N/A  
 Diameter at sample site: \_\_\_\_\_ Stack height: \_\_\_\_\_  
 Approx. stack gas flow (ACFM): \_\_\_\_\_  
 Approx. gas temp. (degF): \_\_\_\_\_  
 Approx. gas moisture (%): \_\_\_\_\_  
 Reason for test: \_\_\_\_\_  
 State Agreed Order: Yes/No: \_\_\_\_\_ Operating permit: Yes/No: Yes  
 Construction Permit: Yes/No: \_\_\_\_\_ Compliance w 326 \_\_\_\_\_  
 NSPS 40 CFR 60 Subpart: \_\_\_\_\_ Other \_\_\_\_\_  
 Title V: \_\_\_\_\_  
 Other (i.e. EPA, CD, state, 114) \_\_\_\_\_

326 IAC 3-2.1 requires this completed form and fee to be submitted 35 days prior to proposed test date to  
 (FEE NOT APPLICABLE IF FESOP OR TITLE V)

Questions may be directed to 317-232-4338, FAX: 317-233-6805

Compliance Data Section  
 Office of Air Management  
 Indiana Department of Environmental Management  
 109 North Senate  
 PO BOX 6015  
 Indianapolis, IN 46206-4015

ΔAir Analysis, Inc.

NUCOR

Project Number: 302

**APPENDIX IX**

**PRODUCTION DATA**

---





Nucor Steel - Crawfordsville, IN  
 Baghouse #1 & #2 Stack Test Production Data  
 April 18, 2008

Nucor Steel - Crawfordsville, IN  
 Baghouse #1 & #2 Stack Test Production Data  
 April 19, 2008

Nucor Steel - Crawfordsville, IN  
 Baghouse #1 & #2 Stack Test Production Data  
 April 22, 2008

PM/PM10 Run 1: 12:50 pm - 7:36 pm

PM/PM10 Run 2: 8:30 am - 4:08 pm

PM/PM10 Run 3: 8:33 am - 2:14 pm

Hour	Start	End	Net Loads	Total	Run	Total	Average
Number			Tons	Minutes	Run	Run	Weight
125928	12:52 PM	1:18 PM	131.7	46.0	38.0	106.0	
152928	2:17 PM	2:42 PM	114.5	88.0	59.0	143.0	
182927	3:37 PM	3:57 PM	130.2	57.0	41.0	113.0	
192927	4:14 PM	4:51 PM	131.9	37.0	11.0	113.0	
192928	4:51 PM	5:28 PM	131.2	46.0	41.0	134.2	
192927	5:28 PM	5:57 PM	130.2	46.0	46.0	134.2	
192928	5:57 PM	7:36 PM	130.5	41.0	4.0	130.5	
224927	7:36 PM	8:13 PM	118.4	76.0	63.0	178.3	
224928	8:13 PM	8:50 PM	118.4	76.0	63.0	178.3	
224929	8:50 PM	9:27 PM	118.4	76.0	63.0	178.3	
224930	9:27 PM	10:04 PM	118.4	76.0	63.0	178.3	
224931	10:04 PM	10:41 PM	118.4	76.0	63.0	178.3	
224932	10:41 PM	11:18 PM	118.4	76.0	63.0	178.3	
224933	11:18 PM	11:55 PM	118.4	76.0	63.0	178.3	
224934	11:55 PM	12:32 PM	118.4	76.0	63.0	178.3	
224935	12:32 PM	1:09 PM	118.4	76.0	63.0	178.3	
224936	1:09 PM	1:46 PM	118.4	76.0	63.0	178.3	
224937	1:46 PM	2:23 PM	118.4	76.0	63.0	178.3	
224938	2:23 PM	3:00 PM	118.4	76.0	63.0	178.3	
224939	3:00 PM	3:37 PM	118.4	76.0	63.0	178.3	
224940	3:37 PM	4:14 PM	118.4	76.0	63.0	178.3	
224941	4:14 PM	4:51 PM	118.4	76.0	63.0	178.3	
224942	4:51 PM	5:28 PM	118.4	76.0	63.0	178.3	
224943	5:28 PM	6:05 PM	118.4	76.0	63.0	178.3	
224944	6:05 PM	6:42 PM	118.4	76.0	63.0	178.3	
224945	6:42 PM	7:19 PM	118.4	76.0	63.0	178.3	
224946	7:19 PM	7:56 PM	118.4	76.0	63.0	178.3	
224947	7:56 PM	8:33 PM	118.4	76.0	63.0	178.3	
224948	8:33 PM	9:10 PM	118.4	76.0	63.0	178.3	
224949	9:10 PM	9:47 PM	118.4	76.0	63.0	178.3	
224950	9:47 PM	10:24 PM	118.4	76.0	63.0	178.3	
224951	10:24 PM	11:01 PM	118.4	76.0	63.0	178.3	
224952	11:01 PM	11:38 PM	118.4	76.0	63.0	178.3	
224953	11:38 PM	12:15 PM	118.4	76.0	63.0	178.3	
224954	12:15 PM	12:52 PM	118.4	76.0	63.0	178.3	
224955	12:52 PM	1:29 PM	118.4	76.0	63.0	178.3	
224956	1:29 PM	2:06 PM	118.4	76.0	63.0	178.3	
224957	2:06 PM	2:43 PM	118.4	76.0	63.0	178.3	
224958	2:43 PM	3:20 PM	118.4	76.0	63.0	178.3	
224959	3:20 PM	3:57 PM	118.4	76.0	63.0	178.3	
224960	3:57 PM	4:34 PM	118.4	76.0	63.0	178.3	
224961	4:34 PM	5:11 PM	118.4	76.0	63.0	178.3	
224962	5:11 PM	5:48 PM	118.4	76.0	63.0	178.3	
224963	5:48 PM	6:25 PM	118.4	76.0	63.0	178.3	
224964	6:25 PM	7:02 PM	118.4	76.0	63.0	178.3	
224965	7:02 PM	7:39 PM	118.4	76.0	63.0	178.3	
224966	7:39 PM	8:16 PM	118.4	76.0	63.0	178.3	
224967	8:16 PM	8:53 PM	118.4	76.0	63.0	178.3	
224968	8:53 PM	9:30 PM	118.4	76.0	63.0	178.3	
224969	9:30 PM	10:07 PM	118.4	76.0	63.0	178.3	
224970	10:07 PM	10:44 PM	118.4	76.0	63.0	178.3	
224971	10:44 PM	11:21 PM	118.4	76.0	63.0	178.3	
224972	11:21 PM	11:58 PM	118.4	76.0	63.0	178.3	
224973	11:58 PM	12:35 PM	118.4	76.0	63.0	178.3	
224974	12:35 PM	1:12 PM	118.4	76.0	63.0	178.3	
224975	1:12 PM	1:49 PM	118.4	76.0	63.0	178.3	
224976	1:49 PM	2:26 PM	118.4	76.0	63.0	178.3	
224977	2:26 PM	3:03 PM	118.4	76.0	63.0	178.3	
224978	3:03 PM	3:40 PM	118.4	76.0	63.0	178.3	
224979	3:40 PM	4:17 PM	118.4	76.0	63.0	178.3	
224980	4:17 PM	4:54 PM	118.4	76.0	63.0	178.3	
224981	4:54 PM	5:31 PM	118.4	76.0	63.0	178.3	
224982	5:31 PM	6:08 PM	118.4	76.0	63.0	178.3	
224983	6:08 PM	6:45 PM	118.4	76.0	63.0	178.3	
224984	6:45 PM	7:22 PM	118.4	76.0	63.0	178.3	
224985	7:22 PM	7:59 PM	118.4	76.0	63.0	178.3	
224986	7:59 PM	8:36 PM	118.4	76.0	63.0	178.3	
224987	8:36 PM	9:13 PM	118.4	76.0	63.0	178.3	
224988	9:13 PM	9:50 PM	118.4	76.0	63.0	178.3	
224989	9:50 PM	10:27 PM	118.4	76.0	63.0	178.3	
224990	10:27 PM	11:04 PM	118.4	76.0	63.0	178.3	
224991	11:04 PM	11:41 PM	118.4	76.0	63.0	178.3	
224992	11:41 PM	12:18 PM	118.4	76.0	63.0	178.3	
224993	12:18 PM	12:55 PM	118.4	76.0	63.0	178.3	
224994	12:55 PM	1:32 PM	118.4	76.0	63.0	178.3	
224995	1:32 PM	2:09 PM	118.4	76.0	63.0	178.3	
224996	2:09 PM	2:46 PM	118.4	76.0	63.0	178.3	
224997	2:46 PM	3:23 PM	118.4	76.0	63.0	178.3	
224998	3:23 PM	4:00 PM	118.4	76.0	63.0	178.3	
224999	4:00 PM	4:37 PM	118.4	76.0	63.0	178.3	
225000	4:37 PM	5:14 PM	118.4	76.0	63.0	178.3	
225001	5:14 PM	5:51 PM	118.4	76.0	63.0	178.3	
225002	5:51 PM	6:28 PM	118.4	76.0	63.0	178.3	
225003	6:28 PM	7:05 PM	118.4	76.0	63.0	178.3	
225004	7:05 PM	7:42 PM	118.4	76.0	63.0	178.3	
225005	7:42 PM	8:19 PM	118.4	76.0	63.0	178.3	
225006	8:19 PM	8:56 PM	118.4	76.0	63.0	178.3	
225007	8:56 PM	9:33 PM	118.4	76.0	63.0	178.3	
225008	9:33 PM	10:10 PM	118.4	76.0	63.0	178.3	
225009	10:10 PM	10:47 PM	118.4	76.0	63.0	178.3	
225010	10:47 PM	11:24 PM	118.4	76.0	63.0	178.3	
225011	11:24 PM	12:01 PM	118.4	76.0	63.0	178.3	
225012	12:01 PM	12:38 PM	118.4	76.0	63.0	178.3	
225013	12:38 PM	1:15 PM	118.4	76.0	63.0	178.3	
225014	1:15 PM	1:52 PM	118.4	76.0	63.0	178.3	
225015	1:52 PM	2:29 PM	118.4	76.0	63.0	178.3	
225016	2:29 PM	3:06 PM	118.4	76.0	63.0	178.3	
225017	3:06 PM	3:43 PM	118.4	76.0	63.0	178.3	
225018	3:43 PM	4:20 PM	118.4	76.0	63.0	178.3	
225019	4:20 PM	4:57 PM	118.4	76.0	63.0	178.3	
225020	4:57 PM	5:34 PM	118.4	76.0	63.0	178.3	
225021	5:34 PM	6:11 PM	118.4	76.0	63.0	178.3	
225022	6:11 PM	6:48 PM	118.4	76.0	63.0	178.3	
225023	6:48 PM	7:25 PM	118.4	76.0	63.0	178.3	
225024	7:25 PM	8:02 PM	118.4	76.0	63.0	178.3	
225025	8:02 PM	8:39 PM	118.4	76.0	63.0	178.3	
225026	8:39 PM	9:16 PM	118.4	76.0	63.0	178.3	
225027	9:16 PM	9:53 PM	118.4	76.0	63.0	178.3	
225028	9:53 PM	10:30 PM	118.4	76.0	63.0	178.3	
225029	10:30 PM	11:07 PM	118.4	76.0	63.0	178.3	
225030	11:07 PM	11:44 PM	118.4	76.0	63.0	178.3	
225031	11:44 PM	12:21 PM	118.4	76.0	63.0	178.3	
225032	12:21 PM	12:58 PM	118.4	76.0	63.0	178.3	
225033	12:58 PM	1:35 PM	118.4	76.0	63.0	178.3	
225034	1:35 PM	2:12 PM	118.4	76.0	63.0	178.3	
225035	2:12 PM	2:49 PM	118.4	76.0	63.0	178.3	
225036	2:49 PM	3:26 PM	118.4	76.0	63.0	178.3	
225037	3:26 PM	4:03 PM	118.4	76.0	63.0	178.3	
225038	4:03 PM	4:40 PM	118.4	76.0	63.0	178.3	
225039	4:40 PM	5:17 PM	118.4	76.0	63.0	178.3	
225040	5:17 PM	5:54 PM	118.4	76.0	63.0	178.3	
225041	5:54 PM	6:31 PM	118.4	76.0	63.0	178.3	
225042	6:31 PM	7:08 PM	118.4	76.0	63.0	178.3	
225043	7:08 PM	7:45 PM	118.4	76.0	63.0	178.3	
225044	7:45 PM	8:22 PM	118.4	76.0	63.0	178.3	
225045	8:22 PM	8:59 PM	118.4	76.0	63.0	178.3	
225046	8:59 PM	9:36 PM	118.4	76.0	63.0	178.3	
225047	9:36 PM	10:13 PM	118.4	76.0	63.0	178.3	
225048	10:13 PM	10:50 PM	118.4	76.0	63.0	178.3	
225049	10:50 PM	11:27 PM	118.4	76.0	63.0	178.3	
225050	11:27 PM	12:04 PM	118.4	76.0	63.0	178.3	
225051	12:04 PM	12:41 PM	118.4	76.0	63.0	178.3	
225052	12:41 PM	1:18 PM	118.4	76.0	63.0	178.3	
225053	1:18 PM	1:55 PM					



Nucor Steel - Crawfordsville, IN  
 Baghouse #1 & #2 Stack Test Production Data  
 April 18, 2006

Nucor Steel - Crawfordsville, IN  
 Baghouse #1 & #2 Stack Test Production Data  
 April 19, 2006

Nucor Steel - Crawfordsville, IN  
 Baghouse #1 & #2 Stack Test Production Data  
 April 19, 2006

VOC/Metals Run 1: 12:50 pm - 3:36 pm

VOC/Metals Run 2: 6:06 pm - 7:20 pm

VOC/Metals Run 3: 8:20am - 1:25 pm

Heat Number	Start	End	Net Loads	Total	Run	Total	Average	Heat Number	Start	End	Net Loads	Total	Run	Total	Average	Heat Number	Start	End	Net Loads	Total	Run	Total	Average
			Tons	Minutes	Minutes	Tons	ton/hr				Tons	Minutes	Minutes	Tons	ton/hr				Tons	Minutes	Minutes	Tons	ton/hr
156928	12:52 PM	1:18 PM	130.7	46.0	25.0	73.6	1.61	156927	4:51 PM	5:29 PM	131.2	36.0	24.0	62.3	1.70	254850	7:53 AM	8:00 AM	123.4	65.0	75.9	118.1	1.57
156929	1:18 PM	2:12 PM	114.0	48.0	14.6	114.6	2.39	156928	5:29 PM	6:17 PM	130.2	46.0	48.0	130.2	2.83	254851	8:23 AM	10:33 AM	123.4	85.0	124.6	124.6	1.47
156930	2:12 PM	3:17 PM	114.5	47.0	11.5	115.0	2.45	156929	6:17 PM	7:20 PM	131.0	35.0	20.0	48.1	1.37	254852	10:33 AM	12:33 PM	123.4	82.0	124.6	124.6	1.51
156931	3:17 PM	4:39 PM	114.5	47.0	11.5	115.0	2.45	156930	7:20 PM	8:23 PM	117.5	62.0	18.0	28.6	0.46	254853	12:33 PM	2:05 PM	118.7	62.0	118.1	118.1	1.91
156932	4:39 PM	5:29 PM	114.5	47.0	11.5	115.0	2.45	156931	8:23 PM	9:01 PM	118.5	62.0	78.0	110.8	1.79	254854	2:05 PM	3:24 PM	124.7	64.0	124.7	124.7	1.96
156933	5:29 PM	6:17 PM	114.5	47.0	11.5	115.0	2.45	156932	9:01 PM	9:51 PM	118.5	62.0	78.0	110.8	1.79	254855	3:24 PM	4:54 PM	124.7	64.0	124.7	124.7	1.96
156934	6:17 PM	7:20 PM	114.5	47.0	11.5	115.0	2.45	156933	9:51 PM	10:33 PM	117.5	62.0	18.0	28.6	0.46	254856	4:54 PM	6:24 PM	124.7	64.0	124.7	124.7	1.96
156935	7:20 PM	8:23 PM	114.5	47.0	11.5	115.0	2.45	156934	10:33 PM	11:15 PM	117.5	62.0	18.0	28.6	0.46	254857	6:24 PM	7:54 PM	124.7	64.0	124.7	124.7	1.96
156936	8:23 PM	9:01 PM	114.5	47.0	11.5	115.0	2.45	156935	11:15 PM	11:57 PM	117.5	62.0	18.0	28.6	0.46	254858	7:54 PM	9:24 PM	124.7	64.0	124.7	124.7	1.96
156937	9:01 PM	9:51 PM	114.5	47.0	11.5	115.0	2.45	156936	11:57 PM	12:39 AM	117.5	62.0	18.0	28.6	0.46	254859	9:24 PM	10:54 PM	124.7	64.0	124.7	124.7	1.96
156938	9:51 PM	10:33 PM	114.5	47.0	11.5	115.0	2.45	156937	12:39 AM	1:21 AM	117.5	62.0	18.0	28.6	0.46	254860	10:54 PM	12:24 AM	124.7	64.0	124.7	124.7	1.96
156939	10:33 PM	11:15 PM	114.5	47.0	11.5	115.0	2.45	156938	1:21 AM	2:03 AM	117.5	62.0	18.0	28.6	0.46	254861	12:24 AM	1:54 AM	124.7	64.0	124.7	124.7	1.96
156940	11:15 PM	11:57 PM	114.5	47.0	11.5	115.0	2.45	156939	2:03 AM	2:45 AM	117.5	62.0	18.0	28.6	0.46	254862	1:54 AM	3:24 AM	124.7	64.0	124.7	124.7	1.96
156941	11:57 PM	12:39 AM	114.5	47.0	11.5	115.0	2.45	156940	2:45 AM	3:27 AM	117.5	62.0	18.0	28.6	0.46	254863	3:24 AM	4:54 AM	124.7	64.0	124.7	124.7	1.96
156942	12:39 AM	1:21 AM	114.5	47.0	11.5	115.0	2.45	156941	3:27 AM	4:09 AM	117.5	62.0	18.0	28.6	0.46	254864	4:54 AM	6:24 AM	124.7	64.0	124.7	124.7	1.96
156943	1:21 AM	2:03 AM	114.5	47.0	11.5	115.0	2.45	156942	4:09 AM	4:51 AM	117.5	62.0	18.0	28.6	0.46	254865	6:24 AM	7:54 AM	124.7	64.0	124.7	124.7	1.96
156944	2:03 AM	2:45 AM	114.5	47.0	11.5	115.0	2.45	156943	4:51 AM	5:33 AM	117.5	62.0	18.0	28.6	0.46	254866	7:54 AM	9:24 AM	124.7	64.0	124.7	124.7	1.96
156945	2:45 AM	3:27 AM	114.5	47.0	11.5	115.0	2.45	156944	5:33 AM	6:15 AM	117.5	62.0	18.0	28.6	0.46	254867	9:24 AM	10:54 AM	124.7	64.0	124.7	124.7	1.96
156946	3:27 AM	4:09 AM	114.5	47.0	11.5	115.0	2.45	156945	6:15 AM	6:57 AM	117.5	62.0	18.0	28.6	0.46	254868	10:54 AM	12:24 AM	124.7	64.0	124.7	124.7	1.96
156947	4:09 AM	4:51 AM	114.5	47.0	11.5	115.0	2.45	156946	6:57 AM	7:39 AM	117.5	62.0	18.0	28.6	0.46	254869	12:24 AM	1:54 AM	124.7	64.0	124.7	124.7	1.96
156948	4:51 AM	5:33 AM	114.5	47.0	11.5	115.0	2.45	156947	7:39 AM	8:21 AM	117.5	62.0	18.0	28.6	0.46	254870	1:54 AM	3:24 AM	124.7	64.0	124.7	124.7	1.96
156949	5:33 AM	6:15 AM	114.5	47.0	11.5	115.0	2.45	156948	8:21 AM	9:03 AM	117.5	62.0	18.0	28.6	0.46	254871	3:24 AM	4:54 AM	124.7	64.0	124.7	124.7	1.96
156950	6:15 AM	6:57 AM	114.5	47.0	11.5	115.0	2.45	156949	9:03 AM	9:45 AM	117.5	62.0	18.0	28.6	0.46	254872	4:54 AM	6:24 AM	124.7	64.0	124.7	124.7	1.96
156951	6:57 AM	7:39 AM	114.5	47.0	11.5	115.0	2.45	156950	9:45 AM	10:27 AM	117.5	62.0	18.0	28.6	0.46	254873	6:24 AM	7:54 AM	124.7	64.0	124.7	124.7	1.96
156952	7:39 AM	8:21 AM	114.5	47.0	11.5	115.0	2.45	156951	10:27 AM	11:09 AM	117.5	62.0	18.0	28.6	0.46	254874	7:54 AM	9:24 AM	124.7	64.0	124.7	124.7	1.96
156953	8:21 AM	9:03 AM	114.5	47.0	11.5	115.0	2.45	156952	11:09 AM	11:51 AM	117.5	62.0	18.0	28.6	0.46	254875	9:24 AM	10:54 AM	124.7	64.0	124.7	124.7	1.96
156954	9:03 AM	9:45 AM	114.5	47.0	11.5	115.0	2.45	156953	11:51 AM	12:33 AM	117.5	62.0	18.0	28.6	0.46	254876	10:54 AM	12:24 AM	124.7	64.0	124.7	124.7	1.96
156955	9:45 AM	10:27 AM	114.5	47.0	11.5	115.0	2.45	156954	12:33 AM	1:15 AM	117.5	62.0	18.0	28.6	0.46	254877	12:24 AM	1:54 AM	124.7	64.0	124.7	124.7	1.96
156956	10:27 AM	11:09 AM	114.5	47.0	11.5	115.0	2.45	156955	1:15 AM	1:57 AM	117.5	62.0	18.0	28.6	0.46	254878	1:54 AM	3:24 AM	124.7	64.0	124.7	124.7	1.96
156957	11:09 AM	11:51 AM	114.5	47.0	11.5	115.0	2.45	156956	1:57 AM	2:39 AM	117.5	62.0	18.0	28.6	0.46	254879	3:24 AM	4:54 AM	124.7	64.0	124.7	124.7	1.96
156958	11:51 AM	12:33 AM	114.5	47.0	11.5	115.0	2.45	156957	2:39 AM	3:21 AM	117.5	62.0	18.0	28.6	0.46	254880	4:54 AM	6:24 AM	124.7	64.0	124.7	124.7	1.96
156959	12:33 AM	1:15 AM	114.5	47.0	11.5	115.0	2.45	156958	3:21 AM	4:03 AM	117.5	62.0	18.0	28.6	0.46	254881	6:24 AM	7:54 AM	124.7	64.0	124.7	124.7	1.96
156960	1:15 AM	1:57 AM	114.5	47.0	11.5	115.0	2.45	156959	4:03 AM	4:45 AM	117.5	62.0	18.0	28.6	0.46	254882	7:54 AM	9:24 AM	124.7	64.0	124.7	124.7	1.96
156961	1:57 AM	2:39 AM	114.5	47.0	11.5	115.0	2.45	156960	4:45 AM	5:27 AM	117.5	62.0	18.0	28.6	0.46	254883	9:24 AM	10:54 AM	124.7	64.0	124.7	124.7	1.96
156962	2:39 AM	3:21 AM	114.5	47.0	11.5	115.0	2.45	156961	5:27 AM	6:09 AM	117.5	62.0	18.0	28.6	0.46	254884	10:54 AM	12:24 AM	124.7	64.0	124.7	124.7	1.96
156963	3:21 AM	4:03 AM	114.5	47.0	11.5	115.0	2.45	156962	6:09 AM	6:51 AM	117.5	62.0	18.0	28.6	0.46	254885	12:24 AM	1:54 AM	124.7	64.0	124.7	124.7	1.96
156964	4:03 AM	4:45 AM	114.5	47.0	11.5	115.0	2.45	156963	6:51 AM	7:33 AM	117.5	62.0	18.0	28.6	0.46	254886	1:54 AM	3:24 AM	124.7	64.0	124.7	124.7	1.96
156965	4:45 AM	5:27 AM	114.5	47.0	11.5	115.0	2.45	156964	7:33 AM	8:15 AM	117.5	62.0	18.0	28.6	0.46	254887	3:24 AM	4:54 AM	124.7	64.0	124.7	124.7	1.96
156966	5:27 AM	6:09 AM	114.5	47.0	11.5	115.0	2.45	156965	8:15 AM	8:57 AM	117.5	62.0	18.0	28.6	0.46	254888	4:54 AM	6:24 AM	124.7	64.0	124.7	124.7	1.96
156967	6:09 AM	6:51 AM	114.5	47.0	11.5	115.0	2.45	156966	8:57 AM	9:39 AM	117.5	62.0	18.0	28.6	0.46	254889	6:24 AM	7:54 AM	124.7	64.0	124.7	124.7	1.96
156968	6:51 AM	7:33 AM	114.5	47.0	11.5	115.0	2.45	156967	9:39 AM	10:21 AM	117.5	62.0	18.0	28.6	0.46	254890	7:54 AM	9:24 AM	124.7	64.0	124.7	124.7	1.96
156969	7:33 AM	8:15 AM	114.5	47.0	11.5	115.0	2.45	156968	10:21 AM	11:03 AM	117.5	62.0	18.0	28.6	0.46	254891	9:24 AM	10:54 AM	124.7	64.0	124.7	124.7	1.96
156970	8:15 AM	8:57 AM	114.5	47.0	11.5	115.0	2.45	156969	11:03 AM	11:45 AM	117.5	62.0	18.0	28.6	0.46	254892	10:54 AM	12:24 AM	124.7	64.0	124.7	124.7	1.96
156971	8:57 AM	9:39 AM	114.5	47.0	11.5	115.0	2.45	156970	11:45 AM	12:27 AM	117.5</												

# Melt Shop / AOD Baghouse Baseline PM and Opacity Testing Baghouse #1

## Run 1 Fan Amps and Damper Positions

DATE: 4/18/05 Run 1 Time: 12:50 pm - 7:36 pm

Time	FAN 1		FAN 2		FAN 3		FAN 4		FAN 5		FAN 6	
	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position
12:48 PM	159	100%	153	100%					144	100%	161	99%
1:03 PM	155	100%	149	100%					142	100%	155	100%
1:18 PM	153	100%	143	99%					140	100%	157	100%
1:33 PM	149	100%	142	99%					138	100%	149	100%
1:48 PM	162	86%	154	99%					154	100%	160	99%
2:03 PM	157	100%	148	100%					148	100%	155	100%
2:18 PM	162	92%	155	99%					154	100%	157	98%
2:33 PM	161	90%	152	99%					152	100%	160	100%
2:48 PM	157	100%	145	100%					149	100%	159	100%
3:03 PM	147	100%	138	100%					136	100%	146	100%
3:18 PM	157	100%	150	100%					146	100%	156	100%
3:33 PM	155	100%	151	100%					146	100%	157	100%
3:48 PM	154	100%	149	100%					147	100%	155	100%
4:03 PM	159	100%	152	100%					149	100%	156	100%
4:18 PM	161	79%	161	68%					156	100%	158	96%
4:33 PM	155	100%	156	100%					143	100%	155	100%
4:48 PM	162	94%	164	79%					152	100%	158	99%
5:03 PM	159	92%	159	74%					142	100%	151	100%
5:18 PM	156	100%	157	99%					142	100%	159	100%
5:33 PM	155	100%	156	100%					144	100%	159	100%
5:48 PM	161	84%	160	67%					155	99%	160	100%
6:03 PM	161	100%	161	92%					148	100%	159	100%
6:18 PM	160	82%	160	66%					155	100%	161	100%
6:33 PM	162	90%	161	74%					151	100%	159	97%
6:48 PM	158	100%	159	83%					149	100%	158	100%
7:03 PM												
7:18 PM	152	100%	155	100%					143	100%	151	100%
7:33 PM	161	95%	162	74%					152	100%	159	99%
7:48 PM	127	100%	137	100%					116	100%	130	100%

	Grand Totals					
	Fan 1	Fan 2	Fan 3	Fan 4	Fan 5	Fan 6
Max	162	164			156	161
Min	127	164			116	130
Avg	156.3	153.2			146.5	155.7

# Melt Shop / AOD Baghouse Baseline PM and Opacity Testing

## Baghouse #1

### Run 2 Fan Amps and Damper Positions

DATE: 4/19/05 Run 2 Time: 8:20 am - 4:08 pm

Time	FAN 1		FAN 2		FAN 3		FAN 4		FAN 5		FAN 6			
	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position		
8:15 AM	160	83%	161	67%					152	100%	161	97%		
8:30 AM	158	96%	160	76%					149	100%	159	100%		
8:45 AM	147	100%	151	100%					136	100%	150	100%		
9:00 AM	166	83%	164	66%					159	100%	159	98%		
9:15 AM	160	84%	161	68%					152	100%	161	99%		
9:30 AM	161	95%	161	73%					149	100%	162	99%		
9:45 AM	153	100%	155	100%					142	100%	154	100%		
10:00 AM	161	74%	165	63%					163	98%	157	95%		
10:15 AM	160	70%	163	58%					162	91%	157	93%		
10:30 AM	161	68%	161	58%					161	89%	158	94%		
10:45 AM	160	67%	161	54%					159	82%	164	93%		
11:00 AM	162	76%	158	61%					161	96%	163	97%		
					TESTING SUSPENDED									
12:40 PM	162	76%	158	61%					160	97%	159	94%		
12:55 PM	159	85%	160	69%					152	100%	164	100%		
1:10 PM	152	100%	159	100%					146	100%	153	100%		
1:25 PM	151	100%	153	100%					140	100%	155	100%		
1:40 PM	159	78%	161	66%					155	100%	160	99%		
1:55 PM	161	94%	162	73%					149	100%	164	100%		
2:10 PM	153	100%	160	95%					140	100%	161	100%		
2:25 PM	144	100%	148	100%					136	100%	147	100%		
2:40 PM	155	100%	160	95%					145	100%	160	100%		
2:55 PM	157	89%	158	71%					150	100%	160	100%		
3:10 PM	161	77%	161	62%					157	100%	162	98%		
3:25 PM	157	100%	159	87%					150	100%	156	100%		
3:40 PM	150	100%	157	99%					138	100%	155	100%		
3:55 PM	156	100%	160	99%					146	100%	157	100%		
4:10 PM	158	100%	163	96%					150	100%	158	100%		
AVG	157	89%	159	78%					150	98%	158	98%		

	Fan 1	Fan 2	Fan 3	Fan 4	Fan 5	Fan 6	Grand Totals
Max	166	165			163	164	166
Min	144	148			136	147	136
Avg	157.2	159.3			150.3	158.4	156.3



## Melt Shop / AOD Baghouse Baseline PM and Opacity Testing

4/18/2005			4/19/2005			4/22/2005		
Run 1			Run 2			Run 3		
	BH #1	BH #2		BH #1	BH #2		BH #1	BH #2
Time	DP, in. H2O	DP, in. H2O	Time	DP, in. H2O	DP, in. H2O	Time	DP, in. H2O	DP, in. H2O
12:48 PM	7.5	9.5	8:15 AM	7.6	8.6	8:33 AM	7.5	7.9
1:03 PM	7.6	10.1	8:30 AM	7.5	9.4	8:48 AM	7.9	8.1
1:18 PM	7.7	9.2	8:45 AM	7.4	8.8	9:03 AM	8.1	8.3
1:33 PM	8.0	10.3	9:00 AM	7.6	8.9	9:18 AM	8.4	9.0
1:48 PM	7.6	10.0	9:15 AM	6.8	9.4	9:33 AM	7.6	8.6
2:03 PM	7.3	8.9	9:30 AM	7.1	9.9	9:48 AM	7.9	9.2
2:18 PM	7.6	8.8	9:45 AM	7.4	7.4	10:03 AM	8.4	9.8
2:33 PM	7.2	10.1	10:00 AM	7.0		10:18 AM	7.3	9.0
2:48 PM	8.0	10.4	10:15 AM	7.1	10.1	10:33 AM	8.0	9.0
3:03 PM	7.7	9.1	10:30 AM	6.5	8.4	10:48 AM	8.0	9.6
3:18 PM	7.8	10.8	10:45 AM	6.4	8.2			
3:33 PM	7.8	10.1	11:00 AM	6.7				
3:48 PM	7.8	10.3				11:30 AM	8.1	7.9
4:03 PM	7.2	10.8				11:45 AM	8.6	8.2
4:18 PM	7.6	10.2	12:40 PM	6.8	6.9	12:00 PM	7.7	9.3
4:33 PM	7.8	10.7	12:55 PM	7.5	8.4	12:15 PM	8.1	10.1
4:48 PM	7.8	9.8	1:10 PM	7.8	8.3	12:30 PM	8.3	9.0
5:03 PM	7.6	10.1	1:25 PM	7.7	7.6	12:45 PM	7.7	10.0
5:18 PM	7.7	10.9	1:40 PM	6.8	9.3	1:00 PM	8.1	10.7
5:33 PM	8.3	9.5	1:55 PM	7.7	9.6	1:15 PM	8.0	8.8
5:48 PM	7.6	10.1	2:10 PM	7.7	8.0	1:30 PM	8.1	10.2
6:03 PM	7.6	10.8	2:25 PM	7.8	7.7	1:45 PM	7.9	10.1
6:18 PM	7.7	9.4	2:40 PM	7.1	9.4	2:00 PM	7.8	9.8
6:33 PM	7.5	10.1	2:55 PM	7.2	9.5	2:15 PM	8.6	9.9
6:48 PM	7.8	9.8	3:10 PM	7.4	9.1			
7:03 PM	8.0	9.0	3:25 PM	7.9	9.6			
7:18 PM	7.5	10.0	3:40 PM	7.0	10.0			
7:33 PM	7.9	9.1	3:55 PM	8.0	9.2			
7:48 PM	7.7	9.9	4:10 PM	7.3	10.3			
Max	8.3	10.9	Max	8.0	10.3	Max	8.6	10.7
Min	7.2	8.8	Min	6.4	6.9	Min	7.3	7.9
Avg	7.7	9.9	Avg	7.3	8.9	Avg	8.0	9.2

# Melt Shop / AOD Baghouse Baseline PM and Opacity Testing

## Baghouse #1

### Run 1 Bag Leak Detection System

DATE: 4/18/05

Run 1 Time: 12:50 pm - 7:36 pm

#### Baghouse #1 Compartment

Time	1/2	3/4	5/6	7/8	9/10	11/12	13/14	15/16
12:48 PM	1.4%	1.2%	2.1%	8.5%	1.2%	0.8%	0.8%	0.8%
1:03 PM	1.0%	0.5%	0.8%	2.6%	0.4%	0.8%	0.6%	0.8%
1:18 PM	0.2%	0.4%	0.8%	3.6%	0.7%	1.4%	1.1%	0.8%
1:33 PM	1.0%	1.3%	1.1%	5.4%	2.0%	5.0%	1.0%	0.9%
1:48 PM	0.8%	0.4%	0.8%	0.7%	1.2%	0.8%	0.9%	0.8%
2:03 PM	0.9%	1.1%	1.6%	0.0%	1.8%	0.4%	2.3%	1.1%
2:18 PM	0.8%	0.8%	0.8%	0.1%	1.2%	0.8%	1.1%	0.8%
7:12 PM	0.8%	0.8%	0.8%	0.7%	1.1%	0.8%	0.7%	1.5%
2:48 PM	0.8%	1.5%	1.3%	0.8%	1.6%	8.2%	1.1%	1.4%
3:03 PM	1.4%	4.7%	4.2%	12.6%	8.0%	2.6%	0.3%	2.8%
3:18 PM	1.9%	0.5%	0.9%	7.2%	0.7%	0.8%	4.3%	1.2%
3:33 PM	0.7%	0.8%	0.5%	4.5%	1.0%	5.6%	1.2%	0.8%
3:48 PM	1.0%	1.5%	1.4%	3.0%	1.0%	0.8%	0.8%	1.8%
4:03 PM	0.2%	0.5%	0.4%	3.5%	1.2%	1.6%	1.1%	0.7%
4:18 PM	0.8%	0.7%	0.7%	0.9%	0.8%	0.4%	1.0%	0.7%
4:33 PM	1.6%	1.8%	1.6%	1.8%	1.3%	1.7%	0.7%	0.8%
4:48 PM	0.7%	0.7%	0.7%	0.7%	1.1%	0.8%	0.8%	0.7%
5:03 PM	1.5%	0.7%	0.7%	1.2%	0.6%	0.7%	1.0%	0.7%
5:18 PM	0.7%	1.2%	0.8%	0.1%	1.2%	1.2%	2.2%	0.8%
5:33 PM	0.8%	1.0%	1.2%	0.5%	1.0%	0.8%	1.1%	1.5%
5:48 PM	0.7%	0.7%	0.7%	0.6%	0.8%	0.7%	0.8%	1.5%
6:03 PM	0.8%	0.8%	1.6%	0.6%	0.8%	0.7%	4.1%	1.1%
6:18 PM	1.5%	0.7%	0.7%	0.4%	1.1%	0.7%	1.0%	0.7%
6:33 PM	1.3%	0.7%	0.7%	1.9%	1.7%	0.7%	1.4%	1.1%
6:48 PM	1.1%	1.2%	1.1%	1.7%	0.3%	0.6%	0.8%	0.8%
7:03 PM	1.4%	0.7%	0.7%	1.2%	5.5%	0.8%	1.2%	0.7%
7:18 PM	2.8%	1.8%	0.8%	1.3%	0.9%	0.9%	1.2%	0.8%
7:33 PM	0.7%	0.7%	0.7%	0.6%	1.5%	4.3%	0.3%	0.7%
7:48 PM	1.2%	0.8%	0.8%	1.4%	0.8%	0.8%	0.8%	0.7%



# Melt Shop / AOD Baghouse Baseline PM and Opacity Testing

## Baghouse #1

### Run 2 Bag Leak Detection System

DATE: 4/19/05

Run 2 Time: 8:20 am - 4:08 pm

Baghouse #1 Compartment								
Time	1/2	3/4	5/6	7/8	9/10	11/12	13/14	15/16
8:15 AM	0.8%	0.1%	0.6%	2.4%	2.5%	1.0%	0.8%	0.8%
8:30 AM	1.2%	0.9%	0.8%	3.0%	1.4%	1.2%	0.7%	1.0%
8:45 AM	2.8%	3.9%	1.3%	0.2%	1.3%	2.8%	1.7%	1.6%
9:00 AM	0.8%	0.8%	0.8%	1.4%	0.9%	2.6%	1.1%	0.6%
9:15 AM	0.8%	0.8%	0.1%	1.4%	0.5%	1.0%	1.6%	0.8%
9:30 AM	1.5%	0.1%	2.3%	1.0%	0.5%	0.8%	1.5%	0.8%
9:45 AM	1.0%	3.6%	2.3%	0.4%	2.1%	5.2%	1.5%	2.3%
10:00 AM	0.8%	3.0%	1.6%	0.3%	1.5%	0.6%	1.8%	0.8%
10:15 AM	1.0%	0.8%	0.8%	1.8%	0.4%	0.8%	0.2%	0.8%
10:30 AM	0.8%	0.8%	1.3%	0.1%	0.8%	0.8%	0.8%	0.8%
10:45 AM	0.8%	0.8%	0.8%	1.8%	0.7%	0.6%	0.4%	0.8%
11:00 AM	0.8%	0.9%	0.8%	1.9%	1.2%	1.4%	0.8%	1.2%
<b>TESTING SUSPENDED</b>								
12:40 PM	0.7%	0.7%	0.7%	0.9%	1.4%	0.7%	1.2%	0.7%
12:55 PM	0.6%	1.1%	0.8%	1.7%	0.6%	0.8%	0.8%	0.8%
1:10 PM	1.0%	1.4%	0.5%	1.5%	2.3%	17.7%	0.8%	1.4%
1:25 PM	1.0%	1.6%	1.3%	0.7%	3.5%	4.5%	1.4%	1.5%
1:40 PM	0.8%	0.8%	0.8%	0.2%	2.2%	1.4%	1.6%	1.1%
1:55 PM	0.8%	1.4%	0.5%	3.0%	1.4%	1.1%	1.0%	0.8%
2:10 PM	0.8%	1.4%	0.9%	1.1%	1.1%	2.2%	1.2%	0.9%
2:25 PM	0.6%	0.8%	0.8%	1.4%	1.2%	2.9%	70.0%	1.4%
2:40 PM	6.2%	0.9%	3.4%	1.4%	1.2%	2.1%	0.7%	0.7%
2:55 PM	0.8%	0.8%	0.7%	1.0%	0.7%	2.7%	4.7%	0.4%
3:10 PM	0.6%	0.8%	0.8%	1.6%	0.7%	1.6%	1.0%	0.8%
3:25 PM	1.2%	2.0%	1.6%	3.2%	2.9%	2.7%	1.3%	1.1%
3:40 PM	0.8%	7.0%	3.1%	0.4%	2.4%	9.9%	1.8%	1.2%
3:55 PM	1.9%	1.0%	1.8%	0.9%	1.2%	2.0%	2.3%	0.8%
4:10 PM	0.6%	1.0%	3.8%	1.7%	1.2%	9.4%	6.9%	0.6%

# Melt Shop / AOD Baghouse Baseline PM and Opacity Testing

## Baghouse #1

### Run 3 Bag Leak Detection System

DATE: 4/22/05

Run 3 Time: 8:33 am - 2:14 pm

Baghouse #1 Compartment									
Time	1/2	3/4	5/6	7/8	9/10	11/12	13/14	15/16	
8:33 AM	0.7%	0.7%	0.7%	0.4%	0.6%	0.6%	0.7%	0.7%	
8:48 AM	1.0%	4.2%	1.3%	0.5%	0.8%	3.9%	1.0%	3.3%	
9:03 AM	0.4%	2.4%	0.9%	0.6%	0.2%	0.1%	0.6%	0.8%	
9:18 AM	0.8%	0.7%	0.7%	0.8%	0.3%	0.3%	0.7%	0.8%	
9:33 AM	0.6%	2.7%	1.7%	2.6%	1.4%	5.0%	1.2%	1.1%	
9:48 AM	0.5%	1.5%	0.7%	0.3%	0.3%	26.3%	0.2%	0.7%	
10:03 AM	0.7%	0.7%	0.7%	6.5%	1.2%	1.0%	0.7%	0.8%	
10:18 AM	0.7%	0.6%	1.2%	0.8%	0.4%	0.0%	0.2%	0.7%	
10:33 AM	2.6%	1.0%	0.8%	2.2%	0.7%	0.8%	0.8%	0.7%	
10:48 AM	0.8%	0.9%	1.0%	1.9%	0.8%	2.0%	0.9%	0.8%	
				<b>TESTING SUSPENDED</b>					
11:30 AM	0.7%	0.5%	1.1%	2.0%	0.5%	0.8%	2.4%	1.2%	
11:45 AM	2.4%	1.0%	0.7%	3.9%	0.0%	1.0%	1.0%	1.0%	
12:00 PM	0.7%	0.7%	0.7%	4.7%	1.1%	0.5%	0.7%	0.7%	
12:15 PM	0.7%	1.0%	0.7%	0.6%	0.8%	0.7%	1.8%	0.7%	
12:30 PM	0.8%	0.7%	0.7%	2.4%	1.0%	0.4%	0.5%	0.7%	
12:45 PM	0.7%	0.7%	3.3%	0.4%	0.7%	0.7%	0.7%	0.7%	
1:00 PM	1.0%	0.8%	2.7%	0.7%	0.8%	0.9%	1.2%	0.9%	
1:15 PM	0.0%	0.7%	3.4%	4.6%	0.4%	1.0%	1.8%	0.8%	
1:30 PM	0.7%	0.7%	3.0%	1.0%	0.2%	0.7%	0.7%	0.7%	
1:45 PM	7.6%	0.5%	0.7%	0.8%	0.1%	0.2%	0.1%	0.7%	
2:00 PM	1.1%	1.9%	1.7%	0.5%	1.7%	4.1%	1.1%	1.3%	
2:15 PM	0.8%	1.0%	1.1%	5.5%	1.5%	3.6%	1.8%	1.5%	



Monthly Summary Report

REPORT  
DATE  
TIME  
UNIT  
MATERIAL  
WASTE  
REMARKS

UNIT  
MATERIAL  
WASTE  
REMARKS

REPORT

Signature

UNIT	MATERIAL	WASTE	REMARKS	REPORT	DATE	TIME	UNIT	MATERIAL	WASTE	REMARKS
------	----------	-------	---------	--------	------	------	------	----------	-------	---------

DP 7.5



General Baghouse Report

12/20/04  
12/21/04  
12/22/04  
12/23/04  
12/24/04  
12/25/04  
12/26/04  
12/27/04

12/28/04  
12/29/04  
12/30/04  
12/31/04  
1/1/05  
1/2/05  
1/3/05  
1/4/05

1/5/05

Shop Aspmo 10/1/04

1	2	3	4	5	6	7	8	9	10	11	12
---	---	---	---	---	---	---	---	---	----	----	----

OP - 7.6



Monthly Summary Reports

- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT

- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT

REPORT

Show Report folder

DP 7.7



Report Description

12/24/04  
12/25/04  
12/26/04  
12/27/04  
12/28/04  
12/29/04  
12/30/04  
12/31/04

12/24/04  
12/25/04  
12/26/04  
12/27/04  
12/28/04  
12/29/04  
12/30/04  
12/31/04

12/24/04

Report Description

12/24/04	12/25/04	12/26/04	12/27/04	12/28/04	12/29/04	12/30/04	12/31/04	12/24/04	12/25/04	12/26/04	12/27/04	12/28/04	12/29/04	12/30/04	12/31/04
----------	----------	----------	----------	----------	----------	----------	----------	----------	----------	----------	----------	----------	----------	----------	----------

DP-8.0

Family Report Button

- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT

- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT

REPORT

Show Report Folder

Home	Reports	Reports	Reports	Reports	Reports	Reports	Reports	Reports	Reports	Reports
------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------

DP-7.6



Vertical Baghouse Filter

10000  
10000  
10000  
10000  
10000  
10000  
10000  
10000  
10000

10000  
10000  
10000  
10000  
10000  
10000  
10000  
10000  
10000

10000

Horizontal Filter

Home	Back	Forward	Print	Refresh	Stop	Pause	Play	Full Screen	Exit
------	------	---------	-------	---------	------	-------	------	-------------	------

OP 7.3





Reportly Generation

- 12/2004
- 12/2004
- 12/2004
- 12/2004
- 12/2004
- 12/2004
- 12/2004
- 12/2004

- 12/2004
- 12/2004
- 12/2004
- 12/2004
- 12/2004
- 12/2004
- 12/2004
- 12/2004

12/2004

Show Report Fields

Home	Reports	Print	Configuration	Database	Tools	Help	Support	Admin	Users	Log
------	---------	-------	---------------	----------	-------	------	---------	-------	-------	-----

OP 7.6

Report Name: [faded]

[faded]  
[faded]  
[faded]  
[faded]  
[faded]  
[faded]  
[faded]  
[faded]  
[faded]

[faded]  
[faded]  
[faded]  
[faded]  
[faded]  
[faded]  
[faded]  
[faded]  
[faded]

[faded]

Show Report Header

[faded]	[faded]	[faded]	[faded]	[faded]	[faded]	[faded]	[faded]	[faded]	[faded]	[faded]
---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------

OP - 7.2



Print Report

- Print Report
- Print Report
- Print Report
- Print Report
- Print Report
- Print Report
- Print Report
- Print Report

- Print Report
- Print Report
- Print Report
- Print Report
- Print Report
- Print Report
- Print Report
- Print Report

Print Report

Show Report Header

DP 8.0



Verify data at bottom

10000  
10000  
10000  
10000  
10000  
10000  
10000  
10000  
10000

10000  
10000  
10000  
10000  
10000  
10000  
10000  
10000  
10000

10000

Show Report Header

File Edit View Options Database Reports Help

DP - 7.8





Print Report

- Print
- Print
- Print
- Print
- Print
- Print
- Print
- Print
- Print

- Print
- Print
- Print
- Print
- Print
- Print
- Print
- Print
- Print

Print

Show Report

Print	Print	Print	Print	Print	Print	Print	Print	Print	Print	Print
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

DP-7.8

Monthly General Report

200504  
200503  
200502  
200501  
200412  
200411  
200410  
200409  
200408

200504  
200503  
200502  
200501  
200412  
200411  
200410  
200409  
200408

200504

Filter Report Filter

Filter	Filter	Filter	Filter	Filter	Filter	Filter	Filter	Filter	Filter	Filter
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

DP 7.2





Virtual Capacity Report

1/1/05  
1/1/05  
1/1/05  
1/1/05  
1/1/05  
1/1/05  
1/1/05  
1/1/05

1/1/05  
1/1/05  
1/1/05  
1/1/05  
1/1/05  
1/1/05  
1/1/05  
1/1/05

1/1/05

Virtual Capacity Report

Home	Back	Print	Refresh	Report	Help	Logout	Search	Clear	Print	Exit
------	------	-------	---------	--------	------	--------	--------	-------	-------	------

DP 7/6



Manual Report Generation

- 1. 10/1/04
- 2. 10/1/04
- 3. 10/1/04
- 4. 10/1/04
- 5. 10/1/04
- 6. 10/1/04
- 7. 10/1/04
- 8. 10/1/04

- 9. 10/1/04
- 10. 10/1/04
- 11. 10/1/04
- 12. 10/1/04
- 13. 10/1/04
- 14. 10/1/04
- 15. 10/1/04
- 16. 10/1/04

17. 10/1/04

Manual Report Generation



DP 7.8





Multi-Component Report

UNIT 1  
UNIT 2  
UNIT 3  
UNIT 4  
UNIT 5  
UNIT 6  
UNIT 7  
UNIT 8  
UNIT 9  
UNIT 10  
UNIT 11  
UNIT 12  
UNIT 13  
UNIT 14  
UNIT 15  
UNIT 16  
UNIT 17  
UNIT 18  
UNIT 19  
UNIT 20  
UNIT 21  
UNIT 22  
UNIT 23  
UNIT 24  
UNIT 25  
UNIT 26  
UNIT 27  
UNIT 28  
UNIT 29  
UNIT 30  
UNIT 31  
UNIT 32  
UNIT 33  
UNIT 34  
UNIT 35  
UNIT 36  
UNIT 37  
UNIT 38  
UNIT 39  
UNIT 40  
UNIT 41  
UNIT 42  
UNIT 43  
UNIT 44  
UNIT 45  
UNIT 46  
UNIT 47  
UNIT 48  
UNIT 49  
UNIT 50  
UNIT 51  
UNIT 52  
UNIT 53  
UNIT 54  
UNIT 55  
UNIT 56  
UNIT 57  
UNIT 58  
UNIT 59  
UNIT 60  
UNIT 61  
UNIT 62  
UNIT 63  
UNIT 64  
UNIT 65  
UNIT 66  
UNIT 67  
UNIT 68  
UNIT 69  
UNIT 70  
UNIT 71  
UNIT 72  
UNIT 73  
UNIT 74  
UNIT 75  
UNIT 76  
UNIT 77  
UNIT 78  
UNIT 79  
UNIT 80  
UNIT 81  
UNIT 82  
UNIT 83  
UNIT 84  
UNIT 85  
UNIT 86  
UNIT 87  
UNIT 88  
UNIT 89  
UNIT 90  
UNIT 91  
UNIT 92  
UNIT 93  
UNIT 94  
UNIT 95  
UNIT 96  
UNIT 97  
UNIT 98  
UNIT 99  
UNIT 100

UNIT 1  
UNIT 2  
UNIT 3  
UNIT 4  
UNIT 5  
UNIT 6  
UNIT 7  
UNIT 8  
UNIT 9  
UNIT 10  
UNIT 11  
UNIT 12  
UNIT 13  
UNIT 14  
UNIT 15  
UNIT 16  
UNIT 17  
UNIT 18  
UNIT 19  
UNIT 20  
UNIT 21  
UNIT 22  
UNIT 23  
UNIT 24  
UNIT 25  
UNIT 26  
UNIT 27  
UNIT 28  
UNIT 29  
UNIT 30  
UNIT 31  
UNIT 32  
UNIT 33  
UNIT 34  
UNIT 35  
UNIT 36  
UNIT 37  
UNIT 38  
UNIT 39  
UNIT 40  
UNIT 41  
UNIT 42  
UNIT 43  
UNIT 44  
UNIT 45  
UNIT 46  
UNIT 47  
UNIT 48  
UNIT 49  
UNIT 50  
UNIT 51  
UNIT 52  
UNIT 53  
UNIT 54  
UNIT 55  
UNIT 56  
UNIT 57  
UNIT 58  
UNIT 59  
UNIT 60  
UNIT 61  
UNIT 62  
UNIT 63  
UNIT 64  
UNIT 65  
UNIT 66  
UNIT 67  
UNIT 68  
UNIT 69  
UNIT 70  
UNIT 71  
UNIT 72  
UNIT 73  
UNIT 74  
UNIT 75  
UNIT 76  
UNIT 77  
UNIT 78  
UNIT 79  
UNIT 80  
UNIT 81  
UNIT 82  
UNIT 83  
UNIT 84  
UNIT 85  
UNIT 86  
UNIT 87  
UNIT 88  
UNIT 89  
UNIT 90  
UNIT 91  
UNIT 92  
UNIT 93  
UNIT 94  
UNIT 95  
UNIT 96  
UNIT 97  
UNIT 98  
UNIT 99  
UNIT 100

Multi-Component Report



DP 7.6



Monthly General Report

DATE: 4/18/2005  
TIME: 5:33:02 PM  
USER: bhoper

REPORT TYPE: Monthly General Report  
REPORT PERIOD: 4/18/2005  
REPORT START DATE: 4/18/2005  
REPORT END DATE: 4/18/2005  
REPORT START TIME: 5:33:02 PM  
REPORT END TIME: 5:33:02 PM  
REPORT START USER: bhoper  
REPORT END USER: bhoper

Report Summary



DP 8.3

5:48 PM

4-18-05

#1	161	84%
#2	160	67%
#5	155	99%
#6	160	100%
RA	17	99%

DP 2.6

Chang ink



Vegetally Generated

- 10/1/04
- 10/1/04
- 10/1/04
- 10/1/04
- 10/1/04
- 10/1/04
- 10/1/04
- 10/1/04

- 10/1/04
- 10/1/04
- 10/1/04
- 10/1/04
- 10/1/04
- 10/1/04
- 10/1/04
- 10/1/04

SEARCH

Show Report Full

Home	Log Out	Log In	Company Information	Company Information	REPORTS	TRENDS	REPORTS	DATA	TRUCKS	Help
------	---------	--------	---------------------	---------------------	---------	--------	---------	------	--------	------

DP 7.6





Virtual Report

- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT

- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT

REPORT

Show Backgroun

sp 7.7

Verify Generation

- 10/2004
- 11/2004
- 12/2004
- 1/2005
- 2/2005
- 3/2005
- 4/2005
- 5/2005
- 6/2005

- 7/2004
- 8/2004
- 9/2004
- 10/2004
- 11/2004
- 12/2004
- 1/2005
- 2/2005
- 3/2005

1/2005


Show Report Header

Home	Reports	Log	System	Control	Alarms	Trending	Reports	Help	Exit	Help
------	---------	-----	--------	---------	--------	----------	---------	------	------	------

DP 7.5

Monthly Open Year Report

2005  
 2004  
 2003  
 2002  
 2001  
 2000  
 1999  
 1998  
 1997  
 1996  
 1995  
 1994  
 1993  
 1992  
 1991  
 1990  
 1989  
 1988  
 1987  
 1986  
 1985  
 1984  
 1983  
 1982  
 1981  
 1980  
 1979  
 1978  
 1977  
 1976  
 1975  
 1974  
 1973  
 1972  
 1971  
 1970  
 1969  
 1968  
 1967  
 1966  
 1965  
 1964  
 1963  
 1962  
 1961  
 1960  
 1959  
 1958  
 1957  
 1956  
 1955  
 1954  
 1953  
 1952  
 1951  
 1950  
 1949  
 1948  
 1947  
 1946  
 1945  
 1944  
 1943  
 1942  
 1941  
 1940  
 1939  
 1938  
 1937  
 1936  
 1935  
 1934  
 1933  
 1932  
 1931  
 1930  
 1929  
 1928  
 1927  
 1926  
 1925  
 1924  
 1923  
 1922  
 1921  
 1920  
 1919  
 1918  
 1917  
 1916  
 1915  
 1914  
 1913  
 1912  
 1911  
 1910  
 1909  
 1908  
 1907  
 1906  
 1905  
 1904  
 1903  
 1902  
 1901  
 1900  
 1899  
 1898  
 1897  
 1896  
 1895  
 1894  
 1893  
 1892  
 1891  
 1890  
 1889  
 1888  
 1887  
 1886  
 1885  
 1884  
 1883  
 1882  
 1881  
 1880  
 1879  
 1878  
 1877  
 1876  
 1875  
 1874  
 1873  
 1872  
 1871  
 1870  
 1869  
 1868  
 1867  
 1866  
 1865  
 1864  
 1863  
 1862  
 1861  
 1860  
 1859  
 1858  
 1857  
 1856  
 1855  
 1854  
 1853  
 1852  
 1851  
 1850  
 1849  
 1848  
 1847  
 1846  
 1845  
 1844  
 1843  
 1842  
 1841  
 1840  
 1839  
 1838  
 1837  
 1836  
 1835  
 1834  
 1833  
 1832  
 1831  
 1830  
 1829  
 1828  
 1827  
 1826  
 1825  
 1824  
 1823  
 1822  
 1821  
 1820  
 1819  
 1818  
 1817  
 1816  
 1815  
 1814  
 1813  
 1812  
 1811  
 1810  
 1809  
 1808  
 1807  
 1806  
 1805  
 1804  
 1803  
 1802  
 1801  
 1800  
 1799  
 1798  
 1797  
 1796  
 1795  
 1794  
 1793  
 1792  
 1791  
 1790  
 1789  
 1788  
 1787  
 1786  
 1785  
 1784  
 1783  
 1782  
 1781  
 1780  
 1779  
 1778  
 1777  
 1776  
 1775  
 1774  
 1773  
 1772  
 1771  
 1770  
 1769  
 1768  
 1767  
 1766  
 1765  
 1764  
 1763  
 1762  
 1761  
 1760  
 1759  
 1758  
 1757  
 1756  
 1755  
 1754  
 1753  
 1752  
 1751  
 1750  
 1749  
 1748  
 1747  
 1746  
 1745  
 1744  
 1743  
 1742  
 1741  
 1740  
 1739  
 1738  
 1737  
 1736  
 1735  
 1734  
 1733  
 1732  
 1731  
 1730  
 1729  
 1728  
 1727  
 1726  
 1725  
 1724  
 1723  
 1722  
 1721  
 1720  
 1719  
 1718  
 1717  
 1716  
 1715  
 1714  
 1713  
 1712  
 1711  
 1710  
 1709  
 1708  
 1707  
 1706  
 1705  
 1704  
 1703  
 1702  
 1701  
 1700  
 1699  
 1698  
 1697  
 1696  
 1695  
 1694  
 1693  
 1692  
 1691  
 1690  
 1689  
 1688  
 1687  
 1686  
 1685  
 1684  
 1683  
 1682  
 1681  
 1680  
 1679  
 1678  
 1677  
 1676  
 1675  
 1674  
 1673  
 1672  
 1671  
 1670  
 1669  
 1668  
 1667  
 1666  
 1665  
 1664  
 1663  
 1662  
 1661  
 1660  
 1659  
 1658  
 1657  
 1656  
 1655  
 1654  
 1653  
 1652  
 1651  
 1650  
 1649  
 1648  
 1647  
 1646  
 1645  
 1644  
 1643  
 1642  
 1641  
 1640  
 1639  
 1638  
 1637  
 1636  
 1635  
 1634  
 1633  
 1632  
 1631  
 1630  
 1629  
 1628  
 1627  
 1626  
 1625  
 1624  
 1623  
 1622  
 1621  
 1620  
 1619  
 1618  
 1617  
 1616  
 1615  
 1614  
 1613  
 1612  
 1611  
 1610  
 1609  
 1608  
 1607  
 1606  
 1605  
 1604  
 1603  
 1602  
 1601  
 1600  
 1599  
 1598  
 1597  
 1596  
 1595  
 1594  
 1593  
 1592  
 1591  
 1590  
 1589  
 1588  
 1587  
 1586  
 1585  
 1584  
 1583  
 1582  
 1581  
 1580  
 1579  
 1578  
 1577  
 1576  
 1575  
 1574  
 1573  
 1572  
 1571  
 1570  
 1569  
 1568  
 1567  
 1566  
 1565  
 1564  
 1563  
 1562  
 1561  
 1560  
 1559  
 1558  
 1557  
 1556  
 1555  
 1554  
 1553  
 1552  
 1551  
 1550  
 1549  
 1548  
 1547  
 1546  
 1545  
 1544  
 1543  
 1542  
 1541  
 1540  
 1539  
 1538  
 1537  
 1536  
 1535  
 1534  
 1533  
 1532  
 1531  
 1530  
 1529  
 1528  
 1527  
 1526  
 1525  
 1524  
 1523  
 1522  
 1521  
 1520  
 1519  
 1518  
 1517  
 1516  
 1515  
 1514  
 1513  
 1512  
 1511  
 1510  
 1509  
 1508  
 1507  
 1506  
 1505  
 1504  
 1503  
 1502  
 1501  
 1500  
 1499  
 1498  
 1497  
 1496  
 1495  
 1494  
 1493  
 1492  
 1491  
 1490  
 1489  
 1488  
 1487  
 1486  
 1485  
 1484  
 1483  
 1482  
 1481  
 1480  
 1479  
 1478  
 1477  
 1476  
 1475  
 1474  
 1473  
 1472  
 1471  
 1470  
 1469  
 1468  
 1467  
 1466  
 1465  
 1464  
 1463  
 1462  
 1461  
 1460  
 1459  
 1458  
 1457  
 1456  
 1455  
 1454  
 1453  
 1452  
 1451  
 1450  
 1449  
 1448  
 1447  
 1446  
 1445  
 1444  
 1443  
 1442  
 1441  
 1440  
 1439  
 1438  
 1437  
 1436  
 1435  
 1434  
 1433  
 1432  
 1431  
 1430  
 1429  
 1428  
 1427  
 1426  
 1425  
 1424  
 1423  
 1422  
 1421  
 1420  
 1419  
 1418  
 1417  
 1416  
 1415  
 1414  
 1413  
 1412  
 1411  
 1410  
 1409  
 1408  
 1407  
 1406  
 1405  
 1404  
 1403  
 1402  
 1401  
 1400  
 1399  
 1398  
 1397  
 1396  
 1395  
 1394  
 1393  
 1392  
 1391  
 1390  
 1389  
 1388  
 1387  
 1386  
 1385  
 1384  
 1383  
 1382  
 1381  
 1380  
 1379  
 1378  
 1377  
 1376  
 1375  
 1374  
 1373  
 1372  
 1371  
 1370  
 1369  
 1368  
 1367  
 1366  
 1365  
 1364  
 1363  
 1362  
 1361  
 1360  
 1359  
 1358  
 1357  
 1356  
 1355  
 1354  
 1353  
 1352  
 1351  
 1350  
 1349  
 1348  
 1347  
 1346  
 1345  
 1344  
 1343  
 1342  
 1341  
 1340  
 1339  
 1338  
 1337  
 1336  
 1335  
 1334  
 1333  
 1332  
 1331  
 1330  
 1329  
 1328  
 1327  
 1326  
 1325  
 1324  
 1323  
 1322  
 1321  
 1320  
 1319  
 1318  
 1317  
 1316  
 1315  
 1314  
 1313  
 1312  
 1311  
 1310  
 1309  
 1308  
 1307  
 1306  
 1305  
 1304  
 1303  
 1302  
 1301  
 1300  
 1299  
 1298  
 1297  
 1296  
 1295  
 1294  
 1293  
 1292  
 1291  
 1290  
 1289  
 1288  
 1287  
 1286  
 1285  
 1284  
 1283  
 1282  
 1281  
 1280  
 1279  
 1278  
 1277  
 1276  
 1275  
 1274  
 1273  
 1272  
 1271  
 1270  
 1269  
 1268  
 1267  
 1266  
 1265  
 1264  
 1263  
 1262  
 1261  
 1260  
 1259  
 1258  
 1257  
 1256  
 1255  
 1254  
 1253  
 1252  
 1251  
 1250  
 1249  
 1248  
 1247  
 1246  
 1245  
 1244  
 1243  
 1242  
 1241  
 1240  
 1239  
 1238  
 1237  
 1236  
 1235  
 1234  
 1233  
 1232  
 1231  
 1230  
 1229  
 1228  
 1227  
 1226  
 1225  
 1224  
 1223  
 1222  
 1221  
 1220  
 1219  
 1218  
 1217  
 1216  
 1215  
 1214  
 1213  
 1212  
 1211  
 1210  
 1209  
 1208  
 1207  
 1206  
 1205  
 1204  
 1203  
 1202  
 1201  
 1200  
 1199  
 1198  
 1197  
 1196  
 1195  
 1194  
 1193  
 1192  
 1191  
 1190  
 1189  
 1188  
 1187  
 1186  
 1185  
 1184  
 1183  
 1182  
 1181  
 1180  
 1179  
 1178  
 1177  
 1176  
 1175  
 1174  
 1173  
 1172  
 1171  
 1170  
 1169  
 1168  
 1167  
 1166  
 1165  
 1164  
 1163  
 1162  
 1161  
 1160  
 1159  
 1158  
 1157  
 1156  
 1155  
 1154  
 1153  
 1152  
 1151  
 1150  
 1149  
 1148  
 1147  
 1146  
 1145  
 1144  
 1143  
 1142  
 1141  
 1140  
 1139  
 1138  
 1137  
 1136  
 1135  
 1134  
 1133  
 1132  
 1131  
 1130  
 1129  
 1128  
 1127  
 1126  
 1125  
 1124  
 1123  
 1122  
 1121  
 1120  
 1119  
 1118  
 1117  
 1116  
 1115  
 1114  
 1113  
 1112  
 1111  
 1110  
 1109  
 1108  
 1107  
 1106  
 1105  
 1104  
 1103  
 1102  
 1101  
 1100  
 1099  
 1098  
 1097  
 1096  
 1095  
 1094  
 1093  
 1092  
 1091  
 1090  
 1089  
 1088  
 1087  
 1086  
 1085  
 1084  
 1083  
 1082  
 1081  
 1080  
 1079  
 1078  
 1077  
 1076  
 1075  
 1



Auto Discharge  
Function

[Label]


[Label]

[Label]

[Label]

[Label]

[Label]



[Label]	[Label]	[Label]	[Label]	[Label]	[Label]	[Label]	[Label]	[Label]	[Label]	[Label]
---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------

DP 8.0

Printable Report

- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT

- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT

REPORT

Show Report folder

DP 7.5



Mainly 40101 to Report

- 40101
- 40102
- 40103
- 40104
- 40105
- 40106
- 40107
- 40108
- 40109

- 40110
- 40111
- 40112
- 40113
- 40114
- 40115
- 40116
- 40117
- 40118

40119

Show Report Folder

Home	Reports	DP	Compendium	Process	Home	Reports	DP	Compendium	Process	Home	Reports	DP	Compendium	Process
------	---------	----	------------	---------	------	---------	----	------------	---------	------	---------	----	------------	---------

DP 7-9

Annals - generate report

- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT

- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT

REPORT

Show Report Fields

Home	Dashboard	Reports	Configuration	System Overview	Alerts	Transfer	Reports	Help	Logout
------	-----------	---------	---------------	-----------------	--------	----------	---------	------	--------

DP 2-7

Monthly Report - Alarm

04/19/05

04/19/05

04/19/05

04/19/05

04/19/05

04/19/05

04/19/05

04/19/05

04/19/05

04/19/05

04/19/05

04/19/05

04/19/05

04/19/05

04/19/05

04/19/05

04/19/05

Show Alarm Log

Home	Reports	Print	Refresh	Logout	Help	Search	Print	Refresh	Logout	Help	Search
------	---------	-------	---------	--------	------	--------	-------	---------	--------	------	--------

DP-7.6



Printable Report

REPORT  
REPORT  
REPORT  
REPORT  
REPORT  
REPORT  
REPORT  
REPORT  
REPORT

REPORT  
REPORT  
REPORT  
REPORT  
REPORT  
REPORT  
REPORT  
REPORT  
REPORT

REPORT

Show Report Folder

Home	Reports	Print	Compare	Generate	Admin	Training	Reports	Help	Print	Help
------	---------	-------	---------	----------	-------	----------	---------	------	-------	------

OP-7.5



Manually Generated Reports

- 1. 10/12/04
- 2. 10/13/04
- 3. 10/14/04
- 4. 10/15/04
- 5. 10/16/04
- 6. 10/17/04
- 7. 10/18/04
- 8. 10/19/04
- 9. 10/20/04

- 10. 10/21/04
- 11. 10/22/04
- 12. 10/23/04
- 13. 10/24/04
- 14. 10/25/04
- 15. 10/26/04
- 16. 10/27/04
- 17. 10/28/04
- 18. 10/29/04
- 19. 10/30/04
- 20. 10/31/04

10/31/04

Show Report Detail

- Home
- Reports Overview
- Full Overview
- Component Overview
- Component Details
- Alarms
- Trending
- Reports
- Scan
- Help
- Logout

DP- 7.4



Manually Enter to Report

10/2/05

10/2/05

10/2/05

10/2/05

10/2/05

10/2/05

10/2/05

10/2/05

10/2/05

10/2/05

10/2/05

10/2/05

10/2/05

10/2/05

10/2/05

10/2/05

10/2/05

Show Report Data

- Home
- Baghouse Overview
- Process Overview
- Equipment Overview
- Equipment Overview
- Alarm
- Trends
- Events
- Chart
- Table
- Help

DP 7.6



Manually generated reports

REPORT

REPORT

REPORT

REPORT

REPORT

REPORT

REPORT

REPORT

REPORT

REPORT

REPORT

REPORT

REPORT

REPORT

REPORT

REPORT

REPORT

Show Report Folder

Man	Baghouse	1st	2nd	3rd	4th	5th	6th	7th	8th	9th	10th
Man	Baghouse	1st	2nd	3rd	4th	5th	6th	7th	8th	9th	10th

▷ P 6.8

Generally General Reports

10/1/2004

10/1/2004

10/2/2004

10/2/2004

10/3/2004

10/3/2004

10/4/2004

10/4/2004

10/5/2004

10/5/2004

10/6/2004

10/6/2004

10/7/2004

10/7/2004

10/8/2004

10/8/2004

10/9/2004

Show Report folder

- Home
- Dashboard Overview
- Full Overview
- Configuration Overview
- General Overview
- Alarms
- Trends
- Reports
- Help
- Track
- Help

DP 7.1



Manually Generated Report

12/1/04

12/1/04

12/2/04

12/2/04

12/3/04

12/3/04

12/4/04

12/4/04

12/5/04

12/5/04

12/6/04

12/6/04

12/7/04

12/7/04

12/8/04

12/8/04

12/9/04

Stop Report Title

- Home
- Dashboard
- Log On/Off
- Configuration
- Display
- Alarm
- Tramming
- Reports
- Chart
- Track
- Help

ΔP 7.4



Manually Generated Report

1/1/2005  
 2/1/2005  
 3/1/2005  
 4/1/2005  
 5/1/2005  
 6/1/2005  
 7/1/2005  
 8/1/2005  
 9/1/2005  
 10/1/2005  
 11/1/2005  
 12/1/2005

1/1/2005  
 2/1/2005  
 3/1/2005  
 4/1/2005  
 5/1/2005  
 6/1/2005  
 7/1/2005  
 8/1/2005  
 9/1/2005  
 10/1/2005  
 11/1/2005  
 12/1/2005

NO DATA

Show Report Fields

- Home
- Baghouse Overview
- Bag Overview
- Compartment Overview
- Collector Overview
- Alarms
- Trending
- Reports
- Clean
- Tools
- Help

DP 7.0



Monthly General Report

- 1.00000
- 1.00000
- 1.00000
- 1.00000
- 1.00000
- 1.00000
- 1.00000
- 1.00000
- 1.00000
- 1.00000

- 1.00000
- 1.00000
- 1.00000
- 1.00000
- 1.00000
- 1.00000
- 1.00000
- 1.00000
- 1.00000
- 1.00000

1.00000

Show Report Fields

1.00000	1.00000	1.00000	1.00000	1.00000	1.00000	1.00000	1.00000	1.00000	1.00000	1.00000
---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------

DP 7.1





Virtual Generator Report

12/20/04

12/20/04

12/21/04

12/21/04

12/22/04

12/22/04

12/23/04

12/23/04

12/24/04

12/24/04

12/25/04

12/25/04

12/26/04

12/26/04

12/27/04

12/27/04

12/28/04

Show Legend/Filter

- Home
- Baghouse
- PM
- Compartments
- Control
- Alarms
- Training
- Reports
- Help
- Truck
- Run

△G.S



Manually Generate Report

NOX Data

NOX Data

NOX Data

NOX Data

NOX Data

NOX Data

NOX Data

NOX Data

NOX Data

NOX Data

NOX Data

NOX Data

NOX Data

NOX Data

NOX Data

NOX Data

NOX Data

Show Report folder

Home	Baghouse	Plant	Compliance	Process	Quality	Trending	Reports	Graph	Print	Help
------	----------	-------	------------	---------	---------	----------	---------	-------	-------	------

DP 6.4



Manual Baghouse Selection

- 1000000
- 1000001
- 1000002
- 1000003
- 1000004
- 1000005
- 1000006
- 1000007
- 1000008
- 1000009

- 1000010
- 1000011
- 1000012
- 1000013
- 1000014
- 1000015
- 1000016
- 1000017
- 1000018
- 1000019

1000020

Surge Report Filter

△ 67

Vehicle General Report

01/01/05

01/01/05

01/01/05

01/01/05

01/01/05

01/01/05

01/01/05

01/01/05

01/01/05

01/01/05

01/01/05

01/01/05

01/01/05

01/01/05

01/01/05

01/01/05

01/01/05

Show Report Filter

Home	Reports	Log	Configuration	System	Admin	Training	Reports	Chart	Print	Help
------	---------	-----	---------------	--------	-------	----------	---------	-------	-------	------

Δ 6.8





Manually generated reports

2005-04-19

2005-04-19

2005-04-18

2005-04-18

2005-04-17

2005-04-17

2005-04-16

2005-04-16

2005-04-15

2005-04-15

2005-04-14

2005-04-14

2005-04-13

2005-04-13

2005-04-12

2005-04-12

2005-04-11

Show Report folder

- Home
- Control Overview
- PLC Overview
- Production Overview
- Capacity Overview
- Alarms
- Trending
- Reports
- Graph
- Truck
- Help

7.8



Monthly General Report

1000000

1000000

1000000

1000000

1000000

1000000

1000000

1000000

1000000

1000000

1000000

1000000

1000000

1000000

1000000

1000000

1000000

Show Report Folder



Manually generated Report

05/20/04  
 05/21/04  
 05/22/04  
 05/23/04  
 05/24/04  
 05/25/04  
 05/26/04  
 05/27/04  
 05/28/04  
 05/29/04  
 05/30/04  
 05/31/04

05/20/04  
 05/21/04  
 05/22/04  
 05/23/04  
 05/24/04  
 05/25/04  
 05/26/04  
 05/27/04  
 05/28/04  
 05/29/04  
 05/30/04  
 05/31/04

05/31/04

Show Report table

- Home
- Engineer Overview
- Plant Overview
- Online Work Overview
- Energy Overview
- Alarms
- Trending
- Reports
- Chart
- Help

6.8





Randomly Generated Reports

01/01/05

01/01/05

02/01/05

02/01/05

03/01/05

03/01/05

04/01/05

04/01/05

05/01/05

05/01/05

06/01/05

06/01/05

07/01/05

07/01/05

08/01/05

08/01/05

09/01/05

Show Report folder

- Home
- Baghouse Overview
- 24 Hour Overview
- 24 Hour Overview
- 24 Hour Overview
- Alarms
- Trends
- Reports
- Clean
- Tools
- Help

7.7

Printable Report Station

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

Show Report Data

Home	Performance	Plant	Component	General	History	Trending	Report	Alarm	Help
------	-------------	-------	-----------	---------	---------	----------	--------	-------	------

7.7



Manually generate report

11/11/04

11/11/04

11/11/04

11/11/04

11/11/04

11/11/04

11/11/04

11/11/04

11/11/04

11/11/04

11/11/04

11/11/04

11/11/04

11/11/04

11/11/04

11/11/04

11/11/04

Show Report Folder

Home	Reports	Home	Home	Home	Home	Home	Home	Home	Home	Home
------	---------	------	------	------	------	------	------	------	------	------

7.8

Normally/General/General

10/2004

10/2004

11/2004

11/2004

12/2004

12/2004

1/2005

1/2005

2/2005

2/2005

3/2005

3/2005

4/2005

4/2005

5/2005

5/2005

REPORTS

Show Report Folder

7.1



Manually Generated Report

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

Print

Show Report Folder

- Home
- Dashboard
- Reports
- Commitment Overview
- Capacity Overview
- Alerts
- Trending
- Reports
- Chart
- Grid
- Help

7.3



General Information

10/1/05  
10/1/05  
10/1/05  
10/1/05  
10/1/05  
10/1/05  
10/1/05  
10/1/05

10/1/05  
10/1/05  
10/1/05  
10/1/05  
10/1/05  
10/1/05  
10/1/05  
10/1/05

10/1/05

Single Report

Home	Baghouse	General	Connection	General	Alarm	Trending	Reports	Start	Print	Help
------	----------	---------	------------	---------	-------	----------	---------	-------	-------	------

Δ 7.5



View USG Electrical Report

- 11/20/04
- 11/21/04
- 11/22/04
- 11/23/04
- 11/24/04
- 11/25/04
- 11/26/04
- 11/27/04
- 11/28/04

- 11/29/04
- 11/30/04
- 12/01/04
- 12/02/04
- 12/03/04
- 12/04/04
- 12/05/04
- 12/06/04
- 12/07/04

Print

Show Parent Folder

7.9



Print Report

Print

Print

Print

Print

Print

Print

Print

Print

Print

Print

Print

Print

Print

Print

Print

Print

Print

Show All Data

Home	Reports	Print	Control Panel	System	Help	Logout	Print	Print	Print	Print
------	---------	-------	---------------	--------	------	--------	-------	-------	-------	-------

8-1





Printable version of the report

- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT

- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT

REPORT

Show a report of

Home	Dashboard	System	Configuration	Database	Tools	Reports	Admin	Help	Logout
------	-----------	--------	---------------	----------	-------	---------	-------	------	--------

8-4



Print Report

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

1/1/2005

Print

Show Report Table

Home	Reports	Print	Navigation	Help	Admin	Training	Reports	Search	Print	Help
------	---------	-------	------------	------	-------	----------	---------	--------	-------	------

7.6



Print Report

- 12/1/04
- 12/2/04
- 12/3/04
- 12/4/04
- 12/5/04
- 12/6/04
- 12/7/04
- 12/8/04
- 12/9/04

- 12/10/04
- 12/11/04
- 12/12/04
- 12/13/04
- 12/14/04
- 12/15/04
- 12/16/04
- 12/17/04
- 12/18/04

12/19/04

Show Report Data

Menu	Baghouse	Fan	Compartment	Control	Unit	Standby	Reports	Scan	Track	Help
------	----------	-----	-------------	---------	------	---------	---------	------	-------	------

7-9



Monthly Summary Report

2005  
 2004  
 2003  
 2002  
 2001  
 2000  
 1999  
 1998  
 1997  
 1996  
 1995  
 1994  
 1993  
 1992  
 1991  
 1990  
 1989  
 1988  
 1987  
 1986  
 1985  
 1984  
 1983  
 1982  
 1981  
 1980  
 1979  
 1978  
 1977  
 1976  
 1975  
 1974  
 1973  
 1972  
 1971  
 1970  
 1969  
 1968  
 1967  
 1966  
 1965  
 1964  
 1963  
 1962  
 1961  
 1960  
 1959  
 1958  
 1957  
 1956  
 1955  
 1954  
 1953  
 1952  
 1951  
 1950  
 1949  
 1948  
 1947  
 1946  
 1945  
 1944  
 1943  
 1942  
 1941  
 1940  
 1939  
 1938  
 1937  
 1936  
 1935  
 1934  
 1933  
 1932  
 1931  
 1930  
 1929  
 1928  
 1927  
 1926  
 1925  
 1924  
 1923  
 1922  
 1921  
 1920  
 1919  
 1918  
 1917  
 1916  
 1915  
 1914  
 1913  
 1912  
 1911  
 1910  
 1909  
 1908  
 1907  
 1906  
 1905  
 1904  
 1903  
 1902  
 1901  
 1900  
 1899  
 1898  
 1897  
 1896  
 1895  
 1894  
 1893  
 1892  
 1891  
 1890  
 1889  
 1888  
 1887  
 1886  
 1885  
 1884  
 1883  
 1882  
 1881  
 1880  
 1879  
 1878  
 1877  
 1876  
 1875  
 1874  
 1873  
 1872  
 1871  
 1870  
 1869  
 1868  
 1867  
 1866  
 1865  
 1864  
 1863  
 1862  
 1861  
 1860  
 1859  
 1858  
 1857  
 1856  
 1855  
 1854  
 1853  
 1852  
 1851  
 1850  
 1849  
 1848  
 1847  
 1846  
 1845  
 1844  
 1843  
 1842  
 1841  
 1840  
 1839  
 1838  
 1837  
 1836  
 1835  
 1834  
 1833  
 1832  
 1831  
 1830  
 1829  
 1828  
 1827  
 1826  
 1825  
 1824  
 1823  
 1822  
 1821  
 1820  
 1819  
 1818  
 1817  
 1816  
 1815  
 1814  
 1813  
 1812  
 1811  
 1810  
 1809  
 1808  
 1807  
 1806  
 1805  
 1804  
 1803  
 1802  
 1801  
 1800  
 1799  
 1798  
 1797  
 1796  
 1795  
 1794  
 1793  
 1792  
 1791  
 1790  
 1789  
 1788  
 1787  
 1786  
 1785  
 1784  
 1783  
 1782  
 1781  
 1780  
 1779  
 1778  
 1777  
 1776  
 1775  
 1774  
 1773  
 1772  
 1771  
 1770  
 1769  
 1768  
 1767  
 1766  
 1765  
 1764  
 1763  
 1762  
 1761  
 1760  
 1759  
 1758  
 1757  
 1756  
 1755  
 1754  
 1753  
 1752  
 1751  
 1750  
 1749  
 1748  
 1747  
 1746  
 1745  
 1744  
 1743  
 1742  
 1741  
 1740  
 1739  
 1738  
 1737  
 1736  
 1735  
 1734  
 1733  
 1732  
 1731  
 1730  
 1729  
 1728  
 1727  
 1726  
 1725  
 1724  
 1723  
 1722  
 1721  
 1720  
 1719  
 1718  
 1717  
 1716  
 1715  
 1714  
 1713  
 1712  
 1711  
 1710  
 1709  
 1708  
 1707  
 1706  
 1705  
 1704  
 1703  
 1702  
 1701  
 1700  
 1699  
 1698  
 1697  
 1696  
 1695  
 1694  
 1693  
 1692  
 1691  
 1690  
 1689  
 1688  
 1687  
 1686  
 1685  
 1684  
 1683  
 1682  
 1681  
 1680  
 1679  
 1678  
 1677  
 1676  
 1675  
 1674  
 1673  
 1672  
 1671  
 1670  
 1669  
 1668  
 1667  
 1666  
 1665  
 1664  
 1663  
 1662  
 1661  
 1660  
 1659  
 1658  
 1657  
 1656  
 1655  
 1654  
 1653  
 1652  
 1651  
 1650  
 1649  
 1648  
 1647  
 1646  
 1645  
 1644  
 1643  
 1642  
 1641  
 1640  
 1639  
 1638  
 1637  
 1636  
 1635  
 1634  
 1633  
 1632  
 1631  
 1630  
 1629  
 1628  
 1627  
 1626  
 1625  
 1624  
 1623  
 1622  
 1621  
 1620  
 1619  
 1618  
 1617  
 1616  
 1615  
 1614  
 1613  
 1612  
 1611  
 1610  
 1609  
 1608  
 1607  
 1606  
 1605  
 1604  
 1603  
 1602  
 1601  
 1600  
 1599  
 1598  
 1597  
 1596  
 1595  
 1594  
 1593  
 1592  
 1591  
 1590  
 1589  
 1588  
 1587  
 1586  
 1585  
 1584  
 1583  
 1582  
 1581  
 1580  
 1579  
 1578  
 1577  
 1576  
 1575  
 1574  
 1573  
 1572  
 1571  
 1570  
 1569  
 1568  
 1567  
 1566  
 1565  
 1564  
 1563  
 1562  
 1561  
 1560  
 1559  
 1558  
 1557  
 1556  
 1555  
 1554  
 1553  
 1552  
 1551  
 1550  
 1549  
 1548  
 1547  
 1546  
 1545  
 1544  
 1543  
 1542  
 1541  
 1540  
 1539  
 1538  
 1537  
 1536  
 1535  
 1534  
 1533  
 1532  
 1531  
 1530  
 1529  
 1528  
 1527  
 1526  
 1525  
 1524  
 1523  
 1522  
 1521  
 1520  
 1519  
 1518  
 1517  
 1516  
 1515  
 1514  
 1513  
 1512  
 1511  
 1510  
 1509  
 1508  
 1507  
 1506  
 1505  
 1504  
 1503  
 1502  
 1501  
 1500  
 1499  
 1498  
 1497  
 1496  
 1495  
 1494  
 1493  
 1492  
 1491  
 1490  
 1489  
 1488  
 1487  
 1486  
 1485  
 1484  
 1483  
 1482  
 1481  
 1480  
 1479  
 1478  
 1477  
 1476  
 1475  
 1474  
 1473  
 1472  
 1471  
 1470  
 1469  
 1468  
 1467  
 1466  
 1465  
 1464  
 1463  
 1462  
 1461  
 1460  
 1459  
 1458  
 1457  
 1456  
 1455  
 1454  
 1453  
 1452  
 1451  
 1450  
 1449  
 1448  
 1447  
 1446  
 1445  
 1444  
 1443  
 1442  
 1441  
 1440  
 1439  
 1438  
 1437  
 1436  
 1435  
 1434  
 1433  
 1432  
 1431  
 1430  
 1429  
 1428  
 1427  
 1426  
 1425  
 1424  
 1423  
 1422  
 1421  
 1420  
 1419  
 1418  
 1417  
 1416  
 1415  
 1414  
 1413  
 1412  
 1411  
 1410  
 1409  
 1408  
 1407  
 1406  
 1405  
 1404  
 1403  
 1402  
 1401  
 1400  
 1399  
 1398  
 1397  
 1396  
 1395  
 1394  
 1393  
 1392  
 1391  
 1390  
 1389  
 1388  
 1387  
 1386  
 1385  
 1384  
 1383  
 1382  
 1381  
 1380  
 1379  
 1378  
 1377  
 1376  
 1375  
 1374  
 1373  
 1372  
 1371  
 1370  
 1369  
 1368  
 1367  
 1366  
 1365  
 1364  
 1363  
 1362  
 1361  
 1360  
 1359  
 1358  
 1357  
 1356  
 1355  
 1354  
 1353  
 1352  
 1351  
 1350  
 1349  
 1348  
 1347  
 1346  
 1345  
 1344  
 1343  
 1342  
 1341  
 1340  
 1339  
 1338  
 1337  
 1336  
 1335  
 1334  
 1333  
 1332  
 1331  
 1330  
 1329  
 1328  
 1327  
 1326  
 1325  
 1324  
 1323  
 1322  
 1321  
 1320  
 1319  
 1318  
 1317  
 1316  
 1315  
 1314  
 1313  
 1312  
 1311  
 1310  
 1309  
 1308  
 1307  
 1306  
 1305  
 1304  
 1303  
 1302  
 1301  
 1300  
 1299  
 1298  
 1297  
 1296  
 1295  
 1294  
 1293  
 1292  
 1291  
 1290  
 1289  
 1288  
 1287  
 1286  
 1285  
 1284  
 1283  
 1282  
 1281  
 1280  
 1279  
 1278  
 1277  
 1276  
 1275  
 1274  
 1273  
 1272  
 1271  
 1270  
 1269  
 1268  
 1267  
 1266  
 1265  
 1264  
 1263  
 1262  
 1261  
 1260  
 1259  
 1258  
 1257  
 1256  
 1255  
 1254  
 1253  
 1252  
 1251  
 1250  
 1249  
 1248  
 1247  
 1246  
 1245  
 1244  
 1243  
 1242  
 1241  
 1240  
 1239  
 1238  
 1237  
 1236  
 1235  
 1234  
 1233  
 1232  
 1231  
 1230  
 1229  
 1228  
 1227  
 1226  
 1225  
 1224  
 1223  
 1222  
 1221  
 1220  
 1219  
 1218  
 1217  
 1216  
 1215  
 1214  
 1213  
 1212  
 1211  
 1210  
 1209  
 1208  
 1207  
 1206  
 1205  
 1204  
 1203  
 1202  
 1201  
 1200  
 1199  
 1198  
 1197  
 1196  
 1195  
 1194  
 1193  
 1192  
 1191  
 1190  
 1189  
 1188  
 1187  
 1186  
 1185  
 1184  
 1183  
 1182  
 1181  
 1180  
 1179  
 1178  
 1177  
 1176  
 1175  
 1174  
 1173  
 1172  
 1171  
 1170  
 1169  
 1168  
 1167  
 1166  
 1165  
 1164  
 1163  
 1162  
 1161  
 1160  
 1159  
 1158  
 1157  
 1156  
 1155  
 1154  
 1153  
 1152  
 1151  
 1150  
 1149  
 1148  
 1147  
 1146  
 1145  
 1144  
 1143  
 1142  
 1141  
 1140  
 1139  
 1138  
 1137  
 1136  
 1135  
 1134  
 1133  
 1132  
 1131  
 1130  
 1129  
 1128  
 1127  
 1126  
 1125  
 1124  
 1123  
 1122  
 1121  
 1120  
 1119  
 1118  
 1117  
 1116  
 1115  
 1114  
 1113  
 1112  
 1111  
 1110  
 1109  
 1108  
 1107  
 1106  
 1105  
 1104  
 1103  
 1102  
 1101  
 1100  
 1099  
 1098  
 1097  
 1096  
 1095  
 1094  
 1093  
 1092  
 1091  
 1090  
 1089  
 1088  
 1087  
 1086  
 1085  
 1084  
 1083  
 1082  
 1081  
 1080  
 1079  
 1078  
 1077  
 1076  
 1075  
 1074  
 1073  
 1072



Normally generate reports

- 1. 00001
- 1. 00002
- 1. 00003
- 1. 00004
- 1. 00005
- 1. 00006
- 1. 00007
- 1. 00008

- 1. 00009
- 1. 00010
- 1. 00011
- 1. 00012
- 1. 00013
- 1. 00014
- 1. 00015
- 1. 00016

1. 00017

Show Header Header

Home	Back	Print	Refresh	Copy	Paste	Find	Print	Print	Print	Print
------	------	-------	---------	------	-------	------	-------	-------	-------	-------

7.3



Print Job Control Panel

Print Job

Print Job

Print Job

Print Job

Print Job

Print Job

Print Job

Print Job

Print Job

Print Job

Print Job

Print Job

Print Job

Print Job

Print Job

Print Job

Print Job

Show Report Table

Home	Production	Run	Commission	Control	ADMS	Inventory	Reports	Blank	Track	Help
------	------------	-----	------------	---------	------	-----------	---------	-------	-------	------

8.0



Verify status of Report

- 10/1/2004
- 10/2/2004
- 10/3/2004
- 10/4/2004
- 10/5/2004
- 10/6/2004
- 10/7/2004
- 10/8/2004
- 10/9/2004

- 10/10/2004
- 10/11/2004
- 10/12/2004
- 10/13/2004
- 10/14/2004
- 10/15/2004
- 10/16/2004
- 10/17/2004
- 10/18/2004

10/19/2004

Show Report Builder

- Home
- Reports
- Full
- Department
- Company
- Unit
- Trending
- Records
- Cost
- Track
- Help

8-0

Stop Test, South Furnace Down waiting  
on castor turn around



Verbally Generated Report

04/22/2005  
11:30:06 AM  
Nucor Baghouse #1  
Verbally Generated Report  
04/22/2005  
11:30:06 AM  
Nucor Baghouse #1  
Verbally Generated Report

04/22/2005  
11:30:06 AM  
Nucor Baghouse #1  
Verbally Generated Report  
04/22/2005  
11:30:06 AM  
Nucor Baghouse #1  
Verbally Generated Report

04/22/2005

Show Report File

Home	Reports	Print	Configuration	Database	Tools	Logout	Search	Print	Help
------	---------	-------	---------------	----------	-------	--------	--------	-------	------

8.1

SOUTH FURNACE BACK UP and RUNNING  
Re Start TEST





Virtual Gate Alarms

- 12:00:00
- 12:00:00
- 12:00:00
- 12:00:00
- 12:00:00
- 12:00:00
- 12:00:00
- 12:00:00

- 12:00:00
- 12:00:00
- 12:00:00
- 12:00:00
- 12:00:00
- 12:00:00
- 12:00:00
- 12:00:00

12:00:00

Show Alarm Filter

8.6



Manually generated Report

- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT

- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT

REPORT

Show Help Guide

Home	Reports	Log	Configuration	Database	Tools	Admin	Search	Exit	Help	Print
------	---------	-----	---------------	----------	-------	-------	--------	------	------	-------





Manually Generate Report

- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT

- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT
- REPORT

REPORT

Show Report Folder

Home	Reports	My	Computer	Common	Settings	Hardware	Reports	Tools	Index	Help
------	---------	----	----------	--------	----------	----------	---------	-------	-------	------

Normally starts report

1/1/2005

1/1/2005

1/2/2005

1/2/2005

1/3/2005

1/3/2005

1/4/2005

1/4/2005

1/5/2005

1/5/2005

1/6/2005

1/6/2005

1/7/2005

1/7/2005

1/8/2005

1/8/2005

1/9/2005

Show Report folder

Home	Baghouse Overview	1st	2nd	3rd	4th	5th	6th	7th	8th	9th	10th
------	-------------------	-----	-----	-----	-----	-----	-----	-----	-----	-----	------

7-7



General Configuration

- REPORTS
- REPORTS
- REPORTS
- REPORTS
- REPORTS
- REPORTS
- REPORTS
- REPORTS
- REPORTS

- REPORTS
- REPORTS
- REPORTS
- REPORTS
- REPORTS
- REPORTS
- REPORTS
- REPORTS
- REPORTS

REPORTS

Show Report Header

Home	Navigation	System	Department	General	Reports	Trending	Reports	Cost	Time	Help
------	------------	--------	------------	---------	---------	----------	---------	------	------	------



Manually Clean Bag Filter

MANUAL

MANUAL

MANUAL

MANUAL

MANUAL

MANUAL

MANUAL

MANUAL

MANUAL

MANUAL

MANUAL

MANUAL

MANUAL

MANUAL

MANUAL

MANUAL

MANUAL

Show Filter Filter

Home	Equipment Overview	Filter Overview	Compartments Overview	Control Overview	Alarm	Manual	Reports	Clear	Print	Exit
------	--------------------	-----------------	-----------------------	------------------	-------	--------	---------	-------	-------	------

8.1



Monthly General Ledger

- 11/2004
- 12/2004
- 1/2005
- 2/2005
- 3/2005
- 4/2005
- 5/2005
- 6/2005
- 7/2005
- 8/2005
- 9/2005
- 10/2005

- 11/2004
- 12/2004
- 1/2005
- 2/2005
- 3/2005
- 4/2005
- 5/2005
- 6/2005
- 7/2005
- 8/2005
- 9/2005
- 10/2005

GO BACK

Ship Headers

Home	Dashboard	Gen Overview	Component Overview	Category Overview	Alerts	Trending	Reports	Chart	Tools	Help
------	-----------	--------------	--------------------	-------------------	--------	----------	---------	-------	-------	------

7.8





Print Report

- Print
- Print
- Print
- Print
- Print
- Print
- Print
- Print

- Print
- Print
- Print
- Print
- Print
- Print
- Print
- Print

Print

Show Report

5-6

**ATP** - Air Test Professionals, Inc.

1201 North Graham Avenue, Indianapolis, Indiana 4

(317) 345-1720 FAX (317) 351-

---

**REPORT on  
PARTICULATE, METALS AND VOC TESTING**

Performed for:  
**Nucor Steel**  
*Crawfordsville, Indiana*  
**PPFF Baghouse #2**  
on April 18-19, 22, 2005

---

---

**REPORT on  
PARTICULATE, METALS AND VOC TESTING**

Performed for:  
**Nucor Steel**  
*Crawfordsville, Indiana*  
**PPFF Baghouse #2**  
on April 18-19, 22, 2005

---


**RECEIVED**

JUN 06 2005

State of Indiana  
Department of Environmental Management  
Office of Air Quality

To the best of our knowledge, the data presented in this report is accurate and complete.

Respectfully Submitted by:



Carlos Brown, Project Manager

## TABLE OF CONTENTS

---

1.	<b>PROJECT OVERVIEW</b>	
	TEST SUMMARY, Table 1-1	1-1
	PROJECT OVERVIEW	1-2
2.	<b>RESULTS</b>	
	FILTERABLE AND CONDENSIBLE PM, Table 2-1	2-1
	METALS & VOC EMISSIONS, Table 2-2	2-2
	VISIBLE EMISSIONS, Table 2-3	2-3
3.	<b>DESCRIPTION OF INSTALLATION</b>	
	DESCRIPTION OF PROCESS	3-1
4.	<b>METHODOLOGY</b>	
	SUMMARY OF SAMPLING PROCEDURES	4-1
	DESCRIPTION OF REFERENCE METHODS	4-2
5.	<b>APPENDIX</b>	
	SAMPLE CALCULATIONS	A
	FIELD DATA PRINTOUTS	B
	FIELD DATA	C
	LABORATORY DATA	D
	CHAIN OF CUSTODY	E
	CALIBRATION DATA	F
	VISIBLE EMISSIONS DATA	G
	SUBMITTED PROTOCOL	H
	PRODUCTION DATA	I

## 1-1 PROJECT OVERVIEW

Air Test Professionals, Inc. was contracted by Nucor Steel to perform air emissions sampling of their Positive Pressure Fabric Filter (PPFF) Baghouse #2, located in Crawfordsville, Indiana on April 18-19, 22, 2005. The objective of the testing was to determine compliance with 40CFR60, Subpart AAa for Particulate Matter (PM) emissions including Condensable Particulate Matter (CPM), Volatile Organic Compound (VOC) emissions, and Metals emissions. Testing was also performed in accordance with paragraph 48 of the Consent Decree to establish operating baselines as required by NSPS at the Electric Arc Furnace. The following personnel were involved with the testing program:

ATP	Carlos Brown
ATP	Andrew Young
ATP	Ron Stapert
Nucor	Mark Washer
Nucor	Rex Kelsey
IDEM	Steve Friend

The testing program included flow and gas analysis (US EPA Methods 1-4), particulate (US EPA Method 5), condensable particulate matter (US EPA Method 202), volatile organic compound emissions (US EPA Method 25A), and metals emissions (US EPA Method 29). Listed below is a summary of the results.

### Test Summary

Table 1-1

Pollutant	Location	Emissions Rate (Avgs.) (lbs/hr)	Permitted Limits (lbs/hr)
Lead	PPFF Baghouse #2	0.002	0.134 (Pb)
Mercury		< 0.016	0.023 (Hg)

Pollutant	Location	PM (TSP) Filterable	PM/PM10 Filterable & Condensible
Particulate Matter	PPFF Baghouse #2	0.0003 (gr/dscf)	0.0007 (gr/dscf)

<b>Permitted PM Limits</b>	0.0018 (gr/dscf)	0.0052 (gr/dscf)
----------------------------	------------------	------------------

Pollutant	Location	VOC Emissions	Permitted Limit
Volatile Organic Compounds	PPFF Baghouse #2	0.027 (lbs/ton)	0.09 (lbs/ton)

**1-2 PROJECT OVERVIEW**

**Test Program**

<b>Parameter</b>	<b>Methods</b>	<b>Location</b>	<b>Unit</b>
Gas Velocity / Vol. Flow Rate	EPA RM 1-3	Stack Outlet	Baghouse #2
Particulate (PM)	EPA RM 4-5	Stack Outlet	Baghouse #2
Condensibles (CPM)	EPA RM 202	Stack Outlet	Baghouse #2
Metals	EPA RM 29	Stack Outlet	Baghouse #2
Opacity	EPA RM 9	Stack Outlet	Baghouse #2
Opacity	EPA RM 9	Roof Monitors	*Melt Shop

\*NOTE: Visible emissions data sheets for Melt Shop tests are included with Baghouse #1 Test Report.

The schedule of activities is summarized below:

**Schedule of Activities**

<b>Date</b>	<b>Run No.</b>	<b>Time</b>
<b>PM Tests</b>		
04/18/2005	1	12:48 – 19:36
04/19/2005	2	08:20 – 16:08
04/22/2005	3	08:33 – 14:14
<b>Metals &amp; VOC Tests</b>		
04/18/2005	1	12:48 – 15:35
04/18/2005	2	16:58 – 19:26
<b>Metals Test</b>		
04/19/2005	3	08:20 – 13:30
<b>VOC Test</b>		
04/19/2005	3	08:20 - 09:52

**2-1 RESULTS**

---

**FILTERABLE AND CONDENSIBLE PM**  
*PPFF Baghouse*

Table 2-1

<b><u>Gas Conditions</u></b>		<b>1</b>	<b>2</b>	<b>3</b>	<b>Avg</b>
Ts	Stack Temperature	171.8	156.6	149.0	159.1
Bwo	Moisture (volume %)	2.23	2.15	1.93	2.10
O2	Oxygen (dry volume %)	20.0	20.0	20.0	20.0
CO2	Carbon Dioxide (dry volume %)	0.0	0.0	0.0	0.0
<b><u>Volumetric Flow Rate</u></b>					
Qa	Actual Conditions (acfm)	938,461	949,128	920,303	935,964
Qstd	Standard Conditions (dscfm)	772,653	801,267	781,114	785,012
<b><u>Emissions Results</u></b>					
C <sub>TSP</sub>	Concentration, filterable (gr/dscf)	0.0002	0.0003	0.0004	<b>0.0003</b>
C	Concentration, filterable & condensible (gr/dscf)	0.0006	0.0008	0.0007	<b>0.0007</b>
<b><u>Fan Amps / Damper Positions</u></b>					
	Average Fan Amps	159.8	159.6	159.6	<b>159.7</b>
	Average Damper Position	61 %	53 %	57 %	<b>57 %</b>

---

**2-2 RESULTS**

**METALS AND VOC EMISSIONS**  
*PPFF Baghouse*

Table 2-1

<b><u>Gas Conditions</u></b>		<b>1</b>	<b>2</b>	<b>3</b>	<b>Avg</b>
Ts	Stack Temperature	171.7	166.4	156.4	164.8
Bwo	Moisture (volume %)	1.33	1.56	1.47	1.45
O2	Oxygen (dry volume %)	20.0	20.0	20.0	20.0
CO2	Carbon Dioxide (dry volume %)	0.0	0.0	0.0	0.0
<b><u>Volumetric Flow Rate</u></b>					
Qa	Actual Conditions (acfm)	1,038,852	968,442	973,619	993,638
Qstd	Standard Conditions (dscfm)	863,243	809,770	820,262	831,092
<b><u>Emissions Results</u></b>					
Lead	Emission Rate (lbs/hr)	0.002	0.003	0.003	<b>0.002</b>
Mercury	Emission Rate (lbs/hr)	0.015	0.017	0.016	<b>0.016</b>
VOC	Emission Rate (lbs/ton)	0.027	0.023	0.031	<b>0.027</b>



**2-3 RESULTS**

---

**VISIBLE EMISSIONS - OPACITY**

*PPFF Baghouse #2*  
Table 2-1


<b>Run No.</b>	<b>1</b>	<b>2</b>	<b>3</b>	<b>Average</b>
<b>Date</b>	April 18, 2005	April 19, 2005	April 22, 2005	
<b>Start Time (approx)</b>	12:47	08:20	09:00	
<b>Stop Time (approx)</b>	16:45	15:15	13:00	
<b>Visible Emissions</b>				
Opacity (EPA RM 9)	0.0	0.0	0.0	<b>0.0 %</b>

### 3-1 PROCESS DESCRIPTION

Nucor Steel operates a meltshop which is comprised of the following process units: Two (2) EAF units, one ladle metallurgy station, one (1) Argon-Oxygen Decarburization (AOD) furnace and two (2) continuous thin slab casters. All of these emission units are evacuated through two (2) positive-pressure filter fabric baghouses.

The EAF units melt various grades of scrap metal, scrap substitutes, lime and coke into molten steel. The molten steel is refined into various grades of steel at the ladle metallurgy station or refined into stainless steel at the AOD. The molten steel from the ladle metallurgy station or AOD is cast into continuous thin slabs at the two continuous casters.

The emissions from the EAF units, AOD, and casters are generated from melting, refining, charging, tapping, and casting operations and are captured in direct shell evacuation systems (DES or 4<sup>th</sup> hole) and overhead canopy hoods. Prior to 2005, all captured emissions were evacuated through Baghouse #1. In 2005, Nucor commissioned Baghouse #2. The arrangement of the baghouses is such that the all captured emissions from the 4<sup>th</sup> hole duct of the South furnace are evacuated through Baghouse #2 and all captured emissions from the 4<sup>th</sup> hole duct of the North furnace are evacuated through Baghouse #1. Emissions from the overhead scavenger hoods may split between both baghouses. Please refer to the schematic below.



## 4-1 METHODOLOGY

---

The sampling procedures utilized by Air Test Professionals, Inc. were as follows:

Title 40 CFR Part 60 Appendix A

Method 1	"Sampling of Velocity Traverses for Stationary Sources"
Method 2	"Determining of Stack Gas Velocity and Volumetric Flow Rate"
Method 3	"Gas Analysis for the Determination of Molecular Weight"
Method 4	"Determination of Moisture Content in Stack Gas"
Method 5	"Determination of Particulate Emissions from Stationary Sources"
Method 25A	"Determination of Volatile Organic Compounds from Stationary Sources"
Method 29	"Determination of Metals Emissions from Stationary Sources"

Title 40 CFR Part 51 Appendix M

Method 202	"Determination of Condensable Particulate Emissions from Stationary Sources"
------------	--

---

## SAMPLE POINT DETERMINATION

Sampling point locations were determined according to EPA Reference Method 1.

**Sampling Points**  
Table 4-1

<b>Location</b>	<b>Dimensions</b>	<b>Points / port</b>	<b>Total Points</b>
Baghouse	25' x 25' ID	5	25

---

## 4-2 METHODOLOGY

---

### VELOCITY AND VOLUMETRIC FLOW RATE – EPA METHOD 2

EPA Method 2 was used to determine the gas velocity and flow rate at the stack. Figure 4-2 includes the components of the EPA Method 2 sampling apparatus. Each set of velocity determinations included the measurement of gas velocity pressure and gas temperature at each of the Method 1 determined traverse points. The velocity pressures were measured with a Type S pitot tube. Gas temperature measurements were made with a Type K thermocouple and digital pyrometer.

### GAS COMPOSITION AND MOLECULAR WEIGHT – EPA METHOD 3

In order to determine the oxygen and carbon dioxide concentrations, a sample of gas was obtained and analyzed in accordance with EPA Method 3. The gas sample was collected using a Fyrite analyzer. The results were used to determine gas molecular weight.

### MOISTURE CONTENT – EPA METHOD 4

The flue gas moisture content at the testing locations was determined in accordance with EPA Method 4. The gas moisture was determined by quantitatively condensing moisture in the chilled impingers and silica absorption. The amount of moisture condensed was determined gravimetrically. A dry gas meter was used to measure the volume of gas sampled. Moisture content is used to determine stack gas velocity.

### PARTICULATE/CONDENSIBLE DETERMINATION – EPA METHOD 5/202

Stack gas is withdrawn isokinetically and particulate matter is collected on the nozzle and filter. Condensible particulate is captured in the first three impingers; each impinger contains 100 mls of deionized water. A fourth and final impinger contains an amount of approximately 200 grams of silica gel. The impinger temperature exit gas is maintained at or below 68 degrees Fahrenheit.

The nozzle and glass filter holder are rinsed with acetone and captured in a sealed glass container. The impingers and connecting glassware are rinsed twice with deionized water and captured in a sealed container. Two rinses of methylene chloride were captured and stored in a sealed container.

### DETERMINATION OF METALS EMISSIONS – EPA METHOD 29

Stack gas is withdrawn isokinetically and particulate matter is collected on the nozzle and filter. Gaseous emissions are collected in an absorbing solution of HNO<sub>3</sub>/H<sub>2</sub>O<sub>2</sub> (0.1 N Nitric Acid & Hydrogen Peroxide) in the 2<sup>nd</sup> and 3<sup>rd</sup> impingers and then in an aqueous acidic solution of KmnO<sub>4</sub> (Potassium Permanganate) in the 5<sup>th</sup> and 6<sup>th</sup> impingers (analyzed for Hg). The 1<sup>st</sup> and 4<sup>th</sup> impingers are empty and the 7<sup>th</sup> impinger contains approximately 200 grams of silica gel. Impinger exit gas temperature is maintained at or below 68 degrees F.

The nozzle and filter holder are rinsed with 100 ml of 0.1 N HNO<sub>3</sub> and cleaned with a Teflon brush and collected in a jar. Impingers 1, 2 and 3 are measured for moisture pick-up and then collected in a jar before rinsing the impingers with 100 ml 0.1 N HNO<sub>3</sub>, along with the back-half of the glass filter holder. Absorbing solutions are combined along with the rinse solution. Impinger 4 is measured for moisture pick-up (individually), collected and then rinsed with 100 ml 0.1 N HNO<sub>3</sub> which is combined with the moisture pick-up. Impingers 5 and 6 are measured for moisture pick-up, collected in an amber jar with Teflon lid liner and rinsed with 100 ml of KMnO<sub>4</sub> and followed by a 100 ml rinse of HPLC water which is combined with the absorbing solution. Impingers 5 and 6 are then rinsed with 25 ml of 8 N HCl and collected in a jar. Silica gel is also weighed for moisture pick-up.

## **4-2 METHODOLOGY, cont.**

---


### **VISIBLE EMISSIONS – EPA METHOD 9**

Stack opacity readings were taken at 15-second intervals, for 30-minutes per each 60-minutes tested by a certified visible emissions reader. The visible emissions readings were conducted during each of the particulate test runs. The results are reported as an average emissions percentage for each test period. Copies of the visible emissions certification cards are included in Appendix G.

### **VOC DETERMINATION – EPA METHOD 25A**

Flue gas is drawn into a flame ionization analyzer (FIA) that determines organic concentrations and generates an output proportional to the gas concentration. The sample line is heated to 250 degrees F to prevent the development of condensation in the sampling apparatus. Gases used for, either calibrations, fuel, or combustion air, are contained in compressed gas cylinders and are prepared according to the procedure in EPA Protocol No. 1. Calibration gases consist of Zero Gas with less than 0.1 ppmv, Low-level gas at 25 to 35 percent of span, Mid-level gas at 45 to 55 percent of span and High-level gas at 80 to 90 percent of span. Pre-test instrument calibration checks and post-test drift checks are conducted during the test period to validate sampling accuracy. All calibrations and sample measurements are collected and compiled utilizing an electric data-recording device. The sample average is determined by the integration of the output recorded over the period specified in the applicable regulation.

This method is applicable for the measurement of aromatic hydrocarbons and is expressed in terms of propane or in terms of carbon.



## SAMPLE CALCULATIONS

---

### 1. Volume of water collected (wstd)

$$V_{wstd} = (0.04707)(V_{lc})$$

$V_{wstd}$	volume of water collected at standard conditions (ft <sup>3</sup> )
$V_{lc}$	total volume of liquid collected in impingers and silica (ml)
0.04707	conversion factor (ft <sup>3</sup> /ml)

### 2. Volume of gas metered at standard conditions (dscf)

$$V_{mstd} = \frac{(17.64)(V_m) \left( P_{baro} + \frac{\Delta H}{13.6} \right) (\Gamma_d)}{(460 + T_m)}$$

$V_{mstd}$	volume of sample gas through dry gas meter at standard conditions (ft <sup>3</sup> )
$V_m$	volume of sample gas through dry gas meter at meter conditions (ft <sup>3</sup> )
$P_{baro}$	barometric pressure (in Hg)
$\Delta H$	average pressure drop across meter box orifice (in H <sub>2</sub> O)
$\Gamma_d$	gas meter correction factor (dimensionless)
$T_m$	average dry gas meter temperature (°F)
17.64	conversion factor (°R/in Hg)
13.6	conversion factor (in H <sub>2</sub> O/in Hg)
460	conversion constant, °F to °R

### 3. Sample gas pressure (in Hg)

$$P_s = P_{baro} + \left( \frac{P_g}{13.6} \right)$$

$P_s$	absolute sample gas pressure (in Hg)
$P_{baro}$	barometric pressure (in Hg)
$P_g$	sample gas static pressure (in H <sub>2</sub> O)
13.6	conversion factor (in H <sub>2</sub> O/in Hg)

### 4. Actual vapor pressure (in Hg)

$$P_v = P_s$$

$P_v$	vapor pressure, actual (in Hg)
$P_s$	absolute sample gas pressure (in Hg)

5. Moisture content (%)

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

$B_{wo}$	portion of water vapor in the gas stream by volume (%)
$V_{wstd}$	volume of water collected at standard conditions (ft <sup>3</sup> )
$V_{mstd}$	volume of sample gas through dry gas meter at standard conditions (ft <sup>3</sup> )

6. Saturated moisture content (%)

$$B_{ws} = \frac{P_v}{P_s}$$

$B_{ws}$	portion of water vapor in gas stream by volume at saturated conditions (%)
$P_v$	vapor pressure, actual (in Hg)
$P_s$	absolute sample gas pressure (in Hg)

7. Molecular weight of dry gas stream (lb/lb-mole)

$$M_d = M_{CO_2} \left( \frac{CO_2}{100} \right) + M_{O_2} \left( \frac{O_2}{100} \right) + M_{CO+N_2} \left( \frac{CO+N_2}{100} \right)$$

$M_d$	dry molecular weight of sample gas (lb/lb-mole)
$M_{CO_2}$	molecular weight of carbon dioxide (lb/lb-mole)
$M_{O_2}$	molecular weight of oxygen (lb/lb-mole)
$M_{CO+N_2}$	molecular weight of carbon monoxide and nitrogen (lb/lb-mole)
$CO_2$	portion of carbon dioxide in the gas stream by volume (%)
$O_2$	portion of oxygen in the gas stream by volume (%)
$CO+N_2$	portion of carbon monoxide and nitrogen in gas stream by volume (%)
100	conversion factor (%)

8. Molecular weight of sample gas (lb/lb-mole)

$$M_s = (M_d)(1 - B_{ws}) + (M_{H_2O})(B_{wo})$$

$M_d$	dry molecular weight of sample gas (lb/lb-mole)
$B_{wo}$	portion of water vapor in the gas stream by volume (%)
$M_{H_2O}$	molecular weight of water (lb/lb-mole)
$M_s$	molecular weight of sample gas, wet basis (lb/lb-mole)



9. Velocity of sample gas (ft/sec)

$$V_s = (K_p)(C_p)(\sqrt{\Delta P}) \left( \sqrt{\frac{(t_s + 460)}{(M_s)(P_s)}} \right)$$

$V_s$	average sample gas velocity (ft/sec)
$K_p$	velocity pressure coefficient (dimensionless)
$C_p$	pitot tube constant
$\Delta P$	average differential pressure in the gas stream (in H <sub>2</sub> O)
$t_s$	average sample gas temperature (°F)
$M_s$	molecular weight of sample gas, wet basis (lb/lb-mole)
$P_s$	absolute sample gas pressure (in Hg)
460	conversion constant, °F to °R

10. Total flow of sample gas (acfm)

$$Q_a = (60)(A_s)(V_s)$$

$Q_a$	volumetric flow rate at actual conditions (acfm)
$A_s$	cross-sectional area of sampling location (ft <sup>2</sup> )
$V_s$	average sample gas velocity (ft/sec)
60	conversion factor (seconds/minute)

11. Total flow of sample gas (dscfm)

$$Q_{std} = \frac{(Q_a)(P_s)(17.64)(1 - B_{wo})}{(t_s + 460)}$$

$Q_{std}$	volumetric flow rate at standard conditions (dscfm)
$Q_a$	volumetric flow rate at actual conditions (acfm)
$P_s$	absolute sample gas pressure (in Hg)
$B_{wo}$	portion of water vapor in the gas stream by volume (%)
$t_s$	average sample gas temperature (°F)
17.64	conversion factor (°R/in Hg)
460	conversion constant, °F to °R

12. Percent isokinetic (%)

$$I = \frac{(0.09450)(T_s)(V_{mstd})}{(P_s)(V_s) \left( \frac{(D_n)^2(\pi)}{(144)(4)} \right) (\theta)(1 - B_{wo})}$$

I	percent relative to isokinetic sampling (%)
T <sub>s</sub>	absolute sample gas temperature (°R)
V <sub>mstd</sub>	volume of sample gas through dry gas meter at standard conditions (ft <sup>3</sup> )
P <sub>s</sub>	absolute sample gas pressure (in Hg)
V <sub>s</sub>	average sample gas velocity (ft/sec)
D <sub>n</sub>	diameter of nozzle (inches)
B <sub>wo</sub>	portion of water vapor in the gas stream by volume (%)
θ	total sample time (minutes)
0.09450	conversion constant

13. Particulate concentration (gr/dscf)

$$C_{gr/dscf} = \frac{(15.43)(M_n)}{V_{mstd}}$$

C <sub>gr/dscf</sub>	measured concentration in gas stream (gr/dscf)
M <sub>n</sub>	particulate collected, corrected for reagent blank (grams)
V <sub>mstd</sub>	volume of sample gas through dry gas meter at standard conditions (ft <sup>3</sup> )
15.43	conversion factor (grains/gram)

14. Particulate emissions, mass emission rate (lbs/hr)

$$E_{lb/hr} = \frac{(M_n)(Q_{std})}{(7.567)(V_{mstd})}$$

E <sub>lbs/hr</sub>	mass emission rate (lbs/hr)
M <sub>n</sub>	particulate collected, corrected for reagent blank (grams)
Q <sub>std</sub>	volumetric flow rate at standard conditions (dscfm)
V <sub>mstd</sub>	volume of sample gas through dry gas meter at standard conditions (ft <sup>3</sup> )
7.567	conversion factor (grams/pound)

15. Gas emission concentration (ppm)

$$C_{gas} = (\bar{C} - C_o) \frac{C_{ma}}{C_m - C_o}$$

$C_{gas}$	effluent gas concentration (ppm)
$\bar{C}$	average gas concentration indicated by gas analyzer (ppm)
$C_o$	average of initial and final system bias checks for zero gas (ppm)
$C_{ma}$	actual concentration of the upscale gas (ppm)
$C_m$	average of initial and final system bias check for upscale cal gas (ppm)

16. VOC emissions, mass emission rate (lbs/hr)


$$VOC_{lb/hr} = \frac{(PPM)(Q_{std})(60)(12)}{(385)(10^6)}$$

$VOC_{lb/hr}$	mass emission rate (lbs/hr)
PPM	pollutant concentration dry as carbon
$Q_{std}$	volumetric flow rate at standard conditions (dscfm)
60	per minute to per hour conversion
12	molecular weight factor
$385 \times 10^6$	ppm to dry standard cubic feet conversion factor

17. Pollutant emission rate (lbs/ton)

$$E_{lbs/ton} = \frac{(E)}{(P_{tons/hr})}$$

$E_{lbs/ton}$	emission rate (lbs/ton)
E	pollutant emission rate (lbs/hr)
$P_{tons/hr}$	facility production rate (tons/hr)



## STACK EMISSION SUMMARY

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	PPFF Baghouse #2 - PM/PM10
Date:	04/18/05 - 04/22/05

	Run 1	Run 2	Run 3	Average
<b>Particulate Concentration</b>				
Filterable (gr/dscf)	0.0002	0.0003	0.0004	<b>0.0003</b>
Filterable & Condensable (gr/dscf)	0.0006	0.0008	0.0007	<b>0.0007</b>
Filterable & Condensable (lb/hr)	3.7072	5.6825	4.4709	4.6202
<b>Avg. Stack Vol. Flow Rate</b>				
ACFM	938,461	949,128	920,303	935,964
DSCFM	772,653	801,267	781,114	785,012
Avg. Stack Temp	171.8	156.6	149.0	159.1
Stack Gas Velocity	25.03	25.31	24.54	24.96
Avg. Velocity Head	0.166	0.173	0.164	0.168
Avg. Sq. Rt of Delta P	0.407	0.417	0.405	0.409
<b>ISOKINETIC TESTING SUMMARY</b>				
Allowable isokinetic 90-110%	98.15	97.73	99.38	98.42
% Moisture of Stack Gas	2.23%	2.15%	1.93%	2.10%
Sample Volume	261.902	270.448	268.074	266.808

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	PPFF Baghouse #2 - PM/PM10
Date:	04/18/2005
Run Number:	1

**FIELD DATA**

K' Factor	16.5
-----------	------

Start Time	12:48
Stop Time	19:36

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 20  
 Md (g/mol) = 28.8

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vw (mL) = 127.2  
 Vw (scf) = 5.98730

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 93.6  
 Vm (ft<sup>3</sup>) = 273.333  
 Pb (in Hg) = 30.15  
 delta H (in H2O) = 2.917  
 gamma = 0.99  
 Vm (dscf) = 261.90

Moisture Content of Stack Gas, Bwo  
 Bwo = 2.23%  
 1-Bwo = 97.77%

Molecular Weight of Stack Gas, Ms  
 Ms (g/mol) = 28.56

Area of Stack (enter diameter in inches), As  
 Depth = 300  
 Width = 300  
 diameter (in) = 0  
 No. of Stacks = 1  
 As(L\*W) (ft<sup>2</sup>) = 625.0  
 As(dia.) (ft<sup>2</sup>) = 625.0

Absolute Pressure, Ps  
 Static (in H2O) = -0.02  
 Ps (in Hg) = 30.15

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sqr(delta p) = 0.407  
 Ts (F) = 171.8  
 Vs (fps) = 25.03

Stack Gas Flowrate, Qs  
 As (ft<sup>2</sup>) = 625.00  
 Qs (acfm) = 938.461

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscf/m) = 772.653  
 Qstd (dscf/hr) = 46,359.180

Velocity at the Nozzle, Vn Area of Nozzle, An  
 Dia. of Nozzle (in) = 0.371 An (ft<sup>2</sup>) = 0.0007507  
 Time of Run (min) = 287.50  
 Vn (fps) = 24.56

% Isokinetic, %I  
 %I = 98.15  
 % Isokinetic measured from intermediate values  
 %I = 98.15

Pollutant Mass Emission Rate, PMR  
 Mn (g) 0.0038 0.0057  
 PMR (lbs/hr) 1.48 2.22 3.71  
 Filterable Condensible Total

Grains per acf  
 gr/acf = 0.0002 0.0003 0.0005

Grains per dscf  
 gr/dscf = 0.0002 0.0003 0.0006

	Delta P	Squ Δ P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	0.11	0.332		1.82	176	98	98
2	0.12	0.346		1.98	184	94	95
3	0.14	0.374		2.31	177	95	94
4	0.11	0.332		1.82	171	95	94
5	0.09	0.300		1.49	179	92	91
6	0.09	0.300		1.49	176	94	91
7	0.11	0.332		1.82	164	92	91
8	0.08	0.283		1.32	158	94	92
9	0.05	0.224		0.83	165	92	92
10	0.14	0.374		2.31	180	92	92
11	0.08	0.283		1.32	171	92	90
12	0.08	0.283		1.32	171	94	91
13	0.20	0.447		3.30	181	94	92
14	0.15	0.387		2.48	180	96	93
15	0.10	0.316		1.65	170	96	94
16	0.28	0.510		4.29	183	92	91
17	0.26	0.510		4.29	176	94	92
18	0.24	0.490		3.96	182	94	92
19	0.29	0.539		4.79	157	94	92
20	0.27	0.520		4.46	167	94	92
21	0.26	0.510		4.29	176	96	93
22	0.28	0.529		4.62	165	96	94
23	0.28	0.529	1117.533	4.62	166	96	95
24	0.30	0.548	844.2	4.95	172	97	95
25	0.33	0.574		5.45	167	96	95

	Squ Δ P	Volume	Delta H	Stack T	Meter Temp
0.177	0.407	273.333	2.917	171.8	93.6

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	PPFF Baghouse #2 - PM/PM10
Date:	04/19/05
Run Number:	2

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 20  
 Md (g/gmol) = 28.8

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vlc (mL) = 126  
 Vw (scf) = 5.93082

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 87.2  
 Vm (ft<sup>3</sup>) = 278.874  
 Pb (in Hg) = 30.15  
 delta H (in H2O) = 3.073  
 gamma = 0.99  
 Vm (dscf) = 270.45

Moisture Content of Stack Gas, Bwo  
 Bwo = 2.15%  
 1-Bwo = 97.85%

Molecular Weight of Stack Gas, Ms  
 Ms (g/gmol) = 28.57

Area of Stack (enter diameter in inches), As  
 L = 300  
 W = 300  
 diameter (in) = 0  
 No. of Stacks = 1  
 As(L\*W) (ft<sup>2</sup>) = 625.0  
 As(dia.) (ft<sup>2</sup>) = 625.0

Absolute Pressure, Ps  
 Static (in H2O) = -0.05  
 Ps (in Hg) = 30.15

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sqrt(delta p) = 0.417  
 Ts (F) = 156.6  
 Vs (fps) = 25.31

Stack Gas Flowrate, Qs  
 As (ft<sup>2</sup>) = 625.00  
 Qs (acfm) = 949,128

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscf/m) = 801,267  
 Qstd (dscf/hr) = 48,076,037

Velocity at the Nozzle, Vn Area of Nozzle, An  
 Dia. of Nozzle (in) = 0.371 An (ft<sup>2</sup>) = 0.0007507  
 Time of Run (min) = 287.5  
 Vn (fps) = 24.74

% Isokinetic, %I  
 %I = 97.73  
 % Isokinetic measured from intermediate values  
 %I = 97.74

Pollutant Mass Emission Rate, PMR  
 Mn (g) 0.0051 0.0094  
 PMR (lbs/hr) 1.9987 3.68 5.68  
 Filterable Condensable Total

Grains per acf  
 gr/acf = 0.0002 0.0005 0.0007

Grains per dscf  
 gr/dscf = 0.0003 0.0005 0.0008

FIELD DATA

K' Factor 16.7

Start Time 8:20  
 Stop Time 16:08

	Delta P	Squ Δ P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	0.21	0.458		3.51	144	87	86
2	0.28	0.529		4.68	156	87	86
3	0.33	0.574		5.51	163	87	86
4	0.16	0.400		2.67	154	89	88
5	0.26	0.510		4.34	164	92	90
6	0.30	0.548		5.01	168	96	93
7	0.20	0.447		3.34	163	99	96
8	0.27	0.520		4.51	155	100	98
9	0.25	0.500		4.18	148	83	82
10	0.17	0.412		2.84	161	84	84
11	0.23	0.480		3.84	136	87	84
12	0.27	0.520		4.51	151	87	84
13	0.19	0.436		3.17	160	87	85
14	0.28	0.529		4.68	157	88	86
15	0.27	0.520		4.51	142	87	86
16	0.14	0.374		2.34	133	84	84
17	0.13	0.361		2.17	152	86	84
18	0.09	0.300		1.50	162	85	84
19	0.08	0.283		1.34	152	86	85
20	0.08	0.283		1.34	163	87	85
21	0.08	0.283		1.34	164	87	85
22	0.08	0.283		1.34	163	86	86
23	0.07	0.265	398.785	1.17	159	86	85
24	0.09	0.300	119.911	1.50	169	86	85
25	0.09	0.300		1.50	177	86	85

	Squ Δ P	Volume	Delta H	Stack T	Meter Temp
0.184	0.417	278.874	3.073	158.6	87.2





## STACK EMISSION SUMMARY

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	PPFF Baghouse #2 - Metals/VOC
Date:	4/18/05 - 4/19/05

	Run 1	Run 2	Run 3	Average
<b>Pollutant Concentration</b>				
Lead (lbs/hr)	0.002	0.003	0.003	<b>0.002</b>
Mercury (lbs/hr)	0.015	0.017	0.016	<b>0.016</b>
VOC (lbs/hr)	9.40	8.50	11.64	<b>9.84</b>
VOC (lbs/ton)	0.027	0.023	0.031	<b>0.027</b>
<b>Avg. Stack Vol. Flow Rate</b>				
ACFM	1,038,852	968,442	973,619	993,638
DSCFM	863,243	809,770	820,262	831,092
Avg. Stack Temp	171.7	166.4	156.4	164.8
Stack Gas Velocity	27.70	25.83	25.96	26.50
Avg. Velocity Head	0.204	0.178	0.181	0.188
Avg. Sq. Rt of Delta P	0.451	0.422	0.426	0.433
<b>ISOKINETIC TESTING SUMMARY</b>				
Allowable isokinetic 90-110%	98.04	95.42	94.61	96.02
% Moisture of Stack Gas	1.33%	1.56%	1.47%	1.45%
Sample Volume	90.159	82.319	82.673	85.050

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	PPFF Baghouse #2 - Metals/VOC
Date:	04/18/2005
Run Number:	1

**FIELD DATA**

K' Factor	8.2
-----------	-----

Start Time	12:48
Stop Time	15:35

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 20  
 Md (g/gmol) = 28.8

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vlc (mL) = 25.9  
 Vw (scf) = 1.21911

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 93.1  
 Vm (ft<sup>3</sup>) = 94.265  
 Pb (in Hg) = 30.15  
 delta H (in H2O) = 1.768  
 gamma = 0.99  
 Vm (dscf) = 90.16

Moisture Content of Stack Gas, Bwo  
 Bwo = 1.33%  
 1-Bwo = 98.67%

Molecular Weight of Stack Gas, Ms  
 Ms (g/gmol) = 28.66

Area of Stack (enter diameter in inches), As  
 Depth = 300  
 Width = 300  
 diameter (in) = 0  
 No. of Stacks = 1  
 As(L\*W) (ft<sup>2</sup>) = 625.0  
 As(dia.) (ft<sup>2</sup>) = 625.0

Absolute Pressure, Ps  
 Static (in H2O) = -0.02  
 Ps (in Hg) = 30.15

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sqrt(delta p) = 0.451  
 Ts (F) = 171.7  
 Vs (fps) = 27.70

Stack Gas Flowrate, Qs  
 As (ft<sup>2</sup>) = 625.00  
 Qs (acfm) = 1,038,852

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscf/m) = 863,243  
 Qstd (dscf/hr) = 51,794,579

Velocity at the Nozzle, Vn Area of Nozzle, An  
 Dia. of Nozzle (in) = 0.3125 An (ft<sup>2</sup>) = 0.0005326  
 Time of Run (min) = 125  
 Vn (fps) = 27.16

% Isokinetic, %I  
 %I = 98.04  
 % Isokinetic measured from intermediate values  
 %I = 98.04

Pollutant Mass Emission Rate, PMR  
 Mn (g) 1.82E-06 1.20E-05  
 PMR (lbs/hr) 0.002 0.015  
 Lead Mercury

Grains per acf  
 gr/acf 2.59E-07 1.71E-06

Grains per dscf  
 gr/dscf 3.12E-07 2.05E-06

Pollutant Mass Emission Rate, PMR  
 VOC Conc. (PPM) 1.94  
 PMR (lbs/hr) 9.40  
 PMR (lbs/ton) 0.027  
 VOC

	Delta P	Squ Δ P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	0.32	0.566		2.62	172	96	96
2	0.32	0.566		2.62	175	95	95
3	0.32	0.566		2.62	175	93	93
4	0.32	0.566		2.62	170	93	94
5	0.32	0.566		2.62	170	94	94
6	0.30	0.548		2.46	170	95	93
7	0.28	0.529		2.30	170	95	93
8	0.28	0.529		2.30	182	94	93
9	0.28	0.510		2.13	177	94	93
10	0.25	0.500		2.05	179	94	93
11	0.25	0.500		2.05	181	95	93
12	0.28	0.529		2.30	166	94	93
13	0.22	0.469		1.80	157	93	93
14	0.30	0.548		2.46	158	93	93
15	0.30	0.548		2.46	157	93	93
16	0.15	0.387		1.23	163	93	92
17	0.16	0.400		1.31	177	93	92
18	0.10	0.316		0.82	176	93	92
19	0.10	0.316		0.82	181	93	92
20	0.08	0.283		0.66	167	92	91
21	0.06	0.245		0.49	162	92	91
22	0.12	0.346		0.98	176	92	91
23	0.12	0.346	852.265	0.98	179	93	91
24	0.09	0.300	758	0.74	173	93	91
25	0.09	0.300		0.74	180	93	92

0.216	Squ Δ P	Volume	Delta H	Stack T	Meter Temp
	0.451	94.265	1.768	171.7	93.1

**Production Rate**

South EAF	151.1 tons/hr
North EAF	93.7 tons/hr
AOD	97.8 tons/hr
<b>Total Avg Tons/hour</b>	<b>342.6</b>

<b>Company:</b>	Nucor Steel
<b>Location:</b>	Crawfordsville, Indiana
<b>Source:</b>	PPFF Baghouse #2 - Metals/VOC
<b>Date:</b>	04/18/05
<b>Run Number:</b>	2

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 20  
 Md (g/gmol) = 28.8

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vw (mL) = 27.7  
 Vw (scf) = 1.30384

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 92.2  
 Vm (ft<sup>3</sup>) = 85.98  
 Pb (in Hg) = 30.15  
 delta H (in H2O) = 1.546  
 gamma = 0.99  
 Vm (dscf) = 82.32

Moisture Content of Stack Gas, Bwo  
 Bwo = 1.56%  
 1-Bwo = 98.44%

Molecular Weight of Stack Gas, Ms  
 Ms (g/gmol) = 28.63

Area of Stack (enter diameter in inches), As  
 L = 300  
 W = 300  
 diameter (in) = 0  
 No. of Stacks = 1  
 As(L\*W) (ft<sup>2</sup>) = 625.0  
 As(dia.) (ft<sup>2</sup>) = 625.0

Absolute Pressure, Ps  
 Static (in H2O) = -0.02  
 Ps (in Hg) = 30.15

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sqrt(delta p) = 0.422  
 Ts (F) = 166.4  
 Vs (fps) = 25.83

Stack Gas Flowrate, Qs  
 As (ft<sup>2</sup>) = 625.00  
 Qs (acfm) = 968,442

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscf/m) = 809,770  
 Qstd (dscf/hr) = 48,586,212

Velocity at the Nozzle, Vn Area of Nozzle, An  
 Dia. of Nozzle (in) = 0.3125 An (ft<sup>2</sup>) = 0.0005326  
 Time of Run (min) = 125  
 Vn (fps) = 24.64

% Isokinetic, %I  
 %I = 95.42  
 % Isokinetic measured from intermediate values  
 %I = 95.42

Pollutant Mass Emission Rate, PMR  
 Mn (g) 1.96E-06 1.31E-05  
 PMR (lbs/hr) 0.003 0.017  
 Lead Mercury

Grains per acf  
 gr/acf 3.07E-07 2.05E-06

Grains per dscf  
 gr/dscf 3.67E-07 2.46E-06

Pollutant Mass Emission Rate, PMR  
 VOC Conc. (PPM) 1.87  
 PMR (lbs/hr) 8.50  
 PMR (lbs/ton) 0.023  
 VOC

**FIELD DATA**

K' Factor	8.2
-----------	-----

Start Time	16:58
Stop Time	19:26

	Delta P	Squ Δ P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	0.16	0.400		1.31	163	89	89
2	0.17	0.412		1.39	165	89	89
3	0.17	0.412		1.39	175	89	89
4	0.12	0.346		0.98	177	89	89
5	0.12	0.346		0.98	178	90	89
6	0.12	0.346		0.98	175	90	89
7	0.12	0.346		0.98	162	90	89
8	0.07	0.265		0.57	152	91	89
9	0.07	0.265		0.57	154	91	89
10	0.11	0.332		0.90	171	91	89
11	0.09	0.300		0.74	170	92	90
12	0.09	0.300		0.74	173	92	90
13	0.16	0.400		1.31	176	93	91
14	0.14	0.374		1.15	157	93	91
15	0.14	0.374		1.15	151	94	91
16	0.23	0.480		1.89	162	95	92
17	0.30	0.548		2.46	164	97	93
18	0.30	0.548		2.46	169	97	93
19	0.30	0.548		2.46	175	97	94
20	0.29	0.539		2.40	157	97	93
21	0.29	0.539		2.40	164	97	93
22	0.29	0.539		2.40	165	98	94
23	0.29	0.539	938.69	2.40	168	98	94
24	0.29	0.539	852.71	2.40	175	98	94
25	0.27	0.520		2.21	161	98	94

	Squ Δ P	Volume	Delta H	Stack T	Meter Temp
0.166	0.422	85.98	1.546	166.4	92.2

**Production Rate**

South EAF	190.5 tons/hr
North EAF	84.6 tons/hr
AOD	92.9 tons/hr
<b>Total Avg Tons/hour</b>	<b>368.0</b>

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	PPFF Baghouse #2 - Metals/VOC
Date:	04/19/05
Run Number:	3

**FIELD DATA**

K' Factor	8.3
-----------	-----

Start Time	8:20
Stop Time	13:30

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 20  
 Md (g/gmol) = 28.8

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vlc (mL) = 26.2  
 Vw (scf) = 1.23323

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 96.1  
 Vm (ft<sup>3</sup>) = 87.75  
 Pb (in Hg) = 29.87  
 delta H (in H2O) = 1.587  
 gamma = 0.99  
 Vm (dscf) = 82.67

Moisture Content of Stack Gas, Bwo  
 Bwo = 1.47%  
 1-Bwo = 98.53%

Molecular Weight of Stack Gas, Ms  
 Ms (g/gmol) = 28.64

Area of Stack (enter diameter in inches), As  
 L = 300  
 W = 300  
 diameter (in) = 0  
 No. of Stacks = 1  
 As(L\*W) (ft<sup>2</sup>) = 625.0  
 As(dia.) (ft<sup>2</sup>) = 625.0

Absolute Pressure, Ps  
 Static (in H2O) = -0.02  
 Ps (in Hg) = 29.87

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sqr(delta p) = 0.426  
 Ts (F) = 156.4  
 Vs (fps) = 25.96

Stack Gas Flowrate, Qs  
 As (ft<sup>2</sup>) = 625.00  
 Qs (acfm) = 973,619

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscf/min) = 820,262  
 Qstd (dscf/hr) = 49,215,715

Velocity at the Nozzle, Vn Area of Nozzle, An  
 Dia. of Nozzle (in) = 0.3125 An (ft<sup>2</sup>) = 0.000533  
 Time of Run (min) = 125  
 Vn (fps) = 24.56

% Isokinetic, %I  
 %I = 94.61  
 % Isokinetic measured from intermediate values  
 %I = 94.61

Pollutant Mass Emission Rate, PMR  
 Mn (g) 1.91E-06 1.24E-05  
 PMR (lbs/hr) 0.003 0.016  
 Lead Mercury

Grains per acf  
 gr/acf 3.00E-07 1.95E-06

Grains per dscf  
 gr/dscf 3.57E-07 2.31E-06

Pollutant Mass Emission Rate, PMR  
 VOC Conc. (PPM) 2.53  
 PMR (lbs/hr) 11.64  
 PMR (lbs/ton) 0.031  
 VOC

	Delta P	Squ Δ P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	0.23	0.480		1.91	155	92	90
2	0.23	0.480		1.91	164	92	90
3	0.22	0.469		1.83	166	93	91
4	0.24	0.490		1.99	158	95	91
5	0.24	0.490		1.99	158	97	93
6	0.25	0.500		2.08	153	99	95
7	0.27	0.520		2.24	181	99	96
8	0.28	0.529		2.32	166	102	98
9	0.28	0.529		2.32	177	103	98
10	0.30	0.548		2.49	160	104	100
11	0.30	0.548		2.49	158	107	102
12	0.30	0.548		2.49	155	107	102
13	0.22	0.469		1.83	154	108	103
14	0.20	0.447		1.66	142	95	95
15	0.20	0.447		1.66	152	96	95
16	0.13	0.361		1.08	148	94	93
17	0.10	0.316		0.83	141	94	93
18	0.10	0.316		0.85	140	94	93
19	0.11	0.332		0.94	145	95	93
20	0.08	0.283		0.68	151	94	93
21	0.08	0.283		0.68	156	94	93
22	0.10	0.316		0.85	160	94	93
23	0.10	0.316	1027.05	0.85	168	94	93
24	0.10	0.316	939.3	0.85	161	95	94
25	0.10	0.316		0.85	162	96	93

0.19	Squ Δ P	Volume	Delta H	Stack T	Meter Temp
	0.426	87.75	1.587	156.4	96.1

**Production Rate**

South EAF	139.7 tons/hr
North EAF	98.2 tons/hr
AOD	176 tons/hr
<b>Total Avg Tons/hour</b>	<b>413.9</b>
<b>Tons/hr during VOC testing:</b>	<b>370.7</b>

# VELOCITY TRAVERSE POINT DETERMINATION

(EPA Method 1)

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	PPFF Baghouse #2 - PM/PM10
Date:	04/18/05 - 04/22/05

## Rectangular Stack

Depth-in : 300      Diameter (inches): 300.0  
 Width-in : 300      Ports: 5

## Points per port:

	2	4	5	8	10	13
1	75.0	37.5	30.0	18.8	15.0	11.5
2	225.0	112.5	90.0	56.3	45.0	34.6
3		187.5	150.0	93.8	75.0	57.7
4		262.5	210.0	131.3	105.0	80.8
5			270.0	168.8	135.0	103.8
6				206.3	165.0	126.9
7				243.8	195.0	150.0
8				281.3	225.0	173.1
9					255.0	196.2
10					285.0	219.2
11						242.3
12						265.4
13						288.5

## Spacing

0.00	75.00	60.00	37.50	30.00	23.08
------	-------	-------	-------	-------	-------

CLIENT: Nucor Steel  
 LOCATION: Cawthronville, IN  
 UNIT: BANGHOUSE #2  
 DATE: 04-18-05  
 PROJECT #:  
 METER OPERATOR: ANDREW YOUNG  
 PROBE OPERATOR: ANDREW YOUNG  
 VISIBLE EMISSIONS READER: RON STAPERT  
 CLIENT CONTACT: MARY WAGNER  
 AGENCY CONTACT: STEVE FRIEND

METER BOX ID: A-1  
 METER Y: 0.99  
 PITOT Co: 0.84  
 PROBE ID: 13-1  
 BAROMETRIC: 30.15  
 STATIC PRESSURE (in. H<sub>2</sub>O):  
 LEAK RATE BEFORE (cfm): 0.000 @ (in. Hg)  
 LEAK RATE AFTER (cfm): 0.000 @ (in. Hg)  
 START TIME: 1248 STOP TIME: 1936

K FACTOR: 16.3  
 METER ΔH: 1.72  
 PROBE LINER: BELOW  
 NOZZLE ID: 0.371  
 AMBIENT TEMP (°F):  
 - 0.02

DUCT DIMENSIONS (in.): 25' x 25'  
 PORT LENGTH (in.): 0.0  
 FILTER ID: R1  
 SILICA ID: 1  
 TEDLAR BAG ID:  
 PITOT CHECK: PASS  FAIL   
 H<sub>2</sub>O (mL):  
 SILICA GEL (g): 42.2  
 TOTAL Vc: 127.2

Traverse Point Number	Mini/Point Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tip (°F)	Filter T1 (°F) Set Points		Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
							Probe Tip (°F)	Filter T1 (°F)					
1	11.5	0.11	1.82	853.1	176	249	249	249	67	98	98	3	
2	23.0	0.12	1.98	862.4	184	250	251	251	66	94	95	3	
3	34.5	0.14	2.31	872.41	177	251	251	251	66	95	94	4	
4	46.0	0.11	1.82	881.7	171	252	248	248	65	95	94	3.5	
5	57.5	0.09	1.49	889.6	179	254	247	247	66	92	91	3.5	
6	69.0	0.09	1.49	897.9	176	251	248	248	65	94	91	3.0	
7	80.5	0.11	1.82	906.2	164	255	251	251	65	92	91	3.0	
8	92.0	0.08	1.32	914.5	158	251	252	252	66	94	92	3.0	
9	103.5	0.05	0.83	920.7	165	248	246	246	65	92	92	3.0	
10	115.0	0.14	2.31	930.8	180	254	253	253	65	92	92	4.0	
11	126.5	0.08	1.32	938.5	171	250	248	248	65	92	90	3.0	
12	138.0	0.08	1.32	946.0	171	245	248	248	66	94	91	3.0	
13	149.5	0.20	3.30	958.0	181	256	252	252	66	94	92	6.0	
14	161.0	0.15	2.48	969.1	180	243	247	247	65	96	93	5.0	
15	172.5	0.10	1.65	976.5	170	247	259	259	66	96	94	3.0	
16	184.0	0.26	4.29	990.2	163	247	252	252	64	92	91	7.5	
17	195.5	0.26	4.29	1004.0	176	245	248	248	59	94	92	7.5	
18	207.0	0.24	3.96	1017.2	182	246	250	250	61	94	92	7.5	
19	218.5	0.29	4.79	1031.8	157	246	251	251	58	94	92	8.5	
20	230.0	0.27	4.46	1045.8	167	245	250	250	57	94	92	8.5	
21	241.5	0.26	4.29	1059.1	176	242	249	249	58	96	93	8.5	
22	253.0	0.28	4.62	1072.0	165	247	250	250	59	96	94	8.5	
23	264.5	0.28	4.62	1087.1	166	241	250	250	58	98	95	8.5	
24	276	0.30	4.95	1105.0	172	240	250	250	58	97	95	9.0	
25	287.5	0.33	5.45	1117.533	167	246	248	248	58	96	95	9.5	

PA = 6.0

Diagram of Test Location

**AIR TEST PROFESSIONALS FIELD DATA SHEET**

PM/PA TEST.

EPA METHOD 5/202

RUN 2

PAGE \_\_\_ OF \_\_\_

Diagram of Test Location

CLIENT	MUSCO STEEL	METER BOX ID	A-1	K FACTOR	16.7	DUCT DIMENSIONS (in.)	2.5' x 2.5'
LOCATION	CHATEAUBRIANNE IN	METER Y	0.99	METER ΔH	1.72	PORT LENGTH (in.)	
UNIT	PPE BAGHOUSE #2	PITOT Cp	0.84	PROBE LINER	TEFLON	FILTER ID	R 2
DATE	4-19-05	PROJECT #	13-1	NOZZLE ID	0.371	TEDLAR BAG ID	SILICA ID
METER OPERATOR	A. Young	BAROMETRIC	30.15	AMBIENT TEMP (°F)	70°	PITOT CHECK	03 20
PROBE OPERATOR	A. Young	STATIC PRESSURE (in. H <sub>2</sub> O)	-0.05			PASS/FAIL	02 20
VISIBLE EMISSIONS READER	R. STAPERT	LEAK RATE BEFORE (cfm)	0.000	@ (in. Hg)	15	H <sub>2</sub> O (mL)	84
AGENCY CONTACT	S. FRIED	LEAK RATE AFTER (cfm)	0.000	@ (in. Hg)	14	SILICA GEL (g)	42.0
AGENCY CONTACT	M. W. STOKER	START TIME	08:20	STOP TIME	16:08	TOTAL VIC	126

Traverse Point Number	Min/Point Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tp (°F)	Filter Tt (°F)	Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
	11.5	0.21	3.5	119.911	144	251	250	64	87	86	7	
	23.0	0.28	4.7	132.2	156	249	247	61	87	86	8	
	34.5	0.33	5.5	145.9	163	249	248	61	87	86	11	
	46.0	0.16	2.7	160.9	154	248	250	58	89	88	5	
	57.5	0.26	4.34	171.8	164	250	248	57	92	90	8	
	69.0	0.30	5.01	185.9	168	252	250	58	96	93	10	
	80.5	0.20	3.34	200.15	163	251	253	58	99	96	7	
	92.0	0.27	4.57	212.3	155	253	249	58	100	98	8	~ 3 hour delay
31	103.5	0.26	4.18	226.0	148	245	248	56	83	82	8	
	115.0	0.17	2.84	251.1	161	249	251	59	84	84	5	
	126.5	0.25	3.80	262.95	156	248	249	52	87	84	7	
	138.0	0.27	4.51	277.3	151	247	252	58	87	84	9	
	149.5	0.19	3.17	289.0	160	248	250	61	87	85	6	
	161.0	0.28	4.68	302.9	157	247	251	63	88	86	10	
	172.5	0.27	4.51	317.1	142	245	254	65	87	86	9	
	184.0	0.14	2.34	327.2	133	255	257	66	84	84	4	
	195.5	0.13	2.17	336.9	152	246	249	62	86	84	4	
	207.0	0.09	1.50	344.9	162	256	256	61	85	84	3.5	pH = 6
	218.5	0.08	1.34	352.4	152	257	254	58	86	85	3.5	
	230.0	0.08	1.34	360.1	163	250	252	59	87	85	3.5	
	241.5	0.08	1.34	367.7	164	246	251	60	87	85	3.5	
	253.0	0.08	1.34	375.2	163	254	254	62	86	86	3.5	
	264.5	0.07	1.17	382.1	159	250	251	62	86	85	3.5	
	276.0	0.09	1.50	390.5	169	251	253	62	86	85	3.5	
	287.5	0.09	1.50	398.785	177	250	254	62	86	85	3.5	

**AIR TEST PROFESSIONALS FIELD DATA SHEET**

PM/PM<sub>10</sub> TEST

EPA METHOD 5/202

RUN 3

PAGE 1 OF 1

CLIENT: Alvac Steel  
 LOCATION: Crows Landing, IL  
 UNIT: PPF Bldg #2  
 DATE: 4-22-05  
 METER OPERATOR: A Young  
 PROBE OPERATOR: A Young  
 VISIBLE EMISSIONS READER: C Roemer  
 CLIENT CONTACT: M Washer  
 AGENCY CONTACT: S Friend

METER BOX ID: A-1 K FACTOR: 16.5 DUCT DIMENSIONS (in.): 25' x 25'  
 METER: 0.79 METER ΔH: 1.72 PORT LENGTH (in.): ---  
 PITOT Cp: 0.84 PROBE LINER: Teflon FILTER ID: --- SILICA ID: 3  
 PROBE ID: 13-1 NOZZLE ID: 0.371 TEDLAR BAG ID: ---  
 BAROMETRIC: 29.87 AMBIENT TEMP (°F): --- PITOT CHECK: ---  
 STATIC PRESSURE (in. H<sub>2</sub>O): -0.03 PASS: --- FAIL: ---  
 LEAK RATE BEFORE (cfm): 0.00 @ (in. Hg): --- H<sub>2</sub>O (ml): ---  
 LEAK RATE AFTER (cfm): 0.00 @ (in. Hg): --- SILICA GEL (g): 40.2  
 START TIME: 0833 STOP TIME: 1414 TOTAL VIL: 112.2

Traverse Point Number	MiniPoint Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tip (°F)	Filter T1 (°F)	Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
	11.6	0.13	2.15	399.318	116	250	249	47	58	57	4	
	23	0.13	2.15	418.4	131	248	251	48	60	58	4	
	34.5	0.12	1.98	427.2	142	248	248	49	63	59	4	
	46	0.09	1.49	435.7	149	253	254	51	64	61	3	
	57.5	0.08	1.32	443.1	138	247	249	50	65	61	3	
	69	0.08	1.32	450.7	140	250	244	50	67	63	3	
	80.5	0.10	1.65	459.2	147	251	253	51	69	64	3	
	92	0.07	1.16	466.3	164	249	246	52	72	67	3	
	103.5	0.06	0.99	472.6	143	249	244	52	74	69	3	
	115	0.07	1.16	480.0	134	251	249	53	75	71	3	
	126.5	0.07	1.16	487.5	148	252	251	53	76	72	3	
	138	0.08	1.32	494.5	156	250	247	53	77	73	3	
	149.5	0.08	1.32	502.3	131	249	256	52	76	75	3	
	161	0.17	2.81	513.4	128	250	252	52	77	75	3	
	172.5	0.14	2.31	523.5	150	245	243	54	77	75	5	
	184	0.24	3.96	536.6	161	254	255	53	77	75	4	
	195.5	0.26	4.29	550.5	147	247	247	53	79	76	6	
	207	0.27	4.46	564.4	156	249	246	53	79	76	6	
	218.5	0.31	5.12	580.1	164	250	246	54	79	77	6	
	230	0.34	5.61	594.9	170	251	250	54	79	77	7	
	241.5	0.28	4.62	610.5	144	250	253	54	78	77	8	
	253	0.30	4.95	624.0	153	250	247	54	80	77	7	
	264.5	0.33	5.45	637.3	169	250	244	55	81	78	8	
	276	0.34	5.61	655.0	180	250	248	57	83	79	8	
	287.5	0.34	5.61	670.847	164	251	251	58	84	80	8	

pH = 6.0

← Furnace Delay



# VELOCITY TRAVERSE POINT DETERMINATION

(EPA Method 1)

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	PPFF Baghouse #2
Date:	04/18/05 - 04/22/05

## Rectangular Stack

Depth-in : 300      Diameter (inches): 300.0  
 Width-in : 300      Ports: 5

### Points per port:

	2	4	5	8	10	13
1	75.0	37.5	30.0	18.8	15.0	11.5
2	225.0	112.5	90.0	56.3	45.0	34.6
3		187.5	150.0	93.8	75.0	57.7
4		262.5	210.0	131.3	105.0	80.8
5			270.0	168.8	135.0	103.8
6				206.3	165.0	126.9
7				243.8	195.0	150.0
8				281.3	225.0	173.1
9					255.0	196.2
10					285.0	219.2
11						242.3
12						265.4
13						288.5

### Spacing

0.00	75.00	60.00	37.50	30.00	23.08
------	-------	-------	-------	-------	-------

AIR TEST PROFESSIONALS FIELD DATA SHEET

METALS TEST

EPA METHOD 1-4/29/9

RUN 1

PAGE OF

CLIENT Nuclear STEEL METER BOX ID A-2 K FACTOR 8.2 DUCT DIMENSIONS (in.) 25 x 25

LOCATION CRAWFORDSVILLE, IN METER Y 0.99 METER ΔH@ 1.83 PORT LENGTH (in.) 0.0

UNIT BAGHOUSE #2 PROJECT # 13' 2" PROBE ID 0.84 PROBE LINER TEFLON FILTER ID 21 SILICA ID 4

DATE 4-18-05 PROJECT # 13' 2" NOZZLE ID 0.3125 AMBIENT TEMP (°F) 64


METER OPERATOR CARLOS BROWN BAROMETRIC 30.15 AMBIENT TEMP (°F) 64

PROBE OPERATOR CARLOS BROWN STATIC PRESSURE (in. H<sub>2</sub>O) 0.006 @ (in. Hg) 10

VISIBLE EMISSIONS READER RON STAPERT LEAK RATE BEFORE (dlm) 0.000 @ (in. Hg) 10

CLIENT CONTACT MARIE WALKER LEAK RATE AFTER (dlm) 0.000 @ (in. Hg) 10

AGENCY CONTACT STEVE FRIEND START TIME 12:48 STOP TIME 1:33 TOTAL Vc 25.9



Traverse Point Number	Min/Point	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tp (°F)	Filter Tt (°F)	Condt. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
1	5	0.32	2.62	758.0	172	250	248	55	96	96	8	R1 = 8.2
2	10	0.32	2.62	768.6	175	250	248	55	95	95	8	
3	15	0.32	2.62	774.7	175	250	250	54	93	93	8	
4	20	0.32	2.62	779.5	170	248	250	55	94	94	8	
5	25	0.32	2.62	748.9	170	248	250	56	94	94	8	
6	30	0.30	2.46	788.3	170	251	252	56	95	93	7.5	
7	35	0.28	2.30	792.9	170	251	254	57	95	93	7.0	
8	40	0.28	2.30	797.8	182	254	250	63	94	93	7.0	
9	45	0.26	2.13	801.3	177	253	250	64	94	93	7.0	
10	50	0.25	2.05	805.0	179	252	251	63	94	93	7.0	
11	55	0.25	2.05	809.1	181	250	249	61	95	93	7.0	
12	60	0.28	2.30	813.8	166	245	252	61	94	93	7.0	
13	65	0.22	1.80	818.2	157	250	251	61	93	93	6.0	
14	70	0.30	2.46	821.34	158	248	250	58	93	93	8.0	
15	75	0.30	2.46	825.8	157	246	253	58	93	93	8.0	
16	80	0.15	1.23	829.2	163	254	245	61	93	92	5.0	
17	85	0.16	1.31	832.4	177	255	244	57	93	92	5.0	
18	90	0.10	0.82	834.9	176	247	244	60	93	92	3.0	
19	95	0.10	0.82	837.4	181	248	247	60	93	92	3.0	
20	100	0.08	0.66	839.7	167	248	250	62	92	91	3.0	
21	105	0.06	0.49	841.8	162	252	248	59	92	91	2.0	
22	110	0.12	0.98	844.9	176	247	252	61	92	91	3.0	
23	115	0.12	0.98	847.4	179	250	259	59	93	91	3.5	
24	120	0.09	0.74	850.0	173	251	260	62	93	91	3.0	
25	125	0.09	0.74	852.265	180	252	248	62	93	92	3.0	

**AIR TEST PROFESSIONALS FIELD DATA SHEET**

TEST # 1658

EPA METHOD 1-4/23

RUN 2

PAGE      OF     

CLIENT Nikea Steel METER BOX ID A-2 K FACTOR 8.2 DUCT DIMENSIONS (in.) 25" x 25" Diagram of Test Location

LOCATION Crawfordsville, IN METER ΔH @ 1.83 PORT LENGTH (in.)     

UNIT BAGHOUSE #2 PITOT Cp 0.84 PROBE LINER TEFLON FILTER ID R-2 SILICA ID #5

DATE 04-18-05 PROJECT #      PROBE ID 13.2 NOZZLE ID 0.3125 TEDLAR BAG ID     

METER OPERATOR CARLOS BROWN BAROMETRIC 30.15 AMBIENT TEMP (°F)      PITOT CHECK      O<sub>2</sub> 20.0

PROBE OPERATOR CARLOS BROWN STATIC PRESSURE (in. H<sub>2</sub>O) -0.02 PASS  FAIL  CO<sub>2</sub> 0.0

VISIBLE EMISSIONS READER RON STAPERT LEAK RATE BEFORE (cm) 0.000 @ (in. Hg) 12" H<sub>2</sub>O (ml) 11

CLIENT CONTACT MARK WATKIN LEAK RATE AFTER (cm) 0.000 @ (in. Hg) 14" SILICA GEL (g) 16.7

AGENCY CONTACT STEVE FRIEND START TIME 1658 STOP TIME 1926 TOTAL Vc 27.7

Traverse Point Number	MiniPoint	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tip (°F)	Filler Tl (°F)	Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
1	5	0.16	1.31	852.71	163	248	250	64	89	89	4.5	
2	10	0.17	1.39	859.2	165	249	250	59	89	89	4.5	
3	15	0.17	1.39	862.3	175	249	250	61	89	89	4.5	
4	20	0.12	0.98	865.5	177	250	246	60	89	89	4.0	
5	25	0.12	0.98	868.2	178	253	251	60	90	89	4.0	
6	30	0.12	0.98	871.0	175	246	248	60	90	89	4.0	
7	35	0.12	0.98	874.2	162	251	251	62	90	89	4.0	
8	40	0.07	0.57	876.1	152	251	248	61	91	89	3.0	
9	45	0.07	0.57	878.2	154	250	249	62	91	89	3.0	
10	50	0.11	0.90	881.6	171	252	251	62	91	89	3.5	
11	55	0.09	0.74	883.6	170	250	249	61	92	90	3.5	
12	60	0.09	0.74	885.9	173	248	249	61	92	90	3.5	
13	65	0.16	1.31	889.2	176	253	250	64	93	91	4.0	
14	70	0.14	1.15	892.0	157	251	248	64	93	91	4.0	
15	75	0.14	1.15	895.0	151	247	250	62	94	91	4.0	
16	80	0.23	1.89	898.9	162	253	250	62	95	92	6.0	
17	85	0.30	2.46	903.5	164	250	250	62	97	93	8.0	
18	90	0.30	2.46	907.6	169	245	248	63	97	93	8.0	
19	95	0.30	2.46	912.0	175	250	250	65	97	94	8.0	
20	100	0.29	2.40	916.8	157	250	252	63	97	93	8.0	
21	105	0.29	2.40	921.1	164	249	250	63	97	93	8.0	
22	110	0.29	2.40	925.5	165	250	252	63	98	94	8.0	
23	115	0.29	2.40	929.7	168	250	251	63	98	94	8.0	
24	120	0.29	2.40	933.9	175	250	249	63	98	94	8.0	
25	125	0.27	2.21	938.69	161	249	250	63	98	94	7.5	

**AIR TEST PROFESSIONALS FIELD DATA SHEET**

TEST NO. METALS

EPA METHOD 1-4/29

RUN 3

PAGE 3 OF     

CLIENT	<u>NUCOR STEEL</u>	METER BOX ID	<u>A-2</u>	KFACTOR	<u>8.3c</u>	DUCT DIMENSIONS (in.)	<u>25' x 25'</u>
LOCATION	<u>CLATSOP COUNTY, IN</u>	METER Y	<u>0.99</u>	METER ΔH@	<u>1.83</u>	PORT LENGTH (in.)	<u>0.0</u>
UNIT	<u>PPF BAKHOUSE #2</u>	PITOT Co	<u>0.84</u>	PROBE LINER	<u>727-201</u>	FILTER ID	<u>R-3</u>
DATE	<u>04-19-05</u>	PROJECT #	<u>1312</u>	NOZZLE ID	<u>0.3125</u>	TEFLAR BAG ID	<u>6</u>
METER OPERATOR	<u>CARLOS BROWN</u>	BAROMETRIC	<u>30.15</u>	AMBIENT TEMP (°F)	<u>-0.02</u>	PITOT CHECK	<u>0<sub>2</sub> 20.0</u>
PROBE OPERATOR	<u>CARLOS BROWN</u>	STATIC PRESSURE (in. H <sub>2</sub> O)	<u>0.000</u>	@ (in. Hg)	<u>15.1</u>	FAIL	<u>0<sub>2</sub> 0.0</u>
VISIBLE EMISSIONS READER	<u>RON STAPERT</u>	LEAK RATE BEFORE (cfm)	<u>0.000</u>	@ (in. Hg)	<u>10</u>	SILICA GEL (g)	<u>16.2</u>
CLIENT CONTACT	<u>WALF LUKATEL</u>	LEAK RATE AFTER (cfm)	<u>0.000</u>	@ (in. Hg)	<u>10</u>	TOTAL VIC	<u>26.2</u>
AGENCY CONTACT	<u>STEVE FRIEND</u>	START TIME	<u>0820</u>	STOP TIME	<u>1330</u>		

Traverse Point Number	MiniPoint Elapsed Time	Velocity Head ΔPs (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tp (°F)	Filter Tt (°F)	Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
1	5	0.23	1.91	943.2	155	252	249	62	92	90	6.0	
2	10	0.23	1.91	946.9	164	248	250	54	92	90	6.0	
3	15	0.22	1.83	950.8	166	249	249	54	93	91	6.0	
4	20	0.24	1.99	955.0	158	250	252	54	95	91	6.0	
5	25	0.24	1.99	959.0	158	252	248	55	97	93	6.0	
6	30	0.25	2.08	962.7	153	246	252	55	99	95	6.5	10 m/s pick-up Run 1
7	35	0.27	2.24	967.1	161	257	253	56	99	96	7.0	
8	40	0.28	2.32	971.3	166	251	250	56	102	98	7.0	11 m/s pick-up Run 2
9	45	0.28	2.32	975.7	177	250	248	56	103	98	7.0	
10	50	0.30	2.49	979.2	160	250	256	57	104	100	7.0	
11	55	0.30	2.49	983.0	158	250	249	57	107	102	7.0	
12	60	0.30	2.49	987.0	155	249	252	57	107	102	7.0	
13	65	0.22	1.83	993.1	154	250	250	58	108	103	6.0	
14	70	0.20	1.66	996.0	142	250	246	58	95	95	6.0	
15	75	0.20	1.66	1000.0	152	250	252	57	96	95	6.0	
16	80	0.13	1.08	1003.8	148	250	251	61	94	93	5.0	
17	85	0.10	0.83	1006.4	141	250	250	61	94	93	4.0	
18	90	0.10	0.85	1009.1	140	249	248	61	94	93	4.0	CHANGE K' = 8.5
19	95	0.11	0.94	1012.0	145	250	250	60	95	93	4.0	
20	100	0.08	0.68	1014.0	151	250	252	61	94	93	3.0	
21	105	0.08	0.68	1016.3	156	250	250	62	94	93	3.0	
22	110	0.10	0.85	1018.7	160	250	247	63	94	93	3.0	
23	115	0.10	0.85	1021.8	168	250	248	63	94	93	3.0	
24	120	0.10	0.85	1025.0	161	250	253	63	95	94	3.0	
25	125	0.10	0.85	1027.05	162	249	249	64	96	94	3.0	

ANALYZER FIELD DATA

Company: Nucor Steel  
 Location: Crawfordsville, Indiana  
 Source: PFFF Baghouse #2 - VOC  
 Date: 4/18/05 - 4/19/05

NUCOR STEEL  
 \*\*\*\*\* OFF \*\*\*\*\*  
 VOC - Baghouse #2  
 \*\*\*\*\* ON \*\*\*\*\*  
 \*\*\*\*\* RUN \*\*\*\*\*

10:18:57 04/18/05  
 2 0076.7

77.0

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*  
 \*\*\*\*\* RUN \*\*\*\*\*

10:21:04 04/18/05  
 2 0000.3

zero

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*  
 \*\*\*\*\* RUN \*\*\*\*\*

10:24:30 04/18/05  
 2 0029.6

29.6

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*  
 \*\*\*\*\* RUN \*\*\*\*\*

10:27:51 04/18/05  
 2 0048.4

48.6

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*  
 \*\*\*\*\* RUN \*\*\*\*\*

\*\*\*\*\* RUN (1) \*\*\*\*\*

12:50:12 04/18/05  
 2 0002.3

12:51:12 04/18/05  
 2 0002.2

12:52:12 04/18/05  
 2 0002.2

12:53:12 04/18/05  
 2 0002.2

12:54:12 04/18/05  
 2 0002.2

12:55:12 04/18/05  
 2 0002.2

12:56:12 04/18/05  
 2 0002.2

12:57:12 04/18/05  
 2 0002.9

12:58:12 04/18/05  
 2 0002.3

12:59:12 04/18/05  
 2 0002.3

13:00:12 04/18/05  
 2 0002.3

13:01:12 04/18/05  
 2 0002.2

13:02:12 04/18/05  
 2 0002.1

13:03:12 04/18/05  
 2 0001.9

13:04:12 04/18/05  
 2 0001.9

13:05:12 04/18/05  
 2 0001.9

13:06:12 04/18/05  
 2 0001.9

13:07:12 04/18/05  
 2 0002.0

13:08:12 04/18/05  
 2 0002.0

13:09:12 04/18/05  
 2 0001.9

13:10:12 04/18/05  
 2 0002.0

13:11:12 04/18/05  
 2 0002.1

13:12:12 04/18/05  
 2 0002.1

13:13:12 04/18/05  
 2 0002.0

13:14:12 04/18/05  
 2 0002.2

13:15:12 04/18/05  
 2 0002.3

13:16:12 04/18/05  
 2 0002.3

13:17:12 04/18/05  
 2 0002.2

13:18:12 04/18/05  
 2 0002.3

13:19:12 04/18/05  
 2 0002.1

13:20:12 04/18/05  
 2 0002.2

13:21:12 04/18/05  
 2 0002.2

13:22:12 04/18/05  
 2 0002.5

13:23:12 04/18/05  
 2 0002.4

13:24:12 04/18/05  
 2 0002.4

13:25:12 04/18/05  
 2 0002.3

13:26:12 04/18/05  
 2 0002.2

13:27:12 04/18/05  
 2 0002.1

13:28:12 04/18/05  
 2 0001.9

13:29:12 04/18/05  
 2 0001.9

13:30:12 04/18/05  
 2 0001.9

13:31:12 04/18/05  
 2 0001.9

13:32:12 04/18/05  
 2 0001.8

13:33:12 04/18/05  
 2 0002.1

13:34:12 04/18/05  
 2 0002.0

13:35:12 04/18/05  
 2 0001.9

13:36:12 04/18/05  
 2 0001.9

13:37:12 04/18/05  
 2 0002.0

**ANALYZER FIELD DATA**

**Company:** Nucor Steel  
**Location:** Crawfordsville, Indiana  
**Source:** PPF Baghouse #2 - VOC  
**Date:** 4/18/05 - 4/19/05

13:38:12 04/18/05  
 2 0002.1

13:39:12 04/18/05  
 2 0002.3

13:40:12 04/18/05  
 2 0002.2

13:41:12 04/18/05  
 2 0002.1

13:42:12 04/18/05  
 2 0002.1

13:43:12 04/18/05  
 2 0002.1

13:44:12 04/18/05  
 2 0002.0

13:45:12 04/18/05  
 2 0001.9

13:46:12 04/18/05  
 2 0002.0

13:47:12 04/18/05  
 2 0002.0

13:48:12 04/18/05  
 2 0002.0

13:49:12 04/18/05  
 2 0002.0

13:50:12 04/18/05  
 2 0001.9

13:51:12 04/18/05  
 2 0001.8

13:52:12 04/18/05  
 2 0001.7

13:53:12 04/18/05  
 2 0001.4

13:54:12 04/18/05  
 2 0001.7

13:55:12 04/18/05  
 2 0001.8

13:56:12 04/18/05  
 2 0001.9

13:57:12 04/18/05  
 2 0001.8

13:58:12 04/18/05  
 2 0001.5

13:59:12 04/18/05  
 2 0001.5

14:00:12 04/18/05  
 2 0001.5

14:01:12 04/18/05  
 2 0001.7

14:02:12 04/18/05  
 2 0001.7

14:03:12 04/18/05  
 2 0001.8

14:04:12 04/18/05  
 2 0001.9

14:05:12 04/18/05  
 2 0002.1

14:06:12 04/18/05  
 2 0002.2

14:07:12 04/18/05  
 2 0002.2

14:08:12 04/18/05  
 2 0002.2

14:09:12 04/18/05  
 2 0002.1

14:10:12 04/18/05  
 2 0002.0

14:11:12 04/18/05  
 2 0002.1

14:12:12 04/18/05  
 2 0002.0

14:13:12 04/18/05  
 2 0001.9

14:14:12 04/18/05  
 2 0001.9

14:15:12 04/18/05  
 2 0001.9

14:16:12 04/18/05  
 2 0001.8

14:17:12 04/18/05  
 2 0001.8

14:18:12 04/18/05  
 2 0002.0

14:19:12 04/18/05  
 2 0001.9

14:20:12 04/18/05  
 2 0001.9

14:21:12 04/18/05  
 2 0001.8

14:22:12 04/18/05  
 2 0002.0

14:23:12 04/18/05  
 2 0001.8

14:24:12 04/18/05  
 2 0001.9

14:25:12 04/18/05  
 2 0001.9

14:26:12 04/18/05  
 2 0001.9

14:27:12 04/18/05  
 2 0001.8

14:28:12 04/18/05  
 2 0001.9

14:29:12 04/18/05  
 2 0001.9

14:30:12 04/18/05  
 2 0001.8

14:31:12 04/18/05  
 2 0001.7

14:32:12 04/18/05  
 2 0001.7

14:33:12 04/18/05  
 2 0001.5

14:34:12 04/18/05  
 2 0001.4

14:35:12 04/18/05  
 2 0001.7

14:36:12 04/18/05  
 2 0001.7

14:37:12 04/18/05  
 2 0001.8

14:38:12 04/18/05  
 2 0001.8

14:39:12 04/18/05  
 2 0002.1

14:40:12 04/18/05  
 2 0002.2

**ANALYZER FIELD DATA**

**Company:** Nucor Steel  
**Location:** Crawfordsville, Indiana  
**Source:** PPF Baghouse #2 - VOC  
**Date:** 4/18/05 - 4/19/05

2	14:41:12	04/18/05	2	15:02:12	04/18/05	2	15:22:12	04/18/05
	0002.1			0001.7			0002.2	
2	14:42:12	04/18/05	2	15:03:12	04/18/05	2	15:23:12	04/18/05
	0002.1			0001.7			0002.1	
2	14:43:12	04/18/05	2	15:04:12	04/18/05	2	15:24:12	04/18/05
	0002.1			0001.5			0001.9	
2	14:44:12	04/18/05	2	15:05:12	04/18/05	2	15:25:12	04/18/05
	0001.9			0001.5			0001.9	
2	14:45:12	04/18/05	2	15:06:12	04/18/05	2	15:26:12	04/18/05
	0001.9			0001.4			0001.9	
2	14:46:12	04/18/05	2	15:07:12	04/18/05	2	15:27:12	04/18/05
	0002.0			0001.4			0001.8	
2	14:47:12	04/18/05	2	15:08:12	04/18/05	2	15:28:12	04/18/05
	0002.1			0001.4			0001.8	
2	14:48:12	04/18/05	2	15:09:12	04/18/05	2	15:29:12	04/18/05
	0002.1			0001.4			0001.5	
2	14:49:12	04/18/05	2	15:10:12	04/18/05	2	15:30:12	04/18/05
	0002.3			0001.5			0001.5	
2	14:50:12	04/18/05	2	15:11:12	04/18/05	2	15:31:12	04/18/05
	0002.2			0001.5			0001.4	
2	14:51:12	04/18/05	2	15:12:12	04/18/05	2	15:32:12	04/18/05
	0001.9			0001.7			0001.4	
2	14:52:12	04/18/05	2	15:13:12	04/18/05	2	15:33:12	04/18/05
	0001.9			0001.8			0001.4	
2	14:53:12	04/18/05	2	15:14:12	04/18/05	2	15:34:12	04/18/05
	0002.1			0001.9			0001.5	
2	14:54:12	04/18/05	2	15:15:12	04/18/05	2	15:35:12	04/18/05
	0002.0			0001.9			0001.4	
2	14:55:12	04/18/05	2	15:16:12	04/18/05	2	15:36:12	04/18/05
	0001.7			0001.9			0001.5	
2	14:56:12	04/18/05	2	15:17:12	04/18/05	2	15:37:12	04/18/05
	0001.7			0002.1			0001.5	
2	14:57:12	04/18/05	2	15:18:12	04/18/05	2	15:38:12	04/18/05
	0001.5			0002.2			0001.4	
2	14:58:12	04/18/05	2	15:19:12	04/18/05	2	15:39:12	04/18/05
	0001.7			0002.1			0001.5	
2	14:59:12	04/18/05	2	15:20:12	04/18/05	2	15:40:12	04/18/05
	0001.5			0002.2			0001.7	
2	15:00:12	04/18/05	2	15:21:12	04/18/05	2	15:41:12	04/18/05
	0001.5			0002.4			0001.5	
2	15:01:12	04/18/05						
	0001.7							

**ANALYZER FIELD DATA**

**Company:** Nucor Steel  
**Location:** Crawfordsville, Indiana  
**Source:** PPF Baghouse #2 - VOC  
**Date:** 4/18/05 - 4/19/05

```

15:42:12 04/18/05
2 0001.8

15:43:12 04/18/05
2 0001.8

15:44:12 04/18/05
2 0001.8

15:45:12 04/18/05
2 0001.4

15:46:12 04/18/05
2 0001.4

15:47:12 04/18/05
2 0001.5

15:48:12 04/18/05
2 0001.5

15:49:12 04/18/05
2 0001.5

15:50:12 04/18/05
2 0001.7

15:51:12 04/18/05
2 0001.7

15:52:12 04/18/05
2 0001.8

15:53:12 04/18/05
2 0001.8

15:54:12 04/18/05
2 0001.9

15:55:12 04/18/05
2 0002.1

15:56:12 04/18/05
2 0002.1

15:57:12 04/18/05
2 0002.2

15:58:12 04/18/05
2 0002.2

15:59:12 04/18/05
2 0002.2
    
```

```

*** ON (RUNNING) ***
***** STOP *****
15:59:21 04/18/05
Run statistics N=00190
Min Avg Max
2 0001.4 0001.9 0002.9
    
```

```

***** RUN *****
16:06:03 04/18/05
2 0048.0 48.6

***** OFF *****
***** ON *****
***** RUN *****
16:09:02 04/18/05
2 -0000.4 zero

***** OFF *****
***** ON *****
***** RUN (2) *****
17:00:08 04/18/05
2 0002.0

17:01:08 04/18/05
2 0001.9

17:02:08 04/18/05
2 0001.9

17:03:08 04/18/05
2 0001.9

17:04:08 04/18/05
2 0001.9

17:05:08 04/18/05
2 0001.9

17:06:08 04/18/05
2 0001.9

17:07:08 04/18/05
2 0001.8

17:08:08 04/18/05
2 0001.9

17:09:08 04/18/05
2 0001.8

17:10:08 04/18/05
2 0001.8

17:11:08 04/18/05
2 0001.8

17:12:08 04/18/05
2 0002.1

17:13:08 04/18/05
2 0002.1
    
```

```

17:14:08 04/18/05
2 0002.2

17:15:08 04/18/05
2 0002.1

17:16:08 04/18/05
2 0002.2

17:17:08 04/18/05
2 0002.3

17:18:08 04/18/05
2 0002.1

17:19:08 04/18/05
2 0001.9

17:20:08 04/18/05
2 0001.8

17:21:08 04/18/05
2 0001.8

17:22:08 04/18/05
2 0001.9

17:23:08 04/18/05
2 0001.9

17:24:08 04/18/05
2 0001.9

17:25:08 04/18/05
2 0001.9

17:26:08 04/18/05
2 0001.9

17:27:08 04/18/05
2 0001.8

17:28:08 04/18/05
2 0001.8

17:29:08 04/18/05
2 0001.9

17:30:08 04/18/05
2 0001.9

17:31:08 04/18/05
2 0002.0

17:32:08 04/18/05
2 0001.9

17:33:08 04/18/05
2 0001.9

17:34:08 04/18/05
2 0001.9
    
```



**ANALYZER FIELD DATA**

**Company:** Nucor Steel  
**Location:** Crawfordsville, Indiana  
**Source:** PPF Baghouse #2 - VOC  
**Date:** 4/18/05 - 4/19/05

17:35:08	04/18/05	17:36:08	04/18/05	18:17:08	04/18/05
2 0002.0		2 0001.9		2 0001.5	
17:36:08	04/18/05	17:57:08	04/18/05	18:18:08	04/18/05
2 0002.1		2 0002.1		2 0001.7	
17:37:08	04/18/05	17:58:08	04/18/05	18:19:08	04/18/05
2 0001.9		2 0002.2		2 0001.5	
17:38:08	04/18/05	17:59:08	04/18/05	18:20:08	04/18/05
2 0002.0		2 0002.1		2 0001.5	
17:39:08	04/18/05	18:00:08	04/18/05	18:21:08	04/18/05
2 0002.1		2 0002.0		2 0001.5	
17:40:08	04/18/05	18:01:08	04/18/05	18:22:08	04/18/05
2 0003.1		2 0002.0		2 0002.6	
17:41:08	04/18/05	18:02:08	04/18/05	18:23:08	04/18/05
2 0002.9		2 0001.9		2 0002.8	
17:42:08	04/18/05	18:03:08	04/18/05	18:24:08	04/18/05
2 0002.1		2 0002.0		2 0001.9	
17:43:08	04/18/05	18:04:08	04/18/05	18:25:08	04/18/05
2 0001.9		2 0001.8		2 0002.1	
17:44:08	04/18/05	18:05:08	04/18/05	18:26:08	04/18/05
2 0001.9		2 0001.9		2 0001.9	
17:45:08	04/18/05	18:06:08	04/18/05	18:27:08	04/18/05
2 0001.8		2 0001.9		2 0001.5	
17:46:08	04/18/05	18:07:08	04/18/05	18:28:08	04/18/05
2 0001.7		2 0001.9		2 0001.5	
17:47:08	04/18/05	18:08:08	04/18/05	18:29:08	04/18/05
2 0001.8		2 0001.8		2 0001.7	
17:48:08	04/18/05	18:09:08	04/18/05	18:30:08	04/18/05
2 0001.8		2 0001.7		2 0001.5	
17:49:08	04/18/05	18:10:08	04/18/05	18:31:08	04/18/05
2 0001.8		2 0001.8		2 0001.5	
17:50:08	04/18/05	18:11:08	04/18/05	18:32:08	04/18/05
2 0001.8		2 0001.5		2 0001.5	
17:51:08	04/18/05	18:12:08	04/18/05	18:33:08	04/18/05
2 0001.8		2 0001.8		2 0001.7	
17:52:08	04/18/05	18:13:08	04/18/05	18:34:08	04/18/05
2 0001.8		2 0001.7		2 0001.8	
17:53:08	04/18/05	18:14:08	04/18/05	18:35:08	04/18/05
2 0001.8		2 0001.8		2 0002.5	
17:54:08	04/18/05	18:15:08	04/18/05	18:36:08	04/18/05
2 0001.8		2 0001.7		2 0002.1	
17:55:08	04/18/05	18:16:08	04/18/05	18:37:08	04/18/05
2 0001.9		2 0001.7		2 0002.1	

**ANALYZER FIELD DATA**

**Company:** Nucor Steel  
**Location:** Crawfordsville, Indiana  
**Source:** PFFF Baghouse #2 - VOC  
**Date:** 4/18/05 - 4/19/05

2	18:38:08	04/18/05	2	18:58:08	04/18/05	2	19:18:08	04/18/05
	0001.9			0001.9			0001.8	
2	18:39:08	04/18/05	2	18:59:08	04/18/05	2	19:19:08	04/18/05
	0001.9			0001.9			0001.8	
2	18:40:08	04/18/05	2	19:00:08	04/18/05	2	19:20:08	04/18/05
	0001.9			0001.8			0002.0	
2	18:41:08	04/18/05	2	19:01:08	04/18/05	2	19:21:08	04/18/05
	0001.9			0001.8			0001.9	
2	18:42:08	04/18/05	2	19:02:08	04/18/05	2	19:22:08	04/18/05
	0002.0			0001.9			0002.0	
2	18:43:08	04/18/05	2	19:03:08	04/18/05	2	19:23:08	04/18/05
	0002.0			0001.9			0001.9	
2	18:44:08	04/18/05	2	19:04:08	04/18/05	2	19:24:08	04/18/05
	0002.1			0001.9			0001.8	
2	18:45:08	04/18/05	2	19:05:08	04/18/05	2	19:25:08	04/18/05
	0002.2			0001.8			0001.9	
2	18:46:08	04/18/05	2	19:06:08	04/18/05	2	19:26:08	04/18/05
	0002.0			0001.7			0001.8	
2	18:47:08	04/18/05	2	19:07:08	04/18/05	2	19:27:08	04/18/05
	0001.9			0001.5			0001.8	
2	18:48:08	04/18/05	2	19:08:08	04/18/05	2	19:28:08	04/18/05
	0001.8			0001.4			0001.9	
2	18:49:08	04/18/05	2	19:09:08	04/18/05	2	19:29:08	04/18/05
	0001.8			0001.5			0001.9	
2	18:50:08	04/18/05	2	19:10:08	04/18/05	2	19:30:08	04/18/05
	0001.8			0001.5			0001.9	
2	18:51:08	04/18/05	2	19:11:08	04/18/05	2	19:31:08	04/18/05
	0001.7			0001.5			0002.0	
2	18:52:08	04/18/05	2	19:12:08	04/18/05	2	19:32:08	04/18/05
	0001.8			0001.7			0001.9	
2	18:53:08	04/18/05	2	19:13:08	04/18/05	2	19:33:08	04/18/05
	0001.8			0001.5			0001.9	
2	18:54:08	04/18/05	2	19:14:08	04/18/05	2	19:34:08	04/18/05
	0001.8			0001.5			0001.9	
2	18:55:08	04/18/05	2	19:15:08	04/18/05	2	19:35:08	04/18/05
	0002.0			0001.7			0002.0	
2	18:56:08	04/18/05	2	19:16:08	04/18/05	2	19:36:08	04/18/05
	0001.9			0001.7			0001.9	
2	18:57:08	04/18/05	2	19:17:08	04/18/05	2	19:37:08	04/18/05
	0001.9			0001.5			0001.9	
							19:38:08	04/18/05
							0002.1	

**ANALYZER FIELD DATA**

Company: Nucor Steel  
 Location: Crawfordsville, Indiana  
 Source: PPF Baghouse #2 - VOC  
 Date: 4/18/05 - 4/19/05

19:39:08 04/18/05	19:59:08 04/18/05
2 0001.8	2 0001.4
19:40:08 04/18/05	20:00:08 04/18/05
2 0001.8	2 0001.5
19:41:08 04/18/05	20:01:08 04/18/05
2 0001.8	2 0001.8
19:42:08 04/18/05	20:02:08 04/18/05
2 0001.7	2 0001.9
19:43:08 04/18/05	20:03:08 04/18/05
2 0001.7	2 0001.8
19:44:08 04/18/05	20:04:08 04/18/05
2 0001.5	2 0001.8
19:45:08 04/18/05	20:05:08 04/18/05
2 0001.5	2 0001.8
19:46:08 04/18/05	20:06:08 04/18/05
2 0001.5	2 0001.8
19:47:08 04/18/05	20:07:08 04/18/05
2 0001.4	2 0001.7
19:48:08 04/18/05	20:08:08 04/18/05
2 0001.4	2 0001.4
19:49:08 04/18/05	20:09:08 04/18/05
2 0001.2	2 0001.4
19:50:08 04/18/05	20:10:08 04/18/05
2 0001.2	2 0001.4
19:51:08 04/18/05	20:11:08 04/18/05
2 0001.2	2 0001.5
19:52:08 04/18/05	20:12:08 04/18/05
2 0001.2	2 0001.8
19:53:08 04/18/05	20:13:08 04/18/05
2 0001.7	2 0001.5
19:54:08 04/18/05	20:14:08 04/18/05
2 0001.5	2 0001.4
19:55:08 04/18/05	20:15:08 04/18/05
2 0001.5	2 0001.5
19:56:08 04/18/05	20:16:08 04/18/05
2 0001.5	2 0001.5
19:57:08 04/18/05	20:17:08 04/18/05
2 0001.5	2 0001.5
19:58:08 04/18/05	
2 0001.4	

\*\*\*\*\* RUN \*\*\*\*\*

20:18:12 04/18/05  
 2 0048.6 **48.6**

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*  
 \*\*\*\*\* RUN \*\*\*\*\*

20:20:12 04/18/05  
 2 -0000.7 **zero**

**4/19/05**

\*\*\*\*\* RUN \*\*\*\*\*

07:18:00 04/19/05  
 2 0000.2 **zero**

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*  
 \*\*\*\*\* RUN \*\*\*\*\*

07:22:28 04/19/05  
 2 0076.9 **77**

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*  
 \*\*\*\*\* RUN \*\*\*\*\*

07:25:04 04/19/05  
 2 0029.9 **29.6**

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*  
 \*\*\*\*\* RUN \*\*\*\*\*

07:27:29 04/19/05  
 2 0048.8 **48.6**

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\* ON (RUNNING) \*\*\*  
 \*\*\*\*\* STOP \*\*\*\*\*  
 20:17:16 04/18/05  
 Run statistics N=00198  
 Min Avg Max  
 2 0001.2 0001.8 0003.1

**ANALYZER FIELD DATA**

**Company:** Nucor Steel  
**Location:** Crawfordsville, Indiana  
**Source:** PFFF Baghouse #2 - VOC  
**Date:** 4/18/05 - 4/19/05

***** ON *****	***** RU *****	*****	*****	*****	*****
07:30:09	04/19/05	2	0002.5	07:50:09	04/19/05
07:31:09	04/19/05	2	0002.5	07:51:09	04/19/05
07:32:09	04/19/05	2	0002.5	07:52:09	04/19/05
07:33:09	04/19/05	2	0002.6	07:53:09	04/19/05
07:34:09	04/19/05	2	0002.6	07:54:09	04/19/05
07:35:09	04/19/05	2	0002.5	07:55:09	04/19/05
07:36:09	04/19/05	2	0002.8	07:56:09	04/19/05
07:37:09	04/19/05	2	0002.8	07:57:09	04/19/05
07:38:09	04/19/05	2	0002.9	07:58:09	04/19/05
07:39:09	04/19/05	2	0002.8	07:59:09	04/19/05
07:40:09	04/19/05	2	0002.8	08:00:09	04/19/05
07:41:09	04/19/05	2	0002.8	08:01:09	04/19/05
07:42:09	04/19/05	2	0002.8	08:02:09	04/19/05
07:43:09	04/19/05	2	0002.6	08:03:09	04/19/05
07:44:09	04/19/05	2	0002.5	08:04:09	04/19/05
07:45:09	04/19/05	2	0002.5	08:05:09	04/19/05
07:46:09	04/19/05	2	0002.5	08:06:09	04/19/05
07:47:09	04/19/05	2	0002.4	08:07:09	04/19/05
07:48:09	04/19/05	2	0002.5	08:08:09	04/19/05
07:49:09	04/19/05	2	0002.5	08:09:09	04/19/05
				08:10:09	04/19/05
				08:11:09	04/19/05
				08:12:09	04/19/05
				08:13:09	04/19/05
				08:14:09	04/19/05
				08:15:09	04/19/05
				08:16:09	04/19/05
				08:17:09	04/19/05
				08:18:09	04/19/05
				08:19:09	04/19/05
				08:20:09	04/19/05
				08:21:09	04/19/05
				08:22:09	04/19/05
				08:23:09	04/19/05
				08:24:09	04/19/05
				08:25:09	04/19/05
				08:26:09	04/19/05
				08:27:09	04/19/05
				08:28:09	04/19/05
				08:29:09	04/19/05
				08:30:09	04/19/05
				08:31:09	04/19/05

**ANALYZER FIELD DATA**

**Company:** Nucor Steel  
**Location:** Crawfordsville, Indiana  
**Source:** PPF Baghouse #2 - VOC  
**Date:** 4/18/05 - 4/19/05

2	08:32:09	04/19/05	2	08:53:09	04/19/05	2	09:14:09	04/19/05
	0002.3			0002.4			0002.5	
2	08:33:09	04/19/05	2	08:54:09	04/19/05	2	09:15:09	04/19/05
	0002.3			0002.5			0002.8	
2	08:34:09	04/19/05	2	08:55:09	04/19/05	2	09:16:09	04/19/05
	0002.4			0002.6			0003.7	
2	08:35:09	04/19/05	2	08:56:09	04/19/05	2	09:17:09	04/19/05
	0003.0			0002.6			0002.8	
2	08:36:09	04/19/05	2	08:57:09	04/19/05	2	09:18:09	04/19/05
	0002.8			0002.5			0002.5	
2	08:37:09	04/19/05	2	08:58:09	04/19/05	2	09:19:09	04/19/05
	0002.8			0002.5			0002.4	
2	08:38:09	04/19/05	2	08:59:09	04/19/05	2	09:20:09	04/19/05
	0002.8			0002.4			0002.4	
2	08:39:09	04/19/05	2	09:00:09	04/19/05	2	09:21:09	04/19/05
	0002.6			0002.4			0002.4	
2	08:40:09	04/19/05	2	09:01:09	04/19/05	2	09:22:09	04/19/05
	0002.5			0002.4			0002.3	
2	08:41:09	04/19/05	2	09:02:09	04/19/05	2	09:23:09	04/19/05
	0002.5			0003.0			0002.4	
2	08:42:09	04/19/05	2	09:03:09	04/19/05	2	09:24:09	04/19/05
	0002.4			0002.8			0002.4	
2	08:43:09	04/19/05	2	09:04:09	04/19/05	2	09:25:09	04/19/05
	0002.3			0002.5			0002.4	
2	08:44:09	04/19/05	2	09:05:09	04/19/05	2	09:26:09	04/19/05
	0002.3			0002.6			0002.5	
2	08:45:09	04/19/05	2	09:06:09	04/19/05	2	09:27:09	04/19/05
	0002.4			0002.5			0002.5	
2	08:46:09	04/19/05	2	09:07:09	04/19/05	2	09:28:09	04/19/05
	0002.4			0002.4			0002.5	
2	08:47:09	04/19/05	2	09:08:09	04/19/05	2	09:29:09	04/19/05
	0002.4			0002.4			0002.5	
2	08:48:09	04/19/05	2	09:09:09	04/19/05	2	09:30:09	04/19/05
	0002.4			0002.4			0002.5	
2	08:49:09	04/19/05	2	09:10:09	04/19/05	2	09:31:09	04/19/05
	0002.4			0002.4			0002.5	
2	08:50:09	04/19/05	2	09:11:09	04/19/05	2	09:32:09	04/19/05
	0002.4			0002.4			0002.5	
2	08:51:09	04/19/05	2	09:12:09	04/19/05	2	09:33:09	04/19/05
	0002.5			0002.4			0002.4	
2	08:52:09	04/19/05	2	09:13:09	04/19/05	2	09:34:09	04/19/05
	0002.4			0002.5			0002.3	

ANALYZER FIELD DATA

Company: Nucor Steel  
Location: Crawfordsville, Indiana  
Source: PPF Baghouse #2 - VOC  
Date: 4/18/05 - 4/19/05

09:35:09 04/19/05  
2 0002.4  
09:36:09 04/19/05  
2 0002.4  
09:37:09 04/19/05  
2 0002.3  
09:38:09 04/19/05  
2 0002.3  
09:39:09 04/19/05  
2 0002.4  
09:40:09 04/19/05  
2 0002.4  
09:41:09 04/19/05  
2 0002.4  
09:42:09 04/19/05  
2 0002.4  
09:43:09 04/19/05  
2 0002.4  
09:44:09 04/19/05  
2 0002.5  
09:45:09 04/19/05  
2 0002.5  
09:46:09 04/19/05  
2 0002.5  
09:47:09 04/19/05  
2 0003.2  
09:48:09 04/19/05  
2 0003.1  
09:49:09 04/19/05  
2 0003.1  
09:50:09 04/19/05  
2 0003.0  
09:51:09 04/19/05  
2 0003.0  
09:52:09 04/19/05  
2 0002.8

\*\*\*\*\* ON \*\*\*\*\*  
\*\*\*\*\* RUN \*\*\*\*\*

10:12:05 04/19/05  
2 0048.3  
98.6

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*  
\*\*\*\*\* RUN \*\*\*\*\*

10:13:51 04/19/05  
2 0000.6  
zero

**LABORATORY DATA**

**PARTICULATE WEIGHT SHEET**

**Source:** Nucor Steel PPF #2 – Crawfordsville, IN

Date:	04/18/05	04/19/05	04/22/05
<b>Aspirate</b>	<b>Blank</b>	<b>1</b>	<b>2</b>
Run ID#	A-10	A1	A3
Tare Wt	63.8178	66.3444	64.5674
Gross Wt	63.8178	66.3467	64.5708
Correction	0.0000	0.0000	0.0000
Net Wt	0.0000	0.0023	0.0034
<b>Filter</b>	<b>1</b>	<b>2</b>	<b>3</b>
Run ID#	#330	#329	#331
Tare Wt	0.4353	0.4382	0.4400
Gross Wt	0.4368	0.4399	0.4419
Net Wt	0.0015	0.0017	0.0019
<b>Total Gain</b>	<b>0.0038</b>	<b>0.0051</b>	<b>0.0076</b>

# **Air Test Professionals, Inc.**

1201 North Graham Avenue  
Indianapolis, IN 46219

**Nucor Steel-PPFF Baghouse # 2**  
PO# 128

**Analytical Report**  
(0405-92)

***EPA Method 202***  
Condensable particulate

***HPLC Analysis***  
Sulfate



**Enthalpy Analytical, Inc.**

Phone: (919) 850 - 4392 / Fax: (919) 850 - 9012 / [www.enthalpy.com](http://www.enthalpy.com)  
2202 Ellis Road Durham, NC 27703 - 5518



I certify that to the best of my knowledge all analytical data presented in this report:

- Have been checked for completeness
- Are accurate, error-free, and legible
- Have been conducted in accordance with approved protocol, and that all deviations and analytical problems are summarized in the appropriate narrative(s)
- This analytical report was prepared in Portable Document Format (.PDF) and contains 57 pages.



QA Review Performed by: Michael Steven Schapira



# Summary of Results



**EPA Method 202 - Condensable Particulate Determination - Data Analysis**

Company	Air Test Professionals
Analyst	SLG
Parameters	Method 202
# Samples	3 Runs and 1 Blank

Client #	Nucor Steel-PPFF BH-2
Job #	0405-92
PO #	128
Report Date	5/16/05

**Analysis of Particulate Recovery**

Sample ID Number	Run-1	Run-2	Run-3
<i>Organic</i>			
Beaker Number	6827	6832	6839
Final Weight, g	0.9379	0.9422	0.9423
Reweigh, Final, g	0.9378	0.9422	0.9423
Beaker Tare Weight, g	0.9345	0.9390	0.9387
Beaker Tare Reweigh, Initial, g	0.9345	0.9387	0.9386
Solvent Blank, g	0.0017	0.0017	0.0017
MeCl2 FV, mL	230	212	226
Net Organic Catch, mg	1.6	1.8	2.0
<i>Inorganic</i>			
Beaker Number	6873	6879	6895
Final Weight, g	0.9486	0.9537	0.9448
Reweigh, Final, g	0.9485	0.9537	0.9447
Beaker Tare Weight, g	0.9417	0.9374	0.9397
Beaker Tare Reweigh, Initial, g	0.9416	0.9374	0.9396
Water Blank, g	0.0009	0.0008	0.0010
Sample Final Volume, mL	509	479	547
Charge and Rinse Vol, mL	424	395	475
Sulfate aliquot, mL	5.00	5.00	5.00
Sulfate aliquot CF	1.01	1.01	1.01
Net Inorganic CF	1.09	1.09	1.09
Net Inorganic, mg	6.7	17.1	4.6
Sulfate Catch, ug	7,126	26,499	7,158
Sulfate Correction, mg	2.5	9.5	2.6
Total Correction, mg	2.5	9.5	2.6
Corrected Inorganic, mg	4.2	7.6	2.0
Condensable Particulate, mg	5.7	9.4	4.0

**Blank Analysis**

Sample ID Number	MeCl Blank
Beaker Number	6837
Final Weight, g	0.9375
Reweigh, Final, g	0.9376
Initial Weight, g	0.9389
Reweigh, Initial, g	0.9390
MeCl2 Residue, g	-0.0014
MeCl2 Volume, mL	102
Max. MeCl2 Residue, g	0.0014

Sample ID Number	H2O Blank
Beaker Number	6877
Final Weight, g	0.9358
Reweigh, Final, g	0.9358
Initial Weight, g	0.9349
Reweigh, Initial, g	0.9348
Water Residue, g	0.0010
Water Volume, mL	469
Max. Water Residue, g	0.0047

**In-House Blank Analysis**

Sample ID Number	MeCl Blank
Beaker Number	6836
Final Weight, g	0.9390
Reweigh, Final, g	0.9390
Initial Weight, g	0.9365
Reweigh, Initial, g	0.9364
MeCl2 Residue, g	0.0026
MeCl2 Volume, mL	225
Max. MeCl2 Residue, g	0.0030

Sample ID Number	H2O Blank
Beaker Number	6894
Final Weight, g	0.9416
Reweigh, Final, g	0.9416
Initial Weight, g	0.9409
Reweigh, Initial, g	0.9409
Water Residue, g	0.0007
Water Volume, mL	250
Max. Water Residue, g	0.0025

Company	Air Test Professionals
Analyst Initials	TG
Parameters	HPLC Analysis
# Samples	3 Runs & 1 blank

Client #	Nucor Steel-PPFF-BH#2
Job #	0405-92
PO #	128
Report Date	5/16/2005

Compound	Sample ID / Catch Weight (ug)			
	<b>Run 1</b>	<b>Run 2</b>	<b>Run 3</b>	<b>Blank</b>
Sulfate	7,126	26,499	7,158	53.6

# Results



Company Air Test Professionals  
 Analyst Initials TG  
 Parameters HPLC Analysis  
 # Samples 3 Runs & 1 blank

Client # Nucor Steel-PPFF-BH#2  
 Job # 0405-92  
 PO # 128  
 Report Date 5/16/2005

MDL 0.0622 (ug/mL)

LOQ 0.300 (ug/mL)

Compound Sulfate

Lower Curve Limit 0.617 (ug/mL)

Upper Curve Limit 13.0 (ug/mL)

Sample ID	Lab ID # 1	Lab ID # 2	Analysis Method	Ret Time # 1	Ret Time # 2	% Diff Ret	Conc # 1	Conc # 2	% Diff Conc	Avg Conc (ug/mL)	Vol (mL)	DF	Catch Weight (ug)	Qual
Run 1	033-3801.D	033-3802.D	0405-92R.	9.37	9.37	0.1	1.19	1.18	0.6	1.19	60.0	100	7,126	
Run 2	034-3901.D	034-3902.D	0405-92R.	9.36	9.36	0.0	4.44	4.39	0.5	4.42	60.0	100	26,499	
Run 3	035-4001.D	035-4002.D	0405-92R.	9.37	9.37	0.0	1.19	1.19	0.1	1.19	60.0	100	7,158	
Blank	014-1201.D	014-1202.D	0405-92R.	9.37	9.40	0.3	0.898	0.889	0.5	0.893	60.0	1	53.6	
IH Blank	036-4101.D	036-4102.D	0405-92R.	9.40	9.38	0.2	0.468	0.482	1.5	0.475	60.0	1	28.5	
Lab blank	008-0801.D	008-0802.D	0405-92R.	NA	NA	NA	0.0622	0.0622	NA	0.0622	1.00	1	0.0622	ND
MS / Run 2	045-4401.D	045-4402.D	0405-92R.	9.36	9.36	0.0	6.90	6.82	0.5	6.86	1.05	1	7.20	

spike amount (ug) 2.50  
 native amount (ug) 4.42  
 spike recovery 111%

# Narrative Summary



# Enthalpy Analytical Narrative Summary

<b>Company:</b>	Air Test Professionals
<b>Client #:</b>	Nucor Steel-PPFF Baghouse #2
<b>PO #</b>	128

<b>Enthalpy #:</b>	0405-92
<b>Analyst:</b>	SLG / TG
<b>Parameters:</b>	EPA Method 202

**Custody** Craig Mefford of Enthalpy Analytical, Inc. received the samples at 15.8 °C on 4/28/05 after being relinquished by Air Test Professionals, Inc. Prior to analysis the samples were kept under lock with access only by authorized personnel of Enthalpy Analytical, Inc.

**Methodology** All samples were analyzed in accordance to the requirements and specifications of EPA Method 202.

**Instrumentation** All samples were weighed on a Mettler AB265-S (SN-1125163272), certified by Precision Weighing, Inc. through November 8, 2005 (NIST Test # 936770B).

**Labeling** OK

**Reporting Notes** The inorganic and organic catch weights are adjusted by a blank correction value. A mathematically determined (theoretical) maximum value is calculated and compared with the actual value measured for each blank. The lower of the two values is used as the blank correction value, which is then factored by the sample volume divided by the blank volume, and subtracted from the sample's catch weight.

The client's methylene chloride blank had a negative particulate weight. The final value was remeasured again and confirmed the earlier measurements, so it appears that the tare weight must have been wrong. No blank adjustment has been made for the portion of the methylene chloride sample which was from the client. The blank adjustment which does appear in the spreadsheet for the organic fractions is from the 150 mL of Enthalpy's purchased methylene chloride, which is used to complete the sample extraction process.

Enthalpy considers gravimetric analyses for M202  $\pm 0.5$  mg at best. Therefore, negative catch weights between 0 and  $-0.5$  mg are set to zero and no investigation is undertaken. Negative catch weights  $< -0.5$  mg are investigated. None of the catch results for this data set were  $< -0.5$  mg.

We have reported the sulfate result from the analysis of the post-(resuspended liquid) fraction of the samples, rather than the pre-(initial liquid) fraction. This gives the more scientifically correct number.



## Enthalpy Analytical Narrative Summary

Company:	Air Test Professionals	Enthalpy #:	0405-92
Client #:	Nucor Steel-PPFF	Analyst:	TG
PO #:	128	Parameters:	HPLC Analysis

**Custody** Craig Mefford of Enthalpy Analytical, Inc. received the samples at 15.8 °C on 4/28/05 after being relinquished by Air Test Professionals, Inc. Prior to analysis the samples were kept under lock with access only by authorized personnel of Enthalpy Analytical, Inc.

**Analysis** The samples were analyzed for sulfate using a Hewlett-Packard series 1100 High Performance Liquid Chromatograph with a Waters 430 conductivity detector and an Alltech ERIS 1000HP Autosuppressor.

**Separation** Separation was accomplished by a Dionex IonPac AS14A 250 x 4.0 mm analytical column using 8.0 mM Na<sub>2</sub>CO<sub>3</sub>/1.0 mM NaHCO<sub>3</sub> as the eluent at 1.2 mL per minute. A copy of the analytical method (0305-96.M) is included.

Before the sample analyses, a calibration curve was prepared and analyzed.

Sulfate eluted at approximately 9.4 minutes, separated well, and was easily identified.

**Matrix Spike** A matrix spike was prepared by spiking a 1.00-mL aliquot of sample *Run 2* with 2.50 µg of sulfate (50.0 µL of a 50.0 µg/mL solution). The spiked sample was analyzed in the same manner as the other samples. The calculated spike recovery was 111%.

**Reproducibility** OK

**Blank** One blank sample, *Blank*, was analyzed and reported. No blank adjustments were made to any of the reported data.

**Reporting Notes** None.

## General Reporting Notes

The following are general reporting notes that are applicable to all Enthalpy Analytical, Inc. reports, unless specifically noted otherwise.

- The symbol *MDL* represents the Minimum Detection Limit. Below this value the laboratory cannot confirm the presence of the analyte of interest reliably.
- The symbol *LOQ* represents the Limit of Quantification. Below this value the laboratory cannot quantitate the analyte of interest within the criteria of the method.
- The symbol *ND* following a value indicates a non-detect or analytical result below the MDL.
- The symbol *J* following a value indicates an analytical result between the MDL and the LOQ. A J flag indicates that the laboratory can positively identify the analyte of interest as present, but the value should be considered an estimate.
- The symbol *E* following a value indicates an analytical result exceeding 100% of the highest calibration point.
- The symbol *DF* represents a Dilution Factor. This number represents dilutions during the extraction and/or laboratory stages of sample treatment. The analytical result taken from a laboratory instrument is multiplied by the DF to get final results.
- The Sample ID *MS* represents a Matrix Spike. An aliquot of an actual sample is spiked with a known amount of analyte so that a percent recovery value can be determined. This shows what effect the sample matrix may have on the target analyte, i.e. whether or not anything in the sample matrix prohibits analysis for the analyte(s).
- The Sample ID *MSD* represents a Matrix Spike Duplicate. Prepared in the same manner as an MS, the use of duplicate matrix spikes allows further confirmation of laboratory quality by showing the consistency of results gained by performing the same steps multiple times. Most methods performed by Enthalpy do not require analysis of an MSD.
- The Sample ID *BS* represents a Blind Spike. A member of the Quality Assurance department has created BS samples for many of the analytes Enthalpy tests for, and only QA and the Enthalpy Analytical ownership have access to the actual values of these samples. The laboratory analyzes them without knowledge of the actual value, and the spreadsheets get completed for these samples solely by the QA group.
- The Sample ID *LCS* represents a Laboratory Control Sample. Whenever spikes are prepared for our clients more spikes are prepared than needed. The extras (randomly chosen) are kept in-house at the appropriate temperature conditions. When the spike samples come back from the client for analysis, the LCSs (usually two are saved) are analyzed to confirm that the analyte could be recovered from the media, separate from the spike samples which were used on the project and which may have had issues caused during collection and/or transport.
- **Significant Figures:** Where the reported value is much greater than unity (1.00) in the units expressed (specifically values of 1,000 or greater), the number is rounded to a whole number of units, rather than to 3 significant figures. For example, a value of 10,456.45 ug catch is rounded to 10,456 ug. There are five significant digits reported, but no confidence should be placed on more than three significant digits.



# Sample Custody








# ATP - Air Test Professionals, Inc.

1201 North Graham Avenue  
Indianapolis, Indiana 46219

Phone (317) 345-1723  
Fax (317) 351-0411  
Email: atp\_stack@sbcglobal.net

## CHAIN OF CUSTODY RECORD

CUSTOMER INFORMATION		PROJECT INFORMATION				NO. OF CONTAINERS		REMARKS / PRECAUTIONS
COMPANY	PROJECT NAME/NUMBER	SAMPLE DATE	SAMPLE TIME	SAMPLE MATRIX	CONTAINER	PRESERV		
ATP	Nucor Steel - PPFF Baghouse #2	04/18/05		AQ	4 OZ		EPA METHOD 202	
Carlos Brown	BILLING INFORMATION	04/19/05		AQ	4 OZ			
1201 N. Graham Ave.	Same	04/22/05		AQ	4 OZ			
Indianapolis, Indiana 46219								
PHONE: (317) 345-1723								
FAX: (317) 351-0411								
Run 1	MeCl2 Rinse	04/18/05		AQ	4 OZ		1 X	
Run 2	MeCl2 Rinse	04/19/05		AQ	4 OZ		1 X	
Run 3	MeCl2 Rinse	04/22/05		AQ	4 OZ		1 X	
Run 1	DI H2O Rinse	04/18/05		AQ	500 ml		1 X	
Run 2	DI H2O Rinse	04/19/05		AQ	500 ml		1 X	
Run 3	DI H2O Rinse	04/22/05		AQ	500 ml		1 X	
BLANK	Common - MeCl2			AQ	4 OZ		1 X	
BLANK	Common - DI H2O			AQ	500 ml		1 X	
SAMPLER	Carlos Brown	SHIPMENT METHOD:						AIRBILL NO:
REQUIRED TURNAROUND: *								
1. RELINQUISHED BY:		DATE	2. RELINQUISHED BY:		DATE	3. RECEIVED BY:		
SIGNATURE: 		04/27/05	SIGNATURE:			SIGNATURE: 		
PRINTED NAME/COMPANY: ATP		TIME	PRINTED NAME/COMPANY:		TIME	PRINTED NAME/COMPANY: 		
1. RECEIVED BY:		DATE	2. RECEIVED BY:		DATE	3. RECEIVED BY:		
SIGNATURE:			SIGNATURE:			SIGNATURE: 		
PRINTED NAME/COMPANY:		TIME	PRINTED NAME/COMPANY:		TIME	PRINTED NAME/COMPANY: 		
						DATE: 4/24/05		
						TIME: 9:30		

← USE COMMON  
BLANKS - ISSUE  
SEPARATE REPORTS.


T = 15.8°C

# Sample Chromatograms



```

=====
Injection Date   : 5/12/2005 12:40:32 PM      Seq. Line :   38
Sample Name     : Run 1 Post*100              Location  : Vial 33
Acq. Operator  : TG                          Inj       :    1
Acq. Instrument : Gonzo                       Inj Volume: 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/12/2005 12:38:21 PM by TG
                  (modified after loading)
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 1:03:27 PM
                  (modified after loading)
=====
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 1:03:25 PM
Multiplier    : 1.0000
Dilution      : 1.0000
    
```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.374	MM	57.49072	2.07782e-2	1.19455	Sulfate	Manual Integration (TG)


Totals : 1.19455

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date : 5/12/2005 12:54:44 PM      Seq. Line : 38
Sample Name    : Run 1 Post*100             Location  : Vial 33
Acq. Operator  : TG                        Inj      : 2
Acq. Instrument : Gonzo                    Inj Volume : 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/12/2005 12:52:43 PM by TG
                (modified after loading)
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 1:03:27 PM
                (modified after loading)
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 1:03:25 PM
Multiplier     : 1.0000
Dilution       : 1.0000
    
```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.367	MM	56.73701	2.08125e-2	1.18084	Sulfate	Manual Integration (TG)


Totals : 1.18084

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date   : 5/12/2005 1:09:09 PM      Seq. Line :   39
Sample Name     : Run 2 Post*100             Location  : Vial 34
Acq. Operator   : TG                        Inj       :    1
Acq. Instrument : Gonzo                     Inj Volume: 25 µl
Acq. Method     : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed    : 5/12/2005 1:06:54 PM by TG
                  (modified after loading)
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed    : 5/12/2005 1:03:27 PM
                  (modified after loading)
=====
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 1:03:25 PM
Multiplier     : 1.0000
Dilution       : 1.0000
    
```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.364	BB	235.80093	1.88240e-2	4.43872		Sulfate

Totals : 4.43872


Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*



```

=====
Injection Date   : 5/12/2005 1:23:28 PM      Seq. Line : 39
Sample Name     : Run 2 Post*100             Location  : Vial 34
Acq. Operator  : TG                          Inj      : 2
Acq. Instrument : Gonzo                       Inj Volume: 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/12/2005 1:21:20 PM by TG
                (modified after loading)
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 1:03:27 PM
                (modified after loading)
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 1:03:25 PM
Multiplier    : 1.0000
Dilution      : 1.0000
    
```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.361	BB	233.35565	1.88306e-2	4.39423		Sulfate


Totals : 4.39423

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date   : 5/12/2005 1:37:49 PM      Seq. Line : 40
Sample Name     : Run 3 Post*100             Location  : Vial 35
Acq. Operator  : TG                          Inj       : 1
Acq. Instrument : Gonzo                      Inj Volume: 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/12/2005 1:35:40 PM by TG
                  (modified after loading)
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 1:03:27 PM
                  (modified after loading)
=====
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 1:03:25 PM
Multiplier    : 1.0000
Dilution      : 1.0000
    
```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.367	MM	57.47750	2.07788e-2	1.19431		Sulfate <span style="border: 1px solid black; padding: 2px;">Manual Integration (TG)</span>

Totals : 1.19431


Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date : 5/12/2005 1:52:08 PM      Seq. Line : 40
Sample Name    : Run 3 Post*100             Location  : Vial 35
Acq. Operator  : TG                        Inj      : 2
Acq. Instrument : Gonzo                    Inj Volume : 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/12/2005 1:49:59 PM by TG
                (modified after loading)
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 1:03:27 PM
                (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 1:03:25 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.371	MM	57.32795	2.07856e-2	1.19159	Sulfate	Manual Integration (TG)

Totals : 1.19159

Results obtained with enhanced integrator!


```

=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 5/12/2005 12:12:13 AM      Seq. Line   : 12
Sample Name     : Blank Post                  Location    : Vial 14
Acq. Operator  : TG                          Inj         : 1
Acq. Instrument : Gonzo                      Inj Volume  : 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/12/2005 12:10:01 AM by TG
                (modified after loading)
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 1:03:27 PM
                (modified after loading)
=====
    
```



External Standard Report

```

=====
Sorted By      : Signal
Calib. Data Modified : 5/12/2005 1:03:25 PM
Multiplier    : 1.0000
Dilution      : 1.0000
    
```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.372	MM	41.16916	2.18028e-2	8.97601e-1	Sulfate	Manual Integration (TG)


Totals : 8.97601e-1

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date : 5/12/2005 12:26:36 AM      Seq. Line : 12
Sample Name    : Blank Post                  Location  : Vial 14
Acq. Operator  : TG                        Inj       : 2
Acq. Instrument : Gonzo                    Inj Volume: 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/12/2005 12:24:25 AM by TG
                (modified after loading)
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 1:03:27 PM
                (modified after loading)
=====
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 1:03:25 PM
Multiplier     : 1.0000
Dilution       : 1.0000
    
```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.397	MM	40.67235	2.18468e-2	8.88562e-1	Sulfate	Manual Integration (TG)


Totals : 8.88562e-1

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date   : 5/12/2005 2:06:30 PM      Seq. Line :   41
Sample Name     : IH Blank Post              Location  : Vial 36
Acq. Operator   : TG                        Inj       :    1
Acq. Instrument : Gonzo                     Inj Volume: 25 µl
Acq. Method     : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed    : 5/12/2005 2:04:21 PM by TG
                  (modified after loading)
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed    : 5/12/2005 1:03:27 PM
                  (modified after loading)
=====
    
```



External Standard Report

```

=====
Sorted By       : Signal
Calib. Data Modified : 5/12/2005 1:03:25 PM
Multiplier      : 1.0000
Dilution        : 1.0000
    
```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.398	MM	19.51635	2.39646e-2	4.67701e-1		Sulfate <span style="border: 1px solid black; padding: 2px;">Manual Integration (TG)</span>


Totals : 4.67701e-1

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date : 5/12/2005 2:20:55 PM      Seq. Line : 41
Sample Name    : IH Blank Post              Location  : Vial 36
Acq. Operator  : TG                        Inj      : 2
Acq. Instrument : Gonzo                    Inj Volume : 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/12/2005 2:20:32 PM by TG
                (modified after loading)
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 1:03:27 PM
                (modified after loading)
=====
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 1:03:25 PM
Multiplier     : 1.0000
Dilution       : 1.0000
    
```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.379	MM	20.12613	2.39646e-2	4.82314e-1	Sulfate	Manual Integration (TG)

Totals : 4.82314e-1


Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date   : 5/11/2005 10:16:59 PM      Seq. Line :    8
Sample Name     : Lab blank                   Location  : Vial 8
Acq. Operator  : TG                          Inj       :    1
Acq. Instrument : Gonzo                      Inj Volume: 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/7/2005 3:14:56 PM by TG
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 12:35:10 PM
                (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 12:35:08 PM
Multiplier     : 1.0000
Dilution      : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.360	-	-	-	-	-	Sulfate

Totals : 0.00000

Results obtained with enhanced integrator!

1 Warnings or Errors :


Warning : Calibrated compound(s) not found



```

=====
Injection Date : 5/11/2005 10:31:25 PM      Seq. Line : 8
Sample Name    : Lab blank                    Location  : Vial 8
Acq. Operator : TG                           Inj      : 2
Acq. Instrument : Gonzo                       Inj Volume : 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/11/2005 10:31:02 PM by TG
                  (modified after loading)
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 12:35:10 PM
                  (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 12:35:08 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.360	-	-	-	-	-	Sulfate

Totals : 0.00000


```

Results obtained with enhanced integrator!
1 Warnings or Errors :
Warning : Calibrated compound(s) not found
=====

```

```

=====
Injection Date   : 5/12/2005 3:32:47 PM           Seq. Line :   44
Sample Name     : MSRun 2 Post*100                Location  : Vial 45
Acq. Operator  : TG                               Inj       :    1
Acq. Instrument : Gonzo                           Inj Volume: 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/12/2005 3:30:38 PM by TG
                  (modified after loading)
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 7:04:37 PM by TG
                  (modified after loading)
=====
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 7:04:40 PM
Multiplier    : 1.0000
Dilution      : 1.0000
Use Multiplier & Dilution Factor with ISTDs
    
```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.360	BB	370.82919	1.85946e-2	6.89541		Sulfate


Totals : 6.89541

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date : 5/12/2005 3:47:09 PM      Seq. Line : 44
Sample Name    : MSRUn 2 Post*100          Location  : Vial 45
Acq. Operator  : TG                        Inj       : 2
Acq. Instrument : Gonzo                    Inj Volume: 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/12/2005 3:44:59 PM by TG
                (modified after loading)
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 7:04:37 PM by TG
                (modified after loading)
=====
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 7:04:40 PM
Multiplier     : 1.0000
Dilution       : 1.0000
Use Multiplier & Dilution Factor with ISTDs
    
```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.363	BB	366.86438	1.85989e-2	6.82328		Sulfate

Totals : 6.82328

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

# **Curve(s)/QA Point(s) Chromatograms**



=====  
 Calibration Table  
 =====

Calib. Data Modified : 5/12/2005 12:32:42 PM

Calculate : External Standard  
 Based on : Peak Area

Rel. Reference Window : 5.000 %  
 Abs. Reference Window : 0.000 min  
 Rel. Non-ref. Window : 5.000 %  
 Abs. Non-ref. Window : 0.000 min  
 Uncalibrated Peaks : not reported  
 Partial Calibration : Yes, identified peaks are recalibrated  
 Correct All Ret. Times: No, only for identified peaks

Curve Type : Linear  
 Origin : Connected  
 Weight : Equal

Recalibration Settings:  
 Average Response : Average all calibrations  
 Average Retention Time: Floating Average New 75%

Calibration Report Options :  
 Printout of recalibrations within a sequence:  
 Calibration Table after Recalibration  
 Normal Report after Recalibration  
 If the sequence is done with bracketing:  
 Results of first cycle (ending previous bracket)


Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Lvl Sig	Amount [ng/ul]	Area	Amt/Area	Ref Grp Name
9.360	1	6.17000e-1	33.42069	1.84616e-2	Sulfate
	2	2.38000	125.84741	1.89118e-2	
	3	4.55000	229.45097	1.98299e-2	
	4	6.52000	344.49469	1.89263e-2	
	5	9.18000	499.86865	1.83648e-2	
	6	13.00000	710.17908	1.83052e-2	

=====  
 Peak Sum Table  
 =====

\*\*\*No Entries in table\*\*\*  
 =====

=====  
 Calibration Curves  
 =====




Sulfate at exp. RT: 9.360  
 ADC1 B, Dionex ED 40  
 Correlation: 0.99955  
 Residual Std. Dev.: 8.42160  
 Formula:  $y = mx + b$   
 m: 54.96338  
 b: -8.16605  
 x: Amount[ng/ul]  
 y: Area

```

=====
Injection Date   : 5/11/2005 6:55:56 PM      Seq. Line :    1
Sample Name     : Standard 1                 Location  : Vial 1
Acq. Operator   : TG                        Inj       :    1
Acq. Instrument : Gonzo                     Inj Volume: 25 µl
Acq. Method     : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed    : 5/7/2005 3:14:56 PM by TG
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed    : 5/12/2005 12:35:10 PM
                  (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : 5/12/2005 12:35:08 PM
Multiplier      : 1.0000
Dilution        : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.348	MM	33.48057	2.26315e-2	7.57716e-1	Sulfate	Manual Integration (TG)

Totals : 7.57716e-1

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date : 5/11/2005 7:09:57 PM      Seq. Line : 1
Sample Name    : Standard 1                Location  : Vial 1
Acq. Operator  : TG                       Inj      : 2
Acq. Instrument : Gonzo                   Inj Volume : 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/7/2005 3:14:56 PM by TG
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 12:35:10 PM
                (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 12:35:08 PM
Multiplier     : 1.0000
Dilution      : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.377	MM	33.28167	2.26580e-2	7.54097e-1	Sulfate	Manual Integration (TG)

Totals : 7.54097e-1

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date : 5/11/2005 7:24:20 PM      Seq. Line : 2
Sample Name    : Standard 2                  Location  : Vial 2
Acq. Operator  : TG                          Inj       : 1
Acq. Instrument : Gonzo                      Inj Volume: 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/7/2005 3:14:56 PM by TG
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 12:35:10 PM
                (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 12:35:08 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.356	MM	123.02875	1.94016e-2	2.38695	Sulfate	Manual Integration (TG)

Totals : 2.38695

Results obtained with enhanced integrator!

```

=====
*** End of Report ***


```



```

=====
Injection Date   : 5/11/2005 7:39:06 PM      Seq. Line :    2
Sample Name     : Standard 2                 Location  : Vial 2
Acq. Operator   : TG                        Inj       :    2
Acq. Instrument : Gonzo                     Inj Volume: 25 µl
Acq. Method     : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed    : 5/7/2005 3:14:56 PM by TG
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed    : 5/12/2005 12:35:10 PM
                  (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 12:35:08 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.375	MM	126.69941	1.93666e-2	2.45373	Sulfate	Manual Integration (TG)

Totals : 2.45373

Results obtained with enhanced integrator!

```

=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 5/11/2005 7:53:27 PM           Seq. Line :    3
Sample Name     : Standard 3                       Location  : Vial 3
Acq. Operator   : TG                               Inj       :    1
Acq. Instrument : Gonzo                            Inj Volume: 25 µl
Acq. Method     : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed    : 5/7/2005 3:14:56 PM by TG
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed    : 5/12/2005 12:35:10 PM
                  (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : 5/12/2005 12:35:08 PM
Multiplier      : 1.0000
Dilution        : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.360	BB	227.82349	1.88461e-2	4.29358		Sulfate

Totals : 4.29358

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date : 5/11/2005 8:07:50 PM      Seq. Line : 3
Sample Name    : Standard 3                 Location  : Vial 3
Acq. Operator  : TG                        Inj      : 2
Acq. Instrument : Gonzo                    Inj Volume : 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/7/2005 3:14:56 PM by TG
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 12:35:10 PM
                (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 12:35:08 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.360	BB	231.07845	1.88369e-2	4.35280		Sulfate

Totals : 4.35280

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 5/11/2005 8:22:09 PM      Seq. Line :    4
Sample Name     : Standard 4                 Location  : Vial 4
Acq. Operator  : TG                          Inj       :    1
Acq. Instrument : Gonzo                      Inj Volume: 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/7/2005 3:14:56 PM by TG
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 12:35:10 PM
                (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 12:35:08 PM
Multiplier    : 1.0000
Dilution      : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.358	BB	343.51971	1.86264e-2	6.39855		Sulfate

Totals : 6.39855

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date : 5/11/2005 8:36:33 PM      Seq. Line : 4
Sample Name    : Standard 4                 Location  : Vial 4
Acq. Operator  : TG                        Inj       : 2
Acq. Instrument : Gonzo                    Inj Volume: 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/7/2005 3:14:56 PM by TG
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 12:35:10 PM
                (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 12:35:08 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.360	BB	345.46967	1.86240e-2	6.43402		Sulfate

Totals : 6.43402

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 5/11/2005 8:50:56 PM      Seq. Line :    5
Sample Name     : Standard 5                 Location  : Vial 5
Acq. Operator   : TG                        Inj       :    1
Acq. Instrument : Gonzo                     Inj Volume: 25 µl
Acq. Method     : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed    : 5/7/2005 3:14:56 PM by TG
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed    : 5/12/2005 12:35:10 PM
                  (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : 5/12/2005 12:35:08 PM
Multiplier      : 1.0000
Dilution        : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.351	BB	500.49374	1.84908e-2	9.25452		Sulfate

Totals : 9.25452

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date : 5/11/2005 9:05:13 PM      Seq. Line : 5
Sample Name    : Standard 5                  Location  : Vial 5
Acq. Operator  : TG                          Inj      : 2
Acq. Instrument : Gonzo                       Inj Volume : 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
ast changed   : 5/7/2005 3:14:56 PM by TG
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 12:35:10 PM
                (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 12:35:08 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.362	BB	499.24356	1.84915e-2	9.23178		Sulfate

Totals : 9.23178

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 5/11/2005 9:19:34 PM      Seq. Line   :    6
Sample Name     : Standard 6                 Location    : Vial 6
Acq. Operator   : TG                        Inj         :    1
Acq. Instrument : Gonzo                     Inj Volume  : 25 µl
Acq. Method     : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed    : 5/7/2005 3:14:56 PM by TG
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed    : 5/12/2005 12:35:10 PM
                  (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : 5/12/2005 12:35:08 PM
Multiplier      : 1.0000
Dilution        : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.355	BB	711.78613	1.84027e-2	13.09876		Sulfate

Totals : 13.09876

Results obtained with enhanced integrator!

```

=====
*** End of Report ***
=====


```



```

=====
Injection Date : 5/11/2005 9:33:52 PM      Seq. Line : 6
Sample Name    : Standard 6                 Location  : Vial 6
Acq. Operator  : TG                        Inj       : 2
Acq. Instrument : Gonzo                    Inj Volume: 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/7/2005 3:14:56 PM by TG
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 12:35:10 PM
                (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 12:35:08 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.348	BB	708.57202	1.84036e-2	13.04028		Sulfate

Totals : 13.04028

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 5/11/2005 9:48:17 PM      Seq. Line :    7
Sample Name     : Standard SS                Location  : Vial 7
Acq. Operator   : TG                        Inj       :    1
Acq. Instrument : Gonzo                     Inj Volume: 25 µl
Acq. Method     : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed    : 5/7/2005 3:14:56 PM by TG
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed    : 5/12/2005 12:35:10 PM
                  (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : 5/12/2005 12:35:08 PM
Multiplier      : 1.0000
Dilution        : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.361	BB	223.26709	1.88594e-2	4.21068	Sulfate	4.55 ug/ml

Totals : 4.21068

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date : 5/11/2005 10:02:36 PM      Seq. Line : 7
Sample Name    : Standard SS                 Location  : Vial 7
Acq. Operator  : TG                         Inj      : 2
Acq. Instrument : Gonzo                     Inj Volume : 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/7/2005 3:14:56 PM by TG
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 12:35:10 PM
                (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 12:35:08 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.357	BB	221.80493	1.88638e-2	4.18408		Sulfate 4.55 ug/ml

Totals : 4.18408

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 5/12/2005 2:35:52 AM      Seq. Line : 17
Sample Name     : Standard 3                 Location  : Vial 3
Acq. Operator  : TG                          Inj       : 1
Acq. Instrument : Gonzo                      Inj Volume: 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/12/2005 2:33:34 AM by TG
                (modified after loading)
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 12:35:10 PM
                (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : 5/12/2005 12:35:08 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.370	BB	230.96286	1.88372e-2	4.35069		Sulfate

Totals : 4.35069

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date : 5/12/2005 2:50:15 AM      Seq. Line : 17
Sample Name    : Standard 3                 Location  : Vial 3
Acq. Operator  : TG                        Inj      : 2
Acq. Instrument : Gonzo                    Inj Volume : 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/12/2005 2:48:01 AM by TG
                (modified after loading)
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 12:35:10 PM
                (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 12:35:08 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.364	BB	230.24608	1.88392e-2	4.33765		Sulfate

Totals : 4.33765

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 5/12/2005 8:21:21 AM      Seq. Line : 29
Sample Name     : Standard 3                 Location  : Vial 3
Acq. Operator   : TG                       Inj       : 1
Acq. Instrument : Gonzo                     Inj Volume: 25 µl
Acq. Method     : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed    : 5/12/2005 8:20:58 AM by TG
                  (modified after loading)
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed    : 5/12/2005 12:35:10 PM
                  (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : 5/12/2005 12:35:08 PM
Multiplier      : 1.0000
Dilution        : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.376	BB	241.47716	1.88092e-2	4.54199		Sulfate

Totals : 4.54199

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date : 5/12/2005 8:35:40 AM      Seq. Line : 29
Sample Name    : Standard 3                Location  : Vial 3
Acq. Operator  : TG                       Inj      : 2
Acq. Instrument : Gonzo                   Inj Volume : 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/12/2005 8:33:33 AM by TG
                (modified after loading)
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 12:35:10 PM
                (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 12:35:08 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.375	BB	232.51897	1.88329e-2	4.37901		Sulfate

Totals : 4.37901

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date : 5/12/2005 12:11:18 PM      Seq. Line : 37
Sample Name    : Standard 3                  Location  : Vial 3
Acq. Operator  : TG                          Inj       : 1
Acq. Instrument : Gonzo                      Inj Volume: 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/12/2005 12:11:20 PM by TG
                (modified after loading)
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 12:35:10 PM
                (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 12:35:08 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.367	BB	234.99467	1.88262e-2	4.42405		Sulfate

Totals : 4.42405

Results obtained with enhanced integrator!

```

=====
*** End of Report ***
=====


```



```

=====
Injection Date : 5/12/2005 12:26:08 PM      Seq. Line : 37
Sample Name    : Standard 3                  Location  : Vial 3
Acq. Operator  : TG                          Inj      : 2
Acq. Instrument : Gonzo                      Inj Volume : 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/12/2005 12:23:52 PM by TG
                (modified after loading)
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 12:35:10 PM
                (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 12:35:08 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.362	BB	234.22632	1.88282e-2	4.41007		Sulfate

Totals : 4.41007

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 5/12/2005 4:58:54 PM      Seq. Line : 47
Sample Name     : Standard 3                 Location  : Vial 3
Acq. Operator  : TG                          Inj       : 1
Acq. Instrument : Gonzo                      Inj Volume: 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/12/2005 4:58:32 PM by TG
                  (modified after loading)
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 7:04:37 PM by TG
                  (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By           : Signal
Calib. Data Modified : 5/12/2005 7:04:40 PM
Multiplier          : 1.0000
Dilution            : 1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.360	BB	237.80737	1.88187e-2	4.47522		Sulfate

Totals : 4.47522

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date : 5/12/2005 5:13:22 PM      Seq. Line : 47
Sample Name    : Standard 3                Location  : Vial 3
Acq. Operator  : TG                       Inj      : 2
Acq. Instrument : Gonzo                   Inj Volume : 25 µl
Acq. Method    : H:\LC2005Q2\GONZO\METHODS\0305-96.M
Last changed   : 5/12/2005 5:11:07 PM by TG
                (modified after loading)
Analysis Method : H:\LC2005Q2\GONZO\METHODS\0405-92R.M
Last changed   : 5/12/2005 7:04:37 PM by TG
                (modified after loading)
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : 5/12/2005 7:04:40 PM
Multiplier     : 1.0000
Dilution       : 1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ng/ul]	Grp	Name
9.361	BB	238.40685	1.88171e-2	4.48613		Sulfate

Totals : 4.48613

Results obtained with enhanced integrator!

```

=====
*** End of Report ***
=====

```

Sequence Table:

Method and Injection Info Part:

Line	Location	SampleName	Method	Inj	SampleType	InjVolume	DataFile
1	Vial 1	Standard 1	0305-96	2	Sample		
2	Vial 2	Standard 2	0305-96	2	Sample		
3	Vial 3	Standard 3	0305-96	2	Sample		
4	Vial 4	Standard 4	0305-96	2	Sample		
5	Vial 5	Standard 5	0305-96	2	Sample		
6	Vial 6	Standard 6	0305-96	2	Sample		
7	Vial 7	Standard SS	0305-96	2	Sample		
8	Vial 8	Lab blank	0305-96	2	Sample		
<del>9</del>	<del>Vial 11</del>	<del>Run 1 Post*10</del>	<del>0305-96</del>	<del>2</del>	<del>Sample</del>		
10	Vial 12	Run 2 Post*10	0305-96	2	Sample		
11	Vial 13	Run 3 Post*10	0305-96	2	Sample		
12	Vial 14	Blank Post	0305-96	2	Sample		
13	Vial 15	IH Blank Post	0305-96	2	Sample		
14	Vial 16	Run 1 Pre	0305-96	2	Sample		
15	Vial 17	Run 2 Pre	0305-96	2	Sample		
16	Vial 18	Run 3 Pre	0305-96	2	Sample		
17	Vial 3	Standard 3	0305-96	2	Sample		
18	Vial 4	Standard 4	0305-96	2	Sample		
19	Vial 19	Blank Pre	0305-96	2	Sample		
20	Vial 20	IHBlank Pre	0305-96	2	Sample		
21	Vial 21	E1ProbePost*10	0305-96	2	Sample		
22	Vial 22	E1ImpPost*100	0305-96	2	Sample		
23	Vial 23	E6ProbePost*10	0305-96	2	Sample		
24	Vial 24	E6ImpPost*100	0305-96	2	Sample		
25	Vial 25	Blank Post	0305-96	2	Sample		
26	Vial 26	IH Blank Post	0305-96	2	Sample		
27	Vial 27	E1ProbePre*10	0305-96	2	Sample		
28	Vial 28	E1ImpPre*10	0305-96	2	Sample		
29	Vial 3	Standard 3	0305-96	2	Sample		
30	Vial 4	Standard 4	0305-96	2	Sample		
31	Vial 29	E6ProbePre*10	0305-96	2	Sample		
32	Vial 30	E6ImpPre*10	0305-96	2	Sample		
33	Vial 41	Blank Post	0305-96	2	Sample		
34	Vial 42	Blank Pre	0305-96	2	Sample		
35	Vial 31	Blank Pre	0305-96	2	Sample		
36	Vial 32	IH Blank Pre	0305-96	2	Sample		
37	Vial 3	Standard 3	0305-96	2	Sample		
38	Vial 33	Run 1 Post*100	0305-96	2	Sample		
39	Vial 34	Run 2 Post*100	0305-96	2	Sample		
40	Vial 35	Run 3 Post*100	0305-96	2	Sample		
41	Vial 36	IH Blank Post	0305-96	2	Sample		
42	Vial 43	Run 3 Post*50	0305-96	2	Sample		
43	Vial 44	MS/Run 3 Post*50	0305-96	2	Sample		
44	Vial 45	MSRun 2 Post*100	0305-96	2	Sample		
45	Vial 46	MSE1ProbePost*10	0305-96	2	Sample		
46	Vial 37	Run 1 Pre	0305-96	2	Sample		
47	Vial 3	Standard 3	0305-96	2	Sample		
48	Vial 38	Run 2 Pre	0305-96	2	Sample		
49	Vial 39	Run 3 Pre	0305-96	2	Sample		
50	Vial 40	IH Blank Pre	0305-96	2	Sample		
51	Vial 47	Run 2 Pre*10	0305-96	2	Sample		
52	Vial 48	Run 3 Pre*2	0305-96	2	Sample		
53	Vial 3	Standard 3	0305-96	2	Sample		

Method Information

Dionex IonPac AS-14A 4-mm analytical (4x250mm) column.  
Flow rate 1.2 mL/min  
8mM Na<sub>2</sub>CO<sub>3</sub>/1mM NaHCO<sub>3</sub> mobile phase  
Suppressed anion conductivity detection

=====

ANALOG DIGITAL CONVERTER

=====

Signal 1

-----

Description:	Waters 430
Source:	Signal
Unit:	uS
Units/Volt:	1000.000
Peakwidth (Data Rate):	0.053 Min (5.00 Hz)
Stop Time:	No Limit
Data Storage:	Partial:
Start data:	0.01 Min
Stop data:	0.01 Min

Start Signal Source: External Device Will Start 35900

Timed Event Table:  
<no events>

=====

1100 Quaternary Pump 1

=====

Control

Column Flow : 1.200 ml/min  
Stoptime : 12.00 min  
Posttime : Off

Solvents

Solvent A : 0.0 % ( )  
Solvent B : 0.0 % ( )  
Solvent C : 100.0 % (8.0mM Na2CO3/1.0mM NaHCO3)  
Solvent D : Off

PressureLimits

Minimum Pressure : 0 bar  
Maximum Pressure : 400 bar

Auxiliary

Maximal Flow Ramp : 100.00 ml/min^2  
Primary Channel : Auto  
Compressibility :  $83 \times 10^{-6}$ /bar  
Minimal Stroke : Auto

Store Parameters

Store Ratio A : Yes  
Store Ratio B : Yes  
Store Ratio C : Yes  
Store Ratio D : Yes  
Store Flow : Yes  
Store Pressure : Yes

=====

Agilent 1100 Autosampler 1

=====

Injection

Injection Mode : Needle Wash  
Injector volume : 25.00 µl  
Wash Vial : 100  
Optimization : none

Auxiliary

Drawspeed : 100 µl/min  
Ejectspeed : 1000 µl/min  
Draw position : 2.0 mm

Time

Stoptime : As Pump  
Posttime : Off

=====


Agilent 1100 Column Thermostat 1

=====

Temperature settings

Left temperature : 30.0°C  
Right temperature : Same as left  
Enable analysis : When Temp. is within setpoint +/- 0.8°C  
Store left temperature : No  
Store right temperature : No

Time  
Stoptime : As pump  
Posttime : Off  
Column Switching Valve : Column 1





## **Air Test Professionals, Inc.**


1201 North Graham Avenue  
Indianapolis, IN 46219

Project Number: PPF #2

Antimony, Arsenic, Barium,  
Beryllium, Cadmium, Chromium,  
Cobalt, Copper, Lead,  
Manganese, Mercury, Nickel,  
Phosphorus, Selenium,  
Silver, Thallium, and Zinc

EPA Method 29 Analysis


Analytical Report  
5025



Element One, Inc.  
5022-C Wrightsville Av., Wilmington, NC 28403  
910-793-0128 FAX: 910-792-6853 e1lab@e1lab.com

The following data for Analytical Report 5025  
has been reviewed for completeness, accuracy,  
adherence to method protocol,  
and compliance with quality assurance guidelines.

Quality Assurance Review by:



Daphne Woodman, Chemist  
May 6, 2005

Report Reviewed and Finalized By:



Ken Smith, Laboratory Director  
May 6, 2005

el<sub>1</sub>

# SUMMARY OF RESULTS

el<sub>1</sub>

## Summary of Analysis

### Summary of Mercury Analysis

Run Number		Average Total Front half Catch, µg	µg	H <sub>2</sub> O <sub>2</sub> /HNO <sub>3</sub> µg	Empty Imp. µg	KMnO <sub>4</sub> µg
Run 1	#1	12.0	< 0.1	8.41	< 0.2	3.53
	#2		< 0.1	8.55	< 0.2	3.58
Run 2	#1	13.1	< 0.1	8.01	< 0.2	5.11
	#2		< 0.1	7.97	< 0.2	5.15
Run 3	#1	12.4	< 0.1	4.61	< 0.2	7.79
	#2		< 0.1	4.61	< 0.2	7.76
Reagent Blank	#1	< 0.4	< 0.1	< 0.3	< 0.2	< 0.4
	#2		< 0.1	< 0.3	< 0.2	< 0.4

### Summary of Metals Analysis

Element	Run 1 Total µg	Run 2 Total µg	Run 2 Total µg	Run 3 Total µg	Reagent Blank Total µg
Antimony	1.78	< 0.5	< 0.5	< 0.5	< 0.5
Arsenic	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
Barium	2.48	2.51	2.40	2.27	1.98
Beryllium	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05
Cadmium	< 0.2	< 0.2	< 0.2	0.38	< 0.2
Chromium	3.05	2.08	1.91	1.72	0.82
Cobalt	0.87	1.31	1.24	< 0.5	< 0.5
Copper	14.8	7.87	7.52	6.53	0.63
Lead	1.82	1.96	1.92	1.91	< 0.5
Manganese	22.8	8.88	8.30	9.07	0.89
Nickel	3.00	2.34	2.22	1.78	0.87
Phosphorus	24.8	33.3	31.6	14.8	19.2
Selenium	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
Silver	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
Thallium	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
Zinc	52.7	60.9	57.3	63.4	2.10

# ANALYTICAL NARRATIVE

el<sub>1</sub>

## Element One Analytical Narrative

Client	Air Test Professionals, Inc.	Element One #:	5025
Client ID:	PPFF #2- Nucor Steel	Analyst:	DBW, CML, IJJ
Method:	M29	Date Received	4/21/05
Analytes	Sb, As, Ba, Be, Cd, Cr, Co, Cu, Pb, Mn, Ni, P, Se, Ag, Tl, Zn, & Hg	Dates Analyzed	4/27-28/05

### Summary of Analysis

The Method 29 samples were digested, prepared, and analyzed according to Method 29 protocol. Samples were analyzed for mercury on a PerkinElmer FIMS-100 CVAA mercury analyzer. The other metals were analyzed on a PerkinElmer ELAN 6100 ICP-MS.

### Detection Limits

The FIMS-100 CVAA instrument reporting limit for mercury was 0.004 µg per aliquot analyzed. The ICP-MS instrument reporting limits were 0.25 µg/L for beryllium, 1 µg/L for cadmium, 20 µg/L for phosphorus, and 2.5 µg/L for the other metals.

### Analysis QA/QC

Duplicate analyses relative percent difference (RPD), spike sample recovery, and second source calibration verification data are summarized in the Quality Control Section. All QA/QC data was within the criteria of the method.

### Additional Comments

The reported results have not been corrected for any blank or spike recovery values. Nothing unusual was noticed in the analyses, with the exception of the phosphorous in the reagent blank. The phosphorous in the reagent blank was noticeably high; therefore, the reagent blank was reanalyzed to verify its data.

# QUALITY CONTROL SUMMARY

el<sub>1</sub>

## Summary of Quality Control Data

### Mercury Duplicate Analysis RPD

Run Number	Front half	H <sub>2</sub> O <sub>2</sub> /HNO <sub>3</sub>	Empty Imp	KMnO <sub>4</sub>
Run 1	NA	1.6%	NA	1.4%
Run 2	NA	0.6%	NA	0.8%
Run 3	NA	0.1%	NA	0.3%
Reagent Blank	NA	NA	NA	NA

### Mercury Spike Recoveries

Run Number		Front half	H <sub>2</sub> O <sub>2</sub> /HNO <sub>3</sub>	Empty Imp	KMnO <sub>4</sub>
Run 3	# 1	110%	103%	101%	91%
	# 2	101%	106%	98%	92%



## Summary of Quality Control Data

### Metals Duplicate Analysis RPD and Spike Recoveries

Element	Run 2 RPD	Run 3 Recovery
Antimony	NA	104%
Arsenic	NA	110%
Barium	4.6%	89%
Beryllium	NA	110%
Cadmium	NA	96%
Chromium	8.7%	107%
Cobalt	5.0%	116%
Copper	4.6%	111%
Lead	2.2%	112%
Manganese	6.8%	114%
Nickel	5.5%	121%
Phosphorus	5.4%	82%
Selenium	NA	86%
Silver	NA	89%
Thallium	NA	109%
Zinc	6.0%	100%

### Second Source Calibration Check Recoveries

Element	0.25 ppb	1 ppb	100 ppb	200 ppb
Antimony		133%	103%	96%
Arsenic		96%	102%	97%
Barium		109%	102%	97%
Beryllium	100%	99%	98%	94%
Cadmium		105%	103%	97%
Chromium		100%	104%	99%
Cobalt		113%	103%	98%
Copper		116%	108%	104%
Lead		115%	105%	98%
Manganese		115%	104%	98%
Nickel		105%	103%	99%
Phosphorus		115%	96%	107%
Selenium		116%	101%	97%
Silver		100%	102%	70%
Thallium		114%	104%	97%
Zinc		118%	106%	101%

# ANALYTICAL DATA

el<sub>1</sub>

Project ID/ Number:

Nucor Steel / PPF #2

Client: <b>Air Test Professionals, Inc.</b>	Date / Time Received: 4/21/05 / 16155
---	---------------------------------------

HNO <sub>3</sub> Lot: 1104050	HF Lot: 5104011	HCl Lot: 1104060	Ref. Method: 29
Volume Marked (Y)/N	Volume Loss Y/(N)?	pH < 2.0 (Y)/N	

	Sample Identification		Sample Identification
1	Run 1		
2	Run 2		
3	Run 2 Duplicate		
4	Run 3		
5	Run 3 Spike		
6	Reagent Blank		

**Analyses Requested: Sb, As, Ba, Be, Cd, Cr, Co, Cu, Pb, Mn, Ni, P, Se, Ag, Tl, Zn & Hg**

SAMPLE	Front Half		Back Half			HNO <sub>3</sub> (A)		KMnO <sub>4</sub> (B)		HCl (C)	
	BV, ml	FV, ml	BV, ml	Used	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml
1	92ml	100	300	150	50	104	200	395	500	<del>X</del>	
2/3	110ml		310	155		109		400			
4/5	106		320	160		110		400			
6	100		200 H <sub>2</sub> O <sub>2</sub> 100.1N H <sub>2</sub> O <sub>2</sub>	150		200ml		100ml KMnO <sub>4</sub> 33ml DI as 400ml			

Comments: No "C" fraction submitted. 4-25-05 IJJ

# Dataset Report

User Name: daphne.woodman

Computer Name: ICPMS1

Dataset File Path: C:\elandata\Dataset\042705-2\

Report Date/Time: Thursday, April 28, 2005 08:05:22

*Daphne Woodman*  
4-28-05

Autosampler Position: 3

## The Dataset

Time	Sample ID	Batch ID	Read Type	Description	Init. Quant	Prep. Vol.	Aliquot. Vol.	Diluted V
14:38:38 Wed 27-Apr-05	Blank		Blank					
14:41:40 Wed 27-Apr-05	Standard 1		Standard #1					
14:44:43 Wed 27-Apr-05	Standard 2		Standard #2					
14:47:47 Wed 27-Apr-05	Standard 3		Standard #3					
14:50:51 Wed 27-Apr-05	QC Std 1		QC Std #1					
14:53:54 Wed 27-Apr-05	QC Std 2		QC Std #2					
14:56:58 Wed 27-Apr-05	QC Std 3		QC Std #3					
15:00:01 Wed 27-Apr-05	QC Std 4		QC Std #4					
15:03:05 Wed 27-Apr-05	QC Std 6		QC Std #6					
15:06:09 Wed 27-Apr-05	QC Std 7		QC Std #7					
15:09:13 Wed 27-Apr-05	QC Std 8		QC Std #8					
15:12:18 Wed 27-Apr-05	QC Std 9		QC Std #9	- Carry over for Sb				
15:15:24 Wed 27-Apr-05	QC Std 10		QC Std #10					
15:18:27 Wed 27-Apr-05	5025-1		Sample	Air Test Professionals				
15:21:29 Wed 27-Apr-05	5025-2		Sample	Air Test Professionals				
15:24:32 Wed 27-Apr-05	5025-2	d	QC Duplicate	Air Test Professionals				
15:27:34 Wed 27-Apr-05	5025-4		Sample	Air Test Professionals				
15:30:37 Wed 27-Apr-05	5025-4	s	Spike - 1	Air Test Professionals				
15:33:39 Wed 27-Apr-05	5025-6		Sample	Air Test Professionals				
15:36:46 Wed 27-Apr-05	QC Std 1		QC Std #1					
15:39:48 Wed 27-Apr-05	QC Std 4		QC Std #4					
15:47:20 Wed 27-Apr-05	QC Std #2		QC Std #2					
15:50:25 Wed 27-Apr-05	QC Std #9		QC Std #9					
15:53:30 Wed 27-Apr-05	QC Std #10		QC Std #10					
15:56:34 Wed 27-Apr-05	5025-4	x5	Sample	Air Test Professionals				
15:59:37 Wed 27-Apr-05	5025-4	x5s	Spike - 1	Air Test Professionals				
16:02:41 Wed 27-Apr-05	5025-6		Sample	Air Test Professionals				
16:05:46 Wed 27-Apr-05	5025-6 filter		Sample	Air Test Professionals				
16:08:49 Wed 27-Apr-05	QC Std 1		QC Std #1					
16:11:52 Wed 27-Apr-05	QC Std 4		QC Std #4					
16:17:08 Wed 27-Apr-05	1 ppb Se		Sample					
16:20:11 Wed 27-Apr-05	QC Std 1		QC Std #1					
16:23:14 Wed 27-Apr-05	QC Std 4		QC Std #4					
16:26:37 Wed 27-Apr-05	2.5 ppb Se		Sample					
16:29:40 Wed 27-Apr-05	QC Std 1		QC Std #1					
16:32:43 Wed 27-Apr-05	QC Std 4		QC Std #4					
16:36:06 Wed 27-Apr-05	Blank		Blank					
16:39:09 Wed 27-Apr-05	Standard 1		Standard #1					
16:42:12 Wed 27-Apr-05	Standard 2		Standard #2					
16:45:16 Wed 27-Apr-05	Standard 3		Standard #3					
16:48:19 Wed 27-Apr-05	QC Std 1		QC Std #1					
16:51:23 Wed 27-Apr-05	QC Std 2		QC Std #2					
16:54:27 Wed 27-Apr-05	QC Std 3		QC Std #3					

16:57:30 Wed 27-Apr-05	QC Std 4		QC Std #4	
17:00:34 Wed 27-Apr-05	QC Std 6		QC Std #6	
17:03:38 Wed 27-Apr-05	QC Std 7		QC Std #7	
17:06:42 Wed 27-Apr-05	QC Std 8		QC Std #8	
17:09:47 Wed 27-Apr-05	QC Std 9		QC Std #9	
17:12:53 Wed 27-Apr-05	QC Std 10		QC Std #10	
17:15:56 Wed 27-Apr-05	5025-1		Sample	Air Test Professionals
17:18:58 Wed 27-Apr-05	5025-2		Sample	Air Test Professionals
17:22:01 Wed 27-Apr-05	5025-2	d	QC Duplicate	Air Test Professionals
17:25:03 Wed 27-Apr-05	5025-4		Sample	Air Test Professionals
17:28:06 Wed 27-Apr-05	5025-4	s	Spike - 1	Air Test Professionals
17:31:08 Wed 27-Apr-05	5025-6		Sample	Air Test Professionals
17:34:11 Wed 27-Apr-05	QC Std 1		QC Std #1	
17:37:14 Wed 27-Apr-05	QC Std 4		QC Std #4	

# Sample/Batch Report

User Name: daphne.woodman

Computer Name: ICPMS1

Sample File: C:\elandata\Sample\xb.sam

Report Date/Time: Thursday, April 28, 2005 08:10:44

*Daphne Woodman*  
*4-28-05*

A/S Loc.	Batch ID	Sample ID	Description	Sample Type	Init. Quant.	Prep. Vol.	Aliquot Vol.	Diluted Vol.	Solids Ratio
14		5025-1	Air Test Professionals						
15		5025-2	Air Test Professionals						
16	d	5025-2	Air Test Profes:QC Duplicate						
17		5025-4	Air Test Professionals						
18	s	5025-4	Air Test Profes:Spike - 1						
19		5025-6	Air Test Professionals						
5		QC Std #2							
12		QC Std #9							
13		QC Std #10							
20	x5	5025-4	Air Test Professionals						
21	x5s	5025-4	Air Test Profes:Spike - 1						
22		5025-6	Air Test Professionals						
23		5025-6 filter	Air Test Professionals						
24		1 ppb Se							
25		2.5 ppb Se							
14		5025-1	Air Test Professionals						
15		5025-2	Air Test Professionals						
16	d	5025-2	Air Test Profes:QC Duplicate						
17		5025-4	Air Test Professionals						
18	s	5025-4	Air Test Profes:Spike - 1						
19		5025-6	Air Test Professionals						

*Daphne Wood*  
4-28-05

Analyst: DBW Date: 4-27-05 Solid Samples  / Liquid Samples

A/S Loc	Batch # for sample sets	Sample Lab ID	Sample Description	Type Sample QC Spike QC Dup QC Reg Blank	Spike concentration	Prep Volume (ml)	Aliquot (ml)	Diluted to Volume (ml)	Units
12			LRB	S		100X2			
13			LRB	SS	Table #1	100X2			
14			5025-1	S		100X2			
15			5025-2	S		100X2			
16			5025-2	SD		100X2			
17			5025-4	S		100X2			
18			5025-4	SS	Table #1	100X2			
19			5025-6	S		100X2			

Dilutions and Rechecks

5			QC Std #2						
12			QC Std #9						
13			QC Std #10						
20			5025-4	S		100X2	2.0	10	
21			5025-4	SS	Table #1	100X2	2.0	10	
22			5025-6	S		100X2			
23			5025-6 filter	S		100			
24			1 ppb Se						
25			2.5 ppb Se						
12			LRB	S		100X2			
13			LRB	SS	Table #1	100X2			
14			5025-1	S		100X2			

Analyst: DBW Date: 4-27-05 **Solid Samples**  / *Liquid Samples*

15			5025-2	S		100X2			
16			5025-2	SD		100X2			
17			5025-4	S		100X2			
18			5025-4	SS	Table #1	100X2			
19			5025-6	S		100X2			

Spikes are post at 0.02 mL of 25ppm spiking solutions lot 021405-ABC & F in a final volume of 10ml.

Submitted for QC:	Date: 4-28-05	Time: 8:10	By: DW	QC Review: <i>for</i>	Date: 5-6-05	Time: 1400	By:
Re-Test Required:	No:	Yes:	Comments:				
Resubmitted for QC:	Date:	Time:	By:	QC Review:	Date:	Time:	By:

Element One, Inc. Form 126 - Revision 0.0



Timing Processing Equation Calibration Sampling Devices

Analyte	Mass (amu)	Spike Table 1 [Conc.]	Spike Table 1 Det. Limit [Conc.]	Spike Table 2 [Conc.]	Spike Table 2 Det. Limit [Conc.]	Spike Table 3 [Conc.]	Spike Table 3 Det. Limit [Conc.]	Spike Table 4 [Conc.]
1 Be	9.0122	50	1	25	1	100	1	
2 P	30.9938	250	1	25	1	100	1	
3 Sc	44.9559	50	1	25	1	100	1	
4 Cr	51.9405	50	1	25	1	100	1	
5 Cr	52.9407	50	1	25	1	100	1	
6 Mn	54.9381	50	1	25	1	100	1	
7 Co	58.9332	50	1	25	1	100	1	
8 Ni	59.9332	50	1	25	1	100	1	
9 Cu	62.9298	50	1	25	1	100	1	
10 Cu	64.9278	50	1	25	1	100	1	
11 Zn	65.926	50	1	25	1	100	1	
12 Zn	66.9271	50	1	25	1	100	1	
13 Zn	67.9249	50	1	25	1	100	1	
14 As	74.9216	50	1	25	1	100	1	
15 Se	76.9199	50	1	25	1	100	1	
16 Se	81.9167	50	1	25	1	100	1	
17 Ag	106.905	50	1	25	1	100	1	
18 Ag	108.905	50	1	25	1	100	1	
19 Cd	110.904	50	1	25	1	100	1	
20 Cd	113.904	50	1	25	1	100	1	
21 Sb	120.904	50	1	25	1	100	1	
22 Sb	122.904	50	1	25	1	100	1	
23 Ba	134.906	50	1	25	1	100	1	
24 Ba	136.905	50	1	25	1	100	1	
25 Ti	204.975	50	1	25	1	100	1	

frequency | C Std | Int Stds | Calibration Stds | Sample | Int Stds | Dilution | Duplicate | Spike Tables | QC Action Controls | Autosampler

NUM | LOG | FAIL | 8:02 AM

Start | GpibManager | ELAN Instrument Con...

For help, Press F1



Timing | Processing | Equation | Calibration | Sampling | Devices | QC...

Analyte	Mass (amu)	Spike Table 1 (Conc.)	Spike Table 1 Det. Limit (Conc.)	Spike Table 2 (Conc.)	Spike Table 2 Det. Limit (Conc.)	Spike Table 3 (Conc.)	Spike Table 3 Det. Limit (Conc.)	Spike Table 4 (Conc.)
3 Sc	44.9559	50	1	25	1	100	1	
4 Cr	51.9405	50	1	25	1	100	1	
5 Cr	52.9407	50	1	25	1	100	1	
6 Mn	54.9381	50	1	25	1	100	1	
7 Co	58.9332	50	1	25	1	100	1	
8 Ni	59.9332	50	1	25	1	100	1	
9 Cu	62.9298	50	1	25	1	100	1	
10 Cu	64.9278	50	1	25	1	100	1	
11 Zn	65.926	50	1	25	1	100	1	
12 Zn	66.9271	50	1	25	1	100	1	
13 Zn	67.9249	50	1	25	1	100	1	
14 As	74.9216	50	1	25	1	100	1	
15 Se	76.9199	50	1	25	1	100	1	
16 Se	81.9167	50	1	25	1	100	1	
17 Ag	106.905	50	1	25	1	100	1	
18 Ag	108.905	50	1	25	1	100	1	
19 Cd	110.904	50	1	25	1	100	1	
20 Cd	113.904	50	1	25	1	100	1	
21 Sb	120.904	50	1	25	1	100	1	
22 Sb	122.904	50	1	25	1	100	1	
23 Ba	134.906	50	1	25	1	100	1	
24 Ba	136.905	50	1	25	1	100	1	
25 Tl	204.975	50	1	25	1	100	1	
26 Pb	207.977	50	1	25	1	100	1	
27 Kr	82.9141	50	1	25	1	100	1	

Frequency | QC Std Int Stds | Calibration Stds | Sample Int Stds | Sample | Spike | Dilution | Duplicate | Spike Tables | Action Controls | Autosampler

For help, Press F1

Start | GpibManager | ELAN Instrument Con...

Method 6020 & 200.8 Metals Summary Report

Sample ID: Blank

Sample Date Wednesday, April 27, 2005 14:38:38

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
-	P	31	8982.2		ppb
	Sc	45	278133.2		ppb
>	Rh	103	541985.5		ppb
>	Ho	165	1031216.2		ppb
	Kr	83	168		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: Standard 1

Sample Date Wednesday, April 27, 2005 14:41:40

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
>	Li	6	227526.6		ppb
-	P	31	17177.5	23.72443	ppb
	Sc	45	269263.3		ppb
>	Rh	103	507658.1		ppb
>	Ho	165	973651.3		ppb
	Kr	83	157.7		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: Standard 2

Sample Date Wednesday, April 27, 2005 14:44:43

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
>	Li	6	241772.4		ppb
-	P	31	398055.6	1070.11848	ppb
	Sc	45	269336.1		ppb
>	Rh	103	499820		ppb
>	Ho	165	994806.1		ppb
	Kr	83	177.3		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: Standard 3

Sample Date Wednesday, April 27, 2005 14:47:47

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
>	Li	6	235561		ppb
-	P	31	1819599.8	4998.1468	ppb
	Sc	45	257211.8		ppb
>	Rh	103	469013.7		ppb
>	Ho	165	957219.3		ppb
	Kr	83	226		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 1

Sample Date Wednesday, April 27, 2005 14:50:51

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
>	Li	6	252214.8		ppb
-	P	31	8969.9	2.5428	ppb
	Sc	45	261282.8		ppb
>	Rh	103	483894.7		ppb
>	Ho	165	997557.7		ppb
	Kr	83	150.3		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 2

Sample Date Wednesday, April 27, 2005 14:53:54

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
>	Li	6	252907.3		ppb
-	P	31	15863	22.97656	ppb
	Sc	45	251874.4		ppb
>	Rh	103	462132.4		ppb
>	Ho	165	945561.2		ppb
	Kr	83	146.7		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 3

Sample Date Wednesday, April 27, 2005 14:56:58

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
>	Li		6 249669.3		ppb
-	P	31	1096319.7	3216.01367	ppb
-	Sc	45	245660.8		ppb
>	Rh	103	438141.2		ppb
>	Ho	165	927247.6		ppb
	Kr	83	165.3		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 4

Sample Date Wednesday, April 27, 2005 15:00:01

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
>	Li		6 262302.8		ppb
-	P	31	363727.3	1054.25238	ppb
-	Sc	45	243843.5		ppb
>	Rh	103	437603.9		ppb
>	Ho	165	934681		ppb
	Kr	83	150.3		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 6

Sample Date Wednesday, April 27, 2005 15:03:05

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
>	Li		6 248034.7		ppb
-	P	31	16292492.2	50088.6735	ppb
-	Sc	45	244101		ppb
>	Rh	103	420673.7		ppb
>	Ho	165	952177.4		ppb
	Kr	83	198.7		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 7

Sample Date Wednesday, April 27, 2005 15:06:09

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
>	Li		6 246074.6		ppb
-	P	31	16256682.7	50126.2451	ppb
-	Sc	45	240372.1		ppb
>	Rh	103	419486.6		ppb
>	Ho	165	943559.7		ppb
	Kr	83	180.3		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 9

Sample Date Wednesday, April 27, 2005 15:12:18

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
>	Li		6 272999		ppb
-	P	31	12064.6	12.84064	ppb
-	Sc	45	265521.4		ppb
>	Rh	103	455619.9		ppb
>	Ho	165	981377.3		ppb
	Kr	83	113.7		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 10

Sample Date Wednesday, April 27, 2005 15:15:24

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
>	Li		6 272201.1		ppb
-	P	31	76114.3	218.38225	ppb
-	Sc	45	247272.3		ppb
>	Rh	103	410659.6		ppb
>	Ho	165	915259.7		ppb
	Kr	83	118.7		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 1

Sample Date Wednesday, April 27, 2005 15:36:46

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
>	Li	6	226221.8		ppb
-	P	31	5784.2	-2.59636	ppb
-	Sc	45	193496.5		ppb
>	Rh	103	397092.9		ppb
>	Ho	165	912600.9		ppb
	Kr	83	106.7		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 4

Sample Date Wednesday, April 27, 2005 15:39:48

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
>	Li	6	210509.3		ppb
-	P	31	286745.2	966.80453	ppb
-	Sc	45	183008.1		ppb
>	Rh	103	375425.3		ppb
>	Ho	165	866287.2		ppb
	Kr	83	121.3		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std #9

Sample Date Wednesday, April 27, 2005 15:50:25

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
>	Li	6	227286.5		ppb
-	P	31	8956.6	8.09593	ppb
-	Sc	45	205620		ppb
>	Rh	103	392641.4		ppb
>	Ho	165	899545.6		ppb
	Kr	83	95.3		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std #10

Sample Date Wednesday, April 27, 2005 15:53:30

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
>	Li	6	211547.2		ppb
-	P	31	61047.1	194.78458	ppb
-	Sc	45	187651.7		ppb
>	Rh	103	365305.1		ppb
>	Ho	165	847267.5		ppb
	Kr	83	104.7		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: 5025-4

Sample Date Wednesday, April 27, 2005 15:56:34

Sample Desc Air Test Professionals

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
>	Li	6	216054.4		ppb
-	P	31	10651.7	14.81621	ppb
-	Sc	45	241874.2		ppb
>	Rh	103	380215.1		ppb
>	Ho	165	878678.8		ppb
	Kr	83	130		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: 5025-4

Sample Date Wednesday, April 27, 2005 15:59:37

Sample Desc Air Test Professionals

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
>	Li	6	205509.1		ppb
-	P	31	67673.6	219.11954	ppb
-	Sc	45	239726.6		ppb
>	Rh	103	364043.1		ppb
>	Ho	165	869359.2		ppb
	Kr	83	144		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: 5025-6

Sample Date Wednesday, April 27, 2005 16:02:41

Sample Desc Air Test Professionals

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
▷	Li		6 221549.4		ppb
└	P		31 33086.9	96.16662	ppb
└	Sc		45 680823		ppb
▷	Rh		103 363999.6		ppb
▷	Ho		165 875275.6		ppb
	Kr		83 286.3		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 1

Sample Date Wednesday, April 27, 2005 16:08:49

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
▷	Li		6 193526.1		ppb
└	P		31 4150.6	-6.49154	ppb
└	Sc		45 164809.7		ppb
▷	Rh		103 359237.1		ppb
▷	Ho		165 823777.5		ppb
	Kr		83 104.7		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 4

Sample Date Wednesday, April 27, 2005 16:11:52

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
▷	Li		6 186822.9		ppb
└	P		31 258296.4	956.49276	ppb
└	Sc		45 161840.3		ppb
▷	Rh		103 341789.5		ppb
▷	Ho		165 808442.3		ppb
	Kr		83 110		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: Blank

Sample Date Wednesday, April 27, 2005 16:36:06

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
▷	Li		6 191047.7		ppb
└	Be		9 16		ppb
└	P		31 5128		ppb
└	Sc		45 158850.8		ppb
└	Cr		52 5332.4		ppb
└	Cr		53 20414.5		ppb
└	Mn		55 1416.8		ppb
└	Co		59 352.3		ppb
└	Ni		60 262		ppb
└	Cu		63 485.7		ppb
└	Cu		65 421.3		ppb
└	Zn		66 2493.6		ppb
└	Zn		67 1610.8		ppb
└	Zn		68 4286		ppb
└	As		75 285.9		ppb
└	Se		77 1508.4		ppb
└	Se		82 31.4		ppb
▷	Rh		103 355310.7		ppb
└	Ag		107 6261.1		ppb
└	Ag		109 5925.6		ppb
└	Cd		111 102		ppb
└	Cd		114 232.7		ppb
└	Sb		121 14195.8		ppb
└	Sb		123 10908.2		ppb
└	Ba		135 1227.1		ppb
└	Ba		137 2179.9		ppb
▷	Ho		165 824018.9		ppb
└	Tl		205 1690.8		ppb
└	Pb		208 5760.2		ppb
	Kr		83 104.7		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: Standard 1

Sample Date Wednesday, April 27, 2005 16:39:09

Sample Description:

Concentration Results

Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
Li	6	184602.6		ppb
Be	9	299.3	0.9386	ppb
P	31	10333.8	20.90948	ppb
Sc	45	153352.6		ppb
Cr	52	10847.2	0.92063	ppb
Cr	53	20622.8	1.55214	ppb
Mn	55	10721.1	0.87793	ppb
Co	59	7387.3	0.902	ppb
Ni	60	1674.4	0.85006	ppb
Cu	63	3929.2	0.94064	ppb
Cu	65	2043.2	0.89194	ppb
Zn	66	1853.8	-0.44286	ppb
Zn	67	1529.4	-0.01355	ppb
Zn	68	3833.2	-0.27756	ppb
As	75	1329.3	0.76291	ppb
Se	77	1499.4	0.58283	ppb
Se	82	148.8	0.81828	ppb
Rh	103	337942.1		ppb
Ag	107	8331.2	0.28412	ppb
Ag	109	7754.8	0.26725	ppb
Cd	111	1904.4	1.01219	ppb
Cd	114	4419.1	1.08122	ppb
Sb	121	8764.8	-0.73775	ppb
Sb	123	6697.3	-0.73227	ppb
Ba	135	2315.2	0.52789	ppb
Ba	137	4091.6	0.55641	ppb
Ho	165	791976.9		ppb
Tl	205	25059.5	1.03288	ppb
Pb	208	35684.4	0.99418	ppb
Kr	83	99		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: Standard 2

Sample Date Wednesday, April 27, 2005 16:42:12

Sample Description:

Concentration Results

Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
Li	6	189294.4		ppb
Be	9	29038.8	93.76534	ppb
P	31	262786.6	964.19778	ppb
Sc	45	159600.7		ppb
Cr	52	575769.2	89.17497	ppb
Cr	53	88211.7	86.25032	ppb
Mn	55	920888.5	84.58074	ppb
Co	59	704089.4	88.26564	ppb
Ni	60	153453.7	89.56473	ppb
Cu	63	349972.8	92.96405	ppb
Cu	65	169621.6	90.12099	ppb
Zn	66	101392.9	83.15239	ppb
Zn	67	17708.5	81.37402	ppb
Zn	68	78708.4	83.52139	ppb
As	75	130617	92.0446	ppb
Se	77	11615.2	89.40802	ppb
Se	82	13688.8	91.9401	ppb
Rh	103	346537.2		ppb
Ag	107	862439.6	100.00715	ppb
Ag	109	825517.6	100.00735	ppb
Cd	111	188139.6	102.61009	ppb
Cd	114	429802.9	107.76588	ppb
Sb	121	622628.5	90.65034	ppb
Sb	123	474825.7	88.48713	ppb
Ba	135	212067.1	96.31625	ppb
Ba	137	376641.6	102.55091	ppb
Ho	165	807804.7		ppb
Tl	205	2299281.9	99.19891	ppb
Pb	208	3157583.5	101.79488	ppb
Kr	83	115.7		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: Standard 3

Sample Date Wednesday, April 27, 2005 16:45:16

Sample Description:

Concentration Results

Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
> Li	6	166815.9		ppb
- Be	9	131145.2	500.48464	ppb
- P	31	1168105.7	4995.49287	ppb
- Sc	45	147551.3		ppb
- Cr	52	2599838.5	499.69915	ppb
- Cr	53	335201.4	500.07483	ppb
- Mn	55	4170205.9	499.63658	ppb
- Co	59	3183387.2	499.58942	ppb
- Ni	60	688400	499.4554	ppb
- Cu	63	1559107.1	499.3131	ppb
- Cu	65	759679.1	499.43254	ppb
- Zn	66	453936.3	499.7732	ppb
- Zn	67	75800.4	499.95323	ppb
- Zn	68	338565.5	499.45602	ppb
- As	75	596476.6	499.80967	ppb
- Se	77	47465.5	499.6862	ppb
- Se	82	62137.5	499.69434	ppb
> Rh	103	320245.2		ppb
- Ag	107	3082846.5	388.99007	ppb
- Ag	109	2850137.1	375.55668	ppb
- Cd	111	849317.4	499.55535	ppb
- Cd	114	1911294.1	499.26008	ppb
- Sb	121	2799000.1	499.47156	ppb
- Sb	123	2155430.8	499.66634	ppb
- Ba	135	969942.2	499.53594	ppb
- Ba	137	1684985.2	499.09683	ppb
> Ho	165	760283		ppb
- Tl	205	11134686.4	500.56091	ppb
- Pb	208	14684047.3	499.80205	ppb
- Kr	83	147.3		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 1

Sample Date Wednesday, April 27, 2005 16:48:19

Sample Description:

Concentration Results

Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
> Li	6	162072.4		ppb
- Be	9	45.7	0.12683	ppb
- P	31	6054.7	5.79954	ppb
- Sc	45	148095.4		ppb
- Cr	52	6056.3	0.22484	ppb
- Cr	53	20007.6	2.09711	ppb
- Mn	55	2568.9	0.15087	ppb
- Co	59	1156.4	0.1294	ppb
- Ni	60	396.7	0.11279	ppb
- Cu	63	942.4	0.15784	ppb
- Cu	65	679.7	0.19146	ppb
- Zn	66	2495.6	0.23778	ppb
- Zn	67	1711.8	1.58591	ppb
- Zn	68	4238	0.47221	ppb
- As	75	780.3	0.42957	ppb
- Se	77	1318.4	-0.64121	ppb
- Se	82	146.4	0.93577	ppb
> Rh	103	324702.7		ppb
> Ag	107	115689.9	13.7023	ppb
- Ag	109	110691.9	13.70194	ppb
- Cd	111	288.4	0.11343	ppb
- Cd	114	620.1	0.1052	ppb
- Sb	121	35771.2	4.0191	ppb
- Sb	123	27458.2	4.00436	ppb
- Ba	135	1401.1	0.12596	ppb
- Ba	137	2556.3	0.14785	ppb
> Ho	165	774651.6		ppb
- Tl	205	10970.2	0.41689	ppb
- Pb	208	12389.6	0.23567	ppb
- Kr	83	109		ppb



Method 6020 & 200.8 Metals Summary Report  
 Sample ID: QC Std 2  
 Sample Date Wednesday, April 27, 2005 16:51:23  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
> Li	6	158399		ppb
- Be	9	269	1.02819	ppb
- P	31	10349.2	24.53282	ppb
- Sc	45	144826.5		ppb
- Cr	52	10776.8	1.1472	ppb
- Cr	53	20636.1	3.49979	ppb
- Mn	55	10179.1	1.06534	ppb
- Co	59	7057.5	1.0563	ppb
- Ni	60	1653.8	1.02719	ppb
- Cu	63	3865.9	1.09652	ppb
- Cu	65	2051.8	1.09826	ppb
- Zn	66	1814.1	-0.48107	ppb
- Zn	67	1660.8	1.39675	ppb
- Zn	68	3640.5	-0.33823	ppb
- As	75	1611.1	1.13184	ppb
- Se	77	1334.1	-0.2901	ppb
- Se	82	173.2	1.16401	ppb
> Rh	103	320682.9		ppb
- Ag	107	47854.8	5.32358	ppb
- Ag	109	44522.5	5.16352	ppb
- Cd	111	1802.2	1.00478	ppb
- Cd	114	4147.3	1.0272	ppb
- Sb	121	10130.7	-0.47228	ppb
- Sb	123	7957	-0.42932	ppb
- Ba	135	2134.2	0.55249	ppb
- Ba	137	3780.2	0.56088	ppb
> Ho	165	736451.9		ppb
- Tl	205	25074.6	1.09345	ppb
- Pb	208	34390.5	1.0278	ppb
- Kr	83	97.3		ppb

Method 6020 & 200.8 Metals Summary Report  
 Sample ID: QC Std 3  
 Sample Date Wednesday, April 27, 2005 16:54:27  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
> Li	6	159642.6		ppb
- Be	9	49670	198.03094	ppb
- P	31	722548.6	3175.91853	ppb
- Sc	45	147064.7		ppb
- Cr	52	999556	197.32846	ppb
- Cr	53	139466.9	197.74422	ppb
- Mn	55	1558214.8	192.22775	ppb
- Co	59	1223129.4	197.73168	ppb
- Ni	60	266215.5	198.88084	ppb
- Cu	63	610797.6	201.41079	ppb
- Cu	65	296715.6	200.81255	ppb
- Zn	66	169400.2	190.59963	ppb
- Zn	67	29764.3	196.42525	ppb
- Zn	68	131271.2	195.98052	ppb
- As	75	227530.4	196.25108	ppb
- Se	77	18852.6	195.72686	ppb
- Se	82	23381.8	193.41045	ppb
> Rh	103	310800		ppb
- Ag	107	1075484.5	139.3206	ppb
- Ag	109	1046857.1	141.73266	ppb
- Cd	111	319788.6	193.76301	ppb
- Cd	114	726232.8	195.42409	ppb
- Sb	121	1076021.7	195.73658	ppb
- Sb	123	828466.6	195.77639	ppb
- Ba	135	366083.3	193.31331	ppb
- Ba	137	645093.5	195.89888	ppb
> Ho	165	740164.7		ppb
- Tl	205	4148221.1	191.43167	ppb
- Pb	208	5488045.1	191.72201	ppb
- Kr	83	114.7		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 4

Sample Date Wednesday, April 27, 2005 16:57:30

Sample Description:

Concentration Results

Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
> Li	6	158078.6		ppb
- Be	9	25729.7	103.54854	ppb
- P	31	239064.5	1008.46242	ppb
- Sc	45	146936		ppb
- Cr	52	533800.4	102.05333	ppb
- Cr	53	83759.8	103.42218	ppb
- Mn	55	837304.9	100.38393	ppb
- Co	59	652013.8	102.48457	ppb
- Ni	60	142195.8	103.22301	ppb
- Cu	63	325871.6	104.43151	ppb
- Cu	65	156360	102.79167	ppb
- Zn	66	92956.8	100.54181	ppb
- Zn	67	16678.2	102.58708	ppb
- Zn	68	71215.1	100.68646	ppb
- As	75	120387.5	100.8929	ppb
- Se	77	10677.1	101.20216	ppb
- Se	82	12337.3	99.2318	ppb
> Rh	103	319569.8		ppb
- Ag	107	806895.5	101.48105	ppb
- Ag	109	757314.9	99.47845	ppb
- Cd	111	170729.1	100.57711	ppb
- Cd	114	391377.6	102.38645	ppb
- Sb	121	586898.6	103.82352	ppb
- Sb	123	452816.2	104.05106	ppb
- Ba	135	196948.7	101.89785	ppb
- Ba	137	348898.2	103.82011	ppb
> Ho	165	753311.9		ppb
- Tl	205	2234262.9	101.27427	ppb
- Pb	208	2974150.8	102.00658	ppb
- Kr	83	108.7		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 6

Sample Date Wednesday, April 27, 2005 17:00:34

Sample Description:

Concentration Results

Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
> Li	6	160924.7		ppb
- Be	9	15	0.00621	ppb
- P	31	11094388.2	50720.5485	ppb
- Sc	45	149544.2		ppb
- Cr	52	9145	0.94888	ppb
- Cr	53	24093.6	11.45824	ppb
- Mn	55	21597.5	2.60479	ppb
- Co	59	7108.8	1.13948	ppb
- Ni	60	2172.2	1.50702	ppb
- Cu	63	3755.5	1.14171	ppb
- Cu	65	3048.7	1.88583	ppb
- Zn	66	4800.5	3.16759	ppb
- Zn	67	2334.5	6.95488	ppb
- Zn	68	5040.6	2.24831	ppb
- As	75	343.8	0.09146	ppb
- Se	77	1967.8	7.97598	ppb
- Se	82	32.2	0.05049	ppb
> Rh	103	300590.5		ppb
- Ag	107	24689.1	2.62355	ppb
- Ag	109	23142.7	2.56253	ppb
- Cd	111	132.4	0.02918	ppb
- Cd	114	3743.3	0.98777	ppb
- Sb	121	16977.7	0.66912	ppb
- Sb	123	13034.6	0.66541	ppb
- Ba	135	713.4	-0.21938	ppb
- Ba	137	1235.4	-0.23356	ppb
> Ho	165	767557.1		ppb
- Tl	205	1981.5	0.01819	ppb
- Pb	208	12655.7	0.24614	ppb
- Kr	83	129		ppb

Method 6020 & 200.8 Metals Summary Report  
 Sample ID: QC Std 7  
 Sample Date Wednesday, April 27, 2005 17:03:38  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas.	Intens	Conc.	Mean	Report Unit
Li	6	154080.5				ppb
Be	9	9.7			-0.01329	ppb
P	31	11081356.9	51659.1793			ppb
Sc	45	150636.5				ppb
Cr	52	59961.7		11.61347		ppb
Cr	53	30703		23.5991		ppb
Mn	55	100849.5		12.97649		ppb
Co	59	125582.9		21.36337		ppb
Ni	60	27292.3		21.34236		ppb
Cu	63	31941		10.97205		ppb
Cu	65	16752.3		11.71843		ppb
Zn	66	12418.9		12.43834		ppb
Zn	67	3475.8		15.62391		ppb
Zn	68	10393.9		11.08539		ppb
As	75	11365.1		10.13331		ppb
Se	77	2929.3		19.74911		ppb
Se	82	1110.9		9.4837		ppb
Rh	103	294746.4				ppb
Ag	107	67320.6		8.53147		ppb
Ag	109	63118.8		8.34909		ppb
Cd	111	7942.5		5.02123		ppb
Cd	114	21373.2		6.01138		ppb
Sb	121	8124.4		-0.88599		ppb
Sb	123	6233.7		-0.88672		ppb
Ba	135	536.3		-0.30618		ppb
Ba	137	932		-0.31893		ppb
Ho	165	757615.6				ppb
Tl	205	1017		-0.02424		ppb
Pb	208	8989.5		0.12625		ppb
Kr	83	136.7				ppb

Method 6020 & 200.8 Metals Summary Report  
 Sample ID: QC Std 8  
 Sample Date Wednesday, April 27, 2005 17:06:42  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas.	Intens	Conc.	Mean	Report Unit
Li	6	139694.1				ppb
Be	9	36			0.24745	ppb
P	31	6775.4	10.89497			ppb
Sc	45	140615.4				ppb
Cr	52	8037		0.70968		ppb
Cr	53	23226.8		9.69215		ppb
Mn	55	3664.8		0.31103		ppb
Co	59	1696.5		0.2315		ppb
Ni	60	520		0.22737		ppb
Cu	63	1436.4		0.3458		ppb
Cu	65	937.4		0.40169		ppb
Zn	66	1136.7		-1.15778		ppb
Zn	67	1632.1		1.83272		ppb
Zn	68	3139.4		-0.8138		ppb
As	75	372		0.11379		ppb
Se	77	1597.1		3.55462		ppb
Se	82	71.2		0.37755		ppb
Rh	103	303069.8				ppb
Ag	107	940.4		-0.58752		ppb
Ag	109	992		-0.56656		ppb
Cd	111	474.6		0.24098		ppb
Cd	114	1077.8		0.24267		ppb
Sb	121	4954.9		-1.39776		ppb
Sb	123	3868.7		-1.37975		ppb
Ba	135	214.7		-0.4653		ppb
Ba	137	366		-0.48029		ppb
Ho	165	710866.5				ppb
Tl	205	5814.9		0.20938		ppb
Pb	208	14679.7		0.35357		ppb
Kr	83	37				ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 9

Sample Date Wednesday, April 27, 2005 17:09:47

Sample Description:

Concentration Results

Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
> Li	6	146880.9		ppb
- Be	9	8	-0.01882	ppb
- P	31	8090.4	15.14326	ppb
- Sc	45	155613.2		ppb
- Cr	52	5011.6	0.04656	ppb
- Cr	53	6253.1	-19.08949	ppb
- Mn	55	9848.8	1.0356	ppb
- Co	59	1448.4	0.17904	ppb
- Ni	60	2773.6	1.85542	ppb
- Cu	63	1907.1	0.47463	ppb
- Cu	65	1096.4	0.47657	ppb
- Zn	66	2591.3	0.40092	ppb
- Zn	67	1095.7	-2.33805	ppb
- Zn	68	4174.7	0.51004	ppb
- As	75	311.4	0.04689	ppb
- Se	77	278.7	-11.68908	ppb
- Se	82	46.6	0.15116	ppb
> Rh	103	318020.6		ppb
- Ag	107	743	-0.61836	ppb
- Ag	109	694.7	-0.61244	ppb
- Cd	111	107.2	0.00942	ppb
- Cd	114	39.1	-0.04452	ppb
- Sb	121	30180.2	3.12766	ppb
- Sb	123	23110.9	3.10323	ppb
- Ba	135	630.4	-0.2548	ppb
- Ba	137	1096.4	-0.26734	ppb
> Ho	165	751271.9		ppb
- Tl	205	667.4	-0.03975	ppb
- Pb	208	22620.6	0.59824	ppb
- Kr	83	80.7		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 10

Sample Date Wednesday, April 27, 2005 17:12:53

Sample Description:

Concentration Results

Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
> Li	6	138445.6		ppb
- Be	9	11770	54.06847	ppb
- P	31	47490	200.72015	ppb
- Sc	45	144616.3		ppb
- Cr	52	246050	50.33087	ppb
- Cr	53	32829.7	27.02987	ppb
- Mn	55	388889.4	50.26957	ppb
- Co	59	297888.4	50.53255	ppb
- Ni	60	69135	54.10754	ppb
- Cu	63	154734.4	53.48025	ppb
- Cu	65	75055.4	53.15943	ppb
- Zn	66	47224.7	54.03528	ppb
- Zn	67	8432.9	51.57319	ppb
- Zn	68	37556.4	54.85396	ppb
- As	75	60735.8	54.8658	ppb
- Se	77	3819.9	30.05621	ppb
- Se	82	4784.5	41.41275	ppb
> Rh	103	295949.4		ppb
- Ag	107	321876.8	43.30408	ppb
- Ag	109	305234.2	42.89451	ppb
- Cd	111	71753.2	45.61653	ppb
- Cd	114	165671.7	46.774	ppb
- Sb	121	250931.6	46.1756	ppb
- Sb	123	193802.9	46.34095	ppb
- Ba	135	86827.6	47.72531	ppb
- Ba	137	153012.1	48.35749	ppb
> Ho	165	704646.4		ppb
- Tl	205	1054629.7	51.07898	ppb
- Pb	208	1442630.2	52.81448	ppb
- Kr	83	87.3		ppb

Method 6020 & 200.8 Metals Summary Report  
 Sample ID: 5025-1  
 Sample Date Wednesday, April 27, 2005 17:15:56  
 Sample Desc: Air Test Professionals  
 Concentration Results

Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
> Li	6	171849.9		ppb
Be	9	21	0.025	ppb
P	31	33369.6	123.98947	ppb
Sc	45	447792.7		ppb
Cr	52	83607.4	15.23216	ppb
Cr	53	12429.5	-9.34002	ppb
Mn	55	947914	113.89986	ppb
Co	59	27928.9	4.35166	ppb
Ni	60	20819	14.99343	ppb
Cu	63	231074.6	74.14674	ppb
Cu	65	112078.3	73.74827	ppb
Zn	66	239475.1	263.49267	ppb
Zn	67	37064.4	240.40668	ppb
Zn	68	177299.2	259.72825	ppb
As	75	725.2	0.39405	ppb
Se	77	199	-12.56235	ppb
Se	82	-65.1	-0.75484	ppb
> Rh	103	318987.6		ppb
Ag	107	16318.5	1.35875	ppb
Ag	109	15214.9	1.31162	ppb
Cd	111	1529.1	0.84916	ppb
Cd	114	1531.7	0.34761	ppb
Sb	121	61793.7	8.73238	ppb
Sb	123	48292.5	8.90537	ppb
Ba	135	24709.3	12.1616	ppb
Ba	137	43807.8	12.40194	ppb
> Ho	165	759983.3		ppb
Tl	205	857.7	-0.03148	ppb
Pb	208	273049.5	9.11896	ppb
Kr	83	281.3		ppb

Method 6020 & 200.8 Metals Summary Report  
 Sample ID: 5025-2  
 Sample Date Wednesday, April 27, 2005 17:18:58  
 Sample Desc: Air Test Professionals  
 Concentration Results

Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
> Li	6	173974		ppb
Be	9	17	0.00903	ppb
P	31	41424.1	166.7196	ppb
Sc	45	711071.3		ppb
Cr	52	56142	10.41469	ppb
Cr	53	8800.1	-14.46648	ppb
Mn	55	354327.3	44.39536	ppb
Co	59	39971.6	6.53201	ppb
Ni	60	15607.7	11.71121	ppb
Cu	63	117569.4	39.36192	ppb
Cu	65	57395	39.35183	ppb
Zn	66	264376.6	304.33498	ppb
Zn	67	40835.7	278.24951	ppb
Zn	68	198265	304.5421	ppb
As	75	730.1	0.42648	ppb
Se	77	150.3	-13.02221	ppb
Se	82	-109.8	-1.15463	ppb
> Rh	103	305221.8		ppb
Ag	107	11528.4	0.8157	ppb
Ag	109	10517.6	0.75179	ppb
Cd	111	1670.6	0.97677	ppb
Cd	114	1911.9	0.46905	ppb
Sb	121	12448.5	-0.06472	ppb
Sb	123	9395.1	-0.105	ppb
Ba	135	24205.4	12.18576	ppb
Ba	137	43332.7	12.55049	ppb
> Ho	165	743132.7		ppb
Tl	205	553.3	-0.04467	ppb
Pb	208	286406.9	9.79479	ppb
Kr	83	318.3		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: 5025-2

Sample Date Wednesday, April 27, 2005 17:22:01

Sample Descr Air Test Professionals

Concentration Results

Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
> Li	6	169424		ppb
- Be	9	8.3	-0.02198	ppb
- P	31	39359.5	157.9563	ppb
- Sc	45	648419.9		ppb
- Cr	52	51678.2	9.54238	ppb
- Cr	53	7841.9	-16.01669	ppb
- Mn	55	330230.9	41.48591	ppb
- Co	59	37944.7	6.21615	ppb
- Ni	60	14744.1	11.08677	ppb
- Cu	63	111964.5	37.58404	ppb
- Cu	65	55446	38.11199	ppb
- Zn	66	248282.7	286.47952	ppb
- Zn	67	38214.1	260.53244	ppb
- Zn	68	185780.1	285.86148	ppb
- As	75	817.2	0.50553	ppb
- Se	77	168.7	-12.80989	ppb
- Se	82	-71.4	-0.82873	ppb
> Rh	103	304398.8		ppb
> Ag	107	12180.6	0.90654	ppb
- Ag	109	11103.1	0.83723	ppb
- Cd	111	1611.5	0.94348	ppb
- Cd	114	1797.4	0.43878	ppb
- Sb	121	11383.6	-0.24861	ppb
- Sb	123	8829.7	-0.22817	ppb
- Ba	135	23218.8	11.73274	ppb
- Ba	137	41254.6	11.98823	ppb
> Ho	165	739072.8		ppb
- Tl	205	506.3	-0.0467	ppb
- Pb	208	278754.6	9.58142	ppb
- Kr	83	309.7		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: 5025-4

Sample Date Wednesday, April 27, 2005 17:25:03

Sample Descr Air Test Professionals

Concentration Results

Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
> Li	6	148857.1		ppb
- Be	9	10.7	-0.00765	ppb
- Sc	45	321211.8		ppb
- Cr	52	44196.4	8.60107	ppb
- Cr	53	6686.6	-17.2172	ppb
- Mn	55	339065.6	45.36132	ppb
- Co	59	13320.3	2.29201	ppb
- Ni	60	11190.8	8.92368	ppb
- Cu	63	91493.8	32.67074	ppb
- Cu	65	44629.1	32.62642	ppb
- Zn	66	257813.9	316.93685	ppb
- Zn	67	39095.5	284.64149	ppb
- Zn	68	190959.6	313.26591	ppb
- As	75	418.4	0.17655	ppb
- Se	77	158.3	-12.80738	ppb
- Se	82	-57.2	-0.74515	ppb
> Rh	103	285959.1		ppb
> Ag	107	12144.6	1.00618	ppb
- Ag	109	11202.5	0.9511	ppb
- Cd	111	2997.3	1.92076	ppb
- Cd	114	5670.4	1.60465	ppb
- Sb	121	4971.6	-1.37641	ppb
- Sb	123	3914.4	-1.35042	ppb
- Ba	135	20954.6	11.19289	ppb
- Ba	137	36904.3	11.32724	ppb
> Ho	165	697925.3		ppb
- Tl	205	408.7	-0.0501	ppb
- Pb	208	262878.9	9.57045	ppb
- Kr	83	217.3		ppb

Method 6020 & 200.8 Metals Summary Report  
 Sample ID: 5025-4  
 Sample Date Wednesday, April 27, 2005 17:28:06  
 Sample Desc Air Test Professionals  
 Concentration Results

Analyte	Mass	Meas.	Intens	Conc.	Mean	Report Unit
Li	6	145582.4				ppb
Be	9	12571.3		54.89878		ppb
Sc	45	314824.5				ppb
Cr	52	289219		62.28358		ppb
Cr	53	35801.2		35.09606		ppb
Mn	55	754007.3		102.40134		ppb
Co	59	338392.8		60.22848		ppb
Ni	60	84587.9		69.50968		ppb
Cu	63	242604.2		88.05478		ppb
Cu	65	117565.5		87.49718		ppb
Zn	66	294322		367.05014		ppb
Zn	67	45674.4		338.75904		ppb
Zn	68	218476.8		364.22845		ppb
As	75	58038.6		55.00944		ppb
Se	77	3801.5		32.02504		ppb
Se	82	4752		43.18329		ppb
Rh	103	282148.6				ppb
Ag	107	321692.8		45.43704		ppb
Ag	109	302390.2		44.6165		ppb
Cd	111	74571.4		49.73323		ppb
Cd	114	171069.6		50.66335		ppb
Sb	121	266900.9		50.56279		ppb
Sb	123	206506.5		50.84024		ppb
Ba	135	97191		54.84271		ppb
Ba	137	172084.7		55.84021		ppb
Ho	165	687327.5				ppb
Tl	205	1095099.4		54.37845		ppb
Pb	208	1750553.1		65.73708		ppb
Kr	83	225.3				ppb

Method 6020 & 200.8 Metals Summary Report  
 Sample ID: 5025-6  
 Sample Date Wednesday, April 27, 2005 17:31:08  
 Sample Desc Air Test Professionals  
 Concentration Results

Analyte	Mass	Meas.	Intens	Conc.	Mean	Report Unit
Li	6	145699.9				ppb
Be	9	13.3		0.0051		ppb
Sc	45	476958.1				ppb
Cr	52	22900.2		4.10351		ppb
Cr	53	3915.9		-21.98996		ppb
Mn	55	33651.6		4.44668		ppb
Co	59	790.4		0.09165		ppb
Ni	60	5452.8		4.34179		ppb
Cu	63	8987.6		3.14288		ppb
Cu	65	4549.1		3.16284		ppb
Zn	66	10307.5		10.51926		ppb
Zn	67	1857.8		4.4863		ppb
Zn	68	11869.7		14.43372		ppb
As	75	694.4		0.44802		ppb
Se	77	137.3		-13.0337		ppb
Se	82	-70.4		-0.87317		ppb
Rh	103	280740.8				ppb
Ag	107	1448.4		-0.50436		ppb
Ag	109	1123.7		-0.53582		ppb
Cd	111	539.2		0.30776		ppb
Cd	114	28.4		-0.04637		ppb
Sb	121	15557.3		0.74119		ppb
Sb	123	11934.2		0.73433		ppb
Ba	135	17951.5		9.66458		ppb
Ba	137	31984.1		9.90402		ppb
Ho	165	686700.3				ppb
Tl	205	407.3		-0.04983		ppb
Pb	208	30466.5		0.96755		ppb
Kr	83	239				ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 1

Sample Date Wednesday, April 27, 2005 17:34:11

Sample Description:

Concentration Results

Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
> Li	6	137586.5		ppb
Be	9	17	0.02555	ppb
P	31	5357.4	5.89557	ppb
Sc	45	127660.3		ppb
Cr	52	4305.7	0.00242	ppb
Cr	53	12811.9	-6.40774	ppb
Mn	55	1239.4	0.0132	ppb
Co	59	309.3	0.00449	ppb
Ni	60	198.7	-0.01002	ppb
Cu	63	426.3	0.01261	ppb
Cu	65	377.7	0.02822	ppb
Zn	66	1806.1	-0.25026	ppb
Zn	67	992.4	-2.29308	ppb
Zn	68	3376.1	-0.12647	ppb
As	75	272.2	0.03928	ppb
Se	77	858.4	-4.3219	ppb
Se	82	40	0.13204	ppb
> Rh	103	286154.4		ppb
Ag	107	1131.1	-0.55322	ppb
Ag	109	1101.7	-0.54231	ppb
Cd	111	75.4	-0.00444	ppb
Cd	114	171.4	-0.0047	ppb
Sb	121	760.7	-2.19964	ppb
Sb	123	558.6	-2.20211	ppb
Ba	135	996.4	-0.0263	ppb
Ba	137	1775.8	-0.02515	ppb
> Ho	165	700848.7		ppb
Tl	205	1304.4	-0.00651	ppb
Pb	208	3828.9	-0.03951	ppb
Kr	83	80		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 4

Sample Date Wednesday, April 27, 2005 17:37:14

Sample Description:

Concentration Results

Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
> Li	6	134305.3		ppb
Be	9	20583	97.49114	ppb
P	31	188691.6	917.11756	ppb
Sc	45	123422.5		ppb
Cr	52	448212.2	98.88602	ppb
Cr	53	68499.2	96.03959	ppb
Mn	55	699986.6	96.89809	ppb
Co	59	564616.2	102.45543	ppb
Ni	60	123820.2	103.76499	ppb
Cu	63	285202.3	105.52179	ppb
Cu	65	138976.2	105.48163	ppb
Zn	66	80633.7	100.69445	ppb
Zn	67	13859.9	98.01883	ppb
Zn	68	61055.8	99.59312	ppb
As	75	103834.2	100.4624	ppb
Se	77	8866.2	96.39495	ppb
Se	82	10267.6	95.34296	ppb
> Rh	103	276843.1		ppb
Ag	107	691656.1	100.42551	ppb
Ag	109	652300.5	98.91187	ppb
Cd	111	144894.9	98.53534	ppb
Cd	114	332492.7	100.42416	ppb
Sb	121	489906.9	95.98973	ppb
Sb	123	379316.6	96.56719	ppb
Ba	135	173647.1	99.69543	ppb
Ba	137	306421.7	101.18028	ppb
> Ho	165	678762.7		ppb
Tl	205	2045768.2	102.92263	ppb
Pb	208	2806408.5	106.83497	ppb
Kr	83	109.7		ppb



Sample_ID	Sam_Date	Sam_Time	Mean_Sig	Mean_ST	Mean_SA	Units	Wt	Dilu	Sig 1	Std_U 1	Smp_U 1	Sig 2	Std_U 2	Smp_U 2
Calib Blank	4/28/2005	11:51:28	0.0027957			µg			0.0027957					
STD1= .004ug	4/28/2005	11:52:31	0.00088695			µg			0.00088695					
STD2= .04ug	4/28/2005	11:53:34	0.0089693			µg			0.0089693					
STD3= .08ug	4/28/2005	11:54:40	0.01892292			µg			0.01892292					
STD4= .12ug	4/28/2005	11:55:46	0.0278251			µg			0.0278251					
STD5= .16ug	4/28/2005	11:56:53	0.03692484			µg			0.03692484					
STD6= .2ug	4/28/2005	11:58:01	0.0455162			µg			0.0455162					
Reagent Blank	4/28/2005	11:59:37	0.00006637	0.00029396	0.00029396	µg			0.00018154	0.00080407	0.00080407	-0.0000487	-0.0002161	-0.0002161
0.004 = DL	4/28/2005	12:04:02	0.00083476	0.00369569	0.00369569	µg			0.00083476	0.00369569	0.00369569			
0.080 = QC STD 2	4/28/2005	12:05:09	0.01819567	0.07973295	0.07973295	µg			0.01819567	0.07973295	0.07973295			
0.080 = QC STD 3	4/28/2005	12:06:16	0.01918385	0.08401424	0.08401424	µg			0.01918385	0.08401424	0.08401424			
REAGENT BLANK	4/28/2005	12:07:20	0.0001008	0.0004465	0.0004465	µg			0.0001008	0.0004465	0.0004465			
0.004 = DL	4/28/2005	12:25:27	0.00088292	0.0039088	0.0039088	µg	4	500	0.00088292	0.0039088	0.0039088			
0.080 = QC STD 2	4/28/2005	12:26:34	0.01800944	0.07892556	0.07892556	µg			0.01800944	0.07892556	0.07892556			
REAGENT BLANK	4/28/2005	12:27:38	0.00012063	0.00053429	0.00053429	µg			0.00012063	0.00053429	0.00053429			
5025-A-1	4/28/2005	12:38:40	0.00018726	0.00082956	0.00082956	µg			0.00027556	0.00122042	0.061021	0.00009895	0.0004383	0.02191516
5025-A-2/3	4/28/2005	12:40:16	0.00006487	0.00028733	0.00028733	µg			0.0000283	0.00012539	0.00626958	0.00010143	0.00044927	0.02246639
5025-A-4	4/28/2005	12:41:54	-0.000008	0.00000355	-0.00017765	µg			-0.0000156	-0.0000691	-0.0034592	-0.0000004	-0.0000018	-0.0000937
5025-A-5-SPK	4/28/2005	12:43:31	0.01844641	0.08081976	0.08081976	µg			0.01845019	0.08083614	4.04180732	0.01844263	0.08080338	4.04016947
0.004 = DL	4/28/2005	12:45:46	0.00089887	0.0039794	0.0039794	µg			0.00089887	0.0039794	0.0039794			
0.080 = QC STD 2	4/28/2005	12:46:53	0.01839917	0.08061502	0.08061502	µg			0.01839917	0.08061502	0.08061502			
REAGENT BLANK	4/28/2005	12:47:57	0.00007547	0.00033431	0.00033431	µg			0.00007547	0.00033431	0.00033431			
5025-A-6	4/28/2005	12:49:33	0.0000531	0.00017618	0.00017618	µg			0.00005161	0.00022859	0.01142399	0.0000546	0.00024186	0.01209346
5025-B-1	4/28/2005	12:51:10	0.00643973	0.02841546	0.02841546	µg			0.00639522	0.0282198	3.52747591	0.00648424	0.02861112	3.57639002
5025-B-2/3	4/28/2005	12:52:50	0.00931505	0.0410329	0.0410329	µg			0.00927939	0.04087672	5.10959108	0.0093507	0.04118907	5.14863485
5025-B-4	4/28/2005	12:54:25	0.01416465	0.06221683	0.06221683	µg			0.01418946	0.06232429	7.79061337	0.01413984	0.06210876	7.76359583
5025-B-5-SPK	4/28/2005	12:55:57	0.03117714	0.13558086	0.13558086	µg			0.03107378	0.13513956	16.8924459	0.0312805	0.13602215	17.0027695
5025-B-6	4/28/2005	12:57:29	0.00029059	0.00128684	0.00128684	µg			0.000464	0.00205472	0.20547202	0.00011717	0.00051897	0.05189794
5025-BH-1	4/28/2005	12:59:02	0.02592464	0.11308622	0.11308622	µg			0.02570962	0.11216254	8.4121907	0.02613966	0.1140099	8.55074258
5025-BH-2/3	4/28/2005	13:00:35	0.02360066	0.10308932	0.10308932	µg			0.02367091	0.10339194	8.01287576	0.02353041	0.10278669	7.965966905
5025-BH-4	4/28/2005	13:02:10	0.01311764	0.05765358	0.05765358	µg			0.01311414	0.05763832	4.6110656	0.01312114	0.05766884	4.61350773
5025-BH-5-SPK	4/28/2005	13:03:44	0.03142129	0.13662304	0.13662304	µg			0.03124059	0.13585174	10.8681399	0.031602	0.13739433	10.9915471
0.004 = DL	4/28/2005	13:05:58	0.00091281	0.00404106	0.00404106	µg			0.00091281	0.00404106	0.00404106			
0.080 = QC STD 2	4/28/2005	13:07:05	0.018561	0.08131632	0.08131632	µg			0.018561	0.08131632	0.08131632			
REAGENT BLANK	4/28/2005	13:08:09	0.00017973	0.00079603	0.00079603	µg			0.00017973	0.00079603	0.00079603			
5025-BH-6	4/28/2005	13:09:43	-0.0000407	0.00013534	-0.00013534	µg			-0.0000352	-0.0001563	-0.0117248	-0.0000461	-0.0002045	-0.0153421
0.004 = DL	4/28/2005	13:26:27	0.00095026	0.00420676	0.00420676	µg			0.00095026	0.00420676	0.00420676			
0.080 = QC STD 2	4/28/2005	13:27:34	0.01870361	0.08193424	0.08193424	µg			0.01870361	0.08193424	0.08193424			
REAGENT BLANK	4/28/2005	13:28:38	0.00017892	0.00079246	0.00079246	µg			0.00017892	0.00079246	0.00079246			
0.004 = DL	4/28/2005	14:41:32	0.00094513	0.00418406	0.00418406	µg			0.00094513	0.00418406	0.00418406			
0.080 = QC STD 3	4/28/2005	14:42:39	0.01914398	0.08384159	0.08384159	µg			0.01914398	0.08384159	0.08384159			
REAGENT BLANK	4/28/2005	14:43:44	0.00025959	0.00114968	0.00114968	µg			0.00025959	0.00114968	0.00114968			
Calib Blank	4/28/2005	15:30:36	0.00315633			µg			0.00315633					

Sample_ID	Sam_Date	Sam_Time	Mean_Sig	Mean_ST	Mean_SA	Units	Wt	Dilu	Sig 1	Std_U 1	Smp_U 1	Sig 2	Std_U 2	Smp_U 2
STD1=.004ug	4/28/2005	15:31:40	0.00110669			µg			0.00110669					
STD2=.04ug	4/28/2005	15:32:44	0.01024893			µg			0.01024893					
STD3=.08ug	4/28/2005	15:33:49	0.02107251			µg			0.02107251					
STD4=.12ug	4/28/2005	15:34:55	0.03059855			µg			0.03059855					
STD5=.16ug	4/28/2005	15:36:02	0.04119103			µg			0.04119103					
STD6=.2ug	4/28/2005	15:37:10	0.05061039			µg			0.05061039					
Reagent Blank	4/28/2005	15:38:46	0.00037005	0.00137381	0.00137381	µg			0.0006621	0.00245827	0.00245827	0.00007799	0.00028936	0.00028936
0.004 = DL	4/28/2005	15:42:25	0.00110223	0.00409474	0.00409474	µg			0.00110223	0.00409474	0.00409474			
0.080 = QC STD 2	4/28/2005	15:43:31	0.02159506	0.08245496	0.08245496	µg			0.02159506	0.08245496	0.08245496			
0.080 = QC STD 3	4/28/2005	15:44:37	0.02113913	0.08066424	0.08066424	µg			0.02113913	0.08066424	0.08066424			
REAGENT BLANK	4/28/2005	15:45:41	0.00043178	0.00160263	0.00160263	µg			0.00043178	0.00160263	0.00160263			
5025/5031-FH-BLK	4/28/2005	15:47:14	0.00018098	0.00067154	0.01678865	µg	4	100	0.00018098	0.00067154	0.01678865			
5025/5031-FH-BLK-S	4/28/2005	15:48:47	0.01905613	0.07251101	4.53193813	µg	1.6	100	0.01898927	0.07225007	4.51562971	0.01912298	0.07277194	4.54824655
5025-FH-2/3	4/28/2005	15:51:57	0.00067335	0.00250005	0.06250145	µg	4	100	0.00067335	0.00251309	0.06282736	0.0001588	0.00042995	0.01074885
5025-FH-4	4/28/2005	15:53:34	0.00013547	0.00050263	0.01256578	µg	4	100	0.00013547	0.0005753	0.01438272	0.0001588	0.00042995	0.01074885
5025-FH-5-SPK	4/28/2005	15:55:11	0.02347405	0.09985846	2.24646173	µg	4	100	0.02339446	0.09954408	2.23860209	0.02355363	0.09017285	2.25432136
5025/5031-FH-6	4/28/2005	15:56:49	0.00067602	0.00251008	0.06275211	µg	4	100	0.00081606	0.0030305	0.0757625	0.00053598	0.00198966	0.04974172
0.004 = DL	4/28/2005	16:02:42	0.00113023	0.00419891	0.00419891	µg	4	100	0.00113023	0.00419891	0.00419891			
0.080 = QC STD 2	4/28/2005	16:03:50	0.02169196	0.08283586	0.08283586	µg	4	100	0.02169196	0.08283586	0.08283586			
REAGENT BLANK	4/28/2005	16:04:54	0.00041923	0.00155603	0.00155603	µg	4	100	0.00041923	0.00155603	0.00155603			
Call Blank	4/28/2005	17:17:54	0.0033103			µg	4	200	0.0033103					
STD1=.004ug	4/28/2005	17:18:57	0.00098543			µg	4	200	0.00098543					
STD2=.04ug	4/28/2005	17:20:02	0.01046968			µg	4	200	0.01046968					
STD3=.08ug	4/28/2005	17:21:07	0.02137058			µg	4	200	0.02137058					
STD4=.12ug	4/28/2005	17:22:13	0.03152574			µg	4	200	0.03152574					
STD5=.16ug	4/28/2005	17:23:20	0.04216271			µg	4	200	0.04216271					
STD6=.2ug	4/28/2005	17:24:28	0.05159739			µg	4	200	0.05159739					
Reagent Blank	4/28/2005	17:29:02	0.00047997	0.00187354	0.00187354	µg	4	200	0.00097793	0.00381736	0.00381736	-0.0000179	-0.0000702	-0.0000702
0.004 = DL	4/28/2005	17:30:07	0.00099915	0.00390014	0.00390014	µg	4	200	0.00099915	0.00390014	0.00390014			
0.080 = QC STD 2	4/28/2005	17:31:14	0.02166576	0.08354377	0.08354377	µg	4	200	0.02166576	0.08354377	0.08354377			
0.080 = QC STD 3	4/28/2005	17:32:21	0.02162116	0.08337398	0.08337398	µg	4	200	0.02162116	0.08337398	0.08337398			
REAGENT BLANK	4/28/2005	17:33:25	0.00047467	0.00185343	0.00185343	µg	4	200	0.00047467	0.00185343	0.00185343			
5025-FH-1	4/28/2005	17:34:59	0.00068333	0.00266783	0.06669579	µg	4	100	0.00079048	0.00308598	0.07714973	0.00057618	0.00224967	0.05624184
0.004 = DL	4/28/2005	17:50:33	0.00096775	0.00377764	0.00377764	µg	4	200	0.00096775	0.00377764	0.00377764			
0.080 = QC STD 2	4/28/2005	17:51:40	0.02139496	0.0825127	0.0825127	µg	4	200	0.02139496	0.0825127	0.0825127			
REAGENT BLANK	4/28/2005	17:52:44	0.00044525	0.0017386	0.0017386	µg	4	200	0.00044525	0.0017386	0.0017386			



1 of 2

**ATP - Air Test Professionals, Inc.**  
 1201 North Graham Avenue  
 Indianapolis, Indiana 46219

Phone (317) 345-1723  
 Fax (317) 351-0411  
 Email: atp\_stack@sbcglobal.net

**COPY**

**CHAIN OF CUSTODY RECORD**

CUSTOMER INFORMATION		PROJECT INFORMATION		BILLING INFORMATION		REMARKS/PRECAUTIONS	
COMPANY:	ATP	PROJECT NAME/NUMBER:	Nucor Steel - PPF #2				
SEND REPORT TO:	Carlos Brown	BILL TO:					
ADDRESS:	1201 N. Graham Ave.	ADDRESS:	Same				
PHONE:	(317) 345-1723	PHONE:					
FAX:	(317) 351-0411	FAX:					
		PO NO.:	127				
		LAB JOB NO.:	5025				
Run 1	Container #1 - Filter	04/18/05	Filter	Petri	1	X	* ANALYZE FOR 16-METALS + MERCURY
Run 1	Container #3 - 0.1N HNO3	04/18/05	AQ	500 ml	1	X	
Run 1	Container #4 - HNO3/H2O2	04/18/05	AQ	500 ml	1	X	
Run 1	Container #5A - 0.1N HNO3	04/18/05	AQ	500 ml	1	X	
Run 2	Container #1 - Filter	04/18/05	Filter	Petri	1	X	
Run 2	Container #3 - 0.1N HNO3	04/18/05	AQ	500 ml	1	X	
Run 2	Container #4 - HNO3/H2O2	04/18/05	AQ	500 ml	1	X	
Run 2	Container #5A - 0.1N HNO3	04/18/05	AQ	500 ml	1	X	
SAMPLER:	Carlos Brown	SHIPMENT METHOD:		AIRBILL NO.:			
REQUIRED TURN AROUND: *							
SIGNATURE: <i>[Signature]</i>		DATE: 04/19/05	SIGNATURE:		DATE:		
PRINTED NAME/COMPANY: ATP		TIME:	PRINTED NAME/COMPANY:		TIME:		
RECEIVED BY: <i>[Signature]</i>		DATE: 04/21/05	RECEIVED BY SIGNATURE:		DATE:		
PRINTED NAME/COMPANY: ELEMENT ONE INC		TIME: 1615	PRINTED NAME/COMPANY:		TIME:		

EPA Method 29

No. of Containers

# ATP - Air Test Professionals, Inc.

1201 North Graham Avenue  
Indianapolis, Indiana 46219

Phone (317) 345-1723  
Fax (317) 351-0411  
Email: atp\_stack@sbeGLOBAL.net

# COP

1 of 1

## CHAIN OF CUSTODY RECORD

CUSTOMER INFORMATION		PROJECT INFORMATION		BILLING INFORMATION		REMARKS/REVISIONS	
COMPANY:	ATP	PROJECT NAME/NUMBER:	Nucor Steel - PPFF #2	BILLING INFORMATION			
SEND REPORT TO:	Carlos Brown	BILL TO:					
ADDRESS:	1201 N. Graham Ave.	ADDRESS:	Same				
PHONE:	(317) 345-1723	PHONE:					
FAX:	(317) 351-0411	FAX:					
		PO NO:	127				
Run 1	Container #5B - KMnO4	04/19/05	AQ	1000 ml	1	X	* ANALYZE FOR 16-METALS + MERCURY
Run 2	Container #5B - KMnO4	04/19/05	AQ	1000 ml	1	X	
Run 3	Container #5B - KMnO4	04/19/05	AQ	1000 ml	1	X	
BLANK	Container #10 - KMnO4	04/19/05	AQ	500 ml	1	X	
SAMPLER:	Carlos Brown	SHIPMENT METHOD:		AIRBILL NO:			
REQUIRED TURNAROUND:							
SIGNATURE	<i>[Signature]</i>	DATE	04/19/05	SIGNATURE	<i>[Signature]</i>	DATE	
PRINTED NAME/COMPANY	ATP	TIME		PRINTED NAME/COMPANY		TIME	
RECEIVED BY	<i>[Signature]</i>	DATE	4/22/05	RECEIVED BY	<i>[Signature]</i>	DATE	
SIGNATURE	<i>[Signature]</i>	TIME	1145	SIGNATURE	<i>[Signature]</i>	TIME	
PRINTED NAME/COMPANY	Element One Inc			PRINTED NAME/COMPANY	Element One Inc		

EPA Method 29

LAB JOB NO.  
5025

No. of Containers

*[Signature]*  
ATP

*[Signature]*  
Element One Inc

# ATP - Air Test Professionals, Inc.

1201 North Graham Avenue  
Indianapolis, Indiana 46219

# COPY

Phone (317) 345-1723  
Fax (317) 351-0411  
Email: atp\_stack@sbcglobal.net

4 of 2

## CHAIN OF CUSTODY RECORD

CUSTOMER INFORMATION		PROJECT INFORMATION		BILLING INFORMATION		LABORATORY INFORMATION		REMARKS / PRECAUTIONS	
COMPANY:	ATP	PROJECT NAME/NUMBER:	Nucor Steel - PPF #2	BILL TO:		LABORATORY:			
SEND REPORT TO:	Carlos Brown	ADDRESS:	1201 N. Graham Ave.	PHONE:	(317) 345-1723	ANALYSIS:			
ADDRESS:	Indianapolis, Indiana 46219	BILL TO:	Same	FAX:	(317) 351-0411	CONTAINER:			
PHONE:		ADDRESS:		PO NO:	127	DATE:			
FAX:		PHONE:				TIME:			
Run 3	Container #1 - Filter	DATE:	04/19/05	Filter	Petri				
Run 3	Container #3 - 0.1N HNO3	DATE:	04/19/05	AQ	500 ml				
Run 3	Container #4 - HNO3/H2O2	DATE:	04/19/05	AQ	500 ml				
Run 3	Container #5A - 0.1N HNO3	DATE:	04/19/05	AQ	500 ml				
BLANK	Container #8A - 0.1N HNO3	DATE:	04/19/05	AQ	500 ml				
BLANK	Container #8B - HPLC H2O	DATE:	04/19/05	AQ	500 ml				
BLANK	Container #9 - HNO3/H2O2	DATE:	04/19/05	AQ	500 ml				
BLANK	Container #12 - Filter	DATE:	04/19/05	Filter	Petri				
SAMPLER: Carlos Brown		SHIPMENT METHOD:		AIRBILL NO:					
<p>REQUIRED TURNAROUND:</p> <p>RECEIVED BY: <i>[Signature]</i> DATE: 04/19/05 TIME: <i>[Blank]</i></p> <p>PRINTED NAME/COMPANY: ATP</p> <p>RECEIVED BY: <i>[Signature]</i> DATE: 4/21/05 TIME: 16:15</p> <p>PRINTED NAME/COMPANY: ELEMENT ONE INC</p>									

EPA Method 29

LAB JOB NO.  
5025

\* ANALYZE FOR  
16 - METALS  
+ MERCURY

No. of Containers

1 X  
1 X  
1 X  
1 X

# CALIBRATION CHECK

(Post Test) per EMTIC Guideline GD-26

Company: Nucor Steel  
 Date: 4/18/05, 4/19/05, 4/22/05  
 Source: PPF Baghouse #2  
 Location: Crawfordsville, Indiana

	Run 1	Run 2	Run 3	Average
Y qa =	1.027	1.027	1.026	1.027
Average result must be within 5% of Y				
Result (%)	3.66			
PASSED POST CAL				
Dry Gas Meter Box:				
ID:	A-1			
Y:	0.99			
Delta H:	1.72			

Run 1	Volume	Delta H	DGM Inlet	DGM Outlet
1		1.82	98	98
2		1.98	94	95
3		2.31	95	94
4		1.82	95	94
5		1.49	92	91
6		1.49	94	91
7		1.82	92	91
8		1.32	94	92
9		0.83	92	92
10		2.31	92	92
11		1.32	92	90
12		1.32	94	91
13		3.30	94	92
14		2.48	96	93
15		1.65	96	94
16		4.29	92	91
17		4.29	94	92
18		3.96	94	92
19		4.79	94	92
20		4.46	94	92
21		4.29	96	93
22		4.62	96	94
23	1117.533	4.62	98	95
24	844.2	4.95	97	95
25		5.45	96	95

Volume	Delta H	Meter Temp
273.333	2.917	93.6

Barometric Pressure
30.15

Test Time
287.50

Y qa:	1.027
-------	-------

Run 2	Volume	Delta H	DGM Inlet	DGM Outlet
1		3.51	87	86
2		4.68	87	86
3		5.51	87	86
4		2.67	89	88
5		4.34	92	90
6		5.01	96	93
7		3.34	99	96
8		4.51	100	98
9		4.18	83	82
10		2.84	84	84
11		3.84	87	84
12		4.51	87	84
13		3.17	87	85
14		4.68	88	86
15		4.51	87	86
16		2.34	84	84
17		2.17	86	84
18		1.50	85	84
19		1.34	86	85
20		1.34	87	85
21		1.34	87	85
22		1.34	86	86
23	398.785	1.17	86	85
24	119.911	1.50	86	85
25		1.50	86	85

Volume	Delta H	Meter Temp
278.874	3.073	87.2

Barometric Pressure
30.15

Test Time
287.50

Y qa:	1.027
-------	-------

Run 3	Volume	Delta H	DGM Inlet	DGM Outlet
1		2.15	58	57
2		2.15	60	58
3		1.98	63	59
4		1.49	64	61
5		1.32	65	61
6		1.32	67	63
7		1.65	69	64
8		1.16	72	67
9		0.99	74	69
10		1.16	75	71
11		1.16	76	72
12		1.32	77	73
13		1.32	76	75
14		2.81	77	75
15		2.31	77	75
16		3.96	77	75
17		4.29	79	76
18		4.46	79	76
19		5.12	79	77
20		5.61	79	77
21		4.62	78	77
22		4.95	80	77
23	670.85	5.45	81	78
24	399.318	5.61	83	79
25		5.61	84	80

Volume	Delta H	Meter Temp
271.529	2.957	72.4

Barometric Pressure
29.87

Test Time
287.50

Y qa:	1.026
-------	-------

**CALIBRATION CHECK**

(Post Test) per EMTIC Guideline GD-26

Company: Nucor Steel  
 Date: 4/18/05, 4/19/05  
 Source: PPF Baghouse #2 - Metals/VOC  
 Location: Crawfordsville, Indiana

	Run 1	Run 2	Run 3	Average
Y qa =	0.978	1.002	1.003	0.995
Average result must be within 5% of Y				
Result (%)	0.45			
<b>PASSED POST CAL</b>				
<b>Dry Gas Meter Box:</b>				
ID:	A-2			
Y:	0.99			
Delta H:	1.83			

Run 1	Volume	Delta H	DGM Inlet	DGM Outlet
1		2.62	96	96
2		2.62	95	95
3		2.62	93	93
4		2.62	93	94
5		2.62	94	94
6		2.46	95	93
7		2.30	95	93
8		2.30	94	93
9		2.13	94	93
10		2.05	94	93
11		2.05	95	93
12		2.30	94	93
13		1.80	93	93
14		2.46	93	93
15		2.46	93	93
16		1.23	93	92
17		1.31	93	92
18		0.82	93	92
19		0.82	93	92
20		0.66	92	91
21		0.49	92	91
22		0.98	92	91
23	852.265	0.98	93	91
24	758	0.74	93	91
25		0.74	93	92

Volume	Delta H	Meter Temp
94.265	1.768	93.1

Barometric Pressure
30.15

Test Time
125.00

Y qa:	0.978
-------	-------

Run 2	Volume	Delta H	DGM Inlet	DGM Outlet
1		1.31	89	89
2		1.39	89	89
3		1.39	89	89
4		0.98	89	89
5		0.98	90	89
6		0.98	90	89
7		0.98	90	89
8		0.57	91	89
9		0.57	91	89
10		0.90	91	89
11		0.74	92	90
12		0.74	92	90
13		1.31	93	91
14		1.15	93	91
15		1.15	94	91
16		1.89	95	92
17		2.46	97	93
18		2.46	97	93
19		2.46	97	94
20		2.40	97	93
21		2.40	97	93
22		2.40	98	94
23	938.69	2.40	98	94
24	852.71	2.40	98	94
25		2.21	98	94

Volume	Delta H	Meter Temp
85.98	1.546	92.2

Barometric Pressure
30.15

Test Time
125.00

Y qa:	1.002
-------	-------

Run 3	Volume	Delta H	DGM Inlet	DGM Outlet
1		1.91	92	90
2		1.91	92	90
3		1.83	93	91
4		1.99	95	91
5		1.98	97	93
6		2.08	99	95
7		2.24	99	96
8		2.32	102	98
9		2.32	103	98
10		2.49	104	100
11		2.49	107	102
12		2.48	107	102
13		1.83	108	103
14		1.66	95	95
15		1.66	96	95
16		1.08	94	93
17		0.83	94	93
18		0.85	94	93
19		0.94	95	93
20		0.68	94	93
21		0.68	94	93
22		0.85	94	93
23	1027.05	0.85	94	93
24	939.3	0.85	95	94
25		0.85	96	93

Volume	Delta H	Meter Temp
87.75	1.587	96.1

Barometric Pressure
29.87

Test Time
125.00

Y qa:	1.003
-------	-------



APEX INSTRUMENTS  
 EPA Method 5  
 522 Series Meter Box Calibration  
 Post-Test Orifice Method  
 English Meter Box Units, English K' Factor

Filename: Orifice Calibration

Serial #: **A1** Date: 01/31/05  
 Barometric Pressure: 30.4 in Hg  
 Critical Orifice Vacuum: 19 in Hg

**IMPORTANT!!** For valid test results, the Critical Orifice Vacuum must be equal to or higher than the value shown above. The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>\*(deg R)<sup>0.5</sup>/((in.Hg)\*(min)).

----- DRY GAS METER READINGS -----

dH (in H2O)	Time (min)	Volume		Volume		Final Temps.		Orifice K' Orifice Serial# (number)	Coefficient (see above)	Ambient Temperature		Average (deg F)
		Initial (cu ft)	Final (cu ft)	Initial (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)			Initial (deg F)	Final (deg F)	
0.38	14.20	396	401	58	68	69	68	AT-15	0.269	19	70	70
0.38	14.20	401	406	5	68	70	68	AT-15	0.269	19	70	70
0.38	14.20	406	411	5	68	71	69	AT-15	0.269	19	70	70

\*\*\*\*\* RESULTS \*\*\*\*\*

--- DRY GAS METER ---		----- ORIFICE -----		--- DRY GAS METER ---		----- ORIFICE -----	
VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	Value (number)	Variation (number)	Value (in H2O)	Variation (in H2O)
Vm(std) (cu ft)	Vm(std) (liters)	Vcr(std) (cu ft)	Vm(std) (liters)	0.9928294	-0.0011	1.724942094	0.00434
5.08044375	143.878	5.04401388	142.84647	0.9937691	-0.00016	1.721681334	0.001079
5.07563955	143.742	5.04401388	142.84647	0.9951787	0.001253	1.715183278	-0.00542
5.06845026	143.539	5.04401388	142.84647	Average Y ----->		1.721 43.703297 <----- Average dH@	

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.

For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.

Calibrated by: Carlos Brown Date: January 31, 2005

APEX INSTRUMENTS  
 EPA Method 5  
 522 Series Meter Box Calibration  
 Post-Test Orifice Method  
 English Meter Box Units, English 'K' Factor

Filename: Orifice Calibration

Serial #: **A2** Date: 01/31/05  
 Barometric Pressure: 30.4 in Hg  
 Critical Orifice Vacuum: 20 in Hg

**IMPORTANT!!!** For valid test results, the Critical Orifice Vacuum must be equal to or higher than the value shown above.  
 The Critical Orifice Coefficient, K, must be entered in English units, (ft)<sup>3</sup>\*(deg R)<sup>0.5</sup>/((in.Hg)<sup>3</sup>\*(min)).

CRITICAL ORIFICE READINGS

dH (in H2O)	Time (min)	Volume		Initial Temps.		Final Temps.		Orifice K' Orifice Serial# (number)	Orifice Coefficient (see above)	Ambient Temperature		
		Initial (cu ft)	Final (cu ft)	Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)			Initial (deg F)	Final (deg F)	Average (deg F)
0.39	14.35	368	373	5	69	70	70	AT-15	0.264	20	70	70
0.39	14.35	373	378	5	70	71	70	AT-15	0.264	20	70	70
0.39	14.35	378	383	5	71	72	70	AT-15	0.264	20	70	70

DRY GAS METER READINGS

\*\*\*\*\* RESULTS \*\*\*\*\*

--- DRY GAS METER ---		----- ORIFICE -----		-- DRY GAS METER --		----- ORIFICE -----	
VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	Value (number)	Variation (number)	Value (in H2O)	Variation (in H2O)
Vm(std) (cu ft)	Vm(std) (liters)	Vcr(std) (cu ft)	Vm(std) (liters)	0.9851049	-0.00124	1.831196214	0.005745
5.06857274	143.542	4.99307592	141.40391	0.9865002	0.000155	1.82429703	-0.00115
5.06140361	143.339	4.99307592	141.40391	0.9874305	0.001085	1.820861443	-0.00459
5.05663545	143.204	4.99307592	141.40391	Average Y ----->		Average dH@	
				0.99		1.825	46.36647

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.02.

For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/-0.2.

Calibrated by: Carlos Brown Date: January 31, 2005

**ATP – Air Test Professionals, Inc.**  
**Pitot Tube Calibration**

**Reference: 40 CFR 60, Appendix A, Method 2, Section 2.1**

Probe Length/ID.: 14 ft. Type-S

External Tubing Diameter: 0.375" inches

Base to Opening Plane Distance (Pa): 0.46" inches

Base to Opening Plane Distance (Pa): 0.46" inches

	Measured	Allowable
<b>Pa/Dt</b>	1.23"	1.05 – 1.50 inches
<b>Pb/Dt</b>	1.23"	1.05 – 1.50 inches
<b>Angle <math>\alpha</math> 1</b>	0 deg	$\alpha$ 1 and $\alpha$ 2 $\leq$ 10.0
<b>Angle <math>\alpha</math> 2</b>	0 deg	$\alpha$ 1 and $\alpha$ 2 $\leq$ 10.0
<b>Angle <math>\beta</math> 1</b>	1 deg	$\beta$ 1 and $\beta$ 2 $\leq$ 10.0
<b>Angle <math>\beta</math> 2</b>	1 deg	$\beta$ 1 and $\beta$ 2 $\leq$ 10.0
<b>z (inches)</b>	0.0"	0.125 inches
<b>w (inches)</b>	0.0"	0.031 inches
	If all criteria are met, Pitot Coefficient is 0.84	Pitot Coefficient: <b>0.84</b>

Calibrated By: Carlos Brown Date Calibrated: January 14, 2005

**ATP - Air Test Professionals, Inc.**  
**Pitot Tube Calibration**

**Reference: 40 CFR 60, Appendix A, Method 2, Section 2.1**

Probe Length/ID.: 12 ft. Type-S

External Tubing Diameter: 0.375" inches

Base to Opening Plane Distance (Pa): 0.470" inches

Base to Opening Plane Distance (Pa): 0.470" inches

	Measured	Allowable
<b>Pa/Dt</b>	1.25"	1.05 – 1.50 inches
<b>Pb/Dt</b>	1.25"	1.05 – 1.50 inches
<b>Angle <math>\alpha</math> 1</b>	0 deg	$\alpha 1$ and $\alpha 2 \leq 10.0$
<b>Angle <math>\alpha</math> 2</b>	0 deg	$\alpha 1$ and $\alpha 2 \leq 10.0$
<b>Angle <math>\beta</math> 1</b>	0 deg	$\beta 1$ and $\beta 2 \leq 10.0$
<b>Angle <math>\beta</math> 2</b>	0 deg	$\beta 1$ and $\beta 2 \leq 10.0$
<b>z (inches)</b>	0.0"	0.125 inches
<b>w (inches)</b>	0.0"	0.031 inches
	If all criteria are met, Pitot Coefficient is 0.84	Pitot Coefficient: <b>0.84</b>

Calibrated By: Carlos Brown Date Calibrated: January 14, 2005

**ATP – Air Test Professionals, Inc.**  
**Thermocouple Calibration**

Probe Length/ID: 14 ft. Type-S Dry Gas Meter ID: A-1

Standard Used: Mercury Thermometer Temperature Scale: Degrees F

Temperature Range	Mercury Thermometer	Probe Thermometer
Hot Bath	510 deg	510 deg
Room Temperature	72 deg	72 deg
Ice Bath	33 deg	34 deg

Calibrated By: Carlos Brown Date Calibrated: January 14, 2005

**ATP – Air Test Professionals, Inc.**  
**Thermocouple Calibration**

Probe Length/ID: 12 ft. Type-S Dry Gas Meter ID: A-1

Standard Used: Mercury Thermometer Temperature Scale: Degrees F

<b>Temperature Range</b>	<b>Mercury Thermometer</b>	<b>Probe Thermometer</b>
Hot Bath	505 deg	505 deg
Room Temperature	72 deg	72 deg
Ice Bath	33 deg	33 deg

Calibrated By: Carlos Brown Date Calibrated: January 14, 2005

**ATP** - AIR TEST PROFESSIONALS, INC.  
Nozzle Calibration


Nozzle Type: Stainless Steel

**NOZZLE DIAMETER MEASUREMENT**

A = 0.371 inches

B = 0.371 inches

C = 0.371 inches



Calibrated by: Andrew Young

Date Calibrated: April 18, 2005

**ATP** - AIR TEST PROFESSIONALS, INC.  
Nozzle Calibration


Nozzle Type: Glass

NOZZLE DIAMETER MEASUREMENT

A = 0.3125 inches

B = 0.3125 inches

C = 0.3125 inches



Calibrated by: Andrew Young

Date Calibrated: April 18, 2005



B16079B

**Certificate of Analysis**  
EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

*Manufactured and certified at:*

AGA Gas, Inc.  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

*Produced for customer:*

AGA COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

<b>Material:</b>	6601 EPA C3H8/ZERO AIR1-99 PPM	<b>Blend Tolerance:</b>	5 % Relative
<b>Production #:</b>	100053784	<b>Store/Use Temp:</b>	35 to 90 F
<b>Batch #:</b>	02499G2070UA	<b>Blend Type:</b>	EPA Protocol
<b>Cylinder #:</b>	CC148249	<b>Cyl. Pressure:</b>	2000 psig
<b>Expiration Date:</b>	7/15/2005	<b>Balance Gas:</b>	Air
<b>Shelf Life:</b>	36 months	<b>CGA:</b>	590
		<b>Analytical Accuracy:</b>	1.00 % Relative

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
74-98-6	Propane	29	29.6 +/- 0.3 ppm	07/15/2002
132259-10-0	Air		Balance	07/15/2002

CAS #	Analyzed (For Ref Use Only)	Concentration	Analysis Date
7782-44-7	Oxygen	21 %	07/15/2002

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
74-98-6	Propane	CC100800 , GMIS	101.5 ppm	12/31/2003
74-98-6	Propane	CC92031 , GMIS	10.04 ppm	12/31/2003
7782-44-7	Oxygen	AGAC142674 , LS	21.11 %	09/01/2006

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba FLA-510	56847471	Flame Ionization	06/30/2002
Rosemount 755R	1000559	Paramagnetic	06/27/2002

This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

Analytical report approved by Roy Yoder

*Roy Yoder*



**Certificate of Analysis**

**EPA Protocol**

Performed according to EPA-600/R-97/121, Procedure G1

B16078B

Notice: This Cylinder is not to be used when pressure is under 150 psig.

*Manufactured and certified at:*

AGA Gas, Inc.  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

*Produced for customer:*

AGA COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

<b>Material:</b>	6601 EPA C3H8/ZERO AIR1-99 PPM	<b>Blend Tolerance:</b>	5 % Relative
<b>Production #:</b>	100053785	<b>Store/Use Temp:</b>	35 to 90 F
<b>Batch #:</b>	02499G2070SB1	<b>Blend Type:</b>	EPA Protocol
<b>Cylinder #:</b>	CC148384	<b>Cyl. Pressure:</b>	2000 psig
<b>Expiration Date:</b>	7/15/2005	<b>Balance Gas:</b>	Air
<b>Shelf Life:</b>	36 months	<b>CGA:</b>	590
		<b>Analytical Accuracy:</b>	1.00 % Relative

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
74-98-6	Propane	49	48.6 +/- 0.5 ppm	07/15/2002
132259-10-0	Air		Balance	07/15/2002

CAS #	Analyzed (For Ref Use Only)	Concentration	Analysis Date
7782-44-7	Oxygen	21 %	07/15/2002

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
7782-44-7	Oxygen	CC73286 , NTRM	20.89 %	09/01/2002

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba FIA-510	56847471	Flame Ionization	06/30/2002
Rosemount 755R	1000559	Paramagnetic	06/27/2002

*This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.*

Analytical report approved by Roy Yoder

*Roy Yoder*



### Certificate of Analysis EPA Protocol

B116077B

Performed according to EPA-600/R-97/121, Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

**Manufactured and certified at:**

AGA Gas, Inc.  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

**Produced for customer:**

AGA COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

<b>Material:</b>	6601 EPA C3H8/ZERO AIR1-99 PPM	<b>Blend Tolerance:</b>	5 % Relative
<b>Production #:</b>	100053786	<b>Store/Use Temp:</b>	35 to 90 F
<b>Batch #:</b>	02499G2070SC1	<b>Blend Type:</b>	EPA Protocol
<b>Cylinder #:</b>	CC148354	<b>Cyl. Pressure:</b>	2000 psig
<b>Expiration Date:</b>	7/15/2005	<b>Balance Gas:</b>	Air
<b>Shelf Life:</b>	36 months	<b>CGA:</b>	590
		<b>Analytical Accuracy:</b>	1.00 % Relative

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
74-98-6	Propane	81	77.0 +/- 0.8 ppm	07/15/2002
132259-10-0	Air		Balance	07/15/2002


CAS #	Analyzed (For Ref Use Only)	Concentration	Analysis Date
7782-44-7	Oxygen	21 %	07/15/2002

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
7782-44-7	Oxygen	CC73286 , NTRM	20.89 %	09/01/2002
74-98-6	Propane	CC100800 , GMIS	101.5 ppm	12/31/2003
74-98-6	Propane	CC92031 , GMIS	10.04 ppm	12/31/2003

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba FIA-510	56847471	Flame Ionization	06/30/2002
Rosemount 755R	1000559	Paramagnetic	06/27/2002

*This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.*

analytical report approved by Roy Yoder



CARL KOONTZ ASSOCIATES  
of Nashville, Tennessee

This is to acknowledge that

CARLOS BROWN

successfully participated in Visible Emissions  
training on MAR 24 2005

and is qualified to evaluate Visible Emissions  
for a period of six (6) months from the date of  
certification.

*Carl Koontz*  
Instructor

---

**CARL KOONTZ ASSOCIATES**  
of Nashville, Tennessee

This is to acknowledge that

RONALD STAPERT


successfully participated in Visible Emissions  
training on MAR 24 2005  
and is qualified to evaluate Visible Emissions  
for a period of six (6) months from the date of  
certification.

Carl Koontz  
Instructor

Visible Emissions Observations Form

RUN NUMBER 1

SOURCE NAME <b>NUCOR STEEL</b>			OBSERVATION DATE <b>4-18-05</b>				START TIME <b>12:47</b>		STOP TIME <b>2:15</b>	
ADDRESS			sec				sec			
			min	0	15	30	45	min	0	
CITY <b>CRAWFORDSVILLE</b>			1	0	0	0	0	31		
STATE <b>IN</b>			2	0	0	0	0	32		
ZIP			3	0	0	0	0	33		
PHONE			4	0	0	0	0	34		
SOURCE ID NUMBER <b>EAF # 100</b>			5	0	0	0	0	35		
PROCESS EQUIPMENT <b>BAGHOUSE #2</b>			6	0	0	0	0	36		
OPERATING MODE			7	0	0	0	0	37		
CONTROL EQUIPMENT			8	0	0	0	0	38		
OPERATING MODE			9	0	0	0	0	39		
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>25' X 25' STACK</b>			10	0	0	0	0	40		
HEIGHT ABOVE GROUND LEVEL START <b>170'</b> STOP			11	0	0	0	0	41		
HEIGHT RELATIVE TO OBSERVER START <b>130'</b> STOP			12	0	0	0	0	42		
DISTANCE FROM OBSERVER START <b>1100</b> STOP <input checked="" type="checkbox"/>			13	0	0	0	0	43		
DIRECTION FROM OBSERVER START <b>60°</b> STOP <input checked="" type="checkbox"/>			14	0	0	0	0	44		
DESCRIBE EMISSIONS START <b>CLEAR</b> STOP <input checked="" type="checkbox"/>			15	0	0	0	0	45		
EMISSION COLOR START <b>CLEAR</b> STOP <input checked="" type="checkbox"/>			16	0	0	0	0	46		
PLUME TYPE: <b>(CONTINUOUS)</b>			17	0	0	0	0	47		
FUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>			18	0	0	0	0	48		
WATER DROPLETS PRESENT <b>(NO)</b> YES <input checked="" type="checkbox"/>			19	0	0	0	0	49		
IF WATER DROPLET PLUME: ATTACHED <input type="checkbox"/> <b>(DETACHED)</b>			20	0	0	0	0	50		
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <b>20'</b> STOP <input checked="" type="checkbox"/>			21	0	0	0	0	51		
DESCRIBE BACKGROUND START <b>LIGHT BLUE</b> STOP <input checked="" type="checkbox"/>			22	0	0	0	0	52		
BACKGROUND COLOR START <b>LIGHT BLUE</b> STOP <input checked="" type="checkbox"/>			23	0	0	0	0	53		
SKY CONDITIONS START <b>MOSTLY SUNNY</b> STOP			24	0	0	0	0	54		
WIND SPEED (MPH) START <b>5-10</b> STOP <input checked="" type="checkbox"/>			25	0	0	0	0	55		
WIND DIRECTION START <b>NW</b> STOP <input checked="" type="checkbox"/>			26	0	0	0	0	56		
AMBIENT TEMPERATURE (F) START <b>70°</b> STOP <b>72°</b>			27	0	0	0	0	57		
			28	0	0	0	0	58		
			29	0	0	0	0	59		
			30	0	0	0	0	60		



AVERAGE OPACITY FOR HIGHEST PERIOD		NUMBER OF READINGS ABOVE WERE
RANGE OF OPACITY READINGS		
MINIMUM	MAXIMUM	
OBSERVER'S NAME (PRINT) <b>RONALD STAPERT</b>		
OBSERVER'S SIGNATURE <i>Ronald Stapert</i>		DATE <b>4-18-05</b>
ORGANIZATION <b>Air Test Professionals, Inc. (ATP)</b>		
CERTIFIED BY <b>Carl Koontz Associates</b>		DATE <b>3-24-05</b>
Comments:		

- X = Emission Point
- = Observer's Position
- ☼ = Sun
- = Wind
- = Plume

BAGHOUSE #2


212

Visible Emissions Observations Form

RUN NUMBER

1

SOURCE NAME <b>NUCOR STEEL</b>			OBSERVATION DATE <b>4 18-05</b>			START TIME <b>2:15</b>		STOP TIME <b>2:45</b>				
ADDRESS			sec				sec					
			min	0	15	30	45	min	0	15	30	45
CITY <b>CRAWFORDSVILLE</b>	STATE <b>IN</b>	ZIP	1	0	0	0	0	31				
PHONE		SOURCE ID NUMBER <b>EAF &amp; AOD</b>	2	0	0	0	0	32				
PROCESS EQUIPMENT <b>BAG HOUSE #2</b>		OPERATING MODE	3	0	0	0	0	33				
CONTROL EQUIPMENT		OPERATING MODE	4	0	0	0	0	34				
			5	0	0	0	0	35				
			6	0	0	0	0	36				
			7	0	0	0	0	37				
			8	0	0	0	0	38				
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>25' X 25' STACK</b>			9	0	0	0	0	39				
			10	0	0	0	0	40				
HEIGHT ABOVE GROUND LEVEL START <b>170'</b> STOP <input checked="" type="checkbox"/>		HEIGHT RELATIVE TO OBSERVER START <b>130'</b> STOP <input checked="" type="checkbox"/>	11	0	0	0	0	41				
			12	0	0	0	0	42				
DISTANCE FROM OBSERVER START <b>1100'</b> STOP <input checked="" type="checkbox"/>		DIRECTION FROM OBSERVER START <b>60°</b> STOP <input checked="" type="checkbox"/>	13	0	0	0	0	43				
			14	0	0	0	0	44				
DESCRIBE EMISSIONS START <b>CLEAR</b> STOP <input checked="" type="checkbox"/>			15	0	0	0	0	45				
			16	0	0	0	0	46				
EMISSION COLOR START <b>CLEAR</b> STOP <input checked="" type="checkbox"/>		PLUME TYPE: <b>CONTINUOUS</b>	17	0	0	0	0	47				
		FUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>	18	0	0	0	0	48				
WATER DROPLETS PRESENT <b>NO</b> YES <input type="checkbox"/>		IF WATER DROPLET PLUME: ATTACHED <input type="checkbox"/> <b>DETACHED</b>	19	0	0	0	0	49				
			20	0	0	0	0	50				
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <b>20'</b> STOP <input checked="" type="checkbox"/>			21	0	0	0	0	51				
			22	0	0	0	0	52				
DESCRIBE BACKGROUND START <b>LIGHT BLUE</b> STOP <input checked="" type="checkbox"/>			23	0	0	0	0	53				
			24	0	0	0	0	54				
BACKGROUND COLOR START <b>LIGHT BLUE</b> STOP <input checked="" type="checkbox"/>		SKY CONDITIONS START <b>MOSTLY SUNNY</b> STOP <input checked="" type="checkbox"/>	25	0	0	0	0	55				
			26	0	0	0	0	56				
WIND SPEED (MPH) START <b>5-10</b> STOP <input checked="" type="checkbox"/>		WIND DIRECTION START <b>NW</b> STOP <input type="checkbox"/>	27	0	0	0	0	57				
			28	0	0	0	0	58				
AMBIENT TEMPERATURE (F) START <b>76</b> STOP <b>77</b>		WIND BUILT UP <input type="checkbox"/> PLUME PRESENT <input type="checkbox"/>	29	0	0	0	0	59				
			30	0	0	0	0	60				



AVERAGE OPACITY FOR HIGHEST PERIOD	NUMBER OF READINGS ABOVE WERE
RANGE OF OPACITY READINGS	
MINIMUM	MAXIMUM
OBSERVER'S NAME (PRINT) <b>RONALD STAPERT</b>	
OBSERVER'S SIGNATURE <i>Ronald Stapert</i>	DATE <b>4 18-05</b>
ORGANIZATION <b>Air Test Professionals, Inc. (ATP)</b>	
CERTIFIED BY <b>Carl Koontz Associates</b>	DATE <b>3-27-05</b>
Comments:	

- X = Emission Point
- = Observer's Position
- ☼ = Sun
- = Wind
- = Plume

BAG HOUSE #2 (2R)




317a

Visible Emissions Observations Form

RUN NUMBER 1

SOURCE NAME NUCOR STEEL			OBSERVATION DATE 4-18-05				START TIME 2:45		STOP TIME 3:15	
ADDRESS			sec				sec			
			min	0	15	30	45	min	0	
CITY CARWINDS VILLE			STATE IN	ZIP		1	0	31		
PHONE			SOURCE ID NUMBER EAP E A00		2	0	32			
PROCESS EQUIPMENT BAG HOUSE #2			OPERATING MODE		3	0	33			
CONTROL EQUIPMENT			OPERATING MODE		4	0	34			
DESCRIBE EMISSION POINT (Stack Exit Dimensions) 25' X 25' STACK					5	0	35			
HEIGHT ABOVE GROUND LEVEL START 170' STOP -			HEIGHT RELATIVE TO OBSERVER START 130' STOP -		6	0	36			
DISTANCE FROM OBSERVER START 110' STOP ✓			DIRECTION FROM OBSERVER START 300° STOP ✓		7	0	37			
DESCRIBE EMISSIONS START CLEAR ✓ STOP ✓					8	0	38			
EMISSION COLOR START CLEAR STOP ✓			PLUME TYPE: CONTINUOUS FUGITIVE INTERMITTENT		9	0	39			
WATER DROPLETS PRESENT NO YES			IF WATER DROPLET PLUME: ATTACHED DETACHED		10	0	40			
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START STOP					11	0	41			
DESCRIBE BACKGROUND START LIGHT BLUE STOP					12	0	42			
BACKGROUND COLOR START LIGHT BLUE STOP ✓			SKY CONDITIONS START MOSTLY SUNNY STOP		13	0	43			
WIND SPEED (MPH) START 5-10 STOP ✓			WIND DIRECTION START NW STOP		14	0	44			
AMBIENT TEMPERATURE (F) START 79 STOP ✓			WET BULB GLOB TEMPERATURE PRESENT		15	0	45			



AVERAGE OPACITY FOR HIGHEST PERIOD	0	NUMBER OF READINGS ABOVE 0 WERE	0
RANGE OF OPACITY READINGS	MINIMUM 0	MAXIMUM	0
OBSERVER'S NAME (PRINT) RONALD STAPERT			
OBSERVER'S SIGNATURE Ronald Stapert		DATE 4-18-05	
ORGANIZATION Air Test Professionals, Inc. (ATP)			
CERTIFIED BY Carl Koontz Associates		DATE 4-18-05	
Comments:			

X = Emission Point      = Wind →

• = Observer's Position      = Plume

☀ = Sun


BAG HOUSE #2

4 AND 4 1/2

Visible Emissions Observations Form

RUN NUMBER 1

SOURCE NAME <b>NUCOR STEEL</b>			OBSERVATION DATE <b>4-18-05</b>				START TIME <b>345</b>		STOP TIME <b>445</b>	
ADDRESS			sec				sec			
			min	0	15	30	45	min	0	
CITY <b>CRANFORDSVILLE</b>			STATE <b>IN</b>	ZIP				0	15	
PHONE			SOURCE ID NUMBER					30	45	
PROCESS EQUIPMENT <b>BAG HOUSE #2</b>			OPERATING MODE					31	0	
CONTROL EQUIPMENT <b>25' X 25' STACK</b>			OPERATING MODE					32	0	
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>25' X 25' STACK</b>								33	0	
HEIGHT ABOVE GROUND LEVEL START <b>120'</b> STOP <input checked="" type="checkbox"/>			HEIGHT RELATIVE TO OBSERVER START <b>130'</b> STOP <input checked="" type="checkbox"/>					34	0	
DISTANCE FROM OBSERVER START <b>1100'</b> STOP <input checked="" type="checkbox"/>			DIRECTION FROM OBSERVER START <b>66°</b> STOP <input checked="" type="checkbox"/>					35	0	
DESCRIBE EMISSIONS START <b>CLEAR</b> STOP <input checked="" type="checkbox"/>								36	0	
EMISSION COLOR START <b>CLEAR</b> STOP <input checked="" type="checkbox"/>			PLUME TYPE: <u>CONTINUOUS</u>					37	0	
WATER DROPLETS PRESENT <input checked="" type="checkbox"/> YES			IF WATER DROPLET PLUME: <u>ATTACHED</u> <u>DETACHED</u>					38	0	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <b>20'</b> STOP <input checked="" type="checkbox"/>								39	0	
DESCRIBE BACKGROUND START <b>LIGHT BLUE</b> STOP <input checked="" type="checkbox"/>								40	0	
BACKGROUND COLOR START <b>LIGHT BLUE</b> STOP <input checked="" type="checkbox"/>			SKY CONDITIONS START <b>MOSTLY SUNNY</b> STOP <input checked="" type="checkbox"/>					41	0	
WIND SPEED (MPH) START <b>5-16</b> STOP <input checked="" type="checkbox"/>			WIND DIRECTION START <b>NW</b> STOP <input checked="" type="checkbox"/>					42	0	
AMBIENT TEMPERATURE (F) START <b>80'</b> STOP <input checked="" type="checkbox"/>								43	0	



AVERAGE OPACITY FOR HIGHEST PERIOD <input type="checkbox"/>	NUMBER OF READINGS ABOVE <input type="checkbox"/> WERE <input type="checkbox"/>
RANGE OF OPACITY READINGS MINIMUM <input type="checkbox"/> MAXIMUM <input type="checkbox"/>	
OBSERVER'S NAME (PRINT) <b>RONALD STAPERT</b>	
OBSERVER'S SIGNATURE <i>Ronald Stapert</i>	DATE <b>4-18-05</b>
ORGANIZATION <b>Air Test Professionals, Inc. (ATP)</b>	
CERTIFIED BY <b>Carl Koontz Associates</b>	DATE <b>3-24-05</b>
Comments:	

- X = Emission Point
- = Observer's Position
- ☼ = Sun
- = Wind
- = Plume

BAG HOUSE #2


# NUCOR STEEL

Run #

9,20-950

4-19-05 (8:20) - (8:50)

CITY CRAWFORDSULLIVAN	STATE IN	ZIP 47	1	0	0	0	0	0	31	0	0	0	0
PHONE	SOURCE ID NUMBER		2	0	0	0	0	0	32	0	0	0	0
PROCESS EQUIPMENT BAG House #2	OPERATING MODE BAF #1A0		3	0	0	0	0	0	33	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE		4	0	0	0	0	0	34	0	0	0	0
DESCRIBE EMISSION POINT START 25' X 25' STOP STACK			5	0	0	0	0	0	35	0	0	0	0
HEIGHT ABOVE GROUND LEVEL START 170' STOP	HEIGHT RELATIVE TO OBSERVER START 130' STOP ✓		6	0	0	0	0	0	36	0	0	0	0
DISTANCE FROM OBSERVER START 110 STOP ✓	DIRECTION FROM OBSERVER START 55° STOP ✓		7	0	0	0	0	0	37	0	0	0	0
DESCRIBE EMISSIONS START CLEAR STOP ✓			8	0	0	0	0	0	38	0	0	0	0
EMISSION COLOR START CLEAR STOP ✓	PLUME TYPE CONTINUOUS <input checked="" type="checkbox"/> FUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>		9	0	0	0	0	0	39	0	0	0	0
WATER DROPLETS PRESENT NO <input checked="" type="checkbox"/> YES <input type="checkbox"/>	IF WATER DROPLET PLUME: ATTACHED <input type="checkbox"/> DETACHED <input checked="" type="checkbox"/>		10	0	0	0	0	0	40	0	0	0	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START 20' UP STOP ✓			11	0	0	0	0	0	41	0	0	0	0
DESCRIBE BACKGROUND START BLUE STOP ✓			12	0	0	0	0	0	42	0	0	0	0
BACKGROUND COLOR START BLUE STOP ✓	SKY CONDITIONS MOSTLY Sunny STOP ✓		13	0	0	0	0	0	43	0	0	0	0
WIND SPEED START 5 STOP ✓	WIND DIRECTION START S STOP ✓		14	0	0	0	0	0	44	0	0	0	0
AMBIENT TEMPERATURE START 65° STOP 68	NET BULB TEMP.	R.H. PERCENT	15	0	0	0	0	0	45	0	0	0	0
SOURCE LAYOUT SKETCH			16	0	0	0	0	0	46	0	0	0	0



AVERAGE OPACITY FOR HIGHEST PERIOD	0	NUMBER OF READINGS ABOVE 0 WERE	0
RANGE OF OPACITY READINGS	MINIMUM 0	MAXIMUM 0	
OBSERVER'S NAME (PRINT)	RONALD STAPERT		
OBSERVER'S SIGNATURE	DATE	4 119 105	
ORGANIZATION	AIR TEST PROFESSIONALS INC		
CERTIFIED BY	DATE	3-24-05	
Comments:			

BAG H #2


# NUCOR STEEL

4-19-05

1,45-215  
12:45-1:15  
12:45-1:20  
RUN 2

CITY CRAWFORDSVILLE		STATE IN	ZIP	1	0	0	0	0	31	0	0	0	0
PHONE		SOURCE ID NUMBER EAF & AOD		2	0	0	0	0	32	0	0	0	0
PROCESS EQUIPMENT BAG HOUSE #2		OPERATING MODE		3	0	0	0	0	33	0	0	0	0
CONTROL EQUIPMENT		OPERATING MODE		4	0	0	0	0	34	0	0	0	0
DESCRIBE EMISSION POINT START 25' X 25' STACK STOP				5	0	0	0	0	35	0	0	0	0
HEIGHT ABOVE GROUND LEVEL START 170' STOP		HEIGHT RELATIVE TO OBSERVER START 30' STOP		6	0	0	0	0	36	0	0	0	0
DISTANCE FROM OBSERVER START 110' STOP		DIRECTION FROM OBSERVER START 60' STOP		7	0	0	0	0	37	0	0	0	0
DESCRIBE EMISSIONS START CLEAR STOP				8	0	0	0	0	38	0	0	0	0
EMISSION COLOR		PLUME TYPE: CONTINUOUS <input checked="" type="checkbox"/>		9	0	0	0	0	39	0	0	0	0
WATER DROPLETS PRESENT NO <input checked="" type="checkbox"/> YES <input type="checkbox"/>		IF WATER DROPLET PLUME: ATTACHED <input type="checkbox"/> DETACHED <input checked="" type="checkbox"/>		10	0	0	0	0	40	0	0	0	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START 20' STOP				11	0	0	0	0	41	0	0	0	0
DESCRIBE BACKGROUND START BLUE STOP				12	0	0	0	0	42	0	0	0	0
BACKGROUND COLOR START BLUE STOP <input checked="" type="checkbox"/>		SKY CONDITIONS START MOSTLY SUNNY STOP		13	0	0	0	0	43	0	0	0	0
WIND SPEED START 10-15 STOP <input checked="" type="checkbox"/>		WIND DIRECTION START S E STOP <input checked="" type="checkbox"/>		14	0	0	0	0	44	0	0	0	0
AMBIENT TEMPERATURE START 80° STOP <input checked="" type="checkbox"/>		WET BULB TEMP. R.H. PERCENT		15	0	0	0	0	45	0	0	0	0

AVERAGE OPACITY FOR HIGHEST PERIOD	0	NUMBER OF READINGS ABOVE 0 WERE	0
RANGE OF OPACITY READINGS	MINIMUM 0	MAXIMUM 0	
OBSERVER'S NAME (PRINT) RONALD STAPART		DATE 4 19 05	
OBSERVER'S SIGNATURE Ronald Stapart		DATE 3-24-05	
ORGANIZATION AIR TEST PROFESSIONAL INC			
CERTIFIED BY CARL KOONITZ		DATE 3-24-05	
Comments:			



BAG-H #2


NUCOR STEEL

4-19-05

2:45 - 3:45

CITY CRAWFORDSVILLE	STATE IN	ZIP	1	0	0	0	0	31
PHONE	SOURCE ID NUMBER		2	0	0	0	0	32
PROCESS EQUIPMENT BAG HOUSE #2	OPERATING MODE		3	0	0	0	0	33
CONTROL EQUIPMENT	OPERATING MODE		4	0	0	0	0	34
DESCRIBE EMISSION POINT START 25' X 25' STACK STOP			5	0	0	0	0	35
HEIGHT ABOVE GROUND LEVEL START 170' STOP ✓	HEIGHT RELATIVE TO OBSERVER START 130' STOP ✓		6	0	0	0	0	36
DISTANCE FROM OBSERVER START 1000 STOP ✓	DIRECTION FROM OBSERVER START 60° STOP ✓		7	0	0	0	0	37
DESCRIBE EMISSIONS START CLEAR STOP ✓			8	0	0	0	0	38
EMISSION COLOR START CLEAR STOP	PLUME TYPE: CONTINUOUS <input checked="" type="checkbox"/> FUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>		9	0	0	0	0	39
WATER DROPLETS PRESENT <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES	IF WATER DROPLET PLUME ATTACHED <input type="checkbox"/> DETACHED <input checked="" type="checkbox"/>		10	0	0	0	0	40
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START 20' STOP ✓			11	0	0	0	0	41
DESCRIBE BACKGROUND START BLUE STOP ✓	SKY CONDITIONS START MUSTY SUNNY STOP		12	0	0	0	0	42
BACKGROUND COLOR START BLUE STOP ✓	WIND SPEED START 10-15 STOP 10-15		13	0	0	0	0	43
WIND DIRECTION START SE STOP	WIND DIRECTION START SE STOP		14	0	0	0	0	44
AMBIENT TEMPERATURE START 80° STOP 86°	WET BULB TEMP.		15	0	0	0	0	45
	REL PERCENT		16	0	0	0	0	46

AVERAGE OPACITY FOR HIGHEST PERIOD	0	NUMBER OF READINGS ABOVE WERE	0
RANGE OF OPACITY READINGS	MINIMUM 0	MAXIMUM 0	
OBSERVER'S NAME (PRINT)	RONALD STAPERT		
OBSERVER'S SIGNATURE	DATE	4 19 05	
ORGANIZATION	AIR TEST PROFESSIONAL INC		
CERTIFIED BY	DATE	3-24-05	
Comments:			




BAG H #2

Visible Emissions Observations Form

RUN NUMBER

3

SOURCE NAME <i>Nucor Steel</i>			OBSERVATION DATE <i>04-22-05</i>				START TIME <i>0900</i>		STOP TIME <i>1000</i>				
ADDRESS			sec				sec						
			min	0	15	30	45	min	0	15	30	45	
CITY <i>Crawfordsville</i>	STATE <i>IN</i>	ZIP	1	0	0	0	0	31	0	0	0	0	
			2	0	0	0	0	32	0	0	0	0	
PHONE			SOURCE ID NUMBER						3	0	0	0	0
									4	0	0	0	0
PROCESS EQUIPMENT <i>EAF'S &amp; AOD</i>			OPERATING MODE						5	0	0	0	0
									6	0	0	0	0
CONTROL EQUIPMENT <i>PPFF BAGHOUSE #2</i>			OPERATING MODE <i>NORMAL</i>						7	0	0	0	0
									8	0	0	0	0
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <i>25' x 25' STACK</i>									9	0	0	0	0
									10	0	0	0	0
HEIGHT ABOVE GROUND LEVEL START <i>170'</i> STOP <i>170'</i>			HEIGHT RELATIVE TO OBSERVER START <i>140'</i> STOP <i>140'</i>						11	0	0	0	0
									12	0	0	0	0
DISTANCE FROM OBSERVER START <i>600'</i> STOP <i>600'</i>			DIRECTION FROM OBSERVER START <i>W</i> STOP <i>W</i>						13	0	0	0	0
									14	0	0	0	0
DESCRIBE EMISSIONS START <i>N/A</i> STOP <i>N/A</i>									15	0	0	0	0
									16	0	0	0	0
EMISSION COLOR START <i>N/A</i> STOP <i>N/A</i>			PLUME TYPE: CONTINUOUS						17	0	0	0	0
			FUGITIVE INTERMITTENT						18	0	0	0	0
WATER DROPLETS PRESENT <input checked="" type="radio"/> NO <input type="radio"/> YES			IF WATER DROPLET PLUME: ATTACHED DETACHED						19	0	0	0	0
									20	0	0	0	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <i>STACK EXIT</i> STOP <i>STACK EXIT</i>									21	0	0	0	0
									22	0	0	0	0
DESCRIBE BACKGROUND START <i>SKY</i> STOP <i>SKY</i>									23	0	0	0	0
									24	0	0	0	0
BACKGROUND COLOR START <i>GRAY</i> STOP <i>GRAY</i>			SKY CONDITIONS START <i>OVERCAST</i> STOP <i>OVERCAST</i>						25	0	0	0	0
									26	0	0	0	0
WIND SPEED (MPH) START <i>8-5</i> STOP <i>0-5</i>			WIND DIRECTION START <i>N</i> STOP <i>N</i>						27	0	0	0	0
									28	0	0	0	0
AMBIENT TEMPERATURE (F) START <i>55°</i> STOP <i>57°</i>			WET BULB TEMP			REL. HUMIDITY			29	0	0	0	0
									30	0	0	0	0



AVERAGE OPACITY FOR HIGHEST PERIOD

NUMBER OF READINGS ABOVE WERE

RANGE OF OPACITY READINGS

MINIMUM  MAXIMUM

OBSERVER'S NAME (PRINT)  
*Carlos Brown*

OBSERVER'S SIGNATURE  
*[Signature]* DATE *04-22-05*

ORGANIZATION  
*ATP - Air Test Professionals, Inc.*

CERTIFIED BY  
*Carl Kooztz* DATE

Comments:


- X = Emission Point
- = Observer's Position
- ☀ = Sun
- = Wind
- = Plume

Visible Emissions Observations Form

RUN NUMBER

3

SOURCE NAME NUCOR STEEL			OBSERVATION DATE 04-22-05				START TIME 1030		STOP TIME 1100	
ADDRESS			sec				sec			
			min	0	15	30	45	min	0	
CITY CRAWFORDSVILLE			STATE IN	ZIP				0	15	
PHONE			SOURCE ID NUMBER					30	45	
PROCESS EQUIPMENT EAP'S & ADD			OPERATING MODE					31	0	
CONTROL EQUIPMENT PPPP BAGHOUSE #2			OPERATING MODE NORMAL					32	0	
DESCRIBE EMISSION POINT (Stack Exit Dimensions) 25' x 25' STACK								33	0	
HEIGHT ABOVE GROUND LEVEL START 170' STOP 170'			HEIGHT RELATIVE TO OBSERVER START 170' STOP 170'					34	0	
DISTANCE FROM OBSERVER START 600' STOP 600'			DIRECTION FROM OBSERVER START W STOP W					35	0	
DESCRIBE EMISSIONS START N/A STOP N/A								36	0	
EMISSION COLOR START N/A STOP N/A			PLUME TYPE: CONTINUOUS					37	0	
WATER DROPLETS PRESENT NO YES			IF WATER DROPLET PLUME: ATTACHED DETACHED					38	0	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START STACK EXIT STOP STACK ENT								39	0	
DESCRIBE BACKGROUND START SKY STOP SKY								40	0	
BACKGROUND COLOR START GRAY STOP GRAY			SKY CONDITIONS START OVERCAST STOP OVERCAST					41	0	
WIND SPEED (MPH) START 0.5 STOP 0.5			WIND DIRECTION START N STOP N					42	0	
AMBIENT TEMPERATURE (F) START STOP			WET BULB TEMP / RH PERCENT					43	0	



AVERAGE OPACITY FOR HIGHEST PERIOD 0

NUMBER OF READINGS ABOVE WERE 0

RANGE OF OPACITY READINGS  
MINIMUM 0 MAXIMUM 0

OBSERVER'S NAME (PRINT)  
Charles Brown

OBSERVER'S SIGNATURE  
[Signature]

DATE  
04-22-05

ORGANIZATION  
ATP - Air Test Professionals, Inc.

CERTIFIED BY  
[Signature]

DATE


Comments:

- X = Emission Point
- Observer's Position
- Sun
- = Wind
- = Plume

Visible Emissions Observations Form

RUN NUMBER 3


SOURCE NAME <b>Nucor STEEL</b>			OBSERVATION DATE <b>04-22-05</b>				START TIME <b>1230</b>		STOP TIME <b>1300</b>			
ADDRESS			sec				sec					
CITY <b>Charlottesville</b>			min	0	15	30	45	min	0	15	30	45
STATE <b>VA</b>		ZIP	1	0	0	0	0	31				
PHONE		SOURCE ID NUMBER	2	0	0	0	0	32				
PROCESS EQUIPMENT <b>EAF'S # ADD</b>		OPERATING MODE	3	0	0	0	0	33				
CONTROL EQUIPMENT <b>PPAF BACTURE #2</b>		OPERATING MODE <b>NORMAL</b>	4	0	0	0	0	34				
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>25' X 25' RECTANGULAR STACK</b>			5	0	0	0	0	35				
HEIGHT ABOVE GROUND LEVEL <b>START 170' STOP 170'</b>		HEIGHT RELATIVE TO OBSERVER <b>START 170' STOP 170'</b>	6	0	0	0	0	36				
DISTANCE FROM OBSERVER <b>START 600' STOP 600'</b>		DIRECTION FROM OBSERVER <b>START W STOP W</b>	7	0	0	0	0	37				
DESCRIBE EMISSIONS <b>START N/A STOP N/A</b>			8	0	0	0	0	38				
EMISSION COLOR <b>START N/A STOP N/A</b>		PLUME TYPE: CONTINUOUS	9	0	0	0	0	39				
WATER DROPLETS PRESENT <b>NO YES</b>		IF WATER DROPLET PLUME: ATTACHED DETACHED	10	0	0	0	0	40				
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED <b>START STACK EXIT STOP STACK EXIT</b>			11	0	0	0	0	41				
DESCRIBE BACKGROUND <b>START Sky STOP Sky</b>			12	0	0	0	0	42				
BACKGROUND COLOR <b>START Gray STOP Gray</b>		SKY CONDITIONS <b>START Partly Cloudy STOP Partly Cloudy</b>	13	0	0	0	0	43				
WIND SPEED (MPH) <b>START 0-5 STOP 0-5</b>		WIND DIRECTION <b>START N STOP N</b>	14	0	0	0	0	44				
AMBIENT TEMPERATURE (F) <b>START STOP</b>		WET BULB TEMP. RH PERCENT	15	0	0	0	0	45				
SOURCE LAYOUT SKETCH			16	0	0	0	0	46				



AVERAGE OPACITY FOR HIGHEST PERIOD		NUMBER OF READINGS ABOVE WERE	
C		0 WERE 0	
RANGE OF OPACITY READINGS			
MINIMUM		MAXIMUM	
A		0	
OBSERVER'S NAME (PRINT)			
Chris Brown			
OBSERVER'S SIGNATURE			DATE
[Signature]			04-22-05
ORGANIZATION			
Air Test Professionals, Inc. (ATP)			
CERTIFIED BY			DATE
Carl Koontz Associates			
Comments:			

- X = Emission Point
- = Observer's Position
- ☀ = Sun
- = Wind
- = Plume





**COMPLIANCE TEST PROTOCOL  
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT**

Date Prepared: March 7, 2005 Proposed Test Date: To Be Determined

Plant Address and Location: 4537 South Nucor Street, Crawfordsville, IN


1. Source Information  
 AFS: Id Number: Nucor Steel Permit Number: 107-16823-00038  
 Company: 4537 South Nucor Street  
 Mail Address: Crawfordsville, Indiana Zip: 47933  
 City: Mark Washer Phone: (765) 364-1323  
 Co-Contact:

Check program if applicable:  
 FESOP: \_\_\_\_\_  
 Title V: X  
 SSOA: \_\_\_\_\_

AGENCY USE ONLY Date Rec'd: \_\_\_\_\_  
 Inspector: \_\_\_\_\_ Reviewer: \_\_\_\_\_ Date Appr: \_\_\_\_\_

2. Tester Information  
 Name: Air Test Professionals, Inc.  
 Address: 1201 N. Graham Ave.  
 Contact: Carlos M. Brown Phone: 317-345-1723  
 Pre-Test Inspection Complete? Yes

3. Process Information  
 Unit to Test: Melshop EAF Baghouse #2  
 Max. Rated Capacity: 502 tons/hour  
 Proposed Operating Speed: Normal (MAX)  
 Pollution Control Equipment: 2 Pos. Pressure Baghouses  
 Process Description: EAF's & AOD & other units  
mill scrap steel for processing



4. Test Information

Methods	# Runs	Time/Run
Method 1-4	3	~240 min
Method 5/202	3	~240 min
Method 6		
Method 29	3	120 min
Method 25A	3	60 min

Other Testing: \_\_\_\_\_

5. Sampling Strategy  
 a. Describe any deviations from the standard test method.  
None

b. Describe method used to determine quantity of raw materials  
Plant personnel will keep record production

6. Sample Site Location  
 Does sample port location meet 40 CFR 60, Appx A, Method 1  
 Section 1.2 requirements: Yes/No: yes If No, Explain \_\_\_\_\_

Number of sample points for MS: 25  
 Diameter at sample site: 25' x 25' Stack height: ~200'  
 Approx. stack gas flow (ACFM): 800,000  
 Approx. gas temp. (deg F): 150 - 200  
 Approx. gas moisture (%): 3%

Reason for test:  
 State Agreed Order: Yes/No: \_\_\_\_\_ Operating permit: Yes/No: Yes  
 Construction Permit: Yes/No: \_\_\_\_\_ Compliance w 316  
 NSPS 40 CFR 60 Subpart: \_\_\_\_\_ Other \_\_\_\_\_  
 Title V: \_\_\_\_\_  
 Other (i.e. EPA, CD, state, 114) \_\_\_\_\_

326 IAC 5-2.1 requires this completed form and fee to be submitted 35 days prior to proposed test date to:  
 (FEE NOT APPLICABLE IF FESOP OR TITLE V)

Compliance Data Section  
 Office of Air Management  
 Indiana Department of Environmental Management  
 100 North Senate  
 PO BOX 6015  
 Indianapolis, IN 46206-6015

Questions may be directed to 317-232-8338, FAX: 317-233-6865

**Nucor Steel - Crawfordsville, IN**  
**Baghouse #1 & #2 Stack Test Production Data**  
**April 18, 2005**

**PM/PM10 Run 1: 12:50 pm - 7:36 pm**

	Heat Number	Start	End	Net Ladle Tons	Total Minutes	Run Minutes	Tons During Run	Total Tons	Average tons/hr
South EAF	159264	12:32 PM	1:18 PM	130.7	46.0	38.0	108.0		
	159265	1:18 PM	2:17 PM	114.6	59.0	59.0	114.6		
	159266	2:17 PM	2:55 PM	114.0	38.0	2:20 pm - 2:47 pm	37.9		
	159267	2:55 PM	3:37 PM	115.5	40.0	40.0	115.5		
	159268	3:37 PM	4:14 PM	131.0	37.0	11.0	36.9		
	159269	4:14 PM	4:51 PM	131.0	37.0	3:48 pm - 5:08 pm	0.0		
	159270	4:51 PM	5:29 PM	131.2	38.0	21.0	72.5		
	159271	5:29 PM	6:17 PM	130.2	48.0	48.0	130.2		
	159272	6:17 PM	6:57 PM	129.5	40.0	40.0	129.5		
159273	6:57 PM	7:32 PM	131.0	35.0	35.0	131.0			
159274	7:32 PM	8:13 PM	130.5	41.0	4.0	12.7	890.9	178.9	
North EAF	254837	12:47 PM	2:06 PM	118.4	79.0	76.0	113.9		
	254838	2:06 PM	3:17 PM	119.0	74.0	2:20 pm - 2:47 pm	75.4		
	254839	3:17 PM	4:39 PM	119.0	82.0	31.0	45.0		
	254840	4:39 PM	6:01 PM	116.5	83.0	3:48 pm - 5:08 pm	75.3		
	254841	6:01 PM	7:24 PM	116.5	83.0	83.0	116.5		
254842	7:24 PM	9:40 PM	117.2	136.0	12.0	10.3	436.5	87.6	
AOD	254835	12:17 PM	1:41 PM	130.0	84.0	51.0	78.9		
	254836	1:41 PM	2:51 PM	131.5	70.0	43.0	80.8		
	254837	2:51 PM	4:15 PM	124.4	84.0	37.0	64.4		
	254838	4:15 PM	5:40 PM	123.4	85.0	3:48 pm - 5:08 pm	54.7		
	254839	5:40 PM	7:02 PM	123.4	85.0	85.0	123.4		
254840	7:02 PM	8:23 PM	117.5	82.0	34.0	48.7	471.0	94.6	

**Total Meltshop Production - Avg. tons/hr: 361.1**  
**Total Test Run Length, hrs: 4.98**  
**Tons produced during run: 1798.3**

**Nucor Steel - Crawfordsville, IN**  
**Baghouse #1 & #2 Stack Test Production Data**  
**April 19, 2005**

**PM/PM10 Run 2: 8:20 am - 4:08 pm**

	Heat Number	Start	End	Net Ladle Tons	Total Minutes	Run Minutes	Tons During Run	Total Tons	Average tons/hr
South EAF	159290	8:15 AM	8:57 AM	130.6	42.0	37.0	115.1		
	159291	8:57 AM	9:42 AM	130.2	45.0	45.0	130.2		
	159292	9:42 AM	10:50 AM	127.1	68.0	10.0	18.7		
	159293	10:50 AM	11:36 AM	129.9	46.0	0.0	0.0		
	159294	11:36 AM	1:22 PM	129.6	106.0	47.0	57.5		
	159295	1:22 PM	2:02 PM	129.3	40.0	40.0	129.3		
	159296	2:02 PM	3:01 PM	129.3	59.0	59.0	129.3		
	159297	3:01 PM	3:41 PM	129.9	40.0	40.0	129.9		
	159298	3:41 PM	4:23 PM	115.2	42.0	27.0	74.1	784.0	154.3
North EAF	254850	7:55 AM	9:00 AM	123.4	65.0	40.0	75.9		
	254851	9:00 AM	11:01 AM	121.5	121.0	52.0	52.2		
	254852	11:01 AM	12:40 PM	120.9	99.0	0.0	5.8		
	254853	12:40 PM	1:34 PM	118.5	54.0	54.0	118.5		
	254854	1:34 PM	2:45 PM	114.5	71.0	71.0	114.5		
	254855	2:45 PM	4:09 PM	119.0	84.0	83.0	117.6		
							484.5	95.4	
AOD	254849	8:20 AM	9:24 AM	124.7	64.0	64.0	124.7		
	254850	9:24 AM	10:33 AM	127.2	69.0	28.0	51.6		
	254851	10:33 AM	12:33 PM	127.9	120.0	0.0	0.0		
	254852	12:33 PM	2:05 PM	118.7	92.0	2.0	2.6		
	254853	2:05 PM	3:43 PM	122.1	98.0	98.0	122.1		
	254854	3:43 PM	5:00 PM	118.3	77.0	25.0	38.4	339.4	66.8

**Total Meltshop Production - Avg. tons/hr: 316.5**  
**Total Test Run Length, hrs: 5.08**  
**Tons produced during run: 1607.9**

**Nucor Steel - Crawfordsville, IN**  
**Baghouse #1 & #2 Stack Test Production Data**  
**April 22, 2005**

**PM/PM10 Run 3: 8:33 am - 2:14 pm**

	Heat Number	Start	End	Net Ladle Tons	Total Minutes	Run Minutes	Tons During Run	Total Tons	Average tons/hr
South EAF	159361	7:21 AM	8:38 AM	132.0	77.0	5.0	8.6		
	159362	8:38 AM	9:19 AM	132.8	41.0	41.0	132.8		
	159363	9:19 AM	10:04 AM	131.8	45.0	45.0	131.8		
	159364	10:04 AM	11:36 AM	131.1	92.0	57.0	81.2		
	159365	11:36 AM	12:19 PM	125.4	43.0	43.0	125.4		
	159366	12:19 PM	1:05 PM	129.4	46.0	46.0	129.4		
	159367	1:05 PM	1:53 PM	130.1	48.0	48.0	130.1		
	159368	1:53 PM	2:37 PM	129.9	44.0	21.0	62.0	801.3	157.1
North EAF	254910	8:30 AM	9:19 AM	123.9	49.0	46.0	116.3		
	254911	9:19 AM	10:06 AM	125.4	47.0	47.0	125.4		
	254912	10:06 AM	11:04 AM	126.2	58.0	42.0	91.5		
	254913	11:04 AM	11:47 AM	126.2	43.0	43.0	70.4		
	254914	11:47 AM	12:42 PM	126.7	55.0	55.0	126.7		
	254915	12:42 PM	1:27 PM	126.8	45.0	45.0	126.8		
	254916	1:27 PM	2:16 PM	126.2	49.0	47.0	121.0	778.2	152.6
AOD	254908	8:16 AM	8:57 AM	127.9	41.0	24.0	74.9		
	254910	8:57 AM	10:09 AM	127.1	72.0	72.0	127.1		
	254911	10:09 AM	11:05 AM	127.8	56.0	39.0	89.0		
	254912	11:05 AM	12:02 PM	126.8	57.0	37.0	88.1		
	254913	12:02 PM	12:50 PM	128.7	48.0	48.0	128.7		
	254914	12:50 PM	1:49 PM	129.9	59.0	59.0	129.9		
	254915	1:49 PM	2:44 PM	129.9	55.0	25.0	59.0	696.7	136.6

**Total Meltshop Production - Avg. tons/hr: 446.3**  
**Total Test Run Length, hrs: 5.1**  
**Tons produced during run: 2276.2**

**Nucor Steel - Crawfordsville, IN**  
**Baghouse Testing - Heat Summary**

PM/PM10 - Run 1 - 4/18/05 - 12:50 - 19:36

	Heat No.	Grade			Start			
South EAF	159264	1005T1	142.1	130.7	12:32	45.6	20.8	13.6
	159265	1005S1	142.2	114.6	13:18	59.7	21	27.4
	159266	1005T1	131.8	131	14:17	37.8	20.9	8.7
	159267	1005S1	130.8	115.5	14:55	41.7	21.1	11.5
	159268	1005T1	130.5	131	15:37	36.9	20.6	9
	159269	1005T1	132.8	131.6	16:14	37.6	21.2	10
	159270	1005T1	132.4	131.2	16:51	37.9	21.3	8.2
	159271	1005T1	136.8	130.2	17:29	47.3	20.7	18.2
	159272	1005T1	137.5	129.5	18:17	40.9	21.3	10.3
	159273	1005T1	64	131	18:57	34.4	31.6	17.7
	159274	1005T1	130.5	130.5	19:32	41.1	21.2	10.4
	159275	1005S1	130.9	115.8	20:13	44.2	21	13.2
North EAF	254837	409S1	130.3	118.4	12:47	79.1	27.5	33.8
	254838	409S1	132.7	121.7	14:06	70.8	27.8	26.5
	254839	409S1	108.4	119	15:17	81.4	27.6	42
	254840	409S1	112.8	116.5	16:39	82.5	39	42.8
	254841	409S1	112.3	116.5	18:01	82.7	27.6	47.5
	254842	409S1	114.1	117.2	19:24	135.9	88.7	92.4
AOD	254843	409S1	123.3	118	21:40	219.5	27.1	179.9
	254835	409S1	121	130	12:17	84		
	254836	409S1	122	131.5	13:41	70		
	254837	409S1	119	124.4	14:51	84		
	254838	409S1	122	128.3	16:15	75		
	254839	409S1	119	123.4	17:40	85		
	254840	409S1	117	117.5	19:02	82		
254841	409S1	117	119	20:23	79			

**Nucor Steel - Crawfordsville, IN**  
**Baghouse Testing - Heat Summary**

PM/PM10 - Run 2 - 4/19/05 - 8:20 - 16:08

Select	Heat No.	Grade			Start			
South EAF	159290	1005T1	134	130.6	8:15	42.1	21.3	12.7
	159291	1005T1	136.6	130.2	8:57	45.4	21.6	14.9
	159292	1005T1	136.3	127.1	9:42	67.4	21.4	37.6
	159293	1005T1	137.6	129.9	10:50	45.9	25.8	14.6
	159294	1005T1	153.1	129.6	11:36	106.7	79.6	76.4
	159295	1005T1	140.5	129.3	13:22	39.5	21.8	9.4
	159296	1005T1	138.4	129.3	14:02	59.5	21.2	28.6
	159297	1005T1	137	129.9	15:01	39.4	21.1	9.1
	159298	1005S1	136.7	115.2	15:41	41.9	21	10
	159299	1005T1	136.6	130.5	16:23	39.1	20.6	9.4
North EAF	254850	409S1	125.1	123.4	7:55	65.5	27.7	23.6
	254851	409S1	128.1	121.5	9:00	121.3	27.8	77.4
	254852	409S1	125.5	114.3	11:01	98.6	27.7	56.2
	254853	409S1	126.8	118.5	12:40	54.5	27.7	13.1
	254854	409S1	128.6	114.5	13:34	70.3	27.2	30
	254855	409S1	132	119	14:45	84.2	40.5	40.2
	254856	1050	151.9	121.8	16:09	97.1	24.9	57.1
254857	1050	142.2	121.9	17:46	72.6	24.3	35.8	
AOD	254849	409S1	120	124.7	8:20	64		
	254850	409S1	124	127.2	9:24	69		
	254851	409S1	122	124.8	10:33	120		
	254852	409S1	114.5	118.7	12:33	92		
	254853	409S1	119	122.1	14:05	98		
	254854	409S1	115	118.3	15:43	77		
	254855	409S1	112	124.4	17:00	72		
	254856	1050	122	122.9	18:12	67		
	254857	1050	122	121.9	19:19	35		
	254858	1050	122.5	122.9	19:54	32		
254859	1050	123	123.3	20:26	161			

**Nucor Steel - Crawfordsville, IN**  
**Baghouse Testing - Heat Summary**

PM/PM10 - Run 3 - 4/22/05 - 8:33 - 14:14

Select	Heat No.	Grade			Start			
South EAF	<u>159361</u>	1008W3	176	132	7:21	76.3	23.4	59.7
	<u>159362</u>	1008W3	141.2	132.8	8:38	41.2	21.8	9.1
	<u>159363</u>	1008W3	148.4	131.8	9:19	45.4	22.4	13.1
	<u>159364</u>	1008W3	140.7	131.1	10:04	91.7	31.6	59.2
	<u>159365</u>	1026A2	141.1	125.4	11:36	43.4	21.9	12
	<u>159366</u>	1026A2	135.1	129.4	12:19	45.7	21.3	14.9
	<u>159367</u>	1026A2	135	130.1	13:05	48.4	21.8	17.1
	<u>159368</u>	1026A2	135.9	129.9	13:53	43.8	21.6	13
	<u>159369</u>	1026A2	139.6	125.7	14:37	41.4	21.7	10.6
North EAF	<u>254910</u>	1001S8	131.2	123.9	8:30	49	23.3	12.1
	<u>254911</u>	1001S8	132.2	125.4	9:19	46.3	23.2	12.2
	<u>254912</u>	1001S8	138	126.3	10:06	58.5	30.2	23.2
	<u>254913</u>	1001S8	133.8	126.2	11:04	43.3	22.2	9.7
	<u>254914</u>	1001S8	132.1	126.7	11:47	54.7	23	18.5
	<u>254915</u>	1001S8	134.3	126.8	12:42	44.8	23.3	11.6
	<u>254916</u>	1001S8	133.7	126.2	13:27	48.8	27.9	13.9
	<u>254917</u>	1005S1	133.6	107.2	14:16	58.4	22.3	24
AOD	<u>254908</u>	1001S8	125	127.9	8:16	41		
	<u>254910</u>	1001S8	124.3	127.1	8:57	72		
	<u>254911</u>	1001S8	125	127.8	10:09	56		
	<u>254912</u>	1001S8	126	128.8	11:05	57		
	<u>254913</u>	1001S8	126	128.7	12:02	48		
	<u>254914</u>	1001S8	127	129.9	12:50	59		
	<u>254915</u>	1001S8	127	129.9	13:49	55		



**Nucor Steel - Crawfordsville, IN**  
**Baghouse #1 & #2 Stack Test Production Data**  
**April 18, 2005**

**VOC/Metals Run 1: 12:50 pm - 3:35 pm**

	Heat Number	Start	End	Net Ladle Tons	Total Minutes	Run Minutes	Tons During Run	Total Tons	Average tons/hr
South EAF	159264	12:32 PM	1:18 PM	130.7	46.0	28.0	79.6		
	159265	1:18 PM	2:17 PM	114.6	59.0	59.0	114.6		
	159266	2:17 PM	2:55 PM	114.0	38.0	2:20 pm - 2:47 pm	37.9		
	159267	2:55 PM	3:37 PM	115.5	40.0	40.0	115.5		
							347.6	151.1	
North EAF	254837	12:47 PM	2:06 PM	118.4	79.0	76.0	113.9		
	254838	2:06 PM	3:17 PM	104.7	71.0	2:20 pm - 2:47 pm	75.4		
	254839	3:17 PM	4:39 PM	119.0	82.0	18.0	26.1		
							215.4	93.7	
AOD	254835	12:17 PM	1:41 PM	130.0	84.0	51.0	78.9		
	254836	1:41 PM	2:51 PM	131.5	70.0	43.0	80.8		
	254837	2:51 PM	4:15 PM	124.4	84.0	44.0	65.2		
							224.9	97.8	

**Total Meltshop Production - Avg. tons/hr: 342.6**  
**Total Test Run Length (less delays), hrs: 2.3**  
**Tons produced during run: 787.9**

**Nucor Steel - Crawfordsville, IN**  
**Baghouse #1 & #2 Stack Test Production Data**  
**April 18, 2005**

**VOC/Metals Run 2: 5:05 pm - 7:20 pm**

	Heat Number	Start	End	Net Ladle Tons	Total Minutes	Run Minutes	Tons During Run	Total Tons	Average tons/hr
South EAF	159270	4:51 PM	5:29 PM	131.2	38.0	24.0	82.9	428.6	190.5
	159271	5:29 PM	6:17 PM	130.2	48.0	48.0	130.2		
	159272	6:17 PM	6:57 PM	129.5	40.0	40.0	129.5		
	159273	6:57 PM	7:32 PM	131.0	35.0	23.0	86.1		
North EAF	254840	4:39 PM	6:01 PM	116.5	82.0	56.0	79.6	190.4	84.6
	254841	6:01 PM	7:24 PM	116.5	83.0	79.0	110.9		
AOD	254838	4:15 PM	5:40 PM	128.3	75.0	35.0	59.9	209.1	92.9
	254839	5:40 PM	7:02 PM	123.4	85.0	85.0	123.4		
	254840	7:02 PM	8:23 PM	117.5	82.0	18.0	25.8		

**Total Meltshop Production - Avg. tons/hr: 368.1**  
**Total Test Run Length, hrs: 2.25**  
**Tons produced during run: 828.2**

**Nucor Steel - Crawfordsville, IN**  
**Baghouse #1 & #2 Stack Test Production Data**  
**April 19, 2005**

**VOC/Metals Run 3: 8:20am - 1:25 pm**

	Heat Number	Start	End	Net Ladle Tons	Total Minutes	Run Minutes	Tons During Run	Total Tons	Average tons/hr
South EAF	159290	8:15 AM	8:57 AM	130.6	42.0	37.0	115.1		
	159291	8:57 AM	9:42 AM	130.2	45.0	45.0	130.2		
	159292	9:42 AM	10:50 AM	127.1	68.0	10.0	18.7		
	159293	10:50 AM	11:36 AM	129.9	46.0	0.0	0.0		
	159294	11:36 AM	1:22 PM	129.6	106.0	47.0	57.5		
	159295	1:22 PM	2:02 PM	129.3	40.0	3.0	9.7	331.1	139.7
North EAF	254850	7:55 AM	9:00 AM	123.4	65.0	40.0	75.9		
	254851	9:00 AM	11:01 AM	121.5	121.0	52.0	52.2		
	254852	11:01 AM	12:40 PM	114.3	99.0	5.0	5.8		
	254853	12:40 PM	1:34 PM	118.5	54.0	45.0	98.8	232.7	98.2
AOD	254849	8:20 AM	9:24 AM	124.7	64.0	64.0	124.7		
	254850	9:24 AM	10:33 AM	127.2	69.0	28.0	51.0		
	254851	10:33 AM	12:33 PM	124.8	120.0	120.0	124.8		
	254852	12:33 PM	2:05 PM	118.7	92.0	90.0	116.1	417.2	176.0

Total Meltshop Production - Avg. tons/hr: 413.9  
 Total Test Run Length, hrs: 2.37  
 Tons produced during run: 981.0

98763

**Nucor Steel - Crawfordsville, IN**  
**Baghouse Testing - Heat Summary**

VOC/Metals - Run 1 - 4/18/05 - 12:50 - 15:50

	Heat No.	Grade			Start			
South EAF	159264	1005T1	142.1	130.7	12:32	45.6	20.8	13.6
	159265	1005T1	142.2	117.6	13:16	59.7	21.1	27.7
	159266	1005T1	131.8	131	14:17	37.8	20.9	8.7
	159267	1005T1	130.8	115.5	14:55	41.7	21.1	11.1
	159268	1005T1	130.5	131	15:37	36.9	20.6	9
North EAF	254837	409S1	130.3	118.4	12:47	79.1	27.5	33.8
	254838	409S1	132.7	121.1	14:05	70.8	27.8	26.5
	254839	409S1	108.4	119	15:17	81.4	27.6	42
	254840	409S1	112.8	115.5	15:49	82.5	39	42.8
	254835	409S1	121	140	17:07			
AOD	254836	409S1	122	131.5	13:41	70		
	254837	409S1	119	123	14:51	64		
	254838	409S1	122	128.3	16:15	75		

**Nucor Steel - Crawfordsville, IN**  
**Baghouse Testing - Heat Summary**

VOC/Metals - Run 2 - 4/18/05 - 17:05 - 19:20

Select	Heat No.	Grade			Start			
South EAF	159270	1005T1	132.4	131.2	16:51	37.9	21.3	8.2
	159271	1005T1	135.5	130.2	17:20	47.9	20.7	8.2
	159272	1005T1	137.5	129.5	18:17	40.9	21.3	10.3
	159273	1005T1	134.1	131.5	18:57	41.3	21.3	10.3
North EAF	254840	409S1	112.3	116.5	16:39	82.5	27.6	47.5
	254841	409S1	112.3	116.5	18:01	82.7	27.6	47.5
	254842	409S1	114.5	117.2	19:22	85.9	28.7	49.2
AOD	254838	409S1	122	128.3	16:15	75		
	254839	409S1	119	125.1	17:10	85		
	254840	409S1	117	117.5	19:02	82		
	254841	409S1	117.5	119	20:23	79		

**Nucor Steel - Crawfordsville, IN**  
**Baghouse Testing - Heat Summary**

VOC/Metals - Run 3 - 4/19/05 - 8:20 - 13:25

Select	Heat No.	Grade			Start			
South EAF	159290	100ST1	134	130.5	8:15	42.1	21.5	12.2
	159291	100ST1	136.6	130.2	8:57	45.4	21.6	14.9
	159292	100ST1	136.3	127.1	9:26	67.1	17.1	3.6
	159293	100ST1	137.6	129.9	10:50	45.9	25.8	14.6
	159294	100ST1	138.1	129.6	11:35	106.7	29.6	16.1
	159295	100ST1	140.5	129.3	13:22	39.5	21.8	9.4
North EAF	159296	100ST1	138.4	129.5	11:02	50.5	21.2	28.5
	254850	409S1	125.1	123.4	7:55	65.5	27.7	23.6
	254851	409S1	128.1	121.5	9:00	121.5	27.3	11.1
	254852	409S1	125.5	114.3	11:01	98.6	27.7	56.2
	254853	409S1	126.8	118.5	12:40	54.5	27.7	15.1
AOD	254854	409S1	128.6	114.5	13:34	70.3	27.2	30
	254853	409S1	126.8	116.5	12:40	54.5	27.7	15.1
	254849	409S1	120	124.7	8:20	64		
	254850	409S1	121	127.2	9:21	69		
	254851	409S1	122	124.8	10:33	120		

## Melt Shop / AOD Baghouse Baseline PM and Opacity Testing

4/18/2005			4/19/2005			4/22/2005		
Run 1			Run 2			Run 3		
	BH #1	BH #2		BH #1	BH #2		BH #1	BH #2
Time	DP, in. H2O	DP, in. H2O	Time	DP, in. H2O	DP, in. H2O	Time	DP, in. H2O	DP, in. H2O
12:48 PM	7.5	9.5	8:15 AM	7.6	8.6	8:33 AM	7.5	7.9
1:03 PM	7.6	10.1	8:30 AM	7.5	9.4	8:48 AM	7.9	8.1
1:18 PM	7.7	9.2	8:45 AM	7.4	8.8	9:03 AM	8.1	8.3
1:33 PM	8.0	10.3	9:00 AM	7.6	8.9	9:18 AM	8.4	9.0
1:48 PM	7.6	10.0	9:15 AM	6.8	9.4	9:33 AM	7.6	8.6
2:03 PM	7.3	8.9	9:30 AM	7.1	9.9	9:48 AM	7.9	9.2
2:18 PM	7.6	8.8	9:45 AM	7.4	7.4	10:03 AM	8.4	9.8
2:33 PM	7.2	10.1	10:00 AM	7.0		10:18 AM	7.3	9.0
2:48 PM	8.0	10.4	10:15 AM	7.1	10.1	10:33 AM	8.0	9.0
3:03 PM	7.7	9.1	10:30 AM	6.5	8.4	10:48 AM	8.0	9.6
3:18 PM	7.8	10.8	10:45 AM	6.4	8.2			
3:33 PM	7.8	10.1	11:00 AM	6.7				
3:48 PM	7.8	10.3				11:30 AM	8.1	7.9
4:03 PM	7.2	10.8				11:45 AM	8.6	8.2
4:18 PM	7.6	10.2	12:40 PM	6.8	6.9	12:00 PM	7.7	9.3
4:33 PM	7.8	10.7	12:55 PM	7.5	8.4	12:15 PM	8.1	10.1
4:48 PM	7.8	9.8	1:10 PM	7.8	8.3	12:30 PM	8.3	9.0
5:03 PM	7.6	10.1	1:25 PM	7.7	7.6	12:45 PM	7.7	10.0
5:18 PM	7.7	10.9	1:40 PM	6.8	9.3	1:00 PM	8.1	10.7
5:33 PM	8.3	9.5	1:55 PM	7.7	9.6	1:15 PM	8.0	8.8
5:48 PM	7.6	10.1	2:10 PM	7.7	8.0	1:30 PM	8.1	10.2
6:03 PM	7.6	10.8	2:25 PM	7.8	7.7	1:45 PM	7.9	10.1
6:18 PM	7.7	9.4	2:40 PM	7.1	9.4	2:00 PM	7.8	9.8
6:33 PM	7.5	10.1	2:55 PM	7.2	9.5	2:15 PM	8.6	9.9
6:48 PM	7.8	9.8	3:10 PM	7.4	9.1			
7:03 PM	8.0	9.0	3:25 PM	7.9	9.6			
7:18 PM	7.5	10.0	3:40 PM	7.0	10.0			
7:33 PM	7.9	9.1	3:55 PM	8.0	9.2			
7:48 PM	7.7	9.9	4:10 PM	7.3	10.3			
Max	8.3	10.9	Max	8.0	10.3	Max	8.6	10.7
Min	7.2	8.8	Min	6.4	6.9	Min	7.3	7.9
Avg	7.7	9.9	Avg	7.3	8.9	Avg	8.0	9.2

# Melt Shop / AOD Baghouse Baseline PM and Opacity Testing

## Baghouse #2

### Run 1 Fan Amps and Damper Positions

Run 1 Time: 12:50 pm - 7:36 pm

DATE: 4/18/05

Time	FAN 1		FAN 2		FAN 3		FAN 4		FAN 5		FAN 6	
	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position
12:48 PM	158	58%	159	68%	158	53%	158	53%				
1:03 PM	158	63%	159	74%	163	57%	159	57%				
1:18 PM	164	52%	161	61%	160	48%	163	46%				
1:33 PM	161	63%	163	75%	165	57%	163	58%				
1:48 PM	160	61%	159	72%	157	56%	160	55%				
2:03 PM	160	51%	162	60%	162	47%	161	46%				
2:18 PM	160	53%	161	63%	159	49%	156	47%				
2:33 PM	157	61%	157	71%	158	55%	159	55%				
2:48 PM	158	61%	163	73%	163	57%	163	56%				
3:03 PM	162	54%	160	63%	156	50%	161	49%				
3:18 PM	163	63%	161	74%	161	57%	163	57%				
3:33 PM	161	53%	163	92%	161	49%	161	48%				
3:48 PM	156	59%	164	90%	156	54%	159	54%				
4:03 PM	159	62%	156	91%	162	57%	157	56%				
4:18 PM	157	55%	157	91%	160	50%	158	49%				
4:33 PM	163	60%	158	92%	162	55%	161	54%				
4:48 PM	164	55%	155	92%	162	50%	163	49%				
5:03 PM	154	58%	157	93%	156	53%	158	52%				
5:18 PM	162	63%	159	91%	158	57%	158	57%				
5:33 PM	162	50%	164	91%	157	46%	158	44%				
5:48 PM	159	58%	156	91%	159	53%	157	53%				
6:03 PM	158	61%	157	91%	162	57%	159	55%				
6:18 PM	161	51%	156	93%	160	47%	158	45%				
6:33 PM	161	58%	158	92%	160	52%	160	52%				
6:48 PM	162	63%	158	92%	160	56%	160	57%				
7:03 PM	159	54%	155	93%	159	50%	161	48%				
7:18 PM	159	55%	162	90%	161	50%	161	49%				
7:33 PM	161	48%	161	92%	160	45%	160	43%				
7:48 PM	163	59%	158	90%	163	54%	161	54%				
AVG	160	57%	159	83%	160	52%	160	52%				

	Grand Totals					
	Fan 1	Fan 2	Fan 3	Fan 4	Fan 5	Fan 6
Max	164	164	165	163		
Min	154	155	156	156		
Avg	160.1	159.3	160.0	159.9		



# Melt Shop / AOD Baghouse Baseline PM and Opacity Testing

## Baghouse #2

### Run 2 Fan Amps and Damper Positions

Run 2 Time: 8:20 am - 4:08 pm

DATE: 4/19/05

Time	FAN 1		FAN 2		FAN 3		FAN 4		FAN 5		FAN 6	
	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position
8:15 AM	165	48%	160	55%	158	43%	160	42%				
8:30 AM	159	55%	158	64%	158	50%	157	50%				
8:45 AM	157	58%	158	68%	160	54%	157	54%				
9:00 AM	158	49%	162	57%	161	46%	159	44%				
9:15 AM	160	54%	158	63%	159	50%	161	49%				
9:30 AM	159	60%	156	71%	160	55%	159	55%				
9:45 AM	155	50%	155	58%	157	47%	153	44%				
10:00 AM												
10:15 AM	160	60%	160	71%	160	55%	160	55%				
10:30 AM	159	47%	159	55%	158	44%	161	41%				
10:45 AM	163	46%	160	53%	161	43%	160	40%				
11:00 AM												
<b>TESTING SUSPENDED</b>												
12:40 PM	158	44%	154	50%	157	41%	161	37%				
12:55 PM	163	54%	161	63%	159	49%	164	49%				
1:10 PM	161	53%	165	63%	162	49%	163	49%				
1:25 PM	161	46%	162	53%	158	42%	159	40%				
1:40 PM	162	56%	163	67%	159	51%	162	52%				
1:55 PM	158	60%	161	71%	162	54%	158	55%				
2:10 PM	163	47%	161	54%	160	43%	159	41%				
2:25 PM	158	46%	160	53%	158	44%	158	41%				
2:40 PM	160	55%	162	65%	161	50%	162	50%				
2:55 PM	159	62%	160	73%	159	56%	159	56%				
3:10 PM	157	53%	159	63%	159	50%	154	49%				
3:25 PM	162	56%	160	66%	160	51%	159	51%				
3:40 PM	161	54%	160	64%	162	49%	162	49%				
3:55 PM	157	60%	157	71%	157	55%	161	56%				
4:10 PM	159	60%	160	71%	158	54%	161	55%				
AVG	160	53%	160	62%	159	49%	160	48%				

	Grand Totals					
	Fan 1	Fan 2	Fan 3	Fan 4	Fan 5	Fan 6
Max	165	165	162	164		
Min	155	154	157	153		
Avg	159.8	159.6	159.3	159.6		

# Melt Shop / AOD Baghouse Baseline PM and Opacity Testing

## Baghouse #2

### Run 3 Fan Amps and Damper Positions

Run 3 Time: 8:33 am - 2:14 pm

DATE: 4/22/05

Time	FAN 1		FAN 2		FAN 3		FAN 4		FAN 5		FAN 6	
	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position
8:33 AM	162	49%	160	57%	157	43%	161	43%				
8:48 AM	158	53%	160	61%	154	61%	160	49%				
9:03 AM	160	51%	161	59%	156	100%	159	46%				
9:18 AM	165	53%	165	62%	158	14%	164	48%				
9:33 AM	160	54%	162	61%	157	51%	156	48%				
9:48 AM	156	57%	156	65%	160	52%	163	51%				
10:03 AM	162	55%	162	64%	164	49%	165	49%				
10:18 AM	161	48%	162	56%	161	45%	164	43%				
10:33 AM	162	52%	159	60%	159	48%	161	46%				
10:48 AM	158	59%	156	69%	159	54%	162	55%				
<b>TESTING SUSPENDED</b>												
11:30 AM	157	51%	155	58%	158	47%	155	46%				
11:45 AM	157	51%	160	58%	161	47%	162	45%				
12:00 PM	161	56%	159	66%	164	51%	160	52%				
12:15 PM	166	60%	166	70%	165	54%	163	54%				
12:30 PM	159	56%	157	64%	159	51%	158	50%				
12:45 PM	156	63%	160	74%	163	57%	156	59%				
1:00 PM	167	62%	162	91%	163	56%	162	55%				
1:15 PM	140	50%	140	93%	137	46%	142	44%				
1:30 PM	163	63%	170	91%	159	58%	162	58%				
1:45 PM	163	66%	162	92%	158	59%	160	60%				
2:00 PM	165	59%	158	92%	163	54%	161	54%				
2:15 PM	159	61%	163	91%	164	55%	159	55%				
AVG	160	56%	160	71%	159	52%	160	50%				

	Grand Totals					
	Fan 1	Fan 2	Fan 3	Fan 4	Fan 5	Fan 6
Max	167	170	165	165		170
Min	140	140	137	142		137
Avg	159.9	159.8	159.0	159.8		159.6

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 12:49:42 PM

Main Fan #1 Operating Current	158Amps
Main Fan #2 Operating Current	159Amps
Main Fan #3 Operating Current	158Amps
Main Fan #4 Operating Current	158Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	77Amps
Reverse Air Fan #2 Operating Current	81Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	57.6%
Main Fan #2 Inlet Damper Position	67.6%
Main Fan #3 Inlet Damper Position	52.6%
Main Fan #4 Inlet Damper Position	52.6%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30.1%
Reverse Air Fan #2 Damper Position	30%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.1inWC
Baghouse Differential Duct Pressure	9.5inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 1:05:44 PM

Main Fan #1 Operating Current	158Amps
Main Fan #2 Operating Current	159Amps
Main Fan #3 Operating Current	163Amps
Main Fan #4 Operating Current	159Amps
Main Fan #5 Operating Current	2Amps
Main Fan #6 Operating Current	2Amps
Reverse Air Fan #1 Operating Current	54Amps
Reverse Air Fan #2 Operating Current	59Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	62.5%
Main Fan #2 Inlet Damper Position	73.5%
Main Fan #3 Inlet Damper Position	57%
Main Fan #4 Inlet Damper Position	57%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30.1%
Reverse Air Fan #2 Damper Position	30%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	4.8inWC
Baghouse Differential Duct Pressure	10.1inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 1:20:19 PM

Main Fan #1 Operating Current	164Amps
Main Fan #2 Operating Current	161Amps
Main Fan #3 Operating Current	160Amps
Main Fan #4 Operating Current	163Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	54Amps
Reverse Air Fan #2 Operating Current	58Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	51.7%
Main Fan #2 Inlet Damper Position	60.8%
Main Fan #3 Inlet Damper Position	47.6%
Main Fan #4 Inlet Damper Position	45.8%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30.1%
Reverse Air Fan #2 Damper Position	30%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.2inWC
Baghouse Differential Duct Pressure	9.2inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 1:35:47 PM

Main Fan #1 Operating Current	161Amps
Main Fan #2 Operating Current	163Amps
Main Fan #3 Operating Current	165Amps
Main Fan #4 Operating Current	163Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	55Amps
Reverse Air Fan #2 Operating Current	59Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	62.8%
Main Fan #2 Inlet Damper Position	74.5%
Main Fan #3 Inlet Damper Position	57%
Main Fan #4 Inlet Damper Position	58.3%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30.1%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.6inWC
Baghouse Differential Duct Pressure	10.3inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 1:50:37 PM

Main Fan #1 Operating Current	160Amps
Main Fan #2 Operating Current	159Amps
Main Fan #3 Operating Current	157Amps
Main Fan #4 Operating Current	160Amps
Main Fan #5 Operating Current	0Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	56Amps
Reverse Air Fan #2 Operating Current	59Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	61.3%
Main Fan #2 Inlet Damper Position	71.9%
Main Fan #3 Inlet Damper Position	55.8%
Main Fan #4 Inlet Damper Position	55.2%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30.1%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.2inWC
Baghouse Differential Duct Pressure	10inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 2:05:40 PM

Main Fan #1 Operating Current	160Amps
Main Fan #2 Operating Current	162Amps
Main Fan #3 Operating Current	162Amps
Main Fan #4 Operating Current	161Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	54Amps
Reverse Air Fan #2 Operating Current	61Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	51.3%
Main Fan #2 Inlet Damper Position	60.3%
Main Fan #3 Inlet Damper Position	47.2%
Main Fan #4 Inlet Damper Position	45.9%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30.1%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.6inWC
Baghouse Differential Duct Pressure	8.9inWC



# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 2:20:57 PM

Main Fan #1 Operating Current	160Amps
Main Fan #2 Operating Current	161Amps
Main Fan #3 Operating Current	159Amps
Main Fan #4 Operating Current	156Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	54Amps
Reverse Air Fan #2 Operating Current	57Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	53.3%
Main Fan #2 Inlet Damper Position	62.9%
Main Fan #3 Inlet Damper Position	48.6%
Main Fan #4 Inlet Damper Position	47%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30.1%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.7inWC
Baghouse Differential Duct Pressure	8.8inWC

2:35 P.M.

FAN INLET S.4

FAN #	AMP.	DAMPEN.
1	157	61
2	157	71
3	158	55
4	159	55
5	1	0
6	1	0

DUCT PRESSURE 10.1 IN WG

R. AIR. #1	55	30%
#2	58	30%
#3	0	0.

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 2:50:14 PM

Main Fan #1 Operating Current	158Amps
Main Fan #2 Operating Current	163Amps
Main Fan #3 Operating Current	163Amps
Main Fan #4 Operating Current	163Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	54Amps
Reverse Air Fan #2 Operating Current	58Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	61.2%
Main Fan #2 Inlet Damper Position	72.8%
Main Fan #3 Inlet Damper Position	55.6%
Main Fan #4 Inlet Damper Position	55.9%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30.1%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.9inWC
Baghouse Differential Duct Pressure	10.4inWC

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 3:02:26 PM

Main Fan #1 Operating Current	162Amps
Main Fan #2 Operating Current	160Amps
Main Fan #3 Operating Current	156Amps
Main Fan #4 Operating Current	161Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	58Amps
Reverse Air Fan #2 Operating Current	60Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	54.3%
Main Fan #2 Inlet Damper Position	63.2%
Main Fan #3 Inlet Damper Position	50%
Main Fan #4 Inlet Damper Position	48.9%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30.1%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.7inWC
Baghouse Differential Duct Pressure	9.1inWC

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 3:17:00 PM

Main Fan #1 Operating Current	163Amps
Main Fan #2 Operating Current	161Amps
Main Fan #3 Operating Current	161Amps
Main Fan #4 Operating Current	163Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	54Amps
Reverse Air Fan #2 Operating Current	52Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	62.7%
Main Fan #2 Inlet Damper Position	73.8%
Main Fan #3 Inlet Damper Position	57%
Main Fan #4 Inlet Damper Position	56.9%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30.1%
Reverse Air Fan #2 Damper Position	30.2%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.2inWC
Baghouse Differential Duct Pressure	10.8inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 3:38:15 PM

Main Fan #1 Operating Current	161Amps
Main Fan #2 Operating Current	163Amps
Main Fan #3 Operating Current	161Amps
Main Fan #4 Operating Current	161Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	56Amps
Reverse Air Fan #2 Operating Current	58Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	53.2%
Main Fan #2 Inlet Damper Position	91.8%
Main Fan #3 Inlet Damper Position	48.7%
Main Fan #4 Inlet Damper Position	47.9%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30.1%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.7inWC
Baghouse Differential Duct Pressure	10.1inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 3:50:56 PM

Main Fan #1 Operating Current	156Amps
Main Fan #2 Operating Current	164Amps
Main Fan #3 Operating Current	156Amps
Main Fan #4 Operating Current	159Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	54Amps
Reverse Air Fan #2 Operating Current	58Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	59.3%
Main Fan #2 Inlet Damper Position	90.3%
Main Fan #3 Inlet Damper Position	54.4%
Main Fan #4 Inlet Damper Position	53.9%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30.1%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.7inWC
Baghouse Differential Duct Pressure	10.3inWC

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 4:06:28 PM

Main Fan #1 Operating Current	159Amps
Main Fan #2 Operating Current	156Amps
Main Fan #3 Operating Current	162Amps
Main Fan #4 Operating Current	157Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	0Amps
Reverse Air Fan #1 Operating Current	71Amps
Reverse Air Fan #2 Operating Current	75Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	61.7%
Main Fan #2 Inlet Damper Position	91.2%
Main Fan #3 Inlet Damper Position	56.8%
Main Fan #4 Inlet Damper Position	56.2%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0%
Reverse Air Fan #1 Damper Position	30.1%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.3inWC
Baghouse Differential Duct Pressure	10.8inWC



# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 4:21:22 PM

Main Fan #1 Operating Current	157Amps
Main Fan #2 Operating Current	157Amps
Main Fan #3 Operating Current	160Amps
Main Fan #4 Operating Current	158Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	0Amps
Reverse Air Fan #1 Operating Current	73Amps
Reverse Air Fan #2 Operating Current	79Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	54.7%
Main Fan #2 Inlet Damper Position	91%
Main Fan #3 Inlet Damper Position	49.7%
Main Fan #4 Inlet Damper Position	48.8%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0%
Reverse Air Fan #1 Damper Position	30%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.1inWC
Baghouse Differential Duct Pressure	10.2inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 4:36:33 PM

Main Fan #1 Operating Current	163Amps
Main Fan #2 Operating Current	158Amps
Main Fan #3 Operating Current	162Amps
Main Fan #4 Operating Current	161Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	71Amps
Reverse Air Fan #2 Operating Current	74Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	60.4%
Main Fan #2 Inlet Damper Position	92.3%
Main Fan #3 Inlet Damper Position	54.7%
Main Fan #4 Inlet Damper Position	54.3%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0%
Reverse Air Fan #1 Damper Position	30%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.3inWC
Baghouse Differential Duct Pressure	10.7inWC

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 4:50:47 PM

Main Fan #1 Operating Current	164Amps
Main Fan #2 Operating Current	155Amps
Main Fan #3 Operating Current	162Amps
Main Fan #4 Operating Current	163Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	55Amps
Reverse Air Fan #2 Operating Current	59Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	55%
Main Fan #2 Inlet Damper Position	92%
Main Fan #3 Inlet Damper Position	50.1%
Main Fan #4 Inlet Damper Position	48.6%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	6.1inWC
Baghouse Differential Duct Pressure	9.8inWC

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 5:06:44 PM

Main Fan #1 Operating Current	154Amps
Main Fan #2 Operating Current	157Amps
Main Fan #3 Operating Current	156Amps
Main Fan #4 Operating Current	158Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	54Amps
Reverse Air Fan #2 Operating Current	56Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	57.9%
Main Fan #2 Inlet Damper Position	93%
Main Fan #3 Inlet Damper Position	52.6%
Main Fan #4 Inlet Damper Position	52%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0%
Reverse Air Fan #1 Damper Position	30%
Reverse Air Fan #2 Damper Position	30%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.9inWC
Baghouse Differential Duct Pressure	10.1inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 5:21:17 PM

Main Fan #1 Operating Current	162Amps
Main Fan #2 Operating Current	159Amps
Main Fan #3 Operating Current	158Amps
Main Fan #4 Operating Current	158Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	73Amps
Reverse Air Fan #2 Operating Current	77Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	62.6%
Main Fan #2 Inlet Damper Position	91.1%
Main Fan #3 Inlet Damper Position	57%
Main Fan #4 Inlet Damper Position	56.7%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0%
Reverse Air Fan #1 Damper Position	30%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.5inWC
Baghouse Differential Duct Pressure	10.9inWC

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 5:35:58 PM

Main Fan #1 Operating Current	162Amps
Main Fan #2 Operating Current	164Amps
Main Fan #3 Operating Current	157Amps
Main Fan #4 Operating Current	158Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	55Amps
Reverse Air Fan #2 Operating Current	60Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	50.1%
Main Fan #2 Inlet Damper Position	91.3%
Main Fan #3 Inlet Damper Position	45.9%
Main Fan #4 Inlet Damper Position	44.4%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0%
Reverse Air Fan #1 Damper Position	30%
Reverse Air Fan #2 Damper Position	30%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.8inWC
Baghouse Differential Duct Pressure	9.5inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 5:50:20 PM

Main Fan #1 Operating Current	159Amps
Main Fan #2 Operating Current	156Amps
Main Fan #3 Operating Current	159Amps
Main Fan #4 Operating Current	157Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	55Amps
Reverse Air Fan #2 Operating Current	59Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	57.9%
Main Fan #2 Inlet Damper Position	91.2%
Main Fan #3 Inlet Damper Position	52.8%
Main Fan #4 Inlet Damper Position	52.5%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30%
Reverse Air Fan #2 Damper Position	30%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.6inWC
Baghouse Differential Duct Pressure	10.1inWC

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 6:07:47 PM

Main Fan #1 Operating Current	158Amps
Main Fan #2 Operating Current	157Amps
Main Fan #3 Operating Current	162Amps
Main Fan #4 Operating Current	159Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	74Amps
Reverse Air Fan #2 Operating Current	78Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	61.4%
Main Fan #2 Inlet Damper Position	92.1%
Main Fan #3 Inlet Damper Position	56.6%
Main Fan #4 Inlet Damper Position	55%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30%
Reverse Air Fan #2 Damper Position	30%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.4inWC
Baghouse Differential Duct Pressure	10.8inWC



# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 6:21:54 PM

Main Fan #1 Operating Current	161Amps
Main Fan #2 Operating Current	156Amps
Main Fan #3 Operating Current	160Amps
Main Fan #4 Operating Current	158Amps
Main Fan #5 Operating Current	2Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	56Amps
Reverse Air Fan #2 Operating Current	58Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	51.1%
Main Fan #2 Inlet Damper Position	93.1%
Main Fan #3 Inlet Damper Position	46.8%
Main Fan #4 Inlet Damper Position	45.2%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0%
Reverse Air Fan #1 Damper Position	30%
Reverse Air Fan #2 Damper Position	30%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.9inWC
Baghouse Differential Duct Pressure	9.4inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 6:40:44 PM

Main Fan #1 Operating Current	161Amps
Main Fan #2 Operating Current	158Amps
Main Fan #3 Operating Current	160Amps
Main Fan #4 Operating Current	160Amps
Main Fan #5 Operating Current	2Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	72Amps
Reverse Air Fan #2 Operating Current	76Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	57.8%
Main Fan #2 Inlet Damper Position	91.8%
Main Fan #3 Inlet Damper Position	52.4%
Main Fan #4 Inlet Damper Position	52.5%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0%
Reverse Air Fan #1 Damper Position	30%
Reverse Air Fan #2 Damper Position	30%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.7inWC
Baghouse Differential Duct Pressure	10.1inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 6:50:47 PM

Main Fan #1 Operating Current	162Amps
Main Fan #2 Operating Current	158Amps
Main Fan #3 Operating Current	160Amps
Main Fan #4 Operating Current	160Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	55Amps
Reverse Air Fan #2 Operating Current	59Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	62.6%
Main Fan #2 Inlet Damper Position	92%
Main Fan #3 Inlet Damper Position	56.2%
Main Fan #4 Inlet Damper Position	57.4%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	29.9%
Reverse Air Fan #2 Damper Position	30%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	6.1inWC
Baghouse Differential Duct Pressure	9.8inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 7:05:53 PM

Main Fan #1 Operating Current	159Amps
Main Fan #2 Operating Current	155Amps
Main Fan #3 Operating Current	159Amps
Main Fan #4 Operating Current	161Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	56Amps
Reverse Air Fan #2 Operating Current	60Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	54.4%
Main Fan #2 Inlet Damper Position	93.2%
Main Fan #3 Inlet Damper Position	49.6%
Main Fan #4 Inlet Damper Position	48.5%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0%
Reverse Air Fan #1 Damper Position	29.9%
Reverse Air Fan #2 Damper Position	30%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.7inWC
Baghouse Differential Duct Pressure	9inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 7:21:46 PM

Main Fan #1 Operating Current	159Amps
Main Fan #2 Operating Current	162Amps
Main Fan #3 Operating Current	161Amps
Main Fan #4 Operating Current	161Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	56Amps
Reverse Air Fan #2 Operating Current	58Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	55%
Main Fan #2 Inlet Damper Position	90.4%
Main Fan #3 Inlet Damper Position	49.8%
Main Fan #4 Inlet Damper Position	48.8%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0%
Reverse Air Fan #1 Damper Position	29.9%
Reverse Air Fan #2 Damper Position	30%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.9inWC
Baghouse Differential Duct Pressure	10inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 7:35:24 PM

Main Fan #1 Operating Current	161Amps
Main Fan #2 Operating Current	161Amps
Main Fan #3 Operating Current	160Amps
Main Fan #4 Operating Current	160Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	54Amps
Reverse Air Fan #2 Operating Current	59Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	48.5%
Main Fan #2 Inlet Damper Position	92.4%
Main Fan #3 Inlet Damper Position	44.9%
Main Fan #4 Inlet Damper Position	43.1%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0%
Reverse Air Fan #1 Damper Position	29.9%
Reverse Air Fan #2 Damper Position	29.9%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.8inWC
Baghouse Differential Duct Pressure	9.1inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/18/2005/ 7:50:42 PM

Main Fan #1 Operating Current	163Amps
Main Fan #2 Operating Current	158Amps
Main Fan #3 Operating Current	163Amps
Main Fan #4 Operating Current	161Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	0Amps
Reverse Air Fan #1 Operating Current	57Amps
Reverse Air Fan #2 Operating Current	58Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	59.4%
Main Fan #2 Inlet Damper Position	89.6%
Main Fan #3 Inlet Damper Position	53.9%
Main Fan #4 Inlet Damper Position	54.5%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0%
Reverse Air Fan #1 Damper Position	29.9%
Reverse Air Fan #2 Damper Position	29.9%
Reverse Air Fan #3 Damper Position	0%
Fan Inlet Duct Pressure	5.9inWC
Baghouse Differential Duct Pressure	9.9inWC

BH#1 BLOS

Start 12:48<sub>p</sub> (PLC time)

Run 1

4/18/05


	1/2	3/4	5/6	7/8	9/10	11/12	13/14	15/16
12:48	1.4	1.2	2.1	8.5	1.2	0.8	0.8	0.8
13:03	1.0	0.5	0.8	2.6	0.4	0.8	0.6	0.8
13:18	0.2	0.4	0.8	3.6	0.7	1.4	1.1	0.8
13:33	1.0	1.3	1.1	5.4	2.0	5.0	1.0	0.9
13:48	0.8	0.4	0.8	0.7	1.2	0.8	0.9	0.8
14:03	0.9	1.1	1.6	0.0	1.8	0.4	2.3	1.1
14:18	0.8	0.8	0.8	0.1	1.2	0.8	1.1	0.8
14:33	0.8	0.8	0.8	0.7	1.1	0.8	0.7	1.5
14:48	0.8	1.5	1.3	0.8	1.6	8.2	1.1	1.4
15:03	1.4	4.7	4.2	12.6	8.0	2.6	0.3	2.8
15:18	1.9	0.5	0.9	7.2	0.7	0.8	4.3	1.2
15:33	0.7	0.8	0.5	4.5	1.0	5.6	1.2	0.8
15:48	1.0	1.5	1.4	3.0	1.0	0.8	0.8	1.8
16:03	0.2	0.5	0.4	3.5	1.2	1.6	1.1	0.7
16:18	0.8	0.7	0.7	0.9	0.8	0.4	1.0	0.7
16:33	1.6	1.8	1.6	1.8	1.3	1.7	0.7	0.8
16:48	0.7	0.7	0.7	0.7	1.1	0.8	0.8	0.7
17:03	1.5	0.7	0.7	1.2	0.6	0.7	1.0	0.7
17:18	0.7	1.2	0.8	0.1	1.2	1.2	2.2	0.8
17:33	0.8	1.0	1.2	0.5	1.0	0.8	1.1	1.5
17:48	0.7	0.7	0.7	0.6	0.8	0.7	0.8	1.5
18:03	0.8	0.8	1.6	0.6	0.8	0.7	4.1	1.1

Run  
2



	1/2	3/4	5/6	7/8	9/10	11/12	13/14	15/16
10:28	1.5	0.7	0.7	0.4	1.1	0.7	1.0	0.7
18:33	1.3	0.7	0.7	1.9	1.7	6.7	1.4	1.1
18:48	1.1	1.2	1.1	1.7	0.3	0.6	0.8	0.8
19:03	1.4	0.7	0.7	1.2	5.5	0.8	1.2	0.7
19:18	2.8	1.8	0.8	1.3	0.9	0.9	1.2	0.8
19:33	0.7	0.7	0.7	0.6	1.5	4.3	0.3	0.7
19:48	1.2	0.8	0.8	1.4	0.8	0.8	0.8	0.7


[DustSensor]



~~12:45:00~~  
Display From: 4/18/2005 1:40:24 PM To: 4/18/2005 4:49:17 PM

12:50 PM


[DustSensor]



Display From: 4/18/2005 2:03:38 PM To: 4/18/2005 2:06:07 PM

1:05 PM


[DustSensor]



Display From: 4/18/2005 2:16:30 PM To: 4/18/2005 2:17:53 PM

1:20 PM


[DustSensor]



Display From: 4/18/2005 2:34:30 PM To: 4/18/2005 2:35:54 PM

1:35 PM


[DustSensor]



Display From: 4/18/2005 2:46:14 PM To: 4/18/2005 2:48:39 PM

1:50 PM


[DustSensor]



Display From: 4/18/2005 3:04:46 PM To: 4/18/2005 3:05:49 PM

3:05 PM

[DustSensor]




Display From: 4/18/2005 3:16:51 PM To: 4/18/2005 3:17:53 PM

2:20 PM




[DustSensor]



Display From: 4/18/2005 2:34:57 PM To: 4/18/2005 2:36:30 PM


2:38 PM

[DustSensor]



3.05 ✓


[DustSensor]



Display From: 4/18/2005 4:18:29 PM To: 4/18/2005 4:21:23 PM

15 20


[DustSensor]



Display From: 4/18/2005 4:35:06 PM To: 4/18/2005 4:35:32 PM

3:35 PM


[DustSensor]



Display From: 4/18/2005 4:50:00 PM To: 4/18/2005 4:50:50 PM

*3.50 PM*


[DustSensor]



Display From: 4/18/2005 4:04:59 PM To: 4/18/2005 4:05:50 PM

~~4:05~~  
4:05 PM


[DustSensor]



Display From: 4/18/2005 4:20:28 PM To: 4/18/2005 4:20:58 PM

108  
4:20 PM


[DustSensor]



4:35 PM




[DustSensor]



Display From: 4/18/2005 4:49:55 PM To: 4/18/2005 4:51:07 PM

4:50 PM


[DustSensor]



Display From: 4/18/2005 6:05:15 PM To: 4/18/2005 6:05:36 PM

5:05 PM


[DustSensor]



Display From: 4/18/2005 6:19:59 PM To: 4/18/2005 6:21:00 PM

5:20 PM


[DustSensor]



Display From: 4/18/2005 6:34:58 PM To: 4/18/2005 6:35:43 PM

*108 5:35 PM*


[DustSensor]



Display From: 4/18/2005 6:49:59 PM To: 4/18/2005 6:51:00 PM

5:50 PM


[DustSensor]



Display From: 4/18/2005 7:04:59 PM To: 4/18/2005 7:05:59 PM

6:05 PM


[DustSensor]



Display From: 4/18/2005 7:19:50 PM To: 4/18/2005 7:21:00 PM

6:20 P.M.

[DustSensor]




Display From: 4/18/2005 7:34:58 PM To: 4/18/2005 7:35:52 PM

6:35 PM




[DustSensor]



Display From: 4/18/2005 7:49:59 PM To: 4/18/2005 7:51:00 PM

6:50 Pm


[DustSensor]



Display From: 4/18/2005 8:04:58 PM To: 4/18/2005 8:05:59 PM

7:05 P.M.


[DustSensor]



Display From: 4/18/2005 8:19:59 PM To: 4/18/2005 8:21:00 PM

7:21 PM


[DustSensor]



Display From: 4/18/2005 8:34:57 PM To: 4/18/2005 8:35:56 PM

7:35 P.M.

[DustSensor]



Display From: 4/18/2005 8:50:00 PM To: 4/18/2005 8:51:02 PM

7:50 PM

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/19/2005/ 8:15:57 AM

Main Fan #1 Operating Current	165Amps
Main Fan #2 Operating Current	160Amps
Main Fan #3 Operating Current	158Amps
Main Fan #4 Operating Current	160Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	77Amps
Reverse Air Fan #2 Operating Current	79Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	47.6%
Main Fan #2 Inlet Damper Position	54.6%
Main Fan #3 Inlet Damper Position	43.4%
Main Fan #4 Inlet Damper Position	42%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	29.9%
Reverse Air Fan #2 Damper Position	29.9%
Reverse Air Fan #3 Damper Position	0.2%
Fan Inlet Duct Pressure	5.6inWC
Baghouse Differential Duct Pressure	8.6inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/19/2005/ 8:31:05 AM

Main Fan #1 Operating Current	159Amps
Main Fan #2 Operating Current	158Amps
Main Fan #3 Operating Current	158Amps
Main Fan #4 Operating Current	157Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	76Amps
Reverse Air Fan #2 Operating Current	82Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	54.9%
Main Fan #2 Inlet Damper Position	63.9%
Main Fan #3 Inlet Damper Position	50.4%
Main Fan #4 Inlet Damper Position	50.1%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	29.9%
Reverse Air Fan #2 Damper Position	29.9%
Reverse Air Fan #3 Damper Position	0.2%
Fan Inlet Duct Pressure	4.8inWC
Baghouse Differential Duct Pressure	9.4inWC

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/19/2005/ 8:45:36 AM

Main Fan #1 Operating Current	157Amps
Main Fan #2 Operating Current	158Amps
Main Fan #3 Operating Current	160Amps
Main Fan #4 Operating Current	157Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	55Amps
Reverse Air Fan #2 Operating Current	58Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	58%
Main Fan #2 Inlet Damper Position	67.8%
Main Fan #3 Inlet Damper Position	53.7%
Main Fan #4 Inlet Damper Position	53.9%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	29.9%
Reverse Air Fan #2 Damper Position	29.9%
Reverse Air Fan #3 Damper Position	0.2%
Fan Inlet Duct Pressure	5inWC
Baghouse Differential Duct Pressure	8.8inWC



# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/19/2005/ 9:01:22 AM

Main Fan #1 Operating Current	158Amps
Main Fan #2 Operating Current	162Amps
Main Fan #3 Operating Current	161Amps
Main Fan #4 Operating Current	159Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	78Amps
Reverse Air Fan #2 Operating Current	80Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	49.3%
Main Fan #2 Inlet Damper Position	57.2%
Main Fan #3 Inlet Damper Position	45.9%
Main Fan #4 Inlet Damper Position	43.9%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	29.9%
Reverse Air Fan #2 Damper Position	29.9%
Reverse Air Fan #3 Damper Position	0.2%
Fan Inlet Duct Pressure	5inWC
Baghouse Differential Duct Pressure	8.9inWC

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/19/2005/ 9:15:59 AM

Main Fan #1 Operating Current	160Amps
Main Fan #2 Operating Current	158Amps
Main Fan #3 Operating Current	159Amps
Main Fan #4 Operating Current	161Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	74Amps
Reverse Air Fan #2 Operating Current	81Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	54%
Main Fan #2 Inlet Damper Position	63.3%
Main Fan #3 Inlet Damper Position	50.3%
Main Fan #4 Inlet Damper Position	48.9%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	29.9%
Reverse Air Fan #2 Damper Position	29.9%
Reverse Air Fan #3 Damper Position	0.1%
Fan Inlet Duct Pressure	5.2inWC
Baghouse Differential Duct Pressure	9.4inWC

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/19/2005/ 9:30:54 AM

Main Fan #1 Operating Current	159Amps
Main Fan #2 Operating Current	156Amps
Main Fan #3 Operating Current	160Amps
Main Fan #4 Operating Current	159Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	54Amps
Reverse Air Fan #2 Operating Current	58Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	60.1%
Main Fan #2 Inlet Damper Position	70.8%
Main Fan #3 Inlet Damper Position	54.8%
Main Fan #4 Inlet Damper Position	54.9%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	29.9%
Reverse Air Fan #2 Damper Position	29.9%
Reverse Air Fan #3 Damper Position	0.1%
Fan Inlet Duct Pressure	5inWC
Baghouse Differential Duct Pressure	9.9inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/19/2005/ 9:45:39 AM

Main Fan #1 Operating Current	155Amps
Main Fan #2 Operating Current	155Amps
Main Fan #3 Operating Current	157Amps
Main Fan #4 Operating Current	153Amps
<del>Main Fan #5 Operating Current</del>	<del>1Amps</del>
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	54Amps
Reverse Air Fan #2 Operating Current	59Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	49.7%
Main Fan #2 Inlet Damper Position	57.6%
Main Fan #3 Inlet Damper Position	46.7%
Main Fan #4 Inlet Damper Position	44.3%
Main Fan #5 Inlet Damper Position	0.1%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	29.9%
Reverse Air Fan #2 Damper Position	29.9%
Reverse Air Fan #3 Damper Position	0.1%
Fan Inlet Duct Pressure	5.3inWC
Baghouse Differential Duct Pressure	7.4inWC

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/19/2005/ 10:15:21 AM

Main Fan #1 Operating Current	160Amps
Main Fan #2 Operating Current	160Amps
Main Fan #3 Operating Current	160Amps
Main Fan #4 Operating Current	160Amps
Main Fan #5 Operating Current	2Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	54Amps
Reverse Air Fan #2 Operating Current	57Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	60.5%
Main Fan #2 Inlet Damper Position	70.6%
Main Fan #3 Inlet Damper Position	54.6%
Main Fan #4 Inlet Damper Position	55%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	29.9%
Reverse Air Fan #2 Damper Position	29.9%
Reverse Air Fan #3 Damper Position	0.1%
Fan Inlet Duct Pressure	5.3inWC
Baghouse Differential Duct Pressure	10.1inWC

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/19/2005/ 10:33:25 AM

Main Fan #1 Operating Current	159Amps
Main Fan #2 Operating Current	159Amps
Main Fan #3 Operating Current	158Amps
Main Fan #4 Operating Current	161Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	54Amps
Reverse Air Fan #2 Operating Current	59Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	47.1%
Main Fan #2 Inlet Damper Position	54.6%
Main Fan #3 Inlet Damper Position	43.5%
Main Fan #4 Inlet Damper Position	41.4%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	29.9%
Reverse Air Fan #2 Damper Position	29.9%
Reverse Air Fan #3 Damper Position	0.1%
Fan Inlet Duct Pressure	5.7inWC
Baghouse Differential Duct Pressure	8.4inWC

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/19/2005/ 10:46:41 AM

Main Fan #1 Operating Current	163Amps
Main Fan #2 Operating Current	160Amps
Main Fan #3 Operating Current	161Amps
Main Fan #4 Operating Current	160Amps
<del>Main Fan #5 Operating Current</del>	<del>1Amps</del>
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	57Amps
Reverse Air Fan #2 Operating Current	59Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	46.2%
Main Fan #2 Inlet Damper Position	53.4%
Main Fan #3 Inlet Damper Position	43.2%
Main Fan #4 Inlet Damper Position	40.2%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	29.9%
Reverse Air Fan #2 Damper Position	29.9%
Reverse Air Fan #3 Damper Position	0.1%
Fan Inlet Duct Pressure	5.9inWC
Baghouse Differential Duct Pressure	8.2inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/19/2005/ 12:40:23 PM

Main Fan #1 Operating Current	158Amps
Main Fan #2 Operating Current	154Amps
Main Fan #3 Operating Current	157Amps
Main Fan #4 Operating Current	161Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	0Amps
Reverse Air Fan #1 Operating Current	79Amps
Reverse Air Fan #2 Operating Current	85Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	43.5%
Main Fan #2 Inlet Damper Position	49.9%
Main Fan #3 Inlet Damper Position	41.3%
Main Fan #4 Inlet Damper Position	37.1%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30%
Reverse Air Fan #2 Damper Position	29.9%
Reverse Air Fan #3 Damper Position	0.1%
Fan Inlet Duct Pressure	5.2inWC
Baghouse Differential Duct Pressure	6.9inWC



# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/19/2005/ 12:55:46 PM

Main Fan #1 Operating Current	163Amps
Main Fan #2 Operating Current	161Amps
Main Fan #3 Operating Current	159Amps
Main Fan #4 Operating Current	164Amps
<del>Main Fan #5 Operating Current</del>	<del>1Amps</del>
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	58Amps
Reverse Air Fan #2 Operating Current	57Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	54.4%
Main Fan #2 Inlet Damper Position	63.3%
Main Fan #3 Inlet Damper Position	49.3%
Main Fan #4 Inlet Damper Position	48.6%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30%
Reverse Air Fan #2 Damper Position	29.9%
Reverse Air Fan #3 Damper Position	0.1%
Fan Inlet Duct Pressure	4.8inWC
Baghouse Differential Duct Pressure	8.4inWC

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/19/2005/ 1:12:42 PM

Main Fan #1 Operating Current	161Amps
Main Fan #2 Operating Current	165Amps
Main Fan #3 Operating Current	162Amps
Main Fan #4 Operating Current	163Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	0Amps
Reverse Air Fan #1 Operating Current	57Amps
Reverse Air Fan #2 Operating Current	58Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	53.3%
Main Fan #2 Inlet Damper Position	62.6%
Main Fan #3 Inlet Damper Position	48.9%
Main Fan #4 Inlet Damper Position	48.7%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30%
Reverse Air Fan #2 Damper Position	29.9%
Reverse Air Fan #3 Damper Position	0.1%
Fan Inlet Duct Pressure	5.9inWC
Baghouse Differential Duct Pressure	8.3inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/19/2005/ 1:25:14 PM

Main Fan #1 Operating Current	161Amps
Main Fan #2 Operating Current	162Amps
Main Fan #3 Operating Current	158Amps
Main Fan #4 Operating Current	159Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	0Amps
Reverse Air Fan #1 Operating Current	77Amps
Reverse Air Fan #2 Operating Current	81Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	45.6%
Main Fan #2 Inlet Damper Position	52.6%
Main Fan #3 Inlet Damper Position	42.5%
Main Fan #4 Inlet Damper Position	39.8%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30.1%
Reverse Air Fan #2 Damper Position	30%
Reverse Air Fan #3 Damper Position	0.1%
Fan Inlet Duct Pressure	5.6inWC
Baghouse Differential Duct Pressure	7.6inWC

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/19/2005/ 1:45:10 PM

Main Fan #1 Operating Current	162Amps
Main Fan #2 Operating Current	163Amps
Main Fan #3 Operating Current	159Amps
Main Fan #4 Operating Current	162Amps
<del>Main Fan #5 Operating Current</del>	<del>1Amps</del>
Main Fan #6 Operating Current	0Amps
Reverse Air Fan #1 Operating Current	75Amps
Reverse Air Fan #2 Operating Current	78Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	56.5%
Main Fan #2 Inlet Damper Position	66.8%
Main Fan #3 Inlet Damper Position	51.1%
Main Fan #4 Inlet Damper Position	51.6%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30%
Reverse Air Fan #2 Damper Position	30%
Reverse Air Fan #3 Damper Position	0.1%
Fan Inlet Duct Pressure	5.3inWC
Baghouse Differential Duct Pressure	9.3inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/19/2005/ 1:55:06 PM

Main Fan #1 Operating Current	158Amps
Main Fan #2 Operating Current	161Amps
Main Fan #3 Operating Current	162Amps
Main Fan #4 Operating Current	158Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	56Amps
Reverse Air Fan #2 Operating Current	60Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	60.1%
Main Fan #2 Inlet Damper Position	71%
Main Fan #3 Inlet Damper Position	54.2%
Main Fan #4 Inlet Damper Position	55.1%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30%
Reverse Air Fan #2 Damper Position	30%
Reverse Air Fan #3 Damper Position	0.1%
Fan Inlet Duct Pressure	5.4inWC
Baghouse Differential Duct Pressure	9.6inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/19/2005/ 2:10:14 PM

Main Fan #1 Operating Current	163Amps
Main Fan #2 Operating Current	161Amps
Main Fan #3 Operating Current	160Amps
Main Fan #4 Operating Current	159Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	0Amps
Reverse Air Fan #1 Operating Current	56Amps
Reverse Air Fan #2 Operating Current	60Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	47.1%
Main Fan #2 Inlet Damper Position	54.2%
Main Fan #3 Inlet Damper Position	43.4%
Main Fan #4 Inlet Damper Position	41.1%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30%
Reverse Air Fan #2 Damper Position	30%
Reverse Air Fan #3 Damper Position	0.1%
Fan Inlet Duct Pressure	5.7inWC
Baghouse Differential Duct Pressure	8inWC

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/19/2005/ 2:25:37 PM

Main Fan #1 Operating Current	158Amps
Main Fan #2 Operating Current	160Amps
Main Fan #3 Operating Current	158Amps
Main Fan #4 Operating Current	158Amps
<del>Main Fan #5 Operating Current</del>	<del>2Amps</del>
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	76Amps
Reverse Air Fan #2 Operating Current	84Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	45.9%
Main Fan #2 Inlet Damper Position	53.3%
Main Fan #3 Inlet Damper Position	43.7%
Main Fan #4 Inlet Damper Position	40.6%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30.1%
Reverse Air Fan #2 Damper Position	30%
Reverse Air Fan #3 Damper Position	0.1%
Fan Inlet Duct Pressure	5.1inWC
Baghouse Differential Duct Pressure	7.7inWC

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/19/2005/ 2:40:23 PM

Main Fan #1 Operating Current	160Amps
Main Fan #2 Operating Current	162Amps
Main Fan #3 Operating Current	161Amps
Main Fan #4 Operating Current	162Amps
<del>Main Fan #5 Operating Current</del>	<del>1Amps</del>
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	76Amps
Reverse Air Fan #2 Operating Current	79Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	55.3%
Main Fan #2 Inlet Damper Position	64.6%
Main Fan #3 Inlet Damper Position	49.9%
Main Fan #4 Inlet Damper Position	50%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30.1%
Reverse Air Fan #2 Damper Position	30%
Reverse Air Fan #3 Damper Position	0.1%
Fan Inlet Duct Pressure	5.7inWC
Baghouse Differential Duct Pressure	9.4inWC



# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/19/2005/ 2:55:18 PM

Main Fan #1 Operating Current	159Amps
Main Fan #2 Operating Current	160Amps
Main Fan #3 Operating Current	159Amps
Main Fan #4 Operating Current	159Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	78Amps
Reverse Air Fan #2 Operating Current	82Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	61.8%
Main Fan #2 Inlet Damper Position	72.6%
Main Fan #3 Inlet Damper Position	56.1%
Main Fan #4 Inlet Damper Position	55.7%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30.1%
Reverse Air Fan #2 Damper Position	30%
Reverse Air Fan #3 Damper Position	0.1%
Fan Inlet Duct Pressure	5.1inWC
Baghouse Differential Duct Pressure	9.5inWC

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/19/2005/ 3:10:36 PM

Main Fan #1 Operating Current	157Amps
Main Fan #2 Operating Current	159Amps
Main Fan #3 Operating Current	159Amps
Main Fan #4 Operating Current	154Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	0Amps
Reverse Air Fan #1 Operating Current	76Amps
Reverse Air Fan #2 Operating Current	81Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	53.2%
Main Fan #2 Inlet Damper Position	62.7%
Main Fan #3 Inlet Damper Position	49.6%
Main Fan #4 Inlet Damper Position	48.8%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30.1%
Reverse Air Fan #2 Damper Position	30%
Reverse Air Fan #3 Damper Position	0.1%
Fan Inlet Duct Pressure	5.5inWC
Baghouse Differential Duct Pressure	9.1inWC

**Nucor Steel, Crawfordsville**  
**Baghouse #2 Operations Report**

Report Date/Time


4/19/2005/ 4:07:50 PM

Main Fan #1 Operating Current	159Amps
Main Fan #2 Operating Current	160Amps
Main Fan #3 Operating Current	158Amps
Main Fan #4 Operating Current	161Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	0Amps
Reverse Air Fan #1 Operating Current	71Amps
Reverse Air Fan #2 Operating Current	77Amps
Reverse Air Fan #3 Operating Current	0Amps
Main Fan #1 Inlet Damper Position	60.2%
Main Fan #2 Inlet Damper Position	71%
Main Fan #3 Inlet Damper Position	54.4%
Main Fan #4 Inlet Damper Position	55.1%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	30%
Reverse Air Fan #2 Damper Position	30%
Reverse Air Fan #3 Damper Position	0.1%
Fan Inlet Duct Pressure	5.6inWC
Baghouse Differential Duct Pressure	10.3inWC






[DustSensor]



Display From: 4/19/2005 1:34:41 PM To: 4/19/2005 1:35:56 PM

12:40 PM


[DustSensor]



Display From: ~~4/19/2005 9:12:44 AM~~ To: 4/19/2005 9:20:57 AM

8:15 AM

[DustSensor]




Display From: 4/19/2005-9:25:19 AM To: 4/19/2005-9:31:58 AM

8:30 AM




[DustSensor]



Display From: 4/19/2005 9:37:47 AM To: 4/19/2005 9:42:19 AM

8:45 AM


[DustSensor]



Display From: 4/19/2005-9:57:09 AM To: 4/19/2005-10:01:02 AM

9:00 AM


[DustSensor]



Display From: 4/19/2005 10:14:08 AM To: 4/19/2005 10:18:26 AM

9:15 AM


[DustSensor]



Display From: 4/19/2005 10:25:07 AM To: 4/19/2005 10:30:51 AM

9:30 AM


[DustSensor]



Display From: 4/19/2005 10:44:01 AM To: 4/19/2005 10:47:08 AM

10:45 AM


[DustSensor]



Display From: 4/19/2005 11:09:25 AM To: 4/19/2005 11:12:08 AM

12:15 PM


[DustSensor]



Display From: 4/19/2005 11:28:18 AM To: 4/19/2005 11:30:11 AM

12:30 PM

[DustSensor]




Display From: 4/19/2005 4:37:56 PM To: 4/19/2005 4:41:23 PM

12:40 PM




[DustSensor]



Display From: 4/19/2005 1:52:42 PM To: 4/19/2005 1:54:05 PM

12:55 PM


[DustSensor]



Display From: 4/19/2005 2:04:35 PM To: 4/19/2005 2:06:13 PM

1:10 PM


[DustSensor]



Display From: 4/19/2005 2:22:25 PM To: 4/19/2005 2:24:03 PM

1:25 PM


[DustSensor]



Display From: 4/19/2005 2:36:58 PM To: 4/19/2005 2:43:27 PM

1:40 PM


[DustSensor]



Display From: 4/19/2005 2:53:14 PM To: 4/19/2005 2:53:56 PM

1:55 PM


[DustSensor]



Display From: 4/19/2005 3:04:58 PM To: 4/19/2005 3:05:57 PM

2:10 PM


[DustSensor]



Display From: 4/19/2005 3:23:04 PM To: 4/19/2005 3:24:05 PM

2.25 PM

[DustSensor]




Display From: 4/19/2005 3:34:58 PM To: 4/19/2005 3:35:59 PM

2:40 PM




[DustSensor]



Display From: 4/19/2005 3:52:58 PM To: 4/19/2005 3:53:59 PM

2:55 PM


[DustSensor]



Display From: 4/19/2005 4:04:53 PM To: 4/19/2005 4:05:55 PM

3:10 PM


[DustSensor]



Display From: 4/19/2005 4:22:55 PM To: 4/19/2005 4:23:58 PM

3:25 PM


[DustSensor]



Display From: 4/19/2005 4:40:08 PM To: 4/19/2005 4:41:59 PM

3:40 PM


[DustSensor]



Display From: 4/19/2005 4:52:57 PM To: 4/19/2005 4:53:53 PM

3:55 PM

[DustSensor]



Display From: 4/19/2005 5:04:50 PM To: 4/19/2005 5:05:59 PM

4:07 PM

Baghouse # 2

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/22/2005/ 8:33:20 AM

Main Fan #1 Operating Current	162Amps
Main Fan #2 Operating Current	160Amps
Main Fan #3 Operating Current	157Amps
Main Fan #4 Operating Current	161Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	0Amps
Reverse Air Fan #1 Operating Current	0Amps
Reverse Air Fan #2 Operating Current	87Amps
Reverse Air Fan #3 Operating Current	80Amps
Main Fan #1 Inlet Damper Position	49.4%
Main Fan #2 Inlet Damper Position	56.8%
Main Fan #3 Inlet Damper Position	43.0%
Main Fan #4 Inlet Damper Position	42.9%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	0.2%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	30.2%
Fan Inlet Duct Pressure	5.5inWC
Baghouse Differential Duct Pressure	7.9inWC

*Inlet Damper on fan #3 isn't reading but it's actually commanding. Found tripped breaker. Damper stuck on = 40%.*

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/22/2005/ 8:49:51 AM

Main Fan #1 Operating Current	158Amps
Main Fan #2 Operating Current	160Amps
Main Fan #3 Operating Current	154Amps
Main Fan #4 Operating Current	160Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	0Amps
Reverse Air Fan #1 Operating Current	0Amps
Reverse Air Fan #2 Operating Current	85Amps
Reverse Air Fan #3 Operating Current	78Amps
Main Fan #1 Inlet Damper Position	52.9%
Main Fan #2 Inlet Damper Position	60.7%
Main Fan #3 Inlet Damper Position	61.0%
Main Fan #4 Inlet Damper Position	48.5%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	0.2%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	30.3%
Fan Inlet Duct Pressure	5.2inWC
Baghouse Differential Duct Pressure	8.1inWC



# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/22/2005/ 9:03:23 AM

Main Fan #1 Operating Current	160Amps
Main Fan #2 Operating Current	161Amps
Main Fan #3 Operating Current	156Amps
Main Fan #4 Operating Current	159Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	0Amps
Reverse Air Fan #1 Operating Current	0Amps
Reverse Air Fan #2 Operating Current	86Amps
Reverse Air Fan #3 Operating Current	80Amps
Main Fan #1 Inlet Damper Position	51.3%
Main Fan #2 Inlet Damper Position	58.5%
Main Fan #3 Inlet Damper Position	100.0%
Main Fan #4 Inlet Damper Position	46%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	0.2%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	30.3%
Fan Inlet Duct Pressure	5.4inWC
Baghouse Differential Duct Pressure	8.3inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/22/2005/ 9:18:10 AM

Main Fan #1 Operating Current	165Amps
Main Fan #2 Operating Current	165Amps
Main Fan #3 Operating Current	158Amps
Main Fan #4 Operating Current	164Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	0Amps
Reverse Air Fan #1 Operating Current	0Amps
Reverse Air Fan #2 Operating Current	84Amps
Reverse Air Fan #3 Operating Current	78Amps
Main Fan #1 Inlet Damper Position	53.2%
Main Fan #2 Inlet Damper Position	62.5%
Main Fan #3 Inlet Damper Position	13.8%
Main Fan #4 Inlet Damper Position	47.7%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	0.2%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	30.3%
Fan Inlet Duct Pressure	5.5inWC
Baghouse Differential Duct Pressure	9inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/22/2005/ 9:33:15 AM

Main Fan #1 Operating Current	160Amps
Main Fan #2 Operating Current	162Amps
Main Fan #3 Operating Current	157Amps
Main Fan #4 Operating Current	156Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	0Amps
Reverse Air Fan #2 Operating Current	86Amps
Reverse Air Fan #3 Operating Current	78Amps
Main Fan #1 Inlet Damper Position	53.7%
Main Fan #2 Inlet Damper Position	60.9%
Main Fan #3 Inlet Damper Position	50.7%
Main Fan #4 Inlet Damper Position	48.5%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	0.2%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	30.3%
Fan Inlet Duct Pressure	5.3inWC
Baghouse Differential Duct Pressure	8.6inWC

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/22/2005/ 9:48:22 AM

Main Fan #1 Operating Current	156Amps
Main Fan #2 Operating Current	156Amps
Main Fan #3 Operating Current	160Amps
Main Fan #4 Operating Current	163Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	0Amps
Reverse Air Fan #1 Operating Current	0Amps
Reverse Air Fan #2 Operating Current	84Amps
Reverse Air Fan #3 Operating Current	72Amps
Main Fan #1 Inlet Damper Position	56.8%
Main Fan #2 Inlet Damper Position	64.6%
Main Fan #3 Inlet Damper Position	51.9%
Main Fan #4 Inlet Damper Position	51%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.2%
Reverse Air Fan #1 Damper Position	0.2%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	30.3%
Fan Inlet Duct Pressure	5inWC
Baghouse Differential Duct Pressure	9.2inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/22/2005/ 10:03:36 AM

Main Fan #1 Operating Current	162Amps
Main Fan #2 Operating Current	162Amps
Main Fan #3 Operating Current	164Amps
Main Fan #4 Operating Current	165Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	0Amps
Reverse Air Fan #1 Operating Current	0Amps
Reverse Air Fan #2 Operating Current	81Amps
Reverse Air Fan #3 Operating Current	75Amps
Main Fan #1 Inlet Damper Position	54.8%
Main Fan #2 Inlet Damper Position	64.3%
Main Fan #3 Inlet Damper Position	49.4%
Main Fan #4 Inlet Damper Position	49.3%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	0.3%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	30.2%
Fan Inlet Duct Pressure	5.3inWC
Baghouse Differential Duct Pressure	9.8inWC

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/22/2005/ 10:18:36 AM

Main Fan #1 Operating Current	161Amps
Main Fan #2 Operating Current	162Amps
Main Fan #3 Operating Current	161Amps
Main Fan #4 Operating Current	164Amps
Main Fan #5 Operating Current	0Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	0Amps
Reverse Air Fan #2 Operating Current	82Amps
Reverse Air Fan #3 Operating Current	76Amps
Main Fan #1 Inlet Damper Position	48.4%
Main Fan #2 Inlet Damper Position	56.3%
Main Fan #3 Inlet Damper Position	44.6%
Main Fan #4 Inlet Damper Position	43.3%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	0.2%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	30.2%
Fan Inlet Duct Pressure	5.4inWC
Baghouse Differential Duct Pressure	9inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/22/2005/ 10:37:28 AM

Main Fan #1 Operating Current	162Amps
Main Fan #2 Operating Current	159Amps
Main Fan #3 Operating Current	159Amps
Main Fan #4 Operating Current	161Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	0Amps
Reverse Air Fan #1 Operating Current	0Amps
Reverse Air Fan #2 Operating Current	61Amps
Reverse Air Fan #3 Operating Current	49Amps
Main Fan #1 Inlet Damper Position	51.8%
Main Fan #2 Inlet Damper Position	60.2%
Main Fan #3 Inlet Damper Position	47.6%
Main Fan #4 Inlet Damper Position	46.5%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	0.2%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	30.3%
Fan Inlet Duct Pressure	5.1inWC
Baghouse Differential Duct Pressure	9inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/22/2005/ 10:45:48 AM

Main Fan #1 Operating Current	158Amps
Main Fan #2 Operating Current	156Amps
Main Fan #3 Operating Current	159Amps
Main Fan #4 Operating Current	162Amps
Main Fan #5 Operating Current	0Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	0Amps
Reverse Air Fan #2 Operating Current	61Amps
Reverse Air Fan #3 Operating Current	48Amps
Main Fan #1 Inlet Damper Position	59%
Main Fan #2 Inlet Damper Position	69.2%
Main Fan #3 Inlet Damper Position	54.2%
Main Fan #4 Inlet Damper Position	54.7%
Main Fan #5 Inlet Damper Position	0.1%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	0.2%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	30.3%
Fan Inlet Duct Pressure	5inWC
Baghouse Differential Duct Pressure	9.6inWC



# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/22/2005/ 11:30:18 AM

Main Fan #1 Operating Current	157Amps
Main Fan #2 Operating Current	155Amps
Main Fan #3 Operating Current	158Amps
Main Fan #4 Operating Current	155Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	0Amps
Reverse Air Fan #1 Operating Current	0Amps
Reverse Air Fan #2 Operating Current	86Amps
Reverse Air Fan #3 Operating Current	79Amps
Main Fan #1 Inlet Damper Position	50.9%
Main Fan #2 Inlet Damper Position	58.5%
Main Fan #3 Inlet Damper Position	46.9%
Main Fan #4 Inlet Damper Position	45.5%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	0.2%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	30.2%
Fan Inlet Duct Pressure	5.1inWC
Baghouse Differential Duct Pressure	7.9inWC

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/22/2005/ 11:48:14 AM

Main Fan #1 Operating Current	157Amps
Main Fan #2 Operating Current	160Amps
Main Fan #3 Operating Current	161Amps
Main Fan #4 Operating Current	162Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	0Amps
Reverse Air Fan #1 Operating Current	0Amps
Reverse Air Fan #2 Operating Current	60Amps
Reverse Air Fan #3 Operating Current	49Amps
Main Fan #1 Inlet Damper Position	50.6%
Main Fan #2 Inlet Damper Position	58.2%
Main Fan #3 Inlet Damper Position	46.7%
Main Fan #4 Inlet Damper Position	45.3%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	0.2%
Reverse Air Fan #2 Damper Position	30.1%
Reverse Air Fan #3 Damper Position	30.2%
Fan Inlet Duct Pressure	5.3inWC
Baghouse Differential Duct Pressure	8.2inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/22/2005/ 12:00:44 PM

Main Fan #1 Operating Current	161Amps
Main Fan #2 Operating Current	159Amps
Main Fan #3 Operating Current	164Amps
Main Fan #4 Operating Current	160Amps
Main Fan #5 Operating Current	0Amps
Main Fan #6 Operating Current	0Amps
Reverse Air Fan #1 Operating Current	0Amps
Reverse Air Fan #2 Operating Current	79Amps
Reverse Air Fan #3 Operating Current	77Amps
Main Fan #1 Inlet Damper Position	56.2%
Main Fan #2 Inlet Damper Position	65.9%
Main Fan #3 Inlet Damper Position	51.1%
Main Fan #4 Inlet Damper Position	51.6%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	0.2%
Reverse Air Fan #2 Damper Position	30.2%
Reverse Air Fan #3 Damper Position	30.2%
Fan Inlet Duct Pressure	5.2inWC
Baghouse Differential Duct Pressure	9.3inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/22/2005/ 12:15:49 PM

Main Fan #1 Operating Current	166Amps
Main Fan #2 Operating Current	166Amps
Main Fan #3 Operating Current	165Amps
Main Fan #4 Operating Current	163Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	0Amps
Reverse Air Fan #1 Operating Current	0Amps
Reverse Air Fan #2 Operating Current	62Amps
Reverse Air Fan #3 Operating Current	50Amps
Main Fan #1 Inlet Damper Position	59.9%
Main Fan #2 Inlet Damper Position	70.2%
Main Fan #3 Inlet Damper Position	54.4%
Main Fan #4 Inlet Damper Position	54.3%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.2%
Reverse Air Fan #1 Damper Position	0.2%
Reverse Air Fan #2 Damper Position	30.2%
Reverse Air Fan #3 Damper Position	30.2%
Fan Inlet Duct Pressure	5.5inWC
Baghouse Differential Duct Pressure	10.1inWC

# Nucor Steel, Crawfordsville

## Baghouse #2 Operations Report

Report Date/Time

4/22/2005/ 12:30:14 PM

Main Fan #1 Operating Current	159Amps
Main Fan #2 Operating Current	157Amps
Main Fan #3 Operating Current	159Amps
Main Fan #4 Operating Current	158Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	0Amps
Reverse Air Fan #1 Operating Current	0Amps
Reverse Air Fan #2 Operating Current	61Amps
Reverse Air Fan #3 Operating Current	49Amps
Main Fan #1 Inlet Damper Position	55.8%
Main Fan #2 Inlet Damper Position	64.2%
Main Fan #3 Inlet Damper Position	51%
Main Fan #4 Inlet Damper Position	50.4%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	0.2%
Reverse Air Fan #2 Damper Position	30.2%
Reverse Air Fan #3 Damper Position	30.2%
Fan Inlet Duct Pressure	5.3inWC
Baghouse Differential Duct Pressure	9inWC

M

OS

OS

OS

OS

OS

OS

OS

OS

%

%

%

%

%

%

%

%

C

C

rt

:31:12 PM

4/22/2005/ 1:45:19 PM

163Amps	163Amps
170Amps	162Amps
159Amps	158Amps
162Amps	160Amps
1Amps	1Amps
0Amps	0Amps
0Amps	0Amps
60Amps	60Amps
48Amps	50Amps
63.3%	66%
91.4%	92%
58.3%	58.8%
58.5%	60.2%
0%	0%
0.1%	0.1%
0.2%	0.2%
0.2%	30.2%
0.2%	30.2%
5.2inWC	5.2inWC
10.2inWC	10.1inWC

# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time

4/22/2005/ 2:00:50 PM

Main Fan #1 Operating Current	165Amps
Main Fan #2 Operating Current	158Amps
Main Fan #3 Operating Current	163Amps
Main Fan #4 Operating Current	161Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	0Amps
Reverse Air Fan #1 Operating Current	0Amps
Reverse Air Fan #2 Operating Current	80Amps
Reverse Air Fan #3 Operating Current	74Amps
Main Fan #1 Inlet Damper Position	58.9%
Main Fan #2 Inlet Damper Position	92.3%
Main Fan #3 Inlet Damper Position	53.8%
Main Fan #4 Inlet Damper Position	54%
Main Fan #5 Inlet Damper Position	0.1%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	0.2%
Reverse Air Fan #2 Damper Position	30.2%
Reverse Air Fan #3 Damper Position	30.2%
Fan Inlet Duct Pressure	5.1inWC
Baghouse Differential Duct Pressure	9.8inWC



# Nucor Steel, Crawfordsville Baghouse #2 Operations Report

Report Date/Time


4/22/2005/ 2:13:58 PM

Main Fan #1 Operating Current	159Amps
Main Fan #2 Operating Current	163Amps
Main Fan #3 Operating Current	164Amps
Main Fan #4 Operating Current	159Amps
Main Fan #5 Operating Current	1Amps
Main Fan #6 Operating Current	1Amps
Reverse Air Fan #1 Operating Current	0Amps
Reverse Air Fan #2 Operating Current	78Amps
Reverse Air Fan #3 Operating Current	73Amps
Main Fan #1 Inlet Damper Position	61%
Main Fan #2 Inlet Damper Position	91.4%
Main Fan #3 Inlet Damper Position	55%
Main Fan #4 Inlet Damper Position	55.3%
Main Fan #5 Inlet Damper Position	0%
Main Fan #6 Inlet Damper Position	0.1%
Reverse Air Fan #1 Damper Position	0.2%
Reverse Air Fan #2 Damper Position	30.2%
Reverse Air Fan #3 Damper Position	30.2%
Fan Inlet Duct Pressure	5inWC
Baghouse Differential Duct Pressure	9.9inWC


<u>4-22-05</u>	1/2	3/4	5/6	7/8	9/10	11/12	13/14	15/16
8:3	0.7	0.7	0.7	0.4	0.6	0.6	0.7	0.7
8:48	1.0	4.2	1.3	0.5	0.8	3.9	1.0	3.3
9:03	0.4	2.4	0.9	0.6	0.2	0.1	0.6	0.8
9:18	0.8	0.7	0.7	0.8	0.3	0.3	0.7	0.8
9:33	0.6	2.7	1.7	2.6	1.4	5.0	1.2	1.1
9:48	0.5	1.5	0.7	0.3	0.3	26.3	0.2	0.7
10:03	0.7	0.7	0.7	6.5	1.2	1.0	0.7	0.8
10:18	0.7	0.6	1.2	0.8	0.4	0.0	0.2	0.7
10:33	2.6	1.0	0.8	2.2	0.7	0.8	0.8	0.7
10:48	0.8	0.9	1.0	1.9	0.8	2.0	0.9	0.8
11:03	0.7	0.5	1.1	2.0	0.5	0.8	2.4	1.2
11:18	2.4	1.0	0.7	3.9	0.0	1.0	1.0	1.0
12:00	0.7	0.7	0.7	4.7	1.1	0.5	0.7	0.7
12:15	0.7	1.0	0.7	0.6	0.8	0.7	1.8	0.7
12:30	0.8	0.7	0.7	2.4	1.0	0.4	0.5	0.7
12:45	0.7	0.7	3.3	0.4	0.7	0.7	0.7	0.7
1:00	1.0	0.8	2.7	0.7	0.2	0.8	1.2	0.8
1:15	0.0	0.7	3.4	4.6	0.4	1.0	1.8	0.8
1:30	0.7	0.7	3.0	1.0	0.2	0.7	0.7	0.7
1:45	7.6	0.5	0.7	0.8	0.1	0.2	0.1	0.7
2:00	1.1	1.9	1.7	0.5	1.7	4.1	1.1	1.3
2:15	0.8	1.0	1.1	5.5	1.5	3.6	1.8	1.5

Restart TEST


[DustSensor]




[DustSensor]




[DustSensor]




[DustSensor]



[DustSensor]




[DustSensor]







[DustSensor]




[DustSensor]




[DustSensor]




[DustSensor]




[DustSensor]




[DustSensor]



[DustSensor]




[DustSensor]







[DustSensor]




[DustSensor]




[DustSensor]



[DustSensor]




[DustSensor]




Display From: 4/22/2005 2:28:46 PM To: 4/22/2005 2:31:24 PM


[DustSensor]



[DustSensor]



[DustSensor]





Heat # 254835      Grade 409S2      Operator ~~Operator~~ *Muffin*  
 Practice CRSS LCLN      Slag ANY SS GRADE      Heat Created 04/18/05 12:17  
 Lining ID      Lining Minutes 17      Heats ~~125~~ 1      Min. Weight 220,000  
 Addswiz Oxygen Estimate 72314      TapToCharge 305.7542

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.004				0.100	11.050			
Max	0.015			0.010	0.200	11.250			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	0.781	0.280	0.036	0.029	0.129	5.950	0.070	0.005	0.009
A1	0.010	0.220	0.034	0.029	0.009	9.030	0.080	0.005	0.002
A2	0.009	0.280	0.035	0.004	0.319	10.690	0.080	0.006	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
51.32	10.16	27.15	11.12	0.00	0.00	17,727.16

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
12:18	Chem T1					
12:19	Charge					
12:20	Decarb					
12:20	Sample		0.7806	11		2352
12:25	Sample		0.7806	11		11218
12:27	Temp	2877				
12:27	Addswiz					
12:28	Decarb					
13:00	Sample		0.0148	91254		90999
13:01	Temp	3057				
13:02	Decarb					
13:06	Chem A1					
13:12	Reduce					
13:13	Addswiz					
13:24	Sample		0.0068	94512		173165
13:29	Temp	2976				
13:40	Sample		0.0070	94512		180554
13:41	Tap					

Tap Heat	04/18/05 13:41		<b>TOTALS</b>	<b>94512</b>	<b>0</b>	<b>180644</b>
Charge Heat	04/18/05 12:19	Transfer Wt	241,993			
Charge - Tap	82	Tap Wt	260,071			

ADDITIONS	Recipe1	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	WizRSg 01	Total
Al					670	537		1,207
Dolo				2,420			1,821	4,241
FeCrSi					1,000			1,000
FeSi					1,200	828		2,028
HCFeCr			19,700					19,700
LCCr	900							900
Lime		5,000					2,388	7,388
<b>Total</b>	<b>900</b>	<b>5,000</b>	<b>19,700</b>	<b>2,420</b>	<b>2,870</b>	<b>1,365</b>	<b>4,209</b>	<b>36,464</b>

Nucor Steel - Crawfordsville AOD Log

Heat # 254836 Grade 409S1 Operator mhinz  
 Practice CRSS LCLN Slag ANY SS GRADE Heat Created 04/18/05 13:43  
 Lining ID Lining Minutes 99 Heats ~~126~~ 2 Min. Weight 220,000  
 Addswiz Oxygen Estimate 73199 TapToCharge 2.708333

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.007				0.170	10.600			
Max	0.030	0.400		0.150	0.400	10.800			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	0.677	0.280	0.035	0.039	0.174	5.630	0.090	0.005	0.009
A1	0.008	0.180	0.031	0.039	0.008	9.460	0.120	0.005	0.002
A2	0.008	0.280	0.031	0.004	0.311	10.770	0.110	0.006	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
51.80	10.13	26.93	10.90	0.00	0.00	18,080.40

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
13:44	Charge					
13:44	Chem T1					
13:48	Sample		0.6771			7995
13:50	Temp	2864				
13:50	Addswiz					
13:50	Decarb					
14:22	Sample		0.0148	90184		85166
14:24	Temp	3066				
14:25	Decarb					
14:29	Chem A1					
14:31	Addswiz					
14:33	Reduce					
14:43	Sample		0.0068	92839		152970
14:46	Temp	3018				
14:51	Tap					

Tap Heat	04/18/05 14:51		<b>TOTALS</b>	<b>92839</b>	<b>0</b>	<b>153076</b>
Charge Heat	04/18/05 13:44	Transfer Wt	244,000			
<b>Charge - Tap</b>	<b>68</b>	<b>Tap Wt</b>	<b>262,930</b>			

ADDITIONS	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	WizRSg 01	Total
Al				707	692		1,399
Dolo			2,574			1,741	4,315
FeCrSi				1,000			1,000
FeSi				760	1,199		1,959
HCFeCr		21,205					21,205
Lime	5,000					2,511	7,511
<b>Total</b>	<b>5,000</b>	<b>21,205</b>	<b>2,574</b>	<b>2,467</b>	<b>1,891</b>	<b>4,252</b>	<b>37,389</b>

Heat # 254837      Grade 409S1      Operator mhinz  
 Practice CRSS LCLN HIT1      Slag ANY SS GRADE      Heat Created 04/18/05 14:54  
 Lining ID      Lining Minutes 167      Heats 127      Min. Weight 220,000  
 Addswiz Oxygen Estimate 67958      TapToCharge 2.8665

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.007				0.170	10.600			
Max	0.030	0.400		0.150	0.400	10.800			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
F1	1.007	0.290	0.032	0.039	0.194	6.930	0.090	0.006	0.009
T1	1.013	0.290	0.031	0.038	0.193	6.950	0.090	0.006	0.009
A1	0.055	0.250	0.027	0.029	0.009	9.760	0.110	0.005	0.002
A2	0.006	0.290	0.028	0.003	0.333	10.480	0.110	0.005	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
50.65	10.98	27.11	11.00	0.00	0.00	16,666.75

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
14:54	Charge					
14:55	Chem T1					
14:58	Sample		1.0130			6198
14:59	Temp	2835				
15:00	Addswiz					
15:00	Decarb					
15:29	Sample		0.0197	81013		83097
15:31	Temp	3020				
15:32	Decarb					
15:39	Chem A1					
15:54	Addswiz					
15:56	Reduce					
16:04	Sample		0.0060	92599		223361
16:10	Temp	2993				
16:15	Tap					

Tap Heat	04/18/05 16:15		<b>TOTALS</b>	<b>92599</b>	<b>0</b>	<b>223468</b>
Charge Heat	04/18/05 14:54	Transfer Wt	238,000			
<b>Charge - Tap</b>	<b>81</b>	<b>Tap Wt</b>	<b>248,738</b>			

ADDITIONS	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	WizRSg 01	Total
Al				602	833		1,435
Dolo			2,153			2,396	4,549
FeCrSi				1,000			1,000
FeSi				295	1,321		1,616
HCFeCr		13,393					13,393
Lime	5,000					1,924	6,924
<b>Total</b>	<b>5,000</b>	<b>13,393</b>	<b>2,153</b>	<b>1,897</b>	<b>2,154</b>	<b>4,320</b>	<b>28,917</b>

Heat # 254838 Grade 409S1 Operator mhinz  
 Practice CRSS LCLN Slag ANY SS GRADE Heat Created 04/18/05 16:17  
 Lining ID Lining Minutes 247 Heats 128 Min. Weight 220,000  
 Addswiz Oxygen Estimate 71696 TapToCharge 3.083333

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.007				0.170	10.600			
Max	0.030	0.400		0.150	0.400	10.800			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	0.940	0.280	0.034	0.040	0.172	6.610	0.080	0.006	0.009
A1	0.041	0.230	0.029	0.030	0.009	9.450	0.110	0.005	0.002
A2	0.005	0.280	0.027	0.003	0.341	10.460	0.110	0.006	0.004

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
50.78	11.34	26.34	11.30	0.00	0.00	18,345.12

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
16:18	Charge					
16:18	Chem T1					
16:22	Sample		0.9402			6641
16:24	Temp	2829				
16:24	Addswiz					
16:25	Decarb					
16:55	Sample		0.0148	85624		83547
16:58	Temp	3028				
16:58	Decarb					
17:02	Chem A1					
17:16	Addswiz					
17:19	Reduce					
17:28	Sample		0.0070	96033		197680
17:32	Temp	3016				
17:37	Reduce					
17:39	Sample		0.0070	96033		203824
17:40	Tap					
Tap Heat	04/18/05 17:40		<b>TOTALS</b>	<b>96033</b>	<b>0</b>	<b>203914</b>
Charge Heat	04/18/05 16:18	Transfer Wt	244,000			
<b>Charge - Tap</b>	<b>82</b>	<b>Tap Wt</b>	<b>256,572</b>			

ADDITIONS	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	WizRSg 01	Total
Al				668	802		1,470
Dolo			2,881			2,047	4,928
FeCrSi				1,000			1,000
FeSi				626	1,304		1,930
HCFeCr		15,180					15,180
Lime	5,000					2,480	7,480
<b>Total</b>	<b>5,000</b>	<b>15,180</b>	<b>2,881</b>	<b>2,294</b>	<b>2,106</b>	<b>4,527</b>	<b>31,988</b>

Heat # 254839      Grade 409S1      Operator mhinz  
 Practice CRSS LCLN      Slag ANY SS GRADE      Heat Created 04/18/05 17:43  
 Lining ID      Lining Minutes 329      Heats 129      Min. Weight 220,000

AddsWiz Oxygen Estimate 67253      TapToCharge 3.145833

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.007				0.170	10.600			
Max	0.030	0.400		0.150	0.400	10.800			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	1.024	0.270	0.033	0.044	0.204	7.660	0.110	0.006	0.010
A1	0.029	0.220	0.028	0.040	0.009	9.900	0.130	0.005	0.002
A2	0.009	0.270	0.027	0.002	0.397	10.630	0.120	0.007	0.004

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
51.51	12.11	24.95	11.16	0.00	0.00	17,856.01

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
17:43	Charge					
17:43	Chem T1					
17:48	Sample		1.0241			8502
17:49	Temp	2782				
17:49	AddsWiz					
17:50	Decarb					
18:18	Sample		0.0197	80276		79520
18:20	Temp	3032				
18:21	Decarb					
18:25	Chem A1					
18:27	Chem A1					
18:39	AddsWiz					
18:44	Reduce					
18:51	Sample		0.0060	90204		194349
18:54	Temp	3000				
19:00	Reduce					
19:02	Sample		0.0060	90204		200036
19:02	Tap					

Tap Heat	04/18/05 19:02		<b>TOTALS</b>	<b>90204</b>	<b>0</b>	<b>200151</b>
Charge Heat	04/18/05 17:43	Transfer Wt	238,000			
<b>Charge - Tap</b>	<b>80</b>	<b>Tap Wt</b>	<b>246,717</b>			

<b>ADDITIONS</b>	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	WizRSg 01	<b>Total</b>
Al				766	735		<b>1,501</b>
Dolo			2,979			2,227	<b>5,206</b>
FeCrSi				1,000			<b>1,000</b>
FeSi				358	1,227		<b>1,585</b>
HCFeCr		10,582					<b>10,582</b>
LCCr				400			<b>400</b>
Lime	5,000					1,955	<b>6,955</b>
<b>Total</b>	<b>5,000</b>	<b>10,582</b>	<b>2,979</b>	<b>2,524</b>	<b>1,962</b>	<b>4,182</b>	<b>27,229</b>

Heat # 254840      Grade 409S1      Operator mhinz  
 Practice CRSS LCLN      Slag ANY SS GRADE      Heat Created 04/18/05 19:04  
 Lining ID      Lining Minutes 408      Heats 130      Min. Weight 220,000  
 Addswiz Oxygen Estimate 53017      TapToCharge 2.920833

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.007				0.170	10.600			
Max	0.030	0.400		0.150	0.400	10.800			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	1.064	0.310	0.038	0.045	0.145	9.720	0.120	0.006	0.008
A1	0.070	0.280	0.030	0.033	0.009	10.300	0.130	0.004	0.003
A2	0.007	0.310	0.031	0.002	0.329	10.970	0.130	0.006	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
50.13	12.46	24.25	12.84	0.00	0.00	13,520.38

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
19:05	Chem T1					
19:05	Charge					
19:09	Sample		1.0644			5942
19:12	Temp	2844				
19:12	Addswiz					
19:12	Decarb					
19:38	Sample		0.0197	59151		77620
19:39	Temp	3003				
19:40	Decarb					
19:46	Chem A1					
20:03	Addswiz					
20:06	Reduce					
20:11	Sample		0.0044	72294		197409
20:14	Temp	3025				
20:21	Reduce					
20:22	Sample		0.0044	72294		202532
20:23	Tap					
Tap Heat	04/18/05 20:23		<b>TOTALS</b>	<b>72294</b>	<b>0</b>	<b>202625</b>
Charge Heat	04/18/05 19:05	Transfer Wt	234,000			
<b>Charge - Tap</b>	<b>78</b>	<b>Tap Wt</b>	<b>234,913</b>			

ADDITIONS	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	WizRSg 01	Total
Al				665	582		1,247
Dolo			2,620			1,374	3,994
FeCrSi				1,000			1,000
FeSi				127	1,071		1,198
HCFerCr		2,379					2,379
LCCr				400			400
Lime	5,000					392	5,392
<b>Total</b>	<b>5,000</b>	<b>2,379</b>	<b>2,620</b>	<b>2,192</b>	<b>1,653</b>	<b>1,766</b>	<b>15,610</b>



Heat # 254841      Grade 409S1      Operator mhinz  
 Practice CRSS LCLN      Slag ANY SS GRADE      Heat Created 04/18/05 20:25  
 Lining ID      Lining Minutes 486      Heats 131      Min. Weight 220,000  
 Addswiz Oxygen Estimate 62164      TapToCharge 2.404167

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.007				0.170	10.600			
Max	0.030	0.400		0.150	0.400	10.800			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	1.083	0.270	0.037	0.042	0.241	8.710	0.140	0.007	0.014
A1	0.040	0.240	0.032	0.031	0.008	10.130	0.140	0.005	0.002
A2	0.009	0.260	0.030	0.002	0.344	10.840	0.140	0.007	0.004

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
50.83	12.22	25.02	11.50	0.00	0.00	14,522.42

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
20:25	Charge					
20:26	Chem T1					
20:30	Sample		1.0833			7746
20:31	Temp	2820				
20:31	Addswiz					
20:32	Decarb					
21:00	Sample		0.0197	68656		83866
21:02	Temp	3015				
21:03	Decarb					
21:09	Chem A1					
21:20	Addswiz					
21:24	Reduce					
21:29	Sample		0.0047	79624		184424
21:34	Temp	3029				
21:40	Reduce					
21:41	Sample		0.0047	79624		189856
21:42	Tap					
Tap Heat	04/18/05 21:42		<b>TOTALS</b>	<b>79624</b>	<b>0</b>	<b>189950</b>
Charge Heat	04/18/05 20:25	Transfer Wt	234,000			
<b>Charge - Tap</b>	<b>77</b>	<b>Tap Wt</b>	<b>238,026</b>			

ADDITIONS	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	WizRSg 01	Total
Al				744	476		1,220
Dolo			2,880			1,345	4,225
FeCrSi				1,000			1,000
FeSi				135	969		1,104
HCFeCr		6,261					6,261
LCCr				400			400
Lime	5,000					690	5,690
<b>Total</b>	<b>5,000</b>	<b>6,261</b>	<b>2,880</b>	<b>2,279</b>	<b>1,445</b>	<b>2,035</b>	<b>19,900</b>

Heat # 254849      Grade 409S1      Operator bfay  
 Practice CR SS LCLN      Slag ANY SS GRADE      Heat Created 04/19/05 08:22  
 Lining ID      Lining Minutes 1011      Heats 139      Min. Weight 220,000  
 Addswiz Oxygen Estimate 65775      TapToCharge 3.016667

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.007				0.170	10.600			
Max	0.030	0.400		0.150	0.400	10.800			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	0.883	0.270	0.027	0.042	0.218	7.390	0.120	0.010	0.009
A1	0.012	0.180	0.023	0.039	0.008	9.150	0.140	0.004	0.002
A2	0.008	0.290	0.023	0.007	0.289	10.590	0.130	0.005	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
52.07	12.02	26.81	8.83	0.01	0.00	17,345.66

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
8:23	Chem T1					
8:23	Charge					
8:29	Sample		0.8826			10675
8:30	Temp	2732				
8:30	Addswiz					
8:31	Decarb					
8:53	Addswiz					
8:57	Sample		0.0246	82689		70953
8:59	Temp	3096				
9:00	Decarb					
9:04	Chem A1					
9:04	Reduce					
9:04	Addswiz					
9:13	Sample		0.0076	84943		121865
9:17	Temp	3061				
9:24	Tap					
Tap Heat	04/19/05 9:24		<b>TOTALS</b>	<b>84943</b>	<b>0</b>	<b>121964</b>
Charge Heat	04/19/05 8:23	Transfer Wt	240,000			
Charge - Tap	61	Tap Wt	249,452			

ADDITIONS	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	WizRSg 01	Total
Al				786	547		1,333
Dolo			3,128			1,835	4,963
FeCrSi				1,000			1,000
FeSi				488	1,051		1,539
HCFeCr		11,810					11,810
Lime	5,000					1,642	6,642
<b>Total</b>	<b>5,000</b>	<b>11,810</b>	<b>3,128</b>	<b>2,274</b>	<b>1,598</b>	<b>3,477</b>	<b>27,287</b>

<b>ADDITIONS</b>	Recipe1	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	WizRSg 01	<b>Total</b>
Al					739	401		<b>1,140</b>
Dolo				2,921			1,183	<b>4,104</b>
FeCrSi					1,000			<b>1,000</b>
FeSi					416	902		<b>1,318</b>
HCFeCr			9,549					<b>9,549</b>
LC FeSi	250							<b>250</b>
LCCr					400			<b>400</b>
Lime		5,000					533	<b>5,533</b>
<b>Total</b>	<b>250</b>	<b>5,000</b>	<b>9,549</b>	<b>2,921</b>	<b>2,555</b>	<b>1,303</b>	<b>1,716</b>	<b>23,294</b>

Heat # 254850      Grade 409S1      Operator bfay  
 Practice CR SS LCLN      Slag ANY SS GRADE      Heat Created 04/19/05 09:26  
 Lining ID      Lining Minutes 1072      Heats 140      Min. Weight 220,000  
 Addswiz Oxygen Estimate 47734      TapToCharge 2.454167

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.007				0.170	10.600			
Max	0.030	0.400		0.150	0.400	10.800			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	0.758	0.300	0.030	0.041	0.091	8.560	0.100	0.005	0.005
A1	0.022	0.270	0.026	0.024	0.010	9.480	0.110	0.004	0.002
A2	0.005	0.310	0.027	0.005	0.269	10.710	0.110	0.005	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
51.56	12.06	23.31	12.86	0.00	0.00	13,797.00

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
9:26	Charge					
9:26	Chem T1					
9:30	Sample		0.7585			7544
9:32	Temp	2884				
9:32	Addswiz					
9:32	Decarb					
9:58	Sample		0.0148	63152		78914
10:00	Temp	3069				
10:01	Decarb					
10:05	Chem A1					
10:14	Addswiz					
10:16	Reduce					
10:22	Sample		0.0041	68449		159431
10:27	Temp	3074				
10:30	Reduce					
10:32	Sample		0.0041	68449		164560
10:33	Tap					

Tap Heat	04/19/05 10:33		<b>TOTALS</b>	<b>68449</b>	<b>0</b>	<b>164672</b>
Charge Heat	04/19/05 9:26	Transfer Wt	248,000			
<b>Charge - Tap</b>	<b>66</b>	<b>Tap Wt</b>	<b>254,352</b>			

ADDITIONS	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	WizRSg 01	Total
Al				634	635		1,269
Dolo			2,503			1,470	3,973
FeCrSi				1,000			1,000
FeSi				170	1,153		1,323
HCFeCr		7,502					7,502
LCCr				400			400
Lime	5,000					364	5,364
<b>Total</b>	<b>5,000</b>	<b>7,502</b>	<b>2,503</b>	<b>2,204</b>	<b>1,788</b>	<b>1,834</b>	<b>20,831</b>

Heat # 254851      Grade 409S1      Operator ~~bfay~~ *W Hinz*  
 Practice CR SS LCLN      Slag ANY SS GRADE      Heat Created 04/19/05 11:19  
 Lining ID      Lining Minutes 1138      Heats 141      Min. Weight 220,000  
 AddsWiz Oxygen Estimate 53526      TapToCharge 47.2125

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.007				0.170	10.600			
Max	0.030	0.400		0.150	0.400	10.800			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	0.809	0.260	0.025	0.037	0.175	8.610	0.110	0.006	0.008
A1	0.008	0.160	0.023	0.038	0.009	9.380	0.120	0.004	0.002
A2	0.006	0.280	0.022	0.003	0.256	10.770	0.120	0.006	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
51.64	12.10	24.18	11.83	0.00	0.00	16,208.39

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
11:20	Charge					
11:20	Chem T1					
11:26	Sample		0.8091		341	11209
11:28	Temp	2776				
11:28	Decarb					
11:29	AddsWiz					
11:57	Sample		0.0148	71568	341	89136
12:00	Temp	3063				
12:00	Decarb					
12:06	Chem A1					
12:07	AddsWiz					
12:11	Reduce					
12:17	Sample		0.0049	74583	341	152087
12:23	Temp	3017				
12:31	Reduce					
12:32	Sample		0.0049	74583	341	157258
12:33	Tap					
Tap Heat	04/19/05 12:33		<b>TOTALS</b>	<b>74583</b>	<b>341</b>	<b>157368</b>
Charge Heat	04/19/05 11:20	Transfer Wt	244,000			
<b>Charge - Tap</b>	<b>73</b>	<b>Tap Wt</b>	<b>249,633</b>			

ADDITIONS	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	WizRSg 01	Total
Al				716	645		1,361
Dolo			2,834			1,827	4,661
FeCrSi				1,000			1,000
FeSi				283	1,154		1,437
HCFeCr		7,114					7,114
LCCr				400			400
Lime	5,000					1,252	6,252
<b>Total</b>	<b>5,000</b>	<b>7,114</b>	<b>2,834</b>	<b>2,399</b>	<b>1,799</b>	<b>3,079</b>	<b>22,225</b>

Heat # 254852      Grade 409S1      Operator mhinz  
 Practice CR SS LCLN      Slag ANY SS GRADE      Heat Created 04/19/05 12:49  
 Lining ID      Lining Minutes 1211      Heats 142      Min. Weight 220,000  
 Addswiz Oxygen Estimate 60551      TapToCharge 20.83317

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.007				0.170	10.600			
Max	0.030	0.400		0.150	0.400	10.800			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	0.854	0.260	0.029	0.042	0.204	7.810	0.120	0.005	0.007
A1	0.008	0.190	0.024	0.038	0.009	8.910	0.140	0.004	0.002
A2	0.008	0.330	0.023	0.012	0.071	11.290	0.130	0.005	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
51.84	12.02	25.64	10.30	0.00	0.00	17,819.13

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
12:54	Charge					
12:57	Chem T1					
12:58	Sample		0.8542			8094
13:00	Temp	2706				
13:00	Decarb					
13:01	Addswiz					
13:29	Sample		0.0148	77812		84429
13:31	Temp	3066				
13:32	Decarb					
13:38	Chem A1					
13:39	Addswiz					
13:42	Reduce					
13:51	Sample		0.0058	80878		155322
13:55	Temp	3011				
14:04	Sample		0.0059	80878		164342
14:05	Tap					
Tap Heat	04/19/05 14:05		<b>TOTALS</b>	<b>80878</b>	<b>0</b>	<b>164460</b>
Charge Heat	04/19/05 12:54	Transfer Wt	229,000			
<b>Charge - Tap</b>	<b>71</b>	<b>Tap Wt</b>	<b>237,326</b>			

ADDITIONS	Recipe1	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	WizRSg 01	Total
Al					801	617		1,418
Dolo				3,128			2,007	5,135
FeCrSi					1,000			1,000
FeSi	500				535	1,094		2,129
HCFeCr			9,661					9,661
LCCr					400			400
Lime		5,000					1,864	6,864
<b>Total</b>	<b>500</b>	<b>5,000</b>	<b>9,661</b>	<b>3,128</b>	<b>2,736</b>	<b>1,711</b>	<b>3,871</b>	<b>26,607</b>

Heat # 254853      Grade 409S1      Operator mhinz  
 Practice CR SS LCLN      Slag ANY SS GRADE      Heat Created 04/19/05 14:07  
 Lining ID      Lining Minutes 1282      Heats 143      Min. Weight 220,000  
 AddsWiz Oxygen Estimate 48425      TapToCharge 3.083333

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.007				0.170	10.600			
Max	0.030	0.400		0.150	0.400	10.800			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	0.858	0.280	0.028	0.039	0.150	9.280	0.100	0.005	0.012
A1	0.063	0.260	0.024	0.021	0.009	9.840	0.120	0.005	0.002
A2	0.007	0.310	0.023	0.003	0.282	10.940	0.110	0.004	0.004

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
50.12	12.34	23.04	14.16	0.00	0.00	16,271.80

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
14:08	Charge					
14:09	Chem T1					
14:13	Sample		0.8583			10383
14:17	Temp	2845				
14:18	Decarb					
14:18	AddsWiz					
14:44	Sample		0.0148	60116		86917
14:46	Temp	3015				
14:47	Decarb					
14:53	Chem A1					
15:07	AddsWiz					
15:12	Reduce					
15:19	Sample		0.0054	73326		207844
15:24	Temp	3050				
15:29	Reduce					
15:33	Sample		0.0059	73326		220676
15:43	Tap					

Tap Heat	04/19/05 15:43		<b>TOTALS</b>	<b>73326</b>	<b>0</b>	<b>220781</b>
Charge Heat	04/19/05 14:08	Transfer Wt	238,000			
<b>Charge - Tap</b>	<b>95</b>	<b>Tap Wt</b>	<b>244,277</b>			

ADDITIONS	Recipe1	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	WizRSg .01	Total
1006	3,500							3,500
Al					667	844		1,511
Dolo				2,643			2,184	4,827
FeCrSi					1,000			1,000
FeSi					141	1,332		1,473
HCFeCr			4,256					4,256
LCCr					300			300
Lime		5,000					1,466	6,466
<b>Total</b>	<b>3,500</b>	<b>5,000</b>	<b>4,256</b>	<b>2,643</b>	<b>2,108</b>	<b>2,176</b>	<b>3,650</b>	<b>23,333</b>



Heat # 254854      Grade 409S1      Operator mhinz  
 Practice CR SS LCLN      Slag ANY SS GRADE      Heat Created 04/19/05 15:45  
 Lining ID      Lining Minutes 1377      Heats 144      Min. Weight 220,000  
 Addswiz Oxygen Estimate 65414      TapToCharge 3.012667

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.007				0.170	10.600			
Max	0.030	0.400		0.150	0.400	10.800			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
F1	0.955	0.290	0.025	0.038	0.387	7.950	0.150	0.006	0.013
A1	0.020	0.210	0.022	0.031	0.009	9.290	0.160	0.004	0.002
A2	0.007	0.290	0.021	0.002	0.323	10.640	0.160	0.004	0.004

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
51.47	12.05	24.86	11.31	0.00	0.00	18,591.38

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
15:46	Charge					
15:46	Chem F1					
15:49	Sample		0.9549			6522
15:51	Sample		0.9549			6614
15:53	Temp	2653				
15:54	Addswiz					
15:54	Decarb					
16:23	Sample		0.0197	81380		79482
16:25	Temp	3052				
16:26	Decarb					
16:29	Chem A1					
16:37	Addswiz					
16:41	Reduce					
16:49	Sample		0.0073	85803		166021
16:52	Temp	2994				
16:57	Reduce					
16:59	Sample		0.0073	85803		170499
17:00	Tap					

Tap Heat	04/19/05 17:00		<b>TOTALS</b>	<b>85803</b>	<b>0</b>	<b>170602</b>
Charge Heat	04/19/05 15:46	Transfer Wt	230,000			
<b>Charge - Tap</b>	<b>74</b>	<b>Tap Wt</b>	<b>236,626</b>			

<b>ADDITIONS</b>	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	WizRSg 01	<b>Total</b>
Al				821	614		<b>1,435</b>
Dolo			3,249			2,119	<b>5,368</b>
FeCrSi				1,000			<b>1,000</b>
FeSi				131	1,093		<b>1,224</b>
HCFeCr		9,038					<b>9,038</b>
LCCr				300			<b>300</b>
Lime	5,000					2,163	<b>7,163</b>
<b>Total</b>	<b>5,000</b>	<b>9,038</b>	<b>3,249</b>	<b>2,252</b>	<b>1,707</b>	<b>4,282</b>	<b>25,528</b>

Heat # 254855      Grade 409S1      Operator mhinz  
 Practice CR SS LCLN      Slag ANY SS GRADE      Heat Created 04/19/05 17:02  
 Lining ID      Lining Minutes 1451      Heats 145      Min. Weight 220,000  
 Addswiz Oxygen Estimate 72237      TapToCharge 2.2875

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.007				0.170	10.600			
Max	0.030	0.400		0.150	0.400	10.800			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	0.918	0.290	0.028	0.040	0.333	6.940	0.110	0.006	0.012
A1	0.013	0.170	0.024	0.039	0.010	9.370	0.130	0.005	0.002
A2	0.006	0.290	0.023	0.004	0.341	10.460	0.120	0.007	0.004

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
51.37	12.10	25.92	10.31	0.00	0.00	18,530.94

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
17:03	Chem T1					
17:07	Sample		0.9178			8061
17:08	Temp	2678				
17:08	Addswiz					
17:09	Decarb					
17:39	Sample		0.0197	87393		83301
17:41	Temp	3035				
17:42	Decarb					
17:45	Chem A1					
17:50	Addswiz					
17:54	Reduce					
18:02	Sample		0.0071	91004		158794
18:05	Temp	2990				
18:10	Reduce					
18:12	Sample		0.0071	91004		164053
18:12	Tap					
Tap Heat	04/19/05 18:12		<b>TOTALS</b>	<b>91004</b>	<b>0</b>	<b>164145</b>

Charge Heat		Transfer Wt	0
<b>Charge - Tap 1</b>		<b>Tap Wt</b>	<b>248,755</b>

ADDITIONS	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	WizRSg 01	Total
Al			862	517		1,379
Dolo		3,368			1,999	5,367
FeCrSi			1,000			1,000
FeSi			410	1,018		1,428
HCFeCr	13,422					13,422
LCCr			300			300
Lime					2,163	2,163
<b>Total</b>	<b>13,422</b>	<b>3,368</b>	<b>2,572</b>	<b>1,535</b>	<b>4,162</b>	<b>25,059</b>

Heat # 254856

Grade 1005S1

Operator mhinz

Practice Castrip

Slag LCLNCarbon

Heat Created 04/19/05 18:40

Lining ID

Lining Minutes 1521

Heats 146 Min. Weight 220,000

AddsWiz Oxygen Estimate

TapToCharge 28.775

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.010	0.500			0.250				
Max	0.040	0.600			0.350				
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
F1	0.044	0.080	0.011	0.024	0.001	0.480	0.032	0.008	0.002
A1	0.006	0.560	0.012		0.389	0.519	0.033	0.005	0.005

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
58.40	8.94	15.22	16.95	0.00	0.00	5,868.98

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
18:41	Charge					
18:42	Chem F1					
18:42	Chem F1					
18:46	Sample		0.0440			9208
18:51	Decarb					
18:55	Reduce					
19:01	Sample		0.0344	7690		34687
19:04	Temp	2958				
19:12	Chem A1					
19:13	Fuel %Si					
19:16	Reduce					
19:18	Sample		0.0060	11290		49616
19:19	Tap					

Tap Heat	04/19/05 19:19		<b>TOTALS</b>	<b>11290</b>	<b>0</b>	<b>49723</b>
Charge Heat	04/19/05 18:41	Transfer Wt	244,000			
<b>Charge - Tap</b>	<b>38</b>	<b>Tap Wt</b>	<b>245,730</b>			

ADDITIONS	Castrip	Total
Al	1,200	1,200
Dolo	1,200	1,200
FeSi	575	575
LC SiMn	1,900	1,900
Lime	3,000	3,000
<b>Total</b>	<b>7,875</b>	<b>7,875</b>

*CASTREP*

Heat # 254857 Grade 1005P1 Operator mhinz  
 Practice LCLNCarbon Slag LCLNCarbon Heat Created 04/19/05 19:22  
 Lining ID Lining Minutes 1559 Heats 147 Min. Weight 220,000

AddsWiz Oxygen Estimate

TapToCharge 3.721

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.005				0.200				
Max	0.030				0.250				
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
F1	0.060	0.080	0.008	0.022		0.193	0.025	0.006	0.002
A1	0.002	0.050	0.001	0.019		0.206	0.025	0.006	0.001

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
70.44	10.40	7.06	3.78	8.19	0.00	6,354.10

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
19:22	Charge					
19:27	Sample					8931
19:29	Chem F1					
19:33	Decarb					
19:37	Reduce					
19:40	Sample		0.0418	6179		29157
19:42	Temp	2913				
19:51	Reduce					
19:54	Sample		0.0417	6179		38200
19:54	Tap					

Tap Heat	04/19/05 19:54		<b>TOTALS</b>	<b>6179</b>	<b>0</b>	<b>38310</b>
Charge Heat	04/19/05 19:22	Transfer Wt	244,000			
<b>Charge - Tap</b>	<b>32</b>	<b>Tap Wt</b>	<b>243,814</b>			

ADDITIONS	Recipe1	Recipe2	Total
Al		200	200
Dolo	1,500		1,500
FeSi		200	200
Lime	4,000		4,000
<b>Total</b>	<b>5,500</b>	<b>400</b>	<b>5,900</b>

Wash Heat

Heat # 254858      Grade 1005P1      Operator mhinz  
 Practice LCLNCarbon      Slag LCLNCarbon      Heat Created 04/19/05 19:59  
 Lining ID      Lining Minutes 1591      Heats 148      Min. Weight 220,000

AddsWiz Oxygen Estimate

TapToCharge 4.729

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.005				0.200				
Max	0.030				0.250				
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
F1	0.054	0.100	0.010	0.020		0.152	0.025	0.006	0.001
A1	0.011	0.090	0.010	0.017		0.175	0.026	0.006	0.001

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
83.00	11.55	2.17	3.19	0.00	0.00	4,648.45

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
19:59	Charge					
20:01	Chem F1					
20:03	Chem F1					
20:04	Sample		0.0540			8798
20:09	Decarb					
20:11	Reduce					
20:13	Sample		0.0534	842		23710
20:16	Temp	2936				
20:21	Reduce					
20:25	Sample		0.0534	842		34008
20:26	Tap					

Tap Heat	04/19/05 20:26		<b>TOTALS</b>	<b>842</b>	<b>0</b>	<b>34141</b>
Charge Heat	04/19/05 19:59	Transfer Wt	245,000			
<b>Charge - Tap</b>	<b>27</b>	<b>Tap Wt</b>	<b>245,755</b>			

ADDITIONS	Recipe1	Recipe2	Total
Al		300	300
Dolo	1,200		1,200
FeSi		250	250
Lime	3,500		3,500
<b>Total</b>	<b>4,700</b>	<b>550</b>	<b>5,250</b>

Heat # 254859      Grade 1005S1      Operator mhinz  
 Practice ~~Casrip~~      Slag LCLNCarbon      Heat Created 04/19/05 22:08  
 Lining ID      Lining Minutes 1618      Heats 150      Min. Weight 220,000

AddsWiz Oxygen Estimate

TapToCharge 101.9833

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.010	0.500			0.250				
Max	0.040	0.600			0.350				
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
F1	0.087	0.080	0.006	0.020	0.003	0.072	0.023	0.005	0.002
A1	0.002	0.060	0.005	0.018		0.084	0.023	0.006	0.001
A2	0.001	0.080	0.008		0.087	0.091	0.022	0.006	0.002

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
65.84	8.88	1.72	23.36	0.00	0.00	4,108.09

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
22:08	Charge					
22:09	Chem F1					
22:13	Decarb					
22:14	Sample		0.0870	514		12623
22:16	Decarb					
22:18	Reduce					
22:25	Sample		0.0890	5321		35894
22:28	Temp	2896				
22:37	Reduce					
22:40	Sample		0.0902	5321		47157
22:46	Temp	2869				
23:07	Tap					
Tap Heat	04/19/05 23:07		<b>TOTALS</b>	<b>5321</b>	<b>0</b>	<b>47252</b>
Charge Heat	04/19/05 22:08	Transfer Wt	246,000			
<b>Charge - Tap</b>	<b>59</b>	<b>Tap Wt</b>	<b>246,671</b>			

ADDITIONS	Casrip	Recipe1	Total
Al		200	200
Dolo	900		900
FeSi	200	200	400
LC SiMn			
Lime	1,500	900	2,400
<b>Total</b>	<b>2,600</b>	<b>1,300</b>	<b>3,900</b>

Heat # 254908      Grade 1001S5      Operator bfay  
 Practice New Motor Lam      Slag LCLNCarbon      Heat Created 04/22/05 07:43  
 Lining ID      Lining Minutes 1686      Heats 154      Min. Weight 220,000

AddsWiz Oxygen Estimate

TapToCharge 92.51266

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.003				0.650				
Max	0.005			0.006	0.700				
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
F1	0.030	0.060	0.010	0.033		0.038	0.028	0.009	0.002
A1	0.003	0.380	0.009	0.010	1.150	0.058	0.028	0.013	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
54.88	11.86	31.15	2.00	0.00	0.00	7,234.59

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
7:47	Chem F1					
8:16	Charge					
8:20	Sample		0.0300			7134
8:24	Temp	2850				
8:25	Decarb					
8:34	Reduce					
8:35	Reduce					
8:40	Sample		0.0050	15584		45096
8:43	Temp	2995				
8:46	AddsWiz					
8:51	Chem A1					
8:53	Reduce					
8:56	Sample		0.0031	15584		55481
8:57	Tap					
Tap Heat	04/22/05 8:57		<b>TOTALS</b>	<b>15584</b>	<b>0</b>	<b>55583</b>
Charge Heat	04/22/05 8:16	Transfer Wt	250,000			
<b>Charge - Tap</b>	<b>41</b>	<b>Tap Wt</b>	<b>255,810</b>			

ADDITIONS

	Recipe1	Recipe3	Recipe4	Total
Dolo 1200	800			800 2000
LC FeSi 5,000		500	100	600 5600
LC SiMn 1250		300		300 1550
Lime 2800	200			200 3000
<b>Total</b>	<b>1,000</b>	<b>800</b>	<b>100</b>	<b>1,900</b>



Heat # 254910      Grade 1001S5      Operator jday  
 Practice New Motor Lam      Slag LCLNCarbon      Heat Created 04/22/05 09:21  
 Lining ID      Lining Minutes 1727      Heats 155      Min. Weight 220,000

AddsWiz Oxygen Estimate

TapToCharge 35.4335

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.003				0.650				
Max	0.005			0.006	0.700				
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
F1	0.027	0.060	0.008	0.026		0.039	0.029	0.009	0.002
A1	0.003	0.450	0.010	0.004	1.321	0.055	0.030	0.009	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
54.55	11.97	30.85	2.51	0.00	0.00	7,123.27

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
9:30	Chem F1					
9:33	Charge					
9:36	Sample		0.0270			6024
9:38	Temp	2922				
9:39	Decarb					
9:48	Reduce					
9:53	Sample		0.0048	15317		42041
9:59	Temp	3060				
10:00	AddsWiz					
10:05	Reduce					
10:06	Chem A1					
10:08	Sample		0.0030	15317		51252
10:09	Tap					
Tap Heat	04/22/05 10:09		<b>TOTALS</b>	<b>15317</b>	<b>0</b>	<b>51364</b>
Charge Heat	04/22/05 9:33	Transfer Wt	248,597			
<b>Charge - Tap</b>	<b>36</b>	<b>Tap Wt</b>	<b>254,186</b>			

ADDITIONS

	Motor Lam	Recipe2	Total
Al	700		700
Dolo	2,000		2,000
FeSi	5,000	150	5,150
LC SiMn	1,450		1,450
Lime	3,000		3,000
<b>Total</b>	<b>12,150</b>	<b>150</b>	<b>12,300</b>

Heat # 254911      Grade 1001S5      Operator jday  
 Practice New Motor Lam      Slag LCLNCarbon      Heat Created 04/22/05 10:16  
 Lining ID      Lining Minutes 1763      Heats 156      Min. Weight 220,000  
 Addswiz Oxygen Estimate 12060      TapToCharge 18.179

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.003				0.650				
Max	0.005			0.006	0.700				
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
F1	0.023	0.050	0.007	0.023		0.035	0.036	0.008	0.003
A1	0.002	0.440	0.010	0.003	1.306	0.049	0.035	0.006	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
53.56	10.74	33.52	2.01	0.00	0.00	7,020.69

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
10:25	Chem F1					
10:27	Charge					
10:30	Sample		0.0230			5858
10:32	Temp	2880				
10:32	Addswiz					
10:33	Decarb					
10:34	Addswiz					
10:43	Reduce					
10:47	Addswiz					
10:50	Sample		0.0039	16066		49279
10:56	Temp	3043				
10:59	Reduce					
11:01	Sample		0.0040	16066		55415
11:05	Tap					

Tap Heat	04/22/05 11:05		<b>TOTALS</b>	<b>16066</b>	<b>0</b>	<b>55521</b>
Charge Heat	04/22/05 10:27	Transfer Wt	249,999			
<b>Charge - Tap</b>	<b>38</b>	<b>Tap Wt</b>	<b>255,681</b>			

ADDITIONS	Motor Lam	Recipe1	Recipe2	Total
Al	700			700
Dolo		1,800		1,800
FeSi	5,000		150	5,150
LC SiMn	1,450			1,450
Lime		3,000		3,000
<b>Total</b>	<b>7,150</b>	<b>4,800</b>	<b>150</b>	<b>12,100</b>

Heat # 254912      Grade 1001S5      Operator jnichols  
 Practice New Motor Lam      Slag LCLNCarbon      Heat Created 04/22/05 11:16  
 Lining ID      Lining Minutes 1801      Heats 157      Min. Weight 220,000

AddsWiz Oxygen Estimate

TapToCharge 12.69167

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.003				0.650				
Max	0.005			0.006	0.700				
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	0.033	0.040	0.006	0.025		0.024	0.029	0.007	0.002
T1	0.033	0.040	0.006	0.025		0.024	0.029	0.007	0.002
A1	0.001	0.420	0.008	0.005	1.272	0.036	0.030	0.007	0.003
A1	0.001	0.420	0.008	0.005	1.272	0.036	0.030	0.007	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
53.94	10.55	33.80	1.59	0.00	0.00	6,881.82

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
11:17	Charge					
11:18	Chem T1					
11:21	Sample		0.0330			6604
11:24	Temp	2849				
11:26	Decarb					
11:26	AddsWiz					
11:35	Reduce					
11:41	Sample		0.0048	16085		42832
11:54	Chem A1					
11:58	Reduce					
12:00	Sample		0.0010	16085		49496
12:02	Tap					
12:07	Temp	2967				
Tap Heat	04/22/05 12:02		<b>TOTALS</b>	<b>16085</b>	<b>0</b>	<b>50171</b>
Charge Heat	04/22/05 11:17	Transfer Wt	252,000			
<b>Charge - Tap</b>	<b>45</b>	<b>Tap Wt</b>	<b>257,592</b>			

ADDITIONS	Recipe1	Recipe2	Recipe4	Total
Dolo	1,800			1,800
Empty		700		700
FeSi		5,000		5,000
LC FeSi			250	250
LC SiMn		1,450		1,450
Lime	3,000			3,000
<b>Total</b>	<b>4,800</b>	<b>7,150</b>	<b>250</b>	<b>12,200</b>

Heat # 254913      Grade 1001S5      Operator jnichols  
 Practice New Motor Lam      Slag LCLNCarbon      Heat Created 04/22/05 12:09  
 Lining ID      Lining Minutes 1846      Heats 158      Min. Weight 220,000  
 Addswiz Oxygen Estimate 14309      TapToCharge 11.60833

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.003				0.650				
Max	0.005			0.006	0.700				
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	0.052	0.040	0.017	0.033		0.027	0.024	0.007	0.002
A1	0.001	0.420	0.018	0.002	1.360	0.035	0.025	0.007	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
54.32	10.65	33.37	1.54	0.00	0.00	6,857.51

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
12:14	Charge					
12:15	Chem T1					
12:20	Sample		0.0520			11600
12:24	Temp	2780				
12:25	Decarb					
12:26	Addswiz					
12:27	Addswiz					
12:34	Reduce					
12:39	Sample		0.0064	16520		46250
12:50	Tap					
12:54	Temp	2945				

Tap Heat 04/22/05 12:50      **TOTALS**      16520      0      47123  
 Charge Heat 04/22/05 12:14      Transfer Wt      252,000  
 Charge - Tap 35      Tap Wt      257,385

ADDITIONS	Recipe1	Recipe2	Total
Al		700	700
Dolo	1,800		1,800
FeSi	<del>3,000</del>	5,000	8,000
LC SiMn		1,450	1,450
<b>Total</b>	<b>4,800</b>	<b>7,150</b>	<b>11,950</b>

Lime 3000  
 Dolo 1800  
 FeS 5000  
 LES. KN 1450  
 AL 700  
 5,000  
~~8,250~~  
 254910 →

Heat # 254914      Grade 1001S5      Operator jnichols  
 Practice New Motor Lam      Slag LCLNCarbon      Heat Created 04/22/05 12:57  
 Lining ID      Lining Minutes 1846      Heats 159      Min. Weight 220,000

AddsWiz Oxygen Estimate 7867      TapToCharge 18.3

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.003				0.650				
Max	0.005			0.006	0.700				
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	0.037	0.040	0.014	0.033		0.025	0.027	0.007	0.002
A1	0.002	0.420	0.016	0.005	1.224	0.048	0.028	0.007	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
52.96	10.68	21.72	14.52	0.00	0.00	7,094.95

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
12:58	Chem T1					
13:08	Charge					
13:12	Sample		0.0370			7189
13:16	Temp	2848				
13:16	Decarb					
13:17	AddsWiz					
13:27	Reduce					
13:34	Sample		0.0051	16380		52201
13:41	Chem A1					
13:44	Reduce					
13:46	Sample		0.0021	16380		59202
13:49	Tap					
13:51	Temp	2976				

Tap Heat	04/22/05 13:49		<b>TOTALS</b>	<b>16380</b>	<b>0</b>	<b>59382</b>
Charge Heat	04/22/05 13:08	Transfer Wt	254,000			
<b>Charge - Tap</b>	<b>41</b>	<b>Tap Wt</b>	<b>259,748</b>			

ADDITIONS	Recipe1	Recipe2	Recipe3	Total
Al		700		700
Dolo	1,800			1,800
FeSi		5,000	450	5,450
LC SiMn		1,450		1,450
Lime	3,000			3,000
<b>Total</b>	<b>4,800</b>	<b>7,150</b>	<b>450</b>	<b>12,400</b>

Heat # 254915      Grade 1001S5      Operator jnichols  
 Practice New Motor Lam      Slag LCLNCarbon      Heat Created 04/22/05 13:53  
 Lining ID      Lining Minutes 1887      Heats 160      Min. Weight 220,000  
 Addswiz Oxygen Estimate      TapToCharge 4.741667

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.003				0.650				
Max	0.005			0.006	0.700				
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
F1	0.030	0.040	0.017	0.028		0.029	0.036	0.007	0.002
T1	0.030	0.050	0.016	0.028	0.007	0.029	0.036	0.007	0.004
A1	0.002	0.430	0.019	0.005	1.233	0.043	0.036	0.008	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
54.10	9.75	33.83	2.08	0.00	0.00	7,061.65

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
13:53	Chem T1					
13:54	Charge					
13:57	Sample		0.0300			5737
14:00	Temp	2882				
14:04	Decarb					
14:14	Reduce					
14:19	Sample		0.0046	16647		43048
14:30	Chem A1					
14:34	Reduce					
14:39	Sample		0.0021	16647		57292
14:44	Tap					
14:48	Temp	3005				
Tap Heat 04/22/05 14:44			<b>TOTALS</b>	<b>16647</b>	<b>0</b>	<b>57391</b>

Charge Heat 04/22/05 13:54	Transfer Wt	254,000
<b>Charge - Tap 50</b>	<b>Tap Wt</b>	<b>259,855</b>

ADDITIONS	Motor Lam	Recipe1	Total
Al	700		700
Dolo	1,600		1,600
FeSi	5,000	450	5,450
LC SiMn	1,450		1,450
Lime	3,200		3,200
<b>Total</b>	<b>11,950</b>	<b>450</b>	<b>12,400</b>

422  
15.2

**ATP** – Air Test Professionals, Inc.

1201 North Graham Avenue, Indianapolis, Indiana 46219

(317) 345-1720 FAX (317) 351-0411

---

**REPORT on  
PARTICULATE AND METALS TESTING**


Performed for:  
**Nucor Steel**  
*Crawfordsville, Indiana*  
**PPFF Baghouse**  
on May 19, 21, 2004

**RECEIVED**  
JUL 06 2004  
State of Indiana  
Department of Environmental Management  
Office of Air Quality

---

To the best of our knowledge, the data presented in this report is accurate and complete.

Respectfully Submitted by:

  
Carlos Brown, Project Manager

## TABLE OF CONTENTS

---

1.	<b>PROJECT OVERVIEW</b>	
	TEST SUMMARY, Table 1-1	1-1
	PROJECT OVERVIEW	1-2
2.	<b>RESULTS</b>	
	FILTERABLE AND CONDENSIBLE PM, Table 2-1	2-1
	METALS EMISSIONS, Table 2-2	2-2
	VISIBLE EMISSIONS, Table 2-3	2-3
3.	<b>DESCRIPTION OF INSTALLATION</b>	
	DESCRIPTION OF PROCESS	3-1
4.	<b>METHODOLOGY</b>	
	SUMMARY OF SAMPLING PROCEDURES	4-1
	DESCRIPTION OF REFERENCE METHODS	4-2
5.	<b>APPENDIX</b>	
	SAMPLE CALCULATIONS	A
	FIELD DATA PRINTOUTS	B
	FIELD DATA	C
	LABORATORY DATA	D
	CHAIN OF CUSTODY	E
	CALIBRATION DATA	F
	VISIBLE EMISSIONS DATA	G
	SUBMITTED PROTOCOL	H
	PRODUCTION DATA	I



**1-1 PROJECT OVERVIEW**

---

Air Test Professionals, Inc. was contracted by Nucor Steel to perform air emissions sampling of their Positive Pressure Fabric Filter (PPFF) Baghouse and Melt Shop, located in Crawfordsville, Indiana on May 19, 21, 2004. The objective of the testing was to determine compliance with 40CFR60, Subpart AAa for particulate matter emissions and to determine Metals emissions. Testing was also performed in accordance with paragraph 48 of the Consent Decree to establish operating baselines as required by NSPS at the Electric Arc Furnace. The following personnel were involved with the testing program:

ATP	Carlos Brown
ATP	Andrew Young
ATP	Terry Kauffman
Nucor	Mark Washer
Nucor	Rex Kelsey
IDEM	Jarrold Fisher

The testing program included flow and gas analysis (US EPA Methods 1-4), particulate (US EPA Method 5D), condensible particulate matter (US EPA Method 202), metals emissions (US EPA Method 29), and visible emissions (US EPA Method 9). Listed below is a summary of the results.

**Test Summary**

Table 1-1

<b>Pollutant</b>	<b>Location</b>	<b>Emissions Rate (Avg.) (lbs/hr)</b>	<b>Permitted Limits (lbs/hr)</b>
Lead	PPFF Baghouse	0.0126 (Pb)	0.134 (Pb)
Mercury		0.0198 (Hg)	0.023 (Hg)

<b>Pollutant</b>	<b>Location</b>	<b>PM (TSP) Filterable</b>	<b>PM/PM10 Filterable &amp; Condensable</b>
Particulate Matter	PPFF Baghouse	0.0010 (gr/dscf)	0.0032 (gr/dscf)

<b>Permitted PM Limits</b>	0.0018 (gr/dscf)	0.0052 (gr/dscf)
----------------------------	------------------	------------------

**1-2 PROJECT OVERVIEW**

**Test Program**  
Table 1-2

<b>Parameter</b>	<b>Methods</b>	<b>Location</b>	<b>Unit</b>
Gas Velocity / Vol. Flow Rate	EPA RM 1-3	Inlet	EAF Baghouse
Particulate	EPA RM 4-5D	Compartment	EAF Baghouse
PM10	EPA RM 202	Compartment	EAF Baghouse
Metals	EPA RM 29	Compartment	EAF Baghouse
Opacity	EPA RM 9	Roof Monitors	EAF Baghouse / Melt Shop
Opacity	EPA RM 9	Silo Exhausts	Old & New Bin Vents

The schedule of activities is summarized below:

**Schedule of Activities**


<b>Date</b>	<b>Run No.</b>	<b>Time</b>
PM & Metals Tests		
05/19/2004	1	15:57-21:29
05/21/2004	2	07:17-12:14
05/21/2004	3	13:07-12:14

## 1-2 PROJECT OVERVIEW

### EAF (PPFF) Baghouse Diagram

- 1.) Nucor Steel PPFF baghouse consists of 16 compartment housings with an area of 366”d x 260”w per compartment.
- 2.) Testing was conducted at 12 of the 16 compartment housings (see Table: 1-3).
- 3.) Three (3) sample runs were conducted at four compartments (per sample run) resulting in a test area of 366”d x 1040”w.
- 4.) The four (4) compartment-per run volumetric flow rates reflect approximately 25% of the total measured inlet flow rate (see 2-1 / 2-2 RESULTS for compartment and Inlet flow rates).

Table: 1-3



LEGEND:	Compartments tested per Run
Run 1	<input type="text"/>
Run 1	<input type="text"/>
Run 3	<input type="text"/>

**2-1 RESULTS**

**FILTERABLE AND CONDENSIBLE PM**  
*PPFF Baghouse*

Table 2-1

<u>Gas Conditions</u>		1	2	3	Averages
Ts	Stack Temperature	208.0	209.75	204.5	207.4
Bwo	Moisture (volume %)	2.01	2.08	2.04	2.04
O2	Oxygen (dry volume %)	19.0	19.0	19.0	19.0
CO2	Carbon Dioxide (dry volume %)	0.0	0.0	0.0	0.0
<u>Volumetric Flow Rate</u>					
Qa	Actual Conditions (acfm)	340,672	341,167	339,799	340,546
Qstd	Standard Conditions (dscfm)	265,284	264,771	265,912	265,322
<u>Emissions Results</u>					
C <sub>TSP</sub>	Concentration, filterable (gr/dscf)	0.0012	0.0010	0.0009	<b>0.0010</b>
E <sub>TSP</sub>	Emission Rate, filterable (lbs/hr)	2.6305	2.3339	2.1419	2.3687
C	Filterable & Condensable (gr/dscf)	0.0033	0.0033	0.0031	0.0032
E	Emission Rate, condensable (lbs/hr)	7.6065	7.3942	7.0158	7.3388
<u>Fan Amps / Damper Positions</u>					
	Average Fan Amps	133.9	125.6	122.9	127.5
	Average Damper Position	100%	100%	100%	100%

**NOTE:** Velocity head settings for Method 5D compartment test runs were derived from Inlet volumetric flow rates. Flow rate calculations were corrected for compartment conditions; temperature, moisture and gas analysis. A minimum of 160 dscf was sampled during each test period.

**2-2 RESULTS**

**METALS EMISSIONS**  
EAF (PPFF) Baghouse

Table 2-2

<u>Gas Conditions</u>		1	2	3	Averages
Ts	Stack Temperature	208.0	206.75	207.75	207.50
Bwo	Moisture (volume %)	3.89	3.51	3.83	3.74
O2	Oxygen (dry volume %)	19.0	19.0	19.0	19.0
CO2	Carbon Dioxide (dry volume %)	0.0	0.0	0.0	0.0
<b><u>Volumetric Flow Rate</u></b>					
Qa	Actual Conditions (acfm)	1,367,551	1,365,281	1,367,145	1,366,659
Qstd	Standard Conditions (dscfm)	1,044,463	1,048,837	1,045,172	1,046,157
<b>METALS EMISSIONS</b>					
E <sub>r</sub>	Lead (lbs/hr)	0.0170	0.0081	0.0071	0.0126
E <sub>r</sub>	Mercury (lbs/hr)	0.0145	0.0169	0.0279	0.0198

**NOTE:** Metals emissions are based on total baghouse (16 compartment) volumetric flow rates for the calculation of mass emissions (lb/hr).

334.9      332.5      318.2      328.5

**2-3 RESULTS**

**VISIBLE EMISSIONS - OPACITY**

*Melt Shop*  
Table 2-3

Run No.	1	2	3	Average
Date	May 19, 2004	May 19, 2004	May 19, 2004	
Start Time (approx)	16:11	17:41	18:41	
Stop Time (approx)	17:11	18:41	19:41	
Visible Emissions				
Opacity (EPA RM 9)	0.0	0.0	0.0	0.0 %

*East Baghouse - Roof Monitors*

Run No.	1A	1B	1C	1D	Average
Date	May 19, 2004	May 19, 2004	May 19, 2004	May 19, 2004	
Start Time (approx)	16:11	17:41	18:41	19:41	
Stop Time (approx)	17:11	18:41	19:41	20:27	
Visible Emissions					
Opacity (EPA RM 9)	0.0	0.0	0.0	0.0	0.0 %

*West Baghouse - Roof Monitors*

Run No.	1A	1B	1C	1D	Average
Date	May 19, 2004	May 19, 2004	May 19, 2004	May 19, 2004	
Start Time (approx)	16:11	17:41	18:41	19:41	
Stop Time (approx)	17:11	18:41	19:41	20:27	
Visible Emissions					
Opacity (EPA RM 9)	0.0	0.0	0.0	0.0	0.0 %

**2-3 RESULTS, cont.**

**VISIBLE EMISSIONS - OPACITY**

*East Baghouse - Roof Monitors*

Run No.	2A	2B	2C	2D	Average
Date	May 21, 2004	May 21, 2004	May 21, 2004	May 21, 2004	
Start Time (approx)	07:16	08:16	09:16	10:30	
Stop Time (approx)	08:16	09:16	10:21	11:30	
Visible Emissions					
Opacity (EPA RM 9)	0.0	0.0	0.0	0.0	0.0 %

*West Baghouse - Roof Monitors*

Run No.	2A	2B	2C	2D	Average
Date	May 21, 2004	May 21, 2004	May 21, 2004	May 21, 2004	
Start Time (approx)	07:16	08:16	09:16	10:30	
Stop Time (approx)	08:16	09:16	10:21	11:30	
Visible Emissions					
Opacity (EPA RM 9)	0.0	0.0	0.0	0.0	0.0 %

*East Baghouse - Roof Monitors*

Run No.	3A	3B	3C	3D	Average
Date	May 21, 2004	May 21, 2004	May 21, 2004	May 21, 2004	
Start Time (approx)	13:20	14:22	15:24	16:25	
Stop Time (approx)	14:20	15:22	16:24	17:25	
Visible Emissions					
Opacity (EPA RM 9)	0.0	0.0	0.0	0.0	0.0 %

**2-3 RESULTS, cont.**

**VISIBLE EMISSIONS - OPACITY**

*West Baghouse - Roof Monitors*

Run No.	3A	3B	3C	3D	Average
Date	May 21, 2004	May 21, 2004	May 21, 2004	May 21, 2004	
Start Time (approx)	13:20	14:22	15:24	16:25	
Stop Time (approx)	14:20	15:22	16:24	17:25	
Visible Emissions					
Opacity (EPA RM 9)	0.0	0.0	0.0	0.0	0.0 %

*Bin Vent - Old Silo*

Run No.	1	2	3	Average
Date	May 19, 2004	May 21, 2004	May 21, 2004	
Start Time (approx)	15:59	07:22	13:10	
Stop Time (approx)	16:59	08:22	14:10	
Visible Emissions				
Opacity (EPA RM 9)	0.0	0.0	0.0	0.0 %

*Bin Vent - New Silo*

Run No.	1	2	3	Average
Date	May 19, 2004	May 21, 2004	May 21, 2004	
Start Time (approx)	15:59	07:22	13:10	
Stop Time (approx)	16:59	08:22	14:10	
Visible Emissions				
Opacity (EPA RM 9)	0.0	0.0	0.0	0.0 %




### 3-1 PROCESS DESCRIPTION

Nucor steel operates a meltshop, which is comprised of the following process units: Two (2) EAF units, one (1) ladle metallurgy station, one (1) AOD with two (2) continuous casters. Of these, the two EAF units, the AOD, and the two caster units, each is evacuated through the meltshop baghouse.

The EAF units melt various grades of scrap metal, scrap substitute, pebbled lime, and coke into molten steel. The molten steel is refined into various grades of carbon steel at the ladle metallurgy station or refined into stainless steel at the AOD. The molten steel from the ladle metallurgy station or AOD is cast into continuous strips at the two continuous casters.

The emissions from the EAF units, AOD, and casters are generated from melting, refining, charging, tapping, and casting operations and are captured in a direct shell evacuation (DEC) system and overhead canopy hoods. All captured emissions are evacuated through the positive pressure fabric filter (PPFF) baghouse for collection.

The testing reported in this document was performed at 12 of the 16 EAF (PPFF) baghouse compartments.



## 4-1 METHODOLOGY

---

The sampling procedures utilized by Air Test Professionals, Inc. were as follows:

### Title 40 CFR Part 60 Appendix A

Method 1	"Sampling of Velocity Traverses for Stationary Sources"
Method 2	"Determining of Stack Gas Velocity and Volumetric Flow Rate"
Method 3	"Gas Analysis for the Determination of Molecular Weight"
Method 4	"Determination of Moisture Content in Stack Gas"
Method 5D	"Determination of Particulate Emissions from PPF Sources"
Method 29	"Determination of Metals Emissions from Stationary Sources"
Method 9	"Determination of Visible Emissions from Stationary Sources"

### Title 40 CFR Part 51 Appendix M

Method 202	"Determination of Condensable Particulate Emissions from Stationary Sources"
------------	--

---

## SAMPLE POINT DETERMINATION

Sampling point locations were determined according to EPA Reference Method 1.

Sampling Points  
Table 4-1

Location	Dimensions	Points / Port	Total Points
Inlet	14.67' x 23.13' ID	4	32
Compartment (ea)	21.67' x 30.50' ID	6	12

---

\*\* Exact traverse point measurements are listed in Appendix C - Field Data.

## 4-2 METHODOLOGY

---

### VELOCITY AND VOLUMETRIC FLOW RATE – EPA METHOD 2

EPA Method 2 was used to determine the gas velocity and flow rate at the Inlet duct. Figure 4-2 includes the components of the EPA Method 2 sampling apparatus. Each set of velocity determinations included the measurement of gas velocity pressure and gas temperature at each of the Method 1 determined traverse points. The velocity pressures were measured with a Type S pitot tube. Gas temperature measurements were made with a Type K thermocouple and digital pyrometer.

### GAS COMPOSITION AND MOLECULAR WEIGHT – EPA METHOD 3

In order to determine the oxygen and carbon dioxide concentrations, a sample of gas was obtained and analyzed in accordance with EPA Method 3. The gas sample was collected using a Fyrite analyzer. The results were used to determine gas molecular weight.

### MOISTURE CONTENT – EPA METHOD 4

The flue gas moisture content at the testing locations was determined in accordance with EPA Method 4. The gas moisture was determined by quantitatively condensing moisture in the chilled impingers and silica absorption. The amount of moisture condensed was determined gravimetrically. A dry gas meter was used to measure the volume of gas sampled. Moisture content is used to determine stack gas velocity.

### PARTICULATE/CONDENSIBLE DETERMINATION – EPA METHOD 5D/202

Stack gas is withdrawn isokinetically and particulate matter is collected on the nozzle and filter. Condensible particulate is captured in the first three impingers; each impinger contains 100 mls of deionized water. A fourth and final impinger contains an amount of approximately 200 grams of silica gel. The impinger temperature exit gas is maintained at or below 68 degrees Fahrenheit.

The nozzle and glass filter holder are rinsed with acetone and captured in a sealed glass container. The impingers and connecting glassware are rinsed twice with deionized water and captured in a sealed container. Two rinses of methylene chloride were captured and stored in a sealed container.

### DETERMINATION OF METALS EMISSIONS – EPA METHOD 29

Stack gas is withdrawn isokinetically and particulate matter is collected on the nozzle and filter. Gaseous emissions are collected in an absorbing solution of HNO<sub>3</sub>/H<sub>2</sub>O<sub>2</sub> (0.1 N Nitric Acid & Hydrogen Peroxide) in the 2<sup>nd</sup> and 3<sup>rd</sup> impingers and then in an aqueous acidic solution of K<sub>2</sub>MnO<sub>4</sub> (Potassium Permanganate) in the 5<sup>th</sup> and 6<sup>th</sup> impingers (analyzed for Hg). The 1<sup>st</sup> and 4<sup>th</sup> impingers are empty and the 7<sup>th</sup> impinger contains approximately 200 grams of silica gel. Impinger exit gas temperature is maintained at or below 68 degrees F.

The nozzle and filter holder are rinsed with 100 ml of 0.1 N HNO<sub>3</sub> and cleaned with a Teflon brush and collected in a jar. Impingers 1, 2 and 3 are measured for moisture pick-up and then collected in a jar before rinsing the impingers with 100 ml 0.1 N HNO<sub>3</sub>, along with the back-half of the glass filter holder. Absorbing solutions are combined along with the rinse solution. Impinger 4 is measured for moisture pick-up (individually), collected and then rinsed with 100 ml 0.1 N HNO<sub>3</sub> which is combined with the moisture pick-up. Impingers 5 and 6 are measured for moisture pick-up, collected in an amber jar with teflon lid liner and rinsed with 100 ml of KMnO<sub>4</sub> and followed by a 100 ml rinse of HPLC water which is combined with the absorbing solution. Impingers 5 and 6 are then rinsed with 25 ml of 8 N HCl and collected in a jar. Silica gel is also weighed for moisture pick-up.

## **4-2 METHODOLOGY, cont.**

---

### **VISIBLE EMISSIONS – EPA METHOD 9**

Stack opacity readings were taken for 60-minutes at 15-second intervals by a certified visible emissions reader. The visible emissions readings were conducted during each of the particulate test runs. The results are reported as an average emissions percentage for each hour period. A copy of the visible emissions certification card is included in Appendix G.

## SAMPLE CALCULATIONS

---

### 1. Volume of water collected (wstd)

$$V_{wstd} = (0.04707)(V_{lc})$$

$V_{wstd}$	volume of water collected at standard conditions (ft <sup>3</sup> )
$V_{lc}$	total volume of liquid collected in impingers and silica (ml)
0.04707	conversion factor (ft <sup>3</sup> /ml)

### 2. Volume of gas metered at standard conditions (dscf)

$$V_{mstd} = \frac{(17.64)(V_m) \left( P_{baro} + \frac{\Delta H}{13.6} \right) (\Gamma_d)}{(460 + T_m)}$$

$V_{mstd}$	volume of sample gas through dry gas meter at standard conditions (ft <sup>3</sup> )
$V_m$	volume of sample gas through dry gas meter at meter conditions (ft <sup>3</sup> )
$P_{baro}$	barometric pressure (in Hg)
$\Delta H$	average pressure drop across meter box orifice (in H <sub>2</sub> O)
$\Gamma_d$	gas meter correction factor (dimensionless)
$T_m$	average dry gas meter temperature (°F)
17.64	conversion factor (°R/in Hg)
13.6	conversion factor (in H <sub>2</sub> O/in Hg)
460	conversion constant, °F to °R

### 3. Sample gas pressure (in Hg)

$$P_s = P_{baro} + \left( \frac{P_g}{13.6} \right)$$

$P_s$	absolute sample gas pressure (in Hg)
$P_{baro}$	barometric pressure (in Hg)
$P_g$	sample gas static pressure (in H <sub>2</sub> O)
13.6	conversion factor (in H <sub>2</sub> O/in Hg)

### 4. Actual vapor pressure (in Hg)

$$P_v = P_s$$

$P_v$	vapor pressure, actual (in Hg)
$P_s$	absolute sample gas pressure (in Hg)

5. Moisture content (%)

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

$B_{wo}$	portion of water vapor in the gas stream by volume (%)
$V_{wstd}$	volume of water collected at standard conditions (ft <sup>3</sup> )
$V_{mstd}$	volume of sample gas through dry gas meter at standard conditions (ft <sup>3</sup> )

6. Saturated moisture content (%)

$$B_{ws} = \frac{P_v}{P_s}$$

$B_{ws}$	portion of water vapor in gas stream by volume at saturated conditions (%)
$P_v$	vapor pressure, actual (in Hg)
$P_s$	absolute sample gas pressure (in Hg)

7. Molecular weight of dry gas stream (lb/lb-mole)

$$M_d = M_{CO_2} \left( \frac{CO_2}{100} \right) + M_{O_2} \left( \frac{O_2}{100} \right) + M_{CO+N_2} \left( \frac{CO+N_2}{100} \right)$$

$M_d$	dry molecular weight of sample gas (lb/lb-mole)
$M_{CO_2}$	molecular weight of carbon dioxide (lb/lb-mole)
$M_{O_2}$	molecular weight of oxygen (lb/lb-mole)
$M_{CO+N_2}$	molecular weight of carbon monoxide and nitrogen (lb/lb-mole)
$CO_2$	portion of carbon dioxide in the gas stream by volume (%)
$O_2$	portion of oxygen in the gas stream by volume (%)
$CO+N_2$	portion of carbon monoxide and nitrogen in gas stream by volume (%)
100	conversion factor (%)

8. Molecular weight of sample gas (lb/lb-mole)

$$M_s = (M_d)(1 - B_{ws}) + (M_{H_2O})(B_{wo})$$

$M_d$	dry molecular weight of sample gas (lb/lb-mole)
$B_{wo}$	portion of water vapor in the gas stream by volume (%)
$M_{H_2O}$	molecular weight of water (lb/lb-mole)
$M_s$	molecular weight of sample gas, wet basis (lb/lb-mole)

9. Velocity of sample gas (ft/sec)

$$V_s = (K_p)(C_p)(\sqrt{\Delta P}) \left( \sqrt{\frac{(t_s + 460)}{(M_s)(P_s)}} \right)$$

$V_s$	average sample gas velocity (ft/sec)
$K_p$	velocity pressure coefficient (dimensionless)
$C_p$	pitot tube constant
$\Delta P$	average differential pressure in the gas stream (in H <sub>2</sub> O)
$t_s$	average sample gas temperature (°F)
$M_s$	molecular weight of sample gas, wet basis (lb/lb-mole)
$P_s$	absolute sample gas pressure (in Hg)
460	conversion constant, °F to °R

10. Total flow of sample gas (acfm)

$$Q_a = (60)(A_s)(V_s)$$

$Q_a$	volumetric flow rate at actual conditions (acfm)
$A_s$	cross-sectional area of sampling location (ft <sup>2</sup> )
$V_s$	average sample gas velocity (ft/sec)
60	conversion factor (seconds/minute)

11. Total flow of sample gas (dscfm)

$$Q_{std} = \frac{(Q_a)(P_s)(17.64)(1 - B_{wo})}{(t_s + 460)}$$

$Q_{std}$	volumetric flow rate at standard conditions (dscfm)
$Q_a$	volumetric flow rate at actual conditions (acfm)
$P_s$	absolute sample gas pressure (in Hg)
$B_{wo}$	portion of water vapor in the gas stream by volume (%)
$t_s$	average sample gas temperature (°F)
17.64	conversion factor (°R/in Hg)
460	conversion constant, °F to °R

12. Percent isokinetic (%)

$$I = \frac{(0.09450)(T_s)(V_{mstd})}{(P_s)(V_s) \left( \frac{(D_n)^2(\pi)}{(144)(4)} \right) (\theta)(1 - B_{wo})}$$

I	percent relative to isokinetic sampling (%)
T <sub>s</sub>	absolute sample gas temperature (°R)
V <sub>mstd</sub>	volume of sample gas through dry gas meter at standard conditions (ft <sup>3</sup> )
P <sub>s</sub>	absolute sample gas pressure (in Hg)
V <sub>s</sub>	average sample gas velocity (ft/sec)
D <sub>n</sub>	diameter of nozzle (inches)
B <sub>wo</sub>	portion of water vapor in the gas stream by volume (%)
θ	total sample time (minutes)
0.09450	conversion constant

13. Particulate concentration (gr/dscf)

$$C_{gr/dscf} = \frac{(15.43)(M_n)}{V_{mstd}}$$

C <sub>gr/dscf</sub>	measured concentration in gas stream (gr/dscf)
M <sub>n</sub>	particulate collected, corrected for reagent blank (grams)
V <sub>mstd</sub>	volume of sample gas through dry gas meter at standard conditions (ft <sup>3</sup> )
15.43	conversion factor (grains/gram)

14. Particulate emissions, mass emission rate (lbs/hr)

$$E_{lb/hr} = \frac{(M_n)(Q_{std})}{(7.567)(V_{mstd})}$$

E <sub>lbs/hr</sub>	mass emission rate (lbs/hr)
M <sub>n</sub>	particulate collected, corrected for reagent blank (grams)
Q <sub>std</sub>	volumetric flow rate at standard conditions (dscfm)
V <sub>mstd</sub>	volume of sample gas through dry gas meter at standard conditions (ft <sup>3</sup> )
7.567	conversion factor (grams/pound)



## STACK EMISSION SUMMARY

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	PPFF Baghouse
Date:	5/19/04

### Particulate Concentration

PM - Filterable (gr/dscf)  
 PM/PM10 - Filterable & Condensable (gr/dscf)  
 Filterable (lbs/hr)  
 Filterable + Condensable (lbs/hr)

**Run 1      Run 2      Run 3      Average**

0.0012	0.0010	0.0009	<b>0.0010</b>
0.0033	0.0033	0.0031	<b>0.0032</b>
2.6305	2.3339	2.1419	2.3687
7.6065	7.3942	7.0158	7.3388

### Avg. Stack Vol. Flow Rate

ACFM  
 DSCFM

340,672	341,167	339,799	340,546
265,284	264,771	265,912	265,322

Avg. Stack Temp  
 Stack Gas Velocity

208.00	209.75	204.50	207.42
2.148	2.151	2.142	2.147

Avg. Velocity Head  
 Avg. Sq. Rt of Delta P

0.00115	0.00115	0.00115	0.00115
0.034	0.034	0.034	0.034

### ISOKINETIC TESTING SUMMARY

Allowable isokinetic 80-120%  
 % Moisture of Stack Gas  
 Sample Volume

101.54	102.05	101.84	101.81
2.01%	2.08%	2.04%	2.04%
160.080	160.568	160.933	160.527

<b>Company:</b>	Nucor Steel
<b>Location:</b>	Crawfordsville, Indiana
<b>Source:</b>	PPFF Baghouse
<b>Date:</b>	5/19/04
<b>Run Number:</b>	1 - Particulate

**FIELD DATA**

K' Factor	840
-----------	-----

Start Time	15:57
Stop Time	21:29

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 19  
 Md (g/gmol) = 28.76

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vc (mL) = 69.6  
 Vw (scf) = 3.27607

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 87.823  
 Vm (ft<sup>3</sup>) = 164.488  
 Pb (in Hg) = 30.08  
 delta H (in H2O) = 0.966  
 gamma = 1.002  
 Vm (dscf) = 160.08

Moisture Content of Stack Gas, Bwo  
 Bwo = 2.01%  
 1-Bwo = 97.99%

Molecular Weight of Stack Gas, Ms  
 Ms (g/gmol) = 28.54

Area of Stack (enter diameter in inches), As  
 Depth = 366  
 Width = > 1040  
 diameter (in) = 0  
 No. of Stacks = 1  
 As(L\*W) (ft<sup>2</sup>) = 2643.333  
 As(dia.) (ft<sup>2</sup>) = 2643.3

Absolute Pressure, Ps  
 Static (in H2O) = 0  
 Ps (in Hg) = 30.08

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sqrt(delta p) = 0.034  
 Ts (F) = 208.0  
 Vs (fps) = 2.15

Stack Gas Flowrate, Qs  
 As (ft<sup>2</sup>) = 2643.33  
 Qs (acfm) = 340,672

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscf/m) = 265,284  
 Qstd (dscf/hr) = 15,917,040

Velocity at the Nozzle, Vn Area of Nozzle, An  
 Dia. of Nozzle (in) = 1.0 An (ft<sup>2</sup>) = 0.0054541  
 Time of Run (min) = 288.00  
 Vn (fps) = 2.18

% Isokinetic, %I  
 %I = 101.54  
 % Isokinetic measured from intermediate values  
 %I = 101.54

Pollutant Mass Emission Rate, PMR  
 Mn (g) = 0.0120 0.0227 7.6065  
 PMR (lb/hr) = 2.6305 4.9760  
 Filterable Condensable Total

Grains per acf  
 gr/acf = 0.0009 0.0009

Grains per dscf  
 gr/dscf = 0.0012 0.0022 0.0033  
 Filterable Condensable Total

Run 1	Delta P	Squ Δ P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	0.00115	0.034		0.97	208	92	92
2	0.00115	0.034		0.97	208	93	92
3	0.00115	0.034		0.97	208	94	92
4	0.00115	0.034		0.97	208	94	92
5	0.00115	0.034		0.97	208	95	92
6	0.00115	0.034		0.97	208	94	93
7	0.00115	0.034		0.97	208	95	93
8	0.00115	0.034		0.97	208	91	91
9	0.00115	0.034		0.97	208	86	88
10	0.00115	0.034		0.97	208	85	86
11	0.00115	0.034		0.97	208	86	85
12	0.00115	0.034		0.97	208	86	85
13	0.00115	0.034		0.97	208	85	85
14	0.00115	0.034		0.97	208	86	85
15	0.00115	0.034		0.97	208	87	85
16	0.00115	0.034		0.97	208	87	85
17	0.00115	0.034		0.97	208	87	85
18	0.00115	0.034		0.97	208	87	84
19	0.00115	0.034		0.97	208	86	84
20	0.00115	0.034		0.97	208	86	84
21	0.00115	0.034		0.97	208	86	84
22	0.00115	0.034		0.97	208	86	84
23	0.00115	0.034		0.97	208	86	84
24	0.00115	0.034		0.97	208	86	84
25	0.00115	0.034		0.97	208	85	84
26	0.00115	0.034		0.97	208	86	84
27	0.00115	0.034		0.97	208	86	84
28	0.00115	0.034		0.97	208	86	84
29	0.00115	0.034		0.97	208	86	84
30	0.00115	0.034		0.97	208	86	84
31	0.00115	0.034		0.97	208	85	84
32	0.00115	0.034		0.97	208	86	84
33	0.00115	0.034		0.97	208	87	84
34	0.00115	0.034		0.97	208	88	84
35	0.00115	0.034		0.97	208	88	85
36	0.00115	0.034		0.97	208	89	85
37	0.00115	0.034		0.97	208	88	85
38	0.00115	0.034		0.97	208	89	86
39	0.00115	0.034		0.97	208	89	86
40	0.00115	0.034		0.97	208	89	86
41	0.00115	0.034		0.97	208	89	86
42	0.00115	0.034		0.97	208	92	87
43	0.00115	0.034		0.97	208	94	89
44	0.00115	0.034		0.97	208	95	91
45	0.00115	0.034		0.97	208	95	91
46	0.00115	0.034	557.558	0.97	208	95	91
47	0.00115	0.034	393.07	0.97	208	94	91
48	0.00115	0.034		0.97	208	94	91

0.001	Squ Δ P	Volume	Delta H	Stack T	Meter Temp
	0.034	164.488	0.966	208.00	87.82

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	PPFF Baghouse
Date:	05/21/04
Run Number:	2 - Particulate

**FIELD DATA**

K Factor	840
----------	-----

Start Time	7:17
Stop Time	12:14

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 19  
 Md (g/gmol) = 28.76

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vlc (mL) = 72.5  
 Vw (scf) = 3.41258

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 95.063  
 Vm (ft<sup>3</sup>) = 167.17  
 Pb (in Hg) = 30.08  
 delta H (in H2O) = 0.966  
 gamma = 1.002  
 Vm (dscf) = 160.57

Moisture Content of Stack Gas, Bwo  
 Bwo = 2.08%  
 1-Bwo = 97.92%

Molecular Weight of Stack Gas, Ms  
 Ms (g/gmol) = 28.54

Area of Stack (enter diameter in inches), As  
 L = 366  
 W = 1040  
 diameter (in) = 0  
 No. of Stacks = 1  
 As(L\*W) (ft<sup>2</sup>) = 2643.333  
 As(dia.) (ft<sup>2</sup>) = 2643.3

Absolute Pressure, Ps  
 Static (in H2O) = 0  
 Ps (in Hg) = 30.08

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sqrt(delta p) = 0.034  
 Ts (F) = 209.8  
 Vs (fps) = 2.15

Stack Gas Flowrate, Qs  
 As (ft<sup>2</sup>) = 2643.33  
 Qs (acfm) = 341,167

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscf/m) = 264,771  
 Qstd (dscf/hr) = 15,886,231

Velocity at the Nozzle, Vn Area of Nozzle, An  
 Dia. of Nozzle (in) = 1.0 An (ft<sup>2</sup>) = 0.0054541  
 Time of Run (min) = 288  
 Vn (fps) = 2.20

% Isokinetic, %I  
 %I = 102.05  
 % Isokinetic measured from intermediate values  
 %I = 102.05

Pollutant Mass Emission Rate, PMR  
 Mn (g) = 0.0107 0.0232  
 PMR (lbs/hr) = 2.3339 5.0603 7.3941918  
 Filterable Condensible Total

Grains per acf  
 gr/acf = 0.0008

Grains per dscf  
 gr/dscf = 0.0010 0.0022 0.0033  
 Filterable Condensible Total

Run 2	Delta P	Squ Δ P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	0.00115	0.034		0.97	208	82	81
2	0.00115	0.034		0.97	208	83	81
3	0.00115	0.034		0.97	208	84	82
4	0.00115	0.034		0.97	208	85	83
5	0.00115	0.034		0.97	208	86	83
6	0.00115	0.034		0.97	208	85	83
7	0.00115	0.034		0.97	208	89	85
8	0.00115	0.034		0.97	208	90	86
9	0.00115	0.034		0.97	208	90	86
10	0.00115	0.034		0.97	208	90	88
11	0.00115	0.034		0.97	208	90	88
12	0.00115	0.034		0.97	208	90	89
13	0.00115	0.034		0.97	215	91	89
14	0.00115	0.034		0.97	215	93	91
15	0.00115	0.034		0.97	215	95	91
16	0.00115	0.034		0.97	215	96	92
17	0.00115	0.034		0.97	215	96	92
18	0.00115	0.034		0.97	215	96	92
19	0.00115	0.034		0.97	215	96	92
20	0.00115	0.034		0.97	215	96	93
21	0.00115	0.034		0.97	215	97	93
22	0.00115	0.034		0.97	215	97	94
23	0.00115	0.034		0.97	215	97	94
24	0.00115	0.034		0.97	215	97	94
25	0.00115	0.034		0.97	195	98	94
26	0.00115	0.034		0.97	195	98	94
27	0.00115	0.034		0.97	195	98	95
28	0.00115	0.034		0.97	195	98	95
29	0.00115	0.034		0.97	195	99	95
30	0.00115	0.034		0.97	195	100	96
31	0.00115	0.034		0.97	195	101	96
32	0.00115	0.034		0.97	195	101	97
33	0.00115	0.034		0.97	195	102	98
34	0.00115	0.034		0.97	195	102	98
35	0.00115	0.034		0.97	195	102	99
36	0.00115	0.034		0.97	185	103	99
37	0.00115	0.034		0.97	221	103	100
38	0.00115	0.034		0.97	221	103	100
39	0.00115	0.034		0.97	221	103	100
40	0.00115	0.034		0.97	221	103	100
41	0.00115	0.034		0.97	221	103	100
42	0.00115	0.034		0.97	221	104	100
43	0.00115	0.034		0.97	221	104	101
44	0.00115	0.034		0.97	221	104	101
45	0.00115	0.034		0.97	221	104	101
46	0.00115	0.034	724.95	0.97	221	105	101
47	0.00115	0.034	557.78	0.97	221	105	102
48	0.00115	0.034		0.97	221	105	102

0.001	Squ Δ P	Volume	Delta H	Stack T	Meter Temp
	0.034	167.17	0.966	209.75	95.06

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	PPFF Baghouse
Date:	05/21/04
Run Number:	3 - Particulate

**FIELD DATA**

K' Factor	850
-----------	-----

Start Time	13:07
Stop Time	17:54

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 19  
 Md (g/gmol) = 28.76

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vc (mL) = 71.1  
 Vw (scf) = 3.34688

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 105.68  
 Vm (ft<sup>3</sup>) = 170.749  
 Pb (in Hg) = 30.08  
 delta H (in H2O) = 0.977  
 gamma = 1.002  
 Vm (dscf) = 160.93

Moisture Content of Stack Gas, Bwo  
 Bwo = 2.04%  
 1-Bwo = 97.96%

Molecular Weight of Stack Gas, Ms  
 Ms (g/gmol) = 28.54

Area of Stack (enter diameter in inches), As  
 L = 366  
 W = 1040  
 diameter (In) = 0  
 No. of Stacks = 1  
 As(L\*W) (ft<sup>2</sup>) = 2643.333  
 As(dia.) (ft<sup>2</sup>) = 2643.3

Absolute Pressure, Ps  
 Static (in H2O) = 0  
 Ps (in Hg) = 30.08

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sqrt(delta p) = 0.034  
 Ts (F) = 204.5  
 Vs (fps) = 2.14

Stack Gas Flowrate, Qs  
 As (ft<sup>2</sup>) = 2643.33  
 Qs (acfm) = 339.799

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscf/m) = 265.912  
 Qstd (dscf/hr) = 15,954,694

Velocity at the Nozzle, Vn Area of Nozzle, An  
 Dia. of Nozzle (in) = 1.0 An (ft<sup>2</sup>) = 0.005454  
 Time of Run (min) = 288  
 Vn (fps) = 2.18

% Isokinetic, %I  
 %I = 101.84  
 % Isokinetic measured from intermediate values  
 %I = 101.84

Pollutant Mass Emission Rate, PMR  
 Mn (g) = 0.0098 0.0223  
 PMR (lbs/hr) = 2.1419 4.8739 7.015818  
 Filterable Condensable Total

Grains per acf  
 gr/acf = 0.0007

Grains per dscf  
 gr/dscf = 0.0009 0.0021 0.0031  
 Filterable Condensable Total

Run 3	Delta P	Squ Δ P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	0.00115	0.034		0.98	187	102	101
2	0.00115	0.034		0.98	187	102	101
3	0.00115	0.034		0.98	187	103	102
4	0.00115	0.034		0.98	187	103	102
5	0.00115	0.034		0.98	187	104	102
6	0.00115	0.034		0.98	187	105	102
7	0.00115	0.034		0.98	187	105	103
8	0.00115	0.034		0.98	187	106	103
9	0.00115	0.034		0.98	187	106	103
10	0.00115	0.034		0.98	187	108	103
11	0.00115	0.034		0.98	187	106	103
12	0.00115	0.034		0.98	187	106	103
13	0.00115	0.034		0.98	228	108	103
14	0.00115	0.034		0.98	228	108	103
15	0.00115	0.034		0.98	228	107	104
16	0.00115	0.034		0.98	228	108	105
17	0.00115	0.034		0.98	228	108	105
18	0.00115	0.034		0.98	228	108	105
19	0.00115	0.034		0.98	228	108	105
20	0.00115	0.034		0.98	228	108	105
21	0.00115	0.034		0.98	228	111	106
22	0.00115	0.034		0.98	228	110	107
23	0.00115	0.034		0.98	228	110	108
24	0.00115	0.034		0.98	228	111	108
25	0.00115	0.034		0.98	202	110	107
26	0.00115	0.034		0.98	202	110	108
27	0.00115	0.034		0.98	202	110	108
28	0.00115	0.034		0.98	202	110	107
29	0.00115	0.034		0.98	202	109	107
30	0.00115	0.034		0.98	202	109	107
31	0.00115	0.034		0.98	202	108	106
32	0.00115	0.034		0.98	202	108	106
33	0.00115	0.034		0.98	202	108	105
34	0.00115	0.034		0.98	202	108	105
35	0.00115	0.034		0.98	202	107	105
36	0.00115	0.034		0.98	202	107	105
37	0.00115	0.034		0.98	201	107	105
38	0.00115	0.034		0.98	201	108	104
39	0.00115	0.034		0.98	201	108	104
40	0.00115	0.034		0.98	201	108	104
41	0.00115	0.034		0.98	201	108	104
42	0.00115	0.034		0.98	201	108	104
43	0.00115	0.034		0.98	201	108	104
44	0.00115	0.034		0.98	201	108	104
45	0.00115	0.034		0.98	201	108	103
46	0.00115	0.034	893.904	0.98	201	108	103
47	0.00115	0.034	723.155	0.98	201	108	103
48	0.00115	0.034		0.98	201	108	103

0.001	Squ Δ P	Volume	Delta H	Stack T	Meter Temp
	0.034	170.749	0.977	204.50	105.68

# METALS - STACK EMISSION SUMMARY

SOURCE TESTED:  
 COMPANY NAME:  
 DATE OF TEST:

**PPFF Baghouse**  
 Nucor Steel  
 May 19, 21, 2004

<b>Metals Emissions (lbs/hr)</b>	<b>Run 1</b>	<b>Run 2</b>	<b>Run 3</b>	<b>Average</b>
Lead	0.0170	0.0081	0.0071	0.0126
Mercury	0.0145	0.0169	0.0279	0.0198
<b>Avg. Stack Vol. Flow Rate</b>				
ACFM	1,367,551	1,365,281	1,367,145	1,366,659
DSCFM	1,044,463	1,048,837	1,045,172	1,046,157
<b>Avg. Stack Temp</b>	208.00	206.75	207.75	207.50
<b>Stack Gas Velocity</b>	2.156	2.152	2.155	2.154
<b>Avg. Velocity Head</b>	0.00115	0.00115	0.00115	0.00115
<b>Avg. Sq. Rt of Delta P</b>	0.034	0.034	0.034	0.034
<b>ISOKINETIC TESTING SUMMARY</b>				
Allowable isokinetic 80-120%	96.88	100.43	96.50	97.94
% Moisture of Stack Gas	3.89%	3.51%	3.83%	3.74%
Sample Volume	37.583	39.124	37.463	38.057

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	PPFF Baghouse
Date:	5/19/04
Run Number:	1 - Metals

**FIELD DATA**

K' Factor	52.5
-----------	------

Start Time	15:58
Stop Time	21:30

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 19  
 Md (g/gmol) = 28.76

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vc (mL) = 32.3  
 Vw (scf) = 1.52036

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 83.927  
 Vm (ft<sup>3</sup>) = 38.894  
 P<sub>b</sub> (in Hg) = 30.08  
 delta H (in H<sub>2</sub>O) = 0.080  
 gamma = 0.99  
 Vm (dscf) = 37.58

Moisture Content of Stack Gas, Bwo  
 Bwo = 3.89%  
 1-Bwo = 96.11%

Molecular Weight of Stack Gas, Ms  
 Ms (g/gmol) = 28.34

Area of Stack (enter diameter in inches), As  
 Depth = 386  
 Width = 4160  
 diameter (in) = 0  
 No. of Stacks = 1  
 As(L\*W) (ft<sup>2</sup>) = 10573.333  
 As(dia.) (ft<sup>2</sup>) = 10573.3

Absolute Pressure, Ps  
 Static (in H<sub>2</sub>O) = 0  
 Ps (in Hg) = 30.08

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sqrt(delta p) = 0.034  
 Ts (F) = 208.0  
 Vs (fps) = 2.16

Stack Gas Flowrate, Qs  
 As (ft<sup>2</sup>) = 10573.33  
 Qs (acfm) = 1,367,551

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscf/m) = 1,044,463  
 Qstd (dscf/hr) = 62,667,790

Velocity at the Nozzle, Vn Area of Nozzle, An  
 Dia. of Nozzle (in) = 0.5 An (ft<sup>2</sup>) = 0.0013635  
 Time of Run (min) = 288.00  
 Vn (fps) = 2.09

% Isokinetic, %I  
 %I = 96.88  
 % Isokinetic measured from intermediate values  
 %I = 96.88

**Pollutant Mass Emission Rate, PMR, lbs./hr.**

Mn 4.64E-06 3.95E-06  
 PMR (lbs/hr) 1.70E-02 1.45E-02  
 LEAD MERCURY

Grains per acf  
 gr/acf = 1.51E-06 1.29E-06

Grains per dscf  
 gr/dscf = 1.90E-06 1.62E-06

Run 1	Delta P	Squ Δ P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	0.00115	0.034		0.06	208	88	88
2	0.00115	0.034		0.06	208	87	88
3	0.00115	0.034		0.06	208	89	88
4	0.00115	0.034		0.06	208	88	88
5	0.00115	0.034		0.06	208	88	88
6	0.00115	0.034		0.06	208	89	89
7	0.00115	0.034		0.06	208	89	89
8	0.00115	0.034		0.06	208	88	88
9	0.00115	0.034		0.06	208	83	84
10	0.00115	0.034		0.06	208	82	83
11	0.00115	0.034		0.06	208	82	83
12	0.00115	0.034		0.06	208	82	82
13	0.00115	0.034		0.06	208	83	84
14	0.00115	0.034		0.06	208	82	84
15	0.00115	0.034		0.06	208	82	82
16	0.00115	0.034		0.06	208	82	82
17	0.00115	0.034		0.06	208	82	82
18	0.00115	0.034		0.06	208	82	82
19	0.00115	0.034		0.06	208	82	82
20	0.00115	0.034		0.06	208	82	82
21	0.00115	0.034		0.06	208	82	82
22	0.00115	0.034		0.06	208	82	82
23	0.00115	0.034		0.06	208	82	82
24	0.00115	0.034		0.06	208	82	82
25	0.00115	0.034		0.06	208	81	82
26	0.00115	0.034		0.06	208	82	82
27	0.00115	0.034		0.06	208	82	82
28	0.00115	0.034		0.06	208	82	82
29	0.00115	0.034		0.06	208	82	81
30	0.00115	0.034		0.06	208	82	81
31	0.00115	0.034		0.06	208	82	81
32	0.00115	0.034		0.06	208	82	82
33	0.00115	0.034		0.06	208	84	82
34	0.00115	0.034		0.06	208	83	82
35	0.00115	0.034		0.06	208	83	82
36	0.00115	0.034		0.06	208	83	82
37	0.00115	0.034		0.06	208	83	83
38	0.00115	0.034		0.06	208	83	83
39	0.00115	0.034		0.06	208	83	83
40	0.00115	0.034		0.06	208	83	83
41	0.00115	0.034		0.06	208	83	82
42	0.00115	0.034		0.06	208	85	84
43	0.00115	0.034		0.06	208	86	87
44	0.00115	0.034		0.06	208	88	88
45	0.00115	0.034		0.06	208	88	87
46	0.00115	0.034	917.17	0.06	208	88	86
47	0.00115	0.034	878.278	0.06	208	87	87
48	0.00115	0.034		0.06	208	87	87

	Squ Δ P	Volume	Delta H	Stack T	Meter Temp
0.001	0.034	38.894	0.060	208.00	83.93

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	PPFF Baghouse
Date:	05/21/04
Run Number:	2 - Metals

**FIELD DATA**

K' Factor	52.5
-----------	------

Start Time	7:17
Stop Time	12:14

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 19  
 Md (g/gmol) = 28.76

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vlo (mL) = 30.2  
 Vw (scf) = 1.42151

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 92.813  
 Vm (ft<sup>3</sup>) = 41.15  
 Pb (in Hg) = 30.08  
 delta H (in H2O) = 0.080  
 gamma = 0.99  
 Vm (dscf) = 39.12

Moisture Content of Stack Gas, Bwo  
 Bwo = 3.51%  
 1-Bwo = 96.49%

Molecular Weight of Stack Gas, Ms  
 Ms (g/gmol) = 28.38

Area of Stack (enter diameter in inches), As  
 L = 366  
 W = 4160  
 diameter (in) = 0  
 No. of Stacks = 1  
 As(L\*W) (ft<sup>2</sup>) = 10573.333  
 As(dia.) (ft<sup>2</sup>) = 10573.3

Absolute Pressure, Ps  
 Static (in H2O) = 0  
 Ps (in Hg) = 30.08

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sqrdelta p = 0.034  
 Ts (F) = 206.8  
 Vs (fps) = 2.15

Stack Gas Flowrate, Qs  
 As (ft<sup>2</sup>) = 10573.33  
 Qs (acfm) = 1,365,281

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscf/m) = 1,048,837  
 Qstd (dscf/hr) = 62,930,236

Velocity at the Nozzle, Vn Area of Nozzle, An  
 Dia. of Nozzle (in) = 0.5 An (ft<sup>2</sup>) = 0.0013635  
 Time of Run (min) = 288  
 Vn (fps) = 2.16

% Isokinetic, %I  
 %I = 100.43  
 % Isokinetic measured from intermediate values  
 %I = 100.43

**Pollutant Mass Emission Rate, PMR, lbs./hr.**

Mn	2.29E-06	4.77E-06
PMR (lbs/hr)	8.11E-03	1.69E-02
	LEAD	MERCURY

Grains per acf  
 gr/acf = 7.18E-07 1.49E-06

Grains per dscf  
 gr/dscf = 9.03E-07 1.88E-06

Run 2	Delta P	Squ Δ P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	0.00115	0.034		0.06	212	80	81
2	0.00115	0.034		0.06	212	81	81
3	0.00115	0.034		0.06	212	81	81
4	0.00115	0.034		0.06	212	82	81
5	0.00115	0.034		0.06	212	82	81
6	0.00115	0.034		0.06	212	83	82
7	0.00115	0.034		0.06	212	83	83
8	0.00115	0.034		0.06	212	85	84
9	0.00115	0.034		0.06	212	86	84
10	0.00115	0.034		0.06	212	87	85
11	0.00115	0.034		0.06	212	88	86
12	0.00115	0.034		0.06	212	89	86
13	0.00115	0.034		0.06	198	90	86
14	0.00115	0.034		0.06	198	90	88
15	0.00115	0.034		0.06	198	90	89
16	0.00115	0.034		0.06	198	91	90
17	0.00115	0.034		0.06	198	91	90
18	0.00115	0.034		0.06	198	91	90
19	0.00115	0.034		0.06	198	92	91
20	0.00115	0.034		0.06	198	92	91
21	0.00115	0.034		0.06	188	93	91
22	0.00115	0.034		0.06	198	93	92
23	0.00115	0.034		0.06	198	93	92
24	0.00115	0.034		0.06	198	93	92
25	0.00115	0.034		0.06	229	94	93
26	0.00115	0.034		0.06	229	94	93
27	0.00115	0.034		0.06	229	94	94
28	0.00115	0.034		0.06	229	95	94
29	0.00115	0.034		0.06	229	95	94
30	0.00115	0.034		0.06	229	96	95
31	0.00115	0.034		0.06	229	97	96
32	0.00115	0.034		0.06	229	97	97
33	0.00115	0.034		0.06	229	98	97
34	0.00115	0.034		0.06	229	98	97
35	0.00115	0.034		0.06	229	98	98
36	0.00115	0.034		0.06	229	99	98
37	0.00115	0.034		0.06	188	100	99
38	0.00115	0.034		0.06	188	100	99
39	0.00115	0.034		0.06	188	100	99
40	0.00115	0.034		0.06	188	100	100
41	0.00115	0.034		0.06	188	101	101
42	0.00115	0.034		0.06	188	101	101
43	0.00115	0.034		0.06	188	102	102
44	0.00115	0.034		0.06	188	102	102
45	0.00115	0.034		0.06	188	102	102
46	0.00115	0.034	958.47	0.06	188	102	102
47	0.00115	0.034	917.32	0.06	188	102	102
48	0.00115	0.034		0.06	188	103	102

0.001	Squ Δ P	Volume	Delta H	Stack T	Meter Temp
	0.034	41.15	0.060	206.75	92.81

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	PPFF Baghouse
Date:	05/21/04
Run Number:	3 - Metals

FIELD DATA

K' Factor	52.5
-----------	------

Start Time	13:07
Stop Time	17:54

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 19  
 Md (g/gmol) = 28.76

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vlc (mL) = 31.7  
 Vw (scf) = 1.49212

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 102.98  
 Vm (ft<sup>3</sup>) = 40.128  
 Pb (in Hg) = 30.08  
 delta H (in H2O) = 0.060  
 gamma = 0.99  
 Vm (dscf) = 37.46

Moisture Content of Stack Gas, Bwo  
 Bwo = 3.83%  
 1-Bwo = 96.17%

Molecular Weight of Stack Gas, Ms  
 Ms (g/gmol) = 28.35

Area of Stack (enter diameter in inches), As  
 L = 366  
 W = 4180  
 diameter (in) = 0  
 No. of Stacks = 1  
 As(L\*W) (ft<sup>2</sup>) = 10573.333  
 As(dia.) (ft<sup>2</sup>) = 10573.3

Absolute Pressure, Ps  
 Static (in H2O) = 0  
 Ps (in Hg) = 30.08

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sqr(delta p) = 0.034  
 Ts (F) = 207.8  
 Vs (fps) = 2.16

Stack Gas Flowrate, Qs  
 As (ft<sup>2</sup>) = 10573.33  
 Qs (acfm) = 1,367.145

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscf/m) = 1,045.172  
 Qstd (dscf/hr) = 62,710,292

Velocity at the Nozzle, Vn Area of Nozzle, An  
 Dia. of Nozzle (in) = 0.5 An (ft<sup>2</sup>) = 0.001364  
 Time of Run (min) = 288  
 Vn (fps) = 2.08

% Isokinetic, %I  
 %I = 96.50  
 % isokinetic measured from intermediate values  
 %I = 96.50

Pollutant Mass Emission Rate, PMR, lbs./hr.

Min	1.93E-06	7.58E-06
PMR (lbs/hr)	7.12E-03	2.79E-02
	LEAD	MERCURY

Grains per acf  
 gr/acf = 6.31E-07 2.49E-06

Grains per dscf  
 gr/dscf = 7.95E-07 3.12E-06

Run #	Delta P	Squ Δ P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	0.00115	0.034		0.06	202	102	102
2	0.00115	0.034		0.06	202	102	102
3	0.00115	0.034		0.06	202	102	102
4	0.00115	0.034		0.06	202	102	102
5	0.00115	0.034		0.06	202	102	102
6	0.00115	0.034		0.06	202	102	102
7	0.00115	0.034		0.06	202	102	102
8	0.00115	0.034		0.06	202	102	102
9	0.00115	0.034		0.06	202	102	102
10	0.00115	0.034		0.06	202	102	103
11	0.00115	0.034		0.06	202	103	103
12	0.00115	0.034		0.06	202	103	103
13	0.00115	0.034		0.06	214	103	103
14	0.00115	0.034		0.06	214	102	102
15	0.00115	0.034		0.06	214	104	103
16	0.00115	0.034		0.06	214	104	103
17	0.00115	0.034		0.06	214	104	103
18	0.00115	0.034		0.06	214	104	103
19	0.00115	0.034		0.06	214	106	103
20	0.00115	0.034		0.06	214	106	103
21	0.00115	0.034		0.06	214	106	105
22	0.00115	0.034		0.06	214	106	105
23	0.00115	0.034		0.06	214	108	105
24	0.00115	0.034		0.06	214	106	105
25	0.00115	0.034		0.06	201	104	105
26	0.00115	0.034		0.06	201	104	105
27	0.00115	0.034		0.06	201	105	105
28	0.00115	0.034		0.06	201	105	105
29	0.00115	0.034		0.06	201	104	104
30	0.00115	0.034		0.06	201	104	104
31	0.00115	0.034		0.06	201	103	103
32	0.00115	0.034		0.06	201	103	103
33	0.00115	0.034		0.06	201	103	103
34	0.00115	0.034		0.06	201	103	102
35	0.00115	0.034		0.06	201	102	102
36	0.00115	0.034		0.06	201	102	102
37	0.00115	0.034		0.06	214	102	102
38	0.00115	0.034		0.06	214	102	102
39	0.00115	0.034		0.06	214	102	102
40	0.00115	0.034		0.06	214	102	102
41	0.00115	0.034		0.06	214	102	102
42	0.00115	0.034		0.06	214	102	102
43	0.00115	0.034		0.06	214	102	102
44	0.00115	0.034		0.06	214	102	102
45	0.00115	0.034		0.06	214	102	102
46	0.00115	0.034	998.858	0.06	214	102	102
47	0.00115	0.034	958.73	0.06	214	102	102
48	0.00115	0.034		0.06	214	102	102

	Squ Δ P	Volume	Delta H	Stack T	Meter Temp
0.001	0.034	40.128	0.060	207.75	102.98



## CYCLONIC FLOW CHECK

(Method 2F)

<b>Date:</b>	May 19, 2004	<b>Box ID:</b>	A-1
<b>Barometric:</b>	30.08	<b>Probe Type:</b>	Type-S
<b>Stack Dia:</b>	278" x 176"	<b>Probe No:</b>	12.1x2
<b>Pitot Cp:</b>	0.84	<b>Pitot Check:</b>	Good

Traverse Points	Percent of Dia.	Vel. Head ( $\Delta P$ )	Yaw Angle ( $\alpha$ )	Temp (deg F.)
1 - Port 1	22.0"	1.10	+ 0.0	184
2	66.0"	1.40	+ 8.0	189
3	110.0"	1.40	+ 8.0	186
4	154.0"	1.05	+ 8.0	180
5 - Port 2	22.0"	0.74	+ 8.0	197
6	66.0"	0.89	+ 12.0	194
7	110.0"	1.05	+ 13.0	192
8	154.0"	0.94	+ 10.0	181
9 - Port 3	22.0"	0.72	+ 3.0	151
10	66.0"	0.97	+ 6.0	160
11	110.0"	1.15	+ 9.0	156
12	154.0"	0.98	+ 9.0	152
13 - Port 4	22.0"	0.52	+ 0.0	179
14	66.0"	0.83	+ 0.0	187
15	110.0"	1.20	+ 3.0	192
16	154.0"	1.25	+ 2.0	197
17 - Port 5	22.0"	0.82	+ 3.0	192
18	66.0"	1.02	+ 5.0	180
19	110.0"	1.45	+ 8.0	169
20	154.0"	1.40	+ 6.0	165
21 - Port 6	22.0"	1.40	+ 5.0	225
22	66.0"	1.50	+ 5.0	245
23	110.0"	1.60	+ 5.0	250
24	154.0"	1.25	+ 5.0	257
25 - Port 7	22.0"	1.30	+ 5.0	237
26	66.0"	1.65	+ 4.0	262
27	110.0"	1.55	+ 5.0	242
28	154.0"	1.30	+ 6.0	223
29 - Port 8	22.0"	0.78	+ 7.0	268
30	66.0"	0.97	+ 8.0	280
31	110.0"	0.97	+ 3.0	287
32	154.0"	0.94	+ 2.0	293
	<b>Absolute Avgs.</b>	<b>1.13 (<math>\Delta P</math>)</b>	<b>5.66° (<math>\alpha</math>)</b>	<b>208.0 F</b>

**NOTE:** The average of the yaw angle ( $\alpha$ ) absolute values must be 20° to be acceptable.

**PRE-TEST FLOW TRAVERSE**  
(Method 1-2)

**RUN 2**

<b>Date:</b>	May 21, 2004	<b>Box ID:</b>	A-1
<b>Barometric:</b>	30.04	<b>Probe Type:</b>	Type-S
<b>Stack Dia:</b>	278" x 176"	<b>Probe No:</b>	12.1x2
<b>Pitot Cp:</b>	0.84	<b>Pitot Check:</b>	Good

Traverse Points	Percent of Dia.	Vcl. Head ( $\Delta P$ )	Temp (deg F.)
1 - Port 1	22.0"	1.40	185
2	66.0"	1.25	188
3	110.0"	1.30	186
4	154.0"	1.30	188
5 - Port 2	22.0"	1.20	190
6	66.0"	0.98	192
7	110.0"	0.93	187
8	154.0"	0.82	188
9 - Port 3	22.0"	1.05	192
10	66.0"	0.92	196
11	110.0"	0.88	198
12	154.0"	0.91	204
13 - Port 4	22.0"	0.92	212
14	66.0"	0.95	218
15	110.0"	1.07	229
16	154.0"	1.10	238
17 - Port 5	22.0"	0.89	244
18	66.0"	0.78	259
19	110.0"	1.20	273
20	154.0"	1.10	282
21 - Port 6	22.0"	1.30	294
22	66.0"	1.20	303
23	110.0"	1.35	310
24	154.0"	1.40	318
25 - Port 7	22.0"	1.30	322
26	66.0"	1.40	328
27	110.0"	1.25	330
28	154.0"	1.30	338
29 - Port 8	22.0"	0.86	334
30	66.0"	0.84	331
31	110.0"	0.88	321
32	154.0"	0.89	319
	<b>Absolute Avgs.</b>	<b>1.09 (<math>\Delta P</math>)</b>	<b>253.0 F</b>


# PRE-TEST FLOW TRAVERSE

(Method 1-2)

## RUN 3

<b>Date:</b>	May 21, 2004	<b>Box ID:</b>	A-1
<b>Barometric:</b>	30.04	<b>Probe Type:</b>	Type-S
<b>Stack Dia:</b>	278" x 176"	<b>Probe No:</b>	12.1x2
<b>Pitot Cp:</b>	0.84	<b>Pitot Check:</b>	Good

Traverse Points	Percent of Dia.	Vel. Head ( $\Delta P$ )	Temp (deg F.)
1 - Port 1	22.0"	1.30	188
2	66.0"	1.30	189
3	110.0"	1.25	192
4	154.0"	1.35	198
5 - Port 2	22.0"	1.25	201
6	66.0"	0.90	212
7	110.0"	0.95	222
8	154.0"	0.90	219
9 - Port 3	22.0"	1.0	191
10	66.0"	0.98	198
11	110.0"	0.90	209
12	154.0"	0.95	219
13 - Port 4	22.0"	0.92	224
14	66.0"	0.90	225
15	110.0"	1.05	225
16	154.0"	1.15	218
17 - Port 5	22.0"	0.90	222
18	66.0"	0.85	235
19	110.0"	1.05	238
20	154.0"	1.15	242
21 - Port 6	22.0"	1.35	245
22	66.0"	1.35	228
23	110.0"	1.40	232
24	154.0"	1.10	233
25 - Port 7	22.0"	1.35	236
26	66.0"	1.45	232
27	110.0"	1.40	238
28	154.0"	1.30	245
29 - Port 8	22.0"	0.98	248
30	66.0"	0.78	252
31	110.0"	0.87	258
32	154.0"	0.89	264
	<b>Absolute Avgs.</b>	<b>1.10 (<math>\Delta P</math>)</b>	<b>217.3 F</b>



**VELOCITY TRAVERSE POINT DETERMINATION**  
(EPA Method 1)

**Nucor Steel**  
PPFF Baghouse Compartment

@

**Crawfordsville, Indiana**


**Depth-in :** 366 **Dia. (inches)** 304.03  
**Width-in :** 260 **Ports:** 2

**Points Per Port:**

	2	4	5	6	10	13
1	91.50	45.75	36.60	<b>30.50</b>	18.30	14.08
2	274.50	137.25	109.80	<b>91.50</b>	54.90	42.23
3		228.75	183.00	<b>152.50</b>	91.50	70.38
4		320.25	256.20	<b>213.50</b>	128.10	98.54
5			329.40	<b>274.50</b>	164.70	126.69
6				<b>335.50</b>	201.30	154.85
7					237.90	183.00
8					274.50	211.15
9					311.10	239.31
10						267.46
11						295.62
12						323.77
13						351.92

**Spacing**

0.00	91.50	73.20	<b>61.00</b>	36.60	28.15
------	-------	-------	--------------	-------	-------



**VELOCITY TRAVERSE POINT DETERMINATION**  
(EPA Method 1)

**Nucor Steel**  
PPFF Baghouse Compartment

@

**Crawfordsville, Indiana**


**Depth-in :** 176 **Dia. (inches)** 215.54  
**Height-in :** 278 **Ports:** 8

**Points Per Port:**

	2	4	5	8	10	13
1	44.00	22.00	17.60	11.00	8.80	6.77
2	132.00	66.00	52.80	33.00	26.40	20.31
3		110.00	88.00	55.00	44.00	33.85
4		154.00	123.20	77.00	61.60	47.38
5			158.40	99.00	79.20	60.92
6				121.00	96.80	74.46
7				143.00	114.40	88.00
8				165.00	132.00	101.54
9					149.60	115.08
10						128.62
11						142.15
12						155.69
13						169.23

**Spacing**

0.00	44.00	35.20	22.00	17.60	13.54
------	-------	-------	-------	-------	-------



**AIR TEST PROFESSIONALS' FIELD DATA SHEET**

RMPMWD TESTING


EPA METHOD 1-S/202/9

RUN 1

PAGE 1 of 2

CLIENT	NUCOR STEEL	METER BOX ID	A-1	K FACTOR	840	DUCT DIMENSIONS (in.)	
LOCATION	CLAYTON, MISSOURI, IN	METER ΔH	1.72	PROBE LENGTH (in.)	0.0	PORT LENGTH (in.)	0.0
UNIT	PIFF BATHHOUSE	PROBE ID	0.87	PROBE LINER	TEPCON	SILICA ID	R1 #4
DATE	05-19-04	PROJECT #	3A	NOZZLE ID	1.08	TEDLAR BAG ID	
METER OPERATOR	CARLOS BROWN	BAROMETRIC	30.08	AMBIENT TEMP (°F)		PASS	<input checked="" type="checkbox"/> O <sub>2</sub> 19.0 <input type="checkbox"/> CO <sub>2</sub> 0.0
PROBE OPERATOR	TERRY KAUFFMAN	STATIC PRESSURE (in. H <sub>2</sub> O)				H <sub>2</sub> O (mL)	6.0
VISIBLE EMISSIONS READER	ANDY YOUNG	LEAK RATE BEFORE (dm)	0.000	@ (in. Hg)	2.0"	SILICA GEL (g)	9.6
CLIENT CONTACT	MARK WASHER	LEAK RATE AFTER (dm)	0.000	@ (in. Hg)	8"	TOTAL Vg	69.6
AGENCY CONTACT	ALAN FISHER	START TIME	15:57	STOP TIME	21:29		

Traverse Point Number	Min/Point	Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tp (°F)	Filter		Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
								Set Points	Tt (°F)					
1	6.0		0.0015	0.97	393.070	208				68	92	92	5.5	
2	12.0			0.97	400.0					66	93	93	5.5	
3	18.0			0.97	403.5					69	94	94	5.5	
4	24.0			0.97	407.5					54	94	92	5.5	
5	30.0			0.97	410.3					51	95	92	5.5	
6	36.0			0.97	411.1					52	94	93	5.5	
7	42.0			0.97	417.5					52	95	93	5.5	
8	48.0			0.97	420.7					54	91	91	5.5	
9	54.0			0.97	424.2					58	86	88	5.5	
10	60.0			0.97	427.7					53	85	86	5.0	
11	66.0			0.97	431.2					54	86	86	5.0	
12	72.0			0.97	434.4					56	86	85	5.0	
13	78.0			0.97	437.8	298				64	85	85	5.0	
14	84.0			0.97	442.0					53	86	85	5.0	
15	90.0			0.97	444.9					54	87	85	5.0	
16	96.0			0.97	448.3					54	87	85	5.0	Shut Down
17	102.0			0.97	451.6					55	87	85	5.0	APPROX 95 MIN
18	108.0			0.97	455.1					56	87	84	5.0	
19	114.0			0.97	458.4					59	86	84	5.0	
20	120.0			0.97	461.8					56	86	84	5.0	
21	126.0			0.97	465.3					57	86	84	5.0	
22	132.0			0.97	468.6					58	86	84	5.0	
23	138.0			0.97	472.0					58	86	84	5.0	
24	144.0			0.97	475.5	208				59	86	84	5.0	
25	150.0			0.97	478.9					64	85	84	5.0	
26	156.0			0.97	482.2					57	86	84	5.0	
27	162.0			0.97	485.9					56	86	84	5.0	
28	168.0			0.97	490.0					56	86	84	5.0	
29	174.0			0.97	492.6					56	86	84	5.0	
30	180.0			0.97	496.2					56	86	84	5.5	




AIR TEST PROFESSIONALS FIELD DATA SHEET

PM/PM10 TESTING

EPA METHOD 1-5/202/9 RUN 1

PAGE 2 of 2

Traverse Point Number	MiniPoint Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tp (°F)	Filter Tt (°F)	Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
31	186		0.97	199.51				56	85	84	5.0	
32	192		0.97	503.4				56	86	84	5.0	
33	198		0.97	506.2				57	87	84	5.0	
34	204		0.97	509.6				57	88	84	5.0	
35	210		0.97	513.0				58	88	85	5.0	
36	216		0.97	516.5				59	89	85	5.0	
37	222		0.97	520.0	208			61	88	85	5.0	
38	228		0.97	523.5				60	89	86	5.0	
39	234		0.97	527.1				61	89	86	5.0	
40	240		0.97	530.6				62	89	86	5.0	
41	246		0.97	534.1				64	89	86	5.0	
42	252		0.97	537.1				63	92	87	5.0	
43	258		0.97	540.4				65	94	89	5.0	
44	264		0.97	543.0				60	95	91	5.0	
45	270		0.97	547.2				59	95	91	5.0	
46	276		0.97	550.6				59	95	91	5.0	
47	282		0.97	554.1				59	94	91	5.0	
48	288		0.97	557.558				59	94	91	5.0	
164.488												





AIR TEST PROFESSIONALS FIELD DATA SHEET

PM/PM10 TESTING

EPA METHOD 1-5/202/9

RUN 2

PAGE 1 of 2

CLIENT	Nucor Steel		
LOCATION	Crawfordsville, IN		
UNIT	PPF Bldg House		
DATE	05-21-04 PROJECT#		
METER OPERATOR	CARLOS BROWN		
PROBE OPERATOR			
VISIBLE EMISSIONS READER			
CLIENT CONTACT			
AGENCY CONTACT			
METER BOX ID	A-1	K FACTOR	
METER Y	1.002	METER ΔH@	1.72
PITOT Cd	0.84	PROBE LINER	TEFLON
PROBE ID	3-A	NOZZLE ID	1.0"
BAROMETRIC	30.04	AMBIENT TEMP (°F)	
STATIC PRESSURE (in. H <sub>2</sub> O)			
LEAK RATE BEFORE (cfm)	0.000	@ (in. Hg)	11"
LEAK RATE AFTER (cfm)	0.000	@ (in. Hg)	8"
START TIME	0717	STOP TIME	12:14

Diagram of Test Location

DUCT DIMENSIONS (in.)  
PORT LENGTH (in.) 0.0  
FILTER ID R2 SILICA ID #5  
TEDLAR BAG ID

PITOT CHECK  
PASS  FAIL


O<sub>2</sub>  
CO<sub>2</sub>

H<sub>2</sub>O (ml) 62

SILICA GEL (g) 10.5

TOTAL V<sub>0</sub> 72.5

Traverse Point Number	Min/Point Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tp (°F)	Filter Tf (°F)	Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
1	6	0.08115	0.97	557.78	208			66	82	81	4.0	
2	12		0.97	564.7				64	83	81	4.0	
3	18		0.97	567.9				63	84	82	4.0	
4	24		0.97	571.5				62	85	83	4.0	
5	30		0.97	574.7				62	85	83	4.0	
6	36		0.97	578.0				60	85	83	4.0	
7	42		0.97	581.4				60	89	85	4.0	
8	48		0.97	584.9				59	90	86	4.0	
9	54		0.97	588.4				58	90	86	4.0	
10	60		0.97	591.9				58	90	88	4.0	
11	66		0.97	595.4				59	90	88	4.0	
12	72		0.97	598.5				59	90	89	4.0	
13	78		0.97	602.0	215			60	91	91	4.0	
14	84		0.97	605.5				61	93	91	4.0	
15	90		0.97	609.0				61	95	91	4.0	
16	96		0.97	612.4				62	96	92	4.0	
17	102		0.97	615.9				60	96	92	4.0	
18	108		0.97	619.4				60	96	92	4.0	
19	114		0.97	622.9				56	96	92	4.0	
20	120		0.97	626.2				56	96	93	4.0	
21	126		0.97	629.6				57	97	93	4.0	
22	132		0.97	633.0				57	97	94	4.0	
23	138		0.97	636.4				57	97	94	4.0	
24	144		0.97	640.0	195			56	97	94	4.0	
25	150		0.97	643.4				56	99	94	4.0	
26	156		0.97	646.9				58	98	94	4.0	
27	162		0.97	650.3				58	98	95	4.0	
28	168		0.97	653.7				59	99	95	4.0	
29	174		0.97	657.1				60	99	95	4.0	
30	180		0.97	660.5				61	100	96	4.0	



**AIR TEST PROFESSIONALS FIELD DATA SHEET**


PM/PM10 TEST

EPA METHOD 1-5/2002/9 RUN 2

PAGE 1 2

CLIENT: NORCO STEEL METER BOX ID: A L 1 K FACTOR: 840 DUCT DIMENSIONS (in.):  
 LOCATION: Chattanooga, TN METER: 1.002 METER ΔH: 1.72 PORT LENGTH (in.):  
 UNIT: PPFF BARTHOLOME PITOT Cp: 0.84 PROBE LINER: TEFLON FILTER ID: R2 SILICA ID: #3  
 DATE: 05-21-04 PROJECT #: 1.04 NOZZLE ID: 1.04 TEDLAR BAG ID:  
 METER OPERATOR: Carlos Brown BAROMETRIC: 30.04 AMBIENT TEMP (°F):  
 PROBE OPERATOR: Carlos Brown STATIC PRESSURE (in. H<sub>2</sub>O):  
 VISIBLE EMISSIONS READER: 0.000 @ (in. Hg) 62.0  
 CLIENT CONTACT: 1214 SILICA GEL (g) 10.5  
 AGENCY CONTACT: 1214 STOP TIME 72.5

Traverse Point Number	MiniPoint Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tp (°F)	Filter T1 (°F)	Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
31	186	0.0015	0.97	663.6				61	101	96	4.0	
32	192		0.97	667.2				60	101	97	4.0	
33	198		0.97	670.8				59	102	98	4.0	
34	204		0.97	674.4				60	102	99	4.0	
35	210		0.97	678.0				60	102	99	4.0	
36	216		0.97	681.6				61	103	99	4.0	
37	222		0.97	685.3	221			62	103	100	4.0	
38	228		0.97	688.7				62	103	100	4.0	
39	234		0.97	692.4				62	103	100	4.0	
40	240		0.97	696.1				64	103	100	4.0	
41	246		0.97	699.7				60	103	100	4.0	
42	252		0.97	703.3				58	104	100	4.0	
43	258		0.97	706.9				57	104	101	4.0	
44	264		0.97	710.5				56	104	101	4.0	
45	270		0.97	714.1				56	104	101	4.0	
46	276		0.97	717.7				58	105	101	4.0	
47	282		0.97	721.3				57	105	102	4.0	
48	288		0.97	724.950				59	105	102	4.0	



AIR TEST PROFESSIONALS FIELD DATA SHEET

PM/PM10 TESTING


EPA METHOD 5/202

RUN 3

PAGE 1 of 2

CLIENT Nucor Steel METER BOX ID A-11 K FACTOR 850 DUCT DIMENSIONS (in.)  
 LOCATION Chattanooga, TN METER 1.002 METER ΔH @ 1.72 PORT LENGTH (in.) 0.0  
 UNIT PPFF BAGHOUSE PITOT Co. 0.84 PROBE LINER TEFLON FILTER ID R.3 SILICA ID #6  
 DATE 5-21-04 PROJECT # Andrew Young NOZZLE ID 1.0 TEDLAR BAG ID  
 METER OPERATOR Andrew Young BAROMETRIC 30.08 AMBIENT TEMP (°F) 85.0 PASS  FAIL   
 PROBE OPERATOR Andrew Young STATIC PRESSURE (in. H<sub>2</sub>O) 3.0 LEAK RATE BEFORE (cm) 0.000 @ (in. Hg) 13" H<sub>2</sub>O (ml) 60  
 VISIBLE EMISSIONS READER LEAK RATE AFTER (cm) 0.000 @ (in. Hg) 10" SILICA GEL (g) 11.1  
 CLIENT CONTACT Andrew Young START TIME 1307 STOP TIME 1754 TOTAL Vols 71.1  
 AGENCY CONTACT

Traverse Point Number	Min/Point Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tp (°F)	Filter Tt (°F)	Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
1	6.0	0.00115	0.98	723.155	187			67	102	101	4	
2	12		0.98	730.3				66	102	101	4	START K' @
3	18		0.98	733.8				66	103	102	4	850
4	24		0.98	737.4				65	103	102	4	(INCREASED Tm)
5	30		0.98	741.0				64	104	102	4	
6	36		0.98	744.5				65	105	102	4	
7	42		0.98	748.0				65	105	103	4	
8	48		0.98	751.6				64	106	103	4	
9	54		0.98	755.2				64	106	103	4	
10	60		0.98	758.8				64	106	103	4	
11	66		0.98	762.3				62	106	103	4	
12	72		0.98	765.9				62	106	103	4	
13	78		0.98	769.4	228			61	106	103	4	
14	84		0.98	772.9				62	106	103	4	
15	90		0.98	776.5				63	107	104	4	
16	96		0.98	780.1				63	108	105	4	
17	102		0.98	783.7				64	108	105	4	
18	108		0.98	787.2				64	108	105	4	
19	114		0.98	790.8				65	108	105	4	
20	120		0.98	794.4				66	108	105	4	
21	126		0.98	797.9				66	111	106	4	
22	132		0.98	801.5				66	110	107	4	
23	138		0.98	805.0				67	110	108	4	
24	144		0.98	808.6				67	111	108	4	
25	150		0.98	812.2	262			63	110	107	4	
26	156		0.98	815.7				60	110	108	4	
27	162		0.98	819.3				58	110	108	4	
28	168		0.98	822.8				59	110	107	4	
29	174		0.98	826.4				61	109	107	4	
30	180		0.98	829.9				62	109	107	4	





**AIR TEST PROFESSIONALS FIELD DATA SHEET**

METALS TESTING

EPA METHOD 1-4/29

RUN 1

PAGE 1 OF 1

CLIENT Nucor Steel METER BOX ID A-2 K FACTOR 52.5 DUCT DIMENSIONS (in.)

LOCATION Cranford, NJ METER ΔH @ 1.827 PORT LENGTH (in.) 0.0

UNIT PIPE BENTHOUSE PITOT Co. 0.84 PROBE LINER TERNAJ FILTER ID R1 SILICA ID E1

DATE 05-19-04 PROJECT # 0.50" NOZZLE ID 0.50" TEDLAR BAG ID

METER OPERATOR Carlos BROWN BAROMETRIC 30.08 AMBIENT TEMP (°F)

PROBE OPERATOR TERRY KAUFMAN STATIC PRESSURE (in. H<sub>2</sub>O)


VISIBLE EMISSIONS READER ANDY YOUNG LEAK RATE BEFORE (cfm) 0.000 @ (in. Hg) 12" H<sub>2</sub>O (ml) 20

CLIENT CONTACT ANDY YOUNG LEAK RATE AFTER (cfm) 0.000 @ (in. Hg) 5" SILICA GEL (g) 12.3

AGENCY CONTACT START TIME 15:58 STOP TIME 2:30 TOTAL Vg 32.3

Traverse Point Number	MiniPoint Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tp (°F)	Filter Tf (°F)	Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
1	6	0.00115	0.060	878.276	208			68	88	88	2.0	
2	12			879.9				68	87	88	2.0	
3	18			880.7				68	89	88	2.0	
4	24			881.6				63	88	88	2.0	
5	30			882.4				58	88	88	2.0	
6	36			883.2				58	89	89	2.0	
7	42			884.1				58	89	89	2.0	
8	48			885.0				57	86	86	2.0	
9	54			885.8				57	83	84	2.0	
10	60			886.6				56	82	83	2.0	
11	66			887.4				56	82	83	2.0	
12	72			888.2				64	82	82	2.0	
13	78			889.0	208			66	83	84	2.0	
14	84			889.8				61	82	84	2.0	
15	90			890.6				58	82	82	2.0	
16	96			891.3				59	82	82	2.0	
17	102			892.1				60	82	82	2.0	
18	108			892.9				63	82	82	2.0	
19	114			893.7				67	82	82	2.0	
20	120			894.5				65	82	82	2.0	
21	126			895.3				65	82	82	2.0	
22	132			896.1				64	82	82	2.0	
23	138			896.8				64	82	82	2.0	
24	144			897.6				64	82	82	2.0	
25	150			898.4	208			67	81	82	2.0	
26	156			899.2				64	82	82	2.0	
27	162			900.0				62	82	82	2.0	
28	168			900.8				62	82	82	2.0	
29	174			901.6				62	82	81	2.0	
30	180			902.4				62	82	81	2.0	

Shut Down  
Approx 45 MIN



AIR TEST PROFESSIONALS FIELD DATA SHEET

TESTING

RUN 1


PAGE 2 of 2

1-8/29

CLIENT NUCOR STEEL METER BOX ID A-2 K FACTOR \_\_\_\_\_ DUCT DIMENSIONS (in.) \_\_\_\_\_  
 LOCATION CRANFORD, N.J. METER ΔH @ 1.829 PORT LENGTH (in.) 0.0 Diagram of Test Location \_\_\_\_\_  
 UNIT PPF BASTHOUSE PITOT C<sub>p</sub> 0.84 PROBE LINER TERCON FILTER ID R1 SILICA ID \_\_\_\_\_  
 DATE 05-19-04 PROJECT # \_\_\_\_\_ NOZZLE ID 0.50 TEDLAR BAG ID \_\_\_\_\_  
 METER OPERATOR ARCO'S BROWN BAROMETRIC 30.08 AMBIENT TEMP (°F) \_\_\_\_\_  
 PROBE OPERATOR TERRY KAUFFMAN STATIC PRESSURE (in. H<sub>2</sub>O) \_\_\_\_\_  
 VISIBLE EMISSIONS READER ANDY GOURG LEAK RATE BEFORE (gim) @ (in. Hg) 2.0  
 CLIENT CONTACT MARIL WASHBURN LEAK RATE AFTER (gim) @ (in. Hg) 5.1 SILICA GEL (g) 12.3  
 AGENCY CONTACT ARCO FISHER START TIME 15:58 STOP TIME 2:30 TOTAL V<sub>ic</sub> 32.3

Traverse Point Number	Min/Point Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume V <sub>m</sub> (ft <sup>3</sup> )	Stack Temp. T <sub>s</sub> (°F)	Probe Temp. T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>m</sub> (°F)	DGM Outlet T <sub>m</sub> (°F)	Pump Vacuum (in. Hg)	Notes
31	186		0.06	903.2				66	82	81	2.0	
32	192		0.06	904.0				64	82	82	2.0	
33	198		0.06	904.7				64	84	82	2.0	
34	204		0.06	905.5				65	83	82	2.0	
35	210		0.06	906.3				67	83	82	2.0	
36	216		0.06	907.1				66	83	82	2.0	
37	222		0.06	908.0	208			67	83	83	2.0	
38	228		0.06	908.8				68	83	83	2.0	
39	234		0.06	909.6				67	83	83	2.0	
40	240		0.06	910.5				67	83	83	2.0	
41	246		0.06	911.3				67	83	82	2.0	
42	252		0.06	912.2				68	85	84	2.0	
43	258		0.06	913.0				69	86	87	2.0	
44	264		0.06	913.5				67	88	88	2.0	
45	270		0.06	914.6				67	88	87	2.0	
46	276		0.06	915.5				66	88	88	2.0	
47	282		0.06	916.3				65	87	87	2.0	
48	288		0.06	917.17				65	87	87	2.0	

38.894



**AIR TEST PROFESSIONALS FIELD DATA SHEET**


TESTING

RUN 2

PAGE 1 of 2

CLIENT Nucor Steel METER BOX ID A-2 K FACTOR 52.5 DUCT DIMENSIONS (in.)  
 LOCATION Crawfordsville, IN METER ΔH@ 1.829 PORT LENGTH (in.) 0.0 Diagram of Test Location  
 UNIT PPF Baghouse PROJECT # 1219 FILTER ID R-2 SILICA ID #2  
 DATE 05-21-04 NOZZLE ID 0.50" TEDLAR BAG ID  
 METER OPERATOR Charles Brodow AMBIENT TEMP (°F) O<sub>2</sub>  
 PROBE OPERATOR 3'B BAROMETRIC 30.04 STATIC PRESSURE (in. H<sub>2</sub>O) CO<sub>2</sub>  
 LEAK RATE BEFORE (cfm) 0.000 @ (in. Hg) 12" H<sub>2</sub>O (ml) 22.0  
 LEAK RATE AFTER (cfm) 0.000 @ (in. Hg) 9" SILICA GEL (g) 8.2  
 START TIME 0917 STOP TIME 1219 TOTAL Vc 30.2

Traverse Point Number	MiniPoint		Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tp (°F)	Filter Tf (°F)	Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
	Elapsed Time	Set Points											
1	6		0.0015	0.060	917.32	212			66	80	81	2.0	
2	12			0.06	918.9				66	81	81	2.0	
3	18			0.06	919.7				65	81	81	2.0	
4	24			0.06	920.5				64	82	81	2.0	
5	30			0.06	921.2				64	82	81	2.0	
6	36			0.06	922.0				63	83	82	2.0	
7	42			0.06	922.8				66	83	83	2.0	
8	48			0.06	923.6				64	85	84	2.0	
9	54			0.06	924.4				64	86	84	2.0	
10	60			0.06	925.2				65	87	85	2.0	
11	66			0.06	926.0				65	87	86	2.0	
12	72			0.06	926.8	198			66	89	86	2.0	
13	78			0.06	927.6				66	90	86	2.0	
14	84			0.06	928.4				67	90	88	2.0	
15	90			0.06	929.2				68	90	89	2.0	
16	96			0.06	930.0				62	91	90	2.0	
17	102			0.06	930.8				62	91	90	2.0	
18	108			0.06	931.6				63	91	90	2.0	
19	114			0.06	932.3				63	92	91	2.0	
20	120			0.06	933.4				63	92	91	2.0	
21	126			0.06	934.5				64	93	91	2.0	
22	132			0.06	935.4				64	93	92	2.0	
23	138			0.06	936.2				65	93	92	2.0	
24	144			0.06	937.0				66	93	92	2.0	
25	150			0.06	937.8	229			66	94	93	2.0	
26	156			0.06	938.6				66	94	93	2.0	
27	162			0.06	939.4				67	94	94	2.0	
28	168			0.06	940.2				67	95	94	2.0	
29	174			0.06	941.1				67	95	94	2.0	
30	180			0.06	942.0				68	96	95	2.0	



**AIR TEST PROFESSIONALS FIELD DATA SHEET**

Metals TESTING


EPA METHOD 1-4/29

RUN 2

PAGE 2 Of 2

CLIENT	Nucor Steel	METER BOX ID	A-2	K FACTOR		DUCT DIMENSIONS (in.)		Diagram of Test Location
LOCATION	Crawfordsville, IN	METER ΔH	0.99	METER ΔH @	1.829	PORT LENGTH (in.)	0.0	
UNIT	DPF BARNHOUSE	PITOT Cp	0.84	PROBE LINER	TEFLON	FILTER ID	2.2	SILICA ID
DATE		PROJECT #		NOZZLE ID	0.5"	TEFLAR BAG ID		
METER OPERATOR	CARLOS BROWN	BAROMETRIC	30.24	AMBIENT TEMP (°F)		PITOT CHECK		O <sub>2</sub>
PROBE OPERATOR		STATIC PRESSURE (in. H <sub>2</sub> O)				PASS	<input type="checkbox"/>	FAIL
VISIBLE EMISSIONS READER		LEAK RATE BEFORE (cfm)		@ (in. Hg)		H <sub>2</sub> O (mL)		22.0
CLIENT CONTACT		LEAK RATE AFTER (cfm)	0.000	@ (in. Hg)	9"	SILICA GEL (g)		8.2
AGENCY CONTACT		START TIME	07:17	STOP TIME	12:14	TOTAL Vc		30.2

Traverse Point Number	MiniPoint Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tp (°F)	Filter Tt (°F)	Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
31	186	0.0015	0.06	942.9				66	97	96	2.0	
32	192		0.06	943.8				64	97	97	2.0	
33	198		0.06	944.6				64	98	97	2.0	
34	204		0.06	945.5				64	98	97	2.0	
35	210		0.06	946.3				65	98	98	2.0	
36	216		0.06	947.4				65	99	98	2.0	
37	222		0.06	948.2	188			65	100	99	2.0	
38	228		0.06	949.2				66	100	99	2.0	
39	234		0.06	950.0				66	100	99	2.0	
40	240		0.06	950.8				67	100	100	2.0	
41	246		0.06	951.6				68	101	101	2.0	
42	252		0.06	952.4				62	101	101	2.0	
43	258		0.06	953.6				63	102	102	2.0	
44	264		0.06	954.4				60	102	102	2.0	
45	270		0.06	955.2				62	102	102	2.0	
46	276		0.06	956.0				64	102	102	2.0	
47	282		0.06	956.8				65	102	102	2.0	
48	288		0.06	958.470				66	103	102	2.0	





AIR TEST PROFESSIONALS FIELD DATA SHEET

ETAALS TESTING


EPA METHOD 29

RUN 3

PAGE 1 of 2

CLIENT Nucor Steel METER BOX ID A-2 KFACTOR 52.5 DUCT DIMENSIONS (in.)  
 LOCATION Crawfordsville, IN METER AH@ 1.829 PORT LENGTH (in.) 0  
 UNIT PFT BAKHOUSE PITOT Cp 0.84 PROBE LINER TEFLON FILTER ID R3 SILICA ID #3  
 DATE 05-21-04 PROJECT # 1 PROBE ID 3'-B NOZZLE ID 0.507 TEDLAR BAG ID  
 METER OPERATOR Andrew Young BAROMETRIC 30.08 AMBIENT TEMP (°F)  
 PROBE OPERATOR Andrew Young STATIC PRESSURE (in. H<sub>2</sub>O)  
 VISBLE EMISSIONS READER LEAK RATE BEFORE (cfm) 0.000 @ (in. Hg) 1"  
 CLIENT CONTACT LEAK RATE AFTER (cfm) 0.000 @ (in. Hg) 8" H<sub>2</sub>O (mL) 24.0  
 AGENCY CONTACT START TIME 13:07 STOP TIME 17:54 SILICA GEL (g) 7.7  
 TOTAL Vc 31.7

Traverse Point Number	Min/Point Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tp (°F)	Filter TT (°F)	Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
1	6	0.0015	0.06	958.73c	202			67	102	102	2	
2	12		0.06	960.4				67	102	102	2	
3	18		0.06	961.3				66	102	102	2	
4	24		0.06	962.1				67	102	102	2	
5	30		0.06	962.9				67	102	102	2	
6	36		0.06	963.8				66	102	102	2	
7	42		0.06	964.6				66	102	102	2	
8	48		0.06	965.4				66	102	102	2	
9	54		0.06	966.3				66	102	102	2	
10	60		0.06	967.1				66	102	103	2	
11	66		0.06	967.9				66	103	103	2	
12	72		0.06	968.8				65	103	103	2	
13	78		0.06	969.6	214			65	103	103	2	
14	84		0.06	970.4				65	102	102	2	
15	90		0.06	971.3				65	104	103	2	
16	96		0.06	972.1				66	104	103	2	
17	102		0.06	972.9				66	104	103	2	
18	108		0.06	973.8				66	104	103	2	
19	114		0.06	974.6				66	106	103	2	
20	120		0.06	975.5				67	106	103	2	
21	126		0.06	976.3				67	106	105	2	
22	132		0.06	977.1				66	106	105	2	
23	138		0.06	977.9				66	106	105	2	
24	144		0.06	978.8				63	106	105	2	
25	150		0.06	979.6	201			61	104	105	2	
26	156		0.06	980.5				61	104	105	2	
27	162		0.06	981.3				62	105	105	2	
28	168		0.06	982.1				62	105	105	2	
29	174		0.06	982.9				63	104	104	2	
30	180		0.06	983.8				63	104	104	2	



AIR TEST PROFESSIONALS FIELD DATA SHEET

Metals TESTING


EPA METHOD 29

RUN 3

PAGE 2 2

CLIENT NUCOR STEEL METER BOX ID A-2 KFACTOR 32.5 DUCT DIMENSIONS (in.)  
 LOCATION CRAWFORDSVILLE IA METER AH@ 1.829 PORT LENGTH (in.) 0"  
 UNIT PPF BASHOUSE PITOT Cp 0.84 PROBE LINER TEFLON FILTER ID R3 SILICA ID  
 DATE 5-21-04 PROJECT # A. YOUNG PROBE ID 3-B NOZZLE ID 0.50" TEDLAR BAG ID  
 METER OPERATOR A. YOUNG BAROMETRIC 30.08 AMBIENT TEMP (°F) 65.7 PITOT CHECK  
 PROBE OPERATOR A. YOUNG STATIC PRESSURE (in. H<sub>2</sub>O) 0.00 @ (in. Hg) 8" H<sub>2</sub>O (mL) 24.0  
 VISIBLE EMISSIONS READER LEAK RATE BEFORE (cfm) 0.000 @ (in. Hg) 8" SILICA GEL (g) 7.7  
 CLIENT CONTACT LEAK RATE AFTER (cfm) 0.000 @ (in. Hg) 8" TOTAL Vc 31.7  
 AGENCY CONTACT START TIME 1307 STOP TIME 1754

Traverse Point Number	MiniPoint Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tp (°F)	Filter Tf (°F)	Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
31	186	0.00115	0.06	984.6	↓	64	103	103	2			
32	192		0.06	985.5		66	103	103	2			
33	198		0.06	986.3		62	103	103	2			
34	204		0.06	987.1		66	103	102	2			
35	210		0.06	987.9		66	102	102	2			
36	216		0.06	988.8	↓	65	102	102	2			
37	222		0.06	989.6	214	65	102	102	2			
38	228		0.06	990.5		66	102	102	2			
39	234		0.06	991.3		66	102	102	2			
40	240		0.06	992.2		67	102	102	2			
41	246		0.06	993.0		67	102	102	2			
42	252		0.06	993.8		66	102	102	2			
43	258		0.06	994.7		66	102	102	2			
44	264		0.06	995.5		64	102	102	2			
45	270		0.06	996.4		63	102	102	2			
46	276		0.06	997.2		63	102	102	2			
47	282		0.06	998.0	↓	64	102	102	2			
48	288		0.06	998.858		62	102	102	2			



**LABORATORY DATA**

**PARTICULATE WEIGHT SHEET**

**Source:** Nucor Steel – PPF Baghouse

Date:	05/19/04	05/21/04	05/21/04	
<b>Velocity</b>	<b>Blank</b>			
Run ID#	A-1	A11	A12	B11
Tare Wt	66.3424	62.6815	63.8495	90.9058
Gross Wt	66.3424	62.6833	63.8497	90.9066
Correction	0.0000	0.0000	0.0000	0.0000
Net Wt	0.0000	0.0018	0.0002	0.0008
<b>Filter</b>	<b>1</b>			<b>3</b>
Run ID#	R1		R2	R3
Tare Wt	2.7671		2.6843	2.3875
Gross Wt	2.7773		2.6948	2.3965
Net Wt	0.0102		0.0105	0.0090
<b>Total Gain</b>	<b>0.0120</b>	<b>0.0107</b>	<b>0.0098</b>	

# **Air Test Professionals, Inc.**

1201 North Graham Avenue  
Indianapolis, IN 46219

**Nucor Steel – PPF Baghouse**  
PO# 079

**Analytical Report**  
(0604-40)

***EPA Method 202***  
Condensable Particulates

***HPLC Analysis***  
Sulfate



**Enthalpy Analytical, Inc.**

Phone: (919) 850 - 4392 / Fax: (919) 850 - 9012 / [www.enthalpy.com](http://www.enthalpy.com)  
2202 Ellis Road Durham, NC 27703 - 5518

I certify that to the best of my knowledge all analytical data presented in this report:

- Have been checked for completeness
- Are accurate, error-free, and legible
- Have been conducted in accordance with approved protocol, and that all deviations and analytical problems are summarized in the appropriate narrative(s)
- This analytical report was prepared in Portable Document Format (.PDF) and contains 57 pages.

*Michael Steven Schapira*

QA Review Performed by: Michael Steven Schapira



# Summary of Results



**EPA Method 202 - Condensible Particulate Determination - Data Analysis**

Company	ATP, Inc.
Analyst	SLG
Parameters	Method 202
# Samples	3 Runs and 1 Blank

Client #	Nucor Steel
Job #	0604-40
PO #	079
Report Date	6/18/2004

**Analysis of Particulate Recovery**

Sample ID Number	Run # 1	Run # 2	Run # 3
<b>Organic</b>			
Beaker Number	5500	5484	5501
Final Weight, g	0.9784	0.9735	0.9778
Reweigh, Final, g	0.9782	0.9733	0.9776
Beaker Tare Weight, g	0.9748	0.9701	0.9719
Beaker Tare Reweigh, Initial, g	0.9746	0.9701	0.9718
Solvent Blank, g	0.0010	0.0009	0.0011
MeCl2 FV, mL	220	194	248
Net Organic Catch, mg	2.6	2.3	4.7
<b>Inorganic</b>			
Beaker Number	5517	5512	5511
Final Weight, g	0.9873	0.9877	0.9823
Reweigh, Final, g	0.9871	0.9876	0.9824
Beaker Tare Weight, g	0.9662	0.9649	0.9641
Beaker Tare Reweigh, Initial, g	0.9660	0.9646	0.9640
Water Blank, g	0.0004	0.0004	0.0004
Sample Final Volume, mL	474	478	528
Sulfate aliquot, mL	10	10	10
Sulfate aliquot CF	1.02	1.02	1.02
Net Inorganic CF	1.15	1.15	1.15
Net Inorganic, mg	24.5	26.7	21.2
Sulfate Catch, ug	12,496	16,503	10,369
Sulfate Correction, mg	4.4	5.8	3.7
Corrected Inorganic, mg	20.1	20.9	17.6
Condensible Particulate, mg	22.7	23.2	22.3

3.2 => 0.141

19.5 => 0.859

**Blank Analysis**

Sample ID Number	MeCl Blank
Beaker Number	5481
Final Weight, g	0.9660
Reweigh, Final, g	0.9659
Initial Weight, g	0.9658
Reweigh, Initial, g	0.9656
MeCl2 Residue, g	0.0003
MeCl2 Volume, mL	68.0
Max. MeCl2 Residue, g	0.0009

Sample ID Number	H2O Blank
Beaker Number	5514
Final Weight, g	0.9676
Reweigh, Final, g	0.9676
Initial Weight, g	0.9675
Reweigh, Initial, g	0.9673
Water Residue, g	0.0003
Water Volume, mL	388
Max. Water Residue, g	0.0039

Company	ATP, Inc.
Analyst Initials	VKS
Parameters	HPLC Analysis
# Samples	3 runs

Client #	Nucor Steel
Job #	0604-40
PO #	079
Report Date	6/18/2004

Compound	Sample ID / Catch Weight (ug)		
	<i>Run1Pre</i>	<i>Run2Pre</i>	<i>Run3Pre</i>
Sulfate	12,496	16,503	10,369



# Results



Company ATP, Inc.  
 Analyst Initials VKS  
 Parameters HPLC Analysis  
 # Samples 3 runs

Client # Nucor Steel  
 Job # 0604-40  
 PO # 079  
 Report Date 6/18/2004

MDL 0.100 (ug/mL)  
 LOQ 0.600 (ug/mL)

Lower Curve Limit 1.23 (ug/mL)  
 Upper Curve Limit 23.1 (ug/mL)

Compound Sulfate

Sample ID	Lab ID # 1	Lab ID # 2	Analysis Method	Ret Time # 1	Ret Time # 2	% Diff Ret	Conc # 1	Conc # 2	% Diff Conc	Avg Conc (ug/mL)	Vol (mL)	DF	Catch Weight (ug)	Qual
Run1Pre	030-2801.D	030-2802.D	0604-40A.	9.00	9.00	0.0	13.1	13.3	0.9	13.2	474	2	12,496	
Run2Pre	031-2901.D	031-2902.D	0604-40A.	9.00	9.00	0.1	17.3	17.2	0.1	17.3	478	2	16,503	
Run3Pre	032-3001.D	032-3002.D	0604-40A.	9.00	9.00	0.1	19.7	19.6	0.4	19.6	528	1	10,369	
Lab Blank	027-2501.D	027-2502.D	0604-40A.	NA	NA	NA.	0.100	0.100	NA	0.100	1.00	1	0.100	ND
BS / Sulfate 11	028-2601.D	028-2602.D	0604-40A.	9.00	9.00	0.0	5.60	5.53	0.6	5.56	1.00	1	5.56	
													spike amount (ug)	5.90
													recovery (%)	94.3%

# **Narrative Summary**



## Enthalpy Analytical Narrative Summary

<b>Company:</b>	ATP, Inc.
<b>Client #:</b>	Nucor Steel-PPFF Baghouse
<b>PO #</b>	079

<b>Enthalpy #:</b>	0604-40
<b>Analyst:</b>	SLG
<b>Parameters:</b>	EPA Method 202

- Custody** Craig Mefford of Enthalpy Analytical, Inc. received the samples at 25.0°C on 6/11/04 after being relinquished by Air test Professionals, Inc. Prior to analysis the samples were kept under lock with access only by authorized personnel of Enthalpy Analytical, Inc.
- Methodology** All samples were analyzed in accordance to the requirements and specifications of EPA Method 202.
- Instrumentation** All samples were weighed on a Sartorius Model BP 110 S (SN-40707606), certified by Precision Weighing, Inc. through November 4, 2004 (NIST Test # 846895).
- Labeling** OK
- Reporting Notes** The inorganic and organic catch weights are adjusted by a blank correction value. A mathematically determined (theoretical) maximum value is calculated and compared with the actual value measured for each blank. The lower of the two values is used as the blank correction value, which is then factored by the sample volume divided by the blank volume, and subtracted from the sample's catch weight.
- Reporting Notes** None.

## Enthalpy Analytical Narrative Summary

Company:	ATP, Inc.
Client #:	Nucor Steel-PPFF Baghouse
PO #:	079

Enthalpy #:	0604-40
Analyst:	VKS
Parameters:	HPLC Sulfate Analysis

- Custody** Craig Mefford of Enthalpy Analytical, Inc. received the samples at 25.0°C on 6/11/04 after being relinquished by Air Test Professionals, Inc. Prior to analysis the samples were kept under lock with access only by authorized personnel of Enthalpy Analytical, Inc.
- Analysis** The samples were analyzed for sulfate using a Hewlett-Packard series 1100 High Performance Liquid Chromatograph with a Waters 430 conductivity detector and an Alltech ERIS 1000HP Autosuppressor.
- Separation** Separation was accomplished by a Dionex IonPac AS14 250 x 4.0 mm analytical column using 8.0 mM Na<sub>2</sub>CO<sub>3</sub>/1.0 mM NaHCO<sub>3</sub> as the eluent at 1.2 mL per minute. A copy of the analytical method (0604-35A.M) is included.
- Before and after sample analysis, a calibration curve was prepared and analyzed.
- Sulfate eluted at approximately 9.0 minutes, separated well, and was easily identified.
- Blind Spike** A QA blind spike was analyzed along with these samples. The analyst did not know the actual concentration. The QA Reviewer added the actual value into the results spreadsheet, and the recovery value was 94.3%.
- Quality of Data** OK
- Reporting Notes** None

## General Reporting Notes

The following are general reporting notes that are applicable to all Enthalpy Analytical, Inc. reports, unless specifically noted otherwise.

- The symbol **MDL** represents the Minimum Detection Limit. Below this value the laboratory cannot confirm the presence of the analyte of interest reliably.
- The symbol **LOQ** represents the Limit of Quantification. Below this value the laboratory cannot quantitate the analyte of interest within the criteria of the method.
- The symbol **ND** following a value indicates a non-detect or analytical result below the MDL.
- The symbol **J** following a value indicates an analytical result between the MDL and the LOQ. A J flag indicates that the laboratory can positively identify the analyte of interest as present, but the value should be considered an estimate.
- The symbol **E** following a value indicates an analytical result exceeding 100% of the highest calibration point.
- The symbol **DF** represents a Dilution Factor. This number represents dilutions during the extraction and/or laboratory stages of sample treatment. The analytical result taken from a laboratory instrument is multiplied by the DF to get final results.
- The Sample ID **MS** represents a Matrix Spike. An aliquot of an actual sample is spiked with a known amount of analyte so that a percent recovery value can be determined. This shows what effect the sample matrix may have on the target analyte, i.e. whether or not anything in the sample matrix prohibits analysis for the analyte(s).
- The Sample ID **MSD** represents a Matrix Spike Duplicate. Prepared in the same manner as an MS, the use of duplicate matrix spikes allows further confirmation of laboratory quality by showing the consistency of results gained by performing the same steps multiple times. Most methods performed by Enthalpy do not require analysis of an MSD.
- The Sample ID **BS** represents a Blind Spike. A member of the Quality Assurance department has created BS samples for many of the analytes Enthalpy tests for, and only QA and the Enthalpy Analytical ownership have access to the actual values of these samples. The laboratory analyzes them without knowledge of the actual value, and the spreadsheets get completed for these samples solely by the QA group.
- The Sample ID **LCS** represents a Laboratory Control Sample. Whenever spikes are prepared for our clients more spikes are prepared than needed. The extras (randomly chosen) are kept in-house at the appropriate temperature conditions. When the spike samples come back from the client for analysis, the LCSs (usually two are saved) are analyzed to confirm that the analyte could be recovered from the media, separate from the spike samples which were used on the project and which may have had issues caused during collection and/or transport.
- **Significant Figures:** Where the reported value is much greater than unity (1.00) in the units expressed (specifically values of 1,000 or greater), the number is rounded to a whole number of units, rather than to 3 significant figures. For example, a value of 10,456.45 ug catch is rounded to 10,456 ug. There are five significant digits reported, but no confidence should be placed on more than three significant digits.



# Sample Chromatograms




0604-40

```

=====
Injection Date   : 6/16/2004 1:48:04 AM      Seq. Line   : 28
Sample Name     : Run1Pre*2                  Location    : Vial 30
.cq. Operator   : vks                       Inj         : 1
Acq. Instrument : Gonzo                     Inj Volume  : 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method     : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed    : 6/16/2004 1:46:38 AM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed    : 6/16/2004 2:53:40 PM by vks
=====

```

ADC1 B, Dionex ED 40 (0604-35A\030-2801.D)



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier      : 1.0000
Dilution        : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
9.000	VB	763.99048	1.71064e-2	13.06911		Sulfate

```
Totals :                               13.06911
```

Results obtained with enhanced integrator!

```

=====
*** End of Report ***
=====

```




0604-40

```

=====
Injection Date   : 6/16/2004 2:00:45 AM      Seq. Line : 28
Sample Name     : Run1Pre*2                 Location  : Vial 30
Acq. Operator  : vks                       Inj      : 2
Acq. Instrument: Gonzo                     Inj Volume: 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method    : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed   : 6/16/2004 2:00:59 AM by vks
                (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed   : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
9.003	VB	777.22644	1.71039e-2	13.29363		Sulfate

```
Totals :                               13.29363
```

Results obtained with enhanced integrator!

```

=====
*** End of Report ***
=====


```

0604-40

```

=====
Injection Date   : 6/16/2004 2:13:24 AM      Seq. Line : 29
Sample Name     : Run2Pre*2                  Location  : Vial 31
.acq. Operator  : vks                        Inj       : 1
Acq. Instrument : Gonzo                      Inj Volume: 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method     : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed    : 6/16/2004 2:12:02 AM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed    : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier      : 1.0000
Dilution        : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
8.996	VB	1012.27026	1.70711e-2	17.28061		Sulfate

```
Totals :                               17.28061
```

Results obtained with enhanced integrator!

```

=====
*** End of Report ***
=====


```

0604-40

```

=====
Injection Date   : 6/16/2004 2:26:04 AM      Seq. Line   : 29
Sample Name     : Run2Pre*2                 Location    : Vial 31
cq. Operator    : vks                      Inj         : 2
Acq. Instrument : Gonzo                    Inj Volume  : 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method     : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed    : 6/16/2004 2:24:40 AM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed    : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier      : 1.0000
Dilution        : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
9.004	VB	1010.14417	1.70714e-2	17.24454		Sulfate

```
Totals :                               17.24454
```

Results obtained with enhanced integrator!

```

=====
*** End of Report ***
=====


```

0604-40

```

=====
Injection Date   : 6/16/2004 2:38:43 AM           Seq. Line :   30
Sample Name     : Run3Pre                         Location  : Vial 32
Acq. Operator  : vks                             Inj       :    1
Acq. Instrument : Gonzo                          Inj Volume: 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method    : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed   : 6/16/2004 2:37:21 AM by vks
                 (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed   : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier    : 1.0000
Dilution      : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
8.996	VB	1155.48413	1.70577e-2	19.70990		Sulfate

```
Totals :                               19.70990
```

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

0604-40

```

=====
Injection Date : 6/16/2004 2:51:22 AM      Seq. Line : 30
Sample Name    : Run3Pre                    Location  : Vial 32
.cq. Operator  : vks                        Inj       : 2
Acq. Instrument : Gonzo                     Inj Volume: 25 µl
Sequence File  : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method    : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed   : 6/16/2004 2:49:59 AM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed   : 6/16/2004 2:53:40 PM by vks
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier     : 1.0000
Dilution       : 1.0000
    
```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
9.002	VB	1147.12341	1.70584e-2	19.56808		Sulfate

Totals : 19.56808

Results obtained with enhanced integrator!


\*\*\* End of Report \*\*\*

H2O

```

=====
Injection Date   : 6/16/2004 12:31:58 AM      Seq. Line   : 25
Sample Name     : LB                          Location    : Vial 27
cq. Operator    : vks                          Inj         : 1
Acq. Instrument : Gonzo                       Inj Volume  : 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method     : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed    : 6/16/2004 12:30:36 AM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed    : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier      : 1.0000
Dilution        : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
8.989	-	-	-	-	-	Sulfate

Totals : 0.00000

Results obtained with enhanced integrator!

1 Warnings or Errors :


Warning : Calibrated compound(s) not found

H2O

```

=====
Injection Date   : 6/16/2004 12:44:36 AM      Seq. Line :   25
Sample Name     : LB                          Location  : Vial 27
  cq. Operator  : vks                          Inj       :    2
Acq. Instrument : Gonzo                       Inj Volume: 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method     : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed    : 6/16/2004 12:43:14 AM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed    : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier      : 1.0000
Dilution        : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
8.989	-	-	-	-	-	Sulfate

Totals : 0.00000


Results obtained with enhanced integrator!  
 1 Warnings or Errors :

Warning : Calibrated compound(s) not found

```

=====
Injection Date   : 6/16/2004 12:57:15 AM      Seq. Line :   26
Sample Name     : BS/Sulfate11                Location  : Vial 28
Acq. Operator   : vks                        Inj       :    1
Acq. Instrument : Gonzo                      Inj Volume: 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method     : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed    : 6/16/2004 12:55:53 AM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed    : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier      : 1.0000
Dilution        : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
9.001	BB	323.51907	1.73020e-2	5.59753		Sulfate

Totals : 5.59753

Results obtained with enhanced integrator!

```

=====
*** End of Report ***
=====


```



```

=====
Injection Date   : 6/16/2004 1:09:57 AM      Seq. Line :   26
Sample Name     : BS/Sulfate11              Location  : Vial 28
Acq. Operator   : vks                      Inj       :    2
Acq. Instrument : Gonzo                    Inj Volume: 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method     : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed    : 6/16/2004 1:08:33 AM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed    : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      :      Signal
Calib. Data Modified :      Wednesday, June 16, 2004 2:51:47 PM
Multiplier     :      1.0000
Dilution       :      1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
8.999	BB	319.40533	1.73064e-2	5.52775		Sulfate

Totals : 5.52775

Results obtained with enhanced integrator!

```

=====
*** End of Report ***
=====

```

# **Curve(s)/QA Point(s) Chromatograms**



Method Information

Dionex IonPac AS-14A 4-mm analytical (4x250mm) column.  
Flow rate 1.2 mL/min

=====

ANALOG DIGITAL CONVERTER

=====

Signal 1

-----

Description:	Waters 430
Source:	Signal
Unit:	uS
Units/Volt:	1000.000
Peakwidth (Data Rate):	0.027 Min (10.00 Hz)
Stop Time:	No Limit
Data Storage:	Partial:
Start data:	0.01 Min
Stop data:	0.01 Min

```
=====
1100 Quaternary Pump 1
=====
```

## Control

```
Column Flow      :      1.200 ml/min
Stoptime        :      11.00 min
Posttime       :      Off
```

## Solvents

```
Solvent A       :      0.0 % ( )
Solvent B       :      0.0 % ( )
Solvent C       :      100.0 % (8.0mM Na2CO3/1.0mM NaHCO3)
Solvent D       :      Off
```

## PressureLimits

```
Minimum Pressure :      0 bar
Maximum Pressure :      400 bar
```

## Auxiliary

```
Maximal Flow Ramp :      100.00 ml/min^2
Primary Channel    :      Auto
Compressibility    :      83*10^-6/bar
Minimal Stroke     :      Auto
```

## Store Parameters

```
Store Ratio A    :      Yes
Store Ratio B    :      Yes
Store Ratio C    :      Yes
Store Ratio D    :      Yes
Store Flow       :      Yes
Store Pressure   :      Yes
```

## Agilent 1100 Contacts Option

```
=====
Contact 1       :      Open
Contact 2       :      Open
Contact 3       :      Open
Contact 4       :      Open
=====
```

```
=====
Agilent 1100 Autosampler 1
=====
```

## Injection

```
Injection Mode   :      Needle Wash
Injector volume  :      25.0 µl
Wash Vial       :      100
```

## Auxiliary

```
Drawspeed       :      100 µl/min
Ejectspeed      :      1000 µl/min
Draw position    :      2.0 mm
```

## Time

```
Stoptime       :      As Pump
Posttime       :      Off
```

```
=====
Agilent 1100 Column Thermostat 1
=====
```

Temperature settings

Left temperature : 30.0°C  
Right temperature : Same as left  
Enable analysis : When Temp. is within setpoint +/- 0.8°C  
Store left temperature : No  
Store right temperature: No

Time

Stoptime : As pump  
Posttime : Off

Column Switching Valve : Column 1

=====  
 Calibration Table  
 =====

Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM

Calculate : External Standard  
 Based on : Peak Area

Rel. Reference Window : 5.000 %  
 Abs. Reference Window : 0.000 min  
 Rel. Non-ref. Window : 7.000 %  
 Abs. Non-ref. Window : 0.000 min  
 Uncalibrated Peaks : not reported  
 Partial Calibration : Yes, identified peaks are recalibrated  
 Correct All Ret. Times: No, only for identified peaks

Curve Type : Linear  
 Origin : Included  
 Weight : Equal

Recalibration Settings:  
 Average Response : Average all calibrations  
 Average Retention Time: No Update

Calibration Report Options :  
 Printout of recalibrations within a sequence:  
     Calibration Table after Recalibration  
     Normal Report after Recalibration  
 If the sequence is done with bracketing:  
     Results of first cycle (ending previous bracket)


Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Lvl Sig	Amount [ug/mL]	Area	Amt/Area	Ref Grp Name
8.989	1 1	1.23000	71.19956	1.72754e-2	Sulfate
	2	4.76000	274.04866	1.73692e-2	
	3	9.09000	519.38173	1.75016e-2	
	4	16.70000	959.28326	1.74088e-2	
	5	23.10000	1372.59271	1.68295e-2	

=====  
 Peak Sum Table  
 =====

\*\*\*No Entries in table\*\*\*

=====  
 Calibration Curves  
 =====




Sulfate at exp. RT: 8.989  
 ADC1 B, Dionex ED 40  
 Correlation: 0.99972  
 Residual Std. Dev.: 14.30564  
 Formula:  $y = mx + b$   
     m: 58.95287  
     b: -6.47129  
     x: Amount [ug/mL]  
     y: Area

```

=====
Injection Date   : 6/15/2004 9:59:48 PM      Seq. Line :   19
Sample Name     : Standard 1-H2O             Location  : Vial 21
Acq. Operator  : vks                          Inj       :    1
Acq. Instrument : Gonzo                       Inj Volume: 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method     : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed    : 6/15/2004 9:58:26 PM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed    : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
9.029	BB	73.00224	1.84664e-2	1.34809		Sulfate

Totals : 1.34809

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 6/15/2004 10:12:33 PM      Seq. Line : 19
Sample Name     : Standard 1-H2O             Location  : Vial 21
Acq. Operator  : vks                          Inj       : 2
Acq. Instrument: Gonzo                       Inj Volume: 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method    : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed   : 6/15/2004 10:11:09 PM by vks
                (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed   : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier    : 1.0000
Dilution      : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
9.035	BB	73.17904	1.84627e-2	1.35108		Sulfate

Totals : 1.35108

Results obtained with enhanced integrator!

```

=====
*** End of Report ***
=====


```



```

=====
Injection Date   : 6/16/2004 5:10:42 AM      Seq. Line :   36
Sample Name     : Standard 1-H2O             Location  : Vial 21
Acq. Operator   : vks                       Inj       :    1
Acq. Instrument : Gonzo                     Inj Volume: 25 µl
Acq. Method     : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed    : 6/16/2004 5:09:17 AM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed    : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
9.009	MF	69.29236	1.85469e-2	1.28516		Sulfate <small>Manual Integration (vks)</small>

Totals : 1.28516

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 6/16/2004 5:23:24 AM      Seq. Line   : 36
Sample Name     : Standard 1-H2O             Location    : Vial 21
Acq. Operator  : vks                        Inj         : 2
Acq. Instrument: Gonzo                      Inj Volume  : 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method    : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed   : 6/16/2004 5:21:59 AM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed   : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
9.008	BB	69.37669	1.85449e-2	1.28659		Sulfate

Totals : 1.28659

Results obtained with enhanced integrator!


```

=====
*** End of Report ***
=====

```

```

=====
Injection Date : 6/15/2004 10:25:15 PM      Seq. Line : 20
Sample Name    : Standard 2-H2O              Location  : Vial 22
Acq. Operator  : vks                          Inj      : 1
Acq. Instrument: Gonzo                       Inj Volume: 25 µl
Sequence File  : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method    : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed   : 6/15/2004 10:23:51 PM by vks
                (modified after loading)
Analysis Method: I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed   : 6/16/2004 2:53:40 PM by vks
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier     : 1.0000
Dilution       : 1.0000
    
```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
9.004	BB	276.23022	1.73601e-2	4.79538		Sulfate

Totals : 4.79538


Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date   : 6/15/2004 10:37:59 PM      Seq. Line :   20
Sample Name     : Standard 2-H2O              Location  : Vial 22
Acq. Operator   : vks                        Inj       :    2
Acq. Instrument : Gonzo                      Inj Volume: 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method     : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed    : 6/15/2004 10:36:35 PM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed    : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier      : 1.0000
Dilution        : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
8.996	BB	282.04434	1.73519e-2	4.89400		Sulfate

Totals : 4.89400

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 6/16/2004 5:36:06 AM          Seq. Line :   37
Sample Name     : Standard 2-H2O                 Location  : Vial 22
Acq. Operator   : vks                           Inj       :    1
Acq. Instrument : Gonzo                         Inj Volume: 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method     : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed    : 6/16/2004 5:36:19 AM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed    : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      :      Signal
Calib. Data Modified :      Wednesday, June 16, 2004 2:51:47 PM
Multiplier     :      1.0000
Dilution       :      1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
9.010	BB	269.11258	1.73706e-2	4.67465		Sulfate

Totals : 4.67465

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 6/16/2004 5:48:49 AM      Seq. Line : 37
Sample Name     : Standard 2-H2O             Location  : Vial 22
Acq. Operator   : vks                       Inj       : 2
Acq. Instrument : Gonzo                     Inj Volume: 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method     : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed    : 6/16/2004 5:47:23 AM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed    : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier      : 1.0000
Dilution        : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
9.003	BB	268.80750	1.73711e-2	4.66947		Sulfate

Totals : 4.66947

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date : 6/15/2004 10:50:39 PM      Seq. Line : 21
Sample Name    : Standard 3-H2O              Location  : Vial 23
Acq. Operator  : vks                        Inj      : 1
Acq. Instrument : Gonzo                     Inj Volume : 25 µl
Sequence File  : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method    : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed   : 6/15/2004 10:49:18 PM by vks
                (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed   : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
9.003	BB	525.63025	1.71715e-2	9.02588		Sulfate

Totals : 9.02588

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 6/15/2004 11:03:18 PM      Seq. Line : 21
Sample Name     : Standard 3-H2O              Location  : Vial 23
Acq. Operator  : vks                          Inj      : 2
Acq. Instrument : Gonzo                       Inj Volume: 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method    : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed   : 6/15/2004 11:01:56 PM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed   : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
8.997	BB	519.43622	1.71740e-2	8.92081		Sulfate

Totals : 8.92081

Results obtained with enhanced integrator!

```

=====
*** End of Report ***
=====


```



```

=====
Injection Date   : 6/16/2004 6:01:29 AM      Seq. Line   : 38
Sample Name     : Standard 3-H2O             Location    : Vial 23
Acq. Operator   : vks                       Inj         : 1
Acq. Instrument : Gonzo                     Inj Volume  : 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method     : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed    : 6/16/2004 6:00:05 AM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed    : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier      : 1.0000
Dilution        : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
9.006	BB	513.70685	1.71764e-2	8.82363		Sulfate

Totals : 8.82363

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 6/16/2004 6:14:10 AM      Seq. Line   : 38
Sample Name     : Standard 3-H2O            Location    : Vial 23
Acq. Operator  : vks                        Inj         : 2
Acq. Instrument : Gonzo                     Inj Volume  : 25 µl
Sequence File  : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method    : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed   : 6/16/2004 6:12:45 AM by vks
                (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed   : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier      : 1.0000
Dilution        : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
9.004	BB	518.75360	1.71743e-2	8.90923		Sulfate

Totals : 8.90923

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date : 6/15/2004 11:16:00 PM      Seq. Line : 22
Sample Name    : Standard 4-H2O              Location  : Vial 24
Acq. Operator  : vks                          Inj      : 1
Acq. Instrument : Gonzo                       Inj Volume : 25 µl
Sequence File  : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method    : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed   : 6/15/2004 11:14:37 PM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed   : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
8.996	BB	962.84552	1.70767e-2	16.44223		Sulfate

Totals : 16.44223

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 6/15/2004 11:28:39 PM      Seq. Line   : 22
Sample Name     : Standard 4-H2O             Location    : Vial 24
Acq. Operator   : vks                       Inj         : 2
Acq. Instrument : Gonzo                     Inj Volume  : 25 µl
icq. Method     : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed    : 6/15/2004 11:27:18 PM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed    : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier      : 1.0000
Dilution        : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
8.994	MF	947.38269	1.70786e-2	16.17994		Sulfate

Totals : 16.17994

Results obtained with enhanced integrator!


```

=====
*** End of Report ***

```

```

=====
Injection Date : 6/16/2004 6:26:50 AM      Seq. Line : 39
Sample Name    : Standard 4-H2O             Location  : Vial 24
Acq. Operator : vks                        Inj      : 1
Acq. Instrument : Gonzo                    Inj Volume : 25 µl
Sequence File  : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method    : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed   : 6/16/2004 6:25:26 AM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed   : 6/16/2004 2:53:40 PM by vks
=====
    
```



External Standard Report

```

=====
Sorted By      : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier     : 1.0000
Dilution       : 1.0000
    
```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
9.003	BB	959.55383	1.70771e-2	16.38640		Sulfate

Totals : 16.38640


Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date   : 6/16/2004 6:39:29 AM      Seq. Line   : 39
Sample Name     : Standard 4-H2O            Location    : Vial 24
Acq. Operator  : vks                        Inj         : 2
Acq. Instrument : Gonzo                    Inj Volume  : 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method     : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed    : 6/16/2004 6:38:06 AM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed    : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier      : 1.0000
Dilution        : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
8.991	BB	967.47528	1.70762e-2	16.52077		Sulfate

Totals : 16.52077

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 6/15/2004 11:41:18 PM      Seq. Line   : 23
Sample Name     : Standard5-H2O              Location    : Vial 25
Acq. Operator  : vks                          Inj         : 1
Acq. Instrument : Gonzo                       Inj Volume  : 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method     : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed    : 6/15/2004 11:39:56 PM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed    : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
8.991	BB	1362.15234	1.70433e-2	23.21555		Sulfate

Totals : 23.21555

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 6/15/2004 11:53:57 PM      Seq. Line   : 23
Sample Name     : Standard5-H2O              Location    : Vial 25
Acq. Operator  : vks                          Inj        : 2
Acq. Instrument: Gonzo                       Inj Volume  : 25 µl
Sequence File  : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method    : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed   : 6/15/2004 11:52:37 PM by vks
                (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed   : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
8.986	BB	1365.67273	1.70431e-2	23.27527		Sulfate

Totals : 23.27527

Results obtained with enhanced integrator!

```

=====
*** End of Report ***
=====


```



```

=====
Injection Date   : 6/16/2004 6:52:10 AM      Seq. Line   : 40
Sample Name     : Standard5-H2O             Location    : Vial 25
Acq. Operator   : vks                      Inj         : 1
Acq. Instrument : Gonzo                    Inj Volume  : 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method     : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed    : 6/16/2004 6:50:46 AM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed    : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier      : 1.0000
Dilution        : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
8.990	BB	1373.20374	1.70426e-2	23.40302		Sulfate

Totals : 23.40302

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 6/16/2004 7:04:52 AM      Seq. Line   : 40
Sample Name     : Standard5-H2O             Location    : Vial 25
Acq. Operator  : vks                       Inj        : 2
Acq. Instrument : Gonzo                    Inj Volume  : 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method    : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed   : 6/16/2004 7:03:26 AM by vks
                (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed   : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier    : 1.0000
Dilution      : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
8.989	BB	1389.34204	1.70417e-2	23.67677		Sulfate

Totals : 23.67677

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date : 6/16/2004 12:13:05 PM      Seq. Line : 41
Sample Name    : Standard 3-H2O              Location  : Vial 23
Acq. Operator  : vks                          Inj       : 1
Acq. Instrument : Gonzo                       Inj Volume: 25 µl
Sequence File  : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method    : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed   : 6/16/2004 12:09:44 PM by vks
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed   : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier     : 1.0000
Dilution       : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
9.067	BB	515.87128	1.71755e-2	8.86034		Sulfate

Totals : 8.86034

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 6/16/2004 12:25:37 PM      Seq. Line   : 41
Sample Name     : Standard 3-H2O              Location    : Vial 23
Acq. Operator  : vks                          Inj         : 2
Acq. Instrument : Gonzo                       Inj Volume  : 25 µl
Sequence File  : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method    : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed   : 6/16/2004 12:09:44 PM by vks
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed   : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier    : 1.0000
Dilution      : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
9.061	BB	517.34888	1.71749e-2	8.88541		Sulfate

Totals : 8.88541

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 6/16/2004 1:29:04 PM           Seq. Line :   44
Sample Name     : Standard 4-H2O                 Location  : Vial 24
Acq. Operator   : vks                           Inj       :    1
Acq. Instrument : Gonzo                         Inj Volume: 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method     : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed    : 6/16/2004 1:27:36 PM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed    : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier      : 1.0000
Dilution        : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
9.001	BB	940.54651	1.70794e-2	16.06398		Sulfate

Totals : 16.06398

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 6/16/2004 1:41:43 PM      Seq. Line   : 44
Sample Name     : Standard 4-H2O             Location    : Vial 24
Acq. Operator  : vks                        Inj         : 2
Acq. Instrument : Gonzo                     Inj Volume  : 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method    : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed   : 6/16/2004 1:41:53 PM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed   : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier    : 1.0000
Dilution      : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
9.003	BB	953.48206	1.70778e-2	16.28340		Sulfate

Totals : 16.28340

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 6/16/2004 12:06:38 AM      Seq. Line :   24
Sample Name     : S.S.Std-H2O                Location  : Vial 26
Acq. Operator  : vks                          Inj       :    1
Acq. Instrument : Gonzo                       Inj Volume: 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method     : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed    : 6/16/2004 12:05:15 AM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed    : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier      : 1.0000
Dilution        : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
8.990	BB	551.28632	1.71618e-2	9.46108		Sulfate 10.0

Totals : 9.46108

Results obtained with enhanced integrator!

```


=====
*** End of Report ***

```

```

=====
Injection Date   : 6/16/2004 12:19:18 AM      Seq. Line   : 24
Sample Name     : S.S.Std-H2O                Location    : Vial 26
Acq. Operator  : vks                          Inj         : 2
Acq. Instrument : Gonzo                       Inj Volume  : 25 µl
Sequence File   : I:\LC2004Q2\GONZO\JUN\SEQUENCE\0604-35A.S
Acq. Method    : H:\LC2004Q2\GONZO\JUN\METHODS\0604-35A.M
Last changed   : 6/16/2004 12:17:55 AM by vks
                  (modified after loading)
Analysis Method : I:\LC2004Q2\GONZO\JUN\METHODS\0604-40A.M
Last changed   : 6/16/2004 2:53:40 PM by vks
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Wednesday, June 16, 2004 2:51:47 PM
Multiplier      : 1.0000
Dilution        : 1.0000

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [us*s]	Amt/Area	Amount [ug/mL]	Grp	Name
9.000	BB	557.72876	1.71595e-2	9.57036		Sulfate 10.0

Totals : 9.57036

Results obtained with enhanced integrator!

```

=====
*** End of Report ***
=====


```



Sequence Table:

Method and Injection Info Part:

Line	Location	SampleName	Method	Inj	SampleType	InjVolume	DataFile
1	Vial 1	Standard 1-OH	0604-35A	2	Sample		
2	Vial 2	Standard 2-OH	0604-35A	2	Sample		
3	Vial 3	Standard 3-OH	0604-35A	2	Sample		
4	Vial 4	Standard 4-OH	0604-35A	2	Sample		
5	Vial 5	Standard 5-OH	0604-35A	2	Sample		
6	Vial 6	S.S.Standard-OH	0604-35A	2	Sample		
7	Vial 7	LB	0604-35A	2	Sample		
8	Vial 8	BS/Chloride16	0604-35A	2	Sample		
9	Vial 9	Run1*401	0604-35B	2	Sample		
10	Vial 10	Run2*401	0604-35B	2	Sample		
11	Vial 11	Run3*401	0604-35B	2	Sample		
12	Vial 12	MS/Run3*401	0604-35B	2	Sample		
13	Vial 13	Blank*4.04	0604-35B	2	Sample		
14	Vial 1	Standard 1-OH	0604-35A	2	Sample		
15	Vial 2	Standard 2-OH	0604-35A	2	Sample		
16	Vial 3	Standard 3-OH	0604-35A	2	Sample		
17	Vial 4	Standard 4-OH	0604-35A	2	Sample		
18	Vial 5	Standard 5-OH	0604-35A	2	Sample		
19	Vial 21	Standard 1-H2O	0604-35A	2	Sample		
20	Vial 22	Standard 2-H2O	0604-35A	2	Sample		
21	Vial 23	Standard 3-H2O	0604-35A	2	Sample		
22	Vial 24	Standard 4-H2O	0604-35A	2	Sample		
23	Vial 25	Standard5-H2O	0604-35A	2	Sample		
24	Vial 26	S.S.Std-H2O	0604-35A	2	Sample		
25	Vial 27	LB	0604-35A	2	Sample		
26	Vial 28	BS/Sulfate11	0604-35A	2	Sample		
27	Vial 29	BS/Chloride17	0604-35A	2	Sample		
28	Vial 30	Run1Pre*2	0604-35A	2	Sample		
29	Vial 31	Run2Pre*2	0604-35A	2	Sample		
30	Vial 32	Run3Pre	0604-35A	2	Sample		
31	Vial 33	Audit/M1674	0604-35A	2	Sample		
32	Vial 34	Run1Post*10	0604-35A	2	Sample		
33	Vial 35	Run2Post*10	0604-35A	2	Sample		
34	Vial 36	MS/Run2Post*10	0604-35A	2	Sample		
35	Vial 37	Run3Post*10	0604-35A	2	Sample		
36	Vial 21	Standard 1-H2O	0604-35A	2	Sample		
37	Vial 22	Standard 2-H2O	0604-35A	2	Sample		
38	Vial 23	Standard 3-H2O	0604-35A	2	Sample		
39	Vial 24	Standard 4-H2O	0604-35A	2	Sample		
40	Vial 25	Standard5-H2O	0604-35A	2	Sample		
41	Vial 23	Standard 3-H2O	0604-35A	2	Sample		
42	Vial 38	Run3Post*25	0604-35A	2	Sample		
43	Vial 39	MS/Run3Post*25	0604-35A	2	Sample		
44	Vial 24	Standard 4-H2O	0604-35A	2	Sample		



# **Air Test Professionals, Inc.**


1201 North Graham Avenue  
Indianapolis, IN 46219

Project Number: 079 – PPF Baghouse

Antimony, Arsenic, Barium,  
Beryllium, Cadmium, Chromium,  
Cobalt, Copper, Lead,  
Manganese, Mercury, Nickel,  
Phosphorus, Selenium,  
Silver, Thallium, and Zinc

EPA Method 29 Analysis

Analytical Report  
3361-M29




Element One, Inc.  
5022-C Wrightsville Av., Wilmington, NC 28403  
910-793-0128 FAX:910-792-6853 e1lab@hotmail.com


I have reviewed the following data for completeness,  
accuracy, adherence to method protocol, and compliance  
with quality assurance guidelines.

Quality assurance review by Bruce Hawks

*B. Hawks 6/16/04*



# SUMMARY OF RESULTS



## Summary of Analysis


### Summary of Mercury Analysis

Run Number		Average Total Catch, $\mu\text{g}$	Front half $\mu\text{g}$	$\text{H}_2\text{O}_2$ / $\text{HNO}_3$ $\mu\text{g}$	Empty Impinger $\mu\text{g}$	$\text{KMnO}_4$ $\mu\text{g}$
Run 1	# 1	3.95	< 0.1	2.72	< 0.2	1.19
	# 2		< 0.1	2.78	< 0.2	1.21
Run 2	# 1	4.77	< 0.1	4.03	< 0.2	0.69
	# 2		< 0.1	4.10	< 0.2	0.72
Run 3	# 1	7.58	0.53	3.98	< 0.2	3.10
	# 2		0.52	4.00	< 0.2	3.04
Blank	# 1	< 0.4	< 0.1	< 0.3	< 0.2	< 0.4
	# 2		< 0.1	< 0.3	< 0.2	< 0.4

### Summary of Metals Analysis

Element	Run 1 Total $\mu\text{g}$	Run 2 Total $\mu\text{g}$	Run 2 Total $\mu\text{g}$	Run 3 Total $\mu\text{g}$
Antimony	< 0.5	< 0.5	< 0.5	0.77
Arsenic	< 0.5	< 0.5	< 0.5	< 0.5
Barium	6.69	5.93	5.86	5.45
Beryllium	< 0.05	< 0.05	< 0.05	< 0.05
Cadmium	0.61	0.37	0.35	0.31
Chromium	17.6	6.17	6.26	6.56
Cobalt	< 0.5	< 0.5	< 0.5	< 0.5
Copper	5.62	2.33	2.33	2.68
Lead	4.64	2.29	2.26	1.93
Manganese	40.4	13.9	13.9	12.6
Nickel	4.72	2.11	2.10	2.52
Phosphorus	38.1	29.3	30.8	29.6
Selenium	< 0.5	< 0.5	< 0.5	< 0.5
Silver	< 0.5	< 0.5	< 0.5	< 0.5
Thallium	< 0.5	< 0.5	< 0.5	< 0.5
Zinc	93.5	40.4	41.0	45.7

# ANALYTICAL NARRATIVE



## Element One Analytical Narrative

Client	Air Test Professionals, Inc.	Element One #:	3361
Client ID:	079 – PPF Baghouse Nucor Steel	Analyst:	DBW, CML, BPL
Date Received	6/10/04	Method:	M29
Analytes	Sb, As, Ba, Be, Cd, Cr, Co, Cu, Pb, Mn, Ni, P, Se, Ag, Tl, Zn, & Hg	Dates Analyzed	6/11 - 16/04

### Summary of Analysis

The Method 29 samples were digested, prepared, and analyzed according to Method 29 protocol. Samples were analyzed for mercury on a PerkinElmer FIMS-100 CVAA mercury analyzer. The other metals were analyzed on a PerkinElmer ELAN 6100 ICP-MS.

### Detection Limits

The FIMS-100 CVAA instrument reporting limit for mercury was 0.004 µg per aliquot analyzed. The ICP-MS instrument reporting limits were 0.25 µg/L for beryllium, 1 µg/L for cadmium, 20 µg/L for phosphorus, and 2.5 µg/L for the other metals.

### Analysis QA/QC


Duplicate analyses relative percent difference (RPD), spike sample recovery, and second source calibration verification data are summarized on the following pages. All QA/QC data was within the criteria of the method.

### Additional Comments

The reported results have not been corrected for any blank values or spike recovery values. Nothing unusual was noticed with any of the samples or analyses.



# QUALITY CONTROL SUMMARY



## Summary of Quality Control Data

### Mercury Duplicate Analysis RPD

Run Number	Front half	H <sub>2</sub> O <sub>2</sub> /HNO <sub>3</sub>	Empty Imp	KMnO <sub>4</sub>
Run 1	NA	2.1%	NA	2.0%
Run 2	NA	1.8%	NA	3.8%
Run 3	2.2%	0.5%	NA	2.1%
Blank	NA	NA	NA	NA

### Metals Duplicate Analysis RPD and Spike Recoveries

Element	Run 2 RPD	Run 3 Recovery
Antimony	NA	103%
Arsenic	NA	96%
Barium	1.1%	101%
Beryllium	NA	96%
Cadmium	5.9%	88%
Chromium	1.5%	104%
Cobalt	NA	103%
Copper	0.3%	104%
Lead	1.2%	103%
Manganese	0.3%	105%
Nickel	0.4%	104%
Phosphorus	4.9%	96%
Selenium	NA	80%
Silver	NA	96%
Thallium	NA	103%
Zinc	1.4%	103%

## Summary of Quality Control Data (continued)


### Mercury Spike Recoveries

Run Number		Front half	H <sub>2</sub> O <sub>2</sub> /HNO <sub>3</sub>	Empty Imp	KMnO <sub>4</sub>
Run 3	# 1	110%	103%	101%	91%
	# 2	101%	106%	98%	92%

### Second Source Calibration Check Recoveries

Element	0.25 ppb	1 ppb	10 ppb	50 ppb	500 ppb
Antimony		104%	103%	107%	107%
Arsenic		99%	102%	111%	108%
Barium		98%	98%	102%	98%
Beryllium	108%	102%	94%	111%	107%
Cadmium		96%	97%	98%	95%
Chromium		103%	95%	101%	109%
Cobalt		100%	99%	100%	106%
Copper		105%	103%	105%	100%
Lead		104%	104%	103%	99%
Manganese		98%	96%	100%	110%
Nickel		103%	99%	102%	103%
Phosphorus		96%		101%	99%
Selenium		93%	101%	103%	96%
Silver		100%	98%	97%	
Thallium		106%	105%	104%	100%
Zinc		116%	105%	115%	107%

# ANALYTICAL DATA



Client ID/PO: 079 – PPF Baghouse Nucor Steel		Date Received: 6/10/04	Page: 1 of 1
Customer: Air Test Professionals, Inc.		Results Requested: 6/24/04	Time Rec: 1045
Address: 1201 N. Graham Av.		Contact: Carlos Brown	Rec by: BGH
Indianapolis, IN 46219		Email: atp_stack@sbcglobal.net	Via:
		Phone: 317-345-1723	Fax:
HNO <sub>3</sub> Lot: 1103080	HF Lot: 510124	HCl Lot: 4103101	
Volume Marked (Y) N	Volume Loss Y (N) ?	pH < 2.0 (Y) N	Ref. Method: 29

	Sample Identification		Sample Identification
1	Run 1		
2	Run 2		
3	Run 2 Duplicate		
4	Run 3		
5	Run 3 Spike		
6	Blank		

Elements to Analyze: Sb, As, Ba, Be, Cd, Cr, Co, Cu, Pb, Mn, Ni, P, Se, Ag, Tl, Zn, & Hg FH/BH Combined

SAMPLE	Front Half		Back Half			HNO <sub>3</sub> (A)		KMnO <sub>4</sub> (B)		HCl (C)	
	BV, ml	FV, ml	BV, ml	Used	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml
1	98	100	320	160	50	104ml	200ml	390ml	600ml		
2/3	104	↓	320	160	↓	104ml	↓	400ml	500ml		
4/5	94	↓	290	145	↓	104ml	↓	405ml	600ml		
6	50	↓	100 ml 50 ml HCl	150	↓	200 ml	200 ml	27.7 ml H <sub>2</sub> O 847 ml KMnO <sub>4</sub>	400ml		
						6-10-04		6-10-04			
						FH-BLK-F.V. = 100ml 6-11-04 153					
						BH-BLK-F.V. = 100ml 50ml					
						FH-BLK-SPK @ 5ug except for P is @ 20ug					
						BH-BLK-SPK @ 2.5ug except for P is @ 10ug					
						SPK-lot: 021404-A, B, C, F					
						6-11-04 153					

Comments: No 'C' Fraction, Recombined Digest filter w/ 'B' Fraction and brought to Volume  
 Element One, Inc. Form 118 - Revision 6.0



# Dataset Report

*Alph Woodman*  
*6-15-04*

Operator Name: dwoodman  
Computer Name: ICPMS1  
Dataset File Path: c:\elandata\dataset\061504-2\  
Report Date/Time: Tuesday, June 15, 2004 15:49:43

Autosampler Position: 6

## The Dataset

Time	Sample ID	Batch ID	Read Type	Description	Init. Quant	Prep. Vol.	Aliquot. Vol.	Diluted V
13:20:23 Tue 15-Jun-04	Blank		Blank					
13:23:25 Tue 15-Jun-04	Standard 1		Standard #1					
13:26:29 Tue 15-Jun-04	Standard 2		Standard #2					
13:29:33 Tue 15-Jun-04	Standard 3		Standard #3					
13:32:37 Tue 15-Jun-04	QC Std 1		QC Std #1					
13:35:41 Tue 15-Jun-04	QC Std 2		QC Std #2					
13:38:43 Tue 15-Jun-04	QC Std 3		QC Std #3					
13:41:45 Tue 15-Jun-04	QC Std 4		QC Std #4					
13:44:48 Tue 15-Jun-04	QC Std 5		QC Std #5					
13:47:52 Tue 15-Jun-04	QC Std 6		QC Std #6					
13:50:56 Tue 15-Jun-04	QC Std 7		QC Std #7					
13:54:00 Tue 15-Jun-04	QC Std 8		QC Std #8					
13:57:05 Tue 15-Jun-04	LRB		Sample	Air Test Professionals, Inc.				
14:00:10 Tue 15-Jun-04	LRB		Spike - 1	Air Test Professionals, Inc.				
14:03:14 Tue 15-Jun-04	3361-1		Sample	Air Test Professionals, Inc.				
14:06:16 Tue 15-Jun-04	3361-2		Sample	Air Test Professionals, Inc.				
14:09:18 Tue 15-Jun-04	3361-2		QC Duplicate	Air Test Professionals, Inc.				
14:12:20 Tue 15-Jun-04	3361-4		Sample	Air Test Professionals, Inc.				
14:15:23 Tue 15-Jun-04	3361-4		Spike - 1	Air Test Professionals, Inc.				
14:18:26 Tue 15-Jun-04	3361-6		Sample	Air Test Professionals, Inc.				
14:21:28 Tue 15-Jun-04	QC Std 3		QC Std #3					
14:24:30 Tue 15-Jun-04	QC Std 4		QC Std #4					
14:48:05 Tue 15-Jun-04	LRB	x2	Sample	Air Test Professionals, Inc.				
14:51:08 Tue 15-Jun-04	LRB	x2	Spike - 2	Air Test Professionals, Inc.				
14:54:12 Tue 15-Jun-04	3361-1	x5	Sample	Air Test Professionals, Inc.				
14:57:15 Tue 15-Jun-04	QC Std 3		QC Std #3					
15:00:17 Tue 15-Jun-04	QC Std 4		QC Std #4					
15:12:37 Tue 15-Jun-04	LRB		Sample	Air Test Professionals, Inc.				
15:15:42 Tue 15-Jun-04	LRB		Spike - 1	Air Test Professionals, Inc.				
15:18:45 Tue 15-Jun-04	QC Std 3		QC Std #3					
15:21:48 Tue 15-Jun-04	QC Std 4		QC Std #4					
15:32:47 Tue 15-Jun-04	QC #1		QC Std #1					
15:35:51 Tue 15-Jun-04	QC #2		QC Std #2					
15:38:53 Tue 15-Jun-04	QC Std 3		QC Std #3					
15:41:55 Tue 15-Jun-04	QC Std 4		QC Std #4					

# Sample/Batch Report

*Daph Wood*  
*6-15-04*

Operator Name: dwoodman

Computer Name: ICPMS1

Sample File: C:\elandata\Sample\xxx.sam

Report Date/Time: Tuesday, June 15, 2004 15:49:50

A/S Loc.	Batch ID	Sample ID	Description	Sample Type	Init. Quant.	Prep. Vol.	Aliquot Vol.	Diluted Vol.	Solids Ratio
12		LRB	Air Test Professionals, Inc.						
13		LRB	Air Test ProfestSpike - 1						
14		3361-1	Air Test Professionals, Inc.						
15		3361-2	Air Test Professionals, Inc.						
16		3361-2	Air Test ProfestQC Duplicate						
17		3361-4	Air Test Professionals, Inc.						
18		3361-4	Air Test ProfestSpike - 1						
19		3361-6	Air Test Professionals, Inc.						
20	x2	LRB	Air Test Professionals, Inc.						
21	x2	LRB	Air Test ProfestSpike - 2						
22	x5	3361-1	Air Test Professionals, Inc.						
23		LRB	Air Test Professionals, Inc.						
24		LRB	Air Test ProfestSpike - 1						
5		QC #1							
6		QC #2							



*Daphne Wash*  
6-15-04

Analyst: DBW Date: 06-15-04 Solid Samples  / Liquid Samples

Sample Loc	Batch # for sample sets	Sample Lab ID	Sample Description	Type Sample QC Spike QC Dup QC Reg Blank	Spike concentratio	Prep Volume (ml)	Aliquot (ml)	Diluted to Volume (ml)	Units
12			LRB	S		100X2			
13			LRB	SS	Table #1	100X2			
14			3361-1	S		100X2			
15			3361-2	S		100X2			
16			3361-2	SD		100X2			
17			3361-4	S		100X2			
18			3361-4	SS	Table #1	100X2			
19			3361-6	S		100X2			

Dilutions

			LRB	S		100X2	5.0	10	
21			LRB	SS	Table #2	100X2	5.0	10	
22			3361-1	S		100X2	2.0	10	
23			LRB	S		100X2			
24			LRB*	SS	Table #1	100X2			

\*1.0mL of HCl was added to the sample prep, to aid in the recovery of silver.

Spikes are post at 0.02ml of 25ppm spiking solutions lot 021404-ABC & F in a final volume of 10ml.

Submitted for QC:	Date: <u>6-15-04</u>	Time: <u>15:30</u>	By: <u>DBW</u>	QC Review:	Date: <u>6/16/04</u>	Time: <u>1800</u>	By: <u>BGA</u>	
Re-Test Required:	No:	Yes:	Comments:					
Resubmitted for QC:	Date:	Time:	By:	QC Review:	Date:	Time:	By:	

File Edit Options Window Help

Timing Processing Equation Calibration Sampling Devices

QC

Analyte	Mass (amu)	Spike Table 1 (Conc)	Spike Table 1 Det. Limit (Conc)	Spike Table 2 (Conc)	Spike Table 2 Det. Limit (Conc)	Spike Table 3 (Conc)	Spike Table 3 Det. Limit (Conc)	Spike Table 3 (Conc)	Spike Table 3 Det. Limit (Conc)	Spike Table 4 (Conc)
Be	9.0122	50	1	25	1	100	1	100	1	
P	30.9938	200	1	100	1	100	1	100	1	
Sc	44.9559	50	1	25	1	100	1	100	1	
Cr	51.9405	50	1	25	1	100	1	100	1	
Cr	52.9407	50	1	25	1	100	1	100	1	
Mn	54.9381	50	1	25	1	100	1	100	1	
Co	58.9332	50	1	25	1	100	1	100	1	
Ni	59.9332	50	1	25	1	100	1	100	1	
Cu	62.9298	50	1	25	1	100	1	100	1	
Cu	64.9278	50	1	25	1	100	1	100	1	
Zn	65.926	50	1	25	1	100	1	100	1	
Zn	66.9271	50	1	25	1	100	1	100	1	
Zn	67.9249	50	1	25	1	100	1	100	1	
As	74.9216	50	1	25	1	100	1	100	1	
Se	76.9199	50	1	25	1	100	1	100	1	
Se	81.9167	50	1	25	1	100	1	100	1	
Ag	106.905	50	1	25	1	100	1	100	1	
Ag	108.905	50	1	25	1	100	1	100	1	
Cd	110.904	50	1	25	1	100	1	100	1	
Cd	113.904	50	1	25	1	100	1	100	1	
Sb	120.904	50	1	25	1	100	1	100	1	
Sb	122.904	50	1	25	1	100	1	100	1	
Ba	134.906	50	1	25	1	100	1	100	1	
Ba	136.905	50	1	25	1	100	1	100	1	
Tl	204.975	50	1	25	1	100	1	100	1	

Frequency (Hz) Std In Stds Calibration Stds Sample In Stds Spike In Stds Duplicate Spike Tables

QC Action Controls Autosampler

ELAN Instrument... ELAN Edit/Reproc... Microsoft Word ICP... Microsoft Excel... 3:25 PM

Method 6020 & 200.8 Metals Summary Report

Sample ID: Blank  
 Sample Date/Time: Tuesday, June 15, 2004 13:20:23  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
>	Li	6	117114	ppb
	Be	9	7.7	ppb
	P	31	3722.1	ppb
	Sc	45	122296.7	ppb
	Cr	52	7387.1	ppb
	Cr	53	656.4	ppb
	Mn	55	374.3	ppb
	Co	59	65.3	ppb
	Ni	60	83.3	ppb
	Cu	63	279.7	ppb
	Cu	65	213	ppb
	Zn	66	551.4	ppb
	Zn	67	154.7	ppb
	Zn	68	4469.5	ppb
	As	75	-203	ppb
	Se	77	168	ppb
	Se	82	3.3	ppb
>	Rh	103	355429.5	ppb
	Ag	107	333.3	ppb
	Ag	109	325.3	ppb
	Cd	111	23.2	ppb
	Cd	114	52.8	ppb
	Sb	121	498	ppb
	Sb	123	392.1	ppb
	Ba	135	78.7	ppb
	Ba	137	129.7	ppb
>	Ho	165	803542.6	ppb
	Tl	205	401.3	ppb
	Pb	208	3231.3	ppb
	Kr	83	76.7	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: Standard 1  
 Sample Date/Time: Tuesday, June 15, 2004 13:23:25  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
>	Li	6	117474.7	ppb
	Be	9	1900.6	10.49585 ppb
	P	31	15638.9	50.03389 ppb
	Sc	45	127963.3	ppb
	Cr	52	67271	10.19349 ppb
	Cr	53	7731	10.00711 ppb
	Mn	55	86210	10.30032 ppb
	Co	59	82663.3	10.25731 ppb
	Ni	60	18645.3	10.11338 ppb
	Cu	63	44154.1	10.32463 ppb
	Cu	65	20968.7	10.26415 ppb
	Zn	66	12136.2	10.40815 ppb
	Zn	67	2140.3	10.43292 ppb
	Zn	68	13199.4	10.35811 ppb
	As	75	14105.2	10.20176 ppb
	Se	77	1390.5	10.44319 ppb
	Se	82	1551.5	10.13854 ppb
>	Rh	103	354408.2	ppb
	Ag	107	90720.1	10.16609 ppb
	Ag	109	86997.8	10.21346 ppb
	Cd	111	19640	10.09369 ppb
	Cd	114	45804.5	10.32851 ppb
	Sb	121	50597.5	8.91074 ppb
	Sb	123	38910.3	8.91521 ppb
	Ba	135	22368.4	10.19595 ppb
	Ba	137	40118.4	10.31653 ppb
>	Ho	165	801738.4	ppb
	Tl	205	272182.2	10.38619 ppb
	Pb	208	360956.5	10.22785 ppb
	Kr	83	81.3	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: Standard 2  
 Sample Date/Time: Tuesday, June 15, 2004 13:26:29  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
Li	6	115572		ppb
Be	9	3732.5	20.99358	ppb
P	31	51164.4	202.72381	ppb
Sc	45	127618.1		ppb
Cr	52	125177.8	20.41052	ppb
Cr	53	14704	20.22253	ppb
Mn	55	169607.4	20.65759	ppb
Co	59	163865.4	20.6909	ppb
Ni	60	37397.5	20.6858	ppb
Cu	63	86740.4	20.697	ppb
Cu	65	41138.3	20.58851	ppb
Zn	66	23699.4	21.15935	ppb
Zn	67	4133.3	21.27746	ppb
Zn	68	21810.7	21.001	ppb
As	75	28493.7	20.81263	ppb
Se	77	2526.7	20.51557	ppb
Se	82	3173.9	21.11568	ppb
Rh	103	348370.3		ppb
Ag	107	180548.9	20.61752	ppb
Ag	109	171526.1	20.52091	ppb
Cd	111	39104	20.45818	ppb
Cd	114	90099.7	20.67953	ppb
Sb	121	111381.2	20.04855	ppb
Sb	123	84954.1	19.89977	ppb
Ba	135	44785.2	20.81057	ppb
Ba	137	78622.7	20.60979	ppb
Ho	165	787815.5		ppb
Tl	205	541076.7	21.02809	ppb
Pb	208	709982.1	20.56546	ppb
Kr	83	84.3		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: Standard 3  
 Sample Date/Time: Tuesday, June 15, 2004 13:29:33  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
Li	6	116003.2		ppb
Be	9	17760.2	99.7517	ppb
P	31	237941.7	999.45354	ppb
Sc	45	128800		ppb
Cr	52	584556.3	99.89855	ppb
Cr	53	70162.8	99.95478	ppb
Mn	55	818539.5	99.83845	ppb
Co	59	790590.2	99.83609	ppb
Ni	60	180231.6	99.8515	ppb
Cu	63	417423.5	99.82814	ppb
Cu	65	198781.1	99.85588	ppb
Zn	66	109729.1	99.72731	ppb
Zn	67	18812.6	99.70122	ppb
Zn	68	87185.7	99.76399	ppb
As	75	137445.2	99.8173	ppb
Se	77	11663.9	99.85257	ppb
Se	82	14986.3	99.76301	ppb
Rh	103	348445.8		ppb
Ag	107	873452.4	99.85989	ppb
Ag	109	833710.6	99.87447	ppb
Cd	111	190887.3	99.89899	ppb
Cd	114	434882.4	99.83124	ppb
Sb	121	556395.5	100.09922	ppb
Sb	123	427692	100.12853	ppb
Ba	135	215501.2	99.81829	ppb
Ba	137	382115.8	99.84639	ppb
Ho	165	791337.1		ppb
Tl	205	2577199.8	99.75576	ppb
Pb	208	3451378.9	99.86412	ppb
Kr	83	73		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 1  
 Sample Date/Time: Tuesday, June 15, 2004 13:32:37  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
Li	6	114784.4		ppb
Be	9	1770.9	10.00456	ppb
P	31	3986.9	1.7946	ppb
Sc	45	123601.2		ppb
Cr	52	63720.9	9.99495	ppb
Cr	53	7354	9.8625	ppb
Mn	55	80138.6	9.93165	ppb
Co	59	77687.3	10.00055	ppb
Ni	60	17728.4	9.97947	ppb
Cu	63	41348.2	10.02983	ppb
Cu	65	19805.8	10.05547	ppb
Zn	66	11488.7	10.2114	ppb
Zn	67	2006.6	10.12549	ppb
Zn	68	12714.3	10.34598	ppb
As	75	13637.6	10.23402	ppb
Se	77	1304.1	10.1256	ppb
Se	82	1526.2	10.3466	ppb
Rh	103	341571.3		ppb
Ag	107	87198.5	10.13754	ppb
Ag	109	82586.6	10.05962	ppb
Cd	111	18552.1	9.89279	ppb
Cd	114	42598.7	9.96524	ppb
Sb	121	71061	13.15787	ppb
Sb	123	55226.4	13.30579	ppb
Ba	135	20759.6	9.9242	ppb
Ba	137	36911.5	9.95619	ppb
Ho	165	764287.8		ppb
Tl	205	251088.6	10.04963	ppb
Pb	208	339583.3	10.09131	ppb
Kr	83	72.7		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 2  
 Sample Date/Time: Tuesday, June 15, 2004 13:35:41  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
Li	6	114682.1		ppb
Be	9	202.7	1.10908	ppb
P	31	8366.9	20.42865	ppb
Sc	45	123842.5		ppb
Cr	52	13246.8	1.05847	ppb
Cr	53	1345.1	1.02508	ppb
Mn	55	8526.8	1.00433	ppb
Co	59	7948.9	1.00423	ppb
Ni	60	1847.2	0.98747	ppb
Cu	63	4578.9	1.03942	ppb
Cu	65	2237.6	1.02955	ppb
Zn	66	1732.5	1.10208	ppb
Zn	67	345.3	1.0506	ppb
Zn	68	5279.9	1.13708	ppb
As	75	1279.8	1.0807	ppb
Se	77	296.7	1.16713	ppb
Se	82	172.1	1.13448	ppb
Rh	103	345561.7		ppb
Ag	107	9137	1.01639	ppb
Ag	109	8704.6	1.01373	ppb
Cd	111	1980.9	1.03389	ppb
Cd	114	4391.5	1.00495	ppb
Sb	121	8232.8	1.42032	ppb
Sb	123	6379.8	1.43083	ppb
Ba	135	2198.6	1.00041	ppb
Ba	137	3838.8	0.98743	ppb
Ho	165	777787		ppb
Tl	205	25723.9	0.99788	ppb
Pb	208	37011.6	0.99843	ppb
Kr	83	70		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 3  
 Sample Date/Time: Tuesday, June 15, 2004 13:38:43  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
>	Li	6	116204.4	ppb
	Be	9	6.7	-0.00509 ppb
	P	31	3535.7	-0.35535 ppb
	Sc	45	124166.5	ppb
	Cr	52	7372.7	0.03316 ppb
	Cr	53	643.7	0.00799 ppb
	Mn	55	381	0.00208 ppb
	Co	59	70	0.00082 ppb
	Ni	60	77	-0.00226 ppb
	Cu	63	313	0.00989 ppb
	Cu	65	208	0.00045 ppb
	Zn	66	543.4	0.00656 ppb
	Zn	67	150.7	0.00147 ppb
	Zn	68	4387.4	0.05055 ppb
	As	75	-132.9	0.04706 ppb
	Se	77	169	0.04939 ppb
	Se	82	19.3	0.10785 ppb
>	Rh	103	345608.5	ppb
	Ag	107	570.4	0.02841 ppb
	Ag	109	562.7	0.02978 ppb
	Cd	111	31.5	0.00471 ppb
	Cd	114	42.5	-0.00206 ppb
	Sb	121	1573.5	0.19974 ppb
	Sb	123	1151.9	0.18394 ppb
	Ba	135	85.7	0.00448 ppb
	Ba	137	135	0.00252 ppb
>	Ho	165	778107.6	ppb
	Tl	205	405.7	0.00068 ppb
	Pb	208	3369.9	0.00713 ppb
	Kr	83	77.3	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 4  
 Sample Date/Time: Tuesday, June 15, 2004 13:41:45  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
>	Li	6	115558.9	ppb
	Be	9	9842.1	55.43794 ppb
	P	31	50066	201.88559 ppb
	Sc	45	125119.7	ppb
	Cr	52	294605	50.64755 ppb
	Cr	53	35752.2	51.41269 ppb
	Mn	55	403914.9	50.14542 ppb
	Co	59	387895.4	49.86669 ppb
	Ni	60	90723.7	51.16297 ppb
	Cu	63	215004.1	52.32543 ppb
	Cu	65	101225.7	51.72071 ppb
	Zn	66	62126.2	57.28503 ppb
	Zn	67	10498.2	56.31188 ppb
	Zn	68	50736	56.9606 ppb
	As	75	74960.6	55.49201 ppb
	Se	77	5880	50.55297 ppb
	Se	82	7560.3	51.25792 ppb
>	Rh	103	342291.7	ppb
	Ag	107	416166.2	48.43504 ppb
	Ag	109	400748.7	48.86141 ppb
	Cd	111	92187.6	49.10788 ppb
	Cd	114	212240.3	49.60288 ppb
	Sb	121	290825	53.54583 ppb
	Sb	123	223290.8	53.50053 ppb
	Ba	135	106716.3	50.59817 ppb
	Ba	137	190853.5	51.04876 ppb
>	Ho	165	772834.3	ppb
	Tl	205	1306698.3	51.78587 ppb
	Pb	208	1741724.1	51.56112 ppb
	Kr	83	76	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 5  
 Sample Date/Time: Tuesday, June 15, 2004 13:44:48  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
Li	6	107436		ppb
Be	9	88306.8	535.49424	ppb
P	31	431142.1	1977.93111	ppb
Sc	45	123647.7		ppb
Cr	52	2905543.2	543.83099	ppb
Cr	53	326279.3	507.70644	ppb
Mn	55	4148489.7	548.72289	ppb
Co	59	3878976.1	531.00371	ppb
Ni	60	854730.5	513.51591	ppb
Cu	63	1925702.5	499.57952	ppb
Cu	65	930967.7	507.45176	ppb
Zn	66	540444.8	534.62931	ppb
Zn	67	92113.3	532.65868	ppb
Zn	68	410485.8	530.79132	ppb
As	75	686017.4	539.48414	ppb
Se	77	50778.9	476.59622	ppb
Se	82	66475.5	479.74399	ppb
Rh	103	321399.2		ppb
Ag	107	1567283.1	194.27475	ppb
Ag	109	1582068.4	205.52404	ppb
Cd	111	840194.2	476.71233	ppb
Cd	114	1914351.2	476.46707	ppb
Sb	121	2771921.6	531.53583	ppb
Sb	123	2139887.8	533.9987	ppb
Ba	135	1000592.1	493.71694	ppb
Ba	137	1764844.4	491.25488	ppb
Ho	165	742974.6		ppb
Tl	205	12114903.1	499.49648	ppb
Pb	208	16047099	494.85844	ppb
Kr	83	84.3		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 6  
 Sample Date/Time: Tuesday, June 15, 2004 13:47:52  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
Li	6	105666		ppb
Be	9	19.3	0.07689	ppb
P	31	11252143.8	56256.63374	ppb
Sc	45	123080.6		ppb
Cr	52	10785.2	0.9351	ppb
Cr	53	5412.3	8.20229	ppb
Mn	55	15125.7	2.11929	ppb
Co	59	8130.4	1.19566	ppb
Ni	60	4387.1	2.80553	ppb
Cu	63	6862	1.86007	ppb
Cu	65	3612.4	2.02542	ppb
Zn	66	5678.2	5.58744	ppb
Zn	67	1352.8	7.6636	ppb
Zn	68	6867	4.42107	ppb
As	75	510.7	0.57789	ppb
Se	77	816.7	6.88842	ppb
Se	82	20.3	0.13728	ppb
Rh	103	297176.8		ppb
Ag	107	10844.3	1.41715	ppb
Ag	109	10242.2	1.40097	ppb
Cd	111	315.6	0.18201	ppb
Cd	114	5956.4	1.59185	ppb
Sb	121	18859.2	3.65619	ppb
Sb	123	14511.4	3.65936	ppb
Ba	135	972.7	0.46059	ppb
Ba	137	1646.8	0.44067	ppb
Ho	165	718479.7		ppb
Tl	205	2597.7	0.09546	ppb
Pb	208	14177.1	0.36008	ppb
Kr	83	155		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 7  
 Sample Date/Time: Tuesday, June 15, 2004 13:50:56  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
Li	6	100927.7		ppb
Be	9	4.7	-0.01246	ppb
P	31	10128722.2	54220.75177	ppb
Sc	45	112739.6		ppb
Cr	52	58539.5	11.46296	ppb
Cr	53	11841.2	20.45013	ppb
Mn	55	81005.5	12.3636	ppb
Co	59	139619.2	22.12519	ppb
Ni	60	32951.3	22.87985	ppb
Cu	63	39241.2	11.72335	ppb
Cu	65	18927.5	11.84315	ppb
Zn	66	13475.8	14.95752	ppb
Zn	67	2918.8	18.76516	ppb
Zn	68	12334.5	13.37422	ppb
As	75	11257.2	10.39189	ppb
Se	77	1769.2	17.85615	ppb
Se	82	1058.8	8.82447	ppb
Rh	103	277588.7		ppb
Ag	107	70129.8	10.03126	ppb
Ag	109	67182	10.06836	ppb
Cd	111	7208.8	4.72381	ppb
Cd	114	22421.9	6.44999	ppb
Sb	121	6526.4	1.32517	ppb
Sb	123	5034.7	1.32861	ppb
Ba	135	902.4	0.46703	ppb
Ba	137	1605.2	0.4712	ppb
Ho	165	657912.9		ppb
Tl	205	737	0.01902	ppb
Pb	208	9709.5	0.24607	ppb
Kr	83	153.7		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 8  
 Sample Date/Time: Tuesday, June 15, 2004 13:54:00  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
Li	6	101778.3		ppb
Be	9	49	0.27063	ppb
P	31	4123	6.10607	ppb
Sc	45	100345.5		ppb
Cr	52	8210.5	0.4975	ppb
Cr	53	1495.8	1.72421	ppb
Mn	55	2252.3	0.2938	ppb
Co	59	1860.9	0.2815	ppb
Ni	60	443.7	0.25767	ppb
Cu	63	1223.8	0.29537	ppb
Cu	65	699	0.32817	ppb
Zn	66	546.4	0.12121	ppb
Zn	67	250.3	0.83731	ppb
Zn	68	4220	0.98566	ppb
As	75	213	0.33457	ppb
Se	77	209.3	0.81002	ppb
Se	82	54.2	0.42263	ppb
Rh	103	282794.1		ppb
Ag	107	24512.3	3.40799	ppb
Ag	109	23145.9	3.37009	ppb
Cd	111	425	0.26226	ppb
Cd	114	1004.4	0.27224	ppb
Sb	121	2645.4	0.52566	ppb
Sb	123	2051.5	0.52908	ppb
Ba	135	178	0.0704	ppb
Ba	137	280.3	0.06107	ppb
Ho	165	614051.3		ppb
Tl	205	6163.8	0.29223	ppb
Pb	208	10063.3	0.28351	ppb
Kr	83	55.3		ppb



Method 6020 & 200.8 Metals Summary Report

Sample ID: LRB  
 Sample Date/Time: Tuesday, June 15, 2004 13:57:05  
 Sample Description: Air Test Professionals, Inc.  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
Li	6	108473.2		ppb
Be	9	9	0.01161	ppb
P	31	6503.1	17.47837	ppb
Sc	45	111951.8		ppb
Cr	52	7960.6	0.38717	ppb
Cr	53	1228.1	1.17761	ppb
Mn	55	1912.9	0.23324	ppb
Co	59	318.7	0.03989	ppb
Ni	60	482.4	0.27274	ppb
Cu	63	1194.8	0.27487	ppb
Cu	65	646	0.28185	ppb
Zn	66	1375.8	1.00295	ppb
Zn	67	329	1.28579	ppb
Zn	68	4870	1.70641	ppb
As	75	433.2	0.51919	ppb
Se	77	206	0.69971	ppb
Se	82	44.5	0.33314	ppb
Rh	103	292718.2		ppb
Ag	107	1381.1	0.15098	ppb
Ag	109	1077.4	0.11577	ppb
Cd	111	526.5	0.31621	ppb
Cd	114	154.6	0.03037	ppb
Sb	121	63501.4	13.95537	ppb
Sb	123	49238.8	14.07892	ppb
Ba	135	432	0.20992	ppb
Ba	137	795.4	0.22201	ppb
Ho	165	644570		ppb
Tl	205	1769.9	0.06882	ppb
Pb	208	27035	0.86938	ppb
Kr	83	60		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: LRB  
 Sample Date/Time: Tuesday, June 15, 2004 14:00:10  
 Sample Description: Air Test Professionals, Inc.  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
Li	6	110578.6		ppb
Be	9	7479.5	44.01854	ppb
P	31	41803.7	197.47578	ppb
Sc	45	111743.4		ppb
Cr	52	238749.3	48.11171	ppb
Cr	53	29000.8	48.89942	ppb
Mn	55	330262.3	48.10478	ppb
Co	59	326820.7	49.31608	ppb
Ni	60	77170.3	51.06505	ppb
Cu	63	177846.2	50.78249	ppb
Cu	65	85136.9	51.04305	ppb
Zn	66	45122.5	48.75452	ppb
Zn	67	7830.1	49.16902	ppb
Zn	68	38084.7	49.5475	ppb
As	75	56941.6	49.4781	ppb
Se	77	3871.5	38.7488	ppb
Se	82	4942.2	39.31374	ppb
Rh	103	291643		ppb
Ag	107	179771.1	24.52997	ppb
Ag	109	170286.6	24.34746	ppb
Cd	111	66153.1	41.35821	ppb
Cd	114	150952	41.396	ppb
Sb	121	268087.5	58.25891	ppb
Sb	123	205533.6	58.12105	ppb
Ba	135	86643.9	48.48	ppb
Ba	137	154334	48.72035	ppb
Ho	165	654763		ppb
Tl	205	1075185.3	50.28611	ppb
Pb	208	1456406.8	50.88198	ppb
Kr	83	67.7		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: 3361-1  
 Sample Date/Time: Tuesday, June 15, 2004 14:03:14  
 Sample Description: Air Test Professionals, Inc.  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
>	Li	6	114531.1	ppb
	Be	9	20.7	0.07477 ppb
	P	31	42770.5	190.34355 ppb
	Sc	45	122667.4	ppb
	Cr	52	456487.8	87.78185 ppb
	Cr	53	52587.2	84.42705 ppb
	Mn	55	1466937.7	201.92553 ppb
	Co	59	6238.2	0.88088 ppb
	Ni	60	37799.1	23.60457 ppb
	Cu	63	104314.1	28.10686 ppb
	Cu	65	50261.8	28.41768 ppb
	Zn	66	453996.2	467.46083 ppb
	Zn	67	69476.3	418.12856 ppb
	Zn	68	329685.1	443.00602 ppb
	As	75	2244.2	1.9799 ppb
	Se	77	220.3	0.72999 ppb
	Se	82	34.1	0.23273 ppb
>	Rh	103	308787.3	ppb
	Ag	107	14837.9	1.87779 ppb
	Ag	109	12328.1	1.62921 ppb
	Cd	111	5164.4	3.03706 ppb
	Cd	114	5899.2	1.51541 ppb
	Sb	121	8737.3	1.68045 ppb
	Sb	123	6774.2	1.69413 ppb
	Ba	135	64030.6	33.31044 ppb
	Ba	137	113907	33.43407 ppb
>	Ho	165	703910.5	ppb
	Tl	205	3767.9	0.14905 ppb
	Pb	208	715932.8	23.21536 ppb
	Kr	83	144	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: 3361-2  
 Sample Date/Time: Tuesday, June 15, 2004 14:06:16  
 Sample Description: Air Test Professionals, Inc.  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
>	Li	6	115033.4	ppb
	Be	9	21	0.07644 ppb
	P	31	34354.1	146.54992 ppb
	Sc	45	123866.7	ppb
	Cr	52	167593.6	30.8317 ppb
	Cr	53	20214.3	31.23436 ppb
	Mn	55	514919.2	69.47319 ppb
	Co	59	2844.8	0.38935 ppb
	Ni	60	17287.6	10.55419 ppb
	Cu	63	44186.6	11.63362 ppb
	Cu	65	21472.9	11.84236 ppb
	Zn	66	200612.8	202.22704 ppb
	Zn	67	31061.3	182.7723 ppb
	Zn	68	150044.5	194.68256 ppb
	As	75	497	0.543 ppb
	Se	77	207.3	0.56147 ppb
	Se	82	-51.5	-0.40239 ppb
>	Rh	103	314926.1	ppb
	Ag	107	9371.3	1.14843 ppb
	Ag	109	7411.8	0.94436 ppb
	Cd	111	3252.1	1.87153 ppb
	Cd	114	1459.5	0.35923 ppb
	Sb	121	6279.2	1.16469 ppb
	Sb	123	4812.8	1.15961 ppb
	Ba	135	57782.6	29.64845 ppb
	Ba	137	102390.6	29.63041 ppb
>	Ho	165	713981.6	ppb
	Tl	205	882.1	0.02256 ppb
	Pb	208	359147.1	11.43891 ppb
	Kr	83	215	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: 3361-2  
 Sample Date/Time: Tuesday, June 15, 2004 14:09:18  
 Sample Description: Air Test Professionals, Inc.  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
Li	6	115774.8		ppb
Be	9	20.3	0.0718	ppb
P	31	36216.4	153.8675	ppb
Sc	45	126363.6		ppb
Cr	52	171447.4	31.29138	ppb
Cr	53	20488.6	31.3838	ppb
Mn	55	521080	69.69863	ppb
Co	59	2888.2	0.392	ppb
Ni	60	17370.8	10.51617	ppb
Cu	63	44683.3	11.6651	ppb
Cu	65	21756.9	11.89638	ppb
Zn	66	205266	205.1556	ppb
Zn	67	31631.6	184.51221	ppb
Zn	68	152862.1	196.70761	ppb
As	75	385.2	0.44999	ppb
Se	77	204.3	0.51568	ppb
Se	82	-24.2	-0.19906	ppb
Rh	103	317666.8		ppb
Ag	107	8979.9	1.08909	ppb
Ag	109	7109.2	0.89631	ppb
Cd	111	3095	1.76502	ppb
Cd	114	1899	0.46589	ppb
Sb	121	6077.1	1.09307	ppb
Sb	123	4779.6	1.11864	ppb
Ba	135	58349	29.14825	ppb
Ba	137	103983	29.30427	ppb
Ho	165	733064.2		ppb
Tl	205	688.7	0.01348	ppb
Pb	208	364648.5	11.30785	ppb
Kr	83	173.7		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: 3361-4  
 Sample Date/Time: Tuesday, June 15, 2004 14:12:20  
 Sample Description: Air Test Professionals, Inc.  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
Li	6	118475.8		ppb
Be	9	20.3	0.0688	ppb
P	31	35532.3	148.02026	ppb
Sc	45	126147.5		ppb
Cr	52	182462.9	32.82048	ppb
Cr	53	21880.2	33.02915	ppb
Mn	55	477126.5	62.77972	ppb
Co	59	2863.8	0.35489	ppb
Ni	60	21102.7	12.57845	ppb
Cu	63	52223.5	13.41987	ppb
Cu	65	25347.9	13.64968	ppb
Zn	66	232454.6	228.66046	ppb
Zn	67	35329.9	202.88874	ppb
Zn	68	170206.7	216.0059	ppb
As	75	541.5	0.5689	ppb
Se	77	220.3	0.63382	ppb
Se	82	-6	-0.06242	ppb
Rh	103	322897.9		ppb
Ag	107	9145	1.09137	ppb
Ag	109	7055.5	0.87415	ppb
Cd	111	2738.6	1.53417	ppb
Cd	114	1284.6	0.30672	ppb
Sb	121	20748.2	3.88472	ppb
Sb	123	15791.5	3.84378	ppb
Ba	135	55712.5	27.40694	ppb
Ba	137	98111.2	27.23405	ppb
Ho	165	744273.5		ppb
Tl	205	412.7	0.00168	ppb
Pb	208	316976.9	9.66861	ppb
Kr	83	187		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: 3361-4  
 Sample Date/Time: Tuesday, June 15, 2004 14:15:23  
 Sample Description: Air Test Professionals, Inc.  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
>	Li	6	112819.2	ppb
	Be	9	8323.9	48.02309 ppb
	P	31	73993.3	339.04698 ppb
	Sc	45	121322.7	ppb
	Cr	52	443563.6	84.97022 ppb
	Cr	53	53381.9	85.29373 ppb
	Mn	55	840392.5	115.16887 ppb
	Co	59	363560.9	51.57233 ppb
	Ni	60	104032.7	64.73041 ppb
	Cu	63	244177.1	65.58176 ppb
	Cu	65	117816.2	66.45671 ppb
	Zn	66	273554.2	280.23886 ppb
	Zn	67	42791.2	256.04824 ppb
	Zn	68	203489.4	270.09185 ppb
	As	75	58908.5	48.12899 ppb
	Se	77	4373.4	41.2352 ppb
	Se	82	5370.5	40.14844 ppb
>	Rh	103	310171.1	ppb
	Ag	107	381013	48.92498 ppb
	Ag	109	361679.2	48.65139 ppb
	Cd	111	77124.2	45.33797 ppb
	Cd	114	171640.1	44.26536 ppb
	Sb	121	275049.7	55.02802 ppb
	Sb	123	212994.3	55.44778 ppb
	Ba	135	149689.9	77.15315 ppb
	Ba	137	267006.6	77.63109 ppb
>	Ho	165	711144.7	ppb
	Tl	205	1201065.9	51.71942 ppb
	Pb	208	1906384.8	61.35007 ppb
	Kr	83	179.7	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: 3361-6  
 Sample Date/Time: Tuesday, June 15, 2004 14:18:26  
 Sample Description: Air Test Professionals, Inc.  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
>	Li	6	116421.1	ppb
	Be	9	18	0.058 ppb
	P	31	36612.3	157.25071 ppb
	Sc	45	135501.9	ppb
	Cr	52	111350.4	20.01697 ppb
	Cr	53	11743.7	17.75441 ppb
	Mn	55	244478.3	32.96001 ppb
	Co	59	84130.4	11.74695 ppb
	Ni	60	33755.2	20.64772 ppb
	Cu	63	49523	13.04764 ppb
	Cu	65	24033.3	13.26355 ppb
	Zn	66	26358.4	26.13929 ppb
	Zn	67	4489.2	25.72345 ppb
	Zn	68	23626.6	26.20722 ppb
	As	75	657.6	0.67171 ppb
	Se	77	199.3	0.48353 ppb
	Se	82	2.1	-0.00667 ppb
>	Rh	103	315019.9	ppb
	Ag	107	3536.4	0.41052 ppb
	Ag	109	2032.6	0.23158 ppb
	Cd	111	2572.7	1.47678 ppb
	Cd	114	618.1	0.14393 ppb
	Sb	121	8590.8	1.58234 ppb
	Sb	123	6506.6	1.55615 ppb
	Ba	135	60321.4	30.14483 ppb
	Ba	137	108443	30.57465 ppb
>	Ho	165	732911.6	ppb
	Tl	205	355.3	-0.00044 ppb
	Pb	208	149385.8	4.57952 ppb
	Kr	83	109	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 3  
 Sample Date/Time: Tuesday, June 15, 2004 14:21:28  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
>	Li	6	110746	ppb
	Be	9	6.7	-0.00338 ppb
	P	31	3187.9	0.08606 ppb
	Sc	45	102382.7	ppb
	Cr	52	6501.7	0.04175 ppb
	Cr	53	772.4	0.35296 ppb
	Mn	55	393	0.01042 ppb
	Co	59	89	0.00484 ppb
	Ni	60	75	0.00254 ppb
	Cu	63	239.7	0.00042 ppb
	Cu	65	228.7	0.02731 ppb
	Zn	66	537.4	0.07125 ppb
	Zn	67	173.3	0.25617 ppb
	Zn	68	3922.2	0.15945 ppb
	As	75	-28.5	0.12043 ppb
	Se	77	161.7	0.18594 ppb
	Se	82	16.5	0.10455 ppb
>	Rh	103	302763.8	ppb
	Ag	107	520.4	0.03111 ppb
	Ag	109	561	0.03921 ppb
	Cd	111	18.8	-0.00055 ppb
	Cd	114	49.8	0.00127 ppb
	Sb	121	400	-0.00423 ppb
	Sb	123	311.1	-0.00539 ppb
	Ba	135	94	0.01494 ppb
	Ba	137	147.7	0.01167 ppb
>	Ho	165	678000.6	ppb
	Tl	205	371	0.00147 ppb
	Pb	208	3159.9	0.01464 ppb
	Kr	83	57.7	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 4  
 Sample Date/Time: Tuesday, June 15, 2004 14:24:30  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
>	Li	6	108090.7	ppb
	Be	9	8588.1	51.72158 ppb
	P	31	41477.9	196.48534 ppb
	Sc	45	106571.5	ppb
	Cr	52	246362.3	49.83839 ppb
	Cr	53	29569.3	50.04498 ppb
	Mn	55	335858.3	49.08234 ppb
	Co	59	332085	50.26094 ppb
	Ni	60	78250.9	51.93211 ppb
	Cu	63	187138.7	53.61012 ppb
	Cu	65	89334.8	53.74607 ppb
	Zn	66	54041	58.6722 ppb
	Zn	67	9348.2	59.05866 ppb
	Zn	68	44008.7	58.26212 ppb
	As	75	64308.1	56.03232 ppb
	Se	77	4954.4	50.13592 ppb
	Se	82	6381.1	50.89092 ppb
>	Rh	103	290742.2	ppb
	Ag	107	353365.1	48.41077 ppb
	Ag	109	335496.3	48.15021 ppb
	Cd	111	77430.7	48.55825 ppb
	Cd	114	177852.2	48.92982 ppb
	Sb	121	237679.3	50.99571 ppb
	Sb	123	185456.7	51.78097 ppb
	Ba	135	90728.7	50.13626 ppb
	Ba	137	159651	49.77011 ppb
>	Ho	165	663042.4	ppb
	Tl	205	1175531.2	54.29819 ppb
	Pb	208	1555888.4	53.68606 ppb
	Kr	83	61	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: LRB  
 Sample Date/Time: Tuesday, June 15, 2004 14:48:05  
 Sample Description: Air Test Professionals, Inc.  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
Li	6	112638.5		ppb
Be	9	9.3	0.01127	ppb
P	31	4774.6	8.35918	ppb
Sc	45	109922.7		ppb
Cr	52	6974.1	0.1652	ppb
Cr	53	673.4	0.21255	ppb
Mn	55	1142.4	0.119	ppb
Co	59	188	0.0198	ppb
Ni	60	288.7	0.14257	ppb
Cu	63	609.7	0.1058	ppb
Cu	65	387	0.12392	ppb
Zn	66	1018.1	0.59876	ppb
Zn	67	228	0.62279	ppb
Zn	68	4219.7	0.6953	ppb
As	75	102.1	0.23198	ppb
Se	77	156.3	0.16409	ppb
Se	82	34.8	0.25118	ppb
Rh	103	296527.4		ppb
Ag	107	248.7	-0.004	ppb
Ag	109	224	-0.00671	ppb
Cd	111	86.3	0.04113	ppb
Cd	114	106.3	0.01675	ppb
Sb	121	33494.6	7.05179	ppb
Sb	123	25670.7	7.03091	ppb
Ba	135	242	0.09685	ppb
Ba	137	424	0.09783	ppb
Ho	165	668483.8		ppb
Tl	205	941.7	0.02785	ppb
Pb	208	15519.7	0.43993	ppb
Kr	83	57		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: LRB  
 Sample Date/Time: Tuesday, June 15, 2004 14:51:08  
 Sample Description: Air Test Professionals, Inc.  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
Li	6	114479.9		ppb
Be	9	4065.9	23.10013	ppb
P	31	23211.8	97.88422	ppb
Sc	45	111683.3		ppb
Cr	52	125059.9	23.53732	ppb
Cr	53	14860.3	23.55725	ppb
Mn	55	171680.2	23.96248	ppb
Co	59	166847.9	24.13449	ppb
Ni	60	39539.9	25.06332	ppb
Cu	63	91819.1	25.10751	ppb
Cu	65	43925	25.20658	ppb
Zn	66	25762	26.46996	ppb
Zn	67	4498.5	26.71731	ppb
Zn	68	22767.7	26.14247	ppb
As	75	30293.6	25.30965	ppb
Se	77	2210	20.55369	ppb
Se	82	2719.9	20.72149	ppb
Rh	103	304146.3		ppb
Ag	107	88361.6	11.54425	ppb
Ag	109	83333.8	11.40297	ppb
Cd	111	35745	21.42248	ppb
Cd	114	82135.3	21.59798	ppb
Sb	121	143784.2	29.95928	ppb
Sb	123	111148.5	30.13654	ppb
Ba	135	44934.6	24.12788	ppb
Ba	137	79421.5	24.0596	ppb
Ho	165	681940.5		ppb
Tl	205	565666.2	25.39531	ppb
Pb	208	767532.4	25.7079	ppb
Kr	83	60.3		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: 3361-1  
 Sample Date/Time: Tuesday, June 15, 2004 14:54:12  
 Sample Description: Air Test Professionals, Inc.  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
>	Li	6	115851.4	ppb
	Be	9	9	0.00785 ppb
	P	31	11262.1	39.39992 ppb
	Sc	45	112297.8	ppb
	Cr	52	89974.4	16.55977 ppb
	Cr	53	10624.3	16.55077 ppb
	Mn	55	290443.9	40.50868 ppb
	Co	59	1259.8	0.17396 ppb
	Ni	60	7553.9	4.74345 ppb
	Cu	63	21916.6	5.93517 ppb
	Cu	65	10594.3	5.98963 ppb
	Zn	66	108688.3	113.10563 ppb
	Zn	67	16555.6	100.39517 ppb
	Zn	68	81676.6	107.27849 ppb
	As	75	366	0.44834 ppb
	Se	77	178	0.33934 ppb
	Se	82	23.7	0.15888 ppb
>	Rh	103	304549.9	ppb
	Ag	107	4128.6	0.5029 ppb
	Ag	109	3704.8	0.46964 ppb
	Cd	111	978.1	0.57414 ppb
	Cd	114	1253	0.31725 ppb
	Sb	121	1893.9	0.30188 ppb
	Sb	123	1407.2	0.28677 ppb
	Ba	135	12838.5	6.76943 ppb
	Ba	137	22972.9	6.835 ppb
>	Ho	165	691825	ppb
	Tl	205	3821.3	0.15493 ppb
	Pb	208	147151.8	4.78365 ppb
	Kr	83	77.3	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 3  
 Sample Date/Time: Tuesday, June 15, 2004 14:57:15  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
>	Li	6	108915.4	ppb
	Be	9	7.3	0.00124 ppb
	P	31	2956.2	-0.451 ppb
	Sc	45	98787.3	ppb
	Cr	52	6446.7	0.08415 ppb
	Cr	53	647.4	0.19055 ppb
	Mn	55	331.7	0.00378 ppb
	Co	59	57.7	0.00064 ppb
	Ni	60	60.7	-0.00496 ppb
	Cu	63	225	-0.00106 ppb
	Cu	65	195.3	0.01273 ppb
	Zn	66	506.4	0.06081 ppb
	Zn	67	153.3	0.17233 ppb
	Zn	68	3842.2	0.2706 ppb
	As	75	-173.1	-0.00606 ppb
	Se	77	155	0.18336 ppb
	Se	82	5.8	0.02532 ppb
>	Rh	103	290695.5	ppb
	Ag	107	440.3	0.02298 ppb
	Ag	109	424.3	0.02277 ppb
	Cd	111	20	0.00062 ppb
	Cd	114	47.5	0.00123 ppb
	Sb	121	349	-0.01242 ppb
	Sb	123	280	-0.0112 ppb
	Ba	135	79.3	0.0085 ppb
	Ba	137	120	0.00454 ppb
>	Ho	165	655235	ppb
	Tl	205	681	0.01654 ppb
	Pb	208	3108.2	0.01655 ppb
	Kr	83	59.7	ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 4  
 Sample Date/Time: Tuesday, June 15, 2004 15:00:17  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
Li	6	106939.6		ppb
Be	9	8322.9	50.67204	ppb
P	31	39729	193.34058	ppb
Sc	45	102767.5		ppb
Cr	52	238222.9	49.55686	ppb
Cr	53	28652.7	49.8625	ppb
Mn	55	325814.2	48.97116	ppb
Co	59	320143.3	49.82828	ppb
Ni	60	75527.5	51.55045	ppb
Cu	63	179315.5	52.82626	ppb
Cu	65	87111.3	53.90008	ppb
Zn	66	52963	59.1405	ppb
Zn	67	8952.2	58.1456	ppb
Zn	68	42549.8	57.90034	ppb
As	75	62354.5	55.8778	ppb
Se	77	4898.7	51.0062	ppb
Se	82	6205.6	50.90858	ppb
Rh	103	282689.6		ppb
Ag	107	342712.5	48.28735	ppb
Ag	109	327763.8	48.3789	ppb
Cd	111	74596.1	48.11457	ppb
Cd	114	172229.5	48.7354	ppb
Sb	121	231357.6	51.50968	ppb
Sb	123	178675.5	51.77094	ppb
Ba	135	87488.2	50.17618	ppb
Ba	137	154617.7	50.02396	ppb
Ho	165	638949.8		ppb
Tl	205	1142490.2	54.77132	ppb
Pb	208	1493768.1	53.49205	ppb
Kr	83	70.7		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: LRB  
 Sample Date/Time: Tuesday, June 15, 2004 15:12:37  
 Sample Description: Air Test Professionals, Inc.  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
Li	6	114343		ppb
Be	9	8.3	0.00482	ppb
P	31	6011.4	13.7963	ppb
Sc	45	113691.1		ppb
Cr	52	7653.6	0.26391	ppb
Cr	53	706	0.23818	ppb
Mn	55	2022.9	0.23803	ppb
Co	59	331	0.0398	ppb
Ni	60	548.4	0.3031	ppb
Cu	63	1033.1	0.21764	ppb
Cu	65	604	0.24297	ppb
Zn	66	1412.8	0.98481	ppb
Zn	67	295	0.99807	ppb
Zn	68	4531.2	0.97443	ppb
As	75	374.5	0.45501	ppb
Se	77	178	0.34032	ppb
Se	82	32.1	0.22292	ppb
Rh	103	304213.9		ppb
Ag	107	285.3	-0.00002	ppb
Ag	109	254.3	-0.00333	ppb
Cd	111	116.7	0.058	ppb
Cd	114	158.6	0.02979	ppb
Sb	121	64415.4	13.25514	ppb
Sb	123	49664.1	13.29746	ppb
Ba	135	418.3	0.18708	ppb
Ba	137	725	0.18458	ppb
Ho	165	687946		ppb
Tl	205	1956.6	0.07182	ppb
Pb	208	28497.4	0.85718	ppb
Kr	83	62		ppb



Method 6020 & 200.8 Metals Summary Report

Sample ID: LRB  
 Sample Date/Time: Tuesday, June 15, 2004 15:15:42  
 Sample Description: Air Test Professionals, Inc.  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
Li	6	113612.5		ppb
Be	9	7602.9	43.55313	ppb
P	31	41851.6	191.35263	ppb
Sc	45	114576.7		ppb
Cr	52	243565.1	47.58516	ppb
Cr	53	55679.6	91.87569	ppb
Mn	55	336538.3	47.54439	ppb
Co	59	324307.9	47.4531	ppb
Ni	60	75980.3	48.74841	ppb
Cu	63	174333.7	48.27461	ppb
Cu	65	84089	48.89891	ppb
Zn	66	45738.9	47.91865	ppb
Zn	67	9170.4	55.97117	ppb
Zn	68	37904.9	47.63496	ppb
As	75	55208.2	46.53308	ppb
Se	77	6548.8	64.46777	ppb
Se	82	4893.9	37.73727	ppb
Rh	103	300730.6		ppb
Ag	107	167757.8	22.19847	ppb
Ag	109	160910.2	22.30812	ppb
Cd	111	66312.1	40.20823	ppb
Cd	114	153258.6	40.75881	ppb
Sb	121	273945.6	56.84281	ppb
Sb	123	210480.6	56.83588	ppb
Ba	135	87575	46.79357	ppb
Ba	137	156123.5	47.06068	ppb
Ho	165	685692.1		ppb
Tl	205	1091846.4	48.76631	ppb
Pb	208	1488732.6	49.66426	ppb
Kr	83	62.3		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 3  
 Sample Date/Time: Tuesday, June 15, 2004 15:18:45  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
Li	6	107229.7		ppb
Be	9	6.7	-0.00203	ppb
P	31	2970.5	0.04562	ppb
Sc	45	95333.5		ppb
Cr	52	6281.6	0.08584	ppb
Cr	53	2998.9	4.39835	ppb
Mn	55	343.3	0.0068	ppb
Co	59	79.3	0.00429	ppb
Ni	60	70.7	0.003	ppb
Cu	63	255.7	0.00977	ppb
Cu	65	214.7	0.02799	ppb
Zn	66	532.7	0.10555	ppb
Zn	67	429	2.01806	ppb
Zn	68	3781.2	0.33338	ppb
As	75	-130.3	0.02827	ppb
Se	77	206.7	0.78196	ppb
Se	82	10.8	0.06677	ppb
Rh	103	282886.4		ppb
Ag	107	696.7	0.06097	ppb
Ag	109	651.7	0.05813	ppb
Cd	111	21.2	0.00176	ppb
Cd	114	58.6	0.00469	ppb
Sb	121	348	-0.00987	ppb
Sb	123	251.3	-0.01673	ppb
Ba	135	79	0.00999	ppb
Ba	137	133.7	0.01038	ppb
Ho	165	631701.2		ppb
Tl	205	4756	0.21608	ppb
Pb	208	3169.3	0.02292	ppb
Kr	83	61		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 4  
 Sample Date/Time: Tuesday, June 15, 2004 15:21:48  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
Li	6	105829.1		ppb
Be	9	8240.5	50.68498	ppb
P	31	38942.3	191.77632	ppb
Sc	45	102373.8		ppb
Cr	52	232704.2	49.00553	ppb
Cr	53	29038.6	51.19447	ppb
Mn	55	314816.2	47.90553	ppb
Co	59	313725.1	49.44419	ppb
Ni	60	74076.4	51.19783	ppb
Cu	63	177382.1	52.92217	ppb
Cu	65	85317	53.45369	ppb
Zn	66	51510.7	58.23552	ppb
Zn	67	8995.9	59.17994	ppb
Zn	68	42212.9	58.1917	ppb
As	75	61815.7	56.09713	ppb
Se	77	4844	51.07389	ppb
Se	82	6135.6	50.96123	ppb
Rh	103	279146.8		ppb
Ag	107	336606	48.01669	ppb
Ag	109	319513.3	47.75333	ppb
Cd	111	73750.5	48.17063	ppb
Cd	114	168613.2	48.31125	ppb
Sb	121	227624	51.77439	ppb
Sb	123	174736.4	51.72782	ppb
Ba	135	84734.6	49.66051	ppb
Ba	137	151803.8	50.18892	ppb
Ho	165	625272.9		ppb
Tl	205	1112547.4	54.50172	ppb
Pb	208	1470228.3	53.80109	ppb
Kr	83	72		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC #1  
 Sample Date/Time: Tuesday, June 15, 2004 15:32:47  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
Li	6	105399.7		ppb
Be	9	1533.8	9.44085	ppb
P	31	3011.5	0.48236	ppb
Sc	45	96907.5		ppb
Cr	52	49968.1	9.54204	ppb
Cr	53	6210.5	10.22745	ppb
Mn	55	63011.6	9.55701	ppb
Co	59	62597.7	9.86371	ppb
Ni	60	14341.8	9.87941	ppb
Cu	63	34646.9	10.28789	ppb
Cu	65	16669.4	10.363	ppb
Zn	66	9653.6	10.51723	ppb
Zn	67	1774.9	11.03411	ppb
Zn	68	10518.9	10.54384	ppb
As	75	11122.9	10.21888	ppb
Se	77	1078.4	10.26452	ppb
Se	82	1213.6	10.06943	ppb
Rh	103	279090.7		ppb
Ag	107	68954.2	9.81158	ppb
Ag	109	65434	9.75268	ppb
Cd	111	14792.1	9.65306	ppb
Cd	114	34080.6	9.75851	ppb
Sb	121	45342.6	10.30875	ppb
Sb	123	34769.5	10.28451	ppb
Ba	135	16717.2	9.82805	ppb
Ba	137	29693	9.84959	ppb
Ho	165	621442.4		ppb
Tl	205	214005	10.53429	ppb
Pb	208	284292.2	10.39183	ppb
Kr	83	63		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC #2  
 Sample Date/Time: Tuesday, June 15, 2004 15:35:51  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
Li	6	107156.1		ppb
Be	9	174.7	1.01895	ppb
P	31	6563.1	19.27726	ppb
Sc	45	99282.3		ppb
Cr	52	10587.6	1.02713	ppb
Cr	53	1449.1	1.66837	ppb
Mn	55	6714.2	0.97501	ppb
Co	59	6418.3	1.00069	ppb
Ni	60	1558.1	1.02961	ppb
Cu	63	3762.1	1.05494	ppb
Cu	65	1849.9	1.05287	ppb
Zn	66	1457.1	1.16275	ppb
Zn	67	348.7	1.50868	ppb
Zn	68	4466.8	1.41911	ppb
As	75	937	0.99011	ppb
Se	77	249.3	1.26512	ppb
Se	82	114.8	0.92975	ppb
Rh	103	279958.2		ppb
Ag	107	7300	1.00181	ppb
Ag	109	6900.7	0.99106	ppb
Cd	111	1498.1	0.96397	ppb
Cd	114	3482.9	0.98331	ppb
Sb	121	4943.4	1.04137	ppb
Sb	123	3805.2	1.04117	ppb
Ba	135	1732.8	0.98296	ppb
Ba	137	3062.5	0.98238	ppb
Ho	165	623628.2		ppb
Tl	205	21916.9	1.06141	ppb
Pb	208	30889.2	1.04308	ppb
Kr	83	63.3		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 3  
 Sample Date/Time: Tuesday, June 15, 2004 15:38:53  
 Sample Description:  
 Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
Li	6	106380.5		ppb
Be	9	7	0.00039	ppb
P	31	2794.1	-0.66202	ppb
Sc	45	98287.3		ppb
Cr	52	6195.8	0.08747	ppb
Cr	53	885.1	0.66607	ppb
Mn	55	318.7	0.00387	ppb
Co	59	60	0.00139	ppb
Ni	60	68	0.00182	ppb
Cu	63	218	-0.00036	ppb
Cu	65	198	0.01949	ppb
Zn	66	475	0.04869	ppb
Zn	67	180.7	0.39601	ppb
Zn	68	3761.1	0.38741	ppb
As	75	-143.1	0.01493	ppb
Se	77	147.3	0.16917	ppb
Se	82	12.5	0.08307	ppb
Rh	103	278674.3		ppb
Ag	107	445	0.02625	ppb
Ag	109	426.3	0.02564	ppb
Cd	111	22.2	0.00266	ppb
Cd	114	52.5	0.00319	ppb
Sb	121	511	0.0296	ppb
Sb	123	384.7	0.02511	ppb
Ba	135	85	0.01469	ppb
Ba	137	126	0.00892	ppb
Ho	165	617297.3		ppb
Tl	205	553	0.01215	ppb
Pb	208	2908.2	0.01582	ppb
Kr	83	56.7		ppb

Method 6020 & 200.8 Metals Summary Report

Sample ID:

QC Std 4

Sample Date/Time:

Tuesday, June 15, 2004 15:41:55

Sample Description:

Concentration Results

Analyte	Mass	Meas. Intens. Mean	Conc. Mean	Report Unit
Li	6	105029.4		ppb
Be	9	8256.8	51.1701	ppb
P	31	38438.5	190.08888	ppb
Sc	45	100019		ppb
Cr	52	230672	48.82083	ppb
Cr	53	28263.5	50.05676	ppb
Mn	55	312500.4	47.78854	ppb
Co	59	311219.8	49.29178	ppb
Ni	60	73878.1	51.31794	ppb
Cu	63	175312.2	52.56917	ppb
Cu	65	83737.4	52.7244	ppb
Zn	66	51037.1	57.98202	ppb
Zn	67	8754	57.85545	ppb
Zn	68	41603.7	57.58967	ppb
As	75	60589	55.26268	ppb
Se	77	4670.9	49.44975	ppb
Se	82	5998.9	50.07857	ppb
Rh	103	277764.7		ppb
Ag	107	333224	47.76969	ppb
Ag	109	318424.4	47.83093	ppb
Cd	111	72427.5	47.54172	ppb
Cd	114	167349.3	48.18436	ppb
Sb	121	225787.6	52.0123	ppb
Sb	123	174870	52.42783	ppb
Ba	135	84290.8	50.02997	ppb
Ba	137	149983.5	50.21447	ppb
Ho	165	617326.6		ppb
Tl	205	1099004.5	54.52809	ppb
Pb	208	1441577.1	53.42833	ppb
Kr	83	60.7		ppb

Mercury Perkin-Elmer AAWinLab

ID #	Sample_ID	Sam_Date	Sam_Time	Mean_Sig	Mean_ST	Mean_SA	Units	Wt	Dilu
1	Calib Blank	6/11/2004	12:39:58	8.15E-05			mg/L		1
	STD1=.04ug	6/11/2004	12:41:02	0.008887			mg/L		2
3	STD2=.08ug	6/11/2004	12:42:06	0.018055			mg/L		3
4	STD3=.12ug	6/11/2004	12:43:11	0.026582			mg/L		4
5	STD4=.16ug	6/11/2004	12:44:17	0.036754			mg/L		5
6	STD5=.2ug	6/11/2004	12:45:24	0.044488			mg/L		6
7	Reagent Blank	6/11/2004	12:47:01	5.08E-05	0.000228	0.000228	mg/L		1
8	0.004 = DL	6/11/2004	12:48:06	0.000896	0.004019	0.004019	mg/L		7
9	0.080 = QC STD 2	6/11/2004	12:49:13	0.018633	0.083215	0.083215	mg/L		5
10	0.080 = QC STD 3	6/11/2004	12:50:19	0.017809	0.079549	0.079549	mg/L		6
11	REAGENT BLANK	6/11/2004	12:51:24	-9.82E-05	-0.00044	-0.00044	mg/L		1
12	3361-1-A	6/11/2004	12:52:57	-2.05E-05	-9.2E-05	-0.00461	mg/L		9 200
13	3361-2/3-A	6/11/2004	12:54:31	-7E-07	-3.3E-06	-0.00017	mg/L		10 200
14	3361-4-A	6/11/2004	12:56:06	-2.77E-05	-0.00012	-0.00623	mg/L		11 200
15	3361-5-A-SPK	6/11/2004	12:57:41	0.017794	0.079483	3.974161	mg/L		12 200
16	3361-6-A	6/11/2004	12:59:18	1.07E-06	4.8E-06	0.00024	mg/L		13 200
17	3361-1-B	6/11/2004	13:00:55	0.001782	0.007988	1.198252	mg/L		14 600
18	3361-2/3-B	6/11/2004	13:02:33	0.001263	0.005663	0.707897	mg/L		15 500
19	3361-4-B	6/11/2004	13:04:13	0.004568	0.020468	3.070224	mg/L		16 600
20	3361-5-B-SPK	6/11/2004	13:05:49	0.020926	0.093403	14.01039	mg/L		17 600
21	3361-6-B	6/11/2004	13:07:21	0.000171	0.000765	0.076492	mg/L		18 400
	0.004 = DL	6/11/2004	13:08:26	0.00084	0.003767	0.003767	mg/L		7 400
23	0.080 = QC STD 2	6/11/2004	13:09:33	0.017923	0.080056	0.080056	mg/L		5 400
24	REAGENT BLANK	6/11/2004	13:10:38	-8.67E-05	-0.00039	-0.00039	mg/L		1 400
25	Calib Blank	6/16/2004	10:02:28	0.000164			mg/L		1
26	STD1=.04ug	6/16/2004	10:03:31	0.009311			mg/L		2
27	STD2=.08ug	6/16/2004	10:04:35	0.018597			mg/L		3
28	STD3=.12ug	6/16/2004	10:05:40	0.027207			mg/L		4
29	STD4=.16ug	6/16/2004	10:06:46	0.034684			mg/L		5
30	STD5=.2ug	6/16/2004	10:07:53	0.044932			mg/L		6
31	Reagent Blank	6/16/2004	10:10:00	7.62E-05	0.000322	0.000322	mg/L		1
32	0.004 = DL	6/16/2004	10:11:05	0.000913	0.003864	0.003864	mg/L		7
33	0.080 = QC STD 2	6/16/2004	10:12:12	0.019404	0.084558	0.084558	mg/L		5
34	0.080 = QC STD 3	6/16/2004	10:13:18	0.018757	0.081652	0.081652	mg/L		6
35	REAGENT BLANK	6/16/2004	10:14:21	4.99E-05	0.000211	0.000211	mg/L		1
36	3361-1-FH	6/16/2004	10:25:32	0.000161	0.000681	0.017036	mg/L		9 100
37	3361-2/3-FH	6/16/2004	10:27:05	0.000132	0.000556	0.013912	mg/L		10 100
38	3361-4/5-FH	6/16/2004	10:28:39	0.004906	0.020898	0.522451	mg/L		11 100
39	3361-4/5-FH-SPK	6/16/2004	10:30:14	0.023959	0.105168	2.629198	mg/L		12 100
40	0.004 = DL	6/16/2004	10:31:20	0.000995	0.004214	0.004214	mg/L		7 100
41	0.080 = QC STD 2	6/16/2004	10:32:26	0.019169	0.083501	0.083501	mg/L		5 100
	REAGENT BLANK	6/16/2004	10:33:30	0.000109	0.000461	0.000461	mg/L		1 100
43	3361-6-FH	6/16/2004	10:35:04	9.64E-05	0.000408	0.010195	mg/L		13 100

ID #	Sig 1	Std_U 1	Smp_U 1	Sig 2	Std_U 2	Smp_U 2
1	0.00008153					
	0.00888746					
3	0.01805501					
4	0.02658208					
5	0.03675401					
6	0.04448763					
7	-0.0000033	-0.0000149	-0.0000149	0.00010502	0.0004711	0.0004711
8	0.00089613	0.00401859	0.00401859			
9	0.01863318	0.08321466	0.08321466			
10	0.01780898	0.07954901	0.07954901			
11	-0.0000982	-0.0004407	-0.0004407			
12	-0.0000589	-0.0002645	-0.0132259	0.00001786	8.014E-05	0.0040074
13	-0.000023	-0.0001035	-0.0051779	0.00002158	0.0000968	0.0048402
14	-0.0000218	-0.000098	-0.0049035	-0.0000336	-0.0001511	-0.0075573
15	0.01810345	0.08085885	4.04294254	0.01748497	0.0781076	3.9053786
16	-0.0000039	-0.0000175	-0.0008795	0.00000606	0.0000272	0.0013603
17	0.00176429	0.00791009	1.18651387	0.00179921	0.0080666	1.2099911
18	0.00123929	0.00555699	0.69462379	0.00128667	0.0057694	0.7211708
19	0.00461598	0.02068178	3.1022674	0.00452052	0.0202545	3.0381797
20	0.02086338	0.09312653	13.9689807	0.02098766	0.0936786	14.05179
21	0.00013335	0.0005981	0.05981023	0.00020774	0.0009317	0.093173
	0.00084012	0.00376745	0.00376745			
23	0.01792292	0.08005587	0.08005587			
24	-0.0000867	-0.000389	-0.000389			
25	0.00016406					
26	0.00931062					
27	0.01859707					
28	0.02720668					
29	0.03468363					
30	0.04493234					
31	0.00008851	0.00037427	0.00037427	0.00006391	0.0002703	0.0002703
32	0.00091262	0.00386382	0.00386382			
33	0.01940445	0.08455756	0.08455756			
34	0.01875691	0.08165213	0.08165213			
35	0.00004991	0.00021106	0.00021106			
36	0.00016783	0.00070977	0.01774435	0.00015444	0.0006531	0.0163279
37	0.0001329	0.00056201	0.01405049	0.00013028	0.0005509	0.013773
38	0.00495954	0.02112893	0.52822332	0.00485196	0.0206672	0.5166791
39	0.02469107	0.10850244	2.71256116	0.02322757	0.1018334	2.5458354
40	0.0009951	0.00421354	0.00421354			
41	0.01916915	0.08350111	0.08350111			
	0.00010895	0.00046072	0.00046072			
43	0.00009241	0.00039075	0.00976885	0.00010046	0.0004248	0.0106202

Mercury Perkin-Elmer AAWinLab

ID #	Sample_ID	Sam_Date	Sam_Time	Mean_Sig	Mean_ST	Mean_SA	Units	Wt	Dilu
44	3361-FH-BLK	6/16/2004	10:36:41	0.000119	0.000503	0.012564	mg/L	14	100
	3361-FH-BLK-SPK	6/16/2004	10:38:20	0.015631	0.06771	1.69275	mg/L	15	100
46	0.004 = DL	6/16/2004	10:50:33	0.000933	0.003952	0.003952	mg/L	7	400
47	0.080 = QC STD 2	6/16/2004	10:51:40	0.018594	0.080921	0.080921	mg/L	5	400
48	REAGENT BLANK	6/16/2004	10:52:44	6.83E-05	0.000289	0.000289	mg/L	1	400
49	0.004 = DL	6/16/2004	11:48:02	0.000987	0.00418	0.00418	mg/L	7	400
50	0.080 = QC STD 2	6/16/2004	11:49:10	0.019071	0.083059	0.083059	mg/L	5	400
51	REAGENT BLANK	6/16/2004	11:50:17	9.53E-05	0.000403	0.000403	mg/L	1	400
52	3361-1-BH	6/16/2004	11:51:55	0.008028	0.034365	2.749192	mg/L	53	320
53	3361-2/3-BH	6/16/2004	11:53:33	0.011792	0.050776	4.062064	mg/L	54	320
54	3361-4-BH	6/16/2004	11:55:14	0.01275	0.054981	3.986122	mg/L	55	290
55	3361-5-BH-SPK	6/16/2004	11:56:53	0.031167	0.13839	10.0333	mg/L	56	290
56	3361-6-BH	6/16/2004	11:58:32	0.000388	0.001642	0.123114	mg/L	57	300
57	0.004 = DL	6/16/2004	12:00:51	0.001036	0.004387	0.004387	mg/L	7	300
58	0.080 = QC STD 3	6/16/2004	12:02:01	0.018849	0.082066	0.082066	mg/L	6	300
59	REAGENT BLANK	6/16/2004	12:03:10	0.00017	0.000719	0.000719	mg/L	1	300

ID #	Sig 1	Std_U 1	Smp_U 1	Sig 2	Std_U 2	Smp_U 2
44	0.00012919	0.0005463	0.01365766	0.00010849	0.0004588	0.0114699
	0.01563841	0.06774279	1.69356988	0.01562363	0.0676772	1.6919301
46	0.00093344	0.00395211	0.00395211			
47	0.01859379	0.08092117	0.08092117			
48	0.00006832	0.00028891	0.00028891			
49	0.00098717	0.00417992	0.00417992			
50	0.01907069	0.08305928	0.08305928			
51	0.00009526	0.00040283	0.00040283			
52	0.00794445	0.03400241	2.72019355	0.00811172	0.0347274	2.7781904
53	0.01168987	0.05032584	4.02606793	0.01189508	0.0512257	4.0980591
54	0.01272112	0.05485393	3.97691002	0.0127789	0.055108	3.9953331
55	0.03091355	0.13720892	9.94764679	0.03142025	0.1395719	10.118961
56	0.00039557	0.00167344	0.12550859	0.00038049	0.0016096	0.1207192
57	0.00103598	0.00438693	0.00438693			
58	0.0188493	0.08206632	0.08206632			
59	0.00017005	0.00071915	0.00071915			





# ATP - Air Test Professionals, Inc.

1201 North Graham Avenue  
Indianapolis, Indiana 46219

Phone (317) 345-1723

Fax (317) 351-0411

Email: atp\_stack@sbglobal.net

## CHAIN OF CUSTODY RECORD

COMPANY:		PROJECT NAME/NUMBER:		BILLING INFORMATION		LAB JOB NO.	
ATP		Nucor Steel - PFF Baghouse					
SEND REPORT TO:		BILL TO:					
Carlos Brown							
ADDRESS:		ADDRESS:					
1201 N. Graham Ave.		Same					
Indianapolis, Indiana 46219							
PHONE:		PHONE:					
(317) 345-1723							
FAX:		PO NO:					
(317) 351-0411		079					
RUN 1	MeCl2 - Rinse	05/21/04	AQ	4 oz	1	X	* Perform Sulfate Correction
RUN 2	MeCl2 - Rinse	05/21/04	AQ	4 oz	1	X	
RUN 3	MeCl2 - Rinse	05/21/04	AQ	4 oz	1	X	
RUN 1	DI H2O - Rinse	05/21/04	AQ	1000 ml	1	X	
RUN 2	DI H2O - Rinse	05/21/04	AQ	1000 ml	1	X	
RUN 3	DI H2O - Rinse	05/21/04	AQ	1000 ml	1	X	
BLANK	MeCl2 BLANK	05/21/04	AQ	4 oz	1	X	
BLANK	DI H2O BLANK	05/21/04	AQ	1000 ml	1	X	
SAMPLER: Carlos Brown		SHIPMENT METHOD:		AIRBILL NO:			
REQUIRED TURNAROUND:		DATE		SIGNATURE		DATE	
		05/21/04		<i>[Signature]</i>			
PRINTED NAME/COMPANY		TIME		PRINTED NAME/COMPANY		TIME	
Craig Mcelford / Entery		3:00		Craig Mcelford / Entery			

T=25°C

# ATP - Air Test Professionals, Inc.

1201 North Graham Avenue  
Indianapolis, Indiana 46219


## CHAIN OF CUSTODY RECORD

Phone (317) 345-1723  
Fax (317) 351-0411  
Email: atp\_stack@sbcglobal.net

303

CUSTOMER INFORMATION				PROJECT INFORMATION				No. of Containers		EPA Method 29		REMARKS / PRECAUTIONS
COMPANY:	SEND REPORT TO:	ADDRESS:	PHONE:	PROJECT NAME/NUMBER:	BILLING INFORMATION:	ADDRESS:	PHONE:	FAX:	PO NO.:	LAB JOB NO.		
ATP	Carlos Brown	1201 N. Graham Ave. Indianapolis, Indiana 46219	(317) 345-1723	Nucor Steel - PPF Baghouse	Same	Same	(317) 345-1723	(317) 351-0411	079		Analyze for 16 Metals + Mercury	
SAMPLE NO	BLANK	Filter BLANK (12)	05/21/04	Filter	Bag							
SAMPLER: Carlos Brown												
REQUIRED TURNAROUND: .												
SHIPMENT METHOD:												
AIRBILL NO.:												
1. RELINQUISHED BY:				2. RECEIVED BY:				3. RECEIVED BY:				
SIGNATURE: <i>[Signature]</i>				SIGNATURE: <i>[Signature]</i>				SIGNATURE: <i>[Signature]</i>				
DATE: 05/21/04				DATE: 6/10/04				DATE: 6/10/04				
PRINTED NAME/COMPANY: ATP				PRINTED NAME/COMPANY: ATP				PRINTED NAME/COMPANY: ATP				
1. RECEIVED BY:				2. RECEIVED BY:				3. RECEIVED BY:				
SIGNATURE: <i>[Signature]</i>				SIGNATURE: <i>[Signature]</i>				SIGNATURE: <i>[Signature]</i>				
DATE: 6/10/04				DATE: 6/10/04				DATE: 6/10/04				
PRINTED NAME/COMPANY: ATP				PRINTED NAME/COMPANY: ATP				PRINTED NAME/COMPANY: ATP				

0224



# ATP - Air Test Professionals, Inc.

1201 North Graham Avenue  
Indianapolis, Indiana 46219

Phone (317) 345-1723  
Fax (317) 351-0411

Email: [atp\\_stack@sboglobal.net](mailto:atp_stack@sboglobal.net)

1 of 3

## CHAIN OF CUSTODY RECORD

CUSTOMER INFORMATION			PROJECT INFORMATION			BILLING INFORMATION		
COMPANY:	ATP	PROJECT NAME/NUMBER:	Nucor Steel - PPF Baghouse			BILLING INFORMATION		
SEND REPORT TO:	Carlos Brown	BILL TO:						
ADDRESS:	1201 N. Graham Ave.	ADDRESS:	Same					
Indianapolis, Indiana 46219		PHONE:						
		FAX:						
		PHONE:						
		FAX:						
		PO NO.:	079					
SAMPLE NO.	SAMPLE DESCRIPTION	DATE COLLECTED	ANALYSIS METHOD	ANALYSIS VOLUME	CONTAINER	EPA Method 29		
Run 1	0.1N HNO3 Rinse (Container 5A)	05/21/04	AQ	1000 ml		1	X	
Run 2	0.1N HNO3 Rinse (Container 5A)	05/21/04	AQ	1000 ml		1	X	
Run 3	0.1N HNO3 Rinse (Container 5A)	05/21/04	AQ	1000 ml		1	X	
Run 1	KMNO4 (Container 5B)	05/21/04	AQ	1000 ml		1	X	
Run 2	KMNO4 (Container 5B)	05/21/04	AQ	1000 ml		1	X	
Run 3	KMNO4 (Container 5B)	05/21/04	AQ	1000 ml		1	X	
BLANK	0.1N HNO3 BLANK (8A)	05/21/04	AQ	1000 ml		2	X	
BLANK	H2O BLANK (8B)	05/21/04	AQ	1000 ml		2	X	
BLANK	HNO3/H2O2 BLANK (9)	05/21/04	AQ	1000 ml		1	X	
BLANK	KMNO4 BLANK (10)	05/21/04	AQ	1000 ml		1	X	
SAMPLER:	Carlos Brown	SHIPMENT METHOD:		AIRBILL NO.:				
REQUIRED TURNAROUND:								
SIGNATURE:	DATE:	SIGNATURE:	DATE:	SIGNATURE:	DATE:	SIGNATURE:	DATE:	SIGNATURE:
PRINTED NAME/COMPANY:	TIME:	PRINTED NAME/COMPANY:	TIME:	PRINTED NAME/COMPANY:	TIME:	PRINTED NAME/COMPANY:	TIME:	PRINTED NAME/COMPANY:
ATP	05/21/04	ATP	05/21/04	ATP	05/21/04	ATP	05/21/04	ATP
SIGNATURE:	DATE:	SIGNATURE:	DATE:	SIGNATURE:	DATE:	SIGNATURE:	DATE:	SIGNATURE:
PRINTED NAME/COMPANY:	TIME:	PRINTED NAME/COMPANY:	TIME:	PRINTED NAME/COMPANY:	TIME:	PRINTED NAME/COMPANY:	TIME:	PRINTED NAME/COMPANY:
ATP	05/21/04	ATP	05/21/04	ATP	05/21/04	ATP	05/21/04	ATP

\* Analyze for 16 Metals + Mercury

LAB JOB NO.

0 2261



**CALIBRATION CHECK**  
(Post Test) per EMTIC Guideline GD-26

Company: Nucor Steel  
 Date: May 19, 21, 2004  
 Source: PPF Baghouse - METALS  
 Location: Crawfordsville, Indiana

Run 1	Run 2	Run 3	Average
Y ga - 1.005	0.957	0.991	0.984
Average result must be within 5% of Y			
Result (%) 0.98			
<b>PASSED POST CAL</b>			
Dry Gas Meter Box:			
ID:	A-1		
Y:	0.99		
Delta H:	1.829		

Run 1	Volume	Delta H	DGM Inlet	DGM Outlet
1		0.060375	88	88
2		0.060375	87	88
3		0.060375	89	88
4		0.060375	86	88
5		0.060375	88	88
6		0.060375	89	88
7		0.060375	89	88
8		0.060375	89	88
9		0.060375	83	84
10		0.060375	82	83
11		0.060375	82	83
12		0.060375	82	82
13		0.060375	83	84
14		0.060375	82	82
15		0.060375	82	82
16		0.060375	82	82
17		0.060375	82	82
18		0.060375	82	82
19		0.060375	82	82
20		0.060375	82	82
21		0.060375	82	82
22		0.060375	82	82
23		0.060375	82	82
24		0.060375	82	82
25		0.060375	81	82
26		0.060375	82	82
27		0.060375	82	82
28		0.060375	82	82
29		0.060375	82	81
30		0.060375	82	81
31		0.060375	82	81
32		0.060375	82	81
33		0.060375	84	82
34		0.060375	83	82
35		0.060375	83	82
36		0.060375	83	82
37		0.060375	83	83
38		0.060375	83	83
39		0.060375	83	83
40		0.060375	83	83
41		0.060375	83	83
42		0.060375	85	84
43		0.060375	86	87
44		0.060375	88	88
45	917.17	0.060375	89	87
46	878.276	0.060375	88	88
47		0.060375	87	87
48		0.060375	87	87

Volume 38.884 Delta H 0.060  
 Barometric Pressure 30.08  
 Test Time 288.0  
 Y ga. 1.005  
 Meter Temp 83.93

Run 2	Volume	Delta H	DGM Inlet	DGM Outlet
1		0.06	80	81
2		0.06	81	81
3		0.06	81	81
4		0.06	82	81
5		0.06	82	81
6		0.06	83	82
7		0.06	83	82
8		0.06	83	83
9		0.06	85	84
10		0.06	87	85
11		0.06	89	86
12		0.06	89	86
13		0.06	90	86
14		0.06	90	88
15		0.06	90	89
16		0.06	91	90
17		0.06	91	90
18		0.06	91	90
19		0.06	92	91
20		0.06	92	91
21		0.06	93	91
22		0.06	93	92
23		0.06	93	92
24		0.06	93	92
25		0.06	93	92
26		0.06	94	93
27		0.06	94	93
28		0.06	94	93
29		0.06	94	94
30		0.06	95	94
31		0.06	96	95
32		0.06	97	96
33		0.06	98	97
34		0.06	98	97
35		0.06	98	98
36		0.06	98	98
37		0.06	99	98
38		0.06	100	99
39		0.06	100	99
40		0.06	100	100
41		0.06	101	101
42		0.06	101	101
43		0.06	102	102
44		0.06	102	102
45	958.47	0.06	102	102
46	917.32	0.06	102	102
47		0.06	102	102
48		0.06	103	102

Volume 41.16 Delta H 0.060  
 Barometric Pressure 30.08  
 Test Time 288.0  
 Y ga. 0.957  
 Meter Temp 92.81

Run 3	Volume	Delta H	DGM Inlet	DGM Outlet
1		0.06	102	102
2		0.06	102	102
3		0.06	102	102
4		0.06	102	102
5		0.06	102	102
6		0.06	102	102
7		0.06	102	102
8		0.06	102	102
9		0.06	102	102
10		0.06	102	102
11		0.06	103	103
12		0.06	103	103
13		0.06	103	103
14		0.06	103	103
15		0.06	104	103
16		0.06	104	103
17		0.06	104	103
18		0.06	104	103
19		0.06	104	103
20		0.06	104	103
21		0.06	105	105
22		0.06	105	105
23		0.06	105	105
24		0.06	105	105
25		0.06	105	105
26		0.06	105	105
27		0.06	105	105
28		0.06	105	105
29		0.06	105	105
30		0.06	104	104
31		0.06	104	104
32		0.06	103	103
33		0.06	103	103
34		0.06	103	102
35		0.06	102	102
36		0.06	102	102
37		0.06	102	102
38		0.06	102	102
39		0.06	102	102
40		0.06	102	102
41		0.06	102	102
42		0.06	102	102
43		0.06	102	102
44		0.06	102	102
45	988.88	0.06	102	102
46	958.73	0.06	102	102
47		0.06	102	102
48		0.06	102	102

Volume 40.128 Delta H 0.060  
 Barometric Pressure 30.08  
 Test Time 288.0  
 Y ga. 0.991  
 Meter Temp 102.98

**CALIBRATION CHECK**  
(Post Test) Per EIA/IC Guideline GP-26

Company: Nucor Steel  
 Date: May 19, 21, 2004  
 Source: PPF Baghouse - PM/PM10  
 Location: Crawfordsville, Indiana

Run 1 Run 2 Run 3 Average  
 Y ga - 0.982 0.973 0.987 0.974  
 Average result must be within 5% of Y  
 Result (%) 2.80  
**PASSED POST CAL**

Dry Gas Meter Box:  
 ID: A-1  
 Y: 1.002  
 Delta H: 1.72

Run 1	Volume	Delta H	DGM Inlet	DGM Outlet
1		0.986	82	92
2		0.986	83	92
3		0.986	94	92
4		0.986	94	92
5		0.986	95	92
6		0.986	94	93
7		0.986	95	93
8		0.986	91	91
9		0.986	86	85
10		0.986	85	86
11		0.986	88	85
12		0.986	86	85
13		0.986	85	85
14		0.986	86	85
15		0.986	87	85
16		0.986	87	85
17		0.986	87	85
18		0.986	87	84
19		0.986	86	84
20		0.986	86	84
21		0.986	86	84
22		0.986	86	84
23		0.986	86	84
24		0.986	86	84
25		0.986	85	84
26		0.986	86	84
27		0.986	86	84
28		0.986	86	84
29		0.986	86	84
30		0.986	86	84
31		0.986	85	84
32		0.986	86	84
33		0.986	87	84
34		0.986	88	84
35		0.986	88	85
36		0.986	89	85
37		0.986	88	85
38		0.986	89	86
39		0.986	89	86
40		0.986	89	86
41		0.986	89	86
42		0.986	92	87
43		0.986	94	89
44		0.986	95	91
45	557.558	0.986	95	91
46	393.07	0.986	94	91
47		0.986	94	91
48		0.986	94	91

Volume 184.488 Delta H 0.986 Meter Temp 87.82  
 Barometric Pressure 30.08 Test Time 288.0  
 Y ga 0.982

Run 2	Volume	Delta H	DGM Inlet	DGM Outlet
1		0.97	82	81
2		0.97	83	81
3		0.97	84	82
4		0.97	85	83
5		0.97	85	83
6		0.97	85	83
7		0.97	80	85
8		0.97	90	86
9		0.97	90	86
10		0.97	90	88
11		0.97	90	88
12		0.97	90	89
13		0.97	91	89
14		0.97	93	91
15		0.97	95	91
16		0.97	96	92
17		0.97	96	92
18		0.97	96	92
19		0.97	96	93
20		0.97	96	93
21		0.97	97	93
22		0.97	97	94
23		0.97	97	94
24		0.97	97	94
25		0.97	98	94
26		0.97	98	94
27		0.97	98	95
28		0.97	99	95
29		0.97	99	95
30		0.97	100	96
31		0.97	101	96
32		0.97	101	97
33		0.97	102	98
34		0.97	102	99
35		0.97	102	99
36		0.97	103	99
37		0.97	103	100
38		0.97	103	100
39		0.97	103	100
40		0.97	103	100
41		0.97	103	100
42		0.97	104	101
43		0.97	104	101
44		0.97	104	101
45	724.95	0.97	104	101
46	557.78	0.97	105	101
47		0.97	105	102
48		0.97	105	102

Volume 167.17 Delta H 0.986 Meter Temp 98.06  
 Barometric Pressure 30.08 Test Time 288.0  
 Y ga 0.973

Run 3	Volume	Delta H	DGM Inlet	DGM Outlet
1		0.98	102	101
2		0.98	102	101
3		0.98	103	102
4		0.98	103	102
5		0.98	104	102
6		0.98	105	102
7		0.98	105	103
8		0.98	106	103
9		0.98	106	103
10		0.98	106	103
11		0.98	106	103
12		0.98	106	103
13		0.98	106	103
14		0.98	106	103
15		0.98	107	104
16		0.98	107	104
17		0.98	108	105
18		0.98	108	105
19		0.98	108	105
20		0.98	108	105
21		0.98	110	106
22		0.98	110	107
23		0.98	110	108
24		0.98	111	108
25		0.98	110	107
26		0.98	110	108
27		0.98	110	108
28		0.98	110	108
29		0.98	109	107
30		0.98	109	107
31		0.98	108	106
32		0.98	108	106
33		0.98	108	106
34		0.98	108	105
35		0.98	108	105
36		0.98	107	105
37		0.98	107	105
38		0.98	106	104
39		0.98	106	104
40		0.98	106	104
41		0.98	106	104
42		0.98	106	104
43		0.98	106	104
44		0.98	106	104
45	893.90	0.98	106	104
46	723.16	0.98	106	103
47		0.98	106	103
48		0.98	106	103

Volume 170.749 Delta H 0.977 Meter Temp 105.88  
 Barometric Pressure 30.08 Test Time 288.0  
 Y ga 0.987



**Meter Box Post-Test Calibration**

APEX INSTRUMENTS  
 EPA Method 5  
 522 Series Meter Box Calibration  
 Post-Test Orifice Method  
 English Meter Box Units, English K' Factor  
 Filename: Orifice Calibration

Box ID#: **A-1**  
 Date: 01/20/04  
 Barometric Pressure: 29.98 in Hg  
 Critical Orifice Vacuum: 20 in Hg

**IMPORTANT!!!**  
 For valid test results, the Critical Orifice Vacuum must be equal to or higher than the value shown above.  
 The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>/(deg R)<sup>0.5</sup>/(in.Hg)<sup>3</sup>(min).

..... DRY GAS METER READINGS ..... CRITICAL ORIFICE READINGS

dH (in H2O)	Time (min)	Volume		Volume		Volume		Initial Temps.		Final Temps.		Orifice K' Orifice Serial# Coefficient (see above)	Vacuum (in Hg)	Ambient Temperature ..	
		Initial (cu ft)	Final (cu ft)	Initial (cu ft)	Final (cu ft)	Total (cu ft)	Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)	Initial (deg F)			Final Average (deg F)	
0.38	14.08	216	221	5.00	95	93	96	94	AT-15	0.265	20	88	88		
0.38	14.08	221	226	5.00	96	94	97	95	AT-15	0.265	20	88	88		
0.38	14.08	226	231	5.00	97	95	98	95	AT-15	0.265	20	88	88		

\*\*\*\*\* RESULTS \*\*\*\*\*

... DRY GAS METER ...		..... ORIFICE .....		... DRY GAS METER ..		..... ORIFICE .....	
VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	CALIBRATION FACTOR Y	Variation (number)	CALIBRATION FACTOR dH@	Variation (in H2O)
4.7731297	135.175	4.77848116	135.32659	1.00112	-0.0017	1.7248317	43.81073
4.7645372	134.9317	4.77848116	135.32659	1.00293	0.00015	1.7155279	43.57441
4.7581131	134.7498	4.77848116	135.32659	1.00428	0.0015	1.7093635	43.41783
Average Y .....				<b>1.00278</b>		<b>1.717</b>	43.60099

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.02.

For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/-0.2.

Calibrated by: Carlos Brown Date: January 20, 2004

**Meter Box Post-Test Calibration**

APEX INSTRUMENTS  
 EPA Method 5  
 522 Series Meter Box Calibration  
 Post-Test Orifice Method  
 English Meter Box Units, English K' Factor  
 Filename: Orifice Calibration

Box ID#: **A-2**  
 Date: 02/02/04  
 Barometric Pressure: 29.95 in Hg  
 Critical Orifice Vacuum: 20 in Hg

**IMPORTANT!!!**  
 For valid test results, the Critical Orifice Vacuum must be equal to or higher than the value shown above.  
 The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>/(deg R)<sup>0.5</sup>/(in.Hg)<sup>3</sup>(min)).

..... DRY GAS METER READINGS ..... CRITICAL ORIFICE READINGS

dh (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice K' Orifice Serial# Coefficient (see above)	Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)			Initial (deg F)	Final (deg F)	Average (deg F)
0.39	14.30	216	221	5.00	72	70	72	70	AT-15	0.265	20	71	71
0.39	14.30	221	226	5.00	72	70	73	71	AT-15	0.265	20	71	71
0.39	14.29	226	231	5.00	73	71	74	72	AT-15	0.265	20	71	71

\*\*\*\*\* RESULTS \*\*\*\*\*

... DRY GAS METER ...				..... ORIFICE .....				... DRY GAS METER ...				..... ORIFICE .....			
VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	Value (number)	Variation (number)	Value (in H2O)	Variation (mm H2O)	Value (in H2O)	Variation (mm H2O)	Value (in H2O)	Variation (mm H2O)	Value (in H2O)	Variation (mm H2O)	Average dh@	Average dh@
4.979509	141.0197	4.92528627	139.48411	0.98911	-0.001	1.836041	46.63544	1.836041	46.63544	1.8308609	46.50387	1.8205591	46.2422	1.829	46.4605
4.9748246	140.887	4.92528627	139.48411	0.99004	-8E-05	1.8308609	46.50387	1.8308609	46.50387	1.8205591	46.2422	1.8205591	46.2422		
4.9654822	140.6225	4.92184201	139.38657	0.99121	0.00109	1.8205591	46.2422	1.8205591	46.2422	1.8205591	46.2422	1.8205591	46.2422		
Average Y .....				0.99012		1.829	46.4605	1.829	46.4605	1.829	46.4605	1.829	46.4605		

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.

For Orifice Calibration Factor dh@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.

Calibrated by: Carlos Brown Date: February 2, 2004

**ATP – Air Test Professionals, Inc.**  
**Pitot Tube Calibration**

Reference: 40 CFR 60, Appendix A, Method 2, Section 2.1

Probe Length/ID.: 12 ft. (w/2ft ext.) Type-S

External Tubing Diameter: 0.375" inches

Base to Opening Plane Distance (Pa): 0.470" inches

Base to Opening Plane Distance (Pa): 0.470" inches

	Measured	Allowable
<b>Pa/Dt</b>	1.25"	1.05 – 1.50 inches
<b>Pb/Dt</b>	1.25"	1.05 – 1.50 inches
<b>Angle <math>\alpha</math> 1</b>	0 deg	$\alpha 1$ and $\alpha 2 \leq 10.0$
<b>Angle <math>\alpha</math> 2</b>	0 deg	$\alpha 1$ and $\alpha 2 \leq 10.0$
<b>Angle <math>\beta</math> 1</b>	0 deg	$\beta 1$ and $\beta 2 \leq 10.0$
<b>Angle <math>\beta</math> 2</b>	0 deg	$\beta 1$ and $\beta 2 \leq 10.0$
<b>z (inches)</b>	0.0"	0.125 inches
<b>w (inches)</b>	0.0"	0.031 inches
	If all criteria are met, Pitot Coefficient is 0.84	Pitot Coefficient: <b>0.84</b>

Calibrated By: Carlos Brown Date Calibrated: February 16, 2004

**ATP – Air Test Professionals, Inc.**  
**Thermocouple Calibration**

Probe Length/ID: 12 ft. Type-S Dry Gas Meter ID: A-1

Standard Used: Mercury Thermometer Temperature Scale: Degrees F

Temperature Range	Mercury Thermometer	Probe Thermometer
Hot Bath	425 deg	425 deg
Room Temperature	72 deg	72 deg
Ice Bath	30 deg	30 deg

Calibrated By: Carlos Brown Date Calibrated: February 16, 2004


**ATP - Air Test Professionals, Inc.**  
**Thermocouple Calibration**

Probe Length/ID: 10 in. Hand-held Dry Gas Meter ID: Extech Pyrometer

Standard Used: Mercury Thermometer Temperature Scale: Degrees F

Temperature Range	Mercury Thermometer	Probe Thermometer
Hot Bath	425 deg	425 deg
Room Temperature	72 deg	72 deg
Ice Bath	30 deg	30 deg

Calibrated By: Carlos Brown Date Calibrated: February 16, 2004



---

**CARL KOONTZ ASSOCIATES**

of Nashville, Tennessee

This is to acknowledge that

ANDREW YOUNG

successfully participated in Visible Emissions  
training on MAR 22 2004

and is qualified to evaluate Visible Emissions  
for a period of six (6) months from the date of  
certification.

Carl Koontz  
Instructor

**CARL KOONTZ ASSOCIATES**

of Nashville, Tennessee

This is to acknowledge that

**CARLOS BROWN**

successfully participated in Visible Emissions  
training on **MAR 22 2004**

and is qualified to evaluate Visible Emissions  
for a period of six (6) months from the date of  
certification.

*Carl Koontz*

Instructor



**CARL KOONTZ ASSOCIATES**

of Nashville, Tennessee

This is to acknowledge that

REX KELSEY

successfully participated in Visible Emissions

training on MAR 18 2004

and is qualified to evaluate Visible Emissions  
for a period of six (6) months from the date of  
certification.

*Carl Koontz*  
Instructor

Visible Emissions Observations Form

RUN NUMBER

1

SOURCE NAME *Nucor Steel*

OBSERVATION DATE *5/19/04*

START TIME *0411*

*MELT SHOP - 11*  
*ROOF VENT*  
*5%*

ADDRESS

sec					
min	0	15	30	45	ser

CITY

STATE

ZIP

1	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
2	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>

PHONE

SOURCE ID NUMBER

3	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
4	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>

PROCESS EQUIPMENT  
*Melt Shop*

OPERATING MODE

5	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	34
6	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	35

CONTROL EQUIPMENT

OPERATING MODE

7	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	36
8	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	37

DESCRIBE EMISSION POINT (Stack Exit Dimensions)  
*Roof Vent*

9	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	38
10	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	39

HEIGHT ABOVE GROUND LEVEL  
START *~100'* STOP *~100'*

HEIGHT RELATIVE TO OBSERVER  
START *~100'* STOP *~100'*

11	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	40
12	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	41

DISTANCE FROM OBSERVER  
START *~400'* STOP *~400'*

DIRECTION FROM OBSERVER  
START *NNE* STOP *NNE*

13	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	42
14	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	43

DESCRIBE EMISSIONS  
START *none* STOP *none*

15	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	44
16	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	45

EMISSION COLOR  
START *-* STOP *-*

PLUME TYPE: CONTINUOUS  
START *FUGITIVE* STOP *INTERMITTENT*

17	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	46
18	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	47

WATER DROPLETS PRESENT  
 NO YES

IF WATER DROPLET PLUME:  
ATTACHED DETACHED

19	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	48
20	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	49

POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED  
START *Roof Vent exit* STOP *Roof vent exit*

21	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	50
22	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	51

DESCRIBE BACKGROUND  
START *Grey Cloudy Sky* STOP *Dark Grey Sky*

23	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	52
24	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	53

BACKGROUND COLOR  
START *Grey* STOP *Dark Grey*

SKY CONDITIONS  
START *Cloudy* STOP *cloudy*

25	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	54
26	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	55

WIND SPEED (MPH)  
START *5* STOP *5*


WIND DIRECTION  
START *SW* STOP *SW*

27	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	56
28	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	57

AMBIENT TEMPERATURE (F)  
START *80* STOP *75*

WET BULB TEMP RH PERCENT

29	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	58
30	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	59



AVERAGE OPACITY FOR HIGHEST PERIOD *0* NUMBER OF READINGS ABOVE WERE *0*

RANGE OF OPACITY READINGS  
MINIMUM *0* MAXIMUM *0*

OBSERVER'S NAME (PRINT)  
*Andrew Young*

OBSERVER'S SIGNATURE *Andrew Young* DATE *5/19/04*


ORGANIZATION  
*ATP - Air Test Professionals, Inc.*

CERTIFIED BY *Carl Koeltz* DATE

Comments:

- X = Emission Point
- = Observer's Position
- ☀ = Sun
- ↗ = Wind
- = Plume

SOURCE NAME <i>Nucor Steel</i>			OBSERVATION DATE <i>5/19/04</i>				START TIME <i>0541</i>		STOP TIME <i>0641</i>			
ADDRESS			sec				sec					
			min	0	15	30	45	min	0	15	30	45
CITY	STATE	ZIP	1	0	15	30	45	31	0	15	30	45
PHONE			2	0	15	30	45	32	0	15	30	45
SOURCE ID NUMBER			3	0	15	30	45	33	0	15	30	45
PROCESS EQUIPMENT <i>Melt Shop</i>			4	0	15	30	45	34	0	15	30	45
OPERATING MODE			5	0	15	30	45	35	0	15	30	45
CONTROL EQUIPMENT			6	0	15	30	45	36	0	15	30	45
OPERATING MODE			7	0	15	30	45	37	0	15	30	45
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <i>Roof Vent</i>			8	0	15	30	45	38	0	15	30	45
HEIGHT ABOVE GROUND LEVEL START <i>1100'</i> STOP <i>1100'</i>			9	0	15	30	45	39	0	15	30	45
HEIGHT RELATIVE TO OBSERVER START <i>1100'</i> STOP <i>1100'</i>			10	0	15	30	45	40	0	15	30	45
DISTANCE FROM OBSERVER START <i>400'</i> STOP <i>400'</i>			11	0	15	30	45	41	0	15	30	45
DIRECTION FROM OBSERVER START <i>NNE</i> STOP <i>NNE</i>			12	0	15	30	45	42	0	15	30	45
DESCRIBE EMISSIONS START <i>none</i> STOP <i>none</i>			13	0	15	30	45	43	0	15	30	45
EMISSION COLOR START <i>—</i> STOP <i>—</i>			14	0	15	30	45	44	0	15	30	45
PLUME TYPE: CONTINUOUS <input checked="" type="checkbox"/> FUGITIVE <input type="checkbox"/> INTERMITTENT			15	0	15	30	45	45	0	15	30	45
WATER DROPLETS PRESENT <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES			16	0	15	30	45	46	0	15	30	45
IF WATER DROPLET PLUME: ATTACHED <input type="checkbox"/> DETACHED <input type="checkbox"/>			17	0	15	30	45	47	0	15	30	45
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <i>Roof Vent Exit</i> STOP <i>Roof vent exit</i>			18	0	15	30	45	48	0	15	30	45
DESCRIBE BACKGROUND START <i>Blue-white Sky</i> STOP <i>Light blue Sky</i>			19	0	15	30	45	49	0	15	30	45
BACKGROUND COLOR <i>light</i> START <i>blue/white</i> STOP <i>blue</i>			20	0	15	30	45	50	0	15	30	45
SKY CONDITIONS <i>Mostly</i> START <i>Cloudy</i> STOP <i>cloudy</i>			21	0	15	30	45	51	0	15	30	45
WIND SPEED (MPH) START <i>5</i> STOP <i>5</i>			22	0	15	30	45	52	0	15	30	45
WIND DIRECTION START <i>SW</i> STOP <i>S</i>			23	0	15	30	45	53	0	15	30	45
AMBIENT TEMPERATURE (F) START <i>70</i> STOP <i>70</i>			24	0	15	30	45	54	0	15	30	45
WET BULB TEMP			25	0	15	30	45	55	0	15	30	45
RH. PERCENT			26	0	15	30	45	56	0	15	30	45
SOURCE LAYOUT SKETCH			27	0	15	30	45	57	0	15	30	45
Draw North Arrow			28	0	15	30	45	58	0	15	30	45
AVERAGE OPACITY FOR HIGHEST PERIOD			29	0	15	30	45	59	0	15	30	45
NUMBER OF READINGS ABOVE WERE			30	0	15	30	45	60	0	15	30	45



AVERAGE OPACITY FOR HIGHEST PERIOD

NUMBER OF READINGS ABOVE WERE

RANGE OF OPACITY READINGS  
MINIMUM *0* MAXIMUM *0*

OBSERVER'S NAME (PRINT)  
*Andrew Yering*

OBSERVER'S SIGNATURE  
*Andrew Yering* DATE *5/19/04*

ORGANIZATION  
*ATP - Air Test Professionals, Inc.*

CERTIFIED BY  
*Carl Keontz* DATE

Comments:


- X = Emission Point
- = Observer's Position
- ☀ = Sun
- = Wind
- = Plume

Visible Emissions Observations Form

RUN NUMBER

3

SOURCE NAME <i>Nucar Steel</i>			OBSERVATION DATE <i>5/19/04</i>			START TIME <i>0641</i>			STOP TIME <i>0741</i>			
ADDRESS			sec				sec					
			min	0	15	30	45	min	0	15	30	45
CITY	STATE	ZIP	1	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	31	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
PHONE	SOURCE ID NUMBER		2	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	32	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
PROCESS EQUIPMENT <i>Melt Shop</i>		OPERATING MODE	3	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	33	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
CONTROL EQUIPMENT		OPERATING MODE	4	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	34	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <i>Roof Vent</i>			5	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	35	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
HEIGHT ABOVE GROUND LEVEL START <i>100'</i> STOP <i>100'</i>		HEIGHT RELATIVE TO OBSERVER START <i>100'</i> STOP <i>100'</i>		6	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	36	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
DISTANCE FROM OBSERVER START <i>400'</i> STOP <i>400'</i>		DIRECTION FROM OBSERVER START <i>NNE</i> STOP <i>NNE</i>		7	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	37	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
DESCRIBE EMISSIONS START <i>none</i> STOP <i>none</i>			8	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	38	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
EMISSION COLOR START <i>—</i> STOP <i>—</i>		PLUME TYPE: CONTINUOUS <input checked="" type="checkbox"/> POSITIVE <input type="checkbox"/> INTERMITTENT		9	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	39	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
WATER DROPLETS PRESENT <input checked="" type="radio"/> YES <input type="radio"/> NO		IF WATER DROPLET PLUME: <input type="checkbox"/> ATTACHED <input type="checkbox"/> DETACHED		10	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	40	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <i>Roof vent exit</i> STOP <i>Roof Vent Exit</i>			11	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	41	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
DESCRIBE BACKGROUND START <i>H. blue sky</i> STOP <i>Lt. blue sky</i>			12	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	42	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
BACKGROUND COLOR START <i>H. blue</i> STOP <i>Lt. blue</i>		SKY CONDITIONS START <i>cloudy</i> STOP <i>cloudy</i> <i>Partly</i>		13	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	43	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
WIND SPEED (MPH) START <i>5</i> STOP <i>0-5</i>		WIND DIRECTION START <i>SE</i> STOP <i>SE</i>		14	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	44	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
AMBIENT TEMPERATURE (F) START <i>70</i> STOP <i>70</i>		WET BULB TEMP. <input type="checkbox"/> REL. HUMIDITY <input type="checkbox"/>		15	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	45	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
SOURCE LAYOUT SKETCH			16	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	46	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	



AVERAGE OPACITY FOR HIGHEST PERIOD		NUMBER OF READINGS ABOVE WERE	
RANGE OF OPACITY READINGS MINIMUM <i>0</i> MAXIMUM <i>0</i>			
OBSERVER'S NAME (PRINT) <i>Andrew Young</i>			
OBSERVER'S SIGNATURE <i>Andrew Young</i>		DATE <i>5/19/04</i>	
ORGANIZATION <i>ATP - Air Test Professionals, Inc.</i>			
CERTIFIED BY <i>Carl Koontz</i>		DATE	
Comments:			


X = Emission Point      → = Wind  
 v = Observer's Position      = Plume  
 ☀ = Sun

Visible Emissions Observations Form

RUN NUMBER

1A

SOURCE NAME <i>Nucor Steel</i>			OBSERVATION DATE <i>5/19/04</i>				START TIME <i>04:11</i>		STOP TIME <i>05:11</i>	
ADDRESS			sec				sec			
			min	0	15	30	45	min	0	
CITY			STATE	ZIP	1	2	3	4	5	
PHONE			SOURCE ID NUMBER		31	32	33	34	35	
PROCESS EQUIPMENT <i>EAF Furnaces + AOD</i>			OPERATING MODE		36	37	38	39	40	
CONTROL EQUIPMENT <i>Baghouse - East</i>			OPERATING MODE <i>Normal</i>		41	42	43	44	45	
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <i>Roof Vent</i>					46	47	48	49	50	
HEIGHT ABOVE GROUND LEVEL START <i>~75'</i> STOP <i>~75'</i>		HEIGHT RELATIVE TO OBSERVER START <i>~75'</i> STOP <i>~75'</i>				51	52	53	54	
DISTANCE FROM OBSERVER START <i>~500'</i> STOP <i>~500'</i>		DIRECTION FROM OBSERVER START <i>N</i> STOP <i>N</i>				55	56	57	58	
DESCRIBE EMISSIONS START <i>none</i> STOP <i>none</i>					59	60	61	62	63	
EMISSION COLOR START <i>—</i> STOP <i>—</i>		PLUME TYPE: CONTINUOUS <i>FUGITIVE</i> INTERMITTENT				64	65	66	67	
WATER DROPLETS PRESENT <i>NO</i> YES		IF WATER DROPLET PLUME: ATTACHED DETACHED				68	69	70	71	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <i>Roof vent exit</i> STOP <i>Roof vent exit</i>					72	73	74	75	76	
DESCRIBE BACKGROUND START <i>Grey Cloudy Sky</i> STOP <i>Dark Grey Sky</i>					77	78	79	80	81	
BACKGROUND COLOR START <i>Grey</i> STOP <i>Dark Grey</i>		SKY CONDITIONS START <i>Cloudy</i> STOP <i>Dark + Cloudy</i>				82	83	84	85	
WIND SPEED (MPH) START <i>5</i> STOP <i>5</i>		WIND DIRECTION START <i>SW</i> STOP <i>SW</i>				86	87	88	89	
AMBIENT TEMPERATURE (F) START <i>80</i> STOP <i>75</i>		WET BULB TEMP. %RH PERCENT				90	91	92	93	




AVERAGE OPACITY FOR HIGHEST PERIOD	NUMBER OF READINGS ABOVE WERE
RANGE OF OPACITY READINGS MINIMUM <i>0</i> MAXIMUM <i>0</i>	
OBSERVER'S NAME (PRINT) <i>Andrew Young</i>	
OBSERVER'S SIGNATURE <i>Andrew Young</i>	DATE <i>5/19/04</i>
ORGANIZATION <b>ATP - Air Test Professionals, Inc.</b>	
CERTIFIED BY <i>Carl Koontz</i>	DATE
Comments:	

- X = Emission Point
- = Observer's Position
- ☀ = Sun
- = Wind
- = Plume

Visible Emissions Observations Form

RUN NUMBER 1A

SOURCE NAME <b>NUCOR STEEL</b>			OBSERVATION DATE <b>5/19/04</b>			START TIME <b>0411</b>		STOP TIME <b>0511</b>				
ADDRESS			sec				sec					
			min	0	15	30	45	min	0	15	30	45
CITY	STATE	ZIP	1	0	0	0	0	31	0	0	0	0
			2	0	0	0	0	32	0	0	0	0
PHONE			SOURCE ID NUMBER			3	0	0	0	0	0	0
						4	0	0	0	0	0	0
PROCESS EQUIPMENT <b>EAF Furnaces + AOD</b>		OPERATING MODE		5	0	0	0	0	35	0	0	0
				6	0	0	0	0	36	0	0	0
CONTROL EQUIPMENT <b>Baghouse - West</b>		OPERATING MODE <b>Normal</b>		7	0	0	0	0	37	0	0	0
				8	0	0	0	0	38	0	0	0
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>Roof Monitor/Vent</b>			9	0	0	0	0	0	39	0	0	0
			10	0	0	0	0	0	40	0	0	0
HEIGHT ABOVE GROUND LEVEL START <b>~75'</b> STOP <b>~75'</b>		HEIGHT RELATIVE TO OBSERVER START <b>~75'</b> STOP <b>~75'</b>		11	0	0	0	0	41	0	0	0
				12	0	0	0	0	42	0	0	0
DISTANCE FROM OBSERVER START <b>~500'</b> STOP <b>~500'</b>		DIRECTION FROM OBSERVER START <b>N</b> STOP <b>N</b>		13	0	0	0	0	43	0	0	0
				14	0	0	0	0	44	0	0	0
DESCRIBE EMISSIONS START <b>none</b> STOP <b>none</b>			15	0	0	0	0	0	45	0	0	0
			16	0	0	0	0	0	46	0	0	0
EMISSION COLOR START <b>-</b> STOP <b>-</b>		PLUME TYPE: CONTINUOUS		17	0	0	0	0	47	0	0	0
		<del>PUGITIVE</del> INTERMITTENT		18	0	0	0	0	48	0	0	0
WATER DROPLETS PRESENT <b>NO</b> YES		IF WATER DROPLET PLUME: ATTACHED DETACHED		19	0	0	0	0	49	0	0	0
				20	0	0	0	0	50	0	0	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <b>Roof vent exit</b> STOP <b>Roof Vent Exit</b>			21	0	0	0	0	0	51	0	0	0
			22	0	0	0	0	0	52	0	0	0
DESCRIBE BACKGROUND START <b>Grey Cloudy sky</b> STOP <b>Dark Grey sky</b>			23	0	0	0	0	0	53	0	0	0
			24	0	0	0	0	0	54	0	0	0
BACKGROUND COLOR START <b>Grey</b> STOP <b>Dark Grey</b>		SKY CONDITIONS START <b>Cloudy</b> STOP <b>Dark &amp; Cloudy</b>		25	0	0	0	0	55	0	0	0
				26	0	0	0	0	56	0	0	0
WIND SPEED (MPH) START <b>5</b> STOP <b>5</b>		WIND DIRECTION START <b>SW</b> STOP <b>SW</b>		27	0	0	0	0	57	0	0	0
				28	0	0	0	0	58	0	0	0
AMBIENT TEMPERATURE (F) START <b>80</b> STOP <b>75</b>		WET BULB TEMP. / RH. PERCENT		29	0	0	0	0	59	0	0	0
				30	0	0	0	0	60	0	0	0



AVERAGE OPACITY FOR HIGHEST PERIOD

NUMBER OF READINGS ABOVE WERE

RANGE OF OPACITY READINGS  
MINIMUM **0** MAXIMUM **0**

OBSERVER'S NAME (PRINT)  
**Andrew Young**

OBSERVER'S SIGNATURE  
*Andrew Young* DATE **5/19/04**

ORGANIZATION  
**ATP - Air Test Professionals, Inc.**

CERTIFIED BY  
**Carl Kowitz** DATE

Comments:

- X = Emission Point
- = Observer's Position
- ☀ = Sun
- ≡ = Wind
- = Plume

Visible Emissions Observations Form

RUN NUMBER

13

SOURCE NAME *Nucor Steel*

OBSERVATION DATE *5/19/04*

START TIME *0541*

STOP TIME *0641*

ADDRESS

sec										
min	0	15	30	45	min	0	15	30	45	

CITY

STATE

ZIP

1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	31	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	32	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

PHONE

SOURCE ID NUMBER

3	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	33	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	34	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

PROCESS EQUIPMENT  
*EAF Furnaces + AOD*

OPERATING MODE

5	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	35	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	36	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

CONTROL EQUIPMENT  
*Baghouse - EAST*

OPERATING MODE  
*Normal*

7	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	37	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	38	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

DESCRIBE EMISSION POINT (Stack Exit Dimensions)  
*Roof vent*

9	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	39	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	40	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

HEIGHT ABOVE GROUND LEVEL  
START *~75'* STOP *~75'*

HEIGHT RELATIVE TO OBSERVER  
START *~75'* STOP *~75'*

11	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	41	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	42	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

DISTANCE FROM OBSERVER  
START *~900'* STOP *~900'*

DIRECTION FROM OBSERVER  
START *N* STOP *N*

13	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	43	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	44	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

DESCRIBE EMISSIONS  
START *none* STOP *none*

15	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	45	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	46	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

EMISSION COLOR  
START *-* STOP *-*

PLUME TYPE: CONTINUOUS  
FUGITIVE INTERMITTENT

17	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	47	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
18	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	48	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

WATER DROPLETS PRESENT  
 NO YES

IF WATER DROPLET PLUME:  
ATTACHED DETACHED

19	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	49	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
20	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	50	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED  
START *Roof vent exit* STOP *Roof Vent Exit*

21	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	51	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
22	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	52	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

DESCRIBE BACKGROUND  
START *blue/white sky* STOP *lt. blue sky*

23	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	53	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
24	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	54	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

BACKGROUND COLOR  
START *blue/white* STOP *lt. blue*

SKY CONDITIONS  
START *cloudy* STOP *cloudy*

25	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	55	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
26	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	56	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

WIND SPEED (MPH)  
START *5* STOP *5*


WIND DIRECTION  
START *SW* STOP *S*

27	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	57	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
28	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	58	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

AMBIENT TEMPERATURE (F)  
START *70* STOP *70*

WET BULB TEMP REL PERCENT

29	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	59	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
30	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	60	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>



AVERAGE OPACITY FOR HIGHEST PERIOD

NUMBER OF READINGS ABOVE WERE

RANGE OF OPACITY READINGS  
MINIMUM *0* MAXIMUM *0*

OBSERVER'S NAME (PRINT)  
*Andrew Young*

OBSERVER'S SIGNATURE  
*Andrew Young*

DATE  
*5/19/04*

ORGANIZATION  
*ATP - Air Test Professionals, Inc.*

CERTIFIED BY  
*Carl Koantz*

DATE

Comments:


X = Emission Point → = Wind  
o = Observer's Position = Plume  
☉ = Sun

Visible Emissions Observations Form

RUN NUMBER

18

SOURCE NAME <i>Nucor Steel</i>			OBSERVATION DATE <i>5/19/04</i>				START TIME <i>5:41</i>		STOP TIME <i>6:41</i>			
ADDRESS			sec				sec					
			min	0	15	30	45	min	0	15	30	45
CITY	STATE	ZIP	1	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	31	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
PHONE		SOURCE ID NUMBER	2	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	32	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
PROCESS EQUIPMENT <i>EAF Furnaces &amp; AOD</i>		OPERATING MODE	3	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	33	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
CONTROL EQUIPMENT <i>Baghouse - West</i>		OPERATING MODE <i>Normal</i>	4	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	34	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <i>Roof Vent</i>			5	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	35	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
HEIGHT ABOVE GROUND LEVEL START <i>~75'</i> STOP <i>~75'</i>		HEIGHT RELATIVE TO OBSERVER START <i>~75'</i> STOP <i>~75'</i>	6	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	36	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
DISTANCE FROM OBSERVER START <i>~500'</i> STOP <i>~500'</i>		DIRECTION FROM OBSERVER START <i>N</i> STOP <i>N</i>	7	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	37	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
DESCRIBE EMISSIONS START <i>none</i> STOP <i>-</i>			8	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	38	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
EMISSION COLOR START <i>-</i> STOP <i>-</i>		PLUME TYPE: CONTINUOUS FUGITIVE INTERMITTENT	9	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	39	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
WATER DROPLETS PRESENT <input checked="" type="radio"/> NO YES		IF WATER DROPLET PLUME: ATTACHED DETACHED	10	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	40	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <i>Roof vent exit</i> STOP <i>Roof vent Exit</i>			11	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	41	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
DESCRIBE BACKGROUND START <i>Blue/white Sky</i> STOP <i>Light blue Sky</i>			12	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	42	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
BACKGROUND COLOR START <i>blue/white</i> STOP <i>lt. blue</i>		SKY CONDITIONS START <i>Cloudy</i> STOP <i>cloudy</i>	13	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	43	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
WIND SPEED (MPH) START <i>5</i> STOP <i>5</i>		WIND DIRECTION START <i>SW</i> STOP <i>S</i>	14	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	44	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
AMBIENT TEMPERATURE (F) START <i>70</i> STOP <i>70</i>		WET BULB TEMP. REL. HUMIDITY	15	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	45	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
SOURCE LAYOUT SKETCH			16	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	46	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>



AVERAGE OPACITY FOR HIGHEST PERIOD

NUMBER OF READINGS ABOVE WERE

RANGE OF OPACITY READINGS  
MINIMUM  MAXIMUM

OBSERVER'S NAME (PRINT)  
*Andrew Young*

OBSERVER'S SIGNATURE  
*Andrew Young*

DATE  
*5/19/04*

ORGANIZATION  
*ATP - Air Test Professionals, Inc.*

CERTIFIED BY  
*Carl Kooitz*

DATE

Comments:


- X = Emission Point
- ☀ = Sun
- = Wind
- = Plume
- = Observer's Position



Visible Emissions Observations Form

RUN NUMBER 1C

SOURCE NAME			OBSERVATION DATE				START TIME				STOP TIME						
Near Steel			5/19/04				06:41				09:41						
ADDRESS			sec				sec				sec						
			min	0	15	30	45	min	0	15	30	45	min	0	15	30	45
CITY	STATE	ZIP	1	0	0	0	0	31	0	0	0	0	0	0	0	0	0
			2	0	0	0	0	32	0	0	0	0	0	0	0	0	0
PHONE	SOURCE ID NUMBER		3	0	0	0	0	33	0	0	0	0	0	0	0	0	0
			4	0	0	0	0	34	0	0	0	0	0	0	0	0	0
PROCESS EQUIPMENT	OPERATING MODE		5	0	0	0	0	35	0	0	0	0	0	0	0	0	0
EAF Furnaces & AOD			6	0	0	0	0	36	0	0	0	0	0	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE		7	0	0	0	0	37	0	0	0	0	0	0	0	0	0
Baghouse - EAST	Normal		8	0	0	0	0	38	0	0	0	0	0	0	0	0	0
DESCRIBE EMISSION POINT (Stack Exit Dimensions)			9	0	0	0	0	39	0	0	0	0	0	0	0	0	0
Roof Vent			10	0	0	0	0	40	0	0	0	0	0	0	0	0	0
HEIGHT ABOVE GROUND LEVEL	HEIGHT RELATIVE TO OBSERVER		11	0	0	0	0	41	0	0	0	0	0	0	0	0	0
START 75' STOP 75'	START 75' STOP 75'		12	0	0	0	0	42	0	0	0	0	0	0	0	0	0
DISTANCE FROM OBSERVER	DIRECTION FROM OBSERVER		13	0	0	0	0	43	0	0	0	0	0	0	0	0	0
START 400' STOP 400'	START N STOP N		14	0	0	0	0	44	0	0	0	0	0	0	0	0	0
DESCRIBE EMISSIONS			15	0	0	0	0	45	0	0	0	0	0	0	0	0	0
START none STOP none			16	0	0	0	0	46	0	0	0	0	0	0	0	0	0
EMISSION COLOR	PLUME TYPE: CONTINUOUS		17	0	0	0	0	47	0	0	0	0	0	0	0	0	0
START - STOP -	FUGITIVE INTERMITTENT		18	0	0	0	0	48	0	0	0	0	0	0	0	0	0
WATER DROPLETS PRESENT	IF WATER DROPLET PLUME:		19	0	0	0	0	49	0	0	0	0	0	0	0	0	0
(NO) YES	ATTACHED DETACHED		20	0	0	0	0	50	0	0	0	0	0	0	0	0	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED			21	0	0	0	0	51	0	0	0	0	0	0	0	0	0
START Roof vent exit STOP Roof vent exit			22	0	0	0	0	52	0	0	0	0	0	0	0	0	0
DESCRIBE BACKGROUND			23	0	0	0	0	53	0	0	0	0	0	0	0	0	0
START lt. blue sky STOP lt. blue sky			24	0	0	0	0	54	0	0	0	0	0	0	0	0	0
BACKGROUND COLOR	SKY CONDITIONS		25	0	0	0	0	55	0	0	0	0	0	0	0	0	0
START lt. blue STOP lt. blue	START Cloudy STOP Partly Cloudy		26	0	0	0	0	56	0	0	0	0	0	0	0	0	0
WIND SPEED (MPH)	WIND DIRECTION		27	0	0	0	0	57	0	0	0	0	0	0	0	0	0
START 5 STOP 0-5	START SE STOP SE		28	0	0	0	0	58	0	0	0	0	0	0	0	0	0
AMBIENT TEMPERATURE (F)	WET BULB TEMP	REL. HUMIDITY	29	0	0	0	0	59	0	0	0	0	0	0	0	0	0
START 70 STOP 70			30	0	0	0	0	60	0	0	0	0	0	0	0	0	0



AVERAGE OPACITY FOR HIGHEST PERIOD

NUMBER OF READINGS ABOVE WERE

RANGE OF OPACITY READINGS

MINIMUM 0 MAXIMUM 0

OBSERVER'S NAME (PRINT) Andrew Yang

OBSERVER'S SIGNATURE [Signature] DATE 5/19/04

ORGANIZATION ATP - Air Test Professionals, Inc.

CERTIFIED BY Carl Keontz DATE


Comments:

Visible Emissions Observations Form

RUN NUMBER

1C

SOURCE NAME <i>Nucor Steel</i>			OBSERVATION DATE <i>5/19/04</i>				START TIME <i>6:41</i>		STOP TIME <i>7:41</i>				
ADDRESS			sec				sec						
			min	0	15	30	45	min	0	15	30	45	
CITY		STATE	ZIP	1	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	31	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
PHONE		SOURCE ID NUMBER		2	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	32	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
PROCESS EQUIPMENT <i>EAF Furnaces &amp; AOD</i>		OPERATING MODE		3	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	33	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
CONTROL EQUIPMENT <i>Baghouse - WEST</i>		OPERATING MODE <i>Normal</i>		4	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	34	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <i>Roof Vent</i>				5	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	35	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
HEIGHT ABOVE GROUND LEVEL START <i>75'</i> STOP <i>75'</i>		HEIGHT RELATIVE TO OBSERVER START <i>75'</i> STOP <i>75'</i>		6	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	36	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
DISTANCE FROM OBSERVER START <i>400'</i> STOP <i>400'</i>		DIRECTION FROM OBSERVER START <i>N</i> STOP <i>N</i>		7	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	37	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
DESCRIBE EMISSIONS START <i>none</i> STOP <i>none</i>				8	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	38	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
EMISSION COLOR START <i>-</i> STOP <i>-</i>		PLUME TYPE: CONTINUOUS FUGITIVE INTERMITTENT		9	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	39	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
WATER DROPLETS PRESENT <input checked="" type="radio"/> NO YES		IF WATER DROPLET PLUME: ATTACHED DETACHED		10	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	40	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <i>Roof vent exit</i> STOP <i>Roof Vent Exit</i>				11	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	41	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
DESCRIBE BACKGROUND START <i>lt. blue sky</i> STOP <i>lt. blue sky</i>				12	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	42	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
BACKGROUND COLOR START <i>lt. blue</i> STOP <i>lt. blue</i>		SKY CONDITIONS START <i>cloudy</i> STOP <i>cloudy</i> <i>Partly</i>		13	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	43	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
WIND SPEED (MPH) START <i>5</i> STOP <i>0-5</i>		WIND DIRECTION START <i>SE</i> STOP <i>SE</i>		14	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	44	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
AMBIENT TEMPERATURE (F) START <i>70</i> STOP <i>70</i>		WET BULB TEMPERATURE PERCENT		15	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	45	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
SOURCE LAYOUT SKETCH				16	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	46	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>



AVERAGE OPACITY FOR HIGHEST PERIOD		NUMBER OF READINGS ABOVE WERE	
RANGE OF OPACITY READINGS			
MINIMUM <i>0</i>		MAXIMUM <i>0</i>	
OBSERVER'S NAME (PRINT) <i>Andrew Young</i>			
OBSERVER'S SIGNATURE <i>Andrew Young</i>		DATE <i>5/19/04</i>	
ORGANIZATION <i>ATP - Air Test Professionals, Inc.</i>			
CERTIFIED BY <i>Carl Kaantz</i>		DATE	
Comments:			

Visible Emissions Observations Form

RUN NUMBER 1 D

SOURCE NAME *Nucor Steel*

OBSERVATION DATE *5/19/04*

START TIME *7:41*

STOP TIME *8:27*

ADDRESS

CITY STATE ZIP

PHONE SOURCE ID NUMBER

PROCESS EQUIPMENT *EAF Furnace + AOD* OPERATING MODE

CONTROL EQUIPMENT *Reghouse - West* OPERATING MODE *Normal*

DESCRIBE EMISSION POINT (Stack Exit Dimensions) *Roof Vent*

HEIGHT ABOVE GROUND LEVEL START *75'* STOP *75'* HEIGHT RELATIVE TO OBSERVER START *75'* STOP *75'*

DISTANCE FROM OBSERVER START *400'* STOP *400'* DIRECTION FROM OBSERVER START *NE* STOP *NE*

DESCRIBE EMISSIONS START *none* STOP *none*

EMISSION COLOR START STOP PLUME TYPE: CONTINUOUS FUGITIVE INTERMITTENT

WATER DROPLETS PRESENT *NO* YES IF WATER DROPLET PLUME: ATTACHED DETACHED

POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START *Roof vent exit* STOP *Roof Vent Exit*

DESCRIBE BACKGROUND START *lt blue sky* STOP


BACKGROUND COLOR START *lt blue* STOP SKY CONDITIONS START *Pt. Cloudy* STOP

WIND SPEED (MPH) START *0-5* STOP WIND DIRECTION START *S* STOP

AMBIENT TEMPERATURE (F) START *70* STOP WET BULB TEMP RH PERCENT

sec	min	0	15	30	45	sec	min	0	15	30	45
1						31					
2						32					
3						33					
4						34					
5						35					
6						36					
7						37					
8						38					
9						39					
10						40					
11						41					
12						42					
13						43					
14						44					
15						45					
16						46					
17						47					
18						48					
19						49					
20						50					
21						51					
22						52					
23						53					
24						54					
25						55					
26						56					
27						57					
28						58					
29						59					
30						60					

Darkness



AVERAGE OPACITY FOR HIGHEST PERIOD NUMBER OF READINGS ABOVE WERE

RANGE OF OPACITY READINGS MINIMUM 0 MAXIMUM 0

OBSERVER'S NAME (PRINT) *Andrew Young*

OBSERVER'S SIGNATURE *Andrew Young* DATE *5/19/04*

ORGANIZATION *ATP - Air Test Professionals, Inc.*

CERTIFIED BY *Carl Koontz* DATE

Comments:

- X = Emission Point
- = Observer's Position
- ☉ = Sun
- = Wind
- = Plume

Visible Emissions Observations Form

RUN NUMBER

10

SOURCE NAME  
*Nucor Steel*

OBSERVATION DATE  
*5/19/04*

START TIME  
*7:41*

STOP TIME  
*8:07*

ADDRESS

CITY STATE ZIP

PHONE SOURCE ID NUMBER

PROCESS EQUIPMENT  
*EAF Furnace & AOD*

OPERATING MODE

CONTROL EQUIPMENT  
*Baghouse - EAST*

OPERATING MODE  
*Normal*

DESCRIBE EMISSION POINT (Stack Exit Dimensions)  
*Roof Vent*

HEIGHT ABOVE GROUND LEVEL  
START *75'* STOP *75'*

HEIGHT RELATIVE TO OBSERVER  
START *75'* STOP *75'*

DISTANCE FROM OBSERVER  
START *400'* STOP *400'*

DIRECTION FROM OBSERVER  
START *NE* STOP *NE*

DESCRIBE EMISSIONS  
START *none* STOP

EMISSION COLOR  
START STOP

PLUME TYPE: CONTINUOUS  
FUGITIVE INTERMITTENT

WATER DROPLETS PRESENT  
 YES

IF WATER DROPLET PLUME:  
ATTACHED DETACHED

POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED  
START *Roof vent exit* STOP

DESCRIBE BACKGROUND  
START *lt blue sky* STOP

BACKGROUND COLOR  
START *lt blue* STOP

SKY CONDITIONS  
START *Pt. Cloudy* STOP

WIND SPEED (MPH)  
START *0-5* STOP


WIND DIRECTION  
START *S* STOP

AMBIENT TEMPERATURE (F)  
START *70* STOP

WET BULB TEMP. RH. PERCENT

sec	0	15	30	45	sec	0	15	30	45
1	0	0	0	0	31	0	0	0	0
2	0	0	0	0	32	0	0	0	0
3	0	0	0	0	33	0	0	0	0
4	0	0	0	0	34	0	0	0	0
5	0	0	0	0	35	0	0	0	0
6	0	0	0	0	36	0	0	0	0
7	0	0	0	0	37	0	0	0	0
8	0	0	0	0	38	0	0	0	0
9	0	0	0	0	39	0	0	0	0
10	0	0	0	0	40	0	0	0	0
11	0	0	0	0	41	0	0	0	0
12	0	0	0	0	42	0	0	0	0
13	0	0	0	0	43	0	0	0	0
14	0	0	0	0	44	0	0	0	0
15	0	0	0	0	45	0	0	0	0
16	0	0	0	0	46	0	0	0	0
17	0	0	0	0	47	0	0	0	0
18	0	0	0	0	48				
19	0	0	0	0	49				
20	0	0	0	0	50				
21	0	0	0	0	51				
22	0	0	0	0	52				
23	0	0	0	0	53				
24	0	0	0	0	54				
25	0	0	0	0	55				
26	0	0	0	0	56				
27	0	0	0	0	57				
28	0	0	0	0	58				
29	0	0	0	0	59				
30	0	0	0	0	60				

Darkness



AVERAGE OPACITY FOR HIGHEST PERIOD NUMBER OF READINGS ABOVE WERE

RANGE OF OPACITY READINGS MINIMUM 0 MAXIMUM

OBSERVER'S NAME (PRINT)  
*Andrew Young*

OBSERVER'S SIGNATURE  
*Andrew Young* DATE *5/19/04*

ORGANIZATION  
*ATP - Air Test Professionals, Inc.*

CERTIFIED BY  
*Carl Koontz* DATE

Comments:


X = Emission Point  
 = Observer's Position  
 = Sun  
 = Wind  
 = Plume

Visible Emissions Observations Form

RUN NUMBER

2A

SOURCE NAME <i>Nucor Steel</i>			OBSERVATION DATE <i>5/21/04</i>				START TIME <i>0716</i>		STOP TIME <i>0816</i>	
ADDRESS			sec				sec			
			min	0	15	30	45	min	0	
CITY			STATE	ZIP	1	2	3	4	5	
PHONE			SOURCE ID NUMBER		31	32	33	34	35	
PROCESS EQUIPMENT <i>EAF Furnaces &amp; AOD</i>			OPERATING MODE		36	37	38	39	40	
CONTROL EQUIPMENT <i>Boiler - EAST</i>			OPERATING MODE <i>Normal</i>		41	42	43	44	45	
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <i>Roof vent</i>					46	47	48	49	50	
HEIGHT ABOVE GROUND LEVEL START <i>75'</i> STOP <i>75'</i>		HEIGHT RELATIVE TO OBSERVER START <i>75'</i> STOP <i>75'</i>				51	52	53	54	
DISTANCE FROM OBSERVER START <i>~300'</i> STOP <i>~300'</i>		DIRECTION FROM OBSERVER START <i>S</i> STOP <i>S</i>				55	56	57	58	
DESCRIBE EMISSIONS START <i>none</i> STOP <i>none</i>					59	60				
EMISSION COLOR START <i>—</i> STOP <i>—</i>		PLUME TYPE: CONTINUOUS FUGITIVE INTERMITTENT								
WATER DROPLETS PRESENT <input checked="" type="radio"/> NO YES		IF WATER DROPLET PLUME: ATTACHED DETACHED								
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <i>vent exit</i> STOP <i>vent exit</i>										
DESCRIBE BACKGROUND START <i>Overcast sky</i> STOP <i>Dark overcast sky</i>										
BACKGROUND COLOR START <i>white</i> STOP <i>Grey</i>		SKY CONDITIONS START <i>Overcast</i> STOP <i>overcast</i>								
WIND SPEED (MPH) START <i>0-5</i> STOP <i>5</i>		WIND DIRECTION START <i>W</i> STOP <i>W</i>								
AMBIENT TEMPERATURE (F) START <i>75</i> STOP <i>75</i>		WET BULB TEMP. RH. PERCENT								



AVERAGE OPACITY FOR HIGHEST PERIOD <i>0</i>		NUMBER OF READINGS ABOVE <i>0</i> WERE <i>0</i>	
RANGE OF OPACITY READINGS			
MINIMUM <i>0</i>		MAXIMUM <i>0</i>	
OBSERVER'S NAME (PRINT) <i>Andrew Young</i>			DATE <i>5/21/04</i>
OBSERVER'S SIGNATURE <i>Andrew Young</i>			
ORGANIZATION <i>ATP - Air Test Professionals, Inc.</i>			
CERTIFIED BY <i>Carl Keentz</i>			DATE
Comments:			


- X = Emission Point
- = Observer's Position
- ☀ = Sun
- = Wind
- = Plume

Visible Emissions Observations Form

RUN NUMBER

2A

SOURCE NAME <b>NUCOR STEEL</b>			OBSERVATION DATE <b>5/21/04-</b>			START TIME <b>0716</b>			STOP TIME <b>0816</b>			
ADDRESS			sec				sec					
CITY			min	0	15	30	45	min	0	15	30	45
STATE			1	0	0	0	0	31	0	0	0	0
ZIP			2	0	0	0	0	32	0	0	0	0
PHONE			3	0	0	0	0	33	0	0	0	0
SOURCE ID NUMBER			4	0	0	0	0	34	0	0	0	0
PROCESS EQUIPMENT <b>EAF Furnaces &amp; AOD</b>			5	0	0	0	0	35	0	0	0	0
OPERATING MODE			6	0	0	0	0	36	0	0	0	0
CONTROL EQUIPMENT <b>Baghouse - WEST</b>			7	0	0	0	0	37	0	0	0	0
OPERATING MODE <b>Normal</b>			8	0	0	0	0	38	0	0	0	0
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>Roof vent</b>			9	0	0	0	0	39	0	0	0	0
HEIGHT ABOVE GROUND LEVEL			10	0	0	0	0	40	0	0	0	0
HEIGHT RELATIVE TO OBSERVER			11	0	0	0	0	41	0	0	0	0
START <b>75'</b> STOP <b>75'</b>			12	0	0	0	0	42	0	0	0	0
DISTANCE FROM OBSERVER			13	0	0	0	0	43	0	0	0	0
DIRECTION FROM OBSERVER			14	0	0	0	0	44	0	0	0	0
START <b>300'</b> STOP <b>~300'</b>			15	0	0	0	0	45	0	0	0	0
DIRECTION FROM OBSERVER			16	0	0	0	0	46	0	0	0	0
START <b>S</b> STOP <b>S</b>			17	0	0	0	0	47	0	0	0	0
DESCRIBE EMISSIONS			18	0	0	0	0	48	0	0	0	0
START <b>none</b> STOP <b>none</b>			19	0	0	0	0	49	0	0	0	0
EMISSION COLOR			20	0	0	0	0	50	0	0	0	0
START <b>—</b> STOP <b>—</b>			21	0	0	0	0	51	0	0	0	0
PLUME TYPE: CONTINUOUS			22	0	0	0	0	52	0	0	0	0
FUGITIVE INTERMITTENT			23	0	0	0	0	53	0	0	0	0
WATER DROPLETS PRESENT			24	0	0	0	0	54	0	0	0	0
IF WATER DROPLET PLUME:			25	0	0	0	0	55	0	0	0	0
ATTACHED DETACHED			26	0	0	0	0	56	0	0	0	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED			27	0	0	0	0	57	0	0	0	0
START <b>Roof vent exit</b> STOP <b>Vent exit</b>			28	0	0	0	0	58	0	0	0	0
DESCRIBE BACKGROUND			29	0	0	0	0	59	0	0	0	0
START <b>Overcast sky</b> STOP <b>Dark overcast sky</b>			30	0	0	0	0	60	0	0	0	0
BACKGROUND COLOR												
START <b>White</b> STOP <b>Grey</b>												
SKY CONDITIONS												
START <b>Overcast</b> STOP <b>Overcast</b>												
WIND SPEED (MPH)												
START <b>0-5</b> STOP <b>5</b>												
WIND DIRECTION												
START <b>W</b> STOP <b>W</b>												
AMBIENT TEMPERATURE (F)												
START <b>75</b> STOP <b>75</b>												



AVERAGE OPACITY FOR HIGHEST PERIOD **0**

NUMBER OF READINGS ABOVE WERE **0**

RANGE OF OPACITY READINGS

MINIMUM **0** MAXIMUM **0**

OBSERVER'S NAME (PRINT) **Andrew Young**

OBSERVER'S SIGNATURE **Andrew Young** DATE **5/21/04-**

ORGANIZATION **ATP - Air Test Professionals, Inc.**

CERTIFIED BY **Carl Koontz** DATE

Comments:


- X = Emission Point
- = Observer's Position
- ☀ = Sun
- = Wind
- = Plume

Visible Emissions Observations Form

RUN NUMBER

28

SOURCE NAME <i>Ndoor Steel</i>			OBSERVATION DATE <i>5/21/04</i>				START TIME <i>0816</i>		STOP TIME <i>0916</i>			
ADDRESS			sec				sec					
			min	0	15	30	45	min	0	15	30	45
CITY		STATE	ZIP	1	0	0	0	31	0	0	0	0
				2	0	0	0	32	0	0	0	0
PHONE		SOURCE ID NUMBER		3	0	0	0	33	0	0	0	0
				4	0	0	0	34	0	0	0	0
PROCESS EQUIPMENT <i>EAF Furnaces + AOD</i>		OPERATING MODE		5	0	0	0	35	0	0	0	0
				6	0	0	0	36	0	0	0	0
CONTROL EQUIPMENT <i>Baghouse - EAST</i>		OPERATING MODE <i>Normal</i>		7	0	0	0	37	0	0	0	0
				8	0	0	0	38	0	0	0	0
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <i>Roof vent</i>			9	0	0	0	39	0	0	0	0	0
			10	0	0	0	40	0	0	0	0	0
HEIGHT ABOVE GROUND LEVEL START <i>75'</i> STOP <i>75'</i>		HEIGHT RELATIVE TO OBSERVER START <i>75'</i> STOP <i>75'</i>		11	0	0	0	41	0	0	0	0
				12	0	0	0	42	0	0	0	0
DISTANCE FROM OBSERVER START <i>~300'</i> STOP <i>~300'</i>		DIRECTION FROM OBSERVER START <i>S</i> STOP <i>S</i>		13	0	0	0	43	0	0	0	0
				14	0	0	0	44	0	0	0	0
DESCRIBE EMISSIONS START <i>None</i> STOP <i>None</i>			15	0	0	0	45	0	0	0	0	0
			16	0	0	0	46	0	0	0	0	0
EMISSION COLOR START <i>—</i> STOP <i>—</i>		PLUME TYPE: CONTINUOUS		17	0	0	0	47	0	0	0	0
		FUGITIVE INTERMITTENT		18	0	0	0	48	0	0	0	0
WATER DROPLETS PRESENT <input checked="" type="checkbox"/> NO YES		IF WATER DROPLET PLUME: ATTACHED DETACHED		19	0	0	0	49	0	0	0	0
				20	0	0	0	50	0	0	0	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <i>vent exit</i> STOP <i>VENT EXIT</i>			21	0	0	0	51	0	0	0	0	0
			22	0	0	0	52	0	0	0	0	0
DESCRIBE BACKGROUND START <i>Dark Overcast sky</i> STOP <i>Overcast sky</i>			23	0	0	0	53	0	0	0	0	0
			24	0	0	0	54	0	0	0	0	0
BACKGROUND COLOR START <i>Grey</i> STOP <i>Grey</i>		SKY CONDITIONS START <i>Dark &amp; Overcast</i> STOP <i>Overcast</i>		25	0	0	0	55	0	0	0	0
				26	0	0	0	56	0	0	0	0
WIND SPEED (MPH) START <i>5</i> STOP <i>5</i>		WIND DIRECTION START <i>W</i> STOP <i>W</i>		27	0	0	0	57	0	0	0	0
				28	0	0	0	58	0	0	0	0
AMBIENT TEMPERATURE (F) START <i>75</i> STOP <i>75</i>		WET BULB TEMP. RH PERCENT		29	0	0	0	59	0	0	0	0
				30	0	0	0	60	0	0	0	0



AVERAGE OPACITY FOR HIGHEST PERIOD *0*

NUMBER OF READINGS ABOVE WERE *0*

RANGE OF OPACITY READINGS  
MINIMUM *0* MAXIMUM *0*

OBSERVER'S NAME (PRINT)  
*Andrew Young*

OBSERVER'S SIGNATURE  
*Andrew Young*

DATE  
*5/21/04*

ORGANIZATION  
*ATP - Air Test Professionals, Inc.*

CERTIFIED BY  
*Carl Koontz*

DATE

Comments:


- X = Emission Point
- = Observer's Position
- ☀ = Sun
- = Wind
- = Plume

Visible Emissions Observations Form

RUN NUMBER

2B

SOURCE NAME <i>Nucor Steel</i>			OBSERVATION DATE <i>5/21/04</i>				START TIME <i>0816</i>		STOP TIME <i>0916</i>			
ADDRESS			sec				sec					
			min	0	15	30	45	min	0	15	30	45
CITY	STATE	ZIP	1	0	0	0	0	31	0	0	0	0
			2	0	0	0	0	32	0	0	0	0
PHONE		SOURCE ID NUMBER	3	0	0	0	0	33	0	0	0	0
			4	0	0	0	0	34	0	0	0	0
PROCESS EQUIPMENT <i>EAF Furnaces + AOD</i>		OPERATING MODE	5	0	0	0	0	35	0	0	0	0
			6	0	0	0	0	36	0	0	0	0
CONTROL EQUIPMENT <i>Reghouse - WEST</i>		OPERATING MODE <i>Normal</i>	7	0	0	0	0	37	0	0	0	0
			8	0	0	0	0	38	0	0	0	0
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <i>Roof vent</i>			9	0	0	0	0	39	0	0	0	0
			10	0	0	0	0	40	0	0	0	0
HEIGHT ABOVE GROUND LEVEL START <i>75</i> STOP <i>75</i>		HEIGHT RELATIVE TO OBSERVER START <i>75'</i> STOP <i>75'</i>	11	0	0	0	0	41	0	0	0	0
			12	0	0	0	0	42	0	0	0	0
DISTANCE FROM OBSERVER START <i>~300'</i> STOP <i>~300'</i>		DIRECTION FROM OBSERVER START <i>S</i> STOP <i>S</i>	13	0	0	0	0	43	0	0	0	0
			14	0	0	0	0	44	0	0	0	0
DESCRIBE EMISSIONS START <i>None</i> STOP <i>None</i>			15	0	0	0	0	45	0	0	0	0
			16	0	0	0	0	46	0	0	0	0
EMISSION COLOR START <i>—</i> STOP <i>—</i>		PLUME TYPE: CONTINUOUS FUGITIVE INTERMITTENT	17	0	0	0	0	47	0	0	0	0
			18	0	0	0	0	48	0	0	0	0
WATER DROPLETS PRESENT <input checked="" type="radio"/> NO YES		IF WATER DROPLET PLUME: ATTACHED DETACHED	19	0	0	0	0	49	0	0	0	0
			20	0	0	0	0	50	0	0	0	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <i>vent exit</i> STOP <i>Vent Exit</i>			21	0	0	0	0	51	0	0	0	0
			22	0	0	0	0	52	0	0	0	0
DESCRIBE BACKGROUND START <i>Dark overcast sky</i> STOP <i>Overcast sky</i>			23	0	0	0	0	53	0	0	0	0
			24	0	0	0	0	54	0	0	0	0
BACKGROUND COLOR START <i>Grey</i> STOP <i>Grey</i>		SKY CONDITIONS START <i>Dark overcast</i> STOP <i>Overcast</i>	25	0	0	0	0	55	0	0	0	0
			26	0	0	0	0	56	0	0	0	0
WIND SPEED (MPH) START <i>5</i> STOP <i>5</i>		WIND DIRECTION START <i>W</i> STOP <i>W</i>	27	0	0	0	0	57	0	0	0	0
			28	0	0	0	0	58	0	0	0	0
AMBIENT TEMPERATURE (F) START <i>75</i> STOP <i>75</i>		WET BULB TEMPERATURE REF. REFERENCE	29	0	0	0	0	59	0	0	0	0
			30	0	0	0	0	60	0	0	0	0



AVERAGE OPACITY FOR HIGHEST PERIOD *0*

NUMBER OF READINGS ABOVE WERE *0*

RANGE OF OPACITY READINGS  
MINIMUM *0* MAXIMUM *0*

OBSERVER'S NAME (PRINT)  
*Andrew Young*

OBSERVER'S SIGNATURE  
*Andrew Young*

DATE  
*5/21/04*

ORGANIZATION  
*ATP - Air Test Professionals, Inc.*

CERTIFIED BY  
*Carl Koantz*

DATE

Comments:

- X = Emission Point
- = Observer's Position
- ☀ = Sun
- ← = Wind
- = Plume




Visible Emissions Observations Form

RUN NUMBER

20

SOURCE NAME <i>Nucar Steel</i>			OBSERVATION DATE <i>5/21/04</i>				START TIME <i>0916</i>		STOP TIME <i>1021</i>			
ADDRESS			sec				sec					
			min	0	15	30	45	min	0	15	30	45
CITY		STATE	ZIP	1	0	0	0	31	0	0	0	0
				2	0	0	0	32	0	0	0	0
PHONE		SOURCE ID NUMBER		3	0	0	0	33	0	0	0	0
				4	0	0	0	34	0	0	0	0
PROCESS EQUIPMENT <i>EAF Furnaces + AOD</i>		OPERATING MODE		5	0	0	0	35	0	0	0	0
				6	0	0	0	36	0	0	0	0
CONTROL EQUIPMENT <i>Baghouse - East</i>		OPERATING MODE <i>Normal</i>		7	0	0	0	37	0	0	0	0
				8	0	0	0	38	0	0	0	0
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <i>Roof vent</i>			9	0	0	0	39	0	0	0	0	0
			10	0	0	0	40	0	0	0	0	0
HEIGHT ABOVE GROUND LEVEL START <i>75'</i> STOP <i>75'</i>		HEIGHT RELATIVE TO OBSERVER START <i>75'</i> STOP <i>75'</i>		11	0	0	0	41	0	0	0	0
				12	0	0	0	42	0	0	0	0
DISTANCE FROM OBSERVER START <i>300'</i> STOP <i>300'</i>		DIRECTION FROM OBSERVER START <i>S</i> STOP <i>S</i>		13	0	0	0	43	0	0	0	0
				14	0	0	0	44	0	0	0	0
DESCRIBE EMISSIONS START <i>None</i> STOP <i>none</i>			15	0	0	0	45	0	0	0	0	0
			16	0	0	0	46	0	0	0	0	0
EMISSION COLOR START <i>-</i> STOP <i>-</i>		PLUME TYPE: CONTINUOUS		17	0	0	0	47	0	0	0	0
		FUGITIVE INTERMITTENT		18	0	0	0	48	0	0	0	0
WATER DROPLETS PRESENT <input checked="" type="radio"/> NO YES		IF WATER DROPLET PLUME: ATTACHED DETACHED		19	0	0	0	49	0	0	0	0
				20	0	0	0	50	0	0	0	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <i>Vent Exit</i> STOP <i>vent exit</i>			21	0	0	0	51	0	0	0	0	0
			22	0	0	0	52	0	0	0	0	0
DESCRIBE BACKGROUND START <i>Overcast sky</i> STOP <i>overcast sky</i>			23	0	0	0	53	0	0	0	0	0
			24	0	0	0	54	0	0	0	0	0
BACKGROUND COLOR START <i>Grey</i> STOP <i>white/grey</i>		SKY CONDITIONS START <i>overcast</i> STOP <i>Mostly Cloudy</i>		25	0	0	0	55	0	0	0	0
				26	0	0	0	56	0	0	0	0
WIND SPEED (MPH) START <i>5</i> STOP <i>5-10</i>		WIND DIRECTION START <i>W</i> STOP <i>W</i>		27	0	0	0	57	0	0	0	0
				28	0	0	0	58	0	0	0	0
AMBIENT TEMPERATURE (F) START <i>75</i> STOP <i>80</i>		WET BULB TEMP. REL. HUMIDITY		29	0	0	0	59	0	0	0	0
				30	0	0	0	60	0	0	0	0

SOURCE LAYOUT SKETCH Draw North Arrow



AVERAGE OPACITY FOR HIGHEST PERIOD	NUMBER OF READINGS ABOVE WERE
0	0
RANGE OF OPACITY READINGS	
MINIMUM	MAXIMUM
0	0
OBSERVER'S NAME (PRINT) <i>Andrew Young</i>	
OBSERVER'S SIGNATURE <i>Carl Kuntz</i>	DATE <i>5/21/04</i>
ORGANIZATION <i>ATP - Air Test Professionals, Inc.</i>	
CERTIFIED BY <i>Carl Kuntz</i>	DATE

Comments:


- X = Emission Point
- = Observer's Position
- ☀ = Sun
- = Wind
- = Plume

Visible Emissions Observations Form

RUN NUMBER

20

SOURCE NAME <i>Nucor Steel</i>			OBSERVATION DATE <i>5/21/04</i>				START TIME <i>0916</i>		STOP TIME <i>1021</i>				
ADDRESS			sec				sec						
			min	0	15	30	45	min	0	15	30	45	
CITY		STATE	ZIP	1	0	15	30	45	31	0	15	30	45
PHONE		SOURCE ID NUMBER		2	0	15	30	45	32	0	15	30	45
PROCESS EQUIPMENT <i>EAF Furnaces + AOD</i>		OPERATING MODE		3	0	15	30	45	33	0	15	30	45
CONTROL EQUIPMENT <i>Baghouse - West</i>		OPERATING MODE <i>Normal</i>		4	0	15	30	45	34	0	15	30	45
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <i>Roof Vent</i>			5	0	15	30	45	35	0	15	30	45	
HEIGHT ABOVE GROUND LEVEL START <i>75'</i> STOP <i>75'</i>		HEIGHT RELATIVE TO OBSERVER START <i>75'</i> STOP <i>75'</i>		6	0	15	30	45	36	0	15	30	45
DISTANCE FROM OBSERVER START <i>300'</i> STOP <i>300'</i>		DIRECTION FROM OBSERVER START <i>S</i> STOP <i>S</i>		7	0	15	30	45	37	0	15	30	45
DESCRIBE EMISSIONS START <i>None</i> STOP <i>none</i>			8	0	15	30	45	38	0	15	30	45	
EMISSION COLOR START <i>-</i> STOP <i>-</i>		PLUME TYPE: CONTINUOUS		9	0	15	30	45	39	0	15	30	45
WATER DROPLETS PRESENT <input checked="" type="checkbox"/> YES		IF WATER DROPLET PLUME: ATTACHED DETACHED		10	0	15	30	45	40	0	15	30	45
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <i>Vent Exit</i> STOP <i>vent exit</i>			11	0	15	30	45	41	0	15	30	45	
DESCRIBE BACKGROUND START <i>Overcast sky</i> STOP <i>Mostly cloudy sky</i>			12	0	15	30	45	42	0	15	30	45	
BACKGROUND COLOR START <i>Grey</i> STOP <i>white/grey</i>		SKY CONDITIONS START <i>Overcast</i> STOP <i>Mostly cloudy</i>		13	0	15	30	45	43	0	15	30	45
WIND SPEED (MPH) START <i>5</i> STOP <i>5-10</i>		WIND DIRECTION START <i>W</i> STOP <i>W</i>		14	0	15	30	45	44	0	15	30	45
AMBIENT TEMPERATURE (F) START <i>75</i> STOP <i>80</i>		WET BULB TEMP. RH. PERCENT		15	0	15	30	45	45	0	15	30	45
SOURCE LAYOUT SKETCH			16	0	15	30	45	46	0	15	30	45	



AVERAGE OPACITY FOR HIGHEST PERIOD		NUMBER OF READINGS ABOVE WERE	
<i>0</i>		<i>0</i>	
RANGE OF OPACITY READINGS			
MINIMUM		MAXIMUM	
<i>0</i>		<i>0</i>	
OBSERVER'S NAME (PRINT) <i>Andrew Young</i>			
OBSERVER'S SIGNATURE <i>Andrew Young</i>		DATE <i>5/21/04</i>	
ORGANIZATION <i>ATP - Air Test Professionals, Inc.</i>			
CERTIFIED BY <i>Carl Kautz</i>		DATE	
Comments:			


- X = Emission Point
- = Observer's Position
- ☀ = Sun
- = Wind
- = Plume

Visible Emissions Observations Form

RUN NUMBER

20

SOURCE NAME <i>Nucar Steel</i>			OBSERVATION DATE <i>5/21/04</i>				START TIME <i>1030</i>		STOP TIME <i>1130</i>			
ADDRESS			sec				sec					
			min	0	15	30	45	min	0	15	30	45
CITY		STATE	ZIP	1	2	3	4	5	6	7	8	9
PHONE		SOURCE ID NUMBER		10	11	12	13	14	15	16	17	18
PROCESS EQUIPMENT <i>EAF Furnaces &amp; AOD</i>			OPERATING MODE			19	20	21	22	23	24	25
CONTROL EQUIPMENT <i>Baghouse - East</i>			OPERATING MODE <i>Normal</i>			26	27	28	29	30	31	32
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <i>Roof vents</i>			33	34	35	36	37	38	39	40	41	42
HEIGHT ABOVE GROUND LEVEL START <i>75'</i> STOP <i>75'</i>		HEIGHT RELATIVE TO OBSERVER START <i>75'</i> STOP <i>75'</i>		43	44	45	46	47	48	49	50	51
DISTANCE FROM OBSERVER START <i>~400'</i> STOP <i>~400'</i>		DIRECTION FROM OBSERVER START <i>N</i> STOP <i>N</i>		52	53	54	55	56	57	58	59	60
DESCRIBE EMISSIONS START <i>None</i> STOP <i>none</i>			15	16	17	18	19	20	21	22	23	24
EMISSION COLOR START <i>-</i> STOP <i>-</i>		PLUME TYPE <i>CONTINUOUS</i>		25	26	27	28	29	30	31	32	33
WATER DROPLETS PRESENT <i>NO</i> YES		IF WATER DROPLET PLUME: ATTACHED DETACHED		34	35	36	37	38	39	40	41	42
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <i>Roof vent exit</i> STOP <i>Vent exit</i>			43	44	45	46	47	48	49	50	51	52
DESCRIBE BACKGROUND START <i>Mostly Cloudy sky</i> STOP <i>Mostly Cloudy sky</i>			53	54	55	56	57	58	59	60		
BACKGROUND COLOR START <i>White/grey</i> STOP <i>grey</i>		SKY CONDITIONS START <i>Mostly Cloudy</i> STOP <i>Mostly Cloudy</i>		25	26	27	28	29	30			
WIND SPEED (MPH) START <i>5-10</i> STOP <i>5-10</i>		WIND DIRECTION START <i>W</i> STOP <i>W</i>		27	28	29	30					
AMBIENT TEMPERATURE (F) START <i>80</i> STOP <i>80</i>		WET BULB TEMP		29	30							



AVERAGE OPACITY FOR HIGHEST PERIOD		NUMBER OF READINGS ABOVE WERE	
<i>0</i>		<i>0</i>	
RANGE OF OPACITY READINGS			
MINIMUM		MAXIMUM	
<i>0</i>		<i>0</i>	
OBSERVER'S NAME (PRINT) <i>Andrew Young</i>			
OBSERVER'S SIGNATURE <i>Andrew Young</i>		DATE <i>5/21/04</i>	
ORGANIZATION <i>ATP - Air Test Professionals, Inc.</i>			
CERTIFIED BY <i>Carl Kautz</i>		DATE	
Comments:			


- X = Emission Point
- ↖ = Wind
- = Observer's Position
- = Plume
- ☀ = Sun

Visible Emissions Observations Form

RUN NUMBER

20

SOURCE NAME <i>Nucor Steel</i>			OBSERVATION DATE <i>5/21/04</i>				START TIME <i>10 30</i>		STOP TIME <i>11 30</i>			
ADDRESS			sec				sec					
			min	0	15	30	45	min	0	15	30	45
CITY	STATE	ZIP	1	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	31	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
			2	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	32	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
PHONE			SOURCE ID NUMBER				3	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
			4	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	34	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
PROCESS EQUIPMENT <i>EAF Furnaces &amp; AOD</i>		OPERATING MODE		5	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	35	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
				6	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	36	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
CONTROL EQUIPMENT <i>Baghouse - West</i>		OPERATING MODE <i>Normal</i>		7	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	37	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
				8	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	38	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <i>Roof Vents</i>			9	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	39	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
			10	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	40	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
HEIGHT ABOVE GROUND LEVEL START <i>75'</i> STOP <i>75'</i>		HEIGHT RELATIVE TO OBSERVER START <i>75'</i> STOP <i>75'</i>		11	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	41	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
				12	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	42	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
DISTANCE FROM OBSERVER START <i>~400'</i> STOP <i>~400'</i>		DIRECTION FROM OBSERVER START <i>N</i> STOP <i>N</i>		13	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	43	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
				14	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	44	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
DESCRIBE EMISSIONS START <i>None</i> STOP <i>none</i>			15	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	45	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
			16	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	46	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
EMISSION COLOR START <i>-</i> STOP <i>-</i>		PLUME TYPE: <u>CONTINUOUS</u>		17	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	47	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
		FUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>		18	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	48	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
WATER DROPLETS PRESENT <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		IF WATER DROPLET PLUME: ATTACHED <input type="checkbox"/> DETACHED <input type="checkbox"/>		19	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	49	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
				20	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	50	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <i>Roof vent exit</i> STOP <i>vent exit</i>			21	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	51	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
			22	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	52	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	
DESCRIBE BACKGROUND START <i>Mostly Clear sky</i> STOP <i>mostly cloudy sky</i>			23	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	53	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
			24	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	54	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	
BACKGROUND COLOR START <i>white</i> STOP <i>grey</i>		SKY CONDITIONS START <i>Mostly Clear</i> STOP <i>cloudy</i>		25	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	55	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
				26	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	56	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
WIND SPEED (MPH) START <i>5-10</i> STOP <i>5-10</i>		WIND DIRECTION START <i>W</i> STOP <i>W</i>		27	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	57	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
				28	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	58	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
AMBIENT TEMPERATURE (F) START <i>80</i> STOP <i>80</i>		WET BULB TEMP		29	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	59	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
		RH PERCENT		30	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	60	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>



AVERAGE OPACITY FOR HIGHEST PERIOD

NUMBER OF READINGS ABOVE WERE

RANGE OF OPACITY READINGS  
MINIMUM  MAXIMUM

OBSERVER'S NAME (PRINT) *Andrew Young*

OBSERVER'S SIGNATURE *Andrew Young* DATE *5/21/04*

ORGANIZATION *ATP - Air Test Professionals, Inc.*

CERTIFIED BY *Carl Kowitz* DATE

Comments:

- X = Emission Point
- P = Observer's Position
- ☀ = Sun
- = Wind
- = Plume

Visible Emissions Observations Form

RUN NUMBER

3A

SOURCE NAME **NUCOR STEEL**

OBSERVATION DATE **05 - 21 - 04**

START TIME **1320**

STOP TIME **1420**

ADDRESS

sec					sec				
min	0	15	30	45	min	0	15	30	45

CITY **CRAWFORDSVILLE**

STATE **IN**

ZIP

1	0	0	0	0	31	0	0	0	0
2	0	0	0	0	32	0	0	0	0

PHONE

SOURCE ID NUMBER

3	0	0	0	0	33	0	0	0	0
4	0	0	0	0	34	0	0	0	0

PROCESS EQUIPMENT **EAF & AOD**

OPERATING MODE **NORMAL**

5	0	0	0	0	35	0	0	0	0
6	0	0	0	0	36	0	0	0	0

CONTROL EQUIPMENT **BAGHOUSE - EAST**

OPERATING MODE **NORMAL**

7	0	0	0	0	37	0	0	0	0
8	0	0	0	0	38	0	0	0	0

DESCRIBE EMISSION POINT (Stack Exit Dimensions) **ROOF MONITORS**

9	0	0	0	0	39	0	0	0	0
10	0	0	0	0	40	0	0	0	0

HEIGHT ABOVE GROUND LEVEL **START 75' STOP 75'**

HEIGHT RELATIVE TO OBSERVER **START 75' STOP 75'**

11	0	0	0	0	41	0	0	0	0
12	0	0	0	0	42	0	0	0	0

DISTANCE FROM OBSERVER **START 200 yd STOP 200 yd**

DIRECTION FROM OBSERVER **START NE STOP NE**

13	0	0	0	0	43	0	0	0	0
14	0	0	0	0	44	0	0	0	0

DESCRIBE EMISSIONS **START N/A STOP N/A**

15	0	0	0	0	45	0	0	0	0
16	0	0	0	0	46	0	0	0	0

EMISSION COLOR **START N/A STOP N/A**

PLUME TYPE: **CONTINUOUS**  
FUGITIVE **INTERMITTENT**

17	0	0	0	0	47	0	0	0	0
18	0	0	0	0	48	0	0	0	0

WATER DROPLETS PRESENT **NO**

IF WATER DROPLET PLUME: **ATTACHED** **DETACHED**

19	0	0	0	0	49	0	0	0	0
20	0	0	0	0	50	0	0	0	0

POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED **START ROOF MONITOR STOP ROOF MONITOR**

21	0	0	0	0	51	0	0	0	0
22	0	0	0	0	52	0	0	0	0

DESCRIBE BACKGROUND **START Mostly Cloudy Sky STOP Mostly Cloudy Sky**

23	0	0	0	0	53	0	0	0	0
24	0	0	0	0	54	0	0	0	0

BACKGROUND COLOR **START Gray STOP Gray**

SKY CONDITIONS **START MC STOP MC**

25	0	0	0	0	55	0	0	0	0
26	0	0	0	0	56	0	0	0	0

WIND SPEED (MPH) **START 5 mph STOP 5 mph**


WIND DIRECTION **START E STOP E**

27	0	0	0	0	57	0	0	0	0
28	0	0	0	0	58	0	0	0	0

AMBIENT TEMPERATURE (F) **START 85 STOP 85**

WET BULB TEMP **RAI PERCENT**

29	0	0	0	0	59	0	0	0	0
30	0	0	0	0	60	0	0	0	0



AVERAGE OPACITY FOR HIGHEST PERIOD **0** NUMBER OF READINGS ABOVE WERE **0**

RANGE OF OPACITY READINGS MINIMUM **0** MAXIMUM **0**

OBSERVER'S NAME (PRINT) **CARLOS BROWN**

OBSERVER'S SIGNATURE **[Signature]** DATE **05 - 21 - 04**

ORGANIZATION **ATP - Air Test Professionals, Inc.**

CERTIFIED BY **CARL KOONTZ** DATE

Comments:


- X = Emission Point
- Observer's Position
- Sun
- = Wind
- = Plume


Visible Emissions Observations Form

RUN NUMBER

3A

SOURCE NAME <b>NUCOR STEEL</b>			OBSERVATION DATE <b>05 - 21 - 04</b>				START TIME <b>1320</b>		STOP TIME <b>1420</b>	
ADDRESS			sec				sec			
			min	0	15	30	45	min	0	
CITY <b>CRAWFORDSVILLE</b>		STATE <b>IN</b>	ZIP							
PHONE		SOURCE ID NUMBER								
PROCESS EQUIPMENT <b>EAP's &amp; Add</b>		OPERATING MODE <b>NORMAL</b>								
CONTROL EQUIPMENT <b>PPFF BAGHOUSE (WEST)</b>		OPERATING MODE <b>NORMAL</b>								
DESCRIBE EMISSION POINT, (Stack Exit Dimensions) <b>ROOF MONITORS</b>										
HEIGHT ABOVE GROUND LEVEL START <b>75'</b> STOP <b>75'</b>		HEIGHT RELATIVE TO OBSERVER START <b>75'</b> STOP <b>75'</b>								
DISTANCE FROM OBSERVER START STOP		DIRECTION FROM OBSERVER START <b>NE</b> STOP <b>NE</b>								
DESCRIBE EMISSIONS START <b>N/A</b> STOP <b>N/A</b>										
EMISSION COLOR START <b>N/A</b> STOP <b>N/A</b>		PLUME TYPE: CONTINUOUS								
		FUGITIVE INTERMITTENT								
WATER DROPLETS PRESENT <input checked="" type="radio"/> NO YES		IF WATER DROPLET PLUME: ATTACHED DETACHED								
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <b>ROOF MONITORS</b> STOP <b>ROOF MONITORS</b>										
DESCRIBE BACKGROUND START <b>Cloudy Sky</b> STOP <b>Cloudy Sky</b>										
BACKGROUND COLOR START <b>Gray</b> STOP <b>Gray</b>		SKY CONDITIONS START <b>Cloudy</b> STOP <b>Cloudy</b>								
WIND SPEED (MPH) START <b>5</b> STOP <b>5</b>		WIND DIRECTION START <b>E</b> STOP <b>E</b>								
AMBIENT TEMPERATURE (F) START <b>85</b> STOP <b>85</b>		WET BULB TEMP		REL. HUMIDITY						

AVERAGE OPACITY FOR HIGHEST PERIOD <b>0</b>		NUMBER OF READINGS ABOVE WERE <b>0</b>	
RANGE OF OPACITY READINGS MINIMUM <b>0</b> MAXIMUM <b>0</b>			
OBSERVER'S NAME (PRINT) <b>CARLOS BROWN</b>			
OBSERVER'S SIGNATURE 		DATE <b>05 - 21 - 04</b>	
ORGANIZATION <b>ATP - Air Test Professionals, Inc.</b>			
CERTIFIED BY <b>CARL KOONTZ</b>		DATE <b>05-2</b>	
Comments:			




- X = Emission Point
- = Observer's Position
- ☀ = Sun
- ~ = Wind
- = Plume

Visible Emissions Observations Form

RUN NUMBER 3B

SOURCE NAME <b>NUCOR STEEL</b>		OBSERVATION DATE <b>05-21-04</b>				START TIME <b>1422</b>		STOP TIME <b>1522</b>			
ADDRESS		sec				sec					
CITY <b>Crawfordsville</b>	STATE <b>IN</b>	min	0	15	30	45	min	0	15	30	45
PHONE	SOURCE ID NUMBER	1	0	0	0	0	31	0	0	0	0
PROCESS EQUIPMENT <b>EAP's &amp; AOD</b>	OPERATING MODE <b>NORMAL</b>	2	0	0	0	0	32	0	0	0	0
CONTROL EQUIPMENT <b>BAGHOUSE - EAST</b>	OPERATING MODE <b>NORMAL</b>	3	0	0	0	0	33	0	0	0	0
PROCESS EQUIPMENT	OPERATING MODE	4	0	0	0	0	34	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	5	0	0	0	0	35	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	6	0	0	0	0	36	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	7	0	0	0	0	37	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	8	0	0	0	0	38	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	9	0	0	0	0	39	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	10	0	0	0	0	40	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	11	0	0	0	0	41	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	12	0	0	0	0	42	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	13	0	0	0	0	43	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	14	0	0	0	0	44	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	15	0	0	0	0	45	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	16	0	0	0	0	46	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	17	0	0	0	0	47	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	18	0	0	0	0	48	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	19	0	0	0	0	49	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	20	0	0	0	0	50	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	21	0	0	0	0	51	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	22	0	0	0	0	52	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	23	0	0	0	0	53	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	24	0	0	0	0	54	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	25	0	0	0	0	55	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	26	0	0	0	0	56	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	27	0	0	0	0	57	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	28	0	0	0	0	58	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	29	0	0	0	0	59	0	0	0	0
CONTROL EQUIPMENT	OPERATING MODE	30	0	0	0	0	60	0	0	0	0



AVERAGE OPACITY FOR HIGHEST PERIOD	0	NUMBER OF READINGS ABOVE	0
RANGE OF OPACITY READINGS	MINIMUM 0	MAXIMUM 0	WERE 0
OBSERVER'S NAME (PRINT)	CARLOS BROWN		
OBSERVER'S SIGNATURE	[Signature]		
DATE	05-21-04		
ORGANIZATION	ATP - Air Test Professionals, Inc.		
CERTIFIED BY	CARL KOONTZ		DATE
Comments:			

X = Emission Point = Wind

☉ = Observer's Position = Plume


☀ = Sun

Visible Emissions Observations Form

RUN NUMBER 3B

SOURCE NAME <b>NUCOR STEEL</b>			OBSERVATION DATE <b>05-21-04</b>				START TIME <b>1422</b>		STOP TIME <b>1522</b>	
ADDRESS			sec				sec			
			min	0	15	30	45	min	0	
CITY <b>CRAWFORDVILLE</b>			STATE <b>IN</b>	ZIP						
PHONE			SOURCE ID NUMBER							
PROCESS EQUIPMENT <b>EAF'S &amp; ADD</b>			OPERATING MODE <b>NORMAL</b>							
CONTROL EQUIPMENT <b>BAGHOUSE - WEST</b>			OPERATING MODE							
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>ROOF MONITORS</b>										
HEIGHT ABOVE GROUND LEVEL START <b>75'</b> STOP <b>75'</b>		HEIGHT RELATIVE TO OBSERVER START <b>75'</b> STOP <b>75'</b>								
DISTANCE FROM OBSERVER START <b>200 yd</b> STOP <b>200 yd</b>		DIRECTION FROM OBSERVER START <b>NE</b> STOP <b>NE</b>								
DESCRIBE EMISSIONS START <b>N/A</b> STOP <b>N/A</b>										
EMISSION COLOR START <b>N/A</b> STOP <b>N/A</b>		PLUME TYPE: CONTINUOUS								
		FUGITIVE INTERMITTENT								
WATER DROPLETS PRESENT <input checked="" type="checkbox"/> YES		IF WATER DROPLET PLUME: ATTACHED DETACHED								
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <b>ROOF MONITOR</b> STOP <b>ROOF MONITOR</b>										
DESCRIBE BACKGROUND START <b>Mostly Cloudy Sky</b> STOP <b>Cloudy Sky</b>										
BACKGROUND COLOR START <b>Gray</b> STOP <b>Gray</b>		SKY CONDITIONS START <b>Cloudy</b> STOP <b>Cloudy</b>								
WIND SPEED (MPH) START <b>5</b> STOP <b>5</b>		WIND DIRECTION START <b>E</b> STOP <b>E</b>								
AMBIENT TEMPERATURE (F) START <b>85</b> STOP <b>85</b>		WET BULB TEMP		REL. HUMIDITY						

AVERAGE OPACITY FOR HIGHEST PERIOD <b>0</b>		NUMBER OF READINGS ABOVE WERE <b>0</b>	
RANGE OF OPACITY READINGS MINIMUM <b>0</b> MAXIMUM <b>0</b>			
OBSERVER'S NAME (PRINT) <b>CARLOS BROWN</b>			
OBSERVER'S SIGNATURE <i>[Signature]</i>		DATE <b>05-21-04</b>	
ORGANIZATION <b>ATP - Air Test Professionals, Inc.</b>			
CERTIFIED BY <i>[Signature]</i>		DATE	
Comments:			



X = Emission Point  
 = Observer's Position  
 = Sun  
 = Wind  
 = Plume




Visible Emissions Observations Form

RUN NUMBER

3 C

SOURCE NAME <b>NUCOR STEEL</b>		OBSERVATION DATE <b>05-21-04</b>		START TIME <b>1524</b>		STOP TIME <b>1624</b>	
ADDRESS		sec				sec	
CITY <b>Chattanooga TN</b>		min	0	15	30	45	min
STATE <b>TN</b>		0	0	0	0	0	31
ZIP		1	0	0	0	0	0
PHONE		2	0	0	0	0	32
SOURCE ID NUMBER		3	0	0	0	0	33
PROCESS EQUIPMENT <b>EAF'S &amp; AOD</b>		4	0	0	0	0	34
OPERATING MODE <b>NORMAL</b>		5	0	0	0	0	35
CONTROL EQUIPMENT <b>BATHHOUSE - WEST</b>		6	0	0	0	0	36
OPERATING MODE <b>NORMAL</b>		7	0	0	0	0	37
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>Roof Monitors</b>		8	0	0	0	0	38
HEIGHT ABOVE GROUND LEVEL START <b>75'</b> STOP <b>75'</b>		9	0	0	0	0	39
HEIGHT RELATIVE TO OBSERVER START <b>75'</b> STOP <b>75'</b>		10	0	0	0	0	40
DISTANCE FROM OBSERVER START <b>200 yd</b> STOP <b>200 yd</b>		11	0	0	0	0	41
DIRECTION FROM OBSERVER START <b>NE</b> STOP <b>NE</b>		12	0	0	0	0	42
DESCRIBE EMISSIONS START <b>N/A</b> STOP <b>N/A</b>		13	0	0	0	0	43
EMISSION COLOR START <b>N/A</b> STOP <b>N/A</b>		14	0	0	0	0	44
PLUME TYPE: CONTINUOUS START <b>N/A</b> STOP <b>N/A</b>		15	0	0	0	0	45
FUGITIVE: INTERMITTENT		16	0	0	0	0	46
WATER DROPLETS PRESENT <b>(NO)</b> YES		17	0	0	0	0	47
IF WATER DROPLET PLUME: ATTACHED DETACHED		18	0	0	0	0	48
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <b>ROOF MONITORS</b> STOP <b>ROOF MONITORS</b>		19	0	0	0	0	49
DESCRIBE BACKGROUND START <b>Cloudy</b> STOP <b>Cloudy</b>		20	0	0	0	0	50
BACKGROUND COLOR START <b>Gray</b> STOP <b>Gray</b>		21	0	0	0	0	51
SKY CONDITIONS START <b>Cloudy</b> STOP <b>Cloudy</b>		22	0	0	0	0	52
WIND SPEED (MPH) START <b>5</b> STOP <b>5</b>		23	0	0	0	0	53
WIND DIRECTION START <b>E</b> STOP <b>E</b>		24	0	0	0	0	54
AMBIENT TEMPERATURE (F) START <b>85</b> STOP <b>85</b>		25	0	0	0	0	55
WET BULB TEMP. REL. HUMIDITY		26	0	0	0	0	56
SOURCE LAYOUT SKETCH		27	0	0	0	0	57
Draw North Arrow		28	0	0	0	0	58
X Emission Point		29	0	0	0	0	59
Observer's Position		30	0	0	0	0	60
140		AVERAGE OPACITY FOR HIGHEST PERIOD		NUMBER OF READINGS ABOVE WERE			
SUN LOCATION LINE		MINIMUM		MAXIMUM			
		OBSERVER'S NAME (PRINT)		OBSERVER'S SIGNATURE		DATE	
		ORGANIZATION		CERTIFIED BY		DATE	
		Comments:					



- X = Emission Point
- = Observer's Position
- ☀ = Sun
- = Wind
- = Plume

AVERAGE OPACITY FOR HIGHEST PERIOD: 0

NUMBER OF READINGS ABOVE WERE: 0

RANGE OF OPACITY READINGS: MINIMUM 0, MAXIMUM 0

OBSERVER'S NAME (PRINT): CARLOS BROWN

OBSERVER'S SIGNATURE: [Signature]

DATE: 05-21-04

ORGANIZATION: ATP - Air Test Professionals, Inc.

CERTIFIED BY: [Signature]

DATE: [Blank]

Comments:

Visible Emissions Observations Form

RUN NUMBER

30

SOURCE NAME NUCON STEEL

OBSERVATION DATE 05 - 21 - 04

START TIME 1524

STOP TIME 1624

ADDRESS

sec					sec				
min	0	15	30	45	min	0	15	30	45

CITY CRAWFORDSVILLE

STATE IN

ZIP

1	0	0	0	0	31	0	0	0	0
2	0	0	0	0	32	0	0	0	0

PHONE

SOURCE ID NUMBER

3	0	0	0	0	33	0	0	0	0
4	0	0	0	0	34	0	0	0	0

PROCESS EQUIPMENT EAP'S & AOD

OPERATING MODE NORMAL

5	0	0	0	0	35	0	0	0	0
6	0	0	0	0	36	0	0	0	0

CONTROL EQUIPMENT Boilerhouse - EAST

OPERATING MODE NORMAL

7	0	0	0	0	37	0	0	0	0
8	0	0	0	0	38	0	0	0	0

DESCRIBE EMISSION POINT (Stack Exit Dimensions)  
ROOF MONITORS

9	0	0	0	0	39	0	0	0	0
10	0	0	0	0	40	0	0	0	0

HEIGHT ABOVE GROUND LEVEL  
START 75' STOP 75'

HEIGHT RELATIVE TO OBSERVER  
START 75' STOP 75'

11	0	0	0	0	41	0	0	0	0
12	0	0	0	0	42	0	0	0	0

DISTANCE FROM OBSERVER  
START 200yd STOP 200yd

DIRECTION FROM OBSERVER  
START NE STOP NE

13	0	0	0	0	43	0	0	0	0
14	0	0	0	0	44	0	0	0	0

DESCRIBE EMISSIONS  
START N/A STOP N/A

15	0	0	0	0	45	0	0	0	0
16	0	0	0	0	46	0	0	0	0

EMISSION COLOR  
START N/A STOP N/A

PLUME TYPE: CONTINUOUS  
FUGITIVE INTERMITTENT

17	0	0	0	0	47	0	0	0	0
18	0	0	0	0	48	0	0	0	0

WATER DROPLETS PRESENT  
 NO  YES

IF WATER DROPLET PLUME:  
 ATTACHED  DETACHED

19	0	0	0	0	49	0	0	0	0
20	0	0	0	0	50	0	0	0	0

POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED  
START ROOF MONITOR STOP ROOF MONITOR

21	0	0	0	0	51	0	0	0	0
22	0	0	0	0	52	0	0	0	0

DESCRIBE BACKGROUND  
START Cloudy STOP Cloudy

23	0	0	0	0	53	0	0	0	0
24	0	0	0	0	54	0	0	0	0

BACKGROUND COLOR  
START Gray STOP Gray

SKY CONDITIONS  
START Cloudy STOP Cloudy

25	0	0	0	0	55	0	0	0	0
26	0	0	0	0	56	0	0	0	0

WIND SPEED (MPH)  
START 5 STOP 5


WIND DIRECTION  
START E STOP E

27	0	0	0	0	57	0	0	0	0
28	0	0	0	0	58	0	0	0	0

AMBIENT TEMPERATURE (F)  
START 85 STOP 85

WET BULB TEMPERATURE PERCENT

29	0	0	0	0	59	0	0	0	0
30	0	0	0	0	60	0	0	0	0



AVERAGE OPACITY FOR HIGHEST PERIOD 0 NUMBER OF READINGS ABOVE 0 WERE 0

RANGE OF OPACITY READINGS  
MINIMUM 0 MAXIMUM 0

OBSERVER'S NAME (PRINT) Carlos Brown

OBSERVER'S SIGNATURE [Signature] DATE 05 - 21 - 04

ORGANIZATION ATP - Air Test Professionals, Inc.

CERTIFIED BY Carl Koontz DATE


Comments:

- X = Emission Point
- Observer's Position
- Sun
- Wind
- Plume

Visible Emissions Observations Form

RUN NUMBER 3 D

SOURCE NAME <b>NICOR STEEL</b>		OBSERVATION DATE <b>05-21-04</b>				START TIME <b>1625</b>		STOP TIME <b>1725</b>	
ADDRESS		sec				sec			
CITY <b>CRAWFORDVILLE</b>		min	0	15	30	45	min	0	15
STATE <b>IN</b>		1	0	0	0	0	31	0	0
ZIP		2	0	0	0	0	32	0	0
PHONE		3	0	0	0	0	33	0	0
SOURCE ID NUMBER		4	0	0	0	0	34	0	0
PROCESS EQUIPMENT <b>ERF's &amp; AOD</b>		5	0	0	0	0	35	0	0
OPERATING MODE <b>NORMAL</b>		6	0	0	0	0	36	0	0
CONTROL EQUIPMENT <b>BAGHOUSE - EAST</b>		7	0	0	0	0	37	0	0
OPERATING MODE <b>NORMAL</b>		8	0	0	0	0	38	0	0
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>ROOF MONITORS</b>		9	0	0	0	0	39	0	0
HEIGHT ABOVE GROUND LEVEL		10	0	0	0	0	40	0	0
START <b>75'</b> STOP <b>75'</b>		11	0	0	0	0	41	0	0
HEIGHT RELATIVE TO OBSERVER		12	0	0	0	0	42	0	0
START <b>75'</b> STOP <b>75'</b>		13	0	0	0	0	43	0	0
DISTANCE FROM OBSERVER		14	0	0	0	0	44	0	0
START <b>200 yd</b> STOP <b>200 yd</b>		15	0	0	0	0	45	0	0
DIRECTION FROM OBSERVER		16	0	0	0	0	46	0	0
START <b>NE</b> STOP <b>NE</b>		17	0	0	0	0	47	0	0
DESCRIBE EMISSIONS		18	0	0	0	0	48	0	0
START <b>N/A</b> STOP <b>N/A</b>		19	0	0	0	0	49	0	0
EMISSION COLOR		20	0	0	0	0	50	0	0
START <b>N/A</b> STOP <b>N/A</b>		21	0	0	0	0	51	0	0
PLUME TYPE CONTINUOUS		22	0	0	0	0	52	0	0
FUGITIVE INTERMITTENT		23	0	0	0	0	53	0	0
WATER DROPLETS PRESENT		24	0	0	0	0	54	0	0
<input checked="" type="radio"/> YES		25	0	0	0	0	55	0	0
IF WATER DROPLET PLUME:		26	0	0	0	0	56	0	0
ATTACHED DETACHED		27	0	0	0	0	57	0	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED		28	0	0	0	0	58	0	0
START <b>ROOF MONITORS</b> STOP <b>ROOF MONITORS</b>		29	0	0	0	0	59	0	0
DESCRIBE BACKGROUND		30	0	0	0	0	60	0	0
START <b>Cloudy</b> STOP <b>Cloudy</b>									
BACKGROUND COLOR									
START <b>GRAY</b> STOP <b>GRAY</b>									
SKY CONDITIONS									
START <b>Cloudy</b> STOP <b>Cloudy</b>									
WIND SPEED (MPH)									
START <b>5</b> STOP <b>5</b>									
WIND DIRECTION									
START <b>E</b> STOP <b>E</b>									
AMBIENT TEMPERATURE (F)									
START <b>82</b> STOP <b>82</b>									



AVERAGE OPACITY FOR HIGHEST PERIOD 0

NUMBER OF READINGS ABOVE WERE 0

RANGE OF OPACITY READINGS

MINIMUM 0 MAXIMUM 0

OBSERVER'S NAME (PRINT) **ARLYN BROWN**

OBSERVER'S SIGNATURE *[Signature]* DATE **05-21-04**

ORGANIZATION **ATP - Air Test Professionals, Inc.**

CERTIFIED BY **ARL KOEHLER** DATE


Comments:

- X = Emission Point
- Observer's Position
- Sun
- Wind
- Plume

Visible Emissions Observations Form

RUN NUMBER 3D

SOURCE NAME <b>NIPER STEEL</b>			OBSERVATION DATE <b>05-21-04</b>				START TIME <b>1625</b>		STOP TIME <b>1725</b>	
ADDRESS			sec				sec			
CITY <b>Crawfordsville</b>			min	0	15	30	45	min	0	
STATE <b>IN</b>			1	0	0	0	0	31	0	
ZIP			2	0	0	0	0	32	0	
PHONE			3	0	0	0	0	33	0	
SOURCE ID NUMBER			4	0	0	0	0	34	0	
PROCESS EQUIPMENT <b>EAF'S &amp; ADD</b>			5	0	0	0	0	35	0	
OPERATING MODE <b>NORMAL</b>			6	0	0	0	0	36	0	
CONTROL EQUIPMENT <b>BAGHOUSE - WEST</b>			7	0	0	0	0	37	0	
OPERATING MODE <b>NORMAL</b>			8	0	0	0	0	38	0	
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>ROOF MONITORS</b>			9	0	0	0	0	39	0	
HEIGHT ABOVE GROUND LEVEL START <b>75'</b> STOP <b>75'</b>			10	0	0	0	0	40	0	
HEIGHT RELATIVE TO OBSERVER START <b>75'</b> STOP <b>75'</b>			11	0	0	0	0	41	0	
DISTANCE FROM OBSERVER START <b>200 YD</b> STOP <b>200 YD</b>			12	0	0	0	0	42	0	
DIRECTION FROM OBSERVER START <b>NE</b> STOP <b>NE</b>			13	0	0	0	0	43	0	
DESCRIBE EMISSIONS START <b>N/A</b> STOP <b>N/A</b>			14	0	0	0	0	44	0	
EMISSION COLOR START <b>N/A</b> STOP <b>N/A</b>			15	0	0	0	0	45	0	
PLUME TYPE: CONTINUOUS			16	0	0	0	0	46	0	
FUGITIVE INTERMITTENT			17	0	0	0	0	47	0	
WATER DROPLETS PRESENT <input checked="" type="checkbox"/> YES			18	0	0	0	0	48	0	
IF WATER DROPLET PLUME: ATTACHED DETACHED			19	0	0	0	0	49	0	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <b>ROOF MONITORS</b> STOP <b>ROOF MONITORS</b>			20	0	0	0	0	50	0	
DESCRIBE BACKGROUND START <b>Cloudy</b> STOP <b>Cloudy</b>			21	0	0	0	0	51	0	
BACKGROUND COLOR START <b>GRAY</b> STOP <b>GRAY</b>			22	0	0	0	0	52	0	
SKY CONDITIONS START <b>Cloudy</b> STOP <b>Cloudy</b>			23	0	0	0	0	53	0	
WIND SPEED (MPH) START <b>5</b> STOP <b>5</b>			24	0	0	0	0	54	0	
WIND DIRECTION START <b>E</b> STOP <b>E</b>			25	0	0	0	0	55	0	
AMBIENT TEMPERATURE (F) START <b>82</b> STOP <b>82</b>			26	0	0	0	0	56	0	
WET BULB TEMP. RH PERCENT			27	0	0	0	0	57	0	
			28	0	0	0	0	58	0	
			29	0	0	0	0	59	0	
			30	0	0	0	0	60	0	



AVERAGE OPACITY FOR HIGHEST PERIOD: 0

NUMBER OF READINGS ABOVE WERE: 0

RANGE OF OPACITY READINGS: MINIMUM 0, MAXIMUM 0

OBSERVER'S NAME (PRINT): **CARLOS BROWN**

OBSERVER'S SIGNATURE: *[Signature]* DATE: **05-21-04**

ORGANIZATION: **ATP - Air Test Professionals, Inc.**

CERTIFIED BY: *[Signature]* DATE:


Comments:

- X = Emission Point
- = Observer's Position
- ☀ = Sun
- = Wind
- = Plume

Visible Emissions Observations Form

RUN NUMBER 1-A

SOURCE NAME <b>Nucor Steel</b>		OBSERVATION DATE <b>5/19/04</b>				START TIME <b>3:59 PM</b>		STOP TIME <b>4:59 PM</b>			
ADDRESS <b>4537 S. Nucor Rd.</b>		sec				sec					
CITY <b>Crawfordsville</b>	STATE <b>IN</b>	min	0	15	30	45	min	0	15	30	45
PHONE <b>765-364-1373</b>	SOURCE ID NUMBER <b>00078</b>	1	0	0	0	0	31	0	0	0	0
PROCESS EQUIPMENT <b>Old Silo Bin Vent</b>	OPERATING MODE <b>Run</b>	2	0	0	0	0	32	0	0	0	0
CONTROL EQUIPMENT <b>Bin Vent</b>	OPERATING MODE <b>Run</b>	3	0	0	0	0	33	0	0	0	0
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>Bin Vent Port</b>		4	0	0	0	0	34	0	0	0	0
HEIGHT ABOVE GROUND LEVEL START <b>80ft</b> STOP <b>80ft</b>	HEIGHT RELATIVE TO OBSERVER START <b>75ft</b> STOP <b>75ft</b>	5	0	0	0	0	35	0	0	0	0
DISTANCE FROM OBSERVER START <b>150ft</b> STOP <b>150ft</b>	DIRECTION FROM OBSERVER START <b>SE</b> STOP <b>SE</b>	6	0	0	0	0	36	0	0	0	0
DESCRIBE EMISSIONS START <b>None</b> STOP <b>None</b>		7	0	0	0	0	37	0	0	0	0
EMISSION COLOR START <b>—</b> STOP <b>—</b>	PLUME TYPE: CONTINUOUS FUGITIVE INTERMITTENT	8	0	0	0	0	38	0	0	0	0
WATER DROPLETS PRESENT NO <b>NA</b> YES	IF WATER DROPLET PLUME: ATTACHED <b>NA</b> DETACHED	9	0	0	0	0	39	0	0	0	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START STOP		10	0	0	0	0	40	0	0	0	0
DESCRIBE BACKGROUND START <b>SKY</b> STOP <b>SKY</b>		11	0	0	0	0	41	0	0	0	0
BACKGROUND COLOR START <b>Gray</b> STOP <b>Gray</b>	SKY CONDITIONS START <b>Cloudy</b> STOP <b>Cloudy</b>	12	0	0	0	0	42	0	0	0	0
WIND SPEED (MPH) START <b>10-15</b> STOP <b>10-15</b>	WIND DIRECTION START <b>SW</b> STOP <b>SW</b>	13	0	0	0	0	43	0	0	0	0
AMBIENT TEMPERATURE (F) START <b>80</b> STOP <b>80</b>	WET BULB TEMP. REL. HUMIDITY	14	0	0	0	0	44	0	0	0	0
SOURCE LAYOUT SKETCH	Draw North Arrow	15	0	0	0	0	45	0	0	0	0
		16	0	0	0	0	46	0	0	0	0
		17	0	0	0	0	47	0	0	0	0
		18	0	0	0	0	48	0	0	0	0
		19	0	0	0	0	49	0	0	0	0
		20	0	0	0	0	50	0	0	0	0
		21	0	0	0	0	51	0	0	0	0
		22	0	0	0	0	52	0	0	0	0
		23	0	0	0	0	53	0	0	0	0
		24	0	0	0	0	54	0	0	0	0
		25	0	0	0	0	55	0	0	0	0
		26	0	0	0	0	56	0	0	0	0
		27	0	0	0	0	57	0	0	0	0
		28	0	0	0	0	58	0	0	0	0
		29	0	0	0	0	59	0	0	0	0
		30	0	0	0	0	60	0	0	0	0



AVERAGE OPACITY FOR HIGHEST PERIOD **0**

NUMBER OF READINGS ABOVE WERE

RANGE OF OPACITY READINGS

MINIMUM MAXIMUM

OBSERVER'S NAME (PRINT) **Rex Kelsey**

OBSERVER'S SIGNATURE **Rex Kelsey** DATE **5/19/04**

ORGANIZATION **ATP - Air Test Professionals, Inc.**

CERTIFIED BY **Carl Koontz** DATE **3/18/04**

Comments:

- X = Emission Point
- Observer's Position
- Sun
- Wind
- Plume

Visible Emissions Observations Form

RUN NUMBER

1-B

SOURCE NAME  
Nucor Steel

OBSERVATION DATE  
5/19/04

START TIME  
3:59 PM

STOP TIME  
4:59 PM

ADDRESS  
4537 S, Nucor Rd.

sec	0	15	30	45	sec	0	15	30	45
1	0	0	0	0	31	0	0	0	0
2	0	0	0	0	32	0	0	0	0
3	0	0	0	0	33	0	0	0	0
4	0	0	0	0	34	0	0	0	0
5	0	0	0	0	35	0	0	0	0
6	0	0	0	0	36	0	0	0	0
7	0	0	0	0	37	0	0	0	0
8	0	0	0	0	38	0	0	0	0
9	0	0	0	0	39	0	0	0	0
10	0	0	0	0	40	0	0	0	0
11	0	0	0	0	41	0	0	0	0
12	0	0	0	0	42	0	0	0	0
13	0	0	0	0	43	0	0	0	0
14	0	0	0	0	44	0	0	0	0
15	0	0	0	0	45	0	0	0	0
16	0	0	0	0	46	0	0	0	0
17	0	0	0	0	47	0	0	0	0
18	0	0	0	0	48	0	0	0	0
19	0	0	0	0	49	0	0	0	0
20	0	0	0	0	50	0	0	0	0
21	0	0	0	0	51	0	0	0	0
22	0	0	0	0	52	0	0	0	0
23	0	0	0	0	53	0	0	0	0
24	0	0	0	0	54	0	0	0	0
25	0	0	0	0	55	0	0	0	0
26	0	0	0	0	56	0	0	0	0
27	0	0	0	0	57	0	0	0	0
28	0	0	0	0	58	0	0	0	0
29	0	0	0	0	59	0	0	0	0
30	0	0	0	0	60	0	0	0	0

CITY  
Crawfordsville

STATE  
IN

ZIP  
47933

PHONE  
765-364-1323

SOURCE ID NUMBER  
00038

PROCESS EQUIPMENT  
New Silo Bin Vent

OPERATING MODE  
Run

CONTROL EQUIPMENT  
Bin Vent

OPERATING MODE  
Run

DESCRIBE EMISSION POINT (Stack Exit Dimensions)  
Bin Vent Port

HEIGHT ABOVE GROUND LEVEL  
START 75ft STOP 75ft

HEIGHT RELATIVE TO OBSERVER  
START 75ft STOP 75ft

DISTANCE FROM OBSERVER  
START 200ft STOP 200ft

DIRECTION FROM OBSERVER  
START SE STOP SE

DESCRIBE EMISSIONS  
START None STOP None

EMISSION COLOR  
START - STOP -

PLUME TYPE: CONTINUOUS  
FUGITIVE INTERMITTENT

WATER DROPLETS PRESENT  
NO N/A YES

IF WATER DROPLET PLUME:  
ATTACHED N/A DETACHED

POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED  
START STOP

DESCRIBE BACKGROUND  
START Broken Sky STOP Sky

BACKGROUND COLOR  
START Blue/White STOP Blue/White


SKY CONDITION  
START Broken STOP Broken

WIND SPEED (MPH)  
START 10-15 STOP 10-15

WIND DIRECTION  
START S STOP S

AMBIENT TEMPERATURE (F)  
START 80 STOP 80

WET BULB TEMP / RH PERCENT



AVERAGE OPACITY FOR HIGHEST PERIOD 0

NUMBER OF READINGS ABOVE WERE

RANGE OF OPACITY READINGS

MINIMUM MAXIMUM

OBSERVER'S NAME (PRINT)  
Rex Kelsey

OBSERVER'S SIGNATURE  
Rex Kelsey

DATE  
5/19/04

ORGANIZATION  
ATP - Air Test Professionals, Inc.

CERTIFIED BY  
Carl Koontz

DATE  
3/18/04

Comments:

- X = Emission Point
- Observer's Position
- Sun
- Wind
- Plume

Visible Emissions Observations Form

RUN NUMBER

2 - A

SOURCE NAME  
Nacor Steel

OBSERVATION DATE  
5/21/04

START TIME  
7:22 AM

STOP TIME  
8:22 AM

ADDRESS  
4537 South Nacor Rd

sec					sec				
min	0	15	30	45	min	0	15	30	45

CITY  
Crawfordsville

STATE  
IN

ZIP  
47937

1	0	0	0	0	31	0	0	0	0
2	0	0	0	0	32	0	0	0	0

PHONE  
765-364-1377

SOURCE ID NUMBER  
00038

3	0	0	0	0	33	0	0	0	0
4	0	0	0	0	34	0	0	0	0

PROCESS EQUIPMENT  
Bin Vent

OPERATING MODE  
Run

5	0	0	0	0	35	0	0	0	0
6	0	0	0	0	36	0	0	0	0

CONTROL EQUIPMENT  
Bin vent old silo

OPERATING MODE  
Run

7	0	0	0	0	37	0	0	0	0
8	0	0	0	0	38	0	0	0	0

DESCRIBE EMISSION POINT (Stack Exit Dimensions)  
Vent Port on Bin Vent

9	0	0	0	0	39	0	0	0	0
10	0	0	0	0	40	0	0	0	0

HEIGHT ABOVE GROUND LEVEL  
START 75 STOP 75

HEIGHT RELATIVE TO OBSERVER  
START 75 STOP 75

11	0	0	0	0	41	0	0	0	0
12	0	0	0	0	42	0	0	0	0

DISTANCE FROM OBSERVER  
START 200ft STOP 200ft

DIRECTION FROM OBSERVER  
START S STOP S

13	0	0	0	0	43	0	0	0	0
14	0	0	0	0	44	0	0	0	0

DESCRIBE EMISSIONS  
START STOP

15	0	0	0	0	45	0	0	0	0
16	0	0	0	0	46	0	0	0	0

EMISSION COLOR  
START STOP

PLUME TYPE: CONTINUOUS  
FUGITIVE INTERMITTENT

17	0	0	0	0	47	0	0	0	0
18	0	0	0	0	48	0	0	0	0

WATER DROPLETS PRESENT  
NO NA YES NA

IF WATER DROPLET PLUME:  
ATTACHED NA DETACHED

19	0	0	0	0	49	0	0	0	0
20	0	0	0	0	50	0	0	0	0

POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED  
START Bin Vent Port STOP Bin Vent Port

21	0	0	0	0	51	0	0	0	0
22	0	0	0	0	52	0	0	0	0

DESCRIBE BACKGROUND  
START Sky STOP Sky

23	0	0	0	0	53	0	0	0	0
24	0	0	0	0	54	0	0	0	0

BACKGROUND COLOR  
START Gray STOP Gray

SKY CONDITIONS  
START Cloudy STOP Cloudy

25	0	0	0	0	55	0	0	0	0
26	0	0	0	0	56	0	0	0	0

WIND SPEED (MPH)  
START 10-15 STOP 10-15


WIND DIRECTION  
START SW STOP SW

27	0	0	0	0	57	0	0	0	0
28	0	0	0	0	58	0	0	0	0

AMBIENT TEMPERATURE (F)  
START 70 STOP 70

WET BULB TEMP  
REL. HUMIDITY

29	0	0	0	0	59	0	0	0	0
30	0	0	0	0	60	0	0	0	0



AVERAGE OPACITY FOR HIGHEST PERIOD 0

NUMBER OF READINGS ABOVE WERE

RANGE OF OPACITY READINGS MINIMUM MAXIMUM

OBSERVER'S NAME (PRINT)  
Rex Kelsey

OBSERVER'S SIGNATURE  
Rex Kelsey

DATE  
5/21/04

ORGANIZATION  
Nacor Steel

CERTIFIED BY  
Carl Koontz

DATE  
3/18/04

Comments:

- X = Emission Point
- Observer's Position
- Sun
- Wind
- Plume

Visible Emissions Observations Form

RUN NUMBER 2-B

SOURCE NAME Nucor Steel

OBSERVATION DATE 5/21/04

START TIME 7:22 AM

STOP TIME 8:22 AM

ADDRESS 4537 South Nucor Rd

sec	0	15	30	45	sec	0	15	30	45
1	0	0	0	0	31	0	0	0	0
2	0	0	0	0	32	0	0	0	0
3	0	0	0	0	33	0	0	0	0
4	0	0	0	0	34	0	0	0	0
5	0	0	0	0	35	0	0	0	0
6	0	0	0	0	36	0	0	0	0
7	0	0	0	0	37	0	0	0	0
8	0	0	0	0	38	0	0	0	0
9	0	0	0	0	39	0	0	0	0
10	0	0	0	0	40	0	0	0	0
11	0	0	0	0	41	0	0	0	0
12	0	0	0	0	42	0	0	0	0
13	0	0	0	0	43	0	0	0	0
14	0	0	0	0	44	0	0	0	0
15	0	0	0	0	45	0	0	0	0
16	0	0	0	0	46	0	0	0	0
17	0	0	0	0	47	0	0	0	0
18	0	0	0	0	48	0	0	0	0
19	0	0	0	0	49	0	0	0	0
20	0	0	0	0	50	0	0	0	0
21	0	0	0	0	51	0	0	0	0
22	0	0	0	0	52	0	0	0	0
23	0	0	0	0	53	0	0	0	0
24	0	0	0	0	54	0	0	0	0
25	0	0	0	0	55	0	0	0	0
26	0	0	0	0	56	0	0	0	0
27	0	0	0	0	57	0	0	0	0
28	0	0	0	0	58	0	0	0	0
29	0	0	0	0	59	0	0	0	0
30	0	0	0	0	60	0	0	0	0

CITY Crawfordsville

STATE IN

ZIP 47933

PHONE 765-364-1323

SOURCE ID NUMBER 00038

PROCESS EQUIPMENT Bin Vent

OPERATING MODE Run

CONTROL EQUIPMENT Bin Vent New Silo

OPERATING MODE Run

DESCRIBE EMISSION POINT (Stack Exit Dimensions) Vent Port on Bin Vent

HEIGHT ABOVE GROUND LEVEL START 80 STOP 80

HEIGHT RELATIVE TO OBSERVER START 80 STOP 80

DISTANCE FROM OBSERVER START 150FT STOP 150FT

DIRECTION FROM OBSERVER START S STOP S

DESCRIBE EMISSIONS START STOP

EMISSION COLOR START STOP

PLUME TYPE: CONTINUOUS FUGITIVE INTERMITTENT

WATER DROPLETS PRESENT NO N/A YES N/A

IF WATER DROPLET PLUME: ATTACHED N/A DETACHED

POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START Bin Vent Port STOP Bin Vent Port

DESCRIBE BACKGROUND START Sky STOP Sky

BACKGROUND COLOR START Gray STOP Gray


SKY CONDITIONS START Cloudy STOP Cloudy

WIND SPEED (MPH) START 10-15 STOP 10-15

WIND DIRECTION START SW STOP SW

AMBIENT TEMPERATURE (F) START 70 STOP 70

WET BULB TEMP. REL. HUMIDITY



AVERAGE OPACITY FOR HIGHEST PERIOD 0

NUMBER OF READINGS ABOVE WERE

RANGE OF OPACITY READINGS MINIMUM MAXIMUM

OBSERVER'S NAME (PRINT) Rex Kelsey

OBSERVER'S SIGNATURE Rex Kelsey

DATE 5/21/04

ORGANIZATION Nucor Steel

CERTIFIED BY Carl Koontz

DATE 3/18/04

Comments:


- X = Emission Point
- = Observer's Position
- ☀ = Sun
- = Wind
- = Plume



Visible Emissions Observations Form

RUN NUMBER 3-A

SOURCE NAME <b>Nucor Steel</b>			OBSERVATION DATE <b>5/21/04</b>				START TIME <b>1:10 PM</b>		STOP TIME <b>2:10 PM</b>			
ADDRESS <b>4537 South Nucor Road</b>			sec				sec					
CITY <b>Crawfordsville</b>	STATE <b>IN</b>	ZIP <b>47933</b>	min	0	15	30	45	min	0	15	30	45
PHONE <b>765-364-1323</b>	SOURCE ID NUMBER <b>00038</b>		1	0	0	0	0	31	0	0	0	0
PROCESS EQUIPMENT <b>Bin Vent</b>	OPERATING MODE <b>Run</b>		2	0	0	0	0	32	0	0	0	0
CONTROL EQUIPMENT <b>Bin Ken New Silo</b>	OPERATING MODE <b>Run</b>		3	0	0	0	0	33	0	0	0	0
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>Vent Port on Bin Vent</b>			4	0	0	0	0	34	0	0	0	0
HEIGHT ABOVE GROUND LEVEL START <b>80</b> STOP <b>80</b>	HEIGHT RELATIVE TO OBSERVER START <b>80</b> STOP <b>80</b>		5	0	0	0	0	35	0	0	0	0
DISTANCE FROM OBSERVER START <b>150ft</b> STOP <b>150ft</b>	DIRECTION FROM OBSERVER START <b>S</b> STOP <b>S</b>		6	0	0	0	0	36	0	0	0	0
DESCRIBE EMISSIONS START _____ STOP _____			7	0	0	0	0	37	0	0	0	0
EMISSION COLOR START _____ STOP _____	PLUME TYPE: CONTINUOUS FUGITIVE INTERMITTENT		8	0	0	0	0	38	0	0	0	0
WATER DROPLETS PRESENT NO <b>N/A</b> YES <b>N/A</b>	IF WATER DROPLET PLUME: ATTACHED <b>N/A</b> DETACHED		9	0	0	0	0	39	0	0	0	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <b>Bin Vent Port</b> STOP <b>Bin Vent Port</b>			10	0	0	0	0	40	0	0	0	0
DESCRIBE BACKGROUND START <b>sky</b> STOP <b>sky</b>			11	0	0	0	0	41	0	0	0	0
BACKGROUND COLOR START <b>white</b> STOP _____	SKY CONDITIONS START <b>cloudy</b> STOP <b>cloudy</b>		12	0	0	0	0	42	0	0	0	0
WIND SPEED (MPH) START <b>10-15</b> STOP _____	WIND DIRECTION START <b>SW</b> STOP _____		13	0	0	0	0	43	0	0	0	0
AMBIENT TEMPERATURE (F) START <b>8.5</b> STOP _____	WET BULB TEMP. R.A. PERCENT		14	0	0	0	0	44	0	0	0	0
SOURCE LAYOUT SKETCH	Draw North Arrow		15	0	0	0	0	45	0	0	0	0




AVERAGE OPACITY FOR HIGHEST PERIOD		NUMBER OF READINGS ABOVE WERE	
RANGE OF OPACITY READINGS			
MINIMUM		MAXIMUM	
OBSERVER'S NAME (PRINT) <b>Rex Kelsey</b>			
OBSERVER'S SIGNATURE <i>Rex Kelsey</i>		DATE <b>5/21/04</b>	
ORGANIZATION <b>ATP - Air Test Professionals, Inc.</b>			
CERTIFIED BY <b>Carl Koontz</b>		DATE <b>3/18/04</b>	
Comments:			

- X = Emission Point
- = Observer's Position
- ☀ = Sun
- = Wind
- = Plume

Visible Emissions Observations Form

RUN NUMBER 3-B

SOURCE NAME <i>Nucor steel</i>			OBSERVATION DATE - -				START TIME <i>1:10 PM</i>		STOP TIME <i>2:10 PM</i>	
ADDRESS <i>4537 South Nucor Road</i>			sec				sec			
CITY <i>Crawfordsville</i>			min	0	15	30	45	min	0	
STATE <i>IN</i>			1	0	0	0	0	31	0	
ZIP <i>47933</i>			2	0	0	0	0	32	0	
PHONE <i>765-364-1327</i>			3	0	0	0	0	33	0	
SOURCE ID NUMBER <i>00038</i>			4	0	0	0	0	34	0	
PROCESS EQUIPMENT <i>Bin Vent</i>			5	0	0	0	0	35	0	
OPERATING MODE <i>Run</i>			6	0	0	0	0	36	0	
CONTROL EQUIPMENT <i>Bin Vent on old Silo</i>			7	0	0	0	0	37	0	
OPERATING MODE <i>Run</i>			8	0	0	0	0	38	0	
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <i>Vent Part on Bin Vent</i>			9	0	0	0	0	39	0	
HEIGHT ABOVE GROUND LEVEL START <i>75</i> STOP <i>75</i>			10	0	0	0	0	40	0	
HEIGHT RELATIVE TO OBSERVER START <i>75</i> STOP <i>75</i>			11	0	0	0	0	41	0	
DISTANCE FROM OBSERVER START <i>200</i> STOP <i>200</i>			12	0	0	0	0	42	0	
DIRECTION FROM OBSERVER START <i>S</i> STOP <i>S</i>			13	0	0	0	0	43	0	
DESCRIBE EMISSIONS START <i>-</i> STOP <i>-</i>			14	0	0	0	0	44	0	
EMISSION COLOR START <i>-</i> STOP <i>-</i>			15	0	0	0	0	45	0	
PLUME TYPE: CONTINUOUS FUGITIVE INTERMITTENT			16	0	0	0	0	46	0	
WATER DROPLETS PRESENT NO <i>NA</i> YES <i>N/A</i>			17	0	0	0	0	47	0	
IF WATER DROPLET PLUME: ATTACHED <i>N/A</i> DETACHED			18	0	0	0	0	48	0	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <i>Bin Vent Part</i> STOP <i>Bin Vent Part</i>			19	0	0	0	0	49	0	
DESCRIBE BACKGROUND START <i>SKY</i> STOP <i>SKY</i>			20	0	0	0	0	50	0	
BACKGROUND COLOR START <i>White</i> STOP			21	0	0	0	0	51	0	
SKY CONDITIONS START <i>Cloudy</i> STOP			22	0	0	0	0	52	0	
WIND SPEED (MPH) START <i>10-15</i> STOP			23	0	0	0	0	53	0	
WIND DIRECTION START <i>7W</i> STOP			24	0	0	0	0	54	0	
AMBIENT TEMPERATURE (F) START <i>85</i> STOP			25	0	0	0	0	55	0	
WET BULB TEMP			26	0	0	0	0	56	0	
REL. HUMIDITY			27	0	0	0	0	57	0	
			28	0	0	0	0	58	0	
			29	0	0	0	0	59	0	
			30	0	0	0	0	60	0	



AVERAGE OPACITY FOR HIGHEST PERIOD		NUMBER OF READINGS ABOVE WERE	
RANGE OF OPACITY READINGS			
MINIMUM		MAXIMUM	
OBSERVER'S NAME (PRINT) <i>Rex Kelsey</i>			
OBSERVER'S SIGNATURE <i>Rex Kelsey</i>		DATE <i>5/24/04</i>	
ORGANIZATION <i>Nucor Steel</i> <small>ATP - Air Test Professionals, Inc.</small>			
CERTIFIED BY <i>Carl Koontz</i>		DATE <i>3/18/04</i>	
Comments:			

- X = Emission Point
- = Observer's Position
- ☀ = Sun
- = Wind
- = Plume

**COMPLIANCE TEST PROTOCOL  
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT**

Date Prepared: April 1, 2004 Proposed Test Date May 19-21, 2004

Plant Address and Location:

4537 S. Nucor Road, Crawfordsville, Indiana 47933

**1. Source Information**

AFS: Id Number: 107-16823-00038 Permit Number: 107-16823-00038  
 Company: Nucor Steel  
 Mail Address: RR2 Box 311, CR 400 E  
 City: Crawfordsville, Indiana Zip: 47933  
 Co. Contact: Mark Washer Phone: (765) 364-1323

**Check program if applicable:**

FESOP: \_\_\_\_\_  
 Title V: X  
 SSOA: \_\_\_\_\_

**2. Tester Information**

Name: Air Test Professionals, Inc.  
 Address: 1201 N. Graham Ave.  
 Contact: Carlos M. Brown Phone: 317-345-1723  
 Pre-Test Inspection Complete? Yes

**3. Process Information**

Unit to Test: PPFF Baghouse (2-EAF's + 1-AOD)  
 Max. Rated Capacity: 502 tons per hour  
 Proposed Operating Speed: Close to Max as possible  
 Pollution Control Equipment: PPFF Baghouse  
 Process Description: Process of melting scrap metal to make carbon steel.

**4. Test Information**

Methods	Moisture/Flow	# Runs	Time/Run
Method 1-4		3	@ Inlet
Method 5D	PM	3	240 min @ Compartments
Method 6			
Method 7			
Method 9	Opacity	3	60 min @ Roof Monitors
Other Testing:	M202	3	240 min @ Compartments
	M29	3	240 min @ Compartments

326 IAC 3-2.1 requires this completed form and fee to be submitted 35 days prior to proposed test date to:  
 (FEE NOT APPLICABLE IF FESOP OR TITLE V)

Questions may be directed to 317-232-8338, FAX : 317-233-6865

<b>AGENCY USE ONLY</b>		Date Rec'd: _____
Inspector: _____	Reviewer: _____	Date Appr: _____


**5. Sampling Strategy**

a. Describe any deviations from the standard test method.  
None

b. Describe method used to determine quantity of raw materials  
Plant personnel will keep record of weight rates. New Baseline Values for Fan Amps and Delta P's.

**6. Sample Site Location**

Does sample port location meet 40 CFR 60, Appx A, Method 1 Section 1.2 requirements: Yes/No: YES If No, Explain \_\_\_\_\_



Number of sample points for M5: 32  
 Diameter at sample site: 209" Stack height: N/A  
 Approx. stack gas flow (ACFM): 1,309,000  
 Approx. gas temp. (degF): 250 F Max  
 Approx. gas moisture (%): 3%

**Reason for test:**

State Agreed Order: Yes/No: \_\_\_\_\_ Operating permit: Yes/No: Yes  
 Construction Permit: Yes/No: \_\_\_\_\_ Compliance w 326 \_\_\_\_\_  
 NSPS 40 CFR 60 Subpart: \_\_\_\_\_ Other \_\_\_\_\_  
 Title V: \_\_\_\_\_  
 Other (i.e. EPA, CD, state, 114) \_\_\_\_\_

Note: To test 12 of 16 compartments.  
 Volume req. at 160 DSCF.  
 Will Establish Baseline Fan Amps and Delta P during test.

Compliance Data Section  
 Office of Air Management  
 Indiana Department of Environmental Management  
 180 North Senate  
 PO BOX 6015  
 Indianapolis, IN 46206-6015

# Melt Shop / AOD Baghouse Baseline PM and Opacity Testing

## Run 1 Fan Amps and Damper Positions

DATE: 5/19/04 Run 1 Time: 4:00 pm - 9:34 pm

Time	FAN 1		FAN 2		FAN 3		FAN 4		FAN 5		FAN 6	
	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position
4:00 PM	135	100%	144	100%			139	100%	122	100%	137	100%
4:15 PM	138	100%	149	100%			142	100%	127	100%	138	100%
4:30 PM	139	100%	148	100%			142	100%	126	100%	139	100%
4:45 PM	132	100%	141	100%			138	100%	122	100%	136	100%
5:00 PM	144	100%	152	100%			150	100%	132	100%	145	100%
5:15 PM												
5:30 PM												
<b>Testing Suspended</b>												
5:34 PM	127	100%	138	100%			131	100%	115	100%	128	100%
5:49 PM	138	100%	146	100%			140	100%	122	100%	136	100%
6:04 PM	136	100%	145	100%			140	100%	120	100%	137	100%
6:19 PM	126	100%	136	100%			129	100%	115	100%	126	100%
6:34 PM	130	100%	141	100%			132	100%	118	100%	132	100%
6:49 PM	129	100%	140	100%			133	100%	119	100%	130	100%
7:04 PM	125	100%	134	100%			126	100%	111	100%	124	100%
7:19 PM	124	100%	135	100%			128	100%	113	100%	127	100%
7:34 PM	125	100%	137	100%			130	100%	113	100%	128	100%
7:49 PM	121	100%	131	100%			124	100%	113	100%	124	100%
8:04 PM	131	100%	143	100%			137	100%	120	100%	135	100%
8:19 PM	120	100%	132	100%			123	100%	108	100%	120	100%
8:34 PM	137	100%	145	100%			142	80%	123	80%	138	100%
8:49 PM	141	100%	152	100%			146	100%	130	100%	141	100%
9:04 PM	129	100%	139	100%			131	100%	118	100%	127	100%
9:19 PM	122	100%	132	100%			125	100%	113	100%	122	100%
9:34 PM	127	100%	137	100%			132	100%	116	100%	130	100%

	Fan 1	Fan 2	Fan 3	Fan 4	Fan 5	Fan 6	Grand Totals
Max	144	152		150	132	145	152
Min	120	131		123	108	120	108
Avg	130.7	140.8		134.5	118.9	131.8	133.9

# Melt Shop / AOD Baghouse Baseline PM and Opacity Testing

## Run 2 Fan Amps and Damper Positions

Run 2 Time: 7:21 am - 12:06 pm

DATE: 5/21/04

Time	FAN 1		FAN 2		FAN 3		FAN 4		FAN 5		FAN 6	
	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position
7:21 AM	135	100%			132	100%	125	100%	119	100%	128	100%
7:36 AM	136	100%			132	100%	125	100%	118	100%	122	100%
7:51 AM	130	100%			126	100%	120	100%	113	100%	120	100%
8:06 AM	135	100%			133	100%	127	100%	120	100%	126	100%
8:21 AM	136	100%			134	100%	128	100%	121	100%	127	100%
8:36 AM	133	100%			130	100%	123	100%	117	100%	122	100%
8:51 AM	127	100%			124	100%	120	100%	111	100%	117	100%
9:06 AM	137	100%			133	100%	128	100%	116	100%	126	100%
9:21 AM	140	100%			136	100%	132	100%	119	100%	129	100%
9:36 AM	129	100%			123	100%	117	100%	110	100%	117	100%
9:51 AM	134	100%			129	100%	124	100%	113	100%	124	100%
10:06 AM	138	100%			137	100%	131	100%	123	100%	127	100%
10:21 AM	134	100%			129	100%	124	100%	113	100%	124	100%
10:36 AM	132	100%			127	100%	123	100%	115	100%	121	100%
10:51 AM	134	100%			133	100%	126	100%	122	100%	125	100%
11:06 AM	143	100%			143	100%	137	100%	127	100%	136	100%
11:21 AM	126	100%			120	100%	114	100%	108	100%	112	100%
11:36 AM	128	100%			126	100%	121	100%	114	100%	119	100%
11:51 AM	135	100%			131	100%	125	100%	119	100%	125	100%
12:06 PM	130	100%			126	100%	121	100%	112	100%	120	100%
AVG	134	100%			130	100%	125	100%	117	100%	123	100%

	Fan 1	Fan 2	Fan 3	Fan 4	Fan 5	Fan 6	Grand Totals
Max	143		143	137	127	136	143
Min	126		120	114	108	112	108
Avg	133.6		130.2	124.6	116.5	123.4	125.6

# Melt Shop / AOD Baghouse Baseline PM and Opacity Testing

## Run 3 Fan Amps and Damper Positions

Run 3 Time: 1:07 pm - 5:54 pm

DATE: 5/21/04

Time	FAN 1		FAN 2		FAN 3		FAN 4		FAN 5		FAN 6	
	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position	Amps	Damper Position
1:07 PM	138	100%			135	100%	130	100%	121	100%	130	100%
1:22 PM	119	100%			112	100%	108	100%	102	100%	107	100%
1:37 PM	125	100%			120	100%	116	100%	108	100%	116	100%
1:52 PM	133	100%			128	100%	124	100%	114	100%	125	100%
2:07 PM	135	100%			132	100%	127	100%	119	100%	127	100%
2:22 PM	135	100%			131	100%	126	100%	115	100%	126	100%
2:37 PM	139	100%			134	100%	130	100%	121	100%	129	100%
2:52 PM	136	100%			132	100%	124	100%	119	100%	124	100%
3:07 PM	136	100%			132	100%	127	100%	117	100%	126	100%
3:22 PM	127	100%			124	100%	119	100%	111	100%	120	100%
3:37 PM	129	100%			122	100%	119	100%	111	100%	117	100%
3:52 PM	134	100%			128	100%	124	100%	113	100%	124	100%
4:07 PM	134	100%			128	100%	125	100%	113	100%	126	100%
4:22 PM	138	100%			136	100%	128	100%	122	100%	129	100%
4:37 PM	119	100%			112	100%	108	100%	102	100%	109	100%
4:52 PM	132	100%			127	100%	123	100%	114	100%	123	100%
5:07 PM	138	100%			134	100%	131	100%	121	100%	130	100%
5:22 PM	122	100%			114	100%	110	100%	105	100%	111	100%
5:37 PM	128	100%			123	100%	118	100%	111	100%	119	100%
5:52 PM	129	100%			123	100%	118	100%	110	100%	117	100%
AVG	131	100%			126	100%	122	100%	113	100%	122	100%

	Fan 1	Fan 2	Fan 3	Fan 4	Fan 5	Fan 6	Grand Totals
Max	139		136	131	122	130	139
Min	119		112	108	102	107	102
Avg	131.3		126.4	121.8	113.5	121.8	122.9

### Melt Shop / AOD Baghouse Baseline PM and Opacity Testing

5/19/04		5/21/04			
Run 1		Run 2		Run 3	
Time	DP, in. H2O	Time	DP, in. H2O	Time	DP, in. H2O
4:00 PM	7.8	7:21 AM	8.9	1:07 PM	8.7
4:15 PM	7.5	7:36 AM	7.9	1:22 PM	8.0
4:30 PM	8.1	7:51 AM	8.5	1:37 PM	8.4
4:45 PM	7.6	8:06 AM	8.9	1:52 PM	8.6
5:00 PM	7.3	8:21 AM	8.3	2:07 PM	8.2
5:15 PM	suspended	8:36 AM	8.4	2:22 PM	7.9
5:30 PM	suspended	8:51 AM	8.6	2:37 PM	7.5
5:34 PM	6.8	9:06 AM	8.2	2:52 PM	7.9
5:49 PM	6.9	9:21 AM	7.7	3:07 PM	7.7
6:04 PM	6.8	9:36 AM	8.2	3:22 PM	7.7
6:19 PM	6.9	9:51 AM	7.8	3:37 PM	7.9
6:34 PM	7.7	10:06 AM	8.1	3:52 PM	8.2
6:49 PM	7.8	10:21 AM	8.6	4:07 PM	7.6
7:04 PM	7.3	10:36 AM	8.0	4:22 PM	8.3
7:19 PM	6.9	10:51 AM	7.9	4:37 PM	7.8
7:34 PM	7.7	11:06 AM	8.9	4:52 PM	8.3
7:49 PM	7.2	11:21 AM	8.0	5:07 PM	8.8
8:04 PM	7.0	11:36 AM	8.3	5:22 PM	7.9
8:19 PM	6.9	11:51 AM	8.9	5:37 PM	8.1
8:34 PM	7.6	12:06 PM	8.1	5:52 PM	7.8
8:49 PM	7.2				
9:04 PM	7.1				
9:19 PM	7.4				
9:34 PM	7.6				

Max	8.1		8.9		8.8
Min	6.8		7.7		7.5
Average	7.3		8.3		8.1

**Furnace 1 Production: 5/19/04**

Heat No.	Tons	Tap Time	Prev. Tap Time	Tap-to-Tap Minutes	Average tons/hr
141211	130	9:25 AM	8:40 AM	45	173.3
141212	130	10:36 AM	9:25 AM	71	109.9
141213	130	11:30 AM	10:36 AM	54	144.4
141214	129	12:22 PM	11:30 AM	52	148.8
141215	130	1:22 PM	12:22 PM	60	130.0
141216	129	2:10 PM	1:22 PM	48	161.3
141217	130	3:01 PM	2:10 PM	51	152.9
141218	130	3:47 PM	3:01 PM	46	169.6
141219	129	4:30 PM	3:47 PM	43	180.0
141220	129	5:12 PM	4:30 PM	39	194.4
141221	128	6:02 PM	5:12 PM	55	138.0
141222	130	7:00 PM	6:02 PM	52	150.0
141223	129	8:00 PM	7:00 PM	60	130.0
141224	129	9:00 PM	8:00 PM	75	106.0

**Furnace 2 Production: 5/19/04**

Heat No.	Tons	Tap Time	Prev. Tap Time	Tap-to-Tap Minutes	Average tons/hr
246985	106	9:25 AM	8:33 AM	52	122.3
246986	112	10:23 AM	9:25 AM	118	56.8
246987	118	12:40 PM	11:23 AM	77	91.9
246988	115	2:26 PM	12:40 PM	100	66.1
246989	118	3:54 PM	2:26 PM	88	80.5
246990	118	5:21 PM	3:54 PM	102	66.2
246991	115	7:00 PM	5:21 PM	91	72.7
246992	115	8:10 PM	7:00 PM	79	86.1
246993	115	9:57 PM	8:10 PM	78	90.0
246994	115	10:42 PM	9:57 PM	68	101.5

**Stack Gases - SOx, NOx, CO, VOC**

	Run Time	Furn 1 Tons	Furn 2 Tons	AOD Tons	TOTAL
Run 1	10:00 am - 11:00 am	128.8	66.9	46.0	241.7
Run 2	11:44 am - 12:44 pm	142.0	90.1	56.1	288.2

803.5

**AOD Production Data: 5/19/04**

Heat No.	Tons	Tap Time	Charge Time	Charge-Tap Minutes	Average tons/hr
246985	110.1	12:12 PM	9:55 AM	142	60.3
246986	112.2	1:24 PM	12:23 PM	102	66.8
246987	123.8	3:37 PM	2:11 PM	86	86.4
246988	112.5	4:47 PM	3:40 PM	67	106.0
246989	112.2	5:23 PM	5:13 PM	61	116.5
246990	112.2	6:00 PM	6:46 PM	79	89.3
246991	111.1	6:29 PM	6:06 PM	73	90.2
246992	110.0	6:29 PM	6:22 PM	67	106.7

**Run 1 - PM & Metals**

	Run Time	Furn 1 Tons**	Furn 2 Tons**	AOD Tons**	TOTAL**	Avg. Run Production
	11:24 am - 12:24 pm	106.7	458.0	60.0	724.7	241.6

\*\*Run 1 testing was suspended 25 minutes due to furnace downtime.

Production totals are based on 309 minutes run time rather than 334 minutes.



Furnace 1 Production: 5/21/04

Heat No.	Tons	Tap Time	Prev. Tap Time	Tap-to-Tap Minutes	Average tons/hr
141253	108	7:18 AM	6:33 AM	45	144.0
141254	131	8:03 AM	7:18 AM	45	174.7
141255	130	8:54 AM	8:03 AM	51	152.9
141256	129	9:41 AM	8:54 AM	47	164.7
141257	120	10:41 AM	9:41 AM	60	120.0
141258	130	11:29 AM	10:41 AM	48	162.5
141259	130	12:11 PM	11:29 AM	42	185.7
141260	127	1:00 PM	12:11 PM	49	155.5
141261	131	1:41 PM	1:00 PM	41	191.7
141262	129	3:30 PM	1:41 PM	109	71.0
141263	130	4:18 PM	3:30 PM	48	162.5
141264	124	5:05 PM	4:18 PM	47	158.3
141265	130	5:53 PM	5:05 PM	48	162.5
141266	130	6:40 PM	5:53 PM	47	166.0

Furnace 2 Production: 5/21/04

Heat No.	Tons	Tap Time	Prev. Tap Time	Tap-to-Tap Minutes	Average tons/hr
247031	134	8:00 AM	7:18 AM	48	167.5
247032	129	8:54 AM	8:06 AM	48	164.3
247033	130	10:08 AM	8:54 AM	74	106.4
247034	125	10:36 AM	10:08 AM	48	156.3
247035	136	11:48 AM	10:36 AM	62	156.8
247036	119	12:34 PM	11:48 AM	46	156.2
247037	130	1:21 PM	12:34 PM	47	166.0
247038	108	2:02 PM	1:21 PM	41	158.0
247039	122	2:50 PM	2:02 PM	48	152.5
247040	130	3:42 PM	2:50 PM	52	150.0
247041	130	4:36 PM	3:42 PM	54	144.4
247042	130	5:21 PM	4:36 PM	45	173.3
247043	120	6:16 PM	5:21 PM	55	130.9
247044	126	19:07	6:16 PM	51	148.2

AOD Production Data: 5/21/04

Heat No.	Tons	Tap Time	Charge Time	Charge-to-Tap Minutes	Average tons/hr
24702	126.4	7:28 AM	6:56 AM	32	237.0
24703	108.3	8:21 AM	7:44 AM	37	175.6
247036	119.2	1:23 PM	12:52 PM	31	230.7
246988	108.3	2:49 PM	2:20 PM	29	224.1

Run 1 - PM & Metals

	Run Time	Furn 1 Tons	Furn 2 Tons	AOD Tons	TOTAL	Avg. Run Production
Run 2	7:21 am - 12:06 pm	745.8	691.2	142.5	1579.5	332.6
Run 3	1:07 pm - 5:54 pm	621.6	730.7	169.8	1522.1	318.2

**EBT HEAT RECORD**

HEAT NO: 141211 FULL WEIGHT: \_\_\_\_\_ DATE: 5-18 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: DAN KWH START: \_\_\_\_\_  
 LADLE NO: 12 WEIGHT TAPPED: 136 AIM GRADE: 1008A2 KWH USED: 52  
 LAST HEAT TAPPED: 8:40 HEATS ON DELTA: 157 PATCH: \_\_\_\_\_ LBS(EST) \_\_\_\_\_

SAMPLE	TIME	CHEMISTRY													TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N				
F-1		<u>05</u>				<u>052</u>		<u>08</u>									<u>15</u>
F-2																	
F-3																	
F-4																	

CHARGE BKT #1 BKT #2

HOT HEEL	<u>40,000</u>	
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	<u>78</u>	<u>60</u>
BURNT LIME	<u>2000</u>	
DOLO LIME	<u>4700</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	<u>8</u> Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	<u>8</u> Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF 0
Vulcan lance on	_____	_____	_____ Lbs. Inj
Carbon Injector on	_____	_____	

Time	Temp	Time	Temp
_____	<u>3071</u>	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS WEIGHT(LBS)

<u>B#1</u>	

TAP TIME: 9:25

OXYGEN PPM 1078

REMARKS (list)

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

EBT HEAT RECORD

HEAT NO: 1412/2 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: Myers KWH START: \_\_\_\_\_  
 LADLE NO: \_\_\_\_\_ WEIGHT TAPPED: 26000 AIM GRADE: 100873 KWH USED: 50  
 LAST HEAT TAPPED: 9:25 HEATS ON DELTA: 158 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N		
F-1		027			047		071								
F-2															
F-3															
F-4															

CHARGE	BKT #1	BKT #2
HOT HEEL	<del>30,000</del>	
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	75	60
BURNT LIME	2000	
DOLO LIME	4700	
CRG. CARBON	1500	

	START	END		
Drop 1st bucket	_____	_____	8 Tap no.	
Power on	_____	_____		Tap no.
	_____	_____		Tap no.
Oxy-fuel burners	_____	_____	CF	
Vulcan lance on	_____	_____	CF CH	
	_____	_____	CF O	
Drop 2nd bucket	_____	_____	8 Tap no.	
Power on	_____	_____		Tap no.
	_____	_____		CF
Oxy-fuel burners	_____	_____	CF CH	
Vulcan lance on	_____	_____	CF O	
Carbon Injector on	_____	_____	Lbs. Inj	

Time	Temp	Time	Temp
_____	3069	002	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)
B#1	

TAP TIME: 11:36

REMARKS (list)

OXYGEN PPM 1344

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

EBT HEAT RECORD

HEAT NO: 141213 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: Myers KWH START: \_\_\_\_\_  
 LADLE NO: 5 WEIGHT TAPPED: 240000 AIM GRADE: 1008A2 KWH USED: 49  
 LAST HEAT TAPPED: 10136 HEATS ON DELTA: 159 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N				
F-1		<u>0.39</u>					<u>0.57</u>		<u>0.72</u>								
F-2																	
F-3																	
F-4																	

CHARGE BKT #1 BKT #2

HOT HEEL									
BUSHELING									
SKULLS									
BUNDLES									
P/S									
SHREDDED									
SCRAP TOTAL	<u>150</u>	<u>120</u>							
BURNT LIME	<u>2000</u>								
DOLO LIME	<u>4700</u>								
CRG. CARBON	<u>1500</u>								

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Carbon Injector on	_____	_____	_____ Lbs. Inj

LADLE ALLOYS	WEIGHT(LBS)
<u>B#1</u>	

Time	Temp	Time	Temp
_____	<u>3076</u>	<u>.007</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM 11.22  
 REMARKS (list)  
Add A phase 5 mins

EBT HEAT RECORD

HEAT NO: 141214 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: Miers KWH START: \_\_\_\_\_  
 LADLE NO: 10 WEIGHT TAPPED: 25000 AIM GRADE: \_\_\_\_\_ KWH USED: 47  
 LAST HEAT TAPPED: 11:30 HEATS ON DELTA: 160 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N		
F-1		<u>032</u>			<u>050</u>		<u>080</u>								
F-2															
F-3															
F-4															

CHARGE BKT #1 BKT #2

HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	<u>150</u>	<u>129</u>
SCRAP TOTAL		<u>139.540</u>
BURNT LIME	<u>2000</u>	
DOLO LIME	<u>4700</u>	
CRG. CARBON	<u>1500</u>	

	START	END		
Drop 1st bucket	_____	_____	<u>6</u> Tap no.	
Power on	_____	_____		Tap no.
	_____	_____		Tap no.
Oxy-fuel burners	_____	_____	CF	
Vulcan lance on	_____	_____	CF CH	
	_____	_____	CF O	
Drop 2nd bucket	_____	_____	<u>6</u> Tap no.	
Power on	_____	_____		Tap no.
	_____	_____		CF
Oxy-fuel burners	_____	_____	CF CH	
Vulcan lance on	_____	_____	CF O	
Carbon Injector on	_____	_____	Lbs. Inj	

Time	Temp	Time	Temp
_____	<u>3033</u>	<u>10:41</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)
<u>1</u>	

OXYGEN PPM 168

TAP TIME: 12:22

REMARKS (list)  
 \_\_\_\_\_  
 \_\_\_\_\_  
Add # 8 please - 6 min  
 \_\_\_\_\_  
 \_\_\_\_\_

**EBT HEAT RECORD**

HEAT NO: 141215 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: Wyers KWH START: \_\_\_\_\_  
 LADLE NO: 17 WEIGHT TAPPED: 260000 AIM GRADE: \_\_\_\_\_ KWH USED: 377  
 LAST HEAT TAPPED: 12:22 HEATS ON DELTA: 161 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N				
F-1		<u>043</u>				<u>058</u>		<u>088</u>									
F-2																	
F-3																	
F-4																	

CHARGE BKT N1 BKT N2

HOT HEEL																	
BUSHELING																	
SKULLS																	
BUNDLES																	
P/S																	
SHREDDED																	
		<u>150</u>	<u>129</u>														
SCRAP TOTAL			<u>139.56</u>														
BURNT LIME	<u>2000</u>																
DOLO LIME	<u>4700</u>																
CRG. CARBON	<u>1500</u>																

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Carbon Injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Time	Temp
_____	<u>2946</u>	<u>1:027</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS WEIGHT(LBS)

<u>1</u>	

TAP TIME: 1:22

REMARKS (list)

OXYGEN PPM 96

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

EBT HEAT RECORD

HEAT NO: 141216 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: WYERS KWH START: \_\_\_\_\_  
 LADLE NO: 11 WEIGHT TAPPED: 258000 AIM GRADE: \_\_\_\_\_ KWH USED: 47  
 LAST HEAT TAPPED: 1:02 HEATS ON DELTA: 162 PATCH: \_\_\_\_\_ LBS(EST) \_\_\_\_\_

CHEMISTRY

SAMPLE	TIME	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N	TOTAL RESID
F-1		<u>035</u>			<u>056</u>		<u>092</u>							
F-2														
F-3														
F-4														

CHARGE BKT N1 BKT N2

HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	<u>150</u>	<u>129</u>
SCRAP TOTAL		<u>139.5 tons</u>
BURNT LIME	<u>2000</u>	
DOLO LIME	<u>4700</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	<u>6</u> Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	<u>6</u> Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Vulcan lance on	_____	_____	_____ Lbs. Inj
Carbon Injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Time	Temp
_____	<u>2958</u>	<u>1:05</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS WEIGHT(LBS)

<u>1</u>	

OXYGEN PPM 1099

TAP TIME: 2:10

REMARKS (list)

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_





EBT HEAT RECORD

HEAT NO: 141218 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: Myers KWH START: \_\_\_\_\_  
 LADLE NO: 10 WEIGHT TAPPED: 21000 AIM GRADE: \_\_\_\_\_ KWH USED: 96  
 LAST HEAT TAPPED: 3101 HEATS ON DELTA: 164 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY											TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V		N	
F-1		031				0.16	0.19								
F-2															
F-3															
F-4															

CHARGE BKT #1 BKT #2

HOT HEEL														
BUSHELING														
SKULLS														
BUNDLES														
P/S														
SHREDDED														
SCRAP TOTAL		150	133											
BURNT LIME		2000												
DOLO LIME		4700												
CRG. CARBON		1500												

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Carbon Injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Time	Temp
_____	<u>2973</u>	<u>2027</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM 984

TAP TIME: 3:47

REMARKS (list)

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



20

EBT HEAT RECORD

HEAT NO: 1412 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: Myers KWH START: \_\_\_\_\_  
 LADLE NO: 11 WEIGHT TAPPED: 238000 AIM GRADE: \_\_\_\_\_ KWH USED: 23  
 LAST HEAT TAPPED: 4/30 HEATS ON DELTA: 166 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID	
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N			
F-1																
F-2																
F-3																
F-4																

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	P.B	Scrap
	150	127
SCRAP TOTAL		138.5 lbs
BURNT LIME	2000	
DOLO LIME	5500	
CRG. CARBON	1500	

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	6 Tap no.
	_____	_____	Tap no.
	_____	_____	Tap no.
Oxy-fuel burners	_____	_____	CF
	_____	_____	CF CH
Vulcan lance on	_____	_____	CF O
Drop 2nd bucket	_____	_____	
Power on	_____	_____	6 Tap no.
	_____	_____	Tap no.
Oxy-fuel burners	_____	_____	CF
	_____	_____	CF CH
Vulcan lance on	_____	_____	CF O
Carbon Injector on	_____	_____	Lbs. Inj

Time	Temp	Time	Temp
_____	2970	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)
1	

OXYGEN PPM 1047

TAP TIME: 5:52

REMARKS (list)

150,000 P. Back Cast on 1  
Hot Heel Tapped Out  
55 mins

**EBT HEAT RECORD**

HEAT NO: 141221 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: Myers KWH START: \_\_\_\_\_  
 LADLE NO: 7 WEIGHT TAPPED: 256000 AIM GRADE: \_\_\_\_\_ KWH USED: 39  
 LAST HEAT TAPPED: 3:52 HEATS ON DELTA: 167 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N				
F-1		<u>033</u>				<u>042</u>		<u>076</u>									
F-2																	
F-3																	
F-4																	

CHARGE BKT #1 BKT #2

HOT HEEL																	
BUSHELING																	
SKULLS																	
BUNDLES																	
P/S																	
SHREDDED																	
SCRAP TOTAL		<u>154</u>		<u>130</u>													<u>142 total</u>
BURNT LIME		<u>2000</u>															
DOLO LIME		<u>4700</u>															
CRG. CARBON		<u>1500</u>															

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Carbon Injector on	_____	_____	_____ Lbs. Inj

LADLE ALLOYS WEIGHT(LBS)


Time	Temp	Time	Temp
_____	<u>2990</u>	<u>0200</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM 1310

TAP TIME: 6:44

REMARKS (list)

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

IRON STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 141222 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: MYERS KWH START: \_\_\_\_\_  
 LADLE NO: 10 WEIGHT TAPPED: 216000 AIM GRADE: \_\_\_\_\_ KWH USED: 49  
 LAST HEAT TAPPED: 647 HEATS ON DELTA: 168 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N				
F-1		033				047	086										
F-2																	
F-3																	
F-4																	

CHARGE BKT #1 BKT #2

HOT HEEL																	
BUSHING																	
SKULLS																	
BUNDLES																	
P/S																	
SHREDDED																	
SCRAP TOTAL		150	141														
BURNT LIME		2000															
DOLO LIME		4700															
CRG. CARBON		1500															

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Vulcan lance on	_____	_____	
Carbon Injector on	_____	_____	_____ Lbs. Inj

LADLE ALLOYS	WEIGHT(LBS)
<u>1</u>	

Time	Temp	Time	Temp
_____	<u>2941</u>	<u>1836</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM 232

TAP TIME: 7:39

REMARKS (list)

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

INLOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 141223  
HEATS ON BOTTOM: \_\_\_\_\_  
LADLE NO: 12  
LAST HEAT TAPPED: 7139

FULL WEIGHT: \_\_\_\_\_  
TARE WEIGHT: \_\_\_\_\_  
WEIGHT TAPPED: 258000  
HEATS ON DELTA: 109

DATE: 5-19 KWH END: \_\_\_\_\_  
MELTER: MYERS KWH START: \_\_\_\_\_  
AIM GRADE: \_\_\_\_\_ KWH USED: 28  
PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY												TOTAL RESID	
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N		
F-1		<del>037</del>					<del>023</del>								
F-2		037					051			023					
F-3															
F-4															

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	150	129
SCRAP TOTAL		139.5
BURNT LIME	2000	
DOLO LIME	4700	
CRG. CARBON	1500	

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Vulcan lance on	_____	_____	
Carbon Injector on	_____	_____	_____ Lbs. Inj

LADLE ALLOYS	WEIGHT(LBS)
<u>1</u>	

Time	Temp	Time	Temp
_____	<u>3029</u>	<u>002</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

TAP TIME: 8:37

REMARKS (list) OXYGEN PPM 1256  
Add C phase grains

NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 141224 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: 11 years KWH START: \_\_\_\_\_  
 LADLE NO: 11 WEIGHT TAPPED: 258000 AIM GRADE: \_\_\_\_\_ KWH USED: 38  
 LAST HEAT TAPPED: 8:37 HEATS ON DELTA: 170 PATCH: 2500 LBS(EST)

SAMPLE	TIME	CHEMISTRY											TOTAL RESID			
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V		N		
F-1		<u>040</u>				<u>050</u>	<u>083</u>									
F-2																
F-3																
F-4																

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	<u>150</u>	<u>130</u>
SCRAP TOTAL		<u>140 tons</u>
BURNT LIME	<u>2000</u>	
DOLO LIME	<u>4700</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Carbon Injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Time	Temp
_____	<u>3000</u>	<u>-006</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)
<u>1</u>	

OXYGEN PPM 1012

TAP TIME: 9:50

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
patch - 11 miles  
 \_\_\_\_\_  
 \_\_\_\_\_

NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 141225 FULL WEIGHT: \_\_\_\_\_ DATE: 5-18 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: Tim KWH START: \_\_\_\_\_  
 LADLE NO: 7 WEIGHT TAPPED: 129 AIM GRADE: \_\_\_\_\_ KWH USED: 50  
 LAST HEAT TAPPED: 9:50 HEATS ON DELTA: 171 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY												TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N			
F-1		<u>059</u>				<u>054</u>										
F-2																
F-3																
F-4																

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	<u>150</u>	<u>130</u>
SCRAP TOTAL		<u>140 tons</u>
BURNT LIME	<u>2000</u>	
DOLO LIME	<u>4700</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Carbon Injector on	_____	_____	_____ Lbs. Inj

LADLE ALLOYS	WEIGHT(LBS)

Time	Temp	Time	Temp
_____	<u>2591</u>	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM 1018

TAP TIME: 22:54

REMARKS (list)  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_





EBT HEAT RECORD

HEAT NO: 246986 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19-04 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: Delta KWH START: \_\_\_\_\_  
 LADLE NO: 0 WEIGHT TAPPED: 224000 AIM GRADE: 40953 KWH USED: 52  
 LAST HEAT TAPPED: 09:25 HEATS ON DELTA: 82 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY											TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V		N	
F-1		.82			.07	10	.14		8.9					.005	33
F-2															
F-3															
F-4															

CHARGE BKT #1 BKT #2

HOT HEEL		
BUSHING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	80	46
SCRAP TOTAL	16000	92
BURNT LIME	3000	
DOLO LIME	5000	
CRG. CARBON	—	

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Vulcan lance on	_____	_____	_____ CF CH
	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Carbon Injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Time	Temp
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS WEIGHT(LBS)


TAP TIME: 11:23

REMARKS (list)

OXYGEN PPM  8

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

HEAT NO: 24-6987 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19-09 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: 117 KWH START: \_\_\_\_\_  
 LADLE NO: 0 WEIGHT TAPPED: 236006 AIM GRADE: 409 KWH USED: 53  
 LAST HEAT TAPPED: 11:23 HEATS ON DELTA: 83 PATCH: \_\_\_\_\_ LBS(EST)

CHEMISTRY

SAMPLE	TIME	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N	TOTAL RESID
F-1		<u>8</u>	<u>05</u>	<u>05</u>	<u>14</u>	<u>18</u>		<u>8</u>					<u>006</u>	<u>.38</u>
F-2														
F-3														
F-4														

CHARGE BKT #1 BKT #2

HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	<u>81</u>	<u>45</u>
SCRAP TOTAL	<u>162000</u>	<u>90000</u>
BURNT LINE	<u>3000</u>	
DOLO LINE	<u>5000</u>	
CRG. CARBON		

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	Tap no.
	_____	_____	Tap no.
	_____	_____	Tap no.
Oxy-fuel burners	_____	_____	CF
	_____	_____	CF CH
Vulcan lance on	_____	_____	CF O
Drop 2nd bucket	_____	_____	
Power on	_____	_____	Tap no.
	_____	_____	Tap no.
Oxy-fuel burners	_____	_____	CF
	_____	_____	CF CH
Vulcan lance on	_____	_____	CF O
Carbon Injector on	_____	_____	Lbs. Inj

Time	Temp	Time	Temp
_____	_____	_____	<u>2971</u>
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)

TAP TIME: 12:40

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

OXYGEN PPM

HEAT NO: 24-698 FULL WEIGHT: \_\_\_\_\_ DATE: 5-17-04 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: 127 KWH START: \_\_\_\_\_  
 LADLE NO: 0 WEIGHT TAPPED: 230006 AIM GRADE: 401 KWH USED: 56  
 LAST HEAT TAPPED: 12:40 HEATS ON DELTA: 87 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY											TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V		N	
F-1		10		.03	.05	.19	.16		9					.007	.33
F-2															
F-3															
F-4															

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	81	
SCRAP TOTAL	162000	90000
BURNT LIME	3000	
DOLO LIME	5000	
CRG. CARBON		

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Carbon Injector on	_____	_____	_____ Lbs. Inj

Time	Teap	Time	Teap
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)

TAP TIME: 14:26

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

OXYGEN PPM

HEAT NO: 24-6989 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19-64 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: AM KWH START: \_\_\_\_\_  
 LADLE NO: 0 WEIGHT TAPPED: 23600G AIM GRADE: 409 KWH USED: 59  
 LAST HEAT TAPPED: 14:26 HEATS ON DELTA: 85 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY												TOTAL RESID	
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N		
F-1		1.2			0.6	.22	.13		11					.007	52
F-2															
F-3															
F-4															

CHARGE BKT #1 BKT #2

HOT HEEL															
BUSHELING															
SKULLS															
BUNDLES															
P/S															
SHREDDED															
SCRAP TOTAL		80	45												
BURNT LIME		3000													
DOLO LIME		5000													
CRG. CARBON															

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Vulcan lance on	_____	_____	
Drop 2nd bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Vulcan lance on	_____	_____	
Carbon Injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Time	Temp
_____	_____	_____	3012
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM

REMARKS (list) \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

LADLE ALLOYS WEIGHT(LBS)


TAP TIME: 15:54

**EBT HEAT RECORD**

HEAT NO: 24-6990 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19-09 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: 117 KWH START: \_\_\_\_\_  
 LADLE NO: 0 WEIGHT TAPPED: 232006 AIM GRADE: 409 KWH USED: 56  
 LAST HEAT TAPPED: 13354 HEATS ON DELTA: 86 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY											TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V		N	
F-1		1.5			0.4	2	.15		71					.006	.4
F-2															
F-3															
F-4															

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	<u>16000</u>	<u>9000</u>
BURNT LIME	<u>3000</u>	
DOLO LIME	<u>1500</u>	
CRG. CARBON		

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
Vulcan lance on	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
Vulcan lance on	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Carbon Injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Time	Temp
_____	_____	_____	<u>2986</u>
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)
_____	_____
_____	_____

TAP TIME: 17:36

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

OXYGEN PPM

WORLD STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 24-6991 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19-09 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: 102 KWH START: \_\_\_\_\_  
 LADLE NO: 0 WEIGHT TAPPED: 236000 AIM GRADE: 409 KWH USED: 54  
 LAST HEAT TAPPED: 17:36 HEATS ON DELTA: 87 PATCH: 2200 LBS(EST)

SAMPLE	TIME	CHEMISTRY												TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N			
F-1		1.3				.06	.16	.14		10					.006	35
F-2																
F-3																
F-4																

CHARGE BKT #1 BKT #2

HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	16000	9000
BURNT LIME	3000	
DOLO LIME	5000	
CRG. CARBON		

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Vulcan lance on	_____	_____	_____ Lbs. Inj
Carbon Injector on	_____	_____	

Time	Temp	Time	Temp
_____	_____	_____	3061
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)

TAP TIME: 18:51

REMARKS (list)

OXYGEN PPM

patch 11

Hot Mill 10







EBT HEAT RECORD

HEAT NO: 24-6444 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19-04 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: JKR KWH START: \_\_\_\_\_  
 LADLE NO: 0 WEIGHT TAPPED: 230050 AIM GRADE: 409 KWH USED: 46  
 LAST HEAT TAPPED: 21:34 HEATS ON DELTA: 90 PATCH: \_\_\_\_\_ LBS(EST) \_\_\_\_\_

SAMPLE	TIME	CHEMISTRY												TOTAL RESID	
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N		
F-1		1.065			042		16								37
F-2															
F-3															
F-4															

CHARGE BKT #1 BKT #2

HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDER		
SCRAP TOTAL	16000	90000
BURNT LIME	3000	
DOLO LIME	5000	
CRG. CARBON		

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Carbon Injector on	_____	_____	_____ Lbs. Inj

LADLE ALLOYS	WEIGHT(LBS)

Time	Temp	Time	Temp
_____	2965	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

TAP TIME: 22:42

REMARKS (list)

OXYGEN PPM 32  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Heat # 246985

Grade 409S2

Operator bfay

Practice CRSS LCLN

Slag ANY SS GRADE

Heat Created 05/19/04 09:39

Lining ID April#2 04

Lining Minutes 605

Heats 160 Min. Weight 200,000

AddsWiz Oxygen Estimate 75046

TapToCharge 173.0248

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.004				0.100	11.050			
Max	0.015			0.010	0.200	11.250			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	0.582	0.270	0.040	0.065	0.158	5.970	0.140	0.005	0.008
A1	0.026	0.140	0.032	0.065	0.009	7.430	0.150	0.008	0.002
A2	0.009	0.190	0.030	0.048	0.016	9.150	0.140	0.007	0.002
A3	0.009	0.260	0.029	0.018	0.204	10.030	0.140	0.006	0.002
A4	0.010	0.280	0.029	0.018	0.322	10.620	0.140	0.007	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
42.51	6.35	30.04	20.91	0.00	0.00	25,818.52

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
9:40	Chem T1					
9:55	Charge					
9:58	Sample		0.5823			6816
10:03	Temp	2753				
10:04	Decarb					
10:04	AddsWiz					
10:05	Sample		0.5908	3623		10476
10:06	Decarb					
10:06	AddsWiz					
10:35	Sample		0.0147	89996		80254
10:38	Temp	2980				
10:39	Decarb					
10:53	Chem A1					
10:56	Reduce					
10:58	AddsWiz					
11:07	Sample		0.0067	106435		185644
11:15	Temp	2970				
11:18	Chem A2					
11:18	AddsWiz					
11:22	Reduce					
11:28	Sample		0.0088	106435		207823
11:32	Temp	2887				
11:46	AddsWiz					
11:50	Fuel %Al					
11:55	Sample		0.0094	116279		229997
11:59	Temp	2931				
12:11	Chem A4					
12:13	Fuel %Si					
12:16	Sample		0.0106	119817		238525
12:17	Tap					

Tap Heat	05/19/04 12:17		<b>TOTALS</b>	<b>119817</b>	<b>0</b>	<b>238621</b>
Charge Heat	05/19/04 9:55	Transfer Wt	214,000			
Charge - Tap	143	Tap Wt	238,234			

**ADDITIONS**

	Recipe1	Recipe2	Recipe3	Recipe4	Recipe5	Recipe6	Recipe7	Stainless lime	WizDec0 1	WizDSg 01	WizRe 1
Al	500		250	1,000			200				1,0
Dolo										2,772	
FeCrSi											1,0
FeSi	1,000				250						1,5
HCFeCr									17,602		
LCCr	3,500		3,500			1,000					
Lime		1,000						5,000		1,740	
<b>Total</b>	<b>5,000</b>	<b>1,000</b>	<b>3,750</b>	<b>1,000</b>	<b>250</b>	<b>1,000</b>	<b>200</b>	<b>5,000</b>	<b>17,602</b>	<b>4,512</b>	<b>3,6</b>

Heat # 246986      Grade 409S2      Operator bfay  
 Practice CRSS LCLN      Slag ANY SS GRADE      Heat Created 05/19/04 12:22  
 Lining ID April#2 04      Lining Minutes 748      Heats 161      Min. Weight 200,000  
 Addswiz Oxygen Estimate 64707      TapToCharge 4.9585

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.004				0.100	11.050			
Max	0.015			0.010	0.200	11.250			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	0.820	0.340	0.038	0.070	0.106	8.850	0.140	0.005	0.007
A1	0.019	0.210	0.031	0.050	0.010	9.550	0.150	0.005	0.002
A2	0.011	0.300	0.029	0.045	0.122	10.910	0.140	0.006	0.002
A3	0.010	0.320	0.030	0.031	0.189	11.000	0.140	0.006	0.002
L4	0.009	0.330	0.029	0.016	0.243	11.020	0.140	0.006	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
44.28	5.78	34.65	15.04	0.00	0.00	16,135.44

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
12:22	Charge					
12:23	Chem T1					
12:25	Sample		0.8199			4557
12:27	Temp	2725				
12:28	Decarb					
12:28	Addswiz					
12:57	Sample		0.0148	78345		78653
13:01	Temp	2999				
13:02	Decarb					
13:06	Chem A1					
13:12	Reduce					
13:13	Addswiz					
13:19	Sample		0.0040	89910		139344
13:22	Temp	3074				
13:26	Chem A2					
13:29	Reduce					
13:33	Sample		0.0124	89910		155807
13:39	Temp	3015				
13:46	Chem A3					
13:48	Reduce					
13:54	Sample		0.0100	89910		176715
14:04	Tap					

Tap Heat	05/19/04 14:04		<b>TOTALS</b>	<b>89910</b>	<b>0</b>	<b>176832</b>
Charge Heat	05/19/04 12:22	Transfer Wt	224,000			
<b>Charge - Tap</b>	<b>102</b>	<b>Tap Wt</b>	<b>234,273</b>			

**ADDITIONS**

	Recipe1	Recipe2	Recipe3	Recipe4	Recipe5	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	Tot:
Al	250		300						816	700	2,0
Dolo								2,134			2,1
FeCrSi									1,000		1,0
FeSi	350		150						1,225	1,000	2,7
HCFeCr							10,000				10,0
LCCr	750				500						1,2
Lime		1,000		500		5,000		500			7,0
<b>Total</b>	<b>1,350</b>	<b>1,000</b>	<b>450</b>	<b>500</b>	<b>500</b>	<b>5,000</b>	<b>10,000</b>	<b>2,634</b>	<b>3,041</b>	<b>1,700</b>	<b>26,1</b>

Nucor Steel - Crawfordsville AOD Log

Heat # 246987      Grade 409S2      Operator jnichols  
 Practice CRSS LCLN      Slag ANY SS GRADE      Heat Created 05/19/04 14:11  
 Lining ID April#2 04      Lining Minutes 850      Heats 162      Min. Weight 200,000  
 Addswiz Oxygen Estimate 81095      TapToCharge 6.929333

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.004				0.100	11.050			
Max	0.015			0.010	0.200	11.250			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	0.817	0.330	0.035	0.054	0.138	8.010	0.150	0.005	0.008
A1	0.006	0.210	0.028	0.052	0.009	8.710	0.170	0.005	0.002
A2	0.009	0.310	0.027	0.013	0.056	11.280	0.160	0.006	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
51.13	8.17	29.19	11.28	0.00	0.00	22,464.85

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
14:11	Charge					
14:12	Chem T1					
14:13	Sample		0.8175			4428
14:15	Temp	2643				
14:16	Decarb					
14:16	Sample		0.8175	45		6722
14:22	Decarb					
14:22	Addswiz					
14:54	Sample		0.0147	94780		83063
14:56	Temp	3158				
14:57	Decarb					
15:01	Sample		0.0065	96805		101020
15:03	Temp	3065				
15:04	Decarb					
15:09	Chem A1					
15:09	Reduce					
15:09	Addswiz					
15:21	Sample		0.0071	101121		163460
15:27	Temp	3043				
15:30	Chem A2					
15:31	Reduce					
15:36	Sample		0.0095	101121		179103
15:37	Tap					

Tap Heat 05/19/04 15:37      **TOTALS**      101121      0      179216  
 Charge Heat 05/19/04 14:11      Transfer Wt      236,000  
**Charge - Tap 86**      **Tap Wt**      247,565

**ADDITIONS**

	Recipe1	Recipe2	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	WizRSg 01	Total
Al	100					1,154	600		1,854
Dolo					2,997			1,273	4,270
FeCrSi						1,000			1,000
FeSi	400	250				1,814	800		3,264
HCFeCr				13,000					13,000
Lime			5,000		2,310			2,823	10,133
<b>Total</b>	<b>500</b>	<b>250</b>	<b>5,000</b>	<b>13,000</b>	<b>5,307</b>	<b>3,968</b>	<b>1,400</b>	<b>4,096</b>	<b>33,521</b>



Heat # **246988** Grade **409S2** Operator **jnichols**  
 Practice **CRSS LCLN** Slag **ANY SS GRADE** Heat Created **05/19/04 15:40**  
 Lining ID **April#2 04** Lining Minutes **935** Heats **163** Min. Weight **200,000**  
 Addswiz Oxygen Estimate **73566** TapToCharge **3.925**

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.004				0.100	11.050			
Max	0.015			0.010	0.200	11.250			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	1.046	0.340	0.034	0.049	0.189	9.070	0.120	0.007	0.014
A1	0.009	0.250	0.028	0.049	0.010	9.980	0.140	0.005	0.002
A2	0.008	0.330	0.028	0.008	0.236	11.350	0.130	0.006	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
49.12	7.18	30.54	12.78	0.00	0.00	16,048.11

Time	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
15:40	Charge					
15:44	Chem T1					
15:45	Sample		1.0456			8512
15:47	Temp	2669				
15:47	Decarb					
15:48	Addswiz					
16:17	Sample		0.0148	82585		84681
16:20	Temp	3041				
16:20	Decarb					
16:24	Chem A1					
16:27	Reduce					
16:27	Addswiz					
16:37	Sample		0.0057	89875		145934
16:44	Temp	3071				
16:47	Tap					

Tap Heat	05/19/04 16:47	<b>TOTALS</b>	<b>89875</b>	<b>0</b>	<b>146049</b>
Charge Heat	05/19/04 15:40	Transfer Wt	230,000		
<b>Charge - Tap</b>	<b>67</b>	<b>Tap Wt</b>	<b>235,622</b>		

ADDITIONS	Recipe1	WizDec0	WizDSg	WizRed0	WizRed0	WizRSg	Total
		1	01	1	2	01	
Al				1,200	250		1,450
Dolo			2,190			700	2,890
FeCrSi				1,000			1,000
FeSi				1,022	708		1,730
HCFeCr	1,000	6,774					7,774
Lime			450			1,500	1,950
<b>Total</b>	<b>1,000</b>	<b>6,774</b>	<b>2,640</b>	<b>3,222</b>	<b>958</b>	<b>2,200</b>	<b>16,794</b>

Nucor Steel - Crawfordsville AOD Log

Heat # 246989 Grade 409S2 Operator jnichols  
 Practice CRSS LCLN Slag ANY SS GRADE Heat Created 05/19/04 16:56  
 Lining ID April#2 04 Lining Minutes 1002 Heats 164 Min. Weight 200,000

AddsWiz Oxygen Estimate 63016 TapToCharge 25.796

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.004				0.100	11.050			
Max	0.015			0.010	0.200	11.250			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	1.181	0.310	0.033	0.056	0.224	10.870	0.140	0.007	0.018
A1	0.024	0.270	0.027	0.054	0.010	10.590	0.150	0.005	0.002
A2	0.009	0.320	0.027	0.006	0.150	11.370	0.140	0.005	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
51.48	8.28	26.46	13.26	0.02	0.00	15,319.50

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
16:56	Chem T1					
17:13	Charge					
17:18	Sample		1.1813			9086
17:19	Temp	2719				
17:20	Decarb					
17:21	AddsWiz					
17:48	Sample		0.0148	71185		86518
17:50	Temp	3031				
17:51	Decarb					
17:57	Chem A1					
18:04	Reduce					
18:04	AddsWiz					
18:15	Sample		0.0064	81893		174900
18:18	Temp	3057				
18:41	Reduce					
18:42	Sample		0.0064	81893		181362
18:44	Tap					
Tap Heat	05/19/04 18:44		<b>TOTALS</b>	<b>81893</b>	<b>0</b>	<b>181472</b>
Charge Heat	05/19/04 17:13	Transfer Wt	234,000			
Charge - Tap	91	Tap Wt	232,455			

ADDITIONS	Recipe1	Recipe2	Stainless lime	WizDSg 01	WizRed0 1	WizRed0 2	WizRSg 01	Total
Al					1,000	450		1,450
Dolo				1,808			1,077	2,885
FeCrSi					509			509
FeSi		200			541	600		1,341
HCFeCr	750							750
Lime			5,000				1,851	6,851
<b>Total</b>	<b>750</b>	<b>200</b>	<b>5,000</b>	<b>1,808</b>	<b>2,050</b>	<b>1,050</b>	<b>2,928</b>	<b>13,786</b>

Heat # 246990 Grade 409S2 Operator jnichols  
 Practice CRSS LCLN Slag ANY SS GRADE Heat Created 05/19/04 18:46  
 Lining ID April#2 04 Lining Minutes 1093 Heats 165 Min. Weight 200,000  
 Addswiz Oxygen Estimate 69766 TapToCharge 2.133333

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.004				0.100	11.050			
Max	0.015			0.010	0.200	11.250			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	1.526	0.410	0.034	0.049	0.205	10.900	0.190	0.006	0.016
A1	0.059	0.370	0.028	0.041	0.010	11.070	0.190	0.004	0.002
A2	0.006	0.400	0.028	0.003	0.192	11.390	0.190	0.004	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
51.12	7.72	24.39	16.12	0.03	0.00	13,346.82

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
18:46	Charge					
18:46	Chem T1					
18:50	Sample		1.5260			6600
18:52	Temp	2773				
18:53	Decarb					
18:55	Addswiz					
19:23	Sample		0.0148	77151		87515
19:25	Temp	3023				
19:25	Decarb					
19:29	Chem A1					
19:44	Reduce					
19:44	Addswiz					
19:51	Sample		0.0035	90528		186898
19:56	Temp	3109				
20:03	Reduce					
20:03	Chem A2					
20:04	Sample		0.0064	90528		193620
20:05	Tap					
Tap Heat	05/19/04 20:05		<b>TOTALS</b>	<b>90528</b>	<b>0</b>	<b>193744</b>
Charge Heat	05/19/04 18:46	Transfer Wt	236,000			
<b>Charge - Tap</b>	<b>79</b>	<b>Tap Wt</b>	<b>232,566</b>			

ADDITIONS	Recipe1	Recipe2	Stainless lime	WizDSg 01	WizRed0 1	WizRed0 2	Total
Al					900	600	1,500
Dolo				2,500			2,500
FeSi		150				1,000	1,150
HCFeCr	500						500
Lime			5,000	1,500			6,500
<b>Total</b>	<b>500</b>	<b>150</b>	<b>5,000</b>	<b>4,000</b>	<b>900</b>	<b>1,600</b>	<b>12,150</b>

Heat # 246991      Grade 409S2      Operator jnichols  
 Practice CRSS LCLN      Slag ANY SS GRADE      Heat Created 05/19/04 20:07  
 Lining ID April#2 04      Lining Minutes 1172      Heats 166      Min. Weight 200,000

AddsWiz Oxygen Estimate 60933      TapToCharge 2.158333

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.004				0.100	11.050			
Max	0.015			0.010	0.200	11.250			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	1.265	0.270	0.032	0.062	0.163	10.240	0.160	0.006	0.015
A1	0.056	0.250	0.027	0.032	0.009	10.420	0.160	0.004	0.002
A2	0.008	0.290	0.026	0.004	0.143	11.130	0.160	0.005	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
55.64	9.29	20.82	13.74	0.02	0.00	15,580.41

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
20:07	Charge					
20:08	Chem T1					
20:11	Sample		1.2647			6145
20:12	Temp	2884				
20:13	Decarb					
20:14	AddsWiz					
20:42	Sample		0.0148	70455		83622
20:44	Temp	3038				
20:45	Decarb					
20:49	Chem A1					
21:02	Reduce					
21:02	AddsWiz					
21:09	Sample		0.0034	82362		175733
21:13	Temp	3122				
21:17	Reduce					
21:17	Chem A2					
21:19	Sample		0.0078	82362		183385
21:20	Tap					

Tap Heat	05/19/04 21:20	<b>TOTALS</b>	<b>82362</b>	<b>0</b>	<b>183481</b>
Charge Heat	05/19/04 20:07	Transfer Wt	234,000		
<b>Charge - Tap</b>	<b>72</b>	<b>Tap Wt</b>	<b>234,190</b>		

ADDITIONS	Recipe1	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	Total
Al					900	600	1,500
Dolo				3,400			3,400
FeCrSi					616		616
FeSi	300					800	1,100
HCFeCr			2,800				2,800
Lime		5,000		3,000			8,000
<b>Total</b>	<b>300</b>	<b>5,000</b>	<b>2,800</b>	<b>6,400</b>	<b>1,516</b>	<b>1,400</b>	<b>17,416</b>

Heat # 246992 Grade 409S2 Operator jnichols  
 Practice CRSS LCLN Slag ANY SS GRADE Heat Created 05/19/04 21:22  
 Lining ID April#2 04 Lining Minutes 1244 Heats 167 Min. Weight 200,000  
 Addswiz Oxygen Estimate 62770 TapToCharge 2.237333

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.004				0.100	11.050			
Max	0.015			0.010	0.200	11.250			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	1.221	0.290	0.025	0.053	0.152	9.870	0.150	0.004	0.015
A1	0.021	0.270	0.023	0.032	0.010	10.060	0.160	0.004	0.002
A2	0.009	0.310	0.024	0.003	0.047	11.100	0.150	0.005	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
59.27	9.74	16.99	13.50	0.00	0.00	15,268.07

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
21:22	Charge					
21:23	Chem T1					
21:25	Sample		1.2210			6608
21:27	Temp	2863				
21:28	Decarb					
21:28	Addswiz					
21:56	Sample		0.0148	72608		81673
21:58	Temp	3083				
21:59	Decarb					
22:09	Chem A1					
22:11	Reduce					
22:11	Addswiz					
22:18	Sample		0.0051	77351		158460
22:22	Temp	3073				
22:26	Chem A2					
22:26	Reduce					
22:28	Sample		0.0088	77351		163554
22:29	Tap					

Tap Heat	05/19/04 22:29		<b>TOTALS</b>	<b>77351</b>	<b>0</b>	<b>163663</b>
Charge Heat	05/19/04 21:22	Transfer Wt	232,000			
<b>Charge - Tap</b>	<b>67</b>	<b>Tap Wt</b>	<b>235,916</b>			

ADDITIONS	Recipe1	Recipe2	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	Total
1006	1,500							1,500
Al						1,000	450	1,450
Dolo					3,500			3,500
FeCrSi						1,000		1,000
FeSi		600					350	950
HCFeCr				4,000				4,000
LCCr		700						700
Lime			5,000		3,000			8,000
<b>Total</b>	<b>1,500</b>	<b>1,300</b>	<b>5,000</b>	<b>4,000</b>	<b>6,500</b>	<b>2,000</b>	<b>800</b>	<b>21,100</b>

Heat # 246993      Grade 409S2      Operator jnichols  
 Practice CRSS LCLN      Slag ANY SS GRADE      Heat Created 05/19/04 22:30  
 Lining ID April#2 04      Lining Minutes 1311      Heats 168      Min. Weight 200,000

AddsWiz Oxygen Estimate 72507      TapToCharge 1.558333

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.004				0.100	11.050			
Max	0.015			0.010	0.200	11.250			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	1.123	0.340	0.030	0.047	0.170	9.380	0.140	0.006	0.012
A1	0.031	0.300	0.024	0.039	0.010	10.040	0.150	0.004	0.002
A2	0.011	0.350	0.024	0.003	0.209	11.000	0.140	0.006	0.004

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
54.97	8.24	21.86	14.48	0.00	0.00	15,733.01

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
22:30	Charge					
22:32	Chem T1					
22:34	Sample		1.1233			6708
22:35	Temp	2805				
22:35	AddsWiz					
22:36	Decarb					
23:05	Sample		0.0148	76200		81759
23:06	Temp	3048				
23:08	Decarb					
23:10	Chem A1					
23:20	Reduce					
23:20	AddsWiz					
23:27	Sample		0.0059	82297		156354
23:31	Temp	3043				
23:34	Chem A2					
23:35	Reduce					
23:36	Sample		0.0109	82297		161991
23:37	Tap					

Tap Heat	05/19/04 23:37		<b>TOTALS</b>	<b>82297</b>	<b>0</b>	<b>162100</b>
Charge Heat	05/19/04 22:30	Transfer Wt	233,000			
<b>Charge - Tap</b>	<b>67</b>	<b>Tap Wt</b>	<b>239,806</b>			

**ADDITIONS**

	Recipe1	Recipe2	Recipe3	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	Total
1006	300		1,000				1,500		2,800
Al							1,175	400	1,575
Dolo						3,000			3,000
FeCrSi							1,000		1,000
FeSi		175					450	300	925
HCFeCr					5,625				5,625
LCCr		1,200							1,200
Lime				5,000		3,000			8,000
<b>Total</b>	<b>300</b>	<b>1,375</b>	<b>1,000</b>	<b>5,000</b>	<b>5,625</b>	<b>6,000</b>	<b>4,125</b>	<b>700</b>	<b>24,125</b>



Heat # 246994      Grade 409S2      Operator jnichols  
 Practice CRSS LCLN      Slag ANY SS GRADE      Heat Created 05/19/04 23:38  
 Lining ID April#2 04      Lining Minutes 1378      Heats 169      Min. Weight 200,000

AddsWiz Oxygen Estimate 66721

TapToCharge 1.45

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.004				0.100	11.050			
Max	0.015			0.010	0.200	11.250			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	1.066	0.330	0.024	0.043	0.172	9.160	0.150	0.007	0.014
A1	0.033	0.310	0.021	0.024	0.009	10.140	0.160	0.005	0.002
A2	0.009	0.360	0.021	0.008	0.140	11.340	0.160	0.005	0.004

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
53.01	5.85	23.72	16.90	0.01	0.00	15,326.78

Time	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
23:39	Charge					
23:39	Chem T1					
23:42	Sample		1.0655			5320
23:43	Temp	2789				
23:43	AddsWiz					
23:44	Decarb					
0:12	Sample		0.0148	74717		78605
0:14	Temp	3019				
0:14	Decarb					
0:18	Chem A1					
0:28	Reduce					
0:28	AddsWiz					
0:34	Sample		0.0059	83750		152677
0:38	Temp	3095				
0:42	Chem A2					
0:44	Chem A2					
0:44	Reduce					
0:46	Sample		0.0095	83750		159257
0:47	Tap					

Tap Heat	05/20/04 0:47		<b>TOTALS</b>	<b>83750</b>	<b>0</b>	<b>159362</b>
Charge Heat	05/19/04 23:39	Transfer Wt	229,000			
<b>Charge - Tap</b>	<b>68</b>	<b>Tap Wt</b>	<b>237,513</b>			

**ADDITIONS**

	Recipe1	Recipe2	Recipe3	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	Total
1006	300	1,500	1,000				1,500		4,300
Al							1,100	700	1,800
Dolo						2,000			2,000
FeCrSi							1,000		1,000
FeSi		350					150	650	1,150
HCFeCr					6,374				6,374
LCCr		500							500
Lime				5,000		3,000			8,000
<b>Total</b>	<b>300</b>	<b>2,350</b>	<b>1,000</b>	<b>5,000</b>	<b>6,374</b>	<b>5,000</b>	<b>3,750</b>	<b>1,350</b>	<b>25,124</b>

Heat # 246995      Grade 409S2      Operator jnichols  
 Practice CRSS LCLN      Slag ANY SS GRADE      Heat Created 05/20/04 00:48  
 Lining ID April#2 04      Lining Minutes 1446      Heats 170      Min. Weight 200,000

AddsWiz Oxygen Estimate 14025      TapToCharge 1.683333

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.004				0.100	11.050			
Max	0.015			0.010	0.200	11.250			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	1.156	0.330	0.029	0.049	0.228	9.490	0.140	0.006	0.015
A1	0.031	0.280	0.023	0.038	0.009	10.540	0.150	0.004	0.002
A2	0.009	0.330	0.024	0.003	0.171	11.420	0.150	0.005	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
54.48	6.00	22.95	13.82	2.62	0.00	14,875.93

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
0:48	Charge					
0:49	Chem T1					
0:51	Sample		1.1557			5506
0:53	Temp	2800				
0:53	AddsWiz					
0:54	Decarb					
1:21	Sample		0.0148	74799		77818
1:23	Temp	3040				
1:24	Decarb					
1:29	Chem A1					
1:38	Reduce					
1:39	AddsWiz					
1:39	AddsWiz					
1:39	AddsWiz					
1:46	Sample		0.0054	82790		160007
1:50	Temp	3064				
1:55	Chem A2					
1:57	Reduce					
1:57	Chem A2					
1:59	Sample		0.0096	82790		165050
1:59	Tap					

Tap Heat	05/20/04	1:59	<b>TOTALS</b>	<b>82790</b>	<b>0</b>	<b>165152</b>
Charge Heat	05/20/04	0:48	Transfer Wt	232,000		
<b>Charge - Tap</b>	<b>71</b>		<b>Tap Wt</b>	<b>236,423</b>		

**ADDITIONS**

	Recipe1	Recipe2	Recipe3	Recipe4	Recipe5	WizDec0 1	WizRed0 1	Total
1006		300			500		1,500	2,300
Al				500			950	1,450
Dolo	2,000		1,500					3,500
FeCrSi							1,000	1,000
FeSi				400	250		147	797
HCFeCr						5,103		5,103
LCCr								
Lime	3,000		3,000					6,000
<b>Total</b>	<b>5,000</b>	<b>300</b>	<b>4,500</b>	<b>900</b>	<b>750</b>	<b>5,103</b>	<b>3,597</b>	<b>20,150</b>

Heat # 246996      Grade 1005S1      Operator jnichols  
 Practice Castrip      Slag LCLNCarbon      Heat Created 05/20/04 02:02  
 Lining ID April#2 04      Lining Minutes 1517      Heats 171      Min. Weight 200,000

AddsWiz Oxygen Estimate

TapToCharge 7.166667

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.010	0.250			0.150				
Max	0.040	0.450			0.200				
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
F1	0.107	0.130	0.012	0.065	0.010	0.781	0.050	0.007	0.002
T1	0.051	0.090	0.010	0.064	0.001	0.563	0.052	0.009	0.002
A1	0.013	0.590	0.012		0.415	0.579	0.053	0.004	0.003
A2	0.013	0.590	0.012		0.381	0.587	0.052	0.004	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
52.80	9.57	11.48	25.69	0.00	0.00	6,805.43

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
2:06	Chem T1					
2:07	Charge					
2:09	Decarb					
2:15	Reduce					
2:22	Sample		0.0401	12346		37405
2:27	Temp	3007				
2:28	Chem A1					
2:29	Fuel %Al					
2:30	Reduce					
2:30	Reduce					
2:33	Sample		0.0141	14142		47833
2:35	Temp	3011				
2:38	Chem A2					
2:38	Fuel %Al					
2:39	Reduce					
2:42	Sample		0.0130	15112		56695
2:42	Tap					

Tap Heat	05/20/04	2:42	<b>TOTALS</b>	<b>15112</b>	<b>0</b>	<b>56889</b>
Charge Heat	05/20/04	2:07	Transfer Wt	232,997		
<b>Charge - Tap</b>	<b>36</b>		<b>Tap Wt</b>	<b>235,465</b>		

ADDITIONS

	Recipe1	Recipe2	Recipe4	Recipe5	Recipe6	Total
1006					100	100
Al	500	800				1,300
Dolo			1,500			1,500
FeSi		1,200				1,200
Lime			3,000			3,000
Med C		1,300		100		1,400
<b>Total</b>	<b>500</b>	<b>3,300</b>	<b>4,500</b>	<b>100</b>	<b>100</b>	<b>8,500</b>

Heat # 246997      Grade 1005S1      Operator jnichols  
 Practice Castrip      Slag LCLNCarbon      Heat Created 05/20/04 02:47  
 Lining ID April#2 04      Lining Minutes 1553      Heats 172      Min. Weight 200,000

AddsWiz Oxygen Estimate

TapToCharge 12.73333

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.010	0.250			0.150				
Max	0.040	0.450			0.200				
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
F1	0.051	0.050	0.003	0.037		0.135	0.022	0.008	0.002
L1	0.012	0.570	0.004		0.319	0.165	0.023	0.004	0.002
A1	0.012	0.570	0.004		0.316	0.164	0.022	0.004	0.002

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
57.16	10.24	12.75	19.73	0.00	0.00	6,322.28

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
2:48	Chem F1					
2:55	Charge					
2:58	Decarb					
3:03	Reduce					
3:11	Sample		0.0289	12162		38147
3:17	Temp	2989				
3:20	Chem A1					
3:20	Reduce					
3:22	Sample		0.0136	12162		43471
3:23	Tap					

Tap Heat	05/20/04 3:23	<b>TOTALS</b>	<b>12162</b>	<b>0</b>	<b>43598</b>
Charge Heat	05/20/04 2:55	Transfer Wt	236,000		
<b>Charge - Tap</b>	<b>28</b>	<b>Tap Wt</b>	<b>238,596</b>		

ADDITIONS	Recipe1	Recipe3	Recipe4	Total
Al	500	850		1,350
FeSi		1,200		1,200
Med C		1,400	150	1,550
<b>Total</b>	<b>500</b>	<b>3,450</b>	<b>150</b>	<b>4,100</b>

NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 141252 FULL WEIGHT: \_\_\_\_\_ DATE: 5/20 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: TJM KWH START: \_\_\_\_\_  
 LADLE NO: \_\_\_\_\_ WEIGHT TAPPED: 125 AIM GRADE: \_\_\_\_\_ KWH USED: 50  
 LAST HEAT TAPPED: 5:44 HEATS ON DELTA: 198 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY											TOTAL RESID			
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V		N		
F-1		<u>048</u>				<u>067</u>										
F-2																
F-3																
F-4																

CHARGE BKT N1 BKT N2

HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
<u>CASTING HEAT</u>		
SCRAP TOTAL	<u>76</u>	<u>54.5</u>
BURNT LIME	<u>2000</u>	
DOLO LIME	<u>5000</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Carbon Injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Time	Temp
_____	<u>3040</u>	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)
_____	_____
_____	_____

TAP TIME: 6:33

OXYGEN PPM 859

REMARKS (list)

\_\_\_\_\_

HEAT NO: 141254  
 HEATS ON BOTTOM: \_\_\_\_\_  
 LADLE NO: 11  
 LAST HEAT TAPPED: 7:18

FULL WEIGHT: \_\_\_\_\_  
 TARE WEIGHT: \_\_\_\_\_  
 WEIGHT TAPPED: 731  
 HEATS ON DELTA: 200

DATE: 5/20<sup>21</sup> KWH END: \_\_\_\_\_  
 MELTER: TLM KWH START: \_\_\_\_\_  
 AIM GRADE: \_\_\_\_\_ KWH USED: 47  
 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY												TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N			
F-1		<u>036</u>			<u>058</u>											
F-2																
F-3																
F-4																

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	<u>75</u>	<u>54</u>
BURNT LIME	<u>2000</u>	
DOLO LIME	<u>5000</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Carbon Injector on	_____	_____	_____ Lbs. Inj

LADLE ALLOYS	WEIGHT(LBS)

Time	Temp	Time	Temp
_____	<u>3027</u>	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

TAP TIME: 8:03

OXYGEN PPM: 1007  
 REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



NUCOR STEEL - CRANFORDVILLE  
EBT HEAT RECORD

HEAT NO: 141255 FULL WEIGHT: \_\_\_\_\_ DATE: 5/20 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: FIM KWH START: \_\_\_\_\_  
 LADLE NO: 9 WEIGHT TAPPED: 130 AIM GRADE: \_\_\_\_\_ KWH USED: 49  
 \*AST HEAT TAPPED: 8:03 HEATS ON DELTA: 201 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY												TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N			
F-1		<u>038</u>				<u>061</u>										
F-2																
F-3																
F-4																

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	<u>75</u>	<u>60</u>
BURNT LIME	<u>2000</u>	
DOLO LIME	<u>5000</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Vulcan lance on	_____	_____	_____ Lbs. Inj
Carbon Injector on	_____	_____	_____ Lbs. Inj

LADLE ALLOYS	WEIGHT(LBS)

Time	Temp	Time	Temp
_____	<u>5026</u>	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM 905

TAP TIME: 8:54

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 141256 FULL WEIGHT: \_\_\_\_\_ DATE: 5/20 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: TIM KWH START: \_\_\_\_\_  
 LADLE NO: \_\_\_\_\_ WEIGHT TAPPED: 129 AIM GRADE: \_\_\_\_\_ KWH USED: 8750  
 LAST HEAT TAPPED: 8:54 HEATS ON DELTA: 202 PATCH: \_\_\_\_\_ LBS(EST) \_\_\_\_\_

SAMPLE	TIME	CHEMISTRY												TOTAL RESID	
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N		
F-1		<u>034</u>				<u>063</u>									
F-2															
F-3															
F-4															

CHARGE BKT #1 BKT #2

HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	<u>75</u>	<u>60.5</u>
BURNT LIME	<u>2000</u>	
DOLO LIME	<u>5000</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Vulcan lance on	_____	_____	_____ CF O
Carbon Injector on	_____	_____	_____ Lbs. Inj

LADLE ALLOYS	WEIGHT(LBS)

Time	Temp	Time	Temp
_____	<u>2953</u>	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM 979

TAP TIME: 9:41

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

HEAT NO: 141257 FULL WEIGHT: \_\_\_\_\_ DATE: 5/21 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: mye's KWH START: \_\_\_\_\_  
 LADLE NO: 5 WEIGHT TAPPED: 24000 AIM GRADE: \_\_\_\_\_ KWH USED: 50  
 LAST HEAT TAPPED: 9:47 HEATS ON DELTA: 203 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY											TOTAL RESID			
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V		N		
F-1		<u>030</u>				<u>065</u>		<u>076</u>								
F-2																
F-3																
F-4																

CHARGE BKT #1 BKT #2

HOT HEEL		
BUSHING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	<u>75</u>	<u>60</u>
BURNT LIME	<u>2000</u>	
DOLO LIME	<u>5000</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Carbon Injector on	_____	_____	_____ Lbs. Inj

LADLE ALLOYS WEIGHT(LBS)


Time	Temp	Time	Temp
_____	<u>2999</u>	<u>072</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

TAP TIME: 1041

OXYGEN PPM 1198

REMARKS (list)

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 141258 FULL WEIGHT: \_\_\_\_\_ DATE: 5-21 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: MYERS KWH START: \_\_\_\_\_  
 LADLE NO: 4 WEIGHT TAPPED: 2000 AIM GRADE: \_\_\_\_\_ KWH USED: 46  
 LAST HEAT TAPPED: 10:41 HEATS ON DELTA: 204 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID	
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N			
F-1		<u>030</u>				<u>064</u>		<u>085</u>								
F-2																
F-3																
F-4																

CHARGE BKT #1 BKT #2

HOT HEEL																
BUSHELING																
SKULLS																
BUNDLES																
P/S																
SHREDDED																
		<u>150</u>	<u>104</u>													
SCRAP TOTAL			<u>127 ten</u>													
BURNT LIME		<u>2000</u>														
DOLO LIME		<u>5000</u>														
CRG. CARBON		<u>1500</u>														

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Vulcan lance on	_____	_____	
Carbon Injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Time	Temp
_____	<u>3050</u>	<u>023</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)
<u>1</u>	

OXYGEN PPM 1100

TAP TIME: 1129

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 141259 FULL WEIGHT: \_\_\_\_\_ DATE: 5-21 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: NY45 KWH START: \_\_\_\_\_  
 LADLE NO: 11 WEIGHT TAPPED: 26000 AIM GRADE: \_\_\_\_\_ KWH USED: 49  
 LAST HEAT TAPPED: 1429 HEATS ON DELTA: 205 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N				
F-1		041				058		087									
F-2																	
F-3																	
F-4																	

CHARGE BKT #1 BKT #2

HOT HEEL																	
BUSHELING																	
SKULLS																	
BUNDLES																	
P/S																	
SHREDDER																	
		151	120														
SCRAP TOTAL																	
BURNT LIME		2000															
DOLO LIME		5000															
CRG. CARBON		1500															

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	6 Tap no.
	_____	_____	Tap no.
	_____	_____	Tap no.
Oxy-fuel burners	_____	_____	CF
	_____	_____	CF CH
Vulcan lance on	_____	_____	CF 0
Drop 2nd bucket	_____	_____	
Power on	_____	_____	6 Tap no.
	_____	_____	Tap no.
	_____	_____	CF
Oxy-fuel burners	_____	_____	CF CH
	_____	_____	CF 0
Vulcan lance on	_____	_____	
Carbon Injector on	_____	_____	Lbs. Inj

Time	Temp	Time	Temp
_____	3004	027	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)
1	

TAP TIME: 1211

OXYGEN PPM 993

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

NUCOR STEEL - CRAWFORDSVILLE

EBT HEAT RECORD

HEAT NO: 141260 FULL WEIGHT: \_\_\_\_\_ DATE: 5-21 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: MYERS KWH START: \_\_\_\_\_  
 LADLE NO: 3 WEIGHT TAPPED: 254000 AIM GRADE: \_\_\_\_\_ KWH USED: 48  
 LAST HEAT TAPPED: 124 HEATS ON DELTA: 206 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID	
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N			
F-1		<u>042</u>				<u>066</u>		<u>076</u>								
F-2																
F-3																
F-4																

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	<u>150</u>	<u>122</u>
SCRAP TOTAL		<u>136 tons</u>
BURNT LIME	<u>2000</u>	
DOLO LIME	<u>5000</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	<u>6-8</u> Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	
Power on	_____	_____	<u>6-8</u> Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Vulcan lance on	_____	_____	
Carbon Injector on	_____	_____	_____ Lbs. Inj

LADLE ALLOYS	WEIGHT(LBS)

Time	Temp	Time	Temp
_____	<u>2999</u>	<u>026</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM 1046

REMARKS (list) \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

TAP TIME: 1300

NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 14261 FULL WEIGHT: \_\_\_\_\_ DATE: 5-21 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: Myers KWH START: \_\_\_\_\_  
 LADLE NO: 12 WEIGHT TAPPED: 262000 AIM GRADE: \_\_\_\_\_ KWH USED: 52  
 LAST HEAT TAPPED: 1300 HEATS ON DELTA: 207 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N				
F-1		<u>049</u>					<u>058</u>		<u>070</u>								
F-2																	
F-3																	
F-4																	

CHARGE BKT #1 BKT #2

HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	<u>150</u>	<u>120</u> <u>135 ton</u>
BURNT LIME	<u>2000</u>	
DOLO LIME	<u>5000</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	<u>6-8</u> Tap no.
	_____	_____	Tap no.
	_____	_____	Tap no.
Oxy-fuel burners	_____	_____	CF
	_____	_____	CF CH
Vulcan lance on	_____	_____	CF O
Drop 2nd bucket	_____	_____	
Power on	_____	_____	<u>6-8</u> Tap no.
	_____	_____	Tap no.
Oxy-fuel burners	_____	_____	CF
	_____	_____	CF CH
Vulcan lance on	_____	_____	CF O
Carbon Injector on	_____	_____	Lbs. Inj

Time	Temp	Time	Temp
_____	<u>2973</u>	<u>029</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS WEIGHT(LBS)


TAP TIME: 1347

REMARKS (list)

OXYGEN PPM 895

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

NUCOR STEEL - CRAWFORDSVILLE

EBT HEAT RECORD

HEAT NO: 141262 FULL WEIGHT: \_\_\_\_\_ DATE: 5-21 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: Myers KWH START: \_\_\_\_\_  
 LADLE NO: 9 WEIGHT TAPPED: 258000 AIM GRADE: \_\_\_\_\_ KWH USED: 500  
 LAST HEAT TAPPED: 1397 HEATS ON DELTA: 208 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID	
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N			
F-1		<u>040</u>				<u>053</u>		<u>080</u>								
F-2																
F-3																
F-4																

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	<u>150</u>	<u>120</u>
SCRAP TOTAL		<u>13560</u>
BURNT LIME	<u>2000</u>	
DOLO LIME	<u>5000</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	<u>6-8</u> Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	<u>6-8</u> Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Vulcan lance on	_____	_____	_____ CF O
Carbon Injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Time	Temp
_____	<u>2940</u>	<u>026</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM 931

LADLE ALLOYS	WEIGHT(LBS)
<u>1</u>	

TAP TIME: 1530

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
Add B phase - Lewis  
Probe B phase - Lewis



NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 141263  
HEATS ON BOTTOM: \_\_\_\_\_  
LADLE NO: 4  
LAST HEAT TAPPED: 1530

FULL WEIGHT: \_\_\_\_\_  
TARE WEIGHT: \_\_\_\_\_  
WEIGHT TAPPED: 210000  
HEATS ON DELTA: 209

DATE: 5-21 KWH END: \_\_\_\_\_  
MELTER: 114019 KWH START: \_\_\_\_\_  
AIM GRADE: \_\_\_\_\_ KWH USED: 50  
PATCH: \_\_\_\_\_ LBS(EST)

CHEMISTRY

SAMPLE	TIME	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N	TOTAL RESID
F-1		<u>050</u>			<u>059</u>		<u>089</u>							
F-2														
F-3														
F-4														

CHARGE BKT #1 BKT #2

HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	<u>150</u>	<u>119</u>
SCRAP TOTAL		<u>134.5 tons</u>
BURNT LIME	<u>2000</u>	
DOLO LIME	<u>5000</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Carbon Injector on	_____	_____	_____ Lbs. Inj

LADLE ALLOYS WEIGHT(LBS)


Time	Temp	Time	Temp
_____	<u>585</u>	<u>029</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM 1100

TAP TIME: 1618

REMARKS (list)

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 141264 FULL WEIGHT: \_\_\_\_\_ DATE: 5-21 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: Myers KWH START: \_\_\_\_\_  
 LADLE NO: 10 WEIGHT TAPPED: 248000 AIM GRADE: \_\_\_\_\_ KWH USED: 49  
 LAST HEAT TAPPED: 1618 HEATS ON DELTA: 210 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID	
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N			
F-1		<u>0.11</u>			<u>0.02</u>		<u>0.84</u>									
F-2																
F-3																
F-4																

CHARGE BKT #1 BKT #2

HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	<u>150</u>	<u>121</u>
SCRAP TOTAL		<u>135.5</u>
BURNT LINE	<u>2000</u>	
DOLO LINE	<u>5000</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	<u>6</u> Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	<u>6</u> Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF 0
Vulcan lance on	_____	_____	_____ CF 0
Carbon Injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Time	Temp
_____	<u>3039</u>	<u>038</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)
<u>1</u>	

OXYGEN PPM 740

TAP TIME: 1705

REMARKS (list)  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

MUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 141265 FULL WEIGHT: \_\_\_\_\_ DATE: 8-21 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: myers KWH START: \_\_\_\_\_  
 LADLE NO: 12 WEIGHT TAPPED: 26000 AIM GRADE: \_\_\_\_\_ KWH USED: 48  
 LAST HEAT TAPPED: 1705 HEATS ON DELTA: 211 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY												TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N			
F-1		<u>0.33</u>				<u>0.58</u>		<u>0.79</u>								
F-2																
F-3																
F-4																

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	<u>154</u>	<u>106</u>
BURNT LIME	<u>2000</u>	<u>130</u>
DOLO LIME	<u>5000</u>	
CRG. CARBON	<u>150</u>	

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
Vulcan lance on	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
Vulcan lance on	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Carbon Injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Time	Temp
_____	<u>3009</u>	<u>829</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)
<u>1</u>	

TAP TIME: 1753

OXYGEN PPM 442  
 REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 141266 FULL WEIGHT: \_\_\_\_\_ DATE: 5-21 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: Myers KWH START: \_\_\_\_\_  
 LADLE NO: 1 WEIGHT TAPPED: 260000 AIM GRADE: \_\_\_\_\_ KWH USED: 48  
 \*AST HEAT TAPPED: 1753 HEATS ON DELTA: 212 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY												TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N			
F-1		<u>041</u>				<u>063</u>		<u>028</u>								
F-2																
F-3																
F-4																

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	<u>152</u>	<u>118</u>
SCRAP TOTAL		<u>13540</u>
BURNT LINE	<u>2000</u>	
DOLO LINE	<u>5000</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Carbon Injector on	_____	_____	_____ Lbs. Inj

LADLE ALLOYS	WEIGHT(LBS)
<u>1</u>	

Time	Temp	Time	Temp
_____	<u>2518</u>	<u>032</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

TAP TIME: 1840

REMARKS (list)

OXYGEN PPM 064

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 24-7031 FULL WEIGHT: \_\_\_\_\_ DATE: 5-20-04 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: 12M KWH START: \_\_\_\_\_  
 LADLE NO: 9 WEIGHT TAPPED: 268000 AIM GRADE: 1006 KWH USED: 47  
 LAST HEAT TAPPED: 0718 HEATS ON DELTA: 130 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY											TOTAL RESID			
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V		N		
F-1		040				007	077									48
F-2																
F-3																
F-4																

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	152	110
BURNT LIME	1500	
DOLO LIME	5000	
CRG. CARBON	-0-	

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF 0
Vulcan lance on	_____	_____	_____ CF 0
Carbon Injector on	_____	_____	_____ Lbs. Inj

131

Time	Temp	Time	Temp
_____	3037	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)

OXYGEN PPM 837

TAP TIME: 08:06

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 24-7032 FULL WEIGHT: \_\_\_\_\_ DATE: 5-20-04 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: 714 KWH START: \_\_\_\_\_  
 LADLE NO: 7 WEIGHT TAPPED: 258000 AIM GRADE: 1006 KWH USED: 49  
 LAST HEAT TAPPED: 08106 HEATS ON DELTA: 131 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY												TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N			
F-1		036			060		089									17
F-2																
F-3																
F-4																

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	152	120
BURNT LINE	1500	
DOLO LINE	5000	
CRG. CARBON	-0-	

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF 0
Vulcan lance on	_____	_____	_____ Lbs. Inj
Carbon Injector on	_____	_____	

136

Time	Temp	Time	Temp
_____	2961	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)

OXYGEN PPM 731

TAP TIME: 08:54

REMARKS (list)  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

HEAT NO: 24-7033 FULL WEIGHT: \_\_\_\_\_ DATE: 5-20-04 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: 71M KWH START: \_\_\_\_\_  
 LADLE NO: 12 WEIGHT TAPPED: 260000 AIM GRADE: W06 KWH USED: 48  
 LAST HEAT TAPPED: 08154 HEATS ON DELTA: 132 PATCH: 1200 LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID	
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N			
F-1		.04			.006		.10								.006	.15
F-2																
F-3																
F-4																

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	<u>155</u>	<u>120</u>
BURNT LIME	<u>1800</u>	
DOLO LIME	<u>5000</u>	
CRG. CARBON	<u>7500</u>	

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Vulcan lance on	_____	_____	_____ Lbs. Inj
Carbon injector on	_____	_____	

138

Time	Temp	Time	Temp
_____	<u>2962</u>	<u>1:027</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)
_____	_____
_____	_____

TAP TIME: 11:08

OXYGEN PPM 99

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
12 MIN.  
 \_\_\_\_\_

EBT HEAT RECORD

HEAT NO: 24.7034 FULL WEIGHT: \_\_\_\_\_ DATE: 5-21-04 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: DR KWH START: \_\_\_\_\_  
 LADLE NO: 10 WEIGHT TAPPED: 250000 AIM GRADE: 1008D2 KWH USED: 51  
 LAST HEAT TAPPED: 10:08 HEATS ON DELTA: 133 PATCH: 1 LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N		
F-1		<u>.03</u>			<u>.06</u>		<u>.11</u>							<u>.006</u>	<u>.17</u>
F-2															
F-3															
F-4															

CHARGE	BKT N1	BKT N2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDER		
SCRAP TOTAL	<u>150</u>	<u>130</u>
BURNT LIME	<u>1500</u>	
DOLO LIME	<u>4700</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Carbon Injector on	_____	_____	_____ Lbs. Inj

LADLE ALLOYS	WEIGHT(LBS)

Time	Temp	Time	Temp
_____	<u>2975</u>	<u>028</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM 921

TAP TIME: 10:56

REMARKS (list)  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 24-7035 FULL WEIGHT: \_\_\_\_\_ DATE: 5-24-04 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: DR KWH START: \_\_\_\_\_  
 LADLE NO: 9 WEIGHT TAPPED: 270000 AIM GRADE: 1008 PE KWH USED: 54  
 LAST HEAT TAPPED: 10:56 HEATS ON DELTA: 134 PATCH: \_\_\_\_\_ LBS(EST) \_\_\_\_\_

SAMPLE	TIME	CHEMISTRY													TOTAL RESID
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N		
F-1		.03			.06		.10							.007	17
F-2															
F-3															
F-4															

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	<u>160</u>	<u>130</u>
BURNT LIME	<u>1500</u>	
DOLO LIME	<u>4700</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Vulcan lance on	_____	_____	_____ Lbs. Inj
Carbon Injector on	_____	_____	

Time	Temp	Time	Temp
_____	<u>3066</u>	<u>604</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)
_____	_____
_____	_____

OXYGEN PPM 1253  
 REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

TAP TIME: 11:48

NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 24-7036 FULL WEIGHT: \_\_\_\_\_ DATE: 5-21-04 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: DR KWH START: \_\_\_\_\_  
 LADLE NO: 0 WEIGHT TAPPED: 238000 AIM GRADE: 1008 KWH USED: 53  
 LAST HEAT TAPPED: 11:48 HEATS ON DELTA: 135 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY												TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N			
F-1		.04			.07		.08								.006	.17
F-2																
F-3																
F-4																

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	106	120
BURNT LIME	1500	
DOLO LIME	4700	
CRG. CARBON	1500	

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ Tap no.
Vulcan lance on	_____	_____	_____ CF
			_____ CF CH
			_____ CF O
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
Vulcan lance on	_____	_____	_____ CF CH
			_____ CF O
Carbon injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Time	Temp
_____	3070	1:03a	_____
CASTLE			
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM 946

LADLE ALLOYS	WEIGHT(LBS)

TAP TIME: 12:34

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

NUCOR STEEL - CRAWFORDSVILLE

EBT HEAT RECORD

HEAT NO: 24-7037 FULL WEIGHT: \_\_\_\_\_ DATE: 5-21-04 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: DR KWH START: \_\_\_\_\_  
 LADLE NO: 7 WEIGHT TAPPED: 260000 AIM GRADE: 1008 KWH USED: 54  
 LAST HEAT TAPPED: 12/37 HEATS ON DELTA: 136 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY											TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V		N	
F-1		.08			.06		.07							.004	.10
F-2															
F-3															
F-4															

CHARGE BKT #1 BKT #2

HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	<u>1100</u>	<u>120</u>
BURNT LIME	<u>1500</u>	
DOLO LIME	<u>4700</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Carbon Injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Time	Temp
_____	<u>2993</u>	<u>033</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS WEIGHT(LBS)


OXYGEN PPM 268

TAP TIME: 1121

REMARKS (list)

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 24-7038 FULL WEIGHT: \_\_\_\_\_ DATE: 5-21-04 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: DR KWH START: \_\_\_\_\_  
 LADLE NO: 0 WEIGHT TAPPED: 216000 AIM GRADE: 1008 KWH USED: 44  
 LAST HEAT TAPPED: 1.21 HEATS ON DELTA: 137 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY											TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V		N	
F-1		.04			.06		.09							.006	.19
F-2															
F-3															
F-4															

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	<u>1600</u>	<u>600</u>
BURNT LIME	<u>1500</u>	
DOLO LIME	<u>1700</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Vulcan lance on	_____	_____	_____ Lbs. Inj
Carbon Injector on	_____	_____	

LADLE ALLOYS	WEIGHT(LBS)

Time	Temp	Time	Temp
_____	<u>3087</u>	<u>.037</u>	_____
_____			
_____			
_____			
_____			
_____			

CASTLE TP

OXYGEN PPM 849

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

TAP TIME: 2:02

NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 24-7039 FULL WEIGHT: \_\_\_\_\_ DATE: 5-24-04 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: DR KWH START: \_\_\_\_\_  
 LADLE NO: 5 WEIGHT TAPPED: 244000 AIM GRADE: 1008 KWH USED: 54  
 LAST HEAT TAPPED: 0.92 HEATS ON DELTA: 138 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID	
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N			
F-1		.03			.06		.10								.007	.20
F-2																
F-3																
F-4																

CHARGE BKT N1 BKT N2

HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	160	120
SCRAP TOTAL	80 Ton	60 Ton
BURNT LIME	1500	
DOLO LIME	4700	
CRG. CARBON	1500	

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Carbon Injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Time	Temp
_____	3021	.024	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS WEIGHT(LBS)


TAP TIME: 2:50

REMARKS (list)

OXYGEN PPM 1077

Charge crane - 2 min

NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 24-7040 FULL WEIGHT: \_\_\_\_\_ DATE: 5-21-04 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: DR KWH START: \_\_\_\_\_  
 LADLE NO: \_\_\_\_\_ WEIGHT TAPPED: 260000 AIM GRADE: 1008 KWH USED: 52  
 LAST HEAT TAPPED: 0150 HEATS ON DELTA: 139 PATCH: \_\_\_\_\_ LBS(EST)

CHEMISTRY															TOTAL RESID
SAMPLE	TIME	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N		
F-1		.05			.07		.09						.007	.23	
F-2															
F-3															
F-4															

CHARGE BKT #1 BKT #2

HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	80	55
SCRAP TOTAL	160	110
BURNT LIME	1500	
DOLO LIME	4700	
CRG. CARBON	1500	

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF 0
Vulcan lance on	_____	_____	_____ CF 0
Carbon Injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Time	Temp
_____	3029	.030	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)

OXYGEN PPM 939

TAP TIME: 3:42

REMARKS (list) hot panel-2  
Tap 2

NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 24-7041 FULL WEIGHT: \_\_\_\_\_ DATE: 5-21-04 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: DB KWH START: \_\_\_\_\_  
 LADLE NO: 11 WEIGHT TAPPED: 260000 AIM GRADE: 1008 KWH USED: 52  
 LAST HEAT TAPPED: 3:42 HEATS ON DELTA: 140 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY												TOTAL RESID	
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N		
F-1		.02			.06		.10							.007	.18
F-2															
F-3															
F-4															

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	160	110
BURNT LIME	1500	
DOLO LIME	4700	
CRG. CARBON	1500	

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Vulcan lance on	_____	_____	_____ Lbs. Inj
Carbon Injector on	_____	_____	

LADLE ALLOYS	WEIGHT(LBS)

Time	Temp	Time	Temp
_____	13091	.048	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

TAP TIME: 16:34  
4:36

OXYGEN PPM 1091  
 REMARKS (list)  
Set sticks - 8.4 min  
(B phase 204)  
(C phase 203)

NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 287042 FULL WEIGHT: \_\_\_\_\_ DATE: 5-21-05 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: DR KWH START: \_\_\_\_\_  
 LADLE NO: 7 WEIGHT TAPPED: 260000 AIM GRADE: 1008 KWH USED: 51  
 LAST HEAT TAPPED: 4136 HEATS ON DELTA: 191 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY												TOTAL RESID	
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N		
F-1		.04			.06		.11							.007	.79
F-2															
F-3															
F-4															

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	160	120
BURNT LIME	1500	
DOLO LIME	5000	
CRG. CARBON	1500	

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Vulcan lance on	_____	_____	_____ Lbs. Inj
Carbon injector on	_____	_____	

Time	Temp	Time	Temp
_____	3142	033	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM 122

LADLE ALLOYS	WEIGHT(LBS)

TAP TIME: 17:21  
5:21

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 24-7043 FULL WEIGHT: \_\_\_\_\_ DATE: 8-21-04 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: DR KWH START: \_\_\_\_\_  
 LADLE NO: 5 WEIGHT TAPPED: 240000 AIM GRADE: 1008 KWH USED: 49  
 LAST HEAT TAPPED: 5/21 HEATS ON DELTA: 142 PATCH: 2400 LBS(EST)

SAMPLE	TIME	CHEMISTRY												TOTAL RESID	
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N		
F-1		.03			.06		.09							.007	.17
F-2															
F-3															
F-4															

CHARGE BKT #1 BKT #2

HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	<u>100</u>	<u>170</u>
BURNT LIME	<u>1500</u>	
DOLO LIME	<u>5000</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Vulcan lance on	_____	_____	_____ Lbs. Inj
Carbon Injector on	_____	_____	

Time	Temp	Time	Temp
_____	<u>2990</u>	<u>008</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)
_____	_____
_____	_____

OXYGEN PPM 925  
 REMARKS (list) patch - 7min 2400lbs

TAP TIME: 6:16

NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 24-7044 FULL WEIGHT: \_\_\_\_\_ DATE: 5-21-04 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: DR KWH START: \_\_\_\_\_  
 LADLE NO: 9 WEIGHT TAPPED: 252000 AIM GRADE: 1008 KWH USED: \_\_\_\_\_  
 LAST HEAT TAPPED: 6116 HEATS ON DELTA: 143 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY												TOTAL RESID	
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N		
F-1		.04			.07		.09							.006	.17
F-2															
F-3															
F-4															

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	<u>1100</u>	<u>120</u>
BURNT LIME	<u>1500</u>	
DOLO LIME	<u>5000</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Vulcan lance on	_____	_____	_____ Lbs. Inj
Carbon injector on	_____	_____	

Time	Temp	Time	Temp
_____	<u>3025</u>	<u>0321</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)
_____	_____
_____	_____

TAP TIME: 7:07

REMARKS (list)  
 OXYGEN PPM 812  
Set stick - 3.2  
(A phase 18)

NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 24-7045  
WEIGHTS ON BOTTOM: \_\_\_\_\_  
LADLE NO: 11  
LAST HEAT TAPPED: 7:07

FULL WEIGHT: \_\_\_\_\_  
TARE WEIGHT: \_\_\_\_\_  
WEIGHT TAPPED: 20000  
HEATS ON DELTA: 144

DATE: 5-21-04 KWH END: \_\_\_\_\_  
MELTER: DR KWH START: \_\_\_\_\_  
AIM GRADE: 1008 KWH USED: 52  
PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID	
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N			
F-1		.05			.07		.07								.007	.15
F-2																
F-3																
F-4																

CHARGE BKT #1 BKT #2

HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	<u>160</u>	<u>120</u>
BURNT LIME	<u>1500</u>	
DOLO LIME	<u>5000</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Vulcan lance on	_____	_____	_____ Lbs. Inj
Carbon Injector on	_____	_____	

LADLE ALLOYS	WEIGHT(LBS)

Time	Temp	Time	Temp
_____	<u>288.3</u>	<u>036</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

TAP TIME: 7:58

OXYGEN PPM 723

REMARKS (list)  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Heat # 141252      Grade 1005S1      Operator jnichols  
 Practice Castrip      Slag LCLNCarbon      Heat Created 05/21/04 06:43  
 Lining ID April#2 04      Lining Minutes 1717      Heats 179      Min. Weight 200,000

AddsWiz Oxygen Estimate

TapToCharge 398.0123

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.010	0.250			0.150				
Max	0.040	0.450			0.200				
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
F1	0.048	0.100	0.010	0.067		0.048	0.036	0.008	0.002
A1	0.009	0.570	0.011	0.002	0.283	0.070	0.036	0.007	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
57.43	10.26	12.58	19.59	0.00	0.00	6,308.27

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
6:43	Chem F1					
6:56	Charge					
7:03	Decarb					
7:09	Reduce					
7:16	Sample		0.0284	11952		49984
7:23	Temp	2962				
7:24	Chem A1					
7:25	Reduce					
7:26	Sample		0.0103	11952		55513
7:28	Tap					

Tap Heat	05/21/04 7:28		<b>TOTALS</b>	<b>11952</b>	<b>0</b>	<b>55620</b>
Charge Heat	05/21/04 6:56	Transfer Wt	250,000			
<b>Charge - Tap</b>	<b>32</b>	<b>Tap Wt</b>	<b>252,881</b>			

ADDITIONS	Recipe1	Recipe2	Recipe3	Recipe4	Total
Al	850				850
Dolo		1,500			1,500
FeSi	1,200		150	100	1,450
Lime		3,000			3,000
Med C	1,300		150		1,450
<b>Total</b>	<b>3,350</b>	<b>4,500</b>	<b>300</b>	<b>100</b>	<b>8,250</b>

Nucor Steel - Crawfordsville AOD Log

Heat # 141253      Grade 1005S1      Operator jnichols  
 Practice Castrip      Slag LCLNCarbon      Heat Created 05/21/04 07:34  
 Lining ID April#2 04      Lining Minutes 1750      Heats 180      Min. Weight 200,000

AddsWiz Oxygen Estimate

TapToCharge 15.96667

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.010	0.250			0.150				
Max	0.040	0.450			0.200				
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
F1	0.059	0.220	0.013	0.062	0.001	0.051	0.029	0.007	0.002
A1	0.006	0.560	0.013	0.004	0.220	0.076	0.031	0.006	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
57.72	10.34	11.67	20.15	0.00	0.00	6,260.94

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
7:36	Chem F1					
7:44	Charge					
7:49	Decarb					
7:54	Reduce					
8:02	Sample		0.0234	11422		44552
8:06	Temp	3046				
8:12	Chem A1					
8:17	Reduce					
8:20	Sample		0.0076	11422		52290
8:21	Tap					

Tap Heat	05/21/04 8:21		<b>TOTALS</b>	<b>11422</b>	<b>0</b>	<b>52414</b>
Charge Heat	05/21/04 7:44	Transfer Wt	214,023			
<b>Charge - Tap</b>	<b>37</b>	<b>Tap Wt</b>	<b>216,620</b>			

ADDITIONS	Recipe1	Recipe2	Recipe3	Total
Al	800		25	825
FeSi	1,100	225		1,325
Med C	1,000	150		1,150
<b>Total</b>	<b>2,900</b>	<b>375</b>	<b>25</b>	<b>3,300</b>

Heat # 247036      Grade 1005S1      Operator jnichols  
 Practice Castrip      Slag LCLNCarbon      Heat Created 05/21/04 12:33  
 Lining ID April#2 04      Lining Minutes 1787      Heats 182      Min. Weight 200,000

AddsWiz Oxygen Estimate

TapToCharge 270.85

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.010	0.250			0.150				
Max	0.040	0.450			0.200				
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
F1	0.039	0.090	0.007	0.071		0.039	0.029	0.006	0.002
A1	0.010	0.560	0.009	0.001	0.315	0.048	0.029	0.005	0.002

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
60.80	9.43	12.81	16.84	0.00	0.00	6,936.00

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
12:43	WtBath Override					
12:50	Chem F1					
12:52	Charge					
12:58	Decarb					
13:01	Reduce					
13:08	Sample		0.0323	12180		36670
13:14	Temp	2940				
13:20	Chem A1					
13:21	Reduce					
13:23	Sample		0.0108	12180		42551
13:23	Tap					

Tap Heat	05/21/04 13:23		<b>TOTALS</b>	<b>12180</b>	<b>0</b>	<b>42661</b>
Charge Heat	05/21/04 12:52	Transfer Wt	235,990			
<b>Charge - Tap</b>	<b>32</b>	<b>Tap Wt</b>	<b>238,444</b>			

ADDITIONS	Castrip	Recipe1	Recipe2	Total
Al	850	600		1,450
Dolo	1,500			1,500
FeSi	1,200			1,200
Lime	3,700			3,700
Med C	1,300		50	1,350
<b>Total</b>	<b>8,550</b>	<b>600</b>	<b>50</b>	<b>9,200</b>

Nucor Steel - Crawfordsville AOD Log

Heat # 247038      Grade 1005S1      Operator jnichols  
 Practice Castrip      Slag LCLNCarbon      Heat Created 05/21/04 13:28  
 Lining ID April#2 04      Lining Minutes 1818      Heats 183      Min. Weight 200,000

AddsWiz Oxygen Estimate

TapToCharge 56.80433

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.010	0.250			0.150				
Max	0.040	0.450			0.200				
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
F1	0.036	0.070	0.006	0.059		0.037	0.039	0.006	0.001
A1	0.007	0.520	0.008	0.004	0.175	0.045	0.040	0.005	0.002

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
60.21	9.27	12.48	17.99	0.00	0.00	7,061.31

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
14:13	Chem F1					
14:20	Charge					
14:23	WtBath Override					
14:25	Decarb					
14:29	Reduce					
14:35	Sample		0.0286	12643	673	33012
14:43	Temp	2997				
14:45	Chem A1					
14:47	Reduce					
14:49	Sample		0.0091	12643	673	39860
14:49	Tap					
Tap Heat	05/21/04 14:49		<b>TOTALS</b>	<b>12643</b>	<b>673</b>	<b>39983</b>
Charge Heat	05/21/04 14:20	Transfer Wt	220,007			
Charge - Tap	29	Tap Wt	216,522			

ADDITIONS	Castrip	Recipe1	Recipe2	Total
Al	750	500		1,250
Dolo	1,500			1,500
FeSi	1,000		400	1,400
Lime	3,700			3,700
Med C	1,100		200	1,300
<b>Total</b>	<b>8,050</b>	<b>500</b>	<b>600</b>	<b>9,150</b>

