

Type Approval Certificate Extension

This is to certify that Certificate No. 94/00003(E3) for the undernoted products is extended and renumbered as shown.

This certificate is issued to:


PRODUCER	Dubai Cable Company (Private) Limited								
PLACE OF PRODUCTION	P.O. Box 11529 Dubai United Arab Emirates (UAE)								
DESCRIPTION	Flame retardant single power cable XLPE insulated and PVC sheathed.								
APPLICATION	Power and lighting circuits of residential and industrial, including underground installations.								
SPECIFIED STANDARD	BS 5467 IEC 60502-1 IEC 60332-1								
RATINGS	Voltage rating 600/1000V Maximum continuous conductor operating temperature 90°C <table border="0"> <thead> <tr> <th>Conductor size (mm²)</th> <th>No. of Cores</th> </tr> </thead> <tbody> <tr> <td>50, 70, 95, 120, 150, 185,</td> <td>1</td> </tr> <tr> <td>240, 300, 400, 500, 630</td> <td></td> </tr> <tr> <td>800, 1000</td> <td></td> </tr> </tbody> </table>	Conductor size (mm ²)	No. of Cores	50, 70, 95, 120, 150, 185,	1	240, 300, 400, 500, 630		800, 1000	
Conductor size (mm ²)	No. of Cores								
50, 70, 95, 120, 150, 185,	1								
240, 300, 400, 500, 630									
800, 1000									

"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid certificate."

The attached Design Appraisal Document No. 94/00003(E4) and its supplementary Type Approval Terms and Conditions form part of this Certificate.

All other details remain as the previous Certificate No. 94/00003(E3) to which this extension should be attached.

Certificate No.	94/00003(E4)
Issue Date	6 July 2004
Expiry Date	4 January 2009
Sheet	1 of 1


P.A. Hurdley-Hawkins
London Plan Approval
Lloyd's Register EMEA/London Office

Lloyd's Register EMEA
71 Fenchurch Street, London EC3M 4BS