



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Lincolville Central School
523 Hope Road
Lincolville, ME 04849

Date Printed: 04/21/2022
Work Order #: 2203-01969
Client Job #: 265
Date Received: 03/15/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 04/21/2022
CLIENT NAME: Lincolnville Central School

CLIENT ADDRESS: 523 Hope Road
Lincolnville, ME 04849

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 03/15/2022 07:30AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 13° CELSIUS
CLIENT JOB #: 265

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2203-01969-001	Nurse's Office	I	OT	03/12/2022 03:30PM	<1	ppb			DR-NH	04/16/2022 09:43AM
2203-01969-002	Room A-3 Kindergarten Fountain	I	DWF	03/12/2022 03:32PM	<1	ppb			DR-NH	04/16/2022 09:46AM
2203-01969-003	Room A-4 2nd Grade	I	DWF	03/12/2022 03:34PM	1.7	ppb			DR-NH	04/16/2022 09:55AM
2203-01969-004	Art Room Sink 2 (Deep Sink)	I	OT	03/12/2022 03:36PM	<1	ppb			DR-NH	04/16/2022 09:58AM
2203-01969-005	Teachers Lounge	I	KF	03/12/2022 03:38PM	<1	ppb			DR-NH	04/16/2022 10:01AM
2203-01969-006	Staff Bathroom	I	OT	03/12/2022 03:39PM	2.0	ppb			DR-NH	04/16/2022 10:04AM
2203-01969-007	1st Floor Boys Bathroom	I	OT	03/12/2022 03:41PM	3.0	ppb			DR-NH	04/16/2022 10:07AM
2203-01969-008	1st Floor Girls Bathroom	I	OT	03/12/2022 03:42PM	3.3	ppb			DR-NH	04/16/2022 10:10AM
2203-01969-009	1st Floor Drinking Fountains	I	DWF	03/12/2022 03:45PM	<1	ppb			DR-NH	04/16/2022 10:18AM
2203-01969-010	1st Floor Water Bottle Fill Station	I	DWF	03/12/2022 03:43PM	<1	ppb			DR-NH	04/16/2022 10:21AM
2203-01969-011	Boys Locker Room-Sink 1	I	OT	03/12/2022 03:48PM	2.4	ppb			DR-NH	04/16/2022 10:24AM
2203-01969-012	Girls Locker Room-Sink 1	I	OT	03/12/2022 03:47PM	1.8	ppb			DR-NH	04/16/2022 10:27AM
2203-01969-013	Locker Room (Gym) Drinking Fountain	I	DWF	03/12/2022 03:49PM	<1	ppb			DR-NH	04/16/2022 10:36AM
2203-01969-014	Kitchen- Food Prep Sink	I	KF	03/12/2022 03:51PM	2.9	ppb			DR-NH	04/16/2022 10:39AM
2203-01969-015	Kitchen- Mop Sink	I	KF	03/12/2022 03:52PM	79.4	ppb	⊗		DR-NH	04/20/2022 07:23PM
2203-01969-016	Kitchen- Pasta/Bulk Food Cooking Vessel	I	KF	03/12/2022 03:50PM	53.8	ppb	⊗		DR-NH	04/16/2022 10:42AM
2203-01969-017	2nd Floor work & copier room	I	KF	03/12/2022 03:55PM	2.2	ppb			DR-NH	04/16/2022 10:45AM
2203-01969-018	2nd Floor Drinking Fountain RT (Grade 6-8)	I	DWF	03/12/2022 04:09PM	<1	ppb			DR-NH	04/16/2022 10:57AM
2203-01969-019	2nd Floor Water Bottle Fill Station (Gr 6-8)	I	DWF	03/12/2022 04:10PM	<1	ppb			DR-NH	04/16/2022 10:59AM
2203-01969-020	French Room	I	OT	03/12/2022 04:07PM	3.4	ppb			DR-NH	04/16/2022 11:02AM

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 04/21/2022
CLIENT NAME: Lincolnville Central School

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

CLIENT ADDRESS: 523 Hope Road
 Lincolnville, ME 04849

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 03/15/2022 07:30AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 13° CELSIUS
CLIENT JOB #: 265

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2203-01969-021	2nd Floor Drinking Fountain LT (Grade 3-5)	I	DWF	03/12/2022 03:57PM	<1	ppb			DR-NH	04/16/2022 11:05AM
2203-01969-022	2nd Floor Water Bottle Fill Station (Gr 3-5)	I	DWF	03/12/2022 03:58PM	<1	ppb			DR-NH	04/16/2022 11:08AM
2203-01969-023	5th Grade Classroom	I	DWF	03/12/2022 04:05PM	2.5	ppb			DR-NH	04/16/2022 11:11AM
2203-01969-024	4th Grade Classroom	I	DWF	03/12/2022 04:04PM	1.3	ppb			DR-NH	04/16/2022 11:20AM
2203-01969-025	3rd Grade Classroom B5	I	DWF	03/12/2022 04:00PM	<1	ppb			DR-NH	04/16/2022 11:23AM
2203-01969-026	3rd Grade Classroom B4	I	DWF	03/12/2022 04:01PM	1.5	ppb			DR-NH	04/16/2022 11:32AM

Rebecca L. Labranche
 Laboratory Director