


LIGO VACUUM EQUIPMENT FINAL DESIGN REPORT

VOLUME II ATTACHMENT 1 - CALCULATIONS

CONTRACT NO: PC175730

CDRL NO: 03

PSI DOCUMENT NO: V049-1-097



CALIFORNIA INSTITUTE OF TECHNOLOGY
MASSACHUSETTS INSTITUTE OF TECHNOLOGY

 LIGO PROJECT

PROCESS SYSTEMS INTERNATIONAL
20 WALKUP DRIVE
WESTBOROUGH, MASSACHUSETTS 01581

VOLUME II ATTACHMENTS

ATTACHMENT 1

1. STRUCTURAL CALCULATIONS

TITLE	DOCUMENT NO.	REV.
LIGO Vacuum Equipment Structural Design Criteria	V049-1-066	0
Beam Splitter Chamber		
Finite Element Analysis of Upper Section	V049-1-014	0
ASME Code Calculations for Upper Section	V049-1-015	0
FE Analysis of 1 in. Thick Flange for Bolt Preload	V049-1-016	0
FE Analysis of 1 in. Thick Flange for Bolt Preload & Pos. Pressure	V049-1-017	0
FE Analysis of 3/4 in Thick Flange	V049-1-018	0
Flange Design for Internal Pressure	V049-1-019	0
Design of Removable Work Floor	V049-1-020	0
Design of Flange Welds	V049-1-021	0
Finite Element Analysis of Lower Section	V049-1-022	0
Design of 60 in Access Covers	V049-1-023	0
Design of Support Legs & Base Plates	V049-1-024	0
Temporary Cover for 60 in Nozzle	V049-1-025	0
Nozzle to Shell Welds	V049-1-026	0
Lifting Lugs	V049-1-027	0
Shipping Loads	V049-1-028	0
BSC Deflections	V049-1-029	0
NASTRAN Buckling Analysis	V049-1-040	0
BSC Support Clevis	V049-1-069	0

TITLE	DOCUMENT NO.	REV.
Vacuum Equipment General Structural Calculations		
Vacuum Equipment Seismic Acceleration	V049-1-031	0
Component Interface Loads	V049-1-032	0
Bolted Flange Analysis for Tensile Forces	V049-1-042	0
Design of Pipe Bridge (Corner Station)	V049-1-071	0
Horizontal Access Module		
Ham Vessel Stress Analysis (Finite Element Analysis)	V049-1-039	0
Ham Vessel Buckling Analysis	V049-1-041	0
Design of 60 inch Cover	V049-1-073	0
Design of 84 inch Cover	V049-1-074	0
Design of Nozzle Jacking Bolt Assembly	V049-1-048	0

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-066 PAGE 1 OF 3
REV.	DEO #	DATE	BY:	CHECK	TITLE: LIGO Vacuum Equipment Structural Design Criteria	
0	0136	4/24/96	RDC	D.M.W.		
PROJECT: LIGO Vacuum Equipment					BY: R. D. Ciatto	DEPT.: 744
PROJECT NO: V59049						
<u>PURPOSE:</u> Establish structural design criteria for LIGO vacuum vessels and supports.						
<u>METHOD:</u> Review LIGO vacuum equipment specification and design codes to determine requirements for structural integrity.						
<u>ASSUMPTIONS:</u> N/A						
<u>INPUTS:</u> LIGO project drawings and sketches. LIGO E940002-02-V, Vacuum Equipment Specification						
<u>REFERENCES:</u> See INPUTS						
<u>CALCULATIONS:</u> (SEE ATTACHED)						
<u>CONCLUSIONS:</u> These LIGO vacuum equipment structural design criteria conform to project and code requirements.						
<u>NOTES:</u>						

LIGO VACUUM EQUIPMENT STRUCTURAL DESIGN CRITERIA

Design Code for Vessels: ASME Boiler & Pressure Vessel Code, Section VIII, Pressure Vessels, Division 1, 1992 Edition through 1994 Addenda

Alternate Design Code for Vessels: ASME Boiler & Pressure Vessel Code, Section VIII, Pressure Vessels, Division 2, 1992 Edition through 1994 Addenda

Internal Vacuum = -14.7 psig

Positive Internal Pressure = 2 psig for vacuum chambers. Special conditions for 80K cryopumps (see Doc. No. V049-I-056).

Mechanical Loads

- Unbalanced Vacuum Loads - These loads are imposed at end components, and at branches in the system.
- Component Interface Loads - Equipment shall be designed for loads from adjacent components that are imposed when gate valves are closed and portions of the system are vented. See Doc. No. V049-1-032.

Design Temperature = 400° F

Seismic Acceleration = .05625 G (ASCE 7-88) lateral only, single direction

Pressure Boundary Material = SA240, Type 304/304L stainless steel for shells and SA182, Grade F Type 304L for flange forging. Other specification numbers and product forms of Type 304/304L may be used for miscellaneous pressure parts. Flange Bolting Material = SA193, Gr B7.

Basic Stress Limits (Section VIII, Div. 1):

Type 304L

S = 14.7 ksi at 400° F for membrane stress

S = 1.5S = 22 ksi at 400° F for membrane + bending stress

Type 304

S = 16.2 ksi at 400° F for membrane stress

S = 1.5S = 24.3 ksi at 400° F for membrane + bending stress

Basic Stress Limits (Section VIII, Div. 2):

Type 304L

$S_m = 15.8$ ksi at 400° F for Primary Membrane Stress Intensity

$1.5S_m = 23.7$ ksi at 400° F for Primary Bending Stress Intensity

$3S_m = 47.4$ ksi at 400° F for Secondary Membrane + Bending

Type 304

$S_m = 18.7$ ksi at 400° F for Primary Membrane Stress Intensity

$1.5S_m = 28.0$ ksi at 400° F for Primary Bending Stress Intensity

$3S_m = 56.1$ ksi at 400° F for Secondary Membrane + Bending

O-Ring Seal Material = Viton (1/4 in)

Maximum Durometer = 90

Compression Range = .058 in to .080 in (21% to 29 %)

Maximum Compression Force = 160 lb/in

Shipping Acceleration

Vertical Accel = 1G

Horizontal Accel = .5G

Design Code for Supports: AISC Manual of Steel Construction, Allowable Stress Design, Ninth Edition.

Material for Supports: A36 shapes and plate, A500 Gr B tube steel. See AISC Code for allowable stresses.

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-066 PAGE 1 OF 3
REV.	DEO #	DATE	BY:	CHECK	TITLE: LIGO Vacuum Equipment Structural Design Criteria	
0	0136	4/24/96	RLC	DMU		
					BY: R. D. Ciatto	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
PURPOSE: Establish structural design criteria for LIGO vacuum vessels and supports.						
METHOD: Review LIGO vacuum equipment specification and design codes to determine requirements for structural integrity.						
ASSUMPTIONS: N/A						
INPUTS: LIGO project drawings and sketches. LIGO E940002-02-V, Vacuum Equipment Specification						
REFERENCES: See INPUTS						
CALCULATIONS: (SEE ATTACHED)						
CONCLUSIONS: These LIGO vacuum equipment structural design criteria conform to project and code requirements.						
NOTES:						

LIGO VACUUM EQUIPMENT STRUCTURAL DESIGN CRITERIA

Design Code for Vessels: ASME Boiler & Pressure Vessel Code, Section VIII, Pressure Vessels, Division 1, 1992 Edition through 1994 Addenda

Alternate Design Code for Vessels: ASME Boiler & Pressure Vessel Code, Section VIII, Pressure Vessels, Division 2, 1992 Edition through 1994 Addenda

Internal Vacuum = -14.7 psig

Positive Internal Pressure = 2 psig for vacuum chambers. Special conditions for 80K cryopumps (see Doc. No. V049-1-056).

Mechanical Loads

- Unbalanced Vacuum Loads - These loads are imposed at end components, and at branches in the system.
- Component Interface Loads - Equipment shall be designed for loads from adjacent components that are imposed when gate valves are closed and portions of the system are vented. See Doc. No. V049-1-032.

Design Temperature = 400° F

Seismic Acceleration = .05625 G (ASCE 7-88) lateral only, single direction

Pressure Boundary Material = SA240, Type 304/304L stainless steel for shells and SA182, Grade F Type 304L for flange forging. Other specification numbers and product forms of Type 304/304L may be used for miscellaneous pressure parts. Flange Bolting Material = SA193, Gr B7.

Basic Stress Limits (Section VIII, Div. 1):

Type 304L

S = 14.7 ksi at 400° F for membrane stress

S = 1.5S = 22 ksi at 400° F for membrane + bending stress

Type 304

S = 16.2 ksi at 400° F for membrane stress

S = 1.5S = 24.3 ksi at 400° F for membrane + bending stress

Basic Stress Limits (Section VIII, Div. 2):

Type 304L

$S_m = 15.8$ ksi at 400° F for Primary Membrane Stress Intensity

$1.5S_m = 23.7$ ksi at 400° F for Primary Bending Stress Intensity

$3S_m = 47.4$ ksi at 400° F for Secondary Membrane + Bending

Type 304

$S_m = 18.7$ ksi at 400° F for Primary Membrane Stress Intensity

$1.5S_m = 28.0$ ksi at 400° F for Primary Bending Stress Intensity

$3S_m = 56.1$ ksi at 400° F for Secondary Membrane + Bending

O-Ring Seal Material = Viton (1/4 in)

Maximum Durometer = 90

Compression Range = .058 in to .080 in (21% to 29 %)

Maximum Compression Force = 160 lb/in

Shipping Acceleration

Vertical Accel = 1G

Horizontal Accel = .5G

Design Code for Supports: AISC Manual of Steel Construction, Allowable Stress Design, Ninth Edition.

Material for Supports: A36 shapes and plate, A500 Gr B tube steel. See AISC Code for allowable stresses.

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-014 PAGE 1 OF 16
REV.	DEO #	DATE	BY:	CHECK	TITLE: Beam Splitter Chamber - Finite Element Analysis of Upper Section	
0	0024	12/6/95	RDC	WDB		
PROJECT: LIGO Vacuum Equipment					BY: R.D. Cirio	DEPT.: 744
PROJECT NO: V59049						
PURPOSE: To evaluate the upper section of the beam splitter chamber for vacuum pressure and lifting loads.						
METHOD: Finite element analysis of vessel upper section including cylinder, head and lifting lugs. 563 nodes and 537 elements.						
ASSUMPTIONS: Ring stiffener and nozzle omitted from analysis since area of interest is shell near lug.						
INPUTS: LIGO project sketches and drawings. The thickness of the cylinder is .25 in and the thickness head is .375 in.						
REFERENCES: 1. ASME Boiler and Pressure Vessel Code, Section VIII, Pressure Vessels, Division 1. 2. Images - 3D, Version 3.0, R.L. Cloud & Associates. 3. Doc. No V049-1-066, LIGO VACUUM EQUIP., STAFF, DESIG. CRITERIA						
CALCULATIONS: (See Attachment)						
CONCLUSIONS: Stresses in head and shell in the area of the lifting lugs are within limits of ASME Code, Section VIII, Div. 1. A spreader beam should be used when lifting vessel.						
NOTES: See stress contour plots attached. See V049-1-015 for buckling analysis per the ASME Code. COMPUTER FILE: B50UPP1A						

FINITE ELEMENT ANALYSIS OF BEAM SPLITTER CHAMBER UPPER SECTION

THE PURPOSE OF THIS ANALYSIS IS TO EVALUATE THE UPPER HEAD AND CYLINDER OF THE BEAM SPLITTER CHAMBER FOR THE EFFECTS OF VACUUM PRESSURE AND LIFTING LUG LOADS. IT IS NOTED THAT THE UPPER HEAD IS A FLANGED AND DISHED HEAD WITH A CROWN RADIUS OF 105 IN AND A THICKNESS OF 3/4 IN. THE THICKNESS OF THE STRAIGHT CYLINDER IS 1/4 IN.

TO TAKE ADVANTAGE OF SYMMETRY, THE MODEL EXTENDS 180° AROUND ITS CIRCUMFERENCE.

IMAGES WAS USED FOR THE MODEL WHICH IS FILED AS


FILE NAME: BSCUPPER

THE STRESS INTENSITY PLOTS SHOWN IN THIS SECTION CONFIRM THAT STRESSES ARE LOW AND MEET THE REQUIREMENTS OF ASME SECT. VIII, DIV. 1, PAR UG-23(c)

PRIMARY MEMBRANE STRESS $\leq S_{all} = 14.7 \text{ ksi}$
(@ 4000 lb)

PRIMARY MEMBRANE + BENDING STRESS $\leq 1.5 S_{all}$
 $= 22 \text{ ksi}$
(@ 4000 lb)

IMAGES-3D
Ver. 3.0
Geometry Plot




BEAM SPLITTER CHAMBER - UPPER SECTION CYLINDER & HEAD
Hidden Line Removal

10/25/95
13:53:32

Revision 0
Doc. No. V049-1-014
Page 3 of 16

IMAGES-3D
Ver. 3.0
Geometry Plot



BEAM SPLITTER CHAMBER - UPPER SECTION CYLINDER & HEAD
Hidden Line Removal

10/25/95
13:53:32

Revision 0
Doc. No. V049-1-014
Page 3 of 16

MATERIAL PROPERTIES OF SA 240 TYPE 304 L
AT 400 °F

MODULUS OF ELASTICITY

$$26.5 \times 10^6 \text{ PSI}$$

POISSON'S RATIO

$$\nu = .3$$

COEF. OF THERMAL EXPANSION

$$\alpha = 1.19 \times 10^{-6}$$

DENSITY

$$\rho = .390 \text{ LB/IN}^3$$


THESE PROPERTIES ARE GIVEN IN IMAGES
MODELS FOR TYPE 304L SS.

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS




IMAGES-3D
Ver. 3.0
Geometry Plot

BOUNDARY CONDITIONS SHOWN



?





Revision 0
Doc. No. V049-1-014
Page 4 of 16

Auto Node	Blowup Node#	Elem# Plot	Exit Range	Full Rest	Help Rotate	Local Shrink	Move Slice
--------------	-----------------	---------------	---------------	--------------	----------------	-----------------	---------------

IMAGES FOR MODEL

KEY NODE NUMBERS



$$\theta = 90 - \frac{180}{27}$$

$$= 83.3333^\circ$$

$$y = 52.75 \cos 83.3333^\circ$$

$$= 6.0675$$

$$z = 52.75 \sin 83.3333^\circ$$

$$= 51.4967$$


22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS

1.000 [25.4]

2.0000 1.00


39.438 [1001.7]
35.438 [900.1]

11.750 [298.5]



Revision 0
Doc. No. V049-1-014
Page 6 of 16

4




Revision 0
Doc. No. V049-1-014
Page 7 of 16

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



LUG


NODES 534 TO 541 ARE
ADDED AT MID SURFACE OF
PLATE



FIRMENTS 229 TO 231, 254 TO 258
WERE DELETED AND REPLACED WITH
ELEMENTS WITH ABOVE NODES

ADDITIONAL NODES WILL BE ADDED
FROM NODES 534 TO 541 WITH
RIGID ELEMENTS. THESE NEW ELEMENTS
WILL REPLACE THE EXISTING COE

ASSUMING LUG IS 1 IN THICK. RADIUS
TO MID SURFACE IS



$$r = 52.25 + .125 + .5 = 52.875 \text{ IN}$$

$$\theta = \tan^{-1} \left(\frac{6.0619}{51.8969} \right) = 6.6667^\circ$$



$$y = r \sin \theta = 52.875 \sin 6.6667 = 6.1385 \text{ IN}$$

$$z = r \cos \theta = 52.875 \cos 6.6667 = 52.5175 \text{ IN}$$

IMAGES-3D
Ver. 3.0
Geometry Plot

- 5-Solid or 5,F,I
- 6-Spring or 6,F,I
- 7-Rigid or 7,F,I
- 8-No element numbers
- 9-All element numbers
- 10-Exit or 10,Size

- ?9
- ?#
- ?h,n
- ?n
- ?n
- ?n
- ?



Revision 0
 Doc. No. V049-1-014
 Page 9 of 16

Auto **Blowup** **Elem#** **Exit** **Full** **Help** **Local** **Move**
Node **Node#** **Plot** **Range** **Rest** **Rotate** **Shrink** **Slice**

LUG NODES 543 546 549 — 90

LOAD THIS NODE → 555 43

• • • 76

• • • 69

• • • RIGID ELEMENTS 67

• 551 552 54

557 550 553 — 48

RIGID ELEMENTS

I	J	TYPE	RELEASE
{ 534	543	1	0
	535		
	526		
{ 537	540		
	538		
	535		
{ 540	557		
	511		
	542		

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



PLATES 1 TO 25 HAVE EXT. PARALLEL

LOAD LOADS (NODES 555)

VERTICAL (LOAD CASE 2)


TOTAL ESTIMATED WEIGHT

$$W = 12500 \text{ LB}$$

$$F_{Y555} = \frac{12500}{2}$$

$$= 6250 \text{ LB}$$

FOR LEFT TO VERTICAL POSITION ONLY
HORIZONTAL CONSTRUCTION, SHIPING
POSITION, LOAD IS IN X-DIRECTION
ASSUME VESSEL PIVOTS ABOUT BASE
PLATE & CG IS MIDWAY BETWEEN
BACK PLATE AND EYE OF LUG






$$F_x = \frac{W}{2} \times \frac{S}{2} \div S = \frac{W}{4}$$

$$= \frac{12500}{4} = 3125 \text{ LB}$$

LOAD CASE 3

$$F_{Y555} = 3125$$

IMAGES-3D
Version 3.0



Revision 0
Doc. No. V049-1-014
Page 12 of 16



Load Case
1

Stress Contour Plot
Surf: Bottom
Stress Intensity

10/25/95
10:46:21

VACUUM PRESSURE

IMAGES-3D
Version 3.0



Revision 0
Doc. No. V049-1-014
Page 13 of 16

Load Case
2



Surf: Top

Stress Contour Plot
Stress Intensity

10/25/95
10:48:56

VERTICAL CUT 20-10

IMAGES-3D
Version 3.0






Revision 0
Doc. No. V049-1-014
Page 14 of 16

Load Case
2

Stress Contour Plot
Surf: Middle
Stress Intensity

10/25/95
10:52:10

IMAGES-3D
Version 3.0



Revision 0
Doc. No. V049-1-014
Page 15 of 16




Load Case
3

Stress Contour Plot
Surf: Middle
Stress Intensity

10/25/95
10:54:34

HORIZONTAL LOG LOAD

IMAGES-3D
Version 3.0



Revision 0
Doc. No. V049-1-014
Page 16 of 16

Load Case
3

Displacement Contour Plot
DX

10/25/95
11:21: 2

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-015 PAGE 1 OF 57
REV.	DEO #	DATE	BY:	CHECK	TITLE: Beam Splitter Chamber - ASME Code Calculations for Upper Section.	
0	002 ^U	12/1/95	RDC	P.W.Y.		
					BY: R. D. Ciarro	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
PURPOSE: To determine if the upper section of the beam splitter chamber meets Section VIII, Div. 1 of the ASME Code for vacuum pressure.						
METHOD: Equations for thickness requirements and pressure rating in the ASME Code, Section VIII, Div.1 are evaluated using the COMPRESS computer program, Version 5.31.						
ASSUMPTIONS:						
INPUTS: Vacuum pressure = 14.7 psi Design temperature = 400 ⁰ F						
REFERENCES: 1. ASME Boiler & Pressure Vessel Code, Section VIII, Pressure Vessels, Division 1. 2. COMPRESS 5.31, Computer Aided Pressure Vessel Design, Codeware Computer Systems, Inc. 3. Doc. No. V049-1-066, LIGO VACUUM ROOM, STAFFORD DESIGN CORPORATION						
CALCULATIONS: (See Attached)						
CONCLUSIONS: Requirements of the ASME Code, Section VIII, Div. 1 are met for the BSC upper section head and cylinder.						
NOTES: Nozzle G in lower section is included in this analysis. This nozzle penetrates the 1/2 in. shell. No reinforcing pad is required by code.						

THE COMPRESS PROGRAM IS USED TO
EVALUATE THE UPPER SECTION OF THE
BSC. THIS INCLUDES:

TOP HEAD


UPPER CYLINDRICAL SHELL (ABOVE
FLANGE)

SHELL STIFFENER

MAIN CYLINDRICAL SHELL (BELOW
FLANGE) DOES NOT INCLUDE
NOZZLES

COMPRESS FILENAME: BSCUPPER.USL

NOTE: THE 1/2 IN LOWER SHELL
INCLUDING NOZZLE 6 IS ALSO
INCLUDED IN THE COMPRESS MODEL.



22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



NOZZLE E (LOCATED ON 1/4 IN SHELL)

RADIUS 1040 FROM VACUUM AXIS.

$$F_R = \pi r^2 \rho$$

$$r = \frac{13.75}{2} = 6.875 \text{ IN INSIDE RADIUS}$$

$$\rho = 14.7 \text{ PSI}$$

$$F_R = \pi (6.875)^2 (14.7) = 2183 \text{ LB}$$

WRC 107 ALLOW BY COMPRESS

MAX STRESS IS

$$f = 13222 \text{ PSI AT EDGE OF REIN. PAD}$$

$$f = 4686 \text{ PSI AT NOZZLE O.D.}$$

PAD REIN (COMPRESS) FOR NOZ E ON OPPOSE SECTION

$$O.D. = 20" \times t = .75 \text{ IN} *$$

WELDS FROM COMPRESS *

INNER FILLET = .125


OUTER " = .125

VACUUM GROOVE = 0

LOWER REIN = .25

PAD FOR VACUUM SERVICE

*.5 IN USED TO COMPENSATE FOR GAP



* WELDS WERE MODIFIED FOR VACUUM SERVICE SEE V 049-1-026

6 NOT



NOZZLE G (LOCATED ON 1/2 IN SHELL)
 RADIAL LOAD FROM VACUUM PRESSURE

$$F_R = \pi r^2 p$$

$$r = \frac{7.25}{2} = 3.625$$

$$p = 14.7 \text{ psi}$$

$$F_R = \pi (3.625)^2 (14.7)$$

$$= 693.4 \text{ LB}$$

MAX STRESS FROM WRC 107


$$s = 2378 \text{ psi}$$

NO REINFC AND REQ'D FOR THIS NOZZLE
 SINCE IT IS ATTACHED TO 1/2" NOZZLE

REQUIRED WELDS FROM COMPRESS

$$\text{FILLET WELDS} = .125$$

$$\text{GAMMA WELDS} = .1875$$



* WELDS WERE MODIFIED
 FOR VACUUM VESSEL SERVICE

Top Head - BSC

ASME Section VIII Division 1, 1992 Edition, A93 Addenda

Component: F&D head
 Material specification: SA 240 304L HIGH
 Internal design pressure: P = 2 psi @ 400 deg F
 External design pressure: Pe = 14.7 psi @ 400 deg F
 Corrosion allowance: Inner C = 0 Outer = 0 in

PWHT is not performed

Radiography: Category A joints - Spot UW-11(b) type 1
 Head to shell seam - Spot UW-11(b) type 1

Estimated weight: new = 1232.9 corr = 1232.9 lb
 capacity: new = 468.96 corr = 468.96 US ga

ID = 104.25 crown L = 105 knuckle r = 6.5 t = .375 in (min)

Straight flange = 2 forming allowance = 0 in

Design thickness: (At 400 deg F) Appendix 1-4(d) Eq 3

$$M = .25*(3 + (L/r)^.5)$$

$$= .25*(3 + (105/6.5)^.5)$$

$$= 1.7548$$

$$t = P*L*M/(2*S*E - 0.2*P) + Corrosion + fa$$

$$= 2*105*1.7548/(2*14700*0.85 - 0.2*2) + 0 + 0$$

$$= 0.0147 \text{ in}$$

MAP: (New & at 0 deg F) Appendix 1-4(d) Eq 3

$$P = 2*S*E*t/(L*M + 0.2*t) - Ps$$

$$= 2*14700*0.85*0.375/(105*1.7548 + 0.2*0.375) - 0$$

$$= 57.75679 \text{ psi}$$

MAWP: (Corroded & at 400 deg F) Appendix 1-4(d) Eq 3

$$P = 2*S*E*t/(L*M + 0.2*t) - Ps$$

$$= 2*14700*0.85*0.375/(105*1.7548 + 0.2*0.375) - 0$$

$$= 50.83981 \text{ psi}$$

External Pressure: (Corroded & at 400 deg F) UG-33(e)

$$A = .125/(Ro/t)$$

$$= .125/(105.375/0.32589)$$

$$= 0.000387$$

From table HA-3: B = 4755.5

Rev 0
Doc V049-1-015
 Page 6 of 57

Top Head - BSC

$$\begin{aligned} P_a &= B/(Ro/t) \\ &= 4755.5/(105.375/0.32589) \\ &= 14.7072 \text{ psi} \end{aligned}$$

Check the external pressure per UG-33(a)(1)

$$\begin{aligned} t &= 1.67 * P_a * L_o * M / (2 * S * E + 1.67 * P_a * (M - 0.2)) \\ &= 1.67 * 14.7072 * 105.375 * 1.7548 / (2 * 14700 * 1 + 1.67 * 14.7072 * (1.7548 - 0.2)) \\ &= 0.154277 \text{ in} \end{aligned}$$

Design thickness for external pressure $P_a = 14.7072$ psi:

$$\begin{aligned} &= t + \text{Corrosion} + f_a \\ &= 0.32589 + 0 + 0 \\ &= 0.32589 \text{ in} \end{aligned}$$

Maximum Allowable External Pressure: (Corroded @ 400 deg F)

$$\begin{aligned} A &= .125/(Ro/t) \\ &= .125/(105.375/0.375) \\ &= 0.000445 \end{aligned}$$

From table HA-3: $B = 4873.8$

$$\begin{aligned} P_a &= B/(Ro/t) \\ &= 4873.8/(105.375/0.375) \\ &= 17.3445 \text{ psi} \end{aligned}$$

Check the Maximum External Pressure: UG-33(a)(1) & App. 1-4(d)

$$\begin{aligned} P_c &= 2 * S * E * t / ((M * L_o - t * (M - 0.2)) * 1.67) \\ &= 2 * 14700 * 1 * 0.375 / ((1.7548 * 105.375 - 0.375 * (1.7548 - 0.2)) * 1.67) \\ &= 35.81529 \text{ psi} \end{aligned}$$

The maximum allowable external pressure is 17.3445 psi.

REV 0
Doc. No. V049-1-015

Top Head - BSC

ANALYSIS FOR THICKNESSES
REQUIRED BY 1/32"ASME Section VIII Division 1, 1992 Edition, A93 Addenda

Component: F&D head
 Material specification: SA 240 304L HIGH
 Internal design pressure: P = 2 psi @ 400 deg F
 External design pressure: Pe = 14.7 psi @ 400 deg F
 Corrosion allowance: Inner C = 0 Outer = 0 in

PWHT is not performed

Radiography: Category A joints - Spot UW-11(b) type 1
 Head to shell seam - Spot UW-11(b) type 1

Estimated weight: new = 1128.8 corr = 1128.8 lb
 capacity: new = 468.96 corr = 468.96 US ga

ID = 104.25 crown L = 105 knuckle r = 6.5 t = .34375 in (min)
 = 11/32
 Straight flange = 2 forming allowance = 0 in

WARNING! F&D head geometry is not per UG-32(j).

(CROWN R10 = 125 > CD = 124)

Design thickness: (At 400 deg F) Appendix 1-4(d) Eq 3

$$M = .25*(3 + (L/r)^{.5})$$

$$= .25*(3 + (105/6.5)^{.5})$$

$$= 1.7548$$

$$t = P*L*M/(2*S*E - 0.2*P) + \text{Corrosion} + fa$$

$$= 2*105*1.7548/(2*14700*0.85 - 0.2*2) + 0 + 0$$

$$= 0.0147 \text{ in}$$

MAP: (New & at 0 deg F) Appendix 1-4(d) Eq 3

$$P = 2*S*E*t/(L*M + 0.2*t) - Ps$$

$$= 2*14700*0.85*0.34375/(105*1.7548 + 0.2*0.34375) - 0$$

$$= 52.94551 \text{ psi}$$

MAWP: (Corroded & at 400 deg F) Appendix 1-4(d) Eq 3

$$P = 2*S*E*t/(L*M + 0.2*t) - Ps$$

$$= 2*14700*0.85*0.34375/(105*1.7548 + 0.2*0.34375) - 0$$

$$= 46.60474 \text{ psi}$$

External Pressure: (Corroded & at 400 deg F) UG-33(e)

$$A = .125/(R_o/t)$$

$$= .125/(105.3438/0.32589)$$

Top Head - BSC

$$= 0.000387$$

From table HA-3:

$$B = 4754.8$$

$$\begin{aligned} Pa &= B/(Ro/t) \\ &= 4754.8/(105.3438/0.32589) \\ &= 14.7094 \text{ psi} \end{aligned}$$

Check the external pressure per UG-33(a)(1)

$$\begin{aligned} t &= 1.67*Pa*Lo*M/(2*S*E + 1.67*Pa*(M-0.2)) \\ &= 1.67*14.7094*105.3438*1.7548/(2*14700*1 + 1.67*14.7094*(1.7548-0.2)) \\ &= 0.154254 \text{ in} \end{aligned}$$

Design thickness for external pressure Pa = 14.7094 psi:

$$\begin{aligned} &= t + \text{Corrosion} + fa \\ &= 0.32589 + 0 + 0 \\ &= 0.32589 \text{ in} \end{aligned}$$

Maximum Allowable External Pressure: (Corroded @ 400 deg F)

$$\begin{aligned} A &= .125/(Ro/t) \\ &= .125/(105.3438/0.34375) \\ &= 0.000408 \end{aligned}$$

From table HA-3:

$$B = 4797.2$$

$$\begin{aligned} Pa &= B/(Ro/t) \\ &= 4797.2/(105.3438/0.34375) \\ &= 15.6539 \text{ psi} \end{aligned}$$

Check the Maximum External Pressure: UG-33(a)(1) & App. 1-4(d)

$$\begin{aligned} Pe &= 2*S*E*t/((M*Lo - t*(M-0.2))*1.67) \\ &= 2*14700*1*0.34375/((1.7548*105.3438 - 0.34375*(1.7548-0.2))*1.67) \\ &= 32.83179 \text{ psi} \end{aligned}$$

The maximum allowable external pressure is 15.6539 psi.

Upper Cylindrical Shell - BSCASME Section VIII Division 1, 1992 Edition, A93 Addenda

Component: Cylinder
 Material specification: SA 240 304L HIGH

Internal design pressure: P = 2 psi @ 400 deg F
 External design pressure: Pe = 14.7 psi @ 400 deg F

Corrosion allowance: Inner C = 0 Outer = 0 in

PWHT is not performed

Radiography: Category A joints - Spot UW-11(b) type 1
 Category B joints - Spot UW-11(b) type 1

Estimated weight: new = 1428.1 corr = 1428.1 lb
 capacity: new = 2217.078 corr = 2217.078 US ga

ID = 104.25 length Lc = 60 t = 0.25 in (new)

Design thickness: UG-27(c)(1) Circ. stress

$$t = P \cdot R / (S \cdot E - 0.6 \cdot P) + \text{Corrosion}$$

$$= 2 \cdot 52.125 / (14700 \cdot 0.85 - 0.6 \cdot 2) + 0$$

$$= 0.0083 \text{ in}$$

MAP: (New & at 0 deg F) UG-27(c)(1)

$$P = S \cdot E \cdot t / (R + 0.6 \cdot t) - P_s$$

$$= 16700 \cdot 0.85 \cdot 0.25 / (52.125 + 0.6 \cdot 0.25) - 0$$

$$= 67.88618 \text{ psi}$$

MAWP: (Corroded & at 400 deg F) UG-27(c)(1)

$$P = S \cdot E \cdot t / (R + 0.6 \cdot t) - P_s$$

$$= 14700 \cdot 0.85 \cdot 0.25 / (52.125 + 0.6 \cdot 0.25) - 0$$

$$= 59.7561 \text{ psi}$$

External Pressure: (Corroded & at 400 deg F) UG-28

$$L/Do = 37.90131/104.75 = 0.3618 \quad Do/t = 104.75/0.23897 = 438.3395$$

From table G: A = 0.000425
 From table HA-3: B = 4834.6

$$P_a = 4 \cdot B / (3 \cdot Do/t)$$

$$= 4 \cdot 4834.6 / (3 \cdot 104.75/0.23897)$$

$$= 14.7058 \text{ psi}$$

Design thickness for external pressure Pa = 14.7058 psi:

$$= t + \text{Corrosion}$$

$$= 0.23897 + 0$$

Upper Cylindrical Shell - BSC

$$= 0.23897 \text{ in}$$

Maximum Allowable External Pressure: (Corroded @ 400 deg F)

$$L/Do = 37.90131/104.75 = 0.3618 \quad Do/t = 104.75/0.25 = 419$$

$$\text{From table G:} \quad A = 0.000452$$

$$\text{From table HA-3:} \quad B = 4887.2$$

$$\begin{aligned} Pa &= 4*B/(3*Do/t) \\ &= 4*4887.2/(3*104.75/0.25) \\ &= 15.5519 \text{ psi} \end{aligned}$$

Rev. 0
Doc. No. V049-1-015

Shell StiffenerStiffening Ring Calculations Per UG-29ASME Section VIII Division 1, 1992 Edition, A93 Addenda

Identifier:	Shell Stiffener
Ring material specification:	SA 240 304L HIGH
Number of rings in this group:	1
Distance first ring to datum line:	110 in
Ring spacing:	0 in
Ring description:	4x4x1/4 Equal Angle
Ring is rolled:	leg out (easy way)
Ring cross sectional area:	As = 1.94 in ²
Ring moment of inertia:	Ir = 3.04 in ⁴

Calculations for ring 110 in from datum

Shell material specification:	SA 240 304L HIGH
Required shell thickness:	t = 0.23897 in
Corroded shell thickness:	ts = 0.25 in
Shell outer diameter:	Do = 104.75 in
Design temperature:	= 400 deg F
External design pressure:	P = 14.7 psi
Stiffener supported length:	Ls = 33.95065 in

$$\begin{aligned}
 B &= .75*(P*Do/(t + As/Ls)) \\
 &= .75*(14.7*104.75/(0.23897 + 1.94/33.95065)) \\
 &= 3900.111
 \end{aligned}$$

$$\text{From table HA-3 (ring)} \quad A = 2.949634E-04$$

Required moment of inertia of the combined ring-shell section

$$\begin{aligned}
 I_s &= (Do^2*Ls*(t + As/Ls)*A)/10.9 \\
 &= (104.75^2*33.95065*(0.23897 + 1.94/33.95065)*2.949634E-04)/10.9 \\
 &= 2.985063 \text{ in}^4
 \end{aligned}$$

Available moment of inertia of the combined ring-shell section

$$\text{Shell width contributing smaller of} \quad = 5.62911$$

$$\begin{aligned}
 W &= 1.1*\text{Sqr}(Do*ts) \\
 &= 1.1*\text{Sqr}(104.75*0.25) \\
 &= 5.62911 \text{ in}
 \end{aligned}$$

$$W = Ls = 33.95065 \text{ in}$$

$$\text{Shell area } A1 = W*ts = 1.407277 \text{ in}^2$$

Distance to the ring neutral axis

Shell Stiffener

$$\begin{aligned} Y2 &= \text{Ring NA} + ts/2 \\ &= 1.09 + 0.25/2 \\ &= 1.215 \text{ in} \end{aligned}$$

Neutral axis of combined section

$$\begin{aligned} \text{NA} &= A_s * Y2 / (A_1 + A_s) \\ &= 1.94 * 1.215 / (1.407277 + 1.94) \\ &= .7041842 \text{ in} \end{aligned}$$

Inertia of the shell about the combined section NA

$$\begin{aligned} I_1 &= W * ts^3 / 12 + A_1 * \text{NA}^2 \\ &= 5.62911 * 0.25^3 / 12 + 1.407277 * 0.7041842^2 \\ &= .7051639 \text{ in}^4 \end{aligned}$$

Inertia of the ring about the combined section NA

$$\begin{aligned} I_2 &= I_r + A_s * (\text{NA} - Y2)^2 \\ &= 3.04 + 1.94 * (0.7041842 - 1.215)^2 \\ &= 3.54621 \text{ in}^4 \end{aligned}$$

$$\text{Total available I} = I_1 + I_2 = 4.251373 \text{ in}^4$$

The 4x4x1/4 Equal Angle vacuum stiffener is satisfactory.

REV 0
Doc No: 1049.1-0.5

RING STIFFNESS CONNECTION WELD PER AISC
III - 1, UG-30

USE INTERMITTENT WELD STAGGERED, 2 IN
@ 4 IN

MAX. ALLOW. SPACING

$$S = 2 \text{ IN} = 8 t \text{ FOR EXT. RING - OK}$$

$$t = .25 \text{ IN SHELL THICKNESS}$$

1) RADIAL STRESS LOAD

$$P_L = 14.7(30) = 441 \text{ LB/IN}$$

2) RADIAL SHEAR LOAD

$$.01 P_L D_o = .01(441)(105) \\ = 463 \text{ LB}$$

FOR A 4 IN SPACING THE TOTAL RADIAL
PRESS. LOAD IS

$$F = 4 P_L = 4(441) = 1764 \text{ LB}$$

WELD AREA FOR $t = 3/16 =$

$$A_w = 2 \times 2 \times .707(3/16) = .53 \text{ IN}^2$$

WELD SHEAR STRESS

$$f_v = \frac{F}{A_w} = \frac{1764}{.53} = 3300 \text{ PSI OK} \\ < .55(14700) = 8085 \text{ PSI}$$

MIN WELD SIZE IS $1/4"$ (UG 30 f)

∴ USE $1/4$ IN 2 IN @ 4 IN STAGGERED

REV 0
Doc No. 1017-1-015
P. 122 OF 57



Main Section Cylinder

ASME Section VIII Division 1, 1992 Edition, A93 Addenda

Component: Cylinder
 Material specification: SA 240 304L HIGH
 Internal design pressure: P = 2 psi @ 400 deg F
 External design pressure: Pc = 14.7 psi @ 400 deg F
 Corrosion allowance: Inner C = 0 Outer = 0 in

PWHT is not performed

Radiography: Category A joints - Spot UW-11(b) type 1
 Category B joints - Spot UW-11(b) type 1

Estimated weight: new = 3817.3 corr = 3817.3 lb
 capacity: new = 2956.104 corr = 2956.104 US ga

ID = 104.25 length Lc = 80 t = 0.5 in (new)

Design thickness: UG-27(c)(1) Circ. stress

$$t = P \cdot R / (S \cdot E - 0.6 \cdot P) + \text{Corrosion}$$

$$= 2 \cdot 52.125 / (14700 \cdot 0.85 - 0.6 \cdot 2) + 0$$

$$= 0.0083 \text{ in}$$

MAP: (New & at 0 deg F) UG-27(c)(1)

$$P = S \cdot E \cdot t / (R + 0.6 \cdot t) - P_s$$

$$= 16700 \cdot 0.85 \cdot 0.5 / (52.125 + 0.6 \cdot 0.5) - 0$$

$$= 135.3839 \text{ psi}$$

MAWP: (Corroded & at 400 deg F) UG-27(c)(1)

$$P = S \cdot E \cdot t / (R + 0.6 \cdot t) - P_s$$

$$= 14700 \cdot 0.85 \cdot 0.5 / (52.125 + 0.6 \cdot 0.5) - 0$$

$$= 119.1702 \text{ psi}$$

External Pressure: (Corroded & at 400 deg F) UG-28

$$L/Do = 80/105.25 = 0.7601 \quad Do/t = 105.25/0.30747 = 342.3098$$

From table G: A = 0.000288
 From table HA-3: B = 3807.2

$$P_a = 4 \cdot B / (3 \cdot Do/t)$$

$$= 4 \cdot 3807.2 / (3 \cdot 105.25 / 0.30747)$$

$$= 14.8295 \text{ psi}$$

Design thickness for external pressure Pa = 14.8295 psi:

$$= t + \text{Corrosion}$$

$$= 0.30747 + 0$$

REV 0
 Doc. No. 1009-1-015
 Page 14 of 57

Main Section Cylinder

$$= 0.30747 \text{ in}$$

Maximum Allowable External Pressure: (Corroded @ 400 deg F)

$$\begin{aligned} L/Do &= 80/105.25 = 0.7601 & Do/t &= 105.25/0.5 = 210.5 \\ \text{From table G:} & & A &= 0.000587 \\ \text{From table HA-3:} & & B &= 5117.2 \end{aligned}$$

$$\begin{aligned} Pa &= 4*B/(3*Do/t) \\ &= 4*5117.2/(3*105.25/0.5) \\ &= 32.413 \text{ psi} \end{aligned}$$

Nozzle E


Opening N-E Reinforcement Calculations Per UG-37

Located on: Upper Cylindrical Shell - BSC
 Local vessel thickness: .25 in
 Liquid static head included: 0 psi
 Flange description: 14 inch 75# SO A240304L
 ANSI B16.47 flange rating MAP: 115 psi
 ANSI B16.47 flange rating MAWP: 80 psi

Nozzle material specification: SA 240 304L HIGH

Pad material specification: SA 240 304L HIGH

Nozzle orientation: 45 degrees
 End of nozzle to shell center: 55.875 in
 Nozzle offset from center Lo: 0 in
 Projection outside vessel Lpr: 3.5 in



corrosion allow = 0 in
 noz thick new $tn = .12$ in
 nozzle id. new $d = 13.75$ in
 pad diameter $dp = 20$ in
 pad thickness $te = .25$ in
 fillet weld $tw1 = .125$ in
 fillet weld $tw2 = .25$ in
 groove weld $tw3 = .25$ in
 To datum $L = 124$ in

Reinforcement Calculations For Nozzle MAWP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 13.75$ in
 Normal to the vessel wall outside $2.5*(tn-Cn) + te = .55$ in
 Normal to the vessel wall inside $2.5*(tn-Cn-C) = .3$ in

Nozzle required thickness

$$trn = P \cdot Rn / (Sn \cdot E - 0.6 \cdot P)$$

$$= 2 \cdot 6.875 / (14700 \cdot 1 - 0.6 \cdot 2)$$

$$= 0.0009 \text{ in}$$

Required thickness tr from UG-37(a)

$$tr = P \cdot R / (S \cdot E - 0.6 \cdot P)$$

$$= 2 \cdot 52.125 / (14700 \cdot 1 - 0.6 \cdot 2)$$

$$= 0.0071 \text{ in}$$

Area required

Rev 0
Doc. No. V049-1-015

Nozzle E

Allowable stresses: $S_n = 14700$, $S_v = 14700$, $S_p = 14700$ psi

fr1 = lesser of 1 or S_n/S_v so fr1 = 1
 fr2 = lesser of 1 or S_n/S_v so fr2 = 1
 fr3 = lesser of fr2 or S_p/S_v so fr3 = 1
 fr4 = lesser of 1 or S_p/S_v so fr4 = 1

$$\begin{aligned} A &= d \cdot t_r \cdot F + 2 \cdot t_n \cdot t_r \cdot F \cdot (1 - fr1) \\ &= 13.75 \cdot 0.0071 \cdot 1 + 2 \cdot 0.12 \cdot 0.0071 \cdot 1 \cdot (1 - 1) \\ &= .0976 \text{ in}^2 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} = 3.34 \text{ in}^2$$

$$\begin{aligned} &= d \cdot (E1 \cdot t - F \cdot t_r) - 2 \cdot t_n \cdot (E1 \cdot t - F \cdot t_r) \cdot (1 - fr1) \\ &= 13.75 \cdot (1 \cdot 0.25 - 1 \cdot 0.0071) - 2 \cdot 0.12 \cdot (1 \cdot 0.25 - 1 \cdot 0.0071) \cdot (1 - 1) \\ &= 3.34 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 \cdot (t + t_n) \cdot (E1 \cdot t - F \cdot t_r) - 2 \cdot t_n \cdot (E1 \cdot t - F \cdot t_r) \cdot (1 - fr1) \\ &= 2 \cdot (0.25 + 0.12) \cdot (1 \cdot 0.25 - 1 \cdot 0.0071) - 2 \cdot 0.12 \cdot (1 \cdot 0.25 - 1 \cdot 0.0071) \cdot (1 - 1) \\ &= .18 \text{ in}^2 \end{aligned}$$

$$A2 = \text{smaller of the following} = 0.131 \text{ in}^2$$

$$\begin{aligned} &= 5 \cdot (t_n - t_{rn}) \cdot fr2 \cdot t \\ &= 5 \cdot (0.12 - 0.0009) \cdot 1 \cdot 0.25 \\ &= .149 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 \cdot (t_n - t_{rn}) \cdot (2.5 \cdot t_n + t_e) \cdot fr2 \\ &= 2 \cdot (0.12 - 0.0009) \cdot (2.5 \cdot 0.12 + 0.25) \cdot 1 \\ &= .131 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A41 &= \text{Leg}^2 \cdot fr3 \\ &= 0.125^2 \cdot 1 = .016 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A42 &= \text{Leg}^2 \cdot fr4 \\ &= 0.25^2 \cdot 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A5 &= (D_p - d - 2 \cdot t_n) \cdot t_e \cdot fr4 \\ &= (20 - 13.75 - 2 \cdot 0.12) \cdot 0.25 \cdot 1 \\ &= 1.5025 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 + A42 + A5 \\ &= 3.34 + 0.131 + 0.016 + 0.063 + 1.5025 \\ &= 5.0525 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAWP = 2 at 400 Deg F

Check the welds - From UW-16(c)(2)

Inner Fillet: $t_{min} = \text{lesser of } 0.75 \text{ or } t_n \text{ or } t_e$, $t_{min} = 0.12 \text{ in}$
 $t_w(\text{min}) = 0.7 \cdot t_{min} = 0.084 \text{ in}$

Res O
Doc No V049-1-015
 Page 17 of 57

Nozzle E

$$tw(\text{actual}) = 0.7 * \text{Leg} = 0.7 * 0.125 = 0.0875 \text{ in}$$

Outer Fillet: $t_{\text{min}} = \text{lesser of } 0.75 \text{ or } t_e \text{ or } t, t_{\text{min}} = 0.25 \text{ in}$

$$tw(\text{min}) = 0.5 * t_{\text{min}} = 0.125 \text{ in}$$

$$tw(\text{actual}) = 0.7 * \text{Leg} = 0.7 * 0.25 = 0.175 \text{ in}$$

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a): $tr1 = 0.0009 \text{ in } (E = 1)$

Wall thickness per UG-45(b)(1): $tr2 = 0.0071 \text{ in}$

Wall thickness per UG-16(b): $tr3 = 0.0625 \text{ in}$

Std pipe wall per UG-45(b)(4): $tr4 = 0.328125 \text{ in}$

The greater of $tr2$ or $tr3$: $tr5 = 0.0625 \text{ in}$

The lesser of $tr4$ or $tr5$: $tr6 = 0.0625 \text{ in}$

Req'd per UG-45 is the larger of $tr1$ or $tr6 = 0.0625 \text{ in}$

Available nozzle wall thickness new, $t_n = 0.12 \text{ in}$

The nozzle neck thickness is adequate for MAWP.

Allowable stresses in joints UG-45(c) and UW-15(c)

Groove weld in tension = $0.74 * 14700 = 10878 \text{ psi}$

Nozzle wall in shear = $0.7 * 14700 = 10290 \text{ psi}$

Inner fillet weld in shear = $0.49 * 14700 = 7203 \text{ psi}$

Outer fillet weld in shear = $0.49 * 14700 = 7203 \text{ psi}$

Strength of welded joints:

(1) Inner fillet weld in shear

$$(Pi/2) * \text{Nozzle O.D.} * \text{Leg} * S_i = 1.57 * 13.99 * 0.125 * 7203 = 19776.11 \text{ lbf}$$

(2) Outer fillet weld in shear

$$(Pi/2) * \text{Pad O.D.} * \text{Leg} * S_o = 1.57 * 20 * 0.25 * 7203 = 56543.55 \text{ lbf}$$

(3) Nozzle wall in shear

$$(Pi/2) * \text{Mean nozzle dia.} * t_n * S_n = 1.57 * 13.87 * 0.12 * 10290 = 26888.88 \text{ lbf}$$

(4) Groove weld in tension

$$(Pi/2) * \text{Nozzle O.D.} * tw * S_g = 1.57 * 13.99 * 0.25 * 10878 = 59731.91 \text{ lbf}$$

Loading on welds per UG-41(b)(1)

$$\begin{aligned} W &= (A - (d - 2 * t_n) * (E1 * t - F * tr)) * S_v \\ &= (0.0976 - (13.75 - 2 * 0.12) * (1 * 0.25 - 1 * 0.0071)) * 14700 \\ &= -46804.49 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W1-1 &= (A2 + A5 + A41 + A42) * S_v \\ &= (0.131 + 1.5025 + 0.016 + 0.063) * 14700 \\ &= 25173.75 \text{ lbf} \end{aligned}$$

$$W2-2 = (A2 + A3 + A41 + A43 + 2 * t_n * t * fr1) * S_v$$

Rev. 0
Doc No. V049-1-015

Nozzle E

$$= (0.131 + 0 + 0.016 + 0 + 2*0.12*0.25*1)*14700$$

$$= 3042.9 \text{ lbf}$$

$$W3-3 = (A2 + A3 + A5 + A41 + A42 + A43 + 2*tn*tf*fr1)*Sv$$

$$= (0.131 + 0 + 1.5025 + 0.016 + 0.063 + 0 + 2*0.12*0.25*1)*14700$$

$$= 26055.75 \text{ lbf}$$

Load for path 1-1 lesser of W or W1-1 = -46804.49 lbf
 Path 1-1 Thru (2) & (3) = 56543.55 + 26888.88 = 83432.43 lbf
 Path 1-1 is stronger than W so it is acceptable per UG-41(b)(2).

Load for path 2-2 lesser of W or W2-2 = -46804.49 lbf
 Path 2-2 Thru (1), (4) = 19776.11 + 59731.91 = 79508.02 lbf
 Path 2-2 is stronger than W so it is acceptable per UG-41(b)(2).

Load for path 3-3 lesser of W or W3-3 = -46804.49 lbf
 Path 3-3 Thru (2), (4) = 56543.55 + 59731.91 = 116275.5 lbf
 Path 3-3 is stronger than W so it is acceptable per UG-41(b)(2).

Pad strength = $A5*Sp = 22086.75 \text{ lbf}$
 Outer fillet weld strength is adequate.

Reinforcement Calculations for External PressureLimits of reinforcement UG-40

Parallel to the vessel wall $d = 13.75 \text{ in}$
 Normal to the vessel wall outside $2.5*(tn-Cn) + te = .55 \text{ in}$
 Normal to the vessel wall inside $2.5*(tn-Cn-C) = .3 \text{ in}$

Nozzle required thickness

$$L/Do = 3.5/13.99 = .2502 \quad Do/t = 13.99/0.03032 = 461.4116$$

From table G: $A = 0.000587$
 From table HA-3: $B = 5117.2$

$$Pa = 4*B/(3*Do/t)$$

$$= 4*5117.2/(3*13.99/0.03032)$$

$$= 14.7871 \text{ psi}$$

Nozzle required thickness $trn = .03032 \text{ in}$

Required thickness tr from UG-37(d)(1) = .239 in

Area required

Allowable stresses: $Sn = 14700$, $Sv = 14700$, $Sp = 14700 \text{ psi}$

$fr1 = \text{lesser of } 1 \text{ or } Sn/Sv \text{ so } fr1 = 1$
 $fr2 = \text{lesser of } 1 \text{ or } Sn/Sv \text{ so } fr2 = 1$
 $fr3 = \text{lesser of } fr2 \text{ or } Sp/Sv \text{ so } fr3 = 1$
 $fr4 = \text{lesser of } 1 \text{ or } Sp/Sv \text{ so } fr4 = 1$

REV 0
 Doc. No. VCVS-1-015
 Page 19 of 57

Nozzle E

$$\begin{aligned}
 A &= 0.5*(d*tr*F + 2*tn*tr*F*(1 - fr1)) \\
 &= 0.5*(13.75*0.239*1 + 2*0.12*0.239*1*(1 - 1)) \\
 &= 1.6431 \text{ in}^2
 \end{aligned}$$

Area available

$$\begin{aligned}
 A1 &= \text{larger of the following} && = .151 \text{ in}^2 \\
 &= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\
 &= 13.75*(1*0.25-1*0.239) - 2*0.12*(1*0.25-1*0.239)*(1-1) \\
 &= .151 \text{ in}^2 \\
 &= 2*(t+ tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\
 &= 2*(0.25+0.12)*(1*0.25-1*0.239) - 2*0.12*(1*0.25-1*0.239)*(1-1) \\
 &= .008 \text{ in}^2
 \end{aligned}$$

$$\begin{aligned}
 A2 &= \text{smaller of the following} && = 0.099 \text{ in}^2 \\
 &= 5*(tn - trn)*fr2*t \\
 &= 5*(0.12 - 0.03032)*1*0.25 \\
 &= .112 \text{ in}^2 \\
 &= 2*(tn - trn)*(2.5*tn + tc)*fr2 \\
 &= 2*(0.12 - 0.03032)*(2.5*0.12 + 0.25)*1 \\
 &= .099 \text{ in}^2
 \end{aligned}$$

$$\begin{aligned}
 A41 &= Leg^2*fr3 \\
 &= 0.125^2*1 = .016 \text{ in}^2
 \end{aligned}$$

$$\begin{aligned}
 A42 &= Leg^2*fr4 \\
 &= 0.25^2*1 = .063 \text{ in}^2
 \end{aligned}$$

$$\begin{aligned}
 A5 &= (Dp - d - 2*tn)*tc*fr4 \\
 &= (20 - 13.75 - 2*0.12)*0.25*1 \\
 &= 1.5025 \text{ in}^2
 \end{aligned}$$

$$\begin{aligned}
 \text{Area} &= A1 + A2 + A41 + A42 + A5 \\
 &= 0.151 + 0.099 + 0.016 + 0.063 + 1.5025 \\
 &= 1.8315 \text{ in}^2
 \end{aligned}$$

As Area > A the reinforcement is adequate for Pc = 14.7 at 400 Deg F

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.03032 in (E = 1)
Wall thickness per UG-45(b)(2):	tr2 = 0.0522 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.328125 in
The greater of tr2 or tr3:	tr5 = 0.0625 in
The lesser of tr4 or tr5:	tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

REV 0
 V049-1-015
 Page 20 of 22

Nozzle E

Available nozzle wall thickness new, $t_n = 0.12$ in

The nozzle neck thickness is adequate for P_e .

REV 0

Doc. No. 1049-1-015

Page 21 of 57

Nozzle EApplied Loads

Radial load	Pr = 2183 lbf
Circumferential moment	Mc = 0 lbf-ft
Circumferential shear	Vc = 0 lbf
Longitudinal moment	ML = 0 lbf-ft
Longitudinal shear	VL = 0 lbf
Torsion moment	Mt = 0 lbf-ft
Internal pressure	P = 2 psi

Stresses at the nozzle OD per WRC bulletin 107 (psi)

Mean radius Rm = 52.25 in
Rm/t = 104.5

Stress concentration factor Kn (tension) = 1
Stress concentration factor Kb (bending) = 1

Pressure stress intensity factor, Farr equation 11.5

$$\begin{aligned}
 I &= .25*(4 + 3*(r/x)^2 + 3*(r/x)^4) \\
 &= .25*(4 + 3*(6.875/7.12)^2 + 3*(6.875/7.12)^4) \\
 &= 2.351
 \end{aligned}$$

Local circ. pressure stress = $I*P*Rm/t = 491$ psi

Local long. pressure stress = $P*Rm/2t = 104$ psi

Maximum combined stress = -4686 psi
Allowable combined stress = $+3*S = \pm 44100$ psi

The maximum combined stress is within allowable limits.

Maximum primary membrane stress = -1154 psi
Allowable primary membrane stress = $+1.5*S = \pm 22050$ psi

The maximum primary membrane stress is within allowable limits.

REV 0

Doc. No. V049-1-015

Page 22 of 57

Nozzle E

From Fig.	Value read	beta	Au	A1	Bu	B1	Cu	C1	Du	D1
3C*	10.677	0.117					-892	-892	-892	-892
4C*	15.057	0.117	-1258	-1258	-1258	-1258				
1C	0.0765	0.117					-4008	4008	-4008	4008
2C-1	0.0440	0.117	-2305	2305	-2305	2305				
3A*	4.1315	0.117								
1A	0.0774	0.117								
3B*	11.036	0.117								
1B-1	0.0281	0.117								
pressure stress*			491	491	491	491	491	491	491	491
Total circ stress			-3072	1538	-3072	1538	-4409	3607	-4409	3607
Primary membrane circ stress*			-767	-767	-767	-767	-401	-401	-401	-401
3C*	10.677	0.117	-892	-892	-892	-892				
4C*	15.057	0.117					-1258	-1258	-1258	-1258
1C-1	0.0744	0.117	-3898	3898	-3898	3898				
2C	0.0467	0.117					-2447	2447	-2447	2447
4A*	7.5665	0.117								
2A	0.0389	0.117								
4B*	4.0872	0.117								
2B-1	0.0385	0.117								
pressure stress*			104	104	104	104	104	104	104	104
Total long stress			-4686	3110	-4686	3110	-3601	1293	-3601	1293
Primary membrane long stress*			-788	-788	-788	-788	-1154	-1154	-1154	-1154
torsion moment Mt										
Circ shear from Vc										
Long shear from VL										
Total Shear stress										
Combined stress			-4686	3110	-4686	3110	-4409	3607	-4409	3607

REV 0

Doc. No. V049-1-015

Page 23 of 57

Nozzle EStresses at the pad edge per WRC bulletin 107 (psi)

Mean radius $R_m = 52.25$ in
 $R_m/t = 209$

Stress concentration factor K_n (tension) = 1
 Stress concentration factor K_b (bending) = 1

Pressure stress intensity factor, Farr equation 11.5

$$I = .25*(4 + 3*(r/x)^2 + 3*(r/x)^4)$$

$$= .25*(4 + 3*(6.875/10.25)^2 + 3*(6.875/10.25)^4)$$

$$= 1.489$$

Local circ. pressure stress = $I*P*R_m/t = 622$ psi

Local long. pressure stress = $P*R_m/2t = 209$ psi

Maximum combined stress = -13222 psi
 Allowable combined stress = $+3*S = \pm 44100$ psi

The maximum combined stress is within allowable limits.

Maximum primary membrane stress = -3300 psi
 Allowable primary membrane stress = $+1.5*S = \pm 22050$ psi

The maximum primary membrane stress is within allowable limits.

Nozzle E

From Fig.	Value read	beta	Au	A1	Bu	B1	Cu	C1	Du	D1
3C*	8.2255	0.167					-1375	-1375	-1375	-1375
4C*	20.996	0.167	-3509	-3509	-3509	-3509				
1C	0.0595	0.167					-12469	12469	-12469	12469
2C-1	0.0148	0.167	-3102	3102	-3102	3102				
3A*	6.4789	0.167								
1A	0.0553	0.167								
3B*	13.437	0.167								
1B-1	0.0104	0.167								
pressure stress*			622	622	622	622	622	622	622	622
Total circ stress Primary membrane circ stress*			-5989	215	-5989	215	-13222	11716	-13222	11716
			-2887	-2887	-2887	-2887	-753	-753	-753	-753
3C*	8.2255	0.167	-1375	-1375	-1375	-1375				
4C*	20.996	0.167					-3509	-3509	-3509	-3509
1C-1	0.0390	0.167	-8173	8173	-8173	8173				
2C	0.0353	0.167					-7398	7398	-7398	7398
4A*	17.794	0.167								
2A	0.0238	0.167								
4B*	5.7771	0.167								
2B-1	0.0144	0.167								
pressure stress*			209	209	209	209	209	209	209	209
Total long stress Primary membrane long stress*			-9339	7007	-9339	7007	-10698	4098	-10698	4098
			-1166	-1166	-1166	-1166	-3300	-3300	-3300	-3300
torsion moment Mt										
Circ shear from Vc										
Long shear from VL										
Total Shear stress										
Combined stress			-9339	7007	-9339	7007	-13222	11716	-13222	11716

Rev 0
 Doc No V049-1-015
 Page 25 of 57


Nozzle G

Opening N-G Reinforcement Calculations Per UG-37

Located on: Main Section Cylinder
 Local vessel thickness: .5 in
 Liquid static head included: 0 psi
 Flange description: 8 inch 75# WN A240304L
 ANSI B16.47 flange rating MAP: 115 psi
 ANSI B16.47 flange rating MAWP: 80 psi

Nozzle material specification: SA 240 304L HIGH

Nozzle orientation: 90 degrees
 End of nozzle to shell center: 55.625 in
 Nozzle offset from center Lo: 0 in
 Projection outside vessel Lpr: 3 in



corrosion allow = 0 in
 noz thick new $t_n = .12$ in
 nozzle id. new $d = 7.75$ in
 fillet weld $tw_1 = .125$ in
 groove weld $tw_2 = .1875$ in

To datum $L = 40$ in

Reinforcement Calculations For Nozzle MAWP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.75$ in
 Normal to the vessel wall outside $2.5*(t_n - C_n) + t_e = .3$ in
 Normal to the vessel wall inside $2.5*(t_n - C_n - C) = .3$ in

Nozzle required thickness

$$\begin{aligned}
 t_{rn} &= P \cdot R_n / (S_n \cdot E - 0.6 \cdot P) \\
 &= 2 \cdot 3.875 / (14700 \cdot 1 - 0.6 \cdot 2) \\
 &= 0.0005 \text{ in}
 \end{aligned}$$

Required thickness t_r from UG-37(a)

$$\begin{aligned}
 t_r &= P \cdot R / (S \cdot E - 0.6 \cdot P) \\
 &= 2 \cdot 52.125 / (14700 \cdot 1 - 0.6 \cdot 2) \\
 &= 0.0071 \text{ in}
 \end{aligned}$$

Area required

Allowable stresses: $S_n = 14700$, $S_v = 14700$, psi

$fr_1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr_1 = 1$

Rev 0
 Doc No 1009-1-015
 Page 26 of 57

Nozzle G

$$fr2 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr2 = 1$$

$$\begin{aligned} A &= d*tr*F + 2*tn*tr*F*(1 - fr1) \\ &= 7.75*0.0071*1 + 2*0.12*0.0071*1*(1 - 1) \\ &= .055 \text{ in}^2 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} = 3.82 \text{ in}^2$$

$$\begin{aligned} &= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 7.75*(1*0.5-1*0.0071) - 2*0.12*(1*0.5-1*0.0071)*(1-1) \\ &= 3.82 \text{ in}^2 \\ &= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 2*(0.5+0.12)*(1*0.5-1*0.0071) - 2*0.12*(1*0.5-1*0.0071)*(1-1) \\ &= .611 \text{ in}^2 \end{aligned}$$

$$A2 = \text{smaller of the following} = 0.072 \text{ in}^2$$

$$\begin{aligned} &= 5*(tn - trn)*fr2*t \\ &= 5*(0.12 - 0.0005)*1*0.5 \\ &= .299 \text{ in}^2 \\ &= 5*(tn - trn)*fr2*tn \\ &= 5*(0.12 - 0.0005)*1*0.12 \\ &= .072 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A41 &= Leg^2*fr2 \\ &= 0.125^2*1 = .016 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 3.82 + 0.072 + 0.016 \\ &= 3.908 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAWP = 2 at 400 Deg F

Check the welds - From UW-16(d):

$$\begin{aligned} t_{min} &= \text{lesser of } 0.75 \text{ or } t_n \text{ or } t, t_{min} = 0.12 \text{ in} \\ t1 \text{ or } t2(\text{min}) &= \text{lesser of } 0.25 \text{ or } 0.7*t_{min}, t1(\text{min}) = 0.084 \text{ in} \\ t1(\text{actual}) &= 0.7*Leg = 0.7*0.125 = 0.0875 \text{ in} \\ t2(\text{actual}) &= 0.1875 \text{ in} \\ t1 + t2 &= 0.275 \geq 1.25*t_{min} \end{aligned}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.0005 in (E = 1)
Wall thickness per UG-45(b)(1):	tr2 = 0.0071 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in

REV 0

Doc. No. VC45-1-015

Nozzle G

The greater of tr2 or tr3: tr5 = 0.0625 in
 The lesser of tr4 or tr5: tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Available nozzle wall thickness new, tn = 0.12 in

The nozzle neck thickness is adequate for MAWP.

Allowable stresses in joints UG-45(c) and UW-15(c)

Groove weld in tension = $0.74 \cdot 14700 = 10878$ psi

Nozzle wall in shear = $0.7 \cdot 14700 = 10290$ psi

Inner fillet weld in shear = $0.49 \cdot 14700 = 7203$ psi

Strength of welded joints:

(1) Inner fillet weld in shear

$$(\pi/2) \cdot \text{Nozzle O.D.} \cdot \text{Leg} \cdot S_i = 1.57 \cdot 7.99 \cdot 0.125 \cdot 7203 = 11294.57 \text{ lbf}$$

(3) Nozzle wall in shear

$$(\pi/2) \cdot \text{Mean nozzle dia.} \cdot t_n \cdot S_n = 1.57 \cdot 7.87 \cdot 0.12 \cdot 10290 = 15257.07 \text{ lbf}$$

(4) Groove weld in tension

$$(\pi/2) \cdot \text{Nozzle O.D.} \cdot t_w \cdot S_g = 1.57 \cdot 7.99 \cdot 0.1875 \cdot 10878 = 25585.67 \text{ lbf}$$

Loading on welds per UG-41(b)(1)

$$\begin{aligned} W &= (A - (d - 2 \cdot t_n) \cdot (E1 \cdot t - F \cdot t_r)) \cdot S_v \\ &= (0.055 - (7.75 - 2 \cdot 0.12) \cdot (1 \cdot 0.5 - 1 \cdot 0.0071)) \cdot 14700 \\ &= -53606.18 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W1-1 &= (A2 + A5 + A41 + A42) \cdot S_v \\ &= (0.072 + 0 + 0.016 + 0) \cdot 14700 \\ &= 1293.6 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W2-2 &= (A2 + A3 + A41 + A43 + 2 \cdot t_n \cdot t \cdot f_{r1}) \cdot S_v \\ &= (0.072 + 0 + 0.016 + 0 + 2 \cdot 0.12 \cdot 0.5 \cdot 1) \cdot 14700 \\ &= 3057.6 \text{ lbf} \end{aligned}$$

Load for path 1-1 lesser of W or W1-1 = -53606.18 lbf

Path 1-1 Thru (1) & (3) = $11294.57 + 15257.07 = 26551.64$ lbf

Path 1-1 is stronger than W so it is acceptable per UG-41(b)(2).

Load for path 2-2 lesser of W or W2-2 = -53606.18 lbf

Path 2-2 Thru (1), (4) = $11294.57 + 25585.67 = 36880.24$ lbf

Path 2-2 is stronger than W so it is acceptable per UG-41(b)(2).

Reinforcement Calculations for External PressureLimits of reinforcement UG-40

Parallel to the vessel wall d = 7.75 in

REV 0
 Doc. No VC49-1-015
 Page 28 of 57

Nozzle G

Normal to the vessel wall outside $2.5*(t_n - C_n) + t_c = .3$ in
 Normal to the vessel wall inside $2.5*(t_n - C_n - C) = .3$ in

Nozzle required thickness

$$L/Do = 3/7.99 = .3755 \quad Do/t = 7.99/0.01833 = 435.8974$$

From table G: $A = 0.000412$
 From table HA-3: $B = 4808.2$

$$Pa = 4*B/(3*Do/t)$$

$$= 4*4808.2/(3*7.99/0.01833)$$

$$= 14.7074 \text{ psi}$$

Nozzle required thickness $t_{rn} = .01833$ in

Required thickness t_r from UG-37(d)(1) = .3075 in

Area required

Allowable stresses: $S_n = 14700$, $S_v = 14700$, psi

$fr_1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr_1 = 1$
 $fr_2 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr_2 = 1$

$$A = 0.5*(d*t_r*F + 2*t_n*t_r*F*(1 - fr_1))$$

$$= 0.5*(7.75*0.3075*1 + 2*0.12*0.3075*1*(1 - 1))$$

$$= 1.1916 \text{ in}^2$$

Area available

$A_1 = \text{larger of the following} = 1.492 \text{ in}^2$

$$= d*(E_1*t - F*t_r) - 2*t_n*(E_1*t - F*t_r)*(1 - fr_1)$$

$$= 7.75*(1*0.5 - 1*0.3075) - 2*0.12*(1*0.5 - 1*0.3075)*(1 - 1)$$

$$= 1.492 \text{ in}^2$$

$$= 2*(t + t_n)*(E_1*t - F*t_r) - 2*t_n*(E_1*t - F*t_r)*(1 - fr_1)$$

$$= 2*(0.5 + 0.12)*(1*0.5 - 1*0.3075) - 2*0.12*(1*0.5 - 1*0.3075)*(1 - 1)$$

$$= .239 \text{ in}^2$$

$A_2 = \text{smaller of the following} = 0.061 \text{ in}^2$

$$= 5*(t_n - t_{rn})*fr_2*t$$

$$= 5*(0.12 - 0.01833)*1*0.5$$

$$= .254 \text{ in}^2$$

$$= 5*(t_n - t_{rn})*fr_2*t_n$$

$$= 5*(0.12 - 0.01833)*1*0.12$$

$$= .061 \text{ in}^2$$

$$A_{41} = Leg^2*fr_2$$

$$= 0.125^2*1 = .016 \text{ in}^2$$

Rev 0

Doc No. VC49-1-015

Page 28 of 37

Nozzle G

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 1.492 + 0.061 + 0.016 \\ &= 1.569 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for $P_e = 14.7$ at 400 Deg F

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	$tr1 = 0.01833 \text{ in (E = 1)}$
Wall thickness per UG-45(b)(2):	$tr2 = 0.0522 \text{ in}$
Wall thickness per UG-16(b):	$tr3 = 0.0625 \text{ in}$
Std pipe wall per UG-45(b)(4):	$tr4 = 0.28175 \text{ in}$
The greater of $tr2$ or $tr3$:	$tr5 = 0.0625 \text{ in}$
The lesser of $tr4$ or $tr5$:	$tr6 = 0.0625 \text{ in}$

Req'd per UG-45 is the larger of $tr1$ or $tr6 = 0.0625 \text{ in}$

Available nozzle wall thickness new, $tn = 0.12 \text{ in}$

The nozzle neck thickness is adequate for P_e .

Nozzle GApplied Loads

Radial load	$P_r = 693.4 \text{ lbf}$
Circumferential moment	$M_c = 0 \text{ lbf-ft}$
Circumferential shear	$V_c = 0 \text{ lbf}$
Longitudinal moment	$M_L = 0 \text{ lbf-ft}$
Longitudinal shear	$V_L = 0 \text{ lbf}$
Torsion moment	$M_t = 0 \text{ lbf-ft}$
Internal pressure	$P = 2 \text{ psi}$

Stresses at the nozzle OD per WRC bulletin 107 (psi)

Mean radius $R_m = 52.375 \text{ in}$
 $R_m/t = 104.75$

Stress concentration factor K_n (tension) = 1
 Stress concentration factor K_b (bending) = 1

Pressure stress intensity factor, Farr equation 11.5

$$I = .25*(4 + 3*(r/x)^2 + 3*(r/x)^4)$$

$$= .25*(4 + 3*(3.875/4.12)^2 + 3*(3.875/4.12)^4)$$

$$= 2.25$$

Local circ. pressure stress = $I*P*R_m/t = 471 \text{ psi}$

Local long. pressure stress = $P*R_m/2t = 105 \text{ psi}$

Maximum combined stress = -2379 psi
 Allowable combined stress = $\pm 3*S = \pm 44100 \text{ psi}$

The maximum combined stress is within allowable limits.

Maximum primary membrane stress = -364 psi
 Allowable primary membrane stress = $\pm 1.5*S = \pm 22050 \text{ psi}$

The maximum primary membrane stress is within allowable limits.

Nozzle G

From Fig.	Value read	beta	Au	A1	Bu	B1	Cu	C1	Du	D1
3C*	16.021	0.067					-424	-424	-424	-424
4C*	17.720	0.067	-469	-469	-469	-469				
1C	0.1209	0.067					-2012	2012	-2012	2012
2C-1	0.0837	0.067	-1393	1393	-1393	1393				
3A*	3.2919	0.067								
1A	0.0926	0.067								
3B*	10.724	0.067								
1B-1	0.0440	0.067								
pressure stress*			471	471	471	471	471	471	471	471
Total circ stress			-1391	1395	-1391	1395	-1965	2059	-1965	2059
Primary membrane circ stress*			2	2	2	2	47	47	47	47
3C*	16.021	0.067	-424	-424	-424	-424				
4C*	17.720	0.067					-469	-469	-469	-469
1C-1	0.1238	0.067	-2060	2060	-2060	2060				
2C	0.0837	0.067					-1393	1393	-1393	1393
4A*	4.8183	0.067								
2A	0.0535	0.067								
4B*	3.2756	0.067								
2B-1	0.0696	0.067								
pressure stress*			105	105	105	105	105	105	105	105
Total long stress			-2379	1741	-2379	1741	-1757	1029	-1757	1029
Primary membrane long stress*			-319	-319	-319	-319	-364	-364	-364	-364
torsion moment Mt										
Circ shear from Vc										
Long shear from VL										
Total Shear stress										
Combined stress			-2379	1741	-2379	1741	-1965	2059	-1965	2059

REV 0
 Doc. No. V009-1-015
 Page 22 of 27

MAXIMUM ALLOWABLE COMPRESSIVE STRESS
IN UPPER SECTION CYLINDRICAL SHELL

REF: UG-23(b)

$$A = \frac{.125}{(R_o/t)}$$

$$R_o = 52.375 \text{ IN}$$

$$t = .25 \text{ IN}$$

$$A = 597 (1.0)^{-4}$$

$$B = 5750 \text{ (FIG. NA-1 FOR TP304
ALLOWABLE STRESS, II, P. 640)}$$

LONGITUDINAL STRESS

$$S_L = \frac{PR}{2t}$$

$$= \frac{14.7(52.375)}{2(.25)}$$

$$= 1540 \text{ psi} < B = 5750 \text{ psi}$$

REQUIREMENT OF UG-23(b) IS MET
CYLINDRICAL SHELL



105 IN ID SHELL *

HEAD FOR 105 ID SHELL

DIMENSIONS FROM SECT VIII, Div 1, UG-32(b)

CROWN ANALYSIS (INSIDE)

$$ICR = OD \text{ OF SHELL}$$

$$= 105 + 2t$$

$$t = .375$$

$$ICR = 105 + 2(.375) = 105.75$$

$$KUTCHER'S ANALYSIS = 6\% \text{ OF } ICR$$

$$= .06(105.75) = 6.345 \text{ IN}$$

COMPRESS ANALYSIS OF BSC WITH RN
INCREASED ID = 105 IN FOLLOWS

FILENAME: BSC105ID.VSL

RESULTS SHOW THAT CODE REQUIREMENTS ARE
MET FOR THE INCREASED ID.

* FINAL ID IS 104.5 IN



Top Head - BSC

ASME Section VIII Division 1, 1992 Edition, A93 Addenda

Component: F&D head
 Material specification: SA 240 304L HIGH
 Internal design pressure: P = 2 psi @ 400 deg F
 External design pressure: Pe = 14.7 psi @ 400 deg F
 Corrosion allowance: Inner C = 0 Outer = 0 in

PWHT is not performed

Radiography: Category A joints - Spot UW-11(b) type 1
 Head to shell seam - Spot UW-11(b) type 1

Estimated weight: new = 1140.8 lb
 capacity: new = 474.64 US ga
 corr = 1140.8
 corr = 474.64

ID = 105 crown L = 105.75 knuckle r = 6.345 t = .34375 in (min)

3/8 - 1/32 FOR THINNING

Straight flange = 2 forming allowance = 0 in

WARNING! F&D head geometry is not per UG-32(j).

Design thickness: (At 400 deg F) Appendix 1-4(d) Eq 3

$$M = .25*(3 + (L/r)^.5)$$

$$= .25*(3 + (105.75/6.345)^.5)$$

$$= 1.7706$$

$$t = P*L*M/(2*S*E - 0.2*P) + Corrosion + fa$$

$$= 2*105.75*1.7706/(2*14700*0.85 - 0.2*2) + 0 + 0$$

$$= 0.015 \text{ in}$$

MAP: (New & at 0 deg F) Appendix 1-4(d) Eq 3

$$P = 2*S*E*t/(L*M + 0.2*t) - Ps$$

$$= 2*16700*0.85*0.34375/(105.75*1.7706 + 0.2*0.34375) - 0$$

$$= 52.10122 \text{ psi}$$

MAWP: (Corroded & at 400 deg F) Appendix 1-4(d) Eq 3

$$P = 2*S*E*t/(L*M + 0.2*t) - Ps$$

$$= 2*14700*0.85*0.34375/(105.75*1.7706 + 0.2*0.34375) - 0$$

$$= 45.86155 \text{ psi}$$

External Pressure: (Corroded & at 400 deg F) UG-33(e)

$$A = .125/(Ro/t)$$

$$= .125/(106.0938/0.32873)$$

$$= 0.000387$$

REV 0
Doc. No. V049-1-05
Page 35 of 37

Top Head - BSC

From table HA-3: $B = 4755.5$

$$\begin{aligned} Pa &= B/(Ro/t) \\ &= 4755.5/(106.0938/0.32873) \\ &= 14.7348 \text{ psi} \end{aligned}$$

Check the external pressure per UG-33(a)(1)

$$\begin{aligned} t &= 1.67*Pa*Lo*M/(2*S*E + 1.67*Pa*(M-0.2)) \\ &= 1.67*14.7348*106.0938*1.7706/(2*14700*1 + 1.67*14.7348*(1.7706-0.2)) \\ &= 0.15702 \text{ in} \end{aligned}$$

Design thickness for external pressure Pa = 14.7348 psi:

$$\begin{aligned} &= t + \text{Corrosion} + fa \\ &= 0.32873 + 0 + 0 \\ &= 0.32873 \text{ in} \end{aligned}$$

Maximum Allowable External Pressure: (Corroded @ 400 deg F)

$$\begin{aligned} A &= .125/(Ro/t) \\ &= .125/(106.0938/0.34375) \\ &= 0.000405 \end{aligned}$$

From table HA-3: $B = 4793.7$

$$\begin{aligned} Pa &= B/(Ro/t) \\ &= 4793.7/(106.0938/0.34375) \\ &= 15.5319 \text{ psi} \end{aligned}$$

Check the Maximum External Pressure: UG-33(a)(1) & App. 1-4(d)

$$\begin{aligned} Pc &= 2*S*E*t/((M*Lo - t*(M-0.2))*1.67) \\ &= 2*14700*1*0.34375/((1.7706*106.0938 - 0.34375*(1.7706-0.2))*1.67) \\ &= 32.30824 \text{ psi} \end{aligned}$$

The maximum allowable external pressure is 15.5319 psi.

Upper Cylindrical Shell - BSCASME Section VIII Division 1, 1992 Edition, A93 Addenda

Component: Cylinder
 Material specification: SA 240 304L HIGH

Internal design pressure: $P = 2$ psi @ 400 deg F
 External design pressure: $P_e = 14.7$ psi @ 400 deg F

Corrosion allowance: Inner $C = 0$ Outer = 0 in

PWHT is not performed

Radiography: Category A joints - Spot UW-11(b) type 1
 Category B joints - Spot UW-11(b) type 1

Estimated weight: new = 1438.3 corr = 1438.3 lb
 capacity: new = 2249.093 corr = 2249.093 US ga

ID = 105 length $L_c = 60$ $t = 0.25$ in (new)

Design thickness: UG-27(c)(1) Circ. stress

$$t = P \cdot R / (S \cdot E - 0.6 \cdot P) + \text{Corrosion}$$

$$= 2 \cdot 52.5 / (14700 \cdot 0.85 - 0.6 \cdot 2) + 0$$

$$= 0.0084 \text{ in}$$

MAP: (New & at 0 deg F) UG-27(c)(1)

$$P = S \cdot E \cdot t / (R + 0.6 \cdot t) - P_s$$

$$= 16700 \cdot 0.85 \cdot 0.25 / (52.5 + 0.6 \cdot 0.25) - 0$$

$$= 67.40266 \text{ psi}$$

MAWP: (Corroded & at 400 deg F) UG-27(c)(1)

$$P = S \cdot E \cdot t / (R + 0.6 \cdot t) - P_s$$

$$= 14700 \cdot 0.85 \cdot 0.25 / (52.5 + 0.6 \cdot 0.25) - 0$$

$$= 59.33049 \text{ psi}$$

External Pressure: (Corroded & at 400 deg F) UG-28

$$L/Do = 37.90327/105.5 = 0.3593 \quad Do/t = 105.5/0.24092 = 437.9047$$

From table G: $A = 0.000429$
 From table HA-3: $B = 4842.5$

$$P_a = 4 \cdot B / (3 \cdot Do/t)$$

$$= 4 \cdot 4842.5 / (3 \cdot 105.5/0.24092)$$

$$= 14.7445 \text{ psi}$$

Design thickness for external pressure $P_a = 14.7445$ psi:

$$= t + \text{Corrosion}$$

$$= 0.24092 + 0$$

Upper Cylindrical Shell - BSC

$$= 0.24092 \text{ in}$$

Maximum Allowable External Pressure: (Corroded @ 400 deg F)

$$\begin{aligned} L/Do &= 37.90327/105.5 = 0.3593 & Do/t &= 105.5/0.25 = 422 \\ \text{From table G:} & & A &= 0.000452 \\ \text{From table HA-3:} & & B &= 4887.2 \end{aligned}$$

$$\begin{aligned} Pa &= 4*B/(3*Do/t) \\ &= 4*4887.2/(3*105.5/0.25) \\ &= 15.4414 \text{ psi} \end{aligned}$$

Shell StiffenerStiffening Ring Calculations Per UG-29ASME Section VIII Division 1, 1992 Edition, A93 Addenda

Identifier:	Shell Stiffener
Ring material specification:	SA 240 304L HIGH
Number of rings in this group:	1
Distance first ring to datum line:	110 in
Ring spacing:	0 in
Ring description:	4x4x1/4 Equal Angle
Ring is rolled:	leg out (easy way)
Ring cross sectional area:	As = 1.94 in ²
Ring moment of inertia:	Ir = 3.04 in ⁴

Calculations for ring 110 in from datum

Shell material specification:	SA 240 304L HIGH
Required shell thickness:	t = 0.24092 in
Corroded shell thickness:	ts = 0.25 in
Shell outer diameter:	Do = 105.5 in
Design temperature:	= 400 deg F
External design pressure:	P = 14.7 psi
Stiffener supported length:	Ls = 33.95164 in

$$\begin{aligned}
 B &= .75*(P*Do/(t + As/Ls)) \\
 &= .75*(14.7*105.5/(0.24092 + 1.94/33.95164)) \\
 &= 3902.359
 \end{aligned}$$

$$\text{From table HA-3 (ring)} \quad A = 2.951318E-04$$

Required moment of inertia of the combined ring-shell section

$$\begin{aligned}
 I_s &= (Do^2*Ls*(t + As/Ls)*A)/10.9 \\
 &= (105.5^2*33.95164*(0.24092 + 1.94/33.95164)*2.951318E-04)/10.9 \\
 &= 3.049713 \text{ in}^4
 \end{aligned}$$

Available moment of inertia of the combined ring-shell section

$$\text{Shell width contributing smaller of} \quad = 5.649226$$

$$\begin{aligned}
 W &= 1.1*\text{Sqr}(Do*ts) \\
 &= 1.1*\text{Sqr}(105.5*0.25) \\
 &= 5.649226 \text{ in}
 \end{aligned}$$

$$W = Ls = 33.95164 \text{ in}$$

$$\text{Shell area } A1 = W*ts = 1.412306 \text{ in}^2$$

Distance to the ring neutral axis

Rev 0

Doc. No. V000-1-115

Shell Stiffener

$$\begin{aligned}
 Y2 &= \text{Ring NA} + ts/2 \\
 &= 1.09 + 0.25/2 \\
 &= 1.215 \text{ in}
 \end{aligned}$$

Neutral axis of combined section

$$\begin{aligned}
 \text{NA} &= A_s * Y2 / (A_1 + A_s) \\
 &= 1.94 * 1.215 / (1.412306 + 1.94) \\
 &= .7031279 \text{ in}
 \end{aligned}$$

Inertia of the shell about the combined section NA

$$\begin{aligned}
 I1 &= W * ts^3 / 12 + A1 * \text{NA}^2 \\
 &= 5.649226 * 0.25^3 / 12 + 1.412306 * 0.7031279^2 \\
 &= .7055842 \text{ in}^4
 \end{aligned}$$

Inertia of the ring about the combined section NA

$$\begin{aligned}
 I2 &= I_r + A_s * (\text{NA} - Y2)^2 \\
 &= 3.04 + 1.94 * (0.7031279 - 1.215)^2 \\
 &= 3.548306 \text{ in}^4
 \end{aligned}$$

$$\text{Total available } I = I1 + I2 = 4.25389 \text{ in}^4$$

The 4x4x1/4 Equal Angle vacuum stiffener is satisfactory.

Rev 0

Doc. No. 2049-1-015

Main Section Cylinder

ASME Section VIII Division 1, 1992 Edition, A93 Addenda

Component: Cylinder
 Material specification: SA 240 304L HIGH
 Internal design pressure: P = 2 psi @ 400 deg F
 External design pressure: Pe = 14.7 psi @ 400 deg F
 Corrosion allowance: Inner C = 0 Outer = 0 in

PWHT is not performed

Radiography: Category A joints - Spot UW-11(b) type 1
 Category B joints - Spot UW-11(b) type 1

Estimated weight: new = 3844.7 corr = 3844.7 lb
 capacity: new = 2998.79 corr = 2998.79 US ga

ID = 105 length Lc = 80 t = 0.5 in (new)

Design thickness: UG-27(c)(1) Circ. stress

$$t = P \cdot R / (S \cdot E - 0.6 \cdot P) + \text{Corrosion}$$

$$= 2 \cdot 52.5 / (14700 \cdot 0.85 - 0.6 \cdot 2) + 0$$

$$= 0.0084 \text{ in}$$

MAP: (New & at 0 deg F) UG-27(c)(1)

$$P = S \cdot E \cdot t / (R + 0.6 \cdot t) - P_s$$

$$= 16700 \cdot 0.85 \cdot 0.5 / (52.5 + 0.6 \cdot 0.5) - 0$$

$$= 134.4223 \text{ psi}$$

MAWP: (Corroded & at 400 deg F) UG-27(c)(1)

$$P = S \cdot E \cdot t / (R + 0.6 \cdot t) - P_s$$

$$= 14700 \cdot 0.85 \cdot 0.5 / (52.5 + 0.6 \cdot 0.5) - 0$$

$$= 118.3239 \text{ psi}$$

External Pressure: (Corroded & at 400 deg F) UG-28

$$L/Do = 80/106 = 0.7547 \quad Do/t = 106/0.30843 = 343.6761$$

From table G: A = 0.000288
 From table HA-3: B = 3807.2

$$P_a = 4 \cdot B / (3 \cdot Do/t)$$

$$= 4 \cdot 3807.2 / (3 \cdot 106/0.30843)$$

$$= 14.7705 \text{ psi}$$

Design thickness for external pressure Pa = 14.7705 psi:

$$= t + \text{Corrosion}$$

$$= 0.30843 + 0$$

REV 0

Doc. No. V049-1-015

Main Section Cylinder

$$= 0.30843 \text{ in}$$

Maximum Allowable External Pressure: (Corroded @ 400 deg F)

$$L/D_o = 80/106 = 0.7547$$

From table G:

From table HA-3:

$$D_o/t = 106/0.5 = 212$$

$$A = 0.000586$$

$$B = 5115.7$$

$$P_a = 4*B/(3*D_o/t)$$

$$= 4*5115.7/(3*106/0.5)$$

$$= 32.1742 \text{ psi}$$

REV D

Doc No. V009-1-015

Page 406 of 57

Nozzle E


Opening N-E Reinforcement Calculations Per UG-37

Located on: Upper Cylindrical Shell - BSC
 Local vessel thickness: .25 in
 Liquid static head included: 0 psi
 Flange description: 14 inch 75# SO A240304L
 ANSI B16.47 flange rating MAP: 115 psi
 ANSI B16.47 flange rating MAWP: 80 psi

Nozzle material specification: SA 240 304L HIGH

Pad material specification: SA 240 304L HIGH

Nozzle orientation: 45 degrees
 End of nozzle to shell center: 55.875 in
 Nozzle offset from center Lo: 0 in
 Projection outside vessel Lpr: 3.125 in



corrosion allow = 0 in
 noz thick new tn = .12 in
 nozzle id. new d = 13.75 in
 pad diameter dp = 20 in
 pad thickness te = .25 in
 fillet weld tw1 = .125 in
 fillet weld tw2 = .25 in
 groove weld tw3 = .25 in
 To datum L = 124 in

Reinforcement Calculations For Nozzle MAWP

Limits of reinforcement UG-40

Parallel to the vessel wall d = 13.75 in
 Normal to the vessel wall outside 2.5*(tn-Cn) + te = .55 in
 Normal to the vessel wall inside 2.5*(tn-Cn-C) = .3 in

Nozzle required thickness

$$trn = P \cdot Rn / (Sn \cdot E - 0.6 \cdot P)$$

$$= 2 \cdot 6.875 / (14700 \cdot 1 - 0.6 \cdot 2)$$

$$= 0.0009 \text{ in}$$

Required thickness tr from UG-37(a)

$$tr = P \cdot R / (S \cdot E - 0.6 \cdot P)$$

$$= 2 \cdot 52.5 / (14700 \cdot 1 - 0.6 \cdot 2)$$

$$= 0.0071 \text{ in}$$

Area required

Rev 0
 Doc. No. V049-1-015
 Page 41 of 57

Nozzle E

Allowable stresses: $S_n = 14700$, $S_v = 14700$, $S_p = 14700$ psi

$fr_1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr_1 = 1$

$fr_2 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr_2 = 1$

$fr_3 = \text{lesser of } fr_2 \text{ or } S_p/S_v \text{ so } fr_3 = 1$

$fr_4 = \text{lesser of } 1 \text{ or } S_p/S_v \text{ so } fr_4 = 1$

$$\begin{aligned} A &= d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F \cdot (1 - fr_1) \\ &= 13.75 \cdot 0.0071 \cdot 1 + 2 \cdot 0.12 \cdot 0.0071 \cdot 1 \cdot (1 - 1) \\ &= .0976 \text{ in}^2 \end{aligned}$$

Area available

$$A_1 = \text{larger of the following} = 3.34 \text{ in}^2$$

$$\begin{aligned} &= d \cdot (E_1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E_1 \cdot t - F \cdot tr) \cdot (1 - fr_1) \\ &= 13.75 \cdot (1 \cdot 0.25 - 1 \cdot 0.0071) - 2 \cdot 0.12 \cdot (1 \cdot 0.25 - 1 \cdot 0.0071) \cdot (1 - 1) \\ &= 3.34 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 \cdot (t + tn) \cdot (E_1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E_1 \cdot t - F \cdot tr) \cdot (1 - fr_1) \\ &= 2 \cdot (0.25 + 0.12) \cdot (1 \cdot 0.25 - 1 \cdot 0.0071) - 2 \cdot 0.12 \cdot (1 \cdot 0.25 - 1 \cdot 0.0071) \cdot (1 - 1) \\ &= .18 \text{ in}^2 \end{aligned}$$

$$A_2 = \text{smaller of the following} = 0.131 \text{ in}^2$$

$$\begin{aligned} &= 5 \cdot (tn - trn) \cdot fr_2 \cdot t \\ &= 5 \cdot (0.12 - 0.0009) \cdot 1 \cdot 0.25 \\ &= .149 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 \cdot (tn - trn) \cdot (2.5 \cdot tn + te) \cdot fr_2 \\ &= 2 \cdot (0.12 - 0.0009) \cdot (2.5 \cdot 0.12 + 0.25) \cdot 1 \\ &= .131 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A_{41} &= Leg^2 \cdot fr_3 \\ &= 0.125^2 \cdot 1 = .016 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A_{42} &= Leg^2 \cdot fr_4 \\ &= 0.25^2 \cdot 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A_5 &= (D_p - d - 2 \cdot tn) \cdot te \cdot fr_4 \\ &= (20 - 13.75 - 2 \cdot 0.12) \cdot 0.25 \cdot 1 \\ &= 1.5025 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A_1 + A_2 + A_{41} + A_{42} + A_5 \\ &= 3.34 + 0.131 + 0.016 + 0.063 + 1.5025 \\ &= 5.0525 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAWP = 2 at 400 Deg F

Check the welds - From UW-16(c)(2)

Inner Fillet: $t_{min} = \text{lesser of } 0.75 \text{ or } tn \text{ or } te$, $t_{min} = 0.12 \text{ in}$
 $tw(\text{min}) = 0.7 \cdot t_{min} = 0.084 \text{ in}$

Rev D

Doc No 4049-1-015

Page 42 of 57

Nozzle E

$$tw(\text{actual}) = 0.7 * \text{Leg} = 0.7 * 0.125 = 0.0875 \text{ in}$$

Outer Fillet: $t_{\min} = \text{lesser of } 0.75 \text{ or } t_e \text{ or } t, t_{\min} = 0.25 \text{ in}$

$$tw(\text{min}) = 0.5 * t_{\min} = 0.125 \text{ in}$$

$$tw(\text{actual}) = 0.7 * \text{Leg} = 0.7 * 0.25 = 0.175 \text{ in}$$

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a): $tr1 = 0.0009 \text{ in (E = 1)}$

Wall thickness per UG-45(b)(1): $tr2 = 0.0071 \text{ in}$

Wall thickness per UG-16(b): $tr3 = 0.0625 \text{ in}$

Std pipe wall per UG-45(b)(4): $tr4 = 0.328125 \text{ in}$

The greater of $tr2$ or $tr3$: $tr5 = 0.0625 \text{ in}$

The lesser of $tr4$ or $tr5$: $tr6 = 0.0625 \text{ in}$

Req'd per UG-45 is the larger of $tr1$ or $tr6 = 0.0625 \text{ in}$

Available nozzle wall thickness new, $t_n = 0.12 \text{ in}$

The nozzle neck thickness is adequate for MAWP.

Allowable stresses in joints UG-45(c) and UW-15(c)

Groove weld in tension = $0.74 * 14700 = 10878 \text{ psi}$

Nozzle wall in shear = $0.7 * 14700 = 10290 \text{ psi}$

Inner fillet weld in shear = $0.49 * 14700 = 7203 \text{ psi}$

Outer fillet weld in shear = $0.49 * 14700 = 7203 \text{ psi}$

Strength of welded joints:

(1) Inner fillet weld in shear

$$(\pi/2) * \text{Nozzle O.D.} * \text{Leg} * S_i = 1.57 * 13.99 * 0.125 * 7203 = 19776.11 \text{ lbf}$$

(2) Outer fillet weld in shear

$$(\pi/2) * \text{Pad O.D.} * \text{Leg} * S_o = 1.57 * 20 * 0.25 * 7203 = 56543.55 \text{ lbf}$$

(3) Nozzle wall in shear

$$(\pi/2) * \text{Mean nozzle dia.} * t_n * S_n = 1.57 * 13.87 * 0.12 * 10290 = 26888.88 \text{ lbf}$$

(4) Groove weld in tension

$$(\pi/2) * \text{Nozzle O.D.} * tw * S_g = 1.57 * 13.99 * 0.25 * 10878 = 59731.91 \text{ lbf}$$

Loading on welds per UG-41(b)(1)

$$\begin{aligned} W &= (A - (d - 2 * t_n) * (E1 * t - F * tr)) * S_v \\ &= (0.0976 - (13.75 - 2 * 0.12) * (1 * 0.25 - 1 * 0.0071)) * 14700 \\ &= -46804.49 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W1-1 &= (A2 + A5 + A41 + A42) * S_v \\ &= (0.131 + 1.5025 + 0.016 + 0.063) * 14700 \\ &= 25173.75 \text{ lbf} \end{aligned}$$

$$W2-2 = (A2 + A3 + A41 + A43 + 2 * t_n * t * fr1) * S_v$$

REV C

Doc No V049-1.015

Page 43 of 57

Nozzle E

$$= (0.131 + 0 + 0.016 + 0 + 2*0.12*0.25*1)*14700$$

$$= 3042.9 \text{ lbf}$$

$$W3-3 = (A2 + A3 + A5 + A41 + A42 + A43 + 2*tn*tf*fr1)*Sv$$

$$= (0.131 + 0 + 1.5025 + 0.016 + 0.063 + 0 + 2*0.12*0.25*1)*14700$$

$$= 26055.75 \text{ lbf}$$

Load for path 1-1 lesser of W or W1-1 = -46804.49 lbf
 Path 1-1 Thru (2) & (3) = 56543.55 + 26888.88 = 83432.43 lbf
 Path 1-1 is stronger than W so it is acceptable per UG-41(b)(2).

Load for path 2-2 lesser of W or W2-2 = -46804.49 lbf
 Path 2-2 Thru (1), (4) = 19776.11 + 59731.91 = 79508.02 lbf
 Path 2-2 is stronger than W so it is acceptable per UG-41(b)(2).

Load for path 3-3 lesser of W or W3-3 = -46804.49 lbf
 Path 3-3 Thru (2), (4) = 56543.55 + 59731.91 = 116275.5 lbf
 Path 3-3 is stronger than W so it is acceptable per UG-41(b)(2).

Pad strength = $A5*Sp = 22086.75 \text{ lbf}$
 Outer fillet weld strength is adequate.

Reinforcement Calculations for External PressureLimits of reinforcement UG-40

Parallel to the vessel wall $d = 13.75 \text{ in}$
 Normal to the vessel wall outside $2.5*(tn-Cn) + tc = .55 \text{ in}$
 Normal to the vessel wall inside $2.5*(tn-Cn-C) = .3 \text{ in}$

Nozzle required thickness

$$L/Do = 3.125/13.99 = .2234 \quad Do/t = 13.99/0.02972 = 470.7268$$

From table G: $A = 0.000642$
 From table HA-3: $B = 5198.5$

$$Pa = 4*B/(3*Do/t)$$

$$= 4*5198.5/(3*13.99/0.02972)$$

$$= 14.7247 \text{ psi}$$

Nozzle required thickness $tn = .02972 \text{ in}$

Required thickness tr from UG-37(d)(1) = .2409 in

Area required

Allowable stresses: $S_n = 14700$, $S_v = 14700$, $S_p = 14700 \text{ psi}$

$fr1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr1 = 1$
 $fr2 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr2 = 1$
 $fr3 = \text{lesser of } fr2 \text{ or } S_p/S_v \text{ so } fr3 = 1$
 $fr4 = \text{lesser of } 1 \text{ or } S_p/S_v \text{ so } fr4 = 1$

REV 0
 Doc. No. 1049-1-015
 Page 44 of 57

Nozzle E

$$\begin{aligned}
 A &= 0.5*(d*tr*F + 2*tn*tr*F*(1 - fr1)) \\
 &= 0.5*(13.75*0.2409*1 + 2*0.12*0.2409*1*(1 - 1)) \\
 &= 1.6562 \text{ in}^2
 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} = .125 \text{ in}^2$$

$$\begin{aligned}
 &= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\
 &= 13.75*(1*0.25-1*0.2409) - 2*0.12*(1*0.25-1*0.2409)*(1-1) \\
 &= .125 \text{ in}^2
 \end{aligned}$$

$$\begin{aligned}
 &= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\
 &= 2*(0.25+0.12)*(1*0.25-1*0.2409) - 2*0.12*(1*0.25-1*0.2409)*(1-1) \\
 &= .007 \text{ in}^2
 \end{aligned}$$

$$A2 = \text{smaller of the following} = 0.099 \text{ in}^2$$

$$\begin{aligned}
 &= 5*(tn - trn)*fr2*t \\
 &= 5*(0.12 - 0.02972)*1*0.25 \\
 &= .113 \text{ in}^2
 \end{aligned}$$

$$\begin{aligned}
 &= 2*(tn - trn)*(2.5*tn + tc)*fr2 \\
 &= 2*(0.12 - 0.02972)*(2.5*0.12 + 0.25)*1 \\
 &= .099 \text{ in}^2
 \end{aligned}$$

$$\begin{aligned}
 A41 &= Leg^2*fr3 \\
 &= 0.125^2*1 = .016 \text{ in}^2
 \end{aligned}$$

$$\begin{aligned}
 A42 &= Leg^2*fr4 \\
 &= 0.25^2*1 = .063 \text{ in}^2
 \end{aligned}$$

$$\begin{aligned}
 A5 &= (Dp - d - 2*tn)*te*fr4 \\
 &= (20 - 13.75 - 2*0.12)*0.25*1 \\
 &= 1.5025 \text{ in}^2
 \end{aligned}$$

$$\begin{aligned}
 \text{Area} &= A1 + A2 + A41 + A42 + A5 \\
 &= 0.125 + 0.099 + 0.016 + 0.063 + 1.5025 \\
 &= 1.8055 \text{ in}^2
 \end{aligned}$$

As Area > A the reinforcement is adequate for $P_e = 14.7$ at 400 Deg F

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	$tr1 = 0.02972 \text{ in (E = 1)}$
Wall thickness per UG-45(b)(2):	$tr2 = 0.0525 \text{ in}$
Wall thickness per UG-16(b):	$tr3 = 0.0625 \text{ in}$
Std pipe wall per UG-45(b)(4):	$tr4 = 0.328125 \text{ in}$
The greater of $tr2$ or $tr3$:	$tr5 = 0.0625 \text{ in}$
The lesser of $tr4$ or $tr5$:	$tr6 = 0.0625 \text{ in}$

Req'd per UG-45 is the larger of $tr1$ or $tr6 = 0.0625 \text{ in}$

REV 0

Doc. No. VC49-1-015

Page 45 of 57

Nozzle E

Available nozzle wall thickness new, $t_n = 0.12$ in

The nozzle neck thickness is adequate for P_e .

REV. 0

Doc. No. V049-1-015

Page 46 of 57

Nozzle EApplied Loads

Radial load	Pr = 2183 lbf
Circumferential moment	Mc = 0 lbf-ft
Circumferential shear	Vc = 0 lbf
Longitudinal moment	ML = 0 lbf-ft
Longitudinal shear	VL = 0 lbf
Torsion moment	Mt = 0 lbf-ft
Internal pressure	P = 2 psi

Stresses at the nozzle OD per WRC bulletin 107 (psi)

Mean radius Rm = 52.625 in
Rm/t = 105.25

Stress concentration factor Kn (tension) = 1
Stress concentration factor Kb (bending) = 1

Pressure stress intensity factor, Farr equation 11.5

$$\begin{aligned}
 I &= .25*(4 + 3*(r/x)^2 + 3*(r/x)^4) \\
 &= .25*(4 + 3*(6.875/7.12)^2 + 3*(6.875/7.12)^4) \\
 &= 2.351
 \end{aligned}$$

Local circ. pressure stress = I*P*Rm/t = 495 psi

Local long. pressure stress = P*Rm/2t = 105 psi

Maximum combined stress = -4703 psi
Allowable combined stress = +-3*S = +- 44100 psi

The maximum combined stress is within allowable limits.

Maximum primary membrane stress = -1154 psi
Allowable primary membrane stress = +-1.5*S = +- 22050 psi

The maximum primary membrane stress is within allowable limits.

Rev 0

Doc. No 1049-1-015

Page 47 of 57

Nozzle E

From Fig.	Value read	beta	Au	A1	Bu	B1	Cu	C1	Du	D1
3C*	10.776	0.116					-894	-894	-894	-894
4C*	15.180	0.116	-1259	-1259	-1259	-1259				
1C	0.0768	0.116					-4024	4024	-4024	4024
2C-1	0.0443	0.116	-2321	2321	-2321	2321				
3A*	4.1565	0.116								
1A	0.0776	0.116								
3B*	11.121	0.116								
1B-1	0.0282	0.116								
pressure stress*			495	495	495	495	495	495	495	495
Total circ stress			-3085	1557	-3085	1557	-4423	3625	-4423	3625
Primary membrane circ stress*			-764	-764	-764	-764	-399	-399	-399	-399
3C*	10.776	0.116	-894	-894	-894	-894				
4C*	15.180	0.116					-1259	-1259	-1259	-1259
1C-1	0.0747	0.116	-3914	3914	-3914	3914				
2C	0.0469	0.116					-2457	2457	-2457	2457
4A*	7.6047	0.116								
2A	0.0390	0.116								
4B*	4.1127	0.116								
2B-1	0.0387	0.116								
pressure stress*			105	105	105	105	105	105	105	105
Total long stress			-4703	3125	-4703	3125	-3611	1303	-3611	1303
Primary membrane long stress*			-789	-789	-789	-789	-1154	-1154	-1154	-1154
torsion moment Mt										
Circ shear from Vc										
Long shear from VL										
Total Shear stress										
Combined stress			-4703	3125	-4703	3125	-4423	3625	-4423	3625

Rev 0
 Doc. No. V049-1-015
 Page 48 of 57

Nozzle EStresses at the pad edge per WRC bulletin 107 (psi)

Mean radius $R_m = 52.625$ in
 $R_m/t = 210.5$

Stress concentration factor K_n (tension) = 1
 Stress concentration factor K_b (bending) = 1

Pressure stress intensity factor, Farr equation 11.5

$$\begin{aligned} I &= .25*(4 + 3*(r/x)^2 + 3*(r/x)^4) \\ &= .25*(4 + 3*(6.875/10.25)^2 + 3*(6.875/10.25)^4) \\ &= 1.489 \end{aligned}$$

Local circ. pressure stress = $I*P*R_m/t = 627$ psi

Local long. pressure stress = $P*R_m/2t = 210$ psi

Maximum combined stress = -13225 psi
 Allowable combined stress = $\pm 3*S = \pm 44100$ psi

The maximum combined stress is within allowable limits.

Maximum primary membrane stress = -3307 psi
 Allowable primary membrane stress = $\pm 1.5*S = \pm 22050$ psi

The maximum primary membrane stress is within allowable limits.

REV D

Doc No. VP49-1-015

Page 49 of 57

Nozzle E

From Fig.	Value read	beta	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
3C*	8.3321	0.166					-1383	-1383	-1383	-1383
4C*	21.196	0.166	-3517	-3517	-3517	-3517				
1C	0.0595	0.166					-12469	12469	-12469	12469
2C-1	0.0149	0.166	-3123	3123	-3123	3123				
3A*	6.5607	0.166								
1A	0.0553	0.166								
3B*	13.588	0.166								
1B-1	0.0104	0.166								
pressure stress*			627	627	627	627	627	627	627	627
Total circ stress			-6013	233	-6013	233	-13225	11713	-13225	11713
Primary membrane circ stress*			-2890	-2890	-2890	-2890	-756	-756	-756	-756
3C*	8.3321	0.166	-1383	-1383	-1383	-1383				
4C*	21.196	0.166					-3517	-3517	-3517	-3517
1C-1	0.0392	0.166	-8215	8215	-8215	8215				
2C	0.0353	0.166					-7398	7398	-7398	7398
4A*	17.922	0.166								
2A	0.0238	0.166								
4B*	5.8428	0.166								
2B-1	0.0144	0.166								
pressure stress*			210	210	210	210	210	210	210	210
Total long stress			-9388	7042	-9388	7042	-10705	4091	-10705	4091
Primary membrane long stress*			-1173	-1173	-1173	-1173	-3307	-3307	-3307	-3307
torsion moment Mt										
Circ shear from Vc										
Long shear from VL										
Total Shear stress										
Combined stress			-9388	7042	-9388	7042	-13225	11713	-13225	11713

REV 0


Nozzle G

Opening N-G Reinforcement Calculations Per UG-37

Located on: Main Section Cylinder
 Local vessel thickness: .5 in
 Liquid static head included: 0 psi
 Flange description: 8 inch 75# WN A240304L
 ANSI B16.47 flange rating MAP: 115 psi
 ANSI B16.47 flange rating MAWP: 80 psi

Nozzle material specification: SA 240 304L HIGH

Nozzle orientation: 90 degrees
 End of nozzle to shell center: 55.625 in
 Nozzle offset from center Lo: 0 in
 Projection outside vessel Lpr: 2.625 in



corrosion allow = 0 in
 noz thick new tn = .12 in
 nozzle id. new d = 7.75 in
 fillet weld tw1 = .125 in
 groove weld tw2 = .1875 in

To datum L = 40 in

Reinforcement Calculations For Nozzle MAWP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.75$ in
 Normal to the vessel wall outside $2.5*(tn-Cn) + tc = .3$ in
 Normal to the vessel wall inside $2.5*(tn-Cn-C) = .3$ in

Nozzle required thickness

$$trn = \frac{P \cdot Rn}{(Sn \cdot E - 0.6 \cdot P)}$$

$$= \frac{2 \cdot 3.875}{(14700 \cdot 1 - 0.6 \cdot 2)}$$

$$= 0.0005 \text{ in}$$

Required thickness tr from UG-37(a)

$$tr = \frac{P \cdot R}{(S \cdot E - 0.6 \cdot P)}$$

$$= \frac{2 \cdot 52.5}{(14700 \cdot 1 - 0.6 \cdot 2)}$$

$$= 0.0071 \text{ in}$$

Area required

Allowable stresses: $S_n = 14700$, $S_v = 14700$, psi
 $fr1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr1 = 1$

REV 0
 Doc. No. V0119-1-015
 Page 51 of 57

Nozzle G

$$fr2 = \text{lesser of } 1 \text{ or } Sn/Sv \text{ so } fr2 = 1$$

$$\begin{aligned} A &= d*tr*F + 2*tn*tr*F*(1 - fr1) \\ &= 7.75*0.0071*1 + 2*0.12*0.0071*1*(1 - 1) \\ &= .055 \text{ in}^2 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} = 3.82 \text{ in}^2$$

$$\begin{aligned} &= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 7.75*(1*0.5-1*0.0071) - 2*0.12*(1*0.5-1*0.0071)*(1-1) \\ &= 3.82 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 2*(0.5+0.12)*(1*0.5-1*0.0071) - 2*0.12*(1*0.5-1*0.0071)*(1-1) \\ &= .611 \text{ in}^2 \end{aligned}$$

$$A2 = \text{smaller of the following} = 0.072 \text{ in}^2$$

$$\begin{aligned} &= 5*(tn - trn)*fr2*t \\ &= 5*(0.12 - 0.0005)*1*0.5 \\ &= .299 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5*(tn - trn)*fr2*tn \\ &= 5*(0.12 - 0.0005)*1*0.12 \\ &= .072 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A41 &= Leg^2*fr2 \\ &= 0.125^2*1 = .016 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 3.82 + 0.072 + 0.016 \\ &= 3.908 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAWP = 2 at 400 Deg F

Check the welds - From UW-16(d):

$$\begin{aligned} t_{min} &= \text{lesser of } 0.75 \text{ or } t_n \text{ or } t, t_{min} = 0.12 \text{ in} \\ t1 \text{ or } t2(\text{min}) &= \text{lesser of } 0.25 \text{ or } 0.7*t_{min}, t1(\text{min}) = 0.084 \text{ in} \\ t1(\text{actual}) &= 0.7*Leg = 0.7*0.125 = 0.0875 \text{ in} \\ t2(\text{actual}) &= 0.1875 \text{ in} \\ t1 + t2 &= 0.275 > = 1.25*t_{min} \end{aligned}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.0005 in (E = 1)
Wall thickness per UG-45(b)(1):	tr2 = 0.0071 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in

REV 0
Doc. No. VC49-1-015
Page 52 OF 57

Nozzle G

The greater of tr2 or tr3: tr5 = 0.0625 in
 The lesser of tr4 or tr5: tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Available nozzle wall thickness new, tn = 0.12 in

The nozzle neck thickness is adequate for MAWP.

Allowable stresses in joints UG-45(c) and UW-15(c)

Groove weld in tension = $0.74 \times 14700 = 10878$ psi

Nozzle wall in shear = $0.7 \times 14700 = 10290$ psi

Inner fillet weld in shear = $0.49 \times 14700 = 7203$ psi

Strength of welded joints:

(1) Inner fillet weld in shear

$$(\pi/2) \times \text{Nozzle O.D.} \times \text{Leg} \times S_i = 1.57 \times 7.99 \times 0.125 \times 7203 = 11294.57 \text{ lbf}$$

(3) Nozzle wall in shear

$$(\pi/2) \times \text{Mean nozzle dia.} \times t_n \times S_n = 1.57 \times 7.87 \times 0.12 \times 10290 = 15257.07 \text{ lbf}$$

(4) Groove weld in tension

$$(\pi/2) \times \text{Nozzle O.D.} \times t_w \times S_g = 1.57 \times 7.99 \times 0.1875 \times 10878 = 25585.67 \text{ lbf}$$

Loading on welds per UG-41(b)(1)

$$\begin{aligned} W &= (A - (d - 2 \times t_n) \times (E1 \times t - F \times tr)) \times S_v \\ &= (0.055 - (7.75 - 2 \times 0.12) \times (1 \times 0.5 - 1 \times 0.0071)) \times 14700 \\ &= -53606.18 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W1-1 &= (A2 + A5 + A41 + A42) \times S_v \\ &= (0.072 + 0 + 0.016 + 0) \times 14700 \\ &= 1293.6 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W2-2 &= (A2 + A3 + A41 + A43 + 2 \times t_n \times t \times fr1) \times S_v \\ &= (0.072 + 0 + 0.016 + 0 + 2 \times 0.12 \times 0.5 \times 1) \times 14700 \\ &= 3057.6 \text{ lbf} \end{aligned}$$

Load for path 1-1 lesser of W or W1-1 = -53606.18 lbf

Path 1-1 Thru (1) & (3) = $11294.57 + 15257.07 = 26551.64$ lbf

Path 1-1 is stronger than W so it is acceptable per UG-41(b)(2).

Load for path 2-2 lesser of W or W2-2 = -53606.18 lbf

Path 2-2 Thru (1), (4) = $11294.57 + 25585.67 = 36880.24$ lbf

Path 2-2 is stronger than W so it is acceptable per UG-41(b)(2).

Reinforcement Calculations for External PressureLimits of reinforcement UG-40

Parallel to the vessel wall d = 7.75 in

REV 0

Doc. No. UG-1-015

Page 53 of 57

Nozzle GNormal to the vessel wall outside $2.5*(t_n - C_n) + t_c = .3$ inNormal to the vessel wall inside $2.5*(t_n - C_n - C) = .3$ inNozzle required thickness

$$L/Do = 2.625/7.99 = .3285 \quad Do/t = 7.99/0.01796 = 444.8775$$

From table G:

$$A = 0.000462$$

From table HA-3:

$$B = 4906.1$$

$$Pa = 4*B/(3*Do/t)$$

$$= 4*4906.1/(3*7.99/0.01796)$$

$$= 14.704 \text{ psi}$$

Nozzle required thickness $t_{rn} = .01796$ inRequired thickness t_r from UG-37(d)(1) = .3084 inArea requiredAllowable stresses: $S_n = 14700$, $S_v = 14700$, psi $fr_1 =$ lesser of 1 or S_n/S_v so $fr_1 = 1$ $fr_2 =$ lesser of 1 or S_n/S_v so $fr_2 = 1$

$$A = 0.5*(d*tr*F + 2*t_n*tr*F*(1 - fr_1))$$

$$= 0.5*(7.75*0.3084*1 + 2*0.12*0.3084*1*(1 - 1))$$

$$= 1.1951 \text{ in}^2$$

Area available $A_1 =$ larger of the following $= 1.485 \text{ in}^2$

$$= d*(E_1*t - F*tr) - 2*t_n*(E_1*t - F*tr)*(1 - fr_1)$$

$$= 7.75*(1*0.5 - 1*0.3084) - 2*0.12*(1*0.5 - 1*0.3084)*(1 - 1)$$

$$= 1.485 \text{ in}^2$$

$$= 2*(t + t_n)*(E_1*t - F*tr) - 2*t_n*(E_1*t - F*tr)*(1 - fr_1)$$

$$= 2*(0.5 + 0.12)*(1*0.5 - 1*0.3084) - 2*0.12*(1*0.5 - 1*0.3084)*(1 - 1)$$

$$= .238 \text{ in}^2$$

 $A_2 =$ smaller of the following $= 0.061 \text{ in}^2$

$$= 5*(t_n - t_{rn})*fr_2*t$$

$$= 5*(0.12 - 0.01796)*1*0.5$$

$$= .255 \text{ in}^2$$

$$= 5*(t_n - t_{rn})*fr_2*t_n$$

$$= 5*(0.12 - 0.01796)*1*0.12$$

$$= .061 \text{ in}^2$$

$$A_{41} = Leg^2*fr_2$$

$$= 0.125^2*1 = .016 \text{ in}^2$$

Ret. 0

Doc No VCV9-1-015

Page 54 of 57

Nozzle G

$$\begin{aligned}
 \text{Area} &= A1 + A2 + A41 \\
 &= 1.485 + 0.061 + 0.016 \\
 &= 1.562 \text{ in}^2
 \end{aligned}$$

As Area > A the reinforcement is adequate for $P_c = 14.7$ at 400 Deg F

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.01796 in (E = 1)
Wall thickness per UG-45(b)(2):	tr2 = 0.0525 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.0625 in
The lesser of tr4 or tr5:	tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Available nozzle wall thickness new, $t_n = 0.12$ in

The nozzle neck thickness is adequate for P_c .

REV 0

Doc No V249-1-015

Page 55 of 57

Nozzle GApplied Loads

Radial load	$P_r = 693.4$ lbf
Circumferential moment	$M_c = 0$ lbf-ft
Circumferential shear	$V_c = 0$ lbf
Longitudinal moment	$M_L = 0$ lbf-ft
Longitudinal shear	$V_L = 0$ lbf
Torsion moment	$M_t = 0$ lbf-ft
Internal pressure	$P = 2$ psi

Stresses at the nozzle OD per WRC bulletin 107 (psi)

Mean radius $R_m = 52.75$ in
 $R_m/t = 105.5$

Stress concentration factor K_n (tension) = 1
 Stress concentration factor K_b (bending) = 1

Pressure stress intensity factor, Farr equation 11.5

$$\begin{aligned}
 I &= .25*(4 + 3*(r/x)^2 + 3*(r/x)^4) \\
 &= .25*(4 + 3*(3.875/4.12)^2 + 3*(3.875/4.12)^4) \\
 &= 2.25
 \end{aligned}$$

Local circ. pressure stress = $I*P*R_m/t = 475$ psi

Local long. pressure stress = $P*R_m/2t = 106$ psi

Maximum combined stress = -2389 psi
 Allowable combined stress = $\pm 3*S = \pm 44100$ psi

The maximum combined stress is within allowable limits.

Maximum primary membrane stress = -363 psi
 Allowable primary membrane stress = $\pm 1.5*S = \pm 22050$ psi

The maximum primary membrane stress is within allowable limits.

Reid

Doc No V049-1-015

Page 56 of 57

Nozzle G

From Fig.	Value read	beta	Au	A1	Bu	B1	Cu	C1	Du	D1
3C*	16.149	0.066					-425	-425	-425	-425
4C*	17.850	0.066	-469	-469	-469	-469				
1C	0.1215	0.066					-2022	2022	-2022	2022
2C-1	0.0842	0.066	-1401	1401	-1401	1401				
3A*	3.3073	0.066								
1A	0.0927	0.066								
3B*	10.765	0.066								
1B-1	0.0441	0.066								
pressure stress*			475	475	475	475	475	475	475	475
Total circ stress			-1395	1407	-1395	1407	-1972	2072	-1972	2072
Primary membrane circ stress*			6	6	6	6	50	50	50	50
3C*	16.149	0.066	-425	-425	-425	-425				
4C*	17.850	0.066					-469	-469	-469	-469
1C-1	0.1244	0.066	-2070	2070	-2070	2070				
2C	0.0842	0.066					-1401	1401	-1401	1401
4A*	4.8372	0.066								
2A	0.0535	0.066								
4B*	3.2886	0.066								
2B-1	0.0699	0.066								
pressure stress*			106	106	106	106	106	106	106	106
Total long stress			-2389	1751	-2389	1751	-1764	1038	-1764	1038
Primary membrane long stress*			-319	-319	-319	-319	-363	-363	-363	-363
torsion moment Mt										
Circ shear from Vc										
Long shear from VL										
Total Shear stress										
Combined stress			-2389	1751	-2389	1751	-1972	2072	-1972	2072

REV D

Doc. No. V049-1-015

Page 57 of 57

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-016 PAGE 1 OF 33
REV.	DEO #	DATE	BY:	CHECK	TITLE: Beam Splitter Chamber - Finite Element Analysis of 1 in. Thick Flanges for Bolt Preload.	
0	5139	12/6/95	RDC	AGR		
					BY: <i>R.D. Curro</i>	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
PURPOSE: To determine if bolt clamping force results in flange deformation that could allow leakage at Viton o-rings.						
METHOD: A 3D finite element analysis of a section of the plane flange is performed. Brick elements (3D solids) are used in the IMAGES program. Both a coarse model and an enhanced finer model are analyzed. The enhanced model includes compression only springs at the flange interface to simulate gap opening (nonlinear).						
ASSUMPTIONS: Symmetry is used to minimize the model by using appropriate boundary conditions. Curvature of the flange is ignored. O-ring glands and pumping channel are not included.						
INPUTS: LIGO project design sketches and drawings. Durometer is 90 for Viton o-rings.						
REFERENCES: 1. Parker O-Ring Handbook. 2. IMAGES 3D, Version 3.0, R.L. Cloud & Associates						
CALCULATIONS: (See Attachment)						
CONCLUSIONS: At a location that is midway between bolts, the gap between flanges opens a negligible amount that does not affect the seal.						
NOTES: This analysis was performed for the 104 in diameter flange, but it applies to other diameter as well because of similar dimensions and bolt spacing. Computer file is FLANGE.						

104 1 1/4" I D FLANGES - ANALYSIS FOR
VACUUM LOAD

HOLE SPACING

$$N_o. \text{ OF BOLTS} = 44$$

BOIT HOLE DIAM

$$C = 110"$$

CIRCUMF.

$$C' = \pi C = 345.6 \text{ IN}$$

SPACING

$$S = \frac{C'}{N} = \frac{345.6}{44}$$

$$= 7.70 \text{ IN}$$


TR. 7/8" O BOLTS w/ 1" T HOLES

USE FE MODEL TO DETERMINE
IF BOIT SPACING & FLANGE THICKNESS
WILL BE SUFFICIENT TO PROVIDE
CLAMPING FORCE BETWEEN THE BOLTS
AT THE C-RING. 3-D BULK
ELEMENTS WILL BE USED, MODEL
TOP FLANGE WHICH IS THINNER THAN
BOTTOM FLANGE.

THE FE MODEL WILL REPORT
STRESS WHICH MAY BE SIGNIFICANT
AFFECT ON RESULTS.




22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS




$$5' = \frac{1}{2} = 3,600 \text{ IN}$$

M.I.D. POINT TO CENTER





22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS




Revision 0
Doc No. V049-1-016
Page 4 of 33



BOUNDARY CONDITIONS


@ $y = 0, \Delta_z = 0$




Revision 0
 Doc. No. V049-1-016
 Page 5 of 33

G = EQUIV. NET
 1875
 1875

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



TYPICAL ELEMENT NODE NUMBERING



1ST EL i j k l m n o p
 1, 2, 12, 11, 101, 102, 112, 111

DELETE ELEMENTS AT BOLT HOLE
6, 7, 17, 18, 16+, 129, 249, 250

REACTIONS AT BOLT

NODE	F _v
6	14.3
8	-25.6
14	16.7
17	-29.7
18	-8.9

REACTIONS AT LOWER O-RING

NODE	F _v
5	49.3
15	65.2
25	50.6
35	43.4
45	41.0
55	27.6
65	16.7
75	52.5
85	-47.0
95	11.0



22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



IMAGES-3D
Ver. 3.0
Geometry Plot

*DELETE
ELEMENTS*

*2
2*



Revision 0
Doc No. V049-1-016
Page 8 of 33


Flange - ID = 104, No. Bolts = 48
Wireframe Plot

9/29/95
15:4:28

IMAGES-3D
 Ver. 3.0
 Geometry Plot

TOP

OUTER O-RING →





Flange - ID = 104, No. Bolts = 48
 Wireframe Plot

9/29/95
 14:55:49

IMAGES-3D
Ver. 3.0
L Case 1

BOUNDARY CONDITIONS

Reading.....
Reading.....
?t
?r,15,15
?



Revision 0
Doc. No. V049-1-016
Page 10 of 33


Auto	Blowup	Disp	Elem#	Exit	Full	Help	Load
Move	Node	Node#	Range	Rest	Rotate	Shrink	Slice

IMAGES-3D
 Ver. 3.0
 Geometry Plot

8-No element numbers
 9-All elemt. numbers
 10-Exit or 10,Size

?9
 ?i
 X range
 ?-1,.6
 Y range
 ?-1,2
 Z range
 ?-1,6
 ?#
 ?

401	402	403	404	405	406	407	408	409	410
244	245	246	247	248	249	250	251	252	
301	302	303	304	305	306	307	308	309	310
163	164	165	166	167	168	169	170	171	
201	202	203	204	205	206	207	208	209	210
82	83	84	85	86	87	88	89	90	
101	102	103	104	105	106	107	108	109	110
1	2	3	4	5	6	7	8	9	
111	112	113	114	115	116	117	118	119	120



Revision 0
 Doc. No. V049-1-016
 Page 11 of 33

Auto Node	Blowup Node#	Elem# Plot	Exit Range	Full Rest	Help Rotate	Local Shrink	Move Slice
-----------	--------------	------------	------------	-----------	-------------	--------------	------------


ENHANCED FE MODEL

THIS MODEL WILL BE ENHANCED BY
INCREASING THE NO. OF FLUSHES
THROUGH THE FLANGE THICKNESS FROM
4 TO 6 AND BY INCREASING THE
NO OF ELEMENTS ALONG EACH SIDE
FROM 9 TO 14.

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



ENHANCED MODEL { 1575 NODES
1176 ELEMENTS




LAST EL = 1176

* ENHANCED MODEL NODE

BOUND COND SAME AS COARSE MODEL EXCEPT THAT $\Delta z = 0$ ALONG X AXIS ONLY

TYPICAL ELEMENT NODE NUMBERING



1ST EL i j k l m n o p

INITIAL MODEL → 1, 2, 12, 11, 101, 102, 112, 111

1, 2, 17, 16, 226, 227, 242, 241

ENHANCED MODEL

MAT = 1 (STAINLESS)

BEZEL = 2 / 3RD ORDER INTEGRATION

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS




BOTTOM LAYER ELEMENTS

IMAGES-3D
Ver. 3.0
Geometry Plot

Z range
?
Z=Default
?i
X range
?
X=Default
Y range
?-.1,.2
Z range
?
Z=Default
?

1	15	29	43	57	71	85	99	113	127	141	155	169	183
2	16	30	44	58	72	86	100	114	128	142	156	170	184
3	17	31	45	59	73	87	101	115	129	143	157	171	185
4	18	32	46	60	74	88	102	116	130	144	158	172	186
5	19	33	47	61	75	89	103	117	131	145	159	173	187
6	20	34	48	62	76	90	104	118	132	146	160	174	188
7	21	35	49	63	77	91	105	119	133	147	161	175	189
8	22	36	50	64	78	92	106	120	134	148	162	176	190
9	23	37	51	65	79	93	107	121	135	149	163	177	191
10	24	38	52	66	80	94	108	122	136	150	164	178	192
11	25	39	53	67	81	95	109	123	137	151	165	179	193
12	26	40	54	68	82	96	110	124	138	152	166	180	194
13	27	41	55	69	83	97	111	125	139	153	167	181	195
14	28	42	56	70	84	98	112	126	140	154	168	182	196

*DELETED
ELEMENTS FOR
BORE HOLE* →




Auto Blowup Elem# Exit Full Help Local Move
Node Node# Plot Range Rest Rotate Shrink Slice

**IMAGES-3D
Ver. 3.0
Geometry Plot**

TOP LAYER ELEMENTS

9-All elemt. numbers
10-Exit or 10,Size
?9
?i
X range
?
X=Default
Y range
?.8,1.1
Z range
?
Z=Default
?

981	995	1009	1023	1037	1051	1065	1079	1093	1107	1121	1135	1149	1163
982	996	1010	1024	1038	1052	1066	1080	1094	1108	1122	1136	1150	1164
983	997	1011	1025	1039	1053	1067	1081	1095	1109	1123	1137	1151	1165
984	998	1012	1026	1040	1054	1068	1082	1096	1110	1124	1138	1152	1166
985	999	1013	1027	1041	1055	1069	1083	1097	1111	1125	1139	1153	1167
986	1000	1014	1028	1042	1056	1070	1084	1098	1112	1126	1140	1154	1168
987	1001	1015	1029	1043	1057	1071	1085	1099	1113	1127	1141	1155	1169
988	1002	1016	1030	1044	1058	1072	1086	1100	1114	1128	1142	1156	1170
989	1003	1017	1031	1045	1059	1073	1087	1101	1115	1129	1143	1157	1171
990	1004	1018	1032	1046	1060	1074	1088	1102	1116	1130	1144	1158	1172
991	1005	1019	1033	1047	1061	1075	1089	1103	1117	1131	1145	1159	1173
992	1006	1020	1034	1048	1062	1076	1090	1104	1118	1132	1146	1160	1174
993	1007	1021	1035	1049	1063	1077	1091	1105	1119	1133	1147	1161	1175
994	1008	1022	1036	1050	1064	1078	1092	1106	1120	1134	1148	1162	1176



Revision 0
Doc. No. V049-1-016
Page 15 of 33

Auto Node Blowup Node# Elem# Plot Exit Range Full Rest Help Rotate Local Shrink Move Slice


IMAGES-3D
 Ver. 3.0
 Geometry Plot

TOP LAYER Nodes

?
 Z=Default
 ?#
 ?i
 X range
 ?
 X=Default
 Y range
 ?.9,1.1
 Z range
 ?
 Z=Default
 ?

1351-1366-1381-1396-1411-1426-1441-1456-1471-1486-1501-1516-1531-1546-1561
 1352-1367-1382-1397-1412-1427-1442-1457-1472-1487-1502-1517-1532-1547-1562
 1353-1368-1383-1398-1413-1428-1443-1458-1473-1488-1503-1518-1533-1548-1563
 1354-1369-1384-1399-1414-1429-1444-1459-1474-1489-1504-1519-1534-1549-1564
 1355-1370-1385-1400-1415-1430-1445-1460-1475-1490-1505-1520-1535-1550-1565
 1356-1371-1386-1401-1416-1431-1446-1461-1476-1491-1506-1521-1536-1551-1566
 1357-1372-1387-1402-1417-1432-1447-1462-1477-1492-1507-1522-1537-1552-1567
 1358-1373-1388-1403-1418-1433-1448-1463-1478-1493-1508-1523-1538-1553-1568
 1359-1374-1389-1404-1419-1434-1449-1464-1479-1494-1509-1524-1539-1554-1569
 1360-1375-1390-1405-1420-1435-1450-1465-1480-1495-1510-1525-1540-1555-1570
 1361-1376-1391-1406-1421-1436-1451-1466-1481-1496-1511-1526-1541-1556-1571
 1362-1377-1392-1407-1422-1437-1452-1467-1482-1497-1512-1527-1542-1557-1572
 1363-1378-1393-1408-1423-1438-1453-1468-1483-1498-1513-1528-1543-1558-1573
 1364-1379-1394-1409-1424-1439-1454-1469-1484-1499-1514-1529-1544-1559-1574
 1365-1380-1395-1410-1425-1440-1455-1470-1485-1500-1515-1530-1545-1560-1575

LOADING AREA



Revision 0
 Doc No. V049-1-016
 Page 16 of 33

Auto Blowup Elem# Exit Full Help Local Move
 Node Node# Plot Range Rest Rotate Shrink Slice



DELETE ELEMENTS

10, 11, 24, 25 IN BOTTOM LAYER

INCREMENT = 196

TO

990, 991, 1004, 1005 IN TOP COVER

APPLY LOADS $F_y = -10000^*$ LB AT
TOP COVER NODES 1355, 1360, 1362, 1363
1774, 1775, 1777, 1778
1389, TO 1393
1404 TO 1406

* UNIT LOAD SELECTED
TO DETERMINE REQUIRED
LOAD FROM OUTPUT

IMAGES-3D
Ver. 3.0
Geometry Plot

?
Z=Default
?i
X range
?
X=Default
Y range
?-.1,.1
Z range
?
Z=Default
?#
?

1	16	31	46	61	76	91	106	121	136	151	166	181	196	211
2	17	32	47	62	77	92	107	122	137	152	167	182	197	212
3	18	33	48	63	78	93	108	123	138	153	168	183	198	213
4	19	34	49	64	79	94	109	124	139	154	169	184	199	214
5	20	35	50	65	80	95	110	125	140	155	170	185	200	215
6	21	36	51	66	81	96	111	126	141	156	171	186	201	216
7	22	37	52	67	82	97	112	127	142	157	172	187	202	217
8	23	38	53	68	83	98	113	128	143	158	173	188	203	218
9	24	39	54	69	84	99	114	129	144	159	174	189	204	219
10	25	40	55	70	85	100	115	130	145	160	175	190	205	220
11	26	41	56	71	86	101	116	131	146	161	176	191	206	221
12	27	42	57	72	87	102	117	132	147	162	177	192	207	222
13	28	43	58	73	88	103	118	133	148	163	178	193	208	223
14	29	44	59	74	89	104	119	134	149	164	179	194	209	224
15	30	45	60	75	90	105	120	135	150	165	180	195	210	225


← .2571" TIP

OUTER
← O-RING

LIMITS OF LENS

↓
↑

.25" TIP



Revision 0
Doc. No. V049-1-016
Page 18 of 33

Auto Blowup Elem# Exit Full Help Local Move
Node Node# Plot Range Rest Rotate Shrink Slice



CLAMPING FORCE AT OUTER O-RING
 FINISHED MODEL

FORCE WILL BE NORMALIZED BY NODE
 SPACING AND TOTAL BOLT LOAD

NODE SPACING

$$S = \frac{3.6}{14} = .2571$$

TOTAL BOLT $F_y = 14000 \text{ LB}$, SAY 14^5

$$F_y = \frac{F_{iy}}{.2571(14)} = \frac{F_{iy}}{4.629}$$

WHERE .2571 = NODE SPACING *
 * =

NODE	F_{iy}	F_y	$F_y/125$
7	150.5	32.5	130
22	242.5	61.0	244
37	232.6	50.3	201
52	164.4	35.6	142.4
67	94.3	20.8	83.2
82	42.3	9.14	36.6
97	9.02	1.95	7.4
112	-6.54	-1.42	-5.68
127	-11.1	-2.40	-9.60
142	-10.3	-2.22	-8.88
157	-7.69	-1.66	-6.64
172	-5.14	-1.11	-4.44
187	-3.24	-.76	-2.8
202	-2.12	-.48	-1.84
217	-.88	-.19	-.76

WHERE F_{iy} = OUTSIDE FORCE, F_{iy} = FLANGE

$F_y/125$ MEASURED BY NODE SPACING
 IN BOTH DIRECTIONS

RESIDUAL FORCE AT OUTER O-RING
 COARSE MODEL

$$S = \frac{3.6}{9} = .40$$

TOTAL FORCE = $F_y = 14000 \text{ LB} = 14K$

$$F_y = \frac{F_{iy}}{140(11)} = \frac{F_{ix}}{5.6}$$

WHERE .40 = NODE SPACING

NODE	F_{iy}	F_{ix}	$F_{ix} \cdot 349$
5	577.4	103.1	265.1
15	944.6	175.8	457.1
25	612.8	109.4	241.3
35	262.7	46.6	119.4
45	54.3	9.69	24.9
55	-16.2	-2.89	-7.4
65	-21.8	-3.89	-10.0
75	-12.4	-2.25	-5.79
85	-5.46	-.975	-2.51
95	-1.64	-.293	-.753


F_{iy} = OUTPUT FORCE, F_{ix} = FLANGE

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS





NORMALIZED CLAMPING FORCE AT D-RING



NOTE - HIGHER LOAD RESULTS FROM COARSE MODEL BECAUSE APPLIED BOLT FORCE IN MODEL IS CLOSER TO D-RING HEADS THAN IT IS IN ENHANCED MODEL

FRAGMENTED MODEL OF COMP. ONLY SPRINGS FOR FOUNDATIONAL AND LINEAR SPRINGS FOR VITON SPRING RATE OF VITON O RING

CROSS SECTION .275 IN

COMPRESSION 20%
 = .20 (.275)
 = .055 IN

GROOVE DEPTH = .201 to .211
 ∴ COMP = $.275 - .211$
 = .064
 = $\frac{.064}{.275} = 23\% \text{ MIN}$

= $.275 - .201$
 = .074
 = $.074 / .275 = 27\% \text{ MAX}$

COMPRESSION LOAD

F ≈ 25 TO 100 LB PER IN OF LENGTH / IN QUANTITY TO

SEE P. A4-11 OF PARTIAL O-RING HANDBOOK

SAY F = 60 LB

SPRING RATE

$R = \frac{60}{.064} = 938 \text{ LB/IN MIN PER IN OF CIRCUM}$

$R = \frac{60}{.074} = 810 \text{ LB/IN MIN PER IN OF CIRCUM}$

USE

$R = 800 \text{ LB/IN FOR 1 IN LENGTH}$
 $R = 900 (.2571) = 231 \text{ LB/IN FOR MODEL}$

REV D
 VOL 9 - 016
 P. 22 OF 33

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS
AMPAD

TRY DUCTILITY = 90

SQUEEZE (COMPRESSION) VARIES FROM 21 TO 29% (P. A5-13 OF PARKER SEALS HANDBOOK) FROM P. A4-11 OF THE PARKER HANDBOOK. THE COMPRESSIVE STRENGTH PER INCH OF SEAL ROLLS ARE:

70 TO 160 LB/IN

FOR .080 IN COMPRESSION (CORRESPONDING TO MAX DEFORMATION) THE STRENGTH PER INCH OF SEAL IS

$$R = \frac{160}{.080} = 2000 \text{ LB/IN PER INCH OF ROLL.}$$




FOR DISCRETE SPRINGS SPACED .2571 IN APART IN MODEL

$$R = 2000 (.2571) \text{ WHERE } .2571 = \text{NODE SPACING} = 514 \text{ LB/IN} *$$

ALTHOUGH THIS IS HIGHER THAN $R = 231$ LBS/IN USED IN FE ANALYSIS, IT IS ORDERS OF MAGNITUDE LESS STIFF THAN FOUNDATION SPRINGS USED TO REPRESENT THE STEEL. \therefore THE MODEL RESULTS WOULD NOT CHANGE SIGNIFICANTLY IF THE HIGHER VALUE OF R IS USED.

* SEE CALC 018, P. 5 FOR UPDATED VALUE OF R . RESULTS WILL NOT BE AFFECTED.

IMAGES-3D
Version 3.0




IMAGES-3D
Version 3.0

DISPLACEMENT ALONG OUTER O-RING




4 BOLT

SYM



COMP ← → SMALL UPLIFT



Revision 0
Doc No. V049-1-016
Page 25 of 33



Load Case
1

Displacement Contour Plot
DY

10/12/95
7:40:0

DEFLECTION ALONG OUTER O-RING



?c
Scale factor
?500
?



IMAGES-3D
Version 3.0



*DESCRIPTION Along Radial Line
THROUGH Bolt Hole*

X range
?-.1,.1
Y range
?
Y=Default
Z range
?
Z=Default
?r,,-90
?c
Scale factor
?200
?



↑
OVER O-RING

⊥ BSC





Revision 0
Doc. No. V049-1-016
Page 27 of 33

Animate	Auto	Blowup	Elem#	Exit	Full	Help	Lcase
Move	Node#	Origin	Plot	Range	Rotate	Scale	Slice

IMAGES-3D
Version 3.0

DESCRIPTION: ALIGNED BORELINE LINE
MIDWAY BETWEEN BOLTS

?c
Scale factor
?500
?i
X range
?3.3,3.5
Y range
?
Y=Default
Z range
?
Z=Default
?



Revision 0
Doc. No. V049-1-016
Page 28 of 33

Animate	Auto	Blowup	Elem#	Exit	Full	Help	Lcase
Move	Node#	Origin	Plot	Range	Rotate	Scale	Slice

REINFORCED MODEL

FOUNDATION STIFFNESS = 10×10^6 LB/IN

OUTER O-RING DEFECTIONS

NODE	Δy	EXP (10 EXP)
7	-.104	-3
22	-.917	-4
27	-.768	-4
52	-.470	-4
67	-.125	-4
82	.239	-4
97	.572	-4
112	.876	-4
127	.114	-3
142	.136	-3
157	.154	-3
172	.168	-3
187	.178	-3
202	.184	-3
217	.186	-3

FROM COMPUTER OUTPUT
FILE: FLANGE

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



DEFLECTIONS AT BELT

BOTTOM LAYER NODES			TOP LAYER NODES			Δ_{YT}/Δ_{YB}
NODE	$\Delta_{Y BOT}$		NODE	$\Delta_{Y TOP}$		
9	-1.540	-4	1359	-1.799	-3	14.8
10	-.353	-4	1360	-.153	-2	43
12	-.382	-4	1362	-.158	-2	41
13	-.542	-4	1363	-.822	-3	15
24	-.851	-4	1374	-.572	-3	6.8 *
25	-.592	-4	1375	-.101	-2	17.1
27	-.633	-4	1377	-.105	-2	16.6
28	-.847	-4	1378	-.596	-3	7.0
39	-.702	-4	1389	-.500	-3	7.1
40	-.657	-4	1390	-.668	-3	10.2
41	-.464	-4	1391	-.190	-3	19.2
42	-.664	-4	1392	-.684	-3	10.3
43	-.683	-4	1393	-.514	-3	7.53
54	-.510	-4	1404	-.409	-3	8.0
55	-.622	-4	1405	-.468	-3	7.5
56	-.664	-4	1406	-.484	-3	7.3
57	-.618	-4	1407	-.474	-3	7.7
58	-.488	-4	1408	-.416	-3	8.5

MIN RATIO OF TOP TO BOTTOM DEFLECTION = 6.8
 FOUNDATION STIFFNESS, $R = 10 \times 10^6 \text{ LB/IN}$
 IS REASONABLE



MAXIMUM LIFTOFF AT OUTER O-RING

IF THE DEFLECTION IN THE USE DIRECTION IS ACTUALLY 0 AND THE RELATIVE Δy REMAINS CONSTANT, THE MAXIMUM SEPARATION BETWEEN THE FLANGES IS

$$\Delta y = [0.146 - (-0.104)] \times 10^{-3} \\ = 0.250(10)^{-3}$$

THIS IS DOUBLED FOR 2 FLANGES

$$\Delta y = 2(0.250)(10)^{-3} \\ = 0.50(10)^{-3} \\ = 0.00050 \text{ IN}$$

THIS COMPARES TO THE MINIMUM O-RING COMPRESSION OF 0.064 IN *

THE COMPRESSION IS MORE THAN 100 TIMES THE FLANGE SEPARATION.

$$\frac{0.064}{0.00050} = 110$$

* CALCULATED VALUE, FROM PANEL INFORMATION, MAXIMUM COMPRESSION IS 0.080 IN FOR .25 IN O-RING.



FOR THE ANALYSIS, THE BOLT LOAD IS 18000 LB FOR THE HALF MODEL OR 36000 LB PER BOLT. THE TOTAL VACUUM THRUST ON THE FLANGE IS

$$F_f = \pi r^2 (14.7)$$

$$r = \frac{108}{2} = 54$$

= RADIUS TO OUTER O-RING

$$F_f = \pi (54)^2 (14.7)$$

$$= 134,700 \text{ LB}$$

FOR 48 BOLTS THE FORCE PER BOLT IS

$$F_{\text{BOLT}} = \frac{134,700}{48}$$

$$= 2800 \text{ LB} < 36000$$

∴ BOLT PRELOAD CAN BE REDUCED TO, SAY 6000 LB, AND THE BOLTS WILL HAVE A NET TENSION UNDER THE VACUUM LOAD

$$F_f = 6000 - 2800 = 3200 \text{ LB}$$

FOR A PRELOAD OF 6000 LB THE UNIFORM LOAD ON THE INNER AND OUTER O-RINGS IS

$$W = \frac{48(6000)}{\pi(108) + \pi(105)} \quad (\text{ASSUME RIGID FLG})$$

$$= 430 \text{ LB/IN} >> 160 \text{ LB/IN}$$

MAX LOAD REQUIRED TO COMPRESS 1/4 VITON O-RING FOR DURING 90

∴ VITON WILL BE COMPRESSED INTO GLAND

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



FOR FLANGES OF OTHER DIAMETERS,
MAINTAIN BOLT SPACING AT 7.2 IN

FLANGE ID	BC DIAM D _{BC}	BC CIRCUM π D _{BC} = C _{BC}	NO. OF BOLTS N = C _{BC} /7.2	USE N =
104 1/4	110	345.6"	48	48
84 1/4	90	282.7	39	40
72 1/4	78	245.0	34	36
60 1/4	66	207.3	29	30
48 1/4	54	169.6	24	24
44 1/4	50	157.1	22	24
30 1/4	36	113	16	16

BOLT DIAMETER = 7/8"
WITH 1" HOLES


TOP FLANGE = 1" THICK
BOTTOM " = 1 1/4" THICK

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-017 PAGE 1 OF 10
REV.	DEO #	DATE	BY:	CHECK	TITLE: Beam Splitter Chamber Finite Element Analysis of 1 in Thick Flange for Bolt Preload plus Positive Pressure	
0	0135	12/4/95	RDC	AGR		
					BY: R. D. CLARKE	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
<p>PURPOSE: To determine if bolt clamping force combined with a positive internal pressure of 2 psi results in flange deformation that could allow leakage at o-rings.</p>						
<p>METHOD: The same method used for the preload - only analysis (V049-1-016) is used in this analysis. Pressure load is added to the finite elements model.</p>						
<p>ASSUMPTIONS: Same as preload-only analysis (calc. V049-1-016). The fine model is used with compression-only springs at the surface between flanges.</p>						
<p>INPUTS: LIGO project design sketches and drawings. Durometer of 90 for Viton o-rings.</p>						
<p>REFERENCES: 1. Parker O-Ring Handbook. 2. IMAGES-3D, Version 3.0, R.L. Cloud and Associates</p>						
<p>CALCULATIONS: (SEE ATTACHED)</p>						
<p>CONCLUSIONS: The gap opening between flanges is negligible and does not permit leakage of o-ring seals.</p>						
<p>NOTES: Computer file is FLANGE A.</p>						

FLANGES - 3D FE ANALYSIS FOR BOLT PRELOAD PLUS POS PRESSURE

ANALYSIS FOR POSITIVE PRESSURE USING 3D FE MODEL - 104 ID FLANGE USED

PRESSURE LOAD FROM ATTACHED CYLINDER



$$F_y = \frac{P \cdot r}{2}$$

$$P = 2 \text{ PSI}$$

$$r = \frac{104.25}{2}$$

$$F_y = \frac{2 \left(\frac{104.25}{2} \right)}{2} = 52.1 \text{ LBS}$$

NODE SPACING ALONG Y - AXIS IS (.7571)

$$F_{yi} = 52.1 (.7571) = 13.4 \text{ LB} \quad \text{NODES 1266 TO 1540, 1515}$$

$$= \frac{13.4}{2} = 6.7 \text{ AT } Y = 0, 3.6$$

END NODES 1351 & 1561



PRESSURE FORCE

$$F_{PL} = 6000 \text{ LB FOR } 7/8" \text{ } \phi \text{ BOLTS}$$

16 NODES ARE LOADED, 4 NODES ARE AT PLANE OF SYMMETRY ($\gamma = 0$)

$$F_{PL} = 14 F_{yi} + 4 \frac{F_{yi}}{2}$$
$$= 16 F_{yi} \quad \gamma = 0$$

$$F_{yi} = \frac{6000}{16} = -375 \text{ LB}$$

NODES 1274, 1375, 1377, 1278
1285 TO 1393
1404 TO 1408

$$F_{yi} = \frac{375}{2} = -188 \text{ LB NODES } 1359, 1360, 1362, 1363$$

THE TOTAL PRESSURE FORCE ON THE CYLINDER IS

$$F_y = 52.1 \times 2.60 = 188 \text{ LB}$$

$$\ll F_{PL} = 6000 \text{ LB}$$

∴ IT WILL BE ASSUMED THAT PRESSURE DOES NOT CHANGE THE PRELOAD FORCE



∴ ACTUAL LOAD IS 3000 LB FOR 1/2 BOLT
THIS ANALYSIS IS CONSERVATIVE FOR
EVALUATION OF FLANGE SEPARATION.

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



Turbo... Pressure

IMAGES-3D
Version 3.0



Revision 0
Doc. No. V049-1-017
Page 4 of 10

Load Case
1





Stress Contour Plot
Stress Intensity

10/18/95
7:48:50

IMAGES-3D
Version 3.0

INTERNAL PRESSURE
DEFLECTION ALONG RADIAL LINE
THROUGH BOLT HOLE

?C
Scale factor
?200
?I
X range
?-.1,.1
Y range
?
Y=Default
Z range
?
Z=Default
?



↑
Original D-Line

Revision 0
Doc. No. V049-1-017
Page 5 of 10

Animate	Auto	Blowup	Elen#	Exit	Full	Help	Lcase
Move	Node#	Origin	Plot	Range	Rotate	Scale	Slice


IMAGES-3D
Version 3.0

INTERNAL PRESSURE
DIRECTIONAL MOMENTS OUTSIDE O-RING

?C
Scale factor
?100
?I
X range
?
X=Default
Y range
?
Y=Default
Z range
?1.4,1.6
?

4 BOLT

MID PLANE
BETWEEN
BOLTS



Animate	Auto	Blowup	Elen#	Exit	Full	Help	Lcase
Move	Node#	Origin	Plot	Range	Rotate	Scale	Slice



DEFLECTIONS AT OUTER O-RING

NODE	Δy
7	$.296 \times 10^{-5}$
217	$.134 \times 10^{-3}$

SPRING LOADS ALONG OUTER O-RING

NODE	F ₁ *	EXPANST
7	.152	- 2
22	.271	- 2
37	.615	- 2
52	.120	- 1
67	.1197	- 1
82	.281	- 1
97	.366	- 1
112	.445	- 1
127	.515	- 1
142	.574	- 1
157	.624	- 1
172	.662	- 1
187	.690	- 1
202	.706	- 1
217	.711	- 1

* OUTPUT FROM FILE FLANGE A



MAXIMUM SEPARATION OF FLANGES

AT NODE 217 WHICH IS MIDWAY BETWEEN 2 GAPS ALONG THE OUTER O-RING, THE DEFLCTION IS

$$\Delta_y = .134 (11)^{-3} \text{ IN}$$

WHICH INDICATES A VERY SLIGHT OPENING OR GAP UNDER INTERNAL PRESSURE OF 2 PSI. FOR THE 2 FLANGES, THIS IS DOUBLED

$$\Delta_y = 2 (.134) (10)^{-3} \\ = .276 (10)^{-3} \text{ IN}$$

THIS COMPARES TO THE MINIMUM COMPRESSION OF .058 IN FROM PARSON HANDBOOK (P. A5-12)

$$\frac{58 (10)^{-3}}{.276 (10)^{-3}} = 210$$

∴ OPENING OR GAP << INITIAL COMPRESSION OF O-RING AND O-RING REMAINS IN CONTACT AGAINST INTERNAL PRESS = 2 PSI.

MAX TENSILE LOAD IS $T = \frac{.711 (10)^{-1} \text{ LB}}{.257 \text{ IN}}$

$$T = .280 \text{ LB/IN}$$

THIS COMPARES TO MIN SEALING LOAD OF 70 LB/IN FOR DIMENSION = 92 (PARSON HANDBOOK P A4-11)


$$C - T = 70 - .28 = 69.7 \text{ LB/IN}$$

Hoop Stress in Flange Ring Due to Internal Pressure

3D FE Model Does Not Compute Hoop Stress

Q

$$p = 2 \text{ psi}$$



$$V = .660 p \sqrt{rt}$$

$$r = \frac{ID}{2} + \frac{t}{2}$$

$$ID = 104.75 \text{ (inches)}$$

$$t = .5 \text{ (inches thickness)}$$


$$r = \frac{104.75}{2} + \frac{.5}{2} = 52.4$$

$$V = .660 (2) \sqrt{52.4 (.5)}$$

$$= 6.8 \text{ (lb/in)}$$

Total Radial Load

$$F_r = p(r) + V = 2 + 6.8 = 8.8 \text{ (lb/in)}$$




$$dF_y = F_r ds \sin \theta$$

$$ds = r d\theta$$

$$dF_y = F_r r \sin \theta d\theta$$





$$\begin{aligned}
 \bar{F}_\theta &= - \int_0^{\frac{\pi}{2}} dF_y = \\
 &= - \int_0^{\frac{\pi}{2}} F_r r \sin \theta d\theta \\
 &= - F_r r \int_0^{\frac{\pi}{2}} \sin \theta d\theta \\
 &= + F_r r \cos \theta \Big|_0^{\frac{\pi}{2}} \\
 &= + F_r r (1) \\
 &= + F_r r \\
 &= 8.4(52.4) = 461 \text{ LB}
 \end{aligned}$$

FLANGE CROSS SECTION

$$A = 3.5(1) = 3.5 \text{ IN}^2$$

LOOP STRESS

$$f_\theta = \frac{461}{3.5} = 132 \text{ PSI NEG}$$

THIS STRESS & STRESS INTENSITY PLOT CONFIRMS THAT STRESS IN FLANGE ARE LOW, EXCEPT AT LOCAL AREA UNDER BOLT

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-018 PAGE 1 OF 18
REV.	DEO #	DATE	BY:	CHECK	TITLE: Beam Splitter Chamber - Finite Element Analysis of 3/4 in. Thick Flange	
0	139	12/6/95	RDC	AGR		
					BY: R. D. Ciatto	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
<p>PURPOSE: To determine if thin flange (3/4 in) can withstand clamping force due to bolt preload plus 2 psi internal pressure without leakage at o-ring.</p>						
<p>METHOD: The 3-D finite element model used for the 1 in. thick flange is modified to obtain a 3/4 thick flange model.</p>						
<p>ASSUMPTIONS: Same as 1 in. thick flange analysis.</p>						
<p>INPUTS: LIGO project design sketches and drawings. Durometer of 90 for Viton o-rings.</p>						
<p>REFERENCES: 1. Parker O-Ring Handbook. 2. IMAGES 3D, Version 3.0, R.L. Cloud & Associates.</p>						
<p>CALCULATIONS: (SEE ATTACHED)</p>						
<p>CONCLUSIONS: Although the gap opening between flanges is greater for the 3/4 in. thickness than it is for the 1 in. thickness, it still does not permit leakage. If a 1 in. or 1 1/4 in. flange is damaged by gouging, its thickness may be reduced by as much as 1/4 in by machining.</p>						
<p>NOTES: If a flange requires machining, its location should be evaluated for tensile force. Computer file is FLANGE B.</p>						

FLANGE ANALYSIS USING 3D MODEL
FOR THICKNESS = 3/4 IN

THE FOLLOWING ANALYSIS USES THE
SAME MODEL AS THE ENHANCED
MODEL BUT THERE ARE 5 ELEMENTS
THROUGH THE THICKNESS RATHER
THAN 6 BECAUSE THE FLANGE IS
THINNER, 3/4" VS. 1".

LOADS INCLUDE THE 8500* LB AL -
REACTION AND THE 2 PSI
INTERNAL PRESSURE WHICH IS A
WORST CASE FOR OPENING OF THE
GAP BETWEEN THE FLANGES.


NONLINEAR GAP ELEMENTS ARE USED
AT THE FOUNDATION OF THE MODEL TO
SIMULATE THE OPENING OF THE GAP.

BOTH THE INNER AND OUTER CIRCLES
ARE INCLUDED, THESE ARE MODELED
AS LINEAR SPRINGS USING THE MAX
STIFFNESS POSSIBLE FOR THE 1/4 IN
VITON MATERIAL.


* THE MAXIMUM LOAD WILL BE 10000 LB
(REF. CALC V049-1-042, P. 26). THIS
WILL NOT AFFECT THE RESULTS OF THIS
CALL SIGNIFICANTLY.



22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



TYPICAL ELEMENT WITH DIMENSIONS




1st EL i j k l m n o p

226, 227, 242, 241, 451, 452, 467, 468



BOUNDARY CONDITIONS

@ $y = 0$, $\Delta y = 0$



Revision 0
 Doc. No. V049-1-018
 Page 4 of 18

SPRING RATE FOR SPRINGS REPAIRED WITH
VITON O RING

DIAMETER = 90

OPERIN MIN SPRING RATE

MAX COMP IN 25% (P. 45-13 OF
PARKER HANDBOOK) FROM P. 44-11
THE MAX LINEAR FORCE IS

$$160 \text{ LB/IN}$$

MIN DEFLATION (SQUARED) IS .058
(P. 45-13)

$$R = \frac{160}{.058} = 2759 \text{ LB/IN PER IN OF CIRCUMFERENCE}$$

FOR REPAIRED SPRINGS AT .2571*
IN SPACING

$$R_s = 2759 (.2571) = 709 \text{ LB/IN}$$

* REF CALL V049-1-016, P. 14 FOR
NOSE SPACING


22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



FLANGES - 3D FE ANALYSIS FOR BOLT PRELOAD
PLUS POS PRESSURE

ANALYSIS FOR POSITIVE PRESSURE USING
3D FE MODEL - 104 ID FLANGE USED

PRESSURE LOAD FROM ATTACHED
CYLINDER



$$F_y = \frac{P \cdot r}{2}$$

$$P = 2 \text{ PSI}$$

$$r = \frac{104.25}{2}$$

$$F_y = \frac{2 \left(\frac{104.25}{2} \right)}{2}$$

$$= 52.1 \text{ LB/IN}$$

NODE SPACING ALONG Y - GIVEN IS .2571

$$F_{y1} = 52.1 (.2571)$$

$$= 13.4 \text{ LB}$$

$$= \frac{13.4}{2} = 6.7 \text{ AT } Y=0, 3.6$$

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



DELETE SPANNERS
151, 152

DELETE SOLIDS
10, 11, 24, 25
206, 207, 220, 221
402, 403, 416, 417
598, 599, 612, 613
794, 795, 808, 809

BOLT LOADS

$$F_{PL} = 8500 \text{ LB}$$

FOR 1/2 BOLT

$$F_{PL} = -4250 \text{ LB}$$

$$F_{PL} = 14 F_{y1} + 4 F_{y2} / 2$$

$$-4250 = 16 F_{y1}$$

$$F_{y1} = -266 \text{ LB INTERIOR NODES}$$

$$F_{y1} = -\frac{266}{2} = -133 \text{ LB @ } X=0 \text{ AT END NODES}$$

PRESSURE LOAD

$$F_{y1} = +13.4 \text{ LB AT INTERIOR NODES @ } Z=0$$


$$F_{y1} = +6.7 \text{ LB AT END NODES @ } Z=0$$

IMAGES-3D
Ver. 3.0
Geometry Plot

TOP LAYER Nodes

?i
X range
?
X=Default
Y range
?.7,.75
Z range
?
Z=Default
?n
?n
?#
?

1351-1366-1381-1396-1411-1426-1441-1456-1471-1486-1501-1516-1531-1546-1561
 1352-1367-1382-1397-1412-1427-1442-1457-1472-1487-1502-1517-1532-1547-1562
 1353-1368-1383-1398-1413-1428-1443-1458-1473-1488-1503-1518-1533-1548-1563
 1354-1369-1384-1399-1414-1429-1444-1459-1474-1489-1504-1519-1534-1549-1564
 1355-1370-1385-1400-1415-1430-1445-1460-1475-1490-1505-1520-1535-1550-1565
 1356-1371-1386-1401-1416-1431-1446-1461-1476-1491-1506-1521-1536-1551-1566
 1357-1372-1387-1402-1417-1432-1447-1462-1477-1492-1507-1522-1537-1552-1567
 1358-1373-1388-1403-1418-1433-1448-1463-1478-1493-1508-1523-1538-1553-1568
 1359-1374-1389-1404-1419-1434-1449-1464-1479-1494-1509-1524-1539-1554-1569
 1360-1375-1390-1405-1420-1435-1450-1465-1480-1495-1510-1525-1540-1555-1570
 1361-1376-1391-1406-1421-1436-1451-1466-1481-1496-1511-1526-1541-1556-1571
 1362-1377-1392-1407-1422-1437-1452-1467-1482-1497-1512-1527-1542-1557-1572
 1363-1378-1393-1408-1423-1438-1453-1468-1483-1498-1513-1528-1543-1558-1573
 1364-1379-1394-1409-1424-1439-1454-1469-1484-1499-1514-1529-1544-1559-1574
 1365-1380-1395-1410-1425-1440-1455-1470-1485-1500-1515-1530-1545-1560-1575



Revision 0
Doc. No. V049-1-018
Page 8 of 18

Auto Node	Blowup Node#	Elem# Plot	Exit Range	Full Rest	Help Rotate	Local Shrink	Move Slice
-----------	--------------	------------	------------	-----------	-------------	--------------	------------

IMAGES-3D
Ver. 3.0
Geometry Plot


Nodes at Y=0 (at interface between flanges)

X range
?
X=Default
Y range
?-.04,.04
Z range
?
Z=Default
?r,90
?n
?n
?#
?

226	241	256	271	286	301	316	331	346	361	376	391	406	421	436
227	242	257	272	287	302	317	332	347	362	377	392	407	422	437
228	243	258	273	288	303	318	333	348	363	378	393	408	423	438
229	244	259	274	289	304	319	334	349	364	379	394	409	424	439
230	245	260	275	290	305	320	335	350	365	380	395	410	425	440
231	246	261	276	291	306	321	336	351	366	381	396	411	426	441
232	247	262	277	292	307	322	337	352	367	382	397	412	427	442
233	248	263	278	293	308	323	338	353	368	383	398	413	428	443
234	249	264	279	294	309	324	339	354	369	384	399	414	429	444
235	250	265	280	295	310	325	340	355	370	385	400	415	430	445
236	251	266	281	296	311	326	341	356	371	386	401	416	431	446
237	252	267	282	297	312	327	342	357	372	387	402	417	432	447
238	253	268	283	298	313	328	343	358	373	388	403	418	433	448
239	254	269	284	299	314	329	344	359	374	389	404	419	434	449
240	255	270	285	300	315	330	345	360	375	390	405	420	435	450

← INNER O-RING

← OUTER O-RING




Revision 0
Doc. No. V049-1-018
Page 9 of 18

Auto	Blowup	Elem#	Exit	Full	Help	Local	Move
Node	Node#	Plot	Range	Rest	Rotate	Shrink	Slice

IMAGES-3D
Version 3.0

DEFLECTION ALONG OUTER O-RING



Revision 0
Doc. No. V049-1-018
Page 10 of 18



IMAGES-3D
Version 3.0

Y- DISPLACEMENT ALONG OUTER O-RING



ε Bolt

*MID PLANE
BETWEEN BOLTS*



Revision 0
Doc. No. V049-1-018
Page 11 of 18


Load Case
1

Displacement Contour Plot
DY

10/20/95
6:53:23

IMAGES-3D
Version 3.0

*Y- Displacement Along RASMI PLANE PASSING
THROUGH BOLT*



Revision 0
Doc. No. V049-1-018
Page 12 of 18




Load Case
1

Displacement Contour Plot
DY

10/20/95
6:57:6

IMAGES-3D
Version 3.0

*Y - DISPLACEMENT ALONG RADIAL PLANE
PASSING MIDWAY BETWEEN BOLTS*



Revision 0
Doc. No. V049-1-018
Page 13 of 18



Load Case
1

Displacement Contour Plot
DY

10/20/95
7: 2:23

IMAGES-3D
Version 3.0

STRESS INTENSITY ALONG RADIAL PLANE PASSING
THROUGH BOLT



Revision 0
Doc. No. V049-1-018
Page 14 of 18




Load Case
1

Stress Contour Plot
Stress Intensity

10/20/95
7:17:13

IMAGES-3D
Version 3.0

*STRESS INTENSITY ALONG RADIAL PLANE PASSING
MIDWAY BETWEEN BOES*



Revision 0
Doc. No. V049-1-018
Page 15 of 18

Load Case
1

Stress Contour Plot
Stress Intensity

10/20/95
7:22:44

14

Y - DISPLACEMENTS

	NODE	Δy	EXP
INNER O-RING	226	.1127	-3
	331	.1501	-3
	436	.1568	-3

IN } FROM
 OUTPUT
 FILE: FLANGE 3

	NODE	Δy	EXP
OUTER O-RING	232	.1536	-4
	337	.172	-3
	442	.251	-3

} SEE P. 10

RESIDUAL WITH = .184 (10)⁻¹⁰
 < 1 (10)⁻⁵

i. RUN CONVERGED AFTER 10 ITERATIONS

FOUNDATION	SPRING	LOADS
	NODE	F _y
INNER O-RING	226	.303 LB
	331	.355
	436	.403
OUTER O-RING	232	.380 (10) ⁻¹
	337	.122
	442	.178

OK

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



CIRCUIT Y-DIRECTION REACTION

$$\begin{aligned} & \text{BOLT} + \text{PRESS} \\ & -4250 + 52.1 \text{ lb/in} \times 3.6 \text{ in} \\ & = -4067 \# \end{aligned}$$

REACTION FROM OUTPUT =

$$\bar{F}_y = 4067 \text{ OR}$$

MAXIMUM SEPARATION OF FLANGES

MAX DEFLECTION IS AT NODE 436 (AT INNER O-RING MIDWAY BETWEEN BOLTS)

$$\Delta_z = .568 (10)^{-3}$$

FOR BOT. BOLT PRELOAD AND INTERNAL PRESSURE. DOUBLE THIS FOR 2 FLANGES

$$\begin{aligned} \Delta_y &= 2(.568) (10)^{-3} \\ &= 1.137 (10)^{-3} \text{ IN} \end{aligned}$$

COMPARE TO MINIMUM COMPRESSION OF .058 IN FROM PARKER HANDBOOK (P A5-13)

$$\frac{54 (10)^{-3}}{1.137} = 51$$

∴ OPENING OF GAP < INITIAL COMPRESSION OF O-RING AND O-RING REMAINS COMPRESSED DURING INTERNAL PRESS = 2 PSIG.

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



MAXIMUM TENSILE LOAD AT VITON O-RING

$$T = .403 \text{ LB AT NODE 436}$$

ALONG THE O-RING, THE LINEAR FORCE IS

$$T = \frac{.403}{.257} \leftarrow \text{NODE SPACING} = 1.57 \text{ LB/IN}$$

THIS COMPARES TO MINIMUM SEALING LOAD OF 70 LB/IN (PAPER WORKBOOK, P. P4-11)

$$C - T = 70 - 1.57 = 68.4 \text{ LB/IN}$$

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-019 PAGE 1 OF 24
REV.	DEO #	DATE	BY:	CHECK	Flange Design for Internal Pressure	
0	0024	12/6/95	RDC	P.W./		
					BY: R.D. Ciarro	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
<p>PURPOSE: To evaluate bolted flanges ranging in diameter from 30 in. to 104 in. for positive internal pressure in accordance with the ASME Code.</p> <p>METHOD: The calculation method provided in Appendix Y of the ASME Code, Section VIII, Division 1, is used. This method applies to flat face flanges with metal-to-metal contact. It has been programmed on the Quattro-Pro spread sheet program.</p>						
ASSUMPTIONS:						
INPUTS: LIGO project sketches and drawings.						
<p>REFERENCES: 1. ASME Boiler & Pressure Vessel Code, Section VIII, Pressure Vessels, Div. 1, Appendix Y. 2. Quattro-Pro Version 5.00 3. Doc. No. V049-1-066, LIGO VACUUM EQUIP., STANDARD DESIGN CRITERIA</p>						
CALCULATIONS: (SEE ATTACHED)						
<p>CONCLUSIONS: Using a nominal bolt spacing of 7.2 in. for 7/8 in. diameter bolts, the flanges meet App. Y of Section VIII, Div. 1 for 2 psi internal pressure. Computer file names are shown in the lower left corner of the output in this calculation.</p>						
<p>NOTES: In this calculation, flange thickness varies from 3/4 in. for small diameter to 1 in. for large diameter flanges.</p>						

FLANGE DESIGN FOR INTERNAL PRESSURE

THE FLANGES ARE EVALUATED IN ACCORDANCE WITH SECT VIII, DIV 1 APP Y FOR END FOC FLANGES. THE DESIGN INTERNAL PRESSURE IS 2100 PSIG

THE NOMINAL FLANGE THICKNESS IS 2.00 IN

ROUNDER PDC IS USED FOR THE FLANGE EVALUATION. IT SHOWS THAT 7/8" BOLTS SPACED AT APPROX 7.2 IN ARE ADEQUATE.

FOR THE MAXIMUM DIAMETER OF 50, THE MAXIMUM C-RING COMPRESSION LOAD IS 160 LB/IN SINCE THERE IS A DOUBLE C-RING, THE LOAD IS MULTIPLIED BY 2 FOR THE ANALYSIS.

Hg = 2(160) = 320 LB/IN

THE ROOT DIAMETER OF THE 7/8" BOLT IS

db = .755 IN (AISC P 4-157)

WHICH IS USED TO REMOVE THE STRESS AREA

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



THIS PROGRAM SOLVES APPENDIX Y (Y-6.1) FLAT FACE FLANGES FOR CLASS 1, CAT 3 (LOOSE TYPE) ASSEMBLIES WITH OR WITHOUT SELF ENERGIZING GASKETS FOR POSITIVE PRESSURE OR VACUUM PRESSURE.

ANALYZE CLASS 1 CATEGORY 3 LOOSE TYPE FLANGES ONLY.

ASSUMPTIONS:

1. $g_1=g_0$ =thickness of vessel wall
2. B substituted for B1
3. conditions at bolt up and operating evaluated separately
4. $F'=0$ for loose type flanges implies M_s is zero

REQUIRED INPUT:

- C = BOLT CIRCLE DIAM in.
- PRES = Internal Pressure for this case
- B=ID OF FLANGE
- A=OD OF FLANGE
- g_1 =THICKNESS OF HUB AT LARGE END
- g_0 =THICK @ SMALL END
- r_b =SEE FIG Y3.1
- V=SEE FIG 2-7.3
- F=SEE FIG 2-7.2
- t=FLANGE THICKNESS ASSUMED VALUE
- G=DIAM OF GASKET
- n=NUMBER OF BOLTS
- d_b =DIAM OF BOLTS
- r_e =RATIO MOD E (flange)/ MOD E (bolts)
- Z=SEE FIG 2-7.1

INPUT VALUES..... 104 1/4 in Flange

C	PRES	B	A	g_1	g_0	V
110.00	2.00	105.00	112.00	0.000	0.000	0.11
				g_1 and $g_2=0$ for loose type flanges		fig 2-7.3 required for integral only

F	t	G	n	db	rE	fhub
0.75	1.00	108.25	48	0.755	0.96	1.00

fig 2-7.2
required for
integral only

fig 2-7.6
fhub= 1 for
loose type
flanges

Sbb	Sfb	Snb	Sbo	Sfo	Sno	Hg(unit)
25000	14700	14700	25000	14700	14700	320

unit gasket
seating and
sealing forces

RESULTS/OUTPUT:

- Si = DESIGN PRESTRESS IN BOLTS
- Sr@BC = RAD. FLANGE STRESS @ BOLT CIRCLE
- Sr@ID = RAD FLG STRESS @ ID
- St = TANGENTIAL FLANGE STRESS @ ID
- Sh = LONGITUDINAL HUB STRESS (= 0 FOR CL1, CAT3 LOOSE TYPE FLANGES)

CALCULATED VALUES.....

R	hd	Js	Jp	B1	BETA	a
2.50	2.50	0.0525	0.0292	105.00	1.02	1.0571

for loose
type flgs

hc	ho	F'	Hd	H	Ht	Hg
0.50	0.00	0.00	17318.0	18406.7	1088.66	108824.8

hg	ht	l	Mpo	Mpb	Ms	E0bo
0.88	1.688	2.755	140353.861	95221.7	0.00	7129.60
			operating moment	bolt up moment		operating slope

E0bb	Hco	Hcb	Wm1o	Wm1b	Ab	D
4837.01	2.807E+05	190443.3	407939.2	299268.1	21.49	0.818
bolt up slope	operating contact	bolt up contact	operating bolt load	bolt up bolt load		

AR	rB	nrB	K	Z
0.113550	0.000467	0.022424	1.066667	15.52

SIGMAbo	SIGMAbb	Sio	Sib	Sr@BCo	Sr@BCb
18983.24	13926.29	18844.7	13832.3	2749.0	1865.0
25000.00	25000.00	25000.00	25000.00	14700.00	14700.00
ok	ok	ok	ok	ok	ok

St@IDo	St@IDb
67.9	46.1
14700.00	14700.00
ok	ok

THIS PROGRAM SOLVES APPENDIX Y (Y-6.1) FLAT FACE FLANGES FOR CLASS 1, CAT 3 (LOOSE TYPE) ASSEMBLIES WITH OR WITHOUT SELF ENERGIZING GASKETS FOR POSITIVE PRESSURE OR VACUUM PRESSURE.

ANALYZE CLASS 1 CATEGORY 3 LOOSE TYPE FLANGES ONLY.

ASSUMPTIONS:

1. $g1=g0$ =thickness of vessel wall
2. B substituted for B1
3. conditions at bolt up and operating evaluated separately
4. $F'=0$ for loose type flanges implies M_s is zero

REQUIRED INPUT:

C = BOLT CIRCLE DIAM in.
 PRES = Internal Pressure for this case
 B=ID OF FLANGE
 A=OD OF FLANGE
 g1=THICKNESS OF HUB AT LARGE END
 g0=THICK @ SMALL END
 rb=SEE FIG Y3.1
 V=SEE FIG 2-7.3
 F=SEE FIG 2-7.2
 t=FLANGE THICKNESS ASSUMED VALUE
 G=DIAM OF GASKET
 n=NUMBER OF BOLTS
 db=DIAM OF BOLTS
 re=RATIO MOD E (flange)/ MOD E (bolts)
 Z=SEE FIG 2-7.1

INPUT VALUES..... 84 1/4 in Flange

C	PRES	B	A	g1	g0	V
89.75	2.00	84.75	91.75	0.000	0.000	0.11

g1 and g2=0 for loose type flanges
 fig 2-7.3 required for integral only

F	t	G	n	db	rE	fhub
	1.00	88.00	40	0.755	0.96	1.00

fig 2-7.2
required for
integral only

fig 2-7.6
fhub= 1 for
loose type
flanges

Sbb	Sfb	Snb	Sbo	Sfo	Sno	Hg(unit)
25000	14700	14700	25000	14700	14700	320

unit gasket
seating and
sealing forces

RESULTS/OUTPUT:

- Si = DESIGN PRESTRESS IN BOLTS
- Sr@BC = RAD. FLANGE STRESS @ BOLT CIRCLE
- Sr@ID = RAD FLG STRESS @ ID
- St = TANGENTIAL FLANGE STRESS @ ID
- Sh = LONGITUDINAL HUB STRESS (= 0 FOR CL1, CAT3 LOOSE TYPE FLANGES)

CALCULATED VALUES.....

R	hd	Js	Jp	B1	BETA	a
2.50	2.50	0.0650	0.0363	84.75	1.03	1.0708

for loose
type flgs

hc	ho	F'	Hd	H	Ht	Hg
0.50	0.00	0.00	11282.3	12164.2	881.90	88467.2

hg	ht	l	Mpo	Mpb	Ms	E0bo
0.88	1.688	2.755	107102.913	77408.8	0.00	6759.70
			operating moment	bolt up moment		operating slope

E0bb	Hco	Hcb	Wm1o	Wm1b	Ab	D
4885.59	2.142E+05	154817.7	314837.3	243284.9	17.91	0.880
bolt up slope	operating contact	bolt up contact	operating bolt load	bolt up bolt load		

AR	rB	nrB	K	Z
0.124841	0.000685	0.027398	1.082596	12.63

SIGMAbo	SIGMAbb	Sio	Sib	Sr@BCo	Sr@BCb
17580.95	13585.37	17451.7	13491.9	2604.2	1882.2
25000.00	25000.00	25000.00	25000.00	14700.00	14700.00
ok	ok	ok	ok	ok	ok

St@IDo	St@IDb
79.8	57.6
14700.00	14700.00
ok	ok

THIS PROGRAM SOLVES APPENDIX Y (Y-6.1) FLAT FACE FLANGES FOR CLASS 1, CAT 3 (LOOSE TYPE) ASSEMBLIES WITH OR WITHOUT SELF ENERGIZING GASKETS FOR POSITIVE PRESSURE OR VACUUM PRESSURE.

ANALYZE CLASS 1 CATEGORY 3 LOOSE TYPE FLANGES ONLY.

ASSUMPTIONS:

- 1. $g_1=g_0$ =thickness of vessel wall
- 2. B substituted for B1
- 3. conditions at bolt up and operating evaluated separately
- 4. $F=0$ for loose type flanges implies M_s is zero

REQUIRED INPUT:

- C = BOLT CIRCLE DIAM in.
- PRES = Internal Pressure for this case
- B=ID OF FLANGE
- A=OD OF FLANGE
- g_1 =THICKNESS OF HUB AT LARGE END
- g_0 =THICK @ SMALL END
- rb=SEE FIG Y3.1
- V=SEE FIG 2-7.3
- F=SEE FIG 2-7.2
- t=FLANGE THICKNESS ASSUMED VALUE
- G=DIAM OF GASKET
- n=NUMBER OF BOLTS
- db=DIAM OF BOLTS
- re=RATIO MOD E (flange)/ MOD E (bolts)
- Z=SEE FIG 2-7.1

INPUT VALUES..... 72 1/4 in Flange

C	PRES	B	A	g_1	g_0	V
77.75	2.00	72.75	79.75	0.000	0.000	0.11
				g1 and g2=0 for loose type flanges		fig 2-7.3 required for integral only

Revision 0
 Doc. No. V049-1-019
 Page 9 of 24

F	t	G	n	db	rE	fhub
	1.00	76.00	36	0.755	0.96	1.00

fig 2-7.2
required for
integral only

fig 2-7.6
fhub= 1 for
loose type
flanges

Sbb	Sfb	Snb	Sbo	Sfo	Sno	Hg(unit)
25000	14700	14700	25000	14700	14700	320

unit gasket
seating and
sealing forces

RESULTS/OUTPUT:

- Si = DESIGN PRESTRESS IN BOLTS
- Sr@BC = RAD. FLANGE STRESS @ BOLT CIRCLE
- Sr@ID = RAD FLG STRESS @ ID
- St = TANGENTIAL FLANGE STRESS @ ID
- Sh = LONGITUDINAL HUB STRESS (= 0 FOR CL1, CAT3 LOOSE TYPE FLANGES)

CALCULATED VALUES.....

R	hd	Js	Jp	B1	BETA	a
2.50	2.50	0.0754	0.0422	72.75	1.03	1.0825

for loose
type flgs

hc	ho	F'	Hd	H	Ht	Hg
0.50	0.00	0.00	8313.5	9072.9	759.38	76403.5

hg	ht	l	Mpo	Mpb	Ms	E0bo
0.88	1.688	2.755	88918.3929	66853.1	0.00	6516.01
			operating moment	bolt up moment		operating slope

E0bb	Hco	Hcb	Wm1o	Wm1b	Ab	D
4899.04	1.778E+05	133706.2	263313.2	210109.7	16.12	0.880
bolt up slope	operating contact	bolt up contact	operating bolt load	bolt up bolt load		

AR	rB	nrB	K	Z
0.129698	0.000825	0.029710	1.096220	10.92

SIGMAbo	SIGMAbb	Sio	Sib	Sr@BCo	Sr@BCb
16337.53	13036.47	16213.8	12943.5	2509.7	1886.9
25000.00	25000.00	25000.00	25000.00	14700.00	14700.00
ok	ok	ok	ok	ok	ok

St@IDo	St@IDb
89.6	67.3
14700.00	14700.00
ok	ok

THIS PROGRAM SOLVES APPENDIX Y (Y-6.1) FLAT FACE FLANGES FOR CLASS 1, CAT 3 (LOOSE TYPE) ASSEMBLIES WITH OR WITHOUT SELF ENERGIZING GASKETS FOR POSITIVE PRESSURE OR VACUUM PRESSURE.

ANALYZE CLASS 1 CATEGORY 3 LOOSE TYPE FLANGES ONLY.

ASSUMPTIONS:

1. $g_1 = g_0 =$ thickness of vessel wall
2. B substituted for B1
3. conditions at bolt up and operating evaluated separately
4. $F = 0$ for loose type flanges implies M_s is zero

REQUIRED INPUT:

C = BOLT CIRCLE DIAM in.
 PRES = Internal Pressure for this case
 B=ID OF FLANGE
 A=OD OF FLANGE
 g_1 =THICKNESS OF HUB AT LARGE END
 g_0 =THICK @ SMALL END
 rb=SEE FIG Y3.1
 V=SEE FIG 2-7.3
 F=SEE FIG 2-7.2
 t=FLANGE THICKNESS ASSUMED VALUE
 G=DIAM OF GASKET
 n=NUMBER OF BOLTS
 db=DIAM OF BOLTS
 re=RATIO MOD E (flange)/ MOD E (bolts)
 Z=SEE FIG 2-7.1

INPUT VALUES..... 60 1/4 in Flange Thickness = 7/8 in

C	PRES	B	A	g_1	g_0	V
65.75	2.00	60.75	67.75	0.000	0.000	0.11

g_1 and $g_2 = 0$ for loose type flanges
 fig 2-7.3 required for integral only

Revision 0
 Doc. No. V049-1-019
 Page 12 of 24

F	t	G	n	db	rE	fhub
	0.875	64.00	30	0.755	0.96	1.00

fig 2-7.2
required for
integral only

fig 2-7.6
fhub= 1 for
loose type
flanges

Sbb	Sfb	Snb	Sbo	Sfo	Sno	Hg(unit)
25000	14700	14700	25000	14700	14700	320

unit gasket
seating and
sealing forces

RESULTS/OUTPUT:

- Si = DESIGN PRESTRESS IN BOLTS
- Sr@BC = RAD. FLANGE STRESS @ BOLT CIRCLE
- Sr@ID = RAD FLG STRESS @ ID
- St = TANGENTIAL FLANGE STRESS @ ID
- Sh = LONGITUDINAL HUB STRESS (= 0 FOR CL1, CAT3 LOOSE TYPE FLANGES)

CALCULATED VALUES.....

R	hd	Js	Jp	B1	BETA	a
2.50	2.50	0.0896	0.0500	60.75	1.04	1.0988

for loose
type flgs

hc	ho	F'	Hd	H	Ht	Hg
0.50	0.00	0.00	5797.1	6434.0	636.86	64339.8

hg	ht	l	Mpo	Mpb	Ms	E0bo
0.88	1.688	2.505	71864.8462	56297.3	0.00	9327.89
			operating moment	bolt up moment		operating slope

E0bb	Hco	Hcb	Wm1o	Wm1b	Ab	D
7307.26	1.437E+05	112594.7	214503.5	176934.5	13.43	0.880
bolt up slope	operating contact	bolt up contact	operating bolt load	bolt up bolt load		

AR	rB	nrB	K	Z
0.127808	0.000960	0.028798	1.115226	9.21

SIGMAbo	SIGMAbb	Sio	Sib	Sr@BCo	Sr@BCb
15970.90	13173.69	15777.3	13022.0	3126.0	2448.9
25000.00	25000.00	25000.00	25000.00	14700.00	14700.00
ok	ok	ok	ok	ok	ok

St@IDo	St@IDb
134.4	105.2
14700.00	14700.00
ok	ok

THIS PROGRAM SOLVES APPENDIX Y (Y-6.1) FLAT FACE FLANGES FOR CLASS 1, CAT 3 (LOOSE TYPE) ASSEMBLIES WITH OR WITHOUT SELF ENERGIZING GASKETS FOR POSITIVE PRESSURE OR VACUUM PRESSURE.

ANALYZE CLASS 1 CATEGORY 3 LOOSE TYPE FLANGES ONLY.

ASSUMPTIONS:

1. $g_1=g_0$ =thickness of vessel wall
2. B substituted for B1
3. conditions at bolt up and operating evaluated separately
4. $F'=0$ for loose type flanges implies M_s is zero

REQUIRED INPUT:

C = BOLT CIRCLE DIAM in.
 PRES = Internal Pressure for this case
 B=ID OF FLANGE
 A=OD OF FLANGE
 g_1 =THICKNESS OF HUB AT LARGE END
 g_0 =THICK @ SMALL END
 rb=SEE FIG Y3.1
 V=SEE FIG 2-7.3
 F=SEE FIG 2-7.2
 t=FLANGE THICKNESS ASSUMED VALUE
 G=DIAM OF GASKET
 n=NUMBER OF BOLTS
 db=DIAM OF BOLTS
 re=RATIO MOD E (flange)/ MOD E (bolts)
 Z=SEE FIG 2-7.1

INPUT VALUES..... 48 1/4 in Flange Thickness = 7/8 in

C	PRES	B	A	g_1	g_0	V
53.75	2.00	48.75	55.75	0.000	0.000	0.11
				g_1 and $g_2=0$ for loose type flanges		fig 2-7.3 required for integral only

F	t	G	n	db	rE	fhub
	0.875	52.00	24	0.755	0.96	1.00

fig 2-7.2
required for
integral only

fig 2-7.6
fhub= 1 for
loose type
flanges

Sbb	Sfb	Snb	Sbo	Sfo	Sno	Hg(unit)
25000	14700	14700	25000	14700	14700	320

unit gasket
seating and
sealing forces

RESULTS/OUTPUT:

- Si = DESIGN PRESTRESS IN BOLTS
- Sr@BC = RAD. FLANGE STRESS @ BOLT CIRCLE
- Sr@ID = RAD FLG STRESS @ ID
- St = TANGENTIAL FLANGE STRESS @ ID
- Sh = LONGITUDINAL HUB STRESS (= 0 FOR CL1, CAT3 LOOSE TYPE FLANGES)

CALCULATED VALUES.....

R	hd	Js	Jp	B1	BETA	a
2.50	2.50	0.1103	0.0615	48.75	1.05	1.1231

for loose
type flgs

hc	ho	F'	Hd	H	Ht	Hg
0.50	0.00	0.00	3733.1	4247.4	514.34	52276.1

hg	ht	l	Mpo	Mpb	Ms	E0bo
0.88	1.688	2.505	55942.2729	45741.6	0.00	8927.49
			operating moment	bolt up moment		operating slope

E0bb	Hco	Hcb	Wm1o	Wm1b	Ab	D
7299.62	1.119E+05	91483.2	168408.1	143759.3	10.74	0.880
bolt up slope	operating contact	bolt up contact	operating bolt load	bolt up bolt load		

AR	rB	nrB	K	Z
0.125074	0.001146	0.027507	1.143590	7.50

SIGMAbo	SIGMAbb	Sio	Sib	Sr@BCo	Sr@BCb
15673.57	13379.53	15489.8	13229.3	2967.4	2426.3
25000.00	25000.00	25000.00	25000.00	14700.00	14700.00
ok	ok	ok	ok	ok	ok

St@IDo	St@IDb
160.2	131.0
14700.00	14700.00
ok	ok

THIS PROGRAM SOLVES APPENDIX Y (Y-6.1) FLAT FACE FLANGES FOR CLASS 1, CAT 3 (LOOSE TYPE) ASSEMBLIES WITH OR WITHOUT SELF ENERGIZING GASKETS FOR POSITIVE PRESSURE OR VACUUM PRESSURE.

ANALYZE CLASS 1 CATEGORY 3 LOOSE TYPE FLANGES ONLY.

ASSUMPTIONS:

1. $g_1=g_0$ =thickness of vessel wall
2. B substituted for B1
3. conditions at bolt up and operating evaluated separately
4. $F'=0$ for loose type flanges implies M_s is zero

REQUIRED INPUT:

C = BOLT CIRCLE DIAM in.
 PRES = Internal Pressure for this case
 B=ID OF FLANGE
 A=OD OF FLANGE
 g_1 =THICKNESS OF HUB AT LARGE END
 g_0 =THICK @ SMALL END
 rb=SEE FIG Y3.1
 V=SEE FIG 2-7.3
 F=SEE FIG 2-7.2
 t=FLANGE THICKNESS ASSUMED VALUE
 G=DIAM OF GASKET
 n=NUMBER OF BOLTS
 db=DIAM OF BOLTS
 re=RATIO MOD E (flange)/ MOD E (bolts)
 Z=SEE FIG 2-7.1

INPUT VALUES..... 44 1/4 in Flange Thickness = 3/4 in

C	PRES	B	A	g_1	g_0	V
49.75	2.00	44.75	51.75	0.000	0.000	0.11
				g_1 and $g_2=0$ for loose type flanges		fig 2-7.3 required for integral only

F	t	G	n	db	rE	fhub
	0.750	48.00	24	0.755	0.96	1.00

fig 2-7.2
required for
integral only

fig 2-7.6
fhub= 1 for
loose type
flanges

Sbb	Sfb	Snb	Sbo	Sfo	Sno	Hg(unit)
25000	14700	14700	25000	14700	14700	320

unit gasket
seating and
sealing forces

RESULTS/OUTPUT:

- Si = DESIGN PRESTRESS IN BOLTS
- Sr@BC = RAD. FLANGE STRESS @ BOLT CIRCLE
- Sr@ID = RAD FLG STRESS @ ID
- St = TANGENTIAL FLANGE STRESS @ ID
- Sh = LONGITUDINAL HUB STRESS (= 0 FOR CL1, CAT3 LOOSE TYPE FLANGES)

CALCULATED VALUES.....

R	hd	Js	Jp	B1	BETA	a
2.50	2.50	0.1199	0.0670	44.75	1.06	1.1341

for loose
type flgs

hc	ho	F'	Hd	H	Ht	Hg
0.50	0.00	0.00	3145.6	3619.1	473.50	48254.9

hg	ht	l	Mpo	Mpb	Ms	E0bo
0.88	1.688	2.255	50886.0759	42223.0	0.00	14046.64
			operating moment	bolt up moment		operating slope

E0bb	Hco	Hcb	Wm1o	Wm1b	Ab	D
11655.27	1.018E+05	84446.0	153646.1	132700.9	10.74	0.880
bolt up slope	operating contact	bolt up contact	operating bolt load	bolt up bolt load		

AR	rB	nrB	K	Z
0.135130	0.001351	0.032420	1.156425	6.93

SIGMAbo	SIGMAbb	Sio	Sib	Sr@BCo	Sr@BCb
14299.69	12350.34	13981.6	12086.4	4015.4	3331.8
25000.00	25000.00	25000.00	25000.00	14700.00	14700.00
ok	ok	ok	ok	ok	ok

St@IDo	St@IDb
235.4	195.3
14700.00	14700.00
ok	ok

THIS PROGRAM SOLVES APPENDIX Y (Y-6.1) FLAT FACE FLANGES FOR CLASS 1, CAT 3 (LOOSE TYPE) ASSEMBLIES WITH OR WITHOUT SELF ENERGIZING GASKETS FOR POSITIVE PRESSURE OR VACUUM PRESSURE.

ANALYZE CLASS 1 CATEGORY 3 LOOSE TYPE FLANGES ONLY.

ASSUMPTIONS:

1. $g_1=g_0$ =thickness of vessel wall
2. B substituted for B1
3. conditions at bolt up and operating evaluated separately
4. $F'=0$ for loose type flanges implies M_s is zero

REQUIRED INPUT:

C = BOLT CIRCLE DIAM in.
 PRES = Internal Pressure for this case
 B=ID OF FLANGE
 A=OD OF FLANGE
 g_1 =THICKNESS OF HUB AT LARGE END
 g_0 =THICK @ SMALL END
 rb=SEE FIG Y3.1
 V=SEE FIG 2-7.3
 F=SEE FIG 2-7.2
 t=FLANGE THICKNESS ASSUMED VALUE
 G=DIAM OF GASKET
 n=NUMBER OF BOLTS
 db=DIAM OF BOLTS
 re=RATIO MOD E (flange)/ MOD E (bolts)
 Z=SEE FIG 2-7.1

INPUT VALUES..... 30 1/4 in Flange Thickness = 3/4 in

C	PRES	B	A	g_1	g_0	V
35.75	2.00	30.75	37.75	0.000	0.000	0.11

g_1 and $g_2=0$ for loose type flanges
 fig 2-7.3 required for integral only

F	t	G	n	db	rE	fhub
	0.750	34.00	16	0.755	0.96	1.00

fig 2-7.2
required for
integral only

fig 2-7.6
fhub= 1 for
loose type
flanges

Sbb	Sfb	Snb	Sbo	Sfo	Sno	Hg(unit)
25000	14700	14700	25000	14700	14700	320

unit gasket
seating and
sealing forces

RESULTS/OUTPUT:

- Si = DESIGN PRESTRESS IN BOLTS
- Sr@BC = RAD. FLANGE STRESS @ BOLT CIRCLE
- Sr@ID = RAD FLG STRESS @ ID
- St = TANGENTIAL FLANGE STRESS @ ID
- Sh = LONGITUDINAL HUB STRESS (= 0 FOR CL1, CAT3 LOOSE TYPE FLANGES)

CALCULATED VALUES.....

R	hd	Js	Jp	B1	BETA	a
2.50	2.50	0.1694	0.0942	30.75	1.08	1.1951

for loose
type flgs

hc	ho	F'	Hd	H	Ht	Hg
0.50	0.00	0.00	1485.3	1815.8	330.55	34180.5

hg	ht	l	Mpo	Mpb	Ms	E0bo
0.88	1.688	2.255	34178.988	29908.0	0.00	13266.80
			operating moment	bolt up moment		operating slope

E0bb	Hco	Hcb	Wm1o	Wm1b	Ab	D
11608.97	6.836E+04	59815.9	104354.3	93996.5	7.16	0.880
bolt up slope	operating contact	bolt up contact	operating bolt load	bolt up bolt load		

AR	rB	nrB	K	Z
0.125365	0.001728	0.027643	1.227642	4.94

SIGMAbo	SIGMAbb	Sio	Sib	Sr@BCo	Sr@BCb
14568.23	13122.23	14273.2	12864.0	3711.4	3247.6
25000.00	25000.00	25000.00	25000.00	14700.00	14700.00
ok	ok	ok	ok	ok	ok

St@IDo	St@IDb
323.6	283.1
14700.00	14700.00
ok	ok

Bolt Preload

PER APP Y, THE DESIGN BOLT PRELOAD IS W_{M10} (CONSIDERS INTERNAL PRESSURE AT OPERATING CONDITION)

FLANGE SIZE	N	W_{M10} LB	$F_{PL} = \frac{W_{M10}}{N}$	USE
104	48	407939	8498	8500 LB
84	40	314137	7870	↓
72	36	263313	7314	
60	30	214504	7150	
48	24	164404	7017	
44	24	153646	6402	
30	16*	104307	6522	

NOTE: BOLT PRELOAD IS INCREASED TO 10 K. BOLT STRESS IS STILL WITHIN LIMIT. REF CALL 042, P. 20.

* NO. OF BOLTS WAS INCREASED TO 24 FOR THE 30 IN FLANGE. REF CALL 042, P. 26


REVISION 0
 Doc. No. V049-1-019
 P 24 OF 24

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-020 PAGE 1 OF 13
REV.	DEO #	DATE	BY:	CHECK	Beam Splitter Chamber - Design of Removable Work Floor	
0	0024	4/12/96	ROC	AGR		
					BY: R.D. Ciatto	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
<u>PURPOSE:</u> To design removable floor and support members to be installed in lower section of BSC.						
<u>METHOD:</u> Hand calculations using standard beam design method for support beams and removable floor sections.						
<u>ASSUMPTIONS:</u>						
<u>INPUTS:</u> See Doc. No. LIGO-C951078-00-4 which provides response to V049-NL-PL-9 (requesting clarifications of BSC internal floor requirements). Maximum load is 500 Kg during maintenance. This occurs at room temperature.						
<u>REFERENCES:</u> 1. ASME Boiler & Pressure Vessel Code, Section VIII, Pressure Vessels, Division 1. 2. Aluminum Association Handbook 3. Doc. No. V049-1-004, LIGO VAC. ROOM, STRUCT. DESIGN CR.						
<u>CALCULATIONS:</u> (SEE ATTACHED)						
<u>CONCLUSIONS:</u> The design of the aluminum floor meets LIGO requirements and the requirements of the applicable design codes.						
<u>NOTES:</u>						

20-141 50 SHEETS
20-142 100 SHEETS
20-144 200 SHEETS



I 6 X 4.3
AL CORR BR



C12 X 10.374 (TYP) - FLAT SIDE UP

MATSR.20

S.B 221 - CORR - T6

REV 0
Doc. No. V047-1-020
P. 2 OF 13


100 SHEETS
142 100 SHEETS
144 200 SHEETS



RING THICKNESS = 1/2"
 GUSSET THICKNESS = 3/8"

REV 0
 Doc. No. V049-1-020
 P. 3 OF 13

FLOOR SUPPORT - 54500 CONCRETE



12-111 100 SHEETS
 12-112 100 SHEETS
 12-114 200 SHEETS
 (12-111)

REV D
 Doc. No. 1047-1-020
 P. 4 OF 13

FLOOR MATERIAL

SB 221 ALLOY 6061
TEMPER T6

YIELD $F_y = 35 \text{ KSI}$ @ ROOM TEMP

ULTIMATE $F_u = 38 \text{ KSI}$ @ ROOM TEMP
REF. ASME B&PV CODE SECT II, TABLE 13

ALLOWABLE BENDING STRESS

FOR WEAK AXIS BENDING USE ASCE CODE

$$F_b = 0.75 F_y \\ = 0.75 (35) = 26.25 \text{ KSI}$$

NOTE: THIS IS LESS THAN ALUMINUM ASCE,
ALLOWABLE USING $F_s = 1.5$

FOR STRONG AXIS BENDING STRESS
WILL BE KEPT RELATIVELY LOW TO
AVOID LOCAL & LATERAL TORSIONAL
BUCKLING

REV 0
Doc. No. V049-1-070
P. 5 OF 13



STIFFNESS OF ALUM C12 X 7.41 FOR
 LOAD AT CENTER BENT ABOUT WEAK
 AXIS

$$\Delta_y = \frac{PL^3}{48EI_y}$$

$$L = 104$$

$$E = 10(10)^6 \text{ psi}$$

$$I_y = 3.99 \text{ in}^4$$

$$\begin{aligned} \Delta_y &= \frac{P(104)^3}{48(10^7)(3.99)} \\ &= \frac{P}{1702.6} \end{aligned}$$

$$R_1 = 1702.6 = \frac{P}{\Delta_y} \text{ LB/IN}$$

STIFFNESS OF ALUM I6 X 4.3 FOR LOAD
 AT CENTER BENT ABOUT STRONG AXIS


$$I_x = 22.08 \text{ in}^4$$

$$\begin{aligned} R_2 = \frac{P}{\Delta_y} &= \frac{48(10)^7(22.08)}{(104)^3} \\ &= 9422 \text{ LB/IN} \end{aligned}$$

REV D
 Doc. No. V049-1-020
 P. 6 OF 13



THE SUPPORT BEAM AND THE LADGE-CHANNEL ACT AS SPRINGS IN PARALLEL FOR A LMO AT THE CENTER OF THE VESSEL



$$K = R_1 + R_2$$

$$= 1703 + 5422 = 11125 \text{ LB/IN}$$

HAN DEFL AT CTR (LIVE LOAD)

$$K = \frac{P}{\Delta}$$

$$\Delta = \frac{P}{K} = \frac{1100}{11125} = .10 \text{ IN OK}$$

STRESS IN INVERTED CHANNEL DUE TO LOAD AT CTR.

$$\Delta = \frac{P_1}{R_1}$$

$$P_1 = \Delta R_1 = .10(1703) = 170 \text{ LB}$$

$$M = \frac{PL}{4} + \frac{wL^2}{8}$$

$$= \frac{170(104)}{4} + \frac{7.41(104)^2}{8}$$

$$= 4420 + 835$$

$$= 5255 \text{ IN-LB}$$

REV D
DOC NO V049-1-020
P. 7 OF 13

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS

$$S_y = 1.76 \text{ FOR } C12 \times 7.41^*$$

* CHANGED TO C12 X 10.374

$$f_b = \frac{M}{S} = \frac{5255}{1.76} = 2985 \text{ psi OK}$$

STRESS IN INVERTED CHANNEL W/ LOAD AT 1/4 PT

$$M = \frac{1150(52)}{4} + \frac{7.41}{12} \frac{(52)^2}{8}$$

$$= 14800 + 209$$

$$= 15009 \text{ IN-LB}$$

$$f_b = \frac{M}{S} = \frac{15009}{1.76} = 8527 \text{ psi OK}$$

STRESS IN SURFACE BEAM DOG - 200

Use $w = 30 \overset{C125}{-} 4.3 = 34.3 \text{ LB/FT}$

$$\approx 3 \text{ LB/IN}$$

$$M = \frac{wL^2}{8} = \frac{3(101)^2}{8}$$

$$= 4056$$

$$f_b = \frac{M}{S_y} = \frac{4056}{7.36} = 550 \text{ psi}$$

REV 0
 Doc. NO. 1049-1-020
 P. 8 OF 13

STRESS IN SUPPORT BEAM DUE TO
LIVE LOAD AT CENTER

$$\Delta = \frac{P_2}{K_2}$$

$$P_2 = K_2 \Delta$$

$$= 9422 (.10) = 942 \text{ LB}$$

$$M = \frac{PL}{4} = \frac{547(104)}{4} = 24500$$

$$f_b = \frac{M}{S_x} = \frac{24500}{22.02}$$

$$= 1100 \text{ psi}$$

TOTAL STRESS IN SUPPORT BEAM DUE TO
DW & LL

$$f_b = 1100 + 550$$


$$= 1650 \text{ psi} \quad 1.0W$$

REV. 0
Doc. No. V045-1-070
P. 9 OF 13

BENDING STRESS IN WEB OF CHANNEL

TAY C12 X 13.374 AISC STD

WEB THICKNESS $t = .510$



ASSUME THAT LOAD IS 3 IN WIDE

$$M = \frac{PL}{4} = \frac{1100(12)}{4} = 3300 \text{ in-lb}$$

$$f = \frac{6M}{bt^2} = \frac{6(3300)}{3(.510)^2} = 25400 \text{ psi}$$

$< 26250 \text{ psi}$ OK

FOR BENDING ABOUT WEAK AXIS

$$S_y = 2.06 \text{ PER AISC CODE}$$

= SECT. MODULUS

ASSUME SIMPLE SUPPORT BEAM AT CENTER OF BSC

$$L = 52$$

$$M = \frac{1100(52)}{4} = 14300 \text{ in-lb}$$

$$f_b = \frac{14300}{2.06} = 6940 \text{ psi}$$

REV D
DOC. NO. VPI19-1-022
P. 10 OR 13

SUPPORT RING

GUSSETS WILL BE PLACED UNDER SUPPORT RING SO THAT THEY ARE ALIGNED WITH POINT OF CONTACT OF C12 FLANGE

THE MAX REACTION FROM THE C12 IS

$$R = 1100 + 52 \times 10.774 \\ = 1640 \text{ LB}$$

SINCE THE GUSSET IS $\frac{3}{8}$ " THICK AND THE WEID BETWEEN THE SHELL & GUSSET IS A FULL PEN., THE WEID AREA IS

$$A_w = 2 \left(\frac{3}{8} \right) = .75 \text{ IN}^2$$

WEID SHEAR STRESS

$$f_v = \frac{R}{A_w} \\ = \frac{1640}{.75} = \\ = 2200 \text{ psi OK}$$

SUPPORT RING & GUSSETS ARE 304/304L

REV D
Doc. No. V049-1-020
P. 11 OF 13

SUPPORT BEAM CONNECTION TO STEEL
THE WEB THICKNESS FOR THE I6x4.3
IS

$$t_w = .23 \text{ IN}$$

FOR A SINGLE 3/4 IN PIN
THE BEARING AREA IS

$$A_p = .75(.23) \\ = .1725$$

THE MAX REACTION IS

$$R = \frac{104}{2(12)} (2 \times 13 \times 4 \frac{1}{2}) + 1100 \\ = 150 + 1100 = 1250 \text{ LB}$$

BEARING STRESS

$$f_p = \frac{R}{A_p} \\ = \frac{1250}{.1725} = 7250 \text{ PSI} \quad \text{WR}$$

USE A 1 IN PIN TO REDUCE f_p

$$f_p = 7250 \times .75 = 5400 \text{ PSI}$$

IN DOUBLE SHEAR

$$A_s = 2 \pi (1.5)^2 \\ = 1.57 \text{ IN}^2$$

$$f_v = \frac{1250}{1.57} = 800 \text{ PSI} \quad \text{OR FOR SS PIN}$$



DICKERSON AND ASSOCIATES
SHELBY AND ACORN SUPPORT BEAM

$$\alpha_{AL} = 13.52 (10)^{-6} \frac{IN}{IN^2 F}$$

FOR 6061

$$\alpha_{SS} = 9.19 (10)^{-6}$$

FOR TEMP RISE TO 400°F

$$\Delta T = 400 - 70 = 330^\circ F$$

$$\delta = (\alpha_{AL} - \alpha_{SS}) L \Delta T$$

$$L = 104 \text{ IN}$$

$$\delta = (13.52 - 9.19) (10)^{-6} (104) (330) \\ = .15 \text{ IN}$$

USE AN OPPOSITE BOLT HOLE TO
TAKE δ FROM B/C $\&$

$$\delta = \frac{.15}{2} = .075$$

HOLE SIZE = $1\frac{1}{2}$ GIVES CLEARANCE


$$.125 > \delta = .075 \quad \text{OK}$$

REV D
Doc. NO. V049-1-020
P. 13 OF 13



PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-021 PAGE 1 OF 7
REV.	DEO #	DATE	BY:	CHECK	Beam Splitter Chamber - Design of Flange Welds	
0	0136	12/6/95	RDC	WDS		
					BY: R. D. Ciatto	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
PURPOSE: Design partial penetration seal weld and external stitch weld between vessel flange and shell.						
METHOD: Hand calculation method programmed on the Quattro-Pro spreadsheet program.						
ASSUMPTIONS: The maximum discontinuity moments and forces are used for design by assuming the welded joint behaves as a cylinder/rigid wall junction.						
INPUTS: LIGO Project sketches and drawings.						
REFERENCES: 1. ASME Boiler & Pressure Vessel Code, Section VIII, Pressure Vessels, Div. 1. 2. Doc. No. V049-1-042, Bolted Flange Analysis for Tensile Forces. 3. Doc. No. V049-1-066, LIGO Vacuum Equip., Structural Design Criteria.						
CALCULATIONS: (SEE ATTACHED)						
CONCLUSIONS: See attached spreadsheet for acceptable welds for various size flanges.						
NOTES: Computer File: Flange.wb1						

EACH FLANGE IS CONNECTED TO THE CYLINDRICAL SHELL WITH 2 WELDS AS SHOWN BELOW



THESE WELDS RESIST DISCONTINUITY FORCES BETWEEN THE CYLINDER AND THE FLANGE.

FOR VACUUM PRESSURE, THE FILLET WELD (STITCH) IS ASSUMED TO RESIST THE DISCONTINUITY MOMENT. FOR POSITIVE PRESSURE, THIS MOMENT IS ASSUMED TO BE RESISTED BY THE PARTIAL PEN WELD.


HOWEVER, FOR DESIGNING THE PARTIAL PENETRATION WELD, IT WILL BE ASSUMED THAT THIS WELD ALSO RESISTS THE DISCONTINUITY SHEAR FORCE DUE TO THE VACUUM AND THE POSITIVE PRESSURE.

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



PRESSURE DISTRIBUTION STRESSES FOR A CYLINDER AT A RIGID WALL.

(FLANGE IS ASSUMED TO ACT AS A RIGID WALL)



FOR EXTERNAL PRESSURE, P

SHEAR $V = .660 P \sqrt{rt}$

MOMENT $M = .257 P r t$

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS





BSC - 104 1/4 ID FLANGE

$$r = 52.125 + .25 = 52.375 \text{ IN}$$

$$t = .5$$

$$p = 14.7 \text{ FOR VACUUM}$$

$$V = .660 p \sqrt{r t} = .660 (14.7) (52.375 \times .5)^{1/2}$$

$$= 49.65 \text{ LB/IN}$$

$$M = .257 p r t = .257 (14.7) (52.375) (.5)$$

$$= 98.93 \text{ IN-LB/IN}$$

PEN. WELD SHEAR STRESS (NO TENSILE STRESS IN WELD DUE TO EXTERNAL PRESSURE)


$$f_v = \frac{V}{t_w r}$$

$$t_w r = .25$$

$$f_v = \frac{49.65}{.25} = 199 \text{ psi}$$

(ACROSS W/ SPREAD SHEET)

STITCH WELD (1/4 LEG, 2 IN LONG @ 6 IN) RESISTS MOMENT



$$F \times \frac{t}{2} = M$$

$$F = \frac{2 \times 98.93}{.5} = 396 \text{ LB/IN}$$

FORCE IN 1 IN OF WELD

$$F = 396 \times \frac{6}{2} = 1188 \text{ LB/IN}$$

STITCH WELD SHEAR STRESS

$$f_v = \frac{F}{.707 t_w s} = \frac{1188}{.707 (.25)}$$

$$= 6721 \text{ psi}$$

(ACROSS W/ SPREAD SHEET)



CONT.

FOR POS PRESSURE

LET

$$P = 10 \text{ PSI} *$$

$$V = 49.65 \times \frac{10}{14.7} = 33.79$$

$$M = 94.93 \times \frac{10}{14.7} = 67.30$$

LONG STRESS IN PEN WELD

$$t_{WP} = .25$$

$$f_a = \frac{P r}{2 t_{WP}} = \frac{10(57.375)}{2(.25)} = 1048 \text{ PSI}$$

WELD BENDING STRESS

$$f_b = \frac{6M}{t_{WP}^2} = \frac{6(67.30)}{.25^2} \leftarrow \text{CONSERVATIVE}$$

$$= 6461 \text{ PSI}$$

TOTAL AXIAL STRESS

$$f_t = f_a + f_b = 7509 \text{ PSI}$$

PAN. PEN WELD SHEAR STRESS

$$f_s = \frac{V}{t_{WP}} = \frac{33.79}{.25} = 135 \text{ PSI}$$

* FINISH POS PRESS = 2 PSI

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



ALLOWABLE WELD STRESSES

Fillet Welds - Allow Shear Stress

$$T_{all} = .55 S_{all}, \text{ See } \sqrt{10}(1), \text{ UW-13, 15}$$

$$S_{all} = 14.7 \text{ ksi} *$$

$$T_{all} = .55(14.7) = 8.1 \text{ ksi}$$

Butt Weld in Shear

$$T_{all} = .70 S_{all}$$

$$= .70(14.7)$$

$$= 10.3 \text{ ksi}$$

* CONSERVATIVE SINCE DUAL GRADE
MATERIAL 304/304L IS USED

FLANGE TO SHELL WELD

Flange I. D., (in) =	104.25	104.25	84.25	72.25	60.25	48.25	44.25	30.25
Shell Thickness, tsh, (in) =	0.5	0.25	0.25	0.25	0.25	0.25	0.25	0.25
Shell Mean Radius, r (in) =	52.375	52.25	42.25	36.25	30.25	24.25	22.25	15.25
Partial Pen Weld Thickness, twp (in) =	0.25	0.125	0.125	0.125	0.125	0.125	0.125	0.125
Stitch Weld Fillet Weld Thickness, tws (in) =	0.25	0.1875	0.125	0.125	0.125	0.125	0.125	0.125
Stitch Weld Spacing, s (in) =	6	4	4	4	6	6	6	6
Stitch Weld Length, l (in) =	2	2	2	2	2	2	2	2
<i>Vacuum</i>								
Pressure, p (psi) =	14.7	14.7	14.7	14.7	14.7	14.7	14.7	14.7
Shear, V, (lb/in) = $.660 \cdot p \cdot (r \cdot tsh)^{.5}$	49.65	35.07	31.53	29.21	26.68	23.89	22.88	18.94
Moment, M (in-lb/in) = $.257 \cdot p \cdot r \cdot tsh$	98.93	49.35	39.90	34.24	28.57	22.90	21.01	14.40
Pen Weld Shear Stress, fv (psi) = V/twp	199	281	252	234	213	191	183	152
Stitch Weld Force per in from Moment, f = $M/(tsh/2)$ =	396	395	319	274	229	183	168	115
Stitch Weld Shear Stress, fv (psi) = $f \cdot (s / (.707 \cdot l \cdot tws))$ =	6717	5956	7224	6199	7759	6220	5707	3911
<i>Positive Pressure in Vessel</i>								
Pressure, ppos (psi) =	3	3	3	3	3	3	3	3
Shear, Vp, (lb/in) = $.660 \cdot ppos \cdot (r \cdot tsh)^{.5}$	10	7	6	6	5	5	5	4
Moment, Mp (in-lb/in) = $.257 \cdot ppos \cdot r \cdot tsh$	20	10	8	7	6	5	4	3
Pen Weld Long. Pressure Stress, fl (psi) = $ppos \cdot r / (2 \cdot twp)$	314	627	507	435	363	291	267	183
Pen Weld Bending Stress, fb (psi) = $6 \cdot Mp / twp^2$	1938	3867	3127	2683	2239	1795	1647	1129
Pen Weld Total Axial stress, ft (psi) = fl+fb	2253	4494	3634	3118	2602	2086	1914	1312
Pen Weld Shear Stress, fv (psi) = Vp/twp	41	57	51	48	44	39	37	31

Revision 0
 Doc. No. V049-1-021
 Page 7 of 7

EFFECT OF FLANGE TENSION DUE TO
COMPONENT INTERFACE LOAD

REF. CALL VO49-1-042 PP 26 & 27

THE MAXIMUM AXIAL STRESS DUE TO
COMPONENT INTERFACE LOADS IS 2900 PSI
IN A 1/8 IN PAR PER WELD (20IM FL). THE
MAXIMUM DESIGN POSITIVE PRESSURE IS
NOW 2 PSI. THE MAX DISCONTINUITY
AXIAL STRESS IS IN THE 104 IN FLANGE
(4494 FOR 3 PSI). CONSERVATIVELY
ADDING THESE WORST CASE AXIAL
WELD STRESSES GIVES

$$\begin{aligned} f_a &= 2900 + \frac{2}{3} (4494) \\ &= 2900 + 3011 \\ &= 5911 \text{ psi} \quad OR \end{aligned}$$

REV 0
Doc. No. VO49-1-021
P. 7A 007



PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-022 PAGE 1 OF 16
REV.	DEO #	DATE	BY:	CHECK	Beam Splitter Chamber, FE Analysis of Lower Section	
0	0128	12/6/95	RDC			
		4/18/96		P.W.Y.		
					BY: R.D. C. 12/22/95	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
PURPOSE: To evaluate the lower section of the beam splitter chamber for vacuum pressure.						
METHOD: A finite element analysis of the lower section shell, head and nozzles is performed.						
ASSUMPTIONS:						
INPUTS: LIGO project sketches and drawings. Shell thickness = .5 in. 60 in. nozzle thickness = .5 in. Head thickness = .375 in.						
REFERENCES: 1. ASME Boiler & Pressure Vessel Code, Section VIII, Div. 1 2. IMAGES 3D, Version 3.0, R.L. Cloud & Associates 3. Doc. No. V049-1-066, LIGO VACUUM EQUIP. SECTORIAL DESIGN CRITERIA						
CALCULATIONS: (SEE ATTACHED)						
CONCLUSIONS: Stresses are within the limits of the ASME Code, Section VIII, Div. 1.						
NOTES: Computer files are BMSPLI10, BMSPLI11, and BMSPLI12.						

BSC

END CAP LOAD ON 60 IN NOZZLES

THERE ARE 32 NOZZLES AROUND THE 60 IN FLANGE. THE AREA FOR THE MODEL IS $\frac{1}{2}$ OF THE CIRCLE

$$A = \frac{\pi r^2}{2}$$

$$r = 30 \text{ IN}$$

$$A = 1414 \text{ IN}^2$$

THE TOTAL VACUUM LOAD IS

$$F = pA$$

$$p = 14.7 \text{ PSI}$$

$$F = 14.7(1414) = 20,782 \text{ LB}$$

FOR EACH FLANGE NOZZLE AT THIS NOZZLE INNER SURFACE, EXCEPT THE FLANGE NOZZLES THE FORCE IS

$$F_i = \frac{20782}{32} = 649.4 \text{ LB}$$

FOR COANER NOZZLES

$$F_i = \frac{649.4}{2} = 324.7 \text{ LB}$$



BSC FE ANALYSIS OF LOWER SHELL

FILE NAME: BMSPL12 - FINAL MODEL

LOAD CASES

1. VACUUM PRESS = 147 PSI
END CAP LOAD ON BOTH GO IN NOZZLE
2. SAME AS 1 BUT GO IN NOZZLE ON Y AXIS HAS NO END CAP LOAD (SIMULATED BELLWIS)
3. SAME AS 1 BUT SUPPORT LEG REACTIONS ARE APPLIED TO SHELL AT 12 NODES AT WELD PAD

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



LOAD CASE 3

SUPPORT LEG REACTION ON SHILL


LOCAL MEMBER FORCES (FROM ASCSOAPB FILE)

MEMBER	NODE	F _y (VERT)	F _z (TANGENTIAL)	F _x (RADIAL)
2	3	-3019	-14900	442 LB
→ 4	6	-18760	125	-15620
6	9	-3281	14900	694
8	12	12460	-125	14490

THE BOUNDARY LOADS ARE AT MEMBER 4
 WHERE THE VERTICAL LOAD IS 18760 AND
 THE RADIAL LOAD IS 15620 LB. MEMBERS
 ARE NOT BRIDGED SO THE SHEAR IS
 UNIFORM.

* DO PRINTED OUTPUT, FOLLOW FROM SHEET

FOR THE ANALYSIS MODEL, THE RADIAL
 LOAD WILL BE APPLIED OUTWARDS AND
 THE VERTICAL LOAD WILL BE DOWNWARDS
 THE GLOBAL LOAD COMPONENTS IN THE
 ANALYSIS MODEL ARE



$$F_y = 18760 \text{ LB}$$

$$F_z = .707 (15620) = 11045 \text{ LB}$$

$$F_x = F_z = 11045 \text{ LB}$$

$\theta = 45^\circ =$ ANGULAR
 LOCATION OF PAD FROM
 Z-AXIS

APPLY LOADS TO THE FOLLOWING NODES

131
 134
 178
 179
 273
 275
 278 \Rightarrow 12 NODES
 279
 751
 1028
 1021
 1035
 1171
 1172

NODAL LOADS

$$F_{Y0} = \frac{F_Y}{12} = \frac{18760}{12} = 1563 \text{ LB}$$

$$F_{Y1} = \frac{F_Y}{12} = \frac{11045}{12} = 920.4 \text{ LB}$$

$$F_{Z0} = \frac{F_Z}{12} = 920.4 \text{ LB}$$

NOTE: THE FINAL SUPPORT LEG FORCES ARE GIVEN ON P. 32 OF CALL 024. THE RESULTANT FINAL LOAD IS $F = 27.2 \text{ K}$. FOR THE FORCES ANALYZED IN THE CALL THE RESULTANT IS SLIGHTLY LOWER

$$F = (18.76^2 + 11.0^2 + 11.0^2)^{\frac{1}{2}} \\ = 24.4 \text{ K}$$

SINCE THE SHELL STRESS PLOT ON P. 15 SHOWS THAT THE MAX STRESS INTENSITY IS ONLY ABOUT $E_s \sigma_{R31}$ AT THE LEG ATTACHMENT, THE SHELL STRESSES MEET THE CRITERIA FOR THE FINAL LOADS.



LOAD CASE 1 RESULTS SUMMARY FOR 3 CASES

BEAM SPL 10

- NO STIFFENERS AT G-NOZZLES
- RING STIFFENER ABOVE PORTS
- ANGLE STIFFENER BELOW "

MAX SE = 15.5 KSI AT MIDDLE NOZZLE

" " = 14 KSI AT UPPER NOZZLES
(HIGH LOCAL AT RING STIFFENER)

MAX SE = 23.8 KSI AT BOTTOM OF
60 IN PORTS

STRESS IN LOWER NOZZLES = 2.7 KSI
MAX RADIAL DISP = .15" @ 60 IN

BEAM SPL 11

- SAME AS BEAM SPL 10 BUT NO STIFFENERS
BELOW 60" PORT

MAX RADIAL DISP = .19 IN @ 60 IN

AT MIDDLE NOZZLE, MAX SE = 21 KSI

AT UPPER NOZZLES, MAX SE = 17.1 KSI
AT RING STIFFENER.

AT BOTTOM OF 60 IN PORTS, SE = 28.4 KSI

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



LOAD CASE 1 RESULTS CONT.

BMLPLI12 (FINAL MODEL)

- STIFFENERS BETWEEN G NOZ*
- RING STIFFENERS ABOVE PORTS (4" x 3/8")
- NO STIFFENERS BELOW PORTS

AT G-NOZZ

MAX SE = 22.9 ksi AT STIFF. TOP W/ 60 IN PORT

MAX Δ = .11" (RADIAL)

AT UPPER NOZZLES

MAX SE = 14 ksi AT TOP OF 60" PORT

AT BOTTOM OF 60" PORTS

MAX SE = 27.9 ksi (WALL THICK)

NOTE: ALL SE'S ARE AT SURFACES

*STIFFENER IS 2" x 3/8"

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



THE FOLLOWING PLOTS ARE FROM
THE MODEL WITH

FILENAME: BMSPLI2

MAX STRESS INTENSITY

$SI_{MAX} = 23.5 \text{ ksi}$ AT A-TYPE JOINT
60 IN NOZZLES

$\leq 1.5 S = 24.3 \text{ ksi @ } 400^\circ \text{ F}$



FOR 304/304L
DUAL CERTIFIED MATERIAL

THIS MAX STRESS IS VER LOCAL


22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



IMAGES-3D
Version 3.0



MAX DEF AT MIDDLE
NOZZLE G
 $D_y = D_z = .106$
Radius $\Delta = (.106^2 + .106^2)^{1/2}$
= .15 IN
INWARD





Load Case
1

Displacement Contour Plot
DY

11/16/95
11:53:45

IMAGES-3D
Version 3.0






Revision 0
Doc. No. V049-1-022
Page 10 of 16

Load Case
1

Stress Contour Plot
Surf: Top
Stress Intensity

11/16/95
11:50:33

IMAGES-3D
Version 3.0




Revision 0
Doc. No. V049-1-022
Page 11 of 16

Load Case
2

Displacement Contour Plot
DY

11/16/95
12:2:0

IMAGES-3D
Version 3.0




Revision 0
Doc. No. V049-1-022
Page 12 of 16

Load Case
2

Displacement Contour Plot
DZ

11/16/95
11:57:54



IMAGES-3D
Version 3.0



SI = 22.7 KSI AT
STIFF/NOZ JOINT



← VALIDATED 027715




Revision 0
Doc. No. V049-1-022
Page 13 of 16

Load Case
2

Stress Contour Plot
Surf: Top
Stress Intensity

11/16/95
13: 1:10

IMAGES-3D
Version 3.0



MAX INWARD DEF
AT MIDDLE HOLE
 $D_1 = D_2 \approx .0914 \text{ IN}$
 RADIAL $\Delta = (.014^2 + .0914^2)^{1/2}$
 = .129 IN






Revision 0
Doc. No. V049-1-022
Page 14 of 16

Load Case
3

Displacement Contour Plot
DZ

11/16/95
13: 7:39

IMAGES-3D
Version 3.0



Revision 0
Doc. No. V049-1-022
Page 15 of 16

Load Case
3

Stress Contour Plot
Surf: Top
Stress Intensity

11/16/95
13:12:30

CONFIRMATION OF NOZZLE G

NOZ G URC 107 ANALYSIS FOR
RADIAL FACE

$$F = 738.9 \text{ LB}$$

STRESS

$$\sigma = -2646 \text{ psi}$$

THE "COMPRESS" PRESSURE VESSEL
PROGRAM SHOWS THAT NO REINFORCEMENT
IS NEEDED.

SHELL THICKNESS = .5 IN


NOZZLE THICKNESS = .125 IN

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-023 PAGE 1 OF 19
REV.	DEO #	DATE	BY:	CHECK	Beam Splitter Chamber - Design of 60 in. Access Covers	
0	0024	12/6/51	RDC	P.W.Y.		
					BY: R. D. CLARKE	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO:	
PURPOSE: To design the cover and nozzles for the 60 in. port in accordance with Section VIII, Division 1 of the ASME Code.						
METHOD: Equations for thickness and reinforcement requirements of the ASME Code, Section VIII, Division 1, are evaluated using the COMPRESS computer program, Version 5.31.						
ASSUMPTIONS:						
INPUTS: Vacuum pressure = 14.7 psi Design temperature = 400 ⁰ F						
REFERENCES: 1. ASME Boiler & Pressure Vessel Code, Section VIII, Pressure Vessels, Division 1. .2. COMPRESS 5.31, Computer Aided Pressure Vessel Design, Codeware Computer Systems, Inc. 3. Doc. No. V049-1-046, LIGO VACUUM EQUIP., STRUCTURAL DESIGN CRITERIA						
CALCULATIONS: (SEE ATTACHED)						
CONCLUSIONS: The requirements of the ASME Code, Section VIII. Division 1, are met for the cover and nozzles for the 60 in. port.						
NOTES:						

NOZZLE LOCATIONS IN COMPRESS



N1 @ CENTER


N2 $\theta = 42.90$

$$r = (10.625^2 + 9.875^2)^{\frac{1}{2}}$$

$$= 14.51$$

60 IN
ACCESS
COVER

$$L = 14.53 - \frac{r}{2}$$



$$y = (60.75^2 - 14.51^2)^{\frac{1}{2}}$$

$$= 58.48 \text{ IN}$$

$$L = 60.75 - 58.48$$

$$= 2.27$$

$$L = 14.53 - 2.27$$

$$= 12.26$$

N3 $\theta = 20$

$$r = 15.75$$

$$y = (60.75^2 - 15.75^2)^{\frac{1}{2}}$$

$$= 58.15$$

$$L = 60.75 - 58.15 = 2.60$$

$$L = 14.53 - 2.60 = 11.93$$

DUE TO DIMINISHING REINFORCEMENT, NOZZLES LOCATIONS WERE MOVED AS SHOWN ON THE REVISION SHEET



60 IN PORT

60 IN PORT

ED = 7.5 IN

WALL THICKNESS = .25 IN


FILLET WRIS = .25

PARTIAL PEN GRADUATION USED = .1475

PERINE. ROD = .73 IN²

" ADDITIONAL .63 IN² CLR W/C PAD

LOCATE NOTCHES AS FOLLOWS



RADIAL PRESSURE LOAD FOR UAC
107 UAC

$$F_R = \frac{\pi}{4} (7.5)^2 (19.7) = 649.4 \text{ LB}$$

MAX STRESS AT O/D OF NOZZLE

$$f = 2802 \text{ PSI STRESS}$$

UAC 107 UAC



BSC 60 in PortASME Section VIII Division 1, 1992 Edition, A93 Addenda

Component: F&D head
 Material specification: SA 240 304L HIGH
 External design pressure: $P_e = 14.7$ psi @ 400 deg F
 Corrosion allowance: Inner C = 0 Outer = 0 in

PWHT is not performed

Radiography: Category A joints - Spot UW-11(b) type 1
 Head to shell seam - Spot UW-11(b) type 1

Estimated weight: new = 272.9 corr = 272.9 lb
 capacity: new = 88.89 corr = 88.89 US ga

ID = 60.25 crown L = 60.25 knuckle r = 3.75 t = .25 in (min)

Straight flange = 1 forming allowance = 0 in

MAP: (New & at 0 deg F) Appendix 1-4(d) Eq 3

$$P = 2 * S * E * t / (L * M + 0.2 * t) - P_s$$

$$= 2 * 16700 * 0.85 * 0.25 / (60.25 * 1.7521 + 0.2 * 0.25) - 0$$

$$= 67.20225 \text{ psi}$$

MAWP: (Corroded & at 0 deg F) Appendix 1-4(d) Eq 3

$$P = 2 * S * E * t / (L * M + 0.2 * t) - P_s$$

$$= 2 * 16700 * 0.85 * 0.25 / (60.25 * 1.7521 + 0.2 * 0.25) - 0$$

$$= 67.20225 \text{ psi}$$

External Pressure: (Corroded & at 400 deg F) UG-33(c)

$$A = .125 / (R_o / t)$$

$$= .125 / (60.5 / 0.18787)$$

$$= 0.000388$$

From table HA-3: B = 4757.7

$$P_a = B / (R_o / t)$$

$$= 4757.7 / (60.5 / 0.18787)$$

$$= 14.774 \text{ psi}$$

Check the external pressure per UG-33(a)(1)

$$t = 1.67 * P_a * L_o * M / (2 * S * E + 1.67 * P_a * (M - 0.2))$$

$$= 1.67 * 14.774 * 60.5 * 1.7521 / (2 * 14700 * 1 + 1.67 * 14.774 * (1.7521 - 0.2))$$

$$= 0.088842 \text{ in}$$

Design thickness for external pressure $P_a = 14.774$ psi:

REV 0

Doc No V049-1-023

Page 4 of 19

BSC 60 in Port

$$\begin{aligned}
 &= t + \text{Corrosion} + fa \\
 &= 0.18787 + 0 + 0 \\
 &= 0.18787 \text{ in}
 \end{aligned}$$

Maximum Allowable External Pressure: (Corroded @ 400 deg F)

$$\begin{aligned}
 A &= .125/(Ro/t) \\
 &= .125/(60.5/0.25) \\
 &= 0.000517
 \end{aligned}$$

From table HA-3: B = 5004.1

$$\begin{aligned}
 Pa &= B/(Ro/t) \\
 &= 5004.1/(60.5/0.25) \\
 &= 20.6781 \text{ psi}
 \end{aligned}$$

Check the Maximum External Pressure: UG-33(a)(1) & App. 1-4(d)

$$\begin{aligned}
 Pc &= 2*S*E*t/((M*Lo - t*(M-0.2))*1.67) \\
 &= 2*14700*1*0.25/((1.7521*60.5 - 0.25*(1.7521-0.2))*1.67) \\
 &= 41.67247 \text{ psi}
 \end{aligned}$$

The maximum allowable external pressure is 20.6781 psi.

REV 0

Doc No. V005-1-023

Page 5 of 15


Center Nozzle n1

Opening n1 Reinforcement Calculations Per UG-37

Located on: BSC 60 in Port
 Local vessel thickness: .25 in
 Liquid static head included: 0 psi
 Flange description: 8 inch 75# SO A240304L
 ANSI B16.47 flange rating MAP: 115 psi
 ANSI B16.47 flange rating MAWP: 115 psi

Nozzle material specification: SA 240 304L HIGH

Nozzle orientation: 0 degrees
 End of nozzle to datum line: 14.53 in
 Nozzle calculated as hillside: no
 Projection outside vessel Lpr: 2.996 in



corrosion allow = 0 in
 noz thick new $t_n = .25$ in
 nozzle id. new $d = 7.5$ in
 fillet weld $tw_1 = .25$ in
 groove weld $tw_2 = .1875$ in

To head center $R = 0$ in

Reinforcement Calculations For Nozzle MAWP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.5$ in
 Normal to the vessel wall outside $2.5*(t_n - C_n) + t_c = .625$ in
 Normal to the vessel wall inside $2.5*(t_n - C_n - C) = .625$ in

Nozzle required thickness

$$t_{rn} = \frac{P \cdot R_n}{S_n \cdot E - 0.6 \cdot P}$$

$$= \frac{0 \cdot 3.75}{16700 \cdot 1 - 0.6 \cdot 0}$$

$$= 0 \text{ in}$$

Required thickness t_r from UG-37(a)(1)

$$t_r = \frac{P \cdot L \cdot M}{2 \cdot S \cdot E - 0.2 \cdot P}$$

$$= \frac{0 \cdot 60.25 \cdot 1}{2 \cdot 16700 \cdot 1 - 0.2 \cdot 0}$$

$$= 0 \text{ in}$$

Area required

Allowable stresses: $S_n = 16700$, $S_v = 16700$, psi

$fr_1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr_1 = 1$

Rev C

Doc. No. V249-1-015

Page 6

Center Nozzle n1

fr2 = lesser of 1 or Sn/Sv so fr2 = 1

$$\begin{aligned} A &= d \cdot t_r \cdot F + 2 \cdot t_n \cdot t_r \cdot F \cdot (1 - fr1) \\ &= 7.5 \cdot 0 \cdot 1 + 2 \cdot 0.25 \cdot 0 \cdot 1 \cdot (1 - 1) \\ &= 0 \text{ in}^2 \end{aligned}$$

Area available

A1 = larger of the following = 1.875 in²

$$\begin{aligned} &= d \cdot (E1 \cdot t - F \cdot t_r) - 2 \cdot t_n \cdot (E1 \cdot t - F \cdot t_r) \cdot (1 - fr1) \\ &= 7.5 \cdot (1 \cdot 0.25 - 1 \cdot 0) - 2 \cdot 0.25 \cdot (1 \cdot 0.25 - 1 \cdot 0) \cdot (1 - 1) \\ &= 1.875 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 \cdot (t + t_n) \cdot (E1 \cdot t - F \cdot t_r) - 2 \cdot t_n \cdot (E1 \cdot t - F \cdot t_r) \cdot (1 - fr1) \\ &= 2 \cdot (0.25 + 0.25) \cdot (1 \cdot 0.25 - 1 \cdot 0) - 2 \cdot 0.25 \cdot (1 \cdot 0.25 - 1 \cdot 0) \cdot (1 - 1) \\ &= .25 \text{ in}^2 \end{aligned}$$

A2 = smaller of the following = 0.313 in²

$$\begin{aligned} &= 5 \cdot (t_n - t_{rn}) \cdot fr2 \cdot t \\ &= 5 \cdot (0.25 - 0) \cdot 1 \cdot 0.25 \\ &= .313 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5 \cdot (t_n - t_{rn}) \cdot fr2 \cdot t_n \\ &= 5 \cdot (0.25 - 0) \cdot 1 \cdot 0.25 \\ &= .313 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A41 &= Leg^2 \cdot fr2 \\ &= 0.25^2 \cdot 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 1.875 + 0.313 + 0.063 \\ &= 2.251 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAWP = 0 at 0 Deg F

Check the welds - From UW-16(d):

$$\begin{aligned} t_{min} &= \text{lesser of } 0.75 \text{ or } t_n \text{ or } t, t_{min} = 0.25 \text{ in} \\ t1 \text{ or } t2(\text{min}) &= \text{lesser of } 0.25 \text{ or } 0.7 \cdot t_{min}, t1(\text{min}) = 0.175 \text{ in} \\ t1(\text{actual}) &= 0.7 \cdot Leg = 0.7 \cdot 0.25 = 0.175 \text{ in} \\ t2(\text{actual}) &= 0.1875 \text{ in} \\ t1 + t2 &= 0.3625 \geq 1.25 \cdot t_{min} \end{aligned}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0 in (E = 1)
Wall thickness per UG-45(b)(1):	tr2 = 0 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in

Rev 0
Doc. No. V049-1-023
Page 7 of 15

Center Nozzle n1

The greater of tr2 or tr3: $tr5 = 0.0625$ in
 The lesser of tr4 or tr5: $tr6 = 0.0625$ in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Available nozzle wall thickness new, $tn = 0.25$ in

The nozzle neck thickness is adequate for MAWP.

Allowable stresses in joints UG-45(c) and UW-15(c)

Groove weld in tension = $0.74 * 16700 = 12358$ psi
 Nozzle wall in shear = $0.7 * 16700 = 11690$ psi
 Inner fillet weld in shear = $0.49 * 16700 = 8183$ psi

Strength of welded joints:

(1) Inner fillet weld in shear
 $(\pi/2) * \text{Nozzle O.D.} * \text{Leg} * Si = 1.57 * 8 * 0.25 * 8183 = 25694.62$ lbf

(3) Nozzle wall in shear
 $(\pi/2) * \text{Mean nozzle dia.} * tn * Sn = 1.57 * 7.75 * 0.25 * 11690 = 35559.52$ lbf

(4) Groove weld in tension
 $(\pi/2) * \text{Nozzle O.D.} * tw * Sg = 1.57 * 8 * 0.1875 * 12358 = 29103.09$ lbf

Loading on welds per UG-41(b)(1)

$W = (A - (d - 2 * tn) * (E1 * t - F * tr)) * Sv$
 $= (0 - (7.5 - 2 * 0.25) * (1 * 0.25 - 1 * 0)) * 16700$
 $= -29225$ lbf

$W1-1 = (A2 + A5 + A41 + A42) * Sv$
 $= (0.313 + 0 + 0.063 + 0) * 16700$
 $= 6279.2$ lbf

$W2-2 = (A2 + A3 + A41 + A43 + 2 * tn * t * fr1) * Sv$
 $= (0.313 + 0 + 0.063 + 0 + 2 * 0.25 * 0.25 * 1) * 16700$
 $= 8366.7$ lbf

Load for path 1-1 lesser of W or W1-1 = -29225 lbf
 Path 1-1 Thru (1) & (3) = $25694.62 + 35559.52 = 61254.14$ lbf
 Path 1-1 is stronger than W so it is acceptable per UG-41(b)(2).

Load for path 2-2 lesser of W or W2-2 = -29225 lbf
 Path 2-2 Thru (1), (4) = $25694.62 + 29103.09 = 54797.71$ lbf
 Path 2-2 is stronger than W so it is acceptable per UG-41(b)(2).

Reinforcement Calculations for External PressureLimits of reinforcement UG-40

Parallel to the vessel wall $d = 7.5$ in

REV 0

Doc. No. V049-1-023

Page 8 of 15

Center Nozzle n1

Normal to the vessel wall outside $2.5*(t_n - C_n) + t_c = .625$ in
 Normal to the vessel wall inside $2.5*(t_n - C_n - C) = .625$ in

Nozzle required thickness

$$\begin{aligned} L/Do &= 2.996/8 = .3745 & Do/t &= 8/0.0184 = 434.7826 \\ \text{From table G:} & & A &= 0.000415 \\ \text{From table HA-3:} & & B &= 4814.3 \end{aligned}$$

$$\begin{aligned} Pa &= 4*B/(3*Do/t) \\ &= 4*4814.3/(3*8/0.0184) \\ &= 14.7639 \text{ psi} \end{aligned}$$

Nozzle required thickness $t_{rn} = .0184$ in

Required thickness t_r from UG-37(d)(1) = .1879 in

Area required

Allowable stresses: $S_n = 14700$, $S_v = 14700$, psi

$fr_1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr_1 = 1$

$fr_2 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr_2 = 1$

$$\begin{aligned} A &= 0.5*(d*t_r*F + 2*t_n*t_r*F*(1 - fr_1)) \\ &= 0.5*(7.5*0.1879*1 + 2*0.25*0.1879*1*(1 - 1)) \\ &= .7046 \text{ in}^2 \end{aligned}$$

Area available

$A_1 = \text{larger of the following} = .466 \text{ in}^2$

$$\begin{aligned} &= d*(E_1*t - F*t_r) - 2*t_n*(E_1*t - F*t_r)*(1 - fr_1) \\ &= 7.5*(1*0.25 - 1*0.1879) - 2*0.25*(1*0.25 - 1*0.1879)*(1 - 1) \\ &= .466 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2*(t + t_n)*(E_1*t - F*t_r) - 2*t_n*(E_1*t - F*t_r)*(1 - fr_1) \\ &= 2*(0.25 + 0.25)*(1*0.25 - 1*0.1879) - 2*0.25*(1*0.25 - 1*0.1879)*(1 - 1) \\ &= .062 \text{ in}^2 \end{aligned}$$

$A_2 = \text{smaller of the following} = 0.289 \text{ in}^2$

$$\begin{aligned} &= 5*(t_n - t_{rn})*fr_2*t \\ &= 5*(0.25 - 0.0184)*1*0.25 \\ &= .289 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5*(t_n - t_{rn})*fr_2*t_n \\ &= 5*(0.25 - 0.0184)*1*0.25 \\ &= .289 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A_{41} &= Leg^2*fr_2 \\ &= 0.25^2*1 = .063 \text{ in}^2 \end{aligned}$$

REV 0

1049-1-023

Center Nozzle n1

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.466 + 0.289 + 0.063 \\ &= .818 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for Pe = 14.7 at 400 Deg F

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.0184 in (E = 1)
Wall thickness per UG-45(b)(2):	tr2 = 0.0528 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.0625 in
The lesser of tr4 or tr5:	tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for Pe.

REV 0

Doc. No: V049-1-023

Page 10 of 19

Center Nozzle n1**Applied Loads**

Radial load	$P_r = 649.4 \text{ lbf}$
Circumferential moment	$M_1 = 0 \text{ lbf-ft}$
Circumferential shear	$V_2 = 0 \text{ lbf}$
Longitudinal moment	$M_2 = 0 \text{ lbf-ft}$
Longitudinal shear	$V_1 = 0 \text{ lbf}$
Torsion moment	$M_t = 0 \text{ lbf-ft}$
Internal pressure	$P = 0 \text{ psi}$

Stresses at the nozzle OD per WRC bulletin 107 (psi)

$$\text{Mean dish radius } R_m = 60.375 \text{ in}$$

$$U = r_o / \text{Sqr}(R_m * t) = 1.03$$

$$\text{Stress concentration factor } K_n \text{ (tension)} = 1$$

$$\text{Stress concentration factor } K_b \text{ (bending)} = 1$$

Pressure stress intensity factor, Farr equation 11.7

$$I = 1 + (r/x)^2$$

$$= 1 + (3.75/4.25)^2$$

$$= 1.779$$

$$\text{Local pressure stress} = I * P * R_m / 2 * t = 0 \text{ psi}$$

$$\text{Maximum combined stress} = -2802 \text{ psi}$$

$$\text{Allowable combined stress} = +3 * S = + - 50100 \text{ psi}$$

The maximum combined stress is within allowable limits.

$$\text{Maximum primary membrane stress} = -670 \text{ psi}$$

$$\text{Allowable primary membrane stress} = +1.5 * S = + - 25050 \text{ psi}$$

The maximum primary membrane stress is within allowable limits.

REV D

Doc. No. V049-1-023

Center Nozzle n1

From Fig.	Value read	Au	A1	Bu	B1	Cu	C1	Du	D1
SR-2*	0.0645	-670	-670	-670	-670	-670	-670	-670	-670
SR-2	0.0342	-2132	2132	-2132	2132	-2132	2132	-2132	2132
SR-3*	0.0750								
SR-3	0.0711								
SR-3*	0.0750								
SR-3	0.0711								
pressure stress*									
Total Ox stress Primary membrane Ox stress*		-2802	1462	-2802	1462	-2802	1462	-2802	1462
		-670	-670	-670	-670	-670	-670	-670	-670
SR-2*	0.0200	-208	-208	-208	-208	-208	-208	-208	-208
SR-2	0.0103	-642	642	-642	642	-642	642	-642	642
SR-3*	0.0226								
SR-3	0.0214								
SR-3*	0.0226								
SR-3	0.0214								
pressure stress*									
Total Oy stress Primary membrane Oy stress*		-850	434	-850	434	-850	434	-850	434
		-208	-208	-208	-208	-208	-208	-208	-208
torsion moment Mt Shear from V1 Shear from V2									
Total Shear stress									
Combined stress		-2802	1462	-2802	1462	-2802	1462	-2802	1462

Rev: 0

Doc. No V048-1-023


Nozzle n5

Opening n5 Reinforcement Calculations Per UG-37

Located on: BSC 60 in Port
 Local vessel thickness: .25 in
 Liquid static head included: 0 psi
 Flange description: 8 inch 75# WN A240304L
 ANSI B16.47 flange rating MAP: 115 psi
 ANSI B16.47 flange rating MAWP: 115 psi

Nozzle material specification: SA 240 304L HIGH

Nozzle orientation: 330 degrees
 End of nozzle to datum line: 13.76 in
 Nozzle calculated as hillside: no
 Projection outside vessel Lpr: 4.173 in



corrosion allow = 0 in
 noz thick new tn = .25 in
 nozzle id. new d = 7.5 in
 fillet weld tw1 = .25 in
 groove weld tw2 = .1875 in

To head center R = 15.75 in

Reinforcement Calculations For Nozzle MAWP

Limits of reinforcement UG-40

Parallel to the vessel wall d = 7.5 in
 Normal to the vessel wall outside 2.5*(tn-Cn) + te = .625 in
 Normal to the vessel wall inside 2.5*(tn-Cn-C) = .625 in

Nozzle required thickness

$$trn = P \cdot Rn / (Sn \cdot E - 0.6 \cdot P)$$

$$= 0 \cdot 3.75 / (16700 \cdot 1 - 0.6 \cdot 0)$$

$$= 0 \text{ in}$$

Required thickness tr from UG-37(a)(1)

$$tr = P \cdot L \cdot M / (2 \cdot S \cdot E - 0.2 \cdot P)$$

$$= 0 \cdot 60.25 \cdot 1 / (2 \cdot 16700 \cdot 1 - 0.2 \cdot 0)$$

$$= 0 \text{ in}$$

Area required

Allowable stresses: Sn = 16700, Sv = 16700, psi

fr1 = lesser of 1 or Sn/Sv so fr1 = 1

REV 0

Doc No 1049-1-023

Nozzle n5

$$fr2 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr2 = 1$$

$$\begin{aligned} A &= d*tr*F + 2*tn*tr*F*(1 - fr1) \\ &= 7.5*0*1 + 2*0.25*0*1*(1 - 1) \\ &= 0 \text{ in}^2 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} = 1.875 \text{ in}^2$$

$$\begin{aligned} &= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 7.5*(1*0.25-1*0) - 2*0.25*(1*0.25-1*0)*(1-1) \\ &= 1.875 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 2*(0.25+0.25)*(1*0.25-1*0) - 2*0.25*(1*0.25-1*0)*(1-1) \\ &= .25 \text{ in}^2 \end{aligned}$$

$$A2 = \text{smaller of the following} = 0.313 \text{ in}^2$$

$$\begin{aligned} &= 5*(tn - trn)*fr2*t \\ &= 5*(0.25 - 0)*1*0.25 \\ &= .313 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5*(tn - trn)*fr2*tn \\ &= 5*(0.25 - 0)*1*0.25 \\ &= .313 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A41 &= \text{Leg}^2*fr2 \\ &= 0.25^2*1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 1.875 + 0.313 + 0.063 \\ &= 2.251 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAWP = 0 at 0 Deg F

Check the welds - From UW-16(d):

$$\begin{aligned} t_{min} &= \text{lesser of } 0.75 \text{ or } t_n \text{ or } t, t_{min} = 0.25 \text{ in} \\ t1 \text{ or } t2(\text{min}) &= \text{lesser of } 0.25 \text{ or } 0.7*t_{min}, t1(\text{min}) = 0.175 \text{ in} \\ t1(\text{actual}) &= 0.7*\text{Leg} = 0.7*0.25 = 0.175 \text{ in} \\ t2(\text{actual}) &= 0.1875 \text{ in} \\ t1 + t2 &= 0.3625 \geq 1.25*t_{min} \end{aligned}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0 in (E = 1)
Wall thickness per UG-45(b)(1):	tr2 = 0 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in

Rev 0

Doc. No. V249-1-023

Nozzle n5

The greater of tr2 or tr3: tr5 = 0.0625 in
 The lesser of tr4 or tr5: tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for MAWP.

Allowable stresses in joints UG-45(c) and UW-15(c)

Groove weld in tension = $0.74 \cdot 16700 = 12358$ psi
 Nozzle wall in shear = $0.7 \cdot 16700 = 11690$ psi
 Inner fillet weld in shear = $0.49 \cdot 16700 = 8183$ psi

Strength of welded joints:

(1) Inner fillet weld in shear
 $(\pi/2) \cdot \text{Nozzle O.D.} \cdot \text{Leg} \cdot S_i = 1.57 \cdot 8 \cdot 0.25 \cdot 8183 = 25694.62$ lbf

(3) Nozzle wall in shear
 $(\pi/2) \cdot \text{Mean nozzle dia.} \cdot t_n \cdot S_n = 1.57 \cdot 7.75 \cdot 0.25 \cdot 11690 = 35559.52$ lbf

(4) Groove weld in tension
 $(\pi/2) \cdot \text{Nozzle O.D.} \cdot t_w \cdot S_g = 1.57 \cdot 8 \cdot 0.1875 \cdot 12358 = 29103.09$ lbf

Loading on welds per UG-41(b)(1)

$W = (A - (d - 2 \cdot t_n) \cdot (E1 \cdot t - F \cdot t_r)) \cdot S_v$
 $= (0 - (7.5 - 2 \cdot 0.25) \cdot (1 \cdot 0.25 - 1 \cdot 0)) \cdot 16700$
 $= -29225$ lbf

$W1-1 = (A2 + A5 + A41 + A42) \cdot S_v$
 $= (0.313 + 0 + 0.063 + 0) \cdot 16700$
 $= 6279.2$ lbf

$W2-2 = (A2 + A3 + A41 + A43 + 2 \cdot t_n \cdot t \cdot f_r1) \cdot S_v$
 $= (0.313 + 0 + 0.063 + 0 + 2 \cdot 0.25 \cdot 0.25 \cdot 1) \cdot 16700$
 $= 8366.7$ lbf

Load for path 1-1 lesser of W or W1-1 = -29225 lbf
 Path 1-1 Thru (1) & (3) = $25694.62 + 35559.52 = 61254.14$ lbf
 Path 1-1 is stronger than W so it is acceptable per UG-41(b)(2).

Load for path 2-2 lesser of W or W2-2 = -29225 lbf
 Path 2-2 Thru (1), (4) = $25694.62 + 29103.09 = 54797.71$ lbf
 Path 2-2 is stronger than W so it is acceptable per UG-41(b)(2).

Reinforcement Calculations for External PressureLimits of reinforcement UG-40

Parallel to the vessel wall d = 7.5 in

Rev 0
 Doc No 1049-1-023
 Page 15 of 19

Nozzle n5Normal to the vessel wall outside $2.5*(tn-Cn) + tc = .625$ inNormal to the vessel wall inside $2.5*(tn-Cn-C) = .625$ inNozzle required thickness

$$L/Do = 4.173/8 = .5216 \quad Do/t = 8/0.02022 = 395.6479$$

$$\text{From table G:} \quad A = 0.000332$$

$$\text{From table HA-3:} \quad B = 4394.8$$

$$\begin{aligned} Pa &= 4*B/(3*Do/t) \\ &= 4*4394.8/(3*8/0.02022) \\ &= 14.8105 \text{ psi} \end{aligned}$$

Nozzle required thickness $trn = .02022$ inRequired thickness tr from UG-37(d)(1) = .1879 inArea requiredAllowable stresses: $S_n = 14700$, $S_v = 14700$, psi $fr1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr1 = 1$ $fr2 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr2 = 1$

$$\begin{aligned} A &= 0.5*(d*tr*F + 2*tn*tr*F*(1 - fr1)) \\ &= 0.5*(7.5*0.1879*1 + 2*0.25*0.1879*1*(1 - 1)) \\ &= .7046 \text{ in}^2 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} \quad = .466 \text{ in}^2$$

$$\begin{aligned} &= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 7.5*(1*0.25-1*0.1879) - 2*0.25*(1*0.25-1*0.1879)*(1-1) \\ &= .466 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 2*(0.25+0.25)*(1*0.25-1*0.1879) - 2*0.25*(1*0.25-1*0.1879)*(1-1) \\ &= .062 \text{ in}^2 \end{aligned}$$

$$A2 = \text{smaller of the following} \quad = 0.287 \text{ in}^2$$

$$\begin{aligned} &= 5*(tn - trn)*fr2*t \\ &= 5*(0.25 - 0.02022)*1*0.25 \\ &= .287 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5*(tn - trn)*fr2*tn \\ &= 5*(0.25 - 0.02022)*1*0.25 \\ &= .287 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A41 &= Leg^2*fr2 \\ &= 0.25^2*1 = .063 \text{ in}^2 \end{aligned}$$

Rev 0

Doc No V049-1-023

Page 16 of 19

Nozzle n5

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.466 + 0.287 + 0.063 \\ &= .816 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for $P_e = 14.7$ at 400 Deg F

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	$tr1 = 0.02022 \text{ in (E = 1)}$
Wall thickness per UG-45(b)(2):	$tr2 = 0.0528 \text{ in}$
Wall thickness per UG-16(b):	$tr3 = 0.0625 \text{ in}$
Std pipe wall per UG-45(b)(4):	$tr4 = 0.28175 \text{ in}$
The greater of $tr2$ or $tr3$:	$tr5 = 0.0625 \text{ in}$
The lesser of $tr4$ or $tr5$:	$tr6 = 0.0625 \text{ in}$

Req'd per UG-45 is the larger of $tr1$ or $tr6 = 0.0625 \text{ in}$

Available nozzle wall thickness new, $tn = 0.25 \text{ in}$

The nozzle neck thickness is adequate for P_e .

Rev 0

Doc No V049-1-023

Page 17 of 19

Nozzle n5Applied Loads

Radial load	$P_r = 649.4 \text{ lbf}$
Circumferential moment	$M_1 = 0 \text{ lbf-ft}$
Circumferential shear	$V_2 = 0 \text{ lbf}$
Longitudinal moment	$M_2 = 0 \text{ lbf-ft}$
Longitudinal shear	$V_1 = 0 \text{ lbf}$
Torsion moment	$M_t = 0 \text{ lbf-ft}$
Internal pressure	$P = 0 \text{ psi}$

Stresses at the nozzle OD per WRC bulletin 107 (psi)

$$\text{Mean dish radius } R_m = 60.375 \text{ in}$$

$$U = r_o / \text{Sqr}(R_m * t) = 1.03$$

$$\text{Stress concentration factor } K_n \text{ (tension)} = 1$$

$$\text{Stress concentration factor } K_b \text{ (bending)} = 1$$

Pressure stress intensity factor, Farr equation 11.7

$$I = 1 + (r/x)^2$$

$$= 1 + (3.75/4.25)^2$$

$$= 1.779$$

$$\text{Local pressure stress} = I * P * R_m / 2 * t = 0 \text{ psi}$$

$$\text{Maximum combined stress} = -2802 \text{ psi}$$

$$\text{Allowable combined stress} = +3 * S = \pm 50100 \text{ psi}$$

The maximum combined stress is within allowable limits.

$$\text{Maximum primary membrane stress} = -670 \text{ psi}$$

$$\text{Allowable primary membrane stress} = +1.5 * S = \pm 25050 \text{ psi}$$

The maximum primary membrane stress is within allowable limits.

REV 0

Doc No V049.1-023

Page 18 of 19

Nozzle n5

From Fig.	Value read	Au	A1	Bu	B1	Cu	C1	Du	D1
SR-2*	0.0645	-670	-670	-670	-670	-670	-670	-670	-670
SR-2	0.0342	-2132	2132	-2132	2132	-2132	2132	-2132	2132
SR-3*	0.0750								
SR-3	0.0711								
SR-3*	0.0750								
SR-3	0.0711								
pressure stress*									
Total Ox stress		-2802	1462	-2802	1462	-2802	1462	-2802	1462
Primary membrane Ox stress*		-670	-670	-670	-670	-670	-670	-670	-670
SR-2*	0.0200	-208	-208	-208	-208	-208	-208	-208	-208
SR-2	0.0103	-642	642	-642	642	-642	642	-642	642
SR-3*	0.0226								
SR-3	0.0214								
SR-3*	0.0226								
SR-3	0.0214								
pressure stress*									
Total Oy stress		-850	434	-850	434	-850	434	-850	434
Primary membrane Oy stress*		-208	-208	-208	-208	-208	-208	-208	-208
torsion moment Mt									
Shear from V1									
Shear from V2									
Total Shear stress									
Combined stress		-2802	1462	-2802	1462	-2802	1462	-2802	1462

REV 0
 V049-1-023
 Page 19 of 19

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-024 PAGE 1 OF 35
REV.	DEO #	DATE	BY:	CHECK	Beam Splitter Chamber - Design of Support Legs and Base Plates	
0	0128	12/29/91	RDC	AGB		
					BY: R.D. CIRRO	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	

PURPOSE: To design BSC support structure to meet requirements of AISC Code for unbalanced vacuum loads.

METHOD: A stiffness analysis of the frame is performed using the IMAGES program.

ASSUMPTIONS:

INPUTS: 1. LIGO project design sketches & drawings.
2. Vacuum pressure = 14.7 psi.
3. Seismic acceleration = .05625 g.
4. Forces from V049-1-032


REFERENCES: 1. AISC Code, Ninth Edition, Allowable Stress Design.
2. ASCE 7-88, Minimum Design Loads
3. IMAGES 3D, Version 3.0, R.L. Cloud & Associates
4. Calc. No. V049-1-032 "Component Interface Loads"
5. V049-1-024, LIGO VAC. EQUIP. STRUCT. DES. CRITERIA

CALCULATIONS: (SEE ATTACHED)







CONCLUSIONS: Support legs and other frame members meet the AISC Code.

NOTES: Computer file is BSCSUPP. *

Revision No. 0
Doc. No. V049-1-024
Page 1 of 35



*SITE SECTION ON
LATER SHEET FOR
WELD*




Revision No. 0
Doc. No. V049-1-024
Page 2 of 35

<p>CONVENTIONS AND ABBREVIATIONS</p> <p>ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED ARE IN INCHES.</p> <p>FRACCTIONS: 1/8, 1/4, 3/8, 1/2, 5/8, 3/4, 7/8, 1, 1 1/8, 1 1/4, 1 1/2, 1 3/4, 1 7/8, 2, 2 1/8, 2 1/4, 2 1/2, 2 3/4, 3, 3 1/8, 3 1/4, 3 1/2, 3 3/4, 4, 4 1/8, 4 1/4, 4 1/2, 4 3/4, 5, 5 1/8, 5 1/4, 5 1/2, 5 3/4, 6, 6 1/8, 6 1/4, 6 1/2, 6 3/4, 7, 7 1/8, 7 1/4, 7 1/2, 7 3/4, 8, 8 1/8, 8 1/4, 8 1/2, 8 3/4, 9, 9 1/8, 9 1/4, 9 1/2, 9 3/4, 10, 10 1/8, 10 1/4, 10 1/2, 10 3/4, 11, 11 1/8, 11 1/4, 11 1/2, 11 3/4, 12, 12 1/8, 12 1/4, 12 1/2, 12 3/4, 13, 13 1/8, 13 1/4, 13 1/2, 13 3/4, 14, 14 1/8, 14 1/4, 14 1/2, 14 3/4, 15, 15 1/8, 15 1/4, 15 1/2, 15 3/4, 16, 16 1/8, 16 1/4, 16 1/2, 16 3/4, 17, 17 1/8, 17 1/4, 17 1/2, 17 3/4, 18, 18 1/8, 18 1/4, 18 1/2, 18 3/4, 19, 19 1/8, 19 1/4, 19 1/2, 19 3/4, 20.</p> <p>UNLESS OTHERWISE SPECIFIED, DIMENSIONS ARE TO BE TAKEN TO THE CENTER OF HOLES AND TO THE CENTER OF GROOVES.</p> <p>ALL DIMENSIONS ARE TO BE TAKEN TO THE CENTER OF HOLES AND TO THE CENTER OF GROOVES.</p> <p>ALL DIMENSIONS ARE TO BE TAKEN TO THE CENTER OF HOLES AND TO THE CENTER OF GROOVES.</p>				<p>UNLESS OTHERWISE SPECIFIED</p> <p>ALL DIMENSIONS ARE TO BE TAKEN TO THE CENTER OF HOLES AND TO THE CENTER OF GROOVES.</p> <p>ALL DIMENSIONS ARE TO BE TAKEN TO THE CENTER OF HOLES AND TO THE CENTER OF GROOVES.</p> <p>ALL DIMENSIONS ARE TO BE TAKEN TO THE CENTER OF HOLES AND TO THE CENTER OF GROOVES.</p>				<p>PROCESS SYSTEMS INTERNATIONAL, INC.</p> <p>CHAMBER SUPPORT ASSEMBLY BSC LIGD VACUUM EQUIPMENT</p> <p>DATE: 08/19/83 REV: 0 DWG. NO: B049-4-023 SHEET: 2 OF 3</p>			
<p>DO NOT SCALE THIS DRAWING</p> <p>USED ON: _____</p> <p>NEXT ASSY: _____</p>				<p>PHILIPSBURY FOR DUBES</p> <p>DATE: _____</p> <p>SCALE: 1/2" = 1'-0"</p>				<p>DATE: 08/19/83</p> <p>REV: 0</p> <p>DWG. NO: B049-4-023</p> <p>SHEET: 2 OF 3</p>			

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS




BASE PLATE



11/16" DIA ADHESIVE ANCHORS
1" Ø , 8 1/4" EMBEDMENT
A307 (OR EQUIV) THREADED ROD

IMAGES-3D
Ver. 3.0
Geometry Plot

IMAGES 3D MODEL
BSC SUPPORT STRUCTURE



Beam Splitter Chamber Support Structure
Wireframe Plot

12/28/95
12:58:58

===== I M A G E S - 3 D =====
 = Copyright (c) 1984-1993. RLCA/Celestial Software =
 =====

SOLVE BEAM LOADS/STRESSES

Version 3.0

12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

Load Case 1:MAXIMUM UNBALANCED LOADS COMBINED WITH DEAD WT + EQ(.056G)

BEAM LOADS AND/OR STRESSES

GLoads Node	Fx	Fy	Fz	Mx	My	Mz
LLoads Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
Stress Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
	Corner1	Corner2	Corner3	Corner4	Maximum	Minimum
BEAM NO. 1						
GLoads 16	-.1840E+05	-.3504E+04	-.1547E+05	.1393E+06	.4803E-11	-.1656E+06
GLoads 2	.1840E+05	.3504E+04	.1547E+05	-.2785E+06	-.4803E-11	.3313E+06
LLoads 16	-.3504E+04	.2395E+05	.2072E+04	.4803E-11	.1865E+05	-.2156E+06
LLoads 2	.3504E+04	-.2395E+05	-.2072E+04	-.4803E-11	-.3730E+05	.4312E+06
Stress 16	.2014E+03	.3201E+04	.2769E+03	-.7064E-13	.4876E+03	.5636E+04
	-.4947E+04	.6325E+04	.5350E+04	-.5923E+04	.6325E+04	-.5923E+04
Stress 2	.2014E+03	.3201E+04	.2769E+03	-.7064E-13	.9752E+03	.1127E+05
	-.1010E+05	.1245E+05	.1050E+05	-.1205E+05	.1245E+05	-.1205E+05
BEAM NO. 2						
GLoads 2	-.1016E+05	-.2198E+03	-.6706E+04	.4805E+05	.0000E+00	.4180E+05
GLoads 3	.1016E+05	.2198E+03	.6706E+04	-.2224E+06	.0000E+00	.2224E+06
LLoads 2	-.2198E+03	.1193E+05	.2444E+04	.0000E+00	-.6353E+05	-.4415E+04
LLoads 3	.2198E+03	-.1193E+05	-.2444E+04	.0000E+00	.0000E+00	.3145E+06
Stress 2	.1263E+02	.1594E+04	.3265E+03	.0000E+00	-.1661E+04	.1154E+03
	-.1764E+04	-.1533E+04	.1789E+04	.1558E+04	.1789E+04	-.1764E+04
Stress 3	.1263E+02	.1594E+04	.3265E+03	.0000E+00	.0000E+00	.8223E+04
	-.8211E+04	.8236E+04	.8236E+04	-.8211E+04	.8236E+04	-.8211E+04
BEAM NO. 3						
GLoads 17	-.5751E+04	.3504E+05	.2574E+04	-.2317E+05	.9770E-13	-.5176E+05
GLoads 5	.5751E+04	-.3504E+05	-.2574E+04	.4633E+05	-.9770E-13	.1035E+06
LLoads 17	.3504E+05	-.5886E+04	.2246E+04	.9770E-13	.2022E+05	.5298E+05
LLoads 5	-.3504E+05	.5886E+04	-.2246E+04	-.9770E-13	-.4043E+05	-.1060E+06
Stress 17	-.2014E+04	-.7866E+03	.3002E+03	-.1437E-14	.5285E+03	-.1385E+04
	-.1001E+03	-.2870E+04	-.3927E+04	-.1157E+04	-.1001E+03	-.3927E+04
Stress 5	-.2014E+04	-.7866E+03	.3002E+03	-.1437E-14	.1057E+04	-.2770E+04
	.1813E+04	-.3727E+04	-.5841E+04	-.3006E+03	.1813E+04	-.5841E+04
BEAM NO. 4						
GLoads 5	-.1399E+05	.2025E+05	-.9445E+04	-.3035E+06	.0000E+00	.3059E+06
GLoads 6	.1399E+05	-.2025E+05	.9445E+04	.5790E+05	.0000E+00	.5790E+05
LLoads 5	.2025E+05	-.3215E+04	.1657E+05	.0000E+00	-.4309E+06	-.1715E+04
LLoads 6	-.2025E+05	.3215E+04	-.1657E+05	.0000E+00	.0000E+00	-.8188E+05
Stress 5	-.1164E+04	-.4297E+03	.2215E+04	.0000E+00	-.1127E+05	.4484E+02
	-.1247E+05	-.1238E+05	.1015E+05	.1006E+05	.1015E+05	-.1247E+05
Stress 6	-.1164E+04	-.4297E+03	.2215E+04	.0000E+00	.0000E+00	-.2141E+04
	.9770E+03	-.3304E+04	-.3304E+04	.9770E+03	.9770E+03	-.3304E+04

LOADS

ESTIMATED INSULATED

$$W = 14000 \text{ LB}$$

SEISMIC FORCE

$$F_{EQ} = a W$$

$$a = .05625 \text{ g} - \text{REF PAGE V049-1-021}$$

$$F_{EQ} = .05625 (14000) \\ = 788 \text{ LB}$$

UNBALANCED VACUUM LOADS

FROM CALC V049-1-032, BSC: 7%
IN THE WALLS HAVE THE MAX UNBALANCED
FORCES. LET $F_x = 45460 \text{ LB}$

$$F_z = 29440 \text{ LB}$$

COMBINE SEISMIC w/ F_x UNBALANCED LOAD


$$\text{NODE 15: } F_y = 45460 + 788 = 46248 \text{ LB}$$

$$\text{NODE 15: } F_y = -W = -14000 \text{ LB}$$

$$\text{NODE 21: } F_z = 29440 \text{ LB}$$

DETERMINE IF CROSS MEMBER WILL CLEAR HEAD

LOWEST PT AT CENTER OF BOTTOM HEAD IS 15 IN ABOVE FLOOR, & OF COLUMN IS 42 IN FROM BEAM TUBE AXIS. CROWN POINT OF LOWER HEAD IS 105.375



$$\sin \theta = \frac{42}{105.375}$$

$$\theta = 23.47^\circ$$

$$S = 105.375 - 105.375 \cos \theta$$

$$= 8.73 \text{ IN}$$

OR FOR 6 IN DEEP MEMBER

HEIGHT OF CURVE MEMBER ABOVE FLOOR


$$h = 15 + \frac{6}{2}$$

$$= 18 \text{ IN TO } \& \text{ OF TS } 6 \times 4 \times \frac{1}{4}$$

USE TS 7x4x3/8

TOTAL CLEARANCE FROM FLOOR =

$$15 + 8.73 = 23.73 \text{ IN}$$





MEMBERS

1 TO 8 } TS 8x4x 5/8
 17 TO 20 }
 9 TO 12 TS 8x4x 1/2
 13 TO 16 DUMMY

PIN TYPE SUPPORTS AT WORKS 1, 4, 7, 8, 9


PIN RELEASE AT TOP OF 8x4x 5/8 TUBE STEEL SUPPORT LEG

SINCE THE SHELL IS FLEXIBLE FOR LOCAL BENDING AT SUPPORT LEG ATTACHMENT, THE FOLLOWING LOCAL MOMENTS ARE RELEASED:

M_x (PIN RELEASE 4 - TORSION IN WBY58)

M_y (" " 5 - WEAK AXIS BENDING IN WBY51)

M_z IS RETAINED SINCE IT TRANSFERS MEMBRANE FORCES INTO SHELL



Y, y, z ARE LOCAL AXES OF SUPPORT LEG

===== I M A G E S - 3 D =====
= Copyright (c) 1984-1993. RLCA/Celestial Software =
=====

Interactive Microcomputer Analysis & Graphics of Engineering Systems

IMAGES-3D Version 3.0 12/31/93

Filename=BSCSUPP RUN ID=XX11111

=====

= NOTICE =

= RLCA/Celestial Software assumes no responsi- =
= bility for the validity, accuracy, or =
= applicability of the results obtained from =
= IMAGES-3D. =

=====

=====

= Any questions or comments concerning the use =
= of IMAGES-3D or the users manual should =
= be addressed to: =

=

= RLCA/Celestial Software =
= 2150 Shattuck Ave. =
= Suite 1200 =
= Berkeley, CA =
= 94704 =

=

= 510-843-0977 =

=====

===== I M A G E S - 3 D =====
= Copyright (c) 1984-1993. RLCA/Celestial Software =
=====

CHECK GEOMETRY

Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

Acceleration of Gravity = 3.864E+02

Force Multiplier Length Multiplier Temp. Multiplier

1.0000E+00 1.0000E+00 1.0000E+00
(For database properties only)

MATERIAL PROPERTIES

Mat No. Name

1 STEEL
2 STEEL
3 STEEL

Mat No	Ex Gxy	Ey Gyz	Ez Gzx	nxy axy	nyz ayz	nzx azx	Density
1	2.900E+07	2.900E+07	2.900E+07	3.000E-01	3.000E-01	3.000E-01	2.830E-01
	1.120E+07	1.120E+07	1.120E+07	6.500E-06	6.500E-06	6.500E-06	
2	2.900E+07	2.900E+07	2.900E+07	3.000E-01	3.000E-01	3.000E-01	2.830E-01
	1.120E+07	1.120E+07	1.120E+07	6.500E-06	6.500E-06	6.500E-06	
3	2.900E+07	2.900E+07	2.900E+07	3.000E-01	3.000E-01	3.000E-01	2.830E-01
	1.120E+07	1.120E+07	1.120E+07	6.500E-06	6.500E-06	6.500E-06	

BEAM CROSS SECTION PROPERTIES

Prop No. Name

1 W8X58
2 TB4X4X4
4 TB8X4X8
5 TB8X8X10

Pr. No.	X-Section Area	Moment of Inertia Iy / Iz	Torsional Const.- J	Iyz	Shear SFy / SFz	Shape Fact. SFz
1	1.710E+01	7.510E+01 / 2.280E+02	3.340E+00	0.000E+00	3.83E+00 / 1.28E+00	1.28E+00
2	3.590E+00	8.220E+00 / 8.220E+00	1.350E+01	0.000E+00	1.79E+00 / 1.79E+00	1.79E+00
3	1.000E+02	1.000E+03 / 1.000E+03	2.000E+03	0.000E+00	0.00E+00 / 0.00E+00	0.00E+00
4	1.040E+01	2.460E+01 / 7.510E+01	6.410E+01	0.000E+00	1.30E+00 / 2.60E+00	2.60E+00
5	1.740E+01	1.530E+02 / 1.530E+02	2.580E+02	0.000E+00	1.74E+00 / 1.74E+00	1.74E+00

===== I M A G E S - 3 D =====
 = Copyright (c) 1984-1993. RLCA/Celestial Software =
 =====

CHECK GEOMETRY

Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

Pr. No.	Bending Stress Recovery Distances				Ctors	Shear Stress Fact.	
	Cy-	Cy+	Cz-	Cz+		SSFy	SSFz
1	4.11E+00	4.11E+00	4.38E+00	4.38E+00	8.10E-01	4.36E+00	1.92E+00
2	2.00E+00	2.00E+00	2.00E+00	2.00E+00	1.92E+00	2.31E+00	2.31E+00
3	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
4	2.00E+00	2.00E+00	4.00E+00	4.00E+00	2.44E+00	1.89E+00	3.43E+00
5	4.00E+00	4.00E+00	4.00E+00	4.00E+00	3.79E+00	2.33E+00	2.33E+00

NODE COORDINATES

Node	X-Coord.	Y-Coord.	Z-Coord.
1	0.00000E+00	0.00000E+00	0.00000E+00
2	0.00000E+00	1.80000E+01	0.00000E+00
3	0.00000E+00	4.40000E+01	0.00000E+00
4	8.40000E+01	0.00000E+00	0.00000E+00
5	8.40000E+01	1.80000E+01	0.00000E+00
6	8.40000E+01	4.40000E+01	0.00000E+00
7	8.40000E+01	0.00000E+00	-8.40000E+01
8	8.40000E+01	1.80000E+01	-8.40000E+01
9	8.40000E+01	4.40000E+01	-8.40000E+01
10	0.00000E+00	0.00000E+00	-8.40000E+01
11	0.00000E+00	1.80000E+01	-8.40000E+01
12	0.00000E+00	4.40000E+01	-8.40000E+01
13	-4.20000E+01	0.00000E+00	-4.20000E+01
14	1.26000E+02	0.00000E+00	-4.20000E+01
15	4.20000E+01	7.00000E+01	-4.20000E+01
16	0.00000E+00	9.00000E+00	0.00000E+00
17	8.40000E+01	9.00000E+00	0.00000E+00
18	8.40000E+01	9.00000E+00	-8.40000E+01
19	0.00000E+00	9.00000E+00	-8.40000E+01
20	0.00000E+00	0.00000E+00	0.00000E+00
21	3.61250E+01	7.00000E+01	-4.20000E+01

*** WARNING - *** Nodes 1 & 20 are <=0.0001 apart in all 3 dirs. ***

BEAM CONNECTIVITY

Beam No	Nodes From/ To / Ref	Prop No	Mat No	PinCodes I / J	Rigid End Offset I / J	Length	Beam Type

===== I M A G E S - 3 D =====
 = Copyright (c) 1984-1993. RLCA/Celestial Software =
 =====

CHECK GEOMETRY

Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

Beam No	Nodes From/ To / Ref	Prop No	Mat No	Pincodes I / J	Rigid End Offset I / J	Length	Beam Type
1	16 2 13	5	1		0.00E+00 0.00E+00	9.0000E+00	Beam
2	2 3 13	5	1	45	0.00E+00 0.00E+00	2.6000E+01	Beam
3	17 5 14	5	1		0.00E+00 0.00E+00	9.0000E+00	Beam
4	5 6 14	5	1	45	0.00E+00 0.00E+00	2.6000E+01	Beam
5	18 8 14	5	1		0.00E+00 0.00E+00	9.0000E+00	Beam
6	8 9 14	5	1	45	0.00E+00 0.00E+00	2.6000E+01	Beam
7	19 11 13	5	1		0.00E+00 0.00E+00	9.0000E+00	Beam
8	11 12 13	5	1	45	0.00E+00 0.00E+00	2.6000E+01	Beam
9	2 5 1	4	2		0.00E+00 0.00E+00	8.4000E+01	Beam
10	5 8 4	4	2		0.00E+00 0.00E+00	8.4000E+01	Beam
11	8 11 7	4	2		0.00E+00 0.00E+00	8.4000E+01	Beam
12	11 2 10	4	2		0.00E+00 0.00E+00	8.4000E+01	Beam
13	3 15 0	3	3		0.00E+00 0.00E+00	6.4838E+01	Beam
14	6 15 0	3	3		0.00E+00 0.00E+00	6.4838E+01	Beam
15	9 15 0	3	3		0.00E+00 0.00E+00	6.4838E+01	Beam
16	12 15 0	3	3		0.00E+00 0.00E+00	6.4838E+01	Beam
17	1 16 13	5	1		0.00E+00 0.00E+00	9.0000E+00	Beam
18	4 17 14	5	1		0.00E+00 0.00E+00	9.0000E+00	Beam
19	7 18 14	5	1		0.00E+00 0.00E+00	9.0000E+00	Beam
20	10 19 13	5	1		0.00E+00 0.00E+00	9.0000E+00	Beam
21	15 21 0	3	3		0.00E+00 0.00E+00	5.8750E+00	Beam

RESTRAINTS

Node No	Global/Local	Restraint Directions
1	GLOBAL	X Y Z - - -
4	GLOBAL	X Y Z - - -
7	GLOBAL	X Y Z - - -
10	GLOBAL	X Y Z - - -

NODAL CONNECTIVITY

*** WARNING - Node 13 not connected to any element ***

PROCESS ENGINEERING INC. S/N:802506A

03/21/96

PAGE 4

RUN ID=XX11111

16:52:37

===== I M A G E S - 3 D =====
= Copyright (c) 1984-1993. RLCA/Celestial Software =
=====

CHECK GEOMETRY

Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

*** WARNING - Node 14 not connected to any element ***

*** WARNING - Node 20 not connected to any element ***

*EXTRA NODE
(NOT REQ'D)*

===== I M A G E S - 3 D =====
= Copyright (c) 1984-1993. RLCA/Celestial Software =
=====

RENUMBER NODES

Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

NODE RENUMBERING CROSS REFERENCE LIST

Was	Is	Was	Is	Was	Is	Was	Is	Was	Is
1	18	2	16	3	15	4	4	5	14
6	11	7	1	8	7	9	5	10	3
11	13	12	10	13	19	14	20	15	12
16	17	17	9	18	2	19	8	20	21
21	6								

===== I M A G E S - 3 D =====
= Copyright (c) 1984-1993. RLCA/Celestial Software =
=====

ASSEMBLE STIFFNESS MATRIX Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

STIFFNESS ASSEMBLY SUMMARY

Number of Node Points.....	21
Number of Truss and Beam Elements.....	21
Number of Plate Elements.....	0
Number of Spring Elements.....	0
Number of Solid Elements.....	0
Number of Axisymmetric Elements.....	0
Number of Nodes with Restraints.....	4
Number of Equations to be Solved.....	96
Number of Blocks in the Matrix.....	1

B L O C K I N F O R M A T I O N

BLCK NO	SIZE (Byte)	BLCK NO	SIZE (Byte)	BLCK NO	SIZE (Byte)	BLCK NO	SIZE (Byte)
----	-----	----	-----	----	-----	----	-----
1	14208						

===== I M A G E S - 3 D =====
 = Copyright (c) 1984-1993. RLCA/Celestial Software =
 =====

ASSEMBLE STIFFNESS MATRIX Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

E Q U A T I O N N U M B E R L I S T

NODE		TRANSLATION			ROTATION		
WAS	IS	X	Y	Z	X	Y	Z
1	18	0	0	0	94	95	96
2	16	82	83	84	85	86	87
3	15	76	77	78	79	80	81
4	4	0	0	0	13	14	15
5	14	70	71	72	73	74	75
6	11	52	53	54	55	56	57
7	1	0	0	0	1	2	3
8	7	28	29	30	31	32	33
9	5	16	17	18	19	20	21
10	3	0	0	0	10	11	12
11	13	64	65	66	67	68	69
12	10	46	47	48	49	50	51
13	19	0	0	0	0	0	0
14	20	0	0	0	0	0	0
15	12	58	59	60	61	62	63
16	17	88	89	90	91	92	93
17	9	40	41	42	43	44	45
18	2	4	5	6	7	8	9
19	8	34	35	36	37	38	39
20	21	0	0	0	0	0	0
21	6	22	23	24	25	26	27

STIFFNESS SUMMARY IN 1 BLOCKS

Minimum Diagonal Stiffness..... .1541D+08
 Eq No of Minimum Diagonal..... 28
 Maximum Diagonal Stiffness..... .2597D+11
 Eq No of Maximum Diagonal..... 62

===== I M A G E S - 3 D =====
= Copyright (c) 1984-1993. RLCA/Celestial Software =
=====

SOLVE DISPLACEMENTS

Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

L O A D C A S E 1

MAXIMUM UNBALANCED LOADS COMBINED WITH DEAD WT + EQ(.056G)

GRAVITY LOADING

X	Y	Z
.0000E+00	.0000E+00	.0000E+00

CONCENTRATED LOADS

Node	Fx	Fy	Fz	Mx	My	Mz
15	.4625E+05	-.11400E+05	.0000E+00	.0000E+00	.0000E+00	.0000E+00
21	.0000E+00	.0000E+00	.2944E+05	.0000E+00	.0000E+00	.0000E+00

REFERENCE TEMPERATURE = .0000E+00

===== I M A G E S - 3 D =====
= Copyright (c) 1984-1993. RLCA/Celestial Software =
=====

SOLVE DISPLACEMENTS

Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

L O A D C A S E 1

MAXIMUM UNBALANCED LOADS COMBINED WITH DEAD WT + EQ(.056G)
APPLIED LOAD VECTOR

Node	Fx	Fy	Fz	Mx	My	Mz
15	.4625E+05	-.1400E+05	.0000E+00	.0000E+00	.0000E+00	.0000E+00
21	.0000E+00	.0000E+00	.2944E+05	.0000E+00	.0000E+00	.0000E+00

===== I M A G E S - 3 D =====
 = Copyright (c) 1984-1993. RLCA/Celestial Software =
 =====

SOLVE DISPLACEMENTS

Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

L O A D C A S E 1

MAXIMUM UNBALANCED LOADS COMBINED WITH DEAD WT + EQ(.056G)

DISPLACEMENTS

Node	T r a n s l a t i o n s			/	R o t a t i o n s		
	X	Y	Z		X	Y	Z
1	.0000E+00	.0000E+00	.0000E+00	/	.1942E-02	-.4443E-05	-.3025E-02
2	.5339E-01	.1250E-03	.3407E-01	/	.1377E-02	-.4443E-05	-.2353E-02
3	.1134E+00	.1363E-03	.6336E-01	/	.1090E-02	-.5882E-03	-.1319E-02
4	.0000E+00	.0000E+00	.0000E+00	/	.1870E-02	.2820E-04	-.3112E-02
5	.5569E-01	-.1250E-02	.3381E-01	/	.1964E-02	.2820E-04	-.2902E-02
6	.1485E+00	-.2293E-02	.1040E+00	/	-.5761E-03	-.6703E-04	-.2981E-04
7	.0000E+00	.0000E+00	.0000E+00	/	.1745E-02	.7949E-04	-.2866E-02
8	.5069E-01	-.3747E-03	.3047E-01	/	.1151E-02	.7949E-04	-.2298E-02
9	.1116E+00	-.7467E-03	.5170E-01	/	.1286E-02	.7517E-03	-.9411E-03
10	.0000E+00	.0000E+00	.0000E+00	/	.2029E-02	.4685E-04	-.2914E-02
11	.5208E-01	.1000E-02	.3651E-01	/	.2019E-02	.4685E-04	-.2676E-02
12	.1368E+00	.1683E-02	.1058E+00	/	-.1979E-03	.2306E-03	-.2257E-03
13	.0000E+00	.0000E+00	.0000E+00	/	.0000E+00	.0000E+00	.0000E+00
14	.0000E+00	.0000E+00	.0000E+00	/	.0000E+00	.0000E+00	.0000E+00
15	.1524E+00	-.8364E-02	.9703E-01	/	.2621E-03	.1263E-03	-.4118E-03
16	.2821E-01	.6250E-04	.1831E-01	/	.1801E-02	-.4443E-05	-.2857E-02
17	.2832E-01	-.6249E-03	.1669E-01	/	.1894E-02	.2820E-04	-.3060E-02
18	.2662E-01	-.1874E-03	.1657E-01	/	.1596E-02	.7949E-04	-.2724E-02
19	.2658E-01	.5001E-03	.1828E-01	/	.2027E-02	.4685E-04	-.2855E-02
20	.0000E+00	.0000E+00	.0000E+00	/	.0000E+00	.0000E+00	.0000E+00
21	.1524E+00	-.5944E-02	.9785E-01	/	.2621E-03	.1438E-03	-.4118E-03

===== I M A G E S - 3 D =====
 = Copyright (c) 1984-1993. RLCA/Celestial Software =
 =====

SOLVE BEAM LOADS/STRESSES

Version 3.0

12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

Load Case 1:MAXIMUM UNBALANCED LOADS COMBINED WITH DEAD WT + EQ(.056G)

GLoads Node	Fx	Fy	Fz	Mx	My	Mz
LLoads Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
Stress Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
	Corner1	Corner2	Corner3	Corner4	Maximum	Minimum
BEAM NO. 5						
GLoads 18	-.1555E+05	.1050E+05	-.1626E+05	.1464E+06	-.1348E-11	-.1400E+06
GLoads 8	.1555E+05	-.1050E+05	.1626E+05	-.2928E+06	.1348E-11	.2800E+06
LLoads 18	.1050E+05	-.2250E+05	.5027E+03	-.1348E-11	.4524E+04	.2025E+06
LLoads 8	-.1050E+05	.2250E+05	-.5027E+03	.1348E-11	-.9049E+04	-.4050E+06
Stress 18	-.6037E+03	-.3007E+04	.6718E+02	.1983E-13	.1183E+03	-.5294E+04
	.4808E+04	-.5779E+04	-.6016E+04	.4572E+04	.4808E+04	-.6016E+04
Stress 8	-.6037E+03	-.3007E+04	.6718E+02	.1983E-13	.2366E+03	-.1059E+05
	.1022E+05	-.1095E+05	-.1143E+05	.9747E+04	.1022E+05	-.1143E+05
BEAM NO. 6						
GLoads 8	-.1056E+05	.7220E+04	-.4245E+04	.9017E+05	.0000E+00	.7412E+05
GLoads 9	.1056E+05	-.7220E+04	.4245E+04	-.2005E+06	.0000E+00	.2005E+06
LLoads 8	.7220E+04	-.1047E+05	-.4468E+04	.0000E+00	.1162E+06	.1135E+05
LLoads 9	-.7220E+04	.1047E+05	.4468E+04	.0000E+00	.0000E+00	-.2836E+06
Stress 8	-.4149E+03	-.1399E+04	-.5971E+03	.0000E+00	.3037E+04	-.2966E+03
	.2919E+04	.2326E+04	-.3749E+04	-.3156E+04	.2919E+04	-.3749E+04
Stress 9	-.4149E+03	-.1399E+04	-.5971E+03	.0000E+00	.0000E+00	-.7415E+04
	.7000E+04	-.7830E+04	-.7830E+04	.7000E+04	.7000E+04	-.7830E+04
BEAM NO. 7						
GLoads 19	-.6542E+04	-.2804E+05	-.2763E+03	.2486E+04	.9042E-12	-.5888E+05
GLoads 11	.6542E+04	.2804E+05	.2763E+03	-.4973E+04	-.9042E-12	.1178E+06
LLoads 19	-.2804E+05	.4430E+04	-.4821E+04	.9042E-12	-.4339E+05	-.3987E+05
LLoads 11	.2804E+05	-.4430E+04	.4821E+04	-.9042E-12	.8678E+05	.7975E+05
Stress 19	.1611E+04	.5920E+03	-.6442E+03	-.1330E-13	-.1134E+04	.1042E+04
	-.5655E+03	.1519E+04	.3788E+04	.1703E+04	.3788E+04	-.5655E+03
Stress 11	.1611E+04	.5920E+03	-.6442E+03	-.1330E-13	-.2269E+04	.2085E+04
	-.2742E+04	.1427E+04	.5965E+04	.1795E+04	.5965E+04	-.2742E+04
BEAM NO. 8						
GLoads 11	-.1153E+05	-.1325E+05	-.9043E+04	-.2712E+06	.0000E+00	.2638E+06
GLoads 12	.1153E+05	.1325E+05	.9043E+04	.3603E+05	.0000E+00	.3603E+05
LLoads 11	-.1325E+05	.1759E+04	-.1455E+05	.0000E+00	.3783E+06	-.5216E+04
LLoads 12	.1325E+05	-.1759E+04	.1455E+05	.0000E+00	.0000E+00	.5096E+05
Stress 11	.7614E+03	.2351E+03	-.1944E+04	.0000E+00	.9889E+04	.1364E+03
	.1051E+05	.1079E+05	-.8991E+04	-.9264E+04	.1079E+05	-.9264E+04
Stress 12	.7614E+03	.2351E+03	-.1944E+04	.0000E+00	.0000E+00	.1332E+04
	-.5708E+03	.2094E+04	.2094E+04	-.5708E+03	.2094E+04	-.5708E+03
BEAM NO. 9						
GLoads 2	-.8235E+04	-.9287E+04	-.1037E+02	-.4993E+04	.1583E+03	-.3758E+06

===== I M A G E S - 3 D =====
= Copyright (c) 1984-1993. RLCA/Celestial Software =
=====

SOLVE BEAM LOADS/STRESSES Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

Load Case 1:MAXIMUM UNBALANCED LOADS COMBINED WITH DEAD WT + EQ(.056G)

GLoads Node	Fx	Fy	Fz	Mx	My	Mz
LLoads Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
Stress Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
	Corner1	Corner2	Corner3	Corner4	Maximum	Minimum
GLoads 5	.8235E+04	.9287E+04	.1037E+02	.4993E+04	.7129E+03	-.4043E+06
LLoads 2	-.8235E+04	.9287E+04	.1037E+02	-.4993E+04	-.1583E+03	.3758E+06
LLoads 5	.8235E+04	-.9287E+04	-.1037E+02	.4993E+04	-.7129E+03	.4043E+06
Stress 2	.7919E+03	.1685E+04	.3425E+01	.1902E+03	-.1287E+02	-.2002E+05
	.2080E+05	-.1924E+05	-.1921E+05	.2082E+05	.2082E+05	-.1924E+05
Stress 5	.7919E+03	.1685E+04	.3425E+01	.1902E+03	.5796E+02	.2153E+05
	-.2068E+05	.2238E+05	.2227E+05	-.2080E+05	.2238E+05	-.2080E+05
BEAM NO. 10						
GLoads 5	.6602E+01	.5502E+04	.1201E+05	.2522E+06	-.7129E+03	-.5140E+04
GLoads 8	-.6602E+01	-.5502E+04	-.1201E+05	.2100E+06	.1583E+03	.5140E+04
LLoads 5	-.1201E+05	-.5502E+04	-.6602E+01	.5140E+04	.7129E+03	-.2522E+06
LLoads 8	.1201E+05	.5502E+04	.6602E+01	-.5140E+04	-.1583E+03	-.2100E+06
Stress 5	.1155E+04	-.9981E+03	-.2180E+01	-.1958E+03	.5796E+02	.1343E+05
	-.1222E+05	.1464E+05	.1453E+05	-.1233E+05	.1464E+05	-.1233E+05
Stress 8	.1155E+04	-.9981E+03	-.2180E+01	-.1958E+03	.1287E+02	-.1118E+05
	.1235E+05	-.1002E+05	-.1004E+05	.1233E+05	.1235E+05	-.1004E+05
BEAM NO. 11						
GLoads 8	-.4983E+04	.8786E+04	-.1037E+02	-.7390E+04	-.1583E+03	-.3592E+06
GLoads 11	.4983E+04	-.8786E+04	.1037E+02	.7390E+04	-.7129E+03	-.3788E+06
LLoads 8	.4983E+04	-.8786E+04	-.1037E+02	.7390E+04	.1583E+03	-.3592E+06
LLoads 11	-.4983E+04	.8786E+04	.1037E+02	-.7390E+04	.7129E+03	-.3788E+06
Stress 8	-.4791E+03	-.1594E+04	-.3425E+01	-.2815E+03	.1287E+02	.1913E+05
	-.1960E+05	.1867E+05	.1864E+05	-.1963E+05	.1867E+05	-.1963E+05
Stress 11	-.4791E+03	-.1594E+04	-.3425E+01	-.2815E+03	-.5796E+02	-.2018E+05
	.1964E+05	-.2071E+05	-.2060E+05	.1975E+05	.1975E+05	-.2071E+05
BEAM NO. 12						
GLoads 11	.6602E+01	-.6002E+04	.8756E+04	.2687E+06	.7129E+03	-.2743E+04
GLoads 2	-.6602E+01	.6002E+04	-.8756E+04	.2355E+06	-.1583E+03	.2743E+04
LLoads 11	.8756E+04	.6002E+04	.6602E+01	-.2743E+04	-.7129E+03	.2687E+06
LLoads 2	-.8756E+04	-.6002E+04	-.6602E+01	.2743E+04	.1583E+03	.2355E+06
Stress 11	-.8420E+03	.1089E+04	.2180E+01	.1045E+03	-.5796E+02	-.1431E+05
	.1341E+05	-.1521E+05	-.1510E+05	.1353E+05	.1353E+05	-.1521E+05
Stress 2	-.8420E+03	.1089E+04	.2180E+01	.1045E+03	-.1287E+02	.1254E+05
	-.1340E+05	.1169E+05	.1171E+05	-.1337E+05	.1171E+05	-.1340E+05
BEAM NO. 13						
GLoads 3	-.1016E+05	-.2198E+03	-.6706E+04	.2224E+06	-.1574E-09	-.2224E+06
GLoads 15	.1016E+05	.2198E+03	.6706E+04	-.4060E+06	.7085E+06	.4774E+06
LLoads 3	-.2327E+04	.7785E+03	-.1193E+05	.2881E+06	-.1261E+06	.8643E-09

===== I M A G E S - 3 D =====
 = Copyright (c) 1984-1993. RLCA/Celestial Software =
 =====

SOLVE BEAM LOADS/STRESSES

Version 3.0

12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

Load Case 1:MAXIMUM UNBALANCED LOADS COMBINED WITH DEAD WT + EQ(.056G)

GLoads Node	Fx	Fy	Fz	Mx	My	Mz
LLoads Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
Stress Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
	Corner1	Corner2	Corner3	Corner4	Maximum	Minimum
-----	-----	-----	-----	-----	-----	-----
LLoads 15	.2327E+04	-.7785E+03	.1193E+05	-.2881E+06	.8995E+06	.5048E+05
Stress 3	.2327E+02	.7785E+01	-.1193E+03	-.1441E+03	-.1261E+03	-.8643E-12
	-.1029E+03	-.1029E+03	.1494E+03	.1494E+03	.1494E+03	-.1029E+03
Stress 15	.2327E+02	.7785E+01	-.1193E+03	-.1441E+03	-.8995E+03	.5048E+02
	-.9267E+03	-.8258E+03	.9732E+03	.8723E+03	.9732E+03	-.9267E+03
		BEAM NO. 14				
GLoads 6	-.1399E+05	.2025E+05	-.9445E+04	-.5790E+05	.6670E-09	-.5790E+05
GLoads 15	.1399E+05	-.2025E+05	.9445E+04	.6628E+06	.1910E+06	-.4288E+06
LLoads 6	.2330E+05	.1190E+05	-.3215E+04	.7501E+05	-.3284E+05	-.2778E-09
LLoads 15	-.2330E+05	-.1190E+05	.3215E+04	-.7501E+05	.2413E+06	.7718E+06
Stress 6	-.2330E+03	.1190E+03	-.3215E+02	-.3751E+02	-.3284E+02	.2778E-12
	-.2659E+03	-.2659E+03	-.2002E+03	-.2002E+03	-.2002E+03	-.2659E+03
Stress 15	-.2330E+03	.1190E+03	-.3215E+02	-.3751E+02	-.2413E+03	.7718E+03
	-.1246E+04	.2975E+03	.7801E+03	-.7635E+03	.7801E+03	-.1246E+04
		BEAM NO. 15				
GLoads 9	-.1056E+05	.7220E+04	-.4245E+04	.2005E+06	-.4327E-09	-.2005E+06
GLoads 15	.1056E+05	-.7220E+04	.4245E+04	-.6142E+06	-.6220E+06	.1720E+06
LLoads 9	.6988E+04	.4822E+04	.1047E+05	-.2598E+06	.1137E+06	.4116E-09
LLoads 15	-.6988E+04	-.4822E+04	-.1047E+05	.2598E+06	-.7927E+06	.3127E+06
Stress 9	-.6988E+02	.4822E+02	.1047E+03	.1299E+03	.1137E+03	-.4116E-12
	.4384E+02	.4384E+02	-.1836E+03	-.1836E+03	.4384E+02	-.1836E+03
Stress 15	-.6988E+02	.4822E+02	.1047E+03	.1299E+03	.7927E+03	.3127E+03
	.4102E+03	.1035E+04	-.5499E+03	-.1175E+04	.1035E+04	-.1175E+04
		BEAM NO. 16				
GLoads 12	-.1153E+05	-.1325E+05	-.9043E+04	-.3603E+05	-.1841E-08	-.3603E+05
GLoads 15	.1153E+05	.1325E+05	.9043E+04	.3574E+06	-.1045E+06	-.2206E+06
LLoads 12	-.1864E+05	-.6303E+04	.1759E+04	-.4668E+05	.2043E+05	.4527E-09
LLoads 15	.1864E+05	.6303E+04	-.1759E+04	.4668E+05	-.1345E+06	-.4087E+06
Stress 12	.1864E+03	-.6303E+02	.1759E+02	.2334E+02	.2043E+02	-.4527E-12
	.2068E+03	.2068E+03	.1660E+03	.1660E+03	.2068E+03	.1660E+03
Stress 15	.1864E+03	-.6303E+02	.1759E+02	.2334E+02	.1345E+03	-.4087E+03
	.7296E+03	-.8779E+02	-.3568E+03	.4606E+03	.7296E+03	-.3568E+03
		BEAM NO. 17				
GLoads 1	-.1840E+05	-.3504E+04	-.1547E+05	-.3289E-09	-.9815E-12	-.3440E-10
GLoads 16	.1840E+05	.3504E+04	.1547E+05	-.1393E+06	.9815E-12	.1656E+06
LLoads 1	-.3504E+04	.2395E+05	.2072E+04	-.9815E-12	.2569E-09	.2082E-09
LLoads 16	.3504E+04	-.2395E+05	-.2072E+04	.9815E-12	-.1865E+05	.2156E+06
Stress 1	.2014E+03	.3201E+04	.2769E+03	.1444E-13	.6715E-11	-.5444E-11
	.2014E+03	.2014E+03	.2014E+03	.2014E+03	.2014E+03	.2014E+03

===== I M A G E S - 3 D =====
 = Copyright (c) 1984-1993. RLCA/Celestial Software =
 =====

SOLVE BEAM LOADS/STRESSES

Version 3.0

12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

Load Case 1:MAXIMUM UNBALANCED LOADS COMBINED WITH DEAD WT + EQ(.056G)

GLoads Node	Fx	Fy	Fz	Mx	My	Mz
LLoads Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
Stress Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
	Corner1	Corner2	Corner3	Corner4	Maximum	Minimum
Stress 16	.2014E+03	.3201E+04	.2769E+03	.1444E-13	.4876E+03	.5636E+04
	-.4947E+04	.6325E+04	.5350E+04	-.5923E+04	.6325E+04	-.5923E+04
	BEAM NO. 18					
GLoads 4	-.5751E+04	.3504E+05	.2574E+04	.1465E-10	.9770E-13	.1489E-10
GLoads 17	.5751E+04	-.3504E+05	-.2574E+04	.2317E+05	-.9770E-13	.5176E+05
LLoads 4	.3504E+05	-.5886E+04	.2246E+04	.9770E-13	-.1705E-12	-.2089E-10
LLoads 17	-.3504E+05	.5886E+04	-.2246E+04	-.9770E-13	-.2022E+05	-.5298E+05
Stress 4	-.2014E+04	-.7866E+03	.3002E+03	-.1437E-14	-.4458E-14	.5461E-12
	-.2014E+04	-.2014E+04	-.2014E+04	-.2014E+04	-.2014E+04	-.2014E+04
Stress 17	-.2014E+04	-.7866E+03	.3002E+03	-.1437E-14	.5285E+03	-.1385E+04
	-.1001E+03	-.2870E+04	-.3927E+04	-.1157E+04	-.1001E+03	-.3927E+04
	BEAM NO. 19					
GLoads 7	-.1555E+05	.1050E+05	-.1626E+05	-.8290E-10	-.1348E-11	.4106E-10
GLoads 18	.1555E+05	-.1050E+05	.1626E+05	-.1464E+06	.1348E-11	.1400E+06
LLoads 7	.1050E+05	-.2250E+05	.5027E+03	-.1348E-11	-.2959E-10	-.8765E-10
LLoads 18	-.1050E+05	.2250E+05	-.5027E+03	.1348E-11	-.4524E+04	-.2025E+06
Stress 7	-.6037E+03	-.3007E+04	.6718E+02	.1983E-13	-.7735E-12	.2292E-11
	-.6037E+03	-.6037E+03	-.6037E+03	-.6037E+03	-.6037E+03	-.6037E+03
Stress 18	-.6037E+03	-.3007E+04	.6718E+02	.1983E-13	.1183E+03	-.5294E+04
	.4808E+04	-.5779E+04	-.6016E+04	.4572E+04	.4808E+04	-.6016E+04
	BEAM NO. 20					
GLoads 10	-.6542E+04	-.2804E+05	-.2763E+03	-.2741E-10	.9042E-12	.3778E-11
GLoads 19	.6542E+04	.2804E+05	.2763E+03	-.2486E+04	-.9042E-12	.5888E+05
LLoads 10	-.2804E+05	.4430E+04	-.4821E+04	.9042E-12	.2206E-10	-.1671E-10
LLoads 19	.2804E+05	-.4430E+04	.4821E+04	-.9042E-12	.4339E+05	.3987E+05
Stress 10	.1611E+04	.5920E+03	-.6442E+03	-.1330E-13	.5766E-12	.4369E-12
	.1611E+04	.1611E+04	.1611E+04	.1611E+04	.1611E+04	.1611E+04
Stress 19	.1611E+04	.5920E+03	-.6442E+03	-.1330E-13	-.1134E+04	.1042E+04
	-.5655E+03	.1519E+04	.3788E+04	.1703E+04	.3788E+04	-.5655E+03
	BEAM NO. 21					
GLoads 15	-.5457E-08	-.1210E-08	-.2944E+05	-.3399E-10	-.1730E+06	-.6029E-08
GLoads 21	.5457E-08	.1210E-08	.2944E+05	.3399E-10	-.6762E-08	.4820E-10
LLoads 15	.5457E-08	-.1210E-08	.2944E+05	.3399E-10	-.1730E+06	.6029E-08
LLoads 21	-.5457E-08	.1210E-08	-.2944E+05	-.3399E-10	-.6762E-08	-.4820E-10
Stress 15	-.5457E-10	-.1210E-10	.2944E+03	-.1700E-13	-.1730E+03	-.6029E-11
	-.1730E+03	-.1730E+03	.1730E+03	.1730E+03	.1730E+03	-.1730E+03
Stress 21	-.5457E-10	-.1210E-10	.2944E+03	-.1700E-13	.6762E-11	-.4820E-13
	-.4776E-10	-.4786E-10	-.6138E-10	-.6128E-10	-.4776E-10	-.6138E-10

===== I M A G E S - 3 D =====
= Copyright (c) 1984-1993. RLCA/Celestial Software =
=====

SOLVE BEAM LOADS/STRESSES

Version 3.0

12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

Load Case 1:MAXIMUM UNBALANCED LOADS COMBINED WITH DEAD WT + EQ(.056G)

GLoads Node	Fx	Fy	Fz	Mx	My	Mz
LLoads Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
Stress Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
	Corner1	Corner2	Corner3	Corner4	Maximum	Minimum

===== I M A G E S - 3 D =====
= Copyright (c) 1984-1993. RLCA/Celestial Software =
=====

SOLVE BEAM LOADS/STRESSES

Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

Load Case 1:MAXIMUM UNBALANCED LOADS COMBINED WITH DEAD WT + EQ(.056G)

MAXIMUM STRESS SUMMARY FOR BEAMS/TRUSSES
WITHIN SPECIFIED RANGE 1- 21

Element	Type	Stress Type	Value
-----	-----	-----	-----
7	BEAM	Axial Tension	.1611E+04
3	BEAM	Axial Compression	-.2014E+04
1	BEAM	Transv. Shear	.3201E+04
15	BEAM	Torsion Shear	.1299E+03
9	BEAM	Bending Stress	.2153E+05
9	BEAM	Max. Comb. Normal	.2238E+05
9	BEAM	Min. Comb. Normal	-.2080E+05

===== I M A G E S - 3 D =====
 = Copyright (c) 1984-1993. RLCA/Celestial Software =
 =====

SOLVE REACTIONS

Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

Load Case 1:MAXIMUM UNBALANCED LOADS COMBINED WITH DEAD WT + EQ(.056G)

REACTIONS

Node	Fx	Fy	Fz	Mx	My	Mz
1	-.1840E+05	-.3504E+04	-.1547E+05	.0000E+00	.0000E+00	.0000E+00
4	-.5751E+04	.3504E+05	.2574E+04	.0000E+00	.0000E+00	.0000E+00
7	-.1555E+05	.1050E+05	-.1626E+05	.0000E+00	.0000E+00	.0000E+00
10	-.6542E+04	-.2804E+05	-.2763E+03	.0000E+00	.0000E+00	.0000E+00
Total	-.4625E+05	.1400E+05	-.2944E+05	.0000E+00	.0000E+00	.0000E+00

MEMBER STRESS EVALUATION

FROM THE IMAGES OUTPUT, SL 9, THE 8x4x1/2 WIDE FLANGE MEMBER, HAS THE HIGHEST STRESS. THIS IS DUE TO BENDING AT THE COLUMN (8x8x5/8 TS SUPPORT LEG)

THIS MEMBER WILL BE AISC GRA B WITH A MIN YIELD STRESS OF 46 KSI

FROM AISC - F1, THE ALLOWABLE UNRESTRICTED LENGTH IS

$$L_c = \left(1950 + \frac{1200 M_1}{M_2} \right) \frac{b}{F_y}$$

$$b = 4 \text{ IN}$$

$$M_1 = 375 \text{ IN-K (NODE 2)}$$

$$M_2 = 404 \text{ IN-K (NODE 5)}$$

$$F_y = 46$$

$$L_c = \left(1950 + 1200 \cdot \frac{375}{404} \right) \frac{4}{46} = 266 \text{ IN}$$

$$\gg L = 84 \text{ IN} \quad \text{OK}$$

$$\frac{b}{t} = \frac{4}{.50} = 8 < \frac{190}{\sqrt{F_y}} = 28 \quad \text{OK}$$

\(\therefore\) SECTION IS COMPACT - AISC TABLE B5.1

$$\Rightarrow F_b = .66 F_y = .66 (46) = 30.4 \text{ KSI}$$

FROM THE IMAGES OUTPUT -

$$f_b = 22.4 \text{ KSI} < F_b = 30.4 \text{ KSI} \quad \text{OK}$$

100 SHEETS
 100 SHEETS
 200 SHEETS

MAX DEFLECTION (NODE 15)

$\Delta_y = .152$

$\Delta_z = .097$

$$\Delta = (\Delta_y^2 + \Delta_z^2)^{\frac{1}{2}}$$

$$= .180 \text{ IN}$$

BASE PLATE / ANCHOR REACTIONS

NODE	1	4	7	10	
F_y	18.4	5.8	15.6	6.5	
F_z	-3.5	35.0	10.5	-28.0	$\left\{ \begin{array}{l} + = \text{COMP} \\ - = \text{TEN} \end{array} \right.$
F_x	15.5	2.6	16.3	.3	
TEN = 1.25 F_y	4.4	—	—	3.5	PAYING
$V = (F_y^2 + F_z^2)^{\frac{1}{2}}$	24.0	6.4	22.6	6.5	
$T = T_{EN}/4$	1.1	—	—	4.75	← MAX BASE TENS 31
Tail	10.96	—	—	10.96	*
T/Tail	.10	—	—	.40	
$V/4$	6.0	1.6	5.7	1.6	
V _{tail}	7.63	7.63	7.63	7.63	*
V/V_{tail}	.79	.21	.75	.21	
T/V_{tail}	.89	.21	.75	1.01	≈ 1.0 OK

* SEE FOLLOWING SHEET

BEARING FOR COMPRESSIVE FORCES

AT DOOR " F_y = 35.0 K

FOR 14x14 BASE PLATE

$$f_p = \frac{35}{14 \times 14} = .18 \text{ ksi } \approx$$

<< f'_c = 3000 psi
FOR CONCRETE

HILTI HVA ADHESIVE ANCHORS WILL BE USED - 4 PER BASE PLATE

USE 1 IN ANCHORS W/ 4 1/4" EMBEDMENT

$$T_{HU} = 10.96 \text{ K (BOND IN 3000 PSI CON.)}$$


$$T_{ALL} = 12.12 \text{ K (A307 STEEL ROD)}$$

$$V_{ALL} = 7.63$$

ALLOWABLES ARE FROM HILTI CATALOG

(HAS-Anchor Rod)

P_{TMIN} = 2 1/2" FOR
STANDARD ROD



USE CUSTOM ROD
FOR LARGE GROUT
PAD

200 SHEETS
 200 SHEETS
 200 SHEETS



TENSILE CAPACITY OF 4-BOLT CLUSTER DUE TO CONCRETE CONE FAILURE. CONSIDER OVERLAPPING CONES

ANCHOR SPACING

$$S = 11 \text{ IN} > A_S = 8 \frac{1}{4} \text{ IN}^2$$

HILTI CALCULOM

SURFACE AREA OF INTERSECTING CONES



$$E = \text{EMBEDMENT} = 8.25 \text{ IN}$$

$$r = E$$

$$2r = 16.5 > S = 11$$

$$\theta = \cos^{-1} \left(\frac{S/2}{r} \right) = \cos^{-1} \left(\frac{5.5}{8.25} \right) = .841 \text{ RAD} = 48.2^\circ$$

$$h = r \sin \theta = 8.25 \sin(.841 \text{ RAD}) = 6.15 \text{ IN}$$

$$A_{IT} = \frac{1}{2} (h/2) = \frac{1}{2} (6.15) = 16.91 \text{ IN}^2$$

$$A_{2\theta} = \pi r^2 \left(\frac{2\theta}{2\pi} \right) = r^2 \theta = (8.25)^2 (.841) = 57.25 \text{ IN}^2$$

$$A_{OL} = A_{2\theta} - 2A_{IT} = 57.25 - 2(16.91) = 23.43 \text{ IN}^2$$

$$\text{FOR ONE CONE: } A_{\text{CONE}} = \pi r^2 - 2A_{OL} = \pi (8.25)^2 - 2(23.43) = 167 \text{ IN}^2$$

TOTAL CONE AREA

$$A_T = 4 A_{\text{CONE}} = 4(167) = 668 \text{ IN}^2$$

Revision No. 0

Doc. No. V049-1-024

Page 30 of 35



CONCRETE STRENGTH FOR THE 4 BOLT ANCHORS

$$T_u = 4 \phi_c \sqrt{f'_c} A_T$$

$$f'_c = 3000 \text{ psi}$$

$$\phi_c = .65$$

$$T_u = 4(.65)(3000)^{\frac{1}{2}} (662) \\ = 95113 \text{ LB}$$

MAXIMUM TENSILE FORCE IN ONE

$$F_y = 28.0 \text{ K}$$

PER AISC CODE, (PART 9), LOAD FACTOR = 1.7

$$1.7F_y = 47.6 < T_u = 95.1 \text{ K OK}$$

ALLOWABLE LOAD PER ANCHOR BASED ON CONCRETE CONE FAILURE

$$T_{all} = \frac{T_u}{4(1.7)} = \frac{95113}{6.8}$$


$$= 14.0 \text{ K}$$

$$> 10.96 \text{ K (BASED ON 3000 PSI CONE)}$$

$$> 12.12 \text{ K (A307 STEEL ROD CAPACITY)}$$

∴ BOND COUSANS ANCHOR FOR $\frac{1}{4}$ " EMBEDMENT

BASE PLATE BENDING DUE TO ANCHOR TENSION



$$b = 2a$$

$$a = \left(\left(\frac{11 - 8}{2} \right)^2 \times 2 \right)^{\frac{1}{2}}$$

$$a = 2.12$$

$$b = 2(2.12) = 4.24$$

MOMENT

$$M = T a = 8.75 (2.12) = 18.6 \text{ IN-K}$$

STRESS

$$f_s = \frac{6M}{b t^2}$$

$$= \frac{6(18.6)}{4(1)^2}$$

$$= 27.8 \text{ KSI} \approx .75 F_y = .75(36) = 27 \text{ KSI}$$

SAY OK

TUBESTIFF TO BASE PLATE WELD

$$T = 28.0 \text{ K} = F_y \quad \text{MAX TENSION}$$

TRY 5/16 FILLET,

$$L = 4(1) = 32$$

$$A_w = .707 \left(\frac{5}{16} \right) (32) \\ = 7.07 \text{ IN}^2$$

WELD STRESS DUE TO SHEAR LOADS

$$V = 24.0 \text{ K} \quad \text{MAX SHEAR} \\ \text{ON ANOTHER} \\ \text{BASE PLATE}$$

$$f_v = \frac{T}{A_w} + \frac{V}{A_w} = \\ = \frac{28.0}{7.07} + \frac{24.0}{7.07} \\ = 4.0 + 3.4 = \\ = 7.4 \text{ KSI} \quad \text{OK}$$





LEG TO VESSEL CONNECTION

PAD WELD - DESIGN FOR RESULTANT FORCE AND BENDING MOMENT AT TOP OF SUPPORT LEG

$$F = (F_x^2 + F_y^2 + F_z^2)^{\frac{1}{2}}$$


$$= (20.3^2 + 3.2^2 + 16.6^2)^{\frac{1}{2}} \quad (\text{BEAM 4, NODE 6})$$

$$= 26.4 \text{ k MAX FORCE}$$

$$M_z = 315 \text{ IN-K, MAX AT BEAM 2, NODE 3}$$

($M_y = M_z = 0$ DUE TO THE BEAMS)

ASSUME WELD IS 3/8 IN THICK - ALL AROUND ON 10 x 12 PAD



$$A = \frac{3}{4} (.707) (10 + 12) (.7) = 11.67 \text{ IN}^2$$

$$I_y = \frac{3}{8} \left(2 \times \frac{12^3}{12} + 2 \times 10 \times 6^2 \right)$$

$$= \frac{3}{8} (1008) = 378 \text{ IN}^4$$

$$I_x = \frac{3}{8} \left(2 \times \frac{10^3}{12} - 2 \times 12 \times 5^2 \right)$$

$$= \frac{3}{8} (767) = 288 \text{ IN}^4$$

$$J = I_x + I_y = 666 \text{ IN}^4$$

$$P = (6^2 + 5^2)^{\frac{1}{2}} = 7.81 \text{ IN}$$

WELD SHEAR STRESS

$$f_v = \frac{F}{A_w} + \frac{M_z P}{J}$$


$$= \frac{26.4}{11.67} + \frac{315 (7.81)}{666}$$

$$= 2.26 + 3.69 = 5.96 \text{ KSI OK}$$

ACTUAL STRESS < 5.96 KSI SINCE MAX MOMENT & MAX FORCE OCCUR AT DIFFERENT JOINTS

WELDED CONNECTION BETWEEN SUPPORT LEG
($8 \times 4 \times 5/8$ TS) AND CROSS MEMBER ($7 \times 4 \times 3/8$)

SINCE THE BENDING STRESS IN THE
CROSS MEMBER IS HIGH AT THE SUPPORT
LEG, THIS CONNECTION WILL BE A
FP BUTT WELD




* FULL THROAT REQUIRED FOR
 $3/8$ THICK MEMBER

NOTE: SEE CALCULATION V049-1-069
FOR DESIGN OF CREVIS CONNECTION
BETWEEN SUPPORT LEG AND WELD
PAD AT SHELL.

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-025 PAGE 1 OF 5
REV.	DEO #	DATE	BY:	CHECK	TITLE: Design of Temporary Covers	
0	0128	4/17/96	RDC	WDB		
					BY: R. D. Ciatto	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
PURPOSE: Design temporary shipping and test covers for 60.5 in nozzles in accordance with the requirements of ASME Section VIII, Div. 1.						
METHOD: Hand calculation to determine membrane and shear stresses.						
ASSUMPTIONS:						
INPUTS:						
1. Atmospheric pressure = 14.7 psi. 2. Temperature = 70°F (SHIPPING). 3. TEMP = 400°F DURING BAKEOUT						
REFERENCES: 1. ASME Boiler & Pressure Vessel Code, Section VIII, Div. 1, Pressure Vessels 2. Doc. No. V049-1-026, LIGO VACUUM EQUIP., STRUCT. DESIGN CRITERIA,						
CALCULATIONS: (SEE ATTACHED)						
CONCLUSIONS: The requirements of the ASME Code are met.						
NOTES:						

TEMPERARY 60.5 IN COVER



C = FLANGE WIDTH FOR 60.5 IN FLANGE

THICKNESS = 1/16 IN

MATERIAL SA 210 304L (CMR 1220)

BOLT PATTERN & SIZE IS SAME AS FLANGE BOLT PATTERN & SIZE


REV D
Dwg. NO V049-1-025
P. 2 OF 5



TEMPERARY COVER FOR 60 IN DIA -

COVER WILL BE 1/2 IN SHEET 304L.
COLD CHAM COVER USING 30 PSID AIR
PISTE

TO FORM THE COVER, THE SHEET WILL
BE CLAMPED BETWEEN 2 CIRCULAR PLATES.
PRESSURE WILL BE APPLIED ON ONE
SIDE. A PLASTIC HINGE WILL FORM
AT THE EDGE OF THE SHEET



MEMBRANE STRESS IN SPHERES

$$\sigma = \frac{PR}{2t}$$

YIELD STRESS AT ROOM TEMP

$$\sigma = S_y = 25 \text{ KSI FOR 304L}$$

$$P = 30$$


$$t = 1/16 = .0625$$

$$25,000 = \frac{30 R}{2(.0625)}$$

$$R = 104.2 \text{ IN}$$

REV D
DOC. NO V049-1-075
P. 3 OF 5

15-111 30 SHEETS
 15-112 100 SHEETS
 15-114 200 SHEETS



$$a = (104.2^2 - 30.25^2)^{\frac{1}{2}}$$

$$= 99.7$$

$$b = 104.2 - a$$

$$= 104.2 - 99.7$$

$$= 5.0 \text{ IN}$$

USING YIELD STRESS FROM CENTER
 DETERMINE PRESSURE REQUIRED
 TO OBTAIN $b = 5 \text{ IN}$

$$P = \frac{2 S_y t}{R}$$

$$= \frac{2 (.0625) S_y}{104.2}$$

$$= 1.20 (10)^{-3} S_y$$

P, S_y IN PSI, S_y @ ROOM TEMP

REQUIRED THICKNESS FROM ASME VIII, (1), APP.1.

$$t = \frac{p R_o}{2SE T.8 P} \quad \text{FOR SPHERICAL SHELL}$$

$$P = 14.7$$

$$R_o = 104.2 + .06$$

$$= 104.3$$

REV D
 Des. No. V049-1-075
 P. 4 OF 5

VESSELS WILL BE BAKED @ 400°IS WHILE
TEMP COVERS ARE IN PLACE
 $S = 14.7$ @ 70°IS ASME II TABLE 1A
FOR SA 240 304L

$$E = \text{JOINT EFFICIENCY} \\ = 1.0 \quad (\text{NO WELD})$$

$$t = \frac{14.7(104.3)}{2(14,700)(1) + 8(14.7)} \\ = .052 < .0625 = 1/16$$

OK

SHEAR STRESS AT EDGE


$$\tau = \frac{\pi \left(\frac{60.5}{2}\right)^2 (14.7)}{\pi (60.5) (.0625)} \\ = 3600 \text{ psi} \quad \text{OK}$$

REV 0
Doc. No. VO-9-1-025
P. 5 OF 5



PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-026 PAGE 1 OF 3
REV.	DEO #	DATE	BY:	CHECK	Beam Splitter Chamber - Evaluation of Nozzle to Shell Welds	
0	0024	12/6/75	RAC	AGR		
					BY: <i>R.D. Castro</i>	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
PURPOSE: To evaluate nozzle to shell fillet welds.						
METHOD: Hand calculation using standard principles of mechanics.						
ASSUMPTIONS:						
INPUTS: LIGO project sketches and drawings.						
REFERENCES: ASME Boiler & Pressure Vessel Code, Section VIII, Division 1. <i>Doc. No. V049-1-066, LIGO VACUUM EQUIP. STRUCTURAL DESIGN CRITERIA.</i>						
CALCULATIONS: (SEE ATTACHED)						
CONCLUSIONS: Nozzle welds are acceptable.						
NOTES:						

NORSE TO SHELL WELDS



MAX NOZZLE DIAMETER THAT USES THIS WELD IS 14" O.D. THE THICKNESS OF THE NOZZLES THAT RANGE FROM 8" TO 14" O.D. IS .125 IN. THE WELD FOR THE 14" NOZZLE HAS THE MIX STRESS.

EVALUATE FULL FILLET FOR END CAP LOAD ONLY. DISCONTINUITY BENDING & STRESS WILL BE NEGLECTED SINCE THEY ARE SECONDARY, BUT THE STRENGTH ADDED BY THE STITCH WELD WILL BE IGNORED.

END CAP FORCE DUE TO VACUUM

$$F = \pi r^2 (14.7)$$

$$= \pi \left(\frac{14}{2}\right)^2 (14.7) = 2263 \text{ LB}$$

14" NOZZLE HAS MAX END CAP LOAD

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



WELD THROAT AREA

$$A_w = \pi 14 \times .707 (.125) \\ = 3.89 \text{ IN}^2$$

WELD SHEAR STRESS

$$f_v = \frac{F}{A_w} \\ = \frac{2263}{3.89} \\ = 582 \text{ psi } \text{OK}$$

THE 60 IN NOTCHES ARE WELDED TO THE SHEET WITH FULL PENETRATION WELDS. NO FURTHER ANALYSIS FOR THESE WELDS IS REQUIRED.

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-027 PAGE 1 OF 6
REV.	DEO #	DATE	BY:	CHECK	Beam Splitter Chamber - Vessel Lifting Devices	
0	0024	12/6/11	RDC	WDB		
					BY: RDC	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
<p>PURPOSE: To design lifting lugs and evaluate leg stresses when BSC is lifted and rotated to & from a horizontal position.</p>						
<p>METHOD: Hand calculation using standard stress analysis method.</p>						
<p>ASSUMPTIONS:</p>						
<p>INPUTS: 1. LIGO project sketches and drawings. 2. Vertical shock acceleration = 1g. 3. DDC No. V049-1-066, LIGO VACUUM EQUIP., STRUCTURAL DESIGN CRITERIA.</p>						
<p>REFERENCES:</p>						
<p>CALCULATIONS: (SEE ATTACHED)</p>						
<p>CONCLUSIONS: Lug & weld stresses are acceptable. Stresses in support legs and shell are acceptable.</p>						
<p>NOTES: A spreader beam should be used for the lift.</p>						

LIFTING LUGS

MAXIMUM ESTIMATED WEIGHT OF BSC

$$W = 15,000 \text{ LB}$$

INCLUDES SUPPORTS & REMOVABLE FLOOR.

SHIPPING ACCIDENTS FOR AIR-AIR TRUCK

VERT $a_v = 1.0 g$



HORIZ. $a_H = .5 g$

ASSUME THAT THESE ACCIDENTS ALSO APPLY TO LIFTING IN SHOP

∴ VERTICAL LOAD = DL + SHIPPING LOAD

$$F_v = W + W = 2W = 30,000 \text{ LB}$$

SINCE THERE WILL BE 2 LIFTING LUGS THE LIFTING LOAD IN EA LUG (FOR DESIGN PURPOSES) IS 15,000 LB. WHEN VESSEL IS IN HORIZ POSITION AND BEING RAISED TO VERTICAL WITH THE LUGS THE LATERAL LOAD IS $F_v/2 = 7,500 \text{ LB}$ ON LUG



22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS




THE FE ADD TO THE BSC UPPER SECTION SHOWED THAT THE MAX SHELL STRESS FOR THE VERTICAL LIFT IS 1590 PSI FOR A LUG LOAD OF 6750 LB. THE MAX STRESS FOR THIS CASE IS

$$SI = \frac{15000 \times 1590}{6750} = 3800 \text{ psi OK}$$

FOR THE HOIST RINGS THE MAX SHELL STRESS FROM THE FE ANALYSIS IS 2630 PSI FOR A LOAD OF 3125 LB. THE MAX STRESS INTERVIEW FOR THIS CASE IS

$$SI = \frac{7500 \times 2630}{3125} = 6300 \text{ psi OK}$$

LUG GEOMETRY



22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS






TENSILE STRESS AT PIN JOINT

$$A_{NET} = (6 - 1.5)(.5) = 2.25 \text{ IN}^2$$

$$f_t = \frac{15}{2.25} = 6.67 \text{ KSI} \quad OK$$

FOR $e = .5$


SHEAR STRESS



$$A_v = 2\left(\frac{6}{2} - 1.5\right)(.5) = 4.5 \text{ IN}^2$$

$$f_s = \frac{15}{4.5} = 3.33 \text{ KSI}$$

BENDING STRESS



$$M = 13.5(7.5) = 101.25 \text{ IN}^2$$

$$f_b = \frac{6M}{t b^2} = \frac{6(101.25)}{1(9)^2} = 15.0 \text{ KSI} \quad OK$$

WELD - 704 1/4 IN FRONT WELD

$$A_w = .707(.75) (12 + 12 + 9) = 5.8 \text{ IN}^2$$


NOTE: DRAWING V049-4-001 SHEET 5 SHOWS A WELD CAN BE WELDED LONG & VESSEL IN 3/16 WELD ALL AROUND TO VESSEL

$$A_w = 3/16(.707)(2 \times 12 + 2 \times 12.5) = 6.8 \text{ IN}^2 > 5.8 \quad OK$$

FOR VERTICAL LIFT, WELD STRESS

$$f_v = \frac{15}{A_w} = \frac{15}{5.8} = 2.6 \text{ ksi OK}$$

TORSIONAL SHEAR STRESS DUE TO LIFT FROM HORIZONTAL POSITION



$$C = \frac{12 \times 9 + 2 \times 12 \times 6}{2 \times 12 + 9}$$

$$= 7.64 \text{ in}$$

$$F_t = 7.5 \text{ in}$$

$$T = 7.5 (13.5 + 7.64) = 158.6 \text{ in}^2$$

$$I_x = \left[\frac{9^3}{12} + 2(12)(45)^2 \right] (.75) (.707)$$

$$= 386.6 (.75) = 96.6 \text{ in}^4$$

$$I_y = \left[9(12-7.64)^2 + 2 \times \frac{12^3}{12} + 2 \times 12 \times 16.6^2 \right] (.707) (.75)$$

$$= 370.2 (.75) = 92.6 \text{ in}^4$$

$$J = I_x + I_y = 96.6 + 92.6 = 189.2 \text{ in}^4$$

$$P_{MAX} = (7.64^2 + 45^2)^{\frac{1}{2}} = 8.90 \text{ in}$$


WELD SHEAR STRESS

$$T = \frac{F_t}{A_w} + \frac{T P_{MAX}}{J}$$

$$= \frac{7.5}{5.8} + \frac{158.6(8.90)}{189.2}$$

$$= 1.3 + 7.43 = 8.7 \text{ ksi OK}$$

LIFTING FORCE ON LEG WHEN BSC IS IN HORIZONTAL POSITION



$$F_{LCG} \approx 7.5K \quad \text{EA. LEG}$$

THIS FORCE IS BOUNDED BY THE MAX SHEAR FORCE IN THE BASE PLATE IMPOSED BY THE UNBALANCED INERTIAL LOAD. FROM SUPPORT CALC

$$V = 14.5K$$

IF STRESS IN SUPPORT STRUTS AND BSC WILL BE TO HIGH AND NECESSARY

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



STRESS IN OUTER WELD FOR PAD TO SHELL CONNECTION (3/16 RIGID ALL AROUND)


FOR VERT LOAD

$$T = 15 \text{ K}$$

$$A_w = .707 \times \frac{3}{16} (2 \times 12 + 2 \times 13.5) \\ = 6.76 \text{ IN}^2$$

$$f_t = \frac{15}{6.76} = 2.21 \text{ KSI OK}$$

FOR HORIZ CASE



$$T = 7.5 (25.5 - 11.5 - \frac{13.5}{2}) \\ = 151.9$$

$$I_y = \frac{3}{16} (.707) [2 \times \frac{12^3}{12} + 2 \times 13.5 \times 6^2] \\ = \frac{3}{16} (891) = 167 \text{ IN}^4$$

$$I_x = \frac{3}{16} (.707) [2 \times \frac{13.5^3}{12} + 2 \times 12 \times (\frac{13.5}{2})^2] \\ = \frac{3}{16} (1063) = 199$$

$$J = I_y + I_x = 366 \text{ IN}^4$$

$$r = [6^2 + (\frac{13.5}{2})^2]^{\frac{1}{2}} = 9.03 \text{ IN}$$

WELD SHEAR STRESS

$$T = \frac{7.5}{6.76} + \frac{151.9(9.03)}{366}$$

$$= 1.1 + 3.74$$

$$= 4.8 \text{ KSI OK}$$

REV D
Doc No 1049-1-077


P. 6a of 6

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-028 PAGE 1 OF 8
REV.	DEO #	DATE	BY:	CHECK	Beam Splitter Chamber - Shipping Loads	
0	0136	4/20/96	ROC	WDB		
					BY: R. D. Ciatto	DEPT: 744
<u>PROJECT:</u> LIGO Vacuum Equipment					<u>PROJECT NO:</u> V59049	
<u>PURPOSE:</u> To evaluate the BSC shell for loads imposed during shipping.						
<u>METHOD:</u> The IMAGES finite element computer program is used to analyze shell stresses.						
<u>ASSUMPTIONS:</u> It is assumed that the BSC will be shipped with its long axis in a horizontal position. Also, it is assumed that the vessel will be supported by 2 wood saddles during shipping.						
<u>INPUTS:</u> Vert shock accel = 1g Horizontal shock accel. = .5g Internal Vacuum Pressure = -14.7 psi						
<u>REFERENCES:</u> 1. IMAGES 3D, Version 3.0, R.L. Cloud & Associates 2. Doc. No. V049-1-066, LIGO Vacuum Equipment, Structural Design Criteria						
<u>CALCULATIONS:</u> (SEE ATTACHED)						
<u>CONCLUSIONS:</u> Shell stresses that result from shipping loads are low. The vessel can withstand a shock of 5Gs or more without damage to the shell.						
<u>NOTES:</u> The computer file name is BSC-SHIP.						

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-028 PAGE 1 OF 7
REV.	DEO #	DATE	BY:	CHECK	Beam Splitter Chamber - Shipping Loads	
0	0128	12/6/95	RDC	WSD		
					BY: R.D.C. [Signature]	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
PURPOSE: To evaluate the BSC shell for loads imposed during shipping.						
METHOD: The IMAGES finite element computer program is used to analyze shell stresses.						
ASSUMPTIONS: It is assumed that the BSC will be shipped with its long axis in a horizontal position. Also, it is assumed that the vessel will be supported by 2 wood saddles during shipping.						
INPUTS: Vert shock accel = 1g Horizontal shock accel. = .5g						
REFERENCES: IMAGES 3D, Version 3.0, R.L. Cloud & Associates						
CALCULATIONS: (SEE ATTACHED)						
CONCLUSIONS: Shell stresses that result from shipping loads are low. <i>THE VESSEL COULD SUSTAIN A SHOCK ACCELERATION OF SEVERAL GS.</i>						
NOTES: The computer file name is BSC-SHIP. *						

BSC SHIPPING LOADS

IT IS EXPECTED THAT THE BSC WILL BE SHIPPED IN A HORIZONTAL POSITION WHILE SUPPORTED BY 2 WOOD SADDLES AND STAPPED TO A WOOD SKID



CRITICAL OPERATIONS ARE IN THE SHELL AT THE SADDLES. SINCE THE THINNEST SHELL IS THE 1/4 IN UPPER SECTION, IT IS EVALUATED.

BECAUSE THE VERTICAL ACCEL (1G) WHEN COMBINED WITH GRAVITY (1G) IS HIGHER THAN THE HORIZONTAL ACCEL (.5G), ONLY THE VERTICAL LOAD WILL BE ANALYZED. THESE ACCELERATIONS ARE THE MAXIMUM FOR AN AIR-RIDE TRUCK.

MAX EST WT

$$W = 15000 \text{ LB}$$

DL + SHOCK LOAD (VERTICAL)

$$F_1 = W + W = 2W \\ = 30000 \text{ LB}$$

SADDLE LOAD

$$F_2 = \frac{F_1}{2} = 15000 \text{ LB}$$

THE HALF MODEL USED FOR THE UPPER SECTION ANALYSIS (BSCUAREA) IS USED TO EVALUATE THE SHELL. THE FILE WAS COPIED TO

FILE: BSC-1M10

AND A SADDLE WAS ADDED. SINCE THIS IS A HALF MODEL, A 7500 LB LOAD IS APPLIED TO THE SADDLE IN THE X DIRECTION. NOAL LOADS ARE

$$F_{Y56Y} = F_{Y56X} = 7500 \text{ LB}$$


$$F_{Y56Y...56X} = 15000 \text{ LB}$$

THE WOOD SADDLE IS 1 IN THICK. IT IS INPUT IN MAT 4 AND PLATE CASE NO. 6.


PLOTS ON THE FOLLOWING SHEETS SHOW THAT THE MAX STRESS INTENSITY IN THE 1/4 IN SHELL IS ONLY 2000 PSI AND THE MAX DEFORMATION IS .01 IN

WHEN COMBINED WITH VACUUM (LOAD CASE 3) THE SHIPPING LOAD STRESS IN THE SHELL IS ONLY 2600 PSI (SEE PLOT ON P. 7. THIS SHOWS THAT THE VERTICAL SHEAR COULD BE 5 G'S OR MORE WITHOUT DAMAGING THE 1/4 IN SHELL

(LOAD CASE 2 IS VACUUM ALONE.)


22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS


?#,130,140
 Next Node 573
 ?D
 Next Node 572
 ?-58.14,24,34
 572) -58.14 24 34
 Next Node 573
 ?-61.625,24,23.45
 573) -61.625 24 23.45
 Next Node 574
 ?-63.545,24,12.05
 574) -63.545 24 12.05
 Next Node 575
 ?-64.25,24,0
 575) -64.25 24 0
 Next Node 576
 ?#,130,140
 Next Node 576
 ?#,564,575
 Next Node 576
 ?■




↑
SADDIE

Auto	Blwup	Chge	Del
Exit	Gen	Help	List
Mult	Prnt	Rot	SCrn
Select	Undel	#	



IMAGES-3D
Ver. 3.0






Revision 0
Doc. No. V049-1-028
Page 5 of 8

Load Case
1

Wireframe Plot

11/30/95
11:29:2

IMAGES-3D
Version 3.0






Revision 0
Doc. No. V049-1-028
Page 6 of 9

Load Case
1

Stress Contour Plot
Surf: Bottom
Stress Intensity

11/30/95
11:25: 6

IMAGES-3D
Version 3.0





Revision 0
Doc. No. V049-1-028
Page 7 of 8

Load Case
1

Displacement Contour Plot
DX

11/30/95
11:27:37

IMAGES-3D
Version 3.0



Rev 0
Doc. No. V045-1-028
P. 8 of 8

Load Case
3



Stress Contour Plot
Surf: Top
Stress Intensity

4/28/96
9:21:40


PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-029 PAGE 1 OF 5
REV.	DEO #	DATE	BY:	CHECK	Beam Splitter Chamber Deflections	
0	002A	12/6/95	TRO			
PROJECT: LIGO Vacuum Equipment					BY: R.D. Ciarro	DEPT.: 744
PROJECT NO: V59049						
PURPOSE: Compute estimated deflections at Beam Splitter 60 in. nozzles.						
METHOD: Combine shell deflections with support deflections to obtain maximum estimated deflections at ports.						
ASSUMPTIONS: Bellows defects with negligible force.						
INPUTS: Deflections from shell FE analysis. Deflections from support frame analysis. PSI layout DWG. showing bellows location.						
REFERENCES:						
CALCULATIONS: (SEE ATTACHED)						
CONCLUSIONS:						
NOTES: The basis for these deflections is the support structure presented in the PDR.						



22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



CORNER STATION KEY PLAN



Revision 0
Doc. No. V049-1-029
Page 2 of 5

50 SHEETS
100 SHEETS
200 SHEETS22-141
22-142
22-144

OPERATING CONDITIONS

1. ALL VACUUM
2. VERTEX SECTION VENTED
3. DIAGONAL SECTION VENTED

DEFLECTIONS RESULT FROM

- SHELL DISPLACEMENT
- SUPPORT DISPLACEMENT

DEFLECTIONS ARE IN INCHES



22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS

JUL-12-1996 13:28

PROCESS SYSTEMS INT'L

P.06

BSC No.	OP. COND. NO.	Port a		Port b		Port c		Port d	
		Δy	Δz	Δy	Δz	Δy	Δz	Δy	Δz
1	1	.125			.125	-.125			-.125
	2								
	3	.125			.125	-.125			-.125
2	1	.125			.125	-.125			-.125
	2								
	3	.125			.125	-.125			-.125
3	1	.125			.125	-.125			-.125
	2								
	3	.125			.125	-.125			-.125
4	1	.125			.125	-.125			-.125
	2	.125			.125	-.125			-.125
	3	-.25			-.25	-.25			-.25

Revision 0
 Doc. No. V049-1-029
 Page 4 of 5



22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS

JUL-12-1996 13:28

PROCESS SYSTEMS INT'L

P.07

5

BSC No.	OP. COND. No.	Port a		Port b		Port c		Port d	
		Δ_1	Δ_2	Δ_1	Δ_2	Δ_1	Δ_2	Δ_1	Δ_2
7	1	.125	-.25		-.125	-.125	-.25		-.375
	2	.375	-.25	.25	-.125	.125	-.25	.25	-.375
	3	.125	-.25		-.125	-.125	-.25		-.375
8	1	.375		.25	.125	.125		.25	-.125
	2	.375	-.25	.25	-.125	.125	-.25	.25	-.375
	3	.375		.25	.125	.125		.25	-.125

Revision 0
 Doc. No. V049-1-029
 Pages of 5

TOTAL P.07

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-040 PAGE 1 OF 7
REV.	DEO #	DATE	BY:	CHECK	TITLE: Buckling Analysis of Beam Splitter Chamber	
0	0128	11/24/77	AM	RDC		
					BY: Kyle Martini	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
PURPOSE: Evaluate the beam splitter chamber (BSC) for buckling modes.						
METHOD: Finite element method and hand calculation.						
ASSUMPTIONS: See attached.						
INPUTS: LIGO project drawings and sketches.						
REFERENCES: NASTRAN Finite Element Program Doc. No. V049-1-066, LIGO VACUUM EQUIP STRUCT. DES. CRITERIA						
CALCULATIONS: (SEE ATTACHED)						
CONCLUSIONS: The minimum factor of safety against elastic buckling for vacuum loading is 5.9.						
NOTES: COMPUTER FILE: BMSPTX.INP						


1.0 Hand Analysis

Assumption - (1) Extra material at nozzles replaces stiffness of vessel material removed

(2) pressure uniform over cylinder

(3) stiffness are ignore

(4) cylinder length is from bottom head to connection between lower & upper beamsplitter $l = 91''$.



From Roark 5th ed table 35 case 19 b

Short tube of length "l" ends held circular but otherwise not constrained, no end loads

$$P_{cr} = 0.809 \frac{Et^2}{lr} \sqrt[4]{\left(\frac{1}{1-\nu^2}\right)^3 \frac{t^2}{r^2}}$$

$t = 0.15''$

$l = 91''$

$\nu = 0.3$

$r = 52.75''$

$E = 29(10^6) \text{ psi}$

$P_{cr} = 127.4 \text{ psi}$

$$F.S. = \frac{P_{cr}}{14.7} = \underline{\underline{8.67}}$$

2.0 COMPUTER ANALYSIS.

- a. The same length shell is analyzed using NASTRAN'S buckling program.
- b. The shell is $\frac{1}{2}$ " thick with the openings or holes for the 60" diameter tubes.
- c. The smaller nozzles are not modeled. It is assume the stiffness of the nozzle replaces the stiffness removed by the hole.
- d. The stiffness of the tube nozzles are model as beams. Assuming the nozzles extend 3" and are $\frac{1}{2}$ " thick.
- e. The vessel junction with the bottom head and the junction with the top position of the vessel are model as reinforcement beams $3" \times 1\frac{1}{2}"$.
- f. An external pressure of 14.7 psi is applied to all plate elements.
- g. An ^(vertical) axial ring load is applied to the bottom of the vessel and the top equal to $-PA$ where A is inside Area of vessel and $P = 14.7$ PSI

REV 0
V049-1-040
P. 3 OF 7




- h. The vessel is restrained at its connection with the support legs.
- i. Four configurations are analyzed, a four bellows model where no load is applied to the tube nozzle, a three bellows model where one nozzle is load, a two bellows model where two opposite nozzles are loaded, and two adjacent bellows loaded.
- j. Except as describe above all other stiffeners are ignore.
- k. The model is a 190°

3.0 Computer Results

<u>Model</u>	<u>Factor of Safety</u>
4 - bellows (Fig 1)	7.0
3 - bellows (Fig 2)	6.5
2 - ^{op} bellows (Fig 3)	6.1
2 - adjacent bellows	5.9

REV 0
 Doc. No V049-1-040
 P. 4 of 7




8

1/29/98

MAX-DEF. = 1.0000000

8




REV D
 Doc. No. Y045-1-REV D
 P. 5-007

HAM 1/1 SYMM MODEL

BUCKLING SOLUTION
 MODAL DEFOR. SUBCASE 2 MODE 5 EIGENV. 7.049044 MASS MODEL

Fig 1 - 4 Bellows Buckling Shape

5/7



Rev D
 Doc. No. V049.1-010
 P. 6 of 7


HAM 1/1 SYMM MODEL

BUCKLING SOLUTION

MODAL DEFOR. SUBCASE 2 MODE 6 EIGENV. 6.478190 MASS MODEL

617

Fig 2 3 Bellows B... diagram



Rev 0
 Doc. No. 10498-1-000
 P. 7 of 7

NAM 1/1 SYMM MODEL

BUCKLING SOLUTION

MODAL DEFOR. SUBCASE 2 MODE 6 EIGENV. 6.126621 MASS MODEL

L16

Fig 3 2 Bellows Asst. View

PROCESS SYSTEMS INTERNATIONAL, INC.
WESTBOROUGH, MA

ENGINEERING
CALCULATIONS

NO: V049-1-069

REV.	DEO #	DATE	BY:	CHECK
0	013/	3-8-96	AGR	RDC

PAGE 1 OF 9

TITLE:
BEAM SPLITTER SUPPORT CLEVIS

By: ART ROUSSOPOULOS | DEPT.: 744

PROJECT: LIGO

PROJECT NO: V59049

PURPOSE: DETERMINE THE STRUCTURAL INTEGRITY
OF THE BSC CLEVIS SUPPORT ASSEMBLY

METHOD: • CLASSICAL STRESS ANALYSIS - MAX SHEAR STRESS THEORY

SUMPTIONS: SEE CALCS

INPUTS: V049-1-024

REFERENCES: DWGS: V049-4-023 + V049-4-001 DOC. NO.
ASME VIII, DIV 2, 1989 ED
AISC, SCH - 9TH. ED.
V049-1-069, LIGO VAC. EQUIP. STRUCT. DESIGN CRITERIA

CALCULATIONS: (SEE ATTACHED)

CONCLUSIONS: STRUCTURAL SUPPORT OF CLEVIS ATTACHMENT + WELDS
ARE DESIGNED TO ASME VIII REQUIREMENTS

NOTES:

TABLE OF CONTENTS

	<u>PAGE</u>
1.- BSC SUPPORT DESIGN SKETCH	3
2.- ALLOWABLE WELD STRESSES	4
3.- SUPPORT WELD ANALYSIS	6
3.1 • CLEVIS / LUG TO VESSEL WELD	6
3.2 • 8X8 STEEL TUBE LEG TO CLEVIS/LUG	8


22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



1.0

BSC SUPPORT DESIGN SKETCH

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS





2.- ALLOWABLE WELD STRESSES

- ALLOWABLE WELD STRESS FOR BASE MATERIAL EVALUATIONS SHALL BE BASED ON SA 240 TYPE 304 AND IS ACCEPTABLE DUE TO DUAL CERTIFICATION OF 304/304L MATERIAL. I.C. 304L SHALL, VIA CMTR'S, MEET THE MINIMUM YIELD AND TENSILE STRESS AND ALL OTHER SA MATERIAL REQUIREMENTS FOR 304.
- ALLOWABLE WELD STRESS IS BASED ON THE REQUIREMENTS OF ASME VIII DIV 2, SECTION AD-920 "STRESS VALUES FOR WELD MATERIAL"
 - DESIGN STRESS INTENSITY, S_m , FOR SA 240 TYPE 304 FROM PART AM, TABLE AHA-1:

$$S_m = 18,700 \text{ PSI AT } 400^\circ\text{F}$$
 - STRESS INTENSITY REDUCTION FACTOR PER AD-920: $= .5$ FOR FILLET WELDS $\leq 1/2"$

2.1 - ALLOWABLE WELD STRESS INTENSITY:

$$S_{m, \text{ALLOW.}} = .5 (18,700) = 9,350 \text{ PSI}$$

2.2 - ALLOWABLE SHEAR STRESS:

- SHALL BE THE LESSER OF THE FOLLOWING:

- PER AD-132.2 "PERIPHERY OF SECTION IN TORSION"

$$\tau \leq .8 S_{m, \text{ALLOW.}} = .8 (.5 S_m) = .4 S_m$$

$$\therefore \tau \leq .4 S_m = .4 (18,700) = 7,480 \text{ PSI}$$

OR

$$\tau \leq .6 S_{m, \text{ALLOW.}} = .6 (.5 S_m) = .3 S_m$$

$$\tau \leq .3 S_m = .3 (18,700) = 5,610 \text{ PSI FOR}$$

PURE SHEAR



- PER AISC, TABLE J2.5, P. 5-70:

$\tau \leq .30 \times$ NOMINAL TENSILE STRENGTH OF WELD METAL. THIS VALUE WILL BE MULTIPLIED BY THE RATIO OF TENSILE STRESS OF THE BASE MATERIAL AT DESIGN TEMP. TO THE TENSILE OF THE BASE MATERIAL AT ROOM TEMP FOR REPRESENTATIVE DESIGN CONDITIONS.

$$\therefore \tau \leq .30 \times 75000 \left(\frac{S_{E, HOT}}{S_{E, COLD}} \right)$$

$$\tau \leq .30 \times 75000 \left(\frac{63450}{82800} \right) = 17,242 \text{ PSI}$$

- CONCLUSION:

- $\tau_{\text{TORSION}} \leq .8 S_m = 7,480 \text{ PSI}$

- $\tau_{\text{PURE}} \leq .6 S_m = 5,610 \text{ PSI}$

2.3 - SUMMARY:

- TORSIONAL SHEAR: $\tau \leq 7,480 \text{ PSI} = .8 S_m \text{ (ALLOWED)}$
- PURE SHEAR: $\tau \leq 5,610 \text{ PSI} = .6 S_m \text{ (ALLOWED)}$
- LOCAL PRIMARY MEMBRANE STRESS: $P_L \leq 1.5 S_m$
(REF: AD 140 (c))

$$P_L \leq 1.5 (.5 S_m) = 1.5 (.5) (18,700) = 14,025 \text{ PSI}$$

- PRIMARY BENDING STRESS: $P_b \leq 1.5 S_m$
(REF: AD 140 (d.))

$$P_b \leq 14,025 \text{ PSI}$$

- $P_L + P_b \leq 1.5 S_m = 14,025 \text{ PSI}$

3 - SUPPORT WELD ANALYSIS


REF: BSC SUPPORT DESIGN SKETCH
PSI DWG. V049-4-043
" " V049-4-001

- THE FOLLOWING ARE THE WORSE CASE LOADS FOR BEAM #2, NODE 3 AS CALCULATED IN REF. DOC. NO. V049-1-024, P.19

$$F_x = 220\# ; F_y = 11,930\# ; F_z = 2444\#$$

$$M_z = 319,500\text{ IN}\cdot\#$$

3.1 - CLEVIS / LUG TO VESSEL WELD



$$\rho = [8^2 + 8^2]^{1/2} = 5.65\text{''}$$

$$I_{x\text{TOT}} = \frac{4bh^3}{12} = \frac{4(2.707)(.5)^3}{12} = 60.3\text{ IN}^4$$

$$I_{y\text{TOT}} = 2 \left\{ \frac{8[2(2.707)(.5)]^3}{12} + (2)(2.707)(.5)(8)(.5)^2 \right\} = 181.5\text{ IN}^4$$

$$J = I_{x\text{TOT}} + I_{y\text{TOT}} = 60.3 + 181.5 = 241.8\text{ IN}^4$$

• TORSION:

$$T = M_z = 319,500\text{ IN}\cdot\#$$

$$\tau = \frac{T\rho}{J} = \frac{319,500(5.65)}{241.8} = 7,349\text{ PSI} < .8S_m = 7,480\text{ PSI} \therefore \text{OK}$$

• SHEAR: $A_s = 4 \times (8)(.707)(.5) = 11.31\text{ IN}^2$

$$\tau_{sx} = F_x / A_s = (220) / 11.31 = 20\text{ PSI} < .6S_m = 5610\text{ PSI} \therefore \text{OK}$$

$$\tau_{sy} = F_y / A_s = (11,930) / 11.31 = 1055\text{ PSI} < .6S_m = 5610\text{ PSI} \therefore \text{OK}$$

• TOTAL COMBINED SHEAR STRESS:

$$\tau_{\text{TOT}} = \sqrt{(\tau + \tau_{sx})^2 + \tau_{sy}^2}$$

$$\tau_{\text{TOT}} = \sqrt{(7349 + 20)^2 + (1055)^2} = 7444\text{ PSI}$$

$$< .8 S_m = 7,480\text{ PSI} \therefore \text{OK}$$

3.1 CONT

- TENSILE / COMPRESSIVE NORMAL STRESS:

$$f_{DC} = \frac{F_z}{A_g} = \frac{2449}{11.31} = 216 \text{ PSI}$$

- COMBINED STRESS:

$$f = \sqrt{216^2 + 7444^2} = 7447 \text{ PSI} < f_{SM} = 7480 \text{ PSI}$$

∴ OK




3.2 - 8x8 STEEL TUBE LEG TO CLEVLIS/LUG

• SHEAR: $F_3 = \sqrt{F_1^2 + F_2^2} = \sqrt{(11930)^2 + (2449)^2} = 12,178 \#$


$$\tau_s = \frac{F_3}{A_s} = \frac{12,178}{2[.707(4375)(8 + 2 \times 5.25)]} = 1,064 \text{ PSI}$$

$$\angle .6 S_m = 5,610 \text{ PSI} \therefore \text{OK}$$

• BENDING:



WELD LINE:



APPLIED MOMENT M PER WELD LINE $M_z/2 = (314,500/2) = 157,250 \text{ IN-}\#$

$$\tau_b = \frac{M_z}{I/c} = \frac{M_c}{I} = \frac{157,250(4)}{58.5} = 10,746 \text{ PSI}$$

$$\angle 1.5 S_m = 14,025 \text{ PSI} \therefore \text{OK}$$

WHEAR:

$$I = \frac{bd^3 - b^3d}{12} \quad \text{REF: MACHINERY HDBK; 17ED; P.364}$$

$$I = [(5.25)(8)^3 - (7.38)^3(5.25 - .31)]/12 = 58.5 \text{ IN}^4$$

$$b = 5.25'' ; d = 8'' ; t = .707(4375) = .31''$$

$$h = 8 - 2 \times (.707)(4375) = 7.38''$$

$$c = 4''$$

• TENSILE / COMPRESSIVE

$$\tau_{t/c} = \frac{F_x}{A_s} = \frac{220}{11.44} = 19 \text{ PSI}$$

• COMBINED STRESS:

$$\sigma = \frac{(10,746 + 19)}{2} \pm \sqrt{\left(\frac{10,746 + 19}{2}\right)^2 + (1064)^2}$$

$$\sigma_{1,2} = 5383 \pm 5487$$

$$\sigma_1 = 10,870 \text{ PSI} ; \sigma_2 = -104 \text{ PSI} ; \sigma_3 = 0$$

• MAX STRESS INTENSITY:

$$S_{\text{MAX}} = 10,780 - (-104) = 10,884 \text{ PSI}$$

$$< 1.5 S_m = 14,025 \text{ PSI} \therefore \text{OK}$$



PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: <i>✓</i> 049-1-031
						PAGE 1 OF 2
REV.	DEO #	DATE	BY:	CHECK	Vacuum Equipment Seismic Acceleration	
0	0.128	12/4/95	RDC	WDB		
					BY: <i>R.D. Carter</i>	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
PURPOSE: To determine maximum seismic acceleration factors for design of LIGO vacuum equipment.						
METHOD: Hand calculation using applicable construction code.						
ASSUMPTIONS:						
INPUTS: LIGO - E940002-02-4, Vacuum Equipment Specification, Rev. 2, September 6, 1995						
REFERENCES: 1. LIGO Specification (above) 2. ASCE 7-88, American Society of Civil Engineers - Minimum Design Loads for Buildings and Other Structures 3. Doc. No. <i>✓</i> 049-1-006, LIGO VACUUM EQUIP SEISMIC DESIGN CRITERIA.						
CALCULATIONS: (SEE ATTACHED)						
CONCLUSIONS: The maximum seismic acceleration factor is .05625G. This factor will be applied to equipment weight in static analyses.						
NOTES: The maximum seismic zone for LIGO equipment is Zone 1.						



SEISMIC ACCEL. SPECTRA PER ASCE 7-88
ZONE = 1, SECTION 9.10 APPLIES

$$F_p = Z I C_p W_p \quad \text{EQ 16, ASCE 7-88}$$

$$Z = 3/16 \quad \text{TABLE 21}$$

$$I = 1.0 \quad \text{TABLE 22}$$

$$C_p = .3 \quad \text{FOR EQUIPMENT TABLE 25}$$

$$W_p = \text{EQUIPMENT WEIGHT}$$

$$F_p = 3/16 (1.0) (.3) W_p \\ = .05625 W_p$$

NO SEISMIC ACCEL = .05625 G (LATERAL)

FORCES IN PRINCIPAL ORTHOGONAL
DIRECTIONS ARE NON CONCURRENT
(ASCE 7-88, 9.4.1)

REV. 0

DOC No. V049-1-031
Pg. 2 of 2

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-032 PAGE 1 OF 23
REV.	DEO #	DATE	BY:	CHECK	TITLE: Component Interface Loads	
0	139	12/29/90	RDK	AGR		
					BY: R. D. CURTIS	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
PURPOSE: Determine vacuum forces on component flanges due to the venting of certain sections of the system while other sections remain under vacuum.						
METHOD: Hand calculation methods of statics are used to determine unbalanced vacuum loads on: <ul style="list-style-type: none"> • Beam Splitter Chambers • Horizontal Access Modules • Gate Valves • 80K Pumps 						
ASSUMPTIONS: Bellows impose negligible axial forces on components. Adapters and valves have no axial restraint.						
INPUTS: PSI Equipment Arrangement Plans and spool piece dwgs. Atmospheric pressure = 14.7 psi.						
REFERENCES: Senior Flexonics, Inc. - Prelim. Design Calculations of LIGO Vacuum Equipment - Bellows (attached).						
CALCULATIONS: (See Attachment)						
CONCLUSIONS: See summary on following sheet.						
NOTES: This calculation may be used to determine vacuum forces on adapters, spool pieces and tubes.						

SUMMARY

THE MAXIMUM UNBALANCED FORCES ON THE
BODY SPLINTER CHAMBERS (BSC) ARE
ON BSC 7 & BSC 6 OF THE
WASHINGTON CORNER STATION - (SEE PAGES 7 & 8)
THE MAX FLANGE TENSION IS 29.5K ON THE 60.5 IN FLANGE

THE MAXIMUM UNBALANCED FORCES ON
THE HEAVY ACCESS HOODS (HAH) ARE
ON HAH 1 AT THE ENDS OF THE
VACUUM SYSTEM. $F = 45.5K$, IN TENSION ON
FLANGES

FOR GATE VALVES, BOLTED FLANGES CAN
HANDLE TENSILE LOADS FROM FULL VACUUM,
THE SAME IS TRUE FOR WELDED FLANGES,


$$F = 29.5K \text{ FOR } 48.25" \text{ VALVE}$$

$$F = 25.4K \text{ " } 44.63" \text{ VALVE}$$

FOR THE 80K PUMPS THE MAXIMUM
FLANGE FORCE IS 25.4K IN TENSION OR
COMPRESSION.

UNBALANCED FORCES RESULTING FROM BELLOWS

100 SHEETS
100 SHEETS



$$F = p \cdot EA$$

$$p = -14.7 \text{ psi}$$

EA = PRESSURE AREA OF BELLOWS
CORRESPONDING TO MEAN
DIAM. OF BELLOWS, D_m
(SEE ATTACHMENT)

48 IN TUBE (48 IN ID)

$$EA = 1983 \text{ in}^2$$

$$F = -14.7(1983) = -29,150 \text{ lb} = -29.2 \text{ K}$$

60 IN TUBE (60 IN ID)

$$EA = 3043$$

$$F = -14.7(3043) = -44,730 \text{ lb} = -44.7 \text{ K}$$

72 IN TUBE (72 IN ID)

$$EA = 4330$$

$$F = -14.7(4330) = -63,650 \text{ lb} = -63.7 \text{ K}$$

FROM THE PRESSURE AREA, EA, IT WAS DETERMINED THAT THE MEAN DIAM. D_M IS ABOUT 2.25 IN LARGER THAN THE TUBE OD, EX. FOR 48 IN

$$r^2 = \frac{EA}{\pi} = \frac{1983}{\pi}$$

$$r = \left(\frac{1983}{\pi}\right)^{\frac{1}{2}} = 25.12$$

$$D_M = 2r = 50.25 > 48 \text{ IN}$$

FORCES FOR REVISED TUBE DIAMETERS ARE:

44.63 IN TUBE

$$D_M = 44.63 + 2.25 = 46.88 \text{ IN}$$

$$F = p \pi \frac{D_M^2}{4}$$

$$= 11.7 \frac{\pi}{4} (46.88)^2$$

$$= 25,371 \text{ LB} = 25.4 \text{ K}$$

NOTE: FOR ALL SHOT TUBE PILES, THE END PILES FROM COMPRESSED COMPONENT TUBES BEHAVES WHERE THERE IS A CLOSED VALVE OR IT PUSHES ON BRACIS SIDE OR VIBRAC TOWERS BELOW.

48.75 IN TUBE

$$D_M = 48.75 + 2.25 = 51.0 \text{ IN}$$

$$F = 11.7 \frac{\pi}{4} (51.0)^2 = 23,400 \text{ LB} = 23.4 \text{ K}$$

60.5 IN TUBE

$$D_M = 60.5 + 2.25 = 62.75 \text{ IN}$$

$$F = 11.7 \frac{\pi}{4} (62.75)^2 = 45,460 \text{ LB} = 45.46 \text{ K}$$

77.25 IN TUBE


$$D_H = 77.25 + 2.25 = 79.5 \text{ IN}$$

$$F = 14.7 \pi \frac{(79.5)^2}{4} = 64080 \text{ LB} = 64.1 \text{ K}$$

WASHINGTON CORNER SECTION
REF. DWG V-42-5-001 FOR LAYOUT OF
3 BELLOWS

BRACE SECTION CALCULATION

BSE 1




NET FORCE

$$F = 45.5 - 29.5 = 16 \text{ K}$$

NO TENSION ON
FLANGES

102 100 SHEETS
 128 000 SHEETS

B5C2




NO UNBALANCED
LOADS EXCEPT FOR
OFFSETS

NO TENSION ON
FLANGES

4) 1) OFFSET - BEARING ELEVATION SAME
AS USE POA -

B5C3




NET FORCE = 16"

NO TENSION ON
FLANGES

100 SHEETS
 100 SHEETS
 100 SHEETS

BSC 4




$29.44''$
 OFFSET ON
 $2.94''$ (NO EFFECT)

UNBALANCED FORCES
 $F = 45.5 - 29.5 = 16''$
 IN DIRECTION

N- TEN. ON FLANGES


BSC 7



$29.5''$ TO THE LEFT
 FLANGE W/ BSC
 IS VENTED

WHEN LEFT SIDE OF SV2
 IS VENTED, UNBALANCED
 FORCE TO RIGHT IS 16.5''

BSC 8




29.5k TEN ON LOWER FLANGE WHEN BSC IS VERTED

WHEN ABOVE BELOW SVI IS VERTED, UNBALANCED LOAD IS 45.5k TOWARD TOP OF AIR GRAM.


Replacement Center Station Unit,
Horizontal Access Modules

H071




NO TENSION ON FLANGES

HAM 2



NO UNBALANCED FORCE

HAM 3




NO UNBALANCED FORCE*

HAM 4	-	SAME AS HAM 2	-	NO UNBALANCED FORCE*
HAM 5	-	SAME AS HAM 2	-	NO UNBALANCED FORCE
HAM 6	-	SAME AS HAM 1	-	UNBALANCED FORCE = 0.5 IN
HAM 7	-	"	"	"
HAM 8	-	"	HAM 2	NO UNBALANCED FORCE
HAM 9	-	SAME AS HAM 3	-	"
HAM 10	-	"	"	"
HAM 11	-	SAME AS HAM 2	"	"
HAM 12	-	SAME AS HAM 1	-	UNBALANCED FORCE = 0.5 IN

WASHINGTON POWER STATION CONT.

GATE VALVES


GV1



TENSILE FORCE ON VALVE
BOITED FLANGE IS 29.5^k
OR COMPRESSIVE LOAD ON
FLANGE IS 29.5^k WHEN
OTHER SIDE IS VENTED

GV2. SAME AS GV1


GV3



FORCES ON BOITED FLANGES ARE SAME
AS GV1


100 SHEETS
150 SHEETS
200 SHEETS

GV 4




FRAMES AND BOLTED
FRANGES ARE SAME AS GV 1

GV 5



FRAMES IN SECTION
FOR CASE SHOWN

GV 6



TENSION OR COMPRESSION ON WELDED NOZZLE CONNECTION, NO LOAD ON BOLTED FLANGE.


GV 7 SAME AS GV 5

GV 8 SAME AS GV 6

80K LONG PUMPS. SEE SECTION FOR GV 5.
 MAX FLANGE TENSION FOR 44.63 IN FLANGE IS 25.4 K. COMPRESSIVE FORCE IN TUBING HAS SAME MAGNITUDE

WASHINGTON MID STATION
 REF. DWG V049-5-004

BSC




NO UNBALANCED LOAD

GATE VALVES. ALL GV'S AT WA MID STA ARE 4" W/ BOLTED FLANGE CONNECTIONS. MAX TEN ON FLANGE IS SAME AS GV 6 ABOVE, 25.4 K.

148 100 SHEETS
 148 500 SHEETS

WA MID STA (CONT.)


80K SHIRT PUMPS



VALUE AT BEAM TUBE ANCHOR WELDS ON ONE END. SEE GUG ON PREVIOUS SHEET

WALWORTH/LOUISIANA END STATIONS
REF DWG V049-5-005

BSC



GAGE VALUES. ALL VALUES HAVE 44.63 IN TO FLANGES. TENSION FORCE = 25.4K. VALUE AT BEAM TUBE ANCHOR WELDS ON ONE SIDE. SEE GUG FOR WARS


80K SHIRT PUMP. SAME AS ABOVE. MAX FLANGE LOAD = 25.4K TOW OR COMP.

100 SHEETS
200 SHEETS

LOUISIANA CORNER SEAM
 REF DWG V049-5-003

BEAM SPLITTER CHAMBERS

BSC 1



UNBALANCED FORCE
 $= 45.5 \times 0.35 = 16 \text{ K}$

NO TEN ON FLANGES

BSC 2 - SAME AS BSC 1, BUT BSC 2 - NO UNBALANCED LOADS

BSC 3 - SAME AS BSC 1, BUT BSC 3 - 16 K UNBAL. FORCE, NO TENSION ON FLANGES.

HORIZ. ACCESS RISERS

HAM 1 - SAME AS VARS HAM 1, 45.5 K UNBAL. LOAD,

HAM 2 - " " " HAM 2, NO UNBAL. FORCE

HAM 3 - " " " HAM 3, " " " *

HAM 4 - " " " HAM 4, " " " *

HAM 5 - " " " HAM 5, " " " "

HAM 6 - " " " HAM 6, 45.5 K UNBAL. LOAD


* OFFSET = 3.94" ON BSC SIDE

250 SHEETS
 360 DIMENS
 100

LA BEARING (A) UNIT.

GATE VALVES


GV1



FORCE ON FLANGE = 29.5K
TEN OR COMP


GV2 - SAME AS GV1

GV3



FORCE ON FLANGE IS 25.4K
TEN OR COMP.

GV4



FLANGE FORCE = 25.4K
TEN OR COMP

GV5 - SAME AS GV3 . 25.4K FLANGE TEN OR COMP

GV6 - " " " " " " " " " " " "


100 SHEETS
144 260 SHEETS

LA CORNER STA CONT

80K LONG PUMP SIE SHTTL FOR GV3
MAX FLOWING FORCE IS 25.4K TEN OR
COMP.

LA MID POINT

THIS VALVE COMPONENT AT THE LOCATION IS
A BUTT WELDED 48" VALVE



$$F = 29.5K$$


(ASSUMES 5500 PSI)

100 SHEETS
150 SHEETS
200 SHEETS

ATTACHMENT

THE FOLLOWING SHEETS ARE PRELIMINARY
SKETCHES AND DESIGN CALCULATIONS FOR
BALLONS BY SENIOR FLEXONICS, INC.

THE PRESSURE AREA, EA , IS GIVEN
FOR EACH SIZE BALLON.




NOTES:

- 1) BUILT TO EJMA STANDARD
- 2) VISUAL INSPECTION FOR BELLOWS
- 3) VACUUM TEST IS NOT INCLUDED ON BID

Revision 0
 Doc. No. V049-1-032
 Page 18 of 23

No. Req'd. 18

P/N	QTY.	DESCRIPTION	MATERIAL	GENERAL SPECIFICATIONS	CUSTOMER	REV.	
9				DESIGN PRESS. 15 PSIG/FV	SENIOR FLEXONICS INC. EXPANSION JOINT DIVISION New Braunfels, TX PROCESS SYSTEMS		
8				DESIGN TEMP. 347F			
7				SERVICE -			
6	-			EFF. AREA 1983 In. sq			
5	-			EXPANSION -			
4	-			COMPRESSION 1 3/4"			
3	4	BELLOWS ADJUSTMENT RODS 3/4"φ	A479-304L	LATERAL OFFSET -		TITLE 48in BELLOWS	
2	2	WELD ENDS 48"φ 1/4" THK	A240-304L	ANGULAR ROT. -			
1	1	BELLOWS 48"φ 1-PLY 20Ga	A240-304L	TEST PRESSURE SOAP & AIR			
				WEIGHT 182 LBS.			
				THIS DESIGN IS THE PROPERTY OF FLEXONICS THE REPRODUCTION, MANUFACTURE OR USE OF ANY ASSEMBLY, SUB-ASSEMBLY OR PART IS PERMITTED ONLY IF AUTHORIZED BY FLEXONICS.	DRAWN BY: LDC	QUOTE NO.: 5/26/LC	
					DATE: 5/26/95	SK. NO.: C	
						0	




NOTES:

- 1) BUILT TO EJMA STANDARD
- 2) VISUAL INSPECTION FOR BELLOWS
- 3) VACUUM TEST IS NOT INCLUDED ON BID

Revision 0
 Doc. No. V049-1-032
 Page 19 of 23

No. Req'd. 26

P/N	QTY.	DESCRIPTION	MATERIAL	GENERAL SPECIFICATIONS	TITLE	REV.
9				DESIGN PRESS. 15 PSIG/FV	SENIOR FLEXONICS INC. EXPANSION JOINT DIVISION New Braunfels, TX CUSTOMER PROCESS SYSTEMS TITLE 60in BELLOWS - DRAWN BY: LDC QUOTE NO.: 5/26/LC DATE: 5/26/95 SK. NO.: B	0
8				DESIGN TEMP. 347F		
7				SERVICE -		
6	-	-	-	EFF. AREA 3043 in sq		
5	-	-	-	EXPANSION -		
4	-	-	-	COMPRESSION 1 3/4"		
3	4	BELLOWS ADJUSTMENT RODS 3/4"Ø	A479-304L	LATERAL OFFSET -		
2	2	WELD ENDS 60"Ø 1/4" THK	A240-304L	ANGULAR ROT. -		
1	1	BELLOWS 60"Ø 1-PLY 20Ga	A240-304L	TEST PRESSURE SOAP & AIR		
				WEIGHT 225 LBS.		
				THIS DESIGN IS THE PROPERTY OF FLEXONICS. THE REPRODUCTION, MANUFACTURE OR USE OF ANY ASSEMBLY, SUB-ASSEMBLY OR PART IS PERMITTED ONLY IF AUTHORIZED BY FLEXONICS.		




NOTES:

- 1) BUILT TO EJMA STANDARD
- 2) VISUAL INSPECTION FOR BELLOWS
- 3) VACUUM TEST IS NOT INCLUDED ON BID

Revision 0
 Doc. No. V049-1-032
 Page 20 of 23

No. Req'd. 18

P/N	QTY.	DESCRIPTION	MATERIAL	GENERAL SPECIFICATIONS	CUSTOMER		REV.	
9				DESIGN PRESS. 15 PSIG/FV	 SENIOR FLEXONICS INC. EXPANSION JOINT DIVISION New Braunfels, TX PROCESS SYSTEMS			
8				DESIGN TEMP. 347F			TITLE 72in BELLOWS	
7				SERVICE -				
6	-	-	-	EFF. AREA 230 in. sq				
5	-	-	-	EXPANSION -				
4	-	-	-	COMPRESSION 1 3/4"				
3	4	BELLOWS ADJUSTMENT RODS 3/4"φ	A479-304L	LATERAL OFFSET -				
2	2	WELD ENDS 72"φ 1/4" THK	A240-304L	ANGULAR ROT. -				
1	1	BELLOWS 72"φ 1-PLY 20Ga	A240-304L	TEST PRESSURE SOAP & AIR				
				WEIGHT 250 LBS.				
				THIS DESIGN IS THE PROPERTY OF FLEXONICS THE REPRODUCTION, MANUFACTURE OR USE OF ANY ASSEMBLY, SUB-ASSEMBLY OR PART IS PERMITTED ONLY IF AUTHORIZED BY FLEXONICS.		DRAWN BY: LDC QUOTE NO.: 5/26/LC DATE: 5/26/95 SK. NO.: A	0	

SENIOR FLEXONICS
CIRCULAR BELLOWS
(UNREINFORCED SINGLE)

BD

CUSTOMER: PROCESS SYSTEMS

JOB #:

DATE : 5/25/95

48in E.J.

RUN BY: LDC

INPUTED DATA

1) Db = I.D. OF BELLOWS = 48 in
 2) n = NUMBER OF PLYS = 1
 3) t = NOM. THK. OF 1 PLY = .0359 in
 4) q = CONVOLUTION PITCH = 2 in
 5) w = CONV HEIGHT (or OD) = 2.25 in
 6) N = NO. OF CONVOLUTIONS = 2
 7) P = PRESSURE = 15 psig
 8) T = TEMPERATURE = 347 deg F
 9) Lt = LENGTH TANGENT = 1.5 in
 10) tc = THICKNESS OF COLLAR = 0 in
 11) Lc = LENGTH COLLAR = 0 in
 12) ~~Ee = AXIAL EXTENSION = 0 in~~
 13) Ec = AXIAL COMPRESSION = 1.5 in
 14) Y+ = +ve LATERAL OFFSET = 0 in
 15) Y- = -ve LATERAL OFFSET = 0 in
 16) AN = ANGULAR ROTATION = 0 deg

MATERIAL INFORMATION

BELLOWS MATERIAL SECT. VIII
 SA240-304
 C-Mod. of E. = 2.83E+07
 H-Mod. of E. = 2.6865E+07
 Sa = 16412 psi

RESULTS

SPRING RATES

THEORETICAL SPRING RATE = 2,979.37 lbf/in
 WORKING SPRING RATE = 1,604.44 lbf/in
 LATERAL SPRING RATE = 6.077E+05 lbf/in
 LATERAL MOMENT RATE = 1.215E+06 in-lbs/in
 ANGULAR MOMENT RATE = 8,838.58 in-lbs/deg
 TORSION MOMENT RATE = 3.955E+07 in-lbs/deg

STRESSES EJMA

S1 = 7644 psi
 S1' = N/A
 S2 = 3804 psi
 S2' = N/A
 S2'' = N/A
 S3 = 480.5 psi
 S4(.35) = 7007 psi
 S5 = 784.7 psi
 S6 = 140900 psi
 ST = 156000 psi

MOVEMENTS

CONVOLUTION GAP = 0.96410 in/conv.
 COMPRESSION DUE TO AXIAL MOVEMENT = 0.75000
 EXTENSION DUE TO AXIAL MOVEMENT = 0.00000
 AXIAL DISP. DUE TO LATERAL OFFSET = 0.00000
 AXIAL DISP. DUE TO ANG. ROTATION = 0.00000
 MAX. EQUIVALENT AXIAL COMPRESSION = 0.75000
 MAX. EQUIVALENT AXIAL EXTENSION = 0.00000
 MAX. EQUIVALENT AXIAL MOVEMENT = 0.75000

EJMA FACTORS

Cp = .6501
 Cf = 1.463
 Cd = 1.74
 Cr = N/A
 Ct = 1 @
 EA = 1983 in²
 Wt. = 17.34 lbs.
 LCW = N/A

OTHER DATA

CYCLE LIFE = 19,316 cycles
 SQUIRM PRESSURE COLD / 2.25 = 838 psig
 SQUIRM PRESSURE HOT / 2.25 = 795.5 psig
 EQUIV. PIPE WALL THICKNESS = .8706 in

SENIOR FLEXONICS
CIRCULAR BELLOWS
(UNREINFORCED SINGLE)

BD

CUSTOMER: PROCESS SYSTEMS

JOB #:

DATE: 5/25/95

60in E.J.


RUN BY: LDC

INPUTED DATA

- 1) Db = I.D. OF BELLOWS = 60 in
- 2) n = NUMBER OF PLYS = 1
- 3) t = NOM. THK. OF 1 PLY = .0359 in
- 4) q = CONVOLUTION PITCH = 2 in
- 5) w = CONV HEIGHT (or OD) = 2.25 in
- 6) N = NO. OF CONVOLUTIONS = 2
- 7) P = PRESSURE = 15 psig
- 8) T = TEMPERATURE = 347 deg F
- 9) Lt = LENGTH TANGENT = 1.5 in
- 10) tc = THICKNESS OF COLLAR = 0 in
- 11) Lc = LENGTH COLLAR = 0 in
- 12) Ee = AXIAL EXTENSION = 0 in
- 13) Ec = AXIAL COMPRESSION = 1.5 in
- 14) Y+ = '+ve LATERAL OFFSET = 0 in
- 15) Y- = '-ve LATERAL OFFSET = 0 in
- 16) AN = ANGULAR ROTATION = 0 deg

MATERIAL INFORMATION

BELLOWS MATERIAL SECT. VIII
SA240-304
C-Mod. of E. = 2.83E+07
H-Mod. of E. = 2.6865E+07
Sa = 16412 psi



RESULTS

SPRING RATES

- THEORETICAL SPRING RATE = 3,633.83 lbf/in
- WORKING SPRING RATE = 1,945.34 lbf/in
- LATERAL SPRING RATE = 1.131E+06 lbf/in
- LATERAL MOMENT RATE = 2.261E+06 in-lbs/in
- ANGULAR MOMENT RATE = 16,446.06 in-lbs/deg
- TORSION MOMENT RATE = 7.717E+07 in-lbs/deg

STRESSES EJMA

- S1 = 8545 psi
- S1' = N/A
- S2 = 4692 psi
- S2' = N/A
- S2'' = N/A
- S3 = 478.5 psi
- S4(.35) = 7160 psi
- S5 = 769.2 psi
- S6 = 143600 psi
- ST = 161100 psi

MOVEMENTS

- CONVOLUTION GAP = 0.96410 in/conv.
- COMPRESSION DUE TO AXIAL MOVEMENT = 0.75000
- EXTENSION DUE TO AXIAL MOVEMENT = 0.00000
- AXIAL DISP. DUE TO LATERAL OFFSET = 0.00000
- AXIAL DISP. DUE TO ANG. ROTATION = 0.00000
- MAX. EQUIVALENT AXIAL COMPRESSION = 0.75000
- MAX. EQUIVALENT AXIAL EXTENSION = 0.00000
- MAX. EQUIVALENT AXIAL MOVEMENT = 0.75000

EJMA FACTORS

- Cp = .6701
- Cf = 1.506
- Cd = 1.691
- Cr = N/A
- Ct = 1 @
- EA = 3043 in^2
- Wt. = 21.67 lbs.
- LCW = N/A

OTHER DATA

- CYCLE LIFE = 16,408 cycles
- SQUIRM PRESSURE COLD / 2.25 = 1022 psig
- SQUIRM PRESSURE HOT / 2.25 = 970.3 psig
- EQUIV. PIPE WALL THICKNESS = .8706 in

FEEL
w/14A7.

(SAME "I" AS EQUAL LATH. OF PIPE.

SENIOR FLEXONICS
CIRCULAR BELLOWS
(UNREINFORCED SINGLE)

BD

CUSTOMER: PROCESS SYSTEMS

JOB #:

DATE : 5/25/95

72in E.J.

RUN BY: LDC

INPUTED DATA

1) Db = I.D. OF BELLOWS = 72 in
 2) n = NUMBER OF PLYS = 1
 3) t = NOM. THK. OF 1 PLY = .0359 in
 4) q = CONVOLUTION PITCH = 2 in
 5) w = CONV HEIGHT (or DD) = 2.25 in
 6) N = NO. OF CONVOLUTIONS = 2
 7) P = PRESSURE = 15 psig
 8) T = TEMPERATURE = 347 deg F
 9) Lt = LENGTH TANGENT = 1.5 in
 10) tc = THICKNESS OF COLLAR = 0 in
 11) Lc = LENGTH COLLAR = 0 in
 12) Ee = AXIAL EXTENSION = 0 in
 13) Ec = AXIAL COMPRESSION = 1.5 in
 14) Y+ = +ve LATERAL OFFSET = 0 in
 15) Y- = -ve LATERAL OFFSET = 0 in
 16) AN = ANGULAR ROTATION = 0 deg

MATERIAL INFORMATION

BELLOWS MATERIAL SECT. VIII
 SA240-304
 C-Mod. of E. = 2.83E+07
 H-Mod. of E. = 2.6865E+07
 Sa = 16412 psi

RESULTS

SPRING RATES

THEORETICAL SPRING RATE = 4,290.03 lbf/in
 WORKING SPRING RATE = 2,289.71 lbf/in
 LATERAL SPRING RATE = 1.893E+06 lbf/in
 LATERAL MOMENT RATE = 3.787E+06 in-lbs/in
 ANGULAR MOMENT RATE = 27,539.77 in-lbs/deg
 TORSION MOMENT RATE = 1.333E+08 in-lbs/deg

STRESSES EJMA

S1 = 9360 psi
 S1' = N/A
 S2 = 5581 psi
 S2' = N/A
 S2'' = N/A
 S3 = 477.1 psi
 S4 (.35) = 7215 psi
 S5 = 759.1 psi
 S6 = 147900 psi
 S7 = 163400 psi

MOVEMENTS

CONVOLUTION GAP = 0.96410 in/conv.
 COMPRESSION DUE TO AXIAL MOVEMENT = 0.75000
 EXTENSION DUE TO AXIAL MOVEMENT = 0.00000
 AXIAL DISP. DUE TO LATERAL OFFSET = 0.00000
 AXIAL DISP. DUE TO ANG. ROTATION = 0.00000
 MAX. EQUIVALENT AXIAL COMPRESSION = 0.75000
 MAX. EQUIVALENT AXIAL EXTENSION = 0.00000
 MAX. EQUIVALENT AXIAL MOVEMENT = 0.75000

EJMA FACTORS

Cp = .6792
 Cf = 1.535
 Cd = 1.67
 Cr = N/A
 Ct = 1 @
 EA = 4330 in²
 Wt. = 26 lbs.
 LCW = N/A

OTHER DATA

CYCLE LIFE = 15,230 cycles
 SQUIRM PRESSURE COLD / 2.25 = 1206 psig
 SQUIRM PRESSURE HOT / 2.25 = 1145 psig
 EQUIV. PIPE WALL THICKNESS = .8706 in

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-042 PAGE 1 OF 37
REV.	DEO #	DATE	BY:	CHECK	Bolted Flange Analysis For Tensile Forces	
0	1.2.	4/25/96	RDC	AGA		
					BY:	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
PURPOSE: Analyze and evaluate flanges and bolts for large tensile forces resulting from normal operation from venting of parts of systems when gate valves are closed.						
METHOD: Hand calculations for forces using statics analysis. Finite element analysis of bolted flange using IMAGES program.						
ASSUMPTIONS:						
INPUTS: 1. Positive purge pressure = 2 psig. 2. Atmospheric pressure = 14.7 psig. 3. Component interface loads.						
REFERENCES: 1. IMAGES - 3D, Version 3.0, R.L. Cloud and Associates. 2. Calc V049-1-032, Component Interface Loads						
CALCULATIONS: (SEE ATTACHED) Appendix A: Confirmatory Hand Calculations Appendix B: Analysis of Bolt Prying Appendix C: Test Pressure to Observe Flange Behavior Under Tension						
CONCLUSIONS: The 30 1/4 in. flange has the maximum bolt force. The number of bolts is increased to 24 for this flange and the bolt preload is increased to 10,000 lb for all flanges.						
NOTES: Computer file: FLANGEC.*						

SINCE ALL FLANGES HAVE THE SAME THICKNESS AND CROSS-SECTION, EACH DIAMETER FLANGE WILL BE ANALYZED TO FIND THE MAXIMUM BOLT TENSILE FORCE.

REF: CALC V049-1-032 FOR COMPONENT INTERFACE LOADS

104 IN FLANGES (IN BSCS)

THESE ARE NOT AFFECTED BY VALVE OPERATION, THE ONLY TENSILE FORCE OCCURS FROM 2 PSI PURGE PRESSURE ANALYZED IN CALC 19.

54 IN FLANGES (NRM COVERS)

SAME AS 54 IN FLANGE NOT AFFECTED BY VALVE OPERATION

72 1/4 IN FLANGE

THESE ARE LOCATED IN THE BEAM TUBE MANIFOLDS AND IN OTHER ADAPTERS. VALVE AT END OF BEAM TUBE MANIFOLD WILL CAUSE LIFT TENSILE LOAD IN FLANGE WHEN THE BEAM TUBE MANIFOLD IS VENTED. A 2 PSI INTERNAL PURGE PRESSURE WILL ADD TO THE TENSILE FORCE

500
143 100 SHEETS
144 200 SHEETS

72 1/4 IN CONT.

DWG V049-5-003 SHOWS SPACE A2 w/ UNBALANCED VALVE FORCE WHEN SYSTEM IS VENTED ON 1 SIDE OF VALVE.
G = 76" CALL-019, P.10

$$F = 29.44 + \pi \frac{76^2}{4} \left(\frac{2}{1000} \right) = 32.76 \text{ K}$$

↑ 2 PSI PULL

PER BOLT

$$N = 36$$

$$F_b = \frac{32.76}{36} = .91 \text{ K}$$

BOLT CIRCULAR DIAM

$$D_b = .7775 \text{ REC P. 9 OF CALL-019}$$

$$\text{SPACING } S = \pi \frac{D_b}{36} = 6.78 \text{ IN}$$

FORCE PER IN


$$f = \frac{.91}{6.78} = 135 \text{ LB/IN}$$

* SEE SKETCH ON FOLLOWING SHEET FOR 60 1/2 IN FLANGE. FORCE DIAGRAM IS SIMILAR.

50 SHEETS
100 SHEETS
200 SHEETS
300 SHEETS
400 SHEETS
500 SHEETS
600 SHEETS
700 SHEETS
800 SHEETS
900 SHEETS
1000 SHEETS

60 1/2 IN FLANGES

THE ONLY FLANGES OF THIS SIZE THAT ARE SUBJECTED TO TENSILE FORCES ARE THOSE IN PORTS OF BSCs 7 AND 8 OF THE WASHINGTON (LOWER STATION) (SEE CALL V049-1-032). IN ADDITION TO THE 29.44" VALVE FORCE, WHICH OCCURS WHEN THE VALVE IS CLOSED AND THE BSC IS VENTED, A 2 PSIG PRESSURE WILL INCREASE THE FLANGE FORCE



GROSS DIAM FOR 60.5 IN FLANGE IS 64 IN

$$F = 29.44 + \pi \frac{64^2}{4} (2) \left(\frac{1}{1000} \right) = 35.9 \text{ K}$$

THIS FLANGE HAS 30 BOLTS, FORCE PER BOLT IS

$$F_b = \frac{35.9}{30} = 1.20 \text{ K}$$

SPACING

$$s = \frac{\pi D_b}{30}$$

20 101 50 SHEETS
 21 142 100 SHEETS
 22 164 200 SHEETS

$$D_3 = \text{BOLT CIRCULAR DIAM.} \\
= 65.75 \quad \text{REF P. 12 CALL V049-1-019}$$


$$S = \frac{\pi (65.75)}{30} \\
= 6.89 \text{ IN}$$

FORCE PER IN OF CIRCUMFERENCE

$$\frac{1}{S} = \frac{1.20}{6.89} = 174 \text{ (lb) IN}$$

48 1/4 IN FORCE

THE MAXIMUM FLANGE FORCE DUE TO PRESSURE IS 29.44 K (PAGE 032)



$$F = 29.44 + \pi \frac{52^2}{4} \frac{2}{1000} = 33.7 \text{ K}$$

← CASSET DIAM. *

FOR 24 BOLTS

$$\frac{F}{B} = \frac{33.7}{24} = 1.40 \text{ K PER BOLT}$$

* REF P. 16 CALL V049-1-019

100 SHEETS
100 SHEETS

SPACING

$$S = \frac{\pi C}{24}$$

$$C = 53.75' \quad \text{PIPE DIA, P. 15}$$

$$S = \frac{\pi (53.75)}{24} \\ = 7.04 \text{ IN}$$

FIBRE PER IN

$$f = \frac{1140}{7.04} = .159 \text{ K} = 159 \text{ LB/IN}$$

44.63 IN FIBRE

$$F = 25.37 + \pi \frac{48^2}{4} \left(\frac{2}{1000} \right)$$

$$= 29.0 \text{ K}$$

$$F_B = \frac{29}{24} = 1.21 \text{ K}$$

$$S = \frac{\pi (49.75)}{24} = 6.51$$


$$f = \frac{1.21}{6.51} = .186 = 186 \text{ LB/IN}$$

← FROM PIPE DIA, P. 19

THE 48 1/4 IN FLANGE HAS THE MAX BOLT FORCE (1.40 K)* AND THE MAX FORCE PER IN OF CIRCUMFERENCE (199 LB/IN).

THIS FLANGE WILL BE ANALYZED USING THE MODEL GENERATED IN CALL V049-1-017. FILE FLANGE.* OF CALL 017 WAS COPIED TO FLANGE C.* FOR THIS ANALYSIS.

NODAL FORCE AT SHELL



FROM CALL 017, P.2

$$F_y = 52.1 \text{ LB/IN} \quad \& \quad F_{y_i} = 13.4 \text{ LB}$$

AT INTERIOR NODES

$$F_{y_i} = 13.4 \left(\frac{199}{52.1} \right) = 51.2 \text{ LB}$$

@ NODES 1366 TO 1546, INC = 15

* SEE LATER SHEETS FOR ANALYSIS OF 30 1/4 IN FLANGE

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



$$F_y = 6.7 \left(\frac{199}{52.1} \right) = 25.6 \text{ LB}$$

NODES 1351 & 1561
IN FLANGE FILE

PRE LOAD

FPL = 8500 LB PER BOLT
 OR FPL = 8500 / 2 = 4250 FOR 1/2 BOLT
 $F_{yi} = -375 + \frac{4250}{6000} \leftarrow \text{CALL 17, P. 3}$
 = -266 LB

@ NODES 1374, 1375, 1377, 1378,
 1389 TO 1393
 1414 TO 1418

$$F_y = \frac{-266}{2} = -133 \text{ LB}$$




@ NODES 1359, 1360, 1362, 1363

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



IMAGES-3D
Version 3.0

48 114 10 FIGURE



Revision 0
Doc. No. V049-1-042
Page 9 of 37




Load Case
1

Stress Contour Plot
Stress Intensity

1/ 5/96
7:51: 9

IMAGES-3D
Version 3.0

48 1/4 IN FLANGE




Revision 0
Doc. No. V049-1-042
Page 10 of 37

Load Case
1

Displacement Contour Plot
DY


1/ 5/96
7:29:53

IMAGES-3D
Version 3.0



DISPLACEMENT AT POINT O-RING
48 IN DIAMETER

Q Bolt



→ Sym.

→ MAXIMUM PLATE DISPLACEMENT
SAME AS ABOVE

$$\Delta = 2(.058)(.00119) = .00119$$


COMPARE TO MAX COMPRESSION OF O-RING
FROM PLATE HARDNESS (.058 IN)

$$RATIO = \frac{.058}{.00119} = 49$$

IMAGES-3D
Version 3.0



Displacements at Inner O-Ring
4x 174 in diameter





$$\Delta = 2 (.130)(10)^{-2} = .26(10)^{-2}$$

$$\text{Ratio} = \frac{.058}{.0026} = 22$$

σ_y @ MAXIMUM SURFACE (Y=0)

48/14 IN PLANE

IMAGES-3D
Version 3.0



COOR. ←

Revision 0
Doc: No V049-1-042
Page 13 of 37

Load Case
1


Stress Contour Plot
GI St: S22

1/ 5/96
7:54:49

48 1/4 IN FLANGE CONT.

BOLT FORCE RESULTING FROM FLANGE DEFORMATION UNDER TENSILE LOAD

THE BOLT WILL BE PRELOADED TO 8500 LB WHICH WAS INPUT TO THE FLANGE IT IMAGE FILE. WHEN THE FLANGE IS LOADED IN TENSION FROM PRESSURE OR COMPONENT LOAD, THE FLANGE DEFORMS SLIGHTLY AND THE BOLT FORCE CHANGES. THE CHANGE CAN BE ESTIMATED CONSERVATIVELY BY ADDING THE AXIAL BOLT STRAIN FROM THE FLANGE IT OUTPUT TO THE PRELOD STRAIN (STRESS).



Δy = DEFORMATION AT NUT FOR PRELOD PLUS F_y FROM DISPLACEMENT CONTROL PLOT

$$\Delta y = .172(10)^{-4} \text{ IN MAX}$$

FOR 1 IN FLANGE THICKNESS, STRAIN IS

$$\epsilon = \frac{\Delta y}{1} = .172(10)^{-4}$$

BOLT STRESS

$$\begin{aligned} f_a &= E \epsilon = 29(10)^6 \times .172(10)^{-4} \\ &= 500 \text{ PSI} \end{aligned}$$

48 1/4 IN FLANGE APERT.

TIRE TENSILE STRESS AREA FOR THE BOLT IS .462 IN² * FOR THE 7/8 IN BOLT. FORCE IS

* REF AISC, P. 4-147

$$F = .462 (500) = 231 \text{ LB}$$

TO OBTAIN A CONSERVATIVE BOLT STRESS, THE NOMINAL BOLT FORCE FROM TIRE TENSION, F_T , ON THE 48 1/4 IN FLANGE WILL BE ADDED TO THE APPLIED

$$F_{TOTAL} = F_0 + F_{AL}$$


$$= 1.72 + 8.50 \text{ K}$$

$$= 10.22 \text{ K}$$

STRESS

$$f_c = \frac{10.22}{.462} = 22.1 \text{ KSI} < S = 25 \text{ KSI @ } 400^\circ\text{F}$$


OK



50 SHEETS
100 SHEETS
200 SHEETS

30.25 IN FLANGES

FOR THE HODE CLEANER TUBES (SPOOL B-3,
Dwg V049-4-133) THE 30.25 IN FLANGE
IS UNDER TENSION DURING NORMAL OPERATION



$$P = -14.7 \text{ psi}$$

$$F_1 = \text{FORCE AT } 60.5 \text{ IN FLANGE} \\ = -45,416 \text{ K} \quad \text{CALL -032, P. 4}$$

$$F_2 = \text{FLANGE FORCE (TGD)}$$

$$F_3 = PA$$

$$A = \pi r_0^2$$

$$r = \frac{G}{2} = \frac{34}{2} = 17 \quad \begin{array}{l} G = \text{GASKET DIA} \\ \text{REF p. 22 OF CALL} \\ \text{V049-1-019} \end{array}$$

$$F_3 = -14.7 \pi (17)^2 = -13.35 \text{ K}$$

$$F_1 + F_2 - F_3 = 0$$

$$F_2 = F_3 - F_1 = -13.35 - (-45,416) \\ = 32,11 \text{ K}$$

FOR F_3 USE INNER O-RING DIAMETER
 IN CASE OUTER O-RING LEAKS. THIS
 GIVES MAX. FLANGE FORCE F_2

$$F_3 = -14.7 \pi \left(\frac{31}{2} \right)^2 \quad \text{DWG V048-4-016}$$

$$= -11.10 \text{ K}$$

$$F_2 = -11.10 - (-45.46) = 34.36 \text{ K}$$

FOR $N = 20$ BOLTS

$$F_2 = \frac{34.36}{20} = 1.72 \text{ K PER BOLT}$$

SPACING

$$S = \frac{\pi C}{20}$$

$$C = 36 \text{ * 3017 HOLE DIA - DWG V049-4-016}$$

$$S = 5.65 \text{ IN} \quad \text{* ACTUAL CHANGED TO 35.75 - DOES NOT AFFECT FINAL RESULT}$$

FORCE PER IN

$$f = \frac{F_2}{S}$$

$$= \frac{1.72}{5.65} = 304 \text{ LB/IN}$$

FORCE PER IN AT SHELL

$$d = 30.25$$

$$f = \frac{F_2}{\pi d}$$


$$= 362 \text{ LB/IN}$$

30 1/4 IN FLANGE CASE

THE 30 1/4 IN FLANGE HAS THE MIN. STRESS FORCE (1.72 K) AND THE MIN. FLANGE AREA IN OF CIRCUMFERENTIAL (362 LB/IN) IN THE SHELL.

THIS FLANGE WILL BE ANALYZED USING THE FLANGE C, * MODEL

NODAL FORCE AT SHELL



FROM CALL OUT, P. 2

$$F_y = 52.1 \text{ LB/IN} \quad \& \quad F_{y_i} = 13.4 \text{ LB}$$

AT INTERIOR LINES

$$F_{y_i} = 13.4 \left(\frac{362}{52.1} \right) = 93.1 \text{ LB}$$

@ NODES 1366 TO 1546, INC = 15

30 1/4 IN FLANGE CONT

$$F_y = 6.7 \left(\frac{362}{57.1} \right) = 46.6 \text{ LB}$$

MODES 1351 & 1561

IN FLANGE FILE

A PRELIMINARY RUN OF FLANGE SHOWED
THAT IT IS NECESSARY TO INCREASE THE
PAYLOAD TO 10000 LB FOR THE
30 1/4 IN FLANGE

CHANGE BOLT PATTERN FROM 8500 TO
10000 LB FOR THE 30 IN FLANGE




NOSE	FORCE* FOR 8500 LB F ₁	FORCE FOR 10000 LB F ₁	$\frac{10}{8.5} = 1.176 = \text{FACTOR}$ ON 8500 LB BOLTS
1359	-133	-156	
1360	-133		
1362	-133		
1363	-133		
1374	-266	-313	
1375	-266		
1377	-266		
1378	-266		
1389	-266		
1390	-266		
1391	-266		
1392	-266		
1393	-266		
1404	-266		
1405	-266		
1406	-266		
1407	-266		
1408	-266		

REF. P. 8
THIS CALL

* REF. P. 8 OF THIS CALL

IMAGES-3D
Version 3.0

30 1/4 IN FLANGE






Load Case
1

Stress Contour Plot
Stress Intensity

2/ 2/96
9:13:50

IMAGES-3D
Version 3.0

30' IN IN FLANGE



Revision 0
Doc No. V049-1-042
Page 22 of 37

Load Case
1




Displacement Contour Plot
DY

2/ 2/96
9:17:45

IMAGES-3D
Version 3.0

30 1/4 IN FLANGE

DISPLACEMENT AT FLANGE O-RING



Revision 0
Doc. No. V049-1-042
Page 23 of 37


Load Case
1

Displacement Contour Plot
DY


2/ 2/96
9:21: 9

30 1/4 IN HOLE

IMAGES-3D
Version 3.0



↓
Load



Revision 0
Doc. No. V049-1-042
Page 24 of 37

Load Case
1

Stress Contour Plot
GI St: S22

2/ 2/96
9:24: 0

50 SHEETS
100 SHEETS
200 SHEETS

30 1/4 IN FLANGE CONT

MAX STRESS INTENSITY

$$S_{I \text{ MAX}} = 18.4 \text{ ksi}$$

VERY LOCAL, UNDER NOT

MAX FLANGE DISPLACEMENT OCCURS AT
INNER O-RING IN Y-DIRECTION

$$\Delta = .00372 \text{ IN} \quad \text{SEE IMAGES OUTLINE P. 23}$$

FOR 2 FLANGES, THE GAP OPENING
IS $2 \times \Delta = .0074 \text{ IN}$. THIS COMPARES
TO THE MIN O-RING COMPRESSION, .058 IN.

$$\text{RATIO} = \frac{.058}{.0074} = 7.8$$

NOTE: THE MODEL IS CONSERVATIVE FOR
THIS CASE BECAUSE THE BOLT SPACING
FOR THE 30 1/4 IN FLANGE WITH
20 BOLTS IS 5.62 IN BUT THE MODEL
BOLT SPACING IS 7.2 IN.

$$\Delta_y \approx .00015 \text{ AT NOT}$$

$$\text{BOLT STRAIN } \epsilon = \frac{.00015}{1} = .00015$$

INCREASED STRESS

$$f_a = .00015(29)(10^3) \\ = 4.4 \text{ ksi}$$

12-141 50 SHEETS
12-142 100 SHEETS
12-144 200 SHEETS

FOR THE 10^K PRELOAD, THE STRESS IS

$$f_a = \frac{10}{.462} = 21.6 \text{ KSI}$$

REF: AISC B. 1-147 FOR
TENSILE AREA = .462 IN²

TOTAL STRESS IS

$$f_a = 21.6 + 4.4 = 26 \text{ KSI SAY } \approx 25$$

OR WHEN THE BOLT APPLIED LOAD
IS ADDED TO PRELOAD

$$f_a = \frac{10 + 1.72}{.462} = 25.4 \text{ KSI } \approx 25 \text{ OK}$$

CHANGE NO. OF BOLTS TO 24

$$F_b = \frac{34.36}{24} = 1.43$$


$$f_a = \frac{10 + 1.43}{.462} = 24.7 < 25$$

BOLT SPACING IS

$$s = \frac{\pi C}{24} = \frac{\pi (36)}{24} = 4.71 \text{ IN } \text{ OK}$$

FORCE PER IN AT SHELL IS STILL 362 LB/IN

STRESS IN FLANGE TO STEEL WELD



50 SHEETS
100 SHEETS
200 SHEETS

THE PARTIAL PENETRATION WELD IS 1/8" THICK. NEGLECT STITCH WELD AND ASSUME THAT ALL LOAD IS TRANSMITTED THROUGH PARTIAL PEN WELD.

$$f_c = \frac{F_y}{.125}$$


$$= \frac{362}{.125} = 2900 \text{ psi OR}$$

REF p. 17 OF THIS PAGE
FOR $F_y = 362 \text{ LB/IN}$

Appendix A

CONFIDENTIAL HAND MADE TO VERIFY
 LARGES RESULTS FOR FLANGE TENSION.

DERIVATION & STRESS IN A 1 IN STRIP
 FLANGE FOR O-RING PRESS



CLAMPING
 ASSUMED AROUND
 ENTIRE RING

FOR A 1-IN STRIP

$$I = \frac{wt^3}{12}$$

w = MAX FLANGE WIDTH TO COMPRESS O-RING
 THE NOMINAL DIAMETER IS 1/4" FROM THE
 PARTS HANDBOOK, P A 5-13 THE MAX "SQUEEZE"
 IS 27%, FROM P A 4-11 THE MAX FLANGE
 PER IN DIA DUCTURE 90 IS

$$w = 170 \text{ LB/IN}$$

FROM DUCT V049-4-016 ← OUTER O-RING DIA

$$S_o = \frac{36}{2} - .5 - \left(\frac{.34}{2} + \frac{.34}{2} \right)$$

$$= .37 \text{ IN}$$

$$S_i = \frac{36}{2} - .5 - \left(\frac{.31}{2} + \frac{.34}{2} \right)$$

$$= 1.83 \text{ IN}$$

✓ .775' CROSS SECTION

Since S_0 is small, ignore initial bending force.

DEFLECTION

$$\Delta = \Delta_b + \Delta_s$$

$$\Delta_b = \text{BENDING DEFLECTION}$$

$$= \frac{w S_0^3}{3EI}$$

$$= \frac{170 (1.83)^3}{3(24.8 \times 10^6) \left(\frac{t^3}{12}\right)}$$

$$= \frac{1.45 (10)^{-4}}{t^3}$$

$$\Delta_s = \text{SHEAR DEFLECTION}$$

$$= \frac{w S_0}{AG}$$

$$A = t(1) = t$$

$$G = \frac{24.8 (10)^5}{2(1+\nu)} = 11.1 (10)^5 \text{ psi}$$

$$\Delta_s = \frac{170 (1.83)}{t (11.1 \times 10)^5} = \frac{.28 (10)^{-4}}{t}$$

$$\Delta = \frac{1.45 (10)^{-4}}{t^3} + \frac{.28 (10)^{-4}}{t}$$

10 SHEETS
 100 SHEETS
 200 SHEETS

For $t = 1$

$$\Delta = (1.45 + .28)(1.0)^{-4} = 1.73(1.0)^{-4}$$

For $t = 7/8 = .875$

$$\Delta = \frac{1.45(1.0)^{-4}}{(.875)^2} + \frac{.28(1.0)^{-4}}{.875} = 2.41(1.0)^{-4}$$

For $t = 3/4 = .75$

$$\Delta = \frac{1.45(1.0)^{-4}}{(.75)^2} + \frac{.28(1.0)^{-4}}{.75} = 3.42(1.0)^{-4}$$

MIN COMP OF D RINGS IS OBTAIN (PARISH HANDBOOK, P 45-13). FOR MINIMUM FLANGE, ASSUME THAT Δ DOUBLES.

 $t = 1$

$$\Delta = (2)1.73(1.0)^{-4} = 3.46(1.0)^{-4}$$

$$\text{RATIO} = \frac{.058}{3.46(1.0)^{-4}} = 168$$

 $t = 3/4$

$$\Delta = 2(2.41)(1.0)^{-4} = 4.82(1.0)^{-4}$$

$$\text{RATIO} = \frac{.058}{4.82(1.0)^{-4}} = 117$$

$t = 3/4$

$\Delta = (2)3.42(1.0)^{-2} = 6.84(1.0)^{-2}$

$RATIO = \frac{.052}{6.84(1.0)^{-2}} = 85$

ADD MAXIMUM TENSILE FORCE TO @. RING LOAD, THIS IS 362 LB/IN FOR THE 20 1/4 IN FLANGE

$W = 170 + 362 = 532$

RATIOS ARE

IMPOSED BY THE TUBES WITH RESULTS

$t = 1 \text{ IN} \quad R = 168 \left(\frac{170}{532} \right) = 54$

$t = 7/8 \quad R = 117 \left(\frac{170}{532} \right) = 37$

$t = 3/4 \quad R = 85 \left(\frac{170}{532} \right) = 27$

MAX BENDING STRESS

$M = W S_c =$
 $= 532(1.83) = 974$

$t = 1$

$S_b = \frac{974(1.5)}{1^3/12} =$
 $= 5844 \text{ psi}$

$$t = 7/8$$

$$f_b = \frac{974 \left(\frac{.875}{2} \right)}{\frac{(.175)^3}{12}}$$

$$= 7630 \text{ psi}$$

$$t = 3/4$$

$$f_b = \frac{974 \left(\frac{.75}{2} \right)}{\frac{.175^3}{12}}$$

$$= 10400 \text{ psi}$$

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



P.W.Y.

PST

L160 FLANGES

1/17/96

SAI
1/13


Given: L160 flanges of various sizes

Req'd:

look @ a typical flange
say a 60 1/4" flange and determine
if there are any significant prying
forces when the flange is put into
tension. Reference previous analysis
by Ray Ciatto 1/3/96

Reference AISC 9th edition pages 4-90, 4-91.

Solution:



$$a = 1.0" \quad a' = 1.0 + \frac{.875}{2} = 1.4375"$$

$$b = 2.5" \quad b' = 2.5 - \frac{.875}{2} = 2.0625"$$

T+Q is total bolt tension force including prying
where Q is the prying force.

APPENDIX B

now calculate same constants

$$P = \frac{\pi(65.75)}{30} = 6.89'' \text{ trib width per bolt.}$$

$$d' = 1.0'' ; \delta = 1 - \frac{d'}{P} = 1 - \frac{1}{6.89} = 0.855$$

$$d = 0.875 \text{ bolt diameter}$$

$$f = \frac{b'}{d'} = \frac{2.0625}{1.4375} = 1.4348$$

now since $\sigma_{allow} = 25 \text{ ksi}$
bolts

then $B = 25(0.755)^2 / 4 \pi = 11.192 \text{ K}$

↖ root diameter of bolt (7/8" OD)

$$T = 3509 / 30 = 1.2 \text{ K force/bolt in 30 bolts}$$

and $B = \frac{1}{f} \left(\frac{B}{T} - 1 \right)$

$$= \frac{1}{1.4348} \left[\frac{11.192}{1.2} - 1 \right] = 5.803 > 1.0$$

$$\Rightarrow \alpha' = 1.0 \quad T$$

then $t_{fly} = \sqrt{\frac{8(1.2)(2.0625)}{6.89(36)(1+0.855(1.0))}}$

for the actual
force T

$$= 0.2075'' < 1.0'' \text{ actual fly thickness}$$

APPENDIX C

TEST PRESSURE TO OBSERVE FAILURE BEHAVIOR UNDER TENSION
 10" TEST NUMBER - REF DATA V049-4-030

HYDRO PRESSURE REQUIRED TO GIVE
 3K AIR BOLT

NOTE: MAX BOLT LOAD = 1.72K FOR 30 1/4" FLANGE
 SA X 2K. INCREASE BY 50% FOR
 HYDROSTIC

$$1.5 \times 2K = 3K$$

$$PA = 3N$$

$$N = 6 \text{ BOLTS}$$

$$A = \pi r^2$$

$$r = 5$$

$$P \pi (5)^2 = 3(6) = 18K$$

$$P = .229 K/IN^2$$

$$= 230 \text{ PSI}$$

HOOP STRESS IN CYL

$$\sigma_0 = \frac{Pr}{t}$$

$$t = 7/16$$

$$\sigma_0 = \frac{230(5)}{7/16} = 6133 \text{ PSI OK}$$

FOR 1/8 IN FILLET CONNECTING FLANGE TO CYL

$$A_w = \pi(10)(.125)(.707) = 2.8 \text{ IN}^2$$

WELD STRESS

$$f_v = \frac{18}{2.8} = 6.5 \text{ KSI OK}$$

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



MAXIMUM BENDING STRESS IN 10" FLAT PLATE:

$$\sigma_M = 1.24 \frac{P r^2}{t^2}$$

$$= 1.24 \frac{(230)(5)^2}{(.5)^2}$$

$$= 28500 \text{ psi}$$

OK
FOR HYDRO

now

Calculate t_c =
 req'd thickness
 of flange to develop
 the full allowable
 flange force B

$$t_c = \sqrt{\frac{8BB'}{PF_y}}$$

$$= \sqrt{\frac{8(11.192)(2.0625)}{6.89(36)}}$$

$$= .863''$$

again actual thickness is $t = 1.0''$
 actual

now $\alpha = \frac{1}{8} \left[\frac{T/B}{(t/t_c)^2} - 1 \right]$

$$= \frac{1}{.855} \left[\frac{1.02/11.192}{(1/.863)^2} - 1 \right]$$

$$= -1.076$$

since this is neg, set $\alpha = 0$

$$\therefore Q = B S \alpha P \left(\frac{t}{t_c} \right)^2 = 0$$

or there is no prying force
 of any significance.

now

Calculate
req'd thickness
of flange to develop
the full allowable
flange force B

$$t_c = \sqrt{\frac{8Bb'}{PF_y}}$$

$$= \sqrt{\frac{8(11.192)(2.0625)}{6.89(36)}}$$

$$= 0.863''$$

again actual thickness is $t = 1.0''$
actual

now

$$\alpha = \frac{1}{\delta} \left[\frac{T/B}{(t/t_c)^2} - 1 \right]$$

$$= \frac{1}{0.855} \left[\frac{1.02/11.192}{(1/0.863)^2} - 1 \right]$$

$$= -1.076$$

since this is neg, set $\alpha = 0$

$$\therefore Q = B \delta \alpha P \left(\frac{t}{t_c} \right)^2 \equiv 0$$

or there is no prying force
of any significance.

PROCESS SYSTEMS INTERNATIONAL, INC.
WESTBOROUGH, MA

ENGINEERING
CALCULATIONS

NO: V049-1-071

PAGE 1 OF 19

REV.	DEO #	DATE	BY:	CHECK
	0128	3-18-96	AGR	RSC

TITLE:
PIPE BRIDGE CORNER STATION

By: ART ROUSSOPOULOS DEPT.: 744

PROJECT: LIGO

PROJECT NO: V59049

PURPOSE: ANALYZE PROPOSED PIPE BRIDGE FOR AISC
COMPLIANCE.

METHOD: STAAD 3 STRUCTURAL COMPUTER SOFTWARE

ASSUMPTIONS: SEE CALCS

INPUTS: "STRUCTURAL DESIGN CRITERIA" REF: DOC. NO. V049-1-066
"DESIGN OF SUPPORT BASE PLATES" DOC. NO. V049-1-024
LIGO PIPE BRIDGE SKETCH SH# 2+3 - REF: V049-4-043 SH# 1 OF 3

Doc. No. V049-1-066, LIGO VAC. EQUIP. STRUCT. DESIGN CRITERIA

REFERENCES: • DWG. V049-4-043 • AISC - 9TH. ED., 3RD. IMP. 1/90
• STAAD3
• HILTI-TECH GUIDE - "ANCHOR + POWDER ACTUATED FASTENING
PUBLICATION # H-427 2/87

CALCULATIONS: (SEE ATTACHED)

CONCLUSIONS: SUBJECT PIPE BRIDGE WITH REVISED 6X4X1/4 MEMBERS IS ACCEPTABLE
• ONLY TWO (2) ANCHOR BOLTS ARE REQUIRED PER PLATE
• ALL WELDS SHALL BE 3/16" FILLET EXCEPT WHEN NOTED.

NOTES: STAAD 3 FILE NAME ARTROU.STD FILED IN DIRECTORY \41896\

TABLE OF CONTENTS

	<u>PAGE</u>
1. - STAAD 3 INPUT	3
• DENSITY	
• E	
• ν	
• SEISMIC	
• PIPE LOADS	
• SEISMIC LOADS	
- PILING	
- PIPE BRIDGE STEEL TUBING	↓
• MODEL FOR PIPE LOADS	4
• MODEL FOR SEISMIC LOADS	5
2. - ANCHOR/PLATES	6
• REACTION LOADS	6
• SUMMARY OF BASE PLATE/ANCHOR REACTIONS	6
• ALLOWABLE LOAD	7
3. - BASE PLATE QUALIFICATION	7
• REQUIRED PLATE THICKNESS	7
• CONCLUSIONS	8
4. - STAAD 3 COMPUTER MODEL INPUT/OUTPUT	9-18
ATTACHMENT: MARKED UP LGS DWG	19
V.049-4-043	

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



REVO
Doc. NO. V049-1-071
P. 2 OF 19

1. - STAAD 3 INPUT:

- DENSITY = .283 #/IN³
- MODULUS OF ELASTICITY $E = 29 \times 10^6$ PSI
- POISSON $\nu = .3$
- SEISMIC = .05625 g
- PIPE LOADS - (REF: 460 PIPE BRIDGE SKETCH SHEET 3043)

$$\begin{aligned} F_1, F_3 &= (1100/2) = 550 \# & F_2 &= 1100 \# \\ F_4 &= 40 \# \\ F_5 &= 40 \# \\ F_6 &= 40 \# \\ F_7 &= 90 \# \\ F_8 &= 90 \# \\ F_9 &= 150 \# \\ F_{10} &= 90 \# \\ F_{11} &= 150 \# \end{aligned}$$

- SEISMIC LOADS F_x, F_z

- PIPING:

$$\begin{aligned} F_1, F_3 &= 550(.05625) = 31 \# & F_2 &= 1100(.05625) = 62 \# \\ F_4 &= 40(.05625) = 2.25 \# \\ F_5 &= 40(.05625) = 2.25 \# \\ F_6 &= 40(.05625) = 2.25 \# \\ F_7 &= 90(.05625) = 5.063 \# \\ F_8 &= 90(.05625) = 5.063 \# \\ F_9 &= 150(.05625) = 8.44 \# \\ F_{10} &= 90(.05625) = 5.063 \# \end{aligned}$$

- PIPE BRIDGE STEEL TUBE (SEE MODEL P. 3+4)

ELEMENT DEADWEIGHT:


- 100, 200, 103 + 203: $8 \times 6 \times 1/4 \times 108$ " LONG EACH
 $WT = [(22.42 \# / FT) / 12] \times 108 = 201.8 \#$ EACH
- 300, 302 + 304: $8 \times 6 \times 1/4 \times 72$ " LONG EACH
 $WT = (22.42 / 12) \times 72 = 134.5 \#$ EACH
- 101, 102, 201 + 202: $8 \times 6 \times 1/4 \times 102$ " LONG EACH
 $WT = (22.42 / 12) \times 102 = 190.6 \#$ EACH
- 301 + 303: $4 \times 3 \times 1/4 \times 124.85$ " LONG EACH
 $WT = (10.51 / 12) \times 124.85 = 109.3 \#$ EACH

SEISMIC LOADS:

- 100, 200, 103 + 203: $F_x, F_z = 201.8(.06) = 12.1 \#$
- 300, 302 + 304: $F_x, F_z = 134.5(.06) = 8.07 \#$
- 101, 102, 201 + 202: $F_x, F_z = 190.6(.06) = 11.1 \#$
- 301, 303: $F_x, F_z = 109.3(.06) = 6.6 \#$



STAAD - MODEL FOR PIPEBRIDGE, REF. DWG. VOI 4-043
 PIPING LADS:




LOADS	
F1	= 550 #
F2	= 1100 #
F3	= 550 #
F4	= 40 #
F5	= 40 #
F6	= 40 #
F7	= 90 #
F8	= 90 #
F9	= 150 #
F10	= 150 #

REV D
 Doc. No. Y049-1-071
 P. 11 OF 19

REV D
 Doc. No. Y049-1-071
 P. 4 OF 19

STAAD - MODEL FOR PIPEBRIDGE
SEIS LOADS



REV 0
DOC. NO. V049-1-071
P. 5 OF 19

REV 0
Doc. No. V049-1-071
P. 5 OF 19

STAAD3 - RESULTS: (SEE OUTPUT P.8-17)

- MAXIMUM WELD SIZE OF 7/16" L3/16 MINIMUM ∴ OK
- ALL STEEL TUBE ELEMENT MEMBERS PASS AISC ACCEPTANCE CRITERIA ∴ THE PIPE BRIDGE WITH REVISED FROM 8X6 X 1/4 TO 6X4X1/4 MEMBERS IS ACCEPTABLE
- A MAXIMUM JOINT DISPLACEMENT OF .27606" OCCURS AT JOINT 30 (SEE P. 12)
.27606" IS DEEMED ACCEPTABLE

2. - ANCHOR / PLATES: - LOCATED AT NODES 10, 50, 60 + 100

- DESIGN OF ANCHOR / SUPPORT BASE PLATES SHALL BE BASED ON THE DESIGN METHODOLOGY FOUND IN DOC. NO. V049-1-029
- REACTION LOADS FROM STAAD3 OUTPUT P.

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM Z
10	1	50.70	390.45	-3.30	0.00	0.00	0.00
	2	144.50	3454.01	-215.09	0.00	0.00	0.00
	3	195.20	3844.46	-218.39	0.00	0.00	0.00
50	1	-50.70	390.45	-3.30	0.00	0.00	0.00
	2	-464.87	3698.52	-182.35	0.00	0.00	0.00
	3	-515.56	4088.97	-185.65	0.00	0.00	0.00
60	1	49.03	390.45	3.30	0.00	0.00	0.00
	2	42.51	566.27	-128.68	0.00	0.00	0.00
	3	91.54	956.72	-125.38	0.00	0.00	0.00
100	1	-49.03	390.45	3.30	0.00	0.00	0.00
	2	-340.81	951.20	-92.55	0.00	0.00	0.00
	3	-389.84	1341.64	-89.25	0.00	0.00	0.00

SUMMARY OF BASE PLATE / ANCHOR REACTIONS

LOAD	NODES			
	10	50	60	100
F _x (#)	195	-516	92	-390
F _y (#)	3845	4089	957	1342
F _z (#)	-218	-186	-125	-89

- VERTICAL LOADS ARE ALL COMPRESSIVE ∴ ONLY HORIZONTAL SHEAR LOADS ARE IMPOSED ONTO ANCHOR BOLTING.
- ANALYZE NODE 50 FOR WORSE CASE LOADING
- MAXIMUM SHEAR LOAD:


$$F_s \text{ MAX} = [F_x^2 + F_z^2]^{1/2} = [(-516)^2 + (-186)^2]^{1/2} = 549 \# \text{ (TOTAL)}$$



2 - CONT

- ALLOWABLE LOAD (REF: HILTI - SPEC TABLE FOR 3/4" HAS ANCHOR ROD)

- THE ALLOWABLE SHEAR LOAD FOR A 3/4" DIA. HAS STD. (SAE 1018) ANCHOR ROD IS: 4,800# WHICH IS GREATER THAN THE MAXIMUM APPLIED SHEAR LOAD OF 549#. ∴ TWO (2) 3/4" DIAMETER ANCHOR BOLTS PER BASE PLATE IS ADEQUATE.



$$d' = 4 - .25 = 3.75"$$

$$m = (N - d') / 2$$

$$m = \frac{14 - 3.75}{2} = 5.125"$$

$$b' = 6 - .25 = 5.75"$$

$$n = (B - b') / 2$$

$$n = \frac{14 - 5.75}{2} = 4.125"$$

3. - BASE PLATE QUALIFICATION REF: AISC P. 3-106

• REQUIRED PLATE THICKNESS:

$$t_p = 2(m \text{ OR } n) \left[\frac{f_p}{F_y} \right]^{1/2} = 2(5.125) \left[\frac{(21)}{(36000)} \right]^{1/2} = .25"$$

WHERE: $m = 4.3125"$ (MAX OF m OR n)

$F_y = 36,000 \text{ PSI}$ FOR PLATE MIN YIELD STRESS

$f_p = \text{ACTUAL BEARING PRESSURE}$

$$f_p = P / (B \times N) = 4089 / (14 \times 14) = 21 \text{ PSI}$$

WHERE: $P = 4089 \#$ (MAX COMPRESSIVE LOAD)

$$f_p = 21 \text{ PSI} < .35 f'_c = .35(3000) = 1050 \text{ PSI} \therefore \text{OK}$$

$$t_p = .25" < 1" \therefore \text{OK}$$



CONCLUSIONS:

- PIPE BRIDGE WITH REVISED 6x4 x 1/4 MEMBERS IS ACCEPTABLE.
- ONLY TWO(2) 3/4" DIA ANCHOR BOLTS PER BASE PLATE ARE REQUIRED
- ALL WELDS SHALL BE 3/16" FILLET

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



REV 0
DOC. NO. V649-1-071
P. 8 OF 19

A.-

```
*****  
*  
*           S T A A D - III           *  
*           Revision 21.0             *  
*           Proprietary Program of    *  
*           Research Engineers, Inc.   *  
*           Date=   MAR 23, 1996      *  
*           Time=   12:32:33          *  
*  
*           USER ID: Process Systems  *  
*           International              *  
*****
```

1. STAAD SPACE PIPE BRIDGE
2. INPUT WIDTH 72
3. *FILE NAME:ARTROU
4. *PIPE BRIDGE
5. UNIT INCHES POUND
6. JOINT COORDINATES
7. 10 0. 0. 0.; 20 0. 108. 0.; 30 102. 108. 0.; 40 204. 108. 0.
8. 50 204. 0. 0.; 60 0. 0. -72.; 70 0. 108. -72.; 80 102. 108. -72.
9. 90 204. 108. -72.; 100 204. 0. -72.
10. MEMBER INCIDENCES
11. 100 10 20; 101 20 30; 102 30 40; 103 40 50; 200 60 70; 201 70 80
12. 202 80 90; 203 90 100; 300 20 70; 301 30 70; 302 30 80; 303 30 90
13. 304 40 90
14. MEMBER PROPERTY AMER
15. 100 TO 103 200 TO 203 300 302 304 TABLE ST TUBE TH 0.25 WT 4. DT 6.
16. 301 303 TABLE ST TUBE TH 0.25 WT 4. DT 3.
17. SUPPORTS
18. 10 50 60 100 FIXED BUT MX MY MZ
19. CONSTANTS
20. E 27999998. ALL
21. DENSITY 0.283 ALL
22. POISSON 0.3 ALL
23. BETA 0. ALL
24. E STEEL ALL
25. POISSON STEEL ALL
26. LOAD 1 TRUSS SELFWEIGHT (D1)
27. SELFWEIGHT Y -1.
28. LOAD 2 PIPE LOADS (D2)
29. JOINT LOAD
30. 20 FX 31. FY -550. FZ 31.
31. 30 FX 31. FY -550. FZ 31.
32. 40 FX 31. FY -550. FZ 31.
33. MEMBER LOAD
34. 100 CON GX 12.1 54. 0.
35. 100 CON GZ 12.1 54. 0.
36. 200 CON GX 12.1 54. 0.
37. 200 CON GZ 12.1 54. 0.
38. 103 CON GX 12.1 54. 0.
39. 103 CON GZ 12.1 54. 0.
40. 203 CON GX 12.1 54. 0.
41. 203 CON GZ 12.1 54. 0.

REV 0
DOC. NO. V049-1-071
P. 9 OF 19

42.	300	CON	GX	8.07	36.	0.
43.	300	CON	GZ	8.07	36.	0.
44.	302	CON	GX	8.07	36.	0.
45.	302	CON	GZ	8.07	36.	0.
46.	304	CON	GX	8.07	36.	0.
47.	304	CON	GZ	8.07	36.	0.
48.	101	CON	GX	11.1	51.	0.
49.	101	CON	GZ	11.1	51.	0.
50.	102	CON	GX	11.1	51.	0.
51.	102	CON	GZ	11.1	51.	0.
52.	201	CON	GX	11.1	51.	0.
53.	201	CON	GZ	11.1	51.	0.
54.	202	CON	GX	11.1	51.	0.
55.	202	CON	GZ	11.1	51.	0.
56.	301	CON	GX	6.6	62.43	0.
57.	301	CON	GZ	6.6	62.43	0.
58.	303	CON	GX	6.6	62.43	0.
59.	303	CON	GZ	6.6	62.43	0.
60.	300	CON	GX	62.	10.	0.
61.	300	CON	GY	-1100.	10.	0.
62.	300	CON	GZ	62.	10.	0.
63.	300	CON	GX	31.	20.	0.
64.	300	CON	GY	-550.	20.	0.
65.	300	CON	GZ	31.	20.	0.
66.	300	CON	GX	2.25	25.25	0.
67.	300	CON	GY	-40.	25.25	0.
68.	300	CON	GZ	2.25	25.25	0.
69.	300	CON	GX	2.25	29.75	0.
70.	300	CON	GY	-40.	29.75	0.
71.	300	CON	GZ	2.25	29.75	0.
72.	300	CON	GX	2.25	34.25	0.
73.	300	CON	GY	-40.	34.25	0.
74.	300	CON	GZ	2.25	34.25	0.
75.	300	CON	GX	5.063	40.	0.
76.	300	CON	GY	-90.	40.	0.
77.	300	CON	GZ	5.063	40.	0.
78.	300	CON	GX	5.063	47.5	0.
79.	300	CON	GY	-90.	47.5	0.
80.	300	CON	GZ	5.063	47.5	0.
81.	300	CON	GX	8.44	55.	0.
82.	300	CON	GY	-150.	55.	0.
83.	300	CON	GZ	8.44	55.	0.
84.	300	CON	GX	5.063	62.5	0.
85.	300	CON	GY	-90.	62.5	0.
86.	300	CON	GZ	5.063	62.5	0.
87.	300	CON	GX	8.44	70.	0.
88.	300	CON	GY	-150.	70.	0.
89.	300	CON	GZ	8.44	70.	0.
90.	302	CON	GX	62.	10.	0.
91.	302	CON	GY	-1100.	10.	0.
92.	302	CON	GZ	62.	10.	0.
93.	302	CON	GX	31.	20.	0.
94.	302	CON	GY	-550.	20.	0.
95.	302	CON	GZ	31.	20.	0.
96.	302	CON	GX	2.25	25.25	0.
97.	302	CON	GY	-40.	25.25	0.

REV 0
DOC. NO. V049-1-071
P10 OF 19

98. 302 CON GZ 2.25 25.25 0.
99. 302 CON GX 2.25 29.75 0.
100. 302 CON GY -40. 29.75 0.
101. 302 CON GZ 2.25 29.75 0.
102. 302 CON GX 2.25 34.25 0.
103. 302 CON GY -40. 34.25 0.
104. 302 CON GZ 2.25 34.25 0.
105. 302 CON GX 5.063 40. 0.
106. 302 CON GY -90. 40. 0.
107. 302 CON GZ 5.063 40. 0.
108. 302 CON GX 5.063 47.5 0.
109. 302 CON GY -90. 47.5 0.
110. 302 CON GZ 5.063 47.5 0.
111. 302 CON GX 8.44 55. 0.
112. 302 CON GY -150. 55. 0.
113. 302 CON GZ 8.44 55. 0.
114. 302 CON GX 5.063 62.5 0.
115. 302 CON GY -90. 62.5 0.
116. 302 CON GZ 5.063 62.5 0.
117. 302 CON GX 8.44 70. 0.
118. 302 CON GY -150. 70. 0.
119. 302 CON GZ 8.44 70. 0.
120. 304 CON GX 62. 10. 0.
121. 304 CON GY -1100. 10. 0.
122. 304 CON GZ 62. 10. 0.
123. 304 CON GX 31. 20. 0.
124. 304 CON GY -550. 20. 0.
125. 304 CON GZ 31. 20. 0.
126. 304 CON GX 2.25 25.25 0.
127. 304 CON GY -40. 25.25 0.
128. 304 CON GZ 2.25 25.25 0.
129. 304 CON GX 2.25 29.75 0.
130. 304 CON GY -40. 29.75 0.
131. 304 CON GZ 2.25 29.75 0.
132. 304 CON GX 2.25 34.25 0.
133. 304 CON GY -40. 34.25 0.
134. 304 CON GZ 2.25 34.25 0.
135. 304 CON GX 5.063 40. 0.
136. 304 CON GY -90. 40. 0.
137. 304 CON GZ 5.063 40. 0.
138. 304 CON GX 5.063 47.5 0.
139. 304 CON GY -90. 47.5 0.
140. 304 CON GZ 5.063 47.5 0.
141. 304 CON GX 8.44 55. 0.
142. 304 CON GY -150. 55. 0.
143. 304 CON GZ 8.44 55. 0.
144. 304 CON GX 5.063 62.5 0.
145. 304 CON GY -90. 62.5 0.
146. 304 CON GZ 5.063 62.5 0.
147. 304 CON GX 8.44 70. 0.
148. 304 CON GY -150. 70. 0.
149. 304 CON GZ 8.44 70. 0.
150. LOAD COMB 3
151. 1 1. 2 1.
152. PERFORM ANALYSIS

P R O B L E M S T A T I S T I C S

NUMBER OF JOINTS/MEMBER+ELEMENTS/SUPPORTS = 10/ 13/ 4
ORIGINAL/FINAL BAND-WIDTH = 6/ 3
TOTAL PRIMARY LOAD CASES = 2, TOTAL DEGREES OF FREEDOM = 48
SIZE OF STIFFNESS MATRIX = 1152 DOUBLE PREC. WORDS
REQRD/AVAIL. DISK SPACE = 12.03/ 378.2 MB, EXMEM = 6.69 MB

++ PROCESSING ELEMENT STIFFNESS MATRIX. 12:32:36
++ PROCESSING GLOBAL STIFFNESS MATRIX. 12:32:37
++ PROCESSING TRIANGULAR FACTORIZATION. 12:32:37
++ CALCULATING JOINT DISPLACEMENTS. 12:32:37
++ CALCULATING MEMBER FORCES. 12:32:38

153. *PRINT MATERIAL PROPERTIES ALL
154. *PRINT JOINT COORDINATES ALL
155. *PRINT SUPPORT INFORMATION ALL
156. *PRINT MEMBER INFORMATION ALL
157. *PRINT MEMBER PROPERTIES ALL
158. PRINT JOINT DISPLACEMENTS ALL

JOINT DISPLACEMENT (INCH RADIANS) STRUCTURE TYPE = SPACE

JNT	LOAD	X-TRANS	Y-TRANS	Z-TRANS	X-ROTAN	Y-ROTAN	Z-ROTAN
10	1	0.00000	0.00000	0.00000	0.00003	0.00000	0.00016
	2	0.00000	0.00000	0.00000	0.00384	0.00022	-0.00145
	3	0.00000	0.00000	0.00000	0.00387	0.00022	-0.00129
20	1	0.00004	-0.00027	0.00141	-0.00003	0.00000	-0.00033
	2	0.20601	-0.00286	0.27114	-0.00015	0.00022	-0.00286
	3	0.20604	-0.00313	0.27255	-0.00018	0.00022	-0.00318
30	1	0.00000	-0.03539	0.00146	0.00002	0.00000	0.00000
	2	0.20579	-0.24067	0.24518	0.00084	0.00025	0.00042
	3	0.20579	-0.27606	0.24665	0.00086	0.00025	0.00042
40	1	-0.00004	-0.00027	0.00141	-0.00003	0.00000	0.00033
	2	0.20554	-0.00306	0.21760	-0.00023	0.00023	0.00105
	3	0.20550	-0.00333	0.21901	-0.00026	0.00023	0.00138
50	1	0.00000	0.00000	0.00000	0.00003	0.00000	-0.00016
	2	0.00000	0.00000	0.00000	0.00314	0.00023	-0.00337
	3	0.00000	0.00000	0.00000	0.00317	0.00023	-0.00353
60	1	0.00000	0.00000	0.00000	-0.00001	0.00000	0.00015
	2	0.00000	0.00000	0.00000	0.00330	0.00028	-0.00159
	3	0.00000	0.00000	0.00000	0.00330	0.00028	-0.00144
70	1	0.00004	-0.00027	0.00141	0.00005	0.00000	-0.00031
	2	0.18703	-0.00047	0.27119	0.00094	0.00028	-0.00203
	3	0.18707	-0.00074	0.27260	0.00099	0.00028	-0.00234
80	1	0.00000	-0.03030	0.00146	0.00010	0.00000	0.00000
	2	0.18679	-0.12860	0.24522	0.00199	0.00027	0.00039
	3	0.18679	-0.15890	0.24668	0.00209	0.00027	0.00039
90	1	-0.00004	-0.00027	0.00141	0.00005	0.00000	0.00031
	2	0.18651	-0.00079	0.21762	0.00090	0.00030	0.00044
	3	0.18647	-0.00105	0.21903	0.00095	0.00030	0.00075
100	1	0.00000	0.00000	0.00000	-0.00001	0.00000	-0.00015
	2	0.00000	0.00000	0.00000	0.00258	0.00030	-0.00280
	3	0.00000	0.00000	0.00000	0.00257	0.00030	-0.00295

***** END OF LATEST ANALYSIS RESULT *****

- 159. *PRINT MEMBER FORCES ALL
- 160. *PRINT MEMBER STRESSES ALL
- 161. PRINT SUPPORT REACTIONS

REV 0
Doc. No. V049-1-071
P 13 of 19

SUPPORT REACTIONS -UNIT POUN INCH STRUCTURE TYPE = SPACE

JNT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM Z
10	1	50.70	390.45	-3.30	0.00	0.00	0.00
	2	144.50	3454.01	-215.09	0.00	0.00	0.00
	3	195.20	3844.46	-218.39	0.00	0.00	0.00
50	1	-50.70	390.45	-3.30	0.00	0.00	0.00
	2	-464.87	3698.52	-182.35	0.00	0.00	0.00
	3	-515.56	4088.97	-185.65	0.00	0.00	0.00
60	1	49.03	390.45	3.30	0.00	0.00	0.00
	2	42.51	566.27	-128.68	0.00	0.00	0.00
	3	91.54	956.72	-125.38	0.00	0.00	0.00
100	1	-49.03	390.45	3.30	0.00	0.00	0.00
	2	-340.81	951.20	-92.55	0.00	0.00	0.00
	3	-389.84	1341.64	-89.25	0.00	0.00	0.00

***** END OF LATEST ANALYSIS RESULT *****

- 162. PARAMETER
- 163. CODE AISC
- 164. MAIN 0. ALL
- 165. WELD 1. ALL
- 166. CHECK CODE ALL

STAAD-III CODE CHECKING - (AISC)

ALL UNITS ARE - POUN INCH (UNLESS OTHERWISE NOTED)

MEMBER	TABLE	RESULT/ FX	CRITICAL COND/ MY	RATIO/ MZ	LOADING/ LOCATION
100	ST TUB E	PASS 3706.97 C	AISC- H1-3 22932.28	0.393 -21734.79	3 108.00
101	ST TUB E	PASS 335.58 C	AISC- H1-3 -464.13	0.444 65820.25	3 102.00
102	ST TUB E	PASS 362.87 C	AISC- H1-3 -398.99	0.449 -66632.07	3 0.00
103	ST TUB E	PASS 3951.48 C	AISC- H1-3 -19396.53	0.585 55027.61	3 0.00
200	ST TUB E	PASS 819.23 C	AISC- H1-3 12887.65	0.192 -10539.33	3 108.00
201	ST TUB E	PASS 361.06 C	AISC- H1-3 227.05	0.241 35356.93	3 102.00
202	ST TUB E	PASS 407.22 C	AISC- H1-3 337.93	0.241 -35233.39	3 0.00
203	ST TUB E	PASS 1204.16 C	AISC- H1-3 -8985.98	0.368 41448.94	3 0.00
300	ST TUB E	PASS 177.87 C	AISC- H1-3 359.43	0.175 25713.20	3 0.00
301	ST TUB E	PASS 228.27 T	AISC- H2-1 -23.11	0.110 -5896.90	2 0.00
302	ST TUB E	PASS 9.01 C	AISC- H1-3 -564.98	0.045 -5998.97	3 72.00
303	ST TUB E	PASS 103.18 T	AISC- H2-1 -28.97	0.133 -7279.46	3 124.85
304	ST TUB E	PASS 125.55 C	AISC- H1-3 771.02	0.156 22401.43	3 0.00

167. SELECT WELD ALL

REV 0
 Doc. No. V049-1-071
 2.15 OF 19

STAAD-III WELD DESIGN

ALL UNITS ARE - INCH POUN

MEMBER	LOCATION/ LOADING	WELD TYPE/ HOR STRESS	WELD SIZE/ VERT STRESS	COMB STRESS/ DIR STRESS
100	STA 3	1 174.71	1/16 156.16	3084.49 3075.57
100	END 3	1 82.51	2/16 82.92	12567.55 12567.00
101	STA 3	1 802.92	1/16 1297.58	11632.56 11532.04
101	END 3	1 270.60	3/16 397.90	9936.68 9925.02
102	STA 3	1 290.05	3/16 499.31	10057.32 10040.73
102	END 3	1 439.51	2/16 800.91	13151.09 13119.32
103	STA 3	1 46.28	3/16 134.26	12733.40 12732.61
103	END 3	1 148.52	1/16 412.45	3300.42 3271.18
200	STA 3	1 100.30	1/16 73.23	775.38 765.37
200	END 3	1 90.62	1/16 82.91	12369.77 12369.16
201	STA 3	1 858.48	1/16 932.89	3032.48 2754.75
201	END 3	1 424.80	2/16 414.50	8085.26 8063.44
202	STA 3	1 444.35	2/16 535.50	8114.59 8084.70
202	END 3	1 439.91	2/16 587.44	7635.14 7599.78
203	STA 3	1 30.86	2/16 151.09	12144.24 12143.26
203	END 3	1 71.40	1/16 311.87	1119.99 1073.32

REVO
DOC. NO. V049-1-071
P. 16 OF 19

STAAD-III WELD DESIGN

ALL UNITS ARE - INCH POUN

MEMBER	LOCATION/ LOADING	WELD TYPE/ HOR STRESS	WELD SIZE/ VERT STRESS	COMB STRESS/ DIR STRESS
300	STA 3	1 986.83	1/16 2373.86	12044.01 11766.44
300	END 3	1 960.86	1/16 795.31	8890.62 8802.69
301	STA 2	1 410.22	1/16 620.97	6614.24 6572.24
301	END 3	1 458.68	1/16 758.17	4511.28 4423.39
302	STA 2	1 110.58	1/16 1194.18	1405.35 732.61
302	END 3	1 72.49	1/16 771.92	3080.75 2981.59
303	STA 2	1 17.50	1/16 120.31	6359.39 6358.23
303	END 3	1 39.66	1/16 226.60	7912.75 7909.41
304	STA 3	1 767.11	1/16 2155.18	10724.02 10477.19
304	END 3	1 721.40	1/16 707.88	7439.25 7370.27

***** END OF TABULATED WELD DESIGN *****

168. STEEL TAKE OFF

STEEL TAKE-OFF

PROFILE	LENGTH(INCH)	WEIGHT(POUN)
ST TUB E	1056.00	1344.293
ST TUB E	249.70	217.493
	TOTAL =	1561.79

***** END OF DATA FROM INTERNAL STORAGE *****

- 169. LOAD LIST ALL
- 170. LOAD LIST 2 3
- 171. FINISH

***** END OF STAAD-III *****


**** DATE= MAR 23,1996 TIME= 12:32:39 ****

 * For questions on STAAD-III, contact: *
 * Research Engineers, Inc at *
 * Ph: (714) 974-2500 Fax: (714) 921-2543 *

5 MAR 96

To: R. CIATTO
From: D. CURTIS

EASE REVIEW & PROVIDE
ANALYSIS,
RE PIPE & ELECT. LOADINGS
& SHTS. 2 & 3 OF 3



NOTES:

- 1) FRAME TO BE SELF SUPPORTING BY FLOOR
- 2) ONE REQ'D @ VASH CORNER STATION
- ONE REQ'D @ LA CORNER STATION

NO

SHT. 1 OF 3

PROPRIETARY AND CONFIDENTIAL

THIS DRAWING CONTAINS PROPRIETARY INFORMATION BELONGING TO PROCESS SYSTEMS INTERNATIONAL, INC. OR ITS RELATED COMPANIES AND SHALL BE USED ONLY FOR THE PURPOSE FOR WHICH IT WAS SUPPLIED. IT SHALL NOT BE COPIED, REPRODUCED OR OTHERWISE USED FOR ANY OTHER PURPOSE WITHOUT THE WRITTEN CONSENT OF PROCESS SYSTEMS INTERNATIONAL, INC. AND SHALL BE RETURNED UPON REQUEST.

DWG. NO.	DESCRIPTION	DWG. NO.	DATE	DESN.



PROCESS SYSTEMS INTERNATIONAL, INC.
20 WILBUR DR. WESTBOROUGH, MASSACHUSETTS 01581 USA

PROPOSED PIPE BRIDGE
CORNER STATION
LIGO VACUUM EQUIPMENT

CAD FILE	REV	DWG. NO.	REV.
V0494043	D	V049-4-043	PI

SCALE: 1/2"=1'-0" SHEET: 1 OF 1

REV'D
DOC. NO. V049-1-021

150121-100 - 142828

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-039 PAGE 1 OF 19
REV.	DEO #	DATE	BY:	CHECK	TITLE: HAM Finite Element Analysis	
0	0128	12/29/97	KM	RDC		
PROJECT: LIGO Vacuum Equipment					BY: Kyle Martini	DEPT.: 744
PROJECT NO: V59049						
<u>PURPOSE:</u> Evaluate the horizontal access module (HAM)						
<u>METHOD:</u> Finite element method and hand calculations.						
<u>ASSUMPTIONS:</u> See attached.						
<u>INPUTS:</u> LIGO project drawings and sketches. Shell thickness = 0.5 in, 60 in nozzle thickness = .5 in, head thickness = 0.375 in Thickness of other nozzles = 0.125 in, saddle wear plate thickness = 0.75 in, Thickness of saddle and stiffeners = 0.5 in, baseplate thickness = 1.0 in						
<u>REFERENCES:</u> 1. ASME Boiler & Pressure Vessel Code, Section VIII, Pressure Vessels, Div. 1 and Div. 2. 2. IMAGES 3D, Version 3.0, R. L. Cloud & Associates 3. Hilti Concrete Fastener Catalog						
<u>CALCULATIONS:</u> (SEE ATTACHED)						
<u>CONCLUSIONS:</u> Stress are within the limits of the ASME Code, Section VIII, Div. 2.						
<u>NOTES:</u> Computer files are HAM6.*						

SUMMARY

ASME SEY VIII DIV 2
Allowable
Stress

Load case

Max
Stress Intensity

- 1. One Bellow Design
 - $P_L + P_B + Q = 28.6 \text{ KSI}$
 - $P_L = 26.5 \text{ KSI}$
 - Bolt Force = 8683 lb
- 2. Two Bellow Design
 - $P_L + P_B + Q = 16.5 \text{ KSI}$
 - $P_L = 15.8 \text{ KSI}$
- 3. Seismic
 - X - 0.15 KSI
 - Y - 0.05 KSI
 - Z - 0.11 KSI
- 4. Lifting
 - 2.7 KSI

$3S_m = 56.1 \text{ KSI}$
 $1.5S_m = 28.0 \text{ KSI}$
 10,960 lb

$3S_m = 56.1 \text{ KSI}$
 $1.5S_m = 28.0 \text{ KSI}$

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



1.0 MODEL (ref. Dwg. V049-4-002)

The HAM finite element model was created using Images. A computer plot of the model is shown in Figure 1. Additional information including a listing, diagonals identifying nodes and elements, loads and plots can be found in Appendix A.

The model is $1/2$ symmetrical using B.C to represent the second half. The total weight of the model is 6300^{lb}.

2.0 ANALYSIS

2.1 One Bellows External Pressure Analysis

The HAM can be configured with one or two opposing bellows. In the analysis it is assumed that the bellows does not transmit any loads or add any stiffness. With one bellows an external pressure unbalance occurs and there are external reactions. A pressure load of -14.7 PSI is applied everywhere. At nozzle which are conservatively modeled w/o caps the load is applied as a line load P_{nozzle} .

The unbalance loading is shown on the deform plot of Figure 2. The effect of the overturning moment can be vividly seen. On the bellow side (opposite the unbalance loaded side) the compressive forces due to the overturning moment combine with the compressive forces from the external pressure. This produces greater deformation and higher stresses. On the loaded side the forces due to the overturning moment subtract from the external pressure forces.

Figure 3 is a contour plot of the resultant displacements $ds = \sqrt{dx^2 + dy^2}$. The maximum displacements occur at the locations farthest from the center of rotation of the overturning moment. This occurs at the top of neck "B" the tube neck. The maximum and minimum displacements in each direction are

<u>direction</u>	<u>max</u>	<u>min</u>
X	+0.11"	-0.04"
Y	+0.14"	-0.30"
Z	+0.05"	-0.34"

Stress Intensity contour plots of the model at the top surface, bottom surface, and averaged across the thickness (membrane) are shown in Figures 4-6. The highest stresses occur at local discontinuities such as nozzle-vessel junction and saddle support locations on the vessel. The maximum stress intensities are

Top Surface - 26.9 KSI

Bottom Surface 28.6 KSI

Membrane 26.5 KSI

Using ASME SEC VIII Div 2 rules.

The S_m allowable stress intensity is

$$S_m = 18.7 \text{ KSI @ } 400^\circ\text{F for TP 304}$$


These stresses are discontinuity stresses and the maximum allowable stress for combined bending and membrane are

$$P_L + P_b + Q = 28.6 < 3 S_m = 56.1 \text{ KSI } \underline{\text{OK}}$$

For membrane alone


$$P_L = 26.5 \text{ KSI} < 1.5 S_m = 27.8 \text{ KSI } \underline{\text{OK}}$$

The maximum anchor load due to the off balance load is calculated as follows



$$P = \frac{(14.7)(60.5)^2 \pi}{(11)(12 \sin)} = 21,129 \#$$

$$h = 65.75''$$



Assume only outer bolts take load

$$F_{bolt} = \frac{Ph}{l(12 \text{ bolts})} = \frac{(21129)(65.75)}{(80)(12 \text{ bolts})}$$

$$F_{bolt} = 8683 \#$$

For 3000 psi concrete, and a 1" Hilti adhesive anchor embedded 8 1/4" $F_{allow} = 10960 \#$

$$F.S. = \frac{10960}{8683} = 1.26 \quad \text{OK}$$

2.2 Two Bellow External Pressure Analysis

In this configuration there is no unbalance loading and no external reaction. The contour plot of the deflection is shown in Figure 9. The maximum deflections for each direction are

<u>Direction</u>	<u>MAX</u>	<u>MIN</u>
X	+1.05	-0.04
Y	+1.06	-0.16
Z	+1.05	-0.05

Figures 8, 9, and 10 plot the stress intensities for this configuration. The max values are

Top surface	15.3 KSI	∠ 56.1 KSI
Bottom surface	16.5 KSI	∠ 56.1 KSI
Membrane	15.8 KSI	∠ 27.8 KSI

There are no external reaction

2.3 SEISMIC


The seismic acceleration from (ASCE 7-88) are 0.05625 g in each direction. The weight of the HAM model is 6269#

$$F_{seismic} = (0.05625)(6269) = 352\#$$

This is a small force compared to the unbalance force due to the external pressure which is 42,258#. The compressive stresses are also small. From the computer model the maximum stresses are


<u>Direction</u>	<u>Stress</u>
X	150 PSI
Y	54 PSI
Z	108 PSI

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS
ANIPAC

2.4 LIFTING LUGS

For the lifting lug analysis, the vessel was supported at four points on the structure for the lifting lug. The maximum stress for a 2 "g" load (DLF = 2.0) is 2.7 KSI

The maximum ^{stress} force on lug 1575#




12/19/98

Fig 1 - FE Model

MASS MODEL

UNDEFORMED SHAPE

IMAGES-3D
Version 3.0
L Case 1
S= .300E+02






Revision No. 0
Doc. No. V049-1-039
Page 11 of 19

Fig 2 Deflected Shape - Wireframe Plot

12/20/95
9: 8:53

11 01 19

IMAGES-3D
Version 3.0



Revision No. 0
Doc. No. V049-1-039
Page 12 of 19

Load Case
1

Fig 3

Displacement Contour Plot
DS




1- Bellows Model

1/20/96
17:26:51

12-31-19

3

**IMAGES-3D
Version 3.0**



Revision No. 0
Doc. No. V049-1-039
Page 13 of 19

**Load Case
1**

**Stress Contour Plot
Surf: Top
Stress Intensity**




**1/16/96
11:50:53**

Fig 4 Arc Bellows Model

13 5 19

4

IMAGES-3D
Version 3.0



Revision No. 0
Doc. No. V049-1-039
Page 14 of 19

Load Case
1




Stress Contour Plot
Surf: Bottom **Stress Intensity**

1/16/96
12:15: 4

Fig 5.1 - Stress Contour Plot

1/16/96

IMAGES-3D
Version 3.0



Revision No. 0
Doc. No. V049-1-039
Page 15 of 19

Load Case
1

Membrane




Stress Contour Plot
Stress Intensity

1/16/96
12: 5:39

Fig 6 Mem Bellows Model

15 04/19

IMAGES-3D
Version 3.0



Revision No. 0
Doc. No. V049-1-039
Page 16 of 19

Load Case
2




Displacement Contour Plot
DS

1/20/96
17:34:46

Fig 2 Two Bellows View

12 27 19

IMAGES-3D
Version 3.0



Revision No. 0
Doc. No. V049-1-039
Page 17 of 19

Load Case
2




Stress Contour Plot
Surf: Top
Stress Intensity

1/16/96
12:53:58

Fig 8 Two Bottom View

17-19

IMAGES-3D
Version 3.0



Revision No. 0
Doc. No. V049-1-039
Page 18 of 19

Load Case
2




Stress Contour Plot
Surf: Bottom
Stress Intensity

1/16/96
13:19:28

1 3 9 Two Bellows Mem.

18 of 19

IMAGES-3D
Version 3.0



Revision No. 0
Doc No. V049-1-039
Page 19 of 19

Load Case
2

Membrane

Stress Contour Plot
Stress Intensity

1/20/96
17:50:52

Fig 10 Two Bellows Model


19 0519

10

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-041 PAGE 1 OF 6
REV.	DEO #	DATE	BY:	CHECK	TITLE: HAM Buckling Analysis	
0	0128	1/29/96	KM	RDC		
					BY: Kyle Martini	DEPT.: 744
<u>PROJECT:</u> LIGO Vacuum Equipment					<u>PROJECT NO:</u> V59049	
<u>PURPOSE:</u> Evaluate the horizontal access module (HAM) for buckling modes.						
<u>METHOD:</u> Finite element method and hand calculation.						
<u>ASSUMPTIONS:</u> See attached.						
<u>INPUTS:</u> LIGO project drawings and sketches. Shell thickness = 0.5 in, 60 in nozzle thickness = 0.5 in, head thickness = 0.375 in Thickness of other nozzles = 0.125 in, saddle wear plate thickness = 0.75 in, Thickness of saddle and stiffeners = 0.5 in, baseplate thickness = 1.0 in						
<u>REFERENCES:</u> NASTRAN Finite Element Program <i>Doc No. V049-1-060, LIGO VAC. EQUIP. STRUCT. DES. CRITERIA</i>						
<u>CALCULATIONS:</u> (SEE ATTACHED)						
<u>CONCLUSIONS:</u> The minimum factor of safety against elastic buckling for vacuum loading is 3.58.						
<u>NOTES:</u> <i>COMPUTER FILE: HAM6D.INP</i>						

1.0 Hand Analysis

- Assumptions:
- 1) Extra material at nozzle replaces slittness of vessel material removed
 - 2) pressure uniform
 - 3) Cylinder length 74.8"



Ref. Part 5th ed Table 35 case 3b
 Short cylinder of length l ends
 held circular bolt otherwise
 not constrained, to end loads

$$P_{cc} = 0.807 \frac{Et^2}{lr} \sqrt{\frac{l}{(1-\nu)^2} \frac{t^2}{r^2}}$$

$$t = 0.15" \quad l = 74.8 \quad \nu = 0.13$$

$$r = 42.25" \quad E = 29(10^6) \text{ PSI}$$

$$P_{cc} = 216.1 \text{ PSI}$$

$$F.S. = \frac{P_{cc}}{14.7} = \underline{\underline{14.7}}$$

2.0 Computer Analysis

- a. The same length shell is analyzed using NASTRAN buckling program
- b. The shell is $\frac{1}{2}$ " thick with the opening for the 60" diameter tubes.
- c. The small nozzles are not modeled. It is assumed the stiffness of the nozzle replaces the stiffness removed by the hole.
- d. The stiffness of the tube nozzles are modeled as beams. Assuming the nozzles extend 3" and are $\frac{1}{2}$ " thick.
- e. The vessel junction with the side heads are modeled as reinforced area 3" x 12"
- f. An external pressure of 14.7 psi is applied to all plate elements.
- g. An axial ring load is applied to the ends of the vessel equal to $-pR$
- h. The vessel is restrained at its supports
- i. Two configurations are modeled. A two bellows center and a one bellows

3.1 Results

Model	Factor of Safety
2 - bellows	11.8
1 - bellows (See Fig)	11.9

REV 0
 Doc. No U049-1-041
 P. 3 OF 6

3.01 Alternative Model

Analysis on static stress model (see fig?)
reference Calc. V049-1-039

<u>Model</u>	<u>Factor of Safety</u>		
1. bellows	3.58	>	3.0
2. bellows	3.89	>	3.0

These values are believed to be conservative.

The buckling modes excluded by NASTRAN
are spurious due to the complicated model.

The real modes are higher.

2/12/48 MAX-987. - 1.00000000

HAM 1/1 SYAM MODEL
BUCKLING SOLUTION
MODAL DEFOR. SUBCASE 2 MODE 8 EIGENV. 11.76848 WAVE MODEL.





Fig 1 - one bellows buckling shape



12/19/98

Fig. 2 - F.E. Model

REV 0
DOC. NO. V049-1-DV1
P. 6 OF 6

WASS MODEL

UNDEFORMED SHAPE

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-073
REV.	DEO #	DATE	BY:	CHECK	PAGE 1 OF 29	
0	0024	4-1-96	AGK	ROC	TITLE: 60" F+D HEAD/NOZZLE DESIGN FOR HAM	
					By: ART ROUSSOPoulos DEPT.: 744	
PROJECT: LIGO					PROJECT NO: V59049	
PURPOSE: QUALIFY THE DESIGN OF THE 60" HAM COVER TO ASME VIII REQUIREMENTS						
METHOD: COMPRESS 5.53 COMPUTER PRESSURE VESSEL SOFTWARE						
ASSUMPTIONS: SEE CALCS						
INPUTS: "STRUCTURAL DESIGN CRITERIA" REF DOC. NO. V049-PL-73						
REFERENCES: DOC. NO. V049-PL-73 DOC. NO. V049-1-066, LIGO VACUUM FEED. STR. DESIGN CRITERIA						
CALCULATIONS: (SEE ATTACHED)						
CONCLUSIONS: COVER/NOZZLE DESIGN IS IN CONFORMANCE WITH ASME VIII REQUIREMENTS						
NOTES: INSIDE DIAM ANALYZED = 60.25". ACTUAL ID = 60.5" RESULTS ARE NOT REFLECTED						

TABLE OF CONTENTS

	<u>PAGE</u>
1. - SCOPE	3
2. - DESIGN CRITERIA	3
3. - MODEL	3
4. - COMPRESS 5.53 - INPUT DATA	4
5. - COMPRESS 5.53 - OUTPUT	5 -

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS




1. - SCOPE:

QUALIFY THE 60" HAM COVER TO ASME VIII REQUIREMENTS FOR THE NOZZLE LAYOUT AS PSI PROPOSED AND CUSTOMER MODIFIED PER DOC. NO. V049-PL-73

2. - DESIGN CRITERIA:

$P_{EXT.} = 14.7 \text{ PSI}$
 $T = 400^\circ \text{ F}$

3. - MODEL:



- NOZZLE LOCATION DATA:

- N1 $r_1 = 8"$
 $\theta_1 = 0^\circ$
- N2 $r_2 = 15.75"$
 $\theta_2 = 90^\circ$
- N3 $r_3 = 15.75"$
 $\theta_3 = 270^\circ$

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



4. - COMPRESS 5.53 INPUT DATA:

• MATERIAL:

- F+D HEAD: SA 240 304L HIGH
- NOZZLES (ALL): SA 240 304L HIGH

• EXTERNAL PRESSURE = 14.7 PSI

• DESIGN TEMP = 400°F

FOR F+D HEAD:

- LONG SEAM X-RAY
- SEAMLESS ∴ NO X-RAY
- HEAD/SHELL SEAM X-RAY
- SPOT PER UW-11(b) TYPE I
- ID = 60.25"
- CROWN INTERNAL RADIUS = 60.25"
- KNUCKLE INTERNAL RADIUS = 3.75"
- FORMING ALLOWANCE = 0"
- STRAIGHT FLANGE = 1"
- THICKNESS = .250"

FOR NOZZLES:

- ID = 7.5" (ALL)
 - THICKNESS = .25" (ALL)
- | <u>ANGLE θ</u> | <u>DISTANCE r</u> |
|----------------------------------|--------------------------------|
| N1: $\theta_1 = 0^\circ$ | $r_1 = 8"$ |
| N2: $\theta_2 = 90^\circ$ | $r_2 = 15.75"$ |
| N3: $\theta_3 = 270^\circ$ | $r_3 = 15.75"$ |

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



5. - COMPRESS 5.53 - OUTPUT

OUTPUT FOR 60" F+D HEAD INCLUDING NOZZLES
1 + 2 ARE ATTACHED TO VERIFY COMPLIANCE
TO ASME VIII, 1992 EDITION INCLUDING A93
ADDENDA

NOTE: ANALYSIS/RESULTS FOR NOZZLE # 3
IS SYMMETRICALLY IDENTICAL TO
NOZZLE # 2.

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



TABLE OF CONTENTS

Pressure Summary	1
Weight Summary	2
Nozzle Summary	3
Thickness Summary	4
60" F&D HAM HEAD	5
N1-CENTER	6
N2-RIGHT	15
Total Pages In This Report	23

Pressure Summary

Pressure summary for pressure chamber 1

Identifier	Nozzle	T	MAWP	MAP	Pe	UG-99	UCS-66	Corrosion	
	Status	design			external	Ratio	MDMT	Exemption or	
	(UG-45)	(deg F)	(psi)	(psi)	(psi)		(deg F)	Stress Reduction	
								Allowance	
								(in)	
60" P&D HAM HEAD		0.0	67.2	67.2	20.6	1.000		Not applicable	0.000
n1 N1-CENTER	ok	0.0	79.0	79.0	15.5	1.000		Not applicable	0.000
n2 N2-RIGHT	ok	0.0	79.0	79.0	15.3	1.000		Not applicable	0.000
n3 N3-LEFT	ok	0.0	79.0	79.0	15.3	1.000		Not applicable	0.000

Vessel MAWP hot & corroded is 67.2 psi @ 0 degrees F.

Vessel MAP new & cold is 67.2 psi @ 70 degrees F.

Vessel allowable external pressure is 15.31 psi @ 400 degrees F.

Hydrotest pressure calculation based on MAWP

$$= 1.5 * (\text{MAWP} + \text{Operating Liquid Head}) * 1 = 100.8 \text{ psi}$$

Vessel hydrotest pressure is 100.8 psi.

Note: vessel MAP rating not valid unless hydrotest pressure based on MAP.

Weight Summary

Component	Weight (lbs) Contributed by Vessel Elements											
	Metal New	Metal Corr	Trays & sup	Packed Beds	Insul	Lining	Piping	Ladder & plat	Rings & Misc	Oper Liquid	Test Liquid	Nozzle & flg
60" f&d ham hea	273	273	0	0	0	0	0	0	0	0	741	24
	273	273	0	0	0	0	0	0	0	0	741	24

Vessel operating weight, corroded: 297 lbs
 Vessel empty weight, corroded: 297 lbs
 Vessel empty weight, new: 297 lbs
 Vessel test weight, new: 1,038 lbs

Vessel center of gravity location (from right weld seam)

Vessel lift weight, new: 297 lbs
 Center of gravity to seam: 7.6 in

Nozzle Summary

Nozzle mark	OD (in)	tn (in)	Req tn (in)	A1?	A2?	Nom t (in)	Req t (in)	User t (in)	Corr (in)	Aa/Ar (%)
n1	8.00	0.2500	0.1427	y	y	0.2500	0.1973	0.2500	0.0000	100.5
n2	8.00	0.2500	0.1427	y	y	0.2500	0.1937	0.2500	0.0000	104.3
n3	8.00	0.2500	0.1427	y	y	0.2500	0.1937	0.2500	0.0000	104.3

- tn - nozzle thickness
- Req tn - nozzle thickness required per UG-45/16
- Nom t - vessel wall thickness
- Req t - required vessel wall thickness due to pressure + corr per UG-37
- User t - local vessel wall thickness (near opening)
- Aa - area available per UG-37, governing condition
- Ar - area required per UG-37, governing condition
- Corr - corrosion allowance on nozzle id.

Thickness Summary

Component Identifier	ID (in)	Length (in)	Nom t (in)	Req t (in)	Joint E	Governing Load Status	Stress	Deflect (in)
60" f&d ham head	60.25		0.2500	0.2500	0.85			

Nom t - vessel wall thickness
Req t - required vessel wall thickness due to governing loading
E - longitudinal seam joint efficiency

Load:

internal - circ stress due to internal pressure governs
external - external pressure governs
wind - combined long stress due to STATUS + wind governs
seismic - combined long stress due to STATUS + seismic governs

60" F&D HAM HEAD

ASME Section VIII Division 1, 1992 Edition, A93 Addenda

Component: F&D head
Material specification: SA 240 304L HIGH

Corrosion allowance: Inner C = 0 Outer= 0 in

PWHT is not performed

Radiography: Category A joints - Seamless NO X-Ray
Head to shell seam - Spot UW-11(b) type 1

Estimated weight: new = 272.9 corr = 272.9 lb
capacity: new = 88.89 corr = 88.89 US ga

ID = 60.25 crown L = 60.25 knuckle r = 3.75 t = .25 in (min)

Straight flange = 1 forming allowance = 0 in

MAP: (New & at 70 deg F) Appendix 1-4(d) Eq 3

$$\begin{aligned} P &= 2*S*E*t / (L*M + 0.2*t) - P_s \\ &= 2*16700*0.85*0.25 / (60.25*1.7521 + 0.2*0.25) - 0 \\ &= 67.20225 \text{ psi} \end{aligned}$$

MAWP: (Corroded & at 0 deg F) Appendix 1-4(d) Eq 3

$$\begin{aligned} P &= 2*S*E*t / (L*M + 0.2*t) - P_s \\ &= 2*16700*0.85*0.25 / (60.25*1.7521 + 0.2*0.25) - 0 \\ &= 67.20225 \text{ psi} \end{aligned}$$

Maximum Allowable External Pressure: (Corroded @ 400 deg F)

$$\begin{aligned} A &= .125 / (R_o/t) \\ &= .125 / (60.5/0.25) \\ &= 0.000517 \end{aligned}$$

From table HA-3: B = 5004.1

$$\begin{aligned} P_a &= B / (R_o/t) \\ &= 5004.1 / (60.5/0.25) \\ &= 20.6781 \text{ psi} \end{aligned}$$

Check the Maximum External Pressure: UG-33(a) (1) & App. 1-4(d)

$$\begin{aligned} P_e &= 2*S*E*t / ((M*Lo - t*(M-0.2))*1.67) \\ &= 2*14700*1*0.25 / ((1.7521*60.5 - 0.25*(1.7521-0.2))*1.67) \\ &= 41.67247 \text{ psi} \end{aligned}$$

The maximum allowable external pressure is 20.6781 psi.


N1-CENTER

Opening n1 Reinforcement Calculations Per UG-37

Located on: 60" F&D HAM HEAD
User input vessel thickness: .25 in
Liquid static head included: 0 psi
Flange description: Not installed

Nozzle material specification: SA 240 304L HIGH

Nozzle orientation: 0 degrees
End of nozzle to datum line: 14.53 in
Nozzle calculated as hillside: yes
Projection outside vessel Lpr: 3.527 in



corrosion allow = 0 in
noz thick new tn = .25 in
nozzle id. new d = 7.5 in
fillet weld tw1 = .25 in
groove weld tw2 = .1875 in

To head center R = 8 in

Reinforcement Calculations For Nozzle MAWP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.567$ in
Normal to the vessel wall outside $2.5*(tn-Cn) + te = .625$ in
Normal to the vessel wall inside $2.5*(tn-Cn-C) = .625$ in

Determination of Chord Length

$$\begin{aligned}\text{Theta1} &= \text{ArcCos}((Lo + Rn)/Rm) \\ &= \text{ArcCos}((8 + 3.75)/60.32135) \\ &= 78.76797\end{aligned}$$

$$\begin{aligned}\text{Theta2} &= \text{ArcCos}((Lo - Rn)/Rm) \\ &= \text{ArcCos}((8 - 3.75)/60.32135) \\ &= 85.96029\end{aligned}$$

$$\begin{aligned}d &= 2*Rm*\text{Sin}((\text{Theta2} - \text{Theta1})/2) \\ &= 2*60.32135*\text{Sin}((85.96029 - 78.76797)/2) \\ &= 7.567 \text{ in}\end{aligned}$$

Nozzle required thickness

$$\begin{aligned}trn &= P*Rn/(Sn*E - 0.6*P) \\ &= 79.06141*3.75/(16700*1 - 0.6*79.06141) \\ &= 0.0178 \text{ in}\end{aligned}$$

N1-CENTER

Required thickness tr from UG-37(a)(1)

$$\begin{aligned} tr &= P*L*M/(2*S*E - 0.2*P) \\ &= 79.06141*60.25*1/(2*16700*1 - 0.2*79.06141) \\ &= 0.1427 \text{ in} \end{aligned}$$

Area required

Allowable stresses: Sn = 16700, Sv = 16700, psi

fr1 = lesser of 1 or Sn/Sv so fr1 = 1
fr2 = lesser of 1 or Sn/Sv so fr2 = 1

$$\begin{aligned} A &= d*tr*F + 2*tn*tr*F*(1 - fr1) \\ &= 7.567*0.1427*1 + 2*0.25*0.1427*1*(1 - 1) \\ &= 1.0798 \text{ in}^2 \end{aligned}$$

Area available

A1 = larger of the following = .812 in²

$$\begin{aligned} &= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 7.567*(1*0.25-1*0.1427) - 2*0.25*(1*0.25-1*0.1427)*(1-1) \\ &= .812 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 2*(0.25+0.25)*(1*0.25-1*0.1427) - 2*0.25*(1*0.25-1*0.1427)*(1-1) \\ &= .107 \text{ in}^2 \end{aligned}$$

A2 = smaller of the following = 0.29 in²

$$\begin{aligned} &= 5*(tn - trn)*fr2*t \\ &= 5*(0.25 - 0.0178)*1*0.25 \\ &= .29 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5*(tn - trn)*fr2*tn \\ &= 5*(0.25 - 0.0178)*1*0.25 \\ &= .29 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A41 &= \text{Leg}^2*fr2 \\ &= 0.25^2*1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.812 + 0.29 + 0.063 \\ &= 1.165 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAWP = 79.06141 at 0 Deg F

Reinforcement check in the plane parallel to the long. axis

Area required

$$A = d*tr*F + 2*tn*tr*F*(1 - fr1)$$

N1-CENTER

$$= 7.5 * 0.1427 * 1 + 2 * 0.25 * 0.1427 * 1 * (1 - 1)$$

$$= 1.07025 \text{ in}^2$$

Area available

$$A1 = \text{larger of the following} = .805 \text{ in}^2$$

$$= d * (E1 * t - F * tr) - 2 * tn * (E1 * t - F * tr) * (1 - fr1)$$

$$= 7.5 * (1 * 0.25 - 1 * 0.1427) - 2 * 0.25 * (1 * 0.25 - 1 * 0.1427) * (1 - 1)$$

$$= .805 \text{ in}^2$$

$$= 2 * (t + tn) * (E1 * t - F * tr) - 2 * tn * (E1 * t - F * tr) * (1 - fr1)$$

$$= 2 * (0.25 + 0.25) * (1 * 0.25 - 1 * 0.1427) - 2 * 0.25 * (1 * 0.25 - 1 * 0.1427) * (1 - 1)$$

$$= .107 \text{ in}^2$$

$$\text{Area} = A1 + A2 + A41$$

$$= 0.805 + 0.29 + 0.063$$

$$= 1.158 \text{ in}^2$$

As Area > A the reinforcement is adequate for MAWP = 79.06141 at 0 Deg F

Check the welds - From UW-16(d):

$$t_{min} = \text{lesser of } 0.75 \text{ or } t_n \text{ or } t, t_{min} = 0.25 \text{ in}$$

$$t1 \text{ or } t2(\text{min}) = \text{lesser of } 0.25 \text{ or } 0.7 * t_{min}, t1(\text{min}) = 0.175 \text{ in}$$

$$t1(\text{actual}) = 0.7 * \text{Leg} = 0.7 * 0.25 = 0.175 \text{ in}$$

$$t2(\text{actual}) = 0.1875 \text{ in}$$

$$t1 + t2 = 0.3625 \geq 1.25 * t_{min}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.0178 in (E = 1)
Wall thickness per UG-45(b)(1):	tr2 = 0.1427 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.1427 in
The lesser of tr4 or tr5:	tr6 = 0.1427 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.1427 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for MAWP.

Allowable stresses in joints UG-45(c) and UW-15(c)

$$\text{Groove weld in tension} = 0.74 * 16700 = 12358 \text{ psi}$$

$$\text{Nozzle wall in shear} = 0.7 * 16700 = 11690 \text{ psi}$$

$$\text{Inner fillet weld in shear} = 0.49 * 16700 = 8183 \text{ psi}$$

Strength of welded joints:

N1-CENTER

(1) Inner fillet weld in shear

$$(\text{Pi}/2) * \text{Nozzle O.D.} * \text{Leg} * \text{Si} = 1.57 * 8 * 0.25 * 8183 = 25694.62 \text{ lbf}$$

(3) Nozzle wall in shear

$$(\text{Pi}/2) * \text{Mean nozzle dia.} * \text{tn} * \text{Sn} = 1.57 * 7.75 * 0.25 * 11690 = 35559.52 \text{ lbf}$$

(4) Groove weld in tension

$$(\text{Pi}/2) * \text{Nozzle O.D.} * \text{tw} * \text{Sg} = 1.57 * 8 * 0.1875 * 12358 = 29103.09 \text{ lbf}$$

Loading on welds per UG-41(b) (1)

$$\begin{aligned} W &= (A - (d - 2 * \text{tn}) * (\text{E1} * \text{t} - \text{F} * \text{tr})) * \text{Sv} \\ &= (1.0798 - (7.567 - 2 * 0.25) * (1 * 0.25 - 1 * 0.1427)) * 16700 \\ &= 5369.232 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W1-1 &= (A2 + A5 + A41 + A42) * \text{Sv} \\ &= (0.29 + 0 + 0.063 + 0) * 16700 \\ &= 5895.1 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W2-2 &= (A2 + A3 + A41 + A43 + 2 * \text{tn} * \text{t} * \text{fr1}) * \text{Sv} \\ &= (0.29 + 0 + 0.063 + 0 + 2 * 0.25 * 0.25 * 1) * 16700 \\ &= 7982.6 \text{ lbf} \end{aligned}$$

Load for path 1-1 lesser of W or W1-1 = 5369.232 lbf

Path 1-1 Thru (1) & (3) = 25694.62 + 35559.52 = 61254.14 lbf

Path 1-1 is stronger than W so it is acceptable per UG-41(b) (2).

Load for path 2-2 lesser of W or W2-2 = 5369.232 lbf

Path 2-2 Thru (1), (4) = 25694.62 + 29103.09 = 54797.71 lbf

Path 2-2 is stronger than W so it is acceptable per UG-41(b) (2).

Reinforcement Calculations For Nozzle MAP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.567 \text{ in}$

Normal to the vessel wall outside $2.5 * (\text{tn} - \text{Cn}) + \text{te} = .625 \text{ in}$

Normal to the vessel wall inside $2.5 * (\text{tn} - \text{Cn} - \text{C}) = .625 \text{ in}$

Determination of Chord Length

$$\begin{aligned} \text{Theta1} &= \text{ArcCos}((\text{Lo} + \text{Rn}) / \text{Rm}) \\ &= \text{ArcCos}((8 + 3.75) / 60.32135) \\ &= 78.76797 \end{aligned}$$

$$\begin{aligned} \text{Theta2} &= \text{ArcCos}((\text{Lo} - \text{Rn}) / \text{Rm}) \\ &= \text{ArcCos}((8 - 3.75) / 60.32135) \\ &= 85.96029 \end{aligned}$$

$$\begin{aligned} d &= 2 * \text{Rm} * \text{Sin}((\text{Theta2} - \text{Theta1}) / 2) \\ &= 2 * 60.32135 * \text{Sin}((85.96029 - 78.76797) / 2) \\ &= 7.567 \text{ in} \end{aligned}$$

N1-CENTER

Nozzle required thickness

$$\begin{aligned} \text{trn} &= P \cdot R_n / (S_n \cdot E - 0.6 \cdot P) \\ &= 79.06141 \cdot 3.75 / (16700 \cdot 1 - 0.6 \cdot 79.06141) \\ &= 0.0178 \text{ in} \end{aligned}$$

Required thickness tr from UG-37(a) (1)

$$\begin{aligned} \text{tr} &= P \cdot L \cdot M / (2 \cdot S \cdot E - 0.2 \cdot P) \\ &= 79.06141 \cdot 60.25 \cdot 1 / (2 \cdot 16700 \cdot 1 - 0.2 \cdot 79.06141) \\ &= 0.1427 \text{ in} \end{aligned}$$

Area required

Allowable stresses: $S_n = 16700$, $S_v = 16700$, psi

$\text{fr1} = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } \text{fr1} = 1$
 $\text{fr2} = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } \text{fr2} = 1$

$$\begin{aligned} A &= d \cdot \text{tr} \cdot F + 2 \cdot \text{tn} \cdot \text{tr} \cdot F \cdot (1 - \text{fr1}) \\ &= 7.567 \cdot 0.1427 \cdot 1 + 2 \cdot 0.25 \cdot 0.1427 \cdot 1 \cdot (1 - 1) \\ &= 1.0798 \text{ in}^2 \end{aligned}$$

Area available

$A_1 = \text{larger of the following} = .812 \text{ in}^2$

$$\begin{aligned} &= d \cdot (E_1 \cdot t - F \cdot \text{tr}) - 2 \cdot \text{tn} \cdot (E_1 \cdot t - F \cdot \text{tr}) \cdot (1 - \text{fr1}) \\ &= 7.567 \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) - 2 \cdot 0.25 \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) \cdot (1 - 1) \\ &= .812 \text{ in}^2 \\ &= 2 \cdot (t + \text{tn}) \cdot (E_1 \cdot t - F \cdot \text{tr}) - 2 \cdot \text{tn} \cdot (E_1 \cdot t - F \cdot \text{tr}) \cdot (1 - \text{fr1}) \\ &= 2 \cdot (0.25 + 0.25) \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) - 2 \cdot 0.25 \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) \cdot (1 - 1) \\ &= .107 \text{ in}^2 \end{aligned}$$

$A_2 = \text{smaller of the following} = 0.29 \text{ in}^2$

$$\begin{aligned} &= 5 \cdot (\text{tn} - \text{trn}) \cdot \text{fr2} \cdot t \\ &= 5 \cdot (0.25 - 0.0178) \cdot 1 \cdot 0.25 \\ &= .29 \text{ in}^2 \\ &= 5 \cdot (\text{tn} - \text{trn}) \cdot \text{fr2} \cdot \text{tn} \\ &= 5 \cdot (0.25 - 0.0178) \cdot 1 \cdot 0.25 \\ &= .29 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A_{41} &= \text{Leg}^2 \cdot \text{fr2} \\ &= 0.25^2 \cdot 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A_1 + A_2 + A_{41} \\ &= 0.812 + 0.29 + 0.063 \\ &= 1.165 \text{ in}^2 \end{aligned}$$

As $\text{Area} > A$ the reinforcement is adequate for $\text{MAP} = 79.06141$ at 70 Deg F

N1-CENTER

Reinforcement check in the plane parallel to the long. axis

Area required

$$\begin{aligned} A &= d*tr*F + 2*tn*tr*F*(1 - fr1) \\ &= 7.5*0.1427*1 + 2*0.25*0.1427*1*(1 - 1) \\ &= 1.07025 \text{ in}^2 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} = .805 \text{ in}^2$$

$$\begin{aligned} &= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 7.5*(1*0.25-1*0.1427) - 2*0.25*(1*0.25-1*0.1427)*(1-1) \\ &= .805 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 2*(0.25+0.25)*(1*0.25-1*0.1427) - 2*0.25*(1*0.25-1*0.1427)*(1-1) \\ &= .107 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.805 + 0.29 + 0.063 \\ &= 1.158 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAP = 79.06141 at 70 Deg F

Check the welds - From UW-16(d):

$$\begin{aligned} t_{\min} &= \text{lesser of } 0.75 \text{ or } t_n \text{ or } t, t_{\min} = 0.25 \text{ in} \\ t1 \text{ or } t2(\min) &= \text{lesser of } 0.25 \text{ or } 0.7*t_{\min}, t1(\min) = 0.175 \text{ in} \\ t1(\text{actual}) &= 0.7*\text{Leg} = 0.7*0.25 = 0.175 \text{ in} \\ t2(\text{actual}) &= 0.1875 \text{ in} \\ t1 + t2 &= 0.3625 \geq 1.25*t_{\min} \end{aligned}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.0178 in (E = 1)
Wall thickness per UG-45(b)(1):	tr2 = 0.1427 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.1427 in
The lesser of tr4 or tr5:	tr6 = 0.1427 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.1427 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for MAP.

Allowable stresses in joints UG-45(c) and UW-15(c)

N1-CENTER

Groove weld in tension = $0.74 \times 16700 = 12358$ psi
Nozzle wall in shear = $0.7 \times 16700 = 11690$ psi
Inner fillet weld in shear = $0.49 \times 16700 = 8183$ psi

Strength of welded joints:

(1) Inner fillet weld in shear

$$(\pi/2) \times \text{Nozzle O.D.} \times \text{Leg} \times S_i = 1.57 \times 8 \times 0.25 \times 8183 = 25694.62 \text{ lbf}$$

(3) Nozzle wall in shear

$$(\pi/2) \times \text{Mean nozzle dia.} \times t_n \times S_n = 1.57 \times 7.75 \times 0.25 \times 11690 = 35559.52 \text{ lbf}$$

(4) Groove weld in tension

$$(\pi/2) \times \text{Nozzle O.D.} \times t_w \times S_g = 1.57 \times 8 \times 0.1875 \times 12358 = 29103.09 \text{ lbf}$$

Loading on welds per UG-41(b) (1)

$$\begin{aligned} W &= (A - (d - 2 \times t_n) \times (E_1 \times t - F \times t_r)) \times S_v \\ &= (1.0798 - (7.567 - 2 \times 0.25) \times (1 \times 0.25 - 1 \times 0.1427)) \times 16700 \\ &= 5369.232 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W_{1-1} &= (A_2 + A_5 + A_{41} + A_{42}) \times S_v \\ &= (0.29 + 0 + 0.063 + 0) \times 16700 \\ &= 5895.1 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W_{2-2} &= (A_2 + A_3 + A_{41} + A_{43} + 2 \times t_n \times t \times f_{r1}) \times S_v \\ &= (0.29 + 0 + 0.063 + 0 + 2 \times 0.25 \times 0.25 \times 1) \times 16700 \\ &= 7982.6 \text{ lbf} \end{aligned}$$

Load for path 1-1 lesser of W or $W_{1-1} = 5369.232$ lbf
Path 1-1 Thru (1) & (3) = $25694.62 + 35559.52 = 61254.14$ lbf
Path 1-1 is stronger than W so it is acceptable per UG-41(b) (2).

Load for path 2-2 lesser of W or $W_{2-2} = 5369.232$ lbf
Path 2-2 Thru (1), (4) = $25694.62 + 29103.09 = 54797.71$ lbf
Path 2-2 is stronger than W so it is acceptable per UG-41(b) (2).

Reinforcement Calculations for External Pressure

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.567$ in
Normal to the vessel wall outside $2.5 \times (t_n - C_n) + t_e = .625$ in
Normal to the vessel wall inside $2.5 \times (t_n - C_n - C) = .625$ in

Determination of Chord Length

$$\begin{aligned} \text{Theta}_1 &= \text{ArcCos}((L_o + R_n)/R_m) \\ &= \text{ArcCos}((8 + 3.75)/60.34865) \\ &= 78.77312 \end{aligned}$$

$$\begin{aligned} \text{Theta}_2 &= \text{ArcCos}((L_o - R_n)/R_m) \\ &= \text{ArcCos}((8 - 3.75)/60.34865) \end{aligned}$$

N1-CENTER

$$= 85.96212$$

$$\begin{aligned}d &= 2*Rm*\sin((\text{Theta}2 - \text{Theta}1)/2) \\ &= 2*60.34865*\sin((85.96212 - 78.77312)/2) \\ &= 7.567 \text{ in}\end{aligned}$$

Nozzle required thickness

$$\begin{array}{ll}L/Do = 3.527/8 = .4409 & Do/t = 8/0.01981 = 403.8364 \\ \text{From table G:} & A = 0.000383 \\ \text{From table HA-3:} & B = 4746.9\end{array}$$

$$\begin{aligned}Pa &= 4*B/(3*Do/t) \\ &= 4*4746.9/(3*8/0.01981) \\ &= 15.6727 \text{ psi}\end{aligned}$$

$$\text{Nozzle required thickness } trn = .01981 \text{ in}$$

Required thickness tr from UG-37(d)(1) = .1973 in

Area required

$$\text{Allowable stresses: } Sn = 14700, \quad Sv = 14700, \quad \text{psi}$$

$$\begin{aligned}fr1 &= \text{lesser of } 1 \text{ or } Sn/Sv \text{ so } fr1 = 1 \\ fr2 &= \text{lesser of } 1 \text{ or } Sn/Sv \text{ so } fr2 = 1\end{aligned}$$

$$\begin{aligned}A &= 0.5*(d*tr*F + 2*tn*tr*F*(1 - fr1)) \\ &= 0.5*(7.567*0.1973*1 + 2*0.25*0.1973*1*(1 - 1)) \\ &= .7465 \text{ in}^2\end{aligned}$$

Area available

$$A1 = \text{larger of the following} \quad = .399 \text{ in}^2$$

$$\begin{aligned}&= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 7.567*(1*0.25-1*0.1973) - 2*0.25*(1*0.25-1*0.1973)*(1-1) \\ &= .399 \text{ in}^2\end{aligned}$$

$$\begin{aligned}&= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 2*(0.25+0.25)*(1*0.25-1*0.1973) - 2*0.25*(1*0.25-1*0.1973)*(1-1) \\ &= .053 \text{ in}^2\end{aligned}$$

$$A2 = \text{smaller of the following} \quad = 0.288 \text{ in}^2$$

$$\begin{aligned}&= 5*(tn - trn)*fr2*t \\ &= 5*(0.25 - 0.01981)*1*0.25 \\ &= .288 \text{ in}^2\end{aligned}$$

$$\begin{aligned}&= 5*(tn - trn)*fr2*tn \\ &= 5*(0.25 - 0.01981)*1*0.25 \\ &= .288 \text{ in}^2\end{aligned}$$

N1-CENTER

$$\begin{aligned} A41 &= \text{Leg}^2 * fr2 \\ &= 0.25^2 * 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.399 + 0.288 + 0.063 \\ &= .75 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for Pe = 15.58935 at 400 Deg F

Reinforcement check in the plane parallel to the long. axis

Area required

$$\begin{aligned} A &= 0.5 * (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \\ &= 0.5 * (7.5 * 0.1973 * 1 + 2 * 0.25 * 0.1973 * 1 * (1 - 1)) \\ &= .739875 \text{ in}^2 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} = .395 \text{ in}^2$$

$$\begin{aligned} &= d * (E1 * t - F * tr) - 2 * tn * (E1 * t - F * tr) * (1 - fr1) \\ &= 7.5 * (1 * 0.25 - 1 * 0.1973) - 2 * 0.25 * (1 * 0.25 - 1 * 0.1973) * (1 - 1) \\ &= .395 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 * (t + tn) * (E1 * t - F * tr) - 2 * tn * (E1 * t - F * tr) * (1 - fr1) \\ &= 2 * (0.25 + 0.25) * (1 * 0.25 - 1 * 0.1973) - 2 * 0.25 * (1 * 0.25 - 1 * 0.1973) * (1 - 1) \\ &= .053 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.395 + 0.288 + 0.063 \\ &= .746 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for Pe = 15.58935 at 400 Deg F

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.01981 in (E = 1)
Wall thickness per UG-45(b) (2):	tr2 = 0.032 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b) (4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.0625 in
The lesser of tr4 or tr5:	tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for Pe.


N2-RIGHT

Opening n2 Reinforcement Calculations Per UG-37

Located on: 60" F&D HAM HEAD
User input vessel thickness: .25 in
Liquid static head included: 0 psi
Flange description: Not installed

Nozzle material specification: SA 240 304L HIGH

Nozzle orientation: 90 degrees
End of nozzle to datum line: 14.53 in
Nozzle calculated as hillside: yes
Projection outside vessel Lpr: 5.082 in



Reinforcement Calculations For Nozzle MAWP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.771$ in
Normal to the vessel wall outside $2.5*(tn-Cn) + te = .625$ in
Normal to the vessel wall inside $2.5*(tn-Cn-C) = .625$ in

Determination of Chord Length

$$\begin{aligned}\text{Theta1} &= \text{ArcCos}((Lo + Rn)/Rm) \\ &= \text{ArcCos}((15.75 + 3.75)/60.32135) \\ &= 71.13968\end{aligned}$$

$$\begin{aligned}\text{Theta2} &= \text{ArcCos}((Lo - Rn)/Rm) \\ &= \text{ArcCos}((15.75 - 3.75)/60.32135) \\ &= 78.52576\end{aligned}$$

$$\begin{aligned}d &= 2*Rm*\text{Sin}((\text{Theta2} - \text{Theta1})/2) \\ &= 2*60.32135*\text{Sin}((78.52576 - 71.13968)/2) \\ &= 7.771 \text{ in}\end{aligned}$$

Nozzle required thickness

$$\begin{aligned}trn &= P*Rn/(Sn*E - 0.6*P) \\ &= 79.06141*3.75/(16700*1 - 0.6*79.06141) \\ &= 0.0178 \text{ in}\end{aligned}$$

N2-RIGHT

Required thickness tr from UG-37(a) (1)

$$\begin{aligned} tr &= P*L*M/(2*S*E - 0.2*P) \\ &= 79.06141*60.25*1/(2*16700*1 - 0.2*79.06141) \\ &= 0.1427 \text{ in} \end{aligned}$$

Area required

Allowable stresses: $S_n = 16700$, $S_v = 16700$, psi

fr1 = lesser of 1 or S_n/S_v so fr1 = 1

fr2 = lesser of 1 or S_n/S_v so fr2 = 1

$$\begin{aligned} A &= d*tr*F + 2*tn*tr*F*(1 - fr1) \\ &= 7.771*0.1427*1 + 2*0.25*0.1427*1*(1 - 1) \\ &= 1.1089 \text{ in}^2 \end{aligned}$$

Area available

A1 = larger of the following = .834 in²

$$\begin{aligned} &= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 7.771*(1*0.25-1*0.1427) - 2*0.25*(1*0.25-1*0.1427)*(1-1) \\ &= .834 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 2*(0.25+0.25)*(1*0.25-1*0.1427) - 2*0.25*(1*0.25-1*0.1427)*(1-1) \\ &= .107 \text{ in}^2 \end{aligned}$$

A2 = smaller of the following = 0.29 in²

$$\begin{aligned} &= 5*(tn - trn)*fr2*t \\ &= 5*(0.25 - 0.0178)*1*0.25 \\ &= .29 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5*(tn - trn)*fr2*tn \\ &= 5*(0.25 - 0.0178)*1*0.25 \\ &= .29 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A41 &= \text{Leg}^2*fr2 \\ &= 0.25^2*1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.834 + 0.29 + 0.063 \\ &= 1.187 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAWP = 79.06141 at 0 Deg F

Reinforcement check in the plane parallel to the long. axis

Area required

$$A = d*tr*F + 2*tn*tr*F*(1 - fr1)$$

N2-RIGHT

$$\begin{aligned} &= 7.5 \times 0.1427 \times 1 + 2 \times 0.25 \times 0.1427 \times 1 \times (1 - 1) \\ &= 1.07025 \text{ in}^2 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} = .805 \text{ in}^2$$

$$\begin{aligned} &= d \times (E1 \times t - F \times tr) - 2 \times tn \times (E1 \times t - F \times tr) \times (1 - fr1) \\ &= 7.5 \times (1 \times 0.25 - 1 \times 0.1427) - 2 \times 0.25 \times (1 \times 0.25 - 1 \times 0.1427) \times (1 - 1) \\ &= .805 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 \times (t + tn) \times (E1 \times t - F \times tr) - 2 \times tn \times (E1 \times t - F \times tr) \times (1 - fr1) \\ &= 2 \times (0.25 + 0.25) \times (1 \times 0.25 - 1 \times 0.1427) - 2 \times 0.25 \times (1 \times 0.25 - 1 \times 0.1427) \times (1 - 1) \\ &= .107 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.805 + 0.29 + 0.063 \\ &= 1.158 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAWP = 79.06141 at 0 Deg F

Check the welds - From UW-16(d):

$$\begin{aligned} t_{\min} &= \text{lesser of } 0.75 \text{ or } t_n \text{ or } t, t_{\min} = 0.25 \text{ in} \\ t1 \text{ or } t2(\min) &= \text{lesser of } 0.25 \text{ or } 0.7 \times t_{\min}, t1(\min) = 0.175 \text{ in} \\ t1(\text{actual}) &= 0.7 \times \text{Leg} = 0.7 \times 0.25 = 0.175 \text{ in} \\ t2(\text{actual}) &= 0.1875 \text{ in} \\ t1 + t2 &= 0.3625 \geq 1.25 \times t_{\min} \end{aligned}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.0178 in (E = 1)
Wall thickness per UG-45(b)(1):	tr2 = 0.1427 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.1427 in
The lesser of tr4 or tr5:	tr6 = 0.1427 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.1427 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for MAWP.

Allowable stresses in joints UG-45(c) and UW-15(c)

$$\begin{aligned} \text{Groove weld in tension} &= 0.74 \times 16700 = 12358 \text{ psi} \\ \text{Nozzle wall in shear} &= 0.7 \times 16700 = 11690 \text{ psi} \\ \text{Inner fillet weld in shear} &= 0.49 \times 16700 = 8183 \text{ psi} \end{aligned}$$

Strength of welded joints:

N2-RIGHT

(1) Inner fillet weld in shear

$$(\text{Pi}/2) * \text{Nozzle O.D.} * \text{Leg} * \text{Si} = 1.57 * 8 * 0.25 * 8183 = 25694.62 \text{ lbf}$$

(3) Nozzle wall in shear

$$(\text{Pi}/2) * \text{Mean nozzle dia.} * \text{tn} * \text{Sn} = 1.57 * 7.75 * 0.25 * 11690 = 35559.52 \text{ lbf}$$

(4) Groove weld in tension

$$(\text{Pi}/2) * \text{Nozzle O.D.} * \text{tw} * \text{Sg} = 1.57 * 8 * 0.1875 * 12358 = 29103.09 \text{ lbf}$$

Loading on welds per UG-41(b) (1)

$$\begin{aligned} W &= (A - (d - 2 * \text{tn}) * (E1 * t - F * \text{tr})) * \text{Sv} \\ &= (1.1089 - (7.771 - 2 * 0.25) * (1 * 0.25 - 1 * 0.1427)) * 16700 \\ &= 5489.652 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W1-1 &= (A2 + A5 + A41 + A42) * \text{Sv} \\ &= (0.29 + 0 + 0.063 + 0) * 16700 \\ &= 5895.1 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W2-2 &= (A2 + A3 + A41 + A43 + 2 * \text{tn} * t * \text{fr1}) * \text{Sv} \\ &= (0.29 + 0 + 0.063 + 0 + 2 * 0.25 * 0.25 * 1) * 16700 \\ &= 7982.6 \text{ lbf} \end{aligned}$$

Load for path 1-1 lesser of W or W1-1 = 5489.652 lbf

Path 1-1 Thru (1) & (3) = 25694.62 + 35559.52 = 61254.14 lbf

Path 1-1 is stronger than W so it is acceptable per UG-41(b) (2).

Load for path 2-2 lesser of W or W2-2 = 5489.652 lbf

Path 2-2 Thru (1), (4) = 25694.62 + 29103.09 = 54797.71 lbf

Path 2-2 is stronger than W so it is acceptable per UG-41(b) (2).

Reinforcement Calculations For Nozzle MAP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.771$ in

Normal to the vessel wall outside $2.5 * (\text{tn} - \text{Cn}) + \text{te} = .625$ in

Normal to the vessel wall inside $2.5 * (\text{tn} - \text{Cn} - \text{C}) = .625$ in

Determination of Chord Length

$$\begin{aligned} \text{Theta1} &= \text{ArcCos}((\text{Lo} + \text{Rn}) / \text{Rm}) \\ &= \text{ArcCos}((15.75 + 3.75) / 60.32135) \\ &= 71.13968 \end{aligned}$$

$$\begin{aligned} \text{Theta2} &= \text{ArcCos}((\text{Lo} - \text{Rn}) / \text{Rm}) \\ &= \text{ArcCos}((15.75 - 3.75) / 60.32135) \\ &= 78.52576 \end{aligned}$$

$$\begin{aligned} d &= 2 * \text{Rm} * \text{Sin}((\text{Theta2} - \text{Theta1}) / 2) \\ &= 2 * 60.32135 * \text{Sin}((78.52576 - 71.13968) / 2) \\ &= 7.771 \text{ in} \end{aligned}$$

N2-RIGHT

Nozzle required thickness

$$\begin{aligned} trn &= P \cdot Rn / (Sn \cdot E - 0.6 \cdot P) \\ &= 79.06141 \cdot 3.75 / (16700 \cdot 1 - 0.6 \cdot 79.06141) \\ &= 0.0178 \text{ in} \end{aligned}$$

Required thickness tr from UG-37(a) (1)

$$\begin{aligned} tr &= P \cdot L \cdot M / (2 \cdot S \cdot E - 0.2 \cdot P) \\ &= 79.06141 \cdot 60.25 \cdot 1 / (2 \cdot 16700 \cdot 1 - 0.2 \cdot 79.06141) \\ &= 0.1427 \text{ in} \end{aligned}$$

Area required

Allowable stresses: Sn = 16700, Sv = 16700, psi

fr1 = lesser of 1 or Sn/Sv so fr1 = 1
fr2 = lesser of 1 or Sn/Sv so fr2 = 1

$$\begin{aligned} A &= d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F \cdot (1 - fr1) \\ &= 7.771 \cdot 0.1427 \cdot 1 + 2 \cdot 0.25 \cdot 0.1427 \cdot 1 \cdot (1 - 1) \\ &= 1.1089 \text{ in}^2 \end{aligned}$$

Area available

A1 = larger of the following = .834 in²

$$\begin{aligned} &= d \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1) \\ &= 7.771 \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) - 2 \cdot 0.25 \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) \cdot (1 - 1) \\ &= .834 \text{ in}^2 \\ &= 2 \cdot (t + tn) \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1) \\ &= 2 \cdot (0.25 + 0.25) \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) - 2 \cdot 0.25 \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) \cdot (1 - 1) \\ &= .107 \text{ in}^2 \end{aligned}$$

A2 = smaller of the following = 0.29 in²

$$\begin{aligned} &= 5 \cdot (tn - trn) \cdot fr2 \cdot t \\ &= 5 \cdot (0.25 - 0.0178) \cdot 1 \cdot 0.25 \\ &= .29 \text{ in}^2 \\ &= 5 \cdot (tn - trn) \cdot fr2 \cdot tn \\ &= 5 \cdot (0.25 - 0.0178) \cdot 1 \cdot 0.25 \\ &= .29 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A41 &= Leg^2 \cdot fr2 \\ &= 0.25^2 \cdot 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.834 + 0.29 + 0.063 \\ &= 1.187 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAP = 79.06141 at 70 Deg F

N2-RIGHT

Reinforcement check in the plane parallel to the long. axis

Area required

$$\begin{aligned} A &= d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F \cdot (1 - fr1) \\ &= 7.5 \cdot 0.1427 \cdot 1 + 2 \cdot 0.25 \cdot 0.1427 \cdot 1 \cdot (1 - 1) \\ &= 1.07025 \text{ in}^2 \end{aligned}$$

Area available

$$\begin{aligned} A1 &= \text{larger of the following} &&= .805 \text{ in}^2 \\ &= d \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1) \\ &= 7.5 \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) - 2 \cdot 0.25 \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) \cdot (1 - 1) \\ &= .805 \text{ in}^2 \\ &= 2 \cdot (t + tn) \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1) \\ &= 2 \cdot (0.25 + 0.25) \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) - 2 \cdot 0.25 \cdot (1 \cdot 0.25 - 1 \cdot 0.1427) \cdot (1 - 1) \\ &= .107 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.805 + 0.29 + 0.063 \\ &= 1.158 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAP = 79.06141 at 70 Deg F

Check the welds - From UW-16(d):

$$\begin{aligned} t_{min} &= \text{lesser of } 0.75 \text{ or } tn \text{ or } t, t_{min} = 0.25 \text{ in} \\ t1 \text{ or } t2(\text{min}) &= \text{lesser of } 0.25 \text{ or } 0.7 \cdot t_{min}, t1(\text{min}) = 0.175 \text{ in} \\ t1(\text{actual}) &= 0.7 \cdot \text{Leg} = 0.7 \cdot 0.25 = 0.175 \text{ in} \\ t2(\text{actual}) &= 0.1875 \text{ in} \\ t1 + t2 &= 0.3625 \geq 1.25 \cdot t_{min} \end{aligned}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.0178 in (E = 1)
Wall thickness per UG-45(b)(1):	tr2 = 0.1427 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.1427 in
The lesser of tr4 or tr5:	tr6 = 0.1427 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.1427 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for MAP.

Allowable stresses in joints UG-45(c) and UW-15(c)

N2-RIGHT

Groove weld in tension = $0.74 \times 16700 = 12358$ psi
Nozzle wall in shear = $0.7 \times 16700 = 11690$ psi
Inner fillet weld in shear = $0.49 \times 16700 = 8183$ psi

Strength of welded joints:

(1) Inner fillet weld in shear

$$(\pi/2) \times \text{Nozzle O.D.} \times \text{Leg} \times S_i = 1.57 \times 8 \times 0.25 \times 8183 = 25694.62 \text{ lbf}$$

(3) Nozzle wall in shear

$$(\pi/2) \times \text{Mean nozzle dia.} \times t_n \times S_n = 1.57 \times 7.75 \times 0.25 \times 11690 = 35559.52 \text{ lbf}$$

(4) Groove weld in tension

$$(\pi/2) \times \text{Nozzle O.D.} \times t_w \times S_g = 1.57 \times 8 \times 0.1875 \times 12358 = 29103.09 \text{ lbf}$$

Loading on welds per UG-41(b) (1)

$$\begin{aligned} W &= (A - (d - 2 \times t_n) \times (E_1 \times t - F \times t_r)) \times S_v \\ &= (1.1089 - (7.771 - 2 \times 0.25) \times (1 \times 0.25 - 1 \times 0.1427)) \times 16700 \\ &= 5489.652 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W_{1-1} &= (A_2 + A_5 + A_{41} + A_{42}) \times S_v \\ &= (0.29 + 0 + 0.063 + 0) \times 16700 \\ &= 5895.1 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W_{2-2} &= (A_2 + A_3 + A_{41} + A_{43} + 2 \times t_n \times t \times f_{r1}) \times S_v \\ &= (0.29 + 0 + 0.063 + 0 + 2 \times 0.25 \times 0.25 \times 1) \times 16700 \\ &= 7982.6 \text{ lbf} \end{aligned}$$

Load for path 1-1 lesser of W or $W_{1-1} = 5489.652$ lbf
Path 1-1 Thru (1) & (3) = $25694.62 + 35559.52 = 61254.14$ lbf
Path 1-1 is stronger than W so it is acceptable per UG-41(b) (2).

Load for path 2-2 lesser of W or $W_{2-2} = 5489.652$ lbf
Path 2-2 Thru (1), (4) = $25694.62 + 29103.09 = 54797.71$ lbf
Path 2-2 is stronger than W so it is acceptable per UG-41(b) (2).

Reinforcement Calculations for External Pressure

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.77$ in
Normal to the vessel wall outside $2.5 \times (t_n - C_n) + t_e = .625$ in
Normal to the vessel wall inside $2.5 \times (t_n - C_n - C) = .625$ in

Determination of Chord Length

$$\begin{aligned} \text{Theta}_1 &= \text{ArcCos}((L_o + R_n)/R_m) \\ &= \text{ArcCos}((15.75 + 3.75)/60.34685) \\ &= 71.14795 \end{aligned}$$

$$\begin{aligned} \text{Theta}_2 &= \text{ArcCos}((L_o - R_n)/R_m) \\ &= \text{ArcCos}((15.75 - 3.75)/60.34685) \end{aligned}$$

N2-RIGHT

$$= 78.53069$$

$$\begin{aligned}d &= 2*Rm*\sin((\text{Theta}2 - \text{Theta}1)/2) \\ &= 2*60.34685*\sin((78.53069 - 71.14795)/2) \\ &= 7.77 \text{ in}\end{aligned}$$

Nozzle required thickness

$$\begin{aligned}L/Do &= 5.082/8 = .6352 & Do/t &= 8/0.02205 = 362.8118 \\ \text{From table G:} & & A &= 0.000317 \\ \text{From table HA-3:} & & B &= 4194.4\end{aligned}$$

$$\begin{aligned}Pa &= 4*B/(3*Do/t) \\ &= 4*4194.4/(3*8/0.02205) \\ &= 15.4144 \text{ psi}\end{aligned}$$

$$\text{Nozzle required thickness } trn = .02205 \text{ in}$$

Required thickness tr from UG-37(d)(1) = .1937 in

Area required

$$\text{Allowable stresses: } Sn = 14700, \quad Sv = 14700, \quad \text{psi}$$

$$\begin{aligned}fr1 &= \text{lesser of } 1 \text{ or } Sn/Sv \text{ so } fr1 = 1 \\ fr2 &= \text{lesser of } 1 \text{ or } Sn/Sv \text{ so } fr2 = 1\end{aligned}$$

$$\begin{aligned}A &= 0.5*(d*tr*F + 2*tn*tr*F*(1 - fr1)) \\ &= 0.5*(7.77*0.1937*1 + 2*0.25*0.1937*1*(1 - 1)) \\ &= .7525 \text{ in}^2\end{aligned}$$

Area available

$$A1 = \text{larger of the following} \quad = .437 \text{ in}^2$$

$$\begin{aligned}&= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 7.77*(1*0.25-1*0.1937) - 2*0.25*(1*0.25-1*0.1937)*(1-1) \\ &= .437 \text{ in}^2\end{aligned}$$

$$\begin{aligned}&= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 2*(0.25+0.25)*(1*0.25-1*0.1937) - 2*0.25*(1*0.25-1*0.1937)*(1-1) \\ &= .056 \text{ in}^2\end{aligned}$$

$$A2 = \text{smaller of the following} \quad = 0.285 \text{ in}^2$$

$$\begin{aligned}&= 5*(tn - trn)*fr2*t \\ &= 5*(0.25 - 0.02205)*1*0.25 \\ &= .285 \text{ in}^2\end{aligned}$$

$$\begin{aligned}&= 5*(tn - trn)*fr2*tn \\ &= 5*(0.25 - 0.02205)*1*0.25 \\ &= .285 \text{ in}^2\end{aligned}$$

N2-RIGHT

$$\begin{aligned} A41 &= \text{Leg}^2 * fr2 \\ &= 0.25^2 * 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.437 + 0.285 + 0.063 \\ &= .785 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for Pe = 15.31362 at 400 Deg F

Reinforcement check in the plane parallel to the long. axis

Area required

$$\begin{aligned} A &= 0.5 * (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \\ &= 0.5 * (7.5 * 0.1937 * 1 + 2 * 0.25 * 0.1937 * 1 * (1 - 1)) \\ &= .726375 \text{ in}^2 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} = .422 \text{ in}^2$$

$$\begin{aligned} &= d * (E1 * t - F * tr) - 2 * tn * (E1 * t - F * tr) * (1 - fr1) \\ &= 7.5 * (1 * 0.25 - 1 * 0.1937) - 2 * 0.25 * (1 * 0.25 - 1 * 0.1937) * (1 - 1) \\ &= .422 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 * (t + tn) * (E1 * t - F * tr) - 2 * tn * (E1 * t - F * tr) * (1 - fr1) \\ &= 2 * (0.25 + 0.25) * (1 * 0.25 - 1 * 0.1937) - 2 * 0.25 * (1 * 0.25 - 1 * 0.1937) * (1 - 1) \\ &= .056 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.422 + 0.285 + 0.063 \\ &= .77 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for Pe = 15.31362 at 400 Deg F

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.02205 in (E = 1)
Wall thickness per UG-45(b)(2):	tr2 = 0.0314 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.0625 in
The lesser of tr4 or tr5:	tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for Pe.

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-074
REV.	DEO #	DATE	BY:	CHECK	PAGE 1 OF 38	
0	0029	3-30-96	AGR	RDC	TITLE: 84" F+D HEAD/NOZZLE DESIGN FOR HAM	
					By: AAT KOUSSOPOULOS DEPT.: 749	
<u>PROJECT:</u> L160					<u>PROJECT NO:</u> V59049	
<u>PURPOSE:</u> QUALIFY THE DESIGN OF THE 84" HAM COVER TO ASME VIII REQUIREMENTS						
<u>METHOD:</u> COMPRESS 5.53 COMPUTER PRESSURE VESSEL SOFTWARE						
<u>ASSUMPTIONS:</u> SEE CALCS						
<u>INPUTS:</u> "STRUCTURAL DESIGN CRITERIA" REF: DOC. NO. V049-1-066						
<u>REFERENCES:</u> DOC. NO. V049-PL-73 DWG. NO. V049-A-040 Doc. No. V049-1-066, L160 VACUUM EQUIP., STRUCTURAL DESIGN CONSULT						
<u>CALCULATIONS:</u> (SEE ATTACHED)						
<u>CONCLUSIONS:</u> COVER/NOZZLE DESIGN IS IN CONFORMANCE WITH ASME VIII REQUIREMENTS						
<u>NOTES:</u>						

TABLE OF CONTENTS

	<u>PAGE</u>
1. - SCOPE:	3
2. - DESIGN CRITERIA:	3
3. - MODEL	3
4. - COMPRESS S. 53 - INPUT DATA	4
5. - COMPRESS S. 53 - OUTPUT	5-38

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS




1. - SCOPE:

- QUALIFY THE 84" HAM COVER TO ASME VIII REQUIREMENTS FOR THE NOZZLE LAYOUT AS PSl PROPOSED AND CUSTOMER ACCEPTANCE PER DOC. NO. V049-PL-73

2. DESIGN CRITERIA:

$P_{EXT.} = 14.7 \text{ PSI}$
 $T = 400^{\circ}\text{F}$

3. MODEL:



- NOZZLE LOCATION DATA:

- N1 $r_1 = 7.875''$; $\theta_1 = 0^{\circ}$
- N2 $r_2 = \sqrt{21.25^2 + 7.875^2} = 22.66''$; $\theta_2 = \tan^{-1} \frac{21.25}{7.875} = 69.7^{\circ}$
- N3 $r_3 = r_2 = 22.66''$; $\theta_3 = (90 - 69.7) + 270 = 290.3^{\circ}$
- N4 $r_4 = \sqrt{10.8125^2 + 20.3125^2} = 23.01''$; $\theta_4 = \tan^{-1} \frac{10.8125}{20.3125} = 28.03^{\circ}$
- N5 $r_5 = r_4 = 23.01''$; $\theta_5 = (90 - 28.03) + 270 = 331.97^{\circ}$

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



4 - COMPRESS 5.53 - INPUT DATA:

• MATERIAL:

- F+D HEAD: SA 240 304L HIGH
- NOZZLES (ALL) SA 240 304L HIGH

• EXTERNAL PRESSURE = 14.7 PSI

• DESIGN TEMP. = 400°F

FOR F+D HEAD:

- LONG SEAM X-RAY
- SEAMLESS ∴ NO XRAY
- HEAD/SHELL SEAM X-RAY
- SPOT PER UW-11(B) TYPE I
- ID = 84.25"
- CROWN INTERNAL RADIUS = 85"
- KNUCKLE INTERNAL RADIUS = 5.25"
- FORMING ALLOWANCE = 0"
- STRAIGHT FLANGE = 2"
- THICKNESS = .375"

FOR NOZZLES:

- ID = 7.75" (ALL)
- THICKNESS = .1875" (ALL)
- ANGLE θ DISTANCE r
- N1: $\theta_1 = 0^\circ$ $r_1 = 7.875"$
- N2: $\theta_2 = 69.7^\circ$ $r_2 = 22.66"$
- N3: $\theta_3 = 290.7^\circ$ $r_3 = 22.66"$
- N4: $\theta_4 = 28.03^\circ$ $r_4 = 23.01"$
- N5: $\theta_5 = 331.97^\circ$ $r_5 = 23.01"$



5. COMPRESS 5.53 - OUTPUT

OUTPUT FOR 84" F+D HEAD, NOZZLES 1, 2 AND 4 ARE ATTACHED TO VERIFY COMPLIANCE TO ASME VIII : EDITION, INCLUDING A9 ADDENDA.

NOTE: THAT ANALYSIS/RESULTS FOR NOZZLE #3 IS SYMMETRICALLY IDENTICAL TO NOZZLE #2 AND NOZZLE #5 IS IDENTICAL TO #4

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



TABLE OF CONTENTS

Pressure Summary	1
Weight Summary	2
Nozzle Summary	3
Thickness Summary	4
84" F&D HAM HEAD	5
N1-1ST ROW-CENTER	6
N2-1ST ROW-RIGHT	15
N4-2ND ROW-RIGHT	24
Total Pages In This Report	32

Pressure Summary

Pressure summary for pressure chamber 1

Identifier	Nozzle	T	MAMP	MAP	Pe	UG-99	UCS-66		Corrosion
	Status (UG-45)	design (deg F)	(psi)	(psi)	external (psi)	Ratio	MDMT (deg F)	Exemption or Stress Reduction	Allowance (in)
84" P&D HAM HEAD		0.0	72.1	72.1	22.4	1.000		Not applicable	0.000
N1 N1-1ST ROW-CENTE	ok	0.0	83.5	83.5	15.7	1.000		Not applicable	0.000
N2 N2-1ST ROW-RIGHT	ok	0.0	83.2	83.0	15.8	1.000		Not applicable	0.000
N3 N3-1ST ROW-LEPT	ok	0.0	83.2	83.0	15.8	1.000		Not applicable	0.000
N4 N4-2ND ROW-RIGHT	ok	0.0	83.2	83.0	15.8	1.000		Not applicable	0.000
N5 N5-2ND ROW-LEPT	ok	0.0	83.2	83.0	15.8	1.000		Not applicable	0.000

Vessel MAWP hot & corroded is 72.11 psi @ 0 degrees F.

Vessel MAP new & cold is 72.11 psi @ 70 degrees F.

Vessel allowable external pressure is 15.76 psi @ 400 degrees F.

Hydrotest pressure calculation based on MAWP

$$= 1.5 * (\text{MAWP} + \text{Operating Liquid Head}) * 1 = 108.2 \text{ psi}$$

Vessel hydrotest pressure is 108.2 psi.

Note: vessel MAP rating not valid unless hydrotest pressure based on MAP.

Weight Summary

Component	Weight (lbs) Contributed by Vessel Elements											
	Metal New	Metal Corr	Trays & sup	Packed Beds	Insul	Lining	Piping	Ladder & plat	Rings & Misc	Oper Liquid	Test Liquid	Nozzle & flg
84" fed ham hea	822	822	0	0	0	0	0	0	0	0	2149	28
	822	822	0	0	0	0	0	0	0	0	2149	28

Vessel operating weight, corroded: 850 lbs
 Vessel empty weight, corroded: 850 lbs
 Vessel empty weight, new: 850 lbs
 Vessel test weight, new: 2,999 lbs

Vessel center of gravity location (from right weld seam)

Vessel lift weight, new: 848 lbs
 Center of gravity to seam: 10.6 in

Nozzle Summary

Nozzle mark	OD (in)	tn (in)	Req tn (in)	A1?	A2?	Nom t (in)	Req t (in)	User t (in)	Corr (in)	Aa/Ar (%)
N1	8.00	0.2500	0.2108	y	y	0.3750	0.2777	0.3750	0.0000	100.1
N2	8.00	0.2500	0.2101	y	y	0.3750	0.2789	0.3750	0.0000	100.0
N3	8.00	0.2500	0.2101	y	y	0.3750	0.2788	0.3750	0.0000	100.0
N4	8.00	0.2500	0.2101	y	y	0.3750	0.2787	0.3750	0.0000	100.0
N5	8.00	0.2500	0.2101	y	y	0.3750	0.2790	0.3750	0.0000	100.0

tn - nozzle thickness

Req tn - nozzle thickness required per UG-45/16

Nom t - vessel wall thickness

Req t - required vessel wall thickness due to pressure + corr per UG-37

User t - local vessel wall thickness (near opening)

Aa - area available per UG-37, governing condition

Ar - area required per UG-37, governing condition

Corr - corrosion allowance on nozzle id.

Thickness Summary

Component Identifier	ID (in)	Length (in)	Nom t (in)	Req t (in)	Joint E	Governing Load Status	Stress	Deflect (in)
84" f&d hem head	84.25		0.3750	0.3750	0.85			

Nom t - vessel wall thickness
Req t - required vessel wall thickness due to governing loading
E - longitudinal seam joint efficiency

Load:
internal - circ stress due to internal pressure governs
external - external pressure governs
wind - combined long stress due to STATUS + wind governs
seismic - combined long stress due to STATUS + seismic governs

84" F&D HAM HEAD

ASME Section VIII Division 1, 1992 Edition, A93 Addenda

Component: F&D head
Material specification: SA 240 304L HIGH

Corrosion allowance: Inner C = 0 Outer = 0 in

PWHT is not performed

Radiography: Category A joints - Seamless NO X-Ray
Head to shell seam - Spot UW-11(b) type 1

Estimated weight: new = 821.5 corr = 821.5 lb
capacity: new = 257.65 corr = 257.65 US ga

ID = 84.25 crown L = 84.25 knuckle r = 5.25 t = .375 in (min)

Straight flange = 2 forming allowance = 0 in

MAP: (New & at 70 deg F) Appendix 1-4(d) Eq 3

$$\begin{aligned} P &= 2*S*E*t / (L*M + 0.2*t) - P_s \\ &= 2*16700*0.85*0.375 / (84.25*1.7515 + 0.2*0.375) - 0 \\ &= 72.11008 \text{ psi} \end{aligned}$$

MAWP: (Corroded & at 0 deg F) Appendix 1-4(d) Eq 3

$$\begin{aligned} P &= 2*S*E*t / (L*M + 0.2*t) - P_s \\ &= 2*16700*0.85*0.375 / (84.25*1.7515 + 0.2*0.375) - 0 \\ &= 72.11008 \text{ psi} \end{aligned}$$

Maximum Allowable External Pressure: (Corroded @ 400 deg F)

$$\begin{aligned} A &= .125 / (R_o/t) \\ &= .125 / (84.625/0.375) \\ &= 0.000554 \end{aligned}$$

From table HA-3: B = 5065.4

$$\begin{aligned} P_a &= B / (R_o/t) \\ &= 5065.4 / (84.625/0.375) \\ &= 22.4464 \text{ psi} \end{aligned}$$

Check the Maximum External Pressure: UG-33(a)(1) & App. 1-4(d)

$$\begin{aligned} P_e &= 2*S*E*t / ((M*Lo - t*(M-0.2))*1.67) \\ &= 2*14700*1*0.375 / ((1.7515*84.625 - 0.375*(1.7515-0.2))*1.67) \\ &= 44.71584 \text{ psi} \end{aligned}$$

The maximum allowable external pressure is 22.4464 psi.


N1-1ST ROW-CENTER

Opening N1 Reinforcement Calculations Per UG-37

Located on: 84" F&D HAM HEAD
User input vessel thickness: .375 in
Liquid static head included: 0 psi
Flange description: Not installed

Nozzle material specification: SA 240 304L HIGH

Nozzle orientation: 0 degrees
End of nozzle to datum line: 19.782 in
Nozzle calculated as hillside: yes
Projection outside vessel Lpr: 3.39 in



corrosion allow = 0 in
noz thick new tn = .25 in
nozzle id. new d = 7.5 in
fillet weld tw1 = .25 in
groove weld tw2 = .1875 in

To head center R = 7.875 in

Reinforcement Calculations For Nozzle MAWP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.533$ in
Normal to the vessel wall outside $2.5 \cdot (tn - Cn) + te = .625$ in
Normal to the vessel wall inside $2.5 \cdot (tn - Cn - C) = .625$ in

Determination of Chord Length

$$\begin{aligned}\text{Theta1} &= \text{ArcCos}((Lo + Rn)/Rm) \\ &= \text{ArcCos}((7.875 + 3.75)/84.3554) \\ &= 82.07932\end{aligned}$$

$$\begin{aligned}\text{Theta2} &= \text{ArcCos}((Lo - Rn)/Rm) \\ &= \text{ArcCos}((7.875 - 3.75)/84.3554) \\ &= 87.19758\end{aligned}$$

$$\begin{aligned}d &= 2 \cdot Rm \cdot \text{Sin}((\text{Theta2} - \text{Theta1})/2) \\ &= 2 \cdot 84.3554 \cdot \text{Sin}((87.19758 - 82.07932)/2) \\ &= 7.533 \text{ in}\end{aligned}$$

Nozzle required thickness

$$\begin{aligned}trn &= P \cdot Rn / (Sn \cdot E - 0.6 \cdot P) \\ &= 83.53057 \cdot 3.75 / (16700 \cdot 1 - 0.6 \cdot 83.53057) \\ &= 0.0188 \text{ in}\end{aligned}$$

N1-1ST ROW-CENTER

Required thickness tr from UG-37(a) (1)

$$\begin{aligned} tr &= P*L*M/(2*S*E - 0.2*P) \\ &= 83.53057*84.25*1/(2*16700*1 - 0.2*83.53057) \\ &= 0.2108 \text{ in} \end{aligned}$$

Area required

Allowable stresses: $S_n = 16700$, $S_v = 16700$, psi

$fr_1 =$ lesser of 1 or S_n/S_v so $fr_1 = 1$
 $fr_2 =$ lesser of 1 or S_n/S_v so $fr_2 = 1$

$$\begin{aligned} A &= d*tr*F + 2*tn*tr*F*(1 - fr_1) \\ &= 7.533*0.2108*1 + 2*0.25*0.2108*1*(1 - 1) \\ &= 1.588 \text{ in}^2 \end{aligned}$$

Area available

$A_1 =$ larger of the following $= 1.237 \text{ in}^2$

$$\begin{aligned} &= d*(E_1*t - F*tr) - 2*tn*(E_1*t - F*tr)*(1 - fr_1) \\ &= 7.533*(1*0.375 - 1*0.2108) - 2*0.25*(1*0.375 - 1*0.2108)*(1 - 1) \\ &= 1.237 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2*(t + tn)*(E_1*t - F*tr) - 2*tn*(E_1*t - F*tr)*(1 - fr_1) \\ &= 2*(0.375 + 0.25)*(1*0.375 - 1*0.2108) - 2*0.25*(1*0.375 - 1*0.2108)*(1 - 1) \\ &= .205 \text{ in}^2 \end{aligned}$$

$A_2 =$ smaller of the following $= 0.289 \text{ in}^2$

$$\begin{aligned} &= 5*(tn - trn)*fr_2*t \\ &= 5*(0.25 - 0.0188)*1*0.375 \\ &= .433 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5*(tn - trn)*fr_2*tn \\ &= 5*(0.25 - 0.0188)*1*0.25 \\ &= .289 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A_{41} &= \text{Leg}^2*fr_2 \\ &= 0.25^2*1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A_1 + A_2 + A_{41} \\ &= 1.237 + 0.289 + 0.063 \\ &= 1.589 \text{ in}^2 \end{aligned}$$

As $\text{Area} > A$ the reinforcement is adequate for MAWP = 83.53057 at 0 Deg F

Reinforcement check in the plane parallel to the long. axis

Area required

$$A = d*tr*F + 2*tn*tr*F*(1 - fr_1)$$

N1-1ST ROW-CENTER

$$\begin{aligned} &= 7.5 \times 0.2108 \times 1 + 2 \times 0.25 \times 0.2108 \times 1 \times (1 - 1) \\ &= 1.581 \text{ in}^2 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} \quad = 1.231 \text{ in}^2$$

$$\begin{aligned} &= d \times (E1 \times t - F \times tr) - 2 \times tn \times (E1 \times t - F \times tr) \times (1 - fr1) \\ &= 7.5 \times (1 \times 0.375 - 1 \times 0.2108) - 2 \times 0.25 \times (1 \times 0.375 - 1 \times 0.2108) \times (1 - 1) \\ &= 1.231 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 \times (t + tn) \times (E1 \times t - F \times tr) - 2 \times tn \times (E1 \times t - F \times tr) \times (1 - fr1) \\ &= 2 \times (0.375 + 0.25) \times (1 \times 0.375 - 1 \times 0.2108) - 2 \times 0.25 \times (1 \times 0.375 - 1 \times 0.2108) \times (1 - 1) \\ &= .205 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 1.231 + 0.289 + 0.063 \\ &= 1.583 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAWP = 83.53057 at 0 Deg F

Check the welds - From UW-16(d):

$$\begin{aligned} t_{\min} &= \text{lesser of } 0.75 \text{ or } t_n \text{ or } t, t_{\min} = 0.25 \text{ in} \\ t1 \text{ or } t2(\min) &= \text{lesser of } 0.25 \text{ or } 0.7 \times t_{\min}, t1(\min) = 0.175 \text{ in} \\ t1(\text{actual}) &= 0.7 \times \text{Leg} = 0.7 \times 0.25 = 0.175 \text{ in} \\ t2(\text{actual}) &= 0.1875 \text{ in} \\ t1 + t2 &= 0.3625 \geq 1.25 \times t_{\min} \end{aligned}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.0188 in (E = 1)
Wall thickness per UG-45(b)(1):	tr2 = 0.2108 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.2108 in
The lesser of tr4 or tr5:	tr6 = 0.2108 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.2108 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for MAWP.

Allowable stresses in joints UG-45(c) and UW-15(c)

$$\begin{aligned} \text{Groove weld in tension} &= 0.74 \times 16700 = 12358 \text{ psi} \\ \text{Nozzle wall in shear} &= 0.7 \times 16700 = 11690 \text{ psi} \\ \text{Inner fillet weld in shear} &= 0.49 \times 16700 = 8183 \text{ psi} \end{aligned}$$

Strength of welded joints:

3.12.1996

N1-1ST ROW-CENTER

(1) Inner fillet weld in shear

$$(\text{Pi}/2) * \text{Nozzle O.D.} * \text{Leg} * \text{Si} = 1.57 * 8 * 0.25 * 8183 = 25694.62 \text{ lbf}$$

(3) Nozzle wall in shear

$$(\text{Pi}/2) * \text{Mean nozzle dia.} * \text{tn} * \text{Sn} = 1.57 * 7.75 * 0.25 * 11690 = 35559.52 \text{ lbf}$$

(4) Groove weld in tension

$$(\text{Pi}/2) * \text{Nozzle O.D.} * \text{tw} * \text{Sg} = 1.57 * 8 * 0.1875 * 12358 = 29103.09 \text{ lbf}$$

Loading on welds per UG-41(b) (1)

$$\begin{aligned} W &= (A - (d - 2 * \text{tn}) * (\text{E1} * t - F * \text{tr})) * \text{Sv} \\ &= (1.588 - (7.533 - 2 * 0.25) * (1 * 0.375 - 1 * 0.2108)) * 16700 \\ &= 7234.131 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W1-1 &= (A2 + A5 + A41 + A42) * \text{Sv} \\ &= (0.289 + 0 + 0.063 + 0) * 16700 \\ &= 5878.4 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W2-2 &= (A2 + A3 + A41 + A43 + 2 * \text{tn} * t * \text{fr1}) * \text{Sv} \\ &= (0.289 + 0 + 0.063 + 0 + 2 * 0.25 * 0.375 * 1) * 16700 \\ &= 9009.65 \text{ lbf} \end{aligned}$$

Load for path 1-1 lesser of W or W1-1 = 5878.4 lbf

Path 1-1 Thru (1) & (3) = 25694.62 + 35559.52 = 61254.14 lbf

Path 1-1 is stronger than W1-1 so it is acceptable per UG-41(b) (1).

Load for path 2-2 lesser of W or W2-2 = 7234.131 lbf

Path 2-2 Thru (1), (4) = 25694.62 + 29103.09 = 54797.71 lbf

Path 2-2 is stronger than W so it is acceptable per UG-41(b) (2).

Reinforcement Calculations For Nozzle MAP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.533$ in

Normal to the vessel wall outside $2.5 * (\text{tn} - \text{Cn}) + t_e = .625$ in

Normal to the vessel wall inside $2.5 * (\text{tn} - \text{Cn} - \text{C}) = .625$ in

Determination of Chord Length

$$\begin{aligned} \text{Theta1} &= \text{ArcCos}((\text{Lo} + \text{Rn}) / \text{Rm}) \\ &= \text{ArcCos}((7.875 + 3.75) / 84.3554) \\ &= 82.07932 \end{aligned}$$

$$\begin{aligned} \text{Theta2} &= \text{ArcCos}((\text{Lo} - \text{Rn}) / \text{Rm}) \\ &= \text{ArcCos}((7.875 - 3.75) / 84.3554) \\ &= 87.19758 \end{aligned}$$

$$\begin{aligned} d &= 2 * \text{Rm} * \text{Sin}((\text{Theta2} - \text{Theta1}) / 2) \\ &= 2 * 84.3554 * \text{Sin}((87.19758 - 82.07932) / 2) \\ &= 7.533 \text{ in} \end{aligned}$$

N1-1ST ROW-CENTER

Nozzle required thickness

$$\begin{aligned} \text{trn} &= P \cdot R_n / (S_n \cdot E - 0.6 \cdot P) \\ &= 83.54077 \cdot 3.75 / (16700 \cdot 1 - 0.6 \cdot 83.54077) \\ &= 0.0188 \text{ in} \end{aligned}$$

Required thickness tr from UG-37(a) (1)

$$\begin{aligned} \text{tr} &= P \cdot L \cdot M / (2 \cdot S \cdot E - 0.2 \cdot P) \\ &= 83.54077 \cdot 84.25 \cdot 1 / (2 \cdot 16700 \cdot 1 - 0.2 \cdot 83.54077) \\ &= 0.2108 \text{ in} \end{aligned}$$

Area required

Allowable stresses: $S_n = 16700$, $S_v = 16700$, psi

$\text{fr1} = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } \text{fr1} = 1$
 $\text{fr2} = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } \text{fr2} = 1$

$$\begin{aligned} A &= d \cdot \text{tr} \cdot F + 2 \cdot \text{tn} \cdot \text{tr} \cdot F \cdot (1 - \text{fr1}) \\ &= 7.533 \cdot 0.2108 \cdot 1 + 2 \cdot 0.25 \cdot 0.2108 \cdot 1 \cdot (1 - 1) \\ &= 1.588 \text{ in}^2 \end{aligned}$$

Area available

$A_1 = \text{larger of the following} = 1.237 \text{ in}^2$

$$\begin{aligned} &= d \cdot (E_1 \cdot t - F \cdot \text{tr}) - 2 \cdot \text{tn} \cdot (E_1 \cdot t - F \cdot \text{tr}) \cdot (1 - \text{fr1}) \\ &= 7.533 \cdot (1 \cdot 0.375 - 1 \cdot 0.2108) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2108) \cdot (1 - 1) \\ &= 1.237 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 \cdot (t + \text{tn}) \cdot (E_1 \cdot t - F \cdot \text{tr}) - 2 \cdot \text{tn} \cdot (E_1 \cdot t - F \cdot \text{tr}) \cdot (1 - \text{fr1}) \\ &= 2 \cdot (0.375 + 0.25) \cdot (1 \cdot 0.375 - 1 \cdot 0.2108) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2108) \cdot (1 - 1) \\ &= .205 \text{ in}^2 \end{aligned}$$

$A_2 = \text{smaller of the following} = 0.289 \text{ in}^2$

$$\begin{aligned} &= 5 \cdot (\text{tn} - \text{trn}) \cdot \text{fr2} \cdot t \\ &= 5 \cdot (0.25 - 0.0188) \cdot 1 \cdot 0.375 \\ &= .433 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5 \cdot (\text{tn} - \text{trn}) \cdot \text{fr2} \cdot \text{tn} \\ &= 5 \cdot (0.25 - 0.0188) \cdot 1 \cdot 0.25 \\ &= .289 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A_{41} &= \text{Leg}^2 \cdot \text{fr2} \\ &= 0.25^2 \cdot 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A_1 + A_2 + A_{41} \\ &= 1.237 + 0.289 + 0.063 \\ &= 1.589 \text{ in}^2 \end{aligned}$$

As $\text{Area} > A$ the reinforcement is adequate for $\text{MAP} = 83.54077$ at 70 Deg F

N1-1ST ROW-CENTER

Reinforcement check in the plane parallel to the long. axis

Area required

$$\begin{aligned} A &= d*tr*F + 2*tn*tr*F*(1 - fr1) \\ &= 7.5*0.2108*1 + 2*0.25*0.2108*1*(1 - 1) \\ &= 1.581 \text{ in}^2 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} \quad = 1.231 \text{ in}^2$$

$$\begin{aligned} &= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 7.5*(1*0.375-1*0.2108) - 2*0.25*(1*0.375-1*0.2108)*(1-1) \\ &= 1.231 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 2*(0.375+0.25)*(1*0.375-1*0.2108) - 2*0.25*(1*0.375-1*0.2108)*(1-1) \\ &= .205 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 1.231 + 0.289 + 0.063 \\ &= 1.583 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAP = 83.54077 at 70 Deg F

Check the welds - From UW-16(d):

$$\begin{aligned} t_{\min} &= \text{lesser of } 0.75 \text{ or } t_n \text{ or } t, t_{\min} = 0.25 \text{ in} \\ t1 \text{ or } t2(\min) &= \text{lesser of } 0.25 \text{ or } 0.7*t_{\min}, t1(\min) = 0.175 \text{ in} \\ t1(\text{actual}) &= 0.7*\text{Leg} = 0.7*0.25 = 0.175 \text{ in} \\ t2(\text{actual}) &= 0.1875 \text{ in} \\ t1 + t2 &= 0.3625 \geq 1.25*t_{\min} \end{aligned}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.0188 in (E = 1)
Wall thickness per UG-45(b)(1):	tr2 = 0.2108 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.2108 in
The lesser of tr4 or tr5:	tr6 = 0.2108 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.2108 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for MAP.

Allowable stresses in joints UG-45(c) and UW-15(c)

N1-1ST ROW-CENTER

Groove weld in tension = $0.74 \times 16700 = 12358$ psi
Nozzle wall in shear = $0.7 \times 16700 = 11690$ psi
Inner fillet weld in shear = $0.49 \times 16700 = 8183$ psi

Strength of welded joints:

(1) Inner fillet weld in shear

$$(\pi/2) \times \text{Nozzle O.D.} \times \text{Leg} \times S_i = 1.57 \times 8 \times 0.25 \times 8183 = 25694.62 \text{ lbf}$$

(3) Nozzle wall in shear

$$(\pi/2) \times \text{Mean nozzle dia.} \times t_n \times S_n = 1.57 \times 7.75 \times 0.25 \times 11690 = 35559.52 \text{ lbf}$$

(4) Groove weld in tension

$$(\pi/2) \times \text{Nozzle O.D.} \times t_w \times S_g = 1.57 \times 8 \times 0.1875 \times 12358 = 29103.09 \text{ lbf}$$

Loading on welds per UG-41(b) (1)

$$\begin{aligned} W &= (A - (d - 2 \times t_n) \times (E_1 \times t - F \times t_r)) \times S_v \\ &= (1.588 - (7.533 - 2 \times 0.25) \times (1 \times 0.375 - 1 \times 0.2108)) \times 16700 \\ &= 7234.131 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W_{1-1} &= (A_2 + A_5 + A_{41} + A_{42}) \times S_v \\ &= (0.289 + 0 + 0.063 + 0) \times 16700 \\ &= 5878.4 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W_{2-2} &= (A_2 + A_3 + A_{41} + A_{43} + 2 \times t_n \times t \times f_{r1}) \times S_v \\ &= (0.289 + 0 + 0.063 + 0 + 2 \times 0.25 \times 0.375 \times 1) \times 16700 \\ &= 9009.65 \text{ lbf} \end{aligned}$$

Load for path 1-1 lesser of W or $W_{1-1} = 5878.4$ lbf
Path 1-1 Thru (1) & (3) = $25694.62 + 35559.52 = 61254.14$ lbf
Path 1-1 is stronger than W_{1-1} so it is acceptable per UG-41(b) (1).

Load for path 2-2 lesser of W or $W_{2-2} = 7234.131$ lbf
Path 2-2 Thru (1), (4) = $25694.62 + 29103.09 = 54797.71$ lbf
Path 2-2 is stronger than W so it is acceptable per UG-41(b) (2).

Reinforcement Calculations for External Pressure

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.533$ in
Normal to the vessel wall outside $2.5 \times (t_n - C_n) + t_e = .625$ in
Normal to the vessel wall inside $2.5 \times (t_n - C_n - C) = .625$ in

Determination of Chord Length

$$\begin{aligned} \text{Theta}_1 &= \text{ArcCos}((L_o + R_n) / R_m) \\ &= \text{ArcCos}((7.875 + 3.75) / 84.38885) \\ &= 82.08248 \end{aligned}$$

$$\begin{aligned} \text{Theta}_2 &= \text{ArcCos}((L_o - R_n) / R_m) \\ &= \text{ArcCos}((7.875 - 3.75) / 84.38885) \end{aligned}$$

N1-1ST ROW-CENTER

$$= 87.19869$$

$$\begin{aligned}d &= 2*Rm*\sin((\text{Theta}2 - \text{Theta}1)/2) \\ &= 2*84.38885*\sin((87.19869 - 82.08248)/2) \\ &= 7.533 \text{ in}\end{aligned}$$

Nozzle required thickness

$$\begin{aligned}L/Do &= 3.39/8 = .4238 & Do/t &= 8/0.01987 = 402.617 \\ \text{From table G:} & & A &= 0.000401 \\ \text{From table HA-3:} & & B &= 4785.4\end{aligned}$$

$$\begin{aligned}Pa &= 4*B/(3*Do/t) \\ &= 4*4785.4/(3*8/0.01987) \\ &= 15.8476 \text{ psi}\end{aligned}$$

$$\text{Nozzle required thickness } trn = .01987 \text{ in}$$

Required thickness tr from UG-37(d)(1) = .2777 in

Area required

$$\text{Allowable stresses: } Sn = 14700, \quad Sv = 14700, \quad \text{psi}$$

$$\begin{aligned}fr1 &= \text{lesser of } 1 \text{ or } Sn/Sv \text{ so } fr1 = 1 \\ fr2 &= \text{lesser of } 1 \text{ or } Sn/Sv \text{ so } fr2 = 1\end{aligned}$$

$$\begin{aligned}A &= 0.5*(d*tr*F + 2*tn*tr*F*(1 - fr1)) \\ &= 0.5*(7.533*0.2777*1 + 2*0.25*0.2777*1*(1 - 1)) \\ &= 1.046 \text{ in}^2\end{aligned}$$

Area available

$$A1 = \text{larger of the following} \quad = .733 \text{ in}^2$$

$$\begin{aligned}&= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 7.533*(1*0.375-1*0.2777) - 2*0.25*(1*0.375-1*0.2777)*(1-1) \\ &= .733 \text{ in}^2\end{aligned}$$

$$\begin{aligned}&= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 2*(0.375+0.25)*(1*0.375-1*0.2777) - 2*0.25*(1*0.375-1*0.2777)*(1-1) \\ &= .122 \text{ in}^2\end{aligned}$$

$$A2 = \text{smaller of the following} \quad = 0.288 \text{ in}^2$$

$$\begin{aligned}&= 5*(tn - trn)*fr2*t \\ &= 5*(0.25 - 0.01987)*1*0.375 \\ &= .431 \text{ in}^2\end{aligned}$$

$$\begin{aligned}&= 5*(tn - trn)*fr2*tn \\ &= 5*(0.25 - 0.01987)*1*0.25 \\ &= .288 \text{ in}^2\end{aligned}$$

N1-1ST ROW-CENTER

$$\begin{aligned} A41 &= \text{Leg}^2 * \text{fr}2 \\ &= 0.25^2 * 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.733 + 0.288 + 0.063 \\ &= 1.084 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for Pe = 15.76347 at 400 Deg F

Reinforcement check in the plane parallel to the long. axis

Area required

$$\begin{aligned} A &= 0.5 * (d * \text{tr} * F + 2 * \text{tn} * \text{tr} * F * (1 - \text{fr}1)) \\ &= 0.5 * (7.5 * 0.2777 * 1 + 2 * 0.25 * 0.2777 * 1 * (1 - 1)) \\ &= 1.041375 \text{ in}^2 \end{aligned}$$

Area available

$$\begin{aligned} A1 &= \text{larger of the following} && = .73 \text{ in}^2 \\ &= d * (E1 * t - F * \text{tr}) - 2 * \text{tn} * (E1 * t - F * \text{tr}) * (1 - \text{fr}1) \\ &= 7.5 * (1 * 0.375 - 1 * 0.2777) - 2 * 0.25 * (1 * 0.375 - 1 * 0.2777) * (1 - 1) \\ &= .73 \text{ in}^2 \\ &= 2 * (t + \text{tn}) * (E1 * t - F * \text{tr}) - 2 * \text{tn} * (E1 * t - F * \text{tr}) * (1 - \text{fr}1) \\ &= 2 * (0.375 + 0.25) * (1 * 0.375 - 1 * 0.2777) - 2 * 0.25 * (1 * 0.375 - 1 * 0.2777) * (1 - 1) \\ &= .122 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.73 + 0.288 + 0.063 \\ &= 1.081 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for Pe = 15.76347 at 400 Deg F

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.01987 in (E = 1)
Wall thickness per UG-45(b) (2):	tr2 = 0.0452 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b) (4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.0625 in
The lesser of tr4 or tr5:	tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for Pe.


N2-1ST ROW-RIGHT

Opening N2 Reinforcement Calculations Per UG-37

Located on: 84" F&D HAM HEAD
User input vessel thickness: .375 in
Liquid static head included: 0 psi
Flange description: Not installed

Nozzle material specification: SA 240 304L HIGH

Nozzle orientation: 69.7 degrees
End of nozzle to datum line: 16.7521 in
Nozzle calculated as hillside: yes
Projection outside vessel Lpr: 3.083 in



corrosion allow = 0 in
noz thick new $tn = .25$ in
nozzle id. new $d = 7.5$ in
fillet weld $tw1 = .25$ in
groove weld $tw2 = .1875$ in

To head center $R = 22.66$ in

Reinforcement Calculations For Nozzle MAWP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.787$ in
Normal to the vessel wall outside $2.5*(tn-Cn) + te = .625$ in
Normal to the vessel wall inside $2.5*(tn-Cn-C) = .625$ in

Determination of Chord Length

$$\begin{aligned}\text{Theta1} &= \text{ArcCos}((Lo + Rn)/Rm) \\ &= \text{ArcCos}((22.66 + 3.75)/84.35505) \\ &= 71.75536\end{aligned}$$

$$\begin{aligned}\text{Theta2} &= \text{ArcCos}((Lo - Rn)/Rm) \\ &= \text{ArcCos}((22.66 - 3.75)/84.35505) \\ &= 77.04626\end{aligned}$$

$$\begin{aligned}d &= 2*Rm*\text{Sin}((\text{Theta2} - \text{Theta1})/2) \\ &= 2*84.35505*\text{Sin}((77.04626 - 71.75536)/2) \\ &= 7.787 \text{ in}\end{aligned}$$

Nozzle required thickness

$$\begin{aligned}trn &= P*Rn/(Sn*E - 0.6*P) \\ &= 83.26131*3.75/(16700*1 - 0.6*83.26131) \\ &= 0.0188 \text{ in}\end{aligned}$$

N2-1ST ROW-RIGHT

Required thickness tr from UG-37(a)(1)

$$\begin{aligned} tr &= P \cdot L \cdot M / (2 \cdot S \cdot E - 0.2 \cdot P) \\ &= 83.26131 \cdot 84.25 \cdot 1 / (2 \cdot 16700 \cdot 1 - 0.2 \cdot 83.26131) \\ &= 0.2101 \text{ in} \end{aligned}$$

Area required

Allowable stresses: $S_n = 16700$, $S_v = 16700$, psi

$fr_1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr_1 = 1$
 $fr_2 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr_2 = 1$

$$\begin{aligned} A &= d \cdot tr \cdot F + 2 \cdot t_n \cdot tr \cdot F \cdot (1 - fr_1) \\ &= 7.787 \cdot 0.2101 \cdot 1 + 2 \cdot 0.25 \cdot 0.2101 \cdot 1 \cdot (1 - 1) \\ &= 1.636 \text{ in}^2 \end{aligned}$$

Area available

$A_1 = \text{larger of the following} = 1.284 \text{ in}^2$

$$\begin{aligned} &= d \cdot (E_1 \cdot t - F \cdot tr) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot tr) \cdot (1 - fr_1) \\ &= 7.787 \cdot (1 \cdot 0.375 - 1 \cdot 0.2101) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2101) \cdot (1 - 1) \\ &= 1.284 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 \cdot (t + t_n) \cdot (E_1 \cdot t - F \cdot tr) - 2 \cdot t_n \cdot (E_1 \cdot t - F \cdot tr) \cdot (1 - fr_1) \\ &= 2 \cdot (0.375 + 0.25) \cdot (1 \cdot 0.375 - 1 \cdot 0.2101) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2101) \cdot (1 - 1) \\ &= .206 \text{ in}^2 \end{aligned}$$

$A_2 = \text{smaller of the following} = 0.289 \text{ in}^2$

$$\begin{aligned} &= 5 \cdot (t_n - t_{rn}) \cdot fr_2 \cdot t \\ &= 5 \cdot (0.25 - 0.0188) \cdot 1 \cdot 0.375 \\ &= .433 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5 \cdot (t_n - t_{rn}) \cdot fr_2 \cdot t_n \\ &= 5 \cdot (0.25 - 0.0188) \cdot 1 \cdot 0.25 \\ &= .289 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A_{41} &= \text{Leg}^2 \cdot fr_2 \\ &= 0.25^2 \cdot 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A_1 + A_2 + A_{41} \\ &= 1.284 + 0.289 + 0.063 \\ &= 1.636 \text{ in}^2 \end{aligned}$$

As $\text{Area} > A$ the reinforcement is adequate for MAWP = 83.26131 at 0 Deg F

Reinforcement check in the plane parallel to the long. axis

Area required

$$A = d \cdot tr \cdot F + 2 \cdot t_n \cdot tr \cdot F \cdot (1 - fr_1)$$

N2-1ST ROW-RIGHT

$$= 7.5 * 0.2101 * 1 + 2 * 0.25 * 0.2101 * 1 * (1 - 1) \\ = 1.57575 \text{ in}^2$$

Area available

$$A1 = \text{larger of the following} = 1.237 \text{ in}^2$$

$$= d * (E1 * t - F * tr) - 2 * tn * (E1 * t - F * tr) * (1 - fr1) \\ = 7.5 * (1 * 0.375 - 1 * 0.2101) - 2 * 0.25 * (1 * 0.375 - 1 * 0.2101) * (1 - 1) \\ = 1.237 \text{ in}^2$$

$$= 2 * (t + tn) * (E1 * t - F * tr) - 2 * tn * (E1 * t - F * tr) * (1 - fr1) \\ = 2 * (0.375 + 0.25) * (1 * 0.375 - 1 * 0.2101) - 2 * 0.25 * (1 * 0.375 - 1 * 0.2101) * (1 - 1) \\ = .206 \text{ in}^2$$

$$\text{Area} = A1 + A2 + A41 \\ = 1.237 + 0.289 + 0.063 \\ = 1.589 \text{ in}^2$$

As Area > A the reinforcement is adequate for MAWP = 83.26131 at 0 Deg F

Check the welds - From UW-16(d):

$$t_{\min} = \text{lesser of } 0.75 \text{ or } t_n \text{ or } t, t_{\min} = 0.25 \text{ in} \\ t1 \text{ or } t2(\min) = \text{lesser of } 0.25 \text{ or } 0.7 * t_{\min}, t1(\min) = 0.175 \text{ in} \\ t1(\text{actual}) = 0.7 * \text{Leg} = 0.7 * 0.25 = 0.175 \text{ in} \\ t2(\text{actual}) = 0.1875 \text{ in} \\ t1 + t2 = 0.3625 \geq 1.25 * t_{\min}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.0188 in (E = 1)
Wall thickness per UG-45(b)(1):	tr2 = 0.2101 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.2101 in
The lesser of tr4 or tr5:	tr6 = 0.2101 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.2101 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for MAWP.

Allowable stresses in joints UG-45(c) and UW-15(c)

$$\text{Groove weld in tension} = 0.74 * 16700 = 12358 \text{ psi} \\ \text{Nozzle wall in shear} = 0.7 * 16700 = 11690 \text{ psi} \\ \text{Inner fillet weld in shear} = 0.49 * 16700 = 8183 \text{ psi}$$

Strength of welded joints:

3.12.1996

N2-1ST ROW-RIGHT

(1) Inner fillet weld in shear

$$(\text{Pi}/2) * \text{Nozzle O.D.} * \text{Leg} * \text{Si} = 1.57 * 8 * 0.25 * 8183 = 25694.62 \text{ lbf}$$

(3) Nozzle wall in shear

$$(\text{Pi}/2) * \text{Mean nozzle dia.} * \text{tn} * \text{Sn} = 1.57 * 7.75 * 0.25 * 11690 = 35559.52 \text{ lbf}$$

(4) Groove weld in tension

$$(\text{Pi}/2) * \text{Nozzle O.D.} * \text{tw} * \text{Sg} = 1.57 * 8 * 0.1875 * 12358 = 29103.09 \text{ lbf}$$

Loading on welds per UG-41(b) (1)

$$\begin{aligned} W &= (A - (d - 2 * \text{tn}) * (\text{E1} * t - F * \text{tr})) * \text{Sv} \\ &= (1.636 - (7.787 - 2 * 0.25) * (1 * 0.375 - 1 * 0.2101)) * 16700 \\ &= 7254.041 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W1-1 &= (A2 + A5 + A41 + A42) * \text{Sv} \\ &= (0.289 + 0 + 0.063 + 0) * 16700 \\ &= 5878.4 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W2-2 &= (A2 + A3 + A41 + A43 + 2 * \text{tn} * t * \text{fr1}) * \text{Sv} \\ &= (0.289 + 0 + 0.063 + 0 + 2 * 0.25 * 0.375 * 1) * 16700 \\ &= 9009.65 \text{ lbf} \end{aligned}$$

Load for path 1-1 lesser of W or W1-1 = 5878.4 lbf

Path 1-1 Thru (1) & (3) = 25694.62 + 35559.52 = 61254.14 lbf

Path 1-1 is stronger than W1-1 so it is acceptable per UG-41(b) (1).

Load for path 2-2 lesser of W or W2-2 = 7254.041 lbf

Path 2-2 Thru (1), (4) = 25694.62 + 29103.09 = 54797.71 lbf

Path 2-2 is stronger than W so it is acceptable per UG-41(b) (2).

Reinforcement Calculations For Nozzle MAP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.787$ in

Normal to the vessel wall outside $2.5 * (\text{tn} - \text{Cn}) + \text{te} = .625$ in

Normal to the vessel wall inside $2.5 * (\text{tn} - \text{Cn} - \text{C}) = .625$ in

Determination of Chord Length

$$\begin{aligned} \text{Theta1} &= \text{ArcCos}((\text{Lo} + \text{Rn}) / \text{Rm}) \\ &= \text{ArcCos}((22.66 + 3.75) / 84.3548) \\ &= 71.7553 \end{aligned}$$

$$\begin{aligned} \text{Theta2} &= \text{ArcCos}((\text{Lo} - \text{Rn}) / \text{Rm}) \\ &= \text{ArcCos}((22.66 - 3.75) / 84.3548) \\ &= 77.04622 \end{aligned}$$

$$\begin{aligned} d &= 2 * \text{Rm} * \text{Sin}((\text{Theta2} - \text{Theta1}) / 2) \\ &= 2 * 84.3548 * \text{Sin}((77.04622 - 71.7553) / 2) \\ &= 7.787 \text{ in} \end{aligned}$$

N2-1ST ROW-RIGHT

Nozzle required thickness

$$\begin{aligned} trn &= P \cdot Rn / (Sn \cdot E - 0.6 \cdot P) \\ &= 83.06746 \cdot 3.75 / (16700 \cdot 1 - 0.6 \cdot 83.06746) \\ &= 0.0187 \text{ in} \end{aligned}$$

Required thickness tr from UG-37(a)(1)

$$\begin{aligned} tr &= P \cdot L \cdot M / (2 \cdot S \cdot E - 0.2 \cdot P) \\ &= 83.06746 \cdot 84.25 \cdot 1 / (2 \cdot 16700 \cdot 1 - 0.2 \cdot 83.06746) \\ &= 0.2096 \text{ in} \end{aligned}$$

Area required

Allowable stresses: $S_n = 16700$, $S_v = 16700$, psi

$$\begin{aligned} fr1 &= \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr1 = 1 \\ fr2 &= \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr2 = 1 \end{aligned}$$

$$\begin{aligned} A &= d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F \cdot (1 - fr1) \\ &= 7.787 \cdot 0.2096 \cdot 1 + 2 \cdot 0.25 \cdot 0.2096 \cdot 1 \cdot (1 - 1) \\ &= 1.6322 \text{ in}^2 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} = 1.288 \text{ in}^2$$

$$\begin{aligned} &= d \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1) \\ &= 7.787 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) \cdot (1 - 1) \\ &= 1.288 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 \cdot (t + tn) \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1) \\ &= 2 \cdot (0.375 + 0.25) \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) \cdot (1 - 1) \\ &= .207 \text{ in}^2 \end{aligned}$$

$$A2 = \text{smaller of the following} = 0.289 \text{ in}^2$$

$$\begin{aligned} &= 5 \cdot (tn - trn) \cdot fr2 \cdot t \\ &= 5 \cdot (0.25 - 0.0187) \cdot 1 \cdot 0.375 \\ &= .434 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5 \cdot (tn - trn) \cdot fr2 \cdot tn \\ &= 5 \cdot (0.25 - 0.0187) \cdot 1 \cdot 0.25 \\ &= .289 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A41 &= Leg^2 \cdot fr2 \\ &= 0.25^2 \cdot 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 1.288 + 0.289 + 0.063 \\ &= 1.64 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAP = 83.06746 at 70 Deg F

N2-1ST ROW-RIGHT

Reinforcement check in the plane parallel to the long. axis

Area required

$$\begin{aligned} A &= d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F \cdot (1 - fr1) \\ &= 7.5 \cdot 0.2096 \cdot 1 + 2 \cdot 0.25 \cdot 0.2096 \cdot 1 \cdot (1 - 1) \\ &= 1.572 \text{ in}^2 \end{aligned}$$

Area available

$$\begin{aligned} A1 &= \text{larger of the following} && = 1.24 \text{ in}^2 \\ &= d \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1) \\ &= 7.5 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) \cdot (1 - 1) \\ &= 1.24 \text{ in}^2 \\ &= 2 \cdot (t + tn) \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1) \\ &= 2 \cdot (0.375 + 0.25) \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) \cdot (1 - 1) \\ &= .207 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 1.24 + 0.289 + 0.063 \\ &= 1.592 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAP = 83.06746 at 70 Deg F

Check the welds - From UW-16(d):

$$\begin{aligned} t_{min} &= \text{lesser of } 0.75 \text{ or } tn \text{ or } t, t_{min} = 0.25 \text{ in} \\ t1 \text{ or } t2(\text{min}) &= \text{lesser of } 0.25 \text{ or } 0.7 \cdot t_{min}, t1(\text{min}) = 0.175 \text{ in} \\ t1(\text{actual}) &= 0.7 \cdot \text{Leg} = 0.7 \cdot 0.25 = 0.175 \text{ in} \\ t2(\text{actual}) &= 0.1875 \text{ in} \\ t1 + t2 &= 0.3625 \geq 1.25 \cdot t_{min} \end{aligned}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.0187 in (E = 1)
Wall thickness per UG-45(b)(1):	tr2 = 0.2096 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.2096 in
The lesser of tr4 or tr5:	tr6 = 0.2096 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.2096 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for MAP.

Allowable stresses in joints UG-45(c) and UW-15(c)

N2-1ST ROW-RIGHT

Groove weld in tension = $0.74 \times 16700 = 12358$ psi
Nozzle wall in shear = $0.7 \times 16700 = 11690$ psi
Inner fillet weld in shear = $0.49 \times 16700 = 8183$ psi

Strength of welded joints:

(1) Inner fillet weld in shear

$$(\pi/2) \times \text{Nozzle O.D.} \times \text{Leg} \times S_i = 1.57 \times 8 \times 0.25 \times 8183 = 25694.62 \text{ lbf}$$

(3) Nozzle wall in shear

$$(\pi/2) \times \text{Mean nozzle dia.} \times t_n \times S_n = 1.57 \times 7.75 \times 0.25 \times 11690 = 35559.52 \text{ lbf}$$

(4) Groove weld in tension

$$(\pi/2) \times \text{Nozzle O.D.} \times t_w \times S_g = 1.57 \times 8 \times 0.1875 \times 12358 = 29103.09 \text{ lbf}$$

Loading on welds per UG-41(b) (1)

$$\begin{aligned} W &= (A - (d - 2 \times t_n) \times (E_1 \times t - F \times t_r)) \times S_v \\ &= (1.6322 - (7.787 - 2 \times 0.25) \times (1 \times 0.375 - 1 \times 0.2096)) \times 16700 \\ &= 7129.734 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W1-1 &= (A_2 + A_5 + A_{41} + A_{42}) \times S_v \\ &= (0.289 + 0 + 0.063 + 0) \times 16700 \\ &= 5878.4 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W2-2 &= (A_2 + A_3 + A_{41} + A_{43} + 2 \times t_n \times t \times f_{r1}) \times S_v \\ &= (0.289 + 0 + 0.063 + 0 + 2 \times 0.25 \times 0.375 \times 1) \times 16700 \\ &= 9009.65 \text{ lbf} \end{aligned}$$

Load for path 1-1 lesser of W or W1-1 = 5878.4 lbf

Path 1-1 Thru (1) & (3) = $25694.62 + 35559.52 = 61254.14$ lbf

Path 1-1 is stronger than W1-1 so it is acceptable per UG-41(b) (1).

Load for path 2-2 lesser of W or W2-2 = 7129.734 lbf

Path 2-2 Thru (1), (4) = $25694.62 + 29103.09 = 54797.71$ lbf

Path 2-2 is stronger than W so it is acceptable per UG-41(b) (2).

Reinforcement Calculations for External Pressure

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.787$ in

Normal to the vessel wall outside $2.5 \times (t_n - C_n) + t_e = .625$ in

Normal to the vessel wall inside $2.5 \times (t_n - C_n - C) = .625$ in

Determination of Chord Length

$$\begin{aligned} \text{Theta1} &= \text{ArcCos}((L_o + R_n)/R_m) \\ &= \text{ArcCos}((22.66 + 3.75)/84.38945) \\ &= 71.76306 \end{aligned}$$

$$\begin{aligned} \text{Theta2} &= \text{ArcCos}((L_o - R_n)/R_m) \\ &= \text{ArcCos}((22.66 - 3.75)/84.38945) \end{aligned}$$

N2-1ST ROW-RIGHT

$$= 77.05163$$

$$\begin{aligned}d &= 2 * R_m * \sin((\text{Theta}2 - \text{Theta}1)/2) \\ &= 2 * 84.38945 * \sin((77.05163 - 71.76306)/2) \\ &= 7.787 \text{ in}\end{aligned}$$

Nozzle required thickness

$$\begin{aligned}L/Do &= 3.083/8 = .3854 \\ \text{From table G:} \\ \text{From table HA-3:}\end{aligned}$$

$$\begin{aligned}Do/t &= 8/0.01962 = 407.7472 \\ A &= 0.000437 \\ B &= 4858.3\end{aligned}$$

$$\begin{aligned}Pa &= 4 * B / (3 * Do/t) \\ &= 4 * 4858.3 / (3 * 8 / 0.01962) \\ &= 15.8866 \text{ psi}\end{aligned}$$

$$\text{Nozzle required thickness } t_{rn} = .01962 \text{ in}$$

Required thickness tr from UG-37(d) (1) = .2789 in

Area required

$$\text{Allowable stresses: } S_n = 14700, \quad S_v = 14700, \quad \text{psi}$$

$$\begin{aligned}fr1 &= \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr1 = 1 \\ fr2 &= \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr2 = 1\end{aligned}$$

$$\begin{aligned}A &= 0.5 * (d * tr * F + 2 * t_n * tr * F * (1 - fr1)) \\ &= 0.5 * (7.787 * 0.2789 * 1 + 2 * 0.25 * 0.2789 * 1 * (1 - 1)) \\ &= 1.0859 \text{ in}^2\end{aligned}$$

Area available

$$A1 = \text{larger of the following} \quad = .748 \text{ in}^2$$

$$\begin{aligned}&= d * (E1 * t - F * tr) - 2 * t_n * (E1 * t - F * tr) * (1 - fr1) \\ &= 7.787 * (1 * 0.375 - 1 * 0.2789) - 2 * 0.25 * (1 * 0.375 - 1 * 0.2789) * (1 - 1) \\ &= .748 \text{ in}^2\end{aligned}$$

$$\begin{aligned}&= 2 * (t + t_n) * (E1 * t - F * tr) - 2 * t_n * (E1 * t - F * tr) * (1 - fr1) \\ &= 2 * (0.375 + 0.25) * (1 * 0.375 - 1 * 0.2789) - 2 * 0.25 * (1 * 0.375 - 1 * 0.2789) * (1 - 1) \\ &= .12 \text{ in}^2\end{aligned}$$

$$A2 = \text{smaller of the following} \quad = 0.288 \text{ in}^2$$

$$\begin{aligned}&= 5 * (t_n - t_{rn}) * fr2 * t \\ &= 5 * (0.25 - 0.01962) * 1 * 0.375 \\ &= .432 \text{ in}^2\end{aligned}$$

$$\begin{aligned}&= 5 * (t_n - t_{rn}) * fr2 * t_n \\ &= 5 * (0.25 - 0.01962) * 1 * 0.25 \\ &= .288 \text{ in}^2\end{aligned}$$

N2-1ST ROW-RIGHT

$$\begin{aligned} A41 &= \text{Leg}^2 * fr2 \\ &= 0.25^2 * 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.748 + 0.288 + 0.063 \\ &= 1.099 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for Pe = 15.82647 at 400 Deg F

Reinforcement check in the plane parallel to the long. axis

Area required

$$\begin{aligned} A &= 0.5 * (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \\ &= 0.5 * (7.5 * 0.2789 * 1 + 2 * 0.25 * 0.2789 * 1 * (1 - 1)) \\ &= 1.045875 \text{ in}^2 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} = .721 \text{ in}^2$$

$$\begin{aligned} &= d * (E1 * t - F * tr) - 2 * tn * (E1 * t - F * tr) * (1 - fr1) \\ &= 7.5 * (1 * 0.375 - 1 * 0.2789) - 2 * 0.25 * (1 * 0.375 - 1 * 0.2789) * (1 - 1) \\ &= .721 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 * (t + tn) * (E1 * t - F * tr) - 2 * tn * (E1 * t - F * tr) * (1 - fr1) \\ &= 2 * (0.375 + 0.25) * (1 * 0.375 - 1 * 0.2789) - 2 * 0.25 * (1 * 0.375 - 1 * 0.2789) * (1 - 1) \\ &= .12 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.721 + 0.288 + 0.063 \\ &= 1.072 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for Pe = 15.82647 at 400 Deg F

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.01962 in (E = 1)
Wall thickness per UG-45(b)(2):	tr2 = 0.0454 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.0625 in
The lesser of tr4 or tr5:	tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for Pe.


N4-2ND ROW-RIGHT

Opening N4 Reinforcement Calculations Per UG-37

Located on: 84" F&D HAM HEAD
User input vessel thickness: .375 in
Liquid static head included: 0 psi
Flange description: Not installed

Nozzle material specification: SA 240 304L HIGH

Nozzle orientation: 28.03 degrees
End of nozzle to datum line: 16.6279 in
Nozzle calculated as hillside: yes
Projection outside vessel Lpr: 3.057 in



corrosion allow = 0 in
noz thick new $t_n = .25$ in
nozzle id. new $d = 7.5$ in
fillet weld $tw_1 = .25$ in
groove weld $tw_2 = .1875$ in

To head center $R = 23.01$ in

Reinforcement Calculations For Nozzle MAWP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.796$ in
Normal to the vessel wall outside $2.5 \cdot (t_n - C_n) + t_e = .625$ in
Normal to the vessel wall inside $2.5 \cdot (t_n - C_n - C) = .625$ in

Determination of Chord Length

$$\begin{aligned}\text{Theta1} &= \text{ArcCos}((L_o + R_n)/R_m) \\ &= \text{ArcCos}((23.01 + 3.75)/84.35505) \\ &= 71.50487\end{aligned}$$

$$\begin{aligned}\text{Theta2} &= \text{ArcCos}((L_o - R_n)/R_m) \\ &= \text{ArcCos}((23.01 - 3.75)/84.35505) \\ &= 76.8022\end{aligned}$$

$$\begin{aligned}d &= 2 \cdot R_m \cdot \text{Sin}((\text{Theta2} - \text{Theta1})/2) \\ &= 2 \cdot 84.35505 \cdot \text{Sin}((76.8022 - 71.50487)/2) \\ &= 7.796 \text{ in}\end{aligned}$$

Nozzle required thickness

$$\begin{aligned}t_{rn} &= P \cdot R_n / (S_n \cdot E - 0.6 \cdot P) \\ &= 83.26131 \cdot 3.75 / (16700 \cdot 1 - 0.6 \cdot 83.26131) \\ &= 0.0188 \text{ in}\end{aligned}$$

3.12.1996

N4-2ND ROW-RIGHT

Required thickness tr from UG-37(a)(1)

$$\begin{aligned} tr &= P \cdot L \cdot M / (2 \cdot S \cdot E - 0.2 \cdot P) \\ &= 83.26131 \cdot 84.25 \cdot 1 / (2 \cdot 16700 \cdot 1 - 0.2 \cdot 83.26131) \\ &= 0.2101 \text{ in} \end{aligned}$$

Area required

Allowable stresses: $S_n = 16700$, $S_v = 16700$, psi

$$\begin{aligned} fr1 &= \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr1 = 1 \\ fr2 &= \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr2 = 1 \end{aligned}$$

$$\begin{aligned} A &= d \cdot tr \cdot F + 2 \cdot t_n \cdot tr \cdot F \cdot (1 - fr1) \\ &= 7.796 \cdot 0.2101 \cdot 1 + 2 \cdot 0.25 \cdot 0.2101 \cdot 1 \cdot (1 - 1) \\ &= 1.6379 \text{ in}^2 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} = 1.286 \text{ in}^2$$

$$\begin{aligned} &= d \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot t_n \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1) \\ &= 7.796 \cdot (1 \cdot 0.375 - 1 \cdot 0.2101) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2101) \cdot (1 - 1) \\ &= 1.286 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 \cdot (t + t_n) \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot t_n \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1) \\ &= 2 \cdot (0.375 + 0.25) \cdot (1 \cdot 0.375 - 1 \cdot 0.2101) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2101) \cdot (1 - 1) \\ &= .206 \text{ in}^2 \end{aligned}$$

$$A2 = \text{smaller of the following} = 0.289 \text{ in}^2$$

$$\begin{aligned} &= 5 \cdot (t_n - t_{rn}) \cdot fr2 \cdot t \\ &= 5 \cdot (0.25 - 0.0188) \cdot 1 \cdot 0.375 \\ &= .433 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5 \cdot (t_n - t_{rn}) \cdot fr2 \cdot t_n \\ &= 5 \cdot (0.25 - 0.0188) \cdot 1 \cdot 0.25 \\ &= .289 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A41 &= \text{Leg}^2 \cdot fr2 \\ &= 0.25^2 \cdot 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 1.286 + 0.289 + 0.063 \\ &= 1.638 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAWP = 83.26131 at 0 Deg F

Reinforcement check in the plane parallel to the long. axis

Area required

$$A = d \cdot tr \cdot F + 2 \cdot t_n \cdot tr \cdot F \cdot (1 - fr1)$$

3.12.1996

N4-2ND ROW-RIGHT

$$= 7.5*0.2101*1 + 2*0.25*0.2101*1*(1 - 1)$$
$$= 1.57575 \text{ in}^2$$

Area available

$$A1 = \text{larger of the following} = 1.237 \text{ in}^2$$

$$= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1)$$
$$= 7.5*(1*0.375-1*0.2101) - 2*0.25*(1*0.375-1*0.2101)*(1-1)$$
$$= 1.237 \text{ in}^2$$

$$= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1)$$
$$= 2*(0.375+0.25)*(1*0.375-1*0.2101) - 2*0.25*(1*0.375-1*0.2101)*(1-1)$$
$$= .206 \text{ in}^2$$

$$\text{Area} = A1 + A2 + A41$$
$$= 1.237 + 0.289 + 0.063$$
$$= 1.589 \text{ in}^2$$

As Area > A the reinforcement is adequate for MAWP = 83.26131 at 0 Deg F

Check the welds - From UW-16(d):

$$t_{\min} = \text{lesser of } 0.75 \text{ or } t_n \text{ or } t, t_{\min} = 0.25 \text{ in}$$
$$t_1 \text{ or } t_2(\min) = \text{lesser of } 0.25 \text{ or } 0.7*t_{\min}, t_1(\min) = 0.175 \text{ in}$$
$$t_1(\text{actual}) = 0.7*\text{Leg} = 0.7*0.25 = 0.175 \text{ in}$$
$$t_2(\text{actual}) = 0.1875 \text{ in}$$
$$t_1 + t_2 = 0.3625 \geq 1.25*t_{\min}$$

The weld sizes for t_1 and t_2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	$tr_1 = 0.0188 \text{ in } (E = 1)$
Wall thickness per UG-45(b)(1):	$tr_2 = 0.2101 \text{ in}$
Wall thickness per UG-16(b):	$tr_3 = 0.0625 \text{ in}$
Std pipe wall per UG-45(b)(4):	$tr_4 = 0.28175 \text{ in}$
The greater of tr_2 or tr_3 :	$tr_5 = 0.2101 \text{ in}$
The lesser of tr_4 or tr_5 :	$tr_6 = 0.2101 \text{ in}$

Req'd per UG-45 is the larger of tr_1 or $tr_6 = 0.2101 \text{ in}$

Available nozzle wall thickness new, $t_n = 0.25 \text{ in}$

The nozzle neck thickness is adequate for MAWP.

Allowable stresses in joints UG-45(c) and UW-15(c)

$$\text{Groove weld in tension} = 0.74*16700 = 12358 \text{ psi}$$
$$\text{Nozzle wall in shear} = 0.7*16700 = 11690 \text{ psi}$$
$$\text{Inner fillet weld in shear} = 0.49*16700 = 8183 \text{ psi}$$

Strength of welded joints:

3.12.1996

N4-2ND ROW-RIGHT

(1) Inner fillet weld in shear

$$(\pi/2) * \text{Nozzle O.D.} * \text{Leg} * S_i = 1.57 * 8 * 0.25 * 8183 = 25694.62 \text{ lbf}$$

(3) Nozzle wall in shear

$$(\pi/2) * \text{Mean nozzle dia.} * t_n * S_n = 1.57 * 7.75 * 0.25 * 11690 = 35559.52 \text{ lbf}$$

(4) Groove weld in tension

$$(\pi/2) * \text{Nozzle O.D.} * t_w * S_g = 1.57 * 8 * 0.1875 * 12358 = 29103.09 \text{ lbf}$$

Loading on welds per UG-41(b)(1)

$$\begin{aligned} W &= (A - (d - 2 * t_n) * (E_1 * t - F * t_r)) * S_v \\ &= (1.6379 - (7.796 - 2 * 0.25) * (1 * 0.375 - 1 * 0.2101)) * 16700 \\ &= 7260.986 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W_{1-1} &= (A_2 + A_5 + A_{41} + A_{42}) * S_v \\ &= (0.289 + 0 + 0.063 + 0) * 16700 \\ &= 5878.4 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W_{2-2} &= (A_2 + A_3 + A_{41} + A_{43} + 2 * t_n * t * f_{r1}) * S_v \\ &= (0.289 + 0 + 0.063 + 0 + 2 * 0.25 * 0.375 * 1) * 16700 \\ &= 9009.65 \text{ lbf} \end{aligned}$$

Load for path 1-1 lesser of W or W₁₋₁ = 5878.4 lbf

Path 1-1 Thru (1) & (3) = 25694.62 + 35559.52 = 61254.14 lbf

Path 1-1 is stronger than W₁₋₁ so it is acceptable per UG-41(b)(1).

Load for path 2-2 lesser of W or W₂₋₂ = 7260.986 lbf

Path 2-2 Thru (1), (4) = 25694.62 + 29103.09 = 54797.71 lbf

Path 2-2 is stronger than W so it is acceptable per UG-41(b)(2).

Reinforcement Calculations For Nozzle MAP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.796$ in

Normal to the vessel wall outside $2.5 * (t_n - C_n) + t_e = .625$ in

Normal to the vessel wall inside $2.5 * (t_n - C_n - C) = .625$ in

Determination of Chord Length

$$\begin{aligned} \text{Theta}_1 &= \text{ArcCos}((L_o + R_n) / R_m) \\ &= \text{ArcCos}((23.01 + 3.75) / 84.3548) \\ &= 71.50481 \end{aligned}$$

$$\begin{aligned} \text{Theta}_2 &= \text{ArcCos}((L_o - R_n) / R_m) \\ &= \text{ArcCos}((23.01 - 3.75) / 84.3548) \\ &= 76.80215 \end{aligned}$$

$$\begin{aligned} d &= 2 * R_m * \text{Sin}((\text{Theta}_2 - \text{Theta}_1) / 2) \\ &= 2 * 84.3548 * \text{Sin}((76.80215 - 71.50481) / 2) \\ &= 7.796 \text{ in} \end{aligned}$$

N4-2ND ROW-RIGHT

Nozzle required thickness

$$\begin{aligned} trn &= P \cdot Rn / (Sn \cdot E - 0.6 \cdot P) \\ &= 83.06746 \cdot 3.75 / (16700 \cdot 1 - 0.6 \cdot 83.06746) \\ &= 0.0187 \text{ in} \end{aligned}$$

Required thickness tr from UG-37(a) (1)

$$\begin{aligned} tr &= P \cdot L \cdot M / (2 \cdot S \cdot E - 0.2 \cdot P) \\ &= 83.06746 \cdot 84.25 \cdot 1 / (2 \cdot 16700 \cdot 1 - 0.2 \cdot 83.06746) \\ &= 0.2096 \text{ in} \end{aligned}$$

Area required

Allowable stresses: Sn = 16700, Sv = 16700, psi

fr1 = lesser of 1 or Sn/Sv so fr1 = 1

fr2 = lesser of 1 or Sn/Sv so fr2 = 1

$$\begin{aligned} A &= d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F \cdot (1 - fr1) \\ &= 7.796 \cdot 0.2096 \cdot 1 + 2 \cdot 0.25 \cdot 0.2096 \cdot 1 \cdot (1 - 1) \\ &= 1.634 \text{ in}^2 \end{aligned}$$

Area available

A1 = larger of the following = 1.289 in²

$$\begin{aligned} &= d \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1) \\ &= 7.796 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) \cdot (1 - 1) \\ &= 1.289 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 \cdot (t + tn) \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1) \\ &= 2 \cdot (0.375 + 0.25) \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) \cdot (1 - 1) \\ &= .207 \text{ in}^2 \end{aligned}$$

A2 = smaller of the following = 0.289 in²

$$\begin{aligned} &= 5 \cdot (tn - trn) \cdot fr2 \cdot t \\ &= 5 \cdot (0.25 - 0.0187) \cdot 1 \cdot 0.375 \\ &= .434 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5 \cdot (tn - trn) \cdot fr2 \cdot tn \\ &= 5 \cdot (0.25 - 0.0187) \cdot 1 \cdot 0.25 \\ &= .289 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A41 &= Leg^2 \cdot fr2 \\ &= 0.25^2 \cdot 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 1.289 + 0.289 + 0.063 \\ &= 1.641 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAP = 83.06746 at 70 Deg F

3.12.1996

N4-2ND ROW-RIGHT

Reinforcement check in the plane parallel to the long. axis

Area required

$$\begin{aligned} A &= d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F \cdot (1 - fr1) \\ &= 7.5 \cdot 0.2096 \cdot 1 + 2 \cdot 0.25 \cdot 0.2096 \cdot 1 \cdot (1 - 1) \\ &= 1.572 \text{ in}^2 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} \quad = 1.24 \text{ in}^2$$

$$\begin{aligned} &= d \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1) \\ &= 7.5 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) \cdot (1 - 1) \\ &= 1.24 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2 \cdot (t + tn) \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1) \\ &= 2 \cdot (0.375 + 0.25) \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) - 2 \cdot 0.25 \cdot (1 \cdot 0.375 - 1 \cdot 0.2096) \cdot (1 - 1) \\ &= .207 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 1.24 + 0.289 + 0.063 \\ &= 1.592 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAP = 83.06746 at 70 Deg F

Check the welds - From UW-16(d):

$$\begin{aligned} t_{\min} &= \text{lesser of } 0.75 \text{ or } tn \text{ or } t, \quad t_{\min} = 0.25 \text{ in} \\ t1 \text{ or } t2(\min) &= \text{lesser of } 0.25 \text{ or } 0.7 \cdot t_{\min}, \quad t1(\min) = 0.175 \text{ in} \\ t1(\text{actual}) &= 0.7 \cdot \text{Leg} = 0.7 \cdot 0.25 = 0.175 \text{ in} \\ t2(\text{actual}) &= 0.1875 \text{ in} \\ t1 + t2 &= 0.3625 \geq 1.25 \cdot t_{\min} \end{aligned}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.0187 in (E = 1)
Wall thickness per UG-45(b)(1):	tr2 = 0.2096 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.2096 in
The lesser of tr4 or tr5:	tr6 = 0.2096 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.2096 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for MAP.

Allowable stresses in joints UG-45(c) and UW-15(c)

N4-2ND ROW-RIGHT

Groove weld in tension = $0.74 \times 16700 = 12358$ psi
Nozzle wall in shear = $0.7 \times 16700 = 11690$ psi
Inner fillet weld in shear = $0.49 \times 16700 = 8183$ psi

Strength of welded joints:

(1) Inner fillet weld in shear

$$(\pi/2) \times \text{Nozzle O.D.} \times \text{Leg} \times S_i = 1.57 \times 8 \times 0.25 \times 8183 = 25694.62 \text{ lbf}$$

(3) Nozzle wall in shear

$$(\pi/2) \times \text{Mean nozzle dia.} \times t_n \times S_n = 1.57 \times 7.75 \times 0.25 \times 11690 = 35559.52 \text{ lbf}$$

(4) Groove weld in tension

$$(\pi/2) \times \text{Nozzle O.D.} \times t_w \times S_g = 1.57 \times 8 \times 0.1875 \times 12358 = 29103.09 \text{ lbf}$$

Loading on welds per UG-41(b) (1)

$$\begin{aligned} W &= (A - (d - 2 \times t_n) \times (E_1 \times t - F \times t_r)) \times S_v \\ &= (1.634 - (7.796 - 2 \times 0.25) \times (1 \times 0.375 - 1 \times 0.2096)) \times 16700 \\ &= 7134.934 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W_{1-1} &= (A_2 + A_5 + A_{41} + A_{42}) \times S_v \\ &= (0.289 + 0 + 0.063 + 0) \times 16700 \\ &= 5878.4 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W_{2-2} &= (A_2 + A_3 + A_{41} + A_{43} + 2 \times t_n \times t \times f_{r1}) \times S_v \\ &= (0.289 + 0 + 0.063 + 0 + 2 \times 0.25 \times 0.375 \times 1) \times 16700 \\ &= 9009.65 \text{ lbf} \end{aligned}$$

Load for path 1-1 lesser of W or $W_{1-1} = 5878.4$ lbf

Path 1-1 Thru (1) & (3) = $25694.62 + 35559.52 = 61254.14$ lbf

Path 1-1 is stronger than W_{1-1} so it is acceptable per UG-41(b) (1).

Load for path 2-2 lesser of W or $W_{2-2} = 7134.934$ lbf

Path 2-2 Thru (1), (4) = $25694.62 + 29103.09 = 54797.71$ lbf

Path 2-2 is stronger than W so it is acceptable per UG-41(b) (2).

Reinforcement Calculations for External Pressure

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.796$ in

Normal to the vessel wall outside $2.5 \times (t_n - C_n) + t_e = .625$ in

Normal to the vessel wall inside $2.5 \times (t_n - C_n - C) = .625$ in

Determination of Chord Length

$$\begin{aligned} \text{Theta}_1 &= \text{ArcCos}((L_o + R_n)/R_m) \\ &= \text{ArcCos}((23.01 + 3.75)/84.38935) \\ &= 71.51266 \end{aligned}$$

$$\begin{aligned} \text{Theta}_2 &= \text{ArcCos}((L_o - R_n)/R_m) \\ &= \text{ArcCos}((23.01 - 3.75)/84.38935) \end{aligned}$$

N4-2ND ROW-RIGHT

$$= 76.80766$$

$$\begin{aligned}d &= 2 * R_m * \sin((\text{Theta}2 - \text{Theta}1) / 2) \\ &= 2 * 84.38935 * \sin((76.80766 - 71.51266) / 2) \\ &= 7.796 \text{ in}\end{aligned}$$

Nozzle required thickness

$$\begin{array}{ll}L/Do = 3.057/8 = .3821 & Do/t = 8/0.01961 = 407.9551 \\ \text{From table G:} & A = 0.000441 \\ \text{From table HA-3:} & B = 4866.1\end{array}$$

$$\begin{aligned}Pa &= 4 * B / (3 * Do / t) \\ &= 4 * 4866.1 / (3 * 8 / 0.01961) \\ &= 15.904 \text{ psi}\end{aligned}$$

$$\text{Nozzle required thickness } tr_n = .01961 \text{ in}$$

Required thickness tr from UG-37(d)(1) = .2787 in

Area required

$$\text{Allowable stresses: } S_n = 14700, \quad S_v = 14700, \quad \text{psi}$$

$$\begin{aligned}fr_1 &= \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr_1 = 1 \\ fr_2 &= \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr_2 = 1\end{aligned}$$

$$\begin{aligned}A &= 0.5 * (d * tr * F + 2 * t_n * tr * F * (1 - fr_1)) \\ &= 0.5 * (7.796 * 0.2787 * 1 + 2 * 0.25 * 0.2787 * 1 * (1 - 1)) \\ &= 1.0864 \text{ in}^2\end{aligned}$$

Area available

$$A_1 = \text{larger of the following} \quad = .751 \text{ in}^2$$

$$\begin{aligned}&= d * (E_1 * t - F * tr) - 2 * t_n * (E_1 * t - F * tr) * (1 - fr_1) \\ &= 7.796 * (1 * 0.375 - 1 * 0.2787) - 2 * 0.25 * (1 * 0.375 - 1 * 0.2787) * (1 - 1) \\ &= .751 \text{ in}^2\end{aligned}$$

$$\begin{aligned}&= 2 * (t + t_n) * (E_1 * t - F * tr) - 2 * t_n * (E_1 * t - F * tr) * (1 - fr_1) \\ &= 2 * (0.375 + 0.25) * (1 * 0.375 - 1 * 0.2787) - 2 * 0.25 * (1 * 0.375 - 1 * 0.2787) * (1 - 1) \\ &= .12 \text{ in}^2\end{aligned}$$

$$A_2 = \text{smaller of the following} \quad = 0.288 \text{ in}^2$$

$$\begin{aligned}&= 5 * (t_n - tr_n) * fr_2 * t \\ &= 5 * (0.25 - 0.01961) * 1 * 0.375 \\ &= .432 \text{ in}^2\end{aligned}$$

$$\begin{aligned}&= 5 * (t_n - tr_n) * fr_2 * t_n \\ &= 5 * (0.25 - 0.01961) * 1 * 0.25 \\ &= .288 \text{ in}^2\end{aligned}$$

N4-2ND ROW-RIGHT

$$\begin{aligned} A41 &= \text{Leg}^2 * \text{fr}2 \\ &= 0.25^2 * 1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.751 + 0.288 + 0.063 \\ &= 1.102 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for Pe = 15.82647 at 400 Deg F

Reinforcement check in the plane parallel to the long. axis

Area required

$$\begin{aligned} A &= 0.5 * (d * \text{tr} * F + 2 * \text{tn} * \text{tr} * F * (1 - \text{fr}1)) \\ &= 0.5 * (7.5 * 0.2787 * 1 + 2 * 0.25 * 0.2787 * 1 * (1 - 1)) \\ &= 1.045125 \text{ in}^2 \end{aligned}$$

Area available

$$\begin{aligned} A1 &= \text{larger of the following} && = .722 \text{ in}^2 \\ &= d * (E1 * t - F * \text{tr}) - 2 * \text{tn} * (E1 * t - F * \text{tr}) * (1 - \text{fr}1) \\ &= 7.5 * (1 * 0.375 - 1 * 0.2787) - 2 * 0.25 * (1 * 0.375 - 1 * 0.2787) * (1 - 1) \\ &= .722 \text{ in}^2 \\ &= 2 * (t + \text{tn}) * (E1 * t - F * \text{tr}) - 2 * \text{tn} * (E1 * t - F * \text{tr}) * (1 - \text{fr}1) \\ &= 2 * (0.375 + 0.25) * (1 * 0.375 - 1 * 0.2787) - 2 * 0.25 * (1 * 0.375 - 1 * 0.2787) * (1 - 1) \\ &= .12 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.722 + 0.288 + 0.063 \\ &= 1.073 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for Pe = 15.82647 at 400 Deg F

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.01961 in (E = 1)
Wall thickness per UG-45(b)(2):	tr2 = 0.0454 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.0625 in
The lesser of tr4 or tr5:	tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for Pe.

PROCESS SYSTEMS INTERNATIONAL, INC.
WESTBOROUGH, MA

ENGINEERING
CALCULATIONS

NO: 1049-1-048

PAGE 1 OF 14

REV.	DEO #	DATE	BY:	CHECK
0	0024	3-27-96	GARENA	RDC

TITLE:
DESIGN OF HAM NOZZLE
JACKING BOLT ASSEMBLIES

By: GARENA DEPT: 744

PROJECT: LIGO VACUUM EQUIPMENT

PROJECT NO: V59049

PURPOSE: SEE BODY OF CALCULATION

METHOD: .

ASSUMPTIONS:

INPUTS:

REFERENCES:

CALCULATIONS: (SEE ATTACHED)

CONCLUSIONS:

NOTES:

1.0 OBJECTIVE

The objective of this calculation is to perform the structural design and analysis for the Jacking Bolt Assemblies on the Horizontal Access Module Chamber (HAM) bellows nozzle.

2.0 METHOD OF ANALYSIS / COMPUTER PROGRAMS & VERSION

No computer programs are used in the execution of this calculation:

Jacking Bolts are placed in locations that will permit operation without interferences with other components. The overall design must not permit any of the components to extend over the flange face because of restrictions in the removal of the adjacent adapter.

The Jacking Bolt Assembly components are designed to AISC allowable stresses and by manual design methods for the greater of two conditions:

- Installation and equipment servicing during which time bellows spring forces act but no pressure loads exist.
- HAM Vessel free standing full vacuum pressure test with bellows pressure loads acting on the jacking assemblies.

Welds are sized by traditional manual calculations found in standard engineering texts.

3.0 GENERAL ASSUMPTIONS

----- None requiring confirmation -----

4.0 REFERENCES

1. ASME Boiler and Pressure Vessel Code, Section VIII, Division I, 1995 Edition
2. Roark & Young, Formulas for Stress and Strain, Fifth Edition
3. Blodgett, Design of Welded Structures
4. LIGO Vacuum Equipment Structural Design Criteria, Doc. No. V049-1-066
5. AISC Steel Construction Manual


6.0 CONCLUSIONS

The Jacking Bolt orientation around the HAM nozzle and the assembly component details are found in the body of this calculation.

The location of the "D" nozzle (electrical/instr. feedthroughs, utility) located on the vertical centerline of the HAM vessel may require relocation due to possible interference with the jacking bolts and/or its close proximity to the "B" nozzle juncture (approx. 1")

JACKING BOLT ORIENTATION

22.141 50 SHEETS
22.142 100 SHEETS
22.144 200 SHEETS



DESIGN LOADS

MAXIMUM WORKING SPRING RATE FOR 2" TRAVEL

6218 #/IN (HYSPAN BELLOWS)

USE 7500 #/IN FOR DESIGN

WORST CONDITION FOR 3 BOLTS LOADED

(4TH BOLT ASSUMED INEFFECTIVE)

$$2F_1 + F_2 = 15000 \text{ \#}$$

$$2F_1 \times 7 + 4F_2 = 0$$


$$F_2 = \frac{14}{41} F_1 = .341 F_1$$

$$2F_1 + .341 F_1 = 15000$$

$$F_1 = \frac{6406 \text{ \#}}{2}$$

$$F_2 = 2188 \text{ \#}$$

USE 6400 # / ROD FOR DESIGN LOAD



DESIGN LOADS (VACUUM TEST)

$$F = \frac{\pi D_m^2}{4} \times 15 \text{ PSIA}$$

$$= \frac{\pi}{4} (2.5)^2 \times 15 = 46020 \#$$

$$\sum F_x + \sum F_y = 23010$$

$$\sum M_x = 0$$

$$2 F_1 R \sin 42 - 2 F_2 R \cos 24 = 0$$

$$F_1 \sin 42 = F_2 \cos 24$$

$$F_2 = F_1 \frac{\sin 42}{\cos 24}$$

$$\Rightarrow F_1 + F_1 \frac{\sin 42}{\cos 24} = 23010$$

$$F_1 = \frac{23010}{\left(1 + \frac{\sin 42}{\cos 24}\right)} = 13282 \#$$

$$F_2 = 9728 \#$$

$$\sum M_y$$

$$F_1 \cos 42 - F_2 \sin 24 = 0$$

$$F_1 + F_1 \frac{\cos 42}{\sin 24} = 23010 \Rightarrow F_1 = \frac{23010}{\left(1 + \frac{\cos 42}{\sin 24}\right)} = 8139 \#$$


$$F_2 = 14871 \#$$

$$F_{1 \text{ AVE}} = \frac{13282 + 8139}{2} = 10710 \#$$

$$F_{2 \text{ AVE}} = \frac{14871 + 9728}{2} = 12300 \#$$

$$\sum F_z \approx 2(10710) + 2(12300) = 46020$$

46020 = 46020 OK




DESIGN LOAD = 12,300 # / ROD

VACUUM TEST LOAD GOVERNS

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



COMPONENT DESIGN



22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS

ROD (IN COMPRESSION) 1" ϕ x 3 THD/IN

ONE END FIXED OTHER END PINNED $K=3$ USE $K=1.0$

MAT'L A320-B8 (304⁵/s) $F_y = 80$ KSI

ROOT DIA OF THDS = 0.833" $r = \frac{.833}{4} = .21$

$L_{EFFECTIVE} = 7 \frac{3}{16} + \frac{3}{4} - 1" = 7 \frac{3}{16}"$

$$F_c @ \frac{KL}{r} \Rightarrow \frac{1 \times 6.9375}{.21} = 33.04 \Rightarrow 35$$

FROM AISC @ $F_y = 90$ $F_c = 44.67$ KSI

$$F_c = 44.67 \times \frac{80}{90} = 39.71 \text{ KSI MAX}$$

$$f_c = \frac{P}{A} = \frac{12.3}{\frac{\pi(.833)^2}{4}} = 22.3 \text{ KSI} < 39.71 \text{ KSI} \quad \text{OK}$$

PIN (DOUBLE SHEAR) A320 B8 $F_y = 100$ KSI

$F_s = .4 F_y = 40$ KSI

$$A_{REQ'D} = \frac{P}{2 F_s} = \frac{12300}{80,000} = .15 \text{ IN}^2 \Rightarrow D_{REQ'D} = .44"$$

USE 1/2" ϕ PIN

FLANGE LUG

A240-TP304 3/5


$F_y = 30 \text{ KSI}$

SHEAR OUT AT PIN HOLE

$$f_s = \frac{P}{A_{\text{PRAL}}} = \frac{12300}{2 \times 1.25 \times t}$$

$$F_s = .4 F_y = 12 \text{ KSI}$$

$$t = \frac{12300}{2.5 \times 12000} = .41''$$



BEARING AT PIN HOLE

$$F_B = 1.35 F_y = 40500 \text{ PSI}$$



$$f_b = \frac{P}{A_{\text{PROJ}}} = \frac{12300}{(.5)(.5)} = 49200 > 40500 \text{ NG}$$

$$@ \frac{5}{8} R \quad \frac{P}{b} = \frac{12300}{.625 \times .5} = 39360 < 40500 \text{ OK}$$


USE $t = 5/8''$

CLEVIS DETAIL

A240 TP304 STD STL



PIN DETAIL




22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



filename: FULLCIR.WR1

FULL CIRCULAR/TRUNNION FILLET WELD

Between part ROD and part CLEVIS



LOAD INPUT (LBS., INCH-LBS.)

F1	F2	F3	M1	M2	M3
0.00	12300.00	0.00	0.00	0.00	0.00

GEOMETRIC DIMENSIONS (FOR FLAT PLATES, INPUT D=100'd)

dw	Dp
0.838	1000.000

SECTION PROPERTIES

A	S _w	J _w	WELD STRESS (PSI)
2.633	0.552	1.103	18000

EFFECTIVE THROAT CORRECTION FACTOR
Mf
1.00

MAXIMUM WELD LOAD (f) - #/INCH
4672


REQUIRED FILLET WELD SIZE (INCHES)
w
0.387

USE 3/8" FILLET WELD

filename: FULLRECT.WR1

ALL AROUND RECTANGULAR OR SQUARE FILLET WELD

Between part FLANGE LUG and part FLANGE



LOAD INPUT (LBS., INCH-LBS.)

F1	F2	F3	M1	M2	M3
0.00	12300.00	0.00	12451.00	0.00	0.00

GEOMETRIC DIMENSIONS

a	b	WELD STRESS (PSI)	SKEWED ANGLE(90°>θ<120°)
3.000	0.625	18000	90.000

SECTION PROPERTIES

A	Sw1	Sw3	J	C1	C3
7.250	4.875	2.005	7.939	1.500	0.313

EFFECTIVE THROAT CORRECTION FACTOR

Mf
1.00

MAXIMUM WELD LOAD (f) - #/INCH

f
5481

REQUIRED FILLET WELD SIZE (INCHES)

w
0.431


USE $\frac{7}{16}$ FILLET WELD

filename: CHNL_WLD.WR1

CHANNEL-SHAPED FILLET WELDS

NOTE: FOR ALL AROUND WELD USE (f)/2 TO SIZE WELD LEG

Between part HAM NOZZLE and part NOZZLE BRACKET



LOAD INPUT (LBS., INCH-LBS.)

F1	F2	F3	M1	M2	M3
12300.00	0.00	0.00	0.00	0.00	41513.00

GEOMETRIC DIMENSIONS

a	b	WELD STRESS	SKEWED ANGLE(90°>B<135°)
6.000	4.000	18000	90.000

SECTION PROPERTIES

A	Sw1	I3	J	C1	C3
14.000	30.000	24.381	114.381	3.000	1.143

Cp
2.857

EFFECTIVE THROAT CORRECTION FACTOR

Mf
1.00

MAXIMUM WELD LOAD (f) - #/INCH

f
4944

EQUIRED FILLET WELD SIZE (INCHES)

w
0.388

$$\frac{w}{2} = .20$$

USE 1/4" FILLET ALL AROUND

OR

1/16 FILLET OUTSIDE EDGES
(3 SIDES)

NOZZLE SHELL STRESS DURING FULL VACUUM TEST
 bracket WRC bulletin 107 design

ASME Code Addenda used - A90

Internal design pressure P = -15 psi
 Design temperature is = 70 deg F
 Corrosion allowance C = 0 in.
 Shell inner diameter, new Di = 60.5 in.
 Shell thickness, new t = .5 in.
 Mat'l is exempt from impact testing per UHA-51(a)
 Allowable tensile stress S = 18800 psi for SA 240 304 HIGH A88^
 Lug length, circ direction 2C1 = 6 in.
 Lug length, long direction 2C2 = 4 in.
 Lug interface radius = .5 in.

Applied Loads

Radial load Pr = 0 lbf
 Circumferential moment Mc = 0 lb-in
 Longitudinal moment ML = 41513 lb-in
 Circumferential shear Vc = 0 lbf
 Longitudinal shear VL = 12300 lbf

Stresses at the lug interface per WRC bulletin 107

Geometric factor gamma = 61
 Stress concentration factor Kn (tension) = 1
 Stress concentration factor Kb (bending) = 1
 Beta1 = 9.836066E-02, Beta2 = 9.836066E-02

From Fig.	Value read	beta	Circumferential (hoop) stress psi							
			Au	Al	Bu	Bl	Cu	Cl	Du	Dl
pressure stress*			-908	-908	-908	-908	-908	-908	-908	-908
4C*	10.216	.098	0	0	0	0				
3C*	8.586	.098					0	0	0	0
2C-1	.075	.098	0	0	0	0				
1C	.109	.098					0	0	0	0
3A*	2.148	.098					0	0	0	0
1A	.09	.109					0	0	0	0
3B*	6.858	.098	-5559	-5559	5559	5559				
1B	.042	.098	-14000	14000	14000	-14000				
Total hoop stress			-20467	7533	18651	-9349	-908	-908	-908	-908
Primary membrane circ. stress*			-6467	-6467	4651	4651	-908	-908	-908	-908

Maximum primary membrane circ. stress = -6467 psi
 Allowable primary membrane circ. stress = +-1.5*S = +- 28200 psi

The maximum primary membrane circ. stress is within allowable limits

From Fig.	Value read	beta	Longitudinal (axial) stress psi							
			Au	Al	Bu	Bl	Cu	Cl	Du	Dl
pressure stress*			-454	-454	-454	-454	-454	-454	-454	-454
4C*	10.216	.098					0	0	0	0
3C*	8.586	.098	0	0	0	0				
1C-1	.111	.098	0	0	0	0				
2C	.074	.098					0	0	0	0
4A*	3.234	.098					0	0	0	0
2A	.047	.111					0	0	0	0
4B*	2.074	.098	-1797	-1797	1797	1797				
2B	.062	.105	-19288	19288	19288	-19288				
Total Axial stress			-21539	17037	20631	-17945	-454	-454	-454	-454
Primary membrane long. stress*			-2251	-2251	1343	1343	-454	-454	-454	-454

Maximum primary membrane long. stress = -2251 psi
 Allowable primary membrane long. stress = $\pm 1.5 \cdot S = \pm 28200$ psi

The maximum primary membrane long. stress is within allowable limits

Loading	Shear stress psi							
	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
torsion moment Mt	0	0	0	0	0	0	0	0
Circ. load Vc	0	0	0	0				
Long. load Vc					-2050	-2050	2050	2050
Total Shear stress	0	0	0	0	-2050	-2050	2050	2050

COMPRESS 4.20

ham

Mar. 27, 1996

At point -->	Combined stress intensity, psi							
	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Combined stress	-21539	17037	20631	-17945	4125	4125	4125	4125

Maximum combined stress = -21539 psi
 Allowable combined stress = $\pm 3 \cdot S = \pm 56400$ psi

The maximum combined stress is within allowable limits.

Hyspan Precision Products, Inc.
1685 Brandywine Avenue
Chula Vista, California 91911, U.S.A.

Telephone (619) 421-1355
Telecopier (619) 421-1702

TELECOPIER TRANSMITTAL

To: PROCESS SYSTEMS INTERNATIONAL
WESTBOROUGH, MASS.

Telecopier No.: (508)-898-0322Date: 2/9/96Total number of pages including this page 3ATTN: GUY ARENAQD-9317Reference: HORIZONTAL ACCESS MODULE CHAMBER (HAM)
NOZZLE BELLOWS DESIGNGuy,

THE FOLLOWING ARE PRELIMINARY BELLOWS
DESIGN CALCULATIONS FOR BOTH THE OPERATING
& MAINTENANCE MODES DESCRIBED IN YOUR
1/24/96 FAX. NOTE THE AXIAL SPRING
RATE OF 6,218 lbs./in. EQUATES TO AN APPROX.
65.5 lbs PER INCH LOAD ON THE CIRCUMFERENCE OF
THE FLANGE I.D. PLEASE LET US KNOW IF
YOU HAVE ANY QUESTION &/OR WE CAN BE
OF FURTHER HELP. HYSPAN LOOKS FORWARD TO
RECEIVING YOUR FORMAL REQUEST FOR THIS
PROJECT.

REGARDS,

From: MARTY KOESTER