

1993.06.15 Salt Kill Study



Norlite Corporation

628 SO. SARATOGA ST.
P.O. BOX 694
COHOES, N.Y. 12047
TEL.: (518) 235-0401
FAX.: (518) 235-0233

June 15, 1993

WJZ-114-93



Mr. William Clarke
Regional Permit Administrator
New York State Department of
Environmental Conservation
Region 4
2176 Guilderland Ave.
Schenectady, NY 12306

Dear Mr. Clarke:

Submitted with this letter is a report on the study of the source of the precipitate observed in the Salt Kill Creek under certain conditions. This study was performed in accordance with a Work Plan submitted to NYSDEC on October 15, 1992. The study concludes that control of scrubber blowdown pH to a range of 8.0 to 8.5 will prevent the formation of the precipitate. This range is also consistent with the optimum pH range for acid gas removal efficiency by the APC system demonstrated in the October 1992 Trial Burn.

If you have any questions, please contact Richard Schlauch or myself at 803/329-9690.

Sincerely,

William J. Ziegler
Vice President of Health,
Safety and Environmental Affairs

WJZ:ncm

Attachment

cc: Carol Lamb-LaFay
William Voshell
Dallas Robinson

JUN 21 1993

**STUDY OF PRECIPITATE IN THE
SALT KILL CREEK AT NORLITE CORPORATION
COHOES, NEW YORK**

JUNE 10, 1993

Prepared by:

Richard Schlauch
Richard Schlauch
Environmental Systems Manager
Norlite Corporation

Operator Certification by:

William J. Ziegler
William J. Ziegler
Vice President of Health,
Safety & Environmental Affairs
Norlite Corporation

**STUDY OF PRECIPITATE OBSERVED IN THE
SALT KILL CREEK AT NORLITE CORPORATION, COHOES, NEW YORK**

<u>CONTENTS</u>		<u>Page #</u>
1.	INTRODUCTION	1
2.	SUMMARY	6
3.	SAMPLING PROGRAM	8
4.	LABORATORY LIQUID-SOLIDS SEPARATION AND JAR TESTS	15
5.	AQUEOUS STREAM SAMPLE ANALYSIS	20
6.	CREEK BOTTOM SEDIMENT SAMPLE ANALYSIS	26
7.	PRECIPITATE FORMATION AND MATERIAL BALANCE CALCULATIONS	29
8.	OPTIONS FOR CONTROL OF PRECIPITATION IN SALT KILL	35
9.	CONCLUSIONS	47
10.	RECOMMENDATIONS	50
11.	REFERENCES	52
12.	APPENDIX	53

1. INTRODUCTION

1.1 Scope of Salt Kill Precipitation Study

To understand the magnitude of the Salt Kill precipitation (or siltation) phenomenon, as well as the cause and sources of the deposited material, an analytical evaluation of both the natural Salt Kill water as well as the Norlite wet scrubber blowdown discharge was performed. The analytical results were then used to accurately predict the chemical composition of an admixture of the natural Salt Kill water with the scrubber blowdown as well as the chemical reactions that will occur (if any) upon mixing.

1.2 Natural Water Characteristics

Reference to any text or published information on natural water supply characteristics (eg. Refs. 1 and 2) indicate that all natural water sources, either in the raw state or after treatment, contain dissolved mineral matter. The most abundant of these dissolved minerals are the bicarbonates, sulfates and chlorides of calcium, magnesium and sodium. Silica (SiO_2) is also a common dissolved constituent of natural water ranging in concentration from about 1 ppm to over 100 ppm. Iron and manganese are also typically present, but in dissolved concentrations of less than 1.0 ppm.

In natural streams such as the Salt Kill, these dissolved minerals enter into the water through the solvent properties of the water acting on soil and rock constituents. For instance, the primary mechanism for calcium and bicarbonate presence in the water is through a natural process where organic matter and carbonaceous materials deposited in the soil (in contact with the water) are decomposed by soil bacteria. The decomposition of carbonaceous matter generates carbon dioxide gas as a by-product, which is absorbed in the water. The dissolved carbon dioxide (CO_2) forms carbonic acid (H_2CO_3) in the water which then dissolves naturally occurring limestone (CaCO_3) that the water comes in contact with. The limestone constituents, when dissolved, form the calcium ion (Ca^{++}) and bicarbonate ion (HCO_3^-) concentrations analyzed in the water. The more decomposing carbonaceous material the water contacts, the more CO_2 can be absorbed (more at cooler temperature than at warm temperature) and the more limestone that can be dissolved into the water.

A water that has become "saturated" with dissolved calcium and bicarbonate in this way, can initially appear crystal clear and colorless without any sign of suspended solids (i.e., the calcium and bicarbonate are completely dissolved in the form of ions in water). To remain in the saturated ionic calcium bicarbonate condition, the water must remain within a specific range of pH value, temperature and total solids concentration. A significant

change in any one or more of these conditions can trigger a reaction between calcium and bicarbonate ions that will precipitate some or most of these constituents, thus forming solid calcium carbonate either as a soft, voluminous precipitate or a hard rock-like (crystalline) material.

The significant changes triggering these precipitation reactions can be the result of either natural or un-natural environmental changes or a combination of both. Environmental changes that cause calcium carbonate precipitation are heating, evaporation and pH increases due to loss of CO_2 content or other influences.

An example of a common natural display of the phenomenon is when groundwater saturated with calcium bicarbonate percolates through the rocks and soil before reaching a cavern or cavity underground. If percolation is slow enough for water droplets to form on an elevated surface of the cavern, some of the droplets will evaporate causing calcium carbonate to crystallize on the surface from which the drop is suspended. When another droplet percolates through to join the first, a portion of the droplet falls to the floor of the cavern where it continues to evaporate and crystallize more calcium carbonate on that surface. As this process continues over many hundreds and thousands of years, gigantic pillars of limestone (i.e., CaCO_3) are formed hanging from the ceiling (stalagmites) and growing up from the floor (stalagmites).

1.3 Scrubber Blowdown Characteristics

The same parameters that cause calcium carbonate to precipitate in natural water will cause calcium carbonate to precipitate in an industrial wastewater discharge such as wet scrubber blowdown. The primary parameters are the calcium and carbonate/bicarbonate concentrations as well as the pH, temperature and total solids concentration of the discharges. Even if no calcium or carbonate concentrations are present in the industrial discharge, mixing the discharge with a natural water can trigger calcium carbonate precipitation due to a shift in the resultant temperature and/or pH of the combined flows.

1.4 Conventional Calcium Carbonate Chemistry Terminology

The study and evaluation of water systems involving calcium carbonate chemistry uses terminology that is almost exclusively limited to the water treatment technology field. Thus, such terms may not be familiar to chemists and engineers who have discipline in more general chemical process or analytical fields. A brief description of the following terms are relevant to understanding the results, discussion and conclusions of this study:

1.4.1 Hardness

The dissolved calcium concentration of a water is not of particular concern from an environmental or health point-of-view. Most naturally occurring calcium compounds are non-toxic substances that make up a large fraction of the earth's crust as well as many living organisms. For example, exoskeletons of many marine and aquatic invertebrates are made of calcium carbonate assimilated from the surrounding water. The skeletons and teeth of higher animals are comprised of calcium phosphate.

From an industrial use point-of-view however, the calcium content of a water is a major concern. For example, because of the tendency of calcium carbonate (and calcium sulfate) to "scale out" of water when it is used for either cooling or steam generating purposes, its analyses in the water source is always essential and treatment for its removal is typically required.

Historically, the term "hardness" was initiated by the laundry and cleaning products industries. The term hardness applies to the natural cationic components of water that cause soap to precipitate and thus, make a water "hard" to wash with. Normally, calcium and magnesium are the most abundant cations in natural water that cause soap to precipitate. Together, the calcium and magnesium concentrations are generally considered the "total hardness" of natural water. Alone, the calcium ion concentration is considered the "calcium hardness" and magnesium ion concentration is the "magnesium hardness".

1.4.2 Alkalinity

Whenever a natural mineral, such as calcium carbonate or sodium chloride dissolve in water, ions of opposite charge called cations (i.e., Ca^{++} , Na^+ , etc.) and anions (i.e., $\text{CO}_3^{=}$, Cl^- , etc.) are formed in chemically equivalent (stoichiometric) concentrations.

Thus, whenever calcium ion is found dissolved in natural water, there must be a chemically equivalent balance with one or more anions (such as bicarbonate, carbonate, sulfate or chloride) present that came from the dissociation of the same dissolved mineral(s).

Certain of the anions have the ability to neutralize mineral acids (i.e., HCl , H_2SO_4 , HNO_3) forming salt and water as the products of the neutralization reaction. Together, the combined concentration of all the acid neutralizing anions is called the "total alkalinity" of the water. In natural water, bicarbonate (HCO_3^-), carbonate ($\text{CO}_3^{=}$) and hydroxide (OH^-) ions make up the "total alkalinity" of the water. The HCO_3^- concentration is the "bicarbonate alkalinity", $\text{CO}_3^{=}$ concentration is the "carbonate alkalinity" and the OH^- concentration is the "hydroxyl

alkalinity" (also referred to as "causticity") of the water. Since most natural water has pH values less than 9.0, and very little OH^- concentration is present at this pH, "total alkalinity" is typically comprised of just HCO_3^- and CO_3^{2-} concentration.

Since SO_4^{2-} and Cl^- are already the anions of salts of these acids, they don't neutralize the acids and do not constitute alkalinity in the water.

Therefore, hardness may be associated with an equivalent concentration of alkalinity or may be associated only with non-alkaline anions or may be associated with some of each. That portion of hardness associated with (or equivalent to) the alkalinity (i.e., HCO_3^- and CO_3^{2-}) of the water is known as "carbonate hardness" and the portion associated with (or equivalent to) the non-alkaline anions (i.e., SO_4^{2-} , Cl^- , NO_3^-) is known as "non-carbonate hardness".

1.4.3 Calcium Carbonate Units or Equivalents

Historically, the conventional water treatment process for removal of calcium hardness involves precipitation with carbonate to form solid calcium carbonate. If not enough carbonate or bicarbonate ion is naturally present, a soluble salt such as soda ash (Na_2CO_3) is added stoichiometrically to maximize the removal of dissolved calcium as much as possible.

Even though ion exchange softening has largely replaced these conventional water treatment methods (that involve treating for dissolved calcium by precipitation of solid calcium carbonate), it is still the convention in both analysis reporting and calculation of treatment dosages to express both hardness and alkalinity constituents in terms of calcium carbonate equivalents (i.e., mg/l as CaCO_3). Therefore, upon glancing at a water analysis it is readily apparent whether or not all the calcium present is associated with (or equivalent to) all the alkalinity present or vice-versa. Also, this convention helps in calculating the dosages of treatment chemicals (such as $\text{Ca}(\text{OH})_2$ and Na_2CO_3) needed to remove either excess calcium or excess alkalinity since they would also be converted to their CaCO_3 equivalents.

Another reason for use of CaCO_3 equivalents is that it is a convenient mechanism with which to put each of the reacting hardness and alkalinity components on the same molar (i.e., chemically equivalent or stoichiometric) basis. Since each chemical species must react with the stoichiometric equivalent of another species, the molecular weight of CaCO_3 (being 100 grams/mole) makes a convenient denominator to divide the molecular weight of the other reacting species by to determine their multiplication factors for calculating concentrations as CaCO_3 equivalents.

The use of CaCO_3 equivalents was a system devised in the early days of water treatment technology since many water treatment operators had no formal training or knowledge of chemical reactions, molar equivalents or stoichiometric balances between reacting species. Therefore, tables were prepared, such as shown in Tables 126 through 134 in Ref. 1, pp 488-489, to allow quick calculation of various chemical species concentrations as calcium carbonate equivalents (i.e., mg/L as CaCO_3).

2. SUMMARY

2.1 Objective

The first objective of this study is to determine the source, quantity and composition of the precipitate observed in the Salt Kill Creek downstream of Norlite's scrubber blowdown outfall.

The second objective is to determine and recommend measures that can be taken to eliminate or minimize the precipitate formation and subsequent deposition in the creek.

2.2 Scope

The results of this study including its conclusions and recommendations are based on data from sampling, measurements and analysis compiled from a 5-day study period representing typical facility operating and creek flow conditions during November 9 to 13, 1992.

These sampling procedures involved compositing five individual daily grab samples (both liquids and solid sediments from upstream Salt Kill, scrubber blowdown and downstream Salt Kill sample points) into 5-day composites to determine average stream compositions during this study period.

The sampling program was carried out by qualified Norlite personnel. Sample analysis were conducted by outside New York State certified laboratories.

2.3 Results

Results of the stream sampling and laboratory testing and analysis studies show that the majority of the precipitate observed in the Salt Kill downstream of the Norlite scrubber blowdown outfall is calcium carbonate. About 80 percent of the precipitate is composed of calcium carbonate while the majority of the remaining 20 percent is attributed to silica (i.e., SiO_2) and water with minor amounts of calcium, magnesium, aluminum and iron silicates, oxides and hydrates.

Mass balance calculations show the majority of the downstream sample point precipitate during the study (i.e., 84%) came from the Salt Kill water flow itself as naturally occurring carbonate hardness. The remaining 16% of the precipitate at the downstream Salt Kill sample point originates from the scrubber blowdown discharge due to calcium carbonate hardness in the scrubber recycle water.

Excess carbonate/bicarbonate alkalinity in the scrubber blowdown, during this study period, was the key factor in initiating calcium carbonate precipitation at the downstream sampling point.

This excess total alkalinity was sufficient to raise the pH of the Salt Kill to about 9.2 at the downstream sample point. At this pH value, the naturally dissolved calcium carbonate hardness in the Salt Kill becomes "mostly" insoluble and the majority precipitates and settles to the bottom of the creek as sediment.

2.4 Recommendations

Recommendations are made considering several options to reduce the pH and "buffering" characteristics of the total alkalinity in the scrubber blowdown stream. Lowering the excess concentration of carbonate buffer in the blowdown by reducing the scrubber recycle pH value from 9.2 to about 8.5 or less is an option that can be immediately taken to reduce the amount of precipitation that was observed during this study. The zero discharge option, if implemented, will also eliminate this source of precipitation. A final effluent pH adjustment system is also an option that could be added to ensure that precipitation of the natural hardness in the Salt Kill is not increased by the blowdown discharge.

The most effective interim option, from an effectiveness and implementation standpoint, is to substitute sodium hydroxide for sodium carbonate as the alkali source for acid neutralization in the scrubber system. This would eliminate excess carbonate buffer in the blowdown and the need for a final effluent pH adjustment system (assuming the blowdown pH value is maintained at a maximum of 9.0). A major reduction in downstream calcium carbonate suspended solids (i.e., precipitate) could be obtained immediately even prior to implementation of the zero discharge option.

3. SAMPLING PROGRAM

3.1 Objective

The sampling and evaluation program was proposed in a letter submitted by Norlite to NYSDEC dated October 15, 1992.

Collection of representative samples during typical kiln operation and Salt Kill Creek flow was performed to determine the composition and quantity of precipitate found settling in the creek bed downstream of Norlite's Outfall 005 discharge. This outfall flow is comprised of blowdown from the wet scrubber process of the expanded lightweight aggregate kiln APC systems.

Based on the typical Salt Kill Creek flow rate and scrubber blowdown rates, the mass of precipitated material was calculated from sample analysis. Recommendations are made in section 10 of this report, proposing alternative measures that will prevent or reduce the mass of precipitated material that has been demonstrated to be formed by admixing of APC wet scrubber blowdown discharge with upstream Salt Kill Creek Water.

3.2 Estimated Representative Conditions

The sampling program was carried out during a period of estimated typical Kiln #1 and #2 operating conditions, Salt Kill flow and weather conditions. The sampling was started on November 9, 1992 and completed on November 13, 1992. Each daily grab sample was combined with the others into a 5-day composite sample to determine average sample source composition over the 5-day period.

In addition to analyzing the composite samples of scrubber blowdown and Salt Kill Creek upstream and downstream locations, a 5-day composite of blowdown (at 1-part by volume) mixed with upstream Salt Kill water (at 7.3 parts by volume) was prepared and studied for precipitate formation. This volume ratio represents the average combined scrubber blowdown flows (at 60 gpm) with Salt Kill flow (at 1 ft³/sec). (The calculated average Salt Kill flow during this study turned out to be 0.94 ft³/sec based on results of the sample analysis).

Salt Kill bottom sediment sample compositions were also compared with the composition of the precipitate formed by mixing of the blowdown water samples with the upstream Salt Kill water samples.

Sample point locations where the grab samples were collected are shown in Figure 3-1. The definition of each sample collected at these sampling locations is included in Table 3-1.

3.3 Sample Collection Procedure

During the period of November 9, 1992 to November 13, 1992, grab samples of the Outfall 005 discharge; the upstream and downstream Salt Kill waters; and upstream and downstream Salt Kill bottom

sediments were collected daily for the period of 5 consecutive days. The samples were collected and combined (i.e., mixed) as follows:

SAMPLE POINT A. Each day a 2-liter grab sample of 005 discharge was split into various portions as follows;

Sample A.1 - A 750-ml portion of the Outfall 005 grab sample was composited each day into a 1-gallon 5-day composite and preserved only by refrigeration. A 200-ml portion of this grab sample was added daily to a 1-liter glass jar, preserved with HNO_3 , to form a 5-day composite. The non-acidified portions were designated Sample A-1 and the HNO_3 preserved portion were designated Sample A.1 (HNO_3 preserved).

Sample A.2 - A one-liter portion of each daily 005 grab sample was measured for pH and temperature and then settled in an Imhoff cone for 60-minutes to measure settleable solids concentrations. Then, 90-ml of the supernatant in the Imhoff cone was saved each day for preparing composite sample C and 750 mls were combined into a 1-gallon 5-day composite designated Sample A.2. Also, a 50-ml portion of each daily supernatant was combined in a 250-ml glass jar preserved with HNO_3 . The non-acidified 1-gallon composite was designated Sample A.2 and the 250-ml acidified composite was designated Sample A.2 (HNO_3 preserved).

SAMPLE POINT B. Each daily 2-liter grab sample of upstream Salt Kill water was split into various portions as follows;

Sample B.1 - A 750-ml sample of upstream water was composited each day into a 1-gallon 5-day composite of the daily grab samples and preserved by refrigeration. A 200-ml portion was composited in a 1-liter glass jar preserved with HNO_3 . These were designated composite Sample B.1 (i.e., 1-gallon non-acidified) and B.1 (HNO_3 preserved).

Sample B.2 - A 1-liter portion of each daily upstream creek sample was measured for pH, temperature and settled in an Imhoff cone for 60-minutes to measure settleable solids concentration. A 660-ml portion of this supernatant sample was saved each day for preparing composite Sample C.

Also, a 200-ml portion of each daily supernatant was combined into a 1-liter non-acidified 5-day composite designated as composite Sample B.2. Additionally, a 50-ml portion of each daily supernatant was combined into a 250-ml glass jar preserved with HNO_3 and designated composite Sample B.2 (HNO_3 preserved).

SAMPLE POINT C. Each day, a 90-ml sample of Imhoff cone supernatant saved from Outfall 005 (i.e., Sample A.2) was combined with a 660-ml portion of supernatant saved from the upstream grab sample (i.e., Sample B.2) in a 1-gallon non-acidified 5-day composite designated composite Sample C.

SAMPLE POINT D. Each daily grab sample of downstream creek water was split into various portions as follows;

Sample D.1 - A 750-ml portion of the downstream creek daily grab was composited daily into a 5-day 1-gallon composite and preserved by refrigeration. Also, a 200-ml portion of this sample was combined daily in a 1-liter glass jar preserved with HNO_3 . The non-acidified 1-gallon sample was designated composite Sample D.1 and the 1-liter acid preserved sample was designated composite Sample D.1 (HNO_3 preserved).

Sample D.2 - A 1-liter portion of each daily downstream creek sample was measured for pH, temperature and settled in an Imhoff cone for 60-minutes to measure settleable solids concentration. A 200-ml portion of this supernatant sample was combined into a 1-liter non-acidified 5-day composite designated as Sample D-2. A 200-ml portion of this supernatant was also combined into a 1-liter HNO_3 preserved sample designated D.2 (HNO_3 preserved)

SAMPLE POINT E. Each day a 750-ml sample of the bottom mud and sediment was collected from the upstream creek bed (consisting of liquid and settled solids) by scooping the sediment off the bottom and measuring in a 1-liter graduated cylinder. Sand and pebbles were avoided in collecting this sediment sample. The daily 750-ml bottom sediment samples were combined into a 1-gallon 5-day composite designated composite Sample E. Note: Due to a limited amount of non-sandy (i.e., muddy) sediment at sample point E, only a small fraction of Sample E was solid sediment.

SAMPLE POINT F. Each day a 750-ml sample of bottom mud and sediment was collected from the downstream creek bed (consisting of approximately 50% by volume liquid and 50% by volume settled solids) by scooping the sediment off the bottom and measuring in a 1-liter graduated cylinder. Sand and pebbles were avoided with this sediment sample. The daily 750-ml bottom sediment samples were combined into a 1-gallon 5-day composite designated composite Sample F.

3.4 Sample Analysis Procedure

3.4.1 - At the completion of the 5-day sampling procedure, all composite samples designated A.1, B.1, D.1, A.2, B.2 and D.2 (including both the 1-gallon non-acidified samples, as well as the HNO_3 preserved portions) were sent directly to AnalytiKEM Inc. in Cherry Hill, New Jersey for the following analyses:

3.4.1.1 - All the 1-gallon (non-acidified) composites were shaken well prior to analysis and analyzed by standard wet chemical analysis for the following parameters;

- o Total hardness
- o Total alkalinity

- o Carbonate alkalinity
- o Bicarbonate alkalinity
- o Hydroxide alkalinity
- o Total sulfate
- o Total suspended solids
- o Total dissolved solids
- o pH value

All the above parameters were determined using procedures described in "Standard Methods for Analysis of Water and Wastewater."

3.4.1.2 - All the HNO₃ preserved portions of these composite samples were analyzed by New York State approved ICP methods for the following metals;

- o Total calcium
- o Total magnesium
- o Total iron
- o Total manganese
- o Total aluminum

3.4.2 Step 1. Laboratory Separations

At the completion of the 5-day sampling period, all composite samples designated C., E. and F. were sent to ThermalKEM Inc. Wastewater Treatment Laboratory in Rock Hill, S.C. for liquid-solid separation by bench test procedures as follows;

3.4.2.1 - Each composite sample (i.e., C., E. and F.) was well shaken, measured for pH, temperature and conductivity and then strained through a U.S. Standard 100-mesh (i.e., 0.15 mm opening) stainless steel sieve. The retained solids (if any) were collected, dried at 104°C, weighed and placed in separate glass jars (unpreserved) and designated Sample C.1, E.1 and F.1 to correspond with the original composite sample.

3.4.2.2 - The portion of each composite sample that passed through the 100-mesh sieve was then individually filtered through a pre-weighed and pre-rinsed filter pad by vacuum flask fitted with a buchner funnel. The vacuum was applied until the free liquid stopped flowing from the solids residue cake on the filter pad. Each filter cake was then dried at 104°C and weighed with the filter pad and the filter pad weight subtracted from the total. The filter pads were removed and each solids residue was placed in a separate glass jar designated Sample C.2, E.2 and F.2.

3.4.3 Step 2. Sample Residue Analysis


Solid residues including Samples F.1, C.2, E.2 and F.2 , were analyzed by x-ray diffraction methods for compounds containing the following elements:

- o calcium
- o Iron
- o manganese
- o aluminum
- o carbon
- o oxygen
- o silicon
- o sulfur

Samples C.1 and E.1 were not of significant quantity to measure or analyze.

TABLE 3-1
NORLITE FACILITY
SALT KILL CREEK SEDIMENT STUDY
SAMPLE DESIGNATION/DESCRIPTION MATRIX

A.1 OUTFALL 005 WASTEWATER DISCHARGE	B.1 UPSTREAM SALT KILL CREEK WATER	C. BLEND OF 1-PART A.2 + 7.3 PARTS B.2	D.1 DOWNSTREAM SALT KILL CREEK WATER	E. SEDIMENT UPSTREAM SALT KILL CREEK BED	F. SEDIMENT DOWNSTREAM SALT KILL CREEK BED
A.2 SUPERNATANT OF OUTFALL 005 DISCHARGE	B.2 SUPERNATANT OF UPSTREAM SALT KILL WATER	C.1 COARSE SOLIDS + 100 MESH FROM SAMPLE C.	D.2 SUPERNATANT OF DOWNSTREAM SALT KILL WATER	E.1 +100 MESH SOLIDS STRAINED FROM SAMPLE E.	F.1 +100 MESH SOLIDS STRAINED FROM SAMPLE F.
		C.2 FINE SOLIDS - 100 MESH FILTER CAKE FROM SAMPLE C.		E.2 -100 MESH SOLIDS RESIDUE FILTERED FROM SAMPLE E.	F.2 -100 MESH SOLIDS RESIDUE FILTERED FROM SAMPLE F.



SCALE
100'

FIGURE 3-1

PROJECT	SALT KILL PRECIPITATION STUDY		
TITLE	SAMPLE LOCATIONS		
NORLITE CORPORATION COHOES, NEW YORK			
APPROVED	DATE	SCALE	BY
R SCHLARCH	NOV 72		
PROJECT	NO.	DATE	BY
	B		

4. LABORATORY LIQUID-SOLIDS SEPARATIONS AND JAR TESTS

4.1 Laboratory Bench Measurements

One gallon samples (sent in a refrigerated cooler) were received at the ThermalKEM, Rock Hill, SC wastewater treatment laboratory on November 17, 1992 for liquid-solids separations and jar tests.

The following bench measurements were made upon receipt of the samples:

<u>Sample</u>	<u>Temperature (°F)</u>	<u>pH Value</u>	<u>Conductivity (micro S/cm)</u>
B-1	51	8.46	750
C	51	8.82	2,870
E	51	8.30	675
F	52	8.88	3,590

4.2 Liquid-Solids Separations

4.2.1 Coarse Solids Fraction

The one-gallon samples of C, E and F were strained through a stainless steel U.S. Standard 100 mesh sieve (i.e., 0.15 mm opening) and solids retained on the sieve were dried at 104°C and weighed to give the following results:

<u>Sample</u>	<u>Settled Solids Vol (ml/L)</u>	<u>Supernatant Vol (L)</u>	<u>Dry Solids (grams)</u>
C.1	0.35	3.65	none
E.1	<0.1	3.60	0.007
F.1	950	3.20*	345.426

* Filtrate volume

4.2.2 Fine Solids Fraction

The suspension passing through the 100-mesh sieve was then filtered through a Whatman GF/A (0.0016 mm pore diameter) filter pad to capture and retain the fine solids fraction. The retained solids on the filter pad were dried at 104°C and weighed to give the following results:

<u>Sample</u>	<u>Settled Solids Vol (ml/L)</u>	<u>Supernatant Vol (L)</u>	<u>Dry Solids (grams)</u>
C.2	NA	3.65	0.368
E.2	NA	3.60	0.106
F.2	NA	3.20	196.625

These results indicate that the total suspended solids resulting from admixing 1-part of scrubber blowdown with 7.3 parts of Salt Kill water (i.e., Sample C) are equal to 101 mg/L (i.e., 368 mg/3.65 liters).

One duplicate of Sample B.1 was initially sent to Rock Hill with samples C.2, E.2 and F.2 for jar tests to study the precipitation potential of the upstream Salt Kill water itself. However, it was reported that the other duplicate B.1 sample was not received at AnalytiKEM in Cherry Hill, New Jersey for general chemical and metals analysis. Therefore, a 500-ml portion of B.1 was used with 3600-ml of Sample E filtrate to represent the upstream Salt Kill water in these jar tests. The remainder of Sample B.1 (about 3-liters) was sent to AnalytiKEM, Cherry Hill, New Jersey for general chemical and metals analyses.

4.3 Upstream Salt Kill Water Jar Tests

Jar tests were performed at varied temperatures, soda ash dosages and pH values to evaluate the potential for calcium carbonate to precipitate from the upstream Salt Kill water. The results of three jar tests are summarized in Table 4-1.

The results of Jar Test #1 show that, at room temperature (71°F) and variable increasing soda ash dosages at pH value above 10.0, an almost constant concentration of calcium hardness will precipitate from the Salt Kill water. This concentration is determined at 134 to 139 mg/L (as CaCO₃).

The results of Jar Test #2 show that at elevated temperature (comparable to the scrubber blowdown temperature at 110°F) the constant minimum dosage of soda ash (i.e., 588 mg/L Na₂CO₃) will generate increasing concentrations of calcium carbonate precipitate in the Salt Kill proportional to increase in pH value between 8.1 and 9.9. This variable range in pH value is the result of adjusting the equilibrium pH to lower values with hydrochloric acid solution.

The results of Jar Test #3 show that at elevated temperature and increasing pH value (i.e., from pH 8.2 to 10.1) increasing concentrations of calcium carbonate precipitated from the Salt Kill. All but about 5 mg/L of the calcium hardness can be precipitated from the Salt Kill as the result of only pH and temperature increases. No soda ash addition is required to precipitate the calcium hardness in the Salt Kill. Also, a modest increase in pH from 8.2 to 8.6 (without carbonate addition) results in 101 mg/L of CaCO₃ precipitated. However, raising the temperature alone, without adding soda ash or increasing the pH, results in only a slight amount of calcium carbonate precipitation.

The results of these three jar tests demonstrate that a filtered Salt Kill sample is naturally saturated with calcium carbonate hardness and that the total suspended solids precipitated by either soda ash addition, temperature increase and/or pH increase (i.e., by sodium hydroxide addition) is virtually 100 percent calcium carbonate precipitate.

4.4 Laboratory Comparison of NaOH vs. Na₂CO₃ for Acid Neutralization in Wet Scrubber

Bench neutralization titrations were performed on a laboratory prepared sample of 1.1 weight percent hydrochloric acid (HCl) solution. The 1.1% HCl solution is calculated to be at least as great as the maximum instantaneous acid concentration absorbed in the wet scrubber solution under average operating conditions. The results of the laboratory titrations comparing sodium hydroxide neutralization efficiency with soda ash neutralization efficiency are shown in Figure 4-1.

These results show clearly that in order to neutralize the HCl solution to a scrubber operating pH value of 9.0, about 12,000 mg/L of NaOH or about 19,200 mg/L of Na₂CO₃ are required. It is also shown that, on a dry weight basis, 60 percent more Na₂CO₃ is required than NaOH to perform the same degree of acid neutralization to pH 7.0.

The results also demonstrate that, where as no carbonate or bicarbonate alkalinity is added to the neutralized solution when using NaOH, use of Na₂CO₃ requires that an excess of about 2000 mg/L Na₂CO₃ are needed to raise the pH from 4.3 to 9.0. Below pH 4.3, essentially no bicarbonate or carbonate alkalinity is present as all the remaining carbonate added exists as carbonic acid. Therefore, about 17,200 mg/L of Na₂CO₃ were used in neutralizing the HCl and the additional 2000 mg/L Na₂CO₃ (i.e., 1880 mg/L as CaCO₃) are required to raise the pH from 4.3 to 9.0 in the neutralized acid solution. Since about 99% of all the acid was neutralized as the pH was raised to 4.3, the excess residual of 1880 mg/L carbonate alkalinity (as CaCO₃) is the minimum required excess existing in the scrubber blowdown at pH 9.0 when using soda ash. Even at acid concentrations of only 1% of the demonstrated 1.1% HCl case (i.e., 0.011% HCl) the required excess of Na₂CO₃ is still about 2000 mg/L Na₂CO₃ to maintain the equilibrium pH at 9.0.

**STUDY OF PRECIPITATE OBSERVED IN THE
SALT KILL CREEK AT MORLITE CORP., COHOES, NY**

TABLE 4-1

JAR TEST RESULTS

Upstream Salt Kill Sample Pre-Filtered - Calcium Hardness = 175 ppm CaCO₃

<u>DOSAGE</u>	<u>TREATMENT</u>		<u>RESULTS</u>	
	<u>pH</u>	<u>TSS (ppm)*</u>	<u>Ca pptd as CaCO₃ (ppm)**</u> (Prefilt.Ca-Postfilt.Ca-Pptd.Ca)	
Jar Test #1 - 71° Reaction Temp. w/Variable Soda Ash Dosage - Reagent Dilution Factor = 0.88 x 175 ppm CaCO ₃ = 154 ppm CaCO ₃				
588 ppm Na ₂ CO ₃ ***	10.21	127	154 - 20 = 134	
2350 ppm Na ₂ CO ₃	10.76	152	154 - 15 = 139	
5880 ppm Na ₂ CO ₃	10.96	159	154 - 16 = 138	
Jar Test #2 - 110°F Reaction Temp. w/Constant Soda Ash & Variable pH - Reagent Dilution Factor = 0.88 x 175 ppm CaCO ₃ = 154 ppm CaCO ₃				
588 ppm Na ₂ CO ₃ +HCl	8.14	107	154 - 52 = 102	
588 ppm Na ₂ CO ₃ +HCl	8.96	148	154 - 15 = 139	
588 ppm Na ₂ CO ₃ +HCl	9.88	157	154 - 5 = 149	
Jar Test #3 - 110°F Reaction Temp. w/Variable pH Only				
0.1 ppm NaOH	8.61	100	175 - 74 = 101	
5 ppm NaOH	10.13	170	175 - 5 = 170	
0	8.15	5	175 - 170 = 5	

NOTES:

- * Total Suspended Solids by gravimetric determination, accuracy = ± 3 ppm
- ** Calcium determination by ICP spectrophotometry, accuracy = ± 4.5%
- *** Typical soda ash purity = 99.2% Na₂CO₃

TITRATION OF 1.1% HCl SOLUTION WITH CAUSTIC SODA
VS SODA ASH SOLUTIONS AT 140 TO 150 °F




FIGURE 4-1

5. AQUEOUS STREAM SAMPLE ANALYSIS

5.1 Field Measurement Data

On a daily basis, during the sampling period, measurements of pH, temperature and settleable solids were made for each aqueous grab sample. Table 5-1 shows the results recorded for these sample measurements. For the purpose of using this grab sample data to represent average study period conditions in conjunction with the 5-day composite samples, the data values are averaged to obtain a 5-day average of the field data. Therefore, the 5-day averaged field data is used with the 5-day composite sample analysis to define average sample point conditions for calculating precipitation material balances in Section 7 of this report.

The results of these measurements for settleable solids indicate that the average value was 3.1 ml/L for this study period. This increase from the average value of 1.3 ml/L, measured during the 3-month period of July to September 1992, is attributed to an increase in the rate of dry lime feed, i.e., $\text{Ca}(\text{OH})_2$, to the baghouses instituted during October 1992. The increase in lime feed was made to improve the removal of HCl and SO_2 in the baghouses and therefore reduce the amount of soda ash feed required for the wet scrubber operation.

However, the increased rate of lime feed allows more lime fines to pass into the wet scrubber solution, therefore contributing calcium which precipitates (eventually) with the carbonate alkalinity of the scrubber solution to form calcium carbonate precipitate in the scrubber blowdown.

5.2 Analytical Laboratory Results for Composite Samples

The daily grab samples from each sample point were composited each day to generate a 5-day composite of each sample source. The analytical results for the aqueous samples from points A, B and D are shown in Table 5-2. The raw sample fractions are labelled A.1, B.1 and D.1, respectively. The corresponding supernatant liquids, after sedimentation in the "Imhoff" settling cone, are designated Samples A.2, B.2 and D.2.

The analysis of scrubber blowdown Samples A.1 and A.2 actually represent final chemical equilibrium conditions rather than conditions at time of blowdown discharge. Since the unpreserved composite samples had opportunity to continue reactions during the 5-day sample collection, in addition to several days elapsed time from sample shipment to laboratory analysis, the average concentration of total suspended solids at the time of sample collection is estimated to be about 2 times lower than the indicated value of 630 mg/L TSS. That is, considering the differences in total concentrations of preserved metals (such as Ca, Al and Fe) observed in Sample A-1 vs. A-2, only about one

half of the metal cations were in precipitated form at the time the grab samples were collected and settled in the Imhoff cone.

The presence of 630 mg/L TSS in the raw composite blowdown sample (A.1) is primarily the result of calcium contributed to the wet scrubber solution by passage of small amounts of lime through the baghouses. Because the lime is in dry particulate form as it contacts the hot wet scrubber solution it does not completely dissolve quickly and some remains suspended as a fine dispersion in the blowdown. Due to the alkaline pH of the scrubber solution (i.e., pH 9.4) the residual lime dissolves very slowly even though the dissolved fraction of calcium ions immediately form calcium carbonate precipitate. Therefore, at the time of grab sample collection and settleable solids testing, a minimum of 1-hour had elapsed before the supernatant sample was collected and preserved for metals analysis. Since 44 mg/L of calcium remained in the supernatant sample following this test, it is evident that portion of the total calcium concentration was not yet precipitated as CaCO_3 , but remained as dispersed Ca(OH)_2 . With compositing, plus shipping time, this lime eventually dissolved and was then precipitated as calcium carbonate.


Calculations show that the 90 mg/L of total calcium in the scrubber blowdown can be eventually precipitated as 457 mg/L of a hydrated form of calcium carbonate (i.e., $\text{CaCO}_3 \cdot 6\text{H}_2\text{O}$). (See Ref #3, pg B-79). Instead of forming the anhydrous crystalline calcite or aragonite (i.e., CaCO_3) as is typically formed in natural waters that are saturated with approximately equivalent concentrations of calcium hardness and carbonate alkalinity, the scrubber solution is saturated with a 15-fold excess of carbonate alkalinity (above the calcium hardness requirement). This causes a high percentage of the water associated with the calcium ions to be included in the crystals of calcium carbonate that are rapidly precipitated. This form of calcium carbonate is not the typical hard scale or dense particle, but a light voluminous precipitate. In addition to the six molecules of water precipitated with each molecule of calcium carbonate formed, significant percentages of dissolved salts (including NaCl , Na_2CO_3 , and Na_2SO_4) are also incorporated in the hydrated calcium carbonate precipitate.

The precipitation of calcium therefore, accounts for the majority of TSS in the blowdown sample. The following composition has been calculated for the 630 mg/L of TSS resulting in the scrubber blowdown:

<u>Compound Precipitated</u>	<u>Percent of TSS</u>
CaCO ₃ .6H ₂ O	72.5
Fe(OH) ₃	4.3
Al(OH) ₃	3.0
Mg(OH) ₂	1.0
Misc. inclusions;	19.2
o SiO ₂	
o H ₂ O	
o NaCl	
o Na ₂ CO ₃ .10H ₂ O	
o Na ₂ SO ₄ .10H ₂ O	

The analysis of the scrubber solution supernatant (i.e., A-2) also indicates that the TSS is comprised mostly of hydrated calcium carbonate with high percentages of entrained water and salts in the precipitate. The increase in dissolved solids in the supernatant has to be attributed to the absorption of CO₂ from the atmosphere as the scrubber water stands in the settling cone during the settleable solids test. As the liquid cools, CO₂ is absorbed from the air forming an increase in the bicarbonate concentration by 850 mg/L (as CaCO₃).

The following equation describes the ambient reaction taking place:



Absorption of atmospheric CO₂ plus a considerable degree of evaporation of hot water from the settling cone surface accounts for the increase in dissolved solids concentrations in the blowdown supernatant sample vs. the raw blowdown sample.

The individual analysis of total calcium and total magnesium (by ICP) in Table 5-2 should be considered more accurate than the total hardness concentrations reported since the total hardness is a titration to a change in color endpoint which is subject to the optical interferences of the TSS in the sample. However, in all three sample sources (A, B and D) there is reasonable agreement between the total hardness by titration and the combined calcium and magnesium concentrations (analyzed by ICP in the acid preserved samples) after converting to CaCO₃ equivalent concentrations.

The analysis of Sample B.1 shows that the upstream Salt Kill is near saturation with carbonate hardness in solution. The calcium hardness is 77 mg/L (as Ca) x 2.5 = 193 mg/L (as CaCO₃). Therefore, 89% of the hardness present in the upstream Salt Kill is carbonate hardness.

STUDY OF PRECIPITATE OBSERVED IN THE SALT KILL CREEK
AT NORLITE CORPORATION, COHOES, NEW YORK

TABLE 5-1

FIELD MEASUREMENT DATA FOR DAILY GRAB SAMPLES COLLECTED FOR 5-DAY COMPOSITE ANALYSIS

DATE	PARAMETER MEASURED	SAMPLE POINT A OUTFALL 005 DISCHARGE	SAMPLE POINT B UPSTREAM SALT KILL	SAMPLE POINT D DOWNSTREAM SALT KILL
Nov. 9, 1992	Time Hrs pH Temp °F Set.Solids ml/l	1435 9.09 102 0.3	1437 8.37 43 <0.1	1439 9.32 52 <0.1
Nov. 10, 1992	Time Hrs pH Temp °F Set.Solids ml/l	1510 9.44 102 4.0	1512 8.43 66 <0.1	1515 9.22 55 0.2
Nov. 11, 1992	Time Hrs pH Temp °F Set.Solids ml/l	1545 8.89 99 5.0	1547 8.44 52 <0.1	1549 9.09 52 <0.1
Nov. 12, 1992	Time Hrs pH Temp °F Set.Solids ml/l	1545 9.26 99 3.0	1547 8.43 55 <0.1	1555 9.39 54 <0.1
Nov. 13, 1992	Time Hrs pH Temp °F Set.Solids ml/l	1100 9.34 100 3.0	1102 8.42 55 <0.1	1106 9.28 54 <0.1
5-Day Average	Time Hrs pH Temp °F Set.Solids ml/l	1427 9.20 100 3.1	1429 8.42 54 <0.1	1433 9.26 53 <0.12

**STUDY OF PRECIPITATE OBSERVED IN THE SALT KILL CREEK
AT NORLITE CORPORATION, COHOES, NEW YORK**

TABLE 5-2

ANALYTICAL LABORATORY RESULTS FOR 5-DAY COMPOSITE AQUEOUS SAMPLES

	A-1	B-1	D-1
pH	9.4	8.5	8.8
TSS mg/l	630	19	77
TDS mg/l	12000	470	2500
T-Hardness mg/l as CaCO ₃	200	240	190
SO ₄	3300	71	740
HCO ₃ mg/l as CaCO ₃	3300	170	1100
CO ₃ mg/l as CaCO ₃	410	2	25
OH mg/l as CaCO ₃	<1	<1	<1
Al mg/l	6.6	0.72	1.1
Ca mg/l	90	77	47
Fe mg/l	14	1.3	1.6
Mg mg/l	10	20	15
Mn mg/l	0.37	0.044	0.061
	A-2	B-2	D-2
pH	9.4	7.7	8.5
TSS mg/l	730	<10	<10
TDS mg/l	17,000	450	2500
T-Hardness mg/l as CaCO ₃	160	250	180
SO ₄	4700	63	700
HCO ₃ mg/l as CaCO ₃	4000	170	480
CO ₃ mg/l as CaCO ₃	560	1.2	13
OH mg/l as CaCO ₃	<1	<1	<1
Al mg/l	2.6	0.73	0.88
Ca mg/l	44	67	40
Fe mg/l	4.8	1.1	1.5
Mg mg/l	6.6	16	14
Mn mg/l	0.11	0.046	0.052

In the downstream Salt Kill (i.e., Sample D.1) 100% of the calcium hardness is present as carbonate hardness. That is, the total carbonate alkalinity is in excess of the total calcium hardness (i.e., 118 mg/L as CaCO_3). This is attributed to the excess carbonate contributed by the discharge of blowdown which precipitates and settles about 30 ppm of calcium hardness (as CaCO_3) by the time the Salt Kill flow reaches downstream sample point D.

The analytical laboratory report shows the results of Samples D.1 and D.2 in reverse order from those shown in Table 5-2. This is concluded to be a sample switch or identification error since it is impossible for the total suspended solids in the raw sample to be less than its supernatant after settling, while at the same time the total alkalinity and total hardness also increase in the supernatant fraction after settling. Due to the temperature of the downstream sample (i.e., 53°F) evaporation would not be a significant factor in this case as is indicated by the constant total dissolved solids in the raw and supernatant fractions of the downstream sample.

However, besides the moderate differences in TSS and bicarbonate (HCO_3^-) alkalinity, there is no significant difference between the raw and supernatant fractions of the downstream Salt Kill (i.e., Samples D.1 and D.2). These modest differences, no matter if the results are reversed or not, do not affect the conclusions of this study in any way.

6. PRECIPITATE AND BOTTOM SEDIMENT ANALYSIS

General inorganic and metals analysis of total constituents in the aqueous stream samples are used to calculate the composition of the precipitates that will form using known solubility values at the measured temperature, pH and concentration conditions. Analysis of the dried solid residues of precipitation and the bottom sediments is an alternative means of determining the composition of the precipitate. Typically, x-ray diffraction (and similar methods) are useful for determining approximate percentages of various suspected compounds in the solid samples.

6.1 Source and Description of Solid Residues Analyzed

Sample C was generated and composited daily by combining of supernatants of grab samples collected from the blowdown source (Sample Point A) and upstream Salt Kill source (Sample Point B). These supernatant samples were blended together at the volume ratio of the average Salt Kill flow to the average blowdown flow (i.e., 7.3 to 1). Since only the supernatants (i.e., liquid after settleable solids are removed) of these samples were blended, it demonstrates that the resulting TSS in the blend is the result of a precipitation reaction between the blowdown and Salt Kill sources and not due to pre-existing settleable solids from either source.

Since the liquid-solids separations test of Sample C (i.e., Section 4) showed that the TSS of this blend was 101 mg/L, it demonstrates that dissolved constituents from the Salt Kill are reacting with the blowdown to form a precipitate (i.e., 101 mg/L as TSS) in the combined streams. It is also important to note that 101 mg/L is precisely the concentration of calcium carbonate precipitated from the "filtered" upstream Salt Kill sample after raising the pH and temperature of the sample without addition of any carbonate alkalinity or calcium hardness. These results are shown for Jar Test #3 in Table 4-1 of Section 4.

After filtering and drying the resulting fine precipitate from Sample C, the solid residue, designated Sample C.2, was submitted for identification and quantification of specific chemical compounds by X-ray diffraction techniques.

The bottom sediment samples from Sample Points E and F were separated from the liquid by U.S. Standard 100-mesh sieve and, then, laboratory vacuum filtration to separately collect the coarse and fine sediment fractions for X-ray diffraction analysis. Sample E, from the upstream Salt Kill Creek bed, contained no observable solids larger than 0.15 mm diameter. Therefore, only a fine fraction, designated Sample E.2, was submitted for X-ray diffraction analysis.

Unlike the upstream bottom sediment Sample E, the downstream bottom sediment Sample F contained a high percentage of solids larger than 0.15 mm diameter. Therefore, a coarse fraction designated Sample F.1 was collected from the 100-mesh sieve and dried at 104°C for X-ray diffraction analysis. The fine fraction was filtered on Whatman GF filter pad (0.0016 mm pore), dried at 104°C and designated Sample F.2 for X-ray diffraction analysis.

6.2 Results of X-Ray Diffraction Analysis

Samples C.2, E.2, F.1 and F.2 were submitted to Adirondack Environmental Services in Albany, New York for X-ray diffraction analysis to target eleven possible inorganic compounds as follows:

calcium carbonate	CaCO ₃
magnesium oxide	MgO
manganese dioxide	MnO ₂
aluminum oxide	Al ₂ O ₃
ferric oxide	Fe ₂ O ₃
calcium sulfite	CaSO ₃ .1/2 H ₂ O
calcium sulfate	CaSO ₄ .2H ₂ O
magnesium silicate	MgSiO ₃
manganese silicate	MnSiO ₃
iron orthosilicate	Fe ₂ SiO ₄
aluminum silicate	Al ₂ O ₃ .SiO ₂

Because of the limited quantities of most of the solid residue samples recovered, the composition could only be quantified for the major constituents, calcium carbonate and silicon dioxide. The following percentages of calcium carbonate and silicon dioxide were determined to be present in each of these samples by the Adirondack Environmental Laboratory:

<u>Sample</u>	<u>Description</u>	<u>Percent by wt.</u>	
		<u>CaCO₃</u>	<u>SiO₂</u>
C.2	Solids precipitated by blending A.2 and B.2	78.73	12.29
E.2	Solids sediment collected from upstream creek bed	7.83	58.32
F.1	Coarse solid sediment collected from downstream creek bed	52.14	26.25
F.2	Fine solid sediment collected from downstream creek bed	31.82	43.12

The high percentage of calcium carbonate (i.e., almost 80%) found in the precipitated solids (i.e., Sample C.2), resulting from blending of scrubber blowdown supernatant with upstream Salt Kill

supernatant, confirms the conclusion made from the aqueous sample analysis that the majority of precipitate observed in the Salt Kill downstream of Outfall 005 is calcium carbonate.

The lower percentage of calcium carbonate in the sediment of the upstream creek bed (i.e., 7.83%) indicates that there is not a high percentage of calcium hardness in the upstream creek water in a precipitated form. The remaining composition of the sediment in the upstream creek bed is assumed to be natural clay, mud and organic matter.

The increased concentrations of calcium carbonate analyzed in both the coarse and fine fractions of the downstream creek bed (i.e., F.1 and F.2) indicate that the rate of calcium carbonate precipitation and sedimentation is increased at the downstream Sample Point F as compared to the upstream Sample Point E.

7. PRECIPITATE FORMATION AND MATERIAL BALANCE CALCULATIONS

7.1 Average Blowdown, Salt Kill and Combined Stream Conditions During Sampling Period

7.1.1 Stream Flow Rates

7.1.1.1 Scrubber Blowdown Rate

The average combined blowdown rate for Kilns #1 and #2 APC system scrubbers = 60 gpm

$$\frac{60 \text{ gal}}{\text{min}} \times \frac{3.785 \text{ Liters}}{\text{gal}} = 227 \text{ L/min}$$

7.1.1.2 Calculation of Salt Kill and Combined Blowdown - Salt Kill Stream (i.e., Downstream) Flow Rate

The flow rates of the combined Salt Kill and blowdown flows, as well as the estimated Salt Kill flow itself, during the sampling period of this study can be calculated from the analyzed total dissolved solids concentrations in each stream as follows:

Sample A-2 - Blowdown total dissolved solids = $C_{BD} = 17,000 \text{ mg/L}$
- Blowdown total flow rate = $V_{BD} = 227 \text{ L/min}$

Sample B-2 - Upstream Salt Kill total dissolved solids = $C = 450 \text{ mg/L}$
- Upstream Salt Kill flow rate = V_{US}

Sample D-2 - Downstream total dissolved solids = $C_{DS} = 2500 \text{ mg/L}$
- Downstream flow rate = $V_{DS} = 227 \text{ L/min} + V_{US}$

$$\begin{aligned}(V_{BD})(C_{BD}) + (V_{US})(C_{US}) &= (V_{DS})(C_{DS}) \\ (227 \text{ L/min})(17,000 \text{ mg/L}) + (V_{US})(450 \text{ mg/L}) &= (V_{US} + 227 \text{ L/min})(2500 \text{ mg/L}) \\ 3,859,000 \text{ mg/min} + 450 V_{US} \text{ mg/min} &= 2500 V_{US} \text{ mg/min} + 567,500 \text{ mg/min} \\ 2050 V_{US} &= 3,291,500 \\ V_{US} &= 1606 \text{ L/min} = 424 \text{ gpm}\end{aligned}$$

$$V_{DS} = V_{US} + 227 \text{ L/min} = 1606 + 227 = 1833 \text{ L/min} = 484 \text{ gpm}$$

Therefore, stream volume ratio = Salt Kill : Blowdown = 7.1:1

7.2 Calculation of Calcium Carbonate Saturation Indices for Upstream Salt Kill and Downstream Salt Kill Sample Points

The precipitation of calcium carbonate from water is dependent upon the concentrations of calcium hardness and carbonate alkalinity (i.e., carbonate/bicarbonate concentrations) as well as certain other existing conditions of the water source in question, including;

- A. The total solids (primarily TDS) concentration
- B. Temperature of the water, at equilibrium conditions
- C. Calcium concentration
- D. Methyl Orange (i.e., Total) Alkalinity concentration
- E. Solution pH, at equilibrium conditions

References #1 (pg 223), #4 (pg 150) and #5 (pg 111) describe formula tables and equations that are used to calculate the pH at which a water in question will be saturated with calcium carbonate based on the other existing conditions listed above. This relationship (known as the Langelier Index for calcium carbonate saturation) is often used by chemists and engineers to determine if calcium carbonate scaling or precipitation will take place in piping systems, cooling towers and other equipment based on a given or predicted water quality.

The Langelier calcium carbonate saturation pH (or pHs) is determined by the following equation:

$$\text{pHs} = (9.3 + A + B) - (C + D) \text{ where;}$$

A = total solids concentration in ppm or mg/L

B = water temperature in °F

C = calcium concentration in ppm or mg/L as CaCO₃

D = methyl orange (total) alkalinity in ppm or mg/L as CaCO₃

The precipitation (or saturation) index is calculated by:

$$\text{Saturation Index} = \text{pH} - \text{pHs} \text{ where;}$$

pH = the measured or predicted pH of the water in question

pHs = the saturation pH as calculated above and, as a result;

- o if $\text{pH} - \text{pHs} = 0$, the water is considered to be in a stable (no potential to scale, precipitate or corrode) condition
- o If $\text{pH} - \text{pHs} = \text{greater than } 0$, the water has a potential to induce precipitation of calcium carbonate which increases relative to the magnitude of the positive $\text{pH} - \text{pHs}$ value.

- o If pH - pHS is less than 0, there is an increasing potential for the water to be corrosive which increases relative to the magnitude of the negative pH - pHS value.

7.2.1 Calcium Carbonate Precipitation Potential in Existing Upstream Salt Kill Water

<u>Existing Water Conditions</u>	<u>Formula Value from Langelier Index Tables</u>
A = Total solids concentration = 470 mg/L =	0.2
B = Temperature during sampling = 54°F =	2.3
C = Calcium hardness (as CaCO ₃) = 193 mg/L =	1.9
D = Total alkalinity (as CaCO ₃) = 172 mg/L =	2.2
and, average measured pH during sampling = 8.4	

$$pH_s = (9.3 + A + B) - (C + D)$$

$$pH_s = 9.3 + 0.2 + 2.3 - 1.9 - 2.2$$

pH_s = 7.7 = pH at which CaCO₃ is at the saturation concentration in upstream Salt Kill and so,

$$\text{Saturation Index} = \text{pH} - \text{pH}_s = 8.4 - 7.7 = +0.7$$

Therefore, the existing upstream Salt Kill flow has a positive potential (saturation index = +0.7) to precipitate CaCO₃ naturally without any influence from Norlite's outfall discharges. This fact is clearly demonstrated by the experimental results in Table 4-1 showing that 5 ppm as CaCO₃ are precipitated from a presettled sample (from upstream Salt Kill sample point B) just by increasing the temperature from 71°F to 110°F. Also, the analytical results shown in Tables 5-1 and 5-2 indicate that by raising the upstream Salt Kill sample temperature from 54°F to about 70°F and setting for 1-hour, 25 ppm of CaCO₃ are precipitated from the raw water sample. Raising the temperature of the water has the effect of approximately doubling the reaction rate for every 10°F rise in temperature (Ref #1, pg 442). The total of 30 ppm CaCO₃ precipitated represents the potential amount of hardness deposited as sediment between sample point B and the Salt Kill's confluence with the Hudson River without any influence from Norlite's outfalls or other downstream point source discharges. This amount of hardness deposition is also increased by introduction of even a slight amount of additional alkalinity due to stormwater runoff and other natural sources.

7.2.2 Calcium Carbonate Precipitation Potential in Existing Downstream Salt Kill Water

<u>Existing Water Conditions</u>	<u>Formula Value from Langelier Index Tables</u>
A = Total solids concentration = 2500 mg/L	= 0.2
B = Temperature during sampling = 53°F	= 2.3
C = Calcium hardness (as CaCO ₃) = 221 mg/L	= 1.9
D = Total alkalinity (as CaCO ₃) = 1125 mg/L	= 3.1 (est)
and, average measured pH during sampling = 9.26	

$$pH_s = (9.3+A+B) - (C+D)$$

$$pH_s = 9.3+0.2+2.3 - 1.9-3.1$$

$$pH_s = 6.8 = \text{pH at which CaCO}_3 \text{ is at the saturation concentration at downstream Salt Kill Sample Point D}$$

$$\text{Saturation Index} = \text{pH} - \text{pH}_s = 9.26-6.8 = +2.46$$

Therefore, the existing downstream Salt Kill flow has a positive potential to precipitate CaCO₃, that is 3.5 times the upstream saturation index.

7.3 Calculation of Theoretical and Experimental Calcium/Carbonate Mass Quantities Precipitated Downstream of Norlite Outfall 005

7.3.1 Calculation of Calcium Hardness at the Saturation Concentration at Downstream Salt Kill Sample Point D

<u>Existing Water Conditions</u>	<u>Formula Value from Langelier Index Tables</u>
A = Total solids concentration = 2500 mg/L	= 0.2
B = Temperature during sampling = 53°F	= 2.3
C = Calcium hardness (as CaCO ₃) at saturation =	C
D = Total alkalinity (as CaCO ₃) = 1125 mg/L	= 3.1 (est)

$$pH_s = (9.3+A+B) - (C+D)$$

$$7.1 = 9.3+0.2+2.3 - C-3.1$$

$$7.1 = 8.7-C$$

$$C = 8.7-7.1 = 1.6$$

Therefore, from Table C in Ref #5 (pg 111) Ca hardness at saturation at downstream sample point = 99 ppm as CaCO₃

7.3.2 Calculation of Theoretical Excess Calcium Hardness Above Saturation from Upstream Salt Kill at the Downstream Sample Point D

$$C_{US} - C_{DS}(\text{sat.}) = C_{US}(XS) \quad \text{where;}$$

C_{US} = calcium hardness as CaCO_3 in upstream Salt Kill

$C_{DS}(\text{sat.})$ = calcium hardness at saturation in downstream Salt Kill

$C_{US}(XS)$ = calcium hardness concentration of upstream Salt Kill in excess of downstream saturation concentration

$$193 \text{ mg/L Ca(as CaCO}_3\text{)} - 99 \text{ mg/L Ca(as CaCO}_3\text{)} = 94 \text{ mg/L excess CaCO}_3$$

7.3.3 Calculation of Excess Calcium Hardness Above Saturation from Scrubber Blowdown at Downtown Sample Point D

$$C_{BD} - C_{DS}(\text{sat.}) = C_{BD}(XS) \quad \text{where;}$$

C_{BD} = calcium hardness as CaCO_3 in blowdown stream

$C_{DS}(\text{sat.})$ = calcium hardness at saturation in downstream Salt Kill

$C_{BD}(XS)$ = calcium hardness concentration of blowdown stream in excess of downstream saturation concentration

$$225 \text{ mg/L Ca(as CaCO}_3\text{)} - 99 \text{ mg/L Ca(as CaCO}_3\text{)} = 126 \text{ mg/L excess CaCO}_3$$

7.3.4 Relative Theoretical Quantities of Calcium Carbonate Precipitated from Upper Salt Kill and Blowdown Streams

Although the concentration of calcium carbonate precipitate originating in the blowdown is somewhat higher than the concentration originating in the upstream Salt Kill, the flow of the Salt Kill is 7.1 times greater than the blowdown flow rate. This means that the theoretical quantity of calcium carbonate precipitated in the Salt Kill originating in the scrubber blowdown is only 16 percent of the total calcium carbonate precipitated in the downstream Salt Kill. The remaining 84 percent CaCO_3 precipitated originates from the upstream Salt Kill itself.

7.3.5 Calculation of Experimental CaCO_3 Concentration Precipitated from Upper Salt Kill After Mixing with the Scrubber Blowdown Flow

Table 5-1 shows, from the analysis of the upstream Salt Kill raw sample (i.e., Sample B-1), that calcium hardness = 77 mg/L (as Ca). It is also shown that the residual calcium hardness (at equilibrium) remaining in solution after discharge of the scrubber blowdown stream (i.e., Sample D-2) = 40 mg/L (as Ca).

Therefore, the concentration of calcium hardness (as CaCO₃) actually precipitated from the upper Salt Kill can be calculated as follows:

$$C_{US} - C_{CS} = C_{PPT} \text{ where;}$$

C_{US} = Upstream Salt Kill Ca hardness = 77 mg/L x 2.5 = 192.5 mg/L (as CaCO₃)
 C_{DS} = Downstream Salt Kill Ca hardness = 40 mg/L x 2.5 = 100 mg/L (as CaCO₃)
 C_{PPT} = Calcium hardness precipitated from upstream Salt Kill (as mg/L CaCO₃)
therefore;

$$192.5 \text{ mg/L CaCO}_3 - 100 \text{ mg/L CaCO}_3 = 92.5 \text{ mg/L CaCO}_3 \text{ precipitated}$$

Note; The 92.5 mg/L CaCO₃ actually precipitated from upstream Salt Kill as demonstrated by these sample analyses is in very close agreement with the theoretical excess of calcium hardness calculated in 7.3.2. That is,

$$\frac{92.5 \text{ mg/L CaCO}_3}{94 \text{ mg/L CaCO}_3} = 0.984 \text{ or at } 98.4\% \text{ agreement}$$

7.3.6 Calculation of Experimental CaCO₃ Concentration Precipitated from Scrubber Blowdown After Mixing with the Upstream Salt Kill Flow

Table 5-1 shows that, from the analysis of the scrubber blowdown (i.e., Sample A-1), the calcium hardness = 90 mg/L (as Ca). Again, considering that the residual calcium hardness (at equilibrium) remaining in solution after mixing with the upstream Salt Kill (i.e., Sample D-2) = 40 mg/L (as Ca), the concentration of calcium hardness (as CaCO₃) actually precipitated from the scrubber blowdown can be calculated as follows:

$$C_{BD} - C_{DS} = C_{PPT} \text{ where;}$$

C_{BD} = Blowdown calcium hardness = 90 mg/L x 2.5 = 225 mg/L (as CaCO₃)
 C_{DS} = Downstream Salt Kill calcium hardness = 40 mg/L x 2.5 = 100 mg/L (as CaCO₃)
 C_{PPT} = Calcium hardness precipitated from blowdown (as mg/L CaCO₃)
therefore;

$$225 \text{ mg/L CaCO}_3 - 100 \text{ mg/L CaCO}_3 = 125 \text{ mg/L CaCO}_3 \text{ precipitated}$$

Again, there is very close agreement between the demonstrated experimental concentration of calcium hardness precipitated from the scrubber blowdown and the theoretical excess calcium hardness concentration calculated for the scrubber blowdown. That is;

$$\frac{125 \text{ mg/L CaCO}_3}{126 \text{ mg/L CaCO}_3} = 0.992 \text{ or at } 99.2\% \text{ agreement}$$

Because of this very close agreement with demonstrated experimental results, the theoretical CaCO₃ saturation index formula (as cited above in 7.2 and references #1,4 and 5) can be used with confidence to predict what the effect will be of changing any given scrubber blowdown condition on precipitation of CaCO₃ in the downstream Salt Kill.

8. OPTIONS CONSIDERED FOR CONTROL OF PRECIPITATION IN SALT KILL

An observation of the relationship between parameters used to calculate the Langelier Saturation Index shows the three most significant parameters causing calcium carbonate to precipitate in any given aqueous stream are as follows:

- o The stream pH at equilibrium compared to the CaCO_3 saturation pH of the stream (i.e., the Saturation Index value)
- o The total alkalinity concentration of the stream
- o The total calcium hardness concentration of the stream

If any one of these parameters is maintained at (or controlled at) a non-significant value, CaCO_3 precipitation cannot occur.

If all three of these parameters are simultaneously present at significant levels, then the Saturation Index value (i.e., pH-pHs) is the most critical parameter to control. The total alkalinity concentration is the second most critical control parameter followed by the actual dissolved calcium (i.e., hardness) concentration.

8.1 Calculation of Blowdown pH Required to Control Downstream Saturation Index at Zero

In order to control the Saturation Index at 0 in the downstream Salt Kill, the existing downstream Salt Kill pH must be reduced to 7.1. That is, for the existing downstream pHs = 7.1:

$$\begin{aligned} \text{pH} - \text{pH}_s &= 0 \\ \text{pH} - 7.1 &= 0 \\ \text{pH} &= 7.1 \end{aligned}$$

For the given upstream and downstream Salt Kill conditions, calculate the blowdown pH value required if total blowdown flow = 60 gpm:
where;

$$\begin{aligned} V_{US} &= \text{Upstream Average Flow Volume} = 1606 \text{ liters/min} \\ \text{pH}_{US} &= \text{Upstream Average pH Value} = 8.4 \\ V_{DS} &= \text{Downstream Average Flow Volume} = 1833 \text{ liters/min} \\ \text{pH}_{DS} &= \text{Downstream Target pH Value} = 7.1 \\ V_{BD} &= \text{Scrubber Blowdown Average Flow Volume} = 227 \text{ liters/min} \\ \text{pH}_{BD} &= \text{Scrubber Blowdown Required pH Value} = C_{BD} \frac{\text{moles H}^+}{\text{liter}} \end{aligned}$$

Since $\text{pH} = \text{Negative log of hydrogen ion concentration in } \frac{\text{moles}}{\text{liter}}$
 $= - \text{Log} [\text{H}^+]$

then;

$$\text{pH}_{\text{US}} = 8.4 = -(\text{Log } [\text{H}^+]_{\text{US}})$$

$$[\text{H}^+]_{\text{US}} = 10^{-8.4} = 4 \times 10^{-9} \frac{\text{moles H}^+}{\text{liter}}$$

$$C_{\text{US}} = 4 \times 10^{-9} \frac{\text{moles H}^+}{\text{liter}}$$

$$\text{pH}_{\text{DS}} = 7.1 = -(\text{Log } [\text{H}^+]_{\text{DS}})$$

$$C_{\text{DS}} = 10^{-7.1} = 7.9 \times 10^{-8} \frac{\text{moles H}^+}{\text{liter}}$$

$$\text{pH}_{\text{BD}} = -(\text{Log } [\text{H}^+]_{\text{BD}})$$

$$C_{\text{BD}} = 10^{-\text{pH}_{\text{BD}}} \frac{\text{moles H}^+}{\text{liter}}$$

$$(V_{\text{BD}})(C_{\text{BD}}) + (V_{\text{US}})(C_{\text{US}}) = (V_{\text{DS}})(C_{\text{DS}})$$
$$(227 \text{ L/min})(C_{\text{BD}}) + (1606 \text{ L/min})(4 \times 10^{-9} \text{ moles/L}) = (1833 \text{ L/min})(7.9 \times 10^{-8} \text{ moles/L})$$

$$227 \text{ L/min } (C_{\text{BD}} \text{ moles/L}) + 6.42 \times 10^{-6} \text{ moles/min} = 1.45 \times 10^{-4} \text{ moles/min}$$

$$C_{\text{BD}} \text{ moles/L} = 4.39 \times 10^{-4} \text{ moles/min} \times 1 \text{ min}/227 \text{ L} = 6.12 \times 10^{-7} \text{ moles/L}$$

therefore;

$$\text{Blowdown pH} = -(\text{Log } 6.12 \times 10^{-7} \frac{\text{moles H}^+}{\text{L}}) = -(-6.21) = 6.21$$

Controlling the scrubber water pH value at 6.21 is not a feasible option since the scrubber pH value must be kept at a pH value of about 8.5 or higher to ensure adequate removal of acid gases from the kiln in the wet scrubber system.

In order to adjust the blowdown pH to 6.2, most of the excess bicarbonate and carbonate alkalinity in the blowdown would have to be neutralized with acid. This would require an average of 1950 lbs/day of 100% HCl or 551 gallons per day of 36% concentrated hydrochloric acid.

8.2 Calculation of Blowdown pH Required to Control Downstream Saturation Index at Upstream Value

In order to control the Saturation Index of the downstream at the same value as the upstream Salt Kill (i.e., 0.7) the pH value downstream must be lowered. Although this would not completely eliminate the potential for CaCO₃ to precipitate, the degree of precipitation that would occur would be equal to the existing potential (i.e., Saturation Index) of the upstream Salt Kill. That is, for the downstream Saturation Index = upstream Saturation Index;

$$\begin{aligned} \text{pH}_{\text{DS}} (\text{existing}) - 0.7 &= \text{pH}_{\text{DS}} (\text{target}) \\ \text{pH}_{\text{DS}} (\text{target}) &= 9.2 - 0.7 = 8.5 \end{aligned}$$

For the given upstream and downstream Salt Kill conditions, the blowdown pH value required to control the downstream pH at 8.5 can be calculated as in Section 8.5 above. However, to maintain the pH of the downstream at 8.5, (while the upstream pH = 8.4) it is self evident that the scrubber blowdown pH must also be at a maximum of 8.5 to ensure a combined stream pH greater than 8.5 will not occur.

On the other hand, to adjust the scrubber blowdown from the existing discharge pH of 9.2 to 8.5, a quantity of about 551 gallons per day of 36% HCl is again required. The same daily quantity of acid that would be required to reduce the blowdown pH from 9.2 to 6.2 is required to reduce the pH from 9.2 to 8.5 because essentially 100% of this acid is required to neutralize the existing average 3710 mg/L (as CaCO₃) of total carbonate-bicarbonate alkalinity in the blowdown.

After all this alkalinity is neutralized, only minimal amounts of acid are then required to reduce the pH values to 8.5 or 6.2 as these differences in hydrogen ion concentration are extremely small. The differences in the existing blowdown stream hydrogen ion concentration, i.e., [H⁺]_{BD} at 9.2 and the [H⁺]_{BD} at either target pH value of 8.5 or 6.2 is calculated as follows:

$$\begin{aligned} \text{pH } 9.2 &= - (\text{Log } [\text{H}^+]_{\text{BD}}) \text{ existing} \\ \text{existing } [\text{H}^+]_{\text{BD}} &= 10^{-9.2} = 6.31 \times 10^{-10} \frac{\text{moles H}^+}{\text{liter}} \end{aligned}$$

$$\begin{aligned} \text{pH } 8.5 &= - (\text{Log } [\text{H}^+]_{\text{BD}}) \text{ target} \\ \text{target } [\text{H}^+]_{\text{BD}} &= 10^{-8.5} = 3 \times 10^{-9} \frac{\text{moles H}^+}{\text{liter}} \end{aligned}$$

$$\begin{aligned} \text{pH } 6.2 &= - (\text{Log } [\text{H}^+]_{\text{BD}}) \text{ target} \\ \text{target } [\text{H}^+]_{\text{BD}} &= 10^{-6.2} = 6.31 \times 10^{-7} \frac{\text{moles H}^+}{\text{liter}} \end{aligned}$$

Acid requirements to establish either target pH from the existing pH 9.2, after neutralization of existing total alkalinity would be:

$$\text{pH } 9.2 \text{ to pH } 8.5 = 3 \times 10^{-9} \frac{\text{moles H}^+}{\text{L}} - 6.31 \times 10^{-10} \frac{\text{moles H}^+}{\text{L}}$$

$$\text{pH } 9.2 \text{ to pH } 8.5 = 2.4 \times 10^{-9} \frac{\text{moles H}^+}{\text{L}}$$

$$2.4 \times 10^{-9} \frac{\text{moles H}^+}{\text{L}} \times \frac{36.5 \text{ grams HCl}}{\text{mole H}^+} = 8.76 \times 10^{-8} \frac{\text{grams HCl}}{\text{L}}$$

$$8.76 \times 10^{-8} \frac{\text{grams HCl}}{\text{L}} \times \frac{227 \text{ L}}{\text{min}} \times \frac{1440 \text{ min}}{\text{day}} = 2.9 \times 10^{-2} \frac{\text{grams HCl}}{\text{day}}$$

$$2.9 \times 10^{-2} \frac{\text{grams HCl}}{\text{day}} \times \frac{100}{36} = 0.08 \frac{\text{grams 36\% HCl}}{\text{day}}$$

$$0.08 \frac{\text{grams 36\% HCl}}{\text{day}} \times \frac{1 \text{ lb}}{454 \text{ gr}} \times \frac{1 \text{ gal}}{9.83 \text{ lb}} = 0.000018 \frac{\text{gal 36\% HCl}}{\text{day}}$$

$$\text{pH } 9.2 \text{ to pH } 6.2 = 6.31 \times 10^{-7} \frac{\text{moles H}^+}{\text{L}} - 6.31 \times 10^{-10} \frac{\text{moles H}^+}{\text{L}}$$

$$\text{pH } 9.2 \text{ to pH } 6.2 = 6.30 \times 10^{-7} \frac{\text{moles H}^+}{\text{L}}$$

$$6.30 \times 10^{-7} \frac{\text{moles H}^+}{\text{L}} \times \frac{36.5 \text{ grams HCl}}{\text{mole H}^+} = 2.3 \times 10^{-5} \frac{\text{grams HCl}}{\text{L}}$$

$$2.3 \times 10^{-5} \frac{\text{grams HCl}}{\text{L}} \times \frac{227 \text{ L}}{\text{min}} \times \frac{1440 \text{ min}}{\text{day}} = 7.5 \frac{\text{grams HCl}}{\text{day}}$$

$$7.5 \frac{\text{grams HCl}}{\text{day}} \times \frac{100}{36} = 20.8 \frac{\text{grams 36\% HCl}}{\text{day}}$$

$$20.8 \frac{\text{grams 36\% HCl}}{\text{day}} \times \frac{1 \text{ lb}}{454 \text{ gr}} \times \frac{1 \text{ gal}}{9.83 \text{ lb}} = 0.005 \frac{\text{gal 36\% HCl}}{\text{day}}$$

Therefore, although about 280 times more HCl is required to reduce the unbuffered pH to 6.2 than to 8.5, these quantities are insignificant compared to the 551 gallons/day of 36% HCl required to neutralize the carbonate buffer in the existing blowdown.

8.3 Calculation of Blowdown Total Alkalinity Required to Control Downstream Saturation Index at Zero

<u>Anticipated Downstream Conditions</u>	<u>Formula Value from Langelier Index Tables</u>
A = Total solids concentration = 2500 mg/L	0.2
B = Temperature = 53°F	2.3
C = Calcium hardness (as CaCO ₃) = 221 mg/L	1.9
D = Total alkalinity (as CaCO ₃) = (to be calculated)	

Assume scrubber blowdown is controlled at pH = 9.0. Then, the theoretical (unbuffered) downstream pH is calculated as follows:

$$V_{US} = \text{Upstream average flow volume} = 1606 \text{ L/min}$$

$$pH_{US} = \text{Upstream average pH value} = 8.4 = 4 \times 10^{-9} \frac{\text{moles H}^+}{\text{L}}$$

$$V_{DS} = \text{Downstream average flow volume} = 1833 \text{ L/min}$$

$$pH_{DS} = \text{Downstream average pH value} = pH_{DS} = - (\text{Log } [H^+]_{DS})$$

V_{BD} = Scrubber blowdown average flow = 227 L/min
 pH_{BD} = Scrubber blowdown average pH value = 9.0 = 1×10^{-9} $\frac{\text{moles H}^+}{\text{L}}$

$$(V_{BD})(C_{BD}) + (V_{US})(C_{US}) = (V_{DS})(C_{DS})$$

$$(227 \text{ L/min})(1 \times 10^{-9} \frac{\text{moles H}^+}{\text{L}}) + (1606 \text{ L/min})(4 \times 10^{-9} \frac{\text{moles H}^+}{\text{L}}) = 1833 \text{ L/min}(C_{DS} \frac{\text{mole}}{\text{L}})$$

$$2.27 \times 10^{-7} \frac{\text{moles H}^+}{\text{min}} + 6.42 \times 10^{-6} \frac{\text{moles H}^+}{\text{L}} = 1833 \text{ L/min}(C_{DS} \frac{\text{moles}}{\text{L}})$$

$$6.65 \times 10^{-6} \frac{\text{moles H}^+}{\text{L}} = 1833 \text{ L/min}(C_{DS} \frac{\text{moles H}^+}{\text{L}})$$

$$C_{DS} \frac{\text{moles H}^+}{\text{L}} = 6.65 \times 10^{-6} \frac{\text{moles H}^+}{\text{min}} \times \frac{1 \text{ min}}{1833 \text{ L}}$$

$$C_{DS} \frac{\text{moles H}^+}{\text{L}} = 3.63 \times 10^{-9} \frac{\text{moles H}^+}{\text{L}}$$

$$pH_{DS} = -(\text{Log } 3.63 \times 10^{-9}) = -(-8.44) = 8.44$$

If Saturation Index = 0 and $pH_{DS} = 8.44$ then,

$$pH - pH_s = 0$$

$$8.44 - pH_s = 0$$

$$pH_s = 8.44 \text{ and,}$$

$$pH_s = (9.3 + A + B) - (C + D)$$

$$8.44 = 9.3 + 0.2 + 2.3 - 1.9 - D$$

$$8.44 = 9.9 - D$$

$$D = 9.9 - 8.44 = 1.46$$

From tables (Ref. 5 pg 111) the total alkalinity would = 29 mg/L (as CaCO_3) in downstream Salt Kill.

The relative calculated total alkalinity of the blowdown would be:

V_{BD} = Volume blowdown = 227 L/min
 C_{BD} = Total Alkalinity of blowdown = C_{BD}
 V_{US} = Volume upstream Salt Kill = 1606 L/min
 C_{US} = Total Alkalinity of upstream = 172 mg/L (as CaCO_3)
 V_{DS} = Volume downstream Salt Kill = 1833 L/min
 C_{DS} = Target Alkalinity of downstream = 29 mg/L (as CaCO_3)

$$(V_{BD})(C_{BD}) + (V_{US})(C_{US}) = (V_{DS})(C_{DS})$$

$$227 \text{ L/min}(C_{BD} \text{ mg/L}) + (1606 \text{ L/min})(172 \text{ mg/L}) = (1833 \text{ L/min})(29 \text{ mg/L})$$

$$227 \text{ L/min}(C_{BD} \text{ mg/L}) + 276232 \text{ mg/min} = 53157 \text{ mg/min}$$

$$227 \text{ L/min}(C_{BD} \text{ mg/L}) = 53157 - 276232 \text{ mg/min}$$

$$C_{BD} = \frac{-223075}{227} = -983 \text{ mg/L (as } \text{CaCO}_3\text{)}$$

Since the total alkalinity of the blowdown cannot be negative at $pH = 8.5$ to 9.0 , control of blowdown alkalinity alone will not reduce the downstream Salt Kill Saturation Index to zero.

8.4 Calculation of Blowdown Total Alkalinity Required to Control Downstream Saturation Index at Upstream Value

<u>Anticipated Downstream Conditions</u>	<u>Formula Value from Langelier Index Tables</u>
A = Total solids concentration = 2500 mg/L	0.2
B = Temperature = 53°F	2.3
C = Calcium hardness (as CaCO ₃) = 221 mg/L	1.9
D = Total alkalinity (as CaCO ₃) = (to be calculated)	

Assume the scrubber blowdown is controlled at pH = 9.0. Then, the theoretical (unbuffered) downstream pH = 8.44. If the downstream Saturation Index = upstream Saturation Index then, downstream Saturation Index = 0.7.

$$\begin{aligned} \text{Since, Saturation Index} &= \text{pH} - \text{pHs} = 0.7 \\ \text{then, } 8.44 - \text{pHs} &= 0.7 \text{ and,} \\ \text{pHs} &= 7.74 \end{aligned}$$

$$\begin{aligned} \text{pHs} &= (9.3 + A + B) - (C + D) \\ 7.74 &= 9.3 + 0.2 + 2.3 - 1.9 - D \\ 7.74 &= 9.9 - D \\ D &= 9.9 - 7.74 = 2.16 \end{aligned}$$

From Langelier Tables (Ref 5, pg 111) total alkalinity should = 146 mg/L (as CaCO₃) in the downstream Salt Kill. Then, total alkalinity of the blowdown must be:

$$\begin{aligned} V_{BD} &= \text{Volume blowdown} = 227 \text{ L/min} \\ C_{BD} &= \text{Total alkalinity of blowdown (as CaCO}_3) = C_{BD} \\ V_{US} &= \text{Volume upstream Salt Kill} = 1606 \text{ L/min} \\ C_{US} &= \text{Total alkalinity of upstream (as CaCO}_3) = 172 \text{ mg/L} \\ V_{DS} &= \text{Volume downstream Salt Kill} = 1833 \text{ L/min} \\ C_{DS} &= \text{Target alkalinity of downstream} = 146 \text{ mg/L (as CaCO}_3) \end{aligned}$$

$$\begin{aligned} (V_{BD})(C_{BD}) + (V_{US})(C_{US}) &= (V_{DS})(C_{DS}) \\ 227 \text{ L/min} (C_{BD} \text{ mg/L}) + (1606 \text{ L/min})(172 \text{ mg/L}) &= (1833 \text{ L/min})(146 \text{ mg/L}) \\ 227 \text{ L/min} (C_{BD} \text{ mg/L}) + 276232 \text{ mg/min} &= 267618 \text{ mg/min} \\ 227 \text{ L/min} (C_{BD} \text{ mg/L}) &= 267618 - 276232 \text{ mg/min} \\ C_{BD} \text{ mg/L} &= -8614 \text{ mg/min} \times \frac{1 \text{ min}}{227 \text{ L}} \\ C_{BD} \text{ mg/L} &= -38 \text{ mg/L (as CaCO}_3) \end{aligned}$$

Therefore, in order to maintain the existing upstream Salt Kill Saturation Index "unchanged" at the downstream Salt Kill sample point, the total alkalinity of the scrubber blowdown would have to be approximately 0 mg/L (as CaCO₃).

Observation of the data and results from this study show that, during the study period, the average total alkalinity was 3710

mg/L (as CaCO₃). Since this total alkalinity concentration is the result of average "real time" blowdown pH value measured at 9.2, it is expected that more accurate control of pH, to remain in the range of 8.5 to 9.0, will reduce the blowdown total alkalinity concentration as follows:

Figure 4-1 shows that titrations of 1.1% HCl solution with soda ash (Na₂CO₃) solution requires 19,200 mg/L (as Na₂CO₃) to reach pH 9.0 and 18,900 mg/L (as Na₂CO₃) to reach pH 8.5. To reach pH 4.0, the required Na₂CO₃ dosage is 17,400 mg/L (as Na₂CO₃). Below pH 4.0, it is expected that all but a solubility limited amount of alkalinity introduced into the acid stream is lost to the atmosphere by generation and evolution of carbon dioxide gas (i.e., CO₂). CO₂ has limited solubility in the scrubber water solution (i.e., about 576 mg/L at 140°F) as described in Ref. #5 pg 18 and Ref. # 2 pg 130.

From this titration data, the excess concentration of combined carbonate and bicarbonate alkalinity can be calculated as follows;

Excess total alkalinity in solution in raising pH from 4.0 to 9.0 =
19,200 mg/L (as Na₂CO₃)-17,400 mg/L (as Na₂CO₃)=1800 mg/L (as Na₂CO₃)
1800 mg/L (as Na₂CO₃)x0.94=1692 mg/L (as CaCO₃)
1692 mg/L (as CaCO₃)+ residual CO₂ at 657 mg/L (as CaCO₃)=2349 mg/L
(as CaCO₃)


Excess total alkalinity in solution in raising pH from 4.0 to 8.5 =
18,800 mg/L (as Na₂CO₃)-17,400 mg/L (as Na₂CO₃)=1400 mg/L (as Na₂CO₃)
1400 mg/L (as Na₂CO₃)x0.94=1316 mg/L (as CaCO₃)
1316 mg/L (as CaCO₃)+ residual CO₂ at 657 mg/L (as CaCO₃)=1973 mg/L
(as CaCO₃)

Even with precise control of the scrubber blowdown pH within the range of 8.5 to 9.0, the total alkalinity concentration in the blowdown will range from 2000 mg/L (as CaCO₃) to 2400 mg/L (as CaCO₃) which is in excess of the zero alkalinity concentration required to maintain the existing upstream Saturation Index of 0.7. Performing the required calculations shows that, at the 2400 mg/L (as CaCO₃) blowdown alkalinity, the resultant downstream Salt Kill Saturation Index will be 1.6. This is significantly lower than the +2.46 Saturation Index value measured during this study (i.e, it is about 65% of the present downstream Saturation Index).

8.5 Calculation of Downstream Saturation Index Resulting from Replacement of Soda Ash with Sodium Hydroxide for Scrubber Water pH Control


As indicated above, use of soda ash (Na₂CO₃) for pH control in the wet scrubber leaves an excess of carbonate and bicarbonate alkalinity in the blowdown (at pH value between 8.5 and 9.0) due

to the necessary formation of bicarbonate ion (HCO_3^-) from neutralization of acid (H^+) as represented by the following equation:



Thus, in neutralizing 1 mg/L of HCl, 2.9 mg/L of Na_2CO_3 are required, generating 3.9 mg/L of total dissolved solids (TDS). The relative concentration of bicarbonate ion remaining in solution is, therefore, dependent upon the concentration of acid being neutralized while maintaining the pH over 8.5 in the scrubber water. Between pH values 4.0 and 8.5, some of the bicarbonate ion generated is lost due to evolution of CO_2 . Below pH 4.0, all bicarbonate concentration is lost but some alkalinity will remain in solution due to the solubility of CO_2 in water as carbonic acid (H_2CO_3). This residual CO_2 concentration (in form of H_2CO_3) will form bicarbonate ion (HCO_3^-) as the pH is raised above 4.0. The portion of CO_2 converted to bicarbonate ion is proportional to the increase in pH value between pH 4.0 and 8.5 (see the graphical relationship in Ref #2. pg 130).

If relatively pure sodium hydroxide (i.e. NaOH) solution is used instead of soda ash, the source of carbonate and bicarbonate addition to the scrubber solution caused by acid neutralization would be eliminated. The following equation represents this reaction;



Thus, in neutralizing 1 mg/L of HCl, 1.1 mg/L of NaOH is required in generating only 1.6 mg/L of TDS. So, besides the elimination of the addition of carbonate-bicarbonate alkalinity when using sodium hydroxide, only 41% of the TDS would be generated in the neutralization reaction.

Reducing the TDS generated in the blowdown will have little if any effect on increasing the downstream Saturation Index, but eliminating the addition of the carbonate-bicarbonate alkalinity to the blowdown shows a marked reduction in the value of the downstream Saturation Index.

However, although essentially no total alkalinity is added by adjusting the pH with sodium hydroxide, some total alkalinity will be present from the carbon dioxide gas (CO_2) which is absorbed by the wet scrubber solution from the kiln off-gas stream. At a scrubber recirculation solution temperature of 140°F (i.e., 60°C) the anticipated absorbed CO_2 concentration in the blowdown stream would be 576 mg/L (as CO_2) x 1.14 = 657 mg/L (as CaCO_3).

Therefore, the calculated downstream total alkalinity would be:

V_{BD} = Volume blowdown = 227 L/min
 C_{BD} = Total alkalinity of blowdown = 657 mg/L (as $CaCO_3$)
 V_{US} = Volume upstream Salt Kill = 1606 L/min
 C_{US} = Total alkalinity upstream = 172 mg/L (as $CaCO_3$)
 V_{DS} = Volume downstream Salt Kill = 1833 L/min
 C_{DS} = Resultant alkalinity downstream = to be calculated

$$(V_{BD})(C_{BD}) + (V_{US})(C_{US}) = (V_{DS})(C_{DS})$$

$$227 \text{ L/min} (657 \text{ mg/L}) + (1606 \text{ L/min})(172 \text{ mg/L}) = (1833 \text{ L/min})(C_{DS} \text{ mg/L})$$

$$149,139 \text{ mg/min} + 276,232 \text{ mg/min} = 1833 \text{ L/min} (C_{DS} \text{ mg/L})$$

$$C_{DS} \text{ mg/L} = 425,371 \text{ mg/min} \times \frac{1 \text{ min}}{1833 \text{ L}}$$

$$C_{DS} \text{ mg/L} = 232 \text{ mg/L (as } CaCO_3)$$

Anticipated Downstream Conditions

Formula Value from Langelier Index Tables

A = Total solids concentration = 1225 mg/L	0.2
B = Temperature = 53°F	2.3
C = Calcium hardness (as $CaCO_3$) = 221 mg/L	1.9
D = Total alkalinity (as $CaCO_3$) = 232 mg/L	2.4

$$pH_{DS} = 8.44 \text{ at blowdown pH} = 9.0$$

$$pH_s = (9.3 + A + B) - (C + D)$$

$$pH_s = 9.3 + 0.2 + 2.3 - 1.9 - 2.4$$

$$pH_s = 7.5$$

$$\text{Saturation Index} = pH - pH_s$$

$$= 8.44 - 7.5$$

$$= 0.94$$

Therefore, the resultant Saturation Index would be only 34% higher than the existing value of the upstream Salt Kill (i.e., 0.7).

8.6 Calculation of Downstream Saturation Index Resulting from Replacement of Soda Ash with Sodium Hydroxide and Pretreatment of the Blowdown for TSS Removal Before Discharge

As indicated in Section 8.5, replacement of the soda ash used for pH control of the wet scrubber solution with sodium hydroxide will reduce the total alkalinity of the blowdown from 3710 mg/L (as $CaCO_3$) to 657 mg/L (as $CaCO_3$). This, along with controlling the pH of the blowdown at 8.5 to 9.0 would have the effect of lowering the downstream Salt Kill Saturation Index to a value of 0.94.

Pretreatment of the blowdown stream for TSS removal would further reduce the downstream Saturation Index due to removal of existing blowdown calcium hardness. The expected total alkalinity of the blowdown would be about 550 mg/L (as CaCO₃) due to CO₂ absorption and neutralization, if soda ash is not used in the wet scrubber pH control process. The expected residual calcium hardness discharged in the effluent would be expected to be about 15 mg/L (as CaCO₃). This expected calcium hardness concentration is confirmed by the observed results of Jar Test #2, shown in Table 4-1.

Under these anticipated blowdown conditions, the downstream Saturation Index is calculated as follows:

Downstream calcium hardness (as CaCO₃) = ;

V_{BD} = Volume blowdown = 227 L/min
 C_{BD} = Blowdown calcium hardness = 15 mg/L (as CaCO₃)
 V_{US} = Upstream volume = 1606 L/min
 C_{US} = Upstream calcium hardness = 193 mg/L (as CaCO₃)
 V_{DS} = Downstream volume = 1833 L/min
 C_{DS} = Downstream calcium hardness = to be calculated

$$(V_{BD})(C_{BD}) + (V_{US})(C_{US}) = (V_{DS})(C_{DS})$$

$$227 \text{ L/min} (15 \text{ mg/L}) + (1606 \text{ L/min})(193 \text{ mg/L}) = (1833 \text{ L/min})(C_{DS} \text{ mg/L})$$

$$3405 \text{ mg/min} + 309958 \text{ mg/min} = 1833 \text{ L/min} (C_{DS} \text{ mg/L})$$

$$C_{DS} \text{ mg/L} = \frac{313,363 \text{ mg/min} \times 1 \text{ min}}{1833 \text{ L}} = 171 \text{ mg/L (as CaCO}_3)$$

Downstream total alkalinity (as CaCO₃) = ;

V_{BD} = Blowdown volume = 227 L/min
 C_{BD} = Blowdown total alkalinity = 325 mg/L (as CaCO₃)
 V_{US} = Upstream volume = 1606 L/min
 C_{US} = Upstream total alkalinity = 172 mg/L (as CaCO₃)
 V_{DS} = Downstream volume = 1833 L/min
 C_{DS} = Downstream total alkalinity = to be calculated

$$(V_{BD})(C_{BD}) + (V_{US})(C_{US}) = (V_{DS})(C_{DS})$$

$$(227 \text{ L/min})(325 \text{ mg/L}) + (1606 \text{ L/min})(172 \text{ mg/L}) = (1833 \text{ L/min})(C_{DS} \text{ mg/L})$$

$$73,775 \text{ mg/min} + 276,232 \text{ mg/min} = 1833 \text{ L/min} (C_{DS} \text{ mg/L})$$

$$C_{DS} \text{ mg/L} = \frac{350,007 \text{ mg/min} \times 1 \text{ min}}{1833 \text{ L}} = 191 \text{ mg/L (as CaCO}_3)$$

Anticipated Downstream Conditions

Formula Value from Langelier Index Tables

A = Total solids concentration = 1225 mg/L	0.2
B = Temperature = 53°F	2.3
C = Calcium hardness (as CaCO ₃) = 171 mg/L	1.8
D = Total alkalinity (as CaCO ₃) = 191 mg/L	2.3

pH_{DS} = 8.44 at blowdown pH = 9.0

pH_s = (9.3+A+B)-(C+D)
pH_s = 9.3+0.2+2.3-1.8-2.3
pH_s = 7.7

Saturation Index = pH - pH_s
= 8.44 - 7.7 = 0.74

Therefore, the resultant Saturation Index would be only 5.7% higher than the existing value of the upstream Salt Kill. This is not expected to cause a noticeable or measurable difference in the concentration of calcium hardness precipitating at the downstream sampling points in comparison with the upstream sampling points.

8.7 Calculation of Downstream Saturation Index Resulting from Pretreatment for TSS Removal without Replacing Soda Ash used in Wet Scrubber

If soda ash is used to adjust pH in the wet scrubber system in combination with TSS removal, most of the existing calcium hardness would be removed, and most of the existing alkalinity would remain in the treated effluent. In other words, the existing total alkalinity in the blowdown would be reduced by the value of the existing blowdown calcium hardness (i.e., about 210 mg/L as insoluble CaCO₃), leaving about 3500 mg/L (as CaCO₃) total alkalinity remaining. The anticipated blowdown and Salt Kill conditions would be calculated as follows:

- V_{BD} = Blowdown volume = 227 L/min
- C_{BD} = Blowdown alkalinity = 3500 mg/L (as CaCO₃)
- V_{US} = Upstream volume = 1606 L/min
- C_{US} = Upstream alkalinity = 172 mg/L (as CaCO₃)
- V_{DS} = Downstream volume = 1833 L/min
- C_{DS} = Downstream alkalinity = to be calculated

(V_{BD})(C_{BD})+(V_{US})(C_{US}) = (V_{DS})(C_{DS})
(227 L/min)(3500 mg/L)+(1606 L/min)(172 mg/L)=(1833 L/min)(C_{DS} mg/L)
794,500 mg/min + 276,232 mg/min = 1833 L/min (C_{DS} mg/L)
C_{DS} mg/L = 1,070,732 mg/min x $\frac{1 \text{ min}}{1833 \text{ L}}$ = 584 mg/L (as CaCO₃)

Therefore;

Anticipated Downstream Conditions

**Formula Value from
Langelier Index Tables**

A = Total solids concentration = 1700 mg/L	0.2
B = Temperature = 53°F	2.3
C = Calcium hardness (as CaCO ₃) = 171 mg/L	1.8
D = Total alkalinity (as CaCO ₃) = 584 mg/L	2.8

$$pH_{Ds} = 8.9 \text{ at blowdown pH} = 9.0$$

$$\begin{aligned} pH_s &= (9.3+A+B)-(C+D) \\ pH_s &= 9.3+0.2+2.3-1.8-2.8 \\ pH_s &= 7.2 \end{aligned}$$

$$\begin{aligned} \text{Saturation Index} &= pH - pH_s \\ &= 8.9 - 7.2 \end{aligned}$$

$$\text{Saturation Index} = 1.7$$

Therefore, pretreatment for total suspended solids removal will not significantly reduce the existing downstream Saturation Index unless the blowdown pH is also reduced to less than pH 9.0. However, it is more effective to replace the use of soda ash in the wet scrubber system with sodium hydroxide since even without pretreatment for total suspended solids removal, soda ash replacement with sodium hydroxide will reduce the Saturation Index to 0.94.

9. CONCLUSIONS

9.1 The Salt Kill water, upstream of the Norlite facility scrubber blowdown outfalls, is very close to the limit of saturation possible for calcium carbonate concentration. This degree of saturation is indicated by the average carbonate hardness concentration and pH value analyzed during this study.

The relatively low temperature measured for the Salt Kill (i.e., $<56^{\circ}\text{F}$) is the major condition keeping the natural hardness from precipitating in the Salt Kill upstream of the Norlite scrubber blowdown outfalls.

9.2 The primary cause for precipitation of suspended solids in the Salt Kill downstream of the Norlite scrubber blowdown outfall location, is the increase in measured stream pH value (during this study) from about 8.4 to 9.2. This causes calcium carbonate to become less soluble and to precipitate in the downstream Salt Kill.

9.3 The secondary cause contributing to the precipitation of suspended solids in the Salt Kill downstream of the Norlite scrubber blowdown outfall is the concentration of calcium carbonate hardness in the scrubber blowdown. About 84 percent of the calcium carbonate precipitated during this study was observed to be from the Salt Kill water source itself and the remaining 16 percent of calcium carbonate precipitated was due to the scrubber blowdown carbonate hardness concentration .

9.4 The characteristics of the scrubber wastewater itself, which cause "settleable solids" to occur in the blowdown samples, is attributed to a slow reaction between excess carbonate alkalinity and residual lime (calcium hydroxide) fines from the baghouses. Even though the scrubber blowdown is relatively clear and low in settleable solids at the time of discharge, residual lime in suspension slowly dissolves due to solution cooling and absorption of CO_2 from the atmosphere during the settling test. These conditions cause the blowdown solution to become saturated with calcium carbonate upon standing and increased concentrations of settleable solids then form.

9.5 Under natural conditions, the concentration of calcium carbonate hardness in the upstream Salt Kill is high enough for calcium carbonate precipitation to be taking place. This is especially more feasible in summer months when sunlight warms the creek bed rocks and substrata in slower moving pools of water. As the cool creek water runs over these warmed solid surfaces, the stoichiometric balance of calcium and carbonate in the stream causes calcium carbonate (CaCO_3) to uniformly "scale-out" on these solid surfaces (as hard crystalline layers) without visible silting or precipitation taking place.

However, under the influence of excess carbonate alkalinity introduced from the scrubber blowdown, a more voluminous hydrated precipitate form of calcium carbonate (i.e., $\text{CaCO}_3 \cdot 6\text{H}_2\text{O}$) forms

which visibly settles to the bottom as a light to tan colored precipitate.

9.6 Combined analysis of the aqueous stream samples and the solid precipitate and sediment samples collected during this study confirm that about 80 percent by weight of the precipitate forming and settling at downstream Sample Points D and F is a form of calcium carbonate. The remaining 20 percent of the weight of the precipitate is attributed to mostly silica and silicates, hydrates and oxides of calcium, iron, aluminum and magnesium.

9.7 Material balance calculations using the aqueous sample analyses show that the Salt Kill flow conditions were in a typical range for this study. The reported average flow conditions for the Salt Kill drainage area are about 1-cubic foot of water per second. The material balance calculations show the upstream Salt Kill flow rate averaged about 0.94 cu ft/sec during this study period.

9.8 Adjusting the composition of the present scrubber blowdown in order to induce less increase in pH value of the downstream Salt Kill will have the greatest effect on reducing the amount of calcium carbonate precipitation in the Salt Kill.

9.9 Eliminating the excess carbonate and bicarbonate buffer concentration in the present scrubber blowdown discharges will enable both a minimal increase in Salt Kill pH value as well as a substantial reduction in carbonate hardness concentration. The minimum pH increase and reduced carbonate hardness in the resulting Salt Kill flow will significantly reduce the potential for calcium carbonate to precipitate.

It is calculated that the calcium carbonate Saturation Index of the downstream Salt Kill can be reduced from + 2.46 to + 0.94 (i.e., 2.6 times lower precipitation potential) by operating the scrubber at a blowdown discharge pH of 9.0 using sodium hydroxide (NaOH) instead of sodium carbonate (Na_2CO_3) as the alkali source for acid neutralization. This resulting Saturation Index of 0.94 is only 34% higher than the existing value of the upstream Salt Kill Saturation Index of + 0.7 which will give a relative reduction in downstream calcium carbonate precipitation.

9.10 Reducing the scrubber blowdown pH (by minimizing Na_2CO_3 dosage) could result in some significant improvement in reducing calcium carbonate precipitation in the Salt Kill. Since, with Na_2CO_3 , an excess carbonate alkalinity is required to maintain pH above 8.5 in the blowdown, the degree of improvement would depend on whether or not a significant increase in the pH value above 8.5 in the Salt Kill would still occur.

However, sodium carbonate usage can be significantly reduced (minimized) by changing the injection points into the wet

scrubber system from the recycle tank to a direct connection into the recycle pump suction lines. Less unused soda ash would be lost to the blowdown with this modified system.

Results of the December 1992 Trial Burn on Kiln #1 show that optimum SO_2 and HCl removal are obtained with a scrubber water pH value in the range of 7.9 to 8.3. Operating in this pH range will ensure the blowdown will not increase the pH of the Salt Kill while at the same time it will reduce the concentration of excess carbonate alkalinity in the downstream Salt Kill. Both of these effects would significantly decrease the concentration of calcium carbonate precipitation in the downstream Salt Kill.

9.11 Adjusting the pH of the scrubber recycle solution to 8.3 to 9.0 with sodium hydroxide (NaOH), and pretreatment for TSS removal is another approach to reducing the mass of calcium carbonate precipitation in the downstream Salt Kill to a value essentially equal to the natural upstream Salt Kill. That is, the Saturation Index of the downstream Salt Kill would be increased to only 0.74 from the upstream value of 0.70. This is not expected to be a difference that will result in any measurable increase in precipitated calcium carbonate from the upstream sample points to the downstream sample points.

Replacement of sodium carbonate with sodium hydroxide is expected to have an NaOH requirement that is about 30 percent less than Na_2CO_3 on a delivered dry weight basis.

10. RECOMMENDATIONS

Although several recommendations can be made as to measures that can be taken to improve or relieve the observed problem of calcium carbonate precipitation in the Salt Kill, there is a definite order of preference based on consideration of effectiveness, cost and dependability. The following recommendations are made in order of most preferable measures first:

10.1 Substituting sodium hydroxide solution (25% W/W NaOH) for sodium carbonate solution (5% W/W Na₂CO₃) as the alkali for neutralization of acid gases in the wet scrubber system is the most direct measure to control blowdown discharges from causing Salt Kill precipitation from the standpoint of effectiveness, cost and long range dependability.

Although this measure will require some initial costs for facility retrofitting including, installation of insulation and heat tracing of chemical holding tanks, transfer pump and lines and possible installation of a 20,000 to 25,000 gallon sodium hydroxide solution storage tank, the following benefits will be immediately gained;

10.1.1 No final effluent pH adjustment with acid would be required, with use of sodium hydroxide, even at a blowdown pH value of 9.0, since carbonate concentration increases in the Salt Kill would be eliminated.

10.1.2 The chemical operating cost for sodium hydroxide would be approximately equal to the present cost of using sodium carbonate without any additional controls for limiting downstream Salt Kill precipitation.

10.1.3 The resultant immediate effect of sodium hydroxide use will be a substantial improvement in suspended solids generated in the downstream Salt Kill due to discharge of the scrubber blowdowns. This is even without pretreatment for suspended solid removal. About a 75% reduction in existing downstream TSS is estimated.

10.1.4 The resultant long-term effect of sodium hydroxide use will be a restoration of the Salt Kill TSS precipitation to a condition essentially equivalent to the upstream Salt Kill TSS concentration. A 90% reduction in existing TSS is estimated with pretreatment for TSS removal. Note; It is not possible to achieve 100% reduction in Salt Kill TSS since the upstream flow already contains 10 to 20 ppm of natural TSS.

10.1.5 The resultant immediate and long-term effect of sodium hydroxide usage would be to reduce the relative total dissolved solids (TDS) loading to the Salt Kill by a factor of up to 50% or more.

10.2 Changing existing sodium carbonate solution injection points (from the recycle tanks) to the recycle pump suction lines, while also reducing the scrubber blowdown pH value to less than 9.0 (eg. pH 8.0 to 8.5) on a continuous basis, would minimize use of sodium carbonate feed to the wet scrubber systems. While this measure is expected to achieve at least 25 to 35% reduction in existing downstream Salt Kill TSS, it would also have the following immediate benefits;

10.2.1 The resulting downstream Salt Kill pH value would be reduced to a value less than 9.0.

10.2.2 No additional or new operating or capital costs would be incurred.

10.2.3 Immediate short-term improvement will be realized until the point at which the zero discharge option is implemented.

10.3 Norlite has proposed a zero discharge option to wastewater management, in which the scrubber blowdown is injected into the kiln. This option will eliminate the blowdown discharge to the Salt Kill creek. Norlite is scheduled to install this system by July 15, 1993.

11. **REFERENCES**

11.1 **Reference #1**

Nordell, Eskel. Water Treatment for Industrial and Other Uses, New York: Reinhold Publishing Corporation (1951)

11.2 **Reference #2**

Betz Handbook of Industrial Water Conditioning, Published by Betz, Trevose, PA: Sixth Ed. (1962)

11.3 **Reference #3**

Weast, Robert C. (Ed.) CRC Handbook of Chemistry and Physics, 69th ed., 1988-1989, CRC Press, Inc., Boca Raton, FL.

11.4 **Reference #4**

Corrosion Basics, an Introduction, Houston, TX: National Association of Corrosion Engineers (1984)

11.5 **Reference #5**

Data Book for Practicing Engineers, etc. Who Work With Water, Wastewater Treatment, Pollution Control and Water Reclamation, Compiled by the Permutit Company, Inc., Warren, NJ: Sixteenth Printing (1991)

12. **APPENDIX**

12.1 Reference Citations

12.2 AnalytiKEM Laboratory Report

12.3 Adirondack Environmental Laboratory Report

12.4 Laboratory Bench and Jar Test Data

APPENDIX A

12.1 Reference Citations

1. Nordell
2. Betz
3. CRC Handbook
4. NACE
5. Permutit

APPENDIX B

12.2 ANALYTIKEM LABORATORY REPORT

Supplemental, December 29, 1992

Original, December 4, 1992

APPENDIX C

12.3 Adirondack Environmental Laboratory Report

APPENDIX D

12.4 Laboratory Bench Test and Jar Test Data
TK Wastewater Treatment Laboratory, Rock Hill, SC

APPENDIX A

12.1 Reference Citations

1. Nordell
2. Betz
3. CRC Handbook
4. NACE
5. Permutit

WATER TREATMENT

FOR INDUSTRIAL AND OTHER USES

by

Eskel Nordell

*Administrator, Analytical Laboratories,
Research and Pilot Plant Divisions,
The Permutit Company*

*Formerly W. O. C. Consultant Water Treatment,
War Production Board, General Machinery
Section, General Industrial Equipment Branch,
General Manager, Water Softening Division,
The Wayne Company*

REINHOLD PUBLISHING CORPORATION
330 WEST FORTY-SECOND STREET
NEW YORK 18, U. S. A.
1951

Lange's "Handbook of Chemistry," Zimmerman and Lavine's "Conversion Factors and Tables," Hering's "Conversion Tables," and The Chemical Rubber Publishing Company's "Handbook of Chemistry and Physics."

I extend my thanks to The Permutit Company for permitting me to engage in this work and allowing me to use company photographs, drawings, and other material; to Henry W. Foulds, President, and Eric Pick for their kindly encouragement; to the Research, Pilot Plant, Analytical Laboratories, Engineering, and other divisions of The Permutit Company for their interest; to my family for their patience during my five years of labor; and to my daughter for typing the manuscript. Some twenty of the illustrations were made from photographs which I took in the field. Credit for these and most of the remaining illustrations is due The Permutit Company. In other cases, a proper courtesy line has been attached.

ESKEL NORDELL

Mount Holly, N.J.
January, 1951

CONTENTS

	PAGE
PREFACE	iii
CHAPTER	
1. INDUSTRIAL WATER SUPPLIES	1
<i>Municipal Water Supplies · Private Water Supplies · Sampling Precautions · Water Analyses: Methods of Expression · Standard Methods of Water Analysis · Analyses and Characteristics of Waters from Various Sources</i>	
2. DISSOLVED MINERAL MATTER	42
<i>Alkalinity: Bicarbonate, Carbonate, and Caustic · Hardness: Calcium and Magnesium · Sodium Salts · Silica · Iron · Manganese · Aluminum · Fluoride · Mineral Acidity</i>	
3. DISSOLVED GASES	80
<i>Carbon Dioxide · Oxygen and Nitrogen · Hydrogen Sulfide · Methane</i>	
4. TURBIDITY, SEDIMENT, COLOR, ORGANIC MATTER, TASTES, ODORS AND MICROORGANISMS	111
<i>Turbidity and Sediment · Color and Organic Matter · Tastes and Odors · Microorganisms</i>	
5. WATER REQUIREMENTS	139
<i>Selection of Process and Equipment · Users of Water-Treating Equipment</i>	
6. BOILER FEED WATERS	189
<i>Boiler Deposits · Boiler Feed-Water Treatments · External Treatment of Boiler Feed-Water Make-up · Treatment of Condensate Returns · Internal Treatment of Boiler Waters · Blowoff · Inter-crystalline Cracking of Boiler Metal · Corrosion Prevention · Cooling Water</i>	

COPYRIGHT 1951 BY
REINHOLD PUBLISHING CORPORATION

All rights reserved

Second Printing, 1951
Third Printing, 1956

46.62.
1.4.24.64.

Lithoprinted in U.S.A.
EDWARDS BROTHERS, INC.
Ann Arbor, Michigan

PREFACE

THIS BOOK was written to provide a comprehensive work on industrial waters that would be of practical value to executives, consultants, engineers, chemists, operating personnel and students, and that would eliminate tedious search through a mass of scattered literature. Every effort has been made to present the material as simply and clearly as possible, and although chemical reactions are included, a chemical training is not necessary in order to understand the basic principles involved.

The first four chapters are devoted chiefly to impurities in water supplies and how they can be eliminated or reduced to allowable tolerances. To illustrate the amounts of impurities in ground and surface waters and the possible variations in the latter, over one-thousand analyses were calculated to a uniform method of expression and concisely tabulated. Chapter 5 concerns the water requirements for industrial uses, and current water-treatment practices in various industries are discussed. Chapters 6 and 7 describe the problems and practices relating to boiler feed waters and cooling waters, respectively. The different processes and equipment used in treating (conditioning) water are covered in detail in Chapters 8 through 18. Duplication of descriptive matter in the text is eliminated, for the most part, by cross references to the chapters in which specific processes are described. The appendix section contains forty-three tables of conversion factors and equivalents and three curves which will be found useful in making calculations.

No attempt has been made to include lists of patents or complete bibliographies of publications on water-treating materials, processes or equipment. Instead, a selected list of publications is presented in the chapter bibliographies. For the reader who wishes to make a thorough search of the literature, the references in the publications listed are probably sufficient to start a chain reaction in that direction.

Solubilities have been largely taken from Seidell's "Solubilities of Inorganic and Metal Organic Compounds" and E. P. Partridge's "Formation and Properties of Boiler Scale," University of Michigan Engineering Research Bulletin No. 15. Handbooks which have been used include

CHAPTER	PAGE
7. COOLING WATERS	219
<i>Scale and Deposits in Cooling Systems · Cooling Water Specifications · Cooling Water Treatments</i>	
8. AERATION	233
<i>Removal of Gases · Removal of Iron and Manganese · Aerators</i>	
9. DEAERATION	249
<i>Removal of Oxygen, Nitrogen and Carbon Dioxide · Deaerators</i>	
10. CHEMICAL FEEDERS	260
<i>Chemical Feeders: Wet Type, Dry Type, Gases · Chemicals</i>	
11. SEDIMENTATION, COAGULATION, SETTLING, AND FILTRATION	284
<i>Sedimentation · Coagulation · Settling · Filtration · Clarification Processes</i>	
12. IRON- AND MANGANESE REMOVAL	317
<i>Ferrous Bicarbonate · Ferric Hydroxide · Ferrous Sulfate · Colloidal or Organic Iron · Manganous Bicarbonate · Manganous Sulfate · Colloidal or Organic Manganese</i>	
13. ZEOLITE (SODIUM CATION-EXCHANGER) WATER-SOFTENING PROCESS	339
<i>Principles of Operation · Zeolites (Sodium-Cation Exchangers) · Zeolite Water Softeners</i>	
14. HYDROGEN CATION-EXCHANGER PROCESSES	374
<i>Principles of Operation · Hydrogen Cation Exchangers</i>	
15. DEMINERALIZATION AND DISTILLATION	390
<i>Demineralization · Distillation · Uses of Demineralized and Distilled Waters</i>	
16. COLD LIME-SODA WATER-SOFTENING PROCESSES	406
<i>Principles of Operation · Types of Cold Lime-Soda Water Softeners · Results with the Various Cold Lime-Soda (or Chemical-Precipitation) Processes · Calculations of Chemical Dosages</i>	
17. HOT LIME-SODA WATER-SOFTENING PROCESS	442
<i>Chemical Feeders · Primary Heater, Vent Condenser, Deaerator · Settling Tanks · Filters · Chemicals: Reactions and Dosages · Hot Lime-Soda Water Softeners: Types and Designs · Hot Lime-Soda, Sodium Cation-Exchanger Process</i>	

CHAPTER	PAGE
18. SILICA REMOVAL	465
<i>Hot Lime-Soda-Magnesia Process · Cold Lime-Soda-Magnesia Process · Ferric Hydroxide Process · Highly Basic Anion-Exchanger Process · Fluosilicate Process · Distillation</i>	
APPENDIX SECTION	481
INDEX	515

TABLE 4. ANALYSES OF NINETY-EIGHT RIVER WATERS—ONE-YEAR AVERAGES

Name of River	Sampled at or near	(expressed as ppm of CaCO ₃)								(ppm) Fe	(ppm) SiO ₂
		Hardness	Ca	Mg	Na + K	HCO ₃	Cl	SO ₄	NO ₃		
✓ Alabama	Selma, Ala.	45	33	12	15	40	3	9	0.6	0.5	21
✓ Allegheny	Kittaning, Pa.	47	35	12	24	32	20	17	0.6	1.2	8
✓ Arkansas	Arkansas City, Kans.	336	238	98	529	207	412	201	1.5	1.6	31
✓ Big Blue	Manhattan, Kans.	225	168	57	96	212	29	46	1.9	3.0	34
✓ Brazos	Waco, Tex.	381	303	78	553	130	477	290	1.8	0.3	22
✓ Cache	Mounds, Ill.	73	48	25	33	70	10	19	1.7	2.5	22
✓ Cahaba	Birmingham, Ala.	43	33	10	20	43	3	9	0.5	0.4	16
✓ Cedar	Cedar Rapids, Ia.	186	120	66	26	171	5	31	2.5	0.1	14
✓ Chattahoochee	West Point, Ga.	15	12	3	17	18	3	5	0.6	0.5	20
✓ Chikaskia	Argonia, Kans.	209	160	49	82	228	21	35	0.9	1.3	28
✓ Chippewa	Eau Claire, Wisc.	52	33	19	18	40	2	14	0.5	0.2	12
✓ Cimarron	Englewood, Kans.	352	213	139	774	253	702	163	1.4	1.4	38
✓ Clackamas	Cazadero, Ore.	19	13	6	4	21	2	4	0.2	0.05	17
✓ Columbia	Cascade Locks, Wash.	57	40	17	15	55	3	13	0.4	0.04	13
✓ Columbia	Northport, Wash.	64	45	19	9	59	1	12	0.2	0.02	9
✓ Cottonwood	Emporia, Kans.	353	255	98	61	256	15	136	2.4	0.9	21
✓ Crooked	Prineville, Ore.	110	65	45	89	165	15	17	0.3	0.1	34
✓ Cumberland	Nashville, Tenn.	80	65	15	21	76	3	14	1.0	0.4	20
✓ Delaware	Lambertville, N.J.	44	30	14	12	38	4	12	0.9	0.07	9
✓ Deschutes	Moody, Ore.	32	21	11	27	47	3	5	0.5	0.05	28
✓ Des Moines	Keosauqua, Ia.	231	145	86	37	177	7	74	2.7	0.4	22
✓ Embarrass	Charleston, Ill.	226	128	98	29	204	7	32	6.1	0.3	17
✓ Fall	Neodesha, Kans.	222	165	57	65	199	18	30	1.5	0.6	28
✓ Flint	Albany, Ga.	28	22	6	15	26	4	6	0.5	0.9	24
✓ Fox	Ottawa, Ill.	281	150	131	31	225	11	63	4.0	0.2	11

TABLE 4. ANALYSES OF NINETY-EIGHT RIVER WATERS—ONE-YEAR AVERAGES (Continued)

Name of River	Sampled at or near	(expressed as ppm of CaCO ₃)								(ppm) Fe	(ppm) SiO ₂
		Hardness	Ca	Mg	Na + K	HCO ₃	Cl	SO ₄	NO ₃		
✓ Grand	Grand Rapids, Mich.	218	140	78	22	189	11	34	1.9	0.07	14
✓ Grande Ronde	Elgin, Ore.	31	25	6	20	44	2	6	0.6	0.25	30
✓ Hudson	Hudson, N.Y.	69	53	16	17	59	6	16	0.6	0.15	11
✓ Illinois	LaSalle, Ill.	215	125	90	35	166	18	52	9.0	0.2	12
✓ Iowa	Iowa City, Ia.	193	123	70	31	172	5	37	2.3	0.25	19
✓ James	Richmond, Va.	47	35	12	15	49	3	7	0.2	0.5	18
✓ Kalamazoo	Kalamazoo, Mich.	212	138	74	18	190	5	24	1.5	0.05	17
✓ Kankakee	Kankakee, Ill.	231	145	86	24	176	7	59	3.3	0.27	15
✓ Kansas	Holliday, Kans.	249	183	66	111	214	57	63	1.9	1.1	29
✓ Kaskaskia	Carlyle, Ill.	200	118	82	31	174	10	35	3.9	0.4	17
✓ Kentucky	Frankfort, Ky.	68	53	15	15	63	3	9	2.0	0.5	16
✓ Klickitat	Klickitat, Wash.	31	18	13	14	36	2	7	0.1	0.13	27
✓ Lehigh	So. Bethlehem, Pa.	59	35	24	16	33	7	31	1.8	0.1	9
✓ Marmaton	Fort Scott, Kans.	239	203	36	51	206	7	36	1.5	1.1	14
✓ Maumee	Toledo, O.	210	143	67	53	145	56	50	3.6	0.27	17
✓ Medicine Lodge	Kiowa, Kans.	589	408	181	228	185	138	473	2.7	1.6	27
✓ Miami	Dayton, O.	246	148	98	20	210	6	42	6.9	0.15	17
✓ Mississippi	Memphis, Tenn.	139	90	49	42	105	12	45	1.4	0.6	24
✓ Mississippi	Minneapolis, Minn.	157	100	57	22	155	2	19	1.1	0.07	15
✓ Missouri	Kansas City, Kans.	229	155	74	96	166	18	140	1.8	0.7	37
✓ Monongahela	Elizabeth, Pa.	39	30	9	16	15	5	34	1.5	0.5	8
✓ Muddy	Murphysboro, Ill.	112	63	49	44	59	18	75	1.6	2.1	24
✓ Muskingum	Zanesville, O.	147	108	39	51	96	56	45	1.3	0.18	14
✓ Okanogan	Okanogan, Wash.	72	53	19	19	67	1	16	0.2	0.02	14
✓ Oostannula	Rome, Ga.	41	30	11	20	44	3	4	0.3	0.7	24

TABLE 4. ANALYSES OF NINETY-EIGHT RIVER WATERS—ONE-YEAR AVERAGES (Continued)

Name of River	Sampled at or near	(expressed as ppm of CaCO ₃)								(ppm) Fe	(ppm) SiO ₂
		Hardness	Ca	Mg	Na + K	HCO ₃	Cl	SO ₄	NO ₃		
Osage	Boicourt, Kans.	217	168	49	61	182	14	37	2.8	2.2	24
✓ Oswegatchie	Ogdensburg, N.Y.	47	33	14	12	43	1	9	0.3	0.2	9
✓ Pearl	Jackson, Miss.	23	18	5	19	27	5	7	0.6	0.37	18
✓ Peedee	Peedee, S.C.	21	17	4	19	27	4	4	0.5	0.3	26
Platte	Columbus, Nebr.	232	158	74	104	153	20	158	1.1	0.2	32
Platte, North	North Platte, Nebr.	164	115	49	69	135	10	79	1.0	0.26	40
✓ Potomac	Cumberland, Md.	79	60	19	20	30	9	60	0.7	0.14	8
Powder	North Powder, Ore.	85	58	27	64	112	9	25	0.5	0.08	26
✓ Raritan	Bound Brook, N.J.	46	30	16	20	42	7	12	1.5	0.15	16
Red	Shreveport, La.	255	185	70	196	111	170	146	0.3	1.1	30
Republican	Junction, Kans.	230	173	57	124	242	42	55	2.4	2.2	48
✓ Rock	Rockford, Ill.	215	113	102	22	207	7	23	3.3	0.44	15
Rogue	Tolo, Ore.	25	18	7	15	32	2	4	0.2	0.07	24
Sacramento	Sacramento, Calif.	61	33	28	29	60	8	17	0.5	0.43	28
Salinas	Paso Robles, Calif.	265	150	115	129	232	55	101	0.6	0.15	31
Saluda	Columbia, S.C.	26	21	5	13	27	5	5	0.4	0.38	21
San Antonio	Bradley, Calif.	244	158	86	82	187	34	98	0.8	0.16	37
San Gabriel	Azusa, Calif.	162	113	49	39	150	6	33	0.9	0.16	21
Sangamon	Decatur, Ill.	245	138	107	31	220	8	36	6.8	0.27	19
San Joaquin	Lathrop, Calif.	91	50	41	78	60	66	40	0.8	0.3	19
Santa Ana	Corona, Calif.	89	65	24	39	84	10	14		0.15	16
✓ Shenandoah	Millville, W. Va.	114	80	34	15	111	4	6	2.1	0.08	15
Siletz	Siletz, Ore.	15	11	4	13	14	6	5	1.3	0.03	9
Skagit	Sedro Woolley, Wash.	27	20	7	8	23	1	8	0.2	0.08	9
Smoky Hill	Lindsborg, Kans.	375	285	90	349	210	269	246	1.5	0.86	28

TABLE 4. ANALYSES OF NINETY-EIGHT RIVER WATERS—ONE-YEAR AVERAGES (Continued)

Name of River	Sampled at or near	(expressed as ppm of CaCO ₃)								(ppm) Fe	(ppm) SiO ₂
		Hardness	Ca	Mg	Na + K	HCO ₃	Cl	SO ₄	NO ₃		
Snake	Weiser, Idaho	123	83	40	53	107	24	36	0.5	0.04	26
Solomon	Beloit, Kans.	296	230	66	187	241	95	112	2.4	1.4	35
Spokane	Spokane, Wash.	43	28	15	12	40	1	9	0.2	0.02	11
Spring	Baxter Springs, Kans.	199	165	34	51	114	10	87	4.3	1.1	13
Susquehanna	West Pittston, Pa.	59	45	14	14	51	6	14	1.2	0.12	10
Tennessee	Knoxville, Tenn.	73	55	18	18	71	14	7	0.6	0.54	25
✓ Tombigbee	Epes, Ala.	52	45	7	22	55	4	7	0.5	0.63	25
Umatilla	Umatilla, Ore.	85	58	27	54	95	13	24	1.0	0.07	34
Umpqua	Elkton, Ore.	29	20	9	13	30	4	5	0.2	0.1	18
Ventura	Ventura, Calif.	388	265	123	102	192	28	261	0.6	0.14	23
Verdigris	Coffeyville, Kans.	223	178	45	72	214	32	32	2.6	1.4	24
Vermilion	Streator, Ill.	257	138	119	39	198	10	70	1.0	0.22	14
Wabash	Logansport, Ind.	348	205	143	308	192	412	82	4.8	0.23	14
Wabash, Little	Carmi, Ill.	87	50	37	33	73	11	33	1.7	2.0	26
Wallowa	Joseph, Ore.	41	38	3	9	39	1	9	0.2	0.02	10
Walnut	Winfield, Kans.	299	225	74	69	240	21	90	3.0	1.2	23
Waterce	Camden, S.C.	23	16	7	18	28	4	4	0.3	0.28	25
Wenatchee	Cashmere, Wash.	23	14	9	9	23	1	7	0.3	0.08	12
✓ White, E. Fork	Azalia, Ind.	247	153	94	21	226	4	31	4.5	0.14	15
White, W. Fork	Indianapolis, Ind.	304	185	119	104	239	110	60	4.9	0.15	14
Willamette	Salem, Ore.	19	13	6	9	21	3	4	0.3	0.1	15
Wisconsin	Portage, Wisc.	63	35	28	18	48	3	18	0.7	0.22	13
✓ Youngiogeny	McKeesport, Pa.	86	58	28	20	acid	6	128	0.9	0.7	9
Yakima	Prosser, Wash.	65	40	25	31	66	7	22	0.3	0.1	19
Yukon	Anvik, Alaska	120	90	30	14	110	2	15		0.07	12

TABLE 6. ANALYSES OF FIFTY LAKE WATERS

Name of Lake	State or Province	(expressed as ppm of CaCO ₃)								(ppm) Fe	(ppm) SiO ₂
		Hardness	Ca	Mg	Na + K	HCO ₃	Cl	SO ₄	NO ₃		
Angela	California	15	13	2	5	15	4	1			5
Bass	Wisconsin	7	2	5	1	3	4	1		1.1	107
Bigstone	Minnesota	312	111	201	87	192	13	198	0.2	0.02	13
Cedar	Washington	23	17	6	8	23	3	6			10
Center	Indiana	253	218	33	20	183	21	68			
Champlain	New York	48	36	12	13	51	1	7			4
Clear	California	87	41	46	12	93	3	4		0.1	7
Crater	Oregon	30	18	12	27	28	15	11	0.3		18
Crystal	California	9	6	3	2	9	1	1			28
Eagle	Texas	326	274	52	189	120	318	58	20.0		
Echo	New Hampshire	12	6	6	5	5	2	9	0.2	0.01	4
Erie	New York	109	78	31	15	94	13	13	0.2	0.07	6
Geneva	Wisconsin	179	68	111	9	154	6	13			10
Goose	California	53	45	8	804	687	141	47	1.2	0.02	50
Hemlock	New York	71	50	21	7	54	3	18	0.3		2
Humboldt	Nevada	104	32	72	685	335	418	32		0.04	33
Huron	Michigan	89	60	29	9	85	4	6	0.3		12
Kampeska	South Dakota	256	138	118	29	216	7	54			4
Kester	West Virginia	36	28	8	3	28	4	8			8
Long	Wisconsin	82	46	36	11	82	11	2			
Massabesic	New Hampshire	12	7	5	6	7	4	7	0.1	0.04	22
Mead	Nevada	305	203	102	189	150	85	253	2.3	0.25	19
Mendota	Wisconsin	139	50	89	11	129	4	15			15
Michigan	Illinois	125	80	45	7	122	3	7		0.03	5
Mille Lacs	Minnesota	118	55	63	25	142	1	1			4

WATER TREATMENT

TABLE 6. ANALYSES OF FIFTY LAKE WATERS (Continued)

Name of Lake	State or Province	(expressed as ppm of CaCO ₃)								(ppm) Fe	(ppm) SiO ₂
		Hardness	Ca	Mg	Na + K	HCO ₃	Cl	SO ₄	NO ₃		
Minnetonka	Minnesota	103	70	33	6	108	1				5
Moosehead	Maine	7	6	1	5	9	3	2	tr.	0.1	1
Nipissing	Ontario, Can.	34	22	12	2	20	3	10	1.1	0.08	6
North	Colorado	48	43	5	29	74	1	tr.			2
North Watuppa	Massachusetts	10	7	3	10	7	9			0.14	2
Okeechobee	Florida	107	78	29	39	93	39	7	0.1	0.1	8
Ontario	Ontario, Can.	123	89	34	17	94	23	23	1.1	0.05	8
Penacook	New Hampshire	12	8	4	8	12	3	4			
St. Johns	Quebec, Can.	19	12	7		6	1		tr.	tr.	4
St. Marys	Ohio	176	119	57	35	120	35	56			
Sebago	Maine	12	7	5	2	3	2	7	0.7	0.05	2
Silver	Massachusetts	9	5	4	10	7	10	6		0.07	4
Silver	Montana	104	75	29	31	122	1	9		tr.	
Simcoe	Ontario, Can.	119	102	17	26	112	8	17	0.5	0.05	11
Skanateles	New York	113	85	28	5	95	2	15	1.2	0.02	6
Spavinaw	Oklahoma	80	75	5	10	76	6	8	tr.	0.1	4
Superior	Michigan	46	33	13	7	46	1	2	0.4	0.06	7
Tahoe	California	36	24	12	20	47	3	6		0.1	14
Washington	Washington	33	16	17		38	11	9		0.5	15
Whatcom	Washington	19	12	7	14	17	8	9	0.6	0.16	7
Winnebago	Wisconsin	162	87	75	4	168	4	10			14
Winnepesaukee	New Hampshire	10	7	3	6	8	2	4	tr.	0.02	1
Winnipeg	Manitoba, Can.	100	63	37	19	77	9	22	4.8	0.4	19
Worth	Texas	164	128	36	57	129	55	36	0.1	0.1	5
Yellowstone	Nevada	23	22	1	44	42	13	8			42

1. INDUSTRIAL WATER SUPPLIES

NOTE: Great Lakes sampled at following points: Erie at Buffalo; Huron at Port Huron; Michigan at Chicago; Ontario at Toronto, and Superior at Sault Ste. Marie

2. DISSOLVED MINERAL MATTER

THE ORDER in which water impurities are discussed in Chapters 2, 3, and 4 is according to the group classification given in Chapter 1, namely: (1) dissolved mineral matter; (2) dissolved gases; (3) turbidity and sediment; (4) color and organic matter; (5) tastes and odors; and (6) microorganisms. Dissolved mineral matter is the subject taken up in this chapter. Chapter 3 is devoted to dissolved gases, while turbidity, sediment, color, organic matter, tastes, odors, and microorganisms are discussed in Chapter 4.

All natural water supplies, either in their raw state or after treatment by a municipality, contain dissolved mineral matter. As shown in the analyses listed in Chapter 1, these mineral constituents differ greatly in the amounts and relative proportions present in various water supplies. The most abundant are the bicarbonates, sulfates, and chlorides of calcium, magnesium and sodium. Silica also is a common constituent of waters and may be present in amounts ranging from as little as 1 ppm to over 100 ppm.

Iron is present in most water supplies in small amounts, and if present to the extent of 0.1 ppm or less, may be considered as negligible for most industrial uses. If present in greater amounts than 0.2 or 0.3 ppm, it is usually very objectionable. Manganese is a rarer constituent but is even more objectionable, and tolerances for special uses may be even lower than the tolerances for iron.

Nitrates are usually absent or present only as traces, but there are exceptions, and if appreciable amounts are present, nitrates are determined. Nitrites are either absent or present in such minute amounts that they are rarely determined in industrial water analyses. Ammonia, which possibly might more appropriately be considered under gases, is also usually such a minor constituent that it is seldom determined in industrial water analyses. There are exceptional cases, however, where heavily contaminated waters have given off enough ammonia in the boilers to have an effect on brass valves and fittings.

NOTE: From a health standpoint and then only in the case of very young babies, nitrates above some 10 to 20 ppm in the drinking water can cause methemoglobinemia.

2. DISSOLVED MINERAL MATTER

43

Bosch, H. M., *et al.*, "Methemoglobinemia and Minnesota Well Supplies," *J. Am. Water Works Assoc.*, 42, 161 (1950) and references in same.

Potassium, because it is usually present in such small amounts and is so much like sodium in most of its properties, is usually grouped with the sodium. Fluorides, which may occur in the waters in certain localities in amounts of from less than 1 to 8 ppm, are of importance from a health angle but are probably of little significance for most industrial uses. A few of the waters in certain western areas contain borates in sufficient amounts to be of importance when used for irrigation. Small amounts of alumina are also commonly found in water supplies, but usually they are of little significance.

Small quantities of carbonate alkalinity may be found, at times, in both natural surface waters and well waters, and objectionable amounts may be present in the so-called alkali waters. Caustic alkalinity is practically never found except in treated waters.

Mineral acidity, usually caused by sulfuric acid, is found in many mine waters and some surface waters which have been contaminated by trade wastes or seepage from mines.

NOTE: Bromine, in commercially extractable amounts, is found in seawater and some connate waters or oil-field brines. Iodine is also present in small amounts in seawater and some connate waters and oil-field brines. In fresh waters, while the amounts of iodine present are extremely small—they are measured in parts per billion instead of in ppm—they are of importance in reducing the prevalence of goiter. For industrial uses, its presence or absence is of no importance. There are also a few very unusual waters which contain

TABLE 15A. MINERAL CONSTITUENTS USUALLY DETERMINED IN WATER ANALYSIS

Name	Formula	Expressed as	Commonly Known as
Calcium	Ca	CaCO ₃	Calcium hardness + Magnesium hardness } = Total hardness
Magnesium	Mg	CaCO ₃	
Sodium	Na	CaCO ₃	—
Bicarbonate	HCO ₃	CaCO ₃	Bicarbonate alkalinity
Carbonate	CO ₃	CaCO ₃	Carbonate alkalinity
Hydroxide	OH	CaCO ₃	Caustic alkalinity
Chloride	Cl	CaCO ₃	—
Sulfate	SO ₄	CaCO ₃	—
Nitrate	NO ₃	CaCO ₃	—
Mineral acid*	—	CaCO ₃	Mineral acidity
Fluoride	F	F	—
Silica	SiO ₂	SiO ₂	—
Iron	Fe	Fe	—
Manganese	Mn	Mn	—

* Mineral acidity may be due to sulfuric acid or sulfates of iron, alumina, or manganese. In the effluent from hydrogen-cation exchangers, both sulfuric and hydrochloric acids may be present, plus, with some waters, small amounts of nitric acid.

measurable amounts of such unusual constituents as arsenic, selenium and strontium, but these are so uncommon that it is probably sufficient merely to mention that they exist. Lead, copper and zinc, in small amounts, may also be picked up from pipe by corrosive waters. Spectroscopic traces of other metals have been found in natural water supplies but, since they are present in only spectroscopic traces, they need not be considered. Trade-waste contamination of waters may also furnish unusual constituents, one of which is chromium.

For ordinary industrial uses and for the usual run of natural and treated water supplies, the mineral constituents, in Table 15A are the only ones that need to be considered:

Alkalinity: Bicarbonate, Carbonate, and Caustic

Alkalinity is determined by titration with a standard acid solution, using phenolphthalein and methyl orange as indicators. The results of titration with the methyl orange indicator are expressed as "methyl orange alkalinity" or "total alkalinity." The results of titration with phenolphthalein indicator are expressed as "phenolphthalein alkalinity" (most natural water supplies contain some free carbon dioxide and show no phenolphthalein alkalinity).

(1) If no phenolphthalein alkalinity is present, all of the alkalinity is assumed to be bicarbonate alkalinity.

(2) If phenolphthalein alkalinity is present, twice the phenolphthalein alkalinity, if less than or equal to the methyl orange alkalinity, is assumed to be carbonate alkalinity.

(3) If twice the phenolphthalein figure exceeds the methyl orange alkalinity, the excess is presumed to be "caustic" or hydroxide alkalinity.

NOTE: There are certain errors inherent in these determinations and these assumptions are not strictly in accordance with physical chemistry concepts, but these methods are simple and very satisfactory for most of the calculations involved in water treatment.

Obviously, in solutions as dilute as fresh water supplies are, the salts are not present as such but instead are practically completely dissociated into the corresponding anions and cations. However, it is often convenient and simpler to visualize some of the salts as if they were undissociated. Thus, it is common practice to refer to the calcium bicarbonate or calcium sulfate content of a water as if these substances were present as undissociated salts instead of as ions. In other cases, it may be simpler to consider the ions that are present.

Hardness: Calcium and Magnesium

The hardness of a water is due to its calcium and magnesium content. Hardness in English-speaking countries is expressed in terms of calcium

carbonate. Calcium hardness is that hardness due to soluble calcium salts; magnesium hardness, to soluble magnesium salts. Total hardness is the sum of the calcium hardness plus the magnesium hardness.

NOTE: The term, hardness, was originally applied to waters that were hard to wash in; it referred to the soap-wasting properties of water. With most normally alkaline waters, these soap-wasting properties are directly and proportionately due to the calcium and magnesium content. It is obvious that in an acid water, the mineral acids present would also act as hardness. Similarly, if appreciable amounts of soluble iron, aluminum, or certain other heavy metals were present, these also would waste soap. However, these are exceptional cases and there is no need of complicating a simple definition with them.

Carbonate hardness, bicarbonate hardness, and temporary hardness are synonymous terms for that hardness attributed to the bicarbonates of calcium and/or magnesium. The first of these, carbonate hardness, is now the preferred term. Noncarbonate hardness, sulfate hardness, and permanent hardness are synonymous terms for that hardness due to the sulfates, chlorides and/or nitrates of calcium and/or magnesium. The first of these, noncarbonate hardness, is now the preferred term.

The amounts of carbonate and noncarbonate hardness present in a given water are determined by inspection of the analysis as follows:

(1) If the methyl orange alkalinity of the water equals or exceeds the total hardness, all of the hardness is present as carbonate hardness.

(2) If the methyl orange alkalinity of the water is less than the total hardness, the carbonate hardness equals the alkalinity.

(3) The noncarbonate hardness, under the conditions in (2), is equal to the total hardness minus the methyl orange alkalinity.

While the terms "carbonate hardness" and "noncarbonate hardness" are often used in the text, there are some deviations for the sake of clarity. For instance, it is not at all obvious what is meant if it is stated that the calcium carbonate hardness breaks down, on heating, to form calcium carbonate. On the other hand, if it is stated that the calcium bicarbonate hardness breaks down, on heating, to form calcium carbonate, it is immediately obvious that a definite change has taken place. In other cases also, especially when sodium alkalinity is also present, it is clearer in showing the relationships to use the terms, "calcium alkalinity" and "magnesium alkalinity" than the terms "calcium carbonate hardness" and "magnesium carbonate hardness."

NOTE: If the methyl orange alkalinity exceeds the total hardness, the excess is the sodium alkalinity.

Calcium Carbonate Scale. Since calcium carbonate is much less soluble than magnesium carbonate and both of them are very much less

soluble than sodium carbonate, it is convenient to visualize the alkalinity as bound first to the calcium, second to the magnesium, and third to the sodium. Such a visualization is helpful for practical purposes, for, when a water containing the bicarbonates of calcium, magnesium, and sodium is heated, the calcium carbonate is the first to be deposited, magnesium carbonate next, while sodium carbonate is so extremely soluble that no separation in the solid form would occur until the solution was greatly concentrated by evaporation. The solubilities of these three carbonates at 212°F are shown in Table 16.

TABLE 16. CARBONATES: SOLUBILITIES OF THE CARBONATES OF CALCIUM, MAGNESIUM, AND SODIUM AT 212°F

Name	Formula	Solubility as CaCO ₃	
		(ppm)	(gpg)
Calcium carbonate	CaCO ₃	13	0.8
Magnesium carbonate	MgCO ₃	75	4.4
Sodium carbonate	Na ₂ CO ₃	289000	16900.0

An inspection of 233 river, lake, spring and well-water analyses in Chapter 1 will indicate that only 10.3 per cent have magnesium alkalinities exceeding 75 ppm, expressed as CaCO₃, and these are divided as follows: 76 to 85 ppm, 3.9 per cent; 86 to 100 ppm, 3.0 per cent; 100 to 125 ppm, 2.1 per cent; and 126 to 147 ppm, 1.3 per cent. This goes far to explain why it is that calcium carbonate is the principal scale-former in condensers and other water-jacketed equipment, water heaters, hot-water piping and fixtures, for, even if the bicarbonates were entirely broken down to the carbonates, there are but relatively few waters which contain enough magnesium alkalinity to exceed the solubility of magnesium carbonate. Also, in practically all cases where the raw water is merely heated but not actually boiled or concentrated, as in the steam boiler, the decomposition of bicarbonates is far from complete; it can be expected that, under such conditions, calcium carbonate will usually be the principal scale-former.

There is a widespread opinion that calcium carbonate scale cannot form unless water is heated beyond 130°F. This is incorrect, for with some waters even a very slight rise in temperature is sufficient to form calcium carbonate scale. For instance, in tropical or semitropical locations, heavy calcium carbonate scale formation in cold-water mains is not unknown. As this is treated very fully in Chapter 7, it need only be mentioned very briefly here that there is an equilibrium, at each temperature, between the free carbon dioxide content of the water and the amount of calcium

bicarbonate that can be held in solution and that with some waters even a slight elevation of temperature is sufficient to upset this equilibrium and cause calcium carbonate to deposit.

An interesting phenomenon is the occasional deposition of some calcium carbonate in pond waters, caused by microorganisms. Some of these, under favorable conditions, use up all the free carbon dioxide content of the water and some of the carbon dioxide content of the bicarbonates, forming thereby some normal carbonate. If the amount of carbonate so formed is much over 1 gpg (17 ppm), precipitation of part of the calcium hardness can occur.





Figure 5. Scaled hot-water pipes.

Calcium Carbonate and Magnesium Hydroxide Scale. At the temperatures prevailing in the steam boiler, both calcium bicarbonate and magnesium bicarbonate break down to form scale, but whereas the calcium scale consists of calcium carbonate, the magnesium deposits as magnesium hydroxide. This is because the magnesium bicarbonate decomposes first to magnesium carbonate and this reacts with the water to form magnesium hydroxide and free carbon dioxide. Sodium bicarbonate undergoes a similar decomposition in the boiler but, since caustic soda is extremely soluble, it remains in solution. These reactions are as follows:



The carbon dioxide formed leaves the boiler with the steam. In the case of the sodium carbonate, the conversion to sodium hydroxide often exceeds 80 per cent. The magnesium hydroxide in the scale may lose part

of its water content by baking on the tubes and appear partly as magnesium oxide. The solubilities of the hydroxides of calcium, magnesium, and sodium, expressed as ppm of CaCO_3 , at 212°F are given in Table 17.

Under higher temperatures and pressures, the solubilities of both calcium carbonate and magnesium hydroxide decrease. At about 210 psi (392°F), the solubility of calcium carbonate is a little less than 5 ppm and that of magnesium hydroxide is only slightly over 1 ppm, expressed as CaCO_3 . Calcium hydroxide also has a solubility that decreases with rise in temperature. At 32°F its solubility is 2390 ppm, at 212° , 888 ppm, and at 210 psi (392°F), 134 ppm, expressed as CaCO_3 . It is not likely to be found in a boiler scale, however, unless the boiler feed water was grossly overtreated with lime.

TABLE 17. HYDROXIDES: SOLUBILITIES OF THE HYDROXIDES OF CALCIUM, MAGNESIUM, AND SODIUM AT 212°F

Name	Formula	Solubility as CaCO_3	
		(ppm)	(gpg)
Calcium hydroxide	Ca(OH)_2	888	51.8
Magnesium hydroxide	Mg(OH)_2	8	0.5
Sodium hydroxide	NaOH	975000	56900.

Calcium Sulfate Scale. Calcium sulfate is the only scale-forming salt in the noncarbonate hardness for magnesium sulfate, and the chlorides and nitrates of both calcium and magnesium have solubilities exceeding 150,000 ppm by weight expressed as CaCO_3 , even at 32°F and over 356,000 ppm at 212°F . Calcium sulfate, in the form of gypsum, has a solubility curve which, on elevations of temperature, shows a rise up to about 104°F , after which it falls until, at 212°F , it is slightly below the solubility at 32°F . At boiler temperatures the curve falls rapidly, until at 322 psi it is only some 40 ppm, expressed as calcium carbonate. This is shown in Table 18.

It is therefore evident that the tolerance for calcium sulfate in a cooling water would be large—over 1200 ppm (70 gpg) expressed as CaCO_3 . This is taken into account in the acid treatment of cooling waters as described in Chapter 7. It is also necessary to see that the blowdown on a cooling pond is regulated so as to maintain the calcium sulfate content below some 1200 ppm, expressed as CaCO_3 . Owing to its low solubility at the temperatures prevailing in steam boilers and because it forms a very hard and adherent scale, no amount of calcium sulfate can be tolerated in steam boilers.

Thermal Conductivities of Scales. From measurements made by Ernst,

Eberle and Holzhauser, Reutlinger, Croft, and Partridge and White, the thermal conductivities (K) of adherent boiler scales, expressed in Btu per square foot of area, per foot of thickness, per hour, per 1°F temperature difference, have been found to lie between 0.66 and 2.06 with a mean value of approximately 1.5. The degree of porosity of the scale affects the thermal conductivity, as apparently these pores may be filled with steam instead of water under boiler operating conditions, thus reducing the thermal conductivity in much the same manner as the air cells in the commonly used heat-insulating materials. There is some evidence that such porous scales may have thermal conductivities of only 0.2 Btu per sq ft per ft per hr per 1°F .

TABLE 18. CALCIUM SULFATE: SOLUBILITIES AT 32 TO 423°F

$^\circ\text{F}$	Solubility as CaCO_3	
	(ppm)	(gpg)
32	1293	75.5
104	1551	90.5
212	1246	72.7
338 (100 psi)	103	6.0
392 (210 psi)	56	3.3
428 (322 psi)	40	2.3

For comparison, the thermal conductivity of firebrick is about 0.75 and steel about 26. Hardwater scales therefore have thermal conductivities of only some 3 per cent to 8 per cent (average about 5 per cent) of that of steel or about the same as that of firebrick. In other words, hardwater scales are practically as good heat-insulating materials as firebrick. Unfortunately, scale forms in the wrong places which accounts for its being called "misplaced insulation."

In order to pass a given number of heat units through a certain area of a vessel in a given period of time, it is necessary to maintain a definite differential of temperature between the inside and the outside of the vessel. If the walls of the vessel consist of clean, unscaled metal, the temperature differential that must be maintained is very much less than if the metal is scaled. How much this temperature differential must be raised, for various rates of heat transfer, if one-tenth of an inch of scale is present, is shown in Table 19, which has been calculated for two scales having thermal conductivities (K) of 1.5 and 0.75.

The heat-insulating properties of hard-water scales are objectionable not only in steam boilers and water heaters but also in water-cooled equipment such as condensers, internal combustion engines and other water-jacketed equipment. Furthermore, these scale deposits do not form

TABLE 19. SCALE: TEMPERATURE ELEVATIONS, AT VARIOUS RATES OF HEAT TRANSFER, CAUSED BY ONE-TENTH INCH THICKNESSES OF TWO SCALES

Rate of Heat Transfer (Btu/sq ft/hr)	Increase in Temperature Differential Caused by One-Tenth Inch of Scale (°F)	
	$K = 0.75$	$K = 1.5$
2000	22	11
5000	56	28
10000	111	56
20000	222	111
40000	444	222
60000	667	333
80000	889	444
100000	1110	556
120000	1330	667
140000	1560	778

a layer which is of even thickness and uniformly distributed over the entire heat transfer area. Instead, scale forms most rapidly and consequently is thickest at points where the rate of heat transfer is greatest.

The maximum safe operating temperature for mild boiler steel is considered to be about 900°F. Temperatures much above this point will result in bagging (Figure 6) or failure (Figure 7). Failures of tubes in



Figure 6. Bagged boiler tube caused by scale.



Figure 7. Boiler tube failure caused by scale.

the highly irradiated sections of modern boilers have been caused by scale thicknesses of less than 0.04 inch. This agrees quite well with the calculated figures, for, if $K = 0.75$ is assumed as the thermal conductivity of the scale, a simple calculation will show 0.04-inch thickness of scale is sufficient to cause boiler metal temperatures exceeding 900°F at heat transfer rates of 100,000 or more Btu per sq ft per hr in boilers operating at pressures of 400 psia or over. At higher pressures, even smaller thicknesses of scale may cause boiler metal temperatures above 900°F and, if a porous scale with a value for K of 0.2 or less is encountered, calcula-

tions indicate that even less than 0.01-inch thickness of scale may be sufficient to cause failure of the boiler metal.

In water jackets, scale is equally objectionable. In Diesel or other internal combustion engines, scaled surfaces in the water jackets cause increases in temperature differentials between the fire side and water side



Figure 8. Scaled flue from locomotive boiler.

in much the same manner as in the steam boiler. As the scale increases in thickness, this temperature differential likewise increases, until finally it becomes so great that the metal is highly overheated and fails. Cylinder heads on Diesel engines are especially prone to cracking from scale deposits. Figure 9 illustrates such a failure. In surface condensers and other nonfired vessels, failure of the metal from overheating could not occur




Figure 9. Cracked Diesel-engine cylinder head caused by scale.

because the temperature differential is too small. In a surface condenser, operating on exhaust steam and under a partial vacuum, of course, there may be less than 50°F temperature differential between the vapor side and the water side of the metal. It is on account of this small temperature differential that scales are so troublesome in condensers, for even a very thin scale will increase the temperature differential, thus lowering the vacuum in the exhaust and decreasing the efficiency of the prime mover.

Hard-water scales are also highly objectionable because they decrease

the effective diameter of pipe lines and thus greatly reduce their carrying capacity. It is not uncommon to see 6-inch pipe with one-inch layer of scale in it, thus reducing its effective diameter to 4 inches and its carrying capacity to less than one-half of what it was originally. Nor is it necessary to have very thick scales in order to reduce the flow rates, especially in the case of smaller pipe. Only one-fourth inch of scale in a one-inch pipe, for instance, will reduce its effective diameter to one-half inch and the maximum flow rate obtainable would be only one-fourth of what it was originally.

Soap Wastage by Hardness. When a hard water comes in contact with soap, the calcium and magnesium ions react with the ions of the fatty acids to precipitate the practically insoluble calcium and magnesium soaps. With pure soap, this destruction by hardness amounts to 1½ pounds of soap per 1000 gallons of water for each grain per gallon (17 ppm) of hardness present, as shown in Table 20.

TABLE 20. HARDNESS: SOAP DESTRUCTION OF WATER OF VARIOUS HARDNESSES

Hardness as CaCO ₃		Soap Wastage (lb/1000 gal)	Hardness as CaCO ₃		Soap Wastage (lb/1000 gal)
(gpg)	(ppm)		(gpg)	(ppm)	
1	17	1.5	16	274	24.0
2	34	3.0	17	291	25.5
3	51	4.5	18	309	27.0
4	69	6.0	19	326	28.5
5	86	7.5	20	343	30.0
6	103	9.0	22	377	33.0
7	120	10.5	24	411	36.0
8	137	12.0	26	446	39.0
9	154	13.5	28	480	42.0
10	171	15.0	30	514	45.0
11	189	16.5	35	549	52.5
12	206	18.0	40	583	60.0
13	223	19.5	45	771	67.5
14	240	21.0	50	857	75.0
15	257	22.5	60	1028	90.0

As the soap destruction is directly proportional to the amount of hardness, a standard solution of soap may be employed to measure the hardnesses of various waters and this figure is often called the "soap hardness." This should agree with the hardness of the water when determined by gravimetric methods, but certain inaccuracies in making the determinations may lead to appreciable discrepancies in the results. This is especially the case with the older Clark method. The potassium palmitate or Blacher method yields much more satisfactory results.

As can be deduced from Table 20, the soap destruction in textile plants, laundries, and other industries where cleansing operations with soap are conducted are large when hard waters are used. Therefore, softening of the water used in such industries effects huge savings. Softening the water supply not only saves soap and other detergents, but it also



Figure 10. Left: hard water and soap. Right: zero hardness water and soap.

effects an incomparably better cleansing and furnishes a superior product. In textile plants and laundries, the washed materials have a better appearance, softer feel, and an increased life. In dyeing, softened water is of importance in securing even dyeing, free from spots and streaks. In the manufacture of rayon, it has been found extremely important to eliminate



Figure 11. Photomicrograph of linen washed in hard water.

even a few ppm of hardness, and water with a practically zero content of hardness is a prime requisite.

Hard water is also a drawback in many other industries, even when soap is not used in processing operations. In alkaline baths, for instance, scale formation is common and causes many processing difficulties. These processes and the difficulties caused by hard waters in various industries are further discussed in Chapter 5.

Hardness of Industrial Water Supplies. The tabulated analyses of various water supplies in Chapter 1 are from a sufficient number of locations to give a fair idea of the ranges in hardness that may be en-



Figure 12. Milk bottles washed with caustic soda in hard water vs. zero hardness water.

countered with various industrial water supplies. The attempted classification of natural water supplies as soft, moderately hard, hard, very hard, and extremely hard is unsatisfactory and misleading because (1) the



Figure 13. Deposits on bottle pasteurized in hard water.

tolerances for hardness for different industrial uses vary so greatly often even in the same plant, and (2) these terms are subject to almost as many interpretations as there are listeners.

Concerning the first, an 85-ppm (5-gpg) hardness water may be "soft" enough for the process water in a paper mill but too "hard" to use in the mill's boilers. Or a 50-ppm (3-gpg) hardness water may be considered "very soft" and satisfactory by a carbonated beverage bottler, while a

rayon manufacturer may consider the same water as "hard" and very unsatisfactory. This matter of water requirements for various end uses in a number of different industries is discussed very fully in Chapter 5.

Concerning the second, an item in a Midwestern newspaper some years ago had a headline which blazoned forth that "— Gets Soft Water Supply" and then the subhead under it stated, "New Well Has a Hardness of Only 20 Grains." Obviously, a water that contains hardness cannot be considered a soft water and a water that contains 20 gpg (343 ppm) is a water that would usually be considered as "very hard" or even "extremely hard." For instance, it is about twenty times as hard as the water supply in Boston or the Catskill supply used in New York; about six times as hard as the water supply of Baltimore and about three times as hard as the water supplies in Cleveland, Chicago, and Milwaukee.

Yet, on reading the item under the headlines, it developed that the well water supply previously used had a hardness of 60 to 70 gpg (1028 to 1200 ppm). Quite naturally then, the reporter considered that any water having only one-third as much hardness as the hard water he was accustomed to must be a soft water. This illustration is a rather extreme one and sounds absurd, but that is only because the hardnesses of the well waters in that town are so much higher than the hardnesses of the waters that most of us are accustomed to in daily use. For instance, there are over 650 municipal water-softening plants in North America, and the waters furnished by these plants are considered to be "soft" waters by millions of users. Yet, with the exception of a scant dozen or so, these plants invariably merely reduce the hardness of the raw water to 85 gpg (5 gpg).

Such "soft" waters, when used in laundries or similar washing processes, are so "hard" that they will waste from 35 to 45 per cent of the total soap used or, expressed in another way, as shown in Table 20, each 1000 gallons will waste about 7½ pounds of pure soap. Therefore, while these waters are "soft" enough for most household uses and these municipalities are to be highly commended for reducing the hardness of the raw waters to this extent, these waters are too "hard" for the great majority of industrial uses.

NOTE: While the average consumption of water in municipalities is about 100 gallons per capita per day, only some 1.2 gallons per capita per day reacts completely with soap. At first glance, this looks absurdly low but it must be considered that, when a person takes a bath, he does not use enough soap to raise a lather with all the water in the tub. Instead, he soaps portions of his anatomy only when out of the water and then rinses in the tub. Consequently, only a thin film of water reacts completely with the soap. The same obviously applies as well to shower baths or in washing in the wash bowl. On the other hand, in dish washing or in the washing machine, all of the water used in the sudsing operations completely reacts with the soap. Yet the cost of the soap

TABLE 21. HARDNESS: VARIATIONS IN HARDNESS OF A GROUP OF NINETY-EIGHT RIVER WATERS OVER A ONE-YEAR PERIOD

Name of River	Sampled at or near	Hardness as ppm CaCO ₃		
		(max.)	(min.)	(aver.)
Alabama	Selma, Ala.	67	28	45
Allegheny	Kittanning, Pa.	90	26	47
Arkansas	Arkansas City, Kans.	473	238	336
Big Blue	Manhattan, Kans.	296	129	225
Brazos	Waco, Texas	652	176	381
Cache	Mounds, Ill.	141	44	73
Cahaba	Birmingham, Ala.	74	21	43
Cedar	Cedar Rapids, Ia.	267	87	186
Chattahoochee	West Point, Ga.	27	5	15
Chikaskia	Argonia, Kans.	251	165	209
Chippewa	Eau Claire, Wis.	78	82	52
Cimarron	Englewood, Kans.	453	283	352
Clackamas	Casadero, Ore.	29	12	19
Columbia	Cascade Locks, Wash.	67	41	57
Columbia	Northport, Wash.	76	56	64
Cottonwood	Emporia, Kans.	475	200	353
Crooked	Prineville, Ore.	149	46	110
Cumberland	Nashville, Tenn.	102	65	80
Delaware	Lambertville, N.J.	61	24	44
Deschutes	Moody, Ore.	50	23	32
Des Moines	Keosauqua, Ia.	406	116	231
Embarrase	Charleston, Ill.	308	161	226
Fall	Neodesha, Kans.	279	156	222
Flint	Albany, Ga.	48	17	28
Fox	Ottawa, Ill.	369	209	281
Grand	Grand Rapids, Mich.	263	164	218
Grande Ronde	Elgin, Ore.	67	20	31
Hudson	Hudson, N.Y.	89	45	69
Illinois	La Salle, Ill.	277	157	215
Iowa	Iowa City, Ia.	267	84	193
James	Richmond, Va.	71	26	47
Kalamazoo	Kalamazoo, Mich.	260	125	212
Kankakee	Kankakee, Ill.	284	171	231
Kansas	Holiday, Kans.	430	135	249
Kaskaskia	Carlyle, Ill.	255	105	200
Kentucky	Frankfort, Ky.	94	38	68
Klickitat	Klickitat, Wash.	42	23	31
Lehigh	South Bethlehem, Pa.	105	26	59
Marmaton	Fort Scott, Kans.	272	180	239
Maumee	Toledo, O.	290	150	210
Medicine Lodge	Kiowa, Kans.	995	323	589
Miami	Dayton, O.	303	139	246
Mississippi	Memphis, Tenn.	184	108	139
Mississippi	Minneapolis, Minn.	188	104	157
Missouri	Kansas City, Kans.	348	159	229
Monongahela	Elizabeth, Pa.	57	26	39
Muddy	Murphysboro, Ill.	222	41	112
Muskingum	Zanesville, O.	209	70	147
Okanogan	Okanogan, Wash.	103	40	72
Oostanula	Rome, Ga.	118	27	41

TABLE 21. HARDNESS: VARIATIONS IN HARDNESS OF A GROUP OF NINETY-EIGHT RIVER WATERS OVER A ONE-YEAR PERIOD (Continued)

Name of River	Sampled at or near	Hardness as ppm CaCO ₃		
		(max.)	(min.)	(aver.)
Osage	Boicourt, Kans.	323	111	217
Oswegatchie	Ogdensburg, N.Y.	58	32	47
Pearl	Jackson, Miss.	35	14	23
Peedee	Peedee, S.C.	33	17	21
Platte	Columbus, Nebr.	301	176	232
Platte, North	North Platte, Nebr.	201	134	164
Potomac	Cumberland, Md.	148	41	79
Powder	North Powder, Ore.	116	59	85
Raritan	Bound Brook, N.J.	55	29	46
Red	Shreveport, La.	779	96	255
Republican	Junction, Kans.	282	163	230
Rock	Rockford, Ill.	282	127	215
Rogue	Tolo, Ore.	37	18	25
Sacramento	Sacramento, Calif.	81	40	61
Salinas	Paso Robles, Calif.	332	191	265
Saluda	Columbia, S.C.	40	20	26
San Antonio	Bradley, Calif.	460	154	244
San Gabriel	Azusa, Calif.	199	136	162
Sangamon	Decatur, Ill.	349	179	245
San Joaquin	Lathrop, Calif.	186	22	91
Santa Ana	Corona, Calif.	248	165	206
Shenandoah	Millville, W. Va.	137	57	114
Siletz	Siletz, Ore.	33	8	15
Skagit	Sedro Woolley, Wash.	42	18	27
Smoky Hill	Lindsborg, Kans.	510	209	348
Snake	Weiser, Idaho	156	66	123
Solomon	Beloit, Kans.	372	211	296
Spokane	Spokane, Wash.	59	22	43
Spring	Baxter Springs, Kans.	275	114	199
Susquehanna	West Pittston, Pa.	94	33	59
Tennessee	Knoxville, Tenn.	94	55	73
Tombigbee	Epas, Ala.	66	35	52
Umatilla	Umatilla, Ore.	145	25	85
Umpqua	Elkton, Ore.	40	21	29
Ventura	Ventura, Calif.	449	344	388
Verdigris	Coffeyville, Kans.	331	120	223
Vermilion	Streator, Ill.	337	202	257
Wabash	Logansport, Ind.	637	169	348
Wabash, Little	Carmi, Ill.	160	46	87
Wallowa	Joseph, Ore.	46	33	41
Walnut	Winfield, Kans.	389	178	299
Wateree	Camden, S.C.	38	14	23
Wenatchee	Cashmere, Wash.	43	13	23
White, E. Fork	Azalia, Ind.	305	174	247
White, W. Fork	Indianapolis, Ind.	394	190	304
Willamette	Salem, Ore.	28	12	19
Wisconsin	Portage, Wisc.	80	35	63
Youghiogony	McKeesport, Pa.	200	47	86
Yakima	Prosser, Wash.	150	39	65
Yukon	Anvik, Alaska	151	68	120

wasted by this approximately 1 per cent of hard raw water is so large that it is some two to three times as great as the cost of the chemicals used in softening all of the water. Therefore, when a municipality "softens" a raw water having a hardness of 200, 300, 400, 500 or more ppm down to 85 ppm, it not only furnishes a water that is quite suitable for most household uses, but it also cuts every citizen's soap bill down to a fraction of what it was with the raw water. In the aggregate, these soap savings are so large that in many cities they may be measured in hundreds of thousands of dollars per year.

Therefore, it is obvious that instead of trying to classify water supplies by these exceedingly loose and indefinite terms, it is necessary to study the composition of each water in conjunction with the requirements for its various end uses. It is also necessary to know what variations in composition are to be expected.

In Chapter 1, it was stated that the composition of a river water is subject to fluctuations over a rather wide range. The ranges of hardness, over a one-year period, of the ninety-eight river waters in Table 4 of Chapter 1, are given in Table 21. An inspection of these analyses will show that in some of these rivers, the maximum hardness is a scant third higher than the minimum hardness, while in others the maximum hardness may be as much as $8\frac{1}{2}$ times the minimum hardness. Expressed in another way, the smallest difference between minimum and maximum hardness is 13 ppm (0.8 gpg); the greatest is 683 ppm (40 gpg).

As these analyses were not made daily but were instead made every 10 days on composite samples, there may have been even greater variations than shown. In any event, this table clearly indicates the advisability of collecting as complete analytical data as possible regarding the changes in composition of any river water intended to furnish the water supply for an industrial plant. Temperature measurements are also important, especially if the river water is also to be used for cooling purposes. This last feature is more fully discussed in Chapter 7.

Surface waters from very large lakes, however, are usually quite constant in composition, as shown by the curves in Figure 14, although temperature variations will be encountered. Some small lakes, ponds, and reservoirs may show considerable seasonal variations in composition, but these, owing to the ironing out effect of their volume, are usually much less abrupt in their changes than is the case with river waters. Others show but small ranges in composition.

A ground water supply, especially if drawn from a deep well, usually shows but slight fluctuations in composition. Such well waters, also, are remarkably constant in temperature throughout the year. Many shallow wells likewise show but small ranges in composition, while others vary over a wider range. Well waters, especially shallow ones, may be contaminated by industrial wastes. In one case, two large shallow wells showed slight acidities at times, due to trade wastes dumped in a dis-

posal pit some 600 feet away. In another case, wells near a small stream carrying acid wastes showed an appreciable content of ferrous sulfate, aluminum sulfate, and sulfuric acid, as well as variations in hardness.

Water Softening. The processes whereby the hardness of a water is reduced or removed are known as water softening. The various water-softening processes and the chapters in which they are described are: (1) zeolite (sodium cation-exchange) water-softening process—Chapter 13; (2) hydrogen cation-exchange process—Chapter 14; (3) ion-exchange demineralizing process—Chapter 15; (4) distillation—Chapter 15; (5) cold lime-soda water-softening processes—Chapter 16; and (6) hot lime-soda water-softening process—Chapter 17.




Figure 14. Hardness curves of four of the Great Lakes over a one-year period, showing relatively constant composition.
 A—Lake Erie at Buffalo, N. Y.
 B—Lake Michigan at St. Ignace, Mich.
 C—Lake Huron at Port Huron, Mich.
 D—Lake Superior at Sault Ste. Marie, Mich.

Sodium Salts

The sodium salts that may occur in various natural water supplies are the sulfate, chloride, nitrate, bicarbonate, and, rarely, carbonate. As to the quantities present in different fresh water supplies, these vary over a wide range. For instance, in the analyses of the various river, lake, spring, and well waters listed in Chapter 1, the sodium salts range from as little as 2 per cent to as much as 98 per cent of the total salts present, the average figure being 25 per cent.

These sodium salts are extremely soluble in either cold or hot water, as is shown in Table 22 (which also includes the hydroxide). Owing to these high solubilities, the sodium salts do not form scales, either on heating or on evaporating in the steam boiler, unless the evaporation is carried out to undue lengths. Also they do not waste soaps since the soaps that are most widely employed are sodium salts of certain of the

TABLE 22. SODIUM SALTS: SOLUBILITIES OF SODIUM BICARBONATE, CARBONATE, CHLORIDE, HYDROXIDE, NITRATE AND SULFATE

Name	Formula	Solubility as ppm of CaCO ₃	
		(at 32°F)	(at 212°F)
Sodium bicarbonate	NaHCO ₃	38400	decomposes
Sodium carbonate	Na ₂ CO ₃	62600	289000
Sodium chloride	NaCl	225000	241000
Sodium hydroxide	NaOH	370000	975000
Sodium nitrate	NaNO ₃	248000	378000
Sodium sulfate	Na ₂ SO ₄	33200	298000

higher fatty acids; there is no reaction between the sodium salts in water and soap.

NOTE: Strong solutions of sodium salts will throw soap out of solution, this effect being known as "salting out." The composition of the soap is unaltered by "salting out" and it can be redissolved either in fresh water or by diluting the saline solution.

Therefore, for many industrial uses moderate amounts of sodium salts in the water supply are of little or no importance. They do increase the amount of blowdown on the steam boiler, and if much sodium bicarbonate is present, it may be advisable to remove it or to neutralize most of it with sulfuric acid and then to aerate or degasify the acid-treated water before feeding it to the boiler, in order to reduce the free carbon dioxide content of the steam.

Sodium bicarbonate also has a yellowing effect on clothes laundered in water containing it, owing to the formation of an oxycellulose when the bicarbonate concentrates under the heat of the iron. The effect is very marked when the sodium bicarbonate alkalinity exceeds 200 ppm; is noticeable above 100 ppm but is unobjectionable below 60 ppm, all expressed as CaCO₃.

In Table 23 are given the analyses of a number of natural water supplies that are high in sodium alkalinity. Most of these are well waters and many of them have a remarkably low hardness. Similar waters have been obtained under known deposits of glauconite (greensand) and it is quite possible that many of these low hardnesses are due to the softening action of zeolite deposits on pocketed or extremely slowly moving ground water.

Sodium salts are objectionable in the processing or manufacture of certain cellulose products, dielectrics, fine drugs and chemicals, synthetic rubber, plastics, photographic materials, silver-plated ware and many other materials. High sodium alkalinity waters are often objectionable in high-pressure steam boilers, laundries and textile plants. Formerly, dis-

tillation was the only process known for removing sodium salts from water. Now sodium bicarbonate may be removed by hydrogen zeolite and the sulfate, chloride, or nitrate by a combination treatment with hydrogen zeolite followed by treatment with an anion exchanger or acid absorbent. The processes for removing sodium salts are described in the following chapters: hydrogen cation-exchange process in Chapter 14, ion-exchange demineralizing process in Chapter 15, and distillation in Chapter 15.


Silica

Silica, in amounts ranging from a fraction of 1 ppm to over 100 ppm, is found in all natural water supplies. In the analyses of rain, hail, and snow, listed in Chapter 1, the silica contents range from 0.1 ppm to 2.8 ppm. In the analyses of various surface and ground waters, listed in the same chapter, the silica contents range from 1 ppm to 107 ppm. Table 24 shows the maximum, minimum, and average silica contents of a group of ninety-eight rivers over a one-year period. It will be noted that these vary over a wide range, the maximum figure ranging from two to forty times the minimum figure.

The above refers to the soluble silica content and not to the silica which may be present in the suspended matter. Suspended matter may be removed from a water supply by coagulation and filtration, but these processes have little effect in reducing the soluble silica content.

Silica is particularly objectionable in modern high-pressure boilers, where it has pronounced scale-forming tendencies. If calcium hardness is present in the boiler salines, the scale formed may be a calcium silicate; if soluble alumina is present, an aluminosilicate scale, such as analcite, may be formed; and under other conditions, the scale may consist almost entirely of silica. These silica scales are usually very hard, glassy, adherent, and difficult to remove. Their thermal conductivities are usually very low and tube failures often occur with even very thin silica scales. Silica is frequently carried over with the steam, forming scale in superheater tubes and on turbine blades. While this action is usually ascribed to mechanical carryover, there is another explanation that has been advanced, namely, that the silica is soluble to a certain extent in high-pressure steam.

In low and moderate pressure steam boilers, silica scale can usually be avoided by maintaining a small excess of phosphate and a ratio of alkalinity to silica of at least 1:1 in the boiler salines. In boilers operated at 600 psi or over, treatment of the make-up water to reduce its silica content is frequently necessary. In fact, many engineers recommend that the silica content of the boiler salines should be below 60 ppm and, in certain cases, even as low as 15 ppm. This is not only to prevent scale in



(From Collins, W. D., U.S. Geol. Survey, Water-Supply Paper 520-F)

Figure 38. Approximate temperature of water from nonthermal wells at depths of 30 to 60 feet.



(From Collins, W. D., U.S. Geol. Survey, Water-Supply Paper 520-F.)
 Figure 38. Approximate temperature of water from nonthermal wells at depths of 30 to 60 feet.

similar decrease of range with depth in North Dakota. . . . From a study of over 3,000 records of temperature of ground water, C. E. Van Ostrand has computed that under normal conditions the temperature of ground water obtained at a depth of 30 to 60 feet will generally exceed by 2° or 3° the mean annual air temperature. In exceptional localities the excess may amount to 5° or 6°. In southern California it may reach 10°.

"After careful examination of the available data relating to increase of earth temperature with depth, a committee of the British Association for the Advancement of Science adopted as the most probable average rate an increase of 1°F for each 64 feet of depth.* On this basis, water from a depth of 640 feet would have a uniform temperature of 10°F above the temperature at 30 or 60 feet. At 200 feet the increase would only be 3°."


Surface Waters. Surface waters are usually subject to large seasonal variations in temperature. In general, with rivers of the United States the difference between winter minimum and summer maximum water temperatures will range from 30 to even as much as 60°F. Winter temperatures of 33 to 36°F are common with river waters over much of the country, and summer temperatures of 75 to 80°F are common and may exceed 85°F. Lakes, ponds, and reservoirs are also subject to seasonal variations in temperature which are particularly wide in range in the shallower waters.

Seawater. At locations where seawater is available, the amounts obtainable are obviously dependent only on the size of intakes, pipe lines, and pumps. Therefore, it is used only once through and then discharged to waste. The annual temperature variations encountered in various locations may cover a range as low as 11° to slightly over 50°F. Location and depth of intake, whether in a bay or fronting the open ocean, currents, etc., will affect the temperature. Minimum winter temperatures may be as low as a couple of degrees Fahrenheit below the freezing point of fresh water and maximum summer temperatures may exceed 80°F.

Scale and Deposits in Cooling Systems

Cooling systems may become clogged with (1) scale, (2) corrosion deposits, (3) sediment, and (4) organic growths.

Scale. The principal scale-forming material in cooling systems is calcium carbonate formed by the decomposition of calcium bicarbonate into calcium carbonate, carbon dioxide, and water, as shown in the following reaction:



In water free from carbon dioxide, calcium carbonate has a very low solubility—about 15 ppm at 32°F and about 13 ppm at 212° or less than

* British Assoc. Adv. Sci. Rept., Fifty-second Meeting, p. 88, 1882.

1 gpg. In water saturated at atmospheric pressure with carbon dioxide at 32°F, 1620 ppm of CaCO₃ (94½ gpg) will dissolve, forming calcium bicarbonate. If this water were boiled for a sufficient length of time, the calcium bicarbonate would decompose to calcium carbonate; the carbon dioxide would all be driven off, and since the solubility of calcium carbonate is only 13 ppm at 212°F, the amount of calcium carbonate deposited would be 1620 - 13 = 1607 ppm (93.7 gpg), which is equivalent to 6.7 tons of scale and sludge per million gallons. Cooling waters, however, are not saturated with carbon dioxide, do not contain 1620 ppm of calcium alkalinity, and are not heated to the boiling point. Very few cooling waters will have calcium alkalinities of more than one-fourth of this maximum figure of 1620 ppm and most cooling waters would have calcium alkalinities under 300 ppm. The amounts of scale that such waters can form in cooling systems are, however, very large and very troublesome even though they never reach, fortunately, more than a fraction of this 6.7 tons per million gallons.

With any specific content of free carbon dioxide there is an equilibrium at each temperature, which establishes the maximum amount of calcium bicarbonate that can be held in solution. Raising this temperature decreases this maximum solubility, the above reaction proceeding toward the right until the equilibrium for the new temperature is reached. From this, it is apparent that with certain waters high in calcium bicarbonate content and low in free carbon dioxide, even a very slight elevation in temperature may be sufficient to form scale.

NOTE: In tropical or semi-tropical climates, scale formation may occur in the cold-water mains. A section of a 4-inch cold-water main, sent to the author from Haiti, was clogged to approximately a 2-inch effective diameter by calcium carbonate scale. In this case, the source of the water was limestone springs in the mountains and the elevation in temperature on flowing through the mains was sufficient to cause this heavy scale formation.

The Langelier index (or calcium carbonate saturation index) is of value in predicting the scale-forming tendencies of a cooling water. In order to calculate the index it is necessary to have (1) the methyl orange alkalinity, (2) the calcium hardness, (3) the total solids (approximately), (4) the pH value and (5) the temperature to which the water will be raised. From these, by using the formulae in Table 70, it is possible to calculate the index and predict the tendencies of a cooling water. These tables were calculated and arranged by the author for field use by non-technical men and will be found simple, rapid, and accurate enough for all practical purposes. In calculating these, the residue-temperature adjustments of Larson and Buswell were taken into consideration. Figures have been rounded off to tenths, which are more accurate than required for cooling purposes.

TABLE 70. DATA FOR RAPID CALCULATIONS OF THE LANGELIER INDEX (CALCIUM CARBONATE SATURATION INDEX)
[Based on the Langelier formula, Larson-Buswell residue, temperature adjustments; arranged by Nordell]

A		C		D	
Total Solids (ppm)	A	Calcium Hardness (ppm of CaCO ₃)	C	M. O. Alkalinity (ppm of CaCO ₃)	D
50-300	0.1	10-11	0.6	10-11	1.0
400-1000	0.2	12-13	0.7	12-13	1.1
		14-17	0.8	14-17	1.2
		18-22	0.9	18-22	1.3
		23-27	1.0	23-27	1.4
		28-34	1.1	28-35	1.5
		35-43	1.2	36-44	1.6
		44-55	1.3	45-55	1.7
		56-69	1.4	56-69	1.8
		70-87	1.5	70-88	1.9
		88-110	1.6	89-110	2.0
		111-138	1.7	111-139	2.1
		139-174	1.8	140-176	2.2
		175-220	1.9	177-220	2.3
		230-270	2.0	230-270	2.4
		280-340	2.1	280-350	2.5
		350-430	2.2	360-440	2.6
		440-550	2.3	450-550	2.7
		560-690	2.4	560-690	2.8
		700-870	2.5	700-880	2.9
		880-1000	2.6	890-1000	3.0

(1) Obtain values of A, B, C and D from above table.

(2) pH_s = (9.3 + A + B) - (C + D).

(3) Saturation index = pH - pH_s.

If index is 0, water is in chemical balance.

If index is a plus quantity, scale-forming tendencies are indicated.

If index is a minus quantity, corrosive tendencies are indicated.

In using the index, a modicum of common sense and practicality are necessary, for the calculated indices are not quantitative, and since the cooling water runs rather rapidly through a cooling system, there is no assurance that calculated equilibria, even if they could be calculated with hair-splitting accuracy, would be reached. In practice, what is done is to use the index as a basis in calculating the treatment required. Then removable lengths of pipe or metal inserts are placed at strategic points and the results are watched. If scale formation is still too heavy, the treatment is adjusted to give a somewhat lower index. If undue corrosion occurs, the treatment is adjusted to give a somewhat higher index.

NOTE: A further extension of Langelier's work may be found in the *Journal of the American Water Works Association*, 38 (1946) pp. 169-178, "Chemical Equilibria in Water Treatment" and pp. 179-185, "Effect of Temperature on the pH of Natural Waters."

16. COLD LIME-SODA WATER-SOFTENING PROCESSES

THE ART of water softening is only a little over a century old, dating back to 1841 when a Scottish Professor of Chemistry in Aberdeen University, Thomas Clark, was granted a patent on "A New Mode of Rendering Certain Waters (including the Thames) Less Impure and Less Hard, for the Supply and Use of Manufactories, Villages, Towns and Cities." Clark's method was to add lime to the water, thus reducing the bicarbonate hardness by precipitation of the calcium alkalinity as calcium carbonate and the magnesium alkalinity as magnesium hydroxide, the added lime being also precipitated as calcium carbonate.

The precipitates were then settled out by plain subsidence and the settled water was either used without further treatment or filtered before use. Clark's process reduced only the bicarbonate hardness, but later John Henderson Porter used soda ash in addition to lime, thus reducing the noncarbonate as well as the bicarbonate hardness. This method of softening water was formerly known as the Porter-Clark process but is now more commonly known as the cold lime-soda process. Clark also established calcium carbonate (in grains per imperial gallon) as the unit of hardness, defining this as follows: "Each degree of hardness is as much as a grain of chalk, or the lime or the calcium in a grain of chalk, would produce in a gallon of water, by whatever means dissolved."

NOTE: As noted by M. N. Baker in "The Quest for Pure Water" (The American Water Works Association, 1948), a book which the author heartily recommends for its wealth of historical data, it had been known for at least a century before Clark's invention, that alkaline salts would soften water. Baker cites Dr. Peter Shaw (1730), Dr. Francis Home (1756), Dr. John Ruttty (1758), Henry Cavendish (1765), Thomas Henry (1781), Edmund Davy (1818), and Abraham Booth (1830) as earlier investigators.

Principles of Operation

In Table 105, the solubilities of the bicarbonates, carbonates, chlorides, hydroxides, and sulfates of calcium, magnesium, and sodium, in terms

of their calcium carbonate equivalents and in ppm and gpg at 32 and 212°F, are given. It will be noted that all the sodium compounds are extremely soluble and that the compounds of calcium and magnesium having the lowest solubilities are calcium carbonate and magnesium hydroxide, which explains why, in the lime-soda processes, the calcium is precipitated as the carbonate and the magnesium as the hydroxide.

TABLE 105. SOLUBILITIES OF CALCIUM, MAGNESIUM AND SODIUM BICARBONATES, CARBONATES, CHLORIDES, HYDROXIDES AND SULFATES

Name	Formula	(ppm of CaCO ₃)		(gpg of CaCO ₃)	
		at 32°F	at 212°F	at 32°F	at 212°F
Calcium bicarbonate	Ca(HCO ₃) ₂	1620	decomp.	94.5	decomp.
Calcium carbonate	CaCO ₃	15	13	0.9	0.8
Calcium chloride	CaCl ₂	336000	554000	19600	32300
Calcium hydroxide	Ca(OH) ₂	2390	888	139	51.8
Calcium sulfate	CaSO ₄	1290	1250	75.3	72.9
Magnesium bicarbonate	Mg(HCO ₃) ₂	37100	decomp.	2170	decomp.
Magnesium carbonate	MgCO ₃	101	75	5.9	4.4
Magnesium chloride	MgCl ₂	362000	443000	21100	25900
Magnesium hydroxide	Mg(OH) ₂	17	8	1.0	0.5
Magnesium sulfate	MgSO ₄	170000	356000	9920	20800
Sodium bicarbonate	NaHCO ₃	38700	decomp.	2260	decomp.
Sodium carbonate	Na ₂ CO ₃	61400	290000	3580	16900
Sodium chloride	NaCl	225000	243000	13100	14200
Sodium hydroxide	NaOH	370000	970000	14200	56900
Sodium sulfate	Na ₂ SO ₄	33600	210000	1970	12300

Calcium, Magnesium, and Sodium Alkalinities. Although the salts in such a dilute solution as water do not exist as such but as ions, it is convenient to picture the bicarbonate radical as bound first to the calcium and second to the magnesium, for this is the order in which precipitation occurs when lime is added to water containing these bicarbonates. That is, calcium carbonate, owing to its low solubility, would first be precipitated. Magnesium carbonate, being roughly about six times as soluble, would not precipitate as the carbonate except for the amount exceeding its solubility. But on continued addition of lime, magnesium hydroxide, which has a very low solubility, would be precipitated next. The sodium salts are all extremely soluble.

Therefore, on inspection of a water analysis, the alkalinity is first calculated as being bound to the calcium and is called "calcium alkalinity." If there is any alkalinity left over, it is calculated as being bound to magnesium and is termed "magnesium alkalinity." With a relatively small number of natural waters, an excess of alkalinity may be present above the

or "negative Alk. C." is below -10 ppm, the dosage of lime should be increased, and if above zero, it should be decreased.

NOTE: The term "negative Alk. C." or "negative caustic alkalinity" is probably peculiar to the water-softening industry. It is based on the following equation yielding a negative result:

$$(2 \times \text{Pht. Alk.}) - \text{M.O. Alk.} = \text{Alk. C.}$$

For instance, if the effluent has a M.O. Alk. of 30 and a Pht. Alk. of 18, it has 6 ppm of Alk. C. or a positive quantity as:

$$(2 \times 18 \text{ ppm}) - 30 \text{ ppm} = 6 \text{ ppm Alk. C.}$$


However, if the effluent has a M.O. Alk. of 30 and a Pht. Alk. of say 13, it would be said to have 4 ppm of negative Alk. C., according to the following:

$$(2 \times 13 \text{ ppm}) - 30 \text{ ppm} = -4 \text{ ppm Alk. C.}$$

Lime and Gypsum Treatment. If the raw water contains sodium bicarbonate, as is the case with a relatively small proportion of natural waters, the calculation for the lime dosage is carried out in the same way, but it is obvious that $H - A$ would be a negative figure, thus indicating that no soda ash were needed except for the 0.25 lb per 1000 gallons excess. In such cases, $A - H$ will indicate the number of ppm of sodium bicarbonate (expressed at CaCO_3) present. In order to obtain this as pounds of Na_2CO_3 present after the lime treatment, the following equation may be used:

$$\frac{A - H}{113} = \text{lb Na}_2\text{CO}_3 \text{ per 1000 gallons}$$

If this Na_2CO_3 figure is less than 0.25 lb per 1000 gallons, the deficiency may be made up by adding whatever fraction of a pound per 1000 gallons of soda ash would be required to make the proper excess. If the result obtained is much above this excess of about 0.25 lb per 1000 gallons, this excess may be reduced to the correct amount by adding the requisite amount of gypsum ($\text{CaSO}_4 \cdot 2\text{H}_2\text{O}$), the reaction being as follows:



As 1 lb of Na_2CO_3 would require 1.62 lb of gypsum, the correction required, for instance, by a water which on lime treatment would yield 0.45 lb of Na_2CO_3 , would be:

$$(0.45 - 0.25) \times 1.62 = 0.32 \text{ lb CaSO}_4 \cdot 2\text{H}_2\text{O per 1000 gallons}$$

Phosphate Treatment. If the hot lime-soda softened water is to have a supplementary treatment with phosphate, as is common practice in

treating feed waters for high-pressure boilers, the excess M.O. alkalinity is usually lower than that given above and the caustic alkalinity is usually carried in the range of 0 to +10 ppm. Adjustment of the lime dosage is then made as follows: if the Alk.C. of the filtered effluent is less than 0 ppm, the dosage of lime is increased; whereas if the Alk.C. is more than 10 ppm, the dosage of lime is decreased. The dosage of soda ash is considered to be right if the total hardness (H) is in the range of 10 to 20 ppm. If H is greater than 20 ppm, the dosage of soda ash is increased; if H is less than 10 ppm, the dosage of soda ash is decreased.

As for the phosphate dosage, if the hardness (H) of the filtered phosphate-treated water is zero and the phosphate content is approximately 5 ppm as PO_4 , the dosage of phosphate is considered to be within the correct range. If H is not zero or if the PO_4 is less than 5 ppm, the phosphate dosage should be increased; if H is zero and the PO_4 is over 5 ppm, the dosage of phosphate should be decreased. As here used, zero means that the total hardness is 2 ppm or less.

The reactions occurring with hydrated lime and soda ash in the hot lime-soda process and also typical reactions for the phosphates and phosphoric acid with the carbonates are given in Table 120. The phosphate reactions are written without including the water of crystallization. For the composition of the various phosphates, see the note under Table 66 in Chapter 6.

Dolomitic Lime or Magnesia. For the calculations of dolomitic lime or magnesia dosages for silica removal by the hot process, see Chapter 18.

Hot Lime-Soda Water Softeners: Types and Designs

Basically, hot lime-soda water softeners may be divided into two main types: (1) the sludge-blanket type and (2) the conventional type. Both these types are available in a number of designs, depending on the degree of deaeration required, whether condensate as well as make-up should be handled (and if so, what percentage of condensate), whether phosphate treatment is required, and whether silica removal is of importance. The sludge-blanket type is the newest type. It was designed primarily for silica removal, as the upward filtration through the sludge blanket uses the silica-removal properties of magnesia much more efficiently than the conventional type. Also, like the sludge-blanket type of cold lime-soda water softener, it utilizes the lime more efficiently and furnishes a clearer effluent. The sludge-blanket type of hot lime-soda water softener is illustrated and described in Chapter 18.

The various forms or designs in which each of these types are available may be grouped as: (1) for 100 per cent make-up and reduction of dissolved oxygen to less than 0.3 ml/liter; (2) for 100 per cent make-up

carbonate have increased the size of the catalyst. Magnesium hydroxide, however, does not form adherent deposits, nor are coagulants of any value in making magnesium deposits adhere. The Spiractor process is therefore largely limited to the removal of calcium.

The detention period in the Spiractor is very much less than in any other type of equipment, as it is only eight to twelve minutes as compared with two to four hours for the conventional type and one hour for the sludge-blanket type. Also, since the by-product is a granular material which drains rapidly to less than 5 per cent of moisture, its disposal is a much simpler matter than that of the usual lime soda sludge, which is a pasty material containing about 90 per cent of water.

In operating the Spiractor, the catalyst bed expands as the granules grow. Since, by the hydraulic grading effected in the equipment, the largest granules are in the bottom, removal of these is effected at periodic intervals by means of a quick-opening type of valve. It is also necessary



Figure 101. Spent spiractor catalyst granule, cut in half to show original particle (center) and surrounding shells of calcium carbonate deposits. Highly magnified.

to add fresh catalyst to the bed from time to time. Roughly, the amount of new catalyst to be added is about 0.043 lb per 1000 gallons per 100 ppm of calcium hardness removed. This figure varies slightly, depending on the amount of free CO_2 present and the amount of lime reacting with magnesium.

In European practice, lime dissolvers are frequently used with the Spiractor, whereas in American practice, a lime slurry is fed. The chemical feeders may be either of the wet or the dry type. Filters are usually required with the catalyst type of softening equipment; they may be either of the gravity or pressure type and the filter medium may be sand, anthracite, or calcite. In general, the catalyst type of lime-soda water softener is best adapted to the softening of water having a hardness composed mostly of calcium salts and a temperature above 50°F . Or, it is of value as a preliminary step preceding a sludge blanket or a conventional type of softener.

Intermittent or Batch-Process Type. Since this type of cold lime-soda water softener is now so seldom used, a very brief description will suffice.

A plant of this type generally consists of three units, and the operations are so staggered that, while the water and chemicals are being mixed in one unit, the next unit is settling and the effluent from the third unit is being drawn off to service.

The usual procedure in operating each unit was to (1) fill the tank with water, (2) add weighed amounts of chemicals and stir thoroughly with a mechanical type of agitator, (3) allow sludge to settle, (4) draw off effluent, and (5) draw off sludge. Excellent results were obtainable when careful dosage and sufficient agitation time were allowed. This type of equipment has practically gone out of existence because of (1) higher cost of equipment, (2) greater space requirements, and (3) greater labor costs.

Results with the Various Cold Lime-Soda (or Chemical-Precipitation) Processes

In Table 105, the solubilities of calcium carbonate and magnesium hydroxide (in terms of CaCO_3 equivalents) in distilled water, free from




Figure 102. Calcium carbonate residuals. Guaranteed maxima.

carbon dioxide, are given. In Figures 102 and 103 the guaranteed removal results for these substances in the cold lime-soda processes are in the form of curves at various alkalinities. It will be noted that the guaran-

usually mounted at floor level to afford the required positive head and prevent flashing on the suction sides of the pumps. The required height of the water level in the settling tank is determined beforehand from the number of feet of head on the suction side of the service pump, specified by the manufacturer, plus some 13 to 15 feet of head to take care of friction losses through the filter bed and piping.




Figure 108. Filter. One unit of a battery, cut away to show interior construction and rotary surface washer.

Chemicals: Reactions and Dosages

Lime and Soda Ash. The principal chemicals used in the hot process are (1) hydrated or chemical lime and (2) soda ash. Hydrated lime of good, average commercial quality will contain approximately 93 per cent of $\text{Ca}(\text{OH})_2$. Chemical lime of good, average commercial quality will contain approximately 90 per cent of CaO ; it should be slaked before use. Soda ash of good, average commercial quality will contain about 99 per cent of Na_2CO_3 and 98 per cent is usually assumed as its purity in making calculations. In practice, the dosages of chemicals required are usually calculated roughly from the above assumptions of

purity and final adjustments in dosages are made according to measurements of the methyl orange alkalinity (M.O. Alk.) and phenolphthalein alkalinity (Pht. Alk.) of the filtered effluent from the hot-process softener.

The approximate dosages of commercial chemicals are calculated as follows:

When A = alkalinity as ppm CaCO_3
 Mg = magnesium hardness as ppm CaCO_3
 H = total hardness as ppm CaCO_3

Hydrated Lime (93% $\text{Ca}(\text{OH})_2$). The number of pounds per 1000 gallons of water treated = $\frac{A + Mg}{151}$.

(Or, if chemical lime (90% CaO) is used, the number of pounds per 1000 gallons of water treated = $\frac{A + Mg}{193}$)

Soda Ash (98% Na_2CO_3). The number of pounds per 1000 gallons of water treated = $\frac{H - A}{111} + \text{required excess (usually 0.25 lb)}$. See Figure 109 for effect of excess soda ash in depressing the hardness.




Figure 109. Hot lime-soda effluent hardness curves. Broken line shows guaranteed results. Solid line shows actual operating results.

If the water is not to be treated further with phosphate, the final adjustments of the chemical dosages are made so that the range of methyl orange alkalinity (M.O. Alk.) in the filtered effluent should be from 20 to 30 ppm, expressed as CaCO_3 , and the caustic alkalinity should range from 0 to -10 ppm, expressed as CaCO_3 . If the M.O. Alk. is below 20 ppm, the dosage of soda ash should be increased; and if above 30 ppm, it should be decreased. If the so-called "negative caustic alkalinity"

TABLE 126. BICARBONATES: ANION AND CATIONS CONVERSION FACTORS

To Convert	To	Multiply by	Bicarbonates anion and cations	To Convert	To	Multiply by
HCO ₃	Ca(HCO ₃) ₂	1.33			Ca(HCO ₃) ₂	HCO ₃
HCO ₃	Mg(HCO ₃) ₂	1.20		Mg(HCO ₃) ₂	HCO ₃	0.834
HCO ₃	NaHCO ₃	1.38		NaHCO ₃	HCO ₃	0.726
Ca	Ca(HCO ₃) ₂	4.05		Ca(HCO ₃) ₂	Ca	0.247
Mg	Mg(HCO ₃) ₂	6.02		Mg(HCO ₃) ₂	Mg	0.166
Na	NaHCO ₃	3.65		NaHCO ₃	Na	0.274

TABLE 127. CARBONATES: ANION AND CATIONS CONVERSION FACTORS

To Convert	To	Multiply by	Carbonates anion and cations	To Convert	To	Multiply by
CO ₃	CaCO ₃	1.67			CaCO ₃	CO ₃
CO ₃	MgCO ₃	1.41		MgCO ₃	CO ₃	0.712
CO ₃	Na ₂ CO ₃	1.77		Na ₂ CO ₃	CO ₃	0.566
Ca	CaCO ₃	2.50		CaCO ₃	Ca	0.400
Mg	MgCO ₃	3.47		MgCO ₃	Mg	0.288
Na	Na ₂ CO ₃	2.30		Na ₂ CO ₃	Na	0.434

TABLE 128. CHLORIDES: ANION AND CATIONS CONVERSION FACTORS

To Convert	To	Multiply by	Chlorides anion and cations	To Convert	To	Multiply by
Cl	CaCl ₂	1.57			CaCl ₂	Cl
Cl	MgCl ₂	1.34		MgCl ₂	Cl	0.745
Cl	NaCl	1.65		NaCl	Cl	0.607
Ca	CaCl ₂	2.77		CaCl ₂	Ca	0.361
Mg	MgCl ₂	3.92		MgCl ₂	Mg	0.255
Na	NaCl	2.54		NaCl	Na	0.393

TABLE 129. HYDROXIDES: ANION AND CATIONS CONVERSION FACTORS

To Convert	To	Multiply by	Hydroxides anion and cations	To Convert	To	Multiply by
OH	Ca(OH) ₂	2.18			Ca(OH) ₂	OH
OH	Mg(OH) ₂	1.72		Mg(OH) ₂	OH	0.583
OH	NaOH	2.35		NaOH	OH	0.425
Ca	Ca(OH) ₂	1.85		Ca(OH) ₂	Ca	0.541
Mg	Mg(OH) ₂	2.40		Mg(OH) ₂	Mg	0.417
Na	NaOH	1.74		NaOH	Na	0.575

TABLE 130. NITRATES: ANION AND CATIONS CONVERSION FACTORS

To Convert	To	Multiply by	Nitrates anion and cations	To Convert	To	Multiply by
NO ₃	Ca(NO ₃) ₂	1.32			Ca(NO ₃) ₂	NO ₃
NO ₃	Mg(NO ₃) ₂	1.19		Mg(NO ₃) ₂	NO ₃	0.838
NO ₃	NaNO ₃	1.37		NaNO ₃	NO ₃	0.730
Ca	Ca(NO ₃) ₂	4.10		Ca(NO ₃) ₂	Ca	0.244
Mg	Mg(NO ₃) ₂	6.10		Mg(NO ₃) ₂	Mg	0.164
Na	NaNO ₃	3.70		NaNO ₃	Na	0.271

TABLE 131. SULFATES: ANION AND CATIONS CONVERSION FACTORS

To Convert	To	Multiply by	Sulfates anion and cations	To Convert	To	Multiply by
SO ₄	CaSO ₄	1.42			CaSO ₄	SO ₄
SO ₄	MgSO ₄	1.25		MgSO ₄	SO ₄	0.798
SO ₄	Na ₂ SO ₄	1.48		Na ₂ SO ₄	SO ₄	0.676
Ca	CaSO ₄	3.40		CaSO ₄	Ca	0.294
Mg	MgSO ₄	4.95		MgSO ₄	Mg	0.202
Na	Na ₂ SO ₄	3.09		Na ₂ SO ₄	Na	0.324

TABLE 132. CARBON DIOXIDE-CARBONATES CONVERSION FACTORS

To Convert CO ₂ to	Multiply by	Reactions (to form carbonates)	To Convert to CO ₂	Multiply by
Ca(OH) ₂	1.68	Ca(OH) ₂ + CO ₂ → CaCO ₃ + H ₂ O	Ca(OH) ₂	0.594
CaO	1.28	CaO + CO ₂ → CaCO ₃	CaO	0.785
Mg(OH) ₂	1.33	Mg(OH) ₂ + CO ₂ → MgCO ₃ + H ₂ O	Mg(OH) ₂	0.754
MgO	0.916	MgO + CO ₂ → MgCO ₃	MgO	1.09
NaOH	1.82	2NaOH + CO ₂ → Na ₂ CO ₃ + H ₂ O	NaOH	0.550
Na ₂ O	1.41	Na ₂ O + CO ₂ → Na ₂ CO ₃	Na ₂ O	0.710

TABLE 133. CARBON DIOXIDE-BICARBONATES CONVERSION FACTORS

To Convert CO ₂ to	Multiply by	Reactions (to form Bicarbonates)	To Convert to CO ₂	Multiply by
CaCO ₃	2.27	CaCO ₃ + CO ₂ + H ₂ O → Ca(HCO ₃) ₂	CaCO ₃	0.440
Ca(OH) ₂	0.842	Ca(OH) ₂ + 2CO ₂ → Ca(HCO ₃) ₂	Ca(OH) ₂	1.19
CaO	0.637	CaO + 2CO ₂ + H ₂ O → Ca(HCO ₃) ₂	CaO	1.57
MgCO ₃	1.92	MgCO ₃ + CO ₂ + H ₂ O → Mg(HCO ₃) ₂	MgCO ₃	0.522
Mg(OH) ₂	0.663	Mg(OH) ₂ + 2CO ₂ → Mg(HCO ₃) ₂	Mg(OH) ₂	1.51
MgO	0.458	MgO + 2CO ₂ + H ₂ O → Mg(HCO ₃) ₂	MgO	2.18
Na ₂ CO ₃	2.41	Na ₂ CO ₃ + CO ₂ + H ₂ O → 2NaHCO ₃	Na ₂ CO ₃	0.415
NaOH	0.909	NaOH + CO ₂ → NaHCO ₃	NaOH	1.10
Na ₂ O	0.704	Na ₂ O + 2CO ₂ + H ₂ O → 2NaHCO ₃	Na ₂ O	1.42

TABLE 134. HYDROCHLORIC ACID CONVERSION FACTORS

To Convert HCl to	Multiply by	Reactions (to form Chlorides)	To Convert to HCl	Multiply by
CaCO ₃	1.37	CaCO ₃ + 2HCl → CaCl ₂ + H ₂ O + CO ₂	CaCO ₃	0.729
Ca(OH) ₂	1.02	Ca(OH) ₂ + 2HCl → CaCl ₂ + 2H ₂ O	Ca(OH) ₂	0.985
CaO	0.769	CaO + 2HCl → CaCl ₂ + H ₂ O	CaO	1.30
CaCl ₂	1.52		CaCl ₂	0.657
MgCO ₃	1.16	MgCO ₃ + 2HCl → MgCl ₂ + H ₂ O + CO ₂	MgCO ₃	0.865
Mg(OH) ₂	0.799	Mg(OH) ₂ + 2HCl → MgCl ₂ + 2H ₂ O	Mg(OH) ₂	1.25
MgO	0.552	MgO + 2HCl → MgCl ₂ + H ₂ O	MgO	1.81
MgCl ₂	1.31		MgCl ₂	0.766
Na ₂ CO ₃	1.45	Na ₂ CO ₃ + 2HCl → 2NaCl + H ₂ O + CO ₂	Na ₂ CO ₃	0.688
NaOH	1.10	NaOH + HCl → NaCl + H ₂ O	NaOH	0.912
Na ₂ O	0.849	Na ₂ O + 2HCl → 2NaCl + H ₂ O	Na ₂ O	1.18
NaCl	1.60		NaCl	0.624
Cl	0.973		Cl	1.03

BETZ HANDBOOK
OF INDUSTRIAL
WATER CONDITIONING

SIXTH EDITION

1962

Published by

BETZ®

TREVOSE, PENNSYLVANIA 19047

SIXTH EDITION—1962

Seventh Printing—May, 1974

Library of Congress Catalog Card Number: 62-21097



Copyright 1962

BETZ LABORATORIES, INC.

TREVOSE, PENNSYLVANIA 19047



All rights reserved. This book, or parts thereof, may not be reproduced in any form without permission of the publisher, except by a reviewer who wishes to quote brief passages in connection with a review written for inclusion in a magazine or newspaper.

Printed in U. S. A.

Acknowledgment

This book was prepared by the engineering and technical staff of Betz Laboratories, Inc. Many individuals contributed to this edition and previous editions. We particularly wish to thank the following for their editorial contributions to this Sixth Edition.

H. L. Boyer	A. J. Piluso
A. B. Cherry	O. H. Preis
R. B. Conlan	M. U. Priester
J. M. Donohue	L. F. Probst
C. M. Frova	R. L. Reed
P. J. Gaughan	J. H. Richards
H. B. Haldeman	C. J. Schafer
R. H. Hayman	J. R. Schieber
J. B. Lord	B. F. Shema
J. J. Maguire	W. A. Tanzola
S. O. Meyer	J. G. Weidman
W. L. Nieland	G. A. Wilhelm
C. A. Noll	

TABLE OF CONTENTS

INDUSTRIAL WATER TREATMENT PROBLEMS AND PROCESSES

<i>Chapter</i>	<i>Page</i>
1. Industrial Water Conditioning	8
2. Water and Its Impurities	12
3. Aeration	18
4. Subsidence	23
5. Coagulation	26
6. Filtration	35
7. Precoat Filtration	42
8. Chlorination	47
9. Hydrogen Sulfide Removal	55
10. Iron Removal and Iron Retention	60
11. Lime-Soda Softening	68
12. Hot Process Phosphate Softening	78
13. Silica Removal By Magnesium Salts	82
14. Sodium Zeolite Softening	88
15. Cation Exchange by Hydrogen Zeolite	95
16. Demineralization	102
17. Dealkalization by Chloride-Anion Exchange	110
18. Hot Lime-Hot Ion Exchange Softening	115
19. Oil Removal	120
20. Deaeration	127
21. Chemical Feed Systems	135
22. Boiler Scale Control	151
23. Boiler Corrosion Control	167
24. Carryover	174
25. Silica Turbine Blade Deposits	182
26. Measurement of Steam Purity	189
27. Condensate Return Line Corrosion	194
28. Embrittlement of Boiler Metal	204
29. Boiler Blowdown Control	210
30. Chemical Cleaning of Boilers	221
31. Cooling Water Treatment: Once-Through Scale Control	229
32. Cooling Water Treatment: Once-Through Corrosion Control	236
33. Cooling Water Treatment: Open Recirculating Scale Control	247
34. Cooling Water Treatment: Open Recirculating Corrosion Control	258

35.	Cooling Water Treatment: Closed Recirculating Systems	270
36.	Pretreatment and On-Stream Cleaning	274
37.	Acid Feeding to Cooling Water Systems	279
38.	Slime and Algae Control	288
39.	Cooling Tower Wood Deterioration	300
40.	Air Conditioning Systems	311
41.	Industrial Waste Treatment	319

CONTROL WATER ANALYSES AND THEIR INTERPRETATION

42.	Methods and Equipment	329
43.	Expression of Analytical Results	335
44.	Acid (Free Mineral)	338
45.	Alkalinity	339
46.	Alkalinity (Hydrate)	343
47.	Ammonia	345
48.	Calcium	347
49.	Carbon Dioxide	349
50.	Chloride	353
51.	Chlorine	356
52.	Chromate	359
53.	Color	363
54.	Conductance (Specific)	365
55.	Hardness	370
56.	Hydrazine	374
57.	Iron	377
58.	Manganese	380
59.	Nitrate	382
60.	Nitrite	384
61.	Oxygen (Dissolved)	386
62.	pH	390
63.	Phosphate	394
64.	Silica	398
65.	Solids (Total, Dissolved, Suspended)	402
66.	Sulfate	404
67.	Sulfite	407
68.	Turbidity	409
69.	Composition of Prepared Reagents	411
	Conversion Factors	415
	Index	417

when the water is heated to the saturation temperature for the pressure imposed on the system. The remaining 5 to 10% of the initial oxygen content must be removed through molecular diffusion. In ridding the system of this last 5 to 10% of the initial oxygen content, it is obvious that the rapidity of oxygen removal will be a function of the heater design and also of the rapidity with which the surrounding atmosphere is changed and gases vented from the system.

The practical considerations involved in the removal of dissolved oxygen from boiler feed water may be briefly summarized as:

- Heating the water to the boiling temperature for the pressure under which the process is conducted (saturation conditions).
- Providing a heater design that secures intimate mixing of steam and water.
- Continuously venting from the system the mixture of gases and steam.

REMOVAL OF CARBON DIOXIDE AND AMMONIA. Unlike oxygen, carbon dioxide and ammonia do not obey Henry's Law because they unite chemically with water. At elevated temperatures their deviation from Henry's Law decreases due to decreased chemical combination with the solvent. The mecha-





Figure 20-1 • Per Cent CO₂ Available for Removal


nism of removal of these gases is primarily molecular diffusion rather than mechanical separation.

When carbon dioxide is dissolved in water it forms a relatively unstable compound, carbonic acid (H₂CO₃). This acid ionizes into the bicarbonate radical (HCO₃⁻) and the hydrogen ion (H⁺). Further ionization of the bicarbonate radical takes place to form the carbonate radical (CO₃⁼) and the hydrogen ion (H⁺) as illustrated.



The hydrogen ion concentration or pH controls the distribution of carbon dioxide among these three forms. It is only in the form of carbonic acid (H₂CO₃) that a gas solution pressure is exerted and that carbon dioxide can be removed by deaeration. Figure 20-1 illustrates the availability of carbon dioxide for removal by deaeration and indicates it is at the more acid pH values that the most efficient removal of carbon dioxide can be obtained.

When ammonia gas is dissolved in water, it forms an unstable compound, ammonium hydroxide (NH₄OH). Ammonium hydroxide ionizes to form the ammonium ion (NH₄⁺) and the hydroxyl ion (OH⁻) as illustrated.



The hydroxyl ion concentration controls the distribution of ammonia between these two forms. It is only in the form of ammonium hydroxide (NH₄OH) that a gas solution pressure is exerted and that ammonia can be removed by deaeration. Figure 20-2




Figure 22-3 • Calcium Solubility, for Calcium Sulfate and Calcium Carbonate

necessary to employ certain factors of safety in interpreting these data. For example, the usual boiler water will contain a variety of salts in solution, tending to alter the theoretical solubilities illustrated. Specifically, in the case of calcium sulfate, an increase in the quantity of sodium sulfate present will lower the calcium sulfate solubility.

Because of the high solubility of calcium sulfate as shown in Figure 22-3 it is relatively simple to introduce chemical treatment to the boiler water and, with proper control, to avoid deposition of calcium sulfate scale.

The use of sodium carbonate (soda ash) was one of the first materials employed to prevent calcium sulfate scale formation. As can be seen from Figure 22-3 calcium carbonate is considerably more insoluble than calcium sulfate and accordingly will be preferentially precipitated. However, calcium carbonate in itself can form a hard adherent deposit and is frequently found as a constituent of boiler scale.

Calcium phosphate and calcium silicate are frequently deposited as boiler scale. Calcium silicate may be formed either from the combination of the calcium and silicate ions naturally present in the boiler feedwater or as a result of the misguided use of sodium silicate as internal chemical treatment. Calcium phosphate, on the other hand, is invariably the result of treatment of the boiler water by the use of the various phosphate

salts commonly employed for this purpose.

Magnesium salts present in the boiler feedwater are usually more easily prevented from forming scale than are the calcium salts. Normally, the magnesium salts found incorporated in boiler scale are magnesium hydroxide, magnesium silicate or magnesium phosphate. The latter salt, magnesium phosphate, tends to form a very sticky deposit, not very hard in nature, but requiring turbinizing for its removal.

SILICA

As mentioned previously, calcium silicate deposits may prove quite troublesome in boiler operation. However, another source of concern is the tendency for silica to form scales of a complex nature, which may or may not include calcium and magnesium in their structure. Particularly in combination with aluminum, silica tends to form complex scales which have been identified by X-ray diffraction methods. Formation of such complex deposits usually occurs in boilers operating at the higher pressures and proper treatment of the boiler water requires the maintenance of both silica and aluminum concentrations at a minimum. Under such operating conditions, the prevention of complex silica scales is primarily a problem for external treatment. The maintenance of high phosphate and alkalinity concentrations in the boiler water is an aid in control of the problem, but only limited silica concentrations can be controlled. Blowdown can be used to reduce silica concentrations to tolerable levels.

The concern for silica is not always because silica concentrations are too high. In some cases, silica can be too low. This situation occurs primarily with waters that contain high magnesium concentrations and low silica values. In these special cases, magnesium will tend to precipitate as magnesium phosphate which produces a sticky sludge. Precipitation in this form is aggravated when the feedwater enters the boiler in a region of low alkalinity and poor circulation. Under these conditions, increasing the silica content

presented by oil contamination of the boiler water. While certain methods of internal treatment may slightly aggravate or slightly minimize the problem caused by oil, there is no method of internal treatment which can be relied upon to cope with any appreciable oil contamination. Since the extent of the difficulties caused by oil are more or less unpredictable, external removal of oil from the boiler feedwater is the only safe policy.

IDENTIFICATION OF SCALE DEPOSITS

In addition to the microscope and gravimetric chemical analyses, a useful tool in identifying boiler scale deposits is the X-ray diffraction method. Any material possessing a crystalline structure will yield a distinctive X-ray pattern which will always be the same and which can be compared with the pattern of standard materials on file. It is thus possible to identify complex chemical compounds and their individual crystalline struc-

Fig. 22-4
Crystalline Scale Constituents, Identified by X-ray Diffraction

NAME	FORMULA
Acmite	$\text{Na}_2\text{O} \cdot \text{Fe}_2\text{O}_3 \cdot 4\text{SiO}_2$
Analcite	$\text{Na}_2\text{O} \cdot \text{Al}_2\text{O}_3 \cdot 4\text{SiO}_2 \cdot 2\text{H}_2\text{O}$
Anhydrite	CaSO_4
Aragonite	CaCO_3
Brucite	$\text{Mg}(\text{OH})_2$
Calcite	CaCO_3
Cancrinite	$4\text{Na}_2\text{O} \cdot \text{CaO} \cdot 4\text{Al}_2\text{O}_3 \cdot 2\text{CO}_2 \cdot 9\text{SiO}_2 \cdot 3\text{H}_2\text{O}$
Hematite	Fe_2O_3
Hydroxyapatite	$\text{Ca}_{10}(\text{OH})_2(\text{PO}_4)_6$
Magnetite	Fe_3O_4
Noselite	$4\text{Na}_2\text{O} \cdot 3\text{Al}_2\text{O}_3 \cdot 6\text{SiO}_2 \cdot \text{SO}_4$
Pectolite	$\text{Na}_2\text{O} \cdot 4\text{CaO} \cdot 6\text{SiO}_2 \cdot \text{H}_2\text{O}$
Quartz	SiO_2
Serpentine	$3\text{MgO} \cdot 2\text{SiO}_2 \cdot 2\text{H}_2\text{O}$
Thenardite	Na_2SO_4
Wollastonite	CaSiO_3
Xonotlite	$5\text{CaO} \cdot 5\text{SiO}_2 \cdot \text{H}_2\text{O}$

ture whereas only the hypothetical structure could be obtained from the usual chemical analysis.




Figure 22-5 • Analysis of Boiler Deposits by X-ray Fluorescence




Figure 33-3 • Solubility of Calcium Carbonate Compared to Calcium Sulfate

Figure 33-4—Typical Analysis of Scales From Open Recirculating Systems

Source	Condenser, %	Pipe Cooler, %
Calcium as CaO	49.79	39.85
Magnesium as MgO	2.42	2.20
Iron as Fe ₂ O ₃	0.61	6.98
Aluminum as Al ₂ O ₃	0.21	0.52
Carbonate as CO ₂	39.00	30.20
Sulfate as SO ₃	1.29	0.50
Silica as SiO ₂	0.15	3.85
Loss on Ignition	6.05	15.00

At 2.0 cycles of concentration, the pHs is 7.3, equivalent to the circulating water pH. Stability Index of 7.3 also indicates a non scaling condition. At two cycles of concentration, calcium carbonate scale would not be expected.

At 3.0 cycles of concentration, a positive Saturation Index of 1.5 is obtained and a Stability Index of 5.3. These values indicate an appreciable tendency toward calcium carbonate scale formation. It would not be safe to exceed 2.0 cycles of concentration with this water, without employing some form of treatment. With organic and inorganic surface active agents, it would be possible to maintain 3.0 cycles of concentration without calcium carbonate scale formation, but this concentration could not be tolerated without such treatment.

Fig. 33-5—Circulating Water Analyses

	Makeup	Circulating Water at 2.0 Cycles	Circulating Water at 3.0 Cycles
Total Hardness as CaCO ₃	60	120	180
Calcium as CaCO ₃	50	100	150
Magnesium as CaCO ₃	10	20	30
P Alkalinity as CaCO ₃	0	0	10
M Alkalinity as CaCO ₃	50	100	150
Sulfate as SO ₄	40	80	120
Chloride as Cl	10	20	30
Silica as SiO ₂	5	10	15
Above values expressed in ppm			
pH	7.0	7.3	8.3
pHs (140F)	7.8	7.3	6.8
Saturation Index	-0.8	0.0	+1.5
Stability Index	8.6	7.3	5.3
Interpretation	Non scale forming	Non scale forming	Scale forming

CRC Handbook of Chemistry and Physics

69TH Edition

1988—1989



Editor-in-Chief

Robert C. Weast, Ph.D.

Associate Editors

Melvin J. Astle, Ph.D.
William H. Beyer, Ph.D.

A Ready-Reference Book of Chemical and Physical Data



CRC Press, Inc.
Boca Raton, Florida

PHYSICAL CONSTANTS OF INORGANIC COMPOUNDS (continued)

Name	Synonyms and Formulae	Mol. wt.	Crystalline form, properties and index of refraction	Density or spec. gravity	Melting point, °C	Boiling point, °C	Solubility, in grams per 100 cc		
							Cold water	Hot water	Other solvents
e5 sulfate	CdSO ₄	208.47	wh. rhomb	4.691 ²⁰	1000		75.5 ⁰	60.8 ¹⁰⁰	i al, acet, NH ₃
e6 sulfate, hydrate	CdSO ₄ ·H ₂ O	226.48	monocl.	3.79 ²⁰	tr 108		s	s	i al
e7 sulfate, hydrate	CdSO ₄ ·7H ₂ O	334.57	col. monocl.	2.48	tr 4		s	s	i al
e8 sulfate hydrate	3CdSO ₄ ·8H ₂ O	769.53	col. monocl.	1.565	tr 41.5		113 ⁰	s	
e9 sulfide	Nat. greenockite, CdS	144.47	yel-or hex.	2.506, 2.529	1750 ^{1000mm}	subl in N ₂ , 980	0.00013 ¹⁸	colloid	s a; v sl s NH ₂ OH
e10 sulfite	CdSO ₃	192.47	cr.		d		sl s		i al; s a, NH ₂ OH
e11 tartrate	CdC ₄ H ₄ O ₄	260.48	wh cr powd.				sl s		s a, NH ₂ OH
e12 telluride	CdTe	240.01	blk. cub.	5.850 ¹⁵	1121	1091	i		i a; d HNO ₃
e13 tungstate	CdWO ₄	360.26	yel cr.				0.05		s NH ₂ OH
Cadmium complexes									
e14 tetramminecadmium perchlorate	[Cd(NH ₃) ₄](ReO ₄) ₂	680.94		3.714 ²⁵					0.037 conc NH ₄ OH
e15 tetrapyridine cadmiumfluosilicate	[Cd(C ₅ H ₅ N) ₄](SiF ₆)	570.89	wh. tricl.	2.282					
Calcium									
e16 acetate	Ca(C ₂ H ₃ O ₂) ₂	158.17	silv wh soft met, cub	1.54	839 ± 2	1484	d to H ₂ + Ca(OH) ₂	d	s a, liq NH ₃ ; sl s al; i bz
e17 acetate, dihydrate	Ca(C ₂ H ₃ O ₂) ₂ ·2H ₂ O	194.20	col cr; 1.55, 1.56, 1.57		d		37.4 ⁰	29.7 ¹⁰⁰	sl s al
e18 acetate, monohydrate	Ca(C ₂ H ₃ O ₂) ₂ ·H ₂ O	176.18	col need.		-1H ₂ O, 84		34.7 ²⁰	33.5 ⁵⁰	
e19 aluminate	CaAl ₂ O ₄ (or CaO·Al ₂ O ₃)	158.04	col need.		d		43.6 ⁰	34.3 ¹⁰⁰	sl s al
e70 aluminate	CaAl ₂ O ₄ (or CaO·Al ₂ O ₃)	158.04	wh monocl, tricl or rhomb; 1.643, 1.665, 1.663	2.981 ²⁵	1600		d		s HCl; i HNO ₃ , H ₂ SO ₄
e71 (tri-)aluminate	Ca ₃ Al ₂ O ₆ (or 3CaO·Al ₂ O ₃)	270.20	wh. cub., 1.710	3.038 ²⁵	d 1535		i		
e72 (tri-)aluminate hexahydrate	3CaO·Al ₂ O ₃ ·6H ₂ O	378.29	col. oct., 1.603	2.52 ²⁰	d 700—800		d		
e73 aluminosilicate	2CaO·Al ₂ O ₃ ·SiO ₂	274.20	col. tetr., 1.669, 1.658	3.048	1590 ± 2				d a
e74 aluminosilicate	Nat. anorthite, CaAl ₃ Si ₂ O ₆ (or CaO·Al ₂ O ₃ ·2SiO ₂)	278.21	wh. tricl., 1.5832	2.765	1551				
e75 orthoarsenate	Ca ₃ (AsO ₄) ₂	398.08	col. amorph powd	3.620	1.455		0.013 ²⁵		
e76 arsenate, trihydrate	Nat. haidingerite, 2CaO·As ₂ O ₅ ·3H ₂ O	396.04	col. rhomb., 1.590, 1.602, 1.638	2.967					
e77 arsenide	Ca ₃ As ₂	270.08	red cr.	3.031 ²⁵	d		d	d	d a; s h HNO ₃
e78 azide	Ca(N ₃) ₂	124.12	col. rhomb. hyg.		-3H ₂ O, 110; exp 144-156		38.1 ⁰	45 ¹⁵	d a; s h HNO ₃ , 0.211 ¹⁶ al; i eth
e79 benzoate	Ca(C ₇ H ₅ O ₂) ₂ ·3H ₂ O	336.36	col. rhomb	1.436	-3H ₂ O, 110		2.7 ⁰	8.3 ⁸⁰	
e80 metaborate	Ca(BO ₂) ₂	125.70	col. flat rhomb pr., 1.550, 1.660, 1.680		1154		sl s		s a, NH ₄ salts; sl s ac a
e81 metaborate, hexahydrate	Ca(BO ₂) ₂ ·6H ₂ O	233.79	col. tetr., 1.520, 1.502	1.88			0.25 ²⁰		
e82 tetraborate	CaB ₄ O ₇	195.32	readily vitrified.		986				
e83 boride	CaB ₆	104.94	blk. cub.	2.3 ³⁰	2235		i	i	s HNO ₃ ; sl s conc H ₂ SO ₄
e84 bromide	CaBr ₂	199.89	col. rhomb need, deliq	3.353 ²⁵	sl d 730	806—812	142 ³⁰	312 ¹⁰⁶	s al, acet, a; sl a NH ₃ , MeOH
e85 bromate	Ca(BrO ₃) ₂ ·H ₂ O	313.90	monocl cr.	3.329	-H ₂ O, 180		v s	v s	
e86 bromide, hexahydrate	CaBr ₂ ·6H ₂ O	307.98	col. hex cr.	2.295	38.2	149	594 ⁰	1360 ²⁵	s al, acet a
e87 butyrate	Ca(C ₄ H ₇ O ₂) ₂ ·3H ₂ O	268.32	col. cr.				s	sl s	
e88 carbide	CaC ₂	64.10	col. tetr., 1.75	2.22	stab 25—447	2300	d	d	
e89 carbonate	Nat. aragonite, CaCO ₃	100.09	col. rhomb., 1.530, 1.681, 1.685	2.930	tr to calcite 520	d 825	0.00153 ²⁵	0.00190 ⁷⁵	s a, NH ₄ Cl
e90 carbonate	Nat. calcite, CaCO ₃	100.09	col. rhomb or hex., 1.6583, 1.4864	2.710 ¹⁸	1339 ¹⁰²⁵	d 898.6	0.0014 ²⁵	0.0018 ⁷⁵	s a, NH ₄ Cl
e91 carbonate, hexahydrate	CaCO ₃ ·6H ₂ O	208.16	col. monocl., 1.460, 1.535, 1.545	1.771 ⁰					
e92 chlorate	Ca(ClO ₃) ₂	206.98	wh cr, hyg.		340 ± 10 (-some O)		s	s	s al, acet
e93 chlorate, dihydrate	Ca(ClO ₃) ₂ ·2H ₂ O	243.01	wh-yelsh, rhomb. or monoc, deliq	2.711	-H ₂ O, 100		177.8 ⁸	v s	s al, acet
e94 perchlorate	(CaClO ₄) ₂	238.98	col cr.	2.651	d 270		188.6 ²⁵	v s	166.2 ²⁵ al; 237.4 MeOH
e95 chloride	CaCl ₂	110.99	col. cub, deliq	2.15 ²⁵	782	>1600	74.5 ²⁰	159 ¹⁰⁰	s al, acet, ace a
e96 chloride aluminate	3CaO·Al ₂ O ₃ ·CaCl ₂ ·10H ₂ O	561.34	col. monocl or hex, hex., 1.550, 1.535	1.892 ¹⁴	-H ₂ O, 105	-8H ₂ O, 350	sl s	d	s a
e97 chloride, dihydrate	CaCl ₂ ·2H ₂ O	147.02	col cr.	0.835			97.7 ⁰	326 ⁶⁰	50 ⁸⁰ al
e98 chloride, hexahydrate	CaCl ₂ ·6H ₂ O	219.08	col. trig, deliq., 1.417, 1.393	1.71 ²⁵	26.92	-4H ₂ O, 30, -6H ₂ O, 200	279 ⁰	536 ²⁰	s al
e99 chloride, monohydrate	CaCl ₂ ·H ₂ O	129.00	col cr, deliq.		260		76.8 ⁰	249 ¹⁰⁰	s al; i acet
e100 chloride fluoride orthophosphate	3Ca ₃ (PO ₄) ₂ ·CaClF	1025.08	col cr., 1.634, 1.631	3.14	1270		v sl s		
e101 chlorite	Ca(ClO ₂) ₂	174.98	wh. cub.	2.71			d	d	i al
e102 hypochlorite	Ca(ClO) ₂	142.98	wh powd or flat pl., 1.545, 1.69	2.35	d 100		s		i al

CORROSION BASICS

An Introduction

National Association of Corrosion Engineers

Published by

National Association of Corrosion Engineers
1440 South Creek Drive
Houston, Texas 77084

Library of Congress Catalog Card Number: 84-061042
ISBN 0-915567-02-4

Neither the National Association of Corrosion Engineers, its officers, directors, nor members thereof accept any responsibility for the use of the methods and materials discussed herein. No authorization is implied concerning the use of patented or copyrighted material. The information is advisory only and the use of the materials and methods is solely at the risk of the user.

Printed in the United States. All rights reserved. Reproduction of contents in whole or part or transfer into electronic or photographic storage without permission of copyright owner is expressly forbidden.

Copyright 1984
National Association of Corrosion Engineers

CONTENTS

Introduction	i
Chapter 1 — Scope and Language of Corrosion	3
<p>This chapter offers a general overview of corrosion and the reasons for studying it. A glossary of corrosion-related terms is included.</p>	
Chapter 2 — Basics of Corrosion	23
<p>Corrosion reactions are presented in the most basic terms. The influence of various factors on the initiation and advancement of corrosion in aqueous systems is discussed. This is the most important chapter.</p>	
Chapter 3 — Metallurgy	49
<p>This chapter discusses the effects of metal structure, alloying elements, mechanical working, and heat treatment on corrosion behavior.</p>	
Chapter 4 — Materials	69
<p>The properties of a wide variety of materials (alloys and nonmetals) are compared with regard to corrosion resistance and mechanical properties.</p>	
Chapter 5 — Localized Corrosion	93
<p>Concentrated attack in the form of pitting, erosion, cavitation, fretting, deposition corrosion, corrosion fatigue, and dealloying is presented in this chapter.</p>	
Chapter 6 — Environmental Cracking	111
<p>The factors involved is stress corrosion, hydrogen embrittlement, and liquid metal embrittlement are defined, and the metals susceptible to attack in specific environments are enumerated.</p>	
Chapter 7 — Inhibitors	127
<p>Anodic, cathodic, and filming inhibitors are discussed along with oxygen scavengers as means of reducing corrosion in aqueous and nonaqueous systems. Mechanisms of inhibition and examples of many practical applications are cited.</p>	
Chapter 8 — Corrosion by Water and Steam	149
<p>Factors affecting corrosion of various materials in fresh water, soft water, boiling H₂O reactors, and superheated steam are discussed in this chapter. Several kinds of corrosion are discussed, as well as action of inhibitors and bacteria.</p>	
Chapter 9 — Cathodic Protection	179
<p>An easy-to-understand chapter on the present-day factors in practical cathodic protection practices and important design features.</p>	

Chapter 10 — Underground Corrosion	203
<p>Certain electrochemical aspects of corrosion are described here, together with an excellent description of how underground corrosion is controlled in various types of soil environments using various techniques.</p>	
Chapter 11 — Atmospheric Corrosion	221
<p>This chapter summarizes metal behavior in air atmospheres throughout the world and especially in the more corrosive areas where heavy industry and salt spray may be present. Preventive measures are discussed briefly.</p>	
Chapter 12 — Coatings	245
<p>The testing, selection, application, and use of organic and inorganic coatings for use in the atmosphere or as linings are described with emphasis on surface preparation and the function of the coating material.</p>	
Chapter 13 — High-Temperature Corrosion	275
<p>This chapter covers the broad field of high-temperature corrosion, including air, flue gases, molten salts and metals, vacuum, etc. It also gives some attention to mechanical properties at high temperatures.</p>	
Chapter 14 — Testing and Inspection	309
<p>The many methods of testing for corrosion and measuring corrosion rates are described and evaluated. Necessary precautions and parameters to watch for in evaluating test results are given.</p>	
Chapter 15 — Design and Failure Analysis	337
<p>Some common sense design features for industrial process equipment are presented with a discussion of problems that occur when these precautions are ignored. A brief description of practical ways of combatting various types of corrosion is also presented. Economic considerations are emphasized.</p>	

INTRODUCTION

This book was originally issued as the *Basic Corrosion Course* in 1970. The utility of that publication can be appreciated when it is realized that 13 printings were necessary to supply the great number of persons interested in the subject.

As envisioned by the Editor in the Introduction of the original book, some revision is necessary with the passage of time. This has been accomplished with a minimum of change from the initial format and material content of the original. The authors of the first edition provided such an excellent coverage of the subject matter that only some rearrangement of the text and updating has been necessary.

Those responsible for the topical matter of the first edition were as follows:

Editor	A. deS. Brasunas
Scope of the Subject	A. deS. Brasunas and N. E. Hamner
Basics	F. L. LaQue and N. D. Greene
Metallurgy	R. F. Hochman
Materials	M. G. Fontana and J. H. Peacock
Localized Corrosion	H. P. Godard
Stress Corrosion Cracking	H. L. Logan
Cathodic Protection and Soils	A. W. Peabody and M. E. Parker
Inhibitors	N. Hackerman and E. S. Snavely
Atmospheric Corrosion	K. G. Compton
Coatings	N. E. Hamner
High Temperature Corrosion	A. deS. Brasunas and J. J. Moran, Jr.
Water Corrosion	W. E. Berry
Testing	B. W. Lifka and F. L. McGeary
Failure Analysis	E. D. Verink

A great amount of the material written by these authors has been retained. Changes have been made where it was believed a better continuity, less repetition, and more recent data would improve the development of the subject. Those responsible for the revisions are C. P. Dillon, J. S. Snodgrass, L. S. Van Delinder, and H. A. Webster.

This book provides a general coverage of the wide field of corrosion control. It is designed to be helpful to those being initiated into the work, and consequently attempts to present each corrosion process or control procedure in the most basic terms. A comprehensive discussion of the topics has not been attempted. Certainly the book is not represented as providing the latest or most erudite discussion of the subject. Yet for those knowledgeable in the field of corrosion control, we hope that each chapter presents some aspect of the work in terms that are stimulating and helpful. We solicit suggestions for improvement of the work.

To assist the reader, a bibliography is provided at the end of each chapter for those who may want to pursue a topic further. Many of the books which are listed in more than one chapter are obviously regarded as prime sources for corrosion information. The appendix to Chapter 1 contains a list of definitions of corrosion-related terms. A comprehensive and thoroughly cross referenced subject index is located in the back of the book and should provide a ready guide for all persons wishing to find specific items.

Education in corrosion control is our primary concern. We sincerely hope this new edition will contribute even more capably in attaining that goal. As with the preponderance of the first edition, a portion of the Introduction must be repeated: "We trust that ... this book will be of considerable benefit to the nation, to numerous industries, and to individuals all over the world who will take advantage of the opportunity afforded them by this educational effort."

L. S. Van Delinder
Editor and Chairman of Subcommittee ETC-1
NACE Education and Training Committee
May, 1984

centuate pitting at pores, cracks, or other voids in the film. If the film attains any significant thickness, the loss of heat transfer through the metal and deposited scale can be a problem in certain applications. Thus, the development of scales on metal surfaces is an important consideration when using metals in waters.

The factors that affect scaling (*i.e.*, the deposition of primarily calcareous deposits) are the total dissolved solids, calcium ion concentration, methyl orange alkalinity (bicarbonates and carbonates), and temperature. Calcium and magnesium carbonates have an inverse solubility with temperature, therefore they tend to deposit scale with rising temperature. In extreme cases, scaling by insoluble calcium sulfate also can be a problem, although it is not a prevalent one under most conditions.

The tendency of a water to deposit such scale, or of the temperature required to initiate such deposition to exist, can be estimated from the Langelier-Ryznar Index, as shown in Table 8.2. From the relationship between the controlling factors, one can estimate the pH_s (*i.e.*, the pH which the water in question would acquire if saturated with calcium carbonate). This can then be used to calculate either the Corrosion Index (which indicates the corrosivity to ordinary cement or concrete), the Saturation Index, or (by substituting the measured pH for the pH_s) the temperature at which deposition will be initiated (Table 8.3).

The effect of oxygen on corrosion with increasing temperature is also shown in Figure 8.2, in-

TABLE 8.2 — Scaling by Water

Corrosion Index = pH - pH _s		Where 0 indicates balanced conditions, + indicates scale formation - indicates scale dissolution or corrosion			
Stability Index = 2 pH _s - pH		Where values greater than 7.5 indicate increasing corrosivity			
pH _s = (9.3 + A + B) - (C + D)					
Total Solids	A	Ca as CaCO ₃	C	M.O. Alk.	D
50-330	0.1	10-11	0.6	10-11	1.0
400-1000	0.2	12-13	0.7	12-13	1.1
		14-17	0.8	14-17	1.2
Temp. °F	B	18-22	0.9	18-22	1.3
		23-27	1.0	23-27	1.4
32-34	2.6	28-34	1.1	28-35	1.5
36-42	2.5	35-43	1.2	36-44	1.6
44-48	2.4	44-45	1.3	45-55	1.7
50-56	2.3	56-69	1.4	56-69	1.8
58-62	2.2	70-87	1.5	70-88	1.9
64-70	2.1	88-110	1.6	89-110	2.0
72-80	2.0	111-138	1.7	111-139	2.1
82-88	1.9	139-174	1.8	140-176	2.2
90-98	1.8	175-220	1.9	177-220	2.3
100-110	1.7	230-270	2.0	230-270	2.4
112-122	1.6	280-340	2.1	280-340	2.5
124-132	1.5	350-430	2.2	360-440	2.6
134-146	1.4	440-450	2.3	450-550	2.7
148-160	1.3	560-600	2.4	560-590	2.8
162-178	1.2	700-870	2.5	700-880	2.9
178-194	1.1	880-1000	2.6	890-1000	3.0
194-210					

NOTE: Use actual pH of water when calculating "B," the temperature at which the water will cause scale

TABLE 8.3 — Calculation of Scaling Temperature

Conditions:

$$\begin{aligned}
 \text{pH} &= 7.5 & \text{A} &= 0.1 \\
 \text{TDS} &= 300 \text{ ppm} & \text{C} &= 1.3 \\
 \text{Ca} &= 45 \text{ ppm} & \text{D} &= 2.1 \\
 \text{M.O. Alk.} &= 120 \text{ ppm} & & \\
 \\
 \text{B} &= \text{pH} - 9.3 - \text{A} + \text{C} + \text{D} \\
 &= 7.5 - 9.3 - 0.1 + 1.3 + 2.1 \\
 &= 10.9 - 9.4 \\
 &= 1.5 \\
 &= 1.5 \quad 132 \text{ F or } 55 \text{ C}
 \end{aligned}$$




FIGURE 8.2 — Effect of oxygen on corrosion of steel.

dicating the results in a closed versus an open container (the latter permitting natural deaeration by ebullition). In a closed vessel, corrosion continues to increase with temperature, whence the requirement for removing dissolved oxygen from hot water systems and boilers.

The effect of oxygen and pH is shown in Figure 8.3. In a broad range of about pH 5 to 9, the corrosion rate can be expressed simply in terms of the amount of dissolved oxygen present (*e.g.*, μm/y




FIGURE 8.3 — Effect of pH and O₂ on the corrosion of steel.

DATA BOOK

*for practicing engineers
and those who work with
Water, Wastewater Treatment,
Pollution Control and Water Reclamation.*

Sixteenth Printing

Compiled by

THE PERMUTIT COMPANY, INC.

a subsidiary of Zurn Industries, Inc.

30 Technology Drive, Warren, NJ 07059

Telephone: 908/668-1700, FAX: 908/668-1393

Property of

INTRODUCTION

The basic inventions, processes and patents introduced by The Permutit Company are the foundations of a great part of all modern water and wastewater treatment technology. These include:

- The Cation Exchange Water Softening Process
- Sea Water Regeneration of Ion Exchangers
- Continuous Automatic Water Softening
- Fluoride Removal
- Ion Exchange for Isotope Separation (Uranium Refining)
- Water Clarification by Solids Contact Separation
- Anion Exchange Resins
- Silica Removal Process
- Three Step Demineralizing
- Water Softening by Catalytic Precipitation
- The Automatic Valveless Gravity Filter
- Double Dish Underdrain Systems
- Triad Bed Ion Exchange
- Chevron Shaped High Rate Tube Settlers
- Progressive Mode Continuous Ion Exchange
- Calex Condensate Treatment Process
- Sulfex Heavy Metals Removal Process

This innovative posture is an integral part of Permutit's philosophy today.

The Permutit Company was incorporated in 1913. In the eight decades since 1913, Permutit, consistent with its origins in research and innovative growth, has pioneered in virtually every aspect of water and wastewater treatment. The Company is expert in clarification, filtration, aeration, deaeration, degasification, dewatering, separation and reverse osmosis as well as all phases of ion exchange. Permutit also offers unique experience in providing integrated controls for all of the process equipment it builds. Its current integrated facilities/headquarters are in Warren, New Jersey.

Advice from Permutit experts on water treatment and waste treatment problems is available to you and your consultants. Analyses of water samples will be made by arrangement with the Permutit Technical Department. Subsequently, equipment, standard or custom design, may be specified to meet your specific requirements.

TABLE OF CONTENTS

I. WATER DATA

General

<i>Section</i>	<i>Subject</i>	<i>Page</i>
1	Water Equivalents	2
2	Tank Capacities, vertical — cylindrical	2
3	Pressure Equivalents	6
4	Impurities in Water, systems of expressing; conversion table	6
5	Water Analysis, conversion table for units employed; equivalents	7
6	Parts per Million to Grains per U.S. Gallon	8
7	Grains per U.S. Gallon \longleftrightarrow Pounds per 1000 Gallons	9
8	Parts per Million \longleftrightarrow Pounds per 1000 Gallons	9
9	Boiler Feedwater Makeup Requirements	10
10	Temperature Conversion Examples	12
11	Requirements in U.S. gpm for Boiler Feedwater	13
12	Saturated Steam Table	14
13	Solubility of Oxygen, from air in water at atmospheric pressure	16
14	Solubility of Air in Water at Atmospheric Pressure	17
15	Solubility of Gases in Water at 760 mm	18
16	Properties of Water, conversion for Specific Gravity, Density and Head of Water at various temperatures	19
17A	Water Quality: Electrolyte Content and Specific Conductivity of Water vs. Specific Resistance at 25°C	20
17B	Conductivity Factors of Ions Commonly Found in Water	21
17C	Proposed Specification for Electronic Grade Water E-1	21
17D	Filtration Spectrum	22
18	Pump Power Requirements	23
19	Friction of Water in Pipes (Standard Weight Steel)	24
20	Hydraulic Conversion Factors for Various Types of Pipes	26
21	Friction Loss in Pipe Fittings (as equivalent feet of straight pipe)	28
22	Flow from Vertical Pipe	28
23	Frictional Resistance to Flow of Water, Saunders Patent valves, expressed as loss of head in feet of water	29
24	Discharge of Pipes in gpm — ¾" to 6"	30
25	Drain Pipes, Carrying Capacities in gpm — 3" to 18"	31
26	Backwash Flows, vertical rise \longleftrightarrow gpm flow	31
27	Rectangular Weir Table, for weirs with free discharge into atmosphere	32
28A	Discharge from Triangular Notch Weir with End Contractions	36
28B	Discharge from Rectangular Weir with End Contractions	37

II. PIPES AND FITTINGS

29A	"Standard Weight" Welded and Seamless Steel Pipe	38
29B	American Standard Steel Pipe Flanges	39
30	Resistance of Valves and Fittings to Flow of Fluids	40
31	General Dimensions, ANSI Standard Steel Pipe Flanges	41

TABLE of CONTENTS (cont.)

<i>Section</i>	<i>Subject</i>	<i>Page</i>
32	Economical Pipe Sizes for Pressure Mains	42
33	Pressure Drop in Steam Piping	43
34	Orifice Table for orifice board controls	44
35	Dimensions of Screwed Fittings	48
36A	Pressure Loss through Multiport Valves Size 2" & 3", Unlined — Design 5	49
36B	Pressure Loss through Multiport Valves Size 4" & 6", Unlined — Design 5	50
36C	Pressure Loss through Multiport Valves Size 2" & 3", Plastic Lined — Design 5	51
36D	Pressure Loss through Multiport Valves Size 4" & 6", Plastic Lined — Design 5	52
37A	Head Loss through Disc Meters — 5/8" - 2"	53
37B	Head Loss through Turbo Meters — 2" - 6"	53
III. CHEMICAL PROPERTIES AND DATA		
38	International Atomic Weights Table	54
39A	Galvanic Series of Metals and Alloys	56
39B	Formulae, Atomic, Molecular and Equivalent Weights and Conversion Factors to CaCO ₃ of substances frequently appearing in the chemistry of water treatment	57
40	Coagulant, Acid and Sulfate, 1 ppm Equivalents	61
41	Alkali and Lime, 1 ppm Equivalents	61
42	Sulfuric, Hydrochloric Acid Equivalents	61
43	Salt and Brine Equivalents	61
44	Chemicals Used in Water Treatment	62
45	Sodium Chloride Solutions	69
46	Specific Gravities (at 20°/4°C)	70
46	Regenerant Solution, Temp. Increase H ₂ SO ₄ Dilution	76
47	Sodium Cation Exchanger Reactions	78
48	Hydrogen Cation Exchanger Reactions	79
49	Anion Exchanger Reactions (weakly basic-strongly basic exchangers)	80
50	Removal and Recovery (Ion Exchange Reactions)	81
51	Cold Lime (or Lime-Soda) Water Softening processes as carried out in the Permutit Precipitator	82
52	Solubilities of Calcium Carbonate-pH values	84
53	Solubilities of Magnesium Hydroxide-pH values	85
54	Dosages and Effects of Coagulants: Modified Water Analysis; definition of terms	86
55	Reduction of Calcium Alkalinity by the Cold Lime process	87
56	Reduction of Calcium and Magnesium Alkalinities by the Cold Lime process	88

TABLE of CONTENTS (cont.)

<i>Section</i>	<i>Subject</i>	<i>Page</i>
57	Reduction of Alkalinity and Noncarbonate Hardness by the Cold Lime-Soda process	90
58	Reduction of Alkalinity in Waters Containing Sodium Alkalinity by the Cold Lime, Calcium Chloride (or Sulfate) process	95
59	Chemical Reactions in Cold Lime, Lime-Soda and Calcium Chloride processes	97
60	Hot Lime-Soda Chemical Charges	99
61	Hot Lime-Soda Effluent Curve	100
62	Sodium Sulfite dosages for dissolved oxygen	100
63	Ferrous Sulfate dosages for dissolved oxygen	102
64	Phosphate Treatment of Boiler Feedwaters; amounts of di-sodium phosphate required	103
65	Phosphate Conversion Factors	105
66	Bicarbonates and Carbonates; reactions on heating	105
67	Phosphate Reactions	106
68	Coagulation Reactions	107
69	Oxidation and Reduction Reactions	107
70	Purification by Dilution	108
71	The Alkalinity Relationships	108
72	Effect of Bicarbonate Alkalinity and CO ₂ on pH	109
73	Effect of Mineral Acidity on pH	109
74	Effect of Carbonate and Bicarbonate Alkalinity on pH	110
75	Stability Indexes; CaCO ₃ Saturation Index (Langelier Index), Ryznar Stability Index	111

IV. MISCELLANEOUS

76	Motor Wiring at Standard Speeds	114
77	Standard NEMA Enclosures	117
78	Fundamental Data Relating to Sieves of the Standard Screen Scale	118
79	Weights and Measures — miscellaneous	120
80	Equivalent Weights and Measures — miscellaneous	121
81	English to Metric — Conversion Factors	122

V. WASTE TREATMENT DATA

82	Water Requirements	126
83	Aeration	127
84	Saturation of Oxygen In Pure Water at Various Temperatures	128
85	Usage of Treatment Chemicals	131
86	Addition of Flocculant and Flocculant Aid Solutions	135
87	Sludge Production	136

TABLE OF CONTENTS (cont.)

<i>Section</i>	<i>Subject</i>	<i>Page</i>
88	Sludge Dewatering and Concentration	137
89	Sludge Carrying Capacity for Conveyors	138
90	Heavy Metals Removal	139
VI.	INDEX	140

SECTION 15. SOLUBILITY OF GASES IN WATER AT 760 MM

a, the absorption coefficient, is the volume of gas when reduced to 0° and 760 mm., absorbed by one volume of water when the pressure of the gas itself, without the aqueous tension, amounts to 760 mm.

q is the weight of gas in grams dissolved in 100 grams of water when the total pressure (i.e., the sum of the partial pressure of the gas plus the aqueous tension at the given temperature) is 760 mm.

Temp. C	Nitrogen*		Oxygen		Hydrogen		Carbon Dioxide	
	a	q	a	q	a	q	a	q
0	0.02354	0.002942	0.04889	0.006945	0.02148	0.0001922	1.713	0.3346
1	0.02297	0.002869	0.04758	0.006756	0.02126	0.0001901	1.646	0.3213
2	0.02241	0.002798	0.04633	0.006574	0.02105	0.0001881	1.584	0.3091
3	0.02187	0.002730	0.04512	0.006400	0.02084	0.0001862	1.527	0.2978
4	0.02135	0.002663	0.04397	0.006232	0.02064	0.0001843	1.473	0.2871
5	0.02086	0.002600	0.04287	0.006072	0.02044	0.0001824	1.424	0.2774
6	0.02037	0.002537	0.04180	0.005918	0.02025	0.0001806	1.377	0.2681
7	0.01990	0.002477	0.04080	0.005773	0.02007	0.0001789	1.331	0.2599
8	0.01945	0.002419	0.03983	0.005632	0.01989	0.0001772	1.282	0.2492
9	0.01902	0.002365	0.03891	0.005498	0.01972	0.0001756	1.237	0.2403
10	0.01861	0.002312	0.03802	0.005368	0.01955	0.0001740	1.194	0.2318
11	0.01823	0.002263	0.03718	0.005246	0.01940	0.0001725	1.154	0.2239
12	0.01786	0.002216	0.03637	0.005128	0.01925	0.0001710	1.117	0.2165
13	0.01750	0.002170	0.03559	0.005014	0.01911	0.0001696	1.083	0.2098
14	0.01717	0.002126	0.03486	0.004906	0.01897	0.0001682	1.050	0.2032
15	0.01685	0.002085	0.03415	0.004802	0.01883	0.0001668	1.019	0.1970
16	0.01654	0.002045	0.03348	0.004703	0.01869	0.0001654	0.985	0.1903
17	0.01625	0.002006	0.03283	0.004606	0.01856	0.0001641	0.956	0.1845
18	0.01597	0.001970	0.03220	0.004514	0.01844	0.0001628	0.928	0.1789
19	0.01570	0.001936	0.03161	0.004426	0.01831	0.0001616	0.902	0.1737
20	0.01545	0.001901	0.03102	0.004339	0.01819	0.0001603	0.878	0.1688
21	0.01522	0.001869	0.03044	0.004252	0.01806	0.0001588	0.854	0.1640
22	0.01498	0.001838	0.02988	0.004169	0.01792	0.0001575	0.829	0.1590
23	0.01476	0.001809	0.02934	0.004087	0.01779	0.0001561	0.804	0.1540
24	0.01454	0.001780	0.02881	0.004007	0.01766	0.0001548	0.781	0.1493
25	0.01434	0.001751	0.02831	0.003931	0.01754	0.0001535	0.759	0.1449
26	0.01413	0.001724	0.02783	0.003857	0.01742	0.0001522	0.738	0.1406
27	0.01394	0.001698	0.02736	0.003787	0.01731	0.0001509	0.718	0.1366
28	0.01376	0.001672	0.02691	0.003718	0.01720	0.0001496	0.699	0.1327
29	0.01358	0.001647	0.02649	0.003651	0.01709	0.0001484	0.682	0.1292
30	0.01342	0.001624	0.02608	0.003588	0.01699	0.0001474	0.665	0.1257
35	0.01256	0.001501	0.02440	0.003315	0.01666	0.0001425	0.592	0.1105
40	0.01184	0.001391	0.02306	0.003082	0.01644	0.0001384	0.530	0.0973
45	0.01130	0.001300	0.02187	0.002858	0.01624	0.0001341	0.479	0.0860
50	0.01088	0.001216	0.02090	0.002657	0.01608	0.0001287	0.436	0.0761
60	0.01023	0.001052	0.01946	0.002274	0.01600	0.0001178	0.359	0.0576
70	0.00977	0.000851	0.01833	0.001856	0.0160	0.000102		
80	0.00958	0.000660	0.01761	0.001381	0.0160	0.000079		
90	0.0095	0.00038	0.0172	0.00079	0.0160	0.000046		
100	0.0095	0.00000	0.0170	0.00000	0.0160	0.000000		

* Atmospheric Nitrogen 98.815% Vol. N₂ + 1.185% Vol. A



SECTION 75. STABILITY INDEXES

CaCO₃ SATURATION INDEX (LANGELIER INDEX)

(Based on the Langelier Formula: Larson—Buswell: Residue—Temperature Adjustments: Arranged by Nordell)

1. $pH_s = (9.30 + A + B) - (C + D)$
(NOTE: Values of A, B, C & D are obtained from tables A, B, C & D)
2. Saturation Index = $pH - pH_s$.
If index is 0, water is in chemical balance.
If index is a plus quantity, scale forming tendencies are indicated.
If index is a minus quantity, corrosive tendencies are indicated.

Example: To find the saturation index at 124° F. of water which has the following characteristics: Total solids—400 ppm; calcium hardness as CaCO₃—240 ppm; alkalinity as CaCO₃—196 ppm; and pH of 7.2. Then:

Total solids 400 ppm = 0.16 (from table A)
 Temperature 124° F. = 1.53 (from table B)
 Calcium hardness as CaCO₃ 240 ppm = 1.98 (from lower table C)
 Alkalinity as CaCO₃ 196 ppm = 2.29 (from upper table D)
 Substituting: $pH_s = (9.30 + 0.16 + 1.53) - (1.98 + 2.29) = 6.72$ (or 6.7)
 Saturation Index = $7.2 - 6.7 = +0.5$

A
Total Solids in ppm

50	.07
75	.08
100	.10
150	.11
200	.13
300	.14
400	.16
500	.18
600	.19
1000	.20
2000	.23
3000	.25
4000	.26
5000	.27
6000	.28

B
Temperatures in degrees Fahrenheit

		UNITS				
		0	2	4	6	8
TEMPERATURE	30		2.60	2.57	2.54	2.51
	40	2.48	2.45	2.43	2.40	2.37
	50	2.34	2.31	2.28	2.25	2.22
	60	2.20	2.17	2.14	2.11	2.09
	70	2.06	2.04	2.03	2.00	1.97
	80	1.95	1.92	1.90	1.88	1.86
	90	1.84	1.82	1.80	1.78	1.76
	100	1.74	1.72	1.71	1.69	1.67
	110	1.65	1.64	1.62	1.60	1.58
	120	1.57	1.55	1.53	1.51	1.50
	130	1.48	1.46	1.44	1.43	1.41
	140	1.40	1.38	1.37	1.35	1.34
150	1.32	1.31	1.29	1.28	1.27	
160	1.26	1.24	1.23	1.22	1.21	
170	1.19	1.18	1.17	1.16		

C
Calcium hardness expressed as ppm CaCO₃
(For 3 to 209 ppm CaCO₃, use upper table)
(For 210 to 990 ppm CaCO₃, use lower table)

		UNITS									
		0	1	2	3	4	5	6	7	8	9
TENS	0	0.00	0.64	0.68	0.72	0.75	0.78	0.81	0.83	0.86	0.88
	10	0.90	0.92	0.94	0.96	0.98	1.00	1.02	1.03	1.05	1.06
	20	1.08	1.09	1.11	1.12	1.13	1.15	1.16	1.17	1.18	1.19
	30	1.20	1.21	1.23	1.24	1.25	1.26	1.27	1.28	1.29	1.29
	40	1.30	1.31	1.32	1.33	1.34	1.35	1.36	1.37	1.37	1.37
	50	1.38	1.39	1.39	1.40	1.41	1.42	1.42	1.43	1.43	1.44
	60	1.45	1.45	1.46	1.47	1.47	1.48	1.48	1.49	1.49	1.50
	70	1.51	1.51	1.52	1.52	1.53	1.53	1.54	1.54	1.55	1.55
	80	1.56	1.56	1.57	1.57	1.58	1.58	1.58	1.59	1.59	1.60
	90	1.60	1.61	1.61	1.61	1.62	1.62	1.63	1.63	1.64	1.64
	100	1.64	1.65	1.65	1.66	1.66	1.66	1.67	1.67	1.67	1.68
	110	1.68	1.68	1.69	1.69	1.70	1.70	1.70	1.71	1.71	1.71
	120	1.72	1.72	1.72	1.73	1.73	1.74	1.74	1.74	1.74	1.75
	130	1.76	1.76	1.76	1.76	1.76	1.77	1.77	1.77	1.77	1.78
	140	1.78	1.78	1.78	1.79	1.79	1.79	1.80	1.80	1.80	1.80
	150	1.81	1.81	1.81	1.81	1.82	1.82	1.82	1.83	1.83	1.83
	160	1.83	1.84	1.84	1.84	1.84	1.85	1.85	1.85	1.86	1.86
	170	1.86	1.86	1.86	1.86	1.87	1.87	1.87	1.87	1.88	1.88
	180	1.88	1.88	1.89	1.89	1.89	1.89	1.89	1.90	1.90	1.90
190	1.90	1.91	1.91	1.91	1.91	1.91	1.92	1.92	1.92	1.92	

D
Alkalinity expressed as ppm CaCO₃
(For 1 to 209 ppm CaCO₃, use upper table)
(For 210 to 990 ppm CaCO₃, use lower table)

		UNITS									
		0	1	2	3	4	5	6	7	8	9
TENS	0	0.00	0.30	0.48	0.60	0.70	0.78	0.85	0.90	0.95	
	10	1.00	1.04	1.06	1.11	1.15	1.18	1.20	1.23	1.26	
	20	1.30	1.32	1.34	1.36	1.38	1.40	1.42	1.43	1.44	
	30	1.46	1.49	1.51	1.52	1.53	1.54	1.56	1.57	1.58	
	40	1.60	1.61	1.62	1.63	1.64	1.65	1.66	1.67	1.68	
	50	1.70	1.71	1.72	1.72	1.73	1.74	1.75	1.76	1.77	
	60	1.78	1.79	1.79	1.80	1.81	1.81	1.82	1.83	1.84	
	70	1.85	1.85	1.86	1.86	1.87	1.88	1.88	1.89	1.90	
	80	1.90	1.91	1.91	1.92	1.92	1.93	1.93	1.94	1.95	
	90	1.95	1.96	1.96	1.97	1.97	1.98	1.98	1.99	2.00	
	100	2.00	2.00	2.01	2.01	2.02	2.02	2.03	2.03	2.04	
	110	2.04	2.05	2.05	2.06	2.06	2.06	2.06	2.07	2.08	
	120	2.08	2.08	2.09	2.09	2.09	2.10	2.10	2.10	2.11	
	130	2.11	2.12	2.12	2.12	2.13	2.13	2.13	2.14	2.14	
	140	2.15	2.15	2.15	2.16	2.16	2.16	2.16	2.17	2.17	
	150	2.18	2.18	2.18	2.18	2.19	2.19	2.19	2.20	2.20	
	160	2.20	2.21	2.21	2.21	2.21	2.22	2.22	2.23	2.23	
	170	2.23	2.23	2.23	2.24	2.24	2.24	2.24	2.25	2.25	
	180	2.26	2.26	2.26	2.26	2.26	2.27	2.27	2.27	2.28	
190	2.28	2.28	2.28	2.29	2.29	2.29	2.29	2.29	2.30		
200	2.30	2.30	2.30	2.31	2.31	2.31	2.31	2.32	2.32		

LOWER TABLE C

		TENS									
		0	10	20	30	40	50	60	70	80	90
HUNDREDS	300		1.92	1.94	1.96	1.98	2.00	2.02	2.03	2.05	2.06
	300	2.08	2.10	2.11	2.12	2.13	2.15	2.16	2.17	2.18	2.19
	400	2.20	2.21	2.23	2.24	2.25	2.26	2.27	2.28	2.29	2.29
	500	2.30	2.31	2.32	2.33	2.34	2.34	2.35	2.36	2.37	2.37
	600	2.38	2.39	2.39	2.40	2.41	2.42	2.43	2.43	2.43	2.44
	700	2.45	2.45	2.46	2.47	2.47	2.48	2.48	2.49	2.49	2.50
	800	2.51	2.51	2.52	2.52	2.53	2.53	2.54	2.54	2.55	2.56
	900	2.58	2.58	2.57	2.57	2.58	2.58	2.58	2.59	2.59	2.60

LOWER TABLE D

		TENS									
		0	10	20	30	40	50	60	70	80	90
HUNDREDS	300		2.32	2.34	2.36	2.38	2.40	2.42	2.43	2.44	2.46
	300	2.48	2.49	2.51	2.52	2.53	2.54	2.56	2.57	2.58	2.59
	400	2.60	2.61	2.62	2.63	2.64	2.66	2.66	2.67	2.68	2.69
	500	2.70	2.71	2.72	2.73	2.73	2.74	2.75	2.76	2.76	2.77
	600	2.78	2.79	2.79	2.80	2.81	2.81	2.82	2.83	2.83	2.84
	700	2.86	2.86	2.86	2.86	2.87	2.88	2.88	2.89	2.89	2.90
	800	2.90	2.91	2.91	2.92	2.92	2.93	2.93	2.94	2.94	2.95
	900	2.95	2.96	2.96	2.97	2.97	2.98	2.98	2.99	2.99	3.00

RYZNAR STABILITY INDEX

The Ryznar Index is a method of quantifying the scale forming or corrosive effect of water. It is based upon the pH of the water and the water's pH of saturation. The pH of saturation, "pH_s", is that pH at which a water cannot hold additional calcium in solution. The Ryznar Index equation is: $RI = 2pH_s - pH$. Ryznar Index values above 6 are progressively corrosive; values below 6 are progressively scale forming.

APPENDIX B

12.2 ANALYTIKEM LABORATORY REPORT

Supplemental, December 29, 1992

Original, December 4, 1992

AnalytiKEM Inc.
28 Springdale Road
Cherry Hill, NJ 08003
609/751-1122
1-800-TRY-LAB1
Fax: 609/751-0824

TEST REPORT NO. A28958, Supplemental

December 29, 1992

Prepared for:

Norlite Corporation
628 South Saratoga Street
Cohoes, NY 12047

Attention: Richard Slaugh

Project: Salt Kill Creek

Reviewed &
Approved by:

Name: Carmine M. Fioriglio

Title: QA/QC Manager

TABLE OF CONTENTS

	<u>Page</u>
I. Certification	1
II. Definition of Terms	2
III. Sample Designations	3
IV. Methodology	4
V. Analytical Results	5

I. Certification

AnalytiKEM, Inc.
Current Certifications/Regulatory Approvals

Tabulated below are the current laboratory certifications that are held by each AnalytiKEM Laboratory. Analyses performed at multiple AnalytiKEM locations will be noted in the test report.

Cherry Hill, NJ		Rock Hill, SC		Houston Analytical, TX	
State	Cert #	State	Cert #	State	Cert #
Arkansas	*	S. Carolina	46067	N. Dakota	R-006
Connecticut	PH-0715	N. Carolina	316	Oklahoma	8403
Florida	880985G	New Jersey	79795	Texas Water Commission	*
Massachusetts	NJ117			Louisiana	92-07
New Jersey	04012			S. Carolina	82011
New York	10815			N. Carolina	367
N. Carolina	258			Wisconsin	998010530
N. Dakota	R-038			New Jersey	82869
Pennsylvania	68366				
S. Carolina	94004				
Tennessee	02908				
Vermont	*				
Oklahoma	9107				

* No certification numbers are issued for these states.

II. Definition of Terms

<u>Term</u>	<u>Definition</u>
D	Detected; result must be greater than zero.
DI	Deionized Water
J	Compound was detected at levels below the practical quantitation limit. The level reported is approximate.
MS/MSD	Matrix Spike/Matrix Spike Duplicate.
NA	Analysis not applicable to the sample matrix.
ND	Not Detected
NR	Not Requested
NTU	Nephelometric Turbidity Units
RPD	Relative Percent Difference
RSD	Relative Standard Deviation
U	Compound was analyzed for but not detected. The preceding number is the practical quantitation limit for the compound.
ppb	Parts-per-billion; may be converted to ppm by dividing by 1,000.
ppm	Parts-per-million; may be converted to ppb by multiplying by 1,000.
ug/l	Micrograms of constituent per liter of sample; equivalent to parts-per-billion.
ug/kg	Micrograms of constituent per kilogram of sample; equivalent to parts-per-billion.
ug/kg dw	Micrograms of constituent per kilogram of sample reported on a dry weight basis.
CCC	Calibration Check Compound; used to verify the precision of a GC/MS calibration curve.
SPCC	System Performance Check Compound; used to verify the correct operation of a GC/MS instrument.
PQL	Practical Quantitation Limit; the minimum level at which compounds can be dependably quantitated.
B	Analyte detected in associated blank as well as the sample. It indicates possible/probable blank contamination.

III. Sample Designations

AnalytiKEM

<u>AnalytiKEM Designation</u>	<u>Client Designation</u>	<u>Matrix</u>	<u>Date Sampled</u>
A28958-1	A1	Aqueous	11/13/92
A28958-2	A2	Aqueous	11/13/92

Note: Samples will be held for 30 days beyond the test report date unless otherwise requested.

IV. Methodology

AnalytiKEM

General Chemistry

Method 160.1, Total Dissolved Solids (Dried at 180 degrees C), Methods for Chemical Analysis of Water and Wastes, EPA-600/4-79-020, USEPA, 1979.

V. Analytical Results

AnalytiKEM

General Chemistry

Sample Designation

<u>Parameter</u>	<u>Method</u> <u>Blank</u>	<u>A28958-1</u> <u>A1</u>	<u>A28958-2</u> <u>A2</u>
Total Dissolved Solids	10,000 U	11,000,000	16,000,000
Units	(ug/l)	(ug/l)	(ug/l)

AnalytiKEM Inc.
28 Springdale Road
Cherry Hill, NJ 08003
609/751-1122
1-800-TRY-LAB1
Fax: 609/751-0824

TEST REPORT NO. A28958

December 4, 1992

Prepared for:

Morlite Corporation
628 South Saratoga Street
Cohoes, NY 12047

Attention: Richard Schlauch

Project: Salt Kill Creek

Reviewed &
Approved by: Michael Thomas, Ph.D. for

Name: Carmine M. Fioriglio

Title: QA/QC Manager

TABLE OF CONTENTS

	<u>Page</u>
I. Certification	1
II. Definition of Terms	2
III. Sample Designations	3
IV. Methodology	4
V. Analytical Results	5 - 6
VI. Quality Control Data	7 - 8
VII. Data Package	
Chain of Custody	A1
Metals	M1 - M49
General Chemistry	G1 - G7

I. Certification

AnalytiKEM, Inc.
Current Certifications/Regulatory Approvals

Tabulated below are the current laboratory certifications that are held by each AnalytiKEM Laboratory. Analyses performed at multiple AnalytiKEM locations will be noted in the test report.

Cherry Hill, NJ		Rock Hill, SC		Houston Analytical, TX	
State	Cert #	State	Cert #	State	Cert #
Arkansas	*	S. Carolina	46067	N. Dakota	R-006
Connecticut	PH-0715	N. Carolina	316	Oklahoma	8403
Florida	880985G	New Jersey	79795	Texas Water Commission *	
Massachusetts	NJ117			Louisiana	92-07
New Jersey	04012			S. Carolina	82011
New York	10815			N. Carolina	367
N. Carolina	258			Wisconsin	998010530
N. Dakota	R-038			New Jersey	82869
Pennsylvania	68366				
S. Carolina	94004				
Tennessee	02908				
Vermont	*				
Oklahoma	9107				

* No certification numbers are issued for these states.

II. Definition of Terms

<u>Term</u>	<u>Definition</u>
D	Detected; result must be greater than zero.
DI	Deionized Water
J	Compound was detected at levels below the practical quantitation limit. The level reported is approximate.
MS/MSD	Matrix Spike/Matrix Spike Duplicate.
NA	Analysis not applicable to the sample matrix.
ND	Not Detected
NR	Not Requested
NTU	Nephelometric Turbidity Units
RPD	Relative Percent Difference
RSD	Relative Standard Deviation
U	Compound was analyzed for but not detected. The preceding number is the practical quantitation limit for the compound.
ppb	Parts-per-billion; may be converted to ppm by dividing by 1,000.
ppm	Parts-per-million; may be converted to ppb by multiplying by 1,000.
ug/l	Micrograms of constituent per liter of sample; equivalent to parts-per-billion.
ug/kg	Micrograms of constituent per kilogram of sample; equivalent to parts-per-billion.
ug/kg dw	Micrograms of constituent per kilogram of sample reported on a dry weight basis.
CCC	Calibration Check Compound; used to verify the precision of a GC/MS calibration curve.
SPCC	System Performance Check Compound; used to verify the correct operation of a GC/MS instrument.
PQL	Practical Quantitation Limit; the minimum level at which compounds can be dependably quantitated.
B	Analyte detected in associated blank as well as the sample. It indicates possible/probable blank contamination.

III. Sample Designations**AnalytiKEM**

<u>AnalytiKEM Designation</u>	<u>Client Designation</u>	<u>Matrix</u>	<u>Date Sampled</u>
A28958-1	A1	Aqueous	11/13/92
A28958-2	A2	Aqueous	11/13/92
A28958-3	B2	Aqueous	11/13/92
A28958-4	D1	Aqueous	11/13/92
A28958-5	D2	Aqueous	11/13/92
A28958-6	B1	Aqueous	11/13/92

Note: Samples will be held for 30 days beyond the test report date unless otherwise requested.

IV. Methodology

AnalytiKEM

Metals

Method 3010, Acid Digestion of Aqueous Samples and Extracts for Total Metals for Analysis by Flame Atomic Absorption Spectroscopy or Inductively Coupled Plasma Spectroscopy, Test Methods for Evaluating Solid Waste. Physical/Chemical Methods, SW846, Third Edition, USEPA, 1986, with all promulgated revisions.

Method 6010, Inductively Coupled Plasma Atomic Emission Spectroscopy, Test Methods for Evaluating Solid Waste, Physical/Chemical Methods, SW846, Third Edition, USEPA, 1986, with all promulgated revisions.

General Chemistry

Method 130.2, Hardness, Methods for Chemical Analysis of Water and Wastes, EPA-600/4-79-020, USEPA, January 1982.

Method 9040, pH Electrometric Measurement, Test Methods for Evaluating Solid Waste, Physical/Chemical Methods, SW846, Third Edition, USEPA, 1986, with all promulgated revisions.

Method 160.1, Total Dissolved Solids (Dried at 180 degrees C), Methods for Chemical Analysis of Water and Wastes, EPA-600/4-79-020, USEPA, 1979.

Method 160.2, Total Suspended Solids (Dried at 103-105 degrees C), Methods for Chemical Analysis of Water and Wastes, EPA-600/4-79-020, USEPA, 1979.

Method 310.1, Alkalinity (Titrimetric, pH4.5), Methods for Chemical Analysis of Water and Wastes, EPA-600/4-79-020, USEPA, 1979.

Method 9038, Sulfate (Turbidimetric), Test Methods for Evaluating Solid Waste, Physical/Chemical Methods, SW846, Third Edition, USEPA, 1986, with all promulgated revisions.

V. Analytical Results

AnalytiKEM

Metals

<u>Parameter</u>	<u>Method</u> <u>Blank</u>	<u>Sample Designation</u>			
		<u>A28958-1</u>	<u>A28958-1</u>	<u>A28958-2</u>	<u>A28958-3</u>
		<u>A1</u>	<u>(Duplicate)</u> <u>A1</u>	<u>A2</u>	<u>B2</u>
Aluminum, total	200 U	6,600	6,600	2,600	730
Calcium, total	5,000 U	90,000	90,000	44,000	67,000
Iron, total	100 U	14,000	14,000	4,800	1,100
Magnesium, total	5,000 U	10,000	10,000	6,600	16,000
Manganese, total	15 U	370	360	110	46
Units	(ug/l)	(ug/l)	(ug/l)	(ug/l)	(ug/l)

<u>Parameter</u>	<u>Method</u> <u>Blank</u>	<u>Sample Designation</u>		
		<u>A28958-4</u>	<u>A28958-5</u>	<u>A28958-6</u>
		<u>D1</u>	<u>D2</u>	<u>B1</u>
Aluminum, total	200 U	880	1,100	720
Calcium, total	5,000 U	40,000	47,000	77,000
Iron, total	100 U	1,500	1,600	1,300
Magnesium, total	5,000 U	14,000	15,000	20,000
Manganese, total	15 U	52	61	44
Units	(ug/l)	(ug/l)	(ug/l)	(ug/l)

V. Analytical Results (Cont'd)

AnalytiKEM

General Chemistry

<u>Parameter</u>	<u>Method</u> <u>Blank</u>	<u>Sample Designation</u>		
		<u>A28958-1</u> <u>A1</u>	<u>A28958-2</u> <u>A2</u>	<u>A28958-3</u> <u>B2</u>
pH, units	--	9.4	9.4	7.7
Total Suspended Solids	10,000 U	630,000; 630,000 *	730,000	10,000 U
Total Dissolved Solids	10,000 U	1,500,000; 1,500,000 *	17,000,000	450,000
Hardness, as CaCO ₃	--	200,000	160,000	250,000
Sulfate	--	3,300,000	4,700,000	63,000
Alkalinity, Bicarbonate	--	3,300,000; 3,400,000 *	4,000,000	170,000
Alkalinity, Carbonate	--	410,000; 460,000 *	560,000	1,200
Alkalinity, Hydroxide	--	1,000 U; 1,000 U*	1,000 U	1,000 U
Units	(ug/l)	(ug/l)	(ug/l)	(ug/l)

<u>Parameter</u>	<u>Method</u> <u>Blank</u>	<u>Sample Designation</u>		
		<u>A28958-4</u> <u>D1</u>	<u>A28958-5</u> <u>D2</u>	<u>A28958-6</u> <u>B1</u>
pH, units	--	8.5	8.8	8.5
Total Suspended Solids	10,000 U	10,000 U	77,000	19,000
Total Dissolved Solids	10,000 U	2,500,000	2,500,000	470,000
Hardness, as CaCO ₃	--	180,000	190,000	240,000
Sulfate	--	700,000	740,000	71,000
Alkalinity, Bicarbonate	--	480,000	1,100,000	170,000
Alkalinity, Carbonate	--	13,000	25,000	2,000
Alkalinity, Hydroxide	--	1,000 U	1,000 U	1,000 U
Units	(ug/l)	(ug/l)	(ug/l)	(ug/l)

* Duplicate analysis.

VI. Quality Control Data

Metals

Aqueous Matrix Spike/Matrix Spike Duplicate Recovery Data

Sample Spiked A28958-1

<u>Parameter</u>	<u>Amount of Spike</u>	<u>Recovery</u>			<u>Control Limits</u>	
		<u>MS</u>	<u>MSD</u>	<u>RPD</u>	<u>Recovery</u>	<u>Max. RPD</u>
Aluminum	500	88	98	11	56-115	23
Calcium	300	*	*	--	11-148	37
Calcium ϕ	300	100	--	--	11-148	37
Iron	300	80	94	16	69-112	10
Iron ϕ	300	96	--	--	69-112	10
Magnesium	300	85	92	8	68-112	10
Manganese	20	85	89	5	82-105	10
Units	(ug)	(%)	(%)	(%)	(%)	(%)

* Not recovered due to high amount of analyte detected in the sample.

Recovery: 0 out of 10 outside control limits

RPD: 1 out of 4 outside control limits

VI. Quality Control Data (Cont'd)

AnalytiKEM

General Chemistry

Aqueous Matrix Spike/Matrix Spike Duplicate Recovery Data

Sample Spiked A28958-1

<u>Parameter</u>	<u>Amount of Spike</u>	<u>Recovery</u>		<u>RPD</u>	<u>Control Limits</u>	
		<u>MS</u>	<u>MSD</u>		<u>Recovery</u>	<u>Max. RPD</u>
Sulfate	1,600	103	102	1	66-141	8
Units	(ug)	(%)	(%)	(%)	(%)	(%)

Recovery: 0 out of 2 outside control limits

RPD: 0 out of 1 outside control limits

28 Springdale Road
Cherry Hill, New Jersey 08003
(609) 751-1122 • (215) 923-2068
Fax: (609) 751-0824

Chain-of-Custody

454 South Anderson Road BTC 532
Rock Hill, South Carolina 29730
(803) 329-9690
Fax: (803) 329-9689

Client NORLITE Corp

Project: SALTRH

AnalytiKEM Contact ELISHA TEAWINKLE

SAMPLE DESIGNATION	DATE	MATRIX											PARAMETERS	
			40 ml vials	950 ml Org. Pres.	ml Unpres.	ml Unpres.	1000 ml HNO ₃	ml H ₂ SO ₄	ml H ₂ SO ₄	ml NaOH	1699			
A1	11/13/92	WATER											X	
A1. HNO ₃ PRESERVED	↓	↓					X							
A2												X		
A2. HNO ₃ PRESERVED							X							
B1												X		
B1. HNO ₃ PRESERVED								X						
B2												X		
B2. HNO ₃ PRESERVED						X								

I. Field Measurements:

Data Sheets: Y N
Filtered: Y Not Required

II. Field Conditions/Comments:

ANALYSE PER RITA SCHUBERT'S INSTRUCTIONS.

III. Special Instructions:

(Detection Limits, Data Package, etc.)

Relinquished By:	Time/Date:	Received By:	Time/Date:
<i>Richard [Signature]</i>	5:30pm 11/13/92	<i>[Signature]</i>	11/17/92 1135

28 Springdale Road
 Cherry Hill, New Jersey 08003
 (609) 751-1122 • (215) 923-2068
 Fax: (609) 751-0824

Chain-of-Custody

454 South Anderson Road BTC 532
 Rock Hill, South Carolina 29730
 (803) 329-9690
 Fax: (803) 329-9689

Client NORLITE Corp

Project: SALT KILL

AnalytiKEM Contact ELISHA TEAWINKLE

SAMPLE DESIGNATION	DATE	MATRIX											PARAMETERS	
			40 ml vials	950 ml Org. Pres.	ml Unpres.	ml Unpres.	1000 ml HNO ₃	ml H ₂ SO ₄	ml H ₂ SO ₄	ml NaOH	150g / 100ml			
D1	11/13/92	WATER											X	
D1. HNO ₃ PRESERVED	↓	↓					X							
D2													X	
D2. HNO ₃ PRESERVED	↓	↓					X							

1. Field Measurements:
 Data Sheets: Y N
 Filtered: Y Not Required

II. Field Conditions/Comments: ANALYSE PER RICH SCHLACICH'S INSTRUCTIONS

III. Special Instructions:
 (Detection Limits, Data Package, etc.)

Relinquished By:	Time/Date:	Received By:	Time/Date:
<i>Richard Frank</i>	5:30pm 11/13/92	<i>Kim Jones</i>	1000 11/17/92

**ANALYTIKEM
SAMPLE RECEIPT CHECKLIST**

AnalytiKEM

NAME Asiote

ANALYTIKEM NO. 29958

NAME _____

COMMENTS

SHIPPED 525 372 4114
 AIR BILL #
 HAND-DELIVERED

COC PRESENT ON RECEIPT
 NO COC ON RECEIPT
 COC TAPE ON CONTAINERS/COOLERS

NO COC TAPE ON CONTAINERS/COOLERS

SAMPLE(S) INTACT ON RECEIPT
 SAMPLE(S) BROKEN/LEAKING
 OTHER (SEE COMMENTS)

1-950^{ml} B1- ~~was preserved~~ rec'd Broken
B1 gal. jug not rec'd

PROPER TEMPERATURE
 IMPROPER TEMPERATURE

PROPERLY PRESERVED
 IMPROPERLY PRESERVED
 NA

RECEIVED WITHIN HOLDING TIME
 NOT RECEIVED WITHIN HOLDING TIME
 NA

DISCREPANCIES BETWEEN COC AND SAMPLE LABELS

rec'd #1 A1- 1 gal up
A1 950 ml

#2 A2 1 gal up
A2 950 ml

#3 B2 1-950 ml
B2 1-950 ml

#4 D1- 1 gal up
D1- 1950 ml

#5 D2- 1 gal up
D2- 1950 ml

NO DISCREPANCIES NOTED

COCS INSPECTED AND LOGGED BY: _____

DATE/TIME: _____

[Signature]
11/17/92 110

Work continued from Page _____

DATE	SAMPLE #	INIT WT/VOL	FINAL VOL.	SPELGE AMT.	Comments
(Foz)	2899S-21	1.25	100		
11/30/92	-22	1.34	↓		
	-23	1.70	↓		
	-24	1.04	↓		
	-25	100	50		FIELD BLANK
	-26	↓	↓		↓
	-24 Dup	1.04	100		
	-24 NS	1.22	↓	52000/SB	
	-24 NSB	1.07	↓	↓	
	DEF PK	1.0	↓		
	Blank	1.0	↓		
1-30-92	28958-1	100 mL	100 mL		HOMOGENIZING W/
(J)	-2	↓	↓		↓
	-3	↓	↓		↓
	-4	↓	↓		↓
	-5	↓	↓		↓
	-6	↓	↓		↓
	-Dup	↓	↓		↓
	-NS	↓	↓	30000 EARLY	↓
	-NSB	↓	↓	↓	↓
	D. SPK	↓	↓		↓
	Blank	↓	↓		↓

SIGNATURE

[Handwritten Signature]

DATE

11-30-92

DISCLOSED TO AND UNDERSTOOD BY

[Handwritten Name]

DATE

12/7/92

WITNESS

DATE

ma

ICP RUN SUMMARY

Sample Spiked: 28958-1

Spike Amount 100 ug

Final Volume 500 ml

Metal	Sample Spiked (wt: _____ g) ug/ml	Spike Recovery (wt: _____ g) ug/ml		Spike Duplicate (wt: _____ g) ug/ml		RFD
			%		%	
Cg	89.820	95.550	191	96.510	223	15

OT

100

Date: 12/4/92
 Task File: Calcium
 Analyst: J. Magallan
 Reference: 1869-ICP
 Samples Run: 28958- (1-5) dilutions

Start Time: _____
 End Time: _____
 Sample Time: _____ min/sample

m3

Report 2

12-04-1992 @ 04:09:31 -- 1

Task: CALCIUM Result File: 28958 - Analysis Results

Sample Name	CA 317.933
04-1992	
1 HIGH STD	24.908
2 ICV	10.130
3 ICB	0.000
4 ICS A	19.866
5 ICS AB	19.885
6 CCV	10.074
7 CCB	0.000
8 28958-1	17.964
9 28958-1 DUP	18.078
10 28958-1 MS	19.110
11 28958-1 MSD	19.302
12 28958-2	22.043
13 28958-3	13.327
14 28958-4	19.845
15 28958-5	23.623
16 CCV	9.985
17 CCB	< 0.000
18 ICS A	19.693
19 ICS AB	19.808
20 CCV	10.047
21 CCB	< 0.000



m4

2-04-1992 @ 03:45:22 -- 1

For Wavelength Calibration, Use (S)pecial or (C)al. Standards ? C

Enter STANDARD NUMBER (1 - 4) or -1 to EXIT: 1

Standard #1 solution aspirating - CONTINUE ? Y

Scanning Around CA 317.933

Element	Peak Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
CA	No Peak!	1	N/A		

BLANK RE-CALCULATED AT END OF CALIBRATION

Enter STANDARD NUMBER (1 - 4) or -1 to EXIT: 2

Standard #2 solution aspirating - CONTINUE ? Y

Scanning Around CA 317.933

Element	Peak Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
CA	-0.0001	1	9727		

STANDARD #2

Element	Wavelength	Ave Int	% R.S.D.	Ref	Blank Int	Off Peak Int	Net Int
CA	317.933	9727	N/A			0	9727

Enter STANDARD NUMBER (1 - 4) or -1 to EXIT: 3

Standard #3 solution aspirating - CONTINUE ? Y

Scanning Around CA 317.933

Element	Peak Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
CA	0.0002	1	18215		

STANDARD #3

Element	Wavelength	Ave Int	% R.S.D.	Ref	Blank Int	Off Peak Int	Net Int
CA	317.933	18215	N/A			0	18215

Enter STANDARD NUMBER (1 - 4) or -1 to EXIT: 4

Standard #4 solution aspirating - CONTINUE ? Y

Scanning Around CA 317.933

Element	Peak Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
CA	0.0005	1	43284		

STANDARD #4

Element	Wavelength	Ave Int	% R.S.D.	Ref	Blank Int	Off Peak Int	Net Int
CA	317.933	43284	N/A			0	43284

Enter STANDARD NUMBER (1 - 4) or -1 to EXIT: -1

STANDARD #1

Element	Wavelength	Ave Int	% R.S.D.	Ref	Blank Int	Off Peak Int	Net Int
CA	317.933	1533	N/A			0	1533

m5

04-1992 @ 03:49:50 -- 1

Statistics For Fitted Curve

Results For CA 317.933

	Low Intensity	High Intensity	Intercept	Slope	Curvature		
Curve 1	1533	43284	-0.92210	0.00060	0.00000		
Standard	Intensity	Concen.	Calc. Con.	Con. Error	% Error	Order	
1	1533	0.000	0.001	0.001		1	
2	9727	5.000	4.936	-0.064	-1.29	1	
3	18215	10.000	10.047	0.047	0.47	1	
4	43284	25.000	25.144	0.144	0.58	1	

The RMS Error is 0.859%

mg

Analyze Samples

12-04-1992 @ 03:50:13 -- 1

Calculate Dilution Correction ? Y

HIGH STD

HIGH STD

Begin Analysis - Sample Number 1

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
CA	317.933	0.0005	42892	42892

Calculating Concentrations for Sample Number 1

Ele. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
CA	317.933	42892	24.908		24.908	24.908

ICV

CV

Begin Analysis - Sample Number 2

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
CA	317.933	0.0002	18353	18353

Calculating Concentrations for Sample Number 2

Ele. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
CA	317.933	18353	10.130		10.130	10.130

ICB

m7

Analyze Samples

12-04-1992 @ 03:53:04 -- 2

Begin Analysis - Sample Number 3

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
CA	317.933	No Peak!	1532	1532

Calculating Concentrations for Sample Number 3

Ele. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
CA	317.933	1532	0.000		0.000	0.000

ICS A

Water Sample Weight 2
 Water Sample Volume 2
 Water Sample Volume 50

ICS A

Begin Analysis - Sample Number 4

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
CA	317.933	0.0005	34520	34520

Calculating Concentrations for Sample Number 4

Ele. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
CA	317.933	34520	19.866		19.866	496.650

ICS AB

m8

Analyze Samples

12-04-1992 @ 03:54:48 -- 3

AS AB

Begin Analysis - Sample Number 5

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
CA	317.933	0.0003	34552	34552

Calculating Concentrations for Sample Number 5

Ele. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
CA	317.933	34552	19.885		19.885	497.125

CCV

Water Sample Weight 1

Water Sample Volume 1

CV

Begin Analysis - Sample Number 6

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
CA	317.933	0.0005	18260	18260

Calculating Concentrations for Sample Number 6

Ele. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
CA	317.933	18260	10.074		10.074	10.074

CCB

m9

Analyze Samples

12-04-1992 @ 03:56:28 -- 4

CCB

Begin Analysis - Sample Number 7

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
CA	317.933	No Peak!	1532	1532

Calculating Concentrations for Sample Number 7

Ele. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
CA	317.933	1532	0.000		0.000	0.000

Enter Sample Volume 5

28958-1

Begin Analysis - Sample Number 8

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
CA	317.933	0.0003	31361	31361

Calculating Concentrations for Sample Number 8

Ele. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
CA	317.933	31361	17.964		17.964	89.820

28958-1 DUP

M10

Analyze Samples

12-04-1992 @ 03:58:04 -- 5

Begin Analysis - Sample Number 9

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
CA	317.933	0.0004	31550	31550

Calculating Concentrations for Sample Number 9

Ele. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
CA	317.933	31550	18.078		18.078	90.390

28958-1 MS

Begin Analysis - Sample Number 10

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
CA	317.933	0.0009	33265	33265

Calculating Concentrations for Sample Number 10

Ele. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
CA	317.933	33265	19.110		19.110	95.550

28958-1 MSD

Begin Analysis - Sample Number 11

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
-----------	-------------	--------------------	---------------------	--------------------

m11

Analyze Samples

12-04-1992 @ 03:59:42 -- 6

CA 317.933 0.0005 33583 33583

Calculating Concentrations for Sample Number 11

Elem. Wave- Sym. length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
CA 317.933 28958-2	33583	19.302		19.302	96.510

Enter Sample Volume 2

28958-2

Begin Analysis - Sample Number 12

Elem. Wave- Sym. length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
CA 317.933	0.0005	38135	38135

Calculating Concentrations for Sample Number 12

Elem. Wave- Sym. length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
CA 317.933 28958-3	38135	22.043		22.043	44.086

Enter Sample Weight 5

Enter Sample Weight 1

Enter Sample Volume 5

28958-3

Begin Analysis - Sample Number 13

m12

Analyze Samples

12-04-1992 @ 04:01:45 -- 7

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
CA	317.933	0.0008	23661	23661

Calculating Concentrations for Sample Number 13

Ele. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
CA	317.933 28958-4	23661	13.327		13.327	66.635

Enter Sample Weight User Abort

Enter Sample Volume 2

28958-4

Begin Analysis - Sample Number 14

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
CA	317.933	0.0005	34485	34485

Calculating Concentrations for Sample Number 14

Ele. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
CA	317.933 28958-5	34485	19.845		19.845	39.690

28958-5

Begin Analysis - Sample Number 15

m13

Analyze Samples

12-04-1992 @ 04:03:43 -- 8

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
CA	317.933	0.0006	40759	40759

Calculating Concentrations for Sample Number 15

Ele. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
CA	317.933	40759	23.623		23.623	47.246

CCV

Begin Analysis - Sample Number 16

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
CA	317.933	0.0008	18111	18111

Calculating Concentrations for Sample Number 16

Ele. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
CA	317.933	18111	9.985		9.985	19.970

CCB

CCB

Begin Analysis - Sample Number 17

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
-----------	-------------	--------------------	---------------------	--------------------

m14

Analyze Samples

12-04-1992 @ 04:05:38 -- 9

CA 317.933 No Peak! 1505 1505

Calculating Concentrations for Sample Number 17

Elem. Wave- ys. length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
317.933 ICS A	1505	-0.016		< 0.000 <	0.000

ICS A

Begin Analysis - Sample Number 18

Enter Sample Weight 2
Enter Sample Volume 50

ICS A

Begin Analysis - Sample Number 18

Elem. Wave- Sym. length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
CA 317.933	0.0006	34233	34233

Calculating Concentrations for Sample Number 18

Elem. Wave- ys. length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
317.933 ICS AB	34233	19.693		19.693	492.325

ICS AB

m15

Analyze Samples

12-04-1992 @ 04:06:51 -- 10

Begin Analysis - Sample Number 19

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
CA	317.933	0.0009	34423	34423

Calculating Concentrations for Sample Number 19

Elem. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
CA	317.933	34423	19.808		19.808	495.200

CCV

Enter Sample Weight 1

Enter Sample Volume 1

CCV

Begin Analysis - Sample Number 20

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
CA	317.933	0.0006	18215	18215

Calculating Concentrations for Sample Number 20

Elem. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
CA	317.933	18215	10.047		10.047	10.047

CCB

CCB

m14

ICP RUN SUMMARY

Sample Spiked: 28958-1

Spike Amount 300 ~~µg~~ 300 ~~µg~~ µg

Final Volume 100 ~~ml~~ ml

Metal	Sample Spiked (wt: _____ g) ug/ml	Spike Recovery (wt: _____ g) ug/ml		Spike Duplicate (wt: _____ g) ug/ml		RFD
			%		%	
Al	6.638	9.273	88	9.588	98	11
Ca	←	Over		Calibration		→
Fe	13.704	16.099	80	16.521	94	16
Mg	10.340	12.896	85	13.092	92	8
Mn	0.369	2.815	85	3.046	89	5
Ni	15.962					
Ni	←	Over		Flow		→

Date: 12/4/92
 Task File: Dirt
 Analyst: J. M. Galt
 Reference: 1862-ICP
 Samples Run: 28958-(1-6)

Start Time: _____
 End Time: _____
 Sample Time: _____ min/sample

m17

Sample Name	K	766.491	NA 588.995
2-04-1992			
1 HIGH STD		25.071	24.538
2 ICV		9.501	10.137
3 ICB	<	0.050	0.206
4 ICB	<	0.050	0.489
5 ICS A	<	0.050	0.340
6 ICS AB	<	0.050	0.255
7 CCV		9.799	9.735
8 CCB	<	0.050	0.220
9 PBW	<	0.050	0.212
10 28958-1		15.962	Overflow
11 28958-1 DUP		23.742	Overflow
12 28958-1 MS		35.044	Overflow
13 28958-1 MSD		7.388	36.485
14 LCS I		9.869	16.463
15 28958-2		8.390	Overflow
16 28958-3		9.144	55.278
17 28958-4		2.823	12.224
18 28958-5		2.803	35.842
19 CCV		11.337	16.445
20 CCB		0.977	4.137
21 28958-6		8.727	75.612
22 28958-6 SER D		1.364	22.262
23 ICS A		0.163	3.858
24 ICS AB		0.580	3.810
25 CCV		11.119	14.505
26 CCV		11.476	14.128
27 CCV		11.228	13.359
28 CCB		0.411	3.322
29 CCB		0.372	3.071

m18

2-04-1992 @ 01:10:33 -- 1

Have previously acquired Calibration data for this task ? N

For Wavelength Calibration, Use (S)pecial or (C)al. Standards ? C

Enter STANDARD NUMBER (1 - 4) or -1 to EXIT: 1

Standard #1 solution aspirating - CONTINUE ? Y

Element	Peak Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
Scanning	Around MN	257.610			
Element	Peak Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
MN	No Peak!	1	N/A	853	832
Scanning	Around FE	259.940			
Element	Peak Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
FE	No Peak!	1	N/A		
Scanning	Around MG	279.553			
Element	Peak Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
MG	0.0014	1	N/A		
Scanning	Around CA	317.933			
Element	Peak Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
CA	No Peak!	1	N/A		
Scanning	Around AL	396.152			
Element	Peak Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
AL	No Peak!	1	N/A		
Scanning	Around NA	588.995			
Element	Peak Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
NA	0.0005	1	N/A		
Scanning	Around K	766.491			
Element	Peak Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
K	No Peak!	1	N/A		

BLANK RE-CALCULATED AT END OF CALIBRATION

Enter STANDARD NUMBER (1 - 4) or -1 to EXIT: 2

Standard #2 solution aspirating - CONTINUE ? Y

Element	Peak Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
Scanning	Around MN	257.610			
Element	Peak Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
MN	0.0011	1	95194	1526	1413
Scanning	Around FE	259.940			
Element	Peak Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
FE	0.0005	1	31650		
Scanning	Around MG	279.553			
Element	Peak Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens

Scanning	Around CA	317.933				
Element	Peak	Replication	Peak Pos.	Off Peak	Off Peak	m19
CA	Position	Number	Intensity	Pnt. 1 Intens	Pnt. 2 Intens	
	0.0005	1	9051			
Scanning	Around AL	396.152				
Element	Peak	Replication	Peak Pos.	Off Peak	Off Peak	
AL	Position	Number	Intensity	Pnt. 1 Intens	Pnt. 2 Intens	
	0.0003	1	22155			
Scanning	Around NA	588.995				
Element	Peak	Replication	Peak Pos.	Off Peak	Off Peak	
NA	Position	Number	Intensity	Pnt. 1 Intens	Pnt. 2 Intens	
	0.0009	1	79520			
Scanning	Around K	766.491				
Element	Peak	Replication	Peak Pos.	Off Peak	Off Peak	
K	Position	Number	Intensity	Pnt. 1 Intens	Pnt. 2 Intens	
	0.0003	1	1806			

STANDARD #2

Element	Wavelength	Ave Int	% R.S.D.	Ref	Blank Int	Off Peak Int	Net Int
AL	396.152	22155	N/A			0	22155
CA	317.933	9051	N/A			0	9051
FE	259.940	31650	N/A			0	31650
MG	279.553	183199	N/A			0	183199

m20

2-04-1992 @ 01:20:20 -- 2

MN	257.610	95194	N/A	1470	93725
K	766.491	1806	N/A	0	1806
NA	588.995	79520	N/A	0	79520

Enter STANDARD NUMBER (1 - 4) or -1 to EXIT: 3

Standard #3 solution aspirating - CONTINUE ? Y

Element	Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
Scanning	Around MN	257.610			
Element	Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
MN	0.0013	1	189641	2464	1955
Scanning	Around FE	259.940			
Element	Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
FE	0.0006	1	60949		
Scanning	Around MG	279.553			
Element	Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
MG	0.0008	1	365783		
Scanning	Around CA	317.933			
Element	Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
CA	0.0009	1	16639		
Scanning	Around AL	396.152			
Element	Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
AL	0.0002	1	40613		
Scanning	Around NA	588.995			
Element	Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
NA	0.0012	1	133075		
Scanning	Around K	766.491			
Element	Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
K	-0.0004	1	2231		

STANDARD #3

Element	Wavelength	Ave Int	* R.S.D.	Ref	Blank Int	Off Peak Int	Net Int
AL	396.152	40613	N/A			0	40613
CA	317.933	16639	N/A			0	16639
FE	259.940	60949	N/A			0	60949
MG	279.553	365783	N/A			0	365783
MN	257.610	189641	N/A			2210	187432
K	766.491	2231	N/A			0	2231
NA	588.995	133075	N/A			0	133075

Enter STANDARD NUMBER (1 - 4) or -1 to EXIT: 4

Standard #4 solution aspirating - CONTINUE ? Y

Element	Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
Scanning	Around MN	257.610			
Element	Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens
MN	0.0012	1	461408	4823	3579
Scanning	Around FE	259.940			
Element	Position	Replication Number	Peak Pos. Intensity	Off Peak Pnt. 1 Intens	Off Peak Pnt. 2 Intens

FE	0.0003	1	149772		
Scanning	Around MG	279.553			
	Peak	Replication	Peak Pos.	Off Peak	Off Peak
ement	Position	Number	Intensity	Pnt. 1 Intens	Pnt. 2 Intens
MG	0.0010	1	902812		
Scanning	Around CA	317.933			
	Peak	Replication	Peak Pos.	Off Peak	Off Peak
ement	Position	Number	Intensity	Pnt. 1 Intens	Pnt. 2 Intens
CA	0.0007	1	39880		
Scanning	Around AL	396.152			
	Peak	Replication	Peak Pos.	Off Peak	Off Peak
ement	Position	Number	Intensity	Pnt. 1 Intens	Pnt. 2 Intens
AL	0.0002	1	94808		
Scanning	Around NA	588.995			
	Peak	Replication	Peak Pos.	Off Peak	Off Peak
ement	Position	Number	Intensity	Pnt. 1 Intens	Pnt. 2 Intens
NA	0.0010	1	292505		
Scanning	Around K	766.491			
	Peak	Replication	Peak Pos.	Off Peak	Off Peak
ement	Position	Number	Intensity	Pnt. 1 Intens	Pnt. 2 Intens
K	0.0001	1	3803		

m21

STANDARD #4

mad

2-04-1992 @ 01:26:00 -- 3

Element	Wavelength	Ave Int	% R.S.D.	Ref Blank Int	Off Peak Int	Net Int
AL	396.152	94808	N/A		0	94808
CA	317.933	39880	N/A		0	39880
FE	259.940	149772	N/A		0	149772
MG	279.553	902812	N/A		0	902812
MN	257.610	461408	N/A		4201	457207
K	766.491	3803	N/A		0	3803
NA	588.995	292505	N/A		0	292505

Enter STANDARD NUMBER (1 - 4) or -1 to EXIT: -1

STANDARD #1

Element	Wavelength	Ave Int	% R.S.D.	Ref Blank Int	Off Peak Int	Net Int
AL	396.152	3592	N/A		0	3592
CA	317.933	1389	N/A		0	1389
FE	259.940	1417	N/A		0	1417
MG	279.553	513	N/A		0	513
MN	257.610	920	N/A		843	78
K	766.491	1263	N/A		0	1263
NA	588.995	21864	N/A		0	21864

md3

12-04-1992 @ 01:26:37 -- 1

Statistics For Fitted Curve

Results For AL 396.152

	Low Intensity	High Intensity	Intercept	Slope	Curvature	
Curve 1	3592	94808	-0.97593	0.00027	0.00000	
Standard	Intensity	Concen.	Calc. Con.	Con. Error	% Error	Order
1	3592	0.000	-0.001	-0.001		1
2	22155	5.000	5.037	0.037	0.75	1
3	40613	10.000	10.047	0.047	0.47	1
4	94808	25.000	24.757	-0.243	-0.97	1

The RMS Error is 0.759%

Results For CA 317.933

	Low Intensity	High Intensity	Intercept	Slope	Curvature	
Curve 1	1389	39880	-0.90607	0.00065	0.00000	
Standard	Intensity	Concen.	Calc. Con.	Con. Error	% Error	Order
1	1389	0.000	0.000	0.000		1
2	9051	5.000	4.999	-0.001	-0.01	1
3	16639	10.000	9.950	-0.050	-0.50	1
4	39880	25.000	25.115	0.115	0.46	1

The RMS Error is 0.390%

Results For FE 259.940

	Low Intensity	High Intensity	Intercept	Slope	Curvature	
Curve 1	1417	149772	-0.23719	0.00017	0.00000	
Standard	Intensity	Concen.	Calc. Con.	Con. Error	% Error	Order
1	1417	0.000	0.000	0.000		1
2	31650	5.000	5.059	0.059	1.18	1
3	60949	10.000	9.962	-0.038	-0.38	1
4	149772	25.000	24.825	-0.175	-0.70	1

may

md5

Statistics For Fitted Curve

12-04-1992 @ 01:26:43 -- 2

Results For MG 279.553

	Low Intensity	High Intensity	Intercept	Slope	Curvature	
Curve 1	513	902812	-0.01410	0.00003	0.00000	
Standard	Intensity	Concen.	Calc. Con.	Con. Error	% Error	Order
1	513	0.000	0.000	0.000		1
2	183199	5.000	5.021	0.021	0.42	1
3	365783	10.000	10.039	0.039	0.39	1
4	902812	25.000	24.799	-0.201	-0.80	1

The RMS Error is 0.570%

Results For MN 257.610

	Low Intensity	High Intensity	Intercept	Slope	Curvature	
Curve 1	78	457207	-0.00420	0.00005	0.00000	
Standard	Intensity	Concen.	Calc. Con.	Con. Error	% Error	Order
1	78	0.000	0.000	0.000		1
2	93725	5.000	5.040	0.040	0.80	1
3	187432	10.000	10.083	0.083	0.83	1
4	457207	25.000	24.602	-0.398	-1.59	1

The RMS Error is 1.135%

Results For K 766.491

	Low Intensity	High Intensity	Intercept	Slope	Curvature	
Curve 1	1263	3803	-12.57832	0.00992	0.00000	
Standard	Intensity	Concen.	Calc. Con.	Con. Error	% Error	Order
1	1263	0.000	-0.045	-0.045		1
2	1806	5.000	5.343	0.343	6.87	1
3	2231	10.000	9.561	-0.439	-4.39	1
4	3803	25.000	25.161	0.161	0.64	1

The RMS Error is 4.721%

mad6

Statistics For Fitted Curve

12-04-1992 @ 01:26:48 -- 3

Results For NA 588.995

Low Intensity High Intensity Intercept Slope Curvature

Curve 1 21864 292505 -1.98436 0.00009 0.00000

Standard	Intensity	Concen.	Calc. Con.	Con. Error	% Error	Order
1	21864	0.000	-0.012	-0.012		1
2	79520	5.000	5.190	0.190	3.81	1
3	133075	10.000	10.022	0.022	0.22	1
4	292505	25.000	24.407	-0.593	-2.37	1

The RMS Error is 2.593%

ma7

Analyze Samples

12-04-1992 @ 01:27:39 -- 1

Calculate Dilution Correction ? Y

HIGH STD

HIGH STD

Begin Analysis - Sample Number 1

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61			
	Off Peak Int.	=	4609	
	Off Peak Int.	=	3541	
		0.0004	468632	464557
FE	259.94	-0.0002	151020	151020
MG	279.553	-0.0001	898004	898004
CA	317.933	0.0001	40145	40145
AL	396.152	-0.0004	94477	94477
NA	588.995	0.0002	293957	293957
K	766.491	-0.0004	3794	3794

Calculating Concentrations for Sample Number 1

Elem. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
AL	396.152	94477	24.667		24.667	24.667
CA	317.933	40145	25.288		25.288	25.288
FE	259.94	151020	25.033		25.033	25.033
MG	279.553	898004	24.667		24.667	24.667
MN	257.61	464557	24.998		24.998	24.998
K	766.491	3794	25.071		25.071	25.071
NA	588.995	293957	24.538		24.538	24.538

ICV

ICV

m28

Analyze Samples

12-04-1992 @ 01:30:34 -- 2

Begin Analysis - Sample Number 2

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61			
	Off Peak Int.	=	2412	
	Off Peak Int.	=	1915	
		0.0001	189872	187708
FE	259.94	-0.0001	60510	60510
MG	279.553	-0.0001	365769	365769
CA	317.933	-0.0002	16966	16966
AL	396.152	-0.0003	40626	40626
NA	588.995	0.0001	134344	134344
K	766.491	-0.0001	2225	2225

Calculating Concentrations for Sample Number 2

Elem. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
L	396.152	40626	10.051		10.051	10.051
A	317.933	16966	10.164		10.164	10.164
E	259.94	60510	9.888		9.888	9.888
G	279.553	365769	10.039		10.039	10.039
N	257.61	187708	10.098		10.098	10.098
	766.491	2225	9.501		9.501	9.501
A	588.995	134344	10.137		10.137	10.137

ICB

CB

Begin Analysis - Sample Number 3

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61			
	Off Peak Int.	=	842	
	Off Peak Int.	=	855	
		No Peak!	909	60
FE	259.94	No Peak!	1401	1401
MG	279.553	No Peak!	446	446
CA	317.933	No Peak!	1363	1363

Analyze Samples

12-04-1992 @ 01:35:54 -- 3

AL	396.152	No Peak!	3598	3598
NA	588.995	-0.0002	24281	24281
K	766.491	No Peak!	1233	1233

Calculating Concentrations for Sample Number 3

Elem. Wave- length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
396.152	3598	0.001		0.001	0.001
317.933	1363	-0.017		< 0.010 <	0.010
259.94	1401	-0.003		< 0.010 <	0.010
279.553	446	-0.002		< 0.050 <	0.050
257.61	60	-0.001		< 0.000 <	0.000
766.491	1233	-0.343		< 0.050 <	0.050
588.995	24281	0.206		0.206	0.206

CB

Begin Analysis - Sample Number 4

Ele. Sym.	Wave- length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61			
	Off Peak Int.	=	854	
	Off Peak Int.	=	852	
		No Peak!	885	32
FE	259.94	No Peak!	1397	1397
MG	279.553	No Peak!	412	412
CA	317.933	No Peak!	1371	1371
AL	396.152	No Peak!	3561	3561
NA	588.995	-0.0001	27414	27414
K	766.491	No Peak!	1226	1226

Calculating Concentrations for Sample Number 4

Elem. Wave- length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
396.152	3561	-0.009		< 0.000 <	0.000
317.933	1371	-0.012		< 0.010 <	0.010
259.94	1397	-0.003		< 0.010 <	0.010
279.553	412	-0.003		< 0.050 <	0.050

mag

Analyze Samples

12-04-1992 @ 01:41:59 -- 4

MN 257.61	32	-0.002	<	0.000	<	0.000
766.491	1226	-0.412	<	0.050	<	0.050
588.995	27414	0.489		0.489		0.489

ICS A

Enter Sample Weight 2

Enter Sample Volume 50

ICS A

Begin Analysis - Sample Number 5

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61			
	Off Peak Int.	=	891	
	Off Peak Int.	=	869	
		No Peak!	922	42
FE	259.94	0.0003	48344	48344
MG	279.553	0.0003	714603	714603
CA	317.933	0.0002	32039	32039
AL	396.152	0.0003	75439	75439
NA	588.995	0.0001	25766	25766
K	766.491	No Peak!	1221	1221

Calculating Concentrations for Sample Number 5

Ele. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
L	396.152	75439	19.500		19.500	487.500
A	317.933	32039	19.999		19.999	499.975
E	259.94	48344	7.852		7.852	196.300
B	279.553	714603	19.627		19.627	490.675
M	257.61	42	-0.002		< 0.000 <	0.000
	766.491	1221	-0.462		< 0.050 <	0.050
A	588.995	25766	0.340		0.340	8.500

ICS AB

m30

Analyze Samples

12-04-1992 @ 01:45:08 -- 5

CS AB

Begin Analysis - Sample Number 6

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61			
	Off Peak Int.	=	883	
	Off Peak Int.	=	884	
		-0.0003	1284	400
FE	259.94	0.0000	48304	48304
MG	279.553	0.0002	703698	703698
CA	317.933	0.0003	31173	31173
AL	396.152	0.0001	75426	75426
NA	588.995	-0.0001	24815	24815
K	766.491	No Peak!	1247	1247

Calculating Concentrations for Sample Number 6

Ele. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
L	396.152	75426	19.496		19.496	487.400
A	317.933	31173	19.434		19.434	485.850
E	259.94	48304	7.846		7.846	196.150
B	279.553	703698	19.327		19.327	483.175
N	257.61	400	0.017		0.017	0.425
	766.491	1247	-0.204		< 0.050 <	0.050
A	588.995	24815	0.255		0.255	6.375

CCV

Enter Sample Weight 1

Enter Sample Volume 1

CV

Begin Analysis - Sample Number 7

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
-----------	-------------	--------------------	---------------------	--------------------

m31

Analyze Samples

12-04-1992 @ 01:48:09 -- 6

MN	257.61			
	Off Peak Int.	=	2421	
	Off Peak Int.	=	1883	
		-0.0001	185943	183791
FE	259.94	0.0000	60921	60921
MG	279.553	0.0001	354290	354290
CA	317.933	0.0001	16460	16460
AL	396.152	0.0001	39378	39378
NA	588.995	0.0003	129885	129885
K	766.491	-0.0002	2255	2255

Calculating Concentrations for Sample Number 7

Elem.	Wave- Sym. length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
L	396.152	39378	9.712		9.712	9.712
A	317.933	16460	9.834		9.834	9.834
E	259.94	60921	9.957		9.957	9.957
G	279.553	354290	9.723		9.723	9.723
N	257.61	183791	9.887		9.887	9.887
S	766.491	2255	9.799		9.799	9.799
A	588.995	129885	9.735		9.735	9.735
CCB						

CB

Begin Analysis - Sample Number 8

Ele.	Wave- Sym. length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61			
	Off Peak Int.	=	848	
	Off Peak Int.	=	864	
		No Peak!	890	34
FE	259.94	No Peak!	1404	1404
MG	279.553	No Peak!	445	445
CA	317.933	No Peak!	1363	1363
AL	396.152	No Peak!	3602	3602
NA	588.995	-0.0003	24437	24437
K	766.491	No Peak!	1246	1246

m 32

Analyze Samples

12-04-1992 @ 01:52:58 -- 7

Calculating Concentrations for Sample Number 8

Wavenumber	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
396.152	3602	0.002		0.002	0.002
317.933	1363	-0.017	<	0.010 <	0.010
259.94	1404	-0.002	<	0.010 <	0.010
279.553	445	-0.002	<	0.050 <	0.050
257.61	34	-0.002	<	0.000 <	0.000
766.491	1246	-0.214	<	0.050 <	0.050
588.995	24437	0.220		0.220	0.220

Water Sample Weight 100

Water Sample Volume 100

Begin Analysis - Sample Number 9

Element	Wavenumber	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61			
	Off Peak Int.	=	850	
	Off Peak Int.	=	855	
		No Peak!	881	28
FE	259.94	No Peak!	1401	1401
MG	279.553	No Peak!	434	434
CA	317.933	No Peak!	1358	1358
AL	396.152	No Peak!	3591	3591
NA	588.995	-0.0003	24338	24338
K	766.491	No Peak!	1253	1253

Calculating Concentrations for Sample Number 9

Wavenumber	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
396.152	3591	-0.001	<	0.000 <	0.000
317.933	1358	-0.020	<	0.010 <	0.010
259.94	1401	-0.003	<	0.010 <	0.010

m33

Analyze Samples

12-04-1992 @ 01:55:20 -- 8

279.553	434	-0.002	<	0.050	<	0.050
257.61	28	-0.003	<	0.000	<	0.000
766.491	1253	-0.144	<	0.050	<	0.050
588.995	24338	0.212		0.212		0.212
28958-1						

28958-1

Begin Analysis - Sample Number 10

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61			
	Off Peak Int.	=	948	
	Off Peak Int.	=	931	
		0.0002	7874	6934
FE	259.94	0.0000	83312	83312
MG	279.553	0.0003	376714	376714
CA	317.933	0.0001	131095	131095
AL	396.152	0.0001	28051	28051
NA	588.995	OVER RANGE! Retrying Integration and Read: Retry Number 1		
		OVER RANGE! Retrying Integration and Read: Retry Number 2		
		Attempted Integration and Read: Failed 3 times		
		Integration and Read Aborted with INTENSITY OVER RANGE Error		
		Overflow		
K	766.491	0.0001	2876	2876

Calculating Concentrations for Sample Number 10

Ele. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
L	396.152	28051	6.638		6.638	6.638
A	317.933	131095	84.630		84.630	84.630
E	259.94	83312	13.704		13.704	13.704
B	279.553	376714	10.340		10.340	10.340
N	257.61	6934	0.369		0.369	0.369
	766.491	2876	15.962		15.962	15.962
A	588.995	Overflow				
28958-1 DUP						

m34

Analyze Samples

12-04-1992 @ 02:00:40 -- 9

8958-1 DUP

Begin Analysis - Sample Number 11

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
-----------	-------------	--------------------	---------------------	--------------------

MN	257.61			
	Off Peak Int.	=	957	
	Off Peak Int.	=	924	
		-0.0003	7630	6689
FE	259.94	-0.0002	83622	83622
MG	279.553	0.0000	377093	377093
CA	317.933	0.0004	130701	130701
AL	396.152	0.0001	27959	27959

NA 588.995 OVER RANGE! Retrying Integration and Read: Retry Number 1
 OVER RANGE! Retrying Integration and Read: Retry Number 2
 Attempted Integration and Read: Failed 3 times
 Integration and Read Aborted with INTENSITY OVER RANGE Error
 Overflow

K	766.491	-0.0002	3660	3660
---	---------	---------	------	------

Calculating Concentrations for Sample Number 11

Elem. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
L	396.152	27959	6.613		6.613	6.613
A	317.933	130701	84.373		84.373	84.373
E	259.94	83622	13.755		13.755	13.755
G	279.553	377093	10.350		10.350	10.350
N	257.61	6689	0.356		0.356	0.356
	766.491	3660	23.742		23.742	23.742
A	588.995	Overflow				

28958-1 MS

8958-1 MS

Begin Analysis - Sample Number 12

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
-----------	-------------	--------------------	---------------------	--------------------

m35

Analyze Samples

12-04-1992 @ 02:05:07 -- 10

MN	257.61			
	Off Peak Int.	=	1390	
	Off Peak Int.	=	1205	
		-0.0001	55531	54233
FE	259.94	-0.0002	97629	97629
MG	279.553	0.0000	469712	469712
CA	317.933	0.0002	134965	134965
AL	396.152	0.0001	37762	37762
NA	588.995	OVER RANGE! Retrying Integration and Read: Retry Number 1		
		OVER RANGE! Retrying Integration and Read: Retry Number 2		
		Attempted Integration and Read: Failed 3 times		
		Integration and Read Aborted with INTENSITY OVER RANGE Error		
		Overflow		
K	766.491	-0.0004	4799	4799

Calculating Concentrations for Sample Number 12

Elem. Wave- Sym. length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
L 396.152	37762	9.273		9.273	9.273
A 317.933	134965	87.155		87.155	87.155
E 259.94	97629	16.099		16.099	16.099
G 279.553	469712	12.896		12.896	12.896
N 257.61	54233	2.915		2.915	2.915
	766.491	4799		35.044	35.044
A 588.995	Overflow				

28958-1 MSD

8958-1 MSD

Begin Analysis - Sample Number 13

Ele. Wave- Sym. length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61		
	Off Peak Int.	=	1387
	Off Peak Int.	=	1220
		0.0000	57987
FE	259.94	-0.0002	100151
MG	279.553	0.0000	476865
CA	317.933	0.0006	131744

m.36

Analyze Samples

12-04-1992 @ 02:09:35 -- 11

AL	396.152	0.0001	38922	38922
NA	588.995	OVER RANGE!	Retrying Integration and Read: Retry Number 1	
0.0009	426376		426376	
K	766.491	0.0004	2012	2012

Calculating Concentrations for Sample Number 13

Elem. Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
396.152	38922	9.588		9.588	9.588
317.933	131744	85.054		85.054	85.054
259.94	100151	16.521		16.521	16.521
279.553	476865	13.092		13.092	13.092
257.61	56683	3.046		3.046	3.046
766.491	2012	7.388		7.388	7.388
588.995	426376	36.485		36.485	36.485

LCS I

S I

Origin Analysis - Sample Number 14

Elem. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61			
	Off Peak Int.	=	1349	
	Off Peak Int.	=	1153	
		-0.0002	56033	54782
FE	259.94	-0.0001	18702	18702
MG	279.553	-0.0001	107530	107530
CA	317.933	0.0005	5979	5979
AL	396.152	0.0001	14544	14544
NA	588.995	0.0002	204456	204456
K	766.491	0.0002	2262	2262

Calculating Concentrations for Sample Number 14

Elem. Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
396.152	14544	2.972		2.972	2.972

m37

Analyze Samples

12-04-1992 @ 02:13:13 -- 12

317.933	5979	2.995	2.995	2.995
259.94	18702	2.892	2.892	2.892
279.553	107530	2.941	2.941	2.941
257.61	54782	2.944	2.944	2.944
766.491	2262	9.869	9.869	9.869
588.995	204456	16.463	16.463	16.463
28958-2				

28958-2

Begin Analysis - Sample Number 15

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61			
	Off Peak Int.	=	912	
	Off Peak Int.	=	905	
		0.0004	3040	2131
FE	259.94	0.0002	30216	30216
MG	279.553	0.0001	239547	239547
CA	317.933	0.0004	62660	62660
AL	396.152	-0.0001	13210	13210
NA	588.995	OVER RANGE!	Retrying Integration and Read:	Retry Number 1
		OVER RANGE!	Retrying Integration and Read:	Retry Number 2
			Attempted Integration and Read:	Failed 3 times
			Integration and Read Aborted with INTENSITY OVER RANGE Error	
			Overflow	
K	766.491	0.0003	2113	2113

Calculating Concentrations for Sample Number 15

Ele. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
	396.152	13210	2.609		2.609	2.609
	317.933	62660	39.978		39.978	39.978
	259.94	30216	4.819		4.819	4.819
	279.553	239547	6.570		6.570	6.570
	257.61	2131	0.110		0.110	0.110
	766.491	2113	8.390		8.390	8.390
	588.995	Overflow				
28958-3						

m38

Analyze Samples

12-04-1992 @ 02:18:02 -- 13

8958-3

Begin Analysis - Sample Number 16

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61			
	Off Peak Int.	=	881	
	Off Peak Int.	=	867	
		-0.0001	1807	933
FE	259.94	-0.0001	8064	8064
MG	279.553	-0.0002	600365	600365
CA	317.933	0.0005	96460	96460
AL	396.152	0.0007	6269	6269
NA	588.995	0.0007	634655	634655
K	766.491	-0.0005	2189	2189

Calculating Concentrations for Sample Number 16

em. Wavelength	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
396.152	6269	0.726		0.726	0.726
317.933	96460	62.032		62.032	62.032
259.94	8064	1.112		1.112	1.112
279.553	600365	16.487		16.487	16.487
257.61	933	0.046		0.046	0.046
766.491	2189	9.144		9.144	9.144
588.995	634655	55.278		55.278	55.278

28958-4

8958-4

Begin Analysis - Sample Number 17

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61			

m39

Analyze Samples

12-04-1992 @ 02:21:43 -- 14

Off Peak Int. = 847
Off Peak Int. = 843

		0.0002	1887	1042
FE	259.94	0.0000	10160	10160
MG	279.553	0.0004	517291	517291
CA	317.933	0.0008	57114	57114
AL	396.152	0.0008	6845	6845

OVER RANGE! Retrying Integration and Reads: Retry Number 1
OVER RANGE! Retrying Integration and Reads: Retry Number 2

Peak!	157472		157472	
K	766.491	0.0001	1552	1552

Calculating Concentrations for Sample Number 17

Elem. Wave- Sym. length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
L 396.152	6845	0.882		0.882	0.882
A 317.933	57114	36.359		36.359	36.359
E 259.94	10160	1.463		1.463	1.463
S 279.553	517291	14.203		14.203	14.203
H 257.61	1042	0.052		0.052	0.052
J 766.491	1552	2.823		2.823	2.823
A 588.995	157472	12.224		12.224	12.224

28958-5

8958-5

Begin Analysis - Sample Number 18

Ele. Wave- Sym. length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61		
Off Peak Int.	=	849	
Off Peak Int.	=	851	
	0.0002	2057	1207
FE	259.94	0.0003	11182
MG	279.553	0.0006	533550
CA	317.933	0.0010	65929

m40

Analyze Samples

12-04-1992 @ 02:25:51 -- 15

AL	396.152	0.0005	7483	7483
NA	588.995	OVER RANGE!	Retrying Integration and Read:	Retry Number 1
		OVER RANGE!	Retrying Integration and Read:	Retry Number 2
	0.0033	419242	419242	
K	766.491	0.0000	1550	1550

Calculating Concentrations for Sample Number 18

Elem. Wave- Sym. length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
L 396.152	7483	1.055		1.055	1.055
M 317.933	65929	42.111		42.111	42.111
E 259.94	11182	1.634		1.634	1.634
S 279.553	533550	14.650		14.650	14.650
M 257.61	1207	0.061		0.061	0.061
K 766.491	1550	2.803		2.803	2.803
NA 588.995	419242	35.842		35.842	35.842

CCV

Begin Analysis - Sample Number 19

Ele. Wave- Sym. length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61		
	Off Peak Int. =	2206	
	Off Peak Int. =	1819	
	0.0003	175632	173619
FE	259.94	56893	56893
MG	279.553	334388	334388
CA	317.933	15336	15336
AL	396.152	37621	37621
NA	588.995	204264	204264
K	766.491	2410	2410

Calculating Concentrations for Sample Number 19

Elem. Wave- Sym. length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
----------------------------	-----------------------	-----------------------------	----------------------------	----------------------	------------------------

m41

Analyze Samples

12-04-1992 @ 02:30:12 -- 16

396.152	37621	9.235	9.235	9.235
317.933	15336	9.100	9.100	9.100
259.94	56893	9.283	9.283	9.283
279.553	334388	9.176	9.176	9.176
257.61	173619	9.340	9.340	9.340
766.491	2410	11.337	11.337	11.337
588.995	204264	16.445	16.445	16.445

CV

Begin Analysis - Sample Number 20

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
-----------	-------------	--------------------	---------------------	--------------------

CCB

CB

Begin Analysis - Sample Number 20

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
-----------	-------------	--------------------	---------------------	--------------------

MN	257.61			
	Off Peak Int.	=	820	
	Off Peak Int.	=	798	
		No Peak!	834	25
FE	259.94	No Peak!	1343	1343
MG	279.553	No Peak!	416	416
CA	317.933	No Peak!	1310	1310
AL	396.152	No Peak!	3404	3404
NA	588.995	0.0006	67846	67846
K	766.491	No Peak!	1366	1366

Calculating Concentrations for Sample Number 20

Ele. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
	396.152	3404	-0.052	<	0.000 <	0.000

m42

Analyze Samples

12-04-1992 @ 02:36:01 -- 17

317.933	1310	-0.051	<	0.010	<	0.010
259.94	1343	-0.012	<	0.010	<	0.010
279.553	416	-0.003	<	0.050	<	0.050
257.61	25	-0.003	<	0.000	<	0.000
766.491	1366	0.977		0.977		0.977
588.995	67846	4.137		4.137		4.137
28958-6						

28958-6

Begin Analysis - Sample Number 21

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61			
	Off Peak Int.	=	837	
	Off Peak Int.	=	811	
		0.0001	1718	894
FE	259.94	0.0001	9475	9475
MG	279.553	-0.0001	726530	726530
CA	317.933	0.0003	114954	114954
AL	396.152	0.0006	6255	6255
NA	588.995	0.0006	860031	860031
K	766.491	0.0000	2147	2147

Calculating Concentrations for Sample Number 21

Ele. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
	396.152	6255	0.722		0.722	0.722
	317.933	114954	74.099		74.099	74.099
	259.94	9475	1.348		1.348	1.348
	279.553	726530	19.954		19.954	19.954
	257.61	894	0.044		0.044	0.044
	766.491	2147	8.727		8.727	8.727
	588.995	860031	75.612		75.612	75.612

28958-6 SER DIL

Water Sample Weight 1

Water Sample Volume 4

m43

Analyze Samples

12-04-1992 @ 02:41:57 -- 18

8958-6 SER DIL

Begin Analysis - Sample Number 22

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61			
	Off Peak Int.	=	823	
	Off Peak Int.	=	806	
		0.0000	1088	273
FE	259.94	0.0001	3483	3483
MG	279.553	0.0001	193562	193562
CA	317.933	0.0009	31037	31037
AL	396.152	No Peak!	4084	4084
NA	588.995	0.0006	268731	268731
K	766.491	No Peak!	1405	1405

Calculating Concentrations for Sample Number 22

Elem. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
AL	396.152	4084	0.133		0.133	0.532
CA	317.933	31037	19.345		19.345	77.380
FE	259.94	3483	0.346		0.346	1.384
MG	279.553	193562	5.306		5.306	21.224
MN	257.61	273	0.010		0.010	0.040
K	766.491	1405	1.364		1.364	5.456
NA	588.995	268731	22.262		22.262	89.048

ICS A

Water Sample Weight 2

Water Sample Volume 50

CS A

Begin Analysis - Sample Number 23

m44

Analyze Samples

12-04-1992 @ 02:44:47 -- 19

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61			
	Off Peak Int.	=	837	
	Off Peak Int.	=	829	
		No Peak!	873	40
FE	259.94	0.0002	55766	55766
MG	279.553	0.0002	788665	788665
CA	317.933	0.0015	36344	36344
AL	396.152	0.0014	88012	88012
NA	588.995	0.0008	64757	64757
K	766.491	No Peak!	1284	1284

Calculating Concentrations for Sample Number 23

Ele. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
	396.152	88012	22.912		22.912	572.800
	317.933	36344	22.808		22.808	570.200
	259.94	55766	9.094		9.094	227.350
	279.553	788665	21.662		21.662	541.550
	257.61	40	-0.002	<	0.000 <	0.000
	766.491	1284	0.163		0.163	4.075
	588.995	64757	3.858		3.858	96.450

ICS AB

ICS AB

Begin Analysis - Sample Number 24

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61			
	Off Peak Int.	=	890	
	Off Peak Int.	=	863	
		0.0006	1334	457
FE	259.94	0.0003	53991	53991
MG	279.553	0.0003	788365	788365
CA	317.933	0.0014	34949	34949
AL	396.152	0.0013	84661	84661
NA	588.995	0.0007	64219	64219

m45

Analyze Samples

12-04-1992 @ 02:49:24 -- 20

K 766.491 No Peak! 1326 1326

Calculating Concentrations for Sample Number 24

Wavelength	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
396.152	84661	22.003		22.003	550.075
317.933	34949	21.897		21.897	547.425
259.94	53991	8.797		8.797	219.925
279.553	788365	21.654		21.654	541.350
257.61	457	0.020		0.020	0.500
766.491	1326	0.580		0.580	14.500
588.995	64219	3.810		3.810	95.250

CCV

Origin Analysis - Sample Number 25

Element	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61			
	Off Peak Int.	=	2456	
	Off Peak Int.	=	2095	
		0.0005	213361	211085
FE	259.94	0.0002	68368	68368
MG	279.553	0.0001	392345	392345
CA	317.933	0.0015	18501	18501
AL	396.152	0.0009	44016	44016
NA	588.995	0.0009	182757	182757
K	766.491	0.0011	2388	2388

Calculating Concentrations for Sample Number 25

Wavelength	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
396.152	44016	10.971		10.971	274.275
317.933	18501	11.165		11.165	279.125
259.94	68368	11.203		11.203	280.075
279.553	392345	10.769		10.769	269.225

m46

Analyze Samples

12-04-1992 @ 02:52:05 -- 21

MN	257.61	211085	11.356	11.356	283.900
	766.491	2388	11.119	11.119	277.975
NA	588.995	182757	14.505	14.505	362.625

Enter Sample Weight 1

Enter Sample Volume 1

CV

Begin Analysis - Sample Number 26

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61			
	Off Peak Int.	=	2538	
	Off Peak Int.	=	2076	
		0.0003	203935	201628
FE	259.94	0.0001	66129	66129
MG	279.553	0.0006	383586	383586
CA	317.933	0.0016	18334	18334
AL	396.152	0.0008	42974	42974
NA	588.995	0.0010	178581	178581
K	766.491	0.0006	2424	2424

Calculating Concentrations for Sample Number 26

Elem. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
AL	396.152	42974	10.688		10.688	10.688
CA	317.933	18334	11.056		11.056	11.056
FE	259.94	66129	10.828		10.828	10.828
MG	279.553	383586	10.529		10.529	10.529
MN	257.61	201628	10.847		10.847	10.847
K	766.491	2424	11.476		11.476	11.476
NA	588.995	178581	14.128		14.128	14.128

CV

Begin Analysis - Sample Number 27

1747

Analyze Samples

12-04-1992 @ 03:00:21 -- 22

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61			
	Off Peak Int.	=	2500	
	Off Peak Int.	=	2117	
		0.0004	197815	195506
FE	259.94	0.0002	65340	65340
MG	279.553	0.0003	379071	379071
CA	317.933	0.0012	17778	17778
AL	396.152	0.0007	41144	41144
NA	588.995	0.0011	170057	170057
K	766.491	0.0016	2399	2399

Calculating Concentrations for Sample Number 27

Elem. Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
AL	396.152	41144	10.191		10.191	10.191
CA	317.933	17778	10.694		10.694	10.694
FE	259.94	65340	10.696		10.696	10.696
MG	279.553	379071	10.405		10.405	10.405
MN	257.61	195506	10.518		10.518	10.518
K	766.491	2399	11.228		11.228	11.228
NA	588.995	170057	13.359		13.359	13.359
CCB						

Origin Analysis - Sample Number 28

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61			
	Off Peak Int.	=	948	
	Off Peak Int.	=	957	
		No Peak!	1025	72
FE	259.94	No Peak!	1574	1574
MG	279.553	0.0001	603	603
CA	317.933	No Peak!	1521	1521
AL	396.152	No Peak!	3934	3934

m48

Analyze Samples

12-04-1992 @ 03:04:29 -- 23

NA	588.995	0.0009	58817	58817
K	766.491	No Peak!	1309	1309

Calculating Concentrations for Sample Number 28

Wavelength	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
396.152	3934	0.092		0.092	0.092
317.933	1521	0.086		0.086	0.086
259.94	1574	0.026		0.026	0.026
279.553	603	0.002		0.050	0.050
257.61	72	0.000		0.000	0.000
766.491	1309	0.411		0.411	0.411
588.995	58817	3.322		3.322	3.322

Origin Analysis - Sample Number 29

Ele. Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	Net Peak Intensity
MN	257.61			
	Off Peak Int.	=	924	
	Off Peak Int.	=	910	
		No Peak!	964	47
FE	259.94	No Peak!	1542	1542
MG	279.553	No Peak!	466	466
CA	317.933	No Peak!	1495	1495
AL	396.152	No Peak!	3938	3938
NA	588.995	0.0007	56029	56029
K	766.491	No Peak!	1305	1305

Calculating Concentrations for Sample Number 29

Wavelength	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
396.152	3938	0.093		0.093	0.093
317.933	1495	0.069		0.069	0.069
259.94	1542	0.021		0.021	0.021
279.553	466	-0.001		0.050	0.050
257.61	47	-0.002		0.000	0.000

m49

Analyze Samples

12-04-1992 @ 03:07:09 -- 24

766.491
588.995

1305
56029

0.372
3.071

0.372
3.071

0.372
3.071

6

TITLE

TSS

PROJECT NO.

GC1

BOOK NO. 1931

SAMPLE	ID	AMT.	Wt. # 1	Wt. # 2	Wt. # 3	\bar{X} INITIAL Wt.
Blank	A	100ml	2.1795	2.1794		
28958-1	B	100ml	2.1060	2.1058		
-1 dup	C	100ml	2.1895	2.1893		
-2	D	100ml	2.1957	2.1955		
-3	E	100ml	2.1924	2.1922		
-4	F	100ml	2.2011	2.2008		
-5	G	100ml	2.0668	2.0664		
28959-1	H	100ml	2.3407	2.3403		
28967-1	I	100ml	1.9418	1.9414		
28969-	J	100ml 75ml	2.1162	2.1158		
			N. Sojan Pallin			11/18/92
Blank	K	100ml	2.0928	2.0930		
28981-4	L	100ml	2.1804	2.1805		
-4 dup	M	100ml	2.1103	2.1105		
-3	N	100ml	2.0332	2.0334		
28977-2	O	100ml	2.0919	2.0920		
-3	P	20ml	2.1706	2.1708		
-4	Q	100ml	2.0531	2.0533		
28970-1	R	70ml	2.1780	2.1781		
28972-1	S	100ml	2.1636	2.1637		
28978-1	T	100ml	2.1276	2.1278		
-2	U	100ml	2.1854	2.1856		
28987-1	V	100ml	2.0974	2.0975		
			N. Sojan Pallin			11/19/92

SIGNATURE

DATE

CLOSED TO AND UNDERSTOOD BY

DATE

WITNESS

DATE

TITLE

PROJECT NO.

6027

BOOK NO.

1931

FINAL WT.

ID	WT. #1	WT #2	WT. #3	FINAL WT. WT #4	PPB
A	2.1791	2.1791			3000
B	2.1687	2.1689			629,000
C	2.2523	2.2524			630,000
D	2.2683	2.2684			728,000
E	2.1931	2.1930			7,000
F	2.2013	2.2012			2,000
G	2.0743	2.0743			77,000
H	2.3407	2.3406			1,000
I	1.9419	1.9416			2,000
J	2.1290	2.1288			286,667
K	2.0928	2.0928			RD 1000 10,000
L	2.1806	2.1804			1,000
M	2.1105	2.1103			
N	2.0335	2.0334			1,000
O	2.1003	2.1001			82,000
P	2.2512	2.2512			4,025,000
Q	2.0567	2.0565			34,000
R	2.1894	2.1892			161,429
S	2.1698	2.1696			61,000
T	2.1286	2.1284			8,000
U	2.1892	2.1890			36,000
V	2.1112	2.1110			137,000
N. Spina-Rollin 11/19/92					

SCIENTIFIC BONDING PRODUCTS CHICAGO

SIGNATURE

DATE

DISCLOSED TO AND UNDERSTOOD BY

DATE


WITNESS

DATE

N EDTA = 0.02 \Rightarrow ctk 0.2198

Sample	Amt	Initial Titant	Final Titant	Total Titant	Hardness (ppb)
Blank	50	0.00	0.01	0.01	10004
CaCO ₃ ctk	10	0.00	10.08	10.08	0.0198
28980-1	50 40	0.00	3.10	3.10	61,380
28958-1	25	2.00 40	7.00	5.00	198,000
-2	25	0.00	4.00	4.00	158,400
-3	25	5.00	11.30	6.30	249,480
-4	25	0.00	4.50	4.50	178,200
-5	25	0.00	4.80	4.80	190,080
-6	25	5.00	11.20	6.00	237,600
28980-1 DNF	25	0.00	1.80	1.80	71,280

Yvette O'Hara 12/1/92



SIGNATURE

DATE

RECORDED AND INDEXED BY

DATE

WITNESS

DATE

Yvette O'Hara

STD	Absorbance	Blank corrected	
Blank	0.069	-	
1.0	0.087	0.018	Corr = 0.9991
5.0	0.136	0.067	slope = 0.011
15	0.249	0.180	Yint = 0.0144
30	0.405	0.336	
40	0.496	0.427	

Sample	Int	F.V.	D.F.	Abs.	Blank corrected	PPB	Comments
28942-1	1.0	50	1:50	0.334	0.265	1192,660 (31.26)	20g/20ml
-1MS	↓	↓	↓	0.462	0.393	100%	(31.46)
-1MSD	↓	↓	↓	0.460	0.391	99% RSD	
28958-1	0.5	50	1:100	0.435	0.326	3346,557 (32.29)	
-1MS	↓	↓	↓	0.493	0.421	103%	(31.42)
-1MSD	↓	↓	↓	0.491	0.422	102%	1% RSD
-2	0.5	50	1:100	0.551	0.482	4450,550	
-3	25	50	1:2	0.413	0.344	62,744	
-4	1.0	50	1:50	0.230	0.161	697,767	
-5	1.0	50	1:50	0.239	0.170	740,594	
-6	25	50	1:2	0.459	0.390	71,499	
-2R	0.25 0.069	50	1:200	0.330	0.261	4694,504	Report this in 40
Plasma Chem STD	50	50	-	0.399	0.330	98% (30.04)	30 ppm (30.6)

spt = 40 mls of 10 ppm
~~10 mls of sample~~
 10 mls of sample

SCIENTIFIC SERVICE PRODUCTS DIVISION

SIGNATURE <i>Yvette O. Garro</i>		DATE 12/2/92	
DISCLOSED TO AND UNDERSTOOD BY <i>AAW</i>	DATE	WITNESS	DATE

194

TITLE

TDS

PROJECT NO.

BOOK NO.

1745

GC5

SAMPLE	ID	AMT.	Wt. 1	Wt. 2	Wt. 3	\bar{X} FINAL Wt
28917-2	D9	100ml	69.7992	69.7992		
28919-3	Z7	100ml	68.9360	68.9360		
-4	AM	100ml	73.4501	73.4500		
-5	Cr	100ml	70.6216	70.6214		
28920-1	Q	100ml	60.1713	60.1712		
28934-1	G ₂	100ml	77.5386	77.5396	77.5394	
	Y₆		68.6990	68.6998	68.6994	
	G		67.0502	67.0509	67.0505	Void net
	Q₂		76.1079	76.1086	76.1083	
	N. Sophia Rollin 11/13/92					
Blank	33	100ml	78.5730	78.5727		
28937-1	34	100 ⁵⁰ ml	78.7238	78.7236		
-1 dup	36	50ml	78.1683	78.1686		
	B₂		73.2614	73.2618		Void net
	N. Sophia Rollin 11/16/92					
Blank	B ₂	100ml	73.2620	73.2620		
28958-1	30	100ml	76.7408	76.7405		
-1 dup	K	100ml	75.2030	75.2029		
-2	31	100ml	74.5443	74.5443		
-3	PM	100ml	72.6180	72.6170	72.6172	
-4	H ₂	100ml	76.3585	76.3583		
-5	32	100ml	73.4069	73.4066		
	N. Sophia Rollin 11/18/92					
20967-2	S₆	100 ml	67.9900	67.9900	-	67.9900
3	AM	100 ml	69.1679	69.1679	-	69.1679
1	F	100 ml	69.1673	69.1673	-	69.1673

SIGNATURE

DATE

DISCLOSED TO AND UNDERSTOOD BY

DATE

WITNESS

DATE

TITLE

TDS

PROJECT NO.

BOOK NO.

1745

G6195

ID	wt #1	wt #2	wt #3	wt #4	\bar{X} FINAL	PPB
D9	69.8296	69.8292				302,000
Z7	68.9985	68.9985				625,000
AM	73.4667	73.4665				166,000
Cr	70.6499	70.6498				283,000
Q	60.2230	60.2226				516,000
G2	77.5601	77.5598				205,000
33	78.5724	78.5735	78.5738			7,500
34	78.7296	78.7318	78.7324	78.7327		178,000
36	78.1755	78.1773	78.1778			184,000
B2	73.2616	73.2618				3,000
30	77.8880	77.8881				1,473,000
K	76.3499	76.3499				1,469,000
31	76.2150	76.2150				16,707,000
PM	72.6620	72.6622				450,000
H2	76.6043	76.6043				2,459,000
32	73.6600	73.6601				2,533,000
Sh	68.0183	68.0183				283,000
AM	69.2164	69.2164				485,000
P	69.1968	69.1968				295,000
SIGNATURE						DATE
DISCLOSED TO AND UNDERSTOOD BY						DATE
						DATE
						DATE

TITLE

PH

PROJECT NO.

G07 135

BOOK NO.

Date	Sample	PH	Calibration
11/17/92	28969-1	7.18 ①	4.00-set 7.00 set 10.00 → 9.96
	28967-1	8.39 ①	10-set 4.00 set 7.00 set 4.00 - 4.02
	28958-1	9.36 ②	
	-2	9.39 ②	
	-3	8.00 ①	7.67
	-3dup	8.00 ①	
	4	8.48 ①	
	5	8.75 ②	

11/17/92 R

Date	Sample	PH	Calibration
11/18/92	28808-11	10.65	Calibration
	28887-2	6.56	50.10g ① 7.00-set, 4.00-set
	28805-25	7.67	20.01g 10 - 10.10
	28805-26	7.92	20.03g in 50ml DI H ₂ O
	28902-1	7.82	50.06g

N. Sujin Hollis

② 7.00-set
10.0 set
4.00 - 3.88

11/18/92	28977-1	7.28	②
	-3	7.04	
	-4	7.49	
	28976-1	6.03	
	-2	6.47	
	-3	6.52	

Next page

SIGNATURE		DATE	
DISCLOSED TO AND UNDERSTOOD BY		DATE	WITNESS
			DATE 12/7/92

APPENDIX C

12.3 Adirondack Environmental Laboratory Report

28 Springdale Road
Cherry Hill, New Jersey 08003
(609) 751-1122 • (215) 923-2068
Fax: (609) 751-0824

Chain-of-Custody

454 South Anderson Road BTC 532
Rock Hill, South Carolina 29730
(803) 329-9690
Fax: (803) 329-9689

Client RICH SCHLAUEH

Project: SALT KILL

NORTE
~~AnalytiKEM~~ Contact DICK FRANKLIN

SAMPLE DESIGNATION	DATE	MATRIX	40 ml vials	950 ml Org. Pres.	ml Unpres.	ml Unpres.	ml HNO ₃	ml H ₂ SO ₄	ml H ₂ SO ₄	ml NaOH				PARAMETERS
C 2	11/23/92	SOLID POWDER	X											EDS ANALYSIS FOR COMPOUNDS PER ATTACHED SHEET (CaCO ₃ as a Minimum)
E 2	11/23/92	SOLID POWDER	X											EDS ANALYSIS FOR COMPOUNDS PER ATTACHED SHEET (CaCO ₃ as a Minimum)
F 1	11/23/92	SOLID GRANULAR	X											EDS ANALYSIS PER ATTACHED SHEET
F 2	11/23/92	SOLID POWDER	X											EDS ANALYSIS PER ATTACHED SHEET

1. Field Measurements:
Data Sheets: Y N
Filtered: Y Not Required

II. Field Conditions/Comments: all samples have been separated from creek water by laboratory filtration and dried at 104° C.

III. Special Instructions: Note: If all compounds per attached sheet cannot be analyzed (Detection Limits, Data Package, etc.) due to limited sample quantity for C2 & E2, analyze CaCO₃ as the priority compound.

Relinquished By:	Time/Date:	Received By:	Time/Date:
<u>R. Schlaueh</u>	<u>11:00 AM Nov. 23, 1992</u>		

TO: Dick Franklin

Nerlite

FROM: Rich Schlauch

THERMOLKEM

DATE: OCT. 20, 1992

II PAGES: 1

IF THIS FAX IS RECEIVED INCOMPLETE, PLEASE CALL RICH

AT 803/324-5310.

THANK YOU!

Dick; Please have the lab give price for the following by X-ray diffraction (etc.) as an alternative to individual elements.

Determine percentages of following compounds plus total carbon in oven dried sediment.

calcium carbonate - CaCO_3

magnesium oxide - MgO

manganese dioxide - MnO_2

aluminum oxide - Al_2O_3

iron(III) oxide - Fe_2O_3

calcium sulfite - $\text{CaSO}_3 \cdot \frac{1}{2}\text{H}_2\text{O}$

calcium sulfate - CaSO_4

magnesium metasilicate - MgSiO_3

manganese metasilicate - MnSiO_3

iron orthosilicate - Fe_2SiO_4

aluminum silicate - $\text{Al}_2\text{O}_3 \cdot \text{SiO}_2$

Total Carbon - T-C

Thanks,
Rich



314 North Pearl Street
Albany, New York 12207
518-434-4546/434-0891 FAX

A full service analytical research laboratory offering solutions to environmental concerns

LABORATORY REPORT

For

Norlite Corporation
628 Saratoga Street
Cohoes, New York 12047

Attention: Mr. Dick Franklin

Report Date: 01/19/93
Number of samples analyzed: 04
AES Project ID: 921208LC



314 North Pearl Street
Albany, New York 12207
518-434-4546/434-0891 FAX

A full service analytical research laboratory offering solutions to environmental concerns

X-RAY DIFFRACTION ANALYSIS OF POWDER SPECIMENS

ABSTRACT

Four powder specimens designated C-2, E-2, F-1 and F-2 were submitted for analysis using x-ray diffraction (XRD) techniques. The purpose of the analysis was to (1) determine chemical composition and (2) report quantitative data relative to twelve compounds of specific interest for each powder specimen.

TEST RESULTS

The following information was provided during examination of the powder specimens:

EDS: Energy dispersive x-ray spectroscopy (EDS) analysis is performed prior to x-ray diffraction (XRD) to expedite diffractogram interpretation. The EDS elemental profiles are presented with the diffractograms within this report. All four powder specimens produced EDS data which indicates calcium and silicon concentrations with traces of magnesium, aluminum, sulfur, potassium, titanium, manganese and iron.

XRD: Calcium carbonate and quartz concentrations were positively identified for all four powder specimens; quantitative determinations are provided in Figure One within this report. Identification and/or quantification for the other 10 compounds of interest could not be obtained using standard XRD procedures since these concentrations are less than the limit of detection (3% by weight).



314 North Pearl Street
Albany, New York 12207
518-434-4548/434-0891 FAX

A full service analytical research laboratory offering solutions to environmental concerns

XRD QUANTITATIVE DATA

Compound	Smp1. C-2	Smp1. E-2	Smp1. F-1	Smp1. F-2
CaCO ₃	78.73%	7.83%	52.14%	31.82%
SiO ₂	12.29%	58.32%	26.25%	43.12%
MgO	BDL	BDL	BDL	BDL
MnO ₂	BDL	BDL	BDL	BDL
Al ₂ O ₃	BDL	BDL	BDL	BDL
Fe ₂ O ₃	BDL	BDL	BDL	BDL
CaSO ₃	BDL	BDL	BDL	BDL
CaSO ₄	BDL	BDL	BDL	BDL
MgSiO ₃	BDL	BDL	BDL	BDL
MnSiO ₃	BDL	BDL	BDL	BDL
Fe SiO ₂ ₄	BDL	BDL	BDL	BDL
Al ₂ O ₃	BDL	BDL	BDL	BDL

BDL - Below Detection Limit of 3% by weight

FIGURE ONE



314 North Pearl Street
Albany, New York 12207
518-434-4546/434-0891 FAX

A full service analytical research laboratory offering solutions to environmental concerns


SPECIMEN PREPARATION

Representative powder sample was packed into graphite crucibles and subjected to energy dispersive x-ray spectroscopy (EDS) analysis in the scanning electron microscope. These sample mounts were then submitted for x-ray diffraction (XRD) analysis.

XRD ANALYSIS

The samples were subjected to a 40kV copper x-ray source from 20 through 50 degrees two-theta. The JCPDS indexing system was used to identify the peaks recorded on the XRD diffractograms (Figures Two through Five). A computer program was implemented to transfer reported integral counts beneath the XRD peak positions to concentration data.


Adirondack Environmental Services, Inc.




Thomas K. Ware
Laboratory Manager

Norlite Corporation
AES Report No. 921208LC


921208 LC 01




921208 LC 02



911208 LC 03



921208 LC 04





314 North Pearl Street
 Albany, New York 12207
 518-434-4546 / 434-0891 FAX

A full service analytical research laboratory offering solutions to environmental concerns

CHAIN OF CUSTODY RECORD

CLIENT NAME NORLITE CORPORATION	PROJECT NAME (Location)	SAMPLERS' (Name) FRANK W. KOVACS
ADDRESS Cobles, N.Y. 12047	PO NUMBER	SAMPLERS: (Signature) <i>[Signature]</i>

AES SAMPLE NUMBER	CLIENT SAMPLE IDENTIFICATION & LOCATION	DATE SAMPLED	TIME A.M./P.M.	SAMPLE TYPE			NUMBER OF CONT'S	ANALYSIS REQUIRED
				MATRIX	COMB	GRAB		
921208LC01, 2	C-7 & E-7	11-23-92		?		X	2	Calcium Carbonate
LC03.4	E1 & F2	11-23-92		?		X	2	*See Below
Analysis for the following MATERIAL VIA XRD								
* CaCO ₃ ; MgO; MnO ₂ ; CuSO ₄ ; Al ₂ O ₃ ; Fe ₂ O ₃ ; Calcium Sulfates; CaSO ₄ ; MgSiO ₃ ; MnSiO ₃ ; Fe ₂ SiO ₄ ; Al ₂ O ₃ · SiO ₂								
* If ANY Question CALL FRANK KOVACS								
THANK YOU!								

Turnaround Time: **10 DAYS** Laboratory Approval: *[Signature]*

Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature)	Date/Time
Relinquished by: (Signature)	Received by: (Signature)	Date/Time
Relinquished by: (Signature)	Received by: (Signature)	Date/Time
Dispatched by: (Signature)	Date/Time	Received for Laboratory by: <i>[Signature]</i>
Method of Shipment:		Date/Time 12/7/92 13:30
Send Report to: Dick Franklin		Client Phone No.: 235-0401

The Laboratory reserves the right to return hazardous samples to the client or may levy a fee of \$10.00 per container for disposal.

APPENDIX D

12.4 Laboratory Bench Test and Jar Test Data
American NuKEM Wastewater Treatment Laboratory, Rock Hill,
SC

28 Springdale Road
Cherry Hill, New Jersey 08003
(609) 751-1122 • (215) 923-2068
Fax: (609) 751-0824

Chain-of-Custody

454 South Anderson Road BTC 532
Rock Hill, South Carolina 29730
(803) 329-9690
Fax: (803) 329-9689

Client RICH SCHLAUCH

Project: SALT KI//

NORLITE
~~AnalytiKEM Contract~~ R. H. FRANKLIN

SAMPLE DESIGNATION	DATE	MATRIX	40 ml vials	950 ml	ml	ml	ml	ml	ml	ml	ml	1 GAL UNPES	PARAMETERS
			Org. Pres.	Unpres.	Unpres.	HNO ₃	H ₂ SO ₄	H ₂ SO ₄	NaOH				
C	11/13/92	WATER										X	
B1	11/13/92	↓										X	Sent to AnalytiKEM Cherry Hill after receipt.
E	11/13/92											X	
F	11/13/92											X	
<p>Note: Due to missing sample of B.1 in package sent from Norlite to AnalytiKEM Cherry Hill N.J. I am Federal Expressing most of the above 1-gallon of B.1 to AnalytiKEM for general chemistry and metals analysis indicated on attached table</p>													

- I. Field Measurements:
Data Sheets: Y N
Filtered: Y Not Required
- II. Field Conditions/Comments: RICH THESE ARE THE SAMPLES YOU REQUESTED. Richard Schlauach 11/13/92
- III. Special Instructions:
(Detection Limits, Data Package, etc.)

Relinquished By:	Time/Date:	Received By:	Time/Date:
<u>[Signature]</u>	<u>5:30 11/13/92</u>	<u>Richard Schlauach</u>	<u>Nov. 17, 1992 / 1:30 PM</u>
<u>B.1 only R. Schlauach</u>	<u>9:00 AM 11/19/92</u>		

[Signature]
Sign

PROJECT Study of Precipitate Observed in Salt Kill Creek

Continued From Page _____

Scrubber Blowdown (outfall 005) and Salt Kill Water + bottom sediments study. Samples collected 11/9-13/92 by Nott's Staff (i.e. Dick Franklin & Frank Kovacs).

Sample Measurements and Analysis upon receipt at Thermal/TEH WWT Plat, Rock Hill SC (Supernatants) Nov. 17 1992 2:00 PM

Sample	ICP Calc ppm as CaCO ₃	pH	Temp	Conductivity
B.1	175 ppm	8.46 8.50	10.5 °C	750 μS/cm
C.		8.82	10.5 °C	2870 μS/cm
E.		8.30	10.5 °C	675 μS/cm
F.		8.88	11.0 °C	3,590 μS/cm

Liquid-Solids Separations Nov. 18, 1992

Coarse Solids (+100 mesh or > 0.15 mm dia.)

Sample	Settled Solids Vol	Supernatant Liquid Volume	Wet solids wt.	Dry solids wt.
C.1	0.35 ml/g	3650 ml	Al dish = 153.266g Dish + solids = none (Diff) Solids = observed	104 °C none observed
E.1	< 0.1 ml/g	3600 ml	Al Dish = 152.277g Dish + solids = 153.128g (Diff) Solids = 0.841g	Trace 152.277g
F.1	9.50 ml/g	3200 ml	Al dish = 151.999g Dish + solids = 467.583g (Diff) Solids =	345.426g

Continued on Page _____

Read and Understood By

Richard Shlemons Nov. 19, 1992
Signed Date

Pete J. Turner
Signed

Nov. 23, 1992
Date

Liquid-Solid Separations (Continued)

Whatman G-F/A 125cm paper

Fine Solids (-100 mesh + 1.6 micron or 0.0016 to 0.05mm)
104°C

Sample	Vol of Settled Solids Filtered	Vol of Filtrate	Wet Cake WT	Dry Cake WT
C.2		0.674	0.096g wt filter = 0.015g wt pan = 1.439g total solid + pan + filter = 2.129g (Diff) Solids = 0.594	1.553g - 1.535g = 0.018g 1.54294g - 1.53944g = 0.350g <u>total dry wt = 0.368g</u>

E.2	+0.354g	0.096g	wt filter = 0.015g wt pan = 1.444g total solid + pan + filter = 3.025g (Diff) Solids =	2.000g - 0.450g (2 filter) 1.55g - 1.444g <u>total dry wt = 0.106g</u>
-----	---------	--------	--	--

F.2			wt filter = 0.685g } wt pan = 152.855g } total solvent pan + filter = 153.540g 152.614g (Diff) Solids =	350.185g 196.625g - 196.625g
-----	--	--	--	---

Continued on Page

Read and Understood By

Richard Schaub

Signed

Nov. 19, 1992

Date

Pete Carter

Signed

Nov. 23, 1992

Date

Sample. Calculations of Total Suspended Solids

C. Initial Volume of Sample = 3.65 liters

Total dry wt. of precipitated solids = 0.368 g

$$\frac{0.368 \text{ g}}{3.65 \text{ liter}} = \frac{0.1008 \text{ g}}{\text{liter}} \times 1000 = \frac{100.8 \text{ mg}}{\text{liter}} \text{ TSS}$$

E. Initial Volume of Sample = 3.6 liters

Total dry wt. of suspended = 0.106 g

$$\frac{0.106}{3.6} = \frac{0.0294 \text{ g}}{\text{liter}} \times 1000 = \frac{29.4 \text{ mg}}{\text{liter}} \text{ TSS}$$

F. Initial Volume of Sample = 3.2 liters

Total dry wt. of suspended solid = 196.625 g

$$\frac{196.625 \text{ g}}{3.2 \text{ L}} = \frac{61.445 \text{ g}}{\text{L}} = 6.1 \% \text{ solids}$$

Continued on Page

Richard Schlack Nov. 20, 1992

Signed

Date

Read and Understood By

Richard Schlack
Richard Schlack

Signed

Nov. 23, 1992

Date

Upstream Sample E. Filtrate 3600 ml + ~500 ml of B-1 Jar Tests										
ICP Test #	Temp	Variable	Na ₂ CO ₃ Solution	pH	After mix and settle	at Equilibrium	TSS			
ICP Test #1	71°F	1	375 ml Na ₂ CO ₃ soln (= 0.25% Na ₂ CO ₃)	8.14	10.21	1.769 g	0.056	1.825 g	0.44	127 mg/l
B 150 ppm	71°F	2	50 ml @ 2.0% (= 1% Na ₂ CO ₃)	8.15	10.76	1.725 g	0.067	1.792 g	0.44	153 mg/l
C 100 ppm	71°F	3	50 ml @ 5.0% (= 2.5% Na ₂ CO ₃)	8.15	10.96	1.791 g	0.070	1.861 g	0.44	159 mg/l
Mix 20 min let settle min. About 5 min mixing before ppt is evident. measure pH Filter for TSS & filtrate metals analyzed										
ICP Test #	Temp	Variable	Na ₂ CO ₃ Solution	pH	After mix and settle	at Equilibrium	TSS			
ICP Test #2	110°F	Cond.	375 ml Na ₂ CO ₃ Soln	8.1	8.14	1.765 g	0.072	1.832 g	0.44	107 ppm
51.5 ppm A		4	50 ml @ 0.5%	8.1	8.96	1.721 g	0.065	1.786 g	0.44	146 ppm
14.0 ppm B		5	50 ml @ 0.5%	8.1	9.88	1.792 g	0.069	1.861 g	0.44	157 ppm
4.1 ppm C		6	50 ml @ 0.5%	8.1						
Note: Precipitation evident after 15 to 30 seconds of mix.										
ICP Test #	Temp	Variable	NaOH Solution	pH	After mix and settle	at Equilibrium	TSS			
ICP Test #3	110°F	Var.	300 ml add 26% NaOH	8.2	8.61	1.721 g	0.03	1.751 g	0.3	100 mg/l
73.5 ppm D		7	300 ml add 26% NaOH	8.2	10.13	1.795 g	0.051	1.846 g	0.3	170 mg/l
5.4 ppm E		8	200 ml Raw filtrate	8.15						
170 ppm F		9	200 ml Raw filtrate	8.15						
Precipitation evident after 30 seconds of mixing										

Continued on Page

Read and Understood By

Richard Schlauder

Nov. 23, 1992

Peter Carter

Nov 23 1992

Signed

Date

Signed

Date

Dec. 4, 1992
Simulated Scrubber ~~to determine~~ Neutralization with Caustic soda (NaOH) vs soda ash (Na₂CO₃).

Scrubber BD/Make-up = 60 GPM = 31,226 lbs/hr.
avg Cl⁻ in LGF = 3.5% of LGF = 338 lbs/hr Cl⁻ in B.D.
 $\frac{338 \text{ lbs}}{31,226 \text{ lbs}} = 0.0108 = 1.1\% \text{ chloride solution.}$

HCl feed solution = 36% NaOH = 24% (approx)
Prepare 10% Na₂CO₃ solution by dissolving 10 grams of Koolite soda ash in 100 grams of ml of H₂O.

Prepare 1.1% HCl solution by diluting 3 ml HCl to 100 ml w/H₂O
∴ Prepare 400 ml of 1.1% HCl by diluting 12 ml HCl to 100 ml w/H₂O.

Titration of 200 ml 1.1% HCl solution pH = 0.36 at 130° to 150°F with 24% NaOH solution

24% NaOH solution			10% Na ₂ CO ₃ solution		
pH	Temp °F	mls titrant	pH	Temp °F	mls titrant
0.35	120°F	0	0.35	120°F	0
1.04	130°F	6.4 mls	0.45	130°F	6.0 mls
2.40	132°F	7.9 mls	0.52	136°F	10.0 mls
3.50	135°F	7.95 mls	0.60	137°F	14.0 mls
10.70	136°F	8.1 mls	0.75	144°F	20.0 mls
			0.89	147°F	24.0 mls
			1.10	148°F	28.0 mls
			1.25	150°F	30.0 mls
			1.53	152°F	32.0 mls
			2.07	151°F	34.0 mls
			5.25	152°F	35.1 mls
			6.21	152°F	36.0 mls
			7.10	151°F	36.8 mls
			7.50	151°F	37.0 mls
			8.10	151°F	37.15 mls
			8.52	151°F	37.50 mls
			8.85	150°F	38.0 mls
			8.99	150°F	38.4 mls
			9.16	150°F	39.0 mls
			9.26	150°F	39.5 mls
			9.76	147°F	46.0 mls
			9.80	147°F	47.0 mls
			9.83	147°F	48.0 mls
			9.89	147°F	50.0 mls
			9.94	147°F	52.0 mls
			9.98	147°F	54.0 mls
			10.01	147°F	56.0 mls
			10.04	147°F	58.0 mls
			10.07	147°F	60.0 mls
			10.12	148°F	66.0 mls
			10.13	150°F	68.0 mls
			10.14	150°F	70.0 mls

Continued on Page

Read and Understood By

Richard Schlanck Dec 4, 1992

Signed

Date

Signed

Date

PROJECT Study of Precipitate Altered in Salt Kill Creek

Continued From Page 21

Titration test for pH adjustment of scrubber solution from neutral to pH 9.5 with Na_2CO_3 vs NaOH at Thermal KEM S.C. WWT Lab

Jan 18, 1992

9:00 AM

Collected sample 500 ml of scrubber solution

500 ml sample = ^{cont} 53.6 ms at 127°F TDS = ~ 4.1%

pH = 10.05

Add 0.9 ml 35% HCl = pH 7.03 at 144°F

(250 mg/ml)

Acidim Carbonate 10% solution (1000 mg/ml)

Acidim Hydroxide 21% solution

mls ppm	pH	Temp °F	mls ppm	pH	Temp °F
0.5 100	7.60	147			
1.0 200	8.06	150			
1.5 300	8.33	150			
2.0 400	8.50	150			
2.5 500	8.63	150			
3.0 600	8.73	150			
3.5 700	8.82	150			
4.0 800	8.88	150			
4.5 900	8.94	148			
5.0 1000	9.00	145			
5.5 1100	9.04	145			
6.0 1200	9.08	144			
6.5 1300	9.12	144			
7.0 1400	9.15	144			
7.5 1500	9.18	144			
8.0 1600	9.21	144			
8.5 1700	9.24	144			
9.0 1800	9.26	144			
9.5 1900	9.28	144			
10 2000	9.30	145			
11 2200	9.35	145			
12 2400	9.38	146			
14 2800	9.42	146			
15 3000	9.44	146			
16 3200	9.47	147			
17 3400	9.50	147			
18 3600	9.52	147			
			0.05 25	7.32	150
			0.10 50	7.55	150
			0.15 75	7.79	150
			0.20 100	7.99	150
			0.25 125	8.15	150
			0.30 150	8.28	150
			0.35 175	8.35	150
			0.45 225	8.53	150
			0.50 250	8.60	150
			0.60 300	8.69	150
			0.70 350	8.79	150
			0.80 400	8.89	150
			0.90 450	8.98	150
			1.0 500	9.06	150
			1.1 550	9.14	150
			1.2 600	9.21	150
			1.3 650	9.28	150
			1.4 700	9.35	150
			1.5 750	9.42	150
			1.6 800	9.49	150
			1.7 850	9.56	150

Titrate scrubber sample from Na_2CO_3 titration w/ 35% HCl from pH 9.52 to 6.95 with 1.8 mls HCl @ 149°F \approx 1440 ppm as HCl
 $\times 1.37 \approx$ 1973 ppm as CaCO_3
 $\times 1.06 \approx$ 2091 ppm as Na_2CO_3

Read and Understood By

Richard Schlaach

Signed

Jan 18, 1993

Date

Signed

Date

Continued on Page 50

PROJECT Study of Precipitation in Salt Kill

Titration of Club Soda (ie saturated CO₂ solution) Jan 26, 1993
 pH at 68°F = 5.55 400 ml

68°F

titrate w 21% NaOH

mls NaOH	ppm	pH	Temp
0	0	5.55	68°F
0.1	65	5.72	
0.2	129	5.84	
0.3	194	5.97	
0.4	258	6.08	
0.5	323	6.19	
0.6	388	6.30	
0.7	452	6.40	
0.8	517	6.53	
0.9	581	6.60	
1.0	646	6.67	

titrate w 21% NaOH at 140°F

mls	ppm	pH	Temp
0	0	6.02	130°F
0.15	97	6.38	136°F
0.30	194	6.80	139°F
0.40	258	7.34	140°F
0.50	323	8.73	146°F
0.60	388	9.01	147°F
0.70	452	9.42	150°F
0.80	517	9.62	150°F

assume soda is saturated w CO₂ at 140°F = 576 ppm CO₂

21% NaOH = 259 g/l = 259 mg/ml

0.4 g

1 ml = 646 ppm

10% NaOH = 100 g/l = 100 mg/ml

0.4 g

1 ml = 250 ppm

titrate w 10% NaOH at 140°F

mls	ppm	pH	Temp
0	0	5.95	130°F
0.1	25	5.98	133°F
0.2	50	6.05	136°F
0.3	75	6.12	138°F
0.4	100	6.16	140°F
0.5	125	6.20	140°F
0.6	150	6.25	142°F
0.7	175	6.30	144°F
0.8	200	6.36	146°F
0.9	225	6.42	147°F
1.0	250	6.47	148°F
1.1	275	6.52	150°F
1.3	325	6.62	150°F
1.5	375	6.71	150°F
1.7	425	6.81	151°F
1.9	475	6.91	151°F
2.1	525	7.00	152°F
2.5	625	7.25	150°F
3.0	750	7.72	150°F
3.5	875	8.39	150°F

mls	ppm	pH	Temp	mls	ppm	pH	Temp
4.0	1000	8.77	149°F				
4.5	1125	8.98	148°F				
5.0	1250	9.10	148°F				
5.5	1375	9.19	147°F				
6.0	1500	9.27	147°F				
6.5	1625	9.34	146°F				
7.0	1750	9.39	146°F				
7.5	1875	9.44	146°F				

Continued on Page

Read and Understood By

Fredrick Schlaubi
Signed

Jan 26, 1993
Date

Signed

Date

Norlite
Salt Kill Test

11/21/92

3410-B

~~3410-B~~ "Bomb" SAF

ICP Metals Analyses

5000 ICP

Begin Analysis - Sample Number ?

File	Wave- Syn. Length	Mean Peak Position	Mean Peak Intensity	% RSD	Net Peak Intensity
S	180.731				
	Off Peak Int. =		714	688	
	Peak Intensity =		3799	3903	
		-0.0001	3851	1.910	3150
SB	187.115				
	Off Peak Int. =		618	586	
	Peak Intensity =		1674	1662	
		0.0000	1668	0.509	1066
Ti	190.864				

Analyze Samples

11-21-1992 @ 12:14:43 -- 4

	Off Peak Int. =		1475	1423	
	Peak Intensity =		4615	4562	
		0.0007	4588	0.786	3140
AS	193.759				
	Off Peak Int. =		1107	1177	
	Peak Intensity =		1124	1143	
		0.0001	5973	5766	
			5672	2.553	4734
HG	194.227				
	Off Peak Int. =		1118	1120	
	Peak Intensity =		1138	1134	
			No Peak!	1136	0.249
					17
SF	196.09				
	Off Peak Int. =		831	822	
	Peak Intensity =		3978	4010	
		0.0006	3994	0.567	3167
SB	206.833				
	Off Peak Int. =		795	816	
	Peak Intensity =		4840	4967	
		-0.0001	4904	1.831	4098
Zn	213.856				
	Off Peak Int. =		466	470	
	Peak Intensity =		292	293	
		0.0001	29937	30304	
			30118	0.873	29737
PR	220.353				
	Off Peak Int. =		1161	1161	
	Peak Intensity =		1183	1200	
		-0.0004	5771	5783	
			5777	0.147	4600
CO	228.88				
	Off Peak Int. =		1037	1022	
	Peak Intensity =		5796	5758	
		-0.0003	56690	2.224	55660
NI	231.604				
	Off Peak Int. =		421	422	
	Peak Intensity =		4504	4583	
		0.0002	4544	1.229	4122
FF	259.94				
	Off Peak Int. =		816	804	
	Peak Intensity =		769	780	
		-0.0001	16837	16354	
			16596	2.058	15803
CR	267.716				
	Off Peak Int. =		885	882	
	Peak Intensity =		13801	13720	
		0.0000	13761	0.416	12877
V	292.402				

Off Peak Int.	3583	3537		
Peak Intensity	45358	44013		
	-0.0002	44686	2.126	41128
Bf 313.042				
Off Peak Int.	488	500		
Peak Intensity	76004	74930		
	0.0005	75469	1.010	24975
Cu 374.754				
Off Peak Int.	895	904		
Peak Intensity	16287	15684		
	0.0003	15986	2.667	15086
Ag 378.068				
Off Peak Int.	753	767		
Peak Intensity	15033	14448		
	-0.0002	14741	2.806	13983
Ca 427.673				
Off Peak Int.	1308	1317		
Peak Intensity	9399	9263		
	0.0003	9331	1.031	8018
Ba 455.403				
Off Peak Int.	586	584		
Peak Intensity	46350	47671		
	0.0007	47011	1.987	46426

5 ppm metals standard
0 ppm Hg

Calculating Concentrations for Sample Number 7

Elem. Wave- Sym. length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
Ag 378.068	13983	5.364		5.364	5.364
As 193.759	4734	5.241		5.241	5.241
Ba 455.403	46426	5.335		5.335	5.335
Bf 313.042	74975	5.405		5.405	5.405
Co 228.86	55660	5.297		5.297	5.297
Cr 267.716	12877	5.266		5.266	5.266
Pb 270.353	4600	5.287		5.287	5.287
Hg 398.777	17	0.012		0.050	0.050
Ni 231.604	4122	5.135		5.135	5.135
Sr 187.115	1066	5.545		5.545	5.545
Sr 206.833	4098	5.848		5.848	5.848
Se 196.09	3167	5.429		5.429	5.429
Ti 190.864	3140	5.125		5.125	5.125
S 180.731	3150	3.678		3.678	3.678
V 292.402	4112	5.202		5.202	5.202
Cu 374.754	15086	5.256		5.256	5.256
Zn 213.856	29737	5.280		5.280	5.280
Pb 259.94	15403	5.111		5.111	5.111
Ca 427.673	8018	5.225		5.225	5.225

	Peak Intensity =	339	882	
	No Peak!	861	3.531	156
SR	187.115			
	Off Peak Int. =	611	624	
	Peak Intensity =	708	703	
	No Peak!	706	0.501	88
TI	190.864			
	Off Peak Int. =	1434	1445	
	Peak Intensity =	1425	1419	
	No Peak!	1422	0.296	-18
AS	191.759			
	Off Peak Int. =	1079	1095	
	Off Peak Int. =	1079	1096	
	Peak Intensity =	1121	1089	
	No Peak!	1105	2.048	17
MG	194.227			
	Off Peak Int. =	1110	1158	
	Peak Intensity =	3159	8120	
	-0.0002	8140	0.339	7006
SF	196.09			
	Off Peak Int. =	825	790	
	Peak Intensity =	811	818	
	No Peak!	815	0.607	7
SR	206.833			
	Off Peak Int. =	796	812	
	Peak Intensity =	897	890	
	No Peak!	892	0.238	88
ZN	213.856			
	Off Peak Int. =	269	268	
	Off Peak Int. =	270	267	
	Peak Intensity =	381	360	
	0.0001	381	0.186	112
PR	220.353			

Analyze Samples

11-21-1992 @ 12:25:15 -- 7

	Off Peak Int. =	1152	1161	
	Off Peak Int. =	1186	1176	
	Peak Intensity =	1162	1157	
	No Peak!	1159	0.244	-10
CD	228.88			
	Off Peak Int. =	916	925	
	Peak Intensity =	950	942	
	No Peak!	946	0.598	25
NI	231.604			
	Off Peak Int. =	408	407	
	Peak Intensity =	411	410	
	No Peak!	411	0.172	3
FE	259.94			
	Off Peak Int. =	754	753	
	Off Peak Int. =	756	768	
	Peak Intensity =	810	808	
	No Peak!	809	0.175	51
CR	267.716			
	Off Peak Int. =	869	875	
	Peak Intensity =	866	865	
	No Peak!	866	0.087	-6
V	292.402			
	Off Peak Int. =	3350	3321	
	Peak Intensity =	3335	3358	
	No Peak!	3347	0.486	11
RF	313.042			
	Off Peak Int. =	315	319	
	Peak Intensity =	351	350	
	No Peak!	351	0.201	34
CU	324.754			
	Off Peak Int. =	873	897	
	Peak Intensity =	898	892	
	No Peak!	895	0.474	10
AG	328.068			
	Off Peak Int. =	712	708	
	Peak Intensity =	715	713	
	No Peak!	714	0.198	4
CA	422.673			
	Off Peak Int. =	1282	1291	
	Peak Intensity =	1305	1294	
	No Peak!	1300	0.598	13
BA	455.403			
	Off Peak Int. =	478	478	
	Peak Intensity =	493	488	
	No Peak!	491	0.720	13

Calculating Concentrations for Sample Number 3

File Wave- Sym. length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
AG 328.068	4	-0.001	<	0.010 <	0.010
AS 193.759	17	-0.009	<	0.125 <	0.125
SA 455.403	13	0.301	<	0.002 <	0.002
RF 313.042	34	0.001	<	0.001 <	0.001
CO 778.88	25	0.102	<	0.002 <	0.002
CR 267.716	-6	-0.006	<	0.015 <	0.015
PR 270.353	-10	-0.014	<	0.100 <	0.100
HG 194.227	7006	3.637	<	3.637 <	3.637
MT 731.604	3	0.001	<	0.020 <	0.020
SR 187.115	88	0.199	<	0.199 <	0.199
SA 206.833	88	0.075	<	0.075 <	0.075
SF 196.09	7	0.031	<	0.250 <	0.250
TI 190.864	-18	-0.074	<	0.250 <	0.250
S 180.731	156	0.068	<	0.068 <	0.068
V 292.402	11	0.007	<	0.025 <	0.025
CU 324.754	10	-0.003	<	0.010 <	0.010
Zn 213.856	112	0.015	<	0.015 <	0.015
FF 759.94	51	0.014	<	0.014 <	0.014
CA 477.078	13	0.307	<	0.250 <	0.250

0 ppm metals std.
3 ppm Hg std.

Enter Sample Weight 9.7

Enter Sample Volume 10

SAMPLE B.1

SAMPLE B.1

Begin Analysis - Sample Number 4

File Wave- Sym. length	Mean Peak Position	Mean Peak Intensity	% RSD	Net Peak Intensity
S 180.731				
Off Peak Int. =		736.0	758	
Peak Intensity =		12680.0	12721	
	-0.0001	12701	0.228	11954
SR 187.115				
Off Peak Int. =		607.0	600	
Peak Intensity =		665.0	677	
	No Peak!	671	1.265	67
TI 190.864				

Off Peak Int. =	1491.0	1541	
Peak Intensity =	1473.0	1463	
	No Peak!	1468	0.482 / -48
AS 193.759			
Off Peak Int. =	1330.0	1296	
Off Peak Int. =	1274.0	1262	
Peak Intensity =	1276.0	1278	
	No Peak!	1277	0.111 / -14
HG 194.227			
Off Peak Int. =	1189.0	1220	
Peak Intensity =	1246.0	1230	
	No Peak!	1238	0.914 / 33
SF 196.09			
Off Peak Int. =	814.0	809	
Peak Intensity =	837.0	843	
	No Peak!	840	0.505 / 28
SR 206.833			
Off Peak Int. =	787.0	813	
Peak Intensity =	817.0	819	
	No Peak!	818	0.173 / 18
Zn 213.856			
Off Peak Int. =	267.0	273	
Off Peak Int. =	276.0	279	
Peak Intensity =	363.0	360	
	0.0002	362	0.586 / 88
PR 270.353			
Off Peak Int. =	1162.0	1166	
Off Peak Int. =	1166.0	1173	
Peak Intensity =	1180.0	1175	
	No Peak!	1172	0.300 / 1*

Off Peak Int. = 747 0 754
 Off Peak Int. = 767 0 761
 Peak Intensity = 1549 0 1517
 0.0001 1531 1.709 774
 CR 267.716
 Off Peak Int. = 866 0 864
 Peak Intensity = 867 0 877
 No Peak! 867 0.816 ?
 V 292.402

Analyze Samples

11-21-1992 @ 12:35:58 -- 10

Off Peak Int. = 3315 0 3309
 Peak Intensity = 3354 0 3341
 No Peak! 3348 0.275 36
 RF 313.042
 Off Peak Int. = 323 0 327
 Peak Intensity = 342 0 343
 No Peak! 343 0.706 18
 CU 374.754
 Off Peak Int. = 876 0 876
 Peak Intensity = 900 0 896
 No Peak! 898 0.315 27
 AG 378.068
 Off Peak Int. = 717 0 716
 Peak Intensity = 710 0 717
 No Peak! 711 0.199 -6
 CA 472.673
 Off Peak Int. = 1552 0 1557
 Peak Intensity = 104107 0 107258
 0.0005 105683 7.108 104128
 RA 455.403
 Off Peak Int. = 482 0 477
 Peak Intensity = 1219 0 1207
 0.0007 1213 0.700 733

SAMPLE B.1
upstream.

Calculating Concentrations for Sample Number 4

Elem. Wave- Sym. length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
AG 378.068	-6	-0.005	<	0.010 <	0.010
AS 193.759	-14	-0.043	<	0.125 <	0.125
RA 455.403	733	0.084	<	0.084	0.087
RC 313.042	18	0.000	<	0.001 <	0.001
CD 228.88	14	0.001	<	0.001	0.001
CR 267.716	?	-0.007	<	0.015 <	0.015
PB 270.353	11	0.010	<	0.100 <	0.100
HG 194.227	33	0.021	<	0.050 <	0.050
NI 231.604	0	-0.007	<	0.020 <	0.020
SR 187.115	67	0.084	<	0.084	0.087
SB 206.833	18	-0.026	<	0.000 <	0.000
SF 196.094	28	0.067	<	0.250 <	0.250
TI 190.864	48	-0.173	<	0.250 <	0.250
S 180.731	11954	14.294	<	14.294	14.736
V 292.402	36	0.010	<	0.025 <	0.025
CU 374.754	72	0.001	<	0.010 <	0.010
7M 213.856	88	0.011	<	0.011	0.011
FF 259.94	274	0.248	<	0.248	0.256
CA 472.673	104128	67.885	<	67.885	69.985

= 70 ppm Ca^M x 2.5 = 175 mg/l CaCO₃

Analyze Samples

11-21-1992 @ 12:30:23 -- 11

SAMPLE #1

SAMPLE #1

Begin Analysis - Sample Number 5

Analyze Samples

11-21-1992 @ 12:38:23 -- 11

SAMPLE #1

SAMPLE #1

Begin Analysis - Sample Number 5

File	Wave- Sym. length	Mean Peak Position	Mean Peak Intensity	% RSD	Net Peak Intensity
S	180.731				
	Off Peak Int. =		770	0.771	
	Peak Intensity =	0.0001	11625	11788	
			11707	0.985	10936
SB	187.115				
	Off Peak Int. =		637	652	
	Peak Intensity =		700	698	
	No Peak!		699	0.202	54
TI	190.864				
	Off Peak Int. =		1649	1673	
	Peak Intensity =		1538	1525	
	No Peak!		1532	0.600	-129
AS	193.759				
	Off Peak Int. =		1530	1559	
	Off Peak Int. =		1501	1488	
	Peak Intensity =		1539	1535	
	No Peak!		1537	0.184	17
HG	194.277				
	Off Peak Int. =		1290	1339	
	Peak Intensity =		1334	1340	
	No Peak!		1337	0.317	27
SF	196.09				
	Off Peak Int. =		865	851	
	Peak Intensity =		885	883	
	No Peak!		884	0.160	26
SA	206.833				
	Off Peak Int. =		820	800	
	Peak Intensity =		835	844	
	No Peak!		840	0.758	30
ZW	213.856				
	Off Peak Int. =		271	281	
	Off Peak Int. =		276	279	
	Peak Intensity =		301	302	
	No Peak!		302	0.234	25
PB	220.353				

Analyze Samples

11-21-1992 @ 12:41:59 -- 12

	Off Peak Int. =		1197	1174	
	Off Peak Int. =		1189	1202	
	Peak Intensity =		1193	1175	
	No Peak!		1184	1.075	-7
CO	228.88				
	Off Peak Int. =		933	955	
	Peak Intensity =		948	950	
	No Peak!		949	0.149	5
NI	231.604				
	Off Peak Int. =		415	418	
	Peak Intensity =		416	420	
	No Peak!		418	0.677	1
FE	259.94				
	Off Peak Int. =		763	763	
	Off Peak Int. =		754	759	
	Peak Intensity =		960	958	
	No Peak!		959	0.147	199
CR	267.716				
	Off Peak Int. =		863	876	
	Peak Intensity =		877	876	
	No Peak!		877	0.081	5
Y	292.402				
	Off Peak Int. =		337	320	

Wave Length	Off Peak Int.	Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
CD 228.88	1197	1184	1.075	-7		
Off Peak Int.	933	948	0.149	5		
Peak Intensity	415	416	0.677	1		
NI 231.604	763	754	0.147	199		
Off Peak Int.	754	960	0.147	199		
Peak Intensity	960	959	0.147	199		
FE 259.94	0.0001	959	0.147	199		
CR 267.716	868	877	0.081	5		
Off Peak Int.	877	876	0.081	5		
Peak Intensity	876	877	0.081	5		
V 292.402	3337	3336	0.696	-6		
Off Peak Int.	3336	3353	0.696	-6		
Peak Intensity	3353	3353	0.696	-6		
BF 313.042	326	343	0.411	20		
Off Peak Int.	343	344	0.411	20		
Peak Intensity	344	344	0.411	20		
CU 324.754	870	911	0.389	34		
Off Peak Int.	911	909	0.389	34		
Peak Intensity	909	909	0.389	34		
AG 328.068	719	707	0.598	-4		
Off Peak Int.	707	710	0.598	-4		
Peak Intensity	710	710	0.598	-4		
CA 422.673	1297	13294	1.370	12120		
Off Peak Int.	13294	13424	1.370	12120		
Peak Intensity	13424	13424	1.370	12120		
RA 455.403	469	811	0.350	336		
Off Peak Int.	811	809	0.350	336		
Peak Intensity	809	809	0.350	336		

ating Concentrations for Sample Number 5

SAMPLE #1 Jay Test
 + 5.88 g/l Na2CO3
 PH = 10.21 Temp = 71°F

Wave Length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
3.068	-4	-0.004	<	0.010	0.010
3.759	17	-0.009	<	0.125	0.125
5.401	336	0.038	<	0.038	0.039
7.042	20	0.000	<	0.001	0.001
7.88	5	0.000	<	0.000	0.000
7.716	5	-0.001	<	0.015	0.015
1.353	7	-0.010	<	0.100	0.100
1.277	22	0.015	<	0.050	0.050
1.604	1	-0.001	<	0.020	0.020
1.115	54	0.013	<	0.013	0.013
1.833	30	0.008	<	0.000	0.000
1.092	26	0.063	<	0.750	0.750
1.864	129	-0.257	<	0.750	0.750
1.731	10936	13.066	<	13.066	13.470
1.402	6	0.005	<	0.025	0.025
1.754	34	0.005	<	0.010	0.010
1.256	75	0.000	<	0.005	0.005
1.94	199	0.061	<	0.061	0.063
1.673	12120	7.900	<	7.900	8.144

x 2.5 = 20.36 ppm as CaCO3

Analysis - Sample Number 6

SAMPLE #2

Begin Analysis - Sample Number 6

File Symb.	Wave-length	Mean Peak Position	Mean Peak Intensity	& RSD	Net Peak Intensity
S	180.731				
	Off Peak Int.	=	840	815	
	Peak Intensity	=	10616	10336	
		0.0001	10476	1.890	9648
SB	187.115				
	Off Peak Int.	=	236	692	
	Peak Intensity	=	749	751	
	No Peak!		750	0.189	36
TL	190.864				
	Off Peak Int.	=	2196	2229	
	Peak Intensity	=	1796	1817	
	No Peak!		1807	0.822	-406
AS	193.759				

Analyze Samples

11-21-1997 @ 12:47:48 -- 14

	Off Peak Int.	=	2711	2694	
	Off Peak Int.	=	2489	2471	
	Peak Intensity	=	2617	2617	
	No Peak!		2617	0.000	75
HC	194.227				
	Off Peak Int.	=	1872	1878	
	Peak Intensity	=	1800	1837	
	No Peak!		1819	1.438	-31
SF	196.09				
	Off Peak Int.	=	969	942	
	Peak Intensity	=	1035	1028	
	No Peak!		1032	0.480	76
SB	206.833				
	Off Peak Int.	=	858	879	
	Peak Intensity	=	902	889	
	No Peak!		896	1.026	27
ZW	213.856				
	Off Peak Int.	=	294	294	
	Off Peak Int.	=	302	300	
	Peak Intensity	=	314	318	
	No Peak!		316	0.895	18
PB	220.353				
	Off Peak Int.	=	1255	1247	
	Off Peak Int.	=	1267	1280	
	Peak Intensity	=	1270	1259	
	No Peak!		1265	0.615	2
CD	228.88				
	Off Peak Int.	=	994	994	
	Peak Intensity	=	1013	1012	
	No Peak!		1013	0.070	19
WT	231.604				
	Off Peak Int.	=	437	438	
	Peak Intensity	=	435	440	
	No Peak!		438	0.807	0
EE	259.94				
	Off Peak Int.	=	811	796	
	Off Peak Int.	=	802	797	
	Peak Intensity	=	912	910	
	No Peak!		911	0.155	109
CP	267.716				
	Off Peak Int.	=	918	913	
	Peak Intensity	=	916	909	
	No Peak!		913	0.542	3
V	292.402				
	Off Peak Int.	=	3487	3419	
	Peak Intensity	=	3452	3487	
	No Peak!		3467	0.612	14
BE	313.042				

Analyze Samples

11-21-1997 @ 12:52:00 -- 15

SAMPLE #2

Regin Analysis - Sample Number 6

File Symb.	Wave-length	Mean Peak Position	Mean Peak Intensity	% RSD	Net Peak Intensity
S	180.731				
	Off Peak Int.	=	840	0	815
	Peak Intensity	=	10616	0	10336
		0.0001	10476	1.890	9648
SB	187.115				
	Off Peak Int.	=	736	0	692
	Peak Intensity	=	749	0	751
	No Peak!		750	0.189	36
TL	190.864				
	Off Peak Int.	=	2196	0	2229
	Peak Intensity	=	1796	0	1817
	No Peak!		1807	0.822	-406
AS	193.759				

Analyze Samples

11-21-1992 @ 12:47:48 -- 14

	Off Peak Int.	=	2711	0	2694
	Off Peak Int.	=	2489	0	2471
	Peak Intensity	=	2617	0	2617
	No Peak!		2617	0.000	25
HG	194.277				
	Off Peak Int.	=	1872	0	1828
	Peak Intensity	=	1800	0	1837
	No Peak!		1819	1.438	-31
SF	196.09				
	Off Peak Int.	=	969	0	942
	Peak Intensity	=	1035	0	1028
	No Peak!		1037	0.480	76
SR	206.833				
	Off Peak Int.	=	858	0	879
	Peak Intensity	=	902	0	889
	No Peak!		896	1.026	27
ZM	213.856				
	Off Peak Int.	=	294	0	294
	Off Peak Int.	=	302	0	300
	Peak Intensity	=	314	0	318
	No Peak!		316	0.895	18
PR	220.353				
	Off Peak Int.	=	1255	0	1247
	Off Peak Int.	=	1267	0	1280
	Peak Intensity	=	1270	0	1259
	No Peak!		1265	0.615	2
CO	228.88				
	Off Peak Int.	=	994	0	994
	Peak Intensity	=	1013	0	1012
	No Peak!		1013	0.070	19
WT	231.604				
	Off Peak Int.	=	437	0	438
	Peak Intensity	=	435	0	440
	No Peak!		438	0.807	0
FE	259.94				
	Off Peak Int.	=	311	0	296
	Off Peak Int.	=	302	0	297
	Peak Intensity	=	912	0	910
	No Peak!		911	0.155	109
CR	267.716				
	Off Peak Int.	=	916	0	913
	Peak Intensity	=	916	0	909
	No Peak!		913	0.542	-3
Y	292.402				
	Off Peak Int.	=	3487	0	3419
	Peak Intensity	=	3452	0	3482
	No Peak!		3467	0.612	14
BF	313.042				

Analyze Samples

11-21-1992 @ 12:52:09 -- 15

Off Peak Int. = 316 # 313
 Peak Intensity = 916 # 909
 No Peak! 913 0.542 -3
 7 292.402
 Off Peak Int. = 3427 # 3419
 Peak Intensity = 3452 # 3422
 No Peak! 3427 0.612 14
 9F 313.042

Analyze Samples

11-21-1992 @ 12:52:09 -- 15

Off Peak Int. = 332 # 336
 Peak Intensity = 353 # 354
 No Peak! 354 0.700 70
 CU 324.754
 Off Peak Int. = 914 # 903
 Peak Intensity = 951 # 951
 No Peak! 951 0.000 42
 AG 328.068
 Off Peak Int. = 741 # 741
 Peak Intensity = 735 # 733
 No Peak! 734 0.193 -7
 CA 427.673
 Off Peak Int. = 1337 # 1332
 Peak Intensity = 10381 # 10275
 0.0004 10328 0.726 8993
 BA 455.403
 Off Peak Int. = 489 # 492
 Peak Intensity = 759 # 761
 0.0008 761 0.372 270

SAMPLE #2 Jar Test

Calculating Concentrations for Sample Number 6

File, Wave- Sym. length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
AG 328.068	-7	-0.005	<	0.010 <	0.010
AS 193.759	25	0.000	<	0.125 <	0.125
BA 455.403	270	0.031	<	0.031	0.032
BF 313.042	70	0.300	<	0.001 <	0.001
CD 228.82	19	0.002	<	0.002	0.002
CR 267.716	-3	-0.005	<	0.015 <	0.015
PR 220.353	7	0.000	<	0.100 <	0.100
HG 194.227	-31	-0.012	<	0.050 <	0.050
MT 231.604	0	-0.002	<	0.020 <	0.020
SB 187.115	36	-0.086	<	0.000 <	0.000
SB 206.833	27	-0.013	<	0.000 <	0.000
SF 196.09	76	0.149	<	0.250 <	0.250
TL 190.864	-406	-0.713	<	0.250 <	0.250
S 180.731	3648	11.513	<	11.513	11.869
V 292.402	14	0.007	<	0.025 <	0.025
CU 324.754	42	0.008	<	0.010 <	0.010
7M 213.856	18	-0.001	<	0.005 <	0.005
FF 259.94	109	0.032	<	0.032	0.033
CA 427.673	8993	5.861	<	5.861	6.042
SAMPLE #3					

x 2.5 = 15.1 ppm as CaCO3

Analyze Samples

11-21-1992 @ 12:54:25 -- 16

SAMPLE #3

Begin Analysis - Sample Number 7

File, Wave- Sym. length	Mean Peak Position	Mean Peak Intensity	% RSD	Net Peak Intensity
----------------------------	-----------------------	------------------------	-------	-----------------------

S 180.731

Off Peak

300 #

300

Analyze Samples

11-21-1992 @ 17:58:30 -- 17

Element	Wave- Sym.	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
AG	378.068	?	-0.002	<	0.010	0.010
AS	193.759	??	0.002	<	0.125	0.125

Element	Wave- Sym.	Off Peak Int.	Peak Intensity	No Peak!	Off Peak Int.	Peak Intensity	No Peak!	Off Peak Int.	Peak Intensity	No Peak!	Off Peak Int.	Peak Intensity	No Peak!	Off Peak Int.	Peak Intensity	No Peak!	Off Peak Int.	Peak Intensity	No Peak!	
NJ	231.604		1072	1083		1087	1088		0.30	10										
FE	259.94		850	845		843	859													
CR	267.716		985	972		976	983													
V	292.402		3642	3648		3649	3649		0.000	4										
BE	313.042		348	357		371	372													
CU	324.754		966	955		1003	1009													
AG	378.068		768	784		778	777													
CA	422.673		1413	1421		11103	11211													
BA	455.403		512	511		913	919													

Calculating Concentrations for Sample Number 7

Elem. Wave- Sym.	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
AG 378.068	?	-0.002	<	0.010	0.010
AS 193.759	??	0.002	<	0.125	0.125

SAMPLE #3 JAN TEST

Analyze Samples

11-21-1992 @ 13:07:24 -- 18

Element	Wave- Sym.	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
BA	455.403	404	0.046		0.046	0.047
BF	313.042	19	0.000	<	0.001	0.001
CD	278.88	10	0.001	<	0.001	0.001
CR	267.716	1	-0.003	<	0.015	0.015
PR	270.353	-1	-0.003	<	0.100	0.100
HC	194.277	52	-0.023	<	0.050	0.050
NI	231.604	-7	-0.011	<	0.020	0.020
SB	182.115	62	0.056		0.056	0.058
SB	206.833	65	0.042		0.042	0.043
SF	196.09	264	0.470		0.470	0.485
TL	190.864	651	-1.116	<	0.250	0.250
S	180.731	11021	13.169		13.169	13.576
V	292.402	4	0.006	<	0.025	0.025
CU	324.754	45	0.009	<	0.010	0.010
NI	213.856	21	-0.001	<	0.005	0.005
FE	259.94	100	0.029		0.029	0.030
CA	422.673	9740	6.348		6.348	6.544

X2.5 = 16.25 ppm as CaCO3

SAMPLE #4

Begin Analysis - Sample Number: 8

SAMPLE #4

Begin Analysis - Sample Number: 2

File Name	Mean Peak Position	Mean Peak Intensity	% RSD	Net Peak Intensity
S 180.731				
Off Peak Int.		765	786	
Peak Intensity	0.0007	10726	10634	
		10680	0.609	9904
SB 187.115				
Off Peak Int.		671	641	
Peak Intensity		691	684	
	No Peak!	688	0.719	57
TI 190.464				
Off Peak Int.		1644	1642	
Peak Intensity		1518	1517	
	No Peak!	1518	0.047	-175
AS 193.759				
Off Peak Int.		1528	1558	
Off Peak Int.		1486	1496	
Peak Intensity		1510	1498	
	No Peak!	1504	0.564	-13
HG 194.277				

Analyze Samples

11-21-1992 @ 13:04:49 -- 19

	Off Peak Int.	1335	1275	
	Peak Intensity	1301	1324	
		1313	1.239	8
SE 196.09				
Off Peak Int.		850	862	
Peak Intensity		879	861	
	No Peak!	870	1.463	14
SB 206.833				
Off Peak Int.		804	793	
Peak Intensity		825	822	
	No Peak!	824	0.257	25
ZW 213.856				
Off Peak Int.		268	269	
Off Peak Int.		278	284	
Peak Intensity		300	302	
	No Peak!	301	0.470	26
PB 220.353				
Off Peak Int.		1157	1190	
Off Peak Int.		1149	1158	
Peak Intensity		1161	1166	
	No Peak!	1164	0.304	0
CQ 228.88				
Off Peak Int.		937	901	
Peak Intensity		923	928	
	No Peak!	926	0.382	9
BT 231.604				
Off Peak Int.		399	399	
Peak Intensity		405	403	
	No Peak!	404	0.350	5
EE 259.94				
Off Peak Int.		737	731	
Off Peak Int.		737	732	
Peak Intensity		1068	1049	
	0.0003	1059	1.269	374
CF 267.216				
Off Peak Int.		819	829	
Peak Intensity		841	842	
	No Peak!	842	0.084	8
Y 292.402				
Off Peak Int.		3265	3268	
Peak Intensity		3232	3270	
	No Peak!	3226	0.263	-40
BE 313.042				
Off Peak Int.		315	313	
Peak Intensity		331	332	
	No Peak!	332	0.213	18
CU 324.754				
Off Peak Int.		854	861	

Peak Intensity =	805	0	277	
Off Peak Int. =	879	0	941	21
Peak Intensity =	593	0	693	
Off Peak Int. =	693	0	100	3
Peak Intensity =	31604	0	32297	
Off Peak Int. =	31951	0	1534	30625
Peak Intensity =	407	0	407	
Off Peak Int. =	991	0	929	
Peak Intensity =	991	0	285	528

Sample #4 Jar Test

Calculating Concentrations for Sample Number 8

Elem. Wave-Sym.	Wave-length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Distortion Correction
AC	328.066	?	-0.002	<	0.010	<
AC	193.759	-13	-1.147	<	1.125	<
BA	455.403	528	0.060	<	0.060	<
BF	313.342	18	1.300	<	0.001	<
CG	228.88	8	0.001	<	0.001	<
CR	267.716	8	0.000	<	0.015	<
PB	220.353	0	-0.002	<	0.100	<
HG	194.227	8	0.008	<	0.050	<
NT	231.604	5	0.004	<	0.020	<
SR	187.115	57	0.029	<	0.029	<
SR	206.833	25	-0.016	<	0.000	<
SF	196.09	14	1.043	<	0.250	<
TI	190.864	-125	-0.250	<	0.250	<
S	180.731	9904	11.822	<	11.822	<
V	292.402	-40	0.001	<	0.025	<
CU	324.754	21	0.100	<	0.010	<
Zn	213.856	26	0.000	<	0.005	<
CF	259.94	124	1.102	<	0.102	<
CA	422.673	30625	19.964	<	19.964	<
SAMPLIF #5						

x 2.5 = 51.45 ppm CaCO3

SAMPLIF #5

Begin Analysis - Sample Number 9

Elem. Wave-Sym.	Wave-length	Mean Peak Position	Mean Peak Intensity	% RSD	Net Peak Intensity
S	180.731				
Off Peak Int. =		146	0	176	
Peak Intensity =		11059	0	11473	
		0.0001	11641	2.648	10880
SR	187.115				
Off Peak Int. =		633	0	629	
Peak Intensity =		699	0	690	
		No Peak!	695	0.916	64
TI	190.864				
Off Peak Int. =		1599	0	1585	
Peak Intensity =		1505	0	1487	
		No Peak!	1496	0.851	-96
AS	193.759				
Off Peak Int. =		1375	0	1370	
Off Peak Int. =		1377	0	1365	
Peak Intensity =		1390	0	1384	
		No Peak!	1387	0.306	16
HG	194.227				
Off Peak Int. =		1230	0	1294	
Peak Intensity =		1266	0	1264	
		No Peak!	1265	0.112	3
SF	196.09				
Off Peak Int. =		828	0	836	
Peak Intensity =		867	0	868	
		No Peak!	868	0.001	36
SR	206.833				
Off Peak Int. =		210	0	241	
Peak Intensity =		210	0	210	

File Symb.	Wave-length	Mean Peak Position	Mean Peak Intensity	% RSD	Net Peak Intensity
S	183.731				
	Off Peak Int. =		746	776	
	Peak Intensity =	0.0001	11641	11471	10883
SB	187.115				
	Off Peak Int. =		633	629	
	Peak Intensity =		699	690	64
	No Peak!		695	0.916	
TL	190.864				
	Off Peak Int. =		1599	1585	
	Peak Intensity =		1505	1487	
	No Peak!		1496	0.851	-96
AS	193.759				
	Off Peak Int. =		1375	1370	
	Off Peak Int. =		1377	1365	
	Peak Intensity =		1390	1384	16
	No Peak!		1387	0.306	
HG	194.277				
	Off Peak Int. =		1230	1294	
	Peak Intensity =		1266	1264	
	No Peak!		1265	0.117	3
SF	196.09				
	Off Peak Int. =		828	836	
	Peak Intensity =		867	868	
	No Peak!		868	0.081	36
SB	206.833				
	Off Peak Int. =		816	841	
	Peak Intensity =		874	832	
	No Peak!		878	0.683	-7
7W	213.856				
	Off Peak Int. =		270	273	
	Off Peak Int. =		281	283	
	Peak Intensity =		296	294	
	No Peak!		295	0.479	18
PB	220.353				
	Off Peak Int. =		1147	1174	
	Off Peak Int. =		1190	1201	
	Peak Intensity =		1184	1201	
	No Peak!		1193	1.000	12
CD	228.88				
	Off Peak Int. =		933	938	
	Peak Intensity =		946	954	
	No Peak!		950	0.595	14
WT	231.604				

Analyze Samples

11-21-1992 @ 13:15:23 -- 77

	Off Peak Int. =		417	413	
	Peak Intensity =		420	416	
	No Peak!		418	0.677	3
FF	259.94				
	Off Peak Int. =		776	758	
	Off Peak Int. =		755	766	
	Peak Intensity =	0.0006	957	963	196
	No Peak!		960	0.442	
CR	267.716				
	Off Peak Int. =		877	884	
	Peak Intensity =		878	877	
	No Peak!		878	0.081	-3
V	292.407				
	Off Peak Int. =		3338	3404	
	Peak Intensity =		3393	3375	
	No Peak!		3384	0.376	13
BF	313.042				
	Off Peak Int. =		328	333	
	Peak Intensity =		344	345	
	No Peak!		345	0.205	14
CU	324.754				
	Off Peak Int. =		878	885	
	Peak Intensity =		915	901	
	No Peak!		908	1.090	26
AG	328.068				
	Off Peak Int. =		717	711	
	Peak Intensity =		716	714	
	No Peak!		715	0.198	1
CA	422.673				
	Off Peak Int. =		1297	1311	
	Peak Intensity =	0.0006	10182	9999	
	No Peak!		10091	1.282	8187
BA	455.403				
	Off Peak Int. =		471	475	
	Peak Intensity =	0.0019	825	822	
	No Peak!		824	0.257	351

SAMPLES

Free intensity = 0.0006
 BA 455.403 = 471 475
 Off Peak Int. = 475 475
 Peak Intensity = 825 827
 0.0712 824 0.251 351

SAMPLE #5 Jar Test

Calculating Concentrations for Sample Number 9

Elem	Wave- Sym. length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
AG	378.068	1	-0.002	<	0.010 <	0.010
AS	193.759	16	-0.010	<	0.125 <	0.125
BA	455.403	351	0.040	<	0.040 <	0.041
BF	115.842	14	0.000	<	0.001 <	0.001
CB	278.86	14	0.005	<	0.001 <	0.001
CR	267.716	-3	-0.005	<	0.015 <	0.015

Analyze Samples

11-21-1992 @ 13:18:55 -- 23

PR	220.353	12	0.011	<	0.100 <	0.100
HG	194.227	3	0.005	<	0.050 <	0.050
MT	231.604	3	0.001	<	0.020 <	0.020
SR	187.115	64	0.067	<	0.067 <	0.069
SR	206.833	-2	-0.055	<	0.300 <	0.000
SF	196.09	36	0.060	<	0.250 <	0.250
TI	190.864	-96	-0.202	<	0.250 <	0.250
S	180.731	10860	12.999	<	12.999 <	13.401
Z	292.402	13	0.007	<	0.025 <	0.025
CU	324.754	26	0.002	<	0.010 <	0.010
ZN	213.856	18	-0.001	<	0.005 <	0.005
FE	258.94	196	0.061	<	0.061 <	0.063
CA	422.673	8787	5.727	<	5.727 <	5.904

x 2.5 = 14.75 ppm as CaCO3

SAMPLE #6

Begin Analysis - Sample Number: 10

Elem	Wave- Sym. length	Mean Peak Position	Mean Peak Intensity	% RSD	Net Peak Intensity
S	180.731				
	Off Peak Int. =	750	756		
	Peak Intensity =	11659	12269		
		0.0007	11964	3.605	11196
SR	187.115				
	Off Peak Int. =	663	638		
	Peak Intensity =	685	698		
		No Peak!	692	1.328	41
TI	190.864				
	Off Peak Int. =	1709	1626		
	Peak Intensity =	1521	1523		
		No Peak!	1522	0.093	-146
AS	193.759				
	Off Peak Int. =	1573	1623		
	Off Peak Int. =	1560	1567		
	Peak Intensity =	1561	1545		
		No Peak!	1553	0.779	-28
HG	194.227				
	Off Peak Int. =	1318	1314		
	Peak Intensity =	1350	1363		
		No Peak!	1357	0.677	41
SF	196.09				

Analyze Samples

11-21-1992 @ 13:21:36 -- 24

Off Peak Int. = 876 851
 Peak Intensity = 877 88*

Off Peak Int.	1182	1177		
Peak Intensity	1203	1191		
CD 228.88	No Peak!	1197	0.709	12
Off Peak Int.	955	960		
Peak Intensity	951	956		
NT 231.604	No Peak!	954	0.371	-4
Off Peak Int.	412	412		
Peak Intensity	423	418		
FF 259.94	No Peak!	419	0.338	8
Off Peak Int.	769	765		
Off Peak Int.	771	762		
Peak Intensity	398	930		
CR 267.716	No Peak!	414	2.476	147
Off Peak Int.	883	857		
Peak Intensity	879	875		
V 292.402	No Peak!	877	0.323	2
Off Peak Int.	3200	3200		
Peak Intensity	3400	3199		
RF 313.042	No Peak!	3400	0.021	-1
Off Peak Int.	324	327		
Peak Intensity	343	342		
CU 324.754	No Peak!	343	0.206	17
Off Peak Int.	892	893		
Peak Intensity	915	910		
AG 328.068	No Peak!	913	0.387	20
Off Peak Int.	725	737		

Analyze Samples

11-21-1992 @ 13:25:58 -- 25

Peak Intensity	717	719		
CA 427.673	No Peak!	718	0.197	-13
Off Peak Int.	1291	1307		
Peak Intensity	4139	4237		
RA 455.403	D.0006	4188	1.655	2889
Off Peak Int.	486	480		
Peak Intensity	721	724		
AG 328.068	D.0011	723	0.293	240

Calculating Concentrations for Sample Number 10

Elem. Wave-Sym. length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
AG 328.068	-13	-0.008		< 0.010	< 0.010
AS 193.759	-28	-0.059		< 0.125	< 0.125
BA 455.403	240	0.027		< 0.027	0.028
BF 313.042	17	0.000		< 0.031	0.031
CD 228.88	-4	0.000		< 0.000	0.000
CR 267.716	?	-0.002		< 0.015	0.015
PR 270.353	12	0.011		< 0.100	0.100
AG 194.227	41	0.025		< 0.050	0.050
NT 231.604	8	0.007		< 0.020	0.020
CR 187.115	41	-0.058		< 0.000	0.000
SR 206.833	33	-0.004		< 0.000	0.000
SF 196.09	23	0.058		< 0.250	0.250
TI 190.864	-146	-0.285		< 0.250	0.250
S 180.731	11196	13.380		13.380	13.794
V 292.402	-1	0.005		< 0.025	0.025
CU 324.754	20	0.000		< 0.010	0.010
ZN 213.856	16	-0.002		< 0.005	0.005
FF 259.94	147	0.045		0.045	0.046
CA 427.673	2889	1.882		1.882	1.940

SAMPLE #6 Jar Test

x2.5 = 4.8 ppm CaCO₃

SAMPLE #7

Begin Analysis - Sample Number 11

Elem. Wave-Sym. length	Mean Peak Position	Mean Peak Intensity	% RSD	Net Peak Intensity
------------------------	--------------------	---------------------	-------	--------------------

Analyze Samples

11-21-1997 @ 13:27:52 -- 26

S	180.731	Off Peak Int. =	756	768	
		Peak Intensity =	12392	12566	
			0.0002	12729	1.811
					11967
SR	187.115	Off Peak Int. =	629	612	
		Peak Intensity =	692	677	
		No Peak!	685	1.548	64
TI	190.864	Off Peak Int. =	558	540	
		Peak Intensity =	482	505	
		No Peak!	1494	1.089	-55
AS	193.759	Off Peak Int. =	1312	1251	
		Off Peak Int. =	1231	1269	
		Peak Intensity =	1255	1241	
		No Peak!	1248	0.793	-18
HC	194.227	Off Peak Int. =	1225	1200	
		Peak Intensity =	1204	1203	
		No Peak!	1204	0.059	-9
SE	196.09	Off Peak Int. =	835	839	
		Peak Intensity =	847	860	
		No Peak!	854	1.076	17
SR	206.833	Off Peak Int. =	797	797	
		Peak Intensity =	817	816	
		No Peak!	817	0.087	20
ZN	213.856	Off Peak Int. =	265	270	
		Off Peak Int. =	270	276	
		Peak Intensity =	296	299	
		No Peak!	298	0.712	27
PR	220.353	Off Peak Int. =	1173	1175	
		Off Peak Int. =	1138	1150	
		Peak Intensity =	1166	1161	
		No Peak!	1164	0.304	-5
CD	228.88	Off Peak Int. =	932	936	
		Peak Intensity =	930	938	
		No Peak!	934	0.606	0
NI	231.604	Off Peak Int. =	411	412	
		Peak Intensity =	414	413	
		No Peak!	414	0.171	2
FE	259.94				

Analyze Samples

11-21-1997 @ 13:32:13 -- 27

		Off Peak Int. =	750	760	
		Off Peak Int. =	747	765	
		Peak Intensity =	1002	1008	
			0.0002	1005	0.422
					249
CR	267.716	Off Peak Int. =	864	866	
		Peak Intensity =	864	867	
		No Peak!	866	0.245	1
V	292.402	Off Peak Int. =	3357	3315	
		Peak Intensity =	3364	3359	
		No Peak!	3362	0.105	26
BF	313.042	Off Peak Int. =	322	323	
		Peak Intensity =	341	340	
		No Peak!	341	0.207	18
CU	324.754	Off Peak Int. =	862	889	
		Peak Intensity =	908	916	
		No Peak!	912	0.620	36
AG	328.068	Off Peak Int. =	709	715	
		Peak Intensity =	713	715	
		No Peak!	714	0.198	2

Wave	Off Peak Int.	Peak Intensity	No Peak	267.716
CR	864	866	0.245	1
V	335	335	0.105	26
RF	327	323	0.207	18
CU	867	889	0.670	36
AG	709	715	0.198	2
CA	1415	1403	43761	
RA	480	483	0.567	651

Calculating Concentrations for Sample Number 11

SAMPLE # 7 Jar Test

Elem. Wave	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
AG 328.068	?	-0.002	<	0.010	0.010
AS 193.759	-18	-0.048	<	0.125	0.125
RA 455.403	651	0.074	<	0.074	0.076
RF 313.042	18	0.000	<	0.001	0.001
CU 324.754	0	0.000	<	0.000	0.000
FR 267.716	1	-0.003	<	0.015	0.015
FR 220.353	-5	-0.006	<	0.100	0.100
FR 194.227	-9	-0.001	<	0.050	0.050
WT 231.604	?	0.000	<	0.020	0.020
SR 187.115	64	0.067	<	0.067	0.369

Analyze Samples

11-21-1997 @ 13:35:22 -- 20

SR 206.833	20	-0.023	<	0.000	0.000
SF 196.09	17	0.048	<	0.250	0.250
TL 190.864	-55	-0.135	<	0.250	0.250
S 180.731	11967	14.309	<	14.309	14.752
V 299.402	26	0.009	<	0.025	0.025
CU 324.754	36	0.006	<	0.010	0.010
FM 213.856	27	0.000	<	0.005	0.005
FF 259.94	249	0.078	<	0.078	0.080
CA 427.673	43761	28.528	<	28.528	29.410

x 2.5 = 73.53 ppm CaCl₂

SAMPLE # 8

Begin Analysis - Sample Number 12

Elem. Wave	Mean Peak Position	Mean Peak Intensity	% RSD	Net Peak Intensity
S 180.731		750	755	
	Off Peak Int.	12794	13031	
	Peak Intensity	12913	1.298	12160
SR 187.115		609	637	
	Off Peak Int.	681	686	
	Peak Intensity	684	0.517	61
TL 190.864		1515	1512	
	Off Peak Int.	1484	1478	
	Peak Intensity	1481	0.286	-33
AS 193.759		1209	1207	
	Off Peak Int.	1245	1211	
	Peak Intensity	1236	1244	
	Off Peak Int.	1240	0.456	22
AG 194.227		715	715	
	Off Peak Int.	714	0.198	

S	180.231	Off Peak Int. = 750	755	
		Peak Intensity = 12794	13031	
		No Peak!		12160
SR	187.115	Off Peak Int. = 608	617	
		Peak Intensity = 601	686	
		No Peak!	684	61
TL	190.864	Off Peak Int. = 1515	1512	
		Peak Intensity = 1484	1478	
		No Peak!	1481	-33
AS	193.759	Off Peak Int. = 1209	1207	
		Off Peak Int. = 1245	1211	
		Peak Intensity = 1236	1244	
		No Peak!	1240	22
HG	194.227	Off Peak Int. = 1206	1164	
		Peak Intensity = 1195	1181	
		No Peak!	1188	3
SF	196.09	Off Peak Int. = 361	341	
		Peak Intensity = 346	355	
		No Peak!	351	0
SR	206.833			

Analyze Samples

11-21-1992 @ 13:32:22 -- 29

		Off Peak Int. = 814	828	
		Peak Intensity = 819	821	
		No Peak!	820	-1
TA	213.856	Off Peak Int. = 270	276	
		Off Peak Int. = 283	279	
		Peak Intensity = 291	289	
		No Peak!	290	13
PA	220.353	Off Peak Int. = 1205	1157	
		Off Peak Int. = 1141	1192	
		Peak Intensity = 1182	1209	
		No Peak!	1196	11
CD	228.88	Off Peak Int. = 941	936	
		Peak Intensity = 958	941	
		No Peak!	950	11
WI	231.604	Off Peak Int. = 412	417	
		Peak Intensity = 419	417	
		No Peak!	418	3
FE	259.94	Off Peak Int. = 759	759	
		Off Peak Int. = 769	772	
		Peak Intensity = 795	796	
		No Peak!	796	31
CR	267.716	Off Peak Int. = 864	870	
		Peak Intensity = 869	876	
		No Peak!	873	6
V	292.402	Off Peak Int. = 3373	3315	
		Peak Intensity = 3364	3355	
		No Peak!	3360	16
MF	313.042	Off Peak Int. = 341	341	
		Peak Intensity = 341	341	
		No Peak!	341	18
CU	324.254	Off Peak Int. = 881	888	
		Peak Intensity = 897	902	
		No Peak!	900	15
AG	328.068	Off Peak Int. = 707	717	
		Peak Intensity = 712	708	
		No Peak!	710	-2
CA	422.673	Off Peak Int. = 1286	1302	

Off Peak Int. = 361 884
 Peak Intensity = 897 902
 AC 328.068 No Peak! 900 0.393
 Off Peak Int. = 707 717
 Peak Intensity = 712 708
 CA 427.673 No Peak! 710 0.398
 Off Peak Int. = 1286 1302

Analyze Samples

11-21-1992 @ 13:42:45 -- 30

Peak Intensity = 5117 5070
 0.0005 5094 0.657 3800
 RA 455.403
 Off Peak Int. = 476 476
 Peak Intensity = 689 680
 0.0011 685 0.929 209

Calculating Concentrations for Sample Number 12

SAMPLE # 8 Jar Test

Elem. Wave--	Net Peak	Calculated	Interference	Net	Dilution
Sym. length	Intensity	Concentration	Correction	Concentration	Correction
AG 328.068	-2	-0.003	<	0.010 <	0.010
AS 193.759	22	-0.003	<	0.125 <	0.125
RA 455.403	209	0.074	<	0.074 <	0.075
RF 313.042	18	0.000	<	0.001 <	0.001
CD 228.88	31	0.001	<	0.001 <	0.001
CR 267.716	6	-0.001	<	0.015 <	0.015
PR 270.353	31	0.010	<	0.100 <	0.100
HG 194.277	3	0.005	<	0.050 <	0.050
NT 231.604	3	0.001	<	0.020 <	0.020
SR 187.115	61	0.051	<	0.051 <	0.053
SB 206.833	-1	-0.053	<	0.000 <	0.000
SE 196.09	0	0.019	<	0.250 <	0.250
TL 190.864	-33	-0.099	<	0.250 <	0.250
S 180.731	12160	14.542	<	14.542 <	14.992
V 292.402	16	0.008	<	0.025 <	0.025
CU 324.754	15	-0.002	<	0.010 <	0.010
ZN 213.856	13	-0.002	<	0.005 <	0.005
FF 259.94	31	0.007	<	0.010 <	0.010
CA 427.673	3800	2.475	<	2.475 <	2.552

x 2.5 = 5.4 ppm CaCO3

SAMPLE #9

Begin Analysis - Sample Number 13

Ele. Wave--	Mean Peak	Mean Peak	% RSD	Net Peak
Sym. length	Position	Intensity		Intensity
S 180.731				
Off Peak Int. =	754	793		
Peak Intensity =	12889	12516		
0.0002	12703	7.076		11829

Analyze Samples

11-21-1992 @ 13:44:36 -- 31

SB 187.115
 Off Peak Int. = 641 632
 Peak Intensity = 686 685
 No Peak! 686 0.103 49
 TL 190.864
 Off Peak Int. = 1544 1546
 Peak Intensity = 1477 1480
 No Peak! 1479 0.143 -66
 AS 193.759
 Off Peak Int. = 1350 1331

Analyze Samples

11-21-1992 @ 13:44:36 -- 31

SB 187.115	Off Peak Int. =	641	632	
	Peak Intensity =	686	685	
	No Peak!	686	0.103	49
TL 190.864	Off Peak Int. =	1544	1546	
	Peak Intensity =	1477	1430	
	No Peak!	1479	0.143	-66
AS 193.759	Off Peak Int. =	1339	1331	
	Off Peak Int. =	1328	1334	
	Peak Intensity =	1298	1325	
	No Peak!	1312	1.455	-21
HG 194.227	Off Peak Int. =	1232	1223	
	Peak Intensity =	1231	1237	
	No Peak!	1234	0.344	6
SF 196.09	Off Peak Int. =	828	850	
	Peak Intensity =	864	859	
	No Peak!	862	0.410	23
SB 206.833	Off Peak Int. =	796	817	
	Peak Intensity =	818	824	
	No Peak!	821	0.517	14
ZN 213.856	Off Peak Int. =	270	278	
	Off Peak Int. =	280	272	
	Peak Intensity =	343	345	
	0.0009	344	0.411	69
PB 220.353	Off Peak Int. =	1192	1146	
	Off Peak Int. =	1174	1171	
	Peak Intensity =	1179	1178	
	No Peak!	1179	0.060	8
CD 228.88	Off Peak Int. =	931	939	
	Peak Intensity =	950	947	
	No Peak!	949	0.224	14
NI 231.604	Off Peak Int. =	411	414	
	Peak Intensity =	411	415	
	No Peak!	413	0.685	0
FF 259.94	Off Peak Int. =	754	754	
	Off Peak Int. =	763	775	
	Peak Intensity =	1195	1202	
	0.0005	1199	0.413	437
CR 267.716				

Analyze Samples

11-21-1992 @ 13:48:57 -- 37

	Off Peak Int. =	884	873	
	Peak Intensity =	875	876	
	No Peak!	876	0.081	3
V 282.407	Off Peak Int. =	3396	3380	
	Peak Intensity =	3382	3365	
	No Peak!	3374	0.356	14
BR 313.049	Off Peak Int. =	324	328	
	Peak Intensity =	342	341	
	No Peak!	342	0.207	16
CU 324.754	Off Peak Int. =	877	889	
	Peak Intensity =	928	920	
	No Peak!	924	0.612	41
Ag 378.064	Off Peak Int. =	714	719	
	Peak Intensity =	715	714	
	No Peak!	715	0.099	2
CA 427.673	Off Peak Int. =	1549	1557	
	Peak Intensity =	102892	102034	
	0.0007	102463	0.592	100910
RA 455.403	Off Peak Int. =	477	440	
	Peak Intensity =	563	560	

Off Peak Int. = 931 0 939
 Peak Intensity = 950 0 947
 No Peak! 948 0.224 14
 NT 231.604
 Off Peak Int. = 411 0 414
 Peak Intensity = 411 0 415
 No Peak! 413 0.685 0
 FF 259.94
 Off Peak Int. = 754 0 754
 Off Peak Int. = 761 0 775
 Peak Intensity = 1195 0 1202
 0.0005 1199 0.413 437
 CR 267.716

Analyze Samples

11-21-1992 @ 13:48:57 -- 32

Off Peak Int. = 884 0 873
 Peak Intensity = 875 0 876
 No Peak! 876 0.021
 V 292.402
 Off Peak Int. = 3396 0 3380
 Peak Intensity = 3382 0 3365
 No Peak! 3374 0.356 14
 BF 313.042
 Off Peak Int. = 324 0 328
 Peak Intensity = 342 0 341
 No Peak! 342 0.207 16
 CU 324.754
 Off Peak Int. = 877 0 889
 Peak Intensity = 928 0 920
 No Peak! 924 0.617 41
 AG 328.068
 Off Peak Int. = 714 0 712
 Peak Intensity = 715 0 714
 No Peak! 715 0.099 2
 CA 422.673
 Off Peak Int. = 1549 0 1557
 Peak Intensity = 102892 0 102034
 0.0007 102463 0.592 100910
 BA 455.403
 Off Peak Int. = 477 0 480
 Peak Intensity = 1563 0 1600
 0.0011 1582 1.654 1103

SAMPLE #9 Jor Test

Calculating Concentrations for Sample Number 13

Elem	Wave- Sym. length	Net Peak Intensity	Calculated Concentration	Interference Correction	Net Concentration	Dilution Correction
AG	328.068	2	-0.002	<	0.010 <	0.010
AS	193.759	-21	-0.051	<	0.125 <	0.125
BA	455.403	1103	0.126	<	0.126 <	0.130
BF	313.042	16	0.000	<	0.001 <	0.001
CD	278.88	14	0.001	<	0.001 <	0.001
CR	267.716	-3	-0.005	<	0.015 <	0.015
PB	270.353	8	0.007	<	0.100 <	0.100
HG	194.227	6	0.007	<	0.050 <	0.050
NT	231.604	0	-0.002	<	0.020 <	0.020
SB	187.115	49	-0.015	<	0.000 <	0.000
SB	206.833	14	-0.031	<	0.000 <	0.000
SF	196.09	23	0.058	<	0.250 <	0.250
TI	190.864	66	-0.153	<	0.250 <	0.250
S	180.731	11929	14.264	<	14.264 <	14.705
V	292.402	-34	0.004	<	0.025 <	0.025

Analyze Samples

11-21-1992 @ 13:51:42 -- 33

CU	324.754	41	0.007	<	0.010 <	0.010
W	213.856	69	-0.008	<	0.008 <	0.008
FF	259.94	437	0.139	<	0.139 <	0.143
CA	422.673	100910	65.787	<	65.787 <	67.822
SPPM ICV						

x 2.5 = 169.6 ppm CaCO3