



Burntisland

what3words - brothers.hillsides.miracles

5 midweek dayshifts

Prepared by:

.....Date

.....Date

.....Date

Approved by the Contractor's Engineering Manager (CEM) / Contractor's Responsible Engineer (CRE):

.....Date

.....Date

.....Date

CEM / CRE Discipline (as stated in the CPP)

This Work Package Plan does not require acceptance by Network Rail / Client

OR

Accepted on behalf of Network Rail / Client:

.....Date

.....Date

.....Date

(See clause 11 of NR/L2/OHS/0044 for the acceptance requirements)

Work Package Plan

Job No.	6381
Structure	090/Sea wall
ELR / Mileage	ECN2/20m 1400yds
Grid Reference	324145,686266
Post Code	KY3 9JX

Start Date: 25/07/22

Finish Date: 29/07/22

Work Package Plan Number:
WPP No. 6381.090.sea.wall

Controlled Copy Number
Add Unique No: 01

Construction [Phase Plan / Reference] Number
Add Unique No:

This document is the property of Amalgamated Construction Ltd / Giffen Group Ltd, the Principal Contractor or Contractor on the project.

Controlled copies will have a controlled copy number shown in **RED**. Any variation will be regarded as uncontrolled for information only.

The responsibility for the health, safety and environmental management of the Works rests fully and unreservedly with the Amalgamated Construction Ltd / Giffen Group Ltd. The acceptance of a Work Package Plan on behalf of Network Rail and involvement in Studies or Audits does not in any way absolve Amalgamated Construction Ltd / Giffen Group Ltd from that accountability and responsibility, nor is it intended to confirm or suggest that Amalgamated Construction Ltd / Giffen Group Ltd fully meets the statutory requirements.



DISTRIBUTION LIST

ISSUED TO:	JOB TITLE	ORGANISATION	VERSION
Brian Thomson	CRE Civils – Perth PM	Amco-Giffen	01
L McQuade	Document Controller	Amco-Giffen	01
	Site Supervisor	Amco-Giffen	01

VERSION CONTROL

REVISION NUMBER	SUMMARY OF CHANGES
Draft	Issued for review
01	Issued for construction
02	

High Street Environment?	Yes		
Competent Representative (COSS)	Name: Signature: Sentinel number:		
Segregation Type	Permanent physical Barrier	<input checked="" type="checkbox"/>	
	Fixed temporary physical barrier	<input type="checkbox"/>	
	Temporary portable barrier	<input type="checkbox"/>	
	Site keeper	<input type="checkbox"/>	
	Other, Describe	<input type="checkbox"/>	
Segregation Comments	<i>Works segregated from track by boundary fence. Op's must not cross boundary fence or go on/near the line.</i>		



CONTENTS

1 Introduction	4
1.1 Brief outline of work methodology	4
1.2 AMCO's delivery organisation	9
1.3 Resources	9
2 Working Together	10
2.1 At site communication	10
2.2 Contact details	10
2.3 Other parties involved with the package of work (interfaces details)	11
3 Hazard Management	11
3.1 Work involving particular risks	11
3.2 Significant railway and construction risks	12
3.3 Lifesaving rules and High Risk Areas	17
4 Environmental and Waste Management Arrangements	18
4.1 Environmental management arrangements	18
4.2 Waste management arrangements	19
5 Emergency Arrangements	19
5.1 Site emergency arrangements	19
5.1.1 First aid arrangements	20
5.1.2 Evacuation arrangements	22
5.1.3 Fire safety arrangements	23
5.1.4 Security arrangements	23
5.1.5 Environmental Emergencies	23
5.1.6 Summoning emergency services	24
5.1.7 Railway emergency (trains and electrical)	24
5.1.8 Asbestos	24
5.1.9 Utilities	24
6 Work Package Arrangements	26
6.1 Site Layout	26
6.2 Access and Egress	26
6.3 Welfare	27
6.4 Rail Traffic Management	27
6.5 Road Traffic Management	27
7 Hand Over and Hand Back Arrangements	28
7.1 Hand over and hand back arrangements	28
APPENDICES – Supporting information	Error! Bookmark not defined.
Appendix 1 – Risk Assessment	29
Appendix 2 – Drawings	Error! Bookmark not defined.
Appendix 3 – Site Layout Plan	Error! Bookmark not defined.
Appendix 4 – Spare	Error! Bookmark not defined.



1 Introduction

1.1 Brief outline of work methodology

Work Details / Remit – Burntisland – ECN2 – 090/Sea wall – 20m 1400yds – KY3 9JX

Grid Ref: 324145,686266

MASONRY REPAIRS - Carry out permanent repairs of areas of Voiding undercutting loose areas to following instructions, One 20m 1513yds, Two 20m 1555yds , Three 20m 1610yds, Four 20m 1644yds Five 20m 1651yds , Six 20M 1682yds , Seven 21m 0040yds , Eight 21m 0235yds ,Nine 21m 0235yds ,Ten 21m 0410yds

Access to the worksite will be made via Burntisland Slipway, behind the swimming baths, KY3 9BS for tracked plant and Bridge 70, A921, KY3 9LH

The site supervisor is to undertake a hazard review on site prior to works commencing to ensure that the WPP and SWP are reflective of the conditions and hazards at site. This is to include walking routes to/from the site and at place of works. This hazard assessment is to be formally recorded on POWRA. The supervisor will communicate this to you and how any further control measures required will be implemented and maintained and this will be recorded on POWRA.

Due to COVID-19 virus all briefings to be carried out with confined space of welfare van. All ops to keep a safe distance from each other during works i.e 2 meters as per recommended safe working practice, ops to wash hands before and after works with hand sanitizer available during works. Ops to be reminded to try and avoid contact with face.

Note* During COVID -19 the site supervisor will sign in on behalf of the works party.

The Site supervisor will ask each individual at the site signing in point:

- *If they currently have any of the potential Covid-19 symptoms, or*
- *If any of the people in their household currently have symptoms, or*
- *If they are living with a vulnerable person who is shielding from Covid-19*

Where any individual advises that they or a household member has symptoms, or is shielding they must leave site, return home and inform their line manager and HR coordinator without delay.

Covid 19 Mitigation

- Prior to attending site if any personnel within their household experiences symptoms they should contact AMCO HR prior to attendance on site.
- If persons on site experiences a dry continuous cough or high fever they should immediately remove themselves from site notifying Amco supervisor via the phone.
- All personnel onsite are to be equipped with face masks, goggles and glasses.
- Where practicable a 2 meter separation distance should be applied for the duration of the works.
- Where a 2 meter separation distance cannot be maintained, personnel should equip themselves with face masks, goggles and gloves.
- Welfare units to be cleaned before and after each use.
- Welfare units to be used by 1 person at a time in line with social distancing rules, staff should be given brakes on a rotational basis or use their own vehicles where possible.



- Further Covid 19 guidance can be found in the Covid 19 Risk assessment section of this document.

Report all incidents (pollution, flood events) and any other potential hazards to your supervisor.

SEPA flood warning web site to check. Work to start when there are no flood warnings in place.
flood.sepa.org.uk

Report any incident (at the time it happens) and any actions to resolve the issue. Any incident should be followed up with a written report to SEPA in due course. The pollution hotline number is 0800 807060 24/7/365.

Working in a marine environment:-

- Marine Scotland Licence to be available on site and the conditions adhered to.
- Tracked plant to be supplied with bio-oil and must be cleaned of all mud etc. from previous site.
- Excavator when tracking to keep away from rock formations and rock pools which could contain marine flora and fauna.
- Excavator must be re-fuelled at least 10m away from MHWS.
- Site Supervisor to issue **Permit to Work in Water**. The Site Supervisor will monitor the tide levels throughout the works. If the tide levels rise significantly the works will be stopped and the tide allowed to recede, before re-entering the watercourse. Life buoy ring to be set up and Life jacket to be worn at all times.
- **NOTE: Follow Check, Clean, Dry procedure on access/egress to the watercourse.**
- Spill kit to be on site and its use and location to be briefed to the workforce.

Excavators on site:-

- Supervisor to check certification of the machine and the competency of the operator.
- Excavator to work within an exclusion zone at all times and under the supervision of the banksman.
- Excavator to be provided with bio-oil and to be clean.
- Excavator to be re-fuelled at least 10m away from the MHWS.
-
-

Site operatives will be signed into the attendance register by the AmcoGiffen supervisor.

Note: AmcoGiffen Supervisor to carry out POWRA prior to works commencement each shift

The site supervisor will carry out a site specific briefing to the workforce prior commencing works including:

- *Work scope*
- *Whiteboard brief*
- *Location of emergency equipment*
- *Network Rail Hazzard Map*
- *Known Hazards*
- *Welfare provisions & Locations*
- *Check Competencies*
- *COVID-19 (Latest Guidance)*



Site supervisor will confirm competencies, certification of plant and inspection of tools/plant prior commencement. The AmcoGiffen site supervisor must be on site at all times when works are taking place.

TBS001 – Sea Wall Repairs

The supervisor will then brief the workforce on the tasks to be completed as per this work package plan.

Methodology

- Supervisor must carry out a POWRA at the beginning of each shift. This must be recorded on the tablet in the first instance or the booklet.

Delivery of plant –collection of plant

- Park up at swimming baths to take delivery of wheeled excavator and dumper.
- Ensure the parked vehicles don't obstruct others.
- Supervisor to ensure the delivery lay down area is suitable for heavy vehicles. No hidden voids and overhead obstructions.
- Trip hazards to be removed if present.
- Delivery vehicle to drive straight into access area. No reversing off the carriageway is permitted. Hazard beacons/lights to be on before slowing down to access.
- Reversing vehicles to be within an exclusion zone and controlled by a banksman.
- Delivery of plant to take place well away from the live railway as no ALO is in place.
- Exclusion zone to be in operation during the unloading of plant.
- Supervisor to check machines are clean and delivered with bio-oil. Check certification is in order and the competency of the operators.
- Spill kit to be available at all times with its location and how to use briefed to the workforce.
- Collection of plant to be carried out as per the delivery.
- When low loader is leaving site, hazard beacon/lights to be on. Access carriageway when it is safe to do so. Do not make oncoming traffic brake or swerve to avoid.

Accessing site with wheeled excavator & dumper

- Supervisor to ensure there is enough time to carry out the works by checking the tide times at the start of every shift.
- **Note:** Beware that tide may come in to the slipway before the work locations and could trap the excavator on the beach.
- Drive down slip way then make way along beach to location of repairs.
- Take care if walking down slipway as may be slippery due to seaweed etc.
- Dumper to be loaded with plant and materials.
- Dumper driver to wear seat belt at all times when driving.
- Keep away from rock pools where marine flora and fauna could be present.
- Banksman to be in attendance at all times and an exclusion zone to be in operation around the working plant and maintained at all times.



Staff accessing the sea wall

- Park up site vehicles next to Bridge 70 on the main Kinghorn Road to unload. Supervisor to ensure the parked vehicles don't obstruct other road users or pedestrians.
- Supervisor to brief the workforce of the presence of trip hazards due to rocks and uneven ground on the beach at the base of the sea wall. Watch where placing feet and do not carry plant and materials which could affect balance.
- Carry all plant and materials down through bridge 70 to access the sea wall.

Works

- Place men at work signs at either side of work location before commencing works.
- At the location of each site, lay polythene sheeting to the base of the wall on the beach to keep clean from the sea wall repairs.
- Make sure spill kit is available at each location of the works.
- Set up paddle mixer on an impervious layer of polythene and plywood at least 10m away from MHWS. Mixing area to be coned off from the general public.
- Set up generator, cables, Hilti-TE-80, Stihl saw. Where possible, all plant, equipment and tools to be set up at least 10m away from the MHWS. All fuelling to take place at least 10m away from MHWS on a plant nappy or drip tray.
- Excavator, working within an exclusion zone, to lift the fallen masonry off the beach and transport to the individual worksites on the sea wall.
- Care to be taken not to disturb the marine environment by lifting the natural stones from the beach or disturbing rock pools etc.

Location one - 20m 1513yds

- Remove all loose concrete from the sea wall and square up with Stihl saw.
- Fill holes with a Natcem 35 and existing masonry from the beach approx. 1sqm x 150mm deep.

Location two - 20m 1555yds

- Fill hole with Natcem35 and existing masonry from the beach approx. 600 x 600 x 500mm.

Location three - 20m 1610yds

- Fill the two holes with Natcem35 and existing masonry from the beach approx. 600 x 600 x 500mm.

Location four - 20m 1644yds

- Fill hole with Natcem35 and existing masonry from beach approx. 1.4 x 600 x 300mm.

Location five - 20m 1651yds

- Fill hole at base of wall with Natcem35 and Mastercrete rapid setting mortar approx. 5m x 300 x 75mm.



- Excavator to pass masonry from beach up onto wall head. Fill in hole with masonry approx. 1.2 x 1m x 500mm.
- Excavator to lift up 20 bags of Soluform from ground level up onto wall head to finish off hole.

Location six - 20m 1682yds

- Fill hole on with masonry from beach approx. 1.5 x 1.3 x 1.2 and level off with 20 Soluform bags to match top of the sea wall.

Location seven - 21m 0040yds

- Excavator to clear a road into the damaged wall leading from the sandy beach. Note no excavations are to take place on the beach below MHWS. Excavator to fill in the voids with masonry lifted from the beach.
- Excavator to place larger masonry into dumper (driver to stand aside during this task) and replace along the front of the damaged wall approx. 7m x 1.2m x 1m
- Ensure the newly placed stones are secure by compacting with bucket of the excavator.

Location eight - 21m 0235yds

- Fill in hole at base of wall using masonry from beach approx. 3m x 2m x 1m.
- Finish off hole with Soluform bags approx. 50 bags and level off to existing wall level.

Location 9 - 21m 0286yds

- Level off masonry stonework below the damaged concrete apron and lay 50 Soluform bags to front of apron.
- Batch Natcem 35 and pour onto the top of the Soluform bags, finish off with a wooden float.
- Excavator to load dumper with larger stones and place to front of the damaged area of wall approx. 7m x 1.2m x 1m

Location ten - 21m 0410yds

- Fill in hole at base of wall using masonry from beach approx. 600 x 600 x 500mm.
- Finish off hole with Natcem 35 and float off to match levels of existing wall.
- At the end of every shift, worksite/beach to be tidy and cleared of all plant and materials.

Site tidy

- All masonry, mortar or related material cleaned from the sea wall to be removed from site as much as possible, and not be allowed to remain on the beach.
- All plant and tools covered in cement/mortar to be washed out into a bucket at least 10m away from MHWS.
- Never allow concrete or mortar wash out in or near the marine environment; the resulting wash water is highly alkaline and can kill fish and other aquatic animals.



- Post photographs of each location to be taken before leaving site at the end of each shift.
- Plant itinerary check sheet to be cross checked when leaving site to ensure no plant is left behind.
- Excavator and dumper to return to slip way and park up in P-way yard in Burntisland.
- Return to the Perth Yard and dispose of debris etc. into the appropriate skips.

1.1.2 The following tasks support this Work Package Plan:

Reference & Prepared by:	Task Briefing Sheet Title	Activity Start Date
TBS001 M Cheyne	Sea wall repairs	25/07/22

1.2 AMCO's delivery organisation

1.2.1 The following individuals from the AMCO's organisation will be involved during this work package:

Contacts		
On call Manager		
Regional Director	Peter Ritchie	
Regional Manager	A Kane	
Contractors Engineering manager		
ALO Responsible Manager		
Temporary Works Coordinator	C Allan	
Sustainability & Assurance Advisor	M McDermott	
Procurement	Procurement North	01226 243 413
Site Agent	B Thomson	
H & S Advisor	Thomas McStay	
Depot Manager Perth	M McFadyen	
Depot Engineer	M Cheyne	
Site Supervisor		

1.2.2 The following companies, specialist contractors and/or individuals will be involved during this work package as defined in the CPP:

Name of company, specialist contractor or individual, etc.	Work activity / Specialism	Point of contact details	
		Name	Mobile
	Excavator hire	-	-
	Dumper hire	-	-

1.3 Resources

1.3.1 The following resources will be used for this work package:

People

Number of People and their competence associated with this WPP		Task
Competence	No of People	TBS Ref
Supervisor	1	TBS001
Skilled operatives	2	TBS001
General operatives	1	TBS001



Plant, Equipment and Tools

Quantity of Plant, Equipment and Tools associated with this WPP		Task
Plant item	No	TBS Ref
Generator	2	TBS001
Breakers	1	TBS001
Stihl saw	1	TBS001
Paddle mixer	1	Tbs001
Mixer	1	TBS001
Men at work signs	2	TBS001
Traffic cones	6	TBS001
Spill kit	2	TBS001

Materials

Quantity of Materials		Task
Material	Quantity	TBS Ref
Building sand	20 bags	TBS001
Rapid setting cement	5 bags	TBS001
Terram	4m x 4m	TBS001
Soluform bags	150	TBS001
Natcem 35	40 bags	TBS001
Polythene sheet	2 @ 2m x 2m	TBS001
Plywood sheet	2	TBS001

2 Working Together

2.1 At site communication

- The Site Supervisor will brief the contents of the WPP, NWR Hazard Map and permits in the Welfare van before works commence.
Other information to be discussed are as follows:
 - Covid-19 site operation requirements.
 - Daily Whiteboard
 - Any Site specific requirements/details.
 - Access/Egress arrangements to the works location.
 - POWRA to be carried out before each task.
- The Use of mobile phones must only be from a position of safety.
- Any Minor Changes to the WPP must be agreed with the **On Call Manager** using the PoWRA booklet refer to 1.2.1 in the WPP above for contact details.
- Any significant changes will require an amendment to the WPP and signed off by the **CRE/CEM** refer to 1.2.1 in the WPP above for contact details.
- Out of Hours any incidents or issues must be discussed with the On Call Manager refer to 1.2.1 in the WPP above for contact details.

2.2 Contact details

2.2.1 The following are the main contacts for this work package:



NR Project Team

Name	Role	Contact details	Tick to confirm number works and has been tested
A Sinclair	Project Manager (Structures)	[REDACTED]	√

Regulators

Organisation	Contact details	Tick to confirm number works and has been tested
Emergency Services	Emergency – 112 / Non Emergency 101	√
British Transport Police	0800 405040	√
HSE	Fatalities and Major Injuries - 0845 3009923. Other - http://www.hse.gov.uk/riddor/report.htm	√
ORR	020 7282 2000	√
EA/SEPA/NRW	0800 807060	√
Flood line	0345 9881188	√
Spill clean up	0800 592 827	√
Local Authority	Fife Council - 03451 55 00 99	✓

3 Hazard Management

3.1 Work involving particular risks

3.1.1 The work in this package does not involve any of the particular risk(s), as detailed in Regulation 12 (2), (Schedule 3) of the CDM Regulations 2015 **OR**

The work in this package involves the following particular risk(s), as detailed in Regulation 12 (2), (Schedule 3) of the CDM Regulations 2015:

Risk	When and where will the risk be present?	Permits Required	How will this risk be controlled?
<p>Work which puts workers at risk of falling from a height.</p> <p>HRA</p>	Risk not present on site		



Work which puts workers at risk from chemical or biological substances constituting a particular danger to the health or safety of workers or involving a legal requirement for health monitoring	Risk not present on site		
Work with ionizing radiation requiring the designation of controlled or supervised areas under regulation 16 of the Ionizing Radiations Regulations 1999	Risk not present on site		
Work near high voltage power lines	Risk not present on site		
Work exposing workers to the risk of drowning	Carrying out sea wall repairs	Permit to work in a watercourse	<ul style="list-style-type: none"> Tide times to be checked before starting work to ensure there is enough time to complete tasks. Remove plant from the beach well in advance of high tide as water levels at access/egress point may be different from those at the worksite location.
Work on wells, underground earthworks and tunnels	Risk not present on site		
Work carried out by divers having a system of air supply	Risk not present on site		
Work carried out by workers in caissons with a compressed air atmosphere	Risk not present on site		
Work involving the use of explosives	Risk not present on site		
Work involving the assembly or dismantling of heavy prefabricated components	Risk not present on site		

3.2 Significant railway and construction risks

3.2.1 The following are the significant railway and construction safety and health risks that apply during this work package. A copy of the risk assessments associated with this WPP can be found in **Appendix 1**

What are the main risks (including health) during this Work Package?	When and where will the risk be present?	Permits Required	How will the risk be controlled
Site procedures for COVID 19	At all times	Social Distancing Inspection Form	Site Operating documents to be fully briefed 2m social distancing to be adhered to at all times Where 2m distancing isn't possible RPE and PPE to be worn at all times, no skin-to-



			skin contact and minimal durations. If any of the Site Procedures cannot be undertaken safely then works should not take place Social Distancing Inspection Form to be completed prior to works commencing
Working in a high street environment – members of the public	At all times / allowing public to pass works safely	No	An appropriate barrier around the works to be set up: Plan work in sections if required to allow members of the public access past the works. One man to be watchman and to direct MOPs safely passed works. Men at work signs to be set up to warn MOPs of the works.
Excavator communications	Sea wall repairs	No	Network rail has mandated the use of DECT Comm II Duplex RRV Communications, where personnel are required to undertake activities involving on-track machines or on-track plant on or about Network Rail managed infrastructure, to improve the machine operator's ability to communicate with people working around the RRV. Work CANNOT start without such a system being in place.
People & Plant Interface - PPI	Sea wall repairs	No	Minimise – Full, physical segregation of people and plant. Observe the Plant Safe Zones by physically restricting people from entering the Red and amber exclusion zone. Erect physical barriers around a single operation outside the maximum reach of the machine. This must be marshalled.
Excavator on site	Sea wall repairs	No	Supervisor to check certification of the machine and the competency of the operator. Excavator to work within an exclusion zone at all times and under the supervision of the banksman. Permit to dig to be issued before any excavations take place.

















			Permit to lift to be issued before any lifting procedures take place. Lifts to be controlled by the slinger/signaller. Supervisor to ensure that the excavator is capable to carry out the planned lift.
Nipping, trapping and crushing 	At all times	No	Use Competent, trained staff and ensure that correct PPE including gloves are worn at all times. Pre-work briefing, toolbox talks. Operatives to complete Point of Work Risk Assessments if any changes to work.
Dumpers 	Transporting materials to and from worksite over rough ground	Plant check sheet. Competency of operator	1 Ton dumpers not to be used. Drivers should also be trained in the safe operation of the specific dumpers that they are required to drive. No one unfit to drive through the influence of alcohol, drugs or medication should be permitted to drive any vehicle. Use seat belts where ROPS are fitted. Get off the dumper when it is being loaded and ensure that the skip is not overloaded. Apply the parking brake, switch off the engine and remove the key when leaving the driver's seat. After carrying out the pre-use inspections, check the effectiveness of the handbrake, this should feel fairly tight and take a bit effort when applied and not at all loose. Avoid the need where possible to park loaded dumpers on any incline. If this cannot be avoided, create a bund from stone or introduce wheel chocks to prevent any movement of the dumper.
COSHH Substances (HRA – HS39)	When handling hazardous or items detrimental to health or the environment	No	COSHH items on site will be: Cement, mortar, Natcem 35 and Soluform. COSHH data to be available on site for COSHH items. Task Specific PPE worn at all times when handling COSHH Items Harmful substances to be used as per manufacturers recommendations.



			COSHH items stored off site when not in use. Operatives to be equipped with task specific PPE at all times whilst using COSHH items.
Plant – use of portable tools and equipment 	Carrying out the works	Competency of operator	Low voltage equipment (110v). Regular maintenance of tools. Circuit tests and PAT HAVs assessments to be undertaken.
Operating small tools 	Carrying out the works	Competency of operator	Operatives must be trained and competent. Inspect plant before use and report any faults to site supervisor.
Cement based products 	Masonry & pointing repairs	COSHH	Cement can cause ill health mainly by skin contact, inhalation of dust and manual handling. Therefore, appropriate PPE and COSHH awareness is essential
HAVS	When using small plant	No	Keep hands warm when operating vibrating plant and tools. Operatives to be briefed on ELV and EAV time limits. Site supervisor to monitor and record trigger times. Rotate workforce to minimise exposure times. N works to commence until Amco supervisor has referred to the trigger time register and briefed all operatives on the EAVs for the plant on site, this must be adhered to at all times during the works
Working in a marine environment 	Sea wall repairs	Marine Scotland licence to be on site. Permit to enter a watercourse	<p>Tide times to be checked to ensure there is enough time to complete tasks.</p> <p>Keep check on water levels at access point as may well be different from tide levels at the individual works sites.</p> <p>Do not work alone. Fresh concrete and cement are very alkaline and corrosive and can cause serious pollution to the marine environment. It is essential to ensure that the use of wet concrete and cement in or close to any beach is carefully controlled so as to minimise the risk of</p>



			any material entering the water.
Works over water  	Working next to a watercourse	Permit to enter a watercourse	Ensure that working platforms are secure with no tripping hazards. Surfaces which become wet and slippery should be cleaned and treated with sand or industrial salt.
Slips, trips and falls  	At all times	No	Get the right footwear with good tread and slip resistant soles. Take extra care poor weather conditions – slow down and look ahead to where you are placing your feet. Always use hand rails when climbing or descending stairs. Play your part in keeping your work place tidy – clear waste as it is generated, clean up spills and store materials safely. In extreme conditions stop work until actions are taken to make access ways safe. Always fix and report close calls, eg: poor underfoot conditions or access, unsafe stairs or walkways
Manual handling  	At all times	No	Operatives to be trained and competent in manual handling techniques. Correct lifting equipment and techniques to be used. Use mechanical means where possible. Assess the load before lifting. Do not lift more than you are capable. Share the load when practical to do so. See appendix for manual handling control measures
Access / egress from site    	At start and finish of shift	No	Care to be taken when walking along beach due to trip hazards from slippy rocks and uneven ground. Walking routes to be suitable and all trip hazards removed if possible
Leptospirosis  	At all times	No	Gloves to be worn at all times, hand washing and welfare facilities to be located on site for duration of the works
Noise / Occupational  	When using power tools	No	Hearing protection to be worn when operating grinders, chainsaws, Stihl saws, strimmers, drills etc.



3.3 Lifesaving rules and High Risk Areas

3.3.1 The following table highlights those Life Saving Rules applicable to this WPP

Always		Never	
	✓ or X		✓ or X
	✓		✓
	✓		✓
	X		X
	✓		✓
	X		✓

3.3.2 The following table highlights those HRA's applicable to this WPP

 Breaking Ground	 Change Management	 Confined Spaces	 Electrical & Stored Energy	 Fire & Hot Work
No	No	No	No	No
 Lifting Activities	 People & Plant	 Railway Operations	 Working at Height	 Work Related Road Risk
No	Yes	No	No	No
 Works In, Over or Near Water	 Works producing dust, noise & vibration	 Activities with Potential to Cause Pollution	 Works Affecting Protected or Invasive Species	




Yes	Yes	Yes	Yes
-----	-----	-----	-----

4 Environmental and Waste Management Arrangements

4.1 Environmental management arrangements

4.1.1 The following environmental issues are applicable to this WPP

Environmental Issues	Project Control Measures	Environmental Consents and Permits
Management of oils and chemicals	<ul style="list-style-type: none"> Containers shall be fit for purpose, labelled and have proper fitting lids. Containers and tanks shall be made secure against vandalism or theft Refuelling shall take place in a dedicated area at least 10m away from a watercourse Drip trays shall be used whilst refuelling. Spill kits shall be kept on site 	
Management of silt	<ul style="list-style-type: none"> Consideration shall be given to the silt hierarchy where potential for silt/soil pollution on site i.e., 1- eliminating work within the water, 2- isolation of working area, 3- minimising soil/silt movement through choice of methodology or reducing veg strip; 4- controlling runoff/silty water using straw bales, Sedimats, silt fences, etc. 	•
Dust, Noise, Odour	<ul style="list-style-type: none"> Dust from cutting to be suppressed using water The workforce is to turn plant off when not in use, this will minimize noise levels within the site of work. 	•
Working in or near a marine environment 	<ul style="list-style-type: none"> Works undertaken above water level, access outside of watercourse. Weather forecast to be monitored, work undertaken during low water levels, if possible. Check, Clean, Dry procedure followed The silt mitigation measures are to be installed as per the methodology of this work package plan where silt is disturbed through works. 	Marine Scotland Licence to be in place before commencing work
Works affecting flora or fauna	<ul style="list-style-type: none"> Work to stop if protected species or nesting birds found and advice sought. 	•
Works affecting cultural heritage	<ul style="list-style-type: none"> Works to comply with consent Works to be in keeping with the style of the original structure. 	•
Flood Risk Management	<ul style="list-style-type: none"> Monitoring of compliance with any permit / licence / consent affecting watercourses and flood risk Daily completion of the Permit to Work Within, Over, and Adjacent to a Watercourse (HS131) Review and communication of weather forecast, flood information and tide times. Use of national flood warning services: https://flood-warning-information.service.gov.uk/warnings Checking of any temporary works to ensure that they suitable and sufficient to cope with seasonal weather / river flows 	•

Work Package Plan – [NR Project Name & Number] – Draft/Issue #



	<ul style="list-style-type: none"> Measures to be established to prevent debris entering the watercourse which may pose a flood risk. Where possible, materials, plant and other items shall be stored at least 10m from the watercourse edge or, preferably, off the flood plain altogether. 	
--	---	--

4.2 Waste management arrangements

4.2.1 The following waste management arrangements are applicable to this WPP. All waste shall be reused or recycled in accordance with the Site Waste management Plan.

Waste type	How will it be stored?	Testing required prior to disposal	Waste classification	Reuse (R) onsite / Disposal off site (D)
General site waste	Bagged	No	Non hazardous	D

5 Emergency Arrangements

5.1 Site emergency arrangements

Site Location: Burntisland – ECN2 – 090/Sea wall – 20m 1400yds – KY3 9JX		
Grid Ref: 324145,686266		
Contact	Name or Location	Tel. Number
Ambulance, Fire	Various	999 (112 from Mobile)
BT Police	Control Centre	0800 405 040
Incident Controller	NWR	0141 335 2020
Gas	Nation Grid	0800 111 999
NR Sharps	NR	01904 525 894
Scottish water	Emergency	0845 600 8855
Nearest A & E Hospital	Victoria Hospital, Kirkcaldy. KY2 5AH	01592 643 355
SEPA	Control Centre	0800 807 060 24/7/365
Flood line	National Flooding Helpline	0345 988 1188.
Spill response	Addler & Allan	0800 592 827

Reporting of Accidents, Incidents & Close Calls

All H&S Accidents, Major Environmental Incidents, Damage to Client or Utility Infrastructure and Rail Possession Irregularities are to be verbally reported as soon as practicable, to line management.

Any Incident/Accident must be reported through the AMCO on-call as soon as site is safe and in a position to do so and or request your assistance to update NWR Control.

Person reporting to the AmcoGiffen 'On-Call Manger' to Check and Confirm the following:

- Who you are (Joe bloggs),
- Your location (Example East Junction or near to SH20 (sierra, hotel, two, zero) signal
- Identify what has happened i.e. the accident/incident/significant close call
- What action needs to be taken i.e. Emergency Assistance, Emergency Line Block etc?



- Confirm whether this has been reported to NWR Control (Decide who will report this)
 Reporting to NWR must be within 2 hours of the event happening.
- Photographs to be taken of location

5.1.1 First aid arrangements

5.1.1.1 The first aid arrangements for this package of work are

First aiders	Name	Qualifications
	XXXXXX	First Aid at Work
Likely injuries associated with this work package	Cuts, abrasions, eye injuries, broken bones, sprains	
First aid equipment provision	Equipment	Location
	First Aid Kit	1 x kept on site during the works 1 x kept in the site welfare van

First Aid Risk Assessment

NR/L2/OHS/00110/F01 - FIRST AID RISK ASSESSMENT		
To be used in conjunction with First Aid at Work business process NR/L2/OHS/00110		
Date:	30/03/22	
Location:	Burntisland	
Name:	M Cheyne	
Workplace/Activity being assessed:	Sea wall repairs	
1. Injury and Ill Health Using your knowledge and experience of the general level of accidents and illnesses suffered by your staff undertaking this type of activity, in the assessed environment allocate a value from 1 to 6 from the table on the right: (If necessary, consult accident records and/or staff representatives)	POTENTIAL SEVERITY 1 Minor injury, but no time off work 1 2 Injury causing up to 3 days' absence 1 3 Injury causing more than 3 days' absence 1 4 Long-term absence 1 5 Single Fatality 1 6 Multiple Fatality 1	
	Potential severity of accident or illness Insert figure here 6	
	2. Work Activity Using your knowledge and experience of the type of activity to be undertaken, allocate an appropriate score from 0 to 5: 0 = no risk, 5= high risk or N/A, then add together for TOTAL figure NOTE: control measures shall affect your scoring	
	On or near the line	0
	Working at height	0
	Hazardous chemicals	3
Manual handling	3	
Electrical	0	
Cutting equipment	3	
Plant machinery	3	



Working at night		0
Any additional hazardous work activity e.g. dealing with public, confined spaces, radiation sources (please score as instructions above and name activity below)		
	Insert TOTAL figure here ■	12
3. Number of people working at workplace or site of work (pick most typical figure)	Lone worker (5)	3
	2 to 50 (3)	
	51 and above (5)	
	Insert figure here ■	
4. Vulnerable Individuals Are there inexperienced workers or people with disabilities or health problems? (assume yes if you do not know the group e.g. Contractors, public)	Yes (5)	1
	No (1)	
	Insert figure here ■	
5. Remoteness 5.1 Likely response time for emergency services to arrive on scene of incident? (pick most typical figure)	8 minutes (1)	3
	30 minutes (3)	
	Over 30 minutes (5)	
	Insert figure here ■	
5.2 Has a suitable road vehicle access point for evacuation been identified at the planning stage? (pick most typical figure)	Yes (1)	1
	Moving worksite (3)	
	No (5)	
	Insert figure here ■	
5.3 Is emergency mobile telephone communication available at the workplace or site of work, with coverage? (pick most typical figure)	Yes (1)	1
	Usually (3)	
	No (5)	
	Insert figure here ■	
Add the numbers you have inserted in the summary boxes for sections 1 – 5 to determine risk level from the Table below. Then use the table on Page 2 of this form for the suggested minimum level of provision for the severity level identified.		
Table:		
Low Severity	1 - 18	
Medium Severity	19 - 30	
High Severity	31 and above	
		Insert OVERALL score here ■
		27
CAUTION – Check the total scores are correctly calculated as it would impact on the severity category		
Table 1 - Suggested first aid provision		



Potential severity of injury/ill health at workplace/site of work	Number of employees	Minimum number of first aid personnel on duty at all times	The following factors may affect provision
Low severity	Fewer than 25	At least 1 Appointed Person	<ul style="list-style-type: none"> • If a low severity has been identified, there is still a possibility of an accident or illness occurring, consider providing a first aider • Planned or unplanned absences of first aid personnel • Members of the public in the area • Employees who work shifts or out of hours • The needs of contractors working for Network Rail • Workplace or site of work remote from emergency services • Types of injuries that can occur with activity
	25 - 50	At least 1 Emergency First Aid at Work first aider	
	More than 50	At least 1 First Aid at Work first aider for every 50 employees	
Medium severity	2 - 24	At least 1 Emergency First Aid at Work first aider	
	More than 25	At least 1 Emergency First Aid at Work first aider OR At least 1 First Aid at Work first aider for every 25 employees , depending on the type of injuries that might occur	
High Severity	2 - 24	At least 1 Emergency First Aid at Work first aider	
	More than 25	At least 1 First Aid at Work first aider for every 25 employees , depending on the type of injuries that might occur	
<p>PLEASE NOTE – First aiders working in high severity environments may require additional training or first aid equipment. More information can be found in the First Aid at Work business process NR/L2/OHS/00110</p>			

5.1.2 Emergency Arrangements

5.1.2.2 All H&S Accidents, Major Environmental Incidents, Damage to Client or Utility Infrastructure and Rail Possession Irregularities are to be verbally reported as soon as practicable, to line management.
 Any Incident/Accident must be reported through the AMCO on-call as soon as site is safe and in a position to do so and or request your assistance to update NWR Control.

Person reporting to the AmcoGiffen 'On-Call Manger' to Check and Confirm the following:



- Who you are (Joe Bloggs),
- Your location (Example East Junction or near to SH20 (sierra, hotel, two, zero) signal
- Identify what has happened i.e. the accident/incident/significant close call
- What action needs to be taken i.e. Emergency Assistance, Emergency Line Block etc.
- Confirm whether this has been reported to NWR Control (Decide who will report this) Reporting to NWR must be within 2 hours of the event happening.
- Photographs to be taken of location

5.1.3 Evacuation arrangements

5.1.3.1 If required, Evacuation will be initiated by COSS/Site Supervisor Muster Point. If evacuation is initiated it will be done verbally and all personnel will make their way to the agreed muster point. Muster point to be identified within the pre-work brief by the Amco supervisor

5.1.4 Fire safety arrangements

In the event of a fire, the person who identifies the fire will utilise the air horn and all site personnel will evacuate using the designated emergency exit route and make their way to the fire assembly point / muster point immediately after hearing the emergency horn, they will wait there until further notice.

5.1.4.1 Firefighting equipment will be available on site in a safe location with additional equipment stored in site vehicles at the access. If in the event of a fire on site the Amco operatives, if safe to do so will extinguish it with the onsite equipment.

5.1.5 Security arrangements

5.1.5.1 Ensure access gates are secured on access/egress

5.1.5.2 Keep site vehicles locked when not attended and remove all plant, tools and materials at end of every shift and during breaks.

5.1.6 Environmental Emergencies

5.1.6.1 Extreme Weather and Flooding:

- Monitoring of compliance with any permit / licence / consent affecting watercourses and flood risk.
- Daily completion of the Permit to Work Within, Over, and Adjacent to a Watercourse (HS131).
- Review and communication of weather forecast, flood information and tide times. Use of national flood warning services: <https://flood-warning-information.service.gov.uk/warnings>.
- Checking of any temporary works to ensure that they suitable and sufficient to cope with seasonal weather / river flows.
- Measures to be established to prevent debris entering the watercourse which may pose a flood risk.
- Where possible, materials, plant and other items shall be stored at least 10m from the watercourse edge or, preferably, off the flood plain altogether.

5.1.6.2 Oil Spill:

Adopt the following procedure where safe to do so: STOP the source of the spill. CONTAIN the spill using available spill equipment. NOTIFY your Site Manager. CLEAN UP the spill and dispose of waste materials as a hazardous waste. If the

23 of 55	Proforma uncontrolled when printed	RFM-HS-006-05
Parent Procedure:	HS52: Planning and Managing Rail Construction Work	



spill is beyond your control, contact the 24hr emergency response contractor on 0800 592827.

5.1.6.3 Silt Incident:

N/A

5.1.7 Summoning emergency services

5.1.8 Emergency Services can be summoned by using the COSS/Site supervisors Mobile (Location to be agreed within Pre start Briefings on site) in the case of this work package plan the workforce will inform the emergency services of the following information relating to the location; Burntisland – ECN2 – 090/Sea wall – 20m 1400yds – KY3 9JX
 Grid Ref: 324145,686266

Railway emergency (trains and electrical)

In the event of an emergency affecting the safety of the railway the following actions will be undertaken.

1. Do not place yourself or the safety of others in danger
2. The lead communicator on site will be one of the following people and in this order – PICOP > Route Setting Agent > Protection Controller > COSS or SWL or IWA.
3. In an emergency a train can be stopped by raising both arms in the air or at night by waving a light vigorously
4. In an emergency the signaller / ECO shall be contacted immediately via mobile phone or using the nearest signal post telephone.
 The lead communicator shall state (*using the phonetic alphabet to communicate any difficult words*) :
 - 'This is an emergency call'
 - Confirm who you are speaking to the right person *ie usually the signaller or Electrical Control Operator (ECO)*
 - Tell them
 - who you are (*Joe bloggs*),
 - what you do (*ie COSS*); and
 - your location (for example *Shapton East Junction or near to SH20 (sierra, hotel, two, zero) signal*)
 - Describe the problem and what part of the railway is affected *ie Down Main xx or Level crossing at yy*
 - Tell them what action needs to be taken *ie any emergency service required*
 - Ask the person to 'repeat back' the information
 - The Signaller or ECO shall end the conversation.

5.1.9 Asbestos

5.1.7.1 N/A

5.1.10 Utilities

5.1.8.1 N/A

Organisation	Contact details
Electricity	Scottish Power 0800 027 0072



Gas	Scottish Gas Networks 0800 912 1700
Telecoms	British Telecom 0800 800150
Water	Scottish Water 0800 077 8778



6 Work Package Arrangements

6.1 Site Layout



6.2 Access and Egress



6.2.1

Parking/Access – Kinghorn Main Road at bridge 70 – pedestrians

Work Package Plan – [NR Project Name & Number] – Draft/Issue #



Parking/Access – Burntisland Slipway.

6.3 Welfare

Welfare Assessment Matrix

No. of Persons	No. of work periods (consecutive shifts, days or nights)								
	1	2	3	4	5	6	1 Week	2 Weeks	>2 Weeks
1	A	A	B	B	B	B	B	B	B
2	A	A	B	B	B	B	B	C	C
3	A	A	B	B	B	B	C	C	C
4	A	B	B	C	C	C	C	C	C
5	A	B	B	C	C	C	C	C	C
6	A	B	B	C	C	C	C	C	C
7	A	B	C	C	C	C	C	C	C
8	A	B	C	C	C	C	C	C	C
9	B	B	C	C	C	C	C	C	C
10	B	C	C	C	C	C	C	C	C
11+	C	C	C	C	C	C	C	C	C

KEY

Category A: Transient site. Arrange for sufficient and suitable local facilities to be used. These may be public or private facilities, e.g. NR stations/depots/buildings/signal boxes, garages and shops.

Category B: Transient site. Arrange for suitable and sufficient temporary welfare facilities, e.g. welfare vehicles.

Category B: Transient site. Use of onsite Hog or Pod.

Category C: Non-Transient site. Establish a site cabin with fixed welfare facilities, car parking, traffic management, site access control, etc.

Note 1 The overall travel time to any toilet provision shall be not more than 20 min from the point of work, but ideally within 10 min

Note 2 In certain circumstances local facilities, if suitable, permanently available and by agreement, may be preferable to temporary site welfare facilities.

Note: Due to site and COVID-19 restrictions works will be serviced by way of Welfare van, Hog or Pod.

Welfare Vans, Hogs or Pods must be thoroughly cleaned at the end of each break / shift, e.g. chairs, door handles etc.

Equipment such as kettles, microwaves etc. are provided, they must be regularly cleaned and/or sanitised and enhanced cleaning measures.

Welfare facilities to be provided in the form of a Welfare Van. AMCO shall comply with the requirements of the Network Rail Welfare Standard NR/L3/INI/CP0036 Appendices A & B. Details on site welfare provision can be found in Appendix 3 of the CPP.

6.4 Rail Traffic Management

6.4.1 N/A

6.5 Road Traffic Management

6.5.1 N/A



7 Hand Over and Hand Back Arrangements

7.1 Hand over and hand back arrangements

- 7.1.1 AmcoGiffen Supervisor will carry out a check of the work site to ensure no materials & equipment has been left within the worksite and surrounding area.
 Working area to be left clean & tidy.



Appendix 1 – Risk Assessment

Control of activity risks

The table identifies particular hazards and risks that may be present during the works. Toolbox talks will be given where on these risks are deemed necessary but at a rate of not less than one per week. Weekly site audits will be undertaken by the Site Supervisor / Site Manager.

PREPARED BY: M Cheyne		DATE PREPARED: 30/03/22		OVERALL RISK	
SEVERITY		PROBABILITY		RISK	
LOW	1	1	NOT LIKELY	LOW	1 TO 6
SLIGHT - FIRST AID TREATMENT	2	2	POSSIBLE - OTHER FACTORS NEEDED BUT NOT LIKELY	MEDIUM	7 TO 15
MODERATE - OVER 3 DAYS INJURY	3	3	QUITE POSSIBLE - OTHER FACTORS NEEDED - LIKELY	HIGH	16 TO 25
HIGH - MAJOR INJURY / DEATH	4	4	LIKELY - OTHER FACTORS THEN WILL HAPPEN		
VERY HIGH - MULTIPLE DEATH	5	5	VERY LIKELY - WAITING TO HAPPEN		

Applicable Tasks	
1.	Sea Wall Repairs
2.	
3.	
4.	

Hazard	Hazard outcome	S	P	Initial risk	Risk control measures	Residual risk	Applicable Tasks			
							1	2	3	4
Starting Works	Reportable or minor Incident	3	3	9	<ul style="list-style-type: none"> The site supervisor is to undertake a hazard review on site prior to works commencing to ensure that the WPP and SWP are reflective of the conditions and hazards at site. This is to include walking routes to/from the site and at place of works. All information to be recorded on POWRA. Site Supervisor to brief any extra control measures and how they will be implemented and maintained. 	3	✓			
Workings	Reportable or minor Incident	3	3	9	<ul style="list-style-type: none"> 5day SSSTS supervisor on site at all times All activities recorded in daily diary All workings supervised at all times Weekly Site Managers inspection carried out 	3	✓			
Slips trips and falls	Reportable or minor Injury	3	3	9	<ul style="list-style-type: none"> Care to be taken when walking on site, especially on the beach. Steel toe cap boots must be worn at all times Site Supervisor to ensure site is cleared on a regular basis and the end of each shift. 	3	✓			



Network Rail Project No: 6381

AG Contract No: SCOAM18

Issue: 01

Revision Date: 30/03/22

Hazard	Hazard outcome	S	P	Initial risk	Risk control measures	Residual risk	Applicable Tasks			
							1	2	3	4
Slips trips while wearing wellington boots	Reportable or minor Injury	3	4	12	<ul style="list-style-type: none"> Wear correct size of boots. Ensure treads are not worn. Steel toe capped and steel shanked mid-sole. Don't drive with them on. Not perished. Stored in the proper manner ie standing up away from oil, grease and fuel. Make sure worn on correct feet. 	2	✓			
High street environment works	Major or minor injury	5	4	20	<ul style="list-style-type: none"> Men at work signs to be placed either side of the works. Man to be positioned to escort pedestrians passed the works to ensure their safety. Stop works if required. 	4	✓			
Working in/adjacent to a marine environment	Reportable or major Injury	5	4	20	<ul style="list-style-type: none"> Tide times to be checked so that there is enough time to complete tasks. Awareness of hazardous flora and fauna. Correct PPE. Use of insect repellents. Adherence to Weill's Disease procedures. Secure working platform. Emergency preparedness and fall recovery procedure. Trained first aiders. Marine Scotland licence to be retained on site and recommendations adhered to. Permit to work in watercourse. 	4	✓			



Hazard	Hazard outcome	S	P	Initial risk	Risk control measures	Residual risk	Applicable Tasks			
							1	2	3	4
					•					
COSHH (HRA – HS39) 	Reportable or minor injury	3	4	12	<ul style="list-style-type: none"> COSHH data on site for COSHH items – cement, mortar, Natcem35 Task Specific PPE worn at all times when handling COSHH Items Harmful substances to be used as per Manufacturers recommendations COSHH items stored off site when not in use Operatives to be equipped with task specific PPE at all times whilst using COSHH items 	3	✓			
Operated Plant – excavator and dumper 	Reportable or Major Injury	5	4	20	<ul style="list-style-type: none"> Site Supervisor to confirm plant operator's competency and certification of the operated plant. Plant operators access permit and plant checklist to be completed prior to undertaking works. Exclusion zone to be established around all plant operations. All plant movements to be controlled by banksman and undertaken within established exclusion zone.	5	✓			
Plant & People Interface PPI	Major, reportable or minor injury	5	4	20	1. Minimise – Full, physical segregation of people and plant. Observe the Plant Safe Zones by physically restricting people from entering the Red and amber exclusion zone. Erect physical barriers around a single operation outside the maximum reach of the machine. This must be marshalled.	5	✓			
Ground worker being struck by slewing excavator causing crush injury or fatality	Fatal or major injury	5	4	20	<ul style="list-style-type: none"> Machine operators CPCS trained and competent. Exclusion zone to be established, no unauthorised personnel allowed within operations. Workers to wear hi visibility vests and helmets at all times. 	5				



Hazard	Hazard outcome	S	P	Initial risk	Risk control measures	Residual risk	Applicable Tasks			
							1	2	3	4
					<ul style="list-style-type: none"> Workers to keep clear of moving excavator at all times and not to approach until signalled by excavator operator. Keep out of swing radius of machine. Ancillary devices to be fully operational. Hazard beacons lights on at times of operation. No use of mobile phones when operating plant. Remove keys and secure plant when not in use. Where possible no works will be undertaking next to excavations. Fencing, signage, bunds and or block stops to be placed around excavations to prevent plant entering excavations. 					
Working within Public access 	Reportable or Major Injury/Incident	4	4	16	<ul style="list-style-type: none"> Men at work signs to be established out with work area to notify of works undertaken Where pedestrian access is required works are to cease, site supervisor to confirm safe access is possible and permit pedestrians access. Site Supervisor to confirm all works are stable, material stored securely and site tidied at the end of the shift. 	4	✓			
Use of Small tools 	Reportable or minor Injury	3	4	12	<ul style="list-style-type: none"> Operators must be trained and competent. Impact goggles/face shield to be worn at all times. Inspect plant and equipment before use and take damaged sections out of use and seek replacements. 	3	✓			



Hazard	Hazard outcome	S	P	Initial risk	Risk control measures	Residual risk	Applicable Tasks			
							1	2	3	4
Operating Small Plant and tools (HRA – HS40) 	Reportable or major Injury	4	3	12	<ul style="list-style-type: none"> Operators must be trained and competent. Impact goggles/Face shield to be worn at all times. Inspect plant and equipment before use. Report faults to Site supervisor. Take damaged plant out of use. Guards to remain in place where fitted to tools. Use HAVS register to record time on equipment. Wearing of gloves and correct PPE for the task. Maintenance of tools. Rotation of workforce to reduce exposure times. 	4	✓			
PPE	Reportable or minor Injury	3	3	12	<ul style="list-style-type: none"> Correct PPE to be worn at all times. Protective glasses to be worn at all times. Task specific PPE will be used as required. PPE should be clean and fit for use Covid 19 specific PPE; FFP2 RPE, eye protection (goggles or face shield), nitrile gloves (or similar) beneath task gloves. The personnel involved should be briefed in the safe way to wear and remove RPE and gloves and the safe disposal of used PPE (see AmcoGiffen TBT 01-20 for guidance on this). 	3	✓			
HAVs 	Reportable or minor Injury	3	4	12	<ul style="list-style-type: none"> Site Supervisor to record Trigger times. Take regular breaks, rotate the task. Inspect plant and equipment before use and take damaged sections out of use and seek replacements. 	3	✓			



Network Rail Project No: 6381


AG Contract No: SCOAM18

Issue: 01

Revision Date: 30/03/22

Hazard	Hazard outcome	S	P	Initial risk	Risk control measures	Residual risk	Applicable Tasks			
							1	2	3	4
Manual Handling	Reportable or minor Injury	4	3	12	<ul style="list-style-type: none"> Check access route across beach before works commence for uneven ground or obstructions. Assess the load before lifting – heavy items include mixers, bags of materials and masonry from the sea wall. Seek help for awkward shaped items of for carrying over long distances. Excavator to lift masonry off the beach and lift up onto the sea wall. See appendix for manual handling control measures 	4	✓			
Access and egress (HS66)	Reportable or minor Injury	3	3	9	<ul style="list-style-type: none"> Supervisor to assess across the beach for suitability. Remove trip hazards to ensure safety of workforce Use of slip way for accessing the beach. Note may be slippery. Care to be taken. 	3	✓			
Working or accessing worksite on slippery ground	Reportable or minor injury	3	4	12	<ul style="list-style-type: none"> Eliminate condition where possible. (Dry sand, salt, grade out uneven land, drain off standing water.) Extra care particularly on slopes. Adequate Safety Footwear to be worn at all times. Remove trip obstructions. 	3	✓			
Working or accessing worksite on inclined ground	Reportable or minor injury	3	4	12	<ul style="list-style-type: none"> Identify alternative access. Identify safe working locations. Secure plant and equipment from slipping. Additional care on grassed areas which can be slippery and loose ground. Adequate Safety Footwear to be worn at all times. 	3	✓			
Leptospirosis	Reportable or Major injury	3	3	9	<ul style="list-style-type: none"> Gloves to be worn at all times. Wash hands before eating, drinking and or smoking. Report to Doctor if flu like symptoms persists. 	3	✓			



Hazard	Hazard outcome	S	P	Initial risk	Risk control measures	Residual risk	Applicable Tasks			
							1	2	3	4
Sharps/Hypodermic needles 	Reportable or Major injury	3	2	6	<ul style="list-style-type: none"> Keep clear until such times as area is cleaned of all sharps/needles. Encourage the wound to bleed, prevent further contamination. Report to hospital, taking offending sharp with patient. Contact the Local Authority Environmental Health Department to get them removed. Report to NWR via Route Control – 0141 335 2775. Highlight area with spray paint. 	3	✓			
Hygiene (HS55)	Illness, weils disease	3	2	6	<ul style="list-style-type: none"> Welfare van available for shelter, place to rest and eat during breaks Welfare van to be kept clean and tidy at all times All site personnel to use site facilities and under no circumstances will food or drink be consumed on site. Rubbish disposal points and regular removal from site. 	3	✓			
Injury	Illness, cuts, falls	3	2	6	<ul style="list-style-type: none"> Appointed Person on site (3day First Aid) First aid kit located within welfare van List of First Aiders in Job Pack A&E Hospital route and location map in Job Packs. All details included in site inductions. 	3	✓			



Appendix 3 – COVID 19 Risk Assessment

Control of activity risks

The table identifies particular hazards and risks that may be present during the works. Toolbox talks will be given where on these risks are deemed necessary but at a rate of not less than one per week. Weekly site audits will be undertaken by the Site Supervisor / Site Manager.

PREPARED BY:	M Cheyne	DATE PREPARED:	30/03/22	OVERALL RISK	
SEVERITY		PROBABILITY		RISK	
LOW	1	1	NOT LIKELY	LOW	1 TO 6
SLIGHT - FIRST AID TREATMENT	2	2	POSSIBLE - OTHER FACTORS NEEDED BUT NOT LIKELY	MEDIUM	7 TO 15
MODERATE - OVER 3 DAYS INJURY	3	3	QUITE POSSIBLE - OTHER FACTORS NEEDED - LIKELY	HIGH	16 TO 25
HIGH - MAJOR INJURY / DEATH	4	4	LIKELY - OTHER FACTORS THEN WILL HAPPEN		
VERY HIGH - MULTIPLE DEATH	5	5	VERY LIKELY - WAITING TO HAPPEN		

Applicable Tasks
1. Sea wall repairs
2.

Hazard	Hazard outcome	S	P	Initial risk	Risk control measures	AMCO Ref	Residual risk	Applicable Tasks			
								1	2	3	4
All activities.	Spread of Coronavirus from poor awareness of AmcoGiffen Covid-19 Guidance causing: <ul style="list-style-type: none"> Mild Illness Severe illness Fatality 	3	3	9	Follow Government guidelines All operatives, via their sponsor to be issued with clear instructions on all safety. Issue AmcoGiffen COVID-19 requirements prior to attending site – minimum one shift in advance. Proof of acceptance and understanding to be provided prior to operative being allowed onto site	AmcoGiffen Covid-19 Guidance	6				



Hazard	Hazard outcome	S	P	Initial risk	Risk control measures	AMCO Ref	Residual risk	Applicable Tasks			
								1	2	3	4
All activities.	Spread of Coronavirus from person who are unaware of AmcoGiffen Covid-19 Guidance and no control; over supplier and subcontractors causing: <ul style="list-style-type: none"> Mild Illness Severe illness Fatality 	3	3	9	If any individual is already self-isolating in accordance with the Government guidelines, they are not to turn up: <ul style="list-style-type: none"> AmcoGiffen management to check register Agencies to confirm all attending are fit for duty and no signs of illness Sub-Contractors to confirm to Project/Depot/Site manager 	AmcoGiffen Covid-19 Guidance	6				
All activities	Spread of Coronavirus due to lack of suitable hand washing facilities and materials causing: <ul style="list-style-type: none"> Mild Illness Severe illness Fatality 	3	3	9	Hot water and soap to be available at all locations to allow operatives to wash hands as frequently as possible for 20 seconds. Apply personal hand sanitiser as frequently as possible. Stay 2m away from other people where possible	AmcoGiffen Covid-19 Guidance	3				
All activities	Damage to mental health of employees due to: <ul style="list-style-type: none"> Concern about contracting the virus through work activities Passing on virus to family members 	3	3	9	Adhere to the control measures in AmcoGiffen Site Operating Procedures for Covid-19. Adequate supervision and monitoring of site activities to provide reassurance on additional controls When there is a 'Change=Stop', stop work and report concerns to supervisor / manager.	AmcoGiffen Covid-19 Guidance	6				
Travel to and from Site	Spread of Coronavirus causing: <ul style="list-style-type: none"> Mild Illness Severe illness Fatality 	3	3	9	Site to brief and implement the following arrangements, wherever possible: <ul style="list-style-type: none"> One person per van. Road vehicles should be single occupancy unless you are able to travel in a medium / 	AmcoGiffen Covid-19 Guidance	3				



Network Rail Project No: 6381

AG Contract No: SCOAM18

Issue: 01

Revision Date: 30/03/22

Hazard	Hazard outcome	S	P	Initial risk	Risk control measures	AMCO Ref	Residual risk	Applicable Tasks			
								1	2	3	4
					<p>long wheelbase crew / messing vehicle that has an approved barrier installed, when two people (including the driver) are permitted. In this case the passenger should sit as far away as possible, on the diagonal, from the driver and good air flow should be maintained. Journeys should be shared between the same individuals. Try not to rotate teams using a van.</p> <ul style="list-style-type: none"> • Limit the number of persons per van to maintain some distance between occupants, e.g. keep an empty seat between each occupied seat during travel to / from / during work. Try not to rotate teams using a van. • Use alternative means of transport to avoid public transport where possible. • If available, travel to site could be using own transport, as long as the relevant insurance is in place and approved by Regional Director. • Providing hand-cleaning facilities at entrances and exits. This should be soap and water or hand sanitiser. • Wipe door handles with bacterial wipes before egressing car. • Regularly clean the inside of vehicle cabs and between uses by different operators. • Vehicles to be thoroughly cleaned at the end of each shift. 						



Hazard	Hazard outcome	S	P	Initial risk	Risk control measures	AMCO Ref	Residual risk	Applicable Tasks			
								1	2	3	4
Parking at the Office, Depot and other sites.	Spread of Coronavirus causing: <ul style="list-style-type: none"> Mild Illness Severe illness Fatality 	2	3	6	All vehicles to be reverse parked or nose to bumper. If the driver parks vehicle next to another vehicle with a passenger – only 1 to egress from vehicle until 2m away before other person egresses.	AmcoGiffen Covid-19 Guidance	3				
Arriving at Depot/Site – Taking of Temperatures	Spread of Coronavirus causing: <ul style="list-style-type: none"> Mild Illness Severe illness Fatality 	3	3	9	Where Depots/Sites have been given a non-contact Forehead Thermometer the following to be implemented. <ul style="list-style-type: none"> Testing must be carried out when operatives arrive on site and prior to any briefings/setting up the work site. Testing must be carried out on all who arrive on site including NWR Employees, AmcoGiffen SHEQ Team etc. Taking of temperatures will require the tester and the employee to wear the following PPE; FFP3 or FFP2 RPE, eye protection (goggles or face shield), nitrile gloves (or similar) beneath task gloves. The personnel involved should be briefed in the safe way to wear and remove RPE and gloves and the safe disposal of used PPE (see AmcoGiffen TBT 01-20 for guidance on this). Waste which relates to COVID-19, such as facemasks, gloves, and cleaning wipes, should be double bagged, labelled with the date & time and secured/isolated for 72 hours. The normal human body temperature range is typically stated as 36.5 – 37.5 °C 	AmcoGiffen Covid-19 Guidance	3				



Hazard	Hazard outcome	S	P	Initial risk	Risk control measures	AMCO Ref	Residual risk	Applicable Tasks			
								1	2	3	4
					<ul style="list-style-type: none"> If a temperature is tested at 37.8°C or more, action will be taken, and the individual will be asked to leave site or the workplace and seek further advice. (NHS online). The supervisor / tester is to inform their line manager if anyone has been asked to leave site. 						
Starting Works	Spread of Coronavirus causing: <ul style="list-style-type: none"> Mild Illness Severe illness Fatality 	3	3	9	<ul style="list-style-type: none"> Staggered starts should be used to reduce numbers congregating in the same place. The site supervisor is to undertake a hazard review on site prior to works commencing to ensure that the WPP and SWP are reflective of the conditions and hazards at site. This is to include walking routes to/from the site and at place of works. The NWR Slips & Trips form must be used prior to commencing works by the Site Supervisor to carry out their own assessment and to check against the Site Hazard Map. All information to be recorded on POWRA. Site Supervisor to brief any extra control measures and how they will be implemented and maintained. Brief outside where possible. Works are to be a min of 3m from nearest running line. 	AmcoGiffen Covid-19 Guidance	3				
Site Access Points & Briefings	Spread of Coronavirus causing: <ul style="list-style-type: none"> Mild Illness Severe illness 	3	3	9	Site to implement the following procedures: <ul style="list-style-type: none"> Stop all non-essential visitors. 	AmcoGiffen Covid-19 Guidance	3				



Network Rail Project No: 6381

AG Contract No: SCOAM18

Issue: 01

Revision Date: 30/03/22

Hazard	Hazard outcome	S	P	Initial risk	Risk control measures	AMCO Ref	Residual risk	Applicable Tasks			
								1	2	3	4
	<ul style="list-style-type: none"> Fatality 				<ul style="list-style-type: none"> Allow plenty of space (at least two metres) between people waiting to enter site. Require all workers to wash or sanitise their hands before entering or leaving the site. Reduce the number of people in attendance at site inductions and consider holding them outdoors wherever possible, keeping a distance of 2 metres between people. When briefing safety documentation, e.g. whiteboards and task briefs consider holding them outdoors wherever possible, keeping a distance of 2 metres between people. Use electronic methods for transferring documentation where possible. Do not collect and return paperwork in person unless an area for collecting and returning paperwork is unavailable and electronic transfer is not possible. Do not hand out the task brief, SWP, whiteboard brief or similar to the workforce to sign, but write in their name on their behalf. When scanning in sentinel cards ask the person to place the card on a surface so that it can be scanned safely and maintain 2 metres. Regularly clean common contact surfaces in office, access control and delivery areas e.g. scanners, turnstiles, screens, telephone handsets, and desks. 						



Network Rail Project No: 6381

AG Contract No: SCOAM18

Issue: 01

Revision Date: 30/03/22

Hazard	Hazard outcome	S	P	Initial risk	Risk control measures	AMCO Ref	Residual risk	Applicable Tasks			
								1	2	3	4
					<ul style="list-style-type: none"> Ensure there is a single drop off / collection point for deliveries. Delivery drivers should remain in their vehicles, if the load will allow it, and must wash or sanitise their hands before unloading goods and materials. When taking deliveries do not sign the delivery ticket but ask the delivery driver to sign on your behalf. 						
Operating small plant and tools	Spread of Coronavirus causing: <ul style="list-style-type: none"> Mild Illness Severe illness Fatality 	3	3	9	<ul style="list-style-type: none"> Operators must be trained and competent for the use of the plant/tools. Impact goggles/Face shield to be worn at all times. Wearing of gloves (cut 5/similar type) at all times. Inspect plant and equipment before use. Report faults to Supervisor. Take damaged plant out of use. Regularly cleaning of plant and tools once used (before and after each shift/use). Shared tools to be wiped down with bacterial wipes before use. Sanitise / wash hands. Avoid hand to face / mouth / nose / eyes touching. 	AmcoGiffen Covid-19 Guidance	3				



Hazard	Hazard outcome	S	P	Initial risk	Risk control measures	AMCO Ref	Residual risk	Applicable Tasks			
								1	2	3	4
					<ul style="list-style-type: none"> Sufficient hand washing and / or hand sanitising facilities to be available. 						
Poor Hygiene - vehicle	Spread of Coronavirus causing: <ul style="list-style-type: none"> Mild Illness Severe illness Fatality 	3	3	9	Enhanced cleaning procedures should be in place for service vehicles including: <ul style="list-style-type: none"> Dash board and steering wheel Use of seat covers – wiped down after each journey. Cleaning of the vehicle internally Cleaning of door handles – internal and external All rubbish should to be put straight in the bin All vehicles to be cleaned after each shift Cleaning of machinery and equipment being transported Regularly clean the inside of vehicle cabs and between use by different operators. 	AmcoGiffen Covid-19 Guidance	3				
Hygiene	Spread of Coronavirus causing: <ul style="list-style-type: none"> Mild Illness Severe illness Fatality 	3	3	9	Enhanced cleaning procedures to be in place, including regular cleaning of: <ul style="list-style-type: none"> Taps and washing facilities, toilet flush and seats. Door handles and push plates. Hand rails on staircases. 	AmcoGiffen Covid-19 Guidance	3				



Network Rail Project No: 6381

AG Contract No: SCOAM18

Issue: 01

Revision Date: 30/03/22

Hazard	Hazard outcome	S	P	Initial risk	Risk control measures	AMCO Ref	Residual risk	Applicable Tasks			
								1	2	3	4
					<ul style="list-style-type: none"> Machinery and equipment controls and shared tools. Vans and vehicles. All surfaces, particularly food preparation and eating surfaces. 						
Cleaning	Spread of Coronavirus causing: <ul style="list-style-type: none"> Mild Illness Severe illness Fatality 	3	3	9	Enhanced cleaning procedures to be in place, including regular cleaning of: <ul style="list-style-type: none"> Taps and washing facilities, toilet flush and seats. Door handles and push plates. Hand rails on staircases. Machinery and equipment controls and shared tools. Vans and vehicles. All surfaces, particularly food preparation and eating surfaces. Telephone equipment, keyboards, photocopiers and other office equipment. 	AmcoGiffen Covid-19 Guidance	3				
Mess / Eating Arrangements	Spread of Coronavirus causing: <ul style="list-style-type: none"> Mild Illness Severe illness Fatality 	3	3	9	The following to be implemented wherever possible: <ul style="list-style-type: none"> Break times staggered to reduce congestion and contact. 	AmcoGiffen Covid-19 Guidance	6				



Network Rail Project No: 6381

AG Contract No: SCOAM18

Issue: 01

Revision Date: 30/03/22

Hazard	Hazard outcome	S	P	Initial risk	Risk control measures	AMCO Ref	Residual risk	Applicable Tasks			
								1	2	3	4
					<ul style="list-style-type: none"> Depending on communal areas i.e. Kitchen, only permit two persons at any one time. Hand cleaning facilities or hand sanitiser should be available where people eat and should be used when entering and leaving the area. Everyone asked to bring pre-prepared meals and refillable drinking bottles from home. Everyone should sit 2 metres apart from each other whilst eating. Where food is provided on site, it should be pre-prepared and wrapped food only. Crockery, eating utensils, cups etc. should not be provided. Where equipment such as kettles, microwaves etc. are provided, they must be regularly cleaned. Drinking water facilities should have enhanced cleaning measures (e.g. tap handles disinfected). Tables should be cleaned between each use. Rubbish should be put straight in the bin and not left for someone else to clear up. 						



Network Rail Project No: 6381

AG Contract No: SCOAM18

Issue: 01

Revision Date: 30/03/22

Hazard	Hazard outcome	S	P	Initial risk	Risk control measures	AMCO Ref	Residual risk	Applicable Tasks			
								1	2	3	4
					<ul style="list-style-type: none"> Areas used for eating must be thoroughly cleaned at the end of each break / shift, e.g. chairs, door handles etc. 						
Changing Facilities, Showers and Drying Rooms	Spread of Coronavirus causing: <ul style="list-style-type: none"> Mild Illness Severe illness Fatality 	3	3	9	Regimes to be put into place to include: <ul style="list-style-type: none"> Ensure use of facilities complies with social distancing, including assessing a max number at any one time and brief workforce. Enhanced cleaning of all facilities throughout the day and at the end of each day. Increasing the number or size of facilities available on site if possible. Suitable and sufficient rubbish bins with regular removal and disposal. 	AmcoGiffen Covid-19 Guidance	6				
Toilet Facilities	Spread of Coronavirus causing: <ul style="list-style-type: none"> Mild Illness Severe illness Fatality 	3	3	9	<ul style="list-style-type: none"> The number of people using toilet facilities must be restricted to maintain 2 metres separation. Prevent use of every second cubical/urinal with a notice posted on the door advising maximum occupancy. Notices must be posted regarding hand washing or sanitising before and after using the facilities. Enhanced cleaning regimes must be implemented, particularly door handles, locks and the toilet flush. 						



Hazard	Hazard outcome	S	P	Initial risk	Risk control measures	AMCO Ref	Residual risk	Applicable Tasks			
								1	2	3	4
					<ul style="list-style-type: none"> Suitable, sufficient rubbish bins for hand towels must be provided with regular disposal. 						
Working within 2m of each other	Spread of Coronavirus causing: <ul style="list-style-type: none"> Mild Illness Severe illness Fatality 	4	3	12	<p>There will be situations where it is not possible or safe for workers to distance themselves from each other by 2 metres. Regimes to be put in place to include:</p> <ul style="list-style-type: none"> Non-essential physical work that requires close contact between workers should not be carried out. Work requiring skin to skin contact should not be carried out. Plan work to minimise contact between workers. Where it is not possible to maintain 2 metres distance for a particular task it is necessary to consider the following: <ol style="list-style-type: none"> Is the task "essential" – if 'yes' continue to next point, if 'no' refer to line management before progressing the task. Is the task "short duration" e.g. short bursts of a few minutes or fairly constant throughout the shift – if it is short duration consider alternative / additional controls, if it is most of the shift it should only progress in exceptional circumstances with Operations Director / SMOC agreement. 	AmcoGiffen Covid-19 Guidance	9				



Network Rail Project No: 6381

AG Contract No: SCOAM18

Issue: 01

Revision Date: 30/03/22

Hazard	Hazard outcome	S	P	Initial risk	Risk control measures	AMCO Ref	Residual risk	Applicable Tasks			
								1	2	3	4
					<p>c. Where essential short duration work is required to be undertaken within 2 metres this will require a specific local risk assessment along with additional PPE comprising FFP3 or FFP2 RPE, eye protection (goggles or face shield), nitrile gloves (or similar) beneath task gloves. The personnel involved should be briefed in the safe way to wear and remove RPE and gloves and the safe disposal of used PPE (see AmcoGiffen TBT 01-20 for guidance on this).</p> <ul style="list-style-type: none"> Waste which relates to COVID-19, such as facemasks, gloves, and cleaning wipes, should be double bagged, labelled with the date & time and secured/isolated for 72 hours. <p>Where lifts or hoists must be used:</p> <ul style="list-style-type: none"> Lower their capacity to reduce congestion and contact at all times. Regularly clean touchpoints, doors/gates, controls, buttons etc. 						



Hazard	Hazard outcome	S	P	Initial risk	Risk control measures	AMCO Ref	Residual risk	Applicable Tasks			
								1	2	3	4
PPE	Spread of Coronavirus causing: <ul style="list-style-type: none"> Mild Illness Severe illness Fatality 	3	3	9	<ul style="list-style-type: none"> Re-usable PPE should be thoroughly cleaned after use and not shared between workers. Single use PPE should be disposed of so that it cannot be reused. Contaminated/Disposal of PPE should be double bagged, labelled with the date & time and secured/isolated for 72 hours. These can then be disposed of as general waste. 	AmcoGiffen Covid-19 Guidance	6				
Operatives feeling unwell/showing signs of COVID-19 prior/during works	Spread of Coronavirus causing: <ul style="list-style-type: none"> Mild Illness Severe illness Fatality 	5	3	15	<ul style="list-style-type: none"> If a worker develops a high temperature or a persistent cough while at work, they should: Report all symptoms immediately to their lead/supervisor/manager maintaining minimum 2m (360 degrees) separation. Return home immediately. Avoid touching anything. Cough or sneeze into a tissue and put it in a bin, or if they do not have tissues, cough and sneeze into the crook of their elbow. They must then follow the guidance on self-isolation and not return to work until their period of self-isolation has been completed. 	AmcoGiffen Covid-19 Guidance	3				
Minor injury requiring first aid.	Spread of Coronavirus causing: <ul style="list-style-type: none"> Mild Illness Severe illness Fatality 	3	3	9	<ul style="list-style-type: none"> IP to self-treat with first aider present and remaining 2m away always. First Aid kit to be wiped down with bacterial wipes and passed to IP. First Aider to wear surgical gloves and face mask. All first aid equipment used to be wiped down with bacterial wipes. 	AmcoGiffen Covid-19 Guidance	3				



Network Rail Project No: 6381

AG Contract No: SCOAM18

Issue: 01

Revision Date: 30/03/22

Hazard	Hazard outcome	S	P	Initial risk	Risk control measures	AMCO Ref	Residual risk	Applicable Tasks			
								1	2	3	4
					<ul style="list-style-type: none"> Follow HS32 - Complaints, Accidents, Incidents, Rule Breaking and Non Conformance (CAIRN) Investigation and Reporting 						
Major injury requiring first aid.	Spread of Coronavirus causing: <ul style="list-style-type: none"> Mild Illness Severe illness Fatality 	4	3	12	<ul style="list-style-type: none"> First Aider to wear surgical gloves and face mask. All first aid equipment used to be wiped down with bacterial wipes. Follow HS32 - Complaints, Accidents, Incidents, Rule Breaking and Non Conformance (CAIRN) Investigation and Reporting Additional response measures to be planned if delays are anticipated with emergency services due to pressure from Coronavirus. 	AmcoGiffen Covid-19 Guidance	9				
Disposal of single use PPE and antibacterial wipes.	Spread of Coronavirus causing: <ul style="list-style-type: none"> Mild Illness Severe illness Fatality 	3	3	9	<ul style="list-style-type: none"> Contaminated/Disposal of PPE should be double bagged, labelled with the date & time and secured/isolated for 72 hours. These can then be disposed of as general waste. 	AmcoGiffen Covid-19 Guidance	3				



Appendix 2 – Manual handling control measures

Manual handling

Manual handling causes over a third of all workplace injuries. These include work-related musculoskeletal disorders (MSDs) such as pain and injuries to arms, legs and joints, and repetitive strain injuries of various sorts.

The term manual handling covers a wide variety of activities including lifting, lowering, pushing, pulling and carrying. If any of these tasks are not carried out appropriately there is a risk of injury.

Why is dealing with manual handling important?

Manual handling injuries can have serious implications for the employer and the person who has been injured. They can occur almost anywhere in the workplace and heavy manual labour, awkward postures, repetitive movements of arms, legs and back or previous/existing injury can increase the risk.

What do I have to do?

To help prevent manual handling injuries in the workplace, you should avoid such tasks as far as possible. However, where it is not possible to avoid handling a load, employers must look at the risks of that task and put sensible health and safety measures in place to prevent and avoid injury.

For any lifting activity

Always take into account:

- individual capability
- the nature of the load
- environmental conditions
- training
- work organisation

If you need to lift something manually

- Reduce the amount of twisting, stooping and reaching
- Avoid lifting from floor level or above shoulder height, especially heavy loads
- Adjust storage areas to minimise the need to carry out such movements
- Consider how you can minimise carrying distances
- Assess the weight to be carried and whether the worker can move the load safely or needs any help – maybe the load can be broken down to smaller, lighter components

If you need to use lifting equipment

- Consider whether you can use a lifting aid, such as a forklift truck, electric or hand-powered hoist, or a conveyor
- Think about storage as part of the delivery process – maybe heavy items could be delivered directly, or closer, to the storage area
- Reduce carrying distances where possible



Good handling technique for lifting

There are some simple things to do before and during the lift/carry:

- Remove obstructions from the route.
- Keep the load close to the waist. The load should be kept close to the body for as long as possible while lifting.
- Keep the heaviest side of the load next to the body.
- Adopt a stable position and make sure your feet are apart, with one leg slightly forward to maintain balance

Think before lifting/handling.

Plan the lift. Can handling aids be used? Where is the load going to be placed? Will help be needed with the load? Remove obstructions such as discarded wrapping materials. For a long lift, consider resting the load midway on a table or bench to change grip.

Adopt a stable position.

The feet should be apart with one leg slightly forward to maintain balance (alongside the load, if it is on the ground). Be prepared to move your feet during the lift to maintain your stability. Avoid tight clothing or unsuitable footwear, which may make this difficult.

Get a good hold.

Where possible, the load should be hugged as close as possible to the body. This may be better than gripping it tightly with hands only.

Start in a good posture.

At the start of the lift, slight bending of the back, hips and knees is preferable to fully flexing the back (stooping) or fully flexing the hips and knees (squatting).

Don't flex the back any further while lifting.

This can happen if the legs begin to straighten before starting to raise the load.

Keep the load close to the waist.

Keep the load close to the body for as long as possible while lifting. Keep the heaviest side of the load next to the body. If a close approach to the load is not possible, try to slide it towards the body before attempting to lift it.

Avoid twisting the back or leaning sideways, especially while the back is bent.

Shoulders should be kept level and facing in the same direction as the hips. Turning by moving the feet is better than twisting and lifting at the same time.

Keep the head up when handling.

Look ahead, not down at the load, once it has been held securely.

Move smoothly.

The load should not be jerked or snatched as this can make it harder to keep control and can increase the risk of injury.



Don't lift or handle more than can be easily managed.

There is a difference between what people can lift and what they can safely lift. If in doubt, seek advice or get help.

Put down, then adjust.

If precise positioning of the load is necessary, put it down first, then slide it into the desired position.



Works Delivery Scotland - Slip Trip & Fall Map

Good Practice Guide

General Guidance

- Workplace conditions change frequently and this leads to unidentified hazards appearing
- Regular and repeated identification of hazards specific to a site and the subsequent briefing of these issues is advantageous to site safety and will reduce the impact of such hazards.

Pre - Site Inspections

- Pre-site inspections present an ideal opportunity for the identification of hazards and provide the potential for the removal of anything that presents a STF hazard.
- Hazards identified should be listed above, so that an appropriate control measure is undertaken and briefed to the workforce on site.

Access Points

- Are they fit for purpose, look for
- Damaged / Missing steps & handrails
- Are they free from vegetation
- What lighting is required to illuminate them

Scrap Management at Depots / Access pts / On site

Is there a need to

- Demarcate the area by fencing
- Highlight the area e.g. additional lighting / painting
- Remove excess or discarded materials
- Remove fly tipped materials

Walking routes

- Are they free from vegetation?
- What lighting is required to illuminate them

Work Impact on walking / working surfaces

- What waste will be produced – where will this be stored – workforce been briefed
- Tools and equipment to be used returned to bogey (storage area)
- Work area illuminated prior to work commencing
- Trailing cables from lighting generators etc.
- Lineside furniture – S & T/OHL bonds/cables – AWS Magnets
- Catch pit lids – are they marked – lid secure – not damaged – require to be fenced off.
- Troughing lids secure – not left as a hazard on site
- UTX chambers – secured – marked
- Test holes – on site – to be filled - marked
- Rails left on site - can they be moved - relocated
- High ballast shoulders
- Wildlife – rabbit holes
- Open drains marked on site
- Lifting / moving equipment – team lifting – 1 x person to control the lift – check area
- and route moving equipment is to take to ensure it is free from hazards that could be moved, workforce briefed on others

Weather

- How the weather may affect the conditions at the access and worksite.
- Snow & Ice - removal from access points - grit and shovels available
- PPE required – wellingtons – ice grips – use



Works Delivery Scotland - Slip Trip & Fall Map

Name		Date
Risk Mapping Diagram		
Workplace / Location		
Key	Hazard	Controls
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		