

Source Emissions Testing – Spring Round 2015



Prepared for:

Northern Pulp Nova Scotia Corporation
P.O. Box 549, Station Main
New Glasgow, NS B2H 5E8

Prepared by:

Stantec Consulting Ltd.
102-40 Highfield Park Drive
Dartmouth, NS B3A 0A3

File: 121413456

August 17, 2015

TABLE OF CONTENTS

EXECUTIVE SUMMARY	III
1.0 INTRODUCTION	1
2.0 OVERALL APPROACH	1
2.1 SUBMISSION OF PRE-TEST PLAN	2
2.2 ON-SITE SOURCE EMISSIONS TESTING	2
2.3 LABORATORY ANALYSIS	3
2.4 INFORMATION REVIEW AND REPORTING	3
3.0 TEST METHODS, EQUIPMENT, AND CALIBRATIONS	3
3.1 SAMPLING PROCEDURES AND EQUIPMENT	3
3.1.1 Total Particulate Matter	3
3.1.2 Combustion Gases	6
3.1.3 Total Reduced Sulphur	6
3.2 QUALITY ASSURANCE AND QUALITY CONTROL	7
4.0 RESULTS AND DISCUSSION	8
4.1 EXHAUST STACK SAMPLE LOCATION DETAILS	8
4.2 LIME KILN	8
4.3 RECOVERY BOILER	11
4.4 SMELT DISSOLVING TANK	12
4.5 POWER BOILER	14
4.6 HIGH LEVEL ROOF VENT	16
4.7 SUMMARY OF RESULTS	17
5.0 CLOSURE	17

LIST OF TABLES

Table 1.1	Source Emissions Testing Matrix	iii
Table 1.2	Source Emissions Testing Results	iv
Table 2.1	Source Emissions Testing Matrix	2
Table 4.1	Sample Location Details	8
Table 4.2	Source Testing Results - Lime Kiln - Particulate Matter	9
Table 4.3	Source Testing Results - Lime Kiln - Combustion Gases	10
Table 4.4	Source Testing Results - Lime Kiln - Total Reduced Sulphur	10
Table 4.5	Source Testing Results - Recovery Boiler - Particulate Matter	11
Table 4.6	Source Testing Results - Recovery Boiler - Combustion Gases	12
Table 4.7	Source Testing Results - Smelt Dissolving Tank - Particulate Matter	12
Table 4.8	Source Testing Results - Smelt Dissolving Tank - Combustion Gases	13
Table 4.9	Source Testing Results - Dissolving Tank - Total Reduced Sulphur	14
Table 4.10	Source Testing Results - Power Boiler - Particulate Matter	14
Table 4.11	Source Testing Results - Power Boiler - Combustion Gases	15
Table 4.12	Source Testing Results - HLRV - Combustion Gases	16
Table 4.13	Source Testing Results - High Level Roof Vent - Total Reduced Sulphur	16

List of Figures

Figure 3.1	Particulate Matter Sampling Train Schematic Diagram	5
------------	---	---

List of Appendices

Appendix A	Pre-test Plan
Appendix B	Calibration Data
Appendix C	Field Data Sheets
Appendix D	Calculations

EXECUTIVE SUMMARY

Northern Pulp Nova Scotia Corporation, referred to herein as Northern Pulp, retained Stantec Consulting Ltd. to conduct source emissions testing at the Kraft pulp mill in New Glasgow, Nova Scotia. Source emissions testing was conducted on the Recovery Boiler, the Lime Kiln, the Smelt Dissolving Tank, the Power Boiler, and the High Level Roof Vent to fulfill the conditions specified in the current Certificate of Approval to Operate (CoA) 2011-076657-A01. The source emissions testing campaign was performed according to the pre-test plan submitted to the Nova Scotia Department of Environment, the United States Environmental Protection Agency Test Method 16B, under the Codes of Regulations (CFR) Part 60 Appendix A, Environment Canada's EPS 1/RM/8, and EPS 1/RM/15. The testing was conducted on April 28-29 and July 21-24, 2015.

In this report, source emissions testing data are presented for measurements which include combustion gases, total particulate matter (PM), total reduced sulphur (TRS) as well as exhaust gas temperature, exhaust flow rate, moisture content, velocity, and volumetric flow rate. The scope of work for the testing campaign is summarized in Table 1.1.

Table 1.1 Source Emissions Testing Matrix

Source	Number of Samples per Source	Approval Condition	Parameter	Sampling Method
Lime Kiln	3	6. a)	Total Particulate Matter (PM)	EPS 1/RM/8
	1	6. b)	Total Reduced Sulphur (TRS)	US EPA Method 16B/C
	3	-	Combustion Gases	EPS 1/RM/15
Recovery Boiler	3	6. a)	Total Particulate Matter (PM)	EPS 1/RM/8
	3	-	Combustion Gases	EPS 1/RM/15
Smelt Dissolving Tank	3	6. a)	Total Particulate Matter (PM)	EPS 1/RM/8
	3	-	Combustion Gases	EPS 1/RM/15
	1	6. b)	Total Reduced Sulphur (TRS)	US EPA Method 16B/C
Power Boiler	3	6. a)	Total Particulate Matter (PM)	EPS 1/RM/8
	3	-	Combustion Gases	EPS 1/RM/15
High Level Roof Vent	1	6. b)	Total Reduced Sulphur (TRS)	US EPA Method 16B/C
	3	-	Combustion Gases	EPS 1/RM/15

Currently there are specified regulatory limits in the facility's CoA for emissions of PM and/or TRS from four of the five exhaust stacks listed. The measured concentration of PM from the Lime Kiln, Smelt Dissolving Tank, Power Boiler, and Recovery Boiler were all below their respective regulatory stack limits. The maximum 4-hour rolling average concentration of TRS from the Lime Kiln was below the regulatory limit. No limit for TRS is specified for the High Level Roof Vent or the Dissolving Tank in the facility's approval. A summary of the results of the source emissions testing is provided in Table 1.2.

Table 1.2 Source Emissions Testing Results

Exhaust Gas Parameters	Recovery Boiler	Power Boiler	Lime Kiln	Sneft Dissolving Tank	HLRV
Total Particulate Matter – TPM (mg/Rm ³ at 11% O ₂)	3.81	148	-	-	-
Total Particulate Matter - TPM (kg/adubmt)	-	-	0.37	0.33	-
Total Reduced Sulphur - TRS (ppm dv)	-	-	6.30	ND	36.0
Sulphur Dioxide – SO ₂ (mg/Rm ³)	7.05	ND	4.38	ND	4.44
Nitrogen Oxides – NO _x (mg/Rm ³)	119	45.9	186	ND	35.8
Carbon Monoxide – CO (mg/Rm ³)	172	634	7.74	ND	158
Volumetric Flow Rate (Rm ³ /s)	77.1	39.4	7.42	3.78	30.9
Velocity (m/s)	12.9	19.9	11.2	7.80	-
Temperature (°C)	66.4	56	70.5	79	-
Moisture Content (%)	28.3	16.3	32.1	50.5	-
Oxygen - O ₂ (%)	6.23	15.4	4.47	20.9	-
Carbon Dioxide - CO ₂ (%)	8.53	3.0	22.5	0	-

1.0 INTRODUCTION

Northern Pulp Nova Scotia Corporation, referred to herein as Northern Pulp, retained Stantec Consulting Ltd. (Stantec) to conduct source emissions testing at the Kraft pulp mill in New Glasgow, Nova Scotia. Source emissions testing was conducted on the Recovery Boiler, the Lime Kiln, the Smelt Dissolving Tank, the Power Boiler, and the High Level Roof Vent to fulfill the conditions specified in the current Certificate of Approval to Operate (CoA) 2011-076657-A01. The source emissions testing campaign was performed according to the pre-test plan submitted to the Nova Scotia Department of Environment, the United States Environmental Protection Agency Test Method 16B, under the Codes of Regulations (CFR) Part 60 Appendix A, and the Environment Canada methods EPS 1/RM/8 and EPS 1/RM/15. The particulate matter and total reduced sulphur testing was conducted during the period of April 28-29 and July 21-24, 2015.

In this report, source emissions testing data are presented for combustion gases, total particulate matter (PM), total reduced sulphur (TRS), exhaust gas temperature, exhaust flow rate, moisture content, velocity, and volumetric flow rate. Source emissions testing were conducted on the following sources:

- Lime Kiln;
- Recovery Boiler;
- Smelt Dissolving Tank;
- Power Boiler; and
- High Level Roof Vent.

This report is in five sections. Section 1 contains the introduction and the scope of work for the project. The study approach and a brief description of the various parts of the project are in Section 2. Section 3 contains a brief description of the testing methodologies, equipment, and calibration techniques used during the source emissions testing program. In Section 4, the results of the source emissions testing are presented and discussed, and concluding remarks are presented in Section 5. Appendices A through E contain supporting information for the report.

2.0 OVERALL APPROACH

The project consisted of five parts:

1. Submission of the Pre-test Plan;
2. Site Preparation and Preliminary Survey;
3. On-site Source Emissions Testing;
4. Laboratory Analysis; and
5. Information Review and Reporting.

Each of these parts is described below.

2.1 SUBMISSION OF PRE-TEST PLAN

The on-site testing was conducted in accordance with the Pre-Test Plan (Appendix A) submitted on February 20, 2015 to Nova Scotia Environment (NSE). The Pre-Test Plan outlined the rationale for the selection of the associated contaminants to be tested, as well as the methodologies proposed for conducting the source testing on the exhaust stacks.

2.2 ON-SITE SOURCE EMISSIONS TESTING

Stantec set up the source emissions testing equipment and conducted a preliminary survey to measure the exhaust gas temperature, velocity, and flue gas composition in the five exhaust points. The data from this survey was used to determine the appropriate nozzle size to conduct isokinetic sampling (where the velocity of the gas entering the nozzle is equal to the gas velocity in the stack) for particulate matter during the source emissions testing part of the work.

Three (3) tests for total particulate matter were conducted at defined sampling locations on the exhaust stacks of the Recovery Boiler, the Lime Kiln, the Smelt Dissolving Tank, and the Power Boiler. Three tests for combustion gases were also conducted, near the centre of the exhaust stacks of the Recovery Boiler, the Lime Kiln, the Smelt Dissolving Tank, the Power Boiler and the High Level Roof Vent. All testing was completed in compliance with the sampling methods presented in Table 2.1, in accordance with the *Air Quality Regulation*, under the *Environment Act*, Section 112 issued by Nova Scotia Environment (NSE) and the requirements of the facility's approval (2011-076657-R03) issued by the NSE.

The source emissions testing of the Lime Kiln, Dissolving Tank and the High Level Roof Vent for total reduced sulphur (TRS) was conducted in accordance with US EPA Method 16B and the requirements of the facility's approval (2011-076657-R03) issued by NSE.

The methodologies used for testing the emissions from each exhaust stack are summarized in Table 2.1.

Table 2.1 Source Emissions Testing Matrix

Source	Number of Samples per Source	Approval Condition	Parameter	Sampling Method
Lime Kiln	3	6. a)	Total Particulate Matter (PM)	EPS 1/RM/8
	1	6. b)	Total Reduced Sulphur (TRS)	US EPA Method 16B/C
	3	-	Combustion Gases	EPS 1/RM/15
Recovery Boiler	3	6. a)	Total Particulate Matter (PM)	EPS 1/RM/8
	3	-	Combustion Gases	EPS 1/RM/15
	3	6. a)	Total Particulate Matter (PM)	EPS 1/RM/8
Smelt Dissolving Tank	3	-	Combustion Gases	EPS 1/RM/15
	1	6. b)	Total Reduced Sulphur (TRS)	US EPA Method 16B/C
	3	6. a)	Total Particulate Matter (PM)	EPS 1/RM/8
Power Boiler	3	-	Combustion Gases	EPS 1/RM/15
	3	6. a)	Total Particulate Matter (PM)	EPS 1/RM/8
	1	6. b)	Total Reduced Sulphur (TRS)	US EPA Method 16B/C
High Level Roof Vent	3	-	Combustion Gases	EPS 1/RM/15
	3	-	Combustion Gases	EPS 1/RM/15

In addition to the above testing (as required to meet the Approval conditions), the exhaust flow rate was determined for the High Level Roof Vent.

2.3 LABORATORY ANALYSIS

Prior to the particulate matter testing, several filters were conditioned and pre-weighed. Following the testing, particulate matter was recovered from the nozzle, the sampling probe and the in-line filter. Following testing the filter, containing the particulate sample, was conditioned and weighed, and the net weight of the collected particulate matter was determined. After each test, the probe and nozzle were rinsed with acetone and this acetone was collected, placed into a pre-weighed container and evaporated until dry. The amount of particulate for each part of the sample was determined gravimetrically, and the mass of particulate matter collected for each test was calculated as the sum of the particulate matter collected in the filter, probe, and nozzle rinse. The contents of the impingers were recovered gravimetrically for particulate matter and reported separately. These recoveries were performed at Stantec's laboratory in Fredericton, New Brunswick.

2.4 INFORMATION REVIEW AND REPORTING

The data collected in the field, along with data from the laboratory analyses, were entered into the Stantec's source emissions testing spreadsheets for analysis. Emissions calculations were then performed to produce the detailed source emissions testing information. Spreadsheet calculations were verified by hand, and numerous spot checks of spreadsheet formulas were conducted to confirm the accuracy of data. Summary tables were prepared and incorporated into this report for submission to Northern Pulp.

3.0 TEST METHODS, EQUIPMENT, AND CALIBRATIONS

This section contains a description of the methods and equipment used to conduct the source emissions testing campaign. The calibration procedures used to ensure the quality of the source emissions testing data are also summarized in this section.

3.1 SAMPLING PROCEDURES AND EQUIPMENT

The following sub-sections contain brief descriptions of the sampling equipment and methodologies used during the source emissions testing campaign.

3.1.1 Total Particulate Matter

Particulate matter emissions from the four exhaust stacks (Recovery Boiler, Lime Kiln, Smelt Dissolving Tank, and Power Boiler) were measured in accordance with the Environment Canada Reference Method EPS 1/RM/8, entitled *Reference Methods for Source Testing: Measurement of Releases of Particulate from Stationary Sources*.

The sampling train, used specifically for isokinetic sampling of particulate matter, is described in detail in EPS 1/RM/8, and is generally referred to as the 'Method 5' sampling train for particulate matter, named after the United States Environmental Protection Agency (US EPA) protocol. The sampling train consists of several different components which include: a heated sampling probe (a nozzle, stainless steel liner,

thermocouple, and pitot tube assembly), a heated sample case containing a filter, an ice box containing impinger glassware, and an umbilical cord leading to the pump and control console. A schematic of the sampling system is shown in Figure 3.1. The operation of the Method 5 sampling train can be generally described as follows.

Exhaust gases are drawn through the probe nozzle at or near isokinetic conditions (*i.e.*, where the gas velocity in the nozzle is at the same velocity as the gas in the stack). The gases are then drawn through the inner stainless steel liner of the electrically heated sampling probe to the other components of the sampling train.

A pitot tube assembly is attached to the probe next to the nozzle to measure the exhaust gas velocity in the area of the probe nozzle. Using the differential pressure reading on the control console, the desired nozzle flow rate is determined from the differential pressure across a calibrated orifice.


The exhaust gases are drawn from the probe liner through a pre-weighed glass fiber filter, in the hot side of the sampling unit, and then through pre-weighed impingers in an ice bath to cool the gases and condense the moisture in the gas, before the gas enters the umbilical cord.

The umbilical cord carries the filtered, cooled exhaust gases from the sampling site to the control console. The control console contains a fiber vane vacuum pump, which is used to draw the exhaust gases through the sampling train. A calibrated dry gas meter records the volume of gas sampled.

After completion of testing, the impingers are re-weighed, with the difference in mass corresponding to the mass of water collected. This measurement is used to calculate the moisture content of the exhaust gas.

Total particulate matter is determined gravimetrically at Stantec's laboratory in Fredericton, New Brunswick.

Appendix B contains the calibration data.



**SOURCE EMISSIONS TESTING
METHOD 5 SAMPLING TRAIN**

Scale:	N.T.S.
Fig. No:	3.1

3.1.2 Combustion Gases

The combustion gases (O_2 , CO_2 , CO , NO_x , and SO_2) were sampled according to the Environment Canada reference method EPS 1/RM/15, entitled *Reference Method for the Monitoring of Gaseous Emissions from Fossil Fuel-fired Burners*. In this method, samples of flue gas are drawn through a probe, non-isokinetically, from a single point near the centre of the stack. The combustion gases were analyzed using a Testo 350 XL Flue Gas Analyzer manufactured by Testo GmbH and Co. This unit is equipped with electrochemical cells that are used to measure the concentrations of oxygen, carbon dioxide, sulphur dioxide, nitrogen oxides, carbon monoxide, and total hydrocarbons, in accordance with EPS 1/RM/15. The system is equipped with a flue gas probe that has an integrated filter trap and condensate trap and a housing unit that contains the pump and the electrochemical cells. The equipment is manufactured and calibrated to ensure high accuracy.

The concentrations and emission rates of oxygen, carbon dioxide, and SO_2 were measured continuously from the Lime Kiln, Dissolving Tank and the High Level Roof Vent during total reduced sulphur measurements in accordance with the following US EPA protocols for source emissions testing.

Carbon Dioxide (CO_2) and Oxygen (O_2): Carbon dioxide and oxygen are analyzed according to the US EPA Method 3A, entitled *Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources (Instrumental Analyzer Procedure)*. In this method, a sample of stack gas is continuously extracted from the effluent stream at a single point near the centre of the stack through a heated filter and sample line. A portion of the sample is distributed to a paramagnetic analyzer for the determination of oxygen concentration, and to a Luff-type non-dispersive infrared (NDIR) analyzer or equivalent for the determination of carbon dioxide concentration.

Sulphur Dioxide (SO_2): Sulphur dioxide is analyzed according to the US EPA Method 6C, entitled *Determination of Sulphur Dioxide Emissions from Stationary Sources (Instrumental Analyzer Procedure)*. In this method, a sample of stack gas is continuously extracted from the effluent stream at a single point near the centre of the stack through a heated filter and sample line. A portion of the sample is distributed to an instrumental ultraviolet (UV) analyzer for the determination of SO_2 concentration.

3.1.3 Total Reduced Sulphur

The source emissions testing of the Lime Kiln and the High Level Roof Vent for total reduced sulphur was conducted in accordance with US EPA Method 16B, entitled *Determination of Total Reduced Sulfur Emissions from Stationary Sources* and US EPA Method 16C (*real-time data*).

Method 16C uses the sampling procedures of Method 16A/B and the analytical procedures of Method 6C (for SO_2 analysis) to measure TRS. Total reduced sulfur is defined as hydrogen sulfide, methyl mercaptan, dimethyl sulfide, and dimethyl disulfide (reported as H_2S). As in Method 16A and B, the sample is collected from the source through a heated probe. Stantec modified Method 16 by omitting the citrate buffer scrubber. The citrate buffer scrubber is used to remove SO_2 from the gas stream prior to the oxidizing oven. This modification was done to facilitate 24-hour sampling as removal of SO_2 using the scrubber requires frequent stops and starts and checks on the buffer to ensure the buffer does not become saturated. This modification thus improves the accuracy of sampling over using the buffer.

The sample is extracted from the exhaust gas of the stack through a heated Teflon line and directed through a first SO₂ analyzer (non-dispersive ultra-violet (NDUV) continuous analyzer) to confirm SO₂ present prior to the oven. The sample is then directed through an oven to thermally oxidize any reduced sulphur compounds to SO₂. Following oxidation of the sample, the exhaust gas from the oven is drawn through a second SO₂ non-dispersive ultra-violet (NDUV) continuous analyzer to analyze the gas for SO₂. The concentration of Total Reduced Sulphur (TRS) is then calculated by subtracting any SO₂ measured in the gas prior to oxidation (measured via the first SO₂ analyzer prior to the oven) from the total SO₂ present after the oxidation oven. Monitoring was conducted continuously over a 24-hour period on each source.

3.2 QUALITY ASSURANCE AND QUALITY CONTROL

Throughout the source emissions testing program, quality assurance and quality control procedures were applied to confirm the accuracy of the accurate emissions data. These checks were performed by test personnel throughout the program under the guidance of the source testing crew chief in the field and the project manager during post testing review.

The quality control (QC) checks included the following:

- use of standardized checklists and field notebooks to ensure completeness, traceability, and comparability of the process information and samples collected;
- field checking of standardized forms by a second person to confirm completeness;
- testing for cyclonic or reverse flow, as well as stratified flow conditions; and
- leak checks of sampling trains

Equipment was calibrated according to the protocols and schedule as prescribed by Environment Canada. These calibrations include the following:

Pitots: Calibrated in a wind tunnel with probe and nozzles attached.

Gas meters: Calibrated using a critical orifice calibration set.

Nozzle: Four diameter measurements made using a micrometer across the sharpened edges.

Thermocouples: Calibrated using a potentiometric technique.

Gas Analyzer: Calibrated against reference gases using standard calibration gases within the expected range of concentrations from the source.

Calibration data are in Appendix B of this report.

4.0 RESULTS AND DISCUSSION

The results of the source emissions testing campaigns are provided and discussed in this section.

Appendices B through D contain supporting information including calibration information, field data sheets, and calculations.

4.1 EXHAUST STACK SAMPLE LOCATION DETAILS

Table 4.1 provides a summary of the sample location details for each exhaust stack sampled.

Table 4.1 Sample Location Details

Parameter	Recovery Boiler	Lime Kiln	Smelt Dissolving Tank	Power Boiler	High Level Roof Vent
Stack Height – Above Grade (m)	69	37	51	51	65
Diameter / Equivalent Diameter (m)	3.51	1.22	1.22	1.93	1.83
Stack/Duct Description	Circular	Circular	Circular	Circular	Circular
Stack Orientation	Vertical	Vertical	Vertical	Vertical	Vertical
Number of Sample Ports	4	2	2	2	1
Sample Port Diameter (m)	0.1	0.15	0.1	0.1	0.1
Location Upstream from any Disturbance,	>2	2	>2	>2	-
Location Downstream from any Disturbance,	1.45	8	6	>4	-
Ideal or Non Ideal Flow Characteristics at The Sample Location ¹	Not Ideal	Not Ideal ²	Not Ideal	Not Ideal	-
Total Number of Sample Points	24	24	20	24	1
Number of Sample Points per Traverse	12	12	10	12	NA
Sample Time per Point (min)	5	5	5	5	NA
Sample time per Test for PM (min)	120	120	100	120	NA
Sample time per Test for TRS (min)	NA	1,440	1,440	NA	1,440
Notes:					
¹ The exhaust gas flow characteristics at the sampling location are referred to as being "Ideal" if the sample ports are located in a straight section of stack at least eight stack diameters downstream and two stack diameters upstream of any flow disturbance.					
² The Lime Kiln sampling location is not ideal due to the cyclonic flow.					

4.2 LIME KILN

The results of the source emissions testing for total particulate matter from the Lime Kiln exhaust stack are in Table 4.2. The results of the source emissions testing for combustion gases and total reduced sulphur are in Tables 4.3 and 4.4, respectively.

Table 4.2 Source Testing Results - Lime Kiln - Particulate Matter

Parameter	Test #1	Test #2	Test #3	Average	Stack Emission Limit (Table 1 of Approval)
Test Date	July 21, 2015	July 22, 2015	July 22, 2015	-	-
Test Start time	09:05	14:00	17:10	-	-
Test Duration (min)	120	120	120	120	-
Volume of Gas Sampled (Rm ³)	0.89	0.76	0.80	0.82	-
Average Isokineticity (%)	108	108	102	106	-
Total Volume of Moisture Collected in Impingers (mL)	359	251	250	286	-
Particulate Matter From Filter and Probe Wash (mg)	285	389	255	310	-
Particulate Matter From Impingers (mg)	20.5	3.3	3.5	9.1	-
Plant Production (adubmt/day)	596	701	701	666	-
Exhaust Gas Parameters					
Exhaust Gas Temperature (°C)	71.1	70.0	70.6	70.5	-
Exhaust Gas Moisture Content (%)	35.5	30.9	29.9	32.1	-
Exhaust Gas Velocity (m/s)	12.1	10.7	10.9	11.2	-
Exhaust Gas Volumetric Flow Rate (Rm ³ /s)	7.86	7.41	7.67	7.64	-
Oxygen - O ₂ (%)	4.64	4.59	4.2	4.47	-
Carbon Dioxide - CO ₂ (%)	22.1	22.5	23.0	22.5	-
Total Particulate Matter - PM					
Concentration at 11% O ₂ (mg/Rm ³)	322	510	320	384	-
Emission Rate (g/s)	2.46	3.67	2.37	2.83	-
Emission metric (kg/adubmt)	0.36	0.45	0.29	0.37	0.50
Legend:					
°C Degrees Celsius.					
m/s Metres per second.					
Rm ³ /s Dry cubic metres per second at reference conditions (25°C and 101.3 kPa).					
mg/Rm ³ Milligrams per dry cubic metre at reference conditions (25°C and 101.3 kPa).					
kg/hr Kilograms per hour.					
adubmt Reference production rate in air dried unbleached metric tonnes.					

The average measured emission rate of particulate matter was 0.37 kg/adubmt, which is below the stack emission limit of 0.50 kg/adubmt presented in Table 5 of the facility's Approval (No. 2011-076657-A01).

It should be noted that, as with previous testing, cyclonic flow is present at the sampling location for this source. Sampling was conducted following the angle adjustment approach with the cosine correction applied, as per the US EPA Guidance Document – GD-008.

Table 4.3 Source Testing Results - Lime Kiln - Combustion Gases

Parameter	Test #1	Test #2	Test #3	Average
Test Date	April 29, 2015	April 29, 2015	April 29, 2015	-
Test Duration (min)	60	60	60	60
Exhaust Gas Volumetric Flow Rate (Rm ³ /s)	7.64	7.20	7.42	7.42
Sulphur Dioxide - SO₂				
Concentration (ppm)	1.68	1.67	1.67	1.67
Concentration (mg/Rm ³)	4.41	4.37	4.37	4.38
Emissions Rate (kg/hr)	0.12	0.11	0.12	0.12
Nitrogen Oxides - NO_x*				
Concentration (ppm)	117	131	47.9	98.7
Concentration (mg/Rm ³)	220	247	90.1	186
Emissions Rate (kg/hr)	6.05	6.41	2.41	4.95
Carbon Monoxide - CO				
Concentration (ppm)	6.93	6.78	6.57	6.76
Concentration (mg/Rm ³)	7.94	7.76	7.52	7.74
Emissions Rate (kg/hr)	0.22	0.20	0.20	0.21
Legend:				
Rm ³ /s	Dry cubic metres per second at reference conditions (25°C and 101.3 kPa) based on average of PM test measurements.			
mg/Rm ³	Milligrams per dry cubic metre at reference conditions (25°C and 101.3 kPa).			
kg/hr	Kilograms per hour.			
ND	Not detected.			
*	NO _x concentration was measured during the particulate matter testing while other gases were measured during the TRS sampling period.			

The average emission rates for SO₂, NO_x, and CO for the Lime Kiln were 0.12 kg/hr, 4.95 kg/hr and 0.21 kg/hr, respectively.

Table 4.4 Source Testing Results – Lime Kiln – Total Reduced Sulphur

Parameter	24-hour TRS Monitoring	Stack Emission Limit (Table 1 of Approval)
Test Start	April 29, 2015 08:25	-
Test Finish	April 30, 2015 08:25	-
Average exhaust gas concentration (ppm dv)	6.30	-
Maximum 4-hour rolling average exhaust gas concentration (ppm dv)	11.7	20
Legend:		
ppm dv Parts per million, dry volume.		

The maximum 4-hour rolling average observed during the testing was 11.7 ppm (dry basis), which is below the stack emission limit of 20 ppm presented in Table 5 of the facility's Approval (No. 2011-076657-A01).

4.3 RECOVERY BOILER

The results of the source emissions testing for total particulate matter and combustion gases from the Recovery Boiler exhaust stack are in Tables 4.5 and 4.6, respectively.

Table 4.5 Source Testing Results - Recovery Boiler - Particulate Matter

Parameter	Test #1	Test #2	Test #3	Average	Stack Emission Limit (Table 1 of Approval)
Test Date	July 23, 2015	July 23, 2015	July 24, 2015	-	-
Test Start	09:45	13:20	08:12	-	-
Test Duration (min)	120	120	120	120	-
Volume of Gas Sampled (Rm ³)	1.42	1.58	1.87	1.62	-
Average Isokineticity (%)	96.9	101	107	102	-
Total Volume of Moisture Collected in Impingers (mL)	393	443	587	474	-
Particulate Matter From Filter and Probe Wash (mg)	15.5	8.58	0.20	8.08	-
Particulate Matter From Impingers (mg)	1.50	1.04	1.47	1.34	-
Exhaust Gas Parameters					
Exhaust Gas Temperature (°C)	65.5	65.5	68.1	66.4	-
Exhaust Gas Moisture Content (%)	27.4	27.6	29.9	28.3	-
Exhaust Gas Velocity (m/s)	11.8	12.7	14.3	12.9	-
Exhaust Gas Volumetric Flow Rate (Rm ³ /s)	70.7	76.2	84.5	77.1	-
Oxygen - O ₂ (%)	6.72	6.64	5.31	6.23	-
Carbon Dioxide - CO ₂ (%)	7.97	8.02	9.59	8.53	-
Total Particulate Matter - PM Concentration at 11% O ₂ (mg/Rm ³)	7.61	3.76	0.07	3.81	77
Emission Rate (g/s)	0.77	0.41	0.01	0.40	-
Legend:					
°C Degrees Celsius.					
m/s Metres per second.					
Rm ³ /s Dry cubic metres per second at reference conditions (25°C and 101.3 kPa).					
mg/Rm ³ Milligrams per dry cubic metre at reference conditions (25°C and 101.3 kPa).					
kg/hr Kilograms per hour.					

The average measured concentration of particulate matter was 3.81 mg/Rm³ (corrected to 11% O₂), which is below the current stack emission limit of 77 mg/Rm³ presented in Table 5 of the facility's Approval (No. 2011-076657-A01).

Table 4.6 Source Testing Results - Recovery Boiler - Combustion Gases

Parameter	Test #1	Test #2	Test #3	Average
Test Date	July 23, 2015	July 23, 2015	July 24, 2015	-
Test Duration (min)	30	30	30	30
Exhaust Gas Volumetric Flow Rate (Rm ³ /s)	70.7	76.2	84.5	77.1
<u>Sulphur Dioxide - SO₂</u>				
Concentration (ppm)	2.71	4.71	4.57	4.00
Concentration (mg/Rm ³)	4.97	8.58	7.61	7.05
Emissions Rate (kg/hr)	1.81	3.39	3.64	2.95
<u>Nitrogen Oxides - NO_x</u>				
Concentration (ppm)	66.6	63.1	59.4	63.0
Concentration (mg/Rm ³)	125	119	112	119
Emissions Rate (kg/hr)	31.9	32.6	34.0	32.8
<u>Carbon Monoxide - CO</u>				
Concentration (ppm)	96.1	120	236	151
Concentration (mg/Rm ³)	110	137	270	172
Emissions Rate (kg/hr)	28.0	37.6	82.0	49.2
Legend:				
Rm ³ /s Dry cubic metres per second at reference conditions (25°C and 101.3 kPa).				
mg/Rm ³ Milligrams per dry cubic metre at reference conditions (25°C and 101.3 kPa).				
kg/hr Kilograms per hour.				

The emission rates for SO₂, NO_x and CO for the Recovery Boiler were 2.95 kg/hr, 32.8 kg/hr, and 49.2 kg/hr, respectively.

4.4 SMELT DISSOLVING TANK

The results of the source emissions testing for total particulate matter from the Smelt Dissolving Tank exhaust stack are in Table 4.7. The results of the source emissions testing for combustion gases and total reduced sulphur are in Tables 4.8 and 4.9, respectively.

Table 4.7 Source Testing Results - Smelt Dissolving Tank - Particulate Matter

Parameter	Test #1	Test #2	Test #3	Average	Stack Emission Limit (Table 1 of Approval)
Test Date	July 21, 2015	July 22, 2015	July 22, 2015	-	-
Test Start	09:00	12:45	15:55	-	-
Test Duration (min)	100	100	100	100	-
Volume of Gas Sampled (Rm ³)	0.92	0.81	0.86	0.86	-
Average Isokineticity (%)	91.1	97.4	93.2	93.9	-
Total Volume of Moisture Collected in Impingers (mL)	695	642	610	649	-
Particulate Matter From Filter and Probe Wash (mg)	438	770	533	581	-
Particulate Matter From Impingers (mg)	29.4	21.8	13.7	21.7	-

Table 4.7 Source Testing Results - Smelt Dissolving Tank - Particulate Matter

Parameter	Test #1	Test #2	Test #3	Average	Stack Emission Limit (Table 1 of Approval)
Pulp Production (adubmt/day)	596	701	701	666	-
Exhaust Gas Parameters					
Exhaust Gas Temperature (°C)	77	83	78	79	-
Exhaust Gas Moisture Content (%)	50.5	51.8	49.2	50.5	-
Exhaust Gas Velocity (m/s)	8.53	7.28	7.59	7.80	-
Exhaust Gas Volumetric Flow Rate (Rm ³ /s)	4.16	3.42	3.77	3.78	-
Oxygen - O ₂ (%)	20.9	20.9	20.9	20.9	-
Carbon Dioxide - CO ₂ (%)	0.0	0.0	0.0	0.0	-
Total Particulate Matter - PM					
Concentration (mg/Rm ³)	474	951	622	682	-
Emission Rate (g/s)	1.97	3.25	8.44	9.08	-
Emission metric (kg/adubmt)	0.29	0.40	0.29	0.33	0.50
Legend:					
°C Degrees Celsius.					
m/s Metres per second.					
Rm ³ /s Dry cubic metres per second at reference conditions (25°C and 101.3 kPa).					
mg/Rm ³ Milligrams per dry cubic metre at reference conditions (25°C and 101.3 kPa).					
kg/hr Kilograms per hour.					
adubmt Reference production rate in air dried unbleached metric tonnes.					

The average measured emission rate of particulate matter was 0.33 kg/adubmt, which is below the stack emission limit of 0.50 kg/adubmt presented in Table 5 of the facility's Approval (No. 2011-076657-A01).

Table 4.8 Source Testing Results - Smelt Dissolving Tank - Combustion Gases

Parameter	Test #1	Test #2	Test #3	Average
Test Date	July 21, 2015	July 22, 2015	July 22, 2015	-
Test Duration (min)	30	30	30	30
Exhaust Gas Volumetric Flow Rate (Rm ³ /s)	4.16	3.42	3.77	3.78
Sulphur Dioxide - SO₂				
Concentration (ppm)	ND	ND	ND	ND
Concentration (mg/Rm ³)	ND	ND	ND	ND
Emissions Rate (kg/hr)	ND	ND	ND	ND
Nitrogen Oxides - NO_x				
Concentration (ppm)	ND	ND	ND	ND
Concentration (mg/Rm ³)	ND	ND	ND	ND
Emissions Rate (kg/hr)	ND	ND	ND	ND
Carbon Monoxide - CO				
Concentration (ppm)	ND	ND	ND	ND
Concentration (mg/Rm ³)	ND	ND	ND	ND

Table 4.8 Source Testing Results - Smelt Dissolving Tank - Combustion Gases

Parameter	Test #1	Test #2	Test #3	Average
Emissions Rate (kg/hr)	ND	ND	ND	ND
Legend:				
Rm ³ /s Dry cubic metres per second at reference conditions (25°C and 101.3 kPa).				
mg/Rm ³ Milligrams per dry cubic metre at reference conditions (25°C and 101.3 kPa).				
kg/hr Kilograms per hour.				
ND Not detected.				

Sulphur dioxide, nitrogen oxides, and carbon monoxide were not detected from the smelt dissolving tank.

Table 4.9 Source Testing Results – Dissolving Tank – Total Reduced Sulphur

Parameter	24-hour TRS Monitoring	Stack Emission Limit (Table 1 of Approval)
Test Start	April 28, 2015 17:40	-
Test Finish	April 29, 2015 17:40	-
Average exhaust gas concentration (ppm dv)	ND	nl
Maximum 4-hour rolling average exhaust gas concentration (ppm dv)	3.82	nl
Legend:		
ppm dv Parts per million, dry volume.		
nl No limit established.		
ND not detected		

The average TRS measured was below the detection limit of the sampling system. The maximum 4-hour rolling average observed during the testing was 3.82 ppm (dry basis). There is no stack emission limit specified in the facility's Approval (No. 2011-076657-A01).

4.5 POWER BOILER

The results of the source emissions testing for total particulate matter and combustion gases from the Power Boiler exhaust stack are in Tables 4.10 and 4.11, respectively.

Table 4.10 Source Testing Results - Power Boiler - Particulate Matter

Parameter	Test #1	Test #2	Test #3	Average	Stack Emission Limit (Table 1 of Approval)
Test Date	July 23, 2015	July 23, 2015	July 24, 2015	-	-
Test Start	09:42	13:25	08:00	-	-
Test Duration (min)	120	120	120	120	-
Volume of Gas Sampled (Rm ³)	1.62	1.63	1.61	1.62	-
Average Isokineticity (%)	98.6	101	101	100	-
Total Volume of Moisture Collected in Impingers (mL)	204	258	238	233	-
Particulate Matter From Filter and Probe Wash (mg)	97.2	97.3	208	134	-

Table 4.10 Source Testing Results - Power Boiler - Particulate Matter

Parameter	Test #1	Test #2	Test #3	Average	Stack Emission Limit (Table 1 of Approval)
Particulate Matter From Impingers (mg)	23.7	1.2	3.7	9.5	
Exhaust Gas Parameters					
Exhaust Gas Temperature (°C)	53.9	56.8	57.4	56.0	-
Exhaust Gas Moisture Content (%)	14.6	17.7	16.7	16.3	-
Exhaust Gas Velocity (m/s)	19.7	20.3	19.7	19.9	-
Exhaust Gas Volumetric Flow Rate (Rm ³ /s)	40.0	39.3	38.9	39.4	-
Oxygen - O ₂ (%)	16.1	17.0	13.2	15.4	-
Carbon Dioxide - CO ₂ (%)	2.53	2.24	4.23	3.00	-
Total Particulate Matter - PM					
Concentration at 11% O ₂ (mg/Rm ³)	125	150	167	148	150
Emission Rate (g/s)	2.40	2.34	5.03	3.26	-
Legend:					
°C Degrees Celsius.					
m/s Metres per second.					
Rm ³ /s Dry cubic metres per second at reference conditions (25°C and 101.3 kPa).					
mg/Rm ³ Milligrams per dry cubic metre at reference conditions (25°C and 101.3 kPa).					
kg/hr Kilograms per hour.					

The average measured concentration of particulate matter (corrected to 11% O₂) was 148 mg/Rm³, which is below the stack emission limit of 150 mg/Rm³ presented in Table 5 of the facility's Approval (No. 2011-076657-A01).

Table 4.11 Source Testing Results - Power Boiler - Combustion Gases

Parameter	Test #1	Test #2	Test #3	Average
Test Date	July 23, 2015	July 23, 2015	July 24, 2015	-
Test Duration (min)	30	30	30	-
Exhaust Gas Volumetric Flow Rate (Rm ³ /s)	40.0	39.3	38.9	39.4
Sulphur Dioxide - SO₂				
Concentration (ppm)	ND	ND	ND	ND
Concentration (mg/Rm ³)	ND	ND	ND	ND
Emissions Rate (kg/hr)	ND	ND	ND	ND
Nitrogen Oxides - NO_x				
Concentration (ppm)	18.9	17.6	36.7	24.4
Concentration (mg/Rm ³)	35.5	33.1	69.1	45.9
Emissions Rate (kg/hr)	5.11	4.68	9.67	6.49
Carbon Monoxide - CO				
Concentration (ppm)	1,037	235	388	554
Concentration (mg/Rm ³)	1188	269	444	634
Emissions Rate (kg/hr)	171	38.1	62.2	90.4
Legend:				
Rm ³ /s Dry cubic metres per second at reference conditions (25°C and 101.3 kPa).				
mg/Rm ³ Milligrams per dry cubic metre at reference conditions (25°C and 101.3 kPa).				
kg/hr Kilograms per hour.				

The emission rates of NO_x and CO from the Power Boiler were 6.49 kg/hr and 90.4 kg/hr, respectively. No SO₂ was detected.

4.6 HIGH LEVEL ROOF VENT

The results of the source emissions testing for combustion gases and total reduced sulphur from the High Level Roof Vent exhaust stack are in Tables 4.12 and 4.13, respectively.

Table 4.12 Source Testing Results - HLRV - Combustion Gases

Parameter	Test #1	Test #2	Test #3	Average
Test Date	July 23, 2015	July 23, 2015	July 23, 2015	-
Test Duration (min)	30	30	30	30
Exhaust Gas Volumetric Flow Rate (Rm ³ /s)	30.9	30.8	31.0	30.9
Sulphur Dioxide - SO₂				
Concentration (ppm)	1.76	1.66	1.66	1.70
Concentration (mg/Rm ³)	4.62	4.35	4.36	4.44
Emissions Rate (kg/hr)	0.51	0.48	0.49	0.49
Nitrogen Oxides - NO_x				
Concentration (ppm)	18.9	19.6	18.7	19.0
Concentration (mg/Rm ³)	35.5	36.8	35.2	35.8
Emissions Rate (kg/hr)	3.95	4.09	3.93	3.99
Carbon Monoxide - CO				
Concentration (ppm)	132	138	145	138
Concentration (mg/Rm ³)	151	157	166	158
Emissions Rate (kg/hr)	16.9	17.5	18.5	17.6
Legend:				
Rm ³ /s Dry cubic metres per second at reference conditions (25°C and 101.3 kPa).				
ppm Parts per million by volume at reference conditions.				
mg/Rm ³ Milligrams per dry cubic metre at reference conditions (25°C and 101.3 kPa).				
kg/hr Kilograms per hour.				

The emission rates for SO₂, NO_x, and CO from the High Level Roof Vent were 0.49 kg/hr, 3.99 kg/hr, and 17.7 kg/hr, respectively.

Table 4.13 Source Testing Results - High Level Roof Vent - Total Reduced Sulphur

Parameter	24-hour TRS Monitoring	Stack Emission Limit (Table 1 of Approval)
Test Start	July 22, 2015 08:45	-
Test Finish	July 23, 2015 08:45	-
Average exhaust gas concentration (ppm dv)	36.0	nl
Maximum 4-hour rolling average exhaust gas concentration (ppm dv)	57	nl
Legend:		
ppm dv Parts per million, dry volume.		
nl No limit established.		

The maximum 4-hour rolling average observed during the testing was 57 ppm (dry basis). There is no stack emission limit specified in the facility's Approval (No. 2011-076657-A01).

4.7 SUMMARY OF RESULTS

Currently there are specified regulatory limits in the facility's approval (2011-076657-A01) for emissions of PM and/or TRS from four of the five exhaust stacks listed. The measured concentration of PM from the Lime Kiln, the Smelt Dissolving Tank, the Power Boiler and the Recovery Boiler were all below their respective regulatory stack limits. The maximum 4-hour rolling average concentration of TRS from the Lime Kiln was below the regulatory limit. No limit for TRS is specified for the Dissolving Tank or the High Level Roof Vent in the facility's approval.

5.0 CLOSURE

This report has been prepared for the sole benefit of Northern Pulp Nova Scotia Corporation. This report may not be relied upon by any other person or entity without the express written consent of Stantec and Northern Pulp Nova Scotia Corporation. Any use of this report by a third party, or any reliance on decisions made based upon this report, are the responsibility of the third party. Stantec accepts no responsibility for damages, if any, suffered by any third party as a result of decisions made or actions based on this report.

Stantec makes no representation or warranty with respect to this report, other than the work was undertaken by trained professional and technical staff in accordance with generally accepted engineering and scientific practices current at the time the work was performed. Any information or facts provided by others and referred to or utilized in the preparation of this report was assumed by Stantec to be accurate.

This study was undertaken exclusively for the purpose outlined herein and was limited to those contaminants and sources specifically referenced in this report. It should be noted that the measurements were taken over a relatively short time period on-site, and the emissions results may be considered representative only for the conditions present at the time of testing. This report cannot be used or applied under any circumstances to another location or situation or for any other purpose without further evaluation of the data and related limitations.

This report was developed by Tristan Blair-Hicks, EIT, and reviewed by Gillian Hatcher, M.A.Sc. and Vicki Corning, P.Eng.

If you have any questions regarding the contents of this report, or require any additional information, please do not hesitate to contact the undersigned.



Tristan Blair-Hicks, EIT
Environmental Services
Tel: (506) 452-7000



Vicki Corning, P.Eng.
Senior Associate, Environmental Services
Tel: (506) 452-7000

Appendix A

Pre-test plan



Stantec Consulting Ltd.
102 - 40 Highfield Park Drive
Dartmouth NS B3A 0A3
Tel: (902) 468-7777
Fax: (902) 468-9009

February 20, 2015
File: 121413456

Attention: Mr. Marc Theriault
Nova Scotia Environment
20 Pumphouse Road
Pictou, NS B2H 5C6

Dear Mr. Theriault,

**Reference: Pre-Test Plan for Source Emissions Testing Northern Pulp,
Pictou Mill – 2015 Calendar Year**

Please accept this Pre-test Plan for the completion of source emissions required at the Pictou Mill in New Glasgow, Nova Scotia for the 2015 calendar year.

Introduction

Northern Pulp is required to perform source emissions testing on the Recovery Boiler, Lime Kiln, Smelt Dissolving Tank, Power Boiler and the High Level Roof Vent to fulfil the conditions specified in the current Certificate of Approval (CoA) to Operate 2011-076657-R03. The required annual testing for 2015 consists of:

- Recovery Boiler and Power Boiler particulate matter testing 4 times per year;
- Lime Kiln and Smelt Dissolving Tank particulate matter testing 2 times per year;
- Lime Kiln, High Level Roof Vent and Smelt Dissolving Tank total reduced sulphur (TRS) testing 2 times per year;
- One PM_{2.5} testing event per year on the four stacks noted above for particulate matter; and
- One Chlorine (Cl) and Chlorine Dioxide (ClO₂) event per year on the bleach plant exhaust (High Level Roof Vent being the source of these emissions).

Test Program Organization

The source emissions testing will be performed for:

Company Name: Northern Pulp
Company Address: P.O. Box 549, Station Main, New Glasgow, NS, B2H 5E8
Contact Name:
Position: Environmental/Technical Leader
Telephone Number: (902) 752-8461
Email: @northernpulp.com



**Reference: Pre-Test Plan for Source Emissions Testing Northern Pulp,
 Pictou Mill – 2015 Calendar Year**

Sampling Company: Stantec Consulting Ltd.
 Project Manager: Gillian Hatcher
 Telephone Number: (902) 468-7777
 Fax Number: (902) 468-9009
 Email: @Stantec.com
 Key Sampling Team:

support from other staff as needed)

(with

Source Emissions Testing Program

The proposed source emissions testing methodology and proposed sampling timeframes are presented in Table 1.

Table 1 Source Emissions Testing Matrix

Source	Number of Visits	Number of Tests per Visit	Parameter	Sampling Method	Proposed Timeframe
Recovery Boiler	4	3	Total Particulate Matter (PM)	EPS 1/RM/8	Winter, Spring, Summer, Fall
	4	3	Combustion Gases	EPS 1/RM/15	Winter, Spring, Summer, Fall
	1	3	Particle Size Analysis	Microscopic technique	Fall
Power Boiler	4	3	Total Particulate Matter (PM)	EPS 1/RM/8	Winter, Spring, Summer, Fall
	4	3	Combustion Gases	EPS 1/RM/15	Winter, Spring, Summer, Fall
	1	3	Particle Size Analysis	Microscopic technique	Fall
Lime Kiln	2	3	Total Particulate Matter (PM)	EPS 1/RM/8	Spring, Fall
	2	3	Combustion Gases	EPS 1/RM/15	Spring, Fall
	1	3	Particle Size Analysis	Microscopic technique	Fall
	2	3	Total Reduced Sulphur (TRS)	US EPA Method 16B/C	Spring, Fall
Smelt Dissolving Tank	2	3	Total Particulate Matter (PM)	EPS 1/RM/8	Spring, Fall
	2	3	Combustion Gases	EPS 1/RM/15	Spring, Fall
	1	3	Particle Size Analysis	Microscopic technique	Fall
	2	3	Total Reduced Sulphur (TRS)	US EPA Method 16B/C	Winter, Summer
High Level Roof Vent	2	3	Total Reduced Sulphur (TRS)	US EPA Method 16B/C	Spring, Fall
	2	3	Combustion Gases	EPS 1/RM/15	Spring, Fall



**Reference: Pre-Test Plan for Source Emissions Testing Northern Pulp,
Pictou Mill – 2015 Calendar Year**

Table 1 Source Emissions Testing Matrix

Source	Number of Visits	Number of Tests per Visit	Parameter	Sampling Method	Proposed Timeframe
	1	3	Chlorine and chlorine dioxide	NCASI Special Report 91-07	Spring
Note: Timeframes are as follows based on the approval deadlines-Winter: January-March 31, 2015, Spring: April – June 30, 2015, Summer: July-September 30, 2015, Fall: October-December 31, 2015					

Details of each of the methods identified in Table 1, in addition to the preliminary testing methodology, are provided in the sections that follow.

Preliminary Testing: Upon arrival at each sampling location, Stantec will set up the source emissions testing equipment and conduct a preliminary survey to measure the average velocity, flue gas composition, and moisture content in the stack gases using EPS 1/RM/8 Methods B, C, and D, respectively. The data from this survey will be used to determine the appropriate nozzle size to conduct isokinetic sampling (where the velocity of the gas entering the nozzle is equal to the gas velocity in the stack) for particulate matter during the official testing part of the work. Verification for cyclonic or reverse flow will also be conducted during the preliminary survey, according to procedures outlined in the Environment Canada reference method EPS 1/RM/8.

Should fluctuations in the velocity pressure at a selected traverse point exceed 20% of the average pressure for that point; the diameter of the testing cross section will be reduced to include only those areas along the traverse which meet this requirement (less than 20% of the average). Although the diameter may be reduced, the number of sampling points along each traverse will remain the same as determined from EPS 1/RM/8, Method A, using the equivalent diameter.

Volumetric flow and exhaust gas emissions will be calculated using the full cross sectional area.

Particulate Matter: The source emissions testing of the Recovery Boiler, Lime Kiln, Smelt Dissolving Tank, and the Power Boiler for total particulate matter will be conducted in accordance with the Environment Canada reference method EPS 1/RM/8, entitled "Measurement of Releases of Particulate from Stationary Sources". In addition the alignment approach, as specified in the US EPA Guidance Document – GD-008, will be applied when source testing the Lime Kiln due to the cyclonic flow this source exhibits.

The particulate sampling train, used specifically for isokinetic sampling, is described in detail in EPS 1/RM/8, and is generally referred to as the "Method 5" sampling train for particulate matter (after the US EPA protocol). The sampling train has several different components which include: a heated sampling probe (a nozzle, stainless steel liner, thermocouple, and pitot tube assembly), a heated sample case containing a filter, an ice box containing impinger glassware, and an



February 20, 2015
Mr. Marc Theriault
Page 4 of 12

**Reference: Pre-Test Plan for Source Emissions Testing Northern Pulp,
Pictou Mill – 2015 Calendar Year**

umbilical cord leading to the pump, and control console. A schematic of the sampling system is shown in Figure 1.

For all source tests, leak checks of the sampling train will be performed as per accepted US EPA and Environment Canada methods. For each official test, two (2) traverses with up to twelve (12) sampling points per traverse will be used. Sampling will be conducted for five (5) minutes per sampling point, up to a maximum sampling time of 120 minutes per test.

The amount of material caught in the impingers will be determined gravimetrically and reported separately from the calculated total particulate matter emissions. All particulate matter samples will be recovered and analyzed at the Stantec laboratory in Fredericton, NB.

Microscopic Analysis (Fine Particulate, PM_{2.5}): As per the facility's Industrial Approval to Operate, the Environment Canada EPS 1/RM/55 or an alternative method acceptable to the Department is required for PM_{2.5} testing. As the method quoted in the approval is not valid for stacks with potential for entrained water droplets in the exhaust (which applies to boilers and dissolving tank at Northern) or cyclonic flow (which applies to the Lime Kiln), we propose microscopic analysis of filters as the viable option. This method involves analysis of total particulate matter filters (collected as described above) for fine particulate percentage.

The particle size analyses will be performed by MVA Scientific Consultants, based in Duluth, GA, using a JEOL JSM-6500F field emission scanning electron microscope operating in automated mode under the control of a Thermo Scientific Noran System SIX x-ray analysis system, using their automated particle size analysis method.

Total Reduced Sulphur: The source emissions testing of the Lime Kiln, the Smelt Dissolving Tank and the High Level Roof Vent for total reduced sulphur will be conducted in accordance with US EPA Method 16B. In this method, the sample is extracted from the exhaust gas of the stack through a heated Teflon line. The sample is chilled and then passes through an SO₂ analyzer to measure SO₂ from the source. The sample exits the analyzer and is then passed through a furnace where all sulphur compounds in the gas stream are thermally oxidized to SO₂, this SO₂ is measured in a second inline analyzer. The difference in the initial SO₂ and the final SO₂ measurement is the total reduced sulphur concentration (reported as H₂S). The analyzers are both Western Research SO₂ non-dispersive ultra-violet (NDUV) continuous analyzer. Monitoring will be conducted continuously over a 24 hour period as required by the approval condition.

Chlorine, Chlorine Dioxide (Cl₂, ClO₂): Sampling will be conducted in accordance with NCASI's sampling method which consists of the extraction of a sample bubbling through midget impingers and subsequent analysis by titration. The sampling train for the Cl₂ and ClO₂ consists of series of three mini impingers, connected by Teflon tubing. The first two impingers each contain 20 ml of potassium iodide (KI) solution buffered with potassium di-hydrogen phosphate (KH₂PO₄). The third impinger contains silica gel to remove any remaining moisture from the gas stream. The impingers are cooled by an ice bath, and the dried gas is then drawn through the sampling train with a calibrated pump. Total sampling time for each test is sixty (60) minutes.



February 20, 2015
Mr. Marc Theriault
Page 5 of 12

**Reference: Pre-Test Plan for Source Emissions Testing Northern Pulp,
Pictou Mill – 2015 Calendar Year**

Following completion of each test for Cl_2 and ClO_2 , the contents of the first two impingers are combined in a pre-cleaned beaker. Subsequent analysis via titration will be performed onsite by Stantec. The combined impinger solutions and de-ionized water rinse of the sample line and empty impingers would be titrated with sodium thiosulphate solution (0.010 N). The volume of titrant required to reach the first colorless endpoint would be recorded on a recovery data form. Five (5) ml of 10% sulphuric acid would be added to the sample and the titration continued. The volume of titrant required to reach the second colorless endpoint would be recorded on a recovery data form. These titrations would be conducted on site shortly following sampling by one of the field staff during the testing due to the instability of the samples, which begin to degrade after 24 hours.

Combustion Gases:

The combustion gases (O_2 , CO_2 , CO, NO_x , and SO_2) will be sampled according to the Environment Canada reference method EPS 1/RM/15, entitled *Reference Method for the Monitoring of Gaseous Emissions from Fossil Fuel-fired Burners*. In this method, samples of flue gas are drawn through a probe, non-isokinetically, from a single point near the centre of the stack. An ENERAC Model 500 Micro-Emission Analyzer, manufactured by ENERAC Inc., will be used to conduct the sampling. The Model 500 is equipped with a flue gas probe that has an integrated filter trap and condensate trap, and a housing unit that contains the pump and the electrochemical cells which are used to measure concentrations of sulphur dioxide, nitrogen oxides, carbon monoxide, carbon dioxide, and oxygen.

In accordance with the regulatory requirements for compliance testing, three replicate tests for each contaminant will be conducted on each stack.

Reporting

As per Approval No. 2011-076657-R03, actual particulate matter emission rates will be reported in units of g/s. The concentration released to the atmosphere will be reported in units of mg/m^3 at reference conditions of 25 °C and 101.3 kPa corrected for 11 % oxygen for the Recovery Boiler and Power Boiler and in units of kg/adubmt for the Lime Kiln and the Dissolving Tank. Fine particulate matter concentrations for the Lime Kiln, Dissolving Tank, Power Boiler and Recovery Boiler will be reported in units of mg/m^3 at reference conditions of 25 °C and 101.3 kPa corrected for 11 % oxygen. Total reduced sulphur will be reported in units of parts per million by dry volume (ppmdv). Emission rates of chlorine and chlorine dioxide from the High Level Roof Vent will be reported in units of g/s and the concentrations released to the atmospheric will be reported in units of mg/m^3 .

Results of each source emissions testing event will be documented in a final report for submission to Nova Scotia Environment (NSE) for review and approval within 60 days of completing the testing.




Reference: Pre-Test Plan for Source Emissions Testing Northern Pulp,
Pictou Mill – 2015 Calendar Year

Sampling Locations

The number and location of sample points along each traverse were previously determined according to EPS 1/RM/8, Method A, using the exhaust stack diameter. A diagram of a typical sample location is provided in Figure 2.


Figure 1 Source Emission Testing, Method 5 Sampling Train





Reference: Pre-Test Plan for Source Emissions Testing Northern Pulp,
Pictou Mill – 2015 Calendar Year

Figure 2 Source Emissions Testing, Sample Location Details





**Reference: Pre-Test Plan for Source Emissions Testing Northern Pulp,
 Pictou Mill – 2015 Calendar Year**

A summary of the sample location details is provided in Table 2.

Table 2 Sample Location Details

Parameter	Recovery Boiler	Lime Kiln	Smelt Dissolving Tank	Power Boiler Scrubber Stack	High Level Roof Vent
Stack Height – Above Grade (m)	69	37	51	51	65
Diameter / Equivalent Diameter (m)	3.51	1.22 ³	1.22	1.93	1.83
Stack/Duct Description	Circular	Circular	Circular	Circular	Circular
Stack Orientation	Vertical	Vertical	Vertical	Vertical	Vertical
Location of Source Testing	In Stack	In Stack	In Stack	In Stack	In Stack
Number of Sample Ports	4	2	2	2	1
Sample Port Diameter (m)	0.1	0.15	0.1	0.1	0.1
Location Upstream from any Disturbance,	>2	2	>2	>2	-
Location Downstream from any Disturbance,	1.45	8	6	> 4	-
Ideal or Non Ideal Flow Characteristics at The Sample Location ¹	Not Ideal	Not Ideal ²	Not Ideal	Not Ideal	-
Total Number of Sample Points	24 (for PM)	24 (for PM) 1 (for TRS)	20 (for PM) 1 (for TRS)	24 (for PM)	1 (for TRS and Cl, ClO ₂)
Number of Sample Points per Traverse (PM sampling)	12	12	10	12	NA
Sample Time per Point for PM samples (min)	5	5	5	5	NA
Sample time per Test for PM (min)	120	120	100	120	NA
Sample time per Test for combustion gas (min)	30	30	30	30	30 (for TRS) 60 (for Cl, ClO ₂)
Sample time per Test for TRS (min)	NA	1,440	1,440	NA	1,440

¹ The exhaust gas flow characteristics at the sampling location are referred to as being "Ideal" if the sample ports are located in a straight section of stack at least eight stack diameters downstream and two stack diameters upstream of any flow disturbance.
² The lime kiln sampling location has been changed from ideal to not ideal due to the cyclonic flow.
³ Field measurement – to be confirmed during the Winter/Spring Event

Quality Assurance / Quality Control

Throughout the stack testing program, rigorous quality assurance and quality control procedures will be applied to ensure the collection of reliable, representative, and reproducible emissions data. All equipment will be calibrated according to the protocols as prescribed by Environment Canada, and the US EPA. These calibrations include the following:



February 20, 2015
Mr. Marc Theriault
Page 9 of 12

**Reference: Pre-Test Plan for Source Emissions Testing Northern Pulp,
Pictou Mill – 2015 Calendar Year**

Pitots:	calibrated in a wind tunnel with probe and nozzles attached;
Gas meters:	calibrated against a critical orifice set;
Thermocouples:	calibrated using a potentiometric technique;
Nozzle:	four diameter measurements made using a micrometer across the sharpened edges; and
Combustion Gas Analyser:	2 point calibrations using span gases of known concentrations.

Calibration data will be provided in the final report.

Quality control checks will be performed at several stages during the testing program to ensure the collection of representative samples and the generation of valid results. These checks are performed by test personnel throughout the program under the guidance of the source testing crew chief. The Quality Control (QC) checks include the following:

- Use of standardized checklists and field notebooks to ensure completeness, traceability, and comparability of the process information and samples collected;
- Field checking of standardized forms by a second person to ensure accuracy and completeness;
- Strict adherence to sample chain-of-custody procedures;
- Use of appropriate field blanks (e.g., filter and solution samples); and
- Leak checks of sample trains.

All internal quality assurance and quality control procedures will be strictly adhered to during all test programs to ensure the production of useful and high quality data throughout the course of the program.

Qualifications of Source Testing Team

The successful completion of this project requires the skills of competent and experienced professionals who have a strong commitment to complete the project quickly and efficiently and to produce high quality results. The source testing team we have assembled to meet the challenges of this assignment consists of highly trained professionals who bring a broad range of expertise and experience to the project. The following paragraphs provide brief descriptions of the qualifications of the source emissions testing team:

Senior Reviewer:



February 20, 2015
Mr. Marc Theriault
Page 10 of 12

**Reference: Pre-Test Plan for Source Emissions Testing Northern Pulp,
Pictou Mill – 2015 Calendar Year**

Project Manager and Report Writer:



February 20, 2015
Mr. Marc Theriault
Page 11 of 12

**Reference: Pre-Test Plan for Source Emissions Testing Northern Pulp,
Pictou Mill – 2015 Calendar Year**

Source Testing Team:



February 20, 2015
Mr. Marc Theriault
Page 12 of 12

**Reference: Pre-Test Plan for Source Emissions Testing Northern Pulp,
Pictou Mill – 2015 Calendar Year**

Table 3 Proposed Schedule

Event	Proposed Date	Scope
Winter	February-March 31 (March 9 th week)	Recovery and Power Boiler PM, gases, dissolving tank TRS
Spring	April-June 30	Recovery, Power Boiler, kiln, dissolving tank PM, gases, kiln, HLRV TRS, HLRV chlorine
Summer	July-Sept. 30	Recovery and Power Boiler PM, gases, dissolving tank TRS
Fall	October-Dec. 31	Recovery, Power Boiler, kiln, dissolving tank PM, PM _{2.5} , gases, kiln, HLRV TRS

Closing

Your timely written approval of this pre-test plan is greatly appreciated. If you have any questions, please do not hesitate to contact me directly at (902) 468-7777.

Regards,

STANTEC CONSULTING LTD.

Gillian Hatcher
Project Manager – Environmental Services
Phone: (902) 468-7777
Fax: (902) 468-9009
@stantec.com

Vicky Corning
Team Lead
Phone: (506) 457-3200
Fax: (506) 452-7652
@stantec.com

v:\1214\active\121413\ox\121413456_2015_stack_testing_np\reporting\pre-test plan\pre-test plan northern pulp_2015_vc.docx

Appendix B

Calibration Data


VALLEY ENVIRONMENTAL CALIBRATION SERVICES
PITOT TUBE CALIBRATION REPORT

CLIENT - Stantec
 PROBE ID - 2FT M5
 NOZZLE - #8- 0.250"
 DATE - February 23, 2015

FAN SPEED m/s	STANDARD PITOT (mm H2O)	PROBE PITOT (mm H2O)
0.00	0.00	0.00
12.2	8.90	14.10
13.6	11.10	17.80
15.1	13.70	21.80
16.7	16.70	26.40
18.1	19.70	31.10

PITOT FACTOR $C_p = 0.794$

PITOT - 2FT M5 NOZZLE - #8- 0.250"
 February 23, 2015



Technician: T. Ryan

Signature *T. Ryan*

VALLEY ENVIRONMENTAL SERVICES
 160 Pony Drive #1
 Newmarket, Ontario L3Y 7B6
 PH: (905) 830 0136
 FAX: (905) 830 0137

Tunnel	VES
Std. Pitot C_p	0.999
Static	-0.25
Barometric	29.15
Temperature	65
Abs Static	29.13


VALLEY ENVIRONMENTAL CALIBRATION SERVICES
PITOT TUBE CALIBRATION REPORT

CLIENT - Stantec
 PROBE ID - 5FT M5
 NOZZLE - #10- 0.3125"
 DATE - February 24, 2015

FAN SPEED m/s	STANDARD PITOT (mm H2O)	PROBE PITOT (mm H2O)
0.00	0.00	0.00
12.4	9.00	12.90
13.9	11.40	16.20
15.3	13.80	19.90
16.8	16.70	23.60
18.1	19.40	28.00

PITOT FACTOR $C_p = 0.836$

PITOT - 5FT M5 NOZZLE - #10- 0.3125"
 February 24, 2015



Technician: T. Ryan

Signature: *Thomas Ryan*

VALLEY ENVIRONMENTAL SERVICES
 160 Pony Drive #1
 Newmarket, Ontario L3Y 7B6
 PH: (905) 830 0136
 FAX: (905) 830 0137

Tunnel	VES
Sid. Pitot C_p	0.999
Static	-0.25
Barometric	28.7
Temperature	65
Abs Static	28.68


VALLEY ENVIRONMENTAL CALIBRATION SERVICES
PITOT TUBE CALIBRATION REPORT

CLIENT - Stantec
 PROBE ID - 8-1 FT M5
 NOZZLE - #6- 0.1875"
 DATE - March 3, 2015

FAN SPEED m/s	STANDARD PITOT (mm H2O)	PROBE PITOT (mm H2O)
0.00	0.00	0.00
12.1	8.70	13.00
13.7	11.20	16.80
15.2	13.90	20.70
16.6	16.50	24.70
18.1	19.70	29.90

PITOT FACTOR $C_p = 0.816$

PITOT - 8-1 FT M5 NOZZLE - #6- 0.1875"
 March 3, 2015



Technician: T. Ryan

Signature: *T. Ryan*

VALLEY ENVIRONMENTAL SERVICES
 160 Pony Drive #1
 Newmarket, Ontario L3Y 7B6
 PH: (905) 830 0136
 FAX: (905) 830 0137

Tunnel	VES
Std. Pitot C_p	0.999
Static	-0.25
Barometric	29.1
Temperature	65
Abs Static	29.08

Pre-Test Dry Gas Meter - Control Unit Calibration

Date : 6/29/2015
 Barometric Pressure, Pb : 29.7
 Model Number : 1646
 Calibrated By : JJB
 Job #:

Orifice Manometer Setting, deltaH (in. H2O)	Dry Gas Meter Volume, Vm (cu.ft)					Temperatures (F)			Time, theta (min)
						Dry Gas Meter			
						Outlet, to	Average, fm		
0.9					5.430				10
1.5					5.353	64	65	66	8
2.3					5.803	66	66	67	7

Calculations

Orifice Manometer Setting, deltaH (in. H2O)	Dry Gas Correction Factor, gamma (Tolerance = 0.95 - 1.05, +/-1.5% of avg)	Orifice Pressure Differential (delta H@) yielding 0.75 cfm of air at 68F and 29.92 in.Hg as in. H2O (Tolerance = +/- 0.15 in.)	Orifice Coefficient Ko
0.9	1.039	1.590	0.758
1.5	1.030	1.776	0.723
2.3	1.032	1.770	0.723
Average	1.033	1.712	0.734

METHOD 5 DRY GAS METER CALIBRATION USING CRITICAL ORIFICES



- 1) Select three critical orifices to calibrate the dry gas meter which bracket the expected operating range
- 2) Record barometric pressure before and after calibration procedure
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record data and information in the GREEN cells. YELLOW cells are calculated.

DATE: **9/29/2015** METER SERIAL #: **17483060** BAROMETRIC PRESSURE (in Hg): INITIAL **29.7** FINAL **29.7** AVG (P_{bar}) **29.7**
 METER PART #: **1648** CRITICAL ORIFICE SET SERIAL #: **1463a**

IF Y VARIATION EXCEEDS 2.00%,
ORIFICE SHOULD BE RECALIBRATED

ORIFICE #	RUN #	K FACTOR (AVG)	TESTED VACUUM (in Hg)	DGM READINGS (FT ³)			TEMPERATURES °F					ELAPSED TIME (MIN)	DGM ΔH (in H ₂ O)	(1) V _g (STD)	(2) V _c (STD)	(3) Y	Y VARIATION (%)	ΔH _g	
				INITIAL	FINAL	NET (V _g)	AMBIENT	DGM INLET		DGM OUTLET									DGM AVG
								INITIAL	FINAL	INITIAL	FINAL								
15	1	0.4164	18	983.61	989.03	5.420	20.2	63	66	63	64	64	10.00	0.90	5.4343	5.8454	1.038		1.58
	2	0.4164	18	989.03	994.47	5.440	20.4	66	66	64	65	65.25	10.00	0.90	5.4414	5.8442	1.037		1.58
	3	0.4164	18	994.47	999.90	5.430	20.5	66	66	65	65	65.5	10.00	0.90	5.4288	5.8437	1.040		1.58
AVG = 1.038																0.51			
18	1	0.5065	17	999.90	1,005.25	5.350	20.5	66	67	65	65	65.75	8.00	1.50	5.3542	5.8135	1.030		1.78
	2	0.5065	17	1,005.25	1,010.61	5.360	20.5	67	67	65	66	66.25	8.00	1.50	5.3591	5.8138	1.030		1.78
	3	0.5065	17	1,010.61	1,015.96	5.350	20.5	67	67	66	66	66.5	8.00	1.50	5.3466	5.8135	1.031		1.78
AVG = 1.030																-0.11			
23	1	0.6307	16	1,015.96	1,021.77	5.810	20.5	67	68	66	67	67	7.00	2.30	5.8122	5.8937	1.030		1.77
	2	0.6307	16	1,021.77	1,027.58	5.790	20.5	68	68	67	66	67.5	7.00	2.30	5.7967	5.8937	1.034		1.77
	3	0.6307	16	1,027.58	1,033.37	5.810	20.5	69	69	66	67	67.75	7.00	2.30	5.8040	5.8937	1.031		1.77
AVG = 1.032																-0.18			

USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:

The following equations are used to calculate the standard volumes of air passed through the DGM, V_g (std), and the critical orifice, V_c (std), and the DGM calibration factor, Y. These equations are automatically calculated in the spreadsheet above

AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = **1.033**

AVERAGE ΔH_g = **1.71**

- (1) $V_{g(std)} = K_1 \cdot I'm \cdot \frac{P_{bar} + (\Delta H / 13.6)}{T_m}$ = Net volume of gas sample passed through DGM, corrected to standard conditions
 K₁ = 17.64 (R/in Hg) (English), 0.3858 (K/mm Hg) (Metric)
 T_m = Absolute DGM avg. temperature (°R - English, °K - Metric)
- (2) $V_{c(std)} = K^2 \cdot \frac{I'bur \cdot \Theta}{\sqrt{T_{amb}}}$ = Volume of gas sample passed through the critical orifice, corrected to standard conditions
 T_{amb} = Absolute ambient temperature (°R - English, °K - Metric)
 K = Average K factor from Critical Orifice Calibration
- (3) $Y = \frac{V_{g(std)}}{I'm_{(std)}}$ = DGM calibration factor

$$\Delta H_g = \left(\frac{0.758}{V_{g(std)}} \right)^2 \Delta H \left(\frac{V_{g(std)}}{V_c} \right)$$

Pre-Test Dry Gas Meter - Control Unit Calibration

Date : 6/29/2015
 Barometric Pressure, Pb : 29.7
 Model Number : 1848
 Calibrated By : JJB
 Job #:

Orifice Manometer Setting, deltaH (in. H2O)	Dry Gas Meter Volume, Vm (cu.ft)					Temperatures (F)			Time, theta (min)
						Dry Gas Meter			
	Total					Outlet, to	Average, tm		
0.9					5.000		59	61	10
1.5					4.943		64	65	8
2.3					5.343		66	67	7

Calculations

Orifice Manometer Setting, deltaH (in. H2O)	Dry Gas Correction Factor, gamma (Tolerance = 0.95 - 1.05, +/-1.5% of avg)	Orifice Pressure Differential (delta H@) yielding 0.75 cfm of air at 68F and 29.92 in.Hg as in. H2O (Tolerance = +/- 0.15 in.)	Orifice Coefficient Ko
0.9	1.119	1.602	0.757
1.5	1.113	1.780	0.722
2.3	1.120	1.770	0.720
Average	1.117	1.717	0.733

METHOD 5 DRY GAS METER CALIBRATION USING CRITICAL ORIFICES

6/29/2015

- 1) Select three critical orifices to calibrate the dry gas meter which bracket the expected operating range
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at test JJB
necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record data and information in the GREEN cells. YELLOW cells are calculated.



DATE: 6/29/2015		METER SERIAL #: 16805036		BAROMETRIC PRESSURE (In Hg)		INITIAL: 29.7		FINAL: 29.7		AVG (P _{bar}): 29.7		IF Y VARIATION EXCEEDS 2.00%, ORIFICE SHOULD BE RECALIBRATED							
METER PART #: 1848		CRITICAL ORIFICE SET SERIAL #: 1463a										(1)	(2)	(3)	Y				
ORIFICE #	RUN #	K' FACTOR (AVG)	TESTED VACUUM (In Hg)	DGM READINGS (F ³)			TEMPERATURES *F				ELAPSED TIME (MIN) δ	DGM ΔH (In H ₂ O)	V _{cr} (STO)	V _{cr} (STO)	V _{cr} (STO)	Y VARIATION (%)	ΔH _g		
				INITIAL	FINAL	NET (V _{cr})	AMBIENT	DGM INLET INITIAL	DGM INLET FINAL	DGM OUTLET INITIAL								DGM OUTLET FINAL	DGM AVG
15	1	0.4164	18	544.80	540.78	4.980	19.8	55	62	54	59	57.5	10.00	0.90	5.0596	5.6478	1.117	1.81	
	2	0.4164	18	549.78	554.79	5.010	19.8	62	64	59	61	61.5	10.00	0.90	5.0473	5.6478	1.119	1.80	
	3	0.4164	18	554.79	559.80	5.010	19.9	64	64	61	62	62.75	10.00	0.90	5.0352	5.6472	1.122	1.80	
													AVG =		1.119	0.18			
18	1	0.9085	18	559.80	564.72	4.920	20.1	64	66	62	63	63.75	8.00	1.50	5.8427	5.5158	1.116	1.78	
	2	0.9085	18	564.72	569.67	4.950	20.3	66	67	63	64	65	8.00	1.50	5.8510	5.5147	1.112	1.78	
	3	0.9085	18	569.67	574.63	4.960	20.3	67	67	64	65	65.75	8.00	1.50	5.8539	5.5147	1.111	1.78	
													AVG =		1.113	-0.28			
23	1	0.5307	18	574.63	579.57	5.340	20.3	67	68	65	66	66.5	7.00	2.30	5.3471	5.9850	1.119	1.77	
	2	0.5307	18	579.57	585.31	5.340	20.2	68	68	66	66	67	7.00	2.30	5.3420	5.9858	1.120	1.77	
	3	0.5307	18	585.31	590.66	5.350	20.1	68	68	66	67	67.25	7.00	2.30	5.3495	5.9862	1.119	1.77	
													AVG =		1.120	0.21			

USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:

The following equations are used to calculate the standard volumes of air passed through the DGM, V_g (std), and the critical orifice, V_{cr} (std), and the DGM calibration factor, Y. These equations are automatically calculated in the spreadsheet above.

AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = 1.117

AVERAGE ΔH_g = 1.72

$$(1) V_{m(std)} = K_1 \cdot V_m \cdot \frac{P_{bar} + (\Delta H / 13.6)}{T_m}$$

= Net volume of gas sample passed through DGM, corrected to standard conditions

K₁ = 17.64 °R/in Hg (English), 0.3856 °K/mm Hg (Metric)

T_m = Absolute DGM avg. temperature (°R - English, °K - Metric)

$$(2) V_{cr(std)} = K' \cdot \frac{P_{bar} + \Theta}{\sqrt{T_{amb}}}$$

= Volume of gas sample passed through the critical orifice, corrected to standard conditions

T_{amb} = Absolute ambient temperature (°R - English, °K - Metric)

K' = Average K' factor from Critical Orifice Calibration

$$(3) Y = \frac{V_{cr(std)}}{V_{m(std)}}$$

= DGM calibration factor

$$\Delta H_g = \left(\frac{0.75 R}{V_{cr(std)}} \right)^2 \Delta H \left(\frac{V_m(std)}{V_m} \right)$$

CONTINUOUS EMISSION MONITORS SYSTEM CALIBRATION AND DRIFT

Client: Northern Pulp
 Plant: Pictou
 Location: DIS TANK
 Project No.: 121413456
 Personnel: NGM

Test No.: TRS
 Date: April 28, 2015
 Time Start: 5:40 PM
 Time Finish: 7:40 AM

INSTRUMENT SPAN VALUES			
Oxygen (%):	25	Carbon Dioxide (%):	25
Sulphur Dioxide (ppm):	500	Carbon Monoxide (ppm):	300
		TRS (ppm):	500

Analyzer Setting	Cal. Gas Value	Initial Values			Final Values		Drift (<3% Span)
		Analyzer Calibration	System Calibration	System Cal. Bias (<5% Span)	System Calibration	System Cal. Bias (<5% Span)	
O2 Zero	0.00	0.00	0.00	0.00%	-0.27	-1.08%	-1.08%
O2 Span	21.53	21.53	21.52	-0.04%	21.63	0.40%	0.44%
CO2 Zero	0.00	0.00	0.00	0.00%	0.00	0.00%	0.00%
CO2 Span	20.84	20.86	20.84	-0.08%	20.83	-0.12%	-0.04%
CO Zero	0.00	0.00	0.00	0.00%	0.4	0.12%	0.12%
CO Span	290.0	290.0	289.8	-0.08%	298.1	2.70%	2.78%
SO2 Zero	0.00	0.00	0.00	0.00%	4.1	0.83%	0.83%
SO2 Span	490.0	490.2	490.0	-0.04%	491.5	0.27%	0.30%
TRS Zero	0.00	0.00	0.00	0.00%	3.3	0.66%	0.66%
TRS Span	490.0	490.0	498.89	1.78%	481.15	-1.77%	-3.55%

15:40-16:00
 ZERO SPAN

TRS	-9.9	496.78
SO2	0	498.43

Logger date 02 01 2016 1:32 actual 30 04 2015 15:37



Praxair Distribution Mid-Atlantic
 One Steel Road East
 Morrisville, PA 19067
 Tel. (800)638-6360 Fax (215)736-5240
 PGVP ID: F32014

DocNumber 000007823

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PDI WHSE SAINT JOHN NB BRAN
 28 MCILVEEN DR
 SAINT JOHN NB E2J 4Y

Praxair Order Number: 04821650
 Customer P. O. Number: STANTEC CONS
 Customer Reference Number:

Fill Date: 3/14/2014
 Part Number: NI OX21E-AS
 Lot Number: 3016030734C3
 Cylinder Style & Outlet: AS CGA 590
 Cylinder Pressure & Volume: 2000 psig 140 cu ft

Certified Concentration:

Expiration Date:	3/18/2022	NIST Traceable
Cylinder Number:	CC244607	Analytical Uncertainty:
21.53 %	OXYGEN	± 0.3 %
Balance	NITROGEN	

Certification Information: Certification Date: 3/18/2014 Term: 96 Months Expiration Date: 3/18/2022

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: OXYGEN

Requested Concentration: 21 %
 Certified Concentration: 21.53 %
 Instrument Used: SIEMENS OXYMAT 5F
 Analytical Method: PARAMAGNETIC
 Last Multi-point Calibration: 3/11/2014

First Analysis Data:		Date: 3/18/2014	
Z:	0	R:	21
C:	21.55	Conc:	21.53
R:	21	Z:	0
C:	21.55	C:	21.55
R:	21	Conc:	21.53
Z:	0	C:	21.55
R:	21	Conc:	21.53
UOM:	%	Mean Test Assay:	21.53 %

Reference Standard Type: GMS
 Ref Std Cylinder #: CC207156
 Ref Std Conc: 20.98 %
 Ref Std Traceable to SRM #: 2559A
 SRM Sample #: 71-D-14
 SRM Cylinder #: CAL015789

Second Analysis Data:		Date:	
Z:	0	R:	0
C:	0	Conc:	0
R:	0	Z:	0
C:	0	C:	0
R:	0	Conc:	0
Z:	0	C:	0
R:	0	Conc:	0
UOM:	%	Mean Test Assay:	0 %

Analyzed by:

Jeff Gosner

Certified by:

Megha Patel

Information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Praxair Distribution, Inc., arising out of the use of the information contained herein exceed the fees established for providing such information.



Praxair Distribution Mid-Atlantic
 One Steel Road East,
 Morrisville, PA 19067
 Tel: (800) 638-6360 Fax (215) 736 5240
 PGVP ID: F32012

DocNumber: 000002252

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PDI WHSE SAINT JOHN, NB BRA
 28 MCILVEEN DR
 SAINT JOHN NB CAN E2J4Y

Praxair Order Number: 03982335
 Customer P. O. Number: STANEC CONSU
 Customer Reference Number:

Fill Date: 11/29/2012
 Part Number: NI CO100CE-AS
 Lot Number: 301910333205
 Cylinder Style & Outlet: AS GGA 350
 Cylinder Pressure & Volume: 2000 psig 140 cu ft

Certified Concentration:

Expiration Date:	12/3/2020	NIST Traceable
Cylinder Number:	CC137349	Analytical Uncertainty:
1003 ppm	CARBON MONOXIDE	± 1 %
Balance	NITROGEN	

Certification Information: Certification Date: 12/3/2012 Term: 96 Months Expiration Date: 12/3/2020

This cylinder was certified according to the 1997 EPA Traceability Protocol, Document #EPA-600/R-97/121, using Procedure G1
 Do Not Use this Standard if Pressure is less than 150 PSIG

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: CARBON MONOXIDE


Requested Concentration: 1000 ppm
 Certified Concentration: 1003 ppm
 Instrument Used: HORIBA VIA-S10, S/N 577172041
 Analytical Method: NON-DISPERSIVE INFRARED
 Last Multipoint Calibration: 11/13/2012

Reference Standard Type: GMIS
 Ref Std Cylinder #: CC265152
 Ref Std Conc: 1018 PPM
 Ref Std Traceable to SRM #: 1680B
 SRM Sample #: 02-J-49
 SRM Cylinder #: CALD18038

First Analysis Data:		Date:	
Z:	C:	R:	1018
R:	1018	Z:	0
Z:	0	C:	1003
R:	1018	Z:	0
Z:	0	C:	1003
R:	1018	Z:	0
UOM: PPM		Mean Test Assay: 1003 PPM	

Second Analysis Data:		Date:	
Z:	0	R:	0
R:	0	Z:	0
Z:	0	C:	0
R:	0	Z:	0
Z:	0	C:	0
R:	0	Z:	0
UOM: PPM		Mean Test Assay: 0 PPM	

Analyzed by: 
 Megha Patel

Certified by: 
 Judith Imperial

Information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Praxair Distribution, Inc. arising out of the use of the information contained herein exceed the fee established for providing such information.



Praxair Distribution Mid-Atlantic
 One Steel Road East,
 Morrisville, PA 19067
 Tel (800)638-6360 Fax (215)736-5240
 PGVP ID F32012

DocNumber: 00000948

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PDI WHSE SAINT JOHN, NB BRA
 28 MCILVEEN DR
 SAINT JOHN NB CAN E2J4Y

Praxair Order Number: 03816407
 Customer P. O. Number: STANEC CONSU
 Customer Reference Number

Fill Date: 9/10/2012
 Part Number: NI CD21E-AS
 Lot Number: 304325254203
 Cylinder Style & Outlet: AS CGA 560
 Cylinder Pressure & Volume: 2000 psig 140 cu ft

Certified Concentration:

Expiration Date:	9/21/2015	NIST Traceabl
Cylinder Number:	CC181318	Analytical Uncertainty:
20.84 %	CARBON DIOXIDE	± 1 %
Balance	NITROGEN	

Certification Information: Certification Date: 9/21/2012 Term: 36 Months Expiration Date: 9/21/2015
 This cylinder was certified according to the 1997 EPA Traceability Protocol, Document #EPA-600/R-97/121, using Procedure G1
 Do Not Use this Standard if Pressure is less than 150 PSIG

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: CARBON DIOXIDE


Requested Concentration: 21 %
 Certified Concentration: 20.84 %
 Instrument Used: SIEMENS ULTRAMAT 3E SN. 02-412
 Analytical Method: NON-DISPERSIVE INFRARED
 Last Multipoint Calibration: 9/8/2012

Reference Standard Type: GMIS
 Ref. Std. Cylinder #: CC183802
 Ref. Std. Conc: 18.92 %
 Ref. Std. Traceable to SRM #: 2745
 SRM Sample #: 9-C-34
 SRM Cylinder #: CAL016129

First Analysis Data:				Date:			
Z:	0	R:	19.94	C:	20.86	Conc:	20.839
R:	19.94	Z:	0	C:	20.86	Conc:	20.839
Z:	0	C:	20.86	R:	19.94	Conc:	20.839
UOM:	%	Mean Test Assay:		20.839 %			

Second Analysis Data:				Date:			
Z:	0	R:	0	C:	0	Conc:	0
R:	0	Z:	0	C:	0	Conc:	0
Z:	0	C:	0	R:	0	Conc:	0
UOM:	%	Mean Test Assay:		0 %			

Analyzed by: 
 Megha Patel

Certified by: 
 Judith Imperial

CONTINUOUS EMISSION MONITORS SYSTEM CALIBRATION AND DRIFT

Client: Northern Pulp
 Plant: Pictou
 Location: HLRV
 Project No.: 121419456
 Personnel: NGM

Test No.: TRS
 Date: 22/07/2015 23/07/2015
 Time Start: 8:45 AM
 Time Finish: 2:30 PM

INSTRUMENT SPAN VALUES			
Oxygen (%):	25	Carbon Dioxide (%):	25
Sulphur Dioxide (ppm):	500	Carbon Monoxide (ppm):	300
		TRS (ppm):	500

Analyzer Setting	Cal. Gas Value	Initial Values			Final Values		Drift (<3% Span)
		Analyzer Calibration	System Calibration	System Cal. Bias (<5% Span)	System Calibration	System Cal. Bias (<5% Span)	
O2 Zero	0.00	0.00	0.00	0.00%	-0.01	-0.04%	-0.04%
O2 Span	21.53	21.53	21.51	-0.08%	21.63	0.40%	0.48%
CO2 Zero	0.00	0.01	0.00	-0.04%	0.01	0.00%	0.04%
CO2 Span	20.95	20.95	20.93	-0.08%	20.97	0.08%	0.16%
CO Zero	0.00	0.00	0.00	0.00%	-1.9	-0.65%	-0.65%
CO Span	290.0	290.2	290.0	-0.05%	286.1	-1.34%	-1.29%
SO2 Zero	0.00	0.00	0.00	0.00%	-3.3	-0.66%	-0.66%
SO2 Span	490.0	490.2	490.0	-0.04%	480.2	-2.00%	-1.96%
TRS Zero	0.00	0.00	0.00	0.00%	-6.6	-1.32%	-1.32%
TRS Span	490.0	490.2	490	-0.04%	476.6	-2.72%	-2.68%

CONTINUOUS EMISSION MONITORS SYSTEM CALIBRATION AND DRIFT

Client: Northern Pulp
 Plant: Pictou
 Location: LIME KILN
 Project No.: 121419456
 Personnel: NGM

Test No.: TRS
 Date: April 29 2015
 Time Start: 8:25 AM
 Time Finish: 9:00 AM

INSTRUMENT SPAN VALUES			
Oxygen (%):	25	Carbon Dioxide (%):	25
Sulphur Dioxide (ppm):	500	Carbon Monoxide (ppm):	300
		TRS (ppm):	500

Analyzer Setting	Cal. Gas Value	Initial Values			Final Values		Drift (<3% Span)
		Analyzer Calibration	System Calibration	System Cal. Bias (<5% Span)	System Calibration	System Cal. Bias (<5% Span)	
O2 Zero	0.00	0.00	0.00	0.00%	0.24	0.96%	0.96%
O2 Span	21.53	21.53	21.53	0.00%	21.12	-1.64%	-1.64%
CO2 Zero	0.00	0.00	0.00	0.00%	-0.02	-0.08%	-0.08%
CO2 Span	20.84	20.86	20.80	-0.24%	20.23	-2.52%	-2.28%
CO Zero	0.00	0.00	0.00	0.00%	-2.0	-0.66%	-0.66%
CO Span	290.0	290.0	289.2	-0.27%	282.7	-2.44%	-2.16%
SO2 Zero	0.00	0.00	0.00	0.00%	-3.3	-0.66%	-0.66%
SO2 Span	490.0	490.2	490.0	-0.03%	476.5	-2.73%	-2.70%
TRS Zero	0.00	0.00	0.00	0.00%	-14.85	-2.97%	-2.97%
TRS Span	490.0	490.0	487.86	-0.43%	463.63	-5.27%	-4.85%

	16:40	17:10	
	ZERO	SPAN	10ppm
TRS	-3.3	476.74	6.78
SO2	-14.85	483.85	8.89



Praxair Distribution Mid-Atlantic
 One Steel Road East,
 Morrisville, PA 19067
 Tel: (800)638-6360 Fax: (215)736-5240
 PGVP ID: F32014

DocNumber: 000010131

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PDI WHSE SAINT JOHN NB BRAN
 28 MCILVEEN DR
 SAINT JOHN NB E2J 4Y

Praxair Order Number: 05101372
 Customer P. O. Number: STANEC AEC51
 Customer Reference Number:

Fill Date: 9/9/2014
 Part Number: NI NO1000E-AS
 Lot Number: 304613252401
 Cylinder Style & Outlet: AS CGA 860
 Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date:	9/23/2022	NIST Traceable
Cylinder Number:	CC24169	Analytical Uncertainty:
979.2 ppm	NITRIC OXIDE	± 0.5 %
Balance	NITROGEN	

NOx = 980 ppm

NOx for Reference Only

Certification Information: Certification Date: 9/23/2014 Term: 96 Months Expiration Date: 9/23/2022

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: NITRIC OXIDE

Requested Concentration: 1000 ppm
 Certified Concentration: 979.2 ppm
 Instrument Used: TECO MODEL 42i-HL 0928837883
 Analytical Method: CHEMILUMINESCENCE
 Last Multipoint Calibration: 9/17/2014

Reference Standard Type: GMIS
 Ref. Std. Cylinder #: CC244881
 Ref. Std. Conc: 982.2 PPM
 Ref. Std. Traceable to SRM #: 1686b
 SRM Sample #: 42-M-47
 SRM Cylinder #: CALD18047

First Analysis Data:		Date: 9/16/2014	
Z: 0	R: 982	C: 981	Conc: 980.19
R: 985	Z: 0	C: 979	Conc: 978.19
Z: 0	C: 979	R: 982	Conc: 978.19
UOM: PPM	Mean Test Assay: 978.85 PPM		

Second Analysis Data:		Date: 9/23/2014	
Z: 0	R: 956	C: 971	Conc: 977.98
R: 954	Z: 0	C: 973	Conc: 979.99
Z: 0	C: 974	R: 956	Conc: 981
UOM: PPM	Mean Test Assay: 979.66 PPM		

Analyzed by:

Judith Imperial

Certified by:

Jeff Gosner

Probe Stack Thermocouple Calibration

Calibration Date: 19-Mar-15

Calibrated By: NGM, JJB

Reference ID Fisher Scientific catalog #150414E



Ice Bath

Thermocouple #	Reference Temp (F)	Observed Temp (F)
#1 -2' probe	32	32.3
#1 -3' probe	32	32.1
#1 -4' probe	32	33.7
#1 -5' probe	32	33.1
#1 -6' probe	32	32.5
#1 -8'-1 probe	32	32.7
#1 -8'-2 probe	32	32.6
#1 -10'-1 probe	32	33
#1 -10'-2 probe	32	33
#6 -1848	32	
#7 -1848	32	
#6 -1646	32	
#7 -1646	32	


Percent Difference (Absolute Temp)
-0.06%
-0.02%
-0.34%
-0.22%
-0.10%
-0.14%
-0.12%
-0.20%
-0.20%

Boiling Water

Thermocouple #	Reference Temp (F)	Observed Temp (F)
#1 -2' probe	202	206.7
#1 -3' probe	201	208.7
#1 -4' probe	203	201.6
#1 -5' probe	203	206.3
#1 -6' probe	202	203.3
#1 -8'-1 probe	203	204.5
#1 -8'-2 probe	202	202.3
#1 -10'-1 probe	200	212.1
#1 -10'-2 probe	202	210.3
#6 -1848	202	
#7 -1848	203	
#6 -1646	203	
#7 -1646	201	

Percent Difference (Absolute Temp)
-0.70%
-1.15%
0.21%
-0.50%
-0.20%
-0.23%
-0.05%
-1.80%
-1.24%

Error should be < 1.5%



CAL-CHEK CANADA

250 GOVERNOR'S ROAD - DUNDAS, ONTARIO L9H 3K3
TELEPHONE: (905) 628-4636 FAX: (905) 627-5903
email calchek@cogeco.ca

Scale / Balance Certification

Date: February 9, 2015

Certificate Number: S150165

Customer: Stantec Consulting Ltd.
845 Prospect Street
Fredericton, New Brunswick E3B 2T7

Room Temperature: 20.1°C

Calibration Location: 10 Timothy Road North Kingsclear Lab
Scale / Balance Manufacturer: Radwag

Resolution: 0.0001g

Model Number: XA220-2X

Serial Number: 336271

Capacity: 220 g

Capacity Calibrated To: 220 g

<u>ACTUAL WEIGHT</u>			<u>ACTUAL WEIGHT</u>		
<u>APPLIED</u>	<u>SCALE</u>	<u>ERROR</u>	<u>APPLIED</u>	<u>SCALE</u>	<u>ERROR</u>
<u>GRAMS</u>	<u>READINGS</u>	<u>AS FOUND</u>	<u>GRAMS</u>	<u>READINGS</u>	<u>AS LEFT</u>
	<u>AS FOUND</u>	<u>AS FOUND</u>		<u>AS LEFT</u>	<u>AS LEFT</u>
0.0020	0.0020	0.0000	0.0020	0.0020	0.0000
0.0050	0.0050	0.0000	0.0050	0.0050	0.0000
0.0100	0.0100	0.0000	0.0100	0.0100	0.0000
0.0500	0.0500	0.0000	0.0500	0.0500	0.0000
0.1000	0.1000	0.0000	0.1000	0.1000	0.0000
0.5000	0.5001	-0.0001	0.5000	0.5000	0.0000
1.0000	0.9998	0.0002	1.0000	0.9999	0.0001
5.0000	4.9999	0.0001	5.0000	4.9990	0.0010
10.0000	10.0001	-0.0001	10.0000	10.0000	0.0000
20.0000	20.0016	-0.0016	20.0000	20.0009	-0.0009
50.0000	50.0030	-0.0030	50.0000	50.0020	-0.0020
100.0000	99.9982	0.0018	100.0000	99.9992	0.0008
200.0000	200.0134	-0.0134	200.0000	200.0027	-0.0027
220.0000	220.0170	-0.0170	220.0000	220.0110	-0.0110

The above mentioned Scale / Balance has been checked for accuracy using the following N.I.S.T. calibrated dead weights as per the CSA method.

<u>STANDARD</u>	<u>CAL DATE</u>	<u>NIST LAB #</u>
22XE	03/10/13	681/280058-10

Obtained results are within the manufacturer's stated accuracy and/or are within +/-0.01% or 1 division whichever is greater at any point of the calibrated range.

Pass/Fail statements are based on data from measurements made, procedures utilized, professional experience and the uncertainty associated with this calibration. It is the responsibility of the user of this equipment to determine if the results identified meet specific requirements for its intended application.

Calibration Technician: Dave Newitt

Suggested Calibration Due Date: February 2016


Authorized Signatory: Roni Newitt

Due dates appearing on the certificate of calibration and label are determined by client for administrative purposes and do not imply continued conformance to specifications.
All calibrations performed at customer location unless otherwise noted.

This certificate shall not be reproduced except in full, without the written approval of Cal-Chek Canada



Praxair Distribution Mid-Atlantic
 One Steel Road East,
 Morrisville, PA 19067
 Tel.(800)638-6360 Fax (215)736-5240
 PGVP ID: F32014

DocNumber: 000010141

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PDI WHSE SAINT JOHN NB BRAN
 28 MCILVEEN DR
 SAINT JOHN NB E2J 4Y

Praxair Order Number: 05101372
 Customer P. O. Number: STANEC AEC51
 Customer Reference Number:

Fill Date: 9/15/2014
 Part Number: NI SD2500E-AS
 Lot Number: 304613258406
 Cylinder Style & Outlet: AS CGA 580
 Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date:	9/26/2022	NIST Traceable
Cylinder Number:	CC121441	Analytical Uncertainty:
2497 ppm	SULFUR DIOXIDE	± 0.6 %
Balance	NITROGEN	

Certification Information: Certification Date: 9/26/2014 Term: 96 Months Expiration Date: 9/26/2022

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: SULFUR DIOXIDE

Requested Concentration: 2500 ppm
 Certified Concentration: 2497 ppm
 Instrument Used: SIEMENS ULTRAMAT 6E S/N: J2-36
 Analytical Method: NON-DISPERSIVE INFRARED
 Last Multipoint Calibration: 9/17/2014

Reference Standard Type: GMIS
 Ref. Std. Cylinder #: SA7529
 Ref. Std. Conc: 2957 PPM
 Ref. Std. Traceable to SRM #: 1654A
 SRM Sample #:
 SRM Cylinder #:

First Analysis Data:		Date: 9/19/2014	
Z: 0	R: 2954	C: 2488	Conc: 2493.3
R: 2948	Z: 0	C: 2495	Conc: 2500.4
Z: 0	C: 2496	R: 2950	Conc: 2501.4
UOM: PPM	Mean Test Assay: 2495.4 PPM		

Second Analysis Data:		Date: 9/28/2014	
Z: 0	R: 2956	C: 2474	Conc: 2488
R: 2937	Z: 0	C: 2477	Conc: 2491
Z: 0	C: 2478	R: 2928	Conc: 2492
UOM: PPM	Mean Test Assay: 2490.4 PPM		

Analyzed by:

Judith Imperial

Certified by:

Jeff Gosner

Stantec Consulting Ltd.

Steel Nozzle Calibration Data Sheet

NozzleID	Nozzle Diameter (inches)					
Set - 1	<1>	<2>	<3>	<4>	Hi-Lo	Avg.
1-4	0.125	0.124	0.125	0.125	0.001	0.125
1-6	0.175	0.173	0.165	0.175	0.010	0.172
1-8	0.236	0.232	0.234	0.232	0.004	0.234
1-10	0.307	0.305	0.308	0.305	0.003	0.306
1-12	0.367	0.372	0.367	0.371	0.005	0.369
1-14	0.434	0.434	0.433	0.434	0.001	0.434
1-16	0.500	0.497	0.503	0.501	0.006	0.500
QA/QC Check						
Each Diameter Measured To Within = 0.001 Inches						
High - Low \leq 0.004						
Prepared By: JJB			Date: Feb 05, 2015			



QRM Electronics Inc. calibration laboratory certifies that the described instrument has been presented for inspection and the tests as shown indicate that the work performed has been completed and that the standard used in obtaining data are calibrated regularly traceable to the National Institute of Standards and Technology

Date:	6/24/2015	Customer:	STANTEC
Control Number:	8309	Address:	845 PROSPECT ST. FREDERICTON, NEW BRUNSWICK E3B 2T7
Description:	350M/XL		
Serial Number:	00968835/404 - 00959384/404		

SUGGESTED RECALIBRATION DATE: 6/24/2016

Parameter: Combustion

Accuracy Statement: +/- 20 ppm or 5% of m.v.

STANDARD	AS RECEIVED				AFTER CALIBRATION			
	PPM	°F	PASS/FAIL	NOTE	PPM	°F	PASS/FAIL	NOTE
O2 3.06 %	3.00 %	76.2	PASS		3.05 %	76.2	PASS	SR
CO 497 PPM	482 PPM	76.2	PASS		496 PPM	76.2	PASS	
NO 824 PPM	795 PPM	76.2	PASS		832 PPM	76.2	PASS	
NO2 96 PPM	94.1 PPM	76.2	PASS		97.0 PPM	76.2	PASS	
SO2 994.7 PPM	985 PPM	76.2	PASS		995 PPM	76.2	PASS	
HC 4980 PPM	4160 PPM	76.2	PASS		4990 PPM	76.2	PASS	

*NOTE: SR = Sensor Replaced, RNS = Response Not Stable

Test Equipment				
Transfer standards from:				
Cylinder #	Gas	Concentration	Certification Date	Expiration Date
RA56816	CO / O2	996.9 PPM / 3.10 %	03/27/2014	03/27/2017
XF000167B	SO2	994.7 PPM	03/31/2014	03/31/2016
SV14124	NO2	86 PPM	04/09/2014	04/09/2016
SX34840	NO / CO2	824 PPM / 17 %	06/01/2014	06/01/2017
8970411A	CO / O2	497 PPM / 296 PPM	06/10/2014	06/10/2017
CC107025	NO	81.3 PPM	03/06/2015	03/06/2017
SX21602	CO / O2	99.2 PPM / 3.06 %	03/11/2015	03/11/2018

Calibrated at:
QRM Electronics Inc.
250 West Beaver Creek Rd.
Unit 15, Richmond Hill, ON
L4B 1C7

Phone: (905) 771 5009
Fax : (905) 771 6041

KYLE ANDERSON
Calibrated By

Authorized Signature



Appendix C

Field data sheets

0716-15

MOISTURE FIELD DATA SHEET

Project No.: 121413456
 Client: Northern Pulp
 Plant: Lime Kiln
 Location: Pictou, NS
 Test: PM-1
 Date: July 20, 2015
 Analyst: TBH/SF



Moisture Data

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H2O	994.1	670.2	323.9
2	100 mL H2O	732.5	708.2	24.3
3	Blank	668.3	665.7	2.6
4	200g Silica Gel	966.3	958.5	7.8
Total Weight Gain (g)				358.6
Moisture Volume (mL)				


Volume H₂O Collected: 358.6 ml
 X 0.048 = 17.21 ft³ H₂O (Vwc)

DGM Final 187.12 ft³
 DGM Initial 156.76 ft³
 Final - Initial = 30.36 ft³ (Vmc)

Moisture = $\frac{Vwc}{(Vwc + Vmc)}$

Moisture = $\frac{17.21}{17.21 + 30.36}$

Moisture = 0.36 = 36%



SOURCE TESTING FIELD DATA SHEET

Job No.: 121413456
 Client: Alachua
 Plant: Duval
 Location: Pichu
 Test: P-1
 Date: 3-1-21
 Operators: JH
 Gamma: 1.55
 Delta H₀: 1.317
 Pilot Coeff: 0.816
 Start: 0:05
 Finish: 10:05

Static Pressure (in.H₂O): 0.51
 Port Length (in): 12"
 Stack Dia. (in.): 4.8"
 Probe Length (ft): 8'
 Nozzle ID (in.): 1.6 (0.132)
 Console S/N: 1676

Pre-Test Leak Check:
 Vacuum Pressure: -13
 Post-Test Leak Check:
 Vacuum Pressure: -12

K: 0.48

Traverse Point	Time (min)	Stack Gas Temp., T _s (F)	Velocity Head, d _p (in.H ₂ O)	Orifice d _H (in.H ₂ O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
1	2.5	157	0.58	0.24	156.76	264	242	65	87	66	-1
2	5	157	0.56	0.23	158.14	295	245	58	85	66	-1
	7.5	158	0.58	0.24	158.83	299	245	56	86	66	-1
3	10	161	0.60	0.25	159.49	300	244	55	85	66	-1
	12.5	161	0.52	0.22	160.17	300	245	51	85	66	-1
4	15	162	0.50	0.21	160.74	300	248	54	85	66	-1
	17.5	162	0.35	0.14	161.27	300	249	54	85	66	-1
5	20	162	0.35	0.14	161.81	300	251	54	85	66	-1
	22.5	162	0.40	0.17	162.39	299	250	54	85	66	-1
6	25	162	0.40	0.17	162.98	300	249	56	85	66	-1
	27.5	162	0.45	0.19	163.59	299	248	56	85	66	-1
7	30	162	0.42	0.17	164.15	299	249	56	85	66	-1
	32.5	162	0.44	0.18	164.74	299	248	54	86	66	-1
8	35	162	0.47	0.19	165.34	296	243	54	86	66	-1
	37.5	162	0.53	0.22	165.99	296	249	54	86	66	-1
9	40	163	0.52	0.21	166.63	298	248	51	86	66	-1
	42.5	165	0.50	0.21	167.27	297	247	51	85	66	-1
10	45	165	0.51	0.21	167.89	299	247	51	85	66	-1
	47.5	164	0.50	0.21	168.55	299	248	50	85	66	-1
11	50	162	0.50	0.21	169.18	297	248	50	85	66	-1
	52.5	162	0.48	0.20	169.87	296	248	50	85	66	-1
12	55	161	0.47	0.19	170.38	297	250	50	85	66	-1
	57.5	161	0.48	0.20	171.00	297	250	50	85	66	-1.5
13	60	161	0.47	0.19	171.59	297	252	50	85	66	-1.5

15° 0 5 10 15 20 25 30 35 40 45 50 55 60

Pump oil

SOURCE TESTING FIELD DATA SHEET

Job No.: 121415456
 Client: Alpeterra Airp
 Plant: # Lane 1-14
 Location: Pilsbush MS
 Test: PMA-1
 Date: July 21, 2015
 Operators: TRH/SE
 Gamma: 1.073
 Delta H₀: 1.717
 Pilot Coeff.: 0.816
 Start: 10.12
 Finish: 11.12

Static Pressure (in.H₂O): 0.51
 Port Length (in): 12"
 Stack Dia. (in.): 7.84
 Probe Length (ft): 8'
 Nozzle ID (in.): 1-6 (0.172)
 Console SIN: 1646

Pre-Test Leak Check: _____
 Vacuum Pressure: _____
 Post-Test Leak Check: _____
 Vacuum Pressure: -1.9

K: 0.48

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dP (in.H ₂ O)	Orifice dH (in.H ₂ O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
1	0	159	0.61	0.25	171.59	301	246	58	85	64	-1.5
	2.5	159	0.63	0.26	172.26	300	247	58	85	64	-2
2	5	159	0.60	0.25	173.04	300	246	58	85	64	-2
	7.5	161	0.62	0.26	174.35	300	247	54	84	64	-2
3	10	161	0.58	0.27	175.04	299	248	54	84	64	-2
	12.5	160	0.59	0.24	175.72	300	249	53	84	64	-3
4	15	161	0.54	0.22	176.38	298	249	53	84	64	-3
	17.5	161	0.51	0.21	177.02	299	248	53	84	64	-3
5	20	161	0.47	0.17	177.60	300	250	53	84	64	-3
	22.5	161	0.40	0.17	178.15	300	253	53	84	64	-3
6	25	160	0.35	0.14	178.72	300	253	53	84	64	-3
	27.5	156	0.30	0.12	179.17	300	250	54	84	64	-3
7	30	155	0.40	0.17	179.74	301	255	54	84	64	-3
	32.5	155	0.43	0.18	180.34	300	252	54	84	64	-2
8	35	155	0.45	0.19	180.95	300	252	54	84	63	-2
	37.5	154	0.60	0.21	181.57	301	253	54	84	63	-2
9	40	158	0.69	0.29	182.30	300	254	54	84	63	-2
	42.5	156	0.71	0.30	183.05	300	256	54	84	63	-2
10	45	158	0.79	0.33	183.89	297	257	55	85	64	-3
	47.5	158	0.80	0.33	184.61	300	258	53	85	64	-3
11	50	158	0.50	0.21	185.25	298	258	53	85	64	-3
	52.5	160	0.48	0.20	185.88	299	258	53	85	64	-3
12	55	158	0.48	0.20	186.51	300	260	53	85	64	-3
	57.5	155	0.48	0.20	187.12	300	261	53	85	64	-3
13	60	155	0.45	0.19	187.72	300	261	53	87	64	-3

MOISTURE FIELD DATA SHEET

Project No.: 121413456
 Client: Northern Pulp
 Plant: Line Kiba
 Location: Pictou, NS
 Test: PM-2
 Date: July 22, 2015
 Analyst: TBLT/SF



Moisture Data

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H2O	897.5	663.9	233.6
2	100 mL H2O	725.9	715.5	10.4
3	Blank	667.9	666.3	1.6
4	200g Silica Gel	971.7	966.1	5.6
Total Weight Gain (g)				251.2
Moisture Volume (mL)				

Volume H₂O Collected: 251.2 ml
 X 0.048 = 12.06 ft³ H₂O (Vwc)

DGM Final 713.37 ft³
 DGM Initial 187.47 ft³
 Final - Initial = 215.90 ft³ (Vmc)

Moisture = $\frac{Vwc}{(Vwc + Vmc)}$

Moisture = $\frac{12.06}{37.96}$

Moisture = 0.31 × 100 = 31%

1/2

SOURCE TESTING FIELD DATA SHEET

Job No.: 121113456
 Client: Alachua Co - P
 Plant: Waste Water
 Location: Pickens MS
 Test: PM-2
 Date: July 22, 2015
 Operators: SAH/SE
 Gamma: 1.033
 Delta H₀: 1.317
 Pitot Coeff.: 0.816
 Start: 12:30
 Finish:

Static Pressure (in.H2O): 0.51
 Port Length (in.): 12"
 Stack Dia. (in.): 48"
 Probe Length (ft): 8'
 Nozzle ID (in.): 1.6 (Q172)
 Console S/N: 1646

Pre-Test Leak Check:
 Vacuum Pressure: -12
 Post-Test Leak Check:
 Vacuum Pressure:

K: 0.48

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dp (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
0	0				107.47						
1	2.5	157	0.42	0.16	187.95	275	233	50	78	60	-1
2	5	160	0.40	0.16	188.55 *	300	244	50	80	60	-1
3	7.5	160	0.35	0.14	189.08	300	243	50	80	60	-1
4	10	162	0.35	0.14	189.61	299	244	48	80	60	-1
5	12.5	161	0.35	0.14	190.15	298	243	48	80	60	-1
6	15	161	0.30	0.12	190.65	296	244	48	80	60	-1
7	17.5	161	0.29	0.12	191.13	298	227	50	80	60	-1
8	20	161	0.27	0.11	191.61	292	240	50	79	57	-1
9	22.5	159	0.25	0.10	192.09	291	228	50	79	59	-1
10	25	158	0.25	0.10	192.54	291	228	47	79	59	-1
11	27.5	158	0.25	0.10	193.01	286	226	47	79	57	-1
12	30	157	0.24	0.10	193.47	285	227	47	79	59	-1
13	32.5	158	0.22	0.08	193.90	281	225	47	80	60	-1
14	35	156	0.33	0.16	194.48	276	227	47	80	60	-1
15	37.5	156	0.39	0.17	195.07	279	230	50	80	60	-1
16	40	155	0.39	0.16	195.63	278	230	50	80	60	-1
17	42.5	155	0.38	0.16	196.18	278	227	50	80	60	-1
18	45	155	0.38	0.16	196.70 *	274	228	50	80	60	-1
19	47.5	155	0.41	0.17	197.36	274	226	49	80	60	-1
20	50	154	0.40	0.17	197.92	275	228	47	80	60	-1
21	52.5	154	0.37	0.15	198.47	274	228	47	80	60	-1
22	55	154	0.36	0.15	199.01	273	230	47	80	60	-1
23	57.5	154	0.35	0.14	199.46	275	228	47	80	60	-1
24	60	155	0.35	0.14	200.10	280	231	47	80	60	-1

242

SOURCE TESTING FIELD DATA SHEET

Job No.: 121413456
 Client: Northway P-IP
 Plant: Live Kila
 Location: Pithun, MS
 Test: PM-2
 Date: 24/2/2015
 Operators: JKH/SLF
 Gamma: 1.033
 Delta H@: 1.717
 Pilot Coeff.: 0.816
 Start: 2:40
 Finish: 4:05

Static Pressure (in.H2O): 0.51
 Port Length (in): 12"
 Stack Dia. (in.): 4.8"
 Probe Length (ft): 8'
 Nozzle ID (in.): 1.6 (0.172)
 Console S/N: 1646

Pre-Test Leak Check: _____
 Vacuum Pressure: _____
 Post-Test Leak Check: _____
 Vacuum Pressure: -19

K: 948

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
1	0	155	0.43	0.18	200.10	277	231	52	80	61	-
2	5	158	0.45	0.19	201.27	282	231	52	80	61	-
3	7.5	158	0.42	0.17	201.87	298	225	51	80	60	-
4	10	158	0.42	0.17	202.45	295	228	50	80	60	-
5	12.5	159	0.35	0.14	203.00	291	219	46	80	60	-
6	15	159	0.36	0.15	203.53	290	223	46	80	60	-
7	17.5	161	0.30	0.12	204.03	282	226	46	80	60	-
8	20	162	0.32	0.13	204.54	283	227	45	81	61	-
9	22.5	163	0.31	0.13	205.08	281	219	46	81	61	-
10	25	163	0.31	0.13	205.58	278	231	46	81	61	-
11	27.5	162	0.32	0.13	206.00*	281	235	46	81	61	-
12	30	162	0.37	0.13	206.57	279	233	46	81	61	-
13	32.5	161	0.30	0.12	207.08	279	237	46	81	61	-
14	35	161	0.32	0.13	207.60	285	240	46	81	61	-
15	37.5	161	0.33	0.14	208.14	284	240	46	81	61	-
16	40	161	0.33	0.14	208.78	286	242	46	81	61	-
17	42.5	159	0.37	0.15	209.25	293	245	46	82	62	-
18	45	160	0.37	0.15	209.79	298	250	46	82	62	-
19	47.5	160	0.38	0.16	210.28	293	252	46	82	62	-
20	50	160	0.40	0.16	210.95	293	252	46	82	62	-
21	52.5	160	0.45	0.19	211.56	277	252	46	82	62	-
22	55	160	0.45	0.19	212.19	285	254	47	82	62	-
23	57.5	159	0.43	0.18	212.70*	297	254	47	82	62	-
24	60	158	0.44	0.18	213.37	301	257	47	82	62	-

MOISTURE FIELD DATA SHEET

Project No.: 121413456
 Client: Northern Dole
 Plant: Lime Kiln
 Location: Pinto, NJ
 Test: PM-83
 Date: July 22nd, 2015
 Analyst: TBA/SF



Moisture Data

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H2O	893.7	658.8	234.9
2	100 mL H2O	708.5	698.8	9.7
3	Blank	666.9	666.7	0.2
4	200g Silica Gel	976.4	971.6	4.8
Total Weight Gain (g)				249.6
Moisture Volume (mL)				

Volume H₂O Collected: 249.6 ml
 X 0.048 = 11.98 ft³ H₂O (Vwc)

DGM Final 240.99 ft³
 DGM Initial 213.63 ft³
 Final - Initial = 27.36 ft³ (Vmc)

Moisture = $\frac{Vwc}{(Vwc + Vmc)}$

Moisture = $\frac{11.98}{36.34}$

Moisture = 0.32 32%

1/2

SOURCE TESTING FIELD DATA SHEET

Job No.: 121413456
 Client: Nucleco Pipe
 Plant: Line Leaks
 Location: Boston, MS
 Test: PM-3
 Date: July 22, 2015
 Operators: TH/SE
 Gamma: 1.033
 Delta H@: 1.717
 Pitot Coeff: 0.816
 Start: 5:10
 Finish: 6:10

Static Pressure (in.H2O): 0.51
 Port Length (in.): 12"
 Stack Dia. (in.): 48"
 Probe Length (ft): 81
 Nozzle ID (in.): 1-6 (0.172)
 Console S/N: 1046

Pre-Test Leak Check:
 Vacuum Pressure: -7.0
 Post-Test Leak Check:
 Vacuum Pressure:

K: 0.78

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dp (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
1	0	158	0.50	0.21	213.63	225	215	54	77	61	-
2	5	159	0.50	0.21	214.95	226	230	52	79	61	-
3	7.5	159	0.49	0.20	215.58	261	230	52	79	61	-
4	10	159	0.49	0.20	216.21	270	228	51	79	61	-
5	12.5	159	0.49	0.16	216.74	273	225	45	80	62	-
6	15	160	0.38	0.16	217.32	282	226	45	80	62	-
7	17.5	160	0.35	0.14	217.87	287	227	45	81	62	-
8	20	160	0.35	0.14	218.40	287	229	45	81	62	-
9	22.5	160	0.30	0.12	218.92	289	229	45	81	62	-
10	25	160	0.28	0.12	219.44	288	235	45	82	62	-
11	27.5	160	0.27	0.11	219.95	288	234	45	82	62	-
12	30	160	0.25	0.10	220.41	286	237	45	82	62	-
13	32.5	161	0.26	0.11	220.91	288	239	45	82	62	-
14	35	161	0.28	0.12	221.41	288	241	45	82	63	-
15	37.5	161	0.29	0.12	221.92	286	240	45	82	63	-
16	40	161	0.30	0.12	222.43	284	241	45	82	63	-
17	42.5	161	0.34	0.14	222.98	283	242	45	82	63	-
18	45	161	0.33	0.14	223.51	279	233	44	83	63	-
19	47.5	161	0.35	0.14	224.07	279	233	44	83	63	-
20	50	160	0.38	0.16	224.77	281	237	44	83	63	-
21	52.5	160	0.39	0.16	225.26	300	241	44	83	63	-
22	55	159	0.41	0.17	225.89	300	242	44	83	63	-
23	57.5	160	0.45	0.19	226.52	299	244	44	80	64	-
24	60	159	0.46	0.19	227.16	300	244	44	80	64	-

50° 30° 25° 15° 5° 0° 5° 15° 5° 0° 15°

42

SOURCE TESTING FIELD DATA SHEET

Job No.: 121413456
 Client: No. 1000 P. 1/P
 Plant: Pine. kin
 Location: P. 1000 MS
 Test: PM-3
 Date: 3-14-2015
 Operators: JH/SF
 Gamma: 1.233
 Delta H@: 1.717
 Pitot Coeff.: 0.816
 Start: 0.12
 Finish: 3.02

Static Pressure (in.H2O): 0.51
 Port Length (in.): 12.11
 Stack Dia. (in.): 4.311
 Probe Length (ft): A1
 Nozzle ID (in.): 1-1/2 (0.1221)
 Console S/N: 1870

Pre-Test Leak Check: _____
 Vacuum Pressure: _____
 Post-Test Leak Check: _____
 Vacuum Pressure: -1.8

K: 0.42

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
1	0	159	0.51	0.21	227.16	249	241	49	81	64	-1
2	2.5	160	0.51	0.21	228.50	253	241	49	81	64	-1
3	4.5	159	0.49	0.20	229.13	266	242	49	81	64	-1
4	10	158	0.49	0.20	229.76	281	241	49	82	64	-1
5	12.5	158	0.42	0.17	230.36	289	241	49	82	64	-1
6	15	158	0.40	0.17	230.90	298	241	44	82	64	-1
7	17.5	157	0.35	0.14	231.49	297	242	44	82	64	-1
8	20	159	0.34	0.14	232.01	297	242	44	82	64	-1
9	22.5	157	0.30	0.12	232.52	301	240	44	82	64	-1
10	25	160	0.28	0.12	233.02	299	241	44	82	64	-1
11	27.5	157	0.25	0.10	233.51	300	240	46	83	64	-1
12	30	159	0.29	0.12	234.01	300	241	46	83	64	-1
13	32.5	159	0.31	0.13	234.52*	299	241	46	83	64	-1
14	35	160	0.32	0.13	235.03	300	244	46	83	64	-1
15	37.5	158	0.37	0.13	235.60	300	246	46	83	64	-1
16	40	158	0.33	0.14	236.18	300	246	47	83	65	-1
17	42.5	157	0.33	0.14	236.70*	301	250	47	83	65	-1
18	45	157	0.39	0.16	237.28	300	250	47	83	65	-1
19	47.5	158	0.40	0.17	237.88	300	251	47	83	65	-1
20	50	158	0.40	0.17	238.50	300	251	47	83	65	-1
21	52.5	158	0.41	0.17	239.10	300	251	47	83	65	-1.5
22	55	158	0.44	0.18	239.75*	300	250	49	83	65	-1.5
23	57.5	157	0.44	0.18	240.35	301	250	49	83	65	-1.5
24	60	158	0.46	0.19	240.99	300	252	49	83	65	-1.5

45°
 35°
 20°
 15°
 5°
 0
 1
 10°
 15°
 24°
 32°
 40°

0716-13

MOISTURE FIELD DATA SHEET

Project No.: 121413456
 Client: Northern P.L.
 Plant: Dissaluna Tank
 Location: Porto NS
 Test: PM-1
 Date: 11.20.2015
 Analyst: JIS/FS



Moisture Data

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
	<u>32.41</u>	<u>725.1</u>	<u>658.0</u>	<u>332.1</u>
1	100 mL H2O	<u>988.1</u>	<u>708.5</u>	<u>279.6</u>
2	100 mL H2O	<u>820.0</u>	<u>743.1</u>	<u>76.9</u>
3	Blank 2	<u>595.1</u>	<u>593.7</u>	<u>1.4</u>
4	200g Silica Gel	<u>953.9</u>	<u>947.1</u>	<u>6.8</u>
Total Weight Gain (g)				<u>694.8</u>
Moisture Volume (mL)				<u>694.8</u>

Volume H₂O Collected: 694.8 ml
 X 0.048 = 33.35 ft³ H₂O (Vwc)

DGM Final 762.79 ft³

DGM Initial 732.77 ft³

Final - Initial = 30.02 ft³ (Vmc)

Moisture = $\frac{Vwc}{(Vwc + Vmc)}$

Moisture = $\frac{33.35}{(33.35 + 30.02)}$

Moisture = 52.6%

SOURCE TESTING FIELD DATA SHEET

Job No.: 171413456
 Client: North Star
 Plant: 171413456
 Location: 171413456
 Test: 171413456
 Date: 171413456
 Operators: 171413456
 Gamma: 1.17
 Delta H₀: 1.713
 Pitot Coeff.: 0.936
 Start: 9:00
 Finish: 10:50

Static Pressure (in.H2O): -0.20
 Port Length (in): 6"
 Stack Dia. (in.): 5"
 Probe Length (ft): 5'
 Nozzle ID (in.): 1-10/16"
 Console S/N: 1343

Pre-Test Leak Check: -1K
 Vacuum Pressure: -0.5
 Post-Test Leak Check: -1K
 Vacuum Pressure: -1

K: 2.23

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
1	0	171	0.10	0.19	732.77	228	261	80	87	87	-1
2	2.5	187	0.10	0.19	733.32	264	266	80	87	87	-1
3	7.5	194	0.15	0.27	734.55	265	273	79	87	87	-1
4	10	184	0.15	0.27	735.25	267	264	77	87	87	-1
5	15	184	0.15	0.29	735.94	263	266	77	87	87	-1
6	18	183	0.15	0.29	736.66	263	268	77	87	87	-1
7	21	183	0.15	0.29	737.37	263	264	77	87	87	-1
8	24	180	0.15	0.29	739.07	267	267	77	87	87	-1
9	27	172	0.10	0.19	736.68	267	263	77	87	87	-1
10	30	181	0.15	0.29	739.37	263	263	77	87	87	-1
11	33	185	0.15	0.29	740.07	263	266	77	87	87	-1
12	36	185	0.15	0.29	740.78	263	268	79	88	87	-1
13	39	193	0.15	0.29	741.47	262	258	73	88	87	-1
14	42	193	0.10	0.19	742.09	262	260	79	88	87	-1
15	45	160	0.10	0.20	742.66	265	266	74	88	88	-1
16	48	174	0.10	0.20	743.26	267	270	74	88	88	-2
17	51	173	0.10	0.19	743.88	263	268	80	88	88	-2
18	54	175	0.10	0.19	744.45	263	268	77	88	88	-2
19	57	175	0.10	0.19	745.04	263	267	77	88	88	-2
20	60	174	0.10	0.19	745.61	263	267	77	88	88	-2

42

SOURCE TESTING FIELD DATA SHEET

Job No.: 11113113
 Client: Asst. Dir. - 11113113
 Plant: Missouri State
 Location: 11113113
 Test: 11113113
 Date: 11/11/11
 Operators: 11113113
 Gamma: 11113113
 Delta H@: 11113113
 Pilot Coeff.: 0.070
 Start: _____
 Finish: _____
 Static Pressure (in.H2O): -0.20
 Port Length (in.): 6"
 Stack Dia. (in.): 4.5"
 Probe Length (ft): 5'
 Nozzle ID (in.): 1/2 (0.50)
 Console S/N: 1924
 Pre-Test Leak Check: _____
 Vacuum Pressure: _____
 Post-Test Leak Check: _____
 Vacuum Pressure: _____
 K': 2.23

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dp (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
1	0				745.61						
	2:05	182	0.09	0.17	746.16	259	252	77	88	88	-1
	5	171	0.08	0.15	746.70	256	267	80	88	88	-1
2	9.5	180	0.10	0.19	747.26	253	267	50	88	88	-1
	10	180	0.10	0.19	747.83	255	267	76	88	88	-1
3	12.5	180	0.13	0.25	748.48	256	266	71	88	88	-1
	15	181	0.13	0.25	749.15	257	264	70	88	88	-2
4	18.5	175	0.12	0.23	749.81	262	265	66	88	88	-2
	20	176	0.12	0.23	750.44	263	264	65	88	88	-2
5	22.5	176	0.13	0.25	751.11	262	266	63	88	88	-2
	25	186	0.14	0.28	751.81	265	266	60	88	88	-2
6	27.5	170	0.17	0.33	752.55	264	265	60	88	88	-2
	30	172	0.25	0.48	753.45	265	266	60	88	88	-2
7	31.5	143	0.28	0.54	754.41	262	266	60	88	88	-2
	35	141	0.30	0.61	755.43	262	269	60	88	88	-2
8	35.5	140	0.33	0.67	756.45	263	270	60	88	88	-2
	40	147	0.33	0.67	757.54	263	267	55	88	88	-2
9	42.5	140	0.35	0.71	758.64	263	267	55	88	88	-2
	45	137	0.50	1.01	759.89	260	260	55	88	88	-2
10	47.5	140	0.70	1.43	761.30	262	266	55	88	88	-2
	50	141	0.70	1.43	762.79	262	267	55	88	88	-2

MOISTURE FIELD DATA SHEET

0226 140

Project No.: 171413466
 Client: Norfolk F.L.
 Plant: Dissolution Tank
 Location: Pictou, NS
 Test: PM-2
 Date: JUL 21 2015
 Analyst: JJZ/PS



Moisture Data

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
		1067.8	656.1	411.7
1	100 mL H2O	919.7	705.9	213.8
2	100 mL H2O	736.6	728.7	7.9
3	Blank	595.9	584.3	1.6
4	200g Silica Gel	964.4	957.4	7.0
Total Weight Gain (g)				642.0
Moisture Volume (mL)				642.0

Volume H₂O Collected: 642.0 ml
 X 0.048 = 30.82 ft³ H₂O (Vwc)

DGM Final 803.17 ft³
 DGM Initial 776.99 ft³
 Final - Initial = 26.18 ft³ (Vmc)

Moisture = $\frac{Vwc}{(Vwc + Vmc)}$

Moisture = $\frac{30.82}{(30.82 + 26.18)}$

Moisture = 0.5418 (54.18%)

SOURCE TESTING FIELD DATA SHEET

Job No.: 120103-156
 Client: AGC
 Plant: 2
 Location: 2
 Test: 2
 Date: 11/10/16
 Operators: AGC
 Gamma: 2
 Delta H@: 2
 Pilot Coeff.: 2
 Start: 17:45
 Finish: 2:25

Static Pressure (in.H2O): -0.20
 Port Length (in.): 6"
 Stack Dia. (in.): 4.5"
 Probe Length (ft): 5'
 Nozzle ID (in.): 1-10 (0.952)
 Console S/N: 184R

Pre-Test Leak Check: -1.5
 Vacuum Pressure: -1.4
 Post-Test Leak Check:
 Vacuum Pressure:

K': 2.40

Traverse Point	Time (min)	Stack Gas Temp., T _s (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
1	0	183	0.15	0.31	776.97	262	264	90	85	85	-1
2	5	188	0.15	0.30	777.73	272	278	86	85	85	-1
3	10	195	0.17	0.34	778.46	270	273	85	85	85	-1
4	15	197	0.17	0.34	779.19	249	267	87	85	85	-1
5	20	198	0.17	0.24	780.64	263	267	79	85	85	-1
6	25	177	0.17	0.25	781.38	263	267	78	85	85	-1
7	30	177	0.16	0.35	782.05	264	266	76	86	86	-1
8	35	195	0.16	0.38	782.77	263	264	75	86	85	-1
9	40	185	0.12	0.24	783.47	263	262	74	86	86	-1
10	45	185	0.12	0.24	784.13	262	265	74	86	86	-1
	50	155	0.17	0.24	784.77	262	263	74	87	86	-1
	55	166	0.10	0.20	785.28	263	263	74	87	86	-1
	60	175	0.10	0.20	786.02	263	268	75	87	86	-2
	65	192	0.10	0.20	786.63	263	267	75	87	86	-2
	70	183	0.10	0.20	787.21	263	266	76	87	86	-2
	75	182	0.11	0.22	787.77	263	264	77	87	86	-2
	80	174	0.10	0.20	788.40	263	267	74	87	86	-2
	85	170	0.12	0.24	789.01	263	267	74	88	86	-2
	90	177	0.12	0.14	789.65	263	264	74	87	86	-2
					790.28	263	263	74	87	86	-2

SOURCE TESTING FIELD DATA SHEET

Job No.: 2013456
 Client: Northwest
 Plant: Water
 Location: Water
 Test: SM-2
 Date: 11.22.05
 Operators: JBF, FS
 Gamma: 1.117
 Delta H@: 1.917
 Pitot Coeff.: 0.536
 Start: _____
 Finish: _____

Static Pressure (in.H2O): 27.20
 Port Length (in.): 6"
 Stack Dia. (in.): 4"
 Probe Length (ft): 5'
 Nozzle ID (in.): 1-10/32
 Console S/N: 2019

Pre-Test Leak Check: -18
 Vacuum Pressure: -18
 Post-Test Leak Check: _____
 Vacuum Pressure: _____

K: 2.120

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
1	0				790.28						
	2.5	181	0.12	0.24	790.92	263	266	76	88	87	-0
	5	190	0.12	0.24	791.55	263	270	75	88	85	-0
	7.5	175	0.12	0.24	792.18	263	271	72	87	85	-0
	10	179	0.12	0.24	792.81	263	270	72	88	87	-0
	12.5	140	0.13	0.27	793.50	263	261	72	88	87	-0
	15	178	0.13	0.27	794.17	263	267	70	88	85	-0
	17.5	179	0.13	0.27	794.84	263	267	69	88	87	-0
	20	183	0.13	0.27	795.47	263	264	68	88	88	-0
	22.5	147	0.13	0.27	796.17	263	264	67	88	88	-0
	25	140	0.11	0.23	796.84	263	267	68	88	88	-0
	27.5	169	0.11	0.23	797.47	263	265	68	88	88	-0
	30	180	0.11	0.23	798.11	263	271	69	88	88	-0
	32.5	140	0.11	0.23	798.74	263	266	69	88	88	-0
	35	180	0.11	0.23	799.36	264	263	69	88	88	-0
	37.5	179	0.10	0.21	799.97	263	261	70	88	88	-0
	40	140	0.10	0.21	800.58	263	265	71	88	88	-0
	42.5	141	0.10	0.21	801.18	263	264	70	88	88	-0
	45	143	0.10	0.21	801.80	263	265	70	88	88	-0
	47.5	179	0.13	0.27	802.50	264	269	71	88	88	-0
	50	170	0.13	0.27	803.17	263	266	71	88	88	-0

MOISTURE FIELD DATA SHEET

Project No.: 121413156
 Client: Northco. Pitt.
 Plant: Johnson Fork
 Location: Blk. 2 NC
 Test: PM-3
 Date: NOV 20 2015
 Analyst: VT/ES



Moisture Data

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
	Blank 1	1064.6	285.4	409.2
1	100 mL H2O	491.0	703.0	188.0
2	100 mL H2O	740.0	733.5	6.5
3	Blank 2	595.0	594.1	0.9
4	200g Silica Gel	981.1	975.5	5.6
Total Weight Gain (g)				610.2
Moisture Volume (mL)				610.2

Volume H₂O Collected: 610.2 ml
 X 0.048 = 29.29 ft³ H₂O (Vwc)

DGM Final 831.67 ft³
 DGM Initial 803.66 ft³
 Final - Initial = 28.01 ft³ (Vmc)

Moisture = $\frac{Vwc}{(Vwc + Vmc)}$

Moisture = $\frac{29.29}{(29.29 + 28.01)}$

Moisture = 0.511 51.1%

SOURCE TESTING FIELD DATA SHEET

Job No.: 171413456
 Client: Northern Fork
 Plant: Dissolving Tank
 Location: Bataan, NC
 Test: DM-3
 Date: 2/13/2016
 Operators: JTS/LFS
 Gamma: 1.117
 Delta H@: 1.717
 Plot Coeff.: 0.536
 Start: 3:55
 Finish: 5:40

Static Pressure (in.H2O): -0.20
 Port Length (in.): 6"
 Stack Dia. (in.): 4.8"
 Probe Length (ft): 5'
 Nozzle ID (in.): 1/16 (0.3125)
 Console S/N: 12,98

Pre-Test Leak Check: -12
 Vacuum Pressure: -18
 Post-Test Leak Check:
 Vacuum Pressure:
 K': 2.4

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
	0				803.66						
	3.5	170	0.10	0.21	804.26	246	275	81	86	86	-1
	5	169	0.10	0.21	804.85	262	262	76	86	86	-1
	7.5	170	0.10	0.21	805.43	263	264	75	86	86	-1
	10	170	0.10	0.21	806.01	263	264	74	86	86	-1
	12.5	171	0.12	0.25	806.67	263	267	73	86	86	-1
	15	168	0.12	0.25	807.32	265	267	73	86	86	-1
	17.5	170	0.12	0.25	807.98	264	265	72	87	87	-1
	20	171	0.13	0.27	808.67	263	264	71	87	86	-1
	22.5	170	0.13	0.27	809.35	265	267	71	87	86	-1
	25	171	0.13	0.27	810.04	263	266	70	87	87	-1
	27.5	171	0.13	0.27	810.72	263	265	70	87	87	-1
	30	170	0.13	0.27	811.42	263	267	69	87	87	-1
	32.5	170	0.13	0.27	812.11	265	264	68	87	87	-1
	35	170	0.13	0.27	812.80	263	268	67	87	87	-1
	37.5	172	0.15	0.31	813.51	263	265	67	86	87	-1
	40	171	0.15	0.31	814.29	263	267	67	88	87	-1
	42.5	171	0.15	0.31	815.04	263	265	66	88	87	-1
	45	172	0.15	0.31	815.78	265	268	66	88	87	-1
	47.5	172	0.15	0.31	816.52	263	268	66	88	87	-1
	50	172	0.13	0.27	817.24	265	266	66	88	87	-1

SOURCE TESTING FIELD DATA SHEET

Job No.: 121413456
 Client: Deshon P.I.
 Plant: Deshon Tool
 Location: Patuxent
 Test: DFTS
 Date: July 20, 2015
 Gamma: 1117
 Delta H@: 1.717
 Pilot Coeff.: 0.636
 Start: _____
 Finish: _____

Static Pressure (in.H2O): 0.20
 Port Length (in.): 6"
 Stack Dia. (in.): 58"
 Probe Length (ft): 0
 Nozzle ID (in.): 1-0.60302
 Console SIN: 4348

Pre-Test Leak Check: _____
 Vacuum Pressure: 1.9
 Post-Test Leak Check: _____
 Vacuum Pressure: _____

K: 214

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
1	0				817.24						
2	2.5	173	0.13	0.27	817.96	262	267	67	88	87	-2
3	5	173	0.13	0.27	818.66	262	265	67	88	87	-2
4	7.5	172	0.13	0.27	819.35	263	268	68	89	88	-2
5	10	171	0.13	0.27	820.05	264	265	68	89	88	-2
6	12.5	172	0.14	0.29	820.76	263	268	68	89	88	-2
7	15	172	0.14	0.29	821.47	263	268	68	89	88	-2
8	17.5	173	0.14	0.29	822.17	263	267	69	89	88	-2
9	20	172	0.15	0.31	822.88	263	266	69	89	88	-2
10	22.5	171	0.15	0.31	823.68	263	265	69	89	88	-2
11	25	171	0.15	0.31	824.42	263	266	68	89	88	-2
12	27.5	175	0.15	0.31	825.16	263	266	68	89	88	-2
13	30	177	0.15	0.31	825.91	263	264	69	89	88	-2
14	32.5	177	0.15	0.31	826.64	263	269	69	89	88	-2
15	35	178	0.15	0.31	827.37	262	265	69	89	88	-2
16	37.5	175	0.15	0.31	828.09	264	267	69	89	88	-2
17	40	176	0.15	0.31	828.82	264	264	69	89	88	-2
18	42.5	174	0.13	0.27	829.55	263	267	69	89	88	-2
19	45	173	0.13	0.27	830.26	264	264	69	89	88	-2
20	47.5	174	0.13	0.27	830.97	263	264	69	89	88	-2
21	50	174	0.13	0.27	831.67	263	266	68	89	88	-2

MOISTURE FIELD DATA SHEET

03-1-2018
0 14-1-2018

Project No.: 121413456
 Client: Northern P/L
 Plant: Dumoyne Bore
 Location: Pittman NS
 Test: PM-1
 Date: 11-23-2018
 Analyst: JJE/SS



Moisture Data

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
	Blank 1	0.61	654.7	11.8
1	100 mL H2O	757.3	700.1	57.2
2	100 mL H2O	743.6	732.7	10.9
3	Blank 2	596.1	593.9	2.2
4	200g Silica Gel	492.0	981.0	11
Total Weight Gain (g)				393.1
Moisture Volume (mL)				393.1

Volume H₂O Collected: 393.1 ml
 X 0.048 = 18.87 ft³ H₂O (Vwc)

DGM Final 879.23 ft³
 DGM Initial 897.33 ft³
 Final - Initial = 45.9 ft³ (Vmc) $\frac{18.87}{13.87 + 45.9}$

Moisture = $\frac{Vwc}{(Vwc + Vmc)}$

Moisture = 29.1%

Moisture = 29.1%

SOURCE TESTING FIELD DATA SHEET

Job No.: 21412456
 Client: Aluminum Plant
 Plant: Leavenworth, Kansas
 Location: Plant
 Test: 1
 Date: 11/19/15
 Operators: 1115
 Gamma: 1.313
 Delta H@: 0.221
 Pitot Coeff.: 0.95
 Start: 11:45
 Finish: 11:55

Static Pressure (in.H2O): 1.10
 Port Length (in.): 6"
 Stack Dia. (in.): 15.25"
 Probe Length (ft): 21
 Nozzle ID (in.): 1-87.0.2341
 Console S/N: 1000

Pre-Test Leak Check: -18
 Vacuum Pressure: -18
 Post-Test Leak Check: -18
 Vacuum Pressure: -18

K': 1.61

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
1	0	150	0.42	0.60	833.53	259	270	63	67	57	-
2	5	149	0.42	0.58	835.30	264	265	62	67	68	-1
3	10	149	0.42	0.58	836.07	262	266	62	70	68	-1
4	15	149	0.42	0.58	837.73	265	266	64	71	69	-1
5	20	150	0.41	0.57	838.20	262	270	64	71	69	-1
6	25	149	0.41	0.57	839.17	259	260	65	72	69	-1
7	30	150	0.41	0.57	840.12	260	259	64	72	69	-1
8	35	150	0.41	0.57	841.07	262	266	59	73	70	-1
9	40	150	0.41	0.57	842.04	262	268	58	73	71	-1
10	45	150	0.41	0.57	843.01	262	264	57	74	71	-1
11	50	150	0.41	0.57	843.95	262	265	57	74	71	-1
12	55	150	0.41	0.57	844.92	263	265	55	74	71	-1
13	60	150	0.41	0.58	845.89	267	274	55	75	71	-1
14	65	149	0.41	0.59	846.84	263	258	54	75	72	-1
15	70	150	0.41	0.58	847.85	263	258	53	75	72	-1
16	75	150	0.41	0.58	848.87	264	267	53	75	72	-1
17	80	151	0.41	0.58	849.80	267	265	53	76	71	-1
18	85	150	0.41	0.58	850.83	261	261	53	76	72	-1
19	90	150	0.41	0.58	851.75	262	258	53	76	72	-1
20	95	150	0.41	0.58	852.70	260	260	53	77	72	-1
21	100	150	0.41	0.58	853.68	260	260	53	77	72	-1
22	105	150	0.41	0.58	854.60	262	260	53	77	72	-1
23	110	150	0.41	0.58	855.52	262	262	53	77	72	-1
24	115	150	0.41	0.58	856.51	262	262	53	77	72	-1

SOURCE TESTING FIELD DATA SHEET

Job No.: 1101546
Client: 1101546
Plant: 1101546
Location: 1101546
Test: 1101546
Date: 11/17/2015
Operators: 1101546
Gamma: 1101546
Delta H@: 1101546
Pilot Coeff.: 1101546
Start: _____
Finish: _____

Static Pressure (in.H2O): 1.10
Port Length (in.): 6.0
Stack Dia. (in.): 17.8
Probe Length (ft): 2
Nozzle ID (in.): 1.610 (3.0)
Console S/N: 1101546

Pre-Test Leak Check: -18"
Vacuum Pressure: -18
Post-Test Leak Check: _____
Vacuum Pressure: _____
K: 1.61

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
	0				856.58						
	2.5	150	0.40	0.56	857.55	767	259	53	77	73	-1
	5	150	0.40	0.56	859.22	765	262	53	77	73	-1
	7.5	150	0.40	0.56	859.93	767	265	59	74	73	-1
	10	150	0.40	0.56	859.89	263	264	59	74	73	-
	12.5	149	0.41	0.58	860.87	260	271	58	73	74	-
	15	149	0.41	0.58	861.85	261	272	58	73	74	-1
	17.5	150	0.41	0.58	862.79	262	281	58	75	74	-1
	20	150	0.41	0.58	863.75	264	284	58	76	74	-2
	22.5	150	0.41	0.58	864.74	265	285	58	76	74	-6
	25	150	0.41	0.58	865.74	267	287	58	76	74	-3
	27.5	150	0.41	0.58	866.72	264	289	58	76	74	-2
	30	150	0.41	0.58	867.69	269	273	58	76	71	-1
	32.5	150	0.41	0.58	868.67	263	271	59	77	75	-1
	35	150	0.41	0.58	869.66	263	269	59	77	75	-1
	37.5	149	0.40	0.56	870.64	263	267	60	77	75	-1
	40	149	0.40	0.56	871.58	263	276	60	77	75	-1
	42.5	150	0.40	0.56	872.53	263	265	61	78	75	-1
	45	150	0.40	0.56	873.47	267	270	61	78	76	-1
	47.5	150	0.40	0.56	874.41	262	262	59	78	76	-1
	50	150	0.41	0.58	875.40	262	263	59	78	75	-1
	52.5	150	0.41	0.58	876.35	265	263	59	78	75	-1
	55	150	0.41	0.58	877.30	264	260	58	78	75	-1
	57.5	150	0.41	0.58	878.26	261	272	57	78	75	-1
	60	150	0.41	0.58	879.23	262	257	56	78	76	-1

MOISTURE FIELD DATA SHEET

Project No.: 5143456
 Client: Weather Plus
 Plant: Recovery Center
 Location: Clinton MS
 Test: 411-2
 Date: 12/03/18
 Analyst: JRP/ESS



Moisture Data

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
		1034.3	636.6	377.7
1	100 mL H2O	746.9	700.3	46.6
2	100 mL H2O	733.2	726.3	6.9
3	Blank	575.3	543.4	1.4
4	200g Silica Gel	1002.2	991.4	10.8
Total Weight Gain (g)				443.4
Moisture Volume (mL)				443.4

Volume H₂O Collected: 443.4 ml
 X 0.048 = 21.28 ft³ H₂O (Vwc)

DGM Final 931.70 ft³
 DGM Initial 729.67 ft³
 Final - Initial = 51.93 ft³ (Vmc)

Moisture = $\frac{Vwc}{(Vwc + Vmc)}$

Moisture = $\frac{21.28}{(21.28 + 51.93)}$

Moisture = 0.291 = 29.1%

1/2

SOURCE TESTING FIELD DATA SHEET

Job No.: 171413-156
Client: Well...
Plant: Coastal...
Location: ...
Test: ...
Date: 11/23/2003
Gamma: 1117
Delta H@: 1.517
Pilot Coeff.: 0.534
Start: 10:00
Finish: 3:20

Static Pressure (in.H2O): 110
Port Length (in.): 6"
Stack Dia. (in.): 13"
Probe Length (ft): 21'
Nozzle ID (in.): 1-8 (0.75")
Console S/N: 1558

Pre-Test Leak Check: -1%
Vacuum Pressure: -1%
Post-Test Leak Check:
Vacuum Pressure:

K': 1.68

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dp (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
1	0	150	0.45	0.66	879.47	225	232	57	76	76	-1
	2.5	150	0.43	0.63	880.50	247	231	55	77	76	-1
	5	150	0.43	0.63	882.52	262	231	50	77	76	-1
	7.5	150	0.43	0.63	883.52	262	237	50	77	75	-1
2	10	150	0.42	0.62	884.51	263	248	48	79	77	-1
	12.5	150	0.42	0.62	885.53	261	246	48	79	77	-1
	15	150	0.42	0.62	886.55	261	248	48	79	77	-1
	17.5	150	0.42	0.62	887.55	261	257	50	80	78	-1
	20	150	0.42	0.62	888.56	261	260	50	80	78	-1
	22.5	151	0.42	0.62	889.57	263	261	51	81	78	-1
	25	150	0.42	0.62	890.59	261	261	51	81	78	-1
	27.5	150	0.41	0.61	891.61	263	257	52	81	79	-1
3	30	150	0.41	0.61	892.60	262	251	52	82	79	-1
	32.5	150	0.41	0.61	893.60	262	257	52	82	79	-1
	35	150	0.41	0.61	894.62	263	264	53	82	79	-1
	37.5	150	0.42	0.62	895.63	260	271	53	83	80	-1
4	40	150	0.42	0.62	896.63	267	273	53	83	80	-1
	42.5	151	0.42	0.62	897.63	265	267	53	83	80	-1
	45	151	0.42	0.62	898.64	265	269	53	83	80	-1
10	47.5	150	0.42	0.62	899.65	263	242	53	83	80	-1
	50	150	0.41	0.61	900.66	261	260	53	83	80	-1
	52.5	150	0.41	0.61	901.72	261	260	53	83	80	-1
	55	150	0.43	0.64	902.79	264	258	54	83	81	-1
17	57.5	150	0.43	0.64	903.81	264	242	54	83	81	-1
	60	150	0.43	0.64	903.81	265	237	54	83	81	-1

SOURCE TESTING FIELD DATA SHEET

Job No.: 121413466
 Client: North - Platts
 Plant: Resource Park
 Location: Platts, NC
 Test: PM 2
 Date: 11/28/2014
 Operators: 1117
 Gamma: 1.717
 Delta H₀: 0.794
 Pitot Coeff.: 0.794
 Start: _____
 Finish: _____

Static Pressure (in.H₂O): -0.70
 Port Length (in): 6.1
 Stack Dia. (in.): 13.84
 Probe Length (ft): 71
 Nozzle ID (in.): 1.8 (0.330)
 Console S/N: 1846

Pre-Test Leak Check: _____
 Vacuum Pressure: _____
 Post-Test Leak Check: _____
 Vacuum Pressure: _____

K': 1.68

Traverse Point	Time (min)	Stack Gas Temp., T _s (F)	Velocity Head, dP (in.H ₂ O)	Orifice dH (in.H ₂ O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
1	0	151	0.44	0.66	903.81	265	253	54	53	51	-1
	2.5	151	0.50	0.66	904.86	263	247	54	53	51	-1
	5	149	0.45	0.67	906.06	263	252	54	53	51	-1
2	7.5	150	0.45	0.67	907.93	262	254	54	50	50	-1
	10	150	0.45	0.67	908.91	262	250	54	50	50	-1
3	12.5	150	0.50	0.75	909.97	261	227	54	50	79	-1
	15	149	0.50	0.75	911.02	262	237	54	50	79	-1
	17.5	149	0.52	0.75	912.12	262	249	54	79	79	-1
4	20	151	0.44	0.67	913.17	262	252	54	79	79	-1
	22.5	150	0.44	0.66	914.24	263	255	54	79	79	-1
	25	150	0.37	0.55	915.28	264	238	54	79	79	-1
5	27.5	150	0.51	0.76	916.38	263	242	54	79	79	-1
	30	150	0.63	0.94	917.61	263	251	54	79	79	-1
	32.5	150	0.74	1.10	918.92	263	264	53	90	78	-1
6	35	149	0.70	0.93	921.44	261	268	50	50	79	-2
	37.5	149	0.62	0.81	922.62	263	267	50	50	79	-2
	40	150	0.60	0.89	923.82	263	260	50	50	79	-2
7	42.5	149	0.70	1.04	925.13	263	266	52	80	79	-2
	45	149	0.79	1.17	926.48	261	263	52	80	79	-2
	47.5	149	0.90	1.34	927.92	263	263	52	80	79	-2
8	50	150	0.70	1.04	929.23	263	260	52	80	79	-2
	52.5	150	0.62	0.81	930.29	263	267	52	80	79	-2
	55	150	0.51	0.62	931.30	261	254	52	80	79	-2
	57.5	150	0.42	0.62				52	80	79	-2
	60	150	0.42	0.62				52	80	79	-2

MOISTURE FIELD DATA SHEET

Project No.: 121113156
 Client: Northco P.L.C.
 Plant: Re. 0000000000
 Location: Potomac, MS
 Test: PM-3
 Date: Jul. 23, 2015
 Analyst: WJB/FS



Moisture Data

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
	<u>Blank 1</u>	<u>1058.2</u>	<u>655.2</u>	<u>383.6</u>
1	100 mL H2O	<u>871.7</u>	<u>697.6</u>	<u>174.1</u>
2	100 mL H2O	<u>738.5</u>	<u>726.1</u>	<u>12.2</u>
3	Blank 2	<u>597.8</u>	<u>595.0</u>	<u>2.8</u>
4	200g Silica Gel	<u>924.1</u>	<u>910.1</u>	<u>14</u>
Total Weight Gain (g)				<u>586.7</u>
Moisture Volume (mL)				

Volume H₂O Collected: _____ ml
 X 0.048 = _____ ft³ H₂O (Vwc)

DGM Final _____ ft³
 DGM Initial _____ ft³
 Final - Initial = _____ ft³ (Vmc)

Moisture = $\frac{Vwc}{(Vwc + Vmc)}$

Moisture = _____

Moisture = _____

SOURCE TESTING FIELD DATA SHEET

Job No.: 171513486
 Client: North Fork
 Plant: Recycled Paper
 Location: S. Fork
 Test: PAI-3
 Date: 11/26/08
 Operators: JJE/ES
 Gamma: 117
 Delta H θ : 1.77
 Pilot Coeff: 0.794
 Start: 8:12
 Finish: 10:17

Static Pressure (in. H₂O): 0.210
 Port Length (in.): 2.83
 Stack Dia. (in.): 2.83
 Probe Length (ft): 2.83
 Nozzle ID (in.): 1-8/32
 Console S/N: 1848

Pre-Test Leak Check: -18
 Vacuum Pressure: -18
 Post-Test Leak Check: -18
 Vacuum Pressure: -18
 K: 0.68

Traverse Point	Time (min)	Stack Gas Temp., T _s (F)	Velocity Head, dP (in. H ₂ O)	Grillce dH (in. H ₂ O)	Gas Meter Volume (cu. ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in. Hg)
									In	Out	
1	0	154	0.60	0.88	937.11	263	249	70	69	69	-1
2	7.5	154	0.63	0.91	935.56	263	267	56	69	69	-1
3	10	155	0.63	0.91	937.04	263	265	55	69	69	-1
4	12.5	154	0.62	0.90	938.27	263	266	51	71	69	-1
5	15	154	0.62	0.90	939.49	263	264	50	71	69	-1
6	17.5	154	0.62	0.90	940.72	263	264	49	71	69	-1
7	20	154	0.62	0.90	941.75	263	265	48	74	70	-1
8	22.5	154	0.62	0.90	943.17	263	263	48	74	71	-1
9	25	155	0.62	0.90	944.42	263	265	48	74	71	-1
10	27.5	155	0.62	0.90	945.64	263	265	51	74	71	-1
11	30	154	0.62	0.90	946.86	263	265	51	75	71	-1
12	32.5	154	0.62	0.90	948.06	263	264	51	75	72	-1
13	35	155	0.62	0.90	949.29	262	266	51	75	72	-1
14	37.5	155	0.62	0.90	950.51	262	265	52	75	72	-1
15	40	155	0.62	0.90	951.74	264	264	52	75	73	-1
16	42.5	155	0.61	0.88	952.98	263	265	52	75	72	-1
17	45	155	0.61	0.88	954.20	264	266	52	75	72	-1
18	47.5	154	0.61	0.88	955.42	263	266	53	75	72	-1
19	50	154	0.61	0.88	956.65	263	266	53	75	72	-1
20	52.5	155	0.60	0.89	957.87	262	265	53	75	72	-1
21	55	155	0.61	0.89	959.08	263	264	53	76	73	-1
22	57.5	155	0.60	0.89	960.30	263	265	54	76	73	-1
23	60	155	0.60	0.89	961.54	262	265	54	76	73	-1

SOURCE TESTING FIELD DATA SHEET

Job No.: 171413456
 Client: Muller's Pub
 Plant: Vegetary Riser
 Location: 215
 Test: PM-3
 Date: 11/21/2015
 Operators: ASR/FS
 Gamma: 117
 Delta H₀: 1.717
 Pilot Coeff.: 0.714
 Start: _____
 Finish: 10:17

Static Pressure (in.H2O): 1.030
 Port Length (in): 6'
 Stack Dia. (in.): 7.88"
 Probe Length (ft): 2'
 Nozzle ID (in.): 1.8 (0.75")
 Console S/N: 1942

Pre-Test Leak Check: 1.8
 Vacuum Pressure: 1.5
 Post-Test Leak Check: _____
 Vacuum Pressure: _____
 K: 1.68

Traverse Point	Time (min)	Stack Gas Temp., T _s (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
1	0	154	0.61	0.87	961.54	263	266	56	75	73	-1
	2.5	154	0.61	0.87	962.76	263	265	56	75	73	-1
	5	154	0.60	0.88	964.00	263	266	57	75	73	-1
2	7.5	155	0.61	0.88	965.71	263	265	55	75	73	-1
	10	155	0.60	0.88	966.43	263	265	55	75	73	-1
	12.5	154	0.60	0.88	967.66	263	265	55	75	73	-1
	15	154	0.60	0.88	968.87	263	265	55	75	73	-1
	17.5	154	0.60	0.87	970.09	263	265	47	75	73	-1
	20	154	0.61	0.87	971.30	264	264	47	75	73	-1
	22.5	154	0.60	0.88	972.51	263	265	47	75	73	-1
	25	155	0.60	0.87	973.77	262	265	46	75	73	-1
	27.5	156	0.60	0.87	974.99	262	265	46	75	73	-1
	30	156	0.60	0.87	976.20	265	265	46	75	73	-1
	32.5	156	0.60	0.87	977.41	265	266	46	75	73	-1
	35	156	0.60	0.87	978.62	265	266	46	75	73	-1
	37.5	156	0.60	0.87	979.83	265	266	46	75	73	-1
	40	154	0.62	0.89	981.05	263	264	49	75	73	-2
9	42.5	154	0.62	0.91	982.27	263	264	49	75	73	-2
	45	154	0.62	0.91	983.57	263	264	49	75	73	-2
	47.5	154	0.60	0.90	984.76	263	264	49	75	73	-2
	50	154	0.60	0.87	985.98	263	264	49	75	73	-2
	52.5	154	0.60	0.87	987.19	263	264	49	75	73	-2
	55	154	0.60	0.87	988.39	263	264	49	75	73	-2
	57.5	155	0.60	0.87	989.61	263	264	49	75	73	-2
	60	155	0.60	0.87	990.82	263	264	49	75	73	-2

MOISTURE FIELD DATA SHEET

Project No.: 121413456
 Client: Northern Pulp
 Plant: Power Boilers
 Location: Pictou, NS
 Test: PM-1
 Date: 23rd July 15
 Analyst: TBH / SF



Moisture Data

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H ₂ O	812.4	656.2	155.9
2	100 mL H ₂ O	729.2	696.8	32.4
3	Blank	668.7	665.2	3.5
4	200g Silica Gel	986.9	975.0	11.9
Total Weight Gain (g)				203.7
Moisture Volume (mL)				

Volume H₂O Collected: 203.7 ml
 X 0.048 = 9.78 ft³ H₂O (Vwc)

DGM Final 296.38 ft³
 DGM Initial 241.26 ft³
 Final - Initial = 55.22 ft³ (Vmc)

Moisture = $\frac{Vwc}{(Vwc + Vmc)}$

Moisture = $\frac{9.78}{9.78 + 55.22}$

Moisture = 15.7%

42

SOURCE TESTING FIELD DATA SHEET

Job No.: 121413456
 Client: Northco Pump
 Plant: Power Boiler
 Location: Pickens, MS
 Test: PA-1
 Date: July 23, 2015
 Operators: TSH/SF
 Gamma: 1.233
 Delta H₀: 1.712
 Plot Coeff.: 0.816
 Start: 9:42
 Finish: 10:42

Static Pressure (In.H2O): 0.10
 Port Length (In.): 6.11
 Stack Dia. (In.): 72.11
 Probe Length (ft): 81
 Nozzle ID (In.): 1.6 (2172)
 Console S/N: 1646

Pre-Test Leak Check: _____
 Vacuum Pressure: _____
 Post-Test Leak Check: _____
 Vacuum Pressure: _____

K': 0.62

Transpose Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dp (In.H2O)	Orifice dH (In.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (In.Hg)
									In	Out	
0	0				241.76						
1	2.5	137	0.85	0.48	242.23	289	235	62	92	67	-1
2	5	128	0.80	0.46	243.10*	300	245	62	95	64	-1
3	7.5	132	0.80	0.45	244.12	299	246	58	95	64	-1.5
4	10	132	0.89	0.50	245.18	301	251	58	95	64	-2
5	12.5	131	0.97	0.55	246.23	300	254	54	96	64	-2
6	15	130	0.93	0.53	247.23	300	253	54	96	64	-2
7	17.5	131	0.90	0.50	248.21	294	250	54	96	64	-2
8	20	129	0.95	0.53	249.22	302	253	54	98	65	-2
9	22.5	129	0.91	0.50	250.22	301	254	54	98	65	-2
10	25	126	0.90	0.50	251.24	299	260	54	99	65	-2
11	27.5	124	0.88	0.49	252.23	300	260	54	99	66	-2
12	30	124	0.88	0.49	253.22	297	263	54	99	66	-2
13	32.5	124	0.90	0.50	254.23	299	264	54	99	66	-2
14	35	125	0.88	0.49	255.22	295	261	55	70	67	-2
15	37.5	128	0.96	0.53	256.25	288	261	55	70	67	-2
16	40	128	0.99	0.55	257.27	299	258	55	70	67	-2
17	42.5	129	1.20	0.67	258.47	301	253	55	70	67	-2
18	45	128	1.10	0.61	259.55	299	255	55	70	67	-2
19	47.5	130	1.40	0.78	260.78	300	253	55	70	67	-2
20	50	131	1.35	0.75	261.99	289	256	55	70	67	-2
21	52.5	130	1.60	0.89	263.30*	297	260	55	70	67	-2
22	55	129	1.60	0.89	264.603	300	262	58	73	69	-2
23	57.5	130	1.60	0.89	265.90	299	257	58	73	69	-2
24	60	133	1.50	0.83	267.24	297	255	58	73	69	-2

2/2

SOURCE TESTING FIELD DATA SHEET

Job No.: 121413456
 Client: Weather Corp
 Plant: Power Boiler
 Location: Portsmouth, NS
 Test: PM-1
 Date: July 28, 2015
 Operators: PH/SF
 Gamma: 1.033
 Delta Hg: 1.712
 Pilot Coeff.: 0.816
 Start: 10:51
 Finish: 11:51

Static Pressure (in.H2O): 0.20
 Port Length (in.): 6"
 Stack Dia. (in.): 7.11
 Probe Length (ft): 8'
 Nozzle ID (in.): 1-0.0172
 Console S/N: 1646

Pre-Test Leak Check:
 Vacuum Pressure: _____
 Post-Test Leak Check:
 Vacuum Pressure: -19

K: 0.162

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dp (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
1	0	131	1.40	0.78	267.24	187	267	64	70	70	-2
2	5	130	1.40	0.78	269.64	297	264	60	71	70	-2
3	7.5	129	1.35	0.75	270.87	300	265	51	71	70	-2
4	10	129	1.40	0.78	272.07	300	260	51	72	71	-2
5	12.5	128	1.30	0.73	273.25	300	268	48	72	69	-3
6	15	132	1.28	0.69	274.41	300	268	48	72	69	-3
7	17.5	132	1.20	0.67	275.56	300	268	47	72	69	-3
8	20	131	1.20	0.67	276.71	300	270	47	72	69	-3
9	22.5	129	1.10	0.61	277.83	300	267	47	72	69	-3
10	25	130	1.05	0.59	278.90	300	267	47	72	69	-3
11	27.5	129	1.10	0.61	280.01	300	268	47	72	69	-3
12	30	129	1.10	0.61	281.17	301	266	47	72	69	-3
13	32.5	137	1.20	0.67	282.27	299	266	48	72	69	-3
14	35	130	1.25	0.70	283.47	299	266	48	73	70	-3
15	37.5	129	1.30	0.73	284.66	300	267	48	73	70	-3
16	40	128	1.35	0.76	285.87	300	268	48	73	70	-3
17	42.5	128	1.40	0.78	287.09	300	267	48	73	70	-3
18	45	129	1.40	0.78	288.31	299	268	48	73	70	-3
19	47.5	128	1.40	0.78	289.62	300	271	49	74	71	-3
20	50	128	1.38	0.76	290.94	300	271	49	74	71	-3
21	52.5	127	1.30	1.01	292.25*	300	269	49	74	71	-3
22	55	126	1.25	0.95	293.90*	300	271	49	74	71	-3
23	57.5	126	1.20	0.90	295.17	300	270	49	74	71	-3
24	60	127	1.20	0.84	296.48	299	271	49	74	71	-3

MOISTURE FIELD DATA SHEET

Project No.: 121413456
 Client: Norfolk Pulp
 Plant: Power Boiler
 Location: Princeton, NJ
 Test: PM-2
 Date: July 23, 2015
 Analyst: JGH



Moisture Data

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H2O	883.6	666.4	217.2
2	100 mL H2O	741.5	715.3	26.2
3	Blank	668.9	666.1	2.8
4	200g Silica Gel	1037.2	1025.6	11.6
Total Weight Gain (g)				257.8
Moisture Volume (mL)				

Volume H₂O Collected: 257.8 ml
 X 0.048 = 12.37 ft³ H₂O (Vwc)

DGM Final 352.41 ft³
 DGM Initial 296.72 ft³
 Final - Initial = 55.69 ft³ (Vmc)

Moisture = $\frac{Vwc}{(Vwc + Vmc)}$

Moisture = $\frac{12.37}{68.06}$

Moisture = 0.18 32%

1/2

SOURCE TESTING FIELD DATA SHEET

Job No.: 121413456
 Client: Northwest Pulp
 Plant: Powder Mill
 Location: Fulton MS
 Test: PM-2
 Date: 1-14-2015
 Operators: THH/SE
 Gamma: 1.033
 Delta H₀: 0.810
 Pitot Coeff.: 0.810
 Start: 13:25
 Finish: 14:25

Static Pressure (in.H₂O): 0.20
 Port Length (in.): 6.4
 Stack Dia. (in.): 7.2
 Probe Length (ft): 8
 Nozzle ID (in.): 1.70 (0.192)
 Console S/N: 11046

Pre-Test Leak Check:
 Vacuum Pressure: -18
 Post-Test Leak Check:
 Vacuum Pressure: -18

K: 0.62

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dp (in.H ₂ O)	Orifice dH (in.H ₂ O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
1	0	136	1.50	0.823	296.77	256	250	72	71	71	-1
2	5	137	1.60	0.88	298.01	295	261	69	72	71	-1
	2.5	137	1.40	0.27	300.60*	300	267	63	72	71	-1
3	10	137	1.50	0.83	301.80	300	271	57	72	71	-1
	12.5	134	1.30	0.77	303.00*	300	273	54	72	71	-1
4	15	134	1.30	0.77	304.21	300	275	50	72	71	-3
	17.5	135	1.25	0.69	305.41	300	276	50	72	71	-3
5	20	134	1.25	0.69	306.52	300	280	48	72	71	-3
	22.5	135	1.20	0.66	307.60	300	279	48	72	70	-3
6	25	136	1.20	0.66	308.79	300	282	48	72	70	-3
	27.5	135	1.15	0.64	309.91	300	284	48	72	70	-3
7	30	137	1.20	0.66	311.06	300	286	47	74	71	-3
	32.5	138	1.15	0.63	312.16	300	288	48	74	71	-3
8	35	135	1.10	0.61	313.26	287	286	47	74	71	-3
	37.5	137	1.05	0.58	314.34	297	285	47	74	71	-3
9	40	137	1.05	0.58	315.37	299	282	48	75	72	-3
	42.5	137	1.20	0.60	316.54	300	289	48	75	72	-3
10	45	135	1.15	0.64	317.69	300	287	48	75	72	-3
	47.5	136	1.10	0.78	319.08	299	286	48	75	72	-3
11	50	137	1.10	0.77	320.07	299	291	48	75	72	-3
	52.5	134	1.20	0.73	321.27	299	290	48	77	73	-3
12	55	134	1.50	0.84	322.54	291	292	48	77	73	-3
	57.5	137	1.80	1.00	323.93	297	291	48	77	73	-3
60	135	1.75	1.08	325.31	293	293	48	77	73	-3	

42

SOURCE TESTING FIELD DATA SHEET

Job No.: 121413454
 Client: Northern Pipe
 Plant: Power & Gas
 Location: Pictou, NS
 Test: P.M. 2
 Date: Jan 23, 2015
 Operators: JH/GE
 Gamma: 1.33
 Delta H₀: 1.712
 Pilot Coeff.: 0.816
 Start: 14:40
 Finish: 16:40

Static Pressure (in.H2O): 0.20
 Port Length (in.): 6.4
 Stack Dia. (in.): 7.2
 Probe Length (ft): 81
 Nozzle ID (in.): 1-6 (0.1142)
 Console S/N: 11046

Pre-Test Leak Check:
 Vacuum Pressure: -13
 Post-Test Leak Check:
 Vacuum Pressure: -17

K: 062

Traverse Point	Time (min)	Stack Gas Temp., T _s (F)	Velocity Head, dp (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
1	0	130	0.98	0.55	325.31	287	786	67	74	74	-5
2	2.5	132	0.94	0.53	326.38	300	285	65	74	74	-3.5
3	5	128	0.94	0.53	327.40	300	286	53	74	73	-3
4	10	127	0.92	0.52	328.46	300	286	53	74	73	-3
5	12.5	128	0.88	0.50	329.47	300	285	49	74	73	-3
6	15	132	0.85	0.47	330.47	300	287	48	73	73	-3
7	17.5	133	0.80	0.45	331.44	301	289	48	73	73	-3
8	20	136	0.82	0.45	332.38	299	290	48	73	73	-3
9	22.5	137	0.83	0.46	333.35	299	285	48	73	73	-3
10	25	131	0.84	0.47	334.31	300	281	48	73	73	-3
11	27.5	128	0.95	0.52	335.30	300	284	49	74	73	-3
12	30	130	0.97	0.54	336.32	300	284	49	74	73	-3
13	32.5	130	1.00	0.56	337.36	300	284	49	74	73	-3
14	35	130	1.00	0.56	338.40	300	282	49	74	73	-3
15	37.5	132	1.20	0.67	339.50	300	281	49	74	73	-3
16	40	139	1.40	0.77	340.76	300	280	49	74	73	-3
17	42.5	137	1.40	0.78	341.99	301	283	54	74	73	-3
18	45	135	1.50	0.87	343.26	300	283	54	75	72	-3
19	47.5	135	1.50	0.87	344.51	300	285	54	75	72	-3
20	50	135	1.60	0.89	345.85	300	285	52	76	73	-3
21	52.5	136	1.60	0.89	347.14	300	284	52	76	73	-3
22	55	136	1.60	0.89	348.44	299	286	52	78	74	-3
23	57.5	135	1.60	0.87	349.75	301	289	52	78	74	-3
24	60	134	1.60	0.92	351.08	300	291	52	78	74	-3
25	62.5	134	1.60	0.92	352.41	300	289	51	79	74	-3

MOISTURE FIELD DATA SHEET

Project No.: 121413456
Client: Northern Pulp
Plant: Pacee Bories
Location: Pictou, NS
Test: PM-3
Date: 24th July, 15
Analyst: TBL



Moisture Data

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H ₂ O	778.1	594.3	183.8
2	100 mL H ₂ O	671.7	637.9	33.8
3	Blank	672.2	665.6	6.6
4	200g Silica Gel	1050.6	1037.1	13.5
Total Weight Gain (g)				
Moisture Volume (mL)				

Volume H₂O Collected: _____ ml
 X 0.048 = _____ ft³ H₂O (Vwc)

DGM Final _____ ft³
 DGM Initial _____ ft³
 Final - Initial = _____ ft³ (Vmc)

Moisture = $\frac{Vwc}{(Vwc + Vmc)}$

Moisture = _____

Moisture = _____

1/2

SOURCE TESTING FIELD DATA SHEET

Job No.: 121413456
 Client: North Star Pulp
 Plant: Power Boiler
 Location: Richmond, MS
 Test: PA-3
 Date: July 29, 2015
 Operator: ASH/RS
 Gamma: 1.035
 Delta H₀: 0.212
 Pilot Coeff.: 0.2816
 Start: 09:00
 Finish: 9:00

Static Pressure (in.H2O): 0.20
 Port Length (in.): 64
 Stack Dia. (in.): 72"
 Probe Length (ft): 8'
 Nozzle ID (in.): 1.6101172
 Console SN: 1646

Pre-Test Leak Check:
 Vacuum Pressure: _____
 Post-Test Leak Check:
 Vacuum Pressure: _____

K: 0.62

Traverse Point	Time (min)	Stack Gas Temp., T _s (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (In.Hg)
									In	Out	
1	0	130	0.80	0.45	352.66	255	252	69	73	73	-
2	2.5	131	0.82	0.46	353.62	291	259	64	73	73	-2
3	5	132	0.92	0.51	354.58	320	263	64	73	73	-2
4	7.5	135	0.92	0.51	355.60	322	271	57	73	73	-2
5	10	135	0.95	0.47	357.57	300	275	56	73	73	-2
6	12.5	134	0.86	0.48	358.55	290	235	56	73	73	-2
7	15	134	0.85	0.47	359.51	300	237	50	73	73	-2
8	17.5	134	0.82	0.47	360.49	320	281	50	73	73	-2
9	20	135	0.80	0.46	361.45	300	282	55	73	73	-2
10	22.5	135	0.84	0.45	362.38	300	282	55	76	73	-2
11	25	136	0.82	0.46	363.37	300	283	55	76	73	-2
12	27.5	137	0.84	0.47	364.21	300	283	55	76	73	-2
13	30	137	0.86	0.48	365.28	300	283	58	77	74	-2
14	32.5	137	0.86	0.48	366.25	300	284	58	77	74	-2
15	35	142	0.85	0.47	367.23	300	285	58	77	74	-2
16	37.5	140	0.85	0.47	368.19	300	286	57	77	74	-2
17	40	140	1.10	0.61	369.27	300	286	57	77	74	-2
18	42.5	139	1.10	0.61	370.37	300	286	57	77	74	-2
19	45	142	1.40	0.77	371.59	300	285	57	77	74	-2
20	50	142	1.45	0.80	372.85	300	284	62	79	75	-4
21	52.5	134	1.53	0.84	374.17	300	284	52	79	75	-4
22	55	134	1.70	0.95	375.49	300	283	52	79	75	-4
23	57.5	134	1.75	0.98	376.97	300	284	52	79	75	-4
24	60	134	1.70	0.95	378.23	300	282	50	80	75	-5

42

SOURCE TESTING FIELD DATA SHEET

Job No.: 7.11.17.456
 Client: Northon Duff
 Plant: Northon Duff
 Location: Pictou, NS
 Test: PM-3
 Date: July 29/2015
 Operators: TBH/SE
 Gemma: 1.513
 Delta H: 1.712
 Pilot Coeff.: 0.816
 Start: 9:08
 Finish: 10:03

Static Pressure (in.H2O): 0.20
 Port Length (in.): 6"
 Stack Dia. (in.): 7.2"
 Probe Length (ft): 8'
 Nozzle ID (in.): 1.6(0.172)
 Console S/N: 1446

Pre-Test Leak Check:
 Vacuum Pressure: _____
 Post-Test Leak Check:
 Vacuum Pressure: -18

K: 0.62

Traverse Point	Time (min)	Stack Gas Temp., Ts (F)	Velocity Head, dP (in.H2O)	Orifice dH (in.H2O)	Gas Meter Volume (cu.ft)	Probe Temp. (F)	Oven Temp. (F)	Impinger Outlet Temp. (F)	Gas Meter Temp. (F)		Pump Vacuum (in.Hg)
									In	Out	
1	0				378.23						
1	2.5	134	1.50	0.84	371.51	245	267	65	76	76	5
2	5	132	1.50	0.84	380.77	271	272	58	76	76	5
2	7.5	133	1.35	0.76	382.05	299	276	50	76	76	5
3	10	134	1.45	0.81	383.27	300	278	49	75	75	5
3	11.5	135	1.10	0.67	384.39	303	290	48	78	76	5
4	15	136	1.20	0.67	385.54	301	283	48	78	76	5
4	17.5	135	1.15	0.67	386.67	302	285	48	78	76	5
5	20	134	1.10	0.62	387.78	296	280	48	78	76	5
5	21.5	135	1.10	0.62	388.89	302	280	48	78	76	5
6	25	135	1.15	0.64	390.02	300	283	48	78	76	5
6	27.5	135	1.10	0.62	391.15	300	281	48	78	76	5
7	30	136	1.10	0.62	392.27	300	285	47	78	76	5
7	32.5	136	1.20	0.67	393.39	300	285	47	78	76	5
8	35	136	1.70	0.67	394.58	299	297	47	78	76	5
8	31.5	136	1.30	0.73	395.77	297	291	47	78	76	5
9	40	135	1.25	0.70	396.97	300	297	42	78	76	5
9	42.5	135	1.30	0.73	398.19	300	293	42	78	76	5
10	45	135	1.40	0.78	399.40	300	291	42	78	76	5
10	47.5	135	1.50	0.84	400.63	300	290	41	78	76	5
11	50	135	1.50	0.84	401.97	297	290	41	78	76	5
11	52.5	135	1.70	0.95	403.27	300	286	41	78	76	5
12	55	135	1.80	1.01	404.69	300	287	41	78	76	5
12	57.5	136	1.80	1.00	406.10	300	288	41	78	75	5
12	60	135	1.85	1.03	407.48	300	287	41	78	75	5

Appendix D

Calculations

Raw Data for: Northern Pulp Recovery Boiler PM

Test #1
 Client: Northern Pulp
 Job Number: 121413458
 Plant: Recovery Boiler
 Location: Pictou, NS
 Test: P56.1
 Date: 11-14-13
 Personnel: MJB/PL
 Test Start: 9:43 AM
 Test Finish: 11:41 AM

Particulate Collected from Filter (mg)	12.2
Particulate Collected from Probe Wash (mg)	3.3
Particulate Collected from Impinger Wash (mg)	1.5
Total Particulate Collected (mg):	15.5

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H ₂ O	757.3	730.1	57.2
2	100 mL H ₂ O	743.8	732.7	10.9
3	Bare	508.1	503.8	2.2
4	200g Silica Gel	982.0	981.0	11.0
5	Bare	908.5	854.7	311.8
		Total Weigh Gain (g)		363.1
		Moisture Volume (mL)		363.1

Parameters
 Barometric Pressure, Pbar (in. Hg) 29.88
 Stack Static Pressure, Pstatic (in. H₂O) 1.16
 Ambient Temp, (°F) 64
 H₂O Volume Collected, Vw (mL) 191.1
 Total # Sampling Points, 5
 Sampling Time per Point, (min) 2.5
 Readings Taken Every _____ mins
 Regulatory Agency NSENV

CO ₂ (%)	0.7	Stack Diameter, (in.)	138
CO ₂ (%)	0.0	Stack Area, (sq. ft.)	103.87
N ₂ (%)	85.3	Probe Length, (ft.)	6
CO (ppm)	98.1	Nozzle Diameter, (in.)	0.234
NO _x (ppm)	88.6	Pitot Coefficient, (Cp)	0.794
SO ₂ (ppm)	2.7	Orifice, meter constant	1.117
		Port length (in.)	6

Traverse Point	Time (min)	Stack Gas Temp, T _a (°F)	P-type Pitot delta P (in. H ₂ O)	Orifice delta H (in. H ₂ O)	Gas Meter Volume (cu. ft.)	Gas Meter Temp Inlet (°F)	Gas Meter Temp Outlet (°F)	
Traverse 1	1	2.5	130	0.43	0.40	833.230	67	67
	5	5	149	0.42	0.38	831.300	69	68
	2	7.5	149	0.42	0.38	826.270	70	68
	10	10	149	0.42	0.38	837.230	71	69
	12.5	15	149	0.42	0.38	838.200	71	69
	15	149	0.41	0.37	841.170	72	69	
	17.5	149	0.41	0.37	841.120	72	69	
	20	150	0.41	0.37	841.870	73	70	
	22.5	150	0.41	0.37	842.040	73	71	
	25	150	0.41	0.37	843.010	74	71	
	27.5	150	0.41	0.37	843.930	74	71	
	30	150	0.41	0.37	844.920	74	71	
32.5	150	0.42	0.38	845.890	75	71		
35	149	0.42	0.39	846.880	75	72		
37.5	150	0.41	0.38	847.850	75	72		
40	150	0.41	0.38	848.820	75	72		
42.5	151	0.41	0.38	849.800	76	72		
45	150	0.41	0.38	850.780	76	72		
47.5	150	0.41	0.38	851.750	76	72		
50	150	0.41	0.38	852.700	76	72		
52.5	150	0.41	0.38	853.680	76	72		
55	150	0.41	0.38	854.650	76	72		
57.5	150	0.41	0.38	855.620	76	72		
60	150	0.41	0.38	856.580	76	72		
Traverse 2	1	62.5	150	0.40	0.36	856.590	77	73
	5	65	150	0.40	0.36	857.450	77	73
	10	67.5	150	0.40	0.36	858.220	77	73
	15	70	150	0.40	0.36	859.010	74	73
	20	72.5	150	0.40	0.36	859.890	74	73
	25	75	149	0.41	0.36	860.870	75	74
	30	77.5	149	0.41	0.36	861.850	75	74
	35	80	150	0.41	0.36	862.790	75	74
	40	82.5	150	0.41	0.36	863.750	76	74
	45	85	150	0.41	0.36	864.740	76	74
	50	87.5	150	0.41	0.36	865.740	76	74
	55	90	150	0.41	0.36	866.750	76	74
60	92.5	150	0.41	0.36	867.690	76	74	
65	95	150	0.41	0.36	868.680	77	75	
70	97.5	150	0.41	0.36	869.640	77	75	
75	100	149	0.40	0.36	870.640	77	75	
80	102.5	150	0.40	0.36	871.530	77	75	
85	105	150	0.40	0.36	872.470	78	75	
90	107.5	150	0.40	0.36	873.400	78	75	
95	110	150	0.41	0.36	874.400	78	75	
100	112.5	150	0.41	0.36	875.350	78	75	
105	115	150	0.41	0.36	876.300	78	75	
110	117.5	150	0.41	0.36	877.280	78	75	
115	120	150	0.41	0.36	878.230	78	75	

Calculations for: Northern Pulp Recovery Boiler PM
Test #1

Client: Northern Pulp
Job Number: 121412458
Plant: Recovery Boiler
Location: P1204, H8
Test: PM-1
Date: 23-Jul-13
Personnel: JJB/FB

Calculated Parameters

Stack Gas Pressure, P_g (in. Hg) **29.08**
Stack Gas Molecular Weight, Dry Basis, M_d (lb/lb-mole) **29.54**
Volume of Water Vapour Collected, V_w (cu ft) **18.000**
Stack Gas Moisture Content (% as decimal) **0.274**
Stack Gas Molecular Weight, Wet Basis, M_w (lb/lb-mole) **26.38**

Isokineticity Checks

Check range: Within Criteria
Check average: Within Criteria

Traverse Point	Time (min)	Stack Gas Temp, T _s (°F)	S-type Pitot, delta P (in. H ₂ O)	Orifice delta H (in. H ₂ O)	Stack Gas Velocity, U _s (ft/s)	Meter Press., P _m (in. Hg)	Avg. Temp., T _m (°F)	Gas Meter Volume, V _m (cu. ft.)	Vol. @ Ref. V _m (cu. ft.)	Isokineticity (%)
Traverse 1										
1	2.5	810	0.43	0.80	39.81	29.04	527	1.010	1.118	101.21
2	5	808	0.42	0.58	39.12	29.04	528	0.980	1.058	94.88
3	10	808	0.42	0.58	39.12	29.04	529	0.970	1.068	87.89
4	12.5	810	0.42	0.58	39.15	29.04	530	0.980	1.023	96.70
5	15	809	0.41	0.57	38.85	29.04	531	0.970	1.088	87.79
6	17.5	809	0.41	0.57	38.85	29.04	531	0.950	1.063	90.83
7	20	810	0.41	0.57	38.85	29.04	532	0.950	1.041	94.88
8	22.5	810	0.41	0.57	38.88	29.04	532	0.970	1.062	88.80
9	25	810	0.41	0.57	38.88	29.04	533	0.970	1.081	98.51
10	27.5	810	0.41	0.57	38.88	29.04	533	0.940	1.028	95.46
11	30	810	0.41	0.57	38.88	29.04	533	0.970	1.081	98.51
12	32.5	810	0.42	0.58	39.12	29.04	534	0.970	1.028	98.51
13	35	809	0.42	0.58	39.15	29.04	533	0.970	1.080	97.24
14	37.5	810	0.41	0.58	38.88	29.04	534	0.980	1.080	88.07
15	40	810	0.41	0.58	38.88	29.04	534	0.970	1.059	96.33
16	42.5	811	0.41	0.58	38.88	29.04	534	0.970	1.059	98.33
17	45	810	0.41	0.58	38.88	29.04	534	0.980	1.089	98.33
18	47.5	810	0.41	0.58	38.88	29.04	534	0.980	1.088	98.25
19	50	810	0.41	0.58	38.88	29.04	534	0.970	1.058	98.25
20	52.5	810	0.41	0.58	38.88	29.04	534	0.980	1.058	98.25
21	55	810	0.41	0.58	38.88	29.04	534	0.980	1.088	98.25
22	57.5	810	0.41	0.58	38.88	29.04	534	0.980	1.047	97.22
23	60	810	0.41	0.58	38.88	29.04	534	0.980	1.047	97.22
Traverse 2										
1	62.5	810	0.40	0.56	38.21	29.04	535	0.970	0.947	88.02
2	65	810	0.40	0.56	38.21	29.04	535	0.970	0.838	79.80
3	67.5	810	0.40	0.56	38.21	29.04	534	0.970	0.882	61.07
4	70	810	0.40	0.56	38.21	29.04	534	0.980	0.980	92.21
5	72.5	809	0.41	0.56	38.85	29.04	535	0.980	1.088	98.07
6	75	809	0.41	0.56	38.85	29.04	535	0.980	1.088	98.07
7	77.5	810	0.41	0.56	38.88	29.04	535	0.980	1.088	98.07
8	80	810	0.41	0.56	38.88	29.04	535	0.940	1.024	85.11
9	82.5	810	0.41	0.56	38.88	29.04	535	0.980	1.045	87.04
10	85	810	0.41	0.56	38.88	29.04	535	0.980	1.077	100.07
11	87.5	810	0.41	0.56	38.88	29.04	535	1.000	1.088	101.08
12	90	810	0.41	0.56	38.88	29.04	535	0.980	1.067	98.08
13	92.5	810	0.41	0.56	38.88	29.04	535	0.970	1.058	98.05
14	95	809	0.40	0.56	38.88	29.04	536	0.970	1.075	98.88
15	97.5	809	0.40	0.56	38.88	29.04	536	0.980	1.085	98.88
16	100	809	0.40	0.56	38.18	29.04	536	0.980	1.064	100.02
17	102.5	810	0.40	0.56	38.21	29.04	537	0.940	1.021	95.93
18	105	810	0.40	0.56	38.18	29.04	537	0.950	1.031	98.94
19	107.5	810	0.41	0.56	38.88	29.04	537	0.940	1.020	95.82
20	110	810	0.41	0.56	38.21	29.04	537	0.970	1.052	98.88
21	112.5	810	0.41	0.58	38.88	29.04	537	0.980	1.042	98.77
22	115	810	0.41	0.58	38.88	29.04	537	0.950	1.021	85.78
23	117.5	810	0.41	0.58	38.88	29.04	537	0.980	1.064	98.78
24	120	810	0.41	0.58	38.88	29.04	537	0.950	1.020	95.87
Total	120	Average 810	Average 0.41	Average 0.58	Average 38.88	Average 29.04	Average 534	Total 45.800	Total 50.083	Average 98.87

Combustion Gas Data for: Northern Pulp

Client: Northern Pulp
Job Number: 121413456

Plant: Recovery Boiler
Location: Pictou, NS
Test: PM-1
Date: 23-Jul-15
Personnel: JJB/FS

Test Start:
Test Finish:

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)	NO (ppm)	NO2 (ppm)
0	6.6	8.0	46	0	66	0	66
5	6.6	8.0	94	0	66	0	66
10	6.9	7.8	63	2	66	0	66
15	6.7	8.0	68	4	66	0	66
20	6.7	8.0	72	0	68	0	68
25	6.8	8.0	159	6	67	0	67
30	6.8	8.0	171	7	67	0	67
Average:	6.7	8.0	96	3	67	0	67

Raw Data for: Northern Pulp Recovery Boiler PM
Test #2

Client: Northern Pulp
Job Number: 121413458

Plant: Recovery Boiler
Location: Pictou, NS
Test: PM-2
Date: 15-Jul-17
Personnel: JTB FS

Test Start: 1:20 PM
Test Finish: 3:30 PM

Parameters
Barometric Pressure, Pbar (in. Hg)
Stack Static Pressure, Pstatic (in. H2O)
Ambient Temp, (T_a)
H2O Volume Collected, V_w (mL)
Total # Sampling Points,
Sampling Time per Point, (min)
Readings Taken Every _____ mins
Regulatory Agency

Particulate Collected from Filter (mg): 1.2
Particulate Collected from Probe Wash (mg): 7.4
Particulate Collected from Impinger Wash (mg): 1.0
Total Particulate Collected (mg): 9.6

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H2O	748.8	700.3	48.6
2	100 mL H2O	733.2	728.3	5.0
3	Blank	880.3	880.9	1.4
4	200g Silica Gel	1002.2	981.4	10.8
5	Blank	1004.3	958.8	377.7
		Total Weight Gain (g)		463.4
		Moisture Volume (mL)		443.4

29 (in) CO₂ (%) 0.0
1.10 CO₂ (%) 0.0
63 N₂ (%) 85.3
441.6 CO (ppm) 119.7
54 NO_x (ppm) 63.1
5 SO₂ (ppm) 4.7

Stack Diameter, (in.) 130
Stack Area, (sq. ft.) 103.87
Probe Length, (ft.) 5
Nozzle Diameter, (in.) 0.234
Pilot Coefficient, (C_p) 0.754
Gamma, meter constant 1.117
Port Length (in.) 6

Traverse Point	Time (min)	Stack Gas Temp, T _s (°F)	S-type Pilot orifice P (in. H2O)	Orifice orifice H (in. H2O)	Gas Meter Volume (cu. ft.)	Gas Meter Temp Inlet (°F)	Gas Meter Temp Outlet (°F)	
Traverse 1	1	2.5	130	0.43	0.66	879.476		
	5	130	0.43	0.63	880.508	76	76	
	2	7.5	130	0.43	0.63	881.110	77	76
	10	130	0.43	0.63	882.530	77	76	
	3	12.5	131	0.42	0.62	884.510	79	77
	15	130	0.42	0.62	882.330	79	77	
	4	17.5	130	0.42	0.62	885.330	80	77
	20	130	0.42	0.62	887.590	80	78	
	8	22.5	130	0.42	0.62	888.560	80	78
	25	131	0.42	0.62	889.370	81	78	
	27.5	131	0.42	0.62	890.390	81	78	
	30	130	0.42	0.62	891.610	81	79	
7	32.5	130	0.41	0.61	892.600	82	79	
35	130	0.41	0.61	893.600	82	79		
37.5	130	0.41	0.61	894.620	82	79		
40	130	0.42	0.62	895.630	83	80		
8	42.5	130	0.42	0.62	896.630	83	80	
45	131	0.42	0.62	897.630	83	80		
47.5	131	0.42	0.62	898.640	83	80		
50	130	0.42	0.62	899.650	83	80		
52.5	130	0.41	0.61	900.666	83	80		
55	130	0.44	0.64	901.720	83	81		
57.5	130	0.43	0.64	902.794	83	81		
60	130	0.43	0.64	903.810	83	81		
Traverse 2	1	62.5	131	0.44	0.64	903.810		
	65	131	0.44	0.64	904.860	83	81	
	2	67.5	140	0.45	0.67	906.960	83	81
	70	130	0.33	0.67	907.930	80	80	
	3	72.5	130	0.40	0.73	908.910	80	80
	75	130	0.30	0.73	909.920	80	79	
	4	77.5	140	0.30	0.73	911.000	80	79
	80	140	0.52	0.73	912.120	80	79	
	6	82.5	131	0.45	0.67	913.170	79	79
	85	130	0.44	0.66	914.300	79	78	
	87.5	131	0.37	0.59	913.290	79	79	
	90	130	0.31	0.76	916.380	79	79	
82.5	130	0.63	0.94	917.610	79	79		
85	130	0.36	1.10	918.920	79	79		
87.5	140	0.70	1.04	920.210	80	79		
8	100	0.62	0.93	921.440	80	79		
102.5	140	0.54	0.81	922.630	80	79		
105	140	0.80	0.99	923.820	80	79		
107.5	140	0.70	1.04	925.130	80	79		
110	140	0.90	1.17	926.480	80	79		
112.5	140	0.90	1.34	927.970	82	80		
115	130	0.70	1.04	929.230	82	80		
117.5	130	0.42	0.62	930.290	82	80		
120	130	0.42	0.62	931.300	82	80		

Calculations for: Northern Pub Recovery Boiler PM
Test #2

Client: Northern Pub
Job Number: 121613458

Plant: Recovery Boiler
Location: Active, US
Test: PM-2
Date: 23-Jul-15
Personnel: J/B/PS

Calculated Parameters

Stack Gas Pressure, P_s (in Hg) 29.08
Stack Gas Molecular Weight, Dry Basis, M_d (lb/lb-mole) 29.53
Volume of Water Vapor Collected, V_w (cu. ft.) 21.293
Stack Gas Moisture Content (% as decimal) 0.279
Stack Gas Molecular Weight, Wet Basis, M_w (lb/lb-mole) 38.27

Isokineticity Checks

Check range: Within Criteria
Check average: Within Criteria

Traverse Point	Time (min)	Stack Gas Temp, T _s (R)	S-type Pitot delta P (in. H ₂ O)	Orifice delta H (in. H ₂ O)	Stack Gas Velocity, U _s (ft/s)	Meter Press. P _m (in. Hg)	Avg. Temp. T _m (R)	Gas Meter Volume, V _m (cu. ft.)	Vol. @ Ref. V _m (cu. ft.)	Isokinetics I (%)	
Traverse 1	1	2.5	010	0.43	0.68	40.54	29.05	536	1.020	1.119	98.44
	2	5	010	0.43	0.63	39.63	29.05	537	1.010	1.091	98.95
		7.5	010	0.43	0.63	39.63	29.05	537	1.010	1.091	98.95
	3	12.5	010	0.43	0.63	39.63	29.05	537	1.010	1.091	98.95
		15	010	0.42	0.62	39.18	29.05	538	0.980	1.061	97.84
	4	17.5	010	0.42	0.62	39.18	29.05	538	1.020	1.104	101.54
		20	010	0.42	0.62	39.18	29.05	538	1.020	1.104	101.54
	5	22.5	010	0.42	0.62	39.18	29.05	539	1.000	1.080	98.37
		25	011	0.42	0.62	39.18	29.05	540	1.010	1.091	100.38
	6	27.5	011	0.42	0.62	39.20	29.05	540	1.010	1.090	100.35
		30	010	0.42	0.62	39.18	29.05	540	1.020	1.101	101.34
	7	32.5	010	0.41	0.61	38.70	29.04	541	0.990	1.067	98.29
35		010	0.41	0.61	38.70	29.04	541	1.000	1.077	100.29	
8	37.5	010	0.41	0.61	38.70	29.04	541	1.020	1.098	102.30	
	40	010	0.42	0.62	38.18	29.05	542	1.010	1.088	99.80	
9	42.5	010	0.42	0.62	38.18	29.05	542	1.000	1.075	98.91	
	45	011	0.42	0.62	39.20	29.05	542	1.000	1.075	98.91	
10	47.5	010	0.42	0.62	39.20	29.05	542	1.010	1.086	99.86	
	50	010	0.42	0.62	39.20	29.05	542	1.010	1.086	99.86	
11	52.5	010	0.41	0.61	38.70	29.04	542	1.010	1.086	99.80	
	55	010	0.44	0.66	40.08	29.05	542	1.080	1.138	102.35	
12	57.5	010	0.43	0.64	39.63	29.05	542	1.070	1.150	104.50	
	60	010	0.43	0.64	39.63	29.05	542	1.020	1.088	98.82	
Traverse 2	1	62.5	011	0.44	0.68	40.12	29.05	542	1.050	1.128	101.47
	2	65	008	0.45	0.67	40.12	29.05	542	1.080	1.138	102.43
		67.5	010	0.33	0.57	40.51	29.05	542	1.040	1.117	99.23
	3	70	010	0.40	0.58	34.72	29.05	540	0.970	1.046	104.95
		72.5	010	0.50	0.75	38.22	29.04	540	0.960	1.037	98.59
	4	75	008	0.50	0.75	42.70	29.06	540	1.010	1.090	101.93
		77.5	008	0.52	0.75	43.54	29.06	540	1.100	1.188	100.04
	5	80	011	0.45	0.67	40.57	29.05	538	1.100	1.188	99.09
		82.5	011	0.45	0.67	40.57	29.05	538	1.050	1.124	100.69
	6	85	010	0.44	0.68	40.08	29.05	538	1.070	1.157	103.98
		87.5	011	0.37	0.59	43.18	29.04	539	1.040	1.123	110.18
	7	90	010	0.51	0.78	42.18	29.06	540	1.100	1.188	99.23
92.5		010	0.63	0.84	47.97	29.07	539	1.230	1.330	99.88	
8	95	010	0.74	1.10	51.99	29.07	539	1.310	1.417	98.19	
	97.5	009	0.70	1.04	50.52	29.06	540	1.280	1.384	98.22	
9	100	008	0.62	0.83	47.95	29.07	540	1.230	1.329	100.50	
	102.5	010	0.54	0.81	44.41	29.06	540	1.180	1.274	103.38	
10	105	008	0.60	0.89	46.77	29.07	540	1.200	1.296	99.98	
	107.5	008	0.70	1.04	50.52	29.06	540	1.310	1.415	100.78	
11	110	008	0.78	1.17	53.67	29.08	540	1.350	1.458	97.78	
	112.5	008	0.80	1.34	57.24	29.10	541	1.440	1.553	97.41	
12	115	010	0.70	1.04	50.56	29.08	541	1.310	1.412	100.57	
	117.5	010	0.42	0.62	38.18	29.05	541	1.080	1.141	104.84	
12	120	010	0.42	0.62	38.18	29.05	541	1.010	1.087	98.98	
	Total	120	Average 010	Average 0.48	Average 0.72	Average 41.78	Average 29.05	Average 540	Total 51.830	Total 55.924	Average 100.54

Combustion Gas Data for: Northern Pulp

Client: Northern Pulp
Job Number: 121413456

Plant: Recovery Boiler
Location: Pictou, NS
Test: PM-2
Date: 23-Jul-15
Personnel: JJB/FS

Test Start: 1:20 PM
Test Finish: 1:50 PM

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)	NO (ppm)	NO2 (ppm)
0	6.6	8.0	115	2	63	63	0
5	6.7	8.0	117	2	63	63	0
10	6.7	8.0	117	4	63	63	0
15	6.8	8.0	118	6	62	62	0
20	6.6	8.0	104	2	63	63	0
25	6.5	8.1	132	8	64	64	0
30	6.5	8.1	137	9	64	64	0
Average:	6.6	8.0	120	5	63	63	0

Raw Data for: Northern Pulp Recovery Boiler PM
Test #3

Client: Northern Pulp
Job Number: 121413406

Plant: Recovery Boiler
Location: Potosi, MO
Test: PM-3
Date: 24-Jul-15
Personnel: JDS/YS
Test Start: 8:12 AM
Test Finish: 10:12 AM

Particulate Collected from Filter (mg): 0.2
Particulate Collected from Probe Wash (mg): 0.0
Particulate Collected from Impinger Wash (mg): 1.5
Total Particulate Collected (mg): 0.2

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H2O	871.7	867.8	174.1
2	100 mL H2O	738.3	728.1	12.2
3	Blank	897.8	895.0	2.8
4	200g Silica Gel	924.1	910.1	14.0
5	Blank	1036.8	983.2	383.6
		Total Weight Gain (g)		586.7
		Moisture Volume (mL)		586.7

Parameters

Barometric Pressure, Pbar (In. Hg) 29.90
Stack Static Pressure, Pstatic (In. H2O) 1.16
Ambient Temp, (°F) 60
H2O Volume Collected, Vw (mL) 136.70
Total # Sampling Points, 24
Sampling Time per Point, (min) 34
Readings Taken Every, (min) 2.5
Regulatory Agency NSEPV

O2, (%) 5.3
CO2, (%) 9.6
NOx, (%) 85.1
CO(ppm) 235.8
NOs (ppm) 58.4
SO2 (ppm) 4.8

Stack Diameter, (In.) 138
Stack Area, (sq. ft.) 87.1
Probe Length, (ft.) 8
Nozzle Diameter, (In.) 0.234
Pitot Coefficient, (CF) 0.754
Gamma, meter constant 1.117
Port length (In.) 8

Traverse Point	Time (min)	Stack Gas Temp, Tg (°F)	S-type Pitot delta P (In. H2O)	Orifice delta H (In. H2O)	Gas Meter Volume (cu. ft.)	Gas Meter Inlet (°F)	Gas Meter Outlet (°F)
Traverse 1	1	2.5	134	0.61	822.110	69	69
	2	5	134	0.63	933.320	69	69
	3	7.5	134	0.63	933.880	69	69
	4	10	133	0.63	937.040	71	69
	5	12.5	133	0.62	938.270	71	69
	6	15	134	0.62	939.490	71	69
	7	17.5	134	0.62	940.720	71	69
	8	20	134	0.62	941.950	74	70
	9	22.5	134	0.62	943.170	74	71
	10	25	133	0.62	944.400	74	71
	11	27.5	133	0.62	945.640	74	71
	12	30	134	0.62	946.860	73	71
Traverse 2	1	32.5	133	0.62	948.080	73	72
	2	35	133	0.62	949.290	73	72
	3	37.5	133	0.62	950.510	73	72
	4	40	133	0.62	951.740	73	72
	5	42.5	133	0.61	952.960	73	72
	6	45	133	0.61	954.200	73	72
	7	47.5	134	0.60	955.430	73	72
	8	50	134	0.61	956.650	73	72
	9	52.5	133	0.60	957.870	73	72
	10	55	133	0.61	959.080	76	73
	11	57.5	133	0.60	960.300	76	73
	12	60	133	0.60	961.540	76	73
Traverse 2	1	62.5	134	0.61	962.760	73	73
	2	65	134	0.60	964.000	73	73
	3	67.5	133	0.60	965.210	73	73
	4	70	133	0.60	966.430	73	73
	5	72.5	133	0.60	967.660	76	73
	6	75	134	0.60	968.870	73	73
	7	77.5	134	0.60	970.090	73	73
	8	80	134	0.61	971.300	73	73
	9	82.5	134	0.61	972.540	73	73
	10	85	133	0.60	973.770	73	73
	11	87.5	136	0.60	974.990	73	73
	12	90	133	0.60	976.200	73	73
Traverse 2	1	92.5	136	0.60	977.420	73	73
	2	95	136	0.60	978.640	73	73
	3	97.5	136	0.60	979.860	73	73
	4	100	136	0.60	981.080	73	73
	5	102.5	134	0.61	982.270	76	73
	6	105	134	0.62	983.500	76	73
	7	107.5	132	0.62	984.760	73	73
	8	110	132	0.60	985.980	73	73
	9	112.5	134	0.60	987.200	73	73
	10	115	133	0.60	988.390	73	73
	11	117.5	133	0.60	989.610	73	73
	12	120	133	0.60	990.830	73	73

Calculations for: Northern Pip Recovery Boiler PM
Test #3

Client: Northern Pip
Job Number: 121412-06
Plant: Recovery Boiler
Location: Pickle, NS
Test: PM-3
Date: 24-Jul-13
Personnel: JJB/PS

Calculated Parameters

Stack Gas Pressure, Pa (in.Hg) 29.80
Stack Gas Molecular Weight, Dry Basis, Md (lb/lb-mole) 29.75
Volume of Water Vapour Collected, Vwv (cu.ft) 26.162
Stack Gas Moisture Content (% as decimal) 0.280
Stack Gas Molecular Weight, Wet Basis, Mw (lb/lb-mole) 26.24

Isokineticity Checks

Check range: Within Criteria
Check average: Within Criteria

Traverse	Plane	Time (min)	Stack Gas Temp, Tg (R)	S-type Pitot, delta P (in. H2O)	Orifice delta H (in. H2O)	Stack Gas Velocity, Us (ft/s)	Meter Press. Pm (in. Hg)	Avg. Temp, Tm (R)	Volume, Vm (cu. ft)	Vol. @ Ref. Vm (cu. ft)	Isokineticity I (%)
Traverse 1	1	2.5	814	0.81	0.88	46.75	29.96	528	1.210	1.374	108.78
	2	5	814	0.83	0.91	47.31	29.87	529	1.240	1.408	107.86
		7.5	814	0.83	0.91	47.31	29.87	529	1.240	1.408	107.86
	3	10	815	0.83	0.91	47.55	29.87	530	1.240	1.408	107.54
		12.5	815	0.82	0.90	47.17	29.87	530	1.230	1.384	107.53
	4	15	814	0.82	0.90	47.13	29.87	530	1.230	1.383	106.97
		17.5	814	0.82	0.90	47.15	29.87	533	1.230	1.384	107.44
	5	20	814	0.82	0.90	47.13	29.87	532	1.230	1.388	107.04
		22.5	814	0.82	0.90	47.13	29.87	533	1.230	1.378	106.07
	6	25	815	0.82	0.90	47.17	29.87	533	1.250	1.410	108.77
		27.5	815	0.82	0.89	47.17	29.85	533	1.220	1.378	106.10
	7	30	814	0.82	0.90	47.13	29.87	534	1.220	1.375	105.87
32.5		814	0.82	0.90	47.17	29.87	534	1.220	1.391	104.14	
8	35	815	0.82	0.90	47.17	29.87	534	1.220	1.385	108.83	
	37.5	815	0.82	0.90	47.17	29.87	534	1.220	1.374	109.96	
9	40	815	0.82	0.90	47.17	29.87	534	1.230	1.385	108.83	
	42.5	815	0.81	0.88	46.79	29.86	534	1.230	1.374	107.82	
10	45	815	0.81	0.88	46.79	29.86	534	1.230	1.374	108.82	
	47.5	814	0.80	0.88	46.56	29.86	534	1.230	1.368	108.37	
11	50	814	0.81	0.88	46.75	29.86	534	1.230	1.374	108.82	
	52.5	815	0.80	0.88	46.40	29.88	534	1.220	1.374	107.82	
12	55	815	0.81	0.88	46.79	29.87	535	1.210	1.360	105.75	
	57.5	815	0.80	0.88	46.40	29.86	535	1.220	1.371	107.90	
	60	815	0.80	0.88	46.40	29.86	535	1.240	1.384	108.38	
Traverse 2	1	62.5	814	0.81	0.88	46.75	29.90	534	1.220	1.388	108.40
	2	65	814	0.81	0.88	46.75	29.87	534	1.240	1.385	108.58
		67.5	814	0.80	0.88	46.38	29.87	534	1.210	1.361	108.64
	3	70	815	0.80	0.88	46.40	29.86	534	1.220	1.372	107.80
		72.5	815	0.80	0.88	46.40	29.86	535	1.230	1.362	108.36
	4	75	814	0.80	0.88	46.58	29.86	534	1.230	1.361	108.85
		77.5	814	0.80	0.88	46.58	29.86	534	1.220	1.372	107.52
	5	80	814	0.81	0.88	46.75	29.86	534	1.210	1.361	105.16
		82.5	814	0.81	0.88	46.75	29.87	534	1.240	1.369	108.38
	6	85	815	0.80	0.88	46.40	29.86	534	1.230	1.384	108.49
		87.5	815	0.80	0.87	46.40	29.86	534	1.230	1.372	107.89
	7	90	815	0.80	0.87	46.44	29.86	534	1.210	1.361	106.72
92.5		816	0.80	0.87	46.44	29.86	534	1.220	1.372	107.89	
8	95	816	0.80	0.87	46.44	29.86	534	1.220	1.372	107.89	
	97.5	816	0.80	0.87	46.44	29.86	534	1.220	1.372	107.89	
9	100	816	0.80	0.87	46.44	29.86	534	1.220	1.372	107.89	
	102.5	814	0.81	0.88	46.75	29.86	535	1.220	1.329	105.04	
10	105	814	0.82	0.91	47.13	29.87	535	1.190	1.371	108.53	
	107.5	812	0.82	0.91	47.05	29.87	535	1.250	1.405	108.27	
11	110	812	0.80	0.87	46.28	29.87	534	1.240	1.380	107.53	
	112.5	814	0.80	0.87	46.38	29.86	534	1.220	1.373	107.35	
12	115	814	0.80	0.87	46.38	29.86	534	1.210	1.361	106.83	
	117.5	815	0.80	0.87	46.40	29.86	534	1.200	1.350	105.79	
	120	815	0.80	0.87	46.40	29.86	534	1.220	1.372	107.80	
	Total	120	Average 815	Average 0.81	Average 0.88	Average 46.78	Average 29.86	Average 533	Total 68.710	Total 68.148	Average 107.14

Combustion Gas Data for: Northern Pulp

Client: Northern Pulp
Job Number: 121413456

Plant: Recovery Boiler
Location: Pictou, NS
Test: PM-3
Date: 24-Jul-15
Personnel: JJB/FS

Test Start: 8:20 AM
Test Finish: 8:50 AM

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
0	5.0	9.7	176	6	58
5	5.1	9.6	192	6	58
10	5.3	9.8	187	6	58
15	5.4	9.8	272	0	60
20	5.4	7.9	263	5	61
25	5.5	10.7	262	4	61
30	5.5	9.7	297	5	60
Average:	5.3	9.6	236	5	59

DATA ENTRY

Northern Pulp

Pictou, NS

Fuel: Fuel oil

Operating Conditions: normal

Emission Control Equipment: precipitator

Stack Height from Grade: 69 m

Stack Diameter: 3.51 m

Reference Temperature, Tref (F): 77
 (K): 298
 Reference Pressure, Pref (in.Hg): 29.92
 (Bar): 1.0

Parameter	Symbol	Units	Test 1	Test 2	Test 3	Average
Test ID	-	-	PM-1	PM-2	PM-3	-
Date	-	-	23-Jul-15	23-Jul-15	24-Jul-15	n/a
Start Time	-	-	9:45 AM	1:20 PM	8:12 AM	n/a
End Time	-	-	11:45 AM	3:20 PM	10:12 AM	n/a
Total Sampling Time	-	min	120	120	120	120
Stack Diameter	D	in.	138	138	138	138
Average Stack Gas Temperature	Ts	F	150	150	155	151
Average Dry Gas Meter Temperature	Tm	F	74	80	73	76
Barometric Pressure	Pbar	in.Hg	29.00	29.00	29.90	29.30
Stack Static Pressure	Pstatic	in.H2O	1.10	1.10	1.10	1.10
Average Pressure Drop (Head)	dP	in.H2O	0.41	0.48	0.61	0.50
Average deltaH Orifice	dH	in.H2O	0.58	0.72	0.88	0.73
Average Meter Temperature	Tm	F	74	80	73	76
Gas Sample Volume	Vm	cu.ft	45.90	51.83	58.71	52.15
Average Isokinetics	I	%	96.87	100.56	107.14	101.52
Nozzle Diameter	Dn	in.	0.234	0.234	0.234	0.234
Pitot Coefficient	Cp	-	0.794	0.794	0.794	0.794
Gamma, meter constant	γ	-	1.117	1.117	1.117	1.117
Reference Temperature	Tref	R	537	537	537	537
Reference Pressure	Pref	in.Hg	29.92	29.92	29.92	29.92
Stack Gas Oxygen Content	Co2	%	6.7	6.6	5.3	6.2
Stack Gas Carbon Dioxide Content	Cco2	%	8.0	8.0	9.6	8.5
Stack Gas Nitrogen Content	Cn2	%	85.3	85.3	85.1	85.2
Stack Gas Sulphur Dioxide Content	Cso2	ppm	2.7	4.7	4.6	4.0
Stack Gas Nitrogen Oxides Content	Cnox	ppm	66.6	63.1	59.4	63.0
Stack Gas Carbon Monoxide Content	Cco	ppm	96.1	119.7	235.6	150.5
Volume of Water Collected	Vw	mL	393.1	443.4	586.7	474.4
Particulate Collected from Filter	-	mg	12.2	1.2	0.2	4.5
Particulate Collected from Probe Wash	-	mg	3.3	7.4	0.0	3.5
Particulate Collected from Impinger Wash	-	mg	1.50	1.04	1.47	1.34
Total Particulate Collected (excluding impingers)	Mp	mg	15.5	8.58	0.20	8.08

Legend: F - degrees Fahrenheit
 K - degrees Kelvin
 Bar - bars
 in.Hg - inches of mercury
 in. - inches

in H2O - inches of water
 cu.ft - cubic feet
 R - degrees Rankin
 NOx - as NO2

CALCULATIONS
 Northern Pulp
 Pictou, NS
 Fuel: Fuel oil
 Operating Conditions: normal
 Emission Control Equipment: precipitator
 Stack Height from Grade: 69 m
 Stack Diameter: 3.51 m

Variable	Symbol	Units	Calculation	Test 1	Test 2	Test 3	Average
Stack Area	As	sq ft sq m	$A_s = P \times ((D/2)^2 \times \pi)$ $A_s (sq m) = A_s (sq ft) \times 0.0929$	103.87 9.65	103.87 9.65	103.87 9.65	103.87 9.65
Barometric Pressure	Pbar	kPa	$P_{bar} (kPa) = P_{bar} (in Hg) \times 3.386$	99.2	99.2	101.2	99.2
Stack Static Pressure	Pstatic	kPa	$P_{static} (kPa) = P_{static} (in H2O) \times 0.249$	0.27	0.27	0.27	0.27
Avg. Stack Temperature	Ts	R	$T_s (R) = T_s (F) + 460$	610	610	615	611
Avg. Meter Temperature	Tm	R	$T_m (R) = T_m (F) + 460$	534	540	533	535.6
Nozzle Diameter	Dn	mm	$D_n (mm) = D_n (in.) \times 25.4$	6	6	6	5.9
Gas Meter Pressure	Pm	in. Hg	$P_m = P_{bar} - (dH/13.6)$	29.04	29.05	29.96	29.35
Sample Volume at Ref Cond	Vmc	cu. ft	$V_{mc} = T_{ref} P_{ref} \times (V_m \times P_m \times y) / T_m$	50.06	55.92	66.15	57.4
Volume of Water Vapour	Vwc	cu. ft	$V_{wc} (cu. ft) = 0.02832 \times V_{mc} (cu. ft)$	1.42	1.58	1.87	1.62
Water Fraction	Bwo	-	$B_{wo} = V_{wc} / (V_{wc} + V_{mc})$	0.274	0.276	0.299	0.3
Molecular Weight, Dry	Md	lb/lb-mol	$M_d = 0.44 (CO_2) + 0.52 (CO) + 0.28 (C_2H_6)$	29.54	29.55	29.75	29.6
Molecular Weight, Wet	Mw	lb/lb-mol	$M_w = M_d (1 - B_{wo}) + (18 \times B_{wo})$	26.38	26.38	26.24	26.3
Stack Pressure	Pt	in. Hg	$P_t = P_{bar} - (P_{static}/13.6)$	29.08	29.08	29.98	29.38
Stack Gas Velocity	U	ft/s	$U = 85.33 \times C_p \times ((dP \times T_s) / (P_s \times M_w))^{0.5}$	38.86	41.78	46.76	42.4
Actual Stack Gas Flow Rate	Q	scfm	$U (m/s) = 0.3048 \times U (ft/s)$	11.78	12.74	14.25	12.9
Dry Stack Gas Flow Rate	Qd	Rcfm	$Q = 60 \times U \times A_s$	240.962	260.402	291.414	264.259
	Qd	Rcfm	$Q_d = Q \times (1 - B_{wo}) \times (T_{ref} T_s) / (P_s P_{ref})$	149.784	161.393	178.976	163.384
	Qd	Rcfm	$Q_d (Rcfm) = 0.000472 \times Q_d (Rcfm)$	70.70	76.18	84.48	77.1
Sulphur Dioxide - SO2							
SO2 Measured Concentration	CSO2	ppm	Measurement from Flow Gas Analyser	2.71	4.71	4.57	4.00
Uncorrected @ Ref Cond	CSO2	mg/Rcm	$CSO_2 (mg/Rcm) = CSO_2 (ppm) \times 2.62$	7.11	12.35	11.98	10.48
SO2 Emission Rate	ERSO2	g/s kg/hr	$ER_{SO_2} = CSO_2/1000 \times Q_d$ $ER_{SO_2} (kg/hr) = 3.6 \times ER_{SO_2} (g/s)$	0.50 1.81	0.94 3.39	1.01 3.64	0.82 2.95
SO2 Concentration							
Corrected to 11% O2	CSO2	mg/Rcm	$CSO_2 (11\% O_2) = CSO_2 (mg/Rcm) \times (20.9-11) / (20.9-CSO_2)$	4.97	6.56	7.61	7.05
Corrected to 3% O2	CSO2	mg/Rcm	$CSO_2 (3\% O_2) = CSO_2 (mg/Rcm) \times (20.9-3) / (20.9-CSO_2)$	8.98	15.51	13.75	12.75
Corrected to 12% CO2	CSO2	mg/Rcm	$CSO_2 (12\% CO_2) = CSO_2 (mg/Rcm) \times (12/CSO_2)$	10.71	16.48	14.99	14.73
Nitrogen Oxides - NOx							
NOx Measured Concentration	CNOx	ppm	Measurement from Flow Gas Analyser	66.57	83.14	59.43	63.05
Uncorrected @ Ref Cond	CNOx	mg/Rcm	$CNO_x (mg/Rcm) = CNO_x (ppm) \times 1.882$	125.29	118.83	111.84	118.66
NOx Emission Rate	ERNox	g/s kg/hr	$ER_{NO_x} = CNO_x/1000 \times Q_d$ $ER_{NO_x} (kg/hr) = 3.6 \times ER_{NO_x} (g/s)$	8.86 31.89	9.05 32.59	9.45 34.01	9.12 32.83
NOx Concentration							
Corrected to 11% O2	CNOx	mg/Rcm	$CNO_x (11\% O_2) = CNO_x (mg/Rcm) \times (20.9-11) / (20.9-CSO_2)$	87.50	82.51	71.03	80.35
Corrected to 3% O2	CNOx	mg/Rcm	$CNO_x (3\% O_2) = CNO_x (mg/Rcm) \times (20.9-3) / (20.9-CSO_2)$	158.20	149.18	128.43	145.27
Corrected to 12% CO2	CNOx	mg/Rcm	$CNO_x (12\% CO_2) = CNO_x (mg/Rcm) \times (12/CSO_2)$	188.60	177.84	140.01	168.02
Carbon Monoxide - CO							
CO Measured Concentration	CCO	ppm	Measurement from Flow Gas Analyser	96.14	119.71	235.57	150.48
Uncorrected @ Ref Cond	CCO	mg/Rcm	$CCO (mg/Rcm) = CCO (ppm) \times 1.145$	110.08	137.07	269.73	172.30
CO Emission Rate	ERCO	g/s kg/hr	$ER_{CO} = CCO/1000 \times Q_d$ $ER_{CO} (kg/hr) = 3.6 \times ER_{CO} (g/s)$	7.78 28.02	10.44 37.59	22.79 82.03	13.67 49.21
CO Concentration							
Corrected to 11% O2	CCO	mg/Rcm	$CCO (11\% O_2) = CCO (mg/Rcm) \times (20.9-11) / (20.9-CSO_2)$	78.86	95.17	171.30	114.45
Corrected to 3% O2	CCO	mg/Rcm	$CCO (3\% O_2) = CCO (mg/Rcm) \times (20.9-3) / (20.9-CSO_2)$	139.01	172.08	309.72	206.94
Corrected to 12% CO2	CCO	mg/Rcm	$CCO (12\% CO_2) = CCO (mg/Rcm) \times (12/CSO_2)$	165.72	205.13	337.66	236.17
Particulate Concentration	Cs	mg/Rcm	$C_s = M_p \times V_{mc}$	10.90	5.42	0.11	5.48
Particulate Emission Rate	ERP	g/s kg/hr	$ERP = C_s/1000 \times Q_d$ $ERP (kg/hr) = 3.6 \times ERP (g/s)$	0.77 2.77	0.41 1.49	0.01 0.03	0.40 1.43
Particulate Concentration							
Corrected to 11% O2	Cs	mg/Rcm	$C_s (11\% O_2) = C_s \times (20.9-11) / (20.9-CSO_2)$	7.61	3.76	0.07	3.81
Corrected to 3% O2	Cs	mg/Rcm	$C_s (3\% O_2) = C_s \times (20.9-3) / (20.9-CSO_2)$	13.77	6.80	0.12	6.90
Corrected to 12% CO2	Cs	mg/Rcm	$C_s (12\% CO_2) = C_s \times (12/CSO_2)$	16.41	8.11	0.13	8.22

Legend: sq ft - square feet
 sq m - square metres
 ft - 1/12
 R - degrees Rankin
 ppm - parts per million
 in Hg - inches of mercury
 cu ft - cubic feet
 cu m - cubic metres
 Ref Cond - reference temperature and pressure (25 C and 101.3 kPa)
 Rcfm - dry reference cubic metres per second
 Rcfm - dry reference cubic feet per minute
 mg/Rcm - milligrams per dry reference cubic metre
 g/s - grams per second
 NOx - as NO2
 acfm - actual cubic feet per minute

OFFICIAL STACK TESTING RESULTS

Northern Pulp

Pictou, NS

Fuel: Fuel oil

Operating Conditions: normal

Emission Control Equipment: precipitator

Stack Height from Grade: 69 m

Stack Diameter: 3.51 m

Parameter	Test 1	Test 2	Test 3	Average	NSENV Limits
Test ID	PM-1	PM-2	PM-3	-	-
Test Date	23-Jul-15	23-Jul-15	24-Jul-15	-	-
Stack Gas Temperature (C)	65.5	65.5	68.1	66.4	-
Moisture Content (%)	27.4	27.6	29.9	28.3	-
Velocity (m/s)	11.8	12.7	14.3	12.9	-
Volumetric Flow (Rcms)	70.7	76.2	84.5	77.1	-
Oxygen - O2 (%)	6.72	6.64	5.31	6.23	-
Carbon Dioxide - CO2 (%)	7.97	8.02	9.59	8.53	-
Sulphur Dioxide - SO2					
SO2 Measured Concentration (ppm)	2.71	4.71	4.57	4.00	-
Uncorrected at Ref Cond (mg/Rcm)	4.97	8.58	7.61	7.05	-
Emission Rate (kg/hr)	1.81	3.39	3.64	2.95	-
Nitrogen Oxides - NOx					
NOx Measured Concentration (ppm)	66.6	63.1	59.4	63.0	-
Uncorrected at Ref Cond (mg/Rcm)	125.3	118.8	111.8	118.7	-
Emission Rate (kg/hr)	31.89	32.59	34.01	32.83	-
Carbon Monoxide - CO					
CO Measured Concentration (ppm)	96.1	119.7	235.6	150.5	-
Uncorrected at Ref Cond (mg/Rcm)	110.1	137.1	269.7	172.3	-
Emission Rate (kg/hr)	28.02	37.59	82.03	49.21	-
Particulate Matter - PM					
Particulate Concentration (mg/Rcm)	10.9	5.42	0.11	5.48	-
Concentration, Corrected to 11% O ₂ (mg/Rcm)	7.61	3.76	0.07	3.81	375
Particulate Emission Rate (kg/hr)	2.77	1.49	0.03	1.43	-

Legend: C - degrees Celsius
m/s - metres per second
Rcms - dry reference cubic metres per second
ppm - parts per million

Ref Cond - reference temperature and pressure (25 C and 101.3 kPa)
mg/Rcm - milligrams per dry reference cubic metre
NOx - as NO2
ND - non-detectable

Particulate Resuspension - Impinger Catch, Probe Wash, Filter Catch

Client: Washington State
 Facility: Bozeman School
 Location: Bozeman, MT
 Job Number: 22-01348

MPW0288 CATCH

Container ID	Residue PVA Weights (µg)				Sample ID	Resuspension				Total Probe Water (µl)	Residue PVA Weights (µg)				Unscrubbed Particulate Weight (µg)	Corrected Particulate Weight (µg)
	Date					Air + Sample + Residue (µg)	Jar Tare (µg)	Sample Collected (µg)	Probe Water (µl)		Date					
	Trail 1	Trail 2	Trail 3	Average							Trail 1	Trail 2	Trail 3	Average		
01	111.0951	111.0911		111.0951	PM 1	303.2	303.3	303.1	0.3	109.7	111.0958	111.0987		111.0958	0.0016	0.0015
144	117.6483	117.6480		117.6482	PM 2	870.8	867.8	869.8	0.3	88.7	117.6524	117.6523		117.6523	0.0011	0.0011
153	108.0719	108.0719		108.0719	PM 1	1068.9	1071.7	1069.7	3.7	80.2	108.2054	108.2049		108.2052	0.0013	0.0013
1.1	109.1920	109.1924		109.1922	WT	484.7	483.0	483.7		92.7	109.1884	109.1881		109.1882	0.0010	0.0010

PROBE WASH




Container ID	Residue PVA Weights (µg)				Sample ID	Resuspension				Total Probe Water (µl)	Residue PVA Weights (µg)				Unscrubbed Particulate Weight (µg)	Corrected Particulate Weight (µg)
	Date					Air + Residue (µg)	Jar Tare (µg)	Resuspended Residue (µg)	Probe Residue (µg)		Date					
	Trail 1	Trail 2	Trail 3	Average							Trail 1	Trail 2	Trail 3	Average		
01	112.9248	112.9243		112.9246	PM 1	473.2	391.9	63.8	4.8	60.4	112.9122	112.9100		112.9111	0.0011	0.0011
153	111.1518	111.1518		111.1518	PM 2	438.5	392.5	44.0	4.9	60.0	111.1523	111.1524		111.1524	0.0011	0.0011
04	111.9877	111.9879		111.9878	PM 1	449.1	392.1	64.8	6.4	60.2	111.9897	111.9872		111.9885	0.0011	0.0011
07	111.2480	111.2481		111.2481	AR	373.2	372.2	41.0		41.0	111.2484	111.2483		111.2484	0.0010	0.0010

Capacity of Asesor 0.7880 grams

PM 101 CATCH

Filter ID	PVA Weights (µg)				Sample ID	Probe Weights (µg)				Particulate Weight from Filter (µg)
	Date					Date				
	Trail 1	Trail 2	Trail 3	Average		Trail 1	Trail 2	Trail 3	Average	
0726.17	0.3030	0.3032		0.3031	PM 1	0.3090	0.3090		0.3090	0.0060
0716.14	0.3027	0.3030		0.3029	PM 1	0.3078	0.3073		0.3076	0.0048
0716.18	0.3027	0.3018		0.3022	PM 2	0.3030	0.3036		0.3033	0.0017
0716.15	0.3014	0.3012		0.3013	CU 1	0.3016	0.3016		0.3016	0.0002

Stack Gas Velocity Profiles
Pictou, NS



GAS CALCULATIONS

Client: Northern Pulp
 Plant: Pictou
 Location: High Level Roof Vent

	O ₂ (%)	CO ₂ (%)	CO (ppm)	SO ₂ (ppm)	NO _x (ppm)
ave. Gas 1	20.9	0.2	132.2	1.8	18.9
ave. Gas 2	20.9	0.2	137.5	1.7	19.6
ave. Gas 3	20.9	0.2	145.2	1.7	18.7

All gas data except Nox obtained from TRS data

Test 1	O ₂ (%)	CO ₂ (%)	CO (ppm)	SO ₂ (ppm)	NO _x (ppm)
Time					
12:00	20.90	0.23	132.23	1.76	15
12:05					19
12:10					23
12:15					21
12:20					19
12:25					17
12:30					18

All gas data except Nox obtained from TRS data

Test 2	O ₂ (%)	CO ₂ (%)	CO (ppm)	SO ₂ (ppm)	NO _x (ppm)
Time					
11:00	20.90	0.23	137.55	1.66	24
11:05					17
11:10					16
11:15					21
11:20					22
11:25					20
11:30					17

All gas data except Nox obtained from TRS data

Test 3	O ₂ (%)	CO ₂ (%)	CO (ppm)	SO ₂ (ppm)	NO _x (ppm)
Time					
13:00	20.89	0.23	145.15	1.66	13
13:05					19
13:10					27
13:15					21
13:20					16
13:25					15
13:30					20

Raw Data for: Northern Pulp Fall Source Testing
 Test #1

Client: Northern Pulp
 Job Number: 121412456
 Plant: Pictou
 Location: High Level Roof Vent
 Test: Flow 1
 Date: 24-Jul-15
 Personnel: TBJ/SJM
 Test Start: 10:30 AM
 Test Finish: 11:00 AM

Parameters
 Barometric Pressure, Pbar (In. Hg)
 Stack Static Pressure, Pstatic (In. H2O)
 Ambient Temp, (°F)
 Assumed Moisture Content (as decimal)

30.00
 0.17
 61
 0.3

O2, (%)
 CO2, (%)
 N2, (%)

20.9
 0.2
 79.9

Stack Diameter, (In.)
 Stack Area, (sq. ft.)
 Pitot Coefficient, (Cp)

12
 28.27
 0.840

	Traverse Point	Time (min)	Stack Gas Temp, Ts (°F)	S-type Pitot delta P (In. H2O)
1	1	30	129	0.74
	2		129	0.78
	3		129	0.82
	4		129	0.84
	5		130	0.95
	6		130	0.99
	7		130	1.01
	8		130	1.10
	9		130	1.25
	10		130	0.99
	11		130	0.99
	12		131	0.95
2	1		130	0.76
	2		130	0.78
	3		130	0.84
	4		130	0.89
	5		130	0.90
	6		130	0.99
	7		130	1.00
	8		130	1.10
	9		130	1.25
	10		130	0.99
	11		130	0.99
	12		130	0.84

**Calculations for: Northern Pulp Fall Source Testing
Test #1**

Client: Northern Pulp
Job Number: 121413458
Plant: Picou
Location: High Level Roof Vent
Test: Flow 1
Date: 24-Jul-15
Personnel: TBH/NGM

Calculated Parameters

Stack Gas Pressure, Ps (in. Hg) 30.01
Stack Gas Molecular Weight, Dry Basis, Md (lb/lb-mole) 28.87
Volume of Water Vapour Collected, Vwc (cu.ft) 0.014
Stack Gas Moisture Content (% as decimal) 0.300
Stack Gas Molecular Weight, Wet Basis, Mw (lb/lb-mole) 25.61

	Traverse Point	Time (min)	Stack Gas Temp, Ts (R)	S-type Pitot, delta P (in. H2O)	Stack Gas Velocity, Us (ft/s)
1	1	30	589	0.74	53.97
	2		589	0.78	55.41
	3		589	0.82	56.82
	4		589	0.84	57.51
	5		590	0.95	61.21
	6		590	0.99	62.48
	7		590	1.05	64.35
	8		590	1.10	65.88
	9		590	1.05	64.35
	10		590	0.99	62.48
	11		589	0.99	62.43
	12		591	0.95	61.26
2	1		589	0.76	54.70
	2		589	0.78	55.41
	3		588	0.84	57.46
	4		588	0.89	59.14
	5		590	0.90	59.58
	6		590	0.99	62.48
	7		590	1.00	62.80
	8		589	1.10	65.81
	9		589	1.05	64.29
	10		589	0.98	62.11
	11		590	0.89	59.24
	12		590	0.84	57.55
	Total	30	Average 589	Average 0.93	Average 60.4

Raw Data for: Northern Pulp Fall Source Testing

Test #2

Client: Northern Pulp
 Job Number: 121412456
 Plant: Pictou
 Location: High Level Roof Vex
 Test: Flow 2
 Date: 24-Jul-15
 Personnel: BBN/MJM
 Test Start: 11:00 AM
 Test Finish: 11:30 AM

Parameters

Barometric Pressure, Pbar (In. Hg)
 Stack Static Pressure, Pstatic (In. H2O)
 Ambient Temp, (°F)
 Assumed Moisture Content (as decimal)

30.09
 0.17
 63
 0.3

O2, (%)
 CO2, (%)
 N2, (%)

20.9
 0.2
 78.9

Stack Diameter, (In.)
 Stack Area, (sq. Ft.)
 Pitot Coefficient, (Cp)

72
 28.27
 0.840

	Traverse Point	Time (min)	Stack Gas Temp, Tg (°F)	B-type Pitot delta P (In. H2O)
1	1	30	130	0.79
	2		131	0.82
	3		131	0.88
	4		131	0.92
	5		131	0.96
	6		131	0.99
	7		131	1.16
	8		130	1.06
	9		129	1.00
	10		128	0.95
	11		127	0.85
	12		125	0.80
2	1	30	130	0.79
	2		131	0.82
	3		131	0.88
	4		131	0.92
	5		131	0.96
	6		131	0.99
	7		131	1.16
	8		130	1.06
	9		129	1.00
	10		128	0.95
	11		127	0.85
	12		125	0.80

Calculations for: Northern Pulp Fall Source Testing
 Test #1

Client: Northern Pulp
 Job Number: 121413458

Plant: Pictou
 Location: High Level Roof Vent
 Test: Flow 2
 Date: 24-Jul-15
 Personnel: bryngm

Calculated Parameters

Stack Gas Pressure, Ps (in-Hg)	30.01
Stack Gas Molecular Weight, Dry Basis, Md (lb/lb-mole)	28.87
Volume of Water Vapour Collected, Vwc (cu ft)	0.014
Stack Gas Moisture Content (% as dec/mal)	0.200
Stack Gas Molecular Weight, Wet Basis, Mw (lb/lb-mole)	25.61

	Traverse Point	Time (min)	Stack Gas Temp, Ts (R)	S-type Pitot, delta P (in. H2O)	Stack Gas Velocity, Us (ft/s)
1	1	30	590	0.79	55.82
	2		591	0.82	56.91
	3		591	0.86	58.96
	4		591	0.92	60.28
	5		591	0.96	61.58
	6		591	0.99	62.54
	7		591	1.10	65.92
	8		590	1.00	62.80
	9		589	1.00	62.74
	10		588	0.95	61.10
	11		587	0.85	57.75
	12		588	0.80	56.07
2	1		590	0.79	55.82
	2		591	0.82	56.91
	3		591	0.86	58.96
	4		591	0.92	60.28
	5		591	0.96	61.58
	6		591	0.99	62.54
	7		591	1.10	65.92
	8		590	1.00	62.80
	9		589	1.00	62.74
	10		588	0.95	61.10
	11		587	0.85	57.75
	12		588	0.80	56.07
	Total	30	Average 590	Average 0.92	Average 60.2

Raw Data for: Northern Pulp Fall Source Testing
Test #3

Client: Northern Pulp
 Job Number: 121412456
 Plant: Pictou
 Location: High Level Roof Vent
 Test: Flow 3
 Date: 24-Jul-15
 Personnel: TBM/HGM
 Test Start: 11:30 AM
 Test Finish: 12:00 PM

Parameters

Barometric Pressure, Pbar (in. Hg) 30.00
 Stack Static Pressure, Pstatic (in. H2O) 0.17
 Ambient Temp, (°F) 65
 Assumed Moisture Content (as decimal) 0.3

O2 (%) 20.9
 CO2 (%) 0.2
 N2 (%) 78.9

Stack Diameter, (in.) 72
 Stack Area, (sq. ft.) 36.27
 Pitot Coefficient, (Cp) 0.84

	Traverse Point	Time (min)	Stack Gas Temp, Tg (°F)	S-type Pitot delta P (in. H2O)
1	1	30	127	0.74
	2		130	0.84
	3		127	0.89
	4		128	0.92
	5		129	0.97
	6		130	0.99
	7		131	1.00
	8		130	1.10
	9		129	1.00
	10		128	0.99
	11		130	0.89
	12		130	0.80
2	1		127	0.78
	2		128	0.84
	3		127	0.89
	4		127	0.92
	5		129	0.99
	6		130	0.99
	7		130	1.00
	8		128	1.10
	9		131	1.00
	10		131	0.99
	11		131	0.90
	12		131	0.80

Calculations for: Northern Pulp Mill Source Testing
 Test #1

Client: Northern Pulp
 Job Number: 121413458
 Plant: Pictou
 Location: High Level Roof Vent
 Test: Flow 3
 Date: 24-Jul-15
 Personnel: TBM/TKGM

Calculated Parameters

Stack Gas Pressure, Ps (in. Hg)	30.01
Stack Gas Molecular Weight, Dry Basis, Md (lb/lb-mole)	28.87
Volume of Water Vapour Collected, Vwc (cu. ft)	0.014
Stack Gas Moisture Content (% as decimal)	0.300
Stack Gas Molecular Weight, Wet Basis, Mw (lb/lb-mole)	25.81

	Traverse Point	Time (min)	Stack Gas Temp, Ts (F)	S-type Pitot, delta P (in. H2O)	Stack Gas Velocity, Us (ft/s)
1	1	30	587	0.74	53.86
	2		590	0.86	58.24
	3		587	0.89	59.09
	4		588	0.92	60.13
	5		589	0.87	61.80
	6		590	0.99	62.48
	7		591	1.00	62.85
	8		590	1.10	65.86
	9		589	1.00	62.74
	10		588	0.99	62.38
	11		590	0.89	59.24
	12		590	0.80	56.17
2	1		587	0.78	55.32
	2		588	0.84	57.46
	3		587	0.89	59.09
	4		587	0.92	60.08
	5		589	0.99	62.43
	6		590	1.00	62.80
	7		588	1.10	65.75
	8		591	1.00	62.85
	9		591	0.99	62.54
	10		591	0.95	61.25
	11		591	0.80	59.83
	12		591	0.80	56.22
	Total	30	Average	Average	Average
			589	0.93	60.4

CALCULATIONS
 Northern Pulp
 Pictou
 High Level Roof Vent
 Operating Conditions: Normal

Reference Temperature, Tref (F): 77
 (K): 298
 Reference Pressure, Pref (in.Hg): 29.92
 (Bar): 1.0

Parameter	Symbol	Units	Test 1	Test 2	Test 3	Average
Test ID	-	-	Flow 1	Flow 2	Flow 3	n/a
Date	-	-	24-Jul-15	24-Jul-15	24-Jul-15	n/a
Start Time	-	-	10 30 AM	11 00 AM	11 30 AM	n/a
End Time	-	-	11 00 AM	11 30 AM	12 00 PM	n/a
Total Sampling Time	-	min	30	30	30	30
Stack Diameter	D	in.	72	72	72	72
Average Stack Gas Temperature	Ts	F	129	130	129	129
Barometric Pressure	Pbar	in.Hg	30.0	30.0	30.0	30.0
Stack Static Pressure	Pstatic	in.H ₂ O	0.17	0.17	0.17	0.17
Average Pressure Drop (Head)	dP	in.H ₂ O	0.93	0.92	0.93	0.93
Pitot Coefficient	Cp	-	0.840	0.840	0.840	0.840
Reference Temperature	Tref	R	537	537	537	537
Reference Pressure	Pref	in.Hg	29.92	29.92	29.92	29.92
Water Fraction	Bwo		0.30	0.30	0.30	0.30
Average Stack Velocity	Us	ft/s	60.4	60.2	60.4	60.3
Actual Flow Rate	Acfm	cu.ft/m	102,404	102,137	102,514	102,352
Dry Standard Flow Rate	Dscfm	cu.ft/m	65,505	65,293	65,608	65,469
Dry Standard Flow Rate	MMSCFH		3.93	3.92	3.94	3.93
Dry Standard Flow Rate	Rm ³ /s		30.9	30.8	31.0	30.9

GAS CALCULATIONS
Northern Pulp
Pictou
High Level Roof Vent

Variable	Symbol	Units	Calculation	Test 1	Test 2	Test 3	Average
Dry Stack Gas Flow Rate	Q _s	dcfm dscms	$Q_s \text{ (dscms)} = 0.000473 \times Q_s \text{ (dcfm)}$	85,505 30.9	65,293 30.8	85,608 31.0	65,469 30.9
Stack Gas Oxygen Content	Co ₂	%	Measurement from Flue Gas Analyzer	20.9	20.9	20.9	20.9
Stack Gas Carbon Dioxide Content	Cco ₂	%	Measurement from Flue Gas Analyzer	0.2	0.2	0.2	0.2
Sulphur Dioxide - SO ₂							
SO ₂ Measured Concentration Uncorrected @ STP	Cso ₂	ppm	Measurement from Flue Gas Analyzer	1.76	1.66	1.68	1.70
SO ₂ Emission Rate	ERso ₂	mg/dscm g/s kg/hr	$C_{so2} \text{ (mg/dscm)} = C_{so2} \text{ (ppm)} \times 2.62$ $ER_{so2} = C_{so2}/1000 \times Q_s$ $ER_{so2} \text{ (kg/hr)} = 3.6 \times ER_{so2} \text{ (g/s)}$	4.62 0.14 0.51	4.35 0.13 0.48	4.36 0.13 0.49	4.44 0.14 0.49
SO ₂ Concentration							
Nitrogen Oxides - NO _x							
NO _x Measured Concentration Uncorrected @ STP	Cno _x	ppm	Measurement from Flue Gas Analyzer	18.9	19.6	18.7	19.0
NO _x Emission Rate	ERno _x	mg/dscm g/s kg/hr	$C_{nox} \text{ (mg/dscm)} = C_{nox} \text{ (ppm)} \times 1.892$ $ER_{nox} = C_{nox}/1000 \times Q_s$ $ER_{nox} \text{ (kg/hr)} = 3.6 \times ER_{nox} \text{ (g/s)}$	35.5 1.10 3.95	36.8 1.14 4.09	35.2 1.09 3.93	35.8 1.11 3.99
NO _x Concentration							
Carbon Monoxide - CO							
CO Measured Concentration Uncorrected @ STP	Cco	ppm	Measurement from Flue Gas Analyzer	132	138	145	138
CO Emission Rate	ERco	mg/dscm g/s kg/hr	$C_{co} \text{ (mg/dscm)} = C_{co} \text{ (ppm)} \times 1.145$ $ER_{co} = C_{co}/1000 \times Q_s$ $ER_{co} \text{ (kg/hr)} = 3.6 \times ER_{co} \text{ (g/s)}$	151 4.68 16.9	157 4.85 17.5	166 5.15 18.5	158 4.89 17.6
CO Concentration							

Legend: sq ft - square feet
sq m - square metres
ft - 3.142
R - degrees Rankin
ppm - parts per million

in Hg - inches of mercury
cu ft - cubic feet
cu m - cubic metres
STP - standard temperature and pressure (25 C and 101.3 kPa)
dscms - dry standard cubic metres per second
dcfm - dry standard cubic feet per minute

mg/dscm - milligrams per dry standard cubic metre
g/s - grams per second
NO_x - as NO₂
acfm - actual cubic feet per minute

**STACK TESTING RESULTS
GAS CALCULATIONS
Northern Pulp
Pictou
High Level Roof Vent**

Parameter	Test 1	Test 2	Test 3	Average	Limits
Oxygen - O ₂ (%)	20.9	20.9	20.9	20.9	-
Carbon Dioxide - CO ₂ (%)	0.2	0.2	0.2	0.2	-
Sulphur Dioxide - SO ₂					
SO ₂ Measured Concentration (ppm)	1.76	1.66	1.66	1.70	-
Uncorrected at STP (mg/dscm)	4.62	4.35	4.36	4.44	-
Emission Rate (kg/hr)	0.51	0.48	0.49	0.49	-
Nitrogen Oxides - NO _x					
NO _x Measured Concentration (ppm)	18.9	19.6	18.7	19.0	-
Uncorrected at STP (mg/dscm)	35.5	36.8	35.2	35.8	-
Emission Rate (kg/hr)	3.95	4.09	3.93	3.99	-
Carbon Monoxide - CO					
CO Measured Concentration (ppm)	132	138	145	138	-
Uncorrected at STP (mg/dscm)	151	157	166	158	-
Emission Rate (kg/hr)	16.9	17.5	18.5	17.6	-




Legend: C - degrees Celsius
m/s - metres per second
dscms - dry standard cubic metres per second
ppm - parts per million

STP - standard temperature and pressure (25 C and 101.3 kPa)
mg/dscm - milligrams per dry standard cubic metre
NO_x - as NO₂
ND - non-detectable

Raw Data for:
Pictou

Job No. 121413456

Northern Pulp Fall Source Testing Velocity Profile



Raw Data for: Lime Kiln Particulate Matter Testing

Test #1
 Client: Northern Pulp
 Job Number: 121412456
 Plant: Lime Kiln
 Location: Plover, NB
 Test: P3-1
 Date: 21-Jul-15
 Personnel: TDB:SF
 Test Start: 9:05 AM
 Test Finish: 11:12 AM

Particulate Collected from Filter (mg): 243.4
 Particulate Collected from Probe Wash (mg): 43.1
 Particulate Collected from Impinger Wash (mg): 20.5
 Total Particulate Collected (mg): 306.9

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H2O	804.1	870.2	323.9
2	100 mL H2O	732.5	708.2	24.3
3	Blank	989.3	985.7	2.6
4	200g Seals Gel	988.3	958.5	7.8
Total Weight Gain (g)				358.6
Moisture Volume (mL)				358.6

Parameters
 Barometric Pressure, Pbar (in. Hg)
 Stack Static Pressure, Pstatic (in. H2O)
 Ambient Temp, (°F)
 H2O Volume Collected, Vw (mL)
 Total # Sampling Points,
 Sampling Time per Point, (min)
 Readings Taken Every ___ mins
 Regulatory Agency

29.70	CARBON POINT	O2 (%)	4.44
0.31		CO2 (%)	23.12
43		N2 (%)	73.2
116.4			
24			
3			
2.3			

Stack Diameter, (in.)	48
Stack Area, (sq. ft.)	12.37
Probe Length, (in.)	8
Nozzle Diameter, (in.)	0.172
Pitot Coefficient, (Cp)	0.816
Gammex, meter constant	1.031

Traverse Point	Time (min)	Stack Gas Temp, Ts (°F)	8-type Pitot delta P (in. H2O)	Orifice delta H (in. H2O)	Gas Meter Volume (cu. ft.)	Gas Meter Temp Inlet (°F)	Gas Meter Temp Outlet (°F)	Nozzle Angle (Cyclonic Flow) (deg. from vert.) (+ clockwise)	
Traverse 1	1	2.5	157	0.58	0.24	156.750	87	64	-15
	2	5	159	0.56	0.23	157.460	85	64	-15
	3	7.5	158	0.58	0.24	158.140	85	64	-14
	4	10	161	0.60	0.25	159.490	83	66	-16
	5	12.5	161	0.52	0.22	160.120	83	66	-23
	6	15	162	0.39	0.21	160.340	83	66	-25
	7	17.5	162	0.33	0.14	161.270	83	66	-20
	8	20	162	0.33	0.14	161.810	83	66	-20
	9	22.5	162	0.40	0.17	162.390	83	66	-18
	10	25	162	0.40	0.17	162.980	83	66	-10
	11	27.5	162	0.45	0.19	163.590	83	66	0
	12	30	162	0.42	0.17	164.150	83	66	0
Traverse 2	1	32.5	162	0.44	0.18	164.540	86	66	0
	2	35	162	0.47	0.19	165.340	86	66	0
	3	37.5	162	0.51	0.22	165.990	86	66	10
	4	40	163	0.52	0.21	166.630	85	66	10
	5	42.5	163	0.36	0.21	167.270	83	66	20
	6	45	163	0.31	0.21	167.820	83	66	20
	7	47.5	164	0.30	0.21	168.350	83	66	28
	8	50	162	0.30	0.21	168.760	83	66	28
	9	52.5	161	0.48	0.19	170.380	83	63	33
	10	55	161	0.48	0.20	170.980	83	63	33
	11	57.5	161	0.47	0.19	171.590	83	63	42
	12	60	161	0.47	0.19	171.990	83	63	42
Traverse 3	1	62.5	159	0.61	0.23	172.360	83	64	-15
	2	65	159	0.63	0.26	172.960	83	64	-15
	3	67.5	159	0.60	0.23	173.640	83	64	-15
	4	70	161	0.62	0.26	174.330	84	64	-15
	5	72.5	161	0.78	0.34	175.040	84	64	-15
	6	75	160	0.59	0.24	175.720	84	64	-23
	7	77.5	161	0.54	0.21	176.380	84	64	-20
	8	80	161	0.21	0.22	176.980	84	64	-20
	9	82.5	161	0.42	0.21	177.620	84	64	-10
	10	85	161	0.40	0.17	178.230	84	64	0
	11	87.5	156	0.35	0.14	178.720	84	64	0
	12	90	160	0.30	0.12	179.170	84	64	0
Traverse 4	1	92.5	155	0.40	0.17	179.740	84	64	0
	2	95	153	0.43	0.18	180.340	84	64	0
	3	97.5	153	0.45	0.19	180.930	84	63	12
	4	100	154	0.38	0.21	181.570	84	63	12
	5	102.5	155	0.69	0.28	182.300	84	63	20
	6	105	155	0.71	0.30	183.050	84	63	20
	7	107.5	158	0.79	0.33	183.840	83	64	30
	8	110	158	0.80	0.33	184.610	83	64	30
	9	112.5	158	0.30	0.21	185.250	83	64	33
	10	115	160	0.48	0.20	185.880	83	64	33
	11	117.5	158	0.48	0.20	186.510	83	64	43
	12	120	155	0.47	0.19	187.130	87	63	43

Calculations for: Lime Kiln Particulate Matter Testing
Test #1

Client: Northern Pulp
Job Number: 121415C08

Plant: Lime Kiln
Location: Pictou, NS
Test: PM10
Date: 31-Jul-15
Personnel: TBV/SF

Calculated Parameters

Stack Gas Pressure, P_s (in.Hg)
Stack Gas Molecular Weight, Dry Basis, M_d (lb/lb-mole)
Volume of Water Vapor Collected, V_{wc} (cu ft)
Stack Gas Moisture Content (% as decimat)
Stack Gas Molecular Weight, Wet Basis, M_w (lb/lb-mole)

29.74
31.72
17.313
0.369
29.88

Isokineticity Checks

Check range: Within Criteria
Check average: Outside of Criteria

Traverse Point	Time (min)	Stack Gas Temp, T _s (R)	S-type Ptact, d _{50% P} (in. H ₂ O)	Orifice d _{50% H} (in. H ₂ O)	Measured Stack Gas Velocity, U _s (ft/s)	Vertical Stack Gas Velocity, U _v (ft/s)	Meter Press., P _m (in. Hg)	Avg. Temp, T _m (R)	Gap Meter Volume, V _{gc} (cu. ft.)	Vol. @ Ref. V _{mc} (cu. ft.)	Mathematical (%)	
Traverse 1	1	2.3	017	0.58	0.24	46.81	32.98	29.72	537	0.700	0.719	114.15
		5	018	0.28	0.23	46.87	32.44	29.72	536	0.680	0.700	113.25
	2	7.5	018	0.58	0.24	46.64	37.74	29.72	536	0.690	0.709	112.77
		10	021	0.80	0.25	47.58	38.47	29.72	536	0.980	0.679	105.36
	3	12.9	021	0.52	0.22	44.27	40.13	29.72	536	0.630	0.648	109.03
		15	022	0.30	0.21	43.45	39.38	29.71	538	0.530	0.556	110.01
	4	17.9	022	0.35	0.14	36.35	34.18	29.72	538	0.620	0.636	109.53
		20	022	0.40	0.17	39.88	36.27	29.71	538	0.540	0.545	111.88
	8	22.9	022	0.40	0.17	39.88	36.27	29.71	538	0.540	0.556	110.01
		25	022	0.40	0.17	39.88	36.27	29.71	538	0.540	0.587	114.55
	9	27.9	022	0.45	0.19	41.22	38.27	29.71	538	0.980	0.807	119.52
		30	022	0.42	0.17	39.62	39.62	29.71	538	0.810	0.628	113.56
7	32.9	022	0.47	0.19	42.12	44.05	29.71	538	0.960	0.578	107.83	
	35	022	0.44	0.18	40.78	40.78	29.71	538	0.900	0.808	111.00	
8	37.9	022	0.53	0.22	44.73	42.12	29.71	538	0.800	0.617	109.22	
	40	022	0.53	0.22	44.73	44.05	29.72	538	0.800	0.859	111.45	
9	42.9	023	0.52	0.21	44.34	41.87	29.72	538	0.830	0.828	111.43	
	45	023	0.50	0.21	43.56	38.64	29.72	538	0.850	0.859	111.48	
10	47.9	025	0.51	0.21	43.88	40.83	29.72	538	0.840	0.858	113.34	
	50	024	0.50	0.21	43.52	36.42	29.72	538	0.830	0.859	113.97	
11	52.9	022	0.48	0.20	42.57	35.58	29.72	538	0.830	0.648	111.30	
	55	022	0.48	0.20	42.57	34.87	29.71	535	0.580	0.587	104.67	
12	57.9	021	0.47	0.18	42.08	31.28	29.71	535	0.620	0.578	112.98	
	60	021	0.48	0.20	42.54	31.81	29.71	535	0.620	0.628	111.80	
Traverse 2	1	62.9	018	0.81	0.25	47.87	33.85	29.72	535	0.670	0.681	107.12
		65	019	0.83	0.26	48.65	34.40	29.72	535	0.700	0.722	110.12
	2	67.9	019	0.80	0.25	47.48	38.80	29.72	535	0.680	0.701	109.82
		70	021	0.82	0.26	48.34	39.60	29.72	534	0.710	0.723	112.88
	3	72.9	021	0.58	0.24	46.78	42.38	29.72	534	0.880	0.712	113.41
		75	020	0.58	0.24	47.17	42.71	29.72	534	0.880	0.881	112.43
	4	77.9	021	0.54	0.22	45.12	42.71	29.72	534	0.880	0.881	112.43
		80	021	0.51	0.21	43.85	41.20	29.72	534	0.850	0.881	112.18
	6	82.9	021	0.42	0.17	38.79	38.18	29.71	534	0.590	0.587	108.64
		85	021	0.40	0.17	36.83	38.29	29.71	534	0.570	0.484	102.40
	7	87.9	020	0.35	0.14	36.29	36.29	29.71	534	0.550	0.587	108.64
		90	016	0.30	0.12	33.46	33.49	29.71	534	0.570	0.586	120.48
8	92.9	015	0.40	0.16	40.07	38.64	29.71	534	0.610	0.648	112.25	
	95	015	0.43	0.17	38.64	38.64	29.71	534	0.600	0.619	113.97	
9	97.9	015	0.45	0.18	40.07	40.07	29.71	534	0.610	0.630	113.37	
	100	014	0.50	0.21	43.17	42.22	29.72	534	0.620	0.649	108.23	
10	102.9	018	0.89	0.29	50.75	47.88	29.72	534	0.730	0.754	108.58	
	105	015	0.70	0.20	51.52	48.42	29.72	534	0.750	0.775	111.08	
11	107.9	018	0.78	0.33	54.44	47.14	29.72	534	0.780	0.813	110.81	
	110	018	0.80	0.33	54.78	47.44	29.72	535	0.770	0.794	107.43	
12	112.9	016	0.50	0.21	43.21	35.48	29.72	535	0.640	0.680	112.81	
	115	016	0.48	0.20	42.50	34.82	29.71	535	0.630	0.648	113.62	
	117.9	016	0.48	0.20	42.43	30.01	29.71	535	0.630	0.648	113.64	
	120	015	0.45	0.18	40.99	28.98	29.71	534	0.610	0.627	112.84	
Total	80		Average 020	Average 0.31	Average 0.21	Average 43.80	Average 38.84	Average 29.72	Total 534.88	Total 30.420	Total 31.338	Average 111.48

Combustion Gas Data for: Northern Pulp

Client: Northern Pulp
Job Number: 121413456

Plant: Lime Kiln
Location: Pictou, NS
Test: PM-1
Date: 21-Jul-15
Personnel: TBH/SF

Test Start: 10:30
Test Finish: 11:00

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
0	4.64	22.12	7	2	102
5					111
10					129
15					125
20					114
25					117
30					120
Average:	4.6	22.1	6.9	1.7	116.9

Raw Data for: Lime Kiln Particulate Matter Testing
Test #2

Client: Northern Pig
Job Number: 121413456

Plant: Lime Kiln
Location: Pictou, NS

Test: PA-2

Date: 22-Jul-15

Personnel: TBH:ST

Test Start: 2:00 PM

Test Finish: 4:03 PM

Particulate Collected from Filter (mg): 357.8
Particulate Collected from Probe Wash (mg): 30.9
Particulate Collected from Impinger Wash (mg): 3.3
Total Particulate Collected (mg): 391.9

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H2O	887.5	883.8	3.3
2	100 mL H2O	725.9	718.5	7.4
3	Blank	887.9	888.3	0.6
4	200g 34ca Gel	871.7	868.1	5.6

Total Weight Gain (g) 231.2
Moisture Volume (mL) 251.2

Parameters

Barometric Pressure, Pbar (in. Hg) 29.60
Stack Static Pressure, Pstatic (in. H2O) 0.31
Ambient Temp. (°F) 59
H2O Volume Collected, Vw (mL) 39
Total # Sampling Points 24
Sampling Time per Point, (min) 5
Readings Taken Every _____ mins 2.5
Regulatory Agency NSENV

O2, (%) 4.6
CO2, (%) 22.5
H2, (%) 72.9

Stack Diameter, (in.) 48
Stack Area, (sq. ft.) 12.57
Probe Length, (in.) 8
Nozzle Diameter, (in.) 0.172
Pilot Coefficient, (Cpf) 0.816
Gamma, meter constant 1.033

Traverse Point	Time (min)	Stack Gas Temp, Ts (°F)	S-type Pitot delta P (in. H2O)	Orifice delta H (in. H2O)	Gas Meter Volume (cu. ft.)	Gas Meter Temp (°F)		Nozzle Angle (Cyclonic Flow) (deg. from vert.)	
						Inlet	Outlet		
Traverse 1	1	2.5	157	0.40	0.16	187.480	78	60	-43
	2	5	165	0.40	0.16	187.950	80	60	-43
	3	7.5	160	0.35	0.14	189.080	80	60	-35
	4	10	162	0.35	0.14	189.610	80	60	-35
	5	12.5	161	0.35	0.14	190.190	80	60	-30
	6	15	161	0.30	0.12	190.630	80	60	-20
	7	17.5	161	0.28	0.12	191.190	79	59	-15
	8	20	161	0.27	0.11	191.610	79	59	-11
	9	22.5	159	0.25	0.10	192.090	79	59	-3
	10	25	158	0.25	0.10	192.530	79	59	-5
	11	27.5	158	0.25	0.10	193.010	79	59	0
	12	30	157	0.24	0.10	193.470	79	59	0
Traverse 2	1	32.5	158	0.28	0.08	193.900	80	60	0
	2	35	156	0.38	0.16	194.480	80	60	0
	3	37.5	156	0.40	0.17	195.070	80	60	2
	4	40	153	0.39	0.16	195.630	80	60	8
	5	42.5	153	0.38	0.16	196.180	80	60	15
	6	45	153	0.38	0.16	196.730	80	60	15
	7	47.5	155	0.41	0.17	197.360	80	60	22
	8	50	154	0.40	0.17	197.920	80	60	22
	9	52.5	154	0.37	0.15	198.470	80	60	30
	10	55	154	0.36	0.15	199.010	80	60	30
	11	57.5	153	0.35	0.14	199.530	80	60	43
	12	60	153	0.35	0.14	200.080	80	60	43
Traverse 2	1	62.5	153	0.43	0.18	200.660	80	61	-42
	2	65	150	0.45	0.19	201.290	80	61	-42
	3	67.5	150	0.42	0.17	201.900	80	60	-30
	4	70	150	0.35	0.14	202.430	80	60	-30
	5	72.5	150	0.36	0.15	203.020	80	60	-25
	6	75	161	0.30	0.12	203.530	80	60	-25
	7	77.5	162	0.32	0.13	204.030	81	61	-15
	8	80	163	0.31	0.13	204.540	81	61	-15
	9	82.5	163	0.31	0.13	205.080	81	61	-18
	10	85	163	0.31	0.13	205.580	81	61	-18
	11	87.5	162	0.32	0.13	206.070	81	61	0
	12	90	162	0.32	0.13	206.590	81	61	0
Traverse 2	1	92.5	161	0.30	0.12	207.080	81	61	0
	2	95	161	0.32	0.13	207.600	81	61	0
	3	97.5	161	0.33	0.14	208.140	81	61	3
	4	100	161	0.33	0.14	208.680	81	61	5
	5	102.5	159	0.37	0.15	209.230	82	62	15
	6	105	160	0.37	0.15	209.790	82	62	15
	7	107.5	160	0.38	0.16	210.330	82	62	30
	8	110	160	0.40	0.16	210.900	82	62	30
	9	112.5	160	0.45	0.19	211.560	82	62	30
	10	115	160	0.45	0.19	212.190	82	62	30
	11	117.5	159	0.45	0.18	212.770	82	62	45
	12	120	158	0.44	0.18	213.370	82	62	45

Calculations for: Lime Kiln Particulate Matter Testing Test #2

Client: Northern Pipe
 Job Number: 121412456
 Plant: Lime Kiln
 Location: Poku, NB
 Test: PM-2
 Date: 22-Jun-15
 Personnel: TGN/SP

Calculated Parameters

Stack Gas Pressure, Pa (in Hg) 29.66
 Stack Gas Molecular Weight, Dry Basis, M_d (lb/lb-mole) 31.79
 Volume of Water Vapour Collected, V_w (cu ft) 12.008
 Stack Gas Moisture Content (% as decimal) 0.310
 Stack Gas Molecular Weight, Wet Basis, M_w (lb/lb-mole) 27.52

Isokineticity Checks

Check range Outside of Criteria
 Check range Within Criteria

Traverse Point	Time (min)	Stack Gas Temp, T _s (°F)	S-type Pitot, delta P (in. H ₂ O)	Orifice delta H (in. H ₂ O)	Measured Stack Gas Velocity, U _s (ft/s)	Vertical Stack Gas Velocity, U _v (ft/s)	Motor Press. P _m (in. Hg)	Avg. Temp, T _m (°F)	Gas Meter Volume, V _m (cu. ft.)	Vol. @ Ref. V _m (cu. ft.)	Isokineticity I (%)
Traverse 1											
1	2.5	617	0.43	0.18	38.30	27.08	29.61	529	0.950	0.571	103.12
	5	620	0.40	0.18	38.40	27.15	29.61	530	0.900	0.622	112.58
2	7.5	620	0.35	0.14	35.92	29.42	29.61	530	0.530	0.549	108.29
	10	622	0.35	0.14	35.87	29.47	29.61	530	0.530	0.549	108.48
3	12.5	621	0.35	0.14	35.94	33.78	29.61	530	0.540	0.559	108.38
	15	621	0.30	0.12	33.28	31.27	29.61	529	0.460	0.498	108.36
4	17.5	621	0.29	0.12	32.72	31.80	29.61	529	0.460	0.498	108.02
	20	621	0.27	0.11	31.57	30.40	29.61	529	0.480	0.498	108.96
6	22.5	619	0.25	0.10	30.35	30.21	29.61	529	0.480	0.498	114.01
	25	618	0.25	0.10	30.31	30.19	29.61	529	0.480	0.477	108.17
8	27.5	618	0.25	0.10	29.67	29.67	29.61	529	0.480	0.477	109.17
	30	618	0.20	0.08	27.11	27.11	29.61	529	0.480	0.477	113.87
7	32.5	618	0.38	0.18	37.50	37.50	29.61	530	0.580	0.611	111.23
	35	618	0.40	0.17	37.27	37.30	29.61	530	0.580	0.601	111.27
8	37.5	615	0.38	0.18	37.78	37.30	29.61	530	0.580	0.611	110.33
	40	615	0.38	0.18	37.27	36.00	29.61	530	0.580	0.580	103.96
9	42.5	615	0.38	0.18	37.27	35.90	29.61	530	0.580	0.580	105.43
	45	615	0.38	0.18	37.27	36.00	29.61	530	0.550	0.570	109.26
10	47.5	615	0.41	0.17	38.75	35.43	29.61	530	0.570	0.581	112.58
	50	614	0.40	0.17	38.75	31.83	29.61	530	0.580	0.622	104.95
11	52.5	614	0.37	0.15	36.25	31.38	29.61	530	0.580	0.570	109.78
	55	614	0.36	0.15	36.25	31.38	29.61	530	0.540	0.559	109.26
12	57.5	615	0.35	0.14	35.77	25.29	29.61	530	0.540	0.559	107.85
	60	615	0.35	0.14	35.77	25.29	29.61	530	0.550	0.570	108.95
Traverse 2											
1	62.5	615	0.43	0.18	39.65	29.48	29.61	531	0.580	0.580	100.82
	65	618	0.42	0.19	40.86	30.22	29.61	531	0.630	0.632	111.15
2	67.5	619	0.42	0.17	38.28	34.02	29.61	531	0.610	0.632	111.50
	70	619	0.35	0.14	35.88	31.08	29.61	530	0.550	0.570	110.21
3	72.5	619	0.36	0.15	36.40	33.99	29.61	530	0.570	0.580	112.82
	75	621	0.30	0.12	33.28	30.16	29.61	530	0.510	0.517	108.73
4	77.5	622	0.32	0.13	34.40	33.25	29.61	531	0.510	0.527	108.79
	80	623	0.31	0.13	33.88	33.37	29.61	531	0.510	0.527	108.02
6	82.5	623	0.31	0.13	33.88	34.40	29.61	531	0.540	0.558	115.12
	85	623	0.32	0.13	34.40	33.37	29.61	531	0.500	0.517	108.98
8	87.5	622	0.32	0.13	34.40	34.40	29.61	531	0.480	0.507	102.74
	90	621	0.30	0.12	33.28	33.28	29.61	531	0.520	0.536	109.02
7	92.5	621	0.32	0.13	34.37	34.77	29.61	531	0.540	0.558	110.67
	95	621	0.33	0.14	34.80	34.77	29.61	531	0.540	0.558	111.40
8	97.5	621	0.33	0.14	34.80	34.77	29.61	531	0.540	0.558	111.40
	100	618	0.37	0.15	36.80	35.84	29.61	532	0.570	0.588	110.87
9	102.5	620	0.37	0.15	36.80	35.84	29.61	532	0.540	0.557	104.83
	105	620	0.36	0.16	37.42	35.17	29.61	532	0.580	0.619	107.38
10	107.5	620	0.40	0.16	40.72	35.27	29.61	532	0.610	0.630	112.14
	110	620	0.40	0.16	38.40	38.06	29.61	532	0.630	0.620	107.48
11	112.5	620	0.45	0.19	40.72	38.13	29.61	532	0.580	0.598	104.47
	115	620	0.45	0.19	38.78	29.13	29.61	532	0.600	0.619	108.75
12	117.5	619	0.43	0.18	38.78	29.13	29.61	532	0.600	0.619	108.75
	120	618	0.44	0.18	40.20	29.43	29.61	532	0.600	0.619	108.75
Total			Average	Average	Average	Average	Average	Average	Total	Total	Average
90		619	0.35	0.14	35.78	31.37	29.61	530.42	25.970	26.861	108.85

Combustion Gas Data for: Northern Pulp

Client: Northern Pulp
Job Number: 121413456

Plant: Lime Kiln
Location: Pictou, NS
Test: PM-2
Date: 22-Jul-15
Personnel: TBH/SF

Test Start: 3:10
Test Finish: 3:40

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
0	4.59	22.53	7	2	110
5					114
10					115
15					142
20					150
25					143
30					146
Average:	4.6	22.5	6.8	1.7	131.4

Raw Data for: Lime Kiln Particulate Matter Testing
Test #3

Client: Northern Pulp
Job Number: 121413408

Plant: Lime Kiln
Location: Potosi, MO
Test: PM-1
Date: 22-Jul-13
Personnel: TBI/SF
Test Start: 3:10 PM
Test Finish: 7:13 PM

Particulate Collected from Filter (mg): 233.7
Particulate Collected from Probe Wash (mg): 21.1
Particulate Collected from Impinger Wash (mg): 3.5
Total Particulate Collected (mg): 258.3

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H2O	863.7	868.5	234.8
2	100 mL H2O	708.8	698.8	9.7
3	Burn	898.9	898.7	0.2
4	200g Sacks Gal	978.4	971.6	4.8
Total Weight Gain (g)				249.5
Moisture Volume (mL)				240.8

Parameters

Barometric Pressure, Pbar (in. Hg): 29.50
Stack Static Pressure, Pstatic (in. H2O): 0.31
Ambient Temp, (°F): 68.00
H2O Volume Collected, Vw (mL): 249.88
Total # Sampling Points: 24
Sampling Time per Point, (min): 5
Readings Taken Every ____ min: 2.3
Regulatory Agency: HSENV

CO2 (%)	CO2 (%)	N2 (%)	Stack Diameter (in.)	Stack Area (sq. ft.)	Probe Length (in.)	Nozzle Diameter (in.)	Pitot Coefficient, (Cp)	Gamma, meter constant
4.17	22.06	77.9	-48	12.57	8	0.172	0.816	1.033

Traverse Point	Time (min)	Stack Gas Temp, Ts (°F)	3-Port Pitot delta P (in. H2O)	Orifice delta H (in. H2O)	Gas Meter Volume (cu. ft.)	Gas Meter Temp (°F)		Nozzle Angle (Cyclic Flow) (deg. from vert.)
						Inlet	Outlet	
Traverse 1	1	2.5	158	0.50	213.630	79	61	-43
	2	5	159	0.30	214.950	79	61	-45
	3	12.5	159	0.40	216.310	79	61	-30
	4	15	160	0.38	216.760	80	62	-25
	5	17.5	160	0.35	217.870	81	62	-23
	6	20	160	0.30	218.430	81	62	-13
	7	22.5	160	0.28	219.440	82	62	-5
	8	25	160	0.22	219.440	82	62	-5
	9	27.5	160	0.27	219.950	82	62	0
	10	30	160	0.25	220.410	82	62	0
	11	32.5	161	0.26	220.910	82	63	0
	12	35	161	0.28	221.410	82	63	0
Traverse 2	1	37.5	161	0.30	221.920	82	63	5
	2	40	161	0.30	222.430	82	63	5
	3	42.5	161	0.34	222.980	82	63	11
	4	45	161	0.33	223.510	83	63	15
	5	47.5	161	0.33	224.070	83	63	25
	6	50	161	0.32	224.660	83	63	25
	7	52.5	161	0.30	225.260	83	63	30
	8	55	159	0.41	225.830	83	63	30
	9	57.5	160	0.42	226.720	80	64	45
	10	60	159	0.46	227.160	80	64	45
	11	62.5	159	0.31	227.870	81	64	-45
	12	65	160	0.31	228.360	81	64	-45
13	67.5	159	0.40	229.130	81	64	-35	
14	70	158	0.49	229.760	82	64	-35	
15	72.5	158	0.42	230.360	82	64	-30	
16	75	158	0.40	230.930	82	64	-30	
17	77.5	159	0.35	231.490	82	64	-15	
18	80	159	0.34	232.010	82	64	-15	
19	82.5	159	0.30	232.520	82	64	-5	
20	85	160	0.28	233.020	82	64	-5	
21	87.5	159	0.25	233.510	83	64	0	
22	90	159	0.20	234.010	83	64	0	
23	92.5	159	0.31	234.540	83	64	0	
24	95	160	0.32	235.050	83	64	0	
25	97.5	158	0.31	235.600	83	64	10	
26	100	157	0.33	236.140	83	65	10	
27	102.5	158	0.33	236.700	83	65	15	
28	105	158	0.30	237.260	83	65	15	
29	107.5	158	0.40	237.830	83	65	24	
30	110	158	0.41	238.390	83	65	24	
31	112.5	158	0.40	238.900	83	65	32	
32	115	157	0.44	239.400	83	65	32	
33	117.5	157	0.44	240.330	81	65	48	
34	120	157	0.46	240.990	83	65	48	

**Calculations for: Lime Kiln Particulate Matter Testing
Test #3**

Client: Northern Plus
Job Number: 121413488

Plant: Lums A/B
Location: Phosus, NS
Test: PM-3
Date: 22-Jul-18
Personnel: YB48F

Calculated Parameters

Stack Gas Pressure, P_s (in. Hg)
Stack Gas Molecular Weight, Dry Basis, M_d (lb/lb-mole)
Volume of Water Vapor Collected, V_w (cu ft)
Stack Gas Moisture Content (% as decimal)
Stack Gas Molecular Weight, Wet Basis, M_w (lb/lb-mole)

29.54
31.84
11.881
0.368
27.70

Isokineticity Checks

Check range: Outside of Criteria
Check average: Within Criteria

Traverse Point	Time (min)	Stack Gas Temp, T _s (°F)	S-type Pitot, delta P (in. H ₂ O)	Orifice delta H (in. H ₂ O)	Measured Stack Gas Velocity, U _s (ft/s)	Vertical Stack Gas Velocity, U _v (ft/s)	Meter Press., P _m (in. Hg)	Avg. Temp., T _m (°F)	Gas Meter Volume, V _m (cu ft)	Vol. @ Ref., V _m (cu ft)	Isokineticity I (%)
Traverse 1	1	2.5	818	0.50	42.79	30.76	29.52	530	0.670	0.692	111.07
		5	819	0.50	42.82	30.26	29.52	530	0.650	0.671	107.83
	2	7.5	819	0.48	41.88	36.54	29.51	530	0.630	0.651	106.88
		10	819	0.49	42.20	38.71	29.51	530	0.630	0.651	105.58
	3	12.5	819	0.40	41.16	37.38	29.51	531	0.530	0.546	86.12
		15	820	0.38	40.16	34.83	29.51	532	0.580	0.598	110.23
	4	17.5	820	0.35	40.14	35.88	29.51	531	0.590	0.596	108.83
		20	820	0.35	40.14	35.88	29.51	532	0.580	0.577	110.81
	5	22.5	820	0.30	40.12	33.20	29.51	532	0.480	0.504	104.72
		25	820	0.28	40.12	32.07	29.51	532	0.480	0.525	114.83
	6	27.5	820	0.27	40.11	31.48	29.51	532	0.510	0.473	107.59
		30	820	0.25	40.10	30.30	29.51	532	0.500	0.514	114.86
7	32.5	821	0.26	40.11	30.83	29.51	533	0.500	0.514	110.49	
	35	821	0.25	40.12	32.10	29.51	533	0.510	0.524	110.74	
8	37.5	821	0.29	40.12	33.68	29.51	533	0.510	0.505	108.88	
	40	821	0.30	40.12	33.22	29.51	533	0.530	0.544	107.79	
9	42.5	821	0.34	40.14	35.37	29.51	533	0.580	0.573	113.60	
	45	821	0.33	40.14	34.84	29.51	533	0.590	0.608	111.82	
10	47.5	821	0.33	40.14	34.84	29.51	533	0.600	0.618	112.25	
	50	821	0.28	40.16	37.88	29.51	533	0.620	0.637	112.95	
11	52.5	821	0.28	40.16	37.88	29.51	533	0.640	0.656	111.59	
	55	819	0.41	40.17	38.78	29.51	532	0.640	0.656	110.29	
12	57.5	820	0.45	40.18	40.88	29.51	532	0.640	0.656	110.29	
	60	819	0.46	40.18	41.07	29.51	532	0.640	0.656	110.29	
Traverse 2	1	82.5	819	0.51	43.25	30.58	29.52	533	0.710	0.730	118.09
		85	820	0.51	43.28	30.81	29.52	533	0.630	0.647	105.10
	2	87.5	818	0.49	42.20	34.75	29.51	533	0.630	0.647	105.09
		90	818	0.49	42.20	34.70	29.51	533	0.630	0.647	104.91
	3	92.5	818	0.42	41.17	38.25	29.51	533	0.600	0.618	107.91
		95	818	0.40	40.17	35.98	29.51	533	0.590	0.608	108.73
	4	97.5	819	0.35	40.14	35.31	29.51	533	0.540	0.554	108.47
		100	819	0.34	40.15	33.17	29.51	533	0.520	0.534	104.02
	5	102.5	819	0.30	40.15	33.04	29.51	533	0.510	0.524	108.60
		105	819	0.28	40.10	30.28	29.51	533	0.500	0.513	110.30
	6	107.5	819	0.29	40.12	32.81	29.51	534	0.500	0.502	114.18
		110	820	0.32	40.13	34.28	29.51	534	0.520	0.519	109.19
7	112.5	819	0.31	40.13	33.88	29.51	534	0.530	0.544	110.83	
	115	818	0.33	40.14	34.78	29.51	534	0.540	0.554	111.33	
8	117.5	817	0.33	40.14	34.78	29.51	534	0.540	0.533	106.74	
	120	818	0.38	40.16	38.27	29.51	534	0.540	0.553	109.35	
9	122.5	818	0.40	40.17	38.27	29.51	534	0.580	0.574	113.31	
	125	818	0.40	40.17	38.27	29.51	534	0.580	0.584	108.05	
10	127.5	818	0.41	40.17	38.27	29.51	534	0.600	0.615	110.37	
	130	818	0.44	40.18	40.14	29.51	534	0.620	0.625	114.05	
11	132.5	818	0.44	40.18	40.11	29.51	534	0.600	0.615	109.21	
	135	817	0.44	40.18	40.11	29.51	534	0.650	0.668	114.00	
12	137.5	817	0.48	40.19	41.01	29.51	534	0.600	0.615	103.15	
	140	817	0.48	40.19	41.01	29.51	534	0.640	0.658	108.70	
Total	90	Average	Average	Average	Average	Average	Average	Total	Total	Average	
		619	0.37	0.15	38.83	32.84	29.51	532.63	27.380	28.110	108.55

Combustion Gas Data for: Northern Pulp

Client: Northern Pulp
Job Number: 121413456

Plant: Lime Kiln
Location: Pictou, NS
Test: PM-2
Date: 22-Jul-15
Personnel: TBH/SF

Test Start: 2:00
Test Finish: 2:30

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
0	4.17	22.96	7	2	77
5					44
10					42
15					42
20					44
25					41
30					45
Average:	4.2	23.0	6.6	1.7	47.9

DATA ENTRY

Northern Pulp

Pictou, NS

Fuel Burned: Natural Gas

Stack Height from Grade: 37 m

Stack Diameter: 1.22 m

Standard Temperature, Tstd (F): 77
 (K): 298
 Standard Pressure, Pstd (in.Hg): 29.92
 (Bar): 1.0

Parameter	Symbol	Units	Test 1	Test 2	Test 3	Average
Test ID	-	-	PM-1	PM-2	PM-3	-
Date	-	-	21-Jul-15	22-Jul-15	22-Jul-15	n/a
Start Time	-	-	9:05 AM	2:00 PM	5:10 PM	n/a
End Time	-	-	11:12 AM	4:05 PM	7:15 PM	n/a
Total Sampling Time	-	min	90	67.5	67.5	75
Stack Diameter	D	in.	48	48	48	48
Average Stack Gas Temperature	Ts	F	160	158	159	159
Average Dry Gas Meter Temperature	Tm	F	75	70	73	72
Barometric Pressure	Pbar	in.Hg	29.70	29.60	29.50	29.60
Stack Static Pressure	Pstatic	in.H2O	0.51	0.51	0.51	0.51
Average Pressure Drop (Head)	dP	in.H2O	0.51	0.42	0.49	0.47
Average deltaH Orifice	dH	in.H2O	0.21	0.17	0.20	0.20
Average Meter Temperature	Tm	F	75	70	73	72
Gas Sample Volume	Vm	cu.ft	30.4	26.0	27.4	27.9
Average Isokinetics	I	%	111.5	111.5	105.1	109.4
Nozzle Diameter	Dn	in.	0.172	0.172	0.172	0.172
Pitot Coefficient	Cp	-	0.816	0.816	0.816	0.816
Gamma, meter constant	y	-	1.033	1.033	1.033	1.033
Reference Temperature	Tref	R	537	537	537	537
Reference Pressure	Pref	in.Hg	29.92	29.92	29.92	29.92
Stack Gas Oxygen Content	Co2	%	4.64	4.59	4.17	4.47
Stack Gas Carbon Dioxide Content	Cco2	%	22.1	22.5	23.0	22.5
Stack Gas Nitrogen Content	Cn2	%	73.2	72.9	72.9	73.0
Volume of Water Collected	Vw	mL	359	251	250	286
Particulate Collected from Filter	-	mg	242	358	234	278
Particulate Collected from Probe Wash	-	mg	43.1	30.8	21.1	31.7
Particulate Collected from Impinger Wash	-	mg	20.5	3.3	3.5	9.1
Total Particulate Collected (excl. impingers)	Mp	mg	285	389	255	310
Pulp Production		adubmt/day	596	701	701	666

Legend: F - degrees Fahrenheit
 K - degrees Kelvin
 Bar - bars
 in.Hg - inches of mercury
 in. - inches

in H2O - inches of water
 cu.ft - cubic feet
 R - degrees Rankin
 NOx - as NO2

CALCULATIONS
 Northern Pulp
 Pictou, NS
 Stack Height from Grade: 37 m
 Stack Diameter: 1.22 m

Variable	Symbol	Units	Calculation	Test 1	Test 2	Test 3	Average
Stack Area	A_s	sq.ft sq.m	$A_s = \pi \times ((D/12)^2 \times \pi / 4)$ $A_s \text{ (sq.m)} = A_s \text{ (sq.ft)} \times 0.0929$	12.57 1.17	12.57 1.17	12.57 1.17	12.57 1.17
Barometric Pressure	P_{bar}	kPa	$P_{bar} \text{ (kPa)} = P_{bar} \text{ (in.Hg)} \times 3.386$	101	100	100	100
Stack Static Pressure	P_{static}	kPa	$P_{static} \text{ (kPa)} = P_{static} \text{ (in.H}_2\text{O)} \times 0.249$	0.13	0.13	0.13	0.13
Avg. Stack Temperature	T_s	R	$T_s \text{ (R)} = T_s \text{ (F)} + 460$	620	618	619	619.0
Avg. Meter Temperature	T_m	R	$T_m \text{ (R)} = T_m \text{ (F)} + 460$	535	530	533	532.5
Nozzle Diameter	D_n	mm	$D_n \text{ (mm)} = D_n \text{ (in.)} \times 25.4$	4	4	4	4.4
Gas Meter Pressure	P_m	in.Hg	$P_m = P_{bar} + (dH / 13.6)$	29.7	29.6	29.5	29.6
Sample Volume at STP	V_{mc}	cu.ft cu.m	$V_{mc} = T_{ref}/P_{ref} \times (V_m \times P_m \times s) / T_m$ $V_{mc} \text{ (cu.m)} = 0.02852 \times V_{mc} \text{ (cu.ft)}$	31.3 0.89	29.9 0.76	28.1 0.80	28.8 0.82
Volume of Water Vapour	V_{wc}	cu.ft	$V_{wc} = 0.9489 \times V_m$	17.2	12.1	12.0	13.8
Water Fraction	B_{wo}	-	$B_{wo} = V_{wc} / (V_{wc} + V_{mc})$	0.35	0.31	0.30	0.32
Molecular Weight, Dry	M_d	lb/lb-mol	$M_d = 0.44 \text{ (C}_{20}\text{)} + 0.32 \text{ (C}_{2}\text{)} + 0.28 \text{ (C}_{2}\text{)}$	31.7	31.8	31.8	31.8
Molecular Weight, Wet	M_s	lb/lb-mol	$M_s = M_d \times (1 - B_{wo}) + (18 \times B_{wo})$	26.9	27.5	27.7	27.4
Stack Pressure	P_s	in.Hg	$P_s = P_{bar} + (P_{static} / 13.6)$	29.7	29.6	29.5	29.6
Stack Gas Velocity	U_s	ft/s m/s	$U_s = 85.33 \times C_p \times ((dP \times T_s)/(P_s \times M_s))^{0.5}$ $U_s \text{ (m/s)} = 0.3048 \times U_s \text{ (ft/s)}$	38.6 11.8	34.0 10.4	34.7 10.6	35.8 10.9
Actual Stack Gas Flow Rate	Q	acfm	$Q = 60 \times U_s \times A_s$	29,136	25,649	25,182	26,989
Dry Stack Gas Flow Rate	Q_d	dscfm dscms	$Q_d = Q \times (1 - B_{wo}) \times (T_{ref}/T_s) \times (P_s/P_{ref})$ $Q_d \text{ (dscms)} = 0.000472 \times Q_d \text{ (dscfm)}$	16,190 7.64	15,244 7.20	15,723 7.42	15,719 7.42
Particulate Concentration	C_p	mg/dscm	$C_p = M_p / V_{mc}$	322	510	320	384
Particulate Emission Rate	ERp	g/s kg/hr kg/adubmt	$ER_p = C_p / 1000 \times Q_d$ $ER_p \text{ (kg/hr)} = 3.6 \times ER_p \text{ (g/s)}$ $ER_p \text{ (kg/adubmt)} = ER_p \text{ (kg/hr)} \times 24 / \text{pulp production (adubmt/day)}$	2.46 8.85 0.36	3.67 13.2 0.45	2.37 8.5 0.29	2.83 10.2 0.4
Particulate Concentration Corrected to 11% O2	C_p	mg/dscm	$C_p \text{ (11% O}_2\text{)} = C_p \times (20.9 - 11) / (20.9 - C_{O2})$	196	310	189	232
Corrected to 3% O2	C_p	mg/dscm	$C_p \text{ (3% O}_2\text{)} = C_p \times (20.9 - 3) / (20.9 - C_{O2})$	354	560	342	419
Corrected to 12% CO2	C_p	mg/dscm	$C_p \text{ (12% CO}_2\text{)} = C_p \times (12/C_{CO2})$	175	272	167	204

Legend: sq.ft - square feet
 sq.m - square metres
 ft - 3.142
 R - degrees Rankin
 ppm - parts per million

in.Hg - inches of mercury
 cu.ft - cubic feet
 cu.m - cubic metres
 STP - standard temperature and pressure (25 °C and 101.3 kPa)
 dscfm - dry standard cubic feet per minute

mg/dscm - milligrams per dry standard cubic metre
 g/s - grams per second
 NOx - as NO2
 acfm - actual cubic feet per minute
 dscms - dry standard cubic metres per second

OFFICIAL STACK TESTING RESULTS

Northern Pulp

Pictou, NS

Stack Height from Grade: 37 m

Stack Diameter: 1.22 m

Parameter	Test 1	Test 2	Test 3	Average	NSENV Limits
Test ID	PM-1	PM-2	PM-3	-	-
Test Date	21-Jul-15	22-Jul-15	22-Jul-15	-	-
Stack Gas Temperature (C)	71.1	70.0	70.6	70.5	-
Moisture Content (%)	35.5	30.9	29.9	32.1	-
Velocity (m/s)	11.8	10.4	10.6	10.9	-
Volumetric Flow (dscms)	7.64	7.20	7.42	7.42	-
Oxygen - O2 (%)	4.64	4.59	4.2	4.47	-
Carbon Dioxide - CO2 (%)	22.1	22.5	23.0	22.5	-
Particulate Matter - PM					
Particulate Concentration (mg/dscm)	322	510	320	384	-
Particulate Emission Rate (kg/hr)	8.85	13.2	8.55	10.2	-
Particulate Emission Rate (kg/adubmt)	0.36	0.45	0.29	0.37	0.50

Legend: C - degrees Celsius
 m/s - metres per second
 dscms - dry standard cubic metres per second
 ppm - parts per million
 adubmt - air dried unbleached metric tonne (772.08 adubmt/d)

STP - standard temperature and pressure (25 C and 101.3 kPa)
 mg/dscm - milligrams per dry standard cubic metre
 NOx - as NO2
 ND - non-detectable

Particulate Resuspension Impinger Catch Probe Weight Probe Catch

Client: Northrop Grumman
 Facility: Naval Air Station
 Location: Naval Air Station
 Job Number: 17-01-01

IMPINGER CATCH

Container ID	Booster Pre Weights (g)				Sample ID	Recovery				Booster Post Weights (g)				Unrecovered Particulate Weight (g)	Corrected Particulate Weight (g)
	Data					Data				Data					
	Trap 1	Trap 2	Trap 3	Average		Jet Sample + Rinse (g)	Jet Trap (g)	Recovery (g)	Rinse Water (g)	Total Mass Water (g)	Trap 1	Trap 2	Trap 3		
01	110.2814	110.3073	110.3813	110.3233	PLU 1	822.5	397.1	353.6	10.8	183.2	110.2753	110.4211	110.4917	0.0742	0.0721
12	114.7488	114.7488	114.7488	114.7488	PLU 2	771.1	182.4	221.2	10.3	137.8	114.7561	114.7517	114.7508	0.0041	0.0033
24	107.4682	107.4682	107.4682	107.4682	PLU 3	750.7	382.5	288.8	10.2	117.0	107.4682	107.4648	107.4642	0.0019	0.0011
11	108.1870	108.1874	108.1872	108.1872	WPH	404.2	104.0	84.2	84.7	178.364	108.1841	108.1841	108.1842	0.0071	0.0013




PROBE WATER

Container ID	Booster Pre Weights (g)				Sample ID	Recovery				Booster Post Weights (g)				Unrecovered Particulate Weight (g)	Corrected Particulate Weight (g)
	Data					Data				Data					
	Trap 1	Trap 2	Trap 3	Average		Jet + Rinse (g)	Jet Trap (g)	Recovery (g)	Rinse Acetone (g)	Total Acetone (g)	Trap 1	Trap 2	Trap 3		
01	112.3700	112.3787	112.3799	112.3762	PLU 1	925.1	307.1	115.4	17.8	133.2	112.4214	112.4213	112.4215	0.0493	0.0431
11	112.2184	112.0148	112.0187	112.0173	PLU 2	871.0	300.5	180.5	4.8	180.4	112.0188	112.0181	112.0184	0.0297	0.0308
20	113.1424	113.1424	113.1424	113.1424	PLU 3	418.6	389.9	130.0	17.1	142.3	113.1427	113.1427	113.1424	0.0290	0.0211
17	111.2480	111.2481	111.2481	111.2481	AB	371.2	122.2	41.0	41.8	113.2484	111.2481	111.2484	111.2484	0.0714	0.0722

FILTER CATCH

Filter ID	Pre Weights (g)				Sample ID	Post Weights (g)				Particulate Weight from Filter (g)
	Data					Data				
	Trap 1	Trap 2	Trap 3	Average		Trap 1	Trap 2	Trap 3	Average	
0719.19	0.3303	0.3304	0.3304	0.3304	PLU 1	0.1720	0.1720	0.1720	0.1720	0.2424
0819.08	0.3487	0.3491	0.3489	0.3489	PLU 2	0.5343	0.5340	0.5340	0.5340	0.1451
0918.07	0.3402	0.3407	0.3406	0.3406	PLU 3	0.4108	0.4108	0.4108	0.4108	0.1408
1018.23	0.3181	0.3181	0.3181	0.3181	PLU 1	0.4176	0.4176	0.4176	0.4176	0.2117

Stack Gas Velocity Profiles
Pictou, NS



Raw Data for: Northern Pulp Power Boiler PM
Test #1

Client: Northern Pulp
Job Number: 121412450

Plant: Power Boiler
Location: Pickou, NS
Test: P4-1
Date: 23-Jul-13
Personnel: TDM/ST
Test Start: 9:42 AM
Test Finish: 11:31 AM

Particulate Collected from Filter (mg): 70.8
Particulate Collected from Probe Wash (mg): 28.3
Particulate Collected from Impinger Wash (mg): 23.7
Total Particulate Collected (mg): 97.2

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H2O	812.1	858.2	155.9
2	100 mL H2O	729.3	896.8	32.4
3	Blank	885.7	885.2	3.5
4	200g Silica Gel	888.9	875.0	11.9
Total Weight Gain (g)				203.7
Moisture Volume (mL)				203.7

Parameters
Barometric Pressure, Pbar (in. Hg) 29.60
Stack Static Pressure, Pstatic (in. H2O) 0.30
Ambient Temp, (°F) 64
H2O Volume Collected, Vw (mL) 201.7
Total # Sampling Points, 24
Sampling Time per Point, (mins) 2.3
Readings Taken Every _____ mins
Regulatory Agency NS/DOE

O2 (%) 18.1
CO2 (%) 2.5
H2 (%) 0.3
CO (ppm) 1037.4
NOx (ppm) 10.0
SO2 (ppm) 0.0

Stack Diameter, (in.) 72
Stack Area, (sq. ft.) 28.27
Probe Length, (ft.) 8
Nozzle Diameter, (in.) 0.172
Pitot Coefficient, (Cp) 0.816
Orifice, meter constant
Pitot length (in.) 6

Traverse Point	Time (min)	Stack Gas Temp, Tg (°F)	S-type Pitot delta P (in. H2O)	Orifice delta H (in. H2O)	Gas Meter Volume (cu. ft.)	Gas Meter Temp (°F)		
						Inlet	Outlet	
Traverse 1	1	2.5	132	0.83	0.48	241.260		
	5	128	0.80	0.46	242.230	92	62	
	2	7.5	132	0.89	0.43	243.180	97	64
	10	132	0.99	0.36	244.120	93	64	
	3	15	131	0.97	0.53	245.180	93	64
	17.5	130	0.93	0.53	246.230	96	64	
	4	20	131	0.90	0.50	247.230	96	64
	22.5	129	0.94	0.53	248.210	88	63	
	25	129	0.91	0.50	249.230	68	63	
	27.5	126	0.90	0.50	250.230	66	63	
	30	124	0.88	0.49	251.240	69	63	
	32.5	124	0.88	0.49	252.230	66	64	
Traverse 2	1	82.5	131	1.40	0.78	267.240		
	5	130	1.40	0.78	268.440	70	70	
	2	67.5	129	1.33	0.73	269.640	70	71
	70	129	1.40	0.78	270.870	71	70	
	3	72.5	128	1.30	0.73	272.070	72	70
	75	132	1.25	0.68	273.230	72	71	
	77.5	132	1.20	0.67	274.410	72	68	
	80	131	1.20	0.67	275.540	72	69	
	82.5	129	1.10	0.61	276.710	72	69	
	85	130	1.05	0.59	277.830	72	69	
	87.5	129	1.10	0.61	278.900	72	69	
	90	129	1.10	0.61	280.010	72	69	
92.5	132	1.30	0.67	281.170	72	69		
95	130	1.25	0.70	282.270	72	69		
97.5	129	1.30	0.70	283.370	71	70		
100	128	1.30	0.76	284.440	71	70		
102.5	128	1.40	0.78	285.570	71	70		
105	129	1.40	0.78	286.670	71	70		
107.5	128	1.40	0.78	287.780	71	70		
110	127	1.35	0.76	288.910	71	70		
112.5	128	1.35	0.76	290.040	74	71		
115	128	1.20	0.69	291.180	74	71		
117.5	126	1.40	0.80	292.300	74	71		
120	127	1.50	0.84	293.400	74	71		

Calculations for: Northern Pulp Power Boiler PM Test #1

Client: Northern Pulp
 Job Number: T21412406
 Plant: Power Boiler
 Location: Plant, NS
 Test: PM-1
 Date: 25-Jul-18
 Personnel: T214087

Calculated Parameters

Stack Gas Pressure, Ps (in Hg)
 Stack Gas Molecular Weight, Dry Basis, Md (lb/lb-mole)
 Volume of Water Vapour Collected, Vw (cu ft)
 Stack Gas Moisture Content, % as decimal
 Stack Gas Molecular Weight, Wet Basis, Mw (lb/lb-mole)

29.81
 29.05
 0.778
 0.148
 27.46

Isokineticity Checks

Check Range: 29.81 to 29.05
 Check Average: 29.43
 Within Criteria: 29.81 to 29.05
 Within Criteria: 29.43

Traverse Point	Time (min)	Stack Gas Temp, Ts (F)	E-type Pitot, delta P (in. H2O)	Orifice delta P (in. H2O)	Stack Gas Velocity, Us (ft/s)	Meter Press. Pm (in. Hg)	Gas Meter		Vol. @ Ref. Vm (cu. ft.)	Isokinetics (%)	
							Avg. Temp, Tm (F)	Volume, Vm (cu. ft.)			
Traverse 1	1	2.5	582	0.85	0.48	54.80	29.84	537	0.870	0.882	87.82
	2	5	588	0.80	0.48	52.98	29.83	540	0.950	0.887	87.78
		10	582	0.80	0.43	53.18	29.83	540	0.840	0.857	87.08
	3	12.5	581	0.87	0.55	58.48	29.84	540	1.080	1.080	98.41
		15	581	0.93	0.53	57.22	29.84	540	1.050	1.089	98.30
	4	17.5	589	0.95	0.53	58.06	29.84	540	1.000	1.018	95.53
		20	588	0.90	0.50	58.34	29.84	527	0.980	1.023	87.88
	5	22.5	589	0.81	0.50	57.78	29.84	527	1.010	1.054	87.83
		25	586	0.90	0.50	58.88	29.84	527	1.000	1.043	86.67
	6	27.5	584	0.88	0.48	55.38	29.84	528	1.020	1.053	101.14
		30	584	0.88	0.48	55.38	29.84	528	1.020	1.031	99.01
	7	32.5	584	0.90	0.50	58.06	29.84	529	1.030	1.071	98.79
35		583	0.88	0.48	55.42	29.84	529	1.040	1.081	98.23	
8	37.5	588	0.98	0.53	58.04	29.84	529	1.080	1.029	98.81	
	40	588	1.22	0.81	82.72	29.88	529	1.230	1.071	98.79	
9	42.5	588	1.22	0.81	84.84	29.88	529	1.180	1.081	98.23	
	45	588	1.12	0.87	80.20	29.88	529	1.180	1.227	101.35	
10	47.5	580	1.40	0.78	70.30	29.88	529	1.080	1.123	98.79	
	50	581	1.25	0.75	69.00	29.88	529	1.230	1.280	87.81	
11	52.5	580	1.80	0.88	75.05	29.87	529	1.210	1.298	98.18	
	55	588	1.80	0.88	74.88	29.87	531	1.310	1.343	87.57	
12	57.5	580	1.80	0.88	75.05	29.87	531	1.330	1.378	98.51	
	60	583	1.50	0.83	72.88	29.88	531	1.270	1.315	94.15	
Traverse 2	1	62.3	581	1.40	0.78	70.30	29.88	530	1.200	1.245	85.34
	2	65	580	1.40	0.78	70.30	29.88	531	1.200	1.244	95.17
		67.5	588	1.35	0.75	68.88	29.88	531	1.230	1.275	98.24
	3	70	588	1.40	0.78	70.15	29.88	532	1.200	1.241	94.81
		72.5	588	1.30	0.73	67.54	29.88	532	1.180	1.221	98.75
	4	75	582	1.28	0.68	66.45	29.88	531	1.180	1.202	87.50
		77.5	589	1.20	0.67	65.11	29.88	531	1.150	1.192	88.85
	5	80	581	1.20	0.67	65.05	29.88	531	1.150	1.182	98.58
		82.5	588	1.05	0.61	62.18	29.88	531	1.150	1.182	98.58
	6	85	580	1.18	0.61	62.18	29.88	531	1.120	1.180	100.08
		87.5	588	1.10	0.59	60.80	29.88	531	1.070	1.108	87.84
	7	90	589	1.10	0.61	62.18	29.88	531	1.110	1.150	88.18
92.5		582	1.20	0.67	65.11	29.88	531	1.180	1.202	103.89	
8	95	580	1.25	0.70	67.58	29.88	531	1.100	1.140	94.36	
	97.5	588	1.25	0.70	68.34	29.88	532	1.200	1.241	100.50	
9	100	588	1.25	0.78	69.82	29.88	532	1.180	1.231	97.85	
	102.5	588	1.40	0.78	70.08	29.88	532	1.210	1.252	97.38	
10	105	588	1.40	0.78	70.18	29.88	532	1.220	1.262	98.48	
	107.5	588	1.40	0.78	70.08	29.88	532	1.220	1.262	98.48	
11	110	587	1.25	0.78	69.82	29.88	533	1.310	1.355	103.52	
	112.5	587	1.80	1.01	79.40	29.87	533	1.320	1.383	108.02	
12	115	588	1.75	0.88	78.22	29.87	533	1.480	1.508	101.53	
	117.5	588	1.88	0.90	74.80	29.87	533	1.500	1.550	105.88	
	120	587	1.55	0.84	72.48	29.88	533	1.310	1.312	83.57	
	Total		Average	Average	Average	Average	Average	Total	Total	Average	
	120		589	1.21	0.68	64.77	29.85	531	57.270	1.558	98.57

Combustion Gas Data for: Northern Pulp

Client: Northern Pulp
Job Number: 121413456

Plant: Power Boiler
Location: Pictou, NS
Test: PM-1
Date: 23-Jul-15
Personnel: TBH/SF

Test Start: 11:00 AM
Test Finish: 11:30 AM

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
0	16.8	2.3	801	0	11
5	17.0	2.2	622	0	13
10	16.1	2.7	344	0	20
15	16.5	2.5	1868	0	14
20	15.3	3.1	1121	0	28
25	15.4	2.1	1132	0	20
30	15.9	2.8	1374	0	26
Average:	16.1	2.5	1037	0	19

Raw Data for: Northern Pulp Power Boiler PM
Test #2

Client: Northern Pulp
Job Number: 121413499

Plant: Power Boiler
Location: Pictou, NS
Test: PM-2
Date: 11-16-13
Personnel: TDH/EJ
Test Start: 1:25 PM
Test Finish: 3:40 PM

Particulate Collected from Filter (mg): 77.8
Particulate Collected from Probe Wash (mg): 19.4
Particulate Collected from Impinger Wash (mg): 1.2
Total Particulate Collected (mg): 97.3

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 ml H2O	883.6	886.4	217.2
2	100 ml H2O	741.5	711.3	28.2
3	Burn	888.9	888.9	2.8
4	200g Silica Gel	1037.2	1025.6	11.6

Total Weight Gain (g): 257.8
Moisture Volume (mL): 257.8

Parameters
Barometric Pressure, Pbar (in. Hg)
Stack Static Pressure, Pstatic (in. H2O)
Ambient Temp, (°F)
H2O Volume Collected, Vw (mL)
Total # Sampling Points,
Sampling Time per Point, (mins)
Readings Taken Every ___ mins
Regulatory Agency

29.70 O2 (%) 17.0
6.20 CO2 (%) 2.2
41 H2 (%) 85.8
177.8 CO (ppm) 255.1
24 NO (ppm) 17.6
5 SO2 (ppm) 0.0
2.0

Stack Diameter, (in.) 72
Stack Area, (sq. ft.) 28.27
Probe Length, (ft.) 8
Nozzle Diameter, (in.) 0.172
Pitot Coefficient, (Cp) 0.818
Gorams, meter constant 1.033
Port length, (in.) 6

Traverse Point	Time (mins)	Stack Gas Temp, Ts (°F)	S-type Pitot delta P (in. H2O)	Orifice delta H (in. H2O)	Gas Meter Volume (cu. ft.)	Gas Meter Temp (°F)	
						Inlet	Outlet
Traverse 1	2.5	136	1.80	0.83	296.720	71	71
	5	137	1.60	0.88	298.110	71	71
	7.5	137	1.40	0.77	302.600	72	71
	10	134	1.30	0.83	303.890	72	71
	12.5	134	1.30	0.72	303.000	72	71
	15	134	1.30	0.72	304.210	72	71
	17.5	133	1.25	0.89	303.410	72	72
	20	134	1.25	0.68	307.660	72	71
	22.5	132	1.20	0.69	306.520	72	71
	25	136	1.20	0.66	307.660	72	71
	27.5	135	1.15	0.64	309.910	72	70
	30	137	1.20	0.66	311.060	74	71
32.5	136	1.15	0.63	312.160	74	71	
35	135	1.10	0.61	312.260	74	71	
37.5	137	1.05	0.58	314.590	74	71	
40	137	1.05	0.58	315.590	75	71	
42.5	137	1.20	0.66	316.590	75	72	
45	135	1.15	0.64	318.900	75	72	
47.5	136	1.40	0.84	317.630	75	72	
50	134	1.30	0.70	318.900	75	72	
52.5	134	1.30	0.73	321.270	77	73	
55	134	1.30	0.84	322.540	77	73	
57.5	137	1.80	1.00	323.930	77	73	
60	132	1.75	0.98	323.310	77	73	
Traverse 2	62.5	130	0.98	0.51	323.310	74	74
	65	132	0.94	0.33	326.580	74	74
	67.5	128	0.94	0.33	327.600	74	74
	70	127	0.92	0.51	328.460	74	73
	72.5	128	0.88	0.30	329.870	74	73
	75	132	0.89	0.47	331.440	73	73
	77.5	133	0.89	0.43	332.360	73	73
	80	136	0.82	0.45	333.130	73	73
	82.5	137	0.83	0.46	334.310	73	73
	85	131	0.84	0.47	333.360	73	73
	87.5	130	0.97	0.32	336.320	74	73
	90	130	1.00	0.34	337.360	74	73
92.5	132	1.00	0.54	338.400	74	73	
95	132	1.20	0.67	339.300	74	73	
97.5	139	1.40	0.77	340.760	74	73	
100	137	1.40	0.78	341.990	75	72	
102.5	139	1.20	0.82	343.360	75	72	
105	133	1.20	0.83	344.310	75	72	
107.5	135	1.60	0.99	345.850	76	75	
110	125	1.51	0.86	347.140	76	75	
112.5	136	1.60	0.89	348.440	78	74	
115	134	1.60	0.89	349.750	78	74	
117.5	135	1.60	0.89	351.060	78	74	
120	134	1.63	0.92	352.410	79	74	

Calculations for: Northern Pig Power Boiler PM
Test #2

Client: Northern Pig
Job Number: 121412-058
Plant: Power Boiler
Location: Pictou, NS
Test: PM-3
Date: 23-Jul-19
Personnel: TBM/SF

Calculated Parameters

Stack Gas Pressure, Ps (in Hg) 29.71
Stack Gas Molecular Weight, Dry Basis, Md (lb/lb-mole) 28.84
Volume of Water Vapour Collected, Vwc (cu ft) 12.274
Stack Gas Moisture Content (% as decimal) 0.177
Stack Gas Molecular Weight, Wet Basis, Mw (lb/lb-mole) 27.09

Isokineticity Checks

Check range Within Criteria
Check average Within Criteria

Traverse Point	Time (min)	Stack Gas Temp, Tg (F)	Stack Prot. delta P (in H2O)	Drift delta H (in H2O)	Stack Gas Velocity, Us (ft/s)	Meter Press. Pm (in. Hg)	Gas Meter		Vol. @ Ref. Vm (cu. ft)	Isokinetics (%)	
							Avg. Temp. Tm (F)	Volume, Vm (cu. ft)			
Traverse 1	1	2.5	599	1.50	0.83	73.39	29.78	531	1.290	1.340	102.49
	2	5	597	1.60	0.89	73.88	29.78	532	1.310	1.358	100.87
		10	597	1.40	0.77	70.89	29.78	532	1.280	1.329	100.22
	3	12.5	597	1.50	0.83	73.45	29.78	532	1.290	1.346	99.32
		17.5	594	1.30	0.72	68.20	29.73	532	1.210	1.245	102.10
	4	20	595	1.25	0.69	68.89	29.75	532	1.200	1.256	102.89
		22.5	594	1.20	0.66	62.58	29.75	532	1.110	1.244	104.11
	5	25	595	1.20	0.66	65.84	29.75	532	1.140	1.183	101.03
		27.5	595	1.15	0.64	64.20	29.75	531	1.120	1.173	100.22
	6	30	597	1.30	0.68	65.09	29.75	533	1.150	1.191	101.89
		32.5	597	1.15	0.63	64.38	29.74	533	1.080	1.119	102.28
	7	35	595	1.10	0.61	62.78	29.74	533	1.100	1.139	101.61
37.5		597	1.05	0.58	61.45	29.74	533	1.050	1.119	102.28	
8	40	597	1.20	0.66	65.89	29.75	534	1.080	1.086	99.54	
	42.5	597	1.15	0.64	64.20	29.78	534	1.130	1.180	101.70	
9	45	595	1.40	0.78	70.80	29.75	534	1.110	1.147	100.10	
	47.5	594	1.30	0.72	66.20	29.75	534	1.230	1.293	102.29	
10	50	594	1.30	0.73	66.20	29.75	535	1.170	1.210	99.78	
	52.5	594	1.50	0.84	73.29	29.78	535	1.200	1.237	101.43	
11	55	597	1.80	1.00	80.49	29.77	535	1.270	1.310	98.97	
	57.5	595	1.75	0.98	79.20	29.77	535	1.380	1.434	100.17	
Traverse 2	1	82.5	590	0.98	0.55	59.02	29.74	534	1.070	1.105	103.87
	2	85	587	0.94	0.53	57.80	29.74	534	1.020	1.053	101.36
		87.5	588	0.94	0.53	57.70	29.74	534	1.080	1.095	105.09
	3	70	587	0.82	0.52	57.04	29.74	534	1.010	1.044	101.12
		72.5	586	0.88	0.50	55.83	29.74	534	1.000	1.033	102.45
	4	75	582	0.85	0.47	55.28	29.73	533	0.970	1.002	101.51
		77.5	593	0.90	0.45	53.48	29.73	533	0.940	0.972	103.73
	5	80	596	0.82	0.45	54.28	29.73	533	0.970	1.002	102.13
		82.5	597	0.83	0.46	54.63	29.73	533	0.980	1.024	101.17
	6	85	591	0.84	0.47	54.69	29.74	534	1.020	1.054	100.58
		87.5	588	0.95	0.53	58.01	29.74	534	1.040	1.075	101.87
	7	90	590	0.87	0.54	58.72	29.74	534	1.040	1.075	100.15
92.5		590	1.00	0.58	58.62	29.75	534	1.103	1.137	98.87	
8	95	597	1.40	0.77	70.88	29.78	534	1.260	1.303	103.36	
	97.5	595	1.20	0.67	65.42	29.75	534	1.230	1.272	100.74	
9	100	597	1.40	0.77	70.88	29.78	534	1.260	1.303	103.36	
	102.5	595	1.50	0.83	73.32	29.78	534	1.250	1.293	100.33	
10	105	595	1.50	0.83	73.32	29.78	534	1.250	1.293	100.33	
	107.5	595	1.80	0.89	79.73	29.77	535	1.340	1.384	102.32	
11	110	595	1.80	0.89	79.73	29.77	535	1.340	1.384	102.32	
	112.5	596	1.60	0.88	75.79	29.77	536	1.310	1.358	101.27	
12	115	596	1.60	0.88	75.79	29.77	536	1.310	1.358	101.27	
	117.5	595	1.80	0.88	75.73	29.77	536	1.350	1.398	99.98	
	120	594	1.65	0.82	76.84	29.77	537	1.330	1.368	99.98	
	Total		Average 594	Average 1.25	Average 0.69	Average 66.45	Average 29.75	Average 533	Total 52.990	Total 57.587	Average 101.12

Combustion Gas Data for: Northern Pulp

Client: Northern Pulp
Job Number: 121413456

Plant: Power Boiler
Location: Pictou, NS
Test: PM-2
Date: 23-Jul-15
Personnel: TBH/SF

Test Start: 2:00 PM
Test Finish: 2:30 PM

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
0	17.9	1.9	80	0	14
5	18.2	1.6	122	0	12
10	18.1	1.6	124	0	13
15	16.2	2.7	340	0	21
20	16.2	2.7	323	0	20
25	16.0	2.7	310	0	22
30	16.3	2.6	347	0	21
Average:	17.0	2.2	235	0	18

Raw Data for: Northern Pulp Power Boiler PM
Test #3

Client: Northern Pulp
Job Number: 121413495

Plant: Power Boiler
Location: Pictou, NS
Test: PM-3
Date: 24-Jul-13
Personnel: TDM
Test Start: 9:00 AM
Test Finish: 10:00 AM

Particulate Collected from Filter (mg): 194.8
Particulate Collected from Probe Wash (mg): 13.7
Particulate Collected from Impinger Wash (mg): 2.7
Total Particulate Collected (mg): 211.2

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 ml H2O	778.1	884.3	183.8
2	100 ml H2O	671.7	637.9	33.8
3	Blank	672.2	635.6	6.6
4	200g Silica Gel	1035.6	1037.1	13.5

Total Weight Gain (g): 237.7
Moisture Volume (mL): 237.7

Parameters

Barometric Pressure, Pbar (in. Hg)
Stack Static Pressure, Pstatic (in. H2O)
Ambient Temp, (°F)
H2O Volume Collected, Vw (mL)
Total # Sampling Points,
Sampling Time per Point, (min)
Readings Taken Every ___ mins
Regulatory Agency

29.98	O2, (%)	13.23	Stack Diameter, (in.)	72
0.20	CO2, (%)	4.23	Stack Area, (sq. ft.)	28.27
68	N2, (%)	82.55	Probe Length, (ft.)	8
317.70	CO (ppm)	368.1	Nozzle Diameter, (in.)	0.172
24	NO (ppm)	36.7	Pitot Coefficient, (Cp)	0.816
5	SO2 (ppm)	0.0	Gamma, meter constant	1.033
2.3			Port length, (in.)	6

Traverse Point	Time (min)	Stack Gas Temp, Tg (°F)	S-Type Pitot delta P (in. H2O)	Orifice delta H (in. H2O)	Gas Meter Volume (cu. ft.)	Gas Meter Temp (°F)	
						Inlet	Outlet
Traverse 1	1	2.5	1.90	0.80	352.640	73	73
		5	1.91	0.82	352.630	74	73
	2	7.5	1.92	0.81	354.580	74	73
		10	1.91	0.82	354.610	74	73
	3	12.5	1.93	0.85	357.370	73	73
		15	1.94	0.86	358.330	73	73
	4	17.5	1.94	0.85	359.510	73	73
		20	1.94	0.84	360.690	73	73
	5	22.5	1.93	0.82	361.490	73	73
		25	1.93	0.80	362.380	73	73
	6	27.5	1.93	0.84	363.300	76	73
		30	1.96	0.82	364.290	76	73
7	32.5	1.97	0.84	365.390	77	74	
	35	1.97	0.86	366.230	77	74	
8	37.5	1.92	0.86	367.230	77	74	
	40	1.90	0.83	368.190	77	74	
9	42.5	1.90	1.10	369.270	77	74	
	45	1.90	1.10	370.370	77	74	
10	47.5	1.90	1.40	371.990	77	74	
	50	1.92	1.45	372.850	79	73	
11	52.5	1.94	1.30	374.130	79	73	
	55	1.94	1.70	375.090	79	73	
12	57.5	1.94	1.75	376.070	79	73	
	60	1.94	1.70	376.23	80	73	
Traverse 2	1	62.5	1.94	1.30	378.230	76	76
		65	1.92	0.84	379.510	76	76
	2	67.5	1.93	0.76	380.790	76	76
		70	1.94	1.45	382.050	76	76
	3	72.5	1.93	1.10	383.270	76	76
		75	1.96	1.20	384.590	76	76
	4	77.5	1.93	1.10	385.500	78	76
		80	1.94	1.15	386.670	78	76
	5	82.5	1.93	1.10	387.790	78	76
		85	1.93	1.10	388.690	78	76
	6	87.5	1.93	1.15	390.030	78	76
		90	1.93	1.10	391.130	78	76
7	92.5	1.93	1.10	392.270	78	76	
	95	1.96	1.20	393.390	78	76	
8	97.5	1.96	1.20	394.580	78	76	
	100	1.96	1.20	395.770	78	76	
9	102.5	1.93	1.23	396.970	78	76	
	105	1.96	1.30	398.000	78	76	
10	107.5	1.93	1.40	399.000	78	76	
	110	1.93	1.50	400.630	78	76	
11	112.5	1.93	1.50	401.970	78	76	
	115	1.93	1.70	403.270	78	76	
12	117.5	1.96	1.80	404.600	78	73	
	120	1.93	1.85	405.190	78	73	
				407.480	78	79	

Calculations for: Northern Pulp Power Boiler PM
Test #3

Client: Northern Pulp
Job Number: 121413498
Plant: Power Boiler
Location: Pulp, NB
Test: PM-3
Date: 04-24-15
Personnel: TBN

Calculated Parameters

Stack Gas Pressure, P_s (in. Hg)
Stack Gas Molecular Weight, Dry Basis, M_d (lb/lb-mole)
Volume of Water Vapor Collected, V_w (cu ft)
Stack Gas Moisture Content (% as decimal)
Stack Gas Molecular Weight, Wet Basis, M_w (lb/lb-mole)

28.81
29.21
11.410
0.187
27.33

Isokineticity Checks

Check range
Check average
Within Criteria
Within Criteria

Traverse	Point	Time (min)	Stack Gas Temp, T _s (°F)	S-type Pitot, static P (in. H ₂ O)	Orifice static H (in. H ₂ O)	Stack Gas Velocity, U _s (ft/s)	Water Press., P _w (in. Hg)	Avg. Temp., T _m (°F)	Gas Meter Volume, V _m (cu. ft)	Vol. @ Ref. V _w (cu. ft)	Isokineticity I (%)
Traverse 1	1	2.5	590	0.83	0.45	52.90	29.93	533	0.980	1.000	103.03
		5	591	0.82	0.48	53.81	29.93	534	0.980	0.989	101.78
		7.5	592	0.82	0.51	56.83	29.94	534	1.020	1.051	102.18
	3	12.5	595	0.82	0.51	56.87	29.94	534	1.010	1.051	101.43
		15	594	0.86	0.47	54.76	29.93	534	0.980	0.996	100.20
	4	17.5	594	0.85	0.47	54.72	29.93	534	0.980	1.019	101.80
		20	594	0.84	0.47	54.38	29.93	534	0.980	0.998	100.11
	5	22.5	595	0.82	0.46	53.79	29.93	534	0.980	1.018	102.80
		25	595	0.82	0.48	55.13	29.93	534	0.980	0.998	102.01
	6	27.5	596	0.84	0.47	54.44	29.93	534	0.980	0.987	102.00
	7	30	598	0.82	0.46	53.83	29.93	535	0.980	0.985	100.04
		32.5	597	0.84	0.47	54.53	29.94	536	0.980	0.987	102.00
	35	597	0.88	0.48	55.18	29.93	536	0.980	0.987	102.00	
	37.5	602	0.88	0.47	55.41	29.94	536	0.980	1.025	100.54	
	40	600	0.85	0.47	54.98	29.93	536	0.980	1.016	102.00	
	42.5	600	1.10	0.81	62.56	29.94	536	0.980	0.995	102.33	
	45	600	1.10	0.81	62.56	29.94	536	1.080	1.120	99.28	
10	47.5	600	1.40	0.77	70.58	29.94	536	1.100	1.140	101.08	
	50	602	1.45	0.80	71.85	29.98	537	1.220	1.265	99.43	
	52.5	594	1.70	0.95	77.38	29.97	537	1.260	1.323	102.79	
	55	594	1.70	0.95	77.38	29.97	537	1.270	1.314	99.23	
	57.5	594	1.75	0.98	78.51	29.97	537	1.370	1.416	100.58	
	60	594	1.70	0.95	77.38	29.97	538	1.380	1.428	99.88	
								1.380	1.408	99.75	
Traverse 2	1	62.5	594	1.50	0.84	72.88	29.90	538	1.280	1.324	99.99
		65	592	1.50	0.84	72.87	29.98	538	1.280	1.327	100.03
	2	67.5	593	1.35	0.78	68.90	29.98	537	1.280	1.308	102.86
		70	594	1.45	0.81	71.47	29.98	537	1.220	1.283	97.02
	3	72.5	595	1.10	0.62	62.30	29.98	537	1.130	1.158	102.27
		75	598	1.20	0.67	65.12	29.95	537	1.180	1.199	100.37
	4	77.5	595	1.15	0.64	63.70	29.95	537	1.130	1.188	102.86
		80	594	1.10	0.62	62.25	29.95	537	1.110	1.148	101.23
	5	82.5	595	1.10	0.62	62.30	29.95	537	1.110	1.148	101.31
		85	595	1.10	0.62	62.30	29.95	537	1.130	1.188	100.88
	6	87.5	595	1.10	0.62	62.30	29.95	537	1.130	1.188	100.14
		90	595	1.20	0.67	65.12	29.95	537	1.120	1.158	102.22
	92.5	596	1.20	0.67	65.12	29.95	537	1.120	1.158	97.85	
7	95	595	1.30	0.73	67.78	29.95	537	1.180	1.230	104.08	
	97.5	595	1.25	0.70	66.41	29.95	537	1.180	1.230	102.00	
8	100	595	1.30	0.73	67.78	29.95	537	1.180	1.230	102.00	
	102.5	598	1.25	0.70	66.41	29.95	537	1.200	1.241	102.77	
9	105	595	1.40	0.78	70.28	29.95	537	1.220	1.282	102.33	
	107.5	590	1.50	0.84	72.75	29.98	537	1.210	1.251	97.81	
10	110	598	1.50	0.80	72.45	29.95	537	1.230	1.272	96.17	
	112.5	590	1.70	0.84	72.75	29.98	537	1.340	1.388	104.78	
	115	595	1.80	1.01	78.88	29.98	537	1.300	1.345	95.46	
	117.5	598	1.80	1.00	78.78	29.97	537	1.420	1.471	101.48	
	120	595	1.85	1.03	80.78	29.97	537	1.418	1.461	100.87	
								1.380	1.429	97.36	
	Total	120	Average 595	Average 1.21	Average 0.67	Average 64.85	Average 29.95	Average 538	Total 54.620	Total 56.781	Average 100.80

Combustion Gas Data for: Northern Pulp

Client: Northern Pulp
Job Number: 121413456

Plant: Power Boiler
Location: Pictou, NS
Test: PM-3
Date: 24-Jul-15
Personnel: TBH

Test Start: 8:10 AM
Test Finish: 8:40 AM

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
0	14.2	3.0	473	0	20
5	13.9	4.0	421	0	32
10	13.3	4.3	329	0	37
15	13.4	4.2	362	0	36
20	13.2	4.3	393	0	37
25	12.4	4.8	344	0	49
30	12.2	5.0	395	0	46
Average:	13.2	4.2	388	0	37

DATA ENTRY

Northern Pulp

Pictou, NS

Fuel: Natural Gas

Operating Conditions: low normal

Emission Control Equipment: scrubber

Stack Height from Grade: 51 m

Stack Diameter: 1.93 m

Reference Temperature, Tref (F): 77
 (K): 298
 Reference Pressure, Pref (in.Hg): 29.92
 (Bar): 1.0

Parameter	Symbol	Units	Test 1	Test 2	Test 3	Average
Test ID	-	-	PM-1	PM-2	PM-3	-
Date	-	-	23-Jul-15	23-Jul-15	24-Jul-15	n/a
Start Time	-	-	9:42 AM	1:25 PM	8:00 AM	n/a
End Time	-	-	11:51 AM	3:40 PM	10:08 AM	n/a
Total Sampling Time	-	min	120	120	120	120
Stack Diameter	D	in.	72	72	72	72
Average Stack Gas Temperature	Ts	F	129	134	135	133
Average Dry Gas Meter Temperature	Tm	F	71	73	76	73
Barometric Pressure	Pbar	in.Hg	29.60	29.70	29.90	29.73
Stack Static Pressure	Pstatic	in.H2O	0.20	0.20	0.20	0.20
Average Pressure Drop (Head)	dP	in.H2O	1.21	1.25	1.21	1.22
Average deltaH Orifice	dH	in.H2O	0.68	0.69	0.67	0.68
Average Meter Temperature	Tm	F	71	73	76	73
Gas Sample Volume	Vm	cu.ft	55.22	55.69	54.82	55.24
Average Isokinetics	I	%	98.57	101.12	100.80	100.16
Nozzle Diameter	Dn	in.	0.172	0.172	0.172	0.172
Pitot Coefficient	Cp	-	0.816	0.816	0.816	0.816
Gamma, meter constant	γ	-	1.033	1.033	1.033	1.033
Reference Temperature	Tref	R	537	537	537	537
Reference Pressure	Pref	in.Hg	29.92	29.92	29.92	29.92
Stack Gas Oxygen Content	Co2	%	16.1	17.0	13.2	15.4
Stack Gas Carbon Dioxide Content	Cco2	%	2.5	2.2	4.2	3.0
Stack Gas Nitrogen Content	Cn2	%	81.3	80.8	82.5	81.6
Stack Gas Sulphur Dioxide Content	Cso2	ppm	0.0	0.0	0.0	0.0
Stack Gas Nitrogen Oxides Content	Cnox	ppm	18.9	17.6	36.7	24.4
Stack Gas Carbon Monoxide Content	Cco	ppm	1037.4	235.1	388.1	553.6
Volume of Water Collected	Vw	mL	203.7	257.8	237.7	233.1
Particulate Collected from Filter	-	mg	70.9	77.9	194.6	114.5
Particulate Collected from Probe Wash	-	mg	26.3	19.4	13.7	19.8
Particulate Collected from Impinger Wash	-	mg	23.7	1.2	3.7	9.5
Total Particulate Collected (excluding impingers)	Mp	mg	97.2	97.3	208.3	134.2

Legend: F - degrees Fahrenheit
 K - degrees Kelvin
 Bar - bars
 in.Hg - inches of mercury
 in. - inches

in H2O - inches of water
 cu.ft - cubic feet
 R - degrees Rankin
 NOx - as NO2

CALCULATIONS
 Northern Pulp
 Pictou, NS
 Fuel: Natural Gas
 Operating Conditions: low normal
 Emission Control Equipment: scrubber
 Stack Height from Grade: 51 m
 Stack Diameter: 1.93 m

Variable	Symbol	Units	Calculation	Test 1	Test 2	Test 3	Average
Stack Area	A _s	sq ft sq m	$A_s = \pi \times ((D/2)^2) \times 4$ $A_s (\text{sq m}) = A_s (\text{sq ft}) \times 0.0929$	28.27 2.63	28.27 2.63	28.27 2.63	28.27 2.63
Barometric Pressure	P _{bar}	kPa	$P_{bar} (\text{kPa}) = P_{bar} (\text{in Hg}) \times 3.386$	100.2	100.6	101.2	100.7
Stack Static Pressure	P _{static}	kPa	$P_{static} (\text{kPa}) = P_{static} (\text{in H}_2\text{O}) \times 0.249$	0.05	0.05	0.05	0.05
Avg. Stack Temperature	T _s	R	$T_s (R) = T_s (F) + 460$	589	594	595	593
Avg. Meter Temperature	T _m	R	$T_m (R) = T_m (F) + 460$	531	533	536	533.5
Nozzle Diameter	D _n	mm	$D_n (\text{mm}) = D_n (\text{in.}) \times 25.4$	4	4	4	4.4
Gas Meter Pressure	P _m	in. Hg	$P_m = P_{bar} + (dH / 13.6)$	29.65	29.75	29.95	29.78
Sample Volume at Ref Cond	V _m	cu ft cu m	$V_m = T_{ref} \times P_{ref} \times (V_m \times P_m \times T_s) / T_m$ $V_m (\text{cu m}) = 0.02832 \times V_m (\text{cu ft})$	57.15 1.62	57.60 1.63	56.80 1.81	57.2 1.62
Volume of Water Vapour	V _w	cu ft	$V_w = 0.0480 \times V_m$	9.78	12.37	11.41	11.19
Water Fraction	D _w	-	$D_w = V_w / (V_w + V_m)$	0.146	0.177	0.167	0.2
Molecular Weight, Dry	M _d	lb-lb-mol	$M_d = 0.44 (\text{CO}_2) + 0.32 (\text{CO}_2) + 0.28 (\text{CO}_2)$	29.05	29.04	29.21	29.1
Molecular Weight, Wet	M _w	lb-lb-mol	$M_w = M_d (1 - D_w) + (18 \times D_w)$	27.44	27.09	27.33	27.3
Stack Pressure	P _s	in. Hg	$P_s = P_{bar} + (P_{static} / 13.6)$	29.61	29.71	29.91	29.75
Stack Gas Velocity	V _s	ft/s m/s	$V_s = 85.33 \times C_p \times ((dP \times T_s) / (P_s \times M_d))^{0.5}$ $V_s (\text{m/s}) = 0.3048 \times V_s (\text{ft/s})$	64.77 19.74	66.45 20.25	64.65 19.71	65.3 19.9
Actual Stack Gas Flow Rate	Q	acfm	$Q = 60 \times V_s \times A_s$	109,874	112,729	109,884	110,762
Dry Stack Gas Flow Rate	Q _d	ft ³ /min Rcm	$Q_d = Q \times (1 - D_w) \times (T_{ref} / T_s) \times (P_s / P_{ref})$ $Q_d (\text{Rcm}) = 0.000472 \times Q_d (\text{ft}^3/\text{min})$	84,672 39.97	83,270 39.30	82,367 38.88	83,436 39.4
Sulphur Dioxide - SO ₂							
SO ₂ Measured Concentration	C _{so2}	ppm	Measurement from Flow Gas Analyser	0.00	0.00	0.00	0.00
Uncorrected @ Ref Cond	C _{so2}	mg/Rcm	$C_{so2} (\text{mg/Rcm}) = C_{so2} (\text{ppm}) \times 2.62$	0.00	0.00	0.00	0.00
SO ₂ Emission Rate	ER _{so2}	g/s kg/hr	$ER_{so2} = C_{so2} / 1000 \times Q_d$ $ER_{so2} (\text{kg/hr}) = 3.6 \times ER_{so2} (\text{g/s})$	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00
SO ₂ Concentration							
Corrected to 11% O ₂	C _{so2}	mg/Rcm	$C_{so2} (11\% \text{ O}_2) = C_{so2} (\text{mg/Rcm}) \times (20.9 - 11) / (20.9 - C_{o2})$	0.00	0.00	0.00	0.00
Corrected to 3% O ₂	C _{so2}	mg/Rcm	$C_{so2} (3\% \text{ O}_2) = C_{so2} (\text{mg/Rcm}) \times (20.9 - 3) / (20.9 - C_{o2})$	0.00	0.00	0.00	0.00
Corrected to 12% CO ₂	C _{so2}	mg/Rcm	$C_{so2} (12\% \text{ CO}_2) = C_{so2} (\text{mg/Rcm}) \times (12 - C_{co2})$	0.00	0.00	0.00	0.00
Nitrogen Oxides - NO _x							
NO _x Measured Concentration	C _{no2}	ppm	Measurement from Flow Gas Analyser	18.86	17.57	36.71	24.38
Uncorrected @ Ref Cond	C _{no2}	mg/Rcm	$C_{no2} (\text{mg/Rcm}) = C_{no2} (\text{ppm}) \times 1.892$	35.49	33.07	69.10	45.86
NO _x Emission Rate	ER _{no2}	g/s kg/hr	$ER_{no2} = C_{no2} / 1000 \times Q_d$ $ER_{no2} (\text{kg/hr}) = 3.6 \times ER_{no2} (\text{g/s})$	1.42 5.11	1.30 4.68	2.69 9.67	1.80 6.49
NO _x Concentration							
Corrected to 11% O ₂	C _{no2}	mg/Rcm	$C_{no2} (11\% \text{ O}_2) = C_{no2} (\text{mg/Rcm}) \times (20.9 - 11) / (20.9 - C_{o2})$	73.92	83.37	89.15	82.15
Corrected to 3% O ₂	C _{no2}	mg/Rcm	$C_{no2} (3\% \text{ O}_2) = C_{no2} (\text{mg/Rcm}) \times (20.9 - 3) / (20.9 - C_{o2})$	133.66	150.73	161.19	148.53
Corrected to 12% CO ₂	C _{no2}	mg/Rcm	$C_{no2} (12\% \text{ CO}_2) = C_{no2} (\text{mg/Rcm}) \times (12 - C_{co2})$	168.52	177.27	196.22	180.87
Carbon Monoxide - CO							
CO Measured Concentration	C _{co}	ppm	Measurement from Flow Gas Analyser	1037.43	235.14	388.14	553.57
Uncorrected @ Ref Cond	C _{co}	mg/Rcm	$C_{co} (\text{mg/Rcm}) = C_{co} (\text{ppm}) \times 1.145$	1187.86	269.24	444.42	633.84
CO Emission Rate	ER _{co}	g/s kg/hr	$ER_{co} = C_{co} / 1000 \times Q_d$ $ER_{co} (\text{kg/hr}) = 3.6 \times ER_{co} (\text{g/s})$	47.47 170.90	10.58 38.10	17.28 62.20	25.11 90.40
CO Concentration							
Corrected to 11% O ₂	C _{co}	mg/Rcm	$C_{co} (11\% \text{ O}_2) = C_{co} (\text{mg/Rcm}) \times (20.9 - 11) / (20.9 - C_{o2})$	2474.25	678.73	573.42	1242.13
Corrected to 3% O ₂	C _{co}	mg/Rcm	$C_{co} (3\% \text{ O}_2) = C_{co} (\text{mg/Rcm}) \times (20.9 - 3) / (20.9 - C_{o2})$	4473.65	1227.20	1036.80	2245.88
Corrected to 12% CO ₂	C _{co}	mg/Rcm	$C_{co} (12\% \text{ CO}_2) = C_{co} (\text{mg/Rcm}) \times (12 - C_{co2})$	5640.47	1443.27	1262.05	2781.93
Particulate Concentration	C _p	mg/Rcm	$C_p = M_p / V_m$	60.04	59.63	129.48	83.05
Particulate Emission Rate	ER _p	g/s kg/hr	$ER_p = C_p / 1000 \times Q_d$ $ER_p (\text{kg/hr}) = 3.6 \times ER_p (\text{g/s})$	2.40 8.64	2.34 8.44	5.03 18.12	3.26 11.73
Particulate Concentration							
Corrected to 11% O ₂	C _p	mg/Rcm	$C_p (11\% \text{ O}_2) = C_p \times (20.9 - 11) / (20.9 - C_{o2})$	125.06	150.32	167.07	147.48
Corrected to 3% O ₂	C _p	mg/Rcm	$C_p (3\% \text{ O}_2) = C_p \times (20.9 - 3) / (20.9 - C_{o2})$	226.11	271.78	302.07	266.65
Corrected to 12% CO ₂	C _p	mg/Rcm	$C_p (12\% \text{ CO}_2) = C_p \times (12 - C_{co2})$	285.09	319.64	367.70	324.14

Legend: sq ft - square feet
 sq m - square metres
 ft - 1.42
 R - degrees Rankin
 ppm - parts per million

in Hg - inches of mercury
 cu ft - cubic feet
 cu m - cubic metres
 Ref Cond - reference temperature and pressure (25 °C and 101.3 kPa)
 Rcm - dry reference cubic metres per second
 Rcm - dry reference cubic feet per minute

mg/Rcm - milligrams per dry reference cubic metre
 g/s - grams per second
 NO_x - as NO₂
 acfm - actual cubic feet per minute

OFFICIAL STACK TESTING RESULTS

Northern Pulp

Pictou, NS

Fuel: Natural Gas

Operating Conditions: low normal

Emission Control Equipment: scrubber

Stack Height from Grade: 51 m

Stack Diameter: 1.93 m

Parameter	Test 1	Test 2	Test 3	Average	NSDOE Limits
Test ID	PM-1	PM-2	PM-3	-	-
Test Date	23-Jul-15	23-Jul-15	24-Jul-15	-	-
Stack Gas Temperature (C)	53.9	56.8	57.4	56.0	-
Moisture Content (%)	14.6	17.7	16.7	16.3	-
Velocity (m/s)	19.7	20.3	19.7	19.9	-
Volumetric Flow (Rcms)	40.0	39.3	38.9	39.4	-
Oxygen - O2 (%)	16.1	17.0	13.2	15.4	-
Carbon Dioxide - CO2 (%)	2.53	2.24	4.23	3.00	-
Sulphur Dioxide - SO2					
SO2 Measured Concentration (ppm)	0.0	0.0	0.0	0.0	-
Uncorrected at Ref Cond (mg/Rcm)	0.0	0.0	0.0	0.0	-
Emission Rate (kg/hr)	0.00	0.00	0.00	0.00	-
Nitrogen Oxides - NOx					
NOx Measured Concentration (ppm)	18.9	17.6	36.7	24.4	-
Uncorrected at Ref Cond (mg/Rcm)	35.5	33.1	69.1	45.9	-
Emission Rate (kg/hr)	5.11	4.68	9.67	6.49	-
Carbon Monoxide - CO					
CO Measured Concentration (ppm)	1037.4	235.1	388.1	553.6	-
Uncorrected at Ref Cond (mg/Rcm)	1187.9	269.2	444.4	633.8	-
Emission Rate (kg/hr)	170.90	38.10	62.20	90.40	-
Particulate Matter - PM					
Particulate Concentration (mg/Rcm)	60.0	59.6	129.5	83.0	-
Concentration, corrected to 11% O2 (mg/Rcm)	125.1	150.3	167.1	147.5	150
Particulate Emission Rate (kg/hr)	8.64	8.44	18.12	11.73	-

Legend: C - degrees Celsius
m/s - metres per second
Rcms - dry reference cubic metres per second
ppm - parts per million

Ref Cond - reference temperature and pressure (25 C and 101.3 kPa)
mg/Rcm - milligrams per dry reference cubic metre
NOx - as NO2
ND - non-detectable

Particulate Recovery Impinger Catch, Probe Wash Filter Catch

Client: Southern Pulp
 Facility: Paper Boiler
 Location: Filter #88
 Job Number: 17-433-03

IMPINGER CATCH

Container ID	Sample Pre Weights (g)				Sample ID	Recovery					Sample Post Weights (g)				Unrecovered Particulate Weight (g)	Corrected Particulate Weight (g)
	Date					Jet + Sample + Rinse (g)	Jet Rinse (g)	Sample Ashed (g)	Rinse Water (g)	Total Rinse Water (g)	Date					
	Assembled by										Assembled by					
	Test 1	Test 2	Test 3	Average						Test 1	Test 2	Test 3	Average			
15	110.084	110.099		110.0915	Imp 1	495.4	303.2	223.7	11.9	113.4	112.068	112.067	110.864	0.2218	0.2217	
16	112.1805	112.1881		112.1843	Imp 2	737.4	304.0	227.8	12.5	148.1	112.1798	112.1733	112.1795	0.2540	0.2542	
17	109.0744	109.0748		109.0746	Imp 3	647.4	304.0	227.7	13.1	70.9	109.0722	109.0737	109.0780	0.2042	0.2031	
18	100.1820	100.1824		100.1822	Wt	484.2	304.0	227.7	12.7	64.2	109.1844	109.1847	109.1847	0.2020	0.2020	

PROBE WASH




Container ID	Sample Pre Weights (g)				Sample ID	Recovery					Sample Post Weights (g)				Unrecovered Particulate Weight (g)	Corrected Particulate Weight (g)
	Date					Jet + Ashed (g)	Jet Rinse (g)	Ashed (g)	Rinse Ashed (g)	Total Ashed (g)	Date					
	Assembled by										Assembled by					
	Test 1	Test 2	Test 3	Average						Test 1	Test 2	Test 3	Average			
19	128.0287	128.0387		128.0337	Imp 1	400.0	303.3	217.2	23.0	122.2	128.0284	128.0290	128.0324	0.2205	0.2203	
20	120.1088	120.1152		120.1120	Imp 2	481.8	303.3	217.2	14.7	121.2	120.1084	120.1100	120.1102	0.2202	0.2198	
21	113.1824	113.1829		113.1826	Imp 3	479.7	302.4	217.2	9.2	66.4	113.1802	113.1804	113.1818	0.2184	0.2181	
22	113.2481	113.2481		113.2481	Wt	373.2	222.2	81.5	41.0	113.2481	113.2481	113.2481	0.2194	0.2192		

Labels of Recovery: 0.7880 g/m

FILTER CATCH

Filter ID	Pre Weights (g)				Sample ID	Post Weights (g)				Particulate Weight from Filter (g)
	Assembled by					Assembled by				
	Test 1	Test 2	Test 3	Average		Test 1	Test 2	Test 3	Average	
0716-14	0.1203	0.1204		0.12035	Imp 1	0.1811	0.1813		0.1812	0.0609
0716-11	0.1511	0.1511		0.1511	Imp 2	0.4292	0.4298		0.4295	0.2784
0716-18	0.1274	0.1277		0.12755	Imp 3	0.4214	0.4211		0.42125	0.2938

Stack Gas Velocity Profiles
Pictou, NS



Raw Date for: Northern Pulp Dissolving Tank PM

Test #1

Client: Northern Pulp
Job Number: 121413456

Plant: Dissolving Tank
Location: Pulp, NS
Test: 136-1
Date: 21-Jul-13
Personnel: JJB:JS

Test Start: 9:00 AM
Test Finish: 10:30 AM

Parameters
Barometric Pressure, Pbar (in. Hg)
Stack Static Pressure, Pstatic (in. H2O)
Ambient Temp, (°F)
H2O Volume Collected, Vw (mL)
Total # Sampling Points,
Sampling Time per Point, (min)
Readings Taken Every _____ mins
Regulatory Agency

Particulate Collected from Filter (mg): 301.9
Particulate Collected from Probe Wash (mg): 48.4
Particulate Collected from Impinger Wash (mg): 28.4
Total Particulate Collected (mg): 487.7

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H2O	808.9	708.5	279.6
2	100 mL H2O	820.0	743.1	76.9
3	Blew	808.1	803.7	1.4
4	200g Sacc Gel	853.9	847.1	6.8
5	Blank	865.1	855.0	130.1
		Total Weight Gain (g)		604.8
		Moisture Volume (mL)		604.8

29.70 O2 (%) 30.9
-0.20 CO2 (%)
63 N2 (%) 79.1
644.8 CO (ppm) 0.0
5 NOx (ppm) 0.0
2.3 SO2 (ppm) 0.0
NSENH

Stack Diameter, (in.) 48
Stack Area, (sq. ft.) 17.37
Probe Length, (ft.) 5
Nozzle Diameter, (in.) 0.306
Pitot Coefficient, (Cp) 0.256
Gamma, meter constant
Port length (in.) 1.117
6

Traverse Point	Time (min)	Stack Gas Temp, Tg (°F)	S-type Pitot delta P (in. H2O)	Orifice delta H (in. H2O)	Gas Meter Volume (cu. ft.)	Gas Meter Temp Inlet (°F)	Gas Meter Temp Outlet (°F)	
Traverse 1	1	2.5	171	0.18	0.19	732.776		
	5	182	0.18	0.19	733.320	87	87	
	10	184	0.19	0.20	734.350	87	87	
	15	184	0.19	0.20	735.250	87	87	
	20	183	0.19	0.20	735.940	87	87	
	25	183	0.19	0.20	736.640	87	87	
	30	180	0.19	0.20	737.370	87	87	
	35	179	0.18	0.19	738.070	87	87	
	40	181	0.19	0.20	739.370	87	87	
	45	183	0.19	0.20	740.070	87	87	
Traverse 2	1	32.5	183	0.19	0.20	742.780	88	87
	5	37.5	183	0.18	0.19	743.480	88	87
	10	40	180	0.18	0.20	743.660	88	88
	15	42.5	179	0.18	0.20	743.260	88	88
	20	45	179	0.18	0.19	743.880	88	88
	25	47.5	179	0.18	0.19	744.430	88	88
	30	50	174	0.18	0.19	745.040	88	88
	35	182	0.08	0.17	745.610	88	88	
	40	172	0.06	0.15	746.160	88	88	
	45	180	0.10	0.19	747.360	88	88	

Calculations for: Northern Pulp Desolving Tank PM
Test #1

Client: Northern Pulp
Job Number: 121413458

Plant: Desolving Tank
Location: Pulp Mill
Test: PM-1
Date: 21-Jun-15
Personnel: JJB/TS

Calculated Parameters

Stack Gas Pressure, Pa (in.Hg) 29.69
Stack Gas Molecular Weight, Dry Basis, M_d (lb/lb-mole) 28.84
Volume of Water Vapour Collected, V_{wc} (cu ft) 33.305
Stack Gas Moisture Content (% as decimal) 0.005
Stack Gas Molecular Weight, Wet Basis, M_w (lb/lb-mole) 23.36

Isokineticity Checks

Check range Outside of Criteria
Check average Within Criteria

Traverse	Point	Time (min)	Stack Gas Temp, T _s (°F)	S-type Pitot, delta P (in. H ₂ O)	Orifice delta H (in. H ₂ O)	Stack Gas Velocity, U _s (ft/s)	Meter Press., P _m (in. Hg)	Avg. Temp., T _m (°F)	Volume, V _m (cu ft)	Vol @ Ref., V _{wc} (cu ft)	Isokineticity (%)
Traverse 1	1	2.5	631	0.10	0.19	21.52	29.71	547	0.550	0.509	87.01
	2	5	642	0.10	0.19	21.71	29.71	547	0.560	0.632	92.55
	3	10	644	0.15	0.29	28.62	29.72	547	0.620	0.709	84.84
	4	12.5	644	0.15	0.29	28.62	29.72	547	0.700	0.763	81.37
	5	15	643	0.15	0.29	28.62	29.72	547	0.680	0.752	90.06
	6	17.5	643	0.15	0.29	28.60	29.72	547	0.720	0.784	83.90
	7	20	640	0.15	0.29	28.54	29.72	547	0.710	0.773	82.60
	8	22.5	632	0.10	0.19	21.54	29.71	547	0.700	0.763	87.08
	9	25	641	0.15	0.29	28.56	29.72	547	0.580	0.632	81.63
	10	27.5	643	0.15	0.29	28.60	29.72	547	0.720	0.784	83.78
Traverse 2	1	30	643	0.15	0.29	28.60	29.72	547	0.700	0.763	81.30
	2	32.5	643	0.15	0.29	28.60	29.72	548	0.710	0.773	92.52
	3	35	643	0.10	0.20	21.57	29.71	548	0.700	0.763	91.21
	4	37.5	620	0.10	0.20	21.57	29.71	548	0.600	0.653	89.73
	5	40	634	0.10	0.20	21.33	29.71	548	0.580	0.630	90.79
	6	42.5	633	0.10	0.19	21.55	29.71	548	0.600	0.652	84.97
	7	45	635	0.10	0.19	21.59	29.71	548	0.620	0.674	88.08
	8	47.5	635	0.10	0.19	21.59	29.71	548	0.570	0.620	80.29
	9	50	634	0.10	0.19	21.57	29.71	548	0.560	0.641	80.48
	10										80.22
Traverse 2	1	52.5	642	0.09	0.17	20.99	29.71	548	0.550	0.509	82.34
	2	55	632	0.08	0.15	19.28	29.71	548	0.530	0.578	83.83
	3	57.5	640	0.10	0.19	21.87	29.71	548	0.570	0.620	90.65
	4	60	640	0.10	0.19	21.87	29.71	548	0.570	0.620	90.65
	5	62.5	640	0.13	0.25	24.71	29.72	548	0.650	0.707	90.67
	6	65	625	0.13	0.23	23.85	29.72	548	0.670	0.729	89.45
	7	67.5	625	0.12	0.23	23.87	29.72	548	0.690	0.718	87.18
	8	70	626	0.13	0.25	25.14	29.72	548	0.630	0.685	87.18
	9	72.5	615	0.14	0.28	25.14	29.72	548	0.670	0.728	80.17
	10	75	630	0.17	0.33	28.03	29.72	543	0.650	0.750	80.93
Traverse 2	1	77.5	632	0.29	0.54	32.37	29.75	548	0.750	0.813	80.71
	2	80	623	0.25	0.48	34.05	29.74	549	0.900	0.978	80.94
	3	82.5	601	0.30	0.61	35.20	29.74	549	0.940	1.044	86.58
	4	85	610	0.33	0.67	38.43	29.75	549	1.020	1.109	80.77
	5	87.5	602	0.33	0.67	38.18	29.75	550	1.040	1.131	86.91
	6	90	600	0.35	0.71	39.25	29.75	550	1.070	1.161	80.71
	7	92.5	597	0.30	1.01	48.80	29.77	550	1.100	1.194	82.43
	8	95	600	0.70	1.43	65.32	29.81	550	1.250	1.358	85.80
	9	97.5	601	0.70	1.43	65.26	29.81	550	1.410	1.532	82.01
	10	100	601	0.70	1.43	65.26	29.81	550	1.490	1.619	86.74
Total	100		Average 630	Average 0.19	Average 0.37	Average 27.97	Average 29.73	Average 548	Total 30.620	Total 32.945	Average 81.11

Combustion Gas Data for: Northern Pulp

Client: Northern Pulp
Job Number: 121413456

Plant: Dissolving Tank
Location: Pictou, NS
Test: PM-1
Date: 21-Jul-15
Personnel: JJB/FS

Test Start: [REDACTED]
Test Finish: [REDACTED]

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
0	20.9	0.0	0.0	0.0	0.0
5	20.9	0.0	0.0	0.0	0.0
10	20.9	0.0	0.0	0.0	0.0
15	20.9	0.0	0.0	0.0	0.0
20	20.9	0.0	0.0	0.0	0.0
25	20.9	0.0	0.0	0.0	0.0
30	20.9	0.0	0.0	0.0	0.0
Average:	20.9	0.0	0.0	0.0	0.0

Raw Data for: Northern Pulp Dissolving Tank PM
Test #2

Client: Northern Pulp
Job Number: 121413456

Plant: Dissolving Tank
Location: Pulp, NS
Test: PM-2
Date: 22-Jul-13
Personnel: JJB FS
Test Start: 12:41 PM
Test Finish: 2:25 PM

Particulate Collected from Filter (mg): 576.2
Particulate Collected from Probe Wash (mg): 194.3
Particulate Collected from Impinger Wash (mg): 21.8
Total Particulate Collected (mg): 792.3

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H2O	819.7	733.9	213.8
2	100 mL H2O	736.8	728.7	7.9
3	Blank	885.8	884.3	1.6
4	200g Sacca Gel Blank	964.4	957.4	7.0
5		1087.8	855.1	411.7
		Total Weight Gain (g)		642.0
		Moisture Volume (mL)		642.0

Parameters
Barometric Pressure, Pbar (in. Hg): 29.80
Stack Static Pressure, Pstatic (in. H2O): -0.20
Ambient Temp, (°F): 59
H2O Volume Collected, Vw (mL): 642.0
Total # Sampling Points: 20
Sampling Time per Point, (min): 20
Readings Taken Every: 5 mins
Regulatory Agency: NS/ENV

Parameter	Value	Parameter	Value
O2, (%)	20.9	Stack Diameter, (in.)	48
CO2, (%)	0.0	Stack Area, (sq. ft.)	12.57
H2, (%)	79.1	Probe Length, (ft.)	5
CO (ppm)	0.0	Nozzle Diameter, (in.)	0.305
NOx (ppm)	0.0	Pitot Coefficient, (Cp)	0.836
SO2 (ppm)	0.0	Orifice, meter constant	1.117
		Port length, (in.)	6

Traverse	Point	Time (min)	Stack Gas Temp, Ts (°F)	S-type Pitot delta P (in. H2O)	Orifice delta H (in. H2O)	Gas Meter Volume (cu. ft.)	Gas Meter Temp (°F)	
							Inlet	Outlet
Traverse 1	1	2.5	183	0.15	0.31	776.990	61	63
	2	5	182	0.15	0.30	772.730	61	63
	3	10	183	0.17	0.34	779.190	63	63
	4	12.5	187	0.17	0.34	779.870	63	63
	5	15	188	0.12	0.24	780.670	63	63
	6	17.5	177	0.12	0.23	781.330	61	61
	7	20	185	0.16	0.32	782.030	66	66
	8	22.5	185	0.12	0.24	782.790	66	66
	9	25	183	0.12	0.24	783.470	66	66
	10	27.5	185	0.12	0.24	784.130	66	66
Traverse 2	1	30	183	0.12	0.24	784.770	67	66
	2	32.5	186	0.10	0.20	785.380	67	66
	3	35	172	0.10	0.20	786.030	67	66
	4	37.5	182	0.10	0.20	787.210	67	66
	5	40	183	0.10	0.20	787.790	67	66
	6	42.5	182	0.11	0.22	788.400	67	66
	7	45	184	0.10	0.20	789.010	68	66
	8	47.5	179	0.12	0.24	789.630	67	66
	9	50	177	0.12	0.24	790.280	67	66
	10	52.5	181	0.12	0.24	790.930	68	67
Traverse 3	1	55	179	0.12	0.24	791.550	68	67
	2	57.5	179	0.12	0.24	792.180	68	67
	3	60	179	0.12	0.24	792.810	68	67
	4	62.5	180	0.13	0.27	793.390	68	67
	5	65	178	0.13	0.27	794.170	68	67
	6	67.5	179	0.13	0.27	794.840	68	67
	7	70	183	0.13	0.27	795.690	68	68
	8	72.5	182	0.13	0.27	796.170	68	68
	9	75	180	0.11	0.23	796.840	68	68
	10	77.5	189	0.11	0.23	797.460	68	68
Traverse 4	1	80	180	0.11	0.23	798.110	68	68
	2	82.5	180	0.11	0.23	798.740	68	68
	3	85	180	0.11	0.23	799.360	68	68
	4	87.5	179	0.10	0.21	799.970	68	68
	5	90	180	0.10	0.21	800.580	68	68
	6	92.5	181	0.10	0.21	801.190	68	68
	7	95	183	0.10	0.21	801.800	68	68
	8	97.5	172	0.13	0.27	802.300	68	68
	9	100	170	0.13	0.27	802.970	68	68

Calculations for: Northern Pulp Dissolving Tank #14
Test #2

Client: Northern Pulp
Job Number: 121613400

Plant: Dissolving Tank
Location: Pictou, NS
Test: PM-2
Date: 22-Jul-15
Personnel: JJB/PB

Calculated Parameters

Stack Gas Pressure, P_s (in Hg) 29.79
Stack Gas Molecular Weight, Dry Basis, M_d (lb/lb-mole) 29.84
Volume of Water Vapour Collected, V_{wc} (cu ft) 20.818
Stack Gas Moisture Content (% as decimat) 0.818
Stack Gas Molecular Weight, Wet Basis, M_w (lb/lb-mole) 23.22

Isokineticity Checks

Check range Within Criteria
Check average Within Criteria

Transverse Point	Time (min)	Stack Gas Temp, T _s (R)	S-type Pitot, delta P (in H ₂ O)	Orifice delta H (in H ₂ O)	Stack Gas Velocity, U _s (ft/s)	Meter Press. P _m (in Hg)	Avg. Temp. T _m (R)	Gas Meter Volume, V _m (cu ft.)	Vol. @ Ref. V _{wc} (cu ft.)	Isokinetics (%)
Transverse 1										
1	3.5	643	0.19	0.31	28.84	29.82	545	0.740	0.812	99.38
2	7.5	648	0.19	0.30	28.74	29.82	545	0.720	0.807	98.41
3	12.5	647	0.17	0.34	28.41	29.83	545	0.730	0.801	98.24
4	15	646	0.12	0.24	28.45	29.83	545	0.780	0.866	98.71
5	17.5	637	0.12	0.25	23.92	29.82	545	0.700	0.788	105.49
6	20	637	0.18	0.33	27.38	29.82	545	0.820	0.713	87.12
7	22.5	645	0.18	0.32	27.98	29.82	548	0.720	0.800	94.39
8	25	643	0.12	0.24	23.87	29.82	548	0.740	0.811	98.28
9	27.5	645	0.12	0.24	23.87	29.82	548	0.680	0.744	102.05
10	30	645	0.12	0.24	23.87	29.82	547	0.680	0.723	98.35
11	32.5	646	0.10	0.20	21.80	29.81	547	0.640	0.700	95.96
12	35	635	0.10	0.20	21.82	29.81	547	0.810	0.687	81.46
13	37.5	642	0.10	0.20	21.74	29.81	547	0.640	0.700	103.19
14	40	643	0.10	0.20	21.75	29.81	547	0.580	0.634	96.40
15	42.5	642	0.11	0.22	22.80	29.82	547	0.580	0.634	95.11
16	45	644	0.10	0.20	21.77	29.81	547	0.810	0.687	85.30
17	47.5	639	0.12	0.24	23.75	29.82	547	0.810	0.687	100.01
18	50	637	0.12	0.24	23.72	29.82	547	0.840	0.700	95.51
19								0.630	0.689	93.67
Transverse 2										
1	52.5	641	0.12	0.24	23.79	29.82	548	0.640	0.688	95.49
2	55	640	0.12	0.24	23.77	29.82	548	0.630	0.688	93.82
3	57.5	635	0.12	0.24	23.88	29.82	548	0.630	0.688	93.95
4	60	636	0.12	0.24	23.79	29.82	548	0.630	0.688	93.84
5	62.5	640	0.13	0.27	24.74	29.82	548	0.630	0.688	93.84
6	65	638	0.13	0.27	24.70	29.82	548	0.690	0.753	98.84
7	67.5	638	0.13	0.27	24.72	29.82	548	0.670	0.732	95.82
8	70	643	0.13	0.27	24.78	29.82	548	0.670	0.732	95.80
9	72.5	642	0.13	0.27	24.80	29.82	548	0.650	0.709	93.24
10	75	640	0.11	0.23	22.78	29.82	548	0.680	0.742	87.45
11	77.5	629	0.11	0.23	22.78	29.82	548	0.650	0.731	104.23
12	80	640	0.11	0.23	22.78	29.82	548	0.650	0.731	100.25
13	82.5	640	0.11	0.23	22.78	29.82	548	0.620	0.678	96.45
14	85	640	0.11	0.23	22.78	29.82	548	0.630	0.687	98.01
15	87.5	636	0.10	0.21	21.88	29.82	548	0.620	0.678	96.48
16	90	640	0.10	0.21	21.70	29.82	548	0.610	0.685	98.44
17	92.5	641	0.10	0.21	21.72	29.82	548	0.610	0.685	99.52
18	95	643	0.10	0.21	21.75	29.82	548	0.600	0.654	97.87
19	97.5	632	0.13	0.27	24.98	29.82	548	0.620	0.678	101.35
20	100	630	0.13	0.27	24.95	29.82	548	0.700	0.784	99.55
21								0.670	0.731	95.13
Total	100	Average 641	Average 0.12	Average 0.25	Average 23.88	Average 29.82	Average 547	Total 28.180	Total 28.620	Average 97.41

Combustion Gas Data for: Northern Pulp

Client: Northern Pulp
Job Number: 121413456

Plant: Dissolving Tank
Location: Pictou, NS
Test: PM-2
Date: 22-Jul-15
Personnel: JJB/FS

Test Start: 1:00 PM
Test Finish: 1:30 PM

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
0	20.9	0.0	0.0	0.0	0.0
5	20.9	0.0	0.0	0.0	0.0
10	20.9	0.0	0.0	0.0	0.0
15	20.9	0.0	0.0	0.0	0.0
20	20.9	0.0	0.0	0.0	0.0
25	20.9	0.0	0.0	0.0	0.0
30	20.9	0.0	0.0	0.0	0.0
Average:	20.9	0.0	0.0	0.0	0.0

Raw Data for: Northern Pulp Dissolving Tank PM
Test #3

Client: Northern Pulp
Job Number: 121413486

Plant: Dissolving Tank
Location: POTOSI, NJ
Test: PM-1
Date: 21-Jul-13
Personnel: JJB TS
Test Start: 3:13 PM
Test Finish: 3:40 PM

Particulate Collected from Filter (mg): 372.4
Particulate Collected from Probe Wash (mg): 100.9
Particulate Collected from Impinger Wash (mg): 13.7
Total Particulate Collected (mg): 547.0

Impinger No.	Impinger Contents	Final Weight (g)	Tare Weight (g)	Weight of Moisture (g)
1	100 mL H2O	881.0	733.0	188.0
2	100 mL H2O	740.0	733.5	6.5
3	Blank	525.0	524.1	0.9
4	200g Silica Gel Blank	881.1	973.5	5.6
5		1084.8	933.4	409.2
		Total Weight Gain (g)		810.2
		Moisture Volume (mL)		610.2

Parameters

Barometric Pressure, Pbar (in. Hg) 29.30
Stack Static Pressure, Pstatic (in. H2O) -6.30
Ambient Temp. (°F) 61.80
H2O Volume Collected, Vc (mL) 610.20
Total # Sampling Points, 20
Sampling Time per Point, (min) 5
Readings Taken Every _____ mins 2.5
Regulatory Agency NIE/NEV

Parameter	Value
O2 (%)	20.9
CO2 (%)	0.0
NOx (%)	79.1
CO (ppm)	0.0
NOx (ppm)	0.0
SO2 (ppm)	0.0

Stack Diameter, (in.) 48
Stack Area, (sq. ft.) 12.57
Probe Length, (ft.) 5
Nozzle Diameter, (in.) 0.306
Pitot Coefficient, (Cp) 0.839
Orifice meter constant 1.117
Port length (in.) 0

Traverse Point	Time (min)	Stack Gas Temp. Ts (°F)	S-type Pitot delta P (in. H2O)	Orifice delta H (in. H2O)	Gas Meter Volume (cu. ft.)	Gas Meter Temp (°F)	
						Inlet	Outlet
Traverse 1	1	3.5	170	0.18	303.660	86	86
	2	5	169	0.18	304.250	86	86
	3	7.5	170	0.19	303.440	86	86
	4	12.5	171	0.19	306.030	86	86
	5	15	168	0.12	306.670	86	86
	6	17.5	170	0.12	307.320	86	86
	7	20	171	0.13	308.960	87	86
	8	22.5	170	0.13	308.670	87	87
	9	25	171	0.13	309.350	87	87
	10	27.5	171	0.13	310.040	87	87
Traverse 2	1	32.5	172	0.13	310.720	87	87
	2	35	170	0.13	311.420	87	87
	3	37.5	170	0.13	312.110	87	87
	4	40	170	0.13	312.800	87	87
	5	42.5	171	0.15	313.540	88	87
	6	45	172	0.15	314.290	88	87
	7	47.5	171	0.15	315.040	88	87
	8	50	172	0.15	315.780	88	87
	9		172	0.13	316.520	88	87
	10		172	0.13	317.240	88	87
Traverse 2	1	52.5	173	0.13	317.960	88	87
	2	55	173	0.13	318.660	88	87
	3	57.5	171	0.13	319.345	88	88
	4	60	171	0.13	320.050	89	88
	5	62.5	172	0.14	320.760	89	88
	6	65	172	0.14	321.470	89	88
	7	67.5	172	0.14	322.170	89	88
	8	70	172	0.13	322.930	89	88
	9	72.5	171	0.13	323.680	89	88
	10	75	171	0.15	324.420	89	88
Traverse 2	1	77.5	172	0.15	325.140	89	88
	2	80	177	0.15	325.910	89	88
	3	82.5	178	0.15	326.640	89	88
	4	85	172	0.15	327.370	89	88
	5	87.5	173	0.15	328.080	89	89
	6	90	176	0.15	328.790	89	89
	7	92.5	173	0.13	329.480	89	89
	8	95	174	0.13	330.160	89	89
	9	97.5	174	0.13	330.870	89	89
	10	100	174	0.13	331.670	89	89

Calculations for: Northern Pub Dewatering Tank PM
Test #3

Client: Northern Pub
Job Number: 121413466

Plant: Dewatering Tank
Location: Picton, NS
Test: PM-3
Date: 22-Jul-15
Personnel: JJB,FB

Calculated Parameters

Stack Gas Pressure, Ps (in.Hg)
Stack Gas Molecular Weight, Dry Basis, Md (lb/lb-mole)
Volume of Water Vapour Collected, Vwc (cu.ft)
Stack Gas Moisture Content (% as decima)
Stack Gas Molecular Weight, Wet Basis, Mw (lb/lb-mole)

29.49
29.84
29.290
0.422
23.51

Isokineticity Checks

Check range Within Criteria
Check average Within Criteria

Traverse Point	Time (min)	Stack Gas Temp, Tg (R)	S-type Pitot, delta P (in. H2O)	Orifice delta H (in. H2O)	Stack Gas Velocity, Ua (ft/s)	Motor Press., Pm (in. Hg)	Avg. Temp, Tm (R)	Gas Meter Volume, Vm (cu. ft.)	Vol. @ Ref. Vm (cu. ft.)	Isokineticity I (%)
Traverse 1	1	2.5	630	0.10	21.31	29.52	548	0.600	0.650	92.47
	2	7.5	629	0.10	21.42	29.52	548	0.580	0.639	90.86
		10	630	0.10	21.51	29.52	548	0.590	0.639	90.93
	3	12.5	631	0.12	21.51	29.52	546	0.590	0.639	90.93
		15	628	0.12	21.51	29.52	546	0.640	0.694	90.12
	4	17.5	630	0.12	21.51	29.52	546	0.630	0.680	91.31
		20	631	0.13	21.51	29.52	547	0.660	0.715	92.76
	5	22.5	630	0.13	21.51	29.52	547	0.660	0.747	93.27
		25	631	0.13	21.51	29.52	547	0.680	0.738	91.76
	6	27.5	631	0.13	21.51	29.52	547	0.690	0.747	93.19
30		630	0.13	21.51	29.52	547	0.680	0.736	91.84	
7	32.5	630	0.13	21.51	29.52	547	0.700	0.757	94.46	
	35	630	0.13	21.51	29.52	547	0.690	0.747	93.11	
8	37.5	632	0.15	21.51	29.52	547	0.690	0.747	93.11	
	40	631	0.15	21.51	29.52	548	0.740	0.800	93.04	
9	42.5	631	0.15	21.51	29.52	548	0.750	0.811	94.22	
	45	632	0.15	21.51	29.52	548	0.750	0.811	94.22	
10	47.5	632	0.15	21.51	29.52	548	0.740	0.800	93.04	
	50	632	0.13	21.51	29.52	548	0.720	0.778	97.23	
Traverse 2	1	52.5	633	0.13	24.58	29.50	548	0.720	0.778	97.24
	2	55	633	0.13	24.58	29.52	548	0.700	0.757	94.60
		57.5	632	0.13	24.58	29.52	548	0.683	0.740	92.42
	3	60	631	0.13	24.58	29.52	548	0.708	0.781	94.95
		62.5	632	0.14	24.58	29.52	548	0.710	0.766	92.22
	4	65	633	0.14	24.58	29.52	548	0.710	0.766	92.22
		67.5	632	0.15	24.58	29.52	548	0.700	0.755	91.00
	5	70	631	0.15	24.58	29.52	548	0.780	0.820	95.37
		72.5	631	0.15	24.58	29.52	548	0.750	0.809	94.05
	6	75	631	0.15	24.58	29.52	548	0.740	0.799	92.79
77.5		635	0.15	24.58	29.52	548	0.740	0.799	92.79	
7	80	637	0.15	24.58	29.52	548	0.750	0.809	94.49	
	82.5	638	0.15	24.58	29.52	548	0.750	0.768	91.97	
8	85	638	0.15	24.58	29.52	548	0.730	0.768	91.97	
	87.5	635	0.15	24.58	29.52	548	0.730	0.768	92.05	
9	90	636	0.15	24.58	29.52	548	0.720	0.778	90.48	
	92.5	634	0.13	24.58	29.52	548	0.730	0.787	91.82	
10	95	633	0.13	24.58	29.52	550	0.730	0.786	90.38	
	97.5	634	0.13	24.58	29.52	550	0.710	0.765	95.60	
10	100	634	0.13	24.58	29.52	550	0.710	0.765	95.68	
	100	634	0.13	24.58	29.52	550	0.700	0.754	94.33	
Total	100	Average	Average	Average	Average	Average	Total	Total	Average	
		632	0.13	0.29	24.90	29.52	548	28.010	30.263	93.24

Combustion Gas Data for: Northern Pulp

Client: Northern Pulp
Job Number: 121413459

Plant: Dissolving Tank
Location: Pictou, NS
Test: PM-3
Date: 22-Jul-15
Personnel: JJB/FS

Test Start: 4:00 PM
Test Finish: 4:30 PM

Time (min)	O2 (%)	CO2 (%)	CO (ppm)	SO2 (ppm)	NOx (ppm)
0	20.9	0.0	0.0	0.0	0.0
5	20.9	0.0	0.0	0.0	0.0
10	20.9	0.0	0.0	0.0	0.0
15	20.9	0.0	0.0	0.0	0.0
20	20.9	0.0	0.0	0.0	0.0
25	20.9	0.0	0.0	0.0	0.0
30	20.9	0.0	0.0	0.0	0.0
Average:	20.9	0.0	0.0	0.0	0.0

DATA ENTRY

Northern Pulp

Pictou, NS

Fuel: NA

Operating Conditions: normal

Emission Control Equipment: NA

Stack Height from Grade: 51 m

Stack Diameter: 1.22 m

Reference Temperature, Tref (F): 77
 (K): 298
 Reference Pressure, Pref (in.Hg): 29.92
 (Bar): 1.0

Parameter	Symbol	Units	Test 1	Test 2	Test 3	Average
Test ID	-	-	PM-1	PM-2	PM-3	-
Date	-	-	21-Jul-15	22-Jul-15	22-Jul-15	n/a
Start Time	-	-	9:00 AM	12:45 PM	3:55 PM	n/a
End Time	-	-	10:50 AM	2:25 PM	5:40 PM	n/a
Total Sampling Time	-	min	100	100	100	100
Stack Diameter	D	in.	48	48	48	48
Average Stack Gas Temperature	Ts	F	170	181	172	174
Average Dry Gas Meter Temperature	Tm	F	88	87	88	88
Barometric Pressure	Pbar	in.Hg	29.70	29.80	29.50	29.67
Stack Static Pressure	Pstatic	in.H2O	-0.20	-0.20	-0.20	-0.20
Average Pressure Drop (Head)	dP	in.H2O	0.19	0.12	0.13	0.15
Average deltaH Orifice	dH	in.H2O	0.37	0.25	0.28	0.30
Average Meter Temperature	Tm	F	88	87	88	88
Gas Sample Volume	Vm	cu.ft	30.02	26.18	28.01	28.07
Average Isokinetics	I	%	91.11	97.41	93.24	93.92
Nozzle Diameter	Dn	in.	0.306	0.306	0.306	0.306
Pitot Coefficient	Cp	-	0.836	0.836	0.836	0.836
Gamma, meter constant	y	-	1.117	1.117	1.117	1.117
Reference Temperature	Tref	R	537	537	537	537
Reference Pressure	Pref	in.Hg	29.92	29.92	29.92	29.92
Stack Gas Oxygen Content	Co2	%	20.9	20.9	20.9	20.9
Stack Gas Carbon Dioxide Content	Cco2	%	0.0	0.0	0.0	0.0
Stack Gas Nitrogen Content	Cn2	%	79.1	79.1	79.1	79.1
Stack Gas Sulphur Dioxide Content	Cso2	ppm	0.0	0.0	0.0	0.0
Stack Gas Nitrogen Oxides Content	Cnox	ppm	0.0	0.0	0.0	0.0
Stack Gas Carbon Monoxide Content	Cco	ppm	0.0	0.0	0.0	0.0
Volume of Water Collected	Vw	mL	694.8	642.0	610.2	649.0
Particulate Collected from Filter	-	mg	391.9	576.2	372.4	446.8
Particulate Collected from Probe Wash	-	mg	46.4	194.3	160.9	133.8
Particulate Collected from Impinger Wash	-	mg	29.4	21.8	13.7	21.7
Total Particulate Collected (excluding impingers)	Mp	mg	438.3	770.4	533.2	580.6
Pulp production	-	adubmt/day	596	701	701	666.0

Legend: F - degrees Fahrenheit
 K - degrees Kelvin
 Bar - bars
 in Hg - inches of mercury
 in. - inches

in H2O - inches of water
 cu ft - cubic feet
 R - degrees Rankin
 NOx - as NO2

CALCULATIONS
 Northern Pulp
 Pictou, NS
 Fuel NA
 Operating Conditions: normal
 Emission Control Equipment: NA
 Stack Height from Grade: 51 m
 Stack Diameter: 1.22 m

Variable	Symbol	Units	Calculation	Test 1	Test 2	Test 3	Average
Stack Area	A _s	sq ft sq m	$A_s = P \times ((D/12)^2 \times \pi) / 4$ $A_s (sq m) = A_s (sq ft) \times 0.0929$	12.57 1.17	12.57 1.17	12.57 1.17	12.57 1.17
Barometric Pressure	P _{bar}	hPa	P _{bar} (hPa) = P _{bar} (in. Hg) × 3.386	100.6	100.9	99.9	100.5
Stack Static Pressure	P _{static}	hPa	P _{static} (hPa) = P _{static} (in. H ₂ O) × 0.249	-0.05	-0.05	-0.05	-0.05
Avg. Stack Temperature	T _s	R	T _s (R) = T _s (F) + 460	830	841	832	834
Avg. Meter Temperature	T _m	R	T _m (R) = T _m (F) + 460	548	547	548	547.5
Nozzle Diameter	D _n	mm	D _n (mm) = D _n (in.) × 25.4	8	8	8	7.6
Gas Meter Pressure	P _m	in. Hg	P _m = P _{bar} + (dH) / 13.6	29.73	29.82	29.52	29.69
Sample Volume at Ref Cond	V _{sc}	cu. ft cu. m	$V_{sc} = T_{ref} P_{ref} \times (V_m \times P_m \times T_s) / T_m$ $V_{sc} (cu. m) = 0.02832 \times V_{sc} (cu. ft)$	32.65 0.92	28.82 0.81	30.27 0.86	30.5 0.86
Volume of Water Vapour	V _w	cu. ft	$V_w = 0.0480 \times V_{sc}$	33.35	30.82	29.29	31.15
Water Fraction	B _w	-	$B_w = V_w / (V_{sc} + V_w)$	0.505	0.518	0.492	0.5
Molecular Weight, Dry	M _d	lb/lb-mol	M _d = 0.44 (C _{co2}) + 0.32 (O ₂) + 0.28 (N ₂)	28.84	28.84	28.84	28.8
Molecular Weight, Wet	M _w	lb/lb-mol	M _w = M _d (1 - B _w) + (18 × B _w)	23.36	23.22	23.51	23.4
Stack Pressure	P _s	in. Hg	P _s = P _{bar} + (P _{static}) / 13.6	29.69	29.79	29.49	29.65
Stack Gas Velocity	V _s	ft/s m/s	$V_s = 85.33 \times C_p \times ((dP \times T_s) / (P_s \times V_{sc}))^{0.5}$ $V_s (m/s) = 0.3048 \times V_s (ft/s)$	27.97 8.53	23.89 7.28	24.90 7.59	25.6 7.6
Actual Stack Gas Flow Rate	Q	scfm	Q = 60 × V _s × A _s	21,089	18,012	18,772	19,291
Dry Stack Gas Flow Rate	Q _d	Rcfm Rcfm	$Q_d = Q \times (1 - B_w) \times (T_{ref} T_s) / (P_w P_{ref})$ $Q_d (Rcfm) = 0.00472 \times Q \times (Rcfm)$	8,823 4.16	7,238 3.42	7,987 3.77	8,015 3.6
Sulphur Dioxide - SO ₂	C _{so2}	ppm	Measurement from Flow Gas Analyser	0.00	0.00	0.00	0.00
SO ₂ Measured Concentration	C _{so2}	mg/Rcm	C _{so2} (mg/Rcm) = C _{so2} (ppm) × 2.62	0.00	0.00	0.00	0.00
Uncorrected @ Ref Cond	ER _{so2}	g/s	ER _{so2} = C _{so2} / 1000 × Q _d	0.00	0.00	0.00	0.00
SO ₂ Emission Rate	ER _{so2}	kg/hr	ER _{so2} (kg/hr) = 3.6 × ER _{so2} (g/s)	0.00	0.00	0.00	0.00
SO ₂ Concentration	C _{so2}	mg/Rcm	C _{so2} (11% O ₂) = C _{so2} (mg/Rcm) × (20.9/11) / (20.9-C _{co2})	#DIV/0!	#DIV/0!	0.00	#DIV/0!
Corrected to 11% O ₂	C _{so2}	mg/Rcm	C _{so2} (3% O ₂) = C _{so2} (mg/Rcm) × (20.9/3) / (20.9-C _{co2})	#DIV/0!	#DIV/0!	0.00	#DIV/0!
Corrected to 3% O ₂	C _{so2}	mg/Rcm	C _{so2} (12% CO ₂) = C _{so2} (mg/Rcm) × (12/C _{co2})	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!
Corrected to 12% CO ₂	C _{so2}	mg/Rcm					
Nitrogen Oxides - NO _x	C _{nox}	ppm	Measurement from Flow Gas Analyser	0.00	0.00	0.00	0.00
NO _x Measured Concentration	C _{nox}	mg/Rcm	C _{nox} (mg/Rcm) = C _{nox} (ppm) × 1.682	0.00	0.00	0.00	0.00
Uncorrected @ Ref Cond	ER _{nox}	g/s	ER _{nox} = C _{nox} / 1000 × Q _d	0.00	0.00	0.00	0.00
NO _x Emission Rate	ER _{nox}	kg/hr	ER _{nox} (kg/hr) = 3.6 × ER _{nox} (g/s)	0.00	0.00	0.00	0.00
NO _x Concentration	C _{nox}	mg/Rcm	C _{nox} (11% O ₂) = C _{nox} (mg/Rcm) × (20.9/11) / (20.9-C _{co2})	0.00	0.00	0.00	0.00
Corrected to 11% O ₂	C _{nox}	mg/Rcm	C _{nox} (3% O ₂) = C _{nox} (mg/Rcm) × (20.9/3) / (20.9-C _{co2})	0.00	0.00	0.00	0.00
Corrected to 3% O ₂	C _{nox}	mg/Rcm	C _{nox} (12% CO ₂) = C _{nox} (mg/Rcm) × (12/C _{co2})	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!
Corrected to 12% CO ₂	C _{nox}	mg/Rcm					
Carbon Monoxide - CO	C _{co}	ppm	Measurement from Flow Gas Analyser	0.00	0.00	0.00	0.00
CO Measured Concentration	C _{co}	mg/Rcm	C _{co} (mg/Rcm) = C _{co} (ppm) × 1.145	0.00	0.00	0.00	0.00
Uncorrected @ Ref Cond	ER _{co}	g/s	ER _{co} = C _{co} / 1000 × Q _d	0.00	0.00	0.00	0.00
CO Emission Rate	ER _{co}	kg/hr	ER _{co} (kg/hr) = 3.6 × ER _{co} (g/s)	0.00	0.00	0.00	0.00
CO Concentration	C _{co}	mg/Rcm	C _{co} (11% O ₂) = C _{co} (mg/Rcm) × (20.9/11) / (20.9-C _{co2})	0.00	0.00	0.00	0.00
Corrected to 11% O ₂	C _{co}	mg/Rcm	C _{co} (3% O ₂) = C _{co} (mg/Rcm) × (20.9/3) / (20.9-C _{co2})	0.00	0.00	0.00	0.00
Corrected to 3% O ₂	C _{co}	mg/Rcm	C _{co} (12% CO ₂) = C _{co} (mg/Rcm) × (12/C _{co2})	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!
Corrected to 12% CO ₂	C _{co}	mg/Rcm					
Particulate Concentration	C _p	mg/Rcm	C _p = M _p / V _{sc}	473.99	950.60	822.10	682.23
Particulate Emission Rate	ER _p	g/s kg/hr	ER _p = C _p / 1000 × Q _d ER _p (kg/hr) = 3.6 × ER _p (g/s)	1.97 7.11 0.29	3.25 11.88 0.40	2.35 8.44 0.29	2.52 9.08 0.33
Particulate Concentration	C _p	mg/Rcm	C _p (11% O ₂) = C _p × (20.9/11) / (20.9-C _{co2})	#####	#####	#####	#####
Corrected to 11% O ₂	C _p	mg/Rcm	C _p (3% O ₂) = C _p × (20.9/3) / (20.9-C _{co2})	#####	#####	#####	#####
Corrected to 3% O ₂	C _p	mg/Rcm	C _p (12% CO ₂) = C _p × (12/C _{co2})	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!
Corrected to 12% CO ₂	C _p	mg/Rcm					

sq ft - square feet
 sq m - square metres
 P - 1.142
 R - degrees Rankin
 ppm - parts per million

in Hg - inches of mercury
 cu ft - cubic feet
 cu m - cubic metres
 Ref Cond - reference temperature and pressure (25 C and 101.3 kPa)
 Rcfm - dry reference cubic metres per second
 Rcfm - dry reference cubic feet per minute

mg/Rcm - milligrams per dry reference cubic metre
 g/s - grams per second
 NO_x - as NO₂
 scfm - actual cubic feet per minute

OFFICIAL STACK TESTING RESULTS

Northern Pulp

Pictou, NS

Fuel: NA

Operating Conditions: normal

Emission Control Equipment: NA

Stack Height from Grade: 51 m

Stack Diameter: 1.22 m

Parameter	Test 1	Test 2	Test 3	Average	NSENV Limits
Test ID	PM-1	PM-2	PM-3	-	-
Test Date	21-Jul-15	22-Jul-15	22-Jul-15	-	-
Stack Gas Temperature (C)	77	83	78	79	-
Moisture Content (%)	50.5	51.8	49.2	50.5	-
Velocity (m/s)	8.53	7.28	7.59	7.80	-
Volumetric Flow (Rcms)	4.16	3.42	3.77	3.78	-
Oxygen - O2 (%)	20.9	20.9	20.9	20.9	-
Carbon Dioxide - CO2 (%)	0.0	0.0	0.0	0.0	-
Sulphur Dioxide - SO2					
SO2 Measured Concentration (ppm)	0.0	0.0	0.0	0.0	-
Uncorrected at Ref Cond (mg/Rcm)	0.0	0.0	0.0	0.0	-
Emission Rate (kg/hr)	0.00	0.00	0.00	0.00	-
Nitrogen Oxides - NOx					
NOx Measured Concentration (ppm)	0.0	0.0	0.0	0.0	-
Uncorrected at Ref Cond (mg/Rcm)	0.0	0.0	0.0	0.0	-
Emission Rate (kg/hr)	0.00	0.00	0.00	0.00	-
Carbon Monoxide - CO					
CO Measured Concentration (ppm)	0.0	0.0	0.0	0.0	-
Uncorrected at Ref Cond (mg/Rcm)	0.0	0.0	0.0	0.0	-
Emission Rate (kg/hr)	0.00	0.00	0.00	0.00	-
Particulate Matter - PM					
Particulate Concentration (mg/Rcm)	474.0	950.6	622.1	682.2	-
Particulate Emission Rate (kg/hr)	7.11	11.69	8.44	9.08	-
Particulate Emission Rate (kg/adubmt)	0.29	0.40	0.29	0.33	0.5

Legend: C - degrees Celsius
m/s - metres per second
Rcms - dry reference cubic metres per second
ppm - parts per million

Ref Cond - reference temperature and pressure (25 C and 101.3 kPa)
mg/Rcm - milligrams per dry reference cubic metre
NOx - as NO2
ND - non-detectable

Particulate Recoveries: Highgate Catch, Probe Wash, Filter Catch

Client: Highgate P.A.
 Facility: Deereberg Term
 Location: Phase 1B
 Job Number: 17151268

IMPACTER CATCH

Container ID	Soother Pro Weights (g)				Sample ID	Recoveries					Soother Prod Weights (g)				Unrecovered Particulate Weight (g)	Corrected Particulate Weight (g)
	Date					Jar #	Jar Type	Sample Collected (g)	Rinse Water (g)	Total Rinse Water (g)	Date					
	Analysed by	Analysed by	Analysed by	Average							Analysed by	Analysed by	Analysed by	Average		
01	111.9817	111.9817		111.9816	PM 1	100.3	304.2	554.9	0.1	72.4	111.9816	111.9816		111.9815	0.0321	0.0264
02	109.8993	109.8993		109.8992	PM 2	11.39.5	303.4	442.9	8.5	112.0	109.8993	109.8993		109.8992	0.0241	0.0217
03	109.0229	109.0229		109.0228	PM 3	1197.2	381.8	610.2	8.8	118.8	109.0229	109.0229		109.0228	0.0181	0.0117
1*	179.1979	179.1979		179.1977	VVR	484.2	384.0	587.2		108.1684	179.1979	179.1979		179.1977	0.0000	0.0000

PROBE WASH




Container ID	Soother Pro Weights (g)				Sample ID	Recoveries					Soother Prod Weights (g)				Unrecovered Particulate Weight (g)	Corrected Particulate Weight (g)
	Date					Jar #	Jar Type	Recovered Acetone (g)	Rinse Acetone (g)	Total Acetone (g)	Date					
	Analysed by	Analysed by	Analysed by	Average							Analysed by	Analysed by	Analysed by	Average		
A6	107.9077	107.9077		107.9076	PM 1	492.2	387.8	68.8	115.5	99.8	107.9077	107.9077		107.9076	0.0484	0.2484
A3	109.2345	109.2345		109.2341	PM 2	441.3	392.0	48.8	38.4	38.4	109.2345	109.2345		109.2341	0.0411	0.1643
A7	111.9919	111.9919		111.9918	PM 3	444.4	391.9	53.9	32.2	28.9	111.9919	111.9919		111.9918	0.0000	0.1508
12	111.2489	111.2481		111.2484	PM 1	1019.2	1272.2	88.0		88.0	111.2489	111.2481		111.2484	0.0000	0.0000

PURITY of ACETONE 0.7860 gms

FILTER CATCH

Filter ID	Pro Weights (g)				Sample ID	Prod Weights (g)				Particulate Weight (g)
	Date					Date				
	Analysed by	Analysed by	Analysed by	Average		Analysed by	Analysed by	Analysed by	Average	
07-18-13	0.3179	0.3178		0.3178	PM 1	0.7297	0.1130		0.7297	0.7297
07-18-10	0.2838	0.2831		0.2834	PM 2	0.6287	0.8121		0.6287	0.6287
07-18-16	0.2984	0.2981		0.2982	PM 3	0.6479	0.8814		0.6479	0.6479

Stack Gas Velocity Profiles
Pictou, NS



Project: 121413456
 Test: Power Boiler PM-3
 Date: Aug 13, 2015
 Analyst: TBH

Absolute stack gas pressure (Ps) in in.Hg is:

$$P_s = P_{bar} + \frac{P_{static} \text{ in.H}_2\text{O}}{13.6 \text{ in.H}_2\text{O/in.Hg}}$$

$$P_s = \underline{29.90} + \frac{\underline{0.20}}{13.6}$$

$$P_s = \underline{29.91} \text{ in.Hg}$$

The molecular weight of the stack gas on a dry basis (Md) in lb/lb-mole is:

$$M_d = 0.44 (\%CO_2) + 0.32 (\%O_2) + 0.28 [(\%N_2)]$$

$$M_d = 0.44 \times \underline{4.23} + 0.32 \times \underline{13.23} + 0.28 \left(\underline{0.255} + \frac{\quad}{\quad} \right) + 0.40 \left(\frac{\quad}{\quad} + \frac{\quad}{\quad} \right)$$

$$M_d = \underline{1.8612} + \underline{4.2656} + \underline{23.114} + \underline{\quad}$$

$$M_d = \underline{29.2408} \text{ lb/lb-mole}$$

The volume of water vapour collected at reference conditions (Vwc) in ft³ is:

$$V_{wc} = 0.0480 \text{ ft}^3/\text{mL} \times \text{volume of moisture collected mL.}$$

$$V_{wc} = 0.0480 \times \underline{237.70}$$

$$V_{wc} = \underline{11.41} \text{ ft}^3$$

The average \bar{H} orifice in in.H₂O is:

$$\bar{H} \text{ orifice}_{avg} = \frac{\Sigma \text{H orifice}}{\# \text{ points}}$$

$$\bar{H} \text{ orifice}_{avg} = \frac{32.92}{48}$$

$$\bar{H} \text{ orifice}_{avg} = \underline{0.686} \text{ in.H}_2\text{O}$$

The pressure at the gas meter (P_m) in in.Hg is:

$$P_m = P_{bar} + \frac{\bar{H} \text{ orifice}_{avg} \text{ in.H}_2\text{O}}{13.6 \text{ in.H}_2\text{O/in.Hg}}$$

$$P_m = \underline{29.90} + \frac{0.686}{13.6}$$

$$P_m = \underline{29.90} + \underline{0.05}$$

$$P_m = \underline{29.95} \text{ in.Hg}$$

The temperature of the gas meter (T_m) in °R is:

$$T_m = \frac{\Sigma \text{ meter temp. } ^\circ\text{F}}{\# \text{ points}} + 460$$

$$T_m = \frac{7287}{96} + 460$$

$$T_m = \underline{759} + 460$$

$$T_m = \underline{5359} \text{ } ^\circ\text{R}$$

The total volume of gas metered (V_m) in ft^3 is:

$$V_m = V_f \text{ ft}^3 - V_i \text{ ft}^3$$

$$V_m = \frac{407.48}{1} - \frac{352.66}{1}$$

$$V_m = 54.82 \text{ ft}^3$$

The dry gas volume at reference conditions (V_{mc}) in ft^3 is:

$$V_{mc} = \frac{T_{ref} \text{ } ^\circ\text{R}}{P_{ref} \text{ in.Hg}} \times \frac{P_m \text{ in.Hg} \times V_m \text{ ft}^3 \times \gamma}{T_m \text{ } ^\circ\text{R}}$$

$$V_{mc} = \frac{537}{29.92} \times \frac{29.95 \times 54.82 \times 1.033}{535.91}$$

$$V_{mc} = 56.80 \text{ ft}^3 \times 1 \text{ m}^3 / 35.31 \text{ ft}^3 = 1.61 \text{ m}^3$$

The stack gas moisture content, i.e. the proportion by volume of water vapour in the gas stream (B_{wo}) is:

$$B_{wo} = \frac{V_{wc} \text{ ft}^3}{V_{wc} \text{ ft}^3 + V_{mc} \text{ ft}^3}$$

$$B_{wo} = \frac{11.41}{11.41 + 56.80}$$

$$B_{wo} = \frac{11.41}{68.21}$$

$$B_{wo} = 0.167$$

The Molecular weight of the stack gas on a wet basis (Ms) in lb/lb-mole is:

$$\begin{aligned}
 M_s &= M_d \text{ lb/lb-mole} (1 - B_{wo}) + 18 \text{ lb/lb-mole} \times B_{wo} \\
 M_s &= \underline{29.24} \times (1 - \underline{0.167}) + 18 \times \underline{0.167} \\
 M_s &= \underline{29.24} \times \underline{0.833} + \underline{3.006} \\
 M_s &= \underline{27.33} \text{ lb/lb-mole}
 \end{aligned}$$

The average temperature of the stack (Ts_{avg}) in °R is:

$$\begin{aligned}
 T_{s_{avg}} &= \frac{\sum T_s \text{ } ^\circ\text{F}}{\# \text{ points}} + 460 \\
 T_{s_{avg}} &= \frac{\underline{6498}}{\underline{48}} + 460 \\
 T_{s_{avg}} &= \underline{13538} + 460 \\
 T_{s_{avg}} &= \underline{595.38} \text{ } ^\circ\text{R}
 \end{aligned}$$

The average velocity (Us_{avg}) of the stack in ft/s is:

$$\begin{aligned}
 U_{s_{avg}} &= \frac{\sum V}{\# \text{ points}} \\
 U_{s_{avg}} &= \frac{\underline{3103.43}}{\underline{48}} \\
 U_{s_{avg}} &= \underline{64.65} \text{ ft/s} \times 1 \text{ m} / 3.281 \text{ ft} = \underline{\hspace{2cm}} \text{ m/s}
 \end{aligned}$$

$2-12-2$
 $U_{s1} = 85.33 C_p \sqrt{\frac{\Delta P_1 \cdot T_{s1}}{P_s \cdot M_s}} = \frac{(85.33 \times 2816) \sqrt{1105695}}{\sqrt{29.91 \times 27.33}}$
 $U_{s1} = \underline{80.79} \text{ ft/s} \checkmark$

The cross-sectional area of the stack (A_s) in ft^2 is:

$$A_s = \frac{\pi (D \text{ ft})^2}{4}$$

$$A_s = \frac{\pi}{4} \times \left(\frac{72}{12} \right)^2$$

$$A_s = 0.7854 \times \underline{36}$$

$$A_s = \underline{28.27} \text{ ft}^2$$

The volumetric stack gas flowrate on a dry basis at reference conditions (Q_s) in ft^3/hr is:

$$Q_s = 3600 \text{ s/hr} \times U_s \text{ ft/s} \times A_s \text{ ft}^2 \times (1 - B_{wO}) \times \frac{T_{\text{ref}} \text{ } ^\circ\text{R}}{T_{\text{avg}} \text{ } ^\circ\text{R}} \times \frac{P_s \text{ in.Hg}}{P_{\text{ref}} \text{ in.Hg}}$$

$$Q_s = 3600 \times \underline{64.65} \times \underline{28.27} \times (1 - \underline{0.167}) \times \frac{537}{595.38} \times \frac{29.91}{29.92}$$

$$Q_s = 3600 \times \underline{64.65} \times \underline{28.27} \times \underline{0.833} \times \underline{0.902} \times \underline{0.9997}$$

$$Q_s = \underline{41,942,005} \text{ ft}^3/\text{hr} \times 1 \text{ hr} / 60 \text{ min} = \underline{82,367} \text{ ft}^3/\text{min}$$

$$Q_s = \underline{82,367} \text{ ft}^3/\text{min} \times 1 \text{ m}^3 / 35.31 \text{ ft}^3 \times 1 \text{ min} / 60 \text{ s} = \underline{38.88} \text{ m}^3/\text{s}$$

The total amount of particulate matter collected (Mp) in mg is:

$$M_p = \underline{208.3} \text{ mg}$$

The concentration of the particulate matter in the stack gas on a dry basis at reference conditions (Cp) in lb/ft³ is:

$$C_p = 2.205 \times 10^{-6} \text{ lb/mg} \times \frac{M_p \text{ mg}}{V_{mc} \text{ ft}^3}$$
$$C_p = 2.205 \times 10^{-6} \text{ lb/mg} \times \frac{208.3}{56.80}$$
$$C_p = \underline{8.08 \times 10^{-6}} \text{ lb/ft}^3 \times 453,590 \text{ mg/lb} \times 35.31 \text{ ft}^3/\text{m}^3 = \underline{129.5} \text{ mg/m}^3$$

The emission rate of the particulate matter from the stack on a dry basis at reference conditions (ERp) in lb/hr is:

$$E_{rp} = C_p \text{ lb/ft}^3 \times Q_s \text{ ft}^3/\text{hr}$$
$$E_{rp} = \underline{8.08 \times 10^{-6}} \times \underline{4,942,005}$$
$$E_{rp} = \underline{39.93} \text{ lb/hr} \times 1 \text{ kg}/2.20 \text{ lb} = \underline{18.1} \text{ kg/hr}$$

GAS CALCULATIONS

Client: Northern Pulp
Plant: Lime Kiln
Location: Pictou, NS

	O ₂ (%)	CO ₂ (%)	CO (ppm)	SO ₂ (ppm)	NO _x (ppm)
Gas 1	4.6	22.1	6.9	1.7	116.9
Gas 2	4.6	22.5	6.8	1.7	131.4
Gas 3	4.2	23.0	6.6	1.7	47.9

GAS CALCULATIONS
Northern Pulp
Lime Kiln
Pictou, NS

Variable	Symbol	Units	Calculation	Test 1	Test 2	Test 3	Average
Corresponding PM Test				PM-1	PM-2	PM-3	n/a
Dry Stack Gas Flow Rate	Qs	dscfm dscms	(Entered from PM Test Data) $Qs \text{ (dscms)} = 0.000472 \times Qs \text{ (dscfm)}$	16,190 7.64	15,244 7.20	15,723 7.42	15719.1 7.42
Stack Gas Oxygen Content	Co2	%	Measurement from Flue Gas Analyzer	4.6	4.6	4.2	4.5
Stack Gas Carbon Dioxide Content	Cco2	%	Measurement from Flue Gas Analyzer	22.1	22.5	23.0	22.5
Sulphur Dioxide - SO2							
SO2 Measured Concentration	Cso2	ppm	Measurement from Flue Gas Analyzer	1.7	1.7	1.7	1.67
Uncorrected @ STP	Cso2	mg/dscm	$Cso2 \text{ (mg/dscm)} = Cso2 \text{ (ppm)} \times 2.82$	4.41	4.37	4.37	4.38
SO2 Emission Rate	ERso2	g/s kg/hr	$ERso2 = Cso2/1000 \times Qs$ $ERso2 \text{ (kg/hr)} = 3.6 \times ERso2 \text{ (g/s)}$	0.03 0.12	0.03 0.11	0.03 0.12	0.03 0.12
SO2 Concentration							
Corrected to 11% O2	Cso2	mg/dscm	$Cso2 \text{ (11% O2)} = Cso2 \text{ (mg/dscm)} \times (20.9-11) / (20.9-Co2)$	2.68	2.65	2.58	2.64
Corrected to 3% O2	Cso2	mg/dscm	$Cso2 \text{ (3% O2)} = Cso2 \text{ (mg/dscm)} \times (20.9-3) / (20.9-Co2)$	4.65	4.79	4.67	4.77
Corrected to 12% CO2	Cso2	mg/dscm	$Cso2 \text{ (12% CO2)} = Cso2 \text{ (mg/dscm)} \times (12/Cco2)$	2.39	2.33	2.28	2.33
Nitrogen Oxides - NOx							
NOx Measured Concentration	Cnox	ppm	Measurement from Flue Gas Analyzer	116.9	131.4	47.9	98.71
Uncorrected @ STP	Cnox	mg/dscm	$Cnox \text{ (mg/dscm)} = Cnox \text{ (ppm)} \times 1.842$	219.93	247.35	90.07	185.78
NOx Emission Rate	ERnox	g/s kg/hr	$ERnox = Cnox/1000 \times Qs$ $ERnox \text{ (kg/hr)} = 3.6 \times ERnox \text{ (g/s)}$	1.68 6.05	1.78 6.41	0.67 2.41	1.38 4.95
NOx Concentration							
Corrected to 11% O2	Cnox	mg/dscm	$Cnox \text{ (11% O2)} = Cnox \text{ (mg/dscm)} \times (20.9-11) / (20.9-Co2)$	133.94	150.14	53.29	112.48
Corrected to 3% O2	Cnox	mg/dscm	$Cnox \text{ (3% O2)} = Cnox \text{ (mg/dscm)} \times (20.9-3) / (20.9-Co2)$	242.17	271.47	96.35	203.33
Corrected to 12% CO2	Cnox	mg/dscm	$Cnox \text{ (12% CO2)} = Cnox \text{ (mg/dscm)} \times (12/Cco2)$	119.31	131.72	47.08	99.37
Carbon Monoxide - CO							
CO Measured Concentration	Cco	ppm	Measurement from Flue Gas Analyzer	6.9	6.8	6.6	6.76
Uncorrected @ STP	Cco	mg/dscm	$Cco \text{ (mg/dscm)} = Cco \text{ (ppm)} \times 1.148$	7.94	7.78	7.52	7.74
CO Emission Rate	ERco	g/s kg/hr	$ERco = Cco/1000 \times Qs$ $ERco \text{ (kg/hr)} = 3.6 \times ERco \text{ (g/s)}$	0.06 0.22	0.06 0.20	0.06 0.20	0.06 0.21
CO Concentration							
Corrected to 11% O2	Cco	mg/dscm	$Cco \text{ (11% O2)} = Cco \text{ (mg/dscm)} \times (20.9-11) / (20.9-Co2)$	4.84	4.71	4.45	4.67
Corrected to 3% O2	Cco	mg/dscm	$Cco \text{ (3% O2)} = Cco \text{ (mg/dscm)} \times (20.9-3) / (20.9-Co2)$	8.74	8.52	8.04	8.44
Corrected to 12% CO2	Cco	mg/dscm	$Cco \text{ (12% CO2)} = Cco \text{ (mg/dscm)} \times (12/Cco2)$	4.31	4.13	3.93	4.12

Legend: sq ft - square feet
sq m - square metres
Pi - 3.142
R - degrees Rankin
ppm - parts per million

in Hg - inches of mercury
cu ft - cubic feet
cu m - cubic metres
STP - standard temperature and pressure (25 C and 101.3 kPa)
dscms - dry standard cubic metres per second
dscfm - dry standard cubic feet per minute

mg/dscm - milligrams per dry standard cubic metre
g/s - grams per second
NOx - as NO2
scfm - actual cubic feet per minute

**STACK TESTING RESULTS
GAS CALCULATIONS
Northern Pulp
Lime Kiln
Pictou, NS**

Parameter	Test 1	Test 2	Test 3	Average	Limits
Oxygen - O2 (%)	4.64	4.59	4.17	4.47	-
Carbon Dioxide - CO2 (%)	22.1	22.5	23.0	22.5	-
Sulphur Dioxide - SO2					
SO2 Measured Concentration (ppm)	1.68	1.67	1.67	1.67	-
Uncorrected at STP (mg/dscm)	4.41	4.37	4.37	4.38	-
Emission Rate (kg/hr)	0.12	0.11	0.12	0.12	-
Nitrogen Oxides - NOx					
NOx Measured Concentration (ppm)	117	131	47.9	98.7	-
Uncorrected at STP (mg/dscm)	220	247	90.1	186	-
Emission Rate (kg/hr)	6.05	6.41	2.41	4.95	-
Carbon Monoxide - CO					
CO Measured Concentration (ppm)	6.93	6.78	6.57	6.76	-
Uncorrected at STP (mg/dscm)	7.94	7.76	7.52	7.74	-
Emission Rate (kg/hr)	0.22	0.20	0.20	0.21	-

Legend: C - degrees Celsius
m/s - metres per second
dscms - dry standard cubic metres per second
ppm - parts per million

STP - standard temperature and pressure (25 C and 101.3 kPa)
mg/dscm - milligrams per dry standard cubic metre
NOx - as NO2
ND - non-detectable