

General Disclaimer

One or more of the Following Statements may affect this Document

- This document has been reproduced from the best copy furnished by the organizational source. It is being released in the interest of making available as much information as possible.
- This document may contain data, which exceeds the sheet parameters. It was furnished in this condition by the organizational source and is the best copy available.
- This document may contain tone-on-tone or color graphs, charts and/or pictures, which have been reproduced in black and white.
- This document is paginated as submitted by the original source.
- Portions of this document are not fully legible due to the historical nature of some of the material. However, it is the best reproduction available from the original submission.

N
R+D

A29823

Screening Analysis

DEVELOPMENT OF A SOLAR-POWERED RESIDENTIAL AIR CONDITIONER

Contract NAS8-30758

74-10996(7)

July 25, 1975

(NASA-CR-149974) DEVELOPMENT OF A
SOLAR-POWERED RESIDENTIAL AIR CONDITIONER:
SCREENING ANALYSIS (AiResearch Mfg. Co., Los
Angeles, Calif.) 67 p HC \$4.50 CSCL 10A

N76-30659

Unclas
50113
G3/44

Prepared for

George C. Marshall Space Flight Center
National Aeronautics and Space Administration
Marshall Space Flight Center
Huntsville, Alabama 35812



AIRESEARCH MANUFACTURING COMPANY
OF CALIFORNIA

Screening Analysis


DEVELOPMENT OF A SOLAR-POWERED RESIDENTIAL AIR CONDITIONER

Contract NAS8-30758

74-10996(7)

July 25, 1975

Approved by



J. Rousseau

Prepared for

George C. Marshall Space Flight Center
National Aeronautics and Space Administration
Marshall Space Flight Center
Huntsville, Alabama 35812



AIRESEARCH MANUFACTURING COMPANY
OF CALIFORNIA

CONTENTS

	<u>Page</u>
INTRODUCTION	1
BASELINE DESIGN CONDITIONS	1
METHODOLOGY	3
ASSUMPTIONS	6
COMPUTER LISTING	6
SCREENING ANALYSIS RESULTS	8
Concept A, Ambient Air Condenser	10
Concept B, Humidified Ambient Air	15
Concept C, Evaporative Condenser	18
Concept D, Water Condenser/Cooling Tower	22
COMPARISON OF APPROACHES	27
Baseline LiBr/H ₂ O Absorption System	27
Concept Evaluation	27
Operation at Higher Boiler Temperature	29
CONCLUSIONS	30
REFERENCES	30
<u>Appendix</u>	
A COMPUTER PROGRAM NOMENCLATURE AND LISTING	A-1
B INPUT/OUTPUT DATA FOR SOLAR-POWERED AIR CONDITIONING SYSTEM CONCEPTS	B-1



INTRODUCTION

This report summarizes the results of screening analyses aimed at the definition of an optimum configuration of a Rankine-cycle solar-powered air conditioner designed for residential applications. These investigations are conducted in fulfillment of Task 4 of Contract NAS8-3078. Initial studies revealed that system performance and cost were extremely sensitive to condensing temperature and to the type of condenser used in the system. Consequently, the screening analyses were concerned with the generation of parametric design data for the four different condenser approaches defined in Figure 1 and identified as follows:

- (a) Concept A--Ambient air condenser
- (b) Concept B--Humidified ambient air condenser
- (c) Concept C--Evaporative condenser
- (d) Concept D--Water condenser (with a cooling tower)

All systems considered feature a high-performance turbocompressor and a single refrigerant (R-11) for the power and refrigeration loops. The selection of R-11 as the working fluid is supported by the results of fluid evaluation studies reported in Reference 1.* The data (presented in subsequent discussions) were obtained by computerized methods developed to permit system characterization over a broad range of operating and design conditions. The criteria used for comparison of the candidate system approaches are listed below.

- (a) Overall system COP (refrigeration effect/solar heat input)
- (b) Auxiliary electric power for fans and pumps
- (c) System installed cost or cost to the user

BASELINE DESIGN CONDITIONS


For the purpose of comparison, the following interface conditions were used to generate parametric system characteristics:

- (a) Water temperature at boiler inlet (thermal storage temperature): 366.5 K (200 F)
- (b) Room return air temperatures: 299.8 K (80 F) db, and 292.6 K (67 F) wb
- (c) Ambient air temperatures: 308.2 K (95 F) db, and 297 K (75 F) wb


The 366.5 K (200 F) water temperature from the thermal storage units is representative of the level attainable from a flat-plate solar collector. The

*References are presented at the end of this document (before appendixes).







Concept A, Ambient Air Condenser



Concept B, Humidified Ambient Air Condenser



Concept C, Evaporative Condenser



Concept D, Water Condenser

S-97703

Figure 1. Candidate System Configurations

room return air and ambient air temperatures are those specified by the Air Conditioning and Refrigeration Institute (ARI) for the purpose of rating air conditioners. All screening analyses were performed for a 10.5-kw (3-ton) air conditioner capacity.

METHODOLOGY

The logic used by the computer program is illustrated in Figure 2. Basically, the computation of component and system characteristics follows the approach described in Reference 2. Cycle parameters defining the conditions of the refrigerant within the power and refrigeration loops of the heat exchangers are used to perform thermodynamic analyses. In these computations, it is essential that the efficiencies of the turbine and compressor be estimated accurately and that the speed of these two components be matched to provide realistic refrigerant conditions through the loop and also to assure design feasibility for the turbomachinery. For this purpose, generalized compressor and turbine performance models were used in the computer program.

The efficiency of a single-stage centrifugal compressor can be determined by analytical and experimental data correlated in terms of the following parameters:

- (a) Adiabatic head
- (b) Adiabatic head coefficient
- (c) Specific speed
- (d) Tip mach number
- (e) Reynolds number




Figure 2. Methodology Used in Screening Analyses

The data of Figure 3 show the achievable efficiency of centrifugal compressors plotted as a function of specific speed and tip Mach number. The plot is based on experimental data extending to specific speeds as low as 0.02. The data are representative of recent machines that feature efficient exit diffusers and are fabricated using modern techniques to minimize friction losses by smooth surface finishes and assure high volumetric efficiency by maintaining close tolerances throughout. These fabrication constraints do not preclude low production cost as evidenced by present reciprocating engine turbocharger technology.

The efficiency plot of Figure 3 corresponds to impeller diameters larger than 10.2 cm (4 in.) and Reynolds numbers higher than 10^6 . For smaller compressor sizes and lower Reynolds numbers, the efficiency obtained from Figure 3 must be corrected to account for additional losses. The size correction factor also derived from empirical correlation is shown in Figure 4. The Reynolds number correction factor can be computed by

$$\frac{1-\eta}{1-\eta^*} = \left(\frac{10^6}{Re}\right)^{0.1}$$

where η is the corrected efficiency and η^* is the efficiency determined for $Re > 10^6$.





Figure 3. Generalized Centrifugal Compressor Efficiency





S-97704

Figure 4. Effect of Impeller Size on Centrifugal Compressor Stage Efficiency

As for the centrifugal compressor, radial reaction turbine data have been collected from published literature. These data were correlated and the generalized plot of Figure 5 was prepared. The data below 50 percent represent extrapolation of the test data. Actually, the range of designs used in the screening analysis is well above 50 percent; the reason for the extrapolation is stability of the iterative computer calculations.

The efficiency data of Figure 5 apply to machines with Reynolds numbers larger than 200,000. For lower Reynolds numbers, a correction factor must be applied as follows:

$$\frac{1-\eta}{1-\eta^*} = 0.4 + 0.6 \left(\frac{Re}{200,000} \right)^{-0.2}$$

where η is the corrected turbine efficiency and η^* is the value obtained from Figure 5 for $Re > 200,000$.

Through an iterative procedure designed to match the compressor and turbine speed and power, the computer program determines the system flows, refrigerant conditions, and the system COP. These refrigerant data, or cycle data, are then used together with specified interface and heat exchanger approach temperatures to generate problem statements for the heat exchanger, fans, and pumps. The






Figure 5. Generalized Efficiency

characteristics of these components are then determined in terms of parameters that can be related to cost. Finally, the models described in Reference 3 are used to determine component and overall system cost.

ASSUMPTIONS

A number of assumptions were made in order to develop relatively simple but sufficiently accurate techniques for the characterization of the components and the entire system. These assumptions are summarized in Table 1. Most of the data concerned with component characterization were derived from commercial equipment catalogs and are representative of typical design conditions for this type of equipment. The equipment cost models are substantiated in Reference 3. The system cost model used is also from the same document; equations used in the computer program are as follows:

$$\text{System factory cost} = 1.65 (\Sigma \text{major component costs})$$

$$\text{User's cost} = 6.13 (\Sigma \text{major component costs})$$

COMPUTER LISTING

A listing of the computer program is presented in Appendix A, which also includes the nomenclature of the input data. The program was written in Fortran V language for use on the UNIVAC 1108 computer. Examples of the



MAJOR ASSUMPTIONS FOR COI

Cycle analysis	<ol style="list-style-type: none"> 1. Refrigerant properties from publication, by Allied Chemical, "Genetron 11 Thermodynamic Properties", 1957. 2. Saturated vapor and liquid properties used in table form. 3. Vapor and liquid refrigerant assumed ideal fluids with c_p vapor = 586.6 J/kg K (0.14 Btu/lb F) and c_p liquid = 879.9 J/kg K (0.21 Btu/lb F). 4. R-11 saturated vapor at boiler and evaporator outlet; saturated liquid at condenser outlet. 5. Heat exchanger pressure drop on refrigerant side assumed 5 percent of inlet pressure. 6. Turbocompressor mechanical losses assumed 10 percent of turbine power.
Dry condenser	<ol style="list-style-type: none"> 1. Heat transfer surface: 0.95-cm (3/8-in.) dia copper tubes with wavy aluminum fins. Tube pitch: triangular on 1-in. center. Core density: 560 kg/m³ (35 lb/ft³). 2. Overall heat transfer coefficient: 669.6(w/K) tube row/m² of face area (118 Btu/hr F) tube row/ft² of face area; data from commercial units at face velocity of 2.54 m/sec (500 ft/min). 3. Air-side pressure drop: $\Delta P = 21.9$ (no rows) 0.746 N/m² (0.088 (no rows) 0.746 in. H₂O); data from commercial unit at face velocity of 2.54 m/sec (500 ft/min²). 4. Wrap-up factor: 10 percent of core weight; typical of commercial equipment. 5. Cost: \$1.67/kg (\$0.76/lb tot.)
Evaporative condenser	<ol style="list-style-type: none"> 1. Heat transfer surface: copper tubes with extended surface inside; tube thickness: 0.41 mm (0.016 in.). 2. Evaporative side heat capacity, q, $w = 0.506 \Delta h A$, where Δh, J/kg, is the log mean difference between the enthalpy of air at the metal temperature and the enthalpy of air at inlet and outlet conditions, and A is the surface area in m² (in english units q, Btu/hr = 373Δh(Btu/lb) A(ft²)). 3. Condensing coefficient is taken as 1702 w/Km² (300 Btu/hr ft²F). 4. Air-side pressure drop taken as 124.4 N/m² (0.5 in. H₂O). 5. Cost = \$5/kg (\$2.3/lb) of core weight. 6. Pump cost: \$40 fixed.
Humidifier/condenser	<ol style="list-style-type: none"> 1. Condenser sizing based on same assumptions as dry condenser above. 2. Humidifier performance: effectiveness of 90 percent assumed; $(T_{db \text{ in}} - T_{db \text{ out}}) / (T_{db \text{ in}} - T_{wb}) = 0.9$ 3. Humidifier pressure drop taken as 24.9 N/m² (0.1 in. H₂O). 4. Humidifier cost: 0.2 (condenser cost).
Liquid condenser	<ol style="list-style-type: none"> 1. Heat transfer surface: copper tubes; tube thickness: 0.41 mm (0.016 in.). 2. Condensing side heat transfer coefficient controlling, $h = 1135$ w/Km² (200 Btu/hr ft²F). 3. Wrap-up factor: 2.0 4. Cost: \$3.3/kg tot (\$1.53 lb tot).

FOLDOUT FRAME


 AIRESEARCH MANUFACTURING COMPANY
 OF CALIFORNIA

COMPONENT AND SYSTEM DESIGN

Cooling tower	<ol style="list-style-type: none"> 1. Water outlet temperature assumed in the system calculations. 2. Fan power: PW in watts = $10.1 Q$ where Q in kw (PW in watts = $2.96 \times 10^{-3} Q$ where Q in Btu/hr); typical of commercial cooling towers. 3. Water pump power: PW in watts = $6.5 Q$ where Q in kw (PW in watts = $1.9 \times 10^{-3} Q$ where Q in Btu/hr); typical of commercial equipment. 4. Cooling tower cost: $\\$(40 + 6.5Q)$ where Q in kw, $\\$(40 + 1.905 \times 10^{-3} Q)$ where Q in Btu/hr).
Boiler	<ol style="list-style-type: none"> 1. Heat transfer surface: Copper tubes with extended surface inside; tube thickness: 0.41 mm (0.016 in.). 2. Boiling side heat transfer coefficient is controlling; $h = 1135 \text{ w/K m}^2$ (200 Btu/hr ft²). 4. Cost: $\\$3.3/\text{kg tot.}$ ($\\$1.53/\text{lb tot.}$).
Freon pump	<ol style="list-style-type: none"> 1. Wet motor design. 2. Pump efficiency: 50 percent. 3. Pump cost: $\\$40$ (fixed value).
Water pumps	<ol style="list-style-type: none"> 1. Same efficiency and cost as above.
Fans	<ol style="list-style-type: none"> 1. Axial flow blowers 2. ΔP_{TOT}, $\text{N/m}^2 = 4/3 \Delta P_{STAT} + 37$ ($4/3 \Delta P + 0.15 \text{ in. H}_2\text{O}$). 3. Fan efficiency: 70 percent; motor efficiency: 70 percent. 4. Fan weight: See Figure 5 of Reference 3. 5. Fan cost: $\\$1.9/\text{kg}$ ($\\$0.88/\text{lb}$)
Motor	<ol style="list-style-type: none"> 1. Motor efficiency: 70 percent 2. Motor cost = $\\$(10 + 32.5 \text{ kw})$ where kw is output power.
Evaporator	<ol style="list-style-type: none"> 1. Heat transfer surface: 0.95-cm (3/8-in.) dia tubes with wavy aluminum fins; tube pitch: triangular on 1-in. center; core density: 560 kg/m^3 (35 lb/ft³). 2. Overall heat transfer coefficient: (1) dry portion, $669.6 \text{ (w/k)/tube row/ m}^2$ of face area (118 Btu/hr F/tube row/ft² of face area); (2) wet or condensing portion, $U = 1870 \text{ (w/k)/tube row/ m}^2$ of face area (330 Btu/hr F/tube row/ft² of face area). Data from commercial units at face velocity of 2.54 m/s (500 ft/min). 3. Air-side pressure drop, $\Delta P = 21.9$ (no rows) $0.746, \text{ N/m}^2$, (0.088 (no rows) $0.746 \text{ in. H}_2\text{O}$) for dry portion; for wet portion ΔP increases by factors of 1.36. Data from commercial units at face velocity of 2.54 m/sec (500 ft/min). 4. Wrap-up factor: 10 percent of core weight. 5. Cost: $1.67/\text{kg tot}$ ($\\$0.76/\text{lb tot}$).

FOR UNIT FRAME 2

computer input and output are presented in Appendix B for the four system concepts defined in Figure 1. The output data include:

- (a) Refrigerant temperature, pressure, enthalpy, flow rate, and density at the system stations defined in Figure 1
- (b) Heat exchanger flows, temperatures, heat loads, and UA requirement
- (c) Heat exchanger weight and cost
- (d) Fan characteristics including flow, pressure rise, and power
- (e) Wetbulb temperature of the air at inlet and outlet of the evaporator and condenser where applicable
- (f) Cycle characteristics: power loop efficiency, refrigeration loop COP, and overall system COP. COP is defined as follows:

$$\text{Refrigeration loop COP} = \frac{\text{refrigeration load}}{\text{compressor power input}}$$

$$\text{Overall system COP} = \frac{\text{refrigeration load}}{\text{boiler heat input}}$$

- (g) Turbine and compressor characteristics: efficiency, impeller diameter, and speed
- (h) Electric power requirements for the fans and pumps
- (g) System cost data

The program was written using the english system of units as defined in the nomenclature and the output data printouts.


SCREENING ANALYSIS RESULTS

As mentioned previously, four condenser arrangements defined as concepts A through D were investigated. Design point data were generated for a range of cycle conditions (refrigerant temperatures) and heat exchanger approach temperatures. Temperature profiles through the system heat exchangers illustrating approach temperature in terms of fluid inlet and outlet temperatures are shown in Figure 6. The schematics and plots shown depict counterflow heat exchanger configurations. This arrangement was used for illustration purposes only. In practice, the heat exchangers will generally be of a cross-counterflow design. However, the approach temperature remains a major design factor in determining the size of heat exchangers of any flow configuration.


The system characteristics obtained by computer analysis were plotted in terms of the significant design parameters and are discussed below. The conditions listed in Table 2 were used for purposes of comparison. Data presented later show the sensitivity of the system to water temperature at boiler inlet as high as 300 F.




CONDENSER



BOILER



EVAPORATOR



5-97701

Figure 6. Typical Temperature Profiles

TABLE 2
 BASELINE DESIGN CONDITIONS

Parameter	Design Condition
Water inlet temperature to the boiler	366.5 K (200 F)
Ambient air drybulb temperature	308.2 K (95 F)
Ambient air wetbulb temperature	297 K (75 F)
Room return air drybulb temperature	299.8 K (80 F)
Evaporating temperature	280.4 K (45 F)
Room return air wetbulb temperature	292.6 K (67 F)
System capacity	10.5 kw (3 tons)

Concept A, Ambient Air Condenser

The schematic of Concept A is presented in Figure 7 below. Parametric performance and cost data are shown in Figure 8.






Figure 7. Concept A, Ambient Air Condenser







a. Effect of Condensing Temperature



b. Effect of Condenser Approach Temperature



c. Effect of Boiling Temperature



d. Effect of Boiler Approach Temperature

S-97699

Figure 8. Parametric Data for Concept A



AIRSEARCH MANUFACTURING COMPANY
OF CALIFORNIA

REPRODUCIBILITY OF THE
ORIGINAL PAGE IS POOR

74-10996(7)
Page 11

1. Effect of Condensing Temperature (Figure 8a)

The condenser and its fan constitute the most sensitive equipment in terms of system cost, size, and electrical power. While the system COP increases at low condensing temperature, resulting in lower boiler and condenser heat loads, the lower ΔT (condensing temperature - air temperature) potential for heat transfer with a fixed ambient air heat sink overshadows this effect. As a result, both system power (with condenser fan as the main contributor) and system cost increase rapidly as the design condensing temperature drops below about 320 K (115 F). At that condensing temperature and for the conditions listed on the figure, the overall system COP will be about 0.3.

The sensitivities of these parameters at a condensing temperature of 319 K (115 F) calculated in terms of condensing temperature are as follows:

COP sensitivity:	-0.017/K (-0.0092/F)
Power sensitivity:	-0.12 kw/K (-0.065 kw/F)
Cost sensitivity:	-\$190/K (-\$104/F)

An overall system-level trade can be performed involving system COP and cost because both COP and cost increase as condensing temperature drops. However, at 319 K (115 F), a 0.1 improvement in system COP will cost \$1120; this represents a prohibitive cost increase for higher performance. A condensing temperature of 319 K (115 F) appears about minimum for this type of system designed for the conditions listed in Figure 8a.

2. Effect of Condenser Approach Temperature (Figure 8b)

The condenser cooling airflow \dot{w} can be approximated by

$$\dot{w} = \frac{Q}{c_p \Delta T_{\text{air}}} = \frac{Q}{c_p} \times \frac{1}{(T_{\text{cond}} - T_{\text{air in}}) - \Delta T_{\text{approach}}}$$

where Q is the condenser heat load, c_p is the specific heat of the cooling air, and T_{cond} is the condensing temperature. Reference is made to Figure 6 for

definition of the approach temperature, $\Delta T_{\text{approach}}$, in terms of the fluid temperatures at inlet and outlet of the condenser. As shown by this correlation and plotted in Figure 8b, the cooling airflow through the condenser increases rapidly with increasing air temperature for fixed values of the condensing and ambient air temperatures. This effect overshadows the low condenser UA requirements and smaller condenser size because the thermal design requirements are relaxed at higher approach temperature. For example, the condenser required at 4.2 K (7.5 F) and 8.3 K (15 F) approach temperatures are estimated as

50 kJ/sec m^2K (8810 Btu/hr ft^2F) and 68.2 kJ/sec m^2K (12,000 Btu/hr ft^2F), respectively. As a result, system cost and electrical power requirements will increase with the condenser design approach temperature. In terms of system cost and electrical power requirements (and also detail design of the condensing



heat exchanger), an approach temperature of 5.6 K (10 F) appears to be a reasonable compromise for the operating conditions noted in Figure 8b.

3. Effect of Boiling Temperature (Figure 8c)

The cost and power dependancy on boiling temperatures are relatively mild by comparison to condensing temperature. In this case, the major effect is the most favorable system operating conditions (higher COP) obtained at higher boiler temperature. As the boiling temperature increases from 344 K (160 F) to 355 K (180 F), the quantity of heat processed at the condenser decreases from 60.4 kw (206,300 Btu/hr) to 44.9 kw (153,100 Btu/hr) for a 10.5-kw (3-ton) capacity air conditioner. This effect is reflected in the plot of Figure 8c.

The sensitivity of the system characteristics to boiling temperature (around 355 K (180 F)) are:

COP sensitivity:	+0.008/K (0.0044/F)
Power sensitivity:	-0.035 kw/K (-0.019 kw/F)
Cost sensitivity:	-\$60.4/K (-\$33.6/F)

These data show that the COP sensitivity due to boiling temperature is about one-half of that due to condensing temperature, while power and cost are only one-third as sensitive.

The plot of Figure 8c shows that high boiling temperature is highly desirable. Boiler design considerations, however, limit the boiling temperature to about 258.2 K (185 F) with a water inlet temperature of 366.5 K (200 F).

4. Effect of Boiler Approach Temperature (Figure 8d)

The boiler approach temperature has only a negligible effect on system cost and electrical power requirements. The only significant effects are system level considerations such as water flow rate and thermal energy storage tank thermal management. For a fixed water temperature at boiler inlet of 366.5K (200 F), a lower approach temperature will reduce the hot water flow considerably and enhance thermal energy utilization if adequate stratification is provided in the water storage tank design. This presents significant system operational advantages because water at a high temperature level will be available for a longer period.

With a fully mixed tank, the only advantage of a lower approach temperature is the lower pump flow required. However, a higher boiler effectiveness will be required. Detail design studies of the boiler will be necessary in final selection of the boiler approach temperature. For the conditions noted near the selected design point, an approach of 4.2 K (7.5 F) appears acceptable in view of the high heat transfer coefficients achievable on both sides (water and R-11 side) of this unit.



5. Effect of Evaporator Approach Temperature (Figure 8e)

The evaporating temperature was fixed at 280.4 K (45 F) for all system concepts considered. This represents a maximum value to provide for latent heat removal and control of humidity within the air conditioned space. Data similar to that presented previously are shown in Figure 8e. As shown, the evaporator approach temperature has only a relatively small effect on overall system cost and power requirement. The only limiting factor is the evaporator airflow rate, which exceeds the ARI specification of 0.054 (m³/sec)/kw (400 cfm/ton) at approach temperatures higher than 9 K (16 F). An evaporator approach temperature of 5.6 K (10 F) appears reasonable in view of the thermal design of the evaporator and the ARI flow limitations.




Figure 8e. Effect of Evaporator Approach Temperature



6. System and Component Characteristics

Previous discussions have been concerned with the characteristics of the system as a function of cycle parameters and heat exchanger thermal design. As a result of these discussions, a design point was selected for Concept A equipment corresponding to the interface data of Table 2. The characteristics of this system and its components are listed in Table 3.

Concept B, Humidified Ambient Air Condenser (Figure 9)

Examination of the computer data for Concept B shows a dependence of system characteristics on boiling temperature similar to that for Concept A. Furthermore, the boiler and evaporator approach temperatures have only a mild effect on overall air conditioner cost and power requirements at conditions near the selected design point for this concept. The major parameter affecting cost, power, and COP is again the condensing temperature and the condenser approach temperature. The relationships between these factors are shown in Figure 10.





Figure 9. Concept B, Humidified Ambient Air Condenser

TABLE 3

SYSTEM AND COMPONENT CHARACTERISTICS FOR CONCEPT A


Design Conditions				
Capacity: 10.55 kw (3 tons)				
Hot water supply temperature: 366.5 K (200 F)				
Ambient temperatures: 308.2 K (95 F) db, 297 K (75 F) wb				
Conditioned air return temperatures: 299.8K (80 F) db, 292.6 K (67 F) wb				
Overall System Parameters				
COP: 0.519				
Electrical power requirements: 1.46 kw				
User's cost: \$3970				
Cycle Data				
Boiling temperature: 358.2 K (185 F)				
Condensing temperature: 310.9 K (100 F)				
Evaporating temperature: 280.4 K (45 F)				
Power loop efficiency: 10 percent				
Refrigeration loop COP: 5.75				
Overall COP: 0.519				
Equipment Data				
1. Heat Exchangers	Boiler	Condenser	Evaporator	Humidifier
Heat load, kw(Btu/hr)	20.3 (69,130)	31.0 (104,600)	10.55 (63,000)	38.2 (130,500)
UA, kw/m ² K (Btu/hr ft ² F)	36.2 (6390)	38.1 (6705)	-	-
Cold fluid	R-11	Humidified air	R-11	Water
inlet temperature, K(F)	311.7 (101.3)	298.2 (77)	280.4 (45)	294.3 (70)
Outlet temperature, K(F)	358.2 (185)	305.4 (90)	280.4 (45)	-
Flow rate, kg/sec(lb/hr)	0.102 (808)	-	0.066 (520)	.015 (122)
m ³ /sec (cfm)	-	3.67 (7780)	-	-
m ³ /sec (gpm)	-	-	-	-
Hot fluid	Water	R-11	Return air	Ambient air
inlet temperature, K(F)	366.5 (200)	332.1 (120.1)	299.8 (80) db 292.6 K (67) wb	308.2 (95) db, 297 (75) wb
Outlet temperature, K(F)	362.3 (192.5)	310.9 (100)	285.9 (55) db, 285 (53.4) wb	298.2 (77) db, 297 (75) wb
Flow rate, kg/sec (lb/hr)	-	0.168 (1328)	-	-
m ³ /sec (cfm)	-	-	0.40 (850)	3.67 (7780)
m ³ /sec (gpm)	0.0012 (18.4)	-	-	-
2. Turbomachines		Turbine	Compressor	
Flow, kg/sec (lb/hr)		0.102 (808)	0.066 (520)	
Inlet pressure, k N/m ² (psia)		592.9 (86)	55.16 (8)	
Pressure ratio		3.47	3.1	
Diameter, cm (in)		4.93 (1.94)	5.65 (2.24)	
Speed, rpm		61,716	61,716	
Efficiency, %		78.9	72.5	
3. Blowers and Pumps		Condenser Blower	Evaporator Blower	Freon Pump
Flow, kg/sec (lb/hr)		-	-	0.102 (808)
m ³ /sec (cfm)		3.67 (7780)	0.40 (850)	-
Inlet pressure, k N/m ² (psia)		101.3 (14.7)	101.3 (14.7)	162.6 (23.6)
Pressure rise, N/m ² (in. H ₂ O)		147 (0.59)	214 (0.86)	-
Pressure ratio		-	-	3.83
Electrical power, kw		1.11	0.180	0.064
				0.105





$T_{BOIL} = 355.4K (180F)$
 $T_{EVAP} = 280.4K (45F)$
 BOILER, EVAPORATOR, CONDENSER
 APPROACH TEMPERATURE = 5.56K (10F)
 INTERFACE CONDITIONS: SEE TABLE 2

a. Effect of Condensing Temperature



$T_{BOIL} = 355.4K (180F)$
 $T_{EVAP} = 280.4K (45F)$
 $T_{COND} = 313.7K (105F)$
 BOILER AND EVAPORATOR
 APPROACH TEMPERATURE: 5.56K (10F)
 INTERFACE CONDITIONS: SEE TABLE 2

b. Effect of Condenser Approach Temperature

Figure 10. Parametric Data for Concept B



1. Effect of Condensing Temperature

In this case, the ambient air drybulb temperature is reduced by about 10 K (18 F) from 308.2 K (95 F) by adiabatic humidification upstream of the condenser. As a result, significantly lower condensing temperatures can be achieved without significant cost and power penalties. As shown in Figure 10a, condensing temperatures of 310.9 K (100 F) can be used for design, corresponding to a COP of 0.48. This represents a 50 percent increase over Concept A. Concept B also results in significant cost savings (about \$2000 for a 10.5-kw (3-ton) unit) and a 20 percent savings in fan/pump power requirements.

As the condensing temperature drops below 310.9 K (100 F), both system cost-to-the-user and system power increase rapidly, although the performance of the system improves. Again, in this case this effect is due to the much higher condenser airflow rates necessary at lower condensing temperatures. The cost increase associated with the higher COP at a condensing temperature of 310.9 K (100 F) is estimated at \$780 for 0.1 increase in COP. Tentatively, a condensing temperature of 310.9 K (100 F) is selected for this approach.

2. Effect of Condenser Approach Temperature

This effect is depicted in the plot of Figure 10b for conditions representative of system design point. Again, the condenser airflow required increases rapidly with approach temperature above a ΔT approach of 5.6 K (10 F). The higher heat exchanger effectiveness and weight required at low approach temperature is more than offset by the much lower cooling airflows necessary. There are no apparent problems in designing the condenser for a 5.6 K (10 F) approach.

3. System and Component Characteristics

Table 4 summarizes the characteristics of the system (and its components) identified as Concept B and shown schematically in Figure 9. Design point conditions are listed in the table. Boiling temperature is taken as 358.2 K (185 F) for a boiler approach of 4.2 K (7.5 F); evaporating temperature is 280.4 K (45 F) for an evaporator approach of 5.6 K (10 F). The condensing temperature is 310.9 K (100 F) for an approach of 5.6 K (10 F). Under these conditions, system COP is 0.480.

Concept C, Evaporative Condenser (Figure 11)

A schematic of this arrangement is shown in Figure 11. Water is sprayed on the tubes of the condenser where it evaporates. The vapor formed is entrained by the airstream through the unit. The air is only used as a means for evaporating water. At inlet, near-adiabatic saturation will reduce the drybulb temperature of the air to about 298.2 K (77 F). As the air drybulb temperature increases through the unit, its capacity for water vapor increases rapidly. At outlet, the drybulb temperature of the air exiting the condenser is lower than at inlet.



TABLE 4

SYSTEM AND COMPONENT CHARACTERISTICS FOR CONCEPT B

<u>Design Conditions</u>			
Capacity: 10.55 kw (3 tons)			
Hot water supply temperature: 366.5 K (200 F)			
Ambient temperatures: 308.2 K (95 F) db, 297 K (75 F) wb			
Conditioned air return temperatures: 299.8 K (80 F) db, 292.6 K (67 F) wb			
<u>Overall System Parameters</u>			
COP: 0.326			
Electrical power requirements: 1.72 kw			
User's cost: \$5630			
<u>Cycle Data</u>			
Boiler temperature: 358.2 K (185 F)			
Condenser temperature: 319.3 K (115 F)			
Evaporator temperature: 280.4 K (45 F)			
Power loop efficiency: 8.5%			
Refrigeration loop COP: 4.27			
Overall COP: 0.326			
<u>Equipment Data</u>			
1. Heat exchangers	Boiler	Condenser	Evaporator
Heat load, kw (Btu/hr)	32.3 (110,100)	42.6 (145,500)	10.55 (36,000)
UA, kw/m ² K (Btu/hr ft ² F)	57.9 (10,200)	57.3 (10,100)	-
Cold fluid	R-11	Ambient air	R-11
Inlet temperature, K(F)	319.9 (116.2)	308.2 (95)	280.4 (45)
Outlet temperature, K(F)	358.2 (185)	313.7 (105)	280.4 (45)
Flow rate, kg/sec (lb/hr)	0.169 (1337)	-	0.069 (545)
m ³ /sec (cfm)	-	6.63 (14,050)	-
m ³ /sec (gpm)	-	-	-
Hot fluid	Water	R-11	Return air
Inlet temperature, K(F)	366.5 (200)	330.2 (134.6)	299.8(80) db, 292.6 (67) wb
Outlet temperature, K(F)	362.3 (192.5)	319.3 (115)	285.9(55) db, 285 (53.4) wb
Flow rate, kg/sec (lb/hr)	-	0.238 (1882)	-
m ³ /sec (cfm)	-	-	0.4 (850)
m ³ /sec (gpm)	0.0019 (29.3)	-	-
2. Turbomachines	Turbine	Compressor	
Flow, kg/sec (lb/hr)	0.169 (1337)	0.069 (545)	
Inlet pressure, kN/m ² (psia)	592.9 (86.0)	55.16 (8.0)	
Pressure ratio	2.66	4.04	
Diameter, cm (in.)	4.63 (1.82)	6.70 (2.64)	
Speed, rpm	58,720	58,720	
Efficiency, percent	0.81	0.71	
3. Blowers and Pumps	Evaporator Blower	Condenser Blower	Freon Pump
Flow, kg/sec (lb/hr)	-	-	0.169 (1337)
m ³ /sec (cfm)	0.4 (848)	6.63 (14,050)	-
Inlet pressure, kN/m ² (psia)	101.3 (14.7)	101.3 (14.7)	212.4 (30.8)
Pressure rise, N/m ² (in.H ₂ O)	214 (0.86)	102 (0.41)	-
Pressure ratio	-	-	2.93
Electrical power, kw	0.18	1.45	0.1



In Concept B, the water-carrying capacity of the condenser airstream is limited by the wetbulb temperature of the air at inlet 297 K (75 F), and condenser cooling is affected essentially by sensible heat transfer. In Concept C, the water capacity of the air increases through the heat exchanger as the drybulb temperature of the air increases. Also, much higher heat transfer coefficients can be achieved by water evaporation on the surfaces of the condenser tubes.

Parametric data generated by computer indicate that the boiler and evaporator approach temperatures have only minor effects on the overall system cost and electrical power requirements. As before, these parameters were selected as 4.2 K (7.5 F) and 5.6 K (10 F), respectively. For maximum COP, a boiling temperature of 358.2 K (185 F) was selected.

1. Effect of Condensing Temperature

Figure 12a shows system cost and power requirements as a function of condensing temperature for two values of the approach temperature, 5.6 K (10 F) and 8.3 K (15 F). At condensing temperatures above about 314 K (105 F), cost and power are about the same for the two values of the approach temperature. At lower condensing temperatures, the lower approach yields preferable characteristics. Further, in order to achieve a condensing temperature as low as 305.4 K (90 F) with attendant high COP (0.66), the lower approach is necessary.






Figure 11. Concept C, Evaporative Condenser



$T_{\text{BOILING}} = 355.4\text{K} (180\text{F})$
 $T_{\text{EVAP}} = 280.4\text{K} (45\text{F})$
 BOILER AND EVAPORATOR APPROACH TEMPERATURE: 5.56K (10F)
 CONDENSER APPROACH TEMPERATURE: (SEE NOTE ON FIGURE)
 INTERFACE CONDITIONS: SEE TABLE 2

a. Effect of Condensing Temperature



$T_{\text{BOILING}} = 355.4\text{K} (180\text{F})$
 $T_{\text{EVAP}} = 280.4\text{K} (45\text{F})$
 $T_{\text{COND}} = 305.4\text{K} (90\text{F})$
 BOILER AND EVAPORATOR APPROACH TEMPERATURE = 5.56K (10F)
 INTERFACE CONDITIONS: SEE TABLE 2

b. Effect of Condenser Approach Temperature

Figure 12. Parametric Data for Concept C

TABLE 5

SYSTEM AND COMPONENT SUMMARY FOR CONCEPT C

Design Conditions				
Capacity: 10.55 kw (3 tons)				
Hot water supply temperature: 366.5 K (200 F)				
Ambient temperatures: 308.2 K (95 F) db, 297 K (75 F) wb				
Conditioned air return temperatures: 299.8 K (80 F) db, 292.6 K (67 F) wb				
Overall System Parameters				
CCP: 0.691				
Electrical power requirements: 1.15 kw				
User's cost: \$3055				
Cycle Data				
Boiling temperature: 358.2 K (185 F)				
Condensing temperature: 305.4 K (90 F)				
Evaporating temperature: 280.4 K (45 F)				
Power loop efficiency: 0.108				
Refrigeration loop COP: 7.12				
Overall COP: 0.691				
Equipment Data				
1. Heat exchangers	Boiler	Condenser		Evaporator
Heat load, kw (Btu/hr)	14.4 (51,950)	24.3 (87,560)		5.56 (36,000)
UA, kw/m ² K (Btu/hr ft ² F)	27.2 (4800)	-		-
Cold fluid	R-11	Air and evaporated water		R-11
Inlet temperature, K(F)	306.2 (91.4)	308.2 (95) db, 297 (75) wb		280.4 (45)
Outlet temperature, K(F)	358.2 (185)	299.8 (80) db, 299.8 (80) wb		280.4 (45)
Flow rate, kg/sec (lb/hr)	0.075 (592)	Water evap.: 0.018 (144.6)		0.064 (504)
m ³ /sec (cfm)	-	air: 1.91 (4050)		-
m ³ /sec (gpm)	-	-		-
Hot fluid	Water	R-11		Return air
Inlet temperature, K(F)	366.5 (200)	316.7 (110.9)		299.8 (80) db, 292.6 (67) wb
Outlet temperature, K(F)	362.3 (192.5)	305.4 (90)		285.9 (55) db, 285 (53.4) wb
Flow rate, kg/sec (lb/hr)	-	0.139 (1097)		-
m ³ /sec (cfm)	-	-		0.4 (850)
m ³ /sec (gpm)	0.0009 (13.8)	-		-
2. Turbomachines	Turbine		Compressor	
Flow, kg/sec (lb/hr)	0.075 (592)		0.064 (504)	
Inlet pressure, kN/m ² (psia)	592.9 (86)		55.2 (8)	
Pressure ratio	4.1		2.62	
Diameter, cm (in.)	5.54 (2.18)		5.54 (2.18)	
Speed, rpm	58,470		58,440	
Efficiency, percent	77.1		73.6	
3. Blowers and pumps	Condenser Blower	Evaporator Blower	Freon Pump	Water Pump
Flow, kg/sec (lb/hr)	-	-	0.075 (592)	0.127 (1000)
m ³ /sec (cfm)	1.91 (4050)	0.4 (850)	-	-
Inlet pressure, kN/m ² (psia)	101.3 (14.7)	101.3 (14.7)	137.8 (20)	(101.3) 14.7
Pressure rise, N/m ² (in. H ₂ O)	204 (0.82)	214 (0.86)	-	-
Pressure ratio	-	-	4.52	2
Electrical power, kw	0.830	0.18	0.050	0.088



the order of 305.4 K (90 F) can be achieved. For water-to-air heat pumps, ARI standard 240 (Reference 4) specifies a water temperature at condenser inlet and outlet of 297 K (75 F) and 308.2 K (95 F), respectively. The 297 K (75 F) inlet temperature appears very optimistic in view of the 297 K (75 F) wetbulb temperature of ambient air for air-to-air heat pumps. Further, there appears to be no firm basis for the 308.2 K (95 F) condenser outlet temperature other than limiting the water flow rate and the ΔT through the cooling tower. In this study, the cooling water temperature from the cooling tower was taken as 299.8 K (80 F) because this temperature level is more consistent with an ambient air wetbulb temperature of 297 K (75 F).

As for the three previous concepts, the boiling temperature selected in final evaluation was 358.2 K (185 F) to maximize COP. The approach temperatures at the boiler and evaporator were taken as 4.2 K (7.5 F) and 5.6 K (10 F), respectively. Figure 14 shows parametric data related to the operation and design of the condenser.

1. Effect of Condensing Temperature (Figure 14a)

Both power consumption and system cost increase with condensing temperature primarily because of the lower system effectiveness. In this case, however, the condensing heat exchanger/cooling tower constitute a very efficient heat rejection system; thus, the impact of these components on total system cost and power is not as pronounced as for other competing approaches. The optimum design in terms of condensing temperature occurs at about 305.4 K (90 F). With a water temperature of 299 K (80 F) at condenser inlet, this imposes severe limitations on the approach temperature (as shown in Figure 14b).

2. Effect of Condenser Approach Temperature

The high heat transfer coefficient afforded by the water coolant loop allows the design of a very efficient condenser with a low approach temperature. The 2.8 K (5 F) approach selected may have to be increased as a result of condenser detail design investigations. However, this does not represent an unrealistic design point for this unit.

3. System and Component Characteristics

Table 6 summarizes the characteristics of the system and its components at design point. Cycle operating parameters were selected as follows:


Boiling temperature: 358.2 K (185 F)

Condensing temperature: 305.4 K (90 F)

Evaporating temperature: 280.4 K (45 F)


In this case, the very low system power reflects the low pressure drop of the ambient air through the cooling tower. The value used in the computation of cooling tower power was taken as representative of existing cooling tower equipment.





$T_{\text{BOILING}} = 355.4\text{K} (180\text{F})$
 $T_{\text{EVAP.}} = 280.4\text{K} (45\text{F})$
 BOILER EVAPORATOR APPROACH
 TEMPERATURE = 5.6K (10F)
 CONDENSER APPROACH
 TEMPERATURE: 2.8K (5F)
 INTERFACE CONDITIONS: SEE TABLE 2

a. Effect of Condensing Temperature



$T_{\text{BOILING}} = 355.4\text{K} (180\text{F})$
 $T_{\text{EVAP.}} = 280.4\text{K} (45\text{F})$
 $T_{\text{COND.}} = 305.4\text{K} (90\text{F})$
 BOILER AND EVAPORATOR
 APPROACH TEMPERATURE: 5.6K (10F)
 INTERFACE CONDITIONS: SEE TABLE 2

S-97696

b. Effect of Condenser Approach Temperature

Figure 14. Parametric Data for Concept D



TABLE 6

CONCEPT D SYSTEM AND COMPONENT SUMMARY

<u>Design Conditions</u>				
Capacity: 10.55 kw (3 tons)				
Hot water supply temperature: 366.5 K (200 F)				
Ambient temperatures: 308.2 K (95 F) db, 297 K (75 F) wb				
Conditioned air return temperatures: 299.5 K (50 F) db, 292.6 K (67 F) wb				
Water temperature from cooling tower: 299.8 K (80 F)				
<u>Overall System Parameters</u>				
COP: 0.691				
Electrical power requirements: 0.65 kw				
User's cost: \$3730				
<u>Cycle Data</u>				
Boiling temperature: 358.2 K (185 F)				
Condensing temperature: 305.4 K (90 F)				
Evaporating temperature: 280.4 K (45 F)				
Power loop efficiency: 10.8 percent				
Refrigeration loop COP: 7.12				
Overall COP: 0.691				
<u>Equipment Data</u>				
1. Heat exchangers	Boiler	Condenser	Evaporator	
Heat load, kw (Btu/hr)	15.2 (51,950)	25.65 (87,560)	10.55 (36,000)	
UA, kw/m ² K (Btu/hr ft ² F)	27.2 (4800)	68.8 (12,140)	-	
Cold fluid	R-11	Cooling tower water	R-11	
Inlet temperature, K (F)	306.2 (9.14)	299.8 (80)	280.4 (45)	
Outlet temperature, K (F)	358.2 (185)	302.6 (85)	280.4 (45)	
Flow rate, kg/sec (lb/hr)	.075 (592)	-	0.064 (504)	
m ³ /sec (cfm)	-	-	-	
m ³ /sec (gpm)	-	0.0022 (35)	-	
Hot fluid	Water	R-11	Return air	
Inlet temperature, K (F)	366.5 (200)	316.7 (110.4)	299.8 (80) db, 292.6 (67) wb	
Outlet temperature, K (F)	362.3 (192.5)	305.4 (90)	255.9 (55) db, 285 (53.4) wb	
Flow rate, kg/sec (lb/hr)	-	0.139 (109.7)	-	
m ³ /sec (cfm)	-	-	0.4 (850)	
m ³ /sec (gpm)	.0009 (13.8)	-	-	
2. Turbomachines	Turbine	Compressor		
Flow, kg/sec (lb/hr)	0.075 (592)	0.064 (504)		
Inlet pressure, kw/m ² (psia)	592.9 (86)	55.8 (8.0)		
Pressure ratio	4.1	2.62		
Diameter, cm (in.)	5.54 (2.18)	5.54 (2.18)		
Speed, rpm	58,440	58,440		
Efficiency, percent	77.1	73.6		
3. Blowers and Pumps	Cooling Tower Blower	Evaporator Blower	Freon Pump	Water Pump
Flow, kg/sec (lb/hr)	-	-	0.075 (592)	0.127 (1000)
m ³ /sec (cfm)	2.61 (5000)	-	-	-
Inlet pressure, kN/m ² (psia)	101.3 (14.7)	101.3 (14.7)	157.8 (20)	101.3 (14.7)
Pressure rise, N/m ² (in.H ₂ O)	54.7 (.22)	214 (.86)	-	-
Pressure ratio	-	-	4.62	2
Electrical power, kw	0.26	0.18	0.05	0.17



COMPARISON OF APPROACHES

Baseline LiBr/H₂O Absorption System

Data published by Arkla (Reference 5) on the anticipated performance of a LiBr/H₂O absorption air conditioner designed for solar application and featuring an evaporative condenser are summarized in Table 7. The installed price of such a system (including fans) is estimated at about \$2500 to \$3000 (private communication from Arkla Industries distributor).

The LiBr/H₂O air conditioner has been widely used in conjunction with solar systems and is generally acceptable as the baseline air conditioner. The four Rankine-cycle air conditioner concepts discussed in this report were compared to the LiBr/H₂O system to determine advantages in terms of overall system parameters. The characteristics of the Rankine systems investigated are summarized in Table 8.

Concept Evaluation

Concept A, featuring an ambient air dry condenser, yields excessive system costs and COP's. The high condensing temperatures (319.3 K (115 F)) characteristic of this approach result in a COP of 0.33 and excessive condenser size and ambient cooling airflows. As a result of the low-COP high-condenser heat loads, high condenser effectiveness, and very high airflows, the cost of the system is prohibitive.

In Concept B, a humidifier upstream of the condenser reduces the drybulb temperature of the ambient air and thus provides an effectively lower temperature heat sink. With this approach, condensing temperatures of 310.9 K (100 F) can be achieved without excessively penalizing the system. This reduction in condensing temperature improves cycle COP significantly by comparison to Concept A (from 0.33 to 0.52). As a result, the condenser heat load is reduced considerably; the ambient airflow necessary for cooling also is reduced, and finally, system cost becomes more attractive. By comparison to the Arkla LiBr/H₂O system, Concept B is not competitive; COP is considerably lower (0.52 vs 0.65); installed cost is higher (\$4000 vs \$2700); and auxiliary electrical power (for fans and pumps) also is higher (1.5 kw vs 0.88 kw). Therefore, Concept B is rejected on the basis of all three evaluation criteria.

Concept C features an evaporative condenser where water is evaporated to the ambient airstream from the outer surface of the condenser tanks. As shown in Table 8, the installed cost of this system is comparable to that of the Arkla LiBr/H₂O used as a baseline. The condensing temperature can be reduced to 305.4 K (90 F) with an ambient wetbulb temperature corresponding to ARI conditions (297 K (75 F)). The COP of Concept C is 0.69, which is slightly higher than that of the Arkla unit (0.65). The power requirement is estimated at 1.15 kw, which is slightly higher than that of the Arkla unit. This concept represents a significant improvement over Concepts A and B and is considered competitive with the Arkla system. Off-design performance of Concept B must be determined to fully evaluate the advantages of this approach by comparison to the Arkla unit.

Concept D incorporates a cooling tower that provides the cold water used as the air conditioner heat sink. The performance of this concept as expressed by COP is the same as for Concept C, 0.69. The installed cost is higher than Concept C primarily because of the added use of the cooling tower; power requirement, however, is substantially lower.



TABLE 7

ESTIMATED PERFORMANCE OF WATER-FIRED ABSORPTION AIR CONDITIONER

Cooling capacity	10.54 kw (3 tons)
Hot water source temperature	363.7 K in/358.2 K out (195 F in/185 F out)
Chilled water temperature	285.9 K in/280.4 K out (55 F in/45 F out)
Evaporative heat rejection	298.7 K (78 F wb air in)
Water consumption	25.2 $\mu\text{m}^3/\text{sec}$ (24 gal/hr)
Coefficient of performance	0.65
Electrical consumption	875 watts maximum

TABLE 8

COMPARISON OF APPROACHES

Capacity: 10.55 kw (3 tons) Hot water supply temperatures: 366.5 K (200 F) Ambient air temperatures: 308.2 K (95 F)db, 297 K (75 F)wb Conditioned air temperatures: 299.8 K (80 F)db, 292.6 K (67 F)wb				
Parameter	Dry Condenser (Concept A)	Humidifier (Concept B)	Evaporative Condenser (Concept C)	Cooling Tower (Concept D)
Condensing temperature, K(F)	319.3 (115)	310.9 (100)	305.4 (90)	305.4 (90)
Condenser (cooling tower) airflow, m^3/sec , (cfm)	6.63 (14,050)	3.67 (7780)	1.91 (4050)	2.61 (5000)
Boiler water flow, m^3/sec (gpm)	0.0019 (29.3)	0.0012 (18.4)	0.0009 (13.8)	0.0009 (13.8)
Evaporator airflow, m^3/sec (cfm)	0.4 (850)	0.4 (850)	0.4 (850)	0.4 (850)
COP	0.326	0.519	0.691	0.691
Electrical power requirements, kw	1.72	1.46	1.15	0.65
User's cost, dollars	5630	3970	3055	3730




Detailed investigations of Concept D are warranted to verify by detailed analysis the system cost obtained using the cost model developed earlier in this program.

Operation at Higher Boiler Temperature

While the COP of the absorption system remains about the same over a wide range of heat source temperatures, the Rankine-powered air conditioner performance increases significantly at higher boiler temperature. The data of Figure 15 show this effect. COP's as high as 1.0 can be obtained at a water temperature at boiler inlet of 422 K (300 F). This temperature level could be obtained with a low-performance concentrating collector without sun tracking features. The high COP, relatively low cost, and reasonable power requirements seem to warrant further investigations at temperature levels higher than considered under the present contract.

SYSTEM ARRANGEMENT: CONCEPT C (SEE FIGURE 11)
 SYSTEM CAPACITY: 10.5 kw (3 TONS)
 CONDENSING TEMPERATURE: 305.4K (90F)
 EVAPORATING TEMPERATURE: 280.4K (45F)
 BOILING TEMPERATURE: $T_{WATER IN} - 8.3K (15F)$
 EVAPORATOR AND CONDENSER APPROACH TEMPERATURE: 5.6K(10F)



S-97695

Figure 15. Concept C Characteristics at Higher Boiler Temperature

CONCLUSIONS

The investigations conducted have shown the following:

- (a) COP's as high as 0.69 can be obtained with a Rankine-powered system using water evaporation to enhance condenser performance.
- (b) Detailed studies are required to determine the desirability of an evaporative-type condenser by comparison to the use of a cooling tower.
- (c) On the basis of COP, cost, and electric power usage, the Rankine-powered system is comparable to state-of-art LiBr/H₂O absorption systems.
- (d) Off-design performance analyses are necessary to fully assess the relative merits of the Rankine-powered and absorption systems.
- (e) The present investigations of Rankine-powered systems should be extended to include higher thermal source temperatures as attainable from semi-concentrator type solar collectors. At source temperatures of 422 K (300 F), COP's higher than 1.0 can be achieved; this compares very favorably to the LiBr/H₂O absorption system.

REFERENCES

1. Fourth Monthly Progress Report, Development of a Solar-Powered Air Conditioner, Contract NAS8-30758, AiResearch Report 74-11021(4), March 1975.
2. Design Requirements and Tradeoff Parameters, Development of a Solar-Powered Air Conditioner, Contract NAS8-30758, AiResearch Report 74-10996(2), November 1974.
3. Economic Analysis, Development of a Solar-Powered Air Conditioner, Contract NAS8-30758, AiResearch Report 74-10996(4), March 1975.
4. ARI Standard 240, Standard for Unitary Heat Pump Equipment, Air Conditioning and Refrigeration Institute publication, 1967.
5. Solar Optimized Absorption Cooling Unit, Arkla Proposal to NSF, November 1973.



APPENDIX A

COMPUTER PROGRAM NOMENCLATURE AND LISTING

This appendix contains a definition of the computer program input nomenclature and the listing of the program. The program was written in Fortran language for use with the Univac 1108 computer. The nomenclature is given in Table A-1, which defines all input data required for execution of 'RANKIN' as contained in the NAMELIST 'INPUT'. The data are presented in the same order as they appear in the computer program input data list. The computer program listing is presented in Figure A-1.

TABLE A-1

INPUT DATA NOMENCLATURE FOR 'RANKIN'

VIST	Viscosity of refrigerant at 15 tabulated temperatures TT, centipoise
TT	15 temperatures at which viscosity VIST is given, °F
TTH	17 temperatures at which following saturated liquid and vapor properties are given, °F
HVT	Enthalpy of saturated vapor at temperatures TTH, Btu/lb
HLT	Enthalpy of saturated liquid at temperatures TTH, Btu/lb
PT	Saturation pressure at temperatures TTH, psia
RHOVT	Density of saturated vapor at temperatures TTH, lb/(cu ft)
CP	Specific heat of vapor at constant pressure, Btu/(°F)(lb)
GAMMA	Specific heat ratio of vapor
AK	Ratio of sonic velocity to square root of absolute temperature, ft/(sec) ($\sqrt{^{\circ}R}$)
MW	Molecular weight of refrigerant
DPP	HX pressure drop expressed as a fraction of inlet pressure
EFM	Mechanical efficiency of turbocompressor shaft, in fraction
QR	Refrigeration load, Btu/hr
RHOL	Liquid density, lb/(cu ft)
EFPUMP	Efficiency of liquid pump, in fraction



TABLE A-1 (Continued)

TITLE	Name of refrigerant
NTB	Number of boiler temperatures to be used (maximum of 8 allowed)
TBT	Boiler temperatures to be used, °F
NTC	Number of condenser temperatures to be used (maximum of 8 allowed)
TCT	Condenser temperatures to be used, °F
NTE	Number of evaporator temperatures to be used (maximum of 8 allowed)
TET	Evaporator temperatures to be used, °F
KCR	Control index for the type of condenser employed; 1 for dry condenser, 2 for wet condenser, 3 for condenser using a prehumidifier, 4 for water-cooled condenser in conjunction with a cooling tower
UAER	UA per sq ft front area for a dry condenser, Btu/(hr)(°F)(sq ft)
EFFAN	Fan efficiency (combined aerodynamic and electrical)
CPL	Specific heat of liquid refrigerant, Btu/(lb)(°F)
TG	Air temperatures at evaporator inlet, outlet, condenser inlet and outlet respectively, °F
TW	Wet bulb temperatures of air at evaporator inlet, outlet, condenser inlet and outlet respectively, °F
NDTE	Number of evaporator approach temperatures to be used (maximum of 5 allowed)
DTET	Evaporator approach temperatures to be used, °F
NDTB	Number of boiler temperatures to be used (maximum of 5 allowed)
DTBT	Boiler temperatures to be used, °F
NDTC	Number of condenser temperatures to be used (maximum of 5 allowed)
DTCT	Condenser temperatures to be used, °F
NTBIN	Number of boiler inlet hot water temperatures to be used (maximum of 5 allowed)
TBINT	Boiler inlet hot water temperatures to be used, °F
NTCIN	Number of condenser inlet cooling water temperatures to be used for the case KCR = 4 (maximum of 5 allowed)
TCINT	Condenser inlet cooling water temperatures to be used, °F





* ELT LAGINZ;1;750721; 65739 * 1

```
000001      SUBROUTINE LAGINZ(ID,X,NP,ND,XD,YD,Y)
000002      C      REVISED FOR FORTRAN IV R-8-65 S. WONG
000003      DIMENSION X(2), Y(2)
000004      C
000005          ILO=1
000006          IF(XD=X(1))10,16,4
000007      4      IF(XD=X(NP))19,13,7
000008          7      ILO=NP-1
000009          10     IHI=ILO+1
000010          GO TO 46
000011          13     ILO=NP
000012          16     YOMY(ILO)
000013          RETURN
000014          19     DO 22 ILO=2,NP
000015              IF(XD=X(ILO))25,16,22
000016          22     CONTINUE
000017          25     IHI=ILO
000018              ILO=IHI-1
000019              IF(ND=2)46,44,28
000020          28     DO 43 I=3,ND
000021              IF(ILO=1)40,40,31
000022          31     IF(IHI=NP)34,37,37
000023          34     IF (2.*XD=X(ILO-1)+X(IHI+1)) 37,37,40
000024          37     ILO=ILO-1
000025              GO TO 43
000026          40     IHI=IHI+1
000027          43     CONTINUE
000028          46     YD=0,0
000029              PN=1,0
000030              DO 49 I=ILO,IHI
000031          49     PN=PN*(XD=X(I))
000032              DO 58 I=ILO,IHI
000033              P=PN/(XD=X(I))
000034              DO 55 J=ILO,IHI
000035              IF(J=I)52,55,52
000036          52     P=P/(X(I)-X(J))
000037          55     CONTINUE
000038              YO=YO+P*Y(I)
000039          58     CONTINUE
000040          RETURN
000041      END
```

Figure A-1. Computer Program Listing



* ELT NEWTON+1,750721, 65740 , 1

```
000001      SUBROUTINE NEWTON(N1,NGO,X,Y,X0,Y0,XMIN,XMAX,ER)
000002      SFT N1=1 IN MAIN PROGRAM BEFORE CALL NEWTON. THE ROUTINE
000003      FINDS X FOR Y=0 GIVEN NGO=1 IF RECALCULATIONS REQUIRED,
000004      GIVES NGO=2 IF CONVERGENCE REACHED.
000005      C
000006      1 FORMAT (1H0,1EXCEEDED 20 ITERATIONS IN NEWTON!)
000007      2 FORMAT (10X,1X      X0      XS      Y      YO      SLOPE
000008      1      ER/1X,7G10.4)
000009      C
000010      N1=N1-1
000011      XS=X
000012      IF (ABS(Y)-ER) 8,8,5
000013      5 IF(N1)7,6,7
000014      6 YO=Y
000015      X0=X
000016      X=X0+(XMAX-XMIN)*0.01
000017      IF(X=XMAX)21,21,14
000018      14 X=X0+(XMAX-XMIN)*0.01
000019      GO TO 21
000020      7 SLOPE=(Y-Y0)/(X-X0)
000021      IF (SLOPE) 40,6,40
000022      40 YO=Y
000023      X0=X
000024      X=X+Y/SLOPE
000025      IF(N1+5)20,20,21
000026      20 X=0.5*(X+X0)
000027      IF(N1+20)22,22,21
000028      22 WRITE (6,1)
000029      WRITE (6,2) X,X0,XS,Y,Y0,SLOPE,ER
000030      N1=0
000031      ER=5.*ER
000032      21 CONTINUE
000033      IF(X=XMIN)11,11,12
000034      11 X=XMIN
000035      IF(X=X0)9,8,9
000036      12 IF(X=XMAX)9,13,13
000037      13 X=XMAX
000038      IF(X=X0)9,8,9
000039      9  NGO=1
000040      RETURN
000041      8  NGO=2
000042      N1=1
000043      RETURN
000044      END
```

Figure A-1. (Continued)



* FLT RANKIN:1,750730, 45327 : 1

```

000001 C MAIN PROGRAM FOR RANKINE REFRIGERATION CYCLE K.C. PHANG MAY 1975
000002 C
000003 DIMENSION A(15),T(15),W(15),P(15),R(15),DRP(15),RHO(15),VIST(15)
000004 DIMENSION TT(8),COND(5,4)
000005 DIMENSION TG(4),MG(4),DTHX(4),TW(4)
000006 REAL MTC,MH,NSNC,NBC,NC,NBT
000007 DIMENSION TTH(17),MVT(17),PT(17),RHOVT(17),HLT(17)
000008 DIMENSION TBT(8),TCT(8),TET(8)
000009 DIMENSION DTET(5),DTBT(5),DTCT(5),TRT(5),TCINT(5)
000010 DIMENSION RDATE(2),RTIME(2),DATIME(5)
000011 C
000012 DATA RTIME,RDATE /6H 2H 6H 3H /
000013 DATA DATIME /6HRUN ON,6H 6H A,6HT 6H /
000014 DATA (COND(I,1),I=1,5)/DRY CONDENSER EMPLOYED 1/
000015 DATA (COND(I,2),I=1,5)/
000016 1 WET CONDENSER EMPLOYED 1/
000017 DATA (COND(I,3),I=1,5)/PRECOOLER/HUMIDIFIER EMPLOYED 1/
000018 DATA (COND(I,4),I=1,5)/
000019 1 COOLING TOWER EMPLOYED 1/
000020 NAMELIST /INPUT/ VIST,TT,TTH,MVT,HLT,PT,RHOVT,CP,GAMMA,AK
000021 1,MH,DRP,EFM,WR,RHGL,EFUMP,TITLE,NTA,TRT,NTC,TCT,NTE,TET,
000022 2 KCR, UAER,EFFAN,CPL
000023 3,TG,TM,NDTE,DTET,NDTB,DTBT,NDTC,DTCT,NTRIN,TBINT,NTCIN,TCINT
000024 C
000025 C
000026 1 CONTINUE
000027 UAE=0.
000028 ZQ=0.
000029 READ (5,INPUT,END=150)
000030 NPAGE=0
000031 NM=0
000032 WRITE (3,2) TITLE,(COND(I,KCR), I=1,5)
000033 2 FORMAT (1H1,24X,15OLAR POWERED AIR CONDITIONING SYSTEM USING1
000034 1 4X,A6/25X,5A6//)
000035 WRITE(6,INPUT)
000036 DO 95 NTRIN=1,NTRIN
000037 TBIN=TBINT(NTRIN)
000038 C EVAPORATING TEMP VARIATION
000039 DO 95 NTE=1,NTE
000040 T(1)=TET(NE)
000041 T(5)=T(1)
000042 C CONDENSING TEMP VARIATION
000043 DO 95 NA=1,NTC
000044 T(4)=TCT(NA)
000045 DO 95 NB=1,NTR
000046 POWRCT=0.
000047 POWRWP=0.
000048 POWRFC=0.0
000049 DPCT=0.0
000050 FANCC=0.
000051 MTECR=0.
000052 T(7)=TBT(NB)
000053 C EVAPORATOR APPROACH TEMP
000054 DO 95 NDTB=1,NDTE
000055 DTHX(1)=DTET(NDTE1)
000056 DO 95 NDTB=1,NDTB
000057 DTHX(2)=DTBT(NDTB1)
000058 C CONDENSER APPROACH TEMP

```

Figure A-1. (Continued).



```
000059 DO 95 NDTCl=1,NDTC
000060 DTHX(3)=DTCT(NDTC1)
000061 IF(KCR,NE,4) GO TO 3
000062 DO 95 NTCIN=1,NTCIN
000063 TCIN=TCINT(NTCIN)
000064 3 CONTINUE
000065 KONT=0
000066 DO 701 K=1,3
000067 CALL LAGIN2(1,TTM,17,2,T(7),P(7),PT)
000068 CALL LAGIN2(2,TTM,17,2,T(1),P(1),PT)
000069 CALL LAGIN2(3,TTM,17,2,T(4),P(4),PT)
000070 P(6)=P(7)*(1,+DPP(2))
000071 P(5)=P(1)*(1,+DPP(1))
000072 P(3)=P(4)*(1,+DPP(3))
000073 P(2)=P(3)
000074 P(8)=P(3)
000075 CALL VAPOR(P(1),T(1),H(1),RHO(1))
000076 CALL VAPOR(P(7),T(7),H(7),RHO(7))
000077 CALL LAGIN2(4,TTM,17,2,T(4),H(4),HLT)
000078 H(5)=H(4)
000079 H(6)=H(4)
000080 Q(1)=QH
000081 H(1)=Q(1)/(H(1)-H(4))
000082 W(5)=W(1)
000083 W(2)=W(1)
000084 W(1)=W(1)/60.
000085 CALL TURCP(R(2),T(1),P(2),W(1),P(7),T(7),P(8),W7)
000086 W(7)=47 *60.
000087 CALL PHTR(P(2),H(2),T(2),HND(2))
000088 H(2)=H(1)+DHE/EFCF/778.3
000089 W(8)=W(7)
000090 H(6)=W(7)
000091 H(3)=W(2)+H(6)
000092 H(4)=W(3)
000093 H(1)=(W(2)+H(2)+W(8)+H(8))/(W(2)+W(8))
000094 CALL PHTR(P(3),H(3),T(3),RHO(3))
000095 Q(3)=W(3)*(H(3)-H(4))
000096 PUMP=P(6)+P(4)
000097 VL=W(6)/RHO(1) /3600.
000098 PWRLP=VL*PUMP*144./738/EFPUMP
000099 DQPWR=PWRLP*1.413
000100 H(6)=H(4)+DQPWR/W(6)
000101 T(6)=T(4)+DQPWR/(W(6)*CPL)
000102 Q(2)=W(6)*(H(7)-H(6))
000103 COP=Q(1)/(Q(2)+DQPWR)
000104 NAMELIST /CHECK/T,P,H,U,RHO,EFC,EFT,W,EFCF,PWRLP,COP
000105 701 CONTINUE
000106 CALL BOILER
000107 CALL EVAP
000108 CALL CONDSE(KCR)
000109 IF(KONT,NE,0) GO TO 95
000110 T3=TW(3)
000111 TW=TW(4)
000112 IF(KCR,EQ,4) T3=1.E20
000113 IF(KCR,EQ,4) TW=1.E20
000114 TGC=TG(3)
000115 TGH=TG(4)
000116 IF(KCR,EQ,3) TGC=TG3
000117 IF(KCR,EQ,4) TGC=TCIN
000118 IF(KCR,EQ,4) TGH=TCOUT
```

Figure A-1. (Continued)



```

000119 IF(KCR,F0,4) GC=CCOPL
000120 UA3=UAC
000121 IF(KCR,F0,2) UA3=0.0
000122 PCOP=(7)*(H(7)+H(8))/G(2)
000123 RCOPE=0(1)/(C*(1)*(H(7)+H(8)))
000124 COST1=COSTH+COSTE+CUSTC+100.+40.+FANCE+FANCC
000125 COSTF=1.65*COST1
000126 COSTU=6.13*COST1
000127 PTOT=POWRFE+POWRFC+POWRCT+POWRWP+POWRLP
000128 80 NPAGE=NPAGE+1
000129 CAL DATE (16,DATE)
000130 C TOP (28,DATE)
000131 WRITE (6,90) TITLE,(COND(1,KCR), I=1,5),DATE,NPAGE
000132 90 FORMAT(1H1//////// 24X, 'SOLAR POWERED AIR CONDITIONING SYSTEM USING
000133 11.4X,16/24X,546,15X,5A6,20X,1PAGE 1,13//
000134 2 T3, 'STATION/IN/IT15, 'TEMPERATURE/T3, 'PRESSURE/IT46, 'F
000135 [NTHALPY/IT61, 'FLOW RATE/IT78, 'DENSITY' /T18, 'DPT/IT33, 'PSTA'
000136 2T47, 'RTU/LH/IT63, '18/HR/IT78, 'LH/CO FT' /)
000137 DO 91 N=1,8
000138 WRITE(6,92)N,T(N),P(N),H(N),W(N),RHO(N)
000139 91 CONTINUE
000140 92 FORMAT(18,6F15,4)
000141 WRITE(6,97)
000142 97 FORMAT(/// HEAT HOT FLUID COLD FLUID
000143 1 UA WEIGHT COST FAN DP FAN POWER Q WET
000144 1BULB(F)1/
000145 1
000146 2LO TEMP(F) FLO TEMP(F) I EXCHANGER F
000147 3US S) (TN=H20) (WATT) (BTU/HR) IN (BTU/HR) (LB) (
000148 4 OUT1/
000149 5T (LB/HR) IN OUT (DEG F) HX FAN HX FAN1/)
000150 WRITE(6,98)G,TG(1),TG(2),W(5),T(5),T(1),UAE,WYE,WTFE,COSTE,FANCE,
000151 1 DPET,POWRFE
000152 1+Q(1),TW(1),TW(2)
000153 WRITE(6,99) WSAR,TBIN,TBOU,T(b),T(6),T(7),UAR,WR,ZR,COSTH,ZR,
000154 1ZR,IR,G(2)
000155 WRITE(6,102)W(3),T(3),T(4),GC,TGC,TG4,UA3,WTC,WTFE,COSTE,
000156 1FANCC,OPCT,POWRFC,Q(3),TW(3),TW(4)
000157 98 FORMAT( 1 'EVAP'
000158 1T10,F8,0,F8,1,F7,1,F8,0,F7,1,F6,1,F9,2,4F7,1,F4,2,F10,1,F11,0,
000159 2F7,1,F8,1)
000160 99 FORMAT( 1 'BOILER'
000161 1T10,F8,0,F8,1,F7,1,F8,0,F7,1,F6,1,F9,2,4F7,1,F4,2,F10,1,F11,0,
000162 2F7,1,F8,1)
000163 102 FORMAT( 1 'CONDENS'
000164 1T10,F8,0,F8,1,F7,1,F8,0,F7,1,F6,1,F9,2,4F7,1,F4,2,F10,1,F11,0,
000165 2F7,1,F8,1)
000166 WRITE(6,104)
000167 104 FORMAT(/// COEF OF PERFORMANCE/ T30, 'TURBO-COMPRESSOR/ T60, 'ELECT
000168 1RIC POWER REQD(WATT)1, 190, 'SYSTEM COST($)/ )
000169 WRITE(6,105)PCOP,DC,POWRFE,COSTF
000170 105 FORMAT( 1 'POWER COP1,115,F8,3,T30, 'COMPR DIA(IN)1 T45,F8,3,
000171 2T60, 'EVAP FAN1,T75,F8,3,T90, 'FACTORY COST 1,T105,F8,0)
000172 WRITE(6,106)RCOP,FFCF,POWRFE
000173 106 FORMAT( 1 'REFRIG COP1,T15,F8,3,T30, 'COMPR EFF1,T45,F8,3, 160, 'CONDENS
000174 1R FAN1,T75,F8,3)
000175 WRITE(6,107)COP,NC,POWRCT,COSTU
000176 107 FORMAT( 1 'SYSTEM COP1,T15,F8,3,T30, 'RPH1,T45,F8,0,T60, 'CL TOWER FAN
000177 1,T75,F8,3,T90, 'USER COST1,T105, F8,0)
000178 WRITE(6,108)OT,POWRWP

```

Figure A-1. (Continued)



```

000179      108 FORMAT(T30,1TURBN DIA(IN),T45,F8,3,T60,1WATER PUMPI,T75,F8,3)
000180      WRITE(6,109)EFT,PWRLP
000181      109 FORMAT(T30,1TURBN EFF1,T45,F8,3,T60,1FREFON PUMPI,T75,F8,3)
000182      WRITE(6,110)PTUT
000183      110 FORMAT(T60,1TOTAL1,T75,F8,3)
000184      95 CONTINUE
000185      GO TO 1
000186      150 STOP
C
C
C
000187      FUNCTION VISCF(T)
000188      CALL LAGIN2(8,TT,6,2,T,VISCF,VIST)
000189      VISCF=VISCF**6,7197E-4
000190      RETURN
C
C
C
000191      SUBROUTINE VAPOR(P,T,HV,RHOV)
000192      CALL LAGINZ(17,PT,17,2,P,HSV,HVT)
000193
000194      CALL LAGINZ(18,PT,17,2,P,RHOVS,RHOVT)
000195      CALL LAGIN2(19,PT,17,2,P,TS,TTH)
000196      HV=HSV+CP*(T-TS)
000197      RHOV=RHOVS*(TS+460.)/(T+460.)
000198      RETURN
C
C
C
000199      SUBROUTINE PHTR(P,H,T,RH)
000200      NI=1
000201      601 CONTINUE
000202      CALL VAPOR(P,T,NI,RH)
000203      DH1=H-NI
000204      ER=.005*H
000205      CALL NEWTON(NI,NGD,T,DH1,TU, DH10,=.40, .2R0, .FR)
000206      GO TO(601,602),NGD
000207      602 CONTINUE
000208      RETURN
C
C
C
000209      SUBROUTINE TURCPR(PCI,TCI,PCO,KC,PTI,TTI,PTO,W,T)
000210
000211      THIS IS TURBOCOMPRESSOR DESIGN ROUTINE
000212      PCI CCOMPRESSOR INLET PRESSURE
000213      TCI COMPRESSOR INLET TEMPERATURE
000214      PCO COMPRESSOR OUTLET PRESSURE
000215      KC COMPRESSOR MASS FLOW, Lb/MIN
000216      PTI TURBINE INLET PRESSURE
000217      TTI TURBINE INLET TEMPERATURE
000218      PTO TURBINE OUTLET PRESSURE
C
C
C
000219      DATA GG/32.17#/
000220      R=1.987/4K
000221      EK=GAMMA/(GAMMA-1.)
000222      EK1=1./EK
000223      DHC=EK**((T(1)+460.)*(P(2)/P(1))**EK1-1.)*778.3
000224      DHT=EK**((T(7)+460.)*(1.-P(8)/P(7))**EK1)*778.3
000225      RHOCCRHO(1)
000226      VISC=VISCF(T(1))
000227      UTC=SQRT(GG*DHC/0.60)
000228      SV=K*SQRT(TCI+460.)

```

Figure A-1. (Continued)



```

000239      NTC=UTC/SV
000240      VCI=C/(60,*RHQC)
000241      NSNC=SQRT(VCI)/60/(GG*DHC)**0.75
000242      NSC=0.02
000243      *T0=1.E+20
000244      10 CONTINUE
000245      NC=NSC/NSNC
000246      DC=UTC*720./(3.1416*NC)
000247      DIMENSION NSCT(50),ECT(50),MTCT(5)
000248      DATA NSCT/
000249      5.02, .04, .06, .08, .10, .12, .14, .16, .20, .25,
000250      3.02, .04, .06, .08, .10, .12, .14, .16, .20, .25,
000251      5.02, .04, .06, .08, .10, .12, .14, .16, .20, .25,
000252      3.02, .04, .06, .08, .10, .12, .14, .16, .20, .25,
000253      5.02, .04, .06, .08, .10, .12, .14, .16, .20, .25/
000254      DATA ECT/.65, .82, .86, .885, .90, .91, .92, .92, .92, .91,
000255      1.617, .78, .845, .87, .88, .89, .90, .9, .89, .88,
000256      2.57, .745, .81, .84, .85, .86, .865, .87, .87, .85,
000257      3.50, .70, .755, .79, .815, .82, .825, .825, .82, .80,
000258      4.42, .626, .70, .73, .75, .755, .76, .755, .74, .72/
000259      DATA MTCT/0., 0.2, .5, 1., 1.7!/
000260      EFS=XYZMAP(1,NSCT,ECT,10,MTCT,5,2,2,NSC,NTC,ANS)
000261      EFEFS=1.0
000262      C
000263      C EFFECT OF IMPELLER SIZE
000264      C
000265      DIMENSION DCT(7),EFEFST(7)
000266      DATA DCT/1., 1.5, 2., 2.5, 3., 3.5, 4./
000267      DATA EFEFST/.8, .88, .93, .965, .98, .99, 1./
000268      IF(DC.LT.4.)CALL LAGIN2(100,DCT,7,2,DC,FEFES,EFEFST)
000269      EFC=EFS*EFEFS
000270      C
000271      C CORRECT FOR REYNOLDS NUMBER
000272      C
000273      EFCF=EFC
000274      RE=UTC*RHQC*DC/(12.*VISC)
000275      IF(RE.LT.1.E6)
000276      1EFCF=1.*(1.+EFC)*(1.E+6/RE)**0.1
000277      HPC=NC*DHC/(EFCF*3300.)
000278      EFWT=NC*DHC/(EFCF*EFC*DHT)
000279      DATA EFT/.80/
000280      N1=1
000281      100 CONTINUE
000282      NT=EFWT/EFT
000283      DT=SQRT(GG*DHT)*720./(3.1416*NC)
000284      HTI=H(7)
000285      HTO=HTI*DHT*EFT/778.3
000286      H(8)=HTD
000287      CALL PHTR(P(8),H(8),T(8),RHO(8))
000288      RHDT=RHO(8)
000289      VISCT=VISC(T(8))
000290      YTO=NT/(60.*RHDT)
000291      C YOSCT=
000292      NST=NC*SQRT(YTO)/60./(GG*HMT)**.75
000293      DIMENSION NSTT(60),EFTT(60),DTT(6)
000294      DATA DTT/1.0, 1.5, 2.0, 3., 5., 6./
000295      DATA NSTT/
000296      5.0, .01, .02, .03, .04, .06, .08, .1, .12, .14,
000297      3.0, .01, .02, .03, .04, .06, .08, .1, .12, .14,
000298      5.0, .01, .02, .03, .04, .06, .08, .1, .12, .14.

```

Figure A-1. (Continued)



```

000299      5.0, .01, .02, .03, .04, .06, .08, .1, .12, .14,
000300      5.0, .01, .02, .03, .04, .06, .08, .1, .12, .14,
000301      5.0, .01, .02, .03, .04, .06, .08, .1, .12, .14/
000302      DATA FFTT/
000303      10.,0.,25.,425.,55.,697.,694.,731.,729.,715.,70.,
000304      20., 375.,544.,634.,696.,763.,746.,779.,763.,745.,
000305      30.,465.,615.,704.,757.,815.,835.,825.,806.,783.,
000306      40.,504.,855.,743.,796.,857.,880.,870.,852.,830.,
000307      5 0., .556, .70, .776, .830, .896, .918, .911, .894, .871,
000308      6 0., .556, .70, .776, .830, .896, .918, .911, .894, .871/
000309      EFT1=XYZHAPCI,ASTT,FFTT,10,DTT,6,2,2,NST,DT,ANS2)
000310      NET=24.*WT/(60.*VISC1*UT)
000311      IF(RET.LT. 2.E5) EFT1=1.-(1.-EFT1)*(.#+.6*(RET/2.FS)**-.2)
000312      DEFT=EXT-EFT1
000313      CALL NEWTON(N1,NGO,EFT,DEFT,EFTD,DEFD,.3511,.9255,.00519)
000314      GO TO (100,200),NGO
000315
C 200 CONTINUE
000316      IF(WT.GE.WT0) GO TO 201
000317      WTO=WT
000318      NSC=NSC+.005
000319      GO TO 10
000320
C 201 CONTINUE
000321      RETURN
000322
C 202 CONTINUE
000323      RETURN
000324
C
C
000326      FUNCTION HTYF(1)
000327      VP=VPP (1)
000328      HTYF=VP*18.0/((14.7-VP)*29.)
000329      RETURN
000330
C
C
000332      SUBROUTINE ROILER
000333      TROUT=T(7)+DTHX(2)
000334      NSAB=Q(2)/(TBIN-TROUT)
000335      DT1=TBIN-T(7)
000336      DT2=TROUT-T(7)
000337      IF((TBIN.LE.TROUT),OR.(DT1.LE.0.),OR.(DT2.LE.0.))GO TO 202
000338      DTB=TLAVG(DT1,DT2)
000339      HB=200.
000340      UAB=Q(2)/DTB
000341      AB=UAB/HB
000342      WTB1=AB*144.*.016*.321
000343      WTB=WTB1*2.00
000344      VOLB1=AB/150.
000345      VOLB=1.1*VOLB1
000346      CONSTB=1.53*WTB
000347      RETURN
000348      202 CONTINUE
000349      KONT=1
000350      RETURN
000351
C
C
000352      SUBROUTINE SURFT(TA,HTYA,TS,HTY)
000353
C
000354      TS=T(1)+0.6*(TA-T(1))
000355      N2=1
000356      177 CONTINUE
000357      HTY=HTYF(TS)
000358      UABL=UABR*2./0.27

```

Figure A-1. (Continued)



```
000359 QS=UAER*(TA-TS)*2.0
000360 QL=UAEL*(HTYA-HTY)*(0.0,
000361 DTI=(QL+QS)/(UAER*2)
000362 TS1=T(1)+DTI
000363 QTS=TS-TS1
000364 ER1=0.01*(TA-T(1))
000365 CALL NEWTON(N2,NG02,TA,DTB,TS0,DT50,T(1),TA,ER1)
000366 GO TO (777,778), NG02
000367 778 CONTINUE
000368 RETURN
000369 C
000370 SUBROUTINE FVAP
000371 C
000372 TG(2)=T(1)+DTHX(1)
000373 HWE=HWF(T(1))
000374 HG(1)=HWF(TX(1))
000375 DATA RNE/3./
000376 N3=1
000377 314 CONTINUE
000378 WBDRE=WDRF(RNE)
000379 TX(2)=TG(2)-(TG(1)-TX(1))*WBDRE
000380 HG(2)=HWF(TX(2))
000381 DHG=HG(1)-HG(2)
000382 G=G(1)/DHG
000383 RHQA=29./359.*(492./(TG(1)+460.))
000384 DH1=HG(1)-HWE
000385 DH2=HG(2)-HWE
000386 DHAVG=TLAVG(DH1,DH2)
000387 AFE=G/(500.*60.*RHQA)
000388 D1=330.*RNE*AFE*DHAVG
000389 DQ1=Q(1)-Q1
000390 ER3=Q(1)*0.005+1.E+20
000391 CALL NEWTON(N3,NG03,RNE,DQ1,RNE0,DQ10.,5,20.,ER3)
000392 GO TO (314,315), NG03
000393 315 CONTINUE
000394 QSENS=G*0.230*(TG(1)-TG(2))
000395 QLAT=Q(1)-QSENS
000396 RD=.866/12.
000397 VOLE=AFE*RNE*RD
000398 NTE=38.5*VOLE
000399 COSTE=.76*NTE
000400 DPE=1.367.088*RNE**746
000401 DPET=4./3.*DPE
000402 DPET=DPET+.15
000403 VAE=G/RHQA/3600.
000404 PUNRFE=VAE*DPET*5.20/.738/EFFA
000405 CFHE=G/RHQA/60.
000406 CALL FANHTC(CFHE,DPE,NTE,FANCE)
000407 FANCE=FANCE+10.+32.5*PUNRFE/1000.*0.7
000408 RETURN
000409 C
000410 SUBROUTINE CONDSR(KCR)
000411 C
000412 GO TO (161,162,173,174), KCR
000413 161 CONTINUE
000414 TG(4)=T(4)+DTHX(3)
000415 TX(4)=TX(3)
000416 DT1=T(4)-TG(3)
000417 DT2=T(4)-TG(4)
000418 IF(TG(4).LE.TG(3))GO TO 163
```

Figure A-1. (Continued)



```

000419 IF((DT1,LE,0.) .OR. (DT2,LE,0.)) GO TO 163
000420 DTC=TLAVG(DT1,DT2)
000421 UAC=B(3)/DTC
000422 GC=B(3)/0.23/(TG(4)-TG(3))
000423 RHUAC=29./359.0*(492./(TG(3)+460.))
000424 AFC=GC/(500.+60.*RHUAC)
000425 RNC=UAC/(UAER*AFC)
000426 RDR=866/12.0
000427 VOLC=AFC*RNC*RDR
000428 WTCORC=35.*VOLC
000429 WTC=1.1*WTCORC
000430 COSTC=0.76*WTC
000431 DPC= .088*RNC*.746
000432 GO TO 164
000433 C WET CONDENSER CALCS
000434 162 CONTINUE
000435 TG(4)=1.E20
000436 RHUAC=29./359.*(492./(TG(3)+460.))
000437 TW(4)=T(4)-DTHX(3)
000438 HG(4)=HWF(TW(4))
000439 HG(3)=HWF(TW(3))
000440 DHGC=HG(4)-HG(3)
000441 GC=B(3)/DHGC
000442 AC=B(3)/1000.
000443 N4=1
000444 ERC=.005*B(3)+1.E=20
000445 410 ACM=MAX(1.,AC/3.)
000446 ACX=5.*AC
000447 DTI=B(3)/300.00/AC
000448 THC=T(4)-DTI
000449 HHC=HWF(THC)
000450 DH1C=HHC-HG(3)
000451 DH2C=HHC-HG(4)
000452 IF((DHGC,LE,0.) .OR. (DH1C,LE,0.) .OR. (DH2C,LE,0.)) GO TO 163
000453 DHAVGC=TLAVG(DH1C,DH2C)
000454 GH=373.*DHAVGC*AC
000455 DQC=B(3)-GH
000456 CALL NEWTON(N4,NGO4,AC,DQC,AC0,DQC0,ACM,ACX,ERC)
000457 GO TO (410,411), NGO4
000458 411 CONTINUE
000459 WTC1=AC*144.*016*.321
000460 WTC=WTC1+3.00
000461 COSTC=.76*WTC
000462 COSTC=COSTC+40.
000463 DPC=0.50
000464 PR=RP=1.E=3*B(3)
000465 GO TO 164
000466 173 CONTINUE
000467 C HUMIDIFIER USED TO PRECOOL AIR FOR CONDENSER
000468 C
000469 TG3=TG(3)*.9*(TG(3)-TH(3))
000470 TG(4)=T(4)-DTHX(3)
000471 TW(4)=TW(3)
000472 DT1=T(4)-TG3
000473 DYT=T(4)-TG(4)
000474 DTHC=TG(4)-TG3
000475 IF(DTRC,LE,0.) GO TO 163
000476 IF((DT1,LE,0.) .OR. (DT2,LE,0.)) GO TO 163
000477 DTC=TLAVG(DT1,DT2)
000478 UAC=B(3)/DTC

```

Figure A-1. (Continued)



```

000479      GC=D(3)/.230/DTRC
000480      RHDAC=29./359.*(492./(TG3+460.))
000481      AFC=GC/(500.*60.*RHDAC)
000482      RHC=UAC/(UAER*AFC)
000483      RD=.866/12.0
000484      VOLC=AFC*RHC*RD
000485      WTCORC=35.*VOLC
000486      WTC=1.1*WTCORC
000487      CDSTC=.76*WTC
000488      CNSTC=CDSTC*1.20
000489      DPCR      .088*RHC**746+.10
000490      POWRHP=1.0E-3*Q(3)
000491      GO TO 164
000492      174 CONTINUE
000493      C
000494      C      COOLING TOWER EMPLOYED
000495      C
000496      C
000497      TCOUT =T(4)=DTMX(3)
000498      WCOOL=Q(3)/(TCOUT-TCIN)
000499      DT1=T(4)-TCIN
000500      DT2=T(4)-TCOUT
000501      IF((DT1.LE.0.) .OR. (DT2.LE.0.)) GO TO 163
000502      IF(WCOOL.LE.0.) GO TO 163
000503      DTC=TLAVG(DT1,DT2)
000504      HC=200.
000505      UAC=Q(3)/DTC
000506      AC=UAC/HC
000507      *TC1=AC*144.*.016*.321
000508      WTC=WTC1*2.000
000509      CNSTC=1.53*WTC+1.905E-3*Q(3)+40.
000510      POWRCT=2.96E-3*Q(3)
000511      POWRHP=1.9E-3*Q(3)
000512      RETURN
000513      C
000514      C
000515      C
000516      163 CONTINUE
000517      KONT=1
000518      RETURN
000519      164 CONTINUE
000520      DPCT=4./3.*DPC
000521      DPCT=DPCT+.15
000522      VAC=GC/RHDAC/3600.
000523      POWRFC=VAC*DPCT*5.20/.738/EFFAN
000524      CFHC=VAC*60.
000525      CALL FANWTC(CFHC,DPCT,WTC,FANCC)
000526      FANCC=FANCC+10.+52.5*POWRFC/1000.*.70
000527      RETURN
000528      C
000529      C
000530      FUNCTION WBDRT(RN)
000531      DIMENSION WBDRT(7),RNT(7)
000532      DATA RNT/0., 1.0, 2., 3., 6., 8., 10./
000533      DATA WBDRT/1.0, .667, .442, .306, .162, .112, .074/
000534      CALL LAGIN2(163,RNT,7,2,RN,WBDRT,WBDRT)
000535      RETURN
000536      C
000537      C
000538      FUNCTION HRF(TH)

```

Figure A-1. (Continued)



000539
000540
000541
000542
000543
000544
000545
000546
000547
000548
000549
000550
000551
000552
000553
000554
000555
000556

```
DIMENSION HWT(11), TWT(11)
DATA TWT/20., 30., 40., 50., 60., 70., 80., 90., 100., 110., 120./
DATA HWT/7.1, 10.9, 15.2, 20.3, 26.4, 34.1, 43.7, 55.9, 71.7, 92.3,
120.1/
CALL LAGIN2(164, TWT, 11, 2, 1, DWF, HWT)
RETURN
```

C
C

```
SUBROUTINE FANWTC(CFM, DP, HTF, FANCST)
DIMENSION OPT(5), DWT(5)
DATA OPT/.25, .50, 1.0, 2.0, 4.0/
DATA DWT/122., 106., 85., 50.5, 30.4/
CALL LAGIN2(191, OPT, 5, 2, DP, DWF, DWT)
HTF=10.0 + CFM*DWF/4000.
FANCST=2.20*HTF
FANCST=FANCST*0.40
RETURN
END
```

Figure A-1. (Continued)



RESEARCH MANUFACTURING COMPANY
OF CALIFORNIA

```

000001      C      UCC      81190      FUNCTION XYZMAP      STANG=HUI LIN (AM-303-4R) 10/00/66
000002      C      FUNCTION XYZMAP(INDX,X,Y,YP,Z,NC,IDX,IOY,HX,RY,ANS)
000003      C
000004      C      FUNCTION XYZMAP HAS THE CAPABILITY OF SUBROUTINES MAPRDY + LAGIN2,
000005      C      ANSWER IS ALSO AVAILABLE AT LOCATION (ANS),
000006      C      ALSO CAPABLE OF HANDLING MAP THAT HAS Z=LINES CROSSING EACH OTHER,
000007      C
000008      C      X=ARSSISA, Y=ORDINATE, Z=THIRD PARAMETER,
000009      C
000010      C      IND=0, Z=F(X,Y), (EQUIVALENT TO SUBROUTINE MAPRDY),
000011      C      IND=1, Y=F(X,Z), (EQUIVALENT TO SUBROUTINE MAPRDY),
000012      C      IND=1, Y=F(X) ONLY, (EQUIVALENT TO LAGIN2), THEN Z,NC,IOY, AND AY
000013      C      ARE DUMMY VARIABLES THAT ARE NOT NEEDED IN ACTUAL INTERPOLATION,
000014      C
000015      C      XS MUST BE STORED IN ASCENDING ORDER FOR EACH Z, SIMILARLY,
000016      C      SMALLEST Z RE FED IN AS Z(1), ZS ARE IN ASCENDING ORDER,
000017      C      XS NEED NOT BE THE SAME VALUES FOR VARIOUS ZS,
000018      C      X,Y AND Z ARE TO BE DIMENSIONED IN THE MAIN (OR CALLING) PROGRAM,
000019      C      THEY MUST BE DIMENSIONED NOT LESS THAN *** X(NP*NC), Y(NP*NC) AND
000020      C      Z(NC) *** NOTE NC MAY NOT BE GREATER THAN 20 ***
000021      C
000022      C      NP=NUMBER OF POINTS PER CURVE (OR NUMBER OF X,Y PAIRS FOR EACH Z),
000023      C      NC=NUMBER OF CURVES (OR NUMBER OF ZS), 1 TO A MAXIMUM OF 20.
000024      C
000025      C      IND=POINTS USED FOR INTERPOLATION IN X=DIRECTION,
000026      C      IOY=POINTS USED FOR INTERPOLATION IN Y=DIRECTION (IND=0),
000027      C      OR IN Z=DIRECTION (IND=1),
000028      C      IND OR IOY CAN EITHER BE 2 OR 3 ONLY,
000029      C      BX=FIRST INDEPENDENT VARIABLE,
000030      C      BY=SECOND INDEPENDENT VARIABLE, (WHEN IND=0 OR 1 ONLY),
000031      C      BY=Y INDEPENDENT VARIABLE, WHEN (IND=0),
000032      C      BY=Z INDEPENDENT VARIABLE, WHEN (IND=1),
000033      C      ANS=DEPENDENT VARIABLE Z(X=AX,Y=AY), WHEN IND=0,
000034      C      ANS=DEPENDENT VARIABLE Y(X=AX,Z=AY), WHEN IND=1,
000035      C      ANS=DEPENDENT VARIABLE Y(X=AX), WHEN IND=1,
000036      C
000037      C      NO PRINT OUT, IF DATA OFF THE RANGE OF MAP OR CURVE,
000038      C      THEN, USE Z=POINT INTERPOLATIONS AUTOMATICALLY,
000039      C
000040      C      *****
000041      C      XB, YB, AND ZB ARE READ IN IN MAIN PROGRAM RECOMMENDED AS FOLLOWS:
000042      C4100 FORMAT(8I10) *****
000043      C4101 FORMAT(8F10,0) *****
000044      C ***** FOR IND=0 OR 1 *****
000045      C4101 READ (5,4100) NP,NC *****
000046      C DD 100 N=1,NC *****
000047      C READ (5,4101) Z(N) *****
000048      C MF=NP *****
000049      C M=ME=NP+1 *****
000050      C 100 READ (5,4101) (X(M),Y(M),M=MS,ME) *****
000051      C ***** FOR IND=1 *****
000052      C READ (5,4100) NP *****
000053      C READ (5,4101) (X(M),Y(M),M=1,NP) *****
000054      C *****
000055      C
000056      C      DIMENSION X(2),Y(2),Z(2),ZZ(20),ZX(20)
000057      C      JS=1
000058      C      IF (IND) 105,106,103
    
```

REPRODUCIBILITY OF THE
ORIGINAL PAGE IS POOR

Figure A-1. (Continued)



```
000059      103 DO 104 I=1,NC
000060      104 ZX(I)=Z(I)
000061          GO TO 141
000062      105 JF=1
000063          GO TO 108
000064      106 DO 107 I=1,NC
000065      107 ZZ(I)=Z(I)
000066          JE=NC
000067          NCROSS=0
000068      108 DO 126 J=JS,JF
000069          JX2=(J-1)*NP
000070          DO 109 I=1,MP
000071              J2=I+JX2
000072              IF (BX=X(J2)) 114,110,109
000073      109 CONTINUE
000074          GO TO 119
000075      110 ANS=Y(J2)
000076          GO TO 123
000077      114 IF (I-IDX)120,120,119
000078      119 JX2=J2-IDX
000079      120 IS=JX2+1
000080          IE=JX2+IDX
000081          IF (IDX,GT,2) GO TO 122
000082      121 ANS=(Y(IE)*(BX=X(IS))-Y(IS)*(BX=X(IE)))/(X(IE)-X(IS))
000083          GO TO 123
000084      122 IM=IS+1
000085          G1=(BX=X(IS))/(X(IM)-X(IE))
000086          G2=(BX=X(IM))/(X(IE)-X(IS))
000087          G3=(BX=X(IE))/(X(IS)-X(IM))
000088          ANS=Y(IS)*G2+G3-G1*(Y(IM)*G3+Y(IE)*G2)
000089      123 IF (IND) 158,125,124
000090      124 ZZ(J)=ANS
000091          GO TO 126
000092      125 ZX(J)=ANS
000093          IF (ANS,LT,ZX(I)) NCROSS=1
000094      126 CONTINUE
000095          IF (IND,NE,0) GO TO 1151
000096          IF (NCROSS,EQ,0) GO TO 141
000097      C
000098          DO 130 K=2,NC
000099          JMIN=K-1
000100          DO 129 IP=K,NC
000101              IF (ZX(IP)=ZX(JMIN)) 128,128,129
000102      128 JMIN=IP
000103      129 CONTINUE
000104          IK=K-1
000105          CI=ZX(JMIN)
000106          ZI=ZZ(JMIN)
000107          ZX(JMIN)=ZX(IK)
000108          ZZ(JMIN)=ZZ(IK)
000109          ZX(IK)=CI
000110          ZZ(IK)=ZI
000111      C
000112      141 ICPY= IOY-1
000113          DO 142 I=1,NC
000114              IF (BY=ZX(I))145,144,142
000115      142 CONTINUE
000116          JS=NC-ICPY
000117          GO TO 147
000118      144 JS=J
```

Figure A-1. (Continued)



```
000119      IF (IND.EQ.0) GO TO 151
000120      JF=JS
000121      GO TO 108
000122      145 IF(I.LF.IBY) GO TO 147
000123      146 JS=J+ICPY
000124      147 JE=JS+ICPY
000125      IF (IND) 108,1152,108
000126      C      YWF(X+Z) OR ZWF(X+Y) CALCULATION DEPENDING ON IND=0 OR 1,
000127      151 ANS=ZZ(JS)
000128      GO TO 158
000129      1151 IF(JE.EQ.JS) GO TO 151
000130      1152 IF(IHY.GT.2) GO TO 153
000131      152 ANS=(ZZ(JE)*(BY=ZX(JS))-ZZ(JS)*(BY=ZX(JE)))/(ZX(JE)-ZX(JS))
000132      GO TO 158
000133      153 JH=JS+1
000134      G1=(BY=ZX(JS))/(ZX(JH)-ZX(JE))
000135      G2=(BY=ZX(JH))/(ZX(JE)-ZX(JS))
000136      G3=(BY=ZX(JE))/(ZX(JS)-ZX(JH))
000137      ANS=ZZ(JS)*G2+G3-G1*(ZZ(JH)*G3+ZZ(JE)*G2)
000138      158 XYZMAP=ANS
000139      RETURN
000140      END
```

Figure A-1. (Continued)



AIRESEARCH MANUFACTURING COMPANY
OF CALIFORNIA

• ELT TLAVG,1,750721, 65748 , 1

```
000001      FUNCTION TLAVG(OT1,OT2)
000002      TLAVG=(OT1-OT2)/ALOG(OT1/OT2)
000003      RETURN
000004      END
```

Figure A-1. (Continued)



* ELT VPP,1,750721, 65749 * 1

```
000001      FUNCTION VPP(T)
000002      C      FUNCTION TO CALCULATE VAPOR PRESSURE OF WATER AT T
000003      C      T=TEMP DEG F.
000004      C      VPP=VAPOR PRESS OF WATER PSIA
000005      X=47.27*(T+460.)/1.8
000006      TEMP=X*1.8/(T+460.)*(3.244+5.868E-3*X+1.170E-8*X**3)/(1.+2.188E-3*
000007      1X)
000008      VPP=3207./10.**TEMP
000009      RETURN
000010      END
```

1234 CARDS WRITTEN IN RANKIN/KCHB (718 COMPRESSED CARD IMAGES)
2 BLOCKS ACQUIRED (KEY = 0101)

END CUR

Figure A-1. (Continued)

APPENDIX B

COMPUTER INPUT/OUTPUT DATA FOR SOLAR-POWERED AIR CONDITIONING SYSTEM CONCEPTS

This appendix contains computer input and output data for the four system concepts defined in Figure 1. The data presented are in english units. Input data units are defined in Appendix A, and output data units are given on the printouts. The data are presented as follows:

- Figure B-1. Input Data, Concept A
- Figure B-2. Output Data, Concept A
- Figure B-3. Input Data, Concept B
- Figure B-4. Output Data, Concept B
- Figure B-5. Input Data, Concept C
- Figure B-6. Output Data, Concept C
- Figure B-7. Input Data, Concept D
- Figure B-8. Output Data, Concept D





SOLAR POWERED AIR CONDITIONING SYSTEM USING R-11
DRY CONDENSER EMPLOYED

\$INPUT				
VIST	■	■	■	■
	.95000000+02;	.10250000+01;	.11000000+01;	.11600000+01;
	.12250000+01;	.12820000+01;	.13400000+01;	.13900000+01;
	.00000000+00;	.00000000+00;	.00000000+00;	.00000000+00;
	.00000000+00;	.00000000+00;	.00000000+00;	.00000000+00;
TT	■	■	■	■
	.00000000+00;	.40000000+02;	.80000000+02;	.12000000+03;
	.16000000+03;	.20000000+03;	.24000000+03;	.28000000+03;
TTM	■	■	■	■
	.40000000+02;	.20000000+02;	.00000000+00;	.20000000+02;
	.40000000+02;	.60000000+02;	.80000000+02;	.10000000+03;
	.12000000+03;	.14000000+03;	.16000000+03;	.18000000+03;
	.20000000+03;	.22000000+03;	.24000000+03;	.26000000+03;
	.28000000+03;			
MVT	■	■	■	■
	.87529999+02;	.89949999+02;	.92419999+02;	.94889999+02;
	.97389999+02;	.99879999+02;	.10235999+03;	.10480999+03;
	.10721999+03;	.10958999+03;	.11187999+03;	.11406999+03;
	.11616999+03;	.11812999+03;	.11991999+03;	.12151999+03;
	.12284999+03;			
HLT	■	■	■	■
	.00000000+00;	.39840000+01;	.79899999+01;	.12030000+02;
	.16120000+02;	.20270000+02;	.24480000+02;	.28750000+02;
	.33080000+02;	.37480000+02;	.41950000+02;	.46470000+02;
	.51070000+02;	.55760000+02;	.60530000+02;	.65459999+02;
	.70569999+02;			
PT	■	■	■	■
	.73869999+00;	.14190000+01;	.25540000+01;	.43419999+01;
	.70299999+01;	.10910000+02;	.16310000+02;	.23600000+02;
	.33180000+02;	.45500000+02;	.61010000+02;	.80179999+02;
	.10352999+03;	.13158000+03;	.16487000+03;	.20397000+03;
	.24947000+03;			
RHOVT	■	■	■	■
	.22600000+01;	.41539999+01;	.71709999+01;	.11739999+00;
	.18350000+00;	.27590000+00;	.40100000+00;	.56630000+00;
	.78009999+00;	.10520000+01;	.13920000+01;	.18148000+01;
	.23330000+01;	.29680000+01;	.37440000+01;	.46960000+01;
	.58800000+01;			
CP	■			
	.14000000+00;			
GAMMA	■			
	.11100000+01;			
AK	■			
	.19800000+02;			
TR	■			
	.16500000+03;			
TE	■			
	.40000000+02;			
TC	■			
	.10500000+03;			
MH	■			
	.13740000+03;			
DPP	■	■	■	■
	.49999999+01;	.49999999+01;	.49999999+01;	.49999999+01;
	.49999999+01;	.49999999+01;	.49999999+01;	.49999999+01;
	.49999999+01;	.49999999+01;	.49999999+01;	.49999999+01;
	.49999999+01;	.49999999+01;	.49999999+01;	.49999999+01;
EFF	■			
	.89999999+00;			
QR	■			
	.36000000+03;			
RHQL	■			
	.91000000+02;			
EFFPUMP	■			
	.50000000+00;			
TITLE	■			
	.25018020+18;			
NTB	■			
	1;			
TBT	■	■	■	■
	.18500000+03;	.18500000+03;	.18000000+03;	.19000000+03;
	.00000000+00;	.00000000+00;	.00000000+00;	.00000000+00;
NTC	■			
	1;			
TCT	■	■	■	■
	.11500000+03;	.11500000+03;	.12000000+03;	.12500000+03;
	.00000000+00;	.00000000+00;	.00000000+00;	.00000000+00;
NTE	■			
	1;			
TET	■	■	■	■
	.45000000+02;	.50000000+02;	.80000000+00;	.00000000+00;

Figure B-1. Input Data - Concept A



XCR	■	.00000000+00,	.00000000+00,	.00000000+00,	.00000000+00,
YBIN	■	.20000000+03,			
UAER	■	.11800000+03,			
EFFAN	■	.49000000+00,			
CPL	■	.21000000+00,			
TG	■	.80000000+02,	.00000000+00,	.95000000+02,	.00000000+00,
TH	■	.67000000+02,	.00000000+00,	.75000000+02,	.00000000+00,
NDYE	■	.10000000+02,	.75000000+01,	.20000000+02,	.12500000+02,
DTET	■	.15000000+02,			
NDYB	■	.75000000+01,	.10000000+02,	.15000000+02,	.00000000+00,
DTBT	■	.00000000+00,			
NDYC	■	.10000000+02,	.15000000+02,	.00000000+00,	.00000000+00,
DTCT	■	.00000000+00,			
NTBIN	■	.20000000+03,	.00000000+00,	.00000000+00,	.00000000+00,
TBINT	■	.00000000+00,			
NTGIN	■	.80000000+02,	.85000000+02,	.00000000+00,	.00000000+00,
TCINT	■	.00000000+00,			
SEND					

Figure B-1 (Continued)



8CLAR POWERED AIR CONDITIONING SYSTEM USING
DRY CONDENSER EMPLOYED

H=11
RUN ON 26 JUL 75 AT 15:38:47

STATION/ID	TEMPERATURE DEG F	PRESSURE PSIA	ENTHALPY BTU/LB	FLOW RATE LB/HR	DENSITY LB/CU FT
1	45.0000	8.0000	98.0125	545.3306	.2066
2	164.3327	32.3242	113.4615	545.3306	.7088
3	134.5551	32.3242	109.2925	1881.9654	.7401
4	115.0000	30.7850	31.9975	1881.9654	.0000
5	45.0000	8.4000	31.9975	545.3306	.0000
6	116.1524	90.3184	32.2395	1336.6346	.0000
7	185.0000	86.0175	114.5950	1336.6346	1.9437
8	122.7124	32.3242	107.5917	1336.6346	.7551

HEAT EXCHANGER	HOT FLUID FLO TEMP(F)		COLD FLUID FLO TEMP(F)		UA (BTU/HR/ DEG F)	WEIGHT (LB) HX	COST (US \$) HX	FAN OP (IN=H2O) FAN	FAN POWER (WATT) FAN	Q (BTU/HR)	WET BULB(F)					
	(LB/HR)	IN	OUT	(LB/HR)							IN	OUT	IN	OUT		
EVAP	3815.	80.0	55.0	545.	45.0	45.0	.00	35.8	32.6	27.2	42.7	.86	179.0	34000.	67.0	53.4
BOILER	14677.	200.0	192.5	1337.	116.2	185.0	10173.48	75.2	.0	114.1	.0	.00	.0	110079.		
CONDNSR	1882.	134.6	115.0	63246.	95.0	105.0	10082.98	237.4	421.3	180.4	413.7	.41	1445.7	145467.	75.0	75.0

COEF OF PERFORMANCE		TURBO-COMPRESSOR		ELECTRIC POWER RECD(WATT)		SYSTEM COST(\$)	
POWER COP	.085	COMPR DIA(IN)	2.437	EVAP FAN	178.997	FACTORY COST	1517.
REFRIG COP	4.273	COMPR EFF	.708	CONDNSR FAN	1445.722	USER COST	5634.
SYSTEM COP	.326	RPM	58722.	CL TOWER FAN	.000		
		TURBN DIA(IN)	1.822	WATER PUMP	.000		
		TURBN EFF	.805	FREON PUMP	94.791		
				TOTAL	1719.510		

Figure B-2. Output Data - Concept A



AIRESEARCH MANUFACTURING COMPANY
OF CALIFORNIA

SOLAR POWERED AIR CONDITIONING SYSTEM USING R=11
PRECOOLER/HUMIDIFIER EMPLOYED

SIAPUT					
VIST	■	.95000000-02;	.10250000+01;	.11000000+01;	.11600000+01;
		.12250000+01;	.12820000+01;	.13400000+01;	.13900000+01;
		.00000000+00;	.00000000+00;	.00000000+00;	.00000000+00;
		.00000000+00;	.00000000+00;	.00000000+00;	.00000000+00;
TT	■	.00000000+00;	.40000000+02;	.80000000+02;	.12000000+03;
		.16000000+03;	.20000000+03;	.24000000+03;	.28000000+03;
TYH	■	.40000000+02;	.20000000+02;	.00000000+00;	.20000000+02;
		.40000000+02;	.60000000+02;	.80000000+02;	.10000000+03;
		.12000000+03;	.14000000+03;	.16000000+03;	.18000000+03;
		.20000000+03;	.22000000+03;	.24000000+03;	.26000000+03;
		.28000000+03;			
HVT	■	.87529999+02;	.89949999+02;	.92419999+02;	.94889999+02;
		.97389999+02;	.99879999+02;	.10235999+03;	.10480999+03;
		.10721999+03;	.10958999+03;	.11187999+03;	.11406999+03;
		.11616999+03;	.11812999+03;	.11991999+03;	.12151999+03;
		.12284999+03;			
HLT	■	.00000000+00;	.39800000+01;	.79899999+01;	.12030000+02;
		.16120000+02;	.20270000+02;	.24480000+02;	.28750000+02;
		.33080000+02;	.37400000+02;	.41950000+02;	.46470000+02;
		.51070000+02;	.55740000+02;	.60530000+02;	.65459999+02;
		.70569999+02;			
PT	■	.71869999+00;	.14190000+01;	.25580000+01;	.43419999+01;
		.70299999+01;	.10910000+02;	.16310000+02;	.23600000+02;
		.33180000+02;	.45500000+02;	.61010000+02;	.80179999+02;
		.10352999+03;	.13158000+03;	.16487000+03;	.20397000+03;
		.24947000+03;			
RHOVT	■	.22600000+01;	.41539999+01;	.71709999+01;	.11739999+00;
		.18350000+00;	.27390000+00;	.40100000+00;	.56630000+00;
		.78009999+00;	.10520000+01;	.13920000+01;	.18140000+01;
		.23330000+01;	.29680000+01;	.37440000+01;	.46960000+01;
		.58800000+01;			
CP	■	.14000000+00;			
GAMMA	■	.11100000+01;			
AK	■	.19800000+02;			
TB	■	.16500000+03;			
TE	■	.40000000+02;			
TC	■	.10500000+03;			
MX	■	.13740000+03;			
DPP	■	.49999999+01;	.49999999+01;	.49999999+01;	.49999999+01;
		.49999999+01;	.49999999+01;	.49999999+01;	.49999999+01;
		.49999999+01;	.49999999+01;	.49999999+01;	.49999999+01;
		.49999999+01;	.49999999+01;	.49999999+01;	.49999999+01;
EFH	■	.89999999+00;			
QR	■	.36000000+03;			
RMOL	■	.91000000+02;			
EFFUMP	■	.50000000+00;			
TITLE	■	.25618020+18;			
NTB	■	1;			
TBT	■	.18500000+03;	.18500000+03;	.18000000+03;	.19000000+03;
		.00000000+00;	.00000000+00;	.00000000+00;	.00000000+00;
NTC	■	1;			
TCT	■	.10000000+03;	.11500000+03;	.12000000+03;	.12500000+03;
		.00000000+00;	.00000000+00;	.00000000+00;	.00000000+00;
NTE	■	1;			
TET	■	.45000000+02;	.50000000+02;	.00000000+00;	.00000000+00;

Figure B-3. Input Data - Concept B



KCR	*	.00000000+00,	.00000000+00,	.00000000+00,	.00000000+00,
TPIN	*	3,			
UAER	*	.20000000+03,			
EFFAN	*	.11800000+03,			
CPL	*	.49000000+00,			
TG	*	.21000000+00,			
T*	*	.80000000+02,	.55000000+02,	.95000000+02,	.10500000+03,
NDTE	*	.47000000+02,	.53368063+02,	.75000000+02,	.75000000+02,
DTET	*	1,			
NDTB	*	.10000000+02,	.75000000+01,	.20000000+02,	.12500000+02,
DTBT	*	.15000000+02,			
NDTC	*	1,			
DTCT	*	.75000000+01,	.10000000+02,	.15000000+02,	.00000000+00,
NTBIN	*	.00000000+00,			
TBINT	*	1,			
NTCIN	*	.10000000+02,	.15000000+02,	.00000000+00,	.00000000+00,
TCINT	*	.00000000+00,			
END	*	1,			
	*	.20000000+03,	.00000000+00,	.00000000+00,	.00000000+00,
	*	.00000000+00,			
	*	2,			
	*	.80000000+02,	.85000000+02,	.00000000+00,	.00000000+00,
	*	.00000000+00,			

Figure B-3 (Continued)



AIR RESEARCH MANUFACTURING COMPANY
OF CALIFORNIA

SOLAR POWERED AIR CONDITIONING SYSTEM USING R-11
PRECOOLER/HUMIDIFIER EMPLOYED RUN ON 28 JUL 75 AT 15:38:48

PAGE 1

STATION/ID	TEMPERATURE DEG F	PRESSURE PSIA	ENTHALPY BTU/LB	FLOW RATE LB/HR	DENSITY LB/CU FT
1	45.0000	8.0000	98.0125	519.7418	.2066
2	137.8871	24.7800	110.0661	519.7618	.5575
3	120.1193	24.7800	107.5787	1327.6260	.5746
4	100.0000	23.8000	28.7500	1327.6260	.0000
5	45.0000	8.4000	28.7500	519.7618	.0000
6	101.2917	90.3184	29.0213	807.8642	.0000
7	185.0000	86.0175	114.5950	807.8642	1.9437
8	111.4324	24.7800	105.9783	807.8642	.5833

HEAT EXCHANGER	HOT FLUID		COLD FLUID		UA		WEIGHT		COST		FAN DP		FAN POWER		WET BULB(F)	
	FLO (LB/HR)	TEMP(F) IN OUT	FLO (LB/HR)	TEMP(F) IN OUT	(BTU/HR/ (DEG F)	HX	(LB) FAN	HX	(US \$) FAN	(IN=H2O)	(WATT)	(BTU/HR)	IN	OUT		
EVAP	3815.	80.0 55.0	520.	45.0 45.0	.00	35.8	32.6	27.2	42.7 .86	179.0	38000.	67.0	53.4			
BOILER	9218.	200.0 192.5	808.	101.3 185.0	6389.15	47.3	.0	72.3	.0 .00	.0	69132.					
CONDNSR	1328.	120.1 100.0	35002.	77.0 90.0	6705.24	157.9	211.5	144.0	221.5 .59	1112.1	104655.	75.0	75.0			

COEF OF PERFORMANCE

POWER COP .101
REFRIG COP 5.746
SYSTEM COP .519

TURBO-COMPRESSOR

COMPR DIA(IN) 2.242
COMPR EFF .725
RPM 61716.
TURBN DIA(IN) 1.942
TURBN EFF .789

ELECTRIC POWER REQD(WATT)

EVAP FAN 178.997
CONDNSR FAN 1112.104
CL TOWER FAN .000
WATER PUMP 104.655
FREFN PUMP 64.206
TOTAL 1459.962

SYSTEM COST(\$)

FACTORY COST 1069.
USER COST 3970.

Figure B-4. Output Data - Concept B



AIRESEARCH MANUFACTURING COMPANY
OF CALIFORNIA

SOLAR POWERED AIR CONDITIONING SYSTEM USING R=11
NET CONDENSER EMPLOYED

SIAPUT					
VIST	*	.95000000+02,	.10250000+01,	.11000000+01,	.11600000+01,
		.12250000+01,	.12820000+01,	.13400000+01,	.13900000+01,
		.00000000+00,	.00000000+00,	.00000000+00,	.00000000+00,
		.00000000+00,	.00000000+00,	.00000000+00,	.00000000+00,
TT	*	.00000000+00,	.40000000+02,	.80000000+02,	.12000000+03,
		.16000000+03,	.20000000+03,	.24000000+03,	.28000000+03,
TTM	*	.40000000+02,	.20000000+02,	.00000000+00,	.20000000+02,
		.40000000+02,	.60000000+02,	.80000000+02,	.10000000+03,
		.12000000+03,	.14000000+03,	.16000000+03,	.18000000+03,
		.20000000+03,	.22000000+03,	.24000000+03,	.26000000+03,
		.28000000+03,			
HVT	*	.87529999+02,	.89949999+02,	.92419999+02,	.94889999+02,
		.97389999+02,	.99879999+02,	.10235999+03,	.10480999+03,
		.10721999+03,	.10958999+03,	.11187999+03,	.11406999+03,
		.11616999+03,	.11812999+03,	.11991999+03,	.12151999+03,
		.12284999+03,			
HLT	*	.00000000+00,	.39800000+01,	.79899999+01,	.12030000+02,
		.16120000+02,	.20270000+02,	.24480000+02,	.28750000+02,
		.33080000+02,	.37480000+02,	.41950000+02,	.46470000+02,
		.51070000+02,	.55760000+02,	.60530000+02,	.65459999+02,
		.70369999+02,			
PT	*	.73869999+00,	.14190000+01,	.25540000+01,	.43419999+01,
		.70299999+01,	.10910000+02,	.16310000+02,	.23600000+02,
		.33180000+02,	.45500000+02,	.61010000+02,	.80179999+02,
		.10352999+03,	.13158000+03,	.16487000+03,	.20397000+03,
		.24947000+03,			
RMDVT	*	.22600000+01,	.41539999+01,	.71709999+01,	.11739999+00,
		.18350000+00,	.27590000+00,	.40100000+00,	.56630000+00,
		.78009999+00,	.10520000+01,	.13920000+01,	.18140000+01,
		.23330000+01,	.29680000+01,	.37440000+01,	.46960000+01,
		.58800000+01,			
CP	*	.14000000+00,			
GAMMA	*	.11100000+01,			
AK	*	.19800000+02,			
TB	*	.16500000+03,			
YE	*	.40000000+02,			
YC	*	.10500000+03,			
MW	*	.13740000+03,			
DPP	*	.49999999+01,	.49999999+01,	.49999999+01,	.49999999+01,
		.49999999+01,	.49999999+01,	.49999999+01,	.49999999+01,
		.49999999+01,	.49999999+01,	.49999999+01,	.49999999+01,
		.49999999+01,	.49999999+01,	.49999999+01,	.49999999+01,
EFM	*	.89999999+00,			
QR	*	.36000000+03,			
RHOL	*	.91000000+02,			
EFFUMP	*	.50000000+00,			
TITLE	*	.25618020+16,			
NTB	*	.			
TBT	*	.18500000+03,	.18500000+03,	.18000000+03,	.19000000+03,
		.00000000+00,	.00000000+00,	.00000000+00,	.00000000+00,
NTC	*	1,			
TCT	*	.90000000+02,	.11500000+03,	.12000000+03,	.12500000+03,
		.00000000+00,	.00000000+00,	.00000000+00,	.00000000+00,
NTE	*	1,			
TET	*	.45000000+02,	.50000000+02,	.00000000+00,	.00000000+00,

Figure B-5. Input Data - Concept C



KCR	■	.00000000+00,	.00000000+00,	.00000000+00,	.00000000+00,
		2,			
TBIN	■	.20000000+03,			
UAEW	■	.11800000+03,			
EFFAK	■	.49000000+00,			
CPL	■	.21000000+00,			
TG	■	.80000000+02,	.00000000+00,	.95000000+02,	.00000000+00,
TH	■	.67000000+02,	.00000000+00,	.75000000+02,	.00000000+00,
NDTE	■	1,			
DTET	■	.10000000+02,	.75000000+01,	.20000000+02,	.12500000+02,
		.15000000+02,			
NDTB	■	1,			
DTBT	■	.75000000+01,	.10000000+02,	.15000000+02,	.00000000+00,
		.00000000+00,			
NDTC	■	1,			
DTCT	■	.10000000+02,	.15000000+02,	.00000000+00,	.00000000+00,
		.00000000+00,			
NTBIN	■	1,			
TBINT	■	.20000000+03,	.00000000+00,	.00000000+00,	.00000000+00,
		.00000000+00,			
NTCIN	■	2,			
TCINT	■	.80000000+02,	.85000000+02,	.00000000+00,	.00000000+00,
		.00000000+00,			
SEND					

Figure B-5 (Continued)



AIRESEARCH MANUFACTURING COMPANY
OF CALIFORNIA

SOLAR POWERED AIR CONDITIONING SYSTEM USING
WET CONDENSER EMPLOYED

R=11
RUN ON 28 JUL 75 AT 10:14:38

PAGE 1

STATION/ID	TEMPERATURE DEG F	PRESSURE PSIA	ENTHALPY BTU/LB	FLOW RATE LB/HR	DENSITY LB/CU FT
1	45.0000	8.0000	98.0125	504,2193	.2066
2	122.1692	20.9527	108.0408	504,2193	.4807
3	110.8671	20.9527	106.4585	1096.6669	.4902
4	90.0000	19.9550	26.6150	1096.6669	.0000
5	45.0000	8.4000	26.6150	504,2193	.0000
6	91.3622	90.3184	26.9011	592,4476	.0000
7	185.0000	86.0175	114.5950	592,4476	1.9437
8	101.2450	20.9527	105.1118	592,4476	.4986

HEAT EXCHANGER	HOT FLUID		COLD FLUID		UA (BTU/HR/ DEG F)	WEIGHT (LB)		COST (US \$)		FAN DP (IN-H2O)	FAN POWER (WATT)	Q (BTU/HR)	WET BULB(F)	
	FLO (LB/HR)	TEMP(F) IN OUT	FLO (LB/HR)	TEMP(F) IN OUT		HX	FAN	HX	FAN				IN	OUT
EVAP	3815.	80.0 55.0	504.	45.0 45.0	.00	35.8	32.6	27.2	42.7 .86		179.0	36000.	67.0	53.4
BOILER	6927.	200.0 192.5	592.	91.4 185.0	4801.57	35.5	.0	54.3	.0 .00		.0	51954.		
CONDNSR	1097.	110.9 90.0	18242.	95.0*****	.00	91.8	108.4	109.8	124.3 .82		831.0	87562.	75.0	80.0

COEF OF PERFORMANCE		TURBO-COMPRESSOR		ELECTRIC POWER REQD(WATT)		SYSTEM COST(\$)	
POWER COP	.108	COMPR DIA(IN)	2.176	EVAP FAN	178.997	FACTORY COST	622.
REFRIG COP	7.120	COMPR EFF	.736	CONDNSR FAN	830.980	USER COST	3055.
SYSTEM COP	.691	RPM	58444.	CL TOWER FAN	.000		
		TURBN DIA(IN)	2.176	WATER PUMP	87.562		
		TURBN EFF	.771	FREDN PUMP	49.658		
				TOTAL	1147.197		

Figure B-6. Output Data - Concept C



AIRESEARCH MANUFACTURING COMPANY
OF CALIFORNIA

SOLAR POWERED AIR CONDITIONING SYSTEM USING R-11
COOLING TOWER EMPLOYED

INPUT				
VIST	0.95000000+02	0.10250000+01	0.11000000+01	0.11000000+01
	0.12250000+01	0.12820000+01	0.13400000+01	0.13900000+01
	0.00000000+00	0.00000000+00	0.00000000+00	0.00000000+00
	0.00000000+00	0.00000000+00	0.00000000+00	0.00000000+00
TT	0.00000000+00	0.40000000+02	0.50000000+02	0.12000000+03
	0.00000000+03	0.20000000+03	0.24000000+03	0.28000000+03
TTM	0.40000000+02	0.20000000+02	0.00000000+00	0.20000000+02
	0.40000000+02	0.00000000+02	0.00000000+02	0.10000000+03
	0.12000000+03	0.14000000+03	0.16000000+03	0.18000000+03
	0.20000000+03	0.22000000+03	0.24000000+03	0.26000000+03
	0.28000000+03			
HVT	0.87529999+02	0.89849999+02	0.92019999+02	0.94889999+02
	0.97389999+02	0.99879999+02	0.10235999+03	0.10680999+03
	0.10721999+03	0.10958999+03	0.11187999+03	0.11406999+03
	0.11616999+03	0.11812999+03	0.11991999+03	0.12151999+03
	0.12284999+03			
HLT	0.00000000+00	0.39800000+01	0.79899999+01	0.12030000+02
	0.16120000+02	0.20270000+02	0.24480000+02	0.28750000+02
	0.33080000+02	0.37480000+02	0.41950000+02	0.46470000+02
	0.51070000+02	0.55760000+02	0.60530000+02	0.65459999+02
	0.70569999+02			
PT	0.73869999+00	0.14190000+01	0.25540000+01	0.43419999+01
	0.70299999+01	0.10910000+02	0.10310000+02	0.23600000+02
	0.33180000+02	0.45500000+02	0.61100000+02	0.80179999+02
	0.10352999+03	0.13158000+03	0.16487000+03	0.20397000+03
	0.24947000+03			
RHOVT	0.22600000+01	0.41539999+01	0.71709999+01	0.11739999+00
	0.18350000+00	0.27590000+00	0.40100000+00	0.56630000+00
	0.78009999+00	0.10520000+01	0.13920000+01	0.18140000+01
	0.23330000+01	0.29680000+01	0.37440000+01	0.46960000+01
	0.58800000+01			
CP	0.14000000+00			
GAMHA	0.11100000+01			
AK	0.19800000+02			
YB	0.16500000+03			
TE	0.40000000+02			
TC	0.10500000+03			
MY	0.13740000+03			
DPP	0.49999999+01	0.49999999+01	0.49999999+01	0.49999999+01
	0.49999999+01	0.49999999+01	0.49999999+01	0.49999999+01
	0.49999999+01	0.49999999+01	0.49999999+01	0.49999999+01
	0.49999999+01	0.49999999+01	0.49999999+01	0.49999999+01
	0.49999999+01	0.49999999+01	0.49999999+01	0.49999999+01
EPM	0.89999999+00			
QR	0.36000000+03			
RHOL	0.91000000+02			
EFPUMP	0.50000000+00			
TITLE	0.25618020+18			
NTB	1			
TBT	0.18500000+03	0.18500000+03	0.18400000+03	0.19000000+03
	0.00000000+00	0.00000000+00	0.00000000+00	0.00000000+00
NTC	1			
TCT	0.90000000+02	0.95000000+02	0.11500000+03	0.12500000+03
	0.00000000+00	0.00000000+00	0.00000000+00	0.00000000+00
NTE	1			
TET	0.45000000+02	0.50000000+02	0.00000000+00	0.00000000+00

Figure B-7. Input Data - Concept D



AMRESEARCH MANUFACTURING COMPANY
OF CALIFORNIA

KCR	*	.00000000+00	.00000000+00	.00000000+00	.00000000+00
TRIN	*	.20000000+03			
UAER	*	.11800000+07			
EFFAN	*	.89000000+00			
CPL	*	.21000000+00			
TC	*	.80000000+02	.55000000+02	.95000000+02	.95000000+02
TH	*	.57000000+02	.53368063+02	.75000000+02	.75000000+02
NDTE	*	.10000000+02	.15000000+02	.20000000+02	.12500000+02
DTET	*	.15000000+02			
NDTB	*	.75000000+01	.10000000+02	.20000000+02	.00000000+00
DTBT	*	.00000000+00			
NDTC	*	.50000000+01	.15000000+02	.10000000+02	.15000000+02
DTCT	*	.20000000+02			
NTBIN	*	.20000000+03	.00000000+00	.00000000+00	.00000000+00
TBINT	*	.00000000+00			
NTCIN	*	.80000000+02	.65000000+02	.70000000+00	.00000000+00
TCINT	*	.00000000+00			
SEND					

Figure B-7 (Continued)



SOLAR POWERED AIR CONDITIONING SYSTEM USING R-11
 COOLING TOWER EMPLOYED
 AUG. 24 JUL 75 AT 1412011P

STATION/ID	TEMPERATURE DEG F	PRESSURE PSIA	ENTHALPY BTU/LB	FLOW RATE LBS/HR	DENSITY LBS/CU FT
1	45.0000	8.0000	98.0125	504.2193	.0266
2	122.1692	20.9527	108.0408	504.2193	.04007
3	110.8670	20.9527	106.4585	1046.8049	.04702
4	90.0000	19.7550	26.6150	1046.8049	.03000
5	45.0000	8.4000	26.6150	504.2193	.03167
6	91.3622	90.3184	26.6111	592.4476	.03000
7	185.0000	86.0175	114.5950	592.4476	1.9437
8	101.2480	20.9527	105.1118	592.4476	.04986

HEAT EXCHANGER	HOT FLUID		COLD FLUID		UA (BTU/HR/DEG F)	WRIGHT (LBS)	CONST (LBS F)	FAN LP (IN-H2O)	FAN FLYER (WATT)	U (BTU/HR)	NET BULK(F)			
	FLO. (LBS/HR)	TEMP(F) IN OUT	FLO. (LBS/HR)	TEMP(F) IN OUT							IN	OUT		
EVAP	3815.	80.0 55.0	504.	45.0 45.0	.00	35.8	32.6	27.2	42.7	.86	174.0	3600.	67.0	53.4
BOILER	6927.	200.0 192.5	542.	91.4 125.0	4801.57	35.5	.0	54.3	.0	.00	.0	51954.		
CONDENSER	1097.	110.9 90.0	17512.	80.0 55.0	12138.65	89.8	.0	344.2	.0	.00	.0	47562.	75.0	75.0

COEF OF PERFORMANCE		TURBO-COMPRESSOR		ELECTRIC POWER REQD(WATT)		SYSTEM COST(\$)	
POWER COP	.108	COMPR DIA(IN)	2.176	EVAP FAN	178.947	FACTORY COST	1004.
REFRIG COP	7.120	COMPR EFF	.736	CONDENSER FAN	.000	USER COST	3730.
SYSTEM COP	.691	RPM	58444.	CL TOWER FAN	254.183		
		TURBN DIA(IN)	2.176	WATER PUMP	166.367		
		TURBN EFF	.771	FREON PUMP	49.658		
				TOTAL	654.225		

Figure B-8. Output Data - Concept D