MILBANK[®] ENERGYAT WORK

U3822-20GWR



| Catalog Number | U3822-20GWR |
|-------------------------------|-------------------------------------------------------------------------|
| Marketing Product Description | 60 Ampere Non-fused Alternating Current Disconnect 520GR Pull Out |
| UPC | 784572527829 |
| Length (IN) | 5.065 |
| Width (IN) | 4.672 |
| Height (IN) | 7.5 |
| Weight (LB) | 4.4 |
| Brand Name | Milbank |
| Туре | Air Conditioner Disconnect |
| Special Features | 10 Horse Power;20 Ampere GFCI |
| Application | Metering Accessory |
| Standard | UL Listed;Type 3R |
| Voltage Rating | Up to 240 Volts Alternating Current |
| Amperage Rating | 60 Ampere |
| Interrupt Rating | 10,000 Ampere Interrupting Capacity |
| Number Of Poles | 2 |
| Trip Type | None |
| Contact Configuration | Pull Out |
| Contact Rating | 60 Ampere Up to 240 Volts Alternating Current |

| Connection | Pullout |
|--------------------|------------------------|
| Enclosure | Painted Steel |
| Mounting | Surface Mount |
| Size | 5.065L x 4.672W x 7.5H |
| Conduit Connection | Knockouts |

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.