

**SNEC Results of Groundwater Duplicates Shared With ORISE**

| <b>WELLS</b>          | <b>SAMPLE DATE</b> | <b>TRITIUM (pCi/L)</b> | <b>Cs-137(pCi/L)</b> | <b>Cs-134(pCi/L)</b> | <b>Co-60(pCi/L)</b> |
|-----------------------|--------------------|------------------------|----------------------|----------------------|---------------------|
|                       |                    | <2000(MDA)             | 18(MDA)              | 15(MDA)              | 15(MDA)             |
| <b>GEO-5</b>          | <b>4/2/02</b>      | <b>&lt;308</b>         | <b>&lt;14.0</b>      | <b>&lt;13.5</b>      | <b>&lt;13.2</b>     |
| <b>GEO-8</b>          | <b>4/1/02</b>      | <b>&lt;308</b>         | <b>&lt;13.3</b>      | <b>&lt;12.3</b>      | <b>&lt;12.3</b>     |
| <b>MW-4</b>           | <b>4/2/02</b>      | <b>&lt;308</b>         | <b>&lt;8.0</b>       | <b>&lt;9.3</b>       | <b>&lt;8.3</b>      |
| <b>OW-3</b>           | <b>4/2/02</b>      | <b>&lt;342</b>         | <b>&lt;8.3</b>       | <b>&lt;9.6</b>       | <b>&lt;9.3</b>      |
| <b>OW-3R</b>          | <b>4/2/02</b>      | <b>&lt;308</b>         | <b>&lt;10.9</b>      | <b>&lt;10.9</b>      | <b>&lt;9.4</b>      |
| <b>OW-4R</b>          | <b>4/2/02</b>      | <b>&lt;308</b>         | <b>&lt;12.2</b>      | <b>&lt;12.2</b>      | <b>&lt;11.2</b>     |
| <b>OW-5R</b>          | <b>4/1/02</b>      | <b>&lt;310</b>         | <b>&lt;8.7</b>       | <b>&lt;9.5</b>       | <b>&lt;9.6</b>      |
| <b>OW-6</b>           | <b>4/2/02</b>      | <b>&lt;308</b>         | <b>&lt;12.4</b>      | <b>&lt;10.9</b>      | <b>&lt;12.0</b>     |
| <b>OW-7R</b>          | <b>4/2/02</b>      | <b>&lt;308</b>         | <b>&lt;13.4</b>      | <b>&lt;13.0</b>      | <b>&lt;12.4</b>     |
| <b>NRC ANGLE WELL</b> | <b>4/2/02</b>      | <b>&lt;308</b>         | <b>&lt;7.9</b>       | <b>&lt;8.6</b>       | <b>&lt;8.6</b>      |



**SUB-SURFACE DCGLs FOR  
THE SAXTON NUCLEAR  
EXPERIMENTAL  
CORPORATION SITE**

**CALCULATION PACKAGE**

**July 30, 2002**

**URS Corporation**  
756 East Winchester Street, Suite 400  
Salt Lake City, UT 84107


|                 |  |
|-----------------|--|
| <b>Date:</b>    | June 18, 2002                                    |
| <b>To:</b>      | P. Donnachie, B. Brosey, GPU                     |
| <b>From:</b>    | K. K. Nielson, V. C. Rogers, URS                 |
| <b>Subject:</b> | Subsurface DCGL Technical Approach For SNEC Site |

### DRAFT TECHNICAL APPROACH

This memorandum documents the technical approach proposed by URS Corp to estimate Derived Concentration Guideline Limits (DCGLs) for the Subsurface materials at the Saxton Nuclear Energy Corporation (SNEC) Site. Three areas of concern have been identified at SNEC: the Spray Ponds, the Steam Generating Station (SSGS), and the Reactor area around the Containment Vessel (CV) excavations. Subsurface materials for the Spray Pond and Reactor areas (excluding the CV excavations) are very similar, consisting of approximately two meters of overburden and a greater thickness of underlying bedrock. The subsurface material in the SSGS consists of crushed, homogenized site debris that is covered with one meter of clean fill. Because of these differences, DCGLs will be estimated for only one material (homogenized debris) in the SSGS and for two materials (overburden and bedrock) in the Spray Pond and Reactor areas.

A Resident Farmer Scenario has been selected to most reasonably represent exposures to members of the critical population group. In the scenario, it is assumed that the resident moves onto the Spray Pond, Steam Plant, or Reactor areas, grades the surface, digs a basement, builds a house, develops a bedrock-depth well for drinking water and irrigation, and plants a garden. During these activities, the resident is exposed to residual radioactivity in several ways that include (a) consuming drinking water from the bedrock well, (b) consuming fruits and vegetables grown onsite with irrigation water from the bedrock well, (c) consuming beef and milk from cattle raised onsite using the same irrigation water, (d) consuming fish caught from the adjacent stream into which contaminated runoff and groundwater flows, (e) inhalation of contaminated dust suspended as a result of wind or other activities near the residence, and (f) directly from the material that has been brought to the surface during home construction and yard leveling. The effects of exposure to all pathways will be analyzed and the peak doses compared to the 25 mrem/year criterion to develop DCGLs for each nuclide, soil layer and SNEC area of concern. In addition to these DCGLs, the drinking water pathway will also be analyzed in comparison to the 4 mrem/year drinking water standard to estimate separate drinking water DCGLs for each nuclide, soil layer and SNEC area of concern. To promote consistency with the surface DCGLs, documentation and files for the first five DCGLs for each subsoil region and SNEC area of concern will be transmitted to GPU for review and approval.

The basement of the hypothetical house built by the resident in the Spray Pond, Steam Plant, or Reactor areas penetrates the 1-m surface fill layer and the top part of the underlying material. The materials excavated for the basement are represented here in the same way as they have been in previous NRC guidance documents. The excavation is considered to penetrate sufficiently deep for construction of the basement, and the excavated material is considered to be mixed with overlying fill material and placed in the vicinity of the house.<sup>1,2</sup> Figure 1 illustrates the basement excavations and surface placement of the excavated materials for the different Site areas.



**FIGURE 1. HYPOTHETICAL BASEMENT EXCAVATIONS AND SURFACE MATERIAL SPREADING IN DIFFERENT AREAS OF THE SNEC SITE.**

The footprint area of the hypothetical house and its basement excavation is chosen to be 200 m<sup>2</sup>, which corresponds to the house areas used in the previous NRC analyses.<sup>1,2</sup>

The height of the basement,  $h_b$ , is chosen to be 2 meters based on both the previous NRC guidance and conservative assessment of the site parameters. The previous NRC guidance documents used basement depths of 3 meters for disposal cells that were covered by 2 m of clean soil or cap material.<sup>1</sup> This resulted in 1-meter intrusion depths into the contaminated material. For the present Site, where fill soil layers are 1 m thick, a 2-m basement excavation provides the same 1-m intrusion depth into potentially-contaminated material.

<sup>1</sup> NRC 1986. "Update of Part 61 Impacts Analysis Methodology," O.I. Oztunali and G.W. Roles, Washington DC: U.S. Nuclear Regulatory Commission report NUREG/CR-4370, January 1986.

<sup>2</sup> NRC 1999. "Preliminary Guidelines for Evaluating Dose Assessments in Support of Decommissioning," J.W.N. Hickey, Washington D.C.: U.S. Nuclear Regulatory Commission Memorandum dated March 16, 1999.



The Spray Pond area, Reactor area (except the back-filled CV excavation), and undisturbed areas of the Site feature a 2-m layer of boulder-laden overburden between the 1-m fill soil layer and bedrock, as shown in Figure 1. The overburden discourages excavation because of its large boulders and interstitial cobbles. The hypothetical 2-m basement excavation (1-m into the boulder layer) is therefore conservatively deeper than would normally be expected. Furthermore, the water table at the Site varies between 0.7 and 2.3 m, making the hypothetical 2-m basement excavation conservatively deeper than the average estimated water table depth.

The Steam Plant basement contains homogenized rubble instead of overburden in the bottom half of the hypothetical 2-m excavation (see Figure 1). The hypothetical Steam Plant excavation therefore intrudes to the same extent (1 m) into potentially-contaminated material as in the Spray Pond area and is subject to similar water-table limitations as in other parts of the Site.

The native materials in the CV area are replaced with clean backfill to depths well beyond any realistic basement excavation depths. Therefore, any excavations in the CV area would only bring clean backfill to the surface. The surrounding materials in the Reactor area are represented by the same profile as the Spray Ponds, as illustrated in Figure 1. Because of the identical material profiles in the Spray Pond and Reactor areas, the same DCGL analyses will probably apply to both unless hydraulic gradient or water table depth differences are significant. The potential significance of any differences will be explored before any separate DCGLs are calculated for the Reactor area.

The concentrations of any contaminants in the overburden layer beneath the Spray Ponds or in the homogenized rubble in the Steam Plant are reduced to one-half of their in-situ concentrations by mixing with the top meter of fill soil during their excavation. The two-fold dilution factor results from mixing equal volumes of clean and potentially-contaminated excavation materials using the same calculation approach advocated in the NRC guidance documents.<sup>1,2</sup>

The mixed material from the basement excavation is considered to be spread around the hypothetical house as in the NRC models.<sup>1</sup> The area of this material is conservatively taken to be 2,000 m<sup>2</sup> based on the nominal one-half acre (2,023 m<sup>2</sup>) and 1,000 m<sup>2</sup> to 2,000 m<sup>2</sup> area ranges estimated by NRC.<sup>1</sup> The average thickness of this layer of mixed material is  $h_r = 0.20$  m [estimated as (200 m<sup>2</sup> basement footprint area) x (2 m depth) / (2,000 m<sup>2</sup> spread area)]. This thickness is conservative in giving an approximate maximum gamma radiation activity and approximating the default crop root depth of 0.15 m in the Resrad dose assessment code.<sup>3</sup> Additionally, the geophysical characteristics of this layer of mixed material are depth-weighted averages of those of the Fill and Overburden layers.

The technical approach and detailed steps for determining the DCGLs for the sub-surface materials at the SNEC Site are identified in Figure 2 based on discussions between URS and GPU personnel. The large gray numbers in Figure 2 correspond to the step numbers listed below.

---

<sup>3</sup> Resrad v. 6.2, Charles Yu, Argonne National Laboratory, Environmental Assessment Div., 9700 South Cass Ave., Argonne, IL, 60439, May 31, 2002.




FIGURE 2. TECHNICAL APPROACH FOR SUBSURFACE DCGL CALCULATIONS.

- 1) Generate an appropriate RESRAD 6.1 input file containing all Haley and Aldrich (H & A) values and parameter distributions. Where available, DandD default values will be used for metabolic and behavior inputs. For parameters for which input guidance is unavailable from either DandD or H & A, default RESRAD values and distributions will be used. Uncertainty analysis will be performed by RESRAD for each parameter for which a distribution has been input. A list of these values and distributions is presented in Table 1.
- 2) Uncertainty correlations will be established between density and total porosity, density and effective porosity, and total porosity and effective porosity with a correlation value specified as 0.99.
- 3) A random seed of 1,000 will be used for the uncertainty sampling. Additionally, the Latin HyperCube Sample (LHS) method will be used to generate samples of input values for the probabilistic analysis. The analysis will be repeated three times, with between 300 and 500 points selected for each analysis.
- 4) The RESRAD input file will then be processed using the probabilistic analysis feature of RESRAD 6.1. All output reports will be copied and stored for inclusion in the data CD to be delivered to the NRC.
- 5) The first 6 correlation tables of the MCSUMMARY.REP file will then be extracted. Within these tables, the higher correlation coefficient ( $r^2$  value) between the PRCC and PCC sensitivity methods will be highlighted.
- 6) Sensitive input parameters will then be identified and highlighted for those parameters whose sensitivity correlation value is greater than 0.25 or less than -0.25, using the correlation method identified in 5) with the highest  $r^2$  value.
- 7) The tables with appropriate highlighted points will be printed for inclusion in the Calculation Package and the data CD.
- 8) A copy of the RESRAD input file generated in numbers 1 through 3 will then be made. From within this copy, the uncertainties and input distributions will be deleted for all insensitive parameters (those not highlighted in step 6).
- 9) The RESRAD input file will then begin started using the probabilistic analysis feature of RESRAD 6.1.
- 10) Once the RESRAD processing has completed the LHS step, the RESRAD analysis will be halted.
- 11) The LHSBIN.DAT file will then be copied from the RESRAD output and stored for permanent inclusion in the data CD.
- 12) The LHSBIN.DAT file will then be imported into MS Excel and the MS Excel Data Analysis package will be used to analyze the input parameter distributions to determine mean, 25<sup>th</sup> percentile, and 75<sup>th</sup> percentile for each sensitive input parameter. These values will be summarized in a printout

for inclusion in the Calculation Package and the resulting MS Excel file saved for addition to the data CD.

- 13) The duplicate RESRAD input file, created in step 8, will then be edited within RESRAD. Modifications will include:
  - a. Suppression of the uncertainty analysis.
  - b. The 75<sup>th</sup> percentile value will replace the base-deterministic input value for those sensitive parameters whose coefficients of sensitivity was greater than 0.25.
  - c. The 25<sup>th</sup> percentile value will replace the base-deterministic input value for those sensitive parameters whose coefficients of sensitivity was less than -0.25.
  - d. The mean value calculated in step 12 will replace the base-deterministic input value for those sensitive parameters whose mean is not bounded by the 25<sup>th</sup> and 75<sup>th</sup> percentile values.
  - e. Except when the coefficients of sensitivity for the distribution coefficients ( $K_d$ ) are greater than 0.25, the minimum Argonne distribution coefficient ( $K_d$ ) will be used.
- 14) The input file created in step 13 will then be analyzed using RESRAD 6.1 in a deterministic mode. The input and resulting output reports will be saved for addition to the data CD. The peak dose, year of occurrence, and pathway breakdown for the peak dose will be printed for inclusion in the Calculation Package.
- 15) The 25 mrem/year dose limit will then be divided by the peak dose to determine a DCGL representing exposure from all pathways. This process will be performed for each nuclide, soil region, and SNEC area of concern.
- 16) Steps 1 through 14 will then be repeated with all pathways turned off, except the drinking water pathway. Those files and reports designated for inclusion in the Calculation Package or data CD will be appended with "DW" to signify Drinking Water only.
- 17) The 4 mrem/year drinking water dose limit will then be divided by the peak dose from drinking water only to determine a DW DCGL. This process will be repeated for each nuclide, soil region, and SNEC area of concern.
- 18) A summary table of all cumulative and drinking water DCGLs for each nuclide, subsoil region, and SNEC area of concern and will be prepared.

SNEC - DOSE AND DCGL SUMMARY

| Applicable Limit (mrem/yr) | SPRAY POND AND GENERAL AREA |                            |          |                            |                        |                            |          |                            | BEDROCK             |                            |                     |                            | SSGS                 |          |  |  |
|----------------------------|-----------------------------|----------------------------|----------|----------------------------|------------------------|----------------------------|----------|----------------------------|---------------------|----------------------------|---------------------|----------------------------|----------------------|----------|--|--|
|                            | Overburden on Surface       |                            |          |                            | Undisturbed Overburden |                            |          |                            | Undisturbed Bedrock |                            | Backfill on Surface |                            | Undisturbed Backfill |          |  |  |
|                            | 25                          |                            | 4        |                            | 4                      |                            | 4        |                            | 25                  |                            | 4                   |                            | 4                    |          |  |  |
| Peak Dose (mrem/yr) [year] | DCGL                        | Peak Dose (mrem/yr) [year] | DCGL     | Peak Dose (mrem/yr) [year] | DCGL                   | Peak Dose (mrem/yr) [year] | DCGL     | Peak Dose (mrem/yr) [year] | DCGL                | Peak Dose (mrem/yr) [year] | DCGL                | Peak Dose (mrem/yr) [year] | DCGL                 |          |  |  |
| Hs-222                     | 1.14E-02                    | 2.19E+03                   | 2.78E-03 | 1.44E+03                   | 5.03E-02               | 7.66E+01                   | 1.28E-01 | 3.12E+01                   | 1.08E-02            | 2.31E+03                   | 1.91E-04            | 2.09E+04                   | 1.15E-01             | 3.07E+01 |  |  |
| C-14                       | 5.94E-01                    | 3.21E+01                   | 1.09E-03 | 3.68E+03                   | 5.04E-01               | 7.93E+00                   | 7.31E-01 | 5.47E+00                   | 5.94E-01            | 4.21E+01                   | 1.40E-04            | 2.95E+04                   | 7.11E-01             | 5.63E+00 |  |  |
| Co-60                      | 3.09E+00                    | 8.09E+00                   | 5.31E-22 | 7.53E+21                   | 2.08E-04               | 1.92E+04                   | 1.99E-04 | 2.01E+04                   | 7.76E+03            | 3.22E+03                   | 4.64E-23            | 9.63E+22                   | 7.11E-10             | 1.63E+18 |  |  |
| Ni-63                      | 7.76E-03                    | 3.32E+03                   | 4.879    | 0                          | 0                      | 0                          | 0        | 0                          | 0                   | 0                          | 0                   | 0                          | 0                    | 0        |  |  |
| Sr-90                      | 1.40E+00                    | 5.69E+00                   | 9.48E-02 | 4.23E+01                   | 6.55E+00               | 6.11E-01                   | 6.55E+00 | 6.11E-01                   | 4.49E+00            | 6.69E+00                   | 4.881               | 4.89E+02                   | 5.39E+00             | 1.19E+00 |  |  |
| Ca-137                     | 1.18E+00                    | 2.11E+01                   | 54       | 0                          | 0                      | 0                          | 0        | 0                          | 0                   | 0                          | 41                  | 28                         | 0                    | 0        |  |  |
| Eu-152                     | 1.21E+00                    | 2.07E+01                   | 1.89E-16 | 2.37E+16                   | 2.77E-03               | 1.44E+03                   | 2.77E-03 | 1.44E+03                   | 1.21E+00            | 2.07E+01                   | 1.04E-17            | 3.83E+17                   | 4.21E-15             | 9.51E+14 |  |  |
| Pu-238                     | 2.00E-01                    | 1.28E+02                   | 1.69E-03 | 1.76E+02                   | 1.79E+00               | 4.22E-01                   | 6.54E+00 | 4.19E-01                   | 5.49E+00            | 2.64E+00                   | 3.131               | 3.19E-01                   | 4.35E-01             | 9.20E+00 |  |  |
| Pu-239                     | 1.48E-01                    | 4.58E+01                   | 6.39E-01 | 7.42E+00                   | 1.07E+01               | 3.76E-01                   | 1.07E+01 | 3.76E-01                   | 2.23E-01            | 1.12E+02                   | 9.13E-02            | 1.28E+02                   | 1.95E+01             | 3.83E-01 |  |  |
| Pu-241                     | 5.86E-03                    | 4.28E+03                   | 2.84E-06 | 1.52E+06                   | 2.02E-01               | 1.98E+01                   | 2.02E-01 | 1.98E+01                   | 6.14E-03            | 4.07E+03                   | 4.97E-08            | 8.05E+07                   | 4.31E-05             | 9.28E+04 |  |  |
| Am-241                     | 2.32E-01                    | 1.09E+02                   | 4.10E-05 | 6.76E+04                   | 1.73E+00               | 2.31E+00                   | 1.73E+00 | 2.31E+00                   | 2.32E-01            | 1.08E+02                   | 2.74E-05            | 1.46E+06                   | 1.29E-03             | 2.30E+03 |  |  |

SSGS DW SCENARIO FOR UNDISTURBED BACKFILL

| Menu | Class | PARAMETERS  | Basic                                  | SNEC Range of Values |          | Assigned Distribution | Default Distribution                 | Basis  |
|------|-------|---|--|----------------------|----------|-----------------------|--------------------------------------|--|
|      |       |   | RESRAD Input                           | Min                  | Max      |                       |                                      |  |
| C14  | P     | Thickness of Soil Evasion Layer of C-14 in Soil (m) | 0.3                                    | 0.2                  | 0.6      | Triangular            |                                      | SNEC 5/13/02   |
| D-5  | P     | Bioaccumulation Factors, Fresh Water                | Default Values                         | Varies               | Varies   | Lognormal             |                                      | SNEC 5/13/02   |
| D-34 | P     | Food Transfer Factors                               | Default Values                         | Varies               | Varies   | Lognormal             |                                      | SNEC 5/13/02   |
| RO11 | P     | Area of Contaminated Zone (m^2)                     | 2000                                   | N/A                  | N/A      | N/A                   |                                      | URS Technical Approach 6/18/02   |
| RO11 | NRC   | Basic Radiation Dose Limit (mrem/yr) (NRC)          | 4                                      | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Length Parallel to Aquifer Flow (m)                 | 50.5                                   | N/A                  | N/A      | N/A                   |                                      | RESRAD Data Collection Handbook  |
| RO11 | P     | Thickness of Contaminated Zone 1 (m)                | 2.000E+00                              | N/A                  | N/A      | N/A                   |                                      | URS Technical Approach 6/18/02   |
| RO11 | P     | Time Since Placement of Materials (yr)              | 0                                      | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                         | 1                                      | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                         | 3                                      | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                         | 10                                     | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                         | 35                                     | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                         | 150                                    | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                         | 300                                    | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                         | 1000                                   | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                         | 10000                                  | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO13 | P     | Average Annual Wind Speed (m/sec)                   | N/A                                    | N/A                  | N/A      | N/A                   | Bounded Lognormal-N (1.4 - 13)       | SNEC 5/13/02   |
| RO13 | P     | Contaminated Zone Field Capacity                    | 0.1360                                 | 0.0790               | 0.1920   | Uniform               | None Assigned                        | Backfill properties assumed same as fill soil as per GPU direction 5/13/02 |
| RO13 | P     | Contaminated Zone b Parameter                       | 5.60                                   | 4.05                 | 7.12     | Uniform               | Bounded Lognormal-N (0.5 - 30)       | Backfill properties assumed same as fill soil as per GPU direction 5/13/02 |
| RO13 | P, B  | Contaminated Zone Erosion Rate (m/yr)               | 0.000345                               | 0.00009              | 0.0006   | Loguniform            | Continuous Logarithmic (5E-08 - 0.2) | Backfill properties assumed same as fill soil as per GPU direction 5/13/02 |
| RO13 | P     | Contaminated Zone Hydraulic Conductivity (m/yr)     | 32.30                                  | 0.36                 | 25400.00 | Loguniform            | Bounded Lognormal-N (0.004 - 9250)   | Backfill properties assumed same as fill soil as per GPU direction 5/13/02 |
| RO13 | P     | Contaminated Zone Total Porosity                    | 0.460                                  | 0.350                | 0.560    | Uniform               | Truncated Normal, (0.157 - 0.693)    | Backfill properties assumed same as fill soil as per GPU direction 5/13/02 |
| RO13 | P     | Density of Contaminated Zone (g/cc)                 | 1.6                                    | 1.28                 | 1.92     | Uniform               | Truncated Normal (0.809 - 2.23)      | SNEC 5/13/02 (Same as unsat zone)  |
| RO13 | P     | Evapotranspiration Coefficient (m/yr)               | 0.59                                   | 0.5                  | 0.67     | Uniform               | Uniform (0.5 - 0.75)                 | SNEC 5/13/02   |
| RO13 | P     | Humidity in Air (g/m^3)                             | 8 (H-3) not used for others            | 2.58E+00             | 2.03E+01 | Truncated Lognormal-N |                                      | SNEC 5/13/02   |
| RO13 | B     | Irrigation (m/yr)                                   | 0.2                                    | —                    | —        | None Assigned         |                                      | SNEC 5/13/02   |
| RO13 | B     | Irrigation Mode (Overhead)                          | Overhead                               | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO13 | P     | Precipitation (m/yr)                                | 0.936                                  | 0.688                | 1.327    | Uniform               | None Assigned                        | SNEC 5/13/02   |
| RO13 | P     | Runoff Coefficient                                  | 0.35                                   | 0.3                  | 0.4      | Uniform               | Uniform (0.1 - 0.8)                  | SNEC 5/13/02   |
| RO13 | P     | Watershed Area for Nearby Stream or Pond (m^2)      | 5.00E+06                               | —                    | —        | None Assigned         | None Assigned                        | SNEC 5/13/02   |
| RO14 | P     | Density of Saturated Zone (g/cc)                    | 1.6                                    | 1.28                 | 1.92     | Uniform               | Truncated Normal (0.809 - 2.23)      | SNEC 5/13/02   |
| RO14 | P     | Modal Non-dispersion (ND) or Mass-Balance (MB)      | Mass Balance                           | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone b Parameter                          | Not Used                               | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone Effective Porosity                   | 0.41                                   | 0.28                 | 0.54     | Loguniform            | Truncated Normal (0.075 - 0.635)     | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone Hydraulic Conductivity (m/yr)        | 32.3                                   | 0.362                | 25400    | Uniform               | Bounded Lognormal-N (0.004 - 9250)   | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone Hydraulic Gradient                   | 0.02                                   | 0.013                | 0.03     | Uniform               | Bounded Lognormal-N (0.00007 - 0.5)  | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone Total Porosity                       | 0.46                                   | 0.35                 | 0.56     | Uniform               | Truncated Normal, (0.157 - 0.693)    | SNEC 5/13/02   |
| RO14 | P     | Water Table Drop Rate (m/yr)                        | 0                                      | —                    | —        | None Assigned         | None Assigned                        | SNEC 5/13/02   |
| RO14 | P     | Well Pump Intake Depth (m)                          | 30.2                                   | 10.2                 | 50.2     | Uniform               | Triangular (6 - 30)                  | SNEC 5/13/02 + 0.2m excavation as per URS Technical Approach 6/18/02       |
| RO14 | B, P  | Well Pumping Rate (m^3/yr)                          | 286.2 (reported as not used by RESRAD) | 207.3                | 365      | Uniform               | None Assigned                        | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone Field Capacity                       | 0.136                                  | 0.079                | 0.192    | Uniform               | None Assigned                        | SNEC 5/13/02   |
| RO15 | P     | Density of Unsaturated Zone 1 (g/cc)                | 1.6                                    | 1.28                 | 1.92     | Uniform               | Truncated Normal (0.809 - 2.23)      | SNEC 5/13/02   |
| RO15 | P     | Effective Porosity of Unsaturated Zone 1            | 0.41                                   | 0.28                 | 0.54     | Uniform               | Truncated Normal (0.075 - 0.635)     | SNEC 5/13/02   |
| RO15 | P     | Hydraulic Conductivity of Unsaturated Zone 1 (m/yr) | 32.3                                   | 0.362                | 25400    | Loguniform            | Bounded Lognormal-N (0.004 - 9250)   | SNEC 5/13/02   |
| RO15 | P     | Number of Unsaturated Zone Strata                   | 1                                      | N/A                  | N/A      | N/A                   | N/A                                  | SNEC 5/13/02   |
| RO15 | P     | Thickness of Unsaturated Zone 1 (m)                 | 0.0010                                 | N/A                  | N/A      | N/A                   | Bounded Lognormal-N (0.18 - 320)     | URS Technical Approach 6/18/02 (effectively zero)                          |
| RO15 | P     | Total porosity of Unsaturated Zone 1                | 0.46                                   | 0.35                 | 0.56     | Uniform               | Truncated Normal, (0.157 - 0.693)    | SNEC 5/13/02   |
| RO15 | P     | Unsaturated Zone 1 b Parameter                      | 5.6                                    | 4.05                 | 7.12     | Uniform               | Bounded Lognormal-N (0.5 - 30)       | SNEC 5/13/02   |
| RO15 | P     | Unsaturated Zone Field Capacity                     | 0.136                                  | 0.079                | 0.192    | Uniform               | None Assigned                        | SNEC 5/13/02   |

|  |      |   |                        |                 |                 |                          |                                |
|--|------|---|------------------------|-----------------|-----------------|--------------------------|--------------------------------|
| RO17   | P    | External Gamma Shielding Factor                   | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO17   | P, B | Indoor Dust Filtration Factor                     | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO17   | B    | Indoor Time Fraction                              | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO17   | M, P | Inhalation Rate (m <sup>3</sup> /yr)              | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO17   | P, B | Mass Loading for Inhalation (g/m <sup>3</sup> )   | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO17   | B    | Fraction of Time Spent Outdoors                   | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Aquatic Food             | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Drinking Water           | 1                      | —               | —               | None Assigned            | SNEC 5/13/02                   |
| RO18   | B, P | Contaminated Fraction of Household Water          | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Irrigation Water         | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Livestock Water          | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Meat                     | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Milk                     | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Plant Food               | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | M, B | Drinking Water Intake (L/yr)                      | 478.5                  | 90.4            | 1860            | Truncated Lognormal      | SNEC 5/13/02                   |
| RO18   | M, B | Fish Consumption (kg/yr)                          | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | M, B | Fruit, Vegetable, and Grain Consumption (kg/yr)   | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | M, B | Leafy Vegetable Consumption (kg/yr)               | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | M, B | Meat and Poultry Consumption (kg/yr)              | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | M, B | Milk Consumption                                  | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | M, B | Other Seafood Consumption (kg/yr)                 | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | M, B | Soil Ingestion Rate (g/yr)                        | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO19   | M, B | Livestock Water Intake for Milk                   | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO19   | M, B | Depth of Roots (m)                                | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO19   | M, B | Depth of Soil Mixing Layer (m)                    | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO19B  | M, B | Weathering Removal Constant of all Vegetation     | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO19B  | M, B | Wet Crop Yield for Fodder (kg/m <sup>2</sup> )    | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO19B  | M, B | Wet Crop Yield for Leafy (kg/m <sup>2</sup> )     | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO19B  | M, B | Wet Crop Yield for Non-Leafy (kg/m <sup>2</sup> ) | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO19B  | M, B | Wet Foliar Inception Fraction of Leafy Vegetables | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| STOR   | B    | Storage Times for Livestock Fodder                | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| <b>Distribution Coefficient for Americium &amp; Curium</b> |      |   | <b>Value Used</b>      | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 1000                   | 1000            | 5000            |                          | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 1000                   | 1000            | 5000            |                          | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 1000                   | 1000            | 5000            |                          | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Carbon</b>                 |      |   | <b>ANL Value</b>       | <b>GPU Min</b>  | <b>GPU Max</b>  | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 1                      | 0               | 5               | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 1                      | 0               | 5               | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 1                      | 0               | 5               | Uniform                  | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Cesium</b>                 |      |   | <b>Value Used</b>      | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 2131                   | 2131            | 28341           |                          | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 2131                   | 2131            | 28341           |                          | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 2131                   | 2131            | 28341           |                          | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Cobalt</b>                 |      |   | <b>Value Used</b>      | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 200                    | 200             | 1000            |                          | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 200                    | 200             | 1000            |                          | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 200                    | 200             | 1000            |                          | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Europium</b>               |      |   | <b>Value Used</b>      | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 1000                   | 1000            | 5000            |                          | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 1000                   | 1000            | 5000            |                          | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 1000                   | 1000            | 5000            |                          | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Hydrogen</b>               |      |   | <b>ANL Value (GPU)</b> | <b>GPU Min.</b> | <b>GPU Max.</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 1 (0.25)               | 0               | 0.5             | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 1 (0.25)               | 0               | 0.5             | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 1 (0.25)               | 0               | 0.5             | Uniform                  | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Iron</b>                   |      |   | <b>Value Used</b>      | <b>GPU Min.</b> | <b>GPU Max.</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 10000                  | 10000           | 50000           |                          | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 10000                  | 10000           | 50000           |                          | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 10000                  | 10000           | 50000           |                          | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Lead</b>                   |      |   | <b>Value Used</b>      | <b>ANL Min</b>  | <b>ANL Max.</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 9700                   | 9700            | 160000          |                          | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 9700                   | 9700            | 160000          |                          | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 9700                   | 9700            | 160000          |                          | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Nickel</b>                 |      |   | <b>Value Used</b>      | <b>ANL Min</b>  | <b>ANL Max.</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 1300                   | 1300            | 10000           |                          | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 1300                   | 1300            | 10000           |                          | SNEC 5/13/02                   |

| R16   | P | 3. Saturated Zone (cm <sup>3</sup> /g)    | 1300              | 1300            | 10000           |                          | SNEC 5/13/02 |
|---|---|---|-------------------|-----------------|-----------------|--------------------------|--------------|
| <b>Distribution Coefficient for Plutonium</b> |   |   | <b>Value Used</b> | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |              |
| R16   | P | 1. Contaminated Zone (cm <sup>3</sup> /g) | 160               | 160             | 600             |                          | SNEC 5/13/02 |
| R16   | P | 2. Unsaturated Zone (cm <sup>3</sup> /g)  | 160               | 160             | 600             |                          | SNEC 5/13/02 |
| R16   | P | 3. Saturated Zone (cm <sup>3</sup> /g)    | 160               | 160             | 600             |                          | SNEC 5/13/02 |
| <b>Distribution Coefficient for Strontium</b> |   |   | <b>Value Used</b> | <b>ANL Min</b>  | <b>ANL Max.</b> | <b>Distribution Type</b> |              |
| R16   | P | 1. Contaminated Zone (cm <sup>3</sup> /g) | 11                | 11              | 476             |                          | SNEC 5/13/02 |
| R16   | P | 2. Unsaturated Zone (cm <sup>3</sup> /g)  | 11                | 11              | 476             |                          | SNEC 5/13/02 |
| R16   | P | 3. Saturated Zone (cm <sup>3</sup> /g)    | 11                | 11              | 476             |                          | SNEC 5/13/02 |
| <b>Distribution Coefficient for Uranium</b>   |   |   | <b>Value Used</b> | <b>ANL Min</b>  | <b>ANL Max</b>  | <b>Distribution Type</b> |              |
| R16   | P | 1. Contaminated Zone (cm <sup>3</sup> /g) | 16                | 16              | 5200            |                          | SNEC 5/13/02 |
| R16   | P | 2. Unsaturated Zone (cm <sup>3</sup> /g)  | 16                | 16              | 5200            |                          | SNEC 5/13/02 |
| R16   | P | 3. Saturated Zone (cm <sup>3</sup> /g)    | 16                | 16              | 5200            |                          | SNEC 5/13/02 |

NOTE ANL Kd values may be "greater than" values. The ANL Min. value is the lowest reported value for this element and the ANL Max. value is the highest reported value.  
 NOTE Items in RED type face are SNEC input values.  
 NOTE Items in GREEN type face are URS input values.  
 NOTE Items with BLUE background are D & D default values, while items with a YELLOW background are RESRAD default values. Unlisted parameters are RESRAD defaults.



**SPRAY POND SURFACE SCENARIO FOR EXCAVATED OB MATERIAL (ALL PATHS)**

| Menu | Class | PARAMETERS   | Basic                       | SNEC Range of Values |          | Assigned Distribution | Default Distribution                 | Basis  |
|------|-------|--|-----------------------------|----------------------|----------|-----------------------|--------------------------------------|--|
|      |       |  | RESRAD Input                | Min                  | Max      |                       |                                      |  |
| C14  | P     | Thickness of Soil Evasion Layer of C-14 in Soil (m)        | 0.3                         | 0.2                  | 0.6      | Triangular            |                                      | SNEC 5/13/02   |
| D-5  | P     | Bioaccumulation Factors, Fresh Water                       | Default Values              | Varies               | Varies   | Lognormal             |                                      | SNEC 5/13/02   |
| D-34 | P     | Food Transfer Factors                                      | Default Values              | Varies               | Varies   | Lognormal             |                                      | SNEC 5/13/02   |
| RO11 | P     | Area of Contaminated Zone (m <sup>2</sup> )                | 2000                        | N/A                  | N/A      | N/A                   |                                      | URS Technical Approach 6/18/02   |
| RO11 | NRC   | Basic Radiation Dose Limit (mrem/yr) (NRC)                 | 25                          | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Length Parallel to Aquifer Flow (m)                        | 50.5                        | N/A                  | N/A      | N/A                   |                                      | RESRAD Data Collection Handbook  |
| RO11 | P     | Thickness of Contaminated Zone 1 (m)                       | 2.00E-01                    | N/A                  | N/A      | N/A                   |                                      | URS Technical Approach 6/18/02   |
| RO11 | P     | Time Since Placement of Materials (yr)                     | 0                           | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 1                           | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 3                           | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 10                          | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 35                          | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 150                         | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 300                         | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 1000                        | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 10000                       | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO13 | P     | Average Annual Wind Speed (m/sec)                          | 4.07                        | 3.13                 | 4.83     | Uniform               | Bounded Lognormal-N (1.4 - 13)       | SNEC 5/13/02   |
| RO13 | P     | Contaminated Zone Field Capacity                           | 0.1360                      | 0.0790               | 0.1920   | Uniform               | None Assigned                        | overburden as per URS Technical Approach 6/18/02                                   |
| RO13 | P     | Contaminated Zone b Parameter                              | 5.60                        | 4.05                 | 7.12     | Uniform               | Bounded Lognormal-N (0.5 - 30)       | Weighted average of fill and overburden as per URS Technical Approach 6/5/03       |
| RO13 | P, B  | Contaminated Zone Erosion Rate (m/yr)                      | 0.000345                    | 0.00009              | 0.0006   | Loguniform            | Continuous Logarithmic (5E-08 - 0.2) | SNEC 5/13/02   |
| RO13 | P     | Contaminated Zone Hydraulic Conductivity (m/yr)            | 50.11                       | 7.98                 | 13154.77 | Loguniform            | Bounded Lognormal-N (0.004 - 9250)   | Weighted average of fill and overburden as per URS Technical Approach 6/5/03       |
| RO13 | P     | Contaminated Zone Total Porosity                           | 0.410                       | 0.330                | 0.485    | Uniform               | Truncated Normal, (0.157 - 0.693)    | Weighted average of fill and overburden as per URS Technical Approach 6/5/03       |
| RO13 | P     | Cover Depth (m)  | 0                           | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO13 | P     | Density of Contaminated Zone (g/cc)                        | 1.60                        | 1.28                 | 1.92     | Uniform               | Truncated Normal (0.809 - 2.23)      | Weighted average of fill and overburden as per URS Technical Approach 6/5/06       |
| RO13 | P     | Density of Cover Material (g/cc)                           | Not Used                    | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO13 | P     | Evapotranspiration Coefficient (m/yr)                      | 0.59                        | 0.5                  | 0.67     | Uniform               | Uniform (0.5 - 0.75)                 | SNEC 5/13/02   |
| RO13 | P     | Humidity in Air (g/m <sup>3</sup> )                        | 8 (H-3) not used for others | 2.58E+00             | 2.03E+01 | Truncated Lognormal-N |                                      | SNEC 5/13/02   |
| RO13 | B     | Irrigation (m/yr)  | 0.2                         | ---                  | ---      | None Assigned         |                                      | SNEC 5/13/02   |
| RO13 | B     | Irrigation Mode (Overhead)                                 | Overhead                    | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO13 | P     | Precipitation (m/yr)                                       | 0.936                       | 0.688                | 1.327    | Uniform               | None Assigned                        | SNEC 5/13/02   |
| RO13 | P     | Runoff Coefficient   | 0.35                        | 0.3                  | 0.4      | Uniform               | Uniform (0.1 - 0.8)                  | SNEC 5/13/02   |
| RO13 | P     | Watershed Area for Nearby Stream or Pond (m <sup>2</sup> ) | 5.00E+06                    | ---                  | ---      | None Assigned         | None Assigned                        | SNEC 5/13/02   |
| RO14 | P     | Density of Saturated Zone (g/cc)                           | 1.6                         | 1.28                 | 1.92     | Uniform               | Truncated Normal (0.809 - 2.23)      | SNEC 5/13/02   |
| RO14 | P     | Model Non-dispersion (ND) or Mass-Balance (MB)             | Non-Dispersion              | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone b Parameter                                 | Not Used                    | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone Effective Porosity                          | 0.028                       | 0.005                | 0.05     | Loguniform            | Truncated Normal (0.075 - 0.635)     | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone Hydraulic Conductivity (m/yr)               | 67.91                       | 15.59                | 909.53   | Uniform               | Bounded Lognormal-N (0.004 - 9250)   | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone Hydraulic Gradient                          | 0.02                        | 0.013                | 0.03     | Uniform               | Bounded Lognormal-N (0.00007 - 0.5)  | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone Total Porosity                              | 0.36                        | 0.31                 | 0.41     | Uniform               | Truncated Normal, (0.157 - 0.693)    | SNEC 5/13/02   |
| RO14 | P     | Water Table Drop Rate (m/yr)                               | 0                           | ---                  | ---      | None Assigned         | None Assigned                        | SNEC 5/13/02   |
| RO14 | P     | Well Pump Intake Depth (m)                                 | 30.2                        | 10.2                 | 50.2     | Uniform               | Triangular (6 - 30)                  | SNEC 5/13/02 + 0.2m excavation as per URS Technical Approach 6/18/02               |
| RO14 | B, P  | Well Pumping Rate (m <sup>3</sup> /yr)                     | 286.2                       | 207.3                | 365      | Uniform               | None Assigned                        | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone Field Capacity                              | 0.136                       | 0.079                | 0.192    | Uniform               | None Assigned                        | SNEC 5/13/02   |
| RO15 | P     | Density of Unsaturated Zone 1 (g/cc)                       | 1.6                         | 1.28                 | 1.92     | Uniform               | Truncated Normal (0.809 - 2.23)      | SNEC 5/13/02   |
| RO15 | P     | Effective Porosity of Unsaturated Zone 1                   | 0.41                        | 0.28                 | 0.54     | Uniform               | Truncated Normal (0.075 - 0.635)     | SNEC 5/13/02   |
| RO15 | P     | Hydraulic Conductivity of Unsaturated Zone 1 (m/yr)        | 32.3                        | 0.362                | 25400    | Loguniform            | Bounded Lognormal-N (0.004 - 9250)   | SNEC 5/13/02   |
| RO15 | P     | Number of Unsaturated Zone Strata                          | 1                           | N/A                  | N/A      | N/A                   | N/A                                  | SNEC 5/13/02   |
| RO15 | P     | Thickness of Unsaturated Zone 1 (m)                        | 1.25                        | 1.00                 | 1.50     | Uniform               | Bounded Lognormal-N (0.18 - 320)     | SNEC 5/13/02 + 1.0m original fill soil layer as per URS Technical Approach 6/18/02 |
| RO15 | P     | Total porosity of Unsaturated Zone 1                       | 0.46                        | 0.35                 | 0.56     | Uniform               | Truncated Normal, (0.157 - 0.693)    | SNEC 5/13/02   |
| RO15 | P     | Unsaturated Zone 1 b Parameter                             | 5.6                         | 4.05                 | 7.12     | Uniform               | Bounded Lognormal-N (0.5 - 30)       | SNEC 5/13/02   |

|  |      |   |                        |                 |                 |                          |               |              |
|--|------|---|------------------------|-----------------|-----------------|--------------------------|---------------|--------------|
| RO15   | P    | Unsaturated Zone Field Capacity                   | 0.136                  | 0.079           | 0.192           | Uniform                  | None Assigned | SNEC 5/13/02 |
| RO17   | P    | External Gamma Shielding Factor                   | 0.7                    | 4.400E-02       | 1               | Bounded Lognormal-N      |               | SNEC 5/13/02 |
| RO17   | P, B | Indoor Dust Filtration Factor                     | 0.4                    | 0.15            | 0.95            | Uniform                  |               | SNEC 5/13/02 |
| RO17   | B    | Indoor Time Fraction                              | 0.66                   | 0               | 1               | Continuous Linear        |               | SNEC 5/13/02 |
| RO17   | M, P | Inhalation Rate (m³/yr)                           | 8400                   | 4380            | 13100           | Triangular               |               | SNEC 5/13/02 |
| RO17   | P, B | Mass Loading for Inhalation (g/m³)                | 0.0001                 | 0               | 0.0001          | Continuous Linear        |               | SNEC 5/13/02 |
| RO17   | B    | Fraction of Time Spent Outdoors                   | 0.12                   | —               | —               | None Assigned            |               | SNEC 5/13/02 |
| RO18   | B, P | Contaminated Fraction of Aquatic Food             | 1                      | 0               | 1               | Triangular               |               | SNEC 5/13/02 |
| RO18   | B, P | Contaminated Fraction of Drinking Water           | 1                      | —               | —               | None Assigned            |               | SNEC 5/13/02 |
| RO18   | B, P | Contaminated Fraction of Household Water          | Not Used               | N/A             | N/A             | N/A                      |               | SNEC 5/13/02 |
| RO18   | B, P | Contaminated Fraction of Irrigation Water         | 1                      | —               | —               | None Assigned            |               | SNEC 5/13/02 |
| RO18   | B, P | Contaminated Fraction of Livestock Water          | 1                      | —               | —               | None Assigned            |               | SNEC 5/13/02 |
| RO18   | B, P | Contaminated Fraction of Meat                     | 1                      | —               | —               | None Assigned            |               | SNEC 5/13/02 |
| RO18   | B, P | Contaminated Fraction of Milk                     | 1                      | —               | —               | None Assigned            |               | SNEC 5/13/02 |
| RO18   | B, P | Contaminated Fraction of Plant Food               | 1                      | —               | —               | None Assigned            |               | SNEC 5/13/02 |
| RO18   | M, B | Drinking Water Intake (L/yr)                      | 478.5                  | 90.4            | 1860            | Truncated Lognormal-N    |               | SNEC 5/13/02 |
| RO18   | M, B | Fish Consumption (kg/yr)                          | 20.5                   | —               | —               | None Assigned            |               | SNEC 5/13/02 |
| RO18   | M, B | Fruit, Vegetable, and Grain Consumption (kg/yr)   | 111.8                  | 135             | 318             | Triangular               |               | SNEC 5/13/02 |
| RO18   | M, B | Leafy Vegetable Consumption (kg/yr)               | 21.4                   | —               | —               | None Assigned            |               | SNEC 5/13/02 |
| RO18   | M, B | Meat and Poultry Consumption (kg/yr)              | 67                     | —               | —               | None Assigned            |               | SNEC 5/13/02 |
| RO18   | M, B | Milk Consumption (kg/yr)                          | 233                    | 60              | 200             | Triangular               |               | SNEC 5/13/02 |
| RO18   | M, B | Other Seafood Consumption (kg/yr)                 | 0.9                    | —               | —               | None Assigned            |               | SNEC 5/13/02 |
| RO18   | M, B | Soil Ingestion Rate (g/yr)                        | 18.3                   | 0               | 36.5            | Triangular               |               | SNEC 5/13/02 |
| RO19   | M, B | Livestock Water Intake for Milk                   | 60                     | —               | —               | None Assigned            |               | SNEC 5/13/02 |
| RO19   | M, B | Depth of Roots (m)                                | 0.9                    | 0.3             | 1               | Uniform                  |               | SNEC 5/13/02 |
| RO19   | M, B | Depth of Soil Mixing Layer (m)                    | 0.15                   | 0               | 0.6             | Triangular               |               | SNEC 5/13/02 |
| RO19B  | M, B | Weathering Removal Constant of all Vegetation     | 20                     | 5.1             | 84              | Triangular               |               | SNEC 5/13/02 |
| RO19B  | M, B | Wet Crop Yield for Fodder (kg/m²)                 | 1.1                    | —               | —               | None Assigned            |               | SNEC 5/13/02 |
| RO19B  | M, B | Wet Crop Yield for Leafy (kg/m²)                  | 1.5                    | —               | —               | None Assigned            |               | SNEC 5/13/02 |
| RO19B  | M, B | Wet Crop Yield for Non-Leafy (kg/m²)              | 0.7                    | 0.397           | 7.72            | Truncated Lognormal-N    |               | SNEC 5/13/02 |
| RO19B  | M, B | Wet Foliar Inception Fraction of Leafy Vegetables | 0.25                   | 0.06            | 0.95            | Triangular               |               | SNEC 5/13/02 |
| STOR   | B    | Storage Times for Livestock Fodder                | 0                      | —               | —               | None Assigned            |               | SNEC 5/13/02 |
| <b>Distribution Coefficient for Americium &amp; Curium</b> |      |   | <b>Value Used</b>      | <b>ANL Min</b>  | <b>ANL Max</b>  | <b>Distribution Type</b> |               |              |
| R16  | P    | 1 Contaminated Zone (cm³/g)                       | 1000                   | 1000            | 5000            |                          |               | SNEC 5/13/02 |
| R16  | P    | 2 Unsaturated Zone (cm³/g)                        | 1000                   | 1000            | 5000            |                          |               | SNEC 5/13/02 |
| R16  | P    | 3 Saturated Zone (cm³/g)                          | 1000                   | 1000            | 5000            |                          |               | SNEC 5/13/02 |
| <b>Distribution Coefficient for Carbon</b>                 |      |   | <b>ANL Value</b>       | <b>GPU Min.</b> | <b>GPU Max.</b> | <b>Distribution Type</b> |               |              |
| R16  | P    | 1 Contaminated Zone (cm³/g)                       | 0                      | 0               | 5               | Uniform                  |               | SNEC 5/13/02 |
| R16  | P    | 2 Unsaturated Zone (cm³/g)                        | 0                      | 0               | 5               | Uniform                  |               | SNEC 5/13/02 |
| R16  | P    | 3 Saturated Zone (cm³/g)                          | 0                      | 0               | 5               | Uniform                  |               | SNEC 5/13/02 |
| <b>Distribution Coefficient for Cesium</b>                 |      |   | <b>Value Used</b>      | <b>ANL Min</b>  | <b>ANL Max</b>  | <b>Distribution Type</b> |               |              |
| R16  | P    | 1 Contaminated Zone (cm³/g)                       | 2131                   | 2131            | 28341           |                          |               | SNEC 5/13/02 |
| R16  | P    | 2 Unsaturated Zone (cm³/g)                        | 2131                   | 2131            | 28341           |                          |               | SNEC 5/13/02 |
| R16  | P    | 3 Saturated Zone (cm³/g)                          | 2131                   | 2131            | 28341           |                          |               | SNEC 5/13/02 |
| <b>Distribution Coefficient for Cobalt</b>                 |      |   | <b>Value Used</b>      | <b>ANL Min</b>  | <b>ANL Max</b>  | <b>Distribution Type</b> |               |              |
| R16  | P    | 1 Contaminated Zone (cm³/g)                       | 200                    | 200             | 1000            |                          |               | SNEC 5/13/02 |
| R16  | P    | 2 Unsaturated Zone (cm³/g)                        | 200                    | 200             | 1000            |                          |               | SNEC 5/13/02 |
| R16  | P    | 3 Saturated Zone (cm³/g)                          | 200                    | 200             | 1000            |                          |               | SNEC 5/13/02 |
| <b>Distribution Coefficient for Europium</b>               |      |   | <b>Value Used</b>      | <b>ANL Min</b>  | <b>ANL Max</b>  | <b>Distribution Type</b> |               |              |
| R16  | P    | 1 Contaminated Zone (cm³/g)                       | 1000                   | 1000            | 5000            |                          |               | SNEC 5/13/02 |
| R16  | P    | 2 Unsaturated Zone (cm³/g)                        | 1000                   | 1000            | 5000            |                          |               | SNEC 5/13/02 |
| R16  | P    | 3 Saturated Zone (cm³/g)                          | 1000                   | 1000            | 5000            |                          |               | SNEC 5/13/02 |
| <b>Distribution Coefficient for Hydrogen</b>               |      |   | <b>ANL Value (GPU)</b> | <b>GPU Min.</b> | <b>GPU Max.</b> | <b>Distribution Type</b> |               |              |
| R16  | P    | 1 Contaminated Zone (cm³/g)                       | 1 (0.25)               | 0               | 0.5             | Uniform                  |               | SNEC 5/13/02 |
| R16  | P    | 2 Unsaturated Zone (cm³/g)                        | 1 (0.25)               | 0               | 0.5             | Uniform                  |               | SNEC 5/13/02 |
| R16  | P    | 3 Saturated Zone (cm³/g)                          | 1 (0.25)               | 0               | 0.5             | Uniform                  |               | SNEC 5/13/02 |
| <b>Distribution Coefficient for Iron</b>                   |      |   | <b>Value Used</b>      | <b>GPU Min.</b> | <b>GPU Max.</b> | <b>Distribution Type</b> |               |              |
| R16  | P    | 1 Contaminated Zone (cm³/g)                       | 10000                  | 10000           | 50000           |                          |               | SNEC 5/13/02 |
| R16  | P    | 2 Unsaturated Zone (cm³/g)                        | 10000                  | 10000           | 50000           |                          |               | SNEC 5/13/02 |
| R16  | P    | 3 Saturated Zone (cm³/g)                          | 10000                  | 10000           | 50000           |                          |               | SNEC 5/13/02 |
| <b>Distribution Coefficient for Lead</b>                   |      |   | <b>Value Used</b>      | <b>ANL Min</b>  | <b>ANL Max</b>  | <b>Distribution Type</b> |               |              |
| R16  | P    | 1 Contaminated Zone (cm³/g)                       | 9700                   | 9700            | 180000          |                          |               | SNEC 5/13/02 |
| R16  | P    | 2 Unsaturated Zone (cm³/g)                        | 9700                   | 9700            | 180000          |                          |               | SNEC 5/13/02 |
| R16  | P    | 3 Saturated Zone (cm³/g)                          | 9700                   | 9700            | 180000          |                          |               | SNEC 5/13/02 |
| <b>Distribution Coefficient for Nickel</b>                 |      |   | <b>Value Used</b>      | <b>ANL Min</b>  | <b>ANL Max</b>  | <b>Distribution Type</b> |               |              |
| R16  | P    | 1 Contaminated Zone (cm³/g)                       | 1300                   | 1300            | 10000           |                          |               | SNEC 5/13/02 |

|   |   |  |                   |                 |                 |                          |              |
|---|---|--|-------------------|-----------------|-----------------|--------------------------|--------------|
| R16   | P | 2 Unsaturated Zone (cm <sup>3</sup> /g)  | 1300              | 1300            | 10000           |                          | SNEC 5/13/02 |
| R16   | P | 3 Saturated Zone (cm <sup>3</sup> /g)    | 1300              | 1300            | 10000           |                          | SNEC 5/13/02 |
| <b>Distribution Coefficient for Plutonium</b> |   |  | <b>Value Used</b> | <b>ANL Min.</b> | <b>ANL Max</b>  | <b>Distribution Type</b> |              |
| R16   | P | 1 Contaminated Zone (cm <sup>3</sup> /g) | 160               | 160             | 600             |                          | SNEC 5/13/02 |
| R16   | P | 2 Unsaturated Zone (cm <sup>3</sup> /g)  | 180               | 160             | 600             |                          | SNEC 5/13/02 |
| R16   | P | 3 Saturated Zone (cm <sup>3</sup> /g)    | 160               | 160             | 600             |                          | SNEC 5/13/02 |
| <b>Distribution Coefficient for Strontium</b> |   |  | <b>Value Used</b> | <b>ANL Min</b>  | <b>ANL Max.</b> | <b>Distribution Type</b> |              |
| R16   | P | 1 Contaminated Zone (cm <sup>3</sup> /g) | 11                | 11              | 475             |                          | SNEC 5/13/02 |
| R16   | P | 2 Unsaturated Zone (cm <sup>3</sup> /g)  | 11                | 11              | 475             |                          | SNEC 5/13/02 |
| R16   | P | 3 Saturated Zone (cm <sup>3</sup> /g)    | 11                | 11              | 475             |                          | SNEC 5/13/02 |
| <b>Distribution Coefficient for Uranium</b>   |   |  | <b>Value Used</b> | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |              |
| R16   | P | 1 Contaminated Zone (cm <sup>3</sup> /g) | 16                | 16              | 5200            |                          | SNEC 5/13/02 |
| R16   | P | 2 Unsaturated Zone (cm <sup>3</sup> /g)  | 16                | 16              | 5200            |                          | SNEC 5/13/02 |
| R16   | P | 3 Saturated Zone (cm <sup>3</sup> /g)    | 16                | 16              | 5200            |                          | SNEC 5/13/02 |

NOTE: ANL Kd values may be "greater than" values. The ANL Min. value is the lowest reported value for this element and the ANL Max. value is the highest reported value.  
 NOTE: Items in RED type face are SNEC input values.  
 NOTE: Items in GREEN type face are URS input values.  
 NOTE: Items with BLUE background are D & D default values, while items with a YELLOW background are RESRAD default values. Unlisted parameters are RESRAD defaults.

**SPRAY POND DW SCENARIO FOR UNDISTURBED OVERBURDEN MATERIAL**

| Menu | Class | PARAMETERS   | Basic                          | SNEC Range of Values |        | Assigned Distribution | Default Distribution                | Basis  |
|------|-------|--|--------------------------------|----------------------|--------|-----------------------|-------------------------------------|--|
|      |       |  | RESRAD Input                   | Min                  | Max    |                       |                                     |  |
| C14  | P     | Thickness of Soil Evasion Layer of C-14 in Soil (m)        | 0.3                            | 0.2                  | 0.6    | Triangular            |                                     | SNEC 5/13/02   |
| D-5  | P     | Bioaccumulation Factors, Fresh Water                       | Default Values                 | Varies               | Varies | Lognormal             |                                     | SNEC 5/13/02   |
| D-34 | P     | Food Transfer Factors                                      | Default Values                 | Varies               | Varies | Lognormal             |                                     | SNEC 5/13/02   |
| RO11 | P     | Area of Contaminated Zone (m <sup>2</sup> )                | 2000                           | N/A                  | N/A    | N/A                   |                                     | URS Technical Approach 6/18/02                                       |
| RO11 | NRC   | Basic Radiation Dose Limit (mrem/yr) (NRC)                 | 4                              | N/A                  | N/A    | N/A                   |                                     | SNEC 5/13/02   |
| RO11 | P     | Length Parallel to Aquifer Flow (m)                        | 50.5                           | N/A                  | N/A    | N/A                   |                                     | RESRAD Data Collection Handbook                                      |
| RO11 | P     | Thickness of Contaminated Zone 1 (m)                       | 1.000E+00                      | N/A                  | N/A    | N/A                   |                                     | URS Technical Approach 6/18/02                                       |
| RO11 | P     | Time Since Placement of Materials (yr)                     | 0                              | N/A                  | N/A    | N/A                   |                                     | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 1                              | N/A                  | N/A    | N/A                   |                                     | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 3                              | N/A                  | N/A    | N/A                   |                                     | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 10                             | N/A                  | N/A    | N/A                   |                                     | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 35                             | N/A                  | N/A    | N/A                   |                                     | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 150                            | N/A                  | N/A    | N/A                   |                                     | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 300                            | N/A                  | N/A    | N/A                   |                                     | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 1000                           | N/A                  | N/A    | N/A                   |                                     | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 10000                          | N/A                  | N/A    | N/A                   |                                     | SNEC 5/13/02   |
| RO13 | P     | Average Annual Wind Speed (m/sec)                          | N/A                            | N/A                  | N/A    | N/A                   | Bounded Lognormal-N (1.4 - 13)      | URS Technical Approach 6/18/02                                       |
| RO13 | P     | Contaminated Zone Field Capacity                           | 0.136                          | 0.079                | 0.192  | Uniform               | None Assigned                       | SNEC 5/13/02 (Same as unsat zone)                                    |
| RO13 | P     | Contaminated Zone b Parameter                              | 5.6                            | 4.05                 | 7.12   | Uniform               | Bounded Lognormal-N (0.5 - 30)      | SNEC 5/13/02 (Same as unsat zone)                                    |
| RO13 | P     | Contaminated Zone Hydraulic Conductivity (m/yr)            | 32.3                           | 0.362                | 25400  | Loguniform            | Bounded Lognormal-N (0.004 - 9250)  | SNEC 5/13/02 (Same as unsat zone)                                    |
| RO13 | P     | Contaminated Zone Total Porosity                           | 0.46                           | 0.35                 | 0.56   | Uniform               | Truncated Normal, (0.157 - 0.693)   | SNEC 5/13/02 (Same as unsat zone)                                    |
| RO13 | P     | Cover Depth (m)  | 0                              | N/A                  | N/A    | N/A                   |                                     | SNEC 5/13/02 & URS Technical Approach 6/18/02                        |
| RO13 | P, B  | Cover Depth Erosion Rate (m/yr)                            | N/A                            | N/A                  | N/A    | N/A                   |                                     | URS Technical Approach 6/18/02                                       |
| RO13 | P     | Density of Cover Material (g/cc)                           | 1.6                            | 1.28                 | 1.92   | Uniform               | Truncated Normal (0.809 - 2.23)     | SNEC 5/13/02 (Same as unsat zone)                                    |
| RO13 | P     | Density of Saturated Zone (g/cc)                           | 1.6                            | 1.28                 | 1.92   | Uniform               |                                     | SNEC 5/13/02 (Same as fill zone)                                     |
| RO13 | P     | Evapotranspiration Coefficient (m/yr)                      | 0.59                           | 0.5                  | 0.67   | Uniform               | Uniform (0.5 - 0.75)                | SNEC 5/13/02   |
| RO13 | P     | Humidity in Air (g/m <sup>3</sup> )                        | N/A                            | N/A                  | N/A    | N/A                   |                                     | URS Technical Approach 6/18/02                                       |
| RO13 | B     | Irrigation (m/yr)  | 0.2                            |                      |        | None Assigned         |                                     | SNEC 5/13/02   |
| RO13 | B     | Irrigation Mode (Overhead)                                 | Overhead                       | N/A                  | N/A    | N/A                   |                                     | SNEC 5/13/02   |
| RO13 | P     | Precipitation (m/yr)                                       | 0.936                          | 0.688                | 1.327  | Uniform               | None Assigned                       | SNEC 5/13/02   |
| RO13 | P     | Runoff Coefficient   | 0.35                           | 0.3                  | 0.4    | Uniform               | Uniform (0.1 - 0.8)                 | SNEC 5/13/02   |
| RO13 | P     | Watershed Area for Nearby Stream or Pond (m <sup>2</sup> ) | 5.00E+06                       |                      |        | None Assigned         | None Assigned                       | SNEC 5/13/02   |
| RO14 | P     | Density of Saturated Zone (g/cc)                           | 1.6                            | 1.28                 | 1.92   | Uniform               | Truncated Normal (0.809 - 2.23)     | SNEC 5/13/02   |
| RO14 | P     | Model Non-dispersion (ND) or Mass-Balance (MB)             | Mass Balance                   | N/A                  | N/A    | N/A                   |                                     | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone b Parameter                                 | Not Used                       | N/A                  | N/A    | N/A                   |                                     | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone Effective Porosity                          | 0.028                          | 0.005                | 0.05   | Loguniform            | Truncated Normal (0.075 - 0.635)    | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone Hydraulic Conductivity (m/yr)               | 67.91                          | 15.59                | 909.53 | Uniform               | Bounded Lognormal-N (0.004 - 9250)  | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone Hydraulic Gradient                          | 0.02                           | 0.013                | 0.03   | Uniform               | Bounded Lognormal-N (0.00007 - 0.5) | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone Total Porosity                              | 0.36                           | 0.31                 | 0.41   | Uniform               | Truncated Normal, (0.157 - 0.693)   | SNEC 5/13/02   |
| RO14 | P     | Water Table Drop Rate (m/yr)                               | 0                              |                      |        | None Assigned         | None Assigned                       | SNEC 5/13/02   |
| RO14 | P     | Well Pump Intake Depth (m)                                 | 30.2<br>286.2                  | 10.2                 | 50.2   | Uniform               | Triangular (6 - 30)                 | SNEC 5/13/02 + 0.2m excavation as per URS Technical Approach 6/18/02 |
| RO14 | B, P  | Well Pumping Rate (m <sup>3</sup> /yr)                     | (listed as not used by RESRAD) | 207.3                | 365    | Uniform               | None Assigned                       | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone Field Capacity                              | 0.136                          | 0.079                | 0.192  | Uniform               | None Assigned                       | SNEC 5/13/02   |
| RO15 | P     | Density of Unsaturated Zone 1 (g/cc)                       | 1.6                            | 1.28                 | 1.92   | Uniform               | Truncated Normal (0.809 - 2.23)     | SNEC 5/13/02   |
| RO15 | P     | Effective Porosity of Unsaturated Zone 1                   | 0.41                           | 0.28                 | 0.54   | Uniform               | Truncated Normal (0.075 - 0.635)    | SNEC 5/13/02   |
| RO15 | P     | Hydraulic Conductivity of Unsaturated Zone 1 (m/yr)        | 32.3                           | 0.362                | 25400  | Loguniform            | Bounded Lognormal-N (0.004 - 9250)  | SNEC 5/13/02   |
| RO15 | P     | Number of Unsaturated Zone Strata                          | 1                              | N/A                  | N/A    | N/A                   | N/A                                 | SNEC 5/13/02   |
| RO15 | P     | Thickness of Unsaturated Zone 1 (m)                        | 0.0010                         | N/A                  | N/A    | N/A                   | Bounded Lognormal-N (0.18 - 320)    | URS Technical Approach 6/18/02 (effectively zero)                    |
| RO15 | P     | Total porosity of Unsaturated Zone 1                       | 0.46                           | 0.35                 | 0.56   | Uniform               | Truncated Normal, (0.157 - 0.693)   | SNEC 5/13/02   |
| RO15 | P     | Unsaturated Zone 1 b Parameter                             | 5.6                            | 4.05                 | 7.12   | Uniform               | Bounded Lognormal-N (0.5 - 30)      | SNEC 5/13/02   |
| RO15 | P     | Unsaturated Zone Field Capacity                            | 0.136                          | 0.079                | 0.192  | Uniform               | None Assigned                       | SNEC 5/13/02   |
| RO17 | P     | External Gamma Shielding Factor                            | N/A                            | N/A                  | N/A    | N/A                   |                                     | URS Technical Approach 6/18/02                                       |
| RO17 | P, B  | Indoor Dust Filtration Factor                              | N/A                            | N/A                  | N/A    | N/A                   |                                     | URS Technical Approach 6/18/02                                       |
| RO17 | B     | Indoor Time Fraction                                       | N/A                            | N/A                  | N/A    | N/A                   |                                     | URS Technical Approach 6/18/02                                       |
| RO17 | M, P  | Inhalation Rate (m <sup>3</sup> /yr)                       | N/A                            | N/A                  | N/A    | N/A                   |                                     | URS Technical Approach 6/18/02                                       |

|  |      |   |                        |                 |                 |                          |                                |
|--|------|---|------------------------|-----------------|-----------------|--------------------------|--------------------------------|
| RO17   | P, B | Mass Loading for Inhalation (g/m <sup>3</sup> )   | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO17   | B    | Fraction of Time Spent Outdoors                   | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Aquatic Food             | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Drinking Water           | 1                      | —               | —               | None Assigned            | SNEC 5/13/02                   |
| RO18   | B, P | Contaminated Fraction of Household Water          | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Irrigation Water         | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Livestock Water          | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Meat                     | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Milk                     | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Plant Food               | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | M, B | Drinking Water Intake (L/yr)                      | 478.5                  | 90.4            | 1860            | Truncated Lognormal-N    | SNEC 5/13/02                   |
| RO18   | M, B | Fish Consumption (kg/yr)                          | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | M, B | Fruit, Vegetable, and Grain Consumption (kg/yr)   | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | M, B | Leafy Vegetable Consumption (kg/yr)               | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | M, B | Meat and Poultry Consumption (kg/yr)              | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | M, B | Milk Consumption                                  | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | M, B | Other Seafood Consumption (kg/yr)                 | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | M, B | Soil Ingestion Rate (g/yr)                        | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO19   | M, B | Livestock Water Intake for Milk                   | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO19   | M, B | Depth of Roots (m)                                | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO19   | M, B | Depth of Soil Mixing Layer (m)                    | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO19B  | M, B | Weathering Removal Constant of all Vegetation     | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO19B  | M, B | Wet Crop Yield for Fodder (kg/m <sup>2</sup> )    | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO19B  | M, B | Wet Crop Yield for Leafy (kg/m <sup>2</sup> )     | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO19B  | M, B | Wet Crop Yield for Non-Leafy (kg/m <sup>2</sup> ) | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| RO19B  | M, B | Wet Foliar Inception Fraction of Leafy Vegetables | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| STOR   | B    | Storage Times for Livestock Fodder                | N/A                    | N/A             | N/A             | N/A                      | URS Technical Approach 6/18/02 |
| <b>Distribution Coefficient for Americium &amp; Curium</b> |      |   | <b>Value Used</b>      | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 1000                   | 1000            | 5000            | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 1000                   | 1000            | 5000            | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 1000                   | 1000            | 5000            | Uniform                  | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Carbon</b>                 |      |   | <b>ANL Value</b>       | <b>GPU Min.</b> | <b>GPU Max.</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 1                      | 0               | 5               | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 1                      | 0               | 5               | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 1                      | 0               | 5               | Uniform                  | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Cesium</b>                 |      |   | <b>Value Used</b>      | <b>ANL Min</b>  | <b>ANL Max</b>  | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 2131                   | 2131            | 28341           | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 2131                   | 2131            | 28341           | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 2131                   | 2131            | 28341           | Uniform                  | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Cobalt</b>                 |      |   | <b>Value Used</b>      | <b>ANL Min</b>  | <b>ANL Max</b>  | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 200                    | 200             | 1000            | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 200                    | 200             | 1000            | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 200                    | 200             | 1000            | Uniform                  | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Europium</b>               |      |   | <b>Value Used</b>      | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 1000                   | 1000            | 5000            | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 1000                   | 1000            | 5000            | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 1000                   | 1000            | 5000            | Uniform                  | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Hydrogen</b>               |      |   | <b>ANL Value (GPU)</b> | <b>GPU Min.</b> | <b>GPU Max.</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 1 (0.25)               | 0               | 0.5             | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 1 (0.25)               | 0               | 0.5             | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 1 (0.25)               | 0               | 0.5             | Uniform                  | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Iron</b>                   |      |   | <b>Value Used</b>      | <b>GPU Min.</b> | <b>GPU Max.</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 10000                  | 10000           | 50000           | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 10000                  | 10000           | 50000           | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 10000                  | 10000           | 50000           | Uniform                  | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Lead</b>                   |      |   | <b>Value Used</b>      | <b>ANL Min</b>  | <b>ANL Max</b>  | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 9700                   | 9700            | 160000          | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 9700                   | 9700            | 160000          | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 9700                   | 9700            | 160000          | Uniform                  | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Nickel</b>                 |      |   | <b>Value Used</b>      | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 1300                   | 1300            | 10000           | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 1300                   | 1300            | 10000           | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 1300                   | 1300            | 10000           | Uniform                  | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Plutonium</b>              |      |   | <b>Value Used</b>      | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 160                    | 160             | 600             | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 160                    | 160             | 600             | Uniform                  | SNEC 5/13/02                   |

|   |   |   |                   |                 |                 |                          |              |
|---|---|---|-------------------|-----------------|-----------------|--------------------------|--------------|
| R16   | P | 3. Saturated Zone (cm <sup>3</sup> /g)    | 160               | 160             | 600             |                          | SNEC 5/13/02 |
| <b>Distribution Coefficient for Strontium</b>   |   |   | <b>Value Used</b> | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |              |
| R16   | P | 1. Contaminated Zone (cm <sup>3</sup> /g) | 11                | 11              | 475             |                          | SNEC 5/13/02 |
| R16   | P | 2. Unsaturated Zone (cm <sup>3</sup> /g)  | 11                | 11              | 475             |                          | SNEC 5/13/02 |
| R16   | P | 3. Saturated Zone (cm <sup>3</sup> /g)    | 11                | 11              | 475             |                          | SNEC 5/13/02 |
| <b>Distribution Coefficient for Uranium</b>   |   |   | <b>Value Used</b> | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |              |
| R16   | P | 1. Contaminated Zone (cm <sup>3</sup> /g) | 16                | 16              | 5200            |                          | SNEC 5/13/02 |
| R16   | P | 2. Unsaturated Zone (cm <sup>3</sup> /g)  | 16                | 16              | 5200            |                          | SNEC 5/13/02 |
| R16   | P | 3. Saturated Zone (cm <sup>3</sup> /g)    | 16                | 16              | 5200            |                          | SNEC 5/13/02 |
| <p>NOTE ANL Kd values may be "greater than" values. The ANL Min. value is the lowest reported value for this element and the ANL Max. value is the highest reported value</p> <p>NOTE Items in RED type face are SNEC input values.</p> <p>NOTE Items in GREEN type face are URS input values.</p> <p>NOTE Items with BLUE background are D &amp; D default values, while items with a YELLOW background are RESRAD default values. Unlisted parameters are RESRAD defaults</p> |   |   |                   |                 |                 |                          |              |

**SPRAY POND DW SCENARIO FOR EXCAVATED OVERBURDEN MATERIAL**

| Menu | Class | PARAMETERS   | Basic                          | SNEC Range of Values |          | Assigned Distribution | Default Distribution                 | Basis   |
|------|-------|--|--------------------------------|----------------------|----------|-----------------------|--------------------------------------|---|
|      |       |  | RESRAD Input                   | Min                  | Max      |                       |                                      |   |
| C14  | P     | Thickness of Soil Evasion Layer of C-14 in Soil (m)        | 0.3                            | 0.2                  | 0.6      | Triangular            |                                      | SNEC 5/13/02  |
| D-6  | P     | Bioaccumulation Factors, Fresh Water                       | Default Values                 | Varies               | Varies   | Lognormal             |                                      | SNEC 5/13/02  |
| D-34 | P     | Food Transfer Factors                                      | Default Values                 | Varies               | Varies   | Lognormal             |                                      | SNEC 5/13/02  |
| RO11 | P     | Area of Contaminated Zone (m <sup>2</sup> )                | 2000                           | N/A                  | N/A      | N/A                   |                                      | URS Technical Approach 6/18/02  |
| RO11 | NRC   | Basic Radiation Dose Limit (mrem/yr) (NRC)                 | 4                              | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Length Parallel to Aquifer Flow (m)                        | 50.5                           | N/A                  | N/A      | N/A                   |                                      | RESRAD Data Collection Handbook   |
| RO11 | P     | Thickness of Contaminated Zone 1 (m)                       | 2.000E-01                      | N/A                  | N/A      | N/A                   |                                      | URS Technical Approach 6/18/02  |
| RO11 | P     | Time Since Placement of Materials (yr)                     | 0                              | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 1                              | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 3                              | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 10                             | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 35                             | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 150                            | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 300                            | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 1000                           | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 10000                          | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO13 | P     | Average Annual Wind Speed (m/sec)                          | N/A                            | N/A                  | N/A      | N/A                   | Bounded Lognormal-N (1.4 - 13)       | URS Technical Approach 6/18/02  |
| RO13 | P     | Contaminated Zone Field Capacity                           | 0.136                          | 0.079                | 0.192    | Uniform               | None Assigned                        | SNEC 5/13/02 (Same as unsat zone)   |
| RO13 | P     | Contaminated Zone b Parameter                              | 5.6                            | 4.05                 | 7.12     | Uniform               | Bounded Lognormal-N (0.5 - 30)       | SNEC 5/13/02 (Same as unsat zone)   |
| RO13 | P, B  | Contaminated Zone Erosion Rate (m/yr)                      | 0.000345                       | 0.00009              | 0.0006   | Loguniform            | Continuous Logarithmic (5E-08 - 0.2) | SNEC 5/13/02  |
| RO13 | P     | Contaminated Zone Hydraulic Conductivity (m/yr)            | 50.11                          | 7.98                 | 13154.77 | Loguniform            | Bounded Lognormal-N (0.004 - 9250)   | Weighted average of fill and overburden as per URS Technical Approach 6/18/02                   |
| RO13 | P     | Contaminated Zone Total Porosity                           | 0.41                           | 0.33                 | 0.485    | Uniform               | Truncated Normal, (0.157 - 0.693)    | Weighted average of fill and overburden as per URS Technical Approach 6/18/02                   |
| RO13 | P     | Cover Depth (m)  | 0                              | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02 & URS Technical Approach 6/18/02   |
| RO13 | P     | Density of Contaminated Zone (g/cc)                        | 1.6                            | 1.28                 | 1.92     | Uniform               | Truncated Normal (0.809 - 2.23)      | SNEC 5/13/02 (Same as unsat zone)   |
| RO13 | P     | Evapotranspiration Coefficient (m/yr)                      | 0.59                           | 0.5                  | 0.67     | Uniform               | Uniform (0.5 - 0.75)                 | SNEC 5/13/02  |
| RO13 | P     | Humidity in Air (g/m <sup>3</sup> )                        | 8 (H-3) not used for others    | 2.58E+00             | 2.03E+01 | Truncated Lognormal-N |                                      | SNEC 5/13/02  |
| RO13 | B     | Irrigation (m/yr)  | 0.2                            | ---                  | ---      | None Assigned         |                                      | SNEC 5/13/02  |
| RO13 | B     | Irrigation Mode (Overhead)                                 | Overhead                       | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO13 | P     | Precipitation (m/yr)                                       | 0.936                          | 0.688                | 1.327    | Uniform               | None Assigned                        | SNEC 5/13/02  |
| RO13 | P     | Runoff Coefficient   | 0.35                           | 0.3                  | 0.4      | Uniform               | Uniform (0.1 - 0.8)                  | SNEC 5/13/02  |
| RO13 | P     | Watershed Area for Nearby Stream or Pond (m <sup>2</sup> ) | 5.00E+06                       | ---                  | ---      | None Assigned         | None Assigned                        | SNEC 5/13/02  |
| RO14 | P     | Density of Saturated Zone (g/cc)                           | 1.6                            | 1.28                 | 1.92     | Uniform               | Truncated Normal (0.809 - 2.23)      | SNEC 5/13/02  |
| RO14 | P     | Model Non-dispersion (ND) or Mass-Balance (MB)             | Non-Dispersion                 | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO14 | P     | Saturated Zone b Parameter                                 | Not Used                       | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO14 | P     | Saturated Zone Effective Porosity                          | 0.028                          | 0.005                | 0.05     | Loguniform            | Truncated Normal (0.075 - 0.635)     | SNEC 5/13/02  |
| RO14 | P     | Saturated Zone Hydraulic Conductivity (m/yr)               | 67.91                          | 15.59                | 909.53   | Uniform               | Bounded Lognormal-N (0.004 - 9250)   | SNEC 5/13/02  |
| RO14 | P     | Saturated Zone Hydraulic Gradient                          | 0.02                           | 0.013                | 0.03     | Uniform               | Bounded Lognormal-N (0.0007 - 0.5)   | SNEC 5/13/02  |
| RO14 | P     | Saturated Zone Total Porosity                              | 0.36                           | 0.31                 | 0.41     | Uniform               | Truncated Normal, (0.157 - 0.693)    | SNEC 5/13/02  |
| RO14 | P     | Water Table Drop Rate (m/yr)                               | 0                              | ---                  | ---      | None Assigned         | None Assigned                        | SNEC 5/13/02  |
| RO14 | P     | Well Pump Intake Depth (m)                                 | 30.2                           | 10.2                 | 50.2     | Uniform               | Trangular (6 -30)                    | SNEC 5/13/02 + 0.2m excavation as per URS Technical Approach 6/18/02                            |
| RO14 | B, P  | Well Pumping Rate (m <sup>3</sup> /yr)                     | (listed as not used by RESRAD) | 207.3                | 365      | Uniform               | None Assigned                        | SNEC 5/13/02  |
| RO14 | P     | Saturated Zone Field Capacity                              | 0.136                          | 0.079                | 0.192    | Uniform               | None Assigned                        | SNEC 5/13/02  |
| RO15 | P     | Density of Unsaturated Zone 1 (g/cc)                       | 1.6                            | 1.28                 | 1.92     | Uniform               | Truncated Normal (0.809 - 2.23)      | SNEC 5/13/02  |
| RO15 | P     | Effective Porosity of Unsaturated Zone 1                   | 0.41                           | 0.28                 | 0.54     | Uniform               | Truncated Normal (0.075 - 0.635)     | SNEC 5/13/02  |
| RO15 | P     | Hydraulic Conductivity of Unsaturated Zone 1 (m/yr)        | 32.3                           | 0.362                | 25400    | Loguniform            | Bounded Lognormal-N (0.004 - 9250)   | SNEC 5/13/02  |
| RO15 | P     | Number of Unsaturated Zone Strata                          | 1                              | N/A                  | N/A      | N/A                   | N/A                                  | SNEC 5/13/02  |
| RO15 | P     | Thickness of Unsaturated Zone 1 (m)                        | 1.2500                         | 1.0000               | 1.5000   | Uniform               | Bounded Lognormal-N (0.18 - 320)     | SNEC 5/13/02 + 1.0m original fill soil as per URS Technical Approach 6/18/02 (effectively zero) |
| RO15 | P     | Total porosity of Unsaturated Zone 1                       | 0.46                           | 0.35                 | 0.56     | Uniform               | Truncated Normal, (0.157 - 0.693)    | SNEC 5/13/02  |
| RO15 | P     | Unsaturated Zone 1 b Parameter                             | 5.6                            | 4.05                 | 7.12     | Uniform               | Bounded Lognormal-N (0.5 - 30)       | SNEC 5/13/02  |
| RO15 | P     | Unsaturated Zone Field Capacity                            | 0.136                          | 0.079                | 0.192    | Uniform               | None Assigned                        | SNEC 5/13/02  |
| RO17 | P     | External Gamma Shielding Factor                            | N/A                            | N/A                  | N/A      | N/A                   |                                      | URS Technical Approach 6/18/02  |
| RO17 | P, B  | Indoor Dust Filtration Factor                              | N/A                            | N/A                  | N/A      | N/A                   |                                      | URS Technical Approach 6/18/02  |



|  |      |   |                        |                |                |                          |                                |
|--|------|---|------------------------|----------------|----------------|--------------------------|--------------------------------|
| RO17   | B    | Indoor Time Fraction                              | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO17   | M, P | Inhalation Rate (m <sup>3</sup> /yr)              | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO17   | P, B | Mass Loading for Inhalation (g/m <sup>3</sup> )   | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO17   | B    | Fraction of Time Spent Outdoors                   | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Aquatic Food             | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Drinking Water           | 1                      | —              | —              | None Assigned            | SNEC 5/13/02                   |
| RO18   | B, P | Contaminated Fraction of Household Water          | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Irrigation Water         | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Livestock Water          | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Meat                     | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Milk                     | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Plant Food               | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | M, B | Drinking Water Intake (L/yr)                      | 478.5                  | 90.4           | 1860           | Truncated Lognormal-N    | URS Technical Approach 6/18/02 |
| RO18   | M, B | Fish Consumption (kg/yr)                          | N/A                    | N/A            | N/A            | N/A                      | SNEC 5/13/02                   |
| RO18   | M, B | Fruit, Vegetable, and Grain Consumption (kg/yr)   | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | M, B | Leafy Vegetable Consumption (kg/yr)               | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | M, B | Meat and Poultry Consumption (kg/yr)              | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | M, B | Milk Consumption                                  | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | M, B | Other Seafood Consumption (kg/yr)                 | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO18   | M, B | Soil Ingestion Rate (g/yr)                        | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO19   | M, B | Livestock Water Intake for Milk                   | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO19   | M, B | Depth of Roots (m)                                | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO19   | M, B | Depth of Soil Mixing Layer (m)                    | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO19B  | M, B | Weathering Removal Constant of all Vegetation     | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO19B  | M, B | Wet Crop Yield for Fodder (kg/m <sup>2</sup> )    | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO19B  | M, B | Wet Crop Yield for Leafy (kg/m <sup>2</sup> )     | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO19B  | M, B | Wet Crop Yield for Non-Leafy (kg/m <sup>2</sup> ) | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| RO19B  | M, B | Wet Foliar Inception Fraction of Leafy Vegetables | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| STOR   | B    | Storage Times for Livestock Fodder                | N/A                    | N/A            | N/A            | N/A                      | URS Technical Approach 6/18/02 |
| <b>Distribution Coefficient for Americium &amp; Curium</b> |      |   | <b>Value Used</b>      | <b>ANL Min</b> | <b>ANL Max</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 1000                   | 1000           | 5000           |                          | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 1000                   | 1000           | 5000           |                          | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 1000                   | 1000           | 5000           |                          | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Carbon</b>                 |      |   | <b>ANL Value</b>       | <b>GPU Min</b> | <b>GPU Max</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 1                      | 0              | 5              | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 1                      | 0              | 5              | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 1                      | 0              | 5              | Uniform                  | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Cesium</b>                 |      |   | <b>Value Used</b>      | <b>ANL Min</b> | <b>ANL Max</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 2131                   | 2131           | 28341          |                          | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 2131                   | 2131           | 28341          |                          | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 2131                   | 2131           | 28341          |                          | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Cobalt</b>                 |      |   | <b>Value Used</b>      | <b>ANL Min</b> | <b>ANL Max</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 200                    | 200            | 1000           |                          | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 200                    | 200            | 1000           |                          | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 200                    | 200            | 1000           |                          | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Europium</b>               |      |   | <b>Value Used</b>      | <b>ANL Min</b> | <b>ANL Max</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 1000                   | 1000           | 5000           |                          | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 1000                   | 1000           | 5000           |                          | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 1000                   | 1000           | 5000           |                          | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Hydrogen</b>               |      |   | <b>ANL Value (GPU)</b> | <b>GPU Min</b> | <b>GPU Max</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 1 (0.25)               | 0              | 0.5            | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 1 (0.25)               | 0              | 0.5            | Uniform                  | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 1 (0.25)               | 0              | 0.5            | Uniform                  | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Iron</b>                   |      |   | <b>Value Used</b>      | <b>GPU Min</b> | <b>GPU Max</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 10000                  | 10000          | 50000          |                          | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 10000                  | 10000          | 50000          |                          | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 10000                  | 10000          | 50000          |                          | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Lead</b>                   |      |   | <b>Value Used</b>      | <b>ANL Min</b> | <b>ANL Max</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 9700                   | 9700           | 160000         |                          | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 9700                   | 9700           | 160000         |                          | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 9700                   | 9700           | 160000         |                          | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Nickel</b>                 |      |   | <b>Value Used</b>      | <b>ANL Min</b> | <b>ANL Max</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 1300                   | 1300           | 10000          |                          | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 1300                   | 1300           | 10000          |                          | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 1300                   | 1300           | 10000          |                          | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Plutonium</b>              |      |   | <b>Value Used</b>      | <b>ANL Min</b> | <b>ANL Max</b> | <b>Distribution Type</b> |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 160                    | 160            | 600            |                          | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 160                    | 160            | 600            |                          | SNEC 5/13/02                   |

Spray Pond DW Scenario-OB Matl to Surface.xls

DW Scenano of Excavated Overburden Material

7/27/02



| R16  | P | 3. Saturated Zone (cm <sup>3</sup> /g)    | 160        | 160     | 600     |                   | SNEC 5/13/02 |
|--|---|---|------------|---------|---------|-------------------|--------------|
| Distribution Coefficient for Strontium   |   |   | Value Used | ANL Min | ANL Max | Distribution Type |              |
| R16  | P | 1. Contaminated Zone (cm <sup>3</sup> /g) | 11         | 11      | 475     |                   | SNEC 5/13/02 |
| R16  | P | 2. Unsaturated Zone (cm <sup>3</sup> /g)  | 11         | 11      | 475     |                   | SNEC 5/13/02 |
| R16  | P | 3. Saturated Zone (cm <sup>3</sup> /g)    | 11         | 11      | 475     |                   | SNEC 5/13/02 |
| Distribution Coefficient for Uranium   |   |   | Value Used | ANL Min | ANL Max | Distribution Type |              |
| R16  | P | 1. Contaminated Zone (cm <sup>3</sup> /g) | 16         | 16      | 5200    |                   | SNEC 5/13/02 |
| R16  | P | 2. Unsaturated Zone (cm <sup>3</sup> /g)  | 16         | 16      | 5200    |                   | SNEC 5/13/02 |
| R16  | P | 3. Saturated Zone (cm <sup>3</sup> /g)    | 16         | 16      | 5200    |                   | SNEC 5/13/02 |
| NOTE ANL Kd values may be "greater than" values. The ANL Min value is the lowest reported value for this element and the ANL Max value is the highest reported value |   |   |            |         |         |                   |              |
| NOTE Items in RED type face are SNEC input values.   |   |   |            |         |         |                   |              |
| NOTE Items in GREEN type face are URS input values.  |   |   |            |         |         |                   |              |
| NOTE Items with BLUE background are D & D default values, while items with a YELLOW background are RESRAD default values. Unlisted parameters are RESRAD defaults.   |   |   |            |         |         |                   |              |

SSGS DW SCENARIO FOR EXCAVATED BACKFILL ON SURFACE

| Menu | Class | PARAMETERS   | Basic                                     | SNEC Range of Values |          | Assigned Distribution | Default Distribution                 | Basis   |
|------|-------|--|---|----------------------|----------|-----------------------|--------------------------------------|---|
|      |       |  | RESRAD Input                              | Min                  | Max      |                       |                                      |   |
| C14  | P     | Thickness of Soil Evasion Layer of C-14 in Soil (m)        | 0.3                                       | 0.2                  | 0.6      | Triangular            |                                      | SNEC 5/13/02  |
| D-5  | P     | Bioaccumulation Factors, Fresh Water                       | Default Values                            | Varies               | Varies   | Lognormal             |                                      | SNEC 5/13/02  |
| D-34 | P     | Food Transfer Factors                                      | Default Values                            | Varies               | Varies   | Lognormal             |                                      | SNEC 5/13/02  |
| RO11 | P     | Area of Contaminated Zone (m <sup>2</sup> )                | 2000                                      | N/A                  | N/A      | N/A                   |                                      | URS Technical Approach 6/18/02  |
| RO11 | NRC   | Basic Radiation Dose Limit (mrem/yr) (NRC)                 | 4   | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Length Parallel to Aquifer Flow (m)                        | 50.5                                      | N/A                  | N/A      | N/A                   |                                      | RESRAD Data Collection Handbook   |
| RO11 | P     | Thickness of Contaminated Zone 1 (m)                       | 2.000E-01                                 | N/A                  | N/A      | N/A                   |                                      | URS Technical Approach 6/18/02  |
| RO11 | P     | Time Since Placement of Materials (yr)                     | 0   | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 1   | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 3   | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 10  | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 35  | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 150                                       | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 300                                       | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 1000                                      | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 10000                                     | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO13 | P     | Average Annual Wind Speed (m/sec)                          | N/A                                       | N/A                  | N/A      | N/A                   | Bounded Lognormal-N (1.4 - 13)       | SNEC 5/13/02  |
| RO13 | P     | Contaminated Zone Field Capacity                           | 0.1360                                    | 0.0790               | 0.1920   | Uniform               | None Assigned                        | Backfill properties assumed same as fill soil as per GPU direction 5/13/02                      |
| RO13 | P     | Contaminated Zone b Parameter                              | 5.60                                      | 4.05                 | 7.12     | Uniform               | Bounded Lognormal-N (0.5 - 30)       | Backfill properties assumed same as fill soil as per GPU direction 5/13/02                      |
| RO13 | P, B  | Contaminated Zone Erosion Rate (m/yr)                      | 0.000345                                  | 0.00009              | 0.0006   | Loguniform            | Continuous Logarithmic (5E-08 - 0.2) | Backfill properties assumed same as fill soil as per GPU direction 5/13/02                      |
| RO13 | P     | Contaminated Zone Hydraulic Conductivity (m/yr)            | 32.30                                     | 0.36                 | 25400.00 | Loguniform            | Bounded Lognormal-N (0.004 - 9250)   | Backfill properties assumed same as fill soil as per GPU direction 5/13/02                      |
| RO13 | P     | Contaminated Zone Total Porosity                           | 0.460                                     | 0.350                | 0.560    | Uniform               | Truncated Normal, (0.157 - 0.693)    | Backfill properties assumed same as fill soil as per GPU direction 5/13/02                      |
| RO13 | P     | Density of Contaminated Zone (g/cc)                        | 1.6                                       | 1.28                 | 1.92     | Uniform               | Truncated Normal (0.809 - 2.23)      | SNEC 5/13/02 (Same as unsat zone)   |
| RO13 | P     | Evapotranspiration Coefficient (m/yr)                      | 0.59                                      | 0.5                  | 0.67     | Uniform               | Uniform (0.5 - 0.75)                 | SNEC 5/13/02  |
| RO13 | P     | Humidity in Air (g/m <sup>3</sup> )                        | 8 (H-3) not used for others               | 2.58E+00             | 2.03E+01 | Truncated Lognormal-N |                                      | SNEC 5/13/02  |
| RO13 | B     | Irrigation (m/yr)  | 0.2                                       | —                    | —        | None Assigned         |                                      | SNEC 5/13/02  |
| RO13 | B     | Irrigation Mode (Overhead)                                 | Overhead                                  | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO13 | P     | Precipitation (m/yr)                                       | 0.936                                     | 0.688                | 1.327    | Uniform               | None Assigned                        | SNEC 5/13/02  |
| RO13 | P     | Runoff Coefficient   | 0.35                                      | 0.3                  | 0.4      | Uniform               | Uniform (0.1 - 0.8)                  | SNEC 5/13/02  |
| RO13 | P     | Watershed Area for Nearby Stream or Pond (m <sup>2</sup> ) | 5.00E+06                                  | —                    | —        | None Assigned         | None Assigned                        | SNEC 5/13/02  |
| RO14 | P     | Density of Saturated Zone (g/cc)                           | 1.6                                       | 1.28                 | 1.92     | Uniform               | Truncated Normal (0.809 - 2.23)      | SNEC 5/13/02  |
| RO14 | P     | Model Non-dispersion (ND) or Mass-Balance (MB)             | Non-Dispersion                            | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO14 | P     | Saturated Zone b Parameter                                 | Not Used                                  | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02  |
| RO14 | P     | Saturated Zone Effective Porosity                          | 0.41                                      | 0.28                 | 0.54     | Loguniform            | Truncated Normal (0.075 - 0.635)     | SNEC 5/13/02  |
| RO14 | P     | Saturated Zone Hydraulic Conductivity (m/yr)               | 32.3                                      | 0.362                | 25400    | Uniform               | Bounded Lognormal-N (0.004 - 9250)   | SNEC 5/13/02  |
| RO14 | P     | Saturated Zone Hydraulic Gradient                          | 0.02                                      | 0.013                | 0.03     | Uniform               | Bounded Lognormal-N (0.00007 - 0.5)  | SNEC 5/13/02  |
| RO14 | P     | Saturated Zone Total Porosity                              | 0.46                                      | 0.35                 | 0.56     | Uniform               | Truncated Normal, (0.157 - 0.693)    | SNEC 5/13/02  |
| RO14 | P     | Water Table Drop Rate (m/yr)                               | 0   | —                    | —        | None Assigned         | None Assigned                        | SNEC 5/13/02  |
| RO14 | P     | Well Pump Intake Depth (m)                                 | 30.2                                      | 10.2                 | 50.2     | Uniform               | Triangular (6 - 30)                  | SNEC 5/13/02 + 0.2m excavation as per URS Technical Approach 6/18/02                            |
| RO14 | B, P  | Well Pumping Rate (m <sup>3</sup> /yr)                     | 286.2<br>(reported as not used by RESRAD) | 207.3                | 365      | Uniform               | None Assigned                        | SNEC 5/13/02  |
| RO14 | P     | Saturated Zone Field Capacity                              | 0.136                                     | 0.079                | 0.192    | Uniform               | None Assigned                        | SNEC 5/13/02  |
| RO15 | P     | Density of Unsaturated Zone 1 (g/cc)                       | 1.6                                       | 1.28                 | 1.92     | Uniform               | Truncated Normal (0.809 - 2.23)      | SNEC 5/13/02  |
| RO15 | P     | Effective Porosity of Unsaturated Zone 1                   | 0.41                                      | 0.28                 | 0.54     | Uniform               | Truncated Normal (0.075 - 0.635)     | SNEC 5/13/02  |
| RO15 | P     | Hydraulic Conductivity of Unsaturated Zone 1 (m/yr)        | 32.3                                      | 0.362                | 25400    | Loguniform            | Bounded Lognormal-N (0.004 - 9250)   | SNEC 5/13/02  |
| RO15 | P     | Number of Unsaturated Zone Strata                          | 1   | N/A                  | N/A      | N/A                   | N/A                                  | SNEC 5/13/02  |
| RO15 | P     | Thickness of Unsaturated Zone 1 (m)                        | 1.2500                                    | 1.0000               | 1.5000   | Uniform               | Bounded Lognormal-N (0.18 - 320)     | SNEC 5/13/02 + 1.0m original fill soil as per URS Technical Approach 6/18/02 (effectively zero) |
| RO15 | P     | Total porosity of Unsaturated Zone 1                       | 0.46                                      | 0.35                 | 0.56     | Uniform               | Truncated Normal, (0.157 - 0.693)    | SNEC 5/13/02  |
| RO15 | P     | Unsaturated Zone 1 b Parameter                             | 5.6                                       | 4.05                 | 7.12     | Uniform               | Bounded Lognormal-N (0.5 - 30)       | SNEC 5/13/02  |

|  |      |   |                        |                 |                 |                          |               |                                |
|--|------|---|------------------------|-----------------|-----------------|--------------------------|---------------|--------------------------------|
| RO15   | P    | Unsaturated Zone Field Capacity                   | 0 136                  | 0 079           | 0 192           | Uniform                  | None Assigned | SNEC 5/13/02                   |
| RO17   | P    | External Gamma Shielding Factor                   | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO17   | P, B | Indoor Dust Filtration Factor                     | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO17   | B    | Indoor Time Fraction                              | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO17   | M, P | Inhalation Rate (m <sup>3</sup> /yr)              | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO17   | P, B | Mass Loading for Inhalation (g/m <sup>3</sup> )   | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO17   | B    | Fraction of Time Spent Outdoors                   | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Aquatic Food             | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Drinking Water           | 1                      | ---             | ---             | None Assigned            |               | SNEC 5/13/02                   |
| RO18   | B, P | Contaminated Fraction of Household Water          | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Irrigation Water         | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Livestock Water          | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Meat                     | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Milk                     | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO18   | B, P | Contaminated Fraction of Plant Food               | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO18   | M, B | Drinking Water Intake (L/yr)                      | 478.5                  | 90.4            | 1860            | Truncated Lognormal-N    |               | SNEC 5/13/02                   |
| RO18   | M, B | Fish Consumption (kg/yr)                          | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO18   | M, B | Fruit, Vegetable, and Grain Consumption (kg/yr)   | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO18   | M, B | Leafy Vegetable Consumption (kg/yr)               | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO18   | M, B | Meat and Poultry Consumption (kg/yr)              | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO18   | M, B | Milk Consumption                                  | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO18   | M, B | Other Seafood Consumption (kg/yr)                 | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO18   | M, B | Soil Ingestion Rate (g/yr)                        | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO19   | M, B | Livestock Water Intake for Milk                   | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO19   | M, B | Depth of Roots (m)                                | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO19   | M, B | Depth of Soil Mixing Layer (m)                    | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO19B  | M, B | Weathering Removal Constant of all Vegetation     | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO19B  | M, B | Wet Crop Yield for Fodder (kg/m <sup>2</sup> )    | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO19B  | M, B | Wet Crop Yield for Leafy (kg/m <sup>2</sup> )     | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO19B  | M, B | Wet Crop Yield for Non-Leafy (kg/m <sup>2</sup> ) | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| RO19B  | M, B | Wet Foliar Inception Fraction of Leafy Vegetables | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| STOR   | B    | Storage Times for Livestock Fodder                | N/A                    | N/A             | N/A             | N/A                      |               | URS Technical Approach 6/18/02 |
| <b>Distribution Coefficient for Americium &amp; Curium</b> |      |   | <b>Value Used</b>      | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |               |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 1000                   | 1000            | 5000            | Uniform                  |               | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 1000                   | 1000            | 5000            | Uniform                  |               | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 1000                   | 1000            | 5000            | Uniform                  |               | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Carbon</b>                 |      |   | <b>ANL Value</b>       | <b>GPU Min.</b> | <b>GPU Max.</b> | <b>Distribution Type</b> |               |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 1                      | 0               | 5               | Uniform                  |               | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 1                      | 0               | 5               | Uniform                  |               | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 1                      | 0               | 5               | Uniform                  |               | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Cesium</b>                 |      |   | <b>Value Used</b>      | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |               |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 2131                   | 2131            | 28341           | Uniform                  |               | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 2131                   | 2131            | 28341           | Uniform                  |               | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 2131                   | 2131            | 28341           | Uniform                  |               | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Cobalt</b>                 |      |   | <b>Value Used</b>      | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |               |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 200                    | 200             | 1000            | Uniform                  |               | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 200                    | 200             | 1000            | Uniform                  |               | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 200                    | 200             | 1000            | Uniform                  |               | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Europium</b>               |      |   | <b>Value Used</b>      | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |               |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 1000                   | 1000            | 5000            | Uniform                  |               | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 1000                   | 1000            | 5000            | Uniform                  |               | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 1000                   | 1000            | 5000            | Uniform                  |               | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Hydrogen</b>               |      |   | <b>ANL Value (GPU)</b> | <b>GPU Min.</b> | <b>GPU Max.</b> | <b>Distribution Type</b> |               |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 1 (0.25)               | 0               | 0.5             | Uniform                  |               | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 1 (0.25)               | 0               | 0.5             | Uniform                  |               | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 1 (0.25)               | 0               | 0.5             | Uniform                  |               | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Iron</b>                   |      |   | <b>Value Used</b>      | <b>GPU Min.</b> | <b>GPU Max.</b> | <b>Distribution Type</b> |               |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 10000                  | 10000           | 50000           | Uniform                  |               | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 10000                  | 10000           | 50000           | Uniform                  |               | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 10000                  | 10000           | 50000           | Uniform                  |               | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Lead</b>                   |      |   | <b>Value Used</b>      | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |               |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 9700                   | 9700            | 160000          | Uniform                  |               | SNEC 5/13/02                   |
| R16  | P    | 2. Unsaturated Zone (cm <sup>3</sup> /g)          | 9700                   | 9700            | 160000          | Uniform                  |               | SNEC 5/13/02                   |
| R16  | P    | 3. Saturated Zone (cm <sup>3</sup> /g)            | 9700                   | 9700            | 160000          | Uniform                  |               | SNEC 5/13/02                   |
| <b>Distribution Coefficient for Nickel</b>                 |      |   | <b>Value Used</b>      | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |               |                                |
| R16  | P    | 1. Contaminated Zone (cm <sup>3</sup> /g)         | 1300                   | 1300            | 10000           | Uniform                  |               | SNEC 5/13/02                   |

|   |   |   |                   |                 |                 |                          |              |
|---|---|---|-------------------|-----------------|-----------------|--------------------------|--------------|
| R16   | P | 2. Unsaturated Zone (cm <sup>3</sup> /g)  | 1300              | 1300            | 10000           |                          | SNEC 5/13/02 |
| R16   | P | 3. Saturated Zone (cm <sup>3</sup> /g)    | 1300              | 1300            | 10000           |                          | SNEC 5/13/02 |
| <b>Distribution Coefficient for Plutonium</b>   |   |   | <b>Value Used</b> | <b>ANL Min.</b> | <b>ANL Max</b>  | <b>Distribution Type</b> |              |
| R16   | P | 1. Contaminated Zone (cm <sup>3</sup> /g) | 160               | 160             | 600             |                          | SNEC 5/13/02 |
| R16   | P | 2. Unsaturated Zone (cm <sup>3</sup> /g)  | 160               | 160             | 600             |                          | SNEC 5/13/02 |
| R16   | P | 3. Saturated Zone (cm <sup>3</sup> /g)    | 160               | 160             | 600             |                          | SNEC 5/13/02 |
| <b>Distribution Coefficient for Strontium</b>   |   |   | <b>Value Used</b> | <b>ANL Min.</b> | <b>ANL Max</b>  | <b>Distribution Type</b> |              |
| R16   | P | 1. Contaminated Zone (cm <sup>3</sup> /g) | 11                | 11              | 475             |                          | SNEC 5/13/02 |
| R16   | P | 2. Unsaturated Zone (cm <sup>3</sup> /g)  | 11                | 11              | 475             |                          | SNEC 5/13/02 |
| R16   | P | 3. Saturated Zone (cm <sup>3</sup> /g)    | 11                | 11              | 475             |                          | SNEC 5/13/02 |
| <b>Distribution Coefficient for Uranium</b>   |   |   | <b>Value Used</b> | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |              |
| R16   | P | 1. Contaminated Zone (cm <sup>3</sup> /g) | 16                | 16              | 5200            |                          | SNEC 5/13/02 |
| R16   | P | 2. Unsaturated Zone (cm <sup>3</sup> /g)  | 16                | 16              | 5200            |                          | SNEC 5/13/02 |
| R16   | P | 3. Saturated Zone (cm <sup>3</sup> /g)    | 16                | 16              | 5200            |                          | SNEC 5/13/02 |
| <p>NOTE ANL Kd values may be "greater than" values. The ANL Min. value is the lowest reported value for this element and the ANL Max. value is the highest reported value.</p> <p>NOTE Items in RED type face are SNEC input values.</p> <p>NOTE Items in GREEN type face are URS input values.</p> <p>NOTE Items with BLUE background are D &amp; D default values, while items with a YELLOW background are RESRAD default values. Unlisted parameters are RESRAD defaults.</p> |   |   |                   |                 |                 |                          |              |

**DW SCENARIO IN BEDROCK**

| Menu | Class | PARAMETERS   | Basic                            | SNEC Range of Values |        | Assigned Distribution | Default Distribution                 | Basis   |
|------|-------|--|----------------------------------|----------------------|--------|-----------------------|--------------------------------------|---|
|      |       |  | RESRAD Input                     | Min                  | Max    |                       |                                      |   |
| C14  | P     | Thickness of Soil Evasion Layer of C-14 in Soil (m)        | 0.3                              | 0.2                  | 0.6    | Triangular            |                                      | SNEC 5/13/02  |
| D-5  | P     | Bioaccumulation Factors, Fresh Water                       | Default Values                   | Varies               | Varies | Lognormal             |                                      | SNEC 5/13/02  |
| D-34 | P     | Food Transfer Factors                                      | Default Values                   | Varies               | Varies | Lognormal             |                                      | SNEC 5/13/02  |
| RO11 | P     | Area of Contaminated Zone (m <sup>2</sup> )                | 10000                            | N/A                  | N/A    | N/A                   |                                      | URS Technical Approach 6/5/02                                       |
| RO11 | NRC   | Basic Radiation Dose Limit (mrem/yr) (NRC)                 | 4                                | N/A                  | N/A    | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Length Parallel to Aquifer Flow (m)                        | 112.8                            | N/A                  | N/A    | N/A                   |                                      | RESRAD Data Collection Handbook                                     |
| RO11 | P     | Thickness of Contaminated Zone 1 (m)                       | 2.000E+00                        | N/A                  | N/A    | N/A                   |                                      | URS Technical Approach 6/5/02                                       |
| RO11 | P     | Time Since Placement of Materials (yr)                     | 0                                | N/A                  | N/A    | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 1                                | N/A                  | N/A    | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 3                                | N/A                  | N/A    | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 10                               | N/A                  | N/A    | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 35                               | N/A                  | N/A    | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 150                              | N/A                  | N/A    | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 300                              | N/A                  | N/A    | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 1000                             | N/A                  | N/A    | N/A                   |                                      | SNEC 5/13/02  |
| RO11 | P     | Times for Calculations (yr)                                | 10000                            | N/A                  | N/A    | N/A                   |                                      | SNEC 5/13/02  |
| RO13 | P     | Average Annual Wind Speed (m/sec)                          | 4.07                             | 3.13                 | 4.83   | Uniform               | Bounded Lognormal-N (1 4 - 13)       | SNEC 5/13/02  |
| RO13 | P     | Contaminated Zone Field Capacity                           | 0.136                            | 0 079                | 0.192  | Uniform               | None Assigned                        | SNEC 5/13/02  |
| RO13 | P     | Contaminated Zone b Parameter                              | 5 6                              | 4.05                 | 7.12   | Uniform               | Bounded Lognormal-N (0 5 - 30)       | SNEC 5/13/02  |
| RO13 | P, B  | Contaminated Zone Erosion Rate (m/yr)                      | 0.000345                         | 0.00009              | 0.0006 | Loguniform            | Continuous Logarithmic (5E-08 - 0 2) | SNEC 5/13/02  |
| RO13 | P     | Contaminated Zone Hydraulic Conductivity (m/yr)            | 67.91                            | 15.59                | 909.53 | Uniform               | Bounded Lognormal-N (0 004 - 9250)   | SNEC 5/13/02  |
| RO13 | P     | Contaminated Zone Total Porosity                           | 0.36                             | 0.31                 | 0.41   | Uniform               | Truncated Normal, (0 157 - 0 693)    | SNEC 5/13/02  |
| RO13 | P     | Cover Depth (m)  | 3.2                              | N/A                  | N/A    | N/A                   |                                      | SNEC 5/13/02 & URS Technical Approach 6/5/02                        |
| RO13 | P, B  | Cover Depth Erosion Rate (m/yr)                            | 0.000345                         | 0 00009              | 0.0006 | Loguniform            |                                      | SNEC 5/13/02  |
| RO13 | P     | Density of Contaminated Zone (g/cc)                        | 1.6                              | 1.28                 | 1.92   | Uniform               | Truncated Normal (0 809 - 2 23)      | SNEC 5/13/02  |
| RO13 | P     | Density of Cover Material (g/cc)                           | (reported as not used by RESRAD) | 1.28                 | 1.92   | Uniform               |                                      | SNEC 5/13/02  |
| RO13 | P     | Evapotranspiration Coefficient (m/yr)                      | 0.59                             | 0.5                  | 0.67   | Uniform               | Uniform (0 5 - 0 75)                 | SNEC 5/13/02  |
| RO13 | P     | Humidity in Air (g/m <sup>3</sup> )                        | N/A                              | N/A                  | N/A    | N/A                   |                                      | URS Technical Approach 6/5/02                                       |
| RO13 | B     | Irrigation (m/yr)  | 0 2                              | —                    | —      | None Assigned         |                                      | SNEC 5/13/02  |
| RO13 | B     | Irrigation Mode (Overhead)                                 | Overhead                         | N/A                  | N/A    | N/A                   |                                      | SNEC 5/13/02  |
| RO13 | P     | Precipitation (m/yr)                                       | 0 936                            | 0.688                | 1.327  | Uniform               | None Assigned                        | SNEC 5/13/02  |
| RO13 | P     | Runoff Coefficient   | 0 35                             | 0.3                  | 0.4    | Uniform               | Uniform (0 1 - 0 8)                  | SNEC 5/13/02  |
| RO13 | P     | Watershed Area for Nearby Stream or Pond (m <sup>2</sup> ) | 5.00E+06                         | —                    | —      | None Assigned         | None Assigned                        | SNEC 5/13/02  |
| RO13 | P     | Density of Saturated Zone (g/cc)                           | 1.6                              | 1.28                 | 1.92   | Uniform               | Truncated Normal (0 809 - 2 23)      | SNEC 5/13/02  |
| RO14 | P     | Model Non-dispersion (ND) or Mass-Balance (MB)             | Mass Balance                     | N/A                  | N/A    | N/A                   |                                      | SNEC 5/13/02  |
| RO14 | P     | Saturated Zone b Parameter                                 | Not Used                         | N/A                  | N/A    | N/A                   |                                      | SNEC 5/13/02  |
| RO14 | P     | Saturated Zone Effective Porosity                          | 0 028                            | 0 005                | 0 05   | Loguniform            | Truncated Normal (0 075 - 0 635)     | SNEC 5/13/02  |
| RO14 | P     | Saturated Zone Hydraulic Conductivity (m/yr)               | 67.91                            | 15.59                | 909.53 | Uniform               | Bounded Lognormal-N (0 004 - 9250)   | SNEC 5/13/02  |
| RO14 | P     | Saturated Zone Hydraulic Gradient                          | 0 02                             | 0 013                | 0 03   | Uniform               | Bounded Lognormal-N (0 00007 - 0 5)  | SNEC 5/13/02  |
| RO14 | P     | Saturated Zone Total Porosity                              | 0.36                             | 0 31                 | 0 41   | Uniform               | Truncated Normal, (0 157 - 0 693)    | SNEC 5/13/02  |
| RO14 | P     | Water Table Drop Rate (m/yr)                               | 0                                | —                    | —      | None Assigned         | None Assigned                        | SNEC 5/13/02  |
| RO14 | P     | Well Pump Intake Depth (m)                                 | 30 2                             | 10.2                 | 50 2   | Uniform               | Triangular (6 -30)                   | SNEC 5/13/02 + 0 2m excavation as per URS Technical Approach 6/5/02 |
| RO14 | P     | Well Pump Intake Depth (m)                                 | 286.2                            | —                    | —      | None Assigned         |                                      |   |
| RO14 | P     | Well Pump Intake Depth (m)                                 | (reported as not used by RESRAD) | 207.3                | 365    | Uniform               | None Assigned                        | SNEC 5/13/02  |
| RO14 | B, P  | Well Pumping Rate (m <sup>3</sup> /yr)                     | 0.136                            | 0.079                | 0.192  | Uniform               | None Assigned                        | SNEC 5/13/02  |
| RO14 | P     | Saturated Zone Field Capacity                              | 0.136                            | 0.079                | 0.192  | Uniform               | None Assigned                        | SNEC 5/13/02  |
| RO15 | P     | Density of Unsaturated Zone 1 (g/cc)                       | 1.6                              | 1.28                 | 1.92   | Uniform               | Truncated Normal (0 809 - 2 23)      | SNEC 5/13/02  |
| RO15 | P     | Effective Porosity of Unsaturated Zone 1                   | 0.41                             | 0.28                 | 0.54   | Uniform               | Truncated Normal (0 075 - 0 635)     | SNEC 5/13/02  |
| RO15 | P     | Hydraulic Conductivity of Unsaturated Zone 1 (m/yr)        | 67.91                            | 15.59                | 909.53 | Loguniform            | Bounded Lognormal-N (0 004 - 9250)   | SNEC 5/13/02  |
| RO15 | P     | Number of Unsaturated Zone Strata                          | 1                                | N/A                  | N/A    | N/A                   | N/A                                  | SNEC 5/13/02  |
| RO15 | P     | Thickness of Unsaturated Zone 1 (m)                        | 0 0010                           | N/A                  | N/A    | N/A                   | Bounded Lognormal-N (0 18 - 320)     | URS Technical Approach 6/5/02 (effectively zero)                    |
| RO15 | P     | Total porosity of Unsaturated Zone 1                       | 0.46                             | 0 35                 | 0.56   | Uniform               | Truncated Normal, (0 157 - 0 693)    | SNEC 5/13/02  |

|   |   |   |                   |                 |                 |                          |              |
|---|---|---|-------------------|-----------------|-----------------|--------------------------|--------------|
| R16   | P | 2. Unsaturated Zone (cm <sup>3</sup> /g)  | 9700              | 9700            | 160000          |                          | SNEC 5/13/02 |
| R16   | P | 3. Saturated Zone (cm <sup>3</sup> /g)    | 9700              | 9700            | 160000          |                          | SNEC 5/13/02 |
| <b>Distribution Coefficient for Nickel</b>    |   |   | <b>Value Used</b> | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |              |
| R16   | P | 1. Contaminated Zone (cm <sup>3</sup> /g) | 1300              | 1300            | 10000           |                          | SNEC 5/13/02 |
| R16   | P | 2. Unsaturated Zone (cm <sup>3</sup> /g)  | 1300              | 1300            | 10000           |                          | SNEC 5/13/02 |
| R16   | P | 3. Saturated Zone (cm <sup>3</sup> /g)    | 1300              | 1300            | 10000           |                          | SNEC 5/13/02 |
| <b>Distribution Coefficient for Plutonium</b> |   |   | <b>Value Used</b> | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |              |
| R16   | P | 1. Contaminated Zone (cm <sup>3</sup> /g) | 160               | 160             | 600             |                          | SNEC 5/13/02 |
| R16   | P | 2. Unsaturated Zone (cm <sup>3</sup> /g)  | 160               | 160             | 600             |                          | SNEC 5/13/02 |
| R16   | P | 3. Saturated Zone (cm <sup>3</sup> /g)    | 160               | 160             | 600             |                          | SNEC 5/13/02 |
| <b>Distribution Coefficient for Strontium</b> |   |   | <b>Value Used</b> | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |              |
| R16   | P | 1. Contaminated Zone (cm <sup>3</sup> /g) | 11                | 11              | 475             |                          | SNEC 5/13/02 |
| R16   | P | 2. Unsaturated Zone (cm <sup>3</sup> /g)  | 11                | 11              | 475             |                          | SNEC 5/13/02 |
| R16   | P | 3. Saturated Zone (cm <sup>3</sup> /g)    | 11                | 11              | 475             |                          | SNEC 5/13/02 |
| <b>Distribution Coefficient for Uranium</b>   |   |   | <b>Value Used</b> | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |              |
| R16   | P | 1. Contaminated Zone (cm <sup>3</sup> /g) | 16                | 16              | 5200            |                          | SNEC 5/13/02 |
| R16   | P | 2. Unsaturated Zone (cm <sup>3</sup> /g)  | 16                | 16              | 5200            |                          | SNEC 5/13/02 |
| R16   | P | 3. Saturated Zone (cm <sup>3</sup> /g)    | 16                | 16              | 5200            |                          | SNEC 5/13/02 |

NOTE ANL Kd values may be "greater than" values. The ANL Min value is the lowest reported value for this element and the ANL Max value is the highest reported value

NOTE Items in RED type face are SNEC input values

NOTE Items in GREEN type face are URS input values

NOTE Items with BLUE background are D & D default values, while items with a YELLOW background are RESRAD default values. Unlisted parameters are RESRAD defaults

**SSGS SURFACE ALL PATHS SCENARIO FOR EXCAVATED BACKFILL**

| Menu | Class | PARAMETERS   | Basic                       | SNEC Range of Values |          | Assigned Distribution | Default Distribution                 | Basis  |
|------|-------|--|-----------------------------|----------------------|----------|-----------------------|--------------------------------------|--|
|      |       |  | RESRAD Input                | Min                  | Max      |                       |                                      |  |
| C14  | P     | Thickness of Soil Evasion Layer of C-14 in Soil (m)        | 0.3                         | 0.2                  | 0.6      | Triangular            |                                      | SNEC 5/13/02   |
| D-5  | P     | Bioaccumulation Factors, Fresh Water                       | Default Values              | Varies               | Varies   | Lognormal             |                                      | SNEC 5/13/02   |
| D-34 | P     | Food Transfer Factors                                      | Default Values              | Varies               | Varies   | Lognormal             |                                      | SNEC 5/13/02   |
| RO11 | P     | Area of Contaminated Zone (m <sup>2</sup> )                | 2000                        | N/A                  | N/A      | N/A                   |                                      | URS Technical Approach 6/18/02   |
| RO11 | NRC   | Basic Radiation Dose Limit (mrem/yr) (NRC)                 | 25                          | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Length Parallel to Aquifer Flow (m)                        | 50.5                        | N/A                  | N/A      | N/A                   |                                      | RESRAD Data Collection Handbook  |
| RO11 | P     | Thickness of Contaminated Zone 1 (m)                       | 2.000E-01                   | N/A                  | N/A      | N/A                   |                                      | URS Technical Approach 6/18/02   |
| RO11 | P     | Time Since Placement of Materials (yr)                     | 0                           | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 1                           | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 3                           | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 10                          | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 35                          | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 150                         | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 300                         | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 1000                        | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO11 | P     | Times for Calculations (yr)                                | 10000                       | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO13 | P     | Average Annual Wind Speed (m/sec)                          | 4.07                        | 3.13                 | 4.83     | Uniform               | Bounded Lognormal-N (1.4 - 13)       | SNEC 5/13/02   |
| RO13 | P     | Contaminated Zone Field Capacity                           | 0.1360                      | 0.0790               | 0.1920   | Uniform               | None Assigned                        | Backfill properties assumed same as fill soil as per GPU direction 5/13/02         |
| RO13 | P     | Contaminated Zone b Parameter                              | 5.60                        | 4.05                 | 7.12     | Uniform               | Bounded Lognormal-N (0.5 - 30)       | Backfill properties assumed same as fill soil as per GPU direction 5/13/02         |
| RO13 | P, B  | Contaminated Zone Erosion Rate (m/yr)                      | 0.000345                    | 0.00009              | 0.0006   | Loguniform            | Continuous Logarithmic (5E-08 - 0.2) | Backfill properties assumed same as fill soil as per GPU direction 5/13/02         |
| RO13 | P     | Contaminated Zone Hydraulic Conductivity (m/yr)            | 32.30                       | 0.36                 | 25400.00 | Loguniform            | Bounded Lognormal-N (0.004 - 9250)   | Backfill properties assumed same as fill soil as per GPU direction 5/13/02         |
| RO13 | P     | Contaminated Zone Total Porosity                           | 0.460                       | 0.350                | 0.560    | Uniform               | Truncated Normal, (0.157 - 0.693)    | Backfill properties assumed same as fill soil as per GPU direction 5/13/02         |
| RO13 | P     | Cover Depth (m)  | 0                           | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO13 | P     | Density of Contaminated Zone (g/cc)                        | 1.60                        | 1.28                 | 1.92     | Uniform               | Truncated Normal (0.809 - 2.23)      | Weighted average of fill and overburden as per URS Technical Approach 6/5/06       |
| RO13 | P     | Density of Cover Material (g/cc)                           | Not Used                    | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO13 | P     | Evapotranspiration Coefficient (m/yr)                      | 0.59                        | 0.5                  | 0.67     | Uniform               | Uniform (0.5 - 0.75)                 | SNEC 5/13/02   |
| RO13 | P     | Humidity in Air (g/m <sup>3</sup> )                        | 8 (H-3) not used for others | 2.58E+00             | 2.03E+01 | Truncated Lognormal-N |                                      | SNEC 5/13/02   |
| RO13 | B     | Irrigation (m/yr)  | 0.2                         | —                    | —        | None Assigned         |                                      | SNEC 5/13/02   |
| RO13 | B     | Irrigation Mode (Overhead)                                 | Overhead                    | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO13 | P     | Precipitation (m/yr)                                       | 0.935                       | 0.688                | 1.327    | Uniform               | None Assigned                        | SNEC 5/13/02   |
| RO13 | P     | Runoff Coefficient   | 0.35                        | 0.3                  | 0.4      | Uniform               | Uniform (0.1 - 0.8)                  | SNEC 5/13/02   |
| RO13 | P     | Watershed Area for Nearby Stream or Pond (m <sup>2</sup> ) | 5.00E+06                    | —                    | —        | None Assigned         | None Assigned                        | SNEC 5/13/02   |
| RO14 | P     | Density of Saturated Zone (g/cc)                           | 1.6                         | 1.28                 | 1.92     | Uniform               | Truncated Normal (0.809 - 2.23)      | SNEC 5/13/02   |
| RO14 | P     | Model Non-dispersion (ND) or Mass-Balance (MB)             | Non-Dispersion              | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone b Parameter                                 | Not Used                    | N/A                  | N/A      | N/A                   |                                      | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone Effective Porosity                          | 0.41                        | 0.28                 | 0.54     | Loguniform            | Truncated Normal (0.075 - 0.635)     | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone Hydraulic Conductivity (m/yr)               | 32.3                        | 0.362                | 25400    | Uniform               | Bounded Lognormal-N (0.004 - 9250)   | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone Hydraulic Gradient                          | 0.02                        | 0.013                | 0.03     | Uniform               | Bounded Lognormal-N (0.00007 - 0.5)  | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone Total Porosity                              | 0.46                        | 0.35                 | 0.56     | Uniform               | Truncated Normal, (0.157 - 0.693)    | SNEC 5/13/02   |
| RO14 | P     | Water Table Drop Rate (m/yr)                               | 0                           | —                    | —        | None Assigned         | None Assigned                        | SNEC 5/13/02   |
| RO14 | P     | Well Pump Intake Depth (m)                                 | 30.2                        | 10.2                 | 50.2     | Uniform               | Triangular (6 - 30)                  | SNEC 5/13/02 + 0.2m excavation as per URS Technical Approach 6/18/02               |
| RO14 | B, P  | Well Pumping Rate (m <sup>3</sup> /yr)                     | 286.2                       | 207.3                | 365      | Uniform               | None Assigned                        | SNEC 5/13/02   |
| RO14 | P     | Saturated Zone Field Capacity                              | 0.136                       | 0.079                | 0.192    | Uniform               | None Assigned                        | SNEC 5/13/02   |
| RO15 | P     | Density of Unsaturated Zone 1 (g/cc)                       | 1.6                         | 1.28                 | 1.92     | Uniform               | Truncated Normal (0.809 - 2.23)      | SNEC 5/13/02   |
| RO15 | P     | Effective Porosity of Unsaturated Zone 1                   | 0.41                        | 0.28                 | 0.54     | Uniform               | Truncated Normal (0.075 - 0.635)     | SNEC 5/13/02   |
| RO15 | P     | Hydraulic Conductivity of Unsaturated Zone 1 (m/yr)        | 32.3                        | 0.362                | 25400    | Loguniform            | Bounded Lognormal-N (0.004 - 9250)   | SNEC 5/13/02   |
| RO15 | P     | Number of Unsaturated Zone Strata                          | 1                           | N/A                  | N/A      | N/A                   | N/A                                  | SNEC 5/13/02   |
| RO15 | P     | Thickness of Unsaturated Zone 1 (m)                        | 1.25                        | 1.00                 | 1.50     | Uniform               | Bounded Lognormal-N (0.18 - 320)     | SNEC 5/13/02 + 1.0m original fill soil layer as per URS Technical Approach 6/18/02 |

|  |     |   |                        |                 |                 |                          |                                   |              |
|--|-----|---|------------------------|-----------------|-----------------|--------------------------|-----------------------------------|--------------|
| RO15   | P   | Total porosity of Unsaturated Zone 1              | 0.46                   | 0.35            | 0.56            | Uniform                  | Truncated Normal, (0.157 - 0.693) | SNEC 5/13/02 |
| RO15   | P   | Unsaturated Zone 1 b Parameter                    | 5.6                    | 4.05            | 7.12            | Uniform                  | Bounded Lognormal-N (0.5 - 30)    | SNEC 5/13/02 |
| RO15   | P   | Unsaturated Zone Field Capacity                   | 0.136                  | 0.079           | 0.192           | Uniform                  | None Assigned                     | SNEC 5/13/02 |
| RO17   | P   | External Gamma Shielding Factor                   | 0.7                    | 4.400E-02       | 1               | Bounded Lognormal-N      |                                   | SNEC 5/13/02 |
| RO17   | P,B | Indoor Dust Filtration Factor                     | 0.4                    | 0.15            | 0.95            | Uniform                  |                                   | SNEC 5/13/02 |
| RO17   | B   | Indoor Time Fraction                              | 0.66                   | 0               | 1               | Continuous Linear        |                                   | SNEC 5/13/02 |
| RO17   | M,P | Inhalation Rate (m³/yr)                           | 8400                   | 4380            | 13100           | Triangular               |                                   | SNEC 5/13/02 |
| RO17   | P,B | Mass Loading for Inhalation (g/m³)                | 0.0001                 | 0               | 0.0001          | Continuous Linear        |                                   | SNEC 5/13/02 |
| RO17   | B   | Fraction of Time Spent Outdoors                   | 0.12                   | —               | —               | None Assigned            |                                   | SNEC 5/13/02 |
| RO18   | B,P | Contaminated Fraction of Aquatic Food             | —                      | 0               | 1               | Triangular               |                                   | SNEC 5/13/02 |
| RO18   | B,P | Contaminated Fraction of Drinking Water           | 1                      | —               | —               | None Assigned            |                                   | SNEC 5/13/02 |
| RO18   | B,P | Contaminated Fraction of Household Water          | Not Used               | N/A             | N/A             | N/A                      |                                   | SNEC 5/13/02 |
| RO18   | B,P | Contaminated Fraction of Irrigation Water         | 1                      | —               | —               | None Assigned            |                                   | SNEC 5/13/02 |
| RO18   | B,P | Contaminated Fraction of Livestock Water          | 1                      | —               | —               | None Assigned            |                                   | SNEC 5/13/02 |
| RO18   | B,P | Contaminated Fraction of Meat                     | —                      | —               | —               | None Assigned            |                                   | SNEC 5/13/02 |
| RO18   | B,P | Contaminated Fraction of Milk                     | —                      | —               | —               | None Assigned            |                                   | SNEC 5/13/02 |
| RO18   | B,P | Contaminated Fraction of Plant Food               | —                      | —               | —               | None Assigned            |                                   | SNEC 5/13/02 |
| RO18   | M,B | Drinking Water Intake (L/yr)                      | 478.5                  | 90.4            | 1860            | Truncated Lognormal-N    |                                   | SNEC 5/13/02 |
| RO18   | M,B | Fish Consumption (kg/yr)                          | 20.6                   | —               | —               | None Assigned            |                                   | SNEC 5/13/02 |
| RO18   | M,B | Fruit, Vegetable, and Grain Consumption (kg/yr)   | 111.8                  | 135             | 318             | Triangular               |                                   | SNEC 5/13/02 |
| RO18   | M,B | Leafy Vegetable Consumption (kg/yr)               | 21.4                   | —               | —               | None Assigned            |                                   | SNEC 5/13/02 |
| RO18   | M,B | Meat and Poultry Consumption (kg/yr)              | 67                     | —               | —               | None Assigned            |                                   | SNEC 5/13/02 |
| RO18   | M,B | Milk Consumption (kg/yr)                          | 233                    | 60              | 200             | Triangular               |                                   | SNEC 5/13/02 |
| RO18   | M,B | Other Seafood Consumption (kg/yr)                 | 0.9                    | —               | —               | None Assigned            |                                   | SNEC 5/13/02 |
| RO18   | M,B | Soil Ingestion Rate (g/yr)                        | 18.3                   | 0               | 36.5            | Triangular               |                                   | SNEC 5/13/02 |
| RO19   | M,B | Livestock Water Intake for Milk                   | 60                     | —               | —               | None Assigned            |                                   | SNEC 5/13/02 |
| RO19   | M,B | Depth of Roots (m)                                | 0.9                    | 0.3             | 1               | Uniform                  |                                   | SNEC 5/13/02 |
| RO19   | M,B | Depth of Soil Mixing Layer (m)                    | 0.15                   | 0               | 0.6             | Triangular               |                                   | SNEC 5/13/02 |
| RO19B  | M,B | Weathering Removal Constant of all Vegetation     | 20                     | 5.1             | 84              | Triangular               |                                   | SNEC 5/13/02 |
| RO19B  | M,B | Wet Crop Yield for Fodder (kg/m²)                 | 1.1                    | —               | —               | None Assigned            |                                   | SNEC 5/13/02 |
| RO19B  | M,B | Wet Crop Yield for Leafy (kg/m²)                  | 1.5                    | —               | —               | None Assigned            |                                   | SNEC 5/13/02 |
| RO19B  | M,B | Wet Crop Yield for Non-Leafy (kg/m²)              | 0.7                    | 0.397           | 7.72            | Truncated Lognormal-N    |                                   | SNEC 5/13/02 |
| RO19B  | M,B | Wet Foliar Inception Fraction of Leafy Vegetables | 0.25                   | 0.06            | 0.95            | Triangular               |                                   | SNEC 5/13/02 |
| STOR   | B   | Storage Times for Livestock Fodder                | 0                      | —               | —               | None Assigned            |                                   | SNEC 5/13/02 |
| <b>Distribution Coefficient for Americium &amp; Curium</b> |     |   | <b>Value Used</b>      | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |                                   |              |
| R16  | P   | 1. Contaminated Zone (cm³/g)                      | 1000                   | 1000            | 5000            |                          |                                   | SNEC 5/13/02 |
| R16  | P   | 2. Unsaturated Zone (cm³/g)                       | 1000                   | 1000            | 5000            |                          |                                   | SNEC 5/13/02 |
| R16  | P   | 3. Saturated Zone (cm³/g)                         | 1000                   | 1000            | 5000            |                          |                                   | SNEC 5/13/02 |
| <b>Distribution Coefficient for Carbon</b>                 |     |   | <b>ANL Value</b>       | <b>GPU Min</b>  | <b>GPU Max</b>  | <b>Distribution Type</b> |                                   |              |
| R16  | P   | 1. Contaminated Zone (cm³/g)                      | —                      | 0               | 5               | Uniform                  |                                   | SNEC 5/13/02 |
| R16  | P   | 2. Unsaturated Zone (cm³/g)                       | —                      | 0               | 5               | Uniform                  |                                   | SNEC 5/13/02 |
| R16  | P   | 3. Saturated Zone (cm³/g)                         | —                      | 0               | 5               | Uniform                  |                                   | SNEC 5/13/02 |
| <b>Distribution Coefficient for Cesium</b>                 |     |   | <b>Value Used</b>      | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |                                   |              |
| R16  | P   | 1. Contaminated Zone (cm³/g)                      | 2131                   | 2131            | 28341           |                          |                                   | SNEC 5/13/02 |
| R16  | P   | 2. Unsaturated Zone (cm³/g)                       | 2131                   | 2131            | 28341           |                          |                                   | SNEC 5/13/02 |
| R16  | P   | 3. Saturated Zone (cm³/g)                         | 2131                   | 2131            | 28341           |                          |                                   | SNEC 5/13/02 |
| <b>Distribution Coefficient for Cobalt</b>                 |     |   | <b>Value Used</b>      | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |                                   |              |
| R16  | P   | 1. Contaminated Zone (cm³/g)                      | 200                    | 200             | 1000            |                          |                                   | SNEC 5/13/02 |
| R16  | P   | 2. Unsaturated Zone (cm³/g)                       | 200                    | 200             | 1000            |                          |                                   | SNEC 5/13/02 |
| R16  | P   | 3. Saturated Zone (cm³/g)                         | 200                    | 200             | 1000            |                          |                                   | SNEC 5/13/02 |
| <b>Distribution Coefficient for Europium</b>               |     |   | <b>Value Used</b>      | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |                                   |              |
| R16  | P   | 1. Contaminated Zone (cm³/g)                      | 1000                   | 1000            | 5000            |                          |                                   | SNEC 5/13/02 |
| R16  | P   | 2. Unsaturated Zone (cm³/g)                       | 1000                   | 1000            | 5000            |                          |                                   | SNEC 5/13/02 |
| R16  | P   | 3. Saturated Zone (cm³/g)                         | 1000                   | 1000            | 5000            |                          |                                   | SNEC 5/13/02 |
| <b>Distribution Coefficient for Hydrogen</b>               |     |   | <b>ANL Value (GPU)</b> | <b>GPU Min</b>  | <b>GPU Max</b>  | <b>Distribution Type</b> |                                   |              |
| R16  | P   | 1. Contaminated Zone (cm³/g)                      | 1 (0.25)               | 0               | 0.5             | Uniform                  |                                   | SNEC 5/13/02 |
| R16  | P   | 2. Unsaturated Zone (cm³/g)                       | 1 (0.25)               | 0               | 0.5             | Uniform                  |                                   | SNEC 5/13/02 |
| R16  | P   | 3. Saturated Zone (cm³/g)                         | 1 (0.25)               | 0               | 0.5             | Uniform                  |                                   | SNEC 5/13/02 |
| <b>Distribution Coefficient for Iron</b>                   |     |   | <b>Value Used</b>      | <b>GPU Min</b>  | <b>GPU Max</b>  | <b>Distribution Type</b> |                                   |              |
| R16  | P   | 1. Contaminated Zone (cm³/g)                      | 10000                  | 10000           | 50000           |                          |                                   | SNEC 5/13/02 |
| R16  | P   | 2. Unsaturated Zone (cm³/g)                       | 10000                  | 10000           | 50000           |                          |                                   | SNEC 5/13/02 |
| R16  | P   | 3. Saturated Zone (cm³/g)                         | 10000                  | 10000           | 50000           |                          |                                   | SNEC 5/13/02 |
| <b>Distribution Coefficient for Lead</b>                   |     |   | <b>Value Used</b>      | <b>ANL Min.</b> | <b>ANL Max.</b> | <b>Distribution Type</b> |                                   |              |
| R16  | P   | 1. Contaminated Zone (cm³/g)                      | 9700                   | 9700            | 160000          |                          |                                   | SNEC 5/13/02 |
| R16  | P   | 2. Unsaturated Zone (cm³/g)                       | 9700                   | 9700            | 160000          |                          |                                   | SNEC 5/13/02 |
| R16  | P   | 3. Saturated Zone (cm³/g)                         | 9700                   | 9700            | 160000          |                          |                                   | SNEC 5/13/02 |



|     |   | <i>Distribution Coefficient for Nickel</i>    |  | <i>Value Used</i> | <i>ANL Min.</i> | <i>ANL Max.</i> | <i>Distribution Type</i> |              |
|-----|---|---|--|-------------------|-----------------|-----------------|--------------------------|--------------|
| R16 | P | 1. Contaminated Zone (cm <sup>3</sup> /g)     |  | 1300              | 1300            | 10000           |                          | SNEC 5/13/02 |
| R16 | P | 2. Unsaturated Zone (cm <sup>3</sup> /g)      |  | 1300              | 1300            | 10000           |                          | SNEC 5/13/02 |
| R16 | P | 3. Saturated Zone (cm <sup>3</sup> /g)        |  | 1300              | 1300            | 10000           |                          | SNEC 5/13/02 |
|     |   | <i>Distribution Coefficient for Plutonium</i> |  | <i>Value Used</i> | <i>ANL Min.</i> | <i>ANL Max.</i> | <i>Distribution Type</i> |              |
| R16 | P | 1. Contaminated Zone (cm <sup>3</sup> /g)     |  | 160               | 160             | 600             |                          | SNEC 5/13/02 |
| R16 | P | 2. Unsaturated Zone (cm <sup>3</sup> /g)      |  | 160               | 160             | 600             |                          | SNEC 5/13/02 |
| R16 | P | 3. Saturated Zone (cm <sup>3</sup> /g)        |  | 160               | 160             | 600             |                          | SNEC 5/13/02 |
|     |   | <i>Distribution Coefficient for Strontium</i> |  | <i>Value Used</i> | <i>ANL Min.</i> | <i>ANL Max.</i> | <i>Distribution Type</i> |              |
| R16 | P | 1. Contaminated Zone (cm <sup>3</sup> /g)     |  | 11                | 11              | 475             |                          | SNEC 5/13/02 |
| R16 | P | 2. Unsaturated Zone (cm <sup>3</sup> /g)      |  | 11                | 11              | 475             |                          | SNEC 5/13/02 |
| R16 | P | 3. Saturated Zone (cm <sup>3</sup> /g)        |  | 11                | 11              | 475             |                          | SNEC 5/13/02 |
|     |   | <i>Distribution Coefficient for Uranium</i>   |  | <i>Value Used</i> | <i>ANL Min.</i> | <i>ANL Max.</i> | <i>Distribution Type</i> |              |
| R16 | P | 1. Contaminated Zone (cm <sup>3</sup> /g)     |  | 16                | 16              | 5200            |                          | SNEC 5/13/02 |
| R16 | P | 2. Unsaturated Zone (cm <sup>3</sup> /g)      |  | 16                | 16              | 5200            |                          | SNEC 5/13/02 |
| R16 | P | 3. Saturated Zone (cm <sup>3</sup> /g)        |  | 16                | 16              | 5200            |                          | SNEC 5/13/02 |

NOTE- ANL Kd values may be "greater than" values. The ANL Min. value is the lowest reported value for this element and the ANL Max. value is the highest reported value  
NOTE- Items in RED type face are SNEC input values  
NOTE- Items in GREEN type face are URS input values.  
NOTE- Items with BLUE background are D & D default values, while items with a YELLOW background are RESRAD default values. Unlisted parameters are RESRAD defaults.

|                           | Depth of Roots | Thickness of Soil Evasion Layer | Wind Speed   |
|---------------------------|----------------|---------------------------------|--------------|
| <b>Mean</b>               | 0.649982691    | 0.366662733                     | 3.980098622  |
| <b>Standard Error</b>     | 0.006740618    | 0.002835742                     | 0.016368527  |
| <b>Median</b>             | 0.650117       | 0.354897                        | 3.982175     |
| <b>Mode</b>               | #N/A           | #N/A                            | 4.14391      |
| <b>Standard Deviation</b> | 0.202218541    | 0.085072252                     | 0.491055821  |
| <b>Sample Variance</b>    | 0.040892338    | 0.007237288                     | 0.241135819  |
| <b>Kurtosis</b>           | -1.200049739   | -0.594675096                    | -1.199988957 |
| <b>Skewness</b>           | -0.000299975   | 0.422969497                     | -0.00021101  |
| <b>Range</b>              | 0.698836       | 0.385032                        | 1.6976       |
| <b>Minimum</b>            | 0.300041       | 0.204388                        | 3.13166      |
| <b>Maximum</b>            | 0.998877       | 0.58942                         | 4.82926      |
| <b>Sum</b>                | 584.984422     | 329.99646                       | 3582.08876   |
| <b>Count</b>              | 900            | 900                             | 900          |
| <b>75%</b>                | 0.825627       | 0.427072                        | 4.40533      |
| <b>25%</b>                | 0.475012       | 0.300219                        | 3.55714      |

Contaminated Zone Dimensions                      Initial Soil Concentrations, pCi/g

Area: 2000.00 square meters  
 Thickness: 0.20 meters  
 Cover Depth: 0.00 meters

C-14                      5.000E-01

0  
 Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 2.500E+01 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)

| t (years):        | 0.000E+00                                | 1.000E+00 | 3.000E+00 | 1.000E+01 | 3.500E+01 | 1.500E+02 | 3.000E+02 | 1.000E+03 | 1.000E+04 |
|-------------------|--|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| TDOSE(t):         | 5.936E-01                                | 1.319E-12 | 1.682E-11 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| M(t):             | 2.374E-02                                | 5.275E-14 | 6.730E-13 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Maximum TDOSE(t): | 5.936E-01 mrem/yr at t = 0.000E+00 years |           |           |           |           |           |           |           |           |

|                           | Depth of Roots | Depth of Soil Mixing Layer | Plant Transfer Factor for Ni | Meat Transfer Factor for Ni | Milk Transfer Factor for Ni |
|---------------------------|----------------|----------------------------|------------------------------|-----------------------------|-----------------------------|
| <b>Mean</b>               | 0.649993827    | 0.249986177                | 0.075424134                  | 0.007565828                 | 0.025398861                 |
| <b>Standard Error</b>     | 0.006740584    | 0.004249897                | 0.002741354                  | 0.000276251                 | 0.000645479                 |
| <b>Median</b>             | 0.650577       | 0.2327835                  | 0.0498441                    | 0.00499491                  | 0.02004635                  |
| <b>Mode</b>               | #N/A           | #N/A                       | 0.0270835                    | 0.0160252                   | 0.0212972                   |
| <b>Standard Deviation</b> | 0.202217512    | 0.127496899                | 0.082240619                  | 0.008287517                 | 0.019364374                 |
| <b>Sample Variance</b>    | 0.040891922    | 0.016255459                | 0.006763519                  | 6.86829E-05                 | 0.000374979                 |
| <b>Kurtosis</b>           | -1.2001246     | -0.602278227               | 15.57308108                  | 16.40397836                 | 7.586634947                 |
| <b>Skewness</b>           | 0.00038154     | 0.421420863                | 3.271820383                  | 3.33939064                  | 2.242910824                 |
| <b>Range</b>              | 0.698224       | 0.57292766                 | 0.70178229                   | 0.071301364                 | 0.15766312                  |
| <b>Minimum</b>            | 0.300527       | 0.00658234                 | 0.00219871                   | 0.000291436                 | 0.00245888                  |
| <b>Maximum</b>            | 0.998751       | 0.57951                    | 0.703981                     | 0.0715928                   | 0.160122                    |
| <b>Sum</b>                | 584.994444     | 224.9875592                | 67.88172097                  | 6.809244837                 | 22.8589746                  |
| <b>Count</b>              | 900            | 900                        | 900                          | 900                         | 900                         |
| <b>75%</b>                | 0.825021       | 0.341009                   | 0.0924693                    | 0.00928698                  | 0.0320911                   |
| <b>25%</b>                | 0.475012       | 0.150229                   | 0.02707                      | 0.00269398                  | 0.0125698                   |

| Contaminated Zone Dimensions | Initial Soil Concentrations, pCi/g |           |
|------------------------------|------------------------------------|-----------|
| Area: 2000.00 square meters  | Ni-63                              | 5.000E-01 |
| Thickness: 0.20 meters       |                                    |           |
| Cover Depth: 0.00 meters     |                                    |           |

0

| Total Dose TDOSE(t), mrem/yr   |           |           |           |           |           |           |           |           |           |
|--|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| Basic Radiation Dose Limit = 2.500E+01 mrem/yr                             |           |           |           |           |           |           |           |           |           |
| Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t) |           |           |           |           |           |           |           |           |           |
| t (years):   | 0.000E+00 | 1.000E+00 | 3.000E+00 | 1.000E+01 | 3.500E+01 | 1.500E+02 | 3.000E+02 | 1.000E+03 | 1.000E+04 |
| TDOSE(t):  | 7.763E-03 | 7.690E-03 | 7.546E-03 | 7.061E-03 | 5.564E-03 | 1.815E-03 | 3.550E-04 | 0.000E+00 | 0.000E+00 |
| M(t):  | 3.105E-04 | 3.076E-04 | 3.018E-04 | 2.824E-04 | 2.225E-04 | 7.262E-05 | 1.420E-05 | 0.000E+00 | 0.000E+00 |

Maximum TDOSE(t): 7.763E-03 mrem/yr at t = 0.000E+00 years

|                           | Depth of Roots | External Gamma Shielding Factor | Plant Transfer Factor for Cs | Meat Transfer Factor for Cs | Milk Transfer Factor for Cs |
|---------------------------|----------------|---------------------------------|------------------------------|-----------------------------|-----------------------------|
| <b>Mean</b>               | 0.649993827    | 0.311576942                     | 0.065048881                  | 0.054032323                 | 0.011100371                 |
| <b>Standard Error</b>     | 0.006740584    | 0.005865496                     | 0.002634899                  | 0.000757146                 | 0.000181501                 |
| <b>Median</b>             | 0.650577       | 0.2701895                       | 0.0400047                    | 0.0498017                   | 0.00995379                  |
| <b>Mode</b>               | #N/A           | 0.127979                        | 0.0206515                    | #N/A                        | 0.0103708                   |
| <b>Standard Deviation</b> | 0.202217512    | 0.175964866                     | 0.079046976                  | 0.022714384                 | 0.005445023                 |
| <b>Sample Variance</b>    | 0.040891922    | 0.030963634                     | 0.006248424                  | 0.000515943                 | 2.96483E-05                 |
| <b>Kurtosis</b>           | -1.2001246     | 1.310726062                     | 19.04497359                  | 2.339536098                 | 2.999055409                 |
| <b>Skewness</b>           | 0.00038154     | 1.184287836                     | 3.63998789                   | 1.238550021                 | 1.416613307                 |
| <b>Range</b>              | 0.698224       | 0.9285946                       | 0.70438126                   | 0.1476186                   | 0.03832798                  |
| <b>Minimum</b>            | 0.300527       | 0.0471544                       | 0.00135774                   | 0.0141644                   | 0.00239922                  |
| <b>Maximum</b>            | 0.998751       | 0.975749                        | 0.705739                     | 0.161783                    | 0.0407272                   |
| <b>Sum</b>                | 584.994444     | 280.4192479                     | 58.54399301                  | 48.6290907                  | 9.99033421                  |
| <b>Count</b>              | 900            | 900                             | 900                          | 900                         | 900                         |
| <b>75%</b>                | 0.825021       | 0.399408                        | 0.0781693                    | 0.0655288                   | 0.0136946                   |
| <b>25%</b>                | 0.475012       | 0.182397                        | 0.0206404                    | 0.037896                    | 0.00725339                  |

| Contaminated Zone Dimensions |                       | Initial Soil Concentrations, pCi/g |           |  |  |  |  |  |
|------------------------------|-----------------------|------------------------------------|-----------|--|--|--|--|--|
| Area:                        | 2000.00 square meters | Cs-137                             | 5.000E-01 |  |  |  |  |  |
| Thickness:                   | 0.20 meters           |                                    |           |  |  |  |  |  |
| Cover Depth:                 | 0.00 meters           |                                    |           |  |  |  |  |  |

| Total Dose TDOSE(t), mrem/yr   |           |           |           |           |           |           |           |           |           |
|--|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| Basic Radiation Dose Limit = 2.500E+01 mrem/yr                             |           |           |           |           |           |           |           |           |           |
| Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t) |           |           |           |           |           |           |           |           |           |
| t (years):   | 0.000E+00 | 1.000E+00 | 3.000E+00 | 1.000E+01 | 3.500E+01 | 1.500E+02 | 3.000E+02 | 1.000E+03 | 1.000E+04 |
| TDOSE(t):  | 1.184E+00 | 1.155E+00 | 1.100E+00 | 9.273E-01 | 5.033E-01 | 2.978E-02 | 6.634E-04 | 0.000E+00 | 0.000E+00 |
| M(t):  | 4.735E-02 | 4.621E-02 | 4.401E-02 | 3.709E-02 | 2.013E-02 | 1.191E-03 | 2.654E-05 | 0.000E+00 | 0.000E+00 |

0Maximum TDOSE(t): 1.184E+00 mrem/yr at t = 0.000E+00 years

|                           | Density of Contaminated Zone | External Gamma Shielding Factor |
|---------------------------|------------------------------|---------------------------------|
| <b>Mean</b>               | 1.5999862                    | 0.311548422                     |
| <b>Standard Error</b>     | 0.006163312                  | 0.005862214                     |
| <b>Median</b>             | 1.60063                      | 0.2702035                       |
| <b>Mode</b>               | 1.88748                      | 0.238119                        |
| <b>Standard Deviation</b> | 0.184899372                  | 0.175866421                     |
| <b>Sample Variance</b>    | 0.034187778                  | 0.030928998                     |
| <b>Kurtosis</b>           | -1.200435789                 | 1.291223333                     |
| <b>Skewness</b>           | 0.000232204                  | 1.180458827                     |
| <b>Range</b>              | 0.63895                      | 0.9203616                       |
| <b>Minimum</b>            | 1.28077                      | 0.0471544                       |
| <b>Maximum</b>            | 1.91972                      | 0.967516                        |
| <b>Sum</b>                | 1439.98758                   | 280.3935794                     |
| <b>Count</b>              | 900                          | 900                             |
| <b>75%</b>                | 1.76106                      | 0.399162                        |
| <b>25%</b>                | 1.44001                      | 0.182547                        |



| Contaminated Zone Dimensions |                       | Initial Soil Concentrations, pCi/g |           |
|------------------------------|-----------------------|------------------------------------|-----------|
| Area:                        | 2000.00 square meters | Eu-152                             | 5.000E-01 |
| Thickness:                   | 0.20 meters           |                                    |           |
| Cover Depth:                 | 0.00 meters           |                                    |           |

0

| Total Dose TDOSE(t), mrem/yr   |           |           |           |           |           |           |           |           |           |
|--|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| Basic Radiation Dose Limit = 2.500E+01 mrem/yr                             |           |           |           |           |           |           |           |           |           |
| Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t) |           |           |           |           |           |           |           |           |           |
| t (years):   | 0.000E+00 | 1.000E+00 | 3.000E+00 | 1.000E+01 | 3.500E+01 | 1.500E+02 | 3.000E+02 | 1.000E+03 | 1.000E+04 |
| TDOSE(t):  | 1.207E+00 | 1.144E+00 | 1.029E+00 | 7.092E-01 | 1.876E-01 | 4.075E-04 | 1.250E-07 | 0.000E+00 | 0.000E+00 |
| M(t):  | 4.827E-02 | 4.577E-02 | 4.115E-02 | 2.837E-02 | 7.506E-03 | 1.630E-05 | 4.998E-09 | 0.000E+00 | 0.000E+00 |

0Maximum TDOSE(t): 1.207E+00 mrem/yr at t = 0.000E+00 years

|                           | Depth of<br>Roots | Depth of Soil<br>Mixing Layer | Plant Transfer Factor<br>for Pu |
|---------------------------|-------------------|-------------------------------|---------------------------------|
| <b>Mean</b>               | 0.6499827         | 0.249994075                   | 0.001524553                     |
| <b>Standard Error</b>     | 0.0067406         | 0.004253613                   | 5.88168E-05                     |
| <b>Median</b>             | 0.650117          | 0.2323455                     | 0.001000697                     |
| <b>Mode</b>               | #N/A              | #N/A                          | #N/A                            |
| <b>Standard Deviation</b> | 0.2022185         | 0.12760839                    | 0.001764503                     |
| <b>Sample Variance</b>    | 0.0408923         | 0.016283901                   | 3.11347E-06                     |
| <b>Kurtosis</b>           | -1.20005          | -0.594674848                  | 31.18195251                     |
| <b>Skewness</b>           | -0.0003           | 0.422969496                   | 4.326394078                     |
| <b>Range</b>              | 0.698836          | 0.57754766                    | 0.021008815                     |
| <b>Minimum</b>            | 0.300041          | 0.00658234                    | 5.83849E-05                     |
| <b>Maximum</b>            | 0.998877          | 0.58413                       | 0.0210672                       |
| <b>Sum</b>                | 584.98442         | 224.9946674                   | 1.372097365                     |
| <b>Count</b>              | 900               | 900                           | 900                             |
| <b>75%</b>                | 0.825627          | 0.340609                      | 0.00185214                      |
| <b>25%</b>                | 0.475012          | 0.150328                      | 0.000539749                     |

| Site-Specific Parameter Summary (continued) |   |            |            |   |                |
|---|---|------------|------------|---|----------------|
| Menu  | Parameter                                     | User Input | Default    | Used by RESRAD (If different from user input) | Parameter Name |
| R021  | Volumetric water content of the foundation    | not used   | 3.000E-02  | ---   | PH2OFL         |
| R021  | Diffusion coefficient for radon gas (m/sec):  |            |            |   |                |
| R021  | in cover material                             | not used   | 2.000E-06  | ---   | DIFCV          |
| R021  | in foundation material                        | not used   | 3.000E-07  | ---   | DIFFL          |
| R021  | in contaminated zone soil                     | not used   | 2.000E-06  | ---   | DIFCZ          |
| R021  | Radon vertical dimension of mixing (m)        | not used   | 2.000E+00  | ---   | HMIX           |
| R021  | Average building air exchange rate (1/hr)     | not used   | 5.000E-01  | ---   | REXG           |
| R021  | Height of the building (room) (m)             | not used   | 2.500E+00  | ---   | HRM            |
| R021  | Building interior area factor                 | not used   | 0.000E+00  | ---   | FAI            |
| R021  | Building depth below ground surface (m)       | not used   | -1.000E+00 | ---   | DMFL           |
| R021  | Emanating power of Rn-222 gas                 | not used   | 2.500E-01  | ---   | EMANA (1)      |
| R021  | Emanating power of Rn-220 gas                 | not used   | 1.500E-01  | ---   | EMANA (2)      |
| TITL  | Number of graphical time points               | 32         | ---        | ---   | NPTS           |
| TITL  | Maximum number of integration points for dose | 1          | ---        | ---   | LYMAX          |
| TITL  | Maximum number of integration points for risk | 1          | ---        | ---   | KYMAX          |

Summary of Pathway Selections

| Pathway                     | User Selection |
|-----------------------------|----------------|
| 1 -- external gamma         | active         |
| 2 -- inhalation (w/o radon) | active         |
| 3 -- plant ingestion        | active         |
| 4 -- meat ingestion         | active         |
| 5 -- milk ingestion         | active         |
| 6 -- aquatic foods          | active         |
| 7 -- drinking water         | active         |
| 8 -- soil ingestion         | active         |
| 9 -- radon                  | suppressed     |
| Find peak pathway doses     | active         |

| Contaminated Zone Dimensions |                       | Initial Concentrations, pCi/g |           |
|------------------------------|-----------------------|-------------------------------|-----------|
| Area:                        | 2000.00 square meters | Pu-238                        | 5.000E-01 |
| Thickness:                   | 0.20 meters           |                               |           |
| Cover Depth:                 | 0.00 meters           |                               |           |

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 2.500E+01 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)

|            |           |           |           |           |           |           |           |           |           |
|------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| t (years): | 0.000E+00 | 1.000E+00 | 3.000E+00 | 1.000E+01 | 3.500E+01 | 1.500E+02 | 3.000E+02 | 1.000E+03 | 1.000E+04 |
| TDOSE(t):  | 2.000E-01 | 1.969E-01 | 1.908E-01 | 1.708E-01 | 1.149E-01 | 1.818E-02 | 1.389E-03 | 9.288E-05 | 1.883E-08 |
| M(t):      | 8.001E-03 | 7.877E-03 | 7.632E-03 | 6.832E-03 | 4.597E-03 | 7.273E-04 | 5.557E-05 | 3.715E-06 | 7.531E-10 |

Maximum TDOSE(t): 2.000E-01 mrem/yr at t = 0.000E+00 years

|                    | Depth of Roots | Saturated Zone Hydraulic Conductivity | Depth of Soil Mixing Layer | Saturated Zone Hydraulic Gradient | Well Pump Intake Depth | Precipitation | Plant of Transfer Factor of Pu | Meat Transfer Factor for Pu |
|--------------------|----------------|---------------------------------------|----------------------------|-----------------------------------|------------------------|---------------|--------------------------------|-----------------------------|
| Mean               | 0.649954       | 462.5821307                           | 0.250024336                | 0.021500003                       | 30.20076067            | 1.007516014   | 0.001513964                    | 0.000108553                 |
| Standard Error     | 0.006741       | 8.605859733                           | 0.004251867                | 0.000163665                       | 0.385142389            | 0.006152158   | 5.64332E-05                    | 1.51915E-06                 |
| Median             | 0.650424       | 463.003                               | 0.23242                    | 0.02150015                        | 30.17325               | 1.00774       | 0.000998642                    | 0.000100071                 |
| Mode               | #N/A           | #N/A                                  | 0.210457                   | #N/A                              | #N/A                   | 1.0592        | #N/A                           | #N/A                        |
| Standard Deviation | 0.202218       | 258.175792                            | 0.127556003                | 0.004909947                       | 11.55427167            | 0.184564747   | 0.001692996                    | 4.55746E-05                 |
| Sample Variance    | 0.040892       | 66654.73957                           | 0.016270534                | 2.41076E-05                       | 133.5011939            | 0.034064146   | 2.86623E-06                    | 2.07704E-09                 |
| Kurtosis           | -1.20019       | -1.19985799                           | -0.598277249               | -1.199960676                      | -1.200301514           | -1.200686893  | 26.77309311                    | 2.419496533                 |
| Skewness           | 0.000106       | -0.000593817                          | 0.423447695                | 0.000249728                       | 0.000874386            | 0.000259715   | 3.938086976                    | 1.245098487                 |
| Range              | 0.69816        | 891.6096                              | 0.57216883                 | 0.0169729                         | 39.9469                | 0.637829      | 0.020564731                    | 0.000311274                 |
| Minimum            | 0.300751       | 16.0204                               | 0.00936717                 | 0.0130164                         | 10.2494                | 0.688481      | 5.86693E-05                    | 3.04625E-05                 |
| Maximum            | 0.998911       | 907.63                                | 0.581536                   | 0.0299893                         | 50.1963                | 1.32631       | 0.0206234                      | 0.000341736                 |
| Sum                | 584.9584       | 416323.9176                           | 225.0219022                | 19.3500031                        | 27180.6846             | 906.764413    | 1.362567175                    | 0.097697409                 |
| Count              | 900            | 900                                   | 900                        | 900                               | 900                    | 900           | 900                            | 900                         |
| 75%                | 0.826163       | 686.337                               | 0.340389                   | 0.0257509                         | 40.241                 | 1.16735       | 0.00185126                     | 0.000131715                 |
| 25%                | 0.475012       | 239.113                               | 0.150326                   | 0.0172576                         | 20.2196                | 0.848289      | 0.000538951                    | 7.61345E-05                 |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g

Area: 2000.00 square meters  
 Thickness: 0.20 meters  
 Cover Depth: 0.00 meters

Pu-239 5.000E-01

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 2.500E+01 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)

|            |           |           |           |           |           |           |           |           |           |
|------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| t (years): | 0.000E+00 | 1.000E+00 | 3.000E+00 | 1.000E+01 | 3.500E+01 | 1.500E+02 | 3.000E+02 | 1.000E+03 | 1.000E+04 |
| TDOSE(t):  | 2.233E-01 | 2.213E-01 | 2.173E-01 | 2.038E-01 | 1.621E-01 | 5.515E-02 | 1.132E-02 | 4.096E-01 | 0.000E+00 |
| M(t):      | 8.930E-03 | 8.851E-03 | 8.691E-03 | 8.153E-03 | 6.482E-03 | 2.206E-03 | 4.527E-04 | 1.638E-02 | 0.000E+00 |

Maximum TDOSE(t): 5.462E-01 mrem/yr at t = 970 ± 2 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 9.696E+02 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-Nuclide | Ground    |        | Inhalation |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | Soil      |        |
|---------------|-----------|--------|------------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|
|               | mrem/yr   | fract. | mrem/yr    | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. |
| Pu-239        | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total         | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 9.696E+02 years  
 Water Dependent Pathways

| Radio-Nuclide | Water     |        | Fish      |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | All Pathways* |        |
|---------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
|               | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       | fract. |
| Pu-239        | 4.706E-01 | 0.8617 | 1.171E-03 | 0.0021 | 0.000E+00 | 0.0000 | 7.283E-02 | 0.1334 | 1.505E-03 | 0.0028 | 3.661E-05 | 0.0001 | 5.462E-01     | 1.0000 |
| Total         | 4.706E-01 | 0.8617 | 1.171E-03 | 0.0021 | 0.000E+00 | 0.0000 | 7.283E-02 | 0.1334 | 1.505E-03 | 0.0028 | 3.661E-05 | 0.0001 | 5.462E-01     | 1.0000 |

\*Sum of all water independent and dependent pathways.

|                           | Depth of Roots | Depth of Soil Mixing Layer | Evapotranspiration Coefficient | Mass Loading for Inhalation | Plant Transfer Factor for Pu | Plant Transfer Factor for Am |
|---------------------------|----------------|----------------------------|--------------------------------|-----------------------------|------------------------------|------------------------------|
| <b>Mean</b>               | 0.649988       | 0.249979934                | 0.58500943                     | 2.45659E-05                 | 0.001517364                  | 0.001514999                  |
| <b>Standard Error</b>     | 0.00674        | 0.00425247                 | 0.001636874                    | 3.40419E-07                 | 5.71591E-05                  | 5.6421E-05                   |
| <b>Median</b>             | 0.650017       | 0.2326005                  | 0.585209                       | 2.35352E-05                 | 0.000997934                  | 0.000998544                  |
| <b>Mode</b>               | #N/A           | #N/A                       | #N/A                           | #N/A                        | 0.000655625                  | #N/A                         |
| <b>Standard Deviation</b> | 0.202193       | 0.127574087                | 0.049106209                    | 1.02126E-05                 | 0.001714774                  | 0.001692631                  |
| <b>Sample Variance</b>    | 0.040882       | 0.016275148                | 0.00241142                     | 1.04297E-10                 | 2.94045E-06                  | 2.865E-06                    |
| <b>Kurtosis</b>           | -1.199774      | -0.597085682               | -1.199914998                   | 6.869174325                 | 28.5578476                   | 22.88643449                  |
| <b>Skewness</b>           | 3.82E-05       | 0.420837328                | -0.000518995                   | 1.622119668                 | 4.063024021                  | 3.768802875                  |
| <b>Range</b>              | 0.699176       | 0.57754766                 | 0.16976                        | 9.92024E-05                 | 0.021260094                  | 0.018563233                  |
| <b>Minimum</b>            | 0.300141       | 0.00658234                 | 0.500166                       | 5.1228E-07                  | 6.23057E-05                  | 6.52672E-05                  |
| <b>Maximum</b>            | 0.999317       | 0.58413                    | 0.669926                       | 9.97147E-05                 | 0.0213224                    | 0.0186285                    |
| <b>Sum</b>                | 584.989        | 224.9819402                | 526.508487                     | 0.022109338                 | 1.365627739                  | 1.363498742                  |
| <b>Count</b>              | 900            | 900                        | 900                            | 900                         | 900                          | 900                          |
| <b>75%</b>                | 0.825627       | 0.340444                   | 0.627564                       | 2.87368E-05                 | 0.00185148                   | 0.00185313                   |
| <b>25%</b>                | 0.475012       | 0.150241                   | 0.542537                       | 0.000018362                 | 0.000538557                  | 0.000537897                  |

|                                     |                       |   |           |
|-------------------------------------|-----------------------|---|-----------|
| <u>Contaminated Zone Dimensions</u> |                       | <u>Initial Soil Concentrations, pCi/g</u> |           |
| Area:                               | 2000.00 square meters | Pu-241                                    | 5.000E-01 |
| Thickness:                          | 0.20 meters           |   |           |
| Cover Depth:                        | 0.00 meters           |   |           |

0  
 Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 2.500E+01 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)

|            |           |           |           |           |           |           |           |           |           |
|------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| t (years): | 0.000E+00 | 1.000E+00 | 3.000E+00 | 1.000E+01 | 3.500E+01 | 1.500E+02 | 3.000E+02 | 1.000E+03 | 1.000E+04 |
| TDOSE(t):  | 4.210E-03 | 4.346E-03 | 4.589E-03 | 5.218E-03 | 5.862E-03 | 3.893E-03 | 1.793E-03 | 3.094E-10 | 9.612E-11 |
| M(t):      | 1.684E-04 | 1.738E-04 | 1.836E-04 | 2.087E-04 | 2.345E-04 | 1.557E-04 | 7.173E-05 | 1.237E-11 | 3.845E-12 |

0\*Maximum TDOSE(t): 5.862E-03 mrem/yr at t = 34.10 ± 0.07 years

0  
 Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 3.410E+01 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground    |        | Inhalation |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | Soil      |        |
|-------------------|-----------|--------|------------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|
|                   | mrem/yr   | fract. | mrem/yr    | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. |
| Pu-241            | 2.809E-04 | 0.0479 | 4.081E-05  | 0.0070 | 0.000E+00 | 0.0000 | 4.740E-03 | 0.8085 | 9.933E-05 | 0.0169 | 1.152E-05 | 0.0020 | 6.900E-04 | 0.1177 |
| Total             | 2.809E-04 | 0.0479 | 4.081E-05  | 0.0070 | 0.000E+00 | 0.0000 | 4.740E-03 | 0.8085 | 9.933E-05 | 0.0169 | 1.152E-05 | 0.0020 | 6.900E-04 | 0.1177 |

0  
 Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 3.410E+01 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water     |        | Fish      |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | All Pathways* |        |
|-------------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
|                   | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       | fract. |
| Pu-241            | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 5.862E-03     | 1.0000 |
| Total             | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 5.862E-03     | 1.0000 |

0\*Sum of all water independent and dependent pathways.

|                    | Depth of Roots | Depth of Soil Mixing Layer | External Gamma Shielding Factor | Plant Transfer Factor for Am |
|--------------------|----------------|----------------------------|---------------------------------|------------------------------|
| Mean               | 0.6499669      | 0.249978731                | 0.311688396                     | 0.001507213                  |
| Standard Error     | 0.0067403      | 0.004247832                | 0.005873594                     | 5.42441E-05                  |
| Median             | 0.650424       | 0.2328915                  | 0.2699155                       | 0.000997779                  |
| Mode               | #N/A           | 0.390133                   | 0.246525                        | 0.00052656                   |
| Standard Deviation | 0.2022089      | 0.127434961                | 0.17620783                      | 0.001627322                  |
| Sample Variance    | 0.0408884      | 0.016239669                | 0.031049199                     | 2.64818E-06                  |
| Kurtosis           | -1.20006       | -0.605787603               | 1.340214143                     | 14.76014952                  |
| Skewness           | -9.99E-05      | 0.419931123                | 1.190883367                     | 3.185618162                  |
| Range              | 0.698945       | 0.56945966                 | 0.9405984                       | 0.014255048                  |
| Minimum            | 0.300751       | 0.00658234                 | 0.0496876                       | 5.54525E-05                  |
| Maximum            | 0.999696       | 0.576042                   | 0.990286                        | 0.0143105                    |
| Sum                | 584.97025      | 224.9808583                | 280.519556                      | 1.356491438                  |
| Count              | 900            | 900                        | 900                             | 900                          |
| 75%                | 0.826163       | 0.340362                   | 0.398555                        | 0.0018514                    |
| 25%                | 0.475012       | 0.150013                   | 0.182284                        | 0.000538494                  |



| Contaminated Zone Dimensions |  | Initial Soil Concentrations, pCi/g   |           |           |           |           |           |           |           |
|------------------------------|--|--|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| Area:                        | 2000.00 square meters                    | Am-241   | 5.000E-01 |           |           |           |           |           |           |
| Thickness:                   | 0.20 meters                              |  |           |           |           |           |           |           |           |
| Cover Depth:                 | 0.00 meters                              |  |           |           |           |           |           |           |           |
| 0                            |  |  |           |           |           |           |           |           |           |
|                              |  | Total Dose TDOSE(t), mrem/yr   |           |           |           |           |           |           |           |
|                              |  | Basic Radiation Dose Limit = 2.500E+01 mrem/yr                             |           |           |           |           |           |           |           |
|                              |  | Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t) |           |           |           |           |           |           |           |
| t (years):                   | 0.000E+00                                | 1.000E+00  | 3.000E+00 | 1.000E+01 | 3.500E+01 | 1.500E+02 | 3.000E+02 | 1.000E+03 | 1.000E+04 |
| TDOSE(t):                    | 2.320E-01                                | 2.311E-01  | 2.293E-01 | 2.228E-01 | 2.012E-01 | 1.230E-01 | 5.520E-02 | 8.799E-03 | 2.314E-09 |
| M(t):                        | 9.282E-03                                | 9.245E-03  | 9.170E-03 | 8.914E-03 | 8.048E-03 | 4.920E-03 | 2.208E-03 | 3.520E-10 | 9.258E-11 |
| OMaximum TDOSE(t):           | 2.320E-01 mrem/yr at t = 0.000E+00 years |  |           |           |           |           |           |           |           |

|                    | Saturated Zone Hydraulic Conductivity | Thickness of Unsaturated Zone 1 | Contaminated Zone Hydraulic Conductivity | Evapotranspiration Coefficient | Saturated Zone Hydraulic Gradient | Well Pump Intake Depth | Precipitation | Kd of H-3 in Contaminated Zone | Kd of H-3 in Unsaturated Zone 1 | Kd of H-3 in Saturated Zone |
|--------------------|---------------------------------------|---------------------------------|--|--------------------------------|-----------------------------------|------------------------|---------------|--------------------------------|---------------------------------|-----------------------------|
| Mean               | 462.5551824                           | 1.250028144                     | 1776.825359                              | 0.58499863                     | 0.021499883                       | 30.199142              | 1.007483728   | 0.249988448                    | 0.249995232                     | 0.25000169                  |
| Standard Error     | 8.60764065                            | 0.004814399                     | 97.54111472                              | 0.001636876                    | 0.00016369                        | 0.38505503             | 0.006152986   | 0.00481435                     | 0.004814503                     | 0.00481368                  |
| Median             | -463.2965                             | 1.249865                        | 325.201                                  | 0.5851685                      | 0.02148935                        | 30.18795               | 1.007885      | 0.250076                       | 0.2500775                       | 0.249859                    |
| Mode               | #N/A                                  | 1.46172                         | #N/A                                     | 0.652743                       | 0.0220943                         | 33.8905                | 1.06781       | #N/A                           | #N/A                            | 0.338982                    |
| Standard Deviation | 258.2292195                           | 0.144431978                     | 2926.233442                              | 0.049106286                    | 0.004910709                       | 11.551651              | 0.184589571   | 0.144430487                    | 0.144435085                     | 0.14441044                  |
| Sample Variance    | 66682.32981                           | 0.020860596                     | 8562842.154                              | 0.002411427                    | 2.41151E-05                       | 133.440641             | 0.03407331    | 0.020860166                    | 0.020861494                     | 0.02085437                  |
| Kurtosis           | -1.199962061                          | -1.199859597                    | 3.544515913                              | -1.200335918                   | -1.200401045                      | -1.200391              | -1.200013324  | -1.199667227                   | -1.199391216                    | -1.1996505                  |
| Skewness           | 0.000168595                           | -0.000235192                    | 2.067710609                              | -0.000279067                   | 0.00022789                        | -0.0003736             | -0.00091345   | 0.000339083                    | -0.000324204                    | 3.2336E-05                  |
| Range              | 891.7857                              | 0.49938                         | 12961.10041                              | 0.169634                       | 0.0169463                         | 39.8884                | 0.637786      | 0.49865118                     | 0.499721952                     | 0.49916413                  |
| Minimum            | 16.1493                               | 1.00024                         | 7.99959                                  | 0.500106                       | 0.0130032                         | 10.2081                | 0.688634      | 0.00073782                     | 2.20483E-05                     | 4.8875E-05                  |
| Maximum            | 907.935                               | 1.49962                         | 12969.1                                  | 0.66974                        | 0.0299495                         | 50.0965                | 1.32642       | 0.499389                       | 0.499744                        | 0.499213                    |
| Sum                | 416299.6642                           | 1125.02533                      | 1599142.823                              | 526.498767                     | 19.3498946                        | 27179.2278             | 906.735355    | 224.9896033                    | 224.9957087                     | 225.00152                   |
| Count              | 900                                   | 900                             | 900                                      | 900                            | 900                               | 900                    | 900           | 900                            | 900                             | 900                         |
| Largest(1)         | 907.935                               | 1.49962                         | 12969.1                                  | 0.66974                        | 0.0299495                         | 50.0965                | 1.32642       | 0.499389                       | 0.499744                        | 0.499213                    |
| Smallest(1)        | 16.1493                               | 1.00024                         | 7.99959                                  | 0.500106                       | 0.0130032                         | 10.2081                | 0.688634      | 0.00073782                     | 2.20483E-05                     | 4.8875E-05                  |
| 75%                | 686.072                               | 1.37578                         | 2070.3                                   | 0.627667                       | 0.0257757                         | 40.2158                | 1.16727       | 0.375177                       | 0.376059                        | 0.375077                    |
| 25%                | 239.09                                | 1.12538                         | 50.8494                                  | 0.542576                       | 0.0172524                         | 20.2459                | 0.848868      | 0.125418                       | 0.125915                        | 0.125333                    |

|                    | Saturated Zone Hydraulic Conductivity | Precipitation | Kd of C-14 in contaminated Zone | Kd of C-14 in Unsaturated Zone 1 | Kd of C-14 in Saturated Zone |
|--------------------|---------------------------------------|---------------|---------------------------------|----------------------------------|------------------------------|
| Mean               | 462.5521126                           | 1.00750291    | 2.500454134                     | 2.500056321                      | 2.50007587                   |
| Standard Error     | 8.608111111                           | 0.006151777   | 0.048133255                     | 0.048140062                      | 0.048143279                  |
| Median             | 463.2965                              | 1.00786       | 2.50249                         | 2.501445                         | 2.50084                      |
| Mode               | #N/A                                  | #N/A          | #N/A                            | 4.49243                          | 2.67481                      |
| Standard Deviation | 258.2433333                           | 0.184553316   | 1.443997636                     | 1.444201851                      | 1.444298365                  |
| Sample Variance    | 66689.61922                           | 0.034059927   | 2.085129172                     | 2.085718987                      | 2.085997768                  |
| Kurtosis           | -1.200124418                          | -1.2000071    | -1.199835858                    | -1.200150121                     | -1.200661883                 |
| Skewness           | 0.000381325                           | 0.000132538   | 0.000230347                     | 0.000134696                      | 5.61575E-05                  |
| Range              | 891.6719                              | 0.637702      | 4.98874533                      | 4.98603536                       | 4.98703167                   |
| Minimum            | 16.2631                               | 0.688308      | 0.00165467                      | 0.00483464                       | 0.00617833                   |
| Maximum            | 907.935                               | 1.32601       | 4.9904                          | 4.99087                          | 4.99321                      |
| Sum                | 416296.9013                           | 906.752619    | 2250.408721                     | 2250.050689                      | 2250.068283                  |
| Count              | 900                                   | 900           | 900                             | 900                              | 900                          |
| Largest(1)         | 907.935                               | 1.32601       | 4.9904                          | 4.99087                          | 4.99321                      |
| Smallest(1)        | 16.2631                               | 0.688308      | 0.00165467                      | 0.00483464                       | 0.00617833                   |
| 75%                | 686.072                               | 1.16825       | 3.7519                          | 3.7549                           | 3.75755                      |
| 25%                | 239.09                                | 0.848237      | 1.26514                         | 1.25225                          | 1.25245                      |

Contaminated Zone Dimensions

Initial Soil Concentrations, pCi/g

Area: 2000.00 square meters  
 Thickness: 0.20 meters  
 Cover Depth: 0.00 meters

C-14 5.000E-01

Total Dose TDOSE(t), mrem/yr

Basic Radiation Dose Limit = 4.000E+00 mrem/yr

Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)

|                   |                   |           |           |                          |           |           |           |           |           |
|-------------------|-------------------|-----------|-----------|--------------------------|-----------|-----------|-----------|-----------|-----------|
| t (years):        | 0.000E+00         | 1.000E+00 | 3.000E+00 | 1.000E+01                | 3.500E+01 | 1.500E+02 | 3.000E+02 | 1.000E+03 | 1.000E+04 |
| TDOSE(t):         | 0.000E+00         | 0.000E+00 | 0.000E+00 | 6.528E-18                | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| M(t):             | 0.000E+00         | 0.000E+00 | 0.000E+00 | 1.632E-18                | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Maximum TDOSE(t): | 1.087E-03 mrem/yr |           |           | at t = 7.95 ± 0.02 years |           |           |           |           |           |

|                    | Saturated Zone Hydraulic Conductivity | Thickness of Unsaturated Zone | Contaminated Zone erosion rate | Evapotranspiration Coefficient | Precipitation |
|--------------------|---------------------------------------|-------------------------------|--------------------------------|--------------------------------|---------------|
| Mean               | 462.5521126                           | 1.250002222                   | 0.000268867                    | 0.585001923                    | 1.007509689   |
| Standard Error     | 8.608111111                           | 0.00481359                    | 4.77306E-06                    | 0.001636762                    | 0.006152711   |
| Median             | 463.2965                              | 1.25028                       | 0.000232599                    | 0.5850495                      | 1.007605      |
| Mode               | #N/A                                  | 1.0528                        | 0.000145498                    | 0.652743                       | 1.02984       |
| Standard Deviation | 258.2433333                           | 0.144407692                   | 0.000143192                    | 0.049102864                    | 0.184581334   |
| Sample Variance    | 66689.61922                           | 0.020853582                   | 2.05039E-08                    | 0.002411091                    | 0.034070269   |
| Kurtosis           | -1.200124418                          | -1.2000078                    | -0.744076128                   | -1.200149724                   | -1.200661455  |
| Skewness           | 0.000381325                           | 0.00013691                    | 0.643645529                    | 0.000134412                    | 5.64198E-05   |
| Range              | 891.6719                              | 0.49898                       | 0.000507763                    | 0.169526                       | 0.63734       |
| Minimum            | 16.2631                               | 1.00024                       | 9.00566E-05                    | 0.500164                       | 0.68879       |
| Maximum            | 907.935                               | 1.49922                       | 0.00059782                     | 0.66969                        | 1.32613       |
| Sum                | 416296.9013                           | 1125.002                      | 0.241980407                    | 526.501731                     | 906.75872     |
| Count              | 900                                   | 900                           | 900                            | 900                            | 900           |
| 75%                | 686.072                               | 1.37578                       | 0.000373669                    | 0.627667                       | 1.16822       |
| 25%                | 239.09                                | 1.12538                       | 0.00014545                     | 0.542576                       | 0.848063      |

Contaminated Zone Dimensions

Area: 2000.00 square meters  
 Thickness: 0.20 meters  
 Cover Depth: 0.00 meters

Initial Soil Concentrations, pCi/g

Ni-63 5.000E-01

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)

t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00  
 M(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00  
 Maximum TDOSE(t): 5.312E-22 mrem/yr at t = 4879 ± \* years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 4.879E+03 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground    |        | Inhalation |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | Soil      |        |
|-------------------|-----------|--------|------------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|
|                   | mrem/yr   | fract. | mrem/yr    | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. |
| Ni-63             | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total             | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 4.879E+03 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water     |        | Fish      |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | All Pathways* |        |
|-------------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
|                   | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       | fract. |
| Ni-63             | 5.312E-22 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 5.312E-22     | 1.0000 |
| Total             | 5.312E-22 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 5.312E-22     | 1.0000 |

\*Sum of all water independent and dependent pathways.

|                    | Saturated Zone Hydraulic Conductivity | Thickness of Unsaturated Zone | Evapotranspiration Coefficient | Runoff Coefficient | Saturated Zone Hydraulic Gradient | Well Pump Intake Depth | Precipitation |
|--------------------|---------------------------------------|-------------------------------|--------------------------------|--------------------|-----------------------------------|------------------------|---------------|
| Mean               | 0.499501111                           | 450.5                         | 1.2499738                      | 450.4922222        | 0.499493333                       | 450.5                  | 0.585009323   |
| Standard Error     | 0.009638499                           | 8.665063954                   | 0.004813962                    | 8.665041842        | 0.009638521                       | 8.665063954            | 0.001636641   |
| Median             | 0.4995                                | 450.5                         | 1.25011                        | 450                | 0.4995                            | 450.5                  | 0.5850255     |
| Mode               | #N/A                                  | #N/A                          | 1.34034                        | 287                | 0.68                              | #N/A                   | 0.534356      |
| Standard Deviation | 0.289154967                           | 259.9519186                   | 0.144418874                    | 259.9512553        | 0.289155633                       | 259.9519186            | 0.049099222   |
| Sample Variance    | 0.083610595                           | 67575                         | 0.020856811                    | 67574.65511        | 0.08361098                        | 67575                  | 0.002410734   |
| Kurtosis           | -1.20008036                           | -1.2                          | -1.19941896                    | -1.199983984       | -1.200094766                      | -1.2                   | -1.19957509   |
| Skewness           | 2.30305E-05                           | 5.4459E-18                    | 4.78015E-05                    | 6.68969E-05        | 8.31864E-05                       | 7.42622E-18            | 0.000215841   |
| Range              | 1                                     | 899                           | 0.4987                         | 899                | 1                                 | 899                    | 0.169739      |
| Minimum            | 0                                     | 1                             | 1.00024                        | 1                  | 0                                 | 1                      | 0.500166      |
| Maximum            | 1                                     | 900                           | 1.49894                        | 900                | 1                                 | 900                    | 0.669905      |
| Sum                | 449.551                               | 405450                        | 1124.97642                     | 405443             | 449.544                           | 405450                 | 526.508391    |
| Count              | 900                                   | 900                           | 900                            | 900                | 900                               | 900                    | 900           |
| 75%                | 686.068                               | 1.37578                       | 0.627528                       | 0.375024           | 0.0257728                         | 40.2238                | 1.16727       |
| 25%                | 239.09                                | 1.12548                       | 0.542866                       | 0.325045           | 0.0172583                         | 20.2459                | 0.848089      |

Contaminated Zone Dimensions

Initial Soil Concentrations, pCi/g

Area: 2000.00 square meters  
 Thickness: 0.20 meters  
 Cover Depth: 0.00 meters

Sr-90 5.000E-01

0  
 Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)

|            |           |           |           |           |           |           |           |           |           |
|------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| t (years): | 0.000E+00 | 1.000E+00 | 3.000E+00 | 1.000E+01 | 3.500E+01 | 1.500E+02 | 3.000E+02 | 1.000E+03 | 1.000E+04 |
| TDOSE(t):  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 6.808E-08 | 7.945E-18 | 0.000E+00 | 0.000E+00 |
| M(t):      | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.702E-08 | 1.986E-18 | 0.000E+00 | 0.000E+00 |

0 Maximum TDOSE(t): 9.450E-02 mrem/yr at t = 54.3 ± 0.1 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 5.433E+01 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground    |        | Inhalation |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | Soil      |        |
|-------------------|-----------|--------|------------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|
|                   | mrem/yr   | fract. | mrem/yr    | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. |
| Sr-90             | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total             | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 5.433E+01 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water     |        | Fish      |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | All Pathways* |        |
|-------------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
|                   | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       | fract. |
| Sr-90             | 9.450E-02 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 9.450E-02     | 1.0000 |
| Total             | 9.450E-02 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 9.450E-02     | 1.0000 |

0\*Sum of all water independent and dependent pathways.



|                    | Saturated Zone Hydraulic Conductivity | Contaminated Zone Erosion Rate | Well Pump Intake Depth | Precipitation | Plant Transfer Factor for Gd |
|--------------------|---------------------------------------|--------------------------------|------------------------|---------------|------------------------------|
| Mean               | 462.5521126                           | 0.000268826                    | 30.203633              | 1.007507141   | 0.003625961                  |
| Standard Error     | 8.608111111                           | 4.77235E-06                    | 0.385066042            | 0.0061523     | 0.00016698                   |
| Median             | 463.2965                              | 0.000232628                    | 30.2199                | 1.007685      | 0.00201017                   |
| Mode               | #N/A                                  | 0.000134304                    | #N/A                   | 1.26213       | 0.00221257                   |
| Standard Deviation | 258.2433333                           | 0.00014317                     | 11.55198127            | 0.184568988   | 0.00500941                   |
| Sample Variance    | 66689.61922                           | 2.04978E-08                    | 133.4482714            | 0.034065711   | 2.50942E-05                  |
| Kurtosis           | -1.200124418                          | -0.746029457                   | -1.19983498            | -1.200149408  | 24.98574926                  |
| Skewness           | 0.000381325                           | 0.643147661                    | 0.000230231            | 0.000136172   | 4.128974922                  |
| Range              | 891.6719                              | 0.000508152                    | 39.91                  | 0.637212      | 0.054068145                  |
| Minimum            | 16.2631                               | 9.00823E-05                    | 10.2132                | 0.688618      | 7.22548E-05                  |
| Maximum            | 907.935                               | 0.000598234                    | 50.1232                | 1.32583       | 0.0541404                    |
| Sum                | 416296.9013                           | 0.241943826                    | 27183.2697             | 906.756427    | 3.263364788                  |
| Count              | 900                                   | 900                            | 900                    | 900           | 900                          |
| 75%                | 686.072                               | 0.000374514                    | 40.2152                | 1.16788       | 0.00423756                   |
| 25%                | 239.09                                | 0.000144827                    | 20.3211                | 0.848037      | 0.000959297                  |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g

Area: 2000.00 square meters  
 Thickness: 0.20 meters  
 Cover Depth: 0.00 meters

Eu-152 5.000E-01

0  
 Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)

t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00  
 M(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00  
 0 Maximum TDOSE(t): 1.691E-16 mrem/yr at t = 3587 ± 7 years

0  
 Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 3.587E+03 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground    |        | Inhalation |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | Soil      |        |
|-------------------|-----------|--------|------------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|
|                   | mrem/yr   | fract. | mrem/yr    | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. |
| Eu-152            | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total             | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

0  
 Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 3.587E+03 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water     |        | Fish      |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | All Pathways* |        |
|-------------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
|                   | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       | fract. |
| Eu-152            | 1.691E-16 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 1.691E-16     | 1.0000 |
| Total             | 1.691E-16 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 1.691E-16     | 1.0000 |

0\*Sum of all water independent and dependent pathways.

|                    | Saturated Zone Hydraulic Conductivity | Thickness of Unsaturated Zone | Evapotranspiration Coefficient | Runoff Coefficient | Saturated Zone Hydraulic Gradient | Density of Unsaturated Zone | Effective Porosity of Unsaturated Zone | Total Porosity of Unsaturated Zone | Well Pump Intake Depth | Precipitation |
|--------------------|---------------------------------------|-------------------------------|--------------------------------|--------------------|-----------------------------------|-----------------------------|--|------------------------------------|------------------------|---------------|
| Mean               | 462 5551824                           | 1.250028144                   | 0 585022528                    | 0 349999192        | 0 021499883                       | 1 599986411                 | 0 409993393                            | 0 454995153                        | 30 1996178             | 1 007502112   |
| Standard Error     | 8 60764065                            | 0 004814399                   | 0 001636771                    | 0 000962869        | 0 00016369                        | 0 006160876                 | 0 002503563                            | 0 002022027                        | 0 38516027             | 0 006151884   |
| Median             | 463 2965                              | 1 249865                      | 0 5850845                      | 0 350099           | 0 02148935                        | 1 59981                     | 0 4101575                              | 0 4550315                          | 30 2062                | 1.00732       |
| Mode               | #N/A                                  | 1 46172                       | #N/A                           | 0 355635           | 0 0220943                         | 1 65905                     | #N/A                                   | 0 382189                           | #N/A                   | 1.12122       |
| Standard Deviation | 258 2292195                           | 0 144431978                   | 0 049103125                    | 0 028886055        | 0 004910709                       | 0 184826292                 | 0 075106895                            | 0 060660822                        | 11 5548081             | 0 184556514   |
| Sample Variance    | 66682.32981                           | 0 020860596                   | 0 002411117                    | 0 000834404        | 2 41151E-05                       | 0 034160758                 | 0 005641046                            | 0 003679735                        | 133 51359              | 0 034061107   |
| Kurtosis           | -1.199962061                          | -1 199859597                  | -1.199911991                   | -1.200334777       | -1 200401045                      | -1 200390767                | -1 200012871                           | -1 199668332                       | -1 199391              | -1 199649603  |
| Skewness           | 0 000168595                           | -0 000235192                  | 9 756E-05                      | -0 000278642       | 0 00022789                        | -0 000374962                | -0 000912979                           | 0 000338694                        | -0 0003234             | 3 24491E-05   |
| Range              | 891.7857                              | 0 49938                       | 0 169618                       | 0 099785           | 0 0169463                         | 0 63821                     | 0 259508                               | 0 209433                           | 39 9777                | 0 637928      |
| Minimum            | 16 1493                               | 1 00024                       | 0 500056                       | 0 300062           | 0 0130032                         | 1 28013                     | 0 280258                               | 0 35031                            | 10 2018                | 0 688062      |
| Maximum            | 907.935                               | 1.49962                       | 0 669674                       | 0 399847           | 0 0299495                         | 1 91834                     | 0 539766                               | 0 559743                           | 50 1795                | 1 32599       |
| Sum                | 416299 6642                           | 1125 02533                    | 526 520275                     | 314 999273         | 19 3498946                        | 1439 98777                  | 368 994054                             | 409 495638                         | 27179 656              | 906 751901    |
| Count              | 900                                   | 900                           | 900                            | 900                | 900                               | 900                         | 900                                    | 900                                | 900                    | 900           |
| 75%                | 686 072                               | 1 37578                       | 0 627564                       | 0 375098           | 0 0257757                         | 1.76025                     | 0 475007                               | 0.507574                           | 40 2847                | 1.16735       |
| 25%                | 239 09                                | 1.12538                       | 0 542501                       | 0 325045           | 0 0172524                         | 1.44073                     | 0 345455                               | 0 402676                           | 20 2732                | 0 848176      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g

Area: 2000.00 square meters  
 Thickness: 0.20 meters  
 Cover Depth: 0.00 meters

Pu-238 5.000E-01

0  
 Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 1.716E-05 4.229E-06 1.852E-06 2.920E-09  
 M(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 4.289E-06 1.057E-06 4.631E-07 7.300E-10  
 Maximum TDOSE(t): 6.959E-03 mrem/yr at t = 471.1 ± 0.9 years

0  
 Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 4.711E+02 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground    |        | Inhalation |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | Soil      |        |
|-------------------|-----------|--------|------------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|
|                   | mrem/yr   | fract. | mrem/yr    | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. |
| Pu-238            | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total             | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

0  
 Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 4.711E+02 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water     |        | Fish      |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | All Pathways* |        |
|-------------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
|                   | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       | fract. |
| Pu-238            | 6.959E-03 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 6.959E-03     | 1.0000 |
| Total             | 6.959E-03 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 6.959E-03     | 1.0000 |

0\*Sum of all water independent and dependent pathways.  
 ORESALC.EXE execution time = 1.67 seconds

|                    | Saturated Zone Hydraulic Conductivity | Contaminated Zone Erosion Rate | Evapotranspiration Coefficient | Saturated Zone Hydraulic Gradient | Well Pump Intake Depth | Precipitation |
|--------------------|---------------------------------------|--------------------------------|--------------------------------|-----------------------------------|------------------------|---------------|
| Mean               | 462.5443884                           | 0.000268835                    | 0.58500943                     | 0.021499345                       | 30.19947467            | 1.007493339   |
| Standard Error     | 8.607082884                           | 4.77265E-06                    | 0.001636874                    | 0.000163689                       | 0.385146729            | 0.006151524   |
| Median             | 462.5815                              | 0.000232408                    | 0.585209                       | 0.02150035                        | 30.2031                | 1.007715      |
| Mode               | #N/A                                  | 0.000104856                    | #N/A                           | 0.019049                          | 23.135                 | 1.20429       |
| Standard Deviation | 258.2124865                           | 0.00014318                     | 0.049106209                    | 0.004910669                       | 11.55440187            | 0.184545716   |
| Sample Variance    | 66673.68819                           | 2.05004E-08                    | 0.00241142                     | 2.41147E-05                       | 133.5042027            | 0.034057121   |
| Kurtosis           | -1.199773828                          | -0.744707998                   | -1.199914998                   | -1.199465755                      | -1.200587029           | -1.199877082  |
| Skewness           | 3.8233E-05                            | 0.643362901                    | -0.000518995                   | -0.000162327                      | 0.000183068            | -1.03853E-05  |
| Range              | 892.8885                              | 0.000508858                    | 0.16976                        | 0.0169833                         | 39.934                 | 0.637617      |
| Minimum            | 15.7695                               | 9.00823E-05                    | 0.500166                       | 0.0130164                         | 10.2494                | 0.688933      |
| Maximum            | 908.658                               | 0.00059894                     | 0.669926                       | 0.0299997                         | 50.1834                | 1.32655       |
| Sum                | 416289.9496                           | 0.241951061                    | 526.508487                     | 19.3494105                        | 27179.5272             | 906.744005    |
| Count              | 900                                   | 900                            | 900                            | 900                               | 900                    | 900           |
| 75%                | 686.846                               | 0.000373743                    | 0.627564                       | 0.0257663                         | 40.2028                | 1.16749       |
| 25%                | 239.09                                | 0.000144837                    | 0.542537                       | 0.0172576                         | 20.2196                | 0.847791      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g

Area: 2000.00 square meters  
 Thickness: 0.20 meters  
 Cover Depth: 0.00 meters

Pu-239 5.000E-01

0  
 Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 1.455E-08 1.547E-08 2.016E-01 0.000E+00  
 M(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 3.639E-09 3.867E-09 5.039E-02 0.000E+00  
 Maximum TDOSE(t): 5.391E-01 mrem/yr at t = 894 ± 2 years

0  
 Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 8.940E+02 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground    |        | Inhalation |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | Soil      |        |
|-------------------|-----------|--------|------------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|
|                   | mrem/yr   | fract. | mrem/yr    | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. |
| Pu-239            | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total             | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

0  
 Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 8.940E+02 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water     |        | Fish      |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | All Pathways* |        |
|-------------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
|                   | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       | fract. |
| Pu-239            | 5.391E-01 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 5.391E-01     | 1.0000 |
| Total             | 5.391E-01 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 5.391E-01     | 1.0000 |

0\*Sum of all water independent and dependent pathways.

|                    | Saturated Zone Hydraulic Conductivity | Thickness of Unsaturated Zone | Contaminated Zone Erosion Rate | Evapotranspiration Coefficient | Saturated Zone Hydraulic Gradient | Well Pump Intake Depth | Precipitation | Plant Transfer Factor for Np |
|--------------------|---------------------------------------|-------------------------------|--------------------------------|--------------------------------|-----------------------------------|------------------------|---------------|------------------------------|
| Mean               | 462.5009132                           | 1.2500124                     | 0.000268852                    | 0.585000048                    | 0.021500324                       | 30.20099867            | 1.007525454   | 0.030353059                  |
| Standard Error     | 8.608129991                           | 0.004813444                   | 4.77352E-06                    | 0.001636649                    | 0.000163686                       | 0.385111719            | 0.006151901   | 0.001110218                  |
| Median             | 463.1015                              | 1.250245                      | 0.000232192                    | 0.5850015                      | 0.02148865                        | 30.2148                | 1.007745      | 0.0200573                    |
| Mode               | #N/A                                  | 1.0432                        | 0.000206587                    | #N/A                           | #N/A                              | 12.9547                | 1.06267       | #N/A                         |
| Standard Deviation | 258.2438997                           | 0.144403315                   | 0.000143206                    | 0.049099474                    | 0.004910567                       | 11.55335156            | 0.184557024   | 0.033306554                  |
| Sample Variance    | 66689.91174                           | 0.020852317                   | 2.05079E-08                    | 0.002410758                    | 2.41137E-05                       | 133.4799324            | 0.034061295   | 0.001109327                  |
| Kurtosis           | -1.200185297                          | -1.19985556                   | -0.744096153                   | -1.199960161                   | -1.200302418                      | -1.200687375           | -1.200505914  | 18.3783643                   |
| Skewness           | 0.000105668                           | -0.000594614                  | 0.643576391                    | 0.000249692                    | 0.000875268                       | 0.00025997             | -7.34731E-05  | 3.45567101                   |
| Range              | 891.5912                              | 0.4987                        | 0.000508399                    | 0.169729                       | 0.0169774                         | 39.9265                | 0.638066      | 0.32047254                   |
| Minimum            | 16.5488                               | 1.00024                       | 9.01667E-05                    | 0.500164                       | 0.013021                          | 10.2301                | 0.688634      | 0.00136446                   |
| Maximum            | 908.14                                | 1.49894                       | 0.000598566                    | 0.669893                       | 0.0299984                         | 50.1566                | 1.3267        | 0.321837                     |
| Sum                | 416250.8219                           | 1125.01116                    | 0.241966728                    | 526.500043                     | 19.3502913                        | 27180.8988             | 906.772909    | 27.31775275                  |
| Count              | 900                                   | 900                           | 900                            | 900                            | 900                               | 900                    | 900           | 900                          |
| 75%                | 687.53                                | 1.37516                       | 0.000373669                    | 0.627509                       | 0.0257674                         | 40.206                 | 1.16727       | 0.037319                     |
| 25%                | 239.09                                | 1.12502                       | 0.000144915                    | 0.542576                       | 0.0172583                         | 20.2337                | 0.848225      | 0.0108135                    |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g

Area: 2000.00 square meters  
 Thickness: 0.20 meters  
 Cover Depth: 0.00 meters

Pu-241 5.000E-01

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)

|            |           |           |           |           |           |           |           |           |           |
|------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| t (years): | 0.000E+00 | 1.000E+00 | 3.000E+00 | 1.000E+01 | 3.500E+01 | 1.500E+02 | 3.000E+02 | 1.000E+03 | 1.000E+04 |
| TDOSE(t):  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 2.972E-11 | 1.001E-10 | 2.340E-10 | 6.416E-14 |
| M(t):      | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 7.430E-12 | 2.503E-11 | 5.850E-11 | 1.604E-14 |

Maximum TDOSE(t): 2.639E-06 mrem/yr at t = 3949 ± 8 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 3.949E+03 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground    |        | Inhalation |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | Soil      |        |
|-------------------|-----------|--------|------------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|
|                   | mrem/yr   | fract. | mrem/yr    | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. |
| Pu-241            | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total             | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 3.949E+03 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water     |        | Fish      |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | All Pathways* |        |
|-------------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
|                   | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       | fract. |
| Pu-241            | 2.639E-06 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 2.639E-06     | 1.0000 |
| Total             | 2.639E-06 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 2.639E-06     | 1.0000 |

\*Sum of all water independent and dependent pathways.



|                    | Saturated Zone<br>Hydraulic Conductivity | Thickness of<br>Unsatuated<br>Zone | Contaminated<br>Zone Erosion Rate | Evapotranspiration<br>Coefficient | Saturated Zone<br>Hydraulic Gradient | Well Pump<br>Intake Depth | Precipitation | Plant Transfer<br>Factor for Np |
|--------------------|--|------------------------------------|-----------------------------------|-----------------------------------|--------------------------------------|---------------------------|---------------|---------------------------------|
| Mean               | 462.5009132                              | 1.2500124                          | 0.000268852                       | 0.585000048                       | 0.021500324                          | 30.2009987                | 1.007525454   | 0.030353059                     |
| Standard Error     | 8.608129991                              | 0.004813444                        | 4.77352E-06                       | 0.001636649                       | 0.000163686                          | 0.38511172                | 0.006151901   | 0.001110218                     |
| Median             | 463.1015                                 | 1.250245                           | 0.000232192                       | 0.5850015                         | 0.02148865                           | 30.2148                   | 1.007745      | 0.0200573                       |
| Mode               | #N/A                                     | 1.0432                             | 0.000206587                       | #N/A                              | #N/A                                 | 12.9547                   | 1.06267       | #N/A                            |
| Standard Deviation | 258.2438997                              | 0.144403315                        | 0.000143206                       | 0.049099474                       | 0.004910567                          | 11.5533516                | 0.184557024   | 0.033306554                     |
| Sample Variance    | 66689.91174                              | 0.020852317                        | 2.05079E-08                       | 0.002410758                       | 2.41137E-05                          | 133.479932                | 0.034061295   | 0.001109327                     |
| Kurtosis           | -1.200185297                             | -1.19985556                        | -0.744096153                      | -1.199960161                      | -1.200302418                         | -1.20068738               | -1.200505914  | 18.3783643                      |
| Skewness           | 0.000105668                              | -0.000594614                       | 0.643576391                       | 0.000249692                       | 0.000875268                          | 0.00025997                | -7.34731E-05  | 3.45567101                      |
| Range              | 891.5912                                 | 0.4987                             | 0.000508399                       | 0.169729                          | 0.0169774                            | 39.9265                   | 0.638066      | 0.32047254                      |
| Minimum            | 16.5488                                  | 1.00024                            | 9.01667E-05                       | 0.500164                          | 0.013021                             | 10.2301                   | 0.688634      | 0.00136446                      |
| Maximum            | 908.14                                   | 1.49894                            | 0.000598566                       | 0.669893                          | 0.0299984                            | 50.1566                   | 1.3267        | 0.321837                        |
| Sum                | 416250.8219                              | 1125.01116                         | 0.241966728                       | 526.500043                        | 19.3502913                           | 27180.8988                | 906.772909    | 27.31775275                     |
| Count              | 900                                      | 900                                | 900                               | 900                               | 900                                  | 900                       | 900           | 900                             |
| 75%                | 687.53                                   | 1.37516                            | 0.000373669                       | 0.627509                          | 0.0257674                            | 40.206                    | 1.16727       | 0.037319                        |
| 25%                | 239.09                                   | 1.12502                            | 0.000144915                       | 0.542576                          | 0.0172583                            | 20.2337                   | 0.848225      | 0.0108135                       |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g

Area: 2000.00 square meters  
 Thickness: 0.20 meters  
 Cover Depth: 0.00 meters

Am-241 5.000E-01

0  
 Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 1.265E-09 3.402E-09 4.016E-05 9.965E-13  
 M(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 3.161E-10 8.504E-10 1.004E-05 2.491E-13  
 Maximum TDOSE(t): 4.100E-05 mrem/yr at t = 1040 ± 2 years

0  
 Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.040E+03 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground    |        | Inhalation |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | Soil      |        |
|-------------------|-----------|--------|------------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|
|                   | mrem/yr   | fract. | mrem/yr    | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. |
| Am-241            | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total             | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

0  
 Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.040E+03 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water     |        | Fish      |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | All Pathways* |        |
|-------------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
|                   | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       | fract. |
| Am-241            | 4.100E-05 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 4.100E-05     | 1.0000 |
| Total             | 4.100E-05 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 4.100E-05     | 1.0000 |

0\*Sum of all water independent and dependent pathways.

|                    | Density of Contaminated Zone | Contaminated Zone B Parameter | Contaminated Zone Hydraulic Conductivity | Runoff Coefficient | Precipitation | Kd of H-3 in Contaminated Zone |
|--------------------|------------------------------|-------------------------------|--|--------------------|---------------|--------------------------------|
| Mean               | 1.599988856                  | 5.585036656                   | 2277.140165                              | 0.349996129        | 1.00749158    | 0.249994733                    |
| Standard Error     | 0.006162084                  | 0.029557835                   | 162.5834621                              | 0.000962876        | 0.00615272    | 0.004813397                    |
| Median             | 1.600015                     | 5.585205                      | 97.22505                                 | 0.350002           | 1.007545      | 0.250171                       |
| Mode               | 1.62469                      | #N/A                          | #N/A                                     | 0.381216           | 0.894636      | #N/A                           |
| Standard Deviation | 0.184862511                  | 0.886735047                   | 4877.503862                              | 0.028886285        | 0.184581596   | 0.144401922                    |
| Sample Variance    | 0.034174148                  | 0.786299043                   | 23790043.92                              | 0.000834417        | 0.034070365   | 0.020851915                    |
| Kurtosis           | -1.19977361                  | -1.199467197                  | 7.184586365                              | -1.19946353        | -1.200587087  | -1.199877898                   |
| Skewness           | 3.59934E-05                  | -0.000216834                  | 2.74102626                               | -0.00016192        | 0.000184958   | -1.12037E-05                   |
| Range              | 0.63925                      | 3.06566                       | 25276.43404                              | 0.099901           | 0.63794       | 0.498920271                    |
| Minimum            | 1.28013                      | 4.05148                       | 0.36596                                  | 0.300097           | 0.68879       | 0.000729729                    |
| Maximum            | 1.91938                      | 7.11714                       | 25276.8                                  | 0.399998           | 1.32673       | 0.49965                        |
| Sum                | 1439.98997                   | 5026.53299                    | 2049426.149                              | 314.996516         | 906.742422    | 224.9952596                    |
| Count              | 900                          | 900                           | 900                                      | 900                | 900           | 900                            |
| Largest(1)         | 1.91938                      | 7.11714                       | 25276.8                                  | 0.399998           | 1.32673       | 0.49965                        |
| Smallest(1)        | 1.28013                      | 4.05148                       | 0.36596                                  | 0.300097           | 0.68879       | 0.000729729                    |
| 75%                | 1.76057                      | 6.35399                       | 1567.26                                  | 0.375096           | 1.16729       | 0.37519                        |
| 25%                | 1.44001                      | 4.81996                       | 5.90608                                  | 0.325045           | 0.848063      | 0.125032                       |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g

Area: 2000.00 square meters  
 Thickness: 1.00 meters  
 Cover Depth: 0.00 meters

H-3 1.000E+00

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)

|            |           |           |           |           |           |           |           |           |           |
|------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| t (years): | 0.000E+00 | 1.000E+00 | 3.000E+00 | 1.000E+01 | 3.500E+01 | 1.500E+02 | 3.000E+02 | 1.000E+03 | 1.000E+04 |
| TDOSE(t):  | 0.000E+00 | 2.536E-02 | 5.428E-03 | 2.442E-05 | 9.004E-14 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| M(t):      | 0.000E+00 | 6.339E-03 | 1.357E-03 | 6.105E-06 | 2.251E-14 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

Maximum TDOSE(t): 5.027E-02 mrem/yr at t = 0.1213 ± 0.0002 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.213E-01 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-Nuclide | Ground    |        | Inhalation |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | Soil      |        |
|---------------|-----------|--------|------------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|
|               | mrem/yr   | fract. | mrem/yr    | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. |
| H-3           | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total         | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.213E-01 years  
 Water Dependent Pathways

| Radio-Nuclide | Water     |        | Fish      |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | All Pathways* |        |
|---------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
|               | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       | fract. |
| H-3           | 5.027E-02 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 5.027E-02     | 1.0000 |
| Total         | 5.027E-02 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 5.027E-02     | 1.0000 |

\*Sum of all water independent and dependent pathways.  
 RESCALC.EXE execution time = 1.45 seconds

|                    | Thickness of Evasion Layer of C-14 in Soil | Contaminated Zone Hydraulic Conductivity | Kd of C-14 in contaminated Zone |
|--------------------|--|--|---------------------------------|
| Mean               | 0.366642664                                | 2278.823014                              | 2.500289956                     |
| Standard Error     | 0.00283506                                 | 162.7674136                              | 0.048142715                     |
| Median             | 0.355092                                   | 95.2229                                  | 2.506395                        |
| Mode               | #N/A                                       | #N/A                                     | #N/A                            |
| Standard Deviation | 0.085051815                                | 4883.022407                              | 1.444281457                     |
| Sample Variance    | 0.007233811                                | 23843907.82                              | 2.085948928                     |
| Kurtosis           | -0.598701793                               | 7.164907647                              | -1.199988632                    |
| Skewness           | 0.42028563                                 | 2.739583737                              | -0.000210463                    |
| Range              | 0.384598                                   | 25136.83605                              | 4.99294534                      |
| Minimum            | 0.201525                                   | 0.36395                                  | 0.00487466                      |
| Maximum            | 0.586123                                   | 25137.2                                  | 4.99782                         |
| Sum                | 329.978398                                 | 2050940.713                              | 2250.260961                     |
| Count              | 900  | 900                                      | 900                             |
| Largest(1)         | 0.586123                                   | 25137.2                                  | 4.99782                         |
| Smallest(1)        | 0.201525                                   | 0.36395                                  | 0.00487466                      |
| 75%                | 0.427106                                   | 1574.65                                  | 3.75097                         |
| 25%                | 0.300003                                   | 5.96396                                  | 1.25629                         |

Contaminated Zone Dimensions

Area: 2000.00 square meters  
 Thickness: 1.00 meters  
 Cover Depth: 0.00 meters

Initial Soil Concentrations, pCi/g

C-14 1.000E+00

Total Dose TDOSE(t), mrem/yr

Basic Radiation Dose Limit = 4.000E+00 mrem/yr

Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)

t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 1.176E-03 1.482E-09 2.882E-30 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00  
 M(t): 0.000E+00 2.940E-04 3.705E-10 7.205E-31 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00  
 Maximum TDOSE(t): 5.044E-01 mrem/yr at t = 0.1009 ± 0.0002 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)

As mrem/yr and Fraction of Total Dose At t = 1.009E-01 years

Water Independent Pathways (Inhalation excludes radon)

| Radio-Nuclide | Ground    |        | Inhalation |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | Soil      |        |
|---------------|-----------|--------|------------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|
|               | mrem/yr   | fract. | mrem/yr    | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. |
| C-14          | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total         | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)

As mrem/yr and Fraction of Total Dose At t = 1.009E-01 years

Water Dependent Pathways

| Radio-Nuclide | Water     |        | Fish      |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | All Pathways* |        |
|---------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
|               | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       | fract. |
| C-14          | 5.044E-01 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 5.044E-01     | 1.0000 |
| Total         | 5.044E-01 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 5.044E-01     | 1.0000 |

\*Sum of all water independent and dependent pathways.

|                    | Contaminated Zone              |                        |                                |                    |                             |  |                                    |               |
|--------------------|--------------------------------|------------------------|--------------------------------|--------------------|-----------------------------|--|------------------------------------|---------------|
|                    | Contaminated Zone Erosion Rate | Hydraulic Conductivity | Evapotranspiration Coefficient | Runoff Coefficient | Density of Unsaturated Zone | Effective Porosity of Unsaturated Zone | Total Porosity of Unsaturated Zone | Precipitation |
| Mean               | 0.000268808                    | 2273.909692            | 0.585005496                    | 0.350000028        | 1.600012244                 | 0.410006522                            | 0.455008379                        | 1.007501901   |
| Standard Error     | 4.77306E-06                    | 162.1524557            | 0.001636863                    | 0.000962736        | 0.006162287                 | 0.002503226                            | 0.002021753                        | 0.006151779   |
| Median             | 0.000232647                    | 96.42905               | 0.5849275                      | 0.350001           | 1.59957                     | 0.4100965                              | 0.4550805                          | 1.00773       |
| Mode               | #N/A                           | #N/A                   | 0.565466                       | 0.378622           | 1.60064                     | 0.422049                               | #N/A                               | 1.31383       |
| Standard Deviation | 0.000143192                    | 4864.573672            | 0.049105883                    | 0.028882065        | 0.184868623                 | 0.075096787                            | 0.060652604                        | 0.184553372   |
| Sample Variance    | 2.05039E-08                    | 23664077.01            | 0.002411388                    | 0.000834174        | 0.034176408                 | 0.005639527                            | 0.003678738                        | 0.034059947   |
| Kurtosis           | -0.744097135                   | 7.084605376            | -1.20010564                    | -1.199960807       | -1.200302968                | -1.200686978                           | -1.200503565                       | -1.200385121  |
| Skewness           | 0.643558793                    | 2.728505515            | 0.000137047                    | 0.00025033         | 0.000873747                 | 0.000259907                            | -7.15461E-05                       | 4.61703E-05   |
| Range              | 0.000508049                    | 24804.43605            | 0.169619                       | 0.09984            | 0.63915                     | 0.259522                               | 0.209693                           | 0.637146      |
| Minimum            | 9.01833E-05                    | 0.36395                | 0.500166                       | 0.300097           | 1.28079                     | 0.280196                               | 0.350208                           | 0.689074      |
| Maximum            | 0.000598232                    | 24804.8                | 0.669785                       | 0.399937           | 1.91994                     | 0.539718                               | 0.559901                           | 1.32622       |
| Sum                | 0.241927129                    | 2046518.723            | 526.504946                     | 315.000025         | 1440.01102                  | 369.00587                              | 409.507541                         | 906.751711    |
| Count              | 900                            | 900                    | 900                            | 900                | 900                         | 900                                    | 900                                | 900           |
| 75%                | 3.75E-04                       | 1.57E+03               | 6.28E-01                       | 3.75E-01           | 1.76E+00                    | 4.75E-01                               | 5.08E-01                           | 1.17E+00      |
| 25%                | 1.45E-04                       | 5.89E+00               | 5.43E-01                       | 3.25E-01           | 1.44E+00                    | 3.45E-01                               | 4.03E-01                           | 8.48E-01      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g

Area: 2000.00 square meters  
 Thickness: 1.00 meters  
 Cover Depth: 0.00 meters

Co-60 1.000E+00

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)

|            |           |           |           |           |           |           |           |           |           |
|------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| t (years): | 0.000E+00 | 1.000E+00 | 3.000E+00 | 1.000E+01 | 3.500E+01 | 1.500E+02 | 3.000E+02 | 1.000E+03 | 1.000E+04 |
| TDOSE(t):  | 0.000E+00 | 5.635E-02 | 4.321E-02 | 1.706E-02 | 6.166E-04 | 1.437E-10 | 3.208E-19 | 0.000E+00 | 0.000E+00 |
| M(t):      | 0.000E+00 | 1.409E-02 | 1.080E-02 | 4.264E-03 | 1.542E-04 | 3.594E-11 | 8.019E-20 | 0.000E+00 | 0.000E+00 |

Maximum TDOSE(t): 5.942E-02 mrem/yr at t = 0.652 ± 0.001 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 6.518E-01 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-Nuclide | Ground    |        | Inhalation |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | Soil      |        |
|---------------|-----------|--------|------------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|
|               | mrem/yr   | fract. | mrem/yr    | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. |
| Co-60         | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total         | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 6.518E-01 years  
 Water Dependent Pathways

| Radio-Nuclide | Water     |        | Fish      |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | All Pathways* |        |
|---------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
|               | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       | fract. |
| Co-60         | 5.942E-02 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 5.942E-02     | 1.0000 |
| Total         | 5.942E-02 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 5.942E-02     | 1.0000 |

\*Sum of all water independent and dependent pathways.



|                    | Contaminated Zone<br>Erosion Rate | Evapotranspiration<br>Coefficient | Runoff Coefficient | Density of<br>Unsaturated Zone | Effective Porosity of<br>Unsaturated Zone | Total Porosity of<br>Unsaturated Zone | Precipitation |
|--------------------|-----------------------------------|-----------------------------------|--------------------|--------------------------------|---|---------------------------------------|---------------|
| Mean               | 0.000268837                       | 0.584991104                       | 0.350005479        | 1.599991267                    | 0.409989919                               | 0.455002578                           | 1.007488272   |
| Standard Error     | 4.77281E-06                       | 0.001636747                       | 0.00096273         | 0.006161712                    | 0.002503686                               | 0.002021635                           | 0.006153245   |
| Median             | 0.000232533                       | 0.585038                          | 0.350015           | 1.60075                        | 0.409732                                  | 0.4548075                             | 1.007535      |
| Mode               | 0.00029171                        | 0.573988                          | 0.349318           | 1.86433                        | #N/A                                      | 0.544867                              | 1.30224       |
| Standard Deviation | 0.000143184                       | 0.049102425                       | 0.028881898        | 0.184851368                    | 0.075110588                               | 0.060649047                           | 0.184597359   |
| Sample Variance    | 2.05018E-08                       | 0.002411048                       | 0.000834164        | 0.034170028                    | 0.0056416                                 | 0.003678307                           | 0.034076185   |
| Kurtosis           | -0.746746422                      | -1.199417592                      | -1.199576162       | -1.199980454                   | -1.200826746                              | -1.200016993                          | -1.199911705  |
| Skewness           | 0.642587388                       | 4.72965E-05                       | 0.000215723        | -0.000536939                   | 0.000534848                               | -6.72923E-05                          | 8.59276E-06   |
| Range              | 0.000507779                       | 0.169557                          | 0.099847           | 0.63936                        | 0.259519                                  | 0.209435                              | 0.637726      |
| Minimum            | 0.000090411                       | 0.500082                          | 0.300097           | 1.28022                        | 0.280228                                  | 0.350306                              | 0.688634      |
| Maximum            | 0.00059819                        | 0.669639                          | 0.399944           | 1.91958                        | 0.539747                                  | 0.559741                              | 1.32636       |
| Sum                | 0.241952968                       | 526.491994                        | 315.004931         | 1439.99214                     | 368.990927                                | 409.50232                             | 906.739445    |
| Count              | 900                               | 900                               | 900                | 900                            | 900                                       | 900                                   | 900           |
| 75%                | 3.73E-04                          | 6.28E-01                          | 3.75E-01           | 1.76E+00                       | 4.75E-01                                  | 5.08E-01                              | 1.17E+00      |
| 25%                | 1.45E-04                          | 5.43E-01                          | 3.25E-01           | 1.44E+00                       | 3.45E-01                                  | 4.03E-01                              | 8.48E-01      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g

Area: 2000.00 square meters  
 Thickness: 1.00 meters  
 Cover Depth: 0.00 meters

Ni-63 1.000E+00

0  
 Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 1.972E-04 1.633E-04 6.867E-05 2.217E-05 1.126E-07 0.000E+00  
 M(t): 0.000E+00 0.000E+00 0.000E+00 4.929E-05 4.083E-05 1.717E-05 5.544E-06 2.816E-08 0.000E+00  
 0 Maximum TDOSE(t): 2.078E-04 mrem/yr at t = 3.792 ± 0.008 years

0  
 Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 3.792E+00 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground    |        | Inhalation |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | Soil      |        |
|-------------------|-----------|--------|------------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|
|                   | mrem/yr   | fract. | mrem/yr    | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. |
| Ni-63             | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total             | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

0  
 Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 3.792E+00 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water     |        | Fish      |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | All Pathways* |        |
|-------------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
|                   | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       | fract. |
| Ni-63             | 2.078E-04 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 2.078E-04     | 1.0000 |
| Total             | 2.078E-04 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 2.078E-04     | 1.0000 |

0\*Sum of all water independent and dependent pathways.

|                    | Density of Contaminated Zone | Contaminated Zone b Parameter | Contaminated Zone Hydraulic Conductivity | Contaminated Zone Total Porosity | Evapotranspiration Coefficient | Runoff Coefficient | Precipitation |
|--------------------|------------------------------|-------------------------------|--|----------------------------------|--------------------------------|--------------------|---------------|
| Mean               | 1.599998989                  | 5.584839233                   | 2279.165753                              | 0.454997122                      | 0.584993402                    | 0.350001247        | 1.007488272   |
| Standard Error     | 0.006162766                  | 0.029557717                   | 162.8127778                              | 0.002021813                      | 0.001637026                    | 0.000962683        | 0.006153245   |
| Median             | 1.60022                      | 5.585685                      | 96.05685                                 | 0.455246                         | 0.5848245                      | 0.3499085          | 1.007535      |
| Mode               | 1.60771                      | 5.38614                       | #N/A                                     | 0.420488                         | #N/A                           | 0.392794           | 1.30224       |
| Standard Deviation | 0.184882993                  | 0.886731513                   | 4884.383334                              | 0.060654387                      | 0.04911078                     | 0.028880485        | 0.184597359   |
| Sample Variance    | 0.034181721                  | 0.786292776                   | 23857200.55                              | 0.003678955                      | 0.002411869                    | 0.000834082        | 0.034076185   |
| Kurtosis           | -1.200468675                 | -1.199418707                  | 7.163082773                              | -1.199982036                     | -1.200825834                   | -1.200018055       | -1.199911705  |
| Skewness           | -0.000346662                 | 4.63389E-05                   | 2.739416477                              | -0.000538719                     | 0.00053554                     | -6.73476E-05       | 8.59276E-06   |
| Range              | 0.63744                      | 3.062                         | 25242.13404                              | 0.209789                         | 0.169686                       | 0.09973            | 0.637726      |
| Minimum            | 1.28154                      | 4.05148                       | 0.36596                                  | 0.350074                         | 0.500149                       | 0.300146           | 0.688634      |
| Maximum            | 1.91898                      | 7.11348                       | 25242.5                                  | 0.559863                         | 0.669835                       | 0.399876           | 1.32636       |
| Sum                | 1439.99909                   | 5026.35531                    | 2051249.178                              | 409.49741                        | 526.494062                     | 315.001122         | 906.739445    |
| Count              | 900                          | 900                           | 900                                      | 900                              | 900                            | 900                | 900           |
| 75%                | 1.76002                      | 6.35732                       | 1563.53                                  | 0.50755                          | 0.627728                       | 0.37506            | 1.16727       |
| 25%                | 1.44001                      | 4.82043                       | 6.03474                                  | 0.402594                         | 0.542583                       | 0.325115           | 0.848089      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g

Area: 2000.00 square meters  
 Thickness: 1.00 meters  
 Cover Depth: 0.00 meters

Sr-90 1.000E+00

Total Dose TDOSE(t), mrem/yr

Basic Radiation Dose Limit = 4.000E+00 mrem/yr

Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)

t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 6.353E+00 5.887E+00 4.511E+00 1.743E+00 2.190E-02 7.250E-05 1.834E-16 0.000E+00  
 M(t): 0.000E+00 1.588E+00 1.472E+00 1.128E+00 4.356E-01 5.476E-03 1.813E-05 4.586E-17 0.000E+00

Maximum TDOSE(t): 6.545E+00 mrem/yr at t = 0.2164 ± 0.0004 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)

As mrem/yr and Fraction of Total Dose At t = 2.164E-01 years

Water Independent Pathways (Inhalation excludes radon)

| Radio-Nuclide | Ground    |        | Inhalation |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | Soil      |        |
|---------------|-----------|--------|------------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|
|               | mrem/yr   | fract. | mrem/yr    | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. |
| Sr-90         | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total         | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)

As mrem/yr and Fraction of Total Dose At t = 2.164E-01 years

Water Dependent Pathways

| Radio-Nuclide | Water     |        | Fish      |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | All Pathways* |        |
|---------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
|               | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       | fract. |
| Sr-90         | 6.545E+00 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 6.545E+00     | 1.0000 |
| Total         | 6.545E+00 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 6.545E+00     | 1.0000 |

\*Sum of all water independent and dependent pathways.

|                    | Contaminated Zone<br>Erosion Rate | Evapotranspiration<br>Coefficient | Runoff<br>Coefficient | Density of<br>Unsaturated Zone | Effective Porosity of<br>Unsaturated Zone | Total Porosity of<br>Unsaturated Zone | Precipitation |
|--------------------|-----------------------------------|-----------------------------------|-----------------------|--------------------------------|---|---------------------------------------|---------------|
| Mean               | 0.000268837                       | 0.584991104                       | 0.350005479           | 1.599991267                    | 0.409989919                               | 0.455002578                           | 1.007488272   |
| Standard Error     | 4.77281E-06                       | 0.001636747                       | 0.00096273            | 0.006161712                    | 0.002503686                               | 0.002021635                           | 0.006153245   |
| Median             | 0.000232533                       | 0.585038                          | 0.350015              | 1.60075                        | 0.409732                                  | 0.4548075                             | 1.007535      |
| Mode               | 0.00029171                        | 0.573988                          | 0.349318              | 1.86433                        | #N/A                                      | 0.544867                              | 1.30224       |
| Standard Deviation | 0.000143184                       | 0.049102425                       | 0.028881898           | 0.184851368                    | 0.075110588                               | 0.060649047                           | 0.184597359   |
| Sample Variance    | 2.05018E-08                       | 0.002411048                       | 0.000834164           | 0.034170028                    | 0.0056416                                 | 0.003678307                           | 0.034076185   |
| Kurtosis           | -0.746746422                      | -1.199417592                      | -1.199576162          | -1.199980454                   | -1.200826746                              | -1.200016993                          | -1.199911705  |
| Skewness           | 0.642587388                       | 4.72965E-05                       | 0.000215723           | -0.000536939                   | 0.000534848                               | -6.72923E-05                          | 8.59276E-06   |
| Range              | 0.000507779                       | 0.169557                          | 0.099847              | 0.63936                        | 0.259519                                  | 0.209435                              | 0.637726      |
| Minimum            | 0.000090411                       | 0.500082                          | 0.300097              | 1.28022                        | 0.280228                                  | 0.350306                              | 0.688634      |
| Maximum            | 0.00059819                        | 0.669639                          | 0.399944              | 1.91958                        | 0.539747                                  | 0.559741                              | 1.32636       |
| Sum                | 0.241952968                       | 526.491994                        | 315.004931            | 1439.99214                     | 368.990927                                | 409.50232                             | 906.739445    |
| Count              | 900                               | 900                               | 900                   | 900                            | 900                                       | 900                                   | 900           |
| 75%                | 3.73E-04                          | 6.28E-01                          | 3.75E-01              | 1.76E+00                       | 4.75E-01                                  | 5.08E-01                              | 1.17E+00      |
| 25%                | 1.45E-04                          | 5.43E-01                          | 3.25E-01              | 1.44E+00                       | 3.45E-01                                  | 4.03E-01                              | 8.48E-01      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g

Area: 2000.00 square meters  
 Thickness: 1.00 meters  
 Cover Depth: 0.00 meters

Cs-137 1.000E+00

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)

t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 8.897E-03 4.959E-03 3.369E-04 1.009E-05 7.776E-13 0.000E+00  
 M(t): 0.000E+00 0.000E+00 0.000E+00 2.224E-03 1.240E-03 8.422E-05 2.523E-06 1.944E-13 0.000E+00  
 Maximum TDOSE(t): 1.006E-02 mrem/yr at t = 4.766 ± 0.010 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 4.766E+00 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground    |        | Inhalation |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | Soil      |        |
|-------------------|-----------|--------|------------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|
|                   | mrem/yr   | fract. | mrem/yr    | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. |
| Cs-137            | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total             | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 4.766E+00 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water     |        | Fish      |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | All Pathways* |        |
|-------------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
|                   | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       | fract. |
| Cs-137            | 1.006E-02 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 1.006E-02     | 1.0000 |
| Total             | 1.006E-02 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 1.006E-02     | 1.0000 |

\*Sum of all water independent and dependent pathways.  
 ORESALC.EXE execution time = 1.22 seconds

|                    | Contaminated Zone<br>Erosion Rate | Evapotranspiration<br>Coefficient | Runoff Coefficient | Density of<br>Unsaturated<br>Zone | Effective Porosity<br>of Unsaturated<br>Zone | Total Porosity of<br>Unsaturated Zone | Precipitation |
|--------------------|-----------------------------------|-----------------------------------|--------------------|-----------------------------------|--|---------------------------------------|---------------|
| Mean               | 0.000268837                       | 0.584991104                       | 0.350005479        | 1.599991267                       | 0.409989919                                  | 0.455002578                           | 1.007488272   |
| Standard Error     | 4.77281E-06                       | 0.001636747                       | 0.00096273         | 0.006161712                       | 0.002503686                                  | 0.002021635                           | 0.006153245   |
| Median             | 0.000232533                       | 0.585038                          | 0.350015           | 1.60075                           | 0.409732                                     | 0.4548075                             | 1.007535      |
| Mode               | 0.00029171                        | 0.573988                          | 0.349318           | 1.86433                           | #N/A   | 0.544867                              | 1.30224       |
| Standard Deviation | 0.000143184                       | 0.049102425                       | 0.028881898        | 0.184851368                       | 0.075110588                                  | 0.060649047                           | 0.184597359   |
| Sample Variance    | 2.05018E-08                       | 0.002411048                       | 0.000834164        | 0.034170028                       | 0.0056416                                    | 0.003678307                           | 0.034076185   |
| Kurtosis           | -0.746746422                      | -1.199417592                      | -1.199576162       | -1.199980454                      | -1.200826746                                 | -1.200016993                          | -1.199911705  |
| Skewness           | 0.642587388                       | 4.72965E-05                       | 0.000215723        | -0.000536939                      | 0.000534848                                  | -6.72923E-05                          | 8.59276E-06   |
| Range              | 0.000507779                       | 0.169557                          | 0.099847           | 0.63936                           | 0.259519                                     | 0.209435                              | 0.637726      |
| Minimum            | 0.000090411                       | 0.500082                          | 0.300097           | 1.28022                           | 0.280228                                     | 0.350306                              | 0.688634      |
| Maximum            | 0.00059819                        | 0.669639                          | 0.399944           | 1.91958                           | 0.539747                                     | 0.559741                              | 1.32636       |
| Sum                | 0.241952968                       | 526.491994                        | 315.004931         | 1439.99214                        | 368.990927                                   | 409.50232                             | 906.739445    |
| Count              | 900                               | 900                               | 900                | 900                               | 900  | 900                                   | 900           |
| 75%                | 3.73E-04                          | 6.28E-01                          | 3.75E-01           | 1.76E+00                          | 4.75E-01                                     | 5.08E-01                              | 1.17E+00      |
| 25%                | 1.45E-04                          | 5.43E-01                          | 3.25E-01           | 1.44E+00                          | 3.45E-01                                     | 4.03E-01                              | 8.48E-01      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g

Area: 2000.00 square meters  
 Thickness: 1.00 meters  
 Cover Depth: 0.00 meters

Eu-152 1.000E+00

0  
 Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 2.651E-03 1.837E-03 4.953E-04 1.192E-06 4.579E-10 1.957E-15 0.000E+00  
 M(t): 0.000E+00 0.000E+00 6.628E-04 4.592E-04 1.238E-04 2.980E-07 1.145E-10 4.892E-16 0.000E+00  
 Maximum TDOSE(t): 2.772E-03 mrem/yr at t = 2.282 ± 0.005 years

0  
 Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 2.282E+00 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-Nuclide | Ground    |        | Inhalation |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | Soil      |        |
|---------------|-----------|--------|------------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|
|               | mrem/yr   | fract. | mrem/yr    | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. |
| Eu-152        | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total         | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

0  
 Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 2.282E+00 years  
 Water Dependent Pathways

| Radio-Nuclide | Water     |        | Fish      |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | All Pathways* |        |
|---------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
|               | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       | fract. |
| Eu-152        | 2.772E-03 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 2.772E-03     | 1.0000 |
| Total         | 2.772E-03 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 2.772E-03     | 1.0000 |

0\*Sum of all water independent and dependent pathways.



|                    | Density of Contaminated Zone | Contaminated Zone B Parameter | Contaminated Zone Erosion Rate | Contaminated Zone Hydraulic Conductivity | Evapotranspiration Coefficient | Runoff Coefficient | Precipitation |
|--------------------|------------------------------|-------------------------------|--------------------------------|--|--------------------------------|--------------------|---------------|
| Mean               | 1.599998989                  | 5.584839233                   | 0.000268854                    | 2274.417426                              | 0.584993402                    | 0.350001247        | 1.007488272   |
| Standard Error     | 0.006162766                  | 0.029557717                   | 4.77325E-06                    | 162.3194427                              | 0.001637026                    | 0.000962683        | 0.006153245   |
| Median             | 1.60022                      | 5.585685                      | 0.000232446                    | 97.16735                                 | 0.5848245                      | 0.3499085          | 1.007535      |
| Mode               | 1.60771                      | 5.38614                       | 0.000132053                    | #N/A                                     | #N/A                           | 0.392794           | 1.30224       |
| Standard Deviation | 0.184882993                  | 0.886731513                   | 0.000143198                    | 4869.583281                              | 0.04911078                     | 0.028880485        | 0.184597359   |
| Sample Variance    | 0.034181721                  | 0.786292776                   | 2.05055E-08                    | 23712841.33                              | 0.002411869                    | 0.000834082        | 0.034076185   |
| Kurtosis           | -1.200468675                 | -1.199418707                  | -0.742935775                   | 7.154808843                              | -1.200825834                   | -1.200018055       | -1.199911705  |
| Skewness           | -0.000346662                 | 4.63389E-05                   | 0.644011983                    | 2.736251306                              | 0.00053554                     | -6.73476E-05       | 8.59276E-06   |
| Range              | 0.63744                      | 3.062                         | 0.000509199                    | 25215.63658                              | 0.169686                       | 0.09973            | 0.637726      |
| Minimum            | 1.28154                      | 4.05148                       | 9.01667E-05                    | 0.36342                                  | 0.500149                       | 0.300146           | 0.688634      |
| Maximum            | 1.91898                      | 7.11348                       | 0.000599366                    | 25216                                    | 0.669835                       | 0.399876           | 1.32636       |
| Sum                | 1439.99909                   | 5026.35531                    | 0.241968634                    | 2046975.684                              | 526.494062                     | 315.001122         | 906.739445    |
| Count              | 900                          | 900                           | 900                            | 900                                      | 900                            | 900                | 900           |
| 75%                | 1.76002                      | 6.35732                       | 0.000373517                    | 1564.77                                  | 0.627728                       | 0.37506            | 1.16727       |
| 25%                | 1.44001                      | 4.82043                       | 0.000145208                    | 5.92129                                  | 0.542583                       | 0.325115           | 0.848089      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g

Area: 2000.00 square meters  
 Thickness: 1.00 meters  
 Cover Depth: 0.00 meters

Pu-238 1.000E+00

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)

t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 9.486E+00 9.317E+00 8.747E+00 6.984E+00 2.478E+00 6.413E-01 1.159E-03 0.000E+00  
 M(t): 0.000E+00 2.372E+00 2.329E+00 2.187E+00 1.746E+00 6.195E-01 1.603E-01 2.897E-04 0.000E+00

Maximum TDOSE(t): 9.486E+00 mrem/yr at t = 0.999 ± 0.002 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)

As mrem/yr and Fraction of Total Dose At t = 9.988E-01 years

Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide<br>Nuclide | Ground    |        | Inhalation |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | Soil      |        |
|------------------------------|-----------|--------|------------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|
|                              | mrem/yr   | fract. | mrem/yr    | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. |
| Pu-238                       | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total                        | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)

As mrem/yr and Fraction of Total Dose At t = 9.988E-01 years

Water Dependent Pathways

| Radio-<br>Nuclide<br>Nuclide | Water     |        | Fish      |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | All Pathways* |        |
|------------------------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
|                              | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       | fract. |
| Pu-238                       | 9.486E+00 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 9.486E+00     | 1.0000 |
| Total                        | 9.486E+00 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 9.486E+00     | 1.0000 |

\*Sum of all water independent and dependent pathways.

ORESCALC.EXE execution time = 3.49 seconds

|                    | Density of Contaminated Zone | Contaminated Zone b Parameter | Contaminated Zone Erosion Rate | Contaminated Zone Hydraulic Conductivity | Contaminated Zone Total Porosity | Evapotranspiration Coefficient | Runoff Coefficient | Effective Porosity of Unsaturated Zone | Precipitation |
|--------------------|------------------------------|-------------------------------|--------------------------------|--|----------------------------------|--------------------------------|--------------------|--|---------------|
| Mean               | 1.599994367                  | 5.585002411                   | 0.000268857                    | 2276.496896                              | 0.455012184                      | 0.58500639                     | 0.350003462        | 0.40999103                             | 1.007480358   |
| Standard Error     | 0.006162667                  | 0.029559245                   | 4.77346E-06                    | 162.4249002                              | 0.002021821                      | 0.001636722                    | 0.000962891        | 0.002503333                            | 0.006152832   |
| Median             | 1.599935                     | 5.58379                       | 0.000232267                    | 97.147                                   | 0.4549935                        | 0.585066                       | 0.350074           | 0.409868                               | 1.00774       |
| Mode               | 1.58491                      | 4.71008                       | #N/A                           | 6988.62                                  | #N/A                             | 0.548114                       | 0.375003           | #N/A                                   | 1.03602       |
| Standard Deviation | 0.184880004                  | 0.886777355                   | 0.000143204                    | 4872.747006                              | 0.060654632                      | 0.049101652                    | 0.028886716        | 0.075099979                            | 0.184584959   |
| Sample Variance    | 0.034180616                  | 0.786374078                   | 2.05073E-08                    | 23743663.38                              | 0.003678984                      | 0.002410972                    | 0.000834442        | 0.005640007                            | 0.034071607   |
| Kurtosis           | -1.200119059                 | -1.199864756                  | -0.743648267                   | 7.137040803                              | -1.200703951                     | -1.20038223                    | -1.200129046       | -1.199894282                           | -1.199766018  |
| Skewness           | 0.000354623                  | 1.0021E-05                    | 0.643870607                    | 2.734708529                              | 0.000365453                      | -0.00020634                    | -0.000413371       | -0.000421301                           | -0.000365207  |
| Range              | 0.6384                       | 3.06576                       | 0.000508388                    | 24887.23407                              | 0.20983                          | 0.16959                        | 0.099808           | 0.259775                               | 0.638573      |
| Minimum            | 1.28046                      | 4.05148                       | 9.01349E-05                    | 0.365927                                 | 0.350001                         | 0.500158                       | 0.360099           | 0.280013                               | 0.688027      |
| Maximum            | 1.91886                      | 7.11724                       | 0.000598523                    | 24887.6                                  | 0.559831                         | 0.669748                       | 0.399907           | 0.539788                               | 1.3266        |
| Sum                | 1439.99493                   | 5026.50217                    | 0.241971669                    | 2048847.206                              | 409.510966                       | 526.505751                     | 315.003116         | 368.991927                             | 906.732322    |
| Count              | 900                          | 900                           | 900                            | 900                                      | 900                              | 900                            | 900                | 900                                    | 900           |
| 75%                | 1.76106                      | 6.35567                       | 0.000373669                    | 1577.81                                  | 0.507553                         | 0.627601                       | 0.375003           | 0.475319                               | 1.16879       |
| 25%                | 1.44001                      | 4.82136                       | 0.00014482                     | 5.92129                                  | 0.402603                         | 0.542695                       | 0.325061           | 0.345218                               | 0.848921      |

Contaminated Zone Dimensions

Area: 2000.00 square meters  
 Thickness: 1.00 meters  
 Cover Depth: 0.00 meters

Initial Soil Concentrations, pCi/g

Pu-239 1.000E+00

0  
 Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 2.470E+00 1.056E+01 1.047E+01 1.018E+01 8.926E+02 7.520E+00 3.355E+00 0.000E+00  
 M(t): 0.000E+00 6.176E-01 2.639E+00 2.618E+00 2.544E+00 2.231E+00 1.880E+00 8.387E-01 0.000E+00  
 0 Maximum TDOSE(t): 1.065E+01 mrem/yr at t = 1.093 ± 0.002 years

0  
 Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.093E+00 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-Nuclide | Ground    |        | Inhalation |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | Soil      |        |
|---------------|-----------|--------|------------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|
|               | mrem/yr   | fract. | mrem/yr    | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. |
| Pu-239        | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total         | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

0  
 Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.093E+00 years  
 Water Dependent Pathways

| Radio-Nuclide | Water     |        | Fish      |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | All Pathways* |        |
|---------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
|               | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       | fract. |
| Pu-239        | 1.065E+01 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 1.065E+01     | 1.0000 |
| Total         | 1.065E+01 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 1.065E+01     | 1.0000 |

0\*Sum of all water independent and dependent pathways.  
 0 RESCALC.EXE execution time = 2.03 seconds

|                    | Contaminated Zone                 |                           |                                   |                       |                                |   |                                       |               |
|--------------------|-----------------------------------|---------------------------|-----------------------------------|-----------------------|--------------------------------|---|---------------------------------------|---------------|
|                    | Contaminated Zone<br>Erosion Rate | Hydraulic<br>Conductivity | Evapotranspiration<br>Coefficient | Runoff<br>Coefficient | Density of<br>Unsaturated Zone | Effective Porosity of<br>Unsaturated Zone | Total Porosity of<br>Unsaturated Zone | Precipitation |
| Mean               | 0.000268808                       | 2273.909692               | 0.585005496                       | 0.350000028           | 1.600012244                    | 0.410006522                               | 0.455008379                           | 1.007501901   |
| Standard Error     | 4.77306E-06                       | 162.1524557               | 0.001636863                       | 0.000962736           | 0.006162287                    | 0.002503226                               | 0.002021753                           | 0.006151779   |
| Median             | 0.000232647                       | 96.42905                  | 0.5849275                         | 0.350001              | 1.59957                        | 0.4100965                                 | 0.4550805                             | 1.00773       |
| Mode               | #N/A                              | #N/A                      | 0.565466                          | 0.378622              | 1.60064                        | 0.422049                                  | #N/A                                  | 1.31383       |
| Standard Deviation | 0.000143192                       | 4864.573672               | 0.049105883                       | 0.028882065           | 0.184868623                    | 0.075096787                               | 0.060652604                           | 0.184553372   |
| Sample Variance    | 2.05039E-08                       | 23664077.01               | 0.002411388                       | 0.000834174           | 0.034176408                    | 0.005639527                               | 0.003678738                           | 0.034059947   |
| Kurtosis           | -0.744097135                      | 7.084605376               | -1.20010564                       | -1.19996081           | -1.200302968                   | -1.200686978                              | -1.200503565                          | -1.200385121  |
| Skewness           | 0.643558793                       | 2.728505515               | 0.000137047                       | 0.00025033            | 0.000873747                    | 0.000259907                               | -7.15461E-05                          | 4.61703E-05   |
| Range              | 0.000508049                       | 24804.43605               | 0.169619                          | 0.09984               | 0.63915                        | 0.259522                                  | 0.209693                              | 0.637146      |
| Minimum            | 9.01833E-05                       | 0.36395                   | 0.500166                          | 0.300097              | 1.28079                        | 0.280196                                  | 0.350208                              | 0.689074      |
| Maximum            | 0.000598232                       | 24804.8                   | 0.669785                          | 0.399937              | 1.91994                        | 0.539718                                  | 0.559901                              | 1.32622       |
| Sum                | 0.241927129                       | 2046518.723               | 526.504946                        | 315.000025            | 1440.01102                     | 369.00587                                 | 409.507541                            | 906.751711    |
| Count              | 900                               | 900                       | 900                               | 900                   | 900                            | 900                                       | 900                                   | 900           |
| 75%                | 3.75E-04                          | 1.57E+03                  | 6.28E-01                          | 3.75E-01              | 1.76E+00                       | 4.75E-01                                  | 5.08E-01                              | 1.17E+00      |
| 25%                | 1.45E-04                          | 5.89E+00                  | 5.43E-01                          | 3.25E-01              | 1.44E+00                       | 3.45E-01                                  | 4.03E-01                              | 8.48E-01      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g

Area: 2000.00 square meters  
 Thickness: 1.00 meters  
 Cover Depth: 0.00 meters

Pu-241 1.000E+00

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)

|            |           |           |           |           |           |           |           |           |           |
|------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| t (years): | 0.000E+00 | 1.000E+00 | 3.000E+00 | 1.000E+01 | 3.500E+01 | 1.500E+02 | 3.000E+02 | 1.000E+03 | 1.000E+04 |
| TDOSE(t):  | 0.000E+00 | 1.974E-01 | 1.847E-01 | 1.464E-01 | 7.981E-02 | 4.301E-02 | 3.164E-02 | 7.568E-03 | 0.000E+00 |
| M(t):      | 0.000E+00 | 4.934E-02 | 4.619E-02 | 3.661E-02 | 1.995E-02 | 1.075E-02 | 7.910E-03 | 1.892E-03 | 0.000E+00 |

Maximum TDOSE(t): 2.018E-01 mrem/yr at t = 0.4656 ± 0.0009 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 4.656E-01 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground    |        | Inhalation |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | Soil      |        |
|-------------------|-----------|--------|------------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|
|                   | mrem/yr   | fract. | mrem/yr    | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. |
| Pu-241            | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total             | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 4.656E-01 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water     |        | Fish      |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | All Pathways* |        |
|-------------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
|                   | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       | fract. |
| Pu-241            | 2.018E-01 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 2.018E-01     | 1.0000 |
| Total             | 2.018E-01 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 2.018E-01     | 1.0000 |

\*Sum of all water independent and dependent pathways.

|                    | Contaminated Zone<br>Erosion Rate | Evapotranspiration<br>Coefficient | Runoff<br>Coefficient | Effective Porosity of<br>Unsaturated Zone | Total Porosity<br>of Unsaturated<br>Zone | Precipitation |
|--------------------|-----------------------------------|-----------------------------------|-----------------------|---|--|---------------|
| Mean               | 0.000268823                       | 0.585002026                       | 0.350005549           | 0.409989978                               | 0.454997262                              | 1.007493339   |
| Standard Error     | 4.77282E-06                       | 0.001636754                       | 0.000962867           | 0.002503478                               | 0.00202202                               | 0.006151524   |
| Median             | 0.00023239                        | 0.585011                          | 0.350123              | 0.4100055                                 | 0.455016                                 | 1.007715      |
| Mode               | #N/A                              | 0.624546                          | 0.387499              | #N/A                                      | 0.402603                                 | 1.20429       |
| Standard Deviation | 0.000143185                       | 0.049102612                       | 0.028886              | 0.075104344                               | 0.060660615                              | 0.184545716   |
| Sample Variance    | 2.05018E-08                       | 0.002411067                       | 0.000834401           | 0.005640662                               | 0.00367971                               | 0.034057121   |
| Kurtosis           | -0.744580078                      | -1.199466682                      | -1.19991697           | -1.199464141                              | -1.200587674                             | -1.199877082  |
| Skewness           | 0.643528202                       | -0.000216204                      | -0.000521509          | -0.000162075                              | 0.000183047                              | -1.03853E-05  |
| Range              | 0.000508856                       | 0.16976                           | 0.099859              | 0.259744                                  | 0.209654                                 | 0.637617      |
| Minimum            | 9.00343E-05                       | 0.500082                          | 0.300097              | 0.280251                                  | 0.350259                                 | 0.688933      |
| Maximum            | 0.00059889                        | 0.669842                          | 0.399956              | 0.539995                                  | 0.559913                                 | 1.32655       |
| Sum                | 0.241940998                       | 526.501823                        | 315.004994            | 368.99098                                 | 409.497536                               | 906.744005    |
| Count              | 900                               | 900                               | 900                   | 900                                       | 900                                      | 900           |
| 75%                | 3.74E-04                          | 6.28E-01                          | 3.75E-01              | 4.75E-01                                  | 5.08E-01                                 | 1.17E+00      |
| 25%                | 1.45E-04                          | 5.43E-01                          | 3.25E-01              | 3.45E-01                                  | 4.03E-01                                 | 8.48E-01      |

Contaminated Zone Dimensions

Initial Soil Concentrations, pCi/g

Area: 2000.00 square meters  
 Thickness: 1.00 meters  
 Cover Depth: 0.00 meters

Am-241 1.000E+00

Total Dose TDOSE(t), mrem/yr

Basic Radiation Dose Limit = 4.000E+00 mrem/yr

Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)

t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 9.554E-12 4.175E-06 1.712E+00 1.632E+00 1.309E+00 9.812E-01 2.540E-01 0.000E+00  
 M(t): 0.000E+00 2.389E-12 1.044E-06 4.280E-01 4.080E-01 3.272E-01 2.453E-01 6.350E-02 0.000E+00  
 Maximum TDOSE(t): 1.730E+00 mrem/yr at t = 7.07 ± 0.01 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)

As mrem/yr and Fraction of Total Dose At t = 7.070E+00 years

Water Independent Pathways (Inhalation excludes radon)

| Radio-Nuclide | Ground    |        | Inhalation |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | Soil      |        |
|---------------|-----------|--------|------------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|
|               | mrem/yr   | fract. | mrem/yr    | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. |
| Am-241        | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total         | 0.000E+00 | 0.0000 | 0.000E+00  | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)

As mrem/yr and Fraction of Total Dose At t = 7.070E+00 years

Water Dependent Pathways

| Radio-Nuclide | Water     |        | Fish      |        | Radon     |        | Plant     |        | Meat      |        | Milk      |        | All Pathways* |        |
|---------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
|               | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       | fract. |
| Am-241        | 1.730E+00 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 1.730E+00     | 1.0000 |
| Total         | 1.730E+00 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 1.730E+00     | 1.0000 |

\*Sum of all water independent and dependent pathways.



|                    | Density of Contaminated Zone | Contaminated Zone b Parameter | Contaminated Zone Hydraulic Conductivity | Evapotranspiration Coefficient | Runoff Coefficient | Effective Porosity of Unsaturated Zone | Total Porosity of Unsaturated Zone | Precipitation | Plant Transfer Factor for Np |
|--------------------|------------------------------|-------------------------------|--|--------------------------------|--------------------|--|------------------------------------|---------------|------------------------------|
| Mean               | 1.599994367                  | 5.585002411                   | 219.9011614                              | 0.585010094                    | 0.350005806        | 0.410009789                            | 0.455007262                        | 1.007477948   | 0.030388272                  |
| Standard Error     | 0.006162667                  | 0.029559245                   | 7.707980835                              | 0.00163666                     | 0.000962772        | 0.002503221                            | 0.00202207                         | 0.006152422   | 0.001124475                  |
| Median             | 1.599935                     | 5.58379                       | 118.955                                  | 0.585196                       | 0.3499965          | 0.4101005                              | 0.455156                           | 1.007175      | 0.0200578                    |
| Mode               | 1.58491                      | 4.71008                       | #N/A                                     | 0.647449                       | #N/A               | 0.353586                               | 0.391116                           | 1.1521        | #N/A                         |
| Standard Deviation | 0.184880004                  | 0.886777355                   | 231.2394251                              | 0.049099809                    | 0.028883145        | 0.075096645                            | 0.060662103                        | 0.184572654   | 0.033734236                  |
| Sample Variance    | 0.034180616                  | 0.786374078                   | 53471.6717                               | 0.002410791                    | 0.000834236        | 0.005639506                            | 0.003679891                        | 0.034067064   | 0.001137999                  |
| Kurtosis           | -1.200119059                 | -1.199864756                  | 0.63825005                               | -1.200395077                   | -1.200704725       | -1.200383095                           | -1.200129568                       | -1.199892558  | 23.06462523                  |
| Skewness           | 0.000354623                  | 1.0021E-05                    | 1.290141998                              | -2.29934E-05                   | 0.000367082        | -0.000206286                           | -0.000413796                       | -0.00042048   | 3.732161591                  |
| Range              | 0.6384                       | 3.06576                       | 889.0969                                 | 0.169526                       | 0.099919           | 0.259373                               | 0.209596                           | 0.638449      | 0.383685247                  |
| Minimum            | 1.28046                      | 4.05148                       | 15.6401                                  | 0.500164                       | 0.300001           | 0.280242                               | 0.350208                           | 0.688031      | 0.000545753                  |
| Maximum            | 1.91886                      | 7.11724                       | 904.737                                  | 0.66969                        | 0.39992            | 0.539615                               | 0.559804                           | 1.32648       | 0.384231                     |
| Sum                | 1439.99493                   | 5026.50217                    | 197911.0453                              | 526.509085                     | 315.005225         | 369.00881                              | 409.506536                         | 906.730153    | 27.34944514                  |
| Count              | 900                          | 900                           | 900                                      | 900                            | 900                | 900                                    | 900                                | 900           | 900                          |
| 75%                | 1.76106                      | 6.35567                       | 329.605                                  | 0.627667                       | 0.375025           | 0.475155                               | 0.507506                           | 1.16803       | 0.0374402                    |
| 25%                | 1.44001                      | 4.82136                       | 43.2158                                  | 0.542576                       | 0.325049           | 0.345298                               | 0.402628                           | 0.848285      | 0.010859                     |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 10000.00 square meters Am-241 1.000E+00  
 Thickness: 2.00 meters  
 Cover Depth: 3.20 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 5.540E-12 7.842E-06 1.713E+00 1.643E+00 1.355E+00 1.053E+00 3.260E-01 3.735E-05  
 TDOSE(t): 0.000E+00 1.385E-12 1.960E-06 4.284E-01 4.108E-01 3.387E-01 2.633E-01 8.149E-02 9.338E-06  
 M(t): 0.000E+00 1.385E-12 1.960E-06 4.284E-01 4.108E-01 3.387E-01 2.633E-01 8.149E-02 9.338E-06  
 Maximum TDOSE(t): 1.731E+00 mrem/yr at t = 7.07E+00 years

Total Dose Contributions TDOSE(1,p,t) for Individual Radionuclides (1) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 7.070E+00 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground    | Inhalation | Radon     | Plant     | Meat      | Milk      | Soil      |
|-------------------|-----------|------------|-----------|-----------|-----------|-----------|-----------|
| Nuclide           | mrem/yr   | mrem/yr    | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   |
| Nuclide           | fract.    | fract.     | fract.    | fract.    | fract.    | fract.    | fract.    |
| Am-241            | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Total             | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

Total Dose Contributions TDOSE(1,p,t) for Individual Radionuclides (1) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 7.070E+00 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water     | Fish      | Radon     | Plant     | Meat      | Milk      | All Pathways* |
|-------------------|-----------|-----------|-----------|-----------|-----------|-----------|---------------|
| Nuclide           | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr       |
| Nuclide           | fract.    | fract.    | fract.    | fract.    | fract.    | fract.    | fract.        |
| Am-241            | 1.731E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.731E+00     |
| Total             | 1.731E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.731E+00     |

\*Sum of all water independent and dependent pathways.

|                    | Density of Contaminated Zone | Contaminated Zone B Parameter | Contaminated Zone Hydraulic Conductivity | Evapotranspiration Coefficient | Precipitation | Kd of C-14 in Contaminated Zone | Kd of C-14 in Unsaturated Zone 1 |
|--------------------|------------------------------|-------------------------------|--|--------------------------------|---------------|---------------------------------|----------------------------------|
| Mean               | 1.599998989                  | 5.584839233                   | 219.8917289                              | 0.584997673                    | 1.00747517    | 2.500061969                     | 2.499909269                      |
| Standard Error     | 0.006162766                  | 0.029557717                   | 7.707887415                              | 0.001636706                    | 0.006153291   | 0.048134153                     | 0.048147501                      |
| Median             | 1.60022                      | 5.585685                      | 119.152                                  | 0.5851995                      | 1.00684       | 2.495425                        | 2.500285                         |
| Mode               | 1.60771                      | 5.38614                       | #N/A                                     | #N/A                           | #N/A          | 4.63969                         | #N/A                             |
| Standard Deviation | 0.184882993                  | 0.886731513                   | 231.2366225                              | 0.049101186                    | 0.184598739   | 1.444024596                     | 1.444425026                      |
| Sample Variance    | 0.034181721                  | 0.786292776                   | 53470.37556                              | 0.002410927                    | 0.034076695   | 2.085207034                     | 2.086363655                      |
| Kurtosis           | -1.200468675                 | -1.199418707                  | 0.640033425                              | -1.199981276                   | -1.200825629  | -1.200018526                    | -1.199911876                     |
| Skewness           | -0.000346662                 | 4.63389E-05                   | 1.29063247                               | -0.000539701                   | 0.000535489   | -6.76913E-05                    | 9.60404E-06                      |
| Range              | 0.63744                      | 3.062                         | 891.8191                                 | 0.169829                       | 0.637819      | 4.98652271                      | 4.99000738                       |
| Minimum            | 1.28154                      | 4.05148                       | 15.6519                                  | 0.50006                        | 0.688561      | 0.00729729                      | 0.00496262                       |
| Maximum            | 1.91898                      | 7.11348                       | 907.471                                  | 0.669889                       | 1.32638       | 4.99382                         | 4.99497                          |
| Sum                | 1439.99909                   | 5026.35531                    | 197902.556                               | 526.497906                     | 906.727653    | 2250.055772                     | 2249.918342                      |
| Count              | 900                          | 900                           | 900                                      | 900                            | 900           | 900                             | 900                              |
| Largest(1)         | 1.91898                      | 7.11348                       | 907.471                                  | 0.669889                       | 1.32638       | 4.99382                         | 4.99497                          |
| Smallest(1)        | 1.28154                      | 4.05148                       | 15.6519                                  | 0.50006                        | 0.688561      | 0.00729729                      | 0.00496262                       |
| 75%                | 1.76002                      | 6.35732                       | 329.319                                  | 0.62754                        | 1.16811       | 3.75298                         | 3.75014                          |
| 25%                | 1.44001                      | 4.82043                       | 43.4646                                  | 0.542576                       | 0.848063      | 1.25574                         | 1.25265                          |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 10000.00 square meters C-14 1.000E+00  
 Thickness: 2.00 meters  
 Cover Depth: 3.20 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 6.904E-01 6.147E-01 4.095E-01 9.599E-02 1.213E-04 2.012E-08 4.593E-26 0.000E+00  
 M(t): 0.000E+00 1.726E-01 1.537E-01 1.024E-01 2.400E-02 3.033E-05 5.030E-09 1.148E-26 0.000E+00  
 Maximum TDOSE(t): 7.309E-01 mrem/yr at t = 0.1393 in 0.0003 years

Total Dose Contributions TDOSE(l,p,t) for Individual Radionuclides (l) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.393E-01 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground<br>mrem/yr<br>fract. | Inhalation<br>mrem/yr<br>fract. | Radon<br>mrem/yr<br>fract. | Plant<br>mrem/yr<br>fract. | Meat<br>mrem/yr<br>fract. | Milk<br>mrem/yr<br>fract. | Soil<br>mrem/yr<br>fract. |
|-------------------|-----------------------------|---------------------------------|----------------------------|----------------------------|---------------------------|---------------------------|---------------------------|
| C-14              | 0.000E+00                   | 0.000E+00                       | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 0.000E+00                 |
| Total             | 0.000E+00                   | 0.000E+00                       | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 0.000E+00                 |

Total Dose Contributions TDOSE(l,p,t) for Individual Radionuclides (l) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.393E-01 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water<br>mrem/yr<br>fract. | Fish<br>mrem/yr<br>fract. | Radon<br>mrem/yr<br>fract. | Plant<br>mrem/yr<br>fract. | Meat<br>mrem/yr<br>fract. | Milk<br>mrem/yr<br>fract. | All Pathways*<br>mrem/yr<br>fract. |
|-------------------|----------------------------|---------------------------|----------------------------|----------------------------|---------------------------|---------------------------|------------------------------------|
| C-14              | 7.309E-01                  | 0.000E+00                 | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 7.309E-01                          |
| Total             | 7.309E-01                  | 0.000E+00                 | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 7.309E-01                          |

\*Sum of all water independent and dependent pathways.

|                    | Contaminated<br>Zone B Parameter | Contaminated Zone<br>Hydraulic Conductivity | Evapotranspiration<br>Coefficient | Runoff Coefficient | Density of<br>Unsaturated Zone | Effective Porosity of<br>Unsaturated Zone | total Porosity of<br>Unsaturated Zone | Precipitation |
|--------------------|----------------------------------|---|-----------------------------------|--------------------|--------------------------------|---|---------------------------------------|---------------|
| Mean               | 5 584797211                      | 219 8155057                                 | 0 585005496                       | 0 350000028        | 1 600012244                    | 0 410006522                               | 0 455008379                           | 1.007501901   |
| Standard Error     | 0 029562333                      | 7 700788063                                 | 0 001636863                       | 0 000962736        | 0 006162287                    | 0 002503226                               | 0 002021753                           | 0 006151779   |
| Median             | 5 58686                          | 119 3195                                    | 0 5849275                         | 0 350001           | 1 59957                        | 0 4100965                                 | 0 4550805                             | 1.00773       |
| Mode               | #N/A                             | 22 1526                                     | 0 565466                          | 0 378622           | 1 60064                        | 0 422049                                  | #N/A                                  | 1.31383       |
| Standard Deviation | 0 886869987                      | 231 0236419                                 | 0 049105883                       | 0 028882065        | 0 184868623                    | 0 075096787                               | 0 060652604                           | 0 184553372   |
| Sample Variance    | 0 786538375                      | 53371 92311                                 | 0 002411388                       | 0 000834174        | 0 034176408                    | 0 005639527                               | 0 003678738                           | 0 034059947   |
| Kurtosis           | -1 200185027                     | 0 628501485                                 | -1 20010564                       | -1 199960807       | -1 200302968                   | -1 200686978                              | -1 200503565                          | -1 200385121  |
| Skewness           | 0 000105678                      | 1 287798565                                 | 0 000137047                       | 0 00025033         | 0 000873747                    | 0 000259907                               | -7.15461E-05                          | 4 61703E-05   |
| Range              | 3 06193                          | 886 0844                                    | 0 169619                          | 0 09984            | 0 63915                        | 0 259522                                  | 0 209693                              | 0 637146      |
| Minimum            | 4 05329                          | 15.6206                                     | 0 500166                          | 0.300097           | 1 28079                        | 0.280196                                  | 0.350208                              | 0 689074      |
| Maximum            | 7.11522                          | 901 705                                     | 0 669785                          | 0 399937           | 1 91994                        | 0 539718                                  | 0 559901                              | 1 32622       |
| Sum                | 5026 31749                       | 197833 9551                                 | 526 504946                        | 315 000025         | 1440 01102                     | 369 00587                                 | 409 507541                            | 906.751711    |
| Count              | 900                              | 900   | 900                               | 900                | 900                            | 900                                       | 900                                   | 900           |
| 75%                | 6 3576                           | 329.535                                     | 0 627564                          | 0 375005           | 1 76066                        | 0 475039                                  | 0.507506                              | 1.16807       |
| 25%                | 4.81755                          | 43 0936                                     | 0 542685                          | 0 325045           | 1.44031                        | 0 345219                                  | 0 402656                              | 0 847987      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 10000.00 square meters Co-60 1.000E+00  
 Thickness: 2.00 meters  
 Cover Depth: 3.20 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 5.638E-02 4.329E-02 1.717E-02 6.322E-04 1.601E-10 3.985E-19 0.000E+00 0.000E+00  
 M(t): 0.000E+00 1.409E-02 1.082E-02 4.293E-03 1.580E-04 4.003E-11 9.962E-20 0.000E+00 0.000E+00  
 Maximum TDOSE(t): 5.944E-02 mrem/yr at t = 0.652 n 0.001 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 6.525E-01 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground<br>mrem/yr<br>fract. | Inhalation<br>mrem/yr<br>fract. | Radon<br>mrem/yr<br>fract. | Plant<br>mrem/yr<br>fract. | Meat<br>mrem/yr<br>fract. | Milk<br>mrem/yr<br>fract. | Soil<br>mrem/yr<br>fract. |
|-------------------|-----------------------------|---------------------------------|----------------------------|----------------------------|---------------------------|---------------------------|---------------------------|
| Co-60             | 0.000E+00                   | 0.000E+00                       | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 0.000E+00                 |
| Total             | 0.000E+00                   | 0.000E+00                       | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 0.000E+00                 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 6.525E-01 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water<br>mrem/yr<br>fract. | Fish<br>mrem/yr<br>fract. | Radon<br>mrem/yr<br>fract. | Plant<br>mrem/yr<br>fract. | Meat<br>mrem/yr<br>fract. | Milk<br>mrem/yr<br>fract. | All Pathways*<br>mrem/yr<br>fract. |
|-------------------|----------------------------|---------------------------|----------------------------|----------------------------|---------------------------|---------------------------|------------------------------------|
| Co-60             | 5.944E-02                  | 0.000E+00                 | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 5.944E-02                          |
| Total             | 5.944E-02                  | 0.000E+00                 | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 5.944E-02                          |

\*Sum of all water independent and dependent pathways.

|                           | Evapotranspiration<br>Coefficient | Runoff Coefficient | Density of<br>Unsaturated Zone | Effective Porosity of<br>Unsaturated Zone | Total Porosity of<br>Unsaturated Zone | Precipitation |
|---------------------------|-----------------------------------|--------------------|--------------------------------|---|---------------------------------------|---------------|
| <b>Mean</b>               | 0.584997016                       | 0.350001207        | 1.600035411                    | 0.409989978                               | 0.454997262                           | 1.007493339   |
| <b>Standard Error</b>     | 0.001636804                       | 0.000962796        | 0.006162343                    | 0.002503478                               | 0.00202202                            | 0.006151524   |
| <b>Median</b>             | 0.585004                          | 0.3500065          | 1.600785                       | 0.4100055                                 | 0.455016                              | 1.007715      |
| <b>Mode</b>               | 0.590284                          | 0.308053           | 1.83999                        | #N/A                                      | 0.402603                              | 1.20429       |
| <b>Standard Deviation</b> | 0.049104121                       | 0.028883867        | 0.184870288                    | 0.075104344                               | 0.060660615                           | 0.184545716   |
| <b>Sample Variance</b>    | 0.002411215                       | 0.000834278        | 0.034177023                    | 0.005640662                               | 0.00367971                            | 0.034057121   |
| <b>Kurtosis</b>           | -1.199773784                      | -1.199466961       | -1.19991514                    | -1.199464141                              | -1.200587674                          | -1.199877082  |
| <b>Skewness</b>           | 3.78472E-05                       | -0.00021806        | -0.00051953                    | -0.000162075                              | 0.000183047                           | -1.03853E-05  |
| <b>Range</b>              | 0.1698                            | 0.099859           | 0.6391                         | 0.259744                                  | 0.209654                              | 0.637617      |
| <b>Minimum</b>            | 0.500034                          | 0.300048           | 1.28062                        | 0.280251                                  | 0.350259                              | 0.688933      |
| <b>Maximum</b>            | 0.669834                          | 0.399907           | 1.91972                        | 0.539995                                  | 0.559913                              | 1.32655       |
| <b>Sum</b>                | 526.497314                        | 315.001086         | 1440.03187                     | 368.99098                                 | 409.497536                            | 906.744005    |
| <b>Count</b>              | 900                               | 900                | 900                            | 900                                       | 900                                   | 900           |
| <b>75%</b>                | 0.627652                          | 0.375048           | 1.76024                        | 0.47525                                   | 0.507515                              | 1.16749       |
| <b>25%</b>                | 0.542503                          | 0.32508            | 1.44014                        | 0.345117                                  | 0.402603                              | 0.847791      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 10000.00 square meters  
 Thickness: 2.00 meters  
 Cover Depth: 3.20 meters  
 Cs-137 1.000E+00

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+01 3.000E+01 1.000E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 8.907E-03 4.991E-03 3.474E-04 1.075E-05 9.708E-13 0.000E+00  
 M(t): 0.000E+00 0.000E+00 0.000E+00 2.227E-03 1.248E-03 8.686E-05 2.688E-06 2.427E-13 0.000E+00  
 Maximum TDOSE(t): 1.005E-02 mrem/yr at t = 4.777 a 0.010 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 4.777E+00 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground           | Inhalation       | Radon            | Plant            | Meat             | Milk             | Soil             |
|-------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
|                   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   |
| Cs-137            | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 |
| Total             | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 4.777E+00 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water            | Fish             | Radon            | Plant            | Meat             | Milk             | All Pathways*    |
|-------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
|                   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   |
| Cs-137            | 1.005E-02 1.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 1.005E-02 1.0000 |
| Total             | 1.005E-02 1.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 1.005E-02 1.0000 |

\*Sum of all water independent and dependent pathways.  
 ORESALC.EXE execution time = 1.04 seconds



|                           | Evapotranspiration Coefficient | Runoff Coefficient | Density of Unsaturated Zone | Effective Porosity of Unsaturated Zone | Total Porosity of Unsaturated Zone | Precipitation |
|---------------------------|--------------------------------|--------------------|-----------------------------|--|------------------------------------|---------------|
| <b>Mean</b>               | 0.584997016                    | 0.350001207        | 1.600035411                 | 0.409989978                            | 0.454997262                        | 1.007493339   |
| <b>Standard Error</b>     | 0.001636804                    | 0.000962796        | 0.006162343                 | 0.002503478                            | 0.00202202                         | 0.006151524   |
| <b>Median</b>             | 0.585004                       | 0.3500065          | 1.600785                    | 0.4100055                              | 0.455016                           | 1.007715      |
| <b>Mode</b>               | 0.590284                       | 0.308053           | 1.83999                     | #N/A                                   | 0.402603                           | 1.20429       |
| <b>Standard Deviation</b> | 0.049104121                    | 0.028883867        | 0.184870288                 | 0.075104344                            | 0.060660615                        | 0.184545716   |
| <b>Sample Variance</b>    | 0.002411215                    | 0.000834278        | 0.034177023                 | 0.005640662                            | 0.00367971                         | 0.034057121   |
| <b>Kurtosis</b>           | -1.199773784                   | -1.199466961       | -1.19991514                 | -1.199464141                           | -1.200587674                       | -1.199877082  |
| <b>Skewness</b>           | 3.78472E-05                    | -0.00021806        | -0.00051953                 | -0.000162075                           | 0.000183047                        | -1.03853E-05  |
| <b>Range</b>              | 0.1698                         | 0.099859           | 0.6391                      | 0.259744                               | 0.209654                           | 0.637617      |
| <b>Minimum</b>            | 0.500034                       | 0.300048           | 1.28062                     | 0.280251                               | 0.350259                           | 0.688933      |
| <b>Maximum</b>            | 0.669834                       | 0.399907           | 1.91972                     | 0.539995                               | 0.559913                           | 1.32655       |
| <b>Sum</b>                | 526.497314                     | 315.001086         | 1440.03187                  | 368.99098                              | 409.497536                         | 906.744005    |
| <b>Count</b>              | 900                            | 900                | 900                         | 900                                    | 900                                | 900           |
| <b>75%</b>                | 0.627652                       | 0.375048           | 1.76024                     | 0.47525                                | 0.507515                           | 1.16749       |
| <b>25%</b>                | 0.542503                       | 0.32508            | 1.44014                     | 0.345117                               | 0.402603                           | 0.847791      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 10000.00 square meters  
 Thickness: 2.00 meters  
 Cover Depth: 3.20 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 2.652E-03 1.841E-03 5.000E-04 1.244E-06 4.992E-10 2.715E-15 5.069E-16  
 M(t): 0.000E+00 0.000E+00 6.630E-04 4.603E-04 1.250E-04 3.111E-07 1.248E-10 6.787E-16 1.267E-16  
 Maximum TDOSE(t): 2.771E-03 mrem/yr at t = 2.288E+00 years

Total Dose Contributions TDOSE(1,p,t) for Individual Radionuclides (1) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 2.288E+00 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground    | Inhalation | Radon     | Plant     | Meat      | Milk      | Soil      |
|-------------------|-----------|------------|-----------|-----------|-----------|-----------|-----------|
|                   | mrem/yr   | mrem/yr    | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   |
| Eu-152            | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Total             | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

Total Dose Contributions TDOSE(1,p,t) for Individual Radionuclides (1) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 2.288E+00 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water     | Fish      | Radon     | Plant     | Meat      | Milk      | All Pathways* |
|-------------------|-----------|-----------|-----------|-----------|-----------|-----------|---------------|
|                   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr       |
| Eu-152            | 2.771E-03 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 2.771E-03     |
| Total             | 2.771E-03 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 2.771E-03     |

\*Sum of all water independent and dependent pathways.

|                    | Density of Contaminated Zone | Contaminated Zone B Parameter | Contaminated Zone Hydraulic Conductivity | Contaminated Zone Total Porosity | Evapotranspiration Coefficient | Runoff Coefficient | Precipitation | Kd of H-3 In Contaminated Zone |
|--------------------|------------------------------|-------------------------------|--|----------------------------------|--------------------------------|--------------------|---------------|--------------------------------|
| Mean               | 1.599957756                  | 5.585075967                   | 219.8949487                              | 0.360000017                      | 0.58500324                     | 0.350002516        | 1.007525454   | 0.25000153                     |
| Standard Error     | 0.006162839                  | 0.029554536                   | 7.70738437                               | 0.000962736                      | 0.001636856                    | 0.000962779        | 0.006151901   | 0.004813601                    |
| Median             | 1.600385                     | 5.58652                       | 118.8725                                 | 0.360001                         | 0.5848865                      | 0.350037           | 1.007745      | 0.250182                       |
| Mode               | 1.61797                      | 4.31525                       | #N/A                                     | 0.388622                         | #N/A                           | 0.306887           | 1.06267       | #N/A                           |
| Standard Deviation | 0.184885174                  | 0.886636073                   | 231.2215311                              | 0.028882066                      | 0.049105667                    | 0.028883361        | 0.184557024   | 0.144408028                    |
| Sample Variance    | 0.034182527                  | 0.786123527                   | 53463.39644                              | 0.000834174                      | 0.002411367                    | 0.000834249        | 0.034061295   | 0.020853678                    |
| Kurtosis           | -1.200184632                 | -1.199858307                  | 0.637331405                              | -1.199960523                     | -1.20030226                    | -1.200684878       | -1.200505914  | -1.200386209                   |
| Skewness           | 0.000104472                  | -0.000593929                  | 1.289859511                              | 0.000250836                      | 0.000875047                    | 0.0002601          | -7.34731E-05  | 4.6435E-05                     |
| Range              | 0.63831                      | 3.062                         | 889.2231                                 | 0.09984                          | 0.169774                       | 0.099816           | 0.638066      | 0.498548309                    |
| Minimum            | 1.28069                      | 4.05148                       | 15.6519                                  | 0.310097                         | 0.50021                        | 0.300075           | 0.688634      | 0.000840691                    |
| Maximum            | 1.919                        | 7.11348                       | 904.875                                  | 0.409937                         | 0.669984                       | 0.399891           | 1.3267        | 0.499389                       |
| Sum                | 1439.96198                   | 5026.56837                    | 197905.4538                              | 324.000015                       | 526.502916                     | 315.002264         | 906.772909    | 225.0013771                    |
| Count              | 900                          | 900                           | 900                                      | 900                              | 900                            | 900                | 900           | 900                            |
| Largest(1)         | 1.919                        | 7.11348                       | 904.875                                  | 0.409937                         | 0.669984                       | 0.399891           | 1.3267        | 0.499389                       |
| Smallest(1)        | 1.28069                      | 4.05148                       | 15.6519                                  | 0.310097                         | 0.50021                        | 0.300075           | 0.688634      | 0.000840691                    |
| 75%                | 1.76106                      | 6.3535                        | 329.605                                  | 0.385005                         | 0.627674                       | 0.375015           | 1.16727       | 0.375644                       |
| 25%                | 1.44001                      | 4.81763                       | 43.277                                   | 0.335045                         | 0.542583                       | 0.325084           | 0.848225      | 0.125185                       |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
AAAAAAAAAAAAAAAAAAAAAAAAAAAAA AAAAAAAAAAAAAAAAAAAAAAAAAAAAA  
Area: 10000.00 square meters H-3 1.000E+00  
Thickness: 2.00 meters  
Cover Depth: 3.20 meters

Total Dose TDOSE(t), mrem/yr  
Basic Radiation Dose Limit = 4.000E+00 mrem/yr

Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
AAAAAAAAAAAAAAAAAAAAAAAAAAAAA AAAAAAAAAAAAAAAAAAAAAAAAAAAAA

|            |           |           |           |           |           |           |           |           |           |
|------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| t (years): | 0.000E+00 | 1.000E+00 | 3.000E+00 | 1.000E+01 | 3.500E+01 | 1.500E+02 | 3.000E+02 | 1.000E+03 | 1.000E+04 |
| TDOSE(t):  | 0.000E+00 | 9.070E-02 | 4.187E-02 | 2.799E-03 | 1.783E-07 | 8.905E-27 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| M(t):      | 0.000E+00 | 2.267E-02 | 1.047E-02 | 6.998E-04 | 4.457E-08 | 2.226E-27 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

Maximum TDOSE(t): 1.283E-01 mrem/yr at t = 0.1215 to 0.0002 years

|                    | Density of Contaminated Zone | Contaminated Zone B Parameter | Evapotranspiration Coefficient | Runoff Coefficient | Effective Porosity of Unsaturated Zone | Total Porosity of Unsaturated Zone | Precipitation |
|--------------------|------------------------------|-------------------------------|--------------------------------|--------------------|--|------------------------------------|---------------|
| Mean               | 1.599998989                  | 5.584839233                   | 0.585009323                    | 0.349998632        | 0.409989919                            | 0.455002578                        | 1.007488272   |
| Standard Error     | 0.006162766                  | 0.029557717                   | 0.001636641                    | 0.000962768        | 0.002503686                            | 0.002021635                        | 0.006153245   |
| Median             | 1.60022                      | 5.585685                      | 0.5850255                      | 0.350117           | 0.409732                               | 0.4548075                          | 1.007535      |
| Mode               | 1.60771                      | 5.38614                       | 0.534356                       | 0.333566           | #N/A                                   | 0.544867                           | 1.30224       |
| Standard Deviation | 0.184882993                  | 0.886731513                   | 0.049099222                    | 0.028883046        | 0.075110588                            | 0.060649047                        | 0.184597359   |
| Sample Variance    | 0.034181721                  | 0.786292776                   | 0.002410734                    | 0.00083423         | 0.0056416                              | 0.003678307                        | 0.034076185   |
| Kurtosis           | -1.200468675                 | -1.199418707                  | -1.19957509                    | -1.199982822       | -1.200826746                           | -1.200016993                       | -1.199911705  |
| Skewness           | -0.000346662                 | 4.63389E-05                   | 0.000215841                    | -0.000539038       | 0.000534848                            | -6.72923E-05                       | 8.59276E-06   |
| Range              | 0.63744                      | 3.062                         | 0.169739                       | 0.0999             | 0.259519                               | 0.209435                           | 0.637726      |
| Minimum            | 1.28154                      | 4.05148                       | 0.500166                       | 0.300035           | 0.280228                               | 0.350306                           | 0.688634      |
| Maximum            | 1.91898                      | 7.11348                       | 0.669905                       | 0.399935           | 0.539747                               | 0.559741                           | 1.32636       |
| Sum                | 1439.99909                   | 5026.35531                    | 526.508391                     | 314.998769         | 368.990927                             | 409.50232                          | 906.739445    |
| Count              | 900                          | 900                           | 900                            | 900                | 900                                    | 900                                | 900           |
| 75%                | 1.76002                      | 6.35732                       | 0.627528                       | 0.375024           | 0.475349                               | 0.507625                           | 1.16727       |
| 25%                | 1.44001                      | 4.82043                       | 0.542866                       | 0.325045           | 0.345127                               | 0.402741                           | 0.848089      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 10000.00 square meters Ni-63 1.000E+00  
 Thickness: 2.00 meters  
 Cover Depth: 3.20 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 1.976E-04 1.647E-04 7.130E-05 2.393E-05 1.465E-07 0.000E+00  
 M(t): 0.000E+00 0.000E+00 0.000E+00 4.939E-05 4.117E-05 1.783E-05 5.982E-06 3.663E-08 0.000E+00  
 Maximum TDOSE(t): 1.987E-04 mrem/yr at t = 9.19 years

Total Dose Contributions TDOSE(1,p,t) for Individual Radionuclides (1) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 9.188E+00 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground    | Inhalation | Radon     | Plant     | Meat      | Milk      | Soil      |
|-------------------|-----------|------------|-----------|-----------|-----------|-----------|-----------|
|                   | mrem/yr   | mrem/yr    | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   |
| Ni-63             | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Total             | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

Total Dose Contributions TDOSE(1,p,t) for Individual Radionuclides (1) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 9.188E+00 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water     | Fish      | Radon     | Plant     | Meat      | Milk      | All Pathways* |
|-------------------|-----------|-----------|-----------|-----------|-----------|-----------|---------------|
|                   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr       |
| Ni-63             | 1.987E-04 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.987E-04     |
| Total             | 1.987E-04 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.987E-04     |

\*Sum of all water independent and dependent pathways.  
 ORESALC.EXE execution time = 1.22 seconds

|                    | Density of Contaminated Zone | Contaminated b Parameter | Contaminated Zone Hydraulic Conductivity | Contaminated Zon Total Porosity | Evapotranspiration Coefficient | Runoff Coefficient | Effective Porosity of Unsaturated Zone | Precipitation |
|--------------------|------------------------------|--------------------------|--|---------------------------------|--------------------------------|--------------------|--|---------------|
| Mean               | 1.599957756                  | 5.585075967              | 219.8949487                              | 0.360000017                     | 0.58500324                     | 0.350002516        | 0.410010379                            | 1.007501901   |
| Standard Error     | 0.006162839                  | 0.029554536              | 7.70738437                               | 0.000962736                     | 0.001636856                    | 0.000962779        | 0.002503123                            | 0.006151779   |
| Median             | 1.600385                     | 5.58652                  | 118.8725                                 | 0.360001                        | 0.5848865                      | 0.350037           | 0.4101                                 | 1.00773       |
| Mode               | 1.61797                      | 4.31525                  | #N/A                                     | 0.388622                        | #N/A                           | 0.306887           | #N/A                                   | 1.31383       |
| Standard Deviation | 0.184885174                  | 0.886636073              | 231.2215311                              | 0.028882066                     | 0.049105667                    | 0.028883361        | 0.075093678                            | 0.184553372   |
| Sample Variance    | 0.034182527                  | 0.786123527              | 53463.39644                              | 0.000834174                     | 0.002411367                    | 0.000834249        | 0.00563906                             | 0.034059947   |
| Kurtosis           | -1.200184632                 | -1.199858307             | 0.637331405                              | -1.199960523                    | -1.20030226                    | -1.20068488        | -1.200504146                           | -1.200385121  |
| Skewness           | 0.000104472                  | -0.000593929             | 1.289859511                              | 0.000250836                     | 0.000875047                    | 0.0002601          | -7.19236E-05                           | 4.61703E-05   |
| Range              | 0.63831                      | 3.062                    | 889.2231                                 | 0.09984                         | 0.169774                       | 0.099816           | 0.259619                               | 0.637146      |
| Minimum            | 1.28069                      | 4.05148                  | 15.6519                                  | 0.310097                        | 0.50021                        | 0.300075           | 0.280258                               | 0.689074      |
| Maximum            | 1.919                        | 7.11348                  | 904.875                                  | 0.409937                        | 0.669984                       | 0.399891           | 0.539877                               | 1.32622       |
| Sum                | 1439.96198                   | 5026.56837               | 197905.4538                              | 324.000015                      | 526.502916                     | 315.002264         | 369.009341                             | 906.751711    |
| Count              | 900                          | 900                      | 900                                      | 900                             | 900                            | 900                | 900                                    | 900           |
| 75%                | 1.76106                      | 6.3535                   | 329.605                                  | 0.385005                        | 0.627674                       | 0.375015           | 0.475007                               | 1.16807       |
| 25%                | 1.44001                      | 4.81763                  | 43.277                                   | 0.335045                        | 0.542583                       | 0.325084           | 0.345193                               | 0.847987      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 10000.00 square meters Pu-238 1.000E+00  
 Thickness: 2.00 meters  
 Cover Depth: 3.20 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 2.188E+00 9.331E+00 8.799E+00 7.136E+00 2.723E+00 7.751E-01 2.245E-03 1.355E-06  
 M(t): 0.000E+00 5.470E-01 2.333E+00 2.200E+00 1.784E+00 6.807E-01 1.938E-01 5.612E-04 3.387E-07  
 Maximum TDOSE(t): 9.544E+00 mrem/yr at t = 1.093E+00 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.093E+00 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-Nuclide | Ground    | Inhalation | Radon     | Plant  | Meat      | Milk   | Soil      |
|---------------|-----------|------------|-----------|--------|-----------|--------|-----------|
|               | mrem/yr   | fract.     | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   |
| Pu-238        | 0.000E+00 | 0.0000     | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 |
| Total         | 0.000E+00 | 0.0000     | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.093E+00 years  
 Water Dependent Pathways

| Radio-Nuclide | Water     | Fish   | Radon     | Plant  | Meat      | Milk   | All Pathways* |
|---------------|-----------|--------|-----------|--------|-----------|--------|---------------|
|               | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       |
| Pu-238        | 9.544E+00 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 9.544E+00     |
| Total         | 9.544E+00 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 9.544E+00     |

\*Sum of all water independent and dependent pathways.



|                    | Density of Contaminated Zone | Contaminated Zone b parameter | Contaminated Zone Hydraulic Conductivity | Evapotranspiration Coefficient | Runoff Coefficient | Effective Porosity of Unsaturated Zone | Precipitation |
|--------------------|------------------------------|-------------------------------|--|--------------------------------|--------------------|--|---------------|
| Mean               | 1.599998989                  | 5.584839233                   | 219.8917289                              | 0.584997673                    | 0.349996113        | 0.410003238                            | 1.007488272   |
| Standard Error     | 0.006162766                  | 0.029557717                   | 7.707887415                              | 0.001636706                    | 0.000962956        | 0.002502976                            | 0.006153245   |
| Median             | 1.60022                      | 5.585685                      | 119.152                                  | 0.5851995                      | 0.3498965          | 0.409762                               | 1.007535      |
| Mode               | 1.60771                      | 5.38614                       | #N/A                                     | #N/A                           | #N/A               | 0.521264                               | 1.30224       |
| Standard Deviation | 0.184882993                  | 0.886731513                   | 231.2366225                              | 0.049101186                    | 0.028888682        | 0.075089281                            | 0.184597359   |
| Sample Variance    | 0.034181721                  | 0.786292776                   | 53470.37556                              | 0.002410927                    | 0.000834556        | 0.0056384                              | 0.034076185   |
| Kurtosis           | -1.200468675                 | -1.199418707                  | 0.640033425                              | -1.199981276                   | -1.20082638        | -1.200018168                           | -1.199911705  |
| Skewness           | -0.000346662                 | 4.63389E-05                   | 1.29063247                               | -0.000539701                   | 0.0005359          | -6.77515E-05                           | 8.59276E-06   |
| Range              | 0.63744                      | 3.062                         | 891.8191                                 | 0.169829                       | 0.099815           | 0.2593                                 | 0.637726      |
| Minimum            | 1.28154                      | 4.05148                       | 15.6519                                  | 0.50006                        | 0.300088           | 0.280379                               | 0.688634      |
| Maximum            | 1.91898                      | 7.11348                       | 907.471                                  | 0.669889                       | 0.399903           | 0.539679                               | 1.32636       |
| Sum                | 1439.99909                   | 5026.35531                    | 197902.556                               | 526.497906                     | 314.996502         | 369.002914                             | 906.739445    |
| Count              | 900                          | 900                           | 900                                      | 900                            | 900                | 900                                    | 900           |
| 75%                | 1.76002                      | 6.35732                       | 329.319                                  | 0.62754                        | 0.375134           | 0.475155                               | 1.16727       |
| 25%                | 1.44001                      | 4.82043                       | 43.4646                                  | 0.542576                       | 0.325049           | 0.345298                               | 0.848089      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 10000.00 square meters Pu-239 1.000E+00  
 Thickness: 2.00 meters  
 Cover Depth: 3.20 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 2.439E+00 1.057E+01 1.053E+01 1.040E+01 9.804E+00 9.080E+00 6.347E+00 5.614E-02  
 M(t): 0.000E+00 6.097E-01 2.642E+00 2.633E+00 2.599E+00 2.451E+00 2.270E+00 1.587E+00 1.404E-02  
 Maximum TDOSE(t): 1.065E+01 mrem/yr at t = 1.093, 0.002 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.093E+00 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground    | Inhalation | Radon     | Plant  | Meat      | Milk   | Soil      |
|-------------------|-----------|------------|-----------|--------|-----------|--------|-----------|
| Nuclide           | mrem/yr   | fract.     | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   |
| Pu-239            | 0.000E+00 | 0.0000     | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 |
| Total             | 0.000E+00 | 0.0000     | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.093E+00 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water     | Fish   | Radon     | Plant  | Meat      | Milk   | All Pathways* |
|-------------------|-----------|--------|-----------|--------|-----------|--------|---------------|
| Nuclide           | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       |
| Pu-239            | 1.065E+01 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 1.065E+01     |
| Total             | 1.065E+01 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 1.065E+01     |

\*Sum of all water independent and dependent pathways.

|                    | Contaminated Zone<br>Hydraulic<br>Conductivity | Evapotranspiration<br>coefficient | Runoff Coefficient | Density of<br>Unsaturated<br>Zone | Effective Porosity of<br>Unsaturated Zone | total Porosity of<br>Unsaturated<br>Zone | Precipitation |
|--------------------|--|-----------------------------------|--------------------|-----------------------------------|---|--|---------------|
| Mean               | 219.8564278                                    | 0.584991104                       | 0.350005479        | 1.599991267                       | 0.409989919                               | 0.455002578                              | 1.007488272   |
| Standard Error     | 7.703317495                                    | 0.001636747                       | 0.00096273         | 0.006161712                       | 0.002503686                               | 0.002021635                              | 0.006153245   |
| Median             | 119.247  | 0.585038                          | 0.350015           | 1.60075                           | 0.409732                                  | 0.4548075                                | 1.007535      |
| Mode               | #N/A   | 0.573988                          | 0.349318           | 1.86433                           | #N/A                                      | 0.544867                                 | 1.30224       |
| Standard Deviation | 231.0995248                                    | 0.049102425                       | 0.028881898        | 0.184851368                       | 0.075110588                               | 0.060649047                              | 0.184597359   |
| Sample Variance    | 53406.99038                                    | 0.002411048                       | 0.000834164        | 0.034170028                       | 0.0056416                                 | 0.003678307                              | 0.034076185   |
| Kurtosis           | 0.629114005                                    | -1.199417592                      | -1.199576162       | -1.199980454                      | -1.200826746                              | -1.200016993                             | -1.199911705  |
| Skewness           | 1.287696308                                    | 4.72965E-05                       | 0.000215723        | -0.000536939                      | 0.000534848                               | -6.72923E-05                             | 8.59276E-06   |
| Range              | 887.916  | 0.169557                          | 0.099847           | 0.63936                           | 0.259519                                  | 0.209435                                 | 0.637726      |
| Minimum            | 15.743   | 0.500082                          | 0.300097           | 1.28022                           | 0.280228                                  | 0.350306                                 | 0.688634      |
| Maximum            | 903.659  | 0.669639                          | 0.399944           | 1.91958                           | 0.539747                                  | 0.559741                                 | 1.32636       |
| Sum                | 197870.785                                     | 526.491994                        | 315.004931         | 1439.99214                        | 368.990927                                | 409.50232                                | 906.739445    |
| Count              | 900  | 900                               | 900                | 900                               | 900                                       | 900                                      | 900           |
| 75%                | 329.132  | 0.627767                          | 0.375017           | 1.76015                           | 0.475349                                  | 0.507625                                 | 1.16727       |
| 25%                | 43.0892  | 0.542662                          | 0.325215           | 1.44029                           | 0.345127                                  | 0.402741                                 | 0.848089      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 10000.00 square meters Pu-241 1.000E+00  
 Thickness: 2.00 meters  
 Cover Depth: 3.20 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 1.975E-01 1.852E-01 1.478E-01 8.195E-02 4.559E-02 3.503E-02 1.035E-02 2.692E-07  
 M(t): 0.000E+00 4.937E-02 4.631E-02 3.695E-02 2.049E-02 1.140E-02 8.759E-03 2.587E-03 6.730E-08  
 Maximum TDOSE(t): 2.019E-01 mrem/yr at t = 0.4666 in 0.0009 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 4.666E-01 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground    | Inhalation | Radon     | Plant     | Meat      | Milk      | Soil      |
|-------------------|-----------|------------|-----------|-----------|-----------|-----------|-----------|
|                   | mrem/yr   | mrem/yr    | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   |
| Pu-241            | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Total             | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 4.666E-01 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water     | Fish      | Radon     | Plant     | Meat      | Milk      | All Pathways* |
|-------------------|-----------|-----------|-----------|-----------|-----------|-----------|---------------|
|                   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr       |
| Pu-241            | 2.019E-01 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 2.019E-01     |
| Total             | 2.019E-01 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 2.019E-01     |

\*Sum of all water independent and dependent pathways.

|                    | Density of Contaminated Zone | Contaminated Zone b Parameter | Contaminated Zone Hydraulic Conductivity | Contaminated Zone Total Porosity | Evapotranspiration Coefficient | Runoff Coefficient | Precipitation |
|--------------------|------------------------------|-------------------------------|--|----------------------------------|--------------------------------|--------------------|---------------|
| Mean               | 1.599998989                  | 5.584839233                   | 219.8917289                              | 0.359998622                      | 0.584993402                    | 0.350001247        | 1.007488272   |
| Standard Error     | 0.006162766                  | 0.029557717                   | 7.707887415                              | 0.000962768                      | 0.001637026                    | 0.000962683        | 0.006153245   |
| Median             | 1.60022                      | 5.585685                      | 119.152                                  | 0.360117                         | 0.5848245                      | 0.3499085          | 1.007535      |
| Mode               | 1.60771                      | 5.38614                       | #N/A                                     | 0.343566                         | #N/A                           | 0.392794           | 1.30224       |
| Standard Deviation | 0.184882993                  | 0.886731513                   | 231.2366225                              | 0.028883049                      | 0.04911078                     | 0.028880485        | 0.184597359   |
| Sample Variance    | 0.034181721                  | 0.786292776                   | 53470.37556                              | 0.000834231                      | 0.002411869                    | 0.000834082        | 0.034076185   |
| Kurtosis           | -1.200468675                 | -1.199418707                  | 0.640033425                              | -1.199982856                     | -1.200825834                   | -1.200018055       | -1.199911705  |
| Skewness           | -0.000346662                 | 4.63389E-05                   | 1.29063247                               | -0.00053861                      | 0.00053554                     | -6.73476E-05       | 8.59276E-06   |
| Range              | 0.63744                      | 3.062                         | 891.8191                                 | 0.0999                           | 0.169686                       | 0.09973            | 0.637726      |
| Minimum            | 1.28154                      | 4.05148                       | 15.6519                                  | 0.310035                         | 0.500149                       | 0.300146           | 0.688634      |
| Maximum            | 1.91898                      | 7.11348                       | 907.471                                  | 0.409935                         | 0.669835                       | 0.399876           | 1.32636       |
| Sum                | 1439.99909                   | 5026.35531                    | 197902.556                               | 323.99876                        | 526.494062                     | 315.001122         | 906.739445    |
| Count              | 900                          | 900                           | 900                                      | 900                              | 900                            | 900                | 900           |
| 75%                | 1.76002                      | 6.35732                       | 329.319                                  | 0.385024                         | 0.627728                       | 0.37506            | 1.16727       |
| 25%                | 1.44001                      | 4.82043                       | 43.4646                                  | 0.335045                         | 0.542583                       | 0.325115           | 0.848089      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 10000.00 square meters Sr-90 1.000E+00  
 Thickness: 2.00 meters  
 Cover Depth: 3.20 meters

0  
 Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 6.396E+00 6.014E+00 4.849E+00 2.248E+00 6.545E-02 6.494E-04 2.908E-13 0.000E+00  
 M(t): 0.000E+00 1.599E+00 1.504E+00 1.212E+00 5.620E-01 1.636E-02 1.624E-04 7.269E-14 0.000E+00  
 0 Maximum TDOSE(t): 6.552E+00 mrem/yr at t = 0.2163 n 0.0004 years

0  
 Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 2.163E-01 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground           | Inhalation       | Radon            | Plant            | Meat             | Milk             | Soil             |
|-------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
|                   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   |
| Sr-90             | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 |
| Total             | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 |

0  
 Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 2.163E-01 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water            | Fish             | Radon            | Plant            | Meat             | Milk             | All Pathways*    |
|-------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
|                   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   |
| Sr-90             | 6.552E+00 1.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 6.552E+00 1.0000 |
| Total             | 6.552E+00 1.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 6.552E+00 1.0000 |

0\*Sum of all water independent and dependent pathways.

|                           | Depth of Roots | Depth of Soil<br>Mixing Layers | External Gamma<br>Shielding Factor | Plant Transfer<br>Factor for Am |
|---------------------------|----------------|--------------------------------|------------------------------------|---------------------------------|
| <b>Mean</b>               | 0.649966946    | 0.249978731                    | 0.311688396                        | 0.001507213                     |
| <b>Standard Error</b>     | 0.006740296    | 0.004247832                    | 0.005873594                        | 5.42441E-05                     |
| <b>Median</b>             | 0.650424       | 0.2328915                      | 0.2699155                          | 0.000997779                     |
| <b>Mode</b>               | #N/A           | 0.390133                       | 0.246525                           | 0.00052656                      |
| <b>Standard Deviation</b> | 0.202208887    | 0.127434961                    | 0.17620783                         | 0.001627322                     |
| <b>Sample Variance</b>    | 0.040888434    | 0.016239669                    | 0.031049199                        | 2.64818E-06                     |
| <b>Kurtosis</b>           | -1.200059872   | -0.605787603                   | 1.340214143                        | 14.76014952                     |
| <b>Skewness</b>           | -9.99408E-05   | 0.419931123                    | 1.190883367                        | 3.185618162                     |
| <b>Range</b>              | 0.698945       | 0.56945966                     | 0.9405984                          | 0.014255048                     |
| <b>Minimum</b>            | 0.300751       | 0.00658234                     | 0.0496876                          | 5.54525E-05                     |
| <b>Maximum</b>            | 0.999696       | 0.576042                       | 0.990286                           | 0.0143105                       |
| <b>Sum</b>                | 584.970251     | 224.9808583                    | 280.519556                         | 1.356491438                     |
| <b>Count</b>              | 900            | 900                            | 900                                | 900                             |
| <b>75%</b>                | 0.826163       | 0.340362                       | 0.398555                           | 0.0018514                       |
| <b>25%</b>                | 0.475012       | 0.150013                       | 0.182284                           | 0.000538494                     |

7/30/2002

LHSBINDAT.xls, Descriptive Stats

7:10 AM

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
AAAAAAAAAAAAAAAAAAAAAAAAAAAAA AAAAAAAAAAAAAAAAAAAAAAAAAAAAA  
Area: 2000.00 square meters Am-241 5.000E-01  
Thickness: 0.20 meters  
Cover Depth: 0.00 meters

0  
Total Dose TDOSE(t), mrem/yr  
Basic Radiation Dose Limit = 2.500E+01 mrem/yr  
Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
AAAAAAAAAAAAAAAAAAAAAAAAAAAAA AAAAAAAAAAAAAAAAAAAAAAAAAAAAA  
t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
TDOSE(t): 2.320E-01 2.311E-01 2.293E-01 2.228E-01 2.012E-01 1.230E-01 5.520E-02 7.153E-09 2.515E-06  
M(t): 9.282E-03 9.245E-03 9.170E-03 8.914E-03 8.048E-03 4.920E-03 2.208E-03 2.861E-10 1.006E-07  
Maximum TDOSE(t): 2.320E-01 mrem/yr at t = 0.000E+00 years



|                           | Depth of Roots | External Gamma Shielding Factor | Plant Transfer Factor for Co | Meat Transfer Factor for Co |
|---------------------------|----------------|---------------------------------|------------------------------|-----------------------------|
| <b>Mean</b>               | 0.649966946    | 0.31152919                      | 0.12115272                   | 0.050265726                 |
| <b>Standard Error</b>     | 0.006740296    | 0.005859029                     | 0.00454535                   | 0.002114444                 |
| <b>Median</b>             | 0.650424       | 0.270305                        | 0.0796347                    | 0.02989765                  |
| <b>Mode</b>               | #N/A           | 0.1218                          | #N/A                         | 0.0145787                   |
| <b>Standard Deviation</b> | 0.202208887    | 0.175770875                     | 0.136360505                  | 0.063433327                 |
| <b>Sample Variance</b>    | 0.040888434    | 0.0308954                       | 0.018594187                  | 0.004023787                 |
| <b>Kurtosis</b>           | -1.200059872   | 1.285485788                     | 25.07457565                  | 19.78702585                 |
| <b>Skewness</b>           | -9.99408E-05   | 1.179186037                     | 3.904341752                  | 3.71564928                  |
| <b>Range</b>              | 0.698945       | 0.9203616                       | 1.54445867                   | 0.59492478                  |
| <b>Minimum</b>            | 0.300751       | 0.0471544                       | 0.00466133                   | 0.00116222                  |
| <b>Maximum</b>            | 0.999696       | 0.967516                        | 1.54912                      | 0.596087                    |
| <b>Sum</b>                | 584.970251     | 280.3762708                     | 109.0374476                  | 45.23915297                 |
| <b>Count</b>              | 900            | 900                             | 900                          | 900                         |
| <b>75%</b>                | 0.826163       | 0.398518                        | 0.14795                      | 0.0598833                   |
| <b>25%</b>                | 0.475012       | 0.182156                        | 0.0429894                    | 0.0149505                   |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
AAAAAAAAAAAAAAAAAAAAAAAAAAAAA AAAAAAAAAAAAAAAAAAAAAAAAAAAAAA  
Area: 2000.00 square meters C-14 5.000E-01  
Thickness: 0.20 meters  
Cover Depth: 0.00 meters

0  
Total Dose TDOSE(t), mrem/yr  
Basic Radiation Dose Limit = 2.500E+01 mrem/yr  
Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
AAAAAAAAAAAAAAAAAAAAAAAAAAAAA AAAAAAAAAAAAAAAAAAAAAAAAAAAAAA  
t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
TDOSE(t): 5.936E-01 2.792E-12 6.145E-03 6.212E-03 2.975E-24 0.000E+00 0.000E+00 0.000E+00 0.000E+00  
M(t): 2.374E-02 1.117E-13 2.458E-04 2.485E-04 1.190E-25 0.000E+00 0.000E+00 0.000E+00 0.000E+00  
Maximum TDOSE(t): 5.936E-01 mrem/yr at t = 0.000E+00 years

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
AAAAAAAAAAAAAAAAAAAAAAAAAAAAA AAAAAAAAAAAAAAAAAAAAAAAAAAAAA  
Area: 2000.00 square meters Co-60 5.000E-01  
Thickness: 0.20 meters  
Cover Depth: 0.00 meters

0  
Total Dose TDOSE(t), mrem/yr  
Basic Radiation Dose Limit = 2.500E+01 mrem/yr  
Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
AAAAAAAAAAAAAAAAAAAAAAAAAAAAA AAAAAAAAAAAAAAAAAAAAAAAAAAAAA  
t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
TDOSE(t): 3.092E+00 2.696E+00 2.049E+00 7.846E-01 2.542E-02 3.511E-09 3.583E-18 0.000E+00 0.000E+00  
M(t): 1.237E-01 1.079E-01 8.198E-02 3.139E-02 1.017E-03 1.405E-10 1.433E-19 0.000E+00 0.000E+00  
Maximum TDOSE(t): 3.092E+00 mrem/yr at t = 0.000E+00 years

|                           | Depth of Roots | External Gamma shielding Factor | Plant Transfer Factor | Meat Transfer Factor | Milk Transfer Factor |
|---------------------------|----------------|---------------------------------|-----------------------|----------------------|----------------------|
| <b>Mean</b>               | 0.649993827    | 0.311576942                     | 0.065048881           | 0.054032323          | 0.011100371          |
| <b>Standard Error</b>     | 0.006740584    | 0.005865496                     | 0.002634899           | 0.000757146          | 0.000181501          |
| <b>Median</b>             | 0.650577       | 0.2701895                       | 0.0400047             | 0.0498017            | 0.00995379           |
| <b>Mode</b>               | #N/A           | 0.127979                        | 0.0206515             | #N/A                 | 0.0103708            |
| <b>Standard Deviation</b> | 0.202217512    | 0.175964866                     | 0.079046976           | 0.022714384          | 0.005445023          |
| <b>Sample Variance</b>    | 0.040891922    | 0.030963634                     | 0.006248424           | 0.000515943          | 2.96483E-05          |
| <b>Kurtosis</b>           | -1.2001246     | 1.310726062                     | 19.04497359           | 2.339536098          | 2.999055409          |
| <b>Skewness</b>           | 0.00038154     | 1.184287836                     | 3.63998789            | 1.238550021          | 1.416613307          |
| <b>Range</b>              | 0.698224       | 0.9285946                       | 0.70438126            | 0.1476186            | 0.03832798           |
| <b>Minimum</b>            | 0.300527       | 0.0471544                       | 0.00135774            | 0.0141644            | 0.00239922           |
| <b>Maximum</b>            | 0.998751       | 0.975749                        | 0.705739              | 0.161783             | 0.0407272            |
| <b>Sum</b>                | 584.994444     | 280.4192479                     | 58.54399301           | 48.6290907           | 9.99033421           |
| <b>Count</b>              | 900            | 900                             | 900                   | 900                  | 900                  |
| <b>75%</b>                | 0.825021       | 0.399408                        | 0.0781693             | 0.0655288            | 0.0136946            |
| <b>25%</b>                | 0.475012       | 0.182397                        | 0.0206404             | 0.037896             | 0.00725339           |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
AAAAAAAAAAAAAAAAAAAAAAAAAAAAA AAAAAAAAAAAAAAAAAAAAAAAAAAAAA  
Area: 2000.00 square meters Cs-137 5.000E-01  
Thickness: 0.20 meters  
Cover Depth: 0.00 meters

0  
Total Dose TDOSE(t), mrem/yr  
Basic Radiation Dose Limit = 2.500E+01 mrem/yr  
Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
AAAAAAAAAAAAAAAAAAAAAAAAAAAAA AAAAAAAAAAAAAAAAAAAAAAAAAAAAA  
t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
TDOSE(t): 1.184E+00 1.155E+00 1.100E+00 9.273E-01 5.033E-01 2.978E-02 6.634E-04 0.000E+00 0.000E+00  
M(t): 4.735E-02 4.621E-02 4.401E-02 3.709E-02 2.013E-02 1.191E-03 2.654E-05 0.000E+00 0.000E+00  
Maximum TDOSE(t): 1.184E+00 mrem/yr at t = 0.000E+00 years

|                    | Density of Contaminated Zone | External Gamma Shielding Factor |
|--------------------|------------------------------|---------------------------------|
| Mean               | 1.5999862                    | 0.311548422                     |
| Standard Error     | 0.006163312                  | 0.005862214                     |
| Median             | 1.60063                      | 0.2702035                       |
| Mode               | 1.88748                      | 0.238119                        |
| Standard Deviation | 0.184899372                  | 0.175866421                     |
| Sample Variance    | 0.034187778                  | 0.030928998                     |
| Kurtosis           | -1.200435789                 | 1.291223333                     |
| Skewness           | 0.000232204                  | 1.180458827                     |
| Range              | 0.63895                      | 0.9203616                       |
| Minimum            | 1.28077                      | 0.0471544                       |
| Maximum            | 1.91972                      | 0.967516                        |
| Sum                | 1439.98758                   | 280.3935794                     |
| Count              | 900                          | 900                             |
| 75%                | 1.76106                      | 0.399162                        |
| 25%                | 1.44001                      | 0.182547                        |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
AAAAAAAAAAAAAAAAAAAAAAAAAAAAA AAAAAAAAAAAAAAAAAAAAAAAAAAAAA  
Area: 2000.00 square meters Eu-152 5.000E-01  
Thickness: 0.20 meters  
Cover Depth: 0.00 meters

0  
Total Dose TDOSE(t), mrem/yr  
Basic Radiation Dose Limit = 2.500E+01 mrem/yr  
Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
AAAAAAAAAAAAAAAAAAAAAAAAAAAAA AAAAAAAAAAAAAAAAAAAAAAAAAAAAA  
t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
TDOSE(t): 1.207E+00 1.144E+00 1.029E+00 7.092E-01 1.876E-01 4.075E-04 1.250E-07 0.000E+00 4.207E-18  
M(t): 4.827E-02 4.577E-02 4.115E-02 2.837E-02 7.506E-03 1.630E-05 4.998E-09 0.000E+00 1.683E-19  
Maximum TDOSE(t): 1.207E+00 mrem/yr at t = 0.000E+00 years

|                    | Depth of Roots | Contaminated Zone B Parameter | Contaminated Zone Hydraulic Conductivity | Kd of H-3 in Contaminated Zone |
|--------------------|----------------|-------------------------------|--|--------------------------------|
| Mean               | 0.649966946    | 5.585091067                   | 2278.595811                              | 0.24999238                     |
| Standard Error     | 0.006740296    | 0.029551739                   | 162.6345917                              | 0.004813285                    |
| Median             | 0.650424       | 5.58763                       | 95.74765                                 | 0.250004                       |
| Mode               | #N/A           | 4.31525                       | #N/A                                     | 0.121367                       |
| Standard Deviation | 0.202208887    | 0.886552159                   | 4879.03775                               | 0.144398552                    |
| Sample Variance    | 0.040888434    | 0.785974731                   | 23805009.37                              | 0.020850942                    |
| Kurtosis           | -1.200059872   | -1.200087672                  | 7.14010619                               | -1.200049984                   |
| Skewness           | -9.99408E-05   | -0.000498973                  | 2.735551509                              | -4.23666E-05                   |
| Range              | 0.698945       | 3.062                         | 25230.33404                              | 0.49868438                     |
| Minimum            | 0.300751       | 4.05148                       | 0.36596                                  | 0.00040262                     |
| Maximum            | 0.999696       | 7.11348                       | 25230.7                                  | 0.499087                       |
| Sum                | 584.970251     | 5026.58196                    | 2050736.23                               | 224.9931417                    |
| Count              | 900            | 900                           | 900                                      | 900                            |
| Largest(1)         | 0.999696       | 7.11348                       | 25230.7                                  | 0.499087                       |
| Smallest(1)        | 0.300751       | 4.05148                       | 0.36596                                  | 0.00040262                     |
| 75%                | 0.826163       | 6.3535                        | 1567.26                                  | 0.375027                       |
| 25%                | 0.475012       | 4.81763                       | 5.91974                                  | 0.125225                       |



Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
AAAAAAAAAAAAAAAAAAAAAAAAAAAAA AAAAAAAAAAAAAAAAAAAAAAAAAAAAA  
Area: 2000.00 square meters H-3 5.000E-01  
Thickness: 0.20 meters  
Cover Depth: 0.00 meters

0  
Total Dose TDOSE(t), mrem/yr  
Basic Radiation Dose Limit = 2.500E+01 mrem/yr  
Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
AAAAAAAAAAAAAAAAAAAAAAAAAAAAA AAAAAAAAAAAAAAAAAAAAAAAAAAAAA  
t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
TDOSE(t): 1.082E-02 6.284E-06 1.284E-04 8.979E-05 2.172E-05 0.000E+00 0.000E+00 0.000E+00 0.000E+00  
M(t): 4.328E-04 2.514E-07 5.136E-06 3.591E-06 8.689E-07 0.000E+00 0.000E+00 0.000E+00 0.000E+00  
Maximum TDOSE(t): 1.082E-02 mrem/yr at t = 0.000E+00 years

|                           | Depth of<br>Roots | Depth of Soil<br>Mixing Layer | Plant Transfer<br>Factor of Ni | Meat Transfer<br>Factor for Ni | Milk Transfer<br>Factor of Ni |
|---------------------------|-------------------|-------------------------------|--------------------------------|--------------------------------|-------------------------------|
| <b>Mean</b>               | 0.64999383        | 0.249986177                   | 0.075424134                    | 0.007565828                    | 0.025398861                   |
| <b>Standard Error</b>     | 0.00674058        | 0.004249897                   | 0.002741354                    | 0.000276251                    | 0.000645479                   |
| <b>Median</b>             | 0.650577          | 0.2327835                     | 0.0498441                      | 0.00499491                     | 0.02004635                    |
| <b>Mode</b>               | #N/A              | #N/A                          | 0.0270835                      | 0.0160252                      | 0.0212972                     |
| <b>Standard Deviation</b> | 0.20221751        | 0.127496899                   | 0.082240619                    | 0.008287517                    | 0.019364374                   |
| <b>Sample Variance</b>    | 0.04089192        | 0.016255459                   | 0.006763519                    | 6.86829E-05                    | 0.000374979                   |
| <b>Kurtosis</b>           | -1.2001246        | -0.602278227                  | 15.57308108                    | 16.40397836                    | 7.586634947                   |
| <b>Skewness</b>           | 0.00038154        | 0.421420863                   | 3.271820383                    | 3.33939064                     | 2.242910824                   |
| <b>Range</b>              | 0.698224          | 0.57292766                    | 0.70178229                     | 0.071301364                    | 0.15766312                    |
| <b>Minimum</b>            | 0.300527          | 0.00658234                    | 0.00219871                     | 0.000291436                    | 0.00245888                    |
| <b>Maximum</b>            | 0.998751          | 0.57951                       | 0.703981                       | 0.0715928                      | 0.160122                      |
| <b>Sum</b>                | 584.994444        | 224.9875592                   | 67.88172097                    | 6.809244837                    | 22.8589746                    |
| <b>Count</b>              | 900               | 900                           | 900                            | 900                            | 900                           |
| <b>75%</b>                | 0.825021          | 0.341009                      | 0.0924693                      | 0.00928698                     | 0.0320911                     |
| <b>25%</b>                | 0.475012          | 0.150229                      | 0.02707                        | 0.00269398                     | 0.0125698                     |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
AAAAAAAAAAAAAAAAAAAAAAAAAAAA Initial Soil Concentrations, pCi/g  
Area: 2000.00 square meters Ni-63 5.000E-01  
Thickness: 0.20 meters  
Cover Depth: 0.00 meters

0  
Total Dose TDOSE(t), mrem/yr  
Basic Radiation Dose Limit = 2.500E+01 mrem/yr  
Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
AAAAAAAAAAAAAAAAAAAAAAAAAAAA  
t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
TDOSE(t): 7.763E-03 7.690E-03 7.546E-03 7.061E-03 5.564E-03 1.815E-03 3.550E-04 0.000E+00 0.000E+00  
M(t): 3.105E-04 3.076E-04 3.018E-04 2.824E-04 2.225E-04 7.262E-05 1.420E-05 0.000E+00 0.000E+00  
Maximum TDOSE(t): 7.763E-03 mrem/yr at t = 0.000E+00 years

|                           | Depth of<br>Roots | Depth of Soil<br>Mixing Layer | Plant Transfer<br>Factor for Pu | Meat Transfer<br>Factor for Pu |
|---------------------------|-------------------|-------------------------------|---------------------------------|--------------------------------|
| <b>Mean</b>               | 0.64997           | 0.249978731                   | 0.001517481                     | 0.000108504                    |
| <b>Standard Error</b>     | 0.00674           | 0.004247832                   | 5.69321E-05                     | 1.51334E-06                    |
| <b>Median</b>             | 0.65042           | 0.2328915                     | 0.000997453                     | 0.000100035                    |
| <b>Mode</b>               | #N/A              | 0.390133                      | #N/A                            | 0.000101962                    |
| <b>Standard Deviation</b> | 0.20221           | 0.127434961                   | 0.001707964                     | 4.54003E-05                    |
| <b>Sample Variance</b>    | 0.04089           | 0.016239669                   | 2.91714E-06                     | 2.06118E-09                    |
| <b>Kurtosis</b>           | -1.20006          | -0.605787603                  | 25.07453717                     | 2.123332729                    |
| <b>Skewness</b>           | -1E-04            | 0.419931123                   | 3.904338254                     | 1.202207735                    |
| <b>Range</b>              | 0.69895           | 0.56945966                    | 0.019344915                     | 0.000297215                    |
| <b>Minimum</b>            | 0.30075           | 0.00658234                    | 5.83849E-05                     | 2.78456E-05                    |
| <b>Maximum</b>            | 0.9997            | 0.576042                      | 0.0194033                       | 0.000325061                    |
| <b>Sum</b>                | 584.97            | 224.9808583                   | 1.365733136                     | 0.097653961                    |
| <b>Count</b>              | 900               | 900                           | 900                             | 900                            |
| <b>75%</b>                | 0.82616           | 0.340362                      | 0.00185313                      | 0.000131507                    |
| <b>25%</b>                | 0.47501           | 0.150013                      | 0.000538457                     | 7.61421E-05                    |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 2000.00 square meters Pu-238 1.000E+00  
 Thickness: 1.00 meters  
 Cover Depth: 0.00 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 9.486E+00 9.317E+00 8.747E+00 6.984E+00 2.478E+00 6.413E-01 1.159E-03 0.000E+00  
 M(t): 0.000E+00 2.372E+00 2.329E+00 2.187E+00 1.746E+00 6.195E-01 1.603E-01 2.897E-04 0.000E+00  
 Maximum TDOSE(t): 9.486E+00 mrem/yr at t = 0.999 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 9.988E-01 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground    | Inhalation | Radon     | Plant  | Meat      | Milk   | Soil      |
|-------------------|-----------|------------|-----------|--------|-----------|--------|-----------|
| Nuclide           | mrem/yr   | fract.     | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   |
| Pu-238            | 0.000E+00 | 0.0000     | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 |
| Total             | 0.000E+00 | 0.0000     | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 9.988E-01 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water     | Fish   | Radon     | Plant  | Meat      | Milk   | All Pathways* |
|-------------------|-----------|--------|-----------|--------|-----------|--------|---------------|
| Nuclide           | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       |
| Pu-238            | 9.486E+00 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 9.486E+00     |
| Total             | 9.486E+00 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 9.486E+00     |

\*Sum of all water independent and dependent pathways.  
 ORESALC.EXE execution time = 3.49 seconds

|                           | Depth of<br>Roots | Depth of Soil<br>Mixing Layer | Plant Transfer<br>Factor for Pu | Meat Transfer<br>Factor for Pu |
|---------------------------|-------------------|-------------------------------|---------------------------------|--------------------------------|
| <b>Mean</b>               | 0.64997           | 0.249978731                   | 0.001517481                     | 0.000108504                    |
| <b>Standard Error</b>     | 0.00674           | 0.004247832                   | 5.69321E-05                     | 1.51334E-06                    |
| <b>Median</b>             | 0.65042           | 0.2328915                     | 0.000997453                     | 0.000100035                    |
| <b>Mode</b>               | #N/A              | 0.390133                      | #N/A                            | 0.000101962                    |
| <b>Standard Deviation</b> | 0.20221           | 0.127434961                   | 0.001707964                     | 4.54003E-05                    |
| <b>Sample Variance</b>    | 0.04089           | 0.016239669                   | 2.91714E-06                     | 2.06118E-09                    |
| <b>Kurtosis</b>           | -1.2001           | -0.605787603                  | 25.07453717                     | 2.123332729                    |
| <b>Skewness</b>           | -1E-04            | 0.419931123                   | 3.904338254                     | 1.202207735                    |
| <b>Range</b>              | 0.69895           | 0.56945966                    | 0.019344915                     | 0.000297215                    |
| <b>Minimum</b>            | 0.30075           | 0.00658234                    | 5.83849E-05                     | 2.78456E-05                    |
| <b>Maximum</b>            | 0.9997            | 0.576042                      | 0.0194033                       | 0.000325061                    |
| <b>Sum</b>                | 584.97            | 224.9808583                   | 1.365733136                     | 0.097653961                    |
| <b>Count</b>              | 900               | 900                           | 900                             | 900                            |
| <b>75%</b>                | 0.82616           | 0.340362                      | 0.00185313                      | 0.000131507                    |
| <b>25%</b>                | 0.47501           | 0.150013                      | 0.000538457                     | 7.61421E-05                    |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
AAAAAAAAAAAAAAAAAAAAAAAAAAAAA AAAAAAAAAAAAAAAAAAAAAAAAAAAAAA  
Area: 2000.00 square meters Pu-239 5.000E-01  
Thickness: 0.20 meters  
Cover Depth: 0.00 meters

0

Total Dose TDOSE(t), mrem/yr  
Basic Radiation Dose Limit = 2.500E+01 mrem/yr  
Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
AAAAAAAAAAAAAAAAAAAAAAAAAAAAA AAAAAAAAAAAAAAAAAAAAAAAAAAAAAA

|            |           |           |           |           |           |           |           |           |           |
|------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| t (years): | 0.000E+00 | 1.000E+00 | 3.000E+00 | 1.000E+01 | 3.500E+01 | 1.500E+02 | 3.000E+02 | 1.000E+03 | 1.000E+04 |
| TDOSE(t):  | 2.234E-01 | 2.217E-01 | 2.182E-01 | 2.064E-01 | 1.692E-01 | 6.614E-02 | 1.626E-02 | 2.347E-02 | 2.522E-02 |
| M(t):      | 8.937E-03 | 8.869E-03 | 8.729E-03 | 8.258E-03 | 6.766E-03 | 2.646E-03 | 6.503E-04 | 9.388E-04 | 1.009E-03 |

Maximum TDOSE(t): 2.234E-01 mrem/yr at t = 0.000E+00 years

|                    | Depth of Roots | Contamianted Zone Erosion Rate | Depth of Soil Mixing Layer | Precipitation | Plant Transfer Factor for Pu | Plant Transfer Factor for Am | Meat Transfer Factor for Np |
|--------------------|----------------|--------------------------------|----------------------------|---------------|------------------------------|------------------------------|-----------------------------|
| Mean               | 0 649998902    | 0 000268803                    | 0 250045715                | 1 007491108   | 0 001512707                  | 0 001509963                  | 0 001267046                 |
| Standard Error     | 0 006740526    | 4.77242E-06                    | 0 0042521                  | 0 006152084   | 5 58058E-05                  | 5 49616E-05                  | 3 26215E-05                 |
| Median             | 0 650244       | 0 000232479                    | 0 2326315                  | 1 00825       | 0 000995407                  | 0 000995665                  | 0 000997863                 |
| Mode               | #N/A           | 0 000233076                    | 0 134864                   | 0 902484      | #N/A                         | #N/A                         | #N/A                        |
| Standard Deviation | 0 202215791    | 0 000143173                    | 0 127563015                | 0 184562521   | 0 001674174                  | 0 001648847                  | 0 000978644                 |
| Sample Variance    | 0 040891226    | 2 04984E-08                    | 0 016272323                | 0 034063324   | 2 80286E-06                  | 2 7187E-06                   | 9 57743E-07                 |
| Kurtosis           | -1.200469152   | -0 744498763                   | -0 594216187               | -1.199982135  | 21.10746885                  | 17 34192825                  | 8 941597005                 |
| Skewness           | -0 000345667   | 0 643655759                    | 0 425255368                | -0 000539688  | 3 634915908                  | 3 377937119                  | 2 387142382                 |
| Range              | 0 697204       | 0 000507504                    | 0 57835483                 | 0 638356      | 0 017007138                  | 0 015909733                  | 0 008367823                 |
| Minimum            | 0 301681       | 9 00823E-05                    | 0 00936717                 | 0 688224      | 5 67619E-05                  | 6 52672E-05                  | 0 000116977                 |
| Maximum            | 0 998885       | 0.000597586                    | 0 587722                   | 1.32658       | 0 0170639                    | 0 015975                     | 0 0084848                   |
| Sum                | 584 999012     | 0 241922941                    | 225 0411437                | 906 741997    | 1 361436678                  | 1 35896654                   | 1 140341712                 |
| Count              | 900            | 900                            | 900                        | 900           | 900                          | 900                          | 900                         |
| 75%                | 0 825018       | 0 000374514                    | 0 340278                   | 1 1674        | 0 00185829                   | 0 00185429                   | 0.00159255                  |
| 25%                | 0 475012       | 0 000144879                    | 0.150645                   | 0 848037      | 0 000538557                  | 0 000539577                  | 0 000625872                 |



Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 2000.00 square meters Pu-241 5.000E-01  
 Thickness: 0.20 meters  
 Cover Depth: 0.00 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 2.500E+01 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 4.296E-03 4.437E-03 4.690E-03 5.356E-03 6.133E-03 4.568E-03 2.813E-03 1.835E-04 1.576E-07  
 M(t): 1.719E-04 1.775E-04 1.876E-04 2.142E-04 2.453E-04 1.827E-04 1.125E-04 7.340E-06 6.303E-09  
 Maximum TDOSE(t): 6.139E-03 mrem/yr at t = 38.28 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 3.828E+01 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground<br>mrem/yr<br>fract. | Inhalation<br>mrem/yr<br>fract. | Radon<br>mrem/yr<br>fract. | Plant<br>mrem/yr<br>fract. | Meat<br>mrem/yr<br>fract. | Milk<br>mrem/yr<br>fract. | Soil<br>mrem/yr<br>fract. |
|-------------------|-----------------------------|---------------------------------|----------------------------|----------------------------|---------------------------|---------------------------|---------------------------|
| Pu-241            | 2.884E-04                   | 1.424E-04                       | 0.0232                     | 0.000E+00                  | 0.0000                    | 4.908E-03                 | 0.7995                    |
| Total             | 2.884E-04                   | 0.0470                          | 1.424E-04                  | 0.0232                     | 0.000E+00                 | 0.0000                    | 4.908E-03                 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 3.828E+01 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water<br>mrem/yr<br>fract. | Fish<br>mrem/yr<br>fract. | Radon<br>mrem/yr<br>fract. | Plant<br>mrem/yr<br>fract. | Meat<br>mrem/yr<br>fract. | Milk<br>mrem/yr<br>fract. | All Pathways*<br>mrem/yr<br>fract. |
|-------------------|----------------------------|---------------------------|----------------------------|----------------------------|---------------------------|---------------------------|------------------------------------|
| Pu-241            | 0.000E+00                  | 0.0000                    | 0.000E+00                  | 0.0000                     | 0.000E+00                 | 0.0000                    | 6.139E-03                          |
| Total             | 0.000E+00                  | 0.0000                    | 0.000E+00                  | 0.0000                     | 0.000E+00                 | 0.0000                    | 6.139E-03                          |

\*Sum of all water independent and dependent pathways.

|                           | Depth of<br>Roots | Plant Transfer<br>Factor for Sr | Meat Transfer Factor<br>for Sr | Milk Transfer<br>Factor for Sr |
|---------------------------|-------------------|---------------------------------|--------------------------------|--------------------------------|
| <b>Mean</b>               | 0.64996695        | 0.488001662                     | 0.010805866                    | 0.002241031                    |
| <b>Standard Error</b>     | 0.0067403         | 0.019434056                     | 0.000152114                    | 3.66584E-05                    |
| <b>Median</b>             | 0.650424          | 0.301838                        | 0.00995047                     | 0.00200926                     |
| <b>Mode</b>               | #N/A              | #N/A                            | #N/A                           | 0.00175358                     |
| <b>Standard Deviation</b> | 0.20220889        | 0.583021673                     | 0.004563408                    | 0.001099753                    |
| <b>Sample Variance</b>    | 0.04088843        | 0.339914272                     | 2.08247E-05                    | 1.20946E-06                    |
| <b>Kurtosis</b>           | -1.20005987       | 17.43171346                     | 2.898742513                    | 2.976637038                    |
| <b>Skewness</b>           | -9.9941E-05       | 3.483614975                     | 1.308121488                    | 1.41700937                     |
| <b>Range</b>              | 0.698945          | 5.141624                        | 0.03416811                     | 0.00741979                     |
| <b>Minimum</b>            | 0.300751          | 0.011346                        | 0.00283409                     | 0.00045629                     |
| <b>Maximum</b>            | 0.999696          | 5.15297                         | 0.0370022                      | 0.00787608                     |
| <b>Sum</b>                | 584.970251        | 439.201496                      | 9.72527896                     | 2.01692818                     |
| <b>Count</b>              | 900               | 900                             | 900                            | 900                            |
| <b>75%</b>                | 0.826163          | 0.58917                         | 0.0130883                      | 0.00275894                     |
| <b>25%</b>                | 0.475012          | 0.154153                        | 0.00757472                     | 0.00146435                     |

7/30/2002

LHSBINDAT.xls, Descriptive Stats

7:12 AM

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
AAAAAAAAAAAAAAAAAAAAAAAAAAAAA AAAAAAAAAAAAAAAAAAAAAAAAAAAAA  
Area: 2000.00 square meters Sr-90 5.000E-01  
Thickness: 0.20 meters  
Cover Depth: 0.00 meters

0  
Total Dose TDOSE(t), mrem/yr  
Basic Radiation Dose Limit = 2.500E+01 mrem/yr  
Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
AAAAAAAAAAAAAAAAAAAAAAAAAAAAA AAAAAAAAAAAAAAAAAAAAAAAAAAAAA  
t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
TDOSE(t): 4.397E+00 3.920E+00 3.096E+00 1.356E+00 7.102E-02 1.141E-03 3.227E-05 1.888E-12 0.000E+00  
M(t): 1.759E-01 1.568E-01 1.239E-01 5.425E-02 2.841E-03 4.563E-05 1.291E-06 7.554E-14 0.000E+00  
Maximum TDOSE(t): 4.397E+00 mrem/yr at t = 0.000E+00 years

|                    | Saturated Zone<br>Hydraulic Conductivity | Contaminated<br>Zone Erosion Rate | Evapotranspiration<br>Coefficient | Saturated Zone<br>Hydraulic<br>Gradient | Well Pump<br>Intake Depth | Precipitation | Plant Transfer<br>Factor for Np |
|--------------------|--|-----------------------------------|-----------------------------------|---|---------------------------|---------------|---------------------------------|
| Mean               | 12700.14008                              | 0.000268803                       | 0.585009323                       | 0.021499767                             | 30.1984438                | 1.007507879   | 0.030396869                     |
| Standard Error     | 244.5813287                              | 4.77242E-06                       | 0.001636641                       | 0.000163671                             | 0.38518245                | 0.006151544   | 0.001117341                     |
| Median             | 12709                                    | 0.000232479                       | 0.5850255                         | 0.02151995                              | 30.1588                   | 1.006915      | 0.0200434                       |
| Mode               | 15744.6                                  | 0.000233076                       | 0.534356                          | 0.0187062                               | #N/A                      | 1.28095       | #N/A                            |
| Standard Deviation | 7337.439862                              | 0.000143173                       | 0.049099222                       | 0.004910118                             | 11.5554736                | 0.184546315   | 0.033520232                     |
| Sample Variance    | 53838023.72                              | 2.04984E-08                       | 0.002410734                       | 2.41093E-05                             | 133.528971                | 0.034057342   | 0.001123606                     |
| Kurtosis           | -1.200468791                             | -0.744498763                      | -1.19957509                       | -1.199981412                            | -1.2008265                | -1.200017641  | 18.64951692                     |
| Skewness           | -0.000345398                             | 0.643655759                       | 0.000215841                       | -0.000539513                            | 0.0005343                 | -6.66298E-05  | 3.486585916                     |
| Range              | 25298.2437                               | 0.000507504                       | 0.169739                          | 0.0169829                               | 39.926                    | 0.637277      | 0.3382866                       |
| Minimum            | 61.3563                                  | 9.00823E-05                       | 0.500166                          | 0.013006                                | 10.2351                   | 0.688933      | 0.0011784                       |
| Maximum            | 25359.6                                  | 0.000597586                       | 0.669905                          | 0.0299889                               | 50.1611                   | 1.32621       | 0.339465                        |
| Sum                | 11430126.07                              | 0.241922941                       | 526.508391                        | 19.3497906                              | 27178.5994                | 906.757091    | 27.35718203                     |
| Count              | 900                                      | 900                               | 900                               | 900                                     | 900                       | 900           | 900                             |
| 75%                | 19050.7                                  | 0.000374514                       | 0.627528                          | 0.025754                                | 40.2537                   | 1.16763       | 0.0371835                       |
| 25%                | 6350.7                                   | 0.000144879                       | 0.542866                          | 0.0172576                               | 20.2196                   | 0.848483      | 0.0108185                       |

7/30/2002

LHSBINDAT.xls, Descriptive Stats

7:12 AM

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 2000.00 square meters Am-241 5.000E-01  
 Thickness: 0.20 meters  
 Cover Depth: 0.00 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 4.555E-11 1.210E-10 2.555E-10 7.165E-14  
 M(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 1.139E-11 3.024E-11 6.388E-11 1.791E-14  
 Maximum TDOSE(t): 2.740E-06 mrem/yr at t = 4455 years

Total Dose Contributions TDOSE(1,p,t) for Individual Radionuclides (1) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 4.455E+03 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground           | Inhalation       | Radon            | Plant            | Meat             | Milk             | Soil             |
|-------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
|                   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   |
| Am-241            | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 |
| Total             | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 |

Total Dose Contributions TDOSE(1,p,t) for Individual Radionuclides (1) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 4.455E+03 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water            | Fish             | Radon            | Plant            | Meat             | Milk             | All Pathways*    |
|-------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
|                   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   |
| Am-241            | 2.740E-06 1.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 2.740E-06 1.0000 |
| Total             | 2.740E-06 1.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 2.740E-06 1.0000 |

\*Sum of all water independent and dependent pathways.

|                    | Well pump intake<br>depth | Precipitation | Kd of C-14 in<br>contaminated Zone | Kd of C-14 in<br>Unsaturated Zone | Kd of C-14 in<br>Saturated Zone |
|--------------------|---------------------------|---------------|------------------------------------|-----------------------------------|---------------------------------|
| Mean               | 30.19964911               | 1.00750291    | 2.500454134                        | 2.500056321                       | 2.50007587                      |
| Standard Error     | 0.385176243               | 0.006151777   | 0.048133255                        | 0.048140062                       | 0.048143279                     |
| Median             | 30.23295                  | 1.00786       | 2.50249                            | 2.501445                          | 2.50084                         |
| Mode               | 27.2774                   | #N/A          | #N/A                               | 4.49243                           | 2.67481                         |
| Standard Deviation | 11.55528729               | 0.184553316   | 1.443997636                        | 1.444201851                       | 1.444298365                     |
| Sample Variance    | 133.5246644               | 0.034059927   | 2.085129172                        | 2.085718987                       | 2.085997768                     |
| Kurtosis           | -1.200124139              | -1.2000071    | -1.199835858                       | -1.200150121                      | -1.200661883                    |
| Skewness           | 0.000381332               | 0.000132538   | 0.000230347                        | 0.000134696                       | 5.61575E-05                     |
| Range              | 39.8985                   | 0.637702      | 4.98874533                         | 4.98603536                        | 4.98703167                      |
| Minimum            | 10.2301                   | 0.688308      | 0.00165467                         | 0.00483464                        | 0.00617833                      |
| Maximum            | 50.1286                   | 1.32601       | 4.9904                             | 4.99087                           | 4.99321                         |
| Sum                | 27179.6842                | 906.752619    | 2250.408721                        | 2250.050689                       | 2250.068283                     |
| Count              | 900                       | 900           | 900                                | 900                               | 900                             |
| Largest(1)         | 50.1286                   | 1.32601       | 4.9904                             | 4.99087                           | 4.99321                         |
| Smallest(1)        | 10.2301                   | 0.688308      | 0.00165467                         | 0.00483464                        | 0.00617833                      |
| 75%                | 40.2012                   | 1.16825       | 3.7519                             | 3.7549                            | 3.75755                         |
| 25%                | 20.2007                   | 0.848237      | 1.26514                            | 1.25225                           | 1.25245                         |

7/30/2002

LHSBINDAT.xls, Descriptive Statistics

7:12 AM

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
AAAAAAAAAAAAAAAAAAAAAAAAAAAAA AAAAAAAAAAAAAAAAAAAAAAAAAAAAA  
Area: 2000.00 square meters C-14 5.000E-01  
Thickness: 0.20 meters  
Cover Depth: 0.00 meters

0  
Total Dose TDOSE(t), mrem/yr  
Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
AAAAAAAAAAAAAAAAAAAAAAAAAAAAA AAAAAAAAAAAAAAAAAAAAAAAAAAAAA  
t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 1.372E-04 1.307E-04 0.000E+00 0.000E+00 0.000E+00 0.000E+00  
M(t): 0.000E+00 0.000E+00 0.000E+00 3.430E-05 3.267E-05 0.000E+00 0.000E+00 0.000E+00 0.000E+00  
Maximum TDOSE(t): 1.403E-04 mrem/yr at t = 9.39 n 0.02 years

|                    | Saturated Zone Hydraulic<br>Conductivity | Contaminated Zone<br>Erosion Rate | Well Pump<br>Intake Depth | Precipitation | Plant Transfer<br>Factor for Gd |
|--------------------|--|-----------------------------------|---------------------------|---------------|---------------------------------|
| Mean               | 12699.95651                              | 0.000268826                       | 30 203633                 | 1.007507141   | 0.003625961                     |
| Standard Error     | 244.5834382                              | 4 77235E-06                       | 0 385066042               | 0.0061523     | 0.00016698                      |
| Median             | 12721.1                                  | 0.000232628                       | 30 2199                   | 1.007685      | 0.00201017                      |
| Mode               | #N/A                                     | 0 000134304                       | #N/A                      | 1.26213       | 0 00221257                      |
| Standard Deviation | 7337.503146                              | 0.00014317                        | 11.55198127               | 0.184568988   | 0 00500941                      |
| Sample Variance    | 53838952 42                              | 2.04978E-08                       | 133 4482714               | 0 034065711   | 2.50942E-05                     |
| Kurtosis           | -1.200124414                             | -0 746029457                      | -1.19983498               | -1.200149408  | 24 98574926                     |
| Skewness           | 0 000381861                              | 0 643147661                       | 0.000230231               | 0 000136172   | 4.128974922                     |
| Range              | 25335 2145                               | 0.000508152                       | 39 91                     | 0.637212      | 0.054068145                     |
| Minimum            | 19.4855                                  | 9.00823E-05                       | 10.2132                   | 0.688618      | 7 22548E-05                     |
| Maximum            | 25354.7                                  | 0.000598234                       | 50.1232                   | 1.32583       | 0.0541404                       |
| Sum                | 11429960 86                              | 0 241943826                       | 27183.2697                | 906 756427    | 3 263364788                     |
| Count              | 900                                      | 900                               | 900                       | 900           | 900                             |
| 75%                | 19050 9                                  | 0 000374514                       | 40.2152                   | 1.16788       | 0.00423756                      |
| 25%                | 6350.7                                   | 0.000144827                       | 20.3211                   | 0.848037      | 0.000959297                     |

7/30/2002

LHSBINDAT.xls, Descriptive Stats

7:13 AM



Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 2000.00 square meters Eu-152 5.000E-01  
 Thickness: 0.20 meters  
 Cover Depth: 0.00 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00  
 M(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00  
 Maximum TDOSE(t): 1.044E-17 mrem/yr at t = 3131.6 years

Total Dose Contributions TDOSE(1,p,t) for Individual Radionuclides (1) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 3.131E+03 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground           | Inhalation       | Radon            | Plant            | Meat             | Milk             | Soil             |
|-------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
| Eu-152            | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 |
| Total             | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 |

Total Dose Contributions TDOSE(1,p,t) for Individual Radionuclides (1) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 3.131E+03 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water            | Fish             | Radon            | Plant            | Meat             | Milk             | All Pathways*    |
|-------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
| Eu-152            | 1.044E-17 1.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 1.044E-17 1.0000 |
| Total             | 1.044E-17 1.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 1.044E-17 1.0000 |

\*Sum of all water independent and dependent pathways.  
 RESCALC.EXE execution time = 1.18 seconds

|                    | Saturated Zone Hydraulic Conductivity | Thickness of Unsaturated Zone | Contaminated Zone Erosion Rate | Evapotranspiration Coefficient | Precipitation |
|--------------------|---------------------------------------|-------------------------------|--------------------------------|--------------------------------|---------------|
| Mean               | 12699.95651                           | 1.25002222                    | 0.000268867                    | 0.585001923                    | 1.007509689   |
| Standard Error     | 244.5834382                           | 0.00481359                    | 4.77306E-06                    | 0.001636762                    | 0.006152711   |
| Median             | 12721.1                               | 1.25028                       | 0.000232599                    | 0.5850495                      | 1.007605      |
| Mode               | #N/A                                  | 1.0528                        | 0.000145498                    | 0.652743                       | 1.02984       |
| Standard Deviation | 7337.503146                           | 0.144407692                   | 0.000143192                    | 0.049102864                    | 0.184581334   |
| Sample Variance    | 53838952.42                           | 0.020853582                   | 2.05039E-08                    | 0.002411091                    | 0.034070269   |
| Kurtosis           | -1.200124414                          | -1.2000078                    | -0.744076128                   | -1.200149724                   | -1.200661455  |
| Skewness           | 0.000381861                           | 0.00013691                    | 0.643645529                    | 0.000134412                    | 5.64198E-05   |
| Range              | 25335.2145                            | 0.49898                       | 0.000507763                    | 0.169526                       | 0.63734       |
| Minimum            | 19.4855                               | 1.00024                       | 9.00566E-05                    | 0.500164                       | 0.68879       |
| Maximum            | 25354.7                               | 1.49922                       | 0.00059782                     | 0.66969                        | 1.32613       |
| Sum                | 11429960.86                           | 1125.002                      | 0.241980407                    | 526.501731                     | 906.75872     |
| Count              | 900                                   | 900                           | 900                            | 900                            | 900           |
| 75%                | 19050.9                               | 1.37578                       | 0.000373669                    | 0.627667                       | 1.16822       |
| 25%                | 6350.7                                | 1.12538                       | 0.00014545                     | 0.542576                       | 0.848063      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 2000.00 square meters H-3 5.000E-01  
 Thickness: 0.20 meters  
 Cover Depth: 0.00 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 2.500E+01 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 2.017E-10 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00  
 M(t): 0.000E+00 0.000E+00 8.066E-12 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00

Maximum TDOSE(t): 1.911E-04 mrem/yr at t = 1.422 ñ 0.003 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.422E+00 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground    | Inhalation | Radon     | Plant     | Meat      | Milk      | Soil      |
|-------------------|-----------|------------|-----------|-----------|-----------|-----------|-----------|
|                   | mrem/yr   | mrem/yr    | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   |
| H-3               | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Total             | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.422E+00 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water     | Fish      | Radon     | Plant     | Meat      | Milk      | All Pathways* |
|-------------------|-----------|-----------|-----------|-----------|-----------|-----------|---------------|
|                   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr       |
| H-3               | 1.911E-04 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.911E-04     |
| Total             | 1.911E-04 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.911E-04     |

0\*Sum of all water independent and dependent pathways.

|                    | Saturated Zone Hydraulic Conductivity | Thickness of Unsaturated Zone | Evapotranspiration Coefficient | Runoff Coefficient | Saturated Zone Hydraulic Gradient | Density of Unsaturated Zone | Effective Porosity of Unsaturated Zone | Total Porosity of Unsaturated Zone | Well Pump Intake Depth | Precipitation |
|--------------------|---------------------------------------|-------------------------------|--------------------------------|--------------------|-----------------------------------|-----------------------------|--|------------------------------------|------------------------|---------------|
| Mean               | 12700 04309                           | 1 250028144                   | 0 585022528                    | 0 349999192        | 0 021499883                       | 1 599986411                 | 0 409993393                            | 0 454995153                        | 30 199618              | 1 007502112   |
| Standard Error     | 244 5700469                           | 0 004814399                   | 0 001636771                    | 0 000962869        | 0 00016369                        | 0 006160876                 | 0 002503563                            | 0 002022027                        | 0 3851603              | 0 006151884   |
| Median             | 12721.1                               | 1 249865                      | 0 5850845                      | 0 350099           | 0 02148935                        | 1 59981                     | 0 4101575                              | 0 4550315                          | 30 2062                | 1 00732       |
| Mode               | #N/A                                  | 1 46172                       | #N/A                           | 0 355635           | 0 0220943                         | 1 65905                     | #N/A                                   | 0 382189                           | #N/A                   | 1 12122       |
| Standard Deviation | 7337 101408                           | 0 144431978                   | 0 049103125                    | 0 028886055        | 0 004910709                       | 0 184826292                 | 0 075106895                            | 0 060660822                        | 11 554808              | 0 184556514   |
| Sample Variance    | 53833057 06                           | 0 020860596                   | 0 002411117                    | 0 000834404        | 2 41151E-05                       | 0 034160758                 | 0 005841046                            | 0 003679735                        | 133 51359              | 0 034061107   |
| Kurtosis           | -1 199961544                          | -1 199859597                  | -1 199911991                   | -1 200334777       | -1 200401045                      | -1 200390767                | -1 200012871                           | -1 199668332                       | -1 199391              | -1 199649603  |
| Skewness           | 0 000169254                           | -0 000235192                  | 9 756E-05                      | -0 000278642       | 0 00022789                        | -0 000374962                | -0 000912979                           | 0 000338694                        | -0 0003234             | 3 24491E-05   |
| Range              | 25338 4455                            | 0 49938                       | 0 169618                       | 0 099785           | 0 0169463                         | 0 63821                     | 0 259508                               | 0 209433                           | 39 9777                | 0 637928      |
| Minimum            | 16 2545                               | 1 00024                       | 0 500056                       | 0 300062           | 0 0130032                         | 1 28013                     | 0 280258                               | 0 35031                            | 10 2018                | 0 688062      |
| Maximum            | 25354 7                               | 1 49962                       | 0 669674                       | 0 399847           | 0 0299495                         | 1 91834                     | 0 539766                               | 0 559743                           | 50 1795                | 1 32599       |
| Sum                | 11430038 78                           | 1125 02533                    | 526 520275                     | 314 999273         | 19 3498946                        | 1439 98777                  | 368 994054                             | 409 495638                         | 27179 656              | 906 751901    |
| Count              | 900                                   | 900                           | 900                            | 900                | 900                               | 900                         | 900                                    | 900                                | 900                    | 900           |
| 75%                | 19050 9                               | 1 37578                       | 0 627564                       | 0 375098           | 0 0257757                         | 1.76025                     | 0 475007                               | 0 507574                           | 40 2847                | 1 16735       |
| 25%                | 6350 7                                | 1.12538                       | 0 542501                       | 0 325045           | 0 0172524                         | 1 44073                     | 0 345455                               | 0 402676                           | 20 2732                | 0 848176      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 2000.00 square meters Ni-63 5.000E-01  
 Thickness: 0.20 meters  
 Cover Depth: 0.00 meters

0  
 Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00  
 M(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00  
 0 Maximum TDOSE(t): 4.635E-23 mrem/yr at t = 4881 n years

0  
 Total Dose Contributions TDOSE(1,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 4.881E+03 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground<br>mrem/yr<br>fract. | Inhalation<br>mrem/yr<br>fract. | Radon<br>mrem/yr<br>fract. | Plant<br>mrem/yr<br>fract. | Meat<br>mrem/yr<br>fract. | Milk<br>mrem/yr<br>fract. | Soil<br>mrem/yr<br>fract. |
|-------------------|-----------------------------|---------------------------------|----------------------------|----------------------------|---------------------------|---------------------------|---------------------------|
| Ni-63             | 0.000E+00                   | 0.000E+00                       | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 0.000E+00                 |
| Total             | 0.000E+00                   | 0.000E+00                       | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 0.000E+00                 |

0  
 Total Dose Contributions TDOSE(1,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 4.881E+03 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water<br>mrem/yr<br>fract. | Fish<br>mrem/yr<br>fract. | Radon<br>mrem/yr<br>fract. | Plant<br>mrem/yr<br>fract. | Meat<br>mrem/yr<br>fract. | Milk<br>mrem/yr<br>fract. | All Pathways*<br>mrem/yr<br>fract. |
|-------------------|----------------------------|---------------------------|----------------------------|----------------------------|---------------------------|---------------------------|------------------------------------|
| Ni-63             | 4.635E-23                  | 1.000E-00                 | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 4.635E-23                          |
| Total             | 4.635E-23                  | 1.000E+00                 | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 4.635E-23                          |

0\*Sum of all water independent and dependent pathways.

|                    | Saturated Zone Hydraulic Conductivity | Evapotranspiration Coefficient | Saturated Zone Hydraulic Gradient | Well Pump Intake Depth | Precipitation |
|--------------------|---------------------------------------|--------------------------------|-----------------------------------|------------------------|---------------|
| Mean               | 12699.95651                           | 0.585000757                    | 0.021501543                       | 30.20045               | 1.007509689   |
| Standard Error     | 244.5834382                           | 0.001636623                    | 0.000163653                       | 0.3851205              | 0.006152711   |
| Median             | 12721.1                               | 0.585096                       | 0.02150845                        | 30.21155               | 1.007605      |
| Mode               | #N/A                                  | 0.53587                        | 0.0139442                         | 46.1394                | 1.02984       |
| Standard Deviation | 7337.503146                           | 0.049098687                    | 0.004909591                       | 11.553616              | 0.184581334   |
| Sample Variance    | 53838952.42                           | 0.002410681                    | 2.41041E-05                       | 133.48604              | 0.034070269   |
| Kurtosis           | -1.200124414                          | -1.200005172                   | -1.199835919                      | -1.2001501             | -1.200661455  |
| Skewness           | 0.000381861                           | 0.000133828                    | 0.000230335                       | 0.0001349              | 5.64198E-05   |
| Range              | 25335.2145                            | 0.169654                       | 0.0169618                         | 39.8882                | 0.63734       |
| Minimum            | 19.4855                               | 0.500082                       | 0.0130056                         | 10.2387                | 0.68879       |
| Maximum            | 25354.7                               | 0.669736                       | 0.0299674                         | 50.1269                | 1.32613       |
| Sum                | 11429960.86                           | 526.500681                     | 19.3513884                        | 27180.405              | 906.75872     |
| Count              | 900                                   | 900                            | 900                               | 900                    | 900           |
| 75%                | 19050.9                               | 0.627767                       | 0.0257564                         | 40.2392                | 1.16822       |
| 25%                | 6350.7                                | 0.54263                        | 0.0173015                         | 20.218                 | 0.848063      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 10000.00 square meters Pu-238 1.000E+00  
 Thickness: 2.00 meters  
 Cover Depth: 3.20 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 2.188E+00 9.331E+00 8.799E+00 7.136E+00 2.723E+00 7.751E-01 2.245E-03 1.355E-06  
 M(t): 0.000E+00 5.470E-01 2.333E+00 2.200E+00 1.784E+00 6.807E-01 1.938E-01 5.612E-04 3.387E-07  
 Maximum TDOSE(t): 9.544E+00 mrem/yr at t = 1.093E+00 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.093E+00 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground<br>mrem/yr<br>fract. | Inhalation<br>mrem/yr<br>fract. | Radon<br>mrem/yr<br>fract. | Plant<br>mrem/yr<br>fract. | Meat<br>mrem/yr<br>fract. | Milk<br>mrem/yr<br>fract. | Soil<br>mrem/yr<br>fract. |
|-------------------|-----------------------------|---------------------------------|----------------------------|----------------------------|---------------------------|---------------------------|---------------------------|
| Pu-238            | 0.000E+00                   | 0.000E+00                       | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 0.000E+00                 |
| Total             | 0.000E+00                   | 0.000E+00                       | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 0.000E+00                 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.093E+00 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water<br>mrem/yr<br>fract. | Fish<br>mrem/yr<br>fract. | Radon<br>mrem/yr<br>fract. | Plant<br>mrem/yr<br>fract. | Meat<br>mrem/yr<br>fract. | Milk<br>mrem/yr<br>fract. | All Pathways*<br>mrem/yr<br>fract. |
|-------------------|----------------------------|---------------------------|----------------------------|----------------------------|---------------------------|---------------------------|------------------------------------|
| Pu-238            | 9.544E+00                  | 0.000E+00                 | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 9.544E+00                          |
| Total             | 9.544E+00                  | 0.000E+00                 | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 9.544E+00                          |

\*Sum of all water independent and dependent pathways.

|                    | Saturated Zone Hydraulic Conductivity | Thickness of Unsaturated Zone | Contaminated Zone Erosion Rate | Evapotranspiration Coefficient | Runoff Coefficient | Saturated Zone Hydraulic Gradient | Well Pump Intake Depth | Precipitation | Plant Transfer Factor for Np |
|--------------------|---------------------------------------|-------------------------------|--------------------------------|--------------------------------|--------------------|-----------------------------------|------------------------|---------------|------------------------------|
| Mean               | 12699.96279                           | 1.25000322                    | 0.000268857                    | 0.585010094                    | 0.350005806        | 0.021500638                       | 30.2013841             | 1.007477948   | 0.030388272                  |
| Standard Error     | 244.5773892                           | 0.004814214                   | 4.77346E-06                    | 0.00163666                     | 0.000962772        | 0.000163672                       | 0.38515617             | 0.006152422   | 0.001124475                  |
| Median             | 12697.55                              | 1.249805                      | 0.000232267                    | 0.585196                       | 0.3499965          | 0.0215066                         | 30.2297                | 1.007175      | 0.0200578                    |
| Mode               | 12101.2                               | 1.41056                       | #N/A                           | 0.647449                       | #N/A               | 0.0178114                         | 15.5447                | 1.1521        | #N/A                         |
| Standard Deviation | 7337.321675                           | 0.144426414                   | 0.000143204                    | 0.049099809                    | 0.028883145        | 0.004910165                       | 11.5546852             | 0.184572654   | 0.033734236                  |
| Sample Variance    | 53836289.36                           | 0.020858989                   | 2.05073E-08                    | 0.002410791                    | 0.000834236        | 2.41097E-05                       | 133.51075              | 0.034067064   | 0.001137999                  |
| Kurtosis           | -1.200119616                          | -1.199865705                  | -0.743648267                   | -1.200395077                   | -1.200704725       | -1.200381941                      | -1.2001298             | -1.199892558  | 23.06462523                  |
| Skewness           | 0.000355026                           | 9.84808E-06                   | 0.643870607                    | -2.29934E-05                   | 0.000367082        | -0.000206435                      | -0.0004132             | -0.00042048   | 3.732161591                  |
| Range              | 25335.9465                            | 0.49931                       | 0.000508388                    | 0.169526                       | 0.099919           | 0.016959                          | 39.9231                | 0.638449      | 0.383685247                  |
| Minimum            | 18.7535                               | 1.00024                       | 9.01349E-05                    | 0.500164                       | 0.300001           | 0.0130158                         | 10.2397                | 0.688031      | 0.000545753                  |
| Maximum            | 25354.7                               | 1.49955                       | 0.000598523                    | 0.66969                        | 0.39992            | 0.0299748                         | 50.1628                | 1.32648       | 0.384231                     |
| Sum                | 11429966.51                           | 1125.00029                    | 0.241971669                    | 526.509085                     | 315.005225         | 19.3505742                        | 27181.2457             | 906.730153    | 27.34944514                  |
| Count              | 900                                   | 900                           | 900                            | 900                            | 900                | 900                               | 900                    | 900           | 900                          |
| 75%                | 19092.3                               | 1.37552                       | 0.000373669                    | 0.627667                       | 0.375025           | 0.0257601                         | 40.2011                | 1.16803       | 0.0374402                    |
| 25%                | 6350.7                                | 1.12563                       | 0.00014482                     | 0.542576                       | 0.325049           | 0.0172695                         | 20.2245                | 0.848285      | 0.010859                     |



Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 2000.00 square meters Pu-239 5.000E-01  
 Thickness: 0.20 meters  
 Cover Depth: 0.00 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 5.313E-10 5.696E-10 2.101E-03 0.000E+00  
 M(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 1.328E-10 1.424E-10 5.252E-04 0.000E+00  
 Maximum TDOSE(t): 3.133E-02 mrem/yr at t = 756.2 years

Total Dose Contributions TDOSE(1,p,t) for Individual Radionuclides (1) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 7.562E+02 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground<br>mrem/yr<br>fract. | Inhalation<br>mrem/yr<br>fract. | Radon<br>mrem/yr<br>fract. | Plant<br>mrem/yr<br>fract. | Meat<br>mrem/yr<br>fract. | Milk<br>mrem/yr<br>fract. | Soil<br>mrem/yr<br>fract. |
|-------------------|-----------------------------|---------------------------------|----------------------------|----------------------------|---------------------------|---------------------------|---------------------------|
| Pu-239            | 0.000E+00                   | 0.000E+00                       | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 0.000E+00                 |
| Total             | 0.000E+00                   | 0.000E+00                       | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 0.000E+00                 |

Total Dose Contributions TDOSE(1,p,t) for Individual Radionuclides (1) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 7.562E+02 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water<br>mrem/yr<br>fract. | Fish<br>mrem/yr<br>fract. | Radon<br>mrem/yr<br>fract. | Plant<br>mrem/yr<br>fract. | Meat<br>mrem/yr<br>fract. | Milk<br>mrem/yr<br>fract. | All Pathways*<br>mrem/yr<br>fract. |
|-------------------|----------------------------|---------------------------|----------------------------|----------------------------|---------------------------|---------------------------|------------------------------------|
| Pu-239            | 3.133E-02                  | 0.000E+00                 | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 3.133E-02                          |
| Total             | 3.133E-02                  | 0.000E+00                 | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 3.133E-02                          |

\*Sum of all water independent and dependent pathways.

|                    | Saturated Zone Hydraulic Conductivity | Thickness of Unsaturated Zone | Evapotranspiration Coefficient | Runoff Coefficient | Saturated Zone Hydraulic Gradient | Effective Porosity of Unsaturated Zone | Well Pump Intake Depth | Precipitation |
|--------------------|---------------------------------------|-------------------------------|--------------------------------|--------------------|-----------------------------------|--|------------------------|---------------|
| Mean               | 12698.50153                           | 1.2500124                     | 0.585005496                    | 0.350000028        | 0.021500324                       | 0.410006522                            | 30.2015979             | 1.007501901   |
| Standard Error     | 244.5839508                           | 0.004813444                   | 0.001636863                    | 0.000962736        | 0.000163686                       | 0.002503226                            | 0.38509579             | 0.006151779   |
| Median             | 12715.55                              | 1.250245                      | 0.5849275                      | 0.350001           | 0.02148865                        | 0.4100965                              | 30.2154                | 1.00773       |
| Mode               | #N/A                                  | 1.0432                        | 0.565466                       | 0.378622           | #N/A                              | 0.422049                               | #N/A                   | 1.31383       |
| Standard Deviation | 7337.518523                           | 0.144403315                   | 0.049105883                    | 0.028882065        | 0.004910567                       | 0.075096787                            | 11.5528737             | 0.184553372   |
| Sample Variance    | 53839178.08                           | 0.020852317                   | 0.002411388                    | 0.000834174        | 2.41137E-05                       | 0.005639527                            | 133.468891             | 0.034059947   |
| Kurtosis           | -1.200184658                          | -1.19985556                   | -1.20010564                    | -1.199960807       | -1.200302418                      | -1.200686978                           | -1.20050378            | -1.200385121  |
| Skewness           | 0.000106211                           | -0.000594614                  | 0.000137047                    | 0.00025033         | 0.000875268                       | 0.000259907                            | -7.1625E-05            | 4.61703E-05   |
| Range              | 25332.8955                            | 0.4987                        | 0.169619                       | 0.09984            | 0.0169774                         | 0.259522                               | 39.9414                | 0.637146      |
| Minimum            | 27.6045                               | 1.00024                       | 0.500166                       | 0.300097           | 0.013021                          | 0.280196                               | 10.2397                | 0.689074      |
| Maximum            | 25360.5                               | 1.49894                       | 0.669785                       | 0.399937           | 0.0299984                         | 0.539718                               | 50.1811                | 1.32622       |
| Sum                | 11428651.38                           | 1125.01116                    | 526.504946                     | 315.000025         | 19.3502913                        | 369.00587                              | 27181.4381             | 906.751711    |
| Count              | 900                                   | 900                           | 900                            | 900                | 900                               | 900                                    | 900                    | 900           |
| 75%                | 19092.3                               | 1.37516                       | 0.627564                       | 0.375005           | 0.0257674                         | 0.475039                               | 40.2011                | 1.16807       |
| 25%                | 6350.7                                | 1.12502                       | 0.542685                       | 0.325045           | 0.0172583                         | 0.345219                               | 20.2298                | 0.847987      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 2000.00 square meters Pu-241 5.000E-01  
 Thickness: 0.20 meters  
 Cover Depth: 0.00 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 1.308E-12 3.921E-12 8.929E-12 2.083E-15  
 M(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 3.270E-13 9.803E-13 2.232E-12 5.206E-16  
 Maximum TDOSE(t): 4.969E-08 mrem/yr at t = 1.664E+03 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.664E+03 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground           | Inhalation       | Radon            | Plant            | Meat             | Milk             | Soil             |
|-------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
| Pu-241            | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 |
| Total             | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.664E+03 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water            | Fish             | Radon            | Plant            | Meat             | Milk             | All Pathways*    |
|-------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
| Pu-241            | 4.969E-08 1.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 4.969E-08 1.0000 |
| Total             | 4.969E-08 1.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 4.969E-08 1.0000 |

\*Sum of all water independent and dependent pathways.

|                           | Thickness of<br>Unsaturated Zone | Evapotranspiration<br>Coefficient | Precipitation | Plant Transfer<br>Factor for Np |
|---------------------------|----------------------------------|-----------------------------------|---------------|---------------------------------|
| <b>Mean</b>               | 1.249976433                      | 0.585005068                       | 1.007536886   | 0.030273173                     |
| <b>Standard Error</b>     | 0.004814497                      | 0.001636417                       | 0.006152487   | 0.001089522                     |
| <b>Median</b>             | 1.250305                         | 0.5851455                         | 1.007415      | 0.0200409                       |
| <b>Mode</b>               | 1.26404                          | 0.514688                          | 1.16652       | 0.0105762                       |
| <b>Standard Deviation</b> | 0.144434905                      | 0.049092505                       | 0.184574618   | 0.032685647                     |
| <b>Sample Variance</b>    | 0.020861442                      | 0.002410074                       | 0.034067789   | 0.001068352                     |
| <b>Kurtosis</b>           | -1.200060028                     | -1.200087396                      | -1.200376148  | 14.76018554                     |
| <b>Skewness</b>           | -9.886E-05                       | -0.000498985                      | 0.000291325   | 3.185622401                     |
| <b>Range</b>              | 0.49924                          | 0.169557                          | 0.637997      | 0.28632021                      |
| <b>Minimum</b>            | 1.00054                          | 0.500082                          | 0.688623      | 0.00111379                      |
| <b>Maximum</b>            | 1.49978                          | 0.669639                          | 1.32662       | 0.287434                        |
| <b>Sum</b>                | 1124.97879                       | 526.504561                        | 906.783197    | 27.24585613                     |
| <b>Count</b>              | 900                              | 900                               | 900           | 900                             |
| <b>75%</b>                | 1.37583                          | 0.627556                          | 1.16749       | 0.0371863                       |
| <b>25%</b>                | 1.12501                          | 0.542507                          | 0.848022      | 0.0108159                       |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 2000.00 square meters Sr-90 5.000E-01  
 Thickness: 0.20 meters  
 Cover Depth: 0.00 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 2.667E-03 5.345E-10 6.351E-20 0.000E+00 0.000E+00  
 M(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 6.667E-04 1.336E-10 1.588E-20 0.000E+00 0.000E+00  
 Maximum TDOSE(t): 8.185E-03 mrem/yr at t = 40.94 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 4.094E+01 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground<br>mrem/yr<br>fract. | Inhalation<br>mrem/yr<br>fract. | Radon<br>mrem/yr<br>fract. | Plant<br>mrem/yr<br>fract. | Meat<br>mrem/yr<br>fract. | Milk<br>mrem/yr<br>fract. | Soil<br>mrem/yr<br>fract. |
|-------------------|-----------------------------|---------------------------------|----------------------------|----------------------------|---------------------------|---------------------------|---------------------------|
| Sr-90             | 0.000E+00                   | 0.000E+00                       | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 0.000E+00                 |
| Total             | 0.000E+00                   | 0.000E+00                       | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 0.000E+00                 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 4.094E+01 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water<br>mrem/yr<br>fract. | Fish<br>mrem/yr<br>fract. | Radon<br>mrem/yr<br>fract. | Plant<br>mrem/yr<br>fract. | Meat<br>mrem/yr<br>fract. | Milk<br>mrem/yr<br>fract. | All Pathways*<br>mrem/yr<br>fract. |
|-------------------|----------------------------|---------------------------|----------------------------|----------------------------|---------------------------|---------------------------|------------------------------------|
| Sr-90             | 8.185E-03                  | 1.000E+00                 | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 8.185E-03                          |
| Total             | 8.185E-03                  | 1.000E+00                 | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 8.185E-03                          |

\*Sum of all water independent and dependent pathways.

|                    | Contaminated Zone<br>b Parameter | Contaminated Zone<br>Hydraulic Conductivity | Kd of C-14 in<br>Contaminated Zone | Kd of C-14 in<br>Unsaturated Zone |
|--------------------|----------------------------------|---|------------------------------------|-----------------------------------|
| Mean               | 5.584855022                      | 2273.224353                                 | 2.50028841                         | 2.4999239                         |
| Standard Error     | 0.029561012                      | 162.1294134                                 | 0.048141507                        | 0.048132853                       |
| Median             | 5.58686                          | 96.8193                                     | 2.499335                           | 2.500045                          |
| Mode               | #N/A                             | #N/A  | 2.18993                            | 1.21367                           |
| Standard Deviation | 0.886830351                      | 4863.882403                                 | 1.444245199                        | 1.443985579                       |
| Sample Variance    | 0.786468072                      | 23657352.03                                 | 2.085844194                        | 2.085094353                       |
| Kurtosis           | -1.200059915                     | 7.090667357                                 | -1.200377179                       | -1.200050044                      |
| Skewness           | -0.0001002                       | 2.729641196                                 | 0.000289718                        | -4.24237E-05                      |
| Range              | 3.06538                          | 24804.43605                                 | 4.99212534                         | 4.9868438                         |
| Minimum            | 4.05329                          | 0.36395                                     | 0.00487466                         | 0.0040262                         |
| Maximum            | 7.11867                          | 24804.8                                     | 4.997                              | 4.99087                           |
| Sum                | 5026.36952                       | 2045901.918                                 | 2250.259569                        | 2249.93151                        |
| Count              | 900                              | 900   | 900                                | 900                               |
| Largest(1)         | 7.11867                          | 24804.8                                     | 4.997                              | 4.99087                           |
| Smallest(1)        | 4.05329                          | 0.36395                                     | 0.00487466                         | 0.0040262                         |
| 75%                | 6.3576                           | 1566.35                                     | 3.7519                             | 3.75027                           |
| 25%                | 4.81755                          | 5.89446                                     | 1.25213                            | 1.25225                           |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 2000.00 square meters Am-241 1.000E+00  
 Thickness: 2.00 meters  
 Cover Depth: 1.20 meters

0  
 Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 4.040E-08 1.859E-07 9.846E-04 4.039E-08  
 M(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 1.010E-08 4.647E-08 2.461E-04 1.010E-08  
 0\*Maximum TDOSE(t): 1.294E-03 mrem/yr at t = 1.459E+03 years

0  
 Total Dose Contributions TDOSE(1,p,t) for Individual Radionuclides (1) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.459E+03 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground<br>mrem/yr<br>fract. | Inhalation<br>mrem/yr<br>fract. | Radon<br>mrem/yr<br>fract. | Plant<br>mrem/yr<br>fract. | Meat<br>mrem/yr<br>fract. | Milk<br>mrem/yr<br>fract. | Soil<br>mrem/yr<br>fract. |
|-------------------|-----------------------------|---------------------------------|----------------------------|----------------------------|---------------------------|---------------------------|---------------------------|
| Am-241            | 0.000E+00                   | 0.000E+00                       | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 0.000E+00                 |
| Total             | 0.000E+00                   | 0.000E+00                       | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 0.000E+00                 |

0  
 Total Dose Contributions TDOSE(1,p,t) for Individual Radionuclides (1) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.459E+03 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water<br>mrem/yr<br>fract. | Fish<br>mrem/yr<br>fract. | Radon<br>mrem/yr<br>fract. | Plant<br>mrem/yr<br>fract. | Meat<br>mrem/yr<br>fract. | Milk<br>mrem/yr<br>fract. | All Pathways*<br>mrem/yr<br>fract. |
|-------------------|----------------------------|---------------------------|----------------------------|----------------------------|---------------------------|---------------------------|------------------------------------|
| Am-241            | 1.294E-03                  | 0.000E+00                 | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 1.294E-03                          |
| Total             | 1.294E-03                  | 0.000E+00                 | 0.000E+00                  | 0.000E+00                  | 0.000E+00                 | 0.000E+00                 | 1.294E-03                          |

0\*Sum of all water independent and dependent pathways.

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 2000.00 square meters C-14 1.000E+00  
 Thickness: 2.00 meters  
 Cover Depth: 1.20 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 6.130E-01 9.550E-02 1.844E-05 2.638E-10 0.000E+00 0.000E+00  
 M(t): 0.000E+00 0.000E+00 0.000E+00 1.532E-01 2.388E-02 4.611E-06 6.594E-11 0.000E+00 0.000E+00  
 Maximum TDOSE(t): 7.106E-01 mrem/yr at t = 8.01E+00 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 8.010E+00 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-Nuclide | Ground    | Inhalation | Radon     | Plant     | Meat      | Milk      | Soil      |
|---------------|-----------|------------|-----------|-----------|-----------|-----------|-----------|
|               | mrem/yr   | mrem/yr    | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   |
| C-14          | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Total         | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 8.010E+00 years  
 Water Dependent Pathways

| Radio-Nuclide | Water     | Fish      | Radon     | Plant     | Meat      | Milk      | All Pathways* |
|---------------|-----------|-----------|-----------|-----------|-----------|-----------|---------------|
|               | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr       |
| C-14          | 7.106E-01 | 1.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 7.106E-01     |
| Total         | 7.106E-01 | 1.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 7.106E-01     |

\*Sum of all water independent and dependent pathways.  
 ORESALC.EXE execution time = 2.09 seconds



|                           | Thickness of Unsaturated Zone | Evapotranspiration Coefficient | Runoff Coefficient | Density of Unsaturated Zone | Effective Porosity of Unsaturated Zone | Total Porosity of Unsaturated Zone | Precipitation |
|---------------------------|-------------------------------|--------------------------------|--------------------|-----------------------------|--|------------------------------------|---------------|
| <b>Mean</b>               | 1.249999211                   | 0.584991104                    | 0.350005479        | 1.599991267                 | 0.409989919                            | 0.455002578                        | 1.007488272   |
| <b>Standard Error</b>     | 0.00481466                    | 0.001636747                    | 0.00096273         | 0.006161712                 | 0.002503686                            | 0.002021635                        | 0.006153245   |
| <b>Median</b>             | 1.250175                      | 0.585038                       | 0.350015           | 1.60075                     | 0.409732                               | 0.4548075                          | 1.007535      |
| <b>Mode</b>               | 1.37837                       | 0.573988                       | 0.349318           | 1.86433                     | #N/A                                   | 0.544867                           | 1.30224       |
| <b>Standard Deviation</b> | 0.144439798                   | 0.049102425                    | 0.028881898        | 0.184851368                 | 0.075110588                            | 0.060649047                        | 0.184597359   |
| <b>Sample Variance</b>    | 0.020862855                   | 0.002411048                    | 0.000834164        | 0.034170028                 | 0.0056416                              | 0.003678307                        | 0.034076185   |
| <b>Kurtosis</b>           | -1.20047105                   | -1.199417592                   | -1.199576162       | -1.199980454                | -1.200826746                           | -1.200016993                       | -1.199911705  |
| <b>Skewness</b>           | -0.000347952                  | 4.72965E-05                    | 0.000215723        | -0.000536939                | 0.000534848                            | -6.72923E-05                       | 8.59276E-06   |
| <b>Range</b>              | 0.498                         | 0.169557                       | 0.099847           | 0.63936                     | 0.259519                               | 0.209435                           | 0.637726      |
| <b>Minimum</b>            | 1.0012                        | 0.500082                       | 0.300097           | 1.28022                     | 0.280228                               | 0.350306                           | 0.688634      |
| <b>Maximum</b>            | 1.4992                        | 0.669639                       | 0.399944           | 1.91958                     | 0.539747                               | 0.559741                           | 1.32636       |
| <b>Sum</b>                | 1124.99929                    | 526.491994                     | 315.004931         | 1439.99214                  | 368.990927                             | 409.50232                          | 906.739445    |
| <b>Count</b>              | 900                           | 900                            | 900                | 900                         | 900                                    | 900                                | 900           |
| <b>75%</b>                | 1.37501                       | 0.627767                       | 0.375017           | 1.76015                     | 0.475349                               | 0.507625                           | 1.16727       |
| <b>25%</b>                | 1.12501                       | 0.542662                       | 0.325215           | 1.44029                     | 0.345127                               | 0.402741                           | 0.848089      |

|                           | Thickness of<br>Unsaturated Zone | Evapotranspiration Coefficient | Precipitation | Plant Transfer Factor<br>for Gd |
|---------------------------|----------------------------------|--------------------------------|---------------|---------------------------------|
| <b>Mean</b>               | 1.249976433                      | 0.585005068                    | 1.007536886   | 0.003626544                     |
| <b>Standard Error</b>     | 0.004814497                      | 0.001636417                    | 0.006152487   | 0.000166913                     |
| <b>Median</b>             | 1.250305                         | 0.5851455                      | 1.007415      | 0.002009285                     |
| <b>Mode</b>               | 1.26404                          | 0.514688                       | 1.16652       | #N/A                            |
| <b>Standard Deviation</b> | 0.144434905                      | 0.049092505                    | 0.184574618   | 0.005007389                     |
| <b>Sample Variance</b>    | 0.020861442                      | 0.002410074                    | 0.034067789   | 2.50739E-05                     |
| <b>Kurtosis</b>           | -1.200060028                     | -1.200087396                   | -1.200376148  | 23.29687677                     |
| <b>Skewness</b>           | -9.886E-05                       | -0.000498985                   | 0.000291325   | 4.051623421                     |
| <b>Range</b>              | 0.49924                          | 0.169557                       | 0.637997      | 0.048892967                     |
| <b>Minimum</b>            | 1.00054                          | 0.500082                       | 0.688623      | 6.28333E-05                     |
| <b>Maximum</b>            | 1.49978                          | 0.669639                       | 1.32662       | 0.0489558                       |
| <b>Sum</b>                | 1124.97879                       | 526.504561                     | 906.783197    | 3.263889993                     |
| <b>Count</b>              | 900                              | 900                            | 900           | 900                             |
| <b>75%</b>                | 1.37583                          | 0.627556                       | 1.16749       | 0.00421624                      |
| <b>25%</b>                | 1.12501                          | 0.542507                       | 0.848022      | 0.000959162                     |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 2000.00 square meters Eu-152 1.000E+00  
 Thickness: 2.00 meters  
 Cover Depth: 1.20 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 2.039E-16  
 M(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 5.099E-17  
 Maximum TDOSE(t): 4.205E-15 mrem/yr at t = 2358 years

Total Dose Contributions TDOSE(1,p,t) for Individual Radionuclides (1) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 2.358E+03 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground    | Inhalation | Radon     | Plant  | Meat      | Milk   | Soil      |        |
|-------------------|-----------|------------|-----------|--------|-----------|--------|-----------|--------|
| Nuclide           | mrem/yr   | fract.     | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. |
| Eu-152            | 0.000E+00 | 0.0000     | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total             | 0.000E+00 | 0.0000     | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(1,p,t) for Individual Radionuclides (1) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 2.358E+03 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water     | Fish   | Radon     | Plant  | Meat      | Milk   | All Pathways* |        |
|-------------------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
| Nuclide           | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       | fract. |
| Eu-152            | 4.205E-15 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 4.205E-15     | 1.0000 |
| Total             | 4.205E-15 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 4.205E-15     | 1.0000 |

\*Sum of all water independent and dependent pathways.  
 ORESALC.EXE execution time = 1.18 seconds

|                    | Density of Contaminated Zone | Thickness of Unsaturated Zone | Contaminated Zone B | Contaminated Zone Hydraulic conductivity | contaminated Zone Total Porosity | Evapotranspiration coefficient | Hydraulic Conductivity of Unsaturated Zone | Precipitation | Kd of H-3 in contaminated Zone | Kd of H-3 in Unsaturated Zone |
|--------------------|------------------------------|-------------------------------|---------------------|--|----------------------------------|--------------------------------|--|---------------|--------------------------------|-------------------------------|
| Mean               | 1 599996578                  | 1 250028144                   | 5 585407            | 2275 842169                              | 0 454998569                      | 0 584996357                    | 2273 50337                                 | 1 007485231   | 0 249995232                    | 0 250001689                   |
| Standard Error     | 0 006162487                  | 0 004814399                   | 0 02955814          | 162 4461704                              | 0 002022057                      | 0 001636484                    | 162 1484073                                | 0 006152737   | 0 004814503                    | 0 004813681                   |
| Median             | 1 600525                     | 1 249865                      | 5 58653             | 96 96265                                 | 0 4548685                        | 0 5849485                      | 96 55985                                   | 1 007595      | 0 2500775                      | 0 249859                      |
| Mode               | 1 3887                       | 1 46172                       | #N/A                | #N/A                                     | 0 462342                         | 0 639223                       | #N/A                                       | 1 13282       | #N/A                           | 0 338982                      |
| Standard Deviation | 0 184874595                  | 0 144431978                   | 0 88674424          | 4873 385112                              | 0 060661709                      | 0 04909453                     | 4864 452218                                | 0 184582097   | 0 144435085                    | 0 144410439                   |
| Sample Variance    | 0 034178616                  | 0 020860596                   | 0 78631535          | 23749882 45                              | 0 003679843                      | 0 002410273                    | 23662895 38                                | 0 034070551   | 0 020861494                    | 0 020854375                   |
| Kurtosis           | -1 1999578                   | -1 199859597                  | -1 1999119          | 7.164108893                              | -1 200402455                     | -1 200390868                   | 7 120653377                                | -1 199667477  | -1.199391216                   | -1 19965048                   |
| Skewness           | 0 000166573                  | -0 000235192                  | 9 7321E-05          | 2 737809968                              | 0 000227049                      | -0 000374024                   | 2 73256335                                 | 0 000338058   | -0 000324204                   | 3 23358E-05                   |
| Range              | 0 63846                      | 0 49938                       | 3 06309             | 24969 93547                              | 0 209337                         | 0 169525                       | 25145 43397                                | 0 637277      | 0 499721952                    | 0 499164125                   |
| Minimum            | 1 2804                       | 1 00024                       | 4 05102             | 0 364529                                 | 0 350039                         | 0 500035                       | 0 366031                                   | 0 688943      | 2 20483E-05                    | 0 000048875                   |
| Maximum            | 1 91886                      | 1 49962                       | 7 11411             | 24970 3                                  | 0 559376                         | 0 66956                        | 25145 8                                    | 1 32622       | 0 499744                       | 0 499213                      |
| Sum                | 1439 99692                   | 1125 02533                    | 5026 8663           | 2048257 952                              | 409 498712                       | 526 496721                     | 2046153 033                                | 906 736708    | 224 9957087                    | 225 0015199                   |
| Count              | 900                          | 900                           | 900                 | 900                                      | 900                              | 900                            | 900  | 900           | 900                            | 900                           |
| Largest(1)         | 1 91886                      | 1 49962                       | 7 11411             | 24970 3                                  | 0 559376                         | 0 66956                        | 25145 8                                    | 1 32622       | 0 499744                       | 0 499213                      |
| Smallest(1)        | 1 2804                       | 1 00024                       | 4 05102             | 0 364529                                 | 0 350039                         | 0 500035                       | 0 366031                                   | 0 688943      | 2 20483E-05                    | 0 000048875                   |
| 75%                | 1 76002                      | 1 37578                       | 6 35366             | 1577 81                                  | 0 507817                         | 0 627567                       | 1561 13                                    | 1.16748       | 0 376059                       | 0 375077                      |
| 25%                | 1 44001                      | 1.12538                       | 4 81751             | 5 92129                                  | 0 40253                          | 0 542695                       | 6 00783                                    | 0 848285      | 0 125915                       | 0.125333                      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 2000.00 square meters H-3 1.000E+00  
 Thickness: 2.00 meters  
 Cover Depth: 1.20 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 3.996E-02 7.361E-04 4.694E-10 0.000E+00 0.000E+00 0.000E+00 0.000E+00  
 M(t): 0.000E+00 0.000E+00 9.990E-03 1.840E-04 1.174E-10 0.000E+00 0.000E+00 0.000E+00 0.000E+00  
 Maximum TDOSE(t): 1.154E-01 mrem/yr at t = 1.154E+00 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.154E+00 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground    | Inhalation | Radon     | Plant     | Meat      | Milk      | Soil      |
|-------------------|-----------|------------|-----------|-----------|-----------|-----------|-----------|
|                   | mrem/yr   | mrem/yr    | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   |
| H-3               | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Total             | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.154E+00 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water     | Fish      | Radon     | Plant     | Meat      | Milk      | All Pathways* |
|-------------------|-----------|-----------|-----------|-----------|-----------|-----------|---------------|
|                   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr       |
| H-3               | 1.154E-01 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.154E-01     |
| Total             | 1.154E-01 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.154E-01     |

\*Sum of all water independent and dependent pathways.  
 ORESALC.EXE execution time = 2.29 seconds

|                           | Thickness of     |                                |                    |               |
|---------------------------|------------------|--------------------------------|--------------------|---------------|
|                           | Unzaturated Zone | Evapotranspiration Coefficient | Runoff Coefficient | Precipitation |
| <b>Mean</b>               | 1.249976433      | 0.585005068                    | 0.350005763        | 1.007490222   |
| <b>Standard Error</b>     | 0.004814497      | 0.001636417                    | 0.00096283         | 0.006151376   |
| <b>Median</b>             | 1.250305         | 0.5851455                      | 0.3499865          | 1.007505      |
| <b>Mode</b>               | 1.26404          | 0.514688                       | 0.338509           | 1.0195        |
| <b>Standard Deviation</b> | 0.144434905      | 0.049092505                    | 0.028884906        | 0.184541287   |
| <b>Sample Variance</b>    | 0.020861442      | 0.002410074                    | 0.000834338        | 0.034055486   |
| <b>Kurtosis</b>           | -1.200060028     | -1.200087396                   | -1.200378505       | -1.200051096  |
| <b>Skewness</b>           | -9.886E-05       | -0.000498985                   | 0.000287687        | -4.28343E-05  |
| <b>Range</b>              | 0.49924          | 0.169557                       | 0.099843           | 0.637315      |
| <b>Minimum</b>            | 1.00054          | 0.500082                       | 0.300097           | 0.688515      |
| <b>Maximum</b>            | 1.49978          | 0.669639                       | 0.39994            | 1.32583       |
| <b>Sum</b>                | 1124.97879       | 526.504561                     | 315.005187         | 906.7412      |
| <b>Count</b>              | 900              | 900                            | 900                | 900           |
| <b>75%</b>                | 1.37583          | 0.627556                       | 0.375038           | 1.16728       |
| <b>25%</b>                | 1.12501          | 0.542507                       | 0.325043           | 0.848037      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 2000.00 square meters N1-63 1.000E+00  
 Thickness: 2.00 meters  
 Cover Depth: 1.20 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00  
 M(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00  
 Maximum TDOSE(t): 7.108E-19 mrem/yr at t = 4616.59 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 4.616E+03 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-Nuclide | Ground    | Inhalation | Radon     | Plant  | Meat      | Milk   | Soil      |
|---------------|-----------|------------|-----------|--------|-----------|--------|-----------|
|               | mrem/yr   | fract.     | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   |
| N1-63         | 0.000E+00 | 0.0000     | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 |
| Total         | 0.000E+00 | 0.0000     | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 4.616E+03 years  
 Water Dependent Pathways

| Radio-Nuclide | Water     | Fish   | Radon     | Plant  | Meat      | Milk   | All Pathways* |
|---------------|-----------|--------|-----------|--------|-----------|--------|---------------|
|               | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr   | fract. | mrem/yr       |
| N1-63         | 7.108E-19 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 7.108E-19     |
| Total         | 7.108E-19 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 7.108E-19     |

\*Sum of all water independent and dependent pathways.

|                    | Thickness of Unsaturated Zone | Evapotranspiration Coefficient | Runoff Coefficient | Density of Unsaturated Zone | Effective Porosity of Unsaturated Zone | Total Porosity of Unsaturated Zone | Precipitation |
|--------------------|-------------------------------|--------------------------------|--------------------|-----------------------------|--|------------------------------------|---------------|
| Mean               | 1.249999211                   | 0.584991104                    | 0.350005479        | 1.599991267                 | 0.409989919                            | 0.455002578                        | 1.007488272   |
| Standard Error     | 0.00481466                    | 0.001636747                    | 0.00096273         | 0.006161712                 | 0.002503686                            | 0.002021635                        | 0.006153245   |
| Median             | 1.250175                      | 0.585038                       | 0.350015           | 1.60075                     | 0.409732                               | 0.4548075                          | 1.007535      |
| Mode               | 1.37837                       | 0.573988                       | 0.349318           | 1.86433                     | #N/A                                   | 0.544867                           | 1.30224       |
| Standard Deviation | 0.144439798                   | 0.049102425                    | 0.028881898        | 0.184851368                 | 0.075110588                            | 0.060649047                        | 0.184597359   |
| Sample Variance    | 0.020862855                   | 0.002411048                    | 0.000834164        | 0.034170028                 | 0.0056416                              | 0.003678307                        | 0.034076185   |
| Kurtosis           | -1.20047105                   | -1.199417592                   | -1.199576162       | -1.199980454                | -1.200826746                           | -1.200016993                       | -1.199911705  |
| Skewness           | -0.000347952                  | 4.72965E-05                    | 0.000215723        | -0.000536939                | 0.000534848                            | -6.72923E-05                       | 8.59276E-06   |
| Range              | 0.498                         | 0.169557                       | 0.099847           | 0.63936                     | 0.259519                               | 0.209435                           | 0.637726      |
| Minimum            | 1.0012                        | 0.500082                       | 0.300097           | 1.28022                     | 0.280228                               | 0.350306                           | 0.688634      |
| Maximum            | 1.4992                        | 0.669639                       | 0.399944           | 1.91958                     | 0.539747                               | 0.559741                           | 1.32636       |
| Sum                | 1124.99929                    | 526.491994                     | 315.004931         | 1439.99214                  | 368.990927                             | 409.50232                          | 906.739445    |
| Count              | 900                           | 900                            | 900                | 900                         | 900                                    | 900                                | 900           |
| 75%                | 1.37501                       | 0.627767                       | 0.375017           | 1.76015                     | 0.475349                               | 0.507625                           | 1.16727       |
| 25%                | 1.12501                       | 0.542662                       | 0.325215           | 1.44029                     | 0.345127                               | 0.402741                           | 0.848089      |



Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 2000.00 square meters Pu-238 1.000E+00  
 Thickness: 2.00 meters  
 Cover Depth: 1.20 meters

0  
 Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 1.105E-03 7.018E-04 2.078E-03 1.062E-07  
 M(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 2.762E-04 1.754E-04 5.196E-04 2.655E-08  
 0\*Maximum TDOSE(t): 4.349E-01 mrem/yr at t = 391.2 in 0.8 years

0  
 Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 3.912E+02 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground           | Inhalation       | Radon            | Plant            | Meat             | Milk             | Soil             |
|-------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
|                   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   |
| Pu-238            | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 |
| Total             | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 |

0  
 Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 3.912E+02 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water            | Fish             | Radon            | Plant            | Meat             | Milk             | All Pathways*    |
|-------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
|                   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   |
| Pu-238            | 4.349E-01 1.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 4.349E-01 1.0000 |
| Total             | 4.349E-01 1.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 4.349E-01 1.0000 |

0\*Sum of all water independent and dependent pathways.

|                           | Thickness of Unsaturated Zone | Evapotranspiration Coefficient | Runoff Coefficient | Density of Unsaturated Zone | Effective Porosity of Unsaturated Zone | Total Porosity of Unsaturated Zone | Precipitation |
|---------------------------|-------------------------------|--------------------------------|--------------------|-----------------------------|--|------------------------------------|---------------|
| <b>Mean</b>               | 1 249999211                   | 0 584991104                    | 0 350005479        | 1 599991267                 | 0 409989919                            | 0 455002578                        | 1.007488272   |
| <b>Standard Error</b>     | 0 00481466                    | 0.001636747                    | 0 00096273         | 0 006161712                 | 0 002503686                            | 0 002021635                        | 0 006153245   |
| <b>Median</b>             | 1 250175                      | 0 585038                       | 0 350015           | 1 60075                     | 0 409732                               | 0 4548075                          | 1 007535      |
| <b>Mode</b>               | 1 37837                       | 0 573988                       | 0 349318           | 1 86433                     | #N/A                                   | 0 544867                           | 1.30224       |
| <b>Standard Deviation</b> | 0 144439798                   | 0.049102425                    | 0 028881898        | 0 184851368                 | 0 075110588                            | 0 060649047                        | 0 184597359   |
| <b>Sample Variance</b>    | 0 020862855                   | 0 002411048                    | 0 000834164        | 0 034170028                 | 0 0056416                              | 0 003678307                        | 0 034076185   |
| <b>Kurtosis</b>           | -1 20047105                   | -1.199417592                   | -1 199576162       | -1 199980454                | -1 200826746                           | -1 200016993                       | -1 199911705  |
| <b>Skewness</b>           | -0 000347952                  | 4 72965E-05                    | 0 000215723        | -0 000536939                | 0 000534848                            | -6 72923E-05                       | 8.59276E-06   |
| <b>Range</b>              | 0 498                         | 0 169557                       | 0.099847           | 0 63936                     | 0.259519                               | 0 209435                           | 0 637726      |
| <b>Minimum</b>            | 1.0012                        | 0 500082                       | 0.300097           | 1.28022                     | 0 280228                               | 0 350306                           | 0 688634      |
| <b>Maximum</b>            | 1.4992                        | 0 669639                       | 0.399944           | 1.91958                     | 0.539747                               | 0 559741                           | 1 32636       |
| <b>Sum</b>                | 1124 99929                    | 526 491994                     | 315.004931         | 1439 99214                  | 368 990927                             | 409 50232                          | 906 739445    |
| <b>Count</b>              | 900                           | 900                            | 900                | 900                         | 900                                    | 900                                | 900           |
| <b>75%</b>                | 1 37501                       | 0 627767                       | 0 375017           | 1 76015                     | 0 475349                               | 0.507625                           | 1.16727       |
| <b>25%</b>                | 1.12501                       | 0 542662                       | 0.325215           | 1.44029                     | 0.345127                               | 0 402741                           | 0 848089      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 2000.00 square meters Pu-239 1.000E+00  
 Thickness: 2.00 meters  
 Cover Depth: 1.20 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 1.645E-06 2.414E-06 6.009E+00 0.000E+00  
 M(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 4.114E-07 6.036E-07 1.502E+00 0.000E+00  
 Maximum TDOSE(t): 1.045E+01 mrem/yr at t = 391.4 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 3.914E+02 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-Nuclide | Ground           | Inhalation       | Radon            | Plant            | Meat             | Milk             | Soil             |
|---------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
|               | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   |
| Pu-239        | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 |
| Total         | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 3.914E+02 years  
 Water Dependent Pathways

| Radio-Nuclide | Water            | Fish             | Radon            | Plant            | Meat             | Milk             | All Pathways*    |
|---------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
|               | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   | mrem/yr fract.   |
| Pu-239        | 1.045E+01 1.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 1.045E+01 1.0000 |
| Total         | 1.045E+01 1.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 0.000E+00 0.0000 | 1.045E+01 1.0000 |

\*Sum of all water independent and dependent pathways.

|                           | Thickness of<br>Unsaturated Zone | Evapotranspiration<br>Coefficient | Precipitation | Plant Transfer<br>Factor for Np |
|---------------------------|----------------------------------|-----------------------------------|---------------|---------------------------------|
| <b>Mean</b>               | 1.249976433                      | 0.585005068                       | 1.007536886   | 0.030273173                     |
| <b>Standard Error</b>     | 0.004814497                      | 0.001636417                       | 0.006152487   | 0.001089522                     |
| <b>Median</b>             | 1.250305                         | 0.5851455                         | 1.007415      | 0.0200409                       |
| <b>Mode</b>               | 1.26404                          | 0.514688                          | 1.16652       | 0.0105762                       |
| <b>Standard Deviation</b> | 0.144434905                      | 0.049092505                       | 0.184574618   | 0.032685647                     |
| <b>Sample Variance</b>    | 0.020861442                      | 0.002410074                       | 0.034067789   | 0.001068352                     |
| <b>Kurtosis</b>           | -1.200060028                     | -1.200087396                      | -1.200376148  | 14.76018554                     |
| <b>Skewness</b>           | -9.886E-05                       | -0.000498985                      | 0.000291325   | 3.185622401                     |
| <b>Range</b>              | 0.49924                          | 0.169557                          | 0.637997      | 0.28632021                      |
| <b>Minimum</b>            | 1.00054                          | 0.500082                          | 0.688623      | 0.00111379                      |
| <b>Maximum</b>            | 1.49978                          | 0.669639                          | 1.32662       | 0.287434                        |
| <b>Sum</b>                | 1124.97879                       | 526.504561                        | 906.783197    | 27.24585613                     |
| <b>Count</b>              | 900                              | 900                               | 900           | 900                             |
| <b>75%</b>                | 1.37583                          | 0.627556                          | 1.16749       | 0.0371863                       |
| <b>25%</b>                | 1.12501                          | 0.542507                          | 0.848022      | 0.0108159                       |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 2000.00 square meters Pu-241 1.000E+00  
 Thickness: 2.00 meters  
 Cover Depth: 1.20 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 9.070E-10 5.510E-09 3.296E-05 1.371E-09  
 M(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 2.268E-10 1.378E-09 8.241E-06 3.426E-10  
 Maximum TDOSE(t): 4.312E-05 mrem/yr at t = 1.456E+03 years

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.456E+03 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground    | Inhalation | Radon     | Plant     | Meat      | Milk      | Soil      |
|-------------------|-----------|------------|-----------|-----------|-----------|-----------|-----------|
|                   | mrem/yr   | mrem/yr    | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   |
| Pu-241            | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Total             | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 1.456E+03 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water     | Fish      | Radon     | Plant     | Meat      | Milk      | All Pathways* |
|-------------------|-----------|-----------|-----------|-----------|-----------|-----------|---------------|
|                   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr       |
| Pu-241            | 4.312E-05 | 1.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 4.312E-05     |
| Total             | 4.312E-05 | 1.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 4.312E-05     |

\*Sum of all water independent and dependent pathways.

|                           | Thickness of Unsaturated Zone | Evapotranspiration Coefficient | Runoff Coefficient | Density of Unsaturated Zone | Effective Porosity of Unsaturated Zone | Total Porosity of Unsaturated Zone | Precipitation |
|---------------------------|-------------------------------|--------------------------------|--------------------|-----------------------------|--|------------------------------------|---------------|
| <b>Mean</b>               | 1.249999211                   | 0.584991104                    | 0.350005479        | 1.599991267                 | 0.409989919                            | 0.455002578                        | 1.007488272   |
| <b>Standard Error</b>     | 0.00481466                    | 0.001636747                    | 0.00096273         | 0.006161712                 | 0.002503686                            | 0.002021635                        | 0.006153245   |
| <b>Median</b>             | 1.250175                      | 0.585038                       | 0.350015           | 1.60075                     | 0.409732                               | 0.4548075                          | 1.007535      |
| <b>Mode</b>               | 1.37837                       | 0.573988                       | 0.349318           | 1.86433                     | #N/A                                   | 0.544867                           | 1.30224       |
| <b>Standard Deviation</b> | 0.144439798                   | 0.049102425                    | 0.028881898        | 0.184851368                 | 0.075110588                            | 0.060649047                        | 0.184597359   |
| <b>Sample Variance</b>    | 0.020862855                   | 0.002411048                    | 0.000834164        | 0.034170028                 | 0.0056416                              | 0.003678307                        | 0.034076185   |
| <b>Kurtosis</b>           | -1.20047105                   | -1.199417592                   | -1.199576162       | -1.199980454                | -1.200826746                           | -1.200016993                       | -1.199911705  |
| <b>Skewness</b>           | -0.000347952                  | 4.72965E-05                    | 0.000215723        | -0.000536939                | 0.000534848                            | -6.72923E-05                       | 8.59276E-06   |
| <b>Range</b>              | 0.498                         | 0.169557                       | 0.099847           | 0.63936                     | 0.259519                               | 0.209435                           | 0.637726      |
| <b>Minimum</b>            | 1.0012                        | 0.500082                       | 0.300097           | 1.28022                     | 0.280228                               | 0.350306                           | 0.688634      |
| <b>Maximum</b>            | 1.4992                        | 0.669639                       | 0.399944           | 1.91958                     | 0.539747                               | 0.559741                           | 1.32636       |
| <b>Sum</b>                | 1124.99929                    | 526.491994                     | 315.004931         | 1439.99214                  | 368.990927                             | 409.50232                          | 906.739445    |
| <b>Count</b>              | 900                           | 900                            | 900                | 900                         | 900                                    | 900                                | 900           |
| <b>75%</b>                | 1.37501                       | 0.627767                       | 0.375017           | 1.76015                     | 0.475349                               | 0.507625                           | 1.16727       |
| <b>25%</b>                | 1.12501                       | 0.542662                       | 0.325215           | 1.44029                     | 0.345127                               | 0.402741                           | 0.848089      |

Contaminated Zone Dimensions Initial Soil Concentrations, pCi/g  
 Area: 2000.00 square meters Sr-90 1.000E+00  
 Thickness: 2.00 meters  
 Cover Depth: 1.20 meters

Total Dose TDOSE(t), mrem/yr  
 Basic Radiation Dose Limit = 4.000E+00 mrem/yr  
 Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)  
 t (years): 0.000E+00 1.000E+00 3.000E+00 1.000E+01 3.500E+01 1.500E+02 3.000E+02 1.000E+03 1.000E+04  
 TDOSE(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 2.583E+00 3.932E-02 1.675E-04 1.447E-15 0.000E+00  
 M(t): 0.000E+00 0.000E+00 0.000E+00 0.000E+00 6.458E-01 9.829E-03 4.186E-05 3.617E-16 0.000E+00  
 Maximum TDOSE(t): 3.392E+00 mrem/yr at t = 27.59 years

Total Dose TDOSE(1,p,t) for Individual Radionuclides (1) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 2.759E+01 years  
 Water Independent Pathways (Inhalation excludes radon)

| Radio-<br>Nuclide | Ground    | Inhalation | Radon     | Plant     | Meat      | Milk      | Soil      |
|-------------------|-----------|------------|-----------|-----------|-----------|-----------|-----------|
|                   | mrem/yr   | mrem/yr    | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   |
| Sr-90             | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Total             | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

Total Dose Contributions TDOSE(1,p,t) for Individual Radionuclides (1) and Pathways (p)  
 As mrem/yr and Fraction of Total Dose At t = 2.759E+01 years  
 Water Dependent Pathways

| Radio-<br>Nuclide | Water     | Fish      | Radon     | Plant     | Meat      | Milk      | All Pathways* |
|-------------------|-----------|-----------|-----------|-----------|-----------|-----------|---------------|
|                   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr   | mrem/yr       |
| Sr-90             | 3.392E+00 | 1.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 3.392E+00     |
| Total             | 3.392E+00 | 1.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 3.392E+00     |

\*Sum of all water independent and dependent pathways.