

**U.S. Environmental Protection Agency  
Western Ecology Division:**

**Radiological Surveys  
and Facilities Decommissioning  
NRC Radioactive Materials License.  
No. 36-12343-02**

**VOLUME I**

**NOVEMBER 30, 2004**

470287

**U.S. Environmental Protection Agency, Western Ecology Division:  
Radiological Surveys and Facilities Decommissioning  
NRC Radioactive Materials License No. 36-12343-02**

**Table of Contents**

**Volume I**

**Summary-**

**Glossary and Abbreviations**

**Facility Maps**

**Facility and Room Radiological Surveys**

**CSB 1**

**General MB and Newport**

**MB 126**

**MB 129**

**MB 130**

**MB 131**

**MB 132**

**MB 133**

**MB 134**

**MB 138**

**MB 149**

**MB 150**

**MB 155**

**MB 159**

**MB 173**

**MB 190**

**MB 204**

**MB 226**

**MB 228**

**MB 232**

**MB 236**

**MB 246**

**MB 248**

**MB 250**

**MB 256**

**MB 258**

**MB 262**

**MB 266**

**MB 270**

**MB 282**

**MB 284**

**MB 290**

**MB 292**

**MB 294**

Table of Contents (cont'd)

Volume II

L106

L108

L123

S118

WASTE RM

Newport General

PEB 115/118

TERA

TERF 8-23

TERF 105

TERF 113

TERF HB

WRS 10

WRS 11

WRS 12

WRS 43

WRS 44

Mechanical Surveys

**U.S. Environmental Protection Agency  
Western Ecology Division**

**Radiological Surveys and facilities Decommissioning  
NRC Radioactive Materials License No. 36-12343-02**

Introduction

*The U.S. Environmental Protection Agency Western Ecology Division: Radiological Surveys and facilities Decommissioning, NRC Radioactive Materials License No. 36-2343-02* Volumes I and II contain the status and radiological survey results of the numerous rooms and areas used for environmental research involving radiotracers and radioactive sealed sources. Research involving the use of radioactive materials spans nearly a 30 year history at the EPA Research Laboratory in Corvallis, Oregon, under NRC License No 36-12343-02. The use of radioactive materials at the Newport, Oregon, facility is limited to approximately 9 years under the present license.

These two volumes are organized by rooms and grouped by buildings. The use of radioisotopes and the final status of each area is discussed room by room. There are seven main groupings of rooms by buildings: Chemical Storage Building (CSB) and Main Building (MB) both at the Corvallis facility, L, S, and Waste Storage at the Newport facility, Plant Ecology Building (PEB, WRF, or WLD), Terrestrial Ecophysiological Research Facility (TERA), Terrestrial Ecological Research Facility (TERF), and Willamette Research Station (WRS or WFTS) all in Corvallis. These room discussions include the final radiological contamination surveys as well as the historical surveys of the work areas. These records demonstrate that the areas were maintained as contaminate-free radioisotope work spaces. Reports on the CSB and MB are found in Volume I. Volume II contains the reports on Newport, PEB, TERA, TERF, and WRS. Summary tables listing results of the final radiological surveys; the radioisotopes used at these facilities, the quantities, and their forms; and a listing of abbreviations, a glossary, and maps of the facilities and rooms are found in the front of both volumes.

Radiological total (fixed + removable) and removable contamination survey results are expressed as dpm/100 cm<sup>2</sup>, Bq/100 cm<sup>2</sup> and or picoCi/100 cm<sup>2</sup> in this report. We deviated from the NRC request for data to be expressed in MBq/100 cm<sup>2</sup> because of the very low levels of contamination. As you will see, 98% of our survey results fell into the range of 0 – 1.0 Bq/100 cm<sup>2</sup>. The majority of the isotope use was hydrogen-3, carbon-14, and nickel-63, all of which are soft beta emitters (0.018 – 0.156 MeV max.). Sulfur-35 (0.167 MeV beta max.) was employed for a short time in small quantities. These soft-beta emitters pose little or no external radiation hazard in the quantities we handled. The other isotopes used at our facilities (phosphorus-32, chromium-51, and rubidium-86), are strong beta or gamma emitters, or both. However, the half-life for these isotopes is relatively short (14 – 87 days). Any contamination at our facilities has fully decayed since the last use (1990). Therefore we did not conduct room surveys

for radiation levels or calculate external radiation doses for our facilities. Any external radiation dose would have been picked up or flagged when performing the total contamination surveys.

Finally, surveys were not performed outside the buildings. We did not contaminate any soil or water (ponds etc). We did not use radioisotopes outside the laboratory environment.

## Abbreviations and Glossary

Bkgrd = Background

Bq = Becquerel

CEB = Coastal Ecology Branch (Newport Facility)

CERL- Corvallis Environmental Research Laboratory (now called WED)

Check Source = Refers to an radioisotope source that is used as a reference radioactive source or standard which is either fixed on a surface or sealed into a container.

CSB = Chemical Storage Building

CPM = counts per minute

Dpm = disintegrations per minute

E = East

ECD = Electron Capture Detector

ERL-C = Environmental Research Laboratory – Corvallis (now called WED)

Ex = Exhaust. Used to refer to a ventilation exhaust vent or duct.

GC = Gas Chromatograph

GFPC = Gas Flow Proportional Counter

G-M = Geiger-Muller

Fixed = Used to refer to non-removable contamination.

HVAC = Heating, Ventilation, and Air Conditioning

LLD<sub>95</sub> = Lower Limits of Detection at the 95% confidence level

LSC = Liquid Scintillation Counter

MB = Main Building

N = North

NA = Not Applicable

ND = Not determined

NEW = Newport

Non-removable = Use to refer to contamination that can not be readily removed from surfaces without abrasion.

PCEB = Pacific Coastal Ecology Branch (Newport Facility)

PCi = picoCuries

PEB = Plant Ecology Building

Removable = Refers to contamination that can readily be removed from surfaces.

Rm = Room

S = South

S Source = Sealed Source

Std = Standard. Refers to a radioisotope source that is used for an analytical standard.

TERA = Terrestrial Ecophysiological Research Area

TERF = Terrestrial Ecology Research Facility

Tracer = A radioisotope that is in a loose form (liquid, solid, or gas).

W = West

WED = Western Ecology Division

WFTS = Western Fish Toxicology Station

WLD = Wildlife Building (also called PEB)

WRF = Wildlife Research Facility (also called PEB)

WRS = Willamette Research Station

## Summary of EPA-WED Contamination Surveys

Bld	Room	Last Use	Form (Tracer or Sealed Source)	Total Contamination Survey		Removable Contamination Survey		Mechanical Surveys (Yes/No)	Supporting Surveys (Yes/No)	Meets Decommission Criteria for H <sup>3</sup> , C <sup>14</sup> , P <sup>32</sup> , S <sup>53</sup> , Ni <sup>63</sup> , and Rb <sup>86</sup> (Yes/No)	Notes
				#	Range dpm/100 cm <sup>2</sup> (Bq/100 cm <sup>2</sup> )	#	Range dpm/100 cm <sup>2</sup> (Bq/100 cm <sup>2</sup> )				
CSB	1	2004	Tracer/ S Source	23	0	23	0 - 41 (0 - 0.68)	Yes	Yes	Yes	
MB	126	1983	Tracer/ S Source	16	0	16	0 - 55 (0 - 0.92)	Yes	Yes	Yes	
MB	130	1994	Tracer/ S Source	13	0	20	0 - 31 (0 - 0.52)	Yes	Yes	Yes	
MB	131	1984	Tracer/ S Source	6	0	---	---	No	Yes	Yes	
MB	132	1990	Tracer/ S Source	12	0	12	0 - 24 (0 - 0.40)	Yes	Yes	Yes	
MB	133	1983	Tracer/ S Source	6	0	---	---	No	Yes	Yes	
MB	134	1996	Tracer/ S Source	23	0	33	0 - 14 (0 - 0.23)	Yes	Yes	Yes	
MB	138	1990	Tracer	12	0	12	0 - 22 (0 - 0.36)	Yes	Yes	Yes	
MB	149	1982	Sealed Source	4	0	4	0	No	No	Yes	
MB	150	1981	Sealed Source	4	0	4	0 - 21 (0 - 0.35)	No	Yes	Yes	
MB	155	NA	NA	6	0	---	---	No	No	Yes	
MB	159	1980	Tracer/ S Source	8	0	---	---	No	Yes	Yes	
MB	173	NA	NA	8	0	---	---	No	No	Yes	
MB	190	2004	Tracer/ S Source	38	0	38	0 - 239 3.98	Yes	Yes	Yes	Note 1
MB	204	1989	Tracer/ S Source	5	0	---	---	No	Yes	Yes	
MB	226	1980	Tracer	9	0	9	0 - 23 (0 - 0.38)	No	Yes	Yes	



### Summary of EPA-WED Contamination Surveys

Bld	Room	Last Use	Form (Tracer or Sealed Source)	Total Contamination Survey		Removable Contamination Survey		Mechanical Surveys (Yes/No)	Supporting Surveys (Yes/No)	Meets Decommission Criteria for H <sup>3</sup> , C <sup>14</sup> , P <sup>32</sup> , S <sup>53</sup> , Ni <sup>63</sup> , and Rb <sup>86</sup> (Yes/No)	Notes
				#	Range dpm/100 cm <sup>2</sup> (Bq/100 cm <sup>2</sup> )	#	Range dpm/100 cm <sup>2</sup> (Bq/100 cm <sup>2</sup> )				
MB	228	1990	Tracer/ S Source	16	0	16	0 - 53 (0 - 0.88)	Yes	Yes	Yes	
MB	232	1999	Tracer/ S Source	48	0	30	0 - 36 (0 - 0.6)	Yes	Yes	Yes	
MB	236	1999	Tracer/ S Source	92	0	95	0	No	Yes	Yes	Notes 2
MB	246	2004	Tracer/ S Source	45	0	60	0 - 2 (0 - 0.03)	Yes	Yes	Yes	
MB	248	1981	Tracer/ S Source	8	0	8	0	No	Yes	Yes	
MB	250	1981	Tracer/ S Source	9	0	9	0 - 36 (0 - 0.6)	No	Yes	Yes	
MB	256	2001	Tracer/ S Source	34	0	46	0 - 139 (0 - 2.3)	Yes	Yes	Yes	
MB	258	1999	Tracer/ S Source	9	0	47	0 - 143 (0 - 2.4)	Yes	Yes	Yes	
MB	262	1986	Tracer	6	0	---	---	Yes	Yes	Yes	
MB	266	1996	Tracer/ S Source	24	0	35	0	Yes	Yes	Yes	
MB	270	1996	Tracer/ S Source	14	0 - 200 (0 - 3.0)	57	0 - 258 (0 - 4.3)	Yes	Yes	Yes	
MB	282	1982	Tracer/ S Source	11	0	11	0 - 61 (0 - 1.02)	No	Yes	Yes	
MB	284	1996	Tracer/ S Source	25	0 - 525 (0 - 9)	25	0	Yes	Yes	Yes	
MB	290	1992	Sealed Source	---	---	10	0 - 14 (0 - 0.23)	No	Yes	Yes	
MB	292	1990	Tracer	10	0	10	0 - 21 (0 - 0.35)	No	Yes	Yes	
MB	294	1990	Tracer	15	0	15	0 - 26 (0 - 0.43)	No	Yes	Yes	

### Summary of EPA-WED Contamination Surveys

Bld	Room	Last Use	Form (Tracer or Sealed Source)	Total Contamination Survey		Removable Contamination Survey		Mechanical Surveys (Yes/No)	Supporting Surveys (Yes/No)	Meets Decommission Criteria for H <sup>3</sup> , C <sup>14</sup> , P <sup>32</sup> , S <sup>53</sup> , Ni <sup>63</sup> , and Rb <sup>86</sup> (Yes/No)	Notes
				#	Range dpm/100 cm <sup>2</sup> (Bq/100 cm <sup>2</sup> )	#	Range dpm/100 cm <sup>2</sup> (Bq/100 cm <sup>2</sup> )				
NEW	L106	1997	Sealed Source	6	0	9	0	No	No	Yes	
NEW	L108	2004	Tracer/ S Source	10	0	31	0	Yes	Yes	Yes	
NEW	L123	pre-1994	Tracer	10	0	29	0	Yes	No	Yes	
NEW	S118	pre-1994	Tracer	7	0	30	0	Yes	No	Yes	
NEW	Waste	2004	Tracer	5	0	10	0	Yes	Yes	Yes	
NEW	General	NA	NA	---	---	13	0	No	No	Yes	
PEB/WLD	115/118	1988	Tracer	---	---	numerous	0 - 49 (0 - 0.82)	Yes	Yes	Yes	
TERA	Control Rm	2002	Sealed Source	---	---	10	0 - 26 (0 - 0.43)	No	Yes	Yes	
TERF	8-23-3/4	1990	Tracer	8	0	11	0	No	Yes	Yes	
TERF	105	1983	Sealed Source	25	0	0	0	Yes	No	Yes	
TERF	113	1993	Tracer	5	0	15	0	Yes	Yes	Yes	
TERF	HB	1993	Tracer	17	0	8	0	No	Yes	Yes	
WRS	10	1986	Tracer/ S Source	13	0	---	---	Yes	Yes	Yes	
WRS	11	1992	Tracer/ S Source	10	0	---	---	Yes	Yes	Yes	
WRS	12	1986	Tracer/ S Source	12	0	11	0 - 28 (0 - 0.46)	Yes	Yes	Yes	
WRS	43	1986	Tracer	5	0	---	---	No	No	Yes	

### Summary of EPA-WED Contamination Surveys

Bld	Room	Last Use	Form (Tracer or Sealed Source)	Total Contamination Survey		Removable Contamination Survey		Mechanical Surveys (Yes/No)	Supporting Surveys (Yes/No)	Meets Decommission Criteria for H <sup>3</sup> , C <sup>14</sup> , P <sup>32</sup> , S <sup>53</sup> , Ni <sup>63</sup> , and Rb <sup>86</sup> (Yes/No)	Notes
				#	Range dpm/100 cm <sup>2</sup> (Bq/100 cm <sup>2</sup> )	#	Range dpm/100 cm <sup>2</sup> (Bq/100 cm <sup>2</sup> )				
WRS	44	1986	Tracer	7	0	---	---	No	Yes	Yes	

## Summary of EPA-WED Contamination Surveys

**Cell: L16**

**Comment: Note 1:** The fume hood was removed in 2003.

**Cell: L21**

**Comment: Note 2:** Hood was removed from the laboratory in 2003.

## Summary of EPA-WED HVAC/Mechanical Contamination Surveys

Bld	Room	Last Use	Form (Tracer or Sealed Source)	Removable Contamination Survey Range	Meets Decommission Criteria for H <sup>3</sup> , C <sup>14</sup> , P <sup>32</sup> , S <sup>53</sup> , Ni <sup>63</sup> , and Rb <sup>86</sup> (Yes/No)	Notes
				dpm/100 cm <sup>2</sup> (Bq/100 cm <sup>2</sup> )		
CSB	1	2004	Tracer/ S Source	0	Yes	
MB	126	1983	Tracer/ S Source	0 - 22 (0 - 0.37)	Yes	
MB	130	1994	Tracer/ S Source	0 - 281 (0 - 0.47)	Yes	
MB	132	1990	Tracer/ S Source	0 - 50 (0 - 0.83)	Yes	
MB	134*	1996	Tracer/ S Source	0 - 14 (0 - 0.23)	Yes	*Swipe made prior to 2004
MB	138	1990	Tracer	33 - 89 (0.55 - 1.48)	Yes	
MB	190	2004	Tracer/ S Source	0 - 22 (0 - 0.37)	Yes	
MB	228	1990	Tracer/ S Source	0 - 25 (0 - 0.42)	Yes	
MB	246	2004	Tracer/ S Source	0	Yes	
MB	256	2001	Tracer/ S Source	0 - 27 (0 - 0.45)	Yes	
MB	258	1999	Tracer/ S Source	0	Yes	
MB	262*	1986	Tracer	0	Yes	*Swipe made prior to 2004
MB	266	1996	Tracer/ S Source	0	Yes	
MB	270	1996	Tracer/ S Source	0 - 41 (0 - 0.68)	Yes	
MB	284	1996	Tracer/ S Source	0	Yes	

## Summary of EPA-WED HVAC/Mechanical Contamination Surveys

Bld	Room	Last Use	Form (Tracer or Sealed Source)	Removable Contamination Survey	Meets Decommission Criteria for H <sup>3</sup> , C <sup>14</sup> , P <sup>32</sup> , S <sup>53</sup> , Ni <sup>63</sup> , and Rb <sup>86</sup> (Yes/No)	Notes
				Range dpm/100 cm <sup>2</sup> (Bq/100 cm <sup>2</sup> )		
NEW	L108	2004	Tracer/ S Source	0	Yes	
NEW	L123	pre-1994	Tracer	0	Yes	
NEW	S118	pre-1994	Tracer	0	Yes	
NEW	Waste	2004	Tracer	0	Yes	
PEB/WLD	115/118*	1988	Tracer	0 - 138 (0 - 2.3)	Yes	*Swipe made prior to 2004
TERF	105	1983	Sealed Source	0 - 3 (0 - 0.05)	Yes	
TERF	113	1993	Tracer	0 - 22 0 - 0.37	Yes	
WRS	10	1986	Tracer/ S Source	13 (0 - 0.22)	Yes	
WRS	11	1992	Tracer/ S Source	0 - 19 (0 - 0.32)	Yes	
WRS	12	1986	Tracer/ S Source	0 - 21 (0 0.83)	Yes	

**EPA WED Isotopes, Locations, and Quantities**

Year	Room	Form	Isotope	Stored mCi	Used mCi
2004	MB 190	Tracer	C-14	10.245	0.000
			H-3	1.217	0.000
			Ni-63	0.040	0.000
		Sealed Sources	Ni-63	60.000	NA
	Check Sources	Assorted*	0.001	NA	
	L108	Tracer	C-14	2.795	0.000
			H-3	1.026	0.000
TERA	Sealed Sources	H-3	200.000	NA	
2003	MB 190	Tracer	C-14	7.706	0.000
			H-3	0.251	0.000
			Ni-63	0.040	0.000
		Sealed Sources	Ni-63	60.000	NA
	Check Sources	Assorted*	0.001	NA	
	L108	Tracer	C-14	2.795	0.000
			H-3	1.026	0.000
			S-35	1.258	1.258
TERA	Sealed Sources	H-3	200.000	NA	
Waste Store (CEB)	Tracer	C-14	0.225	0.000	
2002	MB 190	Tracer	C-14	7.706	0.000
			H-3	0.251	0.000
			Ni-63	0.040	0.000
		Sealed Sources	Ni-63	45.000	NA
	Check Sources	Assorted*	0.001	NA	
	MB 270	Sealed Sources	Ni-63	15.000	NA
	L108	Tracer	C-14	2.795	0.000
			H-3	1.026	0.000
TERA	Sealed Sources	H-3	200.000	NA	
Waste Store (CEB)	Tracer	C-14	0.225	0.000	
2001	MB 190	Tracer	C-14	7.706	0.000
			H-3	0.251	0.000
			Ni-63	0.040	0.000
		Check Sources	Assorted*	0.001	NA
	Sealed Sources	Ni-63	30.000	NA	
	MB 256	Sealed Sources	Ni-63	15.000	NA
	MB 270	Sealed Sources	Ni-63	15.000	NA
	L108	Tracer	C-14	2.795	0.000
H-3			1.026	0.000	
TERA	Sealed Sources	H-3	200.000	NA	
Waste Store (CEB)	Tracer	C-14	0.225	0.000	
2000	MB 190	Tracer	H-3	5.225	0.000
			Ni-63	0.053	0.000
			C-14	12.333	0.000
		Check Sources	Assorted*	0.001	NA
	Sealed Sources	Ni-63		NA	
	MB 232	Sealed Sources	Ni-63	15.000	NA
	MB 256	Sealed Sources	Ni-63	15.000	NA
	MB 258	Sealed Sources	Ni-63	15.000	NA
	MB 270	Sealed Sources	Ni-63	15.000	NA
L108	Tracer	C-14	8.084	0.000	
		H-3	6.026	0.000	
TERA	Sealed Sources	H-3	200.000	NA	

**EPA WED Isotopes, Locations, and Quantities**

Year	Room	Form	Isotope	Stored mCi	Used mCi
	Waste Store (CEB)	Tracer	C-14	0.225	0.000
1999	MB 190	Tracer	C-14	7.231	0.000
			H-3	0.225	0.000
			Ni-63	0.053	0.000
		Check Sources	Assorted*	0.001	NA
		Sealed Sources	Ni-63	15.000	NA
	MB 232	Sealed Sources	Ni-63	15.000	NA
	MB 256	Sealed Sources	Ni-63	15.000	NA
	MB 258	Sealed Sources	Ni-63	15.000	NA
	MB 270	Sealed Sources	Ni-63	15.000	NA
	L108	Tracer	C-14	8.084	0.000
			H-3	6.026	0.000
TERA	Sealed Sources	H-3	200.000	NA	
	Waste Store (CEB)	Tracer	C-14	0.225	0.000
1998	MB 190	Tracer	C-14	7.252	0.000
			H-3	0.251	0.000
			Ni-63	0.053	0.000
		Check Sources	Assorted*	0.001	NA
		Sealed Sources	Am-243:Be	10.000	NA
	MB 232	Sealed Sources	Ni-63	15.000	NA
	MB 256	Sealed Sources	Ni-63	15.000	NA
	MB 270	Sealed Sources	Ni-63	15.000	NA
	L108	Tracer	C-14	8.084	0.000
			H-3	6.026	0.000
	TERA	Sealed Sources	H-3	200.000	NA
	Waste Store (CEB)	Tracer	C-14	0.225	0.000
1997	MB 190	Tracer	C-14	7.498	0.000
			H-3	0.282	0.000
			Ni-63	0.053	0.000
		Sealed Sources	Am-243:Be	10.000	NA
		Check Sources	Assorted*	0.001	NA
	MB 232	Sealed Sources	Ni-63	15.000	NA
	MB 256	Sealed Sources	Ni-63	15.000	NA
	MB 270	Sealed Sources	Ni-63	15.000	NA
	L106	Sealed Sources	Ni-63	15.000	NA
	L108	Tracer	C-14	8.084	0.000
			H-3	6.026	0.000
TERA	Sealed Sources	H-3	200.000	NA	
	Waste Store (CEB)	Tracer	C-14	0.225	0.000
1996	MB 190	Tracer	C-14	8.810	0.000
			H-3	3.714	0.000
			Ni-63	0.053	0.000
		Sealed Sources	Ni-63	60.500	NA
		Sealed Sources	Am-243:Be	10.000	NA
	Check Sources	Assorted*	0.001	NA	
	MB 232	Sealed Sources	Ni-63	15.000	NA
	MB 236	Tracer	C-14	3.645	0.000
	MB 258	Sealed Sources	Ni-63	15.000	NA
	MB 270	Tracer	C-14	0.005	0.000
	MB 282	Sealed Sources	Ni-63	15.000	NA
MB 284	Sealed Sources	Ni-63	29.500	NA	



**EPA WED Isotopes, Locations, and Quantities**

<b>Year</b>	<b>Room</b>	<b>Form</b>	<b>Isotope</b>	<b>Stored mCi</b>	<b>Used mCi</b>
	L106	Sealed Sources	Ni-63	15.000	NA
	L108	Tracer	C-14	8.084	0.000
			H-3	6.026	0.000
	TERA	Sealed Sources	H-3	200.000	NA
	Waste Store (CEB)	Tracer	C-14	0.225	0.000
1995	MB 134/270	Tracer	C-14	0.248	0.002
	MB 190	Tracer	C-14	21.310	0.000
			H-3	3.714	0.000
			Ni-63	0.053	0.000
		Sealed Sources	Ni-63	60.500	NA
		Sealed Sources	Am-243:Be	10.000	NA
		Check Sources	Assorted*	0.001	NA
	MB 232	Sealed Sources	Ni-63	15.000	NA
	MB 236	Tracer	C-14	4.865	0.600
	MB 258	Sealed Sources	Ni-63	15.000	NA
	MB 270	Tracer	C-14	0.636	0.004
	MB 282	Sealed Sources	Ni-63	15.000	NA
	MB 284	Sealed Sources	Ni-63	29.500	NA
	L106	Sealed Sources	Ni-63	15.000	NA
	L108	Tracer	C-14	8.084	NA
H-3			5.026	NA	
Waste Store (CEB)	Tracer	C-14	0.225	NA	
1994	MB 190	Tracer	C-14	19.342	0.000
			H-3	5.657	0.000
			Ni-63	0.053	0.000
		Sealed Sources	Ni-63	43.000	NA
		Sealed Sources	Am-243:Be	10.000	NA
		Check Sources	Assorted*	0.001	NA
	MB 204	Sealed Sources	Ni-63	15.000	NA
	MB 232	Sealed Sources	Ni-63	15.000	NA
	MB 236	Tracer	C-14	4.865	0.240
	MB 246	Sealed Sources	Ni-63	15.000	NA
	MB 258	Sealed Sources	Ni-63	15.000	NA
	MB 270	Tracer	C-14	0.636	0.000
	MB 284	Sealed Sources	Ni-63	29.500	NA
MB 290	Sealed Sources	Ni-63	8.000	NA	
1993	MB 190	Tracer	C-14	19.953	0.000
			H-3	5.657	0.000
			Ni-63	0.053	0.000
		Sealed Sources	Ni-63	23.000	NA
			Ru-106	0.001	NA
			Ti-204	0.001	NA
			Sr-90	0.004	NA
			Pb-210	0.006	NA
			Am-243:Be	10.000	NA
		Check Sources	Assorted*	0.001	NA
	MB 204	Sealed Sources	Ni-63	15.000	NA
	MB 232	Sealed Sources	Ni-63	15.000	NA
	MB 236	Tracer	H-3	0.384	0.000
C-14			0.367	0.000	
MB 246	Sealed Sources	Ni-63	15.000	NA	

### EPA WED Isotopes, Locations, and Quantities

Year	Room	Form	Isotope	Stored mCi	Used mCi
	MB 258	Sealed Sources	Ni-63	15.000	NA
	MB 270	Sealed Sources	Ni-63	8.000	NA
	MB 270/266	Tracer	C-14	0.499	0.136
	MB 284	Sealed Sources	Ni-63	29.500	NA
	TERF HB	Tracer	H-3	29.500	0.050
1992	MB 130	Tracer	H-3	0.198	1.401
			Cr-51	0.100	0.500
	MB 190	Tracer	C-14	19.175	0.000
			H-3	6.474	0.000
			C-51	1.000	0.000
			P-32	0.250	0.000
			Ni-63	48.000	NA
		Ru-106	0.001	NA	
		Ti-204	0.001	NA	
		Sr-90	0.004	NA	
		Pb-210	0.006	NA	
		Am-243:Be	10.000	NA	
	Check Sources	Assorted*	0.001	NA	
	MB 204	Sealed Sources	Ni-63	15.000	NA
	MB 232	Sealed Sources	Ni-63	15.000	NA
	MB 236	Tracer	H-3	0.384	0.000
			C-14	0.367	0.000
	MB 246	Sealed Sources	Ni-63	15.000	NA
	MB 256/258	Sealed Sources	Ni-63	15.000	NA
		Tracer	C-14	3.228	0.000
H-3			0.016	0.000	
MB 266/270	Sealed Sources	Ni-63	8.000	NA	
	Tracer	C-14	0.506	0.506	
MB 284	Sealed Sources	Ni-63	44.000	NA	
MB 290	Sealed Sources	Ni-63	15.000	NA	
WRS 11	Tracer	P-32	0.256	0.000	
1991	MB 130	Tracer	Cr-51	1.000	3.000
			H-3	1.280	1.995
	MB 190	Tracer	C-14	15.855	0.000
			H-3	12.115	0.000
			Cr-51	1.000	0.000
			Ni-63	0.056	0.000
			P-32	0.250	0.000
			S-35	0.250	0.000
			Ru-106	0.001	NA
		Ti-204	0.001	NA	
		Sealed Sources	Sr-90	0.004	NA
			Ni-63	48.000	NA
	Pb-210		0.006	NA	
	Check Sources	Assorted*	0.001	NA	
	MB 232	Sealed Sources	Ni-63	15.000	NA
	MB 236	Tracer	C-14	0.367	0.000
		Tracer	H-3	0.384	0.000
MB 246	Sealed Sources	Ni-63	15.000	NA	
			C-14	0.421	0.000

**EPA WED Isotopes, Locations, and Quantities**

Year	Room	Form	Isotope	Stored mCi	Used mCi
	MB 256/258	Tracer	C-14	2.808	0.000
			H-3	0.016	0.000
	MB 284	Sealed Sources	Ni-63	44.000	NA
	MB 290	Sealed Sources	Ni-63	23.000	NA
	WRS 11	Tracer	P-32	0.143	0.000
1990	MB 130	Tracer	Cr-51	2.205	5.430
			H-3	5.341	1.445
	MB 190	Tracer	C-14	15.854	0.000
			Cr-51	0.290	0.000
			S-35	0.280	0.000
			H-3	1.113	0.000
			Ni-63	0.056	0.000
			Ru-106	0.001	NA
		Sealed Sources	Tl-204	0.001	NA
			Sr-90	0.004	NA
			Pb-210	0.006	NA
			Ni-63	48.000	NA
	Check Sources	Assorted*	0.001	NA	
	MB 232	Sealed Sources	Ni-63	15.000	NA
	MB 236	Tracer	C-14	0.367	0.000
			H-3	0.784	0.416
	MB 246	Sealed Sources	Ni-63	15.000	NA
	MB 258/256	Tracer	C-14	3.230	0.008
			H-3	0.017	0.000
			P-32	0.308	0.000
MB 284	Sealed Sources	Ni-63	44.000	NA	
MB 290	Sealed Sources	Ni-63	23.000	NA	
MB 292/294	Tracer	S-35	1.248	1.700	
TERF HB	Tracer	C-14	0.000	0.950	
1989	Annex	Sealed Sources	Ni-63	15.000	NA
	MB 130	Tracer	Cr-51	5.360	2.900
			H-3	5.228	0.092
	MB 190	Tracer	C-14	15.856	0.000
			H-3	1.901	0.000
			Ni-63	0.056	0.000
			P-32	0.250	0.000
			S-35	1.000	0.000
			Cr-51	0.250	0.000
			Check Sources	Assorted*	0.001
		Sealed Sources	Ni-63	33.000	NA
	MB 228	Sealed Sources	Ni-63	30.000	NA
	MB 236	Tracer	C-14	0.391	0.000
			H-3	1.085	1.744
	MB 246	Sealed Sources	Ni-63	15.000	NA
	MB 256/258	Tracer	C-14	3.232	0.006
			H-3	0.018	0.000
	MB 270	Tracer	P-32	0.240	0.063
	MB 284	Sealed Sources	Ni-63	44.000	NA
	MB 290	Sealed Sources	Ni-63	8.000	NA
MB 292/294	Tracer	S-35	1.058	1.058	

**EPA WED Isotopes, Locations, and Quantities**

Year	Room	Form	Isotope	Stored mCi	Used mCi
1988	TERF HB	Tracer	C-14	0.000	1.700
	Annex	Sealed Sources	Ni-63	15.000	NA
		Tracer	H-3	16.977	16.970
	MB 130	Sealed Sources	Ni-63	15.000	NA
		Sealed Sources	Ni-63	8.000	NA
	MB 190	Tracer	C-14	16.354	0.000
			H-3	1.142	0.000
			Ni-63	0.059	0.007
			P-32	0.250	0.000
		Sealed Sources	Ni-63	18.000	NA
		Check Sources	Assorted*	0.001	NA
		MB 228	Sealed Sources	Ni-63	30.000
	MB 256/258	Tracer	C-14	2.912	1.292
			H-3	1.063	0.867
	MB 270	Tracer	P-32	0.160	0.160
MB 284	Sealed Sources	Ni-63	44.000	NA	
TERF 113	Tracer	C-14	0.000	0.500	
WILD 115/118	Tracer	H-3	0.000	16.970	
1987	Annex	Sealed Sources	Ni-63	15.000	NA
	MB 130	Sealed Sources	Ni-63	15.000	NA
	MB 132	Sealed Sources	Ni-63	8.000	NA
	MB 134	Sealed Sources	Ni-63	0.000	NA
	MB 190	Tracer	C-14	16.536	0.000
			H-3	9.558	0.000
			N-63	0.059	0.000
			Rb-86	1.000	0.000
			P-32	0.250	0.000
		Sealed Sources	Ni-63	18.000	NA
		Check Sources	Assorted*	0.001	NA
	MB 228	Sealed Sources	Ni-63	30.000	NA
	MB 232	Sealed Sources	Ni-63	0.000	NA
	MB 256/258	Tracer	C-14	4.819	1.082
	MB 266	Tracer	P-32	1.500	1.205
MB 284	Sealed Sources	Ni-63	44.000	NA	
TERF 113	Tracer	C-14	0.000	0.500	
		Rb-86	0.000	0.630	
1986	MB 130	Sealed Sources	Ni-63	15.000	NA
	MB 132	Sealed Sources	Ni-63	8.000	NA
	MB 134	Sealed Sources	Ni-63	15.000	NA
	MB 190	Tracer	P-32	0.250	0.000
			C-14	18.082	0.000
			H-3	0.018	0.000
			H-3	1.366	0.000
			N-63	0.059	0.000
			Rb-86	0.316	0.000
			Ni-63	0.059	0.000
		Sealed Sources	Ni-63	18.000	NA
	Check Sources	Assorted*	0.001	NA	
MB 228	Tracer	H-3	0.001	0.000	
MB 232	Sealed Sources	Ni-63	30.000	NA	
MB 258	Tracer	C-14	10.932	0.939	

### EPA WED Isotopes, Locations, and Quantities

Year	Room	Form	Isotope	Stored mCi	Used mCi	
	MB 270	Tracer	P-32	0.250	0.510	
	MB 284	Sealed Sources	Ni-63	44.000	NA	
	TERF 113	Tracer	Rb-86	0.000	0.990	
			C-14	0.000	0.500	
1985	MB 130	Sealed Sources	Ni-63	15.000	NA	
	MB 132	Sealed Sources	Ni-63	8.000	NA	
	MB 190		C-14	18.647	0.000	
			H-3	0.024	0.003	
			Ni-63	0.059	0.000	
			P-32	0.250	0.000	
			Sealed Sources	Ni-63	52.000	NA
		Check Sources	Assorted*	0.001	NA	
	MB 228		Tracer	H-3	0.005	0.000
			Sealed Sources	Ni-63	15.000	NA
	MB 232	Sealed Sources	Ni-63	25.000	NA	
	MB 256/258	Tracer	C-14	3.506	0.708	
	MB 266/270	Tracer	P-32	0.250	0.000	
MB 284	Sealed Sources	Ni-63	44.000	NA		
TERF 113	Tracer	C-14		0.500		
1984**	**MB 126,129 130,131,132,133,13 4,149,150,190,226, 228,236,248,250,25 6,258,266,270,282, TERF 113, WFTS 10, 11, 112, 44	Tracers and Sealed Sources	H-3 sources, C-14 tracers, Ni-63 sources	See Note	See Note	
	MB 130	Sealed Sources	Ni-63	15.000	NA	
	MB 132	Sealed Sources	Ni-63	8.000	NA	
	MB 190	Sealed Sources	Ni-63	52.000	NA	
		Check Sources	Assorted*	0.001	NA	
	MB 228	Sealed Sources	Ni-63	15.000	NA	
	MB 232	Sealed Sources	Ni-63	10.000	NA	
	MB 284	Sealed Sources	Ni-63	29.000	NA	
	TERF 113	Tracers				
1983**	**	Tracers	See Note	See Note	See Note	
	MB 190	Sealed Sources	Ni-63	53.000	NA	
		Check Sources	Assorted*	0.001	NA	
	MB 228	Sealed Sources	Ni-63	38.000	NA	
	MB 284	Sealed Sources	Ni-63	30.000	NA	
	TERF 105	Sealed Sources	Ni-63	10.000	NA	
TERF 113						
1982**	**	Tracers	See Note	See Note	See Note	
	MB 190	Sealed Sources	Ni-63	53.000	NA	
		Check Sources	Assorted*	0.001	NA	
	MB 228	Sealed Sources	Ni-63	38.000	NA	
	MB 284	Sealed Sources	Ni-63	30.000	NA	
TERF 105	Sealed Sources	Ni-63	10.000	NA		
	**	Tracers	See Note	See Note	See Note	
	MB 150	Sealed Sources	H-3/Sc	250.000	NA	

## EPA WED Isotopes, Locations, and Quantities

Year	Room	Form	Isotope	Stored mCi	Used mCi
1981**	MB 190	Sealed Sources	Ni-63	8.000	NA
		Check Sources	Assorted*	0.001	NA
	MB 228	Sealed Sources	Ni-63	8.000	NA
	MB 266	Sealed Sources	Ni-63	29.000	NA
	MB 284	Sealed Sources	Ni-63	29.000	NA
	TERF 105	Sealed Sources	Ni-63	10.000	NA
1980**	**	Tracers	See Note	See Note	See Note
	MB 130	Sealed Sources	H-3/Sc	2000.000	NA
	MB 190	Sealed Sources	Ni-63	30.000	NA
		Check Sources	Assorted*	0.001	NA
	WFTS	Sealed Sources	Ni-63	58.000	NA
1979**	**	Tracers	See Note	See Note	See Note
	MB/WFTS	Sealed Sources	H-3/Sc	3500.000	NA
		Sealed Sources	Ni-63	30.000	NA
	MB 190	Check Sources	Assorted*	0.001	NA
1978**	**	Tracers	See Note	See Note	See Note
	MB 130	Sealed Sources	H-3/Sc	2000.000	NA
	MB 190	Sealed Sources	H-3/Sc	2000.000	NA
		Check Sources	Assorted*	0.001	NA
	MB 266	Sealed Sources	H-3/Sc	4000.000	NA
			Ni-63	29.000	NA
	MB 270	Sealed Sources	Ni-63	14.500	NA
	TERF 105	Sealed Sources	Ni-63	10.000	NA
WFTS	Sealed Sources	Ni-63	14.500	NA	
1977**	**	Tracers	See Note	See Note	See Note
	MB 190	Sealed Sources	Ni-63	43.500	NA
		Sealed Sources	H-3/Sc	7000.000	NA
		Check Sources	Assorted*	0.001	NA
	MB 228	Sealed Sources	Ni-63	29.000	NA
			H-3/Sc	2000.000	NA
	MB 270	Sealed Sources	Ni-63	14.500	NA
WFTS	Sealed Sources	Ni-63	15.000	NA	
1976**	**	Tracers	See Note	See Note	See Note
	MB 130	Sealed Sources	H-3/Sc	1000.000	NA
	MB 190	Check Sources	Assorted*	0.001	NA
	MB 284	Sealed Sources	H-3/Sc	6000.000	NA
			Ni-63	29.000	NA
	WFTS	Sealed Sources	Ni-63	15.000	NA


## EPA WED Isotopes, Locations, and Quantities

Cell: A389


Comment: \*Assorted= Solid form. Assorted instrument check sources, standards, and anti-static devices of 0.1 - 1.0 uCi (H-3, C-14, Co-60, Ni-63, Cs-137, Ra-226, Am-243)

Cell: D389


Comment: \*\*YEAR = Isotopes (H-3 sources, C-14 tracers, and Ni-63 sources) were used in MB 136, 130, 131, 132, 133, 134, 150, 190, 228, 236, 250, 256, 254, 266, 270, 282, TERF 113, and WFTS 10, 11, 12, 44 prior to 1985.








MAIN BUILDING, FIRST FLOOR




MAIN BUILDING, SECOND FLOOR



US ENVIRONMENTAL  
 PROTECTION AGENCY  
 WESTERN ECOLOGY DIVISION  
 COASTAL ECOLOGY BRANCH  
 NEWPORT, OREGON.






WEST ENTRANCE




WILDLIFE TOXICOLOGY FACILITY

*PEB/WLD/WRF*






DIVISION		DATE	BY
UNITED STATES ENVIRONMENTAL PROTECTION AGENCY CORVALLIS ENVIRONMENTAL RESEARCH LABORATORY			
SAFETY	DESIGNED	DRAWN	
REVIEWED	FORN	DATE	
APPROVED	CHECKED	SHEET	OF






TERRESTRIAL ECOLOGY RESEARCH FACILITY

REVISIONS		DATE	BY
UNITED STATES ENVIRONMENTAL PROTECTION AGENCY CORVALLIS ENVIRONMENTAL RESEARCH LABORATORY			
DATE	BY	NO. OF	
REVISION	DESCRIPTION	DATE	BY
APPROVED	DRAWN	DATE	BY




FIELD SAMPLE PROCESSING | GREENHOUSE


Greenhouse 8-2 + 8-4  
TERF



MURPHY APPROVED ASSIGNMENTS 10-29 PCT		
REVISIONS	DATE	BY
UNITED STATES ENVIRONMENTAL PROTECTION AGENCY CORVALLIS ENVIRONMENTAL RESEARCH LABORATORY		
SAFETY:	DESIGNED: PCT	DATE: 10/27/86
REVIEWED:	DRAWN: PCT	DWG. NO.
APPROVED: MURPHY 10-29 BY	CHECKED:	SHEET 1 OF 1



FIRST FLOOR  
 WFTS MAIN BUILDING



SECOND FLOOR  
 WFTS MAIN BUILDING

WRS  
 10, 11, 12, 43, 44



**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Chemical Storage Building –Waste Room  
(CSB-1) Final Contamination Survey.**

Description and Historic Use:

Separate building (450 ft<sup>2</sup>). This is the Radiation Safety Waste Room. Waste from radioisotope tracers and sealed sources used at the Western Ecology Division were often stored and/or handled in CSB-1. There is no radioactive waste remaining in CSB-1.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in CSB-1 in November 2004. All total contamination surveys (23 total) demonstrated no contamination. Eight swipes indicated very low levels of removable contamination from tritium (0.20 – 0.68 Bq/100 cm<sup>2</sup>). All other sampling points were at background. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. A HVAC duct swipe was made in November 2004 which detected no contamination.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of CSB-1 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.



NHEERL-WED  
RADIATION AREA SURVEY

LOG NO. 04-23

DATE 11-18-04

LOCATION LSB

ROOM 1

INSTRUMENT Packard LSC 2200 CA  
SERIAL NO. 036755

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	7	12	0.20
2	8	16	0.26
3	3	LLD <sub>95</sub>	ND
4	3	↓	↓
5	6	↓	↓
6	9	20	0.33
7	7	15	0.25
8	8	22	0.36
9	6	LLD <sub>95</sub>	ND
10	6	↓	↓
11	5	↓	↓
12	5	↓	↓
13	4	↓	↓
14	6	↓	↓
15	6	↓	↓
16	7	12	0.20
17	14	41	0.68
18	3	LLD <sub>95</sub>	ND
19	4	↓	↓
20	4	↓	↓
21	7	24	0.40
22	5	LLD <sub>95</sub>	ND
23	4	↓	↓

3H

LLD<sub>95</sub> = { ( ) X 2.96 } + 7 CPM

BACKGROUND STANDARD (3H) 4 CPM  
69,179 dpm ) 56,056 dpm  
87% eff

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
	21	LLD <sub>95</sub>	ND
	17	↓	↓
	20	↓	↓
	17	↓	↓
	18	↓	↓
	23	↓	↓
	17	↓	↓
	17	↓	↓
	20	↓	↓
	24	↓	↓
	20	↓	↓
	14	↓	↓
	19	↓	↓
	18	↓	↓
	16	↓	↓
	19	↓	↓
	20	↓	↓
	16	↓	↓
	16	↓	↓
	13	↓	↓
	13	↓	↓
	17	↓	↓
	17	↓	↓

14c

LLD<sub>95</sub> = { ( ) X 2.96 } + 30 CPM

BACKGROUND STANDARD (14c) 22 CPM  
84,000 dpm ) 85,603 dpm  
102% eff

COMMENTS:


D. Monahan  
RADIATION SPCL.

11-18-04  
DATE

NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 0A-23

LOCATION: CSB ROOM 1




NHEERL-WED  
RADIATION AREA SURVEY

LOG NO. 0A-18

DATE 10/4/04

FIXED LOCATION CSB

ROOM 1 1/2



SWPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
--------	-----------	---------	---------------------------------

1	125	LLD <sub>95</sub>	NO*
2	↓	↓	↓
3	↓	↓	↓
4	↓	↓	↓
5	↓	↓	↓

$$LLD_{95} = \{ (\sqrt{125}) \times 2.96 \} + 158 = \text{CPM}$$

BACKGROUND 125 CPM  
STANDARD (<sup>137</sup>Cs class) 10,000 cpm  
INSTRUMENT Ludlum #3  
SERIAL NO. 77176

COMMENTS:

NO\* = NOT DETERMINED Below to decision limit.

Q Mo  
RADIATION SPCL.

10/4/04  
DATE



**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building and Newport Facility  
Unrestricted Areas Final Contamination Surveys.**

Five areas of the Main Building facilities and two unrestricted rooms, which to our knowledge were never used for radioisotope work, were surveyed in 2004 for total (fixed + removable) contamination. Ten areas of the Newport facility were surveyed for removable contamination.

Areas surveyed in the Main Building included four hallways, the library (MB 173), the copy center (MB 155), and one reference wall (MB 157). All areas surveyed (19 samples) were at background levels and ranging from 30 – 64 gross cpm/100 cm<sup>2</sup>. The lower limits of detection for the survey instrument was generally 108 – 113 gross cpm. These areas meet the contamination criteria for unrestricted use based upon the isotopes used at our facilities.

Areas surveyed in the Newport Facility included seven hallways. All areas surveyed (7) indicated no contamination. These areas meet the contamination criteria for unrestricted use based upon the isotopes used at our facilities.

We considered it adequate to limit the survey of unrestricted areas to these fourteen locations because of the historic use of radioactive materials at our facilities. Records clearly demonstrate that contamination surveys were regularly performed and that unrestricted areas were never contaminated. These records also demonstrate that there were never any significant contamination events and the restricted areas were maintained as contaminate-free areas. We determined it was unnecessary to conduct further contamination surveys in these areas and other unrestricted areas of our facilities given these survey results and the Western Ecology Division's historic management of radioactive materials.

The survey was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.

NHEERL-WED  
RADIATION AREA SURVEY

LOG NO. 04-23

DATE 11-11-04 LOCATION \_\_\_\_\_ ROOM \_\_\_\_\_ INSTRUMENT <sup>FIXED</sup> Ludlum 2000 Scaler SN 83810/PR070834  
PANCAKE PROBE 44-9

Swipe No.	Description	Isotope <u>P+X</u>			Isotope _____		
		Gross CPM	Net DPM	Activity Bq/100 cm <sup>2</sup>	Gross CPM	Net DPM	Activity Bq/100 cm <sup>2</sup>
	<u>MB Hall 134-133</u>	<u>38</u>	<u>LLD95</u>	<u>ND</u>			
	<u>MB Hall 190-191</u>	<u>30</u>	↓	↓			
	<u>MB Hall 228-231</u>	<u>50</u>	↓	↓			
	<u>MB Hall 294-295</u>	<u>46</u>	↓	↓			
	<u>Reference Wall 157 hall</u>	<u>46</u>	↓	↓			
		$LLD_{95} = \left(\frac{\sqrt{38}}{0.5}\right) \times 2.96 \text{ } 76 = \frac{113}{\text{CPM}}$			$LLD_{95} = \left(\frac{\text{-----}}{\text{-----}}\right) \times 2.96 + \text{-----} = \text{CPM}$		
		BACKGROUND <u>76</u> COUNT TIME <u>0.5 min</u> STANDARD ( $\frac{1}{0.168 \mu\text{Ci}}$ ) <u>10,540 CPM</u> $2.8\% \text{ eff}$			BACKGROUND _____ COUNT TIME _____ STANDARD ( ) _____		

*Shil Monzer*

11-16-04

Comments:

Radiation Safety Specialist

Date



**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 126 Final Contamination Survey.**

Description and Historic Use:

Small double lab (350 ft<sup>2</sup>). Potentially hydrogen-3 and carbon-14 tracers, and nickel-63 and hydrogen-3:scandium sealed sources. No isotope use since prior to 1986. There is no record of leakage of any sealed sources used in this area.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in MB 126 in November 2004. This room was an unrestricted area since prior to 1986; radioactive materials were not used in this area after 1985.

All points surveyed (16 total and 16 removable) demonstrated no significant contamination. Seven points indicated very low levels of removable contamination from tritium (0.10 – 0.92 Bq/100 cm<sup>2</sup>). All other sampling points were at background. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. A HVAC duct swipe was made in November 2004 which detected 0.37 Bq/100 cm<sup>2</sup> of hydrogen-3.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of MB 126 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.

NHEERL-WED  
RADIATION AREA SURVEY  
FIXED SURVEY

LOG NO. 04-23

DATE 11-11-04

LOCATION MB

ROOM 126

INSTRUMENT Ludlum 2000 Scaler Pancake Probe AA-9  
 SERIAL NO. 83810 / PR 070834

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	24	LLD <sub>95</sub>	NA
2	20		
3	26		
4	30		
5	23		
6	26		
7	22		
8	28		
9	24		
10	20		
11	28		
12	24		
13	22		
14	24		
15	30		
16	24		

LLD<sub>95</sub> = { (  $\sqrt{\frac{38}{0.3}}$  ) x 2.96 } + 113 CPM  
 BACKGROUND 75.3 CPM  
 STANDARD ( <sup>14</sup>C 0.168 μCi )  $\frac{110,540 \text{ CPM}}{}$   
 Time 0.5 min.      2.8% eff.

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>

LLD<sub>95</sub> = { ( ----- ) x 2.96 } + = CPM  
 BACKGROUND STANDARD (                                  ) \_\_\_\_\_

COMMENTS:

G. Momen  
RADIATION SPCL.

11-16-04  
DATE

NHEERL-WED  
RADIATION AREA SURVEY

LOG NO. 04-23

DATE 11-11-04

LOCATION MB

ROOM 126

INSTRUMENT LSC Packard 2200 CA  
SERIAL NO. 036755

**3H**

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	7	11	0.18
2	6	LLD <sub>95</sub>	ND
3	8	6	0.10
4	3	LLD <sub>95</sub>	ND
5	3	LLD <sub>95</sub>	ND
6	4	↓	ND
7	6	↓	ND
8	17	55	0.92
9	8	19	0.32
10	9	21	0.35
11	6	LLD <sub>95</sub>	ND
12	7	15	0.25
13	6	LLD <sub>95</sub>	ND
14	3	↓	↓
15	5	↓	↓
16	7	14	0.23

LLD<sub>95</sub> =  $\left\{ \left( \frac{\sqrt{12}}{3} \right) \times 2.96 \right\} + 4 = 7$  CPM

BACKGROUND STANDARD (3H, 64,179 DPM) 56,056 DPM  
2 DPM 87% eff.

**14C**

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
	20	LLD <sub>95</sub>	ND
	16	↓	↓
	16	↓	↓
	17	↓	↓
	12	↓	↓
	13	↓	↓
	14	↓	↓
	15	↓	↓
	13	↓	↓
	12	↓	↓
	14	↓	↓
	13	↓	↓
	13	↓	↓
	15	↓	↓
	16	↓	↓
	15	↓	↓

LLD<sub>95</sub> =  $\left\{ \left( \frac{\sqrt{66}}{3} \right) \times 2.96 \right\} + 30 = 30$  CPM

BACKGROUND STANDARD (14C, 84,000 DPM) 85,603  
28 DPM 102% eff.

COMMENTS:

D. Monahan  
RADIATION SPCL.


11-18-04  
DATE

NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION MB

ROOM 126



← N

UNITED STATES ENVIRONMENTAL PROTECTION  
ENVIRONMENTAL RESEARCH LABORATORY - CORV

SUBJECT

Removal of Rooms 126 & 130 from Radiation  
status

FROM

Jay Gile JG

TO

Radiation Safety Officer

Rooms 126 & 130 are no longer in  
experiments. The monitoring data  
already been submitted, that from 100  
to this memo. Neither room need  
when unoccupied therefore the red  
removed from the doors to both rooms

Approved 4/18/83

JG  
RSD

WEEKLY SWIPE SURVEY

Week of 2/5/83 - 2/11/83

Mike

2/18/83

Swipes taken 2/11/83  
Swipes counted 2/18/83

83-04

RAM # 6  
REGION A LL-UL= 0- 12 LCR= 0 BKG= 0 % 2 SIGMA= .2  
REGION B LL-UL= 12- 156 LCR= 0 BKG= 0 % 2 SIGMA= .2  
SLIDE 1 = 8031 NUCLIDE 2 = 42000  
TIME= 30.00 QIP= SIE/REC SCR= B/A K= 1.000

S#	TIME	CPMA/K DPM1/K	%DEV	CPMB/K DPM2/K	%DEV	QIP	FLAGS	SCR	MIN	DESCRIPTION
1	30.00	18.17	8.57	52.93	5.02	585.	B1	2.914	31	BKGD - LIBRARY
2	30.00	18.20	8.56	53.00	5.02	549.	B	2.912	62	BKGD - COPY ROOM
3	30.00	8.67	12.4	15.60	9.25	576.	B	1.800	93	BKGD - Rm. 192
5	30.00	15.01		40.51		570.		2.699		
5	30.00	.00	10.4	.00	9.62	486.	?	.000	124	126 FLOOR BY HOOD
6	30.00	.00		.00			?	.000		
6	30.00	.00	14.5	.00	9.24	510.	?	.000	155	126-CENTER COUNTER
7	30.00	.00		.00			?	.000		
7	30.00	.00	11.8	.00	7.76	541.	?	.000	186	126-COUNTER LEFT OF HOOD
8	30.00	.00		.00			?	.000		
8	30.00	.00	12.7	.00	9.50	567.	?	.000	217	126 HOOD
9	30.00	.00		.00			?	.000		
9	30.00	.00	15.4	.00	9.11	463.	?	.000	248	130: FLOOR BY HOOD
10	30.00	.00		.00			?	.000		
10	30.00	.00	12.4	.00	7.08	526.	?	.000	278	130: HOOD
11	30.00	.00		.00			?	.000		
11	30.00	.00	14.1	.00	9.35	509.	?	.000	309	130: BENCH BY OXIDIZER
12	30.00	.00		.00			?	.000		
12	30.00	.00	11.7	.00	9.09	535.	?	.000	340	130: FLAMM. LIQ. CABINET
13	30.00	.00		.00			?	.000		
13	30.00	.00	13.6	.00	9.39	529.	?	.000	371	132: S. BENCH
14	30.00	.00		.00			?	.000		
14	30.00	.00	11.5	7.12	5.29	432.	?	.000	402	132: TOP OF GREEN CAB.
15	30.00	.00		9.26			?	.000		
15	30.00	.00	15.5	.00	9.50	456.	?	.000	433	132: FLOOR, IN CENTER
16	30.00	.00		.00			?	.000		
16	30.00	.00	11.4	.00	6.52	572.	?	.000	464	132: HOOD
17	30.00	.00		.00			?	.000		
17	30.00	.00	13.8	.00	9.43	538.	?	.000	495	134: TOP OF TMC #2
18	30.00	.00		.00			?	.000		
18	30.00	.00	13.5	.00	9.61	539.	?	.000	526	134: FLOOR BY DOOR TO 132.
19	30.00	.00		.00			?	.000		
19	30.00	.00	12.5	.00	9.62	567.	?	.000	557	134: E. BENCH
20	30.00	.00		.00			?	.000		
20	30.00	.00	12.5	.00	9.96	565.	?	.000	588	134: FLOOR BY HALL
21	30.00	.00		.00			?	.000		
21	30.00	.00	11.2	.00	9.85	603.	?	.000	619	190: WORK BENCH
22	30.00	.00		.00			?	.000		
22	30.00	.00	14.1	.00	9.57	504.	?	.000	650	190: COUNTER BY RAM SIDE
23	30.00	.00		.00			?	.000		
23	30.00	.00	12.7	.00	9.27	507.	?	.000	681	190: AREA BY N. SINK
24	30.00	.00		.00			?	.000		
24	30.00	.00	15.9	.00	9.59	490.	?	.000	711	190: COUNTER BY TYPE WRITER

M. Mckuzak - Carter

-12-102

# WEEKLY SWIPE SURVEY

counted: 1110-  
2/7/83

Week of 1/29/83 → 2/4/83

83-03

Mike

M. McKenzie - Capt

GRAM #: 6  
 ION A: LL-UL= 0- 12 LCR= 0 BKG= 0 % 2 SIGMA= .2  
 ION B: LL-UL= 12- 156 LCR= 0 BKG= 0 % 2 SIGMA= .2  
 SLIDE 1 = 8031 NUCLIDE 2 = 42000  
 E = 30.00 QIP= SIE/REC SCR= B/A K= 1.000

S#	TIME	CPMA/K DPM1/K	%DEV	CPMB/K DPM2/K	%DEV	QIP	FLAGS	SCR	MIN	
1	30.00	17.70	8.68	50.87	5.12	596.	B	2.874	31	LIBRARY COPY ROOM } BKGD RM 192
2	30.00	16.63	8.95	54.70	4.94	556.	B	3.289	62	
3	30.00	7.37	13.4	16.03	9.12	577.	B	2.176	93	
		13.90		40.53		577.		2.916		
5	30.00	.00	15.2	.00	9.70	524.	?	.000	124	126 - HOOD
		.00		.00			?	.000		
6	30.00	.00	17.0	.00	9.61	424.	?	.000	155	126 - SE CORNER COUNTER
		.00		.00			?	.000		
7	30.00	.00	14.3	.00	9.01	488.	?	.000	186	126 - FLOOR BY RM 130
		.00		.00			?	.000		
8	30.00	.00	13.1	.00	9.35	535.	?	.000	217	126 - SOUTH COUNTER
		.00		.00			?	.000		
9	30.00	2.77	8.94	37.13	4.14	537.		13.422	248	130 - HOOD
		0.00		46.45				.000		
10	30.00	1.00	9.46	29.63	4.36	474.	1	29.633	278	130 - DOOR by hall
		0.00		37.75				.000		
11	30.00	3.23	8.82	31.57	4.30	518.		9.763	309	130 - N. SINK
		0.00		39.61				.000		
12	30.00	2.27	9.08	29.10	4.38	545.		12.838	340	130 - WHITE POWDER ON CART
		0.00		36.35				.000		
13	30.00	12.07	7.17	31.77	4.29	552.	1	2.633	371	132: COUNTER BY HALL
		0.00		39.21				.000		
14	30.00	7.03	7.98	25.67	4.49	420.	1	3.649	402	132: FLOOR BY HALL
		0.00		33.15				.000		
15	30.00	4.37	8.54	27.00	4.44	416.	1	6.183	433	132: FLOOR BY DOOR
		0.00		35.11				.000		
16	30.00	8.67	7.69	54.53	3.75	571.	1	6.292	464	132: HOOD
		0.00		67.60				.000		
17	30.00	.00	11.0	.00	5.74	497.	?	.000	495	134: E. COUNTER
		.00		.00			?	.000		
18	30.00	.00	16.6	.00	8.94	478.	?	.000	526	134: FLOOR BY HALL
		.00		.00			?	.000		
19	30.00	.00	16.3	.00	9.09	449.	?	.000	557	134: FLOOR BY TMC #1
		.00		.00			?	.000		
20	30.00	.00	18.6	.00	9.06	410.	?	.000	588	134: SINK
		.00		.00			?	.000		
21	30.00	4.77	8.45	.00	9.01	498.		.000	619	266 FLOOR BY HALL
		7.86		0.00				.000		
22	30.00	.00	15.0	.00	9.08	502.	?	.000	650	266 DESK TOP
		.00		.00			?	.000		
23	30.00	.00	10.5	.00	10.0	459.	?	.000	680	266 S. SINK
		.00		.00			?	.000		
24	30.00	.00	12.0	.00	9.52	501.	?	.000	711	266 FLOOR IN NW CORNER
		.00		.00			?	.000		

SWIPES OF Rm 126 (CERL) 1/25/83

Special Survey # B3-2


#	TIME	CPMA/K	%DEV	CPMB/K	%DEV	QIP	FLAGS	SCR	MIN	DESCRIPTION
3 15	5.00	24.29 20.80	19.6	.00 20.80	19.6	494		.000 1.000	89	
16	5.00	23.69 20.00	20.0	.00 20.00	20.0	490.		.000 1.000	94	
3 17	5.00	22.81 23.20	18.5	.00 22.80	18.7	519.		.000 .983	100	
3 20	5.00	26.14 36.20	14.8	.00 35.80	14.9	558.	1	.000 .989	106	NORTH COUNTER
4 21	5.00	40.25 37.80	14.5	.00 37.00	14.7	597.	1	.000 .979	112	CENTER COUNTER
3 5 22	5.00	41.88 70.40	10.6	.00 67.20	10.9	601.	1	.000 .955	118	REFRIGERATOR
6 23	5.00	77.97 46.60	13.1	.00 45.40	13.2	587.	1	.000 .974	124	HOOD -
7 24	5.00	51.68 38.60	14.4	.00 37.40	14.6	490.	1	.000 .969	130	FLOOR IN FRONT OF HOOD
3 8 25	5.00	44.02 36.60	14.7	.00 36.60	14.7	467.	1	.000 1.000	136	FLOOR BETWEEN N. & S. COUNTERS
9 26	5.00	42.03 35.20	15.0	.00 35.00	15.1	518.	1	.000 .994	141	FLOOR BETWEEN CENTER COUNTER & hood
		39.68		.00				.000		

#	S#	TIME	CPMA/K	%DEV	CPMB/K	%DEV	QIP	FLAGS	SCR	MIN	DESCRIPTION
10	27	5.00	40.20 45.47	14.1	39.00 .00	14.3	510.	1	.970 .000	147	FLOOR BETWEEN CENTER & S. COUNTER
11	28	5.00	34.20 37.91	15.2	34.00 .00	15.3	591.	1	.994 .000	153	SOUTH COUNTER
12	29	5.00	42.40 47.03	13.7	40.60 .00	14.0	586.	1	.958 .000	159	DESK TOP
13	30	5.00	34.60 38.36	15.2	34.20 .00	15.2	592.	1	.988 .000	165	FLAMMABLE LIQ. CABINET.

No detectable contamination on any of the swipes

M. Melanzone-Carter  
1/26/83





PROGRAM #:   
 REGION A: 6   
 REGION B: LL-UL= 0- 156 LCR= 0 BKG= 0 % 2 SIGMA= 1.0   
 TIME= 30 LL-UL= 4- 156 LCR= 0 BKG= 0 % 2 SIGMA= 1.0   
 J.00 QIP= SIE/REC SCR= A/B K= 1.000

R#	S#	TIME	CPMA/K DPM1/K	%DEV	CPMB/K DPM2/K	%DEV	QIP	FLAGS	SCR	MIN
6	①	30.00	26	7.14	22	7.71	848.	?	1.166	31
			27		0			?	.000	
6	②	30.00	26	7.22	22	7.84	860.	?	1.182	62
			27		0			?	.000	
6	③	30.00	60	4.72	56	4.88	883.	?	1.071	93
			62		0			?	.000	
6	④	30.00	33	6.40	29	6.80	842.	?	1.128	124
			34		0			?	.000	

Final  
 Cleanup Swipes  
 of spill in Rn 126  
 WJZ

REMOVABLE CONTAMINATION LEVELS (SMEARS)\*

Comprehensive Surveys  
of RAD AREAS

DAN TULLO  
Surveyor

Purpose of Survey

12/11/81  
Date

81-08

Location	1 BKG	2 Gross β cpm w/ <sup>3</sup> H	3 Net β cpm w/ <sup>3</sup> H	4 Gross β cpm w/o <sup>3</sup> H	5 Net β cpm w/o <sup>3</sup> H	6 Net β μCi w/o <sup>3</sup> H	7 Net <sup>3</sup> H cpm	8 Net <sup>3</sup> H μCi
RM 126 Hood sill	3.6	3.6	0.0					
Rm 126 floor by Hood	3.6	2.2	0.0					
126 Refrig	3.6	3.2	0.0					
130 Hood sill	3.6	3.6	0.0					
130 floor by liq. waste	3.6	6.4*	2.8					
130 Refrig	3.6	4.4	1.2					
132 Hood sill	3.6	10.6*	7.0					
132 Oxid. sill	3.6	8.4*	4.8					
132 floor	4.2	4.4	0.2					
134 Bench	4.2	4.8	0.6					

\* No smearing efficiency value is factored into these results.

Instrument used: NMC GFPC

LLD(95%) = \_\_\_\_\_ cpm

LLD(β w/o <sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

LLD(<sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

USE REVERSE SIDE FOR CALCULATIONS

REMOVABLE CONTAMINATION LEVELS (SMEARS)\*

81-15

DAN TULLO

Surveyor

Swipes of Duct work  
in Room 126  
 Purpose of Survey

7/13/81

Date

Location	1 BKG	2 Gross β cpm w/ <sup>3</sup> H	3 Net β cpm w/ <sup>3</sup> H	4 Gross β cpm w/o <sup>3</sup> H	5 Net β cpm w/o <sup>3</sup> H	6 Net β μCi w/o <sup>3</sup> H	7 Net <sup>3</sup> H cpm	8 Net <sup>3</sup> H μCi
Front Duct I	17.7	14.0	0.0					
Front Duct II	17.7	14.5	0.0					
Front Duct III	17.7	13.5	0.0					
Rear Duct I	17.7	16.0	0.0					
Rear Duct II	17.7	15.0	0.0					
Ducts in ceiling (Front)	17.7	14.0	0.0					
Ducts in ceiling (REAR)	17.7	27.5	10.0					

\* No smearing efficiency value is factored into these results.

Instrument used: \_\_\_\_\_

LLD(95%) = \_\_\_\_\_ cpm

LLD(β w/o <sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

LLD(<sup>3</sup>H) in μCi = \_\_\_\_\_ μCi


USE REVERSE SIDE FOR CALCULATIONS

FINAL CHECKOUT

1/14/81

J. Chiller  
Rm 126

81-8



**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 129 Final Contamination Survey.**

Description and Historic Use:

Triple lab (MB 125) converted to an office (225 ft<sup>2</sup>). Carbon-14 tracers, and nickel-63 and hydrogen-3:scandium sealed sources. No isotope use since prior to 1986. There is a record of a contamination event due to a tritium:scandium detector that was not properly vented. A record of the event and remediation is enclosed.

Surveys:

A total (fixed + removable) contamination survey was conducted in MB 129 in November 2004. This room has been an unrestricted area since prior to 1986; radioactive materials were not used in this area after 1985.

All points surveyed (6 total) demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities.

We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. A record of the most recent historic surveys (i.e. prior to the final decommissioning survey) of MB 129 is included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector.

NHEERL-WED  
RADIATION AREA SURVEY  
FIXED SURVEY

LOG NO. 04-23

DATE 11-16-04

LOCATION MB ROOM 129

INSTRUMENT Ludlum 2000 Scaler PANcake Probe #49  
SERIAL NO. 83810 / PR 070834

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	66	LLD <sub>95</sub>	NA
2	44	↓	↓
3	22	↓	↓
4	32	↓	↓
5	48	↓	↓
6	42	↓	↓

LLD<sub>95</sub> = { (  $\frac{\sqrt{22}}{0.5}$  ) X 2.96 } + ( 72 ) CPM  
 BACKGROUND STANDARD ( <sup>14</sup>C 0.16  $\frac{\mu}{g}$  ) 44 CPM 11.790 CPM 3.2%  
 Time 0.5 min.

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>

LLD<sub>95</sub> = { ( ----- ) X 2.96 } + = CPM  
 BACKGROUND STANDARD ( ----- ) = CPM

COMMENTS:



P Monac 11-16-04  
RADIATION SPCL. DATE

NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION 11B

ROOM 129



ALL WALL SWIPES



REMOVABLE CONTAMINATION LEVELS (SMEARS)\*

DANTULLO  
Surveyor

Comprehensive surveys

10/28/81

Purpose of Survey

Date

81-07

	1	2	3	4	5	6	7	8
Location	BKG	Gross β cpm w/ <sup>3</sup> H	Net β cpm w/ <sup>3</sup> H	Gross β cpm w/o <sup>3</sup> H	Net β cpm w/o <sup>3</sup> H	Net β μCi w/o <sup>3</sup> H	Net <sup>3</sup> H cpm	Net <sup>3</sup> H μCi
Rm 130-Sink	11.0	12.6	1.2					
Rm 130-floor	11.0	8.4	0.0					
<sup>129</sup> on Rm <del>128</del> -Hood	11.0	8.4	0.0					
<sup>129</sup> on Rm <del>128</del> -floor	11.0	7.4	0.0					
Rm 128-Middle desk	11.0	10.8	0.0					
Hall outside 130	11.0	10.2	0.0					
Hall outside 132	11.0	12.4	1.4					
Rm 228 Hood Rt	6.0	4.8	0.0					
Rm 228 Refrig	6.0	7.2	1.2					
Rm 228 LSS	6.0	6.8	0.8					
Rm 228 Hood Lt	6.0	6.6	0.6					

\* No smearing efficiency value is factored into these results.

Instrument used: \_\_\_\_\_

LLD(95%) = \_\_\_\_\_ cpm

LLD(β w/o <sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

LLD(<sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

USE REVERSE SIDE FOR CALCULATIONS

Tritium Contamination Incident of 23 March 1979

April 5, 1979

M. H. Feldman, RSO

### The Record

On 23 March 1979 a tritium contamination of room 125 was observed after use of the gas chromatograph and its scandium hydride source.

Roger Henderson [Northrup] was using the G.C. on a trial basis, over a six hour period ( $\pm 1$  hour by personal estimate), to do an endosulfan analysis. The tritium source has not been used in approximately 6 months but in the interim the safety exit tube [an original requirement the RSO had specified to Jay Gile (C.O.) to whom the source was entrusted] had been removed. In addition the vent to which the tube would have led was closed so no net flow from the G.C. exit port to the vent occurred. James Collins [Northrup] was unaware the vent was closed and failed to tell Henderson the safety exit tube was absent.

Tritium hot spots were observed in room 125 with some transfer to 130, 126, and 138, as well as 284, by personnel foot traffic. A small amount was found in corridors outside of 125, 130, 126.

During the following 3 days clean up operations were carried out to remove the floor contamination and decontamination is underway 4/2/79 on surfaces benches and property items in room 125.

During the times after first swipe detection of the contamination, personnel were monitored by bioassay for tritium content. For 4 persons monitored no tritium content above background was observed. For 5 persons a very low content, twice background in worst case was observed. This low body burden, giving a dose of about 0.3 MR ( $< 1/15,000$  of annual allowable dose) is the first time any CERL personnel have had a body burden above background since the inception of the RSO program for Radiation Health and Safety.

In the future the following procedures will be used.

1. All safety items on the gear as approved by RSO will be utilized.
2. A sign listing safety point checks will be posted.
3. The temperature controller will be monitored while the run is underway.

In addition before this G.C. is put back into regular use, some safety tests will be made at short time intervals.

1. Check safety exit port tube for tritium contamination.
2. Check gas in  $N_2$  tank for purity and check oxygen removal attachment for its action.
3. Try a small endosulfan injection followed by inspection of the safety tube.

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 130 Final Contamination Survey.**

Description and Historic Use:

Single lab (225 ft<sup>2</sup>). Potentially hydrogen-3, carbon-14, and chromium-51 tracers, and nickel-63 and hydrogen-3:scandium sealed sources. Hydrogen-3 and chromium-51 were used as tracers in the 1990's. This room was decommissioned as a unrestricted area on May 11, 1994. No isotope use since 1994. There is no record of leakage of any sealed sources used in this area.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in MB 130 at the time of restricted use decommissioning. All points surveyed demonstrated no significant contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. A HVAC duct swipe was made in November 2004 which detected 0.47 Bq/100 cm<sup>2</sup> of carbon-14.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events (a small tritium contamination event from a sealed source in MB 125 was reported in 1979), and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of MB 130 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 3 Survey Meter equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
ENVIRONMENTAL RESEARCH LABORATORY  
200 S.W. 35TH STREET  
CORVALLIS, OREGON 97333

file

M E M O R A N D U M

Date: May 11, 1994  
From: Jay D. Giles, Radiation Safety Officer  
To: Peter Beedlow, Branch Chief  
Copies:  
Subject: Decommissioning of MB 130 Laboratory

As of today, all radioactive materials are removed from the main building laboratory room 130. Following removal of the radioisotopes, all equipment used for isotope work as well as the hood, storage cabinets, and facilities were cleaned and surveyed for evidence of radio-contamination.

Results of the survey (on file) demonstrates that the laboratory is free from radioisotope contamination. All radiation signs, labels, and NRC postings are removed. The authorization to use radioactive materials in MB 130 is deactivated and the room decommissioned from service as an radioisotope lab. Lab MB 130 is now classified as a "non-restrictive use" work area.

If you wish to use radioisotopes in MB 130 in the future, petition for re-authorization by the Radiation Safety Committee must be pursued.

If you have questions, please contact me.

cc: C. McFarlane

U.S EPA  
ENVIRONMENTAL RESEARCH LABORATORY -CORVALLIS

Log No. 94-8

RADIATION CONTAMINATION SURVEY

Date: 5-12-94 Type of Survey: REMOVABLE & FIXED

Isotope(s): β

Gross Background Counts: 17 ± CPM Total Count Time (min.): 2'

Lower Limits of Detection:  $(\sqrt{17/2}) 2.96 = 6$  cpm

Instrument Used:  GFPC  LSC  GM  Ion Chamber  Scintillation Model: PACKARD LSC 2200 S/N: \_\_\_\_\_

Background: 17 CPM±SD 19 DPM±SD Standard (<sup>14</sup>C NEN 84,000)  $80,390/84,000 = 96\%$  eff 3 Error

Swipe No.	Room No.	Swipe Description	Nuclide: <u>REMOVABLE</u> per 100 cm <sup>2</sup>			Nuclide: <u>FIXED</u> per 100 cm <sup>2</sup> *		
			NET.CPM±SD	Net DPM	Net Activity pCi	CPM±SD	Net DPM	Net Activity
2	130	Cell HARVESTER	4	LUDS	0			
	Y	CELL HARVESTER	9	29	13 pCi			
		Hood FLOOR - E	7	26	12			
5		Hood FLOOR - W	3	LUDS	0			
		Sill	1	LUDS	0			
		SASH	7	26	12			
		Floor <sup>(hood)</sup> - E	6	25	11			
		Floor <sup>(hood)</sup> - W	11	31	14			
		Hood E WALL						
		Hood W WALL						
		Hood Back WALL						
10		<sup>Hood</sup> Cabinet - E	2	LUDS	0			
11	✓	<sup>Hood</sup> Cabinet - W	7	26	12			

Comments: \* Fixed: Ludlum #3 s/N 97146 ✓ 11,000 cpm BICRED 100 cpm  
 ALL SWIPES Below action level. NO further <sup>15</sup>C eff 45%  
 decr taken when necessary.  
 J. A. Morn, 5/12/94  
 Radiation Safety Date

U.S. EPA  
ENVIRONMENTAL RESEARCH LABORATORY - CORVALLIS

Log No. 2/2

RADIATION CONTAMINATION SURVEY RM 130

Date: 5/12/74 Type of Survey: Removable Contamination

Isotope(s):  $\beta$

Gross Background Counts: 21 ± CPM Total Count Time (min.): 2'

Lower Limits of Detection:  $(\sqrt{21/2})2.96 = 7$  cpm

Instrument Used:  LSC  Ion Chamber Model: LSC Packard 2200 S/N: \_\_\_\_\_  
 GM  Scintillation

Background: 21 CPM±SD 23 DPM±SD Standard ( ): % Error

Swipe No.	Room No.	Swipe Description	Nuclide: _____ per 100 cm <sup>2</sup>			Nuclide: _____ per 100 cm <sup>2</sup>		
			Net CPM±SD	Net DPM	Net Activity	CPM±SD	Net DPM	Net Activity
2	130	Freezer (small) in	2	<LD <sub>95</sub>				
3		" " out	0	∅				
4		refrigerator north in	3	<LD <sub>95</sub>				
5		" " out	0	∅				
6		refrigerator south in	0	∅				
7		" " out	0	∅				
8		incubator in	0	∅				
9		" " out	6	<LD <sub>95</sub>				
10		plate counter	6	<LD <sub>95</sub>				
11		desk/computer	0	∅				

Comments: \_\_\_\_\_

Radiation Safety \_\_\_\_\_ Date \_\_\_\_\_

(979)

89-36 1/1

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: <sup>35</sup>S <sup>51</sup>Cr

Date: 10/27/89

Method of Detection: LSC

*Shirley Mon*  
Radiation Safety Technician

Cassette "B+C"

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
1	294	Bkbed	23	N/A				
		N Hood sill	0					
		N. SASH	0					
		N. hood EX.	0					
		N Floor (Hval)	0					
		N Floor (Counter)	0					
		Phone	0					
		door	0					
	130	door	0					
		Phone Floor	0					
		Floor	0					
		Floor	0					
		Counter	2					
		Hood	0					
		Computer	0					

Calculation of Lower Limits of Detection (LLD)

Nuclide: <sup>230</sup> Nuclide: \_\_\_\_\_

Gross Background Counts:  
Total Background Count time:

230  
10

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) =

7

REMARKS:



89-8

Survey of 130 After  
Clean up

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: 3H

Date: 5-19-81

Method of Detection: LES-LSC

D. A. Mon  
Radiation Safety Technician

Swipe #	Location RM # Area	Gross Nuclide: <sup>3</sup> H		NET <sup>3</sup> H	NET DPM	μCi	DPM Nuclide:		NET DPM	μCi
		NET GPM	NET DPM				NET DPM	NET DPM		
1		Background	38.9	177.3			38.90			
2		Hood Floor	28.4	0						
3		Hood Floor	38.4	2			<			
4		Hood Sill	33.8	0						
5		Hood Sill	35.7	0						
6		Hood wall Duct	41.31	1			<			
7		Hood wall Sides	35.78	0						
8		Hood Cabinet	41.36	1			<			
9		Refr	43.04	1			<			
10		Door	43.21	0						
11		Sink	32.51	0						
12		Phone	20.59	0						
13		Floor	54.62	0						
14		Floor	43.26	0						
15		Floor (Door)	31.72	0						

Calculation of Lower Limits of Detection (LLD)

Nuclide: <sup>3</sup>H Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

52  
3'

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

11

REMARKS:

2.22x10<sup>6</sup> dpm/uCi

2.22x10<sup>3</sup> dpm/nCi

2.22 x

2.22x10<sup>4</sup> uCi

2.22x10 m

2.22 dpm/pCi

### AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: 3H

Date: 5-14-89

Method of Detection: LSC

Radiation Safety Technician

Swipe #	Location		Gross Nuclide:			DPM Nuclide:		pCi/NET
	RM #	Area	NET DPM	NET DPM	NET DPM	NET DPM	NET DPM	
16		Refer top	34.4	0				
17		N Counter	27.5	0				
18		S. Counter	36.5	0				
19		Back bottom	159.21	35		120		54/100 cm <sup>2</sup>
		109 dpm 3H	189.8	67		148		67
		2924 dpm 3H	2859.2	1291		2820		
		272 dpm 3H	321.3	132		282		

#### Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

REMARKS:

~~90~~

1/

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: <sup>51</sup>Cr

Date: 7-6-90

Method of Detection: LSC-460

Philip M...

Radiation Safety Technician  
<sup>14</sup>C, <sup>51</sup>Cr, <sup>35</sup>S

3H

Swipe #	Location		Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi
1		Bkbrd	9.8	—	N/A
2	130	Counter	1	<	
3		Counter	0	N/A	
4		Floor	0	N/A	
5		Floor	0	N/A	
6		Desk	1	<	
7		Door	0	N/A	✓

Nuclide:		
NET CPM	NET DPM	μCi
12	—	N/A
1	<	
0	N/A	
3	<	
0	N/A	
0	N/A	
5	6	✓

Calculation of Lower Limits of Detection (LLD)

Gross Background Counts:  
Total Background Count time:

Nuclide: <u>3H</u>	Nuclide: <u><sup>14</sup>C, <sup>51</sup>Cr, <sup>35</sup>S</u>
<u>100</u>	<u>120</u>
<u>10'</u>	<u>10</u>
<u>5</u>	<u>5</u>

(95%) =  $\frac{\sqrt{\text{Gross Background Counts}}}{\text{Count Time}} \times 4.66$

LLD (95%) =

REMARKS:

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**

**Subject: Room Survey: Main Building 131 Final Contamination Survey.**

Description and Historic Use:

Triple lab (MB 125) converted to single office (225 ft<sup>2</sup>). Carbon-14 tracers, and nickel-63 and hydrogen-3:scandium sealed sources. No isotope use since prior to 1986. There is a record of a contamination event due to a tritium:scandium detector that was not properly vented. A record of the event and remediation is found under MB 129.

Surveys:

A total (fixed + removable) contamination survey was conducted in MB 131 in November 2004. This room has been an unrestricted area since prior to 1986; radioactive materials were not used in this area after 1985.

All points surveyed (6 total) demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities.

We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. A record of the most recent historic surveys (i.e. prior to the final decommissioning survey) of MB 131 is included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector.




NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION MB

ROOM 131



ALL WALL SWIPES

84-32

131

WEEKLY AREA MONITORING: 11/13/84

GRAM #: 5

REGION A: LL-UL= 0- 12 LCR= 0 BKG= 0 % 2 SIGMA= 10.0  
 REGION B: LL-UL= 12- 156 LCR= 0 BKG= 0 % 2 SIGMA= 10.0  
 NUCLIDE 1 = 434900 NUCLIDE 2 = 42000  
 TIME= 10.00 QIP= SIE/REC SCR= B/A K= 1.000

#	S#	TIME	CPMA/K DPM1/K	%DEV	CPMB/K DPM2/K	%DEV	QIP	FLAGS	SCR	MIN	
5	1	10.00	8.50	21.6	13.70	17.0	741.	B	1.612	11	
5	2	10.00	11.50	18.6	13.20	17.4	744.	B	1.148	22	Blanks
5	3	10.00	9.80	20.2	11.00	19.0	743.	B	1.122	33	
			9.93		12.63		743.		1.272		
5	4	10.00	1.37	18.8	4.17	15.4	691.		3.049	43	
			2.44		4.67				1.914		Rm 232/236
5	5	10.00	.00	23.7	3.97	15.5	698.	?	.000	54	
			0.00		4.84				.000		Rm 256
5	6	10.00	.00	20.3	6.67	14.4	644.	?	.000	65	
			0.00		8.16				.000		Rm 258
5	7	10.00	1.67	18.5	4.77	15.1	633.	(1)	2.860	76	
			3.41		5.30				1.554		Rm 190
5	8	7.39	.00	23.7	41.36	10.0	580.	(1)	.000	84	
			0.00		50.89				.000		Rm 131- Oil dip
5	9	10.00	.00	21.0	5.17	14.9	656.	?	.000	95	
			0.00		6.32				.000		Rm 132
5	10	10.00	2.57	17.8	4.57	15.2	633.	(1)	1.779	106	
			6.05		4.76				.787		Rm 131-Floor swipe
5	11	1.15	35.28	27.7	332.58	10.0	432.	(2)	9.426	108	
			53.20		400.51				7.529		Freeze dryer oil- 1 ml

Warren Tinkler 11/13/84

REMOVABLE CONTAMINATION LEVELS (SMEARS)\*

86-04

BD Pichett  
Surveyor

Weekly Survey  
Purpose of Survey

5/9/80  
Date

	1	2	3	4	5	6	7	8
Location	BKG	Gross β cpm w/ <sup>3</sup> H	Net β cpm w/ <sup>3</sup> H	Gross β cpm w/o <sup>3</sup> H	Net β cpm w/o <sup>3</sup> H	Net β μCi w/o <sup>3</sup> H	Net <sup>3</sup> H cpm	Net <sup>3</sup> H μCi
#131 Floor	45.6	45.8	<LLD 0.2	—	—	—	—	—
131 Desk	"	42.8	<LLD 0.0					
134 Floor	"	44.8	<LLD 0.0					
134 micro #1	"	47.6	<LLD 2.0					
126 Floor	"	45.0	<LLD 0.0					
126 bench	"	45.2	<LLD 0.0					
130 Floor	"	47.6	<LLD 2.0					
130 hood	"	46.8	<LLD 1.2					
190 floor	"	45.8	<LLD 0.2					
190 RAM stor	"	46.2	<LLD 0.6					

\* No smearing efficiency value is factored into these results.

Instrument used: NMCGEPC

LLD(95%) = 14.1 cpm = 4.66  $\frac{\sqrt{228}}{5}$

LLD(β w/o <sup>3</sup>H) in μCi = 1.13 × 10<sup>-5</sup> μCi

LLD(<sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

USE REVERSE SIDE FOR CALCULATIONS



REMOVABLE CONTAMINATION LEVELS (SMEARS)\*

80-03

BD Pickett  
Surveyor

Weekly Swipes  
Purpose of Survey

4/25/80  
Date

	1	2	3	4	5	6	7	8
Location	BKG	Gross β cpm w/ <sup>3</sup> H	Net β cpm w/ <sup>3</sup> H	Gross β cpm w/o <sup>3</sup> H	Net β cpm w/o <sup>3</sup> H	Net β μCi w/o <sup>3</sup> H	Net <sup>3</sup> H cpm	Net <sup>3</sup> H μCi
# 131 floor	37.2	35.2	< LLD 0.0	N/A	N/A	—	—	—
# 131 LSS	37.2	36.4	< LLD 0.0					
# 134 floor	37.2	38.0	< LLD 0.8					
# 134 microcosm	37.2	37.8	< LLD 0.6					
# 126 floor	37.2	34.8	< LLD 0.0					
# 126 bench	37.2	35.2	< LLD 0.0					
# 130 floor	37.2	35.0	< LLD 0.0					
# 130 bench	37.2	37.6	< LLD 0.4					

\* No smearing efficiency value is factored into these results.

Instrument used: NM(GFPC I)

LLD(95%) = 12.71 cpm =  $4.66 \frac{\sqrt{186}}{5}$

LLD(β w/o <sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

LLD(<sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

USE REVERSE SIDE FOR CALCULATIONS

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 132 Final Contamination Survey.**

Description and Historic Use:

Single Lab (225 ft<sup>2</sup>). Potentially hydrogen-3 and carbon-14 tracers, and nickel-63 and hydrogen-3:scandium sealed sources. No isotope use since prior to 1990. There is no record of leakage of any sealed sources used in this area.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in MB 132 in November 2004. All points surveyed (12 total and 12 removable) demonstrated no significant contamination. Three points indicated very low levels of removable contamination from tritium (0.28 – 0.40 Bq/100 cm<sup>2</sup>). All other sampling points were at background. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. A HVAC duct swipe was made in November 2004 which detected contamination of 0.83 Bq/100 cm<sup>2</sup> of carbon-14.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of MB 132 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.



NHEERL-WED  
RADIATION AREA SURVEY

LOG NO. OA-23

DATE 11-11-04

LOCATION MB

ROOM 132

INSTRUMENT Packard LSC 2200 CA  
SERIAL NO. Q 36755

3H

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	4	<LLD <sub>95</sub>	ND
2	4	↓	↓
3	8	17	0.28
4	6	<LLD <sub>95</sub>	ND
5	11	24	0.40
6	4	<LLD <sub>95</sub>	ND
7	4	↓	↓
8	6	↓	↓
9	10	20	0.33
10	4	<LLD <sub>95</sub>	ND
11	6	↓	↓
12	5	↓	↓

LLD<sub>95</sub> =  $\left\{ \left( \frac{\sqrt{12}}{3} \right) \times 2.96 \right\} + =$  7 CPM  
BACKGROUND STANDARD (3H) 64,179 DPM = 56,056 DPM (87% eff.)

14C

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
	17	<LLD <sub>95</sub>	ND
	15	↓	↓
	16	↓	↓
	13	↓	↓
	18	↓	↓
	18	↓	↓
	13	↓	↓
	13	↓	↓
	17	↓	↓
	17	↓	↓
	21	↓	↓
	16	↓	↓

LLD<sub>95</sub> =  $\left\{ \left( \frac{\sqrt{66}}{3} \right) \times 2.96 \right\} + =$  22 CPM  
BACKGROUND STANDARD (14C) 89,600 DPM = 85,603 DPM (102% eff.)

COMMENTS:



D. Monan  
RADIATION SPCL. DATE 11-18-04

NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION MD

ROOM 132



U.S. EPA  
ENVIRONMENTAL RESEARCH LABORATORY - CORVALLIS

Log No. 90-40 1/3

RADIATION CONTAMINATION SURVEY

Date: 12-3-90 Type of Survey: Non-Removable Contamination

Isotope(s): P & X

Gross Background Counts: \_\_\_\_\_ CPM Total Count Time (min.): \_\_\_\_\_

Lower Limits of Detection:  $\sqrt{75 \times 4.66} = 40.4$  40.4 cpm

Instrument Used:  GFPC  LSC  GM  Ion Chamber  Scintillation Model: Ludlum #3 SIN: 77222

Background: 75 CPM±SD DPM±SD Standard (<sup>137</sup>CS  $\approx$  1 uCi / 11k cpm): 11,025 cpm % Error

Swipe No.	Room No.	Swipe Description	Nuclide: _____ per 100 cm <sup>2</sup>			Nuclide: _____ per 100 cm <sup>2</sup>		
			net CPM±SD	Net DPM	Net Activity	CPM±SD	Net DPM	Net Activity
	<sup>MB</sup> 138	Hoods	Ø					
		Sink	Ø					
		Floor	Ø					
		Desk	Ø					
		Door	Ø					
	132	Hoods	Ø					
		Sink	Ø					
		Floor	Ø					
		Bench	Ø					
		door	Ø					
	258	Hood <sup>ft. wall</sup>	450 <sup>±</sup>					
		Floor	Ø					
		Sinks	Ø					
		Door	Ø					
	256	Hood	Ø					
		Floor	Ø					
		Phone	Ø					
		door	Ø					

+: + will label this non-removable contamination

Chapman 12/3/90  
Radiation Safety Date

U.S. EPA  
 ENVIRONMENTAL RESEARCH LABORATORY -CORVALLIS  
 RADIATION CONTAMINATION SURVEY

Log No. 2/3

Date: \_\_\_\_\_ Type of Survey: \_\_\_\_\_

Isotope(s): \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  $\pm$  \_\_\_\_\_ CPM Total Count Time (min.): \_\_\_\_\_

Lower Limits of Detection: \_\_\_\_\_ = \_\_\_\_\_ cpm

Instrument Used:  GFPC  LSC  GH  Ion Chamber  Scintillation Model: \_\_\_\_\_ S/N: \_\_\_\_\_

Background: \_\_\_\_\_ CPM $\pm$ SD \_\_\_\_\_ DPM $\pm$ SD Standard ( \_\_\_\_\_ ): \_\_\_\_\_ % Error

Swipe No.	Room No.	Swipe Description	Nuclide: _____ per 100 cm <sup>2</sup>			Nuclide: _____ per 100 cm <sup>2</sup>		
			net CPM $\pm$ SD	Net DPM	Net Activity	CPM $\pm$ SD	Net DPM	Net Activity
236		S. Hood	$\emptyset$					
		Floor	$\emptyset$					
		Sink	$\emptyset$					
		door	$\emptyset$					
		N. Hood	$\emptyset$					
2326		Dink	$\emptyset$					
		Phone	$\emptyset$					
		Floor	$\emptyset$					
		Counter	$\emptyset$					
228		S. Hood	$\emptyset$					
		Floor	$\emptyset$					
		door	$\emptyset$					
		Sink	$\emptyset$					
		N. Hood	$\emptyset$					
236P		Photo lab - sink	$\emptyset$					
		Floor	$\emptyset$					
		Counter	$\emptyset$					
274		N. Hood	$\emptyset$					
		Floor	$\emptyset$					
		Sink	$\emptyset$					

U.S. EPA  
 ENVIRONMENTAL RESEARCH LABORATORY -CORVALLIS  
 RADIATION CONTAMINATION SURVEY

Log No. \_\_\_\_\_ 3/3

Type of Survey: \_\_\_\_\_

Isotope(s): \_\_\_\_\_

Cross Background Counts: \_\_\_\_\_  $\pm$  CPM      Total Count Time (min.): \_\_\_\_\_

Lower Limits of Detection: \_\_\_\_\_ cpm:

Instrument Used:  GFPC       Ion Chamber      Model: \_\_\_\_\_ S/N: \_\_\_\_\_  
 LSC       Scintillation

Background: \_\_\_\_\_ CPM $\pm$ SD      \_\_\_\_\_ DPM $\pm$ SD      Standard ( \_\_\_\_\_ ): \_\_\_\_\_ % Error

Room No.	Swipe Description	Nuclide: _____			Nuclide: _____			
		Net CPM $\pm$ SD	Net DPM	Net Activity	CPM $\pm$ SD	Net DPM	Net Activity	
294	A. Hood	Ø						
C-1	door	Ø						
	1-floor	Ø						
NERF	Rad Lab Hood	Ø						
	Floor	Ø						
	Bench	Ø						
	door	Ø						



100

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: <sup>3</sup>H

Date: 8/29/90

Method of Detection: LSC-2200

PA. Mo  
Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
		BKGRD	(14)	(35)				
		STD	—	—				
	132	Hood Sill	1	LLD <sub>95</sub>				
		Hood Sash	8	LLD				
		Hood interior	16	55				
		Hood interior	2	LLD				
		Floor	12	58				
		Floor	6	LLD				
		Floor (SW)	1	LLD				
		door	2	LLD				
		<sup>3</sup> H STD 278 dpm	195	352				
		<sup>3</sup> H STD 2924	1,532	2,804				
		<sup>3</sup> H STD 29,161	14,581	26,914				

Calculation of Lower Limits of Detection (LLD)

Nuclide: <sup>3</sup>H Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

42 \_\_\_\_\_

$$LLD (95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$$

10 \_\_\_\_\_

LLD (95%) = \_\_\_\_\_

REMARKS:

Post 132 B&P SH Cleanup

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: <sup>3</sup>H

Date: 6-13-89

Method of Detection: LSC

Chris A. Monahan  
Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	µCi	NET CPM	NET-DPM	µCi
0	132	BKGRD	14	31				
1-12	↓	GLASSWARE Hood Counter	Prior to final wash			(see printout)		
13		Hood Sill	3	<LLD				
14			0					
15		Hood SMH	2	<LLD				
16		Hood VENT	0					
17		Hood WALL INSIDE	4	<LLD				
18		FLOOR (by Hood)	1	<LLD				
19		FLOOR (by Hood)	0					
20		Sink	0					
21		Sink	0					
22		FLOOR (by Sink)	0					
23		FLOOR (by Sink)	1	<LLD				
24		N. Counter	5	<LLD				
25		Phone	1	<LLD				

Calculation of Lower Limits of Detection (LLD)

Nuclide: <sup>3</sup>H      Nuclide: \_\_\_\_\_

Gross Background Counts:  
Total Background Count time:

42  
3

$(95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) =

10

REMARKS:

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: \_\_\_\_\_

Date: \_\_\_\_\_

Method of Detection: \_\_\_\_\_

Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	µCi	NET CPM	NET DPM	µCi
		Dool	0					
		Floor (by door)	7	LLD				
		<sup>3</sup> H STD 109	64	145				
		<sup>3</sup> H STD 272	120	255				
		<sup>3</sup> H STD 2,924	1315	2843				

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
 Total Background Count time: \_\_\_\_\_

\_\_\_\_\_  
 \_\_\_\_\_

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

REMARKS:

89-32

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: Cr<sup>51</sup>

Date: 9-8-89

Method of Detection: LSC-460

Philip A. Mon  
Radiation Safety Technician

Bk620

23

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	µCi	NET CPM	NET DPM	µCi
2	132	Door	8	8				
3		FLOOR E	0	N/A				
4		Counter <sup>N</sup>	0	N/A				
5		Counter <sup>S</sup>	1	<LLD <sub>95</sub>				
6		W FLOOR	3	<LLD <sub>95</sub>				
7		Desk	0	N/A				
8		hood	0 <sup>DPM</sup>	N/A				
9		hood exhaust	0 <sup>DPM</sup>	<LLD <sub>95</sub>				
10		hood sill	0	N/A				
		1079 STD C <sup>14</sup>	1053	1132				
		10400 STD C <sup>14</sup>	10,022	10,785				
		109,000 STD C <sup>14</sup>	100,377	108,012				

Calculation of Lower Limits of Detection (LLD)

Nuclide: Cr<sup>51</sup> Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

230  
10'

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

7

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 133 Final Contamination Survey.**

Description and Historic Use:

Triple lab (MB 125) converted to single office (225 ft<sup>2</sup>). Carbon-14 tracers, and nickel-63 and hydrogen-3:scandium sealed sources. No isotope use since prior to 1986. There is a record of a contamination event due to a tritium:scandium detector that was not properly vented. A record of the event and remediation is found under MB 129.

Surveys:

A total (fixed + removable) contamination survey was conducted in MB 131 in November 2004. This room has been an unrestricted area since prior to 1986; radioactive materials were not used in this area after 1985.

All points surveyed (6 total) demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities.

We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. A record of the most recent historic surveys (i.e. prior to the final decommissioning survey) of MB 133 is included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector.

NHEERL-WED  
RADIATION AREA SURVEY  
FIXED SURVEY

LOG NO. 04-23

DATE 11-16-04

LOCATION MP

ROOM 1331

INSTRUMENT Ludlum 2000 Scaler PANCAKE Probe #9  
SERIAL NO. 83810 / PR 070834

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	38	LLD's	NA
2	32	↓	
3	36	↓	
4	38	↓	
5	36	↓	
6	38	↓	

$LLD_{95} = \left\{ \left( \frac{\sqrt{22}}{0.5} \right) \times 2.96 \right\} + 72$  CPM  
BACKGROUND STANDARD (<sup>14</sup>C 0.168 ) 14,790 CPM  
TIME 0.5 min. MCi 3.2%

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>

$LLD_{95} = \left\{ ( \dots ) \times 2.96 \right\} + \dots$  CPM  
BACKGROUND STANDARD ( \_\_\_\_\_ ) \_\_\_\_\_

COMMENTS:

D. Monaco  
RADIATION SPCL.



11-16-04  
DATE

NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION 11B

ROOM 133



All Wall Surveys

Surveys, 12/2, 12/9, cont.

1-5-84

83

S#	TIME	CPMA/K DPM1/K	%DEV	CPMB/K DPM2/K	%DEV	QIP	FLAGS	SCR	MIN#	DESCRIPTION
26	30:00	1.28 1.70	13.0	.00 0.00	8.90	576.	RM 132	.000 .000	803	TABLE SURFACE ALONG N. WALL
27	30:00	.98 1.29	13.3	.00 0.00	10.0	580.	RM	.000 .000	834	FLOOR BY LSC
28	30:00	1.78 2.84	12.6	.00 0.00	8.91	506.	133	.000 .000	865	FLOOR BY FREEZE DRYER
29	30:00	5.01 4.15	10.7	3.40 4.04	7.70	548.		.678 .974	896	FREEZE DRYER
30	30:00	26.14 0.00	6.39	387.20 495.88	1.81	458.		14.810 .000	926	ROOT RENSE ALIQUOT
31	30:00	.24 .31	14.0	.00 0.00	10.3	601.	12/9/83 RM	.000 .000	957	MICROCOSM 7
32	30:00	.88 1.10	13.4	.00 0.00	10.0	602.	G-3	.000 .000	988	TABLETOP BY SINK
33	30:00	.00 .00	16.2	.00 .00	9.93	530.	? ?	.000 .000	1019	FLOOR BY DRY WASTE
34	30:00	.91 1.13	13.3	.00 0.00	10.1	609.		.000 .000	1050	ANALYTIC BALANCE
35	30:00	3.71 1.05	11.4	4.80 5.85	7.47	548.	RM 256	1.293 5.558	1081	TABLETOP BY SINK
36	30:00	2.08 2.63	12.4	.00 0.00	8.85	598.		.000 .000	1112	HOOD SASH
37	30:00	.98 1.27	13.3	.00 0.00	9.63	587.		.000 .000	1143	INTERIOR OF BROKEN GLASS CONTAINER
38	30:00	8.44 0.00	9.44	30.27 37.25	5.20	591.		3.584 .000	1173	OXIDIZER
39	30:00	.88 1.12	13.4	.00 0.00	9.19	596.	RM	.000 .000	1204	HOOD FLASHING
40	30:00	.68 .89	13.6	.00 0.00	9.76	582.	258	.000 .000	1235	HOOD SASH
41	30:00	.54 .69	13.7	.00 0.00	10.0	597.		.000 .000	1266	DOOR HANDLE
42	30:00	.38 .50	13.9	.00 0.00	9.61	583.		.000 .000	1297	TABLETOP BY CYART RECORDER
43	30:00	.38 .61	13.9	.00 0.00	8.47	504.	RM	.000 .000	1328	FLOOR SPILL
44	30:00	1.88 0.00	12.6	7.27 8.97	7.12	576.	G-3	3.870 .000	1359	MICROCOSM 14
45	30:00	.00 .00	14.6	.00 .00	9.81	577.	? RM ? 190	.000 .000	1389	TABLETOP BY SINK
46	30:00	77.44 0.00	3.98	1331.40 1768.59	.99	388.	?	17.192 .000	1420	AQUEOUS SOLNS FROM G-3

Harmon K. Jenkins 1/5/84



REMOVABLE CONTAMINATION LEVELS (SMEARS)\*

Dan Tullio H.P.

Weekly Swipe

8/17/82

Surveyor

Purpose of Survey

Date

Location	1	2	3	4	5	6	7	8	92-
	BKG	Gross B cpm w/ <sup>3</sup> H	Net B cpm w/ <sup>3</sup> H	Gross B cpm w/o <sup>3</sup> H	Net B cpm w/o <sup>3</sup> H	Net B $\mu$ Ci w/o <sup>3</sup> H	Net <sup>3</sup> H cpm	Net <sup>3</sup> H $\mu$ Ci	
Rm 149 G.C. Top surface	32.2	62.3	30.1					.011	
Rm 149 G.C. oven	32.2	87.0	54.8					.021	
149 front Top controls G.C.	32.2	16,491	16,459					6.178	
130 Hood	32.2	55.3	23.1					$2 \times 10^5$	
130 Bench	32.2	45.3	13.1					—	
132 Oxidizer	32.2	33.0	0.8					—	
132 Hood	32.2	132.6	100.4					$9 \times 10^5$	
134 Hall outside	32.2	34.6	2.4					—	
134 Bench	32.2	37.6	5.4					—	
134 floor	32.2	40.0	7.8						

\* No smearing efficiency value is factored into these results.

Instrument used: \_\_\_\_\_

LLD(95%) = \_\_\_\_\_ cpm

LLD(B w/o <sup>3</sup>H) in  $\mu$ Ci = \_\_\_\_\_  $\mu$ Ci

LLD(<sup>3</sup>H) in  $\mu$ Ci = \_\_\_\_\_  $\mu$ Ci

USE REVERSE SIDE FOR CALCULATIONS

REMOVABLE CONTAMINATION LEVELS (SMEARS)\*

Dan Tullo

Surveyor

Wet swipes (cont)

Purpose of Survey

8/17/82

Date

	1	2	3	4	5	6	7	8
Location	BKG	Gross β cpm w/ <sup>3</sup> H	Net β cpm w/ <sup>3</sup> H	Gross β cpm w/o <sup>3</sup> H	Net β cpm w/o <sup>3</sup> H	Net β μCi w/o <sup>3</sup> H	Net <sup>3</sup> H cpm	Net <sup>3</sup> H μCi
133 floor by Door	32.2	37.0	4.8					
133 Spectrophotometer	32.2	37.3	5.1					
126 Hood	32.2	45.3	13.1					
126 Bench	32.2	34.3	2.1					
238 Bench G.C.	32.2	39.3	7.1					
238 Sink ALT.	32.2	41.3	9.1					
246 Hood	32.2	38.3	6.1					
266 floor/Door	32.2	39.6	7.4					
266 fire Door/floor	32.2	44.6	12.5					
266 Hood	32.2	40.0	7.8					

\* No smearing efficiency value is factored into these results.

Instrument used: \_\_\_\_\_

LLD(95%) = \_\_\_\_\_ cpm

LLD(β w/o <sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

LLD(<sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

USE REVERSE SIDE FOR CALCULATIONS

REMOVABLE CONTAMINATION LEVELS (SMEARS)\*

Comprehensive swipe

Survey

Purpose of Survey

4/19/82

Date

82-02

DAN TULLO

Surveyor

Location	1	2	3	4	5	6	7	8
	BKG	Gross $\beta$ cpm w/ $^3H$	Net $\beta$ cpm w/ $^3H$	Gross $\beta$ cpm w/o $^3H$	Net $\beta$ cpm w/o $^3H$	Net $\beta$ $\mu Ci$ w/o $^3H$	Net $^3H$ cpm	Net $^3H$ $\mu Ci$
Rm 133 L.S.S.	4.1	4.7	0.6					
" Refrig 27	4.1	4.8	0.7					
" Refrig 33	4.1	5.1	1.0					
" Door	4.1	5.9	1.8					
Hall outside 133	4.1	6.7	2.6					
Rm 134 <sup>Floor</sup> Microosh	4.1	10.3	6.2	-				
" Door	4.1	5.9	1.8					
" Floor (Door)	8.0	9.1	1.1					
Rm 132 Hood sill	8.0	268.5	260.5	*				
" Oxidizer area	8.0	23.6	15.6	+				

\* No smearing efficiency value is factored into these results.

Instrument used: \_\_\_\_\_

LLD(95%) = \_\_\_\_\_ cpm

LLD( $\beta$  w/o  $^3H$ ) in  $\mu Ci$  = \_\_\_\_\_  $\mu Ci$

LLD( $^3H$ ) in  $\mu Ci$  = \_\_\_\_\_  $\mu Ci$

REMOVABLE CONTAMINATION LEVELS (SMEARS)\*

Swipes cont

12/11/81

Surveyor

Purpose of Survey

Date

	1	2	3	4	5	6	7	8
Location	BKG	Gross β cpm w/ <sup>3</sup> H	Net β cpm w/ <sup>3</sup> H	Gross β cpm w/o <sup>3</sup> H	Net β cpm w/o <sup>3</sup> H	Net β μCi w/o <sup>3</sup> H	Net <sup>3</sup> H cpm	Net <sup>3</sup> H μCi
134 - Floor	4.2	4.0	0.0					
Hall-outside 132	4.2	3.8	0.0					
133 - floor	4.2	3.4	0.0					
133 - Door	4.2	4.2	0.0					
236 - Corridor	4.2	5.0	0.8					
236 - Refrig	4.2	4.4	0.2					
228 - Hood	4.2	4.2	0.0					
228 - Bench	4.2	5.0	0.8					
228 - Refrig	4.2	4.8	0.6					

\* No smearing efficiency value is factored into these results.

Instrument used: \_\_\_\_\_

LLD(95%) = \_\_\_\_\_ cpm

LLD(β w/o <sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

LLD(<sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

USE REVERSE SIDE FOR CALCULATIONS

REMOVABLE CONTAMINATION LEVELS (SHEARS)\*

DANTULLO  
Surveyor

Comprehensive swipes

10/28/81

Purpose of Survey

Date

81-07

Location	1 BKG	2 Gross β cpm w/ <sup>3</sup> H	3 Net β cpm w/ <sup>3</sup> H	4 Gross β cpm w/o <sup>3</sup> H	5 Net β cpm w/o <sup>3</sup> H	6 Net β μCi w/o <sup>3</sup> H	7 Net <sup>3</sup> H cpm	8 Net <sup>3</sup> H μCi
Rm 130-floor	11.0	8.4	0.0					
Rm 128-Hood	11.0	8.4	0.0					
Rm 128-floor	11.0	7.4	0.0					
Rm 128-Middle Deck	11.0	10.8	0.0					
Hall outside 130	11.0	10.2	0.0					
Hall outside 132	11.0	12.4	1.4					
Rm 228 Hood Rt	6.0	4.8	0.0					
Rm 228 Refrig	6.0	7.2	1.2					
Rm 228 LSS	6.0	6.8	0.8					
Rm 228 Hood Lt	6.0	6.6	0.6					

\* No smearing efficiency value is factored into these results.

Instrument used: \_\_\_\_\_

LLD(95%) = \_\_\_\_\_ cpm

LLD(β w/o <sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

LLD(<sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

USE REVERSE SIDE FOR CALCULATIONS

REMOVABLE CONTAMINATION LEVELS (SHEARS)\*

DAN TULLO  
Surveyor

Comprehensive swipes of  
All RAD. AREAS  
Purpose of Survey

10/28/81  
Date

81-07

Location	1 BKG	2 Gross β cpm w/ <sup>3</sup> H	3 Net β cpm w/ <sup>3</sup> H	4 Gross β cpm w/o <sup>3</sup> H	5 Net β cpm w/o <sup>3</sup> H	6 Net β μCi w/o <sup>3</sup> H	7 Net <sup>3</sup> H cpm	8 Net <sup>3</sup> H μCi
Room 150 G.C.	11.0	7.2	0.0					
Rm. 133 LSS	11.0	10.6	0.0					
Rm 133 floor	11.0	8.8	0.0					
Rm 133 Door	11.0	10.8	0.0					
Rm 134 Bench	11.0	9.2	0.0					
Rm 134 floor	11.0	10.6	0.0					
Rm 132 - Hood	11.0	10.4	0.0					
Rm 132 - Oxidizer	11.0	11.8	0.8					
Rm 132 - floor	11.0	8.4	0.0					
Rm 130 - Hood	11.0	16.4	5.4					

\* No smearing efficiency value is factored into these results.

Instrument used: GFPC RM 190

LLD(95%) = \_\_\_\_\_ cpm

LLD(β w/o <sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

LLD(<sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

USE REVERSE SIDE FOR CALCULATIONS

REMOVABLE CONTAMINATION LEVELS (SMEARS)\*

Tullo

Surveyor

Swipe

Purpose of Survey

10/1/81

Date

	1	2	3	4	5	6	7	8
Location	BKG	Gross β cpm w/ <sup>3</sup> H	Net β cpm w/ <sup>3</sup> H	Gross β cpm w/o <sup>3</sup> H	Net β cpm w/o <sup>3</sup> H	Net β μCi w/o <sup>3</sup> H	Net <sup>3</sup> H cpm	Net <sup>3</sup> H μCi
Door 133	18.4	9.0						
Floor 133	18.4	14.2						
L.S.S. 133	18.4	12.2						
HALL Rm 133	18.4	9.2						
HALL Rm 132	18.4	13.4						
Hood 128	15.4	18.6						
Bench 128	15.4	16.0						
Refrig. Rm 128	15.4	15.6						
Hood (Rt) Rm 236	15.4	17.2						
SINK 236	12.2	12.0						

\* No smearing efficiency value is factored into these results.

Instrument used: \_\_\_\_\_

LLD(95%) = \_\_\_\_\_ cpm

LLD(β w/o <sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

LLD(<sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

USE REVERSE SIDE FOR CALCULATIONS

REMOVABLE CONTAMINATION LEVELS (SMEARS)\*

DAN TULLO  
Surveyor

Periodic, Comprehensive  
Swipes of Rad Areas.  
Purpose of Survey

8/14/81  
Date

81-05

	1	2	3	4	5	6	7	8
Location	BKG	Gross β cpm w/ <sup>3</sup> H	Net β cpm w/ <sup>3</sup> H	Gross β cpm w/o <sup>3</sup> H	Net β cpm w/o <sup>3</sup> H	Net β μCi w/o <sup>3</sup> H	Net <sup>3</sup> H cpm	Net <sup>3</sup> H μCi
Rm 133 - LSS	16.8	10.4	0.0					
Rm 133 - floor	16.8	13.6	0.0					
Rm 133 - Refrig.	16.8	16.0	0.0					
Rm 130 - Hood	16.8	9.6	0.0					
Rm 130 - Sink	16.8	13.8	0.0					
Rm 130 - floor	16.8	16.0	0.0					
Rm 130 Refrig	16.8	8.8	0.0					
Rm 132 Hood	16.8	14.2	0.0					
Rm 132 floor	16.8	10.8	0.0					
Rm 134 floor	16.8	12.8	0.0					

\* No smearing efficiency value is factored into these results.

Instrument used: NMC-6FPC

LLD(95%) = \_\_\_\_\_ cpm

LLD(β w/o <sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

LLD(<sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

USE REVERSE SIDE FOR CALCULATIONS



PROGRAM # 6  
 STATION A: LL-UL= 0- 12 LCR= 0 BKG= 0 % 2 SIGMA= 1.0  
 STATION B: LL-UL= 12- 156 LCR= 0 BKG= 0 % 2 SIGMA= 1.0  
 E= 100.00 QIP= SIE/REC SCR= B/A K= 1.000

Tullio Swipes  
 81-04

S#	TIME	CPMA/K DPM17K	%DEV	CPMB/K DPM27K	%DEV	QIP	FLAGS	SCR	MIN	
1	100.00	84 91	2.18	20 0	4.42	723.		.243 .000	101	BLANK
2	100.00	72 79	2.36	20 0	4.43	649.		.284 .000	203	1 Rm 134, Bench
3	100.00	75 82	2.30	21 0	4.36	649.		.280 .000	304	2 Rm 132, hood
4	100.00	55 62	2.69	20 0	4.44	535.	1	.367 .000	405	3 Rm 132, sink
5	100.00	72 79	2.36	20 0	4.48	639.		.278 .000	506	4 Rm 132, floor
6	100.00	70 77	2.39	20 0	4.53	619.		.279 .000	607	5 Rm 130, sink
7	100.00	64 70	2.50	20 0	4.46	583.	1	.316 .000	708	6 Rm 130, hood
8	100.00	63 70	2.51	21 0	4.39	578.		.328 .000	809	7 Rm 130, floor
9	100.00	52 59	2.77	19 0	4.57	528.	1	.366 .000	910	8 Rm 133, LSS
10	100.00	55 61	2.70	20 0	4.49	543.	1	.361 .000	1011	9 Rm 133, floor
11	100.00	61 67	2.57	20 0	4.51	572.	1	.325 .000	1112	10 Hall outside 133
12	100.00	77 84	2.28	21 0	4.41	657.	1	.269 .000	1213	11 Rm 236, Refrig.
13	100.00	68 75	2.42	26 0	3.95	606.	1	.376 .000	1314	12 Rm 228, sn. Ref
14	100.00	63 70	2.51	21 0	4.41	595.	1	.325 .000	1415	13 Rm 228, Hood
15	100.00	67 73	2.45	23 0	4.19	584.	1	.343 .000	1516	14 Rm 228, Lig. chass
16	100.00	61 67	2.56	25 0	3.96	564.		.417 .000	1617	15 Rm 250 hood
17	100.00	75 83	2.30	21 0	4.35	620.		.280 .000	1718	16 Rm 190 Bench
18	100.00	38 42	3.23	17 0	4.81	600.	1	.450 .000	1819	17 Rm 190 Floor

Don Tullio 7/6/81

# DAN TULLO

GRAM #: 6  
 MON A: LL-UL= 0- 12 LCR= 0 BKG= 0 % 2 SIGMA= 1.0  
 MON B: LL-UL= 12- 156 LCR= 0 BKG= 0 % 2 SIGMA= 1.0  
 100.00 QIP= SIE/REC SCR= B/A K= 1.000

81-03

S#	TIME	CPMA/K DPM1/K	%DEV	CPMB/K DPM2/K	%DEV	QIP	FLAGS	SCR	MIN	
1	100.00	100 108	2.00	21 0	4.37	779.		.209 .000	114	BKG
2	100.00	98 106	2.02	19 0	4.64	750.		.188 .000	215	Rm 133 LSS.
3	100.00	97 105	2.04	20 0	4.53	722.		.202 .000	316	Rm 133 Doorway
4	100.00	83 91	2.19	18 0	4.67	698.		.220 .000	417	134 Microcosm
5	100.00	84 91	2.18	18 0	4.66	727.		.220 .000	518	134 Balance NEA
6	100.00	84 91	2.18	18 0	4.72	716.		.212 .000	619	132 Hood
7	100.00	73 79	2.34	18 0	4.74	709.		.244 .000	720	132 Sink
8	100.00	85 92	2.16	19 0	4.64	724.		.218 .000	821	130 Balance AREA
9	100.00	93 101	2.07	21 0	4.41	724.		.220 .000	922	130 Sink
10	100.00	95 102	2.05	19 0	4.53	746.		.205 .000	1023	Hall 130
11	100.00	75 81	2.31	17 0	4.86	775.		.226 .000	1124	Hall 133
12	100.00	96 103	2.04	19 0	4.55	763.		.202 .000	1225	236 Hood (left)
13	100.00	75 81	2.31	17 0	4.83	748.		.230 .000	1326	236 Hood (right)
14	100.00	92 99	2.09	19 0	4.64	733.		.202 .000	1427	236 Sink (center)
15	100.00	95 102	2.06	19 0	4.64	788.		.197 .000	1528	LSS center room
16	100.00	72 78	2.35	17 0	4.87	757.		.234 .000	1629	Floor center room
17	100.00	43 46	3.06	14 0	5.31	752.		.333 .000	1730	228 Hood & Rodrig. 1p.
18	100.00	40 43	3.17	14 0	5.31	728.		.357 .000	1831	228 Hood left
19	100.00	72 77	2.36	17 0	4.82	721.		.240 .000	1932	228 Rodrig - sink (L)
20	100.00	85 92	2.17	19 0	4.54	726.		.229 .000	2033	228 Floor - sink
21	100.00	20 22	4.44	13 0	5.64	762.		.620 .000	2135	236 Hallway
22	100.00	65 70	2.49	17 0	4.81	768.		.268 .000	2236	228 Hallway
23	100.00	34 36	3.44	16 0	5.06	746.		.463 .000	2337	250 Hood
24	100.00	44 48	3.00	16 0	5.01	743.		.359 .000	2438	250 Rodrig.
25	100.00	62 66	2.55	16 0	4.95	766.		.264 .000	2539	246 Balance

Don Tullio

*[Signature]*  
4/14/81

# 6  
 LL-UL= 0-12 LCR= 0 BKG= 0 % 2 SIGMA= 1.0  
 LL-UL= 12-156 LCR= 0 BKG= 0 % 2 SIGMA= 1.0  
 QIP= SIE/REC SCR= B/A K= 1.000

81-02

TIME	CPMA/K DPM1/K	ZDEV	CPMB/K DPM2/K	ZDEV	QIP	FLAGS	SCR	MIN	
1 20:00	16	11.2	12	12.7	807		.787	21	BK6
	17		0			?	.000		
2 20:00	12	13.1	11	13.3	739		.974	42	24 Rn 236 floor (Door)
	12		0				.000		
3 20:00	13	12.6	14	11.8	729		1.139	63	27 Rn 236 refrrg
	14		0				.000		
4 20:00	12	13.1	12	13.0	727		1.026	84	2 Rn 236 Hood Area
	12		0				.000		
5 20:00	10	14.0	10	14.4	739		.941	105	21 Rn 236 sink Area
	11		0				.000		
6 20:00	13	12.2	12	12.9	732		.888	125	20 Hall outside 236
	14		0				.000		
7 20:00	11	13.2	12	12.8	758		1.061	146	19 LSS 228
	12		0				.000		
8 20:00	17	10.7	10	14.0	751		.586	167	18 Rn 228 Hood Area
	19		0				.000		
9 20:00	11	13.2	13	12.3	702		1.149	188	17 Rn 228 Door Area
	12		0				.000		
10 20:00	47	6.49	13	12.3	740		.278	209	16 floor LSS Rn (228)
	51		0				.000		
11 20:00	13	12.2	13	12.4	757		.974	230	15 Rn 236 Hood Area
	14		0				.000		
12 20:00	10	13.8	11	13.5	743		1.053	251	14 Rn 236 floor
	11		0				.000		
13 20:00	12	12.7	11	13.5	754		.882	272	13 LSS Rm 133
	13		0				.000		
14 20:00	12	12.6	11	13.6	752		.859	293	12 11 Rn 133 Downy
	13		0				.000		
15 20:00	17	10.9	11	13.6	752		.650	313	10 Hall outside 130
	18		0				.000		
16 20:00	17	10.9	17	10.7	720		1.039	334	9 Rn 130 sink Area
	18		0				.000		
17 20:00	52	6.21	17	10.9	732		.319	355	8 Rn 130 Hood Area
	56		0				.000		
18 20:00	38	7.28	16	11.2	690		.416	376	8 7 Rn 130 floor
	41		0				.000		
19 20:00	18	10.5	14	12.0	694		.757	397	7 6 Rn 132 hood
	20		0				.000		
20 20:00	12	12.9	12	12.8	719		1.008	418	6 5 Rn 132 floor by sink
	13		0				.000		
21 20:00	39	7.17	16	11.2	714		.405	439	5 4 Rn 132 floor by door
	42		0				.000		
22 20:00	30	8.20	15	11.4	721		.511	460	4 3 Hall outside 134
	32		0				.000		
23 20:00	17	10.9	14	12.0	690		.825	480	2 Rn 134 floor
	18		0				.000		
24 20:00	25	8.99	15	11.5	677		.608	501	1 Rn 134 floor
	27		0				.000		

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 134 Final Contamination Survey.**

Description and Historic Use:

Double lab (450 ft<sup>2</sup>). Carbon-14 tracers were used in the late 1970's – early 1980's and again in early 1990's. This room was decommissioned as an unrestricted area on April 9, 1996. No isotope use since 1995.

Surveys:

Total (fixed + removable) and removable contamination survey were conducted in MB 134 at the time of restricted use decommissioning. All points surveyed demonstrated no significant contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. A HVAC duct swipe was made in November 2004 which detected 0.23 Bq/100 cm<sup>2</sup> of carbon-14.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of MB 134 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 3 Survey Meter equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.

DYNAMAC CORPORATION  
200 SW 35th Street, Corvallis, OR 97333

---

MEMORANDUM

TO: Jay Gile  
FROM: Phil Monaco *PM*  
DATE: April 9, 1996

SUBJECT: Decommissioning of MB 134

The microcosm room (MB134) is free of all radioactive materials. Equipment used in the PCP and TCE carbon-14 projects has been decontaminated and in many cases removed from the room. The microcosm boxes were surveyed for removable and fixed contamination. The microcosm effluent vents were also surveyed for removable contamination as were the room walls and floor. Given the projected use of MB134 and its present "clean" state, I recommend that the room be declared as "decommissioned" and all radioactive materials signs removed.

The results of the surveys are summarized below.

Fixed Contamination Survey (96-05 and 96-09)

Ludlum #3 S/N 77146

Survey Description	CPM	A c t i v i t y (pCi/200 <sup>h</sup> )
Background	125	0
Microcosm A-2		
Outside chamber walls	<LLD*	0 net
Inside chamber walls	<LLD	0 net
Exposure Tank (Glass)	<LLD	0 net
Precision Water bath	<LLD	0 net
Microcosm C-2		
Outside chamber walls	<LLD	0 net
Inside chamber walls	<LLD	0 net
Rack	<LLD	0 net
Bricks	<LLD	0 net
Water float	<LLD	0 net
Bottom	<LLD	0 net
Floor	<LLD	0 net
Floor	<LLD	0 net
Table (grey)	<LLD	0 net
Room		
N. Wall	<LLD	0 NET
S. Wall	<LLD	0 NET
E. Wall	<LLD	0 NET
W. Wall	<LLD	0 NET
Sink counter top	<LLD	0 NET

Survey Description	CPM	Activity (pCi/20cm <sup>2</sup> )
Room (cont'd)		
Floor (sink area)	<LLD	0 NET
N. Floor	<LLD	0 NET
S. Floor	<LLD	0 NET
E. Floor	<LLD	0 NET
W. Floor	<LLD	0 NET

LLD= Lower Limits of Detection at the 95% confidence level as calculated by the formula:

$$125 + \left[ \left( \frac{\sqrt{125 \cdot 1}}{1} \right) 2.96 \right] = 158 \text{ cpm}$$

Removable Contamination (96-06, 96-07, and 96-08).

Packard LSC 2200 CA S/N 036755

Survey Description (per 100 cm <sup>2</sup> )	CPM (gross)	DPM (net)	Activity (pCi)
N Wall	23	<LLD**	0
S Wall	23	<LLD	0
E Wall	17	<LLD	0
W Wall	12	<LLD	0
Sink Counter	17	<LLD	0
Floor (sink area)	18	<LLD	0
N. Floor	20	<LLD	0
S Floor	18	<LLD	0
E Floor	25	<LLD	0
W Floor	17	<LLD	0
microcosom C-3 exit pipe	22	<LLD***	0
microcosom C-2 exit filter box	19	<LLD	0
microcosom C-1 exit filter box	16	<LLD	0
microcosom C-1 exit pipe	23	<LLD	0
microcosom B-1 exit filter box	28	12	5
microcosom B-2 exit filter box	22	<LLD	0
microcosom A-1 exit filter box	17	<LLD	0
microcosom A-2 exit filter box	29	14	6
MICRICOSOM A-2			
outside walls	18	<LLD****	0
inside walls	24	<LLD	0
glass chamber outside walls	19	<LLD	0
glass chamber inside walls	19	<LLD	0
glass chamber lid	22	<LLD	0
Precision water bath outside	30	<LLD	0
Precision water bath inside	16	<LLD	0

Survey Description (per 100 cm <sup>2</sup> )	CPM (gross)	DPM (net)	Activity (pCi)
MICROCOSOM C-2			
outside walls	22	<LLD	0
inside bottom	17	<LLD	0
inside walls	17	<LLD	0
water float	16	<LLD	0
rack inside	13	<LLD	0
table	18	<LLD	0
floor	17	<LLD	0
Room door	21	<LLD	0

\*\*LLD<sub>95</sub> = Lower Limits of Detection at the 95% confidence level as calculated by the formula:

$$19 + \left[ \left( \frac{\sqrt{19 \cdot 2'}}{2'} \right) 2.96 \right] = 28 \text{ cpm}$$

\*\*\*LLD<sub>95</sub> = Lower Limits of Detection at the 95% confidence level as calculated by the formula:

$$36 + \left[ \left( \frac{\sqrt{(17.3 \text{ cpm} \cdot 3')}}{2'} \right) 2.96 \right] = 46 \text{ cpm}$$

\*\*\*\*LLD<sub>95</sub> = Lower Limits of Detection at the 95% confidence level as calculated by the formula:

$$22 \text{ cpm} + \left[ \left( \frac{\sqrt{22 \text{ cpm} \cdot 2'}}{2'} \right) 2.96 \right] = 32 \text{ cpm}$$

U.S. EPA  
ENVIRONMENTAL RESEARCH LABORATORY - CORVALLIS

Log No. 96-09

RADIATION CONTAMINATION SURVEY

Date: 4-4-96 Type of Survey: FIXED CONTAMINATION

Isotope(s): P, X

Gross Background Counts: 125 ± CPM Total Count Time (min.): 1

Lower Limits of Detection:  $(\sqrt{125}) 2.96 = 33 + 125 = 158$  CPM

Instrument Used:  GFPC  LSC  GM  Ion Chamber  Scintillation Model: Ludlum #3 S/N: 77146

Background: 125 ± 33 CPM ± SD DPM ± SD Standard (Cs 137) source 11,000 cpm  $\sqrt{1000}$  3 Err

Swipe No.	Room No.	Swipe Description	Nuclide: _____ per 100 cm <sup>2</sup>			Nuclide: _____ per 100 cm <sup>2</sup>		
			CPM ± SD	Net DPM	Net Activity	CPM ± SD	Net DPM	Net Act.
<u>24</u>	<u>M3/B4</u>	<u>N WALL</u>	<u>0 net</u>	<u>LLD</u>	<u>0 net</u>			
		<u>S WALL</u>	↓	↓	↓			
		<u>E WALL</u>						
		<u>W WALL</u>						
		<u>Sink counter</u>						
		<u>Floor (sink area)</u>						
		<u>N Floor</u>						
		<u>S Floor</u>						
		<u>E Floor</u>						
		<u>W Floor</u>	↓	↓	↓			

Comments:  
Q. Mann 4-4-96  
Radiation Safety Date



U.S. EPA  
ENVIRONMENTAL RESEARCH LABORATORY - CORVALLIS

Log No. 96-08 1/2

RADIATION CONTAMINATION SURVEY

Date: 4-4-96 Type of Survey: REMOVABLE CONTAMINATION

Isotope(s): P

Gross Background Counts: 108  $\pm$  10 CPM Total Count Time (min.): 2

Lower Limits of Detection: 19 +  $\sqrt{(19 \times 2) / 2} = 2.94 = 28$  cpm

Instrument Used:  GEPC  LSC  GM  Ion Chamber  Scintillation Model: Packard 2200 CA SN: 036755

Background: 19 CPM  $\pm$  SD 21 DPM  $\pm$  SD Standard NEW  $^{14}C$  84,000 dpm  $\pm$  83,711 dpm ~~error~~

Swipe No.	Room No.	Swipe Description	Nuclide: <u>P</u> per 100 cm <sup>2</sup>			Nuclide: <u>P</u> per 100 cm <sup>2</sup>		
			CPM $\pm$ SD	Net DPM	Net Activity	CPM $\pm$ SD	Net DPM	Net Activity
2	M13134	N WALL	23	LUDGS	$\emptyset$ net			
		S WALL	23					
		E WALL	17					
		W WALL	12					
		Sink counter	17					
		Floor (sink area)	18					
		N Floor	20					
		S Floor	18					
		E Floor	25					
		W Floor	17					
	M13236	Hood SASH	22					
		" Sill	25					
		Floor by hood	23					
		Floor by sink	21					
		Sink	17					
		DOOR	19					
	M13270	hood sash/sill	22					
		Floor by hood	25					
		Counter opp hood	19					
		Floor (counter?)	18	$\checkmark$	$\checkmark$			

Comments:  
PA. Munn 4/8/96  
Radiation Safety Date

U.S. EPA  
ENVIRONMENTAL RESEARCH LABORATORY - CORVALLIS

Log No. 96-07

RADIATION CONTAMINATION SURVEY

MICROCOSOM Rm MB 134

Date: 4-2-96 Type of Survey: REMOVABLE CONTAMINATION

Isotope(s): <sup>14</sup>C

Gross Background Counts: 57 ± CPM Total Count Time (min.): 3

Lower Limits of Detection:  $[(\sqrt{57}/3)2.96] + 17 = 24$  CPM cpm

Instrument Used:  GFPC  LSC  GM  Ion Chamber  Scintillation Model: Packard 2200 CA SN: 036755

LLD<sub>95</sub> Background: 24 CPM±SD 19 DPM±SD Standard (NEN 84,000 <sup>14</sup>C = 84,740 dpm) 7-14-76

Swipe No.	Room No.	Swipe Description	Nuclide: <u>per 100 cm<sup>2</sup></u>			Nuclide: <u>per 100 cm<sup>2</sup></u>		
			CPM±SD	Net DPM	Net Activity	CPM±SD	Net DPM	Net Activity
2	134	Microcum C-3 <sup>EXIT</sup> PIPE	22	LLD <sub>95</sub>	Net			
3		" C-2 <sup>EXIT</sup> FILTER	19	↓	↓			
4		" C-1 <sup>EXIT</sup> FILTER	16	↓	↓			
5		" C-1 <sup>EXIT</sup> PIPE	23	↓	↓			
6		B-1 <sup>EXIT</sup> FILTER BOX	28	<del>12.4 ± 5.1</del>	5.4 pli			
7		B-2 <sup>EXIT</sup> FILTER BOX	22	LLD <sub>95</sub>	Net			
8		A-1 <sup>EXIT</sup> FILTER BOX	17	↓	↓			
9		A-2 <sup>EXIT</sup> FILTER BOX	29	414	6.3 pli			

Comments:

\_\_\_\_\_  
Radiation Safety                      Date

Protocol #128  
 Region A: LL-UL=0.0-15.0 Lcr=0.0 Bkg=0.00 Sigma=2.00  
 Region B: LL-UL=4.0-15.0 Lcr=0.0 Bkg=0.00 7.2 Sigma=5.00  
 Region C: LL-UL=0.0-10.0 Lcr=0.0 Bkg=0.00 7.2 Sigma=0.00  
 Time = 3.00 QIP = tSIE ES Terminator = Count  
 14C Quench Curve  
 Conventional DPM  
 Nuclide 1 = 113700  
 Luminescence Correction On

S#	TIME	CPMA	DPM1	A:25%	CPMB	B:25%	SIS	tSIE	FLAG	LUM
1	3.00	36.00	44.70	30.54	23.00	24.07	72.400	137.		43 BLANK
2	3.00	34.33	42.76	25.39	27.33	22.08	81.380	136.		28 D-2
3	3.00	39.33	49.17	21.57	28.33	21.69	97.970	134.		14 D-3
4	3.00	29.33	36.68	26.69	22.67	24.25	90.370	134.		23 D-4
5	3.00	15.33	15.71	34.23	13.00	32.02	100.79	965.		19 BKBOUND
6	0.13	82738.5	84740.3	1.92	80369.2	1.95	160.38	975.		0 14C NEW
(6 missing vials)										
13	3.00	17.33	19.16	32.17	11.67	33.80	59.690	265.		9 BLANK
14	3.00	22.00	24.67	27.77	17.33	27.73	78.520	238.		11 2
15	3.00	19.00	21.22	31.57	14.67	30.15	105.39	246.		10 3
16	3.00	15.67	17.50	34.30	14.33	30.49	101.28	245.		18 4
17	3.00	23.33	26.23	27.10	20.33	25.60	86.210	234.		13 5
18	3.00	27.67	31.12	26.28	22.67	24.25	69.200	233.		16 6
19	3.00	21.67	24.31	28.36	17.33	27.73	81.870	238.		18 7
20	3.00	16.67	18.58	37.09	15.67	29.17	74.370	249.		25 8
21	3.00	28.67	32.56	23.71	23.67	23.73	78.190	218.		29 9
(9 missing vials)										
31	3.00	128.00	135.96	10.39	120.00	10.54	97.270	536.		1
32	3.00	1167.33	1233.22	3.38	1118.00	3.45	108.51	587.		0
33	1.01	9937.62	10509.2	1.99	9519.80	2.03	107.65	578.		0
34	0.12	90691.7	95825.6	1.91	87191.7	1.95	108.47	586.		0

Distilled CH<sub>3</sub>CN WASTE  
 Microsoms

A CH<sub>3</sub>CN Distilled WASTE

LLD<sub>95</sub>  $\left[ \left( \frac{\sqrt{136.5}}{3} \right) 2.96 \right] + 36 = 46$  cpm

WASTE	Count cpm	OPM	Activity B.Sul
D-2	34 cpm	< LLD <sub>95</sub>	0
D-3	39	< LLD <sub>95</sub>	0
D-4	29	< LLD <sub>95</sub>	0

B Microsoms Room MB 134  
 LLD<sub>95</sub>

$\left[ \left( \frac{\sqrt{173.3}}{3} \right) 2.96 \right] + 17 = 24$  cpm

U.S. EPA  
ENVIRONMENTAL RESEARCH LABORATORY - CORVALLIS

Log No. 96-06

RADIATION CONTAMINATION SURVEY

Date: 4/1/96 Type of Survey: Removable Contamination

Isotope(s): P (14C)

Gross Background Counts: 44 ± CPM Total Count Time (min.): 2'

Lower Limits of Detection:  $(\sqrt{44}/2) 2.96 = 10 \text{ CPM}$  LLD =  $2.2 \times 10 = 32 \text{ CPM}$  cpm

Instrument Used:  GFPC  LSC  GM  Ion Chamber  Scintillation Model: PACKARD 2200CA S/N: 026755

Background: CPM±SD DPH±SD Standard NEW 14C 84,000 dpm = 83,648 dpm Error

Swipe No.	Room No.	Swipe Description	Nuclide: <u>per 100 cm<sup>2</sup></u>			Nuclide: <u>per 100 cm<sup>2</sup></u>		
			CPM±SD	Net DPM	Net Activity	CPM±SD	Net DPM	Net Activity
		<u>MICROCOSM A2</u>	<u>     </u>	<u>     </u>	<u>     </u>			
<u>2</u>	<u>134</u>	<u>outside</u>	<u>18</u>	<u>LLD<sub>95</sub></u>	<u>0 net</u>			
<u>3</u>		<u>outside CHAMBER</u>	<u>19</u>	<u>Y</u>	<u>Y</u>			
<u>4</u>		<u>inside CHAMBER</u>	<u>19</u>					
<u>5</u>		<u>inside MICROCOSM</u>	<u>24</u>					
<u>6</u>		<u>TANK lid</u>	<u>22</u>					
<u>7</u>		<u>PRECISION WATER BATH outside</u>	<u>30</u>					
<u>8</u>		<u>PRECISION WATER BATH inside</u>	<u>16</u>					
		<u>MICROCOSM C2</u>	<u>     </u>	<u>     </u>	<u>     </u>			
<u>9</u>		<u>outside</u>	<u>22</u>		<u>0 net</u>			
<u>10</u>		<u>inside bottom</u>	<u>17</u>		<u>Y</u>			
<u>11</u>		<u>inside</u>	<u>17</u>					
<u>12</u>		<u>Water float</u>	<u>16</u>					
<u>13</u>		<u>Rack</u>	<u>13</u>					
<u>14</u>		<u>Table</u>	<u>18</u>					
<u>15</u>		<u>FLOOR</u>	<u>17</u>		<u>Y</u>			
<u>16</u>		<u>FLOOR</u>						
<u>17</u>		<u>DOOR</u>	<u>21</u>	<u>Y</u>	<u>0 net</u>			

Comments:

Da Mann 4/2/96  
Radiation Safety Date

U.S. EPA  
 ENVIRONMENTAL RESEARCH LABORATORY - CORVALLIS  
 RADIATION CONTAMINATION SURVEY

Log No. \_\_\_\_\_

Date: 4-1-96 Type of Survey: FIXED CONTAMINATION

Isotope(s): P

Gross Background Counts: 125 ± CPM Total Count Time (min.): 1

Lower Limits of Detection:  $(\sqrt{125}) 2.96 = 33 + 125 = 158$  CPM

Instrument Used:  GFPC  LSC  GM  
 Ion Chamber  Scintillation Model: Kudum #3 S/N: 77146

Background: 125 CPM±SD DPM±SD Standard (Cs<sup>137</sup>, 11,000 CPM): \_\_\_\_\_ % Error

Swipe No.	Room No.	Swipe Description	Nuclide: _____ per 100 cm <sup>2</sup>			Nuclide: _____ per 100 cm <sup>2</sup>		
			CPM±SD	Net DPM	Net Activity	CPM±SD	Net DPM	Net Activity
<del>////</del>	<del>134</del>	<del>Microcosm Az</del>	<del>---</del>	<del>---</del>	<del>---</del>			
		outside	0 net	↓				
		inside	0 net	↓				
		Exposure Tank	0 net	↓				
		WATER FROSTING BATH	0 net	↓				
<del>////</del>	<del>134</del>	<del>Microcosm C2</del>	<del>---</del>	<del>---</del>	<del>---</del>			
		outside	0 net	↓				
		inside	↓	↓				
		Rack	↓	↓				
		Bricks	↓	↓				
		Water float	↓	↓				
		Bottom	↓	↓				
		FLOOR	↓	↓				
		FLOOR	↓	↓				
		Table (grey)	↓	↓				

Comments: Room 134 clean up

Rad. Man 4/1/96

Radiation Safety Date

U.S. EPA  
ENVIRONMENTAL RESEARCH LABORATORY - CORVALLIS

Log No. 96-1  
1/3

RADIATION CONTAMINATION SURVEY

Date: 1/3/96 Type of Survey: REMOVABLE CONTAMINATION

Isotope(s): P

Gross Background Counts: 25 ± CPM Total Count Time (min.): 2'

Lower Limits of Detection:  $(\sqrt{30/2}) 296 = 11$  CPM

Instrument Used:  SFPC  LSC  Ion Chamber Model: Packard 2200 CA S/N: 036753  
 GM  Scintillation

Background: CPM±SD OPM±SD Standard (~~PRE~~ NEW) <sup>14</sup>C 84,000 dpm = 1: 85,035 dpm Error

Swipe No.	Room No.	Swipe Description	Nuclide: <u>P</u> per 100 cm <sup>2</sup>			Nuclide: _____ per 100 cm <sup>2</sup>		
			85 CPM±SD net	Net DPM	Net Activity	CPM±SD	Net DPM	Net Activity
2	134	door Microcosm A-2	∅	∅net	∅net			
		floor area	∅	∅	∅			
		door Microcosm C-2	∅	∅	∅			
5		floor area	2	LLD <sub>net</sub>	∅net			
		room door	∅	∅net	∅net			
	236	S HOOD SASH/SILL	∅	∅	∅			
		S. HOOD FLOOR area	∅	∅	∅			
		SINK	∅	∅	∅			
10		N HOOD SASH/SILL	∅	∅	∅			
		N. HOOD FLOOR AREA	75	84	38 di	* note :		
		desk	∅	∅	∅net			
		door	∅	∅	∅			
	256	Hood SASH/SILL	∅	∅	∅			
15		FLOOR	∅	∅	∅			
		oxidizer	∅	∅	∅			
		Counter by phone	∅	∅	∅			
		LSC	∅	∅	∅			
		desk	∅	∅	∅			
20		door	∅	∅	∅			
	266	Hood SASH/SILL	∅	∅	∅			

Comments:

\* Note. Decontaminated 1/5/96 & reswiped  
see following.

P. Mon 1/5/95  
Radiation Safety Date

P. Mon

U.S. EPA  
ENVIRONMENTAL RESEARCH LABORATORY - CORVALLIS

Log No. 93-16 1/2

RADIATION CONTAMINATION SURVEY

Date: 11-5-93 Type of Survey: REMOVABLE CONTAMINATION

Isotope(s): β

Gross Background Counts: 292 ± CPM Total Count Time (min.): 10'

Lower Limits of Detection:  $\sqrt{292/10} \times 2.96 = 5.1$  = cpm

Instrument Used:  GFPC  LSC  GM  Ion Chamber  Scintillation Model: PIC 2200CA S/N: \_\_\_\_\_  
SN 70791/113688 dpm = 62

Background: 29.2 CPM±SD DPM±SD Standard (<sup>40</sup>K/<sup>137</sup>Cs) 84 dpm 83270 cpm/1000 cm² = 99 EFF

Swipe No.	Room No.	Swipe Description	Nuclide: <u>Net</u>			Nuclide: _____		
			CPM±SD	Net DPM	Net Activity <u>pCi</u>	CPM±SD	Net DPM	Net Activity
2	256	hood	0	0	0			
		oxidizer	0	↓	↓			
		Phone	0	↓	↓			
5		LSC/computer	0	↓	↓			
		door	8	9	4			
	266	hood	1	2LD95	8			
		Floor	0	0	↓			
		Phone	7	8	4			
10		door	6	6	3			
		270 hood	16	17	8			
		floor	15	16	7			
		counter	5	2LD95	2			
		Phone	13	14	6			
		15 door	2	2LD95	2			
	236	S. hood	0	0	0			
		floor by hood	5	2LD95	0			
		Phone	9	9	4			
		floor by N. hood	11	12	5			
20		door	0	0	0			
130		floor by hood	8	9	4			

Notes: All swipes less than 100 dpm/100 cm². No further action necessary or warranted.

Richard Moore 11/8/93  
Radiation Safety Date

U.S. EPA  
ENVIRONMENTAL RESEARCH LABORATORY - CORVALLIS

Log No. \_\_\_\_\_

2/2

RADIATION CONTAMINATION SURVEY

Type of Survey: \_\_\_\_\_

Isotope(s): \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_ ± \_\_\_\_\_ CPM Total Count Time (min.): \_\_\_\_\_

Lower Limits of Detection: \_\_\_\_\_ = \_\_\_\_\_ cpm

Instrument Used:  GFPC  LSC  GM  Ion Chamber  Scintillation Model: \_\_\_\_\_ S/N: \_\_\_\_\_

Background: \_\_\_\_\_ CPM±SD \_\_\_\_\_ DPM±SD Standard ( \_\_\_\_\_ ): \_\_\_\_\_ % Error

Swipe No.	Room No.	Swipe Description	Nuclide: _____ per 100 cm <sup>2</sup>			Nuclide: _____ per 100 cm <sup>2</sup>		
			CPM±SD	Net DPM	Net Activity	CPM±SD	Net DPM	Net Activity
22	130	Phone	0	0	0			
		door	3	<LLD <sub>95</sub>				
	134	Cosom	0	0				
25		Floor	0	0				
		Table	0	0				
		door	2	<LLD <sub>95</sub>				
	190	door	8	9	4			
		floor	0	<LLD <sub>95</sub>	0			
30		Counters 5	3	<LLD <sub>95</sub>	0			
31		Phone	10	11	5			
		<sup>3</sup> H PIC 113,196 DPM	70791 CPM / 113,196 DPM					
		<sup>14</sup> C AEN 84100 DPM	83270 CPM / 84100 DPM					

Notes: \_\_\_\_\_

Radiation Safety \_\_\_\_\_ Date \_\_\_\_\_

(9/20)



**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 138 Final Contamination Survey.**

Description and Historic Use:

Double lab (450 ft<sup>2</sup>). Carbon-14 and potentially Hydrogen-3 tracers. No isotope use since 1990.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in MB 138 in November 2004. All points surveyed (12 total and 12 removable) demonstrated no significant contamination. Six points indicated very low levels of removable contamination from tritium (0.22 – 0.36 Bq/100 cm<sup>2</sup>). All other sampling points were at background. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. A HVAC duct swipe was also made which detected 1.48 and 0.55 Bq/100 cm<sup>2</sup> of hydrogen-3 and carbon-14 respectively.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of MB 138 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.

NHEERL-WED  
RADIATION AREA SURVEY

LOG NO. 04-23

DATE 11-11-04

LOCATION MB

ROOM 138

INSTRUMENT Ludlum 2000 Scaler PANcake Probe AA-9  
SERIAL NO. 83810 / PR 070834

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	26	LLD <sub>95</sub>	NA
2	42	↓	↓
3	24	↓	↓
4	38	↓	↓
5	28	↓	↓
6	35	↓	↓
7	42	↓	↓
8	24	↓	↓
9	40	↓	↓
10	44	↓	↓
11	30	↓	↓
12	30	↓	↓

LLD<sub>95</sub> = {  $\left(\frac{\sqrt{38}}{0.5}\right) \times 2.96$  } / 6 = 113 CPM

BACKGROUND STANDARD (<sup>14</sup>C 0.16<sub>4</sub> Ci)  $\frac{76 \text{ CPM}}{19540 \text{ CPM}}$  2.8% eff.  
Time 0.5'

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>

LLD<sub>95</sub> = { (-----) × 2.96 } / + = CPM

BACKGROUND STANDARD (-----) -----

COMMENTS:

D. Monna  
RADIATION SPCL.

11-16-04  
DATE

NHEERL-WED  
RADIATION AREA SURVEY

LOG NO. 04-23

DATE 11-11-04

LOCATION 110

ROOM 138

INSTRUMENT  
SERIAL NO.

Packard 2200CA LSC  
~~037675~~ 036755

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	5	<LLD <sub>95</sub>	ND
2	6	<LLD <sub>95</sub>	ND
3	7	15	0.25
4	5	<LLD <sub>95</sub>	ND
5	8	17	0.28
6	4	<LLD <sub>95</sub>	ND
7	7	14	0.23
8	7	13	0.22
9	10	22	0.36
10	6	<LLD <sub>95</sub>	ND
11	4	<LLD <sub>95</sub>	ND
12	9	22	0.36

3H

$$\text{LLD}_{95} = \left\{ \left( \frac{\sqrt{12}}{3} \right) \times 2.96 \right\} \frac{1}{4} = 7 \text{ CPM}$$

BACKGROUND STANDARD (3H) 64,175 DPM ) 56,056 DPM  
87% eff.

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
	18	<LLD <sub>95</sub>	ND
	14		
	13		
	13		
	14		
	14		
	17		
	13		
	19		
	11		
	12		
	9		

14C

$$\text{LLD}_{95} = \left\{ \left( \frac{\sqrt{66}}{3} \right) \times 2.96 \right\} \frac{22}{22} = 30 \text{ CPM}$$

BACKGROUND STANDARD (14C) 84,000 DPM ) 85,603 DPM  
102% eff.

COMMENTS:

D. Monan  
RADIATION SPCL.


11-18-04  
DATE

NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION MB

ROOM 138



U.S. EPA  
ENVIRONMENTAL RESEARCH LABORATORY - CORVALLIS

Log No. 90-40 1/3

RADIATION CONTAMINATION SURVEY

Date: 12-3-90 Type of Survey: Non-Removable Contamination

Isotope(s): P & X

Gross Background Counts: ± CPM Total Count Time (min.):           

Lower Limits of Detection:  $\sqrt{75 \times 4.66} = 40.4$  (40.4) cpm

Instrument Used:  GFPC  LSC  GM  Ion Chamber  Scintillation Model: Ludlum #3 SIN: 77222

Background: 75 CPM±SD            DPM±SD Standard (<sup>137</sup>CS  $\approx$  1mbi / 11K CPM ): 11,025 cpm % Error

Swipe No.	Room No.	Swipe Description	Nuclide: <u>          </u> per 100 cm <sup>2</sup>			Nuclide: <u>          </u> per 100 cm <sup>2</sup>		
			Net CPM±SD	Net DPM	Net Activity	CPM±SD	Net DPM	Net Activity
	<sup>MB</sup> 138	Hoods	Ø					
		Sink	Ø					
		Floor	Ø					
		Desk	Ø					
		Door	Ø					
	132	Hoods	Ø					
		Sink	Ø					
		Floor	Ø					
		Bench	Ø					
		door	Ø					
	258	Hood <sup>Et. wall</sup>	450 <sup>±</sup>					
		Floor	Ø					
		Sinks	Ø					
		Door	Ø					
	256	Hood	Ø					
		Floor	Ø					
		Phone	Ø					
		door	Ø					

\* will label this non-removable contamination

Shane Murr 12/3/90  
Radiation Safety Date

U.S. EPA  
 ENVIRONMENTAL RESEARCH LABORATORY - CORVALLIS

Log No. 2/3

RADIATION CONTAMINATION SURVEY

Date: \_\_\_\_\_ Type of Survey: \_\_\_\_\_

Isotope(s): \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  $\pm$  CPM Total Count Time (min.): \_\_\_\_\_

Lower Limits of Detection: \_\_\_\_\_ = \_\_\_\_\_ cpm

Instrument Used:  GFPC  LSC  GM  Ion Chamber  Scintillation Model: \_\_\_\_\_ S/N: \_\_\_\_\_

Background: \_\_\_\_\_ CPM $\pm$ SD \_\_\_\_\_ DPM $\pm$ SD Standard ( \_\_\_\_\_ ): \_\_\_\_\_ % Error

Swipe No.	Room No.	Swipe Description	Nuclide: _____ per 100 cm <sup>2</sup>			Nuclide: _____ per 100 cm <sup>2</sup>		
			net CPM $\pm$ SD	Net DPM	Net Activity	CPM $\pm$ SD	Net DPM	Net Activity
236		S. Hood	$\emptyset$					
		Floor	$\emptyset$					
		Sink	$\emptyset$					
		door	$\emptyset$					
2326		N. Hood	$\emptyset$					
		Sink	$\emptyset$					
		Phone	$\emptyset$					
		Floor	$\emptyset$					
228		Counter	$\emptyset$					
		S. Hood	$\emptyset$					
		Floor	$\emptyset$					
236P		door	$\emptyset$					
		Sink	$\emptyset$					
		N. Hood	$\emptyset$					
		Photo lab - Sink	$\emptyset$					
214		Floor	$\emptyset$					
		Counter	$\emptyset$					
		Sink	$\emptyset$					

U.S EPA  
ENVIRONMENTAL RESEARCH LABORATORY -CORVALLIS

Log No. \_\_\_\_\_

3/3

RADIATION CONTAMINATION SURVEY

Type of Survey: \_\_\_\_\_

Isotope(s): \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_ ± \_\_\_\_\_ CPM Total Count Time (min.): \_\_\_\_\_

Upper Limits of Detection: \_\_\_\_\_ = \_\_\_\_\_ cpm

Instrument Used:  GFPC  LSC  GM  Ion Chamber  Scintillation Model: \_\_\_\_\_ S/N: \_\_\_\_\_

Background: \_\_\_\_\_ CPM±SD \_\_\_\_\_ DPM±SD Standard ( \_\_\_\_\_ ): \_\_\_\_\_ % Error

Room No.	Swipe Description	Nuclide: _____ per 100 cm <sup>2</sup>			Nuclide: _____ per 100 cm <sup>2</sup>		
		Net CPM±SD	Net DPM	Net Activity	Net CPM±SD	Net DPM	Net Activity
294	A. Hood	Ø					
C-1	door	Ø					
	Floor	Ø					
NERF	Rad Lab Hood	Ø					
	Floor	Ø					
	Bench	Ø					
	door	Ø					

Radiation Safety \_\_\_\_\_ Date \_\_\_\_\_

γ

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: <sup>14</sup>C, <sup>3</sup>H

Date: \_\_\_\_\_

Method of Detection: \_\_\_\_\_

3H

Radiation Safety Technician

<sup>14</sup>C

Swipe #	Location		Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi
11	138	BLKGRD	0	N/A	N/A
12		Floor <sup>Hood</sup>	0	N/A	
13		Floor <sup>Hood</sup>	0	N/A	
14		Floor <sup>N</sup>	0	N/A	
15		Hood sash	1	< LLD <sub>3H</sub>	
16		Hood sill	1	< LLD	
17		Counter <sup>E</sup>	0	N/A	
18		Phone	0	N/A	
19		Door	0	N/A	
20	258	Hood sash	2	< LLD	
21		sill	0	N/A	
22		Floor	0	N/A	
23		Floor	0	N/A	
24		Door	0	N/A	
25		LSC	1	<	✓

Nuclide:		
NET CPM	NET DPM	μCi
0	N/A	N/A
2	< LLD	
2	< LLD	
1	< LLD	
0	N/A	
2	< LLD	
1	< LLD	
0	N/A	
1	< LLD	
0	N/A	X
5	6	2.7
6	9	4
0	N/A	N/A
1	< LLD	N/A
2	< LLD	N/A

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
 Total Background Count time: \_\_\_\_\_

\_\_\_\_\_  
 \_\_\_\_\_

$(95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%)= \_\_\_\_\_

REMARKS:



138 90-26  
1/2

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed:  $^{35}\text{S}$   $^{14}\text{C}$

Date: 6-4-70

Method of Detection: LSC-460

Paul A. Moran  
Radiation Safety Technician

Swipe #	Location		Nuclide:		pCi μCi	-Nuclide:		
	RM #	Area	NET CPM	NET DPM		NET CPM	NET DPM	μCi
1		BKGRD						
2	170	Door	0	N/A	N/A			
3	138	Door	4	<LLD <sub>95</sub>				
4	138	Floor-Door	5	<LLD <sub>95</sub>				
	138	Floor-Hood	0	N/A				
	138	Floor-sink	4	<LLD <sub>95</sub>				
	138	hood sash	0	N/A				
	138	hood sill	1	<LLD <sub>95</sub>				
	138	phone	2	<LLD <sub>95</sub>	✓			
	294	Door	10	10	5			
		Floor (door)	30	33	15			
		Desk	11	12	6			
		Balance	28	30	14			
		Floor (balance)	21	23	11			
		phone	18	19	9			

Calculation of Lower Limits of Detection (LLD)

Nuclide: AP Nuclide: \_\_\_\_\_  
AD \_\_\_\_\_  
\_\_\_\_\_

Gross Background Counts:  
Total Background Count time:

$$(95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$$

LLD (95%) =

6

REMARKS:

89-45  
1/2

138 490

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: 3H <sup>14</sup>C

Date: 12-7-89

Method of Detection: LSC 460

*[Signature]*  
Radiation Safety Technician

Swipe #	Location RM # Area	Nuclide: 3H		
		NET CPM	NET DPM	µCi
1	Bkbrd	(12)		
138	Floor MAT	2	<LLD <sub>95</sub>	
	Floor MAT	1		
	Floor MAT	4		
	Floor	0		
	Floor MAT	2		
	Floor (door)	0		
	sink	4		
	phone	0	✓	
	door	5	15	
190	door	0	n/A	
	phone	10	(27)	
	Counter ↓	0	n/A	
	Counter w	0	n/A	
	Counter	0	n/A	

Nuclide: <sup>14</sup> C		
NET CPM	NET DPM	µCi
(13)		
12	15	
7	9	
4	<LLD <sub>95</sub>	
4	<LLD <sub>95</sub>	
10	12	
3	<LLD <sub>95</sub>	
12	14	
0	n/A	
0	n/A	
0	n/A	
2	<LLD <sub>95</sub>	
0	n/A	
3	<LLD <sub>95</sub>	
0	n/A	

Calculation of Lower Limits of Detection (LLD)

Gross Background Counts:  
Total Background Count time:

Nuclide: 3H      Nuclide: <sup>14</sup>C  
120      130

$$L(95\%) = \frac{\sqrt{\text{Gross Background Counts}}}{\text{Count Time}} \times 4.66$$

L(95%) =

5      5

REMARKS:

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 149 Final Contamination Survey.**

Description and Historic Use:

Single lab converted to single office (225 ft<sup>2</sup>). Nickel-63 and hydrogen-3:scandium sealed sources. No tracer isotopes use since prior to 1986. There is no record of leakage of any sealed sources used in this area.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in MB 149 in November 2004. This room has been an unrestricted area since prior to 1986. Radioactive materials were not used in this area after 1985.

All points surveyed (4 total and 4 removable) demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities.

We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.



### NHEERL-WED RADIATION AREA SURVEY

LOG NO. OA-23

DATE 11-11-04

LOCATION MB

ROOM 149

INSTRUMENT Packard LSC 2200CA  
 SERIAL NO. 36755

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	2	$<LLD_{95}$	<u>ND</u>
2	3	↓	↓
3	4	↓	↓
4	5	↓	↓

$$LLD_{95} = \left\{ \left( \frac{\sqrt{2}}{3} \right) \times 2.96 \right\} \frac{1}{4} = \textcircled{7} \text{ CPM}$$

4 CPM

BACKGROUND STANDARD (H 64,179 DPM) 56,056 DPM  
87% eff.

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
	14	$<LLD_{95}$	<u>ND</u>
	14	↓	↓
	14	↓	↓
	14	↓	↓

$$LLD_{95} = \left\{ \left( \frac{\sqrt{66}}{3} \right) \times 2.96 \right\} + 22 = \textcircled{30} \text{ CPM}$$

22 CPM

BACKGROUND STANDARD (<sup>14</sup>C 84,000 DPM) 85,608 DPM  
102% eff.

COMMENTS:


D. Monav  
RADIATION SPCL.

11-18-04  
DATE

NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION MB ROOM 149



Wall survey

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 150 Final Contamination Survey.**

Description and Historic Use:

Single lab converted to single office (225 ft<sup>2</sup>). Nickel-63 and hydrogen-3:Scandium sealed sources. No tracer isotopes use since prior to 1986. There is no record of leakage of any sealed sources used in this area.

Surveys:

A total (fixed + removable) and removable contamination surveys were conducted in MB 150 in November 2004. This room has been an unrestricted area since prior to 1986; radioactive materials were not used in this area after 1985.

The four points surveyed (4 total and 4 removable) demonstrated no significant contamination. One swipe indicated very low levels of removable contamination from tritium (0.35 Bq/100 cm<sup>2</sup>). This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities.

We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. A record of the most recent historic surveys (i.e. prior to the final decommissioning survey) of MB 150 is included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.





NHEERL-WED  
RADIATION AREA SURVEY

LOG NO. 04-23

DATE 11-11-04

LOCATION 11B

ROOM 150

INSTRUMENT Packard LSC 2200CA  
SERIAL NO. 036755

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
<u>1</u>	<u>4</u>	<u>LLD<sub>95</sub></u>	<u>ND</u>
<u>2</u>	<u>4</u>	↓	↓
<u>3</u>	<u>5</u>	↓	↓
<u>4</u>	<u>9</u>	<u>21</u>	<u>0.35</u>

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
	<u>14</u>	<u>LLD<sub>95</sub></u>	<u>ND</u>
	<u>15</u>	↓	↓
	<u>15</u>	↓	↓
	<u>13</u>	↓	↓

LLD<sub>95</sub> =  $\left\{ \left( \frac{\sqrt{12}}{3} \right) \times 2.96 \right\} + = \textcircled{7} \text{ CPM}$   
 4 CPM  
 BACKGROUND STANDARD (B<sub>H</sub> 64,179 dpm) 56,056 DPM  
 87% eff.

LLD<sub>95</sub> =  $\left\{ \left( \frac{\sqrt{66}}{3} \right) \times 2.96 \right\} + = \textcircled{30} \text{ CPM}$   
 22 CPM  
 BACKGROUND STANDARD (14C 84,000 dpm) 83,603 DPM  
 102% eff.

COMMENTS:

D. Monaco  
RADIATION SPCL.


11-18-04  
DATE

NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 0A-23

LOCATION MB

ROOM 150



*Wall Survey*

150

REMOVABLE CONTAMINATION LEVELS (SMEARS)\*

DAN TULLO  
Surveyor

Comprehensive swipes of  
ALL RAD. AREAS  
Purpose of Survey

10/28/81  
Date

81-07

	1	2	3	4	5	6	7	8
Location	BKG	Gross β cpm w/ <sup>3</sup> H	Net β cpm w/ <sup>3</sup> H	Gross β cpm w/o <sup>3</sup> H	Net β cpm w/o <sup>3</sup> H	Net β μCi w/o <sup>3</sup> H	Net <sup>3</sup> H cpm	Net <sup>3</sup> H μCi
Room 150 G.C.	11.0	7.2	0.0					
Rm. 133 LSS	11.0	10.6	0.0					
Rm 133 floor	11.0	8.8	0.0					
Rm 133 Door	11.0	10.8	0.0					
Rm 134 Bench	11.0	9.2	0.0					
Rm 134 floor	11.0	10.6	0.0					
Rm 132 - Hood	11.0	10.4	0.0					
Rm 132 - Oxidim	11.0	11.8	0.8					
Rm 132 - floor	11.0	8.4	0.0					
Rm 130 - Hood	11.0	16.4	5.4					

\* No smearing efficiency value is factored into these results.

Instrument used: GFPC RM190

LLD (95%) = \_\_\_\_\_ cpm

LLD (β w/o <sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

LLD (<sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

USE REVERSE SIDE FOR CALCULATIONS

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**

**Subject: Room Survey: Main Building 155 Final Contamination Survey.**

Description and Historic Use:

Single room (225 ft<sup>2</sup>). No known use of radioisotopes in this room.

Surveys:

A total (fixed + removable) contamination survey was conducted in MB 155 in November 2004.

All points surveyed (6 total) demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities.

We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in the facility.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector.

NHEERL-WED  
 RADIATION AREA SURVEY

LOG NO. 0A-23

DATE 11-16-04

LOCATION 1B

ROOM 155

INSTRUMENT Ludlum 2000 Scaler Panache Probe #9  
 SERIAL NO. 83810 / PR 070834

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	34	LLD <sub>95</sub>	ND
2	64	↓	↓
3	38	↓	↓
4	48	↓	↓
5	44	↓	↓
6	46	↓	↓

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>

$$LLD_{95} = \left\{ \left( \frac{\sqrt{22}}{0.5} \right) \times 2.96 \right\} + = \textcircled{72} \text{ CPM}$$

BACKGROUND STANDARD (<sup>14</sup>C 0.168 μCi) 44 CPM / 16,790 CPM  
 Time 0.5 min. 3.2%

$$LLD_{95} = \left\{ \left( \frac{\sqrt{\quad}}{\quad} \right) \times 2.96 \right\} + = \text{CPM}$$

BACKGROUND STANDARD ( )

COMMENTS:

D. Monaco  
 RADIATION SPCL.


11-16-04  
 DATE

NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION MB

ROOM 155



ALL WALL SURVEYS

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 159 Final Contamination Survey.**

Description and Historic Use:

Double lab (450 ft<sup>2</sup>) converted to a lunch room prior to 1986. Potentially hydrogen-3 and carbon-14 tracers. No isotope use since prior to 1980.

Surveys:

A total (fixed + removable) contamination survey was conducted in MB 159 in November 2004. This room has been an unrestricted area since prior to 1980; radioactive materials were not used in this area after 1980.

All points surveyed (4 total) demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities.

We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. A record of the most recent historic surveys (i.e. prior to the final decommissioning survey) of MB 159 is included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector.

NHEERL-WED  
RADIATION AREA SURVEY

LOG NO. 04-23

DATE 11-11-04

FIXED SURVEY

LOCATION MB

ROOM 159

INSTRUMENT Ludlum 2000 Scaler  
SERIAL NO. 83810 / PR 070834

Pancale Probe AA-9

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
<u>1</u>	<u>24</u>	<u>LLD<sub>95</sub></u>	<u>ND</u>
<u>2</u>	<u>30</u>	<u>↓</u>	<u>↓</u>
<u>3</u>	<u>36</u>	<u>↓</u>	<u>↓</u>
<u>4</u>	<u>28</u>	<u>↓</u>	<u>↓</u>

$LLD_{95} = \left\{ \left( \frac{\sqrt{38}}{0.5} \right) \times 2.96 \right\} \cdot \frac{1}{6} = \frac{113}{CPM}$

BACKGROUND STANDARD <sup>14</sup>C 0.164 <sub>μCi</sub> 76 CPM 10340 CPM  
Time 0.5' 2.8% off.

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>

$LLD_{95} = \left\{ ( \quad ) \times 2.96 \right\} + \quad = \quad CPM$

BACKGROUND STANDARD (          )         

COMMENTS:  
J Monav  
RADIATION SPCL.

11-16-04  
DATE





NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION MB

ROOM 159



Wall Survey's

Vertical text on the left margin, possibly a page number or reference code, including the number '17' at the bottom.

(270)  
159

86-23

DATE: 31 Oct 80

SUBJECT:

Vacating Room 270 and  
Room 159 Box #1

FROM:

Ron Riley *RJR*

TO:

Radiation Safety Officer

via: Assistant Radiation Safety Officer

This is to notify you that as of  
November 5, 1980 I will no longer  
occupy rooms 270 and ~~Room~~ 159  
(Box #1). All radioactive materials  
have been properly disposed or transfer-  
red. Attach is the count data  
for "swipes" taken at various locations  
used for handling or storing radioisotopes.  
To the best of my knowledge there is  
no radioactive contamination in either  
of these rooms.

*RJR*  
H.P.

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 173 Final Contamination Survey.**

Description and Historic Use:

Large Library Room (900 ft<sup>2</sup>). No known use of radioisotopes in this room.

Surveys:

A total (fixed + removable) contamination survey was conducted in MB 173 in November 2004.

All points surveyed (8 total) demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at this facility.

We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in the facility.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector.

NHEERL-WED  
RADIATION AREA SURVEY  
FIXED SURVEY

LOG NO. 04-23

DATE 11-16-04

LOCATION MB

ROOM 17B

INSTRUMENT Ludlum 2000 Scaler Panake Probe A49  
SERIAL NO. 83810 / PR 070834

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	68	2100	ND
2	46		
3	42		
4	34		
5	48		
6	42		
7	38		
8	46		

$LLD_{95} = \left\{ \left( \frac{\sqrt{72}}{0.5} \right) \times 2.96 \right\} + = 72 \text{ CPM}$   
BACKGROUND STANDARD (<sup>14</sup>C 0.168 μCi) 44 CPM 11,790 CPM  
Time 0.5' 3.2%

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>

$LLD_{95} = \left\{ ( \text{---} ) \times 2.96 \right\} + = \text{---} \text{ CPM}$   
BACKGROUND STANDARD ( )

COMMENTS:

D. Monaco  
RADIATION SPCL.


11-16-04  
DATE

NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION NB

ROOM 173  
*Library*



Wall Surveys except #6 (Desk)

Vertical text on the left margin, possibly a page number or reference code, including the number '17' at the bottom.

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date:** November 27, 2004  
**Subject:** Room Survey: Main Building 190 Final Contamination Survey.

Description and Historic Use:

Single Lab (225 ft<sup>2</sup>). This is the Radiation Safety Laboratory/Office. All radioisotopes tracers and sealed sources used at the Western Ecology Division were stored and/or handled in MB 190. Only references and standards are presently stored in this area pending final decommissioning approval and license termination. No sealed sources were used in this area.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in MB 190 in November 2004. All total contamination surveys (38 total) demonstrated no contamination. Six swipes indicated very low levels of removable contamination from tritium (0.14 – 1.73 Bq/100 cm<sup>2</sup>) and/or carbon-14 (0.25 – 1.85 Bq/100 cm<sup>2</sup>). The swipe of the exhaust plenum of a portable ventilation cabinet indicated both tritium and carbon-14 contamination (3.98 – 5.08 Bq/100 cm<sup>2</sup>). This will be decontaminated when disassembled. The sanitary sewer drain line indicated contamination of the iron tail piece (3.47 and 12.25 Bq/100 cm<sup>2</sup> of tritium and carbon-14 respectively). This piece will be removed, decontaminated, and disposed when the lab is disassembled as scheduled (when decommissioning is complete). Both the ventilation cabinet and the drain tail piece are less than the NRC criteria for contamination in an unrestricted area. All other sampling points were at background. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. A HVAC duct swipe was made in November 2004 which detected contamination of 0.37 Bq/100 cm<sup>2</sup> of carbon-14.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of MB 190 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-

wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.







NHEERL-WED  
RADIATION AREA SURVEY  
REMOVABLE

LOG NO. 04-25  
1/2

DATE 11-24-04

LOCATION NB 190 ROOM 190

INSTRUMENT LSC 2000 CA Packard  
SERIAL NO. 036755

3-H

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	4	LLD <sub>95</sub>	ND*
2	9	↓	↓
3	5	↓	↓
4	5	↓	↓
5	4	↓	↓
6	3	↓	↓
7	11	↓	↓
8	61	104	1.73
9	42	67	1.12
10	6	LLD <sub>95</sub>	ND
11	6	↓	ND
12	12	9	0.14
13	22	28	0.47
14	11	LLD <sub>95</sub>	ND
15	4	↓	↓
16	6	↓	↓
17	6	↓	↓
18	3	↓	↓
19	8	↓	↓
20	9	↓	↓
21	6	↓	↓
22	6	↓	↓
23	5	↓	↓
24	1	↓	↓
25	8	↓	↓
26	4	↓	↓
27	10	↓	↓
28	12	9	0.14

LLD<sub>95</sub> =  $\left\{ \left( \frac{\sqrt{21}}{3} \right) \times 2.96 \right\} + = \textcircled{12} \text{ CPM}$   
 BACKGROUND STANDARD (3<sub>H</sub> 64,179 DPM) 7 CPM 64,012 dpm

14-C

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
	14	LLD <sub>95</sub>	ND
	16	↓	↓
	14	↓	↓
	15	↓	↓
	18	↓	↓
	16	↓	↓
	18	↓	↓
	127	111	1.85
	103	87	1.45
	11	LLD <sub>95</sub>	ND
	15	↓	↓
	25	↓	↓
	82	76	1.27
	37	21	0.35
	17	LLD <sub>95</sub>	ND
	17	↓	↓
	14	↓	↓
	12	↓	↓
	18	↓	↓
	15	↓	↓
	17	↓	↓
	19	↓	↓
	16	↓	↓
	14	↓	↓
	15	↓	↓
	16	↓	↓
	16	↓	↓
	31	15	0.25

LLD<sub>95</sub> =  $\left\{ \left( \frac{\sqrt{39}}{3} \right) \times 2.96 \right\} + = \textcircled{19} \text{ CPM}$   
 BACKGROUND STANDARD (14<sub>C</sub> 84,000 DPM) 13 CPM 85,008

COMMENTS: ND\* = NOT DETERMINED. Below the detection limits.

J. Monahan  
RADIATION SPCL.


11-26-04  
DATE



NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-25

LOCATION MB ROOM 190




### NHEERL-WED RADIATION AREA SURVEY FIXED

LOG NO. 04-18  
2/2

DATE 10/4/04

LOCATION MAIN BLDG ROOM 190



SWIPE #	GROSS CPM	NET DPM	ACTIVITY - Bq/100 CM <sup>2</sup>
1	125	LLD <sub>95</sub>	ND*
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			

$LLD_{95} = \left\{ (\sqrt{125}) \times 2.95 \right\} + \dots = 158 \text{ CPM}$   
 BACKGROUND 125 CPM  
 STANDARD (<sup>137</sup>Cs - July 1) 10,000 CPM  
 INSTRUMENT  Ludlum # 3   
 SERIAL NO.  77176



COMMENTS: ND\* = NOT DETERMINED. Below the detection limits.

P. Mann  
RADIATION SPCL

10/4/04  
DATE

## NHEERL-WED RADIATION AREA SURVEY REMOVABLE-LSC


LOG NO. 04-13

1/4

DATE 06-08-04

LOCATION MAIN BLDG ROOM 190

3 H



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
---------	-----------	---------	---------------------------------

10	5	LLD <sub>95</sub>	ND*
11	15	↓	↓
12	5	↓	↓
13	6	↓	↓
14	14	↓	↓
15	10	↓	↓
16	3	↓	↓
17	7	↓	↓
18	8	↓	↓
19	7	↓	↓
20	5	↓	↓
21	9	↓	↓
22	10	↓	↓
23	9	↓	↓

$$B = \text{LLD}_{95} = \left\{ \left( \frac{\sqrt{3 \times 10}}{3} \right) \times 2.96 \right\} + = \text{CPM} \quad 16 \text{ CPM}$$

BACKGROUND 10.33 CPM  
 STANDARD (3H (4, 179 DPM) 73,375 DPM  
 INSTRUMENT Packard 2200CA  
 SERIAL NO. 036755

COMMENTS: ND\* = NOT DETERMINED BELOW THE DETECTION LIMITS OF THE INSTRUMENTS.

PA Mon  
RADIATION SPCL.

6/13/04  
DATE

NO CONTAMINATION

NHEERL-WED  
RADIATION AREA SURVEY


LOG NO. 04-13

3/4

DATE 06-08-04

LOCATION MAIN BLDG ROOM 190

14 C



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
10	28	LLD <sub>95</sub>	ND*
11	66	44	0.73
12	28	LLD <sub>95</sub>	ND*
13			
14	26		
15	36		
16	29		
17	30		
18	25		
19	24		
20	28		
21	27		
22	23		
23	30	✓	✓

LLD<sub>95</sub> =  $\left\{ \left( \frac{\sqrt{31.33}}{3} \right) \times 2.96 \right\} + =$  CPM

41CPM

BACKGROUND 31.33 CPM  
STANDARD (1% 84,000 DPM) 84,914 DPM  
INSTRUMENT Packard 2202CA  
SERIAL NO. 036755



COMMENTS: \*ND = NOT DETERMINED. Below the DETECTION Limits of the INSTRUMENTS

6/13/04 P.A. Man  
RADIATION SPCL. DATE

Contamination is restricted to "Contamination Area" of restricted Rad Lab. Will be decontaminated.  
OK


# NHEERL-WED RADIATION AREA SURVEY

LOG NO. 04-03

DATE 2-4-04

LOCATION MAIN BLDG ROOM 190

REMOVABLE



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	26	44095	ND*
2	33	↓	↓
3	24	↓	↓
4	25	↓	↓
5	28	↓	↓
6	29	↓	↓
7	20	↓	↓

$$LLD_{95} = \left\{ \left( \frac{\sqrt{58}}{2} \right) \times 2.96 \right\} + 40.27 \text{ CPM}$$

BACKGROUND 29 × 2 = 58  
STANDARD (<sup>60</sup>Ni-11,100 dpm 117,666 DPM)  
INSTRUMENT LSC 2200 CA  
SERIAL NO. 036755



COMMENTS: ND\* = NOT DETERMINED. BELOW THE DETECTION LIMITS OF THE INSTRUMENT.

P. A. Monahan  
RADIATION SPCL

2-5-04  
DATE



NHEERL-WED  
RADIATION AREA SURVEY


LOG NO. 04-01

2/2

DATE 1/2/04 1/2/04

FIXED

LOCATION MAIN BLDG ROOM 190



SWIPE #	GROSS CPM	NET DPM	ACTIVITY -Bq/100 CM <sup>2</sup>
1	125	LLD <sub>95</sub>	ND*
2	↓	↓	↓
3	↓	↓	↓
4	↓	↓	↓
5	↓	↓	↓
6	↓	↓	↓
7	↓	↓	↓
8	↓	↓	↓
9	↓	↓	↓
10	↓	↓	↓
11	↓	↓	↓
12	↓	↓	↓
13	↓	↓	↓

LLD<sub>95</sub> = { (√125) X 2.96 } 159 CPM

BACKGROUND 125 CPM  
STANDARD (137Cs) 10,500  
INSTRUMENT Ludlum #3  
SERIAL NO. 77176

COMMENTS: \* ND\* = NOT DETERMINED BELOW THE DETECTION LIMIT OF THE INSTRUMENT.

A. Man  
RADIATION SPCL.

1/21/04  
DATE


NHEERL-WED  
RADIATION AREA SURVEY

LOG NO. 96-29

DATE 11-26-96

LOCATION MAIN BLDG ROOM 190

14C



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	27	LLDS	ND
2	18	"	Act
3	23	"	↓
4	30	13	0.22
5	18	LLDS	ND
6	24	"	↓
7	20	"	↓
8	24	"	↓
9	23	"	↓
10	20	"	↓
11	21	"	↓
12	21	"	↓
13	27	"	↓

$$LLD_{95} = \left\{ \left( \frac{\sqrt{36}}{2} \right) \times 2.96 \right\} + 11 = 27 \text{ CPM}$$

(14)

BACKGROUND	18 CPM (21 DPM)
STANDARD (1% 54000)	85.875
INSTRUMENT	Prokema 2200A
SERIAL NO.	036755

COMMENTS: Re-swipes

*D.A. Moran*  
RADIATION SPCL.


11/27/96  
DATE

NHEERL-WED  
RADIATION AREA SURVEY  
FIXED

LOG NO. \_\_\_\_\_

DATE 10/29/96

LOCATION MAIN BLDG ROOM 190



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>	
1	75	0	0	10/29/96
2	75	0	0	10/29
3	75	0	0	10/29
4	75	0	0	10/29/96
B	75	0	0	10/29/96
1	75	0	0	10/30/96
2	75	0	0	10/30/96
3	75	0	0	10/30/96
4	75	0	0	10/30/96
B	75	0	0	10/30/96
1	75	ND	Dist	10/31/96
2	75	0	0	
3	75	0	0	
4	75	0	0	
B	75	0	0	
1	70	ND	Dist	11-3
2	70	0	0	
3	70	0	0	
4	70	0	0	
B	70	0	0	
1	70	ND	Dist	11-7
2	70	0	0	
3	70	0	0	
4	70	0	0	
B	70	0	0	

LLD<sub>95</sub> = { (√75 / 1) X 2.96 } + = CPM

BACKGROUND 75 cpm  
STANDARD (<sup>137</sup>Cs L<sub>1</sub>) 9500 cpm  
INSTRUMENT Ludlum #3  
SERIAL NO. 77146



COMMENTS:

DA Mon  
RADIATION SPCL

11-7-96  
DATE

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 204 Final Contamination Survey.**

Description and Historic Use:

Single lab (225 ft<sup>2</sup>). Rubidium-86 and phosphorus-32 tracers, and nickel-63 sealed sources. Radioisotopes were not used in this room since 1994. There is no record of leakage of any sealed sources used in this area.

Surveys:

A total (fixed + removable) contamination survey was conducted in MB 204 in November 2004. All points surveyed (5 total) demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities.

We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. A record of the most recent historic surveys (i.e. prior to the final decommissioning survey) of MB 204 is included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector.

NHEERL-WED  
RADIATION AREA SURVEY  
FIXED SURVEY

LOG NO. 04-23

DATE 11-11-04

LOCATION MB

ROOM 204

INSTRUMENT Ludlum 2000 Scaler PANcake Probe #19  
SERIAL NO. 83810 / PR 070834

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
<u>1</u>	<u>32</u>	<u>LLD<sub>95</sub></u>	<u>ND</u>
<u>2</u>	<u>26</u>	↓	↓
<u>3</u>	<u>22</u>	↓	↓
<u>4</u>	<u>22</u>	↓	↓
<u>5</u>	<u>38</u>	↓	↓

LLD<sub>95</sub> =  $\left\{ \left( \frac{\sqrt{38}}{0.5} \right) \times 2.96 \right\} / 6 =$  113 CPM

BACKGROUND STANDARD (<sup>14</sup>C 0.168 μCi) 76 CPM 19340 CPM 2.8% off.

Time 0.5'

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>

LLD<sub>95</sub> =  $\left\{ ( \dots ) \times 2.96 \right\} + =$  CPM

BACKGROUND STANDARD ( ) =

COMMENTS:

Mona  
RADIATION SPCL.



11-16-04  
DATE

NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION MB

ROOM 204



89-7  
5/5

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: <sup>32</sup>P

Date: 4-28-89

Method of Detection: LSC 460

Blank CPM: 23

5-1700

Radiation Safety Technician  
CPM 50-1700 9

Swipe #	Location		Nuclide:		
	RM #	Area	NET CPM	NET DPM	µCi
2	204	Door	54		
3		Phone	20		
4		Floor	3	<LLD <sub>95</sub>	
5		Floor	0		
6		Power Supply	2	<LLD <sub>95</sub>	
7		Counter	0		
8	294	Door	10		
		Hood Sill	1	<LLD <sub>95</sub>	
		Hood Sill	40		
		Floor	0		
		Floor	0		
		Desk	0		

Nuclide:		
NET CPM	NET DPM	µCi
53		
17		
4	<LLD <sub>95</sub>	
0		
2	<LLD <sub>95</sub>	
0		
10		
4	<LLD <sub>95</sub>	
59		
0		
2	<LLD <sub>95</sub>	
0		

Calculation of Lower Limits of Detection (LLD)

Gross Background Counts:  
Total Background Count time:

Nuclide: 5-1700      Nuclide: 50-1700

69      27  
3      3

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

13      8

LLD (95%) =

REMARKS:

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 226 Final Contamination Survey.**

Description and Historic Use:

Small single lab (225 ft<sup>2</sup>). Potentially hydrogen-3 and carbon-14 tracers. No isotope use since prior to 1986.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in MB 226 in November 2004. This room was a unrestricted area since prior to 1986; radioactive materials were not used in this area after 1985.

All points surveyed (9 total and 9 removable) demonstrated no significant contamination. One point indicated very low levels of removable contamination from tritium (0.38 Bq/100 cm<sup>2</sup>). All other sampling points were at background. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of MB 226 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.



NHEERL-WED  
RADIATION AREA SURVEY  
FIXED SURVEY

LOG NO. 04-23

DATE 11-11-04

LOCATION MB 226 ROOM 226

INSTRUMENT Ludlum 2000 Scaler Pancake Probe # 9  
SERIAL NO. 83810 / PR 070834

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	32	LLD <sub>95</sub>	ND
2	26		
3	35		
4	42		
5	26		
6	32		
7	42		
8	42		
9	42		

LLD<sub>95</sub> = {  $\left(\frac{\sqrt{38}}{0.5}\right) \times 2.96$  } 76 = 113 CPM

BACKGROUND STANDARD (<sup>14</sup>C 0.168 μCi) 76 CPM / 10,310 CPM = 2.8% off.  
Time 0.5'

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>

LLD<sub>95</sub> = {  $\left(\frac{\sqrt{\quad}}{\quad}\right) \times 2.96$  } + = CPM

BACKGROUND STANDARD ( ) =

COMMENTS:

D Monaco  
RADIATION SPCL.

11-16-04  
DATE

# NHEERL-WED RADIATION AREA SURVEY

LOG NO. 0A-23

DATE 11-11-04

LOCATION MB

ROOM 226

INSTRUMENT SERIAL NO. Packard LSC 2200 CA  
Q36755

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	4	LLD <sub>95</sub>	ND
2	5	↓	↓
3	6	↓	↓
4	5	↓	↓
5	5	↓	↓
6	5	↓	↓
7	10	23	0.38
8	5	LLD <sub>95</sub>	ND
9	3	↓	↓

LLD<sub>95</sub> = { (---) × 2.96 } + = 7 CPM  
BACKGROUND STANDARD (3<sub>H</sub> 64,179 DPM) 56,056 DPM  
87% eff

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
	16	LLD <sub>95</sub>	ND
	13	↓	↓
	18	↓	↓
	14	↓	↓
	14	↓	↓
	15	↓	↓
	14	↓	↓
	11	↓	↓
	10	↓	↓

LLD<sub>95</sub> = { (---) × 2.96 } + = 30 CPM  
BACKGROUND STANDARD (1<sub>C</sub> 84,000 DPM) 85,603 dpm  
102% eff

COMMENTS:

D. Mon  
RADIATION SPCL.

11-18-04  
DATE

470287


NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 01-23

LOCATION MB

ROOM 226

0  
1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100



226

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
Corvallis Environmental Research Laboratory

SUBJECT: Decommissioning of Room 226 with Regards to Use  
as a Radioisotope Handling Space

DATE: May 6, 1980

FROM: Ron Riley *Ron Riley*

TO: Milt Feldman, RSO

1. Room 226 has been vacated.
2. Representative 10cm<sup>2</sup> areas of bench space<sup>(B)</sup>, floors<sup>(F)</sup>, walls<sup>(W)</sup>, ceiling<sup>(C)</sup>, and sinks<sup>(S)</sup> were swiped with absorbent pads (Fig. 1). The pads were assayed for radioactivity by standard liquid scintillation counting procedures (Table 1).
3. Based on the results of #2, the room is considered, in my opinion, to be free of surface contamination as defined by the "CERL Radiation Rules and Regulations", Section 10.

cc: Frank Stay  
Bob Trippel  
Dave Specht  
Tamotsu Shiroyama  
Ron Gordon

*Bulle  
do a few  
swipes to check him  
and send  
me a memo  
JMF*

REMOVABLE CONTAMINATION LEVELS (SMEARS)\*

226

B. A. Pickett  
Surveyor

Release Survey rm 226  
Purpose of Survey

5/9/80  
Date

	1	2	3	4	5	6	7	8
Location	BKG	Gross β cpm w/ <sup>3</sup> H	Net β cpm w/ <sup>3</sup> H	Gross β cpm w/o <sup>3</sup> H	Net β cpm w/o <sup>3</sup> H	Net β μCi w/o <sup>3</sup> H	Net <sup>3</sup> H cpm	Net <sup>3</sup> H μCi
#226 Door	45.6	48.0	< LLD 2.4	—	—	—	—	—
" Drain	45.6	47.8	< LLD 2.2					
" Sink	45.6	46.2	< LLD 0.6					
" Bench	45.6	47.4	< LLD 1.8					

\* No smearing efficiency value is factored into these results.

Instrument used: NMCGPC # I

LLD(95%) = 14.1 cpm =  $4.66 \frac{\sqrt{228}}{5}$

LLD(β w/o <sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

LLD(<sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

USE REVERSE SIDE FOR CALCULATIONS




Fig. 1. Floor plan, Room 226. Area indicated in red is area designated for handling of radioisotopes. Areas assayed for radioactivity are presented. Please refer to text of memo for explanation. Also, envision room as 3-D space for correct interpretation.

TABLE 1 - Ten minute counts  
of surface swipes. 5/6/80

226

176 22.6 7.5	25.1 7.5	- Blk-1
177 22.1 7.5	23.2 7.5	- F-1
180 25.9 7.5	24.4 7.5	- F-2
181 21.2 7.5	23.1 7.5	- F-3
182 23.0 7.5	25.3 7.5	- F-4
183 20.7 7.5	23.7 7.5	- F-5
184 22.6 7.5	22.2 7.5	- F-6
185 22.7 7.5	23.6 7.5	- F-7
186 23.9 7.5	25.0 7.5	- B-1
187 22.9 7.5	22.1 7.5	- B-2
188 22.4 7.5	24.0 7.5	- B-3
189 23.7 7.5	22.2 7.5	- B-4
190 22.7 7.5	22.0 7.5	- B-6
191 26.2 7.5	26.0 7.5	- <del>S-1</del> B-7
192 24.2 7.5	22.1 7.5	- <del>S-2</del> S-1
193 25.2 7.5	23.2 7.5	- <del>S-3</del> S-2
194 26.1 7.5	21.5 7.5	- <del>S-4</del> S-3
195 21.2 7.5	22.5 7.5	- <del>S-5</del> S-4
196 25.0 7.5	23.1 7.5	- <del>W-1</del> W-1
197 27.5 7.5	25.5 7.5	- <del>W-2</del> W-2
198 24.0 7.5	22.9 7.5	- <del>W-3</del> W-3
199 23.3 7.5	27.6 7.5	- <del>C-1</del> C-1
200 23.0 7.5	21.5 7.5	- <del>C-2</del> C-2
1 24.4 7.5	23.2 7.5	- <del>C-3</del> C-3
2 24.1 7.5	24.0 7.5	- C-4
3 25.0 7.5	23.1 7.5	Blk-2

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 228 Final Contamination Survey.**

Description and Historic Use:

Double lab (450 ft<sup>2</sup>). Hydrogen-3 and carbon-14 tracers, and nickel-63 and hydrogen-3:scandium sealed sources. No isotope use since 1991. There is no record of leakage of any sealed sources used in this area.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in MB 228 in November 2004. All points surveyed for total contamination (16) demonstrated no contamination. Sixteen points were swiped for removable contamination. Eight swipes indicated very low levels of tritium contamination (0.23 – 0.88 Bq/100 cm<sup>2</sup>). All other sampling points were at background. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities.

This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. A HVAC duct swipe was also made in November 2004 which detected 0.42 Bq/100 cm<sup>2</sup> of carbon-14.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of MB 228 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 3 Survey Meter equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.



NHEERL-WED  
RADIATION AREA SURVEY  
FIXED SURVEY

LOG NO. 4-23

DATE 11-11-04

LOCATION MB

ROOM 228

INSTRUMENT Ludlum 2000 Scaler Panache Probe #49  
SERIAL NO. 83810 / PR 070834

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	26	LLD <sub>95</sub>	ND
2	32	↓	↓
3	34	↓	↓
4	34	↓	↓
5	29	↓	↓
6	26	↓	↓
7	46	↓	↓
8	60	↓	↓
9	44	↓	↓
10	50	↓	↓
11	33	↓	↓
12	35	↓	↓
13	36	↓	↓
14	38	↓	↓
15	33	↓	↓
16	32	↓	↓

$$LLD_{95} = \left\{ \left( \frac{\sqrt{38}}{0.3} \right) \times 2.96 \right\} 76 = 113 \text{ CPM}$$

BACKGROUND STANDARD (<sup>14</sup>C 0.16 μCi) 76 CPM  
19540 CPM  
 Time 0.5' 2.8% off.

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>

$$LLD_{95} = \left\{ \left( \frac{\sqrt{\quad}}{\quad} \right) \times 2.96 \right\} + \quad = \text{CPM}$$

BACKGROUND STANDARD ( ) =

COMMENTS:

D Monaro      11-11-04  
RADIATION SPCL.      DATE




NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 4-23

LOCATION MB

ROOM 228



RADIATION CONTAMINATION SURVEY

11-4-91 Type of Survey: Removable Contamination 228

Background Counts:  ${}^3\text{H} = 4.1 \text{ cpm}$   ${}^{14}\text{C} = 10.3 \text{ cpm}$  Total Count Time (min.): 10'

Limits of Detection:  ${}^3\text{H} = (\sqrt{41/10}) \times 466 = 3$   ${}^{14}\text{C} = (\sqrt{103/10}) \times 466 = 5$  cpm

Instrument Used:  GFPC  LSC  Ion Chamber Model: PACKARD 2200 S/N: \_\_\_\_\_  
 GM  Scintillation

Standard:  ${}^3\text{H}$  123, 954 dpm 7%  ${}^{14}\text{C}$  85,428 2% % Error

Room No.	Swipe Description	Nuclide: <u><math>{}^3\text{H}</math></u> per 100 cm <sup>2</sup> pCi			Nuclide: <u><math>{}^{14}\text{C}</math></u> per 100 cm <sup>2</sup>		
		CPM±SD	Net DPM	Net Activity	CPM±SD	Net DPM	Net Activity
130	Hood sill	3	7	32 pCi	3	<LUD <sub>95</sub>	NA
	SASH	0	0	NA	2	↓	↓
	Floor	0	0	↓	2	↓	↓
	N. Counter	0	0	↓	0	0	↓
	S. Counter	0	0	↓	2	<LUD <sub>95</sub>	↓
	door	0	0	↓	0	0	↓
232	S. Hood sill	4	13	5.9 pCi	1	<LUD <sub>95</sub>	↓
	SASH	2	<LUD <sub>95</sub>	NA	0	0	↓
	Floor	0	0	↓	4	<LUD <sub>95</sub>	↓
	N Hood sill	2	<LUD <sub>95</sub>	↓	4	↓	↓
	SASH	1	1	↓	1	↓	↓
	Floor	0	0	↓	0	0	↓
	desk	0	0	↓	1	<LUD <sub>95</sub>	↓
	Phone	1	<LUD <sub>95</sub>	↓	0	0	↓
	Floor	0	0	↓	0	0	↓
	counter	0	0	↓	1	<LUD <sub>95</sub>	↓
	door	0	0	↓	0	0	↓
228	S Hood SASH	2	<LUD <sub>95</sub>	↓	0	0	↓
	Sill	1	<LUD <sub>95</sub>	↓	0	0	↓
	Floor	0	0	↓	0	0	↓

Chris Mon  
 Date \_\_\_\_\_

RADIATION CONTAMINATION SURVEY

11-4-91

Type of Survey: \_\_\_\_\_

Area(s): \_\_\_\_\_

Background Counts: \_\_\_\_\_ ± \_\_\_\_\_ CPM Total Count Time (min.): \_\_\_\_\_

Lower Limits of Detection: \_\_\_\_\_ CDM

Instrument Used:  GFPC  LSC  GM  Ion Chamber  Scintillation Model: \_\_\_\_\_ S/N: \_\_\_\_\_

Background: \_\_\_\_\_ CPM±SD \_\_\_\_\_ DPM±SD Standard ( \_\_\_\_\_ ): \_\_\_\_\_ % Error

Sample No.	Room No.	Swipe Description	Nuclide: _____ per 100 cm <sup>2</sup>			Nuclide: _____ per 100 cm <sup>2</sup>		
			CPM±SD	Net DPM	Net Activity pCi	CPM±SD	Net DPM	Net Activity
22	228	Hood Floor	0	0	NA	0	0	NA
23		Floor	0	0	↓	0	0	↓
24	256	door	1	<LD <sub>95</sub>	↓	0	0	↓
25		Phone	3	8	3.6 pCi	0	0	↓
26		Counter	2	<LD <sub>95</sub>	NA	3	<LD <sub>95</sub>	↓
27		Desk	0	0	NA	0	0	↓
		LSC	3	7	3.2 pCi	3	<LD <sub>95</sub>	↓
28		hood <del>ST</del> <sup>SILL</sup>	1	<LD <sub>95</sub>	NA	3	<LD <sub>95</sub>	↓
29		FLOOR <del>ST</del>	1	<LD <sub>95</sub>	↓	0	0	↓
30	258	Hood <del>ST</del> sill	0	0	↓	6	7	3.2 pCi
31		Floor	1	<LD <sub>95</sub>	↓	3	<LD <sub>95</sub>	↓
32		LSC	1	<LD <sub>95</sub>	↓	3	<LD <sub>95</sub>	↓
33		door	3	7	3.2 pCi	0	0	↓
34	TEMP 113	TABLE	0	0	NA	3	<LD <sub>95</sub>	↓
35		Sink counter	0	0	↓	0	0	↓
36		Floor	0	0	↓	0	0	↓
37		door	0	0	↓	2	<LD <sub>95</sub>	↓
38		TABLE	0	0	↓	2	<LD <sub>95</sub>	↓
39		Floor	0	0	↓	4	<LD <sub>95</sub>	↓

Radiation Safety Date: \_\_\_\_\_

91-2  
1/2

AREA CONTAMINATION SURVEY SHEET  
NON-REMOVABLE Contamination

Radionuclide(s) Surveyed: P + Y

Date: 1/3/91

Method of Detection: G-M S/N ~~22477~~ 77222 PM  
1100cm<sup>2</sup>

John A. Moore  
Radiation Safety Technician

Swipe #	Location RM # Area	Nuclide: <u>P + Y</u>			Nuclide: <u>Y</u>		
		NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
	Bkbed	(125)					
<del>228</del>	S. STANDARD (check source III)	11,000					
46 228	S. Hood inside	∅	N/A	N/A			
	outside	∅					
	Slate Desk	∅					
	FLOOR	∅					
	Counter	∅					
	S. Freezer outside	∅					
	S. Freezer inside	800	32,000 <del>40000</del>	0.017 0.014	∅	N/A	N/A
	Refrigerator (OUT)	∅	N/A	N/A			
	N. Refrigerator (IN)	900 <del>1000</del>	36,225 <del>45000</del>	0.016 0.020	∅	N/A	N/A
	(IN) Drying oven	∅	N/A	N/A			
	OUT Drying oven	∅					
	N. Hood (OUT)	∅					
	N. Hood IN	∅					

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

\_\_\_\_\_

REMARKS:

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: \_\_\_\_\_

Date: \_\_\_\_\_

Method of Detection: \_\_\_\_\_

Radiation Safety Technician

Swipe #	Location		Nuclide: $\beta/\gamma$			Nuclide: $\gamma$		
	RM #	Area	NET CPM	NET DPM	$\mu\text{Ci}$	NET CPM	NET DPM	$\mu\text{Ci}$
	228 MB	Wall by N. Hood	$\emptyset$	N/A	N/A			
		FLOOR	$\emptyset$	↓	↓			
		Counter	$\emptyset$	↓	↓			
		Hood Cabinet	$\emptyset$	↓	↓			
		(DND)						
		$^{14}\text{C}$ 0.168 $\mu\text{Ci}$ source	13000 <del>7750</del>		0.006 <del>0.0034</del>	4.2% $\beta/\gamma$ <del>2.0% <math>\beta/\gamma</math></del> 10		

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_

$LLD (95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%)= \_\_\_\_\_

\_\_\_\_\_

REMARKS:

AREA CONTAMINATION SURVEY SHEET  
Removable Contamination MB 228

Radionuclide(s) Surveyed:  $^3\text{H}$ ,  $^{14}\text{C}$  &  $^{35}\text{S}$

Date: 1/3/71

Method of Detection: LSC

O.A. Mon  
Radiation Safety Technician

Swipe #	Location RM # Area	Nuclide: $^3\text{H}$			Nuclide: $^{14}\text{C}$		
		NET CPM	NET DPM	pli #ct	NET CPM	NET DPM	pli #ct
	BACKRD	10.2	N/A	N/A	13.3	N/A	N/A
228	5 Hood Sash	0	N/A	✓	0	N/A	✓
	" Sill	0	N/A		0	N/A	
	Hood Floor	0	N/A		0	N/A	
	" Walls	0	N/A		3	N/A	
	" Fixtures	0	N/A	✓	0	N/A	✓
	Hood Cup Sinks	5	19	9	6	6	3
	Hood Apron	75	265	119	4	0	N/A
	Floor <sup>in RT Hood</sup>	13	58	26	7	5	3
	Stole desk	0	N/A	N/A	5	7	3
	Lucite hood	0	N/A	N/A	4	0	N/A
	South rope out	0	N/A	N/A	15	19	9
	South rope in	15	17	8	77	95	43
	S. refer in	16	16	8	87	108	49
	S refer in racks	25	27	12	122	151	68

Calculation of Lower Limits of Detection (LLD)

Nuclide:  $^3\text{H}$       Nuclide:  $^{14}\text{C}$

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

102      133  
10'      10'

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = 5      5

REMARKS:



AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: \_\_\_\_\_

Date: \_\_\_\_\_

Method of Detection: \_\_\_\_\_

Radiation Safety Technician \_\_\_\_\_

Swipe #	Location RM # Area	Nuclide:			Nuclide:		
		NET CPM	NET DPM	PCI #/ft	NET CPM	NET DPM	PCI #/ft
	S refer main cool tray	155	250	113	607	743	335
	Zuete (Floor)	2	0	N/A	22	28	13
	Refer NORTH inside	3	0	✓	19	24	11
	Refer NORTH outside	0	0		14	18	8
	Refer NORTH outside	0	0		9	11	5
	Refer NORTH inside	2	0		38	49	22
	Refer NORTH Sub Bench	0	0		10	14	6
	Hood NORTH SASH	0	0		5	6	3
	Hood NORTH Sill	0	N/A		2	0	N/A
	Hood Floor	0	N/A		3	0	N/A
	Hood Floor	0	0		2	0	N/A
	Hood WALL	3	0		40	57	23
	Hood WALL	0	0	✓	8	11	5
	Hood cabinet	32	122	55	9	4	2
	FLOOR	0	0	N/A	5	7	3

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

REMARKS:

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: \_\_\_\_\_

Date: \_\_\_\_\_

Method of Detection: \_\_\_\_\_

Radiation Safety Technician \_\_\_\_\_

Swipe #	Location		Nuclide:		pCi #Et	Nuclide:		pCi #Et
	RM #	Area	NET CPM	NET DPM		NET CPM	NET DPM	
		drying oven	71	276	124	2	0	N/A
		drying oven	0	N/A	N/A	0	N/A	N/A
		drying oven	0	N/A	N/A	1	N/A	N/A
		door	0	N/A	N/A	7	8	4
		3-H 31452	109 233	233		104	109	
		3-H 22602 ± 90	1049 2483	2483		266	130	
		3-H 25165 ± 407	10178 24415	24415		1864	361	
		3-H NEW 64705	64705 13582	13582		10153	109	
		14-C 121 dpm	9	0		95	118	
		14-C 1,19520	127	0		1006	1233	
		14-C 11,055 ± 136	1015	0		8776	10761	
		14-C NEW 84,000	8964	396		70956	84247	

STANDARDS

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
 Total Background Count time: \_\_\_\_\_

$LLD(95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%)= \_\_\_\_\_

REMARKS: \_\_\_\_\_

1/

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: <sup>51</sup>Cr

Date: 7-6-90

Method of Detection: LSC-460

3H

*Philip M...*

Radiation Safety Technician

<sup>14</sup>C, <sup>51</sup>Cr, <sup>35</sup>S

Swipe #	Location		Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi
1		Backrd	9.8	—	N/A
2	130	Counter	1	<	
3		Counter	0	N/A	
4		Floor	0	N/A	
5		Floor	0	N/A	
6		Desk	1	<	
7		Door	0	N/A	✓

Nuclide:		
NET CPM	NET DPM	μCi
12	—	N/A
1	<	
0	N/A	
3	<	
0	N/A	
0	N/A	
5	6	✓

Calculation of Lower Limits of Detection (LLD)

Gross Background Counts:  
Total Background Count time:

Nuclide: 3H      Nuclide: <sup>14</sup>C, <sup>51</sup>Cr, <sup>35</sup>S

100      120

10'      10

5      5

$$LLD (95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$$

LLD (95%)=

REMARKS:

8/4/00

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: \_\_\_\_\_

Date: \_\_\_\_\_

Method of Detection: \_\_\_\_\_

Radiation Safety Technician \_\_\_\_\_

Swipe #	Location RM #	Area	Nuclide:		PLI Act
			NET CPM	NET DPM	
41	238	Counter Dark Room	0	N/A	N/A
42		Floors Dark Room	0		
43		Hood SASH	0		
44		Sill	0		
45		Floor	0		
46	2306	DESK	0		
47		Phone	0	↓	↓
48		Floor	7	32	15
49	228	Hood sill	0	N/A	N/A
50		SASH	0	↓	
51		Floor	0	↓	
52		Hood sill	3	LLD	
53		SASH	0	N/A	
54		Floor	0	↓	
55	294	Hood SASH	0	↓	↓

Nuclide:		PLI Act
NET CPM	NET DPM	
3	<LLD	N/A
4	<LLD	
3	<LLD	
0	N/A	
1	<LLD	
0	N/A	
1	<LLD	
4	<LLD	
1	<LLD	
0	N/A	↓
8	11	5
6	8	4
0	<LLD/N/A	N/A
0	N/A	↓
3	<LLD	↓

Calculation of Lower Limits of Detection (LLD)

Gross Background Counts: \_\_\_\_\_  
 Total Background Count time: \_\_\_\_\_

$(95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

REMARKS: \_\_\_\_\_

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

\_\_\_\_\_  
 \_\_\_\_\_

\_\_\_\_\_

90-22

1/3

AREA CONTAMINATION SURVEY SHEET

228

Radionuclide(s) Surveyed: <sup>35</sup>S <sup>14</sup>C <sup>3</sup>H

Date: 5-18-90

Method of Detection: LSC 460  
3H

PA. Momm  
Radiation Safety Technician  
14C

Ripe #	Location		Nuclide:			Nuclide:			pCi/ft <sup>2</sup>	
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	NET CPM		
1		Backgrd	(12)	(31)	N/A	(15)	(17)	N/A		
2	294	hood sill	46	51	—	230	288	153	<sup>35</sup> S	
3		hood sash	705	<LLD <sub>95</sub>	N/A	34	43	19		
4		Room Floor (hood)	1048	1762	—	3487	4278	2721		
5		W Room Floor	4756	9114	—	14,508	17,786	12,117		
6		N Room Floor	373	663	—	1256	1548	996		
		S Room Floor	448	747	—	1570	1962	1,220		
8		Refr	27	39	—	111	138	78		
9		Freezer	12	15	—	54	67	37		
10		phone	10	5	—	63	79	38		
11		Door	16	30	—	54	67	44		
12		Room Floor (Door)	121	293	—	283	343	286		
13	258	Hood Sill	1	<LLD <sub>95</sub>	N/A	1	<LLD <sub>95</sub>	N/A		
14		Hood SASH	∅ net	<LLD <sub>95</sub>	N/A	5	<LLD <sub>95</sub>	N/A		
15		Floor (E)	∅ net	<LLD <sub>95</sub>	N/A	∅ net	N/A	N/A		

Floor will be decontaminated

END <sup>35</sup>S

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

(95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) =

9                      10

REMARKS: \* Since no <sup>3</sup>H is used in 294, dpm from the low energy range were added to

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: \_\_\_\_\_

Date: 5-18-90

Method of Detection: \_\_\_\_\_

Radiation Safety Technician \_\_\_\_\_

Pipe #	Location		Nuclide:		pCi #Ci	Nuclide:	NET CPM	NET DPM	pCi #Ci
	RM #	Area	NET CPM	NET DPM					
31	236	hood sash <sup>s</sup>	Ø net	N/A	N/A	6	LLD	N/A	
32		hood sill	Ø net	N/A	N/A	Ø net	N/A	N/A	
33		Floor	Ø net	N/A	N/A	Ø net	N/A	N/A	
34		Desk	Ø net	N/A	N/A	Ø net	N/A	N/A	
35		Door	Ø net	N/A	N/A	3	LLD	N/A	
36		hood sash <sup>n</sup>	Ø net	N/A	N/A	Ø net	N/A	N/A	
37		hood sill	20	58	26	23	27	12	
38		Floor	Ø net	N/A	N/A	Ø net	N/A	N/A	
39	228 b	Floor	Ø net	N/A	N/A	Ø net	N/A	N/A	
40		Desk	2	LLD	N/A	1	LLD	N/A	
41		Phone	Ø net	N/A	N/A	5	LLD	N/A	
42	228	hood sash <sup>s</sup>	Ø net	N/A	N/A	Ø net	N/A	N/A	
43		hood sill	Ø net	N/A	N/A	Ø net	N/A	N/A	
44		Floor	Ø net	N/A	N/A	Ø net	N/A	N/A	
45		Door	2	LLD	N/A	6	LLD	N/A	

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
 Total Background Count time: \_\_\_\_\_

$$L(95\%) = \frac{\sqrt{\text{Gross Background Counts}}}{\text{Count Time}} \times 4.66$$

L(95%)= \_\_\_\_\_

MARKS:

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 232 Final Contamination Survey.**

Description and Historic Use:

Single instrument lab (225 ft<sup>2</sup>). Hydrogen-3 and carbon-14 tracers, and nickel-63 and hydrogen-3:scandium sealed sources. This room was decommissioned as a unrestricted area on February 10, 1999. No isotope use since 1999. There is no record of leakage of any sealed sources used in this area.


Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in MB 232 at the time of restricted use decommissioning. The decommissioning records are enclosed. All points surveyed demonstrated no significant contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of MB 232 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.

MEMO

To: Jay Gile, NHEERL RSO  
From: Phil Monaco, Dynamac   
Date: February 10, 1999

Subject: Decommissioning of MB 232b Instrument Lab

The Main Building Instrument Lab Room 232b was surveyed for fixed and removable radioactive contamination. The preliminary surveys found minor contamination levels ( on the counter around the sink covering approximately 200 cm<sup>2</sup>. Fixed contamination ranged from 58-104 Bq/100 cm<sup>2</sup>. <sup>3</sup>H and <sup>14</sup>C removable contamination was 0.02 - 0.6 Bq/100 cm<sup>2</sup> and .015 - .037 Bq/ 100 cm<sup>2</sup> respectively. Contamination levels greater than 1.6 Bq/100 cm<sup>2</sup> were consider unacceptable necessitating decontamination.

The contaminated areas were decontaminated and re-surveyed. Following decontamination, any contamination was below the lower limits of detection for removable and fixed contamination and below the 1.6 Bq/100 cm<sup>2</sup> action level for contamination.

82 locations were swiped or surveyed in the assessment process. The fixed and removable surveys were logged as 99-3, 99-4, 99-5, and 99-6 and placed on file in MB 190.

C: Decommissioning File




# NHEERL-WED RADIATION AREA SURVEY

99  
LOG NO. 95-6

DATE 2-9-99

LOCATION MAIN BLDG ROOM 232B



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM²
1	3H/14C 2.8/3.6	LLD <sub>95</sub>	ND
2	4.6/15.4	↓	↓
3	4.2/3.2	↓	↓
4	1.8/16.2	↓	↓

LLD<sub>95</sub> =  $\left\{ \left( \sqrt{\frac{\text{See Below}}{14C}} \right) \times 2.96 \right\} + 17.6 = \text{CPM}$

*3H 2.6*

**BACKGROUND STANDARD** See Above

**INSTRUMENT** Packard 7200CA

**SERIAL NO.** 36755

COMMENTS: ND = NOT Determined LLD<sub>95</sub>

*[Signature]*  
RADIATION SPCL.

2-10-99  
DATE

3H  $\left( \frac{2.6 \times 5}{5} \right) 2.96 + 2.6 = 4.7 \text{ CPM}$

14C  $\left( \frac{17.6 \times 5}{5} \right) 2.96 + 17.6 = 23. \text{ CPM}$

NHEERL-WED  
**RADIATION AREA SURVEY**  
*Fixed Contamination Survey*

LOG NO. 99-5

DATE 2-9-99

LOCATION MAIN BLDG ROOM 232B

SWIPE # GROSS CPM NET DPM ACTIVITY Bq/100 CM<sup>2</sup>

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	60	LLD <sub>95</sub>	ND*
2	68	LLD <sub>95</sub>	ND
3	927	2194 dpm	183 Resurvey
4	587		
5	867		
6	62	LLD <sub>95</sub>	ND
7	64	LLD <sub>95</sub>	ND
8	687	2111 dpm	176 Resurvey
9	845		
10	727	LLD <sub>95</sub>	ND
11	625		
12	867	2222	185 Resurvey
13	845		
14	64	LLD <sub>95</sub>	ND
15	64	LLD <sub>95</sub>	ND
16	58	LLD <sub>95</sub>	ND

Prior to final cleaning

After final cleaning

Swipe Area

17	44	LLD <sub>95</sub>	ND
18	62	LLD <sub>95</sub>	ND
19			

$$LLD_{95} = \left\{ \left( \frac{\sqrt{48}}{7} \right) \times 2.96 \right\} + \sqrt{69} \text{ CPM}$$

BACKGROUND 48±4 n=4  
 STANDARD (0.168, 0.161 <sup>14</sup>C) 13,403 CPM  
 INSTRUMENT 2000/44-9  
 SERIAL NO. 83810/70878

3.6% eff

COMMENTS: ND\* = LLD<sub>95</sub> NOT Determined  
 Activity Calc. DPM/60s = DPS = 1Bq x

$$\frac{100 \text{ CM}^2}{20 \text{ CM}^2} = \left( \frac{\text{DPM}}{60} \right) 5 = \text{Bq}/100 \text{ CM}^2$$

J.A. Mann  
 RADIATION SPCL.


2-9-99  
 DATE

NHEERL-WED  
**RADIATION AREA SURVEY**  
*Fixed Contamination*

LOG NO. 99-4

DATE 2-4-99

LOCATION MAIN BLDG ROOM 232B



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	50	LLD <sub>95</sub>	ND*
2	2366	694	58
3	5968	750	63
4	1256	1250	104
5	54	LLD <sub>95</sub>	ND
6	50		
7	52		
8	58		
9	66	694	58
10	60	LLD <sub>95</sub>	ND
11	46		
12	54		
13	34		
14	60		
15	54		
16	54		
17	42		
18	52		
19	48		
20	34		
21	40		
22	42		
23	38		
24	40		
25	52		
26	54		
27	50		
28	56		
29	46		
30	46		

Sink area

floor x sim

$$LLD_{95} = \left\{ \left( \frac{41}{1} \right) \times 2.96 \right\} / 1.4 = 60 \text{ CPM}$$

BACKGROUND 41 CPM  
 STANDARD (<sup>14</sup>C 0.168 μCi) 13299 CPM 3.6%  
 INSTRUMENT 2000/44-9 Panache  
 SERIAL NO. 83810/10878

COMMENTS:

\*ND = less than lower limit of detection, not determined.

[Signature]  
 RADIATION SPCL.

2-4-99  
 DATE

Over vent hose 46 LLD<sub>95</sub> ND  
 6L vent hose 40 LLD<sub>95</sub> ND

$$(LPM/60) \times 5 = Bq$$

12-vent  
 13-vent  
 14-vent  
 15-vent  
 16-vent  
 17-vent  
 18-vent  
 19-vent  
 20-vent  
 21-vent  
 22-vent  
 23-vent  
 24-vent  
 25-vent  
 26-vent  
 27-vent  
 28-vent  
 29-vent  
 30-vent


NHEERL-WED  
RADIATION AREA SURVEY  
*Removable Contamination*

LOG NO. \_\_\_\_\_

DATE 2-4-99

LOCATION MAIN BLDG ROOM 232B

§ 14C



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	13	<LLD <sub>95</sub>	ND
2	19	9	0.15
3	14	<LLD <sub>95</sub>	ND
4	12		
5	11		
6	11		
7	13		
8	14		
9	13		
10	16		
11	12		
12	14		
13	15		
14	12		
15	14		
16	18	✓	✓
17	*27	22	0.37
18	17	<LLD <sub>95</sub>	ND
19	*20	10	0.16
20	16	<LLD <sub>95</sub>	ND
21	14	✓	✓
22	15		
23	14		
24	11		
25	11		
26	9		
27	14		
28	12		
29	12		
30	13	✓	✓

$$LLD_{95} = \left\{ \left( \frac{\sqrt{5 \times 13}}{5} \right) \times 2.96 \right\} + = 18 \text{ CPM}$$

BACKGROUND 130pm. (200ppm)  
STANDARD (1°C 54K 7/16) 85,272  
INSTRUMENT Packard 7200 36755  
SERIAL NO. 36755

COMMENTS: \*ND = NOT Determined. ≤ LLD<sub>95</sub>.

All swipes < 1.6 Bq/100 cm<sup>2</sup>

RADIATION SPCL. \_\_\_\_\_

DATE \_\_\_\_\_

NHEERL-WED  
RADIATION AREA SURV

DATE \_\_\_\_\_

LOCATION MAIN BLDG ROOM 232B

3H

*See Attached Map*

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	24	0	0
2	1	Quo <sub>r</sub>	ND*
3	4	10	0.17
4	2	0	0
5	3	11	0.18
6	1	Quo <sub>r</sub>	ND
7	2	0	0
8	3	0	0
9	1	Quo <sub>r</sub>	ND
10	1	Quo <sub>r</sub>	ND
11	3	10	0.17
12	3	5	0.08
13	1	Quo <sub>r</sub>	ND
14	2	0	0
15	4	11	0.18
16	6	36	0.60
17	5	0	0
18	3	0	0
19	6	33	0.55
20	3	4	0.06
21	1	Quo <sub>r</sub>	ND
22	3	5	0.08
23	2	0	0
24	3	10	0.17
25	3	6	0.10
26	5	33	0.55
27	3	4	0.06
28	2	1	0.02
29	3	3	0.05
30	1	Quo <sub>r</sub>	ND

$$LLD_{95} = \left\{ \left( \frac{\sqrt{1.5}}{5} \right) \times 2.96 \right\} + 1 = 2 \text{ CPM}$$

BACKGROUND 1.0cpm (0 dpm)  
STANDARD (B502dpm 479) 79361.6  
INSTRUMENT 2000CA Packard  
SERIAL NO. 36755

COMMENTS: \* ND = NOT DETERMINED = < LLD<sub>95</sub>.  
All swipes < 1.6 Bq/100cm<sup>2</sup>

RADIATION SPCL. \_\_\_\_\_


DATE \_\_\_\_\_

NHEERL-WED  
RADIATION AREA SURVEY

LOG NO. 96-221/4  
232

DATE 10/3/96

LOCATION MAIN BLDG ROOM 232B



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
2	14	LLD <sub>95</sub>	0 net
3	22	'	0 net
4	29	100	1.7

LLD<sub>95</sub> =  $\left\{ \left( \frac{\sqrt{50}}{2} \right) \times 2.96 \right\}^{25} = 3.6 \text{ CPM}$

BACKGROUND (#1) 25 CPM

STANDARD (NEN 8400 M) 85,563

INSTRUMENT Package 2700

SERIAL NO. 036755

COMMENTS:

John A. Moran  
RADIATION SPCL.

10/3/96  
DATE

U.S. EPA  
ENVIRONMENTAL RESEARCH LABORATORY - CORVALLIS

Log No. 92-21  
1/2

RADIATION CONTAMINATION SURVEY

Date: 11-4-92 Type of Survey: Removable Contamination

Isotope(s): β

Gross Background Counts: 43 ± CPM Total Count Time (min.): 1

Lower Limits of Detection:  $\sqrt{43}/1 \times 2.96 = \textcircled{19.4}$  CPM

Instrument Used:  GFPC  LSC  GM  Ion Chamber  Scintillation Model: GTC 7358 / 83810 S/N: \_\_\_\_\_

Background: \_\_\_\_\_ CPM±SD \_\_\_\_\_ DPM±SD Standard (<sup>14</sup>C 0.168/di 149605 dpm / 372960 40% <sup>210</sup>Pb)

Swipe No.	Room No.	Swipe Description	Nuclide: _____ per 100 cm <sup>2</sup>			Nuclide: _____ per 100 cm <sup>2</sup>		
			CPM±SD	Net DPM	Net Activity	CPM±SD	Net DPM	Net Activity
1	130	130 door	3	LD <sub>25</sub>	8 net			
		N Counter	0					
		Desk	11					
		S. Counter	0					
5		Hood	0					
		Floor ft. Hood	0					
	170	Door	14					
		floor	3					
		floor	0					
		S. Counter	0					
		phone	1					
		desk	7					
	230	Door	6					
		s. Hood	0					
		N. hood	0					
		floor by N. Hood	0					
	232	Instrument Room	2					
		floor	0					
		desk	1					
		phone	3	✓	✓			

Comments:

Shed - Mann, 11-6-92  
Radiation Safety Date

U.S. EPA  
ENVIRONMENTAL RESEARCH LABORATORY - CORVALLIS

Log No. 92-13

RADIATION CONTAMINATION SURVEY

Date: 6-5-92 Type of Survey: Removable Contamination

Isotope(s): <sup>14</sup>C <sup>51</sup>Cr <sup>3</sup>H

Gross Background Counts: 76 ± CPM Total Count Time (min.): 2

Lower Limits of Detection:  $(\sqrt{76/2}) \cdot 3 = 13 \text{ CPM}$  = cpm

Instrument Used:  GFPC  LSC  GM  Ion Chamber  Scintillation Model: Packard 2200c SIN: 036755

Background: CPM ± SD DPM ± SD Standard (<sup>14</sup>C) 84,000 DPM =  $\frac{84,280}{84,000}$  100% off

Swipe No.	Room No.	Swipe Description	Nuclide: _____ per 100 cm <sup>2</sup>			Nuclide: _____ per 100 cm <sup>2</sup>		
			CPM ± SD net	Net DPM	Net Activity	CPM ± SD	Net DPM	Net Acti
2	130	Hood ssth	Ø	Ø	Ø			
		Sill	Ø	Ø	Ø			
		Floor (hood)	Ø	Ø	Ø			
5		Floor center	Ø	Ø	Ø			
		N counter	Ø	Ø	Ø			
		desk	Ø	Ø	Ø			
		phone	Ø	Ø	Ø			
-		door	Ø	Ø	Ø			
10	236	<del>B</del> S. Hood sill	Ø	Ø	Ø			
		Floor (S)	Ø	Ø	Ø			
		Floor (s)	Ø	Ø	Ø			
		N. Hood sill	Ø	Ø	Ø			
		FLOOR	Ø	Ø	Ø			
15	236 232	Floor	Ø	Ø	Ø			
		Desk	Ø	Ø	Ø			
		Phone	Ø	Ø	Ø			
		door	Ø	Ø	Ø			✓
20	256	LSC	Ø	Ø	Ø			
		Door	Ø	Ø	Ø			✓

Comments:

Chris A. Moran Date 6/17/92  
Radiation Safety



**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 236 Final Contamination Survey.**

Description and Historic Use:

Double lab (450 ft<sup>2</sup>). Hydrogen-3 and carbon-14 tracers, and nickel-63 sealed sources. This room was decommissioned as an unrestricted area on April 22, 1999. No isotope use since 1999. There is no record of leakage of any sealed sources used in this area.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in MB 236 at the time of restricted use decommissioning. The decommissioning records are enclosed. All points surveyed demonstrated no significant contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of MB 236 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.

**DYNAMAC**  
**CORPORATION**

Environmental Services

200 SW 35th Street  
Corvallis, OR 97333

Telephone: (541) 754-4844

Fax: (541) 754-4818

*OK  
4/22/99*

MEMO

To: Jay Gile, NHEERL RSO  
From: Phil Monaco, Dynamac  
Date: April 22, 1999

Subject: Decommissioning Survey of MB 236

The Main Building lab room 236 was surveyed for fixed and removable radioactive contamination. Ninety-two 20cm spots were surveyed for fixed contamination. Only two spots surveyed revealed fixed contamination. Both these spots are located in the northeast hood and measured 360 and 600 Bq/100 cm<sup>2</sup>.

Eighty-one wet swipes were taken for removable contamination and analyzed for tritium and <sup>14</sup>C. Nine swipes demonstrated activity above the detection limits for either tritium or <sup>14</sup>C. Of these nine swipes, four demonstrated contamination by tritium above the action level (>1.6 Bq/100 cm<sup>2</sup>): three in the northeast hood (and one on the dark room floor). However, only one on the swipes was greater than 5 cpm above the lower limits of detection -- a hood swipe (12.9 Bq/100 cm<sup>2</sup>). No removable <sup>14</sup>C contamination was detected above the action level.

**Recommendations:**


First, I recommend that, even though the contamination is extremely low if not a phantom, the floor area in the dark room be cleaned and further swiped.

Second, given the semi-porous nature of the material the northeast hood is constructed from, cleaning will not be efficient in removing contamination. Therefore, it should go on record that an area of the hood (see attached) is permanently contaminated and should be posted and treated as such during future maintenance operations.

Records of these surveys were logged as 99-9, 99-10, and 99-11, and placed on file in MB 190.

If you have any questions, please contact me.

Attachment (1)



CONTAMINATED  
AREA  
(FLOOR & BACK panel)

Protocol #: 28 N( ): 14C. RadSafety <sup>22</sup> Apr-99 11:43  
 Region A: LL-UL= 0.0-156. Lcr= 0 Bkg= 0.00 %2 Sigma=1.00  
 Region B: LL-UL= 4.0-156. Lcr= 0 Bkg= 0.00 %2 Sigma=1.00  
 Region C: LL-UL= 0.0- 0.0 Lcr= 0 Bkg= 0.00 %2 Sigma=0.00  
 Time = 5.00 QIP = tSIE ES Terminator = Count

14C. QuenchCurve  
 Conventional DPM  
 Nuclide 1 = 113700  
 Luminescence Correction On

14C

S#	TIME	CPMA	DPM1	A:25%	CPMB	B:25%	SIS	tSIE	FLAG	LUM
1	5.00	18.00	18.83	22.66	16.20	22.22	120.71	977.	12	Blank
2	1.24	50906.5	53111.9	0.79	32417.7	0.99	19.500	895.	0	
3	0.52	80163.5	83922.9	0.98	78057.7	0.99	166.42	1004	0	14C syrook
(9 missing vials)										
13	5.00	19.40	23.12	26.32	16.80	21.82	88.190	197.	25	Blank
14	5.00	20.80	25.16	23.39	16.00	22.36	83.270	185.	15	#1
15	5.00	20.60	24.75	22.89	17.20	21.56	76.490	190.	15	#2
(15 missing vials)										
31	5.00	434.20	458.53	4.31	380.20	4.58	93.350	609.	0	
32	5.00	1594.20	1693.04	2.24	1207.20	2.57	68.270	584.	0	
33	5.00	7934.00	8411.01	1.01	4584.40	1.32	27.210	592.	1	
34	5.00	124.60	133.97	8.11	117.80	8.24	103.12	537.	1	
35	5.00	1096.60	1162.84	2.70	1048.60	2.76	109.60	591.	0	
36	4.38	9505.02	10110.2	0.98	9139.50	0.99	110.21	578.	0	
37	0.49	86036.7	91516.3	0.97	82836.7	0.99	109.87	578.	0	

$$LLD_{95} = \left( \frac{\sqrt{100}}{5} \right) 2.96 + 20 = 25 \text{ cpm}$$

Swipe #1 20.8 cpm < LLD<sub>95</sub>  $\frac{\text{Activity}}{\text{NOT DETERMINED}}$   
 Swipe #2 20.6 < LLD<sub>95</sub> NOT DETERMINED

Lab 236 Dark Room Reswipe of Floor Area  
 etc

PA. Manac

Protocol #: 27      N: ( ) : 3H. RadSafety      22  
 1-Apr-99      12:45  
 Region A: LL-UL= 0.0-18.6    Lcr= 0    Bkg= 0.00    %2-Sigma=1.00  
 Region B: LL-UL= 2.0-18.6    Lcr= 0    Bkg= 0.00    %2-Sigma=1.00  
 Region C: LL-UL= 0.0- 0.0    Lcr= 0    Bkg= 0.00    %2-Sigma=0.00  
 Time = 2.00      QIP = tSIE      ES Terminator = Count  
 Tritium, Std. curve generated by mean of 3 cts  
 Conventional DPM  
 Nuclide 1 = 139236  
 Luminescence Correction On

3H

S#	TIME	CPMA	DPM1	A:25%	CPMB	B:25%	SIS	tSIE	FLAG	LUM
1	2.00	11.50	18.94	51.44	10.50	49.48	21.630	968.		4
2	0.79	50887.3	87489.5	1.00	45898.7	1.05	19.230	893.		0
3	2.00	16563.0	26803.8	1.10	16060.0	1.11	33.160	1000	E	0
(9 missing vials)										
13	2.00	8.00	42.87	66.14	8.00	53.03	30.490	196.		26
14	2.00	9.50	54.49	58.60	9.50	50.48	26.100	185.		41
15	2.00	12.00	66.62	50.00	10.00	46.90	24.670	190.		15
(15 missing vials)										
31	2.00	173.00	348.81	10.96	159.50	11.30	25.380	607.		1
32	2.00	976.50	2012.65	4.56	883.50	4.76	20.530	583.		1
33	2.00	7300.00	14966.7	1.66	6387.50	1.77	16.540	589.		1
34	2.00	53.50	116.14	20.39	49.50	20.50	32.980	534.		2
35	2.00	334.50	684.51	7.82	328.50	7.83	33.660	591.		1
36	2.00	2996.00	6200.52	2.59	2915.00	2.62	33.350	579.		0
37	1.53	26224.2	54056.5	1.00	25505.9	1.01	33.240	583.		0

BLANK ✓  
3H 85000k

26 Bkbrd  
41 #1  
15 #2

LLD<sub>95</sub> =

$$\left( \frac{\sqrt{16}}{2} \right) 2.96 + 8 = 14 \text{ CPM}$$

Swipe # 1    9.5 CPM    < LLD<sub>95</sub>

Swipe # 2    12.0    < LLD<sub>95</sub>

Activity

NOT DETERMINED

NOT DETERMINED

Lab 236 Dark Room Reswipes of Floor Area

OK

O.A. Monaco


NHEERL-WED  
**RADIATION AREA SURVEY**  
REMOVABLE CONTAMINATION

LOG NO. 99-10  
 1/3

DATE 4-20-99

LOCATION MAIN BLDG ROOM 236

3H



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	8.5	<LLD <sub>25</sub>	ND*
2	12	✓	✓
3	11		
4	14		
5	9		
6	1.7		
7	13		
8	14		
9	17		
10	14		
11	16		
12	12		
13	14		
14	10		
15	10		
16	15		
17	13		
18	19		
19	16		
20	21		
21	11		
22	17		
23	9		
24	11		
25	10		
26	15		
27	16	✓	✓
	<del>17</del>		

cab  
F2nT3  
sill

$LLD_{95} = \left\{ \left( \frac{\sqrt{28}}{2} \right) \times 2.96 \right\} = 22 \text{ CPM}$

BACKGROUND 14 CPM  
 STANDARD (3H 85,543 dpm) 85,543 dpm ✓  
 INSTRUMENT Packard 2200CA  
 SERIAL NO. 036755

COMMENTS: ND\* = NOT DETERMINED. <LOWER Limits of Detection.  
 \*\* Actim Level 1.7 Bq/100 cm<sup>2</sup>.

[Signature]  
 RADIATION SPCL:


4-22-99  
 DATE

# NHEERL-WED RADIATION AREA SURVEY

2/3

DATE 4-20-97

LOCATION MAIN BLDG ROOM 236



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
28	14	<LLD <sub>95</sub>	ND*
29	24	224	(3.7)
30	24	224	(3.7)
31	15	<LLD <sub>95</sub>	ND*
32	57	772	(12.9)
33	21	<LLD <sub>95</sub>	ND*
34	15	✓	✓
35	14		
36	13		
37	11		
38	16		
39	11		
40	13		
41	19		
42	17		
43	17		
44	14		
45	18		
46	16		
47	14		
48	13		
49	13		
50	13		
51	11		
52	14		
53	16		
54	14	✓	✓
55	11	✓	✓

HOOD SWIPES  
SILL  
CAB FRONT

$$LLD_{95} = \left\{ \left( \sqrt{\quad} \right) \times 2.96 \right\} + \quad = \quad \text{CPM}$$

BACKGROUND STANDARD ( \_\_\_\_\_ ) \_\_\_\_\_  
INSTRUMENT SERIAL NO. \_\_\_\_\_

COMMENTS


RADIATION LEVEL

DATE

NHEERL-WED  
RADIATION AREA SURVEY

DATE 4-20-99

LOCATION MAIN BLDG ROOM 236



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
56	14	LLD <sub>95</sub>	ND*
57	14	↓	↓
58	12	↓	↓
59	16	↓	↓
60	16	↓	↓
61	13	↓	↓
62	12	↓	↓
63	22	↓	↓
64	14	↓	↓
65	16	↓	↓
66	19	↓	↓
67	21	↓	↓
68	15	↓	↓
69	12	↓	↓
70	12	↓	↓
71	12	↓	↓
72	24	224	3.7
73	18	LLD <sub>95</sub>	ND*
74	13	↓	↓
75	16	↓	↓
76	9	↓	↓
77	15	↓	↓
78	17	↓	↓
79	12	↓	↓
80	9	↓	↓
81	14	↓	↓

ON Back

$$LLD_{95} = \left\{ \left( \sqrt{\quad} \right) \times 2.96 \right\} + \quad = \text{CPM}$$


BACKGROUND STANDARD (INSTRUMENT SERIAL NO. \_\_\_\_\_)

COMMENTS:

RADIATION SPCL: \_\_\_\_\_

DATE \_\_\_\_\_






RADIATION AREA SURV  
REMOVABLE CONTAMINATION

DATE 4-20-99

LOCATION MAIN BLDG ROOM 236

14C



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	23	<LD <sub>95</sub>	ND*
2	18		
3	18		
4	23		
5	20		
6	20		
7	22		
8	22		
9	22		
10	22		
11	24		
12	22		
13	24		
14	17		
15	24		
16	21		
17	23		
18	24		
19	19		
20	24		
21	21		
22	19		
23	24		
24	21		
25	25		
26	23		
27	18		

cab  
F2nTS  
SILL

$$LD_{95} = \left\{ \left( \frac{\sqrt{102}}{5} \right) \times 2.95 \right\} + 26 \text{ CPM}$$

BACKGROUND STANDARD (1°C 84,000 dpm) 20.4 CPM (27 dpm)  
 INSTRUMENT Packard 2200CA 83,085 dpm V  
 SERIAL NO. 036755

COMMENTS: See PAGE 2

D. A. M.  
 RADIATION SPCL. DATE 4-22-99


INTERVIEWED  
**RADIATION AREA SURV**

LOG NO. \_\_\_\_\_

2/3

DATE 4-20-99

LOCATION MAIN BLDG ROOM 236



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
28	19	LLD <sub>95</sub>	ND*
29	36	22	0.37
30	28	11	0.18
31	24	LLD <sub>95</sub>	ND*
32	69	69	1.2
33	22	LLD <sub>95</sub>	ND*
34	27	10	0.16
35	27	10	0.16
36	23	LLD <sub>95</sub>	ND*
37	23		
38	23		
39	20		
40	19		
41	23		
42	22		
43	19		
44	18		
45	19		
46	21		
47	19		
48	24		
49	23		
50	24		
51	22		
52	20		
53	22		
54	21		
55	23		

cab front

$$LLD_{95} = \left\{ \left( \sqrt{\quad} \right) \times 2.96 \right\} + \quad \text{CPM}$$

BACKGROUND STANDARD (INSTRUMENT SERIAL NO. \_\_\_\_\_)

COMMENTS: \* ND = NOT DETERMINED. < Lower Limits of DETECTION.  
\*\* Action Level is 1.7 Bq/100cm<sup>2</sup>.

Phil A. Moore  
RADIATION SPCL.


4-22-99  
DATE

UNRECORDED  
**RADIATION AREA SURVEY**

3/3

DATE 4-20-99

LOCATION MAIN BLDG ROOM 236



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
56	21	LLD <sub>95</sub>	ND*
57	22	✓	✓
58	24	✓	✓
59	24	✓	✓
60	21	✓	✓
61	22	✓	✓
62	20	✓	✓
63	25	✓	✓
64	21	✓	✓
65	21	✓	✓
66	21	✓	✓
67	21	✓	✓
68	21	✓	✓
69	19	✓	✓
70	23	✓	✓
71	23	✓	✓
72	23	✓	✓
73	21	✓	✓
74	25	✓	✓
75	19	✓	✓
76	22	✓	✓
77	21	✓	✓
78	21	✓	✓
79	23	✓	✓
80	18	✓	✓
81	21	✓	✓

ON Back


$$LLD_{95} = \left\{ \left( \sqrt{\quad} \right) \times 2.96 \right\} + \quad = \quad \text{CPM}$$

BACKGROUND STANDARD (INSTRUMENT SERIAL NO. \_\_\_\_\_)

- N  
COMMENTS:

RADIATION SPCL: \_\_\_\_\_

DATE \_\_\_\_\_




NHEERL-WED  
RADIATION AREA SURVEY  
FIXED CONTAMINATION

LOG NO. 99-9  
1/4

DATE 4-15-99

LOCATION MAIN BLDG ROOM 236

MAP on BACK Dark Room



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	80	LLDS	ND*
2	66		
3	54		
4	52		
5	72		
6	66		
7	48		
8	54		
9	54		
10	32		
11	38		
12	38		
13	70		
14	62		

LLD<sub>95</sub> = { (  $\frac{\sqrt{21}}{0.5}$  ) X 2.96 } + =  $\frac{96}{x2} = 96$  CPM

BACKGROUND 47 CPM  
STANDARD (0.165<sup>14</sup>C) 12743 CPM  
INSTRUMENT Ludlum 2000  
SERIAL NO. 83810


\* 3.4% off.

COMMENTS: \* ND = NOT Determined. < Lower Limits of Detection.

D.A. Man  
RADIATION SPCL.

4-20-99  
DATE

Dark Room  
236




NHEERL-WED  
RADIATION AREA SURVEY

2/4

DATE 4-14-99

LOCATION MAIN BLDG ROOM 236

t=0.5'



SWPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	58	<LLD <sub>95</sub>	ND
2	50		
3	48		
4	48		
5	52		
6	48		
7	40		
8	54		
9	42		
10	52		
11	60		
12	60		
13	36		
14	42		
15	30		
16	48		
17	50		
18	40		
19	38		
20	48		
21	48		
22	52		
23	48		
24	38		
25	48		
26	48		
27	46		
28	52		

Cabinet face

$$LLD_{95} = \left( \frac{\sqrt{2.96}}{2.96} \right) \times 2.96 \times 53 = 106 \text{ CPM}$$

BACKGROUND STANDARD (MC 0.164 uCi) 48 CPM  
 INSTRUMENT Ludlum 2000  
 SERIAL NO. 83810

3.4% eff.

COMMENTS: \* NDE = NOT Determined < Lower Limit of Detection @

B.A. M...  
RADIATION SPCL.

4-20-99  
DATE




NHEERL-WED  
RADIATION AREA SURVEY  
Fixed

LOG NO. 99-

3/4

DATE 4-19-99

LOCATION MAIN BLDG ROOM 236



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>	
1	28	LUDR	ND†	
2	40	↓	↓	Side
3	292	<del>4294 dpm</del> 7235 dpm	120 Bq x 5 =	(300 Bq)
4	58	LUDR	ND	
5	32	↓	↓	
6	36	↓	↓	side
7	38	↓	↓	side
8	40	↓	↓	S Back
9	32	↓	↓	side
10	34	↓	↓	
11	26	↓	↓	
12	192	4294 dpm	72 Bq	N Back
13	34	LUDR	ND	(360 Bq)
14	38	↓	↓	
15	36	↓	↓	
16	40	↓	↓	
17	30	↓	↓	
18	28	↓	↓	
19	48	↓	↓	
20	50	↓	↓	
21	46	↓	↓	
22	52	↓	↓	

$$LLD_{95} = \left\{ \left( \frac{\sqrt{23}}{0.5} \right) \times 2.96 \right\} + \dots = \text{CPM}$$

x 2. = 103 CPM

BACKGROUND ~~46~~ 46 CPM  
STANDARD (1% 0.68) 12.658 CPM  
INSTRUMENT Ludlum 2000  
SERIAL NO. 83810

COMMENTS: † ND = NOT DETERMINED. < Lower Limit of detection

Conversion to 100 cm<sup>2</sup> = (x.5)

J.A. Mann  
RADIATION SPCL.

4-20-99  
DATE

NHEERL-WED  
RADIATION AREA SURVEY


LOG NO. 99

4/4

DATE 4-19-99

Fixed

LOCATION MAIN BLDG ROOM 236



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
---------	-----------	---------	---------------------------------

1	52	LLDS	ND*
2	58		
3	58		
4	48		
5	62		
6	58		
7	48		
8	58		
9	64		
10	50		
11	48		
12	52		
13	56		
14	50		
15	66		
16	40		
17	50		
18	52		
19	64		
20	64		
21	66		
22	54		
23	48		
24	68		
25	68		
26	54		
27	48		
28	50	✓	✓

inside cabinet

cabinet face

cabinet face

$$LLD_{95} = \left\{ \left( \frac{\sqrt{23}}{0.5} \right) \times 2.95 \right\} + \dots = 103 \text{ CPM}$$

BACKGROUND 46 CPM  
STANDARD (14C 0.168 μCi) 12,698 CPM  
INSTRUMENT Ludlum 2000  
SERIAL NO. 83810

COMMENTS: ND\* = NOT DETERMINED. (Lower Limits OF DETECTION)

GA. Muma  
RADIATION SPCL.

4-20-99  
DATE

← N

**interoffice**  
M E M O R A N D U M

---

**To:** Mr Gile  
**From:** Joel McCrady *Jm*  
**Date:** Apr 12, 1999  
**Subject:** Radiation Safety

A thorough examination of Laboratory 236, Main EPA building, has been conducted. Inclosed are radioactive swipes for your records. There is no radioactive waste, samples, or standards located in Lab 236 (zero micro-curies). Do not hesitate to call on me for additional assistance. Do you require a urine sample or any additional information for your official records? You can expect my full cooperation, as always.

**CC:** Peter Beedlow  
Jillian Gregg

Region A: LL-UL= 0.0-156. Lcr= 0 Bkg= 0.00 %1 Sigma=1.00  
 Region B: LL-UL= 4.0-156. Lcr= 0 Bkg= 0.00 %2 Sigma=1.00  
 Region C: LL-UL= 0.0- 0.0 Lcr= 0 Bkg= 0.00 %2 Sigma=0.00  
 Time = 5.00 QIP = tSIE ES Terminator = Count

14C.QuenchCurve

Conventional DPM

Nuclide 1 = 113700

Luminescence Correction On

S#	TIME	CPMA	DPM1	A:25%	CPMB	B:25%	SIS	tSIE	FLAG	LUM
1	0.38	108697.	113768.	0.98	105905.	0.99	165.86	997.		0
2	0.38	108826.	113299.	0.98	105384.	0.99	141.86	831.		0
3	0.39	107349.	112195.	0.97	102959.	0.99	115.79	664.		0
4	0.41	105446.	114257.	0.96	99975.6	0.98	89.940	507.		0
5	0.42	103317.	113678.	0.96	96402.4	0.99	71.590	400.		0
6	0.43	102360.	114070.	0.95	93244.2	0.99	57.170	312.		0
7	0.47	98287.2	113172.	0.93	86657.4	0.99	44.200	233.		0
8	0.52	92948.1	112838.	0.91	78163.5	0.99	34.990	181.		0
9	0.55	91350.9	114932.	0.89	72980.0	0.99	29.120	145.		0
10	0.63	86312.7	114263.	0.85	63728.6	0.99	24.350	118.	E	0
Blank 11	5.00	22.00	23.00	20.40	19.00	20.51	93.730	956.		8
STD 12	0.52	80357.7	84090.4	0.97	78115.4	0.99	164.99	991.		0
13	5.00	30.60	35.78	17.29	27.00	17.21	95.900	216.		5
14	5.00	28.20	32.94	18.22	24.20	18.18	100.87	217.		6
15	5.00	27.00	31.59	18.91	22.40	18.89	91.080	215.		6
16	5.00	22.80	27.00	20.00	18.40	20.85	107.04	203.		5
17	5.00	27.40	32.52	18.63	24.60	18.03	124.83	201.		8
18	5.00	30.80	36.37	17.42	22.60	18.81	89.520	206.		6
19	5.00	28.20	33.25	18.33	23.20	18.56	106.70	207.		7
20	5.00	24.00	28.30	20.13	21.40	19.33	132.14	207.		10
21	5.00	25.80	30.43	18.66	21.40	19.33	114.88	207.		4
22	5.00	27.20	32.17	19.06	21.40	19.33	92.450	204.		11

700 dpm

Blank

STD

swipe

- 13 - Blank swipe
- 14 - Rad Refrigerator - outside
- 15 - S. Hood, 236, Sill
- 16 - Sink, 236
- 17 - Sink, 232
- 18 - N. Hood, Sill
- 19 - Floor, front of S. Hood
- 20 - Floor, front of Rad. ReFrig.
- 21 - Blank swipe
- 22 - Floor, 232

12 Apr 99

Protocol #:27 N<sub>0</sub>:3H.RadSafety  
Region A: LL-UL= 0.0-1.6 Lcr= 0 Bkg= 0.00 %1 Sigma=1.00  
Region B: LL-UL= 2.0-18.6 Lcr= 0 Bkg= 0.00 %2 Sigma=1.00  
Region C: LL-UL= 0.0- 0.0 Lcr= 0 Bkg= 0.00 %2 Sigma=0.00  
Time = 5.00 QIP = tSIE ES Terminator = Count

Tritium, Std. curve generated by mean of 3 cts  
Conventional DPM  
Nuclide 1 = 139236  
Luminescence Correction On

S#	TIME	CPMA	DPM1	A:25%	CPMB	B:25%	SIS	tSIE	FLAG	LUM
1	0.48	84145.8	137877.	0.99	76941.7	1.04	20.420	978.		0
2	0.52	77571.2	141470.	0.99	68646.2	1.05	17.640	788.		0
3	0.57	70112.3	138998.	1.00	59591.2	1.08	15.260	627.		0
4	0.68	58898.5	139592.	1.00	47061.8	1.11	12.880	468.		0
5	0.81	49544.5	139401.	1.00	36972.8	1.15	11.320	371.		1
6	1.01	39570.3	139516.	1.00	26465.4	1.22	9.950	286.		1
7	1.36	29287.5	139975.	1.00	17036.8	1.31	8.750	216.		1
8	1.84	21665.2	139476.	1.00	10895.1	1.41	7.960	168.		1
9	2.48	16073.4	139915.	1.00	6949.19	1.52	7.380	136.		1
10	3.30	12047.9	140443.	1.01	4465.15	1.64	6.920	112.	E	1
11	5.00	14.60	24.01	26.98	13.80	25.10	21.940	971.		15
12	0.79	50905.1	88246.2	1.00	45876.0	1.05	19.030	879.		0
13	5.00	14.00	69.04	27.70	13.20	25.71	24.900	210.		13
14	5.00	12.00	58.87	30.91	10.80	28.68	26.420	211.		16
15	5.00	15.80	78.75	25.44	14.20	24.71	27.040	208.		11
16	5.00	16.40	86.85	24.14	16.20	23.03	25.710	198.		13
17	5.00	16.40	92.14	25.34	15.20	23.82	27.510	188.		10
18	5.00	19.60	105.73	22.54	18.20	21.64	24.580	195.		6
19	5.00	13.00	67.85	28.36	11.40	27.85	19.300	200.		9
20	5.00	17.00	89.46	25.66	15.60	23.50	23.940	199.		15
21	5.00	14.80	78.53	26.75	14.60	24.35	24.890	197.		13
22	5.00	11.40	59.22	31.18	10.20	29.60	26.860	201.		13

See Swipe log on <sup>14</sup>C Swipes

Protocol # = 28  
Protocol Name? 14C.RadSafety

Count Time? 5.00  
2 Sigma Coincidence? yes

Radionuclide? 14C

	LL	UL	Bkg	2 Sigma%	LCR
Region A:	0.0	156.	0.00	1.0	0
Region B:	4.0	156.	0.00	1.0	0
Region C:	0.0	0.0	0.00	.00	0

Protocol # = 27  
Protocol Name? 3H.RadSafety  
Cycles? 1  
Count Time? 5.00  
2 Sigma Coincidence? no  
# Counts/Vial? 1  
# Vials/Standard? 1  
1st Vial Background? no  
Radionuclide? 3H

Copy Protocol #? no  
# Vials/Sample? 1

	LL	UL	Bkg	2 Sigma%	LCR
Region A:	0.0	18.6	0.00	1.0	0
Region B:	2.0	18.6	0.00	1.0	0
Region C:	0.0	0.0	0.00	.00	0


Qip? tSIE  
% of Reference? no  
Data Mode? dpm

ES Terminator? count

NHEERL-WED  
RADIATION AREA SURVEY

DATE 10/30/96

LOCATION MAIN BLDG ROOM 236



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>	
①	100	ND	0 net	10/30/96
②	100	ND	0 net	10/30/96
B	100	ND	0 net	10/30/96
1	100	ND	0 net	10/31/96
2	100	ND	0 net	10/31/96
3	100	ND	0 net	10/31/96
B	100	ND	0 net	10/31/96
①	100	ND	0 net	11-4-96
②	100	ND	0 net	11-4-96
③	100	ND	0 net	11-4-96
B	100	ND	0 net	11-4-96
①	70	ND	0 net	11-5-96
②	70	ND	0 net	11-5-96
③	70	ND	0 net	11-5-96
B	70	ND	0 net	11-5-96
①	70	ND	0 net	11-6-96
②	70	ND	0 net	11-6-96
③	70	ND	0 net	11-6-96
B	70	ND	0 net	11-6-96
①	70	ND	0 net	11/7/96
②	70	ND	0 net	11/7/96
③	70	ND	0 net	11/7/96
B	70	ND	0 net	11/7/96
1	70	ND	0 net	11-12-96
2	70	ND	0 net	11-12-96
3	70	ND	0 net	11-12-96
B	70	ND	0 net	11-12-96

$$LLD_{95} = \left\{ \left( \frac{\sqrt{100}}{1} \right) \times 2.96 \right\} \div 100 = 130 \text{ CPM}$$

BACKGROUND 100 CPM  
 STANDARD (<sup>137</sup>Cs Inti) 9500  
 INSTRUMENT Ludlum #3  
 SERIAL NO. 77146

\*ND = NOT Detectable

COMMENTS:

D.J. Moore  
 RADIATION SPCL.

11-12-96  
 DATE

← N

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 246 Final Contamination Survey.**

Description and Historic Use:

Double Lab (450 ft<sup>2</sup>). Hydrogen-3 and carbon-14 tracers, and nickel-63 sealed sources. Used for radioactive materials handling in 2004. There is no record of leakage of any sealed sources used in this area.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in MB 246 in November 2004. All points surveyed (46 total and 60 removable) demonstrated no significant contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. A HVAC duct swipe was made in November 2004 which detected no contamination.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of MB 246 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.



NHEERL-WED  
RADIATION AREA SURVEY  
Removable


LOG NO. 04-21

1/2

DATE 8-11-04

LOCATION ~~338~~

ROOM 246



SWIPE #	GROSS CPM	NET DPM	ACTIVITY - Bq/100 CM <sup>2</sup>
1	Back	LLD <sub>95</sub>	ND*
2	Back	LLD <sub>95</sub>	
3	Side 32		
4	Side 33		
5	SAS 437		
6	SAS 435		
7	SILL 39		
8	SILL 36		
9	Floor 37		
10	Floor 32		
11	Floor 35		
12	Floor 35		
13	Floor 38		
14	Floor 35		
15	Floor 32		
16	Floor 35		
17	Floor 36	✓	✓ (0.9 pCi)
18	Count 43	2	3.3 x 10 <sup>-2</sup> Bq
19	Count 36	LLD <sub>95</sub>	ND*
20	Sink 37		
21	Fix 39		
22	Phone 32		
23	Door 34		
24	Light 40		
25	Floor 36		
26	Cab 30		
27	Floor 38		
28	Count 38	✓	✓
29	Desk 29	✓	41 CPM

$$LLD_{95} = \left\{ \left( \frac{\sqrt{33 \times 5}}{5} \right) \times 2.96 \right\} \pm \text{CPM}$$

BACKGROUND 33 CPM  
STANDARD (<sup>14</sup>C) ≈ 84,000 CPM 513,987 DPM  
INSTRUMENT Packard 2200 CA  
SERIAL NO. 036755

COMMENTS: ND\* NOT DETERMINED  
Below the detection of the instruments.

Cabs  
Floor & Hood  
WALLS  
S. Floor ←

J. M. ...  
RADIATION SPCL.

8-12-04  
DATE

NHEERL-WED  
RADIATION AREA SURVEY  
Removable


LOG NO. 04-21

2/2

DATE 8-1-04

LOCATION 688

ROOM 246



SWPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
30	34	LLD <sub>95</sub>	ND*
31	41	LLD <sub>95</sub>	
32	29		
33	37		
34	40		
35	30		
36	37		
37	39		
38	32		
39	39		
40	38		
41	30		
42	38		
43	40		
44	30		
45	37		
46	32		
47	38		
48	39		
49	38		
50	32		
51	41	LLD <sub>95</sub>	
52	35		
53	45		
54	39		
55	40		
56	40		
57	34		
58	49		4 pli.
59	47		3 pli.
60	35		
LLD <sub>95</sub> = ( $\sqrt{\quad}$ ) X 2.96 } + = CPM			

BACKGROUND STANDARD ( INSTRUMENT SERIAL NO. \_\_\_\_\_ ) \_\_\_\_\_

COMMENTS:

RADIATION SPCL. \_\_\_\_\_

DATE \_\_\_\_\_

Protocol #: 28 Name: 14C.RadSafety 12-Aug-99 10:20  
 Region A: LL-UL= 0.0-156. Lcr= 0 Bkg= 0.00 %2 Sigma=1.00  
 Region B: LL-UL= 4.0-156. Lcr= 0 Bkg= 0.00 %2 Sigma=1.00  
 Region C: LL-UL= 0.0- 0.0 Lcr= 0 Bkg= 0.00 %2 Sigma=0.00  
 Time = 5.00 QIP = tSIE ES Terminator = Count

14C.QuenchCurve  
 Conventional DPM  
 Nuclide 1 = 113700  
 Luminescence Correction On

S#	TIME	CPMA	DPM1	A:25%	CPMB	B:25%	SIS	tSIE	FLAG	LUM
1	5.00	20.40	21.27	21.47	13.20	24.61	69.450	683.	Bkgd/BUC SEALED	
2	2.53	36191.7	38146.0	0.66	15811.9	0.99	14.110	618.	3H STD	0
3	0.52	80621.2	83987.7	0.97	77044.2	0.99	120.54	698.	<sup>14</sup> C STD	0 84,000 dPW
4	5.00	33.00	37.24	16.75	25.80	17.60	92.890	273.		5
(8 missing vials)										
13	5.00	367.60	403.86	4.69	313.40	5.05	71.090	413.		0 148
14	5.00	1273.60	1402.20	2.52	888.40	3.00	53.100	394.	3H STD	0 1216
15	5.00	5221.00	5746.73	1.24	2123.60	1.94	22.750	397.		1 1
(1 missing vial)										
17	5.00	124.80	137.92	8.09	113.40	8.39	74.790	364.		0 121
18	5.00	1046.00	1151.32	2.77	973.20	2.86	76.750	397.	<sup>14</sup> C STD	0 1195
19	5.00	8621.00	9497.25	0.96	8001.40	0.99	75.280	389.		0 11055
20	0.57	76231.6	83980.0	0.96	70975.4	0.99	75.280	389.		0 111
(10 missing vials)										
31	5.00	32.60	36.78	16.59	27.40	17.08	61.560	274.	Bkgd	3
32	5.00	40.80	46.49	14.34	33.00	15.56	59.290	251.		1
33	5.00	37.40	42.64	15.60	30.80	16.11	72.490	250.		3
34	5.00	32.40	37.06	16.56	27.00	17.21	73.120	244.		3
35	5.00	33.00	37.40	16.12	27.60	17.02	70.030	263.		5
36	5.00	38.80	44.25	14.79	31.40	15.96	61.180	250.		1
37	5.00	35.40	41.71	15.53	28.80	16.66	61.380	208.		1
38	5.00	38.60	45.50	14.98	32.20	15.76	76.620	208.		1
39	5.00	35.80	40.90	15.68	28.60	16.72	80.270	246.		2
40	5.00	37.20	43.22	15.35	32.20	15.76	67.780	223.		2
41	5.00	32.40	37.74	16.56	27.40	17.08	56.780	220.		3
42	5.00	35.00	40.58	15.95	30.60	16.16	75.000	225.		4
43	5.00	34.80	39.63	15.76	29.20	16.55	71.890	252.		1
44	5.00	37.80	42.87	15.00	30.20	16.27	70.880	261.		1
45	5.00	35.40	40.26	15.53	27.80	16.96	68.250	255.		1

04  
12-Aug-99 12:45

Protocol #:28      Name:14C.RadSafety

Region A: LL-UL= 0.0-156.    Lcr= 0    Bkg= 0.00    %2 Sigma=1.00

Region B: LL-UL= 4.0-156.    Lcr= 0    Bkg= 0.00    %2 Sigma=1.00

Region C: LL-UL= 0.0- 0.0    Lcr= 0    Bkg= 0.00    %2 Sigma=0.00

Time = 2.00      QIP = tSIE      ES Terminator = Count

14C.QuenchCurve  
Conventional DPM  
Nuclide 1 = 113700  
Luminescence Correction On

S#	TIME	CPMA	DPM1	A:2S%	CPMB	B:2S%	SIS	tSIE	FLAG	LUM
15 46	3.55	32.39	36.70	19.44	28.73	19.80	66.600	264.		3
47	2.00	32.50	36.75	26.28	29.50	26.03	75.060	268.		2
48	2.00	35.50	40.33	25.66	30.50	25.60	74.550	257.		3
49	2.00	42.50	49.05	23.41	36.50	23.40	72.110	230.		4
50	2.00	36.00	43.40	23.57	28.00	26.72	56.620	187.		0
20 51	2.00	36.50	42.20	25.84	33.00	24.61	66.040	228.		4
52	2.00	39.00	44.20	22.64	32.00	24.99	68.500	263.		0
53	2.00	32.00	36.11	27.24	30.50	25.60	89.950	273.		2
54	2.00	34.00	38.68	25.30	30.50	25.60	77.740	254.		3
55	2.00	39.50	44.48	22.50	33.00	24.61	95.040	279.		0
25 56	2.00	26.00	29.69	30.76	21.50	30.49	68.270	247.		4
57	2.00	30.00	34.00	27.48	26.00	27.73	55.420	263.		7
58	2.00	27.50	35.15	30.20	23.00	29.48	74.380	137.		6
59	2.00	32.50	37.74	24.80	27.00	27.21	71.630	223.		0
60	2.00	28.50	32.02	26.49	24.50	28.57	79.400	284.		0
30 61	2.00	33.50	37.79	27.52	26.00	27.73	68.410	274.		6
62	2.00	40.50	45.81	24.56	37.00	23.24	75.730	267.		8
63	2.00	29.00	32.72	26.26	25.00	28.28	77.150	274.		0
64	2.00	37.00	41.73	24.77	31.50	25.19	84.710	275.		3
65	2.00	40.00	45.23	23.97	35.50	23.73	83.070	268.		3
35 66	2.00	29.50	36.57	30.12	22.00	30.15	60.280	159.		10
67	2.00	37.00	44.38	24.77	30.00	25.81	67.360	192.		1
68	2.00	38.50	46.09	25.04	32.50	24.80	65.110	193.		4
69	2.00	32.00	37.10	27.95	26.00	27.73	76.060	225.		5
70	2.00	39.00	47.34	24.32	34.00	24.25	97.490	181.		1
46 71	2.00	37.50	42.65	24.87	31.50	25.19	71.000	255.		3
72	2.00	29.50	33.72	29.35	22.50	29.81	75.890	245.		7
73	2.00	38.00	42.89	24.11	34.50	24.07	91.520	272.		1
74	2.00	39.50	44.86	24.93	33.00	24.61	72.280	258.		5
75	2.00	30.00	34.82	29.81	25.50	28.00	63.580	224.		11
45 76	2.00	37.00	41.98	25.35	31.00	25.40	80.070	260.		3
77	2.00	31.50	35.83	28.57	27.50	26.96	77.440	255.		6
78	2.00	38.00	43.06	22.94	28.00	26.72	61.240	263.		0
79	2.00	38.50	43.54	22.79	33.00	24.61	63.940	268.		0
80	2.00	38.00	45.63	24.68	32.50	24.80	65.530	191.		6
50 81	2.00	31.50	36.91	27.85	24.00	28.86	61.290	214.		3
82	2.00	40.50	46.06	23.81	32.50	24.80	58.530	255.		3
83	2.00	35.00	39.79	25.55	32.00	24.99	60.320	256.		5
84	2.00	44.50	50.94	22.80	40.50	22.22	87.400	242.		2
85	2.00	33.50	38.34	26.53	27.50	26.96	55.140	243.		2
35 86	2.00	39.50	44.39	23.88	32.50	24.80	54.500	284.		1
87	2.00	40.00	44.98	24.23	33.00	24.61	61.410	282.		5
88	2.00	34.00	38.74	25.97	29.50	26.03	59.520	251.		3
89	2.00	48.50	54.63	21.72	40.50	22.22	61.080	278.		2
90	2.00	47.00	52.98	22.11	41.50	21.95	65.890	276.		3
66 91	2.00	35.00	39.74	25.87	30.00	25.81	61.280	259.		2

NHEERL-WED  
RADIATION AREA SURVEY  
FIXED


LOG NO. 01-22

1/2

DATE 8/12/04

LOCATION CSB

ROOM 246



SWIPE #	GROSS CPM	NET DPM	ACTIVITY - Bq/100 CM <sup>2</sup>
1 WALL	90	LLD <sub>95</sub>	ND*
2 WALL			
3 Count			
4 Sink			
5 Floor			
6 Cab			
7 WALL			
8 Floor			
9 Cab			
10 Floor			
11 TABLE			
12 Refrig			
13 Floor			
14 phone			
15 Desk			
16 Floor			
17 Door			
18 shelf			
19 WALL			
20 Count			
21 Sink			
22 Floor			
23 Count			
24 Floor			
25 Floor			
26 Floor			
27 Floor			
28 Floor			

LLD<sub>95</sub> =  $\left\{ \left( \frac{\sqrt{90}}{1} \right) \times 2.96 \right\} + 118.6 \text{ CPM} = \text{CPM}$

BACKGROUND 90 CPM  
STANDARD (137Cs tube) 1950 CPM  
INSTRUMENT Zusum 113  
SERIAL NO. 77126

COMMENTS: \* ND = NOT DETERMINED Below the DETECTION Limit of the Instrument.

D.A. Mon  
RADIATION SPCL.

8-12-04  
DATE

NHEERL-WED  
RADIATION AREA SURVEY

LOG NO. \_\_\_\_\_


DATE 8-11-04

Fixed

LOCATION 480

04-22 2/2

ROOM 246



SWIPE #	GROSS CPM	NET DPM	ACTIVITY -Bq/100 CM <sup>2</sup>
29 Cab	90	<LLD <sub>95</sub>	ND*
30 Sill	✓	✓	✓
31 Floor			
32 Hood			
33 Hood			
34 Hood			
35 Hood			
36 Hood			
37 Hood			
38 Sill			
39 Sill			
40 Floor			
41 Floor			
42 Sill			
43 Sill			
44 Floor			
45 Cab	✓	✓	✓
*TRAY	130	+	+

LLD<sub>95</sub> =  $\left\{ \left( \sqrt{90} \right) \times 2.96 \right\} + = \text{CPM}$

BACKGROUND 90 cpm  
STANDARD (<sup>137</sup>Cs 2 mil) 9500 CPM  
INSTRUMENT Ludlum #3  
SERIAL NO. 7776

COMMENTS: # Fiberglass large tray 130 cpm. + will clean + resurvey IF still contaminated, will cut out contaminated section.

Q.A. Man  
RADIATION SPCL.      DATE 8-12-04



NHEERL-WED  
RADIATION AREA SURVEY  
REMOVABLE - LSC


LOG NO. 04-13

DATE 6-8-04

LOCATION CSB

ROOM 246

4/4



SWIPE #	GROSS CPM	NET DPM	ACTIVITY - Bq/100 CM <sup>2</sup>
1	35	LD <sub>95</sub>	ND*
2	23		
3	33		
4	32		
5	27		
6	31		
7	26		
8	29		
9	27	↓	↓

$$LLD_{95} = \left\{ \left( \frac{\sqrt{31.33 \times 3}}{3} \right) \times 2.96 \right\} + 4 \text{ CPM} = \text{CPM}$$

BACKGROUND 31.33  
STANDARD (1"t 84,000 DPM) 84,944 DPM  
INSTRUMENT Packard 2200 CA  
SERIAL NO. 036755

COMMENTS: \*ND = NOT DETERMINED. BELOW THE DETECTION LIMITS OF THE INSTRUMENT.

PA Man  
RADIATION SPCL.

6/13/04  
DATE

NO CONTAMINATION



9709

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: <sup>14</sup>C

Date: 10-13-87

Method of Detection: LSC

P. Monaco  
Radiation Safety Technician

Type #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
	190	Door	0					
	190	Floor	2	5 LLDs				
	190	Sink bench	7	2 LLDs				
	190	E Bench	0					
	190	W Bench	0					
	190	N Bench	0					
	246	under wal sill	0					
	"	hood left	30	35				
	"	hood <del>top</del> <sup>bottom</sup>	8	9 LLDs				
	"	hood side	0					
	"	hood floor	6	8 LLDs				
	"	door	5	6 LLDs				

Calculation of Lower Limits of Detection (LLD)

Nuclide: <sup>14</sup>C      Nuclide: \_\_\_\_\_

Gross Background Counts:  
Total Background Count time:

2575  
3'

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

14

REMARKS:

246

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: <sup>14</sup>C

Date: 9-24-87

Method of Detection: 2SC

Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
3	256	E-Floor	0					
4		W-Floor	2					
5		S-Bench top	0					
6		Door	0					
7	246	N-Floor	12	15				
8		Hood	30	36				
9		Hood	123	144				
10		W-Floor	1	2				
11		E-Floor	0					
12		SW Floor	0					
13		E(S) Bench top	0					
14		DESK	0					
15		Door	10	12				
16	236	Door	0					
17		Floor - W	9	10				
18	228	Door Floor	29	33				

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

REMARKS: \_\_\_\_\_

Rm 246 7-18-87

PROGRAM # 6  
REGION A: LL-UL= 2-156 LCR= 0 BKG= 18 % SIGMA= 2  
REGION B: LL-UL= 4-156 LCR= 0 BKG= 0 % SIGMA= 2  
NUCLIDE 1 = 36900  
TIME= 1.00 QIP= SIE/REC SCR= B/A K= 1.000

PH	S#	TIME	CPMA/K DPM1/K	%DEV	CPMB/K DPM2/K	%DEV	QIP	FLAGS	SCR	MIN	
6	1	1.00	2.00 2.35	44.7	19.00 .00	45.8	504.	L1?	9.500 .000	2	Bench top
6	2	1.00	7.00 8.26	40.0	24.00 .00	40.8	493.	L ?	3.429 .000	4	Floor
6	3	1.00	7.00 8.12	40.0	23.00 .00	41.7	549.	L ?	3.286 .000	6	door Floor

Leaking Waste Container

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: 14C

Date: 7-17-87

Method of Detection: LSC

Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
101	236	S Hood FL.	0					
102		Refer NW	0					
103		Refer SW	0					
104	246	Door	0					
105		Door Fl	0					
<del>106</del> 1		Gen. Hood Floor	22	28				
2	252	Door	0					
3		W Floor	0					
4		LSC Desk Area	0					
5		Phone	0					
6		N E Floor	4	5				
7		Hood	0					
8		oxidizer	0					
9		refer	24	27				

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

REMARKS:

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 248 Final Contamination Survey.**

Description and Historic Use:

Large one and one-half lab (350 ft<sup>2</sup>) shared with MB 250. Potentially hydrogen-3 and carbon-14 tracers and nickel-63 sealed sources. No tracer use since prior to 1986. There is no record of leakage of any sealed sources used in this area.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in MB 248 in November 2004. All points surveyed (8 total and 8 removable) demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. .

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of MB 248 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.

NHEERL-WED  
RADIATION AREA SURVEY

LOG NO. DA-23

DATE 11-11-04

LOCATION MB

ROOM 248

INSTRUMENT Ludlum 2000 Scaler      Panache Probe #9  
SERIAL NO. 83810 / PR 070834

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	24	LLDS	ND
2	38	↓	↓
3	35	↓	↓
4	28	↓	↓
5	34	↓	↓
6	36	↓	↓
7	50	↓	↓
8	32	↓	↓

LLD<sub>95</sub> = { (  $\frac{\sqrt{38}}{0.5}$  ) x 2.96 } / 76 = **113 CPM**

BACKGROUND STANDARD ( <sup>14</sup>C 0.164µCi ) 76 CPM      10540 CPM      2.8% eff.

Time 0.5'

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>

LLD<sub>95</sub> = { ( (-----) ) x 2.96 } + = CPM

BACKGROUND STANDARD ( ----- ) -----

COMMENTS:

Darmon  
RADIATION SPCL.

11-16-04  
DATE

NHEERL-WED  
RADIATION AREA SURVEY

LOG NO. 04-23

DATE 11-11-04

LOCATION MB

ROOM 248

INSTRUMENT PACKARD LSC 2200 CA  
SERIAL NO. 036755

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	2	LLD <sub>95</sub>	ND
2	4	↓	↓
3	3	↓	↓
4	3	↓	↓
5	2	↓	↓
6	3	↓	↓
7	3	↓	↓
8	3	↓	↓

LLD<sub>95</sub> = { (-----) X 2.96 } + = 7 CPM

BACKGROUND STANDARD (3H) 64,179 DPM    4 CPM    56,056 DPM  
87% eff.

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
	9	LLD <sub>95</sub>	ND
	12	↓	↓
	12	↓	↓
	17	↓	↓
	13	↓	↓
	16	↓	↓
	14	↓	↓
	13	↓	↓

LLD<sub>95</sub> = { (-----) X 2.96 } + = 30 CPM

BACKGROUND STANDARD (1C) 84,000 DPM    22 CPM    85,603 DPM  
102% eff.

COMMENTS:


J. Moraw  
RADIATION SPCL.    11-18-04  
DATE

NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION MB

ROOM 248





AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: <sup>14</sup>C

Date: 8-12-87

Method of Detection: LSC

P. Mon  
Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
6	258	door	0					
7		Refrigerator	15	17				
8		floor	3	<				
9		LSC	3	<				
10		Chambers 1	0					
11		2	0					
12	256	door	0					
13		Phone	0					
14		Floor	0					
15		LSC	1	<				
16		refrigerator	0					
17	248	door	2	<				
		floor	0					
		phone	0					
		Sink	0					

Calculation of Lower Limits of Detection (LLD)

Nuclide: <sup>14</sup>C Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

5

REMARKS:

218  
87-20

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: <sup>14</sup>C / <sup>3</sup>H

Date: 8-7-87

Method of Detection: LSC

Phil Monaw  
Radiation Safety Technician

Swipe #	Location		Nuclide: <sup>3</sup> H			Nuclide: <sup>14</sup> C		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
92		Hexazinone				5.97	6.8	
93		Hexazinone				0		
94	180	door	0			0		
95		Bench top	0			8.3	9	
96		Bench top	0			5	5	
1		(SINK) Bench top	49	138		179	205	
2		<del>Sink</del> Bench top	30	91		50	92	
3		SINK FIX floor	13	37		73	84	
4		floor	0			0		
5		floor	0			0		

Calculation of Lower Limits of Detection (LLD)

Gross Background Counts:  
Total Background Count time:

Nuclide: <sup>3</sup>H  
144  
10

Nuclide: <sup>14</sup>C  
454  
20

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) =

5.6

4.9

REMARKS:

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 250 Final Contamination Survey.**

Description and Historic Use:

Large one and one-half lab (350 ft<sup>2</sup>) shared with MB 248. Potentially hydrogen-3 and carbon-14 tracers and nickel-63 sealed sources. No tracer use since prior to 1986. There is no record of leakage of any sealed sources used in this area.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in MB 250 in November 2004. All points surveyed (9 total and 9 removable) demonstrated no significant contamination. Two points indicated very low levels of removable contamination from tritium (0.33 – 0.60 Bq/100 cm<sup>2</sup>). All other sampling points were at background. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. This area meets the contamination criteria for unrestricted use based upon the isotopes used in this area.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of MB 250 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.

NHEERL-WED  
RADIATION AREA SURVEY  
FIXED SURVEY

LOG NO. 04-23

DATE 11-11-04

LOCATION 21B

ROOM 11250

INSTRUMENT Ludlum 2000 Scaler Passive Probe #9  
SERIAL NO. 83810 / PR 070834

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	35	LUDS	ND
2	60	↓	↓
3	38	↓	↓
4	44	↓	↓
5	36	↓	↓
6	56	↓	↓
7	40	↓	↓
8	54	↓	↓
9	50	↓	↓

LLD<sub>95</sub> = {  $(\frac{\sqrt{38}}{0.5}) \times 2.96$  } = 113 CPM

BACKGROUND STANDARD (<sup>14</sup>C 0.168 μCi) 76 CPM 10,540 CPM 2.8% eff.  
Time 0.5'

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>

LLD<sub>95</sub> = { (-----) × 2.96 } + = CPM

BACKGROUND STANDARD ( ) =

COMMENTS:

D. Monahan  
RADIATION SPCL.

11-16-04  
DATE

NHEERL-WED  
RADIATION AREA SURVEY

LOG NO. 04-23

DATE 11-11-04

LOCATION MB

ROOM 250

INSTRUMENT Packard LSC 2200 CA  
SERIAL NO. ~~030~~ 036755

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	4	LLD <sub>95</sub>	ND
2	4	↓	ND
3	12	36	0.60
4	3	LLD <sub>95</sub>	ND
5	2	↓	ND
6	7	20	0.33
7	5	LLD <sub>95</sub>	ND
8	3	↓	ND
9	5	↓	ND

LLD<sub>95</sub> = { (-----) X 2.96 } + (7 CPM)  
A CPM

BACKGROUND STANDARD (3H 64,179 dpm) = 56,056 dpm  
87% eff

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
	12	LLD <sub>95</sub>	ND
	15	↓	↓
	13		
	13		
	15		
	11		
	14		
	13	↓	↓
	17	↓	↓

LLD<sub>95</sub> = { (-----) X 2.96 } + (30 CPM)

BACKGROUND STANDARD (14C 84,000 dpm) = 85,603 dpm  
102% eff

COMMENTS:


D. Monaco  
RADIATION SPCL.

11-18-04  
DATE

NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION MB ROOM 250



8/14  
250

REMOVABLE CONTAMINATION LEVELS (SHEARS)\*

check of Hood in Rm 250  
before it's removed. (U. Johnson Area)  
Purpose of Survey

9/2/81  
Date

DAN TULLO  
Surveyor

Location	1 BKG	2 Gross β cpm w/ <sup>3</sup> H	3 Net β cpm w/ <sup>3</sup> H	4 Gross β cpm w/o <sup>3</sup> H	5 Net β cpm w/o <sup>3</sup> H	6 Net β μCi w/o <sup>3</sup> H	7 Net <sup>3</sup> H cpm	8 Net <sup>3</sup> H μCi
Hood sill	12.8	13.6						
Glass front (outside)	12.8	10.1						
Glass front (inside)	12.8	10.1						
Hood inside (bottom)	12.8	12.6						
Hood inside (Rear wall)	12.8	9.8						
Hood inside (left wall)	12.8	7.0						
Hood inside (Right wall)	12.8	10.6						
Storage cabinet under Hood. (Door)	12.8	5.0						
Storage cabinet under Hood (bottom)	12.8	11.8						
Refrig.	12.8	14.6						

\* No smearing efficiency value is factored into these results.

Instrument used: \_\_\_\_\_

LLD(95%) = \_\_\_\_\_ cpm

LLD(β w/o <sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

LLD(<sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

USE REVERSE SIDE FOR CALCULATIONS

PROGRAM # 6  
 REGION A: LL-UL= 0- 12 LCR= 0 BKG= 0 % 2 SIGMA= 1.0  
 REGION B: LL-UL= 12- 156 LCR= 0 BKG= 0 % 2 SIGMA= 1.0  
 ME= 100.00 QIP= SIE/REC SCR= B/A K= 1.000

Tullio Swipes  
 81-04

S#	TIME	CPMA/K DPM1/K	%DEV	CPMB/K DPM2/K	%DEV	QIP	FLAGS	SCR	MIN	
1	100.00	84 91	2.18	20 0	4.42	723.		.243 .000	101	BLANK
2	100.00	72 79	2.36	20 0	4.43	649.		.284 .000	203	1 Rm 134, Bench
3	100.00	75 82	2.30	21 0	4.36	649.		.280 .000	304	2 Rm 132, hood
4	100.00	55 62	2.69	20 0	4.44	535.	1	.367 .000	405	3 Rm 132, sink
5	100.00	72 79	2.36	20 0	4.48	639.		.278 .000	506	4 Rm 132, floor
6	100.00	70 77	2.39	20 0	4.53	619.		.279 .000	607	5 Rm 130, sink
7	100.00	64 70	2.50	20 0	4.46	583.	1	.316 .000	708	6 Rm 130, hood
8	100.00	63 70	2.51	21 0	4.39	578.		.328 .000	809	7 Rm 130, floor
9	100.00	52 59	2.77	19 0	4.57	528.	1	.366 .000	910	8 Rm 133, LSS
10	100.00	55 61	2.70	20 0	4.49	543.	1	.361 .000	1011	9 Rm 133, floor
11	100.00	61 67	2.57	20 0	4.51	572.	1	.325 .000	1112	10 Hall outside 133
12	100.00	77 84	2.28	21 0	4.41	657.	1	.269 .000	1213	11 Rm 236, Refrig.
13	100.00	68 75	2.42	26 0	3.95	606.	1	.376 .000	1314	12 Rm 228, sn. Refr
14	100.00	63 70	2.51	21 0	4.41	595.	1	.325 .000	1415	13 Rm 228, Hood
15	100.00	67 73	2.45	23 0	4.19	584.	1	.343 .000	1516	14 Rm 228, Lig. change
16	100.00	61 67	2.56	25 0	3.96	564.		.417 .000	1617	15 Rm 250 hood
17	100.00	75 83	2.30	21 0	4.35	620.		.280 .000	1718	16 Rm 190 Bench
18	100.00	38 42	3.23	17 0	4.81	600.	1	.450 .000	1819	17 Rm 190 Floor

Don Hills 7/6/81

25  
 13



# DAN TULLO

# 6  
 A: LL-UL= 0- 12 LCR= 0 BKG= 0 % 2 SIGMA= 1.0  
 B: LL-UL= 12- 156 LCR= 0 BKG= 0 % 2 SIGMA= 1.0  
 100.00 QIP= SIE/REC SCR= B/A K= 1.000

81-03

	TIME	CPMA/K DPM1/K	%DEV	CPMB/K DPM2/K	%DEV	QIP	FLAGS	SCR	MIN	
1	100.00	100	2.00	21	4.37	779.		.209	114	BKG
		108		0				.000		
2	100.00	98	2.02	19	4.64	750.		.188	215	Rm 133 LSS.
		106		0				.000		
3	100.00	97	2.04	20	4.53	722.		.202	316	Rm 133 Doolway
		105		0				.000		
4	100.00	83	2.19	18	4.67	698.		.220	417	134 Microcosm
		91		0				.000		
5	100.00	84	2.18	18	4.66	727.		.220	518	134 Balance AREA
		91		0				.000		
6	100.00	84	2.18	18	4.72	716.		.212	619	132 Hood
		91		0				.000		
7	100.00	73	2.34	18	4.74	709.		.244	720	132 Sink
		79		0				.000		
8	100.00	85	2.16	19	4.64	724.		.218	821	130 Balance AREA
		92		0				.000		
9	100.00	93	2.07	21	4.41	724.		.220	922	130 Sink
		101		0				.000		
10	100.00	95	2.05	19	4.53	746.		.205	1023	Hall 130
		102		0				.000		
11	100.00	75	2.31	17	4.86	775.		.226	1124	Hall 133
		81		0				.000		
12	100.00	96	2.04	19	4.55	763.		.202	1225	236 Hood (left)
		103		0				.000		
13	100.00	75	2.31	17	4.83	748.		.230	1326	236 Hood (right)
		81		0				.000		
14	100.00	92	2.09	19	4.64	733.		.202	1427	236 Sink (ceak)
		99		0				.000		
15	100.00	95	2.06	19	4.64	788.		.197	1528	LSS center room
		102		0				.000		
16	100.00	72	2.35	17	4.87	757.		.234	1629	Floor center room
		78		0				.000		
17	100.00	43	3.06	14	5.31	752.		.333	1730	228 Hood & Refrig
		46		0				.000		
18	100.00	40	3.17	14	5.31	728.		.357	1831	228 Hood left
		43		0				.000		
19	100.00	72	2.36	17	4.82	721.		.240	1932	228 Refrig - sink 1
		77		0				.000		
20	100.00	85	2.17	19	4.54	726.		.229	2033	228 Floor - sink
		92		0				.000		
21	100.00	20	4.44	13	5.64	762.		.620	2135	236 Hallway
		22		0				.000		
22	100.00	65	2.49	17	4.81	768.		.268	2236	228 Hallway
		70		0				.000		
23	100.00	34	3.44	16	5.06	746.		.463	2337	250 Hood
		36		0				.000		
24	100.00	44	3.00	16	5.01	743.		.359	2438	250 Refrig.
		48		0				.000		
25	100.00	62	2.55	16	4.95	766.		.264	2539	246 Balance
		66		0				.000		

AAA - In/Out

# Swipes of Radiation Areas

1/30/81

81-01

7807		35	20.000	1345	890	BKG.
67.2	2.5		44.5 3.5			
7193		36	20.000	872	688	Microcosm Rm 134, Floor
43.6	3.5		34.4 4.5			
7073		37	20.000	724	644	Microcosm Rm 134, Bench
36.7	4.5		32.2 4.5			
6825		38	20.000	1334	1244	Rm 132, hood
66.7	2.5		62.2 2.5			
6551		39	20.000	820	650	Rm 132, Floor
41.0	3.5		32.5 4.5			
6843		40	20.000	878	652	Rm 130, Floor
43.9	3.5		32.6 4.5			
6373		41	20.000	718	724	Rm 130, Sink
35.9	4.5		36.2 4.5			
6627		42	20.000	767	650	Rm 250, Floor
38.3	4.5		32.8 4.5			
6726		43	20.000	711	565	Rm 250, hood
35.5	4.5		28.2 4.5			
6733		44	20.000	965	720	Rm 236, Floor
48.2	3.5		30.2 4.5			
7110		45	20.000	752	654	counter room 2 <sup>nd</sup> floor, Floor
37.6	4.5		32.7 4.5			
6617		46	20.000	966	675	Rm 228, Floor
48.3	3.5		33.7 4.5			
6572		47	20.000	698	591	Hall outside Rm 236
34.9	4.5		29.5 4.5			
6180		48	20.000	650	535	Hall outside Rm 133
32.8	4.5		26.7 4.5			

Donal Lullo N.P.

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**

**Subject: Room Survey: Main Building 256 Final Contamination Survey.**

Description and Historic Use:

Single lab (220 ft<sup>2</sup>). Hydrogen-3 and carbon-14 tracers, and nickel-63 sealed sources. This room was decommissioned as an unrestricted area on March 19, 2002. No isotope use since 2002. There is no record of leakage of any sealed sources used in this area.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in MB 256 at the time of restricted use decommissioning. The decommissioning records are enclosed. All points surveyed demonstrated no significant contamination. The chemical fume hood has minor removable tritium contamination (1.91 Bq/100 cm<sup>2</sup>). This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. A HVAC duct swipe was made in November 2004 which detected 0.45 Bq/100 cm<sup>2</sup> contamination.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of MB 256 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 3 Survey Meter equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.

**DYNAMAC**  
**CORPORATION**  
*Environmental Services*

---

200 South West 35th Street  
Corvallis, OR 97333

Telephone: (541) 754-4844  
Fax: (541) 754-4818



Handwritten signature and date: 3/19/02

**MEMO**

To: Jay Gile, NHEERL RSO  
From: Phil Monaco, Dynamac  
Date: March 19, 2002

Subject: Decommissioning Survey of MB 256

The Main Building laboratory, room 256, was surveyed for fixed and removable radioactive contamination. Thirty-four spots were surveyed for fixed contamination and 46 wet (methanol) swipes were taken for removable contamination and analyzed for tritium and  $^{14}\text{C}$ .

The fixed contamination survey did not reveal any contamination. Two swipes demonstrated activity above the detection limits for either tritium or  $^{14}\text{C}$ : one swipe in the hood was contaminated with tritium ( $2.32 \text{ Bq}/100 \text{ cm}^2$ ); the swipe of the sink demonstrated contamination of both tritium and  $^{14}\text{C}$ ,  $1.91 \text{ Bq}/\text{cm}^2$  and  $1.35 \text{ Bq}/\text{cm}^2$  respectively. The tritium swipe was above the action level ( $>1.6 \text{ Bq}/100 \text{ cm}^2$ ). No removable  $^{14}\text{C}$  contamination was detected above the action level. The sink was washed, re-swiped, and counted for carbon using a scaler as an indicator of cleaning efficiency and contamination. The carbon levels (dropped to below the detection level). An additional wet swipe of the sink was made for LSC counting. The levels of both tritium and  $^{14}\text{C}$  were below the detection limits.

**Recommendations:**

The sink was fully decontaminated by washing. I suspect the sink contamination was a result of chemiluminescence.

Given the semi-porous nature of the construction material of the hood, cleaning is efficient in removing contamination. Therefore, it should go on record that an area of the hood is permanently contaminated and should be posted and treated as such during future maintenance operations.

Records of these surveys were logged as 02-04 and placed on file in MB 190. If you have any questions, please contact me.


NHEERL-WED  
RADIATION AREA SURVEY  
FIXED

LOG NO. 02-04  
1/2

DATE 3-8-02

LOCATION MAIN BLDG ROOM 256

DECONTAMINATION 256  
256



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	125	LD <sub>05</sub>	ND*
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			

$$LLD_{05} = \left\{ \left( \frac{\sqrt{125}}{7} \right) \times 2.96 \right\}_+ = 158 \text{ CPM}$$

BACKGROUND 125 CPM  
STANDARD (<sup>137</sup>Cs, <sup>226</sup>Ra) 11,000 CPM  
INSTRUMENT Lucy # 3  
SERIAL NO. 71176

COMMENTS: ND = NOT DETERMINED. BELOW THE DETECTION LIMITS

J. M...  
RADIATION SPCL.

3-11-02  
DATE



NHEERL-WED  
RADIATION AREA SURVEY

LOG NO. \_\_\_\_\_


DATE 3-8-02

REMOVABLE

3H

LOCATION MAIN BLDG ROOM 256

DECOMMISSIONING MB 256



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>	
#1	3	LLD <sub>95</sub>	ND*	
#2	5			Upper Wall
#3	6			Lower Wall
#4	9			
#5	4			
#6	5			
#7	4			Lower cabinet
#8	3			Behind table
#9	7			
#10	5			DRAWERS
#11	5			
#12	4			
#13	3			
#14	2			
#15	25	176	1.91 Bq	
#16	11			
#17	5			
#18	2			Floor
#19	4			
#20	7			
#21	6			Upper cabinet wall
#22	8			
#23	4			
#24	8			
#25	5			
#26	4			
#27	3			DRAWER FLOOR
#28	9			
#29	6			

$$LLD_{95} = \left\{ \left( \frac{\sqrt{16}}{2} \right) \times 2.96 \right\} + 8 = \left( \frac{14}{\text{CPM}} \right)$$

BACKGROUND 8 CPM  
 STANDARD (72,853 DPM 3H) 26.611  
 INSTRUMENT Packard 2200CA  
 SERIAL NO. 036755

COMMENTS: \*ND = NOT DETERMINED. Below the detection limits.

3-11-02 *om*

Q. Monac  
RADIATION SPCL.


3-10-02  
DATE

NHEERL-WED  
**RADIATION AREA SURVEY**  
 REMOVABLE

LOG NO. \_\_\_\_\_

DATE 3-8-02

LOCATION MAIN BLDG ROOM 256



36 Ball  
 37 L/H  
 38 RT  
 39 BE LT. Floor  
 40 BE RT Floor  
 41 BE Cor. Floor  
 42 - FRT COR. Floor  
 43 - SASH  
 44 - SILL  
 45 - INSIDE  
 46 - Outside  
 46 - Outside

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>	
30	2	LUDS	ND	WALL
31	1	↓	↓	Floor
32	2	↓	↓	Door
33	3	↓	↓	Cabs
34	10	↓	↓	
35	10	↓	↓	File
36	20	139	2.32 Bq	
37	4	LUDS	ND	
38	4	↓	↓	
39	5	↓	↓	
40	3	↓	↓	
41	2	↓	↓	
42	5	↓	↓	
43	1	↓	↓	
44	3	↓	↓	
45	6	↓	↓	
46	5	↓	↓	

$$LLD_{95} = \left\{ \left( \sqrt{\quad} \right) \times 2.96 \right\} + \quad = \text{CPM}$$

BACKGROUND STANDARD ( INSTRUMENT SERIAL NO. \_\_\_\_\_ ) \_\_\_\_\_

COMMENTS:

RADIATION SPCL. \_\_\_\_\_

DATE \_\_\_\_\_



NHEERL-WED  
RADIATION AREA SURVEY


LOG NO. \_\_\_\_\_

DATE 3-8-02

REMOVABLE

14C

LOCATION MAIN BLDG ROOM 256



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>	
#1	24	LLD <sub>95</sub>	N/D*	
#2	21			Upper Wall
#3	18			Lower Wall
#4	22			
#5	21			
#6	21			
#7	25			Lower Wall
#8	20			Behind Table
#9	15			
#10	18			
#11	23			Drawer
#12	23			
#13	18			
#14	27			
#15	85	81	135	
#16	23	LLD <sub>95</sub>	ND	
#17	23			
#18	19			
#19	17			Floor
#20	25			
#21	19			Upper Cab/Wall
#22	26			
#23	17			
#24	24			
#25	23			
#26	31			
#27	23			Drawer Floor
#28	20			
#29	24			

LLD<sub>95</sub> =  $\left\{ \left( \frac{\sqrt{50}}{2} \right) \times 2.96 \right\} + 25 = 36$  CPM

BACKGROUND 25 CPM  
STANDARD (84,000 DPM <sup>14</sup>C) 85,052 DPM  
INSTRUMENT PACKARD 2200CA  
SERIAL NO. 036755

COMMENTS: \* ND = NOT DETERMINED, BELOW the Detection Limits.

DA. Monaco  
RADIATION SPCL.


3-11-02  
DATE

NHEERL-WED  
**RADIATION AREA SURVEY**  
 REMOVABLE

LOG NO. \_\_\_\_\_

DATE 3-8-02

LOCATION MAIN BLDG ROOM 256



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>	
30	21	LD <sub>5</sub>	ND*	Wall
31	22			Floor
32	22			Door
33	19			Cabs
34	18			
35	28			File
36	17			
37	27			
38	23			
39	25			
40	20			
41	20			
42	20			
43	22			
44	26			
45	20			
46	20			

LLD<sub>95</sub> = { (  $\sqrt{\quad}$  ) X 2.96 } + = CPM

BACKGROUND STANDARD ( \_\_\_\_\_ ) \_\_\_\_\_  
 INSTRUMENT SERIAL NO. \_\_\_\_\_

COMMENTS:

RADIATION SPCL. \_\_\_\_\_

DATE \_\_\_\_\_

NHEERL-WED  
RADIATION AREA SURVEY  
REMOVABLE

LOG NO. 02-04

DATE 3-18-02

3H

LOCATION MB

ROOM MB 256

Reswipes Sink

Sink

SWIPE GROSS NET  
ACTIVITY

#	CPM	DPM	Bq/100 CM <sup>2</sup>
<u>1</u>	<u>4.5</u>	<u>LLD<sub>95</sub></u>	<u>ND*</u>

$$LLD_{95} = \left\{ \left( \frac{\sqrt{11}}{2} \right) \times 2.96 \right\} + 10.4 = \text{CPM}$$

BACKGROUND 5.5 CPM  
 STANDARD ( 73,853 DPM<sup>94</sup> ) 81,835  
 INSTRUMENT PACKARD 2200 CA  
 SERIAL NO. # 036755

COMMENTS: ND\* = NOT DETERMINED. BELOW THE DETECTION LIMITS.

DA Moner

3-19-02

NHEERL-WED  
RADIATION AREA SURVEY  
REMOVABLE

LOG NO. 02-04

DATE 3-18-02

14C

LOCATION MB

ROOM MB  
256

Reswipes sink



SWIPE GROSS NET  
ACTIVITY

#	CPM	DPM	Bq/100 CM <sup>2</sup>
1	22	LUD <sub>95</sub>	ND*
<del>2</del>			

LLD<sub>95</sub> = { ( √  $\frac{32}{2}$  ) X 2.96 } + 24 CPM

BACKGROUND 16 CPM  
STANDARD (1<sup>4</sup>C 84,000dpm ) 84,960 DPM  
INSTRUMENT Packard 2200CA  
SERIAL NO. 036755

COMMENTS: ND\* = NOT DETERMINED. Below the detection limit.

[Signature]

3-19-02

Protocol #:30                      Name:3H/14C Radsafety                      04-Jan-80                      05:44  
 Region A: LL-UL= 0.0-12.0    Lcr=    0    Bkg= 0.00    %2    Sigma=0.50  
 Region B: LL-UL=12.0-156.    Lcr=    0    Bkg= 0.00    %2    Sigma=0.50  
 Region C: LL-UL= 0.0- 0.0    Lcr=    0    Bkg= 0.00    %2    Sigma=0.00  
 Time = 2.00                      QIP = tSIE/AEC                      ES Terminator = Count  
 Conventional DPM  
 Nuclide 1 = 139236                      Nuclide 2 = 113700  
 Luminescence Correction On

S#	TIME	CPMA	DPM1	A:25%	CPMB	DPM2	B:25%	SIS	tSIE	FLAG	LUM
<i>Bkg</i> 1	2.00	5.50	8.09	87.19	11.50	13.16	41.70	124.90	759.		6
<i>3H</i> 2	2.00	38474.5	<u>81835.1</u>	0.72	3868.50	0.00	2.27	15.460	681.		0
<i>14C</i> 3	2.00	9940.00	872.35	1.42	71289.5	<u>84959.9</u>	0.52	129.58	770.		0
(9 missing vials)											
{ 13	2.00	82.00	111.55	16.36	326.50	392.60	7.82	76.000	456.		0
{ 14	2.00	587.50	1382.33	5.89	819.50	923.71	4.94	54.520	436.		0
{ 15	2.00	4748.50	13018.7	2.07	1471.00	1026.20	3.68	22.870	438.		1
{ 16	2.00	16.50	10.51	39.74	101.50	124.91	14.03	79.200	401.		0
{ 17	2.00	105.00	0.00	14.44	950.00	1168.10	4.58	85.270	442.		0
{ 18	2.00	986.50	0.00	4.54	7975.00	9808.78	1.58	82.530	431.		0
{ 19	2.00	8428.00	0.00	1.55	71006.5	87394.6	0.53	83.020	431.		0
(1 missing vial)											
<i>Bkg</i> 21	2.00	<u>5.50</u>	<u>18.05</u>	83.31	<u>16.00</u>	<u>19.89</u>	35.35	41.180	236.		5
<i>H1</i> 22	2.00	4.50	17.04	96.86	22.00	29.87	30.82	33.520	147.	E	2






NHEERL-WED  
RADIATION AREA SURVEY

LOG NO. 96-22 2/4  
256

DATE 10/3/96

LOCATION MAIN BLDG ROOM 256



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
12	17	LLD <sub>95</sub>	0 net
13	14		
14	3		
15	22		
16	19		
17	20		
18	14		
19	20		

$$LLD_{95} = \left\{ \left( \sqrt{\quad} \right) \times 2.96 \right\} + \quad = \quad \text{CPM}$$

BACKGROUND STANDARD ( \_\_\_\_\_ )  
INSTRUMENT SERIAL NO. \_\_\_\_\_

COMMENTS:

RADIATION SPCL. \_\_\_\_\_

DATE \_\_\_\_\_



**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 258 Final Contamination Survey.**

Description and Historic Use:

Double lab (450 ft<sup>2</sup>). Hydrogen-3 and carbon-14 tracers, and nickel-63 sealed sources. This room was decommissioned as a unrestricted area on April 27, 1999. No isotope use since 1999. There is no record of leakage of any sealed sources used in this area.

Surveys:

A removable contamination survey was conducted in MB 258 at the time of restricted use decommissioning (1997). The decommissioning records are enclosed. All points surveyed demonstrated no significant contamination. A total contamination survey was conducted in November 2004. All points surveyed (9) demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. A HVAC duct swipe was made in November 2004 which detected no contamination.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of MB 258 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.





NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION MB

ROOM 258



Memo

To: File  
From:  Phil Monaco  
Date: April 27, 1999

Subject: 258 Decommissioning Swipes


The record for Main Building 258 decommissioning swipes is attached. Forty-seven wet swipes were counted. Four swipes were above the detection limits. Only one swipes (the west refrigerator) demonstrated contamination above the 1.6 Bq/100 cm<sup>2</sup> action level (2.4 Bq/100 cm<sup>2</sup>). The refrigerator was posted.

NHEERL-WED  
RADIATION AREA SURVEY  
REMOVABLE

LOG NO. 97-1  
1/2

DATE 1/6/97

LOCATION MAIN BLDG ROOM 258-010  
258  
14C



SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
2	16	LLD <sub>95</sub>	ND
3	27		
4	17		
5	21		
6	25		
7	22	↓	↓
8	29	0.533	0.5
9	26	LLD <sub>95</sub>	ND
10	22		
11	21		
12	22		
13	20		
14	21		
15	23		
16	18		
17	23		
18	18		
19	18		
20	26	↓	↓
21	29	33	0.5
22	22	LLD <sub>95</sub>	ND
23	21		
24	26		
25	20	↓	↓
26	30	35	0.6
27	14.2	1.3	2.4
28	17	LLD <sub>95</sub>	ND
29	21	↓	↓

$$LLD_{95} = \left\{ \left( \sqrt{.38} \right) \times 2.96 \right\} + 19 = 28 \text{ CPM}$$

BACKGROUND 18.5  
STANDARD (<sup>14</sup>C NEW 84800) 86,096  
INSTRUMENT Packard 20-220CA  
SERIAL NO. 036755

COMMENTS:

Chris A. Man  
RADIATION SPCL.

1  
DATE



**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 262 Final Contamination Survey.**

Description and Historic Use:

Single lab (225 ft<sup>2</sup>). Carbon-14 tracer. Samples containing radiotracers were analyzed in this lab one time in 1986. No tracers use since 1986.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in MB 262 in November 2004.

All points surveyed (6 total and 6 removable) demonstrated no significant contamination. Four points indicated very low levels of removable contamination from tritium (0.35 – 0.53 Bq/100 cm<sup>2</sup>). All other sampling points were at background. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of MB 262 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.









NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION MB

ROOM 262



**NORTHROP SERVICES, INC.** A Subsidiary of Northrop Corporation  
ENVIRONMENTAL SCIENCES

200 Southwest 35th Street  
Corvallis, Oregon 97333  
Telephone: (503) 757-4664  
(FTS-420-4664)

SUBJECT: Post-experiment Radionuclide Swipe Survey Rm 262 DATE: Sept. 15, 1986

FROM: Phil Monaco, Radiation Safety *PM*

TO: Jerry Wagner

The following data shows the results of the swipe tests taken in your lab, CERL Room 262. As the figures demonstrate, everything checks out well.

<u>Date</u>	<u>Swipe Location</u>	<u>Net CPM</u>	<u>Net DPM</u>
9/10/86	Instrument work counter	0	
	Floor	1.7	< LLD*
	Room door	0	
9/12/86	Waste Bottle -outside	0	
9/08/86	Waste solution	312.9	345
9/15/86	ICP Stack -inside	2.0	< LLD
8/11/86	ICP Stack -inside (before exp.)	4.1	< LLD

\*LLD is defined as the Lower Limits of Detection at the 95% confidence level determined by the background counts.

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 266 Final Contamination Survey.**

Description and Historic Use:

Double lab (450 ft<sup>2</sup>). Carbon-14 and phosphorus-32 tracers, and hydrogen-3:scandium and nickel-63 sealed sources. This room was decommissioned as a unrestricted area on April 24, 1996. No isotope use since 1993. There is a record of a contamination event due to what may have been a leaking nickel-63 sealed source. However, this was never confirmed. The contaminate isotope may have been tritium. A record of the event and remediation is enclosed.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in MB 266 at the time of restricted use decommissioning. The decommissioning records are enclosed. All points surveyed demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. A HVAC duct swipe was made in November 2004 which detected no contamination.

Records for this room clearly demonstrate that contamination surveys were regularly performed. There was a minor contamination incident of the area thought to be either tritium or nickel-63. The area was thoroughly decontaminated and continually re-swiped and monitored (records enclosed). The laboratory was successfully decontaminated to background levels. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of MB 266 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 3 Survey Meter equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.

DYNAMAC CORPORATION  
200 SW 35th Street, Corvallis, OR 97333

MEMORANDUM

TO: Jay Gile, US EPA  
FROM: Phil Monaco *PM*  
DATE: April 24, 1996

SUBJECT: Decommissioning of MB 266

The Biotech/Remediation lab (MB 266) is free of all radioactive materials. Equipment used in the PCP carbon-14 project was decontaminated. The fume hood, hood cabinet, and counters were cleaned, surveyed for removable and fixed radioactive contamination, and determined to be "clean". Given the projected use of MB 266 and its present "clean" state, I recommend that the room be declared "decommissioned" from radioisotope use and designated for non-restricted use from a radiological point of view and all radioactive material signs removed.

The results of the surveys are summarized below.

Fixed Contamination Survey (96-11 and 96-12)  
Ludlum #3 S/N 77146 GM

Survey Description	Sample Size	CPM	Activity (pCi/20cm <sup>2</sup> )
Hood Interior	--	<LLD	0 net
Hood Exterior	--	<LLD	0 net
Hood Cabinet	--	<LLD	0 net
Floor	5	<LLD	0 net
Wall	1	<LLD	0 net
Counters	10	<LLD	0 net
Cabinet Face	1	<LLD	0 net
Phone	1	<LLD	0 net
Door	1	<LLD	0 net
Sink	2	<LLD	0 net
Appliances	3	<LLD	0 net

\*LLD<sub>95</sub> = gross cpm Bkgd +  $\left( \sqrt{\text{CPM Background} \times \text{Counttime/Count time}} \right) \times 2.96$   
 $125 + \sqrt{125} \times 2.96 = 158 \text{ CPM}$

4/24  
I concur.  
Decommission MB 266  
Remove all signs &  
labels  
Jay Gile

Removable Contamination (96-10 and 96-13).  
 Packard LSC 2000CA S/N 036755

Survey Description	Sample Size	Gross CPM (range)	DPM	Activity (pCi/100cm <sup>2</sup> )
Hood Interior	8	19-24	<LLD**	0 net
Hood Exterior	2	15-19	<LLD**	0 net
Hood Cabinet	1	20	<LLD***	0 net
Floor	5	17-26	<LLD	0 net
Wall	1	19	<LLD	0 net
Counters	10	15-24	<LLD	0 net
Cabinet Face	1	20	<LLD	0 net
Phone	1	21	<LLD	0 net
Door	1	21	<LLD	0 net
Sink	2	20-21	<LLD	0 net
Appliances	3	19-23	<LLD	0 net

\*\*LLD<sub>95</sub> = Lower Limits of Detection at the 95% confidence level as calculated by:  $\text{bkgrd cpm} + \left( \sqrt{\text{bkgrd cpm} \times \text{count time} / \text{count time}} \right) 2.96$

LLD<sub>95</sub>       $24 \text{ cpm} + \left( \frac{\sqrt{(24 \text{ cpm} \times 2')}}{2} \right) 2.96 = 24 \text{ cpm}$

\*\*\*LLD<sub>95</sub> = Lower Limits of Detection at the 95% confidence level as calculated by:  $\text{bkgrd cpm} + \left( \sqrt{\text{bkgrd cpm} \times \text{count time} / \text{count time}} \right) 2.96$

LLD<sub>95</sub>       $18.5 \text{ cpm} + \left( \frac{\sqrt{(18.5 \text{ cpm} \times 2')}}{2} \right) 2.96 = 28 \text{ cpm}$



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
ENVIRONMENTAL RESEARCH LABORATORY  
200 S.W. 35TH ST.  
CORVALLIS, OREGON 97330

Summary Report of Health Physics' Activity Involving  
Room 266 Radiation Contamination Incident

6/9 Notified of possible radiation exposure in Room 266 by B. Griffis, F. Stay, and J. Gakstatter, due to abnormally high temperature operation of  $^{63}\text{Ni}$  sealed source in Gas Chromatograph (Note:  $^{63}\text{Ni}$  source will not vaporize until temperature reaches  $700^{\circ}\text{C}$ , informed that operation temperature was  $470^{\circ}\text{C}$ ). Conducted preliminary swipe survey of Room 266 (see survey report June 9, 1982) using Gas Flow Proportional Counter (GFPC). Detected significant contamination on floor beside machine.

Conducted a detailed swipe survey of Room 266 (June 9, 1982) using GFPC. Detected significant contamination throughout lab. Contamination levels decrease with increasing distance from gas chromatograph (GC), also detected contamination in hall outside Room 266. Immediately cleaned hall area.

6/10-6/11 Conducted swipe survey of Room 266 using Liquid Scintillation Spectrophotometer (LSS) in Room 133 (June 10, 1982). Began clean-up operation of Room 266. Clean-up consisted of washing all surfaces with "Iso-clean" decontamination agent (Isolab, Inc.) and mopping floor with "Iso-clean" solution. Progress was monitored with a daily swipe survey. Surveyed underneath temporary coverings of lab benches and surveyed notebooks and graph paper located in lab (June

11, 1982). Detected no significant contamination under temporary coverings. Detected significant contamination on surface of papers and notebooks.

Detectable energy levels were varied on the LSS to obtain data on identification of isotope present. Swipes of June 10, 1982 were counted using energy detection levels between 0-200 Kev (Region A) and 20-100 Kev (Region B). (Note:  $^{63}\text{Ni}$   $E_{\text{max}} = 67$  Kev,  $^{14}\text{C}$   $E_{\text{max}} = 156$  Kev,  $^3\text{H}$   $E_{\text{max}} = 18$  Kev.) Activity was detected in Region A, no activity was detected in Region B. Swipes (June 11, 1982) were counted using detection levels between 0-200 Kev (Region A) and 0-19 Kev (Region B) activity was detected in Region A; nearly identical activity was detected in Region B. Swipes (June 11, 1982) were counted using tritium channel: Region A 0-19, Region B 2-19. Region B eliminates chemoluminescence phenomenon. Counts in Region A and Region B are nearly identical.

6/14 Continued clean-up of Room 266. Counted urine samples of Gakstatter and Tullo (June 14, 1982). No detectable activity in urine samples. A. Yartzoff refused to submit urine sample (see memo from J. Gakstatter June 11, 1982). Removed  $^{63}\text{Ni}$  detector from GC with help of J. Collins. Detector was sent back to tracor for isotope check and overhaul.

6/15 Completed clean up of lab 266 surfaces. Discussed remaining clean-up procedures with A. Yartzoff.



- 6/16 Took swipes of manuals removed from 266 to Yartzoff's office and of desk and floor in office (6/16/82). Detected contamination on surface of tractor manual.
- 6/17 Yartzoff continued clean-up of lab. Took swipes of manuals removed from 266 to Gakstatters office (6/18/82). Manuals are contaminated. Covers were removed and discarded.
- 6/18 Informed that Yartzoff notified Nuclear Regulatory Commission (NRC) of incident. J. Gakstatter, J. Gile and I gave a verbal report of incident to NRC over telephone. Met with J. McCarty, Yartzoff, Gile, Gakstatter to discuss current data and explore options.
- 6/21 Ran air monitor in Room 266 for 24 hours, control was set up in Room 190. No activity was detected in air sample (6/22/82). Conducted swipe surveys in various labs throughout CERL to obtain spectrum of background activity in CERL (6/21/82).
- 6/22 Conducted final swipe survey of Room 266. No activity detected in laboratory. (6/22/82).

DAN TULLO H.P.  
 Surveyor

Contamination incident Road 66 9 June 82  
 Purpose of Survey Date  
Preliminary survey # 3214

1 2 3 4 5 6 7 8

82-14

Location	BKG	Gross $\beta$ cpm w/ $^3\text{H}$	Net $\beta$ cpm w/ $^3\text{H}$	Gross $\beta$ cpm w/o $^3\text{H}$	Net $\beta$ cpm w/o $^3\text{H}$	Net $\beta$ $\mu\text{Ci}$ w/o $^3\text{H}$	Net $^3\text{H}$ cpm	Net $^3\text{H}$ $\mu\text{Ci}$
Housing $^{63}\text{Ni}$ detector	6.6	10.3	3.7	N/A	N/A	N/A	N/A	N/A
G.C. body (inside)	6.6	8.0	1.4	-	-	-	-	-
G.C. body (outside)	6.6	16.6	10.0					
Wall behind machine	6.6	7.7	1.1					
Floor beside machine	6.6	225.1	218.5*					

no smearing efficiency value is factored into these results.

Instrument used: N.M.C. Gas flow proportional Counter Rn 190

$E_{95\%} = \underline{3.78} \text{ cpm}$

$$4.66 \times \frac{\sqrt{66}}{10}$$

$D(\beta \text{ w/o } ^3\text{H}) \text{ in } \mu\text{Ci} = \underline{\hspace{2cm}} \mu\text{Ci}$

$D(^3\text{H}) \text{ in } \mu\text{Ci} = \underline{\hspace{2cm}} \mu\text{Ci}$

lower limit of detection.

USE REVERSE SIDE FOR CALCULATIONS

REMOVABLE CONTAMINATION LEVELS (SHEARS)\*

~~10/13~~

AW Tullio  
Surveyor

Rm 266 Contamination incident  
Purpose of Survey

9 June 82  
Date

82-13

	1	2	3	4	5	6	7	8
Location	BKG	Gross β cpm w/3H	Net β cpm w/3H	Gross β cpm w/o 3H	Net β cpm w/o 3H	Net β μCi w/o 3H	Net 3H cpm	Net 3H μCi
Wall (Door) ①	5.6	68.4	62.8					
15' Floor Door ②	5.6	30.4	24.8					
Door (Door) 5' ③	5.6	168.4	162.8					
Door (hood) 15' ④	5.6	60.1	54.5					
Floor (Desk) ⑤	5.0	117.8	112.8					
Floor (hood) ⑥	5.0	67.0	62.0					
Floor (sink) ⑦	5.0	503.4	498.4					
bench (sink) ⑧	5.6	184.2	178.6					
bench ⑨	5.6	40.3	34.7					
bench ⑩	5.0	164.0	159.0					

Smearing efficiency value is factored into these results.

Instrument used: NMC Gas flow proportional

(95%) = \_\_\_\_\_ cpm

(B w/o 3H) in μCi = \_\_\_\_\_ μCi

(1) in μCi = \_\_\_\_\_ μCi


USE REVERSE SIDE FOR CALCULATIONS

bench

5.0	17.6	12.6
-----	------	------

2 of 2

JUNE 9, 82



87-12

counts of swipes of Rm 266  
before and after Decontamination

June 10 1982

(See Diagram for swipe locations)

PROGRAM #: 6  
 REGION A: LL-UL= 0- 200 LCR= 0 BKG= 0 % 2 SIGMA= .2  
 REGION B: LL-UL= 20- 100 LCR= 0 BKG= 0 % 2 SIGMA= .2  
 TIME= 30.00 QIP= SIS SCR= B/A K= 1.000

P#	S#	TIME	Region A		Region B		QIP	FLAGS	SCR	MIN	
			CPMA/K	%DEV	CPMB/K	%DEV					
6	1	30.00	78.73	4.12	8.27	12.7	46.2	?	.105	30	BKG.
6	2	30.00	628.10	1.46	8.33	12.6	17.7	?	.013	61	1
6	3	30.00	571.77	1.53	7.60	13.2	18.1	1?	.013	91	2
6	4	30.00	1148.10	1.08	7.27	13.5	15.0	?	.006	121	3
6	5	30.00	704.20	1.38	7.73	13.1	16.5	?	.011	152	4
6	6	30.00	1738.63	.88	7.87	13.0	14.1	?	.005	182	5
6	7	30.00	765.90	1.32	7.60	13.2	16.0	?	.010	212	6
6	8	30.00	6333.50	.46	7.67	13.1	12.7	?	.001	243	7
6	9	30.00	3619.47	.61	7.77	13.1	13.2	?	.002	273	8
6	10	30.00	325.00	2.03	7.53	13.3	22.0	1?	.023	303	9
6	11	30.00	740.10	1.34	7.47	13.3	16.4	?	.010	334	10
6	12	30.00	198.23	2.59	7.63	13.2	26.0	?	.039	364	11
6	13	30.00	11753.0	.34	7.33	13.4	11.8	1?	.001	384	12
6	14	30.00	84.50	3.97	7.53	13.3	47.0	?	.089	425	1
6	15	30.00	93.10	3.78	7.40	13.4	44.6	?	.079	455	2
6	16	30.00	146.30	3.02 *	8.70	12.3	33.3	?	.059	485	3
6	17	30.00	119.57	3.34 *	8.20	12.7	35.6	?	.069	516	4
6	18	30.00	217.83	2.47 *	7.67	13.1	26.6	?	.035	546	5
6	19	30.00	130.70	3.19 *	7.20	13.6	35.3	?	.055	576	6
6	20	30.00	228.60	2.42 *	7.43	13.3	25.0	?	.033	607	7
6	21	30.00	156.30	2.92 *	8.40	12.6	32.7	?	.054	637	8
6	22	30.00	78.00	4.11	7.33	13.4	46.9	?	.093	667	9
6	23	30.00	126.13	3.25 +	7.53	13.3	35.9	?	.060	698	10
6	24	30.00	58.10	4.79	7.67	13.1	62.4	?	.132	728	11
6	25	30.00	196.70	2.60 *	7.73	13.1	28.1	?	.039	758	12.

After Decontam



still a little high.

Region B NO Activity  
contamination energy  
is less than 20 KeV.

Swipe Counts of KM. dleb  
 Recounted with opo channel (Region A) June 11, 1982  
 And tritium channel (Region B) (see chart for swipe locations)

-UL= 0- 200 LCR= 0 BKG= 0 % 2 SIGMA= .2  
 L-UL= 0- 19 LCR= 0 BKG= 0 % 2 SIGMA= .2  
 QIP= SIS SCR= B/A K= 1.000

2-11

	CPMA/K <i>Region A</i>	%DEV	CPMB/K <i>Region B</i>	%DEV	QIP	FLAGS	SCR	MIN	
90	58.00	18.5	47.50	20.5	63.0	?	.819	2	BKG
3	583.00	5.86	573.00	5.91	17.2	?	.983	5	1
3	559.00	5.98	546.50	6.05	19.1	?	.978	7	2
2.00	1084.50	4.29	1072.50	4.32	14.9	?	.989	10	3
00	665.00	5.48	653.00	5.53	16.1	?	.982	12	4
0	1718.50	3.41	1710.00	3.42	13.5	?	.995	14	5
2.00	720.00	5.27	710.00	5.31	14.9	?	.986	16	6
2.00	6160.00	1.80	6152.00	1.80	12.6	?	.999	19	7
0	3525.50	2.38	3512.50	2.39	13.1	?	.996	21	8
2.50	288.00	8.33	274.50	8.54	25.3	?	.953	23	9
0	700.50	5.34	687.50	5.39	18.4	?	.981	25	10
0	202.50	9.94	187.00	10.3	36.0	?	.923	28	11
2.00	12069.0	1.29	12053.5	1.29	12.1	?	.999	30	12
0	80.50	15.7	69.50	16.9	35.5	?	.863	32	1
0	85.50	15.2	73.00	16.5	52.9	?	.854	34	2
2.00	147.50	11.6	138.50	12.3	40.9	?	.885	37	3
0	108.00	13.6	99.00	14.2	34.6	?	.917	39	4
2.00	214.50	9.66	204.00	9.90	26.3	?	.951	41	5
2.00	124.50	12.6	112.00	13.3	39.0	?	.900	44	6
2.00	203.50	9.91	193.00	10.1	26.1	?	.948	46	7
2.00	141.00	11.9	130.00	12.4	37.1	?	.922	48	8
2.00	73.50	16.5	63.00	17.8	41.0	?	.857	50	9
00	113.00	13.3	100.00	14.1	38.8	?	.885	53	10
2.00	50.50	19.9	36.00	23.5	86.2	?	.713	55	11
2.00	180.50	10.5	172.00	10.7	21.3	?	.953	57	12
00	77.50	16.0	66.00	17.4	49.7	1?	.852	59	under paper (13)
00	72.50	16.6	60.50	18.1	49.1	1?	.834	62	under wood (14)
2.00	83.00	15.5	69.00	17.0	55.1	?	.831	64	under paper (15)
00	50.00	20.0	35.00	23.9	88.0	?	.700	66	under cloth (16)
2.00	124.00	12.7	115.50	13.1	26.6	?	.931	69	Books (17) surface
00	114.00	13.2	98.50	14.2	38.7	?	.864	71	paper surface (18)

8-11-82

# Recount of swipes of Rn 226 on tritium channel.

June 11, 1982

tritium channel


Region B - eliminates any chemoluminescence phenomenon  
counts still nearly identical. - Appears to be tritium.

PROGRAM #: 6  
 REGION A: LL-UL= 0- 19 LCR= 0 BKG= 0 % 2 SIGMA= .2  
 REGION B: LL-UL= 2- 19 LCR= 0 BKG= 0 % 2 SIGMA= .2  
 TIME= 2.00 QIP= SIS SCR= B/A K= 1.000

P#	S#	TIME	CPMA/K	%DEV	CPMB/K	%DEV	QIP	FLAGS	SCR	MIN
6	1	2.00	57.50	18.6	49.00	20.2	14.5	?	.852	2 BKG
6	2	2.00	608.50	5.73	534.50	6.12	13.2	?	.878	4 1
6	3	2.00	539.50	6.09	475.50	6.49	13.6	?	.891	7 2
6	4	2.00	1122.50	4.22	988.50	4.50	12.8	?	.891	9 3
6	5	2.00	655.00	5.53	564.50	5.95	12.3	?	.862	11 4
6	6	2.00	1724.50	3.41	1493.50	3.66	12.5	?	.866	13 5
6	7	2.00	691.00	5.38	609.50	5.73	13.1	?	.882	16 6
6	8	2.00	6266.00	1.79	5527.50	1.90	12.7	?	.882	18 7
6	9	2.00	3545.00	2.38	3149.50	2.52	13.2	?	.888	20 8
6	10	2.00	298.00	8.19	269.50	8.61	13.5	?	.904	22 9
6	11	2.00	720.00	5.27	626.00	5.65	12.9	?	.869	25 10
6	12	2.00	185.00	10.4	161.50	11.1	13.4	?	.873	27 11
6	13	2.00	12037.5	1.29	10555.0	1.38	12.0	?	.877	29 12
6	14	2.00	64.00	17.6	57.00	18.7	14.7	?	.891	31 1
6	15	2.00	77.00	16.1	69.50	16.9	13.6	?	.903	34 2
6	16	2.00	119.00	12.9	106.50	13.7	14.6	?	.895	36 3
6	17	2.00	98.00	14.2	87.50	15.1	13.8	?	.893	38 4
6	18	2.00	192.00	10.2	170.50	10.8	14.0	?	.888	40 5
6	19	2.00	117.00	13.0	103.00	13.9	14.6	?	.880	42 6
6	20	2.00	224.00	9.45	201.50	9.96	13.9	?	.900	45 7
6	21	2.00	125.00	12.6	107.50	13.6	14.2	?	.860	47 8
6	22	2.00	63.50	17.7	54.50	19.1	15.1	?	.858	49 9
6	23	2.00	123.00	12.7	109.50	13.5	13.6	?	.890	51 10
6	24	2.00	44.00	21.3	39.50	22.5	17.2	?	.898	54 11
6	25	2.00	183.50	10.4	154.00	11.4	17.2	?	.87	56 12

After Decounts  
↓

June 10 1922



2



# Swipe Counts

June 14, 1982

87.10  
266

6  
 LL-UL= 0- 200 LCR= 0 BKG= 0 % 2 SIGMA= .2  
 LL-UL= 2- 19 LCR= 0 BKG= 0 % 2 SIGMA= .2  
 QIP= SIS SCR= B/A K= 1.000

TIME	CPMA/K	%DEV	CPMB/K	%DEV	QIP	FLAGS	SCR	MIN
30.00	58.27	4.78	37.77	5.94	62.6	?	.648	30 BKG
30.00	93.63	3.77	71.37	4.32	40.7	?	.762	61 1
30.00	91.20	3.92	68.17	4.42	42.9	?	.747	91 2
30.00	79.40	4.10	58.90	4.76	47.3	?	.742	122 3
30.00	132.17	3.18	105.67	3.55	34.9	?	.799	152 4 -
30.00	70.57	4.35	50.43	5.14	51.6	?	.715	182 5
30.00	106.40	3.54	83.63	3.99	39.4	?	.786	212 6 -
30.00	63.10	4.60	43.20	5.56	54.8	?	.685	243 7
30.00	75.80	4.19	57.47	4.82	47.5	?	.758	273 8
30.00	107.93	3.51	85.37	3.95	38.2	?	.791	303 9 -
30.00	55.03	4.92	38.57	5.88	61.6	?	.701	334 10
30.00	55.10	4.92	37.83	5.94	65.2	?	.687	364 11
30.00	92.97	3.79	71.50	4.32	39.8	?	.769	394 12
30.00	80.30	4.07	59.77	4.72	48.6	?	.744	425 13
30.00	56.57	4.85	39.40	5.82	64.1	?	.697	455 14
30.00	107.37	3.52	85.87	3.94	37.4	?	.800	485 15 -
30.00	67.37	4.45	50.23	5.15	51.2	?	.746	516 16
30.00	244.93	2.33	214.27	2.49	26.3	?	.875	546 17 -
30.00	30.13	6.65	17.70	8.68	94.5	?	.587	576 18
30.00	25.90	7.17	12.93	10.1	110.	?	.499	606 19
30.00	31.63	6.49	16.73	8.93	108.	?	.529	637 20
30.00	27.90	6.91	14.67	9.53	97.8	?	.526	667 21
30.00	29.70	6.70	15.27	9.35	110.	?	.514	698 22
30.00	35.60	6.12	20.80	8.01	89.3	?	.584	728 23
30.00	72.00	4.30	52.73	5.03	46.6	?	.732	758 24
30.00	39.20	5.83	22.03	7.78	92.1	?	.562	788 25
30.00	93.73	3.77	70.03	4.36	54.3	?	.747	819 26
30.00	50.50	5.14	32.27	6.43	73.6	?	.639	849 27
30.00	31.43	6.51	13.97	9.77	118.	?	.444	1183
30.00	40.07	5.77	16.70	8.94	142.	?	.417	1213

urive Gakstaden  
urive Tullu

June 14, 1982

8210


# 6  
 LL-UL= 8- 200 LCP= 0 BKD= 0 % 2 SIGMA= .2  
 LL-UL= 2- 18 LCP= 0 BKD= 0 % 2 SIGMA= .2  
 30.00 QIP= SIS SCR= E/A K= 1.000

	TIME	CPNR/K	%DEV	CPNB/K	%DEV	QIP	FLAGS	SCR	MIN
1	30.00	66.53	4.48	47.17	5.32	53.8	?	.709	30 1
2	30.00	52.53	5.04	34.23	6.24	67.5	?	.652	61 2
3	30.00	66.70	4.47	48.17	5.26	57.1	?	.722	91 3
4	30.00	30.70	6.59	17.27	8.79	94.6	?	.562	122 4
5	30.00	441.40	1.74	368.77	1.90	18.2	?	.835	152 5
6	30.00	100.83	3.64	79.97	4.08	42.1	?	.793	182 6
7	30.00	106.83	3.53	81.43	4.05	41.9	?	.762	212 7
8	30.00	58.83	4.76	30.23	6.64	60.7	1?	.514	243 8 Asbestos mat'l
9	30.00	88.67	3.88	42.20	5.62	40.2	1?	.476	273 BKD

Swipe 5 of Bench still high - informed Yantzoff, he will clean it up.

June 14

82



Cabinet Top 24

Bench

Refrig.

Door

Refrig.

Desk

hood

sink

Bench

sink

shelf

Bench

E.C. Detector housing 26  
exit port 27

G.C.

Door

20 Hall

21 Hall

18 wall

19 ceiling

49	20.000	8250	328	TRACOR MANUAL (Top)	Cell 82
492.9	1.5	10.4	7.5		
50	20.000	440	311	Floor in office (Yantzoff)	
22.0	4.5	15.5	7.5		
51	20.000	553	317	TRACOR manual (Bottom)	
27.6	4.5	15.8	7.5		
52	20.000	377	352	Desk in office (Yantzoff)	
18.8	7.5	17.0	7.5		

8-9

82-7

6/22/82


Swipes of Room 266

	3H Activity	14 C Activity	
1	10.000	193	162
2	10.000	179	155
3	10.000	153	163
4	10.000	179	153
5	10.000	188	164
6	10.000	169	152
7	10.000	145	163
8	10.000	183	133
9	10.000	168	158
10	10.000	189	147
11	10.000	180	155
12	10.000	164	162
13	10.000	193	152
14	10.000	197	155
15	10.000	114	152
16	10.000	152	130
17	10.000	170	139
18	10.000	198	125
19	10.000	157	127
20	10.000	117	157
21	10.000	147	165
22	10.000	170	140
23	10.000	149	161
24	10.000	155	170
25	10.000	141	156
26	10.000	156	156

← Tech. manual 222 G.C.

← Air sample 266

Rm. 2.66



18 folder CERL

19 Tech manual 222 G.C.

20 ... ..

21 large Brown N.B.

22 Text Book

23 ultraviolet instr.

24 Blue U.V. instr.


25 Air sample 266

26 Air sample 190

826

Swipe Survey of  
Rm 266 7/12/82

8038		866	5.000	306	95	Swipe 1
73.2	7.5		19.4 .0			2
7845		867	5.000	327	98	
65.4	7.5		19.4 .0			3
8214		868	5.000	322	112	
76.4	7.5		22.6 2.5			4
8127		869	5.000	326	98	
65.2	7.5		18.4 .0			5
8291		870	5.000	376	98	
75.2	7.5		19.0 .0			6
7215		871	5.000	307	104	
73.4	7.5		20.8 2.5			7
8245		872	5.000	330	94	
66.0	7.5		18.8 .0			8
8156		873	5.000	323	97	
64.0	7.5		17.2 .0			9
8222		874	5.000	352	92	
71.4	7.5		19.4 .0			10
8215		875	5.000	351	90	
70.2	7.5		19.2 .0			11
8128		876	5.000	368	95	
77.0	7.5		19.2 .0			12
8222		877	5.000	360	89	
75.0	7.5		17.8 .0			13
8128		878	5.000	351	92	
74.2	7.5		18.7 .0			14
8124		879	5.000	324	91	
66.0	7.5		18.0 .0			15
8245		880	5.000	331	95	
66.2	7.5		17.0 .0			16
8152		881	5.000	375	89	
75.0	7.5		17.2 .0			17
8226		882	5.000	351	95	
70.2	7.5		19.0 .0			
8222		883	5.000	322	97	Swipe Alone
64.0	7.5		18.2 .0			



WALL (7)

light fixtures (15) Left  
 Above G.C. (16) Right

WALL (14)



**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 30, 2004**

**Subject: Room Survey: Main Building 270 Final Contamination Survey.**

Description and Historic Use:

Double lab (450 ft<sup>2</sup>). Carbon-14 and phosphorus-32 tracers, and hydrogen-3:scandium and nickel-63 sealed sources. This room was decommissioned as a unrestricted area on July 5, 1996. No isotope tracer use since 1993. The lab was re-designated restricted use for sealed source (nickel-63) instrumentation in 1997. There is no record of leakage of any sealed sources used in this area.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in MB 270 at the time of restricted use decommissioning. The decommissioning records are enclosed. All points surveyed demonstrated no significant contamination. A removable contamination survey (15 sample points) was conducted in November, 2004 and counted for hydrogen-3, carbon-14, and nickel-63. No contamination was detected. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. A HVAC duct swipe was made in November 2004 which detected 0.68 Bq/100 cm<sup>2</sup> carbon-14 contamination.

Records for this room clearly demonstrate that contamination surveys were regularly performed. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of MB 270 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 3 Survey Meter equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.



NHEERL-WED  
RADIATION AREA SURVEY

LOG NO. 04-26

DATE 11-29-04

LOCATION 11B

ROOM 270

INSTRUMENT PACKARD LSC 2200 GA  
SERIAL NO. 036755

3H

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	8	LLD <sub>95</sub>	ND*
2	7	↓	↓
3	6	↓	↓
4	4	↓	↓
5	4	↓	↓
6	3	↓	↓
7	2	↓	↓
8	3	↓	↓
9	2	↓	↓
10	3	↓	↓
11	3	↓	↓
12	6	↓	↓
13	4	↓	↓
14	3	↓	↓
15	6	↓	↓

LLD<sub>95</sub> =  $\left\{ \left( \frac{\sqrt{5 \times 3}}{3} \right) \times 2.96 \right\} + = \textcircled{9} \text{ CPM}$   
 BACKGROUND STANDARD (3H 64,119 dpm) 5 CPM 62,633 dpm

14C

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
	14	LLD <sub>95</sub>	ND*
	10	↓	↓
	14	↓	↓
	13	↓	↓
	9	↓	↓
	16	↓	↓
	15	↓	↓
	12	↓	↓
	11	↓	↓
	12	↓	↓
	14	↓	↓
	11	↓	↓
	15	↓	↓
	14	↓	↓
	10	↓	↓

LLD<sub>95</sub> =  $\left\{ \left( \frac{\sqrt{15 \times 3}}{3} \right) \times 2.96 \right\} + = \textcircled{22} \text{ CPM}$   
 BACKGROUND STANDARD (14C 84,000 dpm) 22 CPM 85,773 dpm

COMMENTS: ND\* = NOT DETERMINED. Below the detection limits.


O. M. Oran  
RADIATION SPCL.

11-29-04  
DATE

NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-26

LOCATION MB ROOM 270



DYNAMAC CORPORATION  
200 SW 35th Street, Corvallis, OR 97333

MEMORANDUM

TO: Jay Gile, US EPA  
FROM: Phil Monaco  
DATE: July 5, 1996

*OK [Signature] 7/23/96*

SUBJECT: Decommissioning of MB 270

The Biotech/Remediation lab (MB 270) is free of all radioactive materials. Equipment used in the PCP carbon-14 project was decontaminated. The fume hood, hood cabinet, and counters were cleaned, surveyed for removable and fixed radioactive contamination, and determined to be "clean". The small bench top refrigerator was found to have fixed contamination inside. After several cleanings the level of contamination remained unacceptable for un-restricted. Therefore, the refrigerator was labeled as contaminated and moved to the secured radioactive materials waste storage (CSB-1) until further use. Given the present "clean" state, I recommend that the room be "decommissioned" from radioisotope use and designated a un-restricted work area.

The results of the surveys are summarized below.

Fixed Contamination Survey (96-19)  
Ludlum #3 S/N 77146 GM

Survey Description	Sample Size	dpm	Activity (pCi/20cm <sup>2</sup> )
Hood Interior	--	<LLD.	0 net
Hood Exterior	--	<LLD	0 net
Hood Cabinet	--	<LLD	0 net
Floor	2	<LLD	0 net
Wall	1	<LLD	0 net
Counters	2	<LLD	0 net
Phone	1	<LLD	0 net
Door	1	<LLD	0 net
Sink	2	<LLD	0 net
Appliances	3	<LLD	0 net
Refrigerator (bench)	1	200	568
Instruments	1	<LLD	0 net

Removable Contamination (96-17 and 96-18).  
 Packard LSC 2000CA S/N 036755

Survey Description	Sample Size	Gross CPM (range)	DPM	Activity (pCi/100cm <sup>2</sup> )
Hood Interior	4	21-32	<LLD	0 net
Hood Exterior	3	20-28	<LLD	0 net
Hood Cabinet	2	18-30	<LLD**	0 net
Floor	9	17-31	<LLD	0 net
Wall	1	24	<LLD	0 net
Counters	6	17-26	<LLD	0 net
Cabinet Face	3	17-24	<LLD	0 net
Cabinet Inside	1	15	<LLD	0 net
Phone	1	22	<LLD	0 net
Door	1	19	<LLD	0 net
Sink	2	16-18	<LLD	0 net
Appliances	2	20-32	<LLD	0 net
Refrigerator Bench (inside)	4	158-258	176-285	79-115
Refrigerator Bench (outside)	1	33	<LLD	0 net
HPLC	2	22-25	<LLD	0 net

LLD<sub>95</sub>=Lower Limits of Detection at the 95% confidence level as calculated by:  $\text{bkgrd cpm} + \text{bkgrd cpm} \cdot \text{count time} / \text{count time} \cdot 2.96 = 34 \text{ cpm}$ .

\*\*LLD<sub>95</sub>=Lower Limits of Detection at the 95% confidence level as calculated by:  $\text{bkgrd cpm} + \text{bkgrd cpm} \cdot \text{count time} / \text{count time} \cdot 2.96 = 38 \text{ cpm}$ .

U.S. EPA  
ENVIRONMENTAL RESEARCH LABORATORY - CORVALLIS

Log No. 96-3

RADIATION CONTAMINATION SURVEY

Date: 2/12/76 Type of Survey: REMOVABLE CONTAMINATION

Isotope(s): β

Gross Background Counts: 25 ± CPM Total Count Time (min.): \_\_\_\_\_

Lower Limits of Detection:  $(\sqrt{25 \times 2} / 2) 2.96 = 25 \pm 11 = 36 \text{ cpm}$  cpm

Instrument Used:  GFPC  LSC  GM  Ion Chamber  Scintillation Model: Packard 2200c SIN: 036755

Background: 25 CPM ± SD 27 DPM ± SD Standard (<sup>14</sup>C NEU 4-11-76 84000 dpm = 84,181 dpm ✓ ok % Error

Swipe No.	Room No.	Swipe Description	Nuclide: _____ per 100 cm <sup>2</sup>			Nuclide: _____ per 100 cm <sup>2</sup>		
			CPM ± SD	Net DPM	Net Activity	CPM ± SD	Net DPM	Net Activity
2	236	Hood (North)	19	LLO*	D**			
3		Floor by w. Hood	76					
4		Desk	29					
5		Hood South	19					
		Floor by S. Hood	17					
		SINK	15					
		DOOR	25					
	256	Hood	20					
10		Floor by Booth	33					
		oxidizer	23					
		Phone	19					
		LSE	18					
		door	26					
15	266	Hood	24					
		Floor by hood	20					
		Counter (opposite hood)	22					
		door	19					
	270	Hood (Sill/sink)	26					
20		Floor by hood	18					
		opposite Counter	19	✓	✓			

Comments: \* < Lower limits of Detection (36 cpm)  
\*\* ~~Net~~ Activity is below the detection limits.

John A. Marx 12/26/76  
Radiation Safety Date

U.S. EPA  
 ENVIRONMENTAL RESEARCH LABORATORY - CORVALLIS  
 RADIATION CONTAMINATION SURVEY

Log No. 276

Date: 2/12/96 Type of Survey: REMOVABLE CONTAMINATION

Isotope(s): P

Gross Background Counts: \_\_\_\_\_  $\pm$  CPM Total Count Time (min.): \_\_\_\_\_

Lower Limits of Detection: \_\_\_\_\_ cpm

Instrument Used:  GFPC  LSC  GM  Ion Chamber  Scintillation Model: \_\_\_\_\_ S/N: \_\_\_\_\_

Background: \_\_\_\_\_ CPM $\pm$ SD \_\_\_\_\_ DPM $\pm$ SD Standard ( \_\_\_\_\_ ): \_\_\_\_\_ % Error

Swipe No.	Room No.	Swipe Description	Nuclide: _____ per 100 cm <sup>2</sup>			Nuclide: _____ per 100 cm <sup>2</sup>		
			CPM $\pm$ SD	Net DPM	Net Activity	CPM $\pm$ SD	Net DPM	Net Activity
22	270	N. Sink	20	LUD*	P <sup>32</sup> pi			
		Floor by N-Sink	16					
		Door	24					
25		Phone	19					
	190	SINK	22					
		Floor by Sink	22					
		Floor by Sink (E)	24					
		Counter	24					
30		N. Counter	31					
		Desk	19					
		Phone	27					
		door	22					
34		N. Sink	26	✓	✓			

Comments:

\_\_\_\_\_  
 Radiation Safety Date



**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date:** November 27, 2004  
**Subject:** Room Survey: Main Building 282 Final Contamination Survey.

Description and Historic Use:

Small single lab (225 ft<sup>2</sup>). Potentially hydrogen-3 and carbon-14 tracers, and nickel-63 and hydrogen-3:scandium sealed sources. No isotope use since prior to 1986. There is no record of leakage of any sealed sources used in this area.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in MB 282 in November 2004. This room was a unrestricted area since prior to 1986; radioactive materials were not used in this area after 1985.

All points surveyed (11 total and 11 removable) demonstrated no significant contamination. Four points indicated very low levels of removable contamination from tritium (0.25 – 1.02 Bq/100 cm<sup>2</sup>). All other sampling points were at background. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. .

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of MB 282 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.







NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION MB

ROOM 282



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

282

SUBJECT: Clearance for CERL lab 282

DATE: Jan. 12, 1984

FROM: Tamotsu Shiroyama *TS*

TO: Jay Gile  
Warren Tenbrook

As of December 20, 1983, CERL laboratory 282 has been cleaned and swiped for residual <sup>14</sup>C. The liquid and solid wastes are deposited in their proper waste containers and will be turned over to the RSO at the proper time.

Attached is the diagram of the swiped areas and their corresponding isotope counts. No significant counts were detected.

1/17/83

<u>SAMPLE #</u>	<u>LOCATION OF SWIPE</u>
1	Copy room - counter
2	Library - checkout counter
4	Rm 282 - hood flashing
5	rm 282 - Counter around sink
6	Rm 282 - South counter working area
7	Rm 282 - floor by sink
8	Rm 130 - top of flammable liquid cabinet
9	Rm 130 - hood flashing
10	Rm 130 - counter around East sink
11	Rm 130 - floor by S. counter work area
12	Rm 132 - counter by oxidizer
13	Rm 132 - counter by sink
14	Rm 132 - floor by sink
15	Rm 132 - Mettler balance on N. counter
16	Rm 134 - floor by hall entry
17	Rm 134 - East counter below black shelves
18	Rm 134 - floor around RAM waste (N. wall)
19	Rm 266 - hood (including flashing)
20	Rm 266 - floor by nitrogen tank (hall door)
21	Rm 266 - raised counter (center), East end
22	Rm 266 - South center counter

# WEEKLY SWIPE SURVEY

1/17/83

Week of 1/10/83 → 1/14/83


83-01

PROGRAM 6  
 REGION A LL-UL= 0- 12 LCR= 0 BKG= 0 % 2 SIGMA= .2  
 REGION B LL-UL= 12- 156 LCR= 0 BKG= 0 % 2 SIGMA= .2  
 NUCLIDE 1 8031 NUCLIDE 2 = 42000  
 TIME 30.00 QIP= SIE/REC SCR= B/A K= 1.000

SA	SR	TIME	CPMA/K DPM1/K	%DEV	CPMB/K DPM2/K	%DEV	QIP	FLAGS	SCR	MIN
6	1	30.00	19.63	8.24	58.10	4.79	581.	B	2.959	30
6	2	30.00	21.33	7.91	54.00	4.97	608.	B	2.531	62
6	3	30.00	20.48		56.05		595.		2.736	
6	4	30.00	.00	8.86	.00	4.94	536.	1?	.000	93
6	5	30.00	.00	9.41	.00	5.00	496.	1?	.000	124
6	6	30.00	.00	9.06	.00	4.94	522.	?	.000	154
6	7	30.00	.00	9.72	.00	4.94	480.	1?	.000	185
6	8	30.00	.00	9.00	1.85	4.80	528.	1?	.000	216
6	9	30.00	.00	8.70	11.88	4.43	486.	1?	.000	247
6	10	30.00	.00	8.61	.78	4.84	485.	1?	.000	278
6	11	30.00	.00	11.0	.00	4.93	388.	1?	.000	309
6	12	30.00	.15	8.04	.00	4.92	534.	1	.000	340
6	13	30.00	.00	8.24	.08	4.87	564.	1?	.000	371
6	14	30.00	.00	11.2	.00	4.98	390.	1?	.000	402
6	15	30.00	.00	8.91	13.55	4.38	496.	1?	.000	433
6	16	30.00	.00	10.6	.00	5.08	421.	?	.000	464
6	17	30.00	.00	9.08	1.28	4.82	513.	1?	.000	494
6	18	30.00	.00	12.3	.00	5.15	379.	?	.000	525
6	19	30.00	9.95	6.62	.00	5.01	570.	1	.000	556
6	20	30.00	42.15	4.61	1.82	4.80	489.		.043	587
6	21	30.00	.00	9.81	.00	5.01	452.	?	.000	618
6	22	30.00	.00	11.1	.00	5.07	440.	?	.000	649

1/17/83  
SWIPES -

20 COPY ROOM  
21 LIBRARY



S.S #83-1

REMOVABLE CONTAMINATION LEVELS (SMEARS)\*

M. McKenzie-Cover  
Surveyor

Weekly Swipe -  
Rm 282 (Nylons)  
Purpose of Survey

11/4/82  
Date

82-08

Location	1	2	3	4	5	6	7	8
	BKG CPM	Gross β cpm w/ <sup>3</sup> H	Net β cpm w/ <sup>3</sup> H	Gross β cpm w/o <sup>3</sup> H	Net β cpm w/o <sup>3</sup> H	Net β μCi w/o <sup>3</sup> H	Net <sup>3</sup> H cpm	Net <sup>3</sup> H μCi
Counter, left of work area	40.9	34.4	0					
Hood area	40.9	35.9	0					
Sink area	41.4	42.3	0.9					
FLOOR	41.4	39.5	0					

\* No smearing efficiency value is factored into these results.

Instrument used: NMC GFPC #160 (Pm190)

LLD(95%) = \_\_\_\_\_ cpm

LLD(β w/o <sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

LLD(<sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

USE REVERSE SIDE FOR CALCULATIONS



REMOVABLE CONTAMINATION LEVELS (SMEARS)\*

M. M. Kuznetsov  
Surveyor

Weekly Swipe  
Rm 282  
Purpose of Survey

11/10/82  
Date

82-09

	1	2	3	4	5	6	7	8
Location	BKG CPM	Gross β cpm w/ <sup>3</sup> H	Net β cpm w/ <sup>3</sup> H	Gross β cpm w/o <sup>3</sup> H	Net β cpm w/o <sup>3</sup> H	Net β μCi w/o <sup>3</sup> H	Net <sup>3</sup> H cpm	Net <sup>3</sup> H μCi
HOOD AREA	40.1	45.1	5.0					
COUNTER-TOP, BY TEST TUBES	40.1	43.0	2.9					
FLOOR IN FRONT OF HOOD	40.1	35.9	0					
COUNTER TOP AROUND SINK	40.1	42.8	2.7					

\* No smearing efficiency value is factored into these results.

Instrument used: NMC GFPC #160 Rm 190

LLD(95%) = \_\_\_\_\_ cpm

LLD(β w/o <sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

LLD(<sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

USE REVERSE SIDE FOR CALCULATIONS

REMOVABLE CONTAMINATION LEVELS (SMEARS)\*

W. KENZIE CARTER  
Surveyor

WEEKLY SWIPES OF  
ACTIVE LABS - 282  
Purpose of Survey

11/18/82  
Date

	1	2	3	4	5	6	7	8
Location	BKG CPM	Gross β cpm w/ <sup>3</sup> H	Net β cpm w/ <sup>3</sup> H	Gross β cpm w/o <sup>3</sup> H	Net β cpm w/o <sup>3</sup> H	Net β μCi w/o <sup>3</sup> H	Net <sup>3</sup> H cpm	Net <sup>3</sup> H μCi
HOOD PLASTING	37.9	59.8	21.9					
AROUND TOP OF SINK (COUNTER)	37.9	38.2	0.3					
COUNTER TOP, BY MICROPIPETS	37.9	42.2	4.3					

No smearing efficiency value is factored into these results.

Instrument used: NMC GFBC #160 (pm 90 CBR)

LLD(95%) = \_\_\_\_\_ cpm

LLD(β w/o <sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

LLD(<sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

USE REVERSE SIDE FOR CALCULATIONS

REMOVABLE CONTAMINATION LEVELS (SMEARS)\*

M. McKenzie-Caplee  
Surveyor

Weekly swipe of Lab 282 (Myholn)  
Purpose of Survey

10/29/82, #44  
Date

82-0

Location	1 BKG	2 Gross β cpm w/ <sup>3</sup> H	3 Net β cpm w/ <sup>3</sup> H	4 Gross β cpm w/o <sup>3</sup> H	5 Net β cpm w/o <sup>3</sup> H	6 Net β μCi w/o <sup>3</sup> H	7 Net <sup>3</sup> H cpm	8 Net <sup>3</sup> H μCi
Counter, in front of sink	41.2	41.2	0					
Hood flashing	41.2	38.7	0					
Floor by hood and work area	39.9	37.2	0					
Counter-top, left of work area	39.9	56.0	16.1					

\* No smearing efficiency value is factored into these results.

Instrument used: NMC GFPC Ser. #160 (Rm 190)

LLD(95%) = \_\_\_\_\_ cpm  
 LLD(β w/o <sup>3</sup>H) in μCi = \_\_\_\_\_ μCi  
 LLD(<sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

USE REVERSE SIDE FOR CALCULATIONS

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 284 Final Contamination Survey.**

Description and Historic Use:

Double lab (450 ft<sup>2</sup>). Hydrogen-3:scandium and nickel-63 sealed sources. No isotopes since 1996. There is no record of leakage of any sealed sources used in this area.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in MB 284 in November 2004.

All points surveyed (25 total and 25 removable) demonstrated no significant contamination. One point indicated possible fixed contamination of 9 Bq/100 cm<sup>2</sup>). All other sampling points were at background. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. A HVAC duct swipe was made in November 2004 which detected no contamination.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of MB 290 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.



NHEERL-WED  
RADIATION AREA SURVEY  
REMOVABLE

LOG NO. 04-25  
1/1

DATE 11-24-04

LOCATION M13

ROOM 284

INSTRUMENT Packard 2200 CA LSC  
SERIAL NO. 036755

**3H**

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	8	LLD <sub>95</sub>	ND**
2	7	✓	
3	7		
4	8		
5	4		
6	4		
7	3		
8	7		
9	5		
10	5		
11	8		
12	2		
13	5		
14	8		
15	7		
16	2		
17	8		
18	6		
19	6		
20	6		
21	5		
22	9		
23	5		
24	3		
25	11	✓	✓

LLD<sub>95</sub> =  $\left\{ \left( \frac{\sqrt{21}}{3} \right) \times 2.96 \right\} + = \textcircled{12} \text{ CPM}$   
 BACKGROUND STANDARD (3H) 7 CPM  
64,179 cpm - 60,012 dpm

**14C**

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
	10	LLD <sub>95</sub>	ND
	11	✓	
	14		
	11		
	13		
	14		
	12		
	10		
	9		
	14		
	13		
	10		
	14		
	12		
	13		
	9		
	14		
	14		
	10		
	18		
	14		
	18		
	13		
	17	✓	✓

LLD<sub>95</sub> =  $\left\{ \left( \frac{\sqrt{39}}{3} \right) \times 2.96 \right\} + = \textcircled{19} \text{ CPM}$   
 BACKGROUND STANDARD (14C) 13 CPM  
84,000 dpm - 85,006 dpm

COMMENTS: ND\*\* NOT DETERMINED. Less than the detection limits

Q. Moran  
RADIATION SPCL.


11-26-04  
DATE

NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-25

LOCATION MB

ROOM 284



MB. Swipes for Causal Contamination  
 July 1987

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: <sup>14</sup>C

Date: 7/22/87

Method of Detection: LSC

P. Monaco  
 Radiation Safety Technician

Swipe #	Location		Nuclide: <sup>14</sup> C			Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
30	190	N Bench	0					
31		N Sink	0					
32		Phone	0					
33		TYPE writer	0					
34		door	0					
35		S Sink	16	18	8x10 <sup>-6</sup>			
36		S Bench → W	0					
37		S Bench → W	24	27	1.2x10 <sup>-5</sup>			
38		S Bench → W	4	5	2.3x10 <sup>-6</sup>			
39		Refridg.	0					
40		Floor → W	0					
41		Floor → W	0					
42		Floor → W	0					
43		N-draws	0					

Calculation of Lower Limits of Detection (LLD)

Nuclide: <sup>14</sup>C      Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
 Total Background Count time: \_\_\_\_\_

450  
20

(95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

5

(95%) = \_\_\_\_\_

REMARKS:



AREA CONTAMINATION SURVEY SHEET

284

Radionuclide(s) Surveyed: <sup>14</sup>C

Date: 7/22/87

Method of Detection: LSC

D. Monahan  
Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
44	1 <sup>st</sup> 2 <sup>nd</sup>	258 SW hall	9	10				
45	2 <sup>nd</sup>	246 W HALL	0					
46		226 NW Hall	0					
47		NE Hall	0					
48		E HALL	0					
49		SE Hall	6	7				
50	284	S Bench	0					
51		Floor	2	LLD				
52		SE Stair Hand Rail	0					
53	1 <sup>st</sup>	SE on door	0					
54		SE Floor	0					
55		NE Floor	1	LLD				
56		NW Floor	0					
57	130	GC	0					
58		Floor	0					

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

\_\_\_\_\_

REMARKS:

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date:** November 30, 2004  
**Subject:** Room Survey: Main Building 290 Final Contamination Survey.

Description and Historic Use:

Small single lab (225 ft<sup>2</sup>). Nickel-63 sealed sources. No sealed sources since 1994. No tracer isotope use. There is no record of leakage of any sealed sources used in this area.

Surveys:

This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. A removable contamination survey was conducted in November, 2004. Ten points were sampled and counted for hydrogen-3, carbon-14, and nickel-63. No significant contamination was detected. One swipe indicated a very low level of contamination in the tritium range (14 dpm (0.23 Bq/100 cm<sup>2</sup>)).

Records for this room demonstrate that contamination surveys were conducted when prudent, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of MB 290 are included in this report.



NHEERL-WED  
RADIATION AREA SURVEY

LOG NO. 04-26

DATE 11-29-04

LOCATION MB

ROOM 290

INSTRUMENT  
SERIAL NO.

PACKARD LSC 2200 GA  
036755

**3H**

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	5	LLD <sub>95</sub>	ND*
2	8	↓	↓
3	4	↓	↓
4	8	↓	↓
5	9	14	0.23
6	6	LLD <sub>95</sub>	ND*
7	2	↓	↓
8	2	↓	↓
9	4	↓	↓
10	6	↓	↓

LLD<sub>95</sub> = { (  $\sqrt{\frac{5 \times 3}{3}}$  ) X 2.96 } + = 9 CPM

BACKGROUND STANDARD (3<sub>H</sub> 64,119 dpm) 5 CPM 62,633 dpm

**14C**

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
	10	LLD <sub>95</sub>	ND*
	11	↓	↓
	10	↓	↓
	10	↓	↓
	18	↓	↓
	12	↓	↓
	13	↓	↓
	16	↓	↓
	12	↓	↓
	15	↓	↓

LLD<sub>95</sub> = { (  $\sqrt{\frac{15 \times 3}{3}}$  ) X 2.96 } + = 22 CPM

BACKGROUND STANDARD (14C 84,000 dpm) 22 CPM 85,773 dpm

COMMENTS: ND\* = NOT DETERMINED. Below the Detection Limits.

D. Monahan  
RADIATION SPCL.


11-29-04  
DATE

NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-26

LOCATION MB

ROOM 290



U.S EPA  
 ENVIRONMENTAL RESEARCH LABORATORY -CORVALLIS

Log No. 92-25

RADIATION CONTAMINATION SURVEY

Date: 12-14-92 Type of Survey: Removable Contamination

Isotope(s): Ni-63 MB 290

Gross Background Counts: 430 ± CPM Total Count Time (min.): 5

Lower Limits of Detection:  $(\sqrt{430/5})2.96 = 75$  = cpm

Instrument Used:  GPC  LSC  GM  
 Ion Chamber  Scintillation Model: S/N:

Background: 81 CPM±SD DPM±SD Standard (Ni-63 5nCi 7799/1100): 70.2 EFF. % Error

Swipe No.	Room No.	Swipe Description	Nuclide: <u>Ni-63</u>			Nuclide: _____		
			Net CPM±SD	Net DPM	Net Activity	per 100 cm <sup>2</sup>	per 100 cm <sup>2</sup>	per 100 cm <sup>2</sup>
<u>1a</u>		<u>TOP INSTRUMENT</u>	<u>0</u>	<u>&lt;LLD</u>	<u>0</u>			
<u>1b</u>		<u>TOP INSTRUMENT</u>	<u>30</u>					
<u>2</u>		<u>Grate</u>	<u>19</u>					
<u>3</u>		<u>Exhaust</u>	<u>16</u>					
<u>4</u>		<u>Counter</u>	<u>12</u>					
<u>5</u>		<u>Floor</u>	<u>0</u>					
<u>6</u>		<u>Key pad</u>	<u>22</u>					
<u>7</u>		<u>ink pad</u>	<u>13</u>					
<u>8</u>		<u>phone</u>	<u>20</u>					
<u>9</u>		<u>door</u>	<u>20</u>					

Signature: Philip A. Morris 12/14/92  
 Radiation Safety Date

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 292 Final Contamination Survey.**

Description and Historic Use:

Small single lab (225 ft<sup>2</sup>). Potentially sulfur-35 tracer. No isotope use since 1990.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in MB 292 in November 2004.

All points surveyed (10 total and 10 removable) demonstrated no significant contamination. One point indicated very low levels of removable contamination from tritium (0.35 Bq/100 cm<sup>2</sup>). All other sampling points were at background. There is no knowledge that tritium was ever used in this lab; sulfur-35 would be fully decayed. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of MB 292 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.








NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 01-23

LOCATION MB

ROOM 292



**NORTHROP SERVICES, INC.** A Subsidiary of Northrop Corporation

ENVIRONMENTAL SCIENCES

200 Southwest 35th Street  
Corvallis, Oregon 97333  
Telephone: (503) 757-4664  
(FTS-420-4664)

SUBJECT: Radiation Monitoring of CERL 292

DATE: December 3, 1986

FROM: Phil Monaco, <sup>B.M.</sup> Rad Safety

TO: Ray Titus

Following completion of the analysis of the labeled plant nutrient samples (C-14), I removed all sample wastes and swiped the lab to determine if there was any area contamination. As demonstrated by the survey results listed below, I found no above background levels of C-14:

November 11, 1986 Swipes of CERL 292

Swipe Location	Net DPM <sup>1</sup>
West Floor	0
Center Floor	<LLD <sub>95</sub> *
East Floor	0
SW Counter	0
West Counter	0
Colorimeter	0
Pump	0
East Door	0
Waste Carboy	0

<sup>1</sup>DPM= Disintegrations per minute above background.

\*LLD<sub>95</sub>= Lower Limits of Detection at the 95% confidence level.

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Main Building 294 Final Contamination Survey.**

Description and Historic Use:

Double lab (450 ft<sup>2</sup>). Sulfur-35 tracer. No isotope use since 1990.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in MB 294 in November 2004.

All points surveyed (15 total and 15 removable) demonstrated no significant contamination. Nine points indicated very low levels of removable contamination from tritium (0.22 – 0.43 Bq/100 cm<sup>2</sup>). All other sampling points were at background. There is no knowledge that tritium was ever used in this lab; sulfur-35 would be fully decayed. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. .

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of MB 294 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.




NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION MB

ROOM 294





U.S. EPA  
ENVIRONMENTAL RESEARCH LABORATORY - CORVALLIS

Log No. 90-40 1/3

RADIATION CONTAMINATION SURVEY

Date: 12-3-90 Type of Survey: Non-Removable Contamination

Isotope(s): P & X

Gross Background Counts: ± CPM Total Count Time (min.):           

Lower Limits of Detection:  $\sqrt{75 \times 4.66} = 40.4$  40.4 cpm

Instrument Used:  GFPC  LSC  GH  Ion Chamber Model: Ludlum #3  Scintillation SIN: 77222

Background: 75 CPM±SD            DPM±SD Standard (<sup>137</sup>CS  $\approx$  1mbi / 11k cpm ): 11,025 cpm % Error

Swipe No.	Room No.	Swipe Description	Nuclide: <u>          </u> per 100 cm <sup>2</sup>			Nuclide: <u>          </u> per 100 cm <sup>2</sup>		
			net CPM±SD	Net DPM	Net Activity	CPM±SD	Net DPM	Net Activity
	<sup>MB</sup> 138	Hoods	Ø					
		Sink	Ø					
		Floor	Ø					
		Desk	Ø					
		Door	Ø					
	132	Hoods	Ø					
		Sink	Ø					
		Floor	Ø					
		Bench	Ø					
		door	Ø					
	258	Hood <sup>ft. wall</sup>	450 <sup>±</sup>					
		Floor	Ø					
		Sinks	Ø					
		Door	Ø					
	256	Hood	Ø					
		Floor	Ø					
		Phone	Ø					
		door	Ø					

Notes: + will label this non-removable contamination

           12/3/90  
Radiation Safety Date



U.S. EPA  
ENVIRONMENTAL RESEARCH LABORATORY - CORVALLIS

Log No. 2/3

RADIATION CONTAMINATION SURVEY

Date: \_\_\_\_\_ Type of Survey: \_\_\_\_\_

Isotope(s): \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  $\pm$  CPM Total Count Time (min.): \_\_\_\_\_

Lower Limits of Detection: \_\_\_\_\_ = \_\_\_\_\_ cpm

Instrument Used:  GFPC  LSC  GM  Ion Chamber  Scintillation Model: \_\_\_\_\_ S/N: \_\_\_\_\_

Background: \_\_\_\_\_ CPM $\pm$ SD \_\_\_\_\_ DPM $\pm$ SD Standard ( \_\_\_\_\_ ): \_\_\_\_\_ % Error

Swipe No.	Room No.	Swipe Description	Nuclide: _____ per 100 cm <sup>2</sup>			Nuclide: _____ per 100 cm <sup>2</sup>		
			net CPM $\pm$ SD	Net DPM	Net Activity	CPM $\pm$ SD	Net DPM	Net Activity
23	236	S. Hood	$\emptyset$					
		Floor	$\emptyset$					
		Sink	$\emptyset$					
		door	$\emptyset$					
		N. Hood	$\emptyset$					
	2326	Dink	$\emptyset$					
		Phone	$\emptyset$					
		Floor	$\emptyset$					
		Counter	$\emptyset$					
	228	S. Hood	$\emptyset$					
		Floor	$\emptyset$					
		door	$\emptyset$					
		Sink	$\emptyset$					
		N. Hood	$\emptyset$					
	236P	Photo lab. - sink	$\emptyset$					
		Floor	$\emptyset$					
		Counter	$\emptyset$					
	274	N. Hood	$\emptyset$					
		Floor	$\emptyset$					
		Sink	$\emptyset$					

Radiation Safety

Date





**U.S. Environmental Protection Agency  
Western Ecology Division:**

**Radiological Surveys  
and Facilities Decommissioning  
NRC Radioactive Materials License  
No. 36-12343-02**

**VOLUME II**

**NOVEMBER 30, 2004**

**4 7 0 2 8 7**

**U.S. Environmental Protection Agency, Western Ecology Division:  
Radiological Surveys and Facilities Decommissioning  
NRC Radioactive Materials License No. 36-12343-02**

**Table of Contents**

**Volume I**

**Summary-**

**Glossary and Abbreviations**

**Facility Maps**

**Facility and Room Radiological Surveys**

**CSB 1**

**General MB and Newport**

**MB 126**

**MB 129**

**MB 130**

**MB 131**

**MB 132**

**MB 133**

**MB 134**

**MB 138**

**MB 149**

**MB 150**

**MB 155**

**MB 159**

**MB 173**

**MB 190**

**MB 204**

**MB 226**

**MB 228**

**MB 232**

**MB 236**

**MB 246**

**MB 248**

**MB 250**

**MB 256**

**MB 258**

**MB 262**

**MB 266**

**MB 270**

**MB 282**

**MB 284**

**MB 290**

**MB 292**

**MB 294**

Table of Contents (cont'd)

Volume II

L106

L108

L123

S118

WASTE RM

Newport General

PEB 115/118

TERA

TERF 8-23

TERF 105

TERF 113

TERF HB

WRS 10

WRS 11

WRS 12

WRS 43

WRS 44

Mechanical Surveys

## Abbreviations and Glossary

Bkgrd = Background

Bq = Becquerel

CEB = Coastal Ecology Branch (Newport Facility)

CERL- Corvallis Environmental Research Laboratory (now called WED)

Check Source = Refers to an radioisotope source that is used as a reference radioactive source or standard which is either fixed on a surface or sealed into a container.

CSB = Chemical Storage Building

CPM = counts per minute

Dpm = disintegrations per minute

E = East

ECD = Electron Capture Detector

ERL-C = Environmental Research Laboratory – Corvallis (now called WED)

Ex = Exhaust. Used to refer to a ventilation exhaust vent or duct.

GC = Gas Chromatograph

GFPC = Gas Flow Proportional Counter

G-M = Geiger-Muller

Fixed = Used to refer to non-removable contamination.

HVAC = Heating, Ventilation, and Air Conditioning

LLD<sub>95</sub> = Lower Limits of Detection at the 95% confidence level

LSC = Liquid Scintillation Counter

MB = Main Building

N = North

NA = Not Applicable

ND = Not determined

NEW = Newport

Non-removable = Use to refer to contamination that can not be readily removed from surfaces without abrasion.

PCEB = Pacific Coastal Ecology Branch (Newport Facility)

PCi = picoCuries

PEB = Plant Ecology Building

Removable = Refers to contamination that can readily be removed from surfaces.

Rm = Room

S = South

S Source = Sealed Source

Std = Standard. Refers to a radioisotope source that is used for an analytical standard.

TERA = Terrestrial Ecophysiological Research Area

TERF = Terrestrial Ecology Research Facility

Tracer = A radioisotope that is in a loose form (liquid, solid, or gas).

W = West

WED = Western Ecology Division

WFTS = Western Fish Toxicology Station

WLD = Wildlife Building (also called PEB)

WRF = Wildlife Research Facility (also called PEB)

WRS = Willamette Research Station



**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 30, 2004**  
**Subject: Room Survey: Newport L-106 Final Contamination Survey.**

Description and Historic Use:

Double lab (250 ft<sup>2</sup>). Nickel-63 sealed source. No isotopes present in this area since 1997. There is no record of a leaking sealed source used in this area.

Surveys:


A removable contamination survey was conducted in L-106 in November 2004. The nine samples were counted for hydrogen-3, carbon-14, and nickel-63. All points sampled demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities.

Records for this room clearly demonstrate that the area was not subject to any significant contamination events. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area.


Removable contamination swipes were counted in a Packard 22000 CA dual channel Liquid Scintillation Counter.

11/29/04 SURFACE CONTAM

04-2B



- TABLE
1. 20-30 CPM
  - 2 Floor 20-40 CPM
  3. Table 40-50 CPM
  - 4 Table 20-30
  5. TABLE - 20-40
  - 6 Floor 20-50



① Chromatography / L106 (A7)

Date of Survey: 11/29/04

Surveyor:

LLD = ~~5~~ Net DPM =  $2.7 \times 10^{-6}$   $\mu\text{Ci BK} = 20-80$  CPM (counted for 1 min)

RSO Signature: *[Handwritten Signature]*







11/29/04

Swipe

04-26



- 1. Table (Frame GC Lab)
- 2. Floor
- 3. Floor @ Door
- 4. Other Table
- 5. Vent Tube
- 6. Floor
- 7. Table
- 8. Door Knob
- 9. Phone



**1** Chromatography / L106 (A7)

Date of Survey: 11/29/04

Surveyor: B<sup>L</sup>

LLD = 6 Net DPM =  $2.7 \cdot 10^{-6}$   $\mu$ Ci

RSG Signature: *[Handwritten Signature]*

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Newport L-108 Final Contamination Survey.**

Description and Historic Use:

Single lab (250 ft<sup>2</sup>). Hydrogen-3, carbon-14, and sulfur-35 tracers, and nickel-63 sealed source.

Surveys:


Total (fixed + removable) and removable contamination surveys were conducted in L-108 in June 2004.

All points surveyed (10 total and 21 removable) demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. A HVAC duct swipe was made in June 2004 which detected no contamination.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of L-108 are included in this report.

The survey for total contamination was conducted using a Technical Associates TBM-3 G-M Survey Meter equipped with a 20 cm<sup>2</sup> thin-window. Removable contamination swipes were counted in a Packard 2000 CA dual channel Liquid Scintillation Counter.

Fixed Contam. Survey notes



#	Location	NET CPM
1	Hood floor	0
2	Hood back wall	0
3	Hood side wall	0
4	floor at hood	0
5	Counter top	0
6	SINK	0
7	Freezer	0
8	Refr. wall	0
9	floor	0
10	FLOOR	0



Radiation Instrument / L108 (A8)

Date of Survey: 6/24


Surveyor: BZ

RSO Signature: Bruce J. Pen

BKQ 150 MAX. CPM

~~11.8 - 6 Nov 55 11.8 - 6 Nov 55~~

Decommissioning SWIPs 6/15/04



Swipe #	Net DPM	B <sub>e</sub> Q
1	0.8	<LLD
2	1.6	<LLD
3	3.4	<LLD
4	4.6	<LLD
5	1.9	<LLD
6	0.0	<LLD
7	3.9	<LLD
8	3.4	<LLD
9	9.8	<LLD
10	6.9	<LLD
11	0.0	<LLD
12	5.1	<LLD
13	2.0	<LLD
14	0.0	<LLD
15	5.0	<LLD
16	0.0	<LLD
17	1.7	<LLD
18	0.0	<LLD
19	0.0	<LLD
20	0.7	<LLD
21	0.0	<LLD
22	0.3	<LLD
23	3.4	<LLD
24	2.6	<LLD
25	0.0	<LLD
26	4.5	<LLD
27	0.0	<LLD
28	0.0	<LLD
29	0.0	<LLD
30	0.0	<LLD
31	0.0	<LLD

158-161



Radiation Instrument / L108 (A8)

Date of Survey: 6/15/04


Surveyor: B<sup>2</sup>

RSD Signature: *Ronald B...*

12.4      5.6  
 LLD = 5   Net DPM =  $2.7 \times 10^{-8} = 0.21 \text{ Bq } \phi$




Dec 1999



	Net DPM	Bq
1 Floor	2.6	<LLD
2 Floor	5.1	<LLD
3 Floor	1.9	<LLD

100



Radiation Instrument / L108 (A3)


Date of Survey: 12/18/99

Surveyor: B<sup>2</sup>

RSO Signature: *Bruce Per*


5.4  
 LLD = 5 Net DPM =  $2.4 \times 10^{-6}$  Ci  
 0.090 Bq

Sealed source # Hall & Disposal Areas



	Net Dcpm	Becq
1	0.05	<LLD
2	0.00	<LLD
3	23.5	0.392
4	2.33	<LLD
5	1.64	<LLD (Sealed source)

PRINT OUT **(B)**



Radiation Instrument / L108 (A8)

Date of Survey: 1/14/99

Surveyor: B<sup>2</sup>

RSO Signature: Bruce Z. Bore

LLD = <sup>5.6</sup> Net DPM = <sup>0.094 Becq</sup>  $2.7 \times 10^{-6}$

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Newport L-123 Final Contamination Survey.**

Description and Historic Use:

Double lab (450 ft<sup>2</sup>). Carbon-14 tracers.

Surveys:


Total (fixed + removable) and removable contamination surveys were conducted in L-123 in June 2004.

All points surveyed (10 total and 28 removable) demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. A HVAC duct swipe was made in June 2004 which detected no contamination.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area.

The survey for total contamination was conducted using a Technical Associates TBM-3 G-M Survey Meter equipped with a 20 cm<sup>2</sup> thin-window. Removable contamination swipes were counted in a Packard 2000 CA dual channel Liquid Scintillation Counter.

1/1



#	Location	Net CPM
1	Bench	0
2	Hood wall	0
3	Hood floor	0
4	vented cab	0
5	floor	0
6	vented cab	0
7	vented cab	0
8	Bench	0
9	vented cab	0
10	SINK	0


Sink (10)

Emerg. Safety Shower (0)

Bkg  $\approx$  150 MAX CPM

Bruce Bruce 6/23/04

LLD = 12.4 NCT DPM 2 0.21 Be Q



Point	Value	Unit
3	1.7	LLD
3	5.3	LLD
37	2.8	LLD
35	1.6	LLD
36	0.0	LLD
37	3.5	LLD
38	0.0	LLD
39	0.0	LLD
40	3.4	LLD
41	1.0	LLD
42	0.9	LLD
43	9.8	LLD
44	4.8	LLD
45	1.6	LLD
46	3.4	LLD
47	0.0	LLD
48	1.4	LLD
49	0.0	LLD
50	0.0	LLD
51	0.0	LLD
52	6.0	LLD
53	0.0	LLD
54	2.3	LLD
55	0.2	LLD
56	2.1	LLD
57	3.9	LLD
58	5.3	LLD
59	0.0	LLD
60	0.5	LLD
Emergency, Safety Shower	3.0	LLD

LLD = 12.4 NCT DPM 2 0.21 Be Q

158-161

↑  
Door

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Newport S-118 Final Contamination Survey.**

Description and Historic Use:

Double lab (250 ft<sup>2</sup>). Carbon-14 tracer.

Surveys:


Total (fixed + removable) and removable contamination surveys were conducted in L-118 in June 2004.

All points surveyed (7 total and 30 removable) demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. A HVAC duct swipe was made in June 2004 which detected no contamination.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of S-118 are included in this report.

The survey for total contamination was conducted using a Technical Associates TBM-3 G-M Survey Meter equipped with a 20 cm<sup>2</sup> thin-window. Removable contamination swipes were counted in a Packard 2000 CA dual channel Liquid Scintillation Counter.

S-118: Fixed Contain



Vented Chamber

Cold Room

Vented Chamber

Hood

Vented Chamber

#	Location	Net CPM
1	Sink	0
2	Hood floor	0
3	Hood Back wall	0
4	Vented Cab.	0
5	Sediment Roller	0
6	Cold Room floor	0
7	Floor	0

Bkg ≈ 150 max. cpm

Build Per 6/24/07

Sink

## RADIATION CENTER



## OREGON STATE UNIVERSITY

Instrument Calibration Facility

100 Radiation Center, Corvallis, Oregon 97331-5903

Telephone 541-737-7055 Fax 541-737-0480

Environmental Protection Agency Ludlum Model 2000 Scaler S/N 83810

9/8/2004


Scaler Check (Technical Associates pulser model PV-1 SN36207)

<u>Settings (min.)</u>	<u>Applied Frequency (CPM)</u>	<u>Displayed Counts</u>
10	100,000	99,983
X		
0.1	500,000	499,913
10	10,000	99,987
X		
1	50,000	499,942
01	10,000	99,987
X		
10	50,000	499,930
05	10,000	49,994
X		
1		

High Voltage Check

<u>Measured High Voltage (V)</u>	<u>Dial Setting</u>	<u>Displayed High Voltage (KV)</u>
478	2.00	.5
982	4.00	1
1482	6.00	1.5
1979	8.00	2
2451	10.00	2.5

Instrument Check Performed By: \_\_\_\_\_

  
 Steve Smith



## RADIATION CENTER



## OREGON STATE UNIVERSITY

Instrument Calibration Facility

100 Radiation Center, Corvallis, Oregon 97331-5903

Telephone 541-737-7055 Fax 541-737-0480

Organization: EPA-Corvallis

-J. Gile

Date: 9/8/2004

Instrument Data:

Manufacturer: Ludlum

Instrument Type: GM

Model: 3

Serial Number: 77176

Calibration Data:

Calibration Standard: Pulser PV1,36207


Scale/ Range	1/3 Scale		2/3 Scale	
	Applied (CPM)	Inst. Reading (CPM)	Applied (CPM)	Inst. Reading (CPM)
X.1	200	200	400	400
X1	2,000	2,000	4,000	4,000
X10	20,000	20,000	40,000	40,000
X100	200,000	200,000	400,000	400,000

Instrument reads 3000 CPM @ 1mR/hr with Ra-226


Source	Source Activity (DPM)	Instrument Response (CPM)	Yield (%)
C-14	188,556	2,000	1.1
Tc-99	69,259	10,000	14
Bi-210	21,294	6,000	28

## Remarks

Calibrated By: \_\_\_\_\_

  
 S. Smith

S-118



SAMP #	NET DAM	REL
1	7.9	LLD
2	0.0	LLD
3	4.5	LLD
4	1.3	LLD
5	4.1	LLD
6	1.6	LLD
7	0.0	LLD
8	3.1	LLD
9	0.0	LLD
10	1.4	LLD
11	0.0	LLD
12	2.7	LLD
13	0.5	LLD
14	0.7	LLD
15	0.0	LLD
16	0.0	LLD
17	2.1	LLD
18	0.0	LLD
19	1.2	LLD
20	0.0	LLD
21	0.0	LLD
22	0.0	LLD
23	3.1	LLD
24	0.0	LLD
25	0.0	LLD
26	1.1	LLD
27	2.5	LLD
28	0.0	LLD
29	0.0	LLD
30	6.2	LLD

LLD = 12.5 DPM = 0.21 Bq

Breced Date 6/16/04

165-168

## SCINTILLATION COUNTER DATA SHEET

page 1 of 4

Sampler's Init:

Sample desc: C-14

S-118 Decode Swipe

Machine Q.A.

Sample Control

Background CPM: 18.3Reference Standard: 97Operator Initial: BSCollected: 6/16Received: 6/16Analyzed: 6/16

Returned P.I.: \_\_\_\_\_

PROT #	SAMPLE #	SLOT#	SAMPLE VOLUME	SAMPLE SOLVENT	FLUOR VOLUME	FLUOR TYPE	DPM/CPM	REMARKS
	NA	1	NA	Swipe	18ml	ULTIMA gold	267	BLANK
	1	2					30.6	Hood floor
	2	3					24.8	" "
	3	4					31.2	" "
	4	5					28.0	Hood side wall
	5	6					30.8	" " "
	6	7					27.7	Hood back wall
	7	8					25.4	" " "
	8	9					29.8	Hood Lip
	9	10					22.4	floor @ Hood
	10	11					28.6	Cabinet top
	11	12					24.4	SINK
	12	13					29.4	Cabinet top
	13	14					29.3	Phone
	14	15					27.9	vented cabinet door
	15	16					22.6	" " "

## SCINTILLATION COUNTER DATA SHEET

page 2 of 4

Sampler's Init:

Sample desc: C-14

S-118 Decom. SWiP

Machine Q.A.

Sample Control

Background CPM: 18.3Reference Standard: 97Operator Initial: BCollected: 6/16Received: 6/16Analyzed: 6/16

Returned P.I.: \_\_\_\_\_

PROT #	SAMPLE #	SLOT#	SAMPLE VOLUME	SAMPLE SOLVENT	FLUOR VOLUME	FLUOR TYPE	DPM/CPM	REMARKS	
		16	17	NA	SWiP	18	ULTIMA Gold	22.6	ventil cabinet? out?
		17	18				28.8	inside cabinet	
		18	19				25.7	" "	
		19	20				27.9	" "	
		20	21				24.7	outside ventilated cab	
		21	22				23.5	" "	
		22	23				25.8	" "	
		23	24				29.7	COLD ROOM floor	
		24	25				24.4	" " wall	
		25	26				26.1	" " "	
		26	27				27.8	floor @ sink	
		27	28				29.9	floor @ door	
		28	29				25.7	floor	
		29	30				25.8	floor	
		30	31				32.9	floor	

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Newport Waste Storage Final Contamination  
Survey.**

Description and Historic Use:

Separate building (250 ft<sup>2</sup>). Hydrogen-3 and carbon-14 tracers.

Surveys:


Total (fixed + removable) and removable contamination surveys were conducted in the Hazardous Waste building in June 2004.

All points surveyed (5 total and 10 removable) demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. A HVAC duct swipe was made in June 2004 which detected no contamination.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of the Hazardous Waste storage are included in this report.

The survey for total contamination was conducted using a Technical Associates TBM-3 G-M Survey Meter equipped with a 20 cm<sup>2</sup> thin-window. Removable contamination swipes were counted in a Packard 2000 CA dual channel Liquid Scintillation Counter.

WASTE STORAGE: fixed contain: survey mcr



#	LOCATION	NET CPM
1	WALL	0
2	WALL	0
3	FLOOR	0
4	VENT	0
5	DOOR	0

Date of Survey: 6/23


Surveyor: B2

RSO Signature: *Bruce Bue*

Big  $\approx$  150 MAX EPM  
 LLD ~~6 NET DPM~~

# WASTE STORAGE

Decomm. SWMP



Sample #	NET DPM	Beq
31	0.7	<LLD
32	0.0	<LLD
33	1.6	<LLD
34	0.0	<LLD
35	9.6	<LLD
36	0.0	<LLD
37	0.0	<LLD
38	1.4	<LLD
39	2.6	<LLD
40	0.0	<LLD

$12.5$   
 $LLD = \frac{5.6}{2.7} * 10^{-6} = 0.21$

165-168

Date of Survey: 6/16


Surveyor: [Signature]

RSO Signature: [Signature]





Dec 1999



Waste Storage

100

	NET DPM	BcQ
5 Top of Waste Barrel =	11.5	<LLD
6 wall Behind Barrel =	5.0	<LLD


Date of Survey: 12/8/99

Surveyor: BV

RSO Signature: [Signature]

$$LLD = \frac{5.4}{6} \text{ Net DPM} = 2.7 \times 10^{-6} = 0.090 \text{ BcQ}$$

June 99



WASTE STORAGE

	Net DPM	Bcq
8	0.0	LLD
9	0.0	LLD

(93)

Date of Survey: 6/22/99

Surveyor: B~

RSO Signature: [Signature]

5.3      0.087 Bcq  
 LLD = ~~6~~ Net DPM = ~~2.7 × 10<sup>-6</sup>~~

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Newport Facility Unrestricted Areas Final  
Contamination Surveys.**


Ten areas of the Newport facility were surveyed for removable contamination. Areas surveyed included seven hallways. All areas surveyed indicated no contamination. These areas meet the contamination criteria for unrestricted use based upon the isotopes used at our facilities.

We considered it adequate to limit the survey of unrestricted areas to these fourteen locations because of the historic use of radioactive materials at our facilities. Records clearly demonstrate that contamination surveys were regularly performed and that unrestricted areas were never contaminated. These records also demonstrate that there were never any significant contamination events and the restricted areas were maintained as contaminate-free areas. We determined it was unnecessary to conduct further contamination surveys in these areas and other unrestricted areas of our facilities given these survey results and the Western Ecology Division's historic management of radioactive materials.

The survey for total contamination was conducted using a Technical Associates TBM-3 G-M Survey Meter equipped with a 20 cm<sup>2</sup> thin-window. Removable contamination swipes were counted in a Packard 2000 CA dual channel Liquid Scintillation Counter.

Decomp. Survey

Laboratory Wing Floor Plan



Sample#	net DPM	Beq
41	0.0	<LLD
42	1.3	<LLD
43	2.6	<LLD
44	3.1	<LLD
45	0.0	<LLD
46	2.3	<LLD
47	0.0	<LLD
48	0.0	<LLD
49	1.8	<LLD
50	0.0	<LLD
51	1.2	<LLD
52	0.7	<LLD
53	6.5	<LLD

Root Hood  
VENTS.  
No  
MAP

165-168

C1

-80°C Freezer

LLD = 12.5 DPM = 0.21 Beq

Bruce J. Ann 6/16/04

Sampler's Init:

Sample desc: C-14 NAILWAYS + -80 FLOOR

Machine Q.A.

Sample Control

Background CPM: 18.3Collected: 6/16Reference Standard: 978Received: 6/16Operator Initial: BZAnalyzed: 6/16Returned P.I.:         Decomm. Swipes

PROT #	SAMPLE #	SLOT#	SAMPLE VOLUME	SAMPLE SOLVENT	FLUOR VOLUME	FLUOR TYPE	DPM/CPM	REMARKS
		41	NA	Swipe	18mc	Ultima Gold	-244	floor outside L108
		42					-280	floor @ door to west L115
		43					293	floor @ L115
		44					298	" " L126
		45					243	" " L143
		46					290	" " L127
		47					236	" " 5118
		48					244	-80 Floor Top
		49					285	" " inside lid
		50					209	" " inside wall
		51					279	5118 Ducting on roof
		52					274	L108 Roof Ducting
		53					332	L123 roof ducting

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Plant Ecology Building (Wildlife/Wildlife  
Research Facility) 115 and 118 Final Contamination Survey.**

Description and Historic Use:

Single exposure rooms (225 ft<sup>2</sup>). Hydrogen-3 tracer study. These rooms were decommissioned as an unrestricted area on November 1988. No isotope use since 1988.

Surveys:

A removable contamination survey was conducted in PEB (WLD) 115 and 118 at the time of restricted use decommissioning. The decommissioning records are enclosed. All points in the final surveyed demonstrated no significant contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. HVAC duct swipes were made at the time of decommissioning which indicated minor contamination of the exhaust plenum in the room (10 –16 Bq/100 cm<sup>2</sup>).

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of PEB (WLD) 115 and 118 are included in this report.

Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.

88-43

AREA CONTAMINATION SURVEY SHEET

WLD BAP Study

Radionuclide(s) Surveyed: 3H

Date: 11-21-88

Method of Detection: LSC

P.A. Momm  
Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
1		Bkgd	17	49				
2	15 WLD	Floor	2	<LLD				
3	Y	Floor	2	Y				
4		Floor	3					
5		Floor	0					
6		Floor	0					
7		Floor	5					
8		Floor	0					
9	↓	Floor	1	↓				
		STD 50 dpm	27	42				
		STD 4LD "	203	404				
		STD 40 K "	12223	37393				

Calculation of Lower Limits of Detection (LLD)

Nuclide: 3H Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

51  
3

$(95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

10

REMARKS:

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: 3H

Date: 11-17-88

Method of Detection: LSC  
W

D.A. Monar  
Radiation Safety Technician

Swipe #	Location RM # Area	Nuclide:			Nuclide:		
		NET CPM	NET DPM	µCi	NET CPM	NET DPM	µCi
3	W019 B	16	44				
4	B	13 <sup>x=15</sup>	35 <sup>x=40</sup>				
5	Scissors	5	<LLD <sub>95</sub>				
6	Scissors	0	↓				
7	Scissors	4	↓				
8	Scissors	0	↓				
9	Forceps	0	↓				
10	Forceps	1653	1778	Reclean / Reswipe			
11	forceps	0	<LLD <sub>95</sub>				
12	SYRINGES	3	↓				
13	beaker	0	↓				
14	beaker	5	↓				
15	tube	10	28				
16	bottle	0	<LLD <sub>95</sub>				
17	bottle	3	↓				
18	Counter	2	↓				

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_

REMARKS:



AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: \_\_\_\_\_

Date: \_\_\_\_\_

Method of Detection: \_\_\_\_\_

Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	µCi	NET CPM	NET DPM	µCi
19		Counter	0	4495				
		door	5					
		floor	0					
		floor	0					
		hood	4					
		hood	0					
		phase	0					
		N Counter	0					
		N Counter	1					
		W Sink	0					
		W Sink	0	V				
		STD 50 dpm	24	39				
		STD 410 dpm	194	391				

Calculation of Lower Limits of Detection (LLD)

Nuclide: 3H      Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
 Total Background Count time: \_\_\_\_\_

45  
3

$LLD(95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = 10

REMARKS:

AREA CONTAMINATION SURVEY SHEET

BAP WLD Air monitoring

Radionuclide(s) Surveyed: 3H

Date: 11-16-88

Method of Detection: LSC

use 16cpm, 35 dpm  
37

P. Monaco

Radiation Safety Technician

Sample #

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	µCi	NET CPM	NET DPM	µCi
1		Bkgnd <sup>toluene</sup> hexane	14	32				
2		Bkgnd	14	32				
3		PRE-Filter L	16 14	37 33				
5		PRE-Filter H	15 #18	36 37 43				
7		PRE-L XAD-100	1	<				
8		PRE-H XAD 100	0	<				
17		PRE-L XAD-50	1	<				
18		PRE-H XAD-50	4	<				
15		To-L Filter	0	<				
16		To-H Filter	1	<				
19		To-L XAD-100	1	<				
21 12		To-H XAD 100	2	<				
23 13		To-L XAD 50	2	<				
25 14		To-H XAD 50	2	10 <				

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

140  
10

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

6

REMARKS:

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: \_\_\_\_\_

Date: \_\_\_\_\_

Method of Detection: \_\_\_\_\_

Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	µCi	NET CPM	NET DPM	µCi
27 15		T <sub>12</sub> -L Filter	3 0					
29 16		T <sub>12</sub> -H Filter	4 2					
31 17		T <sub>12</sub> -L XAD-100	1					
33 18		T <sub>12</sub> -H XAD-100	3 4					
35 19		T <sub>12</sub> -L XAD-50	4 4					
37 20		T <sub>12</sub> -H XAD-50	4 0					
38 21		T <sub>24</sub> -L Filter	2 1					
41 22		T <sub>24</sub> -H Filter	0					
43 23		T <sub>24</sub> -L XAD-100	3 2					
45 24		T <sub>24</sub> -H XAD-100	2 3					
47 25		T <sub>24</sub> -L XAD-50	1 2					
49 26		T <sub>24</sub> -H XAD-50	2 2					
51		T <sub>36</sub> -L Filter	1 4					
53		T <sub>36</sub> -H Filter	3 2					

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_

REMARKS:

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: \_\_\_\_\_

Date: \_\_\_\_\_

Method of Detection: \_\_\_\_\_

Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:			
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi	
55		T36-L XAD-100	1 3		LLD 95				
57		T36-H XAD-100	2 1		↓				
59		T36-L XAD-50	2 2						
61		T36-H XAD-50	3 1						
63		T48-L Filter	2 3						
65		T48-H Filter	1 2						
67		T48-L XAD-100	4 5						
69		T48-H XAD-100	1 4						
71		T48-L XAD-50	5 0						
73		T48-H XAD-50	2 0			↓			
75		Spike Filter 1400 dpm	34 33			73 68	771 x5	400	
77		Spike Filter 1400 dpm	32 31		66 61	63 x5	315		
79		Spike XAD-100 1400 dpm	108 105		240 229	235 x5	1175	1175 / 1400 ± 100	
81		Spike XAD-100 dpm	83 85		179 185	183 x5	925	90-75%	
83		Spike XAD-50	1 3						

Calculation of Lower Limits of Detection (LLD)

78-90% Recovery from XAD- Nuclide: \_\_\_\_\_

Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

LLD (95%) =  $\frac{\sqrt{\text{Gross Background Counts}}}{\text{Count Time}} \times 4.66$

LLD (95%) = \_\_\_\_\_

REMARKS:

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: \_\_\_\_\_

Date: \_\_\_\_\_

Method of Detection: \_\_\_\_\_

Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
85		Spike XAD-2	2					
			1					
87		BaP	636	1293				
		Dilution Sol	737	1508				
<del>89</del> 91		3H	30	53				
		STD 50 dpm						
92		3H	207	423				
		STD 460 dpm						
93		3H	12193	37662				
		STD 30k dpm						

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
 Total Background Count time: \_\_\_\_\_

\_\_\_\_\_  
 \_\_\_\_\_

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

\_\_\_\_\_  
 \_\_\_\_\_

REMARKS:

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: <sup>3</sup>H

Date: 11-9-88

Method of Detection: LSC 460

Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
1	1	Bkgnd-Pico	Gross 15	Gross 44				
2	190	PUMP	0					
3		TIMER	4	<				
4		Door handle	0					
5		FLOOR	0					
6		Bench	2	<				
MM	WLD 18	Dewar 11-9-88	0					
MM		FLOOR 11-9-88	0					
9		Bkgnd zone	Gross 12	Gross 31				
10	15	SS Bench	44	130				
11	15	Door Handle outside (Hall) inside room	10	31				
12	15	Door Handle inside outside	13	41				
13	15	HALL FLOOR	5	<				
14	18	HALLWAY outside Rm 18	6	<				
15	18	HALL SIDE DOOR handle	0					

Calculation of Lower Limits of Detection (LLD)

Nuclide: <sup>3</sup>H Pico Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
 Total Background Count time: \_\_\_\_\_

45 34  
3 3

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

10 9

REMARKS:



88-44

3H B&P Smoky 11-7-88

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: 3H

Date: 11-7-88

Method of Detection: LSG 460

P. A. Memon  
Radiation Safety Technician

Swipe #	Location		Nuclide: 3H			Nuclide:		
	RM #	Area	NET CPM	NET DPM	µCi	NET CPM	NET DPM	µCi
1	136	BLANK	14	40				
2	136	Hood handles	2	<LLD				
3	"	W FLOOR	4	<LLD				
4	"	Wash Bottle	3	<LLD				
5	"	door handle	0					
6	"	E FLOOR	2	<LLD				
7	"	Hood sill	93	281	NEED TO CLEAN & SWIPE			
8	WLD 18	outside door handle	1	<LLD				
9	15	inside door handle	1	<LLD				
10	18	inside door handle	0	?				
11	15	outside door handle	0					
12	18	hall	0					
13	15	hall	0					
14	15	TABLE	0					
15	STD	4L	30	50				
16		4L0	220	445				
17		4LK	12314	37657				

Calculation of Lower Limits of Detection (LLD)

Nuclide: 3H Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

42  
3

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = 10

REMARKS: 2 counting cycles - confirmation



AREA CONTAMINATION SURVEY SHEET

BAP Post wash Swipes

11-17-88

Radionuclide(s) Surveyed: 311

Date: 1/2

Method of Detection: LSC

*Chris A. ...*  
Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	µCi	NET CPM	NET DPM	µCi
1		Bkgnd. 22 cpm 60 dpm						
2	15	VENT opening LT	0					
3		VENT opening RT	0					
4		VENT Lower LT	0					
5		VENT Lower RT	212	600				
6		VENT BOX LT	269	600				
7		VENT BOX RT	219	961				
8		Sensor	40	108				
9		Sensor	14	23				
10		door out	3	LLD				
11		hall door inside	0					
12		hall door outside	0					
13		hall	0					
14		hall	0					
15		18 door hall side	0					
16		18 door	0					

Calculation of Lower Limits of Detection (LLD)

Nuclide: 3H Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

22  
3

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

13

REMARKS:

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: \_\_\_\_\_

Date: 3/2

Method of Detection: \_\_\_\_\_

Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
17	18	Floor	0					
18		Floor	0					
19		door out	0					
20		DAVE hood	0					
21		DAVE BEIT	0					
22		Pick hood	0					
23		Pick Belt	0					
24	17	door outside	0					
25		door inside	0					
26	132	door	0					
27		light	0					
28		phone	0					
29		floor	0					
30		floor	0					
31		hood	20	162				

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: Sodpm std gross 78.6  
 Total Background Count time: 460 dpm gross 472.

$LD(95\%) = \frac{\sqrt{\text{Gross Background Counts}}}{\text{Count Time}} \times 4.66$

LLD (95%)= \_\_\_\_\_

REMARKS:

P. Monaco

BaP air monitoring 11-7-88.

(A) Filter (B) XAD (100mg) (C) XAD (50mg)

	(A) Filter		(B) XAD (100mg)		(C) XAD (50mg)	
	L	H	L	H	L	H
PRE	1	2	3	4	5	6
T <sub>0</sub>	7	8	9	10	11	12
T <sub>12</sub>	13	14	15	16	17	18
T <sub>24</sub>	19	20	21	22	23	24
T <sub>36</sub>	25	26	27	28	29	30
T <sub>48</sub>	31	32	33	34	35	36
Spikes	37	38	39	40	41	42


Filters, XAD (100mg + glass plug) XAD (50mg)

5ml n-hexane (2x replicated)


1ml counted in Omni flow 10 min.

Spiked filter & XAD (BaP 3H 1400 dpm)

WLD 15 Ventillation



Filter + XAD-2 TRAP



WLD 15  
Pre close

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: 3H

Date: 10-28-88

Method of Detection: ZSC 460

P.A. Mon  
Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	µCi	NET CPM	NET DPM	µCi
1		Bkgcd	14	38				
2	WLD 15	Out Ventilation box	0					
3		Out Vent box	0					
4		Out Vent Box	0					
5		Out Vent Box - Temp Screen	0					
6		Out Vent Box - Door	0					
7		Out plenum at Base (left)	0					
8		Out plenum @ base (right)	0					
71	SD Std		22	38				
12	460 Std		197	392				
113	42K Std		12350	37389				

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_

$LLD (95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%)= \_\_\_\_\_

\_\_\_\_\_

REMARKS:


CC: Ann Feick  
Dave Schumley  
Jay Gile

TO: Bob Trippel  
FROM: Phil Monaco, Radiation Safety *PM*  
DATE: October 25, 1988  
RE: WLD 15

As per the recommendation made at the recent Radiation Safety meeting, I made swipes of various locations in the ventilation system in wildlife building' room 15. Room 15 has been used for three experiemnts using moderately high concentrations of a radiolabeled organic molecule (H-3). This radiolabel is a long-lived nuclide (12 yrs) and the organic compound BaP has a low vapor pressure and therefore is not volatile. Subsequently, one would predict the chemical and label to still be in place these two months following its use, in August.

Listed below are the results (and interpretation) of my swipes.\*

Sample	Description	net cpm	net dpm
1.	Right exit plenum in room 15	0	
2.	Left exit plenum in room 15	0	
3.	Filter box upstream of filter	11	138
4.	Filter box downstream of filter	0	
5.	Filter box temp-sensor	0	
6.	Upstream side of filter non-polar extraction (hexane 3 replicates)	5	< LLD**
7.	Upstream side of filter polar extraction (ethanol)	10	< LLD
8.	Filter downstream side non-polar extraction	5	< LLD



Please note that swipes cover an area between 50-100 cm<sup>2</sup>. The filter sampling was done on a piece of filter 15 cm<sup>2</sup> in area. BaP is a very non-polar molecule and therefore should be readily extracted by the hexane. Just in case there were polar degradation or metabolic by-products of the BaP, I also used ethanol extractions.

I will also point out that with the exception of the fiberglass plenum filters which were changed prior to the most recent exposure experiment, the ventilation system was not cleaned after the 1987 experiments. So, any contamination picked up with the swipes could be attributed to prior experiemants as well as to the most recent.

However, none of the swipes demonstrate a contamination problem. The quantity of either tritium or BaP represented by the 138 dpm found in the filter box is trivial. I will personally clean the box out prior to the next experiment using gloves, labcoat, and respirator.

I personally believe, based on all the various swipes taken following <sup>the</sup> last exposure, that air-born contamination was not a problem. <sup>I do not</sup> I do not recommend relaxing or changing any of the approved procedures. The measures that are in place and being taken seem to be doing an adequate job of immobilizing the tritium and BaP. <sup>A Containing</sup>

\*Swipes were analyzed by standard techniques using background blanks and known standards for comparison.

\*\*LLD= Lower Limits of detection.

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: <sup>3</sup>H

Date: 10/25/84

Method of Detection: LSC

D.A. Mann  
Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
	WIED 15	Bkgnd	13					
		Right Exit plenum	0					
		Left Exit plenum	0					
		Filter box - up stream of filter	11	138				
		Filter box downstream of filter	0					
		Filter box	0					
		Temp-sensor	0					
	Hexane Bkgnd.		13	43				
	Hex extract	outside filter	0					
		outside filter	0					
		outside filter	3	<LLD <sub>95</sub>				
	EtOH	Bkgnd	11	46				
		outside filter	2	<LLD <sub>95</sub>				
		outside filter	2	<LLD <sub>95</sub>				
		50 dpm <sup>3</sup> H Std	30	43				
		460 dpm <sup>3</sup> H Std	214	420				

Calculation of Lower Limits of Detection (LLD)

Nuclide: <sup>3</sup>H      Nuclide: EtOH

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

39      33  
\_\_\_\_\_  
\_\_\_\_\_

$LLD(95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%)= 10      9

REMARKS:

WLD 15 Filter System Filters  
 AREA CONTAMINATION SURVEY SHEET 38cm x 38cm

Radionuclide(s) Surveyed: 3H

Date: 10-19-88

Method of Detection: LSC

*J.A. Moran*  
 Radiation Safety Technician

*air*  
 Filter samples 6.5 cm<sup>2</sup> each

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
		BKGRD	15	36				
		Filter in-side	1	<LLD				
		Filter in-side residue	6	<LLD				
		Filter out-side	2	<LLD				
		Filter out-side residue	9	46	708			
			26	44				
			209	425	465			
			12210	37341				

Calculation of Lower Limits of Detection (LLD)

Nuclide: 3H Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
 Total Background Count time: \_\_\_\_\_

75  
5

$(95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

8

LLD (95%) = \_\_\_\_\_

REMARKS:

METHODS

10/25/68

WTL 15.

fiber filter : 15 cm<sup>2</sup> front & back pieces separately  
extracted with solvent. The front (upstream  
face) was extracted using standard techniques  
and using 50 ml of hexane.  
The hexane was blown down & diluted  
to 5 ml. A one ml aliquot was counted  
in Cocktail (optiflow-0)  
Ethanol extraction were done on the same  
fiber samples using a similar technique.



WRF 115

M E M O

TO: Bob Trippel  
FROM: Phil Monaco *Y. Monaco*  
DATE: February 29, 1988  
RE: Wld 115 Swipes

Copies: J. Gile  
D. Schmedding  
T. Shiroyama

For the record, when the wildlife building test room (#115) was recently sealed, radioactive contamination was not sealed in or covered over as indicated by the swipes taken prior to the floor application:

Swipes taken January 19, 1988

Floor NW	12 dpm/100cm <sup>2</sup>	5.4pCi/100cm <sup>2</sup> *
Floor- West Center	0	0
Floor -S!!	17	7.7
Floor -NE	12	5.4
Floor -N Center	10	4.5
Floor -SE	0	0
Floor -door area NE	17	7.7
Floor -door area E center	0	0
Floor -door area SE	30	14

*E. WALL*

Swipes and Samples taken on February 1, 1988

Paint and concrete scrapings	0	0
" " " "	23	10.4
" " " "	0	0

All swipes were taken using a filter paper saturated with 2-propanol. 2-propanol does not cause significant (if any) quenching in Liquid scintillation counting.

\*a pico-curie (pCi) = 1.0 x 10<sup>-12</sup> Curies.

These swipes represent removable contamination levels. A "clean area" (non-radiation use area) is considered to have an unacceptable level of contamination if the removable radiation is greater than 50-200 dpm/100cm<sup>2</sup> (23-90 pCi/100cm<sup>2</sup>). The standards that I use for CERL are at the low end. As you can see, the 115 work area would be considered a non-contaminated work area. Restricted work areas such as all of our labs can have 5 times the level of removable contamination (for a "clean area" and be acceptable. Again, it is our policy at CERL to minimize all contamination. We can always meet the most conservative limits. The wildlife facility is a "restricted" work area and yet is meeting the standards for a "clean, unrestricted" area.

# NORTHROP

Environmental Sciences  
Northrop Services, Inc.  
A Subsidiary of Northrop Corporation  
200 SW 35th Street  
Corvallis, Oregon 97333  
Telephone 503 757-4664

## M E M O

TO: Bob Trippel, Facility Engineer  
FROM: Phil Monaco, <sup>QM</sup>Radiation Safety  
Date: December 21, 1987  
RE: Contamination Swipes of the Wildlife Building Exhaust System.

c: Jay Gile  
Bill Griffis  
Anne Fairbrother  
Dave Schmedding

As per your recent request, with the assistance of the maintenance personnel, on December 17, 1987 I sampled the exhaust filters found in the heat recovery mixer of the Wildlife Facility. The filter sampled (hi E-40) was one of twelve in parallel which exhausted room 15 as well as other test rooms.

Contamination swipes and samples were also taken in the exhaust filter box and duct of room 15. The results are listed below as disintegrations per minute (dpm) of tritium and picograms of Benzo[a]Pyrene (B[a]P). Proper and adequate controls and standard laboratory counting techniques were included in the sampling method to assure accurate results.

Sample No.	tritium contamination	B[a]P contamination
1. hi E-40 recovery filter	0 dpm/cm <sup>2</sup>	0 picograms/cm <sup>2</sup>
2. hi E-40 recovery filter dust	0 dpm/cm <sup>2</sup>	0
3. Room 15 standard filter sample	94	20
4. Room 15 filter box swipe	19	4
5. Room 15 exhaust duct swipe	2	<1

Each  $\mu\text{Ci}$  of tritium label represents  $4.8\text{E-}7$  grams of B[a]P. Neither the level of radiation or B[a]P concentration presents a health hazard to maintenance personnel. However, our lab standards for radiation protection allows a removable contamination to be  $1\text{ dpm/cm}^2$  in an unrestricted area and  $5\text{ dpm/cm}^2$  in a clean restricted radiation work area. Therefore the filter box and duct work in room 15 need to be decontaminated.

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Terrestrial Ecophysiology Research Area  
(TERA) Control Center Final Contamination Survey.**

Description and Historic Use:

Instrument control room for exposure chambers (150 ft<sup>2</sup>). Hydrogen-3 sealed source electron capture detector. The instrument was recently removed from the room and placed in secured storage. There is no record of leakage of any sealed sources used in this area.

Surveys:

A removable contamination survey was conducted in the TERA Control Center November 2004. The decommissioning records are enclosed. All points in the final surveyed demonstrated no significant contamination. Two swipes indicated very low levels of removable contamination from tritium (0.20 – 0.43 Bq/100 cm<sup>2</sup>). This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of TERA Control center are included in this report.



Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.



NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION TEPA ROOM Control





**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date:** November 27, 2004  
**Subject:** Room Survey: Terrestrial Ecological Research Facility (TERF)  
8-23 3/4 Final Contamination Survey.

Description and Historic Use:

Combined plant material handling rooms (200 ft<sup>2</sup> total). Plant tissue containing carbon-14 tracers was handled these rooms. No isotope use since 1990.

Surveys:

A total (fixed + removable) contamination survey was conducted in TERF 8-23 3/4 in November 2004. The decommissioning records are enclosed. All points surveyed (8) demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of TERF 8-23 3/4 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector.






NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 0A-23

LOCATION Gen

ROOM 8-23-2+4



90-29

1/2

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: 14C

Date: 7-6-90

Method of Detection: LSC-460

Philip M.  
Radiation Safety Technician

Swipe #	Location RM # Area	Background 25		NET CPM	NET DPM	Nuclide: $\mu Ci$
		NET CPM	NET DPM			
	G1484 Desk	0	N/A			N/A
	Radio	0	N/A			
	Chair	2	LUD			
	Sink	0	N/A			
	Counter	0	N/A			
	Chest	0	N/A			
	Floor	0	N/A			
	Floor	3	LUD			
	Lyophilizer	0	N/A			
	Lyophilizer (W)	4	LUD			
	door	0	N/A			
C-2	Floor	0	N/A			
	Floor	47	54			24
	Door	1	LUD			N/A

Calculation of Lower Limits of Detection (LLD)

Gross Background Counts:  
Total Background Count time:

Nuclide: 14C Nuclide: \_\_\_\_\_

250  
\_\_\_\_\_  
\_\_\_\_\_

$LLD(95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%)=

7  
\_\_\_\_\_

REMARKS:

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: \_\_\_\_\_

Date: \_\_\_\_\_

Method of Detection: \_\_\_\_\_

Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
	RM 900	Counter	0	N/A	N/A			
		Counter	0	↓	↓			
		Counter	0	↓	↓			
		Floor	0	↓	↓			
		Floor	0	↓	↓			
		W Counter	0	↓	↓			
		DESK	0	↓	↓			
		DOOR	0	↓	↓			

STANDARDS ON ATTACHED  
Calculation of Lower Limits of Detection (LLD)

PRINT OUT

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_

REMARKS:

90-24  
1/4

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: <sup>35</sup>S <sup>14</sup>C

Date: 5-21-90

Method of Detection: LSC-460

Philip A. Mon  
Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	PCI NET	NET CPM	NET DPM	µCi
	648	Bkbrd	23	—	N/A			
		door	∅ net	∅ net	✓			
		E Counter	∅	∅ net	✓			
		W Counter	3	<LLD <sub>95</sub>	✓			
		W counter	0	∅ net	✓			
		radio	0	∅ net	✓			
		desk	0	∅ net	✓			
		chair	0	∅ net	✓			
		Floor	0	∅ net	✓			
		Floor	7	8	4			
	TERF	WEST door	0	∅ net	N/A			
		FLOOR (door)	1	<LLD <sub>95</sub>	✓			
		FLOOR (Hall)	4	<LLD	✓			
		Work Area Floor	0	∅ net	✓			
		" Floor	0	∅ net	✓			

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

230  
\_\_\_\_\_  
\_\_\_\_\_

$(95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

7  
\_\_\_\_\_

REMARKS:

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: \_\_\_\_\_

Date: \_\_\_\_\_

Method of Detection: \_\_\_\_\_

Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
	TRUF	WORK area Floor (SW)	0 net	0 net	N/A			
		"	0	0 net				
		"	0	0 net				
		"	0	0 net				
		"	0	0 net				
		"	1	LLD				
		Between Chamber Floor	1	LLD				
		"	1	LLD				
		"	10	11	5			
		"	8	9	4			
		Back of chamber 27	21	24	11			
		"	5	LLD				
		"	0	0 net				
		Side of chamber 27	0	0 net				
		Front of chamber (27)	0	0 net				

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
 Total Background Count time: \_\_\_\_\_

$$LLD (95\%) = \frac{\sqrt{\text{Gross Background Counts}}}{\text{Count Time}} \times 4.66$$

LLD (95%)= \_\_\_\_\_

REMARKS :

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: \_\_\_\_\_

Date: \_\_\_\_\_

Method of Detection: \_\_\_\_\_

Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
	TORF	Door handle 27	1	<LLD <sub>95</sub>	M/A			
		Door handle 27	∅ net	∅ net				
		Inside 27	0	∅ net				
		"	1	<LLD <sub>95</sub>				
		"	6	<LLD <sub>95</sub>				
		"	0	∅ net				
		Chair	0	∅ net				
		Control Panel	1	<LLD				
		Control Panel	0	∅				
		E DOOR	0	∅				
		E FLOOR	0	∅				
		Restroom ♂	0	∅				
		Chamber 14 Door	0	∅				
		" Inside Floor	0	∅				
		Inside Floor	0	∅	✓			

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
 Total Background Count time: \_\_\_\_\_

$$LLD (95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$$

LLD (95%)= \_\_\_\_\_

REMARKS:

4/4

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: \_\_\_\_\_

Date: \_\_\_\_\_

Method of Detection: \_\_\_\_\_

Radiation Safety Technician \_\_\_\_\_

Pipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
		inside wall	0	Ø	N/A			
		inside wall	0	Ø				
		FRONT CHARG. 14	0	Ø				
		FRONT	1	LLD				
		control panel	0	Ø				
		FLOOR	0	Ø				
		FLOOR	0	Ø				
		FLOOR	0	Ø				
		CHARG. WASTE CAN	1	LLD				
		WASTE Can 27	0	Ø				
		S. DOOR	0	Ø				
		W WALL	0	Ø				
		W WALL	0	Ø				
		W WALL	0	Ø				
		W WALL	3	LLD <sub>25</sub>	✓			

Calculation of Lower Limits of Detection (LLD)

Gross Background Counts: \_\_\_\_\_  
 Total Background Count time: \_\_\_\_\_

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

$LLD(95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

REMARKS:

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: <sup>14</sup>C

Date: 12-1-89

Method of Detection: LSC-460

Chip A. Mon  
Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
1		Bk6RD	26	N/A	N/A			
2	8-4	Door - 8'	0	N/A	N/A			
3		Chamber Lyophilizer Tank	177	199	8.9x10 <sup>-5</sup>			
4		Lyopha lid	31	35	1.6x10 <sup>-5</sup>			
5		Lyopha Surface	19	21	9.5x10 <sup>-6</sup>			
6		floor	0	N/A	N/A			
7	8-23	door	0	N/A	N/A			
8		Counter	15	16	7.2x10 <sup>-6</sup>			
9		Floor	6	24255	N/A			
10		Floor	3	"	↓			
11		WALL	1	"	↓			
12		WALL	0	"	↓			
13	STD	<sup>14</sup> C 1079 dpm	1094	1176	5.3x10 <sup>-4</sup>			
14	STD	<sup>14</sup> C 10828	10130	10,881	4.9x10 <sup>-3</sup>			
15	STD	<sup>14</sup> C 108102	976 <sup>99523</sup>	106,968	4.8x10 <sup>-2</sup>			

Calculation of Lower Limits of Detection (LLD)

Nuclide: <sup>14</sup>C Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

260  
10'

LLD (5%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) =

7.5

MARKS:



**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date:** November 27, 2004  
**Subject:** Room Survey: Terrestrial Ecological Research Facility (TERF)  
105 Final Contamination Survey.

Description and Historic Use:

Former hydrocarbon instrument lab (300 ft<sup>2</sup> total). Nickel-63 and hydrogen-3:scandium sealed sources. No isotope use since 1983. There is no record of leakage of any sealed sources used in this area. There is no record of leakage of any sealed sources used in this area.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in TERF 105 in November 2004. The decommissioning records are enclosed. All points surveyed (25 total and 25 removable) demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities.

The area was not subject to any significant contamination events. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.



NHEERL-WED  
RADIATION AREA SURVEY

LOG NO. 04-25

DATE 11-24-04

Removable

LOCATION TERF

ROOM 105

INSTRUMENT  
SERIAL NO.

Packard 2200 CA  
036755

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
1	5	LLD <sub>95</sub>	ND*
2	3	↓	↓
3	6	↓	↓
4	5	↓	↓
5	3	↓	↓
6	7	↓	↓
7	3	↓	↓
8	3	↓	↓
9	5	↓	↓
10	3	↓	↓
11	5	↓	↓
12	6	↓	↓
13	4	↓	↓
14	2	↓	↓
15	7	↓	↓
16	5	↓	↓
17	7	↓	↓
18	8	↓	↓
19	7	↓	↓
20	4	↓	↓
21	4	↓	↓
22	5	↓	↓
23	6	↓	↓
24	8	↓	↓
25	7	↓	↓

$LLD_{95} = \left\{ \left( \frac{\sqrt{21}}{3} \right) \times 2.96 \right\} + = \textcircled{12} \text{ CPM}$   
 BACKGROUND STANDARD (<sup>3</sup>H 64,179 dpm) 7 cpm 60,012 dpm

SWIPE #	GROSS CPM	NET DPM	ACTIVITY Bq/100 CM <sup>2</sup>
	14	LLD <sub>95</sub>	ND*
	16	↓	↓
	13.	↓	↓
	12	↓	↓
	12	↓	↓
	11.	↓	↓
	14.	↓	↓
	12	↓	↓
	12	↓	↓
	13.	↓	↓
	11	↓	↓
	12	↓	↓
	13	↓	↓
	11	↓	↓
	10	↓	↓
	13.	↓	↓
	15.	↓	↓
	14	↓	↓
	14.	↓	↓
	13	↓	↓
	8.	↓	↓
	15.	↓	↓
	10	↓	↓
	11	↓	↓

$LLD_{95} = \left\{ \left( \frac{\sqrt{39}}{3} \right) \times 2.96 \right\} + = \textcircled{19} \text{ CPM}$   
 BACKGROUND STANDARD (<sup>14</sup>C 84,000 dpm) 13 cpm 85,006 dpm

COMMENTS: ND\* = NOT DETERMINED. Below the detection limits.



J. Mona  
RADIATION SPCL.

11-26-04  
DATE

NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-25

LOCATION TERF ROOM 105



0  
1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: TERF 113 Final Contamination Survey.**

Description and Historic Use:

Exposure room (300 ft<sup>2</sup>). Carbon-14 and rubidium-86 tracers. This room was decommissioned as a unrestricted area on June 8, 1993. No isotope use since 1988.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in TERF 113 at the time of restricted use decommissioning. The decommissioning records are enclosed. All points surveyed demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. HVAC duct swipes made in November 2004 indicated no significant contamination (0.37 Bq/100 cm<sup>2</sup>).

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of TERF 113 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 3 Survey Meter equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector.

OK file

MANTECH ENVIRONMENTAL TECHNOLOGY , INC  
200 SW 35TH STREET, CORVALLIS, OREGON 97333

M E M O R A N D U M

Date: June 8, 1993  
From: Phil Monaco, Health and Radiation Safety  
To: Jay Gile

Subject: Decommission of TERF 113

During the week of June 1, 1993, Tom Pfleeger cleaned, decontaminated and swipe-tested for radioisotope contamination the TERF 113 Plant Exposure Room and the housed equipment. Room swipes taken by Pfleeger indicated removable contamination in the room to range between 0-13 dpm/100cm<sup>2</sup> net. Results of the equipment swipes ranged between 2-33 dpm/100cm<sup>2</sup> net.

On June 7, 1993, I conducted a contamination survey of the room and equipment for removable and fixed (non-removable) beta and gamma contamination and radiation levels. Removable contamination swipes indicated all were at or below background. Sixteen 100cm<sup>2</sup> swipes were made. The fixed contamination survey indicated that all areas surveyed were at background levels. The radiation levels are at background (<0.2 mR/Hr) and therefore do not present an external radiation hazard.

The ERL-C acceptable level of removable and fixed contamination for a non-restricted area for beta- and gamma - emitters is 50 dpm/100cm<sup>2</sup> and 5000 dpm/100cm<sup>2</sup> respectively.

Historically, the room was used for carbon-14 labelled organic and rubidium-86 labelled inorganic (1987) plant uptake experiments.

Based on the condition of the room and the survey results, I recommend that TERF 113 be recognized as decommissioned for radioisotope use.

C: T. Pfleeger

U.S. EPA  
ENVIRONMENTAL RESEARCH LABORATORY - CORVALLIS

Log No. 93-11

RADIATION CONTAMINATION SURVEY

Date: 6/7/93 Type of Survey: Radiation Survey

Isotope(s): \_\_\_\_\_

Gross Background Counts: 75 ± CPM Total Count Time (min.): 1

Lower Limits of Detection:  $(\sqrt{75}) \times 2.96 = 25.6$  cpm

Instrument Used:  GM  LSC  Ion Chamber Model: Ludlum #3 GM Probe 44-7 SIN: 77287/P292674  
 GM  Scintillation

Background: 0.02 mR/Hr (75) CPM±SD DPM±SD Standard (Cs<sup>137</sup> / ml shield) 1: 0.4 mR/Hr % Error

Swipe No.	Room No.	Swipe Description	Nuclide: _____			Nuclide: _____			
			CPM±SD	Net DPM	Net Activity	CPM±SD	Net DPM	Net Activity	
		<u>TERF 113</u>							
		<u>Room Survey</u>			<u>0.02 mR/Hr</u>				

Notes: Survey radiation level at background of 0.02 mR/Hr.  
Sharon 6/9/93  
Radiation Safety Date

U.S. EPA  
ENVIRONMENTAL RESEARCH LABORATORY - CORVALLIS

Log No. 93-10

RADIATION CONTAMINATION SURVEY

Date: 6/8/93 Type of Survey: Removable Contamination  
Isotope(s): <sup>14</sup>C TELF DECOMMISSIONING

Gross Background Counts: 24 ± CPM Total Count Time (min.): 1

Lower Limits of Detection:  $(\sqrt{24}) 2.96 = 15$  CPM

Instrument Used:  GFPC  LSC  Ion Chamber Model: Packard LSC 2200 CA S/N: 36755  
 GM  Scintillation <sup>14</sup>C NET 84,800 dpm

Background: 24 CPM±SD 27 DPM±SD Standard (1976) ): 84231 100% eff.

Swipe No.	Room No.	Swipe Description	Nuclide: <u>per 100 cm<sup>2</sup></u>			Nuclide: <u>per 100 cm<sup>2</sup></u>		
			CPM±SD	Net DPM	Net Activity	CPM±SD	Net DPM	Net Activity
7	TELF 113	DOOR	0	0	0			
		Table	0	0				
		Counter	0	0				
		Wall (W)	0	0				
		Wall (W)	0	0				
		Wall (E)	0	0				
		Wall (E)	1	<LUDS				
		Floor W	0	0				
10		Floor W	0	0				
		Floor E	0	0				
		Floor E	2	<LUDS				
		Floor C	0	0				
		Floor C	3	<LUDS				
5		CACT	1	<LUDS				
		Phoni	4	<LUDS	✓			

Signature: [Signature] Date: 6/8/93  
Radiation Safety (9/70)






Protocol #: 13 Name: CW Swipes 28-M-93 10:35  
 Region A: LL-UL= 0.0-156. Lcr= 18 Bkg= 0.00 %2 Sigma=2.00  
 Region B: LL-UL= 4.0-156. Lcr= 0 Bkg= 0.00 %2 Sigma=0.00  
 Region C: LL-UL= 0.0- 0.0 Lcr= 0 Bkg= 0.00 %2 Sigma=0.00  
 Time = 10.00 QIP = tSIE ES Terminator = Count  
 Additional DPM  
 Rate 1 = 113700  
 Luminescence Correction On

#	TIME	CPMA A:25%	CPMB	FLAG	LUM	tSIE	Gross DPM1	
1	10.00	34.30 31.17	18.10	E	83	55.7	47.87	Background Room Range cms 0-6 cpm net
2	10.00	30.20 25.13	20.50	E	68	56.1	42.12	
3	10.00	27.50 18.75	19.60	E	43	63.1	37.88	
4	10.00	25.00 23.89	19.80	E	58	67.6	34.17	
5	10.00	33.30 19.54	21.40	E	57	57.5	46.33	
6	10.00	23.10 22.66	18.10	E	52	64.6	31.74	
7	10.00	38.50 27.18	18.70	E	79	73.2	52.12	
8	10.00	44.10 17.25	24.60	E	55	60.2	61.06	
9	10.00	23.50 24.17	18.90	E	60	50.9	33.08	
10	10.00	24.40 20.70	17.60	E	46	66.0	33.45	
11	10.00	27.90 16.67	19.50	E	34	64.5	38.34	5 dpm net 13 dpm net
12	10.00	22.70 26.21	16.70	E	63	65.8	31.13	
13	10.00	27.10 24.73	17.70	E	65	55.2	37.86	
14	10.00	27.80 27.22	19.00	E	71	60.1	38.50	
15	10.00	26.90 19.20	20.30	E	45	60.5	37.23	
16	10.00	29.20 21.02	21.20	E	55	66.7	39.98	
17	10.00	35.90 18.96	23.90	E	54	51.7	50.46	
18	10.00	35.80 17.03	24.00	E	47	70.2	48.72	
19	10.00	59.90 10.67	32.30	E	27	75.3	80.80	
20	10.00	30.30 20.33	19.10	E	53	83.0	40.34	
21	10.00	26.50 38.05	17.50	E	85	81.4	35.37	2 33 dpm net

$$LLD_{95} = \left( \frac{\sqrt{18}}{10} \right) 2.96 =$$



15-17

Figure 1. Plant exposure laboratory floor plan.

COUNTER TOP

7 CART TOPS

#2, 7, 4, 3, 1, 8

FLOOR

TABLE TOP

FLOOR WEST SIDE

DOOR

FLOOR by DOOR

FLOOR by COUNTER

CART COVERS HANGING FROM CEILING

INSIDE CART 2

" " 4

1

BLANK

RADIATION CONTAMINATION SURVEY

Date: 11-4-91 Type of Survey: Removable Contamination  
Isotopes:  $^{35}\text{S}$ ,  $^{60}\text{Co}$ ,  $^{14}\text{C}$ ,  $^3\text{H}$

Background Counts: 3H = 4.1 cpm  $^{14}\text{C} = 10.3 \text{cpm}$   
Total Count Time (min.): 10'

Lower Limits of Detection:  $^3\text{H} = (\sqrt{41/10}) \times 466 = 3$   $^{14}\text{C} = (\sqrt{103/10}) \times 466 = 5$  CDM

Instrument Used:  GFPC  LSC  Ion Chamber Model: PACKARD 2200 S/N: \_\_\_\_\_  
 GM  Scintillation

Background: \_\_\_\_\_ CPM±SD \_\_\_\_\_ DPM±SD Standard ( $^{14}\text{C}$  85,428 2%): \_\_\_\_\_ % Error

Room No.	Swipe Description	Nuclide: <u><math>^3\text{H}</math></u>			Nuclide: <u><math>^{14}\text{C}</math></u>		
		CPM±SD	Net DPM	Net Activity $\mu\text{Ci}$	CPM±SD	Net DPM	Net Activity
2	130 Hood sill	3	7	32 $\mu\text{Ci}$	3	LUD <sub>95</sub>	N/A
	SASH	0	0	N/A	2	↓	↓
4	Floor	0	0	↓	2	↓	↓
5	N. Counter	0	0	↓	0	0	↓
6	S. Counter	0	0	↓	2	LUD <sub>95</sub>	↓
7	door	0	0	↓	0	0	↓
8	232 S. Hood sill	4	13	5.9 $\mu\text{Ci}$	1	LUD <sub>95</sub>	↓
	SASH	2	LUD <sub>95</sub>	N/A	0	0	↓
10	Floor	0	0	↓	4	LUD <sub>95</sub>	↓
11	N Hood sill	2	LUD <sub>95</sub>	↓	4	↓	↓
12	SASH	1	1	↓	1	↓	↓
13	Floor	0	0	↓	0	0	↓
14	desk	0	0	↓	1	LUD <sub>95</sub>	↓
15	Phone	1	LUD <sub>95</sub>	↓	0	0	↓
16	Floor	0	0	↓	0	0	↓
17	counter	0	0	↓	1	LUD <sub>95</sub>	↓
18	door	0	0	↓	0	0	↓
19	228 S Hood SASH	2	LUD <sub>95</sub>	↓	0	0	↓
20	Sill	1	LUD <sub>95</sub>	↓	0	0	↓
21	Floor	0	0	↓	0	0	↓

Comments: \_\_\_\_\_  
Signature: Chris S. Man...  
Radiation Safety Date

RADIATION CONTAMINATION SURVEY

11-4-91

Type of Survey: \_\_\_\_\_

Isotope(s): \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_ ± CPM Total Count Time (min.): \_\_\_\_\_

Lower Limits of Detection: \_\_\_\_\_ CDM

Instrument Used:  GPC  LSC  GM  Ion Chamber  Scintillation Model: \_\_\_\_\_ S/N: \_\_\_\_\_

Background: \_\_\_\_\_ CPM±SD \_\_\_\_\_ DPM±SD Standard ( \_\_\_\_\_ ): \_\_\_\_\_ % Error

Swipe No.	Room No.	Swipe Description	Nuclide: <u>3H</u>			Nuclide: <u>14C</u>		
			CPM±SD	Net DPM	Net Activity <u>pCi</u>	CPM±SD	Net DPM	Net Activity
22	228	Hood Floor	0	0	N/A	0	0	N/A
23		Floor	0	0	↓	0	0	↓
24	256	door	1	LUD <sub>95</sub>	↓	0	0	↓
25		Phone	3	8	3.6 pCi	0	0	↓
26		Counter	2	LUD <sub>95</sub>	N/A	3	LUD <sub>95</sub>	↓
27		Desk	0	0	N/A	0	0	↓
		LSC	3	7	3.2 pCi	4	LUD <sub>95</sub>	↓
28		Hood <del>SILL</del>	1	LUD <sub>95</sub>	N/A	3	LUD <sub>95</sub>	↓
29		FLOOR <del>SILL</del>	1	LUD <sub>95</sub>	↓	0	0	↓
31	258	Hood <del>SILL</del>	0	0	↓	6	7	3.2 pCi
32		Floor	1	LUD <sub>95</sub>	↓	3	LUD <sub>95</sub>	↓
33		LSC	1	LUD <sub>95</sub>	↓	3	LUD <sub>95</sub>	↓
34		door	3	7	3.2 pCi	0	0	↓
35	TECF 113	TABLE	0	0	N/A	3	LUD <sub>95</sub>	↓
36		Sink counter	0	0	↓	0	0	↓
37		Floor	0	0	↓	0	0	↓
38		door	0	0	↓	2	LUD <sub>95</sub>	↓
39		TABLE	0	0	↓	2	LUD <sub>95</sub>	↓
40		Floor	0	0	↓	4	LUD <sub>95</sub>	↓

Comments:

Radiation Safety \_\_\_\_\_ Date \_\_\_\_\_

RADIATION CONTAMINATION SURVEY

Type of Survey: \_\_\_\_\_

Isotope(s): \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  $\pm$  CPM Total Count Time (min.): \_\_\_\_\_

Lower Limits of Detection: \_\_\_\_\_ cpm

Instrument Used:  GFPC  LSC  GM  Ion Chamber  Scintillation Model: \_\_\_\_\_ S/N: \_\_\_\_\_

Background: \_\_\_\_\_ CPM $\pm$ SD \_\_\_\_\_ DPM $\pm$ SD Standard ( \_\_\_\_\_ ): \_\_\_\_\_ % Error

Type No.	Room No.	Swipe Description	Nuclide: <u><sup>3</sup>H</u> per 100 cm <sup>2</sup>			Nuclide: <u><sup>14</sup>C</u> per 100 cm <sup>2</sup>			
			CPM $\pm$ SD	Net DPM	Net Activity	CPM $\pm$ SD	Net DPM	Net Activity	
41	190	Door	0	0	N/A	2	2UD <sub>5</sub>	N/A	
42		Floor	0	0	Y	3	2UD <sub>5</sub>	Y	
43		Counter (S)	0	0	V	2	2UD <sub>5</sub>	V	
44		Counter (S)	0	0					
45		Counter (N)	2	2UD <sub>5</sub>					
46		Phone	0	0					
		Desk	0	0					
			0	0					
					ERROR				
		<sup>3</sup> H 1.4x10 <sup>-4</sup> $\mu$ Li	126	213	9.6x10 <sup>-5</sup>	32%	121	140	—
		<sup>3</sup> H 1.17x10 <sup>-3</sup>	1,152	2,199	9.9x10 <sup>-4</sup>	15%	247	233	—
		<sup>3</sup> H 1.13x10 <sup>-2</sup>	11,211	2,1651	9.8x10 <sup>-3</sup>	14%	1818	1531	—
		<sup>14</sup> C 5.45x10 <sup>-5</sup> $\mu$ Li	14	0	—		110	135	6.1x10 <sup>-5</sup> 12%
		<sup>14</sup> C 5.38x10 <sup>-4</sup>	115	0	—		1011	1,225	5.5x10 <sup>-4</sup> 2%
		<sup>14</sup> C 4.98x10 <sup>-3</sup>	1,045	0	—		8739	10,584	4.8x10 <sup>-3</sup> 4%
		<sup>3</sup> H PACKARD 6.05x10 <sup>-2</sup>	72749	123,957	5.6x10 <sup>-2</sup>	8%	6846	2419	—
		<sup>14</sup> C NEN 3.8x10 <sup>-2</sup>	10,570	0	—		71553	85,428	3.8x10 <sup>-2</sup> 0%

Comments:

Radiation Safety

Date

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed:  $^3\text{H}/^{14}\text{C}$

Date: 4/14/88  
4/22/88

Method of Detection: LSC

P. Mmaw  
Radiation Safety Technician

3H

Swipe #	Location		Nuclide: ---		
	RM #	Area	NET CPM	NET DPM	μCi
	190	door			
		Sink Counter			
		Counter			
		Flair			
1		door	2	<LLD	
2		Counter #1	0	↓	
3		2	1		
4		3	0		
5		Floor 1	0		
6		2	0		
7		3	2		
8		NE Sink	0		
9		NE Counter	4		
10		Phone	0		

Nuclide: $^{14}\text{C}$		NET CPM . NET DPM		μCi
		0		
		0		
		2		
		3		
		3	<LLD	
		0	↓	
		0		
		0		
		0		
		0		
		2		
		2		
		0		
		3		

Calculation of Lower Limits of Detection (LLD)

Nuclide: $^3\text{H}$	Nuclide: $^{14}\text{C}$
<u>37</u>	<u>41</u>
<u>3</u>	<u>3</u>
<u>10</u>	<u>10</u>

Gross Background Counts:  
Total Background Count time:

$$D(95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$$

LLD (95%) =

REMARKS:



AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: <sup>14</sup>C / <sup>3</sup>H

Date: 4-22-88

Method of Detection: LSC

P. Monas  
Radiation Safety Technician

Swipe #	Location		Nuclide: <sup>3</sup> H			Nuclide: <sup>14</sup> C		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
11	22B	Door	0	LLD		0	LLD	
12		NE Hood	0	↓		5	↓	
13	22B6	Phone	0			5		
14		Desk	0			0		
15		Floor (HPLC)	0			0		
16		Floor (Sink)	0			2		
17	236	SE (Hood) Floor	0			1		
18		NE Floor (Hood)	0			0		
19		door	0			5		
20	256	door	0			1		
21		Phone	1			0		
22		Floor (door)	0			1		
23		Floor (hood)	0			0		
24		Floor (oxi)	0			1		
25		Counter (phone)	0		↓	1		↓

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

$LLD (95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

REMARKS:

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: 14/3H  
C/3H

Date: 4-22-88

Method of Detection: LSC

P. Monna  
Radiation Safety Technician

Swipe #	Location		Nuclide: <u>3H</u>			Nuclide: <u>14C</u>		
	RM #	Area	NET CPM	NET DPM	$\mu$ Ci	NET CPM	NET DPM	$\mu$ Ci
26	252	LSC	0	$\downarrow$ LLD		0	$\downarrow$ LLD	
27		Computer	0	$\downarrow$		0	$\downarrow$	
28		reflex	9			0		
29	258	LSC	0			0		
30		<del>FLOOR</del> FLOOR (Hood)	0			0		
31		FLOOR (Sink)	0			0		
32		Door	0			0		
33		Counter (sw)	2			0		
34		Reflex	1	$\downarrow$		3		
35	TEMP 113	TABLE	<del>17</del> 6			3		
36		FLOOR SC	0			6		
37		CW	0			2		
38		NC	0			3	$\downarrow$	
39		NE	0			<del>18</del>		
40		CE <del>NE</del>	0	$\downarrow$		<del>17</del>	$\downarrow$	

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

REMARKS:

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: <sup>14</sup>C / <sup>3</sup>H

Date: 4-22-88

Method of Detection: LSC  
3H

P. Monner  
Radiation Safety Technician  
142

Swipe #	Location		Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi
41	TEMP 113	FLOOR SE	0		
42		Floor E	0		
43		E	0		
44		Sink Faucet	0		
45		Sink counter	0		
46		door	0		
47		Phone	1		
48		Sink	0		
49		CAPT	0		
50		Light Switch	2		
<sup>3</sup> H		Bural std.		37606	✓
<sup>14</sup> C		Bural std.		<del>37263</del>	✓

Nuclide:		
NET CPM	NET DPM	μCi
4		
45		
9		
0		
2		
0		
0		
1		
6		
6		
	1715	
	37263	

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_

LLD (95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

\_\_\_\_\_

REMARKS:

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: TERF High Bay (HB) Final Contamination  
Survey.**

Description and Historic Use:

Very large room (4000 ft<sup>2</sup>) housing plant growth chambers. Carbon-14 and hydrogen-3 tracers. No isotope use since 1993.

Surveys:

A total (fixed + removable) contamination surveys was conducted in TERF HB in November 2004. The decommissioning records are enclosed. All points surveyed (17) demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities.

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. Records of several thorough contamination surveys conducted at the time of the most recent radiotracer experiments are enclosed. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area.

The survey for total contamination was conducted using a Ludlum Model 3 rate meter equipped with a Ludlum Model 44-9, Geiger-Mueller 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.




NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION TERF

ROOM HB



MANTECH ENVIRONMENTAL TECHNOLOGY, INC  
200 SW 35TH STREET, CORVALLIS, OREGON 97333

M E M O R A N D U M

Date: February 18, 1993  
From: Phil Monaco, Health and Radiation Safety  
To: Jay Gile

Subject: Contamination Swipes of TERF Chambers

Reported below are the results of the contamination swipes I made following the completion of the second exposure experiment conducted by Dr. D. Armstrong, OSU, on Feb. 17, 1993 in two TERF high bay exposure chambers (Nos. 26 & 27). No incidents occurred during the experiment. The chemical used was a 3H-adenine compound. The area is clean and can be used for non-restricted space.

Swipe	Description	Activity pCi
2	Cart	0 net
3	Floor	0
4-6	Chamber 26, exposure chambers 1 & 2	0
7-9	Chamber 27, exposure chambers 3 & 4	0

cc: B. Hogsett  
D. Field  
D. Armstrong

U.S. EPA  
ENVIRONMENTAL RESEARCH LABORATORY - CORVALLIS

Log No. 934

RADIATION CONTAMINATION SURVEY

Date: 2/18/73 Type of Survey: Removable

Isotope(s): <sup>3</sup>H

Gross Background Counts: 15 ± CPM Total Count Time (min.): 1

Lower Limits of Detection: (√15) 2.96 = 11.5 = cpm

Instrument Used:  GFPC  LSC  Ion Chamber Model: LSC 2200 CA S/N: \_\_\_\_\_  
 GM  Scintillation

Background: 15 CPM±SD 43 DPM±SD Standard (<sup>3</sup>H) 0.11495 μCi <sup>11/79</sup> Corrected 110 = 92%

Swipe No.	Room No.	Swipe Description	Nuclide: <u><sup>3</sup>H</u> per 100 cm <sup>2</sup>			Nuclide: _____ per 100 cm <sup>2</sup>			
			net CPM±SD	Net DPM	Net Activity	CPM±SD	Net DPM	Net Activity	
2	TRF	CART	0	0	0 net				
3	High	FLOOR	0	0	↓				
4	BY	Chamber # 26 door	0 1	LU055					
5	Chamber	exp. chamber # 1	0	0					
6	↓	exp. chamber # 2	0	0					
7	↓	chamber # 27 door	2	LU055					
8	↓	exp. chamber # 3	0	0					
9	↓	exp. chamber # 4	6	LU055		↓			

Comments: <sup>3</sup>H exp. D. Armstrong. et.

D.A. M... 2/18/73  
Radiation Safety Date



U.S. EPA  
ENVIRONMENTAL RESEARCH LABORATORY - CORVALLIS

Log No. 93-2

RADIATION CONTAMINATION SURVEY

93 PM

Date: 1-13-92 Type of Survey: Penetrable

Isotope(s): <sup>3</sup>H

Gross Background Counts: 14 ± CPM Total Count Time (min.): 1

Lower Limits of Detection:  $(\sqrt{14}) 2.96 =$  11 = CPM

Instrument Used:  GFPC  LSC  GM  Ion Chamber  Scintillation Model: LSC Packard 2200A S/N: \_\_\_\_\_

Background: 14 CPM±SD 39 DPM±SD Standard (Packard 127,618 dpm): 115,619 dpm ~~± Error~~

Swipe No.	Room No.	Swipe Description	Nuclide: _____ per 100 cm <sup>2</sup>			Nuclide: _____ per 100 cm <sup>2</sup>		
			CPM±SD	Net DPM	Net Activity	CPM±SD	Net DPM	Net Activity
2	TRF1	Chamber 27 DOOR	1	0	0			
	HB	COSOM 3 FRONT	0					
		COSOM 3 inside	0					
5		COSOM 4 FRONT	1					
		COSOM 4 inside	0					
		COSOM # 26 DOOR	4	LUD <sub>95</sub>				
		COSOM 1 FRONT	5	LUD <sub>95</sub>				
		COSOM 1 inside	0	LUD <sub>95</sub>				
10		COSOM 2 FRONT	0	0				
		COSOM 2 Inside	<del>18</del> 4	LUD <sub>95</sub>				
		Chamber 27 inside	0	0				
		Chamber 26 inside	0	0				
15		cast floor	4	LUD <sub>95</sub>				
			0	0				

Agents:

ORA Mm, 1/14/92  
Radiation Safety Date

Control #: 27 Name: 3H.RadSafety 14-Jan-93 12:26

Region A: LL-UL= 0.0-18.6 Lcr= 0 Bkg= 0.00 %2 Sigma=1.00

Region B: LL-UL= 2.0-18.6 Lcr= 0 Bkg= 0.00 %2 Sigma=1.00

Region C: LL-UL= 0.0- 0.0 Lcr= 0 Bkg= 0.00 %2 Sigma=0.00

Time = 1.00 QIP = tSIE ES Terminator = Count

Optimum, Std. curve generated by mean of 3 cts

Conventional DPM

Module 1 = 75580

Fluorescence Correction On

S#	TIME	CPMA	DPM1	A:2S%	CPMB	B:2S%	SIS	tSIE	FLAG	LUM
1	1.00	14.00	38.55	63.88	14.00	60.60	26.710	317.	7	Black
2	1.00	15.00	40.10	63.94	15.00	58.11	19.360	329.	24	
3	1.00	13.00	34.94	73.78	12.00	66.66	22.590	327.	13	
4	1.00	12.00	33.00	74.53	12.00	70.71	22.330	318.	14	
5	1.00	15.00	44.01	61.10	15.00	54.97	27.710	293.	6	
6	1.00	11.00	31.15	60.30	10.00	63.24	24.650	306.	0	
7	1.00	18.00	50.65	47.14	16.00	49.99	28.260	308.	0	
8	1.00	19.00	53.00	54.69	16.00	55.90	20.100	312.	5	
9	1.00	15.00	41.57	61.10	15.00	58.11	29.100	314.	6	
10	1.00	13.00	36.22	76.92	12.00	70.71	23.950	312.	12	
11	1.00	18.00	49.87	54.43	17.00	51.28	20.950	315.	5	
12	1.00	14.00	38.19	60.60	14.00	60.60	23.150	321.	7	
13	1.00	11.00	30.62	74.96	10.00	74.83	26.260	313.	8	
14	1.00	17.00	50.60	58.82	17.00	53.91	24.830	288.	5	
15	1.00	8.00	35.24	165.8	6.00	115.5	21.460	196.	62	
16	1.00	162.00	295.84	16.37	151.00	16.59	20.030	619.	1	
17	1.00	1356.00	2467.91	5.48	1159.00	5.88	15.920	623.	1	STDS
18	1.00	11847.0	21612.3	1.84	10090.0	1.99	15.410	620.	1	
19	0.53	75360.4	115619.	1.00	66713.2	1.06	18.400	908.	E	0 Packard 127,618 dpm

90-24  
1/4

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: <sup>35</sup>S <sup>14</sup>C

Date: 5-21-90

Method of Detection: LSC-460

Philip A. Mon  
Radiation Safety Technician

Swipe #	Location		Nuclide:		pCi / CT	Nuclide:		
	RM #	Area	NET CPM	NET DPM		NET CPM	NET DPM	µCi
	648	BEARD	23	—	N/A			
		door	∅ net	∅ net	✓			
		E Counter	∅	∅ net				
		W Counter	3	<LLD <sub>95</sub>				
		W Counter	0	∅ net				
		Radio	0	∅ net				
		desk	0	∅ net				
		chair	0	∅ net				
		Floor	0	∅ net	✓			
		Floor	7	8	4			
	7ERF	WEST door	0	∅ net	N/A			
		FLOOR (door)	1	<LLD <sub>95</sub>	✓			
		FLOOR (Hall)	4	<LLD				
		Work Area Floor	0	∅ net				
		" Floor	0	∅ net				

Calculation of Lower Limits of Detection (LLD)

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

230

$$(95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$$

LLD (95%) =

7

REMARKS:

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: \_\_\_\_\_

Date: \_\_\_\_\_

Method of Detection: \_\_\_\_\_

Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
	TERF	Work area Floor (SW)	0 net	0 net	N/A			
		"	0	0 net	↓			
		"	0	0 net	↓			
		"	0	0 net	↓			
		"	0	0 net	↓			
		"	1	LLD	↓			
		Between Chamber Floor	1	LLD	↓			
		"	1	LLD	↓			
		"	10	11	5			
		"	8	9	4			
		Back of chamber 27	21	24	11			
		"	5	LLD	↓			
		"	0	0 net	↓			
		Side of chamber 27	0	0 net	↓			
		Front of chamber 27 (21)	0	0 net	↓			

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
 Total Background Count time: \_\_\_\_\_

\_\_\_\_\_  
 \_\_\_\_\_

$$(95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$$

LLD (95%) = \_\_\_\_\_

\_\_\_\_\_

REMARKS:

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: \_\_\_\_\_

Date: \_\_\_\_\_

Method of Detection: \_\_\_\_\_

Radiation Safety Technician \_\_\_\_\_

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
	TORF	Door Chalk 27	1	<LLD <sub>95</sub>	N/A			
		Door Chalk 27	Ø net	Ø net				
		Inside 27	0	Ø net				
		"	1	<LLD <sub>95</sub>				
		"	6	<LLD <sub>95</sub>				
		"	0	Ø net				
		Chair	0	Ø net				
		Control Panel	1	<LLD				
		Control Panel	0	Ø				
		E DOOR	0	Ø				
		E Floor	0	Ø				
		Restroom ♂	0	Ø				
		Chamber 14 Door	0	Ø				
		"	0	Ø				
		Inside Floor	0	Ø				
		Inside Floor	0	Ø				

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
 Total Background Count time: \_\_\_\_\_

$$(95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$$

LLD (95%) = \_\_\_\_\_

REMARKS:

4/4

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: \_\_\_\_\_

Date: \_\_\_\_\_

Method of Detection: \_\_\_\_\_

\_\_\_\_\_  
Radiation Safety Technician

wipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
		inside wall	0	Ø	N/A			
		inside wall	0	Ø				
		FRONT Chab. 14	0	Ø				
		FRONT	1	LLD				
		control panel	0	Ø				
		FLOOR	0	Ø				
		FLOOR	0	Ø				
		FLOOR	0	Ø				
		CHABEAU WASTE CAN	1	LLD				
		WASTE can 27	0	Ø				
		S. DOOR	0	Ø				
		W WALL	0	Ø				
		W WALL	0	Ø				
		W WALL	0	Ø				
		W WALL	3	LLD <sub>95</sub>	✓			

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

$(95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LD (95%) = \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_

REMARKS:

1/2/87

89-28

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: Carbon-14

Date: 9-22-89

Method of Detection: LSL 460

Pd. Morris  
Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	µCi	NET CPM	NET DPM	µCi
1	<del>TRF</del>	<del>Door</del> BICBED	24					
2	TRF	DOOR	0					
3		6 E Chamber window	1					
4		SE Chamber door	4					
5		SE Chamber in	0					
6		SE Chamber in	0					
		Floor	3					
8		Floor	2					
9		Floor	35	40		< 100 dpm/100 cm <sup>2</sup>		
10		SW Chamber window	7	8				
11		SW Chamber door	0					
12		SW Chamber in	0					
13		SW Chamber in	3					
14		SW SE SMURF Floor	4					
15		SE SMURF	0					

Calculation of Lower Limits of Detection (LLD)

Nuclide: <sup>14</sup>C Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

240  
\_\_\_\_\_  
\_\_\_\_\_

5%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LD (95%) = 7

REMARKS:

2/3/7

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: \_\_\_\_\_

Date: \_\_\_\_\_

Method of Detection: \_\_\_\_\_

Radiation Safety Technician \_\_\_\_\_

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	µCi	NET CPM	NET DPM	µCi
16		SE Chamber IN	0					
17		SW Chamber IN	0					
18		SW SMURF	0					
19		SW SMURF	0					
20		SW Chamber W side out	1					
21		SW Chamber W-side out	0					
22		SW chamber W-side out	0					
23		SW FLOOR	0					
24		SW FLOOR	0					
25		SW FLOOR	0					
26		SW DOOR	0					
27		CART	73	(82) Ask to Clean				
28		CART	0					
29		Chair	0					
30		TRANSFORMER	0					

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_

Total Background Count time: \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_

$(95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%)= \_\_\_\_\_

REMARKS:



3/4

AREA CONTAMINATION SURVEY SHEET

Radionuclide(s) Surveyed: \_\_\_\_\_

Date: \_\_\_\_\_

Method of Detection: \_\_\_\_\_

Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:		
	RM #	Area	NET CPM	NET DPM	µCi	NET CPM	NET DPM	µCi
31		N Chamber window #7	0					
32		N Chamber Door	0					
33		N Chamber IN	0					
34		N C IN	4					
35		N C IN	0					
36		N C OUT	0					
37		N C OUT	0					
38		FLOOR	2					
39		FLOOR	0					
40		FLOOR	0					
41		TRASH CAN	0					
42		Chamber # OUT 14	0					
43		chair	12					
44		chair	0					
45	190	DOOR	0					

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
 Total Background Count time: \_\_\_\_\_

\_\_\_\_\_  
 \_\_\_\_\_

(95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) = \_\_\_\_\_

REMARKS:

TELE BAN

89-29

PROGRAM #: 6  
 REGION A: LL-UL= 0- 156 LCR= 0 BKG= 0 % 2 SIGMA= 1.0  
 REGION B: LL-UL= 4- 156 LCR= 0 BKG= 0 % 2 SIGMA= 1.0  
 SLIDE 1 = 42000  
 ME= 3.00 QIP= SIE/AEC SCR= B/A K= 1.000

S#	TIME	CPMA/K DPM1/K	%DEV	CPMB/K DPM2/K	%DEV	QIP	FLAGS	SCR	MIN
1	10.00	21.50	13.6	19.70	14.2	662.	B	.916	10 B
2	3.00	288.50 309.35	6.56	262.63 .00	6.87	749.	L	.910 .000	15,272 34
3	3.00	1315.17 1415.14	3.16	1090.63 .00	3.47	715.	L	.829 .000	18 34
4	3.00	12932.8 13894.9	1.01	10647.6 .00	1.12	729.	L1	.823 .000	22 34
5	3.00	1062.83 1143.29	3.51	1049.97 .00	3.53	718.	L	.988 .000	26 1079 C-14
6	3.00	10141.8 10914.7	1.15	10015.9 .00	1.15	713.	L	.988 .000	30 10790 C-14
11	3.00	2.17 2.34	23.7	.97 .00	25.4	685.		.446 .000	33 B
12	3.00	.00 .00	25.0	.00 .00	26.7	619.	?	.000 .000	37
13	3.00	1.50 1.69	24.0	1.63 .00	25.0	499.		1.089 .000	41
14	3.00	.83 .92	24.4	2.63 .00	24.4	594.		3.160 .000	45
ERROR									
15	3.00	.00 2.08	.00	.00 .00	.00	.000	?	.000 .000	49
ERROR									
16	3.00	.00 2.08	.00	.00 .00	.00	.000	?	.000 .000	53
ERROR									
17	3.00	.00 2.08	.00	.00 .00	.00	.000	?	.000 .000	58
ERROR									
18	3.00	.00 2.08	.00	.00 .00	.00	.000	?	.000 .000	62
ERROR									
19	3.00	.00 2.08	.00	.00 .00	.00	.000	?	.000 .000	66
ERROR									
20	3.00	.00 2.08	.00	.00 .00	.00	.000	?	.000 .000	71

CRIT  
 re-sweep  
 following cleaning  
 9-27-87  
 R.M.

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date:** November 27, 2004  
**Subject:** Room Survey: Willamette Research Station (WRS or WFTS) 10  
Final Contamination Survey.

Description and Historic Use:

Single lab (225 ft<sup>2</sup>). Carbon-14 tracer, and nickel-63 and hydrogen-3:scandium sealed sources. No isotope use since prior to 1986. There is no record of leakage of any sealed sources used in this area.

Surveys:

A total (fixed + removable) contamination survey was conducted in WRS 10 in November 2004. All points surveyed (13) demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. HVAC duct swipes were made in November 2004 which indicated no significant contamination (0.22 Bq/100 cm<sup>2</sup>).

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of WRS 10 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination (duct) was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.





NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION WRS

ROOM 10



WFTS

AREA CONTAMINATION SURVEY SHEET

WFTS

Radionuclide(s) Surveyed: <sup>14</sup>C <sup>3</sup>H

Date: 9-24-86

Method of Detection: LSC

P. Monaco  
Radiation Safety Technician

Swipe #	Location		Nuclide: <sup>3</sup> H			Nuclide: <sup>14</sup> C		
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi
24	12	SEE MAP	15.9	51.81		14.05	11.06	
25	}	}	0			3.05	<LLD	
26			1.30	<LLD		0		
27			0			2.65	<LLD	
28			0			0		
29			0			0		
30			0			0		
31			0			0		
32			0			0		
33			0.7	<LLD		0.85	<LLD	
34			0			1.05	<LLD	
35			0			0		
36			0			0		
37			0			0		

Calculation of Lower Limits of Detection (LLD)

Nuclide: <sup>3</sup>H      Nuclide: <sup>14</sup>C

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

\_\_\_\_\_ 275  
\_\_\_\_\_ 20

(95%) =  $\sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LLD (95%) =

3.04      3.86

REMARKS:

AREA CONTAMINATION SURVEY SHEET

WFTS

Radionuclide(s) Surveyed:  $^{14}\text{C}$   $^3\text{H}$

Date: 9/24/86

Method of Detection: LSC

P. Monaw

Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:			
	RM #	Area	NET CPM	NET DPM	$\mu\text{Ci}$	NET CPM	NET DPM	$\mu\text{Ci}$	
	<del>41</del>								
38	10	SEE MAP	0			0			
39	}	}	0			3.05	3.92		
40			0.5	<LLD		3.25	<LLD		
41			0			0			
42			2.50	10.62		6.25	6.50		
43			0			0			
44			0.1	<LLD		0			
45			0			0			
46			44	SEE MAP	0			0	
47			0			0.05	<LLD		
48			0			0.05	<LLD		
49	0			0					
50	0			0					

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
 Total Background Count time: \_\_\_\_\_


\_\_\_\_\_  
 \_\_\_\_\_

$$LLD (95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$$

LLD (95%) = \_\_\_\_\_

REMARKS:

N



W.F.T.S. 10  
(9/86)



REMOVABLE CONTAMINATION LEVELS (SMEARS)\*

5/2/16

DAN TULLO  
Surveyor

Swipe counts of CERL,  
And Western fish.  
Purpose of Survey

7/22/82  
Date

Location	1	2	3	4	5	6	7	8
Location	BKG	Gross β cpm w/ <sup>3</sup> H	Net β cpm w/ <sup>3</sup> H	Gross β cpm w/o <sup>3</sup> H	Net β cpm w/o <sup>3</sup> H	Net β μCi w/o <sup>3</sup> H	Net <sup>3</sup> H cpm	Net <sup>3</sup> H μCi
WFTS Rm 12 Doorsill	33.6	42.0	2.20 8.4					<.007
WFTS Rm 12 NE floor Corners	33.6	38.0	<2.20 4.4					<.007
WFTS Rm 12 Book shelves	33.6	43.5	2.20 9.9					<.007
WFTS Rm 12 110 elect. strip No. wall	33.6	32.5	<2.20 0.0					<.007
WFTS. Rm 10 North wall	33.6	50	<2.20 16.4					<.007
WFTS Rm 10 doors	33.6	108.5	74.9					.028
WFTS Rm 10 door 20	33.6	38.0	2.20 4.4					<.007
CERL 266 7/21 oven door interior	33.6	39.5	2.20 5.9					<.007
CERL 266 oven interior	33.6	57.5	23.9					.009
CERL 266 Lower oven front	33.6	36.5	2.20 2.9					<.007

\* No smearing efficiency value is factored into these results.

H.S.P.

Instrument used: NMC PCC-11T 054 Rad. cent. Lower Limit of Detection

LLD(95%) = 19.1 cpm

LLD(β w/o <sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

LLD(<sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

$$4.66 \times \frac{\sqrt{670}}{2}$$

eff = .0012

USE REVERSE SIDE FOR CALCULATIONS

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Willamette Research Station (WRS or WFTS) 11  
Final Contamination Survey.**

Description and Historic Use:

Single lab (225 ft<sup>2</sup>). Carbon-14 and phosphorus-32 tracers, and nickel-63 and hydrogen-3:scandium sealed sources. WRS 11 was decommissioned from restricted use on June 16, 1992. No isotope use since 1992. There is no record of leakage of any sealed sources used in this area.

Surveys:

A total (fixed + removable) contamination survey was conducted in WRS 11 in November 2004. All points surveyed (10) demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. HVAC duct swipes were made in November 2004 which indicated no significant contamination (0.32 Bq/100 cm<sup>2</sup>).

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of WRS 11 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination (duct) was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter.




NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION WRS

ROOM 11





UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
ENVIRONMENTAL RESEARCH LABORATORY  
200 S.W. 35TH STREET  
CORVALLIS, OREGON 97333

MEMORANDUM

TO: File DATE: June 16, 1992  
FROM: Jay D. Gile *J. Gile*  
Radiation Safety Officer  
RE: Decommission of WRS 11

As of June 15, 1992, all radioactive materials and waste have been removed from WRS Radioisotope Lab Room 11. One slightly contaminated instrument (bag sealer) was appropriately bagged and labeled and left in the lab for decay. The laboratory was surveyed and found free of any radioactive contamination.

The authorization to use P-32 (J. Armstrong, 1985) has been deactivated.

cc: L. Watrud  
P. Monaco

MANTECH ENVIRONMENTAL TECHNOLOGY , INC  
ECOLOGICAL RESEARCH  
200 SW 35TH STREET  
CORVALLIS, OREGON 97333

M E M O R A N D U M

TO: Jay Gile DATE: June 16, 1992  
ERL-C Radiation Safety Officer

FROM: Phil Monaco *Q.A. Monaco*  
Health and Radiation Safety COPY:

RE: Decommission of WRS 11

On June 15, 1992, I removed all radioactive materials (P-32) waste from WRS lab 11 in preparation for the departure Dr. John Armstrong. Following removal of all materials, all equipment which was used for isotope work, the hood, hood cabinet and the laboratory was surveyed for evidence of contamination.

One piece of equipment (a bag sealer) had slight contamination (200 net cpm) on the inner sealing surface. The sealer was placed in a plastic bag, appropriately labeled with isotope and date, and placed in a drawer. This article does not present a radiation hazard.

Results of the survey demonstrate that the laboratory is free from contamination. All radioactive materials signs and postings were removed from the room.

I recommend that this room, WRS 11, be recognized as a decommissioned radioactive materials laboratory.

Since John will be leaving, it is appropriate that his authorization be deactivated.

Attachment: Survey Results

U.S. EPA  
ENVIRONMENTAL RESEARCH LABORATORY - CORVALLIS

Log No. \_\_\_\_\_

RADIATION CONTAMINATION SURVEY

Date: 6-15-92 Type of Survey: DeCommissioning Survey

Isotope(s): 32 P

Gross Background Counts: 125 ± CPM Total Count Time (min.): 1

Lower Limits of Detection:  $(\sqrt{125})^2 = 1.1 D_{95} = 34 \text{ cpm net}$  cpm

Instrument Used:  GFPC  LSC  GM  Ion Chamber  Scintillation Model: Ludlum #3 S/N: 77207

Background: 125 CPM±SD DPM±SD Standard ( ): 17,000 dpm Error

Swipe No.	Room No.	Swipe Description	Nuclide: <u>32 P (32P)</u>			Nuclide: _____		
			CPM±SD	Net DPM	Net Activity per 100 cm <sup>2</sup>	CPM±SD	Net DPM	Net Activity per 100 cm <sup>2</sup>
		Scissors	0					
		Filtration unit	0					
		Shield 1	0					
		Shield 2	0					
		Shield 3	0					
		Forceps	0					
		bag sealer	200					
		floor	0					
		Cabinet	0					
		hood	0					
		counters	0					
		phone	0					

Notes: All areas free of radioactive contamination with the exception of the bag sealer.  
 Guy A. Mowry 6/15/92

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Willamette Research Station (WRS or WFTS) 12  
Final Contamination Survey.**

Description and Historic Use:

Single lab (225 ft<sup>2</sup>). Carbon-14 tracer, and nickel-63 and hydrogen-3:scandium sealed sources. No isotope use since prior to 1986. There is no record of leakage of any sealed sources used in this area.

Surveys:

Total (fixed + removable) and removable contamination surveys were conducted in WRS 12 in November 2004. All points surveyed (12 total and 12 removable) demonstrated no significant contamination. Seven swipes points indicated very low levels of removable contamination from tritium (0.18 – 0.46 Bq/100 cm<sup>2</sup>). This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities. HVAC duct swipes were made in November 2004 which indicated no significant contamination (0.35 Bq/100 cm<sup>2</sup>).

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of WRS 12 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector. Removable contamination was determined using methanol-wetted swipes counted in a Packard 2200 CA dual channel Liquid Scintillation Counter








NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION WRS ROOM 12



WFTS

AREA CONTAMINATION SURVEY SHEET

WFTS

Radionuclide(s) Surveyed: <sup>14</sup>C, <sup>3</sup>H

Date: 9-24-86

Method of Detection: LSC

P. Monaco  
Radiation Safety Technician

Swipe #	Location		Nuclide: <sup>3</sup> H		
	RM #	Area	NET CPM	NET DPM	μCi
24	12	SEE MAP	15.9	51.81	
25	}	}	0		
26			1.30	< LLD	
27			0		
28			0		
29			0		
30			0		
31			0		
32			0		
33			0.7	< LLD	
34			0		
35			0		
36			0		
37			0		

Nuclide: <sup>14</sup> C		NET CPM	NET DPM	μCi
NET CPM	NET DPM			
14.05	11.06			
3.05	< LLD			
0				
2.65	< LLD			
0				
0				
0				
0				
0.85	< LLD			
1.05	< LLD			
0				
0				
0				

Calculation of Lower Limits of Detection (LLD)

Nuclide: <sup>3</sup>H      Nuclide: <sup>14</sup>C  
 \_\_\_\_\_      275  
 \_\_\_\_\_      20'

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

$(95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$

LD (95%) =

3.04      386

REMARKS:

AREA CONTAMINATION SURVEY SHEET

WFTS

Radionuclide(s) Surveyed: <sup>14</sup>C <sup>3</sup>H

Date: 9/24/86

Method of Detection: LSC

P. Monaw  
Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:			
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi	
	<del>38</del>								
38	10	SEE MAP	0			0			
39	}	}	0			3.05	3.92		
40			0.5	<LLD		3.25	<LLD		
41			0			0			
42			2.50	10.62		6.25	6.50		
43			0			0			
44			0.1	<LLD		0			
45			0			0			
46			44	SEE MAP	0			0	
47					0			0.05	<LLD
48					0			0.05	<LLD
49			0			0			
50			0			0			

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_

Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

$$LLD (95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$$

LLD (95%)= \_\_\_\_\_

REMARKS:

REMOVABLE CONTAMINATION LEVELS (SMEARS)\*

SL 16

DAN TULLO  
Surveyor

Swipe counts of CERL,  
and western fish.  
Purpose of Survey

7/22/82  
Date

Location	1	2	3	4	5	6	7	8
Location	BKG	Gross B cpm w/ <sup>3</sup> H	Net B cpm w/ <sup>3</sup> H	Gross B cpm w/o <sup>3</sup> H	Net B cpm w/o <sup>3</sup> H	Net B μCi w/o <sup>3</sup> H	Net <sup>3</sup> H cpm	Net <sup>3</sup> H μCi
WFTS Rm 12 Doorsill	33.6	42.0	2LLD 8.4					<.007
WFTS Rm 12 NE floor Counner	33.6	38.0	2LLD 4.4					<.007
WFTS Rm 12 Book shelves	33.6	43.5	2LLD 9.9					<.007
WFTS Rm 12 110 elect. > trip No. wall	33.6	32.5	2LLD 0.0					<.007
WFTS. Rm 10 North wall	33.6	50	2LLD 16.4					<.007
WFTS Rm 10 doors	33.6	108.5	74.9					.028
WFTS. Rm 10 door 20	33.6	38.0	2LLD 4.4					<.007
CERL 266 7/21 oven door interior	33.6	39.5	2LLD 5.9					<.007
CERL 266 oven interior	33.6	57.5	23.9					.009
CERL 266 Lower oven front	33.6	36.5	2LLD 2.9					<.007

\* No smearing efficiency value is factored into these results.

H 37/11

Instrument used: NMC PCC-11T OSU Rad. cent. Lower Limit of Detection

LLD(95%) = 19.1 cpm

LLD(B w/o <sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

LLD(<sup>3</sup>H) in μCi = \_\_\_\_\_ μCi

4.66 x  $\frac{\sqrt{6.79}}{2}$   
 $\epsilon = .0012$

USE REVERSE SIDE FOR CALCULATIONS

**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date: November 27, 2004**  
**Subject: Room Survey: Willamette Research Station (WRS or WFTS) 43  
Final Contamination Survey.**

Description and Historic Use:

Exposure room (225 ft<sup>2</sup>). Carbon-14 tracer. No isotope use since prior to 1986.

Surveys:

A total (fixed + removable) contamination surveys was conducted in WRS 43 in November 2004. All points surveyed (5) demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector.






NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION URS

ROOM 43



**U.S. Environmental Protection Agency  
Western Ecology Division**

**NRC Radioactive Materials License No. 36-12343-02 Termination and  
Facility Decommissioning**

**Date:** November 27, 2004  
**Subject:** Room Survey: Willamette Research Station (WRS or WFTS) 44  
Final Contamination Survey.

Description and Historic Use:

Exposure room (225 ft<sup>2</sup>). Carbon-14 tracer. No isotope use since prior to 1986.

Surveys:

A total (fixed + removable) contamination surveys was conducted in WRS 44 in November 2004. All points surveyed (7) demonstrated no contamination. This area meets the contamination criteria for unrestricted use based upon the isotopes used at our facilities

Records for this room clearly demonstrate that contamination surveys were regularly performed, the area was not subject to any significant contamination events, and the room was maintained as a contaminate-free area. We determined it was unnecessary to conduct further contamination surveys in this area given these survey results and the Western Ecology Division's historic management of radioactive material use in this area. Records of the most recent historic surveys (i.e. prior to the final decommissioning surveys) of WRS 44 are included in this report.

The survey for total contamination was conducted using a Ludlum Model 2000 Scaler equipped with a Ludlum Model 44-9, 12-cm<sup>2</sup> thin-window Geiger-Muller pancake detector.




NHEERL-WED  
RADIATION AREA SURVEY MAP

LOG NO. 04-23

LOCATION WRS

ROOM 44



86-46

WFTS

AREA CONTAMINATION SURVEY SHEET

WFTS

Radionuclide(s) Surveyed: <sup>14</sup>C, <sup>3</sup>H

Date: 9-24-86

Method of Detection: LSC

P. Monaco  
Radiation Safety Technician

Swipe #	Location		Nuclide: <sup>3</sup> H		
	RM #	Area	NET CPM	NET DPM	μCi
24	12	SEE MAP	15.9	51.81	
25	}	}	0		
26			1.30	<LLD	
27			0		
28			0		
29			0		
30			0		
31			0		
32			0		
33			0.7	LLD	
34			0		
35			0		
36			0		
37			0		

Nuclide: <sup>14</sup> C		NET CPM	NET DPM	μCi
NET CPM	NET DPM			
14.05	11.06			
3.05	<LLD			
0				
2.65	<LLD			
0				
0				
0				
0				
0.85	<LLD			
1.05	<LLD			
0				
0				
0				

Calculation of Lower Limits of Detection (LLD)

Nuclide: <sup>3</sup>H      Nuclide: <sup>14</sup>C  
 \_\_\_\_\_      275'  
 \_\_\_\_\_      20'

Gross Background Counts:  
Total Background Count time:

$$LLD (95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$$

LLD (95%)=

3.04      386

REMARKS:

AREA CONTAMINATION SURVEY SHEET

WFTS

Radionuclide(s) Surveyed: <sup>14</sup>C <sup>3</sup>H

Date: 9/24/86

Method of Detection: LSC

P. Moraw  
Radiation Safety Technician

Swipe #	Location		Nuclide:			Nuclide:			
	RM #	Area	NET CPM	NET DPM	μCi	NET CPM	NET DPM	μCi	
	<del>41</del>								
38	10	SEE MAP	0			0			
39	}	}	0			3.05	3.92		
40			0.5	<LLD		3.25	<LLD		
41			0			0			
42			2.50	10.62		6.25	6.50		
43			0			0			
44			0.1	<LLD		0			
45			0			0			
46			44	SEE MAP	0			0	
47			0			0.05	<LLD		
48			0			0.05	<LLD		
49	0			0					
50	0			0					

Calculation of Lower Limits of Detection (LLD)

Nuclide: \_\_\_\_\_ Nuclide: \_\_\_\_\_


Gross Background Counts: \_\_\_\_\_  
Total Background Count time: \_\_\_\_\_

$$D(95\%) = \sqrt{\frac{\text{Gross Background Counts}}{\text{Count Time}}} \times 4.66$$

LLD (95%)= \_\_\_\_\_

REMARKS:

N



WETS 44  
(9/86)

Spcl. Exhaust Air + Pipe

NHEERL-WED  
RADIATION AREA SURVEY

LOG NO. 04-24

DATE 11-15-04 LOCATION \_\_\_\_\_ ROOM \_\_\_\_\_ INSTRUMENT Packard LSC 2200CA SN 036755 <sup>1/2</sup>

Swipe No.	Description	Isotope <u><sup>3</sup>H</u>			Isotope <u><sup>14</sup>C</u>		
		Gross CPM	Net DPM	Activity Bq/100 cm <sup>2</sup>	Gross CPM	Net DPM	Activity Bq/100 cm <sup>2</sup>
	190 Sink	1634	6202		4923	7327	
	190 Vent, Exhaust	8	<LLD <sub>95</sub>	ND	38	22	
	CSB 1 Vent, Exhaust	3	<LLD <sub>95</sub>		24	<LLD <sub>95</sub>	
	TERF 113 VENT, Exhaust	7	<LLD <sub>95</sub>		37	22	
	WRS 10 VENT, Exhaust	9	<LLD <sub>95</sub>		35	13	
	WRS 11 VENT, Exhaust	7	<LLD <sub>95</sub>		37	19	
	WRS 12 VENT, Exhaust	2	<LLD <sub>95</sub>		36	21	
	MB 126 VENT, Exhaust	10	<LLD <sub>95</sub>		36	22	
	MB 130 VENT, Exhaust	8	<LLD <sub>95</sub>		41	28	
	MB 132 VENT, Exhaust	12	0	ND	54	50	
	MB 138 VENT, Exhaust	13	89		41	33	
	MB 228 VENT, Exhaust	7	<LLD <sub>95</sub>	ND	38	25	
		$LLD_{95} = ((\frac{\sqrt{9}}{3}) \times 2.96) + = \textcircled{12} \text{ CPM}$ BACKGROUND <u>9 CPM</u> COUNT TIME <u>3 min</u> STANDARD (64,179 DPM) <u>56,106</u> 87% off			$LLD_{95} = ((\frac{\sqrt{27}}{3}) \times 2.96) + = \textcircled{32} \text{ CPM}$ BACKGROUND <u>27</u> COUNT TIME <u>3 min</u> STANDARD (84,000 DPM) <u>85,392</u> 102% off		

Comments:

*DM*  
Radiation Safety Specialist


11-29-04  
Date











19  
2

CSB 1

RADIOACTIVE MATERIALS

TOXICS

C-2A

CHEMICALS & SOLVENTS

C-5  
MECHANICAL ROOM

GAS BOTTLES


C-1

C-2


C-4

CHEMICAL STORAGE BUILDING







MAIN BUILDING, SECOND FLOOR



WILDLIFE TOXICOLOGY FACILITY

PEB/WLD/WRF



SOIL MIXING #2

WORM ROOM

SOIL MIXING #1

BUILDING 8-20

GH #8

GH #2

GH #1

112

113

EX 113

111

115

116

114

109

110

HB  
104

105A

105

EX 105

108

106


107

TERRESTRIAL ECOLOGY RESEARCH FACILITY


TERF

REVISIONS		DATE	BY
UNITED STATES ENVIRONMENTAL PROTECTION AGENCY CORVALLIS ENVIRONMENTAL RESEARCH LABORATORY			
DESIGNED	REVISIONS	DATE	
DRAWN	NO. OF	DATE	BY
CHECKED	DATE	DATE	BY
APPROVED	DATE	DATE	BY





FIRST FLOOR  
WFTS MAIN BUILDING



SECOND FLOOR  
WFTS MAIN BUILDING

WES  
10, 11, 12, 43, 44

