



Entergy Nuclear Operations, Inc.
Pilgrim Station
600 Rocky Hill Road
Plymouth, MA 02360

June 28, 2006

Stephen J. Bethay
Director, Nuclear Assessment

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

SUBJECT: Entergy Nuclear Operations, Inc.
Pilgrim Nuclear Power Station
Docket No. 50-293, License No. DPR-35

Request For Approval of ASME Code, Section XI, Third Ten-Year Pilgrim Relief Request, PRR-42, Examinations of Component Welds with Less Than Essentially 100% Examination Coverage

- REFERENCES
1. Entergy (BECO) Letter No. 2.95.091, ASME Section XI, Third Interval Inservice Inspection Plan, Pilgrim Nuclear Power Station, dated September 1, 1995
 2. ASME Section XI, Code Case N-460, "Alternative Examination Coverage for Class 1 and Class 2 Welds, Section XI, Division 1"

LETTER NO. 2.06.054

Dear Sir or Madam:

By Reference 1, Entergy submitted Pilgrim Third Ten-Year Inservice Inspection Plan for the interval of July 1, 1995 to June 30, 2005, in accordance with the 1989 ASME Code, Section XI requirements pursuant to 10 CFR 50.55a.

During the Third Ten-Year interval, Pilgrim completed the required in-service examinations in accordance with the plan; except, certain components could not fully meet the volumetric examination requirements stipulated in the 1989 ASME Code, Section XI, including the clarifications provided in the ASME Code Case N-460 (Ref. 2). Entergy has determined that conformance with the code requirement of essentially 100% coverage of weld volume or area examined was impractical due to various constraints and limitations. Accordingly, pursuant to 10 CFR 50.55a (g)(5)(iii), Entergy submits the attached Pilgrim Relief Request No, PRR-42, for NRC review and approval.

PRR-42 proposes alternatives where the requirement of "essentially 100%" volumetric examination was not feasible due to construction limitations, obstructions, accessibility, and examination techniques. The alternatives and justifications are explained in the attached relief request providing a list of components which requires relief pursuant to 10 CFR 50.55a. The alternatives and justifications provide acceptable level of quality and safety and will not adversely impact the health and safety of the public.


There are no commitments contained in this letter.

A1047

A similar ISI Relief Request No. B-5 for Vermont Yankee Nuclear Power Station was approved by the NRC Letter dated September 19, 2005 (TAC. No. MC 0959).

If you have any questions on this transmittal, please contact Mr. Bryan Ford, Licensing Manager at 508-830-8403.

Sincerely,


Stephen J. Bethay

WGL/dm

Attachments: 1. Pilgrim Relief Request, PRR-42 (8 pages)
2. Pilgrim 3rd Interval ISI Program Data Sheets for Examinations with less than "Essentially 100% coverage (240 pages)

cc: Mr. James Shea, Project Manager
Office of Nuclear Reactor Regulation
Mail Stop: 0-8B-1
U.S. Nuclear Regulatory Commission
1 White Flint North
11555 Rockville Pike
Rockville, MD 20852

U.S. Nuclear Regulatory Commission
Region 1
475 Allendale Road
King of Prussia, PA 19406

Senior Resident Inspector
Pilgrim Nuclear Power Station

PILGRIM RELIEF REQUEST PRR-42

Attachment 1 to Entergy Letter 2.06.054

**Entergy Nuclear Northeast
Pilgrim Nuclear Power Station
3rd 10-Year ISI Interval Closeout**

**Proposed Alternative
In Accordance with 10 CFR 50.55a(g)(5)(iii)
(Inservice Inspection Impracticality - Alternative Provides Acceptable Level
of Quality and Safety)**

1. ASME Code Component(s) Affected

Code Classes: 1, 2

References: Subarticle IWB-2500, Subarticle IWC-2500, GL 88-10, NUREG 0313,
ASME Code Case N-460

Examination Categories: B-A, B-D, B-F, B-H, B-J, B-O, C-C, C-F-1 and C-F-2

Item Numbers: B1.12, B1.21, B1.30, B3.90, B5.10, B5.130, B8.10, B9.11, B9.21,
B14.10, C3.20, C5.11, C5.51

Description: Volumetric and Surface Examination Coverage

Component Numbers: Various, see Table 3

2. Applicable Code Edition and Addenda

1989 Edition with no addenda

3. Applicable Code Requirements

Subarticle IWB-2500 states in part "Components shall be examined and tested as specified in Table IWB-2500-1". Table IWB-2500-1 requires a volumetric examination or a surface and volumetric examination be performed on the component based on Category and Item Number. The applicable examination area or volume and method required are as shown below from Table IWB-2500-1:

TABLE 1

Examination Category	Item Number	Examination Requirements /Figure Number	Examination Method
B-A	B1.12	IWB-2500-2	Volumetric
B-A	B1.21	IWB-2500-3	Volumetric
B-A	B1.30	IWB-2500-4	Volumetric
B-D	B3.90	IWB-2500-7	Volumetric
B-F	B5.10	IWB-2500-8	Volumetric and Surface
B-F	B5.130	IWB-2500-8	Volumetric and Surface
B-H	B8.10	IWB-2500-13	Surface
B-J	B9.11	IWB-2500-8	Volumetric and Surface
B-J	B9.21	IWB-2500-8	Surface
B-O	B14.10	IWB-2500-18	Volumetric or Surface

PILGRIM RELIEF REQUEST PRR-42

Subarticle IWC-2500 states in part, "Components shall be examined and pressure tested as specified in Table IWC-2500-1." Table IWC-2500-1 requires a surface examination or a surface and volumetric examination to be performed on the component based on Category and Item Number. The applicable examination area or volume and method required are as shown below from Table IWC-2500-1:

TABLE 2

Examination Category	Item Number	Examination Requirements / Figure Number	Examination Method
C-C	C3.20	IWC-2500-5	Surface
C-F-1	C5.11	IWC-2500-7	Surface & Volumetric
C-F-2	C5.51	IWC-2500-7	Surface & Volumetric

The Code requires that the entire volume or area be examined.

4. Impracticality of Compliance

Entire volume or area required is defined by ASME Section XI Code Case N-460 titled "Alternative Examination Coverage for Class 1 and Class 2 Welds, Section XI, Division 1". Code Case N-460 states in part, "...when the entire examination volume or area cannot be examined... a reduction in examination coverage... may be accepted provided the reduction in coverage for that weld is less than 10%".

The NRC through Information Notice 98-42 titled "Implementation of 10 CFR 50.55a(g) Inservice Inspection Requirements" termed the reduction in coverage of less than 10% to be "essentially 100 percent". Information Notice 98-42 states in part, "The NRC has adopted and further refined the definition of 'essentially 100 percent' to mean 'greater than 90 percent'... has been applied to all examinations of welds or other areas required by ASME Section XI."

Pilgrim's piping systems and associated components were designed and fabricated before the examination requirements of ASME Section XI were formalized and published. Since this plant was not specifically designed to meet the requirements of ASME Section XI, literal compliance is not feasible or practical within the limits of the current plant design.

Physical obstructions imposed by design, geometry and materials of construction are typical of vessel appurtenances, biological shield wall, insulation support rings, structural and component support members, adjacent component weldments in close proximity, unique component configurations (valves and pumps), and dissimilar metal weldments.

Therefore, examination of the entire volume or area for some of the components which are listed in Table 3 cannot be achieved. The specifics of the limitations and restrictions are also provided in Table 3. The Attachment 2 to this relief request provides the actual data sheets of examinations with less than essentially 100% coverage.

Accordingly, pursuant to 10 CFR 50.55a(g)(5)(iii), Entergy has determined that conformance with the code requirement of essentially 100% coverage of weld volume or area examined was impractical due to various constraints and limitations as stated above. Entergy requests NRC approval of the proposed alternative as stated below.

PILGRIM RELIEF REQUEST PRR-42

5. Burden Caused by Compliance

To increase the percentage coverage of the volume or area examined, the Reactor Pressure Vessel (RPV), Class 1 piping nozzles, portion of the Class 1 piping system, the CRD Housing, and a number of the Class 2 piping system support lugs would have to be re-designed, re-fabricated, or removed. These activities would also require extensive engineering and design effort, as well as the shutdown of the plant for modification installation. These activities are impractical for the plant to undertake.

6. Proposed Alternative and Basis for Use

- A). The components listed in Table 3 have already been examined by the available methods to the maximum extent practical. No additional volumetric or surface examinations will be performed on the components for the 3rd Inservice Inspection Interval.
- B). A visual inspection (VT-2) is performed by VT-2 qualified operators on the subject components during the system pressure tests (with no leakage detected) as required by code category B-P (each refueling outage) and category C-H (each period).

Basis for Use

As a minimum, all components received the required examination(s) to the extent practical with regard to the limited or lack of access available. The examinations conducted confirmed satisfactory results evidencing no unacceptable flaws present, even though "essentially 100%" coverage was not attained. PNPS has concluded that if any active degradation mechanisms were to exist in the subject welds, those degradations would have been identified in the examinations performed.

For surface examinations PNPS calculated the coverage percentage based on the area that was examined within the required coverage area divided by the required surface area to be inspected. For volumetric (ultrasonic) examinations there are many ways to calculate coverage. PNPS elected to use the following method. The required examination volume was calculated. The examination was performed in accordance with an approved ultrasonic procedure that met the governing Code requirements. The approved procedure requires a number of angles and a number of beam directions for each angle. For each angle/beam direction combination the volume interrogated by that beam was calculated (within the required coverage volume). Then that value was divided by the required examination volume to determine percentage coverage for each angle/beam-direction combination. Then those required angle/beam-direction coverage percentages were averaged to determine an overall composite coverage. For example, prior to invoking Appendix VIII, ASME Section V, Article 4 required 0°, 45°, and 60° search units for examining vessel welds from the OD of the vessel. The 45° and 60° search units are each required to be scanned in four orthogonal directions. Therefore, a total of nine angle/beam- directions are required and a coverage percentage is calculated for each of those nine angle/beam-direction combinations. Then those nine values are averaged to determine the overall composite coverage. (Note: Since Appendix VIII was invoked for vessel welds, the required number of angle/beam-direction combinations now depends on the qualified procedure, and thus the calculation would be different.)

For the most part, PNPS did not select alternative welds when coverage was limited on the scheduled weld. A sample plan implies a certain amount of random choice in the

PILGRIM RELIEF REQUEST PRR-42

selection of welds for examination — unless there are more conservative ways to select the sample, such as selecting high stress points or welds where industry experience indicates that damage mechanisms are more likely. This is why for Category C-F-2, terminal end welds are singled out; they are more typically high stressed. The reason for interferences is usually independent of the flaw mechanism. However, there may be cases where this is not true. For example, valve-to-pipe welds and pump-to-pipe weld geometries may inhibit coverage. But, these welds may actually have higher stresses because of their configurations. In these cases, if alternative welds were selected, the sample of higher stressed welds in the population would be diluted. If alternative welds are chosen, the selection randomness decreases. Flaw mechanisms associated with test limitations may be missed and it may be better to accept the limited coverage than to select alternative welds.

There is Code precedent for allowing limited coverage due to inaccessibility. ASME Section XI exempts certain Class 1 and Class 2 welds from examination based on the criteria that they are inaccessible. Paragraphs IWB-1220(c) and IWC-1230 exempt welds that are inaccessible due to control rod drive penetrations or because they are encased in concrete. The Code recognizes that examination of these welds is not possible, and therefore, a Relief Request would not be necessary. The same logic applies to portions of welds that are inaccessible and where examination of those portions of welds is not possible.

To summarize, PNPS has examined all components in the 3rd Interval ISI Program and associated augmented programs to the maximum extent possible given the inspection limitations discussed above. The portion of the PNPS ISI Program surface and volumetric inspection sample that could not be examined (expressed in inches of weld metal) due to limitations/interferences during the 3rd ten year interval is approximately 4% when compared to the total weld length that could have been examined if no limitations had been present.

When the PNPS ISI Program is viewed in total, the overall degree of coverage obtained is still greater than 90%, i.e. essentially 100%. For this and the other reasons detailed in this request, Entergy believes that the limited coverage obtained on the components listed in Table 3 is not significant and will provide an adequate level of quality and safety for examination of the affected welds, and will not adversely impact the health and safety of the public.

7. Duration of Proposed Alternative

Relief is requested for the third ten-year interval of the Inservice Inspection Program for Pilgrim, which began July 1, 1995 and concluded June 30, 2005.

8. Attachment

Pilgrim 3rd Interval ISI program datasheets for examinations with less than “Essentially 100%” coverage are attached (Attachment 2).

PILGRIM RELIEF REQUEST PRR-42

TABLE 3

COMPONENTS WITH LESS THAN "ESSENTIALLY 100%" COVERAGE						
CODE CATEGORY	CODE ITEM	COMPONENT ID	DESCRIPTION	COMBINED NDE COVERAGE		LIMITATION (CAUSE OF REDUCED COVERAGE)
				MT/PT	UT	
B-A	B1.21	RPV-BH-C1	HEAD CIRCUMF. WELD	---	75	VESSEL SKIRT CONFIGURATION AND THERMOCOUPLES
B-A	B1.12	RPV-L-1-338A	LOWER INTERMEDIATE SHELL VERTICAL WELD	---	89	JET PUMP RISER SUPPORT INTERFERENCE
B-A	B1.12	RPV-L-1-338C	LOWER INTERMEDIATE SHELL VERTICAL WELD	---	25	JET PUMP RISER SUPPORT, SURV. SPECIMEN HOLDER & SUPPORT BRACKETS, SHROUD REPAIR TIE ROD INTERFERENCE
B-A	B1.12	RPV-L-2-338A	LOWER SHELL VERTICAL WELD	---	73	BAFFLE PLATE AND BAFFLE GUSSET INTERFERENCE
B-A	B1.12	RPV-L-2-338B	LOWER SHELL VERTICAL WELD	---	78	BAFFLE PLATE GUSSET INTERFERENCE
B-A	B1.12	RPV-L-2-338C	LOWER SHELL VERTICAL WELD	---	25	BAFFLE PLATE, GUSSET, SHROUD REPAIR TIE ROD INTERFERENCE, N2K NOZZLE
B-A	B1.12	RPV-L-2-339A	UPPER INTERMEDIATE SHELL VERTICAL WELD	---	81	FW AND CS SPARGER INTERFERENCE
B-A	B1.12	RPV-L-2-339B	UPPER INTERMEDIATE SHELL VERTICAL WELD	---	75	FW AND CS SPARGER INTERFERENCE AND ID TAPER
B-A	B1.12	RPV-L-2-339C	UPPER INTERMEDIATE SHELL VERTICAL WELD	---	83	FW AND CS SPARGER INTERFERENCE
B-A	B1.30	RPV-SF-0-120	SHELL TO FLANGE	---	81	N3 NOZZLES, NOZZLE PLUGS, GUIDE RODS @ 0 & 180 deg, FLANGE CONFIGURATION

PILGRIM RELIEF REQUEST PRR-42

COMPONENTS WITH LESS THAN "ESSENTIALLY 100%" COVERAGE						
CODE CATEGORY	CODE ITEM	COMPONENT ID	DESCRIPTION	COMBINED NDE COVERAGE		LIMITATION (CAUSE OF REDUCED COVERAGE)
				MT/PT	UT	
B-A	B1.30	RPV-SF-120-240	SHELL TO FLANGE	---	81	N3 NOZZLES, NOZZLE PLUGS, GUIDE RODS @ 0 & 180 deg, FLANGE CONFIGURATION
B-A	B1.30	RPV-SF-240-360	SHELL TO FLANGE	---	81	N3 NOZZLES, NOZZLE PLUGS, GUIDE RODS @ 0 & 180 deg, FLANGE CONFIG.
B-D	B3.90	RPV-N7A-NV	NOZZLE TO VESSEL	---	56.7	NOZZLE CONFIGURATION
B-D	B3.90	RPV-N7B-NV	NOZZLE TO VESSEL	---	56.7	NOZZLE CONFIGURATION
B-D	B3.90	RPV-N8-NV	NOZZLE TO VESSEL	---	70.6	NOZZLE CONFIGURATION
B-F	R1.20 (B5.130)	14-A-10A	VALVE TO PIPE	---	37.1	PIPE TO VALVE WELD PROFILE
B-F	R1.20 (B5.130)	14-B-10A	VALVE TO PIPE	---	22.1	PIPE TO VALVE WELD PROFILE
B-F	R1.20 (B5.10)	2R-N1B-1	NOZZLE TO SAFE END	---	75	REDUCED COVERAGE ON CIRC. SCANS DUE TO SURFACE CONTOUR AND MIN. WALL ISSUES
B-F	R1.20 (B5.10)	2R-N2E-1	SAFE END TO NOZZLE	---	81.2	REDUCED COVERAGE ON CIRC. SCANS DUE TO SURFACE CONTOUR AND MIN. WALL ISSUES
B-F	R1.20 (B5.10)	2R-N2G-1	SAFE END TO NOZZLE	---	75.3	REDUCED COVERAGE ON CIRC. SCANS DUE TO SURFACE CONTOUR AND MIN. WALL ISSUES
B-F	R1.20 (B5.10)	2R-N2J-1	SAFE END TO NOZZLE	---	75	REDUCED COVERAGE ON CIRC. SCANS DUE TO SURFACE CONTOUR AND MIN. WALL ISSUES
B-F	R1.11 (B5.10)	6-N4A-1	SAFE END TO NOZZLE	---	87.5	REDUCED COVERAGE DUE TO WELDED THERMOCOUPLE PADS
B-F	R1.11 (B5.10)	6-N4B-1	SAFE END TO NOZZLE	---	87.5	REDUCED COVERAGE DUE TO WELDED THERMOCOUPLE PADS
B-F	R1.11 (B5.10)	6-N4C-1	SAFE END TO NOZZLE	---	88.6	REDUCED COVERAGE DUE TO WELDED THERMOCOUPLE PADS

PILGRIM RELIEF REQUEST PRR-42

COMPONENTS WITH LESS THAN "ESSENTIALLY 100%" COVERAGE						
CODE CATEGORY	CODE ITEM	COMPONENT ID	DESCRIPTION	COMBINED NDE COVERAGE		LIMITATION (CAUSE OF REDUCED COVERAGE)
				MT/PT	UT	
B-F	R1.11 (B5.10)	6-N4D-1	SAFE END TO NOZZLE	---	88.6	REDUCED COVERAGE DUE TO WELDED THERMOCOUPLE PADS
B-H	B8.10	RPV-SBW-0	RPV STABILIZER WELD	37	---	ONLY UPPER SURFACE ACCESSIBLE
B-J	R1.20 (B9.11)	10-IA-14	PIPE TO FLUED HEAD	---	50	PIPE TO PENETRATION FLUED HEAD CONFIGURATION
B-J	R1.20 (B9.11)	10-IA-15	PIPE TO VALVE	---	50	PIPE TO VALVE WELD PROFILE
B-J	R1.11 (B9.11)	10R-IA-6	PIPE TO VALVE	---	50	PIPE TO VALVE WELD PROFILE
B-J	R1.11 (B9.11)	10R-IA-7	VALVE TO PIPE	---	50	PIPE TO VALVE WELD PROFILE
B-J	R1.20 (B9.11)	12-O-24	PENETRATION TO PIPE	---	56.6	PENETRATION FLUED HEAD TO PIPE CONFIGURATION
B-J	R1.20 (B9.11)	14-A-19	PIPE TO VALVE	---	50	PIPE TO VALVE WELD PROFILE
B-J	R1.20 (B9.11)	14-B-17	PIPE TO PENETRATION	---	58.7	PIPE TO PENETRATION FLUED HEAD CONFIGURATION
B-J	R1.20 (B9.11)	14-B-20	PIPE TO PIPE	---	59.4	WALL OBSTRUCTION
B-J	R1.11 (B9.21)	1-SD-10R	PIPE TO VALVE	---	87.5	PIPE TO VALVE WELD PROFILE
B-J	R1.20 (B9.11)	2R-HB-1	HEADER TO BEND	---	75	REDUCER TO PIPE CONFIGURATION
B-J	R1.20 (B9.11)	2R-HB-4	HEADER TO BEND	---	75	REDUCER TO PIPE CONFIGURATION
B-O	B14.10	RPV-CRD-HSG-1	CRD HOUSING WELD	70	---	LIMITED EXAM DUE TO ADJACENT DRIVES; DRIVES CHOSEN TO MAXIMIZE COVERAGE; SHOOTOUT STEEL REMOVED FOR EXAM.
B-O	B14.10	RPV-CRD-HSG-2	CRD HOUSING WELD	50	---	LIMITED EXAM DUE TO ADJACENT DRIVES; DRIVES CHOSEN TO MAXIMIZE COVERAGE; SHOOTOUT STEEL REMOVED FOR EXAM.
B-O	B14.10	RPV-CRD-HSG-3	CRD HOUSING WELD	50	---	LIMITED EXAM DUE TO ADJACENT DRIVES; DRIVES CHOSEN TO

PILGRIM RELIEF REQUEST PRR-42

COMPONENTS WITH LESS THAN "ESSENTIALLY 100%" COVERAGE						
CODE CATEGORY	CODE ITEM	COMPONENT ID	DESCRIPTION	COMBINED NDE COVERAGE		LIMITATION (CAUSE OF REDUCED COVERAGE)
				MT/PT	UT	
						MAXIMIZE COVERAGE; SHOOTOUT STEEL REMOVED FOR EXAM.
B-O	B14.10	RPV-CRD-HSG-4	CRD HOUSING WELD	65	---	LIMITED EXAM DUE TO ADJACENT DRIVES; DRIVES CHOSEN TO MAXIMIZE COVERAGE; SHOOTOUT STEEL REMOVED FOR EXAM.
C-C	C3.20	EB-23-13HL1(4)	SUPPORT LUGS	87.5	---	HANGER CLAMP AGAINST 1 SIDE OF LUG
C-C	C3.20	EB-23-59HL1(4)	SUPPORT LUGS	83.3	---	HANGER CLAMP AGAINST 1 SIDE OF LUG
C-C	C3.20	HL-10-200HL1(4)	SUPPORT LUGS	90	---	HANGER CLAMP AGAINST 1 SIDE OF LUG
C-F-1	C5.11	GB-14-F34	PIPE TO VALVE	---	29.8	PIPE-TO VALVE WELD PROFILE
C-F-2	C5.51	GB-10-9-2E	WELDOLET	85	63.8	PIPE CLAMP OBSTRUCTION
C-F-2	C5.51	HE-26-F238	VALVE TO PIPE	---	68.8	ONE-SIDED EXAM DUE TO VALVE

Attachment 2 to Entergy Letter 2.06.054

**Entergy Nuclear Northeast
Pilgrim Nuclear Power Station
3rd Interval ISI Program Data Sheets
for Examinations with less than
“Essentially 100% coverage (240 pages)**



206054 Attach 2.pdf

Attachment 2 to Entergy Letter 2.06.054

**Pilgrim 3rd Interval ISI Program Data Sheets for
Examinations with less than
“Essentially 100% coverage
(240 pages)**

**(Third Ten-Year ISI Interval:
July 1, 1995 to June 30, 2005)**

APRIL 2006

Pages 1 of 240



GE ENERGY, NUCLEAR

EXAMINATION SUMMARY SHEET

Report No.: PNL-R15-05-002

Site: Pilgrim Nuclear Power Station Component ID: RPV-BH-C1
 Outage: RF-015 HEAD CIRCUMF WELD
 System RPV ASME Cat.: B-A ASME Item B1.21 Aug Req N/A

Exams Performed	Data Sheet	Cal Sheet	Procedure	Calibration Block	Examination Personnel	Cert Level	Date
60° Long.	UT-086	N/A	TP04-01E (GE-UT-300)	PIL-5E	Scott Erickson	II	4/28/2005
60° Long.	UT-087	N/A	TP04-01E (GE-UT-300)	CAL-IIW2-033	Scott Erickson	II	4/28/2005
60° Long.	UT-088	N/A	TP04-01B (GE-UT-300)	CAL-IIW2-017	Steve Snyder	II	4/28/2005
60° Long.	UT-089	N/A	TP04-01B (GE-UT-300)	PIL-5B	Steve Snyder	II	4/28/2005
45° Shear	UT-090	N/A	TP04-01B (GE-UT-300)	PIL-5B	Steve Snyder	II	4/28/2005
45° Shear	UT-091	N/A	TP04-01B (GE-UT-300)	PIL-5B	Steve Snyder	II	4/28/2005

Examination Results:

Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1989 Edition no Addenda, and Section XI, 1995 Edition with the 1996 Addenda as modified by the PDI program description and the Federal Register, Part II, Nuclear Regulatory Commission, 10 CFR Part 50 for Category B-A Reactor Pressure Vessel (RPV) Assembly Welds.

Manual transverse and parallel scans were performed in accordance with procedure GE-UT-300 V8 using 60° RL search units.

Scanning was restricted from one side of the weld due to the vessel skirt configuration and thermocouples.

Manual UT exams recorded (3) three indications, that were acceptable to the requirements of Section XI.

Coverage = 75%

Examination results were compared to data report 95-E-528,534,531 from 1995 outage with No Change
 These examinations were performed under Work Order: N/A Change

This Summary and the following data sheets have been reviewed and accepted by the following personnel:

BMD UT 4-30-05 UT L.I. III 5-4-05
 Prepared By: Level: Date: Utility Review: Date:
Carl Hansen 5/4/05
 ANII Review: Date:

RWP: 0081
 Dose: 110 mr.
 Page 1 of 12



GE ENERGY, NUCLEAR

Ultrasonic Calibration and Examination Record RPV Components

Site/Unit: Pilgrim Nuclear Power Station / 1
Outage: RF-015

Data Report Number: PIL-R15-05-002 Linearity Sheet: L-002
Data Sheet Number: UT-088

Procedure: TP04-018 (GE-UT-300)

Rev.: R0 (V2) DRR: N/A

Calibration Block: PIL-5B

CS	Flt:	4.35"
Material	Size	Thickness
Initial Cal: <u>1254</u>		Exam Start: <u>1330</u>
Cal Check: <u>N/A</u>		Exam End: <u>1540</u>
Cal Check: <u>N/A</u>	<u>Ultragel II</u>	<u>01225</u>
Final Cal: <u>1631</u>	Couplant:	Batch
<u>242027</u>	<u>68°F</u>	<u>68°F</u>
Thermometer	Initial Cal Temp.	Final Cal Temp:

Search Unit Data

Sigma 22BC-03006 2/1.1"x.62"VRect.
 Manufacturer: Serial Number: Size / Shape:
0.65" 60° 60°
 Incident Point: Nominal Angle: Measured Angle:
3.0 MHz SDC3 Long
 Frequency: Model: Mode:

Search Unit Cable

RG-174 12' 0
 Cable Type: Length: Connectors:

Instrument Settings

Parameetrics / Epoch 4 031526704
 Manufacturer/Model: Serial Number:
9.59 us 0.236 in./usec. 0.8 - 3.0 MHz
 Delay/Zero: Velocity: Narrowband Filter:
Auto Fullwave 12.0 in. Sa / Mod
 Rep Rate: Rectification: Range: Pulsar:
400 Ohms 0 3.03 MHz Dual
 Damping: Reject: Frequency: Mode:
Off: Off: Off: Off:
 DAC: TVG: CSC: DGS:

DAC Construction

Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A
ID	<u>4.1"</u>	1X	<u>80%</u>	<u>7.2"</u>	<u>4.1"</u>	<u>7.2</u>
N/A	N/A	1X	N/A	N/A	N/A	N/A

DAC 1X= 63.0 dB
 Sweep 0-10 6" Depth
 Note N/A dB difference between 3/8 and 5/8 Vee

Exam Data for Weld: RPV-BH-C1
HEAD CIRCUMF WELD

Configuration:

00 72°F
 Exam Surface: Component Temperature

Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
<u>Plate</u>	<u>I</u>	<u>69.0</u>	<u>NRI</u>	<u>60°</u>
<u>Plate CW/GCW</u>	<u>E</u>	<u>69.0</u>	<u>NRI</u>	<u>60°</u>

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Acceptable Linearity performed: 4/15/2005

Comments: Cal/Exam Date is the date of examination. See coverage sheet for limitations.
 Calibration for full volume examination. Exams performed to maintain a 10 - 20% FSH clad roll.
 Exam performed from meridinal weld RPV-BH-M1 to RPV-BH-M3 and from RPV-BH-M7 to RPV-BH-M1.
 Single sided exam due to component configuration.
 Exam limited from meridinal weld # M8 measuring "L" from 31.5" to 36.5" and a "W" of 5 - 6" due to a thermocoupler.

SRE Scott Erickson II 4/28/2005
 Initials: Examiner Level Cal/Exam Date:
N/A N/A
 Initials: Examiner Level
BAM III 4-30-05
 GE Reviewed By: Level: Date:

[Signature] 5-4-05
 Utility Reviewed By: Date:
[Signature] 5/4/05
 ANII Reviewed By: Date:



GE ENERGY, NUCLEAR

Ultrasonic Calibration and Examination Record RPV Components

Site/Unit: Pilgrim Nuclear Power Station / 1
Outage: RF-015
Procedure: TP04-018 (GE-UT-300)

Data Report Number: PIL-R15-05-002 Linearity Sheet: L-002
Data Sheet Number: UT-067

Rev.: R0 (V8) DRR: N/A

Calibration Block: CAL-IIW2-033

CS	N/A	4.0"
Material	Size	Thickness
Initial Cal: <u>1258</u>		Exam Star: <u>1330</u>
Cal Check: <u>N/A</u>		Exam End: <u>1540</u>
Cal Check: <u>N/A</u>	<u>Ultrasel II</u>	<u>01225</u>
Final Cal: <u>1634</u>	Couplant:	Batch
<u>242027</u>	<u>68° F</u>	<u>68° F</u>
Thermometer	Initial Cal Temp.	Final Cal Temp.

DAC Construction

Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
1/4	0.6"	1X	80%	1.15"	582"	3.0
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A

DAC 1X= 60.8 dB
Sweep 0-10 2.0" Depth
Note N/A dB difference between 3/8 and 5/8 Vee

Search Unit Data

Siema 22BC-03006 2(1.1"x.62")/Rect.
Manufacturer: Serial Number: Size / Shape:
0.65" 60° 60°
Incident Point: Nominal Angle: Measured Angle:
3.0 MHz SDC3 Long.
Frequency: Model: Mode:

Search Unit Cable

RG-174 12' 0
Cable Type: Length: Connectors:

Instrument Settings

Panometrics / Epoch 4 031526704
Manufacturer/Model: Serial Number:
9.59 us 0.238 in./ussec. 0.8 - 3.0 MHz
Delay/Zero: Velocity: Narrowband Filter:
Auto Fullwave 4.0 in. Sc / Med
Rep Rate: Rectification: Range: Pulsar:
400 Ohms 0 3.03 MHz Dual
Damping: Reject: Frequency: Mode:
Off Off Off Off
DAC: TVG: CSC: DGS:

Exam Data for Weld: RPV-BH-C1
HEAD CIRCUMF WELD
Configuration:
00 72° F
Exam Surface: Component Temperature

Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
<u>Plate</u>	<u>I</u>	<u>74.8</u>	<u>NFI</u>	<u>60°</u>
<u>Plate CW/CCW</u>	<u>E</u>	<u>74.8</u>	<u>NFI</u>	<u>60°</u>

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Acceptable Linearity performed : 4/15/2005

Comments: Cal/Exam Date is the date of examination. See coverage sheet for limitations.
Calibration for near surface examination. Exams performed a minimum of 14 dB above reference.
Exam performed from meridinal weld RPV-BH-M1 to RPV-BH-M3 and from RPV-BH-M7 thru RPV-BH-M1.
Single sided exam due to component configuration.

ERE Scott Erickson II 4/28/2005
Initials: Examiner Level Cal/Exam Date:
N/A N/A
Initials: Examiner Level
BAM III 4-30-05
GE Reviewed By: Level: Date:

UT L. III 5-4-05
Utility Reviewed By: Date:
Carl Hoffman 5/4/05
ANII Reviewed By: Date:



GE ENERGY, NUCLEAR

Ultrasonic Calibration and Examination Record RPV Components

Site/Unit: Pilgrim Nuclear Power Station / 1

Data Report Number: PIL-R15-05-002 Linearity Sheet: L-004

Outage: RF-015

Data Sheet Number: UT-088

Procedure: TP04-018 (GE-UT-300)

Rev.: R0 (V8)

DRR: N/A

Calibration Block: CAL-IIW2-017

CS	N/A	4.0"
Material	Size	Thickness
Initial Cal: <u>1305</u>		Exam Start <u>1330</u>
Cal Check: <u>N/A</u>		Exam End <u>1540</u>
Cal Check: <u>N/A</u>	<u>Ultrasel II</u>	<u>01225</u>
Final Cal: <u>1643</u>	Couplant:	Batch
<u>242027</u>	<u>68° F</u>	<u>68° F</u>
Thermometer	Initial Cal Temp.	Final Cal Temp:

DAC Construction

Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
1/4	0.6"	1X	80%	1.6"	.61"	3.0
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A

DAC 1X= 58.0 dB

Sweep 0-10 4.0" Depth

Note N/A dB difference between 3/8 and 5/8 Vee

Search Unit Data

Sigma	<u>22BC-03003</u>	<u>2(1.1"x.62")/Rect.</u>
Manufacturer:	Serial Number:	Size / Shape:
<u>0.65"</u>	<u>60°</u>	<u>60°</u>
Incident Point:	Nominal Angle:	Measured Angle:
<u>3.0 MHz</u>	<u>SDC-3</u>	<u>Long</u>
Frequency:	Model:	Mode:

Search Unit Cable

<u>RG-174</u>	<u>12'</u>	<u>0</u>
Cable Type:	Length:	Connectors:

Instrument Settings

<u>Panametrics / Epoch 4</u>	<u>031574111</u>		
Manufacturer/Model:	Serial Number:		
<u>9.33 us</u>	<u>0.233 in./usec.</u>	<u>0.6 - 3.0 MHz</u>	
Delay/Zero:	Velocity:	Narrowband Filter:	
<u>Auto</u>	<u>Fullwave</u>	<u>4.0 in.</u>	<u>Sa / Med</u>
Rep Rate:	Rectification:	Range:	Pulser:
<u>400 Ohms</u>	<u>0</u>	<u>3.03 MHz</u>	<u>Dual</u>
Damping:	Reject:	Frequency:	Mode:
<u>Off</u>	<u>Off</u>	<u>Off</u>	<u>Off</u>
DAC:	TVG:	CSC:	DGS:

Exam Data for Weld: RPV-BH-C1

HEAD CIRCUMF WELD

Configuration:

<u>00</u>	<u>72° F</u>
Exam Surface:	Component Temperature

Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
<u>Plate</u>	<u>I</u>	<u>72.0</u>	<u>NRI</u>	<u>60°</u>
<u>Plate CW/CCW</u>	<u>P</u>	<u>72.0</u>	<u>NRI</u>	<u>60°</u>

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Acceptable Linearity performed: 4/15/2005

Comments: Cal/Exam Date is the date of examination. See coverage sheet for limitations.
 Calibration for near surface examination. Exams performed to maintain a 14 dB above reference.
 Exam performed from meridinal weld RPV-BH-M3 thru RPV-BH-M7.
 Single sided exam due to component configuration.

SS Steve Snyder II 4/28/2005
 Initials: Examiner Level Cal/Exam Date:

N/A N/A
 Initials: Examiner Level
BMM III 4-30-05
 GE Reviewed By: Level: Date:

[Signature] 4/15/05 5-4-05
 Utility Reviewed By: Date:
[Signature] 5/4/05
 ANII Reviewed By: Date:



GE ENERGY, NUCLEAR

Ultrasonic Calibration and Examination Record RPV Components

Site/Unit: Pilgrim Nuclear Power Station / 1

Data Report Number: PIL-R15-05-002 Linearity Sheet: L-004

Outage: RF-015

Data Sheet Number: UT-089

Procedure: TP04-018 (GE-UT-300)

Rev.: R0 (V8)

DRR: N/A

Calibration Block: PIL-5B

CS Flt: 4.35"
Material Size Thickness

Initial Cal: 1307 Exam Start 1330

Cal Check: N/A Exam End 1540

Cal Check: N/A Ultracel II 01225
Couplant: Batch

Final Cal: 1642 68° F 68° F
Thermometer Initial Cal Temp. Final Cal Temp.

Search Unit Data

Sigma 22BC-03003 2(1.1"x.62")/Rect.
Manufacturer: Serial Number: Size / Shape:

0.65° 60° 60°
Incident Point: Nominal Angle: Measured Angle:

3.0 MHz SDC-3 Long
Frequency: Model: Mode:

Search Unit Cable

RG-174 12' 0
Cable Type: Length: Connectors:

Instrument Settings

Panametrics / Epoch 4 031574111
Manufacturer/Model: Serial Number:

9.33 us 0.233 in/us.ec 0.8 - 3.0 MHz
Delay/Zero: Velocity: Narrowband Filter:

Auto Fullwave 12.0 In. Sq. / Med
Rep Rate: Rectification: Range: Pulsar:

400 Ohms 0 3.03 MHz Dual
Damping: Reject: Frequency: Mode:

Off: Off: Off: Off:
DAC: TVG: CSC: DGS:

DAC Construction

Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A
ID	4.1"	1X	80%	7.5"	4.35"	7.3
N/A	N/A	1X	N/A	N/A	N/A	N/A

DAC 1X= 60.5 dB
Sweep 0-10 6" Depth
Note N/A dB difference between 3/8 and 5/8 Vee

Exam Data for Weld: RPV-BH-C1

HEAD CIRCUMF WELD

Configuration:

QR 72° F
Exam Surface: Component Temperature

Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
<u>Plate</u>	<u>I</u>	<u>68.0</u>	<u>Yes</u>	<u>60°</u>
<u>Plate CW/CCW</u>	<u>P</u>	<u>68.0</u>	<u>NRI</u>	<u>60°</u>

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	Amplitude	Gain (dB)	Sweep (SD)
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Acceptable Linearity performed: 4/15/2005

Comments: Cal/Exam Date is the date of examination. See coverage sheet for limitations.

Calibration for full volume examination. Exams performed to maintain a 10 - 20% FSH clad roll.

Exam performed from meridinal weld RPV-BH-M3 thru RPV-BH-M7

Single sided exam due to component configuration.

Exam limited at two places for an "L" of 5" and a "W" of 5 to 6" from weld centerline of M5 weld cw from 55" to 60" and M3 weld from 9" to 14".

SS Steve Snyder II 4/28/2005
Initials: Examiner Level Cal/Exam Date:

UT Lvl III 5-4-05
Utility Reviewed By: Date:

N/A N/A
Initials: Examiner Level

B/M III 4-30-05
GE Reviewed By: Level: Date:

Carl Hanson 5/4/05
ANII Reviewed By: Date:



GE ENERGY, NUCLEAR

Ultrasonic Calibration and Examination Record RPV Components

Site/Unit: Pilgrim Nuclear Power Station / 1

Data Report Number: PIL-R15-05-002 Linearity Sheet: L-002

Outage: RF-015

Data Sheet Number: UT-090

Procedure: TP04-018 (GE-UT-300)

Rev.: R0 (V8)

DRR: NA

Calibration Block: PIL-5B

CS **Flat** **4.3E'**
 Material Size Thickness
 Initial Cal: 1303 Exam Star: 1330
 Cal Check: N/A Exam End: 1540
 Cal Check: N/A **Ultragel II** **01225**
 Final Cal: 1646 Couplant: Batch
242027 **68°F** **68°F**
 Thermometer Initial Cal Temp. Final Cal Temp:

Search Unit Data

KBA **010HX1** **0.5"x1.0"/Rect.**
 Manufacturer: Serial Number: Size / Shape:
0.65" **45°** **45°**
 Incident Point: Nominal Angle: Measured Angle:
1.0 MHz **113-891-600** **Shear**
 Frequency: Model: Mode:

Search Unit Cable

RG-174 **12'** **Ø**
 Cable Type: Length: Connectors:

Instrument Settings

Panometrics / Epoch 4 **031526704**
 Manufacturer/Model: Serial Number:
13.91 us **0.1276 in./usec.** **0.8 - 3.0 MHz**
 Delay/Zero: Velocity: Narrowband Filter:
Auto **Fullwave** **10.0 in.** **Sa / Med**
 Rep Rate: Rectification: Range: Pulsar:
400 Ohms **Ø** **1.0 MHz** **P/E**
 Damping: Reject: Frequency: Mode:
Off **Off** **Off** **Off**
 DAC: TVG: CSC: DGS:

DAC Construction

Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
1/4	1.1"	1X	80%	1.1"	1.1"	1.5
1/2	2.2"	1X	55%	2.2"	2.2"	3.0
3/4	3.3"	1X	34%	3.3"	3.3"	4.5
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A

DAC 1X= 18.9 dB
 Sweep 0-10 Z" Depth
 Note N/A dB difference between 3/8 and 5/8 Vee

Exam Data for Weld: RPV-BH-C1

HEAD CIRCUMF WELD

Configuration:

ØØ **72°F**
 Exam Surface: Component Temperature

Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
<u>Plate</u>	<u>UPST</u>	<u>32.9</u>	<u>NRI</u>	<u>45°</u>

Calibration Verification

Field Simulator Block S/N: NA

Reflector	Amplitude	Gain (dB)	Sweep (SD)
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>


Acceptable Linearity performed: 4/15/2005

Comments: Cal/Exam Date is the date of examination. See coverage sheet for limitations.
 Calibration for indication verification. Exams performed a minimum of 14 dB above reference.

SS Steve Snyder II 4/28/2005
 Initials: Examiner Level Cal/Exam Date:
NA NA
 Initials: Examiner Level Date:
BIM III 4-30-05
 GE Reviewed By: Level: Date:

[Signature] UT Lvl. III 5-11-05
 Utility Reviewed By: Date:
[Signature] 5/1/05
 ANII Reviewed By: Date:

Pilgrim Weld RPV-BH-C1



Pilgrim RF015, 2005

Handwritten signature
EN 2.1. III 5-2-05

Pilgrim - RFO15
 Weld RPV-BH-C1 Bottom Head Circumference
 Spring 2005

Weld Length = 593.8 Exam Volume = 24.5		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. In.	Area Scanned Manual	Percent of Area Manual	Weld Length Manual	Percent Manual
60° NS T-Scan	A	5.3	3.9	15.9%	578.8	7.8%
60° S6 T-Scan	A	16.2	16.1	65.7%	578.8	32.0%
60° S4 T-Scan	A	3.0	3.0	12.2%	578.8	3.0%
60° NS P-Scan	A	5.3	3.2	13.1%	578.8	6.4%
60° S6 P-Scan	A	16.2	9.9	40.4%	578.8	19.7%
60° S4 P-Scan	A	3.0	2.0	8.2%	578.8	4.0%
60° NS T-Scan	B	5.3	3.9	15.9%	15	0.2%
60° S6 T-Scan	B	16.2	14.4	58.8%	15	0.7%
60° S4 T-Scan	B	3.0	2.5	10.2%	15	0.1%
60° NS P-Scan	B	5.3	3.2	13.1%	15	0.2%
60° S6 P-Scan	B	16.2	9.9	40.4%	15	0.5%
60° S4 P-Scan	B	3.0	2.0	8.2%	15	0.1%

% Total Composite Coverage = 75%

Comments: A - T-Scan and P-Scan restricted due to proximity of vessel skirt.
 B - T-Scan and P-Scan restricted due to proximity of vessel skirt and thermocouples.

Note - Rounding methods may affect calculated values.

BK 4761 III 5-4-05


Page 10/240

Pilgrim Weld RPV-BH-C1

60° NS Exam Volume = 5.3 Sq. In.
60° FV Exam Volume = 16.2 Sq. In.
60° Inner 15% Exam Volume = 3.0 Sq. In.

60° NS T-Scan achieved = 3.9 Sq. In.
60° FV T-Scan achieved = 14.4 Sq. In.
60° Inner 15% T-Scan achieved = 2.5 Sq. In.

60° P-Scan achieved = 3.2 Sq. In.
60° FV P-Scan achieved = 9.9 Sq. In.
60° Inner 15% P-Scan achieved = 2.0 Sq. In.



Pilgrim RFO15, 2005

Handwritten: 4/5/05
4/5/05
5-4-05

Page 11 of 12


Handwritten: Page 11/240

Pilgrim Weld RPV-BH-C1

60° NS Exam Volume = 5.3 Sq. In.
60° FV Exam Volume = 16.2 Sq. In.
60° Inner 15% Exam Volume = 3.0 Sq. In.

60° NS T-Scan achieved = 3.9 Sq. In.
60° FV T-Scan achieved = 16.1 Sq. In.
60° Inner 15% T-Scan achieved = 3.0 Sq. In.

60° P-Scan achieved = 3.2 Sq. In.
60° FV P-Scan achieved = 9.9 Sq. In.
60° Inner 15% P-Scan achieved = 2.0 Sq. In.



Pilgrim RF015, 2005

Handwritten signature
5-4-05



EXAMINATION RESULTS

3.1 Examination Results

No recordable indications were detected during the RFO15 examinations, reference Table 1 below. The examination results from RFO14 are also provided in Table 2. The data records for each examination are located in Appendix F (tab 9). The actual RPV ultrasonic data which was recorded with the EDAS data acquisition system was archived onto 8mm data tapes. The EDAS data tapes are also provided as attachments to this report.

Table 1. Examination Results from RFO15

Weld No.	Weld Configuration Description	Examination Results	Examination Coverage
RPV-L-2-338A	Ring 1 Vertical Weld at 78°	No Recordable Indications	73%
RPV-L-2-338C	Ring 1 Vertical Weld at 318°	No Recordable Indications	25%
RPV-L-1-338A	Ring 2 Vertical Weld at 60°	No Recordable Indications	89%
RPV-L-1-338C	Ring 2 Vertical Weld at 300°	No Recordable Indications	25%

Table 2. Examination Results from RFO14

Weld No.	Weld Configuration Description	Examination Results	Examination Coverage
RPV-L-2-338B	Ring 1 Vertical Weld at 198°	No Recordable Indications	78%
RPV-L-1-338A	Ring 2 Vertical Weld at 60°	No Recordable Indications	Partial Exam
RPV-L-1-338B	Ring 2 Vertical Weld at 180°	No Recordable Indications	100%
RPV-L-2-339A	Ring 3 Vertical Weld at 356°	No Recordable Indications	81%
RPV-L-2-339B	Ring 3 Vertical Weld at 116°	No Recordable Indications	75%
RPV-L-2-339C	Ring 3 Vertical Weld at 236°	No Recordable Indications	83%
RPV-L-1-339A	Ring 4 Vertical Weld at 60°	No Recordable Indications	97%
RPV-L-1-339B	Ring 4 Vertical Weld at 180°	1 Acceptable Indication	100%
RPV-L-1-339C	Ring 4 Vertical Weld at 300°	1 Acceptable Indication	98%
RPV-C-4-339	Upper Shell-to-Flange Weld	1 Acceptable Indication	81%

3.2 Examination Limitations

The scanning accessibility of the full length and/or width of some areas from the inside surface of the RPV was limited due to physical obstructions. A description of the examination limitations is provided below in Tables 3 and 4. The actual scan areas (scan axis and increment axis) are recorded on the ISWT Examination Records (data records).



Table 3. Examination Limitations from RFO15

Weld No.	Weld Configuration Description	Examination Limitation
RPV-L-2-338A RPV-L-2-338C	Ring 1 Vertical Weld at 78-deg Ring 1 Vertical Weld at 318-deg	Proximity of Baffle Plate & Baffle Gusset Proximity of Baffle Plate, Baffle Gusset, Core Shroud Tie Rod, & N2K Nozzle
RPV-L-1-338A RPV-L-1-338C	Ring 2 Vertical Weld at 60-deg Ring 2 Vertical Weld at 300-deg	Proximity of Jet Pump Riser Support Proximity of Jet Pump Riser Support, Surveillance Specimen Holder & Support Brackets, and Shroud Tie Rod

Table 4. Examination Limitations from RFO14


Weld No.	Weld Configuration Description	Examination Limitation
RPV-L-2-338B RPV-L-1-338A RPV-L-1-338B RPV-L-2-339A RPV-L-2-339B RPV-L-2-339C RPV-L-1-339A RPV-L-1-339B RPV-L-1-339C RPV-C-4-339	Ring 1 Vertical Weld at 198-deg Ring 2 Vertical Weld at 60-deg Ring 2 Vertical Weld at 180-deg Ring 3 Vertical Weld at 356-deg Ring 3 Vertical Weld at 116-deg Ring 3 Vertical Weld at 236-deg Ring 4 Vertical Weld at 60-deg Ring 4 Vertical Weld at 180-deg Ring 4 Vertical Weld at 300-deg Upper Shell-to-Flange Weld	Proximity of Baffle Plate Gusset Partial Examination None Proximity of FW and CS Spargers Proximity of FW and CS Spargers & ID Taper Proximity of FW and CS Spargers Proximity of N3A Nozzle & Nozzle Plug None Proximity of N3D Nozzle & Nozzle Plug Proximity of N3 Nozzles, Nozzle Plugs, Guide Rods @ 0 & 180, and Flange Configuration

3.3 Explanation of Field Data Records

In addition to the examinations being automatically recorded as described in the previous section of this report, results of the NDE activities and calibrations performed by ISwT personnel were recorded on standard ISwT forms. The field data records for each weld or area were assembled into a data package preceded by a Summary Sheet. The examination areas and Summary Sheet numbers correspond to those listed in the Summary Table and were completed while on site. Therefore, a general explanation of the individual field data forms is provided to further clarify the information contained on the summary sheet.

Page 15/140

G-1



- Notes
1. Rollout as viewed from the vessel centerline.
 2. Circumferential locations (inches) are based on the ID of the Shell Course in which the feature (i.e., vertical weld, nozzle, etc.) is located.
 3. Thickness of shell wall base metal is 7.00" in the region (108.00" diameter from N1 nozzle centerline), per Combustion Engineering Des. No. 232-345-B, Rev. E.
 4. Thickness of shell wall base metal is 7.00" in the region (34.75" diameter from N2 nozzle centerline), per Combustion Engineering Des. No. 232-345-B, Rev. E.
 5. Thickness of shell wall base metal is 7.00" in the region (19.00" diameter from N3 nozzle centerline), per Combustion Engineering Des. No. 232-345-B, Rev. E.
 6. Thickness of shell wall base metal is 8.00" in the region (33.12" diameter from N6 nozzle centerline), per Combustion Engineering Des. No. 232-345-B, Rev. E.
 7. Thickness of shell wall base metal is 7.00" in the region (42.18" diameter from N3 nozzle centerline), per Combustion Engineering Des. No. 232-345-B, Rev. E.

VESSEL INSIDE DIAMETER VARIES ACCORDING TO SHELL COURSE AS FOLLOWS:					
LOCATION	VESSEL ID	1 DEGREE =	360 DEGREES =	CRG. WELD NAME	LOCATION OF ID TRANSITION
FLANGE	224.50"	1.9991"	708.28"	RPV-C-4-330	AT WELD CENTERLINE
SHELL COURSE 4	226.10"	1.9736"	716.56"	RPV-C-3-330A	ABOVE WELD CENTERLINE
SHELL COURSE 3	227.10"	1.9638"	713.75"	RPV-C-3-330B	NO TRANSITION (SAME DIA)
SHELL COURSE 2	227.10"	1.9638"	713.75"	RPV-C-1-331	BELOW WELD CENTERLINE
SHELL COURSE 1	228.10"	1.9736"	716.56"	RPV-C-6-330	NO TRANSITION
LOWER HEAD	R=113.44"	N/A	N/A		

Pilgrim Station
 ID Vessel Rollout
 November 2002
 RPVID

ISWT EXAMINATION SUMMARY RECORD

Project No.: 02-0285

PILGRIM NUCLEAR POWER STATION

Summary Sheet No.: 000400

SITE: PILGRIM STATION
SYSTEM: REACTOR PRESSURE VESSEL
LINE/SUBASSEMBLY: RING 2 VERTICAL WELD @ 60-DEGREES
IDENTIFICATION: RPV-L-1-338A

NDE Method	Proc/Rev/Chg/ICN	NDE Examination	Calibration Sheet No.	Data Sheet No.	N O		Resolution Record	CNF Number	Remarks
					R	T			
AUT	ISWT-PDI-AUT1/0/0/1,2	AUT55T	80031,80032	exam 22-24	X	-	N/A	N/A	Examination no's 22 - 24 were performed during RFO14.
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTSLIC40T	80033,80034	exam 22-24	X	-	N/A	N/A	
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTO	80035	exam 22-24	X	-	N/A	N/A	AUTO for thickness measurement only.
AUT	ISWT-PDI-AUT1/0/0/1,2	AUT55T	0800301,0800302	exam 19-21	X	-	N/A	N/A	
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTSLIC40T	0800303,0800304	exam 19-21	X	-	N/A	N/A	
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTO	0800305	exam 19-21	X	-	N/A	N/A	
AUT	ISWT-PDI-AUT1/0/0/1,2	AUT55	0800301,0800302	exam 25-26	X	-	N/A	N/A	
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTSLIC40	0800303,0800304	exam 25-26	X	-	N/A	N/A	
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTO	0800305	exam 25-26	X	-	N/A	N/A	

- NOTES:
1. Weld RPV-L-1-338A was examined from the inside surface using AIRIS-21 and EDAS-II examination equipment.
 2. No recordable indications were detected during this examination.
 3. Examinations 22 - 24 performed during RFO14.
 4. Examinations 25 and 26 were divided into 2 segments, 25a & 25b; and 26a & 26b.
 5. The examination was limited due to the proximity of the jet pump riser brace, 89% examination coverage was achieved.

****UT CALIBRATION BLOCK(S)****

D-70187-2/D70389-1

Prepared by: Steven J. Todd
 Steven J. Todd - Project Engineer

Date: 4/30/05

Page 1 of 1

Page 16/1740

UT - P. Todd



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Nuclear Station	Weld Identification: RPV-L-1-338A	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-19
Project No.: 02-0285	Weld Description: Ring 2 Vert @ 60°	Device Configuration: D-PNPS-102	Surface Temperature °F
Mod.Conf.: A-07B	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 24 Apr. 04	Start: 1741
Data Acquisition Operator (s) / SNT Level: David Kleinjan / II Alan Schaefer / N/A			End: 1746
			Start: 85
			End: 85

Data Acquisition

Scan Controller Parameters	Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters
Controller: ID Device	Lower Limit	11266	11282	Lower Limit	23188	23188	Beam Direction: Dn/Up
Scan: Y Axis	Upper Limit	12526	12503	Upper Limit	27880	24464	Transducer Size: 1.00
Increment: X Axis	Increment Interval	90		DCI	4		Code % of Overlap: 10
Mode: Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans: 15
Scan Motion: Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position: D (0)
Correction: Default	EDAS Radius In.	113.60					

Module Parameters:	A-07B	Cal 03				Calibration Records:	Examination Notes:
	Status	Angle	Direction	Scan Offset	Step Offset		
Channel 1	On	55	(-)	- 1.40(in)	- 1.21(in)	PNS-03	Check for limitations due to the proximity of the jet pump diffuser and the baffle plate.
Channel 2	On	55	(+)	+ 1.40(in)	- 1.21(in)	0800301	
Channel 3	On	SLIC-40	(-)	- 1.97(in)	+ 1.69(in)	0800302	
Channel 4	On	SLIC-40	(+)	+ 1.97(in)	+ 1.69(in)	0800303	
Channel 5	On	0T	(+)	+ 0.00(in)	+ 1.69(in)	0800304	Examination Remarks: Entergy/Pilgrim Procedure TP04-020
Channel 6	Off	N/A	N/A	N/A	N/A	0800305	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks			
	Increment Position		Scan Position		Yes	No	N/A	Attachment:			
	Start	Stop	Start	Stop	Channel 1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
1 - 15	11282	12503	23188	24464	Channel 2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation		
					Channel 3	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Required:		
					Channel 4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
					Channel 5	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Archive Tape/CD No.:		
					Channel 6	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1A & 1B		
					Channel 7	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Analysis Tape/CD No.:		
					Channel 8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	A & B		

Analyst / SNT Level / Date: Joel G. Godwin / III / 24 Apr. 05 *Paul A. Sodun*

Page 17/240



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Nuclear Station	Weld Identification: RPV-L-1-338A	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-20
Project No.: 02-0285	Weld Description: Ring 2 Vert @ 60°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-07A	Scan Path Drawing: SPLONGSH2&3DS	Exam Date	Examination Time
Data Acquisition Operator (s) / SNT Level: David Kleinjan / II Alan Schaefer / N/A		24 Apr. 04	Surface Temperature °F
		Start	End
		1646	1656
		85	85

Data Acquisition

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	11266	11266	Lower Limit	23188	24360	Beam Direction:	Up/Dn
Scan:	Y Axis	Upper Limit	12526	12538	Upper Limit	27880	26960	Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	15
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	D (180)
Correction:	Default	EDAS Radius In.	113.60						

Module Parameters:						Cal 03	Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset				
Channel 1	On	55	(+)	+ 1.40(in)	+ 1.21(in)		PNS-03	Check for limitations due to the proximity of the jet pump diffuser and the baffle plate.
Channel 2	On	55	(-)	- 1.40(in)	+ 1.21(in)		0800302	
Channel 3	On	SLIC-40	(+)	+ 1.97(in)	- 1.69(in)		0800303	
Channel 4	On	SLIC-40	(-)	- 1.97(in)	- 1.69(in)		0800304	Examination Remarks: Entergy/Pilgrim Procedure TP04-020
Channel 5	On	0T	(+)	+ 0.00(in)	- 1.69(in)		0800305	
Channel 6	Off	N/A	N/A	N/A	N/A		N/A	Upper scan axis limited due to jet pump riser brace. Lower scan axis limited due to welded lug.
Channel 7	Off	N/A	N/A	N/A	N/A		N/A	
Channel 8	Off	N/A	N/A	N/A	N/A		N/A	

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks	
	Increment Position		Scan Position		Yes	No	N/A	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
	Start	Stop	Start	Stop	Channel 1	Channel 2	Channel 3		
1 - 15	11266	12538	24360	26960	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Archive Tape/CD No.: 1A & 1B Analysis Tape/CD No.: A & B	
					Channel 4	Channel 5	Channel 6		
					Channel 7	Channel 8			

Analyst / SNT Level / Date: Joel G. Godwin / III / 24 Apr. 05 *Joel G. Godwin*

Page 18/240



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Nuclear Station	Weld Identification: RPV-L-1-338A	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-21
Project No.: 02-0285	Weld Description: Ring 2 Vert @ 60°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-07B	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 24 Apr. 04	Surface Temperature °F
Data Acquisition Operator (s) / SNT Level: David Kleinjan / II Alan Schaefer / N/A		Start: 1804	End: 1809
		Start: 85	End: 85

Data Acquisition

Scan Controller Parameters		Increment Axis/Arm		Planned	Actual	Scan Axis/Device		Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	11266	11266	11266	Lower Limit	27877	27877	27877	Beam Direction:	Dn/Up
Scan:	Y Axis	Upper Limit	12526	12526	12526	Upper Limit	32101	32101	32101	Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90			DCI	4			Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100			Conversion Counts	100			Number of Scans:	15
Scan Motion:	Bi-directional	Conversion Units In.	1.00			Conversion Units In.	1.00			Device Position:	D (0)
Correction:	Default	EDAS Radius In.	113.60								

Module Parameters: A-07B Cal 03						Calibration Records:	Examination Notes:
Channel	Status	Angle	Direction	Scan Offset	Step Offset		
Channel 1	On	55	(-)	- 1.40(in)	- 1.21(in)	PNS-03	Check for limitations due to the proximity of the jet pump diffuser and the baffle plate.
Channel 2	On	55	(+)	+ 1.40(in)	- 1.21(in)	0800301	
Channel 3	On	SLIC-40	(-)	- 1.97(in)	+ 1.69(in)	0800302	
Channel 4	On	SLIC-40	(+)	+ 1.97(in)	+ 1.69(in)	0800303	
Channel 5	On	0T	(+)	+ 0.00(in)	+ 1.69(in)	0800304	
Channel 6	Off	N/A	N/A	N/A	N/A	0800305	Examination Remarks: Entergy/Pilgrim Procedure TP04-020 Limited exam due to jet pump riser brace.
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks	
	Increment Position		Scan Position		Yes	No	N/A	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
	Start	Stop	Start	Stop	Channel 1	Channel 2	Channel 3		
1 - 15	11260	12526	27877	32101	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Archive Tape/CD No.: 1A & 1B Analysis Tape/CD No.: A & B	
					Channel 4	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 5	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					Channel 6	<input type="checkbox"/>	<input type="checkbox"/>		
					Channel 7	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					Channel 8	<input type="checkbox"/>	<input type="checkbox"/>		

Analyst / SNT Level / Date: Joel G. Godwin / III / 24 Apr. 05 *Joel G. Godwin*

Page 19/24-0



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Nuclear Station	Weld Identification: RPV-L-1-338A	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-25g
Project No.: 02-0285	Weld Description: Ring 2 Vert @ 60°	Device Configuration: D-PNPS-101	
Mod.Conf.: A-07-1D	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 25 Apr. 05	Surface Temperature °F
Data Acquisition Operator (s) / SNT Level: Richard Riddles / II		Examination Time	
		Start: 0112	End: 0130
		Start: 85	End: 85

Data Acquisition

Scan Controller Parameters		Increment Axis/Device		Planned	Actual	Scan Axis/Arm	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	24138	24138	24138	Lower Limit	11146	11146	Beam Direction:	Cow/Cw
Scan:	X Axis	Upper Limit	27918	26298	26298	Upper Limit	12646	12646	Transducer Size:	1.00
Increment:	Y Axis	Increment Interval	90			DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100			Conversion Counts	100		Number of Scans:	43
Scan Motion:	Bi-directional	Conversion Units In.	1.00			Conversion Units In.	1.00		Device Position:	A (0)
Correction:	Default	EDAS Radius In.	113.60							

Module Parameters: A-07-1D Cal 33						Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset		PNS-33	
Channel 1	On	55	(-)	+ 7.00(in)	+ 0.00(in)	0803301	Check for limitations due to the proximity of the jet pump diffuser and the baffle plate.
Channel 2	On	55	(+)	- 7.00(in)	+ 0.00(in)	0803302	
Channel 3	On	SLIC-40	(-)	+ 4.40(in)	+ 1.00(in)	0803303	
Channel 4	On	SLIC-40	(+)	- 4.40(in)	- 1.00(in)	0803304	Examination Remarks: Entergy/Pilgrim Procedure TP04-020 Limited exam due to jet pump riser brace.
Channel 5	On	0T	(+)	+ 4.40(in)	- 1.00(in)	0803305	
Channel 6	Off	N/A	N/A	N/A	N/A	N/A	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Data Analysis

Increment & Scan Positions Actual					Recordable Indications			Analyst Remarks	
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A	Attachment:	
	Start	Stop	Start	Stop				<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
1 - 25	24138	26298	11146	12646	Channel 1 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Archive Tape/CD No.: 1A & 1B Analysis Tape/CD No.: A & B	
					Channel 2 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 3 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 4 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 5 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					Channel 6 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					Channel 7 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					Channel 8 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Analyst / SNT Level / Date: Joel G. Godwin / III / 25 Apr. 05 *Joel G. Godwin*

Brg 20/240



IH SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Nuclear Station	Weld Identification: RPV-L-1-338A	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-25b
Project No.: 02-0285	Weld Description: Ring 2 Vert @ 60°	Device Configuration: D-PNPS-101	
Mod.Conf.: A-07-1C	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 25 Apr. 05	Surface Temperature °F
Data Acquisition Operator (s) / SNT Level: Richard Riddles / II		Examination Time	Start End
		Start End	Start End
		0319 0324	85 85

Data Acquisition

Scan Controller Parameters		Increment Axis/Device		Planned	Actual	Scan Axis/Arm	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	24138	26298	26298	Lower Limit	11146	11146	Beam Direction:	Cw/Ccw
Scan:	X Axis	Upper Limit	27918	27542	27542	Upper Limit	12646	12646	Transducer Size:	1.00
Increment:	Y Axis	Increment Interval	90			DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100			Conversion Counts	100		Number of Scans:	43
Scan Motion:	Bi-directional	Conversion Units In.	1.00			Conversion Units In.	1.00		Device Position:	A (180)
Correction:	Default	EDAS Radius In.	113.60							

Module Parameters:						Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset	Cal		
Channel 1	On	55	(+)	- 7.00(in)	+ 0.00(in)	PNS-33	Check for limitations due to the proximity of the jet pump diffuser and the baffle plate.
Channel 2	On	55	(-)	+ 7.00(in)	+ 0.00(in)	0803301	
Channel 3	On	SLIC-40	(+)	- 4.40(in)	- 1.00(in)	0803302	
Channel 4	On	SLIC-40	(-)	+ 4.40(in)	+ 1.00(in)	0803303	
Channel 5	On	0T	(+)	- 4.40(in)	+ 1.00(in)	0803304	
Channel 6	Off	N/A	N/A	N/A	N/A	0803305	Examination Remarks: Entergy/Pilgrim Procedure TP04-020 Limited exam due to jet pump riser brace.
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Attachment:	Analyst Remarks
	Increment Position		Scan Position		Yes	No	N/A		
	Start	Stop	Start	Stop	Channel 1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Archive Tape/CD No.: 1A & 1B Analysis Tape/CD No.: A & B
25 - 39	26298	27542	11146	12646	Channel 2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 3	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 5	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 6	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 7	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	

Analyst / SNT Level / Date: Joel G. Godwin / III / 25 Apr. 05 *Joel G. Godwin*

Page 21/240



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Nuclear Station	Weld Identification: RPV-L-1-338A	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-26a
Project No.: 02-0285	Weld Description: Ring 2 Vert @ 60°	Device Configuration: D-PNPS-101	
Mod.Conf.: A-07-1D	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 25 Apr. 05	Examination Time: Start 0153, End 0210
Data Acquisition Operator (s) / SNT Level: Richard Riddles / II			Surface Temperature °F: Start 85, End 85

Data Acquisition

Scan Controller Parameters		Increment Axis/Device		Planned	Actual	Scan Axis/Arm		Planned	Actual	Positional Parameters		
Controller:	ID Device	Lower Limit	27877	30307	Lower Limit	11146	11146	Upper Limit	12646	12646	Beam Direction:	Ccw/Cw
Scan:	X Axis	Upper Limit	33997	33997	Upper Limit	12646	12646	DCI	4		Transducer Size:	1.00
Increment:	Y Axis	Increment Interval	90		Conversion Counts	100		Conversion Counts	100		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Units In.	1.00		Conversion Units In.	1.00		Conversion Units In.	1.00		Number of Scans:	69
Scan Motion:	Bi-directional	EDAS Radius In.	113.60								Device Position:	A (0)
Correction:	Default											

Module Parameters: A-07-1D Cal 33						Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset		PNS-33	Check for limitations due to the proximity of the jet pump diffuser and the baffle plate.
Channel 1	On	55	(-)	+ 7.00(in)	+ 0.00(in)	0803301	
Channel 2	On	55	(+)	- 7.00(in)	+ 0.00(in)	0803302	
Channel 3	On	SLIC-40	(-)	+ 4.40(in)	+ 1.00(in)	0803303	
Channel 4	On	SLIC-40	(+)	- 4.40(in)	- 1.00(in)	0803304	Examination Remarks:
Channel 5	On	0T	(+)	+ 4.40(in)	- 1.00(in)	0803305	Entergy/Pilgrim Procedure TP04-020
Channel 6	Off	N/A	N/A	N/A	N/A	N/A	Limited exam due to jet pump riser brace.
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Analyst Remarks
	Increment Position		Scan Position		Yes	No	N/A		
28 - 69	Start	Stop	Start	Stop	Channel 1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	30307	33997	11146	12646	Channel 2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 3	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 5	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 6	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 7	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	

Analyst / SNT Level / Date:

Joel G. Godwin / III / 25 Apr. 05

Joel G. Godwin

0002 22/240



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Nuclear Station	Weld Identification: RPV-L-1-338A	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-26b
Project No.: 02-0285	Weld Description: Ring 2 Vert @ 60°	Device Configuration: D-PNPS-101	
Mod.Conf.: A-07-1D	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 25 Apr. 05	Surface Temperature °F
Data Acquisition Operator (s) / SNT Level: Richard Riddles / II		Examination Time	Start End
		0216 0237	85 85

Data Acquisition

Scan Controller Parameters		Increment Axis/Device Planned		Actual	Scan Axis/Arm	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	33907	33907	Lower Limit	11146	11146	Beam Direction:	CCW/CW
Scan:	X Axis	Upper Limit	40027	40027	Upper Limit	12646	12646	Transducer Size:	1.00
Increment:	Y Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	69
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	A (0)
Correction:	Default	EDAS Radius In.	113.60						

Module Parameters: A-07-1D Cal 33						Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset		PNS-33	Check for limitations due to the proximity of the jet pump diffuser and the baffle plate.
Channel 1	On	55	(-)	+ 7.00(in)	+ 0.00(in)	0803301	
Channel 2	On	55	(+)	- 7.00(in)	+ 0.00(in)	0803302	
Channel 3	On	SLIC-40	(-)	+ 4.40(in)	+ 1.00(in)	0803303	
Channel 4	On	SLIC-40	(+)	- 4.40(in)	- 1.00(in)	0803304	Examination Remarks:
Channel 5	On	0T	(+)	+ 4.40(in)	- 1.00(in)	0803305	Energy/Pilgrim Procedure TP04-020
Channel 6	Off	N/A	N/A	N/A	N/A	N/A	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Data Analysis

Increment & Scan Positions Actual					Recordable Indications			Analyst Remarks	
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A	Attachment:	
	Start	Stop	Start	Stop				<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
1 - 69	33907	40027	11146	12646	Channel 1 <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	Channel 2 <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	Channel 3 <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	Channel 4 <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	Channel 5 <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A
					Channel 6 <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	Channel 7 <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	Channel 8 <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Archive Tape/CD No.: 1A & 1B
								Analysis Tape/CD No.: A & B	

Analyst / SNT Level / Date: Joel G. Godwin / III / 25 Apr. 05 *Joel A. Godwin*

Page 23/240

ISWT EXAMINATION SUMMARY RECORD

Project No.: 02-0285

PILGRIM NUCLEAR POWER STATION

Summary Sheet No.: 000600

SITE: PILGRIM STATION
SYSTEM: REACTOR PRESSURE VESSEL
LINE/SUBASSEMBLY: RING 2 VERTICAL WELD @ 300-DEGREES
IDENTIFICATION: RPV-L-1-338C

NDE Method	Proc/Rev/Chg/ICN	NDE Examination	Calibration Sheet No.	Data Sheet No.	N O		Resolution Record	CNF Number	Remarks
					I	H			
AUT	ISWT-PDI-AUT1/0/0/1,2	AUT45	0803401	exam 37-38	X	-	N/A	N/A	Examination no's 35-38.
AUT	ISWT-PDI-AUT1/0/0/1,2	AUT55	0803402	exam 37-38	X	-	N/A	N/A	AUTO for thickness measurement only.
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTSLIC40	0803403,0803404	exam 37-38	X	-	N/A	N/A	
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTSLIC40	0803403,0803404	exam 37-38	X	-	N/A	N/A	
AUT	ISWT-PDI-AUT1/0/0/1,2	AUT55T	0802301,0802302	exam 35-36	X	-	N/A	N/A	
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTSLIC40T	0802303,0800304	exam 35-36	X	-	N/A	N/A	
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTO	0802305	exam 35-36	X	-	N/A	N/A	

- NOTES:
1. Weld RPV-L-1-338C was examined from the inside surface using AIRIS-21 and EDAS-II examination equipment.
 2. No recordable indications were detected during this examination.
 3. The examination was limited due to the proximity of the jet pump riser brace, specimen holder, and core shroud repair tie rod, 25% Examination coverage was achieved.

****UT CALIBRATION BLOCK(S)****
 D-70187-2/D70389-1

Page 24/340

Prepared by: Steven J. Todd
 Steven J. Todd - Project Engineer

Date: 4/30/05

Page 1 of 1

Handwritten signature

Summary Sheet No.: 000600



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD :

Site/Plant : Pilgrim Nuclear Station	Weld Identification: RPV-L-1-338C	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-35a
Project No.: 02-0285	Weld Description: Ring 2 Vert @ 300°	Device Configuration: D-PNPS-101	Surface Temperature °F
Mod.Conf.: A-07-1B	Scan Path Drawing: SPLONGSH2SS	Exam Date	Start End
Data Acquisition Operator (s) / SNT Level: D. Kleinjan / II, Alan Scheafer / N/A		25 Apr. 05	0811 0835
			83 83

Data Acquisition

Scan Controller Parameters	Increment Axis/Device	Planned	Actual	Scan Axis/Arm	Planned	Actual	Positional Parameters :
Controller: ID Device	Lower Limit	58938	58958	Lower Limit	23538	23538	Beam Direction: Dn/Up
Scan: Y Axis	Upper Limit	60018	60018	Upper Limit	40550	24878	Transducer Size: 1.00
Increment: X Axis	Increment Interval	90		DCI	4		Code % of Overlap: 10
Mode: Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans: 13
Scan Motion: Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position: A (-90)
Correction: Default	EDAS Radius In.	113.60					

Module Parameters:	A-07-1B	Cal 23				Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset			
Channel 1	On	55	(-)	+ 7.00(in)	+ 0.00(in)	PNS-23	Check for limitations due to the proximity of the jet pump, the jet pump riser bracket, the N2 nozzle, and the surveillance capsule holder.
Channel 2	On	55	(+)	- 7.00(in)	+ 0.00(in)	0802301	
Channel 3	On	SLIC-40	(-)	+ 4.40(in)	- 1.00(in)	0802302	
Channel 4	On	SLIC-40	(+)	- 4.40(in)	+ 1.00(in)	0802303	Examination Remarks: Entergy/Pilgrim Procedure TP04-020
Channel 5	On	0T	(+)	+ 4.40(in)	+ 1.00(in)	0802304	
Channel 6	Off	N/A	N/A	N/A	N/A	0802305	Exam continued on exam ID-35b.
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks	
	Increment Position		Scan Position		Yes	No	N/A	Attachment:	
	Start	Stop	Start	Stop				<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
1 - 13	58938	60018	23538	24878	Channel 1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Archive Tape/CD No.: 1A & 1B Analysis Tape/CD No.: A & B
				Channel 2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
				Channel 3	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
				Channel 4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
				Channel 5	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
				Channel 6	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
				Channel 7	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
				Channel 8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Analyst / SNT Level / Date: Joel G. Godwin / III / 25 Apr. 05 *Paul S. Soderum*

Page 25/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Nuclear Station	Weld Identification: RPV-L-1-338C	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-35b
Project No.: 02-0285	Weld Description: Ring 2 Vert @ 300°	Device Configuration: D-PNPS-101	
Mod.Conf.: A-07-1B	Scan Path Drawing: SPLONGSH2SS	Exam Date: 25 Apr. 05	Examination Time: Start 0845, End 0903
Data Acquisition Operator (s) / SNT Level: D. Kleinjan / II, Alan Scheafer / N/A			Surface Temperature °F: Start 83, End 83

Data Acquisition

Scan Controller Parameters		Increment Axis/Device		Planned	Actual	Scan Axis/Arm	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	58938	58943	Lower Limit	23538	24642	Beam Direction:	Dn/Up	
Scan:	Y Axis	Upper Limit	60018	60038	Upper Limit	40550	25342	Transducer Size:	1.00	
Increment:	X Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10	
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	13	
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	A (-90)	
Correction:	Default	EDAS Radius In.	113.60							

Module Parameters: A-07-1B Cal 23						Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset		PNS-23	
Channel 1	On	55	(-)	+ 7.00(in)	+ 0.00(in)	0802301	Check for limitations due to the proximity of the jet pump, the jet pump riser bracket, the N2 nozzle, and the surveillance capsule holder.
Channel 2	On	55	(+)	- 7.00(in)	+ 0.00(in)	0802302	
Channel 3	On	SLIC-40	(-)	+ 4.40(in)	- 1.00(in)	0802303	
Channel 4	On	SLIC-40	(+)	- 4.40(in)	+ 1.00(in)	0802304	
Channel 5	On	0T	(+)	+ 4.40(in)	+ 1.00(in)	0802305	
Channel 6	Off	N/A	N/A	N/A	N/A	N/A	Examination Remarks: Entergy/Pilgrim Procedure TP04-020 Exam continued on exam ID-35c.
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Analyst Remarks
	Start	Stop	Start	Stop	Yes	No	N/A		
1 - 13	58943	60038	24642	25342	Channel 1 <input type="checkbox"/>	Channel 2 <input checked="" type="checkbox"/>	Channel 3 <input type="checkbox"/>	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Archive Tape/CD No.: IA & IB Analysis Tape/CD No.: A & B	
				Channel 4 <input type="checkbox"/>	Channel 5 <input type="checkbox"/>	Channel 6 <input checked="" type="checkbox"/>	Channel 7 <input type="checkbox"/>		
				Channel 8 <input type="checkbox"/>					

Analyst / SNT Level / Date: Joel G. Godwin / III / 25 Apr. 05 *Joel S. Godwin*

Page 26/240



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Nuclear Station	Weld Identification: RPV-L-1-338C	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-35c
Project No.: 02-0285	Weld Description: Ring 2 Vert @ 300°	Device Configuration: D-PNPS-101	
Mod.Conf.: A-07-1B	Scan Path Drawing: SPLONGSH2SS	Exam Date: 25 Apr. 05	Surface Temperature °F:
Data Acquisition Operator (s) / SNT Level: D. Kleinjan / II Alan Scheafer / N/A		Examination Time:	Start: 80 End: 80
		Start: 0938	End: 0940

Data Acquisition

Scan Controller Parameters		Increment Axis/Device - Planned		Actual	Scan Axis/Arm	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	58938	59935	Lower Limit	23538	30942	Beam Direction:	Dn/Up
Scan:	Y Axis	Upper Limit	60018	59245	Upper Limit	40550	31526	Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	13
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	A (-90)
Correction:	Default	EDAS Radius In.	113.60						
Module Parameters: A-07-1B Cal 23					Calibration Records:		Examination Notes:		
Status	Angle	Direction	Scan Offset	Step Offset	PNS-23	Check for limitations due to the proximity of the jet pump, the jet			
Channel 1	On	55	(-) + 7.00(in)	+ 0.00(in)	0802301	pump riser bracket, the N2 nozzle, and the surveillance capsule			
Channel 2	On	55	(+) - 7.00(in)	+ 0.00(in)	0802302	holder.			
Channel 3	On	SLIC-40	(-) + 4.40(in)	- 1.00(in)	0802303				
Channel 4	On	SLIC-40	(+) - 4.40(in)	+ 1.00(in)	0802304	Examination Remarks:			
Channel 5	On	OT	(+) + 4.40(in)	+ 1.00(in)	0802305	Entergy/Pilgrim Procedure TP04-020			
Channel 6	Off	N/A	N/A	N/A	N/A	No exam from 25320 to 30942 due to specimen holder and			
Channel 7	Off	N/A	N/A	N/A	N/A	riser support brackets.			
Channel 8	Off	N/A	N/A	N/A	N/A				

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks	
	Start	Stop	Start	Stop	Yes	No	N/A	Attachment:	
1 - 5	58933	59245	30942	31526	Channel 1 <input type="checkbox"/>	Channel 2 <input checked="" type="checkbox"/>	Channel 3 <input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					Channel 4 <input type="checkbox"/>	Channel 5 <input type="checkbox"/>	Channel 6 <input checked="" type="checkbox"/>	Further Evaluation Required:	
					Channel 7 <input type="checkbox"/>	Channel 8 <input type="checkbox"/>	Channel 8 <input checked="" type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
								Archive Tape/CD No.:	
								1A & 1B	
								Analysis Tape/CD No.:	
								A & B	

Analyst / SNT Level / Date: Joel G. Godwin / III / 25 Apr. 05 *Joel G. Godwin*

Page 27/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Nuclear Station	Weld Identification: RPV-L-1-338C	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-36
Project No.: 02-0285	Weld Description: Ring 2 Vert @ 300°	Device Configuration: D-PNPS-101	
Mod.Conf.: A-07-1A	Scan Path Drawing: SPLONGSH2SS	Exam Date: 25 Apr. 05	Examination Time: Start: N/A, End: N/A
Data Acquisition Operator (s) / SNT Level: Alan Schaefer / N/A			Surface Temperature °F: Start: N/A, End: N/A

Data Acquisition

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	58938	N/A	Lower Limit	23538	N/A	Beam Direction:	Up/Dn
Scan:	Y Axis	Upper Limit	60018	N/A	Upper Limit	40550	N/A	Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	13
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	A (90)
Correction:	Default	EDAS Radius In.	113.60						

Module Parameters: A-07-1A Cal 23						Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset			
Channel 1	On	55	(+)	- 7.00(in)	+ 0.00(in)	PNS-23	Check for limitations due to the proximity of the jet pump, the jet pump riser bracket, the N2 nozzle, and the surveillance capsule holder.
Channel 2	On	55	(-)	+ 7.00(in)	+ 0.00(in)	0802301	
Channel 3	On	SLIC-40	(+)	- 4.40(in)	+ 1.00(in)	0802302	
Channel 4	On	SLIC-40	(-)	+ 4.40(in)	- 1.00(in)	0802303	
Channel 5	On	0T	(+)	- 4.40(in)	- 1.00(in)	0802304	Examination Remarks: Entergy/Pilgrim Procedure TP04-020
Channel 6	On	0T	(+)	+ 4.40(in)	+ 1.00(in)	0802305	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	NO EXAMINATION DUE TO SHROUD TIE ROD REPAIR MECHANISM
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Data Analysis

Increment & Scan Positions Actual					Recordable Indications			Analyst Remarks	
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
	Start	Stop	Start	Stop					
N/A	N/A	N/A	N/A	N/A	Channel 1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Archive Tape/CD No.: N/A Analysis Tape/CD No.: N/A
					Channel 2	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 3	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 4	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 5	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 6	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 7	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	

Analyst / SNT Level / Date: Joel G. Godwin / III / 25 Apr. 05

Joel G. Godwin

Page 28/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Nuclear Station	Weld Identification: RPV-L-1-338C	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-37a
Project No.: 02-0285	Weld Description: Ring 2 Vert @ 300°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-08C	Scan Path Drawing: SPLONGSH2SS	Exam Date: 25 Apr. 05	Surface Temperature °F:
Data Acquisition Operator (s) / SNT Level: D. Kleinjan / II . Alan Schaefer / N/A		Examination Time:	Start: 88 End: 88
		Start: 1340 End: 1414	

Data Acquisition

Scan Controller Parameters		Increment Axis/Arm		Planned	Actual	Scan Axis/Device		Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	24069	24069	24068	Lower Limit	58396	58396	58396	Beam Direction:	Cw
Scan:	X Axis	Upper Limit	40089	40089	25766	Upper Limit	60020	60020	60020	Transducer Size:	1.00
Increment:	Y Axis	Increment Interval	90	90		DCI	4	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100	100		Conversion Counts	100	100		Number of Scans:	179
Scan Motion:	Bi-directional	Conversion Units In.	1.00	1.00		Conversion Units In.	1.00	1.00		Device Position:	D (-90)
Correction:	Default	EDAS Radius In.	113.60	113.60							

Module Parameters:						Calibration Records:		Examination Notes:	
Status	A-08C Angle	Cal 34 Direction	Scan Offset	Step Offset		PNS-34			
Channel 1	On	45	(+)	+ 1.40(in)	- 1.21(in)	0803401	Check for limitations due to the proximity of the jet pump, the jet		
Channel 2	On	55	(+)	- 1.40(in)	- 1.21(in)	0803402	pump riser bracket, the N2 nozzle, and the surveillance capsule holder.		
Channel 3	On	SLIC-40	(+)	+ 1.97(in)	+ 1.69(in)	0803403			
Channel 4	On	SLIC-40	(+)	- 1.97(in)	+ 1.69(in)	0803404	Examination Remarks:		
Channel 5	On	SLIC-40	(-)	+ 0.00(in)	+ 1.69(in)	0803405	Entergy/Pilgrim Procedure TP04-020		
Channel 6	Off	N/A	N/A	N/A	N/A	N/A	Exam limited due to surveillance capsule holder.		
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	Continued on exam ID-37b.		
Channel 8	Off	N/A	N/A	N/A	N/A	N/A			

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Attachment:		Analyst Remarks
	Start	Stop	Start	Stop	Yes	No	N/A	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
1 - 17	24068	25548	58396	60020	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
18 - 20	25638	25766	58396	59430	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Analyst / SNT Level / Date: Joel G. Godwin / III / 25 Apr. 05 *Joel G. Godwin*

Page 29/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD :

Site/Plant : Pilgrim Nuclear Station	Weld Identification: RPV-L-1-338C	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-37b
Project No.: 02-0285	Weld Description: Ring 2 Vert @ 300°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-08C	Scan Path Drawing: SPLONGSH2SS	Exam Date	Examination Time
Data Acquisition Operator (s) / SNT Level: D. Kleinjan / II . Alan Schaefer / N/A		25 Apr. 05	Start End
			Start End
			88 88

Data Acquisition

Scan Controller Parameters	Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters
Controller: ID Device	Lower Limit	24069	31163	Lower Limit	58396	58396	Beam Direction: Cw
Scan: X Axis	Upper Limit	40089	40082	Upper Limit	60020	60020	Transducer Size: 1.00
Increment: Y Axis	Increment Interval	90		DCI	4		Code % of Overlap: 10
Mode: Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans: 179
Scan Motion: Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position: D (-90)
Correction: Default	EDAS Radius In.	113.60					

Module Parameters:	A-08C	Cal 34				Calibration Records:	Examination Notes:
	Status	Angle	Direction	Scan Offset	Step Offset		
Channel 1	On	45	(+)	+ 1.40(in)	- 1.21(in)	PNS-34	Check for limitations due to the proximity of the jet pump, the jet pump riser bracket, the N2 nozzle, and the surveillance capsule holder.
Channel 2	On	55	(+)	- 1.40(in)	- 1.21(in)	0803401	
Channel 3	On	SLIC-40	(+)	+ 1.97(in)	+ 1.69(in)	0803402	
Channel 4	On	SLIC-40	(+)	- 1.97(in)	+ 1.69(in)	0803403	
Channel 5	On	SLIC-40	(-)	+ 0.00(in)	+ 1.69(in)	0803404	
Channel 6	Off	N/A	N/A	N/A	N/A	0803405	Examination Remarks: Entropy/Pilgrim Procedure TP04-020 Exam limited due to surveillance capsule holder and holder support bracket.
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Attachment:	Analyst Remarks
	Increment Position		Scan Position		Yes	No	N/A		
	Start	Stop	Start	Stop	Channel 1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Archive Tape/CD No.: 2A & 2B Analysis Tape/CD No.: A & B
80 - 106	31163	33546	58396	59200	Channel 2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
107 - 120	33636	34729	58396	58912	Channel 3	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
121 - 171	34819	39329	58396	59200	Channel 4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
172 - 179	39419	40082	58396	60020	Channel 5	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 6	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 7	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	

Analyst / SNT Level / Date: Joel G. Godwin / III / 25 Apr. 05 *Joel A. Godwin*

Page 30/40



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Nuclear Station	Weld Identification: RPV-L-1-338C	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-38
Project No.: 02-0285	Weld Description: Ring 2 Vert @ 300°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-08D	Scan Path Drawing: SPLONGSH2SS	Exam Date: 25 Apr. 05	Surface Temperature °F:
Data Acquisition Operator (s) / SNT Level: David Kleinjan / II		Examination Time:	
		Start: N/A	End: N/A
		Start: N/A	End: N/A

Data Acquisition

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	24069	N/A	Lower Limit	58936	N/A	Beam Direction:	Ccw
Scan:	X Axis	Upper Limit	40089	N/A	Upper Limit	60560	N/A	Transducer Size:	1.00
Increment:	Y Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	179
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	D (90)
Correction:	Default	EDAS Radius In.	113.60						

Module Parameters:						Calibration Records:	Examination Notes:
		A-08D	Cal 34				
Status	Angle	Direction	Scan Offset	Step Offset			
Channel 1	On	45	(-)	- 1.40(in)	+ 1.21(in)	PNS-34	Check for limitations due to the proximity of the jet pump, the jet pump riser bracket, the N2 nozzle, and the surveillance capsule holder.
Channel 2	On	55	(-)	+ 1.40(in)	+ 1.21(in)	0803401	
Channel 3	On	SLIC-40	(-)	- 1.97(in)	- 1.69(in)	0803402	
Channel 4	On	SLIC-40	(-)	+ 1.97(in)	- 1.69(in)	0803403	Examination Remarks: Entergy/Pilgrim Procedure TP04-020
Channel 5	On	SLIC-40	(+)	+ 0.00(in)	- 1.69(in)	0803404	
Channel 6	Off	N/A	N/A	N/A	N/A	0803405	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

**NO EXAMINATION DUE TO SHROUD
TIE ROD REPAIR MECHANISM**

Data Analysis

Increment & Scan Positions Actual					Recordable Indications			Analyst Remarks	
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A	Attachment:	Further Evaluation Required:
	Start	Stop	Start	Stop					
N/A	N/A	N/A	N/A	N/A	Channel 1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					Channel 2	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Archive Tape/CD No.: N/A Analysis Tape/CD No.: N/A
					Channel 3	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 4	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 5	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 6	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 7	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	

Analyst / SNT Level / Date:

Joel G. Godwin / III / 25 Apr. 05

Joel G. Godwin

Page 31/34



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Nuclear Station	Weld Identification: RPV-L-1-338C	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-38bDS
Project No.: 02-0285	Weld Description: Ring 2 Vert @ 300°	Device Configuration: D-PNPS-101-	
Mod.Conf.: A-07-1D	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 25 Apr. 05	Surface Temperature °F
Data Acquisition Operator (s) / SNT Level: Richard Riddles / II		Examination Time	
		Start: 0629	End: 0637
		Start: 85	End: 85

Data Acquisition

Scan Controller Parameters		Increment Axis/Device - Planned		Actual	Scan Axis/Arm		Planned		Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	33907	39397	Lower Limit	58728	58728	58728	Beam Direction:	CCW/CW	
Scan:	X Axis	Upper Limit	40027	40098	Upper Limit	60228	60228	60228	Transducer Size:	1.00	
Increment:	Y Axis	Increment Interval	90		DCI	4			Code % of Overlap:	10	
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100			Number of Scans:	69	
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00			Device Position:	A (0)	
Correction:	Default	EDAS Radius In.	113.60								

Module Parameters:						Calibration Records:		Examination Notes:	
A-07-1D		Cal 33							
Status	Angle	Direction	Scan Offset	Step Offset					
Channel 1	On	55	(-)	+ 7.00(in)	+ 0.00(in)	PNS-33		Check for limitations due to the proximity of the jet pump diffuser and the baffle plate.	
Channel 2	On	55	(+)	- 7.00(in)	+ 0.00(in)	0803301			
Channel 3	On	SLIC-40	(-)	+ 4.40(in)	+ 1.00(in)	0803302			
Channel 4	On	SLIC-40	(+)	- 4.40(in)	- 1.00(in)	0803303			
Channel 5	On	0T	(+)	+ 4.40(in)	- 1.00(in)	0803304		Examination Remarks:	
Channel 6	Off	N/A	N/A	N/A	N/A	0803305		Entergy/Pilgrim Procedure TP04-020	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A		Limited exam due to specimen bracket.	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A			

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks		
	Increment Position		Scan Position		Yes	No	N/A			
	Start	Stop	Start	Stop						
62- 70	39397	40098	60228	60228	Channel 1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Attachment:	
					Channel 2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					Channel 3	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation	
					Channel 4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Required:	
					Channel 5	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					Channel 6	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Archive Tape/CD No.:	
					Channel 7	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	IA & IB	
					Channel 8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Analysis Tape/CD No.:	
									A & B	

Analyst / SNT Level / Date:

Joel G. Godwin / III / 25 Apr. 05

Joel G. Godwin

Page 32/140

ISWT EXAMINATION SUMMARY RECORD

Project No.: 02-0285

PILGRIM STATION

Summary Sheet No.: 000100

SITE: PILGRIM STATION
SYSTEM: REACTOR PRESSURE VESSEL
LINE/SUBASSEMBLY: RING 1 VERTICAL WELD @ 78-DEGREES
IDENTIFICATION: RPV-L-2-338A

NDE Method	Proc/Rev/Chg/CN	NDE Examination	Calibration Sheet No.	Data Sheet No.	N O		Resolution Record	CNF Number	Remarks
					I	H			
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTO	0803305	exam 7-8	X	-	N/A	N/A	Examination no's 1-8.
AUT	ISWT-PDI-AUT1/0/0/1,2	AUT55	0803301,0803302	exam 7-8	X	-	N/A	N/A	AUTO for thickness measurement only.
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTSLIC40	0803303,0803304	exam 7-8	X	-	N/A	N/A	
AUT	ISWT-PDI-AUT1/0/0/1,2	AUT55T	0800301,0800302	exam 1-6	X	-	N/A	N/A	
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTSLIC40T	0800303,0800304	exam 1-6	X	-	N/A	N/A	
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTO	0800305	exam 1-6	X	-	N/A	N/A	

- NOTES:**
1. Weld RPV-L-2-338A was examined from the inside surface using AIRIS-21 and EDAS-II examination equipment.
 2. No recordable indications were detected during this examination.
 3. The examination was limited due to proximity of baffle plate and baffle plate gusset, 73% examination coverage was achieved.

****UT CALIBRATION BLOCK(a)****
 D-70187-2/D70389-1

Prepared by: Steven J. Todd
 Steven J. Todd - Project Engineer

Date: 4/30/05

Page 1 of 1

AWB *Chris Hanson* 5/1/05

Summary Sheet No.: 000100

Page 33/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Nuclear Station	Weld Identification: RPV-L-2-338A	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-1
Project No.: 02-0285	Weld Description: Ring 1 Vert @ 78°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-07B	Scan Path Drawing: SPLONGSHI&4DS	Exam Date: 24 Apr. 04	Examination Time: Start: N/A, End: N/A
Data Acquisition Operator (s) / SNT Level: David Kleinjan / II Alan Schaefer / N/A			Surface Temperature °F: Start: N/A, End: N/A

Data Acquisition

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	14766	N/A	Lower Limit	9838	N/A	Beam Direction:	Dn/Up
Scan:	Y Axis	Upper Limit	16026	N/A	Upper Limit	12466	N/A	Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	15
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	D (0)
Correction:	Default	EDAS Radius In.	113.10						

Module Parameters: A-07B Cal 03						Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset		PNS-03	Check for limitations due to the proximity of the jet pump diffuser and the baffle plate.
Channel 1	On	55	(-)	- 1.40(in)	- 1.21(in)	0800301	
Channel 2	On	55	(+)	+ 1.40(in)	- 1.21(in)	0800302	
Channel 3	On	SLIC-40	(-)	- 1.97(in)	+ 1.69(in)	0800303	
Channel 4	On	SLIC-40	(+)	+ 1.97(in)	+ 1.69(in)	0800304	Examination Remarks:
Channel 5	On	0T	(+)	+ 0.00(in)	+ 1.69(in)	0800305	Entergy/Pilgrim Procedure TP04-020
Channel 6	Off	N/A	N/A	N/A	N/A	N/A	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	NO EXAM DUE TO VESSEL TO BAFFLE PLATE GUSSET
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks	
	Increment Position		Scan Position		Yes	No	N/A	Attachment:	
N/A	N/A	N/A	N/A	N/A				<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					Channel 1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Further Evaluation
					Channel 2	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Required:
					Channel 3	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					Channel 4	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Archive Tape/CD No.:
					Channel 5	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
					Channel 6	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Analysis Tape/CD No.:
					Channel 7	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
					Channel 8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	

Analyst / SNT Level / Date: Joel G. Godwin / III / 24 Apr. 05 *Joel G. Godwin*

Page 34/240



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Nuclear Station	Weld Identification: RPV-L-2-338A	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-2
Project No.: 02-0285	Weld Description: Ring 1 Vert @ 78°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-07B	Scan Path Drawing: SPLONGSH1&4DS	Exam Date: 24 Apr. 04	Surface Temperature °F
Data Acquisition Operator (s) / SNT Level: David Kleinjan / II Alan Schaefer / N/A		Examination Time	Start End
		1453 .1501	85 . 85

Data Acquisition

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	14766	14673	Lower Limit	12413	13781	Beam Direction:	Dn/Up
Scan:	Y Axis	Upper Limit	16026	15948	Upper Limit	15041	15041	Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	15
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	D (0)
Correction:	Default	EDAS Radius In.	113.10						

Module Parameters: A-07B Cal 03						Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset		PNS-03	Check for limitations due to the proximity of the jet pump diffuser and the baffle plate.
Channel 1	On	55	(-)	- 1.40(in)	- 1.21(in)	0800301	
Channel 2	On	55	(+)	+ 1.40(in)	- 1.21(in)	0800302	
Channel 3	On	SLIC-40	(-)	- 1.97(in)	+ 1.69(in)	0800303	
Channel 4	On	SLIC-40	(+)	+ 1.97(in)	+ 1.69(in)	0800304	Examination Remarks:
Channel 5	On	0T	(+)	+ 0.00(in)	+ 1.69(in)	0800305	Entergy/Pilgrim Procedure TP04-020
Channel 6	Off	N/A	N/A	N/A	N/A	N/A	Limited examination due to vessel to baffle plate gusset.
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks	
	Increment Position		Scan Position		Yes	No	N/A	Attachment:	
1 - 15	Start	Stop	Start	Stop	Channel 1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
	14673	15948	13781	15041	Channel 2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					Channel 3	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Archive Tape/CD No.: IA & IB
					Channel 5	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 6	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 7	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Analysis Tape/CD No.: A & B
					Channel 8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	

Analyst / SNT Level / Date: Joel G. Godwin / III / 24 Apr. 05 *Joel G. Godwin*

Page 35/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Nuclear Station	Weld Identification: RPV-L-2-338A	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-3
Project No.: 02-0285	Weld Description: Ring 1 Vert @ 78°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-07B	Scan Path Drawing: SPLONGSHI&4DS	Exam Date: 24 Apr. 04	Examination Time: Start 1505, End 1518
Data Acquisition Operator (s) / SNT Level: David Kleinjan / II Alan Schaefer / N/A			Surface Temperature °F: Start 85, End 85

Data Acquisition

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit:	14766	14746	Lower Limit	14988	14988	Beam Direction:	Dn/Up
Scan:	Y Axis	Upper Limit:	16026	16021	Upper Limit	17616	17616	Transducer Size:	1.00
Increment:	X Axis	Increment Interval:	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts:	100		Conversion Counts	100		Number of Scans:	15
Scan Motion:	Bi-directional	Conversion Units In:	1.00		Conversion Units In:	1.00		Device Position:	D (0)
Correction:	Default	EDAS Radius In:	113.10						

Module Parameters: A-07B Cal 03						Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset		PNS-03	Check for limitations due to the proximity of the jet pump diffuser and the baffle plate.
Channel 1	On	55	(-)	- 1.40(in)	- 1.21(in)	0800301	
Channel 2	On	55	(+)	+ 1.40(in)	- 1.21(in)	0800302	
Channel 3	On	SLIC-40	(-)	- 1.97(in)	+ 1.69(in)	0800303	
Channel 4	On	SLIC-40	(+)	+ 1.97(in)	+ 1.69(in)	0800304	Examination Remarks:
Channel 5	On	0T	(+)	+ 0.00(in)	+ 1.69(in)	0800305	Entergy/Pilgrim Procedure TP04-020
Channel 6	Off	N/A	N/A	N/A	N/A	N/A	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Analyst Remarks
	Increment Position		Scan Position		Yes	No	N/A		
1 - 15	Start 14747	Stop 16021	Start 14988	Stop 17616	Channel 1 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Archive Tape/CD No.: 1A & 1B Analysis Tape/CD No.: A & B	
				Channel 2 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
				Channel 3 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
				Channel 4 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
				Channel 5 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
				Channel 6 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
				Channel 7 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
				Channel 8 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>			

Analyst / SNT Level / Date: Joel G. Godwin / III / 24 Apr. 05 *Joel G. Godwin*

Page 36/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Nuclear Station	Weld Identification: RPV-L-2-338A	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-4
Project No.: 02-0285	Weld Description: Ring 1 Vert @ 78°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-07A	Scan Path Drawing: SPLONGSHI&4DS	Exam Date	Examination Time
Data Acquisition Operator (s) / SNT Level: Alan Schaefer / N/A		24 Apr. 04	Start End
			Start End
			85 85

Data Acquisition

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	14766	14749	Lower Limit	17563	17563	Beam Direction:	Up/Dn
Scan:	Y Axis	Upper Limit	16026	16021	Upper Limit	20191	20191	Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	15
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	D (180)
Correction:	Default	EDAS Radius In.	113.10						

Module Parameters:						Cal 03	Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset				
Channel 1	On	55	(+)	+ 1.40(in)	+ 1.21(in)		PNS-03	Check for limitations due to the proximity of the jet pump diffuser and the baffle plate.
Channel 2	On	55	(-)	- 1.40(in)	+ 1.21(in)		0800301	
Channel 3	On	SLIC-40	(+)	+ 1.97(in)	- 1.69(in)		0800302	
Channel 4	On	SLIC-40	(-)	- 1.97(in)	- 1.69(in)		0800303	
Channel 5	On	0T	(+)	+ 0.00(in)	- 1.69(in)		0800304	Examination Remarks:
Channel 6	Off	N/A	N/A	N/A	N/A		0800305	Entergy/Pilgrim Procedure TP04-020
Channel 7	Off	N/A	N/A	N/A	N/A		N/A	
Channel 8	Off	N/A	N/A	N/A	N/A		N/A	

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks	
	Increment Position		Scan Position		Yes	No	N/A	Attachment:	
	Start	Stop	Start	Stop	Channel 1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
1 - 15	14749	16021	17563	20191	Channel 2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation
					Channel 3	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Required:
					Channel 4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					Channel 5	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Archive Tape/CD No.:
					Channel 6	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1A & 1B
					Channel 7	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Analysis Tape/CD No.:
					Channel 8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	A & B

Analyst / SNT Level / Date: Joel G. Godwin / III / 24 Apr. 05 *Joel G. Godwin*

Page 37/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Nuclear Station	Weld Identification: RPV-L-2-338A	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-5
Project No.: 02-0285	Weld Description: Ring 1 Vert @ 78°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-07A	Scan Path Drawing: SPLONGSH1&4DS	Exam Date: 24 Apr. 04	Surface Temperature °F
Data Acquisition Operator (s) / SNT Level: Alan Schaefer / N/A		Examination Time	Start End
		1547 1552	85 85

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	14766	14748	Lower Limit	20138	20138	Beam Direction:	Up/Dn
Scan:	Y Axis	Upper Limit	16026	16013	Upper Limit	22766	22766	Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	15
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	D (180)
Correction:	Default	EDAS Radius In.	113.10						

Module Parameters:						Cal 03	Calibration Records:	Examination Notes:
Channel	Status	Angle	Direction	Scan Offset	Step Offset		PNS-03	Check for limitations due to the proximity of the jet pump diffuser and the baffle plate.
Channel 1	On	55	(+)	+ 1.40(in)	+ 1.21(in)		0800301	
Channel 2	On	55	(-)	- 1.40(in)	+ 1.21(in)		0800302	
Channel 3	On	SLIC-40	(+)	+ 1.97(in)	- 1.69(in)		0800303	
Channel 4	On	SLIC-40	(-)	- 1.97(in)	- 1.69(in)		0800304	Examination Remarks:
Channel 5	On	OT	(+)	+ 0.00(in)	- 1.69(in)		0800305	Entergy/Pilgrim Procedure TP04-020
Channel 6	Off	N/A	N/A	N/A	N/A		N/A	
Channel 7	Off	N/A	N/A	N/A	N/A		N/A	
Channel 8	Off	N/A	N/A	N/A	N/A		N/A	

Increment & Scan Positions Actual					Recordable Indications			Analyst Remarks			
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A	Attachment:	Further Evaluation Required:		
	Start	Stop	Start	Stop	Channel 1	Channel 2	Channel 3	Channel 4		Channel 5	Channel 6
1 - 15	14748	16012	20138	22766	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Archive Tape/CD No.: 1A & 1B		
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Analysis Tape/CD No.: A & B		
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Analyst / SNT Level / Date: Joel G. Godwin / III / 24 Apr. 05 *Joel G. Godwin*

log 38/140



IH SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Nuclear Station	Weld Identification: RPV-L-2-338A	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-6
Project No.: 02-0285	Weld Description: Ring 1 Vert @ 78°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-07A	Scan Path Drawing: SPLONGSH1&4DS	Exam Date: 24 Apr. 04	Surface Temperature °F
Data Acquisition Operator (s) / SNT Level: Alan Schaefer / N/A			Start: 85 End: 85

Data Acquisition

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	14766	14750	Lower Limit	22713	22713	Beam Direction:	Up/Dn
Scan:	Y Axis	Upper Limit	16026	16033	Upper Limit	25341	25341	Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	15
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	D (180)
Correction:	Default	EDAS Radius In.	113.10						

Module Parameters:						Cal 03	Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset				
Channel 1	On	55	(+)	+ 1.40(in)	+ 1.21(in)		PNS-03	Check for limitations due to the proximity of the jet pump diffuser and the baffle plate.
Channel 2	On	55	(-)	- 1.40(in)	+ 1.21(in)		0800301	
Channel 3	On	SLIC-40	(+)	+ 1.97(in)	- 1.69(in)		0800302	
Channel 4	On	SLIC-40	(-)	- 1.97(in)	- 1.69(in)		0800303	
Channel 5	On	0T	(+)	+ 0.00(in)	- 1.69(in)		0800304	Examination Remarks: Entergy/Pilgrim Procedure TP04-020
Channel 6	Off	N/A	N/A	N/A	N/A		0800305	
Channel 7	Off	N/A	N/A	N/A	N/A		N/A	
Channel 8	Off	N/A	N/A	N/A	N/A		N/A	

Data Analysis

Increment & Scan Positions Actual					Recordable Indications			Analyst Remarks	
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
	Start	Stop	Start	Stop					
1 - 15	14750	16034	22713	25341	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Archive Tape/CD No.: 1A & 1B Analysis Tape/CD No.: A & B	
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Analyst / SNT Level / Date: Joel G. Godwin / III / 24 Apr. 05 *Joel G. Godwin*

8892 39/240



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Nuclear Station	Weld Identification: RPV-L-2-338A	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-7
Project No.: 02-0285	Weld Description: Ring 1 Vert @ 78°	Device Configuration: D-PNPS-101	
Mod.Conf.: A-07-1D	Scan Path Drawing: SPLONGSH1&4DS	Exam Date: 24 Apr. 05	Surface Temperature °F
Data Acquisition Operator (s) / SNT Level: Richard Riddles / II		Examination Time	Start End
		2228 2240	80 80

Data Acquisition

Scan Controller Parameters		Increment Axis/Device		Planned	Actual	Scan Axis/Arm	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	10488	14646	14646	Lower Limit	14646	14646	Beam Direction:	Ccw/Cw
Scan:	X Axis	Upper Limit	17508	16146	16146	Upper Limit	16146	16146	Transducer Size:	1.00
Increment:	Y Axis	Increment Interval	90	DCI	4	Conversion Counts	100	Code % of Overlap:	10	
Mode:	Automatic Scan	Conversion Units In.	1.00	Conversion Units In.	1.00	Conversion Units In.	1.00	Number of Scans:	79	
Scan Motion:	Bi-directional	EDAS Radius In.	113.10					Device Position:	A (0)	
Correction:	Default									

Module Parameters: A-07-1D Cal 33						Calibration Records:	Examination Notes:
Channel	Status	Angle	Direction	Scan Offset	Step Offset		
Channel 1	On	55	(-)	+ 7.00(in)	+ 0.00(in)	PNS-33	Check for limitations due to the proximity of the jet pump diffuser and the baffle plate.
Channel 2	On	55	(+)	- 7.00(in)	+ 0.00(in)	0803301	
Channel 3	On	SLIC-40	(-)	+ 4.40(in)	+ 1.00(in)	0803302	
Channel 4	On	SLIC-40	(+)	- 4.40(in)	- 1.00(in)	0803303	
Channel 5	On	0T	(+)	+ 4.40(in)	- 1.00(in)	0803304	Examination Remarks:
Channel 6	Off	N/A	N/A	N/A	N/A	0803305	Entergy/Pilgrim Procedure TP04-020
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	Limited exam due to vessel baffle plate gusset.
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks		
	Increment Position		Scan Position		Yes	No	N/A	Attachment:		
48 - 80	Start	Stop	Start	Stop	Channel 1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Archive Tape/CD No.: 1A & 1B Analysis Tape/CD No.: A & B	
	14707	17508	14646	16146	Channel 2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 3	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 5	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					Channel 6	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					Channel 7	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					Channel 8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Analyst / SNT Level / Date: Joel G. Godwin / III / 25 Apr. 05 *Joel G. Godwin*

Page 40/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Nuclear Station	Weld Identification: RPV-L-2-338A	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-8
Project No.: 02-0285	Weld Description: Ring 1 Vert @ 78°	Device Configuration: D-PNPS-101	
Mod.Conf.: A-07-1D	Scan Path Drawing: SPLONGSHI&4DS	Exam Date	Examination Time
Data Acquisition Operator (s) / SNT Level: Richard Riddles / II		24 Apr. 05	Surface Temperature °F
			Start End
		2345	.0011 80 80

Data Acquisition

Scan Controller Parameters		Increment Axis/Device Planned		Actual	Scan Axis/Arm		Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	17418	17418	Lower Limit	14646	14646		Beam Direction:	CCW/CW
Scan:	X Axis	Upper Limit	24438	24438	Upper Limit	16146	16146		Transducer Size:	1.00
Increment:	Y Axis	Increment Interval	90		DCI	4			Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100			Number of Scans:	79
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00			Device Position:	A (0)
Correction:	Default	EDAS Radius In.	113.10							

Module Parameters:						Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset	Cal		
Channel 1	On	55	(-)	+ 7.00(in)	+ 0.00(in)	PNS-33	Check for limitations due to the proximity of the jet pump diffuser and the baffle plate.
Channel 2	On	55	(+)	- 7.00(in)	+ 0.00(in)	0803301	
Channel 3	On	SLIC-40	(-)	+ 4.40(in)	+ 1.00(in)	0803302	
Channel 4	On	SLIC-40	(+)	- 4.40(in)	- 1.00(in)	0803303	
Channel 5	On	0T	(+)	+ 4.40(in)	- 1.00(in)	0803304	Examination Remarks: Entergy/Pilgrim Procedure TP04-020
Channel 6	Off	N/A	N/A	N/A	N/A	0803305	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Data Analysis

Increment & Scan Positions Actual					Recordable Indications			Analyst Remarks	
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
	Start	Stop	Start	Stop					
1 - 79	17418	24438	14646	16146	Channel 1 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Archive Tape/CD No.: 1A & 1B Analysis Tape/CD No.: A & B	
					Channel 2 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 3 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 4 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 5 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					Channel 6 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					Channel 7 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					Channel 8 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Analyst / SNT Level / Date: Joel G. Godwin / III / 25 Apr. 05 *Paul A. Godwin*

Page 4/14

ISWT EXAMINATION SUMMARY RECORD

Project No.: 02-0285

PILGRIM STATION

Summary Sheet No.: 000300

SITE: PILGRIM STATION
SYSTEM: REACTOR PRESSURE VESSEL
LINE/SUBASSEMBLY: RING 1 VERTICAL WELD @ 318-DEGREES
IDENTIFICATION: RPV-L-2-338C

NDE Method	Proc/Rev/Chg/ICN	NDE Examination	Calibration Sheet No.	Data Sheet No.	N O		Resolution Record	CNF Number	Remarks
					I	H			
AUT	ISWT-PDI-AUT1/0/0/1,2	AUT45	0803401	exam 18	X	-	N/A	N/A	Examination no's 17 - 18.
AUT	ISWT-PDI-AUT1/0/0/1,2	AUT55	0803402	exam 18	X	-	N/A	N/A	AUTO for thickness measurement only.
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTSLIC40	0803403,0803404	exam 18	X	-	N/A	N/A	
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTSLIC40	0803405	exam 18	X	-	N/A	N/A	
AUT	ISWT-PDI-AUT1/0/0/1,2	AUT55T	0802305,0802302	exam 17	X	-	N/A	N/A	
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTSLIC40T	0802303,0802304	exam 17	X	-	N/A	N/A	
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTO	0802305	exam 17	X	-	N/A	N/A	

- NOTES:
1. Weld RPV-L-2-338C was examined from the inside surface using AIRIS-21 and EDAS-II examination equipment.
 2. No recordable indications were detected during this examination.
 3. The examination was limited due to proximity of baffle plate, baffle plate gusset, jet pump diffusers, core shroud tie rod, and the N2K nozzle, 25% examination coverage was achieved.
 4. Examination 18 was divided into 3 segments 18a, 18b, and 18c.

****UT CALIBRATION BLOCK(s)****
 D-70187-2/D70389-1

Page 42/140

Prepared by: Steven J. Todd
 Steven J. Todd - Project Engineer

Date: 4/30/05

Handwritten signature/initials



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Nuclear Station	Weld Identification: RPV-L-2-338C	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-17a
Project No.: 02-0285	Weld Description: Ring 1 Vert @ 318°	Device Configuration: D-PNPS-101	
Mod.Conf.: A-07-1A	Scan Path Drawing: SPLONGSH1&4SS	Exam Date: 26 Apr. 05	Examination Time: Start 0255, End 0309
Data Acquisition Operator (s) / SNT Level: Richard Riddles / II			Surface Temperature °F: Start 88, End 88

Data Acquisitions

Scan Controller Parameters		Increment Axis/Device		Planned	Actual	Scan Axis/Arm		Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	62139	62139	62139	Lower Limit	9888	14050	14050	Beam Direction:	Up/Dn
Scan:	Y Axis	Upper Limit	63399	62693	62693	Upper Limit	25040	15550	15550	Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90			DCI	4			Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100			Conversion Counts	100			Number of Scans:	15
Scan Motion:	Bi-directional	Conversion Units In.	1.00			Conversion Units In.	1.00			Device Position:	A (90)
Correction:	Default	EDAS Radius In.	113.10								

Module Parameters: A-07-1A Cal 23						Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset		PNS-23	Check for limitations due to the proximity of the jet pump diffusers, the tie rod, the N2 nozzle, and the baffle plate.
Channel 1	On	55	(+)	- 7.00(in)	+ 0.00(in)	0802301	
Channel 2	On	55	(-)	+ 7.00(in)	+ 0.00(in)	0802302	
Channel 3	On	SLIC-40	(+)	- 4.40(in)	+ 1.00(in)	0802303	
Channel 4	On	SLIC-40	(-)	+ 4.40(in)	- 1.00(in)	0802304	Examination Remarks:
Channel 5	On	0T	(+)	- 4.40(in)	- 1.00(in)	0802305	Entergy/Pilgrim Procedure TP04-020
Channel 6	Off	N/A	N/A	N/A	N/A	N/A	Limited exam due to the proximity of the baffle plate.
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Attachment:		Analyst Remarks
	Start	Stop	Start	Stop	Yes	No	N/A	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
1 - 8	62139	62693	14050	15550	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Further Evaluation Required:	
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Archive Tape/CD No.:	
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2A & 2B		
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Analysis Tape/CD No.:		
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	A & B		

Analyst / SNT Level / Date: Joel G. Godwin / III / 26 Apr. 05 *Joel A. Godwin*

Page 43/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Nuclear Station	Weld Identification: RPV-L-2-338C	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-18a
Project No.: 02-0285	Weld Description: Ring 1 Vert @ 318°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-08D	Scan Path Drawing: SPLONGSH1&4SS	Exam Date: 25 Apr. 05	Examination Time: Start 1719, End 1810
Data Acquisition Operator (s) / SNT Level: D. Kleinjan / II			Surface Temperature °F: Start 88, End 88

Data Acquisitions

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	10419	13898	Lower Limit	62178	62178	Beam Direction:	Ccw
Scan:	X Axis	Upper Limit	24549	15657	Upper Limit	63986	63986	Transducer Size:	1.00
Increment:	Y Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	158
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	D (90)
Correction:	Default	EDAS Radius In.	113.10						

Module Parameters:						Cal 34	Calibration Records:	Examination Notes:
Status	A-08D Angle	Cal 34 Direction	Scan Offset	Step Offset				
Channel 1	On	45	(-)	- 1.40(in)	+ 1.21(in)		PNS-34	Check for limitations due to the proximity of the jet pump diffusers, the tie rod, the N2 nozzle, and the baffle plate.
Channel 2	On	55	(-)	+ 1.40(in)	+ 1.21(in)		0803401	
Channel 3	On	SLIC-40	(-)	- 1.97(in)	- 1.69(in)		0803402	
Channel 4	On	SLIC-40	(-)	+ 1.97(in)	- 1.69(in)		0803403	
Channel 5	On	SLIC-40	(+)	+ 0.00(in)	- 1.69(in)		0803404	Examination Remarks:
Channel 6	Off	N/A	N/A	N/A	N/A		0803405	Entergy/Pilgrim Procedure TP04-020
Channel 7	Off	N/A	N/A	N/A	N/A		N/A	Limited exam due to the jet pump diffusers.
Channel 8	Off	N/A	N/A	N/A	N/A		N/A	

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Attachment:	Analyst Remarks
	Start	Stop	Start	Stop	Yes	No	N/A		
41 - 59	13898	15657	62178	63986	Channel 1 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					Channel 2 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation Required:	
					Channel 3 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					Channel 4 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Archive Tape/CD No.:	
					Channel 5 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2A & 2B	
					Channel 6 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Analysis Tape/CD No.:	
					Channel 7 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	A & B	
					Channel 8 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Analyst / SNT Level / Date: Joel G. Godwin / III / 26 Apr. 05 *Joel G. Godwin*

Page 44/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Nuclear Station	Weld Identification: RPV-L-2-338C	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-18b
Project No.: 02-0285	Weld Description: Ring 1 Vert @ 318°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-08D	Scan Path Drawing: SPLONGSH1&4SS	Exam Date: 25 Apr. 05	Surface Temperature °F
Data Acquisition Operator (s) / SNT Level: D. Kleinjan / II		Examination Time	
		Start: 1819	End: 1855
		Start: 88	End: 88

Data Acquisition

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	10419	15728	Lower Limit	62178	62178	Beam Direction:	Ccw
Scan:	X Axis	Upper Limit	24549	19382	Upper Limit	63986	63986	Transducer Size:	1.00
Increment:	Y Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	158
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	D (90)
Correction:	Default	EDAS Radius In.	113.10						

Module Parameters:						Calibration Records:	Examination Notes:
A-08D		Cal 34					
Status	Angle	Direction	Scan Offset	Step Offset			
Channel 1	On	45	(-)	- 1.40(in)	+ 1.21(in)	PNS-34	Check for limitations due to the proximity of the jet pump diffusers, the tie rod, the N2 nozzle, and the baffle plate.
Channel 2	On	55	(-)	+ 1.40(in)	+ 1.21(in)	0803401	
Channel 3	On	SLIC-40	(-)	- 1.97(in)	- 1.69(in)	0803403	
Channel 4	On	SLIC-40	(-)	+ 1.97(in)	- 1.69(in)	0803404	Examination Remarks: Entergy/Pilgrim Procedure TP04-020
Channel 5	On	SLIC-40	(+)	+ 0.00(in)	- 1.69(in)	0803405	
Channel 6	Off	N/A	N/A	N/A	N/A	N/A	Limited exam due to the N2K nozzle.
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Data Analysis

Increment & Scan Positions Actual					Recordable Indications			Analyst Remarks	
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
	Start	Stop	Start	Stop					
60 - 100	15728	19382	62178	63986	Channel 1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Archive Tape/CD No.: 2A & 2B Analysis Tape/CD No.: A & B
					Channel 2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 3	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 5	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 6	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 7	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	

Analyst / SNT Level / Date:

Joel G. Godwin / III / 26 Apr. 05

Joel G. Godwin

Boyer 45/2140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Nuclear Station	Weld Identification: RPV-L-2-338C	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-18c
Project No.: 02-0285	Weld Description: Ring 1 Vert @ 318°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-08D	Scan Path Drawing: SPLONGSH1&4SS	Exam Date: 25 Apr. 05	Surface Temperature °F:
Data Acquisition Operator (s) / SNT Level: Richard Riddles / II		Examination Time:	
		Start: 2051	End: 2145
		Start: 88	End: 88

Data Acquisition

Scan Controller Parameters		Increment Axis/Arm		Planned	Actual	Scan Axis/Device		Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	X Axis	10419	22029	Lower Limit	DCI	62178	62178	Beam Direction:	Ccw
Scan:	X Axis	Upper Limit	Y Axis	24549	23019	Upper Limit	Conversion Counts	63986	63986	Transducer Size:	1.00
Increment:	Y Axis	Increment Interval	Automatic Scan	90		Conversion Units In.	DCI			Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	Bi-directional	100		Conversion Units In.	Conversion Counts	100		Number of Scans:	158
Scan Motion:	Bi-directional	Conversion Units In.	Default	1.00		EDAS Radius In.	Conversion Units In.	1.00		Device Position:	D (90)
Correction:	Default	EDAS Radius In.		113.10							

Module Parameters:						Calibration Records:	Examination Notes:
A-08D		Cal 34					
Status	Angle	Direction	Scan Offset	Step Offset			
Channel 1	On	45	(-)	- 1.40(in)	+ 1.21(in)	PNS-34	Check for limitations due to the proximity of the jet pump diffusers, the tie rod, the N2 nozzle, and the baffle plate.
Channel 2	On	55	(-)	+ 1.40(in)	+ 1.21(in)	0803401	
Channel 3	On	SLIC-40	(-)	- 1.97(in)	- 1.69(in)	0803402	
Channel 4	On	SLIC-40	(-)	+ 1.97(in)	- 1.69(in)	0803403	
Channel 5	On	SLIC-40	(+)	+ 0.00(in)	- 1.69(in)	0803404	
Channel 6	Off	N/A	N/A	N/A	N/A	0803405	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Attachment:		Analyst Remarks
	Increment Position		Scan Position		Yes	No	N/A			
	Start	Stop	Start	Stop				<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
130 - 141	21924	23019	62178	63986	Channel 1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
					Channel 2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Further Evaluation
					Channel 3	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Required:
					Channel 4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes
					Channel 5	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> No
					Channel 6	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Archive Tape/CD No.:
					Channel 7	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2A & 2B
					Channel 8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Analysis Tape/CD No.:
										A & B

Analyst / SNT Level / Date: Joel G. Godwin / III / 26 Apr. 05 *Paul S. Godwin*

Page 46/40



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-338B	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-9
Project No.: 02-0285	Weld Description: Ring 1 Vert @ 198°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-07B	Scan Path Drawing: SPLONGSH1&4DS	Exam Date: 1-May-03	Surface Temperature SF:
Data Acquisition Operator (s) / SNT Level: Harper Jacoby / N/A		Examination Time:	Start: 87 End: 87

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	38452		Lower Limit	9838		Beam Direction:	Dn/Up
Scan:	Y Axis	Upper Limit	39712		Upper Limit	12466		Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	15
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	D (0)
Correction:	Default	EDAS Radius In.	113.10						

Module Parameters: A-07B Cal 03						Calibration Records:	Examination Notes:
Channel	Status	Angle	Direction	Scan Offset	Step Offset		
Channel 1	On	55	(-)	- 1.40(in)	- 1.21(in)	PNS-03 80031	Check for limitations due to the proximity of the jet pump diffuser, the NI nozzle, and the baffle plate.
Channel 2	On	55	(+)	+ 1.40(in)	- 1.21(in)	80032	
Channel 3	On	SLIC-40	(-)	- 1.97(in)	+ 1.69(in)	80033	Examination Remarks: No exam due to proximity of baffel plate gusset.
Channel 4	On	SLIC-40	(+)	+ 1.97(in)	+ 1.69(in)	80034	
Channel 5	On	0T	(+)	+ 0.00(in)	+ 1.69(in)	80035	
Channel 6	Off	N/A	N/A	N/A	N/A	N/A	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Increment & Scan Positions Actual					Recordable Indications			Analyst Remarks	
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A	Attachment: <input type="checkbox"/> Yes <input type="checkbox"/> No	Further Evaluation Required: <input type="checkbox"/> Yes <input type="checkbox"/> No
	Start	Stop	Start	Stop					
					Channel 1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Archive Tape/CD No.: Analysis Tape/CD No.:
					Channel 2	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
					Channel 3	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
					Channel 4	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
					Channel 5	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
					Channel 6	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
					Channel 7	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
					Channel 8	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Analyst / SNT Level / Date:
Hector Diaz III 1-May-03

Page 47/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-338B	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-10
Project No.: 02-0285	Weld Description: Ring 1 Vert @ 198°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-07B	Scan Path Drawing: SPLONGSHI&4DS	Exam Date: 1-May-03	Surface Temperature °F:
Data Acquisition Operator (s) / SNT Level: Harper Jacoby / N/A			Start: 87, End: 87

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	38452	38451	Lower Limit	12413	13700	Beam Direction:	Dn/Up
Scan:	Y Axis	Upper Limit	39712	39712	Upper Limit	15041	15041	Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	15
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	D (0)
Correction:	Default	EDAS Radius In.	113.10						

Module Parameters: A-07B Cal 03						Calibration Records:	Examination Notes:
Channel	Status	Angle	Direction	Scan Offset	Step Offset		
Channel 1	On	55	(-)	- 1.40(in)	- 1.21(in)	PNS-03	Check for limitations due to the proximity of the jet pump diffuser, the N1 nozzle, and the baffle plate.
Channel 2	On	55	(+)	+ 1.40(in)	- 1.21(in)	80031	
Channel 3	On	SLIC-40	(-)	- 1.97(in)	+ 1.69(in)	80032	
Channel 4	On	SLIC-40	(+)	+ 1.97(in)	+ 1.69(in)	80033	
Channel 5	On	0T	(+)	+ 0.00(in)	+ 1.69(in)	80034	Examination Remarks: Limited exam due to proximity of baffle plate gusset.
Channel 6	Off	N/A	N/A	N/A	N/A	80035	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Increment & Scan Positions Actual					Recordable Indications			Analyst Remarks	
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
	Start	Stop	Start	Stop					
1 - 5	38471	39552	13621	15041	Channel 1 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Archive Tape/CD No.: 5A Analysis Tape/CD No.: 1A	
6 - 15	38909	39728	13700	15041	Channel 2 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 3 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 4 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 5 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 6 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					Channel 7 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					Channel 8 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Analyst / SNT Level / Date:
Hector Diaz *Hector Diaz* III 1-May-03

Page 48/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-338B	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-11
Project No.: 02-0285	Weld Description: Ring 1 Vert @ 198°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-07B	Scan Path Drawing: SPLONGSH1&4DS	Exam Date: 1-May-03	Surface Temperature °F:
Data Acquisition Operator (s) / SNT Level: Harper Jacoby / N/A		Examination Time:	Start: 87, End: 87
		Start: 1256, End: 1314	

Scan Controller Parameters		Increment Axis/Arm		Planned	Actual	Scan Axis/Device		Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	38452	38452	38452	Lower Limit	14988	14988	Beam Direction:	Dn/Up	
Scan:	Y Axis	Upper Limit	39712	39712	39712	Upper Limit	17616	17616	Transducer Size:	1.00	
Increment:	X Axis	Increment Interval	90			DCI	4		Code % of Overlap:	10	
Mode:	Automatic Scan	Conversion Counts	100			Conversion Counts	100		Number of Scans:	15	
Scan Motion:	Bi-directional	Conversion Units In.	1.00			Conversion Units In.	1.00		Device Position:	D (0)	
Correction:	Default	EDAS Radius In.	113.10								

Module Parameters: A-07B Cal 03						Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset		PNS-03	Check for limitations due to the proximity of the jet pump diffuser, the N1 nozzle, and the baffle plate.
Channel 1	On	55	(-)	- 1.40(in)	- 1.21(in)	80031	
Channel 2	On	55	(+)	+ 1.40(in)	- 1.21(in)	80032	
Channel 3	On	SLIC-40	(-)	- 1.97(in)	+ 1.69(in)	80033	
Channel 4	On	SLIC-40	(+)	+ 1.97(in)	+ 1.69(in)	80034	
Channel 5	On	0T	(+)	+ 0.00(in)	+ 1.69(in)	80035	
Channel 6	Off	N/A	N/A	N/A	N/A	N/A	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks	
	Increment Position		Scan Position		Yes	No	N/A	Attachment:	
1 - 15	Start: 38451	Stop: 39712	Start: 14988	Stop: 17616	Channel 1 <input type="checkbox"/>	Channel 2 <input checked="" type="checkbox"/>	Channel 3 <input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					Channel 4 <input type="checkbox"/>	Channel 5 <input checked="" type="checkbox"/>	Channel 6 <input type="checkbox"/>	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					Channel 7 <input type="checkbox"/>	Channel 8 <input checked="" type="checkbox"/>		Archive Tape/CD No.: 5A	
								Analysis Tape/CD No.: 1A	

Analyst / SNT Level / Date:
Hector Diaz *Hector Diaz* III 1-May-03

Page 49/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-338B	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-12
Project No.: 02-0285	Weld Description: Ring 1 Vert @ 198°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-07A	Scan Path Drawing: SPLONGSH1&4DS	Exam Date: 1-May-03	Surface Temperature °F:
Data Acquisition Operator (s) / SNT Level: Harper Jacoby	/ N/A	Examination Time:	Start End
		1358 1406	87 87

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	38452	38452	Lower Limit	17563	17563	Beam Direction:	Up/Dn
Scan:	Y Axis	Upper Limit	39712	39712	Upper Limit	20191	20191	Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	15
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	D (180)
Correction:	Default	EDAS Radius In.	113.10						

Module Parameters:						Calibration Records:		Examination Notes:	
A-07A		Cal 03							
Status	Angle	Direction	Scan Offset	Step Offset					
Channel 1	On	55	(+)	+ 1.40(in)	+ 1.21(in)	PNS-03	Check for limitations due to the proximity of the jet pump diffuser, the N1 nozzle, and the baffle plate.		
Channel 2	On	55	(-)	- 1.40(in)	+ 1.21(in)	80031			
Channel 3	On	SLIC-40	(+)	+ 1.97(in)	- 1.69(in)	80032			
Channel 4	On	SLIC-40	(-)	- 1.97(in)	- 1.69(in)	80033			
Channel 5	On	0T	(+)	+ 0.00(in)	- 1.69(in)	80034	Examination Remarks:		
Channel 6	Off	N/A	N/A	N/A	N/A	80035			
Channel 7	Off	N/A	N/A	N/A	N/A	N/A			
Channel 8	Off	N/A	N/A	N/A	N/A	N/A			

Increment & Scan Positions Actual					Recordable Indications			Analyst Remarks	
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A		
	Start	Stop	Start	Stop	Channel 1	Channel 2	Channel 3		
1 - 15	38451	29796	17563	20191	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Archive Tape/CD No.: 5A	
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Analysis Tape/CD No.: 1A	
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Analyst / SNT Level / Date:
Hector Diaz *Hector Diaz* III 1-May-03

Page 50/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-338B	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-13
Project No.: 02-0285	Weld Description: Ring 1 Vert @ 198°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-07A	Scan Path Drawing: SPLONGSH1&4DS	Exam Date: 1-May-03	Surface Temperature °F:
Data Acquisition Operator (s) / SNT Level: Harper Jacoby	/ N/A	Examination Time:	Start: 1414 End: 1425
			Start: 87 End: 87

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	38452	38452	Lower Limit	20138	20138	Beam Direction:	Up/Dn
Scan:	Y Axis	Upper Limit	39712	39712	Upper Limit	22766	22766	Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	15
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	D (180)
Correction:	Default	EDAS Radius In.	113.10						

Module Parameters: A-07A Cal 03						Calibration Records:	Examination Notes:
Channel	Status	Angle	Direction	Scan Offset	Step Offset		
Channel 1	On	55	(+)	+ 1.40(in)	+ 1.21(in)	PNS-03	Check for limitations due to the proximity of the jet pump diffuser, the N1 nozzle, and the baffle plate.
Channel 2	On	55	(-)	- 1.40(in)	+ 1.21(in)	80031	
Channel 3	On	SLIC-40	(+)	+ 1.97(in)	- 1.69(in)	80032	
Channel 4	On	SLIC-40	(-)	- 1.97(in)	- 1.69(in)	80033	
Channel 5	On	0T	(+)	+ 0.00(in)	- 1.69(in)	80034	
Channel 6	Off	N/A	N/A	N/A	N/A	80035	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Increment & Scan Positions Actual					Recordable Indications			Analyst Remarks	
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
	Start	Stop	Start	Stop					
1 - 15	38451	39714	20138	22766	Channel 1 <input type="checkbox"/>	Channel 2 <input checked="" type="checkbox"/>	Channel 3 <input type="checkbox"/>	Archive Tape/CD No.: 5A	
					Channel 4 <input type="checkbox"/>	Channel 5 <input checked="" type="checkbox"/>	Channel 6 <input type="checkbox"/>	Analysis Tape/CD No.: 1A	
					Channel 7 <input type="checkbox"/>	Channel 8 <input checked="" type="checkbox"/>			

Analyst / SNT Level / Date:
Hector Diaz *Hector Diaz* III 1-May-03

Page 51/240



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-338B	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-14
Project No.: 02-0285	Weld Description: Ring 1 Vert @ 198°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-07A	Scan Path Drawing: SPLONGSH1&4DS	Exam Date: 1-May-03	Surface Temperature °F:
Data Acquisition Operator (s) / SNT Level: Harper Jacoby	/ N/A	Examination Time:	
		Start: 1433	End: 1443
		Start: 87	End: 87

Scan Controller Parameters			Increment Axis/Arm			Scan Axis/Device			Positional Parameters	
Controller:	ID Device		Planned	Actual	Planned	Actual	Planned	Actual	Beam Direction:	Up/Dn
Scan:	Y Axis		Lower Limit: 38452	38452	Lower Limit: 22713	22241	Upper Limit: 25341	25341	Transducer Size:	1.00
Increment:	X Axis		Upper Limit: 39712	39712	DCI: 4				Code % of Overlap:	10
Mode:	Automatic Scan		Increment Interval: 90		Conversion Counts: 100				Number of Scans:	15
Scan Motion:	Bi-directional		Conversion Units In.: 1.00		Conversion Units In.: 1.00				Device Position:	D (180)
Correction:	Default		EDAS Radius In.: 113.10							

Module Parameters:						Calibration Records:		Examination Notes:	
	Status	Angle	Direction	Scan Offset	Step Offset	PNS-03			
Channel 1	On	55	(+)	+ 1.40(in)	+ 1.21(in)	20031		Check for limitations due to the proximity of the jet pump diffuser, the NI nozzle, and the baffle plate.	
Channel 2	On	55	(-)	- 1.40(in)	+ 1.21(in)	20032			
Channel 3	On	SLIC-40	(+)	+ 1.97(in)	- 1.69(in)	20033			
Channel 4	On	SLIC-40	(-)	- 1.97(in)	- 1.69(in)	20034		Examination Remarks:	
Channel 5	On	0T	(+)	+ 0.00(in)	- 1.69(in)	20035			
Channel 6	Off	N/A	N/A	N/A	N/A	N/A			
Channel 7	Off	N/A	N/A	N/A	N/A	N/A			
Channel 8	Off	N/A	N/A	N/A	N/A	N/A			

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks		
	Increment Position		Scan Position		Yes	No	N/A	Attachment:		
	Start	Stop	Start	Stop	Channel 1	Channel 2	Channel 3	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
1 - 15	38451	39694	22713	25341	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation Required:		
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Archive Tape/CD No.: 5A		
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Analysis Tape/CD No.: 1A		
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>			

Analyst / SNT Level / Date: **Hector Diaz** 111 1-May-03

Page 52/240



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-338B	Pro/Rev/Chg/ICN: ISWT-PDI-AUT.1/0/0/1,2	Examination No.: ID-15
Project No.: 02-0285	Weld Description: Ring 1 Vert @ 198°	Device Configuration: D-PNPS-101	Surface Temperature °F
Mod.Conf.: A-07-ID	Scan Path Drawing: SPLONGSH1&4DS	Exam Date: 1-May-03	Start: 87
Data Acquisition Operator (s) / SNT Level: R.A. Riddles / II		Examination Time	End: 87
		Start: 0543	End: 0600

Scan Controller Parameters		Increment Axis/Device		Planned	Actual	Scan Axis/Arm		Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	10488	13635	Lower Limit	38332	38332	Beam Direction:	Ccw/Cw	Ccw/Cw	
Scan:	X Axis	Upper Limit	17508	17508	Upper Limit	39832	39832	Transducer Size:	1.00	Code % of Overlap: 10	
Increment:	Y Axis	Increment Interval	90		DCI	4		Number of Scans:	79	Device Position: A (0)	
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100					
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00					
Correction:	Default	EDAS Radius In.	113.10								

Module Parameters: A-07-ID Cal 33						Calibration Records:		Examination Notes:	
Status	Angle	Direction	Scan Offset	Step Offset					
Channel 1	On	55	(-)	+ 7.00(in)	+ 0.00(in)	PNS-33	80331	Check for limitations due to the proximity of the jet pump diffuser, the N1 nozzle, and the baffle plate.	
Channel 2	On	55	(+)	- 7.00(in)	+ 0.00(in)	80332			
Channel 3	On	SLIC-40	(-)	+ 4.40(in)	+ 1.00(in)	80333			
Channel 4	On	SLIC-40	(+)	- 4.40(in)	- 1.00(in)	80334		Examination Remarks:	
Channel 5	On	0T	(+)	+ 4.40(in)	- 1.00(in)	80335		Limited exam due to proximity of baffle plate gusset.	
Channel 6	On	0T	(+)	- 4.40(in)	+ 1.00(in)	80336			
Channel 7	Off	N/A	N/A	N/A	N/A	N/A			
Channel 8	Off	N/A	N/A	N/A	N/A	N/A			

Increment & Scan Positions Actual					Recordable Indications			Analyst Remarks	
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A		
	Start	Stop	Start	Stop					
36 - 79	13631	17569	38332	39832	Channel 1 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					Channel 2 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Channel 6 inactive.
					Channel 3 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Archive Tape/CD No.: 5A	
					Channel 4 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Analysis Tape/CD No.: 1A	
					Channel 5 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 6 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					Channel 7 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					Channel 8 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Analyst / SNT Level / Date: Hector Diaz *Hector Diaz* III 1-May-03

Page 53/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-338B	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-16
Project No.: 02-0285	Weld Description: Ring 1 Vert @ 198°	Device Configuration: D-PNPS-101	
Mod.Conf.: A-07-1C	Scan Path Drawing: SPLONGSH1&4DS	Exam Date: I-May-03	Surface Temperature: 87
Data Acquisition Operator (s) / SNT Level: R.A. Riddles / II		Start: 0603	End: 0648

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	17418	17431	Lower Limit	38332	38332	Beam Direction:	Cw/Ccw
Scan:	X Axis	Upper Limit	24438	24432	Upper Limit	39832	39832	Transducer Size:	1.00
Increment:	Y Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	79
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	A (180)
Correction:	Default	EDAS Radius In.	113.10						

Module Parameters: A-07-1C Cal 33						Calibration Records:	Examination Notes:
Channel	Status	Angle	Direction	Scan Offset	Step Offset		
Channel 1	On	55	(+)	- 7.00(in)	+ 0.00(in)	PNS-33	Check for limitations due to the proximity of the jet pump diffuser, the N1 nozzle, and the baffle plate.
Channel 2	On	55	(-)	+ 7.00(in)	+ 0.00(in)	80331	
Channel 3	On	SLIC-40	(+)	- 4.40(in)	- 1.00(in)	80332	
Channel 4	On	SLIC-40	(-)	+ 4.40(in)	+ 1.00(in)	80333	
Channel 5	On	0T	(+)	- 4.40(in)	+ 1.00(in)	80334	Examination Remarks: Limited exam due to proximity of the N2F nozzle.
Channel 6	On	0T	(+)	+ 4.40(in)	- 1.00(in)	80335	
Channel 7	Off	N/A	N/A	N/A	N/A	80336	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Increment & Scan Positions Actual					Recordable Indications			Analyst Remarks	
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
	Start	Stop	Start	Stop	Channel 1	Channel 2	Channel 3		
1 - 20	17431	19155	38332	39832	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Channel 6 inactive.	
21 - 34	19237	20410	38332	39050	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
35 - 43	20499	21175	38332	39090	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
44 - 50	21284	21804	38332	38950	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
51 - 73	21897	23886	38332	39560	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
74 - 79	23978	24427	38332	39832	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Analyst / SNT Level / Date: Hector Diaz / III / I-May-03

Page 54/140

ISwT EXAMINATION SUMMARY RECORD

Project No.: 02-0285

PILGRIM NUCLEAR POWER STATION

Summary Sheet No.: 000700

SITE: PILGRIM STATION
SYSTEM: REACTOR PRESSURE VESSEL
LINE/SUBASSEMBLY: RING 3 VERTICAL WELD @ 356-DEGREES
IDENTIFICATION: RPV-L-2-339A

NDE Method	Proc/Rev/Chg/ICN	NDE Examination	Calibration Sheet No.	Data Sheet No.	N O		Resolution Record	CNF Number	Remarks
					I	H			
AUT	ISwT-PDI-AUT1/0/0/1,2	AUTO	80335,80336	exam 43-46	X	-	N/A	N/A	Examination no's 39-46. AUTO for thickness measurement only.
AUT	ISwT-PDI-AUT1/0/0/1,2	AUT55	80331,80332	exam 43-46	X	-	N/A	N/A	
AUT	ISwT-PDI-AUT1/0/0/1,2	AUTSLIC40	80333,80334	exam 43-46	X	-	N/A	N/A	
AUT	ISwT-PDI-AUT1/0/0/1,2	AUT55T	80031,80032	exam 39-42	X	-	N/A	N/A	
AUT	ISwT-PDI-AUT1/0/0/1,2	AUTSLIC40T	80033,80034	exam 39-42	X	-	N/A	N/A	
AUT	ISwT-PDI-AUT1/0/0/1,2	AUTO	80035	exam 39-42	X	-	N/A	N/A	

- NOTES:
1. Weld RPV-L-2-339A was examined from the inside surface using AIRIS-21 and EDAS-II examination equipment.
 2. No recordable indications were detected during this examination.
 3. The examination was limited due to proximity of feedwater and core spray spargers, 81% examination coverage was achieved.

****UT CALIBRATION BLOCK(S)****
 D-70187-2/D70380 1

Prepared by: Steven J. Todd
 Steven J. Todd - Project Engineer

Date: 04-May-03

Page 1 of 1

Page 55/240



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-339A	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-39
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 356°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-07B	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 28-Apr-03	Examination Time: Start 1154, End 1206
Data Acquisition Operator (s) / SNT Level: Harper Jacoby	/ N/A		Surface Temperature °F: Start 96, End 96

Data Acquisition

Scan Controller Parameters	Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters
Controller: ID Device	Lower Limit	69950	69950	Lower Limit	38750	38750	Beam Direction: Dn/Up
Scan: Y Axis	Upper Limit	71210	71210	Upper Limit	42814	42814	Transducer Size: 1.00
Increment: X Axis	Increment Interval	90		DCI	4		Code % of Overlap: 10
Mode: Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans: 15
Scan Motion: Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position: D (0)
Correction: Default	EDAS Radius In.	113.60					

Module Parameters:	A-07B	Cal 03				Calibration Records:	Examination Notes:
	Status	Angle	Direction	Scan Offset	Step Offset	PNS-03	Check for limitations due to the proximity of the feedwater and core spray spargers and the guide rod.
Channel 1	On	55	(-)	- 1.40(in)	- 1.21(in)	80031	
Channel 2	On	55	(+)	+ 1.40(in)	- 1.21(in)	80032	
Channel 3	On	SLIC-40	(-)	- 1.97(in)	+ 1.69(in)	80033	
Channel 4	On	SLIC-40	(+)	+ 1.97(in)	+ 1.69(in)	80034	
Channel 5	On	0T	(+)	+ 0.00(in)	+ 1.69(in)	80035	
Channel 6	Off	N/A	N/A	N/A	N/A	N/A	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks		
	Increment Position		Scan Position		Yes	No	N/A	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
	Start	Stop	Start	Stop						
1 - 15	69950	71210	38750	42806	Channel 1 <input type="checkbox"/>	Channel 2 <input checked="" type="checkbox"/>	Channel 3 <input type="checkbox"/>	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Archive Tape/CD No.: 3A Analysis Tape/CD No.: 1A		
				Channel 4 <input type="checkbox"/>	Channel 5 <input checked="" type="checkbox"/>	Channel 6 <input type="checkbox"/>				
				Channel 7 <input type="checkbox"/>	Channel 8 <input type="checkbox"/>					

Analyst / SNT Level / Date: **Hector Diaz** *Hector Diaz* III 29-Apr-03

Page 56/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-339A	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-40
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 356°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-07A	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 28-Apr-03	Surface Temperature °F
Data Acquisition Operator (s) / SNT Level: Harper Jacoby	/ N/A	Start: 1129	End: 1144
		Start: 96	End: 96

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	69950	69950	Lower Limit	42763	42763	Beam Direction:	Up/Dn
Scan:	Y Axis	Upper Limit	71210	71210	Upper Limit	46827	46827	Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	15
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	D (180)
Correction:	Default	EDAS Radius In.	113.60						

Module Parameters: A-07A Cal 03						Calibration Records:	Examination Notes:
	Status	Angle	Direction	Scan Offset	Step Offset		
Channel 1	On	55	(+)	+ 1.40(in)	+ 1.21(in)	PMS-03	Check for limitations due to the proximity of the feedwater and core spray spargers and the guide rod.
Channel 2	On	55	(-)	- 1.40(in)	+ 1.21(in)	80031	
Channel 3	On	SLIC-40	(+)	+ 1.97(in)	- 1.69(in)	80032	
Channel 4	On	SLIC-40	(-)	- 1.97(in)	- 1.69(in)	80033	
Channel 5	On	0T	(+)	+ 0.00(in)	- 1.69(in)	80034	Examination Remarks: Limited exam due to proximity of core spray sparger.
Channel 6	Off	N/A	N/A	N/A	N/A	80035	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Increment & Scan Positions Actual					Recordable Indications			Analyst Remarks	
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Archive Tape/CD No.: 3A Analysis Tape/CD No.: 1A	
	Start	Stop	Start	Stop					
1 - 7	69950	70339	42763	46115	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
6 - 15	70351	71210	42763	46827	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Analyst / SNT Level / Date:
Hector Diaz *Hector Diaz*

Boqr 5/7/03



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-339A	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-41
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 356°	Device Configuration: D-PNPS-102	
Mod. Conf.: A-07B	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 28-Apr-03	Examination Time: Start: 0936, End: 0956
Data Acquisition Operator (s) / SNT Level: Harper Jacoby	/ N/A		Surface Temperature °F: Start: 96, End: 96

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	69950	69950	Lower Limit	46776	46760	Beam Direction:	Dn/Up
Scan:	Y Axis	Upper Limit	71210	71210	Upper Limit	52096	50400	Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	15
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	D (0)
Correction:	Default	EDAS Radius In.	113.60						

Module Parameters: A-07B Cal 03						Calibration Records:	Examination Notes:
	Status	Angle	Direction	Scan Offset	Step Offset		
Channel 1	On	55	(-)	- 1.40(in)	- 1.21(in)	PNS-03	Check for limitations due to the proximity of the feedwater and core spray spargers and the guide rod.
Channel 2	On	55	(+)	+ 1.40(in)	- 1.21(in)	80031	
Channel 3	On	SLIC-40	(-)	- 1.97(in)	+ 1.69(in)	80032	
Channel 4	On	SLIC-40	(+)	+ 1.97(in)	+ 1.69(in)	80033	
Channel 5	On	0T	(+)	+ 0.00(in)	+ 1.69(in)	80034	Examination Remarks: Limited exam due to proximity of core spray sparger.
Channel 6	Off	N/A	N/A	N/A	N/A	80035	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks	
	Start	Stop	Start	Stop	Yes	No	N/A	Attachment:	
1 - 15	69950	71210	46760	50400	Channel 1 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					Channel 2 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation Required:	
					Channel 3 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					Channel 4 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Archive Tape/CD No.:	
					Channel 5 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	3A	
					Channel 6 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Analysis Tape/CD No.:	
					Channel 7 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1A	
					Channel 8 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Analyst / SNT Level / Date:
Hector Diaz *Hector Diaz*

log 58/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Station	Weld Identification: RPV-L-2-339A	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-42
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 356°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-07A	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 28-Apr-03	Surface Temperature °F:
Data Acquisition Operator (s) / SNT Level: Harper Jacoby	/ N/A	Examination Time:	Start End
		1004 1010	96 96

Data Acquisition

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	69950	69950	Lower Limit	46776	50300	Beam Direction:	Up/Dn
Scan:	Y Axis	Upper Limit	71210	71210	Upper Limit	51744	51744	Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	15
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	D (180)
Correction:	Default	EDAS Radius In.	113.60						

Module Parameters:						Cal 03	Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset		PNS-03		
Channel 1	On	55	(+)	+ 1.40(in)	+ 1.21(in)	80031	Check for limitations due to the proximity of the feedwater and core spray spargers and the guide rod. Examination Remarks: Limited exam due to proximity of core spray sparger.	
Channel 2	On	55	(-)	- 1.40(in)	+ 1.21(in)	80032		
Channel 3	On	SLIC-40	(+)	+ 1.97(in)	- 1.69(in)	80033		
Channel 4	On	SLIC-40	(-)	- 1.97(in)	- 1.69(in)	80034		
Channel 5	On	0T	(+)	+ 0.00(in)	- 1.69(in)	80035		
Channel 6	Off	N/A	N/A	N/A	N/A	N/A		
Channel 7	Off	N/A	N/A	N/A	N/A	N/A		
Channel 8	Off	N/A	N/A	N/A	N/A	N/A		

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks	
	Increment Position		Scan Position		Yes	No	N/A	Attachment:	
1 - 15	Start	Stop	Start	Stop	Channel 1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
	69950	71210	50300	51700	Channel 2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation
					Channel 3	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Required:
					Channel 4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					Channel 5	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Archive Tape/CD No.:
					Channel 6	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	3A
					Channel 7	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Analysis Tape/CD No.:
					Channel 8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1A

Analyst / SNT Level / Date:
Hector Diaz *Hector Diaz* III 29-Apr-03

Page 59/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-339A	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-43
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 356°	Device Configuration: D-PNPS-101	
Mod.Conf.: A-07-1D	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 29-Apr-03	Surface Temperature °F
Data Acquisition Operator (s) / SNT Level: R.A. Riddles / II		Examination Time	Start End
		0150 0202	87 78

Data Acquisition

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	39650	39638	Lower Limit	69830	69830	Beam Direction:	Ccw/Cw
Scan:	X Axis	Upper Limit	43340	43330	Upper Limit	71330	71330	Transducer Size:	1.00
Increment:	Y Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	42
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	A (0)
Correction:	Default	EDAS Radius In.	113.60						

Module Parameters: A-07-1D Cal 33						Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset		PNS-33	
Channel 1	On	55	(-)	+ 7.00(in)	+ 0.00(in)	80331	Check for limitations due to the proximity of the feedwater and core spray spargers and the guide rail. Examination Remarks:
Channel 2	On	55	(+)	- 7.00(in)	+ 0.00(in)	80332	
Channel 3	On	SLIC-40	(-)	+ 4.40(in)	+ 1.00(in)	80333	
Channel 4	On	SLIC-40	(+)	- 4.40(in)	- 1.00(in)	80334	
Channel 5	On	OT	(+)	+ 4.40(in)	- 1.00(in)	80335	
Channel 6	On	OT	(+)	- 4.40(in)	+ 1.00(in)	80336	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Data Results

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks						
	Increment Position		Scan Position		Yes	No	N/A	Attachment:						
	Start	Stop	Start	Stop				<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No						
1 - 42	39646	43340	69830	71330	Channel 1 <input type="checkbox"/>	Channel 2 <input checked="" type="checkbox"/>	Channel 3 <input type="checkbox"/>	Channel 4 <input type="checkbox"/>	Channel 5 <input type="checkbox"/>	Channel 6 <input type="checkbox"/>	Channel 7 <input type="checkbox"/>	Channel 8 <input type="checkbox"/>	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Channel 6 inactive.
													Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
													Archive Tape/CD No.: 4A	
													Analysis Tape/CD No.: 1A	

Analyst / SNT Level / Date: Hector Diaz Hector Diaz III 29-Apr-03

Page 60/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-339A	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-44
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 356°	Device Configuration: D-PNPS-101	
Mod.Conf.: A-07-1C	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 29-Apr-03	Surface Temperature °F
Data Acquisition Operator (s) / SNT Level: R.A. Riddles / II		Examination Time	Start End
		0213 222	87 78

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	43213	43215	Lower Limit	69830	69830	Beam Direction:	Cw/Ccw
Scan:	X Axis	Upper Limit	46903	45114	Upper Limit	71330	71330	Transducer Size:	1.00
Increment:	Y Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	42
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	A (180)
Correction:	Default	EDAS Radius In.	113.60						

Module Parameters: A-07-1C Cal 33						Calibration Records:	Examination Notes:
Channel	Status	Angle	Direction	Scan Offset	Step Offset		
Channel 1	On	55	(+)	- 7.00(in)	+ 0.00(in)	PNS-33	Check for limitations due to the proximity of the feedwater and core spray spargers and the guide rod.
Channel 2	On	55	(-)	+ 7.00(in)	+ 0.00(in)	80331	
Channel 3	On	SLIC-40	(+)	- 4.40(in)	- 1.00(in)	80332	
Channel 4	On	SLIC-40	(-)	+ 4.40(in)	+ 1.00(in)	80333	
Channel 5	On	0T	(+)	- 4.40(in)	+ 1.00(in)	80334	Examination Remarks: Limited exam due to proximity of core spray sparger.
Channel 6	On	0T	(+)	+ 4.40(in)	- 1.00(in)	80335	
Channel 7	Off	N/A	N/A	N/A	N/A	80336	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks	
	Increment Position		Scan Position		Yes	No	N/A		
	Start	Stop	Start	Stop	Channel 1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
1 - 22	43213	45108	69830	71330	Channel 2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 3	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					Channel 4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 5	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Archive Tape/CD No.: 4A
					Channel 6	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 7	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Analysis Tape/CD No.: 1A
					Channel 8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	

Analyst / SNT Level / Date:
Hector Diaz *Hector Diaz* III 29-Apr-03

Page 61/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-339A	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-45
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 356°	Device Configuration: D-PNPS-101	
Mod.Conf.: A-07-1D	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 29-Apr-03	Surface Temperature °F:
Data Acquisition Operator (s) / SNT Level: R.A. Riddles	/ II	Examination Time:	Start: 87 End: 78
		Start: 0213 End: 0222	

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	46776	47745	Lower Limit	69830	69830	Beam Direction:	Ccw/Cw
Scan:	X Axis	Upper Limit	51186	50620	Upper Limit	71330	71330	Transducer Size:	1.00
Increment:	Y Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	50
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	A (0)
Correction:	Default	EDAS Radius In.	113.60						

Module Parameters: A-07-1D Cal 33						Calibration Records:	Examination Notes:
Channel	Status	Angle	Direction	Scan Offset	Step Offset		
Channel 1	On	55	(-)	+ 7.00(in)	+ 0.00(in)	PNS-33	Check for limitations due to the proximity of the feedwater and core spray spargers and the guide rod.
Channel 2	On	55	(+)	- 7.00(in)	+ 0.00(in)	80331	
Channel 3	On	SLIC-40	(-)	+ 4.40(in)	+ 1.00(in)	80332	
Channel 4	On	SLIC-40	(+)	- 4.40(in)	- 1.00(in)	80333	
Channel 5	On	0T	(+)	+ 4.40(in)	- 1.00(in)	80334	Examination Remarks: Limited exam due to proximity of core spray sparger.
Channel 6	On	0T	(+)	- 4.40(in)	+ 1.00(in)	80335	
Channel 7	Off	N/A	N/A	N/A	N/A	80336	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Increment & Scan Positions Actual					Recordable Indications			Analyst Remarks	
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A	Attachment:	Channel 6 inactive.
	Start	Stop	Start	Stop				<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
12 - 44	47738	50620	69830	71330	Channel 1 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					Channel 2 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation	
					Channel 3 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Required:	
					Channel 4 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					Channel 5 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Archive Tape/CD No.:	
					Channel 6 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	4A	
					Channel 7 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Analysis Tape/CD No.:	
					Channel 8 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1A	

Analyst / SNT Level / Date:
Hector Diaz *Hector Diaz* III 29-Apr-03

Page 62/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-339A	Pro/Rev/Chg/ICN: ISWT-PDI-AUT/1/0/0/1,2	Examination No.: ID-46
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 356°	Device Configuration: D-PNPS-101	
Mod.Conf.: A-07-1C	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 29-Apr-03	Surface Temperature °F:
Data Acquisition Operator (s) / SNT Level: R.A. Riddles / II		Start: 0116	End: 0121
		Start: 87	End: 78

Data Acquisition

Scan Controller Parameters		Increment Axis/Device		Planned	Actual	Scan Axis/Arm		Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	46776	50533	Lower Limit	69830	69830	Beam Direction:	Ccw/Cw	Transducer Size:	1.00
Scan:	X Axis	Upper Limit	51276	51296	Upper Limit	71330	71330	Code % of Overlap:	10	Number of Scans:	51
Increment:	Y Axis	Increment Interval	90		DCI	4		Device Position:	A (180)		
Mode:	Manual Scan	Conversion Counts	100		Conversion Counts	100					
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00					
Correction:	Default	EDAS Radius In.	113.60								

Module Parameters: A-07-1C Cal 33						Calibration Records:	Examination Notes:
Channel	Status	Angle	Direction	Scan Offset	Step Offset		
Channel 1	On	55	(+)	- 7.00(in)	+ 0.00(in)	PNS-33	Check for limitations due to the proximity of the feedwater and core spray spargers and the guide rod.
Channel 2	On	55	(-)	+ 7.00(in)	+ 0.00(in)	80331	
Channel 3	On	SLIC-40	(+)	- 4.40(in)	- 1.00(in)	80332	
Channel 4	On	SLIC-40	(-)	+ 4.40(in)	+ 1.00(in)	80333	
Channel 5	On	0T	(+)	- 4.40(in)	+ 1.00(in)	80334	Examination Remarks: Limited exam due to proximity of core spray sparger.
Channel 6	On	0T	(+)	+ 4.40(in)	- 1.00(in)	80335	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks	
	Start	Stop	Start	Stop	Yes	No	N/A	Attachment:	
43 - 51	50617	51281	69830	71330	Channel 1 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Channel 6 inactive.
					Channel 2 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation Required:	
					Channel 3 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					Channel 4 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Archive Tape/CD No.:	
					Channel 5 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	4A	
					Channel 6 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Analysis Tape/CD No.:	
					Channel 7 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1A	
					Channel 8 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Analyst / SNT Level / Date:
Hector Diaz

Hector Diaz

III

29-Apr-03

Page 63/140

ISWT EXAMINATION SUMMARY RECORD

Project No.: 02-0285

PILGRIM NUCLEAR POWER STATION

Summary Sheet No.: 000800

SITE: PILGRIM STATION
SYSTEM: REACTOR PRESSURE VESSEL
LINE/SUBASSEMBLY: RING 3 VERTICAL WELD @ 116-DEGREES
IDENTIFICATION: RPV-L-2-339B

NDE Method	Proc/Rev/Chg/ICN	NDE Examination	Calibration Sheet No.	Data Sheet No.	N O		Resolution Record	CNF Number	Remarks
					I	H			
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTO	80335,80336	exam 51-54	X	-	N/A	N/A	Examination no's 47-54.
AUT	ISWT-PDI-AUT1/0/0/1,2	AUT55	80331,80332	exam 51-54	X	-	N/A	N/A	AUTO for thickness measurement only.
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTSLIC40	80333,80334	exam 51-54	X	-	N/A	N/A	
AUT	ISWT-PDI-AUT1/0/0/1,2	AUT55T	80031,80032	exam 47-50	X	-	N/A	N/A	
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTSLIC40T	80033,80034	exam 47-50	X	-	N/A	N/A	
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTO	80035	exam 47-50	X	-	N/A	N/A	

- NOTES:
1. Weld RPV-L-2-339B was examined from the inside surface using AIRIS-21 and EDAS-II examination equipment.
 2. No recordable indications were detected during this examination.
 3. The examination was limited due to proximity of feedwater and core spray spargers and ID taper at circ weld C-3-339A, 75% examination coverage was achieved. ID taper configuration in this area was greater (more severe) than experienced for welds RPV-L-2-339A and RPV-L-2-339C, resulting in slightly less examination coverage on this weld.

****UT CALIBRATION BLOCK(S)****

D-70187-2/D70390-1

Prepared by: Steven J. Todd
 Steven J. Todd - Project Engineer

Date: 2 July 2003

Page 1 of 1

Summary Sheet No.: 000800

Page 65/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Station	Weld Identification: RPV-L-2-339B	Pro/Rev/Chg/ICN: ISWT-PDI-AUF1/0/0/1,2	Examination No.: ID-47
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 116°	Device Configuration: D-PNPS-f02	
Mod.Conf.: A-07B	Scan Path Drawing: SPLONGSH2&3DS	Exam Date	Examination Time
Data Acquisition Operator (s) / SNT Level: R.A. Riddles / II		28-Apr-03	Surface Temperature °F
		Start	End
		2006	2019
		Start	End
		87	87

Data Acquisition

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	22368	22348	Lower Limit	38750	38750	Beam Direction:	Dn/Up
Scan:	Y Axis	Upper Limit	23628	23615	Upper Limit	42814	42402	Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	15
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	D (0)
Correction:	Default	EDAS Radius In.	113.60						

Module Parameters: A-07B Cal 03						Calibration Records:	Examination Notes:
	Status	Angle	Direction	Scan Offset	Step Offset	PNS-03	Check for limitations due to the proximity of the feedwater and core spray spargers.
Channel 1	On	55	(-)	- 1.40(in)	- 1.21(in)	80031	
Channel 2	On	55	(+)	+ 1.40(in)	- 1.21(in)	80032	
Channel 3	On	SLIC-40	(-)	- 1.97(in)	+ 1.69(in)	80033	
Channel 4	On	SLIC-40	(+)	+ 1.97(in)	+ 1.69(in)	80034	
Channel 5	On	0T	(+)	+ 0.00(in)	+ 1.69(in)	80035	
Channel 6	Off	N/A	N/A	N/A	N/A	N/A	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Examination Remarks:
Limited exam due to proximity of core spray sparge.

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks	
	Increment Position		Scan Position		Yes	No	N/A	Attachment:	Further Evaluation
	Start	Stop	Start	Stop	Channel 1	Channel 2	Channel 3		
1 - 11	22376	23144	38750	42402	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
12	23317	-	39434	42402	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
13 - 15	23481	33628	39674	42402	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Archive Tape/CD No.:	
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	4AA	
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Analysis Tape/CD No.:	
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1A	

Analyst / SNT Level / Date: Hector Diaz *Hector Diaz* III 29-Apr-03

Page 66/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Station	Weld Identification: RPV-L-2-339B	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-48
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 116°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-07A	Scan Path Drawing: SPLONGSH2&3DS	Exam Date	Examination Time
Data Acquisition Operator (s) / SNT Level: R.A. Riddles / II		28-Apr-03	Surface Temperature °F
		Start	End
		2028	2036
		Start	End
		87	87

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	22368	22348	Lower Limit	42763	42400	Beam Direction:	Up/Dn
Scan:	Y Axis	Upper Limit	23628	23628	Upper Limit	46827	44800	Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	15
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	D (180)
Correction:	Default	EDAS Radius In.	113.60						

Module Parameters: A-07A Cal 03						Calibration Records:	Examination Notes:
	Status	Angle	Direction	Scan Offset	Step Offset		
Channel 1	On	55	(+)	+ 1.40(in)	+ 1.21(in)	PNS-03	Check for limitations due to the proximity of the feedwater and core spray spargers.
Channel 2	On	55	(-)	- 1.40(in)	+ 1.21(in)	80031	
Channel 3	On	SLIC-40	(+)	+ 1.97(in)	- 1.69(in)	80032	
Channel 4	On	SLIC-40	(-)	- 1.97(in)	- 1.69(in)	80033	
Channel 5	On	0T	(+)	+ 0.00(in)	- 1.69(in)	80034	Examination Remarks: Limited exam due to proximity of core spray sparge.
Channel 6	Off	N/A	N/A	N/A	N/A	80035	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks	
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
	Start	Stop	Start	Stop				
1 - 15	22368	23628	42390	44815	Channel 1 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					Channel 2 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 3 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Archive Tape/CD No.: 4AA
					Channel 4 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 5 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Analysis Tape/CD No.: 1A
					Channel 6 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 7 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 8 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	

Analyst / SNT Level / Date:
 Hector Diaz *Hector Diaz* III 29-Apr-03

Page 67/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-339B	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-49
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 116°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-07B	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 28-Apr-03	Surface Temperature °F
Data Acquisition Operator (s) / SNT Level: Steven J. Todd / III		Examination Time	Start / End
		1810 / 1919	96 / 96

Scan Controller Parameters		Increment Axis/Arm		Planned	Actual	Scan Axis/Device		Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	22368	22368	22368	Lower Limit	46776	47550	47550	Beam Direction:	Dn/Up
Scan:	Y Axis	Upper Limit	23628	23628	23628	Upper Limit	52096	48350	48350	Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90			DCI	4			Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100			Conversion Counts	100			Number of Scans:	15
Scan Motion:	Bi-directional	Conversion Units In.	1.00			Conversion Units In.	1.00			Device Position:	D (0)
Correction:	Default	EDAS Radius In.	113.60								

Module Parameters: A-07B Cal 03						Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset		PNS-03	
Channel 1	On	55	(-)	- 1.40(in)	- 1.21(in)	80031	Check for limitations due to the proximity of the feedwater and core spray spargers. Examination Remarks: Limited exnm due to proximity of core spray, feedwater spargers and ID taper on weld RPV-C-3-339A.
Channel 2	On	55	(+)	+ 1.40(in)	- 1.21(in)	80032	
Channel 3	On	SLIC-40	(-)	- 1.97(in)	+ 1.69(in)	80033	
Channel 4	On	SLIC-40	(+)	+ 1.97(in)	+ 1.69(in)	80034	
Channel 5	On	0T	(+)	+ 0.00(in)	+ 1.69(in)	80035	
Channel 6	Off	N/A	N/A	N/A	N/A	N/A	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Analyst Remarks
	Increment Position		Scan Position		Yes	No	N/A		
1 - 15	Start	Stop	Start	Stop	Channel 1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Archive Tape/CD No.: 4AA Analysis Tape/CD No.: 1A
	22343	23549	47550	48350	Channel 2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 3	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 5	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 6	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 7	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	

Analyst / SNT Level / Date: Hector Diaz / III / 29-Apr-03

Page 68/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-339B	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-50
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 116°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-07A	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 28-Apr-03	Surface Temperature °F:
Data Acquisition Operator (s) / SNT Level: R.A. Riddles / II		Start: 1730	End: 1810
		Start: 96	End: 96

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	22368	22345	Lower Limit	46776	50300	Beam Direction:	Up/Dn
Scan:	Y Axis	Upper Limit	23628	23591	Upper Limit	52096	52092	Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	15
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	D (180)
Correction:	Default	EDAS Radius In.	113.60						

Module Parameters: A-07A Cal 03						Calibration Records:	Examination Notes:
Channel	Status	Angle	Direction	Scan Offset	Step Offset		
Channel 1	On	55	(+)	+ 1.40(in)	+ 1.21(in)	FNS-03	Check for limitations due to the proximity of the feedwater and core spray spargers.
Channel 2	On	55	(-)	- 1.40(in)	+ 1.21(in)	80031	
Channel 3	On	SLIC-40	(+)	+ 1.97(in)	- 1.69(in)	80032	
Channel 4	On	SLIC-40	(-)	- 1.97(in)	- 1.69(in)	80033	
Channel 5	On	0T	(+)	+ 0.00(in)	- 1.69(in)	80034	Examination Remarks: Limited exam due to proximity of core spray and feedwater spargers.
Channel 6	Off	N/A	N/A	N/A	N/A	80035	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Increment & Scan Positions Actual					Recordable Indications			Analyst Remarks	
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A	Attachment:	
	Start	Stop	Start	Stop				<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
1 - 15	22368	23628	50300	52096	Channel 1 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					Channel 2 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation Required:	
					Channel 3 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					Channel 4 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Archive Tape/CD No.:	
					Channel 5 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	4AA	
					Channel 6 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Analysis Tape/CD No.:	
					Channel 7 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1A	
					Channel 8 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Analyst / SNT Level / Date: Hector Diaz *Hector Diaz* III 29-Apr-03

Page 69/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-339B	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-51
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 116°	Device Configuration: D-PNPS-101	
Mod.Conf.: A-07-1D	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 27-Apr-03	Surface Temperature °F
Data Acquisition Operator (s) / SNT Level: R.A. Riddles	/ II	Start: 2027	End: 2102
		Start: 96	End: 96

Data Acquisition

Scan Controller Parameters	Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters
Controller: ID Device	Lower Limit:	39650	39637	Lower Limit	22248	22248	Beam Direction: Ccw/Cw
Scan: X Axis	Upper Limit:	43340	40783	Upper Limit	23748	23748	Transducer Size: 1.00
Increment: Y Axis	Increment Interval:	90		DCI	4		Code % of Overlap: 10
Mode: Automatic Scan	Conversion Counts:	100		Conversion Counts:	100		Number of Scans: 42
Scan Motion: Bi-directional	Conversion Units In.:	1.00		Conversion Units In.:	1.00		Device Position: A (0)
Correction: Default	EDAS Radius In.:	113.60					

Module Parameters:	A-07-1D	Cal 33				Calibration Records:	Examination Notes:
	Status	Angle	Direction	Scan Offset	Step Offset	PNS-33	Check for limitations due to the proximity of the feedwater and core spray spargers.
Channel 1	On	55	(-)	+ 7.00(in)	+ 0.00(in)	80331	
Channel 2	On	55	(+)	- 7.00(in)	+ 0.00(in)	80332	
Channel 3	On	SLIC-40	(-)	+ 4.40(in)	+ 1.00(in)	80333	
Channel 4	On	SLIC-40	(+)	- 4.40(in)	- 1.00(in)	80334	
Channel 5	On	0T	(+)	+ 4.40(in)	- 1.00(in)	80335	
Channel 6	On	0T	(+)	- 4.40(in)	+ 1.00(in)	80336	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks			
	Increment Position		Scan Position		Yes	No	N/A	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
	Start	Stop	Start	Stop	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No						
1 - 14	39666	40807	22248	23748	Channel 1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Channel 6 inactive.		
					Channel 2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
					Channel 3	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
					Channel 4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
					Channel 5	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
					Channel 6	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
					Channel 7	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
					Channel 8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>			

Analyst / SNT Level / Date: Hector Diaz III 29-Apr-03

Page 70/740

Hector Diaz



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-339B	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: JD-52
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 116°	Device Configuration: D-PNPS-101	
Mod.Conf.: A-07-1C	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 27-Apr-03	Surface Temperature °F:
Data Acquisition Operator (s) / SNT Level: R.A. Riddles / II		Start: 2118	End: 2251
		Start: 96	End: 96

Data Acquisition

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	43213	40820	Lower Limit	22248	22248	Beam Direction:	Cw/Ccw
Scan:	X Axis	Upper Limit	46903	45017	Upper Limit	23748	23748	Transducer Size:	1.00
Increment:	Y Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	42
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	A (180)
Correction:	Default	EDAS Radius In.	113.60						

Module Parameters: A-07-1C Cal 33						Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset		PNS-33	
Channel 1	On	55	(+)	- 7.00(in)	+ 0.00(in)	80331	Check for limitations due to the proximity of the feedwater and core spray spargers.
Channel 2	On	55	(-)	+ 7.00(in)	+ 0.00(in)	80332	
Channel 3	On	SLIC-40	(+)	- 4.40(in)	- 1.00(in)	80333	
Channel 4	On	SLIC-40	(-)	+ 4.40(in)	+ 1.00(in)	80334	Examination Remarks: Limited exam due to proximity of the Core Spray Sparger.
Channel 5	On	0T	(+)	- 4.40(in)	+ 1.00(in)	80335	
Channel 6	On	0T	(+)	+ 4.40(in)	- 1.00(in)	80336	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Data Analysis

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Analyst Remarks
	Start	Stop	Start	Stop	Yes	No	N/A		
1 - 50	40795	45017	22248	23748	Channel 1 <input type="checkbox"/>	Channel 2 <input checked="" type="checkbox"/>	Channel 3 <input type="checkbox"/>	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Archive Tape/CD No.: 3A Analysis Tape/CD No.: 1A	Channel 6 inactive.
				Channel 4 <input type="checkbox"/>	Channel 5 <input checked="" type="checkbox"/>	Channel 6 <input type="checkbox"/>			
				Channel 7 <input type="checkbox"/>	Channel 8 <input type="checkbox"/>				

Analyst / SNT Level / Date:
Hector Diaz *Hector Diaz* III 29-Apr-03

Page 7/1/240



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-339B	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-53
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 116°	Device Configuration: D-PNPS-101	
Mod.Conf.: A-07-1D	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 27-Apr-03	Surface Temperature °F
Data Acquisition Operator (s) / SNT Level: Harper Jacoby	/ N/A	Start: 1844	End: 1905

Scan Controller Parameters		Increment Axis/Device	Planned	Actual	Scan Axis/Arm	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	46776	47465	Lower Limit	22248	22248	Beam Direction:	Ccw/Cw
Scan:	X Axis	Upper Limit	51186	50037	Upper Limit	23748	23748	Transducer Size:	1.00
Increment:	Y Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	50
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	A (0)
Correction:	Default	EDAS Radius In.	113.60						

Module Parameters: A-07-1D Cal 33						Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset		PNS-33	
Channel 1	On	55	(-)	+ 7.00(in)	+ 0.00(in)	80331	Check for limitations due to the proximity of the feedwater and core spray spargers.
Channel 2	On	55	(+)	- 7.00(in)	+ 0.00(in)	80332	
Channel 3	On	SLIC-40	(-)	+ 4.40(in)	+ 1.00(in)	80333	
Channel 4	On	SLIC-40	(+)	- 4.40(in)	- 1.00(in)	80334	
Channel 5	On	0T	(+)	+ 4.40(in)	- 1.00(in)	80335	
Channel 6	On	0T	(+)	- 4.40(in)	+ 1.00(in)	80336	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Increment & Scan Positions Actual					Recordable Indications			Analyst Remarks	
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
	Start	Stop	Start	Stop					
9-37	47468	50016	22248	23725	Channel 1 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Archive Tape/CD No.: 3A Analysis Tape/CD No.: 1A	
					Channel 2 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 3 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 4 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 5 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 6 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 7 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					Channel 8 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Analyst / SNT Level / Date: Hector Diaz *Hector Diaz* III 29-Apr-03

Page 72/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Station	Weld Identification: RPV-L-2-339B	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-54
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 116°	Device Configuration: D-FNPS-101	
Mod.Conf.: A-07-1C	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 27-Apr-03	Surface Temperature °F
Data Acquisition Operator (s) / SNT Level: Harper Jacoby / N/A		Examination Time	Start End
		1820 1825	96 96

Scan Controller Parameters		Increment Axis/Device		Planned	Actual	Scan Axis/Arm		Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	46776	49824	Lower Limit	22248	22248	Beam Direction:	Cw/Ccw		
Scan:	X Axis	Upper Limit	51186	51194	Upper Limit	23748	23748	Transducer Size:	1.00		
Increment:	Y Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10		
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	50		
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	A (180)		
Correction:	Default	EDAS Radius In.	113.60								

Module Parameters: A-07-1C Cal 33						Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset		FNS-33	Check for limitations due to the proximity of the feedwater and core spray spargers.
Channel 1	On	55	(+)	- 7.00(in)	+ 0.00(in)	80331	
Channel 2	On	55	(-)	+ 7.00(in)	+ 0.00(in)	80332	
Channel 3	On	SLIC-40	(+)	- 4.40(in)	- 1.00(in)	80333	
Channel 4	On	SLIC-40	(-)	+ 4.40(in)	+ 1.00(in)	80334	
Channel 5	On	0T	(+)	- 4.40(in)	+ 1.00(in)	80335	
Channel 6	On	0T	(+)	+ 4.40(in)	- 1.00(in)	80336	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Analyst Remarks
	Increment Position		Scan Position		Yes	No	N/A		
35 - 50	Start	Stop	Start	Stop	Channel 1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Archive Tape/CD No.: 3A Analysis Tape/CD No.: 1A
	49828	51186	22248	23748	Channel 2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 3	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 5	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 6	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 7	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	

Analyst / SNT Level / Date:
Hector Diaz

Hector Diaz

III

29-Apr-03

Page 73/140

Page 74/240

ISwT EXAMINATION SUMMARY RECORD

Project No.: 02-0285

PILGRIM NUCLEAR POWER STATION

Summary Sheet No.: 000900

SITE: PILGRIM STATION
SYSTEM: REACTOR PRESSURE VESSEL
LINE/SUBASSEMBLY: RING 3 VERTICAL WELD @ 236-DEGREES
IDENTIFICATION: RPV-L-2-339C

NDE Method	Proc/Rev/Chg/ICN	NDE Examination	Calibration Sheet No.	Data Sheet No.	N O		Resolution Record	CNF Number	Remarks
					I	H			
AUT	ISwT-PDI-AUT1/0/0/1,2	AUTO	80335,80336	exam 59-62	X	-	N/A	N/A	Examination no's 55-62.
AUT	ISwT-PDI-AUT1/0/0/1,2	AUT55	80331,80332	exam 59-62	X	-	N/A	N/A	AUTO for thickness measurement only.
AUT	ISwT-PDI-AUT1/0/0/1,2	AUTSLIC40	80333,80334	exam 59-62	X	-	N/A	N/A	
AUT	ISwT-PDI-AUT1/0/0/1,2	AUT55T	80031,80032	exam 55-58	X	-	N/A	N/A	
AUT	ISwT-PDI-AUT1/0/0/1,2	AUTSLIC40T	80033,80034	exam 55-58	X	-	N/A	N/A	
AUT	ISwT-PDI-AUT1/0/0/1,2	AUTO	80035	exam 55-58	X	-	N/A	N/A	

- NOTES:
1. Weld RPV-L-2-339C was examined from the inside surface using AIRIS-21 and EDAS-II examination equipment.
 2. No recordable indications were detected during this examination.
 3. The examination was limited due to proximity of feedwater and core spray spargers. 83% examination coverage was achieved.

****UT CALIBRATION BLOCK(s)****
 D-70187-2/D70389-1

Page 75/140

Prepared by: Steven J. Todd
 Steven J. Todd - Project Engineer

Date: 04-May-03

Page 1 of 1



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-339C	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-55
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 236°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-07B	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 28-Apr-03	Surface Temperature °F:
Data Acquisition Operator (s) / SNT Level: Harper Jacoby / N/A		Examination Time:	
		Start: 1425	End: 1432
		Start: 96	End: 96

Data Acquisition										
Scan Controller Parameters			Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device		Lower Limit	46159	46160	Lower Limit	38750	38750	Beam Direction:	Dn/Up
Scan:	Y Axis		Upper Limit	47419	47380	Upper Limit	42814	40862	Transducer Size:	1.00
Increment:	X Axis		Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan		Conversion Counts	100		Conversion Counts	100		Number of Scans:	15
Scan Motion:	Bi-directional		Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	D (0)
Correction:	Default		EDAS Radius In.	113.60						

Module Parameters: A-07B Cal 03						Calibration Records:	Examination Notes:
Channel	Status	Angle	Direction	Scan Offset	Step Offset		
Channel 1	On	55	(-)	- 1.40(in)	- 1.21(in)	PNS-03	Check for limitations due to the proximity of the feedwater and core spray spargers.
Channel 2	On	55	(+)	+ 1.40(in)	- 1.21(in)	80031	
Channel 3	On	SLIC-40	(-)	- 1.97(in)	+ 1.69(in)	80032	
Channel 4	On	SLIC-40	(+)	+ 1.97(in)	+ 1.69(in)	80033	
Channel 5	On	0T	(+)	+ 0.00(in)	+ 1.69(in)	80034	Examination Remarks:
Channel 6	Off	N/A	N/A	N/A	N/A	80035	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Increment & Scan Positions Actual					Recordable Indications			Analyst Remarks	
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
	Start	Stop	Start	Stop					
1 - 15	46146	47392	38750	40862	Channel 1 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Archive Tape/CD No.: 3A	Analysis Tape/CD No.: 1A
					Channel 2 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 3 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 4 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 5 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 6 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					Channel 7 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					Channel 8 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Analyst / SNT Level / Date:
Hector Diaz *Hector Diaz* III 29-Apr-03

Page 76/100



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-339C	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-56
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 236°	Device Configuration: D-PNPS-102	Surface Temperature °F
Mod.Conf.: A-07A	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 28-Apr-03	Start: 96
Data Acquisition Operator (s) / SNT Level: Harper Jacoby / N/A		Examination Time	End: 96
		Start: 1324	End: 1420

Data Acquisition									
Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	46159	46160	Lower Limit	42763	40763	Beam Direction:	Up/Dn
Scan:	Y Axis	Upper Limit	47419	47420	Upper Limit	46827	44795	Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	15
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	D (180)
Correction:	Default	EDAS Radius In.	113.60						

Module Parameters:						Calibration Records:	Examination Notes:
	A-07A	Cal 03					
	Status	Angle	Direction	Scan Offset	Step Offset		
Channel 1	On	55	(+)	+ 1.40(in)	+ 1.21(in)	PNS-03	Check for limitations due to the proximity of the feedwater and core spray spargers.
Channel 2	On	55	(-)	- 1.40(in)	+ 1.21(in)	80031	
Channel 3	On	SLIC-40	(+)	+ 1.97(in)	- 1.69(in)	80032	
Channel 4	On	SLIC-40	(-)	- 1.97(in)	- 1.69(in)	80033	
Channel 5	On	0T	(+)	+ 0.00(in)	- 1.69(in)	80034	Examination Remarks: Limited exam due to proximity of the core spray line.
Channel 6	Off	N/A	N/A	N/A	N/A	80035	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Increment & Scan Positions Actual					Recordable Indications			Analyst Remarks	
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
	Start	Stop	Start	Stop	Channel 1	Channel 2	Channel 3		
1 - 15	46159	47318	40763	44840	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Archive Tape/CD No.: 3A Analysis Tape/CD No.: 1A	
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Analyst / SNT Level / Date:
Hector Diaz *Hector Diaz* III 29-Apr-03

Page 77/770



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-339C	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-57
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 236°	Device Configuration: D-PNPS-102	
Mod.Conf.: A-07B	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 28-Apr-03	Surface Temperature °F
Data Acquisition Operator (s) / SNT Level: Harper Jacoby / N/A		Examination Time	Start End
		1552 1611	96 96

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	46159	46146	Lower Limit	46776	47550	Beam Direction:	Dn/Up
Scan:	Y Axis	Upper Limit	47419	47420	Upper Limit	52096	50402	Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	15
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	D (0)
Correction:	Default	EDAS Radius In.	113.60						

Module Parameters: A-07B Cal 03						Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset		PNS-03	
Channel 1	On	55	(-)	- 1.40(in)	- 1.21(in)	80031	Check for limitations due to the proximity of the feedwater and core spray spargers.
Channel 2	On	55	(+)	+ 1.40(in)	- 1.21(in)	80032	
Channel 3	On	SLIC-40	(-)	- 1.97(in)	+ 1.69(in)	80033	
Channel 4	On	SLIC-40	(+)	+ 1.97(in)	+ 1.69(in)	80034	Examination Remarks: Limited exam due to proximity of core spray sparger.
Channel 5	On	0T	(+)	+ 0.00(in)	+ 1.69(in)	80035	
Channel 6	Off	N/A	N/A	N/A	N/A	N/A	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks	
	Increment Position		Scan Position		Yes	No	N/A	Attachment:	
	Start	Stop	Start	Stop				<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
1 - 15	46159	47414	47550	50402	Channel 1 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					Channel 2 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation	
					Channel 3 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Required:	
					Channel 4 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					Channel 5 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Archive Tape/CD No.:	
					Channel 6 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	3A	
					Channel 7 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Analysis Tape/CD No.:	
					Channel 8 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1A	

Analyst / SNT Level / Date:
Hector Diaz *Hector Diaz* III 29-Apr-03

Page 78/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Station	Weld Identification: RPV-L-2-339C	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-58
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 236°	Device Configuration: D-PNPS-101	
Mod.Conf.: A-07A	Scan Path Drawing: SPLONGSH3TOPDS	Exam Date: 28-Apr-03	Surface Temperature °F
Data Acquisition Operator (s) / SNT Level: Harper Jacoby / N/A		Examination Time	Start / End
		1617 / 1621	96 / 96

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	46159	46160	Lower Limit	46776	50300	Beam Direction:	Up/Dn
Scan:	Y Axis	Upper Limit	47419	47460	Upper Limit	51744	51744	Transducer Size:	1.00
Increment:	X Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	15
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	D (180)
Correction:	Default	EDAS Radius In.	113.60						

Module Parameters:						Calibration Records:	Examination Notes:
	A-07A	Cal 03					
	Status	Angle	Direction	Scan Offset	Step Offset		
Channel 1	On	55	(+)	+ 1.40(in)	+ 1.21(in)	PNS-03	Check for limitations due to the proximity of the feedwater and core spray spargers.
Channel 2	On	55	(-)	- 1.40(in)	+ 1.21(in)	80031	
Channel 3	On	SLIC-40	(+)	+ 1.97(in)	- 1.69(in)	80032	
Channel 4	On	SLIC-40	(-)	- 1.97(in)	- 1.69(in)	80033	
Channel 5	On	0T	(+)	+ 0.00(in)	- 1.69(in)	80034	Examination Remarks:
Channel 6	Off	N/A	N/A	N/A	N/A	80035	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks	
	Start	Stop	Start	Stop	Yes	No	N/A	Attachment:	
1 - 15	46159	47451	50300	51700	Channel 1 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					Channel 2 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation	
					Channel 3 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Required:	
					Channel 4 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					Channel 5 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Archive Tape/CD No.:	
					Channel 6 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	3A	
					Channel 7 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Analysis Tape/CD No.:	
					Channel 8 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1A	

Analyst / SNT Level / Date:
Hector Diaz *Hector Diaz* III 29-Apr-03

Page 79/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-339C	Pro/Rev/Chg/ICN: ISWT-PDI-AUT1/0/0/1,2	Examination No.: ID-59
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 236°	Device Configuration: D-PNPS-101	
Mod.Conf.: A-07-1D	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 29-Apr-03	Surface Temperature °F
Data Acquisition Operator (s) / SNT Level: R.A. Riddles / II		Examination Time	Start - End
		0430 - 0457	99 - 99

Scan Controller Parameters		Increment Axis/Device		Planned		Actual		Scan Axis/Arm		Planned		Actual		Positional Parameters		
Controller:	ID Device	Lower Limit	39650	39657	Lower Limit	46039	36050	Lower Limit	46039	36050	Beam Direction:	Cw/Cw				
Scan:	X Axis	Upper Limit	43340	42890	Upper Limit	47539	47529	Upper Limit	47539	47529	Transducer Size:	1.00				
Increment:	Y Axis	Increment Interval	90		DCI	4		DCI	4		Code % of Overlap:	10				
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Conversion Counts	100		Number of Scans:	42				
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	A (0)				
Correction:	Default	EDAS Radius In.	113.60													

Module Parameters: A-07-1D Cal 33						Calibration Records:		Examination Notes:	
Channel	Status	Angle	Direction	Scan Offset	Step Offset				
Channel 1	On	55	(-)	+ 7.00(in)	+ 0.00(in)	PNS-33		Check for limitations due to the proximity of the feedwater and core spray spargers.	
Channel 2	On	55	(+)	- 7.00(in)	+ 0.00(in)	80331			
Channel 3	On	SLIC-40	(-)	+ 4.40(in)	+ 1.00(in)	80332			
Channel 4	On	SLIC-40	(+)	- 4.40(in)	- 1.00(in)	80333			
Channel 5	On	0T	(+)	+ 4.40(in)	- 1.00(in)	80334		Examination Remarks: Limited exam due to proximity of the core spray sparger.	
Channel 6	On	0T	(+)	- 4.40(in)	+ 1.00(in)	80335			
Channel 7	Off	N/A	N/A	N/A	N/A	80336			
Channel 8	Off	N/A	N/A	N/A	N/A	N/A			

Increment & Scan Positions Actual					Recordable Indications			Analyst Remarks	
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Archive Tape/CD No.: 4A Analysis Tape/CD No.: 1A	
	Start	Stop	Start	Stop					
1 - 37	39650	42867	46050	47630	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Analyst / SNT Level / Date:
Hector Diaz *Hector Diaz* III 29-Apr-03

Boyer 8/14/03



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-339C	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-60
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 236°	Device Configuration: D-PNPS-101	
Mod.Conf.: A-07-1C	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 29-Apr-03	Surface Temperature °F
Data Acquisition Operator (s) / SNT Level: R.A. Riddles / II		Examination Time	
		Start: 0512	End: 0522
		Start: 99	End: 99

Data Acquisition

Scan Controller Parameters		Increment Axis/Device		Planned		Actual		Scan Axis/Arm		Planned		Actual		Positional Parameters	
Controller:	ID Device	Lower Limit	43213	42943	Lower Limit	46039	46030	Lower Limit	46039	46030	Beam Direction:	Cw/Ccw			
Scan:	X Axis	Upper Limit	46903	45020	Upper Limit	47539	47515	Upper Limit	47539	47515	Transducer Size:	1.00			
Increment:	Y Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10						
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	42						
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	A (180)						
Correction:	Default	EDAS Radius In.	113.60												

Module Parameters:						Cal 33		Calibration Records:		Examination Notes:	
Channel	Status	Angle	Direction	Scan Offset	Step Offset	PNS-33					
Channel 1	On	55	(+)	- 7.00(in)	+ 0.00(in)	80331		Check for limitations due to the proximity of the feedwater and core spray spargers.			
Channel 2	On	55	(-)	+ 7.00(in)	+ 0.00(in)	80332					
Channel 3	On	SLIC-40	(+)	- 4.40(in)	- 1.00(in)	80333					
Channel 4	On	SLIC-40	(-)	+ 4.40(in)	+ 1.00(in)	80334		Examination Remarks:			
Channel 5	On	0T	(+)	- 4.40(in)	+ 1.00(in)	80335		Limited exam due to proximity of the core spray sparger.			
Channel 6	On	0T	(+)	+ 4.40(in)	- 1.00(in)	80336					
Channel 7	Off	N/A	N/A	N/A	N/A	N/A					
Channel 8	Off	N/A	N/A	N/A	N/A	N/A					

Data Analysis

Increment & Scan Positions Actual					Recordable Indications			Analyst Remarks			
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Archive Tape/CD No.: 4A Analysis Tape/CD No.: 1A			
	Start	Stop	Start	Stop							
1 - 24	42943	45015	46039	47539	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Channel 6 inactive.			
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				
					<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				
					<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Analyst / SNT Level / Date:
 Hector Diaz *Hector Diaz* III 29-Apr-03

Page 81/140



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant: Pilgrim Station	Weld Identification: RPV-L-2-339C	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-61
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 236°	Device Configuration: D-PNPS-101	
Mod.Conf.: A-07-1D	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 29-Apr-03	Surface Temperature °F:
Data Acquisition Operator (s) / SNT Level:			Start: 82 End: 82
			Start: 2046 End: 2109

Scan Controller Parameters		Increment Axis/Arm	Planned	Actual	Scan Axis/Device	Planned	Actual	Positional Parameters	
Controller:	ID Device	Lower Limit	46776	47496	Lower Limit	46039	46063	Beam Direction:	Ccw/Cw
Scan:	X Axis	Upper Limit	51186	51186	Upper Limit	47539	47523	Transducer Size:	1.00
Increment:	Y Axis	Increment Interval	90		DCI	4		Code % of Overlap:	10
Mode:	Automatic Scan	Conversion Counts	100		Conversion Counts	100		Number of Scans:	50
Scan Motion:	Bi-directional	Conversion Units In.	1.00		Conversion Units In.	1.00		Device Position:	A (0)
Correction:	Default	EDAS Radius In.	113.60						

Module Parameters: A-07-1D Cal 33						Calibration Records:	Examination Notes:
Status	Angle	Direction	Scan Offset	Step Offset			
Channel 1	On	55	(-)	+ 7.00(in)	+ 0.00(in)	PNS-33	Check for limitations due to the proximity of the feedwater and core spray spargers.
Channel 2	On	55	(+)	- 7.00(in)	+ 0.00(in)	80331	
Channel 3	On	SLIC-40	(-)	+ 4.40(in)	+ 1.00(in)	80332	
Channel 4	On	SLIC-40	(+)	- 4.40(in)	- 1.00(in)	80333	
Channel 5	On	OT	(+)	+ 4.40(in)	- 1.00(in)	80334	Examination Remarks: Limited exam due to the proximity of the core spray sparger.
Channel 6	On	OT	(+)	- 4.40(in)	+ 1.00(in)	80335	
Channel 7	Off	N/A	N/A	N/A	N/A	80336	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Scan No.(s)	Increment & Scan Positions Actual				Recordable Indications			Analyst Remarks	
	Increment Position		Scan Position		Yes	No	N/A	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
	Start	Stop	Start	Stop					
9-50	47476	51154	46039	47539	Channel 1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Channel 6 inactive.
					Channel 2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 3	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 5	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
					Channel 6	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 7	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
					Channel 8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	

Analyst / SNT Level / Date: Hector Diaz *Hector Diaz* III 30-Apr-03

log sheet



IHI SOUTHWEST TECHNOLOGIES AUTOMATED ULTRASONIC EXAMINATION RECORD

Site/Plant : Pilgrim Station	Weld Identification: RPV-L-2-339C	Pro/Rev/Chg/ICN: ISwT-PDI-AUT1/0/0/1,2	Examination No.: ID-62
Project No.: 02-0285	Weld Description: Ring 3 Vert @ 236°	Device Configuration: D-PNPS-101	
Mod.Conf.: A-07-1C	Scan Path Drawing: SPLONGSH2&3DS	Exam Date: 29-Apr-03	Surface Temperature: 99
Data Acquisition Operator (s) / SNT Level: R.A. Riddles / II		Examination Time: Start: 0608, End: 0615	Start: 99, End: 99

Scan Controller Parameters		Increment Axis/Device		Scan Axis/Arm		Positional Parameters	
Controller:	ID Device	Planned	Actual	Planned	Actual	Beam Direction:	Ccw/Cw
Scan:	X Axis	Lower Limit 46776	49783	Lower Limit 46039	46039	Transducer Size:	1.00
Increment:	Y Axis	Upper Limit 51186	51289	Upper Limit 47539	47539	Code % of Overlap:	10
Mode:	Manual Scan	Increment Interval 90		DCI 4		Number of Scans:	50
Scan Motion:	Bi-directional	Conversion Counts 100		Conversion Counts 100		Device Position:	A (180)
Correction:	Default	Conversion Units In. 1.00		Conversion Units In. 1.00			
		EDAS Radius In. 113.60					

Module Parameters: A-07-1C Cal 33						Calibration Records:	Examination Notes:
Channel	Status	Angle	Direction	Scan Offset	Step Offset	PNS-33	
Channel 1	On	55	(+)	- 7.00(in)	+ 0.00(in)	80331	Check for limitations due to the proximity of the feedwater and core spray spargers.
Channel 2	On	55	(-)	+ 7.00(in)	+ 0.00(in)	80332	
Channel 3	On	SLIC-40	(+)	- 4.40(in)	- 1.00(in)	80333	
Channel 4	On	SLIC-40	(-)	+ 4.40(in)	+ 1.00(in)	80334	Examination Remarks: Limited exam due to proximity of the core spray sparger.
Channel 5	On	0T	(+)	- 4.40(in)	+ 1.00(in)	80335	
Channel 6	On	0T	(+)	+ 4.40(in)	- 1.00(in)	80336	
Channel 7	Off	N/A	N/A	N/A	N/A	N/A	
Channel 8	Off	N/A	N/A	N/A	N/A	N/A	

Increment & Scan Positions Actual					Recordable Indications			Analyst Remarks	
Scan No.(s)	Increment Position		Scan Position		Yes	No	N/A	Attachment: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Channel 6 inactive.
	Start	Stop	Start	Stop					
34 - 52	49718	51287	46039	47539	Channel 1 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Archive Tape/CD No.: 4A Analysis Tape/CD No.: 1A	
					Channel 2 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 3 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 4 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 5 <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
					Channel 6 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					Channel 7 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
					Channel 8 <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Analyst / SNT Level / Date: **Hector Diaz** / III / 29-Apr-03

Page 83/140

ISWT EXAMINATION SUMMARY RECORD

Project No.: 02-0285

PILGRIM NUCLEAR POWER STATION

Summary Sheet No.: 001300

SITE:	PILGRIM STATION
SYSTEM:	REACTOR PRESSURE VESSEL
LINE/SUBASSEMBLY:	UPPER SHELL-TO-FLANGE
IDENTIFICATION:	RPV-C-4-339

*PNPS ISI Program
Designation
is RPV-SF-
RAB*

NDE Method	Proc/Rev/Chg/CN	NDE Examination	Calibration Sheet No.	Data Sheet No.	N O		Resolution Record	CNF Number	Remarks
					I	H			
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTO	80335,80336	exam 83	X	-	N/A	N/A	Examination no's 83 - 84.
AUT	ISWT-PDI-AUT1/0/0/1,2	AUT45	80041	exam 83	X	-	N/A	N/A	AUTO for thickness measurement only.
AUT	ISWT-PDI-AUT1/0/0/1,2	AUT55	80042	exam 83	X	-	N/A	N/A	Indication detected with AUTSLIC40 was
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTSLIC40	80043,80044	exam 83	-	X	020001	285001	sized with AUTSLIC35 and found to be allowable
AUT	ISWT-PDI-AUT1/0/0/1,2	AUT55T	80331,80332	exam 84	X	-	N/A	N/A	In accordance with the 1989 Edition of ASME
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTSLIC40T	80333,80334	exam 84	X	-	N/A	N/A	Section XI Code.
AUT	ISWT-PDI-AUT1/0/0/1,2	AUTO	80335,80336	exam 84	X	-	N/A	N/A	
AUT	ISWT-PDI-AUT2/0/0/1,2,3	AUTSLIC35	809033	exam 83A-RLA	-	X	020001	285001	

- NOTES:
1. Weld RPV-C-4-339 was examined from the inside surface using AIRIS-21 and EDAS-II examination equipment.
 2. The examination was limited due to proximity of the main steam nozzles, nozzle plugs, guide rods at 0 and 180-degrees, and the configuration of the vessel flange. 81% examination coverage was achieved.
 3. One (1) acceptable flaw indication was recorded and sized.
 4. Detection examination patches included #83A - 83F (6 patches) and 84A - 84AB (53 patches).
 5. Sizing examination patches included #83A-RLA (1 patch).


****UT CALIBRATION BLOCK(s)****
D-70187-2/D70389-1

Page 84/140

Prepared by: Steven J. Todd
Steven J. Todd Project Engineer

Date: 3 July 2003


Page 1 of 1



**PILGRAIM NUCLEAR POWER STATION
COVERAGE REPORT
RFO 14**

Weld No.	Exam Type	Exam No.	X		Y		Sq. Inches Scanned / Exam	Total Sq. Inches Scanned	Sq. Inches Required	Percent	Total Coverage	Remarks		
			Start	Stop	Start	Stop								
RPV-L-1-339A Ring 4 Vert @ 60°	Transverse	63	112.12	124.65	499.44	524.36	312.2				97%	Limitations due to the proximity of N3A nozzle.		
		64	112.12	124.65	524.36	548.78	306.0							
		65	112.12	124.73	548.87	573.20	306.8							
		66	112.12	124.73	573.20	597.62	307.9							
		67	112.12	124.73	597.62	622.04	307.9							
		68	112.12	124.73	622.04	646.46	307.9	1849	1620	100%				
	Parallel	69	110.93	125.93	508.44	578.66	1053.3							
		70-1	110.93	125.93	578.66	592.96	214.5							
		70-2	110.93	120.00	592.96	618.95	235.7							
		70-3	110.93	125.93	618.95	647.60	429.8	1933	2068	93%				
RPV-L-1-339B Ring 4 Vert @ 180°	Transverse	71A	348.99	361.59	499.44	524.36	314.0				100%			
		71B	348.99	361.59	524.36	548.78	307.7							
		71C	348.99	361.59	548.78	573.20	307.7							
		72A	348.99	361.59	573.20	597.62	307.7							
		72B	348.99	361.59	597.62	622.04	307.7							
		72C	348.99	361.59	622.04	646.46	307.7	1852	1620	100%				
	Parallel	73	347.79	362.79	508.29	578.82	1058.0							
		74	347.74	362.79	578.82	647.94	1040.3	2098	2068	100%				
RPV-L-1-339C Ring 4 Vert @ 300°	Transverse	75	585.86	598.46	499.44	524.36	314.0				98%	Limitations due to the proximity of N3D nozzle.		
		76	585.86	598.46	524.36	548.78	307.7							
		77	585.86	598.46	548.78	573.20	307.7							
		78	585.86	598.46	573.20	597.62	307.7							
		79	585.86	598.46	597.62	622.04	307.7							
		80	585.86	598.46	622.04	646.46	307.7	1852	1620	100%				
	Parallel	81	584.66	599.66	508.31	578.41	1051.5							
		82-1	584.66	599.66	578.41	592.12	205.7							
		82-2	589.42	599.66	592.12	614.96	233.9							
		82-3	584.66	599.66	614.96	647.91	494.2	1985	2068	96%				


Page 85/940



PILGRIM NUCLEAR POWER STATION COVERAGE REPORT RFO 14

Weld No.	Exam Type	Exam No.	X		Y		Sq. Inches Scanned / Exam	Total Sq. Inches Scanned	Sq. Inches Required	Percent	Total Coverage	Remarks
			Start	Stop	Start	Stop						
RPV-L-2-339A Ring 3 Vert @ 356°	Transverse	39	699.50	712.10	387.50	428.06	511.1	1211	1481	82%	81%	Limitations due to the proximity of the feedwater and core spray spargers.
		40-1	699.50	703.39	428.06	461.15	128.7					
		40-2	703.39	712.10	461.15	468.27	62.0					
		41	699.50	712.10	476.60	504.00	345.2					
		42	699.50	712.10	504.00	517.00	163.8					
	Parallel	43	698.30	713.30	396.50	433.30	552.0					
		44	698.30	713.30	433.30	451.08	266.7					
		45	698.30	713.30	477.38	506.20	432.3					
		46	698.30	713.30	506.20	512.81	99.1					
RPV-L-2-339B Ring 3 Vert @ 116°	Transverse	47-1	223.76	231.41	387.50	424.02	279.4	1045	1481	71%	75%	Limitations due to the proximity of the feedwater and core spray spargers and ID taper at circ weld C-3-339A.
		47-2	231.41	234.81	394.34	424.02	100.9					
		47-3	234.81	236.28	396.74	424.02	40.1					
		48	223.68	236.28	424.02	448.15	304.0					
		49	223.68	235.49	475.50	483.50	94.5					
		50	223.68	236.28	503.00	520.96	226.3					
	Parallel	51	222.48	237.48	396.66	408.07	171.2					
		52	222.48	237.48	408.07	450.17	631.5					
		53	222.48	237.48	474.68	500.16	382.2					
		54	222.48	237.48	500.16	511.86	175.5					
						1360	1701	80%				
RPV-L-2-339C Ring 3 Vert @ 236°	Transverse	55	461.59	473.92	387.50	408.62	260.4	1244	1481	84%	83%	Limitations due to the proximity of the feedwater and core spray spargers.
		56	461.59	473.18	408.62	448.40	461.1					
		57	461.59	474.19	475.50	504.02	359.4					
		58	461.59	474.19	504.02	517.00	163.5					
	Parallel	59	460.50	476.30	396.50	428.67	508.3					
		60	460.39	475.39	429.43	450.15	310.8					
		61	460.39	475.39	474.76	511.54	551.7					
		62	460.39	475.39	511.54	512.87	19.9					
						1391	1701	82%				


Page 86/140



**PILGRIM NUCLEAR POWER STATION
COVERAGE REPORT
RFO 14**

Weld No.	Exam Type	Exam No.	X		Y		Sq. Inches Scanned / Exam	Total Sq. Inches Scanned	Sq. Inches Required	Percent	Total Coverage	Remarks
			Start	Stop	Start	Stop						
RPV-L-1-338A Ring 2 Vert @ 60°	Transverse	19					0.0				28%	Partial exam.
		20					0.0					
		21					0.0					
		22	112.66	125.26	319.93	349.81	376.5					
		23	112.66	125.26	349.81	379.16	369.8					
		24	112.66	125.26	379.16	408.51	369.8	1116	2026	55%		
	Parallel	25					0.0					
		26					0.0	0	2347	0%		
RPV-L-1-338C Ring 2 Vert @ 180°	Transverse	27	350.57	362.02	231.88	261.76	342.1				100%	
		28	350.57	362.73	261.76	291.11	356.9					
		29	350.57	363.10	291.11	320.46	367.8					
		30	350.57	363.17	320.46	349.91	371.1					
		31	350.57	363.17	349.91	379.16	368.6					
		32	350.57	363.17	379.16	408.51	369.8	2176	2026	100%		
	Parallel	33	349.37	364.37	241.33	321.48	1202.3					
		34	349.37	364.37	321.48	400.68	1188.0	2390	2347	100%		


Page 87/240



**PILGRAIM NUCLEAR POWER STATION
 COVERAGE REPORT
 RFO 14**

Weld No.	Exam Type	Exam No.	X		Y		Sq. Inches Scanned / Exam	Total Sq. Inches Scanned	Sq. Inches Required	Percent	Total Coverage	Remarks	
			Start	Stop	Start	Stop							
RPV-L-2-338B Ring 1 Vert @ 198°	Transverse	9					0.0				78%	Limitations due to the proximity of the baffel plate gusset.	
		10-1	384.71	395.52	136.21	150.41	153.5						
		10-2	395.52	397.28	137.00	150.41	23.6						
		11	384.51	397.12	150.41	176.16	324.7						
		12	384.51	397.12	176.16	201.91	324.7						
		13	384.51	397.12	201.91	227.66	324.7						
		14	384.51	396.94	227.66	253.41	320.1	1471	1620	91%			
	Parallel	15	383.32	398.32	136.31	175.69	590.7						
		16-1	383.32	398.32	175.69	191.55	237.9						
		16-2	383.32	390.50	191.55	204.10	90.1						
		16-3	383.32	390.90	204.10	211.75	58.0						
		16-4	383.32	389.50	211.75	218.04	38.9						
		16-5	383.32	395.60	218.04	238.86	255.7						
	16-6	383.32	398.32	238.86	244.27	81.1	1352	2068	65%				


Page 88/240



PILGRIM NUCLEAR POWER STATION COVERAGE REPORT RFO 14

Weld No.	Exam Type	Exam No.	X		Y		Sq. Inches Scanned / Exam	Total Sq. Inches Scanned	Sq. Inches Required	Percent	Total Coverage	Remarks
			Start	Stop	Start	Stop						
RPV-C-4-339 Flange	Transverse	84A	1.00	14.40	640.14	652.74	168.8			81%	Limitations due to the N3 nozzles, Plugs, the flange configuration, and the guide rods:	
		84B	14.40	27.80	640.14	652.74	168.8					
		84C	27.80	40.80	640.14	652.74	163.8					
		84D	40.80	54.60	640.14	652.74	173.9					
		84E	54.60	68.00	640.14	652.74	168.8					
		84F	68.00	81.40	640.14	652.74	168.8					
		84G	81.40	94.80	640.14	652.74	168.8					
		84H	94.80	108.20	640.14	652.74	168.8					
		84I	108.20	121.60	640.14	652.74	168.8					
		84J					0.0					
		84K					0.0					
		84L					0.0					
		84M	160.90	175.20	640.14	652.74	180.2					
		84N	174.20	188.60	640.14	652.74	181.4					
		84O	188.60	202.00	640.14	652.74	168.8					
		84P	202.00	215.40	640.14	652.74	168.8					
		84Q					0.0					
		84R	227.80	242.20	640.14	652.74	181.4					
		84S	242.20	255.60	640.14	652.74	168.8					
		84T	255.60	269.00	640.14	652.74	168.8					
84U	269.00	282.40	640.14	652.74	168.8							
84V	282.40	295.80	640.14	652.74	168.8							
84W	295.80	309.20	640.14	652.74	168.8							
84X	309.20	322.60	640.14	652.74	168.8							


Page 89/140



**PILGRAIM NUCLEAR POWER STATION
COVERAGE REPORT
RFO 14**

Weld No.	Exam Type	Exam No.	X		Y		Sq. Inches Scanned / Exam	Total Sq. Inches Scanned	Sq. Inches Required	Percent	Total Coverage	Remarks
			Start	Stop	Start	Stop						
RPV-C-4-339 Flange	Transverse	84Y	322.60	336.00	640.14	652.74	168.8	[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]	Limitations due to the N3 nozzles, Plugs, the flange configuration, and the guide rods.
		84Z	336.00	349.40	640.14	652.74	168.8					
		84AA	348.40	362.80	640.14	652.74	181.4					
		84BB	362.80	376.00	640.14	652.74	166.3					
		84CC	376.00	389.60	640.14	652.74	171.4					
		84DD	389.60	403.00	640.14	652.74	168.8					
		84EE	403.00	416.40	640.14	652.74	168.8					
		84FF	416.40	429.50	640.14	652.74	165.1					
		84GG	429.50	442.92	640.14	652.74	169.1					
		84HH	442.92	456.60	640.14	652.74	172.4					
		84II	456.60	470.00	640.14	652.74	168.8					
		84JJ	470.00	483.20	640.14	652.74	166.3					
		84KK	483.20	496.20	640.14	652.74	163.8					
		84LL					0.0					
		84MM					0.0					
		84NN					0.0					
		84OO	536.00	550.40	640.14	652.74	181.4					
		84PP	550.40	563.80	640.14	652.74	168.8					
		84QQ					0.0					
		84RR					0.0					
84SS	589.60	603.55	640.14	652.74	175.8							
84TT	603.55	617.00	640.14	652.74	169.5							
84UU	617.00	630.00	640.14	652.74	163.8							
84VV	630.00	644.20	640.14	652.74	178.9							

Boyer 9/2/14



PILGRIM NUCLEAR POWER STATION COVERAGE REPORT RFO 14

Weld No.	Exam Type	Exam No.	X		Y		Sq. Inches Scanned / Exam	Total Sq. Inches Scanned	Sq. Inches Required	Percent	Total Coverage	Remarks
			Start	Stop	Start	Stop						
RPV-C-4-339 Flange	Transverse	84WW	644.20	657.60	640.14	652.74	168.8		7421	8953	83%	Limitations due to the N3 nozzles, Plugs, the flange configuration, and the guide rods.
		84XX	657.60	670.80	640.14	652.74	166.3					
		84YY	670.80	684.40	640.14	652.74	171.4					
		84ZZ	684.40	697.80	640.14	652.74	168.8					
		84AB	697.80	705.29	640.14	652.74	94.4					
	Parallel	83A	0.00	123.23	633.42	652.38	2336.4					
		83B	161.10	194.31	633.42	652.38	629.7					
		83C	232.20	355.77	633.42	652.38	2342.9					
		83D	356.49	478.80	633.42	652.38	2319.0					
		83E	516.43	549.90	633.42	652.38	634.6					
		83F-1	586.80	701.36	633.42	652.38	2172.1					
		83F-2	701.36	705.29	633.42	650.94	68.9					

X is the dimension in the circumferential direction measure in inches from vessel 0°.


Y is the dimension in elevation measured in inches from vessel 0°.

For the Transverse examinations, X is the increment axis, and the Y is the scan axis.

For the Parallel examinations, X is in the scan axis, and Y is the increment axis.

Page 9/240

Page 92/110



Pilgrim RPV
OD Vessel Rollout (Limitations)
May 2003
Limit RPV.dwg



GE ENERGY, NUCLEAR

EXAMINATION SUMMARY SHEET

Report No.:
PIL-R15-05-026

Site: **Pilgrim Nuclear Power Station** Component ID: **RPV-N7A-NV**
 Outage: **RF-015** **NOZZLE TO VESSEL**
 System **RPV** ASME Cat.: **B-D** ASME Item **B3.90** Aug Req **N/A**

Exams Performed	Data Sheet	Cal Sheet	Procedure	Calibration Block	Examination Personnel	Cert Level	Date
45° Shear	UT-029	N/A	TP04-029 (GE-UT-311)	PIL-5B	J. Kent Montgomery	II	4/22/2005
60° Shear	UT-028	N/A	TP04-029 (GE-UT-311)	PIL-5B	J. Kent Montgomery	II	4/22/2005
60° Long.	UT-003	N/A	TP04-018 (GE-UT-300)	PIL-5B	Brad Dummer	III	4/22/2005
60° Long.	UT-004	N/A	TP04-018 (GE-UT-300)	CAL-IIW2-017	Brad Dummer	III	4/22/2005

Examination Results:

Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1989 Edition no Addenda, and Section XI, 1995 Edition with the 1996 Addenda as modified by the PDI program description and the Federal Register, Part II, Nuclear Regulatory Commission, 10 CFR Part 50 for Category B-D Reactor Pressure Vessel (RPV) Assembly Welds.

Manual scans from the outside surface were performed in accordance with procedure TP04-018 Rev. 0 (GE-UT-300 V8) and TP04-029 Rev. 0 (GE-UT-311 V10).

No indications were recorded.

Scanning was restricted due to nozzle configuration.

Manual coverage = 56.7%

Examination results were compared to data report 95-E-437,439,441 from 1995 outage with No Change
 These examinations were performed under Work Order: N/A Change

This Summary and the following data sheets have been reviewed and accepted by the following personnel:

BMP III 4-24-05 Scott 1-211 4/27/05
 Prepared By: Level: Date: Utility Review: Date:
Carl Hansen 4/27/05
 ANII Review: Date:

RWP: 0065
Dose: 1 mr.

Page 1 of 8



GE ENERGY, NUCLEAR

Ultrasonic Calibration and Examination Record RPV Components

Site/Unit: Pilgrim Nuclear Power Station / 1

Data Report Number: PIL-R15-05-026 Linearity Sheet: L-006

Outage: RF-015

Data Sheet Number: UT-009

Procedure: TP04-018 (GE-UT-300)

Rev.: R0 (V8)

DRR: N/A

Calibration Block: PIL-5B

CS **Flt:** **4.35"**
 Material Size Thickness
 Initial Cal: 0945' Exam Start 1400
 Cal Check: N/A Exam End 1440
 Cal Check: N/A Ultragel II 01225
 Final Cal: 1445' Couplant: Batch
 241890 68° F 68° F
 Thermometer Initial Cal Temp. Final Cal Temp:

DAC Construction

Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A
ID	<u>4.1"</u>	1X	<u>80%</u>	<u>7.8"</u>	<u>8.2"</u>	<u>4.1</u>
N/A	N/A	1X	N/A	N/A	N/A	N/A

DAC 1X= 62 dB

Sweep 0-10 10.0" Depth

Note N/A dB difference between 3/8 and 5/8 Vee

Exam Data for Weld: RPV-N7A-NV

NOZZLE TO VESSEL

Configuration:

OD 72° F
 Exam Surface: Component Temperature

Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
<u>TP</u>	<u>OD</u>	<u>68</u>	<u>NRI</u>	<u>60°</u>

Comments: Cal/Exam Date is the date of examination. See coverage sheet for limitations.

Exams performed to maintain a 10% - 20% FSH clad roll.

* Initial cal date: 4/22/05

* Final date: 4/23/05

Numerous spot indications seen but not recordable per procedure.

BA Brad Dummer NI 4/22/2005
 Initials: Examiner Level Cal/Exam Date:
 N/A N/A
 Initials: Examiner Level
 [Signature] IA 4-24-05
 GE Reviewed By: Level: Date:

Search Unit Data

Sigma 22BC-02005 2(1.1"x.62")/Rect.
 Manufacturer: Serial Number: Size / Shape:
 0.65" 60° 59°
 Incident Point: Nominal Angle: Measured Angle:
 3.0 MHz SDC-3 Long
 Frequency: Model: Mode:

Search Unit Cable

RG-174 12' Ø
 Cable Type: Length: Connectors:

Instrument Settings

Penametrics / Epoch 4 091540506
 Manufacturer/Model: Serial Number:
9.615 us 0.234 in./usec. 0.8 - 3.0 MHz
 Delay/Zero: Velocity: Narrowband Filter:
Auto Fullwave 20.0 in. Sa / Med
 Rep Rate: Rectification: Range: Pulsar:
400 Ohms Ø 3.03 MHz Dual
 Damping: Reject: Frequency: Mode:
Off Off Off Off
 DAC: TVG: CSC: DGS:

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Acceptable Linearity performed: 4/15/2005

[Signature] L-III 4/27/05
 Utility Reviewed By: Date:
[Signature] 4/27/05
 ANII Reviewed By: Date:



GE ENERGY, NUCLEAR

Ultrasonic Calibration and Examination Record RPV Components

Site/Unit: Pilgrim Nuclear Power Station / 1
Outage: RF-015

Data Report Number: PIL-R15-05-026 Linearity Sheet: L-006
Data Sheet Number: UT-004

Procedure: TP04-018 (GE-UT-300)

Rev.: R0 (V8)

DRR: N/A

Calibration Block: CAL-IIW2-017

CS	N/A	4.0"
Material	Size	Thickness
Initial Cal: <u>0945'</u>		Exam Star: <u>1400</u>
Cal Check: <u>N/A</u>		Exam End: <u>1440</u>
Cal Check: <u>N/A</u>	<u>Ultragel II</u>	<u>01225</u>
Final Cal: <u>1445'</u>	Couplant:	Batch
<u>241890</u>	<u>68° F</u>	<u>68° F</u>
Thermometer	Initial Cal Temp.	Final Cal Temp:

Search Unit Data

Sigma: <u>22BC-02001</u>	<u>2(1.1"x.62")/Rect.</u>	
Manufacturer:	Serial Number: Size / Shape:	
<u>0.65"</u>	<u>60"</u>	<u>59"</u>
Incident Point:	Nominal Angle:	Measured Angle:
<u>3.0 MHz</u>	<u>SDC-3</u>	<u>Long</u>
Frequency:	Model:	Mode:

Search Unit Cable

<u>RG-174</u>	<u>12'</u>	<u>0</u>
Cable Type:	Length:	Connectors:

Instrument Settings

<u>Panametrics / Epoch 4</u>	<u>031540506</u>		
Manufacturer/Model:	Serial Number:		
<u>9.615 us</u>	<u>0.234 in./usec.</u>	<u>0.6 - 3.0 MHz</u>	
Delay/Zero:	Velocity:	Narrowband Filter:	
<u>Auto</u>	<u>Fullwave</u>	<u>4.0 in.</u>	<u>Sa / Med</u>
Rep Rate:	Rectification:	Range:	Pulser:
<u>100 Ohms</u>	<u>0</u>	<u>3.03 MHz</u>	<u>Dual</u>
Damping:	Reject:	Frequency:	Mode:
<u>Off</u>	<u>Off</u>	<u>Off</u>	<u>Off</u>
DAC:	TVG:	CSC:	DGS:

DAC Construction

Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
1/4	0.6"	1X	80%	1.0"	.58"	2.8
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A

DAC 1X= 58 dB
Sweep 0-10 2.0" Depth
Note N/A dB difference between 3/8 and 5/8 Vee

Exam Data for Weld: RPV-N7A-NV
NOZZLE TO VESSEL
Configuration:

<u>QD</u>	<u>72° F</u>
Exam Surface:	Component Temperature

Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
<u>TP</u>	<u>QD</u>	<u>72</u>	<u>NRI</u>	<u>60°</u>

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Acceptable Linearity performed: 4/15/2005

Comments: Cal/Exam Date is the date of examination. See coverage sheet for limitations.

Calibration for near surface examination.

* Initial cal date: 4/22/05

* Final date: 4/23/05

Numerous spot indications seen but not recordable per procedure.

<u>BD</u>	<u>Brad Dummer</u>	<u>III</u>	<u>4/22/2005</u>
Initials:	Examiner	Level	Cal/Exam Date:
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	
Initials:	Examiner	Level	
<u>[Signature]</u>	<u>[Signature]</u>	<u>III</u>	<u>4-24-05</u>
GE Reviewed By:	Level:	Date:	

<u>[Signature]</u>	<u>2-10</u>	<u>4/27/05</u>
Utility Reviewed By:		Date:
<u>[Signature]</u>		<u>4/27/05</u>
ANII Reviewed By:		Date:



GE ENERGY, NUCLEAR

Ultrasonic Calibration and Examination Record Inner Radius Examinations

Site/Unit: Pilgrim Nuclear Power Station / 1

Data Report Number: PIL-R15-05-026 Linearity Sheet: L-004

Outage: RF-015

Data Sheet Number: UT-028

Procedure: TP04-029 (GE-UT-311)

Rev: R0 (V10)

DRR: N/A

Calibration Data for Block: PIL-5B

<u>CS</u> Material	<u>Flat</u> Size	<u>4.35"</u> Thickness	
Initial Cal: <u>1030°</u>		Exam Start: <u>14:00</u>	
Cal Check: <u>N/A</u>		Exam End: <u>14:45</u>	
Cal Check: <u>N/A</u>	<u>Ultracel H</u> Couplant:	<u>01225</u> Batch	
Final Cal: <u>1405°</u>	<u>241890</u> Thermometer	<u>68° F</u> Initial Cal Temp.	<u>68° F</u> Final Cal Temp.

DAC Construction

Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
ID	<u>4.1"</u>	1X	<u>80%</u>	<u>7.8"</u>	<u>9.18"</u>	<u>4.6</u>
	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

DAC @ 1X 41 dB

Sweep 0-10 20 Metal Path

Acceptable Linearity performed: 4/15/2005

Search Unit Data

<u>KEA</u> Manufacturer:	<u>010HXM</u> Serial No.:	<u>0.5"x1.0"/Rect.</u> Size/Shape:
<u>0.75 in.</u>	<u>60°</u>	<u>61°</u>
Incident Point:	Nominal Angle:	Measured Angle:
<u>2.25 MHz</u> Frequency:	<u>113-892-600</u> Model:	<u>Shear</u> Mode:

Search Unit Cable

<u>RG-174</u> Cable Type:	<u>12'</u> Length:	<u>0</u> Connectors:
------------------------------	-----------------------	-------------------------

Instrument Settings

<u>Panametrics / Epoch 4</u> Manufacturer/Model:	<u>031574111</u> Serial No.:		
<u>14.27 us</u> Zero:	<u>0.128 in/uscc</u> Velocity:	<u>0.8 - 3.0 MHz</u> Narrowband Filter:	
<u>Auto</u> Rep Rate:	<u>Fullwave</u> Rectification:	<u>20.0 in.</u> Range:	<u>Sa / Med</u> Pulsar/Energy
<u>400 Ohms</u> Damping:	<u>0</u> Reject:	<u>2.0 MHz</u> Frequency:	<u>P/E</u> Mode:
<u>Off</u> DAC:	<u>Off</u> TVG:	<u>Off</u> CSC:	<u>Off</u> DGS:

Exam Data for Component: RPV-N7A-NV

NOZZLE TO VESSEL

Configuration:

<u>00</u> Exam Surface:	<u>70° F</u> Component Temp.				
Examination Area	Exam Angle	Rotation Angle	Wedge S/N	Scan dB	Recordable Indications
<u>0-5°</u>	<u>60°</u>	<u>15° - 85°</u>	<u>N/A</u>	<u>55</u>	<u>NRI</u>

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations.

Exams performed to maintain a 5% FSH ID roll.
Scanned CW and CCW.
Calibration sweep is 20 metal path, examination range setting is 10.
Calibration for nozzle to vessel weld.
* Initial Cal: 4/22/2005
* Final Cal: 4/23/2005

JKM J. Kent Montgomery
Initials: Examiner:

4/22/2005
Level Cal/Exam Date:

Sam T... L-111 4/27/05
Utility Reviewed By: Date:

B/M
GE Reviewed By:

III 4-24-05
Level: Date:

Chris... 4/30/05
ANII Reviewed By: Date:



GE ENERGY, NUCLEAR

Ultrasonic Calibration and Examination Record Inner Radius Examinations

Site/Unit: Pilgrim Nuclear Power Station / 1

Data Report Number: PIL-R15-05-026 Linearity Sheet: L-004

Outage: RF-015

Data Sheet Number: UT-029

Procedure: TP04-029 (GE-UT-311)

Rev: R0 (V10) DRR: N/A

Calibration Data for Block: PIL-5B

CS Flat 4.35"
 Material: " Size Thickness
 Initial Cal: 1020" Exam Start 14:00
 Cal Check: N/A Exam End 14:45
 Cal Check: N/A Ultragel II 01225
 Final Cal: 1400" Couplant: Batch
241890 68° F 68° F
 Thermometer Initial Cal Temp. Final Cal Temp.

DAC Construction

Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
ID	<u>4.1"</u>	<u>1X</u>	<u>80%</u>	<u>4.1"</u>	<u>6.19"</u>	<u>3.1</u>
<u>N/A</u>	<u>N/A</u>	<u>1X</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

DAC @ 1X 35.5 dB

Sweep 0-10 20" Metal Path

Acceptable Linearity performed: 4/15/2005

Exam Data for Component: RPV-N7A-NV

NOZZLE TO VESSEL

Configuration:

00 70° F
 Exam Surface: Component Temp.

Examination Area	Exam Angle	Rotation Angle	Wedge S/N	Scan dB	Recordable Indications
<u>0-8"</u>	<u>45°</u>	<u>15° - 85°</u>	<u>N/A</u>	<u>49.5</u>	<u>NRI</u>

Search Unit Data

KEA 010HXC 0.5"x1.0"/Rect
 Manufacturer: Serial No.: Size/Shape:
0.7 in. 45° 44°
 Incident Point: Nominal Angle: Measured Angle:
2.25 MHz 113-892-600 Shear
 Frequency: Model: Mode:

Search Unit Cable

RG-174 12' 0
 Cable Type: Length: Connectors:

Instrument Settings

Panametrics / Epoch 4 031574111
 Manufacturer/Model: Serial No.:
12.35 us 0.128 in /usec 0.8 - 3.0 MHz
 Zero: Velocity: Narrowband Filter:
Auto Fullwave 20.0 in. Sq. / Med
 Rep Rate: Rectification: Range: Pulsar/Energy
400 Ohms 0 2.0 MHz P/E
 Damping: Reject: Frequency: Mode:
Off: Off: Off: Off:
 DAC: TVG: CSC: DGS:

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	Amplitude	Gain (dB)	Sweep (SD)
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations.

Exams performed to maintain a 5% FSH ID roll.
 Scanned CW and CCW.
 Calibration sweep is 20 metal path, examination range setting is 10.
 Calibration for nozzle to vessel weld.
 * Initial Cal: 4/22/2005
 * Final Cal: 4/23/2005

J. Kent Montgomery II 4/22/2005
 Initials: Examiner: Level Cal/Exam Date:

[Signature] L-III 4/27/05
 Utility Reviewed By: Date:

[Signature] II 4-24-05
 GE Reviewed By: Level: Date:

[Signature] 4/28/05
 ANII Reviewed By: Date:

Page 97/240

MANUAL DETECTION NOZZLE INNER RADIUS AND BORE INSPECTION REQUIREMENTS							
PLANT		Pilgrim					
PREPARED BY		S.C. MORTENSON			DATE 01/10/05		
NOZZLE EXAM ZONE	SCAN SURFACE	SCAN AREA	BEAM ANGLE	ROTATION ANGLE	WEDGE RADIUS	MAX MP	FREQ
RECIRC OUTLET							
N/V Weld (M)	PLATE	0 - 3.0°	45.0°	± 70° - 85°	FLAT	10.0°	1 MHz
N/V Weld/Zone 1 (M)	ODBR	50° - 90°	43.0°	83.0°	6.6°	15.9°	1 MHz
Zone 1 (M)	ODBR	35° - 90°	32.9°	82.2°	6.6°	12.9°	1 MHz
Zone 2a (M)	ODBR	35° - 90°	41.2°	48.9°	6.6°	13.4°	1 MHz
RECIRC INLET							
N/V Weld (M)	PLATE	0 - 6.0°	60.0°	± 35° - 65°	FLAT	15.6°	1 MHz
Zone 1 (M)	PLATE	0 - 6.0°	70.0°	± 30°	FLAT	28.0°	1 MHz
Zone 2a (M)	ODBR	55° - 90°	64.8°	20.3°	6.1°	12.2°	1 MHz
TOP HEAD VENT							
N/V (M)	PLATE	0 - 5.0°	60.0°	32° - 56°	FLAT	6.8°	2.25 MHz
ZONE 1-2A (M)	PLATE	0 - 7.0°	70.0°	± 25°	FLAT	9.7°	2.25 MHz
ZONE 2A (M)	PLATE	0 - 8.0°	80.0°	± 25°	FLAT	12.9°	2.25 MHz
TOP HEAD SPARE							
N/V (M)	PLATE	0 - 8.0°	45.0°	15° - 85°	FLAT	4.6°	2.25 MHz
N/V (M)	PLATE	0 - 5.0°	60.0°	15° - 85°	FLAT	6.8°	2.25 MHz
ZONE 1 (M)	PLATE	0 - 4.0°	80.0°	± 50°	FLAT	6.8°	2.25 MHz
ZONE 1-2A (M)	PLATE	0 - 7.0°	70.0°	± 30°	FLAT	9.7°	2.25 MHz
ZONE 2A (M)	PLATE	0 - 9.0°	80.0°	± 25°	FLAT	17.9°	2.25 MHz

W-071
W-070
W-069

W-072

NOTES:	*	DESIGN / (FIXTURE) ROTATION FOR 3.0° PKG OFFSET
	#	DESIGN / (FIXTURE) ROTATION FOR 1.45° PKG OFFSET
	**	WEDGE / (FIXTURE) ROTATION ANGLE FOR 2.5° OFFSET
	***	DESIGN / (FIXTURE) ROTATION FOR 1.5° PKG OFFSET
	(M)	MANUAL

Questions on this NIR requirements sheet shall be directed to S.C. Mortenson @ 704 948-0253

Signature 4/27/05 1/9/2005

Pilgrim - RFO15
 Weld RPV-N7A-NV Top Head Spray
 Spring 2005

Weld Length = 360. Exam Volume = 28.		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. In.	Area Scanned Manual	Percent of Area Manual	Weld Length Manual	Percent Manual
60° NS T-Scan	A	10.2	1.7	5.1%	180	1.5%
60° S6 T-Scan	A	14.7	11.3	40.4%	180	16.1%
60° S4 / IRS Scan	A	3.1	3.1	11.1%	180	2.8%
60° NS P-Scan	A	10.2	1.3	4.6%	180	1.2%
60° S6 P-Scan	A	25.6	5.9	21.1%	180	5.3%
60° IRS P-Scan	A	3.1	3.1	11.1%	180	2.8%
60° NS T-Scan	B	9.1	2.8	10.0%	180	2.5%
60° S6 T-Scan	B	14.9	14.5	51.8%	180	12.9%
60° S4 / IRS Scan	B	2.9	2.9	10.4%	180	2.6%
60° NS P-Scan	B	10.2	2.2	7.9%	180	2.0%
60° S6 P-Scan	B	25.6	11.8	42.1%	180	10.5%
60° IRS P-Scan	B	3.1	2.9	10.4%	180	2.6%


% Total Composite Coverage = 56.7%

Comments: A - Examined from the top side of the nozzle 180°. Scanning limited due to nozzle configuration.
 B - Examined from the bottom side of the nozzle 180°. Scanning limited due to nozzle configuration.

Note - Rounding methods may affect calculated values.

Page 7 of 8
 Page 98/240

Scanned by [Signature] 4/27/05



Nozzle Top Side

60° NS Exam Volume = 10.2 Sq. In.
 60° FV Exam Volume = 14.7 Sq. In.
 Inner 15%T Exam Volume = 3.1 Sq. In.

60° NS T-Scan achieved = 1.7 Sq. In.
 60° FV T-Scan achieved = 11.3 Sq. In.
 60° Inner 15% T-Scan achieved = 3.1 Sq. In.

Scan Plan Coverage T and P scans

60° NS P-Scan achieved = 1.3 Sq. In.
 60° FV P-Scan achieved = 5.9 Sq. In.
 60° Inner 15% P-Scan achieved = 3.1 Sq. In.


Pilgrim Weld RPV-N7A-NV Top Head Spray

Nozzle Bottom Side

60° NS Exam Volume = 9.1 Sq. In.
 60° FV Exam Volume = 14.9 Sq. In.
 Inner 15%T Exam Volume = 2.9 Sq. In.

60° NS T-Scan achieved = 2.8 Sq. In.
 60° FV T-Scan achieved = 14.5 Sq. In.
 60° Inner 15% T-Scan achieved = 2.9 Sq. In.

60° NS P-Scan achieved = 2.2 Sq. In.
 60° FV P-Scan achieved = 11.8 Sq. In.
 60° Inner 15% P-Scan achieved = 2.9 Sq. In.



Scan Plan
Page 8 of 8
8/27/05
Page 8 of 8

Page 99/140



GE ENERGY, NUCLEAR

EXAMINATION SUMMARY SHEET

Report No.:
PIL-R15-05-028

Site: **Pilgrim Nuclear Power Station** Component ID: **RPV-N7B-NV**
 Outage: **RF-015** **NOZZLE TO VESSEL**
 System **RPV** ASME Cat.: **B-D** ASME Item **B3.90** Aug Req **N/A**

Exams Performed	Data Sheet	Cal Sheet	Procedure	Calibration Block	Examination Personnel	Cert Level	Date
45° Shear	UT-033	N/A	TP04-029 (GE-UT-311)	PIL-5E	J. Kent Montgomery	I	4/22/2005
60° Shear	UT-034	N/A	TP04-029 (GE-UT-311)	PIL-5B	J. Kent Montgomery	II	4/22/2005
60° Long.	UT-005	N/A	TP04-018 (GE-UT-300)	PIL-5B	Brad Dummer	III	4/21/2005
60° Long.	UT-006	N/A	TP04-018 (GE-UT-300)	CAL-IIW2-017	Brad Dummer	III	4/22/2005

Examination Results:

Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1989 Edition no Addenda, and Section XI, 1995 Edition with the 1996 Addenda as modified by the PDI program description and the Federal Register, Part II, Nuclear Regulatory Commission, 10 CFR Part 50 for Category B-D Reactor Pressure Vessel (RPV) Assembly Welds.

Manual scans from the outside surface were performed in accordance with procedures TP04-018 Rev. 0 (GE-UT-300 V8) and TP04-029 Rev. 0 (GE-UT-311 V10).

No indications were recorded.

Scanning was restricted due to nozzle configuration.

Manual coverage = 56.7%.

Examination results were compared to data report 95-E-375,377,379 from 1995 outage with No Change
 These examinations were performed under Work Order: N/A Change

This Summary and the following data sheets have been reviewed and accepted by the following personnel:

Prepared By: Level: III Date: 4-24-05 Utility Review:
 ANII Review: Date: 4/28/05

RWP: 0065
Dose: 1 mr.

Page 1 of 8



GE ENERGY, NUCLEAR

Ultrasonic Calibration and Examination Record RPV Components

Site/Unit: Pilgrim Nuclear Power Station / 1
Outage: RF-015

Data Report Number: PIL-R15-05-028 Linearity Sheet: L-006
Data Sheet Number: UT-006

Procedure: TP04-018 (GE-UT-300)

Rev.: R0 (VB)

DRR: N/A

Calibration Block: CAL-IIW2-017

CS	N/A	4.0"
Material	Size	Thickness
Initial Cal: <u>0945</u>		Exam Start: <u>1445</u>
Cal Check: <u>N/A</u>		Exam End: <u>1535</u>
Cal Check: <u>N/A</u>	<u>Ultragel II</u>	<u>01225</u>
Final Cal: <u>1445</u>	Couplant:	Batch
<u>241690</u>	<u>68° F</u>	<u>68° F</u>
Thermometer	Initial Cal Temp.	Final Cal Temp:

DAC Construction

Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
1/4	0.6"	1X	80%	1.0"	.58"	2.8
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A

DAC 1X= 58 dB
Sweep 0-10 2.0" Depth
Note N/A dB difference between 3/8 and 5/8 Vee

Exam Data for Weld: RPV-N7B-NV

NOZZLE TO VESSEL

Configuration:

00 72° F
Exam Surface: Component Temperature

Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
<u>Plate</u>	<u>I</u>	<u>72</u>	<u>NRI</u>	<u>60°</u>
<u>Plate CW/CCW</u>	<u>P</u>	<u>72</u>	<u>NRI</u>	<u>60°</u>

Search Unit Data

Sigma 22BC-02005 2(1.1"x.62")/Rect.
Manufacturer: Serial Number: Size / Shape:
0.65" 60° 59°
Incident Point: Nominal Angle: Measured Angle:
3.0 MHz SDC-3 Long
Frequency: Model: Mode:

Search Unit Cable

RG-174 12' 0
Cable Type: Length: Connectors:

Instrument Settings

Panametrics / Epoch 4 031540506
Manufacturer/Model: Serial Number:
9.615 us 0.234 in./usec. 0.8 - 3.0 MHz
Delay/Zero: Velocity: Narrowband Filter:
Auto Fullwave 4.0 in. Sa / Med
Rep Rate: Rectification: Range: Pulsar:
400 Ohms 0 3.03 MHz Dual
Damping: Reject: Frequency: Mode:
Off Off Off Off
DAC: TVG: CSC: DGS:

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	N/A	N/A	N/A
Amplitude	N/A	N/A	N/A
Gain (dB)	N/A	N/A	N/A
Sweep (SD)	N/A	N/A	N/A

Acceptable Linearity performed: 4/15/2005

Comments: Cal/Exam Date is the date of examination. See coverage sheet for limitations.

Calibration for near surface examination. Exams performed a minimum of 14 dB above reference.

* Initial cal date: 4/22/05

* Final cal date: 4/23/05

Numerous spot indications seen but not recordable per procedure.

BD Bred Dummer III 4/22/2005
Initials: Examiner Level Cal/Exam Date:
N/A N/A
Initials: Examiner Level
[Signature] III 4-25-05
GE Reviewed By: Level: Date:

[Signature] 4/28/05
Utility Reviewed By: Date:
[Signature] 4/28/05
ANII Reviewed By: Date:



GE ENERGY, NUCLEAR

Ultrasonic Calibration and Examination Record RPV Components

Site/Unit: Pilgrim Nuclear Power Station / 1
Outage: RF-015

Data Report Number: PIL-R15-05-028 Linearity Sheet: L-006
Data Sheet Number: UT-005

Procedure: TP04-018 (GE-UT-300)

Rev.: R0 (V8)

DRR: NA

Calibration Block: PIL-5B

CS Flat 4.3f.
Material Size Thickness

Initial Cal: 0945* Exam Stan: 1445
Cal Check: N/A Exam End: 1535

Cal Check: N/A Ultracal II 01225
Final Cal: 1445* Couplant: Batch

241890 68°F 68°F
Thermometer Initial Cal Temp. Final Cal Temp:

DAC Construction

Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A
ID	<u>4.1"</u>	1X	<u>80%</u>	<u>7.8"</u>	<u>8.2"</u>	<u>4.1</u>
N/A	N/A	1X	N/A	N/A	N/A	N/A

DAC 1X= 62 dB
Sweep 0-10 10.0" Depth
Note N/A dB difference between 3/8 and 5/8 Vee

Search Unit Data

Siema 22BC-0200t 2(1.1"x.62")/Rect.
Manufacture: Serial Number: Size / Shape:

0.65" 60° 58°
Incident Point: Nominal Angle: Measured Angle:

3.0 MHz SDC-3 Long.
Frequency: Model: Mode:

Search Unit Cable

RG-174 12' 0
Cable Type: Length: Connectors:

Instrument Settings

Panametrics / Epoch 4 031540506
Manufacturer/Model: Serial Number:

9.615 us 0.234 in./usec. 0.8 - 3.0 MHz
Delay/Zero: Velocity: Narrowband Filter:

Auto Fullwave 20.0 in. Sg. / Med
Rep Rate: Rectification: Range: Pulsar:

400 Ohms 0 3.03 MHz Dual
Damping: Reject: Frequency: Mode:

Off: Off: Off: Off:
DAC: TVG: CSC: DGS:

Exam Data for Weld: RPV-N7B-NV
NOZZLE TO VESSEL
Configuration:

QD 72°F
Exam Surface: Component Temperature

Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
<u>Plate</u>	<u>I</u>	<u>68°</u>	<u>NRI</u>	<u>60°</u>
<u>Plate CW/CCW</u>	<u>P</u>	<u>68°</u>	<u>NRI</u>	<u>60°</u>

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Acceptable Linearity performed: 4/15/2005

Comments: Cal/Exam Date is the date of examination. See coverage sheet for limitations.
Calibration for full volume examination. Exams performed to maintain a 10% - 20% FSH clad roll.
* Initial cal date: 4/22/05
* Final cal date: 4/23/05
Numerous spot indications seen but not recordable per procedure.

BD Bred Dummer III 4/22/2005
Initials: Examiner Level Cal/Exam Date:

N/A N/A
Initials: Examiner Level

1164 1164 4-24-05
GE Reviewed By: Level: Date:

Scott Scott 4/28/05
Utility Reviewed By: Date:

Chris Chris 4/28/05
ANII Reviewed By: Date:



GE ENERGY, NUCLEAR

Ultrasonic Calibration and Examination Record Inner Radius Examinations

Site/Unit: Pilgrim Nuclear Power Station / 1
Outage: RF-015

Data Report Number: PIL-R15-05-028 Linearity Sheet: L-004
Data Sheet Number: UT-034

Procedure: TP04-029 (GE-UT-311)

Rev: R0 (V10) DRR: N/A

Calibration Data for Block: PIL-5B

<u>CS</u> Material	<u>Flat</u> Size	<u>4.35"</u> Thickness
Initial Cal: <u>1030</u>	Exam Start	<u>15:35</u>
Cal Check: <u>N/A</u>	Exam End	<u>16:25</u>
Cal Check: <u>N/A</u>	<u>Ultracel II</u> Couplant:	<u>01225</u> Batch
Final Cal: <u>1405</u>	<u>241890</u> Thermometer	<u>68° F</u> Initial Cal Temp.
		<u>68° F</u> Final Cal Temp.

DAC Construction

Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
ID	<u>4.1"</u>	1X	<u>80%</u>	<u>7.8"</u>	<u>9.18"</u>	<u>4.6</u>
<u>N/A</u>	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

DAC @ 1X 41 dB

Sweep 0-10 20° Metal Path

Acceptable Linearity performed: 4/15/2005

Search Unit Data

<u>KBA</u> Manufacturer:	<u>010HXM</u> Serial No.:	<u>0.5"x1.0"/Rect.</u> Size/Shape:
<u>0.75 in.</u> Incident Point:	<u>60°</u> Nominal Angle:	<u>61°</u> Measured Angle:
<u>2.25 MHz</u> Frequency:	<u>113-892-600</u> Model:	<u>Shear</u> Mode:

Search Unit Cable

<u>RG-174</u> Cable Type:	<u>12'</u> Length:	<u>0</u> Connectors:
------------------------------	-----------------------	-------------------------

Instrument Settings

<u>Panametrics / Epoch 4</u> Manufacturer/Model:	<u>031574111</u> Serial No.:
---	---------------------------------

<u>14.27 us</u> Zero:	<u>0.128 in / us</u> Velocity:	<u>0.8 - 3.0 MHz</u> Narrowband Filter:
<u>Auto</u> Rep Rate:	<u>Fullwave</u> Rectification:	<u>20.0 in.</u> Range:
<u>400 Ohms</u> Damping:	<u>0</u> Reject:	<u>2.0 MHz</u> Frequency:
<u>Off</u> DAC:	<u>Off</u> TVG:	<u>Off</u> CSC:
		<u>Off</u> DGS:

Exam Data for Component: RPV-N7B-NV

NOZZLE TO VESSEL

Configuration:

Exam Surface:	Exam Angle	Rotation Angle	Wedge S/N	Scan dB	Recordable Indications
<u>00</u>	<u>70° E</u>				
<u>0-5"</u>	<u>60°</u>	<u>15° - 85°</u>	<u>N/A</u>	<u>55</u>	<u>NRI</u>

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations.

Exams performed to maintain a 5% FSH ID roll.
Scanned CW and CCW.
Calibration sweep is 20 metal path, examination range setting is 10.
Calibration for nozzle to vessel weld.
* Initial Cal: 4/22/2005
* Final Cal: 4/23/2005

<u>JKM</u> Initials: Examiner:	<u>II</u> Level:	<u>4/22/2005</u> Cal/Exam Date:	<u>[Signature]</u> Utility Reviewed By:	<u>4/22/05</u> Date:
<u>[Signature]</u> GE Reviewed By:	<u>III</u> Level:	<u>4-24-05</u> Date:	<u>[Signature]</u> ANII Reviewed By:	<u>4/22/05</u> Date:



GE ENERGY, NUCLEAR

Ultrasonic Calibration and Examination Record Inner Radius Examinations

Site/Unit: Pilgrim Nuclear Power Station / 1

Data Report Number: PIL-R15-05-028 Linearity Sheet: L-004

Outage: RF-015

Data Sheet Number: UT-033

Procedure: TP04-029 (GE-UT-311)

Rev: R0 (V10) DRR: N/A

Calibration Data for Block: PIL-5B

CS **Fiel** **4.35'**
 Material Size Thickness
 Initial Cal: 1020* Exam Start 15:35
 Cal Check: N/A Exam End 16:25
 Cal Check: N/A **Ultracel II** 01225
 Final Cal: 1400* Couplant: Batch
241880 **68° F** **68° F**
 Thermometer Initial Cal Temp. Final Cal Temp.

DAC Construction

Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
ID	<u>4.1"</u>	1X	<u>80%</u>	<u>4.1"</u>	<u>6.19"</u>	<u>3.1</u>
	<u>N/A</u>	1X	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

DAC @ 1X 35.5 dB

Sweep 0-10 20° **Metal Path**

Acceptable Linearity performed: 4/15/2005

Search Unit Data

KEA **010HXC** **0.5"x1.0"/Rect**
 Manufacturer: Serial No.: Size/Shape:
0.7 in. **45°** **44°**
 Incident Point: Nominal Angle: Measured Angle:
2.25 MHz **113-892-600** **Shear**
 Frequency: Model: Mode:

Search Unit Cable

RG-174 **12'** **0**
 Cable Type: Length: Connectors:

Instrument Settings

Panometrics / Epoch 4 **031574111**
 Manufacturer/Model: Serial No.:

12.35 us **0.128 in /usec** **0.8 - 3.0 MHz**
 Zero: Velocity: Narrowband Filter:
Auto **Fullwave** **20.0 in.** **Sa / Med**
 Rep Rate: Rectification: Range: Pulsar/Energy
400 Ohms **0** **2.0 MHz** **P/E**
 Damping: Reject: Frequency: Mode:
Off: **Off:** **Off:** **Off:**
 DAC: TVG: CSC: DGS:

Exam Data for Component: RPV-N7B-NV

NOZZLE TO VESSEL

Configuration:

0D **70° F**
 Exam Surface: Component Temp.
 Examination Area Exam Angle Rotation Angle Wedge S/N Scan Recordable dB Indications
0-8" **45°** **15° - 85°** **N/A** **49.5** **NRI**

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations.

Exams performed to maintain a 5% FSH ID roll.
 Scanned CW and CCW.
 Calibration sweep is 20 metal path, examination range setting is 10.
 Calibration for nozzle to vessel weld.
 * Initial Cal: 4/22/2005
 * Final Cal: 4/23/2005

JKM J. Kent Montgomery **II** 4/22/2005 [Signature] 4/22/05
 Initials: Examiner: Level Cal/Exam Date: Utility Reviewed By: Date:
[Signature] **III** 4-24-05 [Signature] 4/24/05
 GE Reviewed By: Level: Date: ANII Reviewed By: Date:

MANUAL DETECTION NOZZLE INNER RADIUS AND BORE INSPECTION REQUIREMENTS							
PLANT		Pilgrim					
PREPARED BY		S.C. MORTENSON			DATE 01/10/05		
NOZZLE EXAM ZONE	SCAN SURFACE	SCAN AREA	BEAM ANGLE	ROTATION ANGLE	WEDGE RADIUS	MAX MP	FREQ
RECIRC OUTLET							
N/V Weld (M)	PLATE	0 - 3.0"	48.0°	± 70° - 85°	FLAT	10.2"	1 MHz
N/V Weld/Zone 1 (M)	ODBR	50° - 90°	43.0°	83.0°	6.6"	15.9"	1 MHz
Zone 1 (M)	ODBR	35° - 90°	32.9°	82.2°	6.6"	12.9"	1 MHz
Zone 2a (M)	ODBR	35° - 90°	41.2°	48.9°	6.6"	13.4"	1 MHz
RECIRC INLET							
N/V Weld (M)	PLATE	0 - 6.0"	60.0°	± 35° - 65°	FLAT	15.6"	1 MHz
Zone 1 (M)	PLATE	0 - 8.0"	70.0°	± 30°	FLAT	28.0"	1 MHz
Zone 2a (M)	ODBR	55° - 90°	64.8°	20.3°	6.1"	12.2"	1 MHz
TOP HEAD VENT							
N/V (M)	PLATE	0 - 5.0"	60.0°	32° - 56°	FLAT	6.8"	2.25 MHz
ZONE 1-2A (M)	PLATE	0 - 7.0"	70.0°	±25°	FLAT	9.7"	2.25 MHz
ZONE 2A (M)	PLATE	0 - 8.0"	80.0°	±25°	FLAT	12.9"	2.25 MHz
TOP HEAD SPARE							
N/V (M)	PLATE	0 - 8.0"	45.0°	15° - 85°	FLAT	4.6"	2.25 MHz
N/V (M)	PLATE	0 - 5.0"	60.0°	15° - 85°	FLAT	6.8"	2.25 MHz
ZONE 1 (M)	PLATE	0 - 4.0"	60.0°	±45°	FLAT	6.6"	2.25 MHz
ZONE 1-2A (M)	PLATE	0 - 7.5"	70.0°	±30°	FLAT	10.6"	2.25 MHz
ZONE 2A (M)	PLATE	0 - 9.0"	80.0°	±25°	FLAT	17.9"	2.25 MHz

W-071
W-070
W-069

W-072

NOTES:
 * DESIGN / (FIXTURE) ROTATION FOR 3.0" PKG OFFSET
 # DESIGN / (FIXTURE) ROTATION FOR 1.45" PKG OFFSET
 ** WEDGE / (FIXTURE) ROTATION ANGLE FOR 2.5" OFFSET
 *** DESIGN / (FIXTURE) ROTATION FOR 1.5" PKG OFFSET
 (M) MANUAL

Questions on this NIR requirements sheet shall be directed to S.C. Mortenson @ 704 948-0253

Pilgrim - RFO15
Weld RPV-N7B-NV Top Head Spray
Spring 2005

		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
Weld Length = 360. Exam Volume = 28.		Required Exam Area Sq. In.	Area Scanned Manual	Percent of Area Manual	Weld Length Manual	Percent Manual
60° NS T-Scan	A	10.2	1.7	5.1%	180	1.5%
60° S6 T-Scan	A	14.7	11.3	45.4%	180	10.1%
60° S4 / IRS Scan	A	3.1	3.1	11.1%	180	2.8%
60° NS P-Scan	A	10.2	1.3	4.6%	180	1.2%
60° S6 P-Scan	A	25.6	5.9	21.1%	180	5.3%
60° IRS P-Scan	A	3.1	3.1	11.1%	180	2.8%
60° NS T-Scan	B	9.1	2.8	10.0%	180	2.5%
60° S6 T-Scan	B	14.9	14.5	51.8%	180	12.9%
60° S4 / IRS Scan	B	2.9	2.9	10.4%	180	2.6%
60° NS P-Scan	B	10.2	2.2	7.9%	180	2.0%
60° S6 P-Scan	B	25.6	11.8	42.1%	180	10.5%
60° IRS P-Scan	B	3.1	2.9	10.4%	180	2.6%


% Total Composite Coverage = 56.7%

Comments: A - Examined from the top side of the nozzle 180°. Scanning limited due to nozzle configuration.
B - Examined from the bottom side of the nozzle 180°. Scanning limited due to nozzle configuration.

Note - Rounding methods may affect calculated values.

Signature 4/28/05

Page 7 of 8
Page 106/240




Nozzle Top Side

60° NS Exam Volume = 10.2 Sq. In.
 60° FV Exam Volume = 14.7 Sq. In.
 Inner 15% T Exam Volume = 3.1 Sq. In.

60° NS T-Scan achieved = 1.7 Sq. In.
 60° FV T-Scan achieved = 11.3 Sq. In.
 60° Inner 15% T-Scan achieved = 3.1 Sq. In.

Scan Plan Coverage T and P scans

60° NS P-Scan achieved = 1.3 Sq. In.
 60° FV P-Scan achieved = 5.9 Sq. In.
 60° Inner 15% P-Scan achieved = 3.1 Sq. In.



Pilgrim Weld RPV-N7B-NV Top Head Spray

Nozzle Bottom Side

60° NS Exam Volume = 9.1 Sq. In.
 60° FV Exam Volume = 14.9 Sq. In.
 Inner 15% T Exam Volume = 2.9 Sq. In.

60° NS T-Scan achieved = 2.8 Sq. In.
 60° FV T-Scan achieved = 14.5 Sq. In.
 60° Inner 15% T-Scan achieved = 2.9 Sq. In.

60° NS P-Scan achieved = 2.2 Sq. In.
 60° FV P-Scan achieved = 11.8 Sq. In.
 60° Inner 15% P-Scan achieved = 2.9 Sq. In.

Scan Plan



GE ENERGY, NUCLEAR

EXAMINATION SUMMARY SHEET

Report No.: PIL-R15-05-030

Site: Pilgrim Nuclear Power Station Component ID: RPV-N8-NV
 Outage: RF-015 NOZZLE TO VESSEL
 System RPV ASME Cat.: B-D ASME Item B3.90 Aug Req N/A

Exams Performed	Data Sheet	Cal Sheet	Procedure	Calibration Block	Examination Personnel	Cert Level	Date
60° Shear	UT-025	N/A	TP04-025 (GE-UT-311)	PIL-5E	J. Kent Montgomery	II	4/22/2005
60° Long.	UT-008	N/A	TP04-018 (GE-UT-300)	CAL-IIW2-017	Brad Dummer	III	4/22/2005
60° Long.	UT-007	N/A	TP04-018 (GE-UT-300)	PIL-5B	Brad Dummer	III	4/22/2005

Examination Results:

Ultrasonic examination results were acceptable to the requirements of ASME B&PV Code Section XI, 1989 Edition no Addenda, and Section XI, 1995 Edition with the 1996 Addenda as modified by the PDI program description and the Federal Register, Part II, Nuclear Regulatory Commission, 10 CFR Part 50 for Category B-D Reactor Pressure Vessel (RPV) Assembly Welds.

Manual scans from outside surface were performed in accordance with procedures TP04-018 Rev. 0 (GE-UT-300 V8) and TP04-029 Rev. 0 (GE-UT-311 V10).

Scan was restricted due to nozzle configuration.

No Indications were recorded.

Manual coverage = 70.6%

Examination results were compared to data report 95-E-263,265,267 from 1995 outage with No Change
 These examinations were performed under Work Order: N/A Change

This Summary and the following data sheets have been reviewed and accepted by the following personnel:

BMD III 4-24-05 [Signature] 6-III 4/28/05
 Prepared By: Level: Date: Utility Review: Date:
[Signature] 4/28/05
 ANII Review: Date:

RWP: 0065
Dose: 1 mr.

Page 1 of 7

Page 107/240



GE ENERGY, NUCLEAR

Ultrasonic Calibration and Examination Record RPV Components

Site/Unit: Pilgrim Nuclear Power Station / 1
Outage: RF-015

Data Report Number: PIL-R15-05-030 Linearity Sheet: L-006
Data Sheet Number: UT-008

Procedure: TP04-018 (GE-UT-300)

Rev.: R0 (V8)

DRR: N/A

Calibration Block: CAL-IIW2-017

<u>CS</u>	<u>N/A</u>	<u>4.0"</u>
Material	Size	Thickness
Initial Cal: <u>0945*</u>		Exam. Star: <u>1540</u>
Cal Check: <u>N/A</u>		Exam End: <u>1605</u>
Cal Check: <u>N/A</u>	<u>Ultrage II</u>	<u>01225</u>
Final Cal: <u>1445*</u>	Couplant:	Batch
<u>241890</u>	<u>68° F</u>	<u>68° F</u>
Thermometer	Initial Cal Temp.	Final Cal Temp:

DAC Construction

Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
1/4	0.6"	1X	80%	1.0"	.58"	2.8
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A

DAC 1X= 58 dB

Sweep 0-10 2.0" Depth

Note N/A dB difference between 3/8 and 5/8 Vee

Exam Data for Weld: RPV-N8-NV

NOZZLE TO VESSEL

Configuration:

<u>OD</u>	<u>72° F</u>
Exam Surface:	Component Temperature

Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
<u>Plate</u>	<u>I</u>	<u>72</u>	<u>NRI</u>	<u>60°</u>
<u>Plate CW/CCW</u>	<u>P</u>	<u>72</u>	<u>NRI</u>	<u>60°</u>

Search Unit Data

<u>Sigma</u>	<u>22BC-02005</u>	<u>2(1.1"x.62") Rect.</u>
Manufacturer:	Serial Number:	Size / Shape:
<u>0.65"</u>	<u>60°</u>	<u>58°</u>
Incident Point:	Nominal Angle:	Measured Angle:
<u>3.0 MHz</u>	<u>SDC-3</u>	<u>Long.</u>
Frequency:	Model:	Mode:

Search Unit Cable

<u>RG-174</u>	<u>12'</u>	<u>0</u>
Cable Type:	Length:	Connectors:

Instrument Settings

<u>Panometrics / Epoch 4</u>	<u>031540506</u>		
Manufacturer/Model:	Serial Number:		
<u>8.615 us</u>	<u>0.234 in./usec.</u>	<u>0.8 - 3.0 MHz</u>	
Delay/Zero:	Velocity:	Narrowband Filter:	
<u>Auto</u>	<u>Fullwave</u>	<u>4.0 in.</u>	<u>So / Mod</u>
Rep Rate:	Rectification:	Range:	Pulser:
<u>400 Ohms</u>	<u>0</u>	<u>3.03 MHz</u>	<u>Dual</u>
Damping:	Reject:	Frequency:	Mode:
<u>Off</u>	<u>Off</u>	<u>Off</u>	<u>Off</u>
DAC:	TVG:	CSC:	DGS:

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Acceptable Linearity performed: 4/15/2005

Comments: Cal/Exam Date is the date of examination. See coverage sheet for limitations.

Calibration for near surface examination. Exams performed a minimum of 14 dB above reference.

* Initial cal date: 4/22/05

* Final cal date: 4/23/05

Numerous spot indications seen but not recordable per procedure.

<u>BD</u>	<u>Bred Dummer</u>	<u>III</u>	<u>4/22/2005</u>
Initials:	Examiner	Level	Cal/Exam Date:
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Initials:	Examiner	Level	Date:
<u>[Signature]</u>	<u>[Signature]</u>	<u>II</u>	<u>4-24-05</u>
GE Reviewed By:	Level:	Date:	

<u>[Signature]</u>	<u>4/25/05</u>
Utility Reviewed By:	Date:
<u>[Signature]</u>	<u>4/24/05</u>
ANII Reviewed By:	Date:



GE ENERGY, NUCLEAR

Ultrasonic Calibration and Examination Record RPV Components

Site/Unit: Pilgrim Nuclear Power Station / 1

Data Report Number: PIL-R15-05-030 Linearity Sheet: L-006

Outage: RF-015

Data Sheet Number: UT-007

Procedure: TP04-018 (GE-UT-300)

Rev.: R0 (V8)

DRR: N/A

Calibration Block: PIL-5B

CS **Flat** **4.35"**
 Material Size Thickness
 Initial Cal: 0945' Exam Start 1540
 Cal Check: N/A Exam End 1605
 Cal Check: N/A **Ultragel II** 01225
 Final Cal: 1445' Couplant: Batch
 241890 **68° F** **68° F**
 Thermometer Initial Cal Temp. Final Cal Temp.

DAC Construction

Reflector	Hole Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A
N/A	N/A	1X	N/A	N/A	N/A	N/A
ID	<u>4.1"</u>	1X	<u>80%</u>	<u>7.8"</u>	<u>8.2"</u>	<u>4.1</u>
N/A	N/A	1X	N/A	N/A	N/A	N/A

DAC 1X= 62 dB
 Sweep 0-10 10.0" Depth
 Note N/A dB difference between 3/8 and 5/8 Vee

Search Unit Data

Siame **22BC-0200E** **2(1.1"x.62")/Rect.**
 Manufacturer: Serial Number: Size / Shape:
 0.65" 60° 59°
 Incident Point: Nominal Angle: Measured Angle:
 3.0 MHz **SDC-3** **Long.**
 Frequency: Model: Mode:

Search Unit Cable

RG-174 **12'** **Ø**
 Cable Type: Length: Connectors:

Instrument Settings

Panametrics / Epoch 4 **031540506**
 Manufacturer/Model: Serial Number:
9.615 us 0.234 in./usec. 0.8 - 3.0 MHz
 Delay/Zero: Velocity: Narrowband Filter:
Auto **Fullwave** **20.0 in.** **Sa. / Mod**
 Rep Rate: Rectification: Range: Pulsar:
400 Ohms Ø 3.03 MHz **Dual**
 Damping: Reject: Frequency: Mode:
Off: **Off:** **Off:** **Off:**
 DAC: TVG: CSC: DGS:

Exam Data for Weld: RPV-N8-NV

NOZZLE TO VESSEL

Configuration:

ØØ **72° F**
 Exam Surface: Component Temperature

Weld Examination Area:	Exam Access	Scan dB	Recordable Indications	Exam Angle
<u>Plate</u>	<u>I</u>	<u>68</u>	<u>NRI</u>	<u>60°</u>
<u>Plate CW/CCW</u>	<u>P</u>	<u>68</u>	<u>NRI</u>	<u>60°</u>

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Acceptable Linearity performed: 4/15/2005

Comments: Cal/Exam Date is the date of examination. See coverage sheet for limitations.
 Calibration for full volume examination. Exams performed to maintain a 10% - 20% FSH clad roll.
 * Initial cal date: 4/22/05
 * Final cal date: 4/23/05
 Numerous spot indications seen but not recordable per procedure.

BD **Brad Dummer** **III** 4/22/2005
 Initials: Examiner Level Cal/Exam Date:
 N/A N/A
 Initials: Examiner Level Date:
 [Signature] III 4-24-05
 GE Reviewed By: Level: Date:

[Signature] 4/25/05
 Utility Reviewed By: Date:
[Signature] 4/25/05
 ANII Reviewed By: Date:

Page 109/240



GE ENERGY, NUCLEAR

Ultrasonic Calibration and Examination Record Inner Radius Examinations

Site/Unit: Pilgrim Nuclear Power Station / 1
Outage: RF-015

Data Report Number: PIL-R15-05-030 Linearity Sheet: L-004
Data Sheet Number: UT-025

Procedure: TP04-029 (GE-UT-311)

Rev: R0 (V10) DRR: N/A

Calibration Data for Block: PIL-5B

<u>CS</u> Material	<u>Flat</u> Size	<u>4.35"</u> Thickness
Initial Cal: <u>1030°</u>	Exam Start	<u>14:48</u>
Cal Check: <u>N/A</u>	Exam End	<u>15:30</u>
Cal Check: <u>N/A</u>	<u>Ultracel II</u> Couplant:	<u>01225</u> Batch
Final Cal: <u>1405°</u>	<u>241890</u> Thermometer	<u>68° F</u> Initial Cal Temp.
		<u>68° F</u> Final Cal Temp:

DAC Construction

Side	Depth	Gain @ 1X	Max Amp	"W" Dim.	Sweep	Screen Div.
ID	<u>4.1"</u>	1X	<u>80%</u>	<u>7.8"</u>	<u>9.18"</u>	<u>4.6</u>
N/A	N/A	1X	N/A	N/A	N/A	N/A

DAC @ 1X 41 dB

Sweep 0-10 20 Metal Path

Acceptable Linearity performed: 4/15/2005

Search Unit Data

<u>KBA</u> Manufacturer:	<u>010HXM</u> Serial No.:	<u>0.5"x1.0"/Rect.</u> Size/Shape:
<u>0.75 in.</u>	<u>60°</u>	<u>61°</u>
Incident Point:	Nominal Angle:	Measured Angle:
<u>2.25 MHz</u> Frequency:	<u>113-892-600</u> Model:	<u>Shear</u> Mode:

Search Unit Cable

<u>BG-174</u> Cable Type:	<u>12'</u> Length:	<u>0</u> Connectors:
------------------------------	-----------------------	-------------------------

Instrument Settings

<u>Panametrics / Epoch 4</u> Manufacturer/Model:	<u>031574111</u> Serial No.:
---	---------------------------------

<u>14.27 us</u> Zero:	<u>0.126 in / usec</u> Velocity:	<u>0.8 - 3.0 MHz</u> Narrowband Filter:
<u>Auto</u> Rep Rate:	<u>Fullwave</u> Rectification:	<u>20.0 in.</u> Range:
<u>400 Ohms</u> Damping:	<u>0</u> Reject:	<u>2.0 MHz</u> Frequency:
<u>Off</u> DAC:	<u>Off</u> TVG:	<u>Off</u> CSC:
		<u>Off</u> DGS:

Exam Data for Component: RPV-N8-NV NOZZLE TO VESSEL

Configuration:

<u>OD</u> Exam Surface:	<u>70° F</u> Component Temp.				
Examination Area	Exam Angle	Rotation Angle	Wedge S/N	Scan Recordable dB	Indications
<u>0-5"</u>	<u>60°</u>	<u>32°-56°</u>	<u>N/A</u>	<u>55</u>	<u>NRI</u>

Calibration Verification

Field Simulator Block S/N: N/A

Reflector	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Amplitude	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Gain (dB)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep (SD)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

Comments: Cal/Exam Date is the date of initial calibration. See coverage sheet for limitations.

Exams performed to maintain a 5% FSH ID roll.
Scanned CW and CCW.
Calibration sweep is 20 metal path, examination range setting is 10.
Calibration for nozzle to vessel weld.
* Initial Cal: 4/22/2005
* Final Cal: 4/23/2005

JKM J. Kent Montgomery II 4/22/2005
Initials: Examiner: Level Cal/Exam Date:

Scott L. II 4/22/05
Utility Reviewed By: Date:

B/M III 4-24-05
GE Reviewed By: Level: Date:

Carl 4/24/05
ANII Reviewed By: Date:

MANUAL DETECTION NOZZLE INNER RADIUS AND BORE INSPECTION REQUIREMENTS							
PLANT		Pilgrim					
PREPARED BY		S.C. MORTENSON			DATE 01/10/05		
NOZZLE EXAM ZONE	SCAN SURFACE	SCAN AREA	BEAM ANGLE	ROTATION ANGLE	WEDGE RADIUS	MAX MP	FREQ
RECIRC OUTLET							
N/V Weld (M)	PLATE	0 - 3.0	45.0°	± 70° - 85°	FLAT	10.2"	1 MHz
N/V Weld/Zone 1 (M)	ODBR	50° - 90°	43.0°	83.0°	6.6"	15.9"	1 MHz
Zone 1 (M)	ODBR	35° - 90°	32.9°	82.2°	6.6"	12.9"	1 MHz
Zone 2a (M)	ODBR	35° - 90°	41.2°	48.9°	6.6"	13.4"	1 MHz
RECIRC INLET							
N/V Weld (M)	PLATE	0 - 6.0"	60.0°	± 35° - 65°	FLAT	15.6"	1 MHz
Zone 1 (M)	PLATE	0 - 8.0"	70.0°	± 30°	FLAT	28.0"	1 MHz
Zone 2a (M)	ODBR	55° - 90°	64.8°	20.3°	6.1"	12.2"	1 MHz
TOP HEAD VENT							
N/V (M)	PLATE	0 - 5.0"	60.0°	32° - 56°	FLAT	6.8"	2.25 MHz
ZONE 1-2A (M)	PLATE	0 - 7.0"	70.0°	±25°	FLAT	9.7"	2.25 MHz
ZONE 2A (M)	PLATE	0 - 8.0"	80.0°	±25°	FLAT	12.9"	2.25 MHz
TOP HEAD SPARE							
N/V (M)	PLATE	0 - 8.0"	45.0°	15° - 85°	FLAT	4.6"	2.25 MHz
N/V (M)	PLATE	0 - 5.0"	60.0°	15° - 85°	FLAT	6.8"	2.25 MHz
ZONE 1 (M)	PLATE	0 - 4.0"	60.0°	±58°	FLAT	6.8"	2.25 MHz
ZONE 1-2A (M)	PLATE	0 - 7.0"	70.0°	±30°	FLAT	10.8"	2.25 MHz
ZONE 2A (M)	PLATE	0 - 9.0"	80.0°	±25°	FLAT	17.9"	2.25 MHz

W-071
W-070
W-069

W-072

NOTES:	*	DESIGN / (FIXTURE) ROTATION FOR 3.0° PKG OFFSET
	#	DESIGN / (FIXTURE) ROTATION FOR 1.45° PKG OFFSET
	**	WEDGE / (FIXTURE) ROTATION ANGLE FOR 2.5° OFFSET
	***	DESIGN / (FIXTURE) ROTATION FOR 1.5° PKG OFFSET
	(M)	MANUAL

Questions on this NIR requirements sheet shall be directed to S.C. Mortenson @ 704 948-0253

[Signature] 4/28/05

Pilgrim - RFO15
Weld RPV-N8-NV Top Head Vent
Spring 2005

Weld Length = 360. Exam Volume = 25.3		CODE CROSS-SECTIONAL AREA		TOTAL CODE COVERAGE		
		Required Exam Area Sq. In.	Area Scanned Manual	Percent of Area Manual	Weld Length Manual	Percent Manual
60° NS T-Scan	A	8.2	3.5	13.8%	360	6.9%
60° S6 T-Scan	A	13.8	13.4	53.0%	360	26.5%
60° S4 / IRS Scan	A	3.3	3.3	13.0%	360	6.5%
60° NS P-Scan	A	8.2	2.9	11.5%	360	5.7%
60° S6 P-Scan	A	25.6	9.3	36.8%	360	18.4%
60° IRS P-Scan	A	3.3	3.3	13.0%	360	6.5%

% Total Composite Coverage = 70.5%

Comments: A - Examined 360°. Scanning limited due to nozzle configuration.

Note - Rounding methods may affect calculated values.


[Signature] 4/28/05

Pilgrim Weld RPV-N8-NV Top Head Vent

60° NS Exam Volume = 8.2 Sq. In.
60° FV Exam Volume = 13.8 Sq. In.
60° Inner 15% Exam Volume = 3.3 Sq. In.

60° NS T-Scan achieved = 3.5 Sq. In.
60° FV T-Scan achieved = 13.4 Sq. In.
60° Inner 15% T-Scan achieved = 3.3 Sq. In.

60° NS P-Scan achieved = 2.9 Sq. In.
60° FV P-Scan achieved = 9.3 Sq. In.
60° Inner 15% P-Scan achieved = 3.3 Sq. In.





GE ENERGY, NUCLEAR

EXAMINATION SUMMARY SHEET

Report No.:
APR-002

Site: Pilgrim Nuclear Power Station Component ID: 14-A-10A
 Outage: RF-015 VALVE TO PIPE
 System CS ASME Cat.: B-F ASME Item B5.10 Aug Req IGSCC D

Exame Performed	Data Sheet	Cal Sheet	Procedure	Calibration Block	Examination Personnel	Cert Level	Date
45° Shear	UT-075	N/A	ENN-NDE-9.10	PIL-115	Randy Linden	III	4/28/2005
45° RL	UT-076	N/A	ENN-NDE-9.10	PIL-115	Randy Linden	III	4/28/2005
60° Long.	UT-077	N/A	ENN-NDE-9.10	PIL-115	Randy Linden	III	4/28/2005

Examination Results:

During the manual ultrasonic examination of the above referenced dissimilar metal weld, no indications associated with IGSCC were recorded utilizing a 45° shear wave, 45° and 60° refracted longitudinal wave search units.

The outside surface weld crown did not meet procedure requirements for 360° due to the valve configuration.

22.9% procedural coverage obtained.

37.1% code coverage obtained.

Previous manual reports and drawings were reviewed prior to this summary.

Examination results were compared to data report 99-E-440 from 1999 outage with No Change

These examinations were performed under Work Order: 03116843 Change

This Summary and the following data sheets have been reviewed and accepted by the following personnel:

Prepared By: [Signature] Level: II Date: 5-2-05
 Utility Review: [Signature] Date: 5-2-05
 ANII Review: [Signature] Date: 5/2/05

RWP: 0080
Dose: 133 mr.

Page 1 of 8

Page 114/240



GE ENERGY, NUCLEAR

Wall Thickness Profile Sheet

Site: Pilgrim Nuclear Power Station Unit: 1

Report No.:

Project: RF-015

APR-002

System: CS

Component ID Number: 14-A-10A


Position	0°	90°	180°	270°
1	N/A	N/A	N/A	N/A
2	N/A	N/A	N/A	N/A
3	0.583	N/A	N/A	N/A
4	0.585	N/A	N/A	N/A
5	0.586	N/A	N/A </td <td>N/A</td>	N/A

Crown Height: 0.1

Crown Width: 0.9"

Nominal Diameter: 10.0"

Weld Length: 34.0"



VALVE
UPST Component:

PIPE
DNST Component:

FLOW

14-A-10A



Valve

Exam Volume

Pipe

Thickness obtained from previous data

Bandy Linden

Initials: Examiner:

III 4/20/2005

Level: Date:

W. J. Kelly

GE Reviewed By:

III 5-2-05

Level: Date:

W. J. Kelly

Utility Review:

5-2-05

Date:

Carl Hansen

ANII Review:

Date:

Page 115/240



GE ENERGY, NUCLEAR

Wall Thickness Profile Sheet

Site: Pilgrim Nuclear Power Station Unit: 1

Report No.:

Project: RF-015

APR-002

System: CS

Component ID Number: 14-A-10A



Position	0°	90°	180°	270°
1	N/A	N/A	N/A	N/A
2	N/A	N/A	N/A	N/A
3	0.683	N/A	N/A	N/A
4	0.585	N/A	N/A	N/A
5	0.586	N/A	N/A	N/A

Crown Height: 0.1

Crown Width: 0.8"

Nominal Diameter: 10.0"

Weld Length: 34.0"



Page 116/240



Randy Linden III 4/28/2005

Initials: Examiner: Level: Date:



III 5-2-05

GE Reviewed By: Level: Date:



UTILITY 5-2-05

Utility Review: Date:



ANII Review: 5/4/05

Date:



GE ENERGY.NUCLEAR

Ultrasonic Calibration and Examination Record Manual Piping and Components

Site/Unit: Pilgrim Nuclear Power Station / 1
Outage: RF-015

Report Number: APR-002
Data Sheet Number: UT-075
Linearity Sheet: L-003

Calibration Data for Block: PIL-115

Procedure: ENN-NDE-9.10

Ver / Rev: 0 DRR: N/A

CS	10"	0.594"	Calibration	Cal Time
Material	Size	Thick	Initial Cal:	<u>0740</u>
<u>Ultracel II</u>	<u>01225</u>		Cal Check:	<u>0817</u>
Couplant:	Couplant batch		Cal Check:	<u>1010</u>
<u>241890</u>	<u>68°F</u>		Final Cal:	<u>1103</u>
Thermometer S/N	Cal Temp.			

Search Unit Data

KBA 010CJP 0.50"/Round
 Manufacturer: Serial Number Size/Shape:
0.55 in. 45° 45°
 Incident Point: Nominal Angle: Measured Angle:
2.25 MHz Como-G Shear 1
 Frequency: Style: Mode: Elements:

Search Unit Cable

RG-174 6' 0
 Cable Type: Length: Connectors:

Instrument Settings

Panametrics / Epoch 4 031573611
 Manufacturer/Model: Serial Number:
6.295 us 0.128 in./usec. 0.8 - 3.0 MHz
 Zero: Velocity: Narrowband Filter:
Auto Fullwave 1.5 in So./Max
 Rep Rate: Rectification: Range: Pulsar/Energy:
400 Ohms Off 2.0 MHz P/E
 Damping: Reject: Frequency: Mode:

DAC Construction

Scan Direction Ax
 Cal Reflector ID Notch
 Signal Amplitude 80%
 Signal Sweep: 5.9 Dlx
 Signal dB: 9.0 dB
 Sweep 0-10 = 1.5 in Metal Path

Calibration Verification

Field Simulator Block S/N: CAL-1W2-017

Reflector	<u>0.60"</u>	<u>N/A</u>
Amplitude	<u>40%</u>	<u>N/A</u>
Gain (dB)	<u>9 dB</u>	<u>N/A</u>
Sweep (SD)	<u>3.8</u>	<u>N/A</u>

Acceptable Linearity performed : 4/15/2005

Exam Comments / Limitations:

Scanned downstream side only.
Did not scan on weld due to configuration.
Maintained a 5% to 20% ID roll during examination.

Exam Data for Weld: 14-A-10A

VALVE TO PIPE

Configuration:

OD 85°F 241890
 Exam Surface: Exam Temp. Exam Thermometer

Axial Circ	UPST DNST	Scan dB	Recordable Indications	Exam Angle
<u>Axial</u>	<u>DNST</u>	<u>23</u>	<u>NBI</u>	<u>45°</u>
<u>Circ</u>	<u>DNST</u>	<u>23</u>	<u>NBI</u>	<u>45°</u>

Exam Start: 0806 Exam End: 0940

(12)

Randy Linden

Initials: Examiner:

Level: III

N/A

Initials: Examiner 2:

Level: N/A

Initial Cal/Exam Date: 4/28/2005

[Signature]
GE Reviewed By:

III 5-2-05

Level: Date:

[Signature]
Utility Review:

5-2-05

Date:

[Signature]
ANII Review:

5/2/05

Date:

Page 4 of 8

Page 117/240



GE ENERGY, NUCLEAR

Ultrasonic Calibration and Examination Record
Manual Piping and Components

Site/Unit: Pilgrim Nuclear Power Station / 1
Outage: RF-015

Report Number: APR-002
Data Sheet Number: UT-076
Linearity Sheet: L-003

Calibration Data for Block: PIL-115

Procedure: ENN-NDE-9.10

Ver / Rev: 0 DRR: N/A

CS	10"	0.564"	Calibration	Cal Time
Material	Size	Thick	Initial Cal:	0750
<u>Ultracel II</u>	<u>01225</u>		Cal Check:	0905
Couplant:	Couplant batch		Cal Check:	0855
<u>241890</u>	<u>68°F</u>		Final Cal:	1102
Thermometer S/N	Cal Temp.			

Search Unit Data

RTD 09-177 2(7x10) mm/Rect.
 Manufacturer: Serial Number Size/Shape:
0.32 in. 45° 44°
 Incident Point: Nominal Angle: Measured Angle:
2.0 Mhz TBL2-Aust RL 2
 Frequency: Style: Mode: Elements:

Search Unit Cable

RG-174 6' 0
 Cable Type: Length: Connectors:

Instrument Settings

Parametrics / Epoch 4 091573611
 Manufacturer/Model: Serial Number:
7.535 in 0.236 in./Assoc. 0.8-3.0
 Zero: Velocity: Narrowband Filter:
Auto Fullwave 2.0 in Sg./Max
 Rep Rate: Rectification: Range: Pulsar/Energy:
400 Ohms Off 2.0 Mhz Dual
 Damping: Reject: Frequency: Mode:

DAC Construction

Scan Direction Ax
 Cal Reflector ID Notch
 Signal Amplitude 80%
 Signal Sweep: 5.9 Div
 Signal dB: 37.9 dB
 Sweep 0-10 = 1.5 in Metal Path

Calibration Verification

Field Simulator Block S/N: CAL-ITW2-017

Reflector	<u>0.60"</u>	<u>N/A</u>
Amplitude	<u>80%</u>	<u>N/A</u>
Gain (dB)	<u>20.3</u>	<u>N/A</u>
Sweep (SD)	<u>5.6</u>	<u>N/A</u>

Acceptable Linearity performed : 4/15/2005

Exam Comments / Limitations:

Scanned downstream side only.
Did not scan on weld due to configuration.
Maintained a 20% ID roll during examination.

Exam Data for Weld: 14-A-10A

VALVE TO PIPE

Configuration:

00 85°F 241890
 Exam Surface: Exam Temp. Exam Thermometer

Axial Circ	UPST DNST	Scan dB	Recordable Indications	Exam Angle
<u>Axial</u>	<u>DNST</u>	<u>43.9</u>	<u>NFI</u>	<u>45°</u>
<u>Circ</u>	<u>DNST</u>	<u>43.9</u>	<u>NFI</u>	<u>45°</u>

Exam Start: 0906 Exam End: 0940

Randy Linden III
 Initials: Examiner: Level:
N/A N/A
 Initials: Examiner 2: Level:
 Initial Cal/Exam Date: 4/28/2005

[Signature] III 5-2-05
 GE Reviewed By: Level: Date:
[Signature] UT/WT/19 5-2-05
 Utility Review: Date:
[Signature] 5/2/05
 ANII Review: Date:



GE ENERGY.NUCLEAR

Ultrasonic Calibration and Examination Record Manual Piping and Components

Site/Unit: Pilgrim Nuclear Power Station / 1
Outage: RF-015

Report Number: APR-002
Data Sheet Number: UT-077
Linearity Sheet: L-003

Calibration Data for Block: PIL-115

Procedure: ENN-NDE-9.10

Ver / Rev: 0 DRR: N/A

CS	10"	0.594"	Calibrator:	Cal Time
Material	Size	Thick	Initial Cal:	0800
<u>Ultracel II</u>	<u>01225</u>		Cal Check:	0930
Couplant:	Couplant batch		Cal Check:	N/A
<u>241890</u>	<u>88° F</u>		Final Cal:	1100
Thermometer S/N	Cal Temp.			

Search Unit Data		
<u>HTP</u>	<u>03-178</u>	<u>2(7x10) mm/Rect.</u>
Manufacturer:	Serial Number	Size/Shape:
<u>0.32 in.</u>	<u>60°</u>	<u>60°</u>
Incident Point:	Nominal Angle:	Measured Angle:
<u>2.0 MHz</u>	<u>TBL2-Aust</u>	<u>Long</u>
Frequency:	Style:	Mode:
		<u>2</u>
		Elements:

DAC Construction

Scan Direction: Ax
 Cal Reflector: ID Notch
 Signal Amplitude: 80%
 Signal Sweep: 5.9 Div
 Signal dB: 47.2 dB
 Sweep 0-10 = 2.0 in Metal Path

Search Unit Cable		
<u>RG-174</u>	<u>6'</u>	<u>0</u>
Cable Type:	Length:	Connectors:

Calibration Verification

Field Simulator Block S/N: CAL-FW2-017

Reflector	<u>0.60"</u>	<u>N/A</u>
Amplitude	<u>80%</u>	<u>N/A</u>
Gain (dB)	<u>42.4</u>	<u>N/A</u>
Sweep (SD)	<u>6.0</u>	<u>N/A</u>

Acceptable Linearity performed: 4/15/2005

Instrument Settings

<u>Panametrics / Epoch 4</u>	<u>031573611</u>
Manufacturer/Model:	Serial Number:
<u>6.155 MHz</u>	<u>0.222 in./usec.</u>
Zero:	Velocity:
<u>Auto</u>	<u>Fullwave</u>
Rep Rate:	Rectification:
<u>2.0 in</u>	<u>Sa / Max</u>
Range:	Pulsar/Energy:
<u>400 Ohms</u>	<u>Off</u>
Damping:	Reject:
<u>2.0 MHz</u>	<u>Dual</u>
Frequency:	Mode:

Exam Data for Weld: 14-A-10A

VALVE TO PIPE.
 Configuration:

00 85° F 241890
 Exam Surface: Exam Temp. Exam Thermometer

Exam Comments / Limitations:

Scanned downstream side only.
 Did not scan on weld due to configuration.
 Maintained a 20-30% ID roll during examination.

Axial Circ	UPST DNST	Scan dB	Recordable Indications	Exam Angle
<u>Axial</u>	<u>DNST</u>	<u>47.2</u>	<u>NFI</u>	<u>60°</u>
<u>Circ</u>	<u>DNST</u>	<u>47.2</u>	<u>NFI</u>	<u>60°</u>

Exam Start: 0806 Exam End: 0940

(RL) Randy Linden III
 Initials: Examiner: Level:

 Initials: Examiner 2: N/A N/A
 Level:

Initial Cal/Exam Date: 4/28/2005

(M) M. M. M. III 5-2-05
 GE Reviewed By: Level: Date:

(L) L. L. L. III 5-2-05
 Utility Review: Date:

(C) C. C. C. 5/2/05
 ANII Review: Date:

Page 6 of 8

Page 119/240



GE ENERGY, NUCLEAR

EXAMINATION SUMMARY SHEET

Report No.:
APR-005

Site: Pilgrim Nuclear Power Station Component ID: 14-B-10A
 Outage: RF-015 VALVE TO PIPE
 System CS ASME Cat.: B-F ASME Item B5.10 Aug Req IGSCC D

Exams Performed	Data Sheet	Cal Sheet	Procedure	Calibration Block	Examination Personnel	Cert Level	Date
45° Shear	UT-072	N/A	ENN-NDE-9.10	PIL-115	Randy Linden	III	4/28/2005
45° RL	UT-073	N/A	ENN-NDE-9.10	PIL-115	Randy Linden	III	4/28/2005
60° Long.	UT-074	N/A	ENN-NDE-9.10	PIL-115	Randy Linden	III	4/28/2005

Examination Results:

During the manual ultrasonic examination of the above referenced dissimilar metal weld, no indications associated with IGSCC were recorded utilizing a 45° shear wave, 45° and 60° refracted longitudinal wave search units.

The outside surface weld crown did not meet procedure requirements for 360° due to the valve configuration and shrinkage at the weld toe.

10.1% procedural coverage obtained.

22.1% code coverage obtained.

Previous manual reports and drawings were reviewed prior to this summary.

Examination results were compared to data report 99-E-441 from 1999 outage with No Change
 These examinations were performed under Work Order: 03118643 Change

This Summary and the following data sheets have been reviewed and accepted by the following personnel:

Prepared By: [Signature] Level: III Date: 5-2-05
 Utility Review: [Signature] Date: 5-2-05
 ANII Review: [Signature] Date: 5/3/05

RWP: 0080
Dose: 133 mr.

Page 1 of 6



GE ENERGY, NUCLEAR

Wall Thickness Profile Sheet

Site: Pilgrim Nuclear Power Station Unit: 1

Report No.:

Project: RF-015


APR-005

System: CS


Component ID Number: 14-B-10A

Position	0°	90°	180°	270°
1	N/A	N/A	N/A	N/A
2	N/A	N/A	N/A	N/A
3	0.728	N/A	N/A	N/A
4	0.545	N/A	N/A	N/A
5	0.557	N/A	N/A </td <td>N/A</td>	N/A

Crown Height: 0.1
 Crown Width: 1.0"
 Nominal Diameter: 10.0"
 Weld Length: 24.0"



14-B-10A



Valve Exam Volume Pipe

Thickness obtained from previous data

Page 121/240

Max For Randy Linden

Level: III Date: 4/20/2005

Initials: Examiner:

Level: Date:

GE Reviewed By: [Signature]

Level: III Date: 5-2-05

Utility Review: [Signature]

Date: 5-2-05

ANII Review: [Signature]

Date: 5/3/05



GE ENERGY, NUCLEAR

Wall Thickness Profile Sheet

Site: Plaquemine Nuclear Power Station Unit: 1

Report No.:

Project: RF-018



APR-003

System: CS

Component ID Number: 14-B-10A

Position	0°	90°	180°	270°
1	N/A	N/A	N/A	N/A
2	N/A	N/A	N/A	N/A
3	0.728	N/A	N/A	N/A
4	0.545	N/A	N/A	N/A
5	0.557	N/A	N/A </td <td>N/A</td>	N/A

Crown Height: 0.1
 Crown Width: 1.0"
 Nominal Diameter: 10.0"
 Weld Length: 34.0"



Randy Linden
 Initials: Examiner: RL Level: III Date: 4/28/2005

Mike Kelly
 GE Reviewed By: MLK Level: III Date: 5-2-05

Carl Herman
 Utility Review: CH Level: III Date: 5-2-05

Carl Herman
 ANII Review: CH Date: 5/2/05

Page 1a2/140



GE ENERGY NUCLEAR

Ultrasonic Calibration and Examination Record Manual Piping and Components

Site/Unit: Pilgrim Nuclear Power Station / 1
Outage: RF-015

Report Number: APR-005
Data Sheet Number: UT-072
Linearity Sheet: L-003

Calibration Data for Block: PIL-115

Procedure: ENN-NDE-9.10

Ver / Rev: 0 DRR: N/A

CS	10"	0.594"	Calibrator:	Cal Time:
Material	Size	Thick	Initial Cal:	0740
<u>Ultracel II</u>	<u>01225</u>		Cal Check:	0917
Couplant:	Couplant batch		Cal Check:	1010
<u>241890</u>	<u>58°F</u>		Final Cal:	1103
Thermometer S/N	Cal Temp.			

Search Unit Data

KBA 010CJP 0.50"/Round
 Manufacturer: Serial Number Size/Shape:
0.55 in. 45° 45°
 Incident Point: Nominal Angle: Measured Angle:
2.25 MHz Compo-G Shear 1
 Frequency: Style: Mode: Elements:

Search Unit Cable

RG-174 6' 0
 Cable Type: Length: Connectors:

Instrument Settings

Panometrics / Epoch 4 031573611
 Manufacturer/Model: Serial Number:
0.295 us 0.128 in./ussec 0.8 - 3.0 MHz
 Zero: Velocity: Narrowband Filter:
Auto Fullwave 1.5 in Sq./Max
 Rep Rate: Rectification: Range: Pulsar/Energy:
400 Ohms Off 2.0 MHz P/E
 Damping: Reject: Frequency: Mode:

DAC Construction

Scan Direction Ax
 Cal Reflector ID Notch
 Signal Amplitude 80%
 Signal Sweep: 5.9 Div
 Signal dB: 9.0 dB
 Sweep 0-10 = 1.5 in Metal Path

Calibration Verification

Field Simulator Block S/N: CAL-1W2-017

Reflector	<u>0.60"</u>	<u>N/A</u>
Amplitude	<u>40%</u>	<u>N/A</u>
Gain (dB)	<u>9 dB</u>	<u>N/A</u>
Sweep (SD)	<u>5.8</u>	<u>N/A</u>

Acceptable Linearity performed : 4/15/2005

Exam Comments / Limitations:

Scanned downstream side only.
 Did not scan on weld due to configuration.
 Lift-off signals seen due to weld shrinkage.
 Maintained a 5% to 20% ID roll during examination.

Exam Data for Weld: 14-B-10A

VALVE TO PIPE

Configuration:

00 85°F 241890
 Exam Surface: Exam Temp. Exam Thermometer

Axial Circ	UPST DNST	Scan dB	Recordable Indications	Exam Angle
<u>Axial</u>	<u>DNST</u>	<u>23</u>	<u>NRI</u>	<u>45°</u>
<u>Circ</u>	<u>DNST</u>	<u>23</u>	<u>NRI</u>	<u>45°</u>

Exam Start: 0945 Exam End: 1025

RL

Randy Linden

Initials: Examiner:

Level: III

N/A

Initials: Examiner 2:

Level: N/A

Initial Cal/Exam Date: 4/28/2005

W. Kaley

GE Reviewed By:

III 5-2-05

Level: Date:

UT Lvl. 19

Utility Reviewer:

5-02-05

Date:

Chris Hanson

ANII Review:

5/3/05

Date:

Page 4 of 6

Page 123/240



GE ENERGY NUCLEAR

Ultrasonic Calibration and Examination Record Manual Piping and Components

Site/Unit: Pilgrim Nuclear Power Station / 1
Outage: RF-015

Report Number: APR-005
Data Sheet Number: UT-073
Linearity Sheet: L-003

Calibration Data for Block: PIL-111

Procedure: ENN-NDE-9.10

Ver / Rev: 0 DRR: N/A

CS	10"	0.594"	Calibration:	Cal Time
Material	Size	Thick	Initial Cal:	0750
<u>Ultracal II</u>	<u>01225</u>		Cal Check:	0905
Couplant:	Couplant batch		Cal Check:	0955
<u>241890</u>	<u>88° F</u>		Final Cal:	1102
Thermometer S/N	Cal Temp.			

Search Unit Data

Manufacturer:	<u>RTD</u>	<u>03-177</u>	<u>2(7x10) mm/Rect.</u>
Serial Number:			
Size/Shape:			
Incident Point:	<u>0.32 in.</u>	<u>45°</u>	<u>44°</u>
Nominal Angle:			Measured Angle:
Frequency:	<u>2.0 MHz</u>	<u>TRI-2-Aux</u>	<u>RL</u>
Style:			Mode:
			Elements:
			<u>2</u>

DAC Construction

Scan Direction: Ax
 Cal Reflector: ID Notch
 Signal Amplitude: 80%
 Signal Sweep: 5.9 Div
 Signal dB: 37.9 dB
 Sweep 0-10 = 1.5 in Metal Path

Search Unit Cable

Cable Type: RG-174 Length: 6' Connectors: 0

Calibration Verification

Field Simulator Block S/N: CAL-HW2-017

Reflector	<u>0.60"</u>	<u>N/A</u>
Amplitude	<u>80%</u>	<u>N/A</u>
Gain (dB)	<u>30.3</u>	<u>N/A</u>
Sweep (SD)	<u>5.6</u>	<u>N/A</u>

Acceptable Linearity performed: 4/15/2005

Instrument Settings

Manufacturer/Model: Panametrics / Epoch 4 Serial Number: 031573811

Zero: 7.525 in Velocity: 0.238 in/ussec Narrowband Filter: 0.8 - 3.0

Rep Rate: Auto Rectification: Fullwave Range: 2.0 in Pulsar/Energy: So / Max

Damping: 400 Ohms Reject: Off Frequency: 2.0 MHz Mode: Dual

Exam Data for Weld: 14-B-10A

VALVE TO PIPE
Configuration:

Exam Surface: 02 Exam Temp: 85° F Exam Thermometer: 241890

Exam Comments / Limitations:

Scanned downstream side only.
 Did not scan on weld due to configuration.
 Lift-off signals seen due to weld shrinkage.
 Maintained a 20% ID roll during examination.

Axial Circ	UPST DNST	Scan dB	Recordable Indications	Exam Angle
<u>Axial</u>	<u>DNST</u>	<u>43.9</u>	<u>NRI</u>	<u>45°</u>
<u>Circ</u>	<u>DNST</u>	<u>43.9</u>	<u>NRI</u>	<u>45°</u>

Exam Start: 0945 Exam End: 1025

⑩ Randy Linden III
 Initials: Examiner: Level:

N/A N/A
 Initials: Examiner 2: Level:

Initial Cal/Exam Date: 4/28/2005

[Signature] II 5-2-05
 GE Reviewed By: Level: Date:

[Signature] UT L.L.T. 5-2-05
 Utility Review: Date:

[Signature] 5/2/05
 ANII Review: Date:



GE ENERGY, NUCLEAR

Ultrasonic Calibration and Examination Record
Manual Piping and Components

Site/Unit: Pilgrim Nuclear Power Station / 1
Outage: RF-015

Report Number: APR-005
Data Sheet Number: UT-074
Linearity Sheet: L-003

Calibration Data for Block: PIL-115

Procedure: ENN-NDE-9.10

Ver / Rev: 2 DRR: N/A

CS	10"	0.594"	Calibration	Cal Time
Material	Size	Thick	Initial Cal:	<u>0800</u>
<u>Ultrasol II</u>	<u>01225</u>		Cal Check:	<u>0930</u>
Couplant:	Couplant batch		Cal Check:	<u>N/A</u>
<u>241890</u>	<u>68°F</u>		Final Cal:	<u>1100</u>
Thermometer S/N	Cal Temp.			

Search Unit Data

RTD 03-179 27x10 mm/Rect.
 Manufacturer: Serial Number Size/Shape:
0.32 in. 60° 60°
 Incident Point: Nominal Angle: Measured Angle:
2.0 MHz TRL2-AVE1 Long 2
 Frequency: Style: Mode: Elements:

Search Unit Cable

RQ-174 6' 0
 Cable Type: Length: Connectors:

Instrument Settings

Panametrix / Epoch 4 031573611
 Manufacturer/Model: Serial Number:
6.155 MHz 0.222 in./sec. 0.8-3.0
 Zero: Velocity: Narrowband Filter:
Auto Fullwave 2.0 in Sq./Max
 Rep Rate: Rectification: Range: Pulsar/Energy:
400 Ohms Off 2.0 MHz Dual
 Damping: Reject: Frequency: Mode:

DAC Construction

Scan Direction: Ax
 Cal Reflector: ID Notch
 Signal Amplitude: 80%
 Signal Sweep: 5.9 Dtv
 Signal dB: 47.2 dB
 Sweep 0-10 = 2.0 in Metal Path

Calibration Verification

Field Simulator Block S/N: CAL-NW2-017

Reflector	<u>0.80"</u>	<u>N/A</u>
Amplitude	<u>80%</u>	<u>N/A</u>
Gain (dB)	<u>42.1</u>	<u>N/A</u>
Sweep (SD)	<u>6.0</u>	<u>N/A</u>

Acceptable Linearity performed: 4/15/2005

Exam Comments / Limitations:

Scanned downstream side only.
 Did not scan on weld due to configuration.
 *Weld shrinkage caused Ehoff signals, causing geometric reflectors.
 Maintained a 20-30% ID roll during examination.

Exam Data for Weld: 14-B-10A

VALVE TO PIPE

Configuration:

OD 85°F 241890
 Exam Surface: Exam Temp. Exam Thermometer

Axial Circ	UPST DNST	Scan dB	Recordable Indications	Exam Angle
<u>Axial</u>	<u>DNST</u>	<u>47.2</u>	<u>NBI</u>	<u>60°</u>
<u>Circ</u>	<u>DNST</u>	<u>47.2</u>	<u>NBI</u>	<u>60°</u>

Exam Start: 0945 Exam End: 1025

RL

Randy Linden

III

Initials: Examiner:

Level:

N/A

N/A

Initials: Examiner 2:

Level:

Initial Cal/Exam Date: 4/28/2005

[Signature]
GE Reviewed By:

III 5-2-05
Level: Date:

[Signature] MT Lvl. II
Utility Review:

5-2-05
Date:

[Signature]
ANII Review:

5/3/05
Date:

Page 6 of 6



GE ENERGY, NUCLEAR

EXAMINATION SUMMARY SHEET

Report No.:
APR-007

Site: **Pilgrim Nuclear Power Station** Component ID: **2R-N1B-1**
 Outage: **RF-015** **NOZZLE TO SAFE END**
 System **RPV** ASME Cat.: **B-F** ASME Item **B5.10** Aug Req **IGSCC D**

Exams Performed	Data Sheet	Cal Sheet	Procedure	Calibration Block	Examination Personnel	Cert Level	Date
45° / RL	N/A	APC-001	TP04-016 (GE-UT-209) R1 (V17)	PIL-79	Richard Jasken	II	4/21/2005
45° / RL	N/A	APC-002	TP04-016 (GE-UT-209) R1 (V17)	PIL-79	Richard Jasken	II	4/21/2005
45° / S	N/A	APC-003	TP04-016 (GE-UT-209) R1 (V17)	PIL-79	Richard Jasken	II	4/21/2005
60° / RL	N/A	APC-004	TP04-016 (GE-UT-209) R1 (V17)	CAL-DPTH-063	Richard Jasken	II	4/21/2005
60° / RL	N/A	APC-006	TP04-016 (GE-UT-209) R1 (V17)	CAL-DPTH-063	Richard Jasken	II	4/21/2005
N/A	APD-001	N/A	TP04-016 (GE-UT-209) R1 (V17)	N/A	Richard Jasken	II	4/21/2005

Examination Results:

During the automated ultrasonic examination of the above referenced dissimilar metal weld, no indications associated with IGSCC or any reportable indications were recorded with the "SMART 2000" system utilizing a 45° shear wave and 45° & 60° refracted longitudinal wave search units.

The 45° shear wave examinations were performed from both the upstream and downstream sides of the weld. Root geometry, beam, redirect and non-relevant indications were recorded.

The 45° RL wave examinations were performed from both the upstream and downstream sides of the weld. Root geometry, acoustic interface and non-relevant indications were recorded.

The 60° RL wave examinations were performed from both the upstream and downstream sides of the weld. Non-relevant indications were recorded.

Transducer lift off was observed at the carbon steel nozzle to butter interface due to the surface contour. Reference the data sheet for the parameters. Due to this lift off, the upstream circumferential scans are considered a best effort examination. 73% coverage was obtained per the procedure and 75% coverage of the code required examination volume.

Previous automated reports and drawings were reviewed prior to this summary.

Examination results were compared to data report 95-E-0643 from 1995 outage with No Change
 These examinations were performed under Work Order: 03116627 Change

This Summary and the following data sheets have been reviewed and accepted by the following personnel:

Prepared By: [Signature] Level: III Date: 4-23-05
 Utility Review: [Signature] Date: 4/26/05
 ANII Review: [Signature] Date: 4/29/05

RWP: 0082
Dose: 2200 mr.

Page 1 of 12

Page 126/240



GE ENERGY, NUCLEAR

Wall Thickness Profile Sheet

Site: Pilarim Nuclear Power Station Unit: 1

Report No.:

Project: RF-015



APR-007

System: RPV

Component ID Number: 2R-N1B-1

Position	0°	90°	180°	270°
1	1.90"	N/A	N/A	N/A
2	1.95"	N/A	N/A	N/A
3	2.05"	N/A	N/A	N/A
4	1.95"	N/A	N/A	N/A
5	1.90"	N/A	N/A	N/A

Crown Height:
 Crown Width: 1.95"
 Nominal Diameter: 28.0"
 Weld Length: 92.0"



Thickness obtained from previous data
 Weld preps obtained from drawings; M1A80 and M1A73 sheet 2
 Scale - 1:2
 * - Concavity found at CS/Inc interface. See page 3 of this report.

Page 127/240

CRB Charles Barrett II 4/20/2005
 Initials: Examiner: Level: Date:

[Signature] III 4-23-05
 GE Reviewed By: Level: Date:

[Signature] L-III 4/26/05
 Utility Review: Date:

[Signature] 4/29/05
 ANII Review: Date:



GE ENERGY, NUCLEAR

Indication / Coverage Plot Sheet

Site: Pillarim Nuclear Power Station Unit: 1

Report Number.:

Project: RF-015

APR-007


System: RPV

Component ID Number: 2R-N1B-1

Configuration: NOZZLE

SAFE END

NOZZLE



FLOW →

Page 128/140

CS

Charles Barrett

II 4/20/2005

Initials: Examiner:

Level: Date:

M. K...

4/23/05

GE Reviewed By:

Level: Date:

Scott D...

4/20/05

Utility Reviewed By:

Date:

Carl...

4/20/05


ANII Reviewed By:

Date:



N1B Nozzle to Safe End

45°RL LKUP Typical Geometry




Page 129/240



N1B Nozzle to Safe End

45° Shear LKUP Typical Root Geometry



Page 13b/240



GE Nuclear Energy

Ultrasonic Data / Scan Parameter Sheet
(Automated with Micro TomoScan)

Site: Pilgrim Nuclear Power Station
Unit: 1
Project No.: RF-015

Procedure: TP04-018 (GE-UT-209)
Version / Revision: R1 (V17)
DRR: N/A

System: RPV
Weld No.: 2R-N1B-1
Configuration: NOZZLE TO SAFE END

Report No.: APR-007
Data Sheet No.: APD-001
Calibration Sheet No.

Scanner Information

Weld Reference, (GE-ADM-1005): Lo: Top Dead Center Wo: Weld Centerline Motor Steps: Cir: 1710 Tra: 2500
Examination Surface: OD Exam Surface Temperature: 94 °F Thermometer S/N: 241687 Exam Start: 4/21/2005 5:50:00 AM
Exam End: 4/22/2005 9:09:00 AM
Nominal Pipe Size 28" Nominal Thickness: 1.90" Weld Width: 1.83" Weld Length: 92"
Scanner: NOVA Track Diameter: 32" Arm Length: 18" Track Location: 8" DOWNSTREAM OF SE TAPER
X Positive Scan Direction: DOWNSTREAM Y Positive Scan Direction: CW
Resolution: ≤ 0.036" Index Ax / Circ: ≤ 0.19" ≤ 0.05" Axial Scan Speed: ≤ 2.0 in./Sec. Circ Scan Speed: ≤ 1.0 in./Sec.
Scanner Zero Positions: CIR: TOP DEAD CENTER TRA: WELD CENTERLINE NOT Zero: LKDN

Scan Parameters and Results

Scan:	Skew:	File ID:	Disk:	X-Start:	X-Stop:	Y-Start:	Y-Stop:	Gain:	Results:	Comments:
Z11	0	2RN1B1Z11	D-01	-5.6"	2.3"	0.0"	83.0"	Log	C.D.H.K	Bi-directional
Z20	180	2RN1B1Z20	D-02	-2.3"	5.7"	0.0"	83.0"	Log	C.D.H.K	Bi-directional
Z30	0	2RN1B1Z30	D-01	0.0"	83.0"	-3.7"	0.0"	Log	C	Uni-directional
Z31	0	2RN1B1Z31	D-02	0.0"	83.0"	0.0"	3.7"	Log	C	Uni-directional
Z40	180	2RN1B1Z40	D-03	0.0"	83.0"	-3.7"	0.0"	Log	C	Bi-directional
Z41	180	2RN1B1Z41	D-04	0.0"	83.0"	0.0"	3.7"	Log	C	Bi-directional

EXAMINATION RESULTS LEGEND

A - NO RECORDABLE INDICATIONS B - NON-GEOMETRIC INDICATIONS C - NON-RELEVANT INDICATIONS D - ACOUSTIC INTERFACE
E - INSIDE SURFACE F - OUTSIDE SURFACE G - WELD DISCONTINUITY H - ROOT GEOMETRY
I - COUNTERBORE J - SHEAR COMPONENT K - BEAM RE-DIRECT

Comments:

Axial scans were limited from a 'L' of 26" to 41.25" with a 'W' of -1.7" to -0.9" and a 'L' of 49" - 86" with a 'W' of -1.5" to 0".
Upstream circ scans were limited from a 'L' of 11" to 39" and 49.6" to 84".

Page 131/140

Richard Jasken	II	4/21/2005	<i>[Signature]</i>	4-23-05	<i>[Signature]</i>	4/24/05	<i>[Signature]</i>	4/26/05
Examiner:	Level:	Date:	GE Review:	Level:	Date:	Utility Review:	Date:	ANII Review: <i>[Signature]</i> Date: <i>[Signature]</i>



GE Energy, Nuclear

ULTRASONIC CALIBRATION DATA SHEET (Automated with Micro TomoScan)

Site Pilgrim Nuclear Power Unit 1

Project RF-015

Report Number APR-007

Calibration Sheet No. APC-001

Weld 2R-N1B-1

Procedure No. TP04-016 (GE-UT-209)

Version R1 (V17) DRR N/A

Instrument Zetec / u Tomo 18121-09 2.2014 2.2014
Manufacturer / Model System Serial No. Acquisition Software Analysis Software
Pulser/Receiver R/D Tech EQTX 100 Pulser/Receiver R/D Tech EQTX 101 Digitizer: R/D Tech EQTX 099
Main Board: Manufacturer / Model Piggy Board: Manufacturer / Model
Search Unit RTD 04-430 2(15x25) mm 1.0 MHz 45° / RL 1.39" 45° 0.75"
Manufacturer Serial No. Element Size Freq. (MHz) Angle / Mode FD,FS/SA,RA Measured Incident to
Cable RG-58/RG-58/RG-174 250' / 25' / 3' 2 No. of Intermediate Connectors Angle Wedge Front
Calibration Standard P1L-79 SS 2.1" 2.1"
Serial No. Material Nominal Thickness Measured Thickness
Thermometer 241576 75 °F Couplant Demin Water N/A
Serial No. Temp (°F) Type Batch No.

Table with 3 columns for Calibration data: Orientation (Circ), Type (ID Notch), Depth (2.10 in), Amplitude / dB (80%, -43.9 dB, -20.7 dB), Sweep (2.95 in), Gain (dB) (34, Log, +25 Log), Screen (Half Path, 25 dB Booster, Active).

Channel Name 45° RL 04-430 P1/R1
General
Timebase Start 0.0 in Range 5.5 in
Units Half Path
Digitizer
Synchro Pulse [X] A Scan Sample Size 8 Bit
Averaging 1 Acquisition Rate 326 Hz
Digitizing Frequency 6.25 MHz Max Recurrence 2000 Hz
Pulser / Receiver

Field Simulator CS Rompas S/N CAL-RHOM-095
Reflector Far SDH
Max Amplitude/dB -11.30 dB
Sweep 1.06"
Gain (dB) + Log

Configuration Conventional Pitch Catch
Pulser P1 Receiver R1
Voltage 300 V Scale Type LOG
Width (Ns) 500 ns Rectification Unsigned
Smoothing 1 MHz
Probe

Table for Calibration Verification with columns: Time, Date, Block(s), Operator. Rows include Initial, Verified, and Final entries.

Wave Type Longitudinal Scan offset 0 in
Velocity 0.2272 in/sec Index offset 0.00 in
Wedge Delay 12.229 usec Angle 45°
Skew 0/180
N1 - 45° RL - Circ scan

Richard Jasken II 4/21/2005
Operator Level Date
Analyst [Signature] 4/23/05
Level Date

Utility Review [Signature] Level Date
ANIII Review [Signature] Level Date

Page 7 of 12



GE Energy, Nuclear

ULTRASONIC CALIBRATION DATA SHEET (Automated with Micro TomoScan)

Site Pilgrim Nuclear Power Unit 1 Weld 2R-N1B-1

Project RF-015

Report Number APR-007 Calibration Sheet No. APC-002

Procedure No. TP04-016 (GE-UT-209)

Version R1 (V17) DRR N/A

Instrument Zetec / u Tomo 18121-09 2.2Q14 2.2Q14
Pulser/Receiver Main Board: R/D Tech EQTX 100
Pulser/Receiver Piggy Board: R/D Tech EQTX 101
Search Unit RTD 03-677 2(20X34) mm 1.0 MHz 45° / RL 2.23° 45° 0.95°
Cable RG-58/RG-58/RG-174 250' / 25' / 3' 2
Calibration Standard PIL-79 SS 2.1" 2.1"
Thermometer 241576 75 °F Demin Water N/A

Table with 3 columns for Calibration data: Orientation, Type, Depth, Amplitude / dB, Sweep, Gain (dB), Screen.

Channel Name 45° RL 03-677 P1/R1
General
Timebase Start 0.0 in. Range 5.5 in.
Units Half Path
Digitizer
Synchro Pulse A Scan Sample Size 8 Bit
Averaging 1 Acquisition Rate 326 Hz
Digitizing Frequency 6.25 MHz Max Recurrence 2000 Hz
Pulser / Receiver
Configuration Conventional Pitch Catch
Pulser P1 Receiver R1
Voltage 300 V Scale Type LOG
Width (Ns) 500 ns Rectification Unsigned
Smoothing 1 MHz
Probe
Wave Type Longitudinal Scan offset 0 in.
Velocity 0.2272 in./sec. Index offset 0.00 in.
Wedge Delay 12.017 usec. Angle 45°
Skew 0/180

Field Simulator CS Rompas S/N CAL-RHOM-095
Reflector Far SDH
Max Amplitude/dB -15.4 dB
Sweep 1.06°
Gain (dB) + Log

Table for Calibration Verification with columns: Time, Date, Block(s), Operator. Rows include Initial, Verified, and Final entries.

Richard Jasken II 4/21/2005
Operator Level Date
Analyst DL 4-23-05
Level Date

Utility Review Level Date
ANIII Review Level Date

Page 133/240



GE Energy, Nuclear

ULTRASONIC CALIBRATION DATA SHEET (Automated with Micro TomoScan)

Site Pilgrim Nuclear Power

Unit 1

Project RF-015

Report Number APR-007

Calibration Sheet No. APC-003

Weld 2R-N1B-1

Procedure No. TP04-016 (GE-UT-209)

Version R1 (V17)

DRP

N/A

Instrument

Zetec / u Tomo

Manufacturer / Model

18121-09

System Serial No.

2.2Q14

Acquisition Software

2.2Q14

Analysis Software

Pulsar/Receiver Main Board:

R/D Tech EQTX 100

Manufacturer / Model

Pulsar/Receiver Piggy Board:

R/D Tech EQTX 101

Manufacturer / Model

Digitizer:

R/D Tech EQTX 098

Manufacturer / Model

Search Unit

RTD

Manufacturer

03-340

Serial No.

Ell(24x17) mm

Element Size

1.5 MHz

Freq. (MHz)

45°/S

Angle / Mode

N/A

FD,FS/SA,RA

45°

Measured Angle

0.52°

Incident to Wedge Front

Cable

RG-58/RG-58/RG-174

Type

250' / 25' / 3'

Length

2

No. of Intermediate Connectors

Calibration Standard

PIL-79

Serial No.

SS

Material

2.1"

Nominal Thickness

2.1"

Measured Thickness

Thermometer

241576

Serial No.

75 °F

Temp (°F)

Couplant

Demin Water

Type

N/A

Batch No.

Calibration

Orientation

Circ

Type

ID Notch

Depth

2.10 in.

Amplitude / dB

-8.2 dB

Sweep

2.97 in.

Gain (dB)

Log

Screen

Half Path

25 dB Booster

Inactive

Channel Name

45° Shear 03-340 P2

General

Timebase

Start 0.0 in.

Range 5.5 in.

Units

Half Path

Digitizer

Synchro Pulse

A Scan

Sample Size

8 Bit

Averaging

1

Acquisition Rate

326 Hz

Digitizing Frequency

12.5 MHz

Max Recurrence

2000 Hz

Pulsar / Receiver

Configuration

Conventional Pulse Echo

Pulsar

P2

Receiver

N/A

Voltage

300 V

Scale Type

LOG

Width (Ns)

333 ns

Rectification

Unsigned

Smoothing

2 MHz

Probe

Wave Type

Transverse

Scan offset

0 in.

Velocity

0.1240 in./sec.

Index offset

-2.50 in.

Wedge Delay

11.951 usec.

Angle

45°

Skew

0/180

N1 - 45° Shear

Ax scan index offset -2.50"

Circ scan offset -2.50"

Calibration Verification

	Time	Date	Block(s)	Operator
Initial	1250	4/11/2005	PIL 79	RJ/MW
Verified	0555	4/21/2005	CAL-RHOM-095	RSG
Verified	1410	4/21/2005	CAL-RHOM-095	RJ
Verified	1332	4/21/2005	CAL-RHOM-095	RSG
Final	0905	4/22/2005	CAL-RHOM-095	RSG

Richard Jasken

II

4/21/2005

Operator

Level

Date

Signature

Utility Review

TJL

4/26/05

Level

Date

Analyst

Level

Date

Signature

ANIII Review

4/28/05

Date

Page 9 of 12



GE Energy, Nuclear

ULTRASONIC CALIBRATION DATA SHEET (Automated with Micro TomoScan)

Site Pilgrim Nuclear Power Unit 1 Project RF-015 Report Number APR-007 Calibration Sheet No. APC-004 Weld 2R-N1B-1

Procedure No. TP04-016 (GE-UT-209) Version R1 (V17) DRR N/A

Instrument Zetec / u Tomo 18121-09 2.2Q14 2.2Q14 Manufacturer / Model System Serial No. Acquisition Software Analysis Software Pulser/Receiver Main Board: R/D Tech EQTX 100 R/D Tech EQTX 101 Digitizer: R/D Tech EQTX 098 Manufacturer / Model Search Unit RTD 04-345 2(20x34) mm 1.0 MHz 60° / RL 1.38" 60° 1.0" Manufacturer Serial No. Element Size Freq. (MHz) Angle / Mode FD,FS/SA,RA Measured Angle Incident to Wedge Front Cable RG-58/RG-58/RG-174 250' / 25' / 3' 2 No. of Intermediate Connectors Calibration Standard CAL-DPTH-063 SS 1.4" 1.4" Serial No. Material Nominal Thickness Measured Thickness Thermometer 241576 75 °F Couplant Demin Water N/A Serial No. Temp (°F) Type Batch No.

Table with 3 columns for Calibration parameters: Orientation (Circ, Circ, Circ), Type (SDH, SDH, SDH), Depth (1.40 in, 1.40 in, 1.40 in), Amplitude / dB (80.8%, -30.7 dB, -6.6 dB), Sweep (2.78 in, 2.78 in, 2.78 in), Gain (dB) (21.0, Log, +25 Log), Screen (Half Path, 25 dB Booster, Active)

Channel Name 60° RL 04-345 P3 / R3 General Timebase Start 0.0 in. Range 8.0 in. Units Half Path Digitizer Synchro Pulse [x] A Scan Sample Size 8 Bit Averaging 1 Acquisition Rate 326 Hz Digitizing Frequency 6.25 MHz Max Recurrence 2000 Hz

Field Simulator CS Rompas S/N CAL-RHOM-095 Reflector Far SDH Max Amplitude/dB -11.9 dB Sweep 1.56" Gain (dB) + Log

Configuration Conventional Pitch Catch Pulser P3 Receiver R3 Voltage 300 V Scale Type LOG Width (Ns) 500 ns Rectification Unsigned Smoothing 1 MHz

Table for Calibration Verification with columns: Time, Date, Block(s), Operator. Rows: Initial (1350, 4/11/2005, CAL-DPTH-063, R/JMW), Verified (0600, 4/21/2005, CAL-RHOM-095, RSG), Verified, Verified, Final (1335, 4/21/2005, CAL-RHOM-095, RSG)

Probe Wave Type Longitudinal Scan offset 0 in. Velocity 0.2272 in./sec. Index offset -5.00 in. Wedge Delay 13.593 usec. Angle 60° Skew 0/180

Richard Jasken II 4/21/2005 Operator Level Date Analyst [Signature] III 4-23-05 Level Date

Utility Review [Signature] III 4/26/05 Level Date ANIII Review [Signature] Date

Page 135/240



GE Energy, Nuclear

ULTRASONIC CALIBRATION DATA SHEET (Automated with Micro TomoScan)

Site Pilgrim Nuclear Power Unit 1 Project RF-015

Report Number APR-007 Calibration Sheet No. APC-006

Weld 2R-N1B-1

Procedure No. TP04-016 (GE-UT-209)

Version R1 (V17) DRP N/A

Instrument Zetec / uTomo 18121-09 2.2Q14 2.2Q14
Manufacturer / Model System Serial No. Acquisition Software Analysis Software
Pulsar/Receiver R/D Tech EQTX 100 Pulsar/Receiver R/D Tech EQTX 101 Digitizer: R/D Tech EQTX 090
Main Board: Manufacturer / Model Piggy Board: Manufacturer / Model
Search Unit RTD 04-431 2(15x25) mm 1.0 MHz 60° / RL 0.89° 60° 0.75°
Manufacturer Serial No. Element Size Freq. (MHz) Angle / Mode FD,FS/SA,RA Measured Incident to
Cable RG-58/RG-58/RG-174 250' / 25' / 3' 2 No. of Intermediate Connectors Angle Wedge Front
Calibration Standard CAL-DPTH-063 SS 0.9" 0.9"
Serial No. Material Nominal Thickness Measured Thickness
Thermometer 241576 75°F Couplant Demin Water N/A
Serial No. Temp (°F) Type Etch No.

Table with 3 columns for Calibration data: Orientation, Type, Depth, Amplitude, Sweep, Gain, Screen.

Channel Name 60° RL 04-431 P3 / R3
General
Timebase Start 0.0 in. Range 8.0 in.
Units Half Path
Digitizer
Synchro Pulse [X] A Scan Sample Size 8 Bit
Averaging 1 Acquisition Rate 326 Hz
Digitizing Frequency 6.25 MHz Max Recurrence 2000 Hz
Pulsar / Receiver
Configuration Conventional Pitch Catch
Pulsar P3 Receiver R3
Voltage 300 V Scale Type LOG
Width (Ns) 500 ns Rectification Unsigned
Smoothing 1 MHz
Probe
Wave Type Longitudinal Scan offset -5 in.
Velocity 0.2272 in./sec. Index offset 0.00 in.
Wedge Delay 12.955 usec. Angle 60°
Skew 0/180

Field Simulator CS Rompac S/N CAL-RHOM-095
Reflector Far SDH
Max Amplitude/dB -33.6 dB
Sweep 1.53"
Gain (dB) + Log

Table for Calibration Verification with columns: Time, Date, Block(s), Operator. Rows include Initial, Verified, Verified, Verified, Final.

Configuration Conventional Pitch Catch
Pulsar P3 Receiver R3
Voltage 300 V Scale Type LOG
Width (Ns) 500 ns Rectification Unsigned
Smoothing 1 MHz
Probe
Wave Type Longitudinal Scan offset -5 in.
Velocity 0.2272 in./sec. Index offset 0.00 in.
Wedge Delay 12.955 usec. Angle 60°
Skew 0/180
N1 - 60° RL - Circ Scan

Richard Jasken II 4/21/2005
Operator Level Date
Analyst [Signature] TL 4-23-05
Level Date

Utility Review [Signature] TL 4/26/05
Level Date
ANIII Review [Signature] TL 4/29/05
Level Date

Page 136/240



GE Energy, Nuclear

Micro-Tomo (Smart 2000) - Auto Piping Weld Examination Checklist

**Pilgrim Unit 1, 2005
2R-NIB-1**

2RN1B1Z10 LKDN	Load appropriate setup	Offsets entered into TV correctly	Transducers Skewed IAW Procedure	Files named IAW Scanplan	360° contact achieved	360° Circ coverage achieved	Full Volume Ax Coverage Achieved	Scan saved to computer HD Verified readable	Data transferred to DA Verified received by DA	Data Reviewed	Analysis Complete	Package Complete	<u>NOTES:</u>
45° Shear	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	RJ	MJK				Lift off due to OD contour
45° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			MJK	MJK	MJK	
60° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>						
2RN1B1Z20 LKUP	Load appropriate setup	Offsets entered into TV correctly	Transducers Skewed IAW Procedure	Files named IAW Scanplan	360° contact achieved	360° Circ coverage achieved	Full Volume Ax Coverage Achieved	Scan saved to computer HD Verified readable	Data transferred to DA Verified received by DA	Data Reviewed	Analysis Complete	Package Complete	<u>NOTES:</u>
45° Shear	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	RJ	MJK				Lift off due to OD contour
45° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			MJK	MJK	MJK	
60° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>						
2RN1B1Z30 LKCW	Load appropriate setup	Offsets entered into TV correctly	Transducers Skewed IAW Procedure	Files named IAW Scanplan	360° contact achieved	360° Circ coverage achieved	Full Volume Ax Coverage Achieved	Scan saved to computer HD Verified readable	Data transferred to DA Verified received by DA	Data Reviewed	Analysis Complete	Package Complete	<u>NOTES:</u>
45° Shear	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	MW	MJK				Lift off due to OD contour on upstream side
45° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			MJK	MJK	MJK	
60° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>						
2RN1B1Z40 LKCCW	Load appropriate setup	Offsets entered into TV correctly	Transducers Skewed IAW Procedure	Files named IAW Scanplan	360° contact achieved	360° Circ coverage achieved	Full Volume Ax Coverage Achieved	Scan saved to computer HD Verified readable	Data transferred to DA Verified received by DA	Data Reviewed	Analysis Complete	Package Complete	<u>NOTES:</u>
45° Shear	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	MW	MJK				Lift off due to OD contour on upstream side
45° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			MJK	MJK	MJK	
60° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>						

Notes: Circ scans separated to upstream and downstream sides of weld centerline.

Page 137/240

Scott D. ...
Page 12 of 12



GE ENERGY, NUCLEAR

EXAMINATION SUMMARY SHEET

Report No.: APR-009

Site: Pilgrim Nuclear Power Station Component ID: 2R-N2E-1
 Outage: RF-015 SAFE END TO NOZZLE
 System RPV ASME Cat.: B-F ASME Item B5.10 Aug Req IGSCC D

Exams Performed	Data Sheet	Cal Sheet	Procedure	Calibration Block	Examination Personne!	Cert Level	Date
45° / S	N/A	APC-07*	TP04-016 (GE-UT-209) R1 (V17)	PIL-7E	Robert Scott Getz	I	4/22/2005
45° / RL	N/A	APC-072	TP04-016 (GE-UT-209) R1 (V17)	PIL-78	Robert Scott Getz	II	4/22/2005
45° / RL	N/A	APC-073	TP04-016 (GE-UT-209) R1 (V17)	PIL-78	Robert Scott Getz	II	4/22/2005
60° / RL	N/A	APC-074	TP04-016 (GE-UT-209) R1 (V17)	CAL-DPTH-063	Robert Scott Getz	II	4/22/2005
60° / RL	N/A	APC-075	TP04-016 (GE-UT-209) R1 (V17)	CAL-DPTH-063	Robert Scott Getz	II	4/22/2005
N/A	APD-005	N/A	TP04-016 (GE-UT-209) R1 (V17)	N/A	Robert Scott Getz	II	4/22/2005

Examination Results:

During the automated ultrasonic examination of the above referenced dissimilar metal weld, no indications associated with IGSCC or any reportable indications were recorded with the "SMART 2000" system utilizing a 45° shear wave, 45° and 60° retracted longitudinal wave search units.

The 45° shear wave examinations were performed from both the upstream and downstream sides of the weld. Root geometry, beam redirect and non-relevant indications were recorded.

The 45° RL wave examinations were performed from both the upstream and downstream sides of the weld. Root geometry, acoustic interface, inside surface geometry and non-relevant indications were recorded.

The 60° RL wave examinations were performed from both the upstream and downstream sides of the weld. Acoustic interface and non-relevant indications were recorded.

The outside surface weld crown did not meet procedure requirements from 11° to 23°. 79.1% coverage was obtained per the procedure and 81.2% coverage of the code required examination volume.

Previous automated electronic data and automated reports and drawings were reviewed prior to this summary.

Examination results were compared to data report 95-E-403 from 1995 outage with No Change
 These examinations were performed under Work Order: 031166227 Change

This Summary and the following data sheets have been reviewed and accepted by the following personnel:

Prepared By: [Signature] Level: III Date: 4-25-05 Utility Review: [Signature] Date: 4/28/05
 ANII Review: [Signature] Date: 4/28/05

RWP: 0062
Dose: 1850 mr.

Page 1 of 13



GE ENERGY, NUCLEAR

Wall Thickness Profile Sheet

Site: Pilarim Nuclear Power Station Unit: 3

Report No.:

Project: RF-015

APR-009

System: RPV

Component ID Number: 2R-N2E-1



Position	0°	90°	180°	270°
1	1.09"	N/A	N/A	N/A
2	1.20"	N/A	N/A	N/A
3	1.21"	N/A	N/A </td <td>N/A</td>	N/A
4	1.08"	N/A	N/A	N/A
5	1.09"	N/A	N/A	N/A

Crown Height: FLUSH

Crown Width: 1.15"

Nominal Diameter: 12.0"

Weld Length: 42.0"



Safe End (-)

Procedural Exam Volume

Nozzle (+)

Thickness obtained from previous data
 Weld preps obtained from drawings; 137C8066 and M1A73 sheet 2
 Bottom of nozzle bore to Inc/CS interface = 4.1"
 Bottom of SE taper to Inc/CS interface = 7.5"

Boqr 139/240

CB Charles Barrett II 4/25/2005
 Initials: Examiner: Level: Date:

[Signature] 4/25/05
 GE Reviewed By: Level: Date:

[Signature] 4/28/05
 Utility Review: Level: Date:

[Signature] 4/28/05
 ANII Review: Date:



GE ENERGY, NUCLEAR

Wall Thickness Profile Sheet

Site: Pilgrim Nuclear Power Station Unit: 1

Report No.:

Project: RE-015

APR-009

System: RPV

Component ID Number: 2R-N2E-1



Position	0°	90°	180°	270°
1	1.09"	N/A	N/A	N/A
2	1.20"	N/A	N/A	N/A
3	1.21"	N/A	N/A	N/A
4	1.09"	N/A	N/A	N/A
5	1.09"	N/A	N/A	N/A

Crown Height: FLUSH

Crown Width: 1.15"

Nominal Diameter: 12.0"

Weld Length: 42.0"



Thickness obtained from previous data
 Weld preps obtained from drawings; 137C8066 and M1A73 sheet 2
 Bottom of nozzle bore to Inc/CS interface = 4.1"
 Bottom of SE taper to Inc/CS interface = 7.5"

Page 140/240

Charles Barrett II 4/25/2005
 Initials: Examiner: Level: Date:

M. J. [Signature] III 4/25/05
 GE Reviewed By: Level: Date:

[Signature] 4/26/05
 Utility Review: Date:

[Signature] 4/26/05
 ANII Review: Date:



GE ENERGY, NUCLEAR

Indication / Coverage Plot Sheet

Site: Pilarim Nuclear Power Station Unit: 1

Report Number.: APR-009

Project: RF-015


APR-009

System: RPV

Component ID Number: 2R-N2E-1

Configuration: SAFE END

NOZZLE



Page 141/240

CB Charles Barrett II 4/25/2005
Initials: Examiner: Level: Date:

[Signature] III 4/25/05
GE Reviewed By: Level: Date:


[Signature] I-III 4/26/05
Utility Reviewed By: Date:

[Signature] 4/27/05
ANII Reviewed By: Date:



N2E Safe End to Nozzle

45°RL LKDN Root Geometry




Page 142/240



N2E Safe End to Nozzle

45°RL LKDN Acoustic Interface



Page 143/240



GE Nuclear Energy

Ultrasonic Data / Scan Parameter Sheet
(Automated with Micro TomoScan)

Site: <u>Pillarim Nuclear Power Station</u>	Procedure: <u>TP04-016 (GE-UT-209)</u>	System: <u>RPV</u>	Report No.: <u>APR-009</u>
Unit: <u>1</u>	Version / Revision: <u>R1 (V17)</u>	Weld No.: <u>2R-N2E-1</u>	Data Sheet No.: <u>APD-005</u>
Project No.: <u>RF-015</u>	DRR: <u>N/A</u>	Configuration: <u>SAFE END TO NOZZLE</u>	Calibration Sheet No.

Scanner Information

Weld Reference, (GE-ADM-1005): Lo: TDC Wo: Weld Centerline Motor Steps: Cir: 2088 Tra: 2500
 Examination Surface: OD Exam Surface Temperature: 92 °F Thermometer S/N: 241878 Exam Start: 4/22/2005 3:25:00 PM
 Exam End: 4/23/2005 7:20:00 AM

Nominal Pipe Size 12" Nominal Thickness: 1.1" Weld Width: 1.12" Weld Length: 42"
 Scanner: NOVA Track Diameter: 16" Arm Length: 18" Track Location: 14" FROM INTERFACE UPSTREAM

X Positive Scan Direction: CW Y Positive Scan Direction: DOWNSTREAM
 Resolution: ≤ 0.036" Index Ax / Circ: ≤ 0.18" ≤ 0.05" Axial Scan Speed: ≤ 1.98 In./Sec. Circ Scan Speed: ≤ 0.98 In./Sec.
 Scanner Zero Positions: CIR: TOP DEAD CENTER TRA: WELD CENTERLINE ROT Zero: LOOKING DOWNSTREAM

Scan Parameters and Results

Scan:	Skew:	File ID:	Disk:	X-Start:	X-Stop:	Y-Start:	Y-Stop:	Gain:	Results:	Comments:
Z11	0	2RN2EZ11	D-09	-4.0"	2.1"	0.0"	43.0"	Log	C.D.H	Uni-directional
Z20	180	2RN2EZ20	D-09	-2.0"	4.1"	0.0"	43.0"	Log	K.C	Bi-directional
Z30	0	2RN2EZ30	D-09	0.0"	43.0"	-2.7"	2.9"	Log	C	Uni-directional
Z40	180	2RN2EZ40	D-09	0.0"	43.0"	-2.7"	2.9"	Log	C.E	Uni-directional

EXAMINATION RESULTS LEGEND

A - NO RECORDABLE INDICATIONS	B - NON-GEOMETRIC INDICATIONS	C - NON-RELEVANT INDICATIONS	D - ACOUSTIC INTERFACE
E - INSIDE SURFACE	F - OUTSIDE SURFACE	G - WELD DISCONTINUITY	H - ROOT GEOMETRY
I - COUNTERBORE	J - SHEAR COMPONENT	K - BEAM RE-DIRECT	

Comments:
 High weld crown from a 'L' of 11" - 23" does not meet procedure requirements.
 Load A01 files for Z11 and Z20 scans.

Robert Scott Getz	II	4/22/2005	<i>[Signature]</i>	III	4-25-05	<i>[Signature]</i>	4/28/05	<i>[Signature]</i>	4/28/05
Examiner:	Level:	Date:	GE Review:	Level:	Date:	Utility Review:	Date:	ANII Review:	Date:

Page 144/240



GE Energy, Nuclear

ULTRASONIC CALIBRATION DATA SHEET (Automated with Micro TomoScan)

Site Pilgrim Nuclear Power Unit 1

Project RF-015

Report Number APR-009

Calibration Sheet No. APC-071

Weld 2R-N2E-1

Procedure No. TP04-016 (GE-UT-209)

Version R1 (V17) DRF N/A

Instrument	<u>Zetec / uTomo</u> Manufacturer / Model	<u>18121-09</u> System Serial No.	<u>2.2Q14</u> Acquisition Software	<u>2.2Q14</u> Analysis Software
Pulsar/Receiver Main Board:	<u>R/D Tech EQTX 100</u> Manufacturer / Model	Pulsar/Receiver Piggy Board: <u>R/D Tech EQTX 101</u> Manufacturer / Model	Digitizer: <u>R/D Tech EQTX 098</u> Manufacturer / Model	
Search Unit	<u>RTD</u> Manufacturer	<u>03-341</u> Serial No.	<u>EII(24x17) mm</u> Element Size	<u>1.5 Mhz</u> Freq. (MHz)
			<u>45° / S</u> Angle / Mode	<u>N/A</u> FD,FS/SA,RA
Cable	<u>RG-58/RG-58/RG-174</u> Type	<u>250' / 25' / 3'</u> Length	<u>2</u> No. of Intermediate Connectors	<u>45°</u> Measured Angle
				<u>0.52"</u> Incident to Wedge Front
Calibration Standard	<u>PIL-78</u> Serial No.	<u>SS</u> Material	<u>1.3"</u> Nominal Thickness	<u>1.3"</u> Measured Thickness
Thermometer	<u>241878</u> Serial No.	<u>75 °F</u> Temp (°F)	<u>Demin Water</u> Couplant Type	<u>N/A</u> Batch No.

Calibration

Orientation	<u>Circ</u>	<u>Circ</u>
Type	<u>ID Notch</u>	<u>ID Notch</u>
Depth	<u>1.30 in.</u>	<u>1.30 in.</u>
Amplitude / dB	<u>85.4%</u>	<u>-9.4 dB</u>
Sweep	<u>1.91 in.</u>	<u>1.91 in.</u>
Gain (dB)	<u>1.0</u>	<u>Log</u>
Screen	<u>Half Path</u>	25 dB Booster <u>Inactive</u>

Channel Name 03-341 45° Shear P2

General

Timebase Start 0.0 in. Range 4.0 in.
Units Half Path

Digitizer

Synchro Pulse A Scan Sample Size 8 Bit
Averaging 1 Acquisition Rate 301 Hz
Digitizing Frequency 12.5 Mhz Max Recurrence 2000 Hz

Pulsar / Receiver

Configuration Conventional Pulse Echo
Pulsar P2 Receiver N/A
Voltage 300 V Scale Type LOG
Width (Ns) 333 ns Rectification Unsigned
Smoothing 2 Mhz

Probe

Wave Type Transverse Scan offset 0.00 in.
Velocity 0.1240 in./sec. Index offset 0.00 in.
Wedge Delay 11.778 usec. Angle 45°
Skew 0/180

Field Simulator CS Rompas S/N CAL-RHOM-095

Reflector Far SDH
Max Amplitude/dB -19.5 dB
Sweep 1.01"
Gain (dB) Log

Calibration Verification

	Time	Date	Block(s)	Operator
Initial	0847	4/11/2005	PIL 78	RJ
Verified	1528	4/22/2005	CAL-RHOM-095	SG
Verified	2224	4/22/2005	CAL-RHOM-095	MW
Verified	1030	4/23/2005	CAL-RHOM-095	RJ
Final	0120	4/24/2005	CAL-RHOM-095	PK

N2 - 45° Shear - Ax/Circ Scan
Ax scan offset: 0 Index offset: -2.60
Circ scan offset: -2.60 Index offset: 0
Calibration verification at 1703, 4/23/04, Block CAL-RHOM-095

Robert Scott Getz	II	4/22/2005
Operator	Level	Date
	<u>II</u>	<u>4/25/05</u>
Analyst	Level	Date

	III	4/28/05
Utility Review	Level	Date
	<u>III</u>	<u>4/28/05</u>
ANIII Review	Level	Date



GE Energy, Nuclear

ULTRASONIC CALIBRATION DATA SHEET (Automated with Micro TomoScan)

Site Pilgrim Nuclear Power

Unit 1

Project RF-015

Report Number APR-009

Calibration Sheet No. APC-072

Weld 2R-N2E-1

Procedure No. TP04-016 (GE-UT-209)

Version R1 (V17) DRF N/A

Instrument Zetec / u Tomo 18121-09 2.2Q14 2.2Q14
Manufacturer / Model System Serial No. Acquisition Software Analysis Software
Pulsar/Receiver R/D Tech EQTX 100 R/D Tech EQTX 101 Digitizer: R/D Tech EQTX 098
Main Board: Manufacturer / Model Piggy Board: Manufacturer / Model
Search Unit RTD 04-302 2(10x18) mm 2.0 MHz 45 / RL 1.0 45 0.55
Manufacturer Serial No. Element Size Freq. (MHz) Angle / Mode FD,FS/SA,RA Measured Incident to
Cable RG-58/RG-58/RG-174 250' / 25' / 3' Length 2 No. of Intermediate Connectors
Calibration Standard PIL-78 SSINC 1.3 1.3
Serial No. Material Nominal Thickness Measured Thickness
Thermometer 241878 75 F Couplant Demin Water N/A
Serial No. Temp (F) Type Batch No.

Calibration

Orientation Circ Circ Circ
Type ID Notch ID Notch ID Notch
Depth 1.30 in. 1.30 in. 1.30 in.
Amplitude / dB 82.4% -32.0 dB -7.2 dB
Sweep 1.85 in. 1.85 in. 1.85 in.
Gain (dB) 23.0 Log +25 Log
Screen Half Path 25 dB Booster Active

Channel Name 45 RL 04-302 P1/R1

General

Timebase Start 0.0 in. Range 4.0 in.
Units Half Path

Digitizer

Synchro Pulse A Scan Sample Size 8 Bit
Averaging 1 Acquisition Rate 301 Hz
Digitizing Frequency 12.5 MHz Max Recurrence 2000 Hz

Pulsar / Receiver

Configuration Conventional Pitch Catch
Pulsar P1 Receiver R1
Voltage 300 V Scale Type LOG
Width (Ns) 250 ns Rectification Unsigned
Smoothing 2 MHz

Probe

Wave Type Longitudinal Scan offset 0.00 in.
Velocity 0.2272 in./sec. Index offset 0.00 in.
Wedge Delay 9.675 usec. Angle 45
Skew 0/180

N2 - 45 RL - Ax Scan

Field Simulator CS Romoss S/N CAL-RHOM-095

Reflector Far SDH
Max Amplitude/dB -5.3 dB
Sweep 1.04
Gain (dB) Log

Calibration Verification

Table with columns: Time, Date, Block(s), Operator. Rows: Initial (0900, 4/11/2005, PIL 78, RJ), Verified (1526, 4/22/2005, CAL-RHOM-095, SG), Verified, Verified, Final (2223, 4/22/2005, CAL-RHOM-095, MW)

Robert Scott Getz Operator Level 4/22/2005 Date
Analyst Level 4/25/05 Date

Utility Review Level 4/28/05 Date
ANIII Review Level 4/28/05 Date

Page 46/240



GE Energy, Nuclear

ULTRASONIC CALIBRATION DATA SHEET (Automated with Micro TomoScan)

Site Pilgrim Nuclear Power Unit 1

Project RF-015

Report Number APR-009

Calibration Sheet No. APC-073

Weld 2R-N2E-1

Procedure No. TP04-016 (GE-UT-209)

Version R1 (V17)

DRR

N/A

Instrument Zetec / u Tomo 18121-09 2.2014 2.2014
Manufacturer / Model System Serial No. Acquisition Software Analysis Software
Pulsar/Receiver R/D Tech EQTX 100 Pulsar/Receiver R/D Tech EQTX 101 Digitizer: R/D Tech EQTX 098
Main Board: Manufacturer / Model Piggy Board: Manufacturer / Model
Search Unit RTD 04-310 2(10x18) mm 1.0 MHz 45° / RL 0.84° 45° 0.55°
Manufacturer Serial No. Element Size Freq. (MHz) Angle / Mode FD,FS/SA,RA Measured Incident to
Cable RG-58/RG-58/RG-174 250' / 25' / 3' 2 No. of Intermediate Connectors
Type Length
Calibration Standard PIL-78 SS/NC 1.3" 1.3"
Serial No. Material Nominal Thickness Measured Thickness
Thermometer 241878 75 °F Couplant Demin Water N/A
Serial No. Temp. (°F) Type Batch No.

Table with 4 columns: Orientation, Type, Depth, Amplitude / dB, Sweep, Gain (dB), Screen. Rows include Circ, ID Notch, 1.30 in., 83.9%, 1.85 in., 37, Half Path.

Channel Name 45° RL 04-310 P1/R1
General
Timebase Start 0.0 in. Range 4.0 in.
Units Half Path

Digitizer
Synchro Pulse [X] A Scan Sample Size 8 Bit
Averaging 1 Acquisition Rate 301 Hz
Digitizing Frequency 6.25 Mhz Max Recurrence 2000 Hz

Pulsar / Receiver
Configuration Conventional Pitch Catch
Pulsar P1 Receiver R1
Voltage 300 V Scale Type LOG
Width (Ns) 500 ns Rectification Unsigned
Smoothing 1 Mhz

Probe
Wave Type Longitudinal Scan offset 0.00 in.
Velocity 0.2272 in./sec. Index offset 0.00 in.
Wedge Delay 12.318 usec. Angle 45°
Skew 0/180

Field Simulator CS Rompas S/N CAL-RHOM-095
Reflector Far SDH
Max Amplitude/dB -17.3 dB
Sweep 1.0"
Gain (dB) + Log

Table: Calibration Verification. Columns: Time, Date, Block(s), Operator. Rows: Initial (0708, 4/23/2005, PIL 78, RJ), Verified (1026, 4/23/2005, CAL-RHOM-095, RJ), Verified (1700, 4/23/2005, CAL-RHOM-095, SG), Verified, Final (0120, 4/24/2005, CAL-RHOM-095, PK)

N2 - 45° RL - Circ Scan

Robert Scott Getz II 4/22/2005
Operator Level Date
Analyst [Signature] III 4-25-05
Level Date

[Signature] III 7/28/05
Utility Review Level Date
[Signature] 4/28/05
ANIII Review Date

Page 147/240



GE Energy, Nuclear

ULTRASONIC CALIBRATION DATA SHEET (Automated with Micro TomoScan)

Site Pilgrim Nuclear Power Unit 1

Project RF-015

Report Number APR-009

Calibration Sheet No. APC-074

Weld 2R-N2E-1

Procedure No. TP04-016 (GE-UT-209)

Version R1 (V17) DR# N/A

Instrument Zetec / uTomo 18121-09 2.2Q14 2.2Q14
Manufacturer / Model System Serial No. Acquisition Software Analysis Software
Pulsar/Receiver R/D Tech EQTX 100 Pulsar/Receiver R/D Tech EQTX 101 Digitizer: R/D Tech EQTX 098
Main Board: Manufacturer / Model Piggy Board: Manufacturer / Model
Search Unit RTD 04-305 2(10x18)mm 2.0 MHz 60°/RL 0.77° 61° 0.52°
Manufacturer Serial No. Element Size Freq. (MHz) Angle / Mode FD,FS/SA,RA Measured Incident to
Cable RG-58/RG-58/RG-174 250'/25'/3' 2 No. of Intermediate Connectors Angle Wedge Front
Calibration Standard CAL-DPTH-063 SS 0.8" 0.8"
Serial No. Material Nominal Thickness Measured Thickness
Thermometer 241878 75 °F Couplant Demin Water N/A
Serial No. Temp (°F) Type Batch No.

Calibration

Orientation Circ Circ Circ
Type SDH SDH SDH
Depth 0.80 in. 0.80 in. 0.80 in.
Amplitude / dB 81.5% -39.9 dB -9.4 dB
Sweep 1.65 in. 1.65 in. 1.65 in.
Gain (dB) 24 Log +25 Log
Screen Half Path 25 dB Booster Active

Channel Name 60° RL 04-305 P3 / R3

General

Timebase Start 0.0 in. Range 5.5 in.
Units Half Path

Digitizer

Synchro Pulse [X] A Scan Sample Size 8 Bit
Averaging 1 Acquisition Rate 301 Hz
Digitizing Frequency 12.5 MHz Max Recurrence 2000 Hz

Pulsar / Receiver

Configuration Conventional Pitch Catch
Pulsar P3 Receiver R3
Voltage 300 V Scale Type LOG
Width (Ns) 250 ns Rectification Unisigned
Smoothing 2 MHz

Probe

Wave Type Longitudinal Scan offset 0.00 in.
Velocity 0.2272 in./sec. Index offset -5.20 in.
Wedge Delay 10.637 usec. Angle 60°
Skew 0/180

Field Simulator CS Rompas S/N CAL-RHOM-095

Reflector Far SDH
Max Amplitude/dB -7.2 dB
Sweep 1.55"
Gain (dB) + Log

Calibration Verification

Table with columns: Time, Date, Block(s), Operator. Rows: Initial (0920, 4/11/2005, CAL-DPTH-063, RJ), Verified (1531, 4/22/2005, CAL-RHOM-095, SG), Verified, Verified, Final (2226, 4/22/2005, CAL-RHOM-095, MW)

N2 - 60° RL - Ax Scan

Robert Scott Getz II 4/22/2005
Operator Level Date
Analyst [Signature] III 4-25-05
Level Date

[Signature] III 4/22/05
Utility Review Level Date
[Signature] III 4/22/05
ANIII Review Level Date



GE Energy, Nuclear

ULTRASONIC CALIBRATION DATA SHEET (Automated with Micro TomoScan)

Site Pilgrim Nuclear Power Unit 1

Project RF-015

Report Number APR-009

Calibration Sheet No. APC-075

Weld 2R-N2E-1

Procedure No. TP04-016 (GE-UT-209)

Version R1 (V17) DRR N/A

Instrument Zetec / u Tomo 18121-09 2.2Q14 2.2Q14
Manufacturer / Model System Serial No. Acquisition Software Analysis Software
Pulsar/Receiver R/D Tech EQTX 100 R/D Tech EQTX 101 Digitizer: R/D Tech EQTX 098
Main Board: Manufacturer / Model Piggy Board: Manufacturer / Model
Search Unit RTD 00-349 2(10x18) mm 1.0 MHz 60° / RL 0.59" 60" 0.50"
Manufacturer Serial No. Element Size Freq. (MHz) Angle / Mode FD,FS/SA,RA Measured Incident to
Cable RG-58/RG-58/RG-174 250' / 25' / 3' 2 No. of Intermediate Connectors
Type Length
Calibration Standard CAL-DPTH-063 SS 0.6" 0.6"
Serial No. Material Nominal Thickness Measured Thickness
Thermometer 241878 75 °F Couplant Demin Water N/A
Serial No. Temp. (°F) Type Batch No.

Table with 3 columns for Calibration parameters: Orientation (Circ), Type (SDH), Depth (0.60 in), Amplitude / dB (84.3%, -42.0 dB, -18.8 dB), Sweep (1.18 in), Gain (dB) (32, Log, +25 Log), Screen (Half Path, 25 dB Booster, Active).

Channel Name 60° RL 00-349 P3 / R3
General
Timebase Start 0.0 in Range 5.5 in
Units Half Path

Digitizer
Synchro Pulse [x] A Scan Sample Size 8 Bit
Averaging 1 Acquisition Rate 301 Hz
Digitizing Frequency 6.25 MHz Max Recurrence 2000 Hz

Pulsar / Receiver
Configuration Conventional Pitch Catch
Pulsar P3 Receiver R3
Voltage 300 V Scale Type LOG
Width (Ns) 500 ns Rectification Unsigned
Smoothing 1 MHz

Probe
Wave Type Longitudinal Scan offset -5.20 in.
Velocity 0.2272 in./sec. Index offset 0.00 in.
Wedge Delay 9.597 usec. Angle 60°
Skew 0/180

Field Simulator CS Rompas S/N CAL-RHOM-095
Reflector Near SDH N/A
Max Amplitude/dB -18.8 dB N/A
Sweep 0.78" N/A
Gain (dB) + Log N/A

Table for Calibration Verification with columns: Time, Date, Block(s), Operator. Rows include Initial (0733, 4/23/2005, CAL-DPTH-063, RJ), Verified (1025, 4/23/2005, CAL-RHOM-095, RJ), Verified (1705, 4/23/2005, CAL-RHOM-095, SG), Verified, and Final (0120, 4/24/2005, CAL-RHOM-095, PK).

N2 - 60° RL - Circ Scan

Robert Scott Getz II 4/22/2005
Operator Level Date
Analyst [Signature] III 4-25-05
Level Date

[Signature] II 4/28/05
Utility Review Level Date
[Signature] III 4/26/05
ANIII Review Date

Page 149/240



GE ENERGY, NUCLEAR

EXAMINATION SUMMARY SHEET

Report No.: APR-011

Site: Pilgrim Nuclear Power Station Component ID: 2R-N2G-1
 Outage: RF-015 SAFE END TO NOZZLE
 System RPV ASME Cat.: B-F ASME Item B5.10 Aug Req N/A

Exams Performed	Data Sheet	Cat Sheet	Procedure	Calibration Block	Examination Personnel	Cert Level	Date
45° / S	N/A	APC-059	TP04-016 (GE-UT-209) R1 (V17)	PIL-76	Kyle Davidson	I-L	4/25/2005
45° / RL	N/A	APC-060	TP04-016 (GE-UT-209) R1 (V17)	PIL-78	Kyle Davidson	I-L	4/25/2005
45° / RL	N/A	APC-061	TP04-016 (GE-UT-209) R1 (V17)	PIL-78	Kyle Davidson	I-L	4/25/2005
60° / RL	N/A	APC-062	TP04-016 (GE-UT-209) R1 (V17)	CAL-DPTH-063	Kyle Davidson	I-L	4/25/2005
60° / RL	N/A	APC-063	TP04-016 (GE-UT-209) R1 (V17)	CAL-DPTH-063	Kyle Davidson	I-L	4/25/2005
N/A	APD-006	N/A	TP04-016 (GE-UT-209) R1 (V17)	N/A	Kyle Davidson	I-L	4/25/2005

Examination Results:

During the automated ultrasonic examination of the above referenced dissimilar metal weld, no indications associated with IGSCC were recorded with the "SMART 2000" system utilizing a 45° shear wave, 45° and 60° refracted longitudinal wave search units.

The 45° shear wave examinations were performed from both the upstream and downstream sides of the weld. Root geometry, inside surface geometry, beam redirect and non-relevant indications were recorded.

The 45° RL wave examinations were performed from both the upstream and downstream sides of the weld. Root geometry, acoustic interface, welding discontinuity, inside surface geometry and non-relevant indications were recorded.

The 60° RL wave examinations were performed from both the upstream and downstream sides of the weld. Acoustic interface, inside surface geometry, welding discontinuity, and non-relevant indications were recorded.

A welding discontinuity was detected and sized to IWB 3514-1. It was found to be acceptable. The indication had the following parameters:

Length: 8.83"-12.43"

Through wall: none

This indication was recorded but not reported in the previous automated data.

The outside surface weld crown did not meet procedure requirements from 0° to 4°, 23° to 28°, 31° to 34° and 38° to 42° circumferentially. 71.8% procedural coverage obtained.

75.3% code coverage obtained.

Previous automated electronic data and automated reports and drawings were reviewed prior to this summary.

Examination results were compared to data report 97-E-357 from 1997 outage with No Change

These examinations were performed under Work Order: 03116627 Change

This Summary and the following data sheets have been reviewed and accepted by the following personnel:

Prepared By: [Signature] Level: UT Date: 4-27-05
 Utility Review: [Signature] Date: 4-28-05
 ANII Review: [Signature] Date: 4/29/05

RWP: 0082
Dose: 1250 mr.

Page 1 of 14



GE ENERGY, NUCLEAR

Wall Thickness Profile Sheet

Site: Pillarim Nuclear Power Station Unit: 1

Report No.:

Project: RF-015

APR-011

System: BPV

Component ID Number: 2R-N2G-1



Position	0°	90°	180°	270°
1	1.18"	N/A	N/A	N/A
2	1.17"	N/A	N/A	N/A
3	1.20"	N/A	N/A	N/A
4	1.14"	N/A	N/A	N/A
5	1.16"	N/A	N/A </td <td>N/A</td>	N/A

Crown Height: FLUSH

Crown Width: 1.4"

Nominal Diameter: 12.0"

Weld Length: 42.25"



Safe End (-)

Procedural Exam Volume

Nozzle (+)

Weld preps obtained from drawings; 137C8066 and M1A73 sheet 2
 Bottom of nozzle bore to Inc/CS interface = 4.0"
 Bottom of SE taper to Inc/CS interface = 8.0"

Page 151/240

CB

Charles Barrett II 4/25/2005

Initials: Examiner: Level: Date:

[Signature]

TLL 4-27-05

GE Reviewed By: Level: Date:

[Signature]

UTLV, III 4-28-05

Utility Review: Date:

[Signature]

4/29/05

ANII Review: Date:



GE ENERGY, NUCLEAR

Wall Thickness Profile Sheet

Site: Pilarim Nuclear Power Station Unit: 1

Report No.:

Project: RF-015

APR-011

System: RPV

Component ID Number: 2B-N2G-1



Position	0°	90°	180°	270°
1	1.18"	N/A	N/A	N/A
2	1.17"	N/A	N/A	N/A
3	1.20"	N/A	N/A	N/A
4	1.14"	N/A	N/A	N/A
5	1.16"	N/A	N/A	N/A

Crown Height: FLUSH

Crown Width: 1.4"

Nominal Diameter: 12.0"

Weld Length: 42.25"



Weld preps obtained from drawings; 137C8066 and M1A73 sheet 2
 Bottom of nozzle bore to Inc/CS interface = 4.0"
 Bottom of SE taper to Inc/CS interface = 8.0"

Page 152/240

CB Charles Barrett II 4/25/2005
 Initials: Examiner: Level: Date:

[Signature] III 4/27/05
 GE Reviewed By: Level: Date:

[Signature] UT Lvl. III 4/28/05
 Utility Review: Date:

[Signature] 4/29/05
 ANII Review: Date:



GE ENERGY, NUCLEAR

Indication / Coverage Plot Sheet

Site: Pillarim Nuclear Power Station Unit: 1

Project: RF-015

Report Number.:


APR-011

System: RPV

Component ID Number: 2R-N2G-1

Configuration: SAFE END

NOZZLE




Page 133/240




Charles Barrett II 4/25/2005

Initials: Examiner: Level: Date:




III 4-27-05

GE Reviewed By: Level: Date:



UT Lot. III 4-28-05

Utility Reviewed By: Date:




4/28/05

ANII Reviewed By: Date:



N2G Safe End to Nozzle

45°RL LKUP Welding Discontinuity




*8:59 AM 1/24/15
che/151260*



N2G Safe End to Nozzle

60°RL LKUP Welding Discontinuity




Page 155/240



N2G Safe End to Nozzle

45°RL LKUP Root Geometry



Boqr 156/240



GE Nuclear Energy

Ultrasonic Data / Scan Parameter Sheet
(Automated with Micro TomoScan)

Site: <u>Pilarim Nuclear Power Station</u>	Procedure: <u>TP04-016 (GE-UT-209)</u>	System: <u>RPV</u>	Report No.: <u>APR-011</u>
Unit: <u>1</u>	Version / Revision: <u>R1(V17)</u>	Weld No.: <u>2R-N2G-1</u>	Data Sheet No.: <u>APD-006</u>
Project No.: <u>RF-015</u>	DRR: <u>N/A</u>	Configuration: <u>SAFE END TO NOZZLE</u>	Calibration Sheet No.

Scanner Information

Weld Reference, (GE-ADM-1005): Lo: TDC Wo: Weld Centerline Motor Steps: Cir: 2092 Tra: 2500
 Examination Surface: OD Exam Surface Temperature: 72 °F Thermometer S/N: 241878 Exam Start: 4/25/2005 4:20:00 AM
 Exam End: 4/25/2005 10:16:00 PM

Nominal Pipe Size 12" Nominal Thickness: 1.07" Weld Width: 1.12" Weld Length: .42"
 Scanner: NOVA Track Diameter: 16" Arm Length: 18" Track Location: 7.5" UPST. OF SE TAPER
 X Positive Scan Direction: DOWNSTREAM Y Positive Scan Direction: CW
 Resolution: ≤ 0.036" Index Ax / Circ: ≤ 0.18" ≤ 0.048" Axial Scan Speed: ≤ 1.94 in./Sec. Circ Scan Speed: ≤ 0.98 in./Sec.
 Scanner Zero Positions: CIR: TOP DEAD CENTER TRA: WELD CENTERLINE ROT Zero: LOOKING DOWNSTREAM

Scan Parameters and Results

Scan:	Skew:	File ID:	Disk:	X-Start:	X-Stop:	Y-Start:	Y-Stop:	Gain:	Results:	Comments:
<u>Z10</u>	<u>0</u>	<u>2RN2GZ10</u>	<u>D-10</u>	<u>-4.1"</u>	<u>2.2"</u>	<u>0.0"</u>	<u>43.0"</u>	<u>Log</u>	<u>C,D,E,H</u>	<u>Uni-directional</u>
<u>Z20</u>	<u>180</u>	<u>2RN2GZ20</u>	<u>D-10</u>	<u>-2.4"</u>	<u>4.1"</u>	<u>0.0"</u>	<u>43.0"</u>	<u>Log</u>	<u>C,D,G,E</u>	<u>Uni-directional</u>
<u>Z30</u>	<u>0</u>	<u>2RN2GZ30</u>	<u>D-10</u>	<u>0.0"</u>	<u>43.0"</u>	<u>-2.7"</u>	<u>2.9"</u>	<u>Log</u>	<u>C</u>	<u>Uni-directional</u>
<u>Z40</u>	<u>180</u>	<u>2RN2GZ40</u>	<u>D-10</u>	<u>0.0"</u>	<u>43.0"</u>	<u>-0.6"</u>	<u>2.9"</u>	<u>Log</u>	<u>C</u>	<u>Uni-directional - Downstream side</u>
<u>Z42</u>	<u>180</u>	<u>2RN2GZ42</u>	<u>D-10</u>	<u>0.0"</u>	<u>43.0"</u>	<u>-2.7"</u>	<u>-1.1"</u>	<u>Log</u>	<u>C</u>	<u>Upstream side</u>

EXAMINATION RESULTS LEGEND

A - NO RECORDABLE INDICATIONS	B - NON-GEOMETRIC INDICATIONS	C - NON-RELEVANT INDICATIONS	D - ACOUSTIC INTERFACE
E - INSIDE SURFACE	F - OUTSIDE SURFACE	G - WELD DISCONTINUITY	H - ROOT GEOMETRY
I - COUNTERBORE	J - SHEAR COMPONENT	K - BEAM RE-DIRECT	

Comments:
 High weld crown from a 'L' of 0"- 4", 23"- 28", 31"- 34" and 38"- 42". These areas do not meet the requirements of the procedure.

Page 157/240

Kyle Davidson Examiner:	HL Level:	4/25/2005 Date:	<i>[Signature]</i> GE Review:	HL Level:	4-27-05 Date:	<i>[Signature]</i> UT LVI III Utility Review:	4-28-05 Date:	<i>[Signature]</i> ANII Review:	4/29/05 Date:
----------------------------	--------------	--------------------	----------------------------------	--------------	------------------	---	------------------	------------------------------------	------------------



GE Energy, Nuclear

ULTRASONIC CALIBRATION DATA SHEET (Automated with Micro TomoScan)

Site Pilgrim Nuclear Power Unit 1 Project RF-015 Report Number APR-011 Calibration Sheet No. APC-059 Weld 2R-N2G-1

Procedure No. TP04-016 (GE-UT-209) Version R1 (V17) DRF N/A

Instrument Zetec / uTomo 18121-09 2.2Q14 2.2Q14
Manufacturer / Model System Serial No. Acquisition Software Analysis Software
Pulsar/Receiver R/D Tech EQTX 100 Pulsar/Receiver R/D Tech EQTX 101 Digitizer: R/D Tech EQTX 098
Main Board: Manufacturer / Model Piggy Board: Manufacturer / Model Manufacturer / Model
Search Unit RTD 03-341 ELK(24x17)mm 1.5 MHz 45°/S N/A 45° 0.52°
Manufacturer Serial No. Element Size Freq. (MHz) Angle / Mode FD,FS/SA,RA Measured Incident to
Cable RG-58/RG-58/RG-174 250' / 25' / 3' 2 2 No. of Intermediate Connectors
Type Length Type
Calibration Standard PIL-78 SS 1.2" 1.2"
Serial No. Material Nominal Thickness Measured Thickness
Thermometer 241878 75 °F SS 1.2" 1.2"
Serial No. Couplant Demin Water N/A
Temp (°F) Type Batch No.

Calibration
Orientation Circ Circ
Type ID Notch ID Notch
Depth 1.30 in. 1.30 in.
Amplitude / dB 85.4% -9.4 dB
Sweep 1.91 in. 1.91 in.
Gain (dB) 1.0 Log
Screen Half Path 25 dB Booster Inactive

Channel Name 03-341 45° Shear P2
General
Timebase Start 0.0 in. Range 4.0 in.
Units Half Path

Digitizer
Synchro Pulse [x] A Scan Sample Size 8 Bit
Averaging 1 Acquisition Rate 301 Hz
Digitizing Frequency 12.5 MHz Max Recurrence 2000 Hz

Pulsar / Receiver
Configuration Conventional Pulse Echo
Pulsar P2 Receiver N/A
Voltage 300 V Scale Type LOG
Width (Ns) 333 ns Rectification Unshielded
Smoothing 2 MHz

Probe
Wave Type Transverse Scan offset -2.60 in.
Velocity 0.1240 in./sec. Index offset 0.00 in.
Wedge Delay 11.778 usec. Angle 45°
Skew 0/180

Field Simulator CS Rompas S/N CAL-RHOM-095
Reflector Far SDH
Max Amplitude/dB -19.5 dB
Sweep 1.01"
Gain (dB) Log

Calibration Verification table with columns: Time, Date, Block(s), Operator. Rows include Initial, Verified, and Final entries.

N2 - 45° Shear - Ax/Circ Scan
Ax: Scan offset -0.0" Index offset -2.6"
Circ: Scan offset -2.6" Index offset 0.0"

Kyle Davidson I-L 4/25/2005
Operator Level Date
Analyst TIL 4-27-05
Level Date

Utility Review UT TIL 4-28-05
Level Date
ANIII Review [Signature] TIL 4/28/05
Date

Page 158/240



GE Energy, Nuclear

ULTRASONIC CALIBRATION DATA SHEET (Automated with Micro TomoScan)

Site Pilgrim Nuclear Power Unit 1 Project RF-015 Report Number APR-011 Calibration Sheet No. APC-060 Weld 2R-N2G-1

Procedure No. TP04-016 (GE-UT-209) Version R1 (V17) DRR N/A

Instrument Zetec / u Tomo 18121-09 2.2Q14 2.2Q14 Manufacturer / Model System Serial No. Acquisition Software Analysis Software
Pulsar/Receiver Main Board: R/D Tech EQTX 100 R/D Tech EQTX 101 Digitizer: R/D Tech EQTX 098
Search Unit: RTD 04-302 2(10x18) mm 2.0 MHz 45° / RL 1.00" 45° 0.55" Manufacturer Serial No. Element Size Freq. (MHz) Angle / Mode FD,FS/SA,RA Measured Angle Incident to Wedge Front
Cable RG-58/RG-58/RG-174 250' / 25' / 3' 2 No. of Intermediate Connectors
Calibration Standard PIL-78 SS/INC 1.2" 1.2" Serial No. Material Nominal Thickness Measured Thickness
Thermometer 241878 75 °F Couplant Demin Water N/A Serial No. Temp (°F) Type Batch No.

Table with 4 columns: Orientation, Type, Depth, Amplitude / dB, Sweep, Gain (dB), Screen. Rows include Circ ID Notch 1.30 in. 82.4% 1.85 in. 23.0 Half Path, Circ ID Notch 1.30 in. -32.0 dB 1.85 in. Log 25 dB Booster Active, and Circ ID Notch 1.30 in. -7.2 dB 1.85 in. +25 Log.

Channel Name 45° RL 04-302 P1/R1
General
Timebase Start 0.0 in. Range 4.0 in.
Units Half Path

Digitizer
Synchro Pulse [X] A Scan Sample Size 8 Bit
Averaging 1 Acquisition Rate 301 Hz
Digitizing Frequency 12.5 MHz Max Recurrence 2000 Hz

Pulsar / Receiver
Configuration Conventional Pitch Catch
Pulsar P1 Receiver R1
Voltage 300 V Scale Type LOG
Width (Ns) 250 ns Rectification Unsigned Smoothing 2 MHz

Probe
Wave Type Longitudinal Scan offset 0.00 in.
Velocity 0.2272 in./sec. Index offset 0.00 in.
Wedge Delay 9.675 usec. Angle 45° Skew 0/180

Field Simulator CS Rompas S/N CAL-RHOM-095
Reflector Far SDH
Max Amplitude/dB -5.3 dB
Sweep 1.04"
Gain (dB) Log

Table with 4 columns: Time, Date, Block(s), Operator. Rows include Initial 0900 4/11/2005 PIL 78 RJ, Verified 1840 4/25/2005 CAL-RHOM-095 KD, Verified, Verified, Final 2216 4/25/2005 CAL-RHOM-095 KD.

N2 - 45° RL - Ax Scan

Kyle Davidson I-L 4/25/2005 Operator Level Date Analyst Level Date

Utility Review Level Date ANIII Review Level Date

Page 159/240



GE Energy, Nuclear

ULTRASONIC CALIBRATION DATA SHEET (Automated with Micro TomoScan)

Site Pilgrim Nuclear Power Unit 1 Project RF-015 Report Number APR-011 Calibration Sheet No. APC-061 Weld 2R-N2G-1

Procedure No. TP04-016 (GE-UT-209) Version R1 (V17) DRF N/A

Instrument Zetec / uTomo 18121-09 2.2Q14 2.2Q14 Manufacturer / Model System Serial No. Acquisition Software Analysis Software
Pulsar/Receiver Main Board: R/D Tech EQTX 100 R/D Tech EQTX 101 Digitizer: R/D Tech EQTX 098
Search Unit RTD 04-310 2(10x18)mm 1.0 MHz 45°/RL 0.84° 45° 0.55°
Cable RG-58/RG-58/RG-174 250' / 25' / 3' 2 No. of Intermediate Connectors
Calibration Standard PIL-78 SS/INC 1.3° 1.3° Serial No. Material Nominal Thickness Measured Thickness
Thermometer 241878 75 °F Couplant Demin Water N/A Serial No. Temp (°F) Type Batch No.

Table with 3 columns for Calibration data: Orientation (Circ), Type (ID Notch), Depth (1.30 in), Amplitude / dB (83.9%), Sweep (1.85 in), Gain (dB) (37), Screen (Half Path).

Channel Name 45° RL 04-310 P1/R1
General
Timebase Start 0.0 in. Range 4.0 in. Units Half Path

Digitizer
Synchro Pulse [x] A Scan Sample Size 8 Bit
Averaging 1 Acquisition Rate 301 Hz
Digitizing Frequency 6.25 MHz Max Recurrence 2000 Hz

Pulsar / Receiver
Configuration Conventional Pitch Catch
Pulsar P1 Receiver R1
Voltage 300 V Scale Type LOG
Width (Ns) 500 ns Rectification Unsigned Smoothing 1 Mhz

Field Simulator CS Rompas SN CAL-RHOM-095
Reflector Far SDH
Max Amplitude/dB -17.3 dB
Sweep 1.0"
Gain (dB) + Log

Probe
Wave Type Longitudinal Scan offset 0.00 in.
Velocity 0.2272 in./sec. Index offset 0.00 in.
Wedge Delay 11.170 usec. Angle 45° Skew 0/180

Table for Calibration Verification with columns: Time, Date, Block(s), Operator. Rows include Initial, Verified, and Final entries.

N2 - 45° RL - Circ Scan

Kyle Davidson IL 4/25/2005
Operator Level Date
Analyst III 4-27-05 Level Date

Utility Review III 4-28-05 Level Date
ANIII Review Date

Page 160/240



GE Energy, Nuclear

ULTRASONIC CALIBRATION DATA SHEET (Automated with Micro TomoScan)

Site Pilgrim Nuclear Power Unit 1 Project RF-015 Report Number APR-011 Calibration Sheet No. APC-062 Weld 2R-N2G-1

Procedure No. TP04-016 (GE-UT-209) Version R1 (V17) DRR N/A

Instrument Zetec / uTomo 18121-09 2.2Q14 2.2Q14 Manufacturer / Model System Serial No. Acquisition Software Analysis Software
Pulsar/Receiver R/D Tech EQTX 100 Pulsar/Receiver R/D Tech EQTX 101 Digitizer: R/D Tech EQTX 098 Main Board: Manufacturer / Model Piggy Board: Manufacturer / Model
Search Unit RTD 04-305 2(10x18)mm 2.0 MHz 60°/RL 0.77" 61" 0.52" Manufacturer Serial No. Element Size Freq. (MHz) Angle / Mode FD,FS/SA,RA Measured Incident to Wedge Front Angle Wedge Front
Cable RG-58/RG-58/RG-174 250' / 25' / 13' 2 No. of Intermediate Connectors
Calibration Standard CAL-DPTH-063 SS 0.8" 0.8" Serial No. Material Nominal Thickness Measured Thickness
Thermometer 241878 75°F Couplant Demin Water N/A Serial No. Temp (°F) Type Batch No.

Table with 3 columns for Calibration data: Orientation (Circ), Type (SDH), Depth (0.80 in), Amplitude / dB (81.5%), Sweep (1.65 in), Gain (dB) (24), Screen (Half Path).

Channel Name 60° RL 04-305 P3 / R3
General
Timebase Start 0.0 in Range 5.5 in
Units Half Path

Digitizer
Synchro. Pulse [X] A Scan Sample Size 8 Bit
Averaging 1 Acquisition Rate 301 Hz
Digitizing Frequency 12.5 MHz Max Recurrence 2000 Hz

Pulsar / Receiver
Configuration Conventional Pitch Catch
Pulsar P3 Receiver R3
Voltage 300 V Scale Type LOG
Width (Ns) 250 ns Rectification Unsigned
Smoothing 2 MHz

Probe
Wave Type Longitudinal Scan offset 0.00 in
Velocity 0.2272 in/sec. Index offset -5.20 in
Wedge Delay 10.637 usec. Angle 60°
Skew 0/180

Field Simulator CS Rompas S/N CAL-RHOM-095
Reflector Far SDH
Max Amplitude/dB -7.2 dB
Sweep 1.55"
Gain (dB) + Log

Table for Calibration Verification with columns: Time, Date, Block(s), Operator. Rows include Initial, Verified, and Final entries.

N2 - 60° RL - Ax Scan

Operator Kyle Davidson I-L 4/25/2005 Analyst M. P. ... III 4-27-05 Utility Review ANIII Review 4/28-05 4/29/05 Page 12 of 14

Page 161/240



GE Energy, Nuclear

ULTRASONIC CALIBRATION DATA SHEET (Automated with Micro TomoScan)

Site Pilgrim Nuclear Power Unit 1 Project RF-015 Weld 2R-N2G-1

Report Number APR-011 Calibration Sheet No. APC-063

Procedure No. TP04-016 (GE-UT-209) Versior: R1 (V17) DRF: N/A

Instrument Zetec / uTomo 18121-09 2.2Q14 2.2Q14
Manufacturer / Model System Serial No. Acquisition Software Analysis Software
Pulsar/Receiver RVD Tech EQTX 100 RVD Tech EQTX 101 Digitizer: RVD Tech EQTX 098
Main Board: Manufacturer / Model Piggy Board: Manufacturer / Model
Search Unit RTD 00-349 2(10x18)mm 1.0 MHz 60° / RL 0.59" 60" 0.50"
Manufacturer Serial No. Element Size Freq. (MHz) Angle / Mode FD,FS/SA,RA Measured Incident to
Cable RG-58/RG-58/RG-174 250' / 25' / 3' 2 No. of Intermediate Connectors
Type Length
Calibration Standard CAL-DPTH-063 SS 0.6" 0.6"
Serial No. Material Nominal Thickness Measured Thickness
Thermometer 241878 75°F Couplant Demin Water N/A
Serial No. Temp (°F) Type Eatch No.

Table with 3 columns for Calibration data: Orientation (Circ), Type (SDH), Depth (0.60 in), Amplitude / dB (-18.8 dB), Sweep (1.18 in), Gain (dB) (32), Screen (Half Path).

Channel Name 60° RL 00-349 P3 / R3
General
Timebase Start 0.0 in Range 5.5 in
Units Half Path

Digitizer
Synchro Pulse [X] A Scan Sample Size 8 Bit
Averaging 1 Acquisition Rate 301 Hz
Digitizing Frequency 6.25 MHz Max Recurrence 2000 Hz

Pulsar / Receiver
Configuration Conventional Pitch Catch
Pulsar P3 Receiver R3
Voltage 300 V Scale Type LOG
Width (Ns) 500 ns Rectification Unsigned
Smoothing 1 MHz

Field Simulator CS Rompas S/N CAL-RHOM-095
Reflector Near SDH N/A
Max Amplitude/dB -18.8 dB N/A
Sweep 0.78" N/A
Gain (dB) + Log N/A

Probe
Wave Type Longitudinal Scan offset -5.20 in
Velocity 0.2272 in/sec Index offset 0.00 in
Wedge Delay 10.240 usec Angle 60°
Skew 0/180

Table for Calibration Verification with columns: Time, Date, Block(s), Operator. Rows include Initial, Verified, and Final entries.

Blue / System #1
N2 - 60° RL - Circ Scan

Kyle Davidson I-L 4/25/2005
Operator Level Date
Analyst Level Date

Utility Review ANIII Review
Level Date
Level Date

Page 162/240



GE Energy Nuclear

Micro-Tomo (Smart 2000) - Auto Piping Weld Examination Checklist

**Pilgrim Unit 1, 2005
2R-N2G**

2RN2GZ10 LKDN	Load appropriate setup	Offsets entered into TV correctly	Transducers Skewed IAW Procedure	Files named IAW Scanplan	360° contact achieved	360° Circ coverage achieved	Full Volume Ax Coverage Achieved	Scan saved to computer HD Verified readable	Data transferred to DA Verified received by DA	Data Reviewed	Analysis Complete	Package Complete	<u>NOTES:</u>
45° Shear	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	KD	MW	MJK	MJK	MJK	
45° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	MJK			MJK	MJK		
60° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	MJK			MJK	MJK		
2RN2GZ20 LKUP	Load appropriate setup	Offsets entered into TV correctly	Transducers Skewed IAW Procedure	Files named IAW Scanplan	360° contact achieved	360° Circ coverage achieved	Full Volume Ax Coverage Achieved	Scan saved to computer HD Verified readable	Data transferred to DA Verified received by DA	Data Reviewed	Analysis Complete	Package Complete	<u>NOTES:</u>
45° Shear	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	KD	KD	MJK	MJK	MJK	
45° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	MJK			MJK	MJK		
60° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	MJK			MJK	MJK		
2RN2GZ30 LKCW	Load appropriate setup	Offsets entered into TV correctly	Transducers Skewed IAW Procedure	Files named IAW Scanplan	360° contact achieved	360° Circ coverage achieved	Full Volume Ax Coverage Achieved	Scan saved to computer HD Verified readable	Data transferred to DA Verified received by DA	Data Reviewed	Analysis Complete	Package Complete	<u>NOTES:</u>
45° Shear	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	SG	SG	MJK	MJK	MJK	
45° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	MJK			MJK	MJK		
60° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	MJK			MJK	MJK		
2RN2GZ40 LKCCW	Load appropriate setup	Offsets entered into TV correctly	Transducers Skewed IAW Procedure	Files named IAW Scanplan	360° contact achieved	360° Circ coverage achieved	Full Volume Ax Coverage Achieved	Scan saved to computer HD Verified readable	Data transferred to DA Verified received by DA	Data Reviewed	Analysis Complete	Package Complete	<u>NOTES:</u>
45° Shear	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	SG	SG	MJK	MJK	MJK	
45° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	MJK			MJK	MJK		
60° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	MJK			MJK	MJK		
Notes: Weld profile does not meet procedural requirements from 0"-4", 23"-28", 31"-34" and 38"-42"													

Page 163/240

[Signature] UT L-1. III 4-28-05



GE ENERGY, NUCLEAR

EXAMINATION SUMMARY SHEET

Report No.:
APR-012

Site: Pilgrim Nuclear Power Station Component ID: 2R-N2J-1
 Outage: RF-015 SAFE END TO NOZZLE
 System RPV ASME Cat.: B-F ASME Item B5.10 Aug Req N/A

Exams Performed	Data Sheet	Cal Sheet	Procedure	Calibration Block	Examination Personnel	Cert Level	Date
45° / RL	N/A	APC-066	TP04-016 (GE-UT-209) R1 (V17)	PIL-7E	Kyle Davidson	I-L	4/25/2005
45° / RL	N/A	APC-067	TP04-016 (GE-UT-209) R1 (V17)	PIL-78	Richard Jasken	II	4/27/2005
60° / RL	N/A	APC-068	TP04-016 (GE-UT-209) R1 (V17)	CAL-DPTH-063	Kyle Davidson	I-L	4/25/2005
60° / RL	N/A	APC-069	TP04-016 (GE-UT-209) R1 (V17)	CAL-DPTH-063	Richard Jasken	II	4/27/2005
45° / S	N/A	APC-065	TP04-016 (GE-UT-209) R1 (V17)	PIL-78	Richard Jasken	II	4/27/2005
N/A	APD-008	N/A	TP04-016 (GE-UT-209) R1 (V17)	N/A	Richard Jasken	II	2/27/2005

Examination Results:

During the automated ultrasonic examination of the above referenced dissimilar metal weld, no indications associated with IGSCC or any reportable indications were recorded with the "SMART 2000" system utilizing a 45° shear wave and 45° & 60° refracted longitudinal wave search units.

The 45° shear wave examinations were performed from both the upstream and downstream sides of the weld. Root geometry, beam redirect and non-relevant indications were recorded.

The 45° RL wave examinations were performed from both the upstream and downstream sides of the weld. Root geometry, acoustic interface, inside surface geometry and non-relevant indications were recorded.

The 60° RL wave examinations were performed from both the upstream and downstream sides of the weld. Inside surface geometry and non-relevant indications were recorded.

The outside surface weld crown did not meet procedure requirements from 13" to 30" on the upstream side of weld centerline and from 0" to 42.0" on the downstream side of the weld centerline to a "W" of 1:10".

65.7% procedural coverage was obtained.
75% code coverage was obtained.

Previous automated reports and drawings were reviewed prior to this summary.

Examination results were compared to data report 95-E-434 from 1995 outage with No Change

These examinations were performed under Work Order: 03116627 Change

This Summary and the following data sheets have been reviewed and accepted by the following personnel:

Prepared By: [Signature] Level: III Date: 4-28-05
 Utility Review: [Signature] Date: 4-29-05
 ANII Review: [Signature] Date: 4/29/05

RWP: 0082
Dose: 1500 mr.

Page 1 of 13

Page 164/240



GE ENERGY, NUCLEAR

Wall Thickness Profile Sheet

Site: Pilarim Nuclear Power Station Unit: 1
Project: RF-015



Report No.:
APR-012

System: RPV

Component ID Number: 2R-N2-I-1

Position	0°	90°	180°	270°
1	1.11"	N/A	N/A	N/A
2	1.11"	N/A	N/A	N/A
3	1.13"	N/A	N/A	N/A
4	1.10"	N/A	N/A	N/A
5	1.14"	N/A	N/A	N/A

Crown Height: 0.1"
Crown Width: 1.8"
Nominal Diameter: 12.0"
Weld Length: 42.0"



Safe End (-)

Procedural Exam Volume

Nozzle (+)

Weld preps obtained from drawings; 137C8066 and M1A73 sheet 2
Bottom of nozzle bore to Inc/CS interface = 4.1"
Bottom of SE taper to Inc/CS interface = 7.5"

Page 165/240

Michael Krueger III 4/27/2005
Initials: Examiner: Level: Date:

[Signature] III 4-29-05
GE Reviewed By: Level: Date:

[Signature] UT Lvl III 4-29-05
Utility Review: Level: Date:

[Signature] 4/29/05
ANII Review: Date:



GE ENERGY, NUCLEAR

Wall Thickness Profile Sheet

Site: Pilaris Nuclear Power Station Unit: 1
Project: RF-015



Report No.: APR-012

System: RPV

Component ID Number: 2R-N2-L-1

Position	0°	90°	180°	270°
1	1.11"	N/A	N/A	N/A
2	1.11"	N/A	N/A	N/A
3	1.13"	N/A	N/A	N/A
4	1.10"	N/A	N/A	N/A
5	1.14"	N/A	N/A	N/A

Crown Height: 0.1"
Crown Width: 1.8"
Nominal Diameter: 12.0"
Weld Length: 42.0"



The scans above show the limited areas. The entire volume was scanned.
Weld preps obtained from drawings; 137C8066 and M1A73 sheet 2
Bottom of nozzle bore to Inc/CS interface = 4.1"
Bottom of SE taper to Inc/CS interface = 7.5"

Page 166/240

Michael Krueger III 4/27/2005
Initials: Examiner: Level: Date:

Michael Krueger III 4-29-05
GE Reviewed By: Level: Date:

Michael Krueger III 4-29-05
Utility Review: Level: Date:

Michael Krueger III 4/28/05
ANII Review: Date:



GE ENERGY, NUCLEAR

Indication / Coverage Plot Sheet

Site: Pilarim Nuclear Power Station Unit: 1

Report Number.:

Project: BE-015

APR-012

System: RPV

Component ID Number: 2R-N2-L1

Configuration: SAFE END

NOZZLE

0° TDC

ENC/CS

90°

ENC/CS

180°

ENC/CS

270°

ENC/CS

Boag 167/2470

MK Michael Krueger III 4/27/2005
Initials: Examiner: Level: Date:

[Signature] JH 4-29-05
GE Reviewed By: Level: Date:


[Signature] HT L. J. III 4-29-05
Utility Reviewed By: Date:

[Signature] 4/29/05
ANII Reviewed By: Date:



N2J Safe End to Nozzle

45°RL LKDN Root Geometry




Page 168/240

Handwritten notes: 1.45 10.00 21. 4.25 15



N2J Safe End to Nozzle

45°RL LKDN Acoustic Interface



Page 169/240

Handwritten notes and signatures at the bottom of the page.



GE Nuclear Energy

Ultrasonic Data / Scan Parameter Sheet
(Automated with Micro TomoScan)

Site: <u>Pilaris Nuclear Power Station</u>	Procedure: <u>TP04-016 (GE-UT-209)</u>	System: <u>RPV</u>	Report No.: <u>APR-012</u>
Unit: <u>1</u>	Version / Revision: <u>R1 (V17)</u>	Weld No.: <u>2R-N2-L-1</u>	Data Sheet No.: <u>APD-008</u>
Project No.: <u>RF-015</u>	DRR: <u>N/A</u>	Configuration: <u>SAFE END TO NOZZLE</u>	Calibration Sheet No.

Scanner Information

Weld Reference, (GE-ADM-1005): Lo: <u>IDC</u> Wo: <u>Weld Centerline</u> Motor Steps: Cir: <u>2076</u> Tra: <u>2500</u>
Examination Surface: <u>OD</u> Exam Surface Temperature: <u>81</u> °F Thermometer S/N: <u>241878</u> Exam Start: <u>4/25/2005 11:30:00 PM</u> Exam End: <u>4/27/2005 11:07:00 AM</u>
Nominal Pipe Size <u>12"</u> Nominal Thickness: <u>1.10"</u> Weld Width: <u>1.8"</u> Weld Length: <u>42"</u>
Scanner: <u>NOVA</u> Track Diameter: <u>16"</u> Arm Length: <u>18"</u> Track Location: <u>15.5" UPST FROM CS/INC INTERFACE</u>
X Positive Scan Direction: <u>DOWNSTREAM</u> Y Positive Scan Direction: <u>CW</u>
Resolution: <u>≤ 0.036"</u> Index Ax / Circ: <u>≤ 0.18" ≤ 0.049"</u> Axial Scan Speed: <u>≤ 2.0 in./Sec.</u> Circ Scan Speed: <u>≤ 1.0 in./Sec.</u>
Scanner Zero Positions: CIR: <u>TOP DEAD CENTER</u> TRA: <u>WELD CENTERLINE</u> ROT Zero: <u>LOOKING DOWNSTREAM</u>

Scan Parameters and Results

Scan:	Skew:	File ID:	Disk:	X-Start:	X-Stop:	Y-Start:	Y-Stop:	Gain:	Results:	Comments:
<u>Z10</u>	<u>0</u>	<u>2RN2JZ10</u>	<u>D-13</u>	<u>-4.1"</u>	<u>2.4"</u>	<u>0.0"</u>	<u>43.0"</u>	<u>Log</u>	<u>C,D,H,E</u>	<u>Uni-directional</u>
<u>Z20</u>	<u>180</u>	<u>2RN2JZ20</u>	<u>D-13</u>	<u>-2.4"</u>	<u>4.2"</u>	<u>0.0"</u>	<u>43.0"</u>	<u>Log</u>	<u>C,E</u>	<u>Uni-directional</u>
<u>Z30</u>	<u>0</u>	<u>2RN2JZ30</u>	<u>D-13</u>	<u>0.0"</u>	<u>43.0"</u>	<u>-2.7"</u>	<u>2.9"</u>	<u>Log</u>	<u>C,E</u>	<u>Uni-directional*</u>
<u>Z40</u>	<u>180</u>	<u>2RN2JZ40</u>	<u>D-13</u>	<u>0.0"</u>	<u>43.0"</u>	<u>-2.7"</u>	<u>2.9"</u>	<u>Log</u>	<u>C,E</u>	<u>Uni-directional*</u>

EXAMINATION RESULTS LEGEND

- A - NO RECORDABLE INDICATIONS B - NON-GEOMETRIC INDICATIONS C - NON-RELEVANT INDICATIONS D - ACOUSTIC INTERFACE
- E - INSIDE SURFACE F - OUTSIDE SURFACE G - WELD DISCONTINUITY H - ROOT GEOMETRY
- I - COUNTERBORE J - SHEAR COMPONENT K - BEAM RE-DIRECT

Comments:
 * Inside surface geometry outside the exam volume.
 LKDN limited from a 'L' of 13" to 30" on the upstream side of the weld centerline due to the OD contour.
 LKUP limited from a 'L' of 0" to 42.0" on the downstream side of the weld centerline due to the OD contour.

Page 170/240

Richard Jaeken	11	4/27/2005	<i>[Signature]</i>	4-28-05	<i>[Signature]</i>	4-29-05	<i>[Signature]</i>	9/29/05
Examiner:	Level:	Date:	GE Review:	Level:	Date:	Utility Review:	Date:	ANII Review: Date:



GE Energy, Nuclear

ULTRASONIC CALIBRATION DATA SHEET (Automated with Micro TomoScan)

Site Pilgrim Nuclear Power Unit 1 Project RF-015 Report Number APR-012 Calibration Sheet No. APC-065 Weld 2R-N2J-1

Procedure No. TP04-016 (GE-UT-209) Version R1 (V17) DRP N/A

Instrument Zetec / uTomo 18121-09 2.2Q14 2.2Q14 Manufacturer / Model System Serial No. Acquisition Software Analysis Software. Pulser/Receiver R/D Tech EQTX-100 R/D Tech EQTX 101 Digitizer: R/D Tech EQTX 098 Main Board: Manufacturer / Model Manufacturer / Model Search Unit RTD 03-341 EII(24x17)mm 1.5 MHz 45°/S N/A 45° 0.52° Manufacturer Serial No. Element Size Freq. (MHz) Angle / Mode FD,FS/SA,RA Measured Angle Incident to Wedge Front Cable RG-58/RG-58/RG-174 250' / 25' / 3' 2 No. of Intermediate Connectors Calibration Standard PIL-78 SS 1.3" 1.3" Serial No. Material Nominal Thickness Measured Thickness Thermometer 241878 75 °F Couplant Demin Water N/A Serial No. Temp (°F) Type Batch No.

Calibration Orientation Circ Circ Type ID Notch ID Notch Depth 1.30 in. 1.30 in. Amplitude / dB 85.4% -2.4 dB Sweep 1.91 in. 1.91 in. Gain (dB) 1.0 Log Screen Half Path 25 dB Booster Inactive

Channel Name 03-341 45° Shear P2 General Timebase Start 0.0 in. Range 4.0 in. Units Half Path

Digitizer Synchro Pulse [X] A Scan Sample Size 8 Bit Averaging 1 Acquisition Rate 301 Hz Digitizing Frequency 12.5 MHz Max Recurrence 2000 Hz

Pulser / Receiver Configuration Conventional Pulse Echo Pulser P2 Receiver N/A Voltage 300 V Scale Type LOG Width (Ns) 333 ns Rectification Unsigned Smoothing 2 MHz

Field Simulator CS Rompac S/N CAL-RHOM-095 Reflector Far SDH Max Amplitude/dB -19.5 dB Sweep 1.01" Gain (dB) Log

Probe Wave Type Transverse Scan offset Velocity 0.1240 in./sec. Index offset Wedge Delay 11.778 usec. Angle 45° Skew 0/180

Calibration Verification table with columns: Time, Date, Block(s), Operator. Rows: Initial (0847, 4/11/2005, PIL 78, RJ), Verified (2214, 4/25/2005, CAL-RHOM-095, KD), Verified (0142, 4/26/2005, CAL-RHOM-095, KD), Verified, Final (1106, 4/27/2005, CAL-RHOM-095, RJ)

N2 - 45° Shear - Ax/Circ Scan Ax scan offset 0.0° Index Offset -2.6° Circ scan offset -2.60° Index Offset -2.7°

Richard Jasken II 4/27/2005 Operator Level Date Analyst [Signature] Level 4-28-05 Date

Utility Review [Signature] Level Date ANIII Review [Signature] Level Date

Page 171/240



GE Energy, Nuclear

ULTRASONIC CALIBRATION DATA SHEET (Automated with Micro TomoScan)

Site Pilgrim Nuclear Power Unit 1 Project RF-015 Report Number APR-012 Calibration Sheet No. APC-066 Weld 2R-N2J-1

Procedure No. TP04-016 (GE-UT-209) Version R1 (V17) DRF N/A

Instrument Zetec / uTomo 18121-09 2.2014 2.2014 Manufacturer / Model System Serial No. Acquisition Software Analysis Software Pulser/Receiver Main Board R/D Tech EQTX 100 R/D Tech EQTX 101 Digitizer: R/D Tech EQTX 098 Manufacturer / Model Search Unit RTD 04-302 2(10x18)mm 2.0 MHz 45°/RL 1.00° 45° 0.55° Manufacturer Serial No. Element Size Freq. (MHz) Angle / Mode FD,FS/SA,RA Measured Angle Incident to Wedge Front Cable RG-58/RG-58/RG-174 250' / 25' / 3' Length 2 No. of Intermediate Connectors Calibration Standard PIL-78 SSANC 1.3" 1.3" Serial No. Material Nominal Thickness Measured Thickness Thermometer 241878 75°F Couplant Demin Water N/A Serial No. Temp (°F) Type Batch No.

Calibration table with columns for Orientation, Type, Depth, Amplitude / dB, Sweep, Gain (dB), Screen. Values include Circ, ID Notch, 1.30 in., 82.4%, 1.85 in., 23.0, Half Path.

Channel Name 45° RL 04-302 P1/R1 General Timebase Start 0.0 in. Range 4.0 in. Units Half Path

Digitizer Synchro Pulse A Scan Sample Size 8 Bit Averaging 1 Acquisition Rate 301 Hz Digitizing Frequency 12.5 MHz Max Recurrence 2000 Hz

Pulser / Receiver Configuration Conventional Pitch Catch Pulser P1 Receiver R1 Voltage 300 V Scale Type LOG Width (Ns) 250 ns Rectification Unsigned Smoothing 2 MHz

Field Simulator CS Rompas S/N CAL-RHOM-095 Reflector Far SDH Max Amplitude/dB -5.3 dB Sweep 1.04" Gain (dB) Log

Probe Wave Type Longitudinal Scan offset 0.00 in. Velocity 0.2272 in./sec. Index offset 0.00 in. Wedge Delay 9.675 usec. Angle 45° Skew 0/180

Calibration Verification table with columns for Time, Date, Block(s), Operator. Rows include Initial, Verified, Verified, Verified, Final.

N2 - 45° RL - Ax Scan

Operator Kyle Davidson I-L 4/26/2005 Utility Review ANIII Review Analyst [Signature] Level Date 4-28-05 Level Date 4-29-05 Page 2 of 13

Page 172/240



GE Energy, Nuclear

ULTRASONIC CALIBRATION DATA SHEET (Automated with Micro TomoScan)

Site Pilgrim Nuclear Power Unit 1 Project RF-015 Report Number APR-012 Calibration Sheet No. APC-067 Weld 2R-N2J-1

Procedure No. TP04-016 (GE-UT-209) Version R1 (V17) DRR N/A

Instrument Zetec / uTomo 18121-09 2.2Q14 2.2Q14 Manufacturer / Model System Serial No. Acquisition Software Analysis Software Pulser/Receiver R/D Tech EQTX 100 R/D Tech EQTX 101 Digitizer: R/D Tech EQTX 098 Main Board: Manufacturer / Model Piggy Board: Manufacturer / Model Search Unit RTD 04-310 2(10x18) mm 1.0 MHz 45 / RL 0.64 45 0.55 Manufacturer Serial No. Element Size Freq. (MHz) Angle / Mode FD,FS/SA,RA Measured Angle Incident to Wedge Front Cable RG-58/RG-58/RG-174 250 / 25 / 3 2 No. of Intermediate Connectors Calibration Standard PIL-78 SSINC 1.3 1.3 Serial No. Material Nominal Thickness Measured Thickness Thermometer 241878 75 F Couplant Demin Water N/A Serial No. Temp (F) Type Batch No.

Table with 3 columns for Calibration data: Orientation (Circ), Type (ID Notch), Depth (1.30 in), Amplitude / dB (83.9%, -46.4 dB, -23.5 dB), Sweep (1.85 in), Gain (dB) (37, Log, +25 Log), Screen (Half Path, 25 dB Booster, Active)

Channel Name 45 RL 04-310 P1/R1

General Timebase Start 0.0 in Range 4.0 in Units Half Path

Digitizer Synchro Pulse A Scan Sample Size 8 Bk Averaging 1 Acquisition Rate 301 Hz Digitizing Frequency 6.25 MHz Max Recurrence 2000 Hz

Pulser / Receiver Configuration Conventional Pitch Catch Pulser P1 Receiver R1 Voltage 300 V Scale Type LOG Width (Ns) 500 ns Rectification Unsigned Smoothing 1 MHz

Probe Wave Type Longitudinal Scan offset 0.00 in Velocity 0.2272 in/sec Index offset -2.70 in Wedge Delay 11.170 usec Angle 45 Skew 0/180

Field Simulator CS Rompas S/N CAL-RHOM-095

Reflector Far SDH Max Amplitude/dB -17.3 dB Sweep 1.0 Gain (dB) + Log

Table with 5 columns: Time, Date, Block(s), Operator. Rows: Initial (0708, 4/23/2005, PIL 78, RJ), Verified (2212, 4/25/2005, CAL-RHOM-095, KD), Verified, Verified, Final (1105, 4/27/2005, CAL-RHOM-095, RJ)

N2 - 45 RL - Circ Scan

Richard Jasken II 4/27/2005 Operator Level Date Utility Review Analyst [Signature] III 4-28-05 Level Date ANIII Review [Signature] III 4-29-05 Level Date Date Page 10 of 13

Page 173/240



GE Energy, Nuclear

ULTRASONIC CALIBRATION DATA SHEET (Automated with Micro TomoScan)

Site Pilgrim Nuclear Power Unit 1 Project RF-015 Weld 2R-N2J-1

Report Number APR-012 Calibration Sheet No. APC-068

Procedure No. TP04-016 (GE-UT-209) Version R1 (V17) DRF N/A

Instrument Zetec / uTomo 18121-09 2-2Q14 2-2Q14
Manufacturer / Model System Serial No. Acquisition Software Analysis Software
Pulsar/Receiver R/D Tech EQTX 100 R/D Tech EQTX 101 Digitizer: R/D Tech EQTX 098
Main Board: Manufacturer / Model Piggy Board: Manufacturer / Model
Search Unit RTD 04-305 2(10x18) mm 2.0 MHz 60° / RL 0.77° 61° 0.52°
Manufacturer Serial No. Element Size Freq. (MHz) Angle / Mode FD,FS/SA,RA Measured Incident to
Cable RG-58/RG-58/RG-174 250' / 25' / 3' 2 No. of Intermediate Connectors Angle Wedge Front
Calibration Standard CAL-DPTH-063 SS 0.8" 0.8"
Serial No. Material Nominal Thickness Measured Thickness
Thermometer 241878 75 °F Couplant Demin Water N/A
Serial No. Temp (°F) Type Batch No.

Table with 3 columns for Calibration data: Orientation (Circ, Circ, Circ), Type (SDH, SDH, SDH), Depth (0.80 in, 0.80 in, 0.80 in), Amplitude / dB (81.5%, -33.9 dB, -9.4 dB), Sweep (1.65 in, 1.65 in, 1.65 in), Gain (dB) (24, Log, +25 Log), Screen (Half Path, 25 dB Booster, Active)

Channel Name 60° RL 04-305 P3 / R3
General
Timebase Start 0.0 in Range 5.5 in
Units Half Path

Digitizer
Synchro Pulse [X] A Scan Sample Size 8 Bit
Averaging 1 Acquisition Rate 301 Hz
Digitizing Frequency 12.5 MHz Max Recurrence 2000 Hz

Pulsar / Receiver
Configuration Conventional Pitch Catch
Pulsar P3 Receiver R3
Voltage 300 V Scale Type LOG
Width (Ns) 250 ns Rectification Unsigned
Smoothing 2 MHz

Field Simulator CS Rompage S/N CAL-RHOM-095
Reflector Far SDH
Max Amplitude/dB -7.2 dB
Sweep 1.55"
Gain (dB) + Log

Probe
Wave Type Longitudinal Scan offset 0.00 in
Velocity 0.2272 in/sec. Index offset -5.20 in
Wedge Delay 10.640 usec. Angle 60°
Skew 0/180

Table for Calibration Verification with columns: Time, Date, Block(s), Operator. Rows include Initial, Verified, Verified, Verified, Final.

N2 - 60° RL - Ax Scan

Kyle Davidson I-L 4/26/2005
Operator Level Date
Analyst Level Date

Utility Review Level Date
ANIII Review Level Date

Page 174/240



GE Energy, Nuclear

ULTRASONIC CALIBRATION DATA SHEET (Automated with Micro TomoScan)

Site Pilgrim Nuclear Power Unit 1 Project RF-015 Report Number APR-012 Calibration Sheet No. APC-069 Weld 2R-N2J-1

Procedure No. TPM-016 (GE-UT-209) Version R1 (V17) DRR N/A

Instrument Zetec / uTomo 18121-09 2.2Q14 2.2Q14 Manufacturer / Model System Serial No. Acquisition Software Analysis Software Pulser/Receiver R/D Tech EQTX 100 R/D Tech EQTX 101 Digitizer: R/D Tech EQTX 098 Main Board: Manufacturer / Model Piggy Board: Manufacturer / Model Search Unit RTD 00-349 2(10x18)mm 1.0 MHz 60°/RL 0.59° 60° 0.50° Manufacturer Serial No. Element Size Freq. (MHz) Angle / Mode FD,FS/SA,RA Measured Angle Incident to Wedge Front Cable RG-58/RG-58/RG-174 250' / 25' / 13' 2 No. of Intermediate Connectors Calibration Standard CAL-DPTH-063 SS 0.6° 0.6° Serial No. Material Nominal Thickness Measured Thickness Thermometer 24187F 75 °F Couplant Demin Water N/A Serial No. Type Batch No.

Calibration table with columns for Orientation, Type, Depth, Amplitude, Sweep, Gain, and Screen. Values include Circ, SDH, 0.60 in, 84.3%, 1.18 in, 32, Half Path, etc.

Channel Name 60° RL 00-349 P3 / R3 General Timebase Start 0.0 in Range 5.5 in Units Half Path

Digitizer Synchro Pulse A Scan Sample Size 8 Bit Averaging 1 Acquisition Rate 301 Hz Digitizing Frequency 6.25 MHz Max Recurrence 2000 Hz

Pulser / Receiver Configuration Conventional Pitch Catch Pulser P3 Receiver R3 Voltage 300 V Scale Type LOG Width (Ns) 500 ns Rectification Unsigned Smoothing 1 MHz

Probe Wave Type Longitudinal Scan offset -5.20 in Velocity 0.2272 in/sec Index offset -2.70 in Wedge Delay 10.240 usec Angle 60° Skew 0/180

Field Simulator CS Rompas S/N CAL-RHOM-095 Reflector Near SDH N/A Max Amplitude/dB -18.8 dB N/A Sweep 0.78° N/A Gain (dB) + Log N/A

Calibration Verification table with columns for Time, Date, Block(s), and Operator. Rows include Initial, Verified, and Final entries.

N2 - 60° RL - Circ Scan

Richard Jasken II 4/27/2005 Operator Level Date Utility Review Level Date Analyst Level Date ANIII Review Level Date Page 12 of 13

Page 175/240



GE Energy Nuclear

Micro-Tomo (Smart 2000) - Auto Piping Weld Examination Checklist

Pilgrim Unit 1, 2005
2R-N2J

2RN2JZ10 LKDN	Load appropriate setup	Offsets entered into TV correctly	Transducers Skewed IAW Procedure	Files named IAW Scanplan	360° contact achieved	360° Circ coverage achieved	Full Volume Ax Coverage Achieved	Scan saved to computer HD Verified readable	Data transferred to DA Verified received by DA	Data Reviewed	Analysis Complete	Package Complete	<u>NOTES:</u>
45° Shear	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	MW	MW	MJK	MJK	MJK	
45° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			MJK	MJK	MJK	
60° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			MJK	MJK	MJK	
2RN2JZ20 LKUP	Load appropriate setup	Offsets entered into TV correctly	Transducers Skewed IAW Procedure	Files named IAW Scanplan	360° contact achieved	360° Circ coverage achieved	Full Volume Ax Coverage Achieved	Scan saved to computer HD Verified readable	Data transferred to DA Verified received by DA	Data Reviewed	Analysis Complete	Package Complete	<u>NOTES:</u>
45° Shear	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	MW	MW	MJK	MJK	MJK	
45° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			MJK	MJK	MJK	
60° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			MJK	MJK	MJK	
2RN2JZ30 LKCW	Load appropriate setup	Offsets entered into TV correctly	Transducers Skewed IAW Procedure	Files named IAW Scanplan	360° contact achieved	360° Circ coverage achieved	Full Volume Ax Coverage Achieved	Scan saved to computer HD Verified readable	Data transferred to DA Verified received by DA	Data Reviewed	Analysis Complete	Package Complete	<u>NOTES:</u>
45° Shear	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	SG	SG	MJK	MJK	MJK	
45° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			MJK	MJK	MJK	
60° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			MJK	MJK	MJK	
2RN2JZ40 LKCCW	Load appropriate setup	Offsets entered into TV correctly	Transducers Skewed IAW Procedure	Files named IAW Scanplan	360° contact achieved	360° Circ coverage achieved	Full Volume Ax Coverage Achieved	Scan saved to computer HD Verified readable	Data transferred to DA Verified received by DA	Data Reviewed	Analysis Complete	Package Complete	<u>NOTES:</u>
45° Shear	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	SG	SG	MJK	MJK	MJK	
45° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			MJK	MJK	MJK	
60° RL	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			MJK	MJK	MJK	

Notes: Transducer liftoff due to the outside surface contour. See the data sheet for parameters

Page 176/240


MJK 11/11/05 4-21-05

UT CALIBRATION DATA SHEET

C.D.S. NO. 99-C-547
 U.T.V. NO. 0027A
 L.D.S. NO. 99-L-351

PROCEDURE NO. QCI 50.71 REV. 4 DATE 5/22/99
 EXAMINATION PERSONNEL: NAME Paul Kelly LEVEL II NAME Timothy La LEVEL II
 INSTRUMENT DATA: MAKE STANLEY MODEL 5000 136 SERIAL NO. 136-549 G
 SEARCH UNIT DATA: MANUFACTURER KBA TYPE M5WQL GAMMA
 SERIAL NO. 002444 SIZE .50" FREQUENCY 225 MHz
 BEAM ANGLE 45° BEAM MODE 6WEP WEDGE TYPE LUCITE
 TABLE DATA: LENGTH 6' TYPE R6-17A
 IMPLANT DATA: TYPE ULTRALUM II BATCH NO. 98275
 CALIBRATION STANDARD DATA: SERIAL NO. PW-17A THICKNESS 1.0" DIAMETER 12"
 MATERIAL CS SA-106 GR. B
 REFLECTOR DATA: TYPE None SIZE .100d x .125w x 1.0L
 ORIENTATION (TO PIPE AXIS) 61deg
 OR DUAL ELEMENT TRANSDUCERS: SPLIT ORIENTATION (TO HOLE CENTERLINE) FOR
 MAXIMUM RESPONSE
 PARALLEL AMPLITUDE N/A TRANSVERSE AMPLITUDE N/A

C CURVE-SCREEN REPRESENTATION



CALIBRATION TIME - RECORDS					
00	01	02	03	04	05
ORIG. DATE	CAL. DATE	CHECK - TIME	E.D.S. #	E.D.S. LINE #	VERIFY 25°F LIMIT YES/NO
5/22/99	1100	1535	99-E-548 (4)	192	464

I.D. OF WELD/COMPONENT

- G-N4A-1
- G-N4B-1
- G-N4C-1
- G-N4D-1

SWEEP RANGE POSITION OR METAL PATH
 10 @ 27 @ 40 @ 32.0dB
 0 @ 62.7 @ 20 @ 32.0dB
 REFERENCE GAIN 33.0dB
 SCANNING GAIN 46.0dB
 REVIEWED BY: Chip Shaver h.v. III DATE 5/25/99
 DATA REVIEWER

ASME SECTION XI EXAMINATION; YES - ANII SIGNATURE REQUIRED
 NO - ANII SIGNATURE NOT REQUIRED

ACCEPTED BY: B Perkins DATE 5/26/99
 BECO LEVEL III OR DESIGNER

REVIEWED BY: [Signature] DATE 5-26-99
 ANII

BOSTON EDISON COMPANY
ULTRASONIC EXAMINATION DATA SHEET

EXAMINATION PERSONNEL:

Exam proc. 5011 Rev. 4

Name [Signature] Level II

M. R. No. 19702057

EDS No. 99-E-548

Name [Signature] Level II

Couplant ULTAZONE II 98325

CDS No. 99-C-547

Scanning Gain 460dB

L.D.S. 99-L-351

Beam Angle 45°

(W) DIMENSION (L) DIMENSION

UTV No. 0027A

DATE 5/26/99

WELD COMP#	CONFIG	IND #	SCAN NO. DIRECTION & SURFACE	MAX. AMP.	LO WO	W _m SP _m	L ₁ SP _{L1}	L _m	L ₂ SP _{L2}	TIME OF EXAM START	STOP	COMP. TEMP.	REMARKS
G-N4A-1	SE-NOZ	N/A	I/+/-							1337	1342	78°F	N21
G-N4A-1	SE-NOZ	N/A	I/-/+			N				1342	1347	78°F	N21
G-N4B-1	SE-NOZ	N/A	I/+/-				A			1245	1250	78°F	N21
G-N4B-1	SE-NOZ	N/A	I/-/+				I			1250	1255	78°F	N21
	N	A			N			A			N	A	

Components meet ASME Section XI Acceptance Criteria: Yes

ASME Section XI Examination:

YES NO → FURTHER EVALUATION REQUIRED

YES-ANII Signature Required
 NO-ANII Signature Not Required

REMARKS: N LIMITED EXAMINATION BETWEEN 26.625" TO 29.625" AND 31.875" TO 34.625" DUE TO THERMAL COUPLER PROBS ON WELDS

Evaluated By: [Signature] Level III Date 5/25/99

Accepted By: [Signature] Level III Date 5/26/99
BeCo Level III or Designee

ANII Review By: [Signature] Date 5-26-99

Boyer 178/240

BOSTON EDISON COMPANY
ULTRASONIC EXAMINATION DATA SHEET

EXAMINATION PERSONNEL:

Name *Phillips* Level *II*
 Name *Jamir Maso* Level *IV*
 Beam Angle 45°

M. R. No. 19702057
 Couplant ULTRACON II 5832S
 Scanning Gain 45dB

Exam proc. 50-71 Rev. 4
 EDS No. 99-E-548
 CDS No. 99-C-547
 L.D.S. 99-L-351
 UTV No. 0021A
 DATE 5/22/99

(W) DIMENSION (L) DIMENSION

WELD COMP#	CONFIG	IND #	SCAN NO. DIRECTION & SURFACE	MAX. AMP.	LO WO	W _m SP _m	L ₁ SP _{L1}	L _m	L ₂ SP _{L2}	TIME OF EXAM START	STOP	COMP. TEMP.	REMARKS
G-N4C-1	6E-N02	N/A	I/+/-							1310	1315	78°F	A) u21
G-N4C-1	6E-N02	N/A	I/-/+							1315	1320	78°F	A) u21
G-N4D-1	6E-N02	N/A	I/+/-							1402	1407	78°F	u21
G-N4D-1	6F-N02	N/A	I/-/+							1407	1412	78°F	u21
	N	A									N	A	

Components meet ASME Section XI Acceptance Criteria:

YES NO → FURTHER EVALUATION REQUIRED

ASME Section XI Examination:

X YES-ANII Signature Required
 NO-ANII Signature Not Required

REMARKS: LIMITED EXAMINATION BETWEEN 26.75° TO 29.75° AND 31.75° TO 33.75° DUE TO THERMAL COUPLER PADS ON WELD.

Evaluated By: *D. Maso* Level *III* Date 5/25/99
 Accepted By: *B. Phillips* Level *III* Date 5/26/99
 BeCo Level III or Designee
 ANII Review By: *V. Ryan* Date 5-26-99


Page 179/240

UT CALIBRATION DATA SHEET

C.D.S. NO. 99-C-549
 U.T.V. NO. 0037A
 L.D.S. NO. 99-L-351

PROCEDURE NO. CGI 5071 REV. 4 DATE 5/22/99
 EXAMINATION PERSONNEL: NAME P. Valentin LEVEL II NAME Frank Mack LEVEL IV
 INSTRUMENT DATA: MAKE STANLEY MODEL Com. 126 SERIAL NO. 126-5496
 WEDGE UNIT DATA: MANUFACTURER KBA TYPE M509C GAMMA
 SERIAL NO. 002W4E SIZE .60" FREQUENCY 2.25 MHz
 BEAM ANGLE 60° BEAM MODE SWEEP WEDGE TYPE LUCITE
 REFLECTOR DATA: LENGTH 12" TYPE R4-174
 REFLECTOR DATA: TYPE Ultra II BATCH NO. 98375
 REFLECTOR STANDARD DATA: SERIAL NO. PL-17A THICKNESS 1.00 DIAMETER 12"
 MATERIAL C6 SA-106 GR. B
 REFLECTOR REFLECTOR(S) DATA: TYPE None SIZE 100'd x 125'w x 10'l
 ORIENTATION (TO PIPE AXIS) Circ
 OR DUAL ELEMENT TRANSDUCERS: SPLIT ORIENTATION (TO HOLE CENTERLINE) FOR
 MAXIMUM RESPONSE
 PARALLEL AMPLITUDE N/A TRANSVERSE AMPLITUDE N/A

C CURVE-SCREEN REPRESENTATION



SWEEP RANGE POSITION OR METAL PATH

TOE 30Z 40E 51Z B
 ODE 44Z 20E 51Z B
 REFERENCE GAIN 61.2dB
 SCANNING GAIN 60.0dB

REVIEWED BY: [Signature] DATE 5/25/99
 DATA REVIEWER

ASME SECTION XI EXAMINATION; YES - ANII SIGNATURE REQUIRED
 NO - ANII SIGNATURE NOT REQUIRED

ACCEPTED BY: [Signature] DATE 5/26/99
 BECO LEVEL III OR DESIGNEE

REVIEWED BY: [Signature] DATE 5/26/99
 ANII

CALIBRATION TIME - RECORDS

00	01	02	03	04	05
ORIG. CAL.	CAL.	LAST CHECK	LAST E.D.S.	LAST E.D.S.	VERIFY 25°F LIMIT
DATE	CAL. TIME	CHECK #	E.D.S. #	E.D.S. #	YES/NO
5/22/99	1065	1838	99-E-550(4)	992	YES

I.D. OF WELD/COMPONENT

6-NAA-1
6-NAB-1
6-NAC-1
6-NAR-1
 Distortion

BOSTON EDISON COMPANY
ULTRASONIC EXAMINATION DATA SHEET

EXAMINATION PERSONNEL:

Name *R. P. [Signature]* Level II

Name *F. M. [Signature]* Level IV

Beam Angle 60°

M. R. No. 19702057
Couplant Ultrasol II 98325
Scanning Gain 600

Exam proc. 50.11 Rev. 4

EDS No. 99-E-550
CDS No. 99-C-549
L.D.S. 99-L-351
UTV No. 6027A
DATE 5/22/99

(W) DIMENSION (L) DIMENSION

WELD COMP#	CONFIG	IND #	SCAN NO. DIRECTION & SURFACE	MAX. AMP.	LO WO	W _m SP _m	L ₁ SP _{L1}	L ₂	L ₂ SP _{L2}	TIME OF EXAM		COMP. TEMP.	REMARKS
										START	STOP		
G-N4A-1	SE-N02	N/A	I/+/-							1347	1353	78°F	N21
G-N4A-1	SE-N02	N/A	I/-/+			N				1353	1359	78°F	N21
G-N4B-1	SE-N02	N/A	I/+/-				A			1255	1301	78°F	A
G-N4B-1	SE-N02	N/A	I/-/+				A			1301	1307	78°F	A
	N	A				N	A					A	

Components meet ASME Section XI Acceptance Criteria: Yes

ASME Section XI Examination:

YES NO → FURTHER EVALUATION REQUIRED

YES-ANII Signature Required
 NO-ANII Signature Not Required

REMARKS: A) LIMITED EXAMINATION BETWEEN 26.875" TO 29.625" TO AND 31.875" TO 34.625" DUE TO THERMO COUPLER PASS OUT WELD.

Evaluated By: *P. [Signature]* Level III Date 5/25/99

Accepted By: *B. [Signature]* Level III Date 5/26/99
BeCo Level III or Designee

ANII Review By: *N. [Signature]* Date 5-16-99

Page 24
181/240

BOSTON EDISON COMPANY
ULTRASONIC EXAMINATION DATA SHEET

EXAMINATION PERSONNEL:

Name R. Walden Level II

Name Tamir Masad Level II

Beam Angle 60°

M. R. No. 19702057
Couplant Ultasonic II 98375
Scanning Gain 60.0

Exam proc. 5011 Rev. 4

EDS No. 99-E-550
CDS No. 79-C-549
L.D.S. 99-L-351
UTV No. 00276
DATE 5/26/99

(W) DIMENSION (L) DIMENSION

WELD COMP#	CONFIG	IND #	SCAN NO. DIRECTION & SURFACE	MAX. AMP.	LO WO	W _m SP _m	L ₁ SP _{L1}	L ₂	L ₂ SP _{L2}	TIME OF EXAM START	STOP	COMP. TEMP.	REMARKS
G-N46-1	SE-NOZ	N/A	I/+/-							1320	1326	78°F	N) NR1
G-N46-1	SE-NOZ	N/A	I/-/+				N			1326	1332	78°F	N) NR1
G-N40-1	SE-NOZ	N/A	I/+/-				A			1412	1418	78°F	NR1
G-N40-1	SE-NOZ	N/A	I/-/+							1418	1424	78°F	NR1
		N	A			N	A				N	A	

Components meet ASME Section XI Acceptance Criteria:

ASME Section XI Examination:

YES NO FURTHER EVALUATION REQUIRED

YES-ANII Signature Required
 NO-ANII Signature Not Required

REMARKS: A) LIMITED EXAMINATION BETWEEN 24.75" TO 29.75" AND 31.75" TO 33.75" DUE TO TAPERED CORNER PRO ON WELD

Evaluated By: D. Harte Level III Date 5/26/99

Accepted By: B. Paul Level III Date 5/26/99
BeCo Level III or Designee

ANII Review By: W. J. G. Date 5-26-99

BOSTON EDISON COMPANY
RECORD OF MAGNETIC PARTICLE EXAMINATION

DATA SHEET #
97-M-119

ITEM ID/PIECE # RPV-SBW-0	SYSTEM <u>54</u> LOCATION <u>DRYWELL</u>	MR # 19600309	ISO/DWG NUMBER ISI-1-54-1
------------------------------	---	------------------	------------------------------

A. MATERIAL TYPE C.S.

CROSS SECTION THICKNESS	MAX	MIN	GEOMETRY	PIPE	PLATE	ROD	OTHER
					<u>X</u>		

FABRICATION PROCESS: CAST WORKED WELDED OTHER _____

SURFACE	MACHINED GROUND	<u>AS FABRICATED</u>	OTHER	INSPECTION HOLD PT <u>FINAL ISI</u>
---------	-----------------	----------------------	-------	--

SURFACE IS SUITABLE FOR SCHEDULED X MT N/A AUT EXAMINATION. YES/NO

SKETCH OR OTHER DETAIL ATTACHED YES NO WEIGHT X 10 LB. 40 LB

B. PROCEDURE # VALIDATION # POLE SPACING	<u>QCI 50.20</u>	EQUIPMENT IDENTIFICATION <u>X</u> AC <u>HWAC</u> <u>SIN 5156</u>
	<u>N/A</u>	
	<u>6" MAX</u>	

C. EVALUATION

LOCATION	SIZE (INCHES)	DESCRIPTION	ACTION (ACCEPT, REWORK, REJECT AND COMMENT AS NECESSARY.)
1		<u>NRI - ACCEPT</u>	<u>EXAMINED 12" OF TOP SURFACE</u>
2			
3			
4			
5			
6			
7			

D. CRITERIA ASME SECT. XI 1989

COMPONENTS MEET/DO NOT MEET ASME SECTION XI ACCEPTANCE CRITERIA, FURTHER EVALUATION REQUIRED. YES X NO

E. ATTEST	<u>D. M. Wood</u>	<u>II</u>	<u>3/5/97</u>
	RESPONSIBLE CERTIFIED PERSONNEL LEVEL	DATE	
	<u>B. Perkins</u>	<u>3/5/97</u>	<u>3/6/97</u>
	BECO LEVEL III DATE	ANII	DATE



Calibration Data Sheet


CDS No: 05-C-450
 LDS No: 05-L-422-151
 Page: 1 of 1

Plant/Unit: PILGRIM STATION
 System: RNR A
 Component: 10-1A-15 / 10-1A-14
 Line No.: "18-DCA-10
 Procedure: END-NDE 9.29 Rev.: 0
 Thermometer SN: 230
 Cal. Blk Temp.: 64 Comp Temp.: 75
 Cal. Block No.: PIL 23A
 Carbon Steel Stainless Steel
 Size: 18 Sch.: .755
 Cal Direction Axial Circ Both
 Scan Area ⊥ to weld
 Scan Area || to weld

Work Order: 03116631
 DWG No.: ISI-I-1-10


Cal Checks	Time
Initial Cal.:	<u>1104 / 1105</u>
Date:	<u>4/29/05</u>
Inter. Cal.:	
Date:	
Inter. Cal.:	
Date:	
Final Cal.:	<u>1752 / 1753</u>
Date:	<u>4/29/05</u>

Couplant
 Type: ULTRAGEL II
 Batch: 01225



Search Unit # 1
 Manufacturer: KBA
 Model: Comp-6
 Serial No.: 00TSCY
 Size: .375 Shape: Round
 Freq.: 15 # Elm: 1
 Angle: 45 Mode: SILENT
 Measured Angle: 45°
 Wedge Style: MSWPC
 Search Unit Cable
 Type: RG-174
 Length: 6.0" # Con.: 0

Instrument Settings
 Manufacturer: STAVELEY
 Model: Sonic 136
 Serial No.: 130P1200404457
 Linearity Due: 5/2/05
 Delay: 1.283 Range: 2.0
 Mtl. Vel.: 123 Pulsar: 334
 Damping: 500 Reject: OFF
 Rep Rate: 4K Freq.: 2.25
 Filter: 2 Mode: P/E
 Reference Sensitivity
 Axial: 29.6 Circ: 29.6



Search Unit # 2
 Manufacturer: RTD
 Model: TRL2
 Serial No.: 00-727
 Size: 2(8x14) Shape: SP
 Freq.: 2 # Elm: 2
 Angle: 70 Mode: LOW
 Measured Angle: 70
 Wedge Style: INTEGRAL
 Search Unit Cable
 Type: RG-174
 Length: 6.0" # Con.: 0

Instrument Settings
 Manufacturer: STAVELEY
 Model: Sonic 136
 Serial No.: 130P1200404457
 Linearity Due: 5/2/05
 Delay: .943 Range: 4.0
 Mtl. Vel.: 250 Pulsar: 250
 Damping: 500 Reject: OFF
 Rep Rate: 4K Freq.: 2.25
 Filter: 2 Mode: DUAL
 Reference Sensitivity
 Axial: 70.8 Circ: N/A

Examination Area / Weld	Access	Recordable Indications			Exam Sens.
		Yes	No	Geom.	
<u>10-1A-14</u>	<u>SINGLE SIDE</u>	<u>N/A</u>	<u>X</u>	<u>NO</u>	<u>57.6 / 72.8</u>
<u>10-1A-15</u>	<u>SINGLE SIDE</u>	<u>N/A</u>	<u>X</u>	<u>NO</u>	<u>37.6 / 72.8</u>

Remarks

Further Evaluation Required: Yes No
 Examiner: [Signature] Level: II Date: 4/30/05
 Examiner: _____ Level: _____ Date: _____
 Reviewer: [Signature] Level: III Date: 4/30/05
 ANII: [Signature] Date: 5/1/05

Page 184/240



Examination Data Sheet

EDS No: 05-E-451-151
 CDS No: 05-C-450-151
 LDS No: 05-L-422-151
 Page: 1 of 2

Plant/Unit: <u>PILGRAM STATION</u>			System: <u>RHR-A</u>				Component: <u>10-1A-14</u>			Procedure: <u>END-NDE-9.23</u>		
Work Order: <u>03116631</u>			DWG No.: <u>ISI-I-170</u> ^{10-1 mm s/des}				<input type="checkbox"/> Carbon Steel <input checked="" type="checkbox"/> Stainless Steel			Revision: <u>0</u>		
Examination Area / Weld No.: <u>10-1A-14</u>			Line No.: <u>18"-DCA-10</u>				Size: <u>18"</u> Schedule: <u>1755</u>			Start Time/Date: <u>1345 4/30/05</u> Finish Time/Date: <u>1415 4/30/05</u>		
Lo Location: <u>TDC</u>			Wo Location: <u>E</u>									
Ind. #	Angle	% of DAC	Indication Length			Max Location		OD SU Loc.	Scan Direct.	Remarks:		
			L1	L Max	L2	W	MP					
<u>N/A</u>												
Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No						Limitations: <u>SINGLE SIDE EXAM 50% COVERAGE</u>						
Remarks												
Examiner: <u>[Signature]</u> Level: <u>II</u> Date: <u>4/30/05</u>						Examiner: <u>N/A</u> Level: <u></u> Date: <u></u>						
Reviewer: <u>[Signature]</u> Level: <u>III</u> Date: <u>4/30/05</u>						ANII: <u>[Signature]</u> Date: <u>5/7/05</u>						

Page 185/240



Sketch Sheet


Data Sheet No: 05-E-451-151

Page: 2 of 2

Plant/Unit: <u>PILGRIM STATION</u>	System: <u>RHR A</u>	Component: <u>10-1A-14</u>	Procedure: <u>END-NDE-9.25</u> Revision: <u>0</u>
Examination Area / Weld No.: <u>10-1A-14</u>	DWG No.: <u>10-1 ^{Weld} 10 _{Sketch}</u> <u>ISI-I-1-10</u>	Line No.: <u>18" OCA-10</u>	Work Order: <u>03116631</u>

PIPE

FLUED HEAD
X51A



Examiner: [Signature] Level: II Date: 4/30/05

Examiner: N/A Level: Date:

Reviewer: [Signature] Level: III Date: 4/30/05

ANII: [Signature] Date: 5/10/05

Page 186/240



Examination Data Sheet

EDS No: 05-E-452-131
 CDS No: 05-C-450-151
 LDS No: 05-L-422-151
 Page 1 of 2

Plant/Unit: <u>PIGRAM STATION</u>			System: <u>RHR - A</u>					Component: <u>10-1A-15</u>			Procedure: <u>END-NDE 923</u>		
Work Order: <u>03116631</u>			DWG No.: <u>ISI-I-1-10</u> ^{10-1 gms} _{studs}					<input type="checkbox"/> Carbon Steel <input checked="" type="checkbox"/> Stainless Steel			Revision: <u>0</u>		
Examination Area / Weld No.: <u>10-1A-15</u>			Line No.: <u>18"-DCA-10</u>					Size: <u>18"</u> Schedule: <u>.755</u>			Start Time/Date: <u>1416 4/30/05</u> Finish Time/Date: <u>1441 4/29/05</u>		
Ind. #	Angle	% of DAC	Indication Length			Max Location		OD SU Loc.	Scan Direct.	Remarks:			
			L1	L Max	L2	W	MP						
<u>NDA</u>													
Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No								Limitations: <u>SINGLE SIDE EXAM 50% COVERAGE</u>					
Remarks													
Examiner: <u>[Signature]</u> Level: <u>II</u> Date: <u>4/30/05</u>						Examiner: <u>NA</u> Level: <u></u> Date: <u></u>							
Reviewer: <u>[Signature]</u> Level: <u>III</u> Date: <u>4/30/05</u>						ANII: <u>[Signature]</u> Date: <u>5/2/05</u>							

Boyer 187/240




Sketch Sheet

Data Sheet No: 05-6-452-151
Page: 2 of 2

Plant/Unit: <u>PILGRIM STATION</u>	System: <u>RHR-A</u>	Component: <u>10-1A-15</u>	Procedure: <u>END-NDE-9.23</u> Revision: <u>0</u>
Examination Area / Weld No.: <u>10-1A-15</u>	DWG No.: <u>ISI-I-1-10</u> ^{10-1 7/16" S/S 15"}	Line No.: <u>18" DCA-10</u>	Work Order: <u>03116631</u>

VALVE
29A

PIPE



FLOW

Examiner: <u>[Signature]</u> Level: <u>II</u> Date: <u>4/30/05</u>	Examiner: <u>N/A</u> Level: <u> </u> Date: <u> </u>
Reviewer: <u>[Signature]</u> Level: <u>III</u> Date: <u>4/30/05</u>	ANII: <u>[Signature]</u> Date: <u>[Signature]</u>

Page 188/240



Calibration Data Sheet


Figure 5

Plan/Unit Pilgrim 1
 Company Scientech
 Comp/System 10R-1A-6
 Procedure No. 50.87
 Rev/Chng. No. 1
 Cal. Block No. F1-64
 Cal. Block Temp 19 Therm S/N
 Size 18" Sch. 0.755 T
 Ferritic Austenitic
 Each Major CRT Div. = .3"/.3"
 Cal. Direction: Axial Circ. Both
 Scan Area: 1 to Weld
11 to Weld

CDS 03-C-126 135
 LDS 03-L-123 8P 4/23/03
 Page 1 of 1 80%

Cal. Checks	Time
Initial Calib.	1335
Initial Calib. Date	4/21/03
Intermediate	
Intermediate	
Final Calib.	1432
Final Calib. Date	4/21/03

Couplant
 Type: Ultragel II
 Batch: 00325




44 Search Unit #1

Manufacture: KBA
 Serial No.: 00W8K0
 Size: 0.50" Shape: Round
 Freq: 1.5 MHz Style: _____
 Exam Angle: 45° Mode: Shear
 Measured Angle: 45°
 Wedge Style: MSWQC

Search Unit Cable
 Type: RG-174
 Length: 6' No. 0

Instrument Settings
 Make/Model: Staveland/Sonic 136
 Serial No.: 850K
 Delay: .458 Range: _____
 M'U Cal/Vel: .125 Pulser: 334us
 Damping: 500Ω Reject: OFF
 Rep. Rate: 4KHz Freq: 2.25
 Filter: 1 Mode: P-E
 Reference Sensitivity (Sens.)
 Axial: 32.4 Circ: 32.4
 SCAN SENS: 38.4



60 Search Unit #2

Manufacture: Megasonics
 Serial No.: 5111
 Size: 2(25x50) Shape: rect
 Freq: 2 MHz Style: CGD
 Exam Angle: 60° Mode: Long
 Measured Angle: 60°
 Wedge Style: integral

Search Unit Cable
 Type: RG-174
 Length: 6' No. 0

Instrument Settings
 Make/Model: Staveland/Sonic 136
 Serial No.: 850K
 Delay: .850 Range: 3.0"
 M'U Cal/Vel: .235 Pulser: 250
 Damping: 500Ω Reject: off
 Rep. Rate: 4KHz Freq: 2.25
 Filter: 1 Mode: Real
 Reference Sensitivity (Sens.)
 Axial: 69dB Circ: 1/1A
 SCAN SENS: 69dB

Examination Area/Weld	Access	Recordable Indications			Exam Sens.
		Yes	No	Geom	
10R-1A-6	UPST		X		38.4
10R-1A-6	UPST	X		X	69
	N				
	A				

Remarks/Reason for Incomplete Scan(s)
 ① Single Sided exam due to component configuration (Pipe to Valve)
 ② Maintained 5-20% ID roll

Examiners: [Signature] Level II Date 4/21/03
 Reviewers: [Signature] Level _____ Date _____
 ERO
 Reviewers: [Signature] Further Evaluation Required? Yes No
4/23/03

Ernsting III

Page 189/240



Ultrasonic Examination Indication Report Sheet

CDS No: 03-C-135	EDS No: 03-E-136	Lo Location: TDC	Start Time 1633	Examiner: TC-1A-Level <i>[Signature]</i>
Item Identification: Weld: 10R-1A-6		Wo Location: Weld E	Finish Time 1700	Examiner: TC-1A-Level <i>[Signature]</i>
Component Information: Diameter(nom): 18" Thickness: 0.94"		Procedure No. 50.87	Rev. 1	Date: 4/23/03 Weld Crown Width: 1.1"

Ind #	Angle Used	% of DAC	Indication Length			Max		OD S.U. Loc.	Scan Direction I II	Remarks
			L1	Max	L2	W	MP			
<i>N/A</i>	<i>45°</i>				<i>N</i>		<i>A</i>			<i>N/A</i>
<i>1</i>	<i>60°L</i>	<i>100% -7dB</i>		<i>6.5"</i>		<i>1.4"</i>	<i>1.8"</i>	<i>upst</i>	<i>I</i>	<i>Previously recorded root geometry observed at higher amplitude due to the use of an RL wave mode</i>


Page 190/240

ANII: *[Signature]* Date **4-23-03**
 Reviewer(s): *B. Rubin* Date **4/23/03** Reviewer(s): *N/A* Date *N/A*

Component Meets, Does Not Meet
 ASME Section XI 1989
 Further Evaluation Required Yes No

Entry III

Figure 6



✓ Reviewed original radiographs and root convexity present. Supports plots.

B. Perkins III
4/22/03

Examiner ~~Paul T. Hayes~~
Paul T. Hayes

Level II

Date 4/21/03

Page 191/240



Calibration Data Sheet

Figure 5

Plan/Unit Pilgrim 1
Company Scientech

Comp/System 10R-1A-7/RHR

Procedure No. 50.87

Rev/Chng. No. 1

Cal. Block No. P1-64

Cal. Block Temp 65° Therm S/N

Size 1.5" Sch. 0.235 T

Ferritic Austenitic

Each Major CRT Div. = .3"/.3"

Cal. Direction: Axial Circ. Both

Scan Area: 1 to Weld
11 to Weld

CDS 03-C-137

LDS 03-L-123


Page 1 of 1

Cal. Checks	Time
Initial Calib.	0817
Initial Calib. Date	4/22/03
Intermediate	
Intermediate	
Final Calib.	1155
Final Calib. Date	4/22/03

Couplant


Type: Ultragel II

Batch: 00325



Search Unit #1

Manufacture: KBA
Serial No.: 00W8K0
Size: 0.50" Shape: ROUND
Freq: 1.5 MHz Style: _____
Exam Angle: 45° Mode: Shear
Measured Angle: 45°
Wedge Style: MSWQC



Search Unit #2

Manufacture: Megasonics
Serial No.: J1111
Size: 2(.25x.50) Shape: RECT
Freq: 2 MHz Style: CGD
Exam Angle: 60° Mode: Long
Measured Angle: 60°
Wedge Style: integral

Search Unit Cable
Type: RG-174
Length: 6' No. Ø

Search Unit Cable
Type: RG-174
Length: 6' No. Ø

Instrument Settings

Make/Model: Staveland/Sonic 136
Serial No: 850K
Delay: .458 Range: 30"
M/I Cal/Wel: .125 Pulser: 334ms
Damping: 500Ω Reject: OFF
Rep. Rate: 4KHz Freq: 2.25
Filter: 1 Mode: P-E

Instrument Settings

Make/Model: Staveland/Sonic 136
Serial No: 850K
Delay: .930 Range: 30"
M/I Cal/Wel: .235 Pulser: 250
Damping: 500Ω Reject: OFF
Rep. Rate: 4KHz Freq: 2.25
Filter: 1 Mode: Dual

Reference Sensitivity (Sens.)
Axial: 32.4 Circ: 32.4
SCAN SENS: 38.4

Reference Sensitivity (Sens.)
Axial: 70dB Circ: N/A
SCAN SENS: 70dB

Examination Area/Weld	Access	Recordable Indications			Exam Sens.
		Yes	No	Geom	
<u>10R-1A-7</u>	<u>DIST</u>	<u>X</u>		<u>X</u>	<u>38.4</u>
<u>10R-1A-7</u>	<u>DIST</u>	<u>X</u>		<u>X</u>	<u>70dB</u>
<u>N</u>					

Remarks/Reason for Incomplete Scan(s)
① Single sided exam due to component configuration (Valve to Pipe)
② Maintained 5-20% ID roll

Examiners: [Signature] Level II Date 4/22/03

Reviewers: [Signature] Level _____ Date _____

Further Evaluation Required? Yes No

Page 192/240



Ultrasonic Examination Indication Report Sheet

CDS No: <u>03-C-137</u>	EDS No: <u>03-E-138</u>	Lo Location: <u>TDC</u>	Start Time: <u>0926</u>	Examiner: TC-1A-Level	
Item Identification: <u>Weld: 10R-1A-7</u>		Wo Location: <u>Weld E</u>	Finish Time: <u>0955</u>	Examiner: TC-1A-Level	
Component Information: Diameter (nom): <u>18"</u> Thickness: <u>0.80"</u>		Procedure No: <u>50.87</u>	Rev: <u>1</u>	Date: <u>4/22/03</u>	Weld Crown Width: <u>1.1"</u>

Ind #	Angle Used	% of DAC	Indication Length			Max		OD S.U. Loc.	Scan Direction I II	Remarks
			L1	Max	L2	W	MP			
<u>1</u>	<u>45°</u>	<u>50%</u>		<u>6.5"</u>		<u>0.8"</u>	<u>1.38"</u>	<u>DNST</u>	<u>I</u>	<u>ROOT Geometry</u>
<u>2</u>	<u>60°</u>	<u>100%</u> <u>-8dB</u>		<u>6.5"</u>		<u>1.35</u>	<u>1.6</u>	<u>DNST</u>	<u>I</u>	<u>Previously recorded root geometry observed at higher amplitudes due to the use of an RL wave mode.</u>


ANII: Date 4-23-03
 ERD Reviewer(s) RB/Ph Date 4/23/03 Reviewer(s) N/A Date N/A

Component Meets, Does Not Meet
 ASME Section XI 1999
 Further Evaluation Required Yes ___ No X

Boag 1/3/240

Entropy III

Figure 6



*also reviewed original
Radiographs of these
welds. Convex root pass
supports plots.

B. Peshani
NDE III
4/23/03

Examiner: *[Signature]* Level: II Date: 4/23/03
Paul T. Hayes

Boq: 194/242



Calibration Data Sheet



Figure 5

Plant/Unit: PNPS
Company: ENERGY

L.D.S. No. 01-L-199
C. Data Sheet # 01-C-316
Page 1 of 1

Comp/System: RWGU
Procedure No.: 11 50.87
Rev/Clng. No.: 0
Cal. Block No.: PIL-8A
Cal. Block Temp.: 64 Therm S/N
Size: 6" Sch.: T

Cal. Checks	Time
Initial Calib.	<u>1035/1146</u>
Initial Calib. Date	<u>5-4-01</u>
Intermediate	<u>N</u>
Intermediate	<u>A</u>
Final Calib.	<u>1800/1804</u>
Final Calib. Date	<u>5-4-01</u>



Ferritic Austenitic
Each Major CRT Div. = 2"/.25"

Cal. Direction: Axial Circ. Both

Scan Area: I to Weld
II to Weld

Couplant
Type: ULTRAGEL JL
Batch: 00325

Manufacture: KBA
Serial No.: 008V60
Size: .375" Shape: Round
Freq: 2.25 MHz Style: Comp G
Exam Angle: 45° Mode: Shear
Measured Angle: 46°
Wedge Style: Non-Integral

Manufacture: KBA
Serial No.: 008V5R
Size: .375" Shape: Round
Freq: 2.25 MHz Style: Comp G
Exam Angle: 70° Mode: Shear
Measured Angle: 67°
Wedge Style: Non-Integral

Examination Area/Weld	Access	Recordable Indications			Exam Sens.
		Yes	No	Geom	
<u>12-0-24 (45°)</u>	<u>DS</u>	<u>N/A</u>	<u>✓</u>	<u>N/A</u>	<u>49.25</u> <u>49.26</u>
<u>12-0-24 (70°)</u>	<u>DS</u>	<u>N/A</u>	<u>✓</u>	<u>N/A</u>	<u>52.26</u>
	<u>N</u>				

Search Unit Cable
Type: RG-174 U
Length: 6' No. 0

Search Unit Cable
Type: RG-174 U
Length: 6' No. 0

Instrument Settings
Make/Model: STAVLEY/Sonic 136
Serial No.: 1009L
Delay: 0.329" Range: 2.0°
M'll Cal/Vol: 0.127% Pulsor: 222nS
Damping: 500 n Reject: OFF
Rep. Rate: 4 kHz Freq: 2.25 MHz
Filter: 1 Mode: P-E
Reference Sensitivity (Sens.)
Axial: 37.0 dB Circ: 37.0 dB
SDH Sensitivity: 43.0 dB / 49.0 dB

Instrument Settings
Make/Model: STAVLEY/Sonic 136
Serial No.: 1009L
Delay: 0.469" Range: 25"
M'll Cal/Vol: 0.127% Pulsor: 222nS
Damping: 500 n Reject: OFF
Rep. Rate: 4 kHz Freq: 2.25 MHz
Filter: 1 Mode: P-E
Reference Sensitivity (Sens.)
Axial: 53.2 dB Circ: NA
SDH Sensitivity: 53.2 dB

Remarks/Reason for Incomplete Scan(s)
SINGLE SIDED EXAM DUE TO FLUGG HEAD TO PIPE.
CONFIGURATION. 56.64% COVERAGE
73P

Examiners: Daniel P. Thiel Level II Date 5-4-01

N/A Level N/A Date N/A

Reviewers: B.P. Pickens Further Evaluation Required? Yes No
NDT III

Page 195/240



Ultrasonic Examination Indication Report Sheet

Calibration Data Sheet Number: <u>Φ1-C-316</u>	EDS: <u>Φ1-E-317</u>	Lo Location: <u>TOP END CENTER</u>	Start Time <u>1520</u>	Examiner: TC-1A-Level <u>DENNIS P. STRICKLAND</u>
Item Identification: <u>12-0-24</u>	TEMP: <u>80°F</u>	Wo Location: <u>W20 E</u>	Finish Time <u>1600</u>	Examiner: TC-1A-Level <u>N/A</u>
Component Information: Diameter(nom): <u>6"</u> Thickness: <u>.432"</u>		Procedure No. <u>50.87</u>	Rev. <u>0</u>	Date: <u>5-04-01</u> Weld Crown Width: <u>.55"</u>

Ind #	Angle Used	% of DAC	Indication Length			Max		OD S.U. Loc.	Scan Direction I II	Remarks
			L1	Max	L2	W	MP			
N/A	45°				N/A				L II	NO RECORDABLE INDICATIONS
N/A	70°				N/A				I	NO RECORDABLE INDICATIONS
N/A										

Additional Remarks: ASME V. 1.10.1.1 DATE 2-5-01 COMPONENT MEETS / DOES NOT MEET ASME SECT. XI 1989


Reviewer(s): B. Pukni 5-5-01 Further Evaluation Required Yes No

George 196/240

NOT III

Figure 6

WELD 12-0-24



Dennis P. Strickland II 5-4-01
DENNIS P. STRICKLAND

TOTAL AREA = .1659"

SCANNED FROM:	sq"	%
(Ax) DS	.12259"	76.56%
(Ax) US	.0859"	50.00%
(Circ) CW	.0859"	50.00%
(Circ) CCW	.0859"	50.00%
		<u>226.56%</u>

$226.56\% \div 4 \text{ (SCAN DIRECTIONS)} = 56.64\%$

TOTAL COVERAGE = 56.64%

Page 177/240

Calibration Data Sheet

CDS No: 05-C-457-151
 LDS No: 05-L-422-151
 Page: 1 of 1

Plant/Unit: PILGRIM
 System: CORE SPRAY
 Component: 14-A-19
 Line No.: 10-DC-14
 Procedure: ENHANCE-923 Rev.: 0
 Thermometer S/N: 230
 Cal. Bik Temp.: 64° Comp Temp.: 67°
 Cal. Block No.: PIL BA
 Carbon Steel Stainless Steel
 Size: 10.0" Sch.: .593 THK

Cal Direction Axial Circ Both
 Scan Area ⊥ to weld
 Scan Area || to weld

Work Order: 0316643
 DWG No.: ISI I 14-1

Cal Checks	Time
Initial Cal.:	<u>850 / 910</u>
Date:	<u>4-29-05</u>
Inter. Cal.:	
Date:	
Inter. Cal.:	
Date:	
Final Cal.:	<u>1645</u>
Date:	<u>4-29-05</u>

Couplant

Type: ULTRAGEL II
 Batch: 01225

Examination Area / Weld	Access	Recordable Indications			Exam Sens.
		Yes	No	Geom.	
<u>14-A-19</u>	<u>SINGLE</u>		<input checked="" type="checkbox"/>		<u>39.0</u>
Remarks					
Further Evaluation Required:		<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No		

Examiner: [Signature] Level: II Date: 4-29-05
 Examiner: [Signature] Level: N/A Date: N/A
 Reviewer: [Signature] Level: III Date: 4/30/05
 ANII: [Signature] Date: [Signature]

FD X MATCH

Search Unit # 1

Manufacturer: KRA
 Model: COMP 6
 Serial No.: 0075C4
 Size: .375 Shape: RAND
 Freq.: 1.5 # Elm: 1
 Angle: 45° Mode: SHEAR
 Measured Angle: 45°
 Wedge Style: MSWGL

Search Unit Cable

Type: RG-174
 Length: 6' # Con.: 0

Instrument Settings

Manufacturer: STANLEY
 Model: SONIC 136
 Serial No.: 136P1200H041457
 Linearity Due: 5-2-05
 Delay: .283 Range: 2.00
 Mtl. Vel.: .123 Pulsar: 334
 Damping: 500 Reject: OFF
 Rep Rate: 4K Freq.: 2.25
 Filter: 2 Mode: P.E

Reference Sensitivity

Axial: 33.0 Circ: 33.0

FD X MATCH

Search Unit # 2

Manufacturer: KRA RTD
 Model: COMP 6 TRIA
 Serial No.: 00-728
 Size: (2) 8x14 Shape: SQR
 Freq.: 2.0 # Elm: 2
 Angle: 70° Mode: LONG.
 Measured Angle: 70°
 Wedge Style: INTEGRAL

Search Unit Cable

Type: (2) RG-174
 Length: 6' # Con.: 0

Instrument Settings

Manufacturer: STANLEY
 Model: SONIC 136
 Serial No.: 136P1200H041457
 Linearity Due: 5-2-05
 Delay: .943 Range: 4.0
 Mtl. Vel.: .230 Pulsar: 250
 Damping: 500 Reject: OFF
 Rep Rate: 4K Freq.: 2.25
 Filter: 2 Mode: DUAL

Reference Sensitivity

Axial: 68.6 Circ: N/A

Page 108/340



Examination Data Sheet

EDS No: 05-E-458-151
 CDS No: 05-C-457-151
 LDS No: 05-L-422-151
 Page: of

Plant/Unit: <i>PILGRIM</i>		System: <i>CORE SPRAY</i>		Component: <i>VALVE TO PIPE</i> <i>14-A-19</i>		Procedure: <i>ENW-NDE-923</i> Revision: <i>0</i>				
Work Order: <i>05116643</i>		DWG No.: <i>ISI I 14-1</i>		<input type="checkbox"/> Carbon Steel <input checked="" type="checkbox"/> Stainless Steel		Start Time/Date: <i>1510 4-29-05</i> Finish Time/Date: <i>1540 4-29-05</i>				
Examination Area / Weld No.: <i>14-A-19</i>		Line No.: <i>10-DC-14</i>		Size: <i>10"</i> Schedule: <i>.595 THK.</i>		Lo Location: <i>T.D.C.</i> Wo Location: <i>WELD 2</i>				
Ind. #	Angle	% of DAC	Indication Length			Max Location		OD SU Loc.	Scan Direct.	Remarks:
			L1	L Max	L2	W	MP			
										<i>NO RECORDABLE INDICATIONS</i>
Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No				Limitations: <i>VALVE</i>						
Remarks										
Examiner: <i>DJ-11</i> Level: <i>II</i> Date: <i>4-29-05</i>				Examiner: <i>N/A</i> Level: <i>N/A</i> Date: <i>N/A</i>						
Reviewer: <i>vo Thibault</i> Level: <i>III</i> Date: <i>4/30/05</i>				ANII: <i>Curt</i> Date: <i>5/1/05</i>						

Page 199/240




Sketch Sheet

Data Sheet No: 05-E-459-131

Page: 2 of 2

Plant/Unit: <u>PILGRIM</u>	System: <u>CORE SPRAY</u>	Component: <u>14-A-19</u>	Procedure: <u>ENR-NDE - 9.23</u> Revision: <u>D</u>
Examination Area / Weld No.: <u>14-A-19</u>	DWG No.: <u>ISI I 14-1</u>	Line No.: <u>10-DC-14</u>	Work Order: <u>03116643</u> <u>ISI I 14-1 DWG NO.</u>



50% CRV. DUE TO SINGLE SIDE EXAM
AS PER ENR-NDE - 9.23 REV. D PAR. 1.8

Examiner: [Signature] Level: II Date: 4-29-05

Examiner: [Signature] Level: III Date: 4/29

Reviewer: [Signature] Level: III Date: 4/30/05

ANII: [Signature] Date: 5/1/05

Page 200/240



Calibration Data Sheet

Figure 5

Plant/Unit PNPS
 Company ENERGY
 Comp/System CORG SPRAY
 Procedure No. ITI 50.87
 Rev/Chng. No. 0
 Cal. Block No PIL-8A
 Cal. Block Temp. 62.1566 Therm S/N
 Size 10" Sch. .513" T
 Ferritic Austenitic
 Each Major CRT Div. = .25"

Cal. Direction: Axial Circ. Both
 Scan Area:

 to Weld
 to Weld

CDS 01-C-193
 LDS 01-L-141

Cal. Checks	Time
Initial Calib.	0130/1015
Initial Calib. Date	4-26-01
Intermediate	N
Intermediate	A
Final Calib.	1553/1556
Final Calib. Date	4-26-01

Compliant
 Type: ULTRAGEL II
 Batch: 00325

3.6
Search Unit #1

Manufacture: KBA
 Serial No.: 0080LR
 Size: 3.75" Shape: ROUND
 Freq: 1.5 MHz Style: LONG
 Exam Angle: 45° Mode: SWEEP
 Measured Angle: 48°
 Wedge Style: NON-INTEGRAL

Search Unit Cable
 Type: BG-174V
 Length: 6' No. 0

Instrument Settings
 Make/Model: STANLEY/Sonic 136
 Serial No: 1009L
 Delay: 0.323" Range: 2.5"
 M'll Ca/Wel: 0.25% Pulsar: 334uS
 Damping: 500u Reject: OFF
 Rep. Rate: 4KHz Freq: 2.25MHz
 Filter: 2 Mode: P/E
 Reference Sensitivity (Sens.)
 Axial: 35.2dB Circ: 35.2dB
 SCAN SENS.: 47.2dB/47.2dB

4.6
Search Unit #2

Manufacture: MEGASONIC
 Serial No.: J1121
 Size: 2.25" x .20" Shape: RECT.
 Freq: 2 MHz Style: CGD
 Exam Angle: 60° Mode: LONG
 Measured Angle: 58.9°
 Wedge Style: INTEGRAL

Search Unit Cable
 Type: RG-174V
 Length: 6' No. 0

Instrument Settings
 Make/Model: STANLEY/Sonic 136
 Serial No: 1009L
 Delay: 0.614" Range: 2.5"
 M'll Ca/Wel: 0.25% Pulsar: 250uS
 Damping: 500u Reject: OFF
 Rep. Rate: 4KHz Freq: 2.25MHz
 Filter: 2 Mode: DUAL
 Reference Sensitivity (Sens.)
 Axial: 61.0dB Circ: N/A
 SCAN SENS.: 67 dB

Examination Area/Weld	Access	Recordable Indications			Exam Sens.
		Yes	No	Geom	
14-B-17	US	N/A	✓	N/A	47.2 67.8
14-B-20	US	N/A	✓	N/A	47.2 67.0
	N				
	A				

Remarks/Reason for Incomplete Scan(s)
SEE ATTACHED COVERAGE PLOTS

Examiners: [Signature] Level III Date 4-26-01
[Signature] Level III Date 4/26/01
 Reviewers: [Signature] Further Evaluation Required? Yes No

Page 201/240

Instruction No. 50.71
 Rev. 5
 Attachment A
 Page 23 of 26



Ultrasonic Examination Indication Report Sheet

EDS No: 01-E-194 CDS No: 01-C-193 Lo Location: TOP DECK CASE Start Time: 1250 Examiner: TC-1A-Level II Dennis P. Strickland

Item Identification: 14-B-20 TEMP: 80°F Wo Location: WAD E Finish Time: 1330 Examiner: TC-1A-Level II Dale Murchiock

Component Information: Diameter(nom): 10" Thickness: .593" Procedure No. 177 50.87 Rev. 0 Date: 4-26-01 Weld Crown Width: .8"

Ind #	Angle Used	% of DAC	Indication Length			Max		OD S.U. Loc.	Scan Direction I II	Remarks
			L1	Max	L2	W	MP			
N/A	45°	—	—	—	N/A	—	—	—	I II	NO RECORDABLE INDICATIONS
N/A	60° RL	—	—	—	N/A	—	—	—	I	NO RECORDABLE INDICATIONS
N/A										

ANII: [Signature] Date 4-28-01
 Reviewer(s) [Signature] Date 4/27/01 Reviewer(s) B. P. Strickland Date 4/28/01
 Component Meets, Does Not Meet
 ASME Section XI 1989
 Further Evaluation Required Yes No

Figure 6

Page 202/240



Ultrasonic Examination Indication Report Sheet

EDS No: <u>01-E-194</u>	CDS No: <u>04-C-193</u>	Lo Location: <u>Top Deck Cover</u>	Start Time: <u>1450</u>	Examiner: TC-1A-Level II <u>Dennis P. Strickland</u>
Item Identification: <u>14-B-17</u>	TEMP. <u>80°F</u>	Wo Location: <u>Weld E</u>	Finish Time: <u>1530</u>	Examiner: TC-1A-Level <u>Dan M. ...</u>
Component Information: Diameter(nom): <u>10"</u> Thickness: <u>.593"</u>		Procedure No. <u>171 50.87</u>	Rev. <u>0</u>	Date: <u>4-26-01</u> Weld Crown Width: <u>.6"</u>

Ind #	Angle Used	% of DAC	Indication Length			Max		OD S.U. Loc.	Scan Direction I II	Remarks
			L 1	Max	L 2	W	MP			
N/A	45°				N/A				I II	No RECORDABLE INDICATIONS.
N/A	60° RL				N/A				I	No RECORDABLE INDICATIONS.
N/A										


ANII: [Signature] Date 4-28-01
 Reviewer(s) [Signature] Date 4/27/01 Reviewer(s) B.P. [Signature] Date 4/26/01
 Component Meets, Does Not Meet
 ASME Section XI 1989
 Further Evaluation Required Yes No

Figure 6

Page 203/240

CDS 01-C-193

LDS 01-L-141




TOTAL AREA = .23 sq"

Dennis P. Strickland II, 4-26-01
DENNIS P. STRICKLAND

SCANNING FROM:	Sq":	%:
(Ax) DS SIDE	.08"	34.82%
(Ax) US SIDE	.29"	100.00%
(Circ) CW SCANS	.145 sq"	50.00%
(Circ) CCW SCANS	.145 sq"	50.00%
		<u>234.82%</u>

$\frac{234.82\%}{4}$ = 58.7% TOTAL COVERAGE
(SCAN DIRECTIONS)

Page 204/240



Dennis P. Strickland JR 4-26-01
 DENNIS P. STRICKLAND

Aug 2005/240

TOTAL AREA = .26 sq"

SCANNED FROM :	Sq "	% :
(AX) DS SIDE	.09859"	37.69%
(AX) US SIDE	.269"	100.00%
(Circ) CW SCANS	.1359"	50.00%
(Circ) CCW SCANS	.1359"	50.00%
		<u>237.69%</u>
	<u>237.69%</u>	
4 (SCAN DIRECTIONS) = 59.42% TOTAL COVERAGE		



Calibration Data Sheet

Figure 5

Plan/Unit PNPS
 Company ENERGY
 Comp/System MAIN STEAM
 Procedure No. ITI 50.71
 Rev/Chng. No. 5
 Cal. Block No PIL-117
 Cal. Block Temp. 66°F Therm S/N
 Size 3" Sch. .438" T
 Ferritic Austenitic
 Each Major CRT Div. = .25"
 Cal. Direction: Axial Circ. Both
 Scan Area: I to Weld
II to Weld

CDS 01-C-252
 LDS IV-L-199


Cal. Checks	Time
Initial Calib.	0824/ 0837
Initial Calib. Date	05-01-01
Intermediate	N
Intermediate	A
Final Calib.	1533/ 1536
Final Calib. Date	05-01-01

Couplant
 Type: ULTRAGEL II
 Batch: 00325

Examination Area/Weld	Access	Recordable Indications			Exam Sens.
		Yes	No	Geom	
1-SD-10R	US	N/A	✓	N/N	52.0dB 68.0dB
		N	A		

Remarks/Reason for Incomplete Scan(s)
SINGLE SIDED EXAM DUE TO PIPE TO VALVE CONFIGURATION.


Examiners: [Signature] Level II Date 05-01-01
[Signature] Level III Date 5/1/01
 Reviewers: [Signature] Further Evaluation Required? Yes No
NDE III



Manufacture: KBA
 Serial No.: 006N3L
 Size: .25" Shape: ROUND
 Freq: 5.0MHz Style: COMP G
 Exam Angle: 45° Mode: SHEAR
 Measured Angle: 45°
 Wedge Style: NON-INTEGRAL

Search Unit Cable
 Type: RG-174 U
 Length: 6' No. 0

Instrument Settings
 Make/Model: STAVLEY/SONIC 136
 Serial No: 1009L
 Delay: 0.236" Range: 2.5"
 M/I CalVel: 0.130% Pulser: POUS
 Damping: 500 Reject: OFF
 Rep. Rate: 4KHz Freq: 5.0MHz
 Filter: 1 Mode: P-E
 Reference Sensitivity (Sens.)
 Axial: 40.0dB Circ: 40.0dB
 SCAN SENS.: 52.0dB/52.0dB



Manufacture: KBA
 Serial No.: 006YWK
 Size: .25" Shape: ROUND
 Freq: 5.0MHz Style: COMP G
 Exam Angle: 70° Mode: SHEAR
 Measured Angle: 70°
 Wedge Style: NON-INTEGRAL

Search Unit Cable
 Type: RG-174 U
 Length: 6' No. 0

Instrument Settings
 Make/Model: STAVLEY/SONIC 136
 Serial No: 1009L
 Delay: 0.295" Range: 3.5"
 M/I CalVel: 0.131% Pulser: 100nS
 Damping: 500 Reject: OFF
 Rep. Rate: 4KHz Freq: 5.0MHz
 Filter: 1 Mode: P-E
 Reference Sensitivity (Sens.)
 Axial: 68.0dB Circ: N/A
 SCAN SENS. 68.0dB

Page 206/240

Instruction No. 50.71
 Rev. 5
 Attachment A
 Page 23 of 26



Ultrasonic Examination Indication Report Sheet

Page 1 of 4

CDS No: <u>01-C-252</u>	EDS No: <u>01-E-253</u>	Lo Location: <u>Top Deck Cover</u>	Start Time <u>1000</u>	Examiner: TC-IA-Level <u>Dennis P. Strickland II</u>
Item Identification: <u>1-50-10R</u>	TEMP: <u>72°F</u>	Wo Location: <u>Weld</u>	Finish Time <u>1100</u>	Examiner: TC-IA-Level <u>[Signature]</u>
Component Information: Diameter (nom): <u>3"</u> Thickness: <u>.438"</u>		Procedure No. <u>ITI 50.71</u>	Rev. <u>5</u>	Date: <u>05-01-01</u> Weld Crown Width: <u>1.1"</u>

Ind #	Angle Used	% of DAC	Indication Length			Max		OD S.U. Loc.	Scan Direction J, II	Remarks
			L1	Max	L2	W	MP			
N/A	45°				N/A				I II	No RECORDABLE INDICATIONS
N/A	70°				N/A				I	No RECORDABLE INDICATIONS
N/A										

ANII: [Signature] Date 5-3-01

Reviewer(s) N/A Date N/A Reviewer(s) B. Rubin Date 5/2/01


Component Meets, Does Not Meet
 ASME Section XI 1989
 Further Evaluation Required Yes No

Page 207/240

Figure 6

Instruction No. 50.71
Rev. 5
Attachment A
Page 24 of 26

WELD 1-SD-10R



Dennis P. Hill II 501-01

TOTAL AREA .2859"

SCAN FROM:	Sq":	% :
(Ax) DS SCAN	.2859"	100%
(Ax) US SCAN	.2859"	100%
(Circ) CCW SCANS	.24559"	75%
(Circ) CW SCANS	.24559"	75%
		<u>350%</u>

350% ÷ 4 (SCAN DIRECTIONS) = 87.5% TOTAL COVERAGE

Page 208/340



Calibration Data Sheet



Figure 5

Plant/Unit PNP3
Company ENERGY

LDS NO: 01-L-140
C. Data Sheet # 01-C-155
Page 1 of 2

Comp/System 2R-HB-1
Procedure No. JIT-5087
Rev/Chng. No. 0
Cal. Block No. P11-63
Cal. Block Temp. 72 Therm S/N
Size 12" Sch. -850" T

Cal. Checks	Time
Initial Calib.	<u>1220</u>
Initial Calib. Date	<u>04/22/01</u>
Intermediate	<u>N</u>
Intermediate	<u>A</u>
Final Calib.	<u>1830</u>
Final Calib. Date	<u>04/22/01</u>



Ferritic Austenitic
Each Major CRT Div. = 45° 205kV = 288"
Cal. Direction: Axial Circ. Both
Scan Area: 11 to Weld

Couplant
Type: ULTRAGEL
Batch: 98325

Search Unit #1
Manufacture: KBA
Serial No.: 0080LR
Size: 3.75 Shape: Round
Freq: 1.5MHz Style: Misc comp
Exam Angle: 45° Mode: SHEAR
Measured Angle: 44°
Wedge Style: NON-INTEGRAL

Search Unit #2
Manufacture: KBA
Serial No.: M15116
Size: .50" Shape: Round
Freq: 1.5" Style: MISC
Exam Angle: 60° Mode: SHEAR
Measured Angle: 58°
Wedge Style: NON-INTEGRAL

Examination Area/Weld	Access	Recordable Indications			Exam Sens.
		Yes	No	Geom	
<u>2R-HB-1 45°</u>	<u>D/S</u>	<u>N/A</u>	<u>X</u>	<u>N/A</u>	<u>53.0</u>
<u>2R-HB-1 60°</u>	<u>D/S</u>	<u>X</u>	<u>N/A</u>	<u>X</u>	<u>62.6</u>

Search Unit Cable
Type: BG-174
Length: 12' No. 1

Search Unit Cable
Type: BG-174
Length: 6' No. 1

Instrument Settings
Make/Model: STANLEY/SUNC 136
Serial No: 1008L
Delay: .293 Range: 2.05
M'll Cal/Vel: .121 Pulsar: 334
Damping: 500Ω Reject: OFF
Rep. Rate: 4K Freq: 2.25
Filter: 1 Mode: PIE
Reference Sensitivity (Sens.)
Axial: 41.0 Circ: 41.0
SDH Sensitivity: N/A

Instrument Settings
Make/Model: STANLEY/SUNC 136
Serial No: 1008L
Delay: .274 Range: 2.88"
M'll Cal/Vel: .121 Pulsar: 334
Damping: 500Ω Reject: ---
Rep. Rate: 4K Freq: 2.25
Filter: 1 Mode: PE
Reference Sensitivity (Sens.)
Axial: 56.6 Circ: 56.6
SDH Sensitivity: N/A

Remarks/Reason for Incomplete Scan(s)
ONE SIDED EXAM DUE TO REDUCER, D/S SIDE ONLY. TOTAL COVERAGE ACHIEVED IS 75%. SEE ATTACHED PLOT.

Examiners: [Signature] Level II Date 04/22/01
[Signature] Level II Date 4-22-01
Reviewers: [Signature] Further Evaluation Required? Yes No
NOT IT

Page 209/240



Ultrasonic Examination Indication Report Sheet

FDS No: <u>01-E-156</u>	CDS No: <u>01-C-155</u>	Lo Location: <u>TDC</u>	Start Time: <u>1500</u>	Examiner: TC-1A-Level <u>Amy E Krauser / Amy E Krauser</u>
Item Identification: <u>2B-HB-1</u>	TEMP <u>82°</u>	Wo Location: <u>CENTERLINE</u>	Finish Time: <u>1545</u>	Examiner: TC-1A-Level <u>SHANE CHARBONNET</u>
Component Information: <u>HEADER TO BEND (22°-12°)</u>		Procedure No. <u>ITI 50.87</u>	Rev. <u>0</u>	Date: <u>4/22/01</u>
Diameter(nom): <u>12"</u>	Thickness: <u>8"</u>			Weld Crown Width: <u>.75"</u>

Ind #	Angle Used	% of DAC	Indication Length			Max		OD S.U. Loc.	Scan Direction I II	Remarks
			L1	Max	L2	W'	MP			
<u>1</u>	<u>60°</u>	<u>100%</u>	<u>0</u>	<u>1.0"</u>	<u>360°</u>	<u>.9"</u>	<u>1.58</u>	<u>D/S</u>	<u>L</u>	<u>ID GEOMETRY SEEN 360° - INTERMITTENT AT VARIOUS LOWER APERTURES</u>
<u>N/A</u>	<u>45°</u>								<u>L/II</u>	<u>NO RECORDABLE INDICATIONS</u>
<u>N/A</u>	<u>60° RL</u>								<u>L</u>	<u>NO RECORDABLE INDICATIONS</u>
				<u>N</u>						
						<u>A</u>				

ANII: [Signature] Date 4-25-01


Reviewer(s) [Signature] Date 4/24/01 Reviewer(s) [Signature] Date 4/24/01

Component Meets, Does Not Meet
 ASME Section XI 1989
 Further Evaluation Required Yes No

Figure 6

Page 211/240

COMPONENT
2R-HB-1




Req. 2/2/24

Amy E Kaiser LVII
04/22/01
[Signature] LVII
4-22-01

EDS# 01 156
P9 373

COMPONENT
2R-HB-1



FLOW →

- COVERAGE
SCAN 1 - AXIAL UPSTREAM = 0%
SCAN 2 AXIAL DOWNSTREAM = 100%
SCAN 3 CIRC CLOCKWISE = 100%
SCAN 4 CIRC COUNTERCLOCKWISE = 100%
T... 100% 75%

Page 2/3/242

Amy E Krauser W II
04/22/01
4-22-01



Calibration Data Sheet



Figure 5

Plant/Unit PNP3
Company ENERGY

LDS No: 01-L-140
C. Data Sheet # 01-C-157
Page 1 of 2

Comp/System 2R-HB-4
Procedure No. TTI-5087
Rev/Chng. No. 0
Cal. Block No. P11-63
Cal. Block Temp. 72 Therm S/N
Size 12" Sch. .850 7"

Cal. Checks	Time
Initial Calib.	1220
Initial Calib. Date	04/22/01
Intermediate	N
Intermediate	A
Final Calib.	1830
Final Calib. Date	04/22/01



Ferritic Austenitic
Each Major CRT Div. = 45°/205/60°/288°
Cal. Direction: Axial Circ. Bolt
Scan Area: 1 to Weld
11 to Weld

Couplant
Type: ULTRAGEI
Batch: 98325

Search Unit #1
Manufacture: KBA
Serial No.: 0080LR
Size: .375 Shape: ROUND
Freq: 1.5MHz Style: M1600C-Camp
Exam Angle: 45° Mode: SHEAR
Measured Angle: 44°
Wedge Style: NON-INTEGRAL

Search Unit #2
Manufacture: KBA
Serial No.: M15116
Size: .50" Shape: ROUND
Freq: 1.5" Style: M1600S
Exam Angle: 60° Mode: SHEAR
Measured Angle: 58°
Wedge Style: NON-INTEGRAL

Examination Area/Weld	Access	Recordable Indications			Exam Sens.
		Yes	No	Geom	
2R-HB4 45°	D/S	N/A	X	N/A	530
2R-HB-4 60°	D/S	N/A	X	N/A	626

Search Unit Cable
Type: BG-174
Length: 12' No. 1

Search Unit Cable
Type: BG-174
Length: 6' No. 1

Instrument Settings
Make/Model: STANLEY/Sonic 136
Serial No: 1008L
Delay: .293 Range: 205
M'll Cal/Vel: .121 Pulsor: 334
Damping: 500Ω Reject: OFF
Rep. Rate: 4K Freq: 2.25
Filler: 1 Mode: PIE
Reference Sensitivity (Sens.)
Axial: 41:0 Circ: 41:0
SDH Sensitivity: N/A

Instrument Settings
Make/Model: STANLEY/Sonic 136
Serial No: 1008L
Delay: .274 Range: 288"
M'll Cal/Vel: .121 Pulsor: 334
Damping: 500Ω Reject: OFF
Rep. Rate: 4K Freq: 2.25
Filler: 1 Mode: PE
Reference Sensitivity (Sens.)
Axial: 56.6 Circ: 56.6
SDH Sensitivity: N/A

Remarks/Reason for Incomplete Scan(s)
ONE SIDED EXAM DUE TO REDUCER. SCANNED D/S ONLY. TOTAL COVERAGE ACHIEVED IS 75%. SEE ATTACHED PLOT

Examiners: Jimmy E. Kramer Level II Date 04/22/01

[Signature] Level II Date 4-22-01

Reviewers: B. Perkins Further Evaluation Required? Yes No
NOT III

Page 214/240



Calibration Data Sheet

Figure 5

Plant/Unit PNPS

LDS No: 01-L-140
C. Data Sheet # 01-C-157

Company ENTERGY

Page 2 of 2

Comp/System 2B-HB-4

Procedure No. ITI 50.87

Rev/Chng. No. 0

Cal. Block No. PIL-63

Cal. Block Temp. 12 m8699 Therm. S/N

Size 12" Sch. .850 T

Ferritic Austenitic

Each Major CRT Div. = .269


Cal. Direction: Axial Circ. (Both)

Scan Area (L) to Weld
to Weld

Cal. Checks	Time
Initial Calib.	<u>1225</u>
Initial Calib. Date	<u>04/22/01</u>
Intermediate	<u>N/A</u>
Intermediate	<u>N/A</u>
Final Calib.	<u>1830</u>
Final Calib. Date	<u>04/22/01</u>


Couplant

Type: ULTRAGEL
Batch: 98325



Search Unit #1

Manufacture: SIGMA
Serial No.: 22AE9001
Size: 2(14x8) Shape: RECT.
Freq: 2MHZ Style: SDA
Exam Angle: 60° Mode: LONG
Measured Angle: 59°
Wedge Style: INTEGRAL



Search Unit #2

Manufacture: _____
Serial No.: _____
Size: _____ Shape: _____
Freq: _____ Style: _____
Exam Angle: _____ Mode: _____
Measured Angle: _____
Wedge Style: _____

Examination Area/Weld	Access	Recordable Indications			Exam Sens.
		Yes	No	Geom	
<u>2B-HB-4</u>	<u>D/S</u>	<u>N/A</u>	<u>X</u>	<u>N/A</u>	<u>71.2</u>

Remarks/Reason for Incomplete Scan(s)
SCANNED AT REFERENCE SENSITIVITY, MAINTAINING 20% ID ROLL

Examiners: Amy E. Krauser Level II Date 04/22/01

[Signature] Level II Date 4-22-01

Reviewers: B. P. [Signature] Further Evaluation Required? Yes No

NOT III

Search Unit Cable

Type: Buckling
Length: 6' No. 2

Search Unit Cable

Type: _____
Length: _____ No. _____

Instrument Settings

Make/Model: STAVELAND/SONIC
Serial No.: 1008L
Delay: 848 Range: 2169°
M'll Cal/Vol: 233 Pulsar: 250
Damping: 500 Reject: OFF
Rep. Rate: 4K Freq: 225
Filler: 2 Mode: PE
Reference Sensitivity (Sens.)
Axial: 71.2 Circ: 71.2
SDH Sensitivity: N/A

Instrument Settings

Make/Model: _____
Serial No.: _____
Delay: _____ Range: _____
M'll Cal/Vol: _____ Pulsar: _____
Damping: _____ Reject: _____
Rep. Rate: _____ Freq: _____
Filler: _____ Mode: _____
Reference Sensitivity (Sens.)
Axial: _____ Circ: _____
SDH Sensitivity: _____

Page 215/340



Ultrasonic Examination Indication Report Sheet

EDS No: <u>01-E-158</u>	CDS No: <u>01-C-157</u>	Lo Location: <u>TDC</u>	Start Time: <u>1420</u>	Examiner: TC-1A-Level <u>AMUE WADYER</u>
Item Identification: <u>2R-HB-4</u>	TEMP: <u>82°</u>	Wo Location: <u>CENTERLINE</u>	Finish Time: <u>1450</u>	Examiner: TC-1A-Level <u>SHANE CHARBONNET</u>
Component Information: <u>HEADER-BOND (ASME)</u>	Procedure No.: <u>ITI-50.87</u>	Rev.: <u>0</u>	Date: <u>4/22/01</u>	Weid Crown Width: <u>.75</u>
Diameter(nom): <u>12"</u>	Thickness: <u>0</u>			


Ind #	Angle Used	% of DAC	Indication Length			Max		OD S.U. Loc.	Scan Direction I II	Remarks
			L1	Max	L2	W	MP			
<u>N/A</u>	<u>45°</u>								<u>I/II</u>	<u>NO RECORDABLE INDICATIONS</u>
<u>N/A</u>	<u>60°</u>								<u>I</u>	<u>NO RECORDABLE INDICATIONS</u>
<u>N/A</u>	<u>60°RL</u>								<u>I</u>	<u>NO RECORDABLE INDICATIONS</u>

ANII: [Signature] Date 4-25-01
 Reviewer(s) [Signature] Date 4/24/01 Reviewer(s) B. P. [Signature] Date 4/24/01
 Component Meets, Does Not Meet
 ASME Section XI 1989
 Further Evaluation Required Yes No

Figure 6

Page 216/240

COMPONENT
2R-HB-4



FLOW →

COVERAGE

- SCAN 1 AXIAL UPSTREAM = 0%
- SCAN 2 AXIAL DOWNSTREAM = 100%
- SCAN 3 CIRC CLOCKWISE = 100%
- SCAN 4 CIRC COUNTERCLOCKWISE = 100%
- TOTAL COVERAGE = 75%

Amy Elkaner LVII
04/22/01

[Signature] LVII
4-22-01

Page 217240



Entergy

ENN
NUCLEAR
MANAGEMENT
MANUAL

QUALITY RELATED
NON-ADMINISTRATIVE PROCEDURE

INFORMATIONAL USE

ENN-NDE-9.41 Revision 0

Page 15 of 20

ATTACHMENT 9.4

LIQUID PENETRANT EXAMINATION REPORT

Page 1 of 1

<input type="checkbox"/> IP2	<input type="checkbox"/> IP3	<input type="checkbox"/> JAF	<input checked="" type="checkbox"/> PNPS	<input type="checkbox"/> VY	Report No: <u>05-P-432-151</u>
WORK AUTHORIZATION <u>03116627</u>	ISO/DWG <u>N/A</u>	COMPONENT/WELD/ITEM # <u>CRDM</u>		Procedure No: <u>ENN-NDE-9.41</u>	REV. <u>0</u>
MAT'L TYPE <input type="checkbox"/> CS <input checked="" type="checkbox"/> SS	TEMPERATURE EXAM SURF. <u>80°F</u>	TEMP. INST. # <u>208</u> DUE DATE <u>8-9-05</u> <input checked="" type="checkbox"/> M&TE LOGGED	SURFACE CONDITION <input checked="" type="checkbox"/> WELDED <input type="checkbox"/> GROUND <input type="checkbox"/> FORGED <input type="checkbox"/> COATED <input type="checkbox"/> BRUSHED <input type="checkbox"/> MACHINED <input type="checkbox"/> SAND-BLASTED <input type="checkbox"/>		
TECHNIQUE <input checked="" type="checkbox"/> SOLVENT REMOVABLE <input type="checkbox"/> WATER WASHABLE					
METHOD <input checked="" type="checkbox"/> VISIBLE <input type="checkbox"/> FLUORESCENT		BLACK LIGHT MODEL <u>N/A</u> SN <u>N/A</u>	BLACK LIGHT METER: <u>N/A</u> CAL DUE DATE: <u>N/A</u>		
CLEANER Manufacturer: <u>SHERWIN</u> Type: <u>DOUBL CHECK DP-60</u> BATCH # <u>524641</u>		PENETRANT Manufacturer: <u>SHERWIN</u> Type: <u>DOUBL CHECK DP-40</u> BATCH # <u>BIN 517-E1</u>		DEVELOPER Manufacturer: <u>SHERWIN</u> Type: <u>DOUBL CHECK-D-100</u> BATCH # <u>A1988/CB 8766</u>	
EXAMINATION RESULTS					
PART IDENTIFICATION	ACC	REJ	IND. CODE	REMARKS*	
<u>CRDM WELD - Loc 30-51</u>	<input checked="" type="checkbox"/>		<u>4</u>	<u>LIMITED TO 50% WELD AREA</u>	
<u>CRDM WELD - Loc 14-51</u>	<input checked="" type="checkbox"/>		<u>4</u>	<u>DUE TO ACCESSABILITY</u> <u>LIMITED TO 70% WELD AREA</u> <u>DUE TO ACCESSABILITY</u>	
ACCEPTANCE CRITERIA: <u>ASME SEC. XI</u> <u>W 4-11.05</u>					
% COMPLETE: <u>SEE REMARKS</u>			LIMITATIONS: <u>SEE REMARKS</u>		
INDICATION CODE: 1: ROUNDED 2: LINEAR 3: NO INDICATIONS 4: NO RELEVANT INDICATIONS. 5: OTHER					
SKETCHES OR COMMENTS SKETCH-Indicate size, location, orientation, and distribution of indications. Provide dimensions on all sketches. Use additional sheets if required.					
EXAMINED BY/LEVEL/DATE <u>Douglas L. Bokey 4-19-05</u>			EXAMINED BY/LEVEL/DATE <u>N/A</u>		
Company FINAL REVIEW LEVEL/DATE <u>W. Steve 111 4/26/05</u>			ANII REVIEW/DATE <u>Carl Hansen 5/8/05</u>		

* QA Category and ASME XI Class

Page 218 / 240

ATTACHMENT 9.4
LIQUID PENETRANT EXAMINATION REPORT

Page 1 of 1

<input type="checkbox"/> IP2		<input type="checkbox"/> IP3		<input type="checkbox"/> JAF		<input checked="" type="checkbox"/> PNPS		<input type="checkbox"/> VY		Report No: <u>05-P-433-151</u>
WORK AUTHORIZATION <u>03116627</u>			ISO/DWG <u>N/A</u>		COMPONENT/WELD/ITEM # <u>CRDM</u>			Procedure No: <u>ENN-NDE-9.41</u> REV. <u>0</u>		
MAT'L TYPE <input type="checkbox"/> CS <input checked="" type="checkbox"/> SS		TEMPERATURE <u>EXAM SURF. 80°F</u>		TEMP. INST. # <u>208</u> DUE DATE <u>8-9-05</u>		SURFACE CONDITION <input checked="" type="checkbox"/> WELDED <input type="checkbox"/> GROUND <input type="checkbox"/> FORGED <input type="checkbox"/> COATED <input type="checkbox"/> BRUSHED <input type="checkbox"/> MACHINED <input type="checkbox"/> SAND-BLASTED <input type="checkbox"/>				
TECHNIQUE <input checked="" type="checkbox"/> SOLVENT REMOVABLE <input type="checkbox"/> WATER WASHABLE										
METHOD <input checked="" type="checkbox"/> VISIBLE <input type="checkbox"/> FLUORESCENT			BLACK LIGHT MODEL <u>N/A</u> SN <u>N/A</u>			BLACK LIGHT METER: <u>N/A</u> CAL DUE DATE: <u>N/A</u>				
CLEANER Manufacturer: <u>SHERWIN</u> Type: <u>DOUGL CHEK DR-60</u> BATCH # <u>524641</u>			PENETRANT Manufacturer: <u>SHERWIN</u> Type: <u>DOUGL CHEK</u> BATCH # <u>BA 517-E1</u>			DEVELOPER Manufacturer: <u>SHERWIN</u> Type: <u>DOUGL CHEK - D-100</u> BATCH # <u>A19881 / CB 8766</u>				
EXAMINATION RESULTS										
PART IDENTIFICATION				ACC	REJ	IND. CODE	REMARKS*			
<u>CRDM WELD - LOC. 42-47</u>				✓		4	<u>Limited to 50% weld area due to accessibility</u>			
<u>CRDM WELD - LOC. 48-11</u>				✓		4	<u>Limited to 65% weld area due to accessibility</u>			
ACCEPTANCE CRITERIA: <u>ASME SEC. XI</u> <u>WS 4-19-05</u>										
% COMPLETE: <u>SEE REMARKS</u> LIMITATIONS: <u>SEE REMARKS</u>										
INDICATION CODE: 1: ROUNDED 2: LINEAR 3: NO INDICATIONS 4: NO RELEVANT INDICATIONS 5: OTHER										
SKETCHES OR COMMENTS SKETCH-Indicate size, location, orientation, and distribution of indications. Provide dimensions on all sketches. Use additional sheets if required.										
EXAMINED BY/LEVEL/DATE <u>Kenneth R. Ellis II</u> <u>4-19-05</u>						EXAMINED BY/LEVEL/DATE <u>MR</u>				
Company FINAL REVIEW LEVEL/TLD/DATE <u>WS [Signature]</u> <u>111</u> <u>4/26/05</u>						ANII REVIEW/DATE <u>[Signature]</u> <u>5/8/05</u>				

* QA Category and ASME XI Class

BOSTON EDISON COMPANY
 RECORD OF MAGNETIC PARTICLE EXAMINATION

DATA SHEET # 97-M-334 *pg 1 of 2*

ITEM ID/PIECE # <u>EB-23-13HL1 (4)</u>	SYSTEM <u>23</u> LOCATION <u>Torus</u>	MR # <u>19600295</u>	ISO/DWG. NUMBER <u>ISS-I-23-2</u>	REV. <u>E4</u>
---	---	-------------------------	--------------------------------------	----------------

A. MATERIAL	TYPE <u>CS</u>
-------------	-------------------

CROSS SECTION THICKNESS	MAX <u>VARIOUS</u>	MIN	GEOMETRY	PIPE	PLATE	ROD	OTHER <u>X LUG'S</u>
-------------------------	-----------------------	-----	----------	------	-------	-----	-------------------------

FABRICATION PROCESS	CAST	WORKED	<u>WELDED</u>	OTHER
---------------------	------	--------	---------------	-------

SURFACE	MACHINED GROUND	<u>AS FABRICATED</u>	OTHER	INSPECTION HOLD PT <u>FINAL MT</u>
---------	-----------------	----------------------	-------	---------------------------------------

SURFACE IS SUITABLE FOR SCHEDULED <u>X</u> MT ^{N/A} EXAMINATION	<u>YES</u> NO
--	---------------

SKETCH OR OTHER DETAIL ATTACHED	<u>YES</u> NO	WEIGHT <u>X</u> 10 LB. 40 LB
---------------------------------	---------------	------------------------------

B. PROCEDURE # VALIDATION # POLE SPACING	<u>QCI 50.20</u> <u>N-A</u> <u>4" TO 6"</u>	EQUIPMENT IDENTIFICATION <u>X</u> AC HWAC <u>5156</u>
--	---	---

C. EVALUATION	
---------------	--

LOCATION	SIZE (INCHES)	DESCRIPTION	ACTION (ACCEPT, REWORK, REJECT AND COMMENT AS NECESSARY.)
1		<u>NO RECORDABLE INDICATIONS</u>	<u>ACCEPT AS LIMITED EXAMINATION</u>
2			<u>due to HANGER CLAMP SEE</u>
3			<u>SKETCH</u>
4			
5			<u>CODE COVERAGE 87.5%</u>
6			
7			

D. CRITERIA	<u>ASME SECT XI 1989</u>
-------------	--------------------------


E. ATTEST	COMPONENTS <u>MEET</u> DO NOT MEET ASME SECTION XI ACCEPTANCE CRITERIA, FURTHER EVALUATION REQUIRED <u>YES</u> <u>X</u> NO
-----------	--

	<u>C. Bell</u> <u>IR</u> <u>II</u> <u>3/18/97</u> RESPONSIBLE CERTIFIED PERSONNEL LEVEL DATE
	<u>B. Rubin</u> <u>3/19/97</u> <u>ANIA</u> <u>3/19/97</u> BECO LEVEL III DATE DATE

SKETCH SHEET

ITEM ID# ER-23-13HL1 (4)

me# 19600295



TYPICAL
1 of 4



HANGER CLAMP TYPICAL



LIMITED EXAM DUE TO HANGER CLAMP

CODE COVERAGE 87.5%

C. E. Bell Lt. II 3-18-97

Page 2 of 2
Page 221/240

RECORD OF MAGNETIC PARTICLE EXAMINATION			DATA SHEET # <u>01-M-272</u>
ITEM ID/PIECE #	SYSTEM <u>(23) HPCI</u>	MR#	ISO/DWG NUMBER
<u>EB-23-59HL1 (4)</u>	LOCATION <u>HPCI Room</u> <u>ELV. 10'</u>	<u>10000542</u>	<u>151-1-23-2</u>
A. MATERIAL		TYPE <u>CARBON STEEL</u>	
CROSS SECTION THICKNESS	MAX <u>N/A</u>	MIN <u>N/A</u>	PIPE PLATE ROD OTHER GEOMETRY <u>N/A</u> <u>N/A</u> <u>N/A</u> <u>LUG TO PIPE WELDS</u>
FABRICATION PROCESS		CAST WORKED <u>WELDED</u> OTHER _____	
SURFACE	MACHINED GROUND AS FABRICATED	OTHER _____	INSPECTION HOLD PT <u>1.S.I.</u>
SURFACE IS SUITABLE FOR SCHEDULE <input checked="" type="checkbox"/> MT <input checked="" type="checkbox"/> UT EXAMINATION <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO			
SKETCH OR OTHER DETAIL ATTACHED YES/NO		WEIGHT <input checked="" type="checkbox"/> 10 LB <input type="checkbox"/> 40 LB	
B. PROCEDURE #	<u>17 50.20</u>	EQUIPMENT IDENTIFICATION	
VALIDATION #	<u>N/A</u>	AC <input checked="" type="checkbox"/> HWAC <input type="checkbox"/>	
POLE SPACING	<u>6"</u>	S/N <u>69</u>	
C. EVALUATION			
<u>N.R.I. OBTAINED 83.3% COVERAGE DUE TO LUG TO CLAMP CONFIGURATION.</u>			
LOCATION	SIZE (INCHES)	DESCRIPTION	ACTION (ACCEPT, REWORK, REJECT AND COMMENT AS NECESSARY)
1.			
2.			
3.			
4.			
5.			
6.			
7.			
D. CRITERIA	COMPONENTS MEET/DO NOT MEET ASME SECTION XI CRITERIA FURTHER EVALUATION REQUIRED <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		
E. ATTEST	ASME SECT. XI 1989		
	<u>[Signature]</u>	RESPONSIBLE CERTIFIED PERSONNEL	LEVEL <u>III</u> DATE <u>5/3/01</u>
	<u>[Signature]</u>	NDT LEVEL III	DATE <u>5/14/01</u>

B. Perkins 5/3/01
 ENERGY III DATE

BOSTON EDISON COMPANY
RECORD OF MAGNETIC PARTICLE EXAMINATION

DATA SHEET # *Page 1 of 2*
97-M-302

ITEM ID/PIECE # <i>HL-10-200HL(4)</i>	SYSTEM <i>10</i> LOCATION <i>R# Aquad</i>	MR # <i>19600301</i>	ISO/DWG NUMBER <i>ISI-I-10-4A-SH-1</i>	<i>Rev. E4</i>
--	--	-------------------------	---	----------------

A. MATERIAL	TYPE <i>CS</i>
-------------	-------------------

CROSS SECTION THICKNESS	MAX <i>VAR 1003</i>	MIN	GEOMETRY	PIPE	PLATE	ROD	OTHER <i>X LOG'S</i>
-------------------------	------------------------	-----	----------	------	-------	-----	-------------------------

FABRICATION PROCESS	CAST	WORKED	<u>WELDED</u>	OTHER
---------------------	------	--------	---------------	-------

SURFACE	MACHINED	<u>GROUND</u>	AS FABRICATED	OTHER	INSPECTION HOLD PT <i>FINAL MT</i>
---------	----------	---------------	---------------	-------	---------------------------------------

SURFACE IS SUITABLE FOR SCHEDULED *X* MT $\frac{1}{2}$ UT EXAMINATION: YES/NO

SKETCH OR OTHER DETAIL ATTACHED	<u>YES</u> /NO	WEIGHT	<i>X</i> 10 LB. <u>40</u> LB.
---------------------------------	----------------	--------	-------------------------------

B. PROCEDURE # VALIDATION # POLE SPACING	<i>QCI 50.20</i> <i>N-A</i> <i>4"-6"</i>	EQUIPMENT IDENTIFICATION <i>X</i> AC <u>5156</u> HWAC
--	--	---

C. EVALUATION	
---------------	--

LOCATION	SIZE (INCHES)	DESCRIPTION	ACTION (ACCEPT, REWORK, REJECT AND COMMENT AS NECESSARY.)
1	<i>NO RECORDABLE</i>	<i>INDICATIONS</i>	<i>LIMITED EXAMINATION. ACCEPT</i>
2			<i>(LIMITED ON UPSTREAM SIDE OF LOG'S BY HANGER CLAMP SEE SKETCH.)</i>
3			
4			
5			<i>CODE COVERAGE 90%</i>
6			
7			

D. CRITERIA	<i>ASME Sect. XI 1989</i>
-------------	---------------------------


COMPONENTS MEET DO NOT MEET ASME SECTION XI ACCEPTANCE CRITERIA, FURTHER EVALUATION REQUIRED: YES *X* NO

E. ATTEST	<i>C. P. Mills</i> RESPONSIBLE CERTIFIED PERSONNEL LEVEL <i>GE REVIEWED BY: M. Jones</i> LEVEL <i>B. P. Pukini</i> BECO LEVEL III	<i>II</i> DATE <i>3/14/97</i>	<i>III</i> DATE <i>3/14/97</i>
-----------	---	-------------------------------------	--------------------------------------

SKETCH SHEET

ITEM ID # HL-10-200HL (4)

FOR DATA SHEET # 97-M-302
Page 2 of 2



HANGER CLAMP

TYPICAL 1 of 4

CODE COVERAGE 90%



Calibration Data Sheet



CDS No: 05-C-377-151
 LDS No: 05-L-338-151 *7/15/05*
 Page: 4 of 4

Plant/Unit: PILGRIM / 1
 System: CORE SPRAY
 Component: GB-14-F34
 Line No.: 6" - GB-14
 Procedure: ENP-ME-9.10 Rev.: 0
 Thermometer S/N: 232
 Cal. Blk Temp.: 63°F Comp Temp.: 64°F
 Cal. Block No.: PIL-96
 Carbon Steel Stainless Steel
 Size: 6" Sch.: .432"
 Cal Direction Axial Circ Both
 Scan Area ⊥ to weld
 Scan Area || to weld

Work Order: 03116642
 DWG No.: ISI I 14-2B

Cal Checks	Time
Initial Cal.:	<u>0945</u>
Date:	<u>4-25-05</u>
Inter. Cal.:	
Date:	
Inter. Cal.:	
Date:	
Final Cal.:	<u>1603</u>
Date:	<u>4-25-05</u>

Couplant
 Type: ULTRAGEL II
 Batch: 01225



Search Unit # 1

Manufacturer: RTD
 Model: TRLA
 Serial No.: 98-1082
 Size: 2(7x10) Shape: RECT
 Freq.: 2 MHz # Elm: 2
 Angle: 70° Mode: LONG
 Measured Angle: 71°

Wedge Style: INTEGRAL

Search Unit Cable

Type: RG 174
 Length: 6' # Con.: 0

Instrument Settings

Manufacturer: STANLEY
 Model: SONIC 136
 Serial No.: 136-875K
 Linearity Due: 5-2-05
 Delay: .815 Range: 2.00
 Mtl. Vel.: .230 Pulser: 250
 Damping: 500 Reject: OFF
 Rep Rate: 4K Freq.: 2.25
 Filter: 2 Mode: DUAL

Reference Sensitivity

Axial: 72.2 Circ: N/A

Search Unit # 2

Manufacturer: _____
 Model: _____
 Serial No.: _____
 Size: _____ Shape: _____
 Freq.: _____ # Elm: _____
 Angle: _____ Mode: _____
 Measured Angle: _____

Wedge Style: _____

Search Unit Cable

Type: _____
 Length: _____ # Con.: _____

Instrument Settings

Manufacturer: N/A
 Model: _____
 Serial No.: _____
 Linearity Due: _____
 Delay: _____ Range: _____
 Mtl. Vel.: _____ Pulser: _____
 Damping: _____ Reject: _____
 Rep Rate: _____ Freq.: _____
 Filter: _____ Mode: _____

Reference Sensitivity

Axial: _____ Circ: _____

Examination Area / Weld	Access	Recordable Indications			Exam Sens.
		Yes	No	Geom.	
<u>GB-14-F34</u>	<u>SINGLE</u>	<u>N/A</u>	<u>✓</u>	<u>N/A</u>	<u>66.2*</u>

Remarks
* SCANNED BELOW REFERENCE DUE TO HIGH NOISE LEVELS

Further Evaluation Required: Yes No

Examiner: [Signature] Level: III Date: 4-25-05
 Examiner: N/A Level: N/A Date: N/A
 Reviewer: W.D. [Signature] Level: III Date: 4/27/05
 ANII: [Signature] Date: 4/25

Page 224/240



Examination Data Sheet

EDS No: 05-E-~~380~~-151 ⁴⁹³
 CDS No: 05-C-~~379~~-151-492-151
 LDS No: 05-L-~~378~~-151-491-151 ^{7/27/05}
 Page: 1 of 4

Plant/Unit: <u>PILGRIM / 1</u>			System: <u>CORE SPRAY</u>				Component: <u>GB-14-F34</u>			Procedure: <u>ENN-NDE-9.10</u>					
Work Order: <u>03116642</u>			DWG No.: <u>ISI I 14-2B</u>				<input checked="" type="checkbox"/> Carbon Steel <input checked="" type="checkbox"/> Stainless Steel			Revision: <u>0</u>					
Examination Area / Weld No.: <u>GB-14-F34</u>			Line No.: <u>6"-GB-14</u>				Size: <u>6"</u> Schedule: <u>.280"</u>			Start Time/Date: <u>1345 / 4-28-05</u> Finish Time/Date: <u>1540 / 4-25-05</u>					
Lo Location: <u>N/A</u>			Wo Location: <u>N/A</u>												
Ind. #	Angle	% of DAC	Indication Length			Max Location		OD SU Loc.	Scan Direct.	Remarks:					
			L1	L Max	L2	W	MP								
<u>N.R.I.</u>															
Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No								Limitations: <u>ONE SIDED EXAM - 29.75% C.R.V.</u>							
Remarks <u>N/A</u>															
Examiner: <u>[Signature]</u>				Level: <u>III</u>				Date: <u>4-25-05</u>				Examiner: <u>N/A</u>			
Level: <u>N/A</u>				Date: <u>N/A</u>				Reviewer: <u>[Signature]</u>				Level: <u>III</u>			
Date: <u>4/27/05</u>				ANII: <u>[Signature]</u>				Date: <u>5/1/05</u>							


Boqr 03/1/05



Sketch Sheet

Data Sheet No: ⁴⁷³ ~~OS-E-380-151~~ ^{7/28/05} ~~577/15~~
 Page: 2 of 4

Plant/Unit: <u>PILGRIM / 1</u>	System: <u>CORE SPRAY</u>	Component: <u>GB-14-F34</u>	Procedure: <u>ENW-NDE-9.6</u>
Examination Area / Weld No.: <u>GB-14-F34</u>	DWG No.: <u>ISI I 14-2B</u>	Line No.: <u>6"-GB-14</u>	Revision: <u>6</u>
			Work Order: <u>03116642</u>



* FORWARD POINT OF 60° & 70° SHEAR EXAMS.

log 226/240


Examiner: <u>[Signature]</u> Level: <u>III</u> Date: <u>4-25-05</u>	Examiner: <u>N/A</u> Level: <u>N/A</u> Date: <u>N/A</u>
Reviewer: <u>[Signature]</u> Level: <u>III</u> Date: <u>4/27/05</u>	ANII: <u>[Signature]</u> Date: <u>5/2/05</u>



Sketch Sheet

Data Sheet No: ⁴⁹³ 05-E-~~38~~-151 ^{7/2/05}
Page: 3 of 4

Plan/Unit: <u>PILGRIM / 1</u>	System: <u>CORE SPRAY</u>	Component: <u>GB-14-F34</u>	Procedure: <u>EWN-NDE-910</u>
Examination Area / Weld No.: <u>GB-14-F34</u>	DWG No.: <u>ISI I 14-2B</u>	Line No.: <u>6" - GB-14</u>	Revision: <u>0</u>
			Work Order: <u>03116642</u>



Examiner: <u>[Signature]</u> Level: <u>III</u> Date: <u>4-25-05</u>	Examiner: <u>[Signature]</u> Level: <u>N/A</u> Date: <u>N/A</u>
Reviewer: <u>[Signature]</u> Level: <u>III</u> Date: <u>4/27/05</u>	ANII: <u>[Signature]</u> Date: <u>5/9/05</u>

Boqr 227/240



Sketch Sheet

Data Sheet No: ⁴⁹³05-E-~~388~~-151 ^{7ms} 5/17/05
 Page: 4 of 4

Plan/Unit: PILGRIM / 1	System: CORE SPRAY	Component: GB-14-F34	Procedure: ENN-NDE-9.10 Revision: ϕ
Examination Area / Weld No.: GB-14-F34	DWG No.: ISI I 14-2B	Line No.: 6" - GB-14	Work Order: 03116642

GB-14-F34 PREP DID NOT MEET PARA. 5.3.4.9 OF ENN-NDE-9.10. DUE TO SURFACE GAPS EXCEEDING 1/32" NO COVERAGE WAS CLAIMED ON WELD IN AX OR. CIRC DIRECTIONS. 60° SHEAR WAS SCANNED IN CIRC DIRECTION TO ENHANCE 45° SCAN DUE TO WIDE WELD CROWN. 60° & 70° RL'S WERE SCANNED FROM PIPE SIDE BUT WELD CROWN REINFORCEMENT PRECLUDED SUFFICIENT FORWARD MOVEMENT FOR SOUND TO REACH THE WELD CENTERLINE.

CODE REQUIRED VOLUME:

AXIAL SCANS - 40%
 CIRC SCANS - 19.5%
 CRV - 29.75%

^{Box} (.11 x 1.40) ⁶⁰ 4-2-05
 TOTAL EXAM AREA - .154 in²
 AXIAL AREA SCANNED - .0735 in²
 CIRC AREA SCANNED - .013 in²

Examiner: [Signature] Level: III Date: 4-25-05

Examiner: N/A Level: N/A Date: N/A

Reviewer: [Signature] Level: III Date: 4/27/05

ANII: [Signature] Date: 5/1/05


Req. 228240

RECORD OF MAGNETIC PARTICLE EXAMINATION		DATA SHEET # <u>03-14-064</u>	
ITEM ID/PIECE #	SYSTEM	MR#	ISO/DWG NUMBER
<u>GB-10-9-2E</u>	<u>RIR</u> LOCATION <u>TORUS ROOM</u>	<u>0115999</u>	<u>ISI-I-10-4B 04.1</u>
A. MATERIAL		TYPE <u>C.S.</u>	
CROSS SECTION THICKNESS	MAX <u>.375"</u>	MIN <u>N/A</u>	PIPE PLATE ROD OTHER GEOMETRY <u>✓</u>
FABRICATION PROCESS		CAST WORKED <u>(WELDED)</u> OTHER _____	
SURFACE		<u>MACHINED GROUND</u> AS OTHER FABRICATED	INSPECTION HOLD PT <u>I.S.I.</u>
SURFACE IS SUITABLE FOR SCHEDULE <input checked="" type="checkbox"/> MT <input checked="" type="checkbox"/> UT EXAMINATION <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO			
SKETCH OR OTHER DETAIL ATTACHED		YES <input checked="" type="checkbox"/> NO <input type="checkbox"/> WEIGHT <input checked="" type="checkbox"/> 10 LB <input type="checkbox"/> 40 LB	
B. PROCEDURE #		<u>50.20</u>	
VALIDATION #		<u>N/A</u>	
POLE SPACING		<u>6"</u>	
EQUIPMENT IDENTIFICATION		<u>BEFORE AND AFTER</u>	
AC <input checked="" type="checkbox"/> HWAC <input type="checkbox"/>		SN <u>70</u>	
C. EVALUATION			
LOCATION	SIZE (INCHES)	DESCRIPTION	ACTION (ACCEPT, REWORK, REJECT AND COMMENT AS NECESSARY)
1.			<u>NRI-ACCEPT</u>
2.			<u>85% coverage obtained.</u>
3.			<u>BP</u>
4.			
5.		<u>ISI GLOOP NOTED.</u>	
6.		<u>BP 4/10/03</u>	
7.			
D. CRITERIA		COMPONENTS <u>(MPE)</u> DO NOT MEET ASME SECTION XI CRITERIA FURTHER EVALUATION REQUIRED <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
E. ATTEST		<u>ASME XI 1989</u>	
RESPONSIBLE CERTIFIED PERSONNEL		LEVEL <u>II</u>	
<u>B. P. P. P.</u>		<u>IL</u>	
DATE <u>4-1-03</u>		DATE <u>3/27/03</u>	
NDT LEVEL III		ANII	

D.S. No. 03-M-064
Pg 2 of 2

DATA SHEET # 03-M-064
COMPONENT # GB 10-9-2E
PAGE 2 OF 2

Page 230/240



EXAMINER Richard R. Danner LEVEL II DATE 3-27-03



Calibration Data Sheet

Figure 5


Plant/Unit PILGRIM / U1
 Company ENERGY
 Comp/System RHA
 Procedure No. 5071
 Rev/Chng. No. 610
 Cal. Block No. PL-47A
 Cal. Block Temp. 67° Therm S/N 12297
 Size 18" Sch. 0375" T
 Ferritic Austenitic
 Each Major CRT Div. = 0.2/0.25"
 Cal. Direction: Axial Circ. Both
 Scan Area: II to Weld
II to Weld

LOS NO. 03-L-046
 Data Sheet # 03-C-072
 Page 1 of 1

Cal. Checks	Time
Initial Calib.	<u>1745</u> <u>1748</u>
Initial Calib. Date	<u>3-27-03</u>
Intermediate	<u>N</u>
Intermediate	<u>A</u>
Final Calib.	<u>2049</u> <u>2050</u>
Final Calib. Date	<u>3-27-03</u>

Couplant


Type: ULTRAGEL II
 Batch: 00325



Manufacture: KBA
 Serial No.: 00WPL4
 Size: 0.25" Shape: ROUND
 Freq: 5.0 Style: COMP 6
 Exam Angle: 45 Mode: SHEAR
 Measured Angle: 40°
 Wedge Style: ST

Search Unit Cable
 Type: R6-174/14
 Length: 6' No. 0

Instrument Settings
 Make/Model: STAVLEY/SONG-136
 Serial No.: 8011300
 Delay: 0.167 Range: 2.0"
 Mtl Cal/Wet: 0125 Putser: 100%
 Damping: 500.0 Reject: OFF
 Rep. Rate: 4K Freq: 5.0
 Filter: 1 Mode: P/E
 Reference Sensitivity (Sens.)
 Axial: 34.6 Circ: 34.6
 SCAN SENS: 58.0



Manufacture: KBA
 Serial No.: 00WPL4
 Size: 0.25" Shape: ROUND
 Freq: 5.0 Style: COMP 6
 Exam Angle: 70° Mode: SHEAR
 Measured Angle: 71°
 Wedge Style: ST

Search Unit Cable
 Type: R6-174/14
 Length: 6' No. 0

Instrument Settings
 Make/Model: STAVLEY/SONG-136
 Serial No.: 8011300
 Delay: 0.371 Range: 2.5
 Mtl Cal/Wet: 0126 Putser: 100%
 Damping: 500.0 Reject: OFF
 Rep. Rate: 4K Freq: 5.0
 Filter: 1 Mode: P/E
 Reference Sensitivity (Sens.)
 Axial: 60.0 Circ: NA
 SCAN SENS: 67.0

Examination Area/Weld	Access	Recordable Indications			Exam Sens.
		Yes	No	Geom	
<u>GB-10-9-2E</u>	<u>PIPE SLOE</u>	<u>NA</u>	<u>X</u>	<u>NA</u>	<u>67</u>
	<u>N</u>				
	<u>A</u>				

Remarks/Reason for Incomplete Scan(s) SEE ATTACHED DRAWING FOR INCOMPLETE AREAS
EXAM IS 63.75% COMPLETE

Examiners: Edward P. A... Level III Date 3-27-03
NA Level NA Date NA
 Reviewers: B.P. Perkins Further Evaluation Required? Yes
Energy III 4-2-03

03/23/04



Ultrasonic Examination Indication Report Sheet

CDS No: <u>03-C-072</u>	EDS No: <u>03-E-073</u>	Lo Location: <u>DATUM 0</u>	Start Time <u>1915</u>	Examiner: TC-1A-Level <u>Robert R. Brown III</u>
Item Identification: <u>GR-10-9-2E</u>	TEMP. <u>76° F</u>	Wo Location: <u>E OF WELD</u>	Finish Time <u>1945</u>	Examiner: TC-1A-Level <u>N/A</u>
Component Information: Diameter (nom): <u>18"</u> Thickness: <u>0.42"</u>		Procedure No. <u>50.71</u>	Rev. <u>6</u>	Date: <u>7-27-03</u> Weld Crown Width: <u>1.1"</u>

Ind #	Angle Used	% of DAC	Indication Lengths			Max		OO S.U. Loc.	Scan Direction J. II	Remarks
			L 1	Max	L 2	W	MP			
	45°									NRI
	70°									NRI


ANII: WJ/MS Date 4-11-03
 Reviewer(s) B. Perkins Date 4-27-03 Reviewer(s) N/A Date N/A
 Component Meets, Does Not Meet ASME Section XI 1989 **COVERAGE**.
 Further Evaluation Required Yes No

Page 232/240

Entropy III

Figure 6

Instruction No. 50.71
Rev. 5
Attachment A
Page 24 of 26




* GEOMETRY IS worse on this side as compared to profile side.
 B. Perkins
 4-2-03

$19.292 - 3.185 = 16.107$
 $19.292 - 10.803 = 8.489$

$16.107 \div 19.292 = 83.5\%$ ONE DIRECTION
 $8.489 \div 19.292 = 44\%$ ONE DIRECTION
 $127.5\% \div 2 = 63.75\%$ TOTAL COVERAGE

CIRCUMFERENCE = 53"
 INNER $\frac{1}{3}$ = 0.364 SQ IN.
 TOTAL CU IN = 19.292 5.096
 14" NO SCAN TOTAL CU IN = 4.356 ^{2.00} 3.2703
 MISSED SCAN AREA
 70° = 3.185 CU IN MISSED ONE DIRECTION
 70° = 10.803 CU IN MISSED ONE DIRECTION



14" NO SCAN DUE TO PIPE CLAMP OBSTRUCTION

EXAMINER Edward R. Dawn LEVEL TII DATE 3-28-03

Page 233/240



Calibration Data Sheet

CDS No: 05-c-338-151
 LDS No: 05-L-323-151
 Page: 1 of 1

Plant/Unit: PILGRIM / 1
 System: RCIC
 Component: HE-26-F238
 Line No.: 6"-HE-26
 Procedure: EN-NDE-9.04 Rev.: 1
 Thermometer S/N: 229
 Cal. Blk Temp.: 68°F Comp Temp.: 73°F
 Cal. Block No.: PIL-39A
 Carbon Steel Stainless Steel
 Size: 6" Sch.: .280"

Work Order: 03116633
 DWG No.: ISI I 13-5

Cal Checks	Time
Initial Cal.:	<u>1620/1625</u>
Date:	<u>3-28-05</u>
Inter. Cal.:	
Date:	
Inter. Cal.:	<u>N/A</u>
Date:	
Final Cal.:	<u>1910/1913</u>
Date:	<u>2-28-05</u>

Cal Direction Axial Circ Both
 Scan Area ⊥ to weld
 Scan Area || to weld

Couplant
 Type: ULTRAGEL II
 Batch: 01225

Search Unit # 1
 Manufacturer: KBA
 Model: COMP-G
 Serial No.: 0114 PT
 Size: .25" Shape: ROUND
 Freq.: 5 MHz # Elm: 1
 Angle: 70° Mode: SHEAR
 Measured Angle: 69
 Wedge Style: MSWAC
 Search Unit Cable
 Type: RG 174
 Length: 6' # Con.: 0

Search Unit # 2
 Manufacturer: KBA
 Model: COMP-G
 Serial No.: 0114 PW
 Size: .25" Shape: ROUND
 Freq.: 5 MHz # Elm: 1
 Angle: 45° Mode: SHEAR
 Measured Angle: 45
 Wedge Style: MSWAC
 Search Unit Cable
 Type: RG 174
 Length: 6' # Con.: 0

Examination Area / Weld	Access	Recordable Indications			Exam Sens.
		Yes	No	Geom.	
<u>HE-26-F238</u>	<u>BOTH</u>	<u>N/A</u>	<u>✓</u>	<u>N/A</u>	<u>400/300</u>
	<u>SINGLE</u>				

Remarks
LAMINATION SCAN - N.R.I.

Further Evaluation Required: Yes No

Examiner: [Signature] Level: III Date: 3-28-05
 Examiner: N/A Level: N/A Date: N/A
 Reviewer: [Signature] Level: JIT/P Date: 4-4-05/4/15
 ANII: [Signature] Date: 4/1/05

Instrument Settings
 Manufacturer: KRAUTKRAMER
 Model: USN 52L
 Serial No.: 00HFX2
 Linearity Due: 4-4-05
 Delay: 5.656 Range: 1.500
 Mtl. Vel.: 1370 Pulsar: SINGLE
 Damping: 1000 Reject: OFF
 Rep Rate: HIGH Freq.: 2-8
 Filter: FULL Mode: SINGLE
 Reference Sensitivity
 Axial: 51.0 Circ: N/A

Instrument Settings
 Manufacturer: KRAUTKRAMER
 Model: USN 52L
 Serial No.: 00HFX2
 Linearity Due: 4-4-05
 Delay: 2.336 Range: 1.000
 Mtl. Vel.: 1262 Pulsar: SINGLE
 Damping: 1000 Reject: OFF
 Rep Rate: HIGH Freq.: 2-8
 Filter: FULL Mode: SINGLE
 Reference Sensitivity
 Axial: N/A Circ: 18.0

Boq 234/240



Examination Data Sheet

EDS No: 05-E-337-151
 CDS No: 05-C-338-151
 LDS No: 05-L-333-151
 Page: 1 of 2

Plant/Unit: <u>PILGRIM / 1</u>		System: <u>RCIC</u>		Component: <u>HE-26-F238</u>		Procedure: <u>ENP-NDE-9.04</u>				
Work Order: <u>03116633</u>		DWG No.: <u>ISI I 13-5</u>		<input checked="" type="checkbox"/> Carbon Steel <input type="checkbox"/> Stainless Steel		Start Time/Date: <u>1735</u> Finish Time/Date: <u>1815</u>				
Examination Area / Weld No.: <u>HE-26-F238</u>		Line No.: <u>6"-HE-26</u>		Size: <u>6"</u> Schedule: <u>.280"</u>		Lo Location: <u>N/A</u> Wo Location: <u>N/A</u>				
Ind. #	Angle	% of DAC	Indication Length			Max Location		OD SU Loc.	Scan Direct.	Remarks:
			L1	L Max	L2	W	MP			
<u>NRT</u>										
Further Evaluation Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No								Limitations: <u>ONE SIDED EXAM</u>		
Remarks: <u>NO RECORDABLE IND FOR LAMINATION SCAN</u>										
Examiner: <u>[Signature]</u> Level: <u>III</u> Date: <u>5-28-05</u>				Examiner: <u>N/A</u> Level: <u>N/A</u> Date: <u>N/A</u>						
Reviewer: <u>[Signature]</u> Level: <u>III</u> Date: <u>4-4-05</u>				ANII: <u>[Signature]</u> Date: <u>4/21/05</u>						
Reviewer: <u>Michael Shum</u> Level: <u>III</u> Date: <u>4/4/05</u>										

Page 235/240




Sketch Sheet

Data Sheet No: 05-E-339-151

Page: 2 of 2

Plant/Unit: <u>PILGRIM / 1</u>	System: <u>RCIC</u>	Component: <u>HE-26-F238</u>	Procedure: <u>ENW-NDE-9.04</u> Revision: <u>1</u>
Examination Area / Weld No.: <u>HE-26-F238</u>	DWG No.: <u>ISI I 13-5</u>	Line No.: <u>6" HE-26</u>	Work Order: <u>03116633</u>



AXIAL SCAN - 87.5%

CIRC SCAN - 50%

TOTAL CODE REQUIRED VOLUME - 68.75%

Examiner: <u>[Signature]</u> Level: <u>III</u> Date: <u>3-28-05</u>	Examiner: <u>N/A</u> Level: <u>N/A</u> Date: <u>N/A</u>
Reviewer: <u>[Signature]</u> Level: <u>III</u> Date: <u>4-4-05</u>	ANII: <u>[Signature]</u> Date: <u>4/2/05</u>
REVISIONS: <u>[Signature]</u> <u>III</u> <u>4/4/05</u>	

Page 236/240

This page intentionally left blank

Page 237/240

This page intentionally left blank

Page 238/240

This page intentionally left blank

Page 239/240