



# International Agreement Report

---

## RELAP5/MOD.2 Post Test Analysis and Accuracy Quantification of Lobi Test BL-34

Prepared by  
F. D'Auria  
M. Frogheri\*  
W. Giannoti

University of Pisa  
Via Diotisalvi 2-56100  
Pisa, Italy

\*University of Genova  
DITEC  
Via all'Opera Pia 15a  
16143 Genova, Italy

**Office of Nuclear Regulatory Research  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001**

**February 1999**

Prepared as part of  
The Agreement on Research Participation and Technical Exchange  
under the International Code Application and Maintenance Program (CAMP)

**Published by  
U.S. Nuclear Regulatory Commission**

## AVAILABILITY NOTICE

### Availability of Reference Materials Cited in NRC Publications

NRC publications in the NUREG series, NRC regulations, and *Title 10, Energy, of the Code of Federal Regulations*, may be purchased from one of the following sources:

1. The Superintendent of Documents  
U.S. Government Printing Office  
P.O. Box 37082  
Washington, DC 20402-9328  
<[http://www.access.gpo.gov/su\\_docs](http://www.access.gpo.gov/su_docs)>  
202-512-1800
2. The National Technical Information Service  
Springfield, VA 22161-0002  
<<http://www.ntis.gov/ordernow>>  
703-487-4650

The NUREG series comprises (1) technical and administrative reports, including those prepared for international agreements, (2) brochures, (3) proceedings of conferences and workshops, (4) adjudications and other issuances of the Commission and Atomic Safety and Licensing Boards, and (5) books.

A single copy of each NRC draft report is available free, to the extent of supply, upon written request as follows:

Address: Office of the Chief Information Officer  
Reproduction and Distribution  
Services Section  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001  
E-mail: <[GRW1@NRC.GOV](mailto:GRW1@NRC.GOV)>  
Facsimile: 301-415-2289

A portion of NRC regulatory and technical information is available at NRC's World Wide Web site:

<<http://www.nrc.gov>>

All NRC documents released to the public are available for inspection or copying for a fee, in paper, microfiche, or, in some cases, diskette, from the Public Document Room (PDR):

NRC Public Document Room  
2121 L Street, N.W., Lower Level  
Washington, DC 20555-0001  
<<http://www.nrc.gov/NRC/PDR/pdr1.htm>>  
1-800-397-4209 or locally 202-634-3273

Microfiche of most NRC documents made publicly available since January 1981 may be found in the Local Public Document Rooms (LPDRs) located in the vicinity of nuclear power plants. The locations of the LPDRs may be obtained from the PDR (see previous paragraph) or through:

<<http://www.nrc.gov/NRC/NUREGS/SR1350/V9/lpdr/html>>

Publicly released documents include, to name a few, NUREG-series reports; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigation reports; licensee event reports; and Commission papers and their attachments.

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, and transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at the NRC Library, Two White Flint North, 11545 Rockville Pike, Rockville, MD 20852-2738. These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute  
11 West 42nd Street  
New York, NY 10036-8002  
<<http://www.ansi.org>>  
212-642-4900

#### DISCLAIMER

This report was prepared under an international cooperative agreement for the exchange of technical information. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third

party's use, or the results of such use, of any information, apparatus, product, or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

## ACKNOWLEDGMENTS

The authors wish to acknowledge the technical support given to the present research by Dr. P. Marsili by ANPA, who also stimulated the same activity.

At DCMN of University of Pisa thanks are due to Dr. G. M. Galassi for storing the needed data and for the suggestions given for solving some of the encountered problems, and to Prof. F. Oriolo for managing the activity.



NUREG/IA-0152



# International Agreement Report

---

## RELAP5/MOD.2 Post Test Analysis and Accuracy Quantification of Lobi Test BL-34

Prepared by  
F. D'Auria  
M. Frogheri\*  
W. Giannotti

University of Pisa  
Via Diotisalvi 2-56100  
Pisa, Italy

\*University of Genova  
DITEC  
Via all'Opera Pia 15a  
16143 Genova, Italy

Office of Nuclear Regulatory Research  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

February 1999

Prepared as part of  
The Agreement on Research Participation and Technical Exchange  
under the International Code Application and Maintenance Program (CAMP)

Published by  
U.S. Nuclear Regulatory Commission



# CONTENTS

<b>ABSTRACT</b>	<b>5</b>
<b>LIST OF FIGURES</b>	<b>7</b>
<b>LIST OF TABLES</b>	<b>9</b>
<b>1. INTRODUCTION</b>	<b>11</b>
<b>2. DESCRIPTION OF THE EXPERIMENT</b>	<b>13</b>
2.1 LOBI facility	13
2.2 Test BL-34	17
<b>3. ADOPTED CODE AND NODALIZATION</b>	<b>21</b>
3.1 Relap5/Mod3.2 code	21
3.2 General criteria adopted for the code models	21
3.3 LOBI/MOD2 nodalization description	22
3.4 Nodalization qualification	29
<b>4. ANALYSIS OF POST-TEST CALCULATION RESULTS</b>	<b>33</b>
4.1 Steady State calculations	33
4.2 Reference calculation results	34
4.2.1 Qualitative and quantitative accuracy evaluation	42
4.3 Sensitivity calculations	47
<b>5. CONCLUSIONS</b>	<b>57</b>
<b>REFERENCES</b>	<b>59</b>
<b>LIST OF ABBREVIATIONS</b>	<b>61</b>
<b>SUBSCRIPTS</b>	<b>61</b>
APPENDIX 1: Steady state calculation	
APPENDIX 2: Results of the reference calculation (run B34D)	
APPENDIX 3: Results of the sensitivity analyses (runs B341, B342, B343, B344, B345 and B346)	
APPENDIX 4: Reference calculation input deck	





## **ABSTRACT**

The present document deals with the Relap5/Mod3.2 analysis of the small break LOCA experiment BL-34 performed in LOBI/MOD2 facility.

LOBI/MOD2 was a PWR simulator (Integral Test Facility) installed at JRC (Joint Research Center) in Ispra Establishment (I). Volume scaling and core power scaling factors are 1/712, with respect to the KWU Siemens 1300 MWe (3900 MWt) standard reactor.

The experiment is originated by a small break in the cold leg (2" equivalent break area in the plant) without the actuation of the high pressure injection system. Low pressure injection system actuation occurs after core dry-out and accumulators intervention is foreseen when primary pressure falls below 4 MPa.

The Relap5 code has been extensively used at University of Pisa; the nodalization of LOBI facility has been qualified through the application of the version Relap5/Mod2 to the same experiment and another test performed in the same facility.

Sensitivity analyses have been addressed to the influence of several parameters (like discharge break coefficient, time of accumulators start etc.) upon the predicted transient evolution.

Qualitative and quantitative code calculation accuracy evaluation has been performed.



## LIST OF FIGURES

Fig. 1: LOBI/MOD2 facility - primary circuit.....	15
Fig. 2: LOBI/MOD2 facility - secondary circuit .....	16
Fig. 3: BL-34 test - measured trends of primary pressure, secondary pressure and rod surface temperature.....	20
Fig. 4 : BL-34 test - measured trends of primary mass and of ECC delivered mass.....	20
Fig. 5: Relap5/Mod3 nodalization of LOBI/MOD2 facility.....	24
Fig. 6: Comparison between measured and calculated volume vs. height curve.....	32
Fig. 7: Comparison between measured and calculated DP vs. length curve.....	32
Fig. 8: LOBI post test BL-34 (reference calc.) - primary and secondary pressure .....	38
Fig. 9: LOBI post test BL-34 (reference calc.) - integral break flow rate.....	38
Fig. 10: LOBI post test BL-34 (reference calc.) - ECCS integral flow rate.....	39
Fig. 11: LOBI post test BL-34 (reference calc.) - pressurizer level.....	39
Fig. 12: LOBI post test BL-34 (reference calc.) - core level.....	40
Fig. 13: LOBI post test BL-34 (reference calc.) - rod surface temperature (high level).....	40
Fig. 14: LOBI post test BL-34 (run B341) - PRZ pressure.....	51
Fig. 15: LOBI post test BL-34 (run B341) - break integral flow rate.....	51
Fig. 16: LOBI post test BL-34 (run B342) - PRZ pressure.....	52
Fig. 17: LOBI post test BL-34 (run B342) - break integral flow rate.....	52
Fig. 18: LOBI post test BL-34 (run B343) - PRZ pressure.....	53
Fig. 19: LOBI post test BL-34 (run B343) - heater rod temperature (high level) .....	53
Fig. 20: LOBI post test BL-34 (run B344) - PRZ pressure.....	54
Fig. 21: LOBI post test BL-34 (run B344) - heater rod temperature (high level) .....	54
Fig. 22: LOBI post test BL-34 (run B345) - PRZ pressure.....	55
Fig. 23: LOBI post test BL-34 (run B345) - heater rod temperature (high level) .....	55
Fig. 24: LOBI post test BL-34 (run B346) - PRZ pressure.....	56
Fig. 25: LOBI post test BL-34 (run B346) - heater rod temperature (high level) .....	56



## LIST OF TABLES

Tab. 1: Relevant initial and boundary conditions for Lobi test BL-34 in comparison with the other counterpart tests. ....	18
Tab. 2: Imposed sequence of trips for LOBI test BL-34.....	19
Tab. 3: LOBI BL-34 experiment: resulting sequence of main events. ....	19
Tab. 4: Relap5/Mod3.2 nodalization - correspondence between code nodes and hydraulic zones....	25
Tab. 5: Relap5/Mod3.2 LOBI nodalization - overview of code resources.....	28
Tab. 6: Criteria for nodalization qualification at the steady-state level. ....	31
Tab. 7: Comparison between measured and calculated (Relap5/Mod2 and Relap5/Mod3.2) relevant initial and boundary conditions .....	37
Tab. 8: Resulting sequence of events, comparison among experimental test and calculated results..	41
Tab. 9: Judgment of code calculation performance on the basis of phenomena included in the CSNI matrix .....	43
Tab. 10: Judgment of code calculation on the basis of relevant thermalhydraulic aspects .....	44
Tab. 11: Summary of results obtained by application of FFT method to the selected parameters for the reference calculation.....	46
Tab. 12: Sensitivity calculation matrix: varied input parameters and FFT results.....	48
Tab. 13: Summary of results obtained by application of FFT method to the selected parameters for the sensitivity calculations (AA values).....	49
Tab. 14: Summary of results obtained by application of FFT method to the selected parameters for the sensitivity calculations (WF values) .....	50



# 1. INTRODUCTION

The performance assessment and validation of large thermalhydraulic codes and the accuracy evaluation when calculating the safety margins of Light Water Reactors are among the objectives of international research programs, such those organized by the committee on the Safety of Nuclear Installations (CSNI) and the Code Application and Maintenance Program (CAMP).

Solution of these problems would ensure the effectiveness of engineered safety features and, eventually, lead to cost reductions through better design. This activities could also contribute to the determination of a uniform basis on which to assess the consequences of reactor system failures in Nuclear Power Plants, refs. [1] and [2].

The execution of the experiments in Integral Test Facilities simulating the behavior of a nuclear plant, plays an important role in this connection, both considering the system code assessment and the possibilities to identify and characterize the relevant phenomena during off-normal conditions.

A special kind of experiments are the so called counterpart tests. These are similar experiments performed in differently scaled facilities. It is well clear that transient scenarios measured in the experimental rigs can not be directly extrapolated to the plant conditions. Nevertheless one of the objectives of a counterpart test is to evaluate the influence of the geometric dimension of the loop upon the evolution of a given accident.

Counterpart tests have been performed in four PWR simulators: LOBI, SPES, BETHSY and LSTF, ref. [3], respectively available at the European Community Joint Research Center of Ispra (I), at SIET in Piacenza (I), at CENG in Grenoble (F) and at JAERI in Tokai-Mura (J). The selected experiment is a small break LOCA originated by a rupture in the cold leg, without actuation of high pressure injection system and with accumulators availability, in particular, starting from low power conditions (about 10% of the nominal period). Both tests have been performed in the smallest facilities, SPES and LOBI, starting from full power conditions, all other conditions being the same.

The activity documented in this report is a part of a multipurpose research aiming at the overall evaluation and exploitation of the counterpart test database. On one hand the Relap5 system code (Mod2 and, presently, Mod3.2) has been applied to the post test analysis of the four experiments and to the evaluation of plant scenario during the same transient; on the other hand the experimental data base have been evaluated to demonstrate the similarity in the behavior of the facilities, ref. [3]. The two parts of the research have been merged and conclusions have been drawn in relation to the scaling of phenomena and of the accuracy of thermalhydraulic code calculations.

Previous reports dealt with the evaluation of the experimental data base constituted by the four counterpart experiments (ref. [4]) and with the qualification of Relap5/Mod2 nodalization used for the post test analyses, ref. [5], as well as with a complete evaluation of the data base leading to the evaluation of uncertainties (e.g. ref. [6]).

The present document deals with the post test analysis performed by Relap5/Mod3.2 of the small break LOCA counterpart test carried out in LOBI/MOD2 facility (BL-34), ref. [7].

The purpose of this report is to evaluate the performance of the Relap5/Mod3.2 in comparison with the previous application with the version Mod2. In order to achieve this, a systematic qualitative and quantitative accuracy evaluation has been performed. The quantitative analysis has been performed adopting a method (ref. [8],) developed at DCMN, which has capabilities in quantifying the errors in code predictions related to the measured experimental signal; the Fast Fourier Transform (FFT) is used aiming to have an integral representation of the code calculation discrepancies (i.e. error between measured and calculated time trends) in the frequency domain.





## 2. DESCRIPTION OF THE EXPERIMENT

### 2.1 LOBI facility

The LOBI-MOD2 facility is a high pressure integral system test facility simulating the geometrical and operating configuration of a four-loops 1300 MWe PWR. More in particular, it reproduces the KWU PWR plant installed at Biblis (Germany).

This facility was designed, released and operated at the Joint Research Centre (JRC) of Ispra Establishment, and it was one of the largest high pressure integral systems of this kind operating in Europe.

A sketch of the primary circuit of the facility is reported in Fig. 1. It essentially consists of the following parts (refs. [9] and [10]):

- a pressure vessel containing the heated bundle consisting of 64 directly heated rods arranged in 8x8 square matrix. A cosine shaped axial power profile is obtained through seven different thickness of the hollow cylinder simulating the rods. Nominal heating power is 5.3 MW. Four bypass flow paths are realized in the vessel region: three between upper plenum and downcomer and one between lower plenum and upper plenum. The ones between upper plenum and downcomer are obtained via gap in the connection hot leg-vessel, via "ad hoc" holes in the barrel and via the upper head, respectively;
- a small vessel simulating the upper head of the PWR vessel;
- two loops, respectively called "INTACT" loop and "BROKEN" loop, the former representing the three unbroken loops of the four-loops reference PWR plant, the latter simulating "broken" loop in which pipe ruptures of various sizes can be mounted at different locations. The two loops are equipped with equal recirculation pumps which, during steady-state, run at different velocities to achieve rightly scaled flow rates. In each loop a steam generator is containing components such as inverted U-tubes, an annular downcomer and coarse and fine steam separators modeling the geometry of the reference plant. The exchanged power in the two steam generators, at the nominal operating conditions, is of 1.32 MW (8 U-tubes) and of 3.96 MW (24 U-tubes) for the BROKEN and the INTACT loop, respectively;
- an active secondary loop system, shown in Fig. 2, containing two condensers simulating the reactor turbines, the feed water pump and the auxiliary feedwater system;
- a pressurizer and surge line connectable to either the intact or broken loop;
- emergency core cooling system equipped with active High Pressure Injection System with up to 4 HPIS injection pumps, Low Pressure Injection System and a Passive Accumulator System, with two accumulators, one in each loop.

The scaling criteria utilized in the LOBI-MOD2 facility led to the following characteristics:

- volume, primary circuit coolant mass flow and power input are scaled down from the referred reactor values, by a factor of 712;
- in order to preserve the gravitational head the absolute heights and relative elevations of the individual system components have been kept at reactor values with the exception of the pressurizer, which is shorter in order to preserve the scaling ratio and maintain, at the same time, an acceptable flow area.

The LOBI test facility was initially designed to simulate the thermalhydraulic scenario in a Pressurized Water Reactor during Large Break Loss-of-Coolant Accident (LBLOCA). Subsequent modifications to the original LOBI/MOD1 facility, like a more accurate design of the secondary side of steam generators, a new reactor pressure vessel and a greater number of thermocouples installed,

made LOBI/MOD2 well faced for simulation of a wide variety of Small Break LOCA (SBLOCA) and special transients experiments.

The instrumentation system of the facility allowed the measurements of the main thermalhydraulic parameters performed at the boundaries of the principal loop components and at the principal sections of the pressure vessel and the steam generators.

The main measurement locations in the facility can be classified as follows:

- Loop pipes: performed within “measurement inserts” which contain the complete instrumentation for each location. The “insert” can be “simple” or “complete”. In the simple insert the measurement of fluid and wall temperatures and absolute and differential pressure are performed. The complete inserts also contain flow and density measurement devices. A distinction, in the instrumentation available in the inserts, is made between vertical and horizontal pipes: the inserts for horizontal flow are supplied with double instrumentation for temperature and flow measurement in order to show eventual stratification phenomena in the pipe section.
- Reactor pressure vessel simulator: with absolute pressure taken in the upper plenum. Differential pressure measurements are provided over all the main sections along the flow path of the pressure vessel. Mass flow information is provided by flow and density measurements in the core inlet box. A second density measurement indicates voiding of the lower plenum. Fluid and wall temperatures are measured in the more representative locations in the vessel.
- Heater rod bundle: each heater rod is supplied with three thermocouples in the tube wall.
- Steam generators: measurements are provided of fluid temperatures, U-tubes wall temperatures and differential pressure on the primary and secondary side.
- Pressurizer: fluid temperatures and pressure are measured and the surge line flow is obtained by a full flow turbine. Differential pressure is measured over the surge line and over the height of the pressurizer to monitor the filling level.





Fig. 1: LOBI/MOD2 facility - primary circuit



**Fig. 2: LOBI/MOD2 facility - secondary circuit**

## 2.2 Test BL-34

The experiment BL-34 is a Small Break LOCA originated by a rupture in the cold leg, without high pressure injection system but with accumulators active and low pressure injection system intervention. It is a low power test, about 12 % of the nominal power.

Few relevant initial conditions, in comparison with the high power test BL-44 and with the other counterpart tests, are reported in Tab. 1. The transient setpoints imposed and the resulting sequence of events for LOBI BL-34 test are reported in Tabs. 2 and 3. The transient scenario can be derived from Figs. 3 and 4.

The accident can be subdivided into four main periods from a phenomenological point of view:

- a) subcooled blowdown and first core dryout rewet (time from 0 to 180 s);
- b) saturated blowdown and primary to secondary side pressure decoupling (from 180 s up to accumulators emptying);
- c) mass depletion in the primary loop (from accumulators emptying to the final core dryout);
- d) intervention of low pressure injection system that quenches the core.

Phase a). Following the break the primary system pressure is subject to an initial fast decrease (0.1 MPa/s) up to the achievement of saturation conditions upstream the break; this occurs at about 80 s into the transient. The sharp initial pressure decrease lead to scram, main coolant pump trip and isolation of steam generators in the first 10 s of the transient. Pressurizer emptying occurs in about 20 seconds. During the phase a), U-tubes draining occurs in primary side (at about 90 s) for the loss of natural circulation between core and downcomer through the steam generators: at this time the saturation temperature in the primary loop is still few degrees higher than saturation temperature in the secondary side.

The stop in natural circulation, essentially due to voiding and mass depletion in the upper zones of the loop, causes manometer type situation in the primary loop piping: the steam produced in the core partly flows directly in the break through the bypass and partly pushes down the level in the core, to balance the liquid level present in loop seals. In this situation core dryout occurs at about 135 s. The rod temperature excursion ends when loop seals clearing starts (at about 160 s in the broken loop). Quench does not occur simultaneously to the broken loop seal clearing at level 10 in the axial position of the bundle, while at level 11 and 12 occurs simultaneously to the intact loop seal clearing.

It could be underlined that, when the loop seals occur, the following situation is present:

- a) being some tubes still in two phase circulation or slowly emptying, they can still have water in both sides;
- b) some tubes must have just steam because, if all of them had been in two phase flow, there would not have been level decrease in the descending side and thus loop seal clearing;
- c) the outlet plenum is empty;
- d) the loop seal (SG side) is voided at least up to the upper part of the horizontal loop seal pipe, to allow steam passing through the pump side loop seal.

After the loop seal clearing of both loops occurs, sufficient liquid mass is present in the core to cool the rods. Following the above events (especially broken loop seal clearing) a large amount of steam is present upstream the break and an important break flow rate decrease takes place.

Phase b). Continuous core boil off and primary-to-secondary side pressure decoupling characterize the first part of phase b). The core boil off (produced steam flows almost entirely to the break) causes a second dryout at about 360 s at a pressure higher than the accumulators pressure (4 MPa); liquid level hold up in the broken loop seal occurs, starting from about 200 s, somewhat limiting steam flow to the break. Probably the reverse speed of the pump (at -28 rpm during the whole transient) contributes to the formation of liquid hold up in the broken loop seal, pump side. In this period the heat transfer from secondary side to primary side is quite small compared with core

power, because the high void fraction in the U-tubes. The accumulators intervention at 420 s causes the recovery of liquid level in the core and a second rewet that is completed at about 550 s. The isolation of accumulators occurs at about 950 s: in the period from 420 to 950 s the primary system mass increases, because the liquid flow rate delivered by accumulators is larger than the break flow rate.

Phase c). The stop of accumulators injection ( $t = 953$  s) causes another mass depletion period, leading to the third dryout at about 1700 s into the transient, when the primary pressure was around 1 MPa. No other significant event occurs in this period, excluding the core level depression. When the rods surface temperature reaches 773 K, the low pressure injection system is actuated (2100 s) in the intact loop cold leg.

Phase d). The LPIS flow rate (0.4 kg/s) is quite effective in causing the third core quench and in recovering the facility. The quench front velocity is larger than 0.02 m/s and, at about 2200 s, the core is completely recovered. Core refill occurs in this period. The test was terminated at 2400 s, with pressure around 0.4 MPa.

	unit	Lobi BL-34	Lobi BL-44	Spes SP-SB-03	Spes SP-SB-04	Bethsy 6.2TC	Lstf SB-CL-21
core power	kW	630	5280	768	5600	2863	7930
pressurizer pressure	MPa	15.47	15.46	15.06	15.16	15.38	15.4
hot leg temperature	K	589	589	586	589	587	590
average core $\Delta T$	K	27.5	35	28.6	31	31	31
core inlet mass flow rate	kg/s	3.6	28	4.21	31.8	19.5	48.4
bypass DC-UH mass flowrate / core mass flowrate	%	0.83	0.11	0.81	0.97	0.72	0.52
steam generator secondary side pressure	MPa	il 6.94 bl 6.91	il 5.12 bl 5.11	6.94 6.87 6.88	6.7	6.86 6.84 6.84	7
steam generator downcomer level	m	il 8.14 bl 4.48	il 8.14 bl 4.48	11.5	11.5	11.2 11.1 11.1	11.24 11.23
pressurizer level	m	5	5.1	3.23	3.77	7.45	1.7
feedwater mass flow rate	kg/s	il 0.19 bl 0.06	il 1.95 bl 0.75	0.095 0.093 0.0965	3.4	0.561	2.2 2.3
feed water temperature	K	il 415 bl 409	-	473.6 437.8 440.1	523	523	523

**Tab. 1: Relevant initial and boundary conditions for Lobi test BL-34 in comparison with the other counterpart tests.**

EVENT	TIME AND/OR SET POINT VALUES
Break opening	0. s
SCRAM signal	PRZ pressure < 13 MPa
Pumps coastdown initiation	PRZ pressure < 13 MPa
Feed water closure	PRZ pressure < 13 MPa
Accumulators start	PRZ pressure < 4.0 MPa
Accumulators stop	0.09 m <sup>3</sup> (low water volume signal)
LPIS intervention	max. rod temperature > 773 K
End of transient	PRZ pressure < 0.7 MPa or ad hoc signal

**Tab. 2: Imposed sequence of trips for LOBI test BL-34 (specified).**

	LOBI BL-34
Break opening	0
Scram power curve enabled	0.5
Start of main coolant pumps coast down	IL 1.1 BL 1.1
Main steam line valve closure	-
Feedwater valve closure	IL 2.7 BL 2.4
Upper plenum in saturation condition	7
Pressurizer emptied	23
Break two phase flow	120
First dryout	135
Loop seal clearing	IL 180 BL 160
Occurrence of minimum primary side mass	420 2100
Primary-secondary pressure reversal	164
Second dryout	362
Rewetting due to accumulators	550
Accumulators injection start	420
Accumulators injection stop	953
Final dryout	1705
LPIS start	2100
Final rewetting	2150
End of test	2400

**Tab. 3 - LOBI BL-34 experiment: resulting sequence of main events.**




Fig. 3: BL-34 test - measured trends of primary pressure, secondary pressure and rod surface temperature




Fig. 4 : BL-34 test - measured trends of primary mass and of ECC delivered mass



### 3. ADOPTED CODE AND NODALIZATION

#### 3.1 Relap5/Mod3.2 code

The light water reactor transient analysis code, RELAP5, was developed at the Idaho National Engineering Laboratory (INEL) for the U.S. Nuclear Regulatory Commission (NRC). Specific applications of the code have included simulations of transients in LWR system such as loss of coolant, anticipated transients without Scram (ATWS) and operational transients, such as loss of feed water, loss of offsite power, station blackout and turbine trip.

The Mod3 version of RELAP5 has been still developed by the INEL, but a consortium consisted of several countries and domestic Organizations that were members of the International Code Assessment and Application Program (ICAP) and its successor organization, Code Application and Maintenance Program (CAMP), contributed to the development and the validation process.

RELAP5/Mod3.2 code, refs. [11] and [12], is based on a non-homogeneous, non-equilibrium set of six partial derivative balance equations for the steam and the liquid phase. A non-condensable component in the steam phase and a non-volatile component (boron) in the liquid phase can be treated by the code. A fast, partially implicit numeric scheme is used to solve the equations inside control volumes connected by junctions.

In particular, the control volume has a direction associated with it that is positive from the inlet to the outlet. The fluid scalar properties, such as pressure, energy, density and void fraction, are represented by the average fluid condition and are viewed as being located at the control volume center. The fluid vector properties, i.e. velocities, are located at the junctions and are associated with mass and energy flow between control volumes. Control volumes are connected in series using junctions to represents flow paths.

Heat flow paths are also modeled in a one-dimensional sense, using a staggered mesh to calculate temperatures and heat flux vectors. The heat structure is thermally connected to the hydrodynamic control volumes through heat flux that is calculated using a boiling heat transfer formulation. The heat structures are used to simulate pipe walls, heater elements, nuclear fuel pills and heat exchanger surfaces.

Several new models, improvements to existing models and user conveniences have been added. The new models include:

- the Bankoff counter-current flow limiting correlation;
- the ECCMIX component for modeling of the mixing of the subcooled emergency core cooling system liquid and resulting interfacial condensation;
- a zirconium-water reaction model to model the exothermic energy production on the surface of zirconium cladding material at high temperature;
- a surface to surface radiation heat transfer model with multiple radiation enclosures defined through user input;
- a thermal stratification model.

#### 3.2 General criteria adopted for the code models

A detailed nodalization reproducing each geometrical zone of the loop has been developed: in principle it is suitable for different types of transients.

The general methodology followed is described in refs. [12] and [13]. Being used, in this case, the Relap5/Mod3 code, great care is given to the information contained in the specific user manual.

Nevertheless, it should be noted that this information alone is generally not exhaustive for the development of an adequate set of input data. So, few supplementary criteria, to those reported in the manual, have been fixed, as result of experience, in the attempt to set up a "homogeneous" nodalization, that is to avoid imbalance in the distribution of hydraulic and thermal meshes. Of course, the achievement of this objective, requires a good user knowledge of the reference facility characteristics. Moreover, the prevision of the phenomena to be simulated in the calculation can also have a role in this context. Compromises apply in the choice of number of nodes: on the one hand there is the need to develop a model adherent to the geometric and material particularities of the physical system, on the other hand computer capabilities (essentially CPU time) limit the maximum number of nodes.

Two limits have been fixed for the linear dimension of nodes: all the volumes should have their flow lengths comprised between 0.5 and 1.0 m (with the exception of core stack, much more detailed, of the descending zone of the SG U-tubes and of the pressurizer and accumulator surge lines, nodalized by 2.0 m length nodes). With regard to conduction heat transfer, the distance between neighboring mesh points inside structures must be less than 5 mm in each case, up to the lower limit of few tenths of mm used for heated rods and steam generator U-tubes. In the subdivision of volumes and slabs the position of instrumentation has been considered.

The following choices have been made with regard to code options:

- thermodynamic non-equilibrium is allowed in all control volumes;
- the smooth area change for all the junctions where it is allowed (i.e. excluding the motor valves);
- the stratification option is used in the junctions of the hot legs and cold legs horizontal parts.

### 3.3 LOBI/MOD2 nodalization description

The LOBI/MOD2 nodalization is shown in Fig. 5. The correspondence between the zones of the facility and the nodes of the code model are exposed in Tab. 4. In this table the facility is divided in general zones, composed by single components, reported in the table according to flow paths in nominal conditions. The number and the type of the hydraulic nodes, corresponding at each single component of the facility, are indicated in the table itself.

Hereafter some significant aspects of the nodalization development are summarized.

#### **Primary system model**

The vessel model consists of 29 hydraulic components which are connected through 48 junctions.

The heat structures utilized in the RPV model are made up of 47 heat slabs, distinguished in:

- 13 active structures for the heaters;
- 30 heat slabs for the vessel wall;
- 4 internal non-active structures.

In the vessel model all the bypass flow paths, reported in the facility description, have been modeled:

- bypass from downcomer top to upper plenum via holes simulated by junctions 430-02 (bypass flow rate equal to 0.35 kg/s);
- bypass from downcomer top to upper plenum via gap in the connections with the hot legs simulated by junctions 500-03 and 700-03 (bypass area strictly dependent by thermal expansion of the structures, thus the bypass flow rate valuable, with a large uncertainty band, roughly equal to 1 kg/s);
- bypass from downcomer top to upper head simulated by node 440-01 with bypass flow rate roughly equating to 0.3 kg/s.

Both the broken and the intact loop represent with geometrical fidelity the real hydraulic configuration of the experimental facility. Notwithstanding this, the degree of detail is properly increased in the BL, where are localized, in transient conditions, the most important thermalhydraulic phenomena.

Intact and broken loop are so simulated:

- 53 nodes and 54 junctions for the IL;
- 55 nodes and 57 junctions for the BL.

The accumulators are schematized in both loops and are connected to the respective cold legs.

The localized pressure drops, due to the "locked rotor resistance simulator" is introduced in the loop by the *motor valve 747* component.

The *time dependent volumes 742, 603 and 602*, connected with the primary system through the *time dependent junctions 744, 601 and 604* respectively, simulate the pump cooling system. Each system is realized with cold water injection in the pump and consequent water draining from the lower plenum.

Two additional systems can be noted in the pressurizer nodalization:

- a *time dependent volume* and related valve (components 541 and 542);
- a *time dependent junction* and related *time dependent volume* (components 531 and 534).

Both are control systems. The former system allows the primary side pressure to remain constant in a steady-state period. The latter system maintains at an assigned value the liquid level inside the pressurizer. The temperature of the fluid possibly injected by this system corresponds to the saturation conditions inside the pressurizer. A check has been made to verify that the flow rates and the energy exchanged between this system and the primary circuit are well below the reference flow rate and energy values of the primary side. Finally the black structures inside the pressurizer model represents the internal heaters.

### Secondary system

The secondary side nodalizations of the two steam generators are very similar, both concerning the hardware of the facility and the control systems (23 nodes, 23 junctions and 45 heat slabs).

Four zones can be recognized in each steam generator:

- 1) the downcomer, consisting of a single stack of nodes that simulates a multitubular geometry;
- 2) the riser zone, essentially including the U-tubes;
- 3) the top of the vessel, including the separator, the dryer and the steam dome regions;
- 4) the steam line downstream the dome of each SG is simulated with a *time dependent volume* (829 for IL and 929 for BL) connected to the dome by a *time dependent junction* (828 for IL and 928 for BL).

The degree of detail of the nodalization is commensurate to what considered in the primary loop. In particular, the heights of the riser volumes are the same as the minimum between the heights of the rising and the descending corresponding nodes of the primary side U-tubes.

The components 815-01 for IL and 915 for BL simulates the separators in the secondary sides that are necessary in the code model in order to achieve quality equal to 1 in the steam domes.

A relatively large number of control volumes are connected with the steam generators; the following functions are accomplished:

- feed water injection: *time dependent volumes 832 (IL) and 932 (BL)*; *time dependent junctions 833 (IL) and 933 (BL)*;
- AFW injection: *time dependent volumes 836 (IL) and 936 (BL)*; *time dependent junctions 837 (IL) and 937 (BL)*;
- safety system: *time dependent volumes 826 (IL) and 926 (BL)*, simulating the safety tanks; *trip valves 825 (IL) and 925 (BL)*, simulating the safety valves;
- components 824-01 and 823, for IL, and 924-01 and 923, for BL, simulate the control system that assures constant pressure during a steady state period.

The geometrical features of the piping and system connected with SGs are not simulated (e.g. feed water lines, pre-heaters, steam lines - including condenser - etc.), because this is not relevant for the prediction of the transients of interest.

The utilized code resources for the LOBI/MOD2 nodalization are summarized in Tab. 5. In particular, the number of hydraulic components and of the heat structures are here reported.




Fig. 5: Relap5/Mod3 nodalization of LOBI/MOD2 facility

GENERAL ZONE	NAME	NUMBER	TYPE	
PRESSURE VESSEL	DOWNCOMER REGION	200	PIPE	
		202	BRANCH	
		210	BRANCH	
	LOWER PLENUM	102	BRANCH	
	CORE REGION	CORE REGION	106	PIPE
			400	BRANCH
			410	BRANCH
			420	BRANCH
			430	BRANCH
			440	BRANCH
	UPPER HEAD	UPPER HEAD	450	BRANCH
			455	BRANCH
			460	PIPE
			465	SNGLJUN
			466	BRANCH
			470	SNGLVOL
INTACT LOOP	VESSEL NOZZLE	500	BRANCH	
	HOT LEG	507	BRANCH	
		510	BRANCH	
		511	BRANCH	
		512	BRANCH	
		550	SNGLVOL	
		555	SNGLJUN	
		560	PIPE	
	SG INLET PLENUM	565	BRANCH	
	U-TUBES	570	PIPE	
	SG OUTLET PLENUM	575	BRANCH	
	LOOP SEAL	LOOP SEAL	580	PIPE
			582	SNGLJUN
			585	SNGLVOL
			587	SNGLJUN
			590	PIPE
			595	BRANCH
	PUMP	600	PUMP	
COLD LEG	COLD LEG	605	BRANCH	
		610	PIPE	
		612	BRANCH	
VESSEL NOZZLE	612	BRANCH		
BROKEN LOOP	VESSEL NOZZLE	700	BRANCH	
	HOT LEG	702	BRANCH	
		705	PIPE	
		710	BRANCH	
		712	PIPE	
	SG INLET PLENUM	718	BRANCH	
	U-TUBES	720	PIPE	
	SG OUTLET PLENUM	722	BRANCH	

Tab. 4 (part 1): Relap5/Mod3.2 nodalization - correspondence between code nodes and hydraulic zones

GENERAL ZONE	NAME	NUMBER	TYPE
GENERAL ZONE	LOOP SEAL	725	PIPE
		727	SNGLJUN
		730	PIPE
	PUMP	740	PUMP
	COLD LEG	745	BRANCH
		747	MTRVLV
		750	PIPE
		770	BRANCH
		772	BRANCH
		774	BRANCH
	PRESSURIZER	SURGE LINE	520
532			SNGLJUN
PRESSURIZER VESSEL		530	BRANCH
		535	PIPE
		537	SNGLJUN
		539	BRANCH
		540	BRANCH
PORV VALVE		543	TRPVLV
PORV TANK		544	TMDPVOL
PORV AD VALVE		545	TRPVLV
PORV TANK	546	TMDPVOL	
SECONDARY SIDE INTACT LOOP	FEEDWATER TANK	832	TMDPVOL
	FEEDWATER JUNCTION	833	TMDPJUN
	AUX. FW. TANK	836	TMDPVOL
	AUX. FW. JUNCTION	837	TMDPJUN
	DOWNCOMER	830	BRANCH
		840	BRANCH
		850	PIPE
		845	SNGLJUN
	RISER	800	ANNULUS
		805	SNGLJUN
		810	PIPE
	SEPARATORS	815	SEPARATOR
	STEAM DOME	820	BRANCH
	STEAM LINE JUN.	828	TMDPJUN
	STEAM LINE TANK	829	TMDPVOL
	SG DIS TANK	826	TMDPVOL
SG DIS JUNCTION	825	TMDPJUN	
SECONDARY SIDE BROKEN LOOP	FEEDWATER TANK	932	TMDPVOL
	FEEDWATER JUNCTION	933	TMDPJUN
	AUX. FW. TANK	936	TMDPVOL
	AUX. FW. JUNCTION	937	TMDPJUN
	DOWNCOMER	930	BRANCH
		940	BRANCH

Tab. 4 (part 2): Relap5/Mod3.2 nodalization - correspondence between code nodes and hydraulic zones

GENERAL ZONE	NAME	NUMBER	TYPE	
SECONDARY SIDE BROKEN LOOP		950	PIPE	
		945	SNGLJUN	
	RISER		900	ANNULUS
			905	SNGLJUN
		910	PIPE	
	SEPARATORS	915	SEPARATOR	
	STEAM DOME	920	BRANCH	
	STEAM LINE JUN.	928	TMDPJUN	
	STEAM LINE TANK	929	TMDPVOL	
	SG DIS TANK	926	TMDPVOL	
	SG DIS JUNCTION	925	TMDPJUN	
	ACCUMULATOR	INTACT LOOP ACC.	615	ACCUM
ACC. SURGE LINE		670	PIPE	
CONNECTION VALVE		675	MTRVLV	
CONTROL COMPONENTS	PRZ CONTROL PRESSURE	541	TMDPVOL	
		542	TRPVLV	
	PRZ CONTROL LEVEL	534	TMDPVOL	
		531	TMDPJUN	
	SG BL CONTROL PRESSURE	924	TMDPVOL	
		923	MTRVLV	
	SG IL CONTROL PRESSURE	824	TMDPVOL	
		823	MTRVLV	
	SG BL CONTROL LEVEL	934	TMDPVOL	
		935	TMDPJUN	
BREAK	SG IL CONTROL LEVEL	834	TMDPVOL	
		835	TMDPJUN	
BREAK	BREAK VOLUME	761	TMDPVOL	
	BREAK VALVE	760	MTRVLV	
LPIS	LPIS TANK	630	TMDPVOL	
	LPIS JUNCTION	625	TMDPJUN	
PUMP SEAL WATER	EXIT SEAL WATER	602	TMDPVOL	
		604	TMDPJUN	
	IL PUMP SEAL WATER	603	TMDPVOL	
		601	TMDPJUN	
	BL PUMP SEAL WATER	742	TMDPVOL	
	744	TMDPJUN		
IL-BL SF CONNECTION		870	TRPVLV	

Tab. 4 (part 3): Relap5/Mod3.2 nodalization - correspondence between code nodes and hydraulic zones

PARAMETER	VALUE
<b>1. NUMBER OF NODES</b>	
– primary side	158
– secondary side	58
– total	216
<b>2. NUMBER OF JUNCTIONS</b>	
– primary side	162
– secondary side	59
– total	221
<b>3. NUMBER OF SLABS</b>	
– primary side	171
– secondary side	76
– total	247
<b>4. OVERALL NUMBER OF MESH POINTS</b>	1841
<b>5. NUMBER OF CORE ACTIVE STRUCTURES</b>	13
<b>6. HEAT TRANSFER AREA (m<sup>2</sup>)</b>	
– core region	14.495
– steam generator U-tubes	32.344
<b>7. NUMBER OF MESH POINTS</b>	
– core slabs	205
– stem generator slabs	336
<b>8. BYPASS FLOW PATHS</b>	
LOWER PLENUM - UPPER PLENUM	
– area (m <sup>2</sup> )	$4.266 \cdot 10^{-3}$
– total energy loss coefficient [ $\sum K_i$ (forward)/ $\sum K_i$ (reverse)]	$6.19 \cdot 10^3 / 6.19 \cdot 10^3$
DOWNCOMER - UPPER HEAD	
– area (m <sup>2</sup> )	$3.14 \cdot 10^{-4}$
– total energy loss coefficient [ $\sum K_i$ (forward)/ $\sum K_i$ (reverse)]	100/100
<b>9. OVERALL VOLUME (m<sup>3</sup>)</b>	$6.445 \cdot 10^{-2}$

**Tab. 5: Relap5/Mod3.2 LOBI nodalization - overview of code resources**



### 3.4 Nodalization qualification

A nodalization representing an actual system (Integral Test Facility or plant) can be considered qualified when:

- it has a geometrical fidelity with the involved system;
- it reproduces the measured nominal steady state condition of the system;
- it shows a satisfactory behavior in time dependent conditions.

Taking into account these statements, a standard procedure to obtain a "qualified nodalization" has been defined, ref. [14].

The qualification process consists of two main phases:

- 1) **steady state level:** the nodalization is qualified against data available from nominal stationary conditions measured in the simulated system. To this aim:
  - a) relevant geometrical parameters of the facility (e.g. volume, heat transfer area, elevations, pressure drops distribution etc.) are compared with the input data and the differences among them must be acceptably small. The adopted acceptability criteria are reported in the first part of Tab. 6 (see also Fig. 6);
  - b) the nominal steady state conditions are simulated with a code running (a hundred seconds time interval is considered acceptable to reach correct steady state values); significant parameters are selected and compared with the measured results. A parameter is considered as significant when it is of major relevance in determining the plant behavior and can be reliably measured. The adopted acceptability criteria for this step are reported in the second part of Tab. 6 (see also Fig. 7).
- 2) **transient level:** the nodalization is tested in time-dependent conditions reproducing the available experimental transients. This phase also includes the procedure for the qualitative and the quantitative (through the application of the FFT based method) evaluation of the code accuracy, necessary to demonstrate the acceptability of the code transient performance. The demonstration of the quality of the nodalization at the transient level, before application to the reference calculation (BL-34 in this case), involves at least one among the following steps:
  - a) perform a "K<sub>v</sub> scaled" calculation aiming at the comparison between the nodalization performance and experimental data in another facility (proper scaling factors must be adopted to fix initial and boundary conditions);
  - b) compare results of the nodalization with experimental data different than those object of the reference calculations (these can be operational transient data in the case of a Nuclear Power Plant);
  - c) compare the results of the nodalization with calculations data coming from a previously qualified nodalization.

The idea of the "K<sub>v</sub>-scaled calculation" (item a) comes from the objective to comparing calculated data with experimental data before adopting any nodalizations (i.e. including NPP nodalization) for any kind of calculation (code assessment, licensing, etc.). In this frame, adopting proper scaling criteria (time preventing, volume/power scaling) a comparison can be made between predicted and experimental data in the area of PWR and BWR. This must be used to detect nodalizations and user choice inadequacies. Correction of errors or deficiencies leads to a "on transient" qualified nodalization ready to be used for other purposes.

The acceptability constraints for the FFT (i. e. 0.4 for Average Accuracy and 0.1 for the primary pressure) must be fulfilled in any case.

The qualification process, summarized above, has been applied to the nodalization of Lobi facility.

As concerns the first phase (steady state level), the steady state acceptability criteria previously defined (reported in Tab. 6) have been verified; in particular, the comparison between the calculated

and the measured volume vs. height curve and the distribution of pressure drops along the length are reported in Figs. 6 and 7, respectively.

The second part of the qualification process (transient level) has been conducted through the step b) and c) described above: in the first case the International Standard Problem 18, ref. [15], has been considered, while in the second case the previous simulation with the version Relap5/Mod2, ref. [5], has been utilized (see also below).

It is to be mentioned that the application of the FFT based methodology has been exhaustively performed in the Relap5/Mod2 simulation of BL-34 [16] and it was not repeated in a systematic way for the Relap5/Mod3.2 simulation. No important differences related to any of the finding of the Relap5/Mod2 analyses are expected.

	QUANTITY	ACCEPTABLE ERROR (°)
1	Primary circuit volume	1 %
2	Secondary circuit volume	2 %
3	Non-active structures heat transfer area (overall)	10 %
4	Active structures heat transfer area (overall)	0.1 %
5	Non-active structures heat transfer volume (overall)	14 %
6	Active structures heat transfer volume (overall)	0.2 %
7	Volume vs. height curve (i.e. "local" primary and secondary circuit volume)	10 %
8	Component relative elevation	0.01 m
9	Axial and radial power distribution (°)	1 %
10	Flow area of components like valves, pumps orifices	1 %
11	Generic flow area	10 %
(*)		
12	Primary circuit power balance	2 %
13	Secondary circuit power balance	2 %
14	Absolute pressure (PRZ, SG, ACC)	0.1 %
15	Fluid temperature	0.5 % (**)
16	Rod surface temperature	10 K
17	Pump velocity	1 %
18	Heat losses	10 %
19	Local pressure drops	10 % (^)
20	Mass inventory in primary circuit	2 % (^^)
21	Mass inventory in secondary circuit	5 % (^^)
22	Flow rates (primary and secondary circuit)	2 %
23	Bypass mass flow rates	10 %
24	Pressurizer level (collapsed)	0.05 m
25	Secondary side or downcomer level	0.1 m (^^)

(°) The % error is defined as the ratio  $\frac{|\text{reference or measured value} - \text{calculated value}|}{|\text{reference or measured value}|}$

The "dimensional error" is the numerator of the above expression

(°°) Additional consideration needed

(\*) With reference to each of the quantities below, following a one hundred s "transient-steady-state" calculation, the solution must be stable with an inherent drift < 1% / 100 s.

(\*\*) And consistent with power error

(^) Of the difference between maximum and minimum pressure in the loop.

(^^) And consistent with other errors.

**Tab. 6 - Criteria for nodalization qualification at the steady-state level.**




Fig. 6: Comparison between measured and calculated volume vs. height curve




Fig. 7: Comparison between measured and calculated DP vs. length curve

## 4. ANALYSIS OF POST-TEST CALCULATION RESULTS

Three main calculation types can be distinguished in a meaningful code assessment process:

- a) 100 s steady state;
- b) reference calculation results;
- c) results from sensitivity studies.

It may be noted that item a) may constitute a part of the nodalization qualification process, described in the previous chapter; however, the fulfillment of criteria reported in Tab. 6 is necessary each time a new experiment is considered and before starting transient calculations by using the previously qualified nodalization.

The reference calculation results, item b), must outcome from the qualified nodalization and satisfy qualitative and quantitative accuracy related criteria. The reference calculation is not "the best" calculation achievable by the code. In order to get the reference calculation, boundary and initial conditions of the considered experiment (i.e. input data for the reference calculation) may be changed within their uncertainty ranges; if a user choice is introduced (e.g. changes in noding detail), its validity and acceptability must be checked by repeating the nodalization qualification process.

Sensitivity analyses, item c), must be carried out to demonstrate the robustness of the calculation, to characterize the reasons for possible discrepancies between measured and calculated trends that appear in the reference calculation, to optimize code results and user option choices, to improve the knowledge of the code by the user.

The attention is focused hereafter toward the analysis of the reference calculation results, item b), considering that steady state calculation, item a), is part of the nodalization qualification process and sensitivity analyses, item c), can be designed following the analyses at the previous step. Typical results are provided in relation to the three steps.

When calculating the quantitative accuracy, twenty-one time trends have been selected in relation to which experimental data exist: these are assumed to be the minimum number of measured quantities that fully describe the experimental scenario. The related list is given in the first column of Tabs. 11, 13 and 14.

When calculating qualitative accuracy, including the comparison between time trends, reference is made to the same list (e.g. Apps. 1 and 2) of Tab. 13; the following quantities have been added to the comparison: pressure drop across DC-UH bypass, pressure drop in the U-tubes ascending leg (also a measure of liquid hold-up in the U-tubes), core inlet flow rate, pressure drop in cold leg, mass flow rate in SG downcomer, hot leg mass flow rate. Fig. 29 has been added to give an overall view of the system performance (primary and secondary pressure together).

### 4.1 Steady State calculations

A steady state calculation, by running the code with the 'TRANSNT' (transient) option for 100 s has been completed. This constitutes the final step of the nodalization qualification process at steady state level.

The related results are shown in Tab. 7 and in App. 1. In both cases, resulting values are compared with experimental data. In the case of Tab. 7, for completeness, the data calculated by Relap5/mod2 are included as taken from ref. [5].

It may be noted that the data in Tab. 7 deal with most of the parameters imposed for the nodalization qualification process (Tab. 6): the values in the table have been taken from the code output at 100. s. The time trends above identified are part of the App. 1, numbering of figures is different owing to the obvious lack of time trends dealing with ECC and break flow rates.

The analysis of data brings to the following conclusions:

- the criteria for nodalization qualification are fulfilled, though the complete comparison between data in Tab. 7 and in App. 1 with acceptability criteria has not been done owing to the lack of experimental data; in addition, some of the criteria can be matched by considering sums or combinations of values from Tab. 7 (e.g. the primary circuit power balance can be obtained by considering data at items 1, 4, 14, 16 and 17); still, the error on bypass flow rate, can be better seen by considering the errors in fluid temperatures owing to the fact that the direct experimental information about bypass flow rate is uncertain (measurement error not available);
- the calculated values are stable as it results from Figs. 1 to 26;
- differences between Relap5/mod2 and Relap5/mod3.2 codes results are negligible;
- discrepancies between measured and calculated values of heater rod temperatures, come from the position of thermocouples and from generic experimental error (the calculation result refer to the surface, the experimental data are taken slightly inside the surface, the error almost disappears at low linear rod power, during the transient);
- discrepancies in the case of primary side mass and vessel riser level, are within the acceptability criteria, considering the experimental uncertainties (about  $\pm 3$  % for primary mass);
- the discrepancy in the cases of pressure drops is attributed to the experimental error and to the position of the measurement pressure taps not accounted for by the calculated results;
- the discrepancy related to the recirculation mass flow rate in the steam generator, can also be originated by a measurement error; however, in this case tuning or adjustments of steady state code results was considered unnecessary owing to the low influence that this parameter has in the selected transient (early main coolant pump and feedwater trips occur).

#### 4.2 Reference calculation results

The post-test calculation was performed starting from the input deck suitable for Relap5/Mod2. A 'blind' post test was performed by Relap5/Mod3.2 constituting the reference calculation for this study (label B34D); the related time trends and significant single valued parameters are reported, together with experimental data, in App. 2 and in Tab. 8, respectively.

A comprehensive comparison between measured and calculated trends or values was performed, including the following steps:

- a) comparison between experimental and calculated time trends on the basis of the 29 variables introduced above (App. 2);
- b) comparison between values of quantities characterizing the sequence of resulting events, Tab. 8;
- c) qualitative evaluation of calculation accuracy on the basis of the phenomena included in the CSNI matrix, ref. [17], as given in Tab. 9;
- d) qualitative evaluation of calculation accuracy on the basis of the Relevant Thermalhydraulic Aspects (RTA, also used for code uncertainty derivation, e.g. ref. [6]), as given in Tab. 10;
- e) quantitative evaluation of calculation accuracy, utilizing the FFT based method (FFTBM), described in refs. [8] and [16], see also App. 1 in ref.[20], as given in Tab. 11.

Comments related to items a) and b) are given below, distinguishing groups of homogeneous variables, while the discussion about items c), d) and e) is given in sect. 4.2.1.

##### Absolute Pressures

The primary system pressure is quite well predicted by the code and the phenomenological phases (e.g. subcooled blowdown, saturated blowdown and steam flow from the break) can be easily recognized from the calculated time trend (Fig. 8 below and Fig. 1 in App. 2). During the saturated blowdown (from about 50 s up to 500 s) the calculated pressure is higher than the experimental one. This discrepancy is connected with the overestimation of the secondary side pressure (Fig. 2 of App. 2): heat losses to the environment appear to have a substantial role in this case.

The accumulator generally follows the primary pressure; time of accumulator actuation is reasonably well predicted, together with the time accumulator stop.

#### Fluid temperatures

Measured and calculated fluid temperatures are compared in Figs. 4, 5, 6, and 8 of App. 2, the last one related to the steam generator and the other ones related to the primary circuit.

Core inlet and outlet fluid temperatures are qualitatively well predicted (Figs. 4 and 5). The predicted core outlet fluid temperature presents two peaks in correspondence to the two core level depressions. The superheating is larger than in the experiment and the position of the thermocouple strongly affects this time trend. This is specifically true for the upper head fluid temperature where a very high superheating is measured; in this case, it seems evident that the thermocouple gives a measure of the structural mass temperature starting from about 400 s into the transient, i.e. following the emptying of the upper head.

#### Mass flow rates and residual mass

The measured values of break flow rate (Fig. 9 below and Figs. 7 and 9 in App. 2), the ECCS flow rate (Fig. 10 below and Fig. 10 in App. 2), core inlet (Fig. 25 in App. 2), hot leg mass flow rate (Fig. 28 in App. 2) and the steam generator downcomer flow rate (Fig. 27 in App. 2) are compared with the respective calculated trends.

Break flow rate is well predicted; up to 500 s into the transient it is slightly underpredicted, but the related error can be considered within the uncertainty bands.

The calculated ECCS flow rate is in a good agreement with the calculated trend; it can be noted the overprediction of the flow rate delivered by accumulators and the slight delay of the LPIS intervention.

The residual mass in primary side is well predicted (Fig. 14 of App. 2); the calculated value is higher than the experimental one for all the transient, but the difference can be considered within the experimental uncertainty band.

#### Pressure drops

Pressure drops between different points of the primary circuit are considered in the comparison, e.g. Figs. 17, 19, 20, 22, 23, 24 and 26 in App. 2. All of the comparisons, with different extent, suffer of the limitation already explained in sect. 4.1 (pressure taps not coincident with the center of the volumes of the nodalization).

Pressure drops in loop seals are reasonably well predicted by the code; in the case of steam generator inlet plenum to U-tubes top and downcomer to upper head bypass, the calculated pressure drops trends are in a very good agreement with the experimental one.

#### Levels

The pressurizer level (Fig. 11 below and Fig. 21 in App. 2) is well predicted in the calculation, testifying the good prediction of the subcooled blowdown flow rate.

Core collapsed level constitutes a critical quantity during this experiment, as the level variations are directly connected with the occurrence of core dryout. The trend of this variable is strongly affected by the distribution of pressure drops along the loop that also influence the occurrence of threshold phenomena like loop seal clearing.

The calculated core level is in a quite good agreement with the experimental trend (Fig. 12 below and Fig. 15 in App. 2). The first core level depression is not predicted by the code: this discrepancy is connected with the bypass flow paths inside the vessel, that can facilitate the steam discharge from the upper plenum and limit the steam binding effect on the core level. Pumps operation and, in particular, uncertainties in the rotation speed as a function of time and in the head as a function of the rotation speed (homologous curves) can also have a role in this connection.

### Rod Surface Temperatures

When analyzing the rod surface temperature trends, the three-dimensional situation in the core must be considered, as described into detail in ref. [4].

Representative experimental data at three core levels have been selected for the present comparison, distinguishing in the axial sense, the core bottom, the core middle and the core top regions (Figs. 11 to 13, respectively in App. 2, and Fig. 13 below related to the top region).

Calculated rod surface temperatures follow well the measured values. The first dryout is not predicted by the code and the reason is connected with the bypass flow paths into the vessel (see above). The second dryout situation is well predicted by the code: this is evident at the core high level, whereas, in the middle region, the code predicts the dryout occurrence in the nodes near to that one reported on figures, where there is an apparent discrepancy with the measured trend. The occurrence of the final dryout is reasonably well predicted.



QUANTITY	UNIT	EXP	CALC R5/M2	CALC R5/M3.2
1) Core power	kW	650	630	630
2) Pressurizer pressure	MPa	15.4	15.47	15.47
3) Pressurizer level	m	4.7	5.0	4.95
4) Core mass flow rate	kg/s	3.58	3.40	3.51
5) Core bypass mass flow rate	kg/s	0	0.0057	-
6) DC-UH bypass mass flow rate	kg/s	0.03	0.0023	0.015
7) Primary pumps speed	rad/s	il 7.11 bl 4.78	il 42.8 bl 18.1	il 42.7 bl 18.1
8) Core inlet temperature	K	558	561	559
9) Core outlet temperature	K	589	589	588
10) Core $\Delta T$	K	31	27.5	29
11) Upper head temperature	K	565	607	562
12) Primary mass	kg	436	450	452
13) Acc. liquid temperature	K	303	303	300
14) Secondary pressure SG	MPa	il 6.9 bl 6.9	il 6.94 bl 6.91	il 6.94 bl 6.94
15) SG downcomer level	m	il 8.0 bl 8.4	il 8.14 bl 8.48	il 7.2 bl 7.9
16) Feedwater temperature	K	il 415 bl 409	il 415 bl 409	il 489 bl 489
17) Feedwater flow rate	kg/s	il 0.182 bl 0.061	il 0.19 bl 0.06	il 0.28 bl 0.11
18) Total primary side heat losses	kW	85.2	85.2	53.2
19) Secondary side heat losses	kW	15	15	23.5

**Tab. 7: Comparison between measured and calculated (Relap5/Mod2 and Relap5/Mod3.2) relevant initial and boundary conditions**




Fig. 8: LOBI post test BL-34 (reference calc.) - primary and secondary pressure




Fig. 9: LOBI post test BL-34 (reference calc.) - integral break flow rate




Fig. 10: LOBI post test BL-34 (reference calc.) - ECCS integral flow rate




Fig. 11: LOBI post test BL-34 (reference calc.) - pressurizer level




Fig. 12: LOBI post test BL-34 (reference calc.) - core level




Fig. 13: LOBI post test BL-34 (reference calc.) - rod surface temperature (high level)

	EXP	B34D	B341	B342	B343	B334	B335	B336
Break opening	0	0	0	0	0	0	0	0
Scram power curve enabled	0.5	59	59	59	58	58	59	59
Start of main coolant pumps coast down	1.1	16	15	17	16	16	16	16
Main steam line valve closure	-	18	16	20	18	17	17	18
Feedwater valve closure	-	0	0	0	0	0	0	0
Upper plenum in saturation condition	7	12	10	11	11	10	11	12
Pressurizer emptied	23	25	223	26	24	24	24	24
Break two phase flow	120	60	50	75	58	54	57	58
First dryout	135	-	-	-	-	-	-	-
Loop seal clearing	il 180 bl 160	il - bl 157	-	-	-	-	il - bl 171	-
Occurrence of minimum primary side mass	420 2100	438	356	595	462	444	445	465
Primary-secondary pressure reversal	164	230	175	327	262	247	247	268
Second dryout	363	378	321	503	425	404	404	424
Rewetting due to accumulators	550	519	410	745	520	504	504	525
Accumulators injection start	420	433	354	593	458	444	444	466
Accumulators injection stop	953	919	755	1248	950	933	935	940
Final dryout	1705	1712	1531	1839	1711	1751	1747	1711
LPIS start	2100	2199	1919	2254	2134	2174	2174	2129
Final rewetting	2150	2206	2026	2317	2226	2271	2275	2219
End of test	2400	2500	2500	2500	2500	2500	2500	2500

**Tab. 8: Resulting sequence of events, comparison among experimental test and calculated results**

## 4.2.1 Qualitative and quantitative accuracy evaluation

### Qualitative accuracy

The qualitative accuracy evaluation here discussed is based upon a systematic procedure consisting in the identification of phenomena (CSNI list) and of RTA. In both cases five levels of judgment are introduced (E, R, M, U, and -) whose meaning is detailed in the notes of Tab. 9 and in App. 1 of ref. [20]. The related results are reported in Tabs. 9 and 10, where for completeness the information related to Relap5/mod2 results are given.

A positive overall qualitative judgment is achieved if 'U' is not present; in addition, the parameters characterizing the RTA (i.e., SVP = Single Valued Parameter, TSE = parameter belonging to the Time Sequence of Events, IPA= Integral Parameter and NDP = Non Dimensional Parameter) give an idea of the amount of the discrepancy.

In the present case the following conclusions could be reached:

- a) no 'U' mark is present;
- b) all RTA of the experiment are present in the calculated data
- c) the accuracy evaluation by adopting RTA and Key Phenomena, supports the conclusion that the calculation is qualitatively correct.

### Quantitative Accuracy

The positive conclusion of the qualitative accuracy evaluation, makes it possible addressing the quantitative accuracy evaluation. To this aim a special methodology, developed at University of Pisa, and widely used has been adopted.

The methodology is based upon the use of the Fast Fourier Transform (e.g. ref. [19]); its main features are detailed in App. 1 of ref. [20].

The results of the application of the method are given in Tab. 11, where again the information related to Relap5/mod2 calculation is given too. The conclusions from the quantitative accuracy evaluation analysis are as follows:

- a) the achieved results are well below the acceptability threshold both in relation to the overall accuracy (AA = 0.24 compared with the acceptability limit of 0.4) and the primary system pressure accuracy (AA = 0.061 compared with the acceptability limit of 0.1);
- b) the achieved results appear slightly better than those obtained by Relap5/mod2.

Definitely, the documented reference calculation is acceptable from the code assessment point of view; i.e. the code is positively assessed in relation to its capabilities to predict this kind of transient.

### Design of sensitivity calculations

Following the performed qualitative and quantitative accuracy evaluation, there is no need to perform additional calculations. Therefore, the planned sensitivity analyses are carried out with the main purpose of understanding the code behavior, rather than following needs for the accuracy evaluation.

The following objective for the studies were established:

- 1) influence of the break discharge coefficients;
- 2) prediction of the secondary side behavior;
- 3) prediction of the rods cladding temperature.

PHENOMENA	FACILITY	EXPERIMENT	JUDGEMENT OF CALC.	JUDGEMENT OF CALC.
	LOBI	BL-34	RELAP5/M2	RELAP5/M3.2
Natural circulation in one-phase flow	o	+	R	R
Natural circulation in two-phase flow	o	+	R	R
Reflux condenser mode and CCFL	+	-	M	M
Asymmetric loop behavior	+	+	M	M
Leak flow	o	o	E	E
Phase separation without mixture level formation	o	-	-	-
Mixture level and entrainment in SG secondary side	+	-	-	-
Mixture level and entrainment in the core	+	+	R	R
Stratification in horizontal pipes	+	+	M	M
Emergency core cooling mixing and condensation	+	+	R	R
Loop seal clearing	o	o	E	E
Pool formation in upper plenum - CCFL	-	-	-	-
Core wide void and flow distribution	-	-	-	-
Heat transfer in covered core	o	o	R	R
Heat transfer in partially uncovered core	+	o	R	R
Heat transfer in SG primary side	o	o	R	R
Heat transfer in SG secondary side	o	-	R	R
Pressurizer thermal hydraulics	+	+	E	E
Surge line hydraulics (CCFL choking)	+	-	-	-
One and two phase pump behavior	o	-	-	-
Structural heat and heat losses	+	+	E	E
Non condensable gas effect on leak flow	o	-	-	-
Phase separation in T-junctions	+	+	M	M
Separator behavior	-	-	-	-
Thermalhydraulic nuclear feedback	-	-	-	-
Boron mixing and transport	-	-	-	-

For the test facility vs. phenomenon:

- o suitable for code assessment
- + limited suitability
- not suitable

For phenomenon vs. test:

- o experimentally well defined
- + occurring but not well characterized
- not occurring or not measured

For phenomenon vs. calculation:

- E = Excellent
- R = Reasonable
- M = Minimal
- U = Unqualified
- = Not applicable

**Tab. 9: Judgment of code calculation performance on the basis of phenomena included in the CSNI matrix**

		UNIT	EXP	CALC (R5/M2)	CALC (R5/M3.2)	Judgment M2/M3.2
<b>RTA: Pressurizer emptying</b>						
TSE	emptying time*	s	23	23	25	E/E
	scram time	s	0.5	0.5	59	E/M
IPA	integrated flow from SL (from 0 up to emptying)	kg	-	-	-	-
<b>RTA: Steam generators secondary side behavior</b>						
TSE	main steam line valve closure	s	-	-	18	-
	difference between PS and SS pressure at 100 s	MPa	0.2	n.a.	0.5	-/R
SVP	SG level	m				
	• at the end of subcooled blowdown		7.8-7.7		7.5-7.9	-/E
	• when PS pressure equals SS pressure		7.9-7.7	n.a.	7.5-7.6	-/E
	• when ACC starts		7.6-7.8		7.5-7.6	-/E
	• when LPIS starts		7.8-7.5		7.41-7.45	-/E
SVP	SG pressure	MPa				
	• at the end of subcooled blowdown		7.2		7.2	-/E
	• when PS pressure equals SS pressure		7.2	n.a.	7.18	-/E
	• when ACC starts		6.9		7.13	-/R
	• when LPIS starts		5.8		6.9	-/R
<b>RTA: Subcooled blowdown</b>						
TSE	upper plenum in sat. conditions	s	7	50	12	R/R
	break two phase flow	s	120	100	60	R/R
IPA	break flow up to 30 s	kg	111	n.a.	118	-/E
<b>RTA: First dryout occurrence</b>						
TSE	time of dry out	s	135	-	-	M/M
	range of dry out occurrence at various core levels	s	135-156	-	-	M/M
	peak cladding temperature	K	625	-	-	M/M
SVP	average linear power	kW/m	1.46	1.45	n.a.	E/-
	maximum linear power	kW/m	1.91	1.88	n.a.	E/-
	core power / primary mass	kW/kg	1.56	1.27	n.a.	R/-
IPA	integral of dry out at 2/3 of core height	°C s	10600	-	-	-
NDP	primary mass / initial mass	%	43.5	37	-	R/-
<b>RTA: Rewet by loop seal clearing</b>						
	time of loop seal clearing	s	il 180 bl 160	il 200 bl 160	il - bl 157	R/M E/E
TSE	range of rewet occurrence	s	160-182	-	-	-
	time when rewet is completed	s	178	-	-	-
<b>RTA: Saturated blowdown</b>						
TSE	PS pressure equal to SS pressure	s	164	167	230	E/R
SVP	break flow at 200 s	kg/s	0.39	n.a.	0.61	/R
	break flow at 1000 s		0.09		0.08	-/E
IPA	integrated flow from 200 to 1000 s	kg	145	n.a.	173	-/R

Tab. 10 (part 1): Judgment of code calculation on the basis of relevant thermalhydraulic aspects



		UNIT	EXP	CALC (R5/M2)	CALC (R5/M3.2)	Judgment M2/M3.2
<b>RTA: Mass distribution in primary side</b>						
TSE	time of minimum mass occurrence	s	420 2100	419 1542	438 2123	E/R R/E
SVP	minimum primary side mass	kg	91.5 88.5	76 71	85 90	R/E R/E
	av. linear power at min. mass	kW/m	0.51	0.41	0.44	R/R
	minimum mass/TTF volume	kg/m <sup>3</sup>	141.2 136.5	117.2 109.5	131.1 138.8	R/R R/E
<b>RTA: Second dryout occurrence</b>						
TSE	time of dry out	s	363	-	378	- / R
	range of dry out occurrence at various core levels	s	363-443	-	264 - 400	- / R
	peak cladding temperature	K	671	-	609	- / R
SVP	average linear power	kW/m	0.79	0.79	0.60	E/R
	core power / primary mass	kW/kg	1.02	-	1.09	- / E
IPA	integral of dry out at 2/3 of core height		48580	-	24948	- / R
NDP	primary mass / initial mass	%	24.4	-	30.3	- / R
<b>RTA: Accumulators behavior</b>						
TSE	accumulators injection starts	s	420	420	433	E/R
	accumulators injection stops	s	953	953	919	E/R
IPA	total mass delivered by accumulators	kg	-	-	139.1	-
NDP	minimum mass/initial mass	%	21	16.8	18.8	R/E
	primary mass/initial mass	%	32.4	30.2	19.2	E/R
<b>RTA: Final dryout occurrence</b>						
TSE	time of dry out	s	1705	1393	1712	R/E
	range of dry out occurrence at various core levels	s	1680-2020	n.a.	1712 - 2023	- / E
	peak cladding temperature	K	783	752	713	R/R
SVP	average linear power	kW/m	0.36	0.28	0.36	R/E
	rate of rod temperature increase	K/s	1.37	0.55	0.61	R/R
	core power / primary mass	kW/kg	0.32	0.45	0.85	R/R
IPA	integral of dry out at 2/3 of core height	°C s	40333	n.a.	32225	- / R
NDP	primary mass / initial mass	%	27	23	23.8	R/R
<b>RTA: LPIS intervention</b>						
TSE	LPIS start	s	2100	-	2119	- / E
	range of rewet occurrence		2114-2188	-	2149 - 2259	- / R
	final rewetting	s	2150	-	2206	- / R
IPA	integrated flow from start to end of rewet	kg	21	-	34	- / R
NDP	primary mass/initial mass	%	20.3	-	19.9	- / E

**Tab. 10 (part 2) : Judgment of code calculation on the basis of relevant thermalhydraulic aspects**

PARAMETER	R5/M2		R5/M3	
	AA	WF	AA	WF
1 - PRZ pressure	0.03	0.05	0.061	0.032
2 - SG pressure - secondary side	0.21	0.05	0.356	0.044
3 - ACC pressure	0.09	0.02	0.061	0.022
4 - Core inlet fluid temperature	0.04	0.05	0.065	0.036
5 - Core outlet fluid temperature	0.14	0.05	0.063	0.048
6 - Upper head fluid temperature	0.31	0.03	0.324	0.026
7 - Integral break flow rate	0.04	0.05	0.076	0.042
8 - SG DC bottom fluid temperature	0.12	0.04	0.098	0.042
9 - Break flow rate	0.6	0.13	0.595	0.114
10 - ECCS integral flow rate	0.27	0.06	0.065	0.034
11 - Heater rod temp. (bottom level)	0.05	0.06	0.076	0.043
12 - Heater rod temp. (middle level)	0.92	0.06	0.530	0.025
13 - Heater rod temp. (high level)	0.78	0.06	0.501	0.032
14 - Primary side total mass	0.34	0.07	0.145	0.049
15 - Core level	0.95	0.07	0.385	0.036
16 - SG DC level	0.14	0.06	0.119	0.054
17 - DP inlet-outlet SG (IL)	0.92	0.05	1.207	0.046
18 - Core power	0.61	0.06	1.150	0.071
19 - DP loop seal BL - ascending side	0.60	0.014	0.398	0.045
20 - DP loop seal BL - descending side	0.53	0.08	0.799	0.042
21 - PRZ level	0.37	0.06	0.226	0.055
<b>TOTAL</b>	<b>0.33</b>	<b>0.05</b>	<b>0.24</b>	<b>0.038</b>

**Tab. 11: Summary of results obtained by application of FFT method to the selected parameters for the reference calculation**

### 4.3 Sensitivity calculations

Considering the reference calculation, a series of sensitivity analyses have been carried out, addressing the items 1), 2) and 3), reported in section 4.2.1, and additional input parameters; these are essentially user's choices that may have some effect in solving discrepancies leading to the same items.

The characteristics of the performed calculations can be drawn from Tab. 12, together with the results of the FFT methodology application (overall calculation and primary pressure). The summary of the FFT results related to all the parameters for all the performed sensitivity calculations are given in Tabs. 13 and 14.

The comparison between calculated and measured trends for each sensitivity analysis is reported in Appendix 3. In Figs. 14 to 25 the comparison of the sensitive analyses with the reference calculation is shown for some parameters of interest (primary pressure, break flow rate, heater rods temperature); more details are given hereafter .

#### 1) Influence of the break discharge coefficients

Two calculations have been performed: in the first one (run B341) the break discharge coefficients (subcooled and two phase) have been increased of 0.2, while in the second analysis (run B342) the discharge coefficients have been decreased of the same quantity. In both cases, there are no improvements of the predicted trends, with respect to the reference calculation, as can be deduced from the global accuracy evaluation (see Tab. 13).

In particular, the increase of the discharge coefficients results in a better prediction of the integral break flow rate (and, consequently, of the primary pressure and the fluid temperatures) up to about 300 s; afterwards, the break flow rate is overestimated, causing a faster depressurization of the primary side, with the consequent anticipation of the accumulators intervention and the early prediction of the dry out occurrence.

The decrease of the discharge coefficients causes the underprediction of the break flow rate: this discrepancy corresponds to the overprediction of the primary pressures (as can be noted from Tab. 13 the related AA value is the worst of all the calculations) and to the delay of the main phenomena, like the dryout occurrence.

#### 2) Prediction of the secondary side behavior

Aiming to improve the prediction of the secondary side parameters, the heat transfer coefficient has been multiplied by 1.5, so to increase the heat losses from the secondary side to the environment. The effect on the calculated results is negligible.

#### 3) Prediction of the rods cladding temperature

In order to obtain a better prediction of the rods cladding temperature, three analyses, adopting different options on the active structure of core, have been performed: in the first one (run B346) the core grids have been introduced (expanded format on card 901); in the other two (runs B344 and B345) the convective boundary conditions for the geometry types vertical boundary without crossflow (option 110 on card 601) and vertical bundle with crossflow (option 111 on card 601) have been activated. In all cases the calculated trends appear unaffected by the adopted changes; in particular the activation of option 110 or 111 give exactly the same results, as can be noted from Tab.13.

<b>ID Calculation</b>	<b>Variations from reference case</b>	<b>FFT application results (AA<sub>tot</sub> / WF / AA<sub>p</sub>)</b>	<b>Notes</b>
B341	CD Break increased of 0.2	0.3 / 0.036 / 0.027	To evaluate the influence of the break discharge coefficients
B342	CD Break decreased of 0.2	0.29 / 0.032 / 0.011	To evaluate the influence of the break discharge coefficients
B343	Secondary side heat losses increased	0.25 / 0.037 / 0.028	To improve the secondary side behavior
B346	Introduction of core grids	0.24 / 0.037 / 0.027	To improve the prediction of rods temperature
B344	Like B346; option 101 on card 601 (active structures of core)	0.26 / 0.039 / 0.03	To improve the prediction of rods temperature
B345	Like B346; option 111 on card 601 (active structures of core)	0.26 / 0.039 / 0.03	To improve the prediction of rods temperature

**Tab. 12: Sensitivity calculation matrix: varied input parameters and FFT results**

Calculation ID	B34D	B341	B342	B343	B344	B345	B346
1) Primary side pressure	0.061	0.092	0.110	0.071	0.064	0.064	0.073
2) Secondary side pressure	0.356	0.356	0.355	0.328	0.359	0.359	0.360
3) Accumulator 1 pressure	0.061	0.185	0.210	0.079	0.066	0.066	0.083
4) Fluid core inlet temperature	0.065	0.125	0.087	0.065	0.069	0.069	0.068
5) Fluid core outlet temperature	0.063	0.107	0.097	0.065	0.063	0.063	0.068
6) Upper plenum fluid temperature	0.324	0.370	0.272	0.324	0.325	0.325	0.326
7) Integral break mass flowrate	0.076	0.079	0.108	0.085	0.078	0.078	0.082
8) SG bottom downcomer fluid temperature	0.098	0.126	0.086	0.180	0.109	0.109	0.107
9) Break mass flowrate	0.595	0.723	0.495	0.690	0.600	0.600	0.604
10) ECCS integral mass flowrate	0.065	0.364	0.269	0.076	0.140	0.140	0.072
11) Rods clad. temperature (bottom level)	0.076	0.124	0.089	0.077	0.075	0.075	0.081
12) Rods clad. temperature (middle level)	0.530	0.705	0.731	0.647	0.694	0.694	0.609
13) Rods clad. temperature (high level)	0.501	0.783	0.834	0.561	0.782	0.782	0.531
14) Primary side mass inventory	0.145	0.185	0.268	0.164	0.189	0.189	0.161
15) Core level	0.385	0.498	0.580	0.415	0.474	0.474	0.432
16) SG downcomer level	0.119	0.109	0.123	0.127	0.116	0.116	0.112
17) Pressure drop SG inlet-outlet	1.207	1.177	1.123	1.184	1.150	1.150	1.218
18) Core power	1.150	0.930	0.369	0.399	0.257	0.257	0.435
19) Pressure drop loop seal (ascending side)	0.398	0.260	0.522	0.426	0.407	0.407	0.424
20) Pressure drop loop seal (decending side)	0.799	0.418	0.963	0.843	0.835	0.835	0.802
21) Pressurizer level	0.226	0.226	0.231	0.226	0.226	0.226	0.226
Calculation result	0.24	0.30	0.29	0.25	0.26	0.26	0.24

**Tab. 13: Summary of results obtained by application of FFT method to the selected parameters for the sensitivity calculations (AA values)**

Calculation ID	B34D	B341	B342	B343	B344	B345	B346
1) Primary side pressure	0.032	0.027	0.011	0.028	0.03	0.03	0.027
2) Secondary side pressure	0.044	0.044	0.043	0.043	0.044	0.044	0.044
3) Accumulator 1 pressure	0.022	0.008	0.007	0.017	0.02	0.02	0.017
4) Fluid core inlet temperature	0.036	0.036	0.017	0.033	0.036	0.036	0.032
5) Fluid core outlet temperature	0.048	0.045	0.023	0.045	0.048	0.048	0.044
6) Upper plenum fluid temperature	0.026	0.029	0.018	0.026	0.026	0.026	0.026
7) Integral break mass flowrate	0.042	0.054	0.034	0.038	0.04	0.04	0.037
8) SG bottom downcomer fluid temperature	0.042	0.043	0.042	0.043	0.042	0.042	0.043
9) Break mass flowrate	0.114	0.104	0.122	0.106	0.113	0.113	0.113
10) ECCS integral mass flow rate	0.034	0.046	0.048	0.05	0.055	0.055	0.049
11) Rods clad. temperature (bottom level)	0.043	0.042	0.017	0.04	0.038	0.038	0.04
12) Rods clad. temperature (middle level)	0.025	0.02	0.037	0.022	0.02	0.02	0.023
13) Rods clad. temperature (high level)	0.032	0.021	0.05	0.028	0.052	0.052	0.029
14) Primary side mass inventory	0.049	0.025	0.047	0.049	0.055	0.055	0.048
15) Core level	0.036	0.023	0.047	0.036	0.043	0.043	0.038
16) SG downcomer level	0.054	0.055	0.053	0.053	0.054	0.054	0.055
17) Pressure drop SG inlet-outlet	0.046	0.039	0.042	0.044	0.037	0.037	0.047
18) Core power	0.071	0.067	0.095	0.097	0.06	0.06	0.091
19) Pressure drop loop seal (ascending side)	0.045	0.044	0.031	0.041	0.029	0.029	0.041
20) Pressure drop loop seal (decending side)	0.042	0.047	0.035	0.038	0.032	0.032	0.038
21) Pressurizer level	0.055	0.055	0.055	0.056	0.056	0.056	0.055
Calculation result	0.038	0.036	0.032	0.037	0.039	0.039	0.037

**Tab. 14: Summary of results obtained by application of FFT method to the selected parameters for the sensitivity calculations (WF values)**




Fig. 14: LOBI post test BL-34 (run B341) - PRZ pressure




Fig. 15: LOBI post test BL-34 (run B341) - break integral flow rate




Fig. 16: LOBI post test BL-34 (run B342) - PRZ pressure




Fig. 17: LOBI post test BL-34 (run B342) - break integral flow rate






Fig. 18: LOBI post test BL-34 (run B343) - PRZ pressure




Fig. 19: LOBI post test BL-34 (run B343) - heater rod temperature (high level)




Fig. 20: LOBI post test BL-34 (run B344) - PRZ pressure




Fig. 21: LOBI post test BL-34 (run B344) - heater rod temperature (high level)




Fig. 22: LOBI post test BL-34 (run B345) - PRZ pressure




Fig. 23: LOBI post test BL-34 (run B345) - heater rod temperature (high level)




Fig. 24: LOBI post test BL-34 (run B346) - PRZ pressure




Fig. 25: LOBI post test BL-34 (run B346) - heater rod temperature (high level)

## 5. CONCLUSIONS

The analyzed transient (BL-34) is a small break LOCA experiment originated by a rupture in the cold leg of the broken loop of the LOBI/MOD2 facility. No high injection system is provided during the test; three dryout situations occur: the first one is quenched by an intrinsic mechanism like loop seal clearing; the second one is quenched by the intervention of the accumulators and the third one is recovered by the actuation of the low pressure injection system.

A qualified Relap5/Mod3.2 nodalization has been used for the analysis. The comparison between the code prediction and the experimental data leads to the conclusion that the code is able to predict all the significant aspects of the transient, with the exception of the first dryout phenomenon.

The present one constitutes the fourth analysis related to Small Break LOCA having similar characteristics (counterpart tests), e.g. refs. [20], [21] and [22].

Basically, the main conclusions achieved in previous analyses are confirmed by the present one:

- the Relap5/Mod3.2 has full capability in predicting the Relevant Thermalhydraulic Aspects that characterize the transient;
- the above conclusion has been reached following a detailed procedure, including qualitative and quantitative evaluation of accuracy;
- a limited set of sensitivity calculations has been carried out in the present case, considering the reasonable agreement reached in the reference calculation and the results of sensitivity analyses performed and documented in the above mentioned studies: the here considered sensitivity studies do not bring important advances in understanding code capabilities;
- minor discrepancies between measured and calculated trends, judged to be reasonable and acceptable, have been discussed in the text.



## REFERENCES

- [1] D'Auria F., Galassi G.M., "Code assessment methodology and results", IAEA Technical Workshop/Committee on Computer Aided Safety Analyses, Moscow, May 14-17, 1990.
- [2] D'Auria F., "Experimental facilities and system codes in Nuclear Reactor safety", Int. Seminar State of the Art on Safety Analyses and Licensing of Nuclear Power Plants, Varna (BG), November 2-6, 1987.
- [3] D'Auria F., Ferri R., Galassi G.M., Sugaroni F., "Evaluation of the data base from the small break LOCA counterpart tests performed in LOBI, SPES, BETHSY and LSTF facilities", University of Pisa Report, DCMN-NT 185 (91), Pisa, December 1991.
- [4] D'Auria F., Galassi G.M., Ingegneri M., "Evaluation of the data base from high power and low power small break LOCA counterpart tests performed in LOBI, SPES, BETHSY and LSTF facilities", University of Pisa Report, DCMN-NT 237 (94), Pisa, November 1994.
- [5] D'Auria F., Galassi G.M., V. Pellicoro "Post test analysis performed by Relap5/Mod2 code of the LOBI/MOD2 small break test BL-34 counterpart to Spes, Lstf and Bethsy experiments", University of Pisa Report, DCMN-NT 198 (92), Pisa, October 1992.
- [6] D'Auria F., Debrecin N., Galassi G.M., "Outline of the Uncertainty Methodology based on Accuracy Extrapolation (UMAE)", OECD-CSNI Special Workshop on Uncertainty Analysis Methods, London (UK), March 1-3 1994, J. Nuclear Technology - Vol. 109, N. 1 1995, pp. 21-38
- [7] Annunziato A., "LOBI project: quick look report Lobi/Mod2 test BL-34", Commission of the European Community, JRC, Ispra Site, Institute for Safety Technology Process Engineering Division, Communication N.4338, June 1991.
- [8] Bovalini R., D'Auria F., Leonardi M., "Qualification of the Fast Fourier Transform based methodology for the quantification of thermalhydraulic code accuracy", DCMN Report, NT 194 (92), Pisa July 1992.
- [9] Ohlmer E., Addabbo C., Piplies L., Riebold W., "The LOBI/MOD2 integral system test facility", Spec. Meeting on Small Break LOCA analyses in LWR's, Pisa, June 23-27, 1985.
- [10] Annunziato A., "Outline of the experimental profile of LOBI/MOD2 test BL-34", Commission of the European Community, JRC, Ispra Site. Technical note N. 1.91.54, April 1991.
- [11] Ramson W.H. et al, "Relap5/Mod2 code manual: user guide and input requirements", NUREG/CR-4312 EGG-2396, Idaho (USA). March 1997.
- [12] The Relap5 Code Development Team, "Relap5/Mod3 code manual", NUREG/CR-5535-V4, Idaho (USA), June 1995.
- [13] Bajs T., Bonuccelli M., D'Auria F., Debrecin N., Galassi G.M., "On transient qualification of Lobi/Mod2, Spes, Lstf, Bethsy and Krsko plant nodalizations for Relap5/Mod2 code", University of Pisa Report, DCMN-NT 185 (91), Pisa, December 1991.
- [14] Bonuccelli M., D'Auria F., Debrecin N., Galassi G.M., "A methodology for the qualification of thermalhydraulic code nodalizations", Proc. of NURETH-6 Conference, Grenoble (F), October 5-8, 1993.
- [15] D'Auria F., Galassi G.M., "Assessment of Relap5/Mod2 code on the basis of the experiments performed in Lobi Facility", J. of Nuclear Technology, Vol. 90, Nr. 3, 1990.
- [16] D'Auria F., Galassi G.M., Galetti R., Leonardi M., "Application of Fast Fourier Transform method to evaluate the accuracy of SBLOCA data base", University of Pisa Report, DCMN-NT 284 (96), Pisa, June 1996.
- [17] Aksan N., D'Auria F., Glaeser H., Lillington J., Pochard R., Sjoberg A., "Evaluation of the Separate Effects Tests (SET) Validation Matrix", OECD/CSNI Report OECD/GD (97) 9, Paris (F), November 1996.

- [18] Annunziato A., Glaeser H., Lillington J., Marsili P., Renault C., Sjoberg A., "CSNI Integral Test Facility Validation Matrix for the Assessment of Thermalhydraulic Codes for LWR LOCA and Transients", OECD Nuclear Energy Agency, NEA/CSNI/R (96) 17, July 1996.
- [19] Ambrosini W., Bovalini R., D'Auria F., "Evaluation of accuracy of thermalhydraulic code calculations", *Energia Nucleare*, vol. 7, pp. 5-16, 1990.
- [20] D'Auria F., Froggeri M., Giannotti W., "Relap5/Mod3.2 post test analysis and accuracy quantification of SPES test SP-SB-04", University of Pisa Report, DCMN-NT 319 (97) Rev. 2, April 1998.
- [21] D'Auria F., Froggeri M., Giannotti W., "Relap5/Mod3.2 post test analysis and accuracy quantification of SPES test SP-SB-03", University of Pisa Report, DCMN-NT 326 (97) Rev. 2, January 1998
- [22] D'Auria F., Froggeri M., Giannotti W., "Relap5/Mod3.2 post test analysis and accuracy quantification of Lobi test BL-44", University of Pisa Report DCMN-NT 356 (98) July 1998



## LIST OF ABBREVIATIONS

AA	Average Amplitude
ACC	Accumulator
ATWS	Anticipated Transient Without Scram
BL	Broken Loop
CAMP	Code Assessment and Maintenance Program
CCFL	Counter Current Flow Limitation
CSNI	Committee on the Safety of Nuclear Installations
DC	Downcomer
DCMN	Dipartimento Costruzioni Meccaniche e Nucleari
DP	Differential Pressure
ECCS	Emergency Core Cooling Systems
FFT	Fast Fourier Transform
HPIS	High Pressure Injection System
ICAP	International Code Assessment and Application Program
IL	Intact Loop
INEL	Idaho National Engineering Laboratories
IPA	Integral parameter
ISP	International Standard Problem
ITF	Integral Test Facility
$K_{reverse}$	Reverse form loss coefficient
LOCA	Loss Of Coolant Accident
LPIS	Low Pressure Injection System
MFWTIV	Main Feed Water Injection Valve
NA	Not Available
NPP	Nuclear Power Plant
NRC	Nuclear Regulatory Commission
PORV	Pressurizer Operated Relief Valve
PRZ	Pressurizer
SG	Steam Generator
SVP	Single Valued Parameter
TSE	Time Sequence of Events
UH	Upper Head
WF	Weighted Frequency

## SUBSCRIPTS

$A_R$	break area
$c$	core
$G_C$	overall core inlet flow rate
$P_R$	break position
RL	recirculation loop
V	fluid volume
W	core power
WI	total energy supplied by the heater rods



**Appendix 1**  
**Steady state calculation**






Fig. 1- PRZ pressure




Fig. 2- SGs secondary side pressure




Fig. 3- Accumulator pressure




Fig. 4- Core inlet fluid temperature




Fig. 5- Core outlet fluid temperature




Fig. 6- Upper Head coolant temperature




Fig. 7- Integral break flowrate (not relevant for steady state)




Fig. 8- SG bottom DC fluid temperature






Fig. 9- Break flowrate (not relevant for steady state)




Fig. 10- ECCS integral flowrate (not relevant for steady state)




Fig. 11- Heater rod temperature (bottom level)




Fig. 12- Heater rod temperature (middle level)




Fig. 13- Heater rod temperature (high level)




Fig. 14- Primary side total mass




Fig. 15- Vessel riser level




Fig. 16- SG DC level




Fig. 17- Pressure drop across inlet-outlet SG




Fig. 18- Core power (exp.) and exchanged power (calc.)




Fig. 19- Pressure drop across loop seal (ascendig side)




Fig. 20- Pressure drop across loop seal (descendig side)




Fig. 21- PRZ level




Fig. 22- Pressure drop between SG inlet plenum and Utubes top




Fig. 23- Pressure drop across DC-UH bypass




Fig. 24- Liquid hold up in SG (primary side)






Fig. 25- Core inlet flow rate




Fig. 26- pressure drop across SG outlet and vessel nozzle.




Fig. 27- SG DC flowrate




Fig. 28- Hot leg mass flowrate




Fig. 29- Primary and secondary pressure



## **Appendix 2**

### **Results of the reference calculation (run B24D)**






Fig. 1- PRZ pressure




Fig. 2- SGs secondary side pressure




Fig. 3- Accumulator pressure




Fig. 4- Core inlet fluid temperature






Fig. 5- Core outlet fluid temperature




Fig. 6- Upper Head coolant temperature




Fig. 7- Integral break flowrate




Fig. 8- SG bottom DC fluid temperature




Fig. 9- Break flowrate




Fig. 10- ECCS integral flowrate




Fig. 11- Heater rod temperature (bottom level)




Fig. 12- Heater rod temperature (middle level)




Fig. 13- Heater rod temperature (high level)




Fig. 14- Primary side total mass




Fig. 15- Vessel riser level




Fig. 16- SG DC level




Fig. 17- Pressure drop across inlet-outlet SG




Fig. 18- Core power (exp.) and exchanged power (calc.)




Fig. 19- Pressure drop across loop seal (ascending side)




Fig. 20- Pressure drop across loop seal (descending side)






Fig. 21- PRZ level




Fig. 22- Pressure drop between SG inlet plenum and Utubes top




Fig. 23- Pressure drop across DC-UH bypass




Fig. 24- Liquid hold up in SG (primary side)




Fig. 25- Core inlet flow rate




Fig. 26- pressure drop across SG outlet and vessel nozzle.




Fig. 27- SG DC flowrate




Fig. 28- Hot leg mass flowrate




Fig. 29- Primary and secondary pressure



**Appendix 3**  
**Results of the sensitivity analyses (runs B341, B342,  
B343, B344, B345 and B346)**








Fig. 1- B341 case : Primary and secondary side pressure




Fig. 2- B341 case : ECCS Integral flowrate and primary side total mass




Fig. 3- B341 case : Heater rod temperature (bottom level)




Fig. 4- B341 case : Heater rod temperature (middle level)




Fig. 5- B341 case : Heater rod temperature (high level)




Fig. 6- B341 case : Core inlet fluid temperature




Fig. 7- B341 case : Integral break flowrate








Fig. 8- B341 case : Pressure drop across loop seal (ascendig side)






Fig. 5- B342 case : Heater rod temperature (high level)




Fig. 6- B342 case : Core inlet fluid temperature




Fig. 7- B342 case : Integral break flowrate




Fig. 8- B342 case : Pressure drop across loop seal (ascendig side)




Fig. 1- B343 case : Primary and secondary side pressure




Fig. 2- B343 case : ECCS Integral flowrate and primary side total mass




Fig. 3- B343 case : Heater rod temperature (bottom level)




Fig. 4- B343 case : Heater rod temperature (middle level)




Fig. 5- B343 case : Heater rod temperature (high level)




Fig. 6- B343 case : Core Inlet fluid temperature




Fig. 7- B343 case : Integral break flowrate




Fig. 8- B343 case : Pressure drop across loop seal (ascending side)




Fig. 1- B344 case : Primary and secondary side pressure




Fig. 2- B344 case : ECCS Integral flowrate and primary side total mass




Fig. 3- B344 case : Heater rod temperature (bottom level)




Fig. 4- B344 case : Heater rod temperature (middle level)




Fig. 5- B344 case : Heater rod temperature (high level)




Fig. 6- B344 case : Core Inlet fluid temperature




Fig. 7- B344 case : Integral break flowrate




Fig. 8- B344 case : Pressure drop across loop seal (ascending side)






Fig. 1- B345 case : Primary and secondary side pressure




Fig. 2- B345 case : ECCS integral flowrate and primary side total mass




Fig. 3- B345 case : Heater rod temperature (bottom level)




Fig. 4- B345 case : Heater rod temperature (middle level)




Fig. 5- B345 case : Heater rod temperature (high level)




Fig. 6- B345 case : Core Inlet fluid temperature




Fig. 7- B345 case : Integral break flowrate




Fig. 8- B345 case : Pressure drop across loop seal (ascndly side)




Fig. 1- B346 case : Primary and secondary side pressure




Fig. 2- B346 case : ECCS Integral flowrate and primary side total mass




Fig. 3- B346 case : Heater rod temperature (bottom level)




Fig. 4- B346 case : Heater rod temperature (middle level)




Fig. 5- B346 case : Heater rod temperature (high level)




Fig. 6- B346 case : Core inlet fluid temperature




Fig. 7- B346 case : Integral break flowrate




Fig. 8- B346 case : Pressure drop across loop seal (ascending side)

**Appendix 4**  
**Reference calculation input deck**



=lobi-m0d2 bl34 post  
 \* lobi.bt17 nodalization used  
 \*  
 0000100 new transrt  
 \*  
 \*01 imp-chk  
 \*  
 \*  
 110 nitrogen  
 \*

\* time steps            min mj re  
 0000201 100. .5e-7 0.5 07003 10 40 40  
 0000202 200. .5e-7 0.1 07003 20 500 500  
 0000203 700. .5e-5 0.1 07003 50 500 500  
 0000204 1050. .5e-5 0.5 07003 10 100 100  
 0000205 1700. .5e-5 0.5 07003 10 100 100  
 0000206 2200. .5e-5 0.5 07003 10 100 100  
 0000207 1.e6 .5e-5 0.5 07003 10 100 100  
 \*

\* minor edits

\*\*\* pressures \*\*\*

301 p 539010000    \* pressurizer top  
 302 p 815010000    \* sg il steam dome  
 303 p 915010000    \* sg bl steam dome  
 304 p 615010000    \* il accumulator  
 305 p 768010000    \* bl accumulator

\*\*\* fluid temperature \*\*\*

306 tempf 106010000    \* core inlet  
 307 tempg 106010000    \* " "  
 308 tempf 540010000    \* pressurized  
 309 tempg 540010000    \* " "  
 310 tempf 500010000    \* il hot leg  
 311 tempg 500010000    \* " "  
 312 tempf 700010000    \* bl hot leg  
 313 tempg 700010000    \* " "  
 314 tempf 900050000    \* sg bl downcomer  
 315 tempg 900050000    \* " "  
 316 tempf 915010000    \* sg bl steam dome  
 317 tempg 915010000    \* " "  
 318 tempf 934010000    \* sg bl feedwater  
 319 tempf 936010000    \* sg bl auxiliary fw  
 320 tempf 615010000    \* il accumulator  
 321 tempf 768010000    \* bl accumulator

\*\*\* mass flowrates \*\*\*

322 mflowj 202010000    \* rpv downcomer  
 323 mflowj 106010000    \* core inlet  
 324 mflowj 430020000    \* dc-up holes by-pass  
 325 cntrlvar 176        \* dc-up gap by-pass  
 326 mflowj 440010000    \* dc-uh by-pass 1  
 327 mflowj 430030000    \* dc-uh by-pass 2  
 328 mflowj 700010000    \* bl hot leg  
 329 mflowj 500010000    \* il hot leg  
 330 mflowj 940010000    \* sg bl downcomer  
 331 mflowj 935000000    \* sg bl feedwater  
 332 mflowj 928000000    \* sg bl steam line  
 333 mflowj 840010000    \* sg il downcomer  
 334 mflowj 835000000    \* sg il feedwater  
 335 mflowj 828000000    \* sg il steam line

\*\*\* liquid levels \*\*\*

336 cntrlvar 001        \* pressurizer  
 338 cntrlvar 002        \* sg il downcomer  
 339 cntrlvar 003        \* sg bl downcomer  
 340 cntrlvar 177        \* il accumulator  
 341 cntrlvar 178        \* bl accumulator

\*\*\* mass inventory \*\*\*

342 cntrlvar 077        \* primary system  
 343 cntrlvar 059        \* sg il mass  
 344 cntrlvar 058        \* ss total mass  
 345 cntrlvar 179        \* il accumulator  
 346 cntrlvar 180        \* bl accumulator

\*\*\* pressure drop \*\*\*

347 cntrlvar 181        \* il total  
 348 cntrlvar 182        \* bl total  
 349 cntrlvar 026        \* il pump  
 350 cntrlvar 025        \* bl pump  
 351 cntrlvar 183        \* sg il u-tubes  
 352 cntrlvar 184        \* sg bl u-tubes  
 353 cntrlvar 016        \* across core

354 cntrlvar 185  
 355 cntrlvar 186

\*\*\* power \*\*\*

356 cntrlvar 036  
 357 cntrlvar 064  
 358 cntrlvar 067  
 359 cntrlvar 093  
 360 mflowj 543000000  
 361 mflowj 545000000  
 362 cntrlvar 060  
 363 cntrlvar 061

\*\*\* varie per plots \*\*\*

364 cntrlvar 057  
 365 tempf 430010000  
 366 tempf 460010000  
 367 tempf 720130000  
 368 tempf 570130000  
 369 tempf 745010000  
 370 tempf 605010000  
 371 tempf 834010000  
 372 tempf 850050000  
 373 tempg 820010000  
 374 velf 730060000  
 375 mflowj 531000000  
 376 mflowj 542000000  
 377 mflowj 923000000  
 378 mflowj 823000000  
 379 mflowj 870000000

\*\*\* rod surface temperatures

380 httemp 995000115  
 381 httemp 996000115  
 382 httemp 997000115  
 383 httemp 998000115  
 384 httemp 999000115  
 385 httemp 999100115  
 386 httemp 999300215  
 387 mflowj 757000000  
 388 mflowj 431000000  
 389 mflowj 871000000

\*

\*

\*\*\* trips \*\*\*

\*

\* break valve actuation bl34

401 time 0 ge null 0 100. 1 \* break on

402 time 0 lt null 0 -1. 1 \* break off

\*

\* shutoff valve

501 time 0 ge null 0 10.e5 1 \* shutoff valve

502 time 0 ge null 0 10.e6 1 \* shutoff valve

601 501 xor 502 n \* shutoff valve uh (477)

\*

\* pressurizer control

503 time 0 ge null 0 0. 1 \* valve 542 open

504 time 0 ge null 0 99. 1 \* valve 542 closure

602 503 xor 504 n \* valve 542 open

\*

\* il pump

505 time 0 lt null 0 -1. n \* pump il trip (600)

\*

506 time 0 ge null 0 0. 1 \* seal wat. il (601)

\*

507 p 539010000 lt null 0 11.6e6 n \* bl34 pu decay vel. il

\*

\*

\* lps actuation

509 httemp 995000115 ge null 0 769. 1\*

517 httemp 996000115 ge null 0 769. 1\*

518 httemp 997000115 ge null 0 769. 1\*

521 httemp 999000115 ge null 0 769. 1\*

534 httemp 999100115 ge null 0 769. 1\*

670 509 or 517 1\*

671 670 or 518 1\*

672 671 or 521 1\*

673 672 or 534 1\* lps actuation (625)

\*

\* bl pump

510 time 0 ge null 0 0. 1 \* seal wat. bl (744)

\* across sg il riser  
 \* across sg bl riser

\* core power  
 \* sg il exchanged power  
 \* sg bl exchanged power  
 \* heat losses primary side  
 \*  
 \* heat losses sg il  
 \* heat losses sg bl

\* sgb mass

\* up temperature  
 \* uh temperature  
 \* bl u-tubes top temp  
 \* il u-tubes top temp  
 \* bl cl temp  
 \* il cl temp  
 \* sg il fw temp  
 \* sg il dc bot temp  
 \* sg il sd temp  
 \* fluid vel bl loop  
 \* prz lvl contr  
 \* prz pre contr  
 \* sg bl pre contr  
 \* sg bl pre contr  
 \* il-bl sg connection

\* vol 400-03

\* vol 400-04

\* vol 400-05

\* vol 400-06

\* vol 400-07

\* vol 400-08

\* vol 420-01

\*

\*

\*

\*  
511 time 0 lt null 0 -1. n \* pump bl trip (740)  
\*  
512 time 0 ge null 0 101.1 n \* bl34 pu decay vel. bl  
\*  
\* prz internal heaters actuation  
513 time 0 ge null 0 0. 1 \* prz heaters  
539 cntrlvar 001 ge null 0 100. n \*  
603 513 and 539 n \* prz heaters actuation  
\*  
514 time 0 ge null 0 1.e6 1 \* bt17 ps leak  
\*  
\*  
\* sg - controllo pressione (stazionario)  
515 time 0 ge null 0 0. 1 \* sgil  
516 p 539010000 lt null 0 11.2e6 n \* bl&il sg p=const (vivs clo  
604 515 xor 516 n \* sgil s.s. sim., up to 13.2  
\* (vivs 823&923)  
\*  
519 p 539010000 lt null 0 11.2e6 n \* bl34 sl bl&il closure (828)  
\*  
520 time 0 ge null 0 0. 1 \* bl34 pump seal discharge(604  
\*  
\*  
522 time 0 ge null 0 0. 1 \* lvl control prez  
523 time 0 ge null 0 99.9 1 \* lvl control stop  
606 522 xor 523 n \* lvl control prez. (531)  
\*  
\* controllo livello sg (stazionario)& fw  
524 time 0 ge null 0 0. 1 \* lvl control sgs  
525 time 0 ge null 0 100. 1 \* lvl control stop  
607 524 xor 525 n \* lvl control sgs ss (835,935)  
\*  
526 time 0 ge null 0 100. 1 \* sg safety tank (active trip)  
\* and transient sl (not used)  
\*  
527 p 539010000 ge null 0 1.e9 n \* prz porv (543)  
\*  
528 time 0 ge null 0 1.e6 1 \* sgtr break valve bl21 (719)  
\*  
\* rotor block  
529 time 0 lt null 0 -1. 1 \* bl pump locked rotor sim.  
530 time 0 ge timeof 512 10.e6 1 \* delay time for opening  
608 529 and 530 n \* ball valve sim. (747)  
531 time 0 ge timeof 512 2.5 1 \* ball valve closure init.  
532 time 0 ge timeof 512 3.5 1 \* ball valve closure end  
609 531 xor 532 n \* ball valve closure trip  
\*  
\* separatore  
533 time 0 ge null 0 -1. 1 \* sep. control trip (814-819)+  
\*  
\* (non usati)  
535 time 0 ge null 0 1.e6 1 \* 2nd break opening (758)  
536 time 0 ge null 0 10.e5 1 \* 2nd break closure (758)  
610 535 xor 536 n \* 2nd break trip open. (758)  
\*  
537 time 0 ge null 0 100. 1 \* viv between sg ss open.  
\* (870)  
\*  
538 time 0 ge null 0 1.e6 n \* lvl contr. in bl sg ss  
\* during transient bl21  
\* end program  
540 time 0 ge null 0 2500. n \* lvl contr. in bl sg ss  
600 540 \* end program  
\*  
\* prz srv (not utilized in bl34)  
541 p 539010000 ge null 0 26.7e6 n \* 16.7  
542 p 539010000 ge null 0 20.0e6 1 \*  
543 p 539010000 lt null 0 16.4e2 n \*  
605 541 xor 542 n \* trip utilized  
\*  
\* prz porv+srv (not utiliz. in bl21 , bt17 and bl34)  
544 time 0 ge null 0 1.e6 1 \*  
545 cntrlvar 002 ge null 0 8.0 n \*  
546 time 0 ge timeof 611 0. 1 \* trip utilized  
611 544 and 545 n \*  
\*  
\* il sl during transient (not active in bl21 , bt17 and bl34)

557 time 0 ge null 0 1.e6 1 \*  
558 p 820010000 lt null 0 1.5e1 1 \*  
559 p 820010000 lt null 0 1.0e1 n \* closure trip  
621 557 xor 558 n \* opening trip  
\*  
\* il sg safety  
560 p 820010000 ge null 0 7.20e6 n \* opening il sg sa  
\*  
\* bl sg safety  
561 p 920010000 ge null 0 7.20e6 n \* opening bl sg sa  
\*  
\*  
\* bl sl during transient (not active in bl21 , bt17 and bl34)  
567 time 0 ge null 0 1.e6 1 \*  
568 p 920010000 lt null 0 1.5e1 1 \*  
569 p 920010000 lt null 0 1.0e1 n \* closure trip  
631 567 xor 568 n \* opening trip  
\*  
\* il afw actuation (not active in bl21 , bt17 and bl34)  
574 time 0 ge null 0 1.e6 1 \*  
570 cntrlvar 002 lt null 0 8.0 n \*  
571 time 0 ge timeof 574 1.e6 1 \*  
651 570 and 571 n \* trip utilized  
\*  
\* bl afw actuation (not active in bl21 , bt17 and bl34)  
572 cntrlvar 003 lt null 0 8.4 n \*  
573 time 0 ge timeof 574 1.e6 1 \*  
653 572 and 573 n \* trip utilized  
\*  
\* bt17 core power table  
575 p 539010000 lt null 0 13.e6 1 \* elect. power  
\*  
\* ssn opening  
576 time 0 ge null 0 1.e6 1 \* ssn opening in bl21  
\*  
\* ps vessel up bleed actuation  
580 htemp 995000115 ge null 0 3000. n \*  
583 htemp 996000115 ge null 0 3000. n \*  
584 htemp 997000115 ge null 0 3000. n \*  
585 htemp 999000115 ge null 0 3000. n \*  
586 htemp 999100115 ge null 0 3000. n \*  
674 580 or 583 n \*  
675 674 or 584 n \*  
676 675 or 585 n \*  
677 676 or 586 n \*  
581 htemp 999100115 lt null 0 3000. n \* clos.  
582 htemp 999100115 ge null 0 2000. 1 \*  
660 677 xor 582 n \* opening trip  
\*  
\* sg ss relief actuation in bt17 (non active in bl34)  
590 htemp 995000115 ge null 0 3000. n \*  
591 htemp 996000115 ge null 0 3000. n \*  
592 htemp 997000115 ge null 0 3000. n \*  
593 htemp 999000115 ge null 0 3000. n \*  
594 htemp 999100115 ge null 0 3000. n \*  
661 590 or 591 1  
662 661 or 592 1  
663 662 or 593 1  
664 663 or 594 1 \* opening trip (831)  
\*  
\* afw actuation in bt-17 (non active in bl34)  
595 p 820010000 lt null 0 -1. 1 \* afw actuation in bt17  
\*  
\* ss pre contr in bt-17 (up to dep. system intervention)  
\* closure trip (end of pre. contr.) is the 664 trip (start of dep.)  
596 time 0 ge null 0 10.e5 1 \* control start  
597 time 0 ge null 0 10.e6 1 \* viv op. trip end of val.  
665 596 xor 597 n \* viv op. trip  
\*  
\* control of leak nr 2 from up in bt17 (leak nr 1 is in bl cl)  
547 time 0 ge null 0 10.e5 1 \*  
548 time 0 ge null 0 10.e6 1 \*  
681 547 xor 548 n \* viv op. trip  
\*  
\* control of leak nr 3 from up in bt17 (leak nr 1 is in bl cl)  
549 time 0 ge null 0 10.e5 1 \*  
550 time 0 ge null 0 10.e6 1 \*  
682 549 xor 550 n \* viv op. trip



*		4000303.663	3
* il acc. viv actuation in bl34		4000304.583	4
485 p 539010000 lt null 0 3.96e6	1 *	4000305.584	5
*486 acvliq 615 lt null 0 0.09	1 * viv clo.	4000306.583	6
*486 time 0 ge null 0 1057.	1 * viv clo.	4000307.663	7
486 cntrivar 006 ge null 0 138.	1 * viv clo	4000308.412	8
487 acvliq 615 lt null 0 1.e-4	1 * viv clo	4000309.4305	9
749 486 or 487	1	4000401 0.9	
750 485 xor 749	n * viv op. (675)	4000601 90.9	
*		4000801 1.27e-7 0.01233	9
* hydraulic components		4000901 0.1 0.1	1
*		4000902 0.2 0.2	2
*		4000903 0.56 0.56	3
* lower plenum		4000904 0.37 0.37	4
1020000 lo.pl. branch		4000905 0.37 0.37	5
1020001 1 1		4000906 0.37 0.37	6
1020101 0.0764 0.373 0.0. -90. -373 4.e-5 0.3436 0000000		4000907 0.15 0.15	7
1020200 0 15.47e6 1.252e6 2.447e6 0.		4000908 0.15 0.15	8
1021101 200010000 102000000 .011252 1.44 0.34 0000000		4001001 0000000 9	
1021201 3.4 0. 0.		4001101 0000000 8	
*		4001201 0 15.47e6	1.268e6 2.447e6 0.0. 1
*		4001202 0 15.47e6	1.284e6 2.447e6 0.0. 2
* core inlet		4001203 0 15.47e6	1.300e6 2.447e6 0.0. 3
1060000 core.in. branch		4001204 0 15.47e6	1.316e6 2.447e6 0.0. 4
1060001 2 1		4001205 0 15.47e6	1.332e6 2.447e6 0.0. 5
1060101 0.02495 1.002 0.0. 90. 1.002 4.e-5 0.120 0000000		4001206 0 15.47e6	1.349e6 2.447e6 0.0. 6
1060200 0 15.47e6 1.252e6 2.447e6 0.		4001207 0 15.47e6	1.365e6 2.447e6 0.0. 7
1061101 102000000 106000000 0.0.1 0.1 0000000		4001208 0 15.47e6	1.383e6 2.447e6 0.0. 8
1062101 106010000 400000000 0.0.7 0.7 0000000		4001209 0 15.47e6	1.406e6 2.447e6 0.0. 9
1061201 3.4 0. 0.		4001300 1	
1062201 3.4 0. 0.		4001301 3.4 0. 0. 8	
*		*	
*		* upper plenum 1	
* downcomer		4100000 up.pl.1 branch	
2000000 dwncmr annulus		4100001 2 1	
2000001 6		4100101 0.0240 0.790 0.0. 90. 0.790 4.e-5 0.035 0011000	
2000101 0.011308 6		4100200 0 15.47e6 1.406e6 2.447e6 0.	
2000301 0.7900 1		4101101 400010000 410000000 0.0.79 0.70 0000000	
2000302 0.8425 2		4102101 410010000 420000000 0.0.00 0.00 0000000	
2000303 1.2460 3		4101201 3.4 0. 0.	
2000304 1.1670 4		4102201 0.0. 0.	
2000305 1.2750 5		*	
2000306 1.0020 6		*	
2000401 0. 6		* upper plenum 2	
2000601 -90. 6		4200000 up.pl.2 branch	
2000801 4.e-5 0.024 6		4200001 0	
2001001 0000000 6		4200101 0.024 0.7945 0.0 0.0 90. 0.7945 4.e-5 0.035 0000000	
2001101 0000000 5		4200200 0 15.47e6 1.406e6 2.447e6 0.	
2001201 0 15.47e6 1.252e6 2.447e6 0.0. 6		*	
2001300 1		* up leak valve (period 3000. - 3800. s)	
2001301 3.4 0. 0. 5		4210000 up.bl.v valve	
*		4210101 430000000 422000000 1.5e-6 0.0.0000100 1. 1.	
*		4210201 1 0. 0. 0.	
* vessel dc top		4210300 trpviv	
2020000 vs.dc.tp branch		4210301 681	
2020001 1 1		*	
2020101 0.011308 0.7945 0.0. -90. -.7945 4.e-5 0.024 0000000		* bt17 ps leak tank nr 2 (non active in bl34)	
2020200 0 15.47e6 1.252e6 2.447e6 0.		4220000 bl.le.t2 trndpvol	
2021101 202010000 200000000 0.0. 0. 0000000		4220101 1. 1. 0. 0. 90. 1. 4.e-5 0.0000000	
2021201 3.4 0. 0.		4220200 0 0	
*		4220201 0. 1.e5 120.e3 2.71e6 0.	
*		*	
* downcomer top		* up leak valve (period 3800. - 6000. s)	
2100000 downc.tp branch		4230000 up.bl.v valve	
2100001 1 1		4230101 430000000 424000000 1.50e-7 0.0.0000100 1. 1.	
2100101 0.011308 0.315 0.0. 90. .315 4.e-5 0.024 0000000		4230201 1 0. 0. 0.	
2100200 0 15.47e6 1.252e6 2.447e6 0.		4230300 trpviv	
2101101 210000000 202000000 0.0. 0. 0000000		4230301 682	
2101201 0. 0. 0.		*	
*		*	
*		* bt17 ps leak tank nr 3 (non active in bl34)	
* core active length (except the first 200 mm)		4240000 bl.le.t3 trndpvol	
4000000 core pipe		4240101 1. 1. 0. 0. 90. 1. 4.e-5 0.0000000	
4000001 9		4240200 0 0	
4000101 .0081152 9		4240201 0. 1.e5 120.e3 2.71e6 0.	
4000301 .200 1		*	
4000302 .412 2		*	
		* upper plenum 3	

4300000 up.pl3 branch  
 4300001 3 1  
 4300101 0.024 0.315 0. 0. 90. 0.315 4.e-5 0.035 0000000  
 4300200 0 15.47e6 1.262e6 2.447e6 0.  
 4301101 420010000 430000000 0. 0.5 0.5 0000000  
 4302101 210010000 430010000 .011308 11.1e4 11.1e4 0000000 \*2  
 f.38 kg/s  
 4303101 430010000 450000000 3.14e-4 50. 50. 0000000 \*uhby  
 .34 "  
 4301201 0. 0. 0.  
 4302201 0. 0. 0.  
 4303201 0. 0. 0.  
 \*  
 \* up bleed valve  
 4310000 up.blv valve  
 4310101 430000000 432000000 2.64e-5 0. 0. 0000100 1. 1.  
 4310201 1 0. 0. 0.  
 4310300 mtrvlv  
 4310301 660 581 0.8 0.  
 \*  
 \*  
 \* up bleed tank  
 4320000 up.bl.t tmdpv01  
 4320101 0.0121 2. 0. 0. 0. 0. 4.e-5 0. 0000000  
 4320200 2  
 4320201 0. 1.0e5 1.0  
 \*  
 \*  
 \* upper head lo.pipe  
 4400000 uh.lo.in branch  
 4400001 2 1  
 4400101 3.14e-4 0.0 .440e-3 0. 90. .655 4.e-5 0. 0000000  
 4400200 0 15.47e6 1.262e6 2.447e6 0.  
 4401101 210010000 440000000 0. 1.e4 1.e4 0000000 \*uhby .34 kg/s  
 4402101 440010000 455000000 0. 0. 0. 0000000 \* " " "  
 4401201 0. 0. 0.  
 4402201 0. 0. 0.  
 \*  
 \*  
 \* upp. head lo. in.  
 4500000 uh.lo.in branch  
 4500001 1 1  
 4500101 3.14e-4 0.0 .570e-3 0. 90. 0.655 4.e-5 0. 0000000  
 4500200 0 15.47e6 1.262e6 2.447e6 0.  
 4501101 450010000 455000000 0. 0. 0. 0000000 \*uhby .34 kg/s  
 4501201 0. 0. 0.  
 \*  
 \*  
 \* upp. head inlet branch  
 4550000 uh.brani branch  
 4550001 1 1  
 4550101 1.13e-2 .85 0. 0. 90. 0.85 4.e-5 0. 0000000  
 4550200 0 15.47e6 1.262e6 2.447e6 0.  
 4551101 455010000 460000000 0. 0. 0. 0000000  
 4551201 0. 0. 0.  
 \*  
 \*  
 \* upper head  
 4600000 upp.head pipe  
 4600001 2  
 4600101 0.0113 2  
 4600301 0.850 1  
 4600302 0.866 2  
 4600401 0. 2  
 4600601 90. 2  
 4600801 4.e-5 0.12 2  
 4600901 0. 0. 1  
 4601001 0000000 2  
 4601101 0000000 1  
 4601201 0 15.47e6 1.262e6 2.447e6 0. 0. 2  
 4601300 1  
 4601301 0. 0. 0. 1  
 \*  
 \*  
 \* up head up. ju.  
 4650000 uh.up.j sngljun  
 4650101 466000000 470000000 0. 1. 1. 0000000  
 4650201 1 0. 0. 0.

\*  
 \*  
 \* upp. head top hor. bran.  
 4660000 uh.top branch  
 4660001 1 1  
 4660101 1.48e-4 .85 0. 0. 0. 0. 4.e-5 0. 0000000  
 4660200 0 15.47e6 1.262e6 2.447e6 0.  
 4661101 466010000 460010000 0. 0. 0. 0000000  
 4661201 0. 0. 0.  
 \*  
 \*  
 \* upp. head conn. with dc pipe (upper)  
 4700000 uh.dc.cn snglvol  
 4700101 1.48e-3 0. 1.29e-3 0. 0. 0. 4.e-5 0. 0000000  
 4700200 0 15.47e6 1.262e6 2.447e6 0.  
 \*  
 \*  
 \* il.hl.vessel out meas.ins.n.11  
 5000000 il.ve.ou branch  
 5000001 3 1  
 5000101 0.004266 0.906 0. 0. 0. 0. 4.e-5 0. 0000000  
 5000200 0 15.47e6 1.406e6 2.447e6 0.  
 5001101 420010000 500000000 0. .9 1.5 0000000  
 5002101 500010000 510000000 0. 0. 0. 0000000  
 5003101 500000000 210000000 0.004266 6.19e4 6.19e4 0000000  
 \*gap dcil 1. kg  
 5001201 2.5 0. 0.  
 5002201 2.5 0. 0.  
 5003201 0. 0. 0.  
 \*  
 \*  
 \* conn betw. prez and bl  
 5070000 il.bl.pr branch  
 5070001 1 1  
 5070101 0. 2.5 7.1e-4 0. -90. -2.5 4.e-5 0. 0000000  
 5070200 0 15.47e6 1.406e6 2.447e6 0.  
 5071101 510000000 507000000 0. 0. 0. 0000000  
 5071201 0. 0. 0.  
 \*  
 \*  
 \* hl il sg. upstream 1  
 5100000 hl.il.g1 branch  
 5100001 1 1  
 5100101 0.004266 0.673 0. 0. 0. 0. 4.e-5 0.0737 0000000  
 5100200 0 15.47e6 1.406e6 2.447e6 0.  
 5101101 510010000 511000000 0. 0. 0. 0000000  
 5101201 2.5 0. 0.  
 \*  
 \*  
 \* hl il sg. upstream 2  
 5110000 hl.il.g2 branch  
 5110001 1 1  
 5110101 0.004266 0.673 0. 0. 0. 0. 4.e-5 0.0737 0000000  
 5110200 0 15.47e6 1.406e6 2.447e6 0.  
 5111101 511010000 512000000 0. 0. 0. 0000000  
 5111201 2.5 0. 0.  
 \*  
 \*  
 \* hl il sg. upstream 3  
 5120000 hl.il.g3 branch  
 5120001 1 1  
 5120101 0.004266 0.673 0. 0. 0. 0. 4.e-5 0.0737 0000000  
 5120200 0 15.47e6 1.406e6 2.447e6 0.  
 5121101 512010000 550000000 0. 0.5 0.5 0000000  
 5121201 2.5 0. 0.  
 \*  
 \*  
 \* surge line  
 5200000 su.li.hl pipe  
 5200001 3  
 5200101 1.36848e-4 3  
 5200301 0.700 1  
 5200302 3.600 2  
 5200303 2.800 3  
 5200401 0. 3  
 5200601 90. 1  
 5200602 -90. 2  
 5200603 90. 3

5200701 0.630 1  
 5200702 -3.380 2  
 5200703 2.500 3  
 5200801 4.e-5 0.0125 3  
 5200901 0. 0. 2  
 5201001 0000000 3  
 5201101 0000000 2  
 5201201 0 15.47e6 1.473e6 2.447e6 0. 0. 3  
 5201300 1  
 5201301 0. 0. 0. 2  
 \*  
 \*  
 \* prez bot  
 5300000 pre.bot. branch  
 5300001 1 1  
 5300101 0.00823 0.790 0. 0. 90. 0.790 4.e-5 0. 0000000  
 5300200 0 15.47e6 1.487e6 2.447e6 0.  
 5301101 530010000 535000000 0. 0. 0. 0000000  
 5301201 0. 0. 0.  
 \*  
 \*  
 \* prez level control j  
 5310000 prz.lec tmdpjun  
 5310101 534000000 530010000 0.  
 5310200 1 606 cntrivar 001  
 5310201 -1. 0. 0. 0.  
 5310202 1. 4.5 0. 0.  
 5310203 4.8 3.2 0. 0.  
 5310204 5.0 0.0 0. 0.  
 5310205 5.3 0. 0. 0.  
 \*  
 \*  
 \*  
 \* surge line inlet  
 5320000 su.li.in sngljun  
 5320101 530010000 520000000 0. 0. 0. 0000000  
 5320201 1 0. 0. 0.  
 \*  
 \*  
 \*  
 \* prez lvl control vol  
 5340000 prz.cvvo tmdpvvl  
 5340101 0. 10. 10. 0. 90. 10. 4.e-5 0. 0000000  
 5340200 2  
 5340201 0. 16.00e6 0.  
 \*  
 \*  
 \* prez middle  
 5350000 prez.m pipe  
 5350001 4  
 5350101 0.00840 1  
 5350102 0.01210 4  
 5350301 0.6300 1  
 5350302 1.120 2  
 5350303 1.500 3  
 5350304 1.500 4  
 5350401 0. 4  
 5350601 90. 4  
 5350801 4.e-5 0.1 4  
 5350901 0. 0. 3  
 5351001 0000000 4  
 5351101 0000000 3  
 5351201 0 15.47e6 1.597e6 2.447e6 0. 0. 4  
 5351300 1  
 5351301 0. 0. 0. 3  
 \*  
 \*  
 \* top prez comm. junction  
 5370000 tp.c.ju sngljun  
 5370101 535010000 540000000 0.0121 0. 0. 0000000  
 5370201 1 0. 0. 0.  
 \*  
 \*  
 \* prz top  
 5390000 prz.top branch  
 5390001 1 1  
 5390101 0.0121 1.0 0. 0. 90. 1.0 4.e-5 0. 0000000  
 5390200 0 15.47e6 1.597e6 2.447e6 1.

5391101 540010000 539000000 0. 0. 0. 0000000  
 5391201 0. 0. 0.  
 \*  
 \*  
 \* prz top inf  
 5400000 prz.topi snglvvl  
 5400101 .0121 1.040 0. 0. 90. 1.040 4.e-5 0. 0000000  
 5400200 0 15.47e6 1.597e6 2.447e6 0.95  
 \*  
 \*  
 \* stabilizzatore per lo stazionario  
 5410000 prez.t tmdpvvl  
 5410101 0.0121 2. 0. 0. 0. 0. 4.e-5 0. 0000000  
 5410200 2  
 5410201 0. 15.47e6 1.0  
 \*  
 \*  
 \* tmdp comm valve to prez  
 5420000 pr.tmv valve  
 5420101 539010000 541000000 0.0121 0. 0. 0000100  
 5420201 1 0. 0. 0.  
 5420300 trpvvl  
 5420301 602  
 \*  
 \*  
 \* prz porv  
 5430000 prz.porv valve  
 5430101 539010000 544000000 1.50e-5 0. 0. 0000100 0.8 0.8  
 \*bt17  
 5430201 1 0. 0. 0.  
 5430300 trpvvl  
 5430301 527  
 \*  
 \*  
 \* prz porv tank  
 5440000 porv.ta tmdpvvl  
 5440101 0.0121 2. 0. 0. 0. 0. 4.e-5 0. 0000000  
 5440200 2  
 5440201 0. 1.5e6 1.0  
 \*  
 \*  
 \* prz srv  
 5450000 prz.srv valve  
 5450101 539010000 546000000 33.2e-6 0. 0. 0000100 1.2 1. \*era  
 9.7  
 5450201 1 0. 0. 0.  
 5450300 mtrvvl  
 5450301 605 543 0.8 0.  
 \*  
 \*  
 \* prz srv tank  
 5460000 srv.ta tmdpvvl  
 5460101 0.0121 2. 0. 0. 0. 0. 4.e-5 0. 0000000  
 5460200 2  
 5460201 0. 1.5e6 1.0  
 \*  
 \*  
 \* prz srv+porv (ssn)  
 5470000 prz.srpo valve  
 5470101 539010000 548000000 33.20e-6 0. 0. 0000100 1. 1.  
 5470201 1 0. 0. 0.  
 5470300 trpvvl  
 5470301 576  
 \*  
 \*  
 \* prz srv+porv tank  
 5480000 srppo.t tmdpvvl  
 5480101 0.0121 2. 0. 0. 0. 0. 4.e-5 0. 0000000  
 5480200 2  
 5480201 0. 1.5e5 1.0  
 \*  
 \*  
 \* il vert. meas. ins. sg.in. n.12  
 5500000 il.v.hi snglvvl  
 5500101 .00407 .828 0. 0. 90. .828 4.e-5 .06 0000000  
 5500200 0 15.47e6 1.406e6 2.447e6 0.  
 \*  
 \*

```

* sg inlet hl ju.
5550000 il.sg.ij sngljun
5550101 550010000 560000000 0. 0. 0. 0000000
5550201 1 2.5 0. 0.
*
*
* il sg inlet
5600000 il.sg.in pipe
5600001 3
5600101 .01089 3
5600301 0.574 3
5600401 0. 3
5600601 90. 3
5600701 0.574 3
5600801 4.e-5 .1177 3
5600901 0. 0. 2
5601001 0000000 3
5601101 0000000 2
5601201 0 15.47e6 1.406e6 2.447e6 0. 0. 3
5601300 1
5601301 2.5 0. 0. 2
*
*
* il sg. lp. inlet
5650000 il.sg.lp branch
5650001 2 1
5650101 0. .338 .009054 0. 90. .338 4.e-5 0. 0000000
5650200 0 15.47e6 1.406e6 2.447e6 0.
5651101 560010000 565000000 0. 0.2 0.05 0000000
5652101 565010000 570000000 0. 0.25 0.45 0000000
5651201 2.5 0. 0.
5652201 2.5 0. 0.
*
*
* il sg. tubes
5700000 il.sg.pl pipe
5700001 24
5700101 .0072412 24
5700301 0.5 6
5700302 0.75 10
5700303 0.656 14
5700304 0.75 18
5700305 0.5 24
5700401 0. 24
5700601 90. 12
5700602 -90. 24
5700701 0.5 6
5700702 0.75 10
5700703 0.656 12
5700704 -.656 14
5700705 -.75 18
5700706 -.5 24
5700801 4.e-5 .019 24
5700901 0. 0. 11
5700902 .08 .08 12
5700903 0. 0. 23
5701001 0000000 24
5701101 0000000 23
5701201 000 15.47e6 1.396e6 2.447e6 0. 0. 1
5701202 000 15.47e6 1.387e6 2.447e6 0. 0. 2
5701203 000 15.47e6 1.378e6 2.447e6 0. 0. 3
5701204 000 15.47e6 1.369e6 2.447e6 0. 0. 4
5701205 000 15.47e6 1.360e6 2.447e6 0. 0. 5
5701206 000 15.47e6 1.351e6 2.447e6 0. 0. 6
5701207 000 15.47e6 1.351e6 2.447e6 0. 0. 7
5701208 000 15.47e6 1.342e6 2.447e6 0. 0. 8
5701209 000 15.47e6 1.342e6 2.447e6 0. 0. 9
5701210 000 15.47e6 1.333e6 2.447e6 0. 0. 10
5701211 000 15.47e6 1.324e6 2.447e6 0. 0. 11
5701212 000 15.47e6 1.316e6 2.447e6 0. 0. 12
5701213 000 15.47e6 1.316e6 2.447e6 0. 0. 13
5701214 000 15.47e6 1.307e6 2.447e6 0. 0. 14
5701215 000 15.47e6 1.307e6 2.447e6 0. 0. 15
5701216 000 15.47e6 1.299e6 2.447e6 0. 0. 16
5701217 000 15.47e6 1.299e6 2.447e6 0. 0. 17
5701218 000 15.47e6 1.290e6 2.447e6 0. 0. 18
5701219 000 15.47e6 1.290e6 2.447e6 0. 0. 19
5701220 000 15.47e6 1.278e6 2.447e6 0. 0. 20

```

```

5701221 000 15.47e6 1.273e6 2.447e6 0. 0. 21
5701222 000 15.47e6 1.268e6 2.447e6 0. 0. 22
5701223 000 15.47e6 1.263e6 2.447e6 0. 0. 23
5701224 000 15.47e6 1.258e6 2.447e6 0. 0. 24
5701300 1
5701301 2.5 0. 0. 23
*
*
* il.sg.lp. outlet
5750000 il.sg.lo branch
5750001 2 1
5750101 0. .338 .009054 0. -90. -0.338 4.e-5 0. 0.
5750200 0 15.47e6 1.252e6 2.447e6 0.
5751101 570010000 575000000 0. .45 .25 0000000
5752101 575010000 580000000 0. .05 .2 0000000
5751201 2.5 0. 0.
5752201 2.5 0. 0.
*
*
* il sg outlet
5800000 il.sg.ou pipe
5800001 3
5800101 .01089 3
5800301 0.574 3
5800401 0. 3
5800601 -90. 3
5800701 -.574 3
5800801 4.e-5 .1177 3
5800901 0. 0. 2
5801001 0000000 3
5801101 0000000 2
5801201 0 15.47e6 1.252e6 2.447e6 0. 0. 3
5801300 1
5801301 2.5 0. 0. 2
*
*
* il sg outlet
5820000 il.sg.ou sngljun
5820101 580010000 585000000 0. 0. 0. 0000000
5820201 1 2.5 0. 0.
*
*
* il vert. meas. ins. sg. ou. n.13
5850000 il.v.n2 sngivol
5850101 .00407 .828 0. 0. -90. -0.828 4.e-5 0.06 0000000
5850200 0 15.47e6 1.252e6 2.447e6 0.
*
*
* il cl. meas. ins.-loop seal ju
5870000 il.loo.s sngljun
5870101 585010000 590000000 0. 0. 0. 0000000
5870201 1 2.5 0. 0.
*
*
* il. loop seal
5900000 il.s.sea pipe
5900001 6
5900101 4.266e-3 6
5900301 .950 1
5900302 .7825 3
5900303 .855 4
5900304 .7825 6
5900401 0. 6
5900601 -90. 3
5900602 0. 4
5900603 90. 6
5900801 4.e-5 .073 6
5900901 0. 0. 5
5901001 0000000 6
5901101 0000000 5
5901201 0 15.47e6 1.252e6 2.447e6 0. 0. 6
5901300 1
5901301 2.5 0. 0. 5
*
*
* il. pump. pl inlet meas. ins n.14
5950000 il.pu.in branch
5950001 1 1

```

5950101 0.00407 0.750 0.0. 90. 0.750 4.e-5 0.0.  
 5950200 0 15.47e6 1.252e6 2.447e6 0.  
 5951101 590010000 595000000 0.0. 0. 0000000  
 5951201 2.5 0.0.  
 \*  
 \*  
 \* il pump  
 6000000 il-pump pump  
 6000101 0. 0.2 2.e-3 0. 90. 0.2 0  
 6000108 595010000 .00407 .060 .02 0000000  
 6000109 605000000 .0 0.02 0.06 0000000  
 6000200 0 15.47e6 1.252e6 2.447e6 0.  
 6000201 1 2.5 0.0.  
 6000202 1 2.5 0.0.  
 6000301 0 0 0 -1 0 505 1  
 6000302 745.6 0.05740 0.027878 139.9 45.47 0.157  
 6000303 747.3 0.0. 0.0. 0.0.  
 \*\*\* head curves \*\*\*  
 6001100 1 1  
 6001101 0. 1.055  
 6001102 0.05 1.064  
 6001103 0.1 1.079  
 6001104 0.2 1.102  
 6001105 0.3 1.12  
 6001106 0.4 1.131  
 6001107 0.5 1.131  
 6001108 0.6 1.123  
 6001109 0.7 1.104  
 6001110 0.8 1.0785  
 6001111 0.9 1.043  
 6001112 1.0 1.  
 \*  
 6001200 1 2  
 6001201 0. -.78  
 6001202 0.1 -.6285  
 6001203 0.2 -.478  
 6001204 0.3 -.323  
 6001205 0.31 -.308  
 6001206 0.4 -.169  
 6001207 0.6 .173  
 6001208 0.7 .365  
 6001209 0.8 .556  
 6001210 0.9 .768  
 6001211 1. 1.  
 \*  
 6001300 1 3  
 6001301 -1. 2.11  
 6001302 -9 1.927  
 6001303 -8 1.758  
 6001304 -7 1.6105  
 6001305 -6 1.489  
 6001306 -.5 1.38  
 6001307 -.4 1.282  
 6001308 -.3 1.20  
 6001309 -.2 1.133  
 6001310 -.1 1.0805  
 6001311 -.05 1.0615  
 6001312 0. 1.055  
 \*  
 6001400 1 4  
 6001401 -1. 2.11  
 6001402 -9 1.862  
 6001403 -8 1.65  
 6001404 -7 1.474  
 6001405 -6 1.332  
 6001406 -.5 1.212  
 6001407 -.4 1.105  
 6001408 -.3 1.002  
 6001409 -.2 0.911  
 6001410 -.1 0.83  
 6001411 0. 0.761  
 \*  
 6001500 1 5  
 6001501 0. .424  
 6001502 .2 .543  
 6001503 .3 .603  
 6001504 .4 .66  
 6001505 .487 .702

6001506 .5 .7095  
 6001507 .55 .7305  
 6001508 .6 .7495  
 6001509 .65 .762  
 6001510 .7 .777  
 6001511 .75 .789  
 6001512 .8 .804  
 6001513 .85 .828  
 6001514 .9 .861  
 6001515 .95 .901  
 6001516 1. .948  
 \*  
 6001600 1 6  
 6001601 0. .761  
 6001602 .1 .71  
 6001603 .2 .664  
 6001604 .3 .644  
 6001605 .35 .646  
 6001606 .4 .653  
 6001607 .5 .6795  
 6001608 .6 .707  
 6001609 .7 .746  
 6001610 .8 .799  
 6001611 .9 .861  
 6001612 .95 .901  
 6001613 1. .948  
 \*  
 6001700 1 7  
 6001701 -1. -.11  
 6001702 -.7 -.46  
 6001703 -.6 -.283  
 6001704 -.5 -.147  
 6001705 -.45 -.081  
 6001706 -.384 0.  
 6001707 -.35 0.041  
 6001708 -.30 .106  
 6001709 -.25 .17  
 6001710 -.20 .233  
 6001711 -.15 .29  
 6001712 -.1 .3395  
 6001713 -.05 .384  
 6001714 0. .424  
 \*  
 6001800 1 8  
 6001801 -1. -1.11  
 6001802 -.7 -1.4  
 6001803 -.5 -1.34  
 6001804 -.3 -1.17  
 6001805 -.1 -0.91  
 6001806 0. -0.78  
 \*\*\* torque curves \*\*\*  
 6001900 2 1  
 6001901 0. .439  
 6001902 .05 .442  
 6001903 .1 .46  
 6001904 .2 .515  
 6001905 .3 .5825  
 6001906 .4 .647  
 6001907 .5 .706  
 6001908 .6 .764  
 6001909 .7 .823  
 6001910 .8 .882  
 6001911 .9 .9415  
 6001912 1. 1.  
 \*  
 6002000 2 2  
 6002001 0. -.518  
 6002002 .1 -.35  
 6002003 .2 -.184  
 6002004 .3 -.018  
 6002005 .31 0.  
 6002006 .4 .151  
 6002007 .6 .464  
 6002008 .7 .5985  
 6002009 .8 .731  
 6002010 .9 .864  
 6002011 1. 1.  
 \*

6002100 2 3  
 6002101 -1. 1.182  
 6002102 -9 1.037  
 6002103 -.8 .911  
 6002104 -.7 .804  
 6002105 -.6 .712  
 6002106 -.5 .632  
 6002107 -.4 .567  
 6002108 -.3 .513  
 6002109 -.2 .473  
 6002110 -.1 .4495  
 6002111 -.05 .441  
 6002112 0. .439  
 \*  
 6002200 2 4  
 6002201 -1. 1.182  
 6002202 -9 1.12  
 6002203 -.8 1.013  
 6002204 -.7 1.104  
 6002205 -.6 1.24  
 6002206 -.5 1.323  
 6002207 -.4 1.34  
 6002208 -.3 1.256  
 6002209 -.2 1.122  
 6002210 -.1 1.041  
 6002211 0. 0.984  
 \*  
 6002300 2 5  
 6002301 0. -.569  
 6002302 .2 -318  
 6002303 .3 -202  
 6002304 .4 -.098  
 6002305 .487 0.  
 6002306 .5 .013  
 6002307 .55 .0695  
 6002308 .6 .121  
 6002309 .65 .173  
 6002310 .7 .229  
 6002311 .75 .284  
 6002312 .8 .345  
 6002313 .85 .409  
 6002314 .9 .474  
 6002315 .95 .549  
 6002316 1. .630  
 \*  
 6002400 2 6  
 6002401 0. .984  
 6002402 .1 .9505  
 6002403 .2 .929  
 6002404 .3 .905  
 6002405 .35 .89  
 6002406 .4 .873  
 6002407 .5 .84  
 6002408 .6 .802  
 6002409 .7 .761  
 6002410 .8 .7205  
 6002411 .9 .678  
 6002412 .95 .653  
 6002413 1. .630  
 \*  
 6002500 2 7  
 6002501 -.6 -1.59  
 6002502 -.5 -1.39  
 6002503 -.45 -1.297  
 6002504 -.384 -1.18  
 6002505 -.35 -1.1205  
 6002506 -.3 -1.04  
 6002507 -.25 -.956  
 6002508 -.2 -.87  
 6002509 -.15 -.7905  
 6002510 -.1 -.716  
 6002511 -.05 -.64  
 6002512 0. -.569  
 \*  
 6002600 2 8  
 6002601 -1. -0.518  
 6002602 0. -0.518

\*\*\* two-phase curves multipliers \*\*\*

6003000 0  
 6003001 0. 0.  
 6003002 .2 0.  
 6003003 .43 1.  
 6003004 .95 1.  
 6003005 1. 0.  
 \*  
 6003100 0  
 6003101 0. 0.  
 6003102 1. 0.  
 \*\*\* two-phase curves differences \*\*\*  
 6004100 1 1  
 6004101 0. .165  
 6004102 .05 .774  
 6004103 .1 .81  
 6004104 .3 .773  
 6004105 .5 .804  
 6004106 .7 .828  
 6004107 1. .816  
 \*  
 6004200 1 2  
 6004201 0. .22  
 6004202 .1 .2285  
 6004203 .3 .248  
 6004204 .5 .329  
 6004205 .7 .477  
 6004206 1. .816  
 \*  
 6004300 1 3  
 6004301 -1. -.82  
 6004302 -.8 -1.491  
 6004303 -.7 -1.6695  
 6004304 -.5 -1.78  
 6004305 -.3 -1.5  
 6004306 -.2 -1.137  
 6004307 -.1 -.5895  
 6004308 0. 0.165  
 \*  
 6004400 1 4  
 6004401 -1. -.82  
 6004402 -.90 -.538  
 6004403 -.8 -.33  
 6004404 -.6 -.098  
 6004405 -.4 -.045  
 6004406 -.2 -.039  
 6004407 0. -.039  
 \*  
 6004500 1 5  
 6004501 0. -.046  
 6004502 .2 -.366  
 6004503 .4 -.58  
 6004504 .6 -.6805  
 6004505 .7 -.693  
 6004506 .8 -.676  
 6004507 1. -.482  
 \*  
 6004600 1 6  
 6004601 0. -.039  
 6004602 .2 -.066  
 6004603 .3 -.095  
 6004604 .4 -.097  
 6004605 .6 -.173  
 6004606 .8 -.331  
 6004607 1. -.482  
 \*  
 6004700 1 7  
 6004701 -1. .89  
 6004702 -.7 .87  
 6004703 -.5 .653  
 6004704 -.3 .366  
 6004705 -.1 .1  
 6004706 0. -.046  
 \*  
 6004800 1 8  
 6004801 -1. .89  
 6004802 -.7 .37  
 6004803 -.5 .03  
 6004804 -.3 .2

6004805 -1 .22  
 6004806 0 .22  
 \*\*\* two-phase torque curve differences \*\*\* (loft l2-5)  
 6004900 2 1  
 6004901 0. 1.  
 6004902 1. 1.  
 \*  
 6005000 2 2  
 6005001 0. 1.  
 6005002 1. 1.  
 \*  
 6005100 2 3  
 6005101 -1. 1.9843  
 6005102 -.80096 1.394  
 6005103 -.60638 1.0975  
 6005104 -.40686 0.82  
 6005105 -.19928 0.6648  
 6005106 0. 0.6032  
 \*  
 6005200 2 4  
 6005201 -1.0000 1.9843  
 6005202 -.82234 1.8308  
 6005203 -.63371 1.6824  
 6005204 -.45853 1.557  
 6005205 -.26702 1.436  
 6005206 -.17610 1.3879  
 6005207 -.0893 1.3481  
 6005208 0. 1.2336  
 \*  
 6005300 2 5  
 6005301 0. -.45  
 6005302 .4 -25  
 6005303 .5 0.  
 6005304 1. .3569  
 \*  
 6005400 2 6  
 6005401 0. 1.2336  
 6005402 .09 1.1965  
 6005403 .1885 1.1096  
 6005404 .2734 1.0416  
 6005405 .4586 0.8958  
 6005406 .5744 .7807  
 6005407 .7381 .6134  
 6005408 .7685 .5849  
 6005409 .87 .4877  
 6005410 1. .357  
 \*  
 6005500 2 7  
 6005501 -1. -1.  
 6005502 -3 -9  
 6005503 -1 -5  
 6005504 0. -.45  
 \*  
 6005600 2 8  
 6005601 -1. -1.  
 6005602 -.25 -9  
 6005603 -.08 -8  
 6005604 0. -.67  
 \*\*\* decay velocity pump intact loop \*\*\*  
 6006100 507  
 6006101 0. 42.8  
 6006102 1.1 42.8  
 6006103 3.1 0.  
 6006104 1.e6 0.  
 \*  
 \* pump seal water ju. il  
 6010000 pu.seax tmdpjun  
 6010101 603000000 605000000 0.  
 6010200 1 506  
 6010201 0. 11.e-3 0. 0.  
 6010202 12. 16.2e-3 0. 0.  
 6010203 20. 12.0e-3 0. 0.  
 6010204 160. 9.7e-3 0. 0.  
 6010205 325. 8.0e-3 0. 0.  
 6010206 700. 5.3e-3 0. 0.  
 6010207 1200. 4.8e-3 0. 0.  
 6010208 2400. 4.2e-3 0. 0.

6010209 1.e6 4.2e-3 0. 0.  
 \*  
 \*  
 \* tmdpvol for pump seal water exit  
 6020000 pu.s.exv tmdpvol  
 6020101 0. 1. 5. 0. 90. 1. 4.e-5 0. 0000000  
 6020200 0 0  
 6020201 0. 0.9e6 120.e3 2.71e6 0.  
 \*  
 \*  
 \* pump seal water tank il  
 6030000 pu.se.i tmdpvol  
 6030101 0. 1. 5. 0. 90. 1. 4.e-5 0. 0000000  
 6030200 0 0  
 6030201 0. 19.4e6 120.e3 2.71e6 0.  
 \*  
 \*  
 \* junction sim. pump seal water exit  
 6040000 pu.s.exj tmdpjun  
 6040101 102010000 602000000 6.0e-4  
 6040200 1 520 cntrivar 175  
 6040201 0. 0.0 0. 0.  
 6040202 1. 1. 0. 0.  
 \*  
 \*  
 \* il. pump. pump exit  
 6050000 pu.il.e branch  
 6050001 1 1  
 6050101 0.00426 1.035 0. 0. 0. 0. 4.e-5 0. 0000000  
 6050200 0 15.47e6 1.252e6 2.447e6 0.  
 6051101 605010000 610000000 0. 0. 0. 0000000  
 6051201 2.5 0. 0.  
 \*  
 \* meas. ins n. 15 and cold leg il  
 6100000 mcl.il pipe  
 6100001 4  
 6100101 4.266e-3 4  
 6100301 .65625 4  
 6100401 0. 4  
 6100601 0. 4  
 6100801 4.e-5 0. 4  
 6100901 0. 0. 3  
 6101001 0000000 4  
 6101101 0000000 3  
 6101201 0 15.47e6 1.252e6 2.447e6 0. 0. 4  
 6101300 1  
 6101301 2.5 0. 0. 3  
 \*  
 \*  
 \* meas. ins. n. 16 il cl ves. side  
 6120000 m.ins.16 branch  
 6120001 2 1  
 6120101 0.004266 0.670 0. 0. 0. 0. 4.e-5 0.068 0000000  
 6120200 0 15.47e6 1.252e6 2.447e6 0.  
 6121101 610010000 612000000 0. 0. 0. 0000000  
 6122101 612010000 202000000 0. 1.05 0.7 0000000  
 6121201 2.5 0. 0.  
 6122201 2.5 0. 0.  
 \*  
 \*  
 \* accumulator il (active in bl34)  
 6150000 il.acc accum  
 6150101 0. 4.68 279.85e-3 0. 90. 4.68 2.3e-5 0. 0000000  
 6150200 3.97e6 300. 0. \* 4.1e6  
 6151101 670010000 4.83e-4 10. 10. 0000000  
 6152200 0.222 0. 0.01 0.01 0.01 0. 0. 0.  
 \*  
 \*  
 \* junction sim. lpiis  
 6250000 hpis.j tmdpjun  
 6250101 630000000 612000000 6.0e-4  
 6250200 1 673  
 6250201 -1. 0. 0. 0.  
 6250202 0. 0.4 0. 0.  
 6250203 1.e6 0.4 0. 0.  
 \*  
 \* lpiis tank  
 6300000 hpis.t tmdpvol

6300101 0. 10. 10. 0. 90. 10. 4.e-5 0. 0000000  
 6300200 0 0  
 6300201 0. 19.4e6 120.e3 2.71e6 0.  
 \*  
 \* il accum injection line (active in bl34)  
 6700000 ilaccl pipe  
 6700001 2  
 6700101 0.483e-3 2  
 6700301 5.7195 1  
 6700302 4.925 2  
 6700401 0. 2  
 6700601 90. 2  
 6700801 4.e-5 0. 2  
 6700901 1. 1. 1  
 6701001 0000000 2  
 6701101 0000000 1  
 6701201 000 4.2e6 1.996e5 2.44e6 0. 0. 2  
 6701300 1  
 6701301 0. 0. 0. 1  
 \*  
 \* il accum valve  
 6750000 ilaccv valve  
 6750101 670000000 200000000 5.150e-5 180. 1.e6 0000100 1. 1.  
 6750201 1 0. 0. 0.  
 6750300 mtrvrv  
 6750301 750 486 2. 0.  
 \*  
 \* broken loop hl vess conn half  
 7000000 bl.ve.ou branch  
 7000001 3 1  
 7000101 1.6691e-3 0.5 0. 0. 0. 0. 4.e-5 0. 0000000  
 7000200 0 15.47e6 1.406e6 2.447e6 0.  
 7001101 420010000 700000000 0. 1.30 1.47 0000000  
 7002101 700010000 702000000 0. 0.1 0.1 0000000  
 7003101 700000000 210000000 1.6691e-3 4.40e4 4.40e4 0000000  
 \*gap dcbl  
 7001201 0.9 0. 0.  
 7002201 0.9 0. 0.  
 7003201 0. 0. 0.  
 \*  
 \* broken loop prz connection tee  
 7020000 prz.bl.c branch  
 7020001 2 1  
 7020101 1.6691e-3 0.563 0. 0. 0. 0. 4.e-5 0. 0000000  
 7020200 0 15.47e6 1.406e6 2.447e6 0.  
 7021101 520010000 702000000 0. 0. 0. 0000000  
 7022101 702010000 705000000 0. 0. 0. 0100000  
 7021201 0. 0. 0.  
 7022201 0.90 0. 0.  
 \*  
 \* bl hl meas. ins is. vol n.1 of the pipe  
 7050000 blhl pipe  
 7050001 3  
 7050101 1.669e-3 3  
 7050301 0.563 3  
 7050401 0. 3  
 7050601 0. 3  
 7050801 4.e-5 0. 3  
 7050901 0. 0. 2  
 7051001 0000000 3  
 7051101 0000000 2  
 7051201 0 15.47e6 1.406e6 2.447e6 0. 0. 3  
 7051300 1  
 7051301 0.90 0. 0. 2  
 \*  
 \* broken loop sg inlet 1  
 7100000 sg.bl.il branch  
 7100001 2 1  
 7100101 1.6691e-3 0.842 0. 0. 90. 0.842 4.e-5 0. 0000000  
 7100200 000 15.47e6 1.406e6 2.447e6 0.  
 7101101 705010000 710000000 0. 0.35 0.35 0000000  
 7102101 710010000 712000000 0. 0.01 0.01 0000000  
 7101201 0.9 0. 0.

7102201 0.9 0. 0.  
 \*  
 \* bl sg inlet  
 7120000 sg.bl.in pipe  
 7120001 3  
 7120101 3.668e-3 3  
 7120301 0.639 2  
 7120302 0.6395 3  
 7120401 0. 3  
 7120601 90. 3  
 7120801 4.e-5 0.04610 3  
 7120901 0. 0. 2  
 7121001 0000000 3  
 7121101 0000000 2  
 7121201 0 15.47e6 1.406e6 2.447e6 0. 0. 3  
 7121300 1  
 7121301 0.9 0. 0. 2  
 \*  
 \* blsg lower ple inlet  
 7180000 sg.bl.il branch  
 7180001 2 1  
 7180101 0. 0.221 3.01e-3 0. 90. 0.221 4.e-5 0. 0000000  
 7180200 0 15.47e6 1.406e6 2.447e6 0.  
 7181101 712010000 718000000 0. 0.30 0.1 0000000  
 7182101 718010000 720000000 0. 0.6 0.8 0000000  
 7181201 0.9 0. 0.  
 7182201 0.9 0. 0.  
 \*  
 \* sgtr break bl21 0.4% (non active in bl34)  
 7190000 sgtr.bre valve  
 7190101 718010000 948000000 0.0039 1.e-6 1.e-6 0000100 1. 1.  
 7190201 1 0. 0. 0.  
 7190300 trpvrv  
 7190301 528  
 \*  
 \* bl sg. tubes  
 7200000 bl.sg.pl pipe  
 7200001 24  
 7200101 .0024137 24  
 7200301 0.5 6  
 7200302 0.75 10  
 7200303 0.656 14  
 7200304 0.75 18  
 7200305 0.5 24  
 7200401 0. 24  
 7200601 90. 12  
 7200602 -90. 24  
 7200701 0.5 6  
 7200702 0.75 10  
 7200703 0.656 12  
 7200704 -.656 14  
 7200705 -.75 18  
 7200706 -.5 24  
 7200801 4.e-5 .019 24  
 7200901 0. 0. 11  
 7200902 .08 .08 12  
 7200903 0. 0. 23  
 7201001 0000000 24  
 7201101 0000000 23  
 7201201 000 15.47e6 1.396e6 2.447e6 0. 0. 1  
 7201202 000 15.47e6 1.387e6 2.447e6 0. 0. 2  
 7201203 000 15.47e6 1.378e6 2.447e6 0. 0. 3  
 7201204 000 15.47e6 1.369e6 2.447e6 0. 0. 4  
 7201205 000 15.47e6 1.360e6 2.447e6 0. 0. 5  
 7201206 000 15.47e6 1.351e6 2.447e6 0. 0. 6  
 7201207 000 15.47e6 1.351e6 2.447e6 0. 0. 7  
 7201208 000 15.47e6 1.342e6 2.447e6 0. 0. 8  
 7201209 000 15.47e6 1.342e6 2.447e6 0. 0. 9  
 7201210 000 15.47e6 1.333e6 2.447e6 0. 0. 10  
 7201211 000 15.47e6 1.324e6 2.447e6 0. 0. 11  
 7201212 000 15.47e6 1.316e6 2.447e6 0. 0. 12  
 7201213 000 15.47e6 1.316e6 2.447e6 0. 0. 13  
 7201214 000 15.47e6 1.307e6 2.447e6 0. 0. 14  
 7201215 000 15.47e6 1.307e6 2.447e6 0. 0. 15



7201216 000 15.47e6 1.299e6 2.447e6 0.0 0.16  
 7201217 000 15.47e6 1.299e6 2.447e6 0.0 0.17  
 7201218 000 15.47e6 1.290e6 2.447e6 0.0 0.18  
 7201219 000 15.47e6 1.290e6 2.447e6 0.0 0.19  
 7201220 000 15.47e6 1.278e6 2.447e6 0.0 0.20  
 7201221 000 15.47e6 1.273e6 2.447e6 0.0 0.21  
 7201222 000 15.47e6 1.268e6 2.447e6 0.0 0.22  
 7201223 000 15.47e6 1.263e6 2.447e6 0.0 0.23  
 7201224 000 15.47e6 1.258e6 2.447e6 0.0 0.24  
 7201300 1  
 7201301 0.9 0.0 0.23  
 \*  
 \*  
 \* bl sg lower plenum outlet  
 7220000 sg.bl.po branch  
 7220001 2 1  
 7220101 0.0221 3.01e-3 0. -90. -0.221 4.e-5 0.0000000  
 7220200 0 15.47e6 1.252e6 2.447e6 0.  
 7221101 720010000 722000000 0.0 0.8 0.6 0000000  
 7222101 722010000 725000000 0.0 0.1 0.3 0000000  
 7221201 0.9 0.0.  
 7222201 0.9 0.0.  
 \*  
 \*  
 \* bl sg outlet  
 7250000 sg.bl.ou pipe  
 7250001 3  
 7250101 3.668e-3 3  
 7250301 0.6395 1  
 7250302 0.639 3  
 7250401 0.3  
 7250601 -90. 3  
 7250801 4.e-5 0.04610 3  
 7250901 0.0 2  
 7251001 0000000 3  
 7251101 0000000 2  
 7251201 000 15.47e6 1.252e6 2.447e6 0.0 0.3  
 7251300 1  
 7251301 0.9 0.0 0.2  
 \*  
 \*  
 \* bl sg outlet meas ins n. 23 inl ju  
 7270000 sg.m.23j sngljun  
 7270101 725010000 730000000 0.0 0.0 0.0000000  
 7270201 1 0.9 0.0.  
 \*  
 \*  
 \* loop seal bl  
 7300000 bl.ls pipe  
 7300001 6  
 7300101 1.6691e-3 6  
 7300301 1.042 1  
 7300302 1.151 2  
 7300303 0.701 3  
 7300304 0.884 4  
 7300305 0.701 5  
 7300306 1.151 6  
 7300401 0.6  
 7300601 -90. 3  
 7300602 0.4  
 7300603 90. 6  
 7300801 4.e-5 0.0460 4  
 7300802 4.e-5 0.0400 6  
 7300901 0.0 3  
 7300902 0.04 0.04 4  
 7300903 0.04 0.04 5  
 7301001 0000000 6  
 7301101 0000000 5  
 7301201 0 15.47e6 1.252e6 2.447e6 0.0 0.6  
 7301300 1  
 7301301 0.9 0.0 0.5  
 \*  
 \*  
 \* bl pump  
 7400000 bl-pump pump  
 7400101 0.0 2.2.e-3 0.90 0.2 0  
 7400108 730010000 1.66e-3 0.03 0.075 0000000  
 7400109 745000000 0.0 0.075 0.03 0000000

7400200 0 15.47e6 1.252e6 2.447e6 0.  
 7400201 1 0.9 0.0.  
 7400202 1 0.9 0.0.  
 7400301 600 600 600 -1 0 511 1  
 7400302 745.6 0.02428 0.027878 139.9 45.47 0.157  
 7400303 747.3 0.0 0.0 0.0.  
 \*  
 \*  
 \* pump bl decay velocity  
 7406100 512  
 7406101 0. 18.1  
 7406102 1.1 18.1  
 7406103 3.1 0.  
 7406104 1.e6 0.  
 \*  
 \*  
 \* bl loop seal tank  
 7420000 bl.pu.st tmdpvol  
 7420101 0.1 5.0 90. 1.4.e-5 0.0000000  
 7420200 0 0  
 7420201 0.19.4e6 120.e3 2.71e6 0.  
 \*  
 \*  
 \* bl pump seal water ju  
 7440000 bl.pusx tmdpjun  
 7440101 742000000 745000000 0.  
 7440200 1 510  
 7440201 0. 9.0e-3 0.0.  
 7440202 5. 10.6e-3 0.0.  
 7440203 20. 8.5e-3 0.0.  
 7440204 50. 7.5e-3 0.0.  
 7440205 200. 7.9e-3 0.0.  
 7440206 400. 6.0e-3 0.0.  
 7440207 600. 5.0e-3 0.0.  
 7440208 1300. 4.7e-3 0.0.  
 7440209 2000. 4.5e-3 0.0.  
 7440210 2400. 4.3e-3 0.0.  
 7440211 1.e6 4.3e-3 0.0.  
 \*  
 \*  
 \* bl pump outlet  
 7450000 bl.pu.ou branch  
 7450001 0  
 7450101 1.6691e-3 0.503 0.0 0.0 4.e-5 0.0000000  
 7450200 0 15.47e6 1.252e6 2.447e6 0.  
 \*  
 \*  
 \* blocked rotor bl pump resist. sim.  
 7470000 bl.bps valve  
 7470101 745010000 750000000 1.669e-3 0.0 0.0000100 1.1.  
 7470201 1 0.9 0.0.  
 7470300 mtrvrv  
 7470301 608 609 .8285 1.  
 \*  
 \*  
 \* bl meas ins 25 break upstream  
 7500000 bl.me.25 pipe  
 7500001 5  
 7500101 1.6691e-3 5  
 7500301 0.369 5  
 7500401 0.5  
 7500601 0.5  
 7500801 4.e-5 0.042 5  
 7500901 0.0 4  
 7501001 0000000 5  
 7501101 0000000 4  
 7501201 0 15.47e6 1.252e6 2.447e6 0.0 0.5  
 7501300 1  
 7501301 0.9 0.0 0.4  
 \*  
 \*  
 \* bt17 ps leak (non active in bl34)  
 7570000 ps.leak tmdpjun  
 7570101 770000000 765000000 0.  
 7570200 1 514  
 7570201 0. .0 0.0.  
 7570202 0.1 .0165 0.0.  
 7570203 3164. .0165 0.0.  
 7570204 3165. .0001 0.001 0.

\* gtot = .059

```

7570205 3846. .0001 0.001 0. * gtot = .059
7570206 3847. .0 0.001 0. * gtot = .0044
7570207 6013. .0 0.001 0. * " "
7570208 6014. .00001 0.078 0.
7570209 1.e6 .00001 0.078 0.
*
* break valve (bl34)
7600000 break.v valve
7600101 774000000 761000000 4.254400e-5 1.2 1.2 0000100 1.15
0.7 1.0
7600201 1 0. 0. 0.
7600300 mtrv1v
7600301 401 402 0.8 0.
*
* containment simulator
7610000 contain. tmdpv0l
7610101 1. 1. 0. 0. 0. 0. 4.e-3 0. 0000000
7610200 0 0
7610201 0. 3.5e5 1.2e5 2.6e6 1.
*
* bt17 ps leak tank (non active in bl34)
7650000 bl.leat tmdpv0l
7650101 1. 1. 0. 0. 90. 1. 4.e-5 0. 0000000
7650200 0 0
7650201 0. 1.e5 120.e3 2.71e6 0.
*
* accumulator bl (not active in bl34)
7680000 bl.acc accum
7680101 0. 6.794 94.35e-3 0. 90. 6.794 2.3e-5 0. 0000000
7680200 0.1e6 300. 0. * 4.1
7681101 770000000 1.84e-4 196. 196. 0000000
7682200 0.0599 0. 10. 6.68 0.01 0 0. 0.
*
* bl loop vessel inlet ins. n.26
7700000 bl.ve.i1 branch
7700001 2 1
7700101 1.66e-3 0.5072 0. 0. 0. 0. 4.e-5 0.04 0000000
7700200 0 15.47e6 1.252e6 2.447e6 0.
7701101 750010000 770000000 0. 0. 0. 0000000
7702101 770010000 772000000 0. 0. 0. 0000000
7701201 0.9 0. 0.
7702201 0.9 0. 0.
*
* bl loop vessel inlet ins. n.26
7720000 bl.ve.i2 branch
7720001 1 1
7720101 1.66e-3 0.5072 0. 0. 0. 0. 4.e-5 0.04 0000000
7720200 0 15.47e6 1.252e6 2.447e6 0.
7721101 772010000 774000000 0. 0. 0. 0000000
7721201 0.9 0. 0.
*
* bl loop vessel inlet ins. n.26
7740000 bl.ve.i3 branch
7740001 1 1
7740101 1.66e-3 0.5072 0. 0. 0. 0. 4.e-5 0.04 0000000
7740200 0 15.47e6 1.252e6 2.447e6 0.
7741101 774010000 776000000 0. 0. 0. 0000000
7741201 0.9 0. 0.
*
* bl loop vessel inlet ins. n.26
7760000 bl.ve.i4 branch
7760001 1 1
7760101 1.66e-3 0.5072 0. 0. 0. 0. 4.e-5 0.04 0000000
7760200 0 15.47e6 1.252e6 2.447e6 0.
7761101 776010000 202000000 0. 1.25 2.3 0000000
7761201 0.9 0. 0.
*
* il sg sec side
8000000 sg.tu.sl annulus
8000001 12
8000101 0.029905 10

```

```

8000102 0.045 12
8000301 0.5 6
8000302 0.75 10
8000303 0.656 11
8000304 0.746 12
8000401 0. 12
8000601 90. 12
8000801 4.e-5 .0122 12
8000901 0.12 0.12 11
8001001 0000000 12
8001101 0000000 11
8001201 000 6.9749e6 1235000.8 2.582e6 4.99625e-2 0. 1
8001202 000 6.9729e6 1235000.8 2.582e6 9.46827e-2 0. 2
8001203 000 6.9709e6 1.255e5 2.582e6 0.13673 0. 3
8001204 000 6.9649e6 1.255e6 2.582e6 0.17439 0. 4
8001205 000 6.9609e6 1.255e6 2.582e6 0.20671 0. 5
8001206 000 6.9549e6 1.255e6 2.582e6 0.23317 0. 6
8001207 000 6.9549e6 1.255e6 2.582e6 0.26170 0. 7
8001208 000 6.9549e6 1.255e6 2.582e6 0.26438 0. 8
8001209 000 6.9549e6 1.255e6 2.582e6 0.27176 0. 9
8001210 000 6.9549e6 1.255e6 2.582e6 0.26627 0. 10
8001211 000 6.9449e6 1.255e6 2.582e6 0.25648 0. 11
8001212 000 6.9489e6 1.255e6 2.582e6 0.25592 0. 12
8001300 1
8001301 11. .0 0. 1
8001302 11.0 .0 0. 2
8001303 11.0 .0 0. 3
8001304 10.70 .193 0. 11
*
* il sg sec side tube out. ju
8050000 sgi.tuou sngljun
8050101 800010000 810000000 0. 1. 1. 0000000
8050201 1 10.20 .800 0.
*
* il sg. sec side tube outlet
8100000 sgi.tuv pipe
8100001 2
8100101 .023 1
8100102 .000 2
8100301 .645 1
8100302 .946 2
8100401 0. 1
8100402 0.050 2
8100601 90. 2
8100801 4.e-5 0. 2
8100901 0. 0. 1
8101001 0000000 2
8101101 0000000 1
8101201 0 6.856e6 1435000. 2.582e6 .465 0. 1
8101202 0 6.856e6 1435000. 2.582e6 .824 0. 2
8101300 1
8101301 10.20 0.800 0. 1
*
* il sg fine separator
8150000 fn.sep separatr
8150001 3 1
8150101 .1538 .791 0. 0. 90. .791 4.e-5 0 0000000
8150200 0 6.852e6 1435000. 2.582e6 0.99
8151101 815010000 820000000 0. .0 .0 0000000 0.5
8152101 815000000 830000000 0. .0 .0 0000000 0.15
8153101 810010000 815000000 98.52e-4 0. 0. 0000000
8151201 0. 0.193 0.
8152201 9. 0. 0.
8153201 9. 0.193 0.
*
* il. sg. ss. up plenum
8200000 sgi.upl branch
8200001 0 1
8200101 .1538 0.424 0. 0. 90. 0.424 4.e-5 0. 0000000
8200200 0 6.852e6 1435000. 2.582e6 0.99
*
* valve conn il sg to tmdpv0l (p=const.)

```

8230000 ilsgcx valve  
 8230101 820010000 824000000 .1538 0. 0. 0000100 1. 1.  
 8230201 1 0. 0. 0.  
 8230300 mtrvfv  
 8230301 604 516 1.5 1.  
 \*  
 \*  
 \* il sg. const vol  
 8240000 ilsg.v tmdpvov  
 8240101 0. 1. 10. 0. 90. 1. 4.e-5 0. 0000000  
 8240200 2 0  
 8240201 0. 69.4e5 0. 9999  
 \*  
 \*  
 \* sl il sim tmdpjum  
 8280000 slilj tmdpjum  
 8280101 820010000 829000000 0.  
 8280200 1 519  
 8280201 -1. 0. 0.193 0.  
 8280202 0. 0. 0.193 0.  
 8280203 1.5 0. 0. 0.  
 8280204 1.e6 0. 0. 0.  
 \*  
 \*  
 \* sl il sim tmdpvov  
 8290000 slil.v tmdpvov  
 8290101 0. 10. 10. 0. 90. 10. 4.e-5 0. 0000000  
 8290200 0 0  
 8290201 0. 10.e5 7.61e5 2.58e6 1.  
 \*  
 \*  
 \* il sg. top.dc  
 8300000 ilsg.tdc branch  
 8300001 1 1  
 8300101 .130 .946 0. 0. -90. -.946 4.e-5 .0 0000000  
 8300200 0 6.856e6 1.435e6 2.582e6 1.0  
 8301101 830010000 840000000 0. .1 .1 0000000  
 8301201 9. 0. 0.  
 \*  
 \*  
 \* sg il feedwater tank  
 8340000 sg.fw.ta tmdpvov  
 8340101 0. 10. 10. 0. 0. 0. 4.e-5 0. 0000000  
 8340200 0 0  
 8340201 0. 80.40e5 9.19e5 2.57e6 0.  
 \*  
 \*  
 \* feed water main  
 8350000 ilmfv tmdpjum  
 8350101 834000000 840010000 0.  
 8350200 1 607 cntrivar 002  
 8350201 -1.0 0. 0. 0.  
 8350202 1.0 1.0 0. 0.  
 8350203 6.9 0.4 0. 0.  
 8350204 8.14 0.193 0. 0.  
 8350205 8.4 0. 0. 0.  
 8350206 12. 0. 0. 0.  
 \*  
 \*  
 \* sg il afw tank  
 8360000 sg.afw.ta tmdpvov  
 8360101 0. 10. 10. 0. 0. 0. 4.e-5 0. 0000000  
 8360200 0 0  
 8360201 0. 90.40e5 6.70e5 2.7e6 0.  
 \*  
 \*  
 \* auxiliary feedwater sg il  
 8370000 il.afw tmdpjum  
 8370101 836000000 840010000 0.  
 8370200 1 595  
 8370201 -1.0 0. 0. 0.  
 8370202 0.0 0.079 0. 0.  
 8370203 1.e6 0.079 0. 0.  
 \*  
 \*  
 \* il sg safety valve  
 8380000 ilsg.sa valve

8380101 820010000 839000000 3.e-5 9. 9. 0000100 \* come bl21  
 rest  
 8380201 1 0. 0. 0.  
 8380300 trpvfv  
 8380301 560  
 \*  
 \*  
 \* il sg safety tank  
 8390000 ilsg.st tmdpvov  
 8390101 0. 10. 10. 0. 90. 10. 4.e-5 0. 0000000  
 8390200 2 526  
 8390201 -1. 3.9e5 0.99  
 8390202 0. 3.9e5 0.99  
 8390203 1.e6 3.9e5 0.99  
 \*  
 \*  
 \* il. top dc  
 8400000 il.tdc branch  
 8400001 1 1  
 8400101 .100 .645 0. 0. -90. -.645 4.e-5 .0 0000000  
 8400200 0 6.856e6 1.251e6 2.582e6 0.001  
 8401101 840010000 850000000 0. .0 .0 0000000  
 8401201 11. 0. 0.  
 \*  
 \*  
 \* sg. il. dc. tube ju. ss  
 8450000 sg.sg.tu sngljum  
 8450101 850010000 800000000 0. 35. 35. 0000000  
 8450201 1 11. 0. 0.  
 \*  
 \*  
 \* sg il dc  
 8500000 sg.il.dc annulus  
 8500001 5  
 8500101 .01195 5  
 8500301 1.402 1  
 8500302 1.5 5  
 8500401 0. 5  
 8500601 -90. 5  
 8500801 4.e-5 .02 5  
 8500901 0. 0. 4  
 8501001 0000000 5  
 8501101 0000000 4  
 8501201 0 6.8890e6 1.213e6 2.582e6 0. 0. 5  
 8501300 1  
 8501301 11. 0. 0. 4  
 \*  
 \*  
 \* il.blsg conetion (attiva nel periodo di isolamento)  
 8700000 il.bl.cn valve  
 8700101 820010000 920010000 0.003 1. 1. 0000100  
 8700201 1 0. 0. 0.  
 8700300 trpvfv  
 8700301 537  
 \*  
 \* sg ss relief valve for bt17 (non active in bl34)  
 8710000 ss.re.v valve  
 8710101 820010000 872000000 6.5e-5 1. 1. 0000100 0.8 0.8  
 8710201 1 0. 0. 0.  
 8710300 trpvfv  
 8710301 664  
 \*  
 \* sg ss relief tank (non active in bl34)  
 8720000 reL.tank tmdpvov  
 8720101 0. 10. 10. 0. 90. 10. 4.e-5 0. 0000000  
 8720200 2 0  
 8720201 0. 1.e5 0.99  
 \*  
 \*  
 \* bl sg sec side  
 9000000 sg.tu.bl annulus  
 9000001 12  
 9000101 0.0094 10  
 9000102 0.017 12  
 9000301 0.5 6  
 9000302 0.75 10  
 9000303 0.656 11  
 9000304 0.746 12

9000401 0. 12  
 9000601 90. 12  
 9000801 4.e-5 .0122 12  
 9000901 0.12 0.12 11  
 9001001 0000000 12  
 9001101 0000000 11  
 9001201 000 6.9749e6 1235000.8 2.582e6 4.91362e-2 0. 1  
 9001202 000 6.9729e6 1235000.8 2.582e6 9.37175e-2 0. 2  
 9001203 000 6.9709e6 1.255e6 2.582e6 0.13693 0. 3  
 9001204 000 6.9649e6 1.255e6 2.582e6 0.17456 0. 4  
 9001205 000 6.9609e6 1.255e6 2.582e6 0.20618 0. 5  
 9001206 000 6.9549e6 1.255e6 2.582e6 0.23260 0. 6  
 9001207 000 6.9549e6 1.255e6 2.582e6 0.24087 0. 7  
 9001208 000 6.9549e6 1.255e6 2.582e6 0.24694 0. 8  
 9001209 000 6.9549e6 1.255e6 2.582e6 0.24006 0. 9  
 9001210 000 6.9549e6 1.255e6 2.582e6 0.22404 0. 10  
 9001211 000 6.9449e6 1.255e6 2.582e6 0.21991 0. 11  
 9001212 000 6.9489e6 1.255e6 2.582e6 0.21410 0. 12  
 9001300 1  
 9001301 3.24 .0 0. 1  
 9001302 3.24 .0 0. 2  
 9001303 3.24 .0 0. 3  
 9001304 3.14 .1 0. 11  
 \*  
 \*  
 \* bl sg sec side tube out\_ju  
 9050000 sgb.tuou sngljun  
 9050101 900010000 910000000 0. 1. 1. 0000000  
 9050201 1 2.94 .300 0.  
 \*  
 \*  
 \* bl. sg. sec side tube outlet  
 9100000 sgi.tuv pipe  
 9100001 2  
 9100101 .01098 1  
 9100102 .000 2  
 9100301 .450 1  
 9100302 1.164 2  
 9100401 0. 1  
 9100402 0.020 2  
 9100601 90. 2  
 9100801 4.e-5 0. 2  
 9100901 0. 0. 1  
 9101001 0000000 2  
 9101101 0000000 1  
 9101201 0 6.856e6 1435000. 2.582e6 .465 0. 1  
 9101202 0 6.856e6 1435000. 2.582e6 .824 0. 2  
 9101300 1  
 9101301 2.94 0.300 0. 1  
 \*  
 \*  
 \*  
 \* bl sg fine separator  
 9150000 bl.sep separatr  
 9150001 3 1  
 9150101 .05832 .567 0. 0. 90. .567 4.e-5 .0 0000000  
 9150200 0 6.852e6 1435000. 2.582e6 0.99  
 9151101 915010000 920000000 0. .0 .0 0000000 .5  
 9152101 915000000 930000000 0. .0 .0 0000000 .15  
 9153101 910010000 915000000 33.183e-4 0. 0. 0000000  
 9151201 0. 0.72 0.  
 9152201 2.52 0. 0.  
 9153201 2.52 0.72 0.  
 \*  
 \*  
 \*  
 \* bl. sg. ss. up plenum  
 9200000 sgb.upl branch  
 9200001 0 1  
 9200101 .05834 0.5 0. 0. 90. 0.500 4.e-5 0. 0000000  
 9200200 0 6.852e6 1435000. 2.582e6 0.99  
 \*  
 \*  
 \* valve conn bl sg to tmdpvool (p=const.)  
 9230000 bl.sgcx valve  
 9230101 920010000 924000000 5.6e-2 0. 0. 0000100 1. 1.  
 9230201 1 0. 0. 0.  
 9230300 mtrvlv

9230301 604 516 1.5 1.  
 \*  
 \*  
 \* bl sg. const vol  
 9240000 bl.sg.v tmdpvool  
 9240101 0. 1. 10. 0. 90. 1. 4.e-5 0. 0000000  
 9240200 2 0  
 9240201 0. 69.4e5 0.9999  
 \*  
 \*  
 \* sl bl sim tmdpjun  
 9280000 sl.bl.j tmdpjun  
 9280101 920010000 929000000 0.  
 9280200 1 519  
 9280201 -1. 0. 0.064 0.  
 9280202 0. 0. 0.064 0.  
 9280203 1.5 0. 0. 0.  
 9280204 1.e6 0. 0. 0.  
 \*  
 \*  
 \* sl bl sim tmdpvool  
 9290000 sl.bl.v tmdpvool  
 9290101 0. 10. 10. 0. 90. 10. 4.e-5 0. 0000000  
 9290200 0 0  
 9290201 0. 10.e5 7.61e5 2.58e6 1.  
 \*  
 \*  
 \* bl. sg. top.dc  
 9300000 blsg.tdc branch  
 9300001 1 1  
 9300101 .03874 1.164 0. 0. -90. -1.164 4.e-5 .0 0000000  
 9300200 0 6.856e6 1435000. 2.582e6 0.61  
 9301101 930010000 940000000 0. .1 .1 0000000  
 9301201 2.52 0. 0.  
 \*  
 \*  
 \*  
 \* sg bl main feedwater tank  
 9340000 sg.mfwta tmdpvool  
 9340101 0. 10. 10. 0. 0. 0. 4.e-5 0. 0000000  
 9340200 0 0  
 9340201 0. 80.40e5 9.195e5 2.57e6 0.  
 \*  
 \*  
 \* main feedwater  
 9350000 bl.mfw tmdpjun  
 9350101 934000000 940010000 0.  
 9350200 1 607 cntrivar 003  
 9350201 -1.0 0. 0. 0.  
 9350202 1.0 0.4 0. 0.  
 9350203 8.2 0.15 0. 0.  
 9350204 8.48 0.064 0. 0.  
 9350205 9.6 0. 0. 0.  
 9350206 12.0 0. 0. 0.  
 \*  
 \*  
 \* sg bl aux feedwater tank  
 9360000 sg.afwta tmdpvool  
 9360101 0. 10. 10. 0. 0. 0. 4.e-5 0. 0000000  
 9360200 0 0  
 9360201 0. 90.40e5 6.70e5 2.70e6 0. \*check !!  
 \*  
 \*  
 \* aux feedwater  
 9370000 bl.afw tmdpjun  
 9370101 936000000 940010000 0.  
 9370200 1 595  
 9370201 -1.0 0. 0. 0.  
 9370202 0.0 0.030 0. 0.  
 9370203 1.e6 0.030 0. 0.  
 \*  
 \*  
 \* bl sg safety valve  
 9380000 bl.sg.sa valve  
 9380101 920010000 939000000 1.0e-5 9. 9. 0000100  
 9380201 1 0. 0. 0.  
 9380300 trpvlv  
 9380301 561

```

*
*
* bl sg safety tank
9390000 blsgst tndpvol
9390101 0. 10. 10. 0. 90. 10. 4.e-5 0. 0000000
9390200 2 526
9390201 -1. 3.9e5 0.99
9390202 0. 3.9e5 0.99
9390203 1.e6 3.9e5 0.99
*
*
* bl top dc
9400000 bl.t.dc branch
9400001 1 1
9400101 .0387.450 0. 0. -.90. -.450 4.e-5 .0 0000000
9400200 0 6.856e6 1.251e6 2.582e6 0.
9401101 940010000 950000000 0. .0 .0 0000000
9401201 2.4 0. 0.
*
*
* sg bl dc. tube ju. ss
9450000 sg.sg.tu sngljun
9450101 947000000 900000000 0. 55. 55. 0000000
9450201 1 3.24 0. 0.
*
*
* added volume for simulating sgtr break
9470000 sgtrbv branch
9470001 1 1
9470101 .0039.300 0. 0. 0. 0. 0. 4.e-5 0.008 0000000
9470200 0 6.490e6 1228713.5 2.5856e6 0.
9471101 947010000 950010000 0. .0 .0 0000000
9471201 3.2 0. 0.
*
*
* added volume for simulating sgtr break line
9480000 sgtrbpv branch
9480001 1 1
9480101 .0039.300 0. 0. 0. 0. 0. 4.e-5 0.008 0000000
9480200 0 6.490e6 1228713.5 2.5856e6 0.
9481101 948010000 947000000 2.835e-6 0.01 1.01 0000000
9481201 0. 0. 0.
*
*
* sg bl dc
9500000 sg.bl.dc amuhus
9500001 5
9500101 .00398 5
9500301 1.402 1
9500302 1.5 5
9500401 0. 5
9500601 -.90. 5
9500801 4.e-5 .02 5
9500901 0. 0. 4
9501001 0000000 5
9501101 0000000 4
9501201 0 6.8890e6 1.213e6 2.582e6 0. 0. 5
9501300 1
9501301 2.4 0. 0. 4
*
*
* drainage tank during sgtr bl21 transient in sgbl ss (non active in bl34)
9600000 sgtrdrai tndpvol
9600101 0. 10. 10. 0. 0. 0. 4.e-5 0. 0000000
9600200 0 0
9600201 0. 3.50e5 1.200e5 2.60e6 0.5
*
*
* drainage water from sg ss bl during bl21 (non active in bl34)
9650000 sgtrdrj tndpvol
9650101 940010000 960000000 0.
9650200 1 538 cntrivar 003
9650201 -1.0 0. 0. 0.
9650202 8.0 0.0 0. 0.
9650203 8.7 0.0 0. 0.
9650204 9.0 0.2 0. 0.
9650205 9.6 0.4 0. 0.
9650206 12.0 0.4 0. 0.

```

```

*
*
***** structures *****
*
*
* lower plenum bottom
11021000 1 7 1 1 0.
11021100 0 1
11021101 6 0.0158
11021201 1 6
11021301 0. 6
11021400 0
11021401 567. 7
11021501 102010000 0 0 1 0.1529 1
11021601 000000000 0 0 1 0.1529 1
11021701 0 0. 0. 0. 1
11021801 0. 10. 10. 0. 0. 0. 0. 1. 1
*
*
* lower plenum walls
11022000 1 7 2 1 0.156
11022100 0 1
11022101 6 0.1718
11022201 1 6
11022301 0. 6
11022400 0
11022401 567. 7
11022501 102010000 0 0 1 0.274 1
11022601 000000000 0 0 1 0.274 1
11022701 0 0. 0. 0. 1
11022801 0. 10. 10. 0. 0. 0. 0. 1. 1
*
*
* int. low zone stru
11061000 1 7 2 1 0.081
11061100 0 1
11061101 6 0.124
11061201 1 6
11061301 0. 6
11061400 0
11061401 567. 7
11061501 106010000 0 0 1 1.0020 1
11061601 200060000 0 0 1 1.0020 1
11061701 0 0. 0. 0. 1
11061801 0. 10. 10. 0. 0. 0. 0. 1. 1
11061901 0. 10. 10. 0. 0. 0. 0. 1. 1
*
*
* by-dc structure
11082000 4 7 2 1 0.098
11082100 0 1
11082101 6 0.119
11082201 1 6
11082301 0. 6
11082400 0
11082401 585. 7
11082501 000000000 0000 0 1 1.275 1
11082502 000000000 0000 0 1 1.167 2
11082503 000000000 0000 0 1 1.246 3
11082504 000000000 0000 0 1 0.8425 4
11082601 200050000 0000 1 1 1.275 1
11082602 200040000 0000 1 1 1.167 2
11082603 200030000 0000 1 1 1.246 3
11082604 200020000 0000 1 1 0.8425 4
11082701 0 0. 0. 0. 4
11082901 0. 10. 10. 0. 0. 0. 0. 1. 1
11082902 0. 10. 10. 0. 0. 0. 0. 1. 2
11082903 0. 10. 10. 0. 0. 0. 0. 1. 3
11082904 0. 10. 10. 0. 0. 0. 0. 1. 4
*
*
* filler
11083000 9 7 2 1 0.074
11083100 0 1
11083101 6 .099
11083201 2 6
11083301 0. 6
11083400 0

```

11083401 580.7  
 11083501 400010000 0 1 1 .200 1  
 11083502 400020000 0 1 1 .412 2  
 11083503 400030000 0 1 1 .663 3  
 11083504 400040000 0 1 1 .583 4  
 11083505 400050000 0 1 1 .584 5  
 11083506 400060000 0 1 1 .583 6  
 11083507 400070000 0 1 1 .663 7  
 11083508 400080000 0 1 1 .4112 8  
 11083509 400090000 0 1 1 .4305 9  
 11083601 000000000 0 0 1 .200 1  
 11083602 000000000 0 0 1 .412 2  
 11083603 000000000 0 0 1 .663 3  
 11083604 000000000 0 0 1 .583 4  
 11083605 000000000 0 0 1 .584 5  
 11083606 000000000 0 0 1 .583 6  
 11083607 000000000 0 0 1 .663 7  
 11083608 000000000 0 0 1 .4112 8  
 11083609 000000000 0 0 1 .4305 9  
 11083701 0 0. 0. 0. 0. 9  
 11083801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 11083802 0. 10. 10. 0. 0. 0. 0. 1. 2  
 11083803 0. 10. 10. 0. 0. 0. 0. 1. 3  
 11083804 0. 10. 10. 0. 0. 0. 0. 1. 4  
 11083805 0. 10. 10. 0. 0. 0. 0. 1. 5  
 11083806 0. 10. 10. 0. 0. 0. 0. 1. 6  
 11083807 0. 10. 10. 0. 0. 0. 0. 1. 7  
 11083808 0. 10. 10. 0. 0. 0. 0. 1. 8  
 11083809 0. 10. 10. 0. 0. 0. 0. 1. 9  
 \*  
 \*  
 \* vessel wall middle  
 12001000 6 7 2 1 0.156  
 12001100 0 1  
 12001101 6 0.1718  
 12001201 1 6  
 12001301 0. 6  
 12001400 0  
 12001401 567. 7  
 12001501 202010000 0 1 1 0.7945 1  
 12001502 200010000 0 1 1 0.7900 2  
 12001503 200020000 0 1 1 0.8425 3  
 12001504 200030000 0 1 1 1.2460 4  
 12001505 200040000 0 1 1 1.1670 5  
 12001506 200050000 0 1 1 1.2750 6  
 12001601 -999 0 3200 1 0.7945 1  
 12001602 -999 0 3200 1 0.7900 2  
 12001603 -999 0 3200 1 0.8425 3  
 12001604 -999 0 3200 1 1.2460 4  
 12001605 -999 0 3200 1 1.1670 5  
 12001606 -999 0 3200 1 1.2750 6  
 12001701 0 0. 0. 0. 0. 6  
 12001801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 12001802 0. 10. 10. 0. 0. 0. 0. 1. 2  
 12001803 0. 10. 10. 0. 0. 0. 0. 1. 3  
 12001804 0. 10. 10. 0. 0. 0. 0. 1. 4  
 12001805 0. 10. 10. 0. 0. 0. 0. 1. 5  
 12001806 0. 10. 10. 0. 0. 0. 0. 1. 6  
 \*  
 \*  
 \* vessel wall bott  
 12002000 1 7 2 1 0.156  
 12002100 0 1  
 12002101 6 0.191  
 12002201 1 6  
 12002301 0. 6  
 12002400 0  
 12002401 567. 7  
 12002501 200060000 0 1 1 1.0020 1  
 12002601 000000000 0 0 1 1.0020 1  
 12002701 0 0. 0. 0. 0. 1  
 12002801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \* dc.top wall struct.  
 12101000 1 7 2 1 0.156  
 12101100 0 1  
 12101101 6 0.176

12101201 1 6  
 12101301 0. 6  
 12101400 0  
 12101401 567. 7  
 12101501 210010000 0 1 1 0.315 1  
 12101601 000000000 0 0 1 0.315 1  
 12101701 0 0. 0. 0. 0. 1  
 12101801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \* up ple - dc stru  
 14201000 3 7 2 1 0.098  
 14201100 0 1  
 14201101 6 0.119  
 14201201 1 6  
 14201301 0. 6  
 14201400 0  
 14201401 599. 7  
 14201501 410010000 0 1 1.790 1  
 14201502 420010000 0 1 1.7945 2  
 14201503 430010000 0 1 1.315 3  
 14201601 200010000 0 1 1.790 1  
 14201602 202010000 0 1 1.7945 2  
 14201603 210010000 0 1 1.315 3  
 14201701 0 0. 0. 0. 0. 3  
 14201801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 14201802 0. 10. 10. 0. 0. 0. 0. 1. 2  
 14201803 0. 10. 10. 0. 0. 0. 0. 1. 3  
 14201901 0. 10. 10. 0. 0. 0. 0. 1. 1  
 14201902 0. 10. 10. 0. 0. 0. 0. 1. 2  
 14201903 0. 10. 10. 0. 0. 0. 0. 1. 3  
 \*  
 \*  
 \* vessel upper ple. top (modificato per sottrarre 16.3 kw)  
 14301000 1 7 1 1 0.  
 14301100 0 1  
 14301101 6 0.007 \*\* per avere uguale volume  
 14301201 1 6  
 14301301 0. 6  
 14301400 0  
 14301401 599. 7  
 14301501 430010000 0 1 1 3.000 1 \*\* area x 100  
 14301601 -999 0 3430 1 3.000 1 \*\* area x 100  
 14301701 0 0. 0. 0. 0. 1  
 14301801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \* uh. lo conn. struct  
 14401000 1 6 2 1 .016  
 14401100 0 1  
 14401101 5 .0225  
 14401201 1 5  
 14401301 0. 5  
 14401400 0  
 14401401 597. 6  
 14401501 440010000 0 1 1 .655 1  
 14401601 0 0 0 1 .655 1  
 14401701 0 0. 0. 0. 0. 1  
 14401801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \*  
 \* uh.by stru  
 14501000 1 6 2 1 .00475  
 14501100 0 1  
 14501101 5 .00675  
 14501201 1 5  
 14501301 0. 5  
 14501400 0  
 14501401 597. 6  
 14501501 450010000 0 1 1 1.814 1  
 14501601 0 0 0 1 1.814 1  
 14501701 0 0. 0. 0. 0. 1  
 14501801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \*  
 \* up head stru  
 14601000 3 7 2 1 .06  
 14601100 0 1

14601101 6.08  
 14601201 1 6  
 14601301 0. 6  
 14601400 0  
 14601401 597. 7  
 14601501 455010000 5000000 1 1.850 2  
 14601502 460020000 0 1 1.866 3  
 14601601 0 0 0 1.850 2  
 14601602 0 0 0 1.866 3  
 14601701 0 0. 0. 0. 3  
 14601801 0. 10. 10. 0. 0. 0. 0. 1. 2  
 14601802 0. 10. 10. 0. 0. 0. 0. 1. 3  
 \*  
 \*  
 \*uh.up. conn stru  
 14701000 1 7 2 1.00475  
 14701100 0 1  
 14701101 6.00675  
 14701201 1 6  
 14701301 0. 6  
 14701400 0  
 14701401 597. 7  
 14701501 470010000 0 1 1 2.6660 1  
 14701601 000000000 0 0 1 2.6660 1  
 14701701 0 0. 0. 0. 1  
 14701801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \*il hl vessel connection stru  
 15001000 1 7 2 1 0.03685  
 15001100 0 1  
 15001101 6 0.05385  
 15001201 3 6  
 15001301 0. 6  
 15001400 0  
 15001401 599. 7  
 15001501 500010000 0 1 1 0.906 1  
 15001601 -999 0 3500 1 0.906 1  
 15001701 0 0. 0. 0. 1  
 15001801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \*il hl pip stru  
 15101000 3 7 2 1 0.03685  
 15101100 0 1  
 15101101 6 0.04445  
 15101201 3 6  
 15101301 0. 6  
 15101400 0  
 15101401 599. 7  
 15101501 510010000 1000000 1 1 0.673 3  
 15101601 0 0 0 1 0.673 3  
 15101701 0 0. 0. 0. 3  
 15101801 0. 10. 10. 0. 0. 0. 0. 1. 3  
 \*  
 \*  
 \*surgeline prez struct.  
 15201000 2 7 2 1 0.0066  
 15201100 0 1  
 15201101 6 0.0086  
 15201201 3 6  
 15201301 0. 6  
 15201400 0  
 15201401 599. 7  
 15201501 520020000 0 1 1 3.600 1  
 15201502 520030000 0 1 1 2.800 2  
 15201601 0 0 0 1 3.600 1  
 15201602 0 0 0 1 2.800 2  
 15201701 0 0. 0. 0. 2  
 15201801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 15201802 0. 10. 10. 0. 0. 0. 0. 1. 2  
 \*  
 \*  
 \*prez structure lower part plate  
 15301000 1 7 1 1 0.  
 15301100 0 1  
 15301101 6 0.06  
 15301201 3 6

15301301 0. 6  
 15301400 0  
 15301401 619. 7  
 15301501 530010000 0 1 1 0.0097 1  
 15301601 0 0 0 1 0.0097 1  
 15301701 0 0. 0. 0. 1  
 15301801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \*prez stru lower part. cyl  
 15302000 1 7 2 1 0.05550  
 15302100 0 1  
 15302101 6 0.07770  
 15302201 3 6  
 15302301 0. 6  
 15302400 0  
 15302401 619. 7  
 15302501 530010000 0 1 1 0.790 1  
 15302601 0 0 0 1 0.790 1  
 15302701 0 0. 0. 0. 1  
 15302801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \*prez heaters  
 15303000 2 7 2 1 0.01  
 15303100 0 1  
 15303101 6 0.0125  
 15303201 4 6  
 15303301 1. 6  
 15303400 0  
 15303401 619. 7  
 15303501 000000000 0 0 1 6.320 1  
 15303502 000000000 0 0 1 6.848 2  
 15303601 530010000 0 1 1 6.320 1  
 15303602 535010000 0 1 1 6.848 2  
 15303701 950 1. 0. 0. 1  
 15303702 0 0. 0. 0. 2  
 15303901 0. 10. 10. 0. 0. 0. 0. 1. 1  
 15303902 0. 10. 10. 0. 0. 0. 0. 1. 2  
 \*  
 \*  
 \*prez structures (middle)  
 15351000 4 7 2 1.06220  
 15351100 0 1  
 15351101 6 0.08  
 15351201 3 6  
 15351301 0. 6  
 15351400 0  
 15351401 619. 7  
 15351501 535010000 0 1 1 0.630 1  
 15351502 535020000 0 1 1 1.120 2  
 15351503 535030000 10000 1 1 1.500 4  
 15351601 -999 0 3535 1 0.630 1  
 15351602 -999 0 3535 1 1.120 2  
 15351603 -999 0 3535 1 1.500 3  
 15351604 -999 0 3535 1 1.500 4  
 15351701 0 0. 0. 0. 4  
 15351801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 15351802 0. 10. 10. 0. 0. 0. 0. 1. 2  
 15351803 0. 10. 10. 0. 0. 0. 0. 1. 4  
 \*  
 \*  
 \*prez structures (top)  
 15401000 2 7 2 1.06220  
 15401100 0 1  
 15401101 6 0.08  
 15401201 3 6  
 15401301 0. 6  
 15401400 0  
 15401401 619. 7  
 15401501 540010000 0 1 1 1.0400 1  
 15401502 539010000 0 1 1 1.0000 2  
 15401601 -998 0 3535 1 1.0400 1  
 15401602 -998 0 3535 1 1.0000 2  
 15401701 0 0. 0. 0. 2  
 15401801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 15401802 0. 10. 10. 0. 0. 0. 0. 1. 2  
 \*

\*  
 \* il hl sg conn stru  
 15501000 1 7 2 1 0.03685  
 15501100 0 1  
 15501101 6 0.05385  
 15501201 3 6  
 15501301 0. 6  
 15501400 0  
 15501401 599. 7  
 15501501 550010000 0 1 1 0.8280 1  
 15501601 0 0 0 1 0.8280 1  
 15501701 0 0. 0. 0. 1  
 15501801 0. 10. 10. 0. 0. 0. 1. 1  
 \*  
 \*  
 \* il hl sg inl stru  
 15601000 3 7 2 1 0.05885  
 15601100 0 1  
 15601101 6 0.06985  
 15601201 3 6  
 15601301 0. 6  
 15601400 0  
 15601401 599. 7  
 15601501 560010000 10000 1 1 0.574 3  
 15601601 -999 0 3560 1 0.574 3  
 15601701 0 0. 0. 0. 3  
 15601801 0. 10. 10. 0. 0. 0. 1. 3  
 \*  
 \*  
 \* il sg lp stru  
 15651000 2 7 1 1 0.  
 15651100 0 1  
 15651101 6 0.03  
 15651201 3 6  
 15651301 0. 6  
 15651400 0  
 15651401 599. 7  
 15651501 565010000 10000000 1 1 0.0656 2  
 15651601 0 0 0 1 0.0656 2  
 15651701 0 0. 0. 0. 2  
 15651801 0. 10. 10. 0. 0. 0. 1. 2  
 \*  
 \*  
 \* il sg lp str2  
 15652000 2 7 2 1 0.156  
 15652100 0 1  
 15652101 6 0.235  
 15652201 3 6  
 15652301 0. 6  
 15652400 0  
 15652401 567. 7  
 15652501 565010000 10000000 1 1 0.0910 2  
 15652601 0 0 0 1 0.0910 2  
 15652701 0 0. 0. 0. 2  
 15652801 0. 10. 10. 0. 0. 0. 1. 2  
 \*  
 \*  
 \* il sg plat stru  
 15653000 2 7 1 1 0.  
 15653100 0 1  
 15653101 6 0.090  
 15653201 3 6  
 15653301 0. 6  
 15653400 0  
 15653401 580. 7  
 15653501 565010000 10000000 1 1 0.0379 2  
 15653601 0 0 0 1 0.0379 2  
 15653701 0 0. 0. 0. 2  
 15653801 0. 10. 10. 0. 0. 0. 1. 2  
 \*  
 \*  
 \* il sg lp subd. pla stru  
 15654000 1 7 1 1 0.  
 15654100 0 1  
 15654101 6 0.025  
 15654201 3 6  
 15654301 0. 6  
 15654400 0

15654401 599. 5  
 15654402 567. 7  
 15654501 565010000 0 1 1 0.0666 1  
 15654601 575010000 0 1 1 0.0666 1  
 15654701 0 0. 0. 0. 1  
 15654801 0. 10. 10. 0. 0. 0. 1. 1  
 15654901 0. 10. 10. 0. 0. 0. 1. 1  
 \*  
 \*  
 \* il sg tubes stru  
 15701000 2 4 7 2 1 0.0098  
 15701100 0 1  
 15701101 6 0.011  
 15701201 3 6  
 15701301 0. 6  
 15701400 0  
 15701401 596. 6  
 15701402 543. 7  
 15701501 570010000 10000 1 1 12.000 6  
 15701502 570070000 10000 1 1 18.000 10  
 15701503 570110000 10000 1 1 15.744 14  
 15701504 570150000 10000 1 1 18.000 18  
 15701505 570190000 10000 1 1 12.000 24  
 15701601 800010000 10000 1 1 12.000 6  
 15701602 800070000 10000 1 1 18.000 10  
 15701603 800110000 10000 1 1 15.744 12  
 15701604 800120000 -10000 1 1 15.744 14  
 15701605 800100000 -10000 1 1 18.000 18  
 15701606 800060000 -10000 1 1 12.000 24  
 15701701 0 0. 0. 0. 24  
 15701801 0. 10. 10. 0. 0. 0. 1. 24  
 15701901 0. 10. 10. 0. 0. 0. 1. 24  
 \*  
 \*  
 \* sg il outlet  
 15801000 3 7 2 1 0.05885  
 15801100 0 1  
 15801101 6 0.06985  
 15801201 3 6  
 15801301 0. 6  
 15801400 0  
 15801401 567. 6  
 15801402 567. 7  
 15801501 580010000 10000 1 1 0.574 3  
 15801601 -999 0 3580 1 0.574 3  
 15801701 0 0. 0. 0. 3  
 15801801 0. 10. 10. 0. 0. 0. 1. 3  
 \*  
 \*  
 \* sg ins n.13 il cl stru  
 15851000 1 7 2 1 0.03685  
 15851100 0 1  
 15851101 6 0.0517  
 15851201 3 6  
 15851301 0. 6  
 15851400 0  
 15851401 567. 6  
 15851402 567. 7  
 15851501 585010000 0 1 1 0.828 1  
 15851601 000000000 0 0 1 0.828 1  
 15851701 0 0. 0. 0. 1  
 15851801 0. 10. 10. 0. 0. 0. 1. 1  
 \*  
 \*  
 \* il loop seal struct  
 15901000 6 7 2 1 0.03685  
 15901100 0 1  
 15901101 6 0.04445  
 15901201 3 6  
 15901301 0. 6  
 15901400 0  
 15901401 567. 6  
 15901402 567. 7  
 15901501 590010000 0 1 1 950 1  
 15901502 590020000 0 1 1 0.7825 2  
 15901503 590030000 0 1 1 0.7825 3  
 15901504 590040000 0 1 1 0.855 4  
 15901505 590050000 0 1 1 0.7825 5



15901506 590060000 0 1 1 0.7825 6  
 15901601 000000000 0 0 1 0.950 1  
 15901602 000000000 0 0 1 0.7825 2  
 15901603 000000000 0 0 1 0.7825 3  
 15901604 000000000 0 0 1 0.855 4  
 15901605 000000000 0 0 1 0.7825 5  
 15901606 000000000 0 0 1 0.7825 6  
 15901701 0 0. 0. 0. 6  
 15901801 0. 10. 10. 0. 0. 0. 0. 1. 6  
 \*  
 \*  
 \* bl cl pump inl ins. n. 14 stru  
 15951000 1 7 2 1 0.03685  
 15951100 0 1  
 15951101 6 0.05385  
 15951201 3 6  
 15951301 0. 6  
 15951400 0  
 15951401 567. 7  
 15951501 595010000 0 1 1 0.750 1  
 15951601 -999 0 3595 1 0.750 1  
 15951701 0 0. 0. 0. 1  
 15951801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \* il pump stru  
 16001000 1 7 2 1 0.03685  
 16001100 0 1  
 16001101 6 0.13685  
 16001201 3 6  
 16001301 0. 6  
 16001400 0  
 16001401 567. 7  
 16001501 600010000 0 1 1 0.200 1  
 16001601 -999 0 3600 1 0.200 1  
 16001701 0 0. 0. 0. 1  
 16001801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \* il cl pump ou stru.  
 16051000 1 7 2 1 0.03685  
 16051100 0 1  
 16051101 6 0.05385  
 16051201 3 6  
 16051301 0. 6  
 16051400 0  
 16051401 567. 7  
 16051501 605010000 0 1 1 0.035 1  
 16051601 -999 0 3605 1 0.035 1  
 16051701 0 0. 0. 0. 1  
 16051801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \* il cl stru.  
 16101000 4 7 2 1 0.03685  
 16101100 0 1  
 16101101 6 0.04445  
 16101201 3 6  
 16101301 0. 6  
 16101400 0  
 16101401 567. 7  
 16101501 610010000 10000 1 1 0.65625 4  
 16101601 0 0 0 1 0.65625 4  
 16101701 0 0. 0. 0. 4  
 16101801 0. 10. 10. 0. 0. 0. 0. 1. 4  
 \*  
 \*  
 \* il cl vessel inlet stru.  
 16121000 1 7 2 1 0.03685  
 16121100 0 1  
 16121101 6 0.05385  
 16121201 3 6  
 16121301 0. 6  
 16121400 0  
 16121401 567. 7  
 16121501 612010000 0 1 1 0.670 1  
 16121601 -999 0 3612 1 0.670 1  
 16121701 0 0. 0. 0. 1

16121801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \* bl hl vess comm stru.  
 17001000 1 7 2 1 0.023  
 17001100 0 1  
 17001101 6 0.04  
 17001201 3 6  
 17001301 0. 6  
 17001400 0  
 17001401 599. 7  
 17001501 700010000 0 1 1 0.500 1  
 17001601 -999 0 3700 1 0.500 1  
 17001701 0 0. 0. 0. 1  
 17001801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \* bl hl stru  
 17051000 4 7 2 1 0.023  
 17051100 0 1  
 17051101 6 0.03  
 17051201 3 6  
 17051301 0. 6  
 17051400 0  
 17051401 599. 7  
 17051501 705010000 10000 1 1 0.563 3  
 17051502 702010000 10000 1 1 0.563 4  
 17051601 0 0 0 1 0.563 4  
 17051701 0 0. 0. 0. 4  
 17051801 0. 10. 10. 0. 0. 0. 0. 1. 4  
 \*  
 \*  
 \* bl hl meas. ins  
 17101000 4 7 2 1 0.023  
 17101100 0 1  
 17101101 6 0.035  
 17101201 3 6  
 17101301 0. 6  
 17101400 0  
 17101401 599. 7  
 17101501 710010000 0 1 1 0.842 1  
 17101502 712010000 10000 1 1 0.639 4  
 17101601 0 0 0 1 0.842 1  
 17101602 -999 0 3710 1 0.639 4  
 17101701 0 0. 0. 0. 4  
 17101801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 17101802 0. 10. 10. 0. 0. 0. 0. 1. 4  
 \*  
 \*  
 \* bl sg in lo. plate struc  
 17181000 2 7 1 1 0.  
 17181100 0 1  
 17181101 6 0.018  
 17181201 3 6  
 17181301 0. 6  
 17181400 -1  
 17181401 599. 599. 599. 599. 599. 599. 599.  
 17181402 568. 568. 568. 568. 568. 568. 568.  
 17181501 718010000 4000000 1 1 0.029 2  
 17181601 0 0 0 1 0.029 2  
 17181701 0 0. 0. 0. 2  
 17181801 0. 10. 10. 0. 0. 0. 0. 1. 2  
 \*  
 \*  
 \* bl sg in lo. cyl  
 17182000 2 7 2 1 0.102  
 17182100 0 1  
 17182101 6 0.122  
 17182201 3 6  
 17182301 0. 6  
 17182400 -1  
 17182401 599. 599. 599. 599. 599. 599. 599.  
 17182402 568. 568. 568. 568. 568. 568. 568.  
 17182501 718010000 4000000 1 1 0.1105 2  
 17182601 0 0 0 1 0.1105 2  
 17182701 0 0. 0. 0. 2  
 17182801 0. 10. 10. 0. 0. 0. 0. 1. 2  
 \*

\*  
 \* bl sg conn plate  
 17183000 1 7 1 1 0.  
 17183100 0 1  
 17183101 6 0.122  
 17183201 3 6  
 17183301 0. 6  
 17183400 -1  
 17183401 599. 589. 585. 580. 575. 574. 574.  
 17183501 718010000 0 1 1 0.0284 1  
 17183601 722010000 0 1 1 0.0284 1  
 17183701 0 0. 0. 0. 1  
 17183801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 17183901 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \* bl sg tube plate structure  
 17184000 2 7 1 1 0.  
 17184100 0 1  
 17184101 6 0.06  
 17184201 3 6  
 17184301 0. 6  
 17184400 -1  
 17184401 599. 599. 599. 599. 599. 599. 599.  
 17184402 568. 568. 568. 568. 568. 568. 568.  
 17184501 718010000 4000000 1 1 0.0163 2  
 17184601 0 0 0 1 0.0163 2  
 17184701 0 0. 0. 0. 2  
 17184801 0. 10. 10. 0. 0. 0. 0. 1. 2  
 \*  
 \*  
 \* bl sg tubes stru 1  
 17201000 24 7 2 1 0.0098  
 17201100 0 1  
 17201101 6 0.011  
 17201201 3 6  
 17201301 0. 6  
 17201400 0  
 17201401 596. 6  
 17201402 543. 7  
 17201501 720010000 10000 1 1 4.00 6  
 17201502 720070000 10000 1 1 6.00 10  
 17201503 720110000 10000 1 1 5.248 14  
 17201504 720150000 10000 1 1 6.00 18  
 17201505 720190000 10000 1 1 4.00 24  
 17201601 900010000 10000 1 1 4.00 6  
 17201602 900070000 10000 1 1 6.00 10  
 17201603 900110000 10000 1 1 5.248 12  
 17201604 900120000 -10000 1 1 5.248 14  
 17201605 900100000 -10000 1 1 6.00 18  
 17201606 900060000 -10000 1 1 4.00 24  
 17201701 0 0. 0. 0. 24  
 17201801 0. 10. 10. 0. 0. 0. 0. 1. 24  
 17201901 0. 10. 10. 0. 0. 0. 0. 1. 24  
 \*  
 \*  
 \* bl hl sg exit  
 17251000 3 7 2 1 0.0342  
 17251100 0 1  
 17251101 6 0.0413  
 17251201 3 6  
 17251301 0. 6  
 17251400 0  
 17251401 569. 7  
 17251501 725010000 10000 1 1 0.639 3  
 17251601 -999 0 3725 1 0.639 3  
 17251701 0 0. 0. 0. 3  
 17251801 0. 10. 10. 0. 0. 0. 0. 1. 3  
 \*  
 \*  
 \* bl loop seal  
 17301000 6 7 2 1 0.023  
 17301100 0 1  
 17301101 6 0.031  
 17301201 3 6  
 17301301 0. 6  
 17301400 0  
 17301401 569. 7

17301501 730010000 0 1 1 1.042 1  
 17301502 730020000 0 1 1 1.151 2  
 17301503 730030000 0 1 1 0.701 3  
 17301504 730040000 0 1 1 0.884 4  
 17301505 730050000 0 1 1 .701 5  
 17301506 730060000 0 1 1 1.151 6  
 17301601 0 0 0 1 1.042 1  
 17301602 0 0 0 1 1.151 2  
 17301603 0 0 0 1 0.701 3  
 17301604 0 0 0 1 0.884 4  
 17301605 0 0 0 1 .701 5  
 17301606 -999 0 3730 1 1.151 6  
 17301701 0 0. 0. 0. 6  
 17301801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 17301802 0. 10. 10. 0. 0. 0. 0. 1. 2  
 17301803 0. 10. 10. 0. 0. 0. 0. 1. 3  
 17301804 0. 10. 10. 0. 0. 0. 0. 1. 4  
 17301805 0. 10. 10. 0. 0. 0. 0. 1. 5  
 17301806 0. 10. 10. 0. 0. 0. 0. 1. 6  
 \*  
 \*  
 \* bl pump stru  
 17401000 1 7 2 1 0.03685  
 17401100 0 1  
 17401101 6 0.13685  
 17401201 3 6  
 17401301 0. 6  
 17401400 0  
 17401401 567. 7  
 17401501 740010000 0 1 1 0.200 1  
 17401601 -999 0 3740 1 0.200 1  
 17401701 0 0. 0. 0. 1  
 17401801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \* bl pump exit stru  
 17451000 1 7 2 1 0.023  
 17451100 0 1  
 17451101 6 0.05  
 17451201 3 6  
 17451301 0. 6  
 17451400 0  
 17451401 567. 7  
 17451501 745010000 0 1 1 0.503 1  
 17451601 -999 0 3745 1 0.503 1  
 17451701 0 0. 0. 0. 1  
 17451801 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \* bl break upstream volume  
 17501000 5 7 2 1 0.023  
 17501100 0 1  
 17501101 6 0.04  
 17501201 3 6  
 17501301 0. 6  
 17501400 0  
 17501401 569. 7  
 17501501 750010000 10000 1 1 0.369 5  
 17501601 0 0 0 1 0.369 5  
 17501701 0 0. 0. 0. 5  
 17501801 0. 10. 10. 0. 0. 0. 0. 1. 5  
 \*  
 \*  
 \* bl break downstream structure  
 17701000 4 7 2 1 0.023  
 17701100 0 1  
 17701101 6 0.033  
 17701201 3 6  
 17701301 0. 6  
 17701400 0  
 17701401 567. 7  
 17701501 770010000 2000000 1 1 0.5072 4  
 17701601 -999 0 3770 1 0.5072 4  
 17701701 0 0. 0. 0. 4  
 17701801 0. 10. 10. 0. 0. 0. 0. 1. 4  
 \*  
 \*  
 \* sg il filler shell s.s. stru

18000000 12 7 2 1 0.076  
 18000100 0 1  
 18000101 6.08415  
 18000201 3 6  
 18000301 0.6  
 18000400 0  
 18000401 553.7  
 18000501 800010000 10000 1 1 0.5 6  
 18000502 800070000 10000 1 1 0.75 10  
 18000503 800110000 0 1 1 0.656 11  
 18000504 800120000 0 1 1 0.746 12  
 18000601 0 0 0 1 0.5 6  
 18000602 0 0 0 1 0.75 10  
 18000603 0 0 0 1 0.656 11  
 18000604 0 0 0 1 0.746 12  
 18000701 0 0.0.0.0.12  
 18000801 0.10.10.0.0.0.0.1.12  
 \*  
 \*  
 \* sg il dc shell stru (bot)  
 18001000 12 7 2 1.15  
 18001100 0 1  
 18001101 6.152  
 18001201 3 6  
 18001301 0.6  
 18001400 0  
 18001401 543.7  
 18001501 800010000 10000 1 1 0.5 6  
 18001502 800070000 10000 1 1 0.75 10  
 18001503 800110000 0 1 1 0.656 11  
 18001504 800120000 0 1 1 0.746 12  
 18001601 850050000 0 1 1 0.5 3  
 18001602 850040000 0 1 1 0.5 6  
 18001603 850030000 0 1 1 0.75 8  
 18001604 850020000 0 1 1 0.75 10  
 18001605 850010000 0 1 1 0.656 11  
 18001606 850010000 0 1 1 0.746 12  
 18001701 0 0.0.0.0.12  
 18001801 0.10.10.0.0.0.0.1.12  
 18001901 0.10.10.0.0.0.0.1.12  
 \*  
 \*  
 \* sg il dc shell stru (top)  
 18101000 1 7 2 1.15  
 18101100 0 1  
 18101101 6.152  
 18101201 3 6  
 18101301 0.6  
 18101400 0  
 18101401 543.7  
 18101501 810010000 0 1 1 .645 1  
 18101601 840010000 0 1 1 .645 1  
 18101701 0 0.0.0.0.1  
 18101801 0.10.10.0.0.0.0.1.1  
 18101901 0.10.10.0.0.0.0.1.1  
 \*  
 \*  
 \* sg il dc shell stru (sep)  
 18102000 1 7 2 1.15  
 18102100 0 1  
 18102101 6.152  
 18102201 3 6  
 18102301 0.6  
 18102400 0  
 18102401 543.7  
 18102501 810020000 0 1 1 .946 1  
 18102601 830010000 0 1 1 .946 1  
 18102701 0 0.0.0.0.1  
 18102801 0.10.10.0.0.0.0.1.1  
 18102901 0.10.10.0.0.0.0.1.1  
 \*  
 \*  
 \* il sg top pla stru  
 18200000 1 7 1 1 0.  
 18200100 0 1  
 18200101 6.032  
 18200201 3 6  
 18200301 0.6

18200400 0  
 18200401 554.3 7  
 18200501 820010000 0 1 1 .217 1  
 18200601 0 0 0 1 .217 1  
 18200701 0 0.0.0.0.1  
 18200801 0.10.10.0.0.0.0.1.1  
 \*  
 \*  
 \* sg il vessel stru (top)  
 18201000 2 7 2 1.1645  
 18201100 0 1  
 18201101 6.1915  
 18201201 3 6  
 18201301 0.6  
 18201400 0  
 18201401 543.7  
 18201501 815010000 0 1 1 .791 1  
 18201502 820010000 0 1 1 .424 2  
 18201601 0 0 0 1 .791 1  
 18201602 0 0 0 1 .424 2  
 18201701 0 0.0.0.0.2  
 18201801 0.10.10.0.0.0.0.1.1  
 18201802 0.10.10.0.0.0.0.1.2  
 \*  
 \*  
 \* sg il vessel stru (mid)  
 18301000 1 7 2 1.1645  
 18301100 0 1  
 18301101 6.1915  
 18301201 3 6  
 18301301 0.6  
 18301400 0  
 18301401 543.7  
 18301501 830010000 0 1 1 .946 1  
 18301601 0 0 0 1 .946 1  
 18301701 0 0.0.0.0.1  
 18301801 0.10.10.0.0.0.0.1.1  
 \*  
 \*  
 \* sg il vessel stru (mid)  
 18401000 1 7 2 1.1645  
 18401100 0 1  
 18401101 6.1915  
 18401201 3 6  
 18401301 0.6  
 18401400 0  
 18401401 533.7  
 18401501 840010000 0 1 1 .645 1  
 18401601 0 0 0 1 .645 1  
 18401701 0 0.0.0.0.1  
 18401801 0.10.10.0.0.0.0.1.1  
 \*  
 \*  
 \* sg il vess stru (bot)  
 18500000 5 7 2 1.1645  
 18500100 0 1  
 18500101 6.1915  
 18500201 3 6  
 18500301 0.6  
 18500400 0  
 18500401 533.7  
 18500501 850010000 0 1 1 1.402 1  
 18500502 850020000 10000 1 1 1.500 5  
 18500601 -999 0 3780 1 1.402 1  
 18500602 -999 0 3780 1 1.500 5  
 18500701 0 0.0.0.0.5  
 18500801 0.10.10.0.0.0.0.1.1  
 18500802 0.10.10.0.0.0.0.1.5  
 \*  
 \*  
 \* sg bl filler shell s.s. stru  
 19000000 12 7 2 1 0.0629  
 19000100 0 1  
 19000101 6.070  
 19000201 3 6  
 19000301 0.6  
 19000400 0  
 19000401 553.7

```

19000501 900010000 10000 1 1 0.5 6
19000502 900070000 10000 1 1 0.75 10
19000503 900110000 0 1 1 0.656 11
19000504 900120000 0 1 1 0.746 12
19000601 0 0 0 1 0.5 6
19000602 0 0 0 1 0.75 10
19000603 0 0 0 1 0.656 11
19000604 0 0 0 1 0.746 12
19000701 0 0. 0. 0. 12
19000801 0. 10. 10. 0. 0. 0. 1. 12
*
*
* sg bl dc shell stru (bot)
19001000 12 7 2 1.1005
19001100 0 1
19001101 6.102
19001201 3 6
19001301 0. 6
19001400 0
19001401 543. 7
19001501 900010000 10000 1 1 0.5 6
19001502 900070000 10000 1 1 0.75 10
19001503 900110000 0 1 1 0.656 11
19001504 900120000 0 1 1 0.746 12
19001601 950050000 0 1 1 0.5 3
19001602 950040000 0 1 1 0.5 6
19001603 950030000 0 1 1 0.75 8
19001604 950020000 0 1 1 0.75 10
19001605 950010000 0 1 1 0.656 11
19001606 950010000 0 1 1 0.746 12
19001701 0 0. 0. 0. 12
19001801 0. 10. 10. 0. 0. 0. 0. 1. 12
19001901 0. 10. 10. 0. 0. 0. 0. 1. 12
*
*
* sg bl dc shell stru (top) **?
19101000 1 7 2 1.1005
19101100 0 1
19101101 6.102
19101201 3 6
19101301 0. 6
19101400 0
19101401 543. 7
19101501 910010000 0 1 1 .450 1
19101601 940010000 0 1 1 .450 1
19101701 0 0. 0. 0. 1
19101801 0. 10. 10. 0. 0. 0. 0. 1. 1
19101901 0. 10. 10. 0. 0. 0. 0. 1. 1
*
*
* sg bl dc shell stru (sep) **?
19102000 1 7 2 1.1005
19102100 0 1
19102101 6.102
19102201 3 6
19102301 0. 6
19102400 0
19102401 543. 7
19102501 910020000 0 1 1 1.164 1
19102601 930010000 0 1 1 1.164 1
19102701 0 0. 0. 0. 1
19102801 0. 10. 10. 0. 0. 0. 0. 1. 1
19102901 0. 10. 10. 0. 0. 0. 0. 1. 1
*
*
* bl sg top pla stru **?
19200000 1 7 1 1 0.
19200100 0 1
19200101 6.020
19200201 3 6
19200301 0. 6
19200400 0
19200401 554. 7
19200501 920010000 0 1 1 .217 1
19200601 0 0 1 .217 1
19200701 0 0. 0. 0. 1
19200801 0. 10. 10. 0. 0. 0. 0. 1. 1
*

```

```

*
* sg bl vessel stru (top)
19201000 2 7 2 1.135
19201100 0 1
19201101 6.152
19201201 3 6
19201301 0. 6
19201400 0
19201401 544. 7
19201501 915010000 0 1 1 .567 1
19201502 920010000 0 1 1 .500 2
19201601 000000000 0 0 1 .567 1
19201602 000000000 0 0 1 .500 2
19201701 0 0. 0. 0. 2
19201801 0. 10. 10. 0. 0. 0. 0. 1. 1
19201802 0. 10. 10. 0. 0. 0. 0. 1. 2
*
*
* sg bl dc shell stru (mid)
19301000 1 7 2 1.1195
19301100 0 1
19301101 6.1345
19301201 3 6
19301301 0. 6
19301400 0
19301401 533. 7
19301501 930010000 0 1 1 1.164 1
19301601 000000000 0 0 1 1.164 1
19301701 0 0. 0. 0. 1
19301801 0. 10. 10. 0. 0. 0. 0. 1. 1
*
*
* sg bl vessel stru (mid)
19401000 1 7 2 1.1195
19401100 0 1
19401101 6.1345
19401201 3 6
19401301 0. 6
19401400 0
19401401 533. 7
19401501 940010000 0 1 1 .450 1
19401601 000000000 0 0 1 .450 1
19401701 0 0. 0. 0. 1
19401801 0. 10. 10. 0. 0. 0. 0. 1. 1
*
*
* sg bl vess stru (bot)
19500000 5 7 2 1.108
19500100 0 1
19500101 6.122
19500201 3 6
19500301 0. 6
19500400 0
19500401 533. 7
19500501 950010000 0 1 1 1.304 1
19500502 950020000 10000 1 1 1.500 5
19500601 -999 0 3790 1 1.304 1
19500602 -999 0 3790 1 1.500 5
19500701 0 0. 0. 0. 5
19500801 0. 10. 10. 0. 0. 0. 0. 1. 1
19500802 0. 10. 10. 0. 0. 0. 0. 1. 5
*
*
* core structure lower conn. 1
19920000 1 20 2 1 0.
19920100 0 1
19920101 19 0.0045
19920201 4 19
19920301 1. 19
19920400 0
19920401 587. 20
19920501 0 0 0 1 21.120 1
19920601 106010000 0 1 1 21.120 1
19920701 900 0.047 0. 0. 1
19920901 0. 10. 10. 0. 0. 0. 0. 1. 1
*
*
* core structure lower conn. 2

```

19930000 1 20 2 1 0.  
 19930100 0 1  
 19930101 19 0.005375  
 19930201 4 19  
 19930301 1. 19  
 19930400 0  
 19930401 589. 20  
 19930501 0 0 0 1 12.800 1  
 19930601 400010000 0 1 1 12.800 1  
 19930701 900 0.005 0. 0. 1  
 19930901 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \* core active zone structure 1  
 19940000 1 15 2 1 0.003225  
 19940100 0 1  
 19940101 14 0.005375  
 19940201 5 14  
 19940301 1. 14  
 19940400 0  
 19940401 595. 15  
 19940501 0 0 0 1 26.368 1  
 19940601 400020000 0 1 1 26.368 1  
 19940701 900 .065 0. 0. 1  
 19940901 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \* core active zone structure 2  
 19950000 1 15 2 1 0.003875  
 19950100 0 1  
 19950101 14 0.005375  
 19950201 5 14  
 19950301 1. 14  
 19950400 0  
 19950401 598. 15  
 19950501 0 0 0 1 42.432 1  
 19950601 400030000 0 1 1 42.432 1  
 19950701 900 0.140 0. 0. 1  
 19950901 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \* core active zone structure 3  
 19960000 1 15 2 1 0.004175  
 19960100 0 1  
 19960101 14 0.005375  
 19960201 5 14  
 19960301 1. 14  
 19960400 0  
 19960401 603. 15  
 19960501 0 0 0 1 37.312 1  
 19960601 400040000 0 1 1 37.312 1  
 19960701 900 0.1502 0. 0. 1  
 19960901 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \* core active zone structure 4  
 19970000 1 15 2 1 0.004175  
 19970100 0 1  
 19970101 14 0.005375  
 19970201 5 14  
 19970301 1. 14  
 19970400 0  
 19970401 603. 15  
 19970501 0 0 0 1 37.376 1  
 19970601 400050000 0 1 1 37.376 1  
 19970701 900 0.1506 0. 0. 1  
 19970901 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \* core active zone structure 5  
 19980000 1 15 2 1 0.004175  
 19980100 0 1  
 19980101 14 0.005375  
 19980201 5 14  
 19980301 1. 14  
 19980400 0  
 19980401 603. 15  
 19980501 0 0 0 1 37.312 1

19980601 400060000 0 1 1 37.312 1  
 19980701 900 0.1502 0. 0. 1  
 19980901 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \* core active zone structure 6  
 19990000 1 15 2 1 0.003875  
 19990100 0 1  
 19990101 14 0.005375  
 19990201 5 14  
 19990301 1. 14  
 19990400 0  
 19990401 610. 15  
 19990501 0 0 0 1 42.432 1  
 19990601 400070000 0 1 1 42.432 1  
 19990701 900 0.1420 0. 0. 1  
 19990901 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \* core active zone structure 7  
 19991000 1 15 2 1 0.003225  
 19991100 0 1  
 19991101 14 0.005375  
 19991201 5 14  
 19991301 1. 14  
 19991400 0  
 19991401 613. 15  
 19991501 0 0 0 1 26.368 1  
 19991601 400080000 0 1 1 26.368 1  
 19991701 900 0.0660 0. 0. 1  
 19991901 0. 10. 10. 0. 0. 0. 0. 1. 1  
 \*  
 \*  
 \* core zone upper part  
 19993000 4 15 2 1 0.0025  
 19993100 0 1  
 19993101 14 0.005375  
 19993201 5 14  
 19993301 1. 14  
 19993400 0  
 19993401 619. 15  
 19993501 0 0 0 1 27.552 1  
 19993502 0 0 0 1 50.560 2  
 19993503 0 0 0 1 50.848 3  
 19993504 0 0 0 1 20.160 4  
 19993601 400090000 0 1 1 27.552 1  
 19993602 410010000 0 1 1 50.560 2  
 19993603 420010000 0 1 1 50.848 3  
 19993604 430010000 0 1 1 20.160 4  
 19993701 900 0.0155 0. 0. 1  
 19993702 900 0.02858 0. 0. 3  
 19993703 900 0.01135 0. 0. 4  
 19993901 0. 10. 10. 0. 0. 0. 0. 1. 1  
 19993902 0. 10. 10. 0. 0. 0. 0. 1. 2  
 19993903 0. 10. 10. 0. 0. 0. 0. 1. 3  
 19993904 0. 10. 10. 0. 0. 0. 0. 1. 4  
 \*  
 \*  
 \* materials tables  
 \*  
 \*  
 \*  
 20100100 tbl/ctn 1 1  
 20100200 tbl/ctn 1 1  
 20100300 tbl/ctn 1 1  
 20100400 tbl/ctn 1 1  
 20100500 tbl/ctn 1 1  
 20100600 tbl/ctn 1 1  
 20100700 tbl/ctn 1 1  
 20100800 tbl/ctn 1 1  
 \*  
 \*  
 \* inc 625 (vessel) conductivity (w/m/k)  
 20100101 93. 12.  
 20100102 473. 12.5  
 20100103 573. 13.9  
 20100104 673. 15.3

20100105 2073. 16.3  
 \*  
 \*  
 \* " heat capacity (j/m3/kg)  
 20100151 93. 3.46e6  
 20100152 373. 3.67e6  
 20100153 473. 3.87e6  
 20100154 573. 4.05e6  
 20100155 673. 4.26e6  
 20100156 2073. 4.36e6  
 \*  
 \*  
 \* filler (al203) conductivity (w/m/k)  
 20100201 93. 41.9  
 20100202 373. 35.6  
 20100203 773. 12.6  
 20100204 2073. 8.4  
 \*  
 \*  
 \* " thermal capacity (j/m3/kg)  
 20100251 93. 4.04e6  
 20100252 2073. 4.04e6  
 \*  
 \* piping steel conductivity (w/m/k)  
 20100301 93. 14.700  
 20100302 2073. 18.60  
 \*  
 \*  
 \* " heat capacity (j/m3/kg)  
 20100351 93. 3.62e6  
 20100352 2073. 4.21e6  
 \*  
 \*  
 \* nickel connectors conductivity (w/m/k)  
 20100401 93. 79.2  
 20100402 533. 61.9  
 20100403 813. 59.0  
 20100404 1088. 64.8  
 20100405 2800. 67.0  
 \*  
 \*  
 \* " heat capacity (j/m3/kg)  
 20100451 93. 4.05e6  
 20100452 2073. 4.05e6  
 \*  
 \* heater rods material (ss 1.4949) conductivity (w/m/k)  
 20100501 293. 16.9  
 20100502 300. 17.0  
 20100503 400. 18.3  
 20100504 500. 18.9  
 20100505 600. 20.1  
 20100506 700. 21.2  
 20100507 800. 22.4  
 20100508 900. 23.5  
 20100509 1000. 24.7  
 20100510 1050. 25.3  
 20100511 1500. 25.9  
 \*  
 \*  
 \* " heat capacity (j/m3/kg)  
 20100551 293. 3.96e6  
 20100552 300. 3.99e6  
 20100553 400. 4.13e6  
 20100554 500. 4.26e6  
 20100555 600. 4.40e6  
 20100556 700. 4.53e6  
 20100557 800. 4.67e6  
 20100558 900. 4.79e6  
 20100559 1000. 4.97e6  
 20100560 1050. 5.07e6  
 20100561 1500. 5.10e6  
 \*  
 \*  
 \* uo2 doel data  
 \*  
 20100601 293. 8.361  
 20100602 366. 7.27  
 20100603 373. 7.18

20100604 473. 6.10  
 20100605 533. 5.6  
 20100606 573. 5.31  
 20100607 623. 4.99  
 20100608 673. 4.70  
 20100609 723. 4.45  
 20100610 773. 4.22  
 20100611 823. 4.02  
 20100612 873. 3.84  
 20100613 923. 3.67  
 20100614 973. 3.52  
 20100615 1023. 3.38  
 20100616 1073. 3.26  
 20100617 1123. 3.14  
 20100618 1223. 2.94  
 20100619 1273. 2.85  
 20100620 1323. 2.76  
 20100621 1373. 2.69  
 20100622 1423. 2.62  
 20100623 1473. 2.55  
 20100624 1523. 2.5  
 20100625 1573. 2.44  
 20100626 1623. 2.39  
 20100627 1673. 2.35  
 20100628 1723. 2.31  
 20100629 1823. 2.25  
 20100630 1873. 2.22  
 20100631 1923. 2.20  
 20100632 1973. 2.22  
 20100633 2023. 2.25  
 20100634 2073. 2.29  
 20100635 2123. 2.33  
 20100636 2173. 2.37  
 20100637 2223. 2.42  
 20100638 2273. 2.47  
 20100639 2323. 2.52  
 20100640 2423. 2.65  
 20100641 2473. 2.73  
 20100642 2523. 2.81  
 20100643 2573. 2.90  
 20100644 2623. 2.99  
 20100645 2673. 3.10  
 20100646 2773. 3.35  
 20100647 2823. 3.49  
 20100648 2873. 3.65  
 20100649 3200. 5.29  
 \*  
 \* uo2 heat capacity  
 \*  
 20100651 273. 2.31e6  
 20100652 323. 2.57e6  
 20100653 373. 2.75e6  
 20100654 473. 2.92e6  
 20100655 673. 3.13e6  
 20100656 1373. 3.44e6  
 20100657 4700. 6.80e6  
 \*  
 \* gap doel data  
 \*  
 20100701 0.56 \*ref. stabilization vessel.  
 20100751 5.4 \*rho-cd egg-loft-5480  
 \*  
 \*  
 \* zr doel data  
 \*  
 20100801 273.15 7.  
 20100802 473.15 1.200438e1  
 20100803 673.15 1.400510e1  
 20100804 873.15 1.700793e1  
 20100805 1073.15 1.900866e1  
 20100806 1273.15 2.200975e1  
 20100807 1473.15 2.501085e1  
 20100808 1673.15 3.001267e1  
 20100809 1873.15 3.601486e1  
 20100810 2073.15 4.401777e1  
 20100811 2273.15 5.502352e1  
 20100812 2473.15 6.802826e1  
 \*

20100851 255.3722 1.904141e6  
 20100852 1077.594 2.312171e6  
 20100853 1185.928 5.712422e6  
 20100854 1248.428 2.311769e6  
 20100855 2199.817 2.312171e6

\* power table nuclear power imposed  
 \* core power table bt17  
 20290000 power 575 1.0 0.630e6  
 20290001 0. 1.  
 20290002 53. 1.  
 20290003 60. 0.941  
 20290004 80. 0.783  
 20290005 100. 0.662  
 20290006 150. 0.463  
 20290007 200. 0.359  
 20290008 400. 0.224  
 20290009 600. 0.195  
 20290010 800. 0.186  
 20290011 1000. 0.178  
 20290012 1500. 0.163  
 20290013 2000. 0.148  
 20290014 2375. 0.144

\* prez heater power decay table  
 20295000 power 603 1.0 1.2e3  
 20295001 -1. 0.  
 20295002 0. 0.  
 20295003 0.01 0.01  
 20295004 1. 1.  
 20295005 1.e6 1.

\* heat losses to environment

\* lp heat losses (102)  
 \*0210200 htc-t  
 \*0210201 0. 121.  
 \*0210202 10000. 121.

\* vessel wall heat losses dc (200)  
 20220000 htc-t  
 20220001 -1. 7.5  
 20220002 0. 7.5  
 20220003 1.e6 7.5

\* vessel upper plate heat losses (430)  
 20243000 htc-t  
 20243001 0. 20.5  
 20243002 10000. 20.5

\* il. vessel conn. heat losses-bl (500)  
 20250000 htc-t  
 20250001 0. 14.3  
 20250002 10000. 14.3

\* prz heat losses (535) (external heaters comp. in bt17)  
 20253500 htc-t  
 20253501 0. 1.e-6 \*4.71  
 20253502 10000. 1.e-6

\* (560)  
 20256000 htc-t  
 20256001 0. 5.8  
 20256002 10000. 5.8

\*  
 \*  
 \* (580)  
 20258000 htc-t  
 20258001 0. 6.5  
 20258002 10000. 6.5

\* (595)  
 20259500 htc-t  
 20259501 0. 37.  
 20259502 10000. 37.

\* (600)  
 20260000 htc-t  
 20260001 0. 93.3  
 20260002 10000. 93.3

\* (605)  
 20260500 htc-t  
 20260501 0. 27.  
 20260502 10000. 27.

\* (612)  
 20261200 htc-t  
 20261201 0. 21.7  
 20261202 10000. 21.7

\* bl vessel outlet hl heat losses (700)  
 20270000 htc-t  
 20270001 0. 42.33  
 20270002 10000. 42.33

\* bl (710)  
 20271000 htc-t  
 20271001 0. 12.64  
 20271002 10000. 12.64

\* bl heat losses (725)  
 20272500 htc-t  
 20272501 0. 11.99  
 20272502 10000. 11.99

\* bl heat losses (730)  
 20273000 htc-t  
 20273001 0. 63.  
 20273002 10000. 63.

\* bl heat losses (740)  
 20274000 htc-t  
 20274001 0. 93.28  
 20274002 10000. 93.28

\* bl heat losses (745)  
 20274500 htc-t  
 20274501 0. 63.  
 20274502 10000. 63.

\* bl heat losses (770)  
 20277000 htc-t  
 20277001 0. 14.21  
 20277002 10000. 14.21

\* ss sg il heat losses (780)  
 20278000 htc-t  
 20278001 0. 5.7  
 20278002 100. 5.7

20278003 101. 8.7 \* 5.7 before bt-17  
 20278004 1.e6 8.7  
 \*  
 \* ss sg bl heat loss (790)  
 20279000 htc-t  
 20279001 0. 8.6  
 20279002 100. 8.6  
 20279003 101. 14.6 \* 8.6 before bt-17  
 20279004 1.e6 14.6  
 \*

\* environment temperature table (per prez)  
 20299800 temp  
 20299801 0. 619.153  
 20299802 100. 619.153  
 20299803 100.01 300.  
 20299804 1.e6 300.  
 \*

\* environment temperature table (for heat-loss)  
 20299900 temp  
 20299901 0. 300.  
 20299902 10000. 300.  
 \*

\* control variables  
 \*  
 \*

\* 001 prez level

id	val	type	sum	1.	0.	1
20500100	pzrvl	voidf	530010000			
20500101	0. .790	voidf	530010000			
20500102	.630	voidf	535020000			
20500103	1.120	voidf	535040000			
20500104	1.500	voidf	535040000			
20500105	1.500	voidf	540010000			
20500106	1.040	voidf	539010000			
20500107	1.000	voidf				

\* 002 il sg dc level (cl93bt)

id	val	type	sum	1.	0.	1
20500200	ilsgdcl	voidf	850050000			
20500201	0. 1.5000	voidf	850040000			
20500202	1.5000	voidf	850030000			
20500203	1.5000	voidf	850020000			
20500204	1.5000	voidf	850010000			
20500205	1.4020	voidf	840010000			
20500206	0.6450	voidf	830010000			
20500207	0.9460	voidf	815010000			
20500208	0.7910	voidf	820010000			
20500209	0.4240	voidf				

\* 003 bl sg dc level (cl83bt)

id	val	type	sum	1.	0.	1
20500300	blsgdcl	voidf	950050000			
20500301	0. 1.5000	voidf	950040000			
20500302	1.5000	voidf	950030000			
20500303	1.5000	voidf	950020000			
20500304	1.5000	voidf	940010000			
20500305	1.3040	voidf	930010000			
20500306	0.4500	voidf	915010000			
20500307	1.1640	voidf	920010000			
20500308	0.5670	voidf				
20500309	0.5000	voidf				

\* 004 core level

id	val	type	sum	1.	0.	1
20500400	cor.lev.	voidf	400010000			
20500401	0. .200	voidf	400020000			
20500402	.412	voidf	400030000			
20500403	.663	voidf	400040000			
20500404	.583	voidf	400050000			
20500405	.584	voidf	400060000			
20500406	.583	voidf	400070000			
20500407	.663	voidf	400080000			
20500408	.412	voidf	400090000			
20500409	.4305	voidf				

\*  
 \* 005 dc level (cl3dyb)  
 20500500 dc.lvl sum 1. 0. 1  
 20500501 0. 1.002 voidf 200060000  
 20500502 1.275 voidf 200050000  
 20500503 1.167 voidf 200040000  
 20500504 1.246 voidf 200030000  
 20500505 .8485 voidf 200020000  
 20500506 .790 voidf 200010000  
 20500507 .7945 voidf 202010000  
 \*

\* 006 acc inj mass  
 20500600 accmas integral 1. 0. 1  
 20500601 mflowj 675000000  
 \*

\* 007 uh level  
 20500700 uh.lvl sum 1. 0. 1  
 20500701 0. .850 voidf 455010000  
 20500702 .850 voidf 460010000  
 20500703 .866 voidf 460020000  
 \*

\* 008 vessel riser level (cl3rya)  
 20500800 up.lvl sum 1. 0. 1  
 20500801 0. .790 voidf 410010000  
 20500802 .7945 voidf 420010000  
 20500803 1. cntrivar 004 \* core level  
 20500804 0.373 voidf 102010000  
 20500805 1.002 voidf 106010000  
 \*

\* 009 il loop seal lev (cl1792x3)  
 20500900 il.Ls.l sum 1. 0. 1  
 20500901 -2.515 .656 voidf 570130000  
 20500902 0.656 voidf 570140000  
 20500903 0.750 voidf 570150000  
 20500904 0.750 voidf 570160000  
 20500905 0.750 voidf 570170000  
 20500906 0.750 voidf 570180000  
 20500907 0.500 voidf 570190000  
 20500908 0.500 voidf 570200000  
 20500909 0.500 voidf 570210000  
 20500910 0.500 voidf 570220000  
 20500911 0.500 voidf 570230000  
 20500912 0.500 voidf 570240000  
 20500913 .338 voidf 575010000  
 20500914 0.574 voidf 580010000  
 20500915 0.574 voidf 580020000  
 20500916 0.574 voidf 580030000  
 20500917 .828 voidf 585010000  
 20500918 0.950 voidf 590010000  
 20500919 0.7825 voidf 590020000  
 20500920 0.7825 voidf 590030000  
 \*

\* 010 bl loop seal lev (cl2782x2)  
 20501000 bl.Ls.l sum 1. 0. 1  
 20501001 -2.052 .656 voidf 720130000  
 20501002 0.656 voidf 720140000  
 20501003 0.750 voidf 720150000  
 20501004 0.750 voidf 720160000  
 20501005 0.750 voidf 720170000  
 20501006 0.750 voidf 720180000  
 20501007 0.500 voidf 720190000  
 20501008 0.500 voidf 720200000  
 20501009 0.500 voidf 720210000  
 20501010 0.500 voidf 720220000  
 20501011 0.500 voidf 720230000  
 20501012 0.500 voidf 720240000  
 20501013 .221 voidf 722010000  
 20501014 0.639 voidf 725010000  
 20501015 0.639 voidf 725020000  
 20501016 0.639 voidf 725030000  
 20501017 1.042 voidf 730010000  
 20501018 1.151 voidf 730020000  
 20501019 0.701 voidf 730030000



20501020 0.884 voidf 730040000  
 \*  
 \* 011 surge line lvl  
 20501100 su.l.lv sum 1. 0. 1  
 20501101 0. 3.380 voidf 520020000  
 \*  
 \* 012 il sg u tube lvl (asc) (cl1190x3)  
 20501200 ilsgutlv sum 1. 0. 1  
 20501201 0. 0.5 voidf 570010000  
 20501202 0.5 voidf 570020000  
 20501203 0.5 voidf 570030000  
 20501204 0.5 voidf 570040000  
 20501205 0.5 voidf 570050000  
 20501206 0.5 voidf 570060000  
 20501207 0.75 voidf 570070000  
 20501208 0.75 voidf 570080000  
 20501209 0.75 voidf 570090000  
 20501210 0.75 voidf 570100000  
 20501211 0.656 voidf 570110000  
 20501212 0.656 voidf 570120000  
 20501213 0.828 voidf 550010000  
 20501214 0.574 voidf 560010000  
 20501215 0.574 voidf 560020000  
 20501216 0.574 voidf 560030000  
 20501217 0.338 voidf 565010000  
 \*  
 \* 013 bl sg u tube lvl (asc) (cl2180x2)  
 20501300 blsgutlv sum 1. 0. 1  
 20501301 0. 0.5 voidf 720010000  
 20501302 0.5 voidf 720020000  
 20501303 0.5 voidf 720030000  
 20501304 0.5 voidf 720040000  
 20501305 0.5 voidf 720050000  
 20501306 0.5 voidf 720060000  
 20501307 0.75 voidf 720070000  
 20501308 0.75 voidf 720080000  
 20501309 0.75 voidf 720090000  
 20501310 0.75 voidf 720100000  
 20501311 0.656 voidf 720110000  
 20501312 0.656 voidf 720120000  
 20501313 0.842 voidf 710010000  
 20501314 0.639 voidf 712010000  
 20501315 0.639 voidf 712020000  
 20501316 0.639 voidf 712030000  
 20501317 0.221 voidf 718010000  
 \*  
 \* differenze di pressione  
 \*  
 \* 014 dp core (brya)  
 20501400 brya.cal sum 1. 1.163e5 0  
 20501401 0. 1. p 102010000  
 20501402 -1. p 420010000  
 \*  
 \* 015 dp downcomer (3dbu)  
 20501500 dbu.cal sum 1. -2.926e4 0  
 20501501 0. 1. p 202010000  
 20501502 -1. p 200060000  
 \*  
 \* 016 dp core inferiore (3rug)  
 20501600 rug.cal sum 1. 1.229e5 0  
 20501601 0. 1. p 106010000  
 20501602 -1. p 410010000  
 \*  
 \* 017 dp core superiore (3rga)  
 20501700 rga.cal sum 1. 1.001e4 0  
 20501701 0. 1. p 410010000  
 20501702 -1. p 420010000  
 \*  
 \* 018 dp cold leg downcomer il (163db3)  
 20501800 dpl6db.c sum 1. 4.696e4 0  
 20501801 0. 1. p 612010000

20501802 -1. p 202010000  
 \*  
 \* 019 dp up.head-up.plenum (3r39a)  
 20501900 r39a.c sum 1. -1.077e4 0  
 20501901 0. 1. p 420010000  
 20501902 -1. p 460010000  
 \*  
 \* 020 dp cold leg-downcomer bl (263db7)  
 20502000 dp26db.c sum 1. 2.461e4 0  
 20502001 0. 1. p 770010000  
 20502002 -1. p 202010000  
 \*  
 \* 021 dp hot leg-up.plenum il (3r11a4)  
 20502100 r11a.c sum 1. 3.446e4 0  
 20502101 0. 1. p 500010000  
 20502102 -1. p 420010000  
 \*  
 \* 022 dp hot leg-up.plenum bl (3r21a4)  
 20502200 r21a.c sum 1. 3.4630e4 0  
 20502201 0. 1. p 700010000  
 20502202 -1. p 420010000  
 \*  
 \* 023 dp cold leg-hot leg il (161133)  
 20502300 dp1611.c sum 1. 1.926e5 0  
 20502301 0. 1. p 612010000  
 20502302 -1. p 500010000  
 \*  
 \* 024 dp loop seal bl (2724)  
 20502400 dp2724.c sum 1. 2.324e4 0  
 20502401 0. 1. p 730040000  
 20502402 -1. p 730060000  
 \*  
 \* 025 dp pompa bl (2524)  
 20502500 dp2524.c sum 1. 3.435e5 0  
 20502501 0. 1. p 730060000  
 20502502 -1. p 745010000  
 \*  
 \* 026 dp pompa il (1514)  
 20502600 dp1514.c sum 1. 3.178e5 0  
 20502601 0. 1. p 605010000  
 20502602 -1. p 595010000  
 \*  
 \* 027 dp ingresso loop seal il (9217a)  
 20502700 dp9217.c sum 1. 4.972e3 0  
 20502701 0. 1. p 580030000  
 20502702 -1. p 590040000  
 \*  
 \* 028 dp u-tube il (9092aa)  
 20502800 aa9092.c sum 1. 6.005e4 0  
 20502801 0. 1. p 560010000  
 20502802 -1. p 580030000  
 \*  
 \* 029 dp loop seal il (1714)  
 20502900 dp1714.c sum 1. 2.152e4 0  
 20502901 0. 1. p 590040000  
 20502902 -1. p 595010000  
 \*  
 \* 030 dp ingresso loop seal bl (8227a)  
 20503000 dp8227.c sum 1. 9.175e3 0  
 20503001 0. 1. p 725030000  
 20503002 -1. p 730040000  
 \*  
 \* 031 dp u-tube ascendente il (90bpx2)  
 20503100 px290b.c sum 1. 7.434e4 0  
 20503101 0. 1. p 565010000

20503102 -1. p 570120000  
 \*  
 \* 032 dp u-tube bl (8082aa)  
 20503200 aa8082.c sum 1.6815e4 0  
 20503201 0.1. p 712010000  
 20503202 -1. p 725030000  
 \*  
 \* 033 dp u-tube ascendente bl (80bpx2)  
 20503300 px280b.c sum 1.7907e4 0  
 20503301 0.1. p 718010000  
 20503302 -1. p 720120000  
 \*  
 \* 034 dp secundario bl (85jp)  
 20503400 dp85jp.c sum 1.1176e4 0  
 20503401 0.1. p 900070000  
 20503402 -1. p 900120000  
 \*  
 \* 035 dp secundario il (95fp)  
 20503500 dp95fp.c sum 1.2290e4 0  
 20503501 0.1. p 800050000  
 20503502 -1. p 800120000  
 \*  
 \* heat exchange  
 \*  
 \* 036 core total power  
 20503600 core.pw sum -1. 0. 1  
 20503601 0.59716 htrnr 992000101  
 20503602 .43228 htrnr 993000101  
 20503603 .89050 htrnr 994000101  
 20503604 1.433 htrnr 995000101  
 20503605 1.2601 htrnr 996000101  
 20503606 1.2623 htrnr 997000101  
 20503607 1.2601 htrnr 998000101  
 20503608 1.433 htrnr 999000101  
 20503609 .89050 htrnr 999100101  
 20503610 .93049 htrnr 999300101  
 20503611 1.70752 htrnr 999300201  
 20503612 1.71724 htrnr 999300301  
 20503613 .68085 htrnr 999300401  
 \*  
 \* 037 lp mass (53.52 l)  
 20503700 vip.mas sum 1. 0. 1  
 20503701 0.0285 rho 102010000  
 20503702 .0250 rho 106010000  
 \*  
 \* 038 vessel dc mass (84.04 l)  
 20503800 dc.mass sum 1. 0. 1  
 20503801 0.00898 rho 202010000  
 20503802 .00893 rho 200010000  
 20503803 .00953 rho 200020000  
 20503804 .01409 rho 200030000  
 20503805 .01320 rho 200040000  
 20503806 .01442 rho 200050000  
 20503807 .01133 rho 200060000  
 20503808 .00356 rho 210010000  
 \*  
 \* 039 up mass (45.59 l)  
 20503900 up.mass sum 1. 0. 1  
 20503901 0.01896 rho 410010000  
 20503902 .01907 rho 420010000  
 20503903 .00756 rho 430010000  
 \*  
 \* 040 core mass (36.77 l)  
 20504000 core.ma sum 1. 0. 1  
 20504001 0.001623 rho 400010000  
 20504002 .003343 rho 400020000  
 20504003 .005380 rho 400030000  
 20504004 .004731 rho 400040000  
 20504005 .004739 rho 400050000  
 20504006 .004731 rho 400060000  
 20504007 .005380 rho 400070000

20504008 .003343 rho 400080000  
 20504009 .003494 rho 400090000  
 \*  
 \* 041 upper head mass (31.31 l)  
 20504100 uh.mass sum 1. 0. 1  
 20504101 0.00044 rho 440010000  
 20504102 .00057 rho 450010000  
 20504103 .00961 rho 455010000  
 20504104 .00961 rho 460010000  
 20504105 .00979 rho 460020000  
 20504106 .00129 rho 470010000  
 \*  
 \* 042 il hl mass (43.66 l)  
 20504200 ilhlmas sum 1. 0. 1  
 20504201 0.003865 rho 500010000  
 20504202 .002871 rho 510010000  
 20504203 .002871 rho 511010000  
 20504204 .002872 rho 512010000  
 20504205 .003370 rho 550010000  
 20504206 .006251 rho 560010000  
 20504207 .006251 rho 560020000  
 20504208 .006251 rho 560030000  
 20504209 .009050 rho 565010000  
 \*  
 \* 043 il sg mass asc. part (105.88 l)  
 20504300 ilsgma sum 1. 0. 1  
 20504301 0.00362 rho 570010000  
 20504302 .00362 rho 570020000  
 20504303 .00362 rho 570030000  
 20504304 .00362 rho 570040000  
 20504305 .00362 rho 570050000  
 20504306 .00362 rho 570060000  
 20504307 .005431 rho 570070000  
 20504308 .005431 rho 570080000  
 20504309 .005431 rho 570090000  
 20504310 .005431 rho 570100000  
 20504311 .00475 rho 570110000  
 20504312 .00475 rho 570120000  
 \*  
 \* 044 il cl mass (55.28 l)  
 20504400 ilclma sum 1. 0. 1  
 20504401 0.009050 rho 575010000  
 20504402 .00625 rho 580010000  
 20504403 .00625 rho 580020000  
 20504404 .00625 rho 580030000  
 20504405 .003370 rho 585010000  
 20504406 .00405 rho 590010000  
 20504407 .00333 rho 590020000  
 20504408 .00333 rho 590030000  
 20504409 .00364 rho 590040000  
 20504410 .00333 rho 590050000  
 20504411 .00333 rho 590060000  
 20504412 .003052 rho 595010000  
 \*  
 \* 045 il cl vess comm mass (21.45 l)  
 20504500 ilclvcm sum 1. 0. 1  
 20504501 0.003 rho 600010000  
 20504502 .00441 rho 605010000  
 20504503 .00280 rho 610010000  
 20504504 .00280 rho 610020000  
 20504505 .00280 rho 610030000  
 20504506 .00280 rho 610040000  
 20504507 .00286 rho 612010000  
 \*  
 \* 046 pressurizer and surge line mass (87.30 l)  
 20504600 pr.sulma sum 1. 0. 1  
 20504601 0.000096 rho 520010000  
 20504602 .000493 rho 520020000  
 20504603 .000383 rho 520030000  
 20504604 .006502 rho 530010000  
 20504605 .005292 rho 535010000  
 20504606 .013552 rho 535020000  
 20504607 .018150 rho 535030000  
 20504608 .018150 rho 535040000  
 20504609 .012584 rho 540010000  
 20504610 .012100 rho 539010000

20504611 .000710 rho 507010000  
 \*  
 \* 047 bl hl mass (17.71 l)  
 20504700 blhlma sum 1.0.1  
 20504701 0.0008345 rho 700010000  
 20504702 .0009396 rho 705010000  
 20504703 .0009396 rho 705020000  
 20504704 .0009396 rho 705030000  
 20504705 .0009396 rho 702010000  
 20504706 .00308 rho 710010000  
 20504707 .00234 rho 712010000  
 20504708 .00234 rho 712020000  
 20504709 .00234 rho 712030000  
 20504710 .00301 rho 718010000  
 \*  
 \*  
 \* 048 bl sg mass asc. part  
 20504800 blsgma sum 1.0.1  
 20504801 0.001206 rho 720010000  
 20504802 .001206 rho 720020000  
 20504803 .001206 rho 720030000  
 20504804 .001206 rho 720040000  
 20504805 .001206 rho 720050000  
 20504806 .001206 rho 720060000  
 20504807 .00181 rho 720070000  
 20504808 .00181 rho 720080000  
 20504809 .00181 rho 720090000  
 20504810 .00181 rho 720100000  
 20504811 .001583 rho 720110000  
 20504812 .001583 rho 720120000  
 \*  
 \*  
 \* 049 bl cl mass (up to pump excluded)  
 20504900 blclma sum 1.0.1  
 20504901 0.00301 rho 722010000  
 20504902 .00234 rho 725010000  
 20504903 .00234 rho 725020000  
 20504904 .00234 rho 725030000  
 20504905 .00141 rho 730010000  
 20504906 .00034 rho 730010000  
 20504907 .00192 rho 730020000  
 20504908 .00117 rho 730030000  
 20504909 .00147 rho 730040000  
 20504910 .00117 rho 730050000  
 20504911 .00192 rho 730060000  
 \*  
 \*  
 \* 050 bl cl vess. com mass (pump included) ( 1)  
 20505000 blclvema sum 1.0.1  
 20505001 0.003 rho 740010000  
 20505002 .00084 rho 745010000  
 20505003 .0006159 rho 750010000  
 20505004 .0006159 rho 750020000  
 20505005 .0006159 rho 750030000  
 20505006 .0006159 rho 750040000  
 20505007 .0006159 rho 750050000  
 20505008 .0008465 rho 770010000  
 20505009 .0008465 rho 772010000  
 20505010 .0008465 rho 774010000  
 20505011 .0008465 rho 776010000  
 \*  
 \*  
 \* 051 sg il dc mass (275.93 l)  
 20505100 sgildcma sum 1.0.1  
 20505101 0.12298 rho 830010000  
 20505102 .06450 rho 840010000  
 20505103 .016754 rho 850010000  
 20505104 .017925 rho 850020000  
 20505105 .017925 rho 850030000  
 20505106 .017925 rho 850040000  
 20505107 .017925 rho 850050000  
 \*  
 \*  
 \* 052 sg il riser mass (382.84 l)  
 20505200 sgilrima sum 1.0.1  
 20505201 0.01495 rho 800010000

20505202 .01495 rho 800020000  
 20505203 .01495 rho 800030000  
 20505204 .01495 rho 800040000  
 20505205 .01495 rho 800050000  
 20505206 .01495 rho 800060000  
 20505207 .02242 rho 800070000  
 20505208 .02242 rho 800080000  
 20505209 .02242 rho 800090000  
 20505210 .02242 rho 800100000  
 20505211 .02952 rho 800110000  
 20505212 .03357 rho 800120000  
 20505213 .01484 rho 810010000  
 20505214 .05000 rho 810020000  
 \*  
 \*  
 \* 053 sg il steam dome mass (186.9 l)  
 20505300 sgilsdma sum 1.0.1  
 20505301 0.12166 rho 815010000  
 20505302 .06521 rho 820010000  
 \*  
 \* 054 sg bl dc mass (91.92 l)  
 20505400 sgbldcma sum 1.0.1  
 20505401 0.04509 rho 930010000  
 20505402 .01742 rho 940010000  
 20505403 .00558 rho 950010000  
 20505404 .00597 rho 950020000  
 20505405 .00597 rho 950030000  
 20505406 .00597 rho 950040000  
 20505407 .00597 rho 950050000  
 \*  
 \* 055 sg bl riser mass (130.98 l)  
 20505500 sgblrima sum 1.0.1  
 20505501 0.0047 rho 900010000  
 20505502 .0047 rho 900020000  
 20505503 .0047 rho 900030000  
 20505504 .0047 rho 900040000  
 20505505 .0047 rho 900050000  
 20505506 .0047 rho 900060000  
 20505507 .00705 rho 900070000  
 20505508 .00705 rho 900080000  
 20505509 .00705 rho 900090000  
 20505510 .00705 rho 900100000  
 20505511 .01115 rho 900110000  
 20505512 .01268 rho 900120000  
 20505513 .00494 rho 910010000  
 20505514 .02000 rho 910020000  
 \*  
 \* 056 sg bl steam dome mass (62.24 l)  
 20505600 sgblsdma sum 1.0.1  
 20505601 0.03307 rho 915010000  
 20505602 .02917 rho 920010000  
 \*  
 \* 057 secondary mass of sg bl  
 20505700 sgblmss sum 1.0.1  
 20505701 0.1. cntrivar 054  
 20505702 1. cntrivar 055  
 20505703 1. cntrivar 056  
 \*  
 \* 058 secondary mass  
 20505800 ss.mass sum 1.0.1  
 20505801 0.1. cntrivar 051  
 20505802 1. cntrivar 052  
 20505803 1. cntrivar 053  
 20505804 1. cntrivar 054  
 20505805 1. cntrivar 055  
 20505806 1. cntrivar 056  
 \*  
 \* 059 secondary mass of sg il  
 20505900 sgi.mss sum 1.0.1  
 20505901 0.1. cntrivar 051  
 20505902 1. cntrivar 052  
 20505903 1. cntrivar 053  
 \*  
 \*  
 \* 060 sg ss il heat losses  
 20506000 hlsq.il sum 1.0.1  
 20506001 0.1.687 htrnr 850000101  
 20506002 1.804 htrnr 850000201

20506003 1.804 htrnr 850000301  
 20506004 1.804 htrnr 850000401  
 20506005 1.804 htrnr 850000501  
 \*  
 \* 061 sg ss bl heat losses  
 20506100 hlsg.bl sum 1. 0.1  
 20506101 0. 1. htrnr 950000101  
 20506102 1.017 htrnr 950000201  
 20506103 1.017 htrnr 950000301  
 20506104 1.017 htrnr 950000401  
 20506105 1.017 htrnr 950000501  
 \*  
 \* 062 sgil heat exchange l  
 20506200 sgi.he1 sum 1. 0.1  
 20506201 0. 1. q 570010000  
 20506202 1. q 570020000  
 20506203 1. q 570030000  
 20506204 1. q 570040000  
 20506205 1. q 570050000  
 20506206 1. q 570060000  
 20506207 1. q 570070000  
 20506208 1. q 570080000  
 20506209 1. q 570090000  
 20506210 1. q 570100000  
 20506211 1. q 570110000  
 20506212 1. q 570120000  
 \*  
 \* 063 sgil heat exchange dl  
 20506300 sgi.he2 sum 1. 0.1  
 20506301 0. 1. q 570130000  
 20506302 1. q 570140000  
 20506303 1. q 570150000  
 20506304 1. q 570160000  
 20506305 1. q 570170000  
 20506306 1. q 570180000  
 20506307 1. q 570190000  
 20506308 1. q 570200000  
 20506309 1. q 570210000  
 20506310 1. q 570220000  
 20506311 1. q 570230000  
 20506312 1. q 570240000  
 \*  
 \* 064 sgil heat exchange total  
 20506400 sgi.he sum 1. 0.1  
 20506401 0. 1. cntrivar 062  
 20506402 1. cntrivar 063  
 \*  
 \* 065 sgbl heat exchange l  
 20506500 sgb.he1 sum 1. 0.1  
 20506501 0. 1. q 720010000  
 20506502 1. q 720020000  
 20506503 1. q 720030000  
 20506504 1. q 720040000  
 20506505 1. q 720050000  
 20506506 1. q 720060000  
 20506507 1. q 720070000  
 20506508 1. q 720080000  
 20506509 1. q 720090000  
 20506510 1. q 720100000  
 20506511 1. q 720110000  
 20506512 1. q 720120000  
 \*  
 \* 066 sgbl heat exchange dl  
 20506600 sgb.he2 sum 1. 0.1  
 20506601 0. 1. q 720130000  
 20506602 1. q 720140000  
 20506603 1. q 720150000  
 20506604 1. q 720160000  
 20506605 1. q 720170000  
 20506606 1. q 720180000  
 20506607 1. q 720190000  
 20506608 1. q 720200000

20506609 1. q 720210000  
 20506610 1. q 720220000  
 20506611 1. q 720230000  
 20506612 1. q 720240000  
 \*  
 \* 067 sgbl heat exchange total  
 20506700 sgb.he sum 1. 0.1  
 20506701 0. 1. cntrivar 065  
 20506702 1. cntrivar 066  
 \*  
 \* 068 il sg mass desc. part (105.88 l)  
 20506800 ilsgma2 sum 1. 0.1  
 20506801 0. .00362 rho 570240000  
 20506802 .00362 rho 570230000  
 20506803 .00362 rho 570220000  
 20506804 .00362 rho 570210000  
 20506805 .00362 rho 570200000  
 20506806 .00362 rho 570190000  
 20506807 .005431 rho 570180000  
 20506808 .005431 rho 570170000  
 20506809 .005431 rho 570160000  
 20506810 .005431 rho 570150000  
 20506811 .00475 rho 570140000  
 20506812 .00475 rho 570130000  
 \*  
 \* 069 bl sg mass dec. part  
 20506900 blsgmad sum 1. 0.1  
 20506901 0. .001206 rho 720240000  
 20506902 .001206 rho 720230000  
 20506903 .001206 rho 720220000  
 20506904 .001206 rho 720210000  
 20506905 .001206 rho 720200000  
 20506906 .001206 rho 720190000  
 20506907 .00181 rho 720180000  
 20506908 .00181 rho 720170000  
 20506909 .00181 rho 720160000  
 20506910 .00181 rho 720150000  
 20506911 .001583 rho 720140000  
 20506912 .001583 rho 720130000  
 \*  
 \* 077 primary mass  
 20507700 pr.mass sum 1. 0.1  
 20507701 0. 1. cntrivar 037  
 20507702 1. cntrivar 038  
 20507703 1. cntrivar 039  
 20507704 1. cntrivar 040  
 20507705 1. cntrivar 041  
 20507706 1. cntrivar 042  
 20507707 1. cntrivar 043  
 20507708 1. cntrivar 044  
 20507709 1. cntrivar 045  
 20507710 1. cntrivar 046  
 20507711 1. cntrivar 047  
 20507712 1. cntrivar 048  
 20507713 1. cntrivar 049  
 20507714 1. cntrivar 050  
 20507715 1. cntrivar 068  
 20507716 1. cntrivar 069  
 \*  
 \* 089 heat loss - prez  
 20508900 pr.ht.ls sum 1. 0. 1  
 20508901 0. 0.317 htrnr 535100101  
 20508902 0.563 htrnr 535100201  
 20508903 0.754 htrnr 535100301  
 20508904 0.754 htrnr 535100401  
 20508905 0.522 htrnr 540100101  
 20508906 0.502 htrnr 540100201  
 \*  
 \* 090 heat loss - vessel  
 20509000 vs.ht.ls sum 1. 0. 1  
 20509001 0. 0.85762 htrnr 200100101  
 20509002 0.85277 htrnr 200100201  
 20509003 0.90944 htrnr 200100301  
 20509004 1.3450 htrnr 200100401  
 20509005 1.2597 htrnr 200100501

20509006 1.3763 htrnr 200100601  
 20509007 3.0000 htrnr 430100101  
 \*  
 \* 091 heat loss - il  
 20509100 il.ht.ls sum 1. 0. 1  
 20509101 0. 0.30654 htrnr 500100101  
 20509102 0.35019 htrnr 605100101  
 20509103 0.227 htrnr 612100101  
 20509104 0.252 htrnr 560100101  
 20509105 0.252 htrnr 560100201  
 20509106 0.252 htrnr 560100301  
 20509107 0.252 htrnr 580100101  
 20509108 0.252 htrnr 580100201  
 20509109 0.252 htrnr 580100301  
 20509110 0.254 htrnr 595100101  
 20509111 0.172 htrnr 600100101  
 \*  
 \* 092 heat loss - bl  
 20509200 bl.ht.ls sum 1. 0. 1  
 20509201 0. 0.12566 htrnr 700100101  
 20509202 0.15802 htrnr 745100101  
 20509203 0.1405 htrnr 710100201  
 20509204 0.1405 htrnr 710100301  
 20509205 0.1405 htrnr 710100401  
 20509206 0.166 htrnr 725100101  
 20509207 0.166 htrnr 725100201  
 20509208 0.166 htrnr 725100301  
 20509209 0.224 htrnr 730100601  
 20509210 0.172 htrnr 740100101  
 20509211 0.1052 htrnr 770100101  
 20509212 0.1052 htrnr 770100201  
 20509213 0.1052 htrnr 770100301  
 20509214 0.1052 htrnr 770100401  
 \*  
 \* 093 heat loss - tot  
 20509300 tt.ht.ls sum -1. 0. 1  
 20509301 0. 1. cntrivar 090  
 20509302 1. cntrivar 091  
 20509303 1. cntrivar 092  
 20509304 1. cntrivar 089  
 \*  
 \* heat exchange fluid structures  
 \*  
 \* ves1  
 20510100 ve.a.hex sum 1. 0. 1  
 20510101 0. 1. q 102010000  
 20510102 1. q 202010000  
 20510103 1. q 200010000  
 20510104 1. q 200020000  
 20510105 1. q 200030000  
 20510106 1. q 200040000  
 20510107 1. q 200050000  
 20510108 1. q 200060000  
 20510109 1. q 210010000  
 \*  
 \* ves2  
 20510200 ve.b.hex sum 1. 0. 1  
 20510201 0. .5099 htrnr 106100100  
 20510202 .09299 htrnr 108300100  
 20510203 .1915 htrnr 108300200  
 20510204 .3082 htrnr 108300300  
 20510205 .2710 htrnr 108300400  
 20510206 .2715 htrnr 108300500  
 20510207 .2710 htrnr 108300600  
 20510208 .3082 htrnr 108300700  
 20510209 .1912 htrnr 108300800  
 20510210 .2002 htrnr 108300900  
 20510211 .4864 htrnr 420100100  
 20510212 .4892 htrnr 420100200  
 20510213 .1939 htrnr 420100300  
 20510214 3.000 htrnr 430100100  
 \*  
 \* uh  
 20510300 uh.a.hex sum 1. 0. 1  
 20510301 0. 1. q 440010000  
 20510302 1. q 450010000  
 20510303 1. q 455010000

20510304 1. q 460010000  
 20510305 1. q 460020000  
 20510306 1. q 470010000  
 \*  
 \* prz + surge line  
 20510400 prz.hex sum 1. 0. 1  
 20510401 0. 1. q 520020000  
 20510402 1. q 520030000  
 20510403 1. q 530010000  
 20510404 1. q 535010000  
 20510405 1. q 535020000  
 20510406 1. q 535030000  
 20510407 1. q 535040000  
 20510408 1. q 540010000  
 20510409 1. q 539010000  
 \*  
 \* il ps 1  
 20510500 il.hex1 sum 1. 0. 1  
 20510501 0. 1. q 500010000  
 20510502 1. q 510010000  
 20510503 1. q 511010000  
 20510504 1. q 512010000  
 20510505 1. q 550010000  
 20510506 1. q 560010000  
 20510507 1. q 560020000  
 20510508 1. q 560030000  
 20510509 1. q 565010000  
 20510510 1. q 575010000  
 20510511 1. q 580010000  
 20510512 1. q 580020000  
 \*  
 \* il ps 2  
 20510600 il.hex2 sum 1. 0. 1  
 20510601 0. 1. q 580030000  
 20510602 1. q 585010000  
 20510603 1. q 590010000  
 20510604 1. q 590020000  
 20510605 1. q 590030000  
 20510606 1. q 590040000  
 20510607 1. q 590050000  
 20510608 1. q 595010000  
 20510609 1. q 600010000  
 20510610 1. q 605010000  
 20510611 1. q 610010000  
 20510612 1. q 610020000  
 20510613 1. q 610030000  
 20510614 1. q 610040000  
 20510615 1. q 612010000  
 \*  
 \* il ps  
 20510700 il.hex sum 1. 0. 1  
 20510701 0. 1. cntrivar 105  
 20510702 1. cntrivar 106  
 \*  
 \* bl ps heat e205106c 1  
 20510800 bl.hex1 sum 1. 0. 1  
 20510801 0. 1. q 700010000  
 20510802 1. q 705010000  
 20510803 1. q 705020000  
 20510804 1. q 705030000  
 20510805 1. q 702010000  
 20510806 1. q 710010000  
 20510807 1. q 712010000  
 20510808 1. q 712020000  
 20510809 1. q 718010000  
 20510810 1. q 722010000  
 20510811 1. q 725010000  
 20510812 1. q 725020000  
 20510813 1. q 725030000  
 \*  
 \* bl ps heat e205106c 2  
 20510900 bl.hex2 sum 1. 0. 1  
 20510901 0. 1. q 730010000  
 20510902 1. q 730020000  
 20510903 1. q 730030000  
 20510904 1. q 730040000  
 20510905 1. q 730050000  
 20510906 1. q 730060000

20510907 1. q 740010000  
 20510908 1. q 745010000  
 20510909 1. q 750010000  
 20510910 1. q 750020000  
 20510911 1. q 750030000  
 20510912 1. q 750040000  
 20510913 1. q 750050000  
 20510914 1. q 770010000  
 20510915 1. q 772010000  
 20510916 1. q 774010000  
 \*  
 \* bl ps heat e205106c  
 20511000 blhex sum 1. 0. 1  
 20511001 0. 1. cntrivar 108  
 20511002 1. cntrivar 109  
 \*  
 \* il sg ss first part  
 20511100 ilsg.hea sum 1. 0. 1  
 20511101 0. 1. q 850010000  
 20511102 1. q 850020000  
 20511103 1. q 850030000  
 20511104 1. q 850040000  
 20511105 1. q 850050000  
 20511106 1. q 840010000  
 20511107 1. q 830010000  
 20511108 1. q 815010000  
 20511109 1. q 820010000  
 20511110 1. q 810010000  
 20511111 1. q 810020000  
 \*  
 \* il sg ss second part 1  
 20511200 ilsg.he1 sum 1. 0. 1  
 20511201 0. .2388 htrnr 800000100  
 20511202 .2388 htrnr 800000200  
 20511203 .2388 htrnr 800000300  
 20511204 .2388 htrnr 800000400  
 20511205 .2388 htrnr 800000500  
 20511206 .2388 htrnr 800000600  
 20511207 .3581 htrnr 800000700  
 20511208 .3581 htrnr 800000800  
 20511209 .3581 htrnr 800000900  
 20511210 .3581 htrnr 800001000  
 20511211 .3132 htrnr 800001100  
 20511212 .3562 htrnr 800001200  
 \*  
 \* il sg ss second part 2  
 20511300 ilsg.he2 sum 1. 0. 1  
 20511313 0. .4712 htrnr 800100100  
 20511314 .4712 htrnr 800100200  
 20511315 .4712 htrnr 800100300  
 20511316 .4712 htrnr 800100400  
 20511317 .4712 htrnr 800100500  
 20511318 .4712 htrnr 800100600  
 20511319 .7068 htrnr 800100700  
 20511320 .7068 htrnr 800100800  
 20511321 .7068 htrnr 800100900  
 20511322 .7068 htrnr 800101000  
 20511323 .6183 htrnr 800101100  
 20511324 .7031 htrnr 800101200  
 \*  
 \* il sg ss second part  
 20511400 ilsg.heb sum 1. 0. 1  
 20511413 0. 1. cntrivar 112  
 20511414 1. cntrivar 113  
 \*  
 \* bl sg ss first part  
 20511500 blsg.hea sum 1. 0. 1  
 20511501 0. 1. q 950010000  
 20511502 1. q 950020000  
 20511503 1. q 950030000  
 20511504 1. q 950040000  
 20511505 1. q 950050000  
 20511506 1. q 940010000  
 20511507 1. q 930010000  
 20511508 1. q 915010000  
 20511509 1. q 920010000  
 20511510 1. q 910010000

20511511 1. q 910020000  
 \*  
 \* bl sg ss second part 1  
 20511600 blsg.he1 sum 1. 0. 1  
 20511601 0. .1976 htrnr 900000100  
 20511602 .1976 htrnr 900000200  
 20511603 .1976 htrnr 900000300  
 20511604 .1976 htrnr 900000400  
 20511605 .1976 htrnr 900000500  
 20511606 .1976 htrnr 900000600  
 20511607 .2964 htrnr 900000700  
 20511608 .2964 htrnr 900000800  
 20511609 .2964 htrnr 900000900  
 20511610 .2964 htrnr 900001000  
 20511611 .2592 htrnr 900001100  
 20511612 .2948 htrnr 900001200  
 \*  
 \* bl sg ss second part 2  
 20511700 blsg.he2 sum 1. 0. 1  
 20511713 0. .3157 htrnr 900100100  
 20511714 .3157 htrnr 900100200  
 20511715 .3157 htrnr 900100300  
 20511716 .3157 htrnr 900100400  
 20511717 .3157 htrnr 900100500  
 20511718 .3157 htrnr 900100600  
 20511719 .4736 htrnr 900100700  
 20511720 .4736 htrnr 900100800  
 20511721 .4736 htrnr 900100900  
 20511722 .4736 htrnr 900101000  
 20511723 .4142 htrnr 900101100  
 20511724 .4711 htrnr 900101200  
 \*  
 \* bl sg ss second part  
 20511800 blsg.heb sum 1. 0. 1  
 20511813 0. 1. cntrivar 116  
 20511814 1. cntrivar 117  
 \*  
 \* ps heat exchange fluid - structures  
 20512000 ps.hex sum 1. 0. 1  
 20512001 0. 1. cntrivar 101  
 20512002 1. cntrivar 102  
 20512003 1. cntrivar 103  
 20512004 1. cntrivar 104  
 20512005 1. cntrivar 107  
 20512006 1. cntrivar 110  
 \*  
 \* ss heat exchange fluid - structures il  
 20512100 ss.he.il sum 1. 0. 1  
 20512101 0. 1. cntrivar 111  
 20512102 1. cntrivar 114  
 \*  
 \* ss heat exchange fluid - structures bl  
 20512200 ss.he.bl sum 1. 0. 1  
 20512201 0. 1. cntrivar 115  
 20512202 1. cntrivar 118  
 \*  
 \* system exchange fluid - structures  
 20513000 syst.hex sum 1. 0. 1  
 20513001 0. 1. cntrivar 120  
 20513002 1. cntrivar 121  
 20513003 1. cntrivar 122  
 \*  
 \* overall mass loss from the break bl21  
 20514000 break.ml integral 1. 0. 0  
 20514001 mflowj 719000000  
 \*  
 \* overall mass loss from safety of sgss il  
 20514100 sgssailit integral 1. 0. 0  
 20514101 mflowj 838000000  
 \*  
 \* overall pump seal (inlet & outlet)  
 20514200 pusea.ba sum 1. 0. 1  
 20514201 0. 1. mflowj 601000000  
 20514202 1. mflowj 744000000  
 20514203 -1. mflowj 604000000  
 \*

```

*
* mass balance of pump seal water
20514300 pu.sc.in integral 1. 0. 0
20514301 cntrivar 142
*
* mass balance of ps (senza accumulatori)
20514400 ps.ma.ba sum 1. 0. 1
20514401 0. -1. cntrivar 157
20514402 1. cntrivar 143
20514403 1. cntrivar 161
*
* power loss from the srv 1 (energy of the node upstream-1)
20515000 po.srva sum 1. 0. 1
20515001 0. 1. ug 539010000
20515002 -1. uf 539010000
*
* power loss from the srv 1 (energy of the node upstream-2)
20515100 po.srvb mult 1. 0. 1
20515101 quals 539010000 cntrivar 150
*
*
* power loss from the srv 1 (energy of the node upstream-3)
20515200 po.srvc sum 1. 0. 1
20515201 0. 1. uf 539010000
20515202 1. cntrivar 151
*
*
* power loss from the srv 2
20515300 po.srvd mult 1. 0. 1
20515301 mflowj 543000000 cntrivar 152
*
*
* overall mass loss from the prz porv
20515400 porvint integral 1. 0. 0
20515401 mflowj 543000000
*
* overall mass loss from the prz srv
20515500 srv.int integral 1. 0. 0
20515501 mflowj 545000000
*
*
* overall mass loss from the prz porv+srv
20515600 po.srv.i integral 1. 0. 0
20515601 mflowj 547000000
*
* loss form prz top (porv, srv, porv+srv)
20515700 prz.loss sum 1. 0. 1
20515701 0. 1. cntrivar 154
20515702 1. cntrivar 155
20515703 1. cntrivar 156
*
*
* mass balance il acc
20515800 ac.ma.il integral 1. 0. 0
20515801 mflowj 615010000
*
* mass balance bl acc
20515900 ac.ma.bl integral 1. 0. 0
20515901 mflowj 768010000
*
* sg bl ss mass
20516000 sg.bl.ma sum 1. 0. 1
20516001 0. 1. cntrivar 54
20516002 1. cntrivar 55
20516003 1. cntrivar 56
*
* mass inlet in ps from accs
20516100 accs.min sum 1. 0. 1
20516101 0. 1. cntrivar 158
20516102 1. cntrivar 159
*
* sl sg il overall flowrate
20516200 sg.il.fl sum 1. 0. 1
20516201 0. 1. mflowj 828000000
20516202 1. mflowj 838000000
*
* sl sg bl overall flowrate
20516300 sg.bl.fl sum 1. 0. 1
20516301 0. 1. mflowj 928000000
20516302 1. mflowj 938000000
*
* sg il ss drift velocity
20517000 sg.il.dv sum 1. 0. 1
20517001 0. -1. velfj 805000000
20517002 1. velgj 805000000
*
* pump sat control
20517100 pu.sa.co sum 1. 0. 1
20517101 0. 1. sattemp 595010000
20517102 -1. tempf 595010000
*
*
* variabile a caso
20517200 rp.perc mult 0.192 0. 1
20517201 mflowj 530010000
*
*
* overall mass loss from safety of sgss bl
20517300 sgblsait integral 1. 0. 0
20517301 mflowj 938000000
*
*
* overall mass drained from sg ss bl dc (to maintain lvl at 9.0m)
20517400 sgblsait integral 1. 0. 0
20517401 mflowj 965000000
*
*
* 175 total pump seal water flowrate (for bt-17 55% of p.s.in)
20517500 pu.s.wt sum 1. 0. 1
20517501 0. 0.50 mflowj 601000000
20517502 0.50 mflowj 744000000
*
*
* 176 dc-up gap by-pass total
20517600 dc-upg sum 1. 0. 1
20517601 0. 1. mflowj 500030000
20517602 1. mflowj 700030000
*
*
* 177 il accumulator level
20517700 iac-lev sum 1. 0. 1
20517701 0. 4.680 voidf 615010000
*
*
* 178 bl accumulator level
20517800 bac-lev sum 1. 0. 1
20517801 0. 6.794 voidf 768010000
*
*
* 179 bl accumulator mass
20517900 iac-mas sum 1. 0. 1
20517901 0. 279.85e-3 rho 615010000
*
*
* 180 bl accumulator mass
20518000 bac-mas sum 1. 0. 1
20518001 0. 94.35e-3 rho 768010000
*
*
* 181 dp il total
20518100 iltot sum 1. 1.751e5 0
20518101 0. 1. p 612010000
20518102 -1. p 500010000
*
*
* 182 dp bl total
20518200 bltot sum 1. 1.926e5 0
20518201 0. 1. p 776010000
20518202 -1. p 700010000
*
*
* 183 dp sg il u-tube
20518300 lutube sum 1. 6.005e4 0
20518301 0. 1. p 565010000
20518302 -1. p 575010000

```


```
*
*
* 184 dp sg bl u-tube
20518400 b.utube sum 1. 6.815e4 0
20518401 0. 1. p 718010000
20518402 -1. p 722010000
*
*
* 185 dp across sg il riser
20518500 sgilr sum 1. 3.6971e4 0
20518501 0. 1. p 800010000
20518502 -1. p 800120000
*
*
* 186 dp across sg bl riser
20518600 sgblr sum 1. 2.9226e4 0
20518601 0. 1. p 900010000
20518602 -1. p 900120000
*
*
/*
```




NRC FORM 335 (2-89) NRCM 1102, 3201, 3202	U.S. NUCLEAR REGULATORY COMMISSION  <b>BIBLIOGRAPHIC DATA SHEET</b> <i>(See instructions on the reverse)</i>	<b>1. REPORT NUMBER</b> (Assigned by NRC, Add Vol., Supp., Rev., and Addendum Numbers, if any.)  NUREG/IA-0152			
<b>2. TITLE AND SUBTITLE</b>  RELAP5/MOD3.2 Post Test Analysis and Accuracy Quantification of Lobi Test BL-34	<b>3. DATE REPORT PUBLISHED</b> <table border="1" style="width: 100%;"> <tr> <td style="width: 50%;">MONTH</td> <td style="width: 50%;">YEAR</td> </tr> <tr> <td>February</td> <td>1999</td> </tr> </table>	MONTH	YEAR	February	1999
	MONTH	YEAR			
	February	1999			
<b>4. FIN OR GRANT NUMBER</b> D6227					
<b>5. AUTHOR(S)</b>  F.D'Auria, M. Frogheri*, W. Giannotti	<b>6. TYPE OF REPORT</b>  Technical				
	<b>7. PERIOD COVERED</b> <i>(Inclusive Dates)</i>				
<b>8. PERFORMING ORGANIZATION - NAME AND ADDRESS</b> <i>(If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)</i>  <table style="width: 100%;"> <tr> <td style="width: 50%;">           University of Pisa            Via Diotisalvi 2-56100            Pisa, Italy         </td> <td style="width: 50%;">           *University of Genova            DITEC            Via all'Opera Pia 15a            16143 Genova, Italy         </td> </tr> </table>			University of Pisa Via Diotisalvi 2-56100 Pisa, Italy	*University of Genova DITEC Via all'Opera Pia 15a 16143 Genova, Italy	
University of Pisa Via Diotisalvi 2-56100 Pisa, Italy	*University of Genova DITEC Via all'Opera Pia 15a 16143 Genova, Italy				
<b>9. SPONSORING ORGANIZATION - NAME AND ADDRESS</b> <i>(If NRC, type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)</i>  Office of Nuclear Regulatory Research U.S. Nuclear Regulatory Commission Washington, DC 20555-0001					
<b>10. SUPPLEMENTARY NOTES</b>					
<b>11. ABSTRACT</b> <i>(200 words or less)</i>  The present document deals with the RELAP5/MOD3.2 analysis of the small break LOCA experiment BL-34 performed in LOBI/MOD2 facility. LOBI/MOD2 was a PWR simulator (Integral Test Facility) installed at JRC Joint Research Center in Ispra Establishment (I). Volume scaling and core power scaling factors are 1/712, with respect to the KWU Siemens 1300 MWe (3900 MWt) standard reactor. The experiment is originated by a small break in the cold leg (2" equivalent break area in the plant) without the actuation of the high pressure injection system. Low pressure injection system actuation occurs after core dry-out and accumulators intervention is foreseen when primary pressure falls below 4 MPa. The RELAP5 code has been extensively used at University of Pisa; the nodalization of LOBI facility has been qualified through the application of the version RELAP5/MOD2 to the same experiment and another test performed in the same facility. Sensitivity analyses have been addressed to the influence of several parameters (like discharge break coefficient, time of accumulators start, etc.) upon the predicted transient evolution. Qualitative and quantitative code calculation accuracy evaluation has been performed.					
<b>12. KEY WORDS/DESCRIPTORS</b> <i>(List words or phrases that will assist researchers in locating the report.)</i>  RELAP5/MOD3.2 LOCA PWR	<b>13. AVAILABILITY STATEMENT</b> unlimited				
	<b>14. SECURITY CLASSIFICATION</b> <i>(This Page)</i> unclassified				
	<i>(This Report)</i> unclassified				
	<b>15. NUMBER OF PAGES</b>				
<b>16. PRICE</b>					







Federal Recycling Program



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, DC 20555-0001

---

OFFICIAL BUSINESS  
PENALTY FOR PRIVATE USE, \$300

SPECIAL STANDARD MAIL  
POSTAGE AND FEES PAID  
USNRC  
PERMIT NO. G-67