

SUMMARY STATUS UPDATE REPORT  
TVA'S COMPLIANCE TO 10CFR50.49

ENVIRONMENTAL QUALIFICATION OF ELECTRICAL  
EQUIPMENT IMPORTANT TO SAFETY FOR  
NUCLEAR POWER PLANTS

WATTS BAR NUCLEAR PLANT - UNIT 1

SEPTEMBER 1986

PREPARED BY: WBN ENVIRONMENTAL QUALIFICATION PROJECT

EQP254.01

8610090051 860930  
PDR ADOCK 05000390  
A PDR

TABLE OF CONTENTS

<u>Subject</u>	<u>Section No.</u>	<u>Volume</u>
Executive Summary	I	1
Introduction	II	1
EQ Program Description	III	1
EQ Documentation Packages (BINDER CONCEPT)	III.1	1
Methodology for Establishing 10CFR50.49 Master List	III.2	1
Design Basis Events - 10CFR50.49 (b)(1)	III.2.a	1
Environmental Data Drawings	III.2.b	1
Design Watts Bar Equipment List (WBEL)	III.2.c	1
Non-Safety-Related Equipment - 10CFR50.49 (b)(2)	III.2.d	1
Post-Accident Monitoring (PAM) - 10CFR50.49 (b)(3)	III.2.e	1
Engineering Operating Instruction Interfaces	III.2.f	1
10CFR50.49 Master Equipment List Description	III.2.g	1
Maintenance of Environmental Qualification Equipment	IV	1
Essential Maintenance, Preventative Maintenance, Surveillance	IV.1	1
Procurement/Storage	IV.2	1
Design Change Control and Binder Maintenance	IV.3	1
Upgrade Program	IV.4	1
IE Notices, Bulletins, Circulars	IV.5	1
Equipment Qualification Binder List	V	1
10CFR50.49 Master EQ Equipment List/Changes	VI	1
List of Additions since previous EEEQR Submittal	VI.1	1
List of Deletions since previous EEEQR Submittal	VI.2	1
Complete 10CFR50.49 Equipment Listing	VI.3	1
EQ Equipment Binder Documentation	VII	1-4
Copy of Equipment Binder TAB A's and TAB B's		
System Component Evaluation Work (SKEW) Sheets	VIII	4
Misc. TVA/NRC EQ Correspondence Items	IX	4
Summary of 10CFR50.49 Qualification Status	X	4
Identification of Outstanding Field Changes	X.1	4
Identification of Outstanding Technical Issues	X.2	4
WBN Environmental Drawings	XI	5

I. EXECUTIVE SUMMARY

On September 11, 1985, TVA indicated in a memo from J. A. Domer (TVA) to E. Adensam (NRC) that the final submittal update to the Watts Bar Electrical Equipment Environmental Qualification Report (EEEQR) was delayed until review and evaluation of the entire EQ program was completed. A summary of the results of TVA's Watts Bar Unit 1 EQ documentation improvement program is presented in this report.

TVA has reevaluated and updated all documentation necessary to verify compliance to 10CFR50.49 for Watts Bar Unit 1. The Watts Bar effort was basically the same as that developed and comprehensively reviewed by NRC for the Sequoyah Nuclear Plant.

This report completely supersedes the EEEQR submitted on July 24, 1984, and all elements of the upgraded EQ program fully comply with the requirements of 10CFR50.49.

This EEEQR update contains the program description, methodology, adds and deletes from previous EEEQR submittals, list of binders, outstanding binder open items and the master equipment list of all 10CFR50.49 devices contained in the Watts Bar Unit 1 EQ Program. Also included for NRC reference are copies of binder Tab A's - List of equipment contained in each binder and binder Tab B's--Checksheets for evaluation of environmental qualification including summary and conclusions. In addition, a complete copy of WBN environmental drawings and ten equipment binder SKEW sheets selected by NRC has been enclosed.

All outstanding open items enclosed and documented in each binder will be resolved and necessary revisions to the binder issued prior to initial criticality of WBN Unit 1.

## II. INTRODUCTION

TVA organized the Watts Bar Equipment Qualification Project (EQP) to evaluate and establish a quality EQ program that demonstrates full compliance with the requirements of 10CFR50.49. Inherent in the EQP objective has been the consolidation and compilation of auditable, evidence which demonstrates that all WBN EQ equipment is environmentally qualified for its application. To accomplish this objective, TVA elected to employ an EQ binder concept which documents, in one place, all data needed to support environmental qualification. Seventy-three binders have been assembled that describe environmental qualification for all WBN unit 1 10CFR50.49 equipment. It is noted that the Watts Bar program is basically the same as that implemented for the Sequoyah Nuclear Plant, and approximately 80 percent of the equipment binders contain the same equipment types and test documentation as contained in the Sequoyah program.

The purpose of this report is to provide a comprehensive summary of TVA's WBN 10CFR50.49 program to NRC to assist in the review and issue of WBN's Safety Evaluation Report (SER) for compliance to 10CFR50.49. The intent of the report is not to provide all the details contained in the EQ binders developed for WBN Unit 1, but rather to summarize their contents and explain TVA's EQ methodology and comprehensive program restructuring since previous EEEQR submittals to the NRC.

Included in this summary is a complete description of the binder process and the program for maintaining environmental qualification for the life of the plant.

### III. EQ PROGRAM DESCRIPTION

#### 1. EQ Documentation Packages (Binder Concept)

Under TVA's program for EQ, all equipment in the scope of 10CFR50.49 is evaluated for compliance with 10CFR50.49 and that evaluation is documented in an EQ Binder.

The EQ binder is a design output document and is the auditable record demonstrating compliance with 10CFR50.49 for all 10CFR50.49 scope equipment. As such, EQ binders constitute quality information and are part of the plant records which are the licensing basis for plant operation. EQ binders are permanent lifetime QA records. EQ binders are maintained current for each equipment type to demonstrate that the equipment is environmentally qualified for its application and that design basis safety functions can be accomplished. An equipment type refers to electrical equipment categorized by manufacturer and model(s) which is representative of all identical equipment in a plant area(s) potentially exposed to the same bounding environmental conditions during and after a design basis accident (e.g., Rosemount electronic pressure transmitters, Model 1153 Series D). All auditable documentation which supports environmental qualification for the equipment type shall be compiled and placed in the EQ binder or referenced therein. EQ binders reflect field-verified plant configuration for all 10CFR50.49 scope equipment.

Each EQ binder consists of:

1. Title page referring to the vendor and equipment types
2. Revision log
3. Table of contents
4. Open item and qualification deficiency listing
5. Tab A - Identification of equipment comprising the equipment type
6. Tab B - Checksheets for evaluation of environmental qualification including summary and conclusion
7. Tab C - Analyses and justification
8. Tab D - Qualification documents
9. Tab E - Miscellaneous documents and correspondence
10. Tab F - Field verification data
11. Tab G - Qualification maintenance data sheets
12. Tab H - Vendor instruction manual
13. Tab I - Vendor drawing for equipment
14. Tab J - Evaluation of IE circulars, bulletins, and vendor bulletins

Design input documents used in preparation of EQ binders include (but are not limited to) the following:

1. Design Equipment List
2. 10CFR50.49 List
3. Category and Operating Times Calculation
4. Environmental Data Drawings
5. Field Verification Data
6. Design Calculations
7. Vendor Test Reports, Correspondence, Drawings, Vendor Manuals, and Miscellaneous Vendor Contract Data

The following paragraphs summarize the contents of each tabulated section of the EQ binder:

(1) Tab A - Identification of Equipment Comprising Equipment Type

This section identifies the equipment within the scope of 10CFR50.49 comprising the equipment type. Equipment is identified by plant ID number, manufacturer, model number, location (or room number), elevation, procurement contract number, safety function, mitigating accident, equipment category, and required operating time.

(2) Tab B - EQ Checksheets for Evaluation of Environmental Qualification Including Summary and Conclusion

The "heart" of the EQ binder is Tab B, the EQ checksheet forms. These forms provide a format for addressing all EQ considerations and documenting the qualification status of 10CFR50.49 equipment.

However, the EQ checksheet forms (Tab B of the EQ binder) are intended only as a tool to assist evaluators in performing qualification evaluations to document the qualification status of electrical equipment. This form is not intended to preclude the exercise of good engineering judgement. The EQ checksheet form is designed to cover explicitly the salient points of EQ, but is not intended to be a totally comprehensive EQ checklist. Evaluators and reviewers are familiar with the criteria against which the evaluation is made. Based on a thorough understanding of the criteria, evaluators may feel justified to make defensible assumptions and engineering judgments when any EQ parameter satisfies the "intent" but not the "letter" of the criteria. All assumptions, engineering judgments, and extrapolations of data must have a sound engineering basis and be documented as part of the qualification package (i.e., the EQ binder). In certain situations, evaluators may find it necessary to augment the EQ checksheet form. In short, EQ is

(2) Tab B - EQ Checksheets for Evaluation of Environmental Qualification Including Summary and Conclusion (Continued)

not a "cookbook" process. The individual sections in Tab B of the EQ binder (checksheet form, sections A through P) may be categorized into three basic parts. First, sections A through N present factual data pertinent to qualification. Provisions are included in sections A through N for short comments and remarks necessary for clarification, but the primary content is technical data and facts. Second, section O is a checklist of questions and considerations which the evaluator considers. The checklist is representative of the types of considerations that evaluators could potentially overlook, even with all of the factual data properly documented. Because the checklist cannot be totally comprehensive, evaluators must review the qualification criteria to ensure no significant consideration is overlooked. Third, section P is a summary writeup which is to include any supplemental comments, justifications, short extrapolations of data, and discussion necessary to document that all significant EQ considerations have been addressed. The writeup is formatted so reviewers can easily ascertain the EQ checksheet sections being supplemented (e.g., each paragraph or comment might be numbered and a note referring the reader to the numbered comment would be included in the EQ checksheet section which the comment supplements). More extensive analysis and justifications (e.g., similarity analysis, aging and materials analysis, calculation of qualified life) shall be incorporated in Tab C of the EQ binder.

The overall philosophy of the three basic parts of the checksheet form is that all significant EQ questions and considerations must be addressed. If a significant EQ-related consideration is not a concern, the evaluator will still document the basis for this conclusion.

(3) Tab C - Analyses and Justification

This section contains data, calculations, and justifications that establish a qualified life for the equipment and present rationale to support elements which serve to establish qualification. All data in this section is cross-referenced to the applicable section of the EQ checksheets in Tab B.

(4) Tab D - Qualification Documents

This section contains qualification documents used to establish qualification such as test reports, analyses, and test plans.

(5) Tab E - Miscellaneous Documents and Correspondence

This section contains all pertinent reference documents, miscellaneous technical data, and correspondence relating to the qualification of the equipment type.

(6) Tab F - Field Verification Data

This section includes all field verification information (such as manufacturer, model number, location, mounting, and nameplate data) pertaining to the installed equipment.

(7) Tab G - Qualification Maintenance Data Sheets

This section contains the qualification maintenance data sheet(s) (QMDS) for the equipment items identified in Tab A. The QMDS serves a dual function in the specific environmental qualification-related maintenance requirements are identified and, if appropriate, surveillance and preventative maintenance activities are recommended based on engineering judgment and a review of documentation pertaining to the equipment. The QMDS addresses:

1. Essential Requirements -

This section of the QMDS establishes the requirements and schedule to be used for environmental qualification-related maintenance and equipment or component replacement. These requirements are essential to maintaining the environmental qualification of the equipment on a continuing basis. Requirements generally deal with critical test program details, special storage considerations, essential vendor instructions, identification of essential equipment interfaces, maintenance intervals, equipment or component replacement intervals (i.e., qualified life), and identification of certain hardware and material considerations. Documented information based upon plant operating and maintenance experience is also incorporated into this section when judged to be appropriate.

2. Recommended Surveillance Parameters and Preventative Maintenance Activities -

- a. Surveillance parameters which are judged to aid in detecting degrading materials or equipment performance. These surveillance parameters have been identified by review of the qualification documentation, evaluation of degrading mechanisms, and by the use of engineering judgment.
- b. Preventative maintenance activities and good practices for maintaining the equipment is based upon review of the vendor documentation and industry experience.

Documented information based on plant operating experience is also incorporated in this section when judged to be appropriate. The recommended surveillance parameters and preventative maintenance activities in and of themselves are not essential environmental qualification related activities; however, it is recognized that these activities are important in establishing



(7) Tab G - Qualification Maintenance Data Sheets (Continued)

equipment operatibility and ensuring proper equipment performance and must be considered within the context of an overall maintenance program.

(8) Tab H - Vendor Instruction Manual

This section contains the latest relevant vendor instruction manual (or cover sheet and appropriate sections) which would assist in the installation and maintenance of the subject equipment. Parts list and bill of materials, where available and needed, are included in this section.

(9) Tab I - Vendor Drawing for Equipment

This section contains relevant drawings (such as equipment outline drawings and installation drawings) of the equipment which would assist in providing technical information and data concerning the equipment.

(10) Tab J - Evaluation of NCR IE Circulars, Bulletins, and Vendor Bulletins

This section includes any relevant IE circulars, bulletins, notices, and vendor bulletins which are applicable to the equipment type. The resolution and disposition of the responses are also included.

III.2 Methodology for Establishing the 10CFR50.49 List

III.2.a Design Basis Events - 10CFR50.49 (b)(1)

Design Basis Events (DBEs) for 10CFR50.49 are high energy line breaks (HELBs) both inside and outside of containment and loss of coolant accident (LOCAs). Equipment in the 10CFR50.49 program was evaluated for the harsh environments through which it is required to function and/or not fail. These environments include flooding both inside and outside containment due to DBEs.

TVA has also evaluated other accidents in Chapter 15 of the WBN FSAR which do not fit the 10CFR50.49 DBA definition as interpreted above but which have the potential to produce environments more severe than those encountered during normal operation or anticipated operational occurrences. These accidents are the waste gas decay tank (WGDT) rupture, the fuel handling accident (FHA), and the steam generator tube rupture (SGTR). These three events do not produce unusual temperature or pressure environments, and the radiation environments associated with them are not significant, with the exception of the FHA in the Auxiliary building. Radiation doses to equipment necessary for mitigation of the WGDT rupture and SGTR are less than  $1 \times 10^4$  rads.

The FHA inside containment and in the auxiliary building were evaluated to determine the maximum dose to equipment due to the event. The analysis provides the conservative results of  $2 \times 10^4$  rads integrated accident dose for the upper compartment of containment and  $4.0 \times 10^4$  rads integrated accident dose at the surface of the Auxiliary Building Gas Treatment System (ABGTS) charcoal filters. These results are based on the assumption that all the release from the pool are retained within the upper containment or auxiliary building.

For the upper containment during refueling operations, the containment will either be isolated or ventilated through the Reactor Building Purge Ventilation System (RBPVS). The RBPVS is an engineered safety feature with air cleanup units (including prefilters, HEPA filters, and charcoal absorbers). The worst case is for all the radioactivity released by the ruptured fuel assembly to be released through the RBPVS to the environment.

In addition, no allowance has been made for possible holdup or mixing in the primary containment or isolation of the primary containment as a result of high radiation signals from monitors in the ventilation system. Containment isolation can only result in smaller releases to the environment and lower doses.

The resulting site boundary doses are below the limits of 10CFR100. If the RBPVS is not functioning, the site boundary doses will be less than those when the RBPVS is assumed to be functioning. Thus since the limits of 10CFR100 and standard review plan 15.7.4 are not exceeded for the FHA inside containment, the event is not considered a 10CFR50.49 DBE per the requirements in 10CFR50.49b(1).

For the FHA in the auxiliary building, the ABGTS is assumed to be functional in determining the site boundary doses for 10CFR100. If the ABGTS is not functional, the site boundary doses will exceed the 10CFR100 limits. The accident dose is  $4.0 \times 10^4$  rads at the surface of the charcoal filter. At a distance of 3.25 feet from large face and 1.75 feet from side face of the charcoal filter, the integrated accident dose drops to  $1 \times 10^4$  rads. An evaluation of Class IE devices and cable in the area of the filters will be performed to determine if any are within the zone of influence.

In summary, the 10CFR50.49 DBEs at WBN that produce harsh environments are only those events which are LOCAs, HELBs inside containment, and HELBs outside containment.

### III.2.b Environmental Data Drawings

TVA environmental data drawings are design output documents which identify and define the conditions of all harsh zones which contain 10CFR50.49 scope equipment. These harsh zones result from the design basis events described in paragraph III.2.a above. All environmental parameters necessary for design, procurement, and qualification of equipment in accordance with 10CFR50.49 are specified on these drawings. These parameters include normal,

abnormal, and accident values for temperature, pressure, relative humidity, radiation (expressed as a 40-year integrated dose and an accident dose), flooding level (due to LOCA and HELB including contribution from spray), and spray chemistry. LOCA and HELB pressure, temperature, and relative humidity profiles are provided. The environmental parameters shown on the drawings are derived from a number of supporting calculations.

III.2.c Watts Bar Equipment List - Class 1E Electrical Equipment in Harsh Environments (WBEL)

The WBEL is a compilation, for areas designated as harsh on the environmental data drawings (reference Section XI), of all safety-related equipment - 10CFR50.49b(1) (designated as Class 1E), any required nonsafety-related equipment - 10CFR50.49b(2), and any equipment added to comply with commitments to NUREG-0737 and/or NUREG 0578 and postaccident monitoring (PAM) equipment 10CFR50.49b(3). The following outlines the general methodology utilized to develop the WBEL (additional details may be found in reference 32).

1. Equipment was classified 1E if it was powered from train A, B, or (S) special power (devices powered from either train A or B), protection set instrument loops that feed the reactor protection system comprised of channels I, II, III, and IV, and special post-accident monitor equipment (PAM) required by FSAR and NUREG-0737. This information was developed from cable schedules, instrument tabulations, and equipment tabulations.
2. Harsh environment areas were identified from the Environmental Data Drawings (refer to Section III.2.b).
3. The Class 1E equipment which was located in a harsh environment were tabulated. The equipment location was determined using conduit and grounding drawings, and local panel drawings.

The WBEL includes a list of cables located in harsh environment areas which are evaluated for inclusion in the EQ program. The list includes those cables which interface with safety-related devices in harsh areas and also cables which are routed through harsh areas but interface with safety-related devices in mild environments (these latter cables are referred to as mild-harsh-mild).

The process utilized the Cable Schedule Summaries, Cable Tray Node Diagrams, and Conduit and Grounding Drawings. The cable reel numbers and contract numbers were obtained from permanent site QA records.

The compiled WBEL is issued as a quality assurance document. As stated, the WBEL is a list of safety-related (1E) electrical equipment located in harsh environments. The list was developed without regard to the function(s) of the 1E equipment. Category and operating time evaluations are provided separately for each 1E device identified on the WBEL.

These category and operating times evaluations are completed for each accident for which a device must function and include the safety function(s) for each accident, the NUREG-0588, Appendix E category for each accident, the required operating time for each category, and additional explanations as needed for the assigned categories and operating times if the safety function information does not make the rationale clear. The category and operating time evaluations are TVA design input documents and will be maintained along with the "10CFR50.49 List" to reflect the as-constructed plant. Category and operating times for cables and other passive devices like junction boxes and penetrations are not assigned directly but are dictated by the category and operating times of the devices served.

### III.2.d Non-Safety-Related Electrical Equipment - 10CFR50.49(b)(2)

Non-safety-related electrical equipment exposed to harsh accident environments must not fail in a manner that can prevent safety-related electrical equipment from performing its safety function. In response to IE Notice 79-22, non-safety-related devices were evaluated for their potential to adversely affect safety-related devices due to environmentally induced failures. Flow, control and logic diagrams for all safety-related systems were reviewed to determine all interfaces with non-safety-related equipment. Detailed wiring diagrams were used if the nature of an interface was not clear from the control and logic diagrams. Each interface with non-safety-related equipment was evaluated for its potential to adversely affect safety functions, and the results were documented. The evaluations concluded that environmental failure of non-safety-related devices interfacing with safety-related systems (or components) will not result in failure to perform the safety function.

The Engineered Safety Features Actuation System (ESFAS) was reviewed to determine if there exist any nondivisional interfaces that could impair the operation of the ESFAS. The evaluation documents that no nondivisional interfaces were identified which could preclude ESFAS operation or cause inadvertent reset.

A separate evaluation was performed to investigate the effects of accident environments on the Class 1E power systems ability to perform their functions. The design basis of the 1E power system includes protective features for coordinated selective clearing of single random faults and overloads. Most failures of non-qualified equipment from environmental causes will occur in a random fashion. The 1E power system is therefore adequately protected by its own design. Operation of this electrical protection was examined previously in analyses done to verify protection of primary containment electrical penetrations and in analyses done to identify associated circuits as defined for 10CFR50 Appendix R. For the latter an additional evaluation was performed. The protection has been shown to satisfy its design basis.

Submergence may, however, cause multiple non-qualified electrical equipment and cable terminations to fault simultaneously. This type of failure is outside the design basis of the 1E power system. Devices and junction boxes outside the scope of 10CFR50.49 exposed to submergence inside containment were identified. The effects of simultaneous faults from these circuits on the ability of the 1E power system to provide power to essential equipment were evaluated. The evaluations concluded that no degradation of the 1E power system will occur. These evaluations also evaluated the Class 1E devices outside containment which are subject to submergence from an HELB. For these devices outside containment the evaluation concluded that no degradation of the 1E power systems will occur.

Areas subject to flooding outside containment were further reviewed to determine if non-safety-related equipment subject to submergence could result in multiple faults on 1E power systems. The conclusion of the review was that none existed.

In addition to submergence, the effects of borated water spray inside containment were evaluated. This evaluation considered exposed cable terminations and terminations inside enclosures subjected to chemical spray. This evaluation concluded that the 1E power systems will not be degraded.

#### III.2.e Post-Accident Monitoring Equipment - 10CFR50.49(b)(3)

TVA will complete environmental qualification of the applicable FSAR Class 1E designed instrumentation and the FSAR PAM Instrumentation before plant startup. For those instruments already added to the plant because of our commitment to post-TMI NUREGs (-0578 and -0737), environmental qualification will be accomplished in accordance with our NUREG responses or any extension granted with respect to the NUREG responses.

Presently for that instrumentation not considered operable or not installed but which will be complete because of Regulatory Guide 1.97 Rev. 2 or post-TMI NUREG's, environmental qualification will be complete at the time of installation and operability.

#### III.2.f Emergency Operating Instruction (EOI) Interface

In response to a concern raised as part of the TVA management review of environmental qualification (EQ), TVA has investigated whether proper consideration of the equipment used in execution of Emergency Operating Instruction (EOI) requirements has been given in development of the 10CFR50.49 equipment scope. Of particular concern, the following was considered:

1. Does the plant operator have at his disposal reliable instruments to identify and mitigate the consequences of DBEs?
2. Have those instruments been marked so as to indicate their importance to the plant operator?

The NRC recognizes that all display instrumentation referenced in the emergency procedures will not necessarily be part of a utility's EQ program (reference Generic Letter No. 82-09). The WBN EQ program and main control room instrument identification practices are consistent with this philosophy.

The installed PAM indicators that support FSAR Table 7.5-1 are specifically identified to the main control room operator. The indicators are marked either P1 or P2 which indicates the function these indicators fill as PAM channel 1 or PAM channel 2. This method of marking the indicators on the main control room boards serves as the method of conveying the indicator's importance in lieu of requiring the indicators to be singled out in the plant procedures as being EQ safety-related.

These installed PAM indicators are served by instruments (e.g., transmitters, etc.) which are qualified to the 10CFR50.49 requirements, if the instrument is located in a harsh environment for the event. When other activities are implemented (i.e., NUREG 0700 and Regulatory Guide 1.97), instruments presently installed but not requiring specific identification and qualification may require upgrading.

TVA concludes that the post-accident monitoring (PAM) equipment which will be installed and qualified at plant start up provides the operator with the necessary information to identify and mitigate DBEs and are appropriately marked to indicate their importance.

### III.2.g 10CFR50.49 Master Equipment List

The 10CFR50.49 List is a compilation of data for electrical equipment which has been determined to be within the scope of 10CFR50.49 via the process beginning with the WBEL through the evaluations performed in preparing a qualification binder. (refer to Section III.1). The list will be maintained for the life of the plant as a permanent record. This maintenance will include revisions resulting from changes occurring in the plant design and configuration which impact the equipment within the scope of 10CFR50.49.

The 10CFR50.49 List (reference Section VI.3 for complete listing) presents equipment installed at time of initial criticality and as design changes are made the list will provide revised data, as needed, for the EQ equipment involved in the design change. The information available in the list identifies the device identification number, functional description, qualification binder number which documents the device qualification level (10CFR50.49 NUREG-0588 Category I or NUREG-0588 Category II), whether the device is for post-accident monitoring or to satisfy NUREG-0737 commitments, manufacturer and model number, location, and controlling operating category.

#### IV. Maintenance of Environmental Qualification

This section describes those elements of TVA's 10CFR50.49 program that assures that environmental qualification (EQ) will be maintained for the life of the plant. TVA's maintenance, surveillance, and postmaintenance testing programs have been developed encompassing operating experience, manufacturers' recommendations, the Nuclear Operational Quality Assurance Manual (N-OQAM), and the requirements of ANS-3.2/ANSI N18.7-1976. To maintain the required level of control has necessitated a number of written Division of Nuclear Engineering (DNE) and site (WBN) procedures. These procedures are not included in this report but are available for audit and are referenced here for continuity of discussion and to illustrate program detail. A list of these documents is tabulated in Table IV.1.

##### IV.1 Essential Maintenance, Preventive Maintenance, and Surveillance

TVA's program for maintaining environmental qualification (EQ) includes written procedures to address essential maintenance, preventive maintenance, and surveillance of 10CFR50.49 scope equipment. DNE's program procedures for EQ include requirements for defining special and preventive maintenance and surveillance in the EQ binder. These details (maintenance and surveillance) are specified as a result of the EQ evaluation documented in the binder in order to ensure that equipment characteristics pertinent to EQ, critical EQ related maintenance and surveillance details, equipment test configuration details pertinent to EQ (e.g., equipment qualified in vertical orientation only and with a sealed conduit), and other such data necessary to maintain a qualified status are clearly identified for site implementation. The plant has in place a maintenance program that meets the requirements for maintenance of Class 1E equipment in its normal environment including storage, installation and maintenance. Implementation of the maintenance and surveillance requirements by the site is also controlled in WBN EQ program procedure AI-1.13 and its related procedures AI-9.1 and AI-9.2.

##### IV.2 Procurement/Storage

TVA's program for EQ includes written procedures for controlling procurement activities involving 10CFR50.49 scope equipment. The special EQ aspects of DNE's procurement activities are controlled by engineering program procedures for engineering activities. Additionally, lower tier DNE documents such as standard specification SS-E18.10.01 are referenced for defining in detail EQ requirements for DNE procurement activities. AI-1.13 defines the responsibilities and requirements for the site's procurement and storage activities for 10CFR50.49 scope equipment. AI-5.1 and 5.8 detail these requirements for procurement and AI-5.2 and 5.4 detail the requirements for receiving and issuing procured materials, respectively. Any special EQ storage requirements are identified on the QMDSs in accordance with the Watts Bar Engineering Project Manual and implemented at the site in AI-5.6 in accordance with the requirements of AI-1.13.

#### IV.3 Design Change Control and Binder Maintenance

For any proposed physical design change, a scope-of-work document which explicitly estimates the impact of the change on the EQ program documents is prepared. Before formal issue of design change documents under an Engineering Change Notice (ECN), a formal checklist is completed and documented to verify any impact of the change on the EQ program documents. In conjunction with the ECN, changes are made to the EQ program documents including the 10CFR50.49 List, EQ binders, and the environmental data drawings which are all issued in an "as designed" status. When the design change is physically implemented, the "as configured" changes are verified and this verification incorporated into the EQ program documents. TVA's design change control related to maintaining qualification and 10CFR50.49 List and EQ binders maintenance is handled in accordance with the procedures referenced in Table IV.1.

#### IV.4 Upgrade Program

TVA's philosophy for EQ includes, where practical, the practice of qualifying equipment to the highest industry standards. In accordance with 10CFR50.49(1), implementation of that philosophy includes provisions in TVA's written procedures to address upgrade of equipment whose qualification criteria is less stringent than 10CFR50.49.

Aspects of TVA's EQ program which address upgrade policy in accordance with AI-1.13 are detailed in AI-5.11 and AI-9.1 and include:

- o Identification of all devices qualified to NUREG-0588, category II, requirements (i.e., candidates for upgrade).
- o Failure and trends evaluations to help determine need to replace (i.e., upgrade).
- o Upgrade of replacement devices for Category II unless sound reasons to the contrary (see R.G. 1.89) are documented.

#### IV.5 IE Notices, Bulletins, Circulars

TVA has identified all NRC generic letters, circulars, information notices, and bulletins which have the potential to impact the equipment qualification program. The bulletins, circulars, etc., were identified by performing a search of the NUS Corporation's Licensing Information Service (LIS) data base and TVA's own



licensing library files. The affected documents were then categorized into equipment types (i.e., valves, motors, switches, relays, cable) and each have been addressed in the binder for the affected equipment type as described in Section III.1. The binder includes and references the NRC documents and any required responses or resolutions as appropriate. TVA's methods for changing EQ documentation to reflect current IE Notices, circulars, bullentins, etc., over the life-of-the plant are described by the procedures listed in Table IV.1.

TABLE IV.1

I. DESIGN CONTROLS

A. Nuclear Engineering Division Procedures

NEP - 1.3	Records Control
NEP - 2.1	Licensing Support
NEP - 3.1	Calculations
NEP - 3.2	Design Input
NEP - 4.1	Procurement
NEP - 5.1	Design Output
NEP - 6.1	Change Control
NEP - 9.1	Corrective Action

B. Watts Bar Engineering Project - Project Manual WBEP-PM

The EQ Project Manual (EQP-01) will have been incorporated into the WBEP Project Manual by October 31, 1986.

II. OPERATIONAL CONTROLS

A. Administrative Instructions Manual

<u>INST NO.</u>	<u>TITLE</u>
AI-1.13	10CFR50.49 Environmental Qualification Program
AI-1.14	10CFR50.49 Equipment List and EQ Binder Control
AI-1.15	EQIS Data Entry Control
AI-3.1	Plant Instructions - Control and Use
AI-4.4	Vendor Manual Control
AI-4.8	Controlled Documents
AI-5.1	Material Procurement and Control
AI-5.2	Receipt Inspection of Materials, Components, and Spare Parts
AI-5.4	Material Issue, Transfer & Traceability

II. OPERATIONAL CONTROLS (Continued)

A. Administrative Instructions Manual (Continued)

<u>INST NO.</u>	<u>TITLE</u>
AI-5.6	Material Storage, Handling, and Shipping Requirements for WBN
AI-5.8	Procurement Specifications for Class 1E Electrical Equipment and Instrumentation and Maintenance Requirements
AI-5.11	Environmental Qualification Category 2 Upgrade Program
AI-8.5	Control of Modification Work on Transferred Systems before Unit Licensing
AI-8.8	Control of Modification Work After Unit Licensing
AI-9.1	Watts Bar Nuclear Plant Maintenance Program
AI-9.2	Maintenance Requests and Equipment Maintenance History
AI-9.8	Drilling, Cutting, Chipping, and Excavating
AI-9.9	Torch Cutting, Welding, Open-Flame, Grinding, and Spark-Producing Work Permit
AI-9.12	Aromatic of Ester Hydrocarbon Release Permit (Painting, Cleaning, Sealing, Torch Cutting or Welding)
AI-9.19	Environmental Qualification Deviations
AI-10.1	Plant Training Program

B. Standard Practices Manual

WB6.1.5	Approved Cleaning Solvents for Both Plastics and Electrical Equipment Containing No Plastic Parts
WB6.2.2	Use of Corrosive Silicone Sealants in Electrical/Electronic Applications
WB6.3.13	Nuclear Operations Experience Review Program
WB7.3.1	Lubrication
WB11.7	Potential Reportable Occurrences

V. WATTS BAR EQUIPMENT QUALIFICATION BINDER LIST

Note: The following codes apply to the "Comment" field only.

- A. Binder has been added since August 12, 1986.
- D. Binder has been deleted (no longer required) since August 12, 1986.
- R. Binder is a "roll over," i.e., the binder has the same manufacturer, type of equipment and the same test reports as a SQN binder.

<u>Package Number</u>	<u>Comment</u>	<u>Type of Equipment</u>	<u>Vendor</u>
(1) SOL-001	R	SOLENOID OPERATED VALVES TARGET ROCK FOR NSSS SYSTEMS	TARGET ROCK
(2) SOL-002	R	SOLENOID OPERATED VALVES TARGET ROCK FOR B.O.P. SYSTEMS	TARGET ROCK
(3) SOL-003	R	SOLENCID OPERATED VALVES - ASCO MODEL 206-381	ASCO
(4) SOL-004	R	MSIV AIR MANIFOLD ASSEMBLY/ SOLENOID OPERATED VALVES	GOULD ALLIED
(5) SOL-005	R	SOLENOID OPERATED VALVES - ASCO MODEL 206-380	ASCO
(6) SOL-006	R	SOLENOID OPERATED VALVES - ASCO MODEL NP8316	ASCO
(7) SOL-007		SOLENOID OPERATED VALVES - ASCO MODEL NP8320	ASCO
(8) MOV-001	R	MOTORIZED VALVE ACTUATORS WITH TYPE RH INSULATION	LIMITORQUE
(9) MOV-002	R	MOTORIZED VALVE ACTUATORS LOCATED IN VALVE VAULTS	LIMITORQUE
(10) MOV-003		MOTORIZED VALVE ACTUATORS WITH CLASS B INSULATION	LIMITORQUE
(11) MOT-001	R	LARGE ELECTRIC INDUCTION MOTORS - OUTSIDE CONTAINMENT	WESTINGHOUSE
(12) MOT-002	R	ELECTRIC INDUCTION MOTOR WITH TYPE RH INSULATION - INSIDE CONTAINMENT	JOY FAN/RELIANCE ELECTRIC
(13) MOT-003		ELECTRIC INDUCTION MOTORS WITH TYPE RH INSULATION - OUTSIDE CONTAINMENT	RELIANCE
(14) MOT-004		ELECTRIC SQUIRREL CAGE INDUCTION MOTOR - OUTSIDE CONTAINMENT	LOUIS ALLIS

V. WATTS BAR EQUIPMENT QUALIFICATION BINDER LIST

<u>Package Number</u>	<u>Comment</u>	<u>Type of Equipment</u>	<u>Vendor</u>
(15) CABL-002	R	LOW VOLTAGE POWER AND CONTROL - EDPM INS/TVA TYPES PXJ AND PXMJ	AIW
(16) CABL-003	R	LOW VOLTAGE POWER AND CONTROL - XLPE INS/TVA TYPES PXJ AND PXMJ	AIW
(17) CABL-005	R	MEDIUM VOLTAGE POWER - EPR INS/ TVA TYPE EPSJ	ANACONDA
(18) CABL-006	R	SIGNAL CABLE - FR-EP/TVA TYPE MS	ANACONDA
(19) CABL-008	R	LOW VOLTAGE POWER AND CONTROL - EPR INS/TVA TYPE PXMJ	ANACONDA
(20) CABL-009	D	LOW VOLTAGE POWER AND CONTROL - SILICONE RUBBER INS/TVA TYPE SROAJ, SROAJH	ANACONDA
(21) CABL-010	R	SIGNAL CABLE - XLPE INS/TVA TYPE MS	BELDEN
(22) CABL-012	R	SIGNAL CABLE - XLPE INS/TVA TYPE MS	BRAND REX
(23) CABL-013	R	SIGNAL CABLE - TEFZEL INS/TVA TYPE ETFE	CAROLINA W&C
(24) CABL-015	R	LOW VOLTAGE POWER AND CONTROL - PE INS/TVA TYPE PJJ	CYPRUS
(25) CABL-017	R	SIGNAL CABLE - XLPO INS/TVA TYPE MS	EATON
(26) CABL-019	D	LOW VOLTAGE POWER AND CONTROL - PE INS/TVA TYPES PXMJ, PXJ	ESSEX
(27) CABL-022	R	LOW VOLTAGE POWER AND CONTROL - XLPE INS/TVA TYPES PXMJ, PXJ	ESSEX
(28) CABL-027	R	MEDIUM VOLTAGE POWER - EPR INS/ TVA TYPE EPSJ	OKONITE
(29) CABL-032	R	LOW VOLTAGE POWER AND CONTROL - XLPE INS/TVA TYPES CPJ AND CPJJ	PWC
(30) CABL-033	A,R	MEDIUM VOLTAGE POWER - XLPE INS/TVA TYPE CPSJ	TRIANGLE PWC

V. WATTS BAR EQUIPMENT QUALIFICATION BINDER LIST

<u>Package Number</u>	<u>Comment</u>	<u>Type of Equipment</u>	<u>Vendor</u>
(31) CABL-034	D	MEDIUM VOLTAGE POWER - XLPE INS/ TVA TYPE PJJ	PWC
(32) CABL-036	R	LOW VOLTAGE POWER AND CONTROL - SILICONE RUBBER INS/TVA TYPES SROAJ, SROAJH	ROCKBESTOS
(33) CABL-037	A,R	SIGNAL CABLE - KXL760D-CXLPE INS/TVA TYPE MS	ROCKBESTOS
(34) CABL-040	D	SIGNAL CABLE -TPR INS/TVA TYPE MS	TIMES W & C
(35) CABL-042		COAX - XLPE INS/TVA TYPE COAX	BRAND REX
(36) CABL-043	R	LOW VOLTAGE POWER AND CONTROL - EPR INS/TVA TYPE PXMJ	OKONITE
(37) CABL-044	R	INSULATED SWITCHBOARD WIRE - RXLPE INS (KXL760G)/TVA TYPE SIS	ROCKBESTOS
(38) CABL-047	R	SIGNAL CABLE - TEFZEL INS/TVA TYPE ETFE	TELEDYNE
(39) CABL-048	D	LOW VOLTAGE POWER AND CONTROL - XLPE INS/TVA TYPES CPJ AND CPJJ	ROME
(40) CABL-049	R	SIGNAL CABLE - CXLPE INS (KXL780)/TVA TYPE MS AND PXMJ	ROCKBESTOS
(41) CABL-061		COAX - XLPE INS/TVA TYPE COAX	ROCKBESTOS
(42) CABL-063		LOW VOLTAGE POWER AND CONTROL - EPR INS/ TVA TYPE PXJ	OKONITE
(43) CABL-064	A	MEDIUM VOLTAGE POWER-EPR INS/TYA TYPE EPSJ	COLLYER
(44) TB-001	R	TERMINAL BLOCKS	GENERAL ELECTRIC
(45) JBOX-001	R	JUNCTION BOXES	VARIOUS
(46) CSC-001	R	ELECTRIC CONDUCTOR CONDUIT SEAL ASSEMBLIES (ECSA)	CONAX CORPORATION

V. WATTS BAR EQUIPMENT QUALIFICATION BINDER LIST

<u>Package Number</u>	<u>Comment</u>	<u>Type of Equipment</u>	<u>Vendor</u>
(47) PENT-001		PRIMARY CONTAINMENT MEDIUM VOLTAGE POWER ELECTRICAL PENETRATIONS	CONAX CORPORATION
(48) PENT-002		PRIMARY CONTAINMENT ELECTRICAL PENETRATION, LOW VOLTAGE POWER AND CONTROL	CONAX CORPORATION
(49) PENT-003		PRIMARY CONTAINMENT ELECTRICAL PENETRATIONS, INSTRUMENTATION AND INDICATION	CONAX CORPORATION
(50) PENT-004	R	PERSONNEL ACCESS AIRLOCK ELECTRICAL PENETRATIONS	CONAX CORPORATION
(51) HS-001		HANDSWITCHES	SQUARE D
(52) SPLC-001	R	HEAT SHRINK CABLE SPLICES (600 VAC OR LESS)	RAYCHEM
(53) BKRA-002		MOLDED CASE CIRCUIT BREAKERS	ITE, SQUARE D & WESTINGHOUSE
(54) XMTR-001	R	TRANSMITTER	BARTON 764, LOT 7 & 4
(55) XMTR-003	R	TRANSMITTER	ROSEMOUNT
(56) XMTR-004	R	TRANSMITTER	BARTON 763, LOT 7
(57) ITE-002	R	RTDs	ROSEMOUNT
(58) ITE-003		RESISTANCE TEMPERATURE DETECTOR (RCS WELL-MOUNTED)	RdF
(59) ITS-001	R	TEMPERATURE SWITCHES	FENWAL
(60) ITS-002	R	TEMPERATURE SWITCHES	STATIC-O-RING
(61) HTR-001	R	ELECTRIC HEATERS/HYDROGEN RECOMBINERS	WESTINGHOUSE
(62) ILP-001	R	HYDROGEN ANALYZERS	COMSIP DELPHI

V. WATTS BAR EQUIPMENT QUALIFICATION BINDER LIST

<u>Package Number</u>	<u>Comment</u>	<u>Type of Equipment</u>	<u>Vendor</u>
(63) ILT-001	R	E13DM PRESSURE TRANSMITTER	FOXBORO
(64) IXT-001	R	TEC MODEL 504A CHARGE CONVERTER ENDEVCO MODEL 2273A ACCELEROMETER TEC ACOUSTIC VALVE FLOW MONITORING SYSTEM	TEC
(65) IFS-001	R	FLOW SWITCHES	FCI
(66) IRE-001	R	RADIATION MONITORS	GENERAL ATOMIC CO.
(67) ILM-001	D	ELECTROPNEUMATIC TRANSDUCER - 8005	MASONELIAN
(68) ILCV-001	R	ELECTROPNEUMATIC VALVE POSITIONER	MASONELIAN
(69) IZS-001	R	EA180 SERIES LIMIT SWITCHES MANUFACTURED AFTER 7/30/80	NAMCO
(70) IZS-002	R	EA180 SERIES LIMIT SWITCHES MANUFACTURED BETWEEN 9/5/78 AND 7/30/80	NAMCO
(71) IZS-003	R	EA740 LIMIT SWITCHES MANUFACTURED AFTER OCTOBER 1, 1981	NAMCO
(72) IZS-004	R	EA740 LIMIT SWITCHES MANUFACTURED BETWEEN FEBRUARY 20, 1978 AND OCTOBER 1, 1981	NAMCO
(73) IMIK-001	R	HEATER AND HEATER CONTROLS	NUTHERM
(74) IPT-001	R	PRESSURE TRANSMITTERS	WESTINGHOUSE
(75) IPT-002	R	PRESSURE TRANSMITTERS	FOXBORO
(76) ITE-001	R	STRAP-ON RTD	WESTINGHOUSE (MINCO)
(77) ITE-004		RESISTANCE TEMPERATURE DETECTOR (FAST RESPONSE WELL-MOUNTED)	RdF
(78) ITE-005		INCORE THERMOCOUPLE	WESTINGHOUSE
(79) GEN-001		GENERIC BINDER	TVA



VI. 10CFR50.49 MASTER EQ EQUIPMENT LIST/CHANGES

Subsequent to previous EEEQR submittals of the WBN 10CFR50.49 equipment list, a number of deletions and additions to that list have been made. For record purposes and as an aid to track changes, Table VI.2 provides a list of devices for deletions made since previous EEEQR submittals, references previous submittal EQS numbers, and defines the status category for each deletion. The description of equipment deletion status categories referenced in this table are as follows:

a. Mild Environment

Equipment not within the scope of 10CFR50.49. The equipment has been reevaluated and been determined to be in a mild environment for the accident it is required to mitigate.

b. NUREG-0588, Category C

Equipment not within the scope of 10CFR50.49. This equipment will experience environmental conditions of design basis accidents through which it need not function for mitigation of said accidents, and whose failure (in any mode) is deemed not detrimental to plant safety or accident mitigation, and need not be qualified for any accident environment, but will be qualified for its non-accident service environment.

c. Equipment not in the Scope of 10CFR50.49

This equipment has been determined not to be within the scope of 10CFR50.49 because the equipment does not perform a safety-related function, equipment was replaced with nonelectrical devices, or the equipment was removed from safety circuit, etc.

Table VI.1 lists equipment that has been added because of required modifications and engineering changes. The following types of equipment were treated generically in previous submittals and have been included in Table VI.3, and therefore, are not listed in Table VII.2 as equipment that has been added to the program:

Terminal Blocks	Cable splices
Handswitches	Penetrations (all types)
Cable (all types)	Conduit Seal Assemblies
Junction boxes	

All this equipment is listed in the 10CFR50.49 master list located in Table VI.3 of this section. Table VI.3 also lists, for reference to previous EEEQR submittals, the equipment qualification sheet (EQS) number where applicable. This updated 10CFR50.49 master list supersedes previous TVA submittals.

VI.1 TABLE OF ADDITIONS

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER
1-FT -003-0147A	-A	SG3 AFW FLOW TRANSMITTER	WBNEQ-IPT -001
1-FT -003-0147B	-B	SG3 AFW FLOW TRANSMITTER	WBNEQ-IPT -001
1-FT -003-0155A	-A	SG2 AFW FLOW TRANSMITTER	WBNEQ-IPT -001
1-FT -003-0155B	-B	SG2 AFW FLOW TRANSMITTER	WBNEQ-IPT -001
1-FT -003-0163A	-A	SG1 AFW FLOW TRANSMITTER	WBNEQ-IPT -001
1-FT -003-0163B	-B	SG1 AFW FLOW TRANSMITTER	WBNEQ-IPT -001
1-FT -003-0170A	-A	SG4 AFW FLOW TRANSMITTER	WBNEQ-IPT -001
1-FT -003-0170B	-B	SG4 AFW FLOW TRANSMITTER	WBNEQ-IPT -001
1-ZS -030-0003/1	-A	INTERIM ABSCE VALVE POS SW	WBNEQ-1ZS -001
1-ZS -030-0003/2	-A	INTERIM ABSCE VALVE POS SW	WBNEQ-1ZS -001
1-ZS -030-0006/1	-B	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001
1-ZS -030-0006/2	-B	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001
1-FSV -030-0013	-A	INTERIM ABSCE ISLN VALVE	WBNEQ-SOL -003
1-ZS -030-0013/1	-A	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001
1-ZS -030-0013/2	-A	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001
1-FSV -030-0018	-B	INTERIM ABSCE ISLN VALVE	WBNEQ-SOL -003
1-ZS -030-0018/1	-B	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001

VI.1 TABLE OF ADDITIONS

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER
1-ZS -030-0018/2 -B	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001
1-ZS -030-0076/1 -A	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001
1-ZS -030-0076/2 -A	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001
1-ZS -030-0091/1 -A	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001
1-ZS -030-0091/2 -A	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001
1-FCO -030-0107/ZS1 -B	PURGE AIR SUP TR B ISLN DMPR POS SW	WBNEQ-1ZS -001
1-FCO -030-0107/ZS2 -B	PURGE AIR SUP TR B ISLN DMPR POS SW	WBNEQ-1ZS -001
1-ZS -030-0115/1 -A	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001
1-ZS -030-0115/2 -A	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001
1-ZS -030-0117/1 -A	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001
1-ZS -030-0117/2 -A	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001
1-ZS -030-0118/1 -B	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001
1-ZS -030-0118/2 -B	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001
1-ZS -030-0119/1 -A	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001
1-ZS -030-0119/2 -A	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001
1-ZS -030-0120/1 -B	INTERIM ABSCE ISOL VALVE POS SWITCH	WBNEQ-1ZS -001
1-ZS -030-0120/2 -B	INTERIM ABSCE ISOL VALVE POS SWITCH	WBNEQ-1ZS -001

VI.1 TABLE OF ADDITIONS

TVA DEVICE ID			DESCRIPTION	BINDER NUMBER
1-ZS -030-0121/1	-A		INTERIM ABSCE ISOL VALVE POS SWITCH	WBNEQ-1ZS -001
1-ZS -030-0121/2	-A		INTERIM ABSCE ISOL VALVE POS SWITCH	WBNEQ-1ZS -001
1-ZS -030-0124/1	-B		INTERIM ABSCE ISOL VALVE POS SWITCH	WBNEQ-1ZS -001
1-ZS -030-0124/2	-B		INTERIM ABSCE ISOL VALVE POS SWITCH	WBNEQ-1ZS -001
1-ZS -030-0125/1	-A		INTERIM ABSCE ISOL VALVE POS SWITCH	WBNEQ-1ZS -001
1-ZS -030-0125/2	-A		INTERIM ABSCE ISOL VALVE POS SWITCH	WBNEQ-1ZS -001
1-ZS -030-0128/1	-B		INTERIM ABSCE ISOL VALVE POS SWITCH	WBNEQ-1ZS -001
1-ZS -030-0128/2	-B		INTERIM ABSCE ISOL VALVE POS SWITCH	WBNEQ-1ZS -001
1-TS -030-0143	-A		TEMPERATURE SWITCH-THERMAL CUTOUT	WBNEQ-1MIK-001
1-FS -030-0146	-B		AIR FLOW SWITCH	WBNEQ-1MIK-001
0-MTR -030-0146	-A		ABGTS FAN MOTOR A-A	WBNEQ-MOT -003
1-FSV -030-0146A	-A		AUX BLDG GAS TMT FAN A-A SUCT DMPR	WBNEQ-SOL -005
1-FSV -030-0146B	-A		AUX BLDG GAS TMT FAN A-A SUCT DMPR	WBNEQ-SOL -005
2-TS -030-0155	-B		TEMPERATURE SWITCH-THERMAL CUTOUT	WBNEQ-1MIK-001
2-FS -030-0157	-A		AIR FLOW SWITCH	WBNEQ-1MIK-001
1-MTR -030-0175	-A		RHR PUMP ROOM 1A-A COOLER FAN MOTOR	WBNEQ-MOT -003
1-MTR -030-0176	-B		RHR PUMP ROOM 1B-B COOLER FAN MOTOR	WBNEQ-MOT -003
1-MTR -030-0177	-A		CTM SPR PUMP RM 1A-ACOOER FAN MOTOR	WBNEQ-MOT -003

VI.1 TABLE OF ADDITIONS

<u>TVA DEVICE ID</u>		<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>
1-MTR -030-0178	-B	CTM SPR PUMP RM 1B-BCOOLER FAN MOTOR	WBNEQ-MOT -003
1-MTR -030-0179	-B	SIS PUMP ROOM 1B-B COOLER FAN MOTOR	WBNEQ-MOT -003
1-MTR -030-0180	-A	SIS PUMP ROOM 1A-A COOLER FAN MOTOR	WBNEQ-MOT -003
1-MTR -030-0182	-B	CEN CHR PUMP RM 1B-BCOOLER FAN MOTOR	WBNEQ-MOT -003
1-MTR -030-0183	-A	CEN CHG PUMP RM 1A-ACOOLER FAN MOTOR	WBNEQ-MOT -003
1-MTR -030-0194	-A	EL 737 PENETRATION ROOM COOLER	WBNEQ-MOT -004
2-MTR -030-0194	-A	EL 737 PENETRATION ROOM COOLER	WBNEQ-MOT -004
1-MTR -030-0195	-B	EL 737 PENETRATION ROOM COOLER	WBNEQ-MOT -004
2-MTR -030-0195	-B	EL 737 PENETRATION ROOM COOLER	WBNEQ-MOT -004
1-MTR -030-0196	-A	EL 713 PENETRATION ROOM COOLER	WBNEQ-MOT -004
1-MTR -030-0197	-B	EL 713 PENETRATION ROOM COOLER	WBNEQ-MOT -004
2-MTR -030-0200	-A	EGTS COOLER FAN	WBNEQ-MOT -004
2-TS -030-0200A	-A	EGTS COOLER FAN	WBNEQ-ITS -002
1-TS -030-0201A	-A	PIPE CHASE COOLERS FAN	WBNEQ-ITS -002
1-TS -030-0201B	-A	PIPE CHASE COOLERS FAN	WBNEQ-ITS -002
1-TS -030-0202A	-B	PIPE CHASE COOLERS FAN	WBNEQ-ITS -002
1-TS -030-0202B	-B	PIPE CHASE COOLERS FAN	WBNEQ-ITS -002
2-MTR -030-0207	-B	EGTS COOLER FAN	WBNEQ-MOT -004

VI.1 TABLE OF ADDITIONS

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER
2-TS -030-0207A	-B	EGTS COOLER FAN	WBNEQ-ITS -002
1-FSV -030-0296	-A	INTERIM ISOL DAMPER CDWE	WBNEQ-SOL -003
1-FCO -030-0296/ZS1	-A	INTERIM ISOL DAMPER CDWE POS SWITCH	WBNEQ-IZS -001
1-FCO -030-0296/ZS2		INTERIM ISOL DAMPER CDWE POS SWITCH	WBNEQ-IZS -001
1-FSV -030-0297	-B	INTERIM ISOL DAMPER CDWE	WBNEQ-SOL -003
1-FCO -030-0297/ZS1	-B	INTERIM ISOL DAMPER CDWE POS SWITCH	WBNEQ-IZS -001
1-FCO -030-0297/ZS2	-B	INTERIM ISOL DAMPER CDWE POS SWITCH	WBNEQ-IZS -001
1-FSV -030-0298	-B	INTERIM ISOL DAMPER CDWE	WBNEQ-SOL -003
1-FCO -030-0298/ZS1	-B	INTERIM ISOL DAMPER CDWE POS SWITCH	WBNEQ-IZS -001
1-FCO -030-0298/ZS2	-B	INTERIM ISOL DAMPER CDWE POS SWITCH	WBNEQ-IZS -001
1-FSV -030-0299	-A	INTERIM ISOL DAMPER CDWE	WBNEQ-SOL -003
1-FCO -030-0299/ZS1	-A	INTERIM ISOL DAMPER CDWE POS SWITCH	WBNEQ-IZS -001
1-FCO -030-0299/ZS2	-A	INTERIM ISOL DAMPER CDWE POS SWITCH	WBNEQ-IZS -001
1-H2E -043-0200	-A	LOCA H2 CONTAINMENT MONITOR ELEMENT	WBNEQ-ILP -001
1-HS -043-0200D	-A	LOCA H2 CNTMT MON FAN SW	WBNEQ-ILP -001
1-H2E -043-0210	-B	LOCA H2 CONTAINMENT MONITOR ELEMENT	WBNEQ-ILP -001
1-HS -043-0210D	-B	LOCA H2 CNTMT MON FAN SW	WBNEQ-ILP -001
1-ZS -063-0003	-A	SIS PMP RECIRC TO RWST VLV ZONE SWITCH	WBNEQ-IZS -001

VI.1 TABLE OF ADDITIONS

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER
1-ZS -063-0004	-B	SIS PMP RECIRC TO RWST VLV ZONE SWITCH	WBNEQ-1ZS -001
1-ZS -063-0175	-B	SIS PMP 1B-B DISCH RWST SHTOFF POS SW	WBNEQ-1ZS -001
2-FSV -065-0004	-B	CNTMT ANN VAC FAN ISLN DMPR	WBNEQ-SOL -007
2-FCV -065-0004/ZS1	-B	CNTMT ANN VAC FANS ISOL DMPR POS SW	WBNEQ-1ZS -001
2-FCV -065-0004/ZS2	-B	CNTMT ANN VAC FANS ISOL DMPR POS SW	WBNEQ-1ZS -001
2-FSV -065-0005	-A	CNTMT ANN VAC FANS ISLN DMPR	WBNEQ-SOL -007
2-FCV -065-0005/ZS1	-A	CNTMT ANN VAC FANS ISOL DMPR POS SW	WBNEQ-1ZS -001
2-FCV -065-0005/ZS2	-A	CNTMT ANN VAC FANS ISOL DMPR POS SW	WBNEQ-1ZS -001
2-FSV -065-0007	-B	EGTS TRAIN A UNIT 2 SUCTION	WBNEQ-SOL -003
2-FSV -065-0009	-A	EGTS TRAIN A UNIT 2 SUCTION	WBNEQ-SOL -007
1-FCV -065-0052/ZS1	-A	CNTMT ANN VAC FANS ISLN VALVE POS SW	WBNEQ-1ZS -001
1-FCV -065-0052/ZS2	-A	CNTMT ANN VAC FANS ISLN VALVE POS SW	WBNEQ-1ZS -001
1-FCV -065-0053/ZS1	-B	CNTMT ANN VAC FANS ISLN VALVE POS SW	WBNEQ-1ZS -001
1-FCV -065-0053/ZS2	-B	CNTMT ANN VAC FANS ISLN VALVE POS SW	WBNEQ-1ZS -001
1-PT -068-0063	-D	LOOP 1 HOT LEG PRESS	WBNEQ-XMTR-004
1-PT -068-0064	-E	REAC COOL LOOP 3 HOT LEG PRESSURE XMTR	WBNEQ-1PT -001
1-FSV -070-0085	-B	EXCESS LETDN HTX OUTLET VALVE	WBNEQ-SOL -003
1-FCV -070-0183	-A	SAMPLE HTX HDR OUTLET VALVE	WBNEQ-MOV -003

VI.1 TABLE OF ADDITIONS

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER
1-FCV -070-0215	-A	SAMPLE HX INLET ISLNVALVE	WBNEQ-MOV -003
1-FT -070-0215A	-A	SAMPLE HTX HDR INLET FLOW	WBNEQ-XMTR-003
1-FT -070-0215B	-A	SAMPLE HTX HDR OUTLET FLOW	WBNEQ-XMTR-003
1-FCV -072-0021	-B	RWST TO SPRAY HDR B FLOW CONTROL VALVE	WBNEQ-MOV -003
1-FCV -072-0022	-A	RWST TO SPRAY HDR A FLOW CONTROL VALVE	WBNEQ-MOV -003
1-ZS -072-0040	-A	RHR SPRAY HDR A ISOLVLV STEM POS SWITCH	WBNEQ-IZS -001
1-ZS -072-0041	-B	RHR SPRAY HDR B ISOLVLV STEM POS SWITCH	WBNEQ-IZS -001
1-ZS -072-0044	-A	CNTMT SMP TO HDR A FCV POS SW	WBNEQ-IZS -002
1-ZS -072-0045	-B	CNTMT SMP TO HDR B FCV POS SW	WBNEQ-IZS -002
1-TS -074-0043	-A	RHR RETURN LINE BREAK DETECTION	WBNEQ-ITS -002
1-TS -074-0044	-A	RHR RETURN LINE BREAK DETECTION	WBNEQ-ITS -002
1-TS -074-0045	-B	RHR RETURN LINE BREAK DETECTION	WBNEQ-ITS -002
1-TS -074-0046	-B	RHR RETURN LINE BREAK DETECTION	WBNEQ-ITS -002
1-FCV -077-0020/ZS1	-A	RCDT N2 SUP FCV POS SWITCH	WBNEQ-IZS -001
1-FCV -077-0020/ZS2	-A	RCDT N2 SUP FCV POS SWITCH	WBNEQ-IZS -001
1-FSV -077-0128	-A	REAC BLDG SUMP DISCHFLOW SOL VALVE	WBNEQ-SOL -003
1-FCV -077-0128/ZS1	-A	REACTOR BLDG SUMP DISCH FCV LIMIT SW	WBNEQ-IZS -003



VI.1 TABLE OF ADDITIONS

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>
1-FCV -077-0128/ZS2 -A	REACTOR BLDG SUMP DISCH FCV LIMIT SW	WBNEQ-1ZS -003
1-PNL -094-0008/A -D	INCORE THERMOCOUPLE REFERENCE JCT BOX	WBNEQ-ITE -005
1-PNL -094-0008/B -E	INCORE THERMOCOUPLE REFERENCE JCT BOX	WBNEQ-ITE -005
0-DPL -234-0001/WDS	CIRCUIT BREAKER	WBNEQ-BKRA-002
0-DPL -234-0002/WDS	CIRCUIT BREAKER	WBNEQ-BKRA-002

VI.2 TABLE OF DELETIONS

TVA DEVICE ID		EQS NUMBER	MILD	CAT C	NOT IN 10CFR50.49 PROGRAM SCOPE
1-PT -001-0005		NEB-1-40		X	
1-PT -001-0012		NEB-XX-48	X		
1-PT -001-0023		NEB-XX-48	X		
1-PT -001-0030		NEB-1-40		X	
1-FCV -001-0147	(LS)	EEB0056		X	
1-FCV -001-0148	(LS)	EEB0056		X	
1-FCV -001-0149	(LS)	EEB0056		X	
1-FCV -001-0150	(LS)	EEB0056		X	
1-FCV -003-0116A		MEB-3-0113	X		
1-FCV -003-0116B		MEB-3-0113	X		
1-MTR -003-0118A		EEB-MTR-1	X		
1-PDT -003-0122A	-A	EEB0072	X		
1-PM -003-0122		EEB0023	X		
1-FCV -003-0126A		MEB-3-0113	X		
1-FCV -003-0126B		MEB-3-0113	X		
1-MTR -003-0128B		EEB-MTR-1	X		
1-PM -003-0132		EEB0023	X		
1-PDT -003-0132A	-B	EEB0072	X		
1-FCV -003-0136A		MEB-3-0114	X		
1-FCV -003-0136B		MEB-3-0114	X		
1-PS -003-0139A		EEB0016	X		
1-PS -003-0139B		EEB0016	X		
1-PS -003-0139D		EEB0016	X		
1-PS -003-0140A		EEB0016			X
1-PS -003-0144A		EEB0016	X		

VI.2 TABLE OF DELETIONS

TVA DEVICE ID	EQS NUMBER	MILD	CAT C	NOT IN 10CFR50.49 PROGRAM SCOPE
1-PS -003-0144B	EEB0016	X		
1-PS -003-0144D	EEB0016	X		
1-LSV -003-0148	EEB0029	X		
1-PS -003-0148	EEB0091	X		
1-LM -003-0148A	EEB0038	X		
1-LSV -003-0148A	EEB0035	X		
1-PS -003-0150A	EEB0016			X
1-LSV -003-0156	EEB0029	X		
1-PS -003-0156	EEB0091	X		
1-LM -003-0156A	EEB0038	X		
1-LSV -003-0156A	EEB0035	X		
1-LSV -003-0164	EEB0029	X		
1-PS -003-0164	EEB0091	X		
1-LM -003-0164A	EEB0038	X		
1-LSV -003-0164A	EEB0035	X		
1-LSV -003-0171	EEB0029	X		
1-PS -003-0171	EEB0091	X		
1-LM -003-0171A	EEB0038	X		
1-LSV -003-0171A	EEB0035	X		
1-LSV -003-0172	EEB0029	X		
1-LSV -003-0173	EEB0029	X		
1-FCV -003-0179A	MEB-3-0114	X		
1-FCV -003-0179B	MEB-3-0114	X		
0-FSV -012-0079	EEB0049			X
0-FSV -012-0082	EEB0049			X

VI.2 TABLE OF DELETIONS

TVA DEVICE ID	EQS NUMBER	MILD	CAT C	NOT IN 10CFR50.49 PROGRAM SCOPE
1-FCV -026-0240	MEB-26-0115	X		
2-FSV -030-0022	NO EQS NUMBER	X		
2-FSV -030-0109	MEB-30-0005	X		
0-MTR -030-0146A	MEB-30-0017			X
1-FS -030-0147	NOT INSTALLED			X
1-TS -030-0147A	NOT INSTALLED			X
1-TS -030-0147B	NOT INSTALLED			X
1-TS -030-0147D	NOT INSTALLED			X
2-MTR -030-0157B	MEB-30-0018			X
1-MTR -030-0190	MEB-30-0013	X		
1-MTR -030-0191	MEB-30-0013	X		
1-FE -030-0194	EEB0015			X
1-FE -030-0195	EEB0015			X
1-FE -030-0196	EEB0080			X
1-FE -030-0197	EEB0080			X
1-TS -030-0214	-S EEB0079		X	
1-STR -046-0056A	EEB-STR-1	X		
1-XS -046-0057	EEB-XS-1	X		
1-SW -046-00AC	EEB-XS-2	X		
1-SW -046-00DC	EEB-XS-2	X		
1-LCV -062-0135	NEB-XX-37	X		
1-LCV -062-0136	NEB-XX-37	X		
1-LT -062-0238	NEB-62-26	X		
1-LT -062-0242	NEB-62-26	X		
1-FCV -063-0038 (LS)	NEB-XX-11		X	

VI.2 TABLE OF DELETIONS

TVA DEVICE ID		EQS NUMBER	MILD	CAT C	NOT IN 10CFR50.49 PROGRAM SCOPE
1-FSV -063-0038		NEB-XX-6		X	
1-FCV -063-0039		NEB-XX-37		X	
1-FCV -063-0040		NEB-XX-37		X	
1-FCV -063-0041	(LS)	NEB-XX-11		X	
1-FSV -063-0041		NEB-XX-6		X	
1-FCV -063-0042	(LS)	NEB-XX-11		X	
1-FSV -063-0042		NEB-XX-6		X	
0-TS -065-0016		MEB-65-0009		X	
0-HTR -065-0017	-A	MEB-65-0010		X	
0-TS -065-0036		MEB-65-0009		X	
0-HTR -065-0037	-B	MEB-65-0010		X	
2-FSV -065-0045		NO EQS NUMBER			X
2-FSV -065-0046		NO EQS NUMBER			X
1-FCV -067-0081		MEB-67-0140		X	
2-FCV -067-0081		NO EQS NUMBER		X	
1-FCV -067-0082		MEB-65-0140		X	
2-FCV -067-0082		NO EQS NUMBER		X	
1-FCV -067-0127		MEB-67-0137		X	
2-FCV -067-0127		NO EQS NUMBER		X	
1-FCV -067-0128		MEB-67-0137		X	
2-FCV -067-0128		NO EQS NUMBER		X	
1-FCV -067-0146		MEB-67-0137	X		
1-FCV -067-0147		MEB-67-0137		X	
2-FCV -067-0147		NO EQS NUMBER		X	
0-FCV -067-0151	-A	MEB-67-0137		X	

VI.2 TABLE OF DELETIONS

TVA DEVICE ID	EQS NUMBER	MILD	CAT C	NOT IN 10CFR50.49 PROGRAM SCOPE
0-FCV -067-0152	-B MEB-67-0137	X		
1-FSV -067-0168	EEB0029		X	
1-FSV -067-0170	EEB0029		X	
0-FCV -067-0205	MEB-67-0162	X		
0-FCV -067-0208	MEB-67-0162	X		
2-FSV -067-0217	EEB0029		X	
2-FSV -067-0219	EEB0029		X	
1-FCV -067-0223	MEB-64-0137	X		
2-FCV -067-0223	NO EQS NUMBER	X		
1-FCV -067-0458	MEB-67-0137	X		
1-FCV -067-0478	MEB-67-0137	X		
1-PT -068-0068	NEB-68-14		X	
1-PT -068-0069	NEB-68-14			X
1-FCV -070-0002	MEB-70-0144		X	
1-FCV -070-0003	MEB-70-0144		X	
2-FCV -070-0003	NO EQS NUMBER		X	
1-FCV -070-0008	MEB-70-0144		X	
1-FCV -070-0009	MEB-70-0144		X	
1-FCV -070-0010	MEB-70-0144		X	
0-FCV -070-0012	MEB-70-0144		X	
1-FCV -070-0013	MEB-70-0141		X	
2-FCV -070-0014	NO EQS NUMBER		X	
2-FCV -070-0018	NO EQS NUMBER		X	
0-FCV -070-0022	MEB-70-0141		X	
1-FCV -070-0023	MEB-70-0141		X	

VI.2 TABLE OF DELETIONS

TVA DEVICE ID		EQS NUMBER	MILD	CAT C	NOT IN 10CFR50.49 PROGRAM SCOPE
2-FCV -070-0023		NO EQS NUMBER		X	
1-FCV -070-0025		MEB-70-0141		X	
1-FCV -070-0026		MEB-70-0141		X	
1-FCV -070-0027		MEB-70-0141		X	
2-FCV -070-0028		NO EQS NUMBER		X	
2-FCV -070-0029		NO EQS NUMBER		X	
0-MTR -070-0033	-B	MEB-72-0204	X		
1-FCV -070-0034		MEB-70-0141		X	
0-MTR -070-0038	-B	MEB-72-0204	X		
0-MTR -070-0046	-A	MEB-72-0204	X		
0-MTR -070-0051	-S	MEB-72-0204	X		
0-MTR -070-0059	-A	MRB-72-0204	X		
1-FCV -070-0064		MEB-70-0141		X	
1-FCV -070-0074		MEB-70-0141		X	
1-FCV -070-0075		MEB-70-0148		X	
2-FCV -070-0075		NO EQS NUMBER		X	
2-FCV -070-0076		NO EQS NUMBER		X	
1-FCV -070-0133		MEB-70-0147		X	
1-FCV -070-0153		MEB-70-0141	X		
1-FCV -070-0156		MEB-70-1041	X		
0-FCV -070-0194		MEB-70-0144	X		
2-FCV -070-0195		NO EQS NUMBER		X	
2-FCV -070-0196		NO EQS NUMBER		X	
0-FCV -070-0197		MEB-70-0144	X		
1-FT -072-0013		NOT INSTALLED	X		

VI.2 TABLE OF DELETIONS

TVA DEVICE ID	EQS NUMBER	MILD	CAT C	NOT IN 10CFR50.49 PROGRAM SCOPE
1-FT -072-0034	NOT INSTALLED	X		
1-FCV -074-0040	NEB-XX-37			X
1-FCV -077-0019	NEB-XX-11			X
1-FCV -077-0020	NEB-XX-11			X
0-MTR -078-0009	NEB-XX-13	X		
0-MTR -078-0012	NEB-XX-13	X		
0-MTR -078-0035	NEB-XX-13	X		
0-MCC -208-000A	EEB-MC-5	X		
0-MCC -216-000A	EEB-MC-3	X		
0-MCC -216-000B	EEB-MC-4	X		
0-BD -228-0001	EEB-BD-1	X		
0-BD -228-0002	EEB-BD-2	X		
0-DPL -234-00A1/CVC	EEB-PNL-1	X		
0-DPL -234-00A2/CVC	EEB-PNL-1	X		
0-DPL -234-00B1/CVC	EEB-PNL-1	X		
0-DPL -234-00B2/CVC	EEB-PNL-1	X		
1-BD -242-0001	EEB-BD-242	X		
1-BD -242-0002	EEB-BD-242			X



### VI.3 COMPLETE 10CFR50.49 EQUIPMENT LISTING

This section contains the master EQ List. This list is a compilation of data for electrical equipment determined to be within the scope of 10CFR50.49. The list will be maintained for the life of the plant as a permanent record. The list will be maintained current by incorporation of revisions resulting from changes occurring in the plant design and configuration which impact the equipment within the scope of 10CFR50.49.

To support the 10CFR50.49 list, additional backup data is available at TVA which documents that all equipment on the list has been properly evaluated. Those items determined to be outside the scope of 10CFR50.49 are classified as such or are either Category C, or located in a MILD environment.

The information contained in the list includes the device identification number, description, the binder number in which the device is located and a reference to the Equipment Qualification Sheet (EQS) number contained in previous EEEQR submittals. Also included is a column denoting the following as related to PAM/TMI applicability:

- PAM - Indicates the component to be associated with PAM as defined in the FSAR
- PAM\* - Indicates the component to be associated with PAM per TVA's response to REG 1.97
- TMI - Indicates the component to be associated with TMI lessons learned
- P/T - Indicates the component to be associated with both PAM and TMI.

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
SPLC		CABL CONN HEAT SHRNKNSCF-W, W-HCK, NPKV	WBNEQ-SPLC-001	EEB-SPL-1	
1-PT -001-0002A	-D	SG1 MAIN STEAM HEADER PRESSURE	WBNEQ-IPT -002	HEB-1-21	PAH X
1-PT -001-0002B	-E	SG1 MAIN STEAM HEADER PRESSURE	WBNEQ-IPT -002	HEB-1-21	PAH X
1-FT -001-0003A	-D	SG1 MAIN STEAM HDR FLOW CHAN 1	WBNEQ-XMTR-001	HEB-XX-47	
1-FT -001-0003B	-E	SG1 MAIN STEAM HDR FLOW CHAN 2	WBNEQ-XMTR-001	HEB-XX-47	
1-FSV -001-0004A	-A	SG 1 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	HEB-1-0101	
1-FSV -001-0004B	-B	SG 1 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	HEB-1-0101	
1-FSV -001-0004D	-A	SG 1 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	HEB-1-0101	
1-FSV -001-0004E	-A	SG 1 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	HEB-1-0101	
1-FSV -001-0004F	-A	SG 1 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	HEB-1-0101	
1-FSV -001-0004G	-B	SG 1 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	HEB-1-0101	
1-FSV -001-0004H	-B	SG 1 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	HEB-1-0101	
1-FSV -001-0004J	-B	SG 1 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	HEB-1-0101	
1-PCV -001-0005/ZS1CS-A		ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-PCV -001-0005/ZS1	-A	SG1 HS HDR PMR RELF CNTL VALVE POS SW	WBNEQ-IZS -001	EEB0087	
1-PCV -001-0005/ZS2CS-A		ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-PCV -001-00051ZS2	-A	S61 MS HDR PWR RELF CHTL VALVE POS SW	WBNEQ-1ZS -001	EED0087	
1-PSV -001-0006A	-A	S61 MAIN STEAM HDR PWR RELIEF CHTL VLV	WBNEQ-SOL -003	EED0009	
1-PSV -001-0006B	CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-PSV -001-0006B	-A	S61 MAIN STEAM HDR PWR RELIEF CHTL VLV	WBNEQ-SOL -003	EED0009	
1-FCV -001-0007	CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -001-0007	-B	S61 BLOWDOWN FLOW SOL VALVE	WBNEQ-SOL -002	EED0036	PAH2
1-PT -001-0009A	-D	S62 MAIN STEAM HDR PRESS	WBNEQ-XMTR-004	NEB-XX-48	PAH2
1-PT -001-0009B	-E	S62 MAIN STEAM HDR PRESS	WBNEQ-XMTR-004	NEB-XX-48	PAH2
1-FT -001-0010A	-D	S62 MAIN STEAM HDR FLOW CHAN 1	WBNEQ-XMTR-001	NEB-XX-47	
1-FT -001-0010B	-E	S62 MAIN STEAM HDR FLOW CHAN 2	WBNEQ-XMTR-001	NEB-XX-47	
1-FSV -001-0011A	-A	S6 2 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	NEB-1-0101	
1-FSV -001-0011B	-B	S6 2 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	NEB-1-0101	
1-FSV -001-0011D	-A	S6 2 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	NEB-1-0101	
1-FSV -001-0011E	-A	S6 2 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	NEB-1-0101	
1-FSV -001-0011F	-A	S6 2 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	NEB-1-0101	
1-FSV -001-0011G	-B	S6 2 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	NEB-1-0101	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-FSV -001-0011H	-B	SG 2 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	NEB-1-0101	
1-FSV -001-0011J	-B	SG 2 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	NEB-1-0101	
1-PCV -001-0012/ZS1CS-B		ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-PCV -001-0012/ZS1	-B	SG2 HS HDR PRESS REL F CHTL VLV POS SW	WBNEQ-IZS -001	EEB0087	
1-PCV -001-0012/ZS2CS-B		ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-PCV -001-0012/ZS2	-B	SG2 HS HDR PRESS REL F CHTL VLV POS SW	WBNEQ-IZS -001	EEB0087	
1-PSV -001-0013A	-B	SG2 MAIN STEAM HDR PRESS RLF CHTL VLV	WBNEQ-SOL -003	EEB0009	
1-PSV -001-0013B	CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-PSV -001-0013B	-B	SG2 MAIN STEAM HDR PRESS RLF CHTL VLV	WBNEQ-SOL -003	EEB0009	
1-FCV -001-0014	CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -001-0014	-A	SG2 BLOWDOWN FLOW SOL VALVE	WBNEQ-SOL -002	EEB0036	PAH
1-FCV -001-0015	-A	AFPT STEAM SUPPLY FROM SG-1	WBNEQ-NOV -002	NEB-1-0107	
1-FCV -001-0016	-A	AFPT STEAM SUPPLY FROM SG-4	WBNEQ-NOV -002	NEB-1-0107	THI
1-FCV -001-0017	-A	STEAM FLOW TO AFPT ISOLATION	WBNEQ-NOV -002	NEB-1-0107	THI
1-TS -001-0017A	-A	TEMP SWITCH STM FLOW TO AFPT ISOL-HI TEMP	WBNEQ-ITS -001	EEB0011	
1-TS -001-0017B	-A	TEMP SWITCH STM FLOW TO AFPT ISOL-HI TEMP	WBNEQ-ITS -001	EEB0011	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAR/ THI
1-FCV -001-0018	-B	STEAM FLOW TO AFPT ISOLATION	WBNEQ-NOV -002	NEB-1-0107	THI
1-TS -001-0018A	-B	TEMP SWITCH STM FLOW TO AFPT ISOL-HI TEMP	WBNEQ-ITS -001	EED0011	
1-TS -001-0018B	-B	TEMP SWITCH STM FLOW TO AFPT ISOL-HI TEMP	WBNEQ-ITS -001	EED0011	
1-PT -001-0020A	-D	SG3 MAIN STEAM HDR PRESS	WBNEQ-XMTR-004	NEB-1-20	PARX
1-PT -001-0020B	-E	SG3 MAIN STEAM HDR PRESS	WBNEQ-XMTR-004	NEB-1-20	PARX
1-FT -001-0021A	-D	SG 3 MAIN STEAM HDR FLOW CHAN 1	WBNEQ-XMTR-001	NEB-XX-47	
1-FT -001-0021B	-E	SG 3 MAIN STEAM HDR FLOW CHAN 2	WBNEQ-XMTR-001	NEB-XX-47	
1-FSV -001-0022A	-A	SG 3 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	NEB-1-0101	
1-FSV -001-0022B	-B	SG 3 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	NEB-1-0101	
1-FSV -001-0022D	-A	SG 3 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	NEB-1-0101	
1-FSV -001-0022E	-A	SG 3 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	NEB-1-0101	
1-FSV -001-0022F	-A	SG 3 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	NEB-1-0101	
1-FSV -001-0022G	-B	SG 3 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	NEB-1-0101	
1-FSV -001-0022H	-B	SG 3 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	NEB-1-0101	
1-FSV -001-0022J	-B	SG 3 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	NEB-1-0101	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1-PCV -001-0023/ZS1CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-PCV -001-0023/ZS1 -A	SG3 HS HDR PRESS REL F CNTL VLV POS SW	WBNEQ-1ZS -001	EEB0087	
1-PCV -001-0023/ZS2CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-PCV -001-0023/ZS2 -A	SG3 HS HDR PRESS REL F CNTL VLV POS SW	WBNEQ-1ZS -001	EEB0087	
1-PSV -001-0024A -A	SG3 MAIN STEAM HDR PRESS RLF CNTL VLV	WBNEQ-SOL -003	EEB0009	
1-PSV -001-0024B CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-PSV -001-0024B -A	SG3 MAIN STEAM HDR PRESS RLF CNTL VLV	WBNEQ-SOL -003	EEB0009	
1-FCV -001-0025 CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -001-0025 -B	SG3 BLOWDOWN FLOW SOL VALVE	WBNEQ-SOL -002	EEB0036	PANX
1-PT -001-0027A -D	SG4 MAIN STEAM HEADER PRESSURE	WBNEQ-IPT -002	NEB-1-21	PANX
1-PT -001-0027B -E	SG4 MAIN STEAM HEADER PRESSURE	WBNEQ-IPT -002	NEB-1-21	PANX
1-FT -001-0028A -D	SG 4 MAIN STEAM HDR FLOW CHAN 1	WBNEQ-XNTR-001	NEB-XX-47	
1-FT -001-0028B -E	SG 4 MAIN STEAM HDR FLOW CHAN 1	WBNEQ-XNTR-001	NEB-XX-47	
1-FSV -001-0029A -A	SG 4 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	NEB-1-0101	
1-FSV -001-0029B -B	SG 4 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	NEB-1-0101	
1-FSV -001-0029D -A	SG 4 MAIN STM HDR ISLN VALVE	WBNEQ-SOL -004	NEB-1-0101	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1-FSV -001-0029E	-A	SG 4 MAIN STN HDR ISLN VALVE	NBNEQ-SOL -004	NEB-1-0101	
1-FSV -001-0029F	-A	SG 4 MAIN STN HDR ISLN VALVE	NBNEQ-SOL -004	NEB-1-0101	
1-FSV -001-0029G	-B	SG 4 MAIN STN HDR ISLN VALVE	NBNEQ-SOL -004	NEB-1-0101	
1-FSV -001-0029H	-B	SG 4 MAIN STN HDR ISLN VALVE	NBNEQ-SOL -004	NEB-1-0101	
1-FSV -001-0029J	-B	SG 4 MAIN STN HDR ISLN VALVE	NBNEQ-SOL -004	NEB-1-0101	
1-PCV -001-0030/2S1CS-B		ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-PCV -001-0030/2S1	-B	SG4 NS HDR PRESS REL F CNTL VLV POS SM	NBNEQ-IZS -001	EEB0087	
1-PCV -001-0030/2S2CS-B		ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-PCV -001-0030/2S2	-B	SG4 NS HDR PRESS REL F CNTL VLV POS SM	NBNEQ-IZS -001	EEB0087	
1-PSV -001-0031A	-B	SG4 MAIN STEAM HDR PRESS RLF CNTL VLV	NBNEQ-SOL -003	EEB0009	
1-PSV -001-0031B	CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-PSV -001-0031B	-B	SG4 MAIN STEAM HDR PRESS RLF CNTL VLV	NBNEQ-SOL -003	EEB0009	
1-FCV -001-0032	CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-FCV -001-0032	-A	SG4 BLOWDOWN FLOW SOL VALVE	NBNEQ-SOL -002	EEB0036	PANZ
1-FSV -001-0147	-A	SG LOOP 1 WARNING VALVE	NBNEQ-SOL -003	EEB0007	
1-FSV -001-0148	-B	SG LOOP 2 WARNING VALVE	NBNEQ-SOL -003	EEB0007	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAR/ THI
1-FSV -001-0149	-A	S6 LOOP 3 WARNING VALVE	WBNEQ-SOL -003	EEB0007	
1-FSV -001-0150	-B	S6 LOOP 4 WARNING VALVE	WBNEQ-SOL -003	EEB0007	
1-FCV -001-0181	CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -001-0181	-A	S61 BLOWDOWN ISLN VALVE INSIDE CONTNT	WBNEQ-SOL -002	EEB0077	PANX
1-FCV -001-0182	CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -001-0182	-B	S62 BLOWDOWN ISLN VALVE INSIDE CONTNT	WBNEQ-SOL -002	EEB0077	PANX
1-FCV -001-0183	CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -001-0183	-A	S63 BLOWDOWN ISLN VALVE INSIDE CNTNHT	WBNEQ-SOL -002	EEB0077	PANX
1-FCV -001-0184	CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -001-0184	-B	S64 BLOWDOWN ISLN VALVE INSIDE CNTNHT	WBNEQ-SOL -002	EEB0077	PANX
1-FCV -003-0033	-A	S61 FW ISOLATION VLV	WBNEQ-NOV -002	NEB-3-0111	PANX
1-LT -003-0038	-E	STN GEN 1 LEVEL WIDE RANGE	WBNEQ-XMTR-001	NEB-3-4	P/T
1-LT -003-0039	-F	STN GEN 1 LEVEL	WBNEQ-XMTR-001	NEB-XX-47	P/T
1-LT -003-0042	-G	STN GEN 1 LEVEL	WBNEQ-XMTR-001	NEB-3-4	THI
1-LT -003-0043	-F	STN GEN 1 LEVEL WIDE RANGE	WBNEQ-XMTR-001	NEB-XX-47	PANX
1-FCV -003-0047	-B	S62 FW ISOLATION VLV	WBNEQ-NOV -002	NEB-3-0111	PANX
1-LT -003-0051	-D	STN GEN 2 LEVEL	WBNEQ-XMTR-001	NEB-3-4	P/T
1-LT -003-0052	-F	STN GEN 2 LEVEL	WBNEQ-XMTR-001	NEB-XX-47	P/T



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAW/ THI
1-LT -003-0055 -G	STN GEN 2 LEVEL	WBNEQ-XNTR-001	NEB-3-4	THI
1-LT -003-0056 -G	STN GEN 2 LEVEL WIDE RANGE	WBNEQ-XNTR-001	NEB-3-4	PANX
1-FCV -003-0087 -A	SG3 FN ISOLATION VLV	WBNEQ-NOV -002	NEB-3-0111	PANX
1-LT -003-0093 -D	STN GEN 3 LEVEL	WBNEQ-XNTR-001	NEB-3-4	P/T
1-LT -003-0094 -F	STN GEN 3 LEVEL WIDE RANGE	WBNEQ-XNTR-001	NEB-3-4	P/T
1-LT -003-0097 -G	STN GEN 3 LEVEL	WBNEQ-XNTR-001	NEB-XX-47	THI
1-LT -003-0098 -G	STN GEN 3 LEVEL	WBNEQ-XNTR-001	NEB-XX-47	PANX
1-FCV -003-0100 -B	SG4 FN ISOLATION VLV	WBNEQ-NOV -002	NEB-3-0111	PANX
1-LT -003-0106 -E	STN GEN 4 LEVEL WIDE RANGE	WBNEQ-XNTR-001	NEB-3-4	P/T
1-LT -003-0107 -F	STN GEN 4 LEVEL	WBNEQ-XNTR-001	NEB-3-4	P/T
1-LT -003-0110 -G	STN GEN 4 LEVEL	WBNEQ-XNTR-001	NEB-XX-47	THI
1-LT -003-0111 -F	STN GEN 4 LEVEL WIDE RANGE	WBNEQ-XNTR-001	NEB-3-4	PANX
1-HS -003-0116A/B -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-HS -003-0116B/B -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-HS -003-0126A/B -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-HS -003-0126B/B -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-HS -003-0136A/B -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-HS -003-0136B/B -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FT -003-0147A -A	SG3 AFN FLOW TRANSMITTER	WBNEQ-IPT -001		P/T
1-FT -003-0147B -B	SG3 AFN FLOW TRANSMITTER	WBNEQ-IPT -001		P/T
1-LT -003-0148 CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-LT -003-0148	-B	STEAM GEN #3 LEVEL	WBNEQ-ILT -001	EED0002	
1-FT -003-0155A	-A	SG2 AFW FLOW TRANSMITTER	WBNEQ-IPT -001		P/T
1-FT -003-0155B	-B	SG2 AFW FLOW TRANSMITTER	WBNEQ-IPT -001		PAH
1-LT -003-0156	CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-LT -003-0156	-A	STEAM GEN #2 LEVEL	WBNEQ-ILT -001	EED0002	
1-FT -003-0163A	-A	SG1 AFW FLOW TRANSMITTER	WBNEQ-IPT -001		P/T
1-FT -003-0163B	-B	SG1 AFW FLOW TRANSMITTER	WBNEQ-IPT -001		PAH
1-LT -003-0164	CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-LT -003-0164	-A	STEAM GEN #1 LEVEL	WBNEQ-ILT -001	EED0002	
1-FT -003-0170A	-A	SG4 AFW FLOW TRANSMITTER	WBNEQ-IPT -001		P/T
1-FT -003-0170B	-B	SG4 AFW FLOW TRANSMITTER	WBNEQ-IPT -001		P/T
1-LT -003-0171	CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-LT -003-0171	-B	STEAM GEN #4 LEVEL	WBNEQ-ILT -001	EED0002	
1-LT -003-0172	CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-LT -003-0172	-A	STEAM GEN #3 LEVEL	WBNEQ-ILT -001	EED0002	
1-LT -003-0173	CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-LT -003-0173	-B	STEAM GEN #2 LEVEL	WBNEQ-ILT -001	EED0002	
1-LT -003-0174	CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1-LSV -003-0174	-B	STN GEN 1 LEVEL SOL VALVE	WBNEQ-SOL -003	EEB0007	THI
1-LT -003-0174	-B	STEAM GEN #1 LEVEL	WBNEQ-ILT -001	EEB0002	
1-LCV -003-0174	-B	STEAM GEN #1 LEVEL CONT VALVE POS	WBNEQ-ILCV-001	EEB0073	THI
1-LT -003-0175	CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-LSV -003-0175	-A	STN GEN 4 LEVEL SOL VALVE	WBNEQ-SOL -003	EEB0007	THI
1-LT -003-0175	-A	STEAM GEN #4 LEVEL	WBNEQ-ILT -001	EEB0002	
1-LCV -003-0175	-A	STEAM GEN #4 LEVEL CONT VALVE POS	WBNEQ-ILCV-001	EEB0073	THI
1-HS -003-0179A/B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-HS -003-0179B/B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -003-0185	-B	SG1 MAIN FM CHECK VALVE BYPASS	WBNEQ-SOL -003	EEB0020	
1-FSV -003-0186	-A	SG2 MAIN FM CHECK VALVE BYPASS	WBNEQ-SOL -003	EEB0020	
1-FSV -003-0187	-B	SG3 MAIN FM CHECK VALVE BYPASS	WBNEQ-SOL -003	EEB0020	
1-FSV -003-0188	-A	SG4 MAIN FM CHECK VALVE BYPASS	WBNEQ-SOL -003	EEB0020	
1-FSV -003-0236A	-A	UPPER TAP MAIN FM SG1 ISLN VALVE	WBNEQ-SOL -003	EEB0020	
1-FSV -003-0236B	-B	UPPER TAP MAIN FM SG1 ISLN VALVE	WBNEQ-SOL -003	EEB0020	
1-FSV -003-0239A	-A	UPPER TAP MAIN FM SG2 ISLN VALVE	WBNEQ-SOL -003	EEB0020	
1-FSV -003-0239B	-B	UPPER TAP MAIN FM SG2 ISLN VALVE	WBNEQ-SOL -003	EEB0020	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-FSV -003-0242A	-A	UPPER TAP MAIN FW SG3 ISLN VALVE	WBNEQ-SOL -003	EEB0020	
1-FSV -003-0242B	-B	UPPER TAP MAIN FW SG3 ISLN VALVE	WBNEQ-SOL -003	EEB0020	
1-FSV -003-0245A	-A	UPPER TAP MAIN FW SG4 ISLN VALVE	WBNEQ-SOL -003	EEB0020	
1-FSV -003-0245B	-B	UPPER TAP MAIN FW SG4 ISLN VALVE	WBNEQ-SOL -003	EEB0020	
0-TS -012-0091A	-A	TEMP SM - AUX BLDG STEAM LINE RUPTURE	WBNEQ-ITS -001	EEB0089	
0-TS -012-0091B	-B	TEMP SM - AUX BLDG STEAM LINE RUPTURE	WBNEQ-ITS -001	EEB0089	
0-TS -012-0092A	-A	TEMP SM - AUX BLDG STEAM LINE RUPTURE	WBNEQ-ITS -001	EEB0089	
0-TS -012-0092B	-B	TEMP SM - AUX BLDG STEAM LINE RUPTURE	WBNEQ-ITS -001	EEB0089	
0-TS -012-0093A	-A	TEMP SM - AUX BLDG STEAM LINE RUPTURE	WBNEQ-ITS -001	EEB0022	
0-TS -012-0093B	-B	TEMP SM - AUX BLDG STEAM LINE RUPTURE	WBNEQ-ITS -001	EEB0022	
0-TS -012-0094A	-A	TEMP SM - AUX BLDG STEAM LINE RUPTURE	WBNEQ-ITS -002	EEB0022	
0-TS -012-0094B	-B	TEMP SM - AUX BLDG STEAM LINE RUPTURE	WBNEQ-ITS -002	EEB0022	
0-TS -012-0095A	-A	TEMP SM - AUX BLDG STEAM LINE RUPTURE	WBNEQ-ITS -001	EEB0022	
0-TS -012-0095B	-B	TEMP SM - AUX BLDG STEAM LINE RUPTURE	WBNEQ-ITS -001	EEB0022	
0-TS -012-0096A	-A	TEMP SM - AUX BLDG STEAM LINE RUPTURE	WBNEQ-ITS -001	EEB0022	
0-TS -012-0096B	-B	TEMP SM - AUX BLDG STEAM LINE RUPTURE	WBNEQ-ITS -001	EEB0022	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ TRI
0-TS -012-0097A -A	TEMP SW - AUX BLDG STEAM LINE RUPTURE	WBNEQ-ITS -002	EEB0022	
0-TS -012-0097B -B	TEMP SW - AUX BLDG STEAM LINE RUPTURE	WBNEQ-ITS -002	EEB0022	
0-TS -012-0098A -A	TEMP SW - AUX BLDG STEAM LINE RUPTURE	WBNEQ-ITS -001	EEB0022	
0-TS -012-0098B -B	TEMP SW - AUX BLDG STEAM LINE RUPTURE	WBNEQ-ITS -001	EEB0022	
0-TS -012-0099A -A	TEMP SW - AUX BLDG STEAM LINE RUPTURE	WBNEQ-ITS -001	EEB0089	
0-TS -012-0099B -B	TEMP SW - AUX BLDG STEAM LINE RUPTURE	WBNEQ-ITS -001	EEB0089	
1-HS -026-0240B -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	PAH
1-HS -026-0241 -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -026-0241 -B	ANN STANDPIPE ISLN VALVE	WBNEQ-NOV -003	NEB-26-0115	
1-HS -026-0242 -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -026-0242 -A	ANN STANDPIPE ISLN VALVE	WBNEQ-NOV -003	NEB-26-0115	
1-FCV -026-0243 -A	REACTOR COOLANT PUMPSRAY ISLN VALVE	WBNEQ-NOV -003	NEB-26-0115	PAHX
1-HS -026-0243B -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	PAH
1-HS -026-0244 -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -026-0244 -B	ANN SPRINKLER SYS ISLN VALVE	WBNEQ-NOV -003	NEB-26-0115	
1-HS -026-0245 -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -026-0245 -A	ANN SPRINKLER SYS ISLN VALVE CONT	WBNEQ-NOV -003	NEB-26-0115	
1-FSV -030-0002 -A	PURGE AIR SUP FAN A ISLN VALVE	WBNEQ-SOL -003	NEB-30-0117	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-FCV -030-0002/2S1 -A	PURGE AIR SUP FAN A ISLN VALVE POS SW	WBNEQ-1ZS -001	NEB-30-0118	
1-FCV -030-0002/2S2 -A	PURGE AIR SUP FAN A ISLN VALVE POS SW	WBNEQ-1ZS -001	NEB-30-0118	
1-HS -030-0003 -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-ZS -030-0003/1 -A	INTERIM ABSCE VALVE POS SW	WBNEQ-1ZS -001		
1-ZS -030-0003/2 -A	INTERIM ABSCE VALVE POS SW	WBNEQ-1ZS -001		
1-FSV -030-0005 -A	PURGE AIR SUP FAN B ISLN VALVE	WBNEQ-SOL -003	NEB-30-0117	
1-FCV -030-0005/2S1 -A	PURGE AIR SUPPLY FANB ISLN VALVE POS SW	WBNEQ-1ZS -001	NEB-30-0118	
1-FCV -030-0005/2S2 -A	PURGE AIR SUPPLY FANB ISLN VALVE POS SW	WBNEQ-1ZS -001	NEB-30-0118	
1-HS -030-0006 -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-ZS -030-0006/1 -B	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001		
1-ZS -030-0006/2 -B	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001		
1-FSV -030-0007 -A	UPPER COMPT PURGE ISLN VALVE	WBNEQ-SOL -003	EEB0054	
1-ZS -030-0007/1 -A	UPPER COMPT PURGE ISLN VALVE POS SW	WBNEQ-1ZS -001	EEB0063	PANX
1-ZS -030-0007/2 -A	UPPER COMPT PURGE ISLN VALVE POS SW	WBNEQ-1ZS -001	EEB0063	PANX
1-FSV -030-0008 -B	UPPER COMPT PURGE ISLN VALVE	WBNEQ-SOL -003	EEB0046	
1-FCV -030-0008/2S1CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-ZS -030-0008/1 -B	UPPER COMPT PURGE ISLN VALVE POS SW	WBNEQ-1ZS -004	EED0018	PAH1
1-FCV -030-0008/ZS2CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EED-CSC-1	
1-ZS -030-0008/2 -B	UPPER COMPT PURGE ISLN VALVE POS SW	WBNEQ-1ZS -004	EED0018	PAH1
1-FSV -030-0009 -B	UPPER COMPT PURGE ISLN VALVE	WBNEQ-SOL -003	EED0054	
1-ZS -030-0009/1 -B	UPPER COMPT PURGE ISLN VALVE POS SW	WBNEQ-1ZS -001	EED0063	PAH1
1-ZS -030-0009/2 -B	UPPER COMPT PURGE ISLN VALVE POS SW	WBNEQ-1ZS -001	EED0063	PAH1
1-FSV -030-0010 -A	UPPER COMPT PURGE ISLN VALVE	WBNEQ-SOL -003	EED0046	
1-FCV -030-0010/ZS1CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EED-CSC-1	
1-ZS -030-0010/1 -A	UPPER COMPT PURGE ISLN VALVE POS SW	WBNEQ-1ZS -004	NEB-30-0121	PAH1
1-FCV -030-0010/ZS2CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EED-CSC-1	
1-ZS -030-0010/2 -A	UPPER COMPT PURGE ISLN VALVE POS SW	WBNEQ-1ZS -004	NEB-30-0121	PAH1
1-FSV -030-0012 -A	ANNULUS PURGE VLV SOLENOID	WBNEQ-SOL -003	EED0054	
1-FCV -030-0012/ZS1 -A	ANNULUS PURGE VALVE POS SW	WBNEQ-1ZS -001	NEB-30-0127	
1-FCV -030-0012/ZS2 -A	ANNULUS PURGE VALVE POS SW	WBNEQ-1ZS -001	NEB-30-0127	
1-FSV -030-0013 -A	INTERIM ABSCE ISLN VALVE	WBNEQ-SOL -003		
1-HS -030-0013 -A	HANDSWITCH	WBNEQ-HS -001	EED-HS-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-ZS -030-0013/1 -A	INTERIM ABSCE ISLN VALVE POS SW	NBNEQ-1ZS -001		
1-ZS -030-0013/2 -A	INTERIM ABSCE ISLN VALVE POS SW	NBNEQ-1ZS -001		
1-FSV -030-0014 -A	LOWER COMPT PURGE ISLN VALVE	NBNEQ-SOL -003	EED0054	
1-ZS -030-0014/1 -A	LOWER COMPT PURGE ISLN VALVE POS SW	NBNEQ-1ZS -001	EED0063	PAH1
1-ZS -030-0014/2 -A	LOWER COMPT PURGE ISLN VALVE POS SW	NBNEQ-1ZS -001	EED0063	PAH1
1-FSV -030-0015 -B	LOWER CHTHT PURGE ISLN VALVE	NBNEQ-SOL -003	EED0047	
1-FCV -030-0015/ZS1CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-ZS -030-0015/1 -B	LOWER COMPT PURGE ISLN VALVE POS SW	NBNEQ-1ZS -004	EED0018	PAH1
1-FCV -030-0015/ZS2CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-ZS -030-0015/2 -B	LOWER COMPT PURGE ISLN VALVE POS SW	NBNEQ-1ZS -004	EED0018	PAH1
1-FSV -030-0016 -B	LOWER CHTHT PURGE ISLN VALVE	NBNEQ-SOL -003	EED0054	
1-FCV -030-0016/ZS1 -B	LOWER COMPT PURGE ISLN VALVE POS SW	NBNEQ-1ZS -001	EED0063	PAH1
1-FCV -030-0016/ZS2 -B	LOWER COMPT PURGE ISLN VALVE POS SW	NBNEQ-1ZS -001	EED0063	PAH1
1-FSV -030-0017 -A	LOWER CHTHT PURGE ISLN VALVE	NBNEQ-SOL -003	EED0047	
1-FCV -030-0017/ZS1CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-FCV -030-0017/ZS1 -A	LOWER COMPT PURGE ISLN VALVE LIMIT SW	NBNEQ-1ZS -004	EED0008	PAH1



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THZ
1-FCV -030-0017/ZS2CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -030-0017/ZS2 -A	LOWER COMPT PURGE ISLN VALVE LIMIT SW	WBNEQ-IZS -004	EEB0008	PANX
1-FSV -030-0018 -B	INTERIM ABSCE ISLN VALVE	WBNEQ-SOL -003		
1-HS -030-0018 -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-ZS -030-0018/1 -B	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-IZS -001		
1-ZS -030-0018/2 -B	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-IZS -001		
1-FSV -030-0019 -B	INCORE INSTR RM PURGE ISLN VALVE	WBNEQ-SOL -003	EEB0054	PANX
1-ZS -030-0019/1 -B	INCORE INST RM PURGEISLN VALVE POS SW	WBNEQ-IZS -001	EEB0063	PANX
1-ZS -030-0019/2 -B	INCORE INST RM PURGEISLN VALVE POS SW	WBNEQ-IZS -001	EEB0063	PANX
1-FSV -030-0020 -A	INCORE INSTR RM PURGE ISLN VALVE	WBNEQ-SOL -003	EEB0047	
1-FCV -030-0020/ZS1CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-ZS -030-0020/1 -A	IIR PURGE ISLN VALVEPOS SWITCH	WBNEQ-IZS -004	EEB0018	PANX
1-FCV -030-0020/ZS2CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-ZS -030-0020/2 -A	IIR PURGE ISLN VALVEPOS SWITCH	WBNEQ-IZS -004	EEB0018	PANX
1-FSV -030-0028 -A	INTERIM ABSCE ISLN VALVE	WBNEQ-SOL -003	NEB-30-0001	
1-HS -030-0028 -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1-ZS -030-0028/1 -A	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001	EEB0067	
1-ZS -030-0028/2 -A	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001	EEB0067	
1-FSV -030-0029 -B	INTERIM ABSCE ISLN VALVE	WBNEQ-SOL -003	NEB-30-0001	
1-HS -030-0029 -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-ZS -030-0029/1 -B	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001	EEB0067	
1-ZS -030-0029/2 -B	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001	EEB0067	
1-HS -030-0032 -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-HS -030-0033 -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -030-0037 -B	LOWER COMPT PURGE SOLENOID	WBNEQ-SOL -003	EEB0054	
1-FCV -030-0037/1ZS1 -B	LOWER COMPT PURGE CNTL VALVE POS SW	WBNEQ-1ZS -001	EEB0063	
1-FCV -030-0037/1ZS2 -B	LOWER COMPT PURGE CNTL VALVE POS SW	WBNEQ-1ZS -001	EEB0063	
1-NTR -030-0038 -A	CONTAINMENT AIR RETURN FAN MOTORS	WBNEQ-NOT -002	NEB-30-0035	
1-NTR -030-0039 -B	CONTAINMENT AIR RETURN FAN MOTORS	WBNEQ-NOT -002	NEB-30-0035	
1-FSV -030-0040 -A	LOWER COMPT PURGE SOLENOID	WBNEQ-SOL -003	EEB0047	
1-FCV -030-0040/1ZS1CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -030-0040/1ZS1 -A	LOWER COMPT PURGE CONT VALVE POS SW	WBNEQ-1ZS -004	EEB0018	PANX
1-FCV -030-0040/1ZS2CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-FCV -030-0040/ZS2 -A	LOWER COMPT PURGE CONT VALVE POS SW	WBNEQ-IZS -004	EEB0018	PAHx
1-PDT -030-0042 -G	CNTMT PRESS DIFF XHTR	WBNEQ-XHTR-001	NO EQS NUMBER	PAHx
1-PDT -030-0043 -F	CNTMT PRESS DIFF XHTR	WBNEQ-XHTR-001	NEB-30-27	PAHx
1-PDT -030-0044 -E	CNTMT PRESS DIFF XHTR	WBNEQ-XHTR-001	NEB-30-27	PAHx
1-PDT -030-0045 -D	CNTMT PRESS DIFF XHTR	WBNEQ-XHTR-001	NEB-30-27	PAHx
1-FSV -030-0050 -B	UPPER CNTMT EXH ISLNVALVE	WBNEQ-SOL -003	EEB0047	
1-FCV -030-0050/ZS1CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-ZS -030-0050/1 -B	UPPER CNTMT EXH ISLN VALVE POS SW	WBNEQ-IZS -004	EEB0018	PAHx
1-FCV -030-0050/ZS2CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-ZS -030-0050/2 -B	UPPER CNTMT EXH ISLN VALVE POS SW	WBNEQ-IZS -004	EEB0018	PAHx
1-FSV -030-0051 -A	UPPER CNTMT EXH ISLNVALVE	WBNEQ-SOL -003	EEB0054	
1-ZS -030-0051/1 -A	UPPER CNTMT EXH ISLN VALVE POS SW	WBNEQ-IZS -001	EEB0063	PAHx
1-ZS -030-0051/2 -A	UPPER CNTMT EXH ISLN VALVE POS SW	WBNEQ-IZS -001	EEB0063	PAHx
1-FSV -030-0052 -A	UPPER CNTMT EXH ISLNVALVE	WBNEQ-SOL -003	EEB0047	
1-FCV -030-0052/ZS1CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-ZS -030-0052/1 -A	UPPER CNTMT EXH ISLN VALVE POS SW	WBNEQ-IZS -004	EEB0018	PAHx

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-FCV -030-0052/ZS2CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-ZS -030-0052/2 -A	UPPER CHTMT EXH ISLN VALVE POS SW	WBNEQ-1ZS -004	EEB0018	PAHX
1-FSV -030-0053 -B	UPPER CHTMT EXH ISLNVALVE	WBNEQ-SOL -003	EEB0054	
1-ZS -030-0053/1 -B	UPPER CHTMT EXH ISLN VALVE POS SW	WBNEQ-1ZS -001	EEB0063	PAHX
1-ZS -030-0053/2 -B	UPPER CHTMT EXH ISLN VALVE POS SW	WBNEQ-1ZS -001	EEB0063	PAHX
1-FSV -030-0054 -A	ANNULUS EXH ISLN VALVE SOLENOID	WBNEQ-SOL -003	EEB0054	
1-FCV -030-0054/ZS1 -A	ANNULUS EXH ISLN VALVE POS SW	WBNEQ-1ZS -001	HEB-30-0127	
1-FCV -030-0054/ZS2 -A	ANNULUS EXH ISLN VALVE POS SW	WBNEQ-1ZS -001	HEB-30-0127	
1-FSV -030-0056 -A	LOWER CHTMT EXH ISLNVALVE	WBNEQ-SOL -003	EEB0047	
1-FCV -030-0056/ZS1CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-ZS -030-0056/1 -A	LOWER CHTMT EXH ISLN VALVE POS SW	WBNEQ-1ZS -004	EEB0018	PAHX
1-FCV -030-0056/ZS2CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-ZS -030-0056/2 -A	LOWER CHTMT EXH ISLN VALVE POS SW	WBNEQ-1ZS -004	EEB0018	PAHX
1-FSV -030-0057 -B	LOWER CHTMT EXH ISLNVALVE	WBNEQ-SOL -003	EEB0054	
1-ZS -030-0057/1 -B	LOWER CHTMT EXH ISLN VALVE POS SW	WBNEQ-1ZS -001	EEB0063	PAHX
1-ZS -030-0057/2 -B	LOWER CHTMT EXH ISLN VALVE POS SW	WBNEQ-1ZS -001	EEB0063	PAHX

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1-FSV -030-0058	-B	INCORE INSTR RM EXH ISLN VALVE	WBNEQ-SOL -003	EED0047	
1-FCV -030-0058/ZS1CS-B		ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-ZS -030-0058/1	-B	INCORE INSTR RM EXHAUST POS SWITCH	WBNEQ-1ZS -003	EED0059	PAN1
1-FCV -030-0058/ZS2CS-B		ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-ZS -030-0058/2	-B	INCORE INSTR RM EXCHANGE POS SWITCH	WBNEQ-1ZS -003	EED0059	PAN1
1-FSV -030-0059	-A	INCORE INSTR RM EXH ISLN VALVE	WBNEQ-SOL -003	EED0054	
1-ZS -030-0059/1	-A	INCORE INSTR RM EXH ISLN VALVE POS SW	WBNEQ-1ZS -001	EED0063	PAN1
1-ZS -030-0059/2	-A	INCORE INSTR RM EXH ISLN VALVE POS SW	WBNEQ-1ZS -001	EED0063	PAN1
1-FSV -030-0060	-A	INTERIM ABSCE ISLN VALVE	WBNEQ-SOL -003	NEB-30-0001	
1-HS -030-0060	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-ZS -030-0060/1	-A	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001	EED0067	
1-ZS -030-0060/2	-A	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001	EED0067	
1-FSV -030-0061	-A	PURGE AIR EXH UNIT A SUCTION VALVE	WBNEQ-SOL -003	NEB-30-0119	
1-FCV -030-0061/ZS1	-A	PURGE AIR EXH UNIT ASUCT VALVE POS SW	WBNEQ-1ZS -001	NEB-30-0118	
1-FCV -030-0061/ZS2	-A	PURGE AIR EXH UNIT ASUCT VALVE POS SW	WBNEQ-1ZS -001	NEB-30-0118	
1-FSV -030-0062	-A	PURGE AIR EXH UNIT B SUCTION VALVE	WBNEQ-SOL -003	NEB-30-0119	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAW/ THI
1-FCV -030-0062/2S1 -A	PURGE AIR EXH UNIT BSUCT VALVE POS SW	WBNEQ-1ZS -001	NEB-30-0118	
1-FCV -030-0062/2S2 -A	PURGE AIR EXH UNIT BSUCT VALVE POS SW	WBNEQ-1ZS -001	NEB-030-0118	
1-FSV -030-0069 -B	INTERIM ABSCE ISLN VALVE	WBNEQ-SOL -003	NEB-30-0001	
1-HS -030-0069 -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-ZS -030-0069/1 -B	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001	EEB0067	
1-ZS -030-0069/2 -B	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001	EEB0067	
1-HS -030-0076 -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-ZS -030-0076/1 -A	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001		
1-ZS -030-0076/2 -A	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001		
1-HS -030-0079 -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-HS -030-0091 -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-ZS -030-0091/1 -A	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001		
1-ZS -030-0091/2 -A	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001		
1-FCO -030-0107/2S1 -B	PURGE AIR SUP TR B ISLN DNPR POS SW	WBNEQ-1ZS -001		
1-FCO -030-0107/2S2 -B	PURGE AIR SUP TR B ISLN DNPR POS SW	WBNEQ-1ZS -001		
1-HS -030-0115 -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-ZS -030-0115/1 -A	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001		
1-ZS -030-0115/2 -A	INTERIM ABSCE ISLN VALVE POS SW	WBNEQ-1ZS -001		

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
1-HS -030-0116 -B	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
1-HS -030-0117 -A	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
1-ZS -030-0117/1 -A	INTERIM ABSCE ISLN VALVE POS SW	NBNEQ-IZS -001		
1-ZS -030-0117/2 -A	INTERIM ABSCE ISLN VALVE POS SW	NBNEQ-IZS -001		
1-HS -030-0118 -B	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
1-ZS -030-0118/1 -B	INTERIM ABSCE ISLN VALVE POS SW	NBNEQ-IZS -001		
1-ZS -030-0118/2 -B	INTERIM ABSCE ISLN VALVE POS SW	NBNEQ-IZS -001		
1-HS -030-0119 -A	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
1-ZS -030-0119/1 -A	INTERIM ABSCE ISLN VALVE POS SW	NBNEQ-IZS -001		
1-ZS -030-0119/2 -A	INTERIM ABSCE ISLN VALVE POS SW	NBNEQ-IZS -001		
1-HS -030-0120 -B	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
1-ZS -030-0120/1 -B	INTERIM ABSCE ISOL VALVE POS SWITCH	NBNEQ-IZS -001		
1-ZS -030-0120/2 -B	INTERIM ABSCE ISOL VALVE POS SWITCH	NBNEQ-IZS -001		
1-HS -030-0121 -A	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
1-ZS -030-0121/1 -A	INTERIM ABSCE ISOL VALVE POS SWITCH	NBNEQ-IZS -001		
1-ZS -030-0121/2 -A	INTERIM ABSCE ISOL VALVE POS SWITCH	NBNEQ-IZS -001		
1-HS -030-0124 -B	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
1-ZS -030-0124/1 -B	INTERIM ABSCE ISOL VALVE POS SWITCH	NBNEQ-IZS -001		

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-ZS -030-0124/2 -B	INTERIM ABSCE ISOL VALVE POS SWITCH	WBNEQ-1ZS -001		
1-HS -030-0125 -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-ZS -030-0125/1 -A	INTERIM ABSCE ISOL VALVE POS SWITCH	WBNEQ-1ZS -001		
1-ZS -030-0125/2 -A	INTERIM ABSCE ISOL VALVE POS SWITCH	WBNEQ-1ZS -001		
1-HS -030-0128 -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-ZS -030-0128/1 -B	INTERIM ABSCE ISOL VALVE POS SWITCH	WBNEQ-1ZS -001		
1-ZS -030-0128/2 -B	INTERIM ABSCE ISOL VALVE POS SWITCH	WBNEQ-1ZS -001		
1-HS -030-0131 -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-HS -030-0132 -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -030-0134 CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FSV -030-0134 -B	CNTNMT ANNULUS DP ISLN VALVE	WBNEQ-SOL -002	EEB0001	PANX
1-FCV -030-0134/ZS1CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FSV -030-0135 -A	CNTNMT ANNULUS DP ISLN VALVE	WBNEQ-SOL -002	EEB0001	PANX
1-TS -030-0143 -A	TEMPERATURE SWITCH-THERMAL CUTOUT	WBNEQ-INIK-001		
1-FS -030-0146 -B	AIR FLOW SWITCH	WBNEQ-INIK-001		
0-HTR -030-0146 -A	ABGTS FAN MOTOR A-A	WBNEQ-HOT -003		
1-FSV -030-0146A -A	AUX BLDG GAS THT FAN A-A SUCT DNPR	WBNEQ-SOL -005		
1-FSV -030-0146B -A	AUX BLDG GAS THT FAN A-A SUCT DNPR	WBNEQ-SOL -005		



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1-HS -030-0146B -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
0-HTR -030-0147 -A	50KM ELECTRIC AIR HEATER	WBNEQ-THK-001	NEB-30-0006	
2-TS -030-0155 -B	TEMPERATURE SWITCH-THERMAL CUTOUT	WBNEQ-THK-001		
0-HTR -030-0156 -B	50KM ELECTRIC AIR HEATER	WBNEQ-THK-001	NEB-30-0006	
2-FS -030-0157 -A	AIR FLOW SWITCH	WBNEQ-THK-001		
2-NTR -030-0157 -B	ABGTS FAN MOTOR B-B	WBNEQ-NOT -003	NEB-30-0018	
2-FSV -030-0157A -B	AUX BLDG GAS THT FAN A-A EXH DNPR	WBNEQ-SOL -005	NO EQS NUMBER	
2-FSV -030-0157B -B	AUX BLDG GAS THT FAN B-B SUCT	WBNEQ-SOL -005	NO EQS NUMBER	
2-HS -030-0157B -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-HS -030-0175 -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-NTR -030-0175 -A	RHR PUMP ROOM 1A-A COOLER FAN MOTOR	WBNEQ-NOT -003		
1-HS -030-0176 -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-NTR -030-0176 -B	RHR PUMP ROOM 1B-B COOLER FAN MOTOR	WBNEQ-NOT -003		
1-HS -030-0177 -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-NTR -030-0177 -A	CTH SPR PUMP RM 1A-ACCOOLER FAN MOTOR	WBNEQ-NOT -003		
1-HS -030-0178 -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-NTR -030-0178 -B	CTH SPR PUMP RM 1B-BCOOLER FAN MOTOR	WBNEQ-NOT -003		
1-HS -030-0179 -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-NTR -030-0179 -B	SIS PUMP ROOM 1B-B COOLER FAN MOTOR	WBNEQ-NOT -003		

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
1-HS -030-0180	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-NTR -030-0180	-A	SIS PUMP ROOM 1A-A COOLER FAN MOTOR	WBNEQ-NOT -003		
1-HS -030-0182	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-NTR -030-0182	-B	CEN CHR PUMP RM 1B-COOLER FAN MOTOR	WBNEQ-NOT -003		
1-HS -030-0183	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-NTR -030-0183	-A	CEN CHG PUMP RM 1A-COOLER FAN MOTOR	WBNEQ-NOT -003		
1-HS -030-0186	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
2-HS -030-0186	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-HS -030-0187	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
2-HS -030-0187	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-HS -030-0190	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-HS -030-0191	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
0-HS -030-0192	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
0-TS -030-0192A	-A	SFP & THERM BARRIER BSTR PUMP COOLER FAN	WBNEQ-ITS -002	EEB0005	
0-TS -030-0192B	-A	SFP & THERM BARRIER BSTR PUMP COOLER FAN	WBNEQ-ITS -002	EEB0005	
0-HS -030-0193	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
0-TS -030-0193A	-B	SFP & THERM BARRIER BSTR PUMP COOLER FAN	WBNEQ-ITS -002	EEB0005	
0-TS -030-0193B	-B	SFP & THERM BARRIER BSTR PUMP COOLER FAN	WBNEQ-ITS -002	EEB0005	
1-HS -030-0194	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
2-HS -030-0194	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
1-NTR -030-0194	-A	EL 737 PENETRATION ROOM COOLER	NBNEQ-NOT -004		
2-NTR -030-0194	-A	EL 737 PENETRATION ROOM COOLER	NBNEQ-NOT -004		
1-TS -030-0194A	-A	PENETRATION ROOM COOLER FAN	NBNEQ-ITS -002	EED0033	
2-TS -030-0194A	-A	PENETRATION ROOM COOLER FAN	NBNEQ-ITS -002	EED0033	
1-TS -030-0194B	-A	PENETRATION ROOM COOLER FAN	NBNEQ-ITS -002	EED0033	
2-TS -030-0194B	-A	PENETRATION ROOM COOLER FAN	NBNEQ-ITS -002	EED0033	
1-HS -030-0195	-B	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
2-HS -030-0195	-B	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
1-NTR -030-0195	-B	EL 737 PENETRATION ROOM COOLER	NBNEQ-NOT -004		
2-NTR -030-0195	-B	EL 737 PENETRATION ROOM COOLER	NBNEQ-NOT -004		
1-TS -030-0195A	-B	PENETRATION ROOM COOLER FAN	NBNEQ-ITS -002	EED0033	
2-TS -030-0195A	-B	PENETRATION ROOM COOLER FAN	NBNEQ-ITS -002	EED0033	
1-TS -030-0195B	-B	PENETRATION ROOM COOLER FAN	NBNEQ-ITS -002	EED0033	
2-TS -030-0195B	-B	PENETRATION ROOM COOLER FAN	NBNEQ-ITS -002	EED0033	
1-HS -030-0196	-A	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
2-HS -030-0196	-A	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
1-NTR -030-0196	-A	EL 713 PENETRATION ROOM COOLER	NBNEQ-NOT -004		

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-TS -030-0196A -A	PENETRATION ROOM COOLER FAN	WBNEQ-ITS -002	EEB0033	
1-TS -030-0196B -A	PENETRATION ROOM COOLER FAN	WBNEQ-ITS -002	EEB0033	
1-HS -030-0197 -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
2-HS -030-0197 -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-NTR -030-0197 -B	EL 713 PENETRATION ROOM COOLER	WBNEQ-NOT -004		
1-TS -030-0197A -B	PENETRATION ROOM COOLER FAN	WBNEQ-ITS -002	EEB0033	
1-TS -030-0197B -B	PENETRATION ROOM COOLER FAN	WBNEQ-ITS -002	EEB0033	
2-HS -030-0200 -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
2-NTR -030-0200 -A	EGTS COOLER FAN	WBNEQ-NOT -004		
2-TS -030-0200A -A	EGTS COOLER FAN	WBNEQ-ITS -002		
1-HS -030-0201 -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
2-HS -030-0201 -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-TS -030-0201A -A	PIPE CHASE COOLERS FAN	WBNEQ-ITS -002		
1-TS -030-0201B -A	PIPE CHASE COOLERS FAN	WBNEQ-ITS -002		
1-HS -030-0202 -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
2-HS -030-0202 -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-TS -030-0202A -B	PIPE CHASE COOLERS FAN	WBNEQ-ITS -002		
1-TS -030-0202B -B	PIPE CHASE COOLERS FAN	WBNEQ-ITS -002		
2-HS -030-0207 -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
2-HTR -030-0207	-B	EGTS COOLER FAN	WBNEQ-NOT -004		
2-TS -030-0207A	-B	EGTS COOLER FAN	WBNEQ-ITS -002		
1-HS -030-0214	-S	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -030-0296	-A	INTERIM ISOL DAMPER CDWE	WBNEQ-SOL -003		
1-HS -030-0296	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCO -030-0296/ZS1	-A	INTERIM ISOL DAMPER CDWE POS SWITCH	WBNEQ-IZS -001		
1-FCO -030-0296/ZS2		INTERIM ISOL DAMPER CDWE POS SWITCH	WBNEQ-IZS -001		
1-FSV -030-0297	-B	INTERIM ISOL DAMPER CDWE	WBNEQ-SOL -003		
1-HS -030-0297	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCO -030-0297/ZS1	-B	INTERIM ISOL DAMPER CDWE POS SWITCH	WBNEQ-IZS -001		
1-FCO -030-0297/ZS2	-B	INTERIM ISOL DAMPER CDWE POS SWITCH	WBNEQ-IZS -001		
1-FSV -030-0298	-B	INTERIM ISOL DAMPER CDWE	WBNEQ-SOL -003		
1-HS -030-0298	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCO -030-0298/ZS1	-B	INTERIM ISOL DAMPER CDWE POS SWITCH	WBNEQ-IZS -001		
1-FCO -030-0298/ZS2	-B	INTERIM ISOL DAMPER CDWE POS SWITCH	WBNEQ-IZS -001		
1-FSV -030-0299	-A	INTERIM ISOL DAMPER CDWE	WBNEQ-SOL -003		
1-HS -030-0299	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCO -030-0299/ZS1	-A	INTERIM ISOL DAMPER CDWE POS SWITCH	WBNEQ-IZS -001		

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-FCO -030-0299/ZS2 -A	INTERIM ISOL DAMPER CONE POS SWITCH	WBNEQ-IZS -001		
1-PT -030-0310 -A	CONTAINMENT PRESSURE TRANSMITTER	WBNEQ-IPT -001	EEB0070	P/T
1-PT -030-0311 -B	CONTAINMENT PRESSURE TRANSMITTER	WBNEQ-IPT -001	EEB0070	P/T
0-HS -031-0049B -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
0-HS -031-0080 -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
0-HS -031-0096 -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -031-0305 -B	INCORE INST RM CHILLA CWR ISLN VALVE	WBNEQ-SOL -003	EEB0065	
1-FCV -031-0305/ZS1 -B	IIR CHILLER A CWR ISLN VALVE LIMIT SW	WBNEQ-IZS -004	EEB0058	PANX
1-FCV -031-0305/ZS2 -B	IIR CHILLER A CWR ISLN VALVE LIMIT SW	WBNEQ-IZS -004	EEB0058	PANX
1-FSV -031-0306 -A	INCORE INST RM CHILLA CWR ISLN VALVE	WBNEQ-SOL -003	EEB0019	
1-FCV -031-0306/ZS1CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -031-0306/ZS1 -A	IIR CHILLER A CWR ISLN VALVE LIMIT SW	WBNEQ-IZS -004	EEB0006	PANX
1-FCV -031-0306/ZS2CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -031-0306/ZS2 -A	IIR CHILLER A CWR ISLN VALVE LIMIT SW	WBNEQ-IZS -004	EEB0006	PANX
1-FSV -031-0308 -A	INCORE INST RM CHILLA CWR ISLN VALVE	WBNEQ-SOL -003	EEB0065	
1-FCV -031-0308/ZS1CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ TNI
1-FCV -031-0308/ZS1 -A	IIR CHILLER A CWS ISLN VALVE LIMIT SW	WBNEQ-IZS -004	EEB0006	PANX
1-FCV -031-0308/ZS2CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -031-0308/ZS2 -A	IIR CHILLER A CWS ISLN VALVE LIMIT SW	WBNEQ-IZS -004	EEB0006	PANX
1-FSV -031-0309 -B	INCORE INST RM CHILLA CHR ISLN VALVE	WBNEQ-SOL -003	EEB0065	
1-FCV -031-0309/ZS1 -B	IIR CHILLER A CWS ISLN VALVE LIMIT SW	WBNEQ-IZS -004	EEB0058	PANX
1-FCV -031-0309/ZS2 -B	IIR CHILLER A CWS ISLN VALVE LIMIT SW	WBNEQ-IZS -004	EEB0058	PANX
1-FSV -031-0326 -A	INCORE INST RM CHILLB CHR ISLN VALVE	WBNEQ-SOL -003	EEB0065	
1-FCV -031-0326/ZS1 -A	IIR CHILLER B CHR ISLN VALVE LIMIT SW	WBNEQ-IZS -004	EEB0058	PANX
1-FCV -031-0326/ZS2 -A	INCORE INSTR RM CHILLER B CHR ISO VL	WBNEQ-IZS -003	EEB0058	PANX
1-FSV -031-0327 -B	INCORE INST RM CHILLB CHR ISLN VALVE	WBNEQ-SOL -003	EEB0065	
1-FCV -031-0327/ZS1CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -031-0327/ZS1 -B	IIR CHILLER B CHR ISLN VALVE LIMIT SW	WBNEQ-IZS -004	EEB0093	PANX
1-FCV -031-0327/ZS2CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -031-0327/ZS2 -B	IIR CHILLER B CHR ISLN VALVE LIMIT SW	WBNEQ-IZS -004	EEB0093	PAN
1-FSV -031-0329 -B	INCORE INST RM CHILLB CHR ISLN VALVE	WBNEQ-SOL -003	EEB0065	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
IE ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TRI
1-FCV -031-0329/ZS1CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -031-0329/ZS1 -B	IIR CHILLER B CMR ISLN VALVE LIMIT SW	WBNEQ-IZS -004	EEB0006	PAMX
1-FCV -031-0329/ZS2CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -031-0329/ZS2 -B	IIR CHILLER B CMR ISLN VALVE LIMIT SW	WBNEQ-IZS -004	EEB0006	PAMX
1-FSV -031-0330 -A	INCORE INST RH CHILLB CMR ISLN VALVE	WBNEQ-SOL -003	EEB0065	
1-FCV -031-0330/ZS1 -A	IIR CHILLER C CMS ISLN VALVE LIMIT SW	WBNEQ-IZS -004	EEB0058	PAMX
1-FCV -031-0330/ZS2 -A	IIR CHILLER B CMR ISLN VALVE LIMIT SW	WBNEQ-IZS -004	EEB0058	PAMX
0-HS -031-0400B -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -032-0080A -A	REACTOR BLDG UNIT 1 TRAIN A ISLN	WBNEQ-SOL -005	EEB0065	
1-FCV -032-0080/ZS1 -A	RB UNIT 1 TRAIN A ISLN VALVE POS SW	WBNEQ-IZS -001	EEB0051	PAMX
1-FSV -032-0080B -A	REACTOR BLDG UNIT 1 TEST SOL	WBNEQ-SOL -005	EEB0044	
1-FCV -032-0080/ZS2 -A	RB UNIT 1 TRAIN A ISLN VALVE POS SW	WBNEQ-IZS -001	EEB0051	PAMX
1-FSV -032-0102A -B	REACTOR BLDG UNIT 1 TRAIN B ISLN	WBNEQ-SOL -005	EEB0065	
1-FCV -032-0102/ZS1 -B	RB UNIT 1 TRAIN B ISLN VALVE POS SW	WBNEQ-IZS -001	EEB0051	PAMX
1-FSV -032-0102B -B	REACTOR BLDG UNIT 1 TEST SOL	WBNEQ-SOL -005	EEB0044	
1-FCV -032-0102/ZS2 -B	RB UNIT 1 TRAIN B ISLN VALVE POS SW	WBNEQ-IZS -001	EEB0051	PAMX



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ TRZ
1-FSV -032-0110A	-A	RB UNIT 1 NON-ESNTL CONT AIR ISLN	WBNEQ-SOL -005	EEB0065	
1-FCV -032-0110/ZS1	-A	RB U1 NON ESNTL ISLNVALVE POS SWITCH	WBNEQ-IZS -001	EEB0051	PANZ
1-FSV -032-0110B	-A	RB UNIT 1 NON-ESNTL CONT AIR ISLN	WBNEQ-SOL -005	EEB0044	
1-FCV -032-0110/ZS2	-A	RB U1 NON ESNTL ISLNVALVE POS SWITCH	WBNEQ-IZS -001	EEB0051	PANZ
1-FSV -043-0002	-B	PRESSURIZER GAS CNTHT ISLN VALVE	WBNEQ-SOL -003	EEB0020	
1-HS -043-0002	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-HS -043-0002A	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -043-0003	-A	PRESSURIZER GAS CNTHT ISLN VALVE	WBNEQ-SOL -003	EEB0065	
1-HS -043-0003	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -043-0011	-B	PRESSURIZER LIQ CNTHT ISLN VALVE	WBNEQ-SOL -003	EEB0020	
1-HS -043-0011	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -043-0012	-A	PRESSURIZER LIQ CNTHT ISLN VALVE	WBNEQ-SOL -003	EEB0065	
1-HS -043-0012	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -043-0022	-B	RCS HOT LEG HDR CNTHT ISLN VALVE	WBNEQ-SOL -003	EEB0020	
1-HS -043-0022	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -043-0023	-A	RCS HOT LEG HDR CNTHT ISLN VALVE	WBNEQ-SOL -003	EEB0065	
1-HS -043-0023	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -043-0034	-B	ACCUM TK HDR CNTHT ISLN VALVE	WBNEQ-SOL -003	EEB0020	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAW/ THI
1-HS -043-0034	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -043-0035	-A	ACCUM TK HDR CNTNT ISLN VALVE	WBNEQ-SOL -003	EEB0039	
1-HS -043-0035	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -043-0054D	-B	STEAM GEN 1 SAMPLE CNTNT ISLN VALVE	WBNEQ-SOL -003	EEB0065	
1-HS -043-0054D	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -043-0055	-A	STEAM GEN BLDG 1 SAMPLE ISLN VALVE	WBNEQ-SOL -003	EEB0039	
1-HS -043-0055	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -043-0056D	-B	STEAM GEN 2 CNTNT ISLN VALVE	WBNEQ-SOL -003	EEB0039	
1-HS -043-0056D	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -043-0058	-A	STEAM GEN BLDG 2 SAMPLE ISLN VALVE	WBNEQ-SOL -003	EEB0039	
1-HS -043-0058	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -043-0059D	-B	STEAM GEN 3 CNTNT ISLN VALVE	WBNEQ-SOL -003	EEB0039	
1-HS -043-0059D	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -043-0061	-A	STEAM GEN BLDG 3 SAMPLE ISLN VALVE	WBNEQ-SOL -003	EEB0039	
1-HS -043-0061	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -043-0063D	-B	STEAM GEN 4 CNTNT ISLN VALVE	WBNEQ-SOL -003	EEB0039	
1-HS -043-0063D	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -043-0064	-A	STEAM GEN BLDG 4 SAMPLE ISLN VALVE	WBNEQ-SOL -003	EEB0039	
1-HS -043-0064	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-FSV -043-0075	-B	DNSTR EXCESS LTDN HTX ISLN VALVE	WBNEQ-SOL -003	EEB0020	
1-HS -043-0075	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -043-0077	-A	DNSTR EXCESS LTDN HTX ISLN VALVE	WBNEQ-SOL -003	EEB0039	
1-HS -043-0077	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-H2AN-043-0200	-A	LOCA H2 CONTAINMENT MONITOR	WBNEQ-ILP -001	EEB0026	P/T
1-H2E -043-0200	-A	LOCA H2 CONTAINMENT MONITOR ELEMENT	WBNEQ-ILP -001		P/T
1-HS -043-02000	-A	LOCA H2 CNTMT MON FAN SW	WBNEQ-ILP -001		THI
1-FSV -043-0201	CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FSV -043-0201	-A	LOCA H2 CNTMT MONITOR ISLN SOL VLV	WBNEQ-SOL -003	EEB0020	THI
1-FSV -043-0202	CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FSV -043-0202	-A	LOCA H2 CNTMT MONITOR ISLN SOL VLV	WBNEQ-SOL -003	EEB0020	THI
1-FSV -043-0207	CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FSV -043-0207	-B	LOCA H2 CNTMT MONITOR ISLN SOL VLV	WBNEQ-SOL -003	EEB0020	THI
1-FSV -043-0208	CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FSV -043-0208	-B	LOCA H2 CNTMT MONITOR ISLN SOL VLV	WBNEQ-SOL -003	EEB0020	THI
1-H2AN-043-0210	-B	LOCA H2 CONTAINMENT MONITOR	WBNEQ-ILP -001	EEB0026	P/T
1-H2E -043-0210	-B	LOCA H2 CONTAINMENT MONITOR ELEMENT	WBNEQ-ILP -001		P/T

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1-HS -043-02100 -B	LOCA H2 CNTHT NON FAN SM	WBNEQ-ILP -001		THI
1-FSV -043-0250 -A	POST ACD SHPLG HOT LEG NO.1 ISLN VALVE	WBNEQ-SOL -002	EEB0001	THI
1-FSV -043-0251 CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FSV -043-0251 -A	POST ACD SHPLG HOT LEG NO.1 ISLN VALVE	WBNEQ-SOL -002	EEB0001	PANX
1-FSV -043-0268 CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FSV -043-0268 -A	POST ACD SHPLG RAD WASTE ISLN VALVE	WBNEQ-SOL -002	EEB0001	
1-FSV -043-0287 -A	POST ACD SHPLG AIR ISLN VALVE	WBNEQ-SOL -002	EEB0001	PANX
1-FSV -043-0288 CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FSV -043-0288 -A	POST ACD SHPLG CNTHT AIR ISLN VLV	WBNEQ-SOL -002	EEB0001	PANX
1-FSV -043-0307 -A	POST ACD SHPLG AIR ISLN VALVE	WBNEQ-SOL -002	EEB0001	PANX
1-FSV -043-0309 -B	POST ACD SHPLG HOT LEG NO.3 ISLN VALVE	WBNEQ-SOL -002	EEB0001	PANX
1-FSV -043-0310 CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FSV -043-0310 -B	POST ACD SHPLG HOT LEG NO.3 ISLN VALVE	WBNEQ-SOL -002	EEB0001	PANX
1-FSV -043-0312 CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FSV -043-0312 -B	POST ACD SHPLG REAC CNTHT SUMP ISLN VLV	WBNEQ-SOL -002	EEB0001	
1-FSV -043-0318 -B	POST ACD SHPLG CNTHT AIR ISLN VLV	WBNEQ-SOL -002	EEB0001	PANX

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAR/ TKI
1-FSV -043-0319 CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FSV -043-0319 -B	POST ACD SHPLG CNTHNT AIR ISLN VLV	WBNEQ-SOL -002	EEB0001	PAMX
1-FSV -043-0325 -B	POST ACD SHPLG CNTHNT AIR ISLN VLV	WBNEQ-SOL -002	EEB0001	PAMX
1-FSV -043-0341 -B	POST ACD SHPLG DR TOCHTNT SUMP ISLN VLV	WBNEQ-SOL -002	EEB0001	
1-FSV -043-0342 -A	POST ACD SHPLG DR TOCHTNT SUMP ISLN VLV	WBNEQ-SOL -002	EEB0001	PAMX
1-FSV -061-0097 -B	INLET ISLN VLV REACTOR BLDG	WBNEQ-SOL -006	EEB0039	
1-FCV -061-0097/2S1CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -061-0097/2S1 -B	INLET ISLN VALVE REACTOR BLDG POS SW	WBNEQ-IZS -002	EEB0051	
1-FCV -061-0097/2S2CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -061-0097/2S2 -B	INLET ISLN VALVE REACTOR BLDG POS SW	WBNEQ-IZS -002	EEB0051	
1-FSV -061-0122 -B	OUTLET ISLN VLV REACTOR BLDG	WBNEQ-SOL -006	EEB0039	
1-FCV -061-0122/2S1CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -061-0122/2S1 -B	OUTLET ISLN VALVE REACTOR BLDG POS SW	WBNEQ-IZS -002	EEB0051	
1-FCV -061-0122/2S2CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -061-0122/2S2 -B	OUTLET ISLN VALVE REACTOR BLDG POS SW	WBNEQ-IZS -002	EEB0051	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
1-FSV -061-0192 -B	GLYCOL SUPPLY ISOLATION VALVE	WBNEQ-SOL -006	EEB0039	
1-FCV -061-0192/ZS1CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -061-0192/ZS1 -B	GLYCOL SUP ISLN VALVE POS SW	WBNEQ-1ZS -002	EEB0051	
1-FCV -061-0192/ZS2CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -061-0192/ZS2 -B	GLYCOL SUP ISLN VALVE POS SW	WBNEQ-1ZS -002	EEB0051	
1-FSV -061-0194 -B	GLYCOL RETURN ISOLATION VALVE	WBNEQ-SOL -006	EEB0039	
1-FCV -061-0194/ZS1CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -061-0194/ZS1 -B	GLYCOL RETURN ISLN VALVE POS SW	WBNEQ-1ZS -002	EEB0051	
1-FCV -061-0194/ZS2CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -061-0194/ZS2 -B	GLYCOL RETURN ISLN VALVE POS SW	WBNEQ-1ZS -002	EEB0051	
1-FCV -062-0061 -B	SEAL FLOW RETURN ISOLATION VALVE	WBNEQ-NOV -001	NEB-XX-36	PAMX
1-FCV -062-0063 -A	SEAL FLOW RETURN ISLN VALVE	WBNEQ-NOV -003	NEB-XX-37	PAMX
1-HS -062-0063B -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	PAMX
1-FSV -062-0069 -A	RC LOOP 3 LETDOWN FLOW	WBNEQ-SOL -006	EEB0028	
1-FCV -062-0069/ZS1CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -062-0069/ZS1 -A	RC LOOP 3 LETDOWN FLOW POS SW	WBNEQ-1ZS -001	EEB0069	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
IE ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ TNI
1-FCV -062-0069/2S2CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -062-0069/2S2 -A	RC LOOP 3 LETDOWN FLOW POS SW	WBNEQ-IZS -001	EEB0069	
1-FSV -062-0070 -A	RC LOOP 3 LETDOWN FLOW	WBNEQ-SOL -006	EEB0020	
1-FCV -062-0070/2S1CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -062-0070/2S1 -A	RC LOOP 3 LETDOWN FLOW POS SW	WBNEQ-IZS -001	EEB0068	
1-FCV -062-0070/2S2CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -062-0070/2S2 -A	RC LOOP 3 LETDOWN FLOW POS SW	WBNEQ-IZS -001	EEB0068	
1-FSV -062-0072 -A	REGEN HTX LTDN ISLN VALVE A	WBNEQ-SOL -006	EEB0028	
1-FSV -062-0073 -A	REGEN HTX LTDN ISLN VALVE B	WBNEQ-SOL -006	EEB0028	
1-FSV -062-0074 -A	REGEN HTX LTDN ISLN VALVE C	WBNEQ-SOL -006	EEB0028	
1-FSV -062-0076 -A	REGEN HTX LTDN ISLN VALVE	WBNEQ-SOL -006	EEB0019	
1-FSV -062-0077 -B	LETDOWN LINE ISOLATION VALVE	WBNEQ-SOL -006	NEB-XX-6	
1-FCV -062-0077/2S1 -B	LTDN LINE ISOL VLV FLOW CONTROL POS SW	WBNEQ-IZS -001	NEB-XX-11	PANX
1-FCV -062-0077/2S2 -B	LTDN LINE ISOL VLV FLOW CONTROL POS SW	WBNEQ-IZS -001	NEB-XX-11	PANX
1-FCV -062-0090 -A	CHARGING FLOW ISLN VALVE	WBNEQ-NOV -003	NEB-XX-37	
1-HS -062-0090B -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TKI
1-FCV -062-0091	-B	CHARGING FLOW ISLN VALVE	WBNEQ-NOV -003	NEB-XX-37	
1-HS -062-0091B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -062-0098	-A	CHARGING PUMP 1A-A MIN FLOW	WBNEQ-NOV -003	NEB-XX-37	
1-HS -062-0098B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -062-0099	-A	CHARGING PUMP 1A-A MIN FLOW	WBNEQ-NOV -003	NEB-XX-37	
1-HS -062-0099B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-NTR -062-0104	-B	CVCS PUMP MOTOR	WBNEQ-NOT -001	NEB-XX-31	
1-NTR -062-0108	-A	CVCS PUMP MOTOR	WBNEQ-NOT -001	NEB-XX-31	
1-HS -062-0108B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-LCV -062-0132	-A	VCT OUTLET ISOLATION VALVE LEVEL CONTROL	WBNEQ-NOV -003	NEB-XX-37	
1-HS -062-0132B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-LCV -062-0133	-B	VCT OUTLET ISOLATION VALVE LEVEL CONTROL	WBNEQ-NOV -003	NEB-XX-37	
1-HS -062-0133B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-HS -062-0135B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-HS -062-0136B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -063-0001	-A	RNST TO RHR PUMP FLOW CONTROL VALVE	WBNEQ-NOV -003	NEB-XX-37	
1-HS -063-0001B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -063-0003	-A	SIS PUMP RECIRC TO RNST VALVE	WBNEQ-NOV -003	NEB-XX-37	
1-ZS -063-0003	-A	SIS PHP RECIRC TO RNST VLV ZONE SWITCH	WBNEQ-1ZS -001		
1-HS -063-0003B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1-FCV -063-0004	-B	SIS PUMP 1A-A DISCH TO RWST SHUTOFF VLV	WBNEQ-NOV -003	NEB-XX-37	
1-ZS -063-0004	-B	SIS PNP RECIRC TO RWST VLV ZONE SWITCH	WBNEQ-IZS -001		
1-HS -063-0004B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -063-0005	-B	RWST TO SIS PUMP FLOW CONTROL VALVE	WBNEQ-NOV -003	NEB-XX-37	
1-HS -063-0005B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -063-0006	-B	SIS PUMP INLET TO CVCS CHG PUMP VALVE	WBNEQ-NOV -003	NEB-XX-37	
1-HS -063-0006B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -063-0007	-A	SIS PUMP INLET TO CVCS CHG PUMP VALVE	WBNEQ-NOV -003	NEB-XX-37	
1-HS -063-0007B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -063-0008	-A	RHR HXA TO CVCS CHG PUMP	WBNEQ-NOV -003	NEB-XX-37	
1-HS -063-0008B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-NTR -063-0010	-A	SIS PUMP MOTOR	WBNEQ-HOT -001	NEB-XX-31	
1-HS -063-0010B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -063-0011	-B	RHR HTX B TO SIS PUMP	WBNEQ-NOV -003	NEB-XX-37	
1-HS -063-0011B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-NTR -063-0015	-B	SIS PUMP MOTOR	WBNEQ-HOT -001	NEB-XX-31	
1-HS -063-0015B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -063-0022	-B	SIS PNP COLD LEG INJECTION	WBNEQ-NOV -003	NEB-XX-37	
1-HS -063-0022B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -063-0023	-B	SIS ACCUM FILL LINE ISLN SW	WBNEQ-SOL -006	NEB-XX-6	PAN

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAW/ THI
1-FCV -063-0023/251 -B	SIS ACCUM FILL LINE ISOL VLV POS SWITCH	WBNEQ-1ZS -001	NEB-XX-11	PAW
1-FCV -063-0023/252 -B	SIS ACCUM FILL LINE ISOL VLV POS SWITCH	WBNEQ-1ZS -001	NEB-XX-11	PAW
1-FCV -063-0025 -B	SIS BORON INJECTION TANK SHUTOFF VALVE	WBNEQ-NOV -003	NEB-XX-37	
1-HS -063-0025B -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -063-0026 -A	SIS BORON INJECTION TANK SHUTOFF VALVE	WBNEQ-NOV -003	NEB-XX-37	
1-HS -063-0026B -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -063-0047 -A	SIS PMP 1A-A INLET VALVE	WBNEQ-NOV -003	NEB-XX-37	
1-HS -063-0047B -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -063-0048 -B	SIS PMP 1B-B INLET VALVE	WBNEQ-NOV -003	NEB-XX-37	
1-HS -063-0048B -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -063-0064 -A	SIS ACCUM TANK NO 2 HDR INLET VLV	WBNEQ-SOL -006	NEB-XX-6	
1-FCV -063-0064/251 -A	SIS ACCUM TANK N2 HDR INLET VLV POS SW	WBNEQ-1ZS -001	NEB-XX-11	PAW1
1-FCV -063-0064/252 -A	SIS ACCUM TANK N2 HDR INLET VLV POS SW	WBNEQ-1ZS -001	NEB-XX-11	PAW1
1-FSV -063-0071 -A	SIS CHECK VLV LEAK TEST ISLN	WBNEQ-SOL -006	EEB0070	
1-FCV -063-0071/2S1CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -063-0071/2S1 -A	SIS CHECK VALVE LEAKTEST ISLN POS SW	WBNEQ-1ZS -002	EEB0051	PAW1
1-FCV -063-0071/2S2CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1-FCV -063-0071/ZS2 -A	SIS CHECK VALVE LEAKTEST ISLN POS SW	WBNEQ-IZS -002	EEB0051	PANX
1-FCV -063-0072 -A	CNTKT SUMP TO RHR PUMP A-A	WBNEQ-NOV -001	NEB-XX-38	PANX
1-FCV -063-0072/ZS1 -A	CNTKT SUMP TO RHR PUMP A-A POS SW	WBNEQ-IZS -002	EEB0061	PANX
1-HS -063-0072B -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -063-0072/ZS2 -A	CNTKT SUMP TO RHR PUMP A-A POS SW	WBNEQ-IZS -002	EEB0061	PANX
1-FCV -063-0073 -B	CNTKT SUMP TO RHR PUMP B-B	WBNEQ-NOV -001	NEB-XX-38	PANX
1-FCV -063-0073/ZS1 -B	CNTKT SUMP TO RHR PUMP B-B POS SW	WBNEQ-IZS -002	EEB0061	PANX
1-HS -063-0073B -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -063-0073/ZS2 -B	CNTKT SUMP TO RHR PUMP B-B POS SW	WBNEQ-IZS -002	EEB0061	PANX
1-FSV -063-0084 -B	SIS CHECK VLV LEAK TEST ISLN	WBNEQ-SOL -006	NEB-XX-6	
1-FCV -063-0084/ZS1 -B	SIS CHK VLV LEAK TEST ISOL VLV POS SW	WBNEQ-IZS -001	NEB-XX-11	PANX
1-FCV -063-0084/ZS2 -B	SIS CHK VLV LEAK TEST ISOL VLV POS SW	WBNEQ-IZS -001	NEB-XX-11	PANX
1-FCV -063-0093 -A	RHR RD RCS 2 AND 3 FLOW CONTROL VALVE	WBNEQ-NOV -003	NEB-XX-37	
1-HS -063-0093B -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -063-0094 -B	RHR TO RCS 1 AND 4 FLOW CONTROL VALVE	WBNEQ-NOV -003	NEB-XX-37	
1-HS -063-0094B -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -063-0152 -A	SIS PUMP 1A-A OUTFLOW CONT VALVE	WBNEQ-NOV -003	NEB-XX-37	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
1-HS -063-0152B -A	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
1-FCV -063-0153 -B	SIS PUMP 1B-B OUTFLOW CONT VALVE	NBNEQ-NOV -003	NEB-XX-37	
1-HS -063-0153B -B	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
1-FCV -063-0156 -A	SIS PUMP OUTLET TO RCS LOOP 1 AND 3 HL	NBNEQ-NOV -003	NEB-XX-37	
1-HS -063-0156B -A	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
1-FCV -063-0157 -B	SIS PUMP OUTLET TO RCS LOOP 2 AND 4 HL	NBNEQ-NOV -003	NEB-XX-37	
1-HS -063-0157B -B	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
1-FCV -063-0172 -B	RHR TO RCS HOTLEG 1 & 3 FLOW ISLN VLV	NBNEQ-NOV -001	NEB-XX-37	
1-HS -063-0172B -B	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
1-FCV -063-0175 -B	SIS PUMP 1B-B DISC HARGE TO RWST SHUT V	NBNEQ-NOV -003	NEB-XX-37	
1-ZS -063-0175 -B	SIS PNP 1B-B DISCH RWST SHTOFF POS SW	NBNEQ-1ZS -001		
1-HS -063-0175B -B	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
1-FCV -063-0177 -A	SIS PUMP INLET TO CVCS CHG PUMP	NBNEQ-NOV -003	NEB-XX-37	
1-HS -063-0177B -A	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
1-LT -063-0180 -D	CHTNT LEVEL NIN LEVEL RHR RECIR	NBNEQ-XNTR-001	NEB-XX-47	P/T
1-LT -063-0181 -E	CHTNT LEVEL NIN LEVEL RHR RECIR	NBNEQ-XNTR-001	NEB-XX-47	P/T
1-LT -063-0182 -F	CHTNT LEVEL NIN LEVEL RHR RECIR	NBNEQ-XNTR-001	NEB-XX-47	THI
1-LT -063-0183 -G	CHTNT LEVEL NIN LEVEL RHR RECIR	NBNEQ-XNTR-001	NEB-63-28	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
2-FSV -065-0004	-B	CNTHT ANN VAC FAN ISLN DNPR	NBNEQ-SOL -007		
2-FCV -065-0004/1ZS1	-B	CNTHT ANN VAC FANS ISOL DNPR POS SW	NBNEQ-1ZS -001		
2-FCV -065-0004/1ZS2	-B	CNTHT ANN VAC FANS ISOL DNPR POS SW	NBNEQ-1ZS -001		
2-FSV -065-0005	-A	CNTHT ANN VAC FANS ISLN DNPR	NBNEQ-SOL -007		
2-FCV -065-0005/1ZS1	-A	CNTHT ANN VAC FANS ISOL DNPR POS SW	NBNEQ-1ZS -001		
2-FCV -065-0005/1ZS2	-A	CNTHT ANN VAC FANS ISOL DNPR POS SW	NBNEQ-1ZS -001		
2-FSV -065-0007	-B	EGTS TRAIN A UNIT 2 SUCTION	NBNEQ-SOL -003		
1-FSV -065-0008	-B	EGTS TRAIN A UNIT 1 SUCTION	NBNEQ-SOL -003	NEB-65-0163	
2-FSV -065-0009	-A	EGTS TRAIN A UNIT 2 SUCTION	NBNEQ-SOL -007		
1-FSV -065-0010	-A	EGTS TRAIN A UNIT 1 SUCTION	NBNEQ-SOL -003	NEB-65-0156	
0-NTR -065-0023	-A	EGTS FAN MOTOR A-A	NBNEQ-NOT -003	NEB-65-0007	
0-HS -065-0023B	-A	HANDSWITCH	NBNEQ-HS -001	EED-HS-1	
0-FSV -065-0024	-A	EGTS TRAIN A FAN A-AISLN DNPR	NBNEQ-SOL -005	NEB-65-0156	
0-FS -065-0025A/B	-A	EGTS TRAIN A RH NTR INTERLOCK	NBNEQ-IFS -001	EED0030	
0-FS -065-0025B/A	-A	EGTS TRAIN A DECRY COOL VALVE CONTROL	NBNEQ-IFS -001	EED0030	
1-FSV -065-0026	-A	UNIT 1 SHEILD BLDG EXH A	NBNEQ-SOL -003	NEB-65-0030	
1-FSV -065-0027	-B	UNIT 1 SHEILD BLDG EXH B	NBNEQ-SOL -003	NEB-65-0030	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
0-FSV -065-0028A	-B	EGTS TRAIN A DECAY COOL VALVE A	WBNEQ-SOL -003	NEB-65-0163	
0-FSV -065-0028B	-B	EGTS TRAIN B DECAY COOL VALVE B	WBNEQ-SOL -003	NEB-65-0163	
2-FSV -065-0029	-B	EGTS TRAIN B UNIT 2 SUCTION	WBNEQ-SOL -007	NO EQS NUMBER	
1-FSV -065-0030	-B	EGTS TRAIN B UNIT 1 SUCTION	WBNEQ-SOL -003	NEB-65-0156	
0-FS -065-0031A/B	-B	EGTS TRAIN A DECAY COOL VALVE CONTROL	WBNEQ-IFS -001	EEB0030	
0-FS -065-0031B/A	-B	EGTS TRAIN A FAN INTERLOCK	WBNEQ-IFS -001	EEB0030	
0-HTR -065-0042	-B	EGTS FAN MOTOR B-B	WBNEQ-HOT -003	NEB-65-0008	
0-HS -065-0042B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
0-FSV -065-0043	-B	EGTS TRAIN B FAN B-BISLN DNPR	WBNEQ-SOL -005	EEB0093	
0-FS -065-0044A/B	-B	EGTS TRAIN B RH HTR INTERLOCK	WBNEQ-IFS -001	EEB0030	
0-FS -065-0044B/A	-B	EGTS TRAIN B DECAY COOL VALVE CONTROL	WBNEQ-IFS -001	EEB0030	
0-FSV -065-0047A	-A	EGTS TRAIN B DECAY COOL VALVE A	WBNEQ-SOL -003	NEB-65-0130	
0-FSV -065-0047B	-A	EGTS TRAIN B DECAY COOL VALVE CONT	WBNEQ-SOL -003	NEB-65-0130	
2-FSV -065-0050	-A	EGTS TRAIN B UNIT 2 SUCTION	WBNEQ-SOL -003	NO EQS NUMBER	
1-FSV -065-0051	-A	EGTS TRAIN B UNIT 1 SUCTION	WBNEQ-SOL -003	NEB-65-0130	
1-FSV -065-0052	-A	CHTNT ANNULUS VAC FANS ISLN DNPR	WBNEQ-SOL -003	NEB-65-0156	
1-FCV -065-0052/251	-A	CHTNT ANN VAC FANS ISLN VALVE POS SH	WBNEQ-IZS -001		

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TRI
1-FCV -065-0052/2S2 -A	CNTHT ANN VAC FANS ISLN VALVE POS SW	NBNEQ-1ZS -001		
1-FSV -065-0053 -B	CNTHT ANNULUS VAC FANS ISLN DRPR	NBNEQ-SOL -003	NEB-65-0156	
1-FCV -065-0053/2S1 -B	CNTHT ANN VAC FANS ISLN VALVE POS SW	NBNEQ-1ZS -001		
1-FCV -065-0053/2S2 -B	CNTHT ANN VAC FANS ISLN VALVE POS SW	NBNEQ-1ZS -001		
0-FS -065-0055A/B -A	EGTS TRAIN B FAN INTERLOCK FLOW SW	NBNEQ-IFS -001	EEB0030	
0-FS -065-0055B/A -A	EGTS TRAIN B FAN INTERLOCK FLOW SW	NBNEQ-IFS -001	EEB0030	
1-HS -065-0080 -A	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
1-PSV -065-0081 -A	SHLD BLDG VENT AND CONT ANNLS ISLN VLV	NBNEQ-SOL -006	NEB-65-0132	
1-HS -065-0082 -B	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
1-PSV -065-0083 -B	SHLD BLDG VENT AND CONT ANNLS ISLN VLV	NBNEQ-SOL -006	NEB-65-0132	
1-HS -065-0090 -A	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
1-HS -065-0097 -B	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
1-FCV -067-0083 -A	LOWER CNTHT A COOLERSUPPLY ISLN VALVE	NBNEQ-NOV -003	NEB-67-0136	PANZ
1-HS -067-0083B -A	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
1-FCV -067-0087 -A	LOWER CNTHT A COOLERDISCH ISLN VALVE IC	NBNEQ-NOV -001	NEB-67-0134	PANZ
1-FCV -067-0088 -B	LOWER CNTHT A CLRS DISCH ISLN VALVE IC	NBNEQ-NOV -003	NEB-67-0136	PANZ
1-HS -067-0088B -B	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAR/ THI
1-FCV -067-0091	-A	LOWER CNTMT C CLRS SUPPLY ISLN VALVE	WBNEQ-NOV -003	NEB-67-0136	PANX
1-HS -067-0091B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -067-0095	-A	LOWER CNTMT C COOLERDISCH ISLN VALVE IC	WBNEQ-NOV -001	NEB-67-0134	PANX
1-FCV -067-0096	-B	LOWER CNTMT C CLRS DISCH ISLN VALVE	WBNEQ-NOV -003	NEB-67-0136	PANX
1-HS -067-0096B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -067-0099	-B	LOWER CNTMT B CLRS SUPPLY ISLN VALVE	WBNEQ-NOV -003	NEB-67-0136	PANX
1-HS -067-0099B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -067-0103	-B	LOWER CNTMT B COOLERDISCH ISLN VALVE IC	WBNEQ-NOV -001	NEB-67-0134	PANX
1-FCV -067-0104	-A	LOWER CNTMT B CLRS DISCH ISLN VALVE DC	WBNEQ-NOV -003	NEB-67-0136	PANX
1-HS -067-0104B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -067-0107	-B	LOWER CNTMT D CLRS SUPPLY ISLN VALVE	WBNEQ-NOV -003	NEB-67-0136	PANX
1-HS -067-0107B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -067-0111	-B	LOWER CNTMT D COOLERDISCH ISLN VALVE IC	WBNEQ-NOV -001	NEB-67-0134	PANX
1-FCV -067-0112	-A	LOWER CNTMT D CLRS DISCH ISLN VALVE DC	WBNEQ-NOV -003	NEB-67-0136	PANX
1-HS -067-0112B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -067-0123	-B	CNTMT SPRAY HTX B SUPPLY CONTROL VALVE	WBNEQ-NOV -003	NEB-67-0137	
2-FCV -067-0123	-B	CNTMT SPRAY HTX B SUPPLY CONTROL VALVE	WBNEQ-NOV -003	NO EQS NUMBER	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
IE ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1-HS -067-0123B	-B HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
2-HS -067-0123B	-B HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -067-0124	-B CNTMT SPRAY HTX B DISCHARGE VALVE	WBNEQ-NOV -003	NEB-67-0139	
2-FCV -067-0124	-B CNTMT SPRAY HTX B DISCHARGE VALVE	WBNEQ-NOV -003	NO EQS NUMBER	
1-HS -067-0124B	-B HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
2-HS -067-0124B	-B HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -067-0125	-A CNTMT SPRAY HTX A SUPPLY CNTRL VALVE	WBNEQ-NOV -003	NEB-67-0137	
2-FCV -067-0125	-A CNTMT SPRAY HTX A SUPPLY CNTRL VALVE	WBNEQ-NOV -003	NO EQS NUMBER	
1-HS -067-0125B	-A HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
2-HS -067-0125B	-A HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -067-0126	-A CNTMT SPRAY HTX A DISCH VALVE	WBNEQ-NOV -003	NEB-67-0139	
2-FCV -067-0126	-A CNTMT SPRAY HTX A DISCH VALVE	WBNEQ-NOV -003	NO EQS NUMBER	
1-HS -067-0126B	-A HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
2-HS -067-0126B	-A HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -067-0130	-A UPPER CNTMT VENT CLRA SUPPLY ISLN VALVE	WBNEQ-NOV -003	NEB-67-0136	PANX
1-HS -067-0130B	-A HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -067-0131	-B UPPER CNTMT VENT CLRA ISLN VALVE OC	WBNEQ-NOV -003	NEB-67-0136	PANX
1-HS -067-0131B	-B HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -067-0133	-A UPPER CNTMT VENT CLRC SUPPLY ISLN VALVE	WBNEQ-NOV -003	NEB-67-0136	PANX

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1-HS -067-0133B -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -067-0134 -B	UPPER CHTMT CLR A DISCH ISLN VALVE	WBNEQ-NOV -003	NEB-67-0136	PANX
1-HS -067-0134B -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -067-0138 -B	UPPER CHTMT VENT CLRB SUPPLY ISLN VALVE	WBNEQ-NOV -003	NEB-67-0136	PANX
1-HS -067-0138B -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -067-0139 -A	UPPER CHTMT VENT CLRB ISLN VALVE DC	WBNEQ-NOV -003	NEB-67-0136	PANX
1-HS -067-0139B -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -067-0141 -B	UPPER CHTMT VENT CLRD SUPPLY ISLN VALVE	WBNEQ-NOV -003	NEB-67-0136	PANX
1-HS -067-0141B -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -067-0142 -A	UPPER CHTMT VENT CLRD ISLN VALVE DC	WBNEQ-NOV -003	NEB-67-0136	PANX
1-HS -067-0142B -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
0-HS -067-0152B -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
0-HS -067-0205B -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
0-HS -067-0208B -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-HS -067-0223B -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
2-HS -067-0223B -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -067-0295 -A	UPPER CHTMT VENT CLRA ISLN VLV INSIDE CN	WBNEQ-NOV -001	NEB-67-0135	PANX
1-FCV -067-0296 -A	UPPER CHTMT VENT CLRC ISLN VLV INSIDE CN	WBNEQ-NOV -001	NEB-67-0135	PANX

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1-FCV -067-0297	-B	UPPER CNTNT VENT CLRB ISLN VLV INSIDE CN	WBNEQ-NOV -001	NEB-67-0135	PANX
1-FCV -067-0298	-B	UPPER CNTNT VENT CLRD ISLN VLV INSIDE CN	WBNEQ-NOV -001	NEB-67-0135	PANX
2-FSV -067-0336	-A	EMERG GAS TRTMT ROOMCOOLER A ICR	WBNEQ-SOL -005	EEB0048	
2-FSV -067-0338	-B	EMERG GAS TRTMT ROOMCOOLER B ICR	WBNEQ-SOL -005	EEB0048	
1-FSV -067-0350	-A	PEN RM CLR A2 SUP CNTL VLV	WBNEQ-SOL -005	EEB0029	
2-FSV -067-0350	-A	PEN RM CLR A2 SUP CNTL VLV	WBNEQ-SOL -005	EEB0029	
1-FSV -067-0352	-B	PEN RM CLR B2 SUP CNTL VLV	WBNEQ-SOL -005	EEB0029	
2-FSV -067-0352	-B	PEN RM CLR B2 SUP CNTL VLV	WBNEQ-SOL -005	EEB0029	
1-FSV -067-0354	-A	PEN RM CLR A3 SUP CNTL VLV	WBNEQ-SOL -005	EEB0029	
2-FSV -067-0354	-A	PEN RM CLR A3 SUP CNTL VLV	WBNEQ-SOL -005	EEB0029	
1-FSV -067-0356	-B	PEN RM CLR B3 SUP CNTL VLV	WBNEQ-SOL -005	EEB0029	
2-FSV -067-0356	-B	PEN RM CLR B3 SUP CNTL VLV	WBNEQ-SOL -005	EEB0029	
1-HS -067-0458B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-HS -067-0478B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-TE -068-0001	CS-D	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-TE -068-0001	-D	RCS LOOP 1 HOT LEG TEMP	WBNEQ-ITE -003	NEB-68-23	PANX

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1-TE -068-0002A	-D	RCS LOOP 1 HOT LEG RTD MAIN TEMP	WBNEQ-ITE -002	NEB-68-24	
1-TE -068-0002B	-D	RCS LOOP 1 HOT LEG RTD MAIN TEMP	WBNEQ-ITE -002	NEB-68-24	
1-TE -068-0014A	-D	RCS LOOP 1 COLD LEG RTD MAIN TEMP	WBNEQ-ITE -002	NEB-68-24	
1-TE -068-0014B	-D	RCS LOOP 1 COLD LEG RTD MAIN TEMP	WBNEQ-ITE -002	NEB-68-24	
1-TE -068-0018	CS-D	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-TE -068-0018	-D	RCS LOOP 1 COLD LEG TEMP	WBNEQ-ITE -003	NEB-68-23	PANX
1-TE -068-0024	CS-D	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-TE -068-0024	-D	RCS LOOP 2 HOT LEG TEMP	WBNEQ-ITE -003	NEB-68-23	PANX
1-TE -068-0025A	-E	RCS LOOP 2 HOT LEG RTD MAIN TEMP	WBNEQ-ITE -002	NEB-68-24	
1-TE -068-0025B	-E	RCS LOOP 2 HOT LEG RTD MAIN TEMP	WBNEQ-ITE -002	NEB-68-24	
1-TE -068-0037A	-E	RCS LOOP 2 COLD LEG RTD MAIN TEMP	WBNEQ-ITE -002	NEB-68-24	
1-TE -068-0037B	-E	RCS LOOP 2 COLD LEG RTD MAIN TEMP	WBNEQ-ITE -002	NEB-68-24	
1-TE -068-0041	CS-D	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-TE -068-0041	-D	RCS LOOP 2 COLD LEG TEMP	WBNEQ-ITE -003	NEB-68-23	PANX
1-TE -068-0043	CS-E	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-TE -068-0043	-E	RCS LOOP 3 HOT LEG TEMP	WBNEQ-ITE -003	NEB-68-23	PIT

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-TE -068-0044A	-F	RCS LOOP 3 HOT LEG RTD MAIN TEMP	WBNEQ-ITE -002	NEB-68-24	
1-TE -068-0044B	-F	RCS LOOP 3 HOT LEG RTD MAIN TEMP	WBNEQ-ITE -002	NEB-68-24	
1-TE -068-0056A	-F	RCS LOOP 3 COLD LEG RTD MAIN TEMP	WBNEQ-ITE -002	NEB-68-24	
1-TE -068-0056B	-F	RCS LOOP 3 COLD LEG RTD MAIN TEMP	WBNEQ-ITE -002	NEB-68-24	
1-TE -068-0060	CS-E	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-TE -068-0060	-E	RCS LOOP 3 COLD LEG TEMP	WBNEQ-ITE -003	NEB-68-23	PAH1
1-PT -068-0063	-D	LOOP 1 HOT LEG PRESS	WBNEQ-XMTR-004		PAHX
1-PT -068-0064	-E	REAC COOL LOOP 3 HOT LEG PRESSURE XMTR	WBNEQ-IPT -001		PAHX
1-TE -068-0065	CS-E	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-TE -068-0065	-E	RCS LOOP 4 HOT LEG TEMP	WBNEQ-ITE -003	NEB-68-23	PIT
1-TE -068-0067A	-G	RCS LOOP 4 HOT LEG RTD MAIN TEMP	WBNEQ-ITE -002	NEB-68-43	
1-TE -068-0067B	-G	RCS LOOP 4 HOT LEG RTD MAIN TEMP	WBNEQ-ITE -002	NEB-68-24	
1-TE -068-0079A	-G	RCS LOOP 4 COLD LEG RTD MAIN TEMP	WBNEQ-ITE -002	NEB-68-24	
1-TE -068-0079B	-G	RCS LOOP 4 COLD LEG RTD MAIN TEMP	WBNEQ-ITE -002	NEB-68-24	
1-TE -068-0083	CS-E	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-TE -068-0083	-E	RCS LOOP 4 COLD LEG TEMP	WBNEQ-ITE -003	NEB-68-23	PAHX

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAK/ THI
1-FSV -068-0305	-A	RCS FLOW CNTL VLV NDS N2 MAN TO PRT	NBNEQ-SOL -006	NEB-XX-6	
1-FCV -068-0305/ZS1	-A	RCS FCV NDS N2 MAN TO PRT POS SWITCH	NBNEQ-IZS -001	NEB-XX-11	PAKX
1-FCV -068-0305/ZS2	-A	RCS FCV NDS N2 MAN TO PRT POS SWITCH	NBNEQ-IZS -001	NEB-XX-11	PAKX
1-FSV -068-0307	-A	RCS FLOW CNTL VALVE NDS 6A TO PRT	NBNEQ-SOL -003	NEB-68-3	
1-FSV -068-0308	-B	RCS FLOW CNTL VLV NDS 6A TO PRT	NBNEQ-SOL -006	EEB0020	
1-FCV -068-0308/ZS1CS-B		ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-FCV -068-0308/ZS1	-B	RCS FLOW CNTL VALVE NDS 6A TO PRT POS SM	NBNEQ-IZS -002	EEB0051	PAKX
1-FCV -068-0308/ZS2CS-B		ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-FCV -068-0308/ZS2	-B	RCS FLOW CNTL VALVE NDS 6A TO PRT POS SM	NBNEQ-IZS -002	EEB0051	PAKX
1-TE -068-0319	CS-F	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-TE -068-0319	-F	RCS PRZR LIQUID TEMP	NBNEQ-ITE -004	NEB-68-44	
1-LT -068-0320	-F	RCS PRZR LEVEL	NBNEQ-XNTR-001	NEB-XX-47	PAKX
1-PT -068-0322	-G	RCS PRZR PRESS	NBNEQ-XNTR-004	NEB-XX-49	THI
1-PT -068-0323	-F	RCS PRZR PRESS	NBNEQ-XNTR-004	NEB-XX-49	
1-TE -068-0324	CS-G	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-TE -068-0324	-G	RCS PRZR VAPOR TEMP	NBNEQ-ITE -004	NEB-68-44	
1-FCV -068-0332	-B	RCS PRZR REL FLOW CONT	NBNEQ-NOV -001	NEB-XX-36	
1-FCV -068-0333	-A	RCS PRZR REL FLOW CONT	NBNEQ-NOV -001	NEB-XX-36	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1-PCV -068-0334	CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-PCV -068-0334	-B	RCS PRZR PWR RELIEF VALVE	WBNEQ-SOL -002	EEB0086	
1-PT -068-0334	-E	RCS PRZR PRESS	WBNEQ-XMTR-004	NEB-XX-49	
1-XE -068-0334		ACOUSTIC VALVE POS ACCELEROMETER	WBNEQ-IXT -001	EEB0074	THI
1-XT -068-0334		ACOUSTIC VALVE POS CHARGE CONVERTER	WBNEQ-IXT -001	EEB0074	THI
1-LT -068-0335	-E	RCS PRZR LEVEL	WBNEQ-XMTR-001	NEB-XX-47	PANX
1-LT -068-0339	-D	RCS PRZR LEVEL	WBNEQ-XMTR-001	NEB-XX-47	PANX
1-PCV -068-0340	CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-PT -068-0340	-D	RCS PRZR PRESS	WBNEQ-XMTR-004	NEB-XX-49	PAN
1-PCV -068-0340A	-A	RCS PRZR PWR RELIEF VALVE	WBNEQ-SOL -002	EEB0086	
1-XE -068-0340A		ACOUSTIC VALVE POS ACCELEROMETER	WBNEQ-IXT -001	EEB0074	THI
1-XT -068-0340A		ACOUSTIC VALVE POS CHARGE CONVERTER	WBNEQ-IXT -001	EEB0074	THI
1-XE -068-0363		ACOUSTIC VALVE POS ACCELEROMETER	WBNEQ-IXT -001	EEB0074	THI
1-XT -068-0363		ACOUSTIC VALVE POS CHARGE CONVERTER	WBNEQ-IXT -001	EEB0074	THI
1-XE -068-0364		ACOUSTIC VALVE POS ACCELEROMETER	WBNEQ-IXT -001	EEB0074	THI
1-XT -068-0364		ACOUSTIC VALVE POS CHARGE CONVERTER	WBNEQ-IXT -001	EEB0074	THI
1-XE -068-0365		ACOUSTIC VALVE POS ACCELEROMETER	WBNEQ-IXT -001	EEB0074	THI

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
IE ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-YT -068-0365	ACOUSTIC VALVE POS CHARGE CONVERTER	NBNEQ-IXT -001	EEB0074	THI
1-TE -068-0373 CS-D	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-TE -068-0373 -D	REAC LEVEL CAP TUBE TEMP COMP	NBNEQ-ITE -001	NEB-68-33	THI
1-TE -068-0376 CS-D	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-TE -068-0376 -D	REAC LEVEL TEMP COMP	NBNEQ-ITE -001	NEB-68-33	THI
1-TE -068-0377 CS-D	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-TE -068-0377 -D	REAC LEVEL CAP TUBE TEMP COMP	NBNEQ-ITE -001	NEB-68-33	THI
1-TE -068-0378 CS-D	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-TE -068-0378 -D	REAC LEVEL CAP TUBE TEMP COMP	NBNEQ-ITE -001	NEB-68-33	THI
1-TE -068-0379 CS-D	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-TE -068-0379 -D	REAC LEVEL CAP TUBE TEMP COMP	NBNEQ-ITE -001	NEB-68-33	THI
1-TE -068-0380 CS-E	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-TE -068-0380 -E	REAC LEVEL CAP TUBE TEMP COMP	NBNEQ-ITE -001	NEB-68-33	THI
1-TE -068-0383 CS-E	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-TE -068-0383 -E	REAC LEVEL TEMP COMP	NBNEQ-ITE -001	NEB-68-33	THI
1-TE -068-0384 CS-E	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-TE -068-0384 -E	REAC LEVEL CAP TUBE TEMP COMP	NBNEQ-ITE -001	NEB-68-33	THI



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
IE ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-TE -068-0385 CS-E	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-TE -068-0385 -E	REAC LEVEL CAP TUBE TEMP COMP	NBNEQ-ITE -001	NEB-68-33	THI
1-TE -068-0386 CS-E	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-TE -068-0386 -E	REAC LEVEL CAP TUBE TEMP COMP	NBNEQ-ITE -001	NEB-68-33	THI
1-TE -068-0393 CS-E	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-TE -068-0393 -E	REAC LEVEL CAP TUBE TEMP COMP	NBNEQ-ITE -001	NEB-68-33	THI
1-FSV -068-0394 CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-FSV -068-0394 -A	REACTOR VESSEL HEAD VENT ISLN VALVE	NBNEQ-SOL -001	NEB-68-43	THI
1-FSV -068-0395 CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-FSV -068-0395 -B	REACTOR VESSEL HEAD VENT ISLN VALVE	NBNEQ-SOL -001	NEB-68-43	THI
1-FSV -068-0396 CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-FSV -068-0396 -B	REACTOR VESSEL HEAD VENT THROTTLE VALVE	NBNEQ-SOL -001	NEB-68-43	THI
1-FSV -068-0397 CS-A	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-FSV -068-0397 -A	REACTOR VESSEL HEAD VENT THROTTLE VALVE	NBNEQ-SOL -001	NEB-68-43	THI
1-HS -070-00388 -B	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
1-HS -070-00468 -A	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	
1-HS -070-00518 -S	HANDSWITCH	NBNEQ-HS -001	EEB-HS-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAR/ THI
2-HS -070-0051B	-S	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FSV -070-0085	-B	EXCESS LETDN HTX OUTLET VALVE	WBNEQ-SOL -003		
1-FCV -070-0085/2S1	-B	EXCESS LTDN HTX OUTLET VALVE POS SW	WBNEQ-1ZS -001	EEB0060	PANX
1-FCV -070-0085/2S2	-B	EXCESS LTDN HTX OUTLET VALVE POS SW	WBNEQ-1ZS -001	EEB0060	PANX
1-FCV -070-0087	-B	RC PHP THERM BAR RET CNTHT ISLN VALVE	WBNEQ-NOV -001	NEB-70-0142	PANX
1-FCV -070-0089	-B	RC PHP OIL CLR RET CNTHT ISLN VALVE	WBNEQ-NOV -001	NEB-70-0142	PANX
1-FCV -070-0090	-A	RCP THERM BAR RET CNTHT ISLN VALVE	WBNEQ-NOV -003	NEB-70-0161	
1-HS -070-0090B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -070-0092	-A	RCP OIL CLR RET CNTHT ISLN VALVE	WBNEQ-NOV -003	NEB-70-0161	PANX
1-HS -070-0092B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -070-0134	-B	RCP THERM BAR CNTHT ISLN VALVE	WBNEQ-NOV -003	NEB-70-0147	PANX
1-HS -070-0134B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -070-0140	-B	RCP OIL CLR HDR CNTHT ISLN VALVE	WBNEQ-NOV -003	NEB-70-0161	PANX
1-HS -070-0140B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -070-0143	-A	EXCESS LET DOWNS HTXCNTHT INLET ISLN VLV	WBNEQ-NOV -003	NEB-70-0161	PANX
1-HS -070-0143B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-HS -070-0153B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-HS -070-0156B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
IE ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1-FCV -070-0183	-A	SAMPLE HTX HDR OUTLET VALVE	WBNEQ-NOV -003		
1-HS -070-0183B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
0-HS -070-0194B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
0-HS -070-0197B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
0-FCV -070-0206	-B	COND BLDG RETURN	WBNEQ-NOV -003	NEB-70-0148	
0-HS -070-0206B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -070-0207	-B	COND DENIN WASTE EVAP BLDG SUPPLY	WBNEQ-NOV -003	NEB-70-0144	
2-FCV -070-0207	-B	COND DENIN WASTE EVAP BLDG SUPPLY	WBNEQ-NOV -003	NO EQS NUMBER	
1-HS -070-0207B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
2-HS -070-0207B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
0-FCV -070-0208	-A	COND DENIN WASTE EVAP BLDG SUPPLY	WBNEQ-NOV -003	NEB-70-0144	
0-HS -070-0208B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-HS -070-0215	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -070-0215	-A	SAMPLE HX INLET ISLN VALVE	WBNEQ-NOV -003		
1-FT -070-0215A	-A	SAMPLE HTX HDR INLET FLOW	WBNEQ-XNTR-003		
1-FT -070-0215B	-A	SAMPLE HTX HDR OUTLET FLOW	WBNEQ-XNTR-003		
1-FCV -072-0002	-B	CNTMT SPRAY HDR B ISLN VALVE	WBNEQ-NOV -003	NEB-XX-37	
1-HS -072-0002B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-NTR -072-0010	-B	CS PUMP MOTOR	WBNEQ-HOT -001	NEB-XX-31	
1-HS -072-0010B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
1-FCV -072-0013	-B	CNTNT SPRAY PHP B	WBNEQ-NOV -003	NEB-72-0151	
1-HS -072-0013B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -072-0021	-B	RNST TO SPRAY HDR B FLOW CONTROL VALVE	WBNEQ-NOV -003		
1-HS -072-0021B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -072-0022	-A	RNST TO SPRAY HDR A FLOW CONTROL VALVE	WBNEQ-NOV -003		
1-HS -072-0022B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-NTR -072-0027	-A	CS PUMP MOTOR	WBNEQ-NOT -001	NEB-XX-31	
1-HS -072-0027B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -072-0034	-A	CNTNT SPRAY PHP A RECIRC FLOW CONT VLV	WBNEQ-NOV -003	NEB-72-0151	
1-HS -072-0034B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -072-0039	-A	CNTNT SPRAY HDR A ISLN VALVE	WBNEQ-NOV -003	NEB-XX-37	
1-HS -072-0039B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -072-0040	-A	RHR SPRAY HDR A ISLNVALVE	WBNEQ-NOV -003	NEB-XX-37	
1-ZS -072-0040	-A	RHR SPRAY HDR A ISOLVLV STEN POS SWITCH	WBNEQ-IZS -001		
1-FCV -072-0041	-B	RHR SPRAY HDR B ISLNVALVE	WBNEQ-NOV -003	NEB-XX-37	
1-ZS -072-0041	-B	RHR SPRAY HDR B ISOLVLV STEN POS SWITCH	WBNEQ-IZS -001		
1-FCV -072-0044	-A	CNTNT SUMP TO HDR A FLOW CONTROL VALVE	WBNEQ-NOV -003	NEB-XX-38	
1-HS -072-0044B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-ZS -072-0044	-A	CNTNT SNP TO HDR A FCV POS SW	WBNEQ-IZS -002		
1-FCV -072-0045	-B	CNTNT SUMP TO HDR B FLOW CONTROL VALVE	WBNEQ-NOV -003	NEB-XX-38	
1-HS -072-0045B	-B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-ZS -072-0045	-B	CNTNT SNP TO HDR B FCV POS SW	WBNEQ-IZS -002		
1-FCV -074-0001	-A	RHR SYSTEM ISOLATIONVALVE	WBNEQ-NOV -001	NEB-XX-36	
1-FCV -074-0002	-B	RHR SYSTEM ISOLATIONVALVE	WBNEQ-NOV -001	NEB-XX-36	PAH
1-FCV -074-0003	-A	RHR PUMP A-A INLET FLOW CNTRL VLV	WBNEQ-NOV -001	NEB-XX-37	
1-HS -074-0003B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -074-0008	-A	RHR SYSTEM ISOLATIONBYPASS VALVE	WBNEQ-NOV -001	NEB-XX-36	
1-FCV -074-0009	-B	RHR SYSTEM ISOLATIONBYPASS VALVE	WBNEQ-NOV -001	NEB-XX-36	
1-NTR -074-0010	-A	RHR PUMP MOTOR	WBNEQ-MOT -001	NEB-XX-31	
1-FCV -074-0012	-A	RHR PHP A-A MINI FLOW VALVE	WBNEQ-NOV -003	NEB-XX-37	
1-HS -074-0012B	-A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-TE -074-0014	CS-6	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-TE -074-0014	-G	RHR PUMP A-A DISCH PUMP	WBNEQ-ITE -004	NEB-74-45	
1-NTR -074-0020	-B	RHR PUMP MOTOR	WBNEQ-MOT -001	NEB-74-31	
1-FCV -074-0021	-B	RHR PUMP B-B INLET FLOW CONTROL VALVE	WBNEQ-NOV -001	NEB-XX-37	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1-HS -074-0021B -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -074-0024 -B	RHR PHP B-B NINI FLOW VALVE	WBNEQ-MOV -003	NEB-XX-37	
1-HS -074-0024B -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-TE -074-0025 CS-F	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-TE -074-0025 -F	RHR PUMP B-B OUTLET TEMP	WBNEQ-ITE -004	NEB-74-45	
1-FCV -074-0033 -A	RHR HT EXH A BYPASS	WBNEQ-MOV -003	NEB-XX-37	
1-HS -074-0033B -A	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-FCV -074-0035 -B	RHR HT EXH B BYPASS CROSS TIE VALVE	WBNEQ-MOV -003	NEB-XX-37	
1-HS -074-0035B -B	HANDSWITCH	WBNEQ-HS -001	EEB-HS-1	
1-TS -074-0043 -A	RHR RETURN LINE BREAK DETECTION	WBNEQ-ITS -002		
1-TS -074-0044 -A	RHR RETURN LINE BREAK DETECTION	WBNEQ-ITS -002		
1-TS -074-0045 -B	RHR RETURN LINE BREAK DETECTION	WBNEQ-ITS -002		
1-TS -074-0046 -B	RHR RETURN LINE BREAK DETECTION	WBNEQ-ITS -002		
1-FSV -077-0009 -B	RCDT PHP DISCH VALVEFLOW CONTROL	WBNEQ-SOL -006	EEB0039	
1-FCV -077-0009/2S1CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -077-0009/2S1 -B	RCDT PUMP DISCH VLV FLOW CNTL POS SW	WBNEQ-IZS -002	EEB0051	PANX
1-FCV -077-0009/2S2CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -077-0009/2S2 -B	RCDT PUMP DISCH VLV FLOW CNTL POS SW	WBNEQ-IZS -002	EEB0051	PANX

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1-FSV -077-0010 -A	RCDT PMP DISCH VALVEFLOW CONTROL	WBNEQ-SOL -006	NEB-XX-6	
1-FSV -077-0016 -B	RCDT TO GAS ANALYZERFLOW SOL VALVE	WBNEQ-SOL -006	EEB0020	
1-FCV -077-0016/2S1CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -077-0016/2S1 -B	RCDT TO GAS ANALYZERFLOW CNTL POS SW	WBNEQ-IZS -002	EEB0051	PANX
1-FCV -077-0016/2S2CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -077-0016/2S2 -B	RCDT TO GAS ANALYZERFLOW CNTL POS SW	WBNEQ-IZS -002	EEB0051	PANX
1-FSV -077-0017 -A	RCDT TO GA FLOW CONTROL	WBNEQ-SOL -006	NEB-XX-6	
1-FSV -077-0018 -B	RCDT TO VENT HDR FLOW CONTROL	WBNEQ-SOL -006	EEB0020	
1-FCV -077-0018/2S1CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -077-0018/2S1 -B	RCDT TO VENT HDR FLOW CNTL POS SW	WBNEQ-IZS -002	EEB0051	PANX
1-FCV -077-0018/2S2CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -077-0018/2S2 -B	RCDT TO VENT HDR FLOW CNTL POS SW	WBNEQ-IZS -002	EEB0051	PANX
1-FSV -077-0019 -A	RCDT TO VENT HDR FLOW CONTROL	WBNEQ-SOL -006	NEB-XX-6	
1-FCV -077-0019/2S1 -A	RCDT TO VENT HDR FCV POS SWITCH	WBNEQ-IZS -001	NEB-XX-11	PANX
1-FCV -077-0019/2S2 -A	RCDT TO VENT HDR FCV POS SWITCH	WBNEQ-IZS -001	NEB-XX-11	PANX

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1-FSV -077-0020	-A	RCDT H2 SUPPLY FLOW CONTROL	WBNEQ-SOL -006	NEB-XX-6	
1-FCV -077-0020/ZS1	-A	RCDT H2 SUP FCV POS SWITCH	WBNEQ-IZS -001		PANX
1-FCV -077-0020/ZS2	-A	RCDT H2 SUP FCV POS SWITCH	WBNEQ-IZS -001		PANX
1-FSV -077-0127	-B	REAC BLDG SUMP DISCHFLOW SOL VALVE	WBNEQ-SOL -003	EEB0019	
1-FCV -077-0127/ZS1CS-B		ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -077-0127/ZS1	-B	REACTOR BLDG SUMP DISCH FLOW CNTL VLV LS	WBNEQ-IZS -003	EEB0018	PANX
1-FCV -077-0127/ZS2CS-B		ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FCV -077-0127/ZS2	-B	REACTOR BLDG SUMP DISCH FLOW CNTL VLV LS	WBNEQ-IZS -003	EEB0018	PANX
1-FSV -077-0128	-A	REAC BLDG SUMP DISCHFLOW SOL VALVE	WBNEQ-SOL -003		
1-FCV -077-0128/ZS1	-A	REACTOR BLDG SUMP DISCH FCV LIMIT SW	WBNEQ-IZS -003		PANX
1-FCV -077-0128/ZS2	-A	REACTOR BLDG SUMP DISCH FCV LIMIT SW	WBNEQ-IZS -003		PANX
0-LT -077-0134	-A	PASSIVE SUMP AUX BLDG LVL TRANSMITTER	WBNEQ-XNTR-003	EEB0027	PAN
0-LT -077-0135	-B	PASSIVE SUMP AUX BLDG LVL TRANSMITTER	WBNEQ-XNTR-003	EEB0027	PAN
1-FSV -001-0012	-A	PW RCS PRESS RELIEF TK & RCP STAND PIPES	WBNEQ-SOL -006	NEB-XX-6	
1-FCV -001-0012/ZS1	-A	PW-RCS PRESS RELF TKRCP STANPIPES POS SW	WBNEQ-IZS -001	NEB-XX-11	PANX



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1-FCV -081-0012/2S2 -A	PH-RCS PRESS RELF TKRCP STAMPINES POS SW	WBNEQ-1ZS -001	NEB-XX-11	PAN1
1-HTR -083-0001 -A	HYDROGEN RECOMBINER	WBNEQ-HTR -001	NEB-83-1	
1-HTR -083-0002 -B	HYDROGEN RECOMBINER	WBNEQ-HTR -001	NEB-83-1	
1-FSV -087-0007 -A	TEST LINE ISOLATION VALVE FLOW CONTROL	WBNEQ-SOL -006	EED0028	
1-FSV -087-0008 -A	TEST LINE ISOLATION VALVE FLOW CONTROL	WBNEQ-SOL -006	EED0028	
1-FSV -090-0107 -A	CNTNT BLDG LMR COMPTNOM ISLN VALVE	WBNEQ-SOL -003	EED0037	
1-FCV -090-0107/2S -A	CNTNT BLDG LMR COMPTNOM ISLN VLV POS SW	WBNEQ-1ZS -001	EED0058	PAN1
1-FCV -090-0108/2S2CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FSV -090-0108 -B	CNTNT BLDG LMR COMPTNOM ISLN VALVE	WBNEQ-SOL -003	EED0019	
1-FCV -090-0108/2S -B	CNTNT BLDG LMR COMPTNOM ISLN VLV POS SW	WBNEQ-1ZS -002	EED0051	PAN1
1-FCV -090-0109/2S2CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FSV -090-0109 -B	CNTNT BLDG LMR COMPTNOM ISLN VALVE	WBNEQ-SOL -003	EED0019	
1-FCV -090-0109/2S -B	CNTNT BLDG LMR COMPTNOM ISLN VLV POS SW	WBNEQ-1ZS -002	EED0051	PAN1
1-FCV -090-0110/2S2CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	WBNEQ-CSC -001	EEB-CSC-1	
1-FSV -090-0110 -B	CNTNT BLDG LMR COMPTNOM ISLN VALVE	WBNEQ-SOL -003	EED0019	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ TMI
1-FCV -090-0110/ZS -B	CNTHT BLDG LWR COMPTNHN ISLN VLV POS SW	NBNEQ-1ZS -002	EEB0051	PANX
1-FSV -090-0111 -A	CNTHT BLDG LWR COMPTNHN ISLN VALVE	NBNEQ-SOL -003	EEB0037	
1-FCV -090-0111/ZS -A	CNTHT BLDG LWR COMPTNHN ISLN VLV POS SW	NBNEQ-1ZS -001	EEB0058	PANX
1-FSV -090-0113 -A	CNTHT BLDG UPR COMPTNHN ISLN VALVE	NBNEQ-SOL -003	EEB0037	
1-FCV -090-0113/ZS -A	CNTHT BLDG UP COMPT NON ISLN VLV POS SW	NBNEQ-1ZS -001	EEB0058	PANX
1-FCV -090-0114/ZS2CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-FSV -090-0114 -B	CNTHT BLDG UPR COMPTNHN ISLN VALVE	NBNEQ-SOL -003	EEB0019	
1-FCV -090-0114/ZS -B	CNTHT BLDG UP COMPT NON ISLN VLV POS SW	NBNEQ-1ZS -002	EEB0051	PANX
1-FCV -090-0115/ZS2CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-FSV -090-0115 -B	CNTHT BLDG UPR COMPTNHN ISLN VALVE	NBNEQ-SOL -003	EEB0019	
1-FCV -090-0115/ZS -B	CNTHT BLDG UP COMPT NON ISLN VLV POS SW	NBNEQ-1ZS -002	EEB0051	PANX
1-FCV -090-0116/ZS2CS-B	ELECTRICAL CONDUIT SEAL ASSEMBLY	NBNEQ-CSC -001	EEB-CSC-1	
1-FSV -090-0116 -B	CNTHT BLDG UPR COMPTNHN ISLN VALVE	NBNEQ-SOL -003	EEB0019	
1-FCV -090-0116/ZS -B	CNTHT BLDG UP COMPT NON ISLN VLV POS SW	NBNEQ-1ZS -002	EEB0051	PANX
1-FSV -090-0117 -A	CNTHT BLDG UPR COMPTNHN ISLN VALVE	NBNEQ-SOL -003	EEB0037	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1-FCV -090-01177S	-A	CNTMT BLDG UP COMPT NON ISLN VLV POS SW	WBNEQ-17S -001	EEB0058	PANX
1-RE -090-0271	-A	POST ACCIDENT AREA MONITOR	WBNEQ-IRE -001	EEB-RM-2	PANX
1-RE -090-0272	-B	POST ACCIDENT AREA MONITOR	WBNEQ-IRE -001	EEB-RM-2	PANX
1-RE -090-0273	-A	POST ACCIDENT AREA MONITOR	WBNEQ-IRE -001	EEB-RM-2	PANX
1-RE -090-0274	-B	POST ACCIDENT AREA MONITOR	WBNEQ-IRE -001	EEB-RM-2	PANX
1-WTE -094-0001	-D	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	PIT
1-WTE -094-0002	-D	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	PIT
1-WTE -094-0003	-D	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	PIT
1-WTE -094-0004	-D	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	PIT
1-WTE -094-0005	-D	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	PIT
1-WTE -094-0006	-D	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	PIT
1-WTE -094-0007	-D	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	PIT
1-WTE -094-0008	-D	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	PIT
1-PWL -094-0008/A	-D	INCORE THERMOCOUPLE REFERENCE JCT BOX	WBNEQ-ITE -005		
1-PWL -094-0008/B	-E	INCORE THERMOCOUPLE REFERENCE JCT BOX	WBNEQ-ITE -005		
1-WTE -094-0009	-D	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	PANX
1-WTE -094-0010	-D	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	PANX
1-WTE -094-0011	-D	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0012	-D	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0013	-D	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ TWI
1-WTE -094-0014	-D	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0015	-D	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0016	-D	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0017	-D	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0018	-D	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0019	-D	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0020	-D	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0021	-D	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0022	-D	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0023	-D	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0024	-D	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0025	-D	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0026	-D	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0027	-D	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0028	-D	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0029	-D	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0030	-D	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0031	-D	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0032	-D	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0033	-D	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0034	-E	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0035	-E	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0036	-E	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	
1-WTE -094-0037	-E	INCORE THERMOCOUPLE	NBNEQ-ITE -005	NEB-94-48	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-NTE -094-0038	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-NTE -094-0039	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-NTE -094-0040	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-NTE -094-0041	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-NTE -094-0042	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-NTE -094-0043	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-NTE -094-0044	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-NTE -094-0045	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-NTE -094-0046	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-NTE -094-0047	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-NTE -094-0048	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-NTE -094-0049	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-NTE -094-0050	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-NTE -094-0051	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-NTE -094-0052	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-NTE -094-0053	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-NTE -094-0054	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-NTE -094-0055	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-NTE -094-0056	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-NTE -094-0057	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-NTE -094-0058	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-NTE -094-0059	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-NTE -094-0060	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	
1-NTE -094-0061	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	PIT

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAW/ THI
1-WTE -094-0062	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	PIT
1-WTE -094-0063	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	PIT
1-WTE -094-0064	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	PIT
1-WTE -094-0065	-E	INCORE THERMOCOUPLE	WBNEQ-ITE -005	NEB-94-48	PIT
0-NCC -217-000A		CIRCUIT BREAKER	WBNEQ-BKRA-002	EEB-NC-1	
0-NCC -217-000B		CIRCUIT BREAKER	WBNEQ-BKRA-002	EEB-NC-2	
0-BD -220-0003		CIRCUIT BREAKER	WBNEQ-BKRA-002	EEB-BD-3	
0-BD -220-0004		CIRCUIT BREAKER	WBNEQ-BKRA-002	EEB-BD-4	
0-DPL -234-0001/WDS		CIRCUIT BREAKER	WBNEQ-BKRA-002		
0-DPL -234-0002/WDS		CIRCUIT BREAKER	WBNEQ-BKRA-002		
0-DPL -234-00A1/SIS		CIRCUIT BREAKER	WBNEQ-BKRA-002	EEB-PNL-1	
0-DPL -234-00A2/SIS		CIRCUIT BREAKER	WBNEQ-BKRA-002	EEB-PNL-1	
0-DPL -234-00A3/CVC		CIRCUIT BREAKER	WBNEQ-BKRA-002	EEB-PNL-1	
0-DPL -234-00A4/CVC		CIRCUIT BREAKER	WBNEQ-BKRA-002	EEB-PNL-1	
0-DPL -234-00B1/SIS		CIRCUIT BREAKER	WBNEQ-BKRA-002	EEB-PNL-1	
0-DPL -234-00B2/SIS		CIRCUIT BREAKER	WBNEQ-BKRA-002	EEB-PNL-1	
0-DPL -234-00B3/CVC		CIRCUIT BREAKER	WBNEQ-BKRA-002	EEB-PNL-1	
0-DPL -234-00B4/CVC		CIRCUIT BREAKER	WBNEQ-BKRA-002	EEB-PNL-1	
1-JB -276-L177	-F	LOC PNL JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -276-L177	-F	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -276-L182A	-D	LOC PNL JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -276-L182A	-D	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -276-L182B	-D	LOC PNL JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -276-L182B	-D	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
1-JB -276-L183A	-E LOC PNL JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -276-L183A	-E TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -276-L183B	-E LOC PNL JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -276-L183B	-E TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -276-L183C	-B LOC PNL JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -276-L183C	-B TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -276-L184A	-F LOC PNL JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -276-L184A	-F TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -276-L184B	-A LOC PNL JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -276-L184B	-A TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -276-L185A	-G LOC PNL JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -276-L185A	-G TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -276-L185B	-G LOC PNL JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -276-L185B	-G TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -276-L196	-D LOC PNL JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -276-L196	-D TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -276-L197	-E LOC PNL JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -276-L197	-E TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -276-L216	-A LOC PNL JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -276-L216	-A TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -276-L217	-A LOC PNL JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -276-L217	-A TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-0004	-A JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-0004	-A TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
2-JB -292-0006	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
2-TB -292-0006	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
0-JB -292-0228	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
0-TB -292-0228	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
0-JB -292-0229	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
0-TB -292-0229	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-0358	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-0358	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-0359	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-0359	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-0530	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-0530	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-0540	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-0540	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-0567	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-0567	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-0569	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-0569	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-0593	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-0593	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-0748	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-0748	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-0772	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-0772	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-JB -292-0773 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-0773 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-0846 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-0846 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-0847 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-0847 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1005 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1005 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1006 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1006 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
2-JB -292-1008 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
2-TB -292-1008 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
0-JB -292-1163 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
0-TB -292-1163 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
0-JB -292-1164 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
0-TB -292-1164 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1182 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1182 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
2-JB -292-1183 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
2-TB -292-1183 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1189 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1189 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1190 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1190 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
1-JB -292-1195 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1195 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1196 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1196 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1231 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1231 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1232 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1232 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1235 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1235 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1246 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1246 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1352 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1352 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1353 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1353 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1354 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1354 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1355 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1355 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1356 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1356 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1357 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1357 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-JB -292-1350 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1350 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1367 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1367 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1368 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1368 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1369 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1369 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1370 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1370 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1371 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1371 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1391 -S	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1391 -S	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1407 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1407 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1408 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1408 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1421 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1421 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1422 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1422 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1425 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1425 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAW/ TNI
1-JB -292-1426	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1426	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1446	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1446	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1447	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1447	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
2-JB -292-1448	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
2-TB -292-1448	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
2-JB -292-1449	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
2-TB -292-1449	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1502	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1502	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
2-JB -292-1503	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
2-TB -292-1503	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1504	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1504	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
2-JB -292-1505	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
2-TB -292-1505	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1506	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1506	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1507	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1507	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
2-JB -292-1508	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
2-TB -292-1508	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TRI
2-JB -292-1509	-B JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
2-TB -292-1509	-B TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	
1-JB -292-1512	-A JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1512	-A TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	
1-JB -292-1514	-A JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1514	-A TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	
1-JB -292-1516	-B JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1516	-B TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	
1-JB -292-1518	-B JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1518	-B TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	
1-JB -292-1543	-A JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1543	-A TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	
1-JB -292-1544	-B JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1544	-B TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	
0-JB -292-1547	-A JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
0-TB -292-1547	-A TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	
0-JB -292-1548	-B JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
0-TB -292-1548	-B TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	
1-JB -292-1549	-A JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1549	-A TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	
2-JB -292-1550	-A JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
2-TB -292-1550	-A TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	
1-JB -292-1551	-B JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1551	-B TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
2-JB -292-1552	-B JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
2-TB -292-1552	-B TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
2-JB -292-1553	-A JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
2-TB -292-1553	-A TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
2-JB -292-1554	-B JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
2-TB -292-1554	-B TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
2-JB -292-1555	-A JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
2-TB -292-1555	-A TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
2-JB -292-1556	-B JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
2-TB -292-1556	-B TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1564	-A JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1564	-A TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1565	-B JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1565	-B TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1566	-B JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1566	-B TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1567	-A JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1567	-A TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1598	-A JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1598	-A TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1599	-B JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1599	-B TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
0-JB -292-1706	-A JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
0-TB -292-1706	-A TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
0-JB -292-1708	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
0-TB -292-1708	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1933	-S	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1933	-S	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
0-JB -292-1942	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
0-TB -292-1942	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
0-JB -292-1943	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
0-TB -292-1943	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1964	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1964	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1966	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1966	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1968	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1968	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1970	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1970	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1972	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1972	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1974	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1974	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1985	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1985	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-1986	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1986	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-JB -292-1987	-B	JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1987	-B	TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	
1-JB -292-1988	-A	JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-1988	-A	TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	
1-JB -292-2007	-B	JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2007	-B	TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	
1-JB -292-2008	-A	JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2008	-A	TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	
1-JB -292-2012	-B	JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2012	-B	TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	
1-JB -292-2013	-A	JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2013	-A	TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	
0-JB -292-2034	-A	JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
0-TB -292-2034	-A	TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	
0-JB -292-2035	-B	JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
0-TB -292-2035	-B	TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	
1-JB -292-2049	-B	JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2049	-B	TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	
2-JB -292-2050	-B	JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
2-TB -292-2050	-B	TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	
1-JB -292-2063	-A	JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2063	-A	TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	
1-JB -292-2064	-B	JUNCTION BOX	NBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2064	-B	TERMINAL BLOCK	NBNEQ-TB -001	EEB-TB-1	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-JB -292-2065 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2065 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2066 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2066 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2071 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2071 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2122 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2122 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2140 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2140 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2141 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2141 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2202 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2202 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2203 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2203 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2204 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2204 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2205 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2205 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2206 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2206 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2207 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2207 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-JB -292-2208	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2208	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2209	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2209	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2210	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2210	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2211	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2211	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2212	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2212	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2234	-S	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2234	-S	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2236	-S	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2236	-S	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2238	-S	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2238	-S	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2240	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -292-2242	-S	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2242	-S	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2244	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -292-2248	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -292-2249	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -292-2252	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2252	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAK/ THI
1-JB -292-2257 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2257 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2260 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2260 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2262 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2262 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2265 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2265 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2386 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2386 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2387 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2387 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2388 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2388 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
2-JB -292-2389 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
2-TB -292-2389 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
2-JB -292-2390 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
2-TB -292-2390 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
2-JB -292-2391 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
2-TB -292-2391 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2503 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2503 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2504 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2504 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EOS NUMBER	PAN/ THI
1-JB -292-2507	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2507	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-2508	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-2508	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
2-JB -292-2761	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
2-TB -292-2761	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
2-JB -292-2762	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
2-TB -292-2762	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
0-JB -292-2765	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
0-TB -292-2765	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
0-JB -292-2766	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
0-TB -292-2766	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
0-JB -292-2856	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
0-TB -292-2856	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
0-JB -292-2894	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
0-TB -292-2894	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-3032	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-3032	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-3033	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-3033	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-3208	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-3208	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
0-JB -292-3213	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
0-TB -292-3213	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1-JB -292-3214 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-3214 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
0-JB -292-3215 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
0-TB -292-3215 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
0-JB -292-3341 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
0-TB -292-3341 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
0-JB -292-3342 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
0-TB -292-3342 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-3422 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-3422 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-3423 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-3423 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-3424 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -292-3425 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -292-3426 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -292-3427 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
0-JB -292-3788 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -292-3870 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-3870 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
0-JB -292-3993 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -292-4011 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-4011 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-4013 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-4013 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ TRI
1-JB -292-4015	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-4015	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-4026	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-4026	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-4027	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-4027	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-4166	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-4166	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-4167	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-4167	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-4261	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-4261	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-4275	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-4275	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-4455	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -292-4984	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-4984	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-4985	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -292-4985	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -292-5058	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-PENT-293-0001		PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-001	EEB-PEN-1	
1-PENT-293-0002		PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-001	EEB-PEN-1	
1-PENT-293-0003		PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-001	EEB-PEN-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TKI
1-PENT-293-0004	PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-001	EEB-PEN-1	
1-PENT-293-0005	PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0006	-A PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0007	-B PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0008	-A PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0009	-B PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0010	PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0011	PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0012	PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0013	PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0014	-A PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0015	-A PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0016	-B PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0017	-B PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0018	PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-003	EEB-PEN-1	
1-PENT-293-0019	-E PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-003	EEB-PEN-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ TKI
1-PENT-293-0020		PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-003	EEB-PEN-1	
1-PENT-293-0021	-A	PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0022		PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-003	EEB-PEN-1	
1-PENT-293-0023	-F	PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-003	EEB-PEN-1	
1-PENT-293-0024		PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0025		PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-003	EEB-PEN-1	
1-PENT-293-0026		PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0027	-A	PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0028		PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-003	EEB-PEN-1	
1-PENT-293-0029		PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-003	EEB-PEN-1	
1-PENT-293-0030	-B	PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-003	EEB-PEN-1	
1-PENT-293-0031	-G	PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-003	EEB-PEN-1	
1-PENT-293-0032		PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0033		PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-003	EEB-PEN-1	
1-PENT-293-0034		PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-003	EEB-PEN-1	
1-PENT-293-0035		PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
1-PENT-293-0036	-B	PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0037	-A	PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-003	EEB-PEN-1	
1-PENT-293-0038	-D	PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-003	EEB-PEN-1	
1-PENT-293-0039		PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-003	EEB-PEN-1	
1-PENT-293-0040	-A	PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-003	EEB-PEN-1	
1-PENT-293-0041		PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0043	-D	PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-003	EEB-PEN-1	
1-PENT-293-0044	-A	PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0045	-F	PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-003	EEB-PEN-1	
1-PENT-293-0046		PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0047		PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0048		PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0049	-G	PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-003	EEB-PEN-1	
1-PENT-293-0050		PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-003	EEB-PEN-1	
1-PENT-293-0051		PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0052	-B	PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
1-PENT-293-0053		PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-002	EEB-PEN-1	
1-PENT-293-0054	-E	PRIMARY CONTAINMENT ELEC PENETRATION	WBNEQ-PENT-003	EEB-PEN-1	
1-55-1		PERSONNEL AIRLOCK ELEC PENETRATION	WBNEQ-PENT-004	EEB-PEN-1	
1-56-1		PERSONNEL AIRLOCK ELEC PENETRATION	WBNEQ-PENT-004	EEB-PEN-1	
1-JB -293-0159	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-0159	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0368	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-0368	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0369	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -293-0394	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-0394	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0542	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-0542	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0544	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-0544	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0546	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-0546	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0548	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-0548	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0550	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-0550	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0553	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-TB -293-0553 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0574 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-0574 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0578 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-0578 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0596 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-0596 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0656 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-0656 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0691 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-0691 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0724 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-0724 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0745 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-0745 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0760 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-0760 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0762 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-0762 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0764 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-0764 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0766 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-0766 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0768 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ TMI
1-TB -293-0768	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0775	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-0775	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0788	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-0788	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0792	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-0792	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-0795	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-0795	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-1034	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-1034	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-1036	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-1036	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-1255	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-1255	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-1277	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-1277	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-1283	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-1283	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-1285	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-1285	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-1287	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-1287	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-1575	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1-TB -293-1575 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-1576 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-1576 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-1736 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-1736 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-1738 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-1738 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-1750 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-1750 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-1758 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-1758 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-1764 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-1764 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-1883 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-1883 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-1885 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-1885 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-1887 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-1887 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-1889 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-1889 -B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-1921 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-1921 -A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-2649 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID		DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1-TB -293-2649	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-2705	-D	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -293-3193	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-3193	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-3201	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-3201	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-3203	-A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-3203	-A	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-3317	-B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-3317	-B	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-3319	-F	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -293-3321	-G	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -293-4326	-D	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-4326	-D	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-4328	-D	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-4328	-D	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-4330	-E	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-4330	-E	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-4332	-E	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-4332	-E	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-4334	-F	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-4334	-F	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-4336	-F	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-4336	-F	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
1E ELECTRICAL EQUIPMENT REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
1-JB -293-4338 -G	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-4338 -G	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-4340 -G	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-TB -293-4340 -G	TERMINAL BLOCK	WBNEQ-TB -001	EEB-TB-1	
1-JB -293-4342 -D	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -293-4344 -D	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -293-4346 -D	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -293-4348 -D	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -293-4350 -E	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -293-4352 -E	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -293-4354 -E	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -293-4356 -E	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -293-4360 -E	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -293-4555 -A	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	
1-JB -293-4557 -B	JUNCTION BOX	WBNEQ-JBOX-001	EEB-JB-1	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TKI
0L 453-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
0L 455-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
0L 458-B	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
0L 460-B	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
0M 320-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0M 850-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0M 851-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0PL2145-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0PL2145-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
0PL2151-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
0PL2158-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
0PL2165-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0PL2165-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
0PL2172-B	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
0PL2178-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0PL2178-B	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
0PL2185-B	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
0PL2192-B	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
0PL3460-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0PL3461-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0PP 300-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 302-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 306-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 310-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TMI
0PP 312-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 313-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 328-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
0PP 330-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0PP 330-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 336-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
0PP 338-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0PP 338-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 350-A	EPSJ	WBNEQ-CABL-005	EEB-CBL-1.0	
0PP 351-A	EPSJ	WBNEQ-CABL-005	EEB-CBL-1.0	
0PP 375-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 378-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 420-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 422-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 426-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 430-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0PP 432-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 433-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 448-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
0PP 450-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 456-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
0PP 458-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 470-A	EPSJ	WBNEQ-CABL-027	EEB-CBL-1.0	
0PP 470-A	CPSJ	WBNEQ-CABL-033	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
0PP 471-A	EPSJ	WBNEQ-CABL-027	EEB-CBL-1.0	
0PP 471-A	CPSJ	WBNEQ-CABL-033	EEB-CBL-1.0	
0PP 495-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 498-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 540-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 540-B	PXNJ	WBNEQ-CABL-022	EEB-CBL-1.0	
0PP 542-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 546-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 550-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0PP 552-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 553-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 568-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
0PP 570-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0PP 570-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 576-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
0PP 578-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0PP 578-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 590-B	EPSJ	WBNEQ-CABL-027	EEB-CBL-1.0	
0PP 590-B	CPSJ	WBNEQ-CABL-033	EEB-CBL-1.0	
0PP 590-B	EPSJ	WBNEQ-CABL-027	EEB-CBL-1.0	
0PP 591-B	EPSJ	WBNEQ-CABL-027	EEB-CBL-1.0	
0PP 591-B	EPSJ	WBNEQ-CABL-027	EEB-CBL-1.0	
0PP 615-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 618-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EGS NUMBER	PAW/ THI
0PP 660-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 660-B	PXNJ	WBNEQ-CABL-022	EEB-CBL-1.0	
0PP 662-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 666-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 670-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0PP 672-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 673-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 688-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
0PP 690-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0PP 690-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 696-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
0PP 698-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0PP 698-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 710-B	EPSJ	WBNEQ-CABL-005	EEB-CBL-1.0	
0PP 711-B	EPSJ	WBNEQ-CABL-005	EEB-CBL-1.0	
0PP 711-B	EPSJ	WBNEQ-CABL-027	EEB-CBL-1.0	
0PP 711-B	CPSJ	WBNEQ-CABL-033	EEB-CBL-1.0	
0PP 711-B	EPSJ	WBNEQ-CABL-027	EEB-CBL-1.0	
0PP 735-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP 738-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0PP1946-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0PP1948-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0PP1949-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0PP1950-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
0PP1952-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0RN 31-A	SPE516	WBNEQ-CABL-047	EEB-CBL-1.0	
0RN 32-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0RN 32-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0RN 33-A	SPE516	WBNEQ-CABL-047	EEB-CBL-1.0	
0RN 36-B	SPE516	WBNEQ-CABL-047	EEB-CBL-1.0	
0RN 37-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0RN 37-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0RN 38-B	SPE516	WBNEQ-CABL-047	EEB-CBL-1.0	
0RN 57-A	SPE516	WBNEQ-CABL-047	EEB-CBL-1.0	
0RN 58-B	SPE516	WBNEQ-CABL-047	EEB-CBL-1.0	
0RN 117-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
0RN 118-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
0RN 120-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0RN 128-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0SG 120-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0SG 121-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0SG 126-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0SG 127-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0SG 128-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0SG 129-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0SG 130-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0SG 131-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0SG 132-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TRI
0SG 133-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0SG 134-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0SG 135-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0SG 150-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0SG 151-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0SG 156-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0SG 157-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0SG 158-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0SG 159-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0SG 160-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0SG 161-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0SG 162-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0SG 163-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0SG 164-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0SG 165-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0SG 166-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 420-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 422-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 430-B	PXHJ	WBNEQ-CABL-049	EEB-CBL-1.0	
0V 432-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 433-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 434-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 435-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 600-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
0V 601-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 602-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 603-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 604-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 605-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 613-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 614-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 615-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 616-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 618-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 619-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 624-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 625-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 626-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 627-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 629-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 630-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 634-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 635-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 636-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 637-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 638-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 639-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 694-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAW/ THI
0V 696-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 697-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 698-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 699-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 702-B	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
0V 704-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 705-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 706-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 707-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 710-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 712-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 718-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 720-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 726-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 728-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 734-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 736-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 742-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 744-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 745-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 746-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 747-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 750-B	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
0V 752-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
0W 753-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0W 754-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0W 755-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0W 758-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0W 760-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0W 761-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0W 762-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0W 763-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0W 766-B	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
0W 768-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0W 769-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0W 770-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0W 771-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0W 774-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0W 776-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0W 777-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0W 778-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0W 779-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0W 782-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0W 784-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0W 785-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0W 786-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0W 787-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0W 790-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAM/ THI</u>
0V 792-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 793-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 794-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 795-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 798-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 800-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 801-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 802-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 803-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 806-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 808-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 809-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 810-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 811-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 814-B	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
0V 816-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 817-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 818-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 819-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 822-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 824-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 830-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 832-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 838-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
0V 840-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 846-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 848-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 854-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 856-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 860-B	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
0V 862-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 868-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 870-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 876-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 878-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 884-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 885-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 886-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 892-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 894-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 965-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 966-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 975-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 976-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 1180-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 1181-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 1196-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 1200-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAK/ THI
0V 1201-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 1215-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 1216-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 1225-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 1226-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 1239-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 1240-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
0V 1242-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 1250-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
0V 1252-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 1941-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 1942-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 1943-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 1944-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 1945-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 1946-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 1947-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 1948-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 1949-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 1950-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 1951-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 1953-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 1974-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 1976-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
0V 1980-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
0V 1981-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 1987-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
0V 1988-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 1991-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 1995-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
0V 2005-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
0V 2009-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 2020-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 2038-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 2061-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 2062-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 2063-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 2064-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 2065-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 2066-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 2067-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 2068-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 2069-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 2070-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 2071-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 2080-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 2082-B	PXJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 2083-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
0V 2084-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 2085-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
0V 2531-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 2533-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
0V 2535-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
0V 2537-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1B 36-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1B 37-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1B 41-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1CR1701-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1CR1702-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1G 217-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1G 222-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1H 591-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1H 812-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1H 814-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1H 980-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1H 982-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1H 1431-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1H 1433-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1H 1435-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1H 1437-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1H 1438-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1H 1439-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1N 1450-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1N 1451-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1N 1452-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1N 1453-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1N 1454-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1N 2340-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1N 2341-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1N 2346-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1N 2347-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1N 2352-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1N 2353-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1N 2358-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1N 2359-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1N 2400-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1N 2401-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1N 2402-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1N 2403-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1N 2407-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1N 2410-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1N 2411-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1N 2412-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1N 2413-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1N 2417-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1N 2441-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAM/ THI</u>
1M 2442-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1M 2443-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1M 2451-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1M 2452-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1M 2453-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1M 2600-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1M 2601-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1M 2602-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1M 2603-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1M 2604-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1M 2605-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1M 2606-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1M 2607-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1M 2608-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1M 2609-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1M 2610-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1M 2611-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1M 2612-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1M 2613-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1M 2614-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1M 2615-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1M 2616-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1M 2617-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1M 2618-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1H 2619-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1H 2620-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1H 2621-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1H 3005-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1H 3007-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1H 3008-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1H 3009-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1H 3010-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1H 3011-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1H 3012-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1H 3013-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1H 3014-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1H 3025-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1H 3027-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1H 3028-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1H 3030-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1H 3031-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1H 3032-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1H 3033-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1H 3034-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1H 3300-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1H 3381-B	PXNJ	WBNEQ-CABL-022	EEB-CBL-1.0	
1H 3400-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1H 3481-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ TNI
1H 3482-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1H 3483-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1H 3484-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1H 3485-B	PXNJ	WBNEQ-CABL-022	EEB-CBL-1.0	
1H 3486-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1H 3487-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1H 3488-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1H 3489-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1H 3506-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1HN 29-D	NS	WBNEQ-CABL-037	EEB-CBL-1.0	
1HN 30-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1HN 209-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1HN 210-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PL1061-A	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL1062-A	SROAJH	WBNEQ-CABL-036	EEB-CBL-1.0	
1PL1063-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL1064-A	NS	WBNEQ-CABL-037	EEB-CBL-1.0	
1PL1065-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PL1081-B	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL1082-B	SROAJH	WBNEQ-CABL-036	EEB-CBL-1.0	
1PL1083-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL1084-B	NS	WBNEQ-CABL-010	EEB-CBL-1.0	
1PL1085-B	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PL2085-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAR/ TRJ
1PL2886-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL2887-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL2895-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL2896-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL2897-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL2981-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL2983-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL2984-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL2985-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL2991-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL2992-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL2993-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL2994-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL2995-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3001-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3003-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3004-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3006-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3011-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL3012-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL3014-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL3015-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3031-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3033-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TRI
1PL3034-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3036-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3041-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3042-B	PXHJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL3043-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3044-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3046-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3051-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3053-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3054-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3055-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3061-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3062-B	PXHJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL3063-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3064-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3066-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3071-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL3072-A	PXHJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL3073-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3074-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL3077-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL3081-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3082-B	PXHJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL3083-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1PL3004-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL3005-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3007-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL3091-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3092-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL3093-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3094-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3096-A	1-TS-30-194A PIGTAIL	WBNEQ-ITS-002	EEB-CBL-1.0	
1PL3098-A	1-TS-30-194B PIGTAIL	WBNEQ-ITS-002	EEB-CBL-1.0	
1PL3101-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3102-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL3103-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3104-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3105-B	1-TS-30-195A PIGTAIL	WBNEQ-ITS-002	EEB-CBL-1.0	
1PL3108-B	1-TS-30-195B PIGTAIL	WBNEQ-ITS-002	EEB-CBL-1.0	
1PL3112-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL3113-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3114-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL3115-B	1-TS-30-196A PIGTAIL	WBNEQ-ITS-002	EEB-CBL-1.0	
1PL3118-B	1-TS-30-196B PIGTAIL	WBNEQ-ITS-002	EEB-CBL-1.0	
1PL3121-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3122-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL3123-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3124-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1PL3125-B	1-TS-30-197A PIGTAIL	WBNEQ-ITS-002	EEB-CBL-1.0	
1PL3128-B	1-TS-30-197B PIGTAIL	WBNEQ-ITS-002	EEB-CBL-1.0	
1PL3131-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3132-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL3133-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3134-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL3135-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3137-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL3141-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3142-B	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL3143-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3144-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL3145-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3147-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL3151-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3152-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL3153-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3154-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL3155-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3157-A	0-TS-30-192B PIGTAIL	WBNEQ-ITS-002	EEB-CBL-1.0	
1PL3161-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3162-B	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL3163-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3164-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1PL3165-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3167-A	0-TS-50-193B PIGTAIL	WBNEQ-ITS-002	EEB-CBL-1.0	
1PL3191-A	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1PL3192-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL3193-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3194-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL3195-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3197-A	1-TS-50-190B PIGTAIL	WBNEQ-ITS-002	EEB-CBL-1.0	
1PL3201-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3202-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL3203-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3204-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL3205-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3207-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL3242-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3250-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3302-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3309-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3472-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3482-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3490-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3497-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3520-A	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1PL3521-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1PL3522-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3523-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL3524-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL3530-B	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1PL3531-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3532-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3533-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL3534-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL3540-A	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1PL3541-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL3542-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL3546-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL3550-B	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1PL3551-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL3552-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL3556-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL3584-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3587-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3603-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3613-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3716-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3760-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3780-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3781-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAK/ THI</u>
1PL3787-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3796-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3800-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3801-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3801-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3810-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3810-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3811-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3811-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3814-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL3820-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3821-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3823-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3825-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3826-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3827-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL3828-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL3829-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL3830-B	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1PL3831-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL3832-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL3835-B	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1PL3836-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL3837-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAK/ THI
1PL3838-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL3839-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL3877-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3880-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3881-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL3882-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3882-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3905-B	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL3905-B	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3906-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3907-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3907-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3913-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3913-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3914-A	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1PL3920-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL3920-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3920-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3921-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL3921-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL3921-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3940-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3941-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL3942-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAR/ THI
1PL3942-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3960-A	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL3960-A	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL3961-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3962-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL3962-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4022-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL4029-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4030-B	PXHJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1PL4031-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4032-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4033-B	PXHJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL4042-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4049-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL4060-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4061-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4071-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4430-B	PXJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL4431-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL4460-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL4461-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4462-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4468-B	PXHJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL4500-A	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
1PL4501-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4502-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4500-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL4520-A	PXJ	WBNEQ-CABL-063	EEB-CBL-1.0	
1PL4521-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4540-A	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4541-S	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL4542-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4543-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4565-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4569-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4577-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4581-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4588-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4589-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4592-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4593-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4600-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4601-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4604-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4605-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4627-A	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4628-A	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4629-A	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAK/ THI
1PL4630-A	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4631-A	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4632-A	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4633-A	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4677-B	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4678-B	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4679-B	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4680-B	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4681-B	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4682-B	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4683-B	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4725-A	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL4726-A	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL4727-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4731-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL4732-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL4733-A	PXJ	WBNEQ-CABL-063	EEB-CBL-1.0	
1PL4734-A	PXJ	WBNEQ-CABL-063	EEB-CBL-1.0	
1PL4735-S	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL4736-S	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL4737-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL4738-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4739-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL4742-B	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TRI
IPL4743-B	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IPL4744-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IPL4746-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IPL4748-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IPL4749-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IPL4750-A	PXNJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IPL4752-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IPL4753-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IPL4755-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IPL4756-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IPL4757-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IPL4758-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IPL4764-B	PXNJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IPL4766-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IPL4767-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IPL4769-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IPL4770-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IPL4771-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IPL4772-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IPL4775-A	PXNJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IPL4777-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IPL4778-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IPL4780-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IPL4781-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TMI
1PL4782-A	SR0AJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1PL4783-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4789-B	PXWJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL4791-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4792-B	SR0AJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1PL4794-B	SR0AJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1PL4795-B	PXWJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL4796-B	SR0AJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1PL4797-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4800-A	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL4804-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4805-A	SR0AJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1PL4807-A	SR0AJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1PL4809-A	SR0AJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1PL4812-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4816-A	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4820-A	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL4825-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4826-A	SR0AJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1PL4828-A	SR0AJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1PL4830-A	SR0AJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1PL4833-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4836-A	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4839-B	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1PL4843-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4844-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1PL4846-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1PL4848-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1PL4850-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4853-B	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4856-B	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL4861-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4862-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1PL4864-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1PL4866-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1PL4870-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4873-B	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL4875-A	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL4876-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1PL4879-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4880-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1PL4881-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4885-B	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL4886-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1PL4889-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4890-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1PL4891-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4895-B	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1PL4896-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL4897-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL4956-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL4968-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL4971-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL4975-A	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL4976-A	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL4978-A	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL4979-A	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL4982-B	PXJ	WBNEQ-CABL-063	EEB-CBL-1.0	
1PL4982-B	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL4982-B	PXJ	WBNEQ-CABL-063	EEB-CBL-1.0	
1PL4983-B	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL4985-B	PXJ	WBNEQ-CABL-063	EEB-CBL-1.0	
1PL4986-B	PXJ	WBNEQ-CABL-063	EEB-CBL-1.0	
1PL5003-A	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL5004-A	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL5005-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL5008-A	J	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL5019-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL5022-B	J	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL5200-B	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL5201-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL5204-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAW/ TNI
1PL5206-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL5209-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL5210-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL5211-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL5212-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL5261-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL5264-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL5270-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL5271-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL5273-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL5274-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL6108-A	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1PL6109-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL6111-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL6114-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL6115-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL6117-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL6120-A	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1PL6122-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL6123-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL6131-B	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1PL6133-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL6134-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL6138-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ TMI
1PL6145-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL6148-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL6149-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL6152-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL6155-B	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL6156-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL6159-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL6160-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL6161-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL6165-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL6166-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL6167-B	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL6168-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL6170-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL6171-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL6172-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL6176-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL6177-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL6178-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL6182-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL6183-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL6184-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL6188-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL6189-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ TKI
1PL6190-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL6245-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL6247-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL6248-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL6249-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL6250-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL6252-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL6253-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL6254-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL6255-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL6257-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL6258-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL6259-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PL6260-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PL6262-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1PL6263-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL6320-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL6330-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PL6360-B	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1PL6381-B	PXNJ	WBNEQ-CABL-022	EEB-CBL-1.0	
1PL6385-A	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1PL6386-A	PXNJ	WBNEQ-CABL-022	EEB-CBL-1.0	
1PL6443-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL6455-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1PL6705-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL6812-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL6814-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL6815-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL6816-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL6817-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL6818-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PL6819-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PH 7-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH 31-G	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH 494-E	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH 494-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH 495-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH 500-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH 501-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH 505-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH 506-D	NS	WBNEQ-CABL-010	EEB-CBL-1.0	
1PH 507-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH 508-D	NS	WBNEQ-CABL-010	EEB-CBL-1.0	
1PH 515-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH 516-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH 517-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH 518-D	NS	WBNEQ-CABL-010	EEB-CBL-1.0	
1PH 520-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
1PM 591-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 594-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 595-E	NS	WBNEQ-CABL-010	EEB-CBL-1.0	
1PM 605-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 606-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 615-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 616-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 625-F	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 626-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 635-E	NS	WBNEQ-CABL-010	EEB-CBL-1.0	
1PM 636-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 637-E	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 638-E	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 645-E	NS	WBNEQ-CABL-010	EEB-CBL-1.0	
1PM 646-E	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 647-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 648-E	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 685-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 686-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 690-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 691-E	NS	WBNEQ-CABL-010	EEB-CBL-1.0	
1PM 695-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 696-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 705-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1PM 706-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 710-F	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 711-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 725-F	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 726-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 727-F	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 728-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 740-F	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 741-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 742-F	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 743-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 777-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 778-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 778-D	NS	WBNEQ-CABL-010	EEB-CBL-1.0	
1PM 783-E	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 784-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 790-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 791-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 800-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 801-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 810-F	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 811-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 820-G	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 821-G	NS	WBNEQ-CABL-006	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAH/ THI</u>
1PM 822-G	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 823-G	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 830-G	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 831-G	NS	WBNEQ-CABL-010	EEB-CBL-1.0	
1PM 832-G	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 833-G	NS	WBNEQ-CABL-010	EEB-CBL-1.0	
1PM 870-E	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 871-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 875-E	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 876-E	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 880-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 881-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 890-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 891-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 900-F	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 901-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 933-F	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 934-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 941-G	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 942-G	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 949-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 950-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PM 987-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PM 988-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAK/ TMI
1PH1007-F	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1008-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1025-G	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1026-G	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1040-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1041-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1070-E	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1071-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1085-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1086-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1222-F	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH1222-F	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1223-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1231-G	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH1231-G	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1232-G	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1240-G	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH1240-G	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1241-G	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1250-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1250-F	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH1251-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1289-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1305-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1PH1313-D	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH1313-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1314-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1325-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1326-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1335-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1347-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1360-G	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1360-G	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH1360-G	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1381-G	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1400-F	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH1400-F	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1401-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1415-E	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH1415-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1416-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1429-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1445-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1453-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1454-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1465-E	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH1465-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1466-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1PH1474-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1480-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1490-F	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1505-G	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH1505-G	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1506-G	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1520-F	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH1520-F	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1521-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1535-D	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH1535-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1536-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1547-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1563-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1572-D	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH1572-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1573-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1585-E	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH1585-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1586-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1595-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1607-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1613-F	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1625-G	NS	WBNEQ-CABL-012	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ TMI
1PH1625-G	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1626-G	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1640-F	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH1640-F	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1641-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1655-D	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH1655-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1656-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1667-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1685-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1693-D	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH1693-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1694-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1705-E	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH1705-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1706-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1715-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1723-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1729-G	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1740-G	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH1740-G	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1741-G	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1755-F	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH1755-F	NS	WBNEQ-CABL-017	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1PH1756-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1770-E	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH1770-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1771-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1800-G	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1807-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1834-G	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1840-F	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH1847-E	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH1854-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH2035-D	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PH2046-E	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PH2060-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH2085-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH2232-F	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH2236-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH2238-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH2240-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH2242-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH2244-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH2245-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH2285-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH2430-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH2435-B	NS	WBNEQ-CABL-006	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ TRI
1PH2440-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH2442-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH2444-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH2445-B	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH2485-B	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH2485-B	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH2540-B	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH2541-B	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH2542-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH2543-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH2544-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH2545-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH2546-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH2547-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH3096-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH3101-B	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH3195-A	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH3195-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH3320-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH3322-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH3324-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH3330-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH3332-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH3334-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAW/ TRI
1PN3721-A	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PN3723-A	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PN3725-B	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PN3727-B	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PN3765-B	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PN3780-A	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PN3805-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PN3806-B	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PN3810-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PN3811-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PN3870-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PN3877-E	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PN3877-E	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PN3882-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PN3882-F	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PN3887-B	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PN3921-B	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PN3926-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PN3990-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PN3995-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PN4360-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PN4370-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PN4395-B	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PN4396-A	NS	WBNEQ-CABL-012	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ TWI
1PH4397-B	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH4398-A	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH4420-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4425-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4430-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH4435-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4450-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4453-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4455-B	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH4455-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4456-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4457-B	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH4458-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4460-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4463-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4465-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH4465-A	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH4466-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH4467-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH4468-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4470-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4473-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4475-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH4475-A	NS	WBNEQ-CABL-012	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1PH4476-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH4477-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH4478-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4480-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4483-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4485-B	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH4485-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4486-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4487-B	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH4488-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4490-A	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH4490-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4491-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH4492-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH4493-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4495-B	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH4495-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4496-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4497-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4498-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4500-B	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH4500-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4501-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4502-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1PH4503-B	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH4505-A	NS	WBNEQ-CABL-012	EEB-CBL-1.0	
1PH4505-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4506-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH4507-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH4508-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH4700-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4701-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4790-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4791-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4800-F	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH4801-F	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH4810-G	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH4811-G	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH5051-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH5053-B	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH5132-E	NS	WBNEQ-CABL-010	EEB-CBL-1.0	
1PH5133-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH5138-E	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH5139-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH5140-E	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH5141-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH5142-E	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH5143-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1PH5144-E	NS	WBNEQ-CABL-010	EEB-CBL-1.0	
1PH5145-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH5146-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH5147-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH5148-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH5155-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH5156-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH5161-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH5162-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH5163-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH5164-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH5165-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH5166-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH5167-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH5168-D	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1PH5169-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH5170-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH5171-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PH5203-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PH5204-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PH5205-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PH5348-E	NS	WBNEQ-CABL-010	EEB-CBL-1.0	
1PH5349-E	NS	WBNEQ-CABL-010	EEB-CBL-1.0	
1PH5420-D	NS	WBNEQ-CABL-017	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAK/ TNI
1PW5430-E	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1PP 429-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PP 430-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 439-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PP 440-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 444-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PP 445-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PP 446-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PP 447-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PP 450-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 454-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 456-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 460-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 462-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 466-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PP 468-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 475-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 478-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 479-A	PXMJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1PP 480-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PP 483-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 484-B	PXMJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1PP 489-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PP 550-A	CPSJ	WBNEQ-CABL-033	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ TKI
1PP 552-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 554-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 562-B	EPSJ	WBNEQ-CABL-005	EEB-CBL-1.0	
1PP 564-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 566-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PP 570-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PP 574-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PP 575-A	EPSJ	WBNEQ-CABL-005	EEB-CBL-1.0	
1PP 577-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 578-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 580-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 587-B	EPSJ	WBNEQ-CABL-005	EEB-CBL-1.0	
1PP 589-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 590-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 592-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 600-A	EPSJ	WBNEQ-CABL-005	EEB-CBL-1.0	
1PP 602-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 603-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 605-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PP 606-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PP 610-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PP 612-B	EPSJ	WBNEQ-CABL-005	EEB-CBL-1.0	
1PP 614-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 615-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1PP 617-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1PP 625-A	CPSJ	NBNEQ-CABL-033	EEB-CBL-1.0	
1PP 627-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1PP 628-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1PP 630-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1PP 637-B	EPSJ	NBNEQ-CABL-005	EEB-CBL-1.0	
1PP 639-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1PP 640-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1PP 642-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1PP 650-A	EPSJ	NBNEQ-CABL-005	EEB-CBL-1.0	
1PP 652-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1PP 653-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1PP 655-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1PP 662-B	EPSJ	NBNEQ-CABL-005	EEB-CBL-1.0	
1PP 664-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1PP 665-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1PP 667-B	PXNJ	NBNEQ-CABL-003	EEB-CBL-1.0	
1PP 675-A	EPSJ	NBNEQ-CABL-005	EEB-CBL-1.0	
1PP 677-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1PP 677-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1PP 679-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1PP 681-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1PP 687-A	EPSJ	NBNEQ-CABL-005	EEB-CBL-1.0	
1PP 689-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ TKI
1PP 689-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 691-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 693-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 700-B	EPSJ	WBNEQ-CABL-064	EEB-CBL-1.0	
1PP 702-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 702-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 704-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PP 706-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PP 712-B	EPSJ	WBNEQ-CABL-064	EEB-CBL-1.0	
1PP 714-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 714-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 716-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PP 718-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PP 751-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 754-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 757-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 760-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 762-B	EPSJ	WBNEQ-CABL-005	EEB-CBL-1.0	
1PP 763-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 766-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 803-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1PP 823-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PP 895-B	J	WBNEQ-CABL-003	EEB-CBL-1.0	
1PS 161-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAW/ THI
IPS 163-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
IPS 164-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IPS 166-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
IPS 167-A	NS	WBNEQ-CABL-049	EEB-CBL-1.0	
IPS 168-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
IPS 181-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IPS 183-B	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
IPS 184-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IPS 186-B	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
IPS 187-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
IPS 188-B	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
IPS 202-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
IPS 207-B	NS	WBNEQ-CABL-010	EEB-CBL-1.0	
IPS 220-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IPS 225-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IPS 230-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IPS 235-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IPS 262-D	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IPS 263-D	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IPS 264-D	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IPS 265-D	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IPS 302-E	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IPS 303-E	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IPS 304-E	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1PS 305-E	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PS 321-F	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PS 322-F	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PS 323-F	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PS 324-F	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PS 325-F	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PS 341-G	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PS 342-G	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PS 343-G	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PS 344-G	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PS 345-G	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PV 20-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PV 21-A	PXNJ	WBNEQ-CABL-022	EEB-CBL-1.0	
1PV 23-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PV 24-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PV 26-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PV 29-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PV 35-A	PXNJ	WBNEQ-CABL-008	EEB-CBL-1.0	
1PV 43-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PV 75-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PV 76-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PV 77-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PV 78-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PV 80-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAW/ THI
1PV 83-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PV 100-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PV 101-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PV 102-A	PXNJ	WBNEQ-CABL-022	EEB-CBL-1.0	
1PV 104-A	PXNJ	WBNEQ-CABL-022	EEB-CBL-1.0	
1PV 105-A	PXNJ	WBNEQ-CABL-008	EEB-CBL-1.0	
1PV 138-B	NS	WBNEQ-CABL-037	EEB-CBL-1.0	
1PV 139-B	PXNJ	WBNEQ-CABL-022	EEB-CBL-1.0	
1PV 139-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PV 141-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PV 142-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PV 145-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PV 148-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PV 157-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PV 163-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PV 174-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PV 180-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PV 181-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1PV 182-B	PXNJ	WBNEQ-CABL-022	EEB-CBL-1.0	
1PV 184-B	PXNJ	WBNEQ-CABL-008	EEB-CBL-1.0	
1PV 185-B	PXNJ	WBNEQ-CABL-008	EEB-CBL-1.0	
1PV 200-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PV 203-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1PV 590-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ TKI
1PV 591-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PV 593-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1PV 604-E	PXNJ	WBNEQ-CABL-022	EEB-CBL-1.0	
1PV 605-D	PXNJ	WBNEQ-CABL-022	EEB-CBL-1.0	
1RM 40-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1RM 41-A	SPE516	WBNEQ-CABL-013	EEB-CBL-1.0	
1RM 42-A	SPE516	WBNEQ-CABL-013	EEB-CBL-1.0	
1RM 43-A	SPE516	WBNEQ-CABL-013	EEB-CBL-1.0	
1RM 46-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1RM 47-B	SPE516	WBNEQ-CABL-013	EEB-CBL-1.0	
1RM 48-B	SPE516	WBNEQ-CABL-013	EEB-CBL-1.0	
1RM 49-B	SPE516	WBNEQ-CABL-013	EEB-CBL-1.0	
1RM 52-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1RM 53-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1RM 55-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1RM 56-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1RM 200-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1RM 205-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1RM 200-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1RM 282-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1RM 283-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1RM 285-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1RM 290-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1RM 292-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAR/ THI
1RW 293-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1RW 295-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1RW 300-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1RW 302-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1RW 303-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1RW 305-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1RW 310-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1RW 312-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1RW 313-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1RW 315-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1RW 320-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1RW 322-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1RW 323-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1RW 324-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1RW 326-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1RW 330-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1RW 332-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1RW 333-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1RW 334-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1RW 336-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1RW 340-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1RW 342-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1RW 343-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1RW 344-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1RM 346-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1RM 350-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1RM 352-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1RM 353-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1RM 353-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1RM 354-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1RM 356-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1RM 360-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1RM 362-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1RM 363-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1RM 364-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1RM 366-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1RM 370-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1RM 372-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1RM 373-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1RM 374-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1RM 376-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1RM 380-B	PXNJ	WBNEQ-CABL-008	EEB-CBL-1.0	
1RM 381-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
1RM 382-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1RM 384-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1RM 385-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1RM 386-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1RM 392-B	PXNJ	WBNEQ-CABL-008	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ TKI
IRM 393-B	NS	NBNEQ-CABL-017	EEB-CBL-1.0	
IRM 394-B	PXMJ	NBNEQ-CABL-002	EEB-CBL-1.0	
IRM 396-A	PXMJ	NBNEQ-CABL-002	EEB-CBL-1.0	
IRM 397-A	NS	NBNEQ-CABL-017	EEB-CBL-1.0	
IRM 398-A	PXMJ	NBNEQ-CABL-002	EEB-CBL-1.0	
IRM 420-A	COAX	NBNEQ-CABL-061	EEB-CBL-1.0	
IRM 422-A	NS	NBNEQ-CABL-017	EEB-CBL-1.0	
IRM 423-A	PXMJ	NBNEQ-CABL-003	EEB-CBL-1.0	
IRM 424-A	PXMJ	NBNEQ-CABL-002	EEB-CBL-1.0	
IRM 427-B	NS	NBNEQ-CABL-017	EEB-CBL-1.0	
IRM 428-B	PXMJ	NBNEQ-CABL-002	EEB-CBL-1.0	
IRM 429-B	PXMJ	NBNEQ-CABL-002	EEB-CBL-1.0	
IRM 431-A	NS	NBNEQ-CABL-017	EEB-CBL-1.0	
IRM 432-A	PXMJ	NBNEQ-CABL-002	EEB-CBL-1.0	
IRM 433-A	PXMJ	NBNEQ-CABL-002	EEB-CBL-1.0	
IRM 435-B	NS	NBNEQ-CABL-017	EEB-CBL-1.0	
IRM 436-B	PXMJ	NBNEQ-CABL-003	EEB-CBL-1.0	
IRM 437-B	PXMJ	NBNEQ-CABL-002	EEB-CBL-1.0	
IRM 440-A	COAX	NBNEQ-CABL-061	EEB-CBL-1.0	
IRM 441-A	COAX	NBNEQ-CABL-042	EEB-CBL-1.0	
IRM 442-A	COAX	NBNEQ-CABL-061	EEB-CBL-1.0	
IRM 443-A	COAX	NBNEQ-CABL-042	EEB-CBL-1.0	
IRM 444-A	COAX	NBNEQ-CABL-061	EEB-CBL-1.0	
IRM 445-A	COAX	NBNEQ-CABL-042	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
IRM 446-A	COAX	WBNEQ-CABL-042	EEB-CBL-1.0	
IRM 447-A	COAX	WBNEQ-CABL-042	EEB-CBL-1.0	
IRM 448-B	COAX	WBNEQ-CABL-061	EEB-CBL-1.0	
IRM 449-B	COAX	WBNEQ-CABL-061	EEB-CBL-1.0	
IRM 450-B	COAX	WBNEQ-CABL-061	EEB-CBL-1.0	
IRM 451-B	COAX	WBNEQ-CABL-061	EEB-CBL-1.0	
IRM 452-B	COAX	WBNEQ-CABL-061	EEB-CBL-1.0	
IRM 453-B	COAX	WBNEQ-CABL-061	EEB-CBL-1.0	
IRM 454-B	COAX	WBNEQ-CABL-042	EEB-CBL-1.0	
IRM 455-B	COAX	WBNEQ-CABL-061	EEB-CBL-1.0	
ISG 80-A	PXHJ	WBNEQ-CABL-049	EEB-CBL-1.0	
ISG 85-B	PXHJ	WBNEQ-CABL-049	EEB-CBL-1.0	
ISG 90-A	PXHJ	WBNEQ-CABL-049	EEB-CBL-1.0	
ISG 95-B	PXHJ	WBNEQ-CABL-049	EEB-CBL-1.0	
ISG 100-A	PXHJ	WBNEQ-CABL-049	EEB-CBL-1.0	
ISG 101-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
ISG 108-A	PXHJ	WBNEQ-CABL-049	EEB-CBL-1.0	
ISG 109-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
ISG 124-B	PXHJ	WBNEQ-CABL-049	EEB-CBL-1.0	
ISG 125-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
ISG 132-B	PXHJ	WBNEQ-CABL-049	EEB-CBL-1.0	
ISG 133-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
ISG 219-S	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
ISG 220-A	PXJ	WBNEQ-CABL-008	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
156 221-B	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
156 222-S	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
156 223-S	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
156 224-S	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
156 225-S	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
156 226-S	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
156 227-S	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
156 228-S	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
156 229-S	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
156 231-S	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
156 232-S	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
156 233-S	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
156 234-S	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
156 240-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
156 241-B	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
156 242-S	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
156 250-S	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
156 251-S	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
156 252-S	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
156 253-S	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
156 255-S	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
156 256-S	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
156 260-S	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
156 261-S	NS	WBNEQ-CABL-006	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TNI
156 262-S	NS	WBNEQ-CABL-049	EEB-CBL-1.0	
156 264-S	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
156 266-S	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
156 267-S	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
156 268-S	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
156 321-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
156 326-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
156 331-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
156 336-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
156 369-S	NS	WBNEQ-CABL-010	EEB-CBL-1.0	
156 370-S	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
156 520-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
156 521-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
156 522-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
156 523-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
156 527-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
156 531-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
156 536-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
156 538-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
156 539-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
156 540-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
156 545-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
156 547-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
156 548-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAN/ TRI</u>
156 549-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
156 553-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
156 557-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
156 561-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
156 563-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
156 564-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
156 565-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
156 602-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
156 603-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
156 606-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
156 610-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
156 611-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
156 614-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
156 615-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
156 616-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
156 619-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
156 623-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
156 624-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
156 627-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 15-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 16-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 17-A	HS	WBNEQ-CABL-006	EEB-CBL-1.0	
IV 18-A	HS	WBNEQ-CABL-006	EEB-CBL-1.0	
IV 37-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
IV 38-B	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
IV 39-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 40-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 41-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 42-B	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
IV 43-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 44-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 45-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 46-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 47-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 49-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 50-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 64-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 66-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 67-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 68-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 69-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 70-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 71-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 72-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 73-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 74-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 75-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 76-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TMI
IV 77-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 78-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 79-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 95-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 96-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 97-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 98-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 99-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 105-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 780-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 784-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 785-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 786-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 787-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 791-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 793-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 794-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 795-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 796-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 824-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 828-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 829-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 830-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 831-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAW/ THI
IV 834-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 836-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 837-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 838-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 839-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 861-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 862-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 863-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 865-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 866-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 867-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 868-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 869-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 877-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 878-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 879-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 880-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 882-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 883-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 884-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 885-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 886-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 893-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 894-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
IV 895-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 896-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 898-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 899-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 900-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 901-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 902-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 911-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 912-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 913-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 914-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 916-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 917-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 918-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 919-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 920-B	SROJJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 940-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 942-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 943-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 944-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 945-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 947-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 948-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 949-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAM/ TMI</u>
IV 950-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 951-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 952-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 953-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 954-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 955-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 956-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 957-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 958-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 959-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 960-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 961-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 962-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 963-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 964-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 980-A	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
IV 981-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
IV 990-A	NS	WBNEQ-CABL-010	EEB-CBL-1.0	
IV 991-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
IV 1000-B	NS	WBNEQ-CABL-037	EEB-CBL-1.0	
IV 1001-B	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
IV 1010-B	NS	WBNEQ-CABL-017	EEB-CBL-1.0	
IV 1011-B	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
IV 1021-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1V 1024-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 1025-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 1026-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1027-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 1030-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 1031-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1034-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 1035-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 1036-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1037-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 1038-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 1040-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 1041-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1044-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 1045-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 1046-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 1046-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1047-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 1048-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 1051-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1054-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 1055-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 1056-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1057-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1V 1062-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1064-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 1065-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1066-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1067-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1070-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1V 1082-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1084-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 1085-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1086-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1087-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1090-A	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1V 1100-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1101-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1102-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1104-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1105-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1106-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1107-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1110-B	NS	WBNEQ-CABL-006	EEB-CBL-1.0	
1V 1120-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1121-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1122-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1124-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
IV 1125-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
IV 1126-B	PXNJ	NBNEQ-CABL-049	EEB-CBL-1.0	
IV 1127-B	PXNJ	NBNEQ-CABL-049	EEB-CBL-1.0	
IV 1130-B	HS	NBNEQ-CABL-006	EEB-CBL-1.0	
IV 1160-A	PXNJ	NBNEQ-CABL-003	EEB-CBL-1.0	
IV 1161-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
IV 1162-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
IV 1163-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
IV 1164-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
IV 1165-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
IV 1220-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
IV 1222-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
IV 1223-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
IV 1224-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
IV 1225-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
IV 1226-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
IV 1235-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
IV 1237-B	PXNJ	NBNEQ-CABL-003	EEB-CBL-1.0	
IV 1238-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
IV 1240-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
IV 1241-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
IV 1242-B	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
IV 1243-B	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
IV 1244-B	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TWI
1V 1256-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1257-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1259-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1260-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1261-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1262-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
1V 1263-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
1V 1264-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
1V 1265-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
1V 1273-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1274-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1276-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1277-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1278-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1279-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
1V 1279-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
1V 1280-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
1V 1281-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
1V 1282-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
1V 1289-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1290-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1291-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1292-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1293-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAH/ THI</u>
1V 1294-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1295-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 1296-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 1297-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 1298-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 1306-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1307-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1308-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 1310-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1311-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1312-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 1313-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 1314-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 1315-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 1322-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1323-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1325-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1326-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1327-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1328-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 1329-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 1330-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 1331-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 1340-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAM/ THI</u>
IV 1341-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1343-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1344-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1345-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1346-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 1347-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 1348-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 1349-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 1356-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1357-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1358-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1359-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1360-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1361-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1363-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 1364-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 1365-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 1373-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1374-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1375-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1376-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1377-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1378-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1379-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
IV 1380-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 1381-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 1382-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 1390-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1392-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 1393-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 1394-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1396-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1397-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 1398-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 1399-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 1412-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1414-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 1415-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 1416-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 1418-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1419-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 1420-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 1421-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 1434-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1436-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1438-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1439-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 1440-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ TWI
1V 1443-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1445-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1446-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
1V 1447-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
1V 1448-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
1V 1449-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
1V 1452-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1454-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1456-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1457-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1458-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1461-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1464-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1465-A	PXNJ	NBNEQ-CABL-002	EEB-CBL-1.0	
1V 1466-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1467-A	PXNJ	NBNEQ-CABL-002	EEB-CBL-1.0	
1V 1470-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1473-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1474-A	PXNJ	NBNEQ-CABL-049	EEB-CBL-1.0	
1V 1475-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1476-A	PXNJ	NBNEQ-CABL-049	EEB-CBL-1.0	
1V 1479-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1482-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1483-A	PXNJ	NBNEQ-CABL-003	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAW/ TMI
1V 1484-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1485-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 1488-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1491-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1492-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 1493-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1494-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 1497-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1500-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1501-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 1502-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1503-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1506-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1509-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1510-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 1511-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1512-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1577-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1582-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 1583-B	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 1584-B	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 1585-B	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 1587-B	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 1588-B	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAH/ THI</u>
1V 1595-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1597-B	PXNJ	NBNEQ-CABL-003	EEB-CBL-1.0	
1V 1598-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1599-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1601-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1602-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1607-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1609-A	PXNJ	NBNEQ-CABL-003	EEB-CBL-1.0	
1V 1610-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
1V 1611-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
1V 1612-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
1V 1614-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
1V 1615-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
1V 1620-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1622-A	PXNJ	NBNEQ-CABL-003	EEB-CBL-1.0	
1V 1623-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1624-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1626-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1627-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
1V 1628-A	SROJJ	NBNEQ-CABL-036	EEB-CBL-1.0	
1V 1629-A	SROAJ	NBNEQ-CABL-036	EEB-CBL-1.0	
1V 1634-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 1636-A	PXNJ	NBNEQ-CABL-003	EEB-CBL-1.0	
1V 1637-A	PXNJ	NBNEQ-CABL-003	EEB-CBL-1.0	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1V 1636-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1640-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1641-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1700-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 1702-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1703-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 1704-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 1705-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 1706-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 1714-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1716-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1717-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1718-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1800-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 1801-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1802-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1803-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1804-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 1810-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 1811-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1812-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1813-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1814-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1820-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
1V 1821-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1822-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1823-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 1824-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 1825-A	PXNJ	WBNEQ-CABL-006	EEB-CBL-1.0	
1V 1826-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 1827-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1828-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1828-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1830-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 1831-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1832-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1833-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 1834-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 1835-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 1850-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 1851-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1852-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1853-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1854-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1855-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1870-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 1871-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1872-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1V 1873-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1874-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1875-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1900-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 1901-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1902-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1903-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1904-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1905-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1906-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1907-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1908-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1909-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1910-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1912-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1914-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1915-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 1916-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 1917-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1918-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 1920-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 1921-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1922-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1923-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1V 1924-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 1925-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1926-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1927-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1928-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1930-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1932-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 1933-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 1934-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1935-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 1936-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1937-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1938-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1940-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 1941-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1942-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1943-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1950-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 1951-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1952-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1953-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 1955-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 1960-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 1961-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
IV 1962-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1963-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1965-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 1970-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 1971-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1972-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1973-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1980-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 1981-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1982-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1983-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1990-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 1991-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1992-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 1992-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 1993-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2000-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 2001-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2002-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2003-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2010-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 2011-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2012-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2013-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAW/ THI
1V 2020-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2021-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2022-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2023-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2030-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2031-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2032-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2033-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2040-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2041-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2042-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2043-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2050-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2051-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2052-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2053-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2060-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2061-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2062-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 2062-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2063-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2070-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2071-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2072-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
 UNIT 1 OPERATION ONLY  
 CABLES REQUIRING QUALIFICATION  
 UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAW/ TMI
1V 2073-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2050-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2081-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2082-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2083-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2085-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 2090-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2091-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2092-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2093-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2100-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2101-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2102-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2103-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2112-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2113-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2114-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2115-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2120-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2121-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2122-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2123-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2130-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2131-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TWI
1V 2132-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2133-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2135-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 2140-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2141-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2142-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2143-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2144-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2145-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2150-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2151-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2152-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2153-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2154-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2155-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2160-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2161-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2162-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2163-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2170-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2171-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2172-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2173-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2200-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ TR1
1V 2201-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2202-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2203-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2208-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2209-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2210-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2211-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2216-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2217-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2218-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2219-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2224-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2225-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2227-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2232-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2233-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2234-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2235-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2240-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2241-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2242-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2243-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2247-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2248-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1V 2249-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2250-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2255-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2256-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2257-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2258-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2261-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2262-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2263-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2264-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2265-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2266-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2268-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2274-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2275-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2276-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2277-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2278-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2279-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2280-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2282-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2283-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2284-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2285-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ TWI
IV 2286-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 2287-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 2288-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2292-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 2293-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2294-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2295-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2320-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 2321-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2322-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2323-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2326-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 2327-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2328-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2329-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2332-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 2333-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2334-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2335-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2338-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 2339-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2340-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2341-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2343-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAK/ TNI
1V 2345-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2346-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2347-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2350-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2351-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2352-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2353-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2356-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2357-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2358-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2359-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2362-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2363-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2364-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2365-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2368-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2369-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2370-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2371-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2374-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2375-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2376-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2377-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2380-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ TKI
1V 2381-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2382-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2383-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2386-A	CPJJ	NBNEQ-CABL-032	EEB-CBL-1.0	
1V 2387-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2388-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2389-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2392-B	CPJJ	NBNEQ-CABL-032	EEB-CBL-1.0	
1V 2393-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2394-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2395-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2398-A	CPJJ	NBNEQ-CABL-032	EEB-CBL-1.0	
1V 2399-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2399-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2401-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2404-B	CPJJ	NBNEQ-CABL-032	EEB-CBL-1.0	
1V 2405-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2407-B	PXNJ	NBNEQ-CABL-002	EEB-CBL-1.0	
1V 2410-A	CPJJ	NBNEQ-CABL-032	EEB-CBL-1.0	
1V 2411-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2412-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2413-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2416-B	CPJJ	NBNEQ-CABL-032	EEB-CBL-1.0	
1V 2417-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAR/ THI
1V 2418-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2419-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2422-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2423-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 2423-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 2425-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2428-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2429-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2430-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2431-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2434-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2435-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2436-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2437-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2440-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2441-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2442-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2443-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2445-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2446-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2447-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 2448-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2449-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2450-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1V 2451-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2452-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2453-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2454-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2454-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2455-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2456-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2460-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2461-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2462-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2463-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2466-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2467-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2468-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2469-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2472-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2473-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2474-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2475-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2478-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2479-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2480-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2481-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2484-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAW/ THI
1V 2485-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2486-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2487-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2490-A	CPJJ	NBNEQ-CABL-032	EEB-CBL-1.0	
1V 2491-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2492-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2493-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2502-B	CPJJ	NBNEQ-CABL-032	EEB-CBL-1.0	
1V 2503-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2504-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2505-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2508-B	CPJJ	NBNEQ-CABL-032	EEB-CBL-1.0	
1V 2509-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2510-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2511-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2514-B	CPJJ	NBNEQ-CABL-032	EEB-CBL-1.0	
1V 2515-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2516-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2517-B	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2520-A	CPJJ	NBNEQ-CABL-032	EEB-CBL-1.0	
1V 2521-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2522-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2523-A	PJJ	NBNEQ-CABL-015	EEB-CBL-1.0	
1V 2526-A	CPJJ	NBNEQ-CABL-032	EEB-CBL-1.0	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAH/ THI</u>
1V 2527-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2528-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2529-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2532-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2533-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2534-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2535-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2538-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2539-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2540-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2541-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2544-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2545-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2546-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2547-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2550-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2551-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2552-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2553-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2556-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2557-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2558-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2559-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2561-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAH/ THI</u>
1V 2562-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2563-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2564-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2565-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2566-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 2567-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 2568-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2569-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2570-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2571-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2572-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 2573-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 2574-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2575-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2576-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2577-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2578-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 2580-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2581-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 2582-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2583-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2606-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2607-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2608-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THE
IV 2609-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2612-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 2613-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2614-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2615-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2620-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 2621-A	PXNJ	WBNEQ-CABL-008	EEB-CBL-1.0	
IV 2622-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 2623-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 2624-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 2625-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2627-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 2630-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 2631-B	PXNJ	WBNEQ-CABL-008	EEB-CBL-1.0	
IV 2632-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2633-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 2634-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 2635-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2639-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 2640-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 2641-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2642-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 2643-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2647-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1V 2648-B	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2649-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2650-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2651-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2652-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2653-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2657-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 2660-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2661-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2662-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2663-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2667-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 2670-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2671-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2672-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2673-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2677-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 2680-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2681-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2682-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2683-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2687-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2688-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2689-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAM/ TMI</u>
1V 2690-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2695-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2696-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2697-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2698-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2703-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2704-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2705-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2706-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2710-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2712-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2713-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2714-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2716-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2720-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2721-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2722-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2723-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2726-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2728-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2729-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2730-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2731-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2734-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAK/ TMI
1V 2743-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2744-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 2745-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2746-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2747-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2748-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2752-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2753-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 2754-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2755-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 2756-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2757-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2760-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2761-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2764-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2765-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2767-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 2768-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 2769-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 2770-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2771-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2774-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2775-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2777-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	FAH/ TRI
1V 2779-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2780-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2781-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2782-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2783-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2784-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2785-A	PXHJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 2786-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 2787-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2790-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2791-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2792-A	PXHJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1V 2793-A	PXHJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1V 2794-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2800-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2801-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2802-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2803-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2808-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2809-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2810-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2811-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2812-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 2813-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAW/ THI
IV 2820-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 2821-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2822-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2823-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2830-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 2831-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2832-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2833-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2840-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 2841-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 2842-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2843-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 2844-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 2845-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 2847-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2849-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IV 2851-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 2852-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 2854-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 2855-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 2856-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 2857-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 2858-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 2859-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TRI
1V 2862-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2867-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2868-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2869-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2870-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2878-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2879-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2880-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2881-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2888-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2889-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2890-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2891-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2900-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2901-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2903-A	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1V 2904-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2905-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2908-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2909-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2911-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2912-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2913-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2920-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

<u>TYA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAM/ TRI</u>
1V 2921-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2923-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2924-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2925-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2930-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2931-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2933-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 2934-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2935-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2940-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2941-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2943-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 2944-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2945-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2950-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2951-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2953-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2954-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2955-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 2960-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2961-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2963-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2964-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2965-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 19CFR50.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAH/ THI</u>
1V 2968-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2969-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2971-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2972-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2973-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 2975-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 2976-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2977-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2978-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2980-A	PXMJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1V 2981-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2984-A	PXMJ	WBNEQ-CABL-008	EEB-CBL-1.0	
1V 2985-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 2990-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 2991-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2994-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 2995-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3000-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3001-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3004-B	PXMJ	WBNEQ-CABL-008	EEB-CBL-1.0	
1V 3005-B	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 3010-B	PXMJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1V 3011-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3014-B	PXMJ	WBNEQ-CABL-008	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
IV 3014-B	PXNJ	WBNEQ-CABL-006	EEB-CBL-1.0	
IV 3015-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IV 3020-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3021-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3023-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3024-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3028-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3029-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3031-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3032-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3035-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3036-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3038-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3039-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3043-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3044-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3046-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3047-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3051-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3052-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3054-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3055-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3060-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3061-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR59.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
1V 3063-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3064-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3069-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 3070-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3072-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3073-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3078-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 3079-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3080-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3082-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3086-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 3087-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 3088-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3090-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3091-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 3092-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 3096-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 3097-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 3098-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3100-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3101-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 3102-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 3106-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 3107-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
IV 3108-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3110-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3111-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 3112-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 3116-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 3117-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IV 3120-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3121-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 3122-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3124-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3125-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 3126-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 3130-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3131-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3132-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3133-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3134-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 3135-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3136-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3139-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 3140-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3141-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3142-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3143-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TKI
IV 3144-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3145-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3146-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3149-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 3150-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3151-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3154-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3155-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3160-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3161-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3164-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3165-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3170-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3171-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3172-A	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
IV 3173-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3174-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3175-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3177-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3185-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3186-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3187-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 3188-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3189-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
1V 3190-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3191-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3192-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3196-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3200-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 3202-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3203-B	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 3204-B	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 3205-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3210-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 3211-A	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 3212-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3213-A	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 3214-A	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 3215-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3217-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3220-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 3221-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3222-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3223-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3300-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 3301-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 3302-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3303-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
IV 3320-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3321-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3322-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3323-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3330-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3330-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3331-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3332-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3332-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3340-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3341-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3342-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3343-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3350-B	PXWJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 3351-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3352-B	PXWJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IV 3353-B	PXWJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 3380-D	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3381-D	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3382-D	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3383-D	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3384-D	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3385-D	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3386-D	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ TNI
IV 3388-D	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 3390-E	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3391-E	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3392-E	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3393-E	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3394-E	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3395-E	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3396-E	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3398-E	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 3400-F	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3402-F	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3410-G	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3412-G	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3413-G	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3416-G	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 3420-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 3422-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3423-A	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 3424-A	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 3425-A	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 3426-A	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 3430-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 3432-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3433-A	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TRI
1V 3434-A	SR0AJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 3435-A	SR0AJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 3436-A	SR0AJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 3440-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3442-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3450-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3452-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3460-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3462-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3464-B	PXMJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1V 3560-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3561-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3562-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3563-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3564-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3570-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3571-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3572-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3573-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3580-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3581-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3582-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3583-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3587-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TRI
1V 3588-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3589-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3592-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3593-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3594-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3601-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3602-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3603-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3610-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3611-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3612-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3613-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3614-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3620-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3621-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3622-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3623-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3627-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3628-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3629-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3630-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3635-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3636-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3637-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TKI
IV 3640-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 3641-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 3642-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 3648-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 3649-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 3650-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 3653-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 3657-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3660-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3661-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 3662-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 3663-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 3666-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3667-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 3668-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 3669-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 3673-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 3674-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 3675-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 3680-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3697-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3700-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 3701-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 3702-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
1V 3703-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3706-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3707-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3708-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3709-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3712-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3713-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3714-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3720-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3727-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3740-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3741-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3742-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3743-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3753-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3754-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3755-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3760-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3761-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3762-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3765-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3766-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3767-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3771-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAM/ TRI</u>
1V 3772-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3773-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3774-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3780-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3781-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3782-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3783-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3791-B	PXHJ	WBNEQ-CABL-008	EEB-CBL-1.0	
1V 3792-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3793-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3807-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3808-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3809-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3814-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3815-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3816-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3820-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3821-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3822-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3826-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3827-B	PXHJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 3828-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3829-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3834-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1V 3835-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3836-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3837-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 3980-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 3980-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 3982-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3984-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 3985-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3988-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 3990-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 3992-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 3993-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3995-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 3996-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 3998-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4000-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4004-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4005-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 4005-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 4007-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4009-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4020-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 4021-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4022-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TMI
1V 4024-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4025-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 4026-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 4050-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 4051-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4052-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4054-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4080-A	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1V 4081-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 4081-B	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1V 4082-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 4083-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 4100-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4101-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 4102-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 4103-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 4200-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4201-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 4202-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 4203-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4204-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 4205-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 4206-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 4207-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ TKI
1V 4210-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 4211-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 4212-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 4213-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 4214-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 4215-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 4216-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 4217-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 4222-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4223-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4225-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4226-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4227-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4228-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4240-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4241-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4243-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4244-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4245-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4246-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4260-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4262-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4263-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4264-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ TKI
IV 4265-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4266-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 4279-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4281-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4282-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 4283-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 4284-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 4295-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4297-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4298-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 4299-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 4300-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 4331-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4332-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4333-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4334-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4336-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4337-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 4338-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 4339-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 4340-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 4352-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4353-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4354-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAM/ THI</u>
1V 4355-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4356-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4357-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4358-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4359-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4360-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4361-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4423-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4425-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4426-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 4427-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 4428-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 4429-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 4432-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4433-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4434-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4435-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4437-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4438-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 4439-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 4440-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 4441-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 4445-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4446-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
IV 4447-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4448-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4449-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4450-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 4451-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 4452-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 4453-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 4459-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4460-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4461-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4462-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 4463-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 4464-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 4465-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 4470-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4471-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4472-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4473-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4477-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4478-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 4479-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 4480-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 4481-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 4485-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAN/ TRI</u>
IV 4486-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4487-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4488-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4492-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4493-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 4494-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 4495-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 4496-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 4500-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4501-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4502-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4503-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4507-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4508-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 4509-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 4510-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 4511-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 4572-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4573-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4574-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 4575-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 4576-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 4577-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 4578-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
1V 4593-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4594-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4595-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4596-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4597-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4598-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 4598-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 4599-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 4600-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 4601-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 4742-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4743-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4745-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4746-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4747-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4748-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4765-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4767-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4768-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4769-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4770-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4782-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4783-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4785-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1V 4786-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4787-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4788-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4795-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4796-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4798-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4799-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4800-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4801-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4827-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4828-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4830-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4831-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4832-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4833-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4918-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4919-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 4920-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 4921-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 4921-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 4922-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 4927-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4928-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4973-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TRI
1V 4977-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4978-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 4980-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 4981-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 5480-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 5481-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 5482-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 5483-A	KS	WBNEQ-CABL-012	EEB-CBL-1.0	
1V 5484-A	KS	WBNEQ-CABL-012	EEB-CBL-1.0	
1V 5485-A	KS	WBNEQ-CABL-012	EEB-CBL-1.0	
1V 5486-A	KS	WBNEQ-CABL-012	EEB-CBL-1.0	
1V 5487-A	KS	WBNEQ-CABL-012	EEB-CBL-1.0	
1V 5488-A	KS	WBNEQ-CABL-012	EEB-CBL-1.0	
1V 5490-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 5491-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 5492-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 5493-B	KS	WBNEQ-CABL-012	EEB-CBL-1.0	
1V 5494-B	KS	WBNEQ-CABL-012	EEB-CBL-1.0	
1V 5495-B	KS	WBNEQ-CABL-012	EEB-CBL-1.0	
1V 5496-B	KS	WBNEQ-CABL-012	EEB-CBL-1.0	
1V 5497-B	KS	WBNEQ-CABL-012	EEB-CBL-1.0	
1V 5498-B	KS	WBNEQ-CABL-012	EEB-CBL-1.0	
1V 5502-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 5503-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ TMI
1V 5504-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 5505-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 5507-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 5508-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 5552-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 5553-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 5556-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 5557-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 5558-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 5559-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 5567-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 5568-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 5570-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 5571-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 5572-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 5573-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 5574-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 5595-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 5596-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 5598-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 5599-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 5600-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 5609-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 5610-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ TMI
IV 5612-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 5613-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 5613-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 5614-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 5634-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IV 5635-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 5637-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IV 5638-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 5640-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 5641-A	PXNJ	WBNEQ-CABL-022	EEB-CBL-1.0	
IV 5642-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 5643-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 5660-B	PXNJ	WBNEQ-CABL-092	EEB-CBL-1.0	
IV 5661-B	PXNJ	WBNEQ-CABL-022	EEB-CBL-1.0	
IV 5662-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 5663-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 5740-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 5741-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 5742-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 5743-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 5745-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 5746-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 5747-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 5748-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
 UNIT 1 OPERATION ONLY  
 CABLES REQUIRING QUALIFICATION  
 UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
1V 5860-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 5862-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 5870-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 5872-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 5883-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 5885-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 5886-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 5887-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 5888-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 5889-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 5903-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 5905-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 5906-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 5907-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 5908-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 5909-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 5920-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 5922-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 5930-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 5932-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 5943-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 5945-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 5946-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 5947-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
 UNIT 1 OPERATION ONLY  
 CABLES REQUIRING QUALIFICATION  
 UNDER 10CFR50.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAM/ THI</u>
IV 5948-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 5949-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 5963-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 5965-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 5966-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 5967-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 5968-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 5969-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 6223-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 6224-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 6225-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 6226-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 6227-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 6228-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 6229-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 6244-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 6245-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 6246-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 6247-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 6248-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 6249-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 6257-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 6259-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 6260-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1V 6261-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6262-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6263-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6273-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6274-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6275-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6276-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6277-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6278-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6279-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6293-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6294-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6295-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6296-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6297-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6298-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6299-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6307-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6309-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6310-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6311-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6312-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6313-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6322-B	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAN/ THI</u>
1V 6323-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6324-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6325-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6326-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6327-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6328-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6329-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6342-B	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 6344-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6345-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6346-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6347-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6348-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6349-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6357-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6359-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6360-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6361-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6362-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6363-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 6372-B	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 6374-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6375-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6376-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	FAM/ THI
IV 6377-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 6378-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 6379-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 6392-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IV 6394-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 6395-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 6396-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 6397-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 6398-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 6399-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 6407-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 6409-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 6410-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 6411-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 6412-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 6413-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 6560-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IV 6561-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 6564-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 6565-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 6566-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 6570-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IV 6571-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 6574-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAM/ THI</u>
1V 6575-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 6576-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 6580-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6581-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6584-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6585-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6586-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6590-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6591-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6594-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6595-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6596-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6600-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 6601-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6603-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6604-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6605-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6610-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6611-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6613-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6614-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6615-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6620-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6621-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAN/ THI</u>
1V 6622-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6623-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6624-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6628-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 6629-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6630-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6631-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6632-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6637-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 6640-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6641-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6642-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6643-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6644-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6645-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6665-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6667-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6669-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6670-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6671-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6672-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6673-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 6695-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6697-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
1V 6712-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 6714-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 7140-B	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 7142-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7143-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 7144-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 7145-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 7146-B	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 7150-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7151-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7152-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 7153-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 7165-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 7167-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7168-A	SROJJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 7169-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 7170-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 7171-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 7173-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 7175-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7176-A	SROJJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 7177-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 7178-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 7179-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAR/ TRZ
IV 7190-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IV 7192-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 7193-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 7194-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 7195-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 7198-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IV 7200-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 7201-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 7202-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 7203-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 7215-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 7217-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 7218-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 7219-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 7220-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 7221-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 7224-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 7226-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 7227-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 7228-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 7229-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 7230-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 7520-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 7521-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TRI
IV 7523-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 7524-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 7525-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 7526-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 7527-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 7536-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 7537-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 7539-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 7540-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 7541-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 7542-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 7543-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 7565-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 7566-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 7567-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 7568-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 7570-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 7571-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 7572-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 7581-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 7582-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 7584-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 7585-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 7586-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EGS NUMBER	PAN/ TNI
1V 7587-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 7588-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 7600-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7601-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7603-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7606-A	PXNJ	WBNEQ-CABL-022	EEB-CBL-1.0	
1V 7610-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7611-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7613-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7616-A	PXNJ	WBNEQ-CABL-022	EEB-CBL-1.0	
1V 7620-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7621-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7623-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7624-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 7627-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 7631-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7633-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7634-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 7637-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 7641-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7643-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7646-B	PXNJ	WBNEQ-CABL-022	EEB-CBL-1.0	
1V 7651-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7653-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TMI
1V 7656-B	PXMJ	WBNEQ-CABL-022	EEB-CBL-1.0	
1V 7661-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7663-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7664-B	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 7667-B	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 7671-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7673-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7674-B	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 7677-B	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 7960-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 7961-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 7964-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 7964-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 7965-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7967-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7970-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 7971-B	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 7973-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 7974-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8040-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8041-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8044-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 8044-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8045-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ TMI
1V 8047-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8050-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8051-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8053-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8054-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8060-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8061-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8063-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8064-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8072-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8074-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8078-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8079-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8080-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8084-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8085-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8087-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8090-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8091-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8093-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8094-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8400-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 8402-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 8402-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR59.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1V 8403-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8404-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8405-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8407-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 8409-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8410-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8411-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8412-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8420-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 8422-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8423-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8424-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8425-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8427-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 8429-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8430-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8431-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8432-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8561-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 8562-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8564-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8565-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8571-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 8572-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAK/ TNI
1V 8574-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8575-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8581-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 8582-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8584-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8585-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8591-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 8592-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8594-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8595-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8601-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 8602-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8604-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8605-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8615-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 8616-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8618-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8619-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8621-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 8622-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8624-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8625-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8635-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 8636-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EGS NUMBER	PAM/ TMI
IV 8638-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 8639-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 8646-A	MS	WBNEQ-CABL-012	EEB-CBL-1.0	
IV 8647-A	MS	WBNEQ-CABL-012	EEB-CBL-1.0	
IV 8660-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 8661-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 8662-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 8663-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 8664-A	PXNJ	WBNEQ-CABL-008	EEB-CBL-1.0	
IV 8665-B	PXNJ	WBNEQ-CABL-008	EEB-CBL-1.0	
IV 8667-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 8668-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 8669-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 8670-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 8671-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 8672-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 8674-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 8675-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 8760-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 8761-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 8762-A	SRGAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 8766-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 8767-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 8768-A	SRGAJ	WBNEQ-CABL-036	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAK/ TKI
1V 8769-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 8770-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 8771-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8772-B	PXHJ	WBNEQ-CABL-022	EEB-CBL-1.0	
1V 8773-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 8777-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 8778-B	PXHJ	WBNEQ-CABL-022	EEB-CBL-1.0	
1V 8779-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 8780-B	PXHJ	WBNEQ-CABL-022	EEB-CBL-1.0	
1V 8781-B	PXHJ	WBNEQ-CABL-022	EEB-CBL-1.0	
1V 8782-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8783-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8784-A	PJHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 8785-A	PXHJ	WBNEQ-CABL-008	EEB-CBL-1.0	
1V 8786-A	PXHJ	WBNEQ-CABL-008	EEB-CBL-1.0	
1V 8787-B	PXHJ	WBNEQ-CABL-008	EEB-CBL-1.0	
1V 8788-B	PXHJ	WBNEQ-CABL-008	EEB-CBL-1.0	
1V 8789-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8790-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 8791-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9100-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 9102-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9104-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 9105-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	FAM/ TWI
IV 9106-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 9107-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 9109-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 9110-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 9111-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 9112-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 9113-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 9120-B	PXMJ	WBNEQ-CABL-043	EEB-CBL-1.0	
IV 9121-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 9124-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 9125-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 9126-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 9127-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 9128-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 9145-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 9146-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 9147-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
IV 9148-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IV 9149-A	PXMJ	WBNEQ-CABL-043	EEB-CBL-1.0	
IV 9150-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 9155-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 9156-B	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IV 9157-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 9158-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ THI
1V 9163-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 9164-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 9165-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 9166-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 9167-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9168-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9170-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 9171-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 9172-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9173-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9175-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 9176-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 9177-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9178-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9242-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9243-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9244-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9245-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 9246-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 9247-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9360-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
1V 9361-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 9362-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9363-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR59.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAM/ TMI</u>
IV 9549-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 9550-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 9551-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9552-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9553-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9554-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9555-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 9556-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 9560-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 9561-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 9562-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9563-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9564-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9565-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9566-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 9567-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 9569-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 9570-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
IV 9571-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9572-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9573-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9573-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9574-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9575-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAR/ TRI
1V 9576-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 9578-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 9579-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 9580-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 9581-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 9582-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 9583-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 9584-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 9585-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 9587-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 9588-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 9589-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 9590-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 9591-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 9592-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 9593-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 9594-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 9595-A	PXMJ	WBNEQ-CABL-022	EEB-CBL-1.0	
1V 9596-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 9597-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 9598-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 9599-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 9600-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 9601-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
IV 9604-A	PXMJ	WBNEQ-CABL-022	EEB-CBL-1.0	
IV 9605-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IV 9606-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 9607-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 9608-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 9609-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IV 9610-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 9613-A	PXMJ	WBNEQ-CABL-022	EEB-CBL-1.0	
IV 9614-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IV 9615-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 9616-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 9617-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 9618-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IV 9619-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 9622-A	PXMJ	WBNEQ-CABL-022	EEB-CBL-1.0	
IV 9623-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IV 9624-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 9625-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 9626-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 9627-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IV 9628-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 9631-A	PXMJ	WBNEQ-CABL-022	EEB-CBL-1.0	
IV 9632-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IV 9633-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
1V 9635-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 9636-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 9637-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 9639-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9723-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 9724-A	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
1V 9725-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9726-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9727-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9728-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9729-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 9737-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9738-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9739-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9748-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9749-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9750-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9759-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9760-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9761-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9840-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
1V 9841-B	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 9842-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
1V 9843-B	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
IV 9844-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9845-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9846-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 9847-B	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IV 9848-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9849-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 9850-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9851-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9852-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9853-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 9855-B	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IV 9856-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9857-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 9858-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9859-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9860-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9861-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
IV 9863-B	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
IV 9864-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9865-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
IV 9866-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9867-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9868-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
IV 9869-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAN/ TMI</u>
1V 9901-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 9904-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 9905-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 9906-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 9908-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 9909-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 9940-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 9941-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 9942-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 9943-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 9944-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 9945-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 9946-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 9950-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 9951-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 9952-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 9953-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 9954-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 9955-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 9956-A	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 9960-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 9961-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 9962-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 9963-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ TKI
1V 9964-B	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 9965-B	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 9966-B	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 9970-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 9971-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
1V 9972-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
1V 9973-B	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 9974-B	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 9975-B	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
1V 9976-B	SRDAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
2M 2340-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2M 2341-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2M 2346-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2M 2347-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2M 2352-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2M 2353-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2M 2358-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2M 2359-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL 4-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PL 5-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PL2895-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2PL2896-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL2897-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL2899-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ TWI
2PL3071-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL3072-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
2PL3073-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3074-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL3075-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3077-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PL3081-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL3082-B	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
2PL3083-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3084-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL3085-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3087-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PL3091-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2PL3092-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
2PL3093-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL3094-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3096-A	2-TS-30-194A PIGTAIL	WBNEQ-ITS-002	EEB-CBL-1.0	
2PL3098-A	2-TS-30-194B PIGTAIL	WBNEQ-ITS-002	EEB-CBL-1.0	
2PL3101-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL3102-B	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
2PL3103-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3104-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PL3105-B	2-TS-30-195A PIGTAIL	WBNEQ-ITS-002	EEB-CBL-1.0	
2PL3108-B	2-TS-30-195B PIGTAIL	WBNEQ-ITS-002	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR59.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ TNI
2PL3111-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL3112-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
2PL3113-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3114-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3121-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2PL3122-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
2PL3123-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3124-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3131-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL3132-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
2PL3133-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3134-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3135-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3137-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PL3141-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL3142-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
2PL3143-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3144-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL3145-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3147-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PL3201-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL3202-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL3203-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3204-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
 UNIT 1 OPERATION ONLY  
 CABLES REQUIRING QUALIFICATION  
 UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAK/ THI
2PL3205-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3472-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3482-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3490-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3497-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3603-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3613-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3697-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2PL3748-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2PL3749-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3751-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3752-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PL3753-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PL3754-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL3760-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2PL3761-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3763-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3764-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PL3765-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL3766-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL3770-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2PL3774-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL3775-A	PXHJ	WBNEQ-CABL-049	EEB-CBL-1.0	
2PL3776-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
2PL3777-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PL3778-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3785-A	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
2PL3786-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3825-A	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
2PL3826-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3827-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3830-B	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
2PL3868-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2PL3880-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2PL3881-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
2PL3882-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3882-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3905-B	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2PL3906-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3907-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3907-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3913-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2PL3913-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2PL3914-A	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
2PL3920-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL3920-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2PL3920-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2PL3921-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAK/ THI
2PL3921-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PL3921-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3940-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2PL3941-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
2PL3942-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3942-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3960-A	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL3960-A	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2PL3961-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3962-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3980-B	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
2PL3981-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL3982-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3983-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
2PL3991-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PL3995-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL3996-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL4000-A	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
2PL4002-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL4003-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
2PL4011-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL4020-A	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
2PL4021-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL4022-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAK/ TMI
2PL4023-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL4061-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL4071-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL4440-B	CPJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2PL4440-B	PXJ	WBNEQ-CABL-063	EEB-CBL-1.0	
2PL4441-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL4460-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2PL4462-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL4500-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2PL4502-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL4520-A	PXJ	WBNEQ-CABL-063	EEB-CBL-1.0	
2PL4521-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL4733-B	PXJ	WBNEQ-CABL-063	EEB-CBL-1.0	
2PL4734-B	PXJ	WBNEQ-CABL-063	EEB-CBL-1.0	
2PL4737-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PL4738-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PL4739-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PL4895-A	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL4897-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL4975-A	PXJ	WBNEQ-CABL-063	EEB-CBL-1.0	
2PL4976-A	PXJ	WBNEQ-CABL-063	EEB-CBL-1.0	
2PL4978-A	PXJ	WBNEQ-CABL-063	EEB-CBL-1.0	
2PL4979-A	PXJ	WBNEQ-CABL-063	EEB-CBL-1.0	
2PL4982-B	PXJ	WBNEQ-CABL-063	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
2PL4983-B	PXJ	WBNEQ-CABL-063	EEB-CBL-1.0	
2PL4985-B	PXJ	WBNEQ-CABL-063	EEB-CBL-1.0	
2PL4986-B	PXJ	WBNEQ-CABL-063	EEB-CBL-1.0	
2PL5120-A	PXJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL5121-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PL5124-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL5130-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL5131-A	PXMJ	WBNEQ-CABL-049	EEB-CBL-1.0	
2PL5132-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PL5133-A	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PL6705-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PH3320-A	MS	WBNEQ-CABL-017	EEB-CBL-1.0	
2PH3322-A	MS	WBNEQ-CABL-017	EEB-CBL-1.0	
2PH3324-A	MS	WBNEQ-CABL-017	EEB-CBL-1.0	
2PH3330-B	MS	WBNEQ-CABL-017	EEB-CBL-1.0	
2PH3332-B	MS	WBNEQ-CABL-017	EEB-CBL-1.0	
2PH3334-B	MS	WBNEQ-CABL-017	EEB-CBL-1.0	
2PP 444-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PP 445-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PP 447-B	PXMJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2PP 450-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PP 456-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PP 460-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PP 466-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAH/ THI
2PP 606-A	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PP 610-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PP 675-A	EPSJ	WBNEQ-CABL-005	EEB-CBL-1.0	
2PP 675-A	CPSJ	WBNEQ-CABL-033	EEB-CBL-1.0	
2PP 677-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PP 677-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PP 679-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PP 681-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PP 687-A	EPSJ	WBNEQ-CABL-005	EEB-CBL-1.0	
2PP 689-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PP 689-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PP 691-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PP 693-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PP 700-B	EPSJ	WBNEQ-CABL-005	EEB-CBL-1.0	
2PP 700-B	EPSJ	WBNEQ-CABL-005	EEB-CBL-1.0	
2PP 702-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PP 702-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PP 704-B	PXMJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PP 706-B	PXMJ	WBNEQ-CABL-043	EEB-CBL-1.0	
2PP 712-B	EPSJ	WBNEQ-CABL-005	EEB-CBL-1.0	
2PP 712-B	EPSJ	WBNEQ-CABL-005	EEB-CBL-1.0	
2PP 712-B	EPSJ	WBNEQ-CABL-027	EEB-CBL-1.0	
2PP 714-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2PP 714-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAM/ THI
2PP 716-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2PP 718-B	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
2PP 759-A	EPSJ	WBNEQ-CABL-005	EEB-CBL-1.0	
2PP 760-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 862-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 863-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 865-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 868-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
2V 869-B	SROAJ	WBNEQ-CABL-036	EEB-CBL-1.0	
2V 879-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 880-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 1940-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2V 1941-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 1942-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2003-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2020-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2V 2021-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2022-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2023-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2160-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2V 2161-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2162-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2163-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2170-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAM/ TR1</u>
2V 2171-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2172-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2173-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2200-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2V 2201-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2202-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2203-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2208-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2V 2209-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2210-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2211-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2398-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2V 2399-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2399-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2401-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2V 2404-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2V 2405-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2405-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2407-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2V 2600-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2V 2601-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2602-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2603-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2608-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ TRI
2V 2689-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2791-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2V 2792-B	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
2V 2793-B	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2V 2794-B	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
2V 2953-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2955-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2V 2968-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2V 2969-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2971-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 2972-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 3980-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2V 3980-A	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2V 3982-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 3984-A	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
2V 3985-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2V 3988-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2V 3989-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 3990-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 3992-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	
2V 3993-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2V 3995-B	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2V 3996-B	CPJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2V 3997-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	



WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAN/ TRI
2V 3998-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 4000-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 4004-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2V 4005-A	CFJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2V 4005-A	CFJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2V 4007-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 4009-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 4050-B	CFJJ	WBNEQ-CABL-032	EEB-CBL-1.0	
2V 4051-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 4052-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 4054-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 4080-A	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
2V 4081-B	PXNJ	WBNEQ-CABL-043	EEB-CBL-1.0	
2V 6560-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 6561-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 6564-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2V 6565-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2V 6566-A	PXNJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2V 6570-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 6571-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2V 6574-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2V 6575-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2V 6576-A	PXNJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2V 6580-B	PXNJ	WBNEQ-CABL-049	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR50.49

TVA DEVICE ID	DESCRIPTION	BINDER NUMBER	EQS NUMBER	PAK/ THI
2V 6581-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 6584-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2V 6585-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2V 6586-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2V 6590-B	PXHJ	WBNEQ-CABL-049	EEB-CBL-1.0	
2V 6591-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 6594-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2V 6595-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2V 6596-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2V 6600-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 6601-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 6603-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2V 6603-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2V 6604-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 6605-A	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2V 6610-B	PXHJ	WBNEQ-CABL-049	EEB-CBL-1.0	
2V 6611-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 6613-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2V 6613-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2V 6614-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 6615-B	PXHJ	WBNEQ-CABL-003	EEB-CBL-1.0	
2V 6620-B	PXHJ	WBNEQ-CABL-049	EEB-CBL-1.0	
2V 6621-B	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 6622-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	

WATTS BAR NUCLEAR PLANT  
UNIT 1 OPERATION ONLY  
CABLES REQUIRING QUALIFICATION  
UNDER 10CFR59.49

<u>TVA DEVICE ID</u>	<u>DESCRIPTION</u>	<u>BINDER NUMBER</u>	<u>EQS NUMBER</u>	<u>PAN/ TMI</u>
2V 6622-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2V 6623-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2V 6624-B	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2V 6628-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 6629-A	PJJ	WBNEQ-CABL-015	EEB-CBL-1.0	
2V 6630-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2V 6630-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2V 6631-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	
2V 6632-A	PXHJ	WBNEQ-CABL-002	EEB-CBL-1.0	

## VII EQ EQUIPMENT BINDER DOCUMENTATION

All EQ equipment for WBN Unit 1 within the scope of 10CFR50.49 has been evaluated and documented in an EQ binder. This section contains copies of all equipment binders TAB A's and TAB B's which can be used as a reference to review TVA's methods for qualification.

Reference should be made to Section III for a description of TVA's binder concept, how the binders are constructed and information as to their contents.

The following summarizes the TAB A and TAB B contents found in this section:

### (1) TAB A - Identification of Equipment Comprising Equipment Type

This section identifies the equipment within the scope of 10CFR50.49 comprising the equipment type. Equipment is identified by plant ID number, manufacturer, model number, location (or room number), elevation, procurement contract number, safety function, mitigating accident, equipment category, and required operating time.

### (2) TAB B - EQ Checksheets for Evaluation of Environmental Qualification Including Summary and Conclusion

The "heart" of the EQ binder is TAB B, the EQ checksheet forms. These forms provide a format for addressing all salient EQ considerations and documenting the qualification status of 10CFR50.49 equipment.

However, the EQ checksheet forms (TAB B of the EQ binder) are intended only as a tool to assist evaluators in performing qualification evaluations to document the qualification status of certain electrical equipment. This form is not intended to preclude good engineering. The EQ checksheet form is designed to cover explicitly the salient points of EQ, but is not intended to be a totally comprehensive EQ checklist. Evaluators and reviewers are expected to be (or become) familiar with the criteria against which the evaluation is made. Based on a thorough understanding of the criteria, evaluators may feel justified to make defensible assumptions and engineering judgments when any EQ parameter satisfies the "intent" but not the "letter" of the criteria. All assumptions, engineering judgments, and extrapolations of data must have a sound engineering basis and be documented as part of the qualification package (i.e., the EQ binder). In certain situations, evaluators may find it necessary to augment the EQ checksheet form. In short, EQ is not a "cookbook" process.

The individual sections in Tab B of the EQ binder (checksheet form, sections (A through P) may be categorized into three basic parts. First, sections A through N present factual data pertinent to qualification. Provisions are included in sections A through N

(2) Tab B - EQ Checksheets for Evaluation of Environmental Qualification Including Summary and Conclusion (Continued)

for short comments and remarks necessary for clarification, but the primary content is technical data and facts. Second, section O is a checklist of questions and considerations which the evaluator should consider. The checklist is representative of the types of considerations that evaluators could potentially overlook, even with all of the factual data properly documented. Because the checklist cannot be totally comprehensive, evaluators must review the qualification criteria to ensure no significant consideration is overlooked. Third, section P is a summary writeup which is to include any supplemental comments, justifications, short extrapolations of data, and discussion necessary to document that all significant EQ considerations have been addressed. The writeup should be formatted so reviewers can easily ascertain the EQ checksheet sections being supplemented (e.g., each paragraph or comment might be numbered and a note referring the reader to the numbered comment would be included in the EQ checksheet section which the comment supplements). More extensive analysis and justification (e.g., similarity analysis, aging and materials analysis, calculation of qualified life) shall be incorporated in Tab C of the EQ binder.

The overall philosophy of the three basic parts of the checksheet form is that all significant EQ questions and considerations must be addressed. If a significant EQ-related consideration is not a concern, the evaluator should still document the basis for this conclusion.

Tab B further contains the statement confirming determination of qualification in Section B. This confirmation additionally signifies that all documentation required to support qualification and as contained in the binder has been reviewed and approved by TVA, as signified by the sign offs on the binder cover sheet.

BINDER NO. WBNEQ-SOL -001 PLANT WBN UNIT(S) 1 SHEET 1 OF 1  
BINDER TITLE SOLENOID VALVES COMPUTED RL DATE 7/7/86 R     R      
TARGET ROCK - MODELS 79AB-001 CHECKED SS DATE 7/17/86  
AND 79AB-003

TABLE OF CONTENTS

TAB A

EQUIPMENT IDENTIFICATION

Section A-1 - Tab A, Equipment Identification Matrix

EQP357.41

PAGE A-1

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WRMED-SOL -001  
 MANUFACTURER: TARGET ROCK  
 PAGE: 1 OF 1

EQIS NO.	UNIT DEVICE ID NO.			DESCRIPTION	MODEL	LOCATION				CONTRACT#	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
						COLUMN	AZ	ELEV	RM/RAD						
MBN-1-FSV -068-0394	-A	1-FSV -068-0394	-A	REACTOR VESSEL HEAD VENT ISOL VLV	79AB-001					L	71C62-54114-1	L	A	100D	SOLENOID VLV MUST OPERATE TO RELEASE NONCONDENSABLES FROM REACTOR VESSEL HEAD
												MS/C	A	100D	
												FW/C	A	100D	
												RH/C	A	1MD	
												CV/C	A	1MD	
MBN-1-FSV -068-0395	-B	1-FSV -068-0395	-B	REACTOR VESSEL HEAD VENT ISOL VLV	79AB-001					L	71C62-54114-1	L	A	100D	SOLENOID VLV MUST OPERATE TO RELEASE NONCONDENSABLES FROM REACTOR VESSEL HEAD
												MS/C	A	100D	
												FW/C	A	100D	
												RH/C	A	1MD	
												CV/C	A	1MD	
MBN-1-FSV -068-0396	-B	1-FSV -068-0396	-B	REACTOR VESSEL HEAD VENT THROTTLE VLV	79AB-003					L	71C62-54114-1	L	A	100D	SOLENOID VLV MUST OPERATE TO RELEASE NONCONDENSABLES FROM REACTOR VESSEL HEAD
												MS/C	A	100D	
												FW/C	A	100D	
												RH/C	A	1MD	
												CV/C	A	1MD	
MBN-1-FSV -068-0397	-A	1-FSV -068-0397	-A	REACTOR VESSEL HEAD VENT THROTTLE VLV	79AB-003					L	71C62-54114-1	L	A	100D	SOLENOID VLV MUST OPERATE TO RELEASE NONCONDENSABLES FROM REACTOR VESSEL HEAD
												MS/C	A	100D	
												FW/C	A	100D	
												RH/C	A	1MD	
												CV/C	A	1MD	

PAGE A-2

\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE RSP 7/2/86  
 CHECKER/DATE SS 7/10/86

BINDER NO. WBNEQ-SOL -001 PLANT WBN UNIT(S) 1 SHEET 1 OF 1

BINDER TITLE SOLENOID VALVES COMPUTED RSP DATE 7/7/86 R     R    

TARGET ROCK - MODELS 79AB-001 CHECKED CRS DATE 7/10/86  
AND 79AB-003

TABLE OF CONTENTS

TAB B

CHECKLIST FOR EVALUATION OF ENVIRONMENTAL QUALIFICATION

Section B-1 - Qualification Checklist

EQP357.41

PAGE B-1



BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 1 OF 24  
BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 7/15/86 R      R       
TARGET ROCK - MODELS 79AB-001  
AND 79AB-003 CHECKED LSB DATE 7/15/86

A. DOCUMENTATION

Equipment Description Solenoid Valves  
Vendor/Manufacturer Target Rock  
Equipment Model No. (s) 79AB-001  
79AB-003

QUALIFICATION REPORTS

- (1) Title/Number/Revision Equipment Qualification RIMS B45 851205 360  
Data Package/EQDP-HE-10A/Revision 2 DATE January 1985
- (2) Title/Number/Revision Equipment Qualification RIMS B45 851205 364  
Test Report/WCAP-8687, Supp. 2-H10A/Revision 2 DATE January 1985
- (3) Title/Number/Revision Equipment Qualification RIMS B45 851205 359  
Data Package/EQDP-HE-10C/Revision 1 DATE January 1985
- (4) Title/Number/Revision Equipment Qualification RIMS B45 851205 362  
Test Report/WCAP-8687, Supp. 2-H10C/Revision 1 DATE January 1985

OTHER (ANALYSIS, VENDOR DATA, ETC.)

Target Rock Test Report No. 4207 (B71 860616 101) (TAB C, Section C-2)  
Target Rock Letter No. TRC C5815 (B70 851121 004) (TAB C, Section C-1)  
Target Rock Letter No. TRC C5702 (B71 860616 102) (TAB E, Section E-2)  
Target Rock Drawing 79AB-001 (TAB I, Section I-1)  
Target Rock Drawing 79AB-003 (TAB I, Section I-2)  
Target Rock Letter dated May 21, 1986, Rims No. B71 860602 001 with  
attachments (TAB C, Section C-2)

PAGE B-2

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 2 OF 24  
 BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 9/12/86  
TARGET ROCK - MODELS 79AB-001 AND 79AB-003 CHECKED RKw DATE 9/12/86

B. CONCLUSION OF REVIEW (Check only one block)

- Equipment Qualified
- Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule
- Equipment Qualification Not Established by Documentation
- Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES

(1) Voltage supplied during accident conditions is presently being evaluated. (2) Normal neutron dose is presently being evaluated.  
(3) Voltage drop between the 79AB-003 valves and their associated controller will be addressed when (1) is complete.

"Open Item" sheets elaborating on the above are contained at the front of this binder.

COMMENTS/RECOMMENDATIONS Due to the "Open Items" listed in the front of this binder, certain sections of this tab have been intentionally left blank. The following sections will be completed when their associated "Open Item" is resolved.

- 1) Sheet 15, Section J(5)(a): "Accident Voltage"
- 2) Sheet 16, Section K(1)(Radiation): "Normal Neutron Dose"

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 3 OF 24  
 BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 7/7/86 R     R      
TARGET ROCK - MODELS 79AB-001  
AND 79AB-003 CHECKED SSP DATE 7/10/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate All Documents Which are Applicable):

- X   Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)
- Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of IE Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

- IEEE 382-1972 "IEEE Trial Use Guide for Type Test of Class I Electric Valve Operators for Nuclear Power Generating Stations"
- IEEE 323-1974 "IEEE standard for Qualifying Class IE Equipment for Nuclear Power Generating Stations"
- IEEE 344-1975 "Guide for Seismic Qualification of Class IE Electrical Equipment for Nuclear Power Generating Stations"

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 4 OF 24

BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/7/86 R     R    

TARGET ROCK - MODELS 79AB-001  
AND 79AB-003 CHECKED SJ DATE 7/10/86

D. QUALIFICATION METHODOLOGY (Check only one block)

- Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- Test of Similar Items with Supporting Analysis
- Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 5 OF 24

BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/7/86 R     R      
TARGET ROCK - MODELS 79AB-001  
AND 79AB-003 CHECKED AS DATE 7/10/86

**E. EQUIPMENT DESCRIPTION**

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? Yes

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Solenoid Valve</u>	<u>Solenoid Valve</u>	<u>Ref. (2) &amp; (4) Sect. 2.0</u>
(2) Manufacturer	<u>Target Rock</u>	<u>Target Rock</u>	<u>Ref. (2) &amp; (4) Sect. 2.0</u>
(3) Model Number(s)	<u>79AB-001</u>	<u>79AB-001</u>	<u>Sect. 2.0 Ref. (4)</u>
	<u>79AB-003</u>	<u>79AB-003*</u>	<u>Sect. 2.0</u>
(4) Serial Number(s)	<u>See TAB F</u>	<u>55</u>	<u>Sect. 2.0</u>
		<u>Design No. 1032110-4</u>	<u>Ref. (1) Sect. 2.1</u>
		<u>Design No. 1033110-1</u>	<u>Ref. (4) Sect. 2.0</u>
(5) Identify Component-Unique checksheet attached:	<u>None</u>		

JUSTIFICATION/COMMENTS In references (2) and (4), Section 2.0, Westinghouse lists solenoid valve design identification numbers that are considered generically qualified by these reports. The Westinghouse solenoid valve design number (WNEED Tag No.) as specified on the valve drawings contained in TAB I and listed in the aforementioned references are as follows:

<u>Target Rock Model No.</u>	<u>WNEED Tag No.</u>
<u>79AB-001</u>	<u>1IS88RA</u>
<u>79AB-003</u>	<u>1RS78RA</u>

\*The controllers for the Model 79AB-003 modulating valves are located in the Auxiliary Building in a mild environment in the Control Rod Drive Equipment Room, room No. A1.

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 6 OF 24  
 BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/7/86 R     R      
TARGET ROCK - MODELS 79AB-001  
AND 79AB-003 CHECKED SP DATE 7/10/86

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the test report and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below). If yes, enter requirement in QMDS, if No, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement (Yes/No/NA)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>NA</u>	<u>   </u>	<u>   </u>
External	<u>NA</u>	<u>   </u>	<u>   </u>
Process Connections	<u>   </u>	<u>   </u>	<u>   </u>
Electrical	<u>NA</u>	<u>   </u>	<u>   </u>
Connections	<u>   </u>	<u>   </u>	<u>Ref. (2), Sect. 5.8</u>
Conduit Seals	<u>Conax Seal Used</u>	<u>Yes</u>	<u>Ref. (4), Sect. 6.9</u>
Connector	<u>NA</u>	<u>   </u>	<u>   </u>
Seals	<u>   </u>	<u>   </u>	<u>Ref. (1), Sect. 1.2</u>
Orientation	<u>NA</u>	<u>   </u>	<u>Ref. (3), Sect. 1.2</u>
Physical Configuration	<u>NA</u>	<u>   </u>	<u>   </u>
Other	<u>NA</u>	<u>   </u>	<u>   </u>

JUSTIFICATION/COMMENTS Refer to QMDS Section B.1 for Conax seal to be  
used as required by TVA Environmental Qualification Binder No.

WBNEQ-CSC-001.

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 7 OF 24  
 BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 7/16/84  
TARGET ROCK - MODELS 79AB-001 AND 79AB-003 CHECKED SRP/ax DATE 7/16/84

G. TEST SEQUENCE

(1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	Ref. (2) & (4) <u>Sect. 5.3</u>
(b) Baseline performance measurements taken	<u>Yes</u>	Ref. (2) & (4) <u>Sect. 5.3 &amp; Tbl 2</u>
(c) Equipment aged:		Ref. (2), Sect. 5.4.2
Thermal	<u>Yes</u>	Ref. (4), <u>Sect. 5.4</u>
Radiation	<u>Yes</u>	Ref. (2), Sect. 5.5.1 Ref. (4), <u>Sect. 5.5</u>
Wear	<u>Yes</u>	Ref. (2), Sect. 5.4.1 & Sect. 5.4.2 Ref. (4) <u>Sect. 5.4</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	Ref. (2) & (4), <u>Sect. 5.6</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	Ref. (2) & (4), Sections <u>5.7 &amp; 5.8</u>
(f) Post-DBE exposure	<u>Yes</u>	Ref. (2) & (4) <u>Sect. 5.8</u> Ref. (2), Sect. 6.5
(g) Final inspection and disassembly	<u>Yes</u>	Ref. (4), <u>Sect. 5.8</u>

(2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes (See comment on sheet 7A).

(3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? No (See comment on sheet 7B). (Reference Ref. (2) & (4), Table I ).

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 7A OF 24

BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/7/86 R     R      
TARGET ROCK - MODELS 79AB-001  
AND 79AB-003 CHECKED CS DATE 7/10/86

COMMENT FOR SECTION G(2):

Model 79AB-001: 2 reed switches and cover-to-body gasket were repaired  
(Ref. (2), Section 6.5, Pg. 20). Silicone potting around reed switches  
had worked loose due to handling and gasket had been broken during  
disassembly. Switches were repotted and gasket was repaired with RTV  
and the entire solenoid valve was then subjected to the steam/spray  
exposure.

Model 79AB-003: Same valve was used. However, during the HELB  
simulation the LVDT failed and the terminal board shorted to ground.  
These failures were attributed to the fact that the caustic spray/steam  
combination had entered the unsealed conduit connection, since the LVDT  
did not show insulation degradation due to thermal aging, radiation  
aging or cyclic aging. This assumption was proven correct when a new,  
unaged LVDT was installed in the test valve and degraded in the same  
manner, and at an equivalent time into the HELB test, as the fully aged  
LVDT. The second test showed that the degradation was not an aging  
related phenomenon, but rather a result of the HELB test environment  
entering the electrical compartment and attacking the insulation of the  
LVDT. After installation of new LVDT, terminal board, terminal board  
strip marker, cover gasket, and Conax conduit seal to prevent HELB test  
environment intrusion, the test was successfully completed (Ref. (4),  
Sect. 6.9).



BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 7B OF 24  
 BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/15/86 R     R      
 TARGET ROCK - MODELS 79AB-001  
AND 79AB-003 CHECKED SEP DATE 7/15/86

COMMENT FOR SECTION G(3):

A list of instrumentation used in testing is attached to qualification report Ref. (2) as Table I; however, accuracy and calibration are not mentioned. In Ref. (4), Table 1 lists equipment and calibration dates but accuracy is not addressed. Even though Westinghouse failed to provide the aforementioned information, it does not significantly impact the qualification status of the valves in this binder, due to the fact that the qualification tests would still envelop the WBN requirements even if an instrumentation inaccuracy as high as 5% was present during testing.

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 8 OF 24  
 R     R      
 BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/7/86  
 TARGET ROCK - MODELS 79AB-001  
AND 79AB-003 CHECKED CSH DATE 7/14/86

H. AGING

(1) Was aging considered in the qualification program (Yes/no/NA)? Yes  
 (Reference Ref. (2), Sect. 4.1.2 & Ref. (4), Sect. 5.4 ).

(2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>Ref. (2), Sect. 4.1.2 Ref. (4), Sect. 5.4</u>
Radiation exposure	<u>Yes</u>	<u>Ref. (2), Sect. 4.1.3 Ref. (4), Sect. 5.5</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>Ref. (2), &amp; (4), Sect. 5.6.1 Ref. (2), Sect. 5.4.1 Ref. (4), Sect. 5.4</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	<u>Sect. 5.4</u>

(3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? Yes (Reference Ref. (2), Section 5.1 ).

JUSTIFICATION/COMMENTS Ref. (4) did not address synergistic effects, however, since similarity of Model 79AB-001 to Model 79AB-003 is documented by Target Rock Letter No. C5815 (see TAB C, Section C-1, Attachment 6) it is safe to conclude that both model valves would not have any synergistic effects.

(4) Thermal Aging:

(a) Was thermal aging considered in the qualification program (Yes/no/NA)? Yes (Reference Ref. (2), Sect. 5.4.2 & Ref. (4), Sect. 5.4 ).

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 9 OF 24

BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/7/86 R     R      
TARGET ROCK - MODELS 79AB-001  
AND 79AB-003 CHECKED CS DATE 7/10/86

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes\*/No\*\* (Reference: \*Ref. (2), Attachment 3 ).

JUSTIFICATION/COMMENTS \*\*Ref. (4), Sect. 5.4 and 7.3.5.

Value of 0.5 eV was assumed for all valve components.

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference Ref. (2), Sect. 5.4.2 & Ref. (4), Sect. 5.4 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference Ref. (2), Sect. 5.4.2 Ref. (4), Sect. 5.4).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	<u>120°F</u>	<u>325°F</u>	<u>120°F</u>
Time	<u>40 Years</u>	<u>485hrs</u>	<u>6.16 yrs.</u>

JUSTIFICATION/COMMENTS References (2) and (4) state that the thermal aging performed during the tests corresponded to 6.16 years at 120°F assuming an activation energy of 0.5eV. We prove a longer life in TAB C.

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference Ref. (2), Sect. 5.4.2 & Ref. (4), Sect. 5.4 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? No (Reference Ref. (2), Att. 3 & Ref. (4), Sect. 5.4 ).

JUSTIFICATION/COMMENTS Westinghouse conservatively assumed an activation energy of 0.5 eV for all valve materials.

PAGE B-12



BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 11 OF 24  
 BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/7/86 R     R      
 TARGET ROCK - MODELS 79AB-001  
AND 79AB-003 CHECKED SJS DATE 7/10/86

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (yes/no/NA)? Yes (Reference Ref. (2), Sect. 5.7 & Ref. (4), Sect. 5.5 ).

Plant normal ambient radiation dose (rd) 2x10<sup>7</sup> rads  
 \*185 Megarads (Mod. 79AB-001)  
 Test exposure dose (rd) \*205.1 Megarads (Mod. 79AB-003)  
 Test exposure dose rate (rd/hr) 1.46 Mrad/Hr (Mod. 79AB-001)  
.67 & .75 Mrads/Hr (Mod. 79AB-003)  
 Test exposure source type (e.g., Co-60 gamma) Co-60 GAMMA

JUSTIFICATION/COMMENTS The tested values of 185 Mrads and 205.1 Mrads exceed plant TID of 6 x 10<sup>7</sup> rads.  
\*See comment on sheet 11A.

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference Ref. (2) & (4), Sect. 5.6.1 ).  
 (b) Was the basis for vibration aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference Ref. (2), Sect. 3.1.6, 5.6.1, and Fig. 1 Ref. (4), Sect. 3.1.5, 5.6.1, and Fig. 1 ).

JUSTIFICATION/COMMENTS The vibration aging documented in Ref. (2) & (4) is identical to that in IEEE 382-1980. Vibration aging testing provides a vibratory environment which is representative of normal plant-induced vibration. Normal service flow vibration is not significant for the valves in the binder because vessel head venting is performed only during an accident or after refueling.

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference Ref. (2) & (4), Sect. 5.4 ).

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 11A OF 24

BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 7/7/86 R     R      
TARGET ROCK - MODELS 79AB-001  
AND 79AB-003 CHECKED SL DATE 7/10/86

COMMENT FOR SECTION H(5)(d):

Westinghouse, who designed and installed the head vent system, determined the radiation dose rates necessary for qualification of these valves to be  $1.75 \times 10^7$  rads GAMMA for a 40 year TID or a 10 year dose of  $8.76 \times 10^5$  rads GAMMA combined with a 10 year neutron dose of  $3.15 \times 10^{13}$  N/cm<sup>2</sup> (reference (2), Att. 2, page 49). The test enveloped the requirement in that it consisted of both a 40 year TID of  $1.85 \times 10^8$  rads GAMMA and a 10 year Neutron dose of  $3.52 \times 10^{13}$  N/cm<sup>2</sup>.

PAGE B-15

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 12 OF 24

BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/15/86 R     R      
TARGET ROCK - MODELS 79AB-001  
AND 79AB-003 CHECKED SSP DATE 7/15/86

H. AGING (Continued)

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference Ref. (2) & (4), Sects. 3.4. & 5.4).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (yes/no/NA)? Yes  
(Reference Ref. (2), Sect. 5.4.2 & Ref. (4), Sect. 5.4 ).

Qualified life (Document in QMDS) 40 years \*

JUSTIFICATION/COMMENTS \*Providing the elastomers are changed at intervals specified in the QMDS. Westinghouse conservatively qualified the valves for 6.16 years. We have extended elastomer life to 17.3 years using the rationale listed in TAB C.

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (yes/no/NA)? Yes  
(Reference Ref. (2), Sect. 6.5 & Ref. (4), Sect. 6.9, p 23 ).

Replacement Intervals (Document in QMDS) See TAB C and QMDS (TAB G).

JUSTIFICATION/COMMENTS The tests qualify the complete valves for 6.16 years based on a very conservative activation energy of 0.5 eV. We prove a longer qualified life in TAB C, of the binder. Also, Section 6.5 of Reference (2) and Section 6.9 of Reference (4) require the cover gasket to be replaced every time it is disturbed or the cover is removed.

PAGE B-16

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 13 OF 24

BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/7/86 R     R    

TARGET ROCK - MODELS 79AB-001 CHECKED LS DATE 7/10/91  
AND 79AB-003

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of EQC Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>Class H Insulation/ Solenoid Assy. &amp; LVDT</u>	<u>NA</u>	<u>   </u>	<u>See Below</u>	<u>Ref. (2), Att. 3 Ref. (4), Sect. 5.4 TRC Letter C5815</u>
(b) <u>Silicone Rubber (RTV)/ Seal/Potting</u>	<u>NA</u>	<u>   </u>	<u>See Below</u>	<u>Ref. (2), Att. 3 Ref. (4), Sect. 5.4</u>
(c) <u>Silicone Rubber/Gasket</u>	<u>NA</u>	<u>   </u>	<u>See Below</u>	<u>Ref. (2), Att. 3 Ref. (4), Sect. 5.4</u>
(d) <u>Silicone Rubber/O-Ring</u>	<u>NA</u>	<u>   </u>	<u>See Below</u>	<u>Ref. (2), Att. 3 Ref. (4), Sect. 5.4</u>
(e) <u>GP Phenolic/Term. Board</u>	<u>NA</u>	<u>   </u>	<u>See Below</u>	<u>Ref. (2), Att. 3 Ref. (4), Sect. 5.4</u>

JUSTIFICATION/COMMENTS Although Reference 4 does not provide a detailed  
list of the materials of construction, Target Rock Letter No. TRC C5815  
(see Attachment 6, TAB C, Section C-1) states that the materials of  
construction are the same for Models 79AB-001 and 79AB-003 except for  
the LVDT which is contained only in the Model 79AB-003 valve. The  
LVDT in the Model 79AB-003 valve is constructed of Class H insulation  
which is listed above. Also, it should be noted that in the above  
references, Westinghouse assigned a conservative value of 0.5 eV to  
the entire valve. Refer to TAB C, Section C-1, Attachments 1 and 3.



BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 14 OF 24

BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 7/7/86 R     R      
TARGET ROCK - MODELS 79AB-001  
AND 79AB-003 CHECKED LS DATE 7/10/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference Ref. (2) & (4), Sect. 5.1 ).

Identify Acceptance Criteria: Valve model 79AB-001 must shift position under all postulated conditions at maximum and minimum differential pressure upon application of 90-140 VDC power and shift to closed position when power is removed. Valve model 79AB-003 must position proportionally to a 4-20 mA signal corresponding to fully closed and open and with either a loss of power or a signal from the controller return to fully closed and remain closed at any value between the maximum and minimum pressure differential. Position indication must indicate valve states under all conditions.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference Ref. (2) & (4), Sect. 5.3 ).

Identify baseline and functional testing: Hydrostatic proof tests, seat leakage test, operational performance test, insulation and solenoid resistance tests.

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes (Reference Ref. (2), Sect. 4.1.6, 5.7, 5.8, & 6.5 & Ref. (4) Sect. 4.1.6, 5.7, 5.8, & 6.9 ).

JUSTIFICATION/COMMENTS The valves were connected to high pressure lines and cycled under pressure throughout the DBE, thermal aging, cyclic aging, and vibration aging exposures.

- (4) Do the applied loads during baseline testing reflect normal operating conditions (yes/no/NA)? Yes (Reference Ref. (2) & (4), Sect. 5.3 )

JUSTIFICATION/COMMENTS Model 79AB-001: Voltage was varied from 55-140 VDC. Valve was under process pressure of 2485 psig. Model 79AB-003: Valve was cycled via controller from fully closed (4mA input to controller) to fully opened (20 mA) while valve was under process pressure of 2500 psig.

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 15 OF 24  
 R     R      
 BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/7/86  
TARGET ROCK - MODELS 79AB-001  
AND 79AB-003 CHECKED cup DATE 7/13/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

(5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) <u>Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference</u>
Voltage	_____	_____
Load	_____	_____
Frequency	_____	_____
Accuracy	_____	_____
<u>Other(s)</u>	_____	_____
_____	_____	_____
_____	_____	_____

JUSTIFICATION/COMMENTS See "Open Items" sheets in the front of the binder.

(b) <u>Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>
Voltage	<u>90-140-VDC</u>	<u>Ref. (1)&amp;(3)</u> <u>Sect. 1.1.1,</u> <u>Ref. (4)</u> <u>Sect. 5.8</u>
Load	<u>NA</u>	<u>Ref. (1)&amp;(3)</u> <u>Sect. 1.1.3</u>
Frequency	<u>NA</u>	<u>Ref. (1)&amp;(3)</u> <u>Sect. 1.1.2</u>
Accuracy	<u>NA</u>	_____
<u>Other(s)</u>	_____	_____
_____	<u>NA</u>	_____
_____	_____	_____

JUSTIFICATION/COMMENTS See comment on sheet 15A.

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 15A OF 24

BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/7/86 R     R    

TARGET ROCK - MODELS 79AB-001

AND 79AB-003 CHECKED YB DATE 7/10/86

COMMENT FOR SECTION J(5)(b):

The conditions listed were demonstrated during functional testing. In  
reference (2) Westinghouse did not stipulate specific voltages at which the  
valve operated under the simulated accident conditions.

In Reference (4) Westinghouse stated that the valve was cycled during the HELB  
simulation utilizing a voltage of 90 VDC.

See TAB C, Section C-2 "ACCIDENT VOLTAGE VS OPERATION" for justification of  
operation under supplied voltage during an accident.

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 16 OF 24  
 BINDER TITLE SOLENOID VALVES - COMPUTED RJR DATE 9/5/86 R     R      
TARGET ROCK - MODELS 79AB-001  
AND 79AB-003 CHECKED SPP/AWT DATE 9/8/86

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-42 R2

(1) Normal Max	(2) Abnormal Max
(a) Temperature (°F) <u>120</u>	(a) Temperature (°F) <u>130</u>
(b) Pressure (psia) <u>14.7</u>	(b) Pressure (psia) <u>14.7</u>
(c) Humidity (%) <u>80</u>	(c) Humidity (%) <u>100</u>
(d) Radiation (rd) <u>2x10<sup>7</sup> TID</u>	(d) Radiation (rd) <u>N/A</u>

(3) Process Interfaces: The temperature of the process fluid dead-headed against the Model 79AB-001 valves could be the only interface with a significant impact. Since the process fluid is non-condensable gases, which would cool to ambient temperature by the time it reaches the valves through over 50 feet of one inch pipe, it is safe to conclude that the process fluid temperature would have no detrimental effect on the valves.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Will occur less than 1% of plant life and could exist for up to 8 hours per excursion.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) <u>327</u>	Accident type <u>LOCA/HELB</u>
(b) Pressure (psia) <u>25.6</u>	Accident type <u>LOCA/HELB</u>
(c) Humidity (%) <u>100</u>	Accident type <u>LOCA/HELB</u>
(d) Radiation (rd) <u>7.4x10<sup>7</sup> (BETA)*</u> <u>2.8x10<sup>7</sup> (GAMMA)*</u>	Accident type <u>LOCA/HELB</u>
(e) Spray Type <u>2000 ppm Boron</u> <u>pH 8.3</u>	Accident type <u>LOCA/HELB</u>

\* See comment on Sheet 18A.

PAGE B-21

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 17 OF 24  
 BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 9/5/86 R     R      
TARGET ROCK - MODELS 79AB-001  
AND 79AB-003 CHECKED SRP/AWT DATE 9/8/86

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.):

The duration of the containment spray is 30 days. Containment spray  
flow rate is equal to 9500 Gal/Min or 0.92 GPM per square foot of  
containment cross section.

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (yes/no/NA)? Yes (Reference See comment on sheet 17A ).

(7) Subject to submergence (yes/no/NA)? No (Reference Dwg. 47E235-42 R2).

Identify initiation time and duration of submergence: Following an  
accident inside primary containment, only those valves below elevation  
722' are subject to submergence. All valves in this binder are above  
that elevation.

(8) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 17A OF 24

BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/7/86 R     R      
TARGET ROCK - MODELS 79AB-001

AND 79AB-003 CHECKED LSP DATE 7/11/86

COMMENTS FOR SECTION K(6):

All valves in this binder have Conax conduit seals installed. Refer to  
QMDS Section B.1 (Binder TAB G) for Conax seal to be used as required by  
TVA Environmental Qualification Binder No. WBNEQ-CSC-001.

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 18 OF 24  
 BINDER TITLE SOLENOID VALVES - COMPUTED RJR DATE 9/5/86 R     R      
 TARGET ROCK - MODELS 79AB-001  
AND 79AB-003 CHECKED SRP/AWT DATE 9/8/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100 Days</u>	<u>30 Days</u>	<u>Ref. (2) &amp; (4), Sect. 5.8</u> <u>Ref. (2), Sect. 5.8 &amp; Fig. 16</u>
Temperature (°F)	<u>327°F</u>	<u>435°F(79AB-001) 500°F(79AB-003)</u>	<u>Ref. (4), Fig. 15</u> <u>Ref. (1), Tbl 1, p 16,</u>
Pressure (psig)	<u>25.6 psia (11.2 psig)</u>	<u>57 psig (79AB-001) 70 psig (79AB-003)</u>	<u>Ref. (3), Tbl. 1 p 14</u> <u>Ref. (1) &amp; (3), Tbl. 1</u>
Relative Humidity (%)	<u>100%</u>	<u>100%</u>	<u>Ref. (2), Sect. 3.3.1 &amp; 5.8</u> <u>Ref. (4), Sects. 3.3.2.2 &amp; 5.8</u>
*Chemical Spray	<u>2000ppm Boron pH 8.3; .92 GPM/Ft. 2.30Days</u>	<u>2500ppm Boron pH 10.5; .15 GPM/Ft. 2.23 Hrs. 1.85x10<sup>8</sup> rads (79AB-001)</u>	<u>Ref. (1) &amp; (3) Tbl.1, Ref.(2) &amp; (4) Att. 1&amp;Sec 5.7</u>
**Radiation (rd)	<u>1.22x10<sup>8</sup> rads (BETA/GAMMA)</u>	<u>2.05x10<sup>8</sup> rads (79AB-003)</u>	
Submergence	<u>N/A</u>	<u>None</u>	<u>N/A</u>

\*Includes spray concentration, flowrate, density, duration, and pH.  
 \*\*Enter 40-year integrated normal dose plus integrated accident dose and specify type. See comment on sheet 18A.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>See (1) Above</u>
Pressure	<u>Yes</u>	<u>See (1) Above</u>
Relative Humidity	<u>Yes</u>	<u>See (1) Above</u>
Chemical Spray	<u>Yes</u>	<u>See comment on sheet 18B</u>
Submergence	<u>PAGE B-24 N/A</u>	<u>N/A</u>

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 18 OF 24  
BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 7/17/86  
TARGET ROCK - MODELS 79AB-001 AND 79AB-003 CHECKED SRP/STK DATE 7/17/86

COMMENTS FOR SECTION L(1) (RADIATION):

OE Calculation WBNNAL3-004 (B45 860205 235) references the use of OE Calculation  
TI-RPS-48 R2 (B45 851105 235) for all accident radiation doses (BETA and GAMMA)  
inside containment at Watts Bar Nuclear Plant. The 100-day accident radiation  
doses given by OE Calculation TI-RPS-48 R2 are  $4.7 \times 10^8$  rads BETA and  $2.8 \times 10^7$   
rads GAMMA.

Post-DBA BETA Radiation must be addressed for all equipment located inside  
containment which is required for LOCA mitigation. The valves in this binder  
are within that scope. All non-metallic parts of these solenoid valves are  
enclosed by metal and the minimum metal thickness is the cover, which is .048"  
thick (18 ga) 300-series stainless steel. OE Calculation GENNAL3-002R3  
(B45 860423 235) "Reduction of Beta Dose by Sheet Steel," page 3.1, shows the  
beta reduction factor for 18-gauge steel is equal to .158. This reduces the  
total 100-day BETA dose to the valve internal parts to  $(4.7 \times 10^8) \times (1.58 \times 10^{-1})$   
 $7.4 \times 10^7$  rads TID BETA.

In the Lower Compartment, the total combined 100-day BETA and GAMMA accident  
radiation dose will equal  $(7.4 \times 10^7 \text{ BETA}) + (2.8 \times 10^7 \text{ GAMMA}) = 1.02 \times 10^8$  rads. The  
combined 100-day accident radiation plus the 40-year dose ( $2 \times 10^7$  rads) equal a  
total radiation dose of  $1.22 \times 10^8$  rads (BETA/GAMMA). These Target Rock valves are  
qualified to  $1.85 \times 10^8$  rads for the Model 79AB-001 valves and  $2.05 \times 10^8$  rads for the  
Model 79AB-003 valves, which envelop the requirement.

PAGE B-25



BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 18B OF 24  
BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 9/5/86 R     R      
TARGET ROCK - MODELS 79AB-001  
AND 79AB-003 CHECKED SRP/NWT DATE 9/8/86

COMMENTS FOR SECTION L(1) AND (2) (CHEMICAL SPRAY):

Containment spray flow rate is equal to 9500 gal/min or 0.92 GPM per square foot  
of containment cross section. The chemical spray concentration is 2000 ppm  
Boron with a pH of 8.3. The test valve was subjected to a spray solution of  
2500 ppm Boron with a pH of 10.5. The spray rate was 0.15 GPM per square foot  
of projected area of the test valve. The test solution is more corrosive than  
the containment spray. Therefore, all valves listed in this binder fall within  
the qualification provided by the test valve. Additionally, these valves have  
gasketed covers and are not susceptible to spray. This was demonstrated by the  
23 hour spray test. Since spray or leakage intrusion is not acknowledged to be  
time dependent in enclosed devices, it can be concluded that the device is  
qualified for 30 days in spray based on the 23 hour test.

PAGE B-26

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 19 OF 24  
 BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 9/5/86 R     R      
 TARGET ROCK - MODELS 79AB-001  
AND 79AB-003 CHECKED SRP/ANT DATE 9/18/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, yes/no/NA)

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
(Mod. 79AB-001/Mod. 79AB-003)		
Temperature: +15 degrees F	<u>&gt; 15°F</u>	<u>Yes</u>
Pressure: +10% but no more than 10 psig	<u>+45.8 psig/ +58.8 psig</u>	<u>Yes</u>
Radiation: +10% of accident dose	<u>+51%/+67%</u>	<u>Yes</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>See Comment Below</u>	<u>No</u>
Voltage: +10% of rated value	<u>+12 to -56%/ +12 to -28%</u>	<u>Yes</u>
Frequency: +5% of rated value	<u>NA/NA</u>	<u>NA</u>
Environmental Transient: the initial transient and the peak temperature applied twice	<u>+108°F/+173°F</u>	<u>Yes</u>
(Seismic) Vibration: +10% added to acceleration	<u>Ref. (2) &amp; (4), Sect. 5.6.3</u>	<u>Yes</u>

JUSTIFICATION/COMMENTS: See TAB C, Section C-2, which proves the 30-day test envelops the 100-day post-accident requirement.

Voltage variations were applied during testing ranging from 55 VDC minimum to 140 VDC maximum (Model 79AB-001) and 90 VDC minimum to 140 VDC maximum (Model 79AB-003).

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 20 OF 24

BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/7/86  
TARGET ROCK - MODELS 79AB-001 CHECKED WJ DATE 7/11/86

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:  
(Reference See TAB A ).

JUSTIFICATION/COMMENTS Solenoids must operate to release non-  
condensables from reactor vessel head.

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes  
(Reference Ref. (2), Sect. 6.5 & Ref. (4), Sect. 7.2 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? Yes  
(Reference Ref. (2), Sect. 6.5 & Ref. (4), Sect. 6.9 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? No (Reference \_\_\_\_\_ ).

JUSTIFICATION/COMMENTS See TAB C, Section C-2, "Post-Accident  
Operability"

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? Yes  
(Reference Ref. (2), Sect. 7.2 & Ref. (4), Sect. 6.9 ).

JUSTIFICATION/COMMENTS We have reviewed and concur with the  
disposition of anomalies in the test report. There is no impact  
on installed equipment.

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 21 OF 24

BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/7/86 R     R      
TARGET ROCK - MODELS 79AB-001

AND 79AB-003 CHECKED LSP DATE 7/10/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS (Ref. (1) & (3), Section 1.4).

See QMDS (TAB G).

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 22 OF 24

BINDER TITLE SOLENOID VALVES - COMPUTED RSL DATE 7/7/86 R     R      
TARGET ROCK - MODELS 79AB-001 CHECKED SP DATE 7/12/86 R     R      
AND 79AB-003

0. SUMMARY OF REVIEW

Yes/No/NA

- (1) Documented evidence of qualification adequate  
(Have all assumptions, mathematical models, and  
all extrapolations of test data used in an  
analysis been justified and documented)? Yes
- (2) Any exceptions (i.e., sound reasons to the contrary)  
taken to the specified qualification level  
adequately justified? N/A
- (3) Choice of qualification methodology adequately  
justified? Yes
- (4) If analysis was performed, complete the following:
  - (a) Were equipment performance requirements  
identified? N/A
  - (b) Were specific features and failure modes and  
effects analyzed? N/A
  - (c) Were assumptions and mathematical models used  
together with appropriate justification for  
their use? N/A
  - (d) Were environmental parameters which affect  
equipment performance identified? N/A
- (5) Adequate similarity between equipment and test  
specimen established? Yes
- (6) Aging degradation evaluated adequately? Yes
  - (a) Mechanical and/or cycle aging addressed? Yes
  - (b) Equipment aged to end of life condition prior to  
application of DBE conditions? Yes
  - (c) Absence of preaging in test/analysis justified? N/A
  - (d) Materials susceptible to thermal/radiation  
aging identified? Yes

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 23 OF 24

BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/7/86 R     R    

TARGET ROCK - MODELS 79AB-001

AND 79AB-003 CHECKED SP DATE 7/10/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>Yes</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>Yes</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>Yes</u>
(11) Criteria regarding submergence satisfied?	<u>N/A</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

PAGE B-31

BINDER NO. WBNEQ-SOL-001 PLANT WBN UNIT(S) 1 SHEET 24 OF 24  
 BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 7/7/86  
 TARGET ROCK - MODELS 79AB-001 AND 79AB-003 CHECKED LS DATE 7/15/86

O. SUMMARY OF REVIEW (Continued)

Yes/No/NA

- (15) Criteria regarding functional testing satisfied? Yes
- (a) Does the test plan/report specify an acceptance criteria for equipment performed? Yes
- (b) Was an initial base line test done to establish required performance characteristics? Yes
- (c) Has the test/analysis demonstrated that performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? Yes
- (16) Criteria regarding instrument accuracy satisfied? N/A
- (17) Test duration margin (1 hour + function time) satisfied? Yes
- (a) Is the minimum specified operating time at least 1 hour? Yes
- (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided? N/A
- (18) Criteria regarding synergistic effects satisfied? Yes
- (19) Criteria regarding margins satisfied? Yes
- (20) Maintenance and surveillance requirements adequately identified? Yes

P. DISCUSSION

---



---



---



---



---

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WBNED-SOL-002  
 MANUFACTURER: TARGET ROCK  
 PAGE: 1 OF 5

EGIS NO.	UNIT DEVICE TO NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV** RM/RAD					
WBN-1-FCV-001-0007	-B 1-FCV-001-0007	-B S61 BLOWDOWN FLOW SOL VALVE	B2AB-001	SVR		745' A01	B2K22-832045	MS/V FW/V	A/B A/B	* /1000 5MIN/1000	MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED TO ISOLATE STEAM GENERATOR
WBN-1-FCV-001-0014	-A 1-FCV-001-0014	-A S62 BLOWDOWN FLOW SOL VALVE	B2AB-001	SVR		745' A01	B2K22-832045	MS/V FW/V	A/B A/B	* /1000 5MIN/1000	MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED TO ISOLATE STEAM GENERATOR
WBN-1-FCV-001-0025	-B 1-FCV-001-0025	-B S63 BLOWDOWN FLOW SOL VALVE	B2AB-001	SVR		745' A01	B2K22-832045	MS/V FW/V	A/B A/B	* /1000 5MIN/1000	MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED TO ISOLATE STEAM GENERATOR
WBN-1-FCV-001-0032	-A 1-FCV-001-0032	-A S64 BLOWDOWN FLOW SOL VALVE	B2AB-001	SVR		745' A01	B2K22-832045	MS/V FW/V	A/B A/B	* /1000 5MIN/1000	MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED TO ISOLATE STEAM GENERATOR
WBN-1-FCV-001-0181	-A 1-FCV-001-0181	-A S61 BLOWDOWN ISLN VALVE INSIDE CONTMT	B2AB-001		350	736' L	B2K22-832045	L MS/C FW/C RH/C CV/C	A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1HR 1HR/1MO	MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED TO ISOLATE CONTAINMENT
WBN-1-FCV-001-0182	-B 1-FCV-001-0182	-B S62 BLOWDOWN ISLN VALVE INSIDE CONTMT	B2AB-001		013	736' L	B2K22-832045	L MS/C FW/C RH/C CV/C	A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1HR 1HR/1MO	MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED TO ISOLATE CONTAINMENT
WBN-1-FCV-001-0183	-A 1-FCV-001-0183	-A S63 BLOWDOWN ISLN VALVE INSIDE CONTMT	B2AB-001		009	733' 6" L	B2K22-832045	L MS/C FW/C RH/C CV/C	A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1HR 1HR/1MO	MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED TO ISOLATE CONTAINMENT

PAGE A-1

\* SEE APPENDIX I TO THIS TAB.

\*\* ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION DATA SHEETS AND FOUND IN TAB F.

R \_\_\_\_\_ R \_\_\_\_\_ R \_\_\_\_\_

PREPARED/DATE RJP 9/9/86  
 CHECKER/DATE RK 9/10/86



TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. W2NEQ-SGL -002  
 MANUFACTURER: TARGET ROCK  
 PAGE: 2 OF 5

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV** RM/RAD					
WRN-1-FCV -001-0184	-B 1-FCV -001-0184	-B 564 BLOWDOWN ISLN VALVE INSIDE CNTMNT	82AB-001	350	736'	6" L	82K22-832045	L MS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/100D 5MIN/100D 5MIN/100D 15MIN/1HR 1HR/1MD	MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED TO ISOLATE CONTAINMENT
WRN-1-FSV -030-0134	-B 1-FSV -030-0134	-B CNTMNT ANNULUS DP ISLN VALVE	77J-001	291	740'	L	77K3-821270	L MS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/100D 5MIN/100D 5MIN/100D 15MIN/1HR 1HR/1MD	MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED TO ISOLATE CONTAINMENT
WRN-1-FSV -030-0135	-A 1-FSV -030-0135	-A CNTMNT ANNULUS DP ISLN VALVE	77J-001	288	742'	ANN	77K3-821270	L MS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/100D 5MIN/100D 5MIN/100D 15MIN/1HR 1HR/1MD	MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED TO ISOLATE CONTAINMENT
WRN-1-FSV -043-0250	-A 1-FSV -043-0250	-A POST ACD SMPLE HOT LEG NO.1 ISLN VALVE	82KK-001	285	729'	6" ANN	82K29-830702	L MS/C FW/C RH/C CV/C	A A A A A	100D 100D 100D 1MD 1MD	MUST OPERATE DURING OR AFTER ACCIDENT TO OBTAIN SAMPLES
WRN-1-FSV -043-0251	-A 1-FSV -043-0251	-A POST ACD SMPLE HOT LEG NO.1 ISLN VALVE	82KK-001	297	723'	6" L	82K29-830702	L MS/C FW/C RH/C CV/C	A A A A A	100D 100D 100D 1MD 1MD	MUST OPERATE DURING OR AFTER ACCIDENT TO OBTAIN SAMPLES

PAGE A-2

\* SEE APPENDIX 1 TO THIS TAB.

\*\* ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION DATA SHEETS AND FOUND IN TAB F.

PREPARED BY DATE RJP 9/9/86  
 CHECKER/DATE R.T. [Signature]

R \_\_\_\_\_ R \_\_\_\_\_ R \_\_\_\_\_

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. MWNEO-SOL -002  
 MANUFACTURER: TARGET ROCK  
 PAGE: 3 OF 5

EDIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION				CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV**	RM/RAD					
MBN-1-FSV -043-0268	-A 1-FSV -043-0268	-A POST ACD SMPLG RAD WASTE ISLN VALVE	B2KK-001			727' 2"	A6	B2K29-830702	L CV/A AF/A AB/A RH/A	A B B B B	1000 1MO 1MO 1MO 1MO	MUST OPERATE DURING OR AFTER ACCIDENT TO OBTAIN SAMPLES
MBN-1-FSV -043-0287	-A 1-FSV -043-0287	-A POST ACD SMPLG AIR ISLN VALVE	B2KK-002		304	732'	ANN	B2K29-830702	L MS/C FW/C RH/C CV/C	A A A A A	1000 1000 1000 1MO 1MO	MUST OPERATE DURING OR AFTER ACCIDENT TO OBTAIN SAMPLES
MBN-1-FSV -043-0288	-A 1-FSV -043-0288	-A POST ACD SMPLG CNTMNT AIR ISLN VLV	B2KK-002		305	722'	L	B2K29-830702	L MS/C FW/C RH/C CV/C	A A A A A	1000 1000 1000 1MO 1MO	MUST OPERATE DURING OR AFTER ACCIDENT TO OBTAIN SAMPLES
MBN-1-FSV -043-0307	-A 1-FSV -043-0307	-A POST ACD SMPLG AIR ISLN VALVE	B2KK-002		300	732'	B* ANN	B2K29-830702	L MS/C FW/C RH/C CV/C	A A A A A	1000 1000 1000 1MO 1MO	MUST OPERATE DURING OR AFTER ACCIDENT TO OBTAIN SAMPLES
MBN-1-FSV -043-0309	-B 1-FSV -043-0309	-B POST ACD SMPLG HOT LEG NO.3 ISLN VALVE	B2KK-001		252	729'	2* ANN	B2K29-830702	L MS/C FW/C RH/C CV/C	A A A A A	1000 1000 1000 1MO 1MO	MUST OPERATE DURING OR AFTER ACCIDENT TO OBTAIN SAMPLES

PAGE A-3

\* SEE APPENDIX I TO THIS TAB.

\*\* ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION DATA SHEETS AND FOUND IN TAB F.

PREPARED/DATE

CHECKER/DATE

RSP 9/9/86  
 RK 10/1/86

R \_\_\_\_\_ R \_\_\_\_\_ R \_\_\_\_\_

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WRNEQ-SOL-002  
 MANUFACTURER: TARGET RUCK  
 PAGE: 4 OF 5

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV** RH/RAD					
WBN-1-FSV -043-0310	-B 1-FSV -043-0310	-B POST ACD SMPLE HOT LEG NO.3 ISLN VALVE	82KK-001	237	719'	8° L	82K29-830702	L	A	1000	MUST OPERATE DURING OR AFTER ACCIDENT TO OBTAIN SAMPLES
								MS/C	A	1000	
								FW/C	A	1000	
								RH/C	A	1MO	
							CV/C	A	1MO		
WBN-1-FSV -043-0312	-B 1-FSV -043-0312	-B POST ACD SMPLE REAC CNTMNT SUMP ISLN VLV	82KK-001		718'	3° A28	82K29-830702	L	A	1000	MUST OPERATE DURING OR AFTER LOCA TO OBTAIN SAMPLES
								CV/A	B	1MO	
								AF/A	B	1MO	
								AB/A	B	1MO	
							RH/A	B	1MO		
WBN-1-FSV -043-0318	-B 1-FSV -043-0318	-B POST ACD SMPLE CNTMNT AIR ISLN VLV	82KK-002	280	734'	ANN	82K29-830702	L	A	1000	MUST OPERATE DURING OR AFTER ACCIDENT TO OBTAIN SAMPLES
								MS/C	A	1000	
								FW/C	A	1000	
								RH/C	A	1MO	
							CV/C	A	1MO		
WBN-1-FSV -043-0319	-B 1-FSV -043-0319	-B POST ACD SMPLE CNTMNT AIR ISLN VLV	82KK-002	292	719'	8° L	82K29-830702	L	A	1000	MUST OPERATE DURING OR AFTER ACCIDENT TO OBTAIN SAMPLES
								MS/C	A	1000	
								FW/C	A	1000	
								RH/C	A	1MO	
							CV/C	A	1MO		
WBN-1-FSV -043-0325	-B 1-FSV -043-0325	-B POST ACD SMPLE CNTMNT AIR ISLN VLV	82KK-002	282	722'	ANN	82K29-830702	L	A	1000	MUST OPERATE DURING OR AFTER ACCIDENT TO OBTAIN SAMPLES
								MS/C	A	1000	
								FW/C	A	1000	
								RH/C	A	1MO	
							CV/C	A	1MO		

PAGE A-4

\* SEE APPENDIX 1 TO THIS TAB.

\*\* ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION DATA SHEETS AND FOUND IN TAB F.

PREPARED/DATE RSP 9/9/86 R \_ \_ R \_ \_  
 CHECKER/DATE RKCC/9/10/86 \_ \_ \_ \_ \_

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. W8NEQ-SDL -002  
 MANUFACTURER: TARGET ROCK  
 PAGE: 5 OF 5

EDIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV**					
WBN-1-FSV -043-0341	-B 1-FSV -043-0341	-B POST ACD SHPL6 DR TO CNTMNT SUMP ISLN VLV	82KX-004	282	724	ANN	82K29-830702	L	A	1000	MUST OPERATE DURING OR AFTER ACCIDENT TO EMPTY PAS WASTE HOLDUP TANK
								MS/C	A	1000	
								FW/C	A	1000	
								RH/C	A	1MO	
								CV/C	A	1MO	
WBN-1-FSV -043-0342	-A 1-FSV -043-0342	-A POST ACD SHPL6 DR TO CNTMNT SUMP ISLN VLV	82KX-004	300	731	ANN	82K29-830702	L	A	1000	MUST OPERATE DURING OR AFTER ACCIDENT TO EMPTY PAS WASTE HOLDUP TANK
								MS/C	A	1000	
								FW/C	A	1000	
								RH/C	A	1MO	
								CV/C	A	1MO	
WBN-1-PCV -068-0334	-B 1-PCV -068-0334	-B RCS PRZR PWR RELIEF VALVE	82UU-001	100	786	L	82K22-831934	L	A	1000	PRZR VNTNG PURPOSES.MUST OPERATE UNTIL RCS IS SUFF GPRZD THEN REMAIN CLOSED
								MS/C	A	1000	
								FW/C	A	1000	
								RH/C	A	1MO	
								CV/C	A	1MO	
WBN-1-PCV -068-0340A	-A 1-PCV -068-0340A	-A RCS PRZR PWR RELIEF VALVE	82UU-001	100	786	L	82K22-831934	L	A	1000	PRZR VNTNG PURPOSES.MUST OPERATE UNTIL RCS IS SUFF GPRZD THEN REMIAN CLOSED
								MS/C	A	1000	
								FW/C	A	1000	
								RH/C	A	1MO	
								CV/C	A	1MO	

PAGE A-5

\* SEE APPENDIX I TO THIS TAB.

\*\* ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION DATA SHEETS AND FOUND IN TAB F.

R \_\_\_\_\_ R \_\_\_\_\_ R \_\_\_\_\_

PREPARED/DATE RSP 9/9/86  
 CHECKER/DATE Rueda 9/11/86

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 1 OF 1  
 BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 8/27/86 R     R      
TARGET ROCK CHECKED WJK DATE 8/29/86

TAB A  
APPENDIX I

The operating time for this valve is dependent upon the size of the Main Steam Line Break inside the South Valve Room. During a large break (1.4 ft<sup>2</sup>), this valve must operate for no more than 12.7 seconds after receipt of the safety injection signal. During a small break (0.4 ft<sup>2</sup>), this valve must operate for no more than 195.9 seconds after receipt of the safety injection signal.

See TAB C, Section C-2, Group III valves, for further information.

Reference: OE Calculation WBNOSG4-003, RIMS No. B45 851112 218.

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 1 OF 26  
BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 8/27/86  
TARGET ROCK CHECKED WPK DATE 8/27/86

A. DOCUMENTATION

Equipment Description Solenoid Valves  
Vendor/Manufacturer Target Rock Corporation  
Equipment Model No.(s) 82AB-001, 77J-001, 82KK-001, 82KK-002,  
82KK-004, 82UU-001

QUALIFICATION REPORTS

- (1) Title/Number/Revision Qualification Test RIMS EEB831003510  
Report/2375/G DATE 5-3-83
- (2) Title/Number/Revision Qualification Extension RIMS EEB830324501  
Analysis/3543 DATE 1-10-83
- (3) Title/Number/Revision Qualification Extension RIMS EEB830215500  
Analysis/3563 DATE 1-10-83
- (4) Title/Number/Revision Qualification Extension RIMS EEB840130501  
Analysis/3619/A DATE 12-13-83
- (5) Title/Number/Revision Analysis Report/ RIMS B71860611101  
557-1468/A DATE 11-2-83

OTHER (ANALYSIS, VENDOR DATA, ETC.) \_\_\_\_\_

Target Rock Letter No. C5631 (B43 850913 001) (TAB D, Section D-1)  
Target Rock Test Report No. 4207 (B71 860616 101) (TAB C, Section C-1)  
TVA Memorandum dated 12-24-85 (B46 851224 002) (TAB C, Section C-2)  
Target Rock Letter No. C5702 (B71 860616 102) (TAB E, Section E-2)

(Continued on Sheet 1A)

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 2 OF 26  
 BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 9/16/86 R     R      
TARGET ROCK CHECKED RZW DATE 9/14/86

B. CONCLUSION OF REVIEW (Check only one block)

- Equipment Qualified
- Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule
- Equipment Qualification Not Established by Documentation
- Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES \_\_\_\_\_

(1) Voltage supplied during accident conditions is presently being evaluated. (2) A conduit seal for Target Rock, Valve 1-FSV-30-134 is required. (3) Flowing media radiation dose effects on inline solenoid valves are presently being evaluated. "Open Item" sheets elaborating on the above are contained at the front of this binder.

COMMENTS/RECOMMENDATIONS Due to the "Open Items" listed in the front of this binder, certain sections of this tab have been intentionally left blank. The following section will be completed when its associated "Open Item" is resolved.

- 1) Sheet 15, Section J(5)(a): "Accident Voltage"

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 1A OF 26  
BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 8/27/86 R     R      
TARGET ROCK CHECKED WPK DATE 8/27/86

OE Calculation WBNOSG4-004 (B45 860418 218) "Main Steam System (1)

NUREG 0588 Category and Operating Times"

OE Calculation WBNOSG4-008 (B45 860320 224) "Containment Ventilation

System (30) NUREG 0588 Category and Operating Times"

OE Calculation WBNOSG4-011 (B45 860314 218) "Sampling System (43)

NUREG 0588 Category and Operating Times"

OE Calculation WBNOSG4-017 (B45 860326 219) "Reactor Coolant System

(68) NUREG 0588 Category and Operating Times"

OE Calculation WBNOSG4-045 (B45 860221 218) "Status and Duty Cycles

of 1E Solenoid Valves Located in Potentially Harsh Environments"

\_\_\_\_\_

\_\_\_\_\_



BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 3 OF 26  
 BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 8/27/86 R     R      
TARGET ROCK CHECKED WAK DATE 8/27/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

  X   Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)

       Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE 382-1972 "IEEE Trial Use Guide for Type Test of Class I  
Electric Valve Operators for Nuclear Power  
Generating Stations"

IEEE 323-1974 "IEEE Standard for Qualifying Class IE Equipment for  
Nuclear Power Generating Stations"

IEEE 344-1975 "Guide for Seismic Qualification for Class IE  
Electrical Equipment for Nuclear Power Generating  
Stations"

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 4 OF 26  
 BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 8/27/86  
TARGET ROCK CHECKED WJK DATE 8/27/86

D. QUALIFICATION METHODOLOGY (Check only one block)

       Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis

  X   Test of Similar Items with Supporting Analysis

       Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions

       Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS Target Rock Report No. 2375 is a type test for Target Rock Solenoid Operated valves. All Target Rock valves listed in this binder are qualified by analysis or comparison to the test valve in the 2375 report. All valves listed in TAB A use the same/similar materials, details of construction, and design features as the tested Model 77CC-001. Target Rock certifies this similarity by their Qualification Extension Analyses Nos. 3543, 3563, and 3619, all of which are in TAB D.

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 5 OF 26  
 BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 8/21/86 R      R       
TARGET ROCK CHECKED WBS/K DATE 8/21/86

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? No

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Solenoid Vlv</u>	<u>Solenoid Vlv</u>	<u>2375, Sec. 1.0</u>
(2) Manufacturer	<u>Target Rock</u>	<u>Target Rock</u>	<u>2375, Sec. 1.0</u>
(3) Model Number(s)	<u>See TAB A</u>	<u>77CC-001</u>	<u>Sec. 1.0</u>
	<u>                    </u>	<u>                    </u>	<u>                    </u>
	<u>                    </u>	<u>                    </u>	<u>                    </u>
(4) Serial Number(s)	<u>See TAB F</u>	<u>                    </u>	<u>                    </u>
	<u>                    </u>	<u>                    </u>	<u>                    </u>
	<u>                    </u>	<u>                    </u>	<u>                    </u>
(5) Identify Component- Unique checksheet attached:	<u>None</u>	<u>                    </u>	<u>                    </u>

JUSTIFICATION/COMMENTS

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the test report and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if No, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>None Specified</u>	<u>N/A</u>	<u>                    </u>
External Process Connections	<u>None Specified</u>	<u>N/A</u>	<u>                    </u>
Electrical Connections	<u>None Specified</u>	<u>N/A</u>	<u>                    </u>
Conduit Seals	<u>Rubber Cement Sealing Used at Conduit Conn.</u>	<u>No</u>	<u>2375 Sec. 4.1.15</u>
Connector Seals	<u>None Specified</u>	<u>N/A</u>	<u>                    </u>
Orientation	<u>None Specified</u>	<u>N/A</u>	<u>                    </u>
Physical Configuration	<u>None Specified</u>	<u>N/A</u>	<u>                    </u>
Other	<u>N/A</u>	<u>                    </u>	<u>                    </u>

JUSTIFICATION/COMMENTS Rubber cement sealing compound was used during qualification testing to seal the test instrumentation wires at the conduit connection. During the course of the test, this sealing compound shrivelled and pulled away, completely opening the switch compartment to the borated water spray. Although the test valve remained operational throughout the test, valves subject to borated water spray will be sealed with a qualified Conax conduit seal in accordance with TVA Environmental Qualification Binder No. WBNEQ-CSC-001.

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 7 OF 26

BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 8/27/86

TARGET ROCK CHECKED WTK DATE 8/29/86

G. TEST SEQUENCE

(1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	<u>2375</u> <u>Sec. 4.1.1</u> <u>2375</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>Sec. 4.1.1</u>
(c) Equipment aged:		<u>2375 App.A</u>
Thermal	<u>Yes</u>	<u>Sec. 4.1.1</u> <u>2375</u>
Radiation	<u>Yes</u>	<u>Sec. 4.1.2 &amp; 4.1.11</u> <u>2375, App.A</u>
Wear	<u>Yes</u>	<u>Sec. 4.2</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>2375, App.A</u> <u>Sec. 4.3</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	<u>2375, Sec. 4.1.9 &amp; App. A</u> <u>Sec. 4.4</u>
(f) Post-DBE exposure	<u>Yes</u>	<u>2375 Sec. 4.1.10</u> <u>&amp; App. A Sec. 4.4.8</u>
(g) Final inspection and disassembly	<u>Yes</u>	<u>2375 Sec. 4.1.15</u> <u>&amp; App. E</u>

(2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes

(3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes  
(Reference 2375, App.A, Sec.2.0 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 8 OF 26  
 BINDER TITLE SOLENOID VALVES - COMPUTED RJR DATE 8/27/86  
TARGET ROCK CHECKED WJK DATE 8/27/86

H. AGING

(1) Was aging considered in the qualification program  
 (Yes/no/NA)? Yes (Reference 2375, App.A, Sec.4.1 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_

(2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>2375 App. A Sec.4.1.1</u>
Radiation exposure	<u>Yes</u>	<u>2375 Sec.4.1.2</u>
Vibration (non-seismic) aging	<u>No</u>	<u>2375 App. A</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	<u>Sec. 4.2</u>

JUSTIFICATION/COMMENTS See Item 1 under "Discussion" on sheet 25.

(3) Were all known synergistic effects which are believed to have a  
 significant effect on equipment performance considered in the aging  
 program (yes/no/NA)? No (Reference \_\_\_\_\_ ).

JUSTIFICATION/COMMENTS See comment on sheet 8A.  
 \_\_\_\_\_

(4) Thermal Aging:

(a) Was thermal aging considered in the qualification program  
 (yes/no/NA)? Yes (Reference 2375, App.A, Sec.4.1.1).

JUSTIFICATION/COMMENTS \_\_\_\_\_

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 8A OF 26  
BINDER TITLE SOLENOID VALVES - COMPUTED RK DATE 8/27/86 R     R      
TARGET ROCK CHECKED WPK DATE 8/27/86

COMMENT FOR H(3):

Target Rock did not address synergistic effects in Test Report 2375. However,  
it is apparent that Target Rock solenoid valves contain materials in which  
radiation-induced synergisms, even though mild, could occur. Silicone rubber  
(per NUREG/CR-2763) and ethylene propylene rubber (per NUREG/CR-2157) exhibit  
insignificant dose rate effects at doses up to 20 Mrad. The worst case 40-year  
TID for the valves in this binder is 20 Mrad. Therefore, synergistic effects  
will be negligible for normal service aging. Also, potential dose rate and  
test sequence synergisms will not impact qualification for accident conditions  
as demonstrated by 2375. In the event an accident occurs, dose rates will be  
comparable to test conditions. Therefore the test sequence of thermal aging  
followed by aging plus accident radiation is a reasonable simulation of actual  
plant requirements. Additional assurance is provided by the severity of the  
radiation test because the specimen was exposed to 135 Mrads, whereas a worst  
case actual dose of 122 Mrads is required.

PAGE B-10

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 9 OF 26  
 BINDER TITLE SOLENOID VALVES - COMPUTED RS DATE 8/27/86  
TARGET ROCK CHECKED WJK DATE 8/27/86

H. AGING (Continued)

(b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes  
 (Reference: 2375, App.F-IC, Para. 3 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_

(c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference 2375, App.F-I, Para. 3 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_

(d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference 2375, App.F, Sec. 4.4 ).

Parameter	Plant Maximum Normal	Test	Equivalent
Temperature	<u>130 F (worst case)</u>	<u>350 F</u>	<u>120 F</u>
Time	<u>40 years</u>	<u>792</u>	<u>40 yrs.</u>

JUSTIFICATION/COMMENTS See Qualified Life Calculations in

TAB C.

(e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference 2375, App.F-I, Para. 3 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_

(f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? Yes  
 (Reference 2375, App.F-IC, Para. 3 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_





BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 11 OF 26  
 BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 8/27/86 R     R      
TARGET ROCK CHECKED WPK DATE 8/27/86

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (yes/no/NA)? Yes (Reference 2375, App. F-I, Para. 2 & App. C ).

Plant normal ambient radiation dose (rd) <sup>7</sup> 2.0x10 rads (worst case)  
 Test exposure dose (rd) <sup>8</sup> 1.35x10 rads  
 Test exposure dose rate (rd/hr) .45MRADS/HR. - Post-DBE  
Not Specified - Pre Aging  
 Test exposure source type (e.g., Co-60 gamma) Co-60 gamma - Post-DBE  
Not Specified - Pre-Aging

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? No (Reference \_\_\_\_\_ ).

JUSTIFICATION/COMMENTS See item 1 under "Discussion" on  
sheet 25.

- (b) Was the basis for vibration aging identified and justified in the qualification program (yes/no/NA)? No (Reference \_\_\_\_\_ ).

JUSTIFICATION/COMMENTS See item 1 under "Discussion" on  
sheet 25.

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference 2375, App. A, Sec. 4.2, App. F, Sec. 4.6 and App. F-IC, Para. 4. ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_

BINDER NO. WBNEQ-SOL-002 PLANT \_\_\_\_\_ WBN \_\_\_\_\_ UNIT(S) 1 SHEET 12 OF 26  
 BINDER TITLE SOLENOID VALVES - COMPUTED RS DATE 8/27/86 R \_\_\_\_\_ R \_\_\_\_\_  
TARGET ROCK CHECKED WPK DATE 8/27/86

H. AGING (Continued)

(b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference 2375, App. A, Sec. 4.2 and App. F-IC, Para. 4).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_

(8) Was the qualified life of the equipment and its basis defined in the qualification program (yes/no/NA)? Yes (Reference 2375, App. F-IB, Para. 3 ).

Qualified life (Document in QMDS) 40 years

JUSTIFICATION/COMMENTS Parameters are defined (see Ref.) but actual life is determined by qualified life calculations (see TAB C)

(9) Were replacement intervals for the equipment or its components defined in the qualification program (yes/no/NA)? Yes (Reference 3543, 3563 & 3619 ).

Replacement Intervals (Document in QMDS) See QMDS.

JUSTIFICATION/COMMENTS In Qualification Extension Analysis Reports 3543, 3563, and 3619 (see TAB D) Target Rock recommends replacement of all silicone rubber O-rings and gaskets every five years. However, our calculations, which are based on the Target Rock test parameters project a longer life. See TAB C.

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 13 OF 26  
 BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 9/9/86 R     R      
TARGET ROCK CHECKED RW DATE 9/9/86

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of EQC Binder for Detailed Materials Analysis)

	<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a)	<u>Silicone rubber/sealing/potting</u>	<u>   </u>	<u>   </u>	<u>1.14</u>	<u>577-1468, Sec. 5.2.13</u>
(b)	<u>EPR/O-Ring</u>	<u>   </u>	<u>   </u>	<u>0.95</u>	<u>557-1468, Sec. 5.2.5</u>
(c)	<u>*Upper Sol Hsg. Compon.</u>	<u>   </u>	<u>   </u>	<u>0.98</u>	<u>Tbl. III</u>
(d)	<u>*Coil Assembly</u>	<u>   </u>	<u>   </u>	<u>1.05</u>	<u>557-1468, Tbl. III</u>

JUSTIFICATION/COMMENTS In Test Report 2375 Target Rock defined the most temperature sensitive material as silicone rubber with an assigned activation energy of 0.61 eV. However, Target Rock later had National Technical Systems perform a materials analysis on a randomly selected solenoid valve to determine the parameters for the accelerated aging of the materials to a state of degradation equivalent to that incurred in normal service. We have listed above, and will use, the activation energies founded by NTS in the referenced report for all life calculations performed for the valves in this binder (see TAB C).

\*The activation energy listed for the upper solenoid housing components and the coil assembly is the lowest activation energy of all materials of their respective subcomponents.

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 14 OF 26  
 BINDER TITLE SOLENOID VALVES - COMPUTED RJR DATE 8/22/86 R     R      
TARGET ROCK CHECKED WPK DATE 8/21/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference 2375, App. G, p. 18 ).

Identify Acceptance Criteria: Valve must operate at minimum 60 Vac and maximum 144 Vac. Allowable seat leakage must not exceed 0.4cc/12 min. Position indicators, when applicable, must satisfactorily indicate when valve is cycled.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference 2375, App. G ).

Identify baseline and functional testing: See (1) above

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes (Reference 2375, App. A, Sec. 4.4 ).

JUSTIFICATION/COMMENTS The valve was connected to high pressure lines and cycled under pressure throughout the DBE, thermal aging, and cyclic aging exposure.

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 15 OF 26  
 BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 8/27/86  
TARGET ROCK CHECKED WPK DATE 8/27/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

(4) Do the applied loads during baseline testing reflect normal operating conditions (yes/no/NA)? Yes (Reference 2375, App. B).

JUSTIFICATION/COMMENTS Voltage was varied from 60-144 Vac. Valve was under process pressure of 2485 psig.

(5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) <u>Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference</u>
Voltage	_____	_____
Load	_____	_____
Frequency	_____	_____
Accuracy	_____	_____
<u>Other(s)</u>	_____	_____
_____	_____	_____
_____	_____	_____

JUSTIFICATION/COMMENTS See "Open Item" sheet in the front of this binder.

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 16 OF 26  
 R     R    

BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 8/27/86

TARGET ROCK CHECKED WMAK DATE 8/29/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

<u>(5)(b) Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>
Voltage	<u>60-144 VAC</u>	<u>2375, App B</u>
Load	<u>2485 psig</u>	<u>2375, App B</u>
Frequency	<u>60 Hz</u>	<u>2375, App B</u>
Accuracy	<u>NA</u>	<u>                  </u>
<u>Other(s)</u>		
<u>                  </u>	<u>NA</u>	<u>                  </u>
<u>                  </u>		<u>                  </u>

JUSTIFICATION/COMMENTS The tested valve successfully completed pre-DBE simulation functional testing at voltages ranging from 60 VAC minimum to 144 VAC maximum. However, during the DBE simulation test, the valve was cycled using 120 VAC only. See TAB C for justification of valve operation under supplied voltage during accident conditions.

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 17 OF 26  
 BINDER TITLE SOLENOID VALVES - COMPUTED RJR DATE 9/9/86 R     R      
TARGET ROCK CHECKED RJC DATE 9/9/86

K. REQUIRED OPERATING ENVIRONMENT

47E235-61 R1, 47E235-44 R1, 47E235-76 R3

Reference Environmental Drawing No. 47E235-42 R2 (worst case)

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F)	<u>130°F</u>	(a) Temperature (°F)	<u>140°F</u>
(b) Pressure (psia)	<u>14.4psia</u>	(b) Pressure (psia)	<u>14.4psia</u>
(c) Humidity (%)	<u>80%</u>	(c) Humidity (%)	<u>100%</u>
(d) Radiation (rd)	<u>2X10<sup>7</sup> RADS; 40 yr TID(worst case)</u>	(d) Radiation (rd)	<u>N/A</u>

(3) Process Interfaces: See TAB C for addressing of appropriate process interfaces.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Will occur less than 1% of plant life and could exist for up to 8 hours per excursion.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F)	<u>327°F</u>	Accident type	<u>LOCA/HELB</u>
(b) Pressure (psia)	<u>25.6 psia</u>	Accident type	<u>LOCA/HELB</u>
(c) Humidity (%)	<u>100%</u>	Accident type	<u>LOCA/HELB</u>
(d) Radiation (rd)	<u>7.4x10<sup>7</sup> rads(beta)* 2.8x10<sup>7</sup> rads(gamma)*</u>	Accident type	<u>LOCA</u>
(e) Spray Type	<u>2000ppm Boron pH 8.3</u>	Accident type	<u>LOCA/HELB</u>

\*See comment on Sheet 19A.



BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 18 OF 26  
 BINDER TITLE SOLENOID VALVES - COMPUTED RJP DATE 9/16/86 R     R      
TARGET ROCK CHECKED RW DATE 9/16/86

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.):

The duration of the containment spray is 30 days. Containment spray flow rate is equal to 9500 gal/min or 0.92 gpm per square foot of containment cross section.

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (yes/no/NA)? Yes (Reference See Sec.P2."Discussion" ).
- (7) Subject to submergence (yes/no/NA)? No  
 (Reference TVA Environmental Dwg 47E235-42 R2 ).

Identify initiation time and duration of submergence: See Justification Comments on Sheet 19.

8) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
<u>OE Calculation WBNNAL3-004</u> <u>"Accident Dose Inside</u> <u>Reactor Building"</u>	<u>B45 860205 235</u>
<u>OE Calculation TI-RPS-48</u> <u>"Integrated Accident Dose</u> <u>Inside Primary Containment"</u>	<u>B45 851105 235</u>
<u>OE Calculation GENNAL3-002</u> <u>"Reduction of Beta Dose by</u> <u>Sheet Metal"</u>	<u>B45 860423 235</u>
<u>OE Calculation WBNOSG4-003</u> <u>"Safety Evaluation of Superheated</u> <u>Steam in the Valve Vaults Caused</u> <u>by a Main Steam Line Break"</u>	<u>B45 851112 218</u>
<u>OE Calculation WBNNAL6-004</u> <u>"Flooding Levels in the North</u> <u>and South Valve Vaults"</u>	<u>B45 860116 235</u>
<u>OE Calculation WBNNAL3-025</u> <u>"Normal Operation Dose for</u> <u>Equipment Qualification Outside</u> <u>the Shield Building"</u>	<u>B45 860401 235</u>
<u>OE Calculation WBNOSG4-045 R1</u> <u>"Status and Duty Cycles of</u> <u>Valves Located in Potentially</u> <u>Harsh Environments"</u>	<u>B45 860902 219</u>

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 19 OF 26  
 BINDER TITLE SOLENOID VALVES - COMPUTED RJR DATE 9/9/86 R     R      
TARGET ROCK CHECKED RJW DATE 9/9/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100 Days</u>	<u>14 Days</u>	<u>2375, App. A</u> <u>Sec. 4.4.6</u>
Temperature (°F)	<u>327°F</u>	<u>385°F</u>	<u>2375, App. A</u> <u>Sec. 4.4.2</u>
Pressure (psig)	<u>25.6 psia</u> <u>(11.2 psig)</u>	<u>66 psig</u>	<u>2375, App. A</u> <u>Sec. 4.4.2</u>
Relative Humidity (%)	<u>100%</u>	<u>100%</u>	<u>2375, App. A</u> <u>Sec. 4.4.2</u>
*Chemical Spray	<u>2000 ppm</u> <u>Boron (H<sub>2</sub>BO<sub>3</sub>)</u> <u>pH 8.3</u>	<u>6200 ppm</u> <u>Boron (H<sub>2</sub>BO<sub>3</sub>)</u> <u>pH 8.6-10.0</u>	<u>2375,</u> <u>App. A,</u> <u>Sec. 4.4.2</u>
**Radiation (rd)	<u>1.22x10<sup>8</sup> rads</u> <u>(beta/gamma)</u>	<u>1.35x10<sup>8</sup> rads</u> <u>gamma</u>	<u>2375, App. C</u>
Submergence	<u>NA</u>	<u>NA</u>	<u>***</u>

\*Includes spray concentration, flowrate, density, duration, and pH.

\*\*Enter 40-year integrated normal dose plus integrated accident dose and specify type. See comment on Sheet 19A.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile</u> <u>Envelopes Specified</u> <u>(Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>See (1) Above</u>
Pressure	<u>Yes</u>	<u>See (1) Above</u>
Relative Humidity	<u>Yes</u>	<u>See (1) Above</u> <u>See Sec.</u>
Chemical Spray	<u>Yes</u>	<u>P. 3</u>
Submergence	<u>NA</u>	<u>***</u>

JUSTIFICATION/COMMENTS \*\*\*Equipment located inside containment inside the crane wall below elevation 722 (surge level) could become submerged following an accident. Outside the crane wall, the steady state flood level is 717.7'. All valves listed in this binder are located outside the crane wall and none are located below these levels. Therefore, no valves in this binder are subject to submergence.

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 19A OF 26  
BINDER TITLE SOLENOID VALVES - COMPUTED RJL DATE 8/27/86 R     R      
TARGET ROCK CHECKED WJK DATE 8/27/86

COMMENTS FOR SECTION L(1) (RADIATION):

OE Calculation WBNNAL3-004 (B45 860205 235) references the use of OE Calculation  
TI-RPS-48 R2 (B45 851105 235) for all accident radiation doses (BETA and GAMMA)  
inside containment at Watts Bar Nuclear Plant. The 100-day accident radiation  
doses given by OE Calculation TI-RPS-48 R2 are  $4.7 \times 10^8$  rads BETA and  $2.8 \times 10^7$   
rads GAMMA.

Post-DBA BETA Radiation must be addressed for all equipment located inside  
containment which is required for LOCA mitigation. The valves listed in TAB C,  
Section C-1 (I) & (II) are within that scope. All non-metallic parts of these  
solenoid valves are contained in a .048" thick (18ga) 300-series stainless  
steel metal enclosure. OE Calculation GENNAL3-002 R3 (B45 860423 235)  
"Reduction of Beta Dose by Sheet Steel," page 3.1, shows the beta reduction  
factor for 18-gauge steel is equal to .158. This reduces the total 100-day  
BETA dose to the valve internal parts to  $(4.7 \times 10^8) \times (1.58 \times 10^{-1}) = 7.4 \times 10^7$  rads TID  
rads TID BETA.

In the Lower Compartment, the total combined 100-day BETA and GAMMA accident  
radiation dose will equal  $(7.4 \times 10^7 \text{ BETA}) + (2.8 \times 10^7 \text{ GAMMA}) = 1.02 \times 10^8$  rads. The  
combined 100-day accident radiation plus the 40-year dose ( $2 \times 10^7$  rads) equal a  
total radiation dose of  $1.22 \times 10^8$  rads (BETA/GAMMA). The Target Rock valves  
contained in this binder are qualified to  $1.35 \times 10^8$  rads, which envelops the  
requirement.

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 20 OF 26  
 BINDER TITLE SOLENOID VALVES - COMPUTED RJR DATE 9/9/86 R     R      
TARGET ROCK CHECKED RJW DATE 9/9/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

(3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, yes/no/NA)

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	<u>+58°F</u>	<u>Yes</u>
Pressure: +10% but no more than 10 psig	<u>+54.8 psig</u>	<u>Yes</u>
Radiation: +10% of accident dose	<u>+10%</u>	<u>Yes</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>See Below</u>	<u>No</u>
Voltage: +10% of rated value	<u>Later</u>	<u>   </u>
Frequency: +5% of rated value	<u>N/A</u>	<u>N/A</u>
Environmental Transient: the initial transient and the peak temperature applied twice	<u>   </u>	<u>Yes</u>
Vibration: +10% added to acceleration	<u>2375, APP. A Sec. 4.3.2</u>	<u>Yes</u>

JUSTIFICATION/COMMENTS: See TAB C, Sections C-1 and C-2, which proves the 14-day test envelops the 100-day post-accident requirement.  
Voltage variations were applied during testing ranging from 60V ac minimum to 144V ac maximum.

BINDER NO. WBNEQ-SOL-002 PLANT \_\_\_\_\_ WBN \_\_\_\_\_ UNIT(S) 1 SHEET 21 OF 26  
BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 8/27/86 R \_\_\_\_\_ R \_\_\_\_\_  
TARGET ROCK CHECKED WJK DATE 8/29/86 \_\_\_\_\_

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:  
(Reference See TAB A ).

JUSTIFICATION/COMMENTS Functions are varied. All are listed  
in TAB A.

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes  
(Reference 2375, Sec. 2.0 & App. A, 5.3 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? Yes  
(Reference 2375, Sec. 2.0 & App. A, 5.3 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? Yes (Reference 2375, Sec. 2.0 & App. A, 4.4 ).

JUSTIFICATION/COMMENTS See TAB C, Sections C-1 and C-2, "Post-  
Accident Life"

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? Yes  
(Reference 2375, Sec. 2.0/4.1.10 ).

JUSTIFICATION/COMMENTS The test anomaly addressed in Sec. 4.1.10  
relative to relay contacts, applies only to the model 77J-001  
valves in this binder, since they are the only valves herein  
having relays. The relays failed to make contact due to surface  
corrosion but functioned properly after they were polished.  
Target Rock did not address the cause of the relay contact corrosion.  
However, after reviewing the test report it is reasonable to deduce  
that moisture entered the test valve during accident simulation  
via an unsealed conduit entry to cause the damage. The model 77J-  
001 valves in this binder, which are subject to moisture  
intrusion, are equipped with Conax conduit seals to prevent such  
intrusion, and therefore, prevent the aforementioned anomaly.



0. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
(1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
(2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>N/A</u>
(3) Choice of qualification methodology adequately justified?	<u>Yes</u>
(4) If analysis was performed, complete the following:	
(a) Were equipment performance requirements identified?	<u>N/A</u>
(b) Were specific features and failure modes and effects analyzed?	<u>N/A</u>
(c) Were assumptions and mathematical models used together with appropriate justification for their use?	<u>N/A</u>
(d) Were environmental parameters which affect equipment performance identified?	<u>N/A</u>
(5) Adequate similarity between equipment and test specimen established?	<u>Yes</u>
(6) Aging degradation evaluated adequately?	<u>Yes</u>
(a) Mechanical and/or cycle aging addressed?	<u>Yes</u>
(b) Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes</u>
(c) Absence of preaging in test/analysis justified?	<u>N/A</u>
(d) Materials susceptible to thermal/radiation aging identified?	<u>Yes</u>

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 24 OF 26  
 BINDER TITLE SOLENOID VALVES - COMPUTED RJ DATE 8/27/86 R     R      
TARGET ROCK CHECKED WJK DATE 8/29/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>Yes</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>Yes</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>Yes</u>
(11) Criteria regarding submergence satisfied?	<u>Yes</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>



BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 25 OF 26  
 BINDER TITLE SOLENOID VALVES - COMPUTED RSP DATE 8/27/86 R     R      
TARGET ROCK CHECKED NBK DATE 8/29/86

O. SUMMARY OF REVIEW (Continued)

- |  | <u>Yes/No/NA</u> |
|--|------------------|
| (15) Criteria regarding functional testing satisfied?  | <u>Yes</u>       |
| (a) Does the test plan/report specify an acceptance criteria for equipment performed?  | <u>Yes</u>       |
| (b) Was an initial base line test done to establish required performance characteristics?  | <u>Yes</u>       |
| (c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? | <u>Yes</u>       |
| (16) Criteria regarding instrument accuracy satisfied?   | <u>Yes</u>       |
| (17) Test duration margin (1 hour + function time) satisfied?  | <u>Yes</u>       |
| (a) Is the minimum specified operating time at least 1 hour?   | <u>Yes</u>       |
| (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided?  | <u>N/A</u>       |
| (18) Criteria regarding synergistic effects satisfied?   | <u>N/A</u>       |
| (19) Criteria regarding margins satisfied?   | <u>Yes</u>       |
| (20) Maintenance and surveillance requirements adequately identified?  | <u>Yes</u>       |

P. DISCUSSION

1. Non-seismic vibration aging (sec. H.(6)). Non-seismic vibration aging was not performed as required by IEEE 323-1974. This does not affect the qualification of the tested or installed valves for the following reasons:

\_\_\_\_\_

\_\_\_\_\_

BINDER NO. WBNEQ-SOL-002 PLANT WBN UNIT(S) 1 SHEET 26 OF 26  
BINDER TITLE SOLENOID VALVES - COMPUTED RSL DATE 8/27/86  
TARGET ROCK CHECKED WKR DATE 8/28/86

P. DISCUSSION (Continued)

(A) There were no test anomalies associated with the seismic portion of the qualification testing.

(B) Non-seismic vibration aging is not a recognized problem for solenoid valves. Other solenoid valves, including some Target Rock models, have been subjected to this type testing with no discrepancies noted.

(C) Periodic maintenance and surveillance activities will detect any problems which would result from the effects of non-seismic vibration aging.

2. Moisture or liquid intrusion (Sec.K (6)).

The valves requiring protection from moisture or liquid intrusion have had Conax conduit seals installed and are identified in Section 1 of the QMDS, which is located in TAB G of the binder.

3. Chemical Spray (Sec. L (1) & (2)).

The containment spray flow rate is equal to 9500 gal/min or 0.92 gpm per square foot of containment cross section. The chemical spray concentration is 2000ppm boron with a pH of 8.35. The Target Rock test valve was subjected to a spray solution of 6200ppm boron and 50ppm hydrazine with a pH of 8.6-10.0. The spray rate was 0.15 gpm per square foot of projected area of the test valve. The test solution is more corrosive than the containment spray. Therefore, all valves listed in this binder fall within the qualification provided by the test valve.

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WBNED-SOL -003  
 MANUFACTURER: ASCO  
 PAGE: 1 OF 20

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION				CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*	RH/RAD					
WBN-1-FSV -001-0006A	-A 1-PSV -001-0006A	-A S61 MAIN STEAM HDR FWR RELIEF CNTL VLV	X206-381-3RF	SVR		729'	A01	80KJ3-827551	FW/V	A/B	5MIN/100D	MUST DEENERGIZE AND REMAIN DEENERGIZED TO PREVENT SECONDARY SIDE PORV OPENING
WBN-1-PSV -001-0006B	-A 1-PSV -001-0006B	-A S61 MAIN STEAM HDR FWR RELIEF CNTL VLV	X206-381-3RF	SVR		729'	A01	80KJ3-827551	FW/V	A	100D	MUST ENERGIZE TO ASSURE SECONDARY SIDE PORV CLOSURE
WBN-1-PSV -001-0013A	-B 1-PSV -001-0013A	-B S62 MAIN STEAM HDR PRESS RLF CNTL VLV	X206-381-3RF	NVR		729'	A02	80KJ3-827551	FW/V	A/B	5MIN/100D	MUST DEENERGIZE AND REMAIN DEENERGIZED TO PREVENT SECONDARY SIDE PORV OPENING
WBN-1-PSV -001-0013B	-B 1-PSV -001-0013B	-B S62 MAIN STEAM HDR PRESS RLF CNTL VLV	X206-381-3RF	NVR/XA2		729'	A02	80KJ3-827551	FW/V	A	100D	MUST ENERGIZE TO ASSURE SECONDARY SIDE PORV CLOSURE
WBN-1-PSV -001-0024A	-A 1-PSV -001-0024A	-A S63 MAIN STEAM HDR PRESS RLF CNTL VLV	X206-381-3RF	NVR		729'	A02	80KJ3-827551	FW/V	A/B	5MIN/100D	MUST DEENERGIZE AND REMAIN DEENERGIZED TO PREVENT SECONDARY SIDE PORV OPENING
WBN-1-PSV -001-0024B	-A 1-PSV -001-0024B	-A S63 MAIN STEAM HDR PRESS RLF CNTL VLV	X206-381-3RF	NVR/XA2		729'	A02	80KJ3-827551	FW/V	A	100D	MUST ENERGIZE TO ASSURE SECONDARY SIDE PORV CLOSURE
WBN-1-PSV -001-0031A	-B 1-PSV -001-0031A	-B S64 MAIN STEAM HDR PRESS RLF CNTL VLV	X206-381-3RF	SVR		729'	A01	80KJ3-827551	FW/V	A/B	5MIN/100D	MUST DEENERGIZE AND REMAIN DEENERGIZED TO PREVENT SECONDARY SIDE PORV OPENING

PAGE A-1

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH  
 TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE E. E. McSwain 8/21/86 R \_\_\_ R \_\_\_ R \_\_\_  
 CHECKER/DATE [Signature] 8/21/86

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WENED-SGL -003  
 MANUFACTURER: ASCO  
 PAGE: 2 OF 20

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						RM/RAD
WBN-1-PSV -001-0031B	-B 1-PSV -001-0031B	-B SG4 MAIN STEAM HDR PRESS RLF CNTL VLV	X206-381-3RF	SVR/U LINE		729'	A01	80KJ3-827551	FW/V	A	100D	MUST ENERGIZED TO ASSURE SECONDARY SIDE PORV CLOSURE
WBN-1-FSV -001-0147	-A 1-FSV -001-0147	-A SG LOOP 1 WARMING VALVE	X206-381-6RVF	SVR/VA1		729'	A01	84PK4-343461	FW/V	A/B	5MIN/100D	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE WARMING VLV
WBN-1-FSV -001-0148	-B 1-FSV -001-0148	-B SG LOOP 2 WARMING VALVE	X206-381-6RVF	NVR/XA1		729'	A02	84PK4-343461	FW/V	A/B	5MIN/100D	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE WARMING VLV
WBN-1-FSV -001-0149	-A 1-FSV -001-0149	-A SG LOOP 3 WARMING VALVE	X206-381-6RVF	NVR/XA1		729'	A02	84PK4-343461	FW/V	A/B	5MIN/100D	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE WARMING VLV
WBN-1-FSV -001-0150	-B 1-FSV -001-0150	-B SG LOOP 4 WARMING VALVE	X206-381-6RVF	SVR/UA1		729'	A01	84PK4-343461	FW/V	A/B	5MIN/100D	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE WARMING VLV
WBN-1-LSV -003-0174	-B 1-LSV -003-0174	-B STM GEN 1 LEVEL SGL VALVE	206-381	SVR/UA2		729'	A01		FW/V	A/B	5MIN/100D	DEENERGIZE SO ASSOCIATED LCV WILL MODULATE. AND REMAIN DEENERGIZED.
WBN-1-LSV -003-0175	-A 1-LSV -003-0175	-A STM GEN 4 LEVEL SGL VALVE	206-381-3RVU	SVR/UA3		729'	A01	80KJ3-827551	FW/V	A/B	5MIN/100D	DEENERGIZE SO ASSOCIATED LCV WILL MODULATE. AND REMAIN DEENERGIZED.
WBN-1-FSV -003-0185	-B 1-FSV -003-0185	-B SG1 MAIN FW CHECK VALVE BYPASS	206-381-2F	SVR/UA1		729'	A01	78K3-822950	HS/V FW/V	A/B A/B	*** /100D 5MIN/100D	VLVS ARE ISOLATED ON A FW ISOLATION SIGNAL.

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

\*\* SEE TAB A, ATTACHMENT 2.

PREPARER/DATE E. E. McLean 9/24/86 R. R. R.  
 CHECKER/DATE W. B. K. / 9/24/86

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WNEB-SOL-003  
 MANUFACTURER: WECO  
 PAGE: 3 OF 20

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						RM/RAD
WBN-1-FSV -003-0186	-A 1-FSV -003-0186	-A S62 MAIN FW CHECK VALVE BYPASS	206-381-2F	NVR		729'	A02	78K3-822950	MS/V FW/V	A/B A/B	*** /1000 5MIN/1000	VLVS ARE ISOLATED ON A FW ISOLATION SIGNAL.
WBN-1-FSV -003-0187	-B 1-FSV -003-0187	-B S63 MAIN FW CHECK VALVE BYPASS	206-381-2F	NVR		729'	A02	78K3-822950	MS/V FW/V	A/B A/B	*** /1000 5MIN/1000	VLVS ARE ISOLATED ON A FW ISOLATION SIGNAL.
WBN-1-FSV -003-0188	-A 1-FSV -003-0188	-A S64 MAIN FW CHECK VALVE BYPASS	206-381	SVR		729'	A01		MS/V FW/V	A/B A/B	*** /1000 5MIN/1000	VLVS ARE ISOLATED ON A FW ISOLATION SIGNAL.
WBN-1-FSV -003-0236A	-A 1-FSV -003-0236A	-A UPPER TAP MAIN FW S61 ISLN VALVE	206-381	SVR/WA1		729'	A01		MS/V FW/V	A/B A/B	*** /1000 5MIN/1000	VLVS MUST CLOSE ON FW ISOL SIGNAL, THESE VLVS ALSO PERFORM CONTAINMENT ISLN FUNCTION.
WBN-1-FSV -003-0236B	-B 1-FSV -003-0236B	-B UPPER TAP MAIN FW S61 ISLN VALVE	206-381	SVR/WA2		729'	A01		MS/V FW/V	A/B A/B	*** /1000 5MIN/1000	VLVS MUST CLOSE ON FW ISOL SIGNAL, THESE VLVS ALSO PERFORM CONTAINMENT ISLN FUNCTION.
WBN-1-FSV -003-0239A	-A 1-FSV -003-0239A	-A UPPER TAP MAIN FW S62 ISLN VALVE	206-381-2F	NVR		729'	A02	78K3-822950	MS/V FW/V	A/B A/B	*** /1000 5MIN/1000	VLVS MUST CLOSE ON FW ISOL SIGNAL, THESE VLVS ALSO PERFORM CONTAINMENT ISLN FUNCTION.
WBN-1-FSV -003-0239B	-B 1-FSV -003-0239B	-B UPPER TAP MAIN FW S62 ISLN VALVE	206-381	NVR/EA2		729'	A02		MS/V FW/V	A/B A/B	*** /1000 5MIN/1000	VLVS MUST CLOSE ON FW ISOL SIGNAL, THESE VLVS ALSO PERFORM CONTAINMENT ISLN FUNCTION.
WBN-1-FSV -003-0242A	-A 1-FSV -003-0242A	-A UPPER TAP MAIN FW S63 ISLN VALVE	206-381	NVR/WA2		729'	A02		MS/V FW/V	A/B A/B	*** /1000 5MIN/1000	VLVS MUST CLOSE ON FW ISOL SIGNAL, THESE VLVS ALSO PERFORM CONTAINMENT ISLN FUNCTION.

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

\*\*\* SEE TAB A, ATTACHMENT 2.

PREPARER/DATE E. E. McCall 9/24/86 R \_\_\_\_\_ R \_\_\_\_\_ R \_\_\_\_\_  
 CHECKER/DATE WBK/2002 9/24/86

TAB A - EQUIPMENT IDENTIFICATION MATRIX

SINDER NO. WENED-SOL-003  
 MANUFACTURER: WSCD  
 PAGE: 4 OF 20

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						
WBN-1-FSV-003-0242B	-B 1-FSV-003-0242B	-B UPPER TAP MAIN FW S63 ISLN VALVE	206-381-2F	NVR/WA2		729'	A02	78K3-822950	MS/V FW/V	A/B A/B	*** /1000 5MIN/1000	VLVS MUST CLOSE ON FW ISOL SIGNAL, THESE VLVS ALSO PERFORM CONTAINMENT ISLN FUNCTION.
WBN-1-FSV-003-0245A	-A 1-FSV-003-0245A	-A UPPER TAP MAIN FW S64 ISLN VALVE	206-381	SVR		729'	A01		MS/V FW/V	A/B A/B	*** /1000 5MIN/1000	VLVS MUST CLOSE ON FW ISOL SIGNAL, THESE VLVS ALSO PERFORM CONTAINMENT ISLN FUNCTION.
WBN-1-FSV-003-0245B	-B 1-FSV-003-0245B	-B UPPER TAP MAIN FW S64 ISLN VALVE	206-381-2F	SVR/UA1		729'	A01	78K3-822950	MS/V FW/V	A/B A/B	*** /1000 5MIN/1000	VLVS MUST CLOSE ON FW ISOL SIGNAL, THESE VLVS ALSO PERFORM CONTAINMENT ISLN FUNCTION.
WBN-1-FSV-030-0002	-A 1-FSV-030-0002	-A PURGE AIR SUP FAN A ISLN VALVE	206-381-3RF	UA3		737'	A05	84K6-835731	L	A/B	5MIN/1000	DAMPERS ARE ACTIVATED BY A CNTMT VENT ISLN SIGNAL AND REQUIRED TO CLOSE AND REMAIN CLOSED FOR THE DURATION OF THE EVENT
WBN-1-FSV-030-0005	-A 1-FSV-030-0005	-A PURGE AIR SUP FAN B ISLN VALVE	206-381-3RF	UA3		737'	A05	84K6-835731	L	A/B	5MIN/1000	DAMPERS ARE ACTIVATED BY A CNTMT VENT ISLN SIGNAL AND REQUIRED TO CLOSE AND REMAIN CLOSED FOR THE DURATION OF THE EVENT
WBN-1-FSV-030-0007	-A 1-FSV-030-0007	-A UPPER COMPT PURGE ISLN VALVE	X206-381-3RF		286	795' 8" ANH		80KJ3-827551	L MS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1MO 1HR/1MO	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV'S ON A CNTMT VENT ISLN SIGNAL AND RESET

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH  
 TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

\*\*\* TAB A, ATTACHMENT 2.

PREPARER/DATE E. E. McRae 9/24/86 R. R. R.  
 CHECKER/DATE W.B.K./JAN 9/24/86

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WBNED-SOL -003  
 MANUFACTURER: ASCO  
 PAGE: 5 OF 20

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*					
WBN-1-FSV -030-0008	-B 1-FSV -030-0008	-B UPPER COMPT PURGE ISLN VALVE	X206-381-3RF		289	797' 2" U	80KJ3-827551	L NS/C FM/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1MD 1HR/1MD	MUST DEENERGIZE AND REMAIN DEENERGIZED TO PREVENT VLV OPENING WITH CNTNT VENT ISLN SIGNAL PRESENT AND RESET
WBN-1-FSV -030-0009	-B 1-FSV -030-0009	-B UPPER COMPT PURGE ISLN VALVE	X206-381-3RF		263	801' ANH	80KJ3-827551	L NS/C FM/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1MD 1HR/1MD	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV'S ON A CNTNT VENT ISLN SIGNAL & RESET
WBN-1-FSV -030-0010	-A 1-FSV -030-0010	-A UPPER COMPT PURGE ISLN VALVE	X206-381-3RF		261	797' U	80KJ3-827551	L NS/C FM/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1MD 1HR/1MD	MUST DEENERGIZE AND REMAIN DEENERGIZED TO PREVENT VLV OPENING W/CNTNT VENT ISLN SIGNAL PRESENT AND RESET
WBN-1-FSV -030-0012	-A 1-FSV -030-0012	-A AIRDLUS PURGE VLV SOLENOID	X206-381-2RU		260	795' 8" ANH	80KJ3-827551	L NS/C FM/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1MD 1HR/1MD	DEENERGIZE ON A CNTNT VENT ISLN SIGNAL & CANNOT FAIL CAUSING FCV TO REMAIN OPEN
WBN-1-FSV -030-0013	-A 1-FSV -030-0013	-A INTERIM ABSCE ISLN VALVE	X206-381-2RU	UA2		713' A06	80KJ3-827551	L	A/B	5MIN/1000	MUST DEENERGIZE TO CLOSE ASSOCIATED FCV ON ABS SIGNAL. MUST REMAIN DEENERGIZED TO PREVENT VALVE OPENING AFTER SIGNAL IS RESET.

PAGE A-5

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE E E McRae 8/1/86

CHECKER/DATE WLB Koz 8/2/86

R \_\_\_\_\_ R \_\_\_\_\_ R \_\_\_\_\_

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WRNEQ-SOL-003  
 MANUFACTURER: ASCO  
 PAGE: 6 OF 20

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*					
WBN-1-FSV-030-0014	-A 1-FSV-030-0014	-A LOWER CNTMT PURGE ISLN VALVE	X206-381-3RF		305	738' 10" ANH	80KJ3-827551	L NS/C FM/C RH/C CV/C	A/B A/B A/B A/B A/B	SMIN/1000 SMIN/1000 SMIN/1000 1SMIN/1ND 1HR/1ND	DEENERGIZE ON A CNTMT VENT ISLN SIGNAL & CANNOT FAIL CAUSING FCV TO REMAIN OPEN
WBN-1-FSV-030-0015	-B 1-FSV-030-0015	-B LOWER CNTMT PURGE ISLN VALVE	X206-381-3RF		298	740' 5" L	80KJ3-827551	L NS/C FM/C RH/C CV/C	A/B A/B A/B A/B A/B	SMIN/1000 SMIN/1000 SMIN/1000 1SMIN/1ND 1HR/1ND	MUST DEENERGIZE AND REMAIN DEENERGIZED TO PREVENT VLV OPENING W/CNTMT VENT ISLN SIGNAL PRESENT OR RESET
WBN-1-FSV-030-0016	-B 1-FSV-030-0016	-B LOWER CNTMT PURGE ISLN VALVE	X206-381-3RF		239	732' 10" ANH	80KJ3-827551	L NS/C FM/C RH/C CV/C	A/B A/B A/B A/B A/B	SMIN/1000 SMIN/1000 SMIN/1000 1SMIN/1ND 1HR/1ND	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV ON A CNTMT VENT ISLN SIGNAL & RESET
WBN-1-FSV-030-0017	-A 1-FSV-030-0017	-A LOWER CNTMT PURGE ISLN VALVE	X206-381-3RF		233	741' 3" L	80KJ3-827551	L NS/C FM/C RH/C CV/C	A/B A/B A/B A/B A/B	SMIN/1000 SMIN/1000 SMIN/1000 1SMIN/1ND 1HR/1ND	MUST DEENERGIZE AND REMAIN DEENERGIZED TO PREVENT VLV OPENING W/CNTMT VENT ISLN SIGNAL PRESENT OR RESET
WBN-1-FSV-030-0018	-B 1-FSV-030-0018	-B INTERIM ABSCE ISLN VALVE	X206-381-2RU	UA2		713' A06	80KJ3-827551	L	A/B	SMIN/1000	MUST DEENERGIZE AND REMAIN DEENERGIZED SO FCV DOES NOT OPEN WITH AN ABI SIGNAL PRESENT.
WBN-1-FSV-030-0019	-B 1-FSV-030-0019	-B INCORE INSTR RM PURGE ISLN VALVE	X206-381-3RF		057	730' ANH	80KJ3-827551	L NS/C FM/C RH/C CV/C	A/B A/B A/B A/B A/B	SMIN/1000 SMIN/1000 SMIN/1000 1SMIN/1ND 1HR/1ND	DEENERGIZE ON A CNTMT VENT ISLN SIGNAL & CANNOT FAIL CAUSING FCV TO REMAIN OPEN

PAGE A-6

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE C.E. M. 8/21/86  
 CHECKER/DATE W.S. 8/21/86

R \_\_\_\_\_ R \_\_\_\_\_ R \_\_\_\_\_



TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WDMED-SOL -003  
 MANUFACTURER: AGCO  
 PAGE: 7 OF 20

EGIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT#	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						RM/RAD
MWM-1-FSV -030-0020	-A 1-FSV -030-0020	-A INCORE INSTR RM PURGE ISLN VALVE	X206-381-3RF		057	727' 11"	11R	80KJ3-827551	L NS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1MD 1HR/1MD	MUST DEENERGIZE AND REMAIN DEENERGIZED TO PREVENT VALVE OPENING W/CNTMT VENT ISLN SIGNAL PRESENT OR RESET
MWM-1-FSV -030-0028	-A 1-FSV -030-0028	-A INTERIM ABSCE ISLN VALVE	X206-381-2RU	U03		737'	A05	80KJ3-827551	L	A/B	5MIN/1000	MUST DEENERGIZE ON AN ABI SIGNAL AND REMAIN DEENERGIZED TO PREVENT VLV OPENING AFTER RESET
MWM-1-FSV -030-0029	-B 1-FSV -030-0029	-B INTERIM ABSCE ISLN VALVE	X206-381-2RU	U03		737'	A05	80KJ3-827551	L	A/B	5MIN/1000	MUST DEENERGIZE ON AN ABI SIGNAL AND REMAIN DEENERGIZED TO PREVENT VLV OPENING AFTER RESET
MWM-1-FSV -030-0037	-B 1-FSV -030-0037	-B LOWER COMPT PURGE BOLENOID	X206-381-3RF		285	714'	6° ANN	80KJ3-827551	L NS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1MD 1HR/1MD	MUST DEENERGIZE AND REMAIN DEENERGIZED ON A CNTMT VENT ISLN SIGNAL OR RESET
MWM-1-FSV -030-0040	-A 1-FSV -030-0040	-A LOWER COMPT PURGE BOLENOID	X206-381-3RF		286	721' 11"	L	80KJ3-827551	L NS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1MD 1HR/1MD	MUST DEENERGIZE AND REMAIN DEENERGIZED TO PREVENT VLV OPENING W/CNTMT VENT ISLN SIGNAL OR RESET
MWM-1-FSV -030-0050	-B 1-FSV -030-0050	-B UPPER CNTMT EIM ISLN VALVE	X206-381-3RF		292	718'	9° L	80KJ3-827551	L NS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1MD 1HR/1MD	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV ON A CNTMT ISLN SIGNAL OR RESET

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

R \_\_\_\_\_ R \_\_\_\_\_ R \_\_\_\_\_

PREPARER/DATE *E.E. Mace 8/21/86*  
 CHECKER/DATE *W.P. [Signature] 8/21/86*

PAGE A-7

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. W6NE0-SOL-003  
 MANUFACTURER: ASCO  
 PAGE: 8 OF 20

EQIB NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION				CONTRACT#	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*	RH/RAD					
MBN-1-FSV -030-0051	-A 1-FBV -030-0051	-A UPPER CNTHT EIH ISLN VALVE	X206-381-3RF	290	745	10" AMN	80KJ3-827551	L MS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	SMIN/1000 SMIN/1000 SMIN/1000 1SMIN/1MO 1HR/1MO	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV ON A CNTHT ISLN SIGNAL OR RESET	
MBN-1-FSV -030-0052	-A 1-FBV -030-0052	-A UPPER CNTHT EIH ISLN VALVE	X206-381-3RF	252	760	U	80KJ3-827551	L MS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	SMIN/1000 SMIN/1000 SMIN/1000 1SMIN/1MO 1HR/1MO	MUST DEENERGIZE AND REMAIN DEENERGIZED TO PREVENT VLV OPENING W/CNTHT VENT ISLN SIGNAL PRESENT AND RESET	
WRN-1-FSV -030-0053	-B 1-FBV -030-0053	-B UPPER CNTHT EIH ISLN VALVE	X206-381-3RF	252	747	11" AMN	80KJ3-827551	L MS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	SMIN/1000 SMIN/1000 SMIN/1000 1SMIN/1MO 1HR/1MO	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV ON A CNTHT ISLN SIGNAL OR RESET	
MBN-1-FSV -030-0054	-A 1-FBV -030-0054	-A ANNULUS EIH ISLN VALVE SOLENOID	X206-381-2RU	039	729	AMN	80KJ3-827551	L MS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	SMIN/1000 SMIN/1000 SMIN/1000 1SMIN/1MO 1HR/1MO	DEENERGIZE ON A CNTHT VENT ISLN SIGNAL AND CANNOT FAIL CAUSING FCV TO REMAIN OPEN	
MBN-1-FSV -030-0056	-A 1-FBV -030-0056	-A LOWER CNTHT EIH ISLN VALVE	X206-381-3RF	038	737	10" L	80KJ3-827551	L MS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	SMIN/1000 SMIN/1000 SMIN/1000 1SMIN/1MO 1HR/1MO	MUST DEENERGIZE AND REMAIN DEENERGIZED TO PREVENT VLV OPENING W/CNTHT VENT ISLN SIGNAL PRESENT AND RESET	

PAGE A-8

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE *E.E. McBean 8/21/86*

CHECKER/DATE *W.B. [Signature] 8/21/86*

R \_\_\_\_\_ R \_\_\_\_\_ R \_\_\_\_\_

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WBNED-SOL-003  
 MANUFACTURER: ASCO  
 PAGE: 9 OF 20

EQUIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*					
WBN-1-FSV-030-0057	-B 1-FSV-030-0057	-B LOWER CNTHT EXH ISLN VALVE	1206-381-3RF		033	732' 8" ANH	80KJ3-827551	L NS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1MD 1HR/1MD	DEENERGIZE ON A CNTHT VENT ISLN SIGNAL AND CANNOT FAIL CAUSING FCV TO REMAIN OPEN
WBN-1-FSV-030-0058	-B 1-FSV-030-0058	-B INCORE INSTR RM EXH ISLN VALVE	1206-381-3RF		118	738' 9" IIR	80KJ3-827551	L NS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1MD 1HR/1MD	DEENERGIZE ON A CNTHT VENT ISLN SIGNAL AND CANNOT FAIL CAUSING FCV TO REMAIN OPEN
WBN-1-FSV-030-0059	-A 1-FSV-030-0059	-A INCORE INSTR RM EXH ISLN VALVE	1206-381-3RF		116	740' 11" ANH	80KJ3-827551	L NS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1MD 1HR/1MD	DEENERGIZE ON A CNTHT VENT ISLN SIGNAL AND CANNOT FAIL CAUSING FCV TO REMAIN OPEN
WBN-1-FSV-030-0060	-A 1-FSV-030-0060	-A INTERIM ABSCE ISLN VALVE	1206-381-2RU	VA11		757' A16	80KJ3-827551	L	A/B	5MIN/1000	MUST DEENERGIZE ON ON ABI SIGNAL AND REMAIN DEENERGIZED TO PREVENT VLV OPENING AFTER RESET
WBN-1-FSV-030-0061	-A 1-FSV-030-0061	-A PURGE AIR EXH UNIT A SUCTION VALVE	206-381-3RF	A1		713' A06	84K6-835731	L	A/B	5MIN/1000	BAMPERS ARE ACTIVATED BY CNTHT VENT ISLN SIGNAL AND ARE REQUIRED TO CLOSE AND REMAIN CLOSED FOR DURATION OF EVENT.
WBN-1-FSV-030-0062	-A 1-FSV-030-0062	-A PURGE AIR EXH UNIT B SUCTION VALVE	206-381-3RF	A1		713' A06	84K6-835731	L	A/B	5MIN/1000	BAMPERS ARE ACTIVATED BY CNTHT VENT ISLN SIGNAL AND ARE REQUIRED TO CLOSE AND REMAIN CLOSED FOR DURATION OF EVENT.

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE

*E.E. McQue 8/24/86*

CHECKER/DATE

*W.B. Hise 8/24/86*

R \_\_\_\_\_ R \_\_\_\_\_ R \_\_\_\_\_

PAGE A-9

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WRNEQ-SOL -003  
 MANUFACTURER: ASCO  
 PAGE: 10 OF 20

EQUIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						
WBN-1-FSV -030-0069	-B 1-FBV -030-0069	-B INTERIM ABSCE ISLN VALVE	X206-381-2RU	VA11		757'	A16	BOKJ3-827551	L	A/B	5MIN/1000	MUST DEENERGIZE ON AB1 SIGNAL AND REMAIN DEENERGIZED TO PREVENT VLV OPENING AFTER RESET
WBN-1-FSV -031-0305	-B 1-FBV -031-0305	-B INCORE INST RM CHILL A CMR ISLN VALVE	X206-381-2RU		060	736' 8" ANN		BOKJ3-827551	L NS/C FM/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1MO 1HR/1MO	MUST DEENERGIZE TO CLOSE FCV AND REMAIN DEENERGIZED WHEN PHASE A ISOLATION SIGNAL IS PRESENT OR ON RESET
WBN-1-FSV -031-0306	-A 1-FBV -031-0306	-A INCORE INST RM CHILL A CMR ISLN VALVE	X206-381-3RF		063	738'	I1R	BOKJ3-827551	L NS/C FM/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1MO 1HR/1MO	MUST DEENERGIZE TO CLOSE FCV AND REMAIN DEENERGIZED WHEN PHASE A ISOLATION SIGNAL IS PRESENT OR ON RESET
WBN-1-FSV -031-0308	-A 1-FBV -031-0308	-A INCORE INST RM CHILL A CMR ISLN VALVE	X206-381-2RU		061	739'	I1R	BOKJ3-827551	L NS/C FM/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1MO 1HR/1MO	MUST DEENERGIZE TO CLOSE FCV AND REMAIN DEENERGIZED WHEN PHASE A ISOLATION SIGNAL IS PRESENT OR ON RESET
WBN-1-FSV -031-0309	-B 1-FBV -031-0309	-B INCORE INST RM CHILL A CMR ISLN VALVE	X206-381-2RU		063	739' 8" ANN		BOKJ3-827551	L NS/C FM/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1MO 1HR/1MO	MUST DEENERGIZE TO CLOSE FCV AND REMAIN DEENERGIZED WHEN PHASE A ISOLATION SIGNAL IS PRESENT OR ON RESET
WBN-1-FSV -031-0326	-A 1-FBV -031-0326	-A INCORE INST RM CHILL B CMR ISLN VALVE	X206-381-2RU		100	733' 2" ANN		BOKJ3-827551	L NS/C FM/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1MO 1HR/1MO	MUST DEENERGIZE TO CLOSE FCV AND REMAIN DEENERGIZED WHEN PHASE A ISOLATION SIGNAL IS PRESENT OR ON RESET

PAGE 10

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE S.C. Mc... 8/21/06  
 CHECKER/DATE W.K. ... 8/21/06

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. MBNEO-SOL-003  
 MANUFACTURER: ASCO  
 PAGE: 11 OF 20

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV* RH/RAD					
MBN-1-FSV -031-0327	-B 1-FBV -031-0327	-B INCORE INST RN CHILL B CWR ISLN VALVE	X206-381-2RU			103-10 733' 7" IIR	80KJ3-827351	L RS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	SMIN/1000 SMIN/1000 SMIN/1000 15MIN/1MO 1HR/1MO	MUST DEENERGIZE TO CLOSE FCV AND REMAIN DEENERGIZED WHEN PHASE A ISOLATION SIGNAL IS PRESENT OR ON RESET
MBN-1-FSV -031-0329	-B 1-FBV -031-0329	-B INCORE INST RN CHILL B CWR ISLN VALVE	X206-381-2RU			102 733' 2" IIR	80KJ3-827351	L RS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	SMIN/1000 SMIN/1000 SMIN/1000 15MIN/1MO 1HR/1MO	MUST DEENERGIZE TO CLOSE FCV AND REMAIN DEENERGIZED WHEN PHASE A ISOLATION SIGNAL IS PRESENT OR ON RESET
MBN-1-FSV -031-0330	-A 1-FBV -031-0330	-A INCORE INST RN CHILL B CWR ISLN VALVE	X206-381-2RU			109 733' 10" ANH	80KJ3-827351	L RS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	SMIN/1000 SMIN/1000 SMIN/1000 15MIN/1MO 1HR/1MO	MUST DEENERGIZE TO CLOSE FCV AND REMAIN DEENERGIZED WHEN PHASE A ISOLATION SIGNAL IS PRESENT OR ON RESET
MBN-1-FSV -043-0002	-B 1-FBV -043-0002	-B PRESSURIZER GAS CWTHT ISLN VALVE	206-381-3RF			202 720' 5" L	75C63-85629-2	L RS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	SMIN/1000 SMIN/1000 SMIN/1000 15MIN/1MO 1HR/1MO	MUST DEENERGIZE AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN IN SPITE OF A PHASE A CWTHT ISOLATION
MBN-1-FSV -043-0003	-A 1-FBV -043-0003	-A PRESSURIZER GAS CWTHT ISLN VALVE	X206-381-3RF			293 721' 10" ANH	80KJ3-827351	L RS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	SMIN/1000 SMIN/1000 SMIN/1000 15MIN/1MO 1HR/1MO	MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN

PAGE 11

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH  
 TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE *88 m o g u 8/26/86*  
 CHECKER/DATE *W. J. ...*

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WRNED-SOL-003  
 MANUFACTURER: ASCO  
 PAGE: 12 OF 20

EDIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*					
WRN-1-FSV-043-0011	-B 1-FSV-043-0011	-B PRESSURIZER LIQ CNTNT ISLN VALVE	206-381-3RU		289	723' 8" L	84PJ5-835888	L RS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1MD 1HR/1MD	MUST DEENERGIZE AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN IN SPITE OF A PHASE A CNTNT ISOLATION
WRN-1-FSV-043-0012	-A 1-FSV-043-0012	-A PRESSURIZER LIQ CNTNT ISLN VALVE	1206-381-3RF		289	720' AMN	80KJ3-827551	L RS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1MD 1HR/1MD	MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN
WRN-1-FSV-043-0022	-B 1-FSV-043-0022	-B RCS HDT LEG HDR CNTNT ISLN VALVE	206-381-3RU		291-30	721' 3" L	84PJ5-835888	L RS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1MD 1HR/1MD	MUST DEENERGIZE AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN IN SPITE OF A PHASE A CNTNT ISOLATION
WRN-1-FSV-043-0023	-A 1-FSV-043-0023	-A RCS HDT LEG HDR CNTNT ISLN VALVE	1206-381-3RF		314	729' 10" AMN	80KJ3-827551	L RS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1MD 1HR/1MD	MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN
WRN-1-FSV-043-0034	-B 1-FSV-043-0034	-B ACCUM TK HDR CNTNT ISLN VALVE	206-381-3RU		295	735' 11" L	84PJ5-835888	L RS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1MD 1HR/1MD	MUST DEENERGIZE AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN IN SPITE OF A PHASE A CNTNT ISOLATION

PAGE A-12

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE B. E. McLean 8/21/86

CHECKER/DATE W. B. Kent 8/21/86

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. N08E0-SOL -003  
 MANUFACTURER: ASCO  
 PAGE:13 OF 26

EDIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT#*	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*					
MBN-1-FSV -043-0035	-A 1-FBV -043-0035	-A ACCUM TK HDR CNTMT ISLN VALVE	206-381-3RU	285	717' 10" ANN		84PJ5-83588B	L HS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	SHIN/1000 SHIN/1000 SHIN/1000 15MIN/1MO 1HR/1MO	MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN
MBN-1-FSV -043-0054D	-B 1-FBV -043-0054D	-B STEAM GEN 1 SAMPLE CNTMT ISLN VALVE	1206-381-3RF	298	721' 9" L		80KJ3-827551	L HS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	SHIN/1000 SHIN/1000 SHIN/1000 15MIN/1MO 1HR/1MO	MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN
MBN-1-FSV -043-0055	-A 1-FBV -043-0055	-A STEAM GEN BLDG 1 SAMPLE ISLN VALVE	206-381-3RU	291	718' ANN		84PJ5-83588B	L HS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	SHIN/1000 SHIN/1000 SHIN/1000 15MIN/1MO 1HR/1MO	MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN
MBN-1-FSV -043-0056D	-B 1-FBV -043-0056D	-B STEAM GEN 2 CNTMT ISLN VALVE	206-381-3RU	287	719' 10" L		83PJ5-83588B	L HS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	SHIN/1000 SHIN/1000 SHIN/1000 15MIN/1MO 1HR/1MO	MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN
MBN-1-FSV -043-0058	-A 1-FBV -043-0058	-A STEAM GEN BLDG 2 SAMPLE ISLN VALVE	206-381-3RU	288	717' 9" ANN		84PJ5-83588B	L HS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	SHIN/1000 SHIN/1000 SHIN/1000 15MIN/1MO 1HR/1MO	MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN

PAGE 8-13

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARED/DATE EE mcbae 8/21/86  
 CHECKER/DATE WJH/8/21/86

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WBN00-SOL-003  
 MANUFACTURER: ASCO  
 PAGE:14 OF 20

EGIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AT	ELEV*					
WBN-1-FSV-043-0059D	-B 1-FSV-043-0059D	-B STEAM GEN 3 CNTHT ISLN VALVE	206-381		285-30	718' 11" L		L	A/B	5MIN/1000	MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN
WBN-1-FSV-043-0061	-A 1-FSV-043-0061	-A STEAM GEN BLDG 3 SAMPLE ISLN VALVE	206-381-3RU		285	723' ANN	84PJ5-835888	L	A/B	5MIN/1000	MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN
WBN-1-FSV-043-0063D	-B 1-FSV-043-0063D	-B STEAM GEN 4 CNTHT ISLN VALVE	206-381-3RU		285-30	718' 7" L	84PJ5-835888	L	A/B	5MIN/1000	MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN
WBN-1-FSV-043-0064	-A 1-FSV-043-0064	-A STEAM GEN BLDG 4 SAMPLE ISLN VALVE	206-381-3RU		286	721' 5" ANN	84PJ5-835888	L	A/B	5MIN/1000	MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN
WBN-1-FSV-043-0075	-B 1-FSV-043-0075	-B DNSTR EXCESS LTDN HTX ISLN VALVE	206-381-3RU		318	721' 2" L	84PJ5-835888	L	A/B	5MIN/1000	MUST DEENERGIZE AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN IN SPITE OF A PHASE A CNTHT ISOLATION

PAGE A-14

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE E. E. McLean 8/21/86  
 CHECKER/DATE W. B. Hill 8/21/86



TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. B0868-SOL -003  
 MANUFACTURER: ASCO  
 PAGE 15 OF 20

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	A1	ELEV*						
MBN-1-FSV -043-0077	-A 1-FSV -043-0077	-A DNSTR EXCESS LTDW HTX ISLN VALVE	206-381-3RU		313	721'	AMB	84PJS-83588B	L RS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/1000 5MIN/1000 5MIN/1000 15MIN/1MO 1HR/1MO	MUST DEENERGIZE ON A PHASE A ISOLATION SIGNAL AND REMAIN DEENERGIZED SO THAT THE FCV DOES NOT OPEN
MBN-1-FSV -043-0201	-A 1-FSV -043-0201	-A LOCA H2 CNTMT MONITOR ISLN SOL VLV	X206-381-2RU		226	723' 3" L		80KJ3-827551	L RS/C FW/C RH/C CV/C	A A A A A	100D 100D 100D 1MO 1MO	MUST FUNCTION TO ALLOW SAMPLING OF CNTMT ATMOSPHERE AFTER AN EVENT
MBN-1-FSV -043-0202	-A 1-FSV -043-0202	-A LOCA H2 CNTMT MONITOR ISLN SOL VLV	X206-381-2RU		230	723' L		80KJ3-827551	L RS/C FW/C RH/C CV/C	A A A A A	100D 100D 100D 1MO 1MO	MUST FUNCTION TO ALLOW SAMPLING OF CNTMT ATMOSPHERE AFTER AN EVENT
MBN-1-FSV -043-0207	-B 1-FSV -043-0207	-B LOCA H2 CNTMT MONITOR ISLN SOL VLV	X206-381-2RU		300	728' L		80KJ3-827551	L RS/C FW/C RH/C CV/C	A A A A A	100D 100D 100D 1MO 1MO	MUST FUNCTION TO ALLOW SAMPLING OF CNTMT ATMOSPHERE AFTER AN EVENT
MBN-1-FSV -043-0208	-B 1-FSV -043-0208	-B LOCA H2 CNTMT MONITOR ISLN SOL VLV	X206-381-2RU		287	727' 8" L		80KJ3-827551	L RS/C FW/C RH/C CV/C	A A A A A	100D 100D 100D 1MO 1MO	MUST FUNCTION TO ALLOW SAMPLING OF CNTMT ATMOSPHERE AFTER AN EVENT

PAGE A-15

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE G. E. McLean 8/21/86  
 CHECKER/DATE W. B. News 1/21/86

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WBNEO-SOL-003  
 MANUFACTURER: ASCO  
 PAGE 16 OF 20

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION				CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*	RM/RAD					
WBN-2-FSV -065-0007	-B 2-FSV -065-0007	-B EGTS TRAIN A UNIT 2 SUCTION	206-381-3RF	UA14		757'	A16	80K8-836669	L	B	1000	FOR A UNIT 1 LOCA, THIS FSV MUST NOT FAIL IN A MANNER THAT COULD OPEN THE ASSOCIATED FCV
WBN-1-FSV -065-0008	-B 1-FSV -065-0008	-B EGTS TRAIN A UNIT 1 SUCTION	206-381-3RU	UA13		757'	A16	84PJ5-835888	L	A	1000	THESE REDUNDANT ISOLATION SOLENOIDS ARE MANUALLY OPERATED AND MAY BE REQUIRED ANYTIME DURING LOCA
WBN-1-FSV -065-0010	-A 1-FSV -065-0010	-A EGTS TRAIN A UNIT 1 SUCTION	206-381-3RF	UA11		757'	A16	84K6-835731	L	A	1000	MUST ENERGIZE TO OPEN ASSOCIATED FCV AND REMAIN ENERGIZED FOR DURATION OF EVENT
WBN-1-FSV -065-0026	-A 1-FSV -065-0026	-A UNIT 1 SHEILD BLDG ETH A	206-381-3RF	VA11		757'	A16	84K6-835731	L	A/B	5MIN/1000	DAMPERS MUST OPEN ON A CNTHT ISLN SIGNAL SO EGTS CAN DISCHARGE
WBN-1-FSV -065-0027	-B 1-FSV -065-0027	-B UNIT 1 SHEILD BLDG ETH B	206-381-3RF	VA11		757'	A16	84K6-835731B	L	A/B	5MIN/1000	DAMPERS MUST OPEN ON A CNTHT ISLN SIGNAL SO EGTS CAN DISCHARGE
WBN-0-FSV -065-0028A	-B 0-FSV -065-0028A	-B EGTS TRAIN A DECAY COOL VALVE A	206-381-3RU	VA13		757'	A16	84PJ5-835888	L	A	1000	AUTOMATICALLY ACTIVATES TO OPEN DAMPERS WHICH REMOVE DECAY HEAT WHENEVER TRAIN IS ISOLATED
WBN-0-FSV -065-0028B	-B 0-FSV -065-0028B	-B EGTS TRAIN B DECAY COOL VALVE B	206-381-3RU	VA13		757'	A16	84PJ5-835888	L	A	1000	MUST ENERGIZE TO OPEN ASSOCIATED FCV AND REMAIN ENERGIZED FOR DURATION OF EVENT

PAGE 16

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE *J.E. McAn 8/21/86*  
 CHECKER/DATE *W. Kian 8/22/86*

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WRNEQ-SOL -003  
 MANUFACTURER: ASCO  
 PAGE:17 OF 20

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION				CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*	RH/RAD					
WBN-1-FSV -065-0030	-B 1-FSV -065-0030	-B EGTS TRAIN B UNIT 1 SUCTION	206-381-3RF	VA14		757'	A16	84K6-835731	L	A	100D	MUST ENERGIZE TO OPEN ASSOCIATED FCV AND REMAIN ENERGIZED FOR DURATION OF EVENT
WBN-0-FSV -065-0047A	-A 0-FSV -065-0047A	-A EGTS TRAIN B DECAY COOL VALVE A	206-381-3RU	UA13		757'	A16	84PJ5-835888	L	A	100D	AUTOMATICALLY ACTIVATES TO OPEN DAMPERS WHICH REMOVE DECAY HEAT WHENEVER TRAIN IS ISOLATED
WBN-0-FSV -065-0047B	-A 0-FSV -065-0047B	-A EGTS TRAIN B DECAY COOL VALVE CONT	206-381-3RU	UA13		757'	A16	84PJ5-835888	L	A	100D	AUTOMATICALLY ACTIVATES TO OPEN DAMPERS WHICH REMOVE DECAY HEAT WHENEVER TRAIN IS ISOLATED
WBN-2-FSV -065-0050	-A 2-FSV -065-0050	-A EGTS TRAIN B UNIT 2 SUCTION	206-381-3RF	UA13		757'	A16	85K8-836669	L	B	100D	FOR A UNIT 1 LOCA, THIS FSV MUST NOT FAIL IN A MANNER THAT COULD OPEN THE ASSOCIATED FCV
WBN-1-FSV -065-0051	-A 1-FSV -065-0051	-A EGTS TRAIN B UNIT 1 SUCTION	206-381-3RU	VA13		757'	A16	84PJ5-835888	L	A	100D	THESE REDUNDANT ISLM SOLENOIDS ARE MANUALLY OPERATED & MAY BE REQUIRED ANYTIME DURING LOCA
WRH-1-FSV -065-0052	-A 1-FSV -065-0052	-A CNTHT ANNULUS VAC FANS ISLM DNPR	X206-381-3RF	VA11		757'	A16	80K33-827551	L	A/B	5MIN/100D	DAMPERS MUST CLOSE ON A CNTHT ISLM SIGNAL TO ISOLATE THE ANNULUS VACUUM FANS.
WBN-1-FSV -065-0053	-B 1-FSV -065-0053	-B CNTHT ANNULUS VAC FANS ISLM DNPR	X206-381-3RF	VA11		757'	A16	80K33-827551	L	A/B	5MIN/100D	DAMPERS MUST CLOSE ON A CNTHT ISLM SIGNAL TO ISOLATE THE ANNULUS VACUUM FANS.

PAGE A-17

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH  
 TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE EE McBea 8/21/86  
 CHECKER/DATE WJ/K... 8/22/86

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WBMD-SOL-003  
 MANUFACTURER: ASCO  
 PAGE 18 OF 20

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						RH/RAD
WBN-1-FSV -068-0307	-A 1-FBV -068-0307	-A RCS FLOW ENTL VALVE WDS GA TO PRT	206-381-3RF		313	718'	ANN	75C63-85629-2	L NS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/100B 5MIN/100B 5MIN/100B 15MIN/1MD 1HR/1MD	MUST DEENERGIZE UPON RECEIVING A PHASE A ISLN SIGNAL AND REMAIN DEENERGIZED THRU EVENT
WBN-1-FSV -070-0085	-B 1-FBV -070-0085	-B EXCESS LETDN HTX OUTLET VALVE	X206-381-2RU	WA4		713'	A28	80KJ3-827551	L	A/B	5MIN/100B	MUST NOT FAIL AND ALLOW THE FCV TO FAIL OPEN FOR CNTNT ISLN DURING A LOCA
WBN-1-FSV -077-0127	-B 1-FBV -077-0127	-B REAC BLDG SUMP DISCH FLOW SOL VALVE	X206-381		296	720' 10" L			L NS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/100B 5MIN/100B 5MIN/100B 15MIN/1MD 1HR/1MD	MUST DEENERGIZE AND REMAIN DEENERGIZED TO PREVENT AN OPEN PATH TO OUTSIDE CNTNT
WBN-1-FSV -077-0128	-A 1-FBV -077-0128	-A REAC BLDG SUMP DISCH FLOW SOL VALVE	X206-381-3RF	WA4		713'	A28	80KJ3-827551	L	A/B	5MIN/100B	MUST DEENERGIZE AND REMAIN DEENERGIZED TO PREVENT AN OPEN PATH TO OUTSIDE CNTNT
WBN-1-FSV -090-0107	-A 1-FBV -090-0107	-A CNTNT BLDG LMR COMPT MON ISLN VALVE	X206-381-3RF		294	741' 11" ANN		80KJ3-827551	L NS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/100B 5MIN/100B 5MIN/100B 15MIN/1MD 1HR/1MD	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV WITH CNTNT VENT ISLN SIGNAL PRESENT OR RESET
WBN-1-FSV -090-0108	-B 1-FBV -090-0108	-B CNTNT BLDG LMR COMPT MON ISLN VALVE	X206-381-3RF		297	737' 9" L		80KJ3-827551	L NS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/100B 5MIN/100B 5MIN/100B 15MIN/1MD 1HR/1MD	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV WITH CNTNT VENT ISLN SIGNAL PRESENT OR RESET

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH  
 TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE C. E. McLean 8/21/86 R \_\_\_ R \_\_\_ R \_\_\_  
 CHECKER/DATE W. B. Kline 8/21/86

PAGE A-18

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WDMED-SOL -003  
 MANUFACTURER: ASCO  
 PAGE: 19 OF 20

EDIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT#*	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*					
WBN-1-FSV -090-0109	-B 1-FSV -090-0109	-B CNTHT BLDG LWR COMPT NON ISLM VALVE	X206-381		298	737' 7" L		L	A/B	5MIN/1000	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV WITH CNTHT VENT ISLM
WBN-1-FSV -090-0110	-B 1-FSV -090-0110	-B CNTHT BLDG LWR COMPT NON ISLM VALVE	X206-381-3RF		296	738' 1" L	80KJ3-827551	L	A/B	5MIN/1000	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV WITH CNTHT VENT ISLM
WBN-1-FSV -090-0111	-A 1-FSV -090-0111	-A CNTHT BLDG LWR COMPT NON ISLM VALVE	X206-381-3RF		293	741' 11" ANN	80KJ3-827551	L	A/B	5MIN/1000	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV WITH CNTHT VENT ISLM
WBN-1-FSV -090-0113	-A 1-FSV -090-0113	-A CNTHT BLDG UPR COMPT NON ISLM VALVE	X206-381-3RF		292	740' 5" ANN	80KJ3-827551	L	A/B	5MIN/1000	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV WITH CNTHT VENT ISLM
WBN-1-FSV -090-0114	-B 1-FSV -090-0114	-B CNTHT BLDG UPR COMPT NON ISLM VALVE	X206-381-3RF		295	737' 9" L	80KJ3-827551	L	A/B	5MIN/1000	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV WITH CNTHT VENT ISLM

PAGE A-19

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH  
 TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE E. E. McEwen 8/21/06  
 CHECKER/DATE CO. B. Hunt 8/21/06

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. W0NEQ-SDL -003  
 MANUFACTURER: ASCO  
 PAGE: 20 OF 20

EQIB NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*					
MBN-1-FSV -090-0115	-B 1-FBV -090-0115	-B CNTMT BLDG UPR COMPT NON ISLN VALVE	I206-381-3RF	294	737'	9" L	80KJ3-827551	L MS/C FW/C RW/C CV/C	A/B A/B A/B A/B A/B	SMIN/1000 SMIN/1000 SMIN/1000 15MIN/1MO 1HR/1MO	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV WITH CNTMT VENT ISLN SIGNAL PRESENT OR RESET
MBN-1-FSV -090-0116	-B 1-FBV -090-0116	-B CNTMT BLDG UPR COMPT NON ISLN VALVE	I206-381	291	737'	8" L		L MS/C FW/C RW/C CV/C	A/B A/B A/B A/B A/B	SMIN/1000 SMIN/1000 SMIN/1000 15MIN/1MO 1HR/1MO	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV WITH CNTMT VENT ISLN SIGNAL PRESENT OR RESET
MBN-1-FSV -090-0117	-A 1-FBV -090-0117	-A CNTMT BLDG UPR COMPT NON ISLN VALVE	I206-381-3RF	290	741'	7" ANN	80KJ3-827551	L MS/C FW/C RW/C CV/C	A/B A/B A/B A/B A/B	SMIN/1000 SMIN/1000 SMIN/1000 15MIN/1MO 1HR/1MO	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE FCV WITH CNTMT VENT ISLN SIGNAL PRESENT OR RESET

PAGE A-20

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH  
 TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE E. E. McBan 8/21/86 R \_\_\_\_\_ R \_\_\_\_\_ R \_\_\_\_\_  
 CHECKER/DATE W. B. Kinn 8/21/86

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 1 OF 1  
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EBM DATE 8/23/86 R     R      
MODEL 206-381 SERIES CHECKED WBY DATE 8/26/86  
(DC CONSTRUCTION)

TAB A  
ATTACHMENT 1

The operating time for this valve is dependent upon the size of the Main Steam Line Break inside the North or South Valve Room. During a large break ( $1.4 \text{ ft}^2$ ), this valve must operate for no more than 9.2 seconds, after receipt of the safety injection signal. During a small break ( $0.4 \text{ ft}^2$ ), this valve must operate for no more than 192.4 seconds after receipt of the safety injection signal.

All solenoid valves located in the North and South valve rooms which must function during a Main Steam Line Break (MSLB) will have completed their safety function (deenergize) prior to superheat temperature conditions following an MSLB. Therefore, the worst case accident condition for these valves is the feedwater line break. All valves in these areas were qualified to the main feedwater HELB accident curve.

The failure evaluation in TAB C-10 which includes the effects of submergence shows that no failure mechanisms exist which could cause the valves to allow the control valve to reopen.

See TAB C-4, Group D valves, for further discussion on the qualification of solenoid valves in the main steam valve rooms

Reference: OE Calculation WBNOSG4-003, RIMS No. B45 851112 218.

TAB A - ATTACHMENT I



TAB A - ATTACHMENT 1

BINDER NO. WBNEQ-SOL -003  
PAGE: 1 OF 1

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	EVENT	CAT	OPER TIME	SAFETY FUNCTION
WBN-1-FSV -030-0296	-A 1-FSV -030-0296	-A INTERIM ISOL DAMPER CDWE	L	A/B	5MIN/1000	VALVES MUST CLOSE AND STAY CLOSED AFTER AN AUX BLDG ISOLATION
WBN-1-FSV -030-0297	-B 1-FSV -030-0297	-B INTERIM ISOL DAMPER CDWE	L	A/B	5MIN/1000	VALVES MUST CLOSE AND STAY CLOSED AFTER AN AUX BLDG ISOLATION
WBN-1-FSV -030-0298	-B 1-FSV -030-0298	-B INTERIM ISOL DAMPER CDWE	L	A/B	5MIN/1000	VALVES MUST CLOSE AND STAY CLOSED AFTER AN AUX BLDG ISOLATION
WBN-1-FSV -030-0299	-A 1-FSV -030-0299	-A INTERIM ISOL DAMPER CDWE	L	A/B	5MIN/1000	VALVES MUST CLOSE AND STAY CLOSED AFTER AN AUX BLDG ISOLATION

NOTE: THESE ITEMS ARE COVERED BY SCR WBNEQP8631 AND ECM 6422 AND DOCUMENTED IN THE OPEN ITEMS SECTION OF THIS BINDER.

R \_\_\_\_\_ R \_\_\_\_\_ R \_\_\_\_\_

PREPARER/DATE E.E. McBar 9/17/86

CHECKER/DATE D. R. Santos 9/1/86

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 1 OF 1  
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EEW DATE 9/24/86 R     R      
MODEL 206-381 SERIES CHECKED WBK/7/86 DATE 9/24/86  
(DC CONSTRUCTION)

TAB A  
ATTACHMENT 2

The operating time for this valve is dependent upon the size of the Main Steam Line Break inside the North or South Valve Room. During a large break (1.4 ft<sup>2</sup>), this valve must operate for no more than 9.2 seconds after receipt of the safety injection signal. During a small break (0.4 ft<sup>2</sup>), this valve must operate for no more than 192.4 seconds after receipt of the safety injection signal.

All solenoid valves located in the North and South valve rooms which must function during a Main Steam Line Break (MSLB) will have completed their safety function (deenergize) prior to superheat temperature conditions following an MSLB. Therefore, the worst case accident condition for these valves is the feedwater line break. All valves in these areas were qualified to the main feedwater HELB accident curve.

The failure evaluation in TAB C-10 which includes the effects of submergence shows that no failure mechanisms exist which could cause the valves to allow the control valve to reopen.

See TAB C-4, Group D valves, for further discussion on the qualification of solenoid valves in the main steam valve rooms

Reference: OE Calculation WBNOSG4-003, RIMS No. B45 851112 218.

BINDER NO WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 1 OF 26

BINDER TITLE ASCO SOLENOID VALVES, MODEL 206-381-SERIES (DC CONSTRUCTION) COMPUTED CEM DATE 8/21/86 R     R      
CHECKED WPK DATE 8/21/87

A. DOCUMENTATION

Equipment Description Solenoid Valves  
Vendor/Manufacturer Automatic Switch Company (ASCO)  
Equipment Model No.(s) 206-381-2RU 206-381-2F  
206-381-3RU  
206-381-3RF  
206-381-3RVU  
206-381-6RVF

QUALIFICATION REPORTS (SEE TAB C, "DISCUSSION")

- (1) Title/Number/Revision "Equipment Qualification RIMS NEB 840925 351 Research-Test Program & Failure Analysis of Class 1E Solenoid Vlvs", F-C5569-309/315, Appendix C. DATE Nov. 1983
- (2) Title/Number/Revision "Report on Qualification RIMS B45 850514 428 of Automatic Switch Co. (ASCO) Catalog NP-1 Solenoid Vlvs for Safety-Related Applications in Nuclear Power Generating Stations", AQR-67368, Rev. 1 DATE 8/19/83
- (3) Title/Number/Revision "Nuclear Environmental RIMS EEB 840731 501 Qualification Test Program on Sealants For Class 1E Devices and GE Terminal Blocks", Report No. 17523-1 DATE 6/20/84

OTHER (ANALYSIS, VENDOR DATA, ETC.) Refer to Sheets 1A & 1B

Note: Throughout this tab, references are made to the ASCO qualification report listed above. This report is identified as (2) in these references. Although the COCs in TAB E certify compliance to ASCO test report AQS21678/TR, Rev. A, NRC Information Notice 85-08, para. 4.b (see TAB J-4) considers all ASCO NP-1 valves (except NP8316 series) qualified to (2) above. Therefore, we are using (2) above for qualification of the valves in this binder.

PAGE B-1

EQP118.22

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 1A OF 26  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EEW DATE 9/24/86 R     R      
 MODEL 206-381 SERIES (DC CONSTRUCTION) CHECKED WBR/han DATE 9/24/86

ANALYSIS, VENDOR DATA, ETC.  
USED IN THE QUALIFICATION PROCESS

<u>Description</u>	<u>RIMs No.</u>
Wyle Laboratories Letter dated December 10, 1985.	B45 851213 008
ASCO Letter dated Decembeer 29, 1980; Storage Instructions.	EEB 810108 025
ASCO Letter dated August 11, 1986; Shelf Life	B71 860902 001
ASCO Letter dated July 26, 1984; Periodic Operation of ASCO NP-1 Solenoid Valves.	EEB 840730 021
ASCO Letter dated April 29, 1985; NP Valve Mounting Orientation.	B43 850502 015
ASCO Letters dated May 8, 1986 and May 16, 1986; respectively; Coil Heat Rise Versus Ambient Temperature Data.	B71 860512 001 & B71 860520 001
Status and Duty Cycles of 1E Solenoid Valves Located in Potentially Harsh Environments (WBNOSG4-045).	B45 860902 219
Flooding Levels in the North and South Valve Vaults (WBNAPS2-001).	B45 860711 236
100-Day Loss of Coolant Accident Dose to Electrical Equipment in the EGTS Filter Train Room (WBNNAL3-031).	B45 860529 237
Reduction of Beta Dose by Sheet Steel (GENNAL3-002)	B45 860423 235
Beta Dose Reduction by PVC-Covered Conduit Inside Primary Containment (GENNAL3-003)	B45 860824 236
Beta Dose Reduction From Finite Volume (GENNAL3-013)	B45 860624 235
Location Specific 40-Year Normal and Accident Radiation Doses (QIR NEB86164)	B45 860919 267
LOCA Temperature Profile in the Dead-Ended Compartments (QIR NEB86170)	B45 860922 253

BINDER NO. WBNEQ-SOL-003 PLANT WBH UNIT(S) 1 SHEET 1B OF 26  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EGM DATE 8/21/86 R     R      
 MODEL 206-381 SERIES (DC CONSTRUCTION) CHECKED WJK DATE 8/21/86

ANALYSIS, VENDOR DATA, ETC.  
USED IN THE QUALIFICATION PROCESS

<u>Description</u>	<u>RIMs No.</u>
Solenoid Valve Voltage Study (WBPE VAR 8602002).	Later
Identification of Harsh Environmental Areas with High Potential for Condensate Formation (GENNAL6-002).	B45 851017235
Category and Operating Times - System 1 (WB NOSC4-004)	B45 860722 219
Category and Operating Times - System 3 (WB NOSC4-005)	B45 860411 219
Category and Operating Times - System 30 (WB NOSC4-008)	B45 860320 224
Category and Operating Times - System 31 (WB NOSC4-009)	B45 860320 222
Category and Operating Times - System 43 (WB NOSC4-011)	B45 860623 218
Category and Operating Times - System 65 (WB NOSC4-015)	B45 860326 222
Category and Operating Times - System 68 (WB NOSC4-017)	B45 860722 218
Category and Operating Times - System 70 (WB NOSC4-018)	B45 860307 219
Category and Operating Times - System 77 (WB NOSC4-021)	B45 860313 219
Category and Operating Times - System 90 (WB NOSC4-026)	B45 860326 220

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 2 OF 26  
BINDER TITLE ASCO SOLENOID VALVES, MODEL 206-381-SERIES COMPUTED EE:m DATE 9/24/86 R     R      
(DC CONSTRUCTION) CHECKED WBK/xxm DATE 9/24/86

B. CONCLUSION OF REVIEW (Check only one block)

- X Equipment Qualified  
 Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule  
 Equipment Qualification Not Established by Documentation  
 Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES

- (1) Parts other than exact replacements used on IE Equipment  
(2) Review of accident condition voltages available at these solenoids must be conducted upon completion of degraded voltage calculation.  
(3) Mounting and interface documentation for installation of these solenoids must be identified and compared to test configurations.  
(4) Need documentation to show six valves covered by ASCO service bulletin have been relubricated.  
(5) Solenoid valves with missing nameplates must be replaced with qualified models and must be field verified.  
(6) Replace four solenoid valves listed on Attachment 1 to TAB A.  
(7) Replace valves 2-FSV-65-7-B, -50-A with qualified model valves per design documentation (I-TAB).

BINDER TITLE ASCO SOLENOID VALVES, MODEL 206-381-SERIES (DC CONSTRUCTION) COMPUTED EEW DATE 8/21/86 R     R      
CHECKED WJK DATE 8/21/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate All Documents Which are Applicable):

  X   Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE 323-1974)

       Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE 323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE 323-1974, IEEE 344-1975, IEEE 382-1980, and IEEE 627-1980

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_







BINDER NO. WBNEQ-SOL-003 PLANT WBW UNIT(S) 1 SHEET 6 OF 26  
 R     R      
 BINDER TITLE ASCO SOLENOID COMPUTED ECM DATE 9/5/86  
 VALVES, MODEL 206-381-SERIES  
 (DC CONSTRUCTION) CHECKED WBK DATE 9/5/86

**F. INSTALLATION INTERFACES**

Does the qualification program address all relevant interfaces of the equipment so that the installed design and configuration is similar or identical to the test configuration (yes/no/NA)? (note below)

<u>Interface</u>	<u>Identify Interface Requirement</u>	<u>Acceptable? (Yes/No/NA)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>None Specified; See TAB C, "Interfaces"</u>	<u>NA</u>	<u>NA</u>
External Process Connections	<u>None Specified; See TAB C, "Interfaces"</u>	<u>NA</u>	<u>NA</u>
Electrical Connections	<u>None Specified; See TAB C, "Interfaces"</u>	<u>NA</u>	<u>NA</u>
Conduit Seals	<u>See TAB C-9</u>	<u>Yes</u>	<u>Section 5.3 of (2)</u>
Connector Seals	<u>N/A</u>	<u>NA</u>	<u>NA</u>
Orientation	<u>Vertical &amp; Upright <sup>+</sup> 45° Conduit/Junction Box must be oriented such that moisture does not drain into coil housing</u>	<u>Yes</u>	<u>App. A, Pg. A2 of (2) &amp; ASCO Letter (TAB E-9)</u>
Physical Configuration	<u>drain into coil housing</u>	<u>NA</u>	<u>Ref (2) Sec. 5.3 and P-1 this Tab</u>
Other	<u>See below</u>	<u>Yes</u>	<u>See below</u>

JUSTIFICATION/COMMENTS ASCO does not identify specific interfacing requirements except to require a 90° street elbow facing downward connected to exhaust port or similar configuration to prevent moisture intrusion from liquid spray. This is required only on valves located inside containment and subject to containment spray. (Reference: Page A18, Section 9.5.3 of (2)). See TAB C for a description of the TVA interfaces. The process fluid for these valves is oil-free instrument air. See TAB J-2 for discussion.

**G. TEST SEQUENCE**

(1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	<u>Sect. 4, pg. 8 of (2)</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>Sect. 4, pg. 8 of (2)</u>
(c) Equipment aged:		<u>Sect. 4.1.1, pg. 8 of (2)</u>
Thermal	<u>Yes</u>	<u>Sect. 4.1.4, pg. 15 of (2)</u>
Radiation	<u>Yes</u>	<u>Sect. 4.1.2, pg. 12 of (2)</u>
Wear	<u>Yes</u>	<u>Sect. 4.1.5, pg. 15</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>Sect. 4.1.6, pg. 17 of (2)</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	<u>Sect. 4.2, pgs. 19-23 of (2)</u>
(f) Post-DBE exposure	<u>Yes</u>	<u>Sect. 4.2.3, pgs. 22 &amp; 23 of (2)</u>
(g) Final inspection and disassembly	<u>Yes</u>	<u>Sect. 4.4, pg. 24 of (2)</u>

(2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes

(3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes  
 (Reference Appendix G of (2) ).

JUSTIFICATION/COMMENTS Test Valve #2 was utilized to qualify the  
the class H coils and Viton elastomers. Ref. to this valve is in  
regard to coil and Viton elastomers qualification only unless  
otherwise noted.

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 8 OF 26

BINDER TITLE ASCO SOLENOID VALVES, MODEL 206-381-SERIES (DC CONSTRUCTION) COMPUTED EE M DATE 8/21/86 R     R      
CHECKED WJK DATE 8/21/86

H. AGING

- (1) Was aging considered in the qualification program (Yes/no/NA) Yes (Reference Appendix A, Sect. 9.4, pg. A10 of (2), and TAB C).

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>App. A, Sect. 9.4.1 of (2)</u>
Radiation exposure	<u>Yes</u>	<u>App. A, Sect. 9.4.4 of (2)</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>App. A, Sect. 9.4.5 of (2)</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	<u>App. A, Sect. 9.4.2 and 9.4.3 of (2)</u>

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? YES (Reference NA).

JUSTIFICATION/COMMENTS See Discussion, P-4.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program (yes/no/NA)? Yes (Reference App. A, Sect. 9.4.1, pg. A10 of (2) and TAB C).

JUSTIFICATION/COMMENTS \_\_\_\_\_

BINDER TITLE ASCO SOLENOID VALVES, MODEL 206-381-SERIES (DC CONSTRUCTION) COMPUTED ECM DATE 8/21/86 R     R      
 CHECKED WJK DATE 8/21/86

H. AGING (Continued)

(b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes (Reference: App. B of (2) ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

(c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference Section 4.1.1 & App. A, Section 9.4.1 of (2) ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

(d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference App. A, Sect. 9.4.1 of (2) ).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	<u>130° F (worst case)</u>	<u>250° F</u>	<u>140° F</u>
Time	<u>40 years</u>	<u>18 1/4 days</u>	<u>8 years</u>

JUSTIFICATION/COMMENTS See TAB C. The above equivalent time is based on the activation energy of the EPDM Elastomers (0.94eV) and does not consider heat rise due to the coil being energized.

(e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference Pg. 9 & App. A, Section 9.4.1 of (2) & TAB C.).

JUSTIFICATION/COMMENTS \_\_\_\_\_

(f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? Yes (Reference App. B of (2) ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 10 OF 26

BINDER TITLE ASCO SOLENOID COMPUTED SEM DATE 8/21/86  
VALVES, MODEL 206-381-SERIES  
(DC CONSTRUCTION) CHECKED WOK DATE 8/21/86

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? N/A (Reference \_\_\_\_\_).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_

- (h) Was the equipment operated during the thermal aging (yes/no/NA)? Yes (Reference Sect. 4.1.1, pg. 11 of (2)).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (yes/no/NA)? Yes (Reference App. A, Sect. 9.4.4 & 9.5.2 of (2)).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (yes/no/NA)? No (Reference \_\_\_\_\_).

JUSTIFICATION/COMMENTS ASCO's intent was not to subject the test specimen to radiation exposure in accordance with the limiting material. Their intent was to demonstrate operability regardless of the radiation threshold values by testing the entire assembly.

- (c) Was the basis for radiation aging exposure identified in the qualification program (yes/no/NA)? Yes (Reference Sect. 4.1.4 & 4.2.2 & App. A, Sect. 9.4.4 & 9.5.2 of (2)).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (yes/no/NA)? Yes (Reference Sect. 4.1.4 of (2)).

Plant normal ambient radiation dose (rd)  $2 \times 10^7$  Rads (worst case)

Test exposure dose (rd)  $2.3 \times 10^7$  Rads, gamma

Test exposure dose rate (rd/hr) 0.71 Mrad/hr

Test exposure source type (e.g., Co-60 gamma) Co-60, gamma

JUSTIFICATION/COMMENTS Test valve was exposed to a combined aging and accident dose of  $2.05 \times 10^8$  Rads, which exceeds the worst case combined plant dose of  $6 \times 10^7$  Rads. Valves with Viton elastomers must be limited to  $2 \times 10^7$  Rads combined normal and accident dose if required to shift position after exposure.

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference App. A, Sect. 9.4.5, pg. A13; and Sect. 4.1.5 of (2)).

JUSTIFICATION/COMMENTS No failure which could be attributed to vibration aging was identified.

- (b) Was the basis for vibration aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference Sect. 4.1.5; App. A, Sect. 9.4.5; of (2)).

JUSTIFICATION/COMMENTS \_\_\_\_\_

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 12 OF 26  
R     R      
BINDER TITLE ASCO SOLENOID COMPUTED ESM DATE 8/21/86  
VALVES, MODEL 206-381-SERIES  
(DC CONSTRUCTION) CHECKED WPK DATE 8/21/86

H. AGING (Continued)

addressed in the qualification program (yes/no/NA)? Yes  
(Reference Sect. 4.1.2, 4.1.3, & 4.1.5 of (2) ).

JUSTIFICATION/COMMENTS Effects resulting from these stresses  
were not discernable from other effects. However, the valves  
successfully passed the baseline tests following thermal aging,  
wear aging, pressurization aging, and radiation aging.

(b) Was the basis for stresses induced during operational aging  
identified and justified in the qualification program  
(yes/no/NA)? Yes (Ref. App. A, Sects. 9.4.2, 9.4.3 & 9.4.5  
of (2) ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

(8) Was the qualified life of the equipment and its basis defined in the  
qualification program (yes/no/NA)? Yes  
(Reference Sect. 4.1.1 of (2) ).

Qualified life (Document in QMS) See TABS C and G

JUSTIFICATION/COMMENTS The qualified life is different, in most  
cases, from the value given in the test report. TAB C provides  
rationale.

(9) Were replacement intervals for the equipment or its components defined  
in the qualification program (yes/no/NA)? Yes  
(Reference App. C of (2) ).

Replacement Intervals (Document in QMS) Replacement intervals and  
qualified life are a function of plant specific conditions in com-  
parison to test conditions. TABS C and G define the replacement  
intervals and qualified life and their basis.

JUSTIFICATION/COMMENTS \_\_\_\_\_

PAGE B-15



BINDER TITLE ASCO SOLENOID VALVES, MODEL 206-381-SERIES (DC CONSTRUCTION) COMPUTED ECM DATE 8/23/86 R     R      
 CHECKED WR DATE 8/27/86

**I. MATERIALS ANALYSIS**

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of EQC Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>(Coil) IsoMica bonded with Hi-Temp Epoxy</u>	<u>NA</u>	<u>NA</u>	<u>1.00</u>	<u>App. B, pg. B5 Thru B7 of (2)</u>
(b) <u>(Seats) Ethylene Propylene Terpolymer</u>	<u>NA</u>	<u>NA</u>	<u>0.94</u>	<u>App. B, pg. B3 of (2)</u>
(c) <u>Viton (Seats)</u>	<u>NA</u>	<u>NA</u>	<u>1.04</u>	<u>App. B, pg. B4 of (2)</u>
(d) _____	_____	_____	_____	_____
(e) _____	_____	_____	_____	_____

**JUSTIFICATION/COMMENTS** Note: The Class H coil is composed of six primary materials. Of these, the one with the lowest activation energy is Iso-Mica bonded with hi-temperature epoxy. Its activation energy is 1.00 eV. The materials of coil construction along with their activation energies are identified in Appendix B, page B5 thru B7 of (2). Radiation values are not required because no analysis was performed. The devices were qualified by test.

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 14 OF 26  
BINDER TITLE ASCO SOLENOID VALVES, MODEL 206-381-SERIES COMPUTED EE M DATE 8/21/86 R     R      
(DC CONSTRUCTION) CHECKED WJK DATE 8/21/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference App. A, Sect. 6.1, 6.2, and 6.3 of (2) ).

Identify Acceptance Criteria: Coil only taken from (2) - Must operate at any voltage between 90VDC and 140VDC. Battery operated DC valves must operate on demand at any voltage between 28% below and 12% above the specified nominal DC voltage. Insulation resistance must measure greater than or equal to 1 megohm at 500VDC. Leakage current must be less than 0.5 milliamps at 1250 VAC for 1 minute. For seats and discs, as taken from (2) - Valves must operate at the minimum and maximum operating pressure differential. Valves must not have a pressure increase at a cylinder port which is required to be vented or a pressure decrease at a cylinder port which is required to be pressurized in excess of 10% of the maximum operating pressure differential. Valves must shift to energized position upon application of power within limits specified above and shift to de-energized position when power is removed, with inlet press. applied at any value between max. and min. pressure differential.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Ref. App. A, Sects. 6.1, 6.2, 7.1, 7.2, and Table 4.4 of (2)).

Identify baseline and functional testing: Recording coil excitation, coil dielectric, seat leakage at 125 psig and 10 psig in both the energized and de-energized state, noise test, external leakage at 125 psi, operational test from 125 psig to 0 psig, insulation resistance and number of active coil turns during initial baseline and following DBA simulation.

BINDER TITLE ASCO SOLENOID VALVES, MODEL 206-381-SERIES (DC CONSTRUCTION) COMPUTED EGM DATE 8/21/86 R     R      
CHECKED WJK DATE 8/21/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes  
(Reference Appendix A, Sect. 9.5.3 & Figure 9.2, page A26 of (2) ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_

- (4) Do the applied loads during baseline testing reflect normal operating conditions (yes/no/NA)? Yes (Reference Table 4.3 and Table 4.4 of (2)).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 16 OF 26  
 BINDER TITLE ASCO SOLENOID VALVES, MODEL 206-381-SERIES COMPUTED EE M DATE 8/21/86  
 (DC CONSTRUCTION) CHECKED WJK DATE 8/21/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

(5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) <u>Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference</u>
Voltage	_____	_____
Load	_____	_____
Frequency	<u>NA</u>	<u>NA</u>
Accuracy	<u>NA</u>	<u>NA</u>
<u>Other(s)</u>	_____	_____
	_____	_____

JUSTIFICATION/COMMENTS \_\_\_\_\_

(b) <u>Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>
Voltage	<u>102 VAC and 76 VDC</u>	<u>Table 4.3 &amp; 4.4 of (2) NP-1 Catalog pg. 5, TAB E-10</u>
Load	<u>35.1 Watts</u>	
Frequency	<u>NA</u>	
Accuracy	<u>NA</u>	
<u>Other(s)</u>	_____	_____
	_____	_____

JUSTIFICATION/COMMENTS A primary concern with solenoid valves is that of voltage available at the coil terminals. The tested valve successfully completed functional testing at the minimum 90 VDC. Required per Ref (2) App A, Section 6.1.1.

PAGE B-19

EQP118.22

**K. REQUIRED OPERATING ENVIRONMENT**

Reference Environmental Drawing No. 47E235-42 (worst case)

- |  |                                      |
|--|--------------------------------------|
| (1) Normal Max   | (2) Abnormal Max                     |
| (a) Temperature (°F) <u>120° F</u>                                   | (a) Temperature (°F) <u>130° F</u>   |
| (b) Pressure (psia) <u>14.7 psia</u>                                 | (b) Pressure (psia) <u>14.7 psia</u> |
| (c) Humidity (%) <u>80%</u>  | (c) Humidity (%) <u>100%</u>         |
| (d) Radiation (rd) <u>2x10<sup>7</sup> rads<br/>TID (worst case)</u> | (d) Radiation (rd) <u>NA</u>         |

(3) Process Interfaces: The process fluid for these valves is oil-free instrument air with a maximum design temperature of 100° F. Therefore, the bounding temperature for these valves is the ambient.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Up to eight hours per excursion and less than 1% of plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- |  |                                |
|--|--------------------------------|
| (a) Temperature (°F) <u>327° F<br/>(12 psig)</u>   | Accident type <u>LOCA/HELB</u> |
| (b) Pressure (psig) <u>26.4 psia</u>   | Accident type <u>LOCA/HELB</u> |
| (c) Humidity (%) <u>100%</u>   | Accident type <u>LOCA/HELB</u> |
| (d) Radiation (rd) <u>5 x 10<sup>8</sup> rads<br/>(beta)<sub>7</sub><br/>4 x 10<sup>7</sup> rads<br/>(gamma)</u>               | Accident type <u>LOCA/HELB</u> |
| (e) Spray Type <u>0.1847 molar H<sub>3</sub>BO<sub>3</sub><br/>(2000 ppm Boron),<br/>0.333 molar NaOH,<br/>pH 8.2 @ 25° C.</u> | Accident type <u>LOCA/HELB</u> |

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 18 OF 26  
 BINDER TITLE ASCO SOLENOID VALVES, MODEL 206-381-SERIES COMPUTED EM DATE 9/24/86 R     R      
 (DC CONSTRUCTION) CHECKED WBK/ DATE 8/24/86

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.):

The duration of the containment spray is 30 days. Containment spray flow rate is equal to 9500 gal/min or 0.92 GPM per square foot of containment cross section.

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (yes/no/NA)? Yes (Reference See Sect. P. (1) "Discussion" ).

(7) Subject to submergence (yes/no/NA)? Yes (Reference                      ).

Identify initiation time and duration of submergence: See page 19A of this tab for discussion on valves subject to submergence.

(8) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
<u>Status and Duty Cycles of 1E Solenoid Valves Located in Potentially Harsh Environments (WBN-OSG4-045)</u>	<u>B45 860902 219</u>
<u>Flooding Levels in the North and South Valve Vaults (WBNAPS2-001)</u>	<u>B45 860711 236</u>
<u>100-Day Loss-of-Coolant Accident Radiation Dose to Electrical Equipment in the EGTS Filter Train Room (WBNNAL3-031)</u>	<u>B45 860529 237</u>
<u>Identification of Harsh Environmental Areas with High Potential for Condensate Formation (GENNAL6-002)</u>	<u>B45 860812 236</u>
<u>Solenoid Valve Voltage Study (WBPE VAR 8602002)</u>	<u>LATER</u>
<u>Location Specific 40-Year Normal and Accident Radiation Doses (QIR NEB86164)</u>	<u>B45 860919 267</u>
<u>LOCA Temperature Profile in the Dead-Ended Compartments (QIR NEB86170)</u>	<u>B45 860922 253</u>

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 18A OF 26  
 R     R      
 BINDER TITLE ASCO SOLENOID COMPUTED EGM DATE 9/24/86  
VALVES, MODEL 206-381-SERIES  
(DC CONSTRUCTION) CHECKED WBK/for DATE 9/24/86

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Reduction of Beta Dose by Sheet Steel (GENNAL3-002)	B45 860423 235
Beta Dose Reduction by PVC-Covered Conduit Inside Primary Containment (GENNAL3-003)	B45 860624 236
Beta Dose Reduction from Finite Volume (GENNAL3-013)	B45 860624 235
Category and Operating Times-System 1 -(WBNOSG4-004)	B45 860722 219
Category and Operating Times-System 3 -(WBNOSG4-005)	B45 860411 219
Category and Operating Times-System 30-(WBNOSG4-008)	B45 860320 224
Category and Operating Times-System 31-(WBNOSG4-009)	B45 860320 222
Category and Operating Times-System 43-(WBNOSG4-011)	B45 860623 218
Category and Operating Times-System 65-(WBNOSG4-015)	B45 860326 222
Category and Operating Times-System 68-(WBNOSG4-017)	B45 860722 218
Category and Operating Times-System 70-(WBNOSG4-018)	B45 860307 219
Category and Operating Times-System 77-(WBNOSG4-021)	B45 860313 219
Category and Operating Times-System 90-(WBNOSG4-026)	B45 860326 220

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 19 OF 26  
 BINDER TITLE ASCO SOLENOID VALVES, MODEL 206-381-SERIES (DC CONSTRUCTION) COMPUTED ELM DATE 8/21/86 R     R      
 CHECKED WPK DATE 8/21/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
	1		Fig. 4.2, pg.
Operating Time	100 Days	30 Days	26 of (2)
			Fig. 4.2, pg.
Temperature (°F)	327° F	450° F	26 of (2)
	26.4 psia		Fig. 4.2, pg.
Pressure (psig)	(12 psig)	86 psig	26 of (2)
			Fig. 4.2, pg.
Relative Humidity (%)	100% <sup>2</sup>	100%	26 of (2)
	2000 ppm Boron (H <sub>3</sub> BO <sub>3</sub> )	3000 ppm	App. A, pg. A20
*Chemical Spray	pH 8.2	Boron pH 10.5	& A21 of (2)
	5 x 10 <sup>8</sup> rads BETA		
**Radiation (rd)	6 x 10 <sup>7</sup> rads GAMMA	2.05 x 10 <sup>8</sup> rads <sup>3</sup> gamma	Sect. 4.1.4, 4.2.2, 5.2, Table 5.1, App. D of (2)
Submergence	Yes	No	See Sheet 19A

\*Includes spray concentration, flowrate, density, duration, and pH.  
 \*\*Enter 40-year integrated normal dose plus integrated accident dose and specify type (see p. 3 "Discussion" for discussion of beta-gamma dose).

- 1 - Within 30 days the temperature will return to maximum normal
- 2 - At 27.78 hours the humidity declines linearly to the maximum normal at 30 days.
- 3 - Valves<sup>7</sup> containing viton elastomers are only qualified to a maximum of 2 x 10<sup>7</sup> rads gamma.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	Yes	See (1) Above
Pressure	Yes	See (1) Above
Relative Humidity	Yes	See (1) Above
Chemical Spray	Yes	See Sect. P.(2) See Sheet 19A &
Submergence	No	TAB C, Sect. C-10

PAGE B-23

EQP118.22



BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 19A OF 26

BINDER TITLE ASCO SOLENOID COMPUTED CEM DATE 8/2/86 R     R    

VALVES, MODEL NO. 206-381-SERIES  
(DC CONSTRUCTION) CHECKED WOK DATE 8/2/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

JUSTIFICATION/COMMENTS: Equipment located inside containment  
inside the crane wall below elevation 722' (surge level) could  
become submerged following an accident. Outside the crane wall,  
the steady state flood level is 717'9". No valves listed in this binder  
are located inside the crane wall and none are located below these  
levels. Some valves in the Valve Vault Rooms could be subjected  
to submergence. Calculation WBNAPS2-001 (B45 860711 236)  
determines the maximum flood levels for the Valve Vault Rooms to  
be 730.84' for the South Room and 730.87' for the North Room. The  
valves in this binder located in the Valve Vault Rooms are  
addressed under TAB C, Section C-4 (Group D Valves).

PAGE B-24

EQP118.22

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 20 OF 26

BINDER TITLE ASCO SOLENOID VALVES, MODEL NO. 206-381-SERIES (DC CONSTRUCTION) COMPUTED CEM DATE 8/21/86 R     R      
 CHECKED WJK DATE 8/21/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

(3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, yes/no/NA)

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	> 15°F	Yes
Pressure: +10% but no more than 10 psig	> 10%	Yes
Radiation: +10% of accident dose	> 10%	Yes
Time: +10% (or 1 hour + operating time per NUREG-0588)	*	No
Voltage: <sup>+</sup> 10% of rated value	+12 to -28%	Yes
Frequency: <sup>+</sup> 5% of rated value	N/A	N/A
Environmental Transient: the initial transient and the peak temperature applied twice	Yes See Sect. 4.2.1	Yes
Seismic Vibration: +10% added to acceleration	of (2)	Yes

JUSTIFICATION/COMMENTS: See Appendix E of (2) for detailed information on margins.

\* The post-accident life calculation in TAB C proves that the 30-day test envelops the 100-day post-accident requirement.

BINDER TITLE ASCO SOLENOID COMPUTED ECM DATE 8/21/86 R     R      
VALVES, MODEL NO. 206-381-SERIES  
(DC CONSTRUCTION) CHECKED WWR DATE 8/21/86

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:  
(Reference See TAB A ).

JUSTIFICATION/COMMENTS Functions are varied. All are listed  
in TAB A.

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes (Ref. Sect. 5, Table 5.1, pg. 59, App. J, and pg. 33 of (2)).

JUSTIFICATION/COMMENTS The test valve is assumed to be normally energized and required to de-energize on receipt of accident signal, then to remain operable for 30 days post-DBA. The specific DBA functions of the TVA valves are described in TAB C.

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? Yes (Ref. Sect. 4.2.3, App. J of (2)).

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? Yes (Reference Table 5.1, pg. 59 and App. J, Table 1 of (2)).

JUSTIFICATION/COMMENTS See TAB C for the analysis of the test DBA versus the plant specific DBA. The test valve demonstrated operability in accordance with the requirements defined in M(2) above.

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? Yes (Ref. Sects. 5.2 and 5.3, pgs. 56 and 57 of (2) and page 33 of (2) ).

JUSTIFICATION/COMMENTS We have reviewed and concur with the disposition of anomalies in the test report. There is no impact on installed equipment.



BINDER TITLE ASCO SOLENOID VALVES, MODEL NO. 206-381-SERIES COMPUTED ESM DATE 8/24/86 R      R       
 (DC CONSTRUCTION) CHECKED WAK DATE 8/21/86

0. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
(1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
(2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>N/A</u>
(3) Choice of qualification methodology adequately justified?	<u>Yes</u>
(4) If analysis was performed, complete the following:	
(a) Were equipment performance requirements identified?	<u>N/A</u>
(b) Were specific features and failure modes and effects analyzed?	<u>N/A</u>
(c) Were assumptions and mathematical models used together with appropriate justification for their use?	<u>N/A</u>
(d) Were environmental parameters which affect equipment performance identified?	<u>N/A</u>
(5) Adequate similarity between equipment and test specimen established?	<u>Yes</u>
(6) Aging degradation evaluated adequately?	<u>Yes</u>
(a) Mechanical and/or cycle aging addressed?	<u>Yes</u>
(b) Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes</u>
(c) Absence of preaging in test/analysis justified?	<u>N/A</u>
(d) Materials susceptible to thermal/radiation aging identified?	<u>Yes</u>

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 24 OF 26

BINDER TITLE ASCO SOLENOID VALVES, MODEL NO. 206-381-SERIES (DC CONSTRUCTION) COMPUTED EE M DATE 8/21/86 R     R      
CHECKED WPK DATE 8/21/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>Yes</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>Yes</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>Yes</u>
(11) Criteria regarding submergence satisfied?	<u>Yes</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

PAGE B-29

BINDER TITLE ASCO SOLENOID VALVES, MODEL NO. 206-381-SERIES (DC CONSTRUCTION) COMPUTED ECM DATE 8/21/86 R     R      
 CHECKED [Signature] DATE 8/21/86

O. SUMMARY OF REVIEW (Continued)

- |  | <u>Yes/No/NA</u> |
|--|------------------|
| (15) Criteria regarding functional testing satisfied?  | <u>Yes</u>       |
| (a) Does the test plan/report specify an acceptance criteria for equipment performed?  | <u>Yes</u>       |
| (b) Was an initial base line test done to establish required performance characteristics?  | <u>Yes</u>       |
| (c) Has the test/analysis demonstrated that performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? | <u>Yes</u>       |
| (16) Criteria regarding instrument accuracy satisfied?   | <u>N/A</u>       |
| (17) Test duration margin (1 hour + function time) satisfied?  | <u>Yes</u>       |
| (a) Is the minimum specified operating time at least 1 hour?   | <u>Yes</u>       |
| (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided?  | <u>N/A</u>       |
| (18) Criteria regarding synergistic effects satisfied?   | <u>Yes</u>       |
| (19) Criteria regarding margins satisfied?   | <u>Yes</u>       |
| (20) Maintenance and surveillance requirements adequately identified?  | <u>Yes</u>       |

P. DISCUSSION

(1) Moisture or liquid intrusion (Sect. K.(6)).  
The valves requiring protection from moisture or liquid intrusion have had Conax conduit seals installed and are identified in Section 1 of the QMDS, which is located in TAB G of the binder. See TAB C-9, submergence for elaboration.

BINDER NO. WBNEQ-SOL-003 PLANT WBN UNIT(S) 1 SHEET 26 OF 26  
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EGM DATE 9/24/86  
MODEL 206-381-SERIES (DC CONSTRUCTION) CHECKED WBK/1002 DATE 9/24/86

P. DISCUSSION (Continued)

(2) Chemical Spray (Sec. L. (1) & (2)).

The containment spray flow rate is equal to 9500 gal/min or 0.92 GPM per square foot of containment cross section and the duration is 30 days. The chemical spray concentration is 2000 ppm Boron with a pH of 8.2. The ASCO test valve was subjected to a 30-day exposure to steam, chemical spray and clear water simulating a combined LOCA/HELB and post-accident cool-down. The chemical spray solution of 3000 ppm Boron as Boric Acid in solution with 0.064 molar sodium thiosulfate buffered with sodium hydroxide to a pH value of 10.5 at room temperature was applied at a rate of 0.7 GPM per square foot of valve area projected in a horizontal plane. The test solution is more corrosive than the containment spray. Therefore, all valves listed in this binder fall within the qualification provided by the test valve.

(3) Beta Radiation (Sec. O.(12)(b)).

Post-DBA beta radiation must be addressed for all equipment located inside containment which is required for LOCA mitigation. Solenoid valves in Group A are located inside containment in the lower compartment, Group B valves are in the upper compartment, and Group C valves are in the Annulus.

Per drawing 47E235-44 R1, which covers the Annulus, 100-day accident radiation dose is  $1.2 \times 10^7$  rads gamma and  $6.0 \times 10^5$  rads beta. Since the ASCO valves are qualified to  $2.05 \times 10^6$  rads, no credit for reduction of the beta dose is necessary for the valves in Group C.

Per drawing 47E235-41 R1, the upper compartment, which covers the lower compartment, shows the 100-day accident radiation to be  $4.7 \times 10^8$  rads beta and  $3.8 \times 10^7$  rads gamma.

Since the combined gamma/beta doses possible in the lower (Group A) and upper (Group B) compartments exceed the qualified level of the valves on face value, it is necessary to consider the inherent shielding afforded these valves.

All non-metallic parts of the valves are totally enclosed by metal with the exception of the 18" wire pigtailed. The minimum thickness of metal is assumed to be the coil housing, which is 3/32" (0.09375) steel, per ASCO's Tom Hays telecon with TVA's Dean Helton on January 7, 1986. OE Calculation GENNAL3-002 R3 (B45 860432 235) "Reduction of Beta Dose by Sheet Steel," page 3.1, shows the beta reduction factor for 14 gauge (0.0747)" steel is equal to 0.0536. This reduces the total 100-day Beta dose to the valve internal parts to  $(4.7 \times 10^8) \times (5.36 \times 10^{-2}) = 2.52 \times 10^7$  rads TID beta.



BINDER TITLE ASCO SOLENOID VALVESMODEL 206-381-SERIES

(DC CONSTRUCTION)

COMPUTED ECMDATE 8/21/86R     R    CHECKED WAKDATE 8/21/86P. DISCUSSION (Continued)

## (3) Radiation (Sec. O.(12)(b) (Continued)

In the lower compartment the total combined 100-day beta and gamma accident radiation dose will equal  $(2.52 \times 10^7 \text{ beta}) + (4.0 \times 10^7 \text{ gamma}) = 6.52 \times 10^7 \text{ rads}$ . The combined 100-day accident radiation plus the 40-year dose ( $8 \times 10^8$  worst case) equals a total radiation dose of  $1.45 \times 10^8 \text{ rads TID}$ . This represents the worst case inside containment since the upper compartment has a lower 40-year TID ( $1 \times 10^6 \text{ rads}$ ) and accident dose ( $2.52 \times 10^7 \text{ beta}$  and  $3.8 \times 10^7 \text{ gamma}$ ). The  $2.05 \times 10^8 \text{ rads}$  the valves are qualified to clearly envelops the requirement.

The pigtail leads to valves No. 1-FSV-43-201, -202, -207, and -208 (subgroup A-2) terminate in a splice inside a piece of 1" solid conduit which attaches to a Conax connector. Inasmuch as these valves must be operable for 100 days after an accident, the pigtails must be qualified for the full 100-day radiation dose. Since a calculation on the reduction of beta dose afforded by solid conduit has not been made at this time, we will relate the wall thickness of the conduit to the aforementioned "Reduction of Beta Dose by Sheet Steel" calculation for this calculation. One-inch rigid conduit has a wall thickness of 0.135". Page 3.1 of the sheet steel calculation shows the beta reduction factor for 1/8-inch sheet steel is equal to 0.0090. This reduces the total 100-day beta dose to  $(4.7 \times 10^8) \times (9.03 \times 10^{-3}) = 4.24 \times 10^6 \text{ rads}$ .

Thus, the total combined 100-day beta and gamma accident radiation dose  $(4.24 \times 10^6 \text{ beta}) + (4.0 \times 10^7 \text{ gamma}) = 4.42 \times 10^7 \text{ rads}$ , plus the 40-year dose ( $2.0 \times 10^8 \text{ rads}$ ) equals a total radiation dose of  $6.42 \times 10^8 \text{ rads}$ . The  $2.05 \times 10^8 \text{ rads}$  the valves are qualified to clearly envelops the requirement.

The pigtail leads of all other valves in Groups A and B are covered by 1/2 or 3/4-inch diameter flexible stainless steel conduit. Since these valves are required to operate for only 5 minutes into a LOCA, the pigtails are not required to be qualified for the full 100-day beta dose. OE Calculation TI-RPS-48R2 (B45 851105 235) "Integrated Accident Dose Inside Primary Containment," Table VI-14, page 7.24, shows the total beta dose at 2 hours into the accident to equal  $4.12 \times 10^7 \text{ rads TID}$ . OE Calculation GENNAL3-003 (B45 860624 236) "Beta Dose Reduction by PVC-Covered Conduit Inside Primary Containment," Table 25, Page 88, shows the minimum reduction factor for 1/2 or 3/4-inch conduit to be 1/8.2 or 0.122. This reduces the two-hour beta dose to  $(4.12 \times 10^7) (1.22 \times 10^{-1}) = 5.03 \times 10^6 \text{ rads TID beta}$ . The total combined beta and gamma radiation dose will equal  $(5.03 \times 10^6 \text{ beta}) + (4.0 \times 10^7 \text{ gamma}) + 4.503 \times 10^7 \text{ rads}$  accident radiation plus the larger lower compartment 40-year dose ( $2.0 \times 10^8 \text{ rads}$ ) equals a total radiation dose of  $6.503 \times 10^8 \text{ rads TID}$ . The ASCO valves are qualified for  $2.05 \times 10^8 \text{ rads}$ .

PAGE B-32

EQP231.02

BINDER NO. WBNEQ-SOL-003 PLANT WBW UNIT(S) 1 SHEET 26 B OF 26  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE M DATE 8/21/86 R     R      
 MODEL 206-381-SERIES  
 (DC CONTRUCTION) CHECKED WPK DATE 8/21/86

DISCUSSION (Continued)

OE Calculation GENNAL3-013, "Beta Dose Reduction from Finite Volume" (B45 860624 235) provides reduction factors for beta radiation doses based on the free space or "box volume" found inside each device. The free space<sub>3</sub> volume for the 206-381 series solenoid valves was calculated to be 692 cm<sup>3</sup>. This was done by calculating the volume of a cylinder with dimensions corresponding to the extreme outside dimensions shown on drawing JVA-206-381 (TAB I) for the coil housing. The cylindrical volume of the conduit entry nipple was added to this and the combined volume was treated as if none of the space was occupied by internal components (space occupied by coil, wiring, etc. was not subtracted). As can be seen from the drawing, this free space volume calculation is extremely conservative.

Using the 692 cm<sup>3</sup> free space volume value and corresponding beta dose reduction factor (per GENNAL3-013), the effective beta radiation dose for the valves in this binder may be calculated:

$$692 \text{ cm}^3 \ll 1000 \text{ cm}^3; \text{ use } 1.44 \times 10^{-6} \text{ reduction factor}$$

$$\text{Effective Beta Dose} = (4.7 \times 10^8 \text{ rads})(1.44 \times 10^{-6}) = 676.8 \text{ rads}$$

The beta dose due to free space volume inside the valve is insignificant (676.8 rads < 3 x 10<sup>8</sup> rads).

P. DISCUSSION (Continued)

(4) Synergisitic Effects (Sec. H(3))

Ethylene Propylene Terpolmer (EPDM) elastomer is used in the  
construction of ASCO solenoid valves as gaskets and diaphragms. EPDM  
is the only material having a potential for radiation induced  
synergisms based on a review of technical information provided in  
NUREG/CR-2157 and NUREG/CR-2553. Data in NUREG/CR-2157 suggests that  
dose rate effects in EPR materials are insignificant up to doses of 10  
to 20 MRADs. A review of the location and environments of ASCO  
solenoid valves listed in TAB C-1 indicates that the maximum normal  
radiation dose will be seen by valves in subgroup A-2. These valves  
are qualified for 40 years without replacement of elastomer parts and  
will therefore be exposed to a maximum normal dose of 20 MRADs. Since  
all elastomer parts are totally enclosed in metal, the radiation dose  
to these parts will be less than 20 MRADs. Synergistic effects will  
be negligible for normal service aging.

Potential dose rate and test sequence synergisms will not impact  
qualification for accident conditions as demonstrated by Test Report  
AQR-67368. The test sequence of thermal aging followed by radiation  
aging plus accident radiation at high dose rates (0.71 MRADs/HR-Aging,  
0.9 MRADs/HR-Accident) is a reasonable simulation of actual plant  
requirements. Additional assurance is provided by the severity of the  
radiation test because the test valve was exposed to 201 MRADs whereas  
an actual dose of about 48 MRADs (28 MRADs accident plus 20 MRADs  
normal service) is required.

BINDER NO. WBNEQ-SOL -004 PLANT WBN UNIT(S) 1 SHEET 1 OF 1  
BINDER TITLE MSIV AIR MANIFOLD COMPUTED RAL DATE 6/4/86 R     R      
ASSEMBLY/SOLENOID VALVES-GOULD ALLIED CHECKED MBR DATE 6/2/86

TAB A

EQUIPMENT IDENTIFICATION MATRIX

PAGE A-1

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. W8MEQ-SDL-004  
 MANUFACTURER: BOWLD ALLIED  
 PAGE: 1 OF 6

ERIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						RM/RAD
W8N-1-FSV-001-0004A	-A 1-FSV-001-0004A -A	S6 1 MAIN STM HDR ISLN VLV	3211-21	SVR		729'	A01	76K38-B3080	MS/V FM/V	A/B A/B	15s/1000 5MIN/1000	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
W8N-1-FSV-001-0004B	-B 1-FSV-001-0004B -B	S6 1 MAIN STM HDR ISLN VLV	3211-21	SVR		729'	A01	76K38-B3080	MS/V FM/V	A/B A/B	15s/1000 5MIN/1000	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
W8N-1-FSV-001-0004D	-A 1-FSV-001-0004D -A	S6 1 MAIN STM HDR ISLN VLV	3211-21	SVR		729'	A01	76K38-B3080	MS/V FM/V	A/B A/B	15s/1000 5MIN/1000	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
W8N-1-FSV-001-0004E	-A 1-FSV-001-0004E -A	S6 1 MAIN STM HDR ISLN VLV	3211-21	SVR		729'	A01	76K38-B3080	MS/V FM/V	A/B A/B	15s/1000 5MIN/1000	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
W8N-1-FSV-001-0004F	-A 1-FSV-001-0004F -A	S6 1 MAIN STM HDR ISLN VLV	3211-21	SVR		729'	A01	76K38-B3080	MS/V FM/V	B/C A/B	15s/1000 5MIN/1000	MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED TO CLOSE THE MSIV IF IN TEST MODE
W8N-1-FSV-001-0004G	-B 1-FSV-001-0004G -B	S6 1 MAIN STM HDR ISLN VLV	3211-21	SVR		729'	A01	76K38-B3080	MS/V FM/V	A/B A/P	15s/1000 5MIN/1000	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN

\* FLDOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE MODEL NUMBER ON EACH VALVE THROUGH TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE

*B. H. Lovelady / 6-11-86*

CHECKER/DATE

*W. B. Hunt / 6-22-86*

R \_\_\_\_\_ R \_\_\_\_\_ R \_\_\_\_\_

PAGE # 2

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. W980-SOL-004  
 MANUFACTURER: GOULD ALLIED  
 PAGE: 2 of 6

EBIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION				CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*	RM/RAD					
WBN-1-FSV -001-0004H	-B 1-FSV -001-0004H -B	SG 1 MAIN STM HDR ISLN VLV	321X-21	SVR		729'	A01	76K38-83080	MS/V FM/V	A/B A/B	15s/100D 5MIN/100D	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
WBN-1-FSV -001-0004J	-B 1-FSV -001-0004J -B	SG 1 MAIN STM HDR ISLN VLV	321X-21	SVR		729'	A01	76K38-83080	MS/V FM/V	B/C A/B	15s/100D 5MIN/100D	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE THE MSIV IF IN TEST MODE
WBN-1-FSV -001-0011A	-A 1-FSV -001-0011A -A	SG 2 MAIN STM HDR ISLN VLV	321X-21	NVR		729'	A02	76K38-83080	MS/V FM/V	A/B A/B	15s/100D 5MIN/100D	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
WBN-1-FSV -001-0011B	-B 1-FSV -001-0011B -B	SG 2 MAIN STM HDR ISLN VLV	321X-21	NVR		729'	A02	76K38-83080	MS/V FM/V	A/B A/B	15s/100D 5MIN/100D	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
WBN-1-FSV -001-0011D	-A 1-FSV -001-0011D -A	SG 2 MAIN STM HDR ISLN VLV	321X-21	NVR		729'	A02	76K38-83080	MS/V FM/V	A/B A/B	15s/100D 5MIN/100D	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
WBN-1-FSV -001-0011E	-A 1-FSV -001-0011E -A	SG 2 MAIN STM HDR ISLN VLV	321X-21	NVR		729'	A02	76K38-83080	MS/V FM/V	A/B A/B	15s/100D 5MIN/100D	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE MODEL NUMBER ON EACH VALVE THROUGH TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREFARER/DATE R.H. Jolley / 6-11-86

CHECKER/DATE W.B. King / 6-12-86

PAGE A-3

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WSEQ-SOL-004  
 MANUFACTURER: GOULD ALLIED  
 PAGE: 3 of 6

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION				CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*	RM/RAD					
WDM-1-FSV-001-0011F	-A 1-FSV-001-0011F -A	SG 2 MAIN STM HDR ISLN VLV	321X-21	NVR		729'	A02	76X38-83080	MS/V FW/V	B/C A/B	15s/1000 5MIN/1000	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE THE MSIV IF IN TEST MODE
WDM-1-FSV-001-0011G	-B 1-FSV-001-0011G -B	SG 2 MAIN STM HDR ISLN VLV	321X-21	NVR		729'	A02	76X38-83080	MS/V FW/V	A/B A/B	15s/1000 5MIN/1000	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
WDM-1-FSV-001-0011H	-B 1-FSV-001-0011H -B	SG 2 MAIN STM HDR ISLN VLV	321X-21	NVR		729'	A02	76X38-83080	MS/V FW/V	A/B A/B	15s/1000 5MIN/1000	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
WDM-1-FSV-001-0011J	-B 1-FSV-001-0011J -B	SG 2 MAIN STM HDR ISLN VLV	321X-21	NVR		729'	A02	76X38-83080	MS/V FW/V	B/C A/B	15s/1000 5MIN/1000	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE THE MSIV IF IN TEST MODE
WDM-1-FSV-001-0022A	-A 1-FSV-001-0022A -A	SG 3 MAIN STM HDR ISLN VLV	321X-21	NVR		729'	A02	76X38-83080	MS/V FW/V	A/B A/B	15s/1000 5MIN/1000	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
WDM-1-FSV-001-0022B	-B 1-FSV-001-0022B -B	SG 3 MAIN STM HDR ISLN VLV	321X-21	NVR		729'	A02	76X38-83080	MS/V FW/V	A/B A/B	15s/1000 5MIN/1000	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE MODEL NUMBER ON EACH VALVE THROUGH TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE R. H. Jowdy/6-11-86  
 CHECKER/DATE W. B. [Signature]/6-11-86

PAGE A-4

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WBNED-SOL -004  
 MANUFACTURER: GOLD ALLIED  
 PAGE: 4 OF 6

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION				CONTRACT**	EVENT	EAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*	RM/RAD					
WBN-1-FSV -001-0022D	-A 1-FSV -001-0022D -A	SG 3 MAIN STM HDR ISLN VLV	321X-21	NVR		729'	A02	76K38-83080	MS/V FM/V	A/B A/B	15s/100D 5MIN/100D	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
WBN-1-FSV -001-0022E	-A 1-FSV -001-0022E -A	SG 3 MAIN STM HDR ISLN VLV	321X-21	NVR		729'	A02	76K38-83080	MS/V FM/V	A/B A/B	15s/100D 5MIN/100D	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
WBN-1-FSV -001-0022F	-A 1-FSV -001-0022F -A	SG 3 MAIN STM HDR ISLN VLV	321X-21	NVR		729'	A02	76K38-83080	MS/V FM/V	B/C A/B	15s/100D 5MIN/100D	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE THE MSIV IF IN TEST MODE
WBN-1-FSV -001-0022G	-B 1-FSV -001-0022G -B	SG 3 MAIN STM HDR ISLN VLV	321X-21	NVR		729'	A02	76K38-83080	MS/V FM/V	A/B A/B	15s/100D 5MIN/100D	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
WBN-1-FSV -001-0022H	-B 1-FSV -001-0022H -B	SG 3 MAIN STM HDR ISLN VLV	321X-21	NVR		729'	A02	76K38-83080	MS/V FM/V	A/B A/B	15s/100D 5MIN/100D	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
WBN-1-FSV -001-0022J	-B 1-FSV -001-0022J -B	SG 3 MAIN STM HDR ISLN VLV	321X-21	NVR		729'	A02	76K38083080	MS/V FM/V	B/C A/B	15s/100D 5MIN/100D	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE THE MSIV IF IN TEST MODE

PAGE A-5

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE MODEL NUMBER ON EACH VALVE THROUGH TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE R.H. Loyday 6-11-86  
 CHECKER/DATE W.B. Horn 16-12-86



TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. W8NEQ-SOL -004  
 MANUFACTURER: GOULD ALLIED  
 PAGE: 5 of 6

EDIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						
W8N-1-FSV -001-0029A	-A 1-FSV -001-0029A -A	SG 4 MAIN STM HDR ISLN VLV	3211-21	SVR		729'	A01	76K38-83080	NS/V FM/V	A/B A/B	15s/100D 5MIN/100D	SOLENOIDS MUST FUNCTION TO SHUT THE NSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
W8N-1-FSV -001-0029B	-B 1-FSV -001-0029B -B	SG 4 MAIN STM HDR ISLN VLV	3211-21	SVR		729'	A01	76K38-83080	NS/V FM/V	A/B A/B	15s/100D 5MIN/100D	SOLENOIDS MUST FUNCTION TO SHUT THE NSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
W8N-1-FSV -001-0029D	-A 1-FSV -001-0029D -A	SG 4 MAIN STM HDR ISLN VLV	3211-21	SVR		729'	A01	76K38-83080	NS/V FM/V	A/B A/B	15s/100D 5MIN/100D	SOLENOIDS MUST FUNCTION TO SHUT THE NSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
W8N-1-FSV -001-0029E	-A 1-FSV -001-0029E -A	SG 4 MAIN STM HDR ISLN VLV	3211-21	SVR		729'	A01	76K38-83080	NS/V FM/V	A/B A/B	15s/100D 5MIN/100D	SOLENOIDS MUST FUNCTION TO SHUT THE NSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
W8N-1-FSV -001-0029F	-A 1-FSV -001-0029F -A	SG 4 MAIN STM HDR ISLN VLV	3211-21	SVR		729'	A01	76K38-83080	NS/V FM/V	B/C A/B	15s/100D 5MIN/100D	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE THE NSIV IF IN TEST MODE
W8N-1-FSV -001-0029G	-B 1-FSV -001-0029G -B	SG 4 MAIN STM HDR ISLN VLV	3211-21	SVR		729'	A01	76K38-83080	NS/V FM/V	A/B A/B	15s/100D 5MIN/100D	SOLENOIDS MUST FUNCTION TO SHUT THE NSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE MODEL NUMBER ON EACH VALVE THROUGH  
 TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE R.H. Jordan/6-11-88  
 CHECKER/DATE W.S. Hester/1/6/90

PAGE # 6

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WBNEQ-5DL-004  
 MANUFACTURER: GOULD ALLIED  
 PAGE: 6 OF 6

EQUIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						
WBM-1-FSV-001-0029H	-B 1-FSV-001-0029H	-B S6 4 MAIN STM HDR ISLN VLV	321X-21	SVR		729'	A01	76K38-83080	MS/V FW/V	A/B A/B	15s/100D 5MIN/100D	SOLENOIDS MUST FUNCTION TO SHUT THE MSIV'S PREVENTING THE NON-FAULTED SG'S FROM BLOWING DOWN
WBM-1-FSV-001-0029J	-B 1-FSV-001-0029J	-B S6 4 MAIN STM HDR ISLN VLV	321X-21	SVR		729'	A01	76K38-83080	MS/V FW/V	D/C A/B	15s/100D 5MIN/100D	MUST DEENERGIZE AND REMAIN DEENERGIZED TO CLOSE THE MSIV IF IN TEST MODE

PAGE A-7

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS FOUND IN TAB F.

CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE MODEL NUMBER ON EACH VALVE THROUGH  
 TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE R.H. Ladday/6-11-86 R. R. R.  
 CHECKER/DATE W.B. Hux/6-12-86

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 1 OF 30  
BINDER TITLE MSIV AIR MANIFOLD COMPUTED RKH DATE 6/4/86 R     R      
ASSEMBLY/SOLENOID VALVES-  
GOULD ALLIED CHECKED WJK DATE 6/12/86

TAB B

CHECKLIST FOR EVALUATION OF  
ENVIRONMENTAL QUALIFICATION  
INCLUDING SUMMARY AND CONCLUSION

NOTE: It is recommended that Section D - Justification/Comments (sheets 5 through 7) be closely reviewed for a clearer understanding of rationale applied towards qualification of the subject main steam isolation valves (MSIV) Air Manifold Assembly/Solenoid Valves.

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 2 OF 30

BINDER TITLE MSIV AIR MANIFOLD ASSEMBLY/SOLENOID VALVES- COMPUTED RHL DATE 6/4/86

GOULD ALLIED CHECKED WJK DATE 6/4/86

A. DOCUMENTATION

Equipment Description MSIV Air Manifold Assembly/Solenoid Valves  
Atwood & Morrill (Valve Actuator)  
Vendor/Manufacturer Chicago Fluid Power (Air Manifold Assembly)  
Gould Allied (Solenoid Valves)  
Equipment Model No.(s) 321X-21

QUALIFICATION REPORTS

- (1) Title/Number/Revision A&M Valve Actuator RIMS B70 850917 100  
Qualification Test Report/Procedure No. 201-39500/Rev. 0 DATE 5-18-79
- (2) Title/Number/Revision Wyle NEO Test Report/ RIMS B71 860514 100  
17514-1/Rev. A DATE 3-14-85
- (3) Title/Number/Revision \_\_\_\_\_ RIMS \_\_\_\_\_  
DATE \_\_\_\_\_

OTHER (ANALYSIS, VENDOR DATA, ETC.)

1. Material composition and similarity of solenoid coils (see Tab  
C/C1-C4).
2. Superheated Steam & Operational cycling calculations, and  
vendor data (see Tab C6-C10).
3. Miscellaneous documents and correspondence (see Tab E/E1-E7, and E9).
4. Tab I: Drawing No. 13824-01-H (sheets 1 thru 3).

Note: For detailed explanation of the use of test reports and other  
documentation listed above, see Section D - Justification/  
Comments (sheets 5 through 7).

PAGE B-2

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 3 OF 30

BINDER TITLE MSIV AIR MANIFOLD ASSEMBLY/SOLENOID VALVES- COMPUTED RAH DATE 9/8/86  
GOULD ALLIED CHECKED RKN DATE 9/9/86

B. CONCLUSION OF REVIEW (Check only one block)

- Equipment Qualified
- Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule
- Equipment Qualification Not Established by Documentation
- Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES See open item sheets at front of binder for detailed explanations of the articles listed below:

(1) QIREQP86038 - Missing screws at MSIV solenoid junction boxes need to be replaced.

(2) Voltage study which determines if solenoid valves have sufficient voltage available during accident conditions.

COMMENTS/RECOMMENDATIONS Equipment qualification is based primarily on similarity to test devices noted in Atwood & Morrill test procedure No. 201-39500 with supplemental justification provided in Wyle Test Report 17514-1. For detailed explanation see Section D Justification/Comments (Sheets 5 through 7).

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 4 OF 30  
 BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/14/86 R     R      
ASSEMBLY/SOLENOID VALVES-  
GOULD ALLIED CHECKED WJK DATE 6/12/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate All Documents Which are Applicable):

- Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)
- X   Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE-323-1974: "IEEE Standard for Qualifying Class 1E Equipment for Nuclear Power Generating Stations".

IEEE-344-1975: "IEEE Recommended Practices for Seismic Qualification of Class 1E Equipment for Nuclear Power Generating Stations".

IEEE-382-1972: "IEEE Trial Use Guide for Type Test of Class 1E Electric Valve Operators for Nuclear Power Generating Stations".

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 5 OF 30  
 BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHK DATE 6/11/86 R     R      
 ASSEMBLY/SOLENOID VALVES-GOULD ALLIED CHECKED WJK DATE 6/12/86

D. QUALIFICATION METHODOLOGY (Check only one block)

- Test of Identical Item Under Identical Conditions of Under Similar Conditions with Supporting Analysis
- Test of Similar Items with Supporting Analysis
- Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS

WBN Main Steam Isolation Valve (MSIV) actuators provided by Atwood and Morrill (A&M) have Chicago Fluid Power air manifold assemblies with Gould Allied solenoid valves model No. 321X-21 which are 125V DC, Class C insulation. Environmental qualification of the subject items is based primarily on similarity to Hartsville Nuclear Plant (HTN) MSIV actuators tested for A&M Procedure No. 201-39500 (see Tab D/D1). HTN MSIV actuators provided by A&M have Chicago Fluid Power air manifold assemblies with Airmatic-Allied solenoid valves model No. 321X-22\* which are 115V AC, Class C insulation. Justification for similarity to the above is noted in Tab C/C1 and C2. A detailed comparison of air manifold assemblies by means of respective instruction manuals (see Tab H [WBN] and E/E8 [HTN]) indicates that at a minimum materials are similar, and in most cases identical.

\*Gould Allied officially changed titles to Airmatic-Allied (w/both being a subsidiary to Snap-tite, Incorporated) on March 17, 1978, and relocated headquarters from Plantsville, Connecticut, to Wilmington, Ohio.

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 6 OF 30  
BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHP DATE 6/11/86 R     R      
ASSEMBLY/SOLENOID VALVES-  
GOULD ALLIED CHECKED WBT DATE 6/12/86

D. JUSTIFICATION/COMMENTS (Continued)

When A&M test data is applied to WBN environmental parameters (normal life, DBE & Post-DBE), all WBN requirements are enveloped. However, due to a very restricted thermal aging program, limiting materials (i.e., O-rings) have a qualified life of less than one year when Arrhenius equation is applied. Therefore an additional test report, WYLE NEQ 17514-1 (see Tab D/D2) is included which addresses similar air manifold assemblies that were subjected to a more extensive thermal aging program (as well as enveloping all other WBN environmental parameters). The WYLE test report is applicable to Browns Ferry Nuclear Plant (BFN) MSIV air manifold assemblies manufactured by Automatic Valve Corporation with Airmatic-Allied solenoid valves model No. V320X-XX. Three types of these solenoids were tested: 250V DC-Class H, 120V AC - Class H, and 120V AC - Class C. Similarity is justified to the 120V AC, Class C solenoid (test solenoid No. 3/test specimen No. 9A3), with exception of demonstrated voltage, and lubricant application to static seals which is justified by similarity to 250V DC Class H (test solenoid No. 1/test specimen No. 9D1), per Tab C/C2, C3, and C4 and Tab D/D2: WYLE test report 17514-1, page No. xvii, comment No. 10 & 11. Air manifold assemblies consist of mechanical valves. A detailed comparison of air manifold assemblies (less solenoid valves) indicates that materials are similar (with majority of parts being metallic) and the most limiting material is identical (O-rings: Fluorocarbon Rubber/Viton E60C per Tab D/D2: Section XVII, Table I-Aging Matrix, and Tab H: Chicago Fluid Power Service Manual DM52377 Reference Drawings). In addition WBN solenoid terminal strips (G.E. CR151B, see Tab B/Section I: item 5, page No. 17 and 18) are more compatible to WYLE-tested terminal strips (see Tab D/D2: page No. xviii, comment No. 14) than those tested by A&M.

Therefore, qualification for the items of this binder are based primarily on A&M test report No. 201-39500 with supplemental references to WYLE test report No. 17514-1 as necessary (i.e., thermal aging results, terminal strip similarity, vibration aging, and additional justification).

Additional References:

Material aging calculation reports (see Tab C/C4A - C4C).

PAGE B-6



WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 7 OF 30  
 MSIV AIR MANIFOLD  
 BINDER NO. \_\_\_\_\_ PLANT \_\_\_\_\_ UNIT(S) \_\_\_\_\_ SHEET \_\_\_\_\_ OF \_\_\_\_\_  
 R \_\_\_\_\_ R \_\_\_\_\_  
 SENSITIVE SOLENOID VALVES- COMPUTED RHK DATE 6/25/86  
 GOULD ALLIED CHECKED WJK DATE 6/25/86

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? No

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference*</u>
(1) Equipment Type	<u>Air Manifold Assembly/Solenoid Valve</u>	<u>Same</u>	<u>(1) Intro.: p 1 (2) pp XVII-10,-11,-12</u>
(2) Manufacturer	<u>Chicago Fluid Pwr/ Gould Allied</u>	<u>Same</u>	<u>(1) Intro.: p 1</u>
		<u>Automatic Valve Corp/Airmatic- Allied</u>	<u>(2) pp XVII-10,-11,-12</u>
(3) Model Number(s)	<u>321X-21</u>	<u>321X-22</u>	<u>(1): Tab C/C1</u>
		<u>V320X-XX</u>	<u>(2) pp XVI-8,-9</u>
(4) Serial Number(s)	<u>NA</u>	<u>NA</u>	<u>(1) NA</u>
		<u>Specimen</u>	<u>(2) p xxi</u>
		<u>9A3 (9D1 for O-ring w/Parker Super-O-Lube)</u>	
(5) Identify Component-Unique checksheet attached:	<u>NA</u>		

JUSTIFICATION/COMMENTS \*Note on references: References throughout

Tab B will be abbreviated as follows:

(1) - Represents Atwood & Morrill Valve Actuator Qualification Test Report/Procedure No. 201-39500/Rev. 0: Tab D/D1.

(2) - Represents WYLE NEQ Test Report/17514-1/Rev. A: Tab D/D2.

Para. - Paragraph, and Sect. - Section

BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHK DATE 6/11/86  
ASSEMBLY/SOLENOID VALVES- CHECKED WJK DATE 6/12/86  
GOULD ALLIED

**F. INSTALLATION INTERFACES**

Does the qualification program address all relevant interfaces of the equipment so that the installed design and configuration is similar or identical to the test configuration (yes/no/NA)? (note below)

<u>Interface</u>	<u>Identify Interface Requirement</u>	<u>Acceptable? (Yes/No/NA)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>None Specified</u>	<u>NA</u>	<u>(1)NA</u> <u>(1)Section 3.2, p 5</u> <u>(2)Section XVII, para. 1,3,4</u>
External Process Connections	<u>None Required</u>	<u>NA</u>	<u>(1)Section 3.2, p 5</u> <u>(2)Section I, para. 2.2.1</u>
Electrical Connections	<u>See Below</u>	<u>Yes</u>	<u>(2)p xviii, Comment 12</u>
Conduit Seals	<u>None Required/See below</u>	<u>Yes</u>	<u>(2)p xviii, Comment 12</u>
Connector Seals	<u>See Below</u>	<u>Yes</u>	<u>(1)Section 3.2, p 5</u> <u>(2)Section XVII, para. 3.5.3.1</u>
Orientation	<u>See Below</u>	<u>Yes</u>	<u>(1)NA</u> <u>(2)p I-13, Fig. I-2</u>
Physical Configuration	<u>See Below</u>	<u>Yes</u>	
Other	<u>Supply Air Pressure: 90-100 psig</u>	<u>Yes</u>	<u>(1)Section 3.2</u>

JUSTIFICATION/COMMENTS: The three test solenoids were electrically connected (flexible conduit with 1" NPT conduit fitting) through a NEMA 4 junction box which houses a terminal strip ((2) pg. No. I-12, Figure I-1). Solenoid assembly was mounted at a 45° angle (with conduit hub directed downward) to simulate worst case in-service mounting. A 1/4" hole at the lowest point of the junction box eliminates conduit seal requirements. WBN MSIV solenoids are housed within a NEMA 4 junction box with terminal strips housed in an adjoining junction block (See Tab H, Drawing No. CFP-305C). As a result of Tab E/E4, WBN electrical connections include Conax conduit seals\* (see Tab F and Binder WBNEQ-CSC-001). Solenoid assembly is mounted at a 45° angle (with conduit hub directed upward). Weep hole requirements are met per TAB G, Section A, item 3. Wyle BFN test set-up was a worst case installation therefore, WBN installation based on being similar and less severe is acceptable.

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 9 OF 30

BINDER TITLE MSIV AIR MANIFOLD ASSEMBLY/SOLENOID VALVES- COMPUTED RAK DATE 6/14/86 R     R    

GOULD ALLIED CHECKED RAK DATE 6/12/86

G. TEST SEQUENCE

(1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	(2)Sect. I, para. 1.1;(1) No*
(b) Baseline performance measurements taken	<u>Yes</u>	(1)Sect. 3.2, 4.0,6.0, 9.0,10.0; (2)Sect. I, para 1.4
(c) Equipment aged:		
Thermal	<u>Yes</u>	(1)Sect. 3.5, 6.0; (2)Sect. VI, para 2.0
Radiation	<u>Yes</u>	(1)Sect. 3.4, 5.0; (2)Sect. II, para 1.0; Sect. IV, para 1.0
Wear	<u>Yes</u>	(1)Sect. 3.3,4.0; (2)Sect. VII, para 1.0
(d) Vibration/seismic testing conducted	<u>Yes</u>	(1)Sect. 3.6,3.7,3.8 7.0,8.0, & 9.0; (2)Sect. XI
(e) Design basis event (DBE) exposure	<u>Yes</u>	(1)Sect. 3.9, 10.0; (2)Sect. XIV, XV
(f) Post-DBE exposure	<u>Yes</u>	(1)Sect. 3.9, 10.0; (2)Sect. XIV, XV (1)Results, p 3; (2)Sect. XVII,
(g) Final inspection and disassembly	<u>Yes</u>	para. 3.6 & 3.7, Sect XVI, para 1.0

(2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes (w/exception of items 2 and 4, p. 10.)

(3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes  
(Reference (1)Section 1.0; (2)See Instrumentation Equipment sheets in appendices of sections referenced above .)

JUSTIFICATION/COMMENTS \*(1)IEEE-323-1974, paragraph 6.3.2 states

"Inspection may be performed to assure that a test unit has not been damaged due to handling..."; therefore, this is constituted as a precautionary measure and not an actual requirement.

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 10 OF 30  
BINDER TITLE MSIV AIR MANIFOLD ASSEMBLY/SOLENOID VALVES- COMPUTED RHK DATE 6/25/86 R     R      
GOULD ALLIED CHECKED WPK DATE 6/25/86

G. TEST SEQUENCE (Continued)

(2) Wear aging was the first phase of the test sequence. Upon completion of the 39th test interval and prior to start-up of the 40th test interval (simulating the 40th-year of service), all non-metallics were replaced, and three solenoid valves were replaced due to noise emanating from air control panel assembly. Since normal hands-on maintenance was allowed between each interval, the replacement of seals and solenoids is considered to be normal maintenance procedures. No piece replacements of equipment were required for the duration of all remaining phases of the test sequence.

(3) In reference to G(1) Test Sequence: Section XVII of Wyle test report 17514-1 ((2) p. 10) established qualification sequence.

(4) 40-Year life could not be achieved due to problems experienced during Post-Radiation functional test. New solenoid test sets (specimens 9A and 9D) with revised 10-year and 5-year equivalent radiation exposure plus accident dose were subjected to baseline functional and radiation testing ((2) Notice of Anomaly No. 3 and 3, Rev. A; page No. iii of Wyle test report 17514-1). 120V AC Class C solenoid valve (test specimen 9A3) was used throughout the test sequence and is qualified for a 10-year life (see note).

Note: Qualified life figures referenced above are based on meeting BFN environmental parameters; for equivalency to WBN requirements see TAB C/C4A-C4C.

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 11 OF 30  
 BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/4/86  
ASSEMBLY/SOLENOID VALVES- R R  
GOULD ALLIED CHECKED WPK DATE 6/12/86

H. AGING

- (1) Was aging considered in the qualification program (Yes/no/NA)? Yes (Reference (1) Section 3.1 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	(1)Sect. 3.5,6.0 (2)Sect. XVII: para. 3.4 & App. I & II
Radiation exposure	<u>Yes</u>	(1)Sect. 3.4, 5.0 (2)Sect XVII, para. 3.4.12
Vibration (non-seismic) aging	<u>Yes</u>	& 3.5.1,2,2 (1)Sect. 3.3,
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	4.0

JUSTIFICATION/COMMENTS A&M report yielded limiting thermal aging data; therefore, more extensive WYLE thermal aging results were used. In addition, WYLE vibration aging is used since A&M test results did not include these effects.

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? NA (Reference --- ).

JUSTIFICATION/COMMENTS No known synergistic effects have been reported for the materials applicable to the subject devices with the exception of silicone rubber (lead wire insulation) as noted: Dose rate synergisms have been reported as minor in NUREG/CR-2763 and were observed to have no significant impact on qualification.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program (yes/no/NA)? Yes (Reference (2)Sect. XVII; para. 3.4 and App. I & II ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 12 OF 30

BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/11/86 R      R     

ASSEMBLY/SOLENOID VALVES-  
GOULD ALLIED CHECKED WBR DATE 6/12/86

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes (Reference: See Below ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

(2) Section XVII/para. 3.4.4.1-3.4.4.7, 3.4.1, 3.4.2, Table I (aging matrix), and II.

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference See Below ).

JUSTIFICATION/COMMENTS (2) Section XVII/Appendix I.

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference See Below ).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature		125°C+38°C	
		Rise	See Tab C/
	130°F+58°C	120°C+38°C	C4A-C4C
Coil Heat Rise		Rise	(C4B: Coil
		2407H(120°C)	Heat Rise)
Time		95H	Material
	40 Years	(125°C)	Aging Rpt

JUSTIFICATION/COMMENTS (2) Section XVII/Appendix I and II

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference See Sect. H(4)(d) above ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? Yes (Reference See Below ).

JUSTIFICATION/COMMENTS (2) Section XVII/Table III Reference list and para. 3.4.3.



BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 14 OF 30

BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHK DATE 6/11/86 R     R    

ASSEMBLY/SOLENOID VALVES-  
GOULD ALLIED CHECKED WJK DATE 6/12/86

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (yes/no/NA)? Yes (Reference (1) Sect. 3.4.5.0, Appendix A (pg. 50) ).

Plant normal ambient radiation dose (rd) 3  
\*1.8x10 (Total 40-yr integrated)

Test exposure dose (rd) 1.74x10<sup>7</sup>

Test exposure dose rate (rd/hr) 0.5 Mrd/hr.

Test exposure source type (e.g., Co-60 gamma) Cobalt 60 gamma

JUSTIFICATION/COMMENTS \*See TAB E/E9

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference See below ).

JUSTIFICATION/COMMENTS (2) Section XVII/para. 3.4.12 and 3.5.1.2.2.

- (b) Was the basis for vibration aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference See below ).

JUSTIFICATION/COMMENTS (2) Section XVII/para. 2.1.3.1.1, 3.4.12, and 3.5.1.2.2.

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference (1) Sect. 3.3, 3.5, 3.9, 4.0, 5.0, 6.0, & 10.0 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_



BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 15 OF 30  
 BINDER TITLE MSIV AIR MANIFOLD ASSEMBLY/SOLENOID VALVES- COMPUTED PHL DATE 6/11/86  
GOULD ALLIED CHECKED WJK DATE 6/12/86

H. AGING (Continued)

(b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference (1) Sect. 3.3 and 3.5 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

(8) Was the qualified life of the equipment and its basis defined in the qualification program (yes/no/NA)? Yes  
 (Reference (2) Page xxi & Section XVII, App. II/para. 1.1.3

Qualified life (Document in QMDS) 12 years (normally energized solenoids), 40 years (exerciser solenoids, air manifold assembly-mechanical valves, and terminal strips only) - see TAB G.

JUSTIFICATION/COMMENTS See Tab C/C4A-C4C for WBN equivalency to BFN WYLE test results.

(9) Were replacement intervals for the equipment or its components defined in the qualification program (yes/no/NA)? Yes  
 (Reference (2) pg. No. xxi ).

Replacement Intervals (Document in QMDS) Total change-out of solenoid valves is required every 12 years with the exception of exerciser test FSVs, air manifold assembly-mechanical valves, and terminal strips which are qualified for 40 years.

JUSTIFICATION/COMMENTS See Tab C/C4A-C4C for WBN equivalency to BFN WYLE test results.

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 16 OF 30

BINDER TITLE MSIV AIR MANIFOLD COMPUTED PHL DATE 6/10/86 R     R      
ASSEMBLY/SOLENOID VALVES-

GOULD ALLIED CHECKED WPK DATE 6/12/86

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of EQC Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>Ryton R-4/Mechanical/ Bobbin</u>	<u><math>5 \times 10^8</math></u>	<u>See Below</u>	<u>1.00</u>	<u>See Below</u>
(b) <u>Silicone Rubber/Mechanical/ Insulation</u>	<u><math>1 \times 10^6</math></u>	<u>See Below</u>	<u>1.44</u>	<u>See Below</u>
(c) <u>Viton/Mechanical/Seal</u>	<u><math>5 \times 10^6</math></u>	<u>See Below</u>	<u>1.16</u>	<u>See Below</u>
(d) <u>Prye-ML/Electrical/ Insulation</u>	<u><math>1.5 \times 10^8</math></u>	<u>See Below</u>	<u>1.42</u>	<u>See Below</u>
(e) <u>Phenolic/Electrical/ Terminal Strip</u>	<u><math>3.8 \times 10^5</math></u>	<u>See Below</u>	<u>1.06</u>	<u>See Below</u>
(f) <u>Silicone/Electrical/ Varnish</u>	<u><math>1 \times 10^8</math></u>	<u>See Below</u>	<u>1.25</u>	<u>See Below</u>
(g) <u>Polymide/Mechanical/ Winding Cover</u>	<u><math>1.5 \times 10^8</math></u>	<u>See Below</u>	<u>1.73</u>	<u>See Below</u>

JUSTIFICATION/COMMENTS Reference: Digital Engineering System 1000  
"Materials Aging & Radiation Effects Library" (see Tab C/C4A-C4C for  
detailed materials analysis calculation).

- (1) Gasket material was not addressed in materials analysis since its degra-  
ation does not affect operability of the solenoid valves ((2) page No. xv  
comment 2). The gaskets serve as a seal between the pilot exhaust  
tube nut and junction box cover, and between the junction box  
(which houses the solenoid valves), junction box cover and the dump  
valve assembly (see Tab H, dwg. No. CFP-305-C for exploded view).  
Failure of the gaskets would not result in moisture or liquid intrusion  
(see Tab C/C5). Material composition of the gaskets is primarily

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 17 OF 30  
BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/11/86 R     R      
ASSEMBLY/SOLENOID VALVES-  
GOULD ALLIED CHECKED WJA DATE 6/12/86

I. MATERIALS ANALYSIS

JUSTIFICATION/COMMENTS (Continued)

asbestos with neoprene acting as a binder. Because  
asbestos is inorganic and considered not to be age-sensitive, it could  
still provide a marginal level of sealing at a minimum (even though  
sealing is not required - (2) page No. xviii, comment 12 for  
justification.)

- (2) Electrical tape (Scotch brand #69 Glass Cloth - per Tab C/C1) was not  
addressed in materials analysis since its degradation/failure is not con-  
sidered detrimental to the safety function of the solenoids  
((2) Section XVII/para. 3.4.4.7, and Table I; item No 1.24.2.1.3).
- (3) Although WBN solenoid valves are comprised of the same materials as  
those solenoids (specimen 9A and 9D) tested at Wyle Labs, lower activa-  
tion energies were applied to the most limiting materials in order to  
factor a degree of conservatism into the comparative results (see Tab  
C/C4A-C4C).
- (4) Bobbin material is not significant, as failure of this component is judged  
to not adversely affect the safety-related function of the solenoids  
((2) Section XVII, Appendix II, para. 1.1.3).
- (5) Visual inspections and per telecon with Richard Mills of Chicago Fluid  
Power on September 26, 1985, indicate that General Electric CR151B

PAGE B-17

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 18 OF 30  
MSIV AIR MANIFOLD COMPUTED RAK DATE 4/25/86 R     R      
~~SENSITIVE~~ SOLENOID VALVES- CHECKED WJR DATE 6/25/86  
GOULD ALLIED

I. MATERIALS ANALYSIS

JUSTIFICATION/COMMENTS (Continued)

terminal strips were supplied in WBN MSIV solenoid junction blocks. Per GE  
letter dated Feb. 24, 1978 (See Tab E/E5), these terminal strips are  
comprised of the same materials as noted by Wyle Labs for a G.E. CR151A  
terminal strip (which was qualified based on similarity to a tested Square  
D KC-1 terminal strip - (2) pg. No. xviii, comment No. 14). Test  
results were applied to a conservative terminal strip activation energy  
of 1.06 (See Tab C/C4C).

- (6) Per Tab H/Chicago Fluid Power drawings: Air manifold assembly/solenoid  
valves contain O-rings and seals which are comprised of either DuPont Viton  
E-60C or 3M Flourel 2170. Since both materials are fluorocarbon rubber,  
Wyle Labs assumed Viton E-60C with an activation energy of 1.18 as the  
worst case (see (2) Section XVII, para. 3.4.4.1). As it has been  
determined that Viton E-60C has a lower activation energy than 3M Flourel  
(1.16 vs. 1.26, see Tab C/C4C: sheets 8 and 8A); Viton E-60C shall be the  
most limiting O-ring/seal material.

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 19 OF 30  
 BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/11/86  
ASSEMBLY/SOLENOID VALVES- CHECKED WJR DATE 6/12/86  
GOULD ALLIED

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference (1)Section 3.2 ).

Identify Acceptance Criteria: Test parameters recorded during test sequence were compared against set limits; but if operation of valve actuator was not affected, failure to meet these limits would not be considered essential.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference (1)Section 3.2 )

Identify baseline and functional testing: \_\_\_\_\_

Valve Closing Time: 3 to 5 seconds

Valve Opening Time: 6.5 to 19.5 seconds

Pneumatic System Leakage (valve open or closed): .5 SCFH max.

JUSTIFICATION/COMMENTS Exhaust pressures and times were measured during all subsequent functional tests ((1)Section 4.0, 5.0, 6.0, 9.0, and 10.0).

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes (Reference (1)Sect. 3.2, last para. ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 20 OF 30

BINDER TITLE MSIV AIR MANIFOLD ASSEMBLY/SOLENOID VALVES- COMPUTED RAL DATE 6/11/86 R     R    

GOULD ALLIED CHECKED WJK DATE 6/12/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

(4) Do the applied loads during baseline testing reflect normal operating conditions (yes/no/NA)? Yes (Reference (1) Sect. 3.2).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

(5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) <u>Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference</u>
Voltage	<u>**later</u>	_____
Load	<u>NA</u>	_____
Frequency	<u>NA</u>	_____
Accuracy	<u>NA</u>	_____
<u>Other(s)</u>	_____	_____

JUSTIFICATION/COMMENTS \*\*Per OE calculation (later), see Tab E/E6.  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 22 OF 30

BINDER TITLE MSIV AIR MANIFOLD ASSEMBLY/SOLENOID VALVES- COMPUTED RHK DATE 9/8/86 R     R    

GOULD ALLIED CHECKED RKCN DATE 9/9/86

**K. REQUIRED OPERATING ENVIRONMENT**

Reference Environmental Drawing No. 47E235-76 R3 (Tab E/E2); \*OE Calculation, See Tab E/E9.

- |                                      |                                 |
|--------------------------------------|---------------------------------|
| (1) Normal Max                       | (2) Abnormal Max                |
| (a) Temperature (°F) <u>130</u>      | (a) Temperature (°F) <u>140</u> |
| (b) Pressure (psig) <u>Atm(-)</u>    | (b) Pressure (psig) <u>Atm</u>  |
| (c) Humidity (%) <u>50</u>           | (c) Humidity (%) <u>100</u>     |
| (d) Radiation (rd) <u>1.8x10 TID</u> | (d) Radiation (rd) <u>NA</u>    |

(3) Process Interfaces: Main steam design process temperature = 600°F;  
valve body and stem configuration eliminate significant additional  
thermal effects which could degrade solenoid components beyond ambient  
conditions.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Will exist up to 8 hours per excursion and will occur less than 1% of the plant life. Humidity only: could exist up to 8 hours and return to normal max of 50% RH in 8 hour period linearly. This condition should occur no more than twice during plant life.

- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- |   |                           |
|---|---------------------------|
| (a) Temperature (°F) <u>325**</u>       | Accident type <u>HELB</u> |
| (b) Pressure (psig) <u>25.18 psia**</u> | Accident type <u>HELB</u> |
| (c) Humidity (%) <u>100**</u>           | Accident type <u>HELB</u> |
| (d) Radiation (rd) <u>NA</u>            | Accident type <u>HELB</u> |
| (e) Spray Type <u>NA</u>                | Accident type <u>NA</u>   |

\*\*See Required Operating Environment on next page.



BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 23 OF 30  
 BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 9/8/86 R     R      
ASSEMBLY/SOLENOID VALVES-  
GOULD ALLIED CHECKED RKW DATE 9/9/86

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.):

\*\*See TVA drawing No. 47E235-76R3 for duration and profiles (Tab E/E2),  
and Tab C/C8 and E/E1 for temperature justification during a main steam  
line break/superheated steam condition. Valves are required to operate  
during an HELB outside containment accident only; therefore,  $1 \times 10^4$  rd  
LOCA radiation dose is not applicable.

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (yes/no/NA)? No (Reference Tab C/C5 ).

(7) Subject to submergence (yes/no/NA)? No  
 (Reference OE Calculation, see Tab E/E7 ).

Identify initiation time and duration of submergence: Maximum flood  
level in steam valve vault will not exceed EL 730.87. MSIV air mani-  
fold assembly lowest elevation is EL 742.0; therefore, submergence is  
not applicable (see Tab F for reference to elevation).

(8) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
<u>Temperature (main steam line</u>	<u>B45 851112 218</u>
<u>break only): WBNOSG4-003</u>	<u>(See Tab C/C8)</u>
<u>&amp; QIRNEB85044</u>	<u>B45 850719 257</u>
<u>_____</u>	<u>(See Tab E/E1)</u>
<u>40 year radiation dose:</u>	<u>B45 860401 235</u>
<u>WBNNAL3-025</u>	<u>(See Tab E/E9)</u>

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 24 OF 30  
 BINDER TITLE MSIV AIR MANIFOLD COMPUTED RAL DATE 6/11/86 R     R      
ASSEMBLY/SOLENOID VALVES-  
GOULD ALLIED CHECKED WAL DATE 6/12/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	FW/V: 5 min. MS/V: 15 sec	1 hour	(1) Figure 5, pg. 56; Tab C/C4C
Temperature (°F)	***380 (25.18-14.7)	***398	(1) Figure 5; Tab C/C9, C10; Tab C/C8 (MS/V only)
Pressure (psig)	= 10.48	110	(1) Sect. 3.2, Tab C/C9
Relative Humidity (%)	100@24hrs	100 @ 10 Days	(1) Figure 5, Tab C/C9
*Chemical Spray	NA	NA	--
**Radiation (rd)	1.8x10 <sup>3</sup> (gamma)	1.74x10 <sup>7</sup>	(1) Sect. 3.4, App. A pg. 50
Submergence	NA	NA	--

\*Includes spray concentration, flowrate, density, duration, and pH.

\*\*Enter 40-year integrated normal dose plus integrated accident dose and specify type.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	Yes	See Sect.
Pressure	Yes	L.(1) Ref
Relative Humidity	Yes	above
Chemical Spray	NA	
Submergence	NA	

JUSTIFICATION/COMMENTS Sect. L.(1) Radiation: Beta contributions not considered during testing since solenoid valves are sufficiently shielded by a junction box comprised of cold rolled steel. Beta dose is not applicable to the subject devices, as they are not required to operate during a LOCA and are located outside of containment.

\*\*\*Specified and demonstrated temperatures include coil heat rise: See Tab C/C4B, items B and C.



BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 26 OF 30  
 BINDER TITLE MSIV AIR MANIFOLD COMPUTED RAH DATE 6/11/86 R     R      
ASSEMBLY/SOLENOID VALVES-  
GOULD ALLIED CHECKED WJK DATE 6/12/86

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:  
 (Reference See Tab A and Tab E/E3 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes  
 (Reference (1)Section 10.0 ).

JUSTIFICATION/COMMENTS Valves are required to de-energize 5 min. into an Feedwater line break and 15 sec. into a Main Steam line break (ref. M(1)). Valves were operated every 10 min. during the first hour of test.

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? Yes  
 (Reference (1)Figure 5 ).

JUSTIFICATION/COMMENTS During Post-DBE the solenoids are not required to operate but must not fail in a manner detrimental to plant safety (ref. M(1)). Since DBE test conditions envelope actual Post-DBE requirements, this criteria has been met (see TAB C/C4C).

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? Yes (Reference (1)Section 10.0 ).

JUSTIFICATION/COMMENTS See M.(2) above.

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? Yes (Reference (1) Results, pg. 2 and 3; (2)p iii through xix ).

JUSTIFICATION/COMMENTS We have reviewed and concur with the disposition of anomalies documented in the reference (1) and (2) test reports. There is no impact on installed equipment; however, Tab G documents those findings which resulted in maintenance activities for corrective action.



BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 28 OF 30  
 BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/4/86  
ASSEMBLY/SOLENOID VALVES- CHECKED WHL DATE 6/12/86  
GOULD ALLIED

0. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
(1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
(2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>No</u>
(3) Choice of qualification methodology adequately justified?	<u>Yes</u>
(4) If analysis was performed, complete the following:	
(a) Were equipment performance requirements identified?	<u>Yes</u>
(b) Were specific features and failure modes and effects analyzed?	<u>Yes</u>
(c) Were assumptions and mathematical models used together with appropriate justification for their use?	<u>Yes</u>
(d) Were environmental parameters which affect equipment performance identified?	<u>Yes</u>
(5) Adequate similarity between equipment and test specimen established?	<u>Yes</u>
(6) Aging degradation evaluated adequately?	<u>Yes</u>
(a) Mechanical and/or cycle aging addressed?	<u>Yes</u>
(b) Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes</u>
(c) Absence of preaging in test/analysis justified?	<u>NA</u>
(d) Materials susceptible to thermal/radiation aging identified?	<u>Yes</u>

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 29 OF 30  
 BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/11/86 R     R      
ASSEMBLY/SOLENOID VALVES-  
GOULD ALLIED CHECKED WJK DATE 6/12/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>NA</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>NA</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>NA</u>
(11) Criteria regarding submergence satisfied?	<u>NA</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>NA</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

BINDER NO. WBNEQ-SOL-004 PLANT WBN UNIT(S) 1 SHEET 30 OF 30

BINDER TITLE MSIV AIR MANIFOLD COMPUTED RHL DATE 6/11/86  
ASSEMBLY/SOLENOID VALVES- R R

GOULD ALLIED CHECKED WPK DATE 6/12/86

O. SUMMARY OF REVIEW (Continued)

Yes/No/NA

- (15) Criteria regarding functional testing satisfied? Yes
- (a) Does the test plan/report specify an acceptance criteria for equipment performed? Yes
- (b) Was an initial base line test done to establish required performance characteristics? Yes
- (c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? Yes
- (16) Criteria regarding instrument accuracy satisfied? NA
- (17) Test duration margin (1 hour + function time) satisfied? Yes
- (a) Is the minimum specified operating time at least 1 hour? Yes
- (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided? NA
- (18) Criteria regarding synergistic effects satisfied? Yes
- (19) Criteria regarding margins satisfied? Yes
- (20) Maintenance and surveillance requirements adequately identified? Yes

P. DISCUSSION

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WBNEQ-SOL -005  
 MANUFACTURER: ASCO  
 PAGE: 1 OF 5

EQUIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						RH/RAD
WBN-1-FSV -030-0146A	-A 1-FSV -030-0146A	-A AUX BLDG GAS TMT FAN A-A SUCT DMPR	206-380-2RVU			737'	A05	80KJ3-827551	L	A	100D	SOLENOIDS ARE ACTUATED BY AN ABI SIGNAL AND ARE REQUIRED TO BE OPERABLE DURING THE MITIGATION OF THIS EVENT.
WBN-1-FSV -030-0146B	-A 1-FSV -030-0146B	-A AUX BLDG GAS TMT FAN A-A SUCT DMPR	206-380-2RVU			737'	A05	80KJ3-827551	L	A	100D	SOLENOIDS ARE ACTUATED BY AN ABI SIGNAL AND ARE REQUIRED TO BE OPERABLE DURING THE MITIGATION OF THIS EVENT.
WBN-2-FSV -030-0157A	-B 2-FSV -030-0157A	-B AUX BLDG GAS TMT FAN A-A EXH DMPR	206-380-2RVU			737'	A09	80KJ3-827551	L	A	100D	SOLENOIDS ARE ACTUATED BY AN ABI SIGNAL AND ARE REQUIRED TO BE OPERABLE DURING THE MITIGATION OF THIS EVENT.
WBN-2-FSV -030-0157B	-B 2-FSV -030-0157B	-B AUX BLDG GAS TMT FAN B-B SUCT	206-380-2RVU			737'	A09	80KJ3-827551	L	A	100D	SOLENOIDS ARE ACTUATED BY AN ABI SIGNAL AND ARE REQUIRED TO BE OPERABLE DURING THE MITIGATION OF THIS EVENT.
WBN-1-FSV -032-0080A	-A 1-FSV -032-0080A	-A REACTOR BLDG UNIT 1 TRAIN A ISLN	206-380-3RU	282	730'	ANN	78K3-822950		L	A/B	5MIN/100D	SOLENOIDS MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED AFTER A PHASE B ISOLATION SIGNAL IS RECEIVED AND RESET

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

REFERENCE WATTS BAR CAT & OPERATING TIME CALCULATIONS WBN0564-008 REV 10, WBN0564-010 REV 3, WBN0564-015 REV 7 AND WBN0564-016 REV 8.

PREPARER/DATE

*[Handwritten Signature]*  
 8/20/86

CHECKER/DATE

*[Handwritten Signature]*  
 8/20/86

R \_\_\_\_\_ R \_\_\_\_\_ R \_\_\_\_\_

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WBNQ-SOL-005  
 MANUFACTURER: ASCO  
 PAGE: 2 OF 5

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*					
WBN-1-FSV -032-0080B	-A 1-FSV -032-0080B	-A REACTOR BLDG UNIT 1 TEST SOL	206-380-2RU	282	730'	ANN	80KJ3-827551	L	B	100D	SOLENOID FAILURE MUST NOT CAUSE ASSOCIATED CNTMT
								MS/C	B	100D	ISOL VALVE TO OPEN AFTER A
								FW/C	B	100D	PHASE B ISOLATION SIGNAL
								RH/C	B	1MD	IS RECEIVED AND RESET
								CV/C	B	1MD	
WBN-1-FSV -032-0102A	-B 1-FSV -032-0102A	-B REACTOR BLDG UNIT 1 TRAIN B ISLN	206-380-3RU	300	716'	ANN	78K3-822950	L	A/B	5MIN/100D	SOLENOIDS MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED
								MS/C	A/B	5MIN/100D	AFTER A PHASE B ISOLATION
								FW/C	A/B	5MIN/100D	SIGNAL IS RECEIVED AND
								RH/C	A/B	15MIN/1MD	RESET
								CV/C	A/B	1HR/1MD	
WBN-1-FSV -032-0102B	-B 1-FSV -032-0102B	-B REACTOR BLDG UNIT 1 TEST SOL	206-380-2RU	300	716'	ANN	80KJ3-827551	L	B	100D	SOLENOID FAILURE MUST NOT CAUSE ASSOCIATED CNTMT
								MS/C	B	100D	ISLN VLV TO OPEN AFTER A
								FW/C	B	100D	PHASE B ISOLATION SIGNAL
								RH/C	B	1MD	IS RECEIVED AND RESET
								CV/C	B	1MD	
WBN-1-FSV -032-0110A	-A 1-FSV -032-0110A	-A RB UNIT 1 NON-ESNTL CONT AIR ISLN	206-308-2RU	295	725'	ANN	80KJ3-827551	L	A/B	5MIN/100D	SOLENOIDS MUST DE-ENERGIZE AND REMAIN DE-ENERGIZED
								MS/C	A/B	5MIN/100D	AFTER A PHASE B ISOLATION
								FW/C	A/B	5MIN/100D	SIGNAL IS RECEIVED AND
								RH/C	A/B	15MIN/1MD	RESET
								CV/C	A/B	1HR/1MD	
WBN-1-FSV -032-0110B	-A 1-FSV -032-0110B	-A RB UNIT 1 NON-ESNTL CONT AIR ISLN	206-380-3RU	295	725'	ANN	78K3-822950	L	B	100D	SOLENOID FAILURE MUST NOT CAUSE ASSOCIATED CNTMT
								MS/C	B	100D	ISLN VLV TO OPEN AFTER A
								FW/C	B	100D	PHASE B ISOLATION SIGNAL
								RH/C	B	1MD	IS RECEIVED AND RESET
								CV/C	B	1MD	

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH  
 TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PAGE A-2

PREPARER/DATE

CHECKER/DATE

*Rand...*  
*W.B....*

R \_\_\_\_\_ R \_\_\_\_\_ R \_\_\_\_\_

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WBNQ-SOL-005  
 MANUFACTURER: ASCO  
 PAGE: 3 OF 5

EBIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						
WBN-0-FSV -065-0024	-A 0-FSV -065-0024	-A EGTS TRAIN A FAN A-A ISLN DMPR	206-380-2RU			757'	A16	80KJ3-827551	L	A	100D	SOLENOIDS MUST OPEN AND REMAIN OPEN ON A PHASE A ISOLATION SIGNAL
WBN-0-FSV -065-0043	-B 0-FSV -065-0043	-B EGTS TRAIN B FAN B-B ISLN DMPR	206-380-2RU			757'	A16	80KJ3-827551	L	A	100D	SOLENOIDS MUST OPEN AND REMAIN OPEN ON A PHASE A ISOLATION SIGNAL
WBN-2-FSV -067-0336	-A 2-FSV -067-0336	-A EMERG GAS TRTMT ROOM COOLER A ICR	206-380-2RU			757'	A16	80KJ3-827551	L	A	100D	MUST OPERATE TO SUPPORT OPERATION OF EGTS & PEN ROOM COOLERS
									RH/A	A	1MO	
									AF/A	A	1MO	
									AB/A	A	1MO	
WBN-2-FSV -067-0338	-B 2-FSV -067-0338	-B EMERG GAS TRTMT ROOM COOLER B ICR	206-308-2RU			757'	A16	80KJ3-827551	L	A	100D	MUST OPERATE TO SUPPORT OPERATION OF EGTS & PEN ROOM COOLERS
									RH/A	A	1MO	
									AF/A	A	1MO	
									AB/A	A	1MO	
WBN-1-FSV -067-0350	-A 1-FSV -067-0350	-A PEN RM CLR A2 SUP CNTL VLV	206-380-2RU			713'	A06	80KJ3-827551	L	A	100D	SOLENOIDS MUST FUNCTION TO PROVIDE FLOW TO COOLERS WHICH SERVE ESF EQUIPMENT
									RH/A	A	1MO	
									CV/A	A	1MO	
									AF/A	A	1MO	
WBN-2-FSV -067-0350	-A 2-FSV -067-0350	-A PEN RM CLR A2 SUP CNTL VLV	206-380-2RU			713'	A19	80KJ3-827551	L	A	100D	SOLENOIDS MUST FUNCTION TO PROVIDE FLOW TO COOLERS WHICH SERVE ESF EQUIPMENT.
									RH/A	A	1MO	
									CV/A	A	1MO	
									AF/A	A	1MO	

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PAGE A-3

REFERENCE WATTS BAR CAT & OPERATING TIME CALCULATIONS WBN0564-008 REV 10, WBN0564-010 REV 3, WBN0564-015 REV 7 AND WBN0564-016 REV 8.

PREPARER/DATE

CHECKER/DATE

*[Handwritten Signature]*  
 8/27/86

R\_\_\_\_\_ R\_\_\_\_\_ R\_\_\_\_\_

SOL-005

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WBNEQ-SOL -005  
 MANUFACTURER: ASCO  
 PAGE: 4 OF 5

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION				CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*	RH/RAD					
WBN-1-FSV -067-0352	-B 1-FSV -067-0352	-B PEN RM CLR B2 SUP CNTL VLV	206-380-2RU			713'	A06	80KJ3-827551	L RH/A CV/A AF/A AB	A A A A A	100D 1MD 1MD 1MD 1MD	SOLENOIDS MUST FUNCTION TO PROVIDE FLOW TO COOLERS WHICH SERVE ESF EQUIPMENT
WBN-2-FSV -067-0352	-B 2-FSV -067-0352	-B PEN RM CLR B2 SUP CNTL VLV	206-380-2RU			713'	A19	80KJ3-827551	L RH/A CV/A AF/A AB	A A A A A	100D 1MD 1MD 1MD 1MD	SOLENOIDS MUST FUNCTION TO PROVIDE FLOW TO COOLERS WHICH SERVE ESF EQUIPMENT.
WBN-1-FSV -067-0354	-A 1-FSV -067-0354	-A PEN RM CLR A3 SUP CNTL VLV	206-380-2RU			737'	A05	80KJ3-827551	L RH/A CV/A AF/A AB	A A A A A	100D 1MD 1MD 1MD 1MD	SOLENOIDS MUST FUNCTION TO PROVIDE FLOW TO COOLERS WHICH SERVE ESF EQUIPMENT
WBN-2-FSV -067-0354	-A 2-FSV -067-0354	-A PEN RM CLR A3 SUP CNTL VLV	206-380-2RU			737'	A09	80KJ3-827551	L RH/C CV/A AF/A AB	A A A A A	100D 1MD 1MD 1MD 1MD	SOLENOIDS MUST FUNCTION TO PROVIDE FLOW TO COOLERS WHICH SERVE ESF EQUIPMENT
WBN-1-FSV -067-0356	-B 1-FSV -067-0356	-B PEN RM CLR B3 SUP CNTL VLV	206-380-2RU			737'	A05	80KJ3-827551	L RH/A CV/A AF/A AB	A A A A A	100D 1MD 1MD 1MD 1MD	SOLENOIDS MUST FUNCTION TO PROVIDE FLOW TO COOLERS WHICH SERVE ESF EQUIPMENT

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH  
 TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PAGE A-4

PREPARER/DATE

CHECKER/DATE

*[Handwritten Signature]* R\_\_\_\_ R\_\_\_\_ R\_\_\_\_  
 1/27/88

REFER TO TABS BAR CAT & OPERATING TIME CALCULATIONS WBN0SG4-008 REV 10, WBN0SG4-010 REV 3, WBN0SG4-011 REV 1 AND WBN0SG4-016 REV 8.

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WBN00-SGL-005  
 MANUFACTURER: ASCO  
 PAGE: 5 OF 5

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	-----LOCATION-----				CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*	RM/RAD					
WBN-2-FSV -067-0356	-B 2-FSV -067-0356	-B PEN RM CLR B3 SUP CNTL VLV	206-380-2RU			737'	A09	86KJ3-B27551	L	A	100D	SOLENOIDS MUST FUNCTION TO PROVIDE FLOW TO COOLERS WHICH SERVE ESF EQUIPMENT
									RH/C	A	1MO	
									CV/A	A	1MO	
									AF/A	A	1MO	
									AB	A	1MO	

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PAGE A-5

REFERENCE WATTS BAR CAT & OPERATING TIME CALCULATIONS WBN0564-008 REV 10, WBN0564-010 REV 3, WBN0564-015 REV 7 AND WBN0564-016 REV 8.

PREPARER/DATE

CHECKER/DATE

*[Handwritten signatures and dates]*  
 8/27/06  
 8/27/06

R\_\_\_\_\_ R\_\_\_\_\_ R\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

TAB B

ENVIRONMENTAL QUALIFICATION CHECKLIST

NOTE: The units common, 1 and 2 solenoid valves covered by this binder are required for Unit 1 operation.

EQP098.51

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 1 OF 27  
 BINDER TITLE ASCO SOLENOID COMPUTED RF DATE 8/28/86 R     R      
 VALVES, MODEL NO. 206-380-SERIES CHECKED WPK DATE 8/28/86  
 (AC CONSTRUCTION)

A. DOCUMENTATION

Equipment Description Solenoid Valves  
 Vendor/Manufacturer Automatic Switch Company (ASCO)  
 Equipment Model No.(s) 206-380-2RVU  
206-380-3RU  
206-380-2RU

QUALIFICATION REPORTS

- (1) Title/Number/Revision "Equipment Qualification RIMS NEB840925351 Research-Test Program & Failure Analysis of Class IE Solenoid Vlvs", F-C5569-309/315 DATE Nov. 1983  
Appendix C, and pages F-3 and F-4.
- (2) Title/Number/Revision "Report on Qualification RIMS B45 850514 428 of Automatic Switch Co. (ASCO) Catalog NP-1 Solenoid Vlvs for Safety-Related Applications in Nuclear Power Generating Stations", AQR-67368, Rev. 1. DATE 8/19/83
- (3) Title/Number/Revision \_\_\_\_\_ RIMS \_\_\_\_\_  
 \_\_\_\_\_ DATE \_\_\_\_\_

OTHER (ANALYSIS, VENDOR DATA, ETC.) ASCO letter, W. M. Brown to F. W. Chandler dated April 29, 1985 (B43 850502 015). Material Aging Data Request WAD-3, ASCO Certificates of Compliance (B43 850326 508, MED 840202 206, B43 860620 503) TVA memorandum D. L. Reed to EEB files dated October 9, 1984 (EEB 841010 946). ASCO Letter, W. M. Brown to D. L. Kitchel dated May 8, 1986 (B71 860512 001). ASCO Letter, W. M. Brown to D. L. Kitchel dated May 16, 1986 (B71 860520 001) See Section K(8), this tab, for a listing of additional calculations. Note: Throughout this TAB, references are made to the ASCO qualification report listed above. This report is identified as "(2)" in these references.





BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 3 OF 27

BINDER TITLE ASCO SOLENOID VALVES, MODEL NO. 206-380-SERIES (AC CONSTRUCTION) COMPUTED RJF DATE 8/27/86 R     R      
CHECKED WBR DATE 8/29/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

  X   Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)

       Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE 323-1974, IEEE 344-1975, IEEE 382-1980, and IEEE 627-1980.  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 5 OF 27  
 BINDER TITLE ASCO SOLENOID VALVES, MODEL NO. 206-380-SERIES COMPUTED RF DATE 8/21/86  
 (AC CONSTRUCTION) CHECKED WJK DATE 8/21/86

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? yes

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Solenoid Vlv</u>	<u>Solenoid Vlv</u>	<u>See TAB. C</u>
(2) Manufacturer	<u>ASCO</u>	<u>ASCO</u>	<u>See TAB C &amp; pg. 5 of (2)</u>
(3) Model Number(s)	<u>206-380-2RVU</u>	<u>K206-380-3RVF</u>	<u>See TAB C &amp; pg. 5 of (2)</u>
	<u>206-380-3RU</u>	<u>206-381-6RF</u>	<u>5 of (2)</u>
	<u>260-380-2RU</u>	<u>                    </u>	<u>                    </u>
	<u>                    </u>	<u>                    </u>	<u>                    </u>
(4) Serial Number(s)	<u>See TAB F</u>	<u>Not Listed</u>	<u>                    </u>
	<u>                    </u>	<u>                    </u>	<u>                    </u>
	<u>                    </u>	<u>                    </u>	<u>                    </u>
(5) Identify Component-Unique checksheet attached:	<u>NA</u>	<u>                    </u>	<u>                    </u>

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

BINDER TITLE ASCO SOLENOID VALVES, MODEL NO. 206-380-SERIES (AC CONSTRUCTION) COMPUTED RF DATE 8/27/86 R     R      
 CHECKED WPK DATE 8/27/86

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the test report and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if No, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	None Specified, See <u>TAB C, "Interfaces"</u>	<u>          </u>	<u>          </u>
External Process Connections	None Specified, See <u>TAB C, "Interfaces"</u>	<u>          </u>	<u>          </u>
Electrical Connections	<u>TAB C, "Interfaces"</u>	<u>          </u>	<u>          </u>
Conduit Seals	<u>See TAB C, "Interfaces"</u>	<u>          </u>	<u>          </u>
Connector Seals	<u>NA</u>	<u>          </u>	<u>          </u>
Orientation	<u>Vertical &amp; Upright <math>\pm</math> 45°</u>	<u>Yes</u>	<u>App. A, Pg. A2 of (2) &amp; ASCO Ltr (B43 850502 015)</u>
Physical Configuration	<u>N/A</u>	<u>          </u>	<u>          </u>
Other	<u>See below</u>	<u>Yes</u>	<u>See below</u>

JUSTIFICATION/COMMENTS 1. ASCO requires the installation of a 90° street elbow facing downward connected to exhaust port or similar configuration to prevent moisture from entering valve internals (Reference: Page A18 of 2). The purpose of this requirement is to prevent moisture intrusion resulting from a liquid spray. Since these valves are not subject to any spray condition the installation of a 90° street elbow is not required.

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 7 OF 27  
BINDER TITLE ASCO SOLENOID COMPUTED RF DATE 8/28/86 R     R      
VALVES, MODEL NO. 206-380-SERIES CHECKED WPK DATE 8/28/86  
(AC CONSTRUCTION)

F. INSTALLATION INTERFACES (Continued)

JUSTIFICATION/COMMENTS (Continued)

2. Medium must be oil free instrument air and a strainer or filter must be installed on the inlet as close to the valve as possible (Reference: ASCO Bulletin for Model 206-380 valves Tab H). ASCO does not identify specific interfacing requirements except as noted above. It is incumbent on each utility to ensure that interfaces are such that they do not interfere with the proper operation or qualification of the solenoid valve. See TAB C for a description of the TVA interfaces. (See Open Items No. 4, 6, 7, 8, and 9).

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 8 OF 27

BINDER TITLE ASCO SOLENOID VALVES, MODEL NO. 206-380-SERIES (AC CONSTRUCTION) COMPUTED RCF DATE 8/27/86 R     R      
CHECKED WPK DATE 8/29/86

G. TEST SEQUENCE

- (1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	<u>Sect. 4, pg 8 of (2)</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>Sect. 4, pg 8 of (2)</u>
(c) Equipment aged:		
Thermal	<u>Yes</u>	<u>Sect 4.1.1, pg 8 of (2).</u>
Radiation	<u>Yes</u>	<u>Sect 4.1.4, pg 15 of (2).</u>
Wear	<u>Yes</u>	<u>Sect 4.1.2, pg 12 of (2).</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>Sect. 4.1.5, pg 15, Sect. 4.1.6, pg 17 &amp; Sect. 4.2.1, pg 19 of (2).</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	<u>Sect. 4.2, pgs 19-23 of (2)</u>
(f) Post-DBE exposure	<u>Yes</u>	<u>Sect. 4.2.3, pgs 22 &amp; 23 of (2)</u>
(g) Final inspection and disassembly	<u>Yes</u>	<u>Sect. 4.4, pg 24 of (2).</u>

- (2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes
- (3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes  
(Reference Appendix G of (2)).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 9 OF 27  
 BINDER TITLE ASCO SOLENOID VALVES, MODEL NO. 206-380-SERIES COMPUTED RCF DATE 8/27/86  
 (AC CONSTRUCTION) CHECKED WJK DATE 8/29/86

H. AGING

- (1) Was aging considered in the qualification program (Yes/no/NA)? Yes (Reference Appendix A, Sect. 9.4, pg A10 of (2); and TAB C).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	App. A, Sect. <u>9.4.1 of (2)</u>
Radiation exposure	<u>Yes</u>	App. A, Sect. <u>9.4.4 of (2)</u>
Vibration (non-seismic) aging	<u>Yes</u>	App. A, Sect. <u>9.4.5 of (2)</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	App. A, Sect. <u>9.4.2 and 9.4.3 of (2)</u>

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? No (Reference \_\_\_\_\_).

JUSTIFICATION/COMMENTS Synergistic effects were considered in the qualification of these valves. Each section of TAB C contains a discussion on this subject.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program (yes/no/NA)? Yes (Reference App. A, Sect. 9.4.1, pg. A10 of (2), and TAB C).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 10 OF 27

BINDER TITLE ASCO SOLENOID VALVES, MODEL NO. 206-380-SERIES COMPUTED RTF DATE 5/27/86  
(AC CONSTRUCTION) CHECKED WPK DATE 8/27/86

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes (Reference: App. B of (2) ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference See H (1) this Tab ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference App. A, Sect. 9.4.1 of (2) ).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	_____	_____	_____
Time	_____	_____	_____

JUSTIFICATION/COMMENTS See TAB C, "Aging"  
\_\_\_\_\_

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference See H(4)(d) this Tab & TAB C ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? Yes (Reference See H(4)(b) this Tab ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_





BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 12 OF 27  
 BINDER TITLE ASCO SOLENOID COMPUTED [Signature] DATE 8/28/86 R     R      
 VALVES, MODEL NO. 206-380-SERIES CHECKED [Signature] DATE 8/28/86  
 (AC CONSTRUCTION)

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (yes/no/NA)? Yes (Reference Sect. 4.1.4 of (2) and Appendix D of (2) ).

Plant normal ambient radiation dose (rd) Various - See TAB C,  
7  
 Test exposure dose (rd) 2.3x10 Rads, gamma  
 Test exposure dose rate (rd/hr) 0.71 Mrad/hr for 33 hours  
 Test exposure source type (e.g., Co-60 gamma) Co-60, gamma

JUSTIFICATION/COMMENTS \_\_\_\_\_

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference App. A, Section 9.4.5 and Sect. 4.1.5 of (2) ).

JUSTIFICATION/COMMENTS No failure which could be attributed to vibration aging was identified.

- (b) Was the basis for vibration aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference App. A, Sect. 9.4.5 of (2) ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference App. A, Sect. 9.4.2 and 9.4.3 of (2) ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 13 OF 27

BINDER TITLE ASCO SOLENOID VALVES, MODEL NO. 206-380-SERIES COMPUTED [Signature] DATE 8/27/86 R     R      
(AC CONSTRUCTION) CHECKED [Signature] DATE 8/27/86

H. AGING (Continued)

(b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (yes/no/NA)? Yes (Ref. App. A, Sects. 9.4.2 & 9.4.3 of (2) ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_

(8) Was the qualified life of the equipment and its basis defined in the qualification program (yes/no/NA)? Yes  
(Reference See below, TAB C, and Sect. 9.4.1 Appendix A of (2) ).

Qualified life (Document in QMDS) \_\_\_\_\_  
JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_

(9) Were replacement intervals for the equipment or its components defined in the qualification program (yes/no/NA)? Yes  
(Reference See below and TAB C ).

Replacement Intervals (Document in QMDS) Replacement intervals and qualified life are a function of plant specific conditions in comparison to test conditions. TABS C and G define the replacement intervals and qualified life and their basis.

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 14 OF 27  
 BINDER TITLE ASCO SOLENOID COMPUTED RCY DATE 8/27/86 R     R      
 VALVES, MODEL NO. 206-380-SERIES (AC CONSTRUCTION) CHECKED WBR DATE 8/27/86

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of EQC Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>(Coil) IsoMica bonded with Hi-Temp Epoxy</u>	<u>1 x 10<sup>7</sup> rads</u>	<u>See below</u>	<u>1.00</u>	<u>See below</u>
<u>Ethylene Propylene</u>	<u>1 x 10<sup>7</sup> rads</u>	<u>See below</u>	<u>0.94</u>	<u>App. B pg B3 of (2)</u>
(b) <u>Terpolymer (Seats)</u>	<u>5 x 10<sup>6</sup> rads</u>	<u>See below</u>	<u>1.04</u>	<u>App. B pg B4 of (2)</u>
(c) <u>Viton (Seats)</u>	<u>   </u>	<u>   </u>	<u>   </u>	<u>   </u>
(d) <u>   </u>	<u>   </u>	<u>   </u>	<u>   </u>	<u>   </u>
(e) <u>   </u>	<u>   </u>	<u>   </u>	<u>   </u>	<u>   </u>

JUSTIFICATION/COMMENTS Note: The Class H coil is composed of six primary materials. Of these, the one with the lowest activation energy is Iso-Mica bonded with hi-temp. epoxy. Its activation energy is 1.00 eV. The materials of coil construction along with their activation energies are identified in Appendix B, page B5 of (2). Radiation threshold values are typical for these materials and listed for information only. These values were not taken from the test report but were supplied by the Digital Materials Data Base. (See TAB E)

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 15 OF 27  
BINDER TITLE ASCO SOLENOID VALVES, MODEL NO. 206-380-SERIES COMPUTED RJY DATE 8/27/86 R     R      
(AC CONSTRUCTION) CHECKED WJK DATE 8/27/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference App. A, Sect. 6.1 and 6.2 of (2) ).

Identify Acceptance Criteria: Coil only taken from (2) - Must operate at any voltage between 102 VAC and 132 VAC. Insulation resistance must measure greater than or equal to 1 megohm at 500 VDC. Leakage current must be less than 0.5 milliamps at 1240 VAC for 1 minute. For seats and discs, as taken from (2) - Valves must operate at the minimum and maximum operating pressure differentials. Valves must not have a pressure increase at a cylinder port which is required to be vented or a pressure decrease at a cylinder port which is required to be pressurized in excess of 10% of the maximum operating pressure differential.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Ref. App. A, Sects. 6.1, 6.2, and App. AIII of (2). )

Identify baseline and functional testing: Recording coil excitation, coil dielectric, seat leakage at 150 psig and 10 psig in both the energized and de-energized state, noise test, external leakage at 150 psi, operational test from 150 psig to 0 psig, insulation resistance and number of active coil turns during initial baseline and following DBA simulation.

PAGE B-16



BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 17 OF 27  
 BINDER TITLE ASCO SOLENOID COMPUTED RTF DATE 8/28/86 R     R      
 VALVES, MODEL NO. 206-380-SERIES CHECKED WPK DATE 8/28/86  
 (AC CONSTRUCTION)

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

(4) Do the applied loads during baseline testing reflect normal operating conditions (yes/no/NA)? Yes (Reference Tbl 4.3, page 30 of (2)).

JUSTIFICATION/COMMENTS Loads of voltage and pressure. Actual plant voltage during normal operation is within the required range of 120VAC ± 10% except as noted below. Plant operating pressure is within the range tested. However, maximum operating pressure differential is function of the specific valve design. (See TAB C).

(5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) <u>Parameter</u>	<u>Specific Accident Conditions</u> <sup>1</sup>	<u>Reference</u>
Voltage	<u>Varies</u>	TVA Calculation WBPEVAR 8602002 Procurement Contracts, Sec. E8 & E9
Load	<u>Not specified</u>	Procurement Contracts, Sec. E8 & E9
Frequency	<u>Not specified</u>	Procurement Contracts, Sec. E8 & E9
Accuracy	<u>NA</u>	<u>   </u>
<u>Other(s)</u>		

JUSTIFICATION/COMMENTS See page 18.





BINDER TITLE ASCO SOLENOID VALVES, MODEL NO. 206-380-SERIES (AC CONSTRUCTION)

COMPUTED RJF

DATE 8/27/86

CHECKED WAK

DATE 8/27/86

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. Various - See Section C

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) Various See TAB C  
 (b) Pressure (psig) Various See TAB C  
 (c) Humidity (%) Various See TAB C  
 (d) Radiation (rd) Various See TAB C

(a) Temperature (°F) Various See TAB C  
 (b) Pressure (psig) Various See TAB C  
 (c) Humidity (%) Various See TAB C  
 (d) Radiation (rd) Various See TAB C

(3) Process Interfaces: The process fluid is oil free instrument air with a design temperature of 100°F maximum (Reference TVA Contracts, TAB E, Sections E8 and E9). The lowest ambient temperature which these valves are qualified to is 104°F, therefore, the process fluid will not provide an increase in this condition.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Up to eight hours per excursion and less than 1% of plant life. See TAB C.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F)	<u>See TAB C</u>	Accident type <u>See TAB C</u>
(b) Pressure (psig)	<u>See TAB C</u>	Accident type <u>See TAB C</u>
(c) Humidity (%)	<u>See TAB C</u>	Accident type <u>See TAB C</u>
(d) Radiation (rd)	<u>See TAB C</u>	Accident type <u>See TAB C</u>
(e) Spray Type	<u>N/A</u>	Accident type <u>See TAB C</u>

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 20 OF 27  
 BINDER TITLE ASCO SOLENOID COMPUTED RCF DATE 9/15/86 R     R      
 VALVES, MODEL NO. 206-380-SERIES CHECKED WBK HXR DATE 9/15/86  
 (AC CONSTRUCTION)

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.):  
The worst case accident profile combination was not utilized as the  
enveloping environment. Qualification to the environment would only produce  
replacement/refurbishment schedules which would be overly conservative for  
many of the valves. Qualification and replacement schedules were based on  
valve specific environments which are defined in TAB C. TAB G defines the  
maintenance which is reflective of these environments.

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (yes/no/NA)? Yes (Reference See TAB C ).

(7) Subject to submergence (yes/no/NA)? No (Reference See TAB C ).

Identify initiation time and duration of submergence: N/A

(8) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
<u>Flooding (WBN-OSG4-044)</u>	<u>B45 860110 218</u>
<u>Moisture Intrusion (GENNAL6-002)</u>	<u>B45 851017 235</u>
<u>Status and Duty Cycles (WBN-OSG4-045)</u>	<u>B45 860902 219</u>
<u>100-day LOCA Dose in EGTS Filter Train Room (WBNNAL3-031)</u>	<u>B45 860529 237</u>
<u>Solenoid Valve Voltage Study (WBPEVAR 8602002)</u>	<u>Later(See Open Item No.3)</u>
<u>Location Specific Rad. Calc. (Later)</u>	<u>(Later) See Open Item #1</u>
<u>EGTS Room Temperature TI-ECS-79</u>	<u>B45 860319 235</u>

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 21 OF 27  
 BINDER TITLE ASCO SOLENOID COMPUTED RF DATE 8/28/86 R     R      
 VALVES, MODEL NO. 206-380-SERIES CHECKED WPK DATE 8/28/86  
 (AC CONSTRUCTION)

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<sup>1</sup> <u>100 Days</u>	<u>30 Days</u>	Fig. 4.1, pg. 25 of (2)
Temperature (°F)	<u>200 @ 11 minutes</u>	<u>448</u>	Fig. 4.1, pg. 25 of (2)
Pressure (psig)	<u>-0-</u>	<u>68 psig</u>	Fig. 4.1, pg. 25 of (2)
Relative Humidity (%)	<sup>2</sup> <u>100</u>	<u>100</u>	Fig. 4.1, pg. 25 of (2)
*Chemical Spray	<sup>3</sup> <u>N/A</u>	<u>pH 10.5 (22 hours)</u>	App. A, pg. A20 A21 of (2)
**Radiation (rd)	<u>Various</u>	<u>2.05 x 10<sup>8</sup> gamma</u>	App. D of (2) & IN 85-08 TAB J
Submergence	<u>See TAB C</u>	<sup>4</sup> <u>2x10<sup>7</sup> gamma</u>	
	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

\*Includes spray concentration, flowrate, density, duration, and pH.  
 \*\*Enter 40-year integrated normal dose plus integrated accident dose and specify type.

- 1 - At 30 days the temperature returns to maximum normal
- 2 - At 24 hours the humidity returns to maximum normal
- 3 - Valves are not subject to containment spray
- 4 - Valves containing Viton elastomers are only qualified to a maximum of 2x10<sup>7</sup> rads, gamma. See TAB C.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>See TAB C</u>
Pressure	<u>Yes</u>	<u>See TAB C</u>
Relative Humidity	<u>Yes</u>	<u>See TAB C</u>
Chemical Spray	<u>N/A</u>	<u>See TAB C</u>
Submergence	<u>N/A</u>	<u>See TAB C</u>

JUSTIFICATION/COMMENTS

PAGE B-22

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 22 OF 27  
 BINDER TITLE ASCO SOLENOID COMPUTED RIF DATE 8/28/86 R     R      
 VALVES, MODEL NO. 206-380-SERIES CHECKED WJK DATE 8/28/86  
 (AC CONSTRUCTION)

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, yes/no/NA)

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	<u>15°F</u>	<u>Yes</u>
Pressure: +10% but no more than 10 psig	<u>68 psig</u>	<u>Yes</u>
Radiation: +10% of accident dose	<u>See TAB C</u>	<u>Yes</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>None</u>	<u>Yes-See Generic Binder WBNEQ-GEN-001 Sec. III.C.4</u>
Voltage: $\pm 10\%$ of rated value	<u>+10%</u> <u>-15%</u>	<u>Yes</u>
Frequency: $\pm 5\%$ of rated value	<u>None</u>	<u>Yes</u>
Environmental Transient: the initial transient and the peak temperature applied twice	<u>--</u> <u>See TAB. C for description of test</u>	<u>Yes</u>
Vibration: +10% added to acceleration	<u>of test</u>	<u>Yes</u>

JUSTIFICATION/COMMENTS: See TAB C for detailed information on margins as they apply to the TVA valves. TVA Calculation WBPEVAR 8602002 (Later - see Open Item #3) documents a degraded voltage condition which has the highest probability of occurrence. Thus, qualification is better substantiated by proving operability under a degraded voltage condition.

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 23 OF 27  
BINDER TITLE ASCO SOLENOID COMPUTED RF DATE 8/28/86 R     R      
VALVES, MODEL NO. 206-380-SERIES CHECKED WJK DATE 8/28/86  
(AC CONSTRUCTION)

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:  
(Reference See TAB C ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes (Ref. See TAB. C ).

JUSTIFICATION/COMMENTS The test valve was assumed to be normally energized and required to de-energize on receipt of accident signal, then to remain operable for 30 days post-DBA. The specific DBA functions of the TVA valves are described in TAB. C.

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? N/A (Ref.     ).

JUSTIFICATION/COMMENTS The test valve was not subject to post-DBA exposure.

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? No (Reference     ).

JUSTIFICATION/COMMENTS See TAB C for the analysis of the test DBA versus the plant specific DBA. However, the test valve did demonstrate operability in accordance with the requirements defined in M(2) above.

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? Yes (Reference Sections 5.2 and 5.3, pgs. 56 and 57 of (2) and page 31 of (2) ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

PAGE B-24



BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 25 OF 27  
 BINDER TITLE ASCO SOLENOID COMPUTED CF DATE 8/28/86 R     R      
 VALVES, MODEL NO. 206-380-SERIES CHECKED WJR DATE 8/28/86  
 (AC CONSTRUCTION)

0. SUMMARY OF REVIEW

- |   | <u>Yes/No/NA</u> |
|---|------------------|
| (1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)? | <u>Yes</u>       |
| (2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?   | <u>N/A</u>       |
| (3) Choice of qualification methodology adequately justified?   | <u>Yes</u>       |
| (4) If analysis was performed, complete the following:  |                  |
| (a) Were equipment performance requirements identified?   | <u>N/A</u>       |
| (b) Were specific features and failure modes and effects analyzed?  | <u>N/A</u>       |
| (c) Were assumptions and mathematical models used together with appropriate justification for their use?  | <u>N/A</u>       |
| (d) Were environmental parameters which affect equipment performance identified?  | <u>N/A</u>       |
| (5) Adequate similarity between equipment and test specimen established?  | <u>Yes</u>       |
| (6) Aging degradation evaluated adequately?   | <u>Yes</u>       |
| (a) Mechanical and/or cycle aging addressed?  | <u>Yes</u>       |
| (b) Equipment aged to end of life condition prior to application of DBE conditions?   | <u>Yes</u>       |
| (c) Absence of preaging in test/analysis justified?   | <u>N/A</u>       |
| (d) Materials susceptible to thermal/radiation aging identified?  | <u>Yes</u>       |

BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 26 OF 27

BINDER TITLE ASCO SOLENOID VALVES, MODEL NO. 206-380-SERIES (AC CONSTRUCTION) COMPUTED [Signature] DATE 8/27/86  
CHECKED [Signature] DATE 8/27/86

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>N/A</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>N/A</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>N/A</u>
(11) Criteria regarding submergence satisfied?	<u>N/A</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>



BINDER NO. WBNEQ-SOL-005 PLANT WBN UNIT(S) 1 SHEET 27 OF 27  
 BINDER TITLE ASCO SOLENOID VALVES, MODEL NO. 206-380-SERIES COMPUTED RJ DATE 8/27/86  
 (AC CONSTRUCTION) CHECKED WJK DATE 8/28/86

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(15) Criteria regarding functional testing satisfied?	<u>Yes</u>
(a) Does the test plan/report specify an acceptance criteria for equipment performed?	<u>Yes</u>
(b) Was an initial base line test done to establish required performance characteristics?	<u>Yes</u>
(c) Has the test/analysis demonstrated that performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured?	<u>Yes</u>
(16) Criteria regarding instrument accuracy satisfied?	<u>N/A</u>
(17) Test duration margin (1 hour + function time) satisfied?	<u>Yes</u>
(a) Is the minimum specified operating time at least 1 hour?	<u>Yes</u>
(b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided?	<u>N/A</u>
(18) Criteria regarding synergistic effects satisfied?	<u>Yes</u>
(19) Criteria regarding margins satisfied?	<u>Yes</u>
(20) Maintenance and surveillance requirements adequately identified?	<u>Yes</u>

P. DISCUSSION

The TVA valves as listed in this report are fully qualified to the requirements of NUREG 0588 Cat. I (IEEE 323-1974) and 10CFR50.49.  
TAB C provides a detailed analysis to support this claim.

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 1 OF 1  
BINDER TITLE ASCO SOLENOID VALVES - COMPUTED EE M DATE 7/14/86 R     R      
MODEL NP 8316 SERIES CHECKED WPK DATE 7/16/86

TAB A  
EQUIPMENT IDENTIFICATION MATRIX

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WBWED-SOL -006  
 MANUFACTURER: ASCO  
 PAGE: 1 OF 5

EQIS NO.	UNIT DEVICE ID NO.		DESCRIPTION	MODEL	LOCATION			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION
					COLUMN	AZ	ELEV*					
WBN-1-FSV -061-0097	-B	1-FSV -061-0097	-B	INLET ISLN VLV REACTOR BLDG	NP1831654E	300	772' 1" U	80KJ3-827551	L NS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/100B 5MIN/100B 5MIN/100B 15MIN/1MO 1HR/1MO	MUST CHANGE POSN TO ALLOW CNTHT ISLN VLV TO CLOSE AND MUST NOT FAIL SUCH THAT AIR CAN BE ADMITTED TO VALVE OPERATOR.
WBN-1-FSV -061-0122	-B	1-FSV -061-0122	-B	OUTLET ISLN VLV REACTOR BLDG	NP1831654E	300	776' 5" U	80KJ3-827551	L NS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/100B 5MIN/100B 5MIN/100B 15MIN/1MO 1HR/1MO	MUST CHANGE POSN TO ALLOW CNTHT ISLN VLV TO CLOSE AND MUST NOT FAIL SUCH THAT AIR CAN BE ADMITTED TO VALVE OPERATOR.
WBN-1-FSV -061-0192	-B	1-FSV -061-0192	-B	GYLCOI SUPPLY ISOLATION VALVE	NP1831654E	300	807' 10" U	80KJ3-827551	L NS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/100B 5MIN/100B 5MIN/100B 15MIN/1MO 1HR/1MO	MUST CHANGE POSN TO ALLOW CNTHT ISLN VLV TO CLOSE AND MUST NOT FAIL SUCH THAT AIR CAN BE ADMITTED TO VALVE OPERATOR.
WBN-1-FSV -061-0194	-B	1-FSV -061-0194	-B	GYLCOI RETURN ISOLATION VALVE	NP1831654E	300	808' U	80KJ3-827551	L NS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/100B 5MIN/100B 5MIN/100B 15MIN/1MO 1HR/1MO	MUST CHANGE POSN TO ALLOW CNTHT ISLN VLV TO CLOSE AND MUST NOT FAIL SUCH THAT AIR CAN BE ADMITTED TO VALVE OPERATOR.
WBN-1-FSV -062-0069	-A	1-FSV -062-0069	-A	RC LOOP 3 LETDOWN FLOW	NP1831654E	132	728' 4" L	80KJ3-827551	CV/C	A/B	1HR/1MO	NECESSARY TO ISOLATE A BREAK IN THE CVCS LETDOWN LINE INSIDE CONTAINMENT
WBN-1-FSV -062-0070	-A	1-FSV -062-0070	-A	RC LOOP 3 LETDOWN FLOW	NP1831654E	133	723' 9" L	80KJ3-827551	CV/C	A/B	1HR/1MO	NECESSARY TO ISOLATE A BREAK IN THE CVCS LETDOWN LINE INSIDE CONTAINMENT

PAGE 1-2

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH  
 TVA ELEMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE E. E. M. C. Bae 7/30/86  
 CHECKER/DATE W. B. [Signature] 7/30/86

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WBNEQ-SOL -006  
 MANUFACTURER: ASCO  
 PAGE: 2 OF 5

EBIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*					
WBN-1-FSV -062-0072	-A 1-FSV -062-0072	-A REGEN HTX LTDN ISLN VALVE A	NPX831654E		042	703' 1" L	80XJ3-827551	L	A/B	5MIN/100D	MUST CHANGE POSH TO ALLOW CNTMT ISLN VLV TO CLOSE AND MUST NOT FAIL SUCH THAT AIR CAN BE ADMITTED TO VALVE OPERATOR.
WBN-1-FSV -062-0073	-A 1-FSV -062-0073	-A REGEN HTX LTDN ISLN VALVE B	NPX831654E		052	703' 7" L	80XJ3-827551	L	A/B	5MIN/100D	MUST CHANGE POSH TO ALLOW CNTMT ISLN VLV TO CLOSE AND MUST NOT FAIL SUCH THAT AIR CAN BE ADMITTED TO VALVE OPERATOR.
WBN-1-FSV -062-0074	-A 1-FSV -062-0074	-A REGEN HTX LTDN ISLN VALVE C	NPX831654E		052	704' 8" L	80XJ3-827551	L	A/B	5MIN/100D	MUST CHANGE POSH TO ALLOW CNTMT ISLN VLV TO CLOSE AND MUST NOT FAIL SUCH THAT AIR CAN BE ADMITTED TO VALVE OPERATOR.
WBN-1-FSV -062-0076	-A 1-FSV -062-0076	-A REGEN HTX LTDN ISLN VALVE	NPX831654E		052	707' 1" L	80XJ3-827551	L	A/B	5MIN/100D	MUST CHANGE POSH TO ALLOW CNTMT ISLN VLV TO CLOSE AND MUST NOT FAIL SUCH THAT AIR CAN BE ADMITTED TO VALVE OPERATOR.
WBN-1-FSV -062-0077	-B 1-FSV -062-0077	-B LETDOWN LINE ISOLATION VALVE	NP8316	WA4		713' A2B		L	A/B	5MIN/100D	MUST CLOSE AND REMAIN CLOSED AFTER PHASE "A" ISLN SIGNAL IS RCVD AND RESET
WBN-1-FSV -063-0023	-B 1-FSV -063-0023	-B SIS ACCUM FILL LINE ISLN SW	NP831654E	WA4		713' A2B	84KK1-835541	L	A/B	5MIN/100D	MUST DE-ENERGIZE TO CLOSE FCV AND NOT FAIL IN THE ENERGIZED POSITION

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE

*E.E. McRee* 9/19/86

CHECKER/DATE

*WBK* 9/19/86

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WRNEQ-SOL -006  
 MANUFACTURER: ASCO  
 PAGE: 3 OF 5

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						
WBN-1-FSV -063-0064	-A 1-FSV -063-0064	-A SIS ACCUM TANK NO 2 HDR INLET VLV	NP831654E	WA4		713'	A2B	84KK1-835541	L	A/B	5MIN/100D	MUST DE-ENERGIZE TO CLOSE FCV IF OPEN AND NOT FAIL IN THE ENERGIZED POSITION
WBN-1-FSV -063-0071	-A 1-FSV -063-0071	-A SIS CHECK VLV LEAK TEST ISLN	NP831654E		290	724' 1" L		80KJ3-827551	L	A/B	5MIN/100D	MUST CLOSE AND REMAIN CLOSED ON A PHASE "A" ISOLATION SIGNAL
									MS/C	A/B	5MIN/100D	
									FW/C	A/B	5MIN/100D	
									RH/C	A/B	15MIN/1MD	
									CV/C	A/B	1HR/1MD	
WBN-1-FSV -063-0084	-B 1-FSV -063-0084	-B SIS CHECK VLV LEAK TEST ISLN	NP831654E	WA4		713'	A2B	84KK1-835541	L	A/B	5MIN/100D	MUST DE-ENERGIZE TO CLOSE FCV AND THEN NOT FAIL IN THE ENERGIZED POSITION
WBN-1-PSV -065-0081	-A 1-PSV -065-0081	-A SHLD BLDG VENT AND CONT ANNLS ISLN VLV	NP831654E		001	832' 10" ANN		84KK1-835541	L	A	100D	MUST OPERATE WHENEVER NEEDED TO HELP REGULATE ANNULUS PRESSURE
									MS/C	A	100D	
									FW/C	A	100D	
									RH/C	A	1MD	
									CV/C	A	1MD	
WBN-1-PSV -065-0083	-B 1-PSV -065-0083	-B SHLD BLDG VENT AND CONT ANNLS ISLN VLV	NP831654E		360	830' 9" ANN		84KK1-835541	L	A	100D	MUST OPERATE WHENEVER NEEDED TO HELP REGULATE ANNULUS PRESSURE
									MS/C	A	100D	
									FW/C	A	100D	
									RH/C	A	1MD	
									CV/C	A	1MD	
WBN-1-FSV -068-0305	-A 1-FSV -068-0305	-A RCS FLOW CNTL VLV WDS N2 MAN TO PRT	NP831654E			713'	A2B	84KK1-835541	L	A/B	5MIN/100D	MUST CLOSE ON CONTAINMENT ISOLATION SIGNAL TO CAUSE FCV-68-305 TO CLOSE

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH DOCUMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE E. E. McRae 4/19/86  
 CHECKER/DATE W.B.K. JDC 9/19/86

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WBNED-SOL -006  
 MANUFACTURER: ASCO  
 PAGE: 4 OF 5

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT#	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV# RM/RAD					
WBN-1-FSV -068-0308	-B 1-FSV -068-0308	-B RCS FLOW CNTL VLV NDS GA TO PRT	NPX831654E		318	723' 11" L	80XJ3-827551	L MS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/100D 5MIN/100D 5MIN/100D 15MIN/1MD 1HR/1MD	MUST DE-ENERGIZE ON PHASE "A" ISOLATION SIGNAL AND REMAIN DE-ENERGIZED
WBN-1-FSV -077-0009	-B 1-FSV -077-0009	-B RCDT PMP DISCH VALVE FLOW CONTROL	NPX831654E		279	725' 3" L	80XJ3-827551	L MS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/100D 5MIN/100D 5MIN/100D 15MIN/1MD 1HR/1MD	MUST DE-ENERGIZE TO CLOSE THE ISOLATION VALVES AND REMAIN IN THAT POSITION
WBN-1-FSV -077-0010	-A 1-FSV -077-0010	-A RCDT PMP DISCH VALVE FLOW CONTROL	NP831654E	WA4		713' A2B	84KK1-835541	L	A/B	5MIN/100D	MUST DE-ENERGIZE ON PHASE "A" ISOLATION SIGNAL TO CLOSE THE ISOLATION VALVES AND REMAIN IN THAT POSITION
WBN-1-FSV -077-0016	-B 1-FSV -077-0016	-B RCDT TO GAS ANALYZER FLOW SOL VALVE	NPX831654E		285	718' 9" L	80XJ3-827551	L MS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/100D 5MIN/100D 5MIN/100D 15MIN/1MD 1HR/1MD	MUST DE-ENERGIZE ON PHASE "A" ISOLATION SIGNAL AND REMAIN DE-ENERGIZED
WBN-1-FSV -077-0017	-A 1-FSV -077-0017	-A RCDT TO GA FLOW CONTROL	NP831654E	WA4		713' A2B	84KK1-835541	L	A/B	5MIN/100D	MUST DE-ENERGIZE ON PHASE "A" ISOLATION SIGNAL AND REMAIN DE-ENERGIZED
WBN-1-FSV -077-0018	-B 1-FSV -077-0018	-B RCDT TO VENT HDR FLOW CONTROL	NPX831654E		283	725' 4" L	80XJ3-827551	L MS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/100D 5MIN/100D 5MIN/100D 15MIN/1MD 1HR/1MD	MUST DE-ENERGIZE ON PHASE "A" ISOLATION SIGNAL AND REMAIN DE-ENERGIZED

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH  
 TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE E. E. M<sup>2</sup> Dec 9/19/86  
 CHECKER/DATE WABK/2000 9/19/86

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WNEB-SOL -006  
 MANUFACTURER: ASCO  
 PAGE: 5 OF 5

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	-----LOCATION-----			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						
WBN-1-FSV -077-0019	-A 1-FSV -077-0019	-A RCDT TO VENT HDR FLOW CONTROL	NP831654E	WA4		713'	A2B	84KK1-835541	L	A/B	5MIN/100D	MUST DE-ENERGIZE ON PHASE "A" ISOLATION SIGNAL AND REMAIN DE-ENERGIZED
WBN-1-FSV -077-0020	-A 1-FSV -077-0020	-A RCDT N2 SUPPLY FLOW CONTROL	NP831654E	WA4		713'	A2B	84KK1-835541	L	A/B	5MIN/100D	MUST DE-ENERGIZE ON PHASE "A" ISOLATION SIGNAL AND REMAIN DE-ENERGIZED
WBN-1-FSV -081-0012	-A 1-FSV -081-0012	-A PW RCS PRESS RELIEF TK & RCP STAND PIPES	NP831654E	WA4		713'	A2B	84KK1-835541	L	A/B	5MIN/100D	MUST DE-ENERGIZE TO CLOSE THE ISOLATION VALVES AND REMAIN IN THAT POSITION
WBN-1-FSV -087-0007	-A 1-FSV -087-0007	-A TEST LINE ISOLATION VALVE FLOW CONTROL	NP1831654E		222	708' 5" L		80KJ3-827551	L MS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/100D 5MIN/100D 5MIN/100D 15MIN/1MD 1HR/1MD	MUST DE-ENERGIZE ON PHASE "A" ISOLATION SIGNAL AND REMAIN DE-ENERGIZED
WBN-1-FSV -087-0008	-A 1-FSV -087-0008	-A TEST LINE ISOLATION VALVE FLOW CONTROL	NP1831654E		222	706' 8" L		80KJ3-827551	L MS/C FW/C RH/C CV/C	A/B A/B A/B A/B A/B	5MIN/100D 5MIN/100D 5MIN/100D 15MIN/1MD 1HR/1MD	MUST DE-ENERGIZE ON PHASE "A" ISOLATION SIGNAL AND REMAIN DE-ENERGIZED

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE

*E. C. McBeal 9/19/86*

CHECKER/DATE

*W.B.K./HOR 9/19/86*

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 1 OF 1  
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EEM DATE 7/14/86 R     R      
MODEL NP8316 SERIES     CHECKED WAK DATE 7/16/86

TAB B

ENVIRONMENTAL QUALIFICATION CHECKLIST



BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 1 OF 33  
BINDER TITLE ASCO SOLENOID VALVES COMPUTED ECM DATE 9/19/86 R     R      
MODEL NP8316 SERIES     CHECKED WBK/2/84 DATE 9/19/84

A. DOCUMENTATION

Equipment Description Solenoid Valves  
Vendor/Manufacturer ASCO  
Equipment Model No.(s) NPX831654E  
NP831654E

QUALIFICATION REPORTS (TAB D) (See also TAB C "Discussion")

- (1) Title/Number/Revision Automatic Switch Company RIMS B43 850627 322  
Test Report No. AQS21678/TR/Rev A DATE July 1979
- (2) Title/Number/Revision ASCO Catalog NP-1 RIMS NEB 840328 363  
valves/AQS21678/TR/Supplement 3 DATE March 8, 1983
- (3) Title/Number/Revision Automatic Switch Company RIMS B45 850514 428  
Test Report No. AQR-67368, Rev 1 DATE August 19, 1983
- (4) Title/Number/Revision Franklin Research Center RIMS NEB 840925 351  
Test Report F-C5569-309/315, Appendix C DATE November 1983
- (5) Title/Number/Revision Wyle RIMS EEB 840731 501  
Laboratories Test Report 17523-1 DATE June 20, 1984

OTHER (ANALYSIS, VENDOR DATA, ETC.) ASCO Letters  
TAB E-7 Mounting Orientation RIMS (B43 850502 015)  
TAB E-8 Storage Instructions RIMS (EEB 810108 025) and  
Shelf Life (B71 860902 001)  
TAB E-11 Periodic Operation RIMS (EEB 840730 021)  
TAB E-12 Coil Heat Rise Data RIMS (B71 860512 001) and  
B71 860520 001)

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 1A OF 33  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EM DATE 9/19/86 R     R      
 MODEL NP8316 SERIES                      CHECKED WBK/TKR DATE 9/19/86

<u>Type</u>	<u>RIMS No.</u>
Category and Operating Times	
System 61 (WBNO SG4-012)	B45 860325 218
System 62 (WBNO SG4-013)	B45 860320 223
System 63 (WBNO SG4-014)	B45 860314 219
System 65 (WBNO SG4-015)	B43 860326 222
System 68 (WBNO SG4-017)	B45 860722 218
System 77 (WBNO SG4-021)	B45 860313 219
System 81 (WBNO SG4-023)	B45 861127 219
System 87 (WBNO SG4-025)	B45 860313 218
Status and Duty Cycles of IE Solenoid Valves Located in Potentially Harsh Environments (WBN-0SG4-045)	B45 860902 219
Solenoid Valve Voltage Study (WBPE VAR 8602002)	Later
Identification of Harsh Environment Areas with High Potential for Condensate Formation (GENNAL6-002)	B45 860812 236

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 1B OF 33  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE M DATE 9/20/86 R     R      
 MODEL NP8316 SERIES CHECKED WBK/ DATE 9/20/86

<u>Type</u>	<u>RIMS No.</u>
Integrated Accident Dose Inside Containmentment (TI-RPS-48)	B45 851105 235
Flooding in Aux. Building Due to Postulated Pipe Breaks (WBNO SG4-44)	B45 860110 218
Beta Dose Reduction by PVC-Covered Conduit Inside Containment (GENNAL3-003)	B45 851210 236
Reduction of Beta Dose by Sheet Steel (GENNAL3-002)	B45 851210 235
Water Level in the Primary Containmentment Following the CVCS HELB (QIR NEB85069)	B45 851030 255
Maximum Containmentment Water Level	NEB 840120 220
Flooding Level Outside the Crane Wall Following Main Feedwater (MFW) and Main Steamline Break (MSLB) (WBNNAL6-005)	B45 860520 235
Reverification of Model Number of Valve 1-FSV-061-0194-B (QIR WBN EQC 86004)	T37 860919 808

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 2 OF 33  
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EGM DATE 9/19/86 R     R      
MODEL NP8316 SERIES CHECKED WBK/mon DATE 9/19/86

B. CONCLUSION OF REVIEW (Check only one block)

- Equipment Qualified
- Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule
- Equipment Qualification Not Established by Documentation
- Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES

- 1) Documentation used by field to install solenoid valves not identified.
- 2) Parts other than exact replacements used on IE equipment.
- 3) Voltage available to solenoid valve coils during accident conditions not determined.
- 4) Nameplate data not available for 1-FSV-62-77-B.

COMMENTS/RECOMMENDATIONS NONE

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_





BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 5 OF 33  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EEM DATE 7/14/86 R    R     
 MODEL NP8316 SERIES    CHECKED WPK DATE 7/16/86

**E. EQUIPMENT DESCRIPTION**

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? NO

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Solenoid Vlv</u>	<u>Solenoid Vlv</u>	<u>  </u>
(2) Manufacturer	<u>ASCO</u>	<u>ASCO</u>	<u>  </u>
(3) Model Number(s)	<u>NPX831654E</u>	<u>NP 831665E</u>	<u>Ref (1) Section 2 Table 1</u>
	<u>NP 831654E</u>	<u>  </u>	<u>  </u>
(4) Serial Number(s)	<u>  </u>	<u>K206-380-3RVF (coil only)</u>	<u>Ref (3) Section 3 Table 3.2</u>
	<u>  </u>	<u>  </u>	<u>  </u>
(5) Identify Component- Unique checksheet attached:	<u>See TAB F</u>	<u>6</u>	<u>Ref (1) Section 2 Table 1</u>
	<u>  </u>	<u>2</u>	<u>Ref (3) Section 3 Table 3.2</u>

JUSTIFICATION/COMMENTS See "Similarity Table", page 6

## ASCO SOLENOID VALVES

## MODEL NP8316 SERIES

SIMILARITY TABLE

Specification	ASCO Test Valve Model No. NP831665E	TVA Valve Model No. NPK831654E	TVA Valve Model No. NP831654E
Description	Three-way direct acting solenoid valve with packless const	Same	Same
Application	Pilot Vlv Controlling Oil Free Instr Air	Same	Same
Form of Flow	Normally Closed	Same	Same
Pipe Size	3/8"	3/8"	3/8"
Orifice Size	5/8"	5/8"	5/8"
Body Material	Brass	Brass	Brass
Coil Class	H	H	H
Seat & Disc Material	Ethylene Propylene	Ethylene Propylene	Ethylene Propylene
Disc Holder Material	303 Stainless Steel	303 Stainless Steel	303 Stainless Steel
Core Tube Material	300 Series Stainless Steel	300 Series Stainless Steel	300 Series Stainless Steel
Core Material	400 Series Stainless Steel	400 Series Stainless Steel	400 Series Stainless Steel
Coil Enclosure	NEMA 4,7,9	NEMA 6	NEMA 6
Maximum Operating Pressure			
Differential	175 psi	175 psi	175 psi
Nominal Voltage	125V DC	125V DC	125V DC
Power Rating	17.4 Watts	17.4 Watts	17.4 Watts
Conduit Connection	3/4" NPT	1/2" NPT	3/4" NPT
Applicable Form Number	V5967	V5967R1	V5967 R1
Terminal Connection	Pigtails (Splice)	Pigtails (Splice)	Pigtails (Splice)
Ambient Temperature	32 - 140°F	120°F - as specified	120°F - as specified
Maximum Fluid Temperature	180°F based on 140°F Ambient	Same	Same
Safe Working Pressure	300 psig	Same	Same

Notes: From Test Report  
AQS-21678 TR/Rev A (TAB D-1)  
Form V5967 (TAB D-1) & ASCO  
Cat. NP-1 (TAB E-5)

Notes: From Contract 827551.  
(TAB E-1) Form V5967 R1  
(TAB H) & ASCO Cat. NP-1  
(TAB E-5). "X" in Model  
Number denotes 1/2" NPT  
conduit connection.

Notes: From Contract 835541 (TAB E-3)  
Form V5967 R1 (TAB H) & ASCO Cat.  
NP-1 (TAB E-5)

Preparer/Date	<u>E. E. M. Bel</u>	<u>7/14/86</u>	<u>R</u>	<u>R</u>	<u>R</u>
Checked/Date	<u>W. P. King</u>	<u>7/16/86</u>			



BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 7 OF 33  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EEM DATE 7/14/86  
 MODEL NP8316 SERIES \_\_\_\_\_ CHECKED W/BK DATE 7/16/86

F. INSTALLATION INTERFACES

Does the qualification program address all relevant interfaces of the equipment so that the installed design and configuration is similar or identical to the test configuration (yes/no/NA)? (note below)

<u>Interface</u>	<u>Identify Interface Requirement</u>	<u>Acceptable? (Yes/No/NA)</u>	<u>Reference Test Report</u>
Mounting Bolts	None Specified, See TAB C-1, "Interfaces" For Typical Discussion, TABS C-2 through C-4 Identical	<u>N/A</u>	_____
External Process Connections	See TAB C-1 through C-4	<u>N/A</u>	See Below and Ref(3) App. A, Pg A2
Electrical Connections	None specified, See TAB C-1, "Interfaces" for Typical Discussion, TAB C-2 through C-4 Identical	<u>N/A</u>	_____
Conduit Seals	See TAB C-1 through C-4 "Conduit Seals"	<u>N/A</u>	Ref(3) Section 5.3
Connector Seals	<u>N/A</u>	<u>N/A</u>	_____
Orientation	<u>Any orientation</u>	<u>Yes</u>	See Note Below
Physical Configuration	Conduit/junction box must be orientated such that moisture does not drain into coil housing	<u>N/A</u>	Ref (3) Sec. 5.3 & P-1 this Tab
Other	<u>NONE</u>	_____	_____

JUSTIFICATION/COMMENTS ASCO does not identify specific interfacing requirements except as follows: (1) ASCO requires a 90° street elbow facing downward connected to exhaust port or similar configuration to prevent moisture intrusion from liquid spray. This is required only on valves located inside containment and subject to containment spray. (2) Flowing Medium must be oil-free instrument air and a strainer or filter must be installed on the inlet as close to the valve as possible. See TAB C for a description of the TVA interfaces and TAB J-2 for discussion of TVA instrument air system.

NOTE: See ASCO letter in TAB E-7.

PAGE B-10

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 8 OF 33  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE M DATE 7/14/86 R     R      
 MODEL NP8316 SERIES            CHECKED WJK DATE 7/16/86

G. TEST SEQUENCE

(1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	Ref (3) p 8 & Ref (1) App.A, <u>Sec. 9.4.2.1</u>
(b) Baseline performance measurements taken	<u>Yes</u>	Ref (3) p 8 & Ref (1) App.A, <u>Sec. 9.4.2.2</u>
(c) Equipment aged:		Ref (1) App. A, Sec. 9.4.2.3.1 & <u>Ref (3), p 8</u>
Thermal	<u>Yes</u>	Ref (1) App. A, Sec. 9.4.2.3.2
Radiation	<u>Yes</u>	<u>&amp; Ref (3), App D</u>
Wear	<u>Yes</u>	Ref (1) App. A, Sec. 9.4.2.3.3 <u>&amp; Ref (3), p 12</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	Ref (1) App. A, Sec. 9.4.2.3.4 <u>&amp; Ref (3), p 15</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	Ref (1) App. A, Sec. 9.4.2.4 <u>&amp; Ref (3), p 19</u>
(f) Post-DBE exposure	<u>Yes</u>	Ref (1) App. A, Sec. 9.4.2.4 <u>&amp; Ref(3), p 23</u>
(g) Final inspection and disassembly	<u>Yes</u>	Ref (1), App.A, Sec. 9.4.3 <u>&amp; Ref (3), p 24</u>

(2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes

(3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes (Reference: Ref (1), App. C., Ref (3), Appendix G).

JUSTIFICATION/COMMENTS AQR-67368, Rev 1 was utilized to qualify the Class H coils. Reference to this report is in regard to coil qualification only unless otherwise noted.

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 9 OF 33  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE M DATE 7/14/86 R     R      
 MODEL NP8316 SERIES CHECKED WPK DATE 7/16/86

H. AGING

- (1) Was aging considered in the qualification program (Yes/no/NA)? Yes (Reference Ref (1) Sec. 4.2, App. A, Sec. 9.4.2.3 & Ref (3) Sec. 4.1, App. A, Section. 9.4 ).

JUSTIFICATION/COMMENTS See TAB C-1 Thru C-4

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u> Ref (1), App.A
Thermal aging	<u>Yes</u>	<u>9.4.2.3.1</u> Section
Radiation exposure	<u>Yes</u>	<u>9.4.2.3.2</u> Section
Vibration (non-seismic) aging	<u>Yes</u>	<u>9.4.2.3.4</u> Section
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	<u>9.4.2.3.3</u>

JUSTIFICATION/COMMENTS In addition, See Reference (3), Section 9.4

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? Yes (Reference NA ).

JUSTIFICATION/COMMENTS See Discussion, Section P-4.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program (yes/no/NA)? Yes (Reference Ref (1) App. A, Sec. 9.4.2.3.1 Ref (3) App. A, Section. 9.4.1 ).

JUSTIFICATION/COMMENTS See TAB C-1 Thru C-4 "Aging".

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 10 OF 33  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE M DATE 7/14/86 R     R      
 MODEL NP8316 SERIES CHECKED WPK DATE 7/16/86

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes (Reference: Ref (2) Sections 1-6 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference Ref (2) Sections 1-6 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference Ref (1) App. A Section 9.4.2.3.1 & Ref. 3, App. A, Section 9.4.1 ).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	<u>   *</u>	<u>   *</u>	<u>   *</u>
Time	<u>                    </u>	<u>                    </u>	<u>                    </u>

JUSTIFICATION/COMMENTS \*See TAB C-1 through C-4, "Aging".  
 \_\_\_\_\_

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference Ref (2) Section 6 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? Yes (Reference Ref (2), Section 4 ).



BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 12 OF 33  
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EGM DATE 7/4/86 R     R      
MODEL NP8316 SERIES     CHECKED WJK DATE 7/16/86

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (yes/no/NA)? Yes (Reference Ref (1) Section 4.3, App. D Ref (3) App. D ).

Plant normal ambient radiation dose (rd) Various -See TABS C-1 through C-4

Test exposure dose (rd) 5 x 10<sup>7</sup> - Aging

1.5 x 10<sup>8</sup> - Accident

Test exposure dose rate (rd/hr) 5.1 x 10<sup>5</sup> for 99 hours

8.0 x 10<sup>5</sup> for 188.5 hours  
accident

Test exposure source type (e.g., Co-60 gamma)

Co-60 gamma

JUSTIFICATION/COMMENTS \_\_\_\_\_

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference Ref (1), Section 4.5, Ref (3), Section 4.1.5 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (b) Was the basis for vibration aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference Ref (1) App. A Section 8.1.6, Ref (3), App. A, Sec. 9.4.5 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference (1) Section 4.4, Ref (3) Section 4.1.2 ).

BINDER NO. WBNEQ-SOL-006 PLANT \_\_\_\_\_ WBN \_\_\_\_\_ UNIT(S) 1 SHEET 13 OF 33  
BINDER TITLE ASCO SOLENOID VALVES COMPUTED CEM DATE 7/14/86 R \_\_\_\_\_ R \_\_\_\_\_  
MODEL NP8316 SERIES CHECKED WJK DATE 7/16/86

H. AGING (Continued)

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference Ref (1) App. A Section 7.1 & 5.2, Ref (3), App. A, Section 9.4.2 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (yes/no/NA)? Yes (Reference Ref (2), Section 6 Ref (1), Section 3.2.2, Ref (3), Appendix C, p. C-8 ).

Qualified life (Document in QMDS) 40 years at 140°F (Coil)  
8 years at 140°F (EPDM)

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (yes/no/NA)? Yes (Reference Ref (2) Section 8 ).

Replacement Intervals (Document in QMDS) See QMDS TAB G.

JUSTIFICATION/COMMENTS Replacement interval depends upon maximum normal ambient temperature and percentage time solenoid valve is energized.

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 14 OF 33  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE M DATE 7/14/86 R     R      
 MODEL NP8316 SERIES CHECKED WPK DATE 7/16/86

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of EQC Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>EPDM</u>	<u>1 x 10<sup>7</sup></u>	<u>See Tab E6</u>	<u>0.94</u>	<u>Ref (2) Sec. 4.1.1</u>
(b) <u>VITON</u>	<u>5 x 10<sup>6</sup></u>	<u>See Tab E6</u>	<u>1.04</u>	<u>Ref (2) Sec. 4.1.2</u>
(c) <u>NOMEX</u>	<u>7 x 10<sup>6</sup></u>	<u>See Tab E6</u>	<u>0.96</u>	<u>Ref (2) Sec. 4.1.3</u>
(d) <u>MAGNET-WIRE ENAMEL</u>	<u>1 x 10<sup>7</sup></u>	<u>See Tab E6</u>	<u>1.16</u>	<u>Ref (2) Sec. 4.2.1</u>
(e) <u>ISO-MICA W/EPOXY</u>	<u>1 x 10<sup>9</sup></u>	<u>See Tab E6</u>	<u>1.00</u>	<u>Ref (2) Sec. 4.2.6</u>
(f) <u>SILICONE RUBBER LEAD WIRE INSULATION</u>	<u>1 x 10<sup>6</sup></u>	<u>See Tab E6</u>	<u>1.59</u>	<u>Ref (2) Sec. 4.2.5</u>

JUSTIFICATION/COMMENTS The above materials are those with lowest activation energies listed in Reference (2), Section 4.1 and 4.2. Radiation threshold values are typical for these materials and are listed for information only. These values were not taken from the test report, but were supplied by the Digital Engineering System 1000, Materials Data Base.  
(SEE TAB E6).



BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 15 OF 33  
BINDER TITLE ASCO SOLENOID VALVES COMPUTED CEM DATE 7/14/86 R    R     
MODEL NP8316 SERIES    CHECKED WJK DATE 7/16/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference Ref (1), App. A, Sec.6.1 & 6.2 ).

Identify Acceptance Criteria: Valves must operate from 90-140VDC at minimum and maximum operating pressure differential. Coil insulation resistance must be a minimum of 1.0 megohm at 500VDC. During Hypot test, current leakage must be less than 0.5 milliamp at twice the rated voltage plus 1000VAC applied for a period of one minute. Valves must operate at test or low voltage condition (90VDC) at maximum pressure differential under all conditions. Valves are not to have a pressure build-up at a vented cylinder port or a pressure decrease at a cylinder port which is required to be pressurized in excess of 10% the nominal inlet supply pressure under all postulated environmental conditions.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference Ref (1) Section 4.1 ).

Identify baseline and functional testing: Recording coil excitation seat leakage, noise test, operational test, external leakage in energized and de-energized state before and after thermal, radiation, wear and vibration aging, and accident radiation and LOCA simulation. Measurement of insulation resistance & coil dielectric tests before thermal aging & after completion of accident radiation and LOCA simulation.

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes (Reference Ref (1) Appendix A, Section 7.0 ).

- (4) Do the applied loads during baseline testing reflect normal operating conditions (yes/no/NA)? Yes (Reference Ref (1), Section 4.8 & Ref (3), Table 4.3 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 16 OF 33  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED ESM DATE 7/14/86 R    R     
 MODEL NP8316 SERIES                      CHECKED WJK DATE 7/16/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

(5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a)

<u>Parameter</u>	<u>Specified Accident Conditions</u>	<u>Reference</u>
Voltage	_____	_____
Load	_____	_____
Frequency	<u>NA (All valves DC powered)</u>	<u>NA</u>
Accuracy	<u>NA</u>	<u>NA</u>
Other(s)	_____	_____

JUSTIFICATION/COMMENTS \_\_\_\_\_

(b)

<u>Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>
Voltage	<u>90VDC</u>	Ref(1) Table 4 p 4-24 & Table 5 <u>p 4-25</u>
Load	<u>20 WATTS</u>	Ref(3) Table 4.3 & NP-1 Catalog <u>p 5 TAB E-5</u>
Frequency	<u>NA</u>	<u>NA</u>
Accuracy	<u>NA</u>	<u>NA</u>
Other(s)	_____	_____

JUSTIFICATION/COMMENTS A primary concern with solenoid valves is that of voltage available at the coil terminals. The tested valve successfully completed functional testing at the minimum 90VDC.

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 17 OF 33  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE M DATE 7/14/86  
 MODEL NP8316 SERIES \_\_\_\_\_ CHECKED WJK DATE 7/14/86

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. Various - See TABS C-1 through C-4

- |                                     |                                     |
|-------------------------------------|-------------------------------------|
| (1) Normal Max                      | (2) Abnormal Max                    |
| (a) Temperature (°F) <u>Various</u> | (a) Temperature (°F) <u>Various</u> |
| (b) Pressure (psig) <u>Various</u>  | (b) Pressure (psig) <u>Various</u>  |
| (c) Humidity (%) <u>Various</u>     | (c) Humidity (%) <u>Various</u>     |
| (d) Radiation (rd) <u>Various</u>   | (d) Radiation (rd) <u>Various</u>   |
- (3) Process Interfaces: The process fluid for these valves is oil-free instrument air with a maximum design temperature of 100°F. Therefore, the bounding temperature for these valves is the ambient.
- (4) State anticipated occurrence frequency and duration of abnormal conditions: Will occur less than 1 percent of plant life and could exist for up to 8 hours per excursion.
- 
- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile): \*
- |                      |                             |               |                  |
|----------------------|-----------------------------|---------------|------------------|
| (a) Temperature (°F) | <u>327°F</u>                | Accident type | <u>LOCA/HELB</u> |
|                      | <u>26.4 psia</u>            |               |                  |
| (b) Pressure (psig)  | <u>(12 psig)</u>            | Accident type | <u>LOCA/HELB</u> |
| (c) Humidity (%)     | <u>100%</u>                 | Accident type | <u>LOCA/HELB</u> |
| (d) Radiation (rd)   | <u>1.2 x 10<sup>8</sup></u> | Accident type | <u>LOCA/HELB</u> |
|                      | <u>2000 PPM BORON</u>       |               |                  |
| (e) Spray Type       | <u>H BO PH 8.3</u>          |               |                  |
|                      | <u>2 3</u>                  | Accident type | <u>LOCA/HELB</u> |

\*See TABS C-1 through C-4.

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 18 OF 33  
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE M DATE 7/14/86 R     R      
MODEL NP8316 SERIES CHECKED WAK DATE 7/16/86

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.):

The worse case accident profile combination was not utilized as the enveloping environment. Qualification to the environment would only produce replacement/refurbishment schedules which would be overly conservative for many of the valves. Qualification and replacement schedules were based on valve specific environments which are defined in TAB C-1 through C-9, TAB G defines the maintenance which is reflective of these environments.

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (yes/no/NA)? Yes (Reference See P.1 "Discussion" ).
- (7) Subject to submergence (yes/no/NA)? Yes (Reference See P.1 Discussion, TAB C-4 ).

Identify initiation time and duration of submergence: Following an accident inside primary containment, valves identified in TAB C-4 and located below elevation 722' inside the crane wall or 717.7' outside the crane wall are subject to submergence. No valves located outside containment and covered by this binder are subject to submergence.

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 19 OF 33  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EM DATE 9/19/86 R     R      
 MODEL NP8316 SERIES     CHECKED WBK/ DATE 9/19/86

K. REQUIRED OPERATING ENVIRONMENT (Continued)

(8) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
Category and Operating Times	
System 61 (WBNO SG4-012)	B45 860325 218
System 62 (WBNO SG4-013)	B45 860320 223
System 63 (WBNO SG4-014)	B45 860314 219
System 65 (WBNO SG4-015)	B43 860326 222
System 68 (WBNO SG4-017)	B45 860722 218
System 77 (WBNO SG4-021)	B45 860313 219
System 81 (WBNO SG4-023)	B45 861127 219
System 87 (WBNO SG4-025)	B45 860313 218
Status and Duty Cycles of IE Solenoid Valves Located in Potentially Harsh Environments (WBN-OSG4-045)	B45 860902 219
Solenoid Valve Voltage Study (WBPE VAR 8602002)	Later
Identification of Harsh Environmental Areas with High Potential for Condensate Formation (GENNAL6-002)	B45 860812 236

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 20 OF 33  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EM DATE 9/20/86 R     R      
 MODEL NP8316 SERIES CHECKED WBK/mm DATE 9/20/86

K. REQUIRED OPERATING ENVIRONMENT (Continued)

(8) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
Integrated Accident Dose Inside Containment (TI-RPS-48)	B45 851105 235
Flooding in Aux. Building Due to Postulated Pipe Breaks (WBNSG4-44)	B45 860110 218
Beta Dose Reduction by PVC-Covered Conduit Inside Containment (GENNAL3-003)	B45 851210 236
Reduction of Beta Dose by Sheet Steel (GENNAL3-002)	B45 851210 235
Water Level in the Primary Containment Following the CVCS HELB (QIR NEB85069)	B45 851030 255
Maximum Containment Water Level	NEB 840120 220
Flooding Level Outside the Crane Wall Following Main Feedwater (MFW) and Main Steamline Break (MSLB) (WBNNAL6-005)	B45 860520 235
Reverification of Model Number of Valve 1-FSV-061-0194-B (QIR WBN EQC 86004)	T37 860919 808

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 21 OF 33  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE m DATE 7/14/86 R     R      
 MODEL NP8316 SERIES     CHECKED WJK DATE 7/16/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100 Days</u>	<u>30 Days</u>	Ref (1) <u>Fig 2</u>
Temperature (°F)	<u>327°F</u>	<u>346°F</u>	Ref (1) <u>Sec 4.7</u>
Pressure (psig)	<u>26.4 psia</u> <u>(12 psig)</u>	<u>110 psig</u>	Ref (1) <u>Sec 4.7</u>
Relative Humidity (%)	<u>100%</u>	<u>100%</u>	Ref (1) <u>Sec 4.7</u>
	<u>2000ppm Boron H<sub>2</sub>B<sub>3</sub></u>	<u>3000ppm Boron</u>	Ref (1)
*Chemical Spray	<u>ph 8.3</u>	<u>ph 9.5-10.5</u>	<u>Sec 4.7</u>
**Radiation (rd)	<u>1.2 x 10<sup>8</sup></u> rads gamma	<u>2.01 x 10<sup>8</sup></u> rads	Ref (1) <u>App D</u>
Submergence	<u>Yes</u>	<u>Yes</u>	See P.1 <u>"Discussion"</u>

\*Includes spray concentration, flowrate, density, duration, and pH.

\*\*Enter 40-year integrated normal dose plus integrated accident dose and specify type.

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 22 OF 33  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE M DATE 7/14/86 R     R      
 MODEL NP8316 SERIES CHECKED WAK DATE 7/16/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified</u> (Yes/No/NA)	<u>Reference</u>
Temperature	<u>Yes</u>	<u>See (1) above</u>
Pressure	<u>Yes</u>	<u>See (1) above</u>
Relative Humidity	<u>Yes</u>	<u>See (1) above</u>
Chemical Spray	<u>Yes</u>	<u>See P. 2 "Discussion"</u>
Submergence	<u>Yes</u>	<u>See P. 1 "Discussion"</u>
<u>JUSTIFICATION/COMMENTS</u>		



BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 23 OF 33  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EEM DATE 7/14/86 R     R      
 MODEL NP8316 SERIES     CHECKED WPK DATE 7/17/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, yes/no/NA)

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	<u>+19°F</u>	<u>Yes</u>
Pressure: +10% but no more than 10 psig	<u>+98psig</u>	<u>Yes</u>
Radiation: +10% of accident dose	<u>+67.5%</u>	<u>Yes</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>NONE</u>	<u>Yes*</u>
Voltage: ± 10% of rated value	<u>No**</u>	<u>No**</u>
Frequency: ± 5% of rated value	<u>N/A</u>	<u>N/A</u>
Environmental Transient: the initial transient and the peak temperature applied twice	<u>Yes</u>	<u>Yes</u>
Vibration: +10% added to acceleration (during seismic testing)	Ref (1), Section 9.4.2.4.2 Ref (3), Sec. 4.1.6	<u>Yes</u>

JUSTIFICATION/COMMENTS: \*Accident degradation calculation (See TAB

C) proves that the 30-day test envelops the 100-day post-accident requirement. See Generic Binder WBNEQ-GEN-001, Section III.C.4.

\*\*The valve was tested at a minimum 90VDC during operability testing which is better proof of operability than increased coil voltage.

During all other tests, either the nominal voltage of 125VDC or the test current of .074 amps was used.

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 24 OF 33  
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE M DATE 7/14/86 R     R      
MODEL NP8316 SERIES CHECKED WJK DATE 7/16/86

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:  
(Reference See TAB A and TAB C ).

JUSTIFICATION/COMMENTS Functions are varied. All are listed in  
TAB A and TABS C-1 through C-4.

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes (Reference Ref (1) Section 5 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? Yes (Reference Ref (1) Section 5 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? No (Reference \_\_\_\_\_ ).

JUSTIFICATION/COMMENTS See TABS C-1 through C-4 for the analysis  
of the test DBA versus the plant specific DBA.

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? Yes (Reference Ref (1) Table 2F  
Ref (3), App. J ).

JUSTIFICATION/COMMENTS TVA has reviewed test anomalies and concurs  
with disposition.



BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 26 OF 33  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED SEM DATE 7/14/86 R     R      
 MODEL NP8316 SERIES            CHECKED WJK DATE 7/16/86

0. SUMMARY OF REVIEW

- |  | <u>Yes/No/NA</u> |
|--|------------------|
| (1) Documented evidence of qualification adequate<br>(Have all assumptions, mathematical models, and<br>all extrapolations of test data used in an<br>analysis been justified and documented)? | <u>Yes</u>       |
| (2) Any exceptions (i.e., sound reasons to the contrary)<br>taken to the specified qualification level<br>adequately justified?  | <u>NA</u>        |
| (3) Choice of qualification methodology adequately<br>justified?   | <u>Yes</u>       |
| (4) If analysis was performed, complete the following:   |                  |
| (a) Were equipment performance requirements<br>identified?   | <u>NA</u>        |
| (b) Were specific features and failure modes and<br>effects analyzed?  | <u>NA</u>        |
| (c) Were assumptions and mathematical models used<br>together with appropriate justification for<br>their use?   | <u>NA</u>        |
| (d) Were environmental parameters which affect<br>equipment performance identified?  | <u>NA</u>        |
| (5) Adequate similarity between equipment and test<br>specimen established?  | <u>Yes</u>       |
| (6) Aging degradation evaluated adequately?  | <u>Yes</u>       |
| (a) Mechanical and/or cycle aging addressed?   | <u>Yes</u>       |
| (b) Equipment aged to end of life condition prior to<br>application of DBE conditions?   | <u>Yes</u>       |
| (c) Absence of preaging in test/analysis justified?  | <u>NA</u>        |
| (d) Materials susceptible to thermal/radiation<br>aging identified?  | <u>Yes</u>       |

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 27 OF 33  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE M DATE 7/14/86 R     R      
 MODEL NP8316 SERIES CHECKED WAK DATE 7/16/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>Yes</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>Yes</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>Yes</u>
(11) Criteria regarding submergence satisfied?	<u>Yes</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes*</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

\*See P. 3 "Discussion".

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 28 OF 33  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EM DATE 7/14/86 R     R      
 MODEL NP8316 SERIES     CHECKED WPK DATE 7/16/86

O. SUMMARY OF REVIEW (Continued)

- |  | <u>Yes/No/NA</u> |
|--|------------------|
| (15) Criteria regarding functional testing satisfied?  | <u>Yes</u>       |
| (a) Does the test plan/report specify an acceptance criteria for equipment performed?  | <u>Yes</u>       |
| (b) Was an initial base line test done to establish required performance characteristics?  | <u>Yes</u>       |
| (c) Has the test/analysis demonstrated that performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? | <u>Yes</u>       |
| (16) Criteria regarding instrument accuracy satisfied?   | <u>NA</u>        |
| (17) Test duration margin (1 hour + function time) satisfied?  | <u>Yes</u>       |
| (a) Is the minimum specified operating time at least 1 hour?   | <u>Yes</u>       |
| (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided?  | <u>NA</u>        |
| (18) Criteria regarding synergistic effects satisfied?   | <u>NA</u>        |
| (19) Criteria regarding margins satisfied?   | <u>Yes</u>       |
| (20) Maintenance and surveillance requirements adequately identified?  | <u>Yes</u>       |

P. DISCUSSION

1. Moisture or liquid intrusion and submergence (Sec. K(6) & K(7)).  
Any TVA solenoid valves which must operate for more than 1 hour and are subject to moisture intrusion have a conax seal installed. However, all solenoid valves covered by this binder that are subject to moisture intrusion or submergence are required to operate only 1 hour into an accident, de-energize and remain de-energized.

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 29 OF 33  
BINDER TITLE ASCO SOLENOID VALVES COMPUTED CEM DATE 7/14/86 R     R      
MODEL NP8316 SERIES CHECKED WPK DATE 7/16/86

P. DISCUSSION (Continued)

Each solenoid valve is enclosed in a NEMA 6 Enclosure. Per NEMA  
publication 250 section 3.09 (c), the design test required for a NEMA  
6 rating requires the enclosure to be submerged to a depth of 6 feet  
of water for 30 minutes without moisture intrusion. In addition,  
testing done by Wyle Laboratories for TVA (see Test Report TAB D-5  
and letter TAB E-10) demonstrated that an ASCO solenoid valve  
(specimen A) operated 114.5 hours and a second valve (specimen D)  
operated for the full 30 day LOCA test with their enclosures full  
of water. Based on the above facts, we conclude that these valves  
will operate for 1 hour regardless of moisture intrusion from  
either submergence or condensation. See TAB C, Section C-5 for  
additional discussion on submerged valves.

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 30 OF 33  
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE m DATE 9/19/86 R     R      
MODEL NP8316 SERIES                      CHECKED WBK/2/86 DATE 9/19/86

P. DISCUSSION (Continued)

2. Chemical Spray (Sec L. (1) & (2)).

The containment spray flow rate is equal to 9500 gal/min or 0.92  
gpm per square foot of containment cross section. The spray duration  
is 30 days. The chemical spray composition is an Alkaline borate  
solution (ph 8.3) produced by mixing boric acid ( $H_3BO_3$ ) with sodium  
tetraborate ( $Na_2B_4O_7 \cdot 10 H_2O$ ). The ASCO test valve was subjected  
to a spray solution of 3000ppm Boron as Boric Acid in solution with  
0.064 molar sodium thiosulfate buffered with sodium hydroxide to a pH  
value of 10 at room temperature at a rate of 0.306 gpm per square  
foot of area covered by the spray for the full 30 days of the test.  
The test solution is more corrosive than the containment spray.  
Therefore all valves listed in this binder subjected to containment  
spray fall within the qualification provided by the test valve.

Reference: Environmental Drawings 47E235-41 and -42.



BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 31 OF 33  
BINDER TITLE ASCO SOLENOID VALVES COMPUTED CEM DATE 9/19/84 R     R      
MODEL NP8316 SERIES                      CHECKED WBK/akm DATE 9/19/84

P. DISCUSSION (Continued)

3. Beta Radiation (Sect. 0.12.b)

Beta Radiation must be addressed for all equipment located inside  
containment. Solenoid valves Groups A, and D (see Tab C) are located  
inside containment. Group B is located in the Annulus area. Per Environ-  
mental Drawing 47E235-44 R1 the accident radiation dose consists  
of  $1.2 \times 10^7$  rads Gamma and a Beta contribution of  $6 \times 10^5$  rads. Since  
the ASCO solenoid valves in Group B are qualified for the 40-year normal  
plus the 100 day accident combined Beta and Gamma doses, no credit for  
reduction of Beta dose was required.

However, for those valves located inside containment in the upper compart-  
ment (Group A, environmental drawing 47E235-41 R1) and lower compartment  
(Group D, environmental drawing 47E235-42 R2) this is not true.  
Additional analysis of Beta radiation is required.

All non-metallic parts of the solenoid valve are totally enclosed by metal  
with the exception of the 18" wire pigtails. The minimum thickness of  
metal is assumed to be the coil housing which is  $3/32$  (0.09375 in.)  
steel. OE calculation GENNAL3-002 (B45 851210 235) "Reduction of Beta  
Dose by Sheet Steel" page 3.1 shows the Beta reduction factor for 14  
gauge (0.0747) in.) steel is equal to 0.0562. This reduces the total  
Beta dose to the valve internal parts to  $(5.0 \times 10^8)$  ( $5.62 \times 10^{-2}$ ) =  
 $2.81 \times 10^7$  rads TID. The total combined Beta and Gamma accident  
radiation dose will equal  $(2.81 \times 10^7 \text{ Beta}) + (4.0 \times 10^7 \text{ Gamma}) = 6.81 \times 10^7$

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 32 OF 33  
BINDER TITLE ASCO SOLENOID VALVES COMPUTED ESM DATE 7/14/86 R     R      
MODEL NP8316 SERIES CHECKED WJK DATE 7/16/86

P. DISCUSSION (Continued)

3. Beta Radiation (Sect. 0.12.b)

rads. Combined accident radiation plus the larger lower compartment 40-  
year dose ( $2.0 \times 10^7$  versus  $1.0 \times 10^6$ ) equals a total radiation of  $8.81 \times$   
 $10^7$  rads TID. These valves are qualified for  $2.0 \times 10^8$  rads TID.

The pigtail leads are covered by 3/4 inch diameter flexible stainless  
steel conduit (see Watts Bar conduit and grounding drawings 45N862-15,  
45N866-7, and 45N860-5,7). Since these valves are required to operate for  
only 5 minutes for a LOCA, the pigtails are not required to be qualified  
for the full 100 day Beta dose. OE calculation TI-RPS-48 (B45 851105 235)  
"Integrated Accident Dose Inside Primary Containment" Table VI-14, page  
7.24 shows the total Beta dose at two hours into the accident to equal  
 $4.12 \times 10^7$  rads TID. OE calculation GENNAL3-003 (B45 851210 236) "Beta  
Dose Reduction by PVC-covered Conduit Inside Primary Containment", Table  
11, page 20.3 shows the minimum reduction factor for 1/2 or 3/4 inch  
conduit to be 0.471. This reduces the two hour Beta dose to ( $4.12 \times 10^7$ )  
 $(4.71 \times 10^{-1}) = 1.94 \times 10^7$  rads TID Beta. The total combined Beta and  
Gamma radiation dose will equal ( $1.94 \times 10^7$  Beta) + ( $4.0 \times 10^7$  Gamma) =  $5.94$   
 $\times 10^7$  rads TID. Accident radiation plus the larger lower compartment 40-  
year dose ( $2.0 \times 10^7$  rads) equals a total radiation dose of  $7.94 \times 10^7$  rads  
TID. These valves are qualified for  $2.0 \times 10^8$  rads.

BINDER NO. WBNEQ-SOL-006 PLANT WBN UNIT(S) 1 SHEET 33 OF 33  
BINDER TITLE ASCO SOLENOID VALVES COMPUTED CEM DATE 7/14/86 R     R      
MODEL NP8316 SERIES CHECKED WPK DATE 7/16/86

P. DISCUSSION (Continued)

4. Synergistic Effects (Sec. H(3))

Ethylene Propylene Terpolymer (EPDM) elastomer is used in the construction of ASCO solenoid valves as gaskets and diaphragms. EPDM is the only material having a potential for radiation induced synergisms based on a review of technical information provided in NUREG/CR-2157 and NUREG/CR-2553. Data in NUREG/CR-2157 suggests that dose rate effects in EPR materials are insignificant up to doses of 10 to 20 MRADs. A review of the location and environments of ASCO solenoid valves listed in TABs C-1 through C-4 indicate that the maximum normal radiation dose will be seen by valves in subgroup D-2. These valves are qualified for 40 years without replacement of elastomer parts and will therefore be exposed to a maximum normal dose of 20 MRADs. Since all elastomer parts are totally enclosed in metal, the radiation dose to these parts will be less than 20 MRADs. Synergistic effects will be negligible for normal service aging.

Potential dose rate and test sequence synergisms will not impact qualification for accident conditions as demonstrated by Test Report AQS-21678. The test sequence of thermal aging followed by radiation aging plus accident radiation at high (0.8 MRAD/HR) dose rate is a reasonable simulation of actual plant requirements. Additional assurance is provided by the severity of the radiation test because the test valve was exposed to 201 MRADs whereas an actual dose of about 60 MRADs (40 MRADs accident plus 20 MRADs normal service) is required.

PAGE B-36

EQP099.51

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 1 OF 1  
BINDER TITLE ASCO SOLENOID VALVES - COMPUTED EEW DATE 7/24/86 R     R      
MODEL NP 8321 SERIES CHECKED JW DATE 7/28/86

TAB A  
EQUIPMENT IDENTIFICATION MATRIX

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WBNQ-SOL -007  
 MANUFACTURER: ASCO  
 PAGE: 1 OF 1

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT**	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						
WBN-2-FSV -065-0004	-B 2-FSV -065-0004	-B CNTMT ANN VAC FAN ISLN DMPR	NPB321			757'	A16		L	A/B	5MIN/1000	MUST DEENERGIZE TO CLOSE DAMPER AFTER PHASE A CNTMT ISOL SIGNAL TO ISOLATE VACUUM FANS.
WBN-2-FSV -065-0005	-A 2-FSV -065-0005	-A CNTMT ANN VAC FANS ISLN DMPR	NPB321A2E	VA12		757'	A16	80KJ3-827551	L	A/B	5MIN/1000	MUST DEENERGIZE TO CLOSE DAMPER ON A PHASE A CNTMT ISLN SIGNAL TO ISOLATE VACUUM FANS.
WBN-2-FSV -065-0009	-A 2-FSV -065-0009	-A EGTS TRAIN A UNIT 2 SUCTION	NPB321	UA13		757'	A16		L	B	1000	DAMPER IS NORMALLY CLOSED AND MUST REMAIN CLOSED DURING THE MITIGATION OF THIS ACCIDENT.
WBN-2-FSV -065-0029	-B 2-FSV -065-0029	-B EGTS TRAIN B UNIT 2 SUCTION	NPB321A2E	UA13		757'	A16	80KJ3-827551	L	B	1000	DAMPER IS NORMALLY CLOSED AND MUST REMAIN CLOSED DURING THE MITIGATION OF THIS ACCIDENT.

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

\*\* CONTRACT NUMBERS SHOWN IN THIS TAB WERE OBTAINED BY TRACING THE SERIAL NUMBER ON EACH VALVE THROUGH  
 TVA PROCUREMENT RECORDS AND DID NOT DEPEND ON FIELD VERIFICATION DATA FOR CONTRACT NUMBERS.

PREPARER/DATE E. E. M. Be. 9/19/86  
 CHECKER/DATE fwl Vostan 9/18/86

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 1 OF 1  
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE M DATE 7/24/86 R     R      
MODEL NP8321 SERIES     CHECKED FW DATE 7/28/86

TAB B

ENVIRONMENTAL QUALIFICATION CHECKLIST

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 1 OF 28  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE M DATE 9/18/86 R     R      
 MODEL NP8321 SERIES     CHECKED fw DATE 9/18/86

**A. DOCUMENTATION**

Equipment Description Solenoid Valves  
 Vendor/Manufacturer ASCO  
 Equipment Model No.(s) NP8321A2E

**QUALIFICATION REPORTS (TAB D) (See also TAB "C" Discussion)**

- (1) Title/Number/Revision Automatic Switch Company RIMS B43 850627 322  
Test Report AQS21678/TR/Rev A DATE July 1979
- (2) Title/Number/Revision Automatic Switch Company RIMS B45 850514 428  
Test Report AQR-67368, Rev 1 DATE August 19, 1983
- (3) Title/Number/Revision ASCO Catalog NP-1 Valves RIMS NEB 840328 363  
AQS 21678/TR/Supplement 3 DATE March 8, 1983
- (4) Title/Number/Revision Franklin Research Center RIMS NEB 840925 351  
Test Report F-C5569-309/315, Appendix C DATE November 1983

OTHER (ANALYSIS, VENDOR DATA, ETC.) ASCO letters

- TAB E-5 Mounting Orientation RIMS B43 850502 015
- TAB E-6 Storage Instructions RIMS EEB 810108 025  
Shelf Life RIMS B71 860902 001
- TAB E-8 Periodic Operation RIMS EEB 840730 021
- TAB E-9 Coil Heat Rise Data RIMS B71 860512 001  
AND B71 860520 001

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 1A OF 28  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EEW DATE 9/18/86 R     R      
 MODEL NP8321 SERIES     CHECKED fw DATE 9/18/86

<u>Type</u>	<u>RIMS No.</u>
Category and Operating Times for Unit 2 Components Required for Unit 1 Operation	B45 860424 218
Status and Duty Cycles of IE Solenoid Valves Located in Potentially Harsh Environments (WBN-OSG4-045)	B45 860221 218
Solenoid Valve Voltage Study (WBPE VAR 8602002)	Later
Flooding in Aux. Building Due to Postulated Pipe Breaks (WBNOSG4-44)	B45 860110 218
Identification of Harsh Environmental Areas with High Potential for Condensate Formation (GENNAL6-002)	B45 851017 235
100-Day Loss of Coolant Accident Dose to Electrical Equipment in the EGTS Filter Train Room (WBNNAL3-031)	B45 860529 237



BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 2 OF 28  
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EEM DATE 9/19/86 R     R      
MODEL NP8321 SERIES     CHECKED fw DATE 9/18/86

B. CONCLUSION OF REVIEW (Check only one block)

- X Equipment Qualified  
 Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule  
 Equipment Qualification Not Established by Documentation  
 Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES 1) Voltage available to solenoid coils during accident conditions not determined.

2) Valve 2-FSV-65-4 not installed. Nameplate data not available for 2-FSV-65-9.

3) DOCUMENTATION USED BY FIELD TO INSTALL SOLENOID VALVES NOT IDENTIFIED.

*EEM  
9/22/86  
fw  
9/22/86*

COMMENTS/RECOMMENDATIONS None



BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 4 OF 28  
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE M DATE 7/24/86 R     R      
MODEL NP8321 SERIES     CHECKED fw DATE 7/28/86

D. QUALIFICATION METHODOLOGY (Check only one block)

    Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis

X Test of Similar Items with Supporting Analysis

    Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions

    Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS See "Similarity Table," page 6.

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 5 OF 28  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EGM DATE 7/31/86 R     R      
 MODEL NP8321 SERIES CHECKED lew DATE 7/31/86

**E. EQUIPMENT DESCRIPTION**

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? No

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Solenoid Vlv</u>	<u>Solenoid Vlv</u>	<u>                  </u>
(2) Manufacturer	<u>ASCO</u>	<u>ASCO</u>	<u>Ref (1)</u> <u>Section 2</u>
(3) Model Number(s)	<u>NP8321A2E</u>	<u>NP8321A5E</u>	<u>Table 1</u>
	<u>                  </u>	<u>K206-380-3RVF</u> <u>(coil only)</u>	<u>Ref (2)</u> <u>Table 3.2</u>
(4) Serial Number(s)	<u>See TAB F</u>	<u>Test</u> <u>Valve 8</u>	<u>                  </u>
	<u>                  </u>	<u>Test</u> <u>Valve 2</u>	<u>Ref (2)</u> <u>Section 3</u> <u>Table 3.2</u>
(5) Identify Component-Unique checksheet attached:	<u>None</u>	<u>                  </u>	<u>                  </u>

JUSTIFICATION/COMMENTS See "Similarity Table," page 6.  
Valve data sheets in TAB E indicate a NEMA 4 enclosure was  
specified. The valve furnished by ASCO has a NEMA 6 enclosure.  
The NEMA 6 enclosure is a tighter enclosure than NEMA 4.

## ASCO SOLENOID VALVES

## MODEL NP8316 SERIES

SIMILARITY TABLE

Specification	ASCO Test Valve Model No. NP8321A5E	TVA Valve Model No. NP8321A2E
Description	Three-way direct acting solenoid valve with packless const	Same
Application	Pilot Vlv Controlling Oil Free Instr Air	Same
Form of Flow	Normally Closed	Same
Pipe Size	1/4"	3/8"
Orifice Size	9/32" Pressure 11/32" Exhaust	9/32" Pressure 11/32" Exhaust
Body Material	Brass	Brass
Coil Class	H	H
Seals & Disc Material	Ethylene Propylene	Ethylene Propylene
Disc Holder Material	Stainless Steel	Stainless Steel
Core Tube Material	300 Series Stainless Steel	300 Series Stainless Steel
Core Material	400 Series Stainless Steel	400 Series Stainless Steel
Coil Enclosure	NEMA 4,7,9	NEMA 6
Maximum Operating Pressure		
Differential	150 psi	150 psi
Nominal Voltage	125V DC	125V DC
Power Rating	17.4 Watts	17.4 Watts
Conduit Connection	3/4" NPT	3/4" NPT
Applicable Form Number	V5971	V5971R1
Terminal Connection	Pigtails (Splice)	Pigtails (Splice)
Ambient Temperature	32 - 180°F	120°F - as specified
Maximum Fluid Temperature	180°F based on 140°F Ambient	Same
Safe Working Pressure	200 psig	Same
	Notes: From Test Report AQS-21678 TR/Rev A (TAB D-1) Form V5971 (TAB D-1) & ASCO Cat. NP-1 (TAB E-3)	Notes: From Contract 827551 (TAB E-1), Form V5971 R1 (TAB H) & ASCO Cat. NP-1 (TAB E-3)

R \_\_\_\_\_ R \_\_\_\_\_ R \_\_\_\_\_

 Preparer/Date E. E. McBea 7/24/86 \_\_\_\_\_  
 Checked/Date Flu ... 11/28/86 \_\_\_\_\_

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 7 OF 28  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EGM DATE 7/24/86 R     R      
 MODEL NP8321 SERIES     CHECKED FW DATE 7/28/86

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the test report and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if No, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	None specified; See <u>TAB C-3, "Interfaces"</u>	<u>N/A</u>	<u>   </u>
External Process Connections	<u>See TAB C-3</u>	<u>N/A</u>	<u>See Below and Ref (2) APP. A.p A2</u>
Electrical Connections	None specified; See <u>TAB C-3, "Interfaces"</u>	<u>N/A</u>	<u>   </u>
Conduit Seals	See <u>TAB C-3 "Conduit Seals"</u>	<u>N/A</u>	<u>Ref (2) Section 5.3</u>
Connector Seals	<u>N/A</u>	<u>N/A</u>	<u>   </u>
Orientation	<u>Any orientation</u>	<u>Yes</u>	<u>See Note Below</u>
Physical Configuration	Conduit/Junction box must be oriented such that moisture does not <u>drain into coil housing</u>	<u>N/A</u>	<u>Ref (2) Sect. 5.3 and TAB C-3</u>
Other	<u>None</u>	<u>   </u>	<u>   </u>

JUSTIFICATION/COMMENTS ASCO does not identify specific interfacing requirements except as follows: (1) ASCO requires a 90° street elbow facing downward connected to exhaust port or similar configuration to prevent moisture intrusion from liquid spray. This is required only on valves located inside containment and subject to containment spray. (2) Flowing medium must be oil-free instrument air and a strainer or filter must be installed on the inlet as close to the valve as possible. See TAB C for a description of the TVA interfaces and TAB J-2 for discussion of TVA instrument air system.

NOTE: See ASCO letter in TAB E-5.

PAGE B9

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 8 OF 28  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE m DATE 7/24/84 R     R      
 MODEL NP8321 SERIES \_\_\_\_\_ CHECKED lu DATE 1/28/86

G. TEST SEQUENCE

(1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	Ref (2), p 8 & Ref (1) App. A, <u>Sec. 9.4.2.1</u>
(b) Baseline performance measurements taken	<u>Yes</u>	Ref (2), p 8 & Ref (1) App. A, <u>Sec. 9.4.2.2</u>
(c) Equipment aged:		Ref (1) App. A, Sec. 9.4.2.3.1 & <u>Ref (2), p 8</u>
Thermal	<u>Yes</u>	Ref (1) App. A, Sec. 9.4.2.3.2 & <u>Ref (2), App. D</u>
Radiation	<u>Yes</u>	Ref (1) App. A, Sec. 9.4.2.3.3 & <u>Ref (2), p 12</u>
Wear	<u>Yes</u>	Ref (1) App. A, Sec. 9.4.2.3.4 & <u>Ref (2), p 15</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	Ref (1) App. A, Sec. 9.4.2.4 & <u>Ref (2), p 19</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	Ref (1) App. A, Sec. 9.4.2.4 & <u>Ref (2), p 23</u>
(f) Post-DBE exposure	<u>Yes</u>	Ref (1) App. A, Sec. 9.4.3 & <u>Ref (2), p 24</u>
(g) Final inspection and disassembly	<u>Yes</u>	

(2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes

(3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes (Reference: Ref (1), App. G; Ref (2), App. G).

JUSTIFICATION/COMMENTS AQR-67368, Rev 1 was utilized to qualify the Class H coils. Reference to this report is in regard to coil qualification only unless otherwise noted.

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 9 OF 28  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE m DATE 7/24/86 R     R      
 MODEL NP8321 SERIES     CHECKED Fuv DATE 7/28/86

H. AGING

- (1) Was aging considered in the qualification program (Yes/no/NA)? Yes (Reference Ref (1), App. A, Sec. 9.4.2.3 & Ref (2), App. A, Sec. 9.4 ).

JUSTIFICATION/COMMENTS See TAB C-3.

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u> Ref (1), App. A Section
Thermal aging	<u>Yes</u>	<u>9.4.2.3.1</u> Section
Radiation exposure	<u>Yes</u>	<u>9.4.2.3.2</u> Section
Vibration (non-seismic) aging	<u>Yes</u>	<u>9.4.2.3.4</u> Section
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	<u>9.4.2.3.3</u>

JUSTIFICATION/COMMENTS In addition, see Reference (2), Section 9.4. and TAB C-3.

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? Yes (Reference NA ).

JUSTIFICATION/COMMENTS See discussion, Section P-1.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program (yes/no/NA)? Yes (Reference Ref (1), App. A, Sec. 9.4.2.3.1; Ref (2), App. A, Sec. 9.4.1 ).

JUSTIFICATION/COMMENTS See TAB C-3 "Thermal Aging".



BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 10 OF 28  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EGM DATE 7/24/86 R     R      
 MODEL NP8321 SERIES            CHECKED JW DATE 7/28/86

H. AGING (Continued)

(b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes (Reference: Ref (2), Appendix B & Ref (3), Section 4 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_

(c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference Ref (3), Sections 5 & 6 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_

(d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference Ref (1), App. A, Section 9.4.2.3.1 & Ref(2), App. A, Section 9.4.1 ).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	*	*	*
Time	_____	_____	_____

JUSTIFICATION/COMMENTS \*See TABs C-1 & C-3 "Thermal Aging".  
 \_\_\_\_\_

(e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference Ref (3), Sections 5 & 6 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_

(f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? Yes (Reference Ref (2), Appendix BI & Ref (3), Section 4 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_



BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 12 OF 28  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EGM DATE 7/24/86 R     R      
 MODEL NP8321 SERIES            CHECKED FUV DATE 7/28/86

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (yes/no/NA)? Yes (Reference Ref (1), Section 4.3, App. D; Ref (2), App. D ).

Plant normal ambient radiation dose (rd)	<u>Various -See TAB C-1</u>
Test exposure dose (rd)	<u>5 x 10<sup>7</sup> - Aging</u>
	<u>1.5 x 10<sup>8</sup> - Accident</u>
Test exposure dose rate (rd/hr)	<u>5.1 x 10<sup>5</sup> for 99 hours</u>
	<u>8.0 x 10<sup>5</sup> for 188.5 hours accident</u>
Test exposure source type (e.g., Co-60 gamma)	<u>Co-60 gamma</u>

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference Ref (1), Section 4.5; Ref (2), Section 4.1.5 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (b) Was the basis for vibration aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference Ref (1), App. A, Section 8.1.6; Ref (2), App. A, Section 9.4.5 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference Ref (1), Sect. 3.2.4; Ref (2), Sect. 4.1.2 & 4.1.3 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 13 OF 28  
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE m DATE 7/24/86 R     R      
MODEL NP8321 SERIES     CHECKED FEW DATE 7/28/86

H. AGING (Continued)

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference Ref (1), App. A, Section 7.1; Ref (2), App. A, Sections 9.4.2 & 9.4.3 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (yes/no/NA)? Yes (Reference Ref (1), Section 3.2.2; Ref (2), Appendix C, p C-8 ).

Qualified life (Document in QMDS) 40 years at 140°F (Coil)  
4.4 years at 140°F (EPDM)

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (yes/no/NA)? Yes (Reference Ref (3), Section 8 ).

Replacement Intervals (Document in QMDS) See QMDS TAB G.

JUSTIFICATION/COMMENTS Replacement interval depends upon maximum normal ambient temperature and percentage time solenoid valve is energized.

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 14 OF 28  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE M DATE 7/24/86 R     R      
 MODEL NP8321 SERIES     CHECKED FW DATE 7/28/86

**I. MATERIALS ANALYSIS**

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of EQC Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>EPDM</u>	<u>1 x 10<sup>7</sup></u>	<u>See TAB E4</u>	<u>0.94</u>	<u>Ref (3) Sec. 4.1.1</u>
(b) <u>VITON</u>	<u>5 x 10<sup>6</sup></u>	<u>See TAB E4</u>	<u>1.04</u>	<u>Ref (3) Sec. 4.1.2</u>
(c) <u>NOMEX</u>	<u>7 x 10<sup>6</sup></u>	<u>See TAB E4</u>	<u>0.96</u>	<u>Ref (3) Sec. 4.1.3</u>
(d) <u>MAGNET-WIRE ENAMEL</u>	<u>1 x 10<sup>7</sup></u>	<u>See TAB E4</u>	<u>1.16</u>	<u>Ref (3) Sec. 4.2.1</u>
(e) <u>ISO-MICA W/EPOXY</u>	<u>1 x 10<sup>9</sup></u>	<u>See TAB E4</u>	<u>1.00</u>	<u>Ref (3) Sec. 4.2.6</u>
(f) <u>SILICONE RUBBER LEAD WIRE INSULATION</u>	<u>1 x 10<sup>6</sup></u>	<u>See TAB E4</u>	<u>1.59</u>	<u>Ref (3) Sec. 4.2.5</u>

JUSTIFICATION/COMMENTS The above materials are those with lowest activation energies listed in Reference (3), Section 4.1 and 4.2. Radiation threshold values are typical for these materials and are listed for information only. These values were not taken from the test report but were supplied by the Digital Engineering System 1000, Materials Data Base. (See TAB E4).

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 15 OF 28  
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EE m DATE 7/24/86 R     R      
MODEL NP8321 SERIES     CHECKED Fuv DATE 7/28/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference Ref (1), App. A, Sec. 6.1 & 6.2 ).

Identify Acceptance Criteria: Valves must operate from 90-140VDC at minimum and maximum operating pressure differential. Coil insulation resistance must be a minimum of 1.0 megohm at 500VDC. During Hypot test, current leakage must be less than 0.5 milliamp at twice the rated voltage plus 1000VAC applied for a period of one minute. Valves must operate at test or low voltage condition (90VDC) at maximum pressure differential under all conditions. Valves are not to have a pressure build-up at a vented cylinder port or a pressure decrease at a cylinder port which is required to be pressurized in excess of 10% the nominal inlet supply pressure under all postulated environmental conditions.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference Ref (1), Section 4.1 ).

Identify baseline and functional testing: Recording coil excitation, seat leakage, noise test, operational test, external leakage in energized and de-energized state before and after thermal, radiation, wear and vibration aging, and accident radiation and LOCA simulation. Measurement of insulation resistance & coil dielectric tests before thermal aging & after completion of accident radiation and LOCA simulation.

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes (Reference Ref (1), Appendix A, Section 7.0 ).
- (4) Do the applied loads during baseline testing reflect normal operating conditions (yes/no/NA)? Yes (Reference Ref (1), Section 4.8 & Ref (2), Table 4.3 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 16 OF 28  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EGM DATE 7/24/86  
 MODEL NP8321 SERIES \_\_\_\_\_ CHECKED fw DATE 7/28/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

(5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a)

<u>Parameter</u>	<u>Specified Accident Conditions</u>	<u>Reference</u>
Voltage	_____	_____
Load	_____	_____
Frequency	<u>NA</u>	<u>NA</u>
Accuracy	<u>NA</u>	<u>NA</u>
<u>Other(s)</u>	_____	_____

JUSTIFICATION/COMMENTS \_\_\_\_\_

(b)

<u>Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>
Voltage	<u>90VDC</u>	Ref (1) Table 4, p 4-24 & Table 5, p 4-25
Load	<u>20 WATTS</u>	Ref (2) Table 4.3 & NP-1 Catalog, p 5, TAB E-3
Frequency	<u>NA</u>	<u>NA</u>
Accuracy	<u>NA</u>	<u>NA</u>
<u>Other(s)</u>	_____	_____

JUSTIFICATION/COMMENTS A primary concern with solenoid valves is that of voltage available at the coil terminals. The tested valve successfully completed functional testing at the minimum 90VDC.

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 17 OF 28  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED ECM DATE 9/18/86 R     R      
 MODEL NP8321 SERIES     CHECKED lew DATE 9/18/86

**K. REQUIRED OPERATING ENVIRONMENT**

Reference Environmental Drawing No. 47E235-78 R3

(1) Normal Max	(2) Abnormal Max
(a) Temperature (°F) <u>104</u>	(a) Temperature (°F) <u>110</u>
(b) Pressure (psig) <u>ATM</u>	(b) Pressure (psig) <u>ATM</u>
(c) Humidity (%) <u>80</u>	(c) Humidity (%) <u>90</u>
(d) Radiation (rd) <u>1.8x10<sup>3</sup></u>	(d) Radiation (rd) <u>NA</u>

(3) Process Interfaces: The process fluid for valves is oil-free instrument air with a maximum design temperature of 100°F. Therefore, the bounding temperature for these valves is the ambient.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Will occur less than 1 percent of plant life and could exist for up to 8 hours per excursion.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) <u>110<sup>(1)</sup></u>	Accident type <u>LOCA</u>
(b) Pressure (psig) <u>NA</u>	Accident type <u>LOCA</u>
(c) Humidity (%) <u>NA</u>	Accident type <u>LOCA</u>
(d) Radiation (rd) <u>3.1x10<sup>6</sup> rads<sup>(2)</sup></u>	Accident type <u>LOCA</u>
(e) Spray Type <u>NA</u>	Accident type <u>LOCA</u>

- (1) Returns to maximum normal after 30 days.  
 (2) Per Calculation WBNNAL3-031 (B45 860529 237).



BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 18 OF 28  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED ETM DATE 9/18/86 R     R      
 MODEL NP8321 SERIES     CHECKED fw DATE 9/18/86

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.):

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (yes/no/NA)? No (Reference GENNAL6-002 (B45 851017 235) ).
- (7) Subject to submergence (yes/no/NA)? No (Reference WBNOSG4-44 (B45 860110 218) ).

Identify initiation time and duration of submergence: \_\_\_\_\_

\_\_\_\_\_

- (8) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
Category and Operating Times for Unit 2 Components Required for Unit 1 Operation	B45 860424 218
Status and Duty Cycles of IE Solenoid Valves Located in Potentially Harsh Environments (WBN-OSG4-045)	B45 860221 218
Solenoid Valve Voltage Study (WBPE VAR 8602002)	Later

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 19 OF 28  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EGM DATE 7/24/86 R     R      
 MODEL NP8321 SERIES     CHECKED FWV DATE 7/28/86

K. REQUIRED OPERATING ENVIRONMENT (Continued)

(8) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
Flooding in Aux. Building Due to Postulated Pipe Breaks (WBNOSG4-44)	B45 860110 218
Identification of Harsh Environmental Areas with High Potential for Condensate Formation (GENNAL6-002)	B45 851017 235
100-Day Loss of Coolant Accident Dose to Electrical Equipment in the EGTS Filter Train Room (WBNNAL3-031)	B45 860529 237

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 20 OF 28  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED CEM DATE 7/24/86 R     R      
 MODEL NP8321 SERIES     CHECKED JW DATE 7/28/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100 Days</u>	<u>30 Days</u>	Ref (1) <u>Fig 2</u>
Temperature (°F)	<u>110°F</u>	<u>346°F</u>	Ref (1) <u>Sec. 4.7</u>
Pressure (psig)	<u>ATM</u>	<u>110 psig</u>	Ref (1) <u>Sec. 4.7</u>
Relative Humidity (%)	<u>90%</u>	<u>100%</u>	Ref (1) <u>Sec. 4.7</u>
*Chemical Spray	<u>NA</u>	<u>3000ppm Boron pH 9.5-10.5</u>	Ref (1) <u>Sec. 4.7</u>
**Radiation (rd)	<u>3.1 x 10<sup>6</sup> rads gamma</u>	<u>2.01 x 10<sup>8</sup> rads</u>	Ref (1) <u>App D</u>
Submergence	<u>No</u>	<u>No</u>	

\*Includes spray concentration, flowrate, density, duration, and pH.  
 \*\*Enter 40-year integrated normal dose plus integrated accident dose and specify type.

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 21 OF 28  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED CEM DATE 7/24/86 R     R      
 MODEL NP8321 SERIES     CHECKED FW DATE 7/28/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	Test Profile Envelopes Specified	<u>Reference</u>
	<u>(Yes/No/NA)</u>	
Temperature	<u>Yes</u>	<u>See (1) above</u>
Pressure	<u>Yes</u>	<u>See (1) above</u>
Relative Humidity	<u>Yes</u>	<u>See (1) above</u>
Chemical Spray	<u>NA</u>	<u>   </u>
Submergence	<u>NA</u>	<u>   </u>
<u>JUSTIFICATION/COMMENTS</u>		

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 22 OF 28  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED SEM DATE 7/24/86 R     R      
 MODEL NP8321 SERIES     CHECKED JW DATE 7/28/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

(3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, yes/no/NA)

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	<u>&gt; 15°F</u>	<u>Yes</u>
Pressure: +10% but no more than 10 psig	<u>&gt; 10%</u>	<u>Yes</u>
Radiation: +10% of accident dose EDPM	<u>6,483%</u>	<u>Yes</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>None</u>	<u>Yes*</u>
Voltage: ± 10% of rated value	<u>No **</u>	<u>No**</u>
Frequency: ± 5% of rated value	<u>N/A</u>	<u>N/A</u>
Environmental Transient: the initial transient and the peak temperature applied twice	<u>Yes</u>	<u>Yes</u>
Vibration: +10% added to acceleration (during seismic testing)	<u>Ref (1), Section 9.4.2.4.2 Ref (2), Sec. 4.1.6</u>	<u>Yes</u>

JUSTIFICATION/COMMENTS: \*Accident degradation calculation (See TAB

C) proves that the 30-day test envelops the 100-day post-accident requirement. See Generic Binder WBNEQ-GEN-001, Section III.C.4.

\*\*The valve was tested at a minimum 90VDC during operability testing, which is better proof of operability than increased coil voltage.

During all other tests, either the nominal voltage of 125VDC or the test current of .080 amps was used.





BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 25 OF 28  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EEY DATE 7/24/86 R     R      
 MODEL NP8321 SERIES     CHECKED FWV DATE 7/28/86

0. SUMMARY OF REVIEW

- |   | <u>Yes/No/NA</u> |
|---|------------------|
| (1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)? | <u>Yes</u>       |
| (2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?   | <u>NA</u>        |
| (3) Choice of qualification methodology adequately justified?   | <u>Yes</u>       |
| (4) If analysis was performed, complete the following:  |                  |
| (a) Were equipment performance requirements identified?   | <u>NA</u>        |
| (b) Were specific features and failure modes and effects analyzed?  | <u>NA</u>        |
| (c) Were assumptions and mathematical models used together with appropriate justification for their use?  | <u>NA</u>        |
| (d) Were environmental parameters which affect equipment performance identified?  | <u>NA</u>        |
| (5) Adequate similarity between equipment and test specimen established?  | <u>Yes</u>       |
| (6) Aging degradation evaluated adequately?   | <u>Yes</u>       |
| (a) Mechanical and/or cycle aging addressed?  | <u>Yes</u>       |
| (b) Equipment aged to end of life condition prior to application of DBE conditions?   | <u>Yes</u>       |
| (c) Absence of preaging in test/analysis justified?   | <u>NA</u>        |
| (d) Materials susceptible to thermal/radiation aging identified?  | <u>Yes</u>       |



BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 26 OF 28  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED ESM DATE 7/27/86 R     R      
 MODEL NP8321 SERIES     CHECKED FW DATE 7/28/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>Yes</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>Yes</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>Yes</u>
(11) Criteria regarding submergence satisfied?	<u>Yes</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>NA</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 27 OF 28  
 BINDER TITLE ASCO SOLENOID VALVES COMPUTED EGM DATE 7/24/86 R     R      
 MODEL NP8321 SERIES     CHECKED JW DATE 7/28/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(15) Criteria regarding functional testing satisfied?	<u>Yes</u>
(a) Does the test plan/report specify an acceptance criteria for equipment performed?	<u>Yes</u>
(b) Was an initial base line test done to establish required performance characteristics?	<u>Yes</u>
(c) Has the test/analysis demonstrated that performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured?	<u>Yes</u>
(16) Criteria regarding instrument accuracy satisfied?	<u>NA</u>
(17) Test duration margin (1 hour + function time) satisfied?	<u>Yes</u>
(a) Is the minimum specified operating time at least 1 hour?	<u>Yes</u>
(b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided?	<u>NA</u>
(18) Criteria regarding synergistic effects satisfied?	<u>NA</u>
(19) Criteria regarding margins satisfied?	<u>Yes</u>
(20) Maintenance and surveillance requirements adequately identified?	<u>Yes</u>

BINDER NO. WBNEQ-SOL-007 PLANT WBN UNIT(S) 1 SHEET 28 OF 28  
BINDER TITLE ASCO SOLENOID VALVES COMPUTED EGM DATE 7/24/86 R     R      
MODEL NP8321 SERIES     CHECKED JW DATE 7/28/86

P. DISCUSSION

1. Synergistic Effects (Sec. H(3))

Ethylene Propylene Terpolymer (EPDM) elastomer is used in the construction of ASCO solenoid valves as gaskets and diaphragms. EPDM is the only material having a potential for radiation induced synergisms based on a review of technical information provided in NUREG/CR-2157 and NUREG/CR-2553. Data in NUREG/CR-2157 suggests that dose rate effects in EPR materials are insignificant up to doses of 10 to 20 MRADs. A review of the location and environments of ASCO solenoid valves listed in TAB C-1 indicates that the maximum normal radiation dose will be seen by valves in subgroup A-2. These valves are qualified for 40 years without replacement of elastomer parts and will therefore be exposed to a maximum normal dose of .001 MRADs. Since all elastomer parts are totally enclosed in metal, the radiation dose to these parts will be less than .001 MRADs. Synergistic effects will be negligible for normal service aging.

Potential dose rate and test sequence synergisms will not impact qualification for accident conditions as demonstrated by Test Report AOS-21678. The test sequence of thermal aging followed by radiation aging plus accident radiation at high (0.8 MRAD/HR) dose rate is a reasonable simulation of actual plant requirements. Additional assurance is provided by the severity of the radiation test because the test valve was exposed to 201 MRADs whereas an actual dose of about 3.1 MRADs (3.1 MRADs accident plus .001 MRADs normal service) is required.

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. N09E0-ROV-001  
 MANUFACTURER: LIMITORQUE  
 PAGE: 1 OF 5

EDIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						
MBN-1-HVDP-062-0061	-B 1-FCV -062-0061	-B SEAL FLOW RETURN ISOLATION VALVE	SB-00		282	713'	L	71C62-54114-1	L RH/C CV/C FW/C HS/C	A/B A/B A/B A/B A/B	5MIN/1000 15MIN/1MO 1HR/1MO 5MIN/1000 5MIN/1000	REQUIRED TO CLOSE AND REMAINED CLOSED AFTER PHASE A ISOLATION SIGNAL IS RECEIVED AND RESET
MBN-1-HVDP-063-0072	-A 1-FCV -063-0072	-A CNTMT SUMP TO RHR PUMP A-A	SB-3	VA4		685'	SVR	71C62-54114-1	L RH/A CV/A AB AF	A B B B B	100B 1MO 1MO 1MO 1MO	L: NORM CLOSED VLV MUST OPEN TO ALIGN SUCTION OF RHR PUMP TO SUMP FOR RECIRC MODE OF "SI" AND MUST REMAIN OPEN DURING RECIRC MODE. MAY NEED TO BE CLOSED TO MITIGATE SINGLE PASSIVE FAILURE.
MBN-1-HVDP-063-0073	-B 1-FCV -063-0073	-B CNTMT SUMP TO RHR PUMP B-B	SB-3	VA4		685'	SVR	71C62-54114-1	L RH/A CV/A AB AF	A B B B B	100B 1MO 1MO 1MO 1MO	L: NORM CLOSED VLV MUST OPEN TO ALIGN SUCTION OF RHR PUMP TO SUMP FOR RECIRC MODE OF "SI" AND MUST REMAIN OPEN DURING RECIRC MODE. MAY NEED TO BE CLOSED TO MITIGATE SINGLE PASSIVE FAILURE.
MBN-1-HVDP-063-0172	-B 1-FCV -063-0172	-B RHR TO RCS HOTLEG 1 & 3 FLOW ISLN VLV	SB-2	MA5		713'	A2B	71C62-54114-1	L RH/A CV/A AB AF/A	A/B C C C C	1HX /1000 NA NA NA NA	NEEDED TO TRANSFER FROM COLD LEG RECIRC TO HOT LEG RECIRC
MBN-1-HVDP-067-0087	-A 1-FCV -067-0087	-A LOWER CNTMT A COOLER DISCH ISOL VLV IC	SMB-000		008	716'	L	78K24-823298	L RH/C CV/C FW/C HS/C	A/B A/B A/B A/B A/B	5MIN/1000 15MIN/1MO 1HR/1MO 5MIN/1000 5MIN/1000	ISOL FLOW TO VERT COOLER UPON RECEIPT OF PHASE "A" CONTAINMENT ISOLATION SIGNAL

PAGE A-1

\* ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS FOUND IN TAB F.

R \_\_\_\_\_ R \_\_\_\_\_ R \_\_\_\_\_

PREPARER/DATE DT Cox 5/21/86  
 CHECKER/DATE WB Hoon 5/21/86

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WBNED-HDV -001  
 MANUFACTURER: LINITORQUE  
 PAGE: 2 OF 5

PAGE A-2

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						
WBN-1-HVOP-067-0095	-A 1-FCV -067-0095	-A LOWER CNTMT C COOLER DISCH ISOL VLV IC	SMB-000		190	716'	L	78K24-823298	L RH/C CV/C FW/C MS/C	A/B A/B A/B A/B A/B	5MIN/1000 15MIN/1MD 1HR/1MD 5MIN/1000 5MIN/1000	ISOL FLOW TO VENT COOLER UPON RECEIPT OF PHASE 'B' CONTAINMENT ISOLATION SIGNAL
WBN-1-HVOP-067-0103	-B 1-FCV -067-0103	-B LOWER CNTMT B COOLER DISCH ISOL VLV IC	SMB-000		173	716'	L	78K24-823298	L RH/C CV/C FW/C MS/C	A/B A/B A/B A/B A/B	5MIN/1000 15MIN/1MD 1HR/1MD 5MIN/1000 5MIN/1000	ISOL FLOW TO VENT COOLER UPON RECEIPT OF PHASE 'B' CONTAINMENT ISOLATION SIGNAL
WBN-1-HVOP-067-0111	-B 1-FCV -067-0111	-B LOWER CNTMT D COOLER DISCH ISOL VLV IC	SMB-000		355	716'	L	78K24-823298	L RH/C CV/C FW/C MS/C	A/B A/B A/B A/B A/B	5MIN/1000 15MIN/1MD 1HR/1MD 5MIN/1000 5MIN/1000	VALVE MUST CLOSE ON A CONTAINMENT ISOL SIGNAL AND REMAIN CLOSED
WBN-1-HVOP-067-0295	-A 1-FCV -067-0295	-A UPPER CNTMT VENT CLR A ISOL VLV INSIDE CN	SMB-000		030	802'	U/C	79KA2-824589-1	L RH/C CV/C FW/C MS/C	A/B A/B A/B A/B A/B	5MIN/1000 15MIN/1MD 1HR/1MD 5MIN/1000 5MIN/1000	VLV MUST CLOSE ON A CONTAINMENT ISOL SIGNAL AND REMAIN CLOSED
WBN-1-HVOP-067-0296	-A 1-FCV -067-0296	-A UPPER CNTMT VENT CLR C ISOL VLV INSIDE CN	SMB-000	202	193	802'	U/C	79KA2-824589-1	L RH/C CV/C FW/C MS/C	A/B A/B A/B A/B A/B	5MIN/1000 15MIN/1MD 1HR/1MD 5MIN/1000 5MIN/1000	VLV MUST CLOSE ON A CONTAINMENT ISOL SIGNAL AND REMAIN CLOSED

\* ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS FOUND IN TAB F.

PREPARER/DATE DJ Copp 5/21/86  
 CHECKER/DATE WJH 5/21/86

FAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WBR02-ROY -001  
 MANUFACTURER: LINTORQUE  
 PAGE: 3 OF 5

PAGE A-3

EQUIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						
WBN-1-HVDP-067-0297	-B I-FCV -067-0297	-B UPPER CNTHT VENT CLR B ISOL VLV INSIDE CN	SMB-000		148	802'	U/C	79KA2-824589-1	L RH/C CV/C FW/C RS/C	A/B A/B A/B A/B A/B	5MIN/1000 15MIN/1MO 1HR/1MO 5MIN/1000 5MIN/1000	VLV MUST CLOSE ON A CONTACT MOMENT ISOL SIGNAL AND REMAIN CLOSED
WBN-1-HVDP-067-0298	-B I-FCV -067-0298	-B UPPER CNTHT VENT CLR D ISOL VLV INSIDE CN	SMB-000	✓338	334	802'	U/C	79KA2-824589-1	L RH/C CV/C FW/C RS/C	A/B A/B A/B A/B A/B	5MIN/1000 15MIN/1MO 1HR/1MO 5MIN/1000 5MIN/1000	VLV MUST CLOSE ON A CONTACT MOMENT ISOL SIGNAL AND REMAIN CLOSED
WBN-1-HVDP-068-0332	-B I-FCV -068-0332	-B RCS PRZR REL FLOW CONT	SB-00	✓104°	101	783'	U	71C62-54114-1	L RH/C CV/C FW/C RS/C	A A A A A	1000 1MO 1MO 1000 1000	VLVS MUST BE CAPABLE OF FUNCTIONING AT ANY TIME FOR ACCIDENT MITIGATION
WBN-1-HVDP-068-0333	-A I-FCV -068-0333	-A RCS PRZR REL FLOW CONT	SB-00	✓104°	102	783'	U	71C62-54114-1	L RH/C CV/C FW/C RS/C	A A A A A	1000 1MO 1MO 1000 1000	VLVS MUST BE CAPABLE OF FUNCTIONING AT ANY TIME FOR ACCIDENT MITIGATION
WBN-1-HVDP-070-0087	-B I-FCV -070-0087	-B RC PHP THERM BAR RET CNTHT ISOL VLV	SMB-00		306	716'	L	78K24-823290	L RH/C CV/C FW/C RS/C	A/B A/B A/B A/B A/B	5MIN/1000 15MIN/1MO 1HR/1MO 5MIN/1000 5MIN/1000	CLOSE ON PHASE 'B' ISOL SIGNAL AND STAY CLOSED AFTER RESET OF SIGNAL TO MAINTAIN CNTHT ISOLATION

\* ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS FOUND IN TAB F.

PREPARER/DATE DA Coy 5/12/06 R \_\_\_\_\_ R \_\_\_\_\_ R \_\_\_\_\_

CHECKER/DATE W. H. ... 5/22/06 \_\_\_\_\_

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. BBNED-MDV-001  
 MANUFACTURER: LINTORQUE  
 PAGE: 4 OF 5

PAGE A-4

EDIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV°						RM/RAD
MBN-1-HVOP-070-0089	-B 1-FCV -070-0089	-B RC PHP OIL CLR RET CNTMT ISOL VLV	SNB-000		286	716'	L	78K24-823298	L	A/B	5MIN/1000	CLOSE ON PHASE 'B' ISOL SIGNAL AND STAY CLOSED AFTER RESET OF SIGNAL TO MAINTAIN CNTMT ISOLATION
MBN-1-HVOP-074-0001	-A 1-FCV -074-0001	-A RHR SYSTEM ISOL VLV	SB-2		348	703'	L	71C62-54114-1	L	C	NA	VLV MUST CLOSE IF OPEN AND REMAIN CLOSED TO MITIGATE RHR BREAK
MBN-1-HVOP-074-0002	-B 1-FCV -074-0002	-B RHR SYSTEM ISOL VLV	SB-2		302	716'	L	71C62-54114-1	L	C	NA	VLV MUST CLOSE IF OPEN AND REMAIN CLOSED TO MITIGATE RHR BREAK
MBN-1-HVOP-074-0003	-A 1-FCV -074-0003	-A RHR PUMP A-A INLET FLOW CNTRL VLV	SB-2	VA6		676'	A11	71C62-54114-1	L	A/B	1WK/1000	VLV MUST CLOSE DURING SWITCH-OVER FROM THE RWST TO THE CNTMT SUPP
MBN-1-HVOP-074-0008	-A 1-FCV -074-0008	-A RHR SYSTEM ISOLATION BYPASS VALVE	SB-1		305	716'	L	71C62-54114-1	L	C	NA	IF OPEN, VLV MUST CLOSE AND REMAIN CLOSED FOR ACCIDENT MITIGATION

\* ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS FOUND IN TAB F.

R \_\_\_\_\_ R \_\_\_\_\_ R \_\_\_\_\_

PREPARER/DATE *D.J. Coy 5/24/86*  
 CHECKER/DATE *W.B. Horn 7/2/86*

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. MBWED-MOV-001  
 MANUFACTURER: LINITORQUE  
 PAGE: 5 OF 5

EBIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						
MBN-1-MVDP-074-0009	-B 1-FCV -074-0009	-B RHR SYSTEM ISOL BYPASS VLV	SB-1		346	703'	L	71C62-54114-1	L	C	NA	IF OPEN, VLV MUST CLOSE AND REMAIN CLOSED FOR ACCIDENT MITIGATION
									RH/C	A/B	15MIN/1MO	
									CV/C	C	NA	
									FW/C	C	NA	
									MS/C	C	NA	
MBN-1-MVDP-074-0021	-B 1-FCV -074-0021	-B RHR PUMP B-B INLET FLOW CONTROL VALVE	SB-2	VA6	676'	A10	71C62-54114	L	A/B	1HK/100D	VLV MUST CLOSE DURING SWITCH-OVER FROM THE RWST TO THE CONTAINMENT SUMP	
								RH/A	C	NA		
								CV/A	C	NA		
								AB	C	NA		
								AF	C	NA		

PAGE A-5

CATEGORIES AND OPERATING TIMES WERE TAKEN FROM THE FOLLOWING DOCUMENTS:  
 SYSTEM 62 - MBN0564-013 REV 7 845860320223    SYSTEM 63 - MBN0564-014 REV 9 845860314219  
 SYSTEM 67 - MBN0564-016 REV 8 845860320218    SYSTEM 68 - MBN0564-017 REV 7 845860326219  
 SYSTEM 70 - MBN0564-018 REV 8 845860307219    SYSTEM 72 - MBN0564-019 REV 3 845860121225  
 SYSTEM 74 - MBN0564-020 REV 6 845860307218

\* ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS FOUND IN TAB F.

PREPARER/DATE D.J. Coy 5/21/86 \_\_\_\_\_  
 CHECKER/DATE W. H. ... 5/21/86 \_\_\_\_\_



BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 1 OF 33  
BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED DA Coy DATE 5/21/86 R     R      
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED WB DATE 5/21/86

A. DOCUMENTATION

Equipment Description Motorized Valve Actuator with Type RH insulation.

Vendor/Manufacturer Limitorque

Equipment Model No.(s) See EOC TAB A

QUALIFICATION REPORTS (See Section P(5))

- (1) Title/Number/Revision Limitorque Valve Actuator RIMS NEB820421203  
Qualification for Nuclear Service #B0058 and  
Appendix A DATE 1-11-80
- (2) Title/Number/Revision Limitorque Valve RIMS NEB820421203  
Actuators for PWR Service #600456 DATE 12-9-75
- (3) Title/Number/Revision Limitorque Valve Actuator RIMS NEB820421203  
Rev. A  
Temp. Related to High Superheat Ambient #B0027 DATE 10-18-78

OTHER (ANALYSIS, VENDOR DATA, ETC.)

(4) Limitorque Valve Actuators with Type LR Motor for Westinghouse  
PWR Report B0212 Dated 4/10/85.

(5) Supplement Report to NUC-9 Rev. 1, 4-14-80, Reliance Electric  
Company Summary Report - Nuclear Power Plant Motor Systems Type Test  
Support Analysis - Random Wound Motors.

(6) Qualification Type Test Report of Multi-Point Terminal Strips,  
for Use in Limitorque. Valve Actuators for PWR Service Dated  
July 1, 1982. Report B0119.

(7) Limitorque telex dated March 21, 1986.

(8) WAC-49

(9) Limitorque letter dated September 25, 1985 (B70 850925 012).

(10) Limitorque letter dated September 5, 1985 (B70 850910 004).

(11) Limitorque telex dated November 6, 1985 (B70 851107 021).

(12) TVA telex dated November 6, 1985 (B70 851107 022).

(13) WAC-67

PAGE B-1

B. CONCLUSION OF REVIEW (Check only one block)

- Equipment Qualified
- Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule
- Equipment Qualification Not Established by Documentation
- Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES \_\_\_\_\_

1. Deficient internal cable is to be replaced per ECN 6025.

Complete field verification must be resubmitted to the DNE binder preparer upon resolution of this open item.

2. Nylon crimp connectors on the field winding leads must be

replaced with acceptable nuclear grade connectors. Complete revised field verification must be resubmitted to the DNE binder preparer upon resolution of this open item.

3. Heaters in the motor and limit switch compartments must be

decommissioned prior to unit start-up. Complete revised field verification must be resubmitted to the DNE binder preparer upon resolution of this open item.

4. Black durez limit switch rotors must be replaced with qualified

subcomponents. Complete revised field verification must be resubmitted to the DNE binder preparer upon resolution of this open item.

COMMENTS/RECOMMENDATIONS \_\_\_\_\_

\_\_\_\_\_

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 3 OF 33  
BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED DA Cop DATE 5/21/86 R     R      
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED W.B. Jones DATE 5/21/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

  X   Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)

       Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of IE Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS \_\_\_\_\_

The Limitorque Environmental Qualification Program was conducted per IEEE-382 (1972), "IEEE Guide for Type Test of Class 1E Electric Valve Operators for Nuclear Power Generating Stations" and meets the requirements of IEEE-323 (1974) as they apply to valve actuators (TR B0058, Section 2.1).

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE 382-1972

BINDER NO. WBNEQ-MOV -001 PLANT WBH UNIT(S) 1 SHEET 4 OF 33  
 BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED D.J. Coy DATE 5/21/86 R     R      
 OPERATORS WITH TYPE EH INSULATED MOTOR CHECKED W.B. Khan DATE 5/21/86

D. QUALIFICATION METHODOLOGY (Check only one block)

- Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- Test of Similar Items with Supporting Analysis
- Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS The Limitorque Qualification Program was  
conducted to encompass the entire family of actuators - SMB, SB,  
SBD, and SMB/HBC in all available unit sizes (SMB-000 to SMB-5).  
This was accomplished by type testing. See EOC TAB C, Section 1.0,  
EOC TAB E Attachment 1 identifies the actuator plant ID number, the  
Limitorque shop order number, the actuator serial number, and the  
documentation reference which establishes traceability to the appli-  
cable test report.

BINDER NO. WBNEQ-MOV -001 PLANT WBH UNIT(S) 1 SHEET 5 OF 33  
 BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED DATE 5/21/86 R    R     
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED W. J. [Signature] DATE 5/21/86

**E. EQUIPMENT DESCRIPTION**

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? No

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Motor Operated Valve Actuator</u>	<u>Motor Operated Valve Actuator</u>	<u>600456, Sect. 2.0</u>
(2) Manufacturer	<u>Limitorque</u>	<u>Limitorque</u>	<u>600456, Sect. 2.0</u>
(3) Model Number(s)	<u>See EQC TAB A</u>	<u>SMB-0</u>	<u>Sect. 2.0</u>
(4) Serial Number(s)	<u>See EQC TAB E Attachment 1</u>	<u>Actuator 189835</u> <u>Motor 2Y267074A1EZ</u>	<u>600456, Sect. 2.0</u> <u>600456, Sect. 2.0</u>
Order No.	<u>See EQC TAB E Attachment 1</u>	<u>Actuator 600456-A</u>	<u>600456, Sect. 2.0</u>
(5) Identify Component-Unique checksheet attached:	<u>None</u>		

JUSTIFICATION/COMMENTS The Limitorque qualification program was conducted to encompass the entire family of actuators - SMB, SB, SBD, and SMB/HBC in all available unit sizes (SMB-000 to SMB-5, Reference #B0058, Section 2.1). This was accomplished by conducting the testing on a mid-size unit SMB-0 with a Reliance motor, 60 HZ, 460 VAC, insulation Class RH, type-P motor, size 40 ft.-lb. stall, 8 ft.-lb. run (Reference #600456, Section 2.0). See EQC TAB C, Section 1.

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 6 OF 33

BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED Df Cap DATE 5/21/86 R     R    

OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED M. H. H. DATE 5/21/86

**F. INSTALLATION INTERFACES**

List all interfaces pertinent to EQ identified in the test report and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if No, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>NA</u>	<u>NA</u>	<u>NA</u>
External Process Connections	<u>NA</u>	<u>NA</u>	<u>NA</u>
Electrical Connections	<u>See Comments</u>	<u>Yes</u>	<u>600456, Sect. 3.4.1</u>
Conduit Seals	<u>None</u>	<u>NA</u>	<u>NA</u>
Connector Seals	<u>None</u>	<u>NA</u>	<u>NA</u>
Orientation	<u>NA</u>	<u>NA</u>	<u>NA</u>
Physical Configuration	<u>NA</u>	<u>NA</u>	<u>NA</u>
Other	<u>NA</u>	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS Control and power lead connections were made through flexible pressure tight conduit connections run between the unit tested and the access ports of the test chamber (ref. #600456, Sect. 3.4.1); however, conduit seals and special connections are not required. See EOC TAB C Section 2 and F(4) of this TAB for justification. There are no specific "installation interfaces" for this equipment specified throughout the qualification program.

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 7 OF 33  
 BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED D. J. Coy DATE 5/2/86 R     R      
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED W. J. Brown DATE 5/2/86

**G. TEST SEQUENCE**

(1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>No</u>	<u>See Comment 600456, Tabl II&amp;III, &amp; App. B</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>App. B</u>
(c) Equipment aged:		
Thermal	<u>Yes</u>	<u>600456, Sect. 3.1.1</u>
Radiation	<u>Yes</u>	<u>600456, Sect. 3.1.3 &amp; 3.3</u>
Wear	<u>Yes</u>	<u>600456, Sect. 3.1.2</u>
(d) Vibration/seismic testing conducted	<u>Yes</u> <u>Seismic</u>	<u>B0058, Sect. 2.1; 600456, Sect. 3.2</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	<u>600456, Sect. 4.4.1, 4.4.5, Tabl III Fig 6</u>
(f) Post-DBE exposure	<u>Yes</u>	<u>600456, Sect. 4.4.1, 4.4.5, Tabl III Fig 6</u>
(g) Final inspection and disassembly	<u>Yes</u>	<u>600456, Sect. 3.7, 4.5, &amp; 4.7</u>

(2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes, 600456 Sect. 4.7.1; see TAB C, Section 4 for details.

(3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes  
 (Reference #600456, App. F, Tabl I).

JUSTIFICATION/COMMENTS Low level vibration is addressed in the EOC TAB C, Section 3. See EOC TAB C, Section 5.0 for discussion of test sequence with respect to radiation exposure. Preinspection is not a requirement of IEEE 323-1974; however, the equipment was manufactured per Limitorque standard nuclear B/M and no damage or deficiencies were noted per 600456, Section 2.

H. AGING

(1) Was aging considered in the qualification program (Yes/no/NA)? Yes (Reference B0058, Section 3.0 and 600456, Section 3.1).

JUSTIFICATION/COMMENTS None

(2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>B0058, Sect. 3.2</u> <u>600456, Sect. 3.1.1</u> <u>600456, Sect. 3.1.3</u>
Radiation exposure	<u>Yes</u>	<u>B0058, Sect. 3.4</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>B0058,</u> <u>Sect. 2.1</u> <u>600456, Sect. 3.1.2</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	<u>B0058, Sect. 3.3</u>

JUSTIFICATION/COMMENTS None

(3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? NA (Reference NA ).

JUSTIFICATION/COMMENTS No known synergistic effects.

(4) Thermal Aging:

(a) Was thermal aging considered in the qualification program (yes/no/NA)? Yes (Reference 600456, Sect. 3.1.1; B0058, Sect. 3.2).

JUSTIFICATION/COMMENTS Thermal aging was conducted on  
Reliance motor stator. See EOC TAB C, Section 4.0 for full  
details.



BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 9 OF 33  
 BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED DJ Cap DATE 5/21/86  
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED WJH DATE 5/21/86

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes (Reference: B0058, Sect. 3.2 ).

JUSTIFICATION/COMMENTS All organic materials subject to thermal aging degradation.

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference B0058, Sect. 3.2 ).

JUSTIFICATION/COMMENTS See EOC TAB C, Section 4.0 for full details.

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference 600456, Sect. 3.1.1; B0058, Sect. 3.2 ).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	<u>120°F</u>	<u>180°C</u>	<u>130°F</u>
Time	<u>40 Years</u>	<u>100 Hr</u>	<u>40 Yrs</u>

JUSTIFICATION/COMMENTS Motor stator thermal aging conducted; analysis conducted on other organic materials. See EOC TAB C, Section 4.0.

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference B0058, Sect. 3.2 ).

JUSTIFICATION/COMMENTS Thermal regression curve used for motor stator; analysis used for other materials. See EOC TAB C, Section 4.0.

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? NA (Reference NA ).

JUSTIFICATION/COMMENTS See EOC TAB C, Section 4.0.

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? Yes (Reference B0058, Sect. 3.2.1.2 ).

JUSTIFICATION/COMMENTS Thermal regression curve used for motor stator. See EOC TAB C, Section 4.0.

- (h) Was the equipment operated during the thermal aging (yes/no/NA)? No (Reference NA ).

JUSTIFICATION/COMMENTS Operation of equipment during thermal aging is not required.

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (yes/no/NA)? Yes (Reference 600456, Sect. 3.1.3 ).  
B0058, Sect. 3.4

JUSTIFICATION/COMMENTS None

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (yes/no/NA)? Yes (Reference B0058, Sect. 3.2 ).

JUSTIFICATION/COMMENTS A specific listing of materials subject to radiation degradation was not provided; however, organic materials, as stated in Section 3.2 of B0058, would be subject to radiation degradation. During the radiation exposure for the test, the whole actuator was radiation aged.

- (c) Was the basis for radiation aging exposure identified in the qualification program (yes/no/NA)? Yes (Reference 600456, Sect. 3.1.3 & 3.3, and B0058, Sect. 3.4 ).

JUSTIFICATION/COMMENTS Aging dose was combined with the accident dose. 4 Mrd was applied for normal dose; 200 Mrd was applied for accident dose.

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 11 OF 33

BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED DJ Cap DATE 5/1/86 R     R    

OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED WJH/KW DATE 5/21/86

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (yes/no/NA)? Yes (Reference 600456, Sect. 3.1.3, 3.3, and Appendix C).

Plant normal ambient radiation dose (rd) 20E06

Test exposure dose (rd) 204E06

Test exposure dose rate (rd/hr) 1.0E06

Test exposure source type (e.g., Co-60 gamma) Co-60 gamma

JUSTIFICATION/COMMENTS Test dose included normal aging plus accident dose.

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference B0058, Sect. 2.1 ).

JUSTIFICATION/COMMENTS Non-seismic vibration is not addressed in the Limitorque test program. See EOC TAB C, Section 3.0.

- (b) Was the basis for vibration aging identified and justified in the qualification program (yes/no/NA)? No (Reference B0058, Sect. 2.1 ).

JUSTIFICATION/COMMENTS See EOC TAB C, Section 3.0 for justification of omission of non-seismic vibration aging.

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference 600456, Sect. 3.1.2 & App. B ).

JUSTIFICATION/COMMENTS The actuator was cycled (mechanical aging) 1208 times; seating thrust was monitored.

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 12 OF 33  
BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED DT Cox DATE 5/2/86 R     R      
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED W.B. King DATE 5/2/86

H. AGING (Continued)

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference 600456, Sect. 3.1.2 & App. B).

JUSTIFICATION/COMMENTS The actuator was cycled (mechanical aging) 1208 times; seating thrust was monitored.

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (yes/no/NA)? Yes (Reference B0058, Sect. 3.2).

Qualified life (Document in QMDS) 40 Years

JUSTIFICATION/COMMENTS See EQC TAB C, Section 4.0 for full details on qualified life and aging.

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (yes/no/NA)? Yes (Reference B0058, Sect. 5.0 and 7.0).

Replacement Intervals (Document in QMDS) None required to maintain qualification. Seals and gaskets are to be replaced during routine maintenance when wear or damage is observed as a good engineering practice and per TAB G.

JUSTIFICATION/COMMENTS None

PAGE B-12

BINDER NO. WBNEQ-MOV -001 PLANT WBR UNIT(S) 1 SHEET 13 OF 33  
 BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED DJ Cop DATE 5/21/86 R     R      
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED WJ/K DATE 5/21/86

**I. MATERIALS ANALYSIS**

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of EQC Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>Melamine (white)</u>	<u>2.04x10<sup>8</sup></u> <u>Rads</u>	<u>600456</u> <u>Sect. 3.1.3</u>	<u>1.35</u>	<u>See</u> <u>Comments</u>
(b) <u>Fiberite (brown)</u>	<u>2.09x10<sup>8</sup></u> <u>Rads</u>	<u>B0212</u> <u>Sect. 6.7</u>	<u>1.78</u>	<u>See</u> <u>Comments</u>
(c) <u>G.P. Phenolic (black)</u>	<u>2.09x10<sup>8</sup></u> <u>Rads</u>	<u>B0212</u> <u>Sect. 6.7</u>	<u>1.63</u>	<u>See</u> <u>Comments</u>
(d) <u>Motor Insulation-RH</u>	<u>2.04x10<sup>8</sup></u> <u>Rads</u>	<u>600456</u> <u>Sect. 3.1.3</u>	<u>1.02</u>	<u>See</u> <u>Comments</u>
(e) <u>Wiring Insulation</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>	<u>TAB C</u> <u>Sect. 4.4</u>

JUSTIFICATION/COMMENTS Radiation threshold does not apply. Limitorque  
has done radiation exposure per the referenced Limitorque test reports.  
The values listed in threshold column represent the testing parameters.  
Activation energies are documented in TABS "D" and "E" as follows:

(a) Melamine - Output display from aging data calculation (WAC-49)

(TAB "E").

(b) Fiberite - Limitorque test report B0212, Sect. 6.2 (TAB "D").

(c) G. P. Phenolic - Limitorque letter dated 9/5/85 (B70 850910 004)

(TAB "E").

(d) Motor Insulation - RH (WAC-49) (TAB "E").

See TAB C, Section 4.1 for material analysis of phenolics and Section 4.2  
for analysis of motor insulation.

BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED AT Cap DATE 5/2/86 R     R    

OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED WJH DATE 5/2/86

**J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS**

(1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference B0058, Sect. 4.1.8 ).

Identify Acceptance Criteria: The actuator must be capable of opening or closing a valve on demand.

(2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference Report 600456, Sect. 4.6), and Appendix B

Identify baseline and functional testing: Motor potential, run current, power, stroke time, peak current, and seating thrust were measured prior to the start of the test and are summarized in Table III of Report 600456. Insulation resistance to ground is tabulated in Table II. See TAB C, Section 9 for summary.

(3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes (Reference See Comment ).

JUSTIFICATION/COMMENTS Load cycling during the test is tabulated in Table III of the test report.

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 15 OF 33  
BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED DA Cep DATE 5/21/86 R     R      
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED WJH/KAS DATE 7/21/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (yes/no/NA)? Yes (Reference Sect. 3.1.2, Report 600456).

JUSTIFICATION/COMMENTS Thrust measurements correspond to the thrust rating for the actuator. In addition, Appendix B of the test report shows baseline, mechanical aging, and post-test thrust measurements.

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

(a) Parameter	Specific Accident Conditions	Reference
Voltage	<u>See TAB C, Section 6</u>	<u>NA</u>
Load	<u>See comment</u>	<u>NA</u>
Frequency	<u>60 Hz</u>	<u>See comments below</u>
Accuracy	<u>NA</u>	<u>   </u>
Other(s)	<u>   </u>	<u>   </u>
<u>NA</u>	<u>   </u>	<u>   </u>
<u>NA</u>	<u>   </u>	<u>   </u>

JUSTIFICATION/COMMENTS Load required will be thrust necessary to stroke the valve. Frequency variations would only occur during the loading of the diesel generators. Since Unit 2 is not operational, the diesels cannot be overloaded to the point of causing frequency variations. This is based on maximum loading occurring during a LOCA on Unit 1 with a full load rejection on Unit 2.

(b) Parameter	Demonstrated Conditions	Reference
Voltage	<u>475VAC</u>	<u>600456 Table III</u>
Load	<u>Approx. 20,000 lbs thrust</u>	<u>600456 Table III</u>
Frequency	<u>See Comment</u>	<u>   </u>
Accuracy	<u>NA</u>	<u>   </u>
Other(s)	<u>   </u>	<u>   </u>

JUSTIFICATION/COMMENTS Justification for lack of reduced voltages starting tests under accident conditions is presented in EQC TAB C, Section 6.0. Although not specifically stated, we have no reason to believe that Limitorque used anything other than a 60 Hz power source.

PAGE B-16



BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 17 OF 33  
 BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED DJ Cop DATE 5/21/86 R     R      
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED WCH DATE 5/21/86

**K. REQUIRED OPERATING ENVIRONMENT**

Reference Environmental Drawing No. See pp. 17A-E

(1) Normal Max

- (a) Temperature (°F) See Above
- (b) Pressure (psig) See Above
- (c) Humidity (%) See Above
- (d) Radiation (rd) See Above

(2) Abnormal Max

- (a) Temperature (°F) See Above
- (b) Pressure (psig) See Above
- (c) Humidity (%) See Above
- (d) Radiation (rd) See Above

(3) Process Interfaces: Valve body and stem connection configuration

eliminates significant additional heating of the degradable actuator parts due to elevated temperatures in process fluids.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal temperatures could occur as a result of outside

temperature excursions, temporarily greater than design heat loads, or degraded environment control system. This could exist for up to 8 hours per excursion and will occur less than 1% of the plant life.

See TAB C, Section 4.0.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F)	<u>327</u>	MSLB-See Accident type <u>EQC TAB A</u>
(b) Pressure (psig)	<u>12</u>	LOCA-See EQC Accident type <u>TAB A</u>
(c) Humidity (%)	<u>100</u>	LOCA-See EQC Accident type <u>TAB A</u>
(d) Radiation (rd)	<u>4 x 10<sup>7</sup>*</u> 8.35pH, 0.18M H <sub>3</sub> BO <sub>3</sub> 2000PPM boron <sub>3</sub> 0.033M NaOH	LOCA-See EQC Accident type <u>TAB A</u>
(e) Spray Type	<u>Duration 30d</u>	LOCA-See EQC Accident type <u>TAB A</u>

\*Construction of Limitorque actuators (i.e., totally steel encased) is such that Beta Radiation is not a consideration.

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-41 RI

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) 110

(a) Temperature (°F) 120

(b) Pressure (psig) 0.3

(b) Pressure (psig) 0.3

(c) Humidity (%) 80

(c) Humidity (%) 90

(d) Radiation (rd) 1.0x10<sup>6</sup>

(d) Radiation (rd) NA

(3) Process Interfaces: Valve body and stem connection configuration

eliminates significant additional heating of the degradable actuator parts due to elevated temperatures in process fluids.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist for up to 8 hours per

excursion and will occur less than 1% of the plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 160

Accident type LOCA

(b) Pressure (psig) 12.0

Accident type LOCA

(c) Humidity (%) 100

Accident type LOCA

(d) Radiation (rd) 3.8 x 10<sup>7</sup>

Accident type LOCA

(e) Spray Type See Sheet 17

Accident type LOCA

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 17B OF 33

BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED D J Cox DATE 5/21/86 R     R    

OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED WJH DATE 5/21/86

**K. REQUIRED OPERATING ENVIRONMENT**

Reference Environmental Drawing No. 47E235-42 R1

(1) Normal Max

(a) Temperature (°F) 120

(b) Pressure (psig) 0.3

(c) Humidity (%) 80

(d) Radiation (rd) 8x10<sup>7</sup>

(2) Abnormal Max

(a) Temperature (°F) 130

(b) Pressure (psig) 0.3

(c) Humidity (%) 100

(d) Radiation (rd) NA

(3) Process Interfaces: Valve body and stem connection configuration

eliminates significant additional heating of the degradable actuator parts due to elevated temperatures in process fluids.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist for up to 8 hours per

excursion and will occur less than 1% of the plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 327 Accident type MSLB

(b) Pressure (psig) 12.0 Accident type LOCA

(c) Humidity (%) 100 Accident type LOCA

(d) Radiation (rd) 4.0 x 10<sup>7</sup> Accident type LOCA

(e) Spray Type See Sheet 17 Accident type LOCA

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-61 R0

- |  |                                   |
|--|-----------------------------------|
| (1) Normal Max                               | (2) Abnormal Max                  |
| (a) Temperature (°F) <u>104</u>              | (a) Temperature (°F) <u>110</u>   |
| (b) Pressure (psig) <u>ATM(-)</u>            | (b) Pressure (psig) <u>ATM(-)</u> |
| (c) Humidity (%) <u>80</u>                   | (c) Humidity (%) <u>90</u>        |
| (d) Radiation (rd) <u>7.5x10<sup>6</sup></u> | (d) Radiation (rd) <u>NA</u>      |

(3) Process Interfaces: Valve body and stem connection configuration eliminates significant additional heating of the degradable actuator parts due to elevated temperatures in process fluids.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist for up to 8 hours per excursion and will occur less than 1% of the plant life.

- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- |  |                           |
|--|---------------------------|
| (a) Temperature (°F) <u>110</u>            | Accident type <u>LOCA</u> |
| (b) Pressure (psig) <u>ATM</u>             | Accident type <u>LOCA</u> |
| (c) Humidity (%) <u>NA</u>                 | Accident type <u>LOCA</u> |
| (d) Radiation (rd) <u>5x10<sup>6</sup></u> | Accident type <u>LOCA</u> |
| (e) Spray Type <u>NA</u>                   | Accident type <u>   </u>  |

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 17D OF 33  
 BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED Df Cop DATE 5/21/86 R     R      
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED Wahman DATE 5/21/86

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-74 RO

(1) Normal Max

(a) Temperature (°F) 104  
 (b) Pressure (psig) ATM(-)  
 (c) Humidity (%) 80  
 (d) Radiation (rd) 4.3x10<sup>5</sup>

(2) Abnormal Max

(a) Temperature (°F) 110  
 (b) Pressure (psig) ATM(-)  
 (c) Humidity (%) 90  
 (d) Radiation (rd) LOCA

(3) Process Interfaces: Valve body and stem connection configuration

eliminates significant additional heating of the degradable actuator parts due to elevated temperatures in process fluids.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist for up to 8 hours per excursion and will occur less than 1% of the plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F)	<u>110</u>	Accident type	<u>LOCA</u>
(b) Pressure (psig)	<u>NA</u>	Accident type	<u>LOCA</u>
(c) Humidity (%)	<u>NA</u>	Accident type	<u>LOCA</u>
(d) Radiation (rd)	<u>1x10<sup>7</sup></u>	Accident type	<u>LOCA</u>
(e) Spray Type	<u>NA</u>	Accident type	<u>   </u>

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-77 R0

- |  |                                 |
|--|---------------------------------|
| (1) Normal Max                               | (2) Abnormal Max                |
| (a) Temperature (°F) <u>104</u>              | (a) Temperature (°F) <u>110</u> |
| (b) Pressure (psig) <u>ATM</u>               | (b) Pressure (psig) <u>ATM</u>  |
| (c) Humidity (%) <u>80</u>                   | (c) Humidity (%) <u>90</u>      |
| (d) Radiation (rd) <u>1.8x10<sup>6</sup></u> | (d) Radiation (rd) <u>NA</u>    |

(3) Process Interfaces: Valve body and stem connection configuration eliminates significant additional heating of the degradable actuator parts due to elevated temperatures in process fluids.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal conditions could exist for up to 8 hours per excursion and will occur less than 1% of the plant life.

- (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):
- |  |                           |
|--|---------------------------|
| (a) Temperature (°F) <u>190</u>            | Accident type <u>LOCA</u> |
| (b) Pressure (psig) <u>ATM</u>             | Accident type <u>LOCA</u> |
| (c) Humidity (%) <u>90</u>                 | Accident type <u>LOCA</u> |
| (d) Radiation (rd) <u>1x10<sup>7</sup></u> | Accident type <u>LOCA</u> |
| (e) Spray Type <u>NA</u>                   | Accident type <u>   </u>  |

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 18 OF 33  
 BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED D & Co DATE 5/21/86 R     R      
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED [Signature] DATE 5/21/86

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.):

See P(1) for discussion on chemical spray.

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (yes/no/NA)? No (Reference See EQC TAB C, item 2 ).

(7) Subject to submergence (yes/no/NA)? Yes  
 (Reference EQC TAB B, item P(3) ).

Identify initiation time and duration of submergence: See discussion on submergence in P(3). Submergence is not a qualification concern based on assessment.

(8) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
<u>Radiation - 40-Yr Containment Dose</u>	<u>B45 851117 235</u>
<u>Radiation - Accident Dose - Reactor Bldg</u>	<u>B45 860205 235</u>
<u>Radiation - 40-Yr Dose - Outside Shield Bldg</u>	<u>B45 860401 235</u>

**L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS**

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100d</u>	<u>30d</u>	<u>600456, Sect. 4.4.1, Fig 6</u>
Temperature (°F)	<u>327</u>	<u>315</u>	<u>600456, Sect. 4.4.1, Fig 6</u>
Pressure (psig)	<u>12.0</u>	<u>78</u>	<u>600456, Fig 7 Sect. 4.4.1</u>
Relative Humidity (%)	<u>100</u>	<u>100</u>	<u>600456</u>
	<u>8.2pH; 0.18M H<sub>3</sub>BO<sub>3</sub></u>		<u>Sect. 4.4.3</u>
	<u>30d; 200PPM Boron</u>	<u>See P(1)</u>	<u>600456</u>
*Chemical Spray	<u>0.033M NaOH</u>		<u>Sect. 4.4.2</u>
			<u>600456</u>
**Radiation (rd)	<u>120E06</u>	<u>204E06</u>	<u>Sect. 3.3</u>
Submergence	<u>TAB B, Sect. P(3)</u>	<u>None</u>	<u>NA</u>

\*Includes spray concentration, flowrate, density, duration, and pH.

\*\*Enter 40-year integrated normal dose plus integrated accident dose and specify type.

\*\*\*See K(5) for discussion on Beta Radiation.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>No</u>	<u>600456 Fig 6</u>
Pressure	<u>Yes</u>	<u>600456 Fig 5,6,7</u>
Relative Humidity	<u>Yes</u>	<u>600456 Sect. 4.4.3</u>
Chemical Spray	<u>Yes</u>	<u>600456 Sect. 4.4.2</u>
Submergence	<u>No</u>	<u>TAB B, Sect. P (3)</u>

JUSTIFICATION/COMMENTS EOC TAB C, Section 7.0 presents justification for comparison of required V.S. test profile for time and temperature. See TAB B, Sect. P (2), for enveloping test profile breakdown.

PAGE B-24



BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 20 OF 33  
 BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED DJ Cap DATE 5/21/86 R     R      
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED WB/Kim DATE 5/21/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

See TAB B, Sect. P (3), for discussion on submergence. With respect to beta radiation, the metallic mass of the operator eliminates the concern for beta radiation.

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, yes/no/NA)

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	<u>None</u>	<u>No</u>
Pressure: +10% but no more than 10 psig	<u>10%</u>	<u>Yes</u>
Radiation: +10% of accident dose	<u>10%</u>	<u>Yes</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>+10%</u>	<u>Yes</u>
Voltage: +10% of rated value	<u>See Comment</u>	<u>No</u>
Frequency: +5% of rated value	<u>NA</u>	<u>NA</u>
Environmental Transient: the initial transient and the peak temperature applied twice	<u>2 DWELLS</u>	<u>Yes</u>
Vibration: +10% added to acceleration	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS: #600456, Section 3.0 states that the test actuator was subjected to additional load cycling after environmental tests and prior to final inspection as an added test margin. EQC TAB C, Section 7.0 presents justification for margin with respect to test temperature and time. See EQC TAB C, Section 6.0 for justification for lack of reduced voltage testing.

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:  
(Reference B0058, Sect. 2.4 ).

JUSTIFICATION/COMMENTS The basic function of a valve actuator is to provide the required torque and/or thrust to open or close the valve as required.

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes  
(Reference 600456, Sect. 4.4.5 & 5.0 ).

JUSTIFICATION/COMMENTS The test unit functioned adequately throughout the entire test.

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? Yes  
(Reference 600456, Sect. 4.4.5 & 5.0 ).

JUSTIFICATION/COMMENTS The test unit functioned adequately throughout the entire test.

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? No (Reference 600456, Fig. 6 ).

JUSTIFICATION/COMMENTS See EQC TAB C, Section 7.0 for justification of actuator operability post-accident.

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? Yes  
(Reference 600456, Sect. 4.4.5 & 4.6 ).

JUSTIFICATION/COMMENTS Minor problems were experienced during and after the LOCA test; however, these had no effect on actuator performance. See referenced sections of Limitorque report 600456.

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 22 OF 33  
BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED DJ Col DATE 5/21/86 R     R      
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED WJH DATE 7/1/86

**N. MAINTENANCE AND SURVEILLANCE**

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the EQC Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS See EQC TAB G.

---

---

---

---

---

---

---

---

---

---

0. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
(1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
(2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>NA</u>
(3) Choice of qualification methodology adequately justified?	<u>Yes</u>
(4) If analysis was performed, complete the following:	
(a) Were equipment performance requirements identified?	<u>NA</u>
(b) Were specific features and failure modes and effects analyzed?	<u>NA</u>
(c) Were assumptions and mathematical models used together with appropriate justification for their use?	<u>NA</u>
(d) Were environmental parameters which affect equipment performance identified?	<u>NA</u>
(5) Adequate similarity between equipment and test specimen established?	<u>Yes</u>
(6) Aging degradation evaluated adequately?	<u>Yes</u>
(a) Mechanical and/or cycle aging addressed?	<u>Yes</u>
(b) Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes*</u>
(c) Absence of preaging in test/analysis justified?	<u>Yes</u>
(d) Materials susceptible to thermal/radiation aging identified?	<u>Yes</u>

\*Only the motor was pre-aged prior to application of DBE conditions. See TAB C for aging of switch materials.

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 24 OF 33  
 BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED Df Cox DATE 5/2/86 R     R      
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED W/Phid DATE 7/2/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>Yes</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>Yes</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>Yes</u>
(11) Criteria regarding submergence satisfied?	<u>Yes</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 25 OF 33  
 BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED DAC DATE 5/21/86 R     R      
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED WJH DATE 5/21/86

O. SUMMARY OF REVIEW (Continued)

- |  | <u>Yes/No/NA</u> |
|--|------------------|
| (15) Criteria regarding functional testing satisfied?  | <u>Yes</u>       |
| (a) Does the test plan/report specify an acceptance criteria for equipment performed?  | <u>Yes</u>       |
| (b) Was an initial base line test done to establish required performance characteristics?  | <u>Yes</u>       |
| (c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? | <u>Yes</u>       |
| (16) Criteria regarding instrument accuracy satisfied?   | <u>NA</u>        |
| (17) Test duration margin (1 hour + function time) satisfied?  | <u>Yes</u>       |
| (a) Is the minimum specified operating time at least 1 hour?   | <u>Yes</u>       |
| (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided?  | <u>NA</u>        |
| (18) Criteria regarding synergistic effects satisfied?   | <u>Yes</u>       |
| (19) Criteria regarding margins satisfied?   | <u>Yes</u>       |
| (20) Maintenance and surveillance requirements adequately identified?  | <u>Yes</u>       |

P. DISCUSSION

(1) Chemical spray: Limitorque report 600456, section 4.4.2 states that chemical spray was applied during the LOCA test in accordance with IEEE Standard 382 (1972), page 12 chemical mixture. Overall spray flowrate was 1.2 gal/min; pH ranged from 11.1 to 10.5;

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 26 OF 33

BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED DTC DATE 5/22/86 R     R    

OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED WBP DATE 5/22/86

P. DISCUSSION (Continued)

each manifold was maintained at 0.6 gal/min spray flowrate. Section 4.4.2 additionally states that test samples were taken at 24 hours into the test. IEEE Standard 382 (72), page 12 specifies 0.28 molar  $H_3BO_3$  (3000PPM boron); 0.064 molar  $Na_2S_2O_3$ . Since Watts Bar's upper and lower containment are physically separated, and only the upper containment actuators will be subjected to chemical spray, and the actuators located in upper containment are only required to be operable for 5 minutes to change position one time, the 24 hour spray during the Limitorque test is acceptable.

(2) Test Profile: (ref. L(2)). Limitorque report 600456, Fig. 5, 6, and 7 show test profile data:

First Dwell: 300°F/78psig/Steam 100%/0-15.2 sec. 295-300°F/70psig  
Steam 100%/15.2 sec. to 33 min., 3.2 hour cooldown.

Second Dwell: 300°F/78psig/Steam 100%/0-13.8 sec. 310-315°F/70psig/  
Steam 100%/13.8 sec. - 24 min. 1 hour rampdown.

245-265°F/30psig/100% Steam/90 hr. 57 min. 1 hour  
rampdown.

192-200°F/10psig/100% Steam/4d 66 min.-30 days.

Cooldown to room ambient.

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 27 OF 33  
 BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED DJ Cas DATE 4/21/86 R     R      
 OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED WJH DATE 5/21/86

P. DISCUSSION (Continued)

(3) Submergence:

<u>I.D. Number</u>	<u>Elevation</u>	<u>Location</u>	<u>Flood Elevation</u>
<u>1-FCV-62-61</u>	<u>730'</u>	<u>Outside crane wall</u>	<u>717'7"</u>
<u>1-FCV-63-72</u>	<u>693'6"</u>	<u>RHR sump valve room</u>	<u>See Note (1)</u>
<u>1-FCV-63-73</u>	<u>693'7"</u>	<u>RHR sump valve room</u>	<u>See Note (1)</u>
<u>1-FCV-63-172</u>	<u>729'4"</u>	<u>713 A28</u>	<u>713'3"</u>
<u>1-FCV-67-87</u>	<u>722'</u>	<u>Outside crane wall</u>	<u>717'7"</u>
<u>1-FCV-67-95</u>	<u>721'</u>	<u>Outside crane wall</u>	<u>717'7"</u>
<u>1-FCV-67-103</u>	<u>722'</u>	<u>Outside crane wall</u>	<u>717'7"</u>
<u>1-FCV-67-111</u>	<u>722'</u>	<u>Outside crane wall</u>	<u>717'7"</u>
<u>1-FCV-67-295</u>	<u>814'</u>	<u>Outside crane wall</u>	<u>717'7"</u>
<u>1-FCV-67-296</u>	<u>814'</u>	<u>Outside crane wall</u>	<u>717'7"</u>
<u>1-FCV-67-297</u>	<u>814'</u>	<u>Outside crane wall</u>	<u>717'7"</u>
<u>1-FCV-67-298</u>	<u>814'</u>	<u>Outside crane wall</u>	<u>717'7"</u>

NOTE 1: For flooding this space is not affected by breaks in any of the following high energy systems: Aux Feedwater, Aux Boiler, RHR, and CVCS.



BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 28 OF 33  
 BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED DJ Cap DATE 5/1/86 R     R      
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED WJH DATE 5/21/86

P. DISCUSSION (Continued)

(3) Submergence:

<u>I.D. Number</u>	<u>Elevation</u>	<u>Location</u>	<u>Flood Elevation</u>
<u>1-FCV-68-332</u>	<u>788'</u>	<u>Inside crane wall</u>	<u>722'0"</u>
<u>1-FCV-68-333</u>	<u>788'</u>	<u>Inside crane wall</u>	<u>722'0"</u>
<u>1-FCV-70-87</u>	<u>733'</u>	<u>Outside crane wall</u>	<u>717'7"</u>
<u>1-FCV-70-89</u>	<u>721'</u>	<u>Outside crane wall</u>	<u>717'7"</u>
<u>1-FCV-74-1</u>	<u>711'</u>	<u>Inside crane wall</u>	<u>See Note (2)</u>
<u>1-FCV-74-2</u>	<u>723'</u>	<u>Outside crane wall</u>	<u>See Note (2)</u>
<u>1-FCV-74-3</u>	<u>686'</u>	<u>676 A11</u>	<u>676'7"</u>
<u>1-FCV-74-8</u>	<u>722'</u>	<u>Inside crane wall</u>	<u>See Note (2)</u>
<u>1-FCV-74-9</u>	<u>710'</u>	<u>Outside crane wall</u>	<u>See Note (2)</u>
<u>1-FCV-74-21</u>	<u>686'</u>	<u>676 A10</u>	<u>676'7"</u>

Listed above are the elevations as taken from TAB F, and the associated flood elevations as taken from the environmental drawing for containment actuators, and from calculation WBNOSG4-44RO for actuators located outside containment. Comparing the actuator elevation to the expected flood levels resulting from design basis accidents, we can determine that no actuators will be submerged.

NOTE 2: While these actuators are located inside containment, they are only required to function for an RHR line break. QIR NEB85061 (B45 850917 268) shows that 15 minutes after an RHR line break the water level inside containment will be less than 1 ft. As stated in TAB A, these actuators are only required to operate 15 minutes for an RHR line break. Therefore, these actuators will have performed their safety function prior to submergence and are qualified for this postulated accident.

- (4) CALCULATION TO DETERMINE THE MAXIMUM AMOUNT OF CONDENSATE TO ACCUMULATE IN THE LIMIT SWITCH COMPARTMENT OF A LIMITORQUE VALVE ACTUATOR DURING A HELB.

Concerning the potential problem of steam entering the conduit during a HELB, condensing, and subsequently running down a long vertical conduit run and into the actuator, we present the following assumptions and calculations:

1. Assume the conduit is 1 1/2 inch rigid steel conduit conforming to the dimensions listed in TVA Electrical Design Standard DS-E13.1.3, Revision 0.

Weight is 2.51 lbs/ft

OD = 1.90

ID = 1.61

Wall Thickness = 0.29

2. Conduit is 0.5% carbon steel with a specific heat of  $0.111 \frac{\text{BTU}}{\text{lb} \cdot ^\circ\text{F}}$ .
3. Peak pressure to be evaluated is 26.8 psia. This is the maximum pressure to be expected in containment following a HELB or LOCA. PEAK PRESSURE, NOT TEMPERATURE is used because steam will condense only as long as the object on which it is condensing remains below the saturation temperature for that particular pressure. Therefore, a conduit will support the condensing of steam during a HELB until the elevated room temperature and the energy liberated by the change in phase from saturated steam to saturated liquid during condensation cause the temperature of the conduit to increase to the saturated steam temperature.
4. Assume the initial conduit temperature is 50°F, which is the minimum abnormal temperature for containment as taken from drawing 85M 47E235-42. It should be noted that the heat loads generated by plant operation will keep the lower containment temperature higher than 50°F. Examination of the time/temperature curve on the environmental drawing shows that the containment temperature will be in excess of 200°F when the ambient pressure reaches 26.7 psia. However, since 50°F is very easily defendable as a minimum temperature, it will be used instead of a temperature more relevant to actual operating conditions.

PAGE B-34

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 30 OF 33  
 BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED D.P. Col DATE 5/6/86 R     R      
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED WJA DATE 5/4/86

Appendix B of NUREG-0588 - "Model for Environmental Qualification for loss of coolant accident and main steam line break inside FWR and BWR dry type containment" bases condensate heat transfer to components upon the following equation:

$$q/A = h_{\text{cond}}(T_s - T_w)$$

Where:

$q/A$  = Component Surface Heat Flux

$h_{\text{cond}}$  = Condensing Heat Transfer Coefficient

$T_s$  = Saturation Temperature

$T_w$  = Component Surface Temperature

If the component surface temperature ( $T_w$ ) is equal to the saturation temperature ( $T_s$ ), the right hand side of the equation will equal zero. Therefore, if no heat is being transferred from the steam, and heat transfer is required for the phase change from steam to condensate, we can conclude that no more condensate will be formed (as stated in assumption No. 3).

The amount of heat required to raise a component from some initial temperature to a higher temperature, in this case the saturation temperature, is:

$$q = M C_p (T_s - T_i)$$

Where:

$M$  = Mass of the Component

$C_p$  = Specific Heat at Constant Pressure

$T_s$  = Saturation Temperature

$T_i$  = Initial Temperature of the Component

For the Conduit:

$$q = 2.51 \frac{\text{lb}}{\text{ft}} * 0.111 \frac{\text{BTU}}{\text{lb} \cdot ^\circ\text{F}} * (244-50)^\circ\text{F}$$

$$= 54.05 \frac{\text{BTU}}{\text{ft}}$$

PAGE B-35

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 31 OF 33  
 BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED D.J. Coy DATE 5/21/86 R     R      
OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED WJH DATE 5/21/86

244°F is the saturation temperature for a relative humidity of 100% and a pressure of 26.8 psia (slightly higher than the 26.7 psia containment pressure). This should yield the theoretical maximum amount of condensate heat transfer.

Assuming none of the condensate vaporizes, the mass of the condensate can now be calculated:

$$M_{\text{condensed}} = \frac{q_{\text{transferred}}}{h_{fg}}$$

Where  $h_{fg}$  = latent heat of vaporization  $\frac{\text{BTU}}{\text{lb}_m}$

$$\text{At } 244^\circ\text{F, } h_{fg} = 949.5 \frac{\text{BTU}}{\text{lb}_m}$$

Note that  $h_{fg}$  increases as temperature decreases. Therefore, the lower temperature in the auxiliary building would yield smaller amounts of condensate.

$$\text{Therefore, } M_{\text{cond}} = \frac{54.05 \frac{\text{BTU}}{\text{ft}}}{949.5 \frac{\text{BTU}}{\text{lb}_m}} = 0.0569 \text{ lb}_m/\text{ft of conduit}$$

This is the amount of condensate that will be formed both inside and outside the conduit. If we consider the conduit to be nonporous, which implies that the condensate on the outside of the conduit will not enter the conduit and increase the mass of the condensate on the inside of the conduit, we can determine the amount of condensate that will be formed inside the conduit. By necessity the external surface area of the conduit is larger than the internal surface area of the conduit, which implies that more than half of condensate formed will be on the outside of the conduit. Comparing the inside and outside surface areas per lineal foot:

$$\frac{D_o}{D_i} = \frac{1.90}{1.61} = 1.18$$

We find that there is 18 percent more surface area outside the conduit on which to form condensate. The mass of condensate inside the conduit ( $m_i$ ) can be determined as follows (mass of condensate is a function of available surface area for formation):

PAGE B-36

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 32 OF 33

BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED D. J. Coy DATE 5/21/86 R     R    

OPERATORS WITH TYPE RH INSULATED MOTOR CHECKED W. J. Coy DATE 5/21/86

$$\frac{M_o}{M_i} = 1.18 \quad M_o = 1.18 M_i$$

$M_i$

$$M_o + M_i = 0.0569 \text{ lb}_m/\text{ft}$$

$$1.18 M_i + M_i = 0.0569 \text{ lb}_m/\text{ft}$$

$$2.18 M_i = 0.0569 \text{ lb}_m/\text{ft}$$

$$M_i = 0.0261 \text{ lb}_m/\text{ft}$$

At 244°F water has a density of approximately 59.7 lb/ft<sup>3</sup>.

If we use the limit switch compartment for the SMB-000 actuator (11.75 x 9.5 in), we can determine the greatest theoretical depth of accumulated condensate.

$$(11.75 \text{ in}) (9.5 \text{ in}) = 111.625 \text{ in}^2 = 0.7752 \text{ ft}^2$$

NOTE: This would be the smallest limit switch compartment for any of the Limitorque operators in the 10CFR50.49 program at WBNP.

If we assume the longest vertical run of unobstructed conduit to be 30 ft in length, we get the following depth of condensate in the limit switch compartment.

$$\frac{0.0261 \text{ lb}/\text{ft} \times 30 \text{ ft} \times 1 \text{ ft}^3/59.7 \text{ lb}}{0.7752 \text{ ft}^2} = 0.0169 \text{ ft} = 0.20 \text{ in}$$

Assuming all conditions to be worst case, that is the largest amount of condensate in the smallest space, we calculate less than 13/64" of condensate in the limit switch compartment, which is not deep enough to submerge any of the electrical contacts on the limit switch. Therefore, the conduit configuration at WBN is deemed to result in no condensate problems for Limitorque MOVs.

BINDER NO. WBNEQ-MOV -001 PLANT WBN UNIT(S) 1 SHEET 33 OF 33  
BINDER TITLE LIMITORQUE MOTORIZED VALVE COMPUTED DTC DATE 5/21/86 R     R      
OPERATORS WITH TYPE RH INSULATED MOTOR     CHECKED WJH DATE 7/21/86

P. DISCUSSION (Continued)

(5) TAB B

<u>Report No</u>	<u>Purpose in Binder</u>
600456	Main Test Report for Qualification
B0058	Summary Report of Limitorque EQ Testing and EQ Philosophy
B0212	Aging of Fiberite Switch Material Low Level Vibration Testing
B0119	Qualification of Marathon Terminal Blocks
NUC-9 Supplement	Points Used to Generate Linear Regression Curve

PAGE B-38

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WBNED-MOV-002  
 MANUFACTURER: LIMITORQUE  
 PAGE: 1 OF 2

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN*	AZ	ELEV*						
WBN-1-MVOP-001-0015	-A 1-FCV-001-0015	-A AFPT STEAM SUPPLY FROM SG-1	SMB-00	SVR		729'	A01	74C38-83015	FM/V	A/B	1HR/100D	IF SG1 IS FAULTED VLV MUST CLOSE AND REMAIN CLOSED. IF SG1 IS NOT FAULTED, N.D. VLV MUST REMAIN OPEN TO ASSURE STEAM AVAIL TO AFPT
WBN-1-MVOP-001-0016	-A 1-FCV-001-0016	-A AFPT STEAM SUPPLY FROM SG-4	SMB-00	SVR		729'	A01	74C38-83015	FM/V	A/B	1HR/100D	IF SG4 IS FAULTED VLV MUST CLOSE AND REMAIN CLOSED. IF SG4 IS NOT FAULTED, N.D. VLV MUST REMAIN OPEN TO ASSURE STEAM AVAIL TO AFPT
WBN-1-MVOP-001-0017	-A 1-FCV-001-0017	-A STEAM FLOW TO AFPT ISOLATION	SMB-00	SVR		729'	A01	74C38-83015	FM/V	B	100D	NORMALLY OPEN VLV MUST REMAIN OPEN TO ASSURE STEAM IS AVAILABLE TO THE AFPT.
WBN-1-MVOP-001-0018	-B 1-FCV-001-0018	-B STEAM FLOW TO AFPT ISOLATION	SMB-00	SVR		729'	A01	74C38-83015	FM/V	B	100D	NORMALLY OPEN VLV MUST REMAIN OPEN TO ASSURE STEAM IS AVAILABLE TO THE AFPT.
WBN-1-MVOP-003-0033	-A 1-FCV-003-0033	-A SG1 FM ISOLATION VLV	SB-4	SVR		729'	A01	74C38-83015	FM/V NS/V	A/B A	5MIN/100D **	THIS VLV MUST CLOSE AND REMAIN CLOSED TO ISOLATE FM FLOW TO THE S.G.
WBN-1-MVOP-003-0047	-B 1-FCV-003-0047	-B SG2 FM ISOLATION VLV	SB-4	NVR		729'	A02	74C38-83015	FM/V NS/V	A/B A	5MIN/100D **	THIS VLV MUST CLOSE AND REMAIN CLOSED TO ISOLATE FM FLOW TO THE S.G.

PAGE A-1

NOTE: ALL SB-4 ACTUATORS IN THIS BINDER ARE EQUIPPED WITH DINGS BRAKES.

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS AND LOCATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS FOUND IN TAB F.

\*\* - SEE APPENDIX I.

PREPARER/DATE *Keith B. Mepstead* 8/14/86  
 CHECKER/DATE *Kevin M. Burton* 8/17/86

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. MBNEQ-MOV-002  
 MANUFACTURER: LIMITORQUE  
 PAGE: 2 OF 2

EDIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN*	AZ	ELEV*						
MBN-1-MVDP-003-0087	-A 1-FCV-003-0087	-A 563 FM ISOLATION VLV	SB-4	NVR		729'	A02	74C38-83015	FM/V NS/V	A/B A	5MIN/1000 **	THIS VLV MUST CLOSE AND REMAIN CLOSED TO ISOLATE FM FLOW TO THE S.G.
MBN-1-MVDP-003-0100	-B 1-FCV-003-0100	-B 564 FM ISOLATION VLV	SB-4	SVR		729'	A01	74C38-83015	FM/V NS/V	A/B A	5MIN/1000 **	THIS VLV MUST CLOSE AND REMAIN CLOSED TO ISOLATE FM FLOW TO THE S.G.

PAGE A-2

NOTE: ALL SB-4 ACTUATORS IN THIS BINDER ARE EQUIPPED WITH DINGS BRAKES.

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS AND LOCATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS FOUND IN TAB F.

\*\* - SEE APPENDIX I.

PREPARER/DATE Keith B. Nassim 8/14/86 R \_\_\_ R \_\_\_ R \_\_\_  
 CHECKER/DATE Juanita A. Benitez 8/14/86



BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 1 OF 1  
 BINDER TITLE LIMITORQUE COMPUTED KBN DATE 8/4/86 R     R      
ACTUATORS IN THE VALVE ROOMS CHECKED B DATE 8/14/86

TAB A

Appendix I

The valves listed below have varying operating times for a MSLB depending on the size of the break. We have tabulated the minimum and maximum times below per OE calculation WBNOSG4-003 (B45 851112 218, TAB E).

<u>Valve ID</u>	<u>Operating time for MSLB</u>	
	<u>Min.</u>	<u>Max.</u>
1-FCV-3-33	9.2 sec.	192.4 sec.
1-FCV-3-47	9.2 sec.	192.4 sec.
1-FCV-3-87	9.2 sec.	192.4 sec.
1-FCV-3-100	9.2 sec.	192.4 sec.

The safety function of these valves is completed 46.8 to 117.1 seconds before tube bundle uncover occurs.

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 1 OF 1  
 BINDER TITLE LIMITORQUE COMPUTED KBN DATE 8/14/86 R     R      
 ACTUATORS IN THE VALVE ROOMS CHECKED B DATE 8/14/86

INTRODUCTION TO TAB B

Use of Test Reports

<u>Report No.</u>	<u>Purpose in Binder</u>
B0003	Main Test Report for Qualification
B0058	Summary Report of Limitorque EQ Testing and EQ Philosophy
B0027	Used to Show Actuators Act as Heat Sinks
B0212	Aging of General Purpose Phenolic Material and Low Level Vibration Testing
B0119	Qualification of Marathon Terminal Blocks
B0080	Thermal Aging of Class B Motors
600198	Used to Show Actuators do not Require Conduit Sealing & Brake Qualification
WCAP-7410-L	Thermal Aging of Class B Motors
600456	Brake Qualification
600376A	Brake Qualification

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 1 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KBN DATE 8/14/86 R     R      
 ACTUATORS IN THE VALVE ROOMS CHECKED 10 DATE 8/14/86

A. DOCUMENTATION

Equipment Description Motor Operated Valve Actuators  
 Vendor/Manufacturer Limitorque  
 Equipment Model No.(s) See Tab A

QUALIFICATION REPORTS

- (1) Title/Number/Revision Limitorque Valve Actuator RIMS NEB 820421 203  
Qualification for Nuclear Services #B0058 DATE 1-11-80  
and Appendix A
- (2) Title/Number/Revision Limitorque Valve Actua- RIMS B70 851119 105  
tors for Outside Containment #B0003 (Appendix D DATE 6-2-76  
of #B0058)
- (3) Title/Number/Revision B0027-Limitorque Valve RIMS NEB 820421 203  
Actuator Temperature Related to High Superheated DATE 10-18-78  
Ambient Temperatures
- (4) Title/Number/Revision B0212-Limitorque Valve RIMS B70 851228 100  
Actuators with Type LR Motor for Westinghouse DATE 4-10-85  
PWR.
- (5) Title/Number/Revision B0119-Multi-Point Termi- RIMS NEB 840823 353  
nal Strips for use in Limitorque Valve Actuators DATE July 1, 1982  
for PWR Service.
- (6) Title/Number/Revision B0080-Class B Motor: RIMS B70 851213 001  
Effects of Thermal Aging on Locked Rotor DATE July 18, 1980  
Performance.
- (7) Title/Number/Revision 600198-Test of Limitorque RIMS MEB 840418 950  
Actuator in Nuclear Reactor Containment DATE January 2, 1969  
Environment
- (8) Title/Number/Revision WCAP-7410-L-Environmental RIMS NEB 801211 308  
Testing of Engineered Safety Features Related DATE December 1970  
Equipment
- (9) Title/Number/Revision 600456-Limitorque Valve RIMS NEB 820421 203  
Actuators for PWR Service DATE December 9, 1975
- (10) Title/Number/Revision 600376A-Limitorque Valve RIMS NEB 820421 203  
Actuators for BWR Service DATE May 13, 1976

PAGE B-2

BINDER NO. WBNEQ-MOV-002 PLANT \_\_\_\_\_ WBN \_\_\_\_\_ UNIT(S) 1 SHEET 2 OF 30  
BINDER TITLE LIMITORQUE COMPUTED KW DATE 8/4/86 R \_\_\_\_\_ R \_\_\_\_\_  
ACTUATORS IN THE VALVE ROOMS CHECKED B DATE 8/14/86

OTHER (ANALYSIS, VENDOR DATA, ETC.) 1. Valve I.D., test report, contract  
cross reference. 2. B70 850925 012. 3. MEB 811215 508.  
4. B70 850910 004. 5. B70 850926 001. 6. B70 851107 021.  
7. B70 851107 022. 8. B70 851213 001. 9. QIR NEB86035 (B45 860317 251)  
10. Aging Calculation WAC-43. 11. Aging Data Transmittal WAD-7  
12. WBNOSG4-003 (B45 851112 218). 13. B71 860623 003 and B71 860623 004  
Copies of above reports and documents can be found in Tabs D and E.

PAGE B-3

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 3 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KBN DATE 9/17/86 R     R      
 ACTUATORS IN THE VALVE ROOMS CHECKED B DATE 9/17/86

B. CONCLUSION OF REVIEW (Check only one block)

- X Equipment Qualified
- Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule
- Equipment Qualification Not Established by Documentation
- Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES \_\_\_\_\_

1. The internal control cable cannot be qualified and will be replaced per SCR WBNEEB8551. 2. Center tap leads (nylon wire nuts) cannot be qualified and will be replaced per SCR WBNMEB8651.  
3. Valves 1-FCV-3-33,-47,-87, and -100 do not have adequate voltage during accident conditions. 4. These valves are equipped with heaters in the limit switch and motor compartments. These will be disconnected per SCR WBNMEB8649. 5. Valves 1-FCV-3-33,-47,-87, and -100 are equipped with brakes that cannot be qualified. These will be replaced per SCR WBNEQP8629. 6. TVA has not provided the NRC with a final response to IE Bulletin 85-03. Complete revised field verification shall be provided upon completion of all of the above items requiring fieldwork. This shall be performed in accordance with TI-72.

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 4 OF 30  
BINDER TITLE LIMITORQUE COMPUTED KBN DATE 8/14/86 R     R      
ACTUATORS IN THE VALVE ROOMS CHECKED B DATE 8/14/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

       Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)

  X   Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS None

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET  
The Limitorque Environmental Qualification program was conducted per IEEE-382 (1972), "IEEE Guide for Type Test of Class 1 Electric Valve Operators for Nuclear Power Generating Stations" and meets the requirements of IEEE-323 (1974) as they apply to valve actuators (#B0058, Section 2.1).

PAGE B-5

BINDER NO. WBNEQ-MOV-002 PLANT \_\_\_\_\_ WBN \_\_\_\_\_ UNIT(S) 1 SHEET 5 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KBU DATE 8/4/86 R \_\_\_\_\_ R \_\_\_\_\_  
 ACTUATORS IN THE VALVE ROOMS \_\_\_\_\_ CHECKED B DATE 8/14/86 \_\_\_\_\_

D. QUALIFICATION METHODOLOGY (Check only one block)

- Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis  
 Test of Similar Items with Supporting Analysis  
 Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions  
 Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS The Limitorque qualification program was  
conducted to encompass the entire family of actuators - SMB, SB,  
SBD, and SMB/HBC in all available unit sizes (SMB-000 to SMB-5).  
This was accomplished by type testing - see EQC Tab C, Section 1.  
Tab E, Attachment 1 identifies the actuator plant ID number, the  
Limitorque shop order number, the actuator serial number, and the  
documentation which establishes traceability to the applicable test  
report. Furthermore, actuators 1-FCV-3-33,-47,-87, and -100 have  
electromagnetic brakes on the motors and brake qualification is  
addressed in TAB C. Except for the brake, these actuators are  
similar to those tested in Limitorque report B0003 (Reference  
Limitorque letter dated September 25, 1985, B70 850925 012 TAB E).

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 6 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KBN DATE 8/14/86 R     R      
 ACTUATORS IN THE VALVE ROOMS CHECKED PJ DATE 8/15/86

**E. EQUIPMENT DESCRIPTION**

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? No

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Motor Operated Valve Actuator</u>	<u>Motor Operated Valve Actuator</u>	<u>B0003, Sect. 3.0</u>
(2) Manufacturer	<u>Limitorque</u>	<u>Limitorque</u>	<u>B0003, Sect. 3.0</u>
(3) Model Number(s)	<u>SMB-00</u>	<u>SMB-0</u>	<u>Sect. 3.0</u>
	<u>SB-4 w/Brakes</u>	<u>                    </u>	<u>                    </u>
(4) Serial Number(s)	<u>See TAB E</u>	<u>195004</u>	<u>B0003, Sect. 3.0</u>
Order Number(s)	<u>See TAB E</u>	<u>600461</u>	<u>B0003, Sect. 3.0</u>
(5) Identify Component-Unique checksheet attached:	<u>None</u>		

JUSTIFICATION/COMMENTS See Tab C, Section 1.

(4 & 5) TAB E, attachment 1 information was taken from Field

Verification sheets contained in TAB F.



BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 7 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KBY DATE 8/14/86 R     R      
 ACTUATORS IN THE VALVE ROOMS CHECKED B DATE 8/14/86

F. INSTALLATION INTERFACES

List all interface pertinent to EQ identified in the test report and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if No, provide justification.

<u>Interface</u>	<u>Identify Interface Requirement</u>	<u>Plant Requirement (Yes/No/)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>NA</u>	<u>NA</u>	<u>NA</u>
External Process Connections	<u>NA</u>	<u>NA</u>	<u>NA</u>
Electrical Connections	<u>NA</u>	<u>NA (See comments)</u>	<u>NA</u>
Conduit Seals	<u>None</u>	<u>No</u>	<u>B0058, Sec. 3.2.3 &amp; 4.1.2 See TAB B, Sec. P</u>
Connector Seals	<u>None</u>	<u>No</u>	<u>B0058, Sec. 3.2.3 &amp; 4.1.2</u>
Orientation	<u>horizontal with limit switch compartment up</u>	<u>No</u>	<u>See TAB G, Sec. A1</u>
Physical Configuration	<u>NA</u>	<u>NA</u>	<u>NA</u>
Other	<u>NA</u>	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS Report B0003 makes no mention of any specific installation interface requirements; however, B0058 Sections 3.2.3 and 4.1.2 conclude that sealing of the actuators (i.e. conduit seals, seals and gaskets) is of no importance for the qualification of the actuators. See Tab C, Sections 3.0 and 7.0. See Tab "C", Section 7.2 concerning orientation of the actuator. For electrical connections, a qualified power cable must be used. Terminal blocks must be Marathon 300 series. See Tab C, Section 4.0 for internal jumper wires.

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 8 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KBU DATE 8/14/86  
 ACTUATORS IN THE VALVE ROOMS CHECKED B DATE 8/14/86

G. TEST SEQUENCE

(1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>No</u>	<u>See Comments B0003, Fig. 2A and 2B</u>
(b) Baseline performance measurements taken	<u>Yes</u>	
(c) Equipment aged:		
Thermal	<u>Yes</u>	<u>B0003, Sect. 4.1</u>
Radiation	<u>Yes</u>	<u>B0003, Sect. 4.3</u>
Wear	<u>Yes</u>	<u>B0003, Sect. 4.2</u>
(d) Vibration/seismic testing conducted	<u>Yes-Seismic</u>	<u>B0003, Sect. 4.4</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	<u>B0003, Sect. 4.5.1</u>
(f) Post-DBE exposure	<u>Yes</u>	<u>B0003, Sect. 4.5.1</u>
(g) Final inspection and disassembly	<u>Yes</u>	<u>B0003, Sect. 4.5.3</u>

(2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes

(3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes  
 (Reference B0003, Appendix I).

JUSTIFICATION/COMMENTS (a) There is no evidence in the report that the equipment was inspected prior to start of the test. However, pre-inspection is not a requirement of IEEE 323 (1974). (b) The baseline performance measurements, taken at time zero, event zero, were within nominal, and are acceptable. (d) Low level vibration is addressed in Tab C, Section 2.0.

PAGE B-9

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 9 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KBN DATE 8/4/86 R     R      
 ACTUATORS IN THE VALVE ROOMS CHECKED B DATE 8/15/86

H. AGING

- (1) Was aging considered in the qualification program (Yes/no/NA)? Yes (Reference B0058, Sect. 3.0 ).

JUSTIFICATION/COMMENTS None

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>B0003, Sect. 4.1.4</u> <u>B0058, Sect. 3.2</u>
Radiation exposure	<u>Yes</u>	<u>B0003, Sect. 4.3</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>B0058, Sect. 2.1</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	<u>B0003, Sect. 4.2</u>

JUSTIFICATION/COMMENTS None

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? NA (Reference NA ).

JUSTIFICATION/COMMENTS A review of the materials used in this operator has shown there are no known synergistic effects.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program (yes/no/NA)? Yes (Reference B0003, Sect.4.1 ).  
B0058, Sect.3.2

JUSTIFICATION/COMMENTS See Tab C, Section 8.

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 10 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KBN DATE 8/14/86 R     R      
 ACTUATORS IN THE VALVE ROOMS CHECKED 12 DATE 8/15/86

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes (Reference: B0058, Sect. 3.2 ).

JUSTIFICATION/COMMENTS See Tab C, Section 8.

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference B0058, Sect. 3.2 ).

JUSTIFICATION/COMMENTS See Tab C, Section 8.

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference B0003, Sect.4.1 ).  
B0058, Sect.3.2.1.3

<u>Parameter</u>	<u>Plant Maximum</u>		
	<u>Normal</u>	<u>Test</u>	<u>Equivalent</u>
<u>Temperature</u>	<u>130°F</u>	<u>See Comments</u>	<u>See Comments</u>
<u>Time</u>	<u>40 years</u>	<u>See Comments</u>	<u>See Comments</u>

JUSTIFICATION/COMMENTS See Tab C, Section 8. All materials which are potentially susceptible to aging have qualified or expected life of greater than 40 years.

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference B0058, Sect. 3.2 ).

JUSTIFICATION/COMMENTS See Tab C, Section 8.

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? NA (Reference NA ).

JUSTIFICATION/COMMENTS See Tab C, Section 8.

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 11 OF 30  
BINDER TITLE LIMITORQUE COMPUTED KBN DATE 8/14/86 R     R      
ACTUATORS IN THE VALVE ROOMS CHECKED B DATE 8/15/86

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? Yes (Reference B0058, Sect. 3.2.1.3 ).

JUSTIFICATION/COMMENTS See Tab C, Section 8. Regression analysis provided for Class "B" insulated motor.

- (h) Was the equipment operated during the thermal aging (yes/no/NA)? Yes (Reference B0003, Sect. 4.1 ).

JUSTIFICATION/COMMENTS None

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (yes/no/NA)? Yes (Reference B0003, Sect. 4.3 ).  
B0058, Sect. 3.4

JUSTIFICATION/COMMENTS None

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (yes/no/NA)? NA  
(Reference B0058, Sect. 3.4 ).

JUSTIFICATION/COMMENTS None identified.

- (c) Was the basis for radiation aging exposure identified in the qualification program (yes/no/NA)? Yes  
(Reference B0058, Sect. 3.4 ).

JUSTIFICATION/COMMENTS None

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 12 OF 30  
BINDER TITLE LIMITORQUE COMPUTED KBN DATE 8/4/86 R     R      
ACTUATORS IN THE VALVE ROOMS CHECKED B DATE 8/15/86

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (yes/no/NA)? Yes (Reference B0003, Sect. 2.3 and 4.3 ).

Plant normal ambient radiation dose (rd) 1.8 x 10<sup>3</sup>

Test exposure dose (rd) 2.0 x 10<sup>7</sup>

Test exposure dose rate (rd/hr) 1.0 x 10<sup>6</sup>

Test exposure source type (e.g., Co-60 gamma) Co-60 gamma

JUSTIFICATION/COMMENTS \_\_\_\_\_

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference B0058, Sect. 2.1 ).

JUSTIFICATION/COMMENTS Non-seismic (low level) vibration was considered but determined to be of no consequence based on experience. See Tab C, Section 2.0.

- (b) Was the basis for vibration aging identified and justified in the qualification program (yes/no/NA)? NA (Reference B0058, Sect. 2.1 ).

JUSTIFICATION/COMMENTS See Tab C, Section 2.0 for justification of omission of non-seismic vibration aging.

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference B0003, Sect. 4.1.5 and 4.2 ).

JUSTIFICATION/COMMENTS The actuator was cycled (mech. aging) 1993 times.

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 13 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KBN DATE 8/14/86 R     R      
 ACTUATORS IN THE VALVE ROOMS CHECKED B DATE 8/15/86

H. AGING (Continued)

(b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference B0003, Sect.4.2 ).  
B0058, Sect.3.3

JUSTIFICATION/COMMENTS The actuator was required to provide its full output rating at the torque seated position during cycling.

(8) Was the qualified life of the equipment and its basis defined in the qualification program (yes/no/NA)? Yes (Reference B0058, Sect. 3.2 and 7.0 ).

Qualified life (Document in QMDS) greater than 40 years

JUSTIFICATION/COMMENTS None

(9) Were replacement intervals for the equipment or its components defined in the qualification program (yes/no/NA)? Yes (Reference B0058, Sect. 7.0 ).

Replacement Intervals (Document in QMDS) Seals and gaskets are to be replaced during routine maintenance when wear or damage is observed. Also, the actuator lubricants must be inspected for separation after each fuel cycle. If lubricant has separated it must be remixed or replaced (see Tab G, Sections A3, 7 and 8).

JUSTIFICATION/COMMENTS None

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 14 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KBN DATE 8/14/86 R     R      
 ACTUATORS IN THE VALVE ROOMS CHECKED B DATE 8/15/86

**I. MATERIALS ANALYSIS**

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Tab C of Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>Durez (Red)</u>	<u><math>2 \times 10^7</math></u>	<u>B0003(4.3)</u>	<u>1.02</u>	<u>See Comments</u>
(b) <u>G.P. Phenolic (Marathon 300)</u>	<u><math>2.09 \times 10^8</math></u>	<u>B0212(6.7)</u>	<u>1.63</u>	<u>See Comments</u>
(c) <u>Motor Insulation-CL-"B"</u>	<u><math>2 \times 10^7</math></u>	<u>B0003(4.3)</u>	<u>0.93</u>	<u>See Comments</u>
(d) <u>Wiring Insulation</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>	<u>See Tab C, Sect. 4.0</u>
(e) _____	_____	_____	_____	_____

JUSTIFICATION/COMMENTS Radiation threshold does not apply. Limitorque has performed radiation exposure per the referenced Limitorque test reports. The values listed in the threshold column represent the testing parameters.

Activation energies are documented in Tab E as follows:

- a. Durez - Limitorque letter September 25, 1985 RIMS (B70 850926 001) and TVA telex of November 6, 1985 RIMS (B70 851107 022)
- b. G. P. Phenolic - Limitorque letter September 15, 1985 RIMS (B70 850910 004)
- c. Motor insulation - Limitorque letter September 25, 1985 RIMS (B70 850926 001) and AC-210

See Tab C, Section 8.0 for material analysis.

Limitorque's telex dated November 6, 1985 RIMS (B70 851107 021) shows the correlation between the material color, material name and the test report.



BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 15 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KAN DATE 8/14/86 R     R      
 ACTUATORS IN THE VALVE ROOMS CHECKED     DATE 8/15/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference B0058, Sect. 4.1.8 ).

Identify Acceptance Criteria: The actuators must be capable of opening or closing a valve on demand, i.e., 6.5 seconds for 1-FCV-3-33, -47, -87, & -100, and 20 seconds for 1-FCV-1-15, & -16. Note that valves 1-FCV-1-17, & -18 do not have to change position for any accident.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference B0003, Sect.4.0, Fig.1, 2A, and 2B )

Identify baseline and functional testing: See Tab "C", Section 10.0.

JUSTIFICATION/COMMENTS None

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? No (Reference NA ).

JUSTIFICATION/COMMENTS B0003 does not describe mechanical loads during DBE testing. Electrical characteristics and stroke time during DBE cycling are shown in Figure 2B.

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 16 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KBN DATE 8/14/86 R     R      
 ACTUATORS IN THE VALVE ROOMS CHECKED B DATE 8/15/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

- (4) Do the applied loads during baseline testing reflect normal operating conditions (yes/no/NA)? Yes (Reference B0003, Sect. 4.1, 4.2, 4.5, Fig. 2A, and Fig. 2B).

JUSTIFICATION/COMMENTS None

- (5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

(a) <u>Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference</u>
Voltage	<u>See Comment</u>	<u>See Comment</u>
Load	<u>See Comment</u>	<u>NA</u>
Frequency	<u>60 Hz <math>\pm</math> 3.2%</u>	<u>WBN FSAR, Page 8.3-17</u>
Accuracy	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS Justification for lack of reduced voltage starting tests under accident conditions are presented in TAB C, Section 5.0. See comment on item 5b for frequency. Actuators are sized to produce the required torque for each valve under specified applications and conditions.

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 17 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KCN DATE 8/14/86 R     R      
 ACTUATORS IN THE VALVE ROOMS CHECKED B DATE 8/15/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

(5)(b) <u>Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>
Voltage	<u>495-500 VAC</u>	<u>B0003, Fig. 2B</u>
Load	<u>Thrust ~20,000 lbs.</u>	<u>B0003 Sect. 4.1</u>
Frequency	<u>60 Hz</u>	<u>See Comments</u>
Accuracy	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS \_\_\_\_\_

Although the test report does not address demonstrated frequency, we have no reason to believe that the operator was tested at other than 60 Hz. Also per Limatorque letter dated 6/18/86 (B71 860623 004 TAB E) the actuator motor is purchased to NEMA standards that require the motor to be able to operate at plus or minus 5 percent of nominal frequency.

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 18 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KBY DATE 8/14/86 R     R      
 ACTUATORS IN THE VALVE ROOMS CHECKED 13 DATE 8/14/86

K. REQUIRED OPERATION ENVIRONMENT

Reference Environmental Drawing No. 47E235-76 R2

(1) Normal Max

(a) Temperature (°F) 130

(b) Pressure (psig) 0

(c) Humidity (%) 50

\*(d) Radiation (rd) 1.8 x 10<sup>3</sup>

(2) Abnormal Max

(a) Temperature (°F) 140

(b) Pressure (psig) 0

(c) Humidity (%) 100

(d) Radiation (rd) 0

(3) Process Interfaces: Valve body and stem connection configuration eliminates significant additional heating of the degradable actuator parts due to high temperature lines.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal temperatures could occur as a result of outside temp. excursions, temporarily greater than design heat loads, or degraded environment control systems. This could exist for up to eight hours per excursion and will occur less than 1% of the plant life, but has been shown not to adversely affect the qualification.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 325 Accident type HELB

(b) Pressure (psig) 10.88 Accident type HELB

(c) Humidity (%) 100 Accident type HELB

(d) Radiation (rd) 1 x 10<sup>4</sup> Accident type LOCA

(e) Spray Type NA Accident type NA

\* See WBNNAL3-025 (B45 860401 235)

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 19 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KBJ DATE 8/14/86 R     R      
 ACTUATORS IN THE VALVE ROOMS CHECKED BJ DATE 8/14/86

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.):

None

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (yes/no/NA)? No (Reference Tab B, Sect. P, and Tab C, Sect. 7.0 ).

(7) Subject to submergence (yes/no/NA)? No  
 (Reference Tab C, Sect. 11.0 ).

Identify initiation time and duration of submergence: \_\_\_\_\_

(8) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
<u>*WBNNAL3-025</u>	<u>B45 860401 235</u>
<u>**WBNA2-001</u>	<u>B45 860711 236</u>
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____

\* Radiation Calculation.  
 \*\*Submergence Calculation.

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 20 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KBU DATE 8/14/86  
 ACTUATORS IN THE VALVE ROOMS CHECKED B DATE 8/14/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	"A" 1Hr "B" 100days	16 days	B0003, Sect. 4.5 & Fig.1
Temperature (°F)	325	250	B0003, Fig.1
Pressure (psig)	10.88	25	B0003, Fig.1
Relative Humidity (%)	100	100	B0003, Sect. 2.5.2 & Fig. 1
*Chemical Spray	NA	NA	NA
**Radiation (rd)	$1.18 \times 10^4$	$2.0 \times 10^7$	B0003, Sect. 4.3
Submergence	NA	NA	See Comments on L(2)

\*Includes spray concentration, flowrate, density, duration, and pH.

\*\*Enter 40-year integrated normal dose plus integrated accident dose and specify type.

JUSTIFICATION/COMMENTS 204Mrad motor only.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile</u> <u>Envelopes Specified</u> <u>(Yes/No/NA)</u>	<u>Reference</u>
Temperature	No	B0003, Fig.1
Pressure	Yes	B0003, Fig.1
Relative Humidity	Yes	B0003 Sect. 2.5.2 and Fig. 1
Chemical Spray	NA	NA
Submergence	NA	See Comments

JUSTIFICATION/COMMENTS See Tab C, Section 6.1 for justification of peak temperature and Section 6.2 for justification of post-accident operability time. None of the actuators in this binder are subject to submergence per DNE calculation WBNAPS2-001 (B45 860711 236).

PAGE B-21

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 21 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KBN DATE 8/14/86 R     R      
 ACTUATORS IN THE VALVE ROOMS CHECKED B DATE 8/15/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

(3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, yes/no/NA)

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	--	No-Tab C, Sect. 6.1
Pressure: +10% but no more than 10 psig	10%	Yes-B0003, Fig. 1
Radiation: +10% of accident dose	10%	Yes-B0003, Sect. 4.3 No-Tab C,
Time: +10% (or 1 hour + operating time per NUREG-0588)	--	Sect. 6.1, 6.2
Voltage: +10% of rated value	+8.7%	No-Tab C, Sect. 5
Frequency: +5% of rated value	NA	NA
Environmental Transient: the initial transient and the peak temperature applied twice	2 Dwells	Yes-B0003, Fig. 1
Vibration: +10% added to acceleration	NA	NA-Tab C, Sect. 2

JUSTIFICATION/COMMENTS: Frequency margin - See TAB B, Section J.5 a & b.

---



---



---



---



---



---



---



---

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 22 OF 30  
BINDER TITLE LIMITORQUE COMPUTED KBN DATE 8/4/86 R     R      
ACTUATORS IN THE VALVE ROOMS CHECKED B DATE 8/15/86

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:  
(Reference B0058, Sect. 2.4 ).

JUSTIFICATION/COMMENTS The actuator must be capable of providing  
the required torque and/or thrust to open or close the valve as  
required, and perform within the specified time (See Tab B,  
Sect. J1).

- (2) Did the equipment perform its intended function during the simulated  
design basis accident exposure (yes/no/NA)? Yes  
(Reference B0003, Sect. 5.0 ).

JUSTIFICATION/COMMENTS None

- (3) Did the equipment perform its intended function during the simulated  
post-design basis accident exposure (yes/no/NA)? Yes  
(Reference B0003, Sect. 5 ).

JUSTIFICATION/COMMENTS None

- (4) Did the test demonstrate the operability requirements for the required  
time interval for which the equipment is required to operate  
(yes/no/NA)? No (Reference B0003, Fig 1, 2A and 2B ).

JUSTIFICATION/COMMENTS See Tab C, Section 6.2 for justification  
of post-accident actuator operability.

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly  
addressed and resolved (yes/no/NA)? Yes  
(Reference B0003, Sect. 4.5.2 ).

JUSTIFICATION/COMMENTS Minor problems were experienced during the  
LOCA test. These problems had no effect on overall actuator per-  
formance. See the referenced section of report B0003.



BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 23 OF 30  
BINDER TITLE LIMITORQUE COMPUTED KBN DATE 8/14/86 R     R      
ACTUATORS IN THE VALVE ROOMS CHECKED B DATE 8/15/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the EQC Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS See Tab G. Note, we require that only Exxon Nebula EP-0 or EP-1 be used in the main gear case. This is an inside containment grade lubricant, but the requirement is to prevent mixing greases with different soap bases. Also, we require that if the motors ever be replaced that they be upgraded to the Class H, type RH Reliance motor which has better insulation characteristics.

PAGE B-24

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 24 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KBN DATE 8/14/86 R     R      
 ACTUATORS IN THE VALVE ROOMS CHECKED 12 DATE 8/15/86

0. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
(1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
(2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>NA</u>
(3) Choice of qualification methodology adequately justified?	<u>Yes</u>
(4) If analysis was performed, complete the following:	
(a) Were equipment performance requirements identified?	<u>NA</u>
(b) Were specific features and failure modes and effects analyzed?	<u>NA</u>
(c) Were assumptions and mathematical models used together with appropriate justification for their use?	<u>NA</u>
(d) Were environmental parameters which affect equipment performance identified?	<u>NA</u>
(5) Adequate similarity between equipment and test specimen established?	<u>Yes</u>
(6) Aging degradation evaluated adequately?	<u>Yes</u>
(a) Mechanical and/or cycle aging addressed?	<u>Yes</u>
(b) Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes</u>
(c) Absence of preaging in test/analysis justified?	<u>Yes</u>
(d) Materials susceptible to thermal/radiation aging identified?	<u>Yes</u>

PAGE B-25

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 25 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KBN DATE 8/14/86 R     R      
 ACTUATORS IN THE VALVE ROOMS CHECKED B DATE 8/15/86

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>NA</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>NA</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>NA</u>
(11) Criteria regarding submergence satisfied?	<u>Yes</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

PAGE B-26

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 26 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KBN DATE 8/14/86 R     R      
 ACTUATORS IN THE VALVE ROOMS CHECKED B DATE 8/15/86

O. SUMMARY OF REVIEW (Continued)

- |  | <u>Yes/No/NA</u> |
|--|------------------|
| (15) Criteria regarding functional testing satisfied?  | <u>Yes</u>       |
| (a) Does the test plan/report specify an acceptance criteria for equipment performed?  | <u>Yes</u>       |
| (b) Was an initial base line test done to establish required performance characteristics?  | <u>Yes</u>       |
| (c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? | <u>Yes</u>       |
| (16) Criteria regarding instrument accuracy satisfied?   | <u>NA</u>        |
| (17) Test duration margin (1 hour + function time) satisfied?  | <u>Yes</u>       |
| (a) Is the minimum specified operating time at least 1 hour?   | <u>Yes</u>       |
| (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided?  | <u>NA</u>        |
| (18) Criteria regarding synergistic effects satisfied?   | <u>Yes</u>       |
| (19) Criteria regarding margins satisfied?   | <u>Yes</u>       |
| (20) Maintenance and surveillance requirements adequately identified?  | <u>Yes</u>       |

P. DISCUSSION JUSTIFICATION FOR NOT USING LIMIT SWITCH COMPARTMENT

DRAINS IN LIMITORQUE VALVE ACTUATORS

Concerning the potential problem of steam entering the conduit during a HELB, condensing, and subsequently running down a long vertical conduit run and into the actuator. We have determined that inside containment presents the worst case. Based on this we present the following assumptions and calculations:

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 27 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KBN DATE 8/14/86 R     R      
 ACTUATORS IN THE VALVE ROOMS CHECKED B DATE 8/15/86

1. Assume the conduit is 1 1/2 inch rigid steel conduit conforming to the dimensions listed in TVA Electrical Design Standard DS-El3.1.3, Revision 0.

Weight is 2.51 lbs/ft  
 OD = 1.90  
 ID = 1.61  
 Wall Thickness = 0.29

2. Conduit is 0.5% carbon steel with a specific heat of 0.111  $\frac{\text{BTU}}{\text{lb} \cdot \text{m} \cdot \text{°F}}$ .
3. Peak pressure to be evaluated is 26.8 psia. This is the maximum pressure to be expected in containment following a HELB or LOCA. PEAK PRESSURE, NOT TEMPERATURE is used because steam will condense only as long as the object on which it is condensing remains below the saturation temperature for that particular pressure. Therefore, a conduit will support the condensing of steam during a HELB until the elevated room temperature and the energy liberated by the change in phase from saturated steam to saturated liquid during condensation cause the temperature of the conduit to increase to the saturated steam temperature.
4. Assume the initial conduit temperature is 50 °F, which is the minimum abnormal temperature for containment as taken from drawing 85M 47E235-45. It should be noted that the heat loads generated by plant operation will keep the lower containment temperature higher than 50 °F. Examination of the time/temperature curve on the environmental drawing shows that the containment temperature will be in excess of 200 °F when the ambient pressure reaches 26.7 psia. However, since 50 °F is very easily defendable as a minimum temperature it will be used instead of a temperature more relevant to actual operating conditions.

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 28 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KBN DATE 8/14/86 R     R      
 ACTUATORS IN THE VALVE ROOMS CHECKED B DATE 8/15/86

Appendix B of NUREG-0588 - "Model for Environmental Qualification for loss of coolant accident and main steam line break inside PWR and BWR dry type containment" bases condensate heat transfer to components upon the following equation:

$$q/A = h_{cond}(T_s - T_w)$$

Where:

$q/A$  = Component Surface Heat Flux

$h_{cond}$  = Condensing Heat Transfer Coefficient

$T_s$  = Saturation Temperature

$T_w$  = Component Surface Temperature

If the component surface temperature ( $T_w$ ) is equal to the saturation temperature ( $T_s$ ), the right hand side of the equation will equal zero. Therefore, if no heat is being transferred from the steam, and heat transfer is required for the phase change from steam to condensate, we can conclude that no more condensate will be formed (as stated in assumption No. 3).

The amount of heat required to raise a component from some initial temperature to a higher temperature, in this case the saturation temperature, is:

$$q = M C_p (T_s - T_i)$$

Where:

$M$  = Mass of the Component

$C_p$  = Specific Heat at Constant Pressure

$T_s$  = Saturation Temperature

$T_i$  = Initial Temperature of the Component

For the Conduit:

$$q = 2.51 \frac{lb_m}{ft} * 0.111 \frac{BTU}{lb_m \cdot ^\circ F} * (244-50)^\circ F$$

$$= 54.05 \frac{BTU}{ft}$$

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 29 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KBU DATE 8/14/86 R     R      
 ACTUATORS IN THE VALVE ROOMS CHECKED B DATE 8/15/86

244°F is the saturation temperature for a relative humidity of 100% and a pressure of 26.8 psia (slightly higher than the 26.7 psia containment pressure). This should yield the theoretical maximum amount of condensate heat transfer.

Assuming none of the condensate vaporizes, the mass of the condensate can now be calculated:

$$M_{\text{condensed}} = \frac{q \text{ transferred}}{h_{fg}}$$

Where  $h_{fg}$  = latent heat of vaporization  $\frac{\text{BTU}}{\text{lb}_m}$

$$\text{At } 244^\circ\text{F, } h_{fg} = 949.5 \frac{\text{BTU}}{\text{lb}_m}$$

Note that  $h_{fg}$  increases as temperature decreases. Therefore, the lower temperature in the auxiliary building would yield smaller amounts of condensate.

$$\text{Therefore, } M_{\text{cond}} = \frac{54.05 \frac{\text{BTU}}{\text{ft}}}{949.5 \frac{\text{BTU}}{\text{lb}_m}} = 0.0569 \text{ lb}_m/\text{ft of conduit}$$

This is the amount of condensate that will be formed both inside and outside the conduit. If we consider the conduit to be nonporous, which implies that the condensate on the outside of the conduit will not enter the conduit and increase the mass of the condensate on the inside of the conduit, we can determine the amount of condensate that will be formed inside the conduit. By necessity the external surface area of the conduit is larger than the internal surface area of the conduit, which implies that more than half of condensate formed will be on the outside of the conduit. Comparing the inside and outside surface areas per lineal foot:

$$\frac{D_o}{D_i} = \frac{1.90}{1.61} = 1.18$$

We find that there is 18 percent more surface area outside the conduit on which to form condensate. The mass of condensate inside the conduit ( $m_i$ ) can be determined as follows (mass of condensate is a function of available surface area for formation):

PAGE B-30

BINDER NO. WBNEQ-MOV-002 PLANT WBN UNIT(S) 1 SHEET 30 OF 30  
 BINDER TITLE LIMITORQUE COMPUTED KBW DATE 8/14/86 R     R      
 ACTUATORS IN THE VALVE ROOMS CHECKED 12 DATE 8/15/86

$$\frac{M_o}{M_i} = 1.18 \quad M_o = 1.18 M_i$$

$M_i$

$$M_o + M_i = 0.0569 \text{ lb}_m/\text{ft}$$

$$1.18 M_i + M_i = 0.0569 \text{ lb}_m/\text{ft}$$

$$2.18 M_i = 0.0569 \text{ lb}_m/\text{ft}$$

$$M_i = 0.0261 \text{ lb}_m/\text{ft}$$

At 244°F water has a density of approximately 59.7 lb/ft<sup>3</sup>.

If we use the limit switch compartment for the SMB-000 actuator (11.75 x 9.5 in) we can determine the greatest theoretical depth of accumulated condensate.

$$(11.75 \text{ in}) (9.5 \text{ in}) = 111.625 \text{ in}^2 = 0.7752 \text{ ft}^2$$

NOTE: This would be the smallest limit switch compartment for any of the Limitorque operators in the 10CFR50.49 program at WBNP.

If we consider the longest vertical run of unobstructed conduit to be 30 ft in length we get the following depth of condensate in the limit switch compartment.

$$\frac{0.0261 \text{ lb}/\text{ft} \times 30 \text{ ft} \times 1 \text{ ft}^3/59.7 \text{ lb}}{0.7752 \text{ ft}^2} = 0.0169 \text{ ft} = 0.20 \text{ in}$$

Assuming all conditions to be worst case, that is the largest amount of condensate in the smallest space, we calculate less than 13/64" of condensate in the limit switch compartment, which is not deep enough to submerge any of the electrical contacts on the limit switch. Therefore the conduit configuration at WBNP is deemed to result in no condensate problems for Limitorque MOVs.

PAGE B-31



TAB A - EQUIPMENT IDENTIFICATION MATRIX

EOLS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL NO.	LOCATION			RM/RAD	CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*						
WBN-1-MVOP-026-0241 -B	1-FCV-026-0241 -B	Arm Standpipe Isol Vlv	SB-00	WAS		713'	A28	822598-6	L	A/B	5Min/100D	Vlv must close on a phase A containment isolation signal
WBN-1-MVOP-026-0242 -A	1-FCV-026-0242 -A	Arm Standpipe Isol Vlv	SB-00	WAS		713'	A28	882598-6	L	A/B	5Min/100D	Vlv must close on a phase A containment isolation signal
WBN-1-MVOP-026-0243 -A	1-FCV-026-0243 -A	Reactor coolant pump spray isol vlv	SB-00			713'	A28	822598-6	L	A/B	5Min/100D	Vlv must close on a phase A containment isolation signal
WBN-1-MVOP-026-0244 -B	1-FCV-026-0244 -B	Arm sprinkler sys isol vlv	SB-00	WAS		713'	A28	822598-6	L	A/B	5Min/100D	Vlv must close on a phase A containment isolation signal
WBN-1-MVOP-026-0245 -A	1-FCV-026-0245 -A	Arm sprinkler sys isol vlv cont	SB-00	WAS		713'	A28	822598-6	L	A/B	5Min/100D	Vlv must close on a phase A containment isolation signal
WBN-1-MVOP-062-0063 -A	1-FCV-062-0063 -A	Seal flow return isol vlv	SB-00		283	713'	A28	54114-1	L	A/B	5Min/100D	Vlv is required to close and remain closed after the phase A isolation signal is received and reset

PAGE A-1

\*Floor/Actual Elevation - Actual elevations are documented on Field Verification Sheets found in TAB F.

Preparer/Date [Signature] 9/12/86 R \_\_\_ R \_\_\_ R \_\_\_  
 Checked/Date [Signature] 9/12/86

TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL NO.	LOCATION			CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*					
WBN-1-MVOP-062-0090 -A	1-FCV-062-0090 -A	Charging flow isol vlv	SMB-00	306	713'	A28	54114-1	L	A/B	5Min/100D	For L:vlv is reqd to close and remain closed after SI signal is recvd and reset. CV/A:vlv reqd to be manually closed and remain in that position during mitigation of event. For AF:vlv must be able to close anytime during event to isolate non-qual flow path. RH/A,AB:vlv used to isolate the qualified Boron injection path from the non-qualified path. Gives operator the option of using preferred non-qual path or the qualified path for mitigation of event.
								RH/A	A/B	5D/1M0	
								CV/A	A/B	15Min/1M0	
								AB	A/B	5D/1M0	
								AF	A/B	1M0	
WBN-1-MVOP-062-0091 -B	1-FCV-062-0091 -B	Charging flow isol vlv	SMB-00	306	713'	A28	54114-1	L	A/B	5Min/100D	For L:vlv is reqd to close and remain closed after SI signal is recd and reset. For CV/A:vlv reqd to be manually closed and remain in that position during mitigation of event. For AF:vlv must be able to close anytime during event to isolate non-qual flow path. RH/A,AB:vlv used to isolate the qualified Boron injection path from the non-qualified path. Gives operator the option of using preferred non-qual or the qualified path for mitigation of event.
								RH/A	A/B	5D/1M0	
								CV/A	A/B	15Min/1M0	
								AB	A/B	5D/1M0	
								AF	A/B	1M0	

PAGE A-2

R R R

\*Floor/Actual Elevation - Actual elevations are documented on Field Verification Sheets found in TAB F.

Preparer/Date CPH 9/12/86  
 Checked/Date BJ 9/12/86

TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL NO.	LOCATION			CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*					
WBN-1-MVOP-062-0098 -A	1-FCV-062-0098 -A	Charging pmp 1A-A min flow	SMB-00	UA5	713'	A28	54114-1	L	A	100D	For L:vlv is closed when RCP decreases below 1600 psi. If LOCA is isol,RCP will increase and vlv must open to protect CCP's. For others:vlv is normally open to maintain min recirc flow to prevent CCP burnout.Must remain open during mitigation of event.
								RH/A	B	1Mo	
								CV/A	B	1Mo	
								AB	B	1Mo	
								AF	B	1Mo	
WBN-1-MVOP-062-0099 -A	1-FCV-062-0099 -A	Charging pmp flow 1A-A min flow	SMB-00	UA5	713'	A28	54114-1	L	A	100D	For L and AF:vlv is closed when RCP decrease below 1600 psi.If LOCA is isol,RCP will increase and vlv must open to protect CCP's. For others:vlv is normally open to maintain min recirc flow to prevent CCP burnout.Must remain open during mitigation of event.
								RH/A	B	1MD	
								CV/A	B	1MD	
								AB	B	1MD	
								AF	B	1MD	
WBN-1-MVOP-062-0132 -A	1-LCV-062-0132 -A	VCT outlet isol vlv	SB-00	UA4	713'	A07'	54114-1	L	A/B	5MIN/100D	For L:Close and remain closed upon a safety injection signal. For RH/A, A/B: VLV must remain operable to allow switch over to to RWST.For CV/A:Close and remain closed to isolate VCT.For AF:Maintain operability of flow path.
								RH/A	A	1MD	
								CV/A	A/B	1D/1MD	
								AB	A	1MD	
								AF	A	1MD	
WBN-1-MVOP-062-0133 -B	1-LCV-062-0133 -B	VCT outlet isol vlv level control	SB-00	UA4	713'	A07'	54114-1	L	A/B	5MIN/100D	For L:Close and remain closed upon a safety injection signal. For RH/A, A/B: VLV must remain operable to allow switch over to to RWST.For CV/A:Close and remain closed to isolate VCT.For AF:Maintain operability of flow path.
								RH/A	A	1MD	
								CV/A	A/B	1D/1MD	
								AB	A	1MD	
								AF	A	1MD	

PAGE A-3

R R R

\*Floor/Actual Elevation - Actual elevations are documented on Field Verification Sheets found in TAB F.

Preparer/Date Spur 9/17/86  
 Checked/Date 12 9/17/86

TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL NO.	LOCATION			CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						RM/RAD
WBN-1-MVOP-063-0001 -A	1-FCV-063-0001 -A	RWST to RHR pmp Flowctrl vlv	SB-2			692'	A08	54114-1	L RH/A	A/B A/B	1WK/100D 1WK/1MD	For L:vlv must remain open to permit safety injection. For RH/A vlv must close and remain closed to prevent RWST drn.
WBN-1-MVOP-063-0003 -A	1-FCV-063-0003 -A	SIS pump recirc to RWST vlv	SMB-00	UA5		692'	A08	54114-1	L	A/B	1WK/100D	Valve must close when going frm inj phase to recirc and must stay closed during recirc.
WBN-1-MVOP-063-0004 -B	1-FCV-063-0004 -B	SIS pump 1A-A disch to RWST shutoff vlv	SMB-00	VA5		692'	A13	54114-1	L	A/B	1WK/100D	Vlv must be closed before aligning the SIS for recirc vlv must remain closed to prevent flow from sump into the RWST
WBN-1-MVOP-063-0005 -B	1-FCV-063-0005 -B	RWST to SIS pump flow cont vlv	SB-00	UA5		692'	A08	54114-1	L	A/B	1WK/100D	Vlv must close when going from inj phase to recirc. and must stay closed during recirc
WBN-1-MVOP-063-0006 -B	1-FCV-063-0006 -B	SIS pmp inlet to CVCS chg pmp vlv	SB-00	UA5		692'	A08	54114-1	L	A/B	1WK/100D	Vlv is normally closed and must be operable to provide supply from RHR to SIS during ECCs recirc.
WBN-1-MVOP-063-0007 -A	1-FCV-063-0007 -A	SIS pmp inlet to CVCs chg pmp vlv	SB-00	UA5		692'	A08	54114-1	L	A/B	1WK/100D	Vlv is normally closed and must be operable to provide supply from RHR to SIS during ECCs recirc.
WBN-1-MVOP-063-0008 -A	1-FCV-063-0008 -A	RHR HKA to CVCS chg pmp	SB-00	WA5		713'	A28	54114-1	L RH/A	A/B B	1WK/100D 1MD	L:Open & remain open during recirc to allow suction for SI & CC pumps RH/A:Remain closed to prevent draining RWST

R R R

\*Floor/Actual Elevation - Actual elevations are documented on Field Verification Sheets found in TAB F.

Preparer/Date 9/12/86  
 Checked/Date 9/12/86

PAGE A-4

TAB A - EQUIPMENT IDENTIFICATION MATRIX

EDIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL NO.	LOCATION				CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*	R/RAD					
WBN-1-MVOP-063-0011 -B	1-FCV-063-0011 -B	RHR HIX B to SIS pmp	SB-00	WA4	293	713'	A28	54114-1	L RH/A	A/B B	1WK/100D 1MD	L:Open & remain open during recirc to allow suction for SI & CC pumps RH/A:Remain closed to prevent draining RWST
WBN-1-MVOP-063-0022 -B	1-FCV-063-0022 -B	SIS pmp cold leg injection	SBD-00	WA5		713'	A28	54114-1	L	A/B	1WK/100D	Vlv must switch from cold leg to hot leg recirc.
WBN-1-MVOP-063-0025 -B	1-FCV-063-0025 -B	SIS Boron injection tank shutoff vlv	SBD-00	WA4		713'	A28	54114-1	L RH/A CV/A AB AF/A	A/B B B B B	5MIN/100D 1MD 1MD 1MD 1MD	For L:Vlv must open and remain open after an SI signal.For others vlv must remain closed to maintain RCP seal inj path.
WBN-1-MVOP-063-0026 -A	1-FCV-063-0026 -A	SIS Boron injection tank shutoff vlv	SBD-00	WA4	293	713'	A28	54114-1	L RH/A CV/A AB AF/A	A/B B B B B	5MIN/100D 1MD 1MD 1MD 1MD	For L:Vlv must open and remain open after an SI signal.For others vlv must remain closed to maintain RCP seal inj path.
WBN-1-MVOP-063-0047 -A	1-FCV-063-0047 -A	SIS pmp 1A-A inlet vlv	SBD-00	VA5		692'	A13	54114-1	L	A	100D	Vlv must remain open during both inj and recirc phase of SI, and remain operable to isolate passive failure.
WBN-1-MVOP-063-0048 -B	1-FCV-063-0048 -B	SIS pmp 1B-B inlet vlv	SB-00			692'	A12	54114-1	L	AB	100D	Vlv must remain open during both inj and recirc phase of SI, and remain operable to isolate passive failure.
WBN-1-MVOP-063-0093 -A	1-FCV-063-0093 -A	RHR ED RCS 2 and 3 flow control vlv	SBD-2		285	713'	A28	54114-1	L	A/B	1WK/100D	Vlv is required to operate to transfer from cold leg to hot leg recirc.

PAGE A-5

\*Floor/Actual Elevation - Actual elevations are documented on Field Verification Sheets found in TAB F.

Prepared/Date July 2/7/86 R R R  
 Checked/Date 13 9/12/86

TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL NO.	LOCATION			CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						
WBN-1-MVOP-063-0094 -B	1-FCV-063-0094 -B	RHR to RCS 1 and 4 flow cntl vlv	SBD-2		290	713'	A28	54114-1	L	A/B	1WK/100D	Vlv is required to operate to transfer from cold leg to hot leg recirc.
WBN-1-MVOP-063-0152 -A	1-FCV-063-0152 -A	SIS pmp 1A-A outflow cntl vlv	SB-00	WA5		713'	A28	54114-1	L	A	100D	Vlv must be open for cold leg injection and recirc modes of SI.Vlv is closed for hot leg recirc.
WBN-1-MVOP-063-0153 -B	1-FCV-063-0153 -B	SIS pmp 1B-B outflow cont vlv	SB-00	WA5		713'	A28	54114-1	L	A	100D	Vlv must open for cold leg injection and recirc modes of SI.Vlv is closed for hot leg recirc.
WBN-1-MVOP-063-0156 -A	1-FCV-063-0156 -A	SIS pmp outlet to RCS loop 1 and 3 HL	SBD-00	WA5		713'	A28	54114-1	L	A/B	1WK/100D	Vlv must switch from cold leg to hot leg recirc.
WBN-1-MVOP-063-0157 -B	1-FCV-063-0157 -B	SIS pmp outlet to RCS loop 2 and 4 HL	SBD-00		289	713'	A28	54114-1	L	A/B	1WK/100D	Vlv must switch from cold leg to hot leg recirc.
WBN-1-MVOP-063-0175 -B	1-FCV-063-0175 -B	SIS pmp 1B-B discharge to RWST shutoff vlv	SMB-00	UA5		692'	A12	54114-1	L	A/B	1WK/100D	Vlv must be closed before aligning the SIS for recirc. Vlv must remain closed to prevent flow from sump into the RWST.
WBN-1-MVOP-063-0177 -A	1-FCV-063-0177 -A	SIS pmp inlet to CVCS chg pmp	SB-00	VA5		692'	A08	54114-1	L	A	100D	Vlv is normally open and must remain open to allow proper operation of recirc modes of SI and must remain operable to isolate passive failure of an adjacent component.

PAGE A-6

\*Floor/Actual Elevation - Actual elevations are documented on Field Verification Sheets found in TAB F.

Prepared/Date July 9/9/86 R R R  
 Checked/Date 12 9/2/86

TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL NO.	LOCATION			CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*					
WBN-1-MVOP-067-0083 -A	1-FCV-067-0083 -A	Lower QNMT A cooler supply isol vlv	SMB-000		008	720'	ANN	83015	L A/B RH/C A/B CV/C A/B FW/C A/B MS/C A/B	5MIN/100D 5MIN/1MD 5MIN/1MD 5MIN/100D 5MIN/100D	Vlv must close and remain closed after a phase B isol signal
WBN-1-MVOP-067-0088 -B	1-FCV-067-0088 -B	Lower QNMT A clrs D ISCH isol vlv IC	SMB-000		010	720'	ANN	83015	L A/B RH/C A/B CV/C A/B FW/C A/B MS/C A/B	5MIN/100D 5MIN/1MD 5MIN/1MD 5MIN/100D 5MIN/100D	Vlv must close and stay closed on a phase B isolation signal
WBN-1-MVOP-067-0091 -A	1-FCV-067-0091 -A	Lower QNMT C clrs supply isol vlv	SMB-000		184	720'	ANN	83015	L A/B RH/C A/B CV/C A/B FW/C A/B MS/C A/B	5MIN/100D 5MIN/1MD 5MIN/1MD 5MIN/100D 5MIN/100D	Vlv must close and stay closed on a phase B isolation signal
WBN-1-MVOP-067-0096 -B	1-FCV-067-0096 -B	Lower QNMT C coolers disch isol V	SMB-000		190	720'	ANN	83015	L A/B RH/C A/B CV/C A/B FW/C A/B MS/C A/B	5MIN/100D 5MIN/100D 5MIN/100D 5MIN/100D 5MIN/100D	Vlv must close and remain closed on a phase B isolation signal
WBN-1-MVOP-067-0099 -B	1-FCV-067-0099 -B	Lower QNMT B clrs supply isol vlv	SMB-000		170	720'	ANN	83015	L A/B RH/C A/B CV/C A/B FW/C A/B MS/C A/B	5MIN/100D 5MIN/1MD 5MIN/1MD 5MIN/100D 5MIN/100D	Vlv must close and remain closed after a phase B isol signal
WBN-1-MVOP-067-0104 -A	1-FCV-067-0104 -A	Lower QNMT B clrs disch isol vlv OC	SMB-000		170	720'	ANN	83015	L A/B RH/C A/B CV/C A/B FW/C A/B MS/C A/B	5MIN/100D 5MIN/1MD 5MIN/1MD 5MIN/100D 5MIN/100D	Vlv must close and remain closed on a phase B isol signal

PAGE A-7

R R R

\*Floor/Actual Elevation - Actual elevations are documented on Field Verification Sheets found in TAB F.

Preparer/Date [Signature]  
 Checked/Date 9/12/86

TAB A - EQUIPMENT IDENTIFICATION MATRIX

EOLIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL NO.	LOCATION				CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*	R/R/RAD					
WBN-1-MVOP-067-0107	-B 1-FCV-067-0107	-B Lower QNMT D clrs supply isol vlv	SMB-000		000	720'	ANN	83015	L	A/B	5MIN/100D	Vlv must close and remain closed after a phase B isol signal
									RH/C	A/B	5MIN/1MD	
									CV/C	A/B	5MIN/1MD	
									FW/C	A/B	5MIN/100D	
									MS/C	A/B	5MIN/100D	
WBN-1-MVOP-067-0112	-A 1-FCV-067-0112	-A Lower QNMT D clrs disch isol vlv OC	SMB-000		350	720'	ANN	83015	L	A/B	5MIN/100D	Vlv must close and stay closed on a phase B isol signal
									RH/C	A/B	5MIN/1MD	
									CV/C	A/B	5MIN/1MD	
									FW/C	A/B	5MIN/100D	
									MS/C	A/B	5MIN/100D	
WBN-1-MVOP-067-0123	-B 1-FCV-067-0123	-B QNMT spray HIX B supply cntl vlv	SMB-000	UA5		737'	A01	83015	L	A	30D	Vlv must open to provide water to QNMT spray HIX
WBN-2-MVOP-067-0123	-B 2-FCV-067-0123	-B QNMT spray HIX B supply cntl vlv	SMB-000	UA13		737'	A01	83015	L	B	100D	Vlv is normally closed and must remain closed during mitigation of event
WBN-1-MVOP-067-0124	-B 1-FCV-067-0124	-B QNMT spray HIX B discharge vlv	SMB-000	UA4		713'	A06	83015	L	A	30D	Vlv must open to provide water to QNMT spray HIX
WBN-2-MVOP-067-0124	-B 2-FCV-067-0124	-B QNMT spray HIX B discharge vlv	SMB-000	VA13		713'	A19	83015	L	B	100D	Vlv normally closed and must remain closed during mitigation event
WBN-1-MVOP-067-0125	-A 1-FCV-067-0125	-A QNMT spray HIX A supply cntl vlv	SMB-000	UA4		737'	A01	83015	L	A	30D	Vlv must open to provide water to QNMT spray HIX
WBN-2-MVOP-067-0125	-A 2-FCV-067-0125	-A QNMT spray HIX A supply cntrol vlv	SMB-000	UA11		737'	A01	83015	L	B	100D	Vlv normally closed and must remain closed during mitigation of event.

PAGE A-8

R R R

\*Floor/Actual Elevation - Actual elevations are documented on Field Verification Sheets found in TAB F.

Preparer/Date [Signature] 9/12/86  
 Checked/Date [Signature] 9/12/86



TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL NO.	LOCATION			CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*					
WBN-1-MVOP-067-0126	-A 1-FCV-067-0126 -A	QNTMT spray HIX A disch vlv	SMB-000			713'	A06	83015	L A	30D	Vlv must open to provide water to QNTMT spray HIX
WBN-2-MVOP-067-0126	-A 2-FCV-067-0126 -A	QNTMT spray HIX A disch vlv	SMB-000	VAL3		713'	A19	83015	L B	100D	Vlv normally closed and must remain closed during mitigation of event.
WBN-1-MVOP-067-0130	-A 1-FCV-067-0130 -A	Upper QNTMT vent clr A supply isol vlv	SMB-000		300	796'	ANN	824589-1	L A/B RH/C A/B CV/C A/B FW/C A/B MS/C A/B	5MIN/100D 5MIN/1MD 1HR/1MD 5MIN/100D 5MIN/100D	Vlv must close and remain closed on a QNTMT isol signal
WBN-1-MVOP-067-0131	-B 1-FCV-067-0131 -B	Upper QNTMT vent clr A isol vlv OC	SMB-000		304	795'	ANN	824589-1	L A/B RH/C A/B CV/C A/B FW/C A/B MS/C A/B	5MIN/100D 5MIN/1MD 1HR/1MD 5MIN/100D 5MIN/100D	Vlv must function to isolate flow to cooler upon receipt of A phase B QNTMT isol signal
WBN-1-MVOP-067-0133	-A 1-FCV-067-0133 -A	Upper QNTMT vent clr C supply isol vlv	SMB-000		301	798'	ANN	824589-1	L A/B RH/C A/B CV/C A/B FW/C A/B MS/C A/B	5MIN/100D 5MIN/1MD 1HR/1MD 5MIN/100D 5MIN/100D	Vlv must close and remain closed on a QNTMT isol signal
WBN-1-MVOP-067-0134	-B 1-FCV-067-0134 -B	Upper QNTMT clr A disch isol vlv	SMB-000		315	800'	ANN	824589-1	L A/B RH/C A/B CV/C A/B FW/C A/B MS/C A/B	5MIN/100D 5MIN/1MD 1HR/1MD 5MIN/100D 5MIN/100D	Vlv must function to isolate flow to cooler upon receipt of a phase B containment isolation signal
WBN-1-MVOP-067-0138	-B 1-FCV-067-0138 -B	Upper QNTMT vent clr B supply isol vlv	SMB-000		310	797'	ANN	824589-1	L A/B RH/C A/B CV/C A/B FW/C A/B MS/C A/B	5MIN/100D 5MIN/100D 5MIN/100D 5MIN/100D 5MIN/100D	Vlv must close and remain closed on a QNTMT isol signal

PAGE A-9

R R R

\*Floor/Actual Elevation - Actual elevations are documented on Field Verification Sheets found in TAB F.

Preparer/Date Justin J. [Signature]  
 Checked/Date 12/9/14/86

TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL NO.	LOCATION				CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*	RW/RAD					
WBN-1-MVOP-067-0139 -A	1-FCV-067-0139 -A	Upper CNVMT vent clr B isol vlv OC	SMB-000		308	798'	ANN	824589-1	L	A/B	5MIN/100D	Vlv must close and remain closed on a CNVMT isol signal
									RR/C	A/B	15MIN/1MD	
									CV/C	A/B	1HR/1MD	
									FW/C	A/B	5MIN/100D	
									MS/C	A/B	5MIN/100D	
WBN-1-MVOP-067-0141 -B	1-FCV-067-0141 -B	Upper CNVMT vent clr D supply isol vlv	SMB-000		310	794'	ANN	824589-1	L	A/B	5MIN/100D	Vlv must close and remain closed on a CNVMT isol signal
									RR/C	A/B	15MIN/1MD	
									CV/C	A/B	1HR/1MD	
									FW/C	A/B	5MIN/100D	
									MS/C	A/B	5MIN/100D	
WBN-1-MVOP-067-0142 -A	1-FCV-067-0142 -A	Upper CNVMT vent clr D isol vlv OC	SMB-000		312	793'	ANN	824589-1	L	A/B	5MIN/100D	Vlv must function to isolate flow to cooler upon receipt of a phase B CNVMT isol signal
									RR/C	A/B	5MIN/1MD	
									CV/C	A/B	5MIN/1MD	
									FW/C	A/B	5MIN/100D	
									MS/C	A/B	5MIN/100D	
WBN-1-MVOP-070-0090 -A	1-FCV-070-0090 -A	RCP therm bar ret CNVMT isol vlv	SMB-00	WAS		713'	A28	83015	L	A/B	5MIN/100D	Vlv must close and remain closed after a phase B isol is initiated
WBN-1-MVOP-070-0092 -A	1-FCV-070-0092 -A	RCP oil clr ret CNVMT isol vlv	SMB-000	WAS		713'	A28	83015	L	A/B	5MIN/100D	Vlv must close and remain closed on a phase B isolation signal
WBN-1-MVOP-070-0134 -B	1-FCV-070-0134 -B	RCP therm bar CNVMT isol vlv	SMB-000	WAS		737'	A05	83015	L	A/B	5MIN/100D	Vlv must close and remain closed after a phase B isolation signal is initiated
WBN-1-MVOP-070-0140 -B	1-FCV-070-0140 -B	RCP oil clr hdr CNVMT isol vlv	SMB-000	WAS		713'	A28	83015	L	A/B	5MIN/100D	Vlv must close and remain closed on a phase B isol signal

PAGE A-10

R R R

\*Floor/Actual Elevation - Actual elevations are documented on Field  
 Verification Sheets found in TAB F.

Preparer/Date 9/1/86  
 Checked/Date 9/1/86

TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL NO.	LOCATION			CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						
WBN-1-MVOP-070-0143 -A	1-FCV-070-0143 -A	Excess let downs HEX QNMT inlet isol vlv	SMB-000	WA4		713'	A28	83015	L	A/B	5MIN/100D	Vlv must close and remain closed on a phase A isolation signal
WBN-1-MVOP-070-0183 -A	1-FCV-070-0183 -A	Sample HEX hdr outlet valve	SMB-000	WA5		713'	A13	83015	L	A	100D	Valve is required to be operable to isolate non-qual piping in the event of a CCS line break
									RH/A	A	1MD	
									CV/A	A	1MD	
									AB	A	1MD	
									AF/A	A	1MD	
WBN-0-MVOP-070-0206 -B	0-FCV-070-0206 -B	CDWE bldg return	SMB-000	VA9		692'	A01	822484-1	L	A/B	1WK/100D	For L:Vlv must be operable to realign the CCS to post accident configuration. For others vlv is reqd to function to protect against break in non-q piping in CDWE bldg
									RH/A	A	1MD	
									CV/A	A	1MD	
									AB	A	1MD	
									AF/A	A	1MD	
WBN-1-MVOP-070-0207 -B	1-FCV-070-0207 -B	Cond demin waste EVAP bldg supply	SMB-000	UA9		737'	A01	822484-1	L	A/B	1WK/100D	For L:Vlv must be operable to realign the CCS to the post accident configuration. For others vlv must be operable to isolate the CDWE
									RH/A	A	1MD	
									CV/A	A	1MD	
									AB	A	1MD	
									AF	A	1MD	
WBN-2-MVOP-070-0207 -B	2-FCV-070-0207 -B	Cond demin waste EVAP bldg supply	SMB-000	UA9		737'	A01	822484-1	L	A/B	1WK/100D	For L:Vlv must be operable to realign the CCS to the post accident configuration. For others vlv must be operable to isolate the CDWE
									RH/A	A	1MD	
									CV/A	A	1MD	
									AB	A	1MD	
									AF	A	1MD	
WBN-0-MVOP-070-0208 -A	0-FCV-070-0208 -A	Cond demin waste EVAP bldg supply	SMB-000	UA9		737'	A01	822484-1	L	A/B	1WK/100D	For L:Vlv must be operable to realign the CCS to the post accident configuration. For others: vlv is required to protect against a break in non-q piping in the CDWE bldg
									RH/A	A	1MD	
									CV/A	A	1MD	
									AB	A	1MD	
									AF/A	A	1MD	

PAGE A-11

\*Floor/Actual Elevation - Actual elevations are documented on Field Verification Sheets found in TAB F.

Prepared/Date 2/9/86 R R R  
 Checked/Date 1/8 9/12/86 \_\_\_\_\_

TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL NO.	LOCATION			CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						
WBN-1-MVOP-070-0215 -A	1-FCV-070-0215 -A	Sample RK inlet isol vlv		WA7		713'	AL3				Vlv is required to operate to isol non-q piping in event of CSC line break	
WBN-1-MVOP-072-0002 -B	1-FCV-072-0002 -B	QNMT spray hdr B isol vlv	SB-0	VA4		737'	A05	54114-1	L	A/B	5MIN/30D	Vlv must be open and remain open during the mitigation of the event to permit flow to the containment spray headers
WBN-1-MVOP-072-0013 -B	1-FCV-072-0013 -B	QNMT spray pmp B	SMB-000	VA5		692'	A08	83015	L	A	30D	Vlv must remain operable to allow minimum recirc to prevent pump burnout
WBN-1-MVOP-072-0021 -B	1-FCV-072-0021 -B	RWST to spray hdr B flow control vlv	SB-0	TA5		676'	A16	54114-1	L	A/B	1WK/100D	For L:Vlv is normally open must be manually closed to transfer suction to the containment sump for the recirc mode. For others: Vlv must remain operable to prevent the RWST from draining to the QNMT sump in event of single failure of FCV-72-44 or FCV-72-45.
WBN-1-MVOP-072-0022 -A	1-FCV-072-0022 -A	RWST to spray hdr A flow control vlv	SB-0	UA5		676'	A16	54114-1	L	A/B	1WK/100D	For L:Vlv is normally open must be manually closed to transfer suction to the containment sump for the recirc mode. For others: Vlv must remain operable to prevent the RWST from draining to the QNMT sump in event of single failure of FCV-72-44 or FCV-72-45.

PAGE A-12

\*Floor/Actual Elevation - Actual elevations are documented on Field Verification Sheets found in TAB F.

Prepared/Date July 9/9/86 \_\_\_\_\_ \_\_\_\_\_  
 Checked/Date 12 9/14/86 \_\_\_\_\_ \_\_\_\_\_

TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL NO.	LOCATION				CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COLUMN	AZ	ELEV*	R/R/RAD					
WBN-1-MVOP-072-0034 -A	1-FCV-072-0034 -A	QNTMT spray pump A recirc control vlv	SMB-000	VA5		692'	A08	83015	L	A	30D	Vlv must remain operable to allow minimum recirc to prevent pump burnout
WBN-1-MVOP-072-0039 -A	1-FCV-072-0039 -A	QNTMT spray hdr A isol vlv	SB-0	WA4		737'	A05	54114-1	L	A	5MIN/30D	Vlv must be open and remain open during the mitigation of the event to permit flow to the containment spray headers
WBN-1-MVOP-072-0040 -A	1-FCV-072-0040 -A	RHR spray hdr A isol vlv	SB-00	WA5		713'	A28	54114-1	L	A	30D	Vlv initially closed during a LOCA may be manually opened to assist CS system.
WBN-1-MVOP-072-0041 -B	1-FCV-072-0041 -B	RHR spray hdr B isol vlv	SB-00	VA5		713'	A28	54114-1	L	A	30D	Vlv initially closed during a LOCA may be manually opened to assist CS system.
WBN-1-MVOP-072-0044 -A	1-FCV-072-0044 -A	QNTMT sump to hdr A flow control vlv	SB-0	VA4		692'	RSVR	54114-1	L	A	100D	For L:Vlv closed when QNTMT spray pumps are taking suction from RWST. Must be opened to take suction from sump. Must remain operable for duration of event. For others: Vlv must not fail in a manner that would drain RWST.
									RH/A	B	30D	
									CV/A	B	30D	
									AB	B	30D	
WBN-1-MVOP-072-0045 -B	1-FCV-072-0045 -B	QNTMT sump to hdr B flow control vlv	SB-0	VA3		692'	RSVR	54114-1	L	A	100D	For L:Vlv closed when QNTMT spray pumps are taking suction from RWST. Must be opened to take suction from sump. Must remain operable for duration of event. For others: Vlv must not fail in a manner that would drain RWST.
									RH/A	B	30D	
									CV/A	B	30D	
									AB	B	30D	

PAGE A-13

\*Floor/Actual Elevation - Actual elevations are documented on Field Verification Sheets found in TAB F.

Preparer/Date July 9/9/86 R R R  
 Checked/Date 12 9/14/86 \_\_\_\_\_

TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL NO.	LOCATION			CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						
WBN-1-MWOP-074-0012 -A	1-FCV-074-0012 -A	RHR pmp A-A mini flow vlv	SMB-000	VA5		676'	AL6	54114-1	L	A	100D	Vlv has safety reqmt to open for pmp protection during ECCS oper. When RCS press is above pmp shut off head and a safety reqmt to close to allow the RHRs to meet its flow reqmt.
WBN-1-MWOP-074-0024 -B	1-FCV-074-0024 -B	RHR pmp B-B mini flow vlv	SMB-000	UA5		676'	AL6	54114-1	L	A	100D	Vlv has safety reqmt to open for pmp protection during ECCS oper. When RCS press is above pmp shut off head and a safety reqmt to close to allow the RHRs to meet its flow reqmt.
WBN-1-MWOP-074-0033 -A	1-FCV-074-0033 -A	RHR ht exh A bypass	SB-00	WA5		713'	AL2	54114-1	L	A	100D	Vlv normally open to assure proper alignment for inj. phase of ECCS operation. Vlv must remain operable to switch over from cold leg to hot leg recirc and protect against passive failures.
WBN-1-MWOP-074-0035 -B	1-FCV-074-0035 -B	RHR ht exh B bypass cross tie vlv	SB-00	VA7		713'	AL1	54114-1	L	A	100D	Vlv normally open to assure proper alignment for inj. phase of ECCS operation. Vlv must remain operable to switch over from cold leg to hot leg recirc and protect against passive failures.

PAGE A-14

Category and operating times were taken from the following documents:

- System 3 WBNSG4-005 R8 B45 860411 219 System 67 WBNSG4-016 R8 B45 860320 218
- System 26 WBNSG4-007 R3 B45 851121 218 System 70 WBNSG4-018 R8 B45 860307 219
- System 62 WBNSG4-013 R7 B45 860320 223 System 72 WBNSG4-019 R3 B45 860121 225
- System 63 WBNSG4-014 R9 B45 860314 219 System 74 WBNSG4-020 R6 B45 860307 218

\*Floor/Actual Elevation - Actual elevations are documented on Field Verification Sheets found in TAB F.

Preparer/Date [Signature] 9/9/86 R R R  
 Checked/Date [Signature] 9/2/86 \_\_\_\_\_

# CHECKLIST

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 1 OF 1  
 BINDER TITLE LIMITORQUE COMPUTED J. J. [Signature] DATE 8/22/86  
 ACTUATORS OUTSIDE CONTAINMENT WITH CLASS B MOTORS CHECKED B DATE 8/22/86

INTRODUCTION TO TAB B

Use of Test Reports

<u>Report No.</u>	<u>Purpose in Binder</u>
B0003	Main Test Report for Qualification
B0058	Summary Report of Limitorque EQ Testing and EQ Philosophy
B0212	Aging of General Purpose Phenolic Material and Low Level Vibration Testing
B0119	Qualification of Marathon Terminal Blocks
B0080	Thermal Aging of Class B Motors
600198	Used to Show Actuators do not Require Conduit Sealing



BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 1 OF 28  
BINDER TITLE LIMITORQUE COMPUTED JW DATE 9/9/86 R     R      
ACTUATORS OUTSIDE CONTAINMENT WITH CHECKED B DATE 9/12/86  
CLASS B MOTORS

A. DOCUMENTATION

Equipment Description Motor Operated Valve Actuators  
Vendor/Manufacturer Limitorque  
Equipment Model No.(s) See Tab A

QUALIFICATION REPORTS

- (1) Title/Number/Revision Limitorque Valve Actua- RIMS B70851119105  
tors for Outside Containment #B0003 DATE 6-2-76  
(2) Title/Number/Revision Limitorque Valve Actua- RIMS NEB820421203  
tor Qualification for Nuclear Services #B0058 DATE 1-11-80

OTHER (ANALYSIS, VENDOR DATA, ETC.)

- 3) Valve ID, Test Report, Contract Cross Reference  
4) MEB 811215 508  
5) MEB 820604 547

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 1A OF 28  
BINDER TITLE LIMITORQUE COMPUTED JCF DATE 9/12/86  
ACTUATORS OUTSIDE CONTAINMENT WITH CHECKED 12 DATE 9/12/86  
CLASS B MOTORS

OTHER (ANALYSIS, VENDOR DATA, ETC.) Continued

- 6) MEB 841212 503
  - 7) B70 850910 004
  - 8) B70 850925 012
  - 9) B70 850926 001
  - 10) B70 851107 022
  - 11) B70 851213 001 - Limitorque Test Report B0080 Class B Motor  
Effect of Thermal Aging on Locked Rotor Performance
  - 12) Limitorque Test Report B0212
  - 13) Limitorque Test Report B0119
  - 14) WAD-28 (AD-67)
  - 15) WAD-27 (AD-74)
  - 16) WAC-101
  - 17) WAC-111
  - 18) WAC-130
  - 19) WAC-131
  - 20) WCAP-7410-L
  - 21) B71 860623 004
  - 22) B70 851107 021
  - 23) B71 860806 004
- Copies of the above reports and documents can be found in TABs  
D and E.

PAGE B-3

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 1B OF 28  
BINDER TITLE LIMITORQUE COMPUTED Jws DATE 9/9/86 R     R      
ACTUATORS OUTSIDE CONTAINMENT WITH CHECKED B DATE 9/12/86  
CLASS B MOTORS

Other calculations used are:

24) WBNNAL3-025 (B45 860328 236)

25) WBNNAL3-026 (B45 860328 237)

26) NEB86052 (#4) (B45 860527 265)

27) GENNAL3-001 (B45 851117 235)

28) WBNNAL3-004 (B45 860205 235)

PAGE B-4

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 2 OF 28  
 BINDER TITLE LIMITORQUE COMPUTED 9/12/86 DATE 9/12/86 R     R      
ACTUATORS OUTSIDE CONTAINMENT WITH CHECKED 12 DATE 9/12/86  
CLASS B MOTORS

B. CONCLUSION OF REVIEW (Check only one block)

- Equipment Qualified
- Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule
- Equipment Qualification Not Established by Documentation
- Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES \_\_\_\_\_

Degraded voltage. 1-FCV-70-215 is a Rotork actuator. Final  
response to NRC IE Bulletin 85-03. Replace internal control cable.\*

COMMENTS/RECOMMENDATIONS \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

\*Replace nylon crimped motor lead connector with nuclear Raychem  
connector. Disconnect limit switch and motor compartment heaters.  
Motor on valve operator 1-FCV-62-99 must be replaced.

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET<sup>3</sup> OF<sup>28</sup>

BINDER TITLE LIMITORQUE COMPUTED John DATE 8/22/86 R     R    

ACTUATORS OUTSIDE CONTAINMENT WITH     CHECKED B DATE 8/22/86  
CLASS B MOTORS

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

- Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)
  
- X   Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET  
The Limitorque Environmental Qualification program was conducted per IEEE-382 (1972), "IEEE Guide for Type Test of Class 1 Electric Valve Operators for Nuclear Power Generating Stations" and meets the requirements of IEEE-323(1974) as they apply to valve actuators (#B0058, Section 2.1).  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 4 OF 8  
BINDER TITLE LIMITORQUE COMPUTED JWH DATE 8/22/86 R     R      
ACTUATORS OUTSIDE CONTAINMENT WITH CHECKED Bj DATE 8/22/86  
CLASS B MOTORS

D. QUALIFICATION METHODOLOGY (Check only one block)

- Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- X  Test of Similar Items with Supporting Analysis
- Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS The Limitorque qualification program was  
conducted to encompass the entire family of actuators - SMB, SB,  
SBD, and SMB/HBC in all available unit sizes (SMB-000 to SMB-5).  
This was accomplished by type testing - see Tab C, Section 1.  
Tab E, Attachment 1 identifies the actuator plant ID number, the  
Limitorque shop order number, the actuator serial number, and the  
documentation which establishes traceability to the applicable test  
report.

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 5 OF 28  
 BINDER TITLE LIMITORQUE COMPUTED July DATE 8/22/86 R     R      
 ACTUATORS OUTSIDE CONTAINMENT WITH CLASS B MOTORS CHECKED 12 DATE 8/22/86

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? No

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	Motor Operated <u>Valve Actuator</u>	Motor Operated <u>Valve Actuator</u>	B0003, <u>Sect. 3.0</u>
(2) Manufacturer	<u>Limitorque</u>	<u>Limitorque</u>	B0003, <u>Sect. 3.0</u>
(3) Model Number(s)	<u>See Tab A</u>	<u>SMB-0</u>	B0003, <u>Sect. 3.0</u>
	_____	_____	_____
	_____	_____	_____
(4) Serial Number(s)	<u>See Tab E</u>	<u>195004</u>	B0003, <u>Sect. 3.0</u>
	_____	_____	_____
Order Number(s)	<u>See Tab E</u>	<u>600461</u>	B0003, <u>Sect. 3.0</u>
	_____	_____	_____
(5) Identify Component- Unique checksheet attached:	<u>None</u>	_____	_____

JUSTIFICATION/COMMENTS See Tab C, Section 1.

(4 and 5) Tab E, Attachment 1, information was taken from Field

Verification Sheet in Tab F.

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 6 OF 8  
 BINDER TITLE LIMITORQUE COMPUTED JWS DATE 8/22/84 R     R      
 ACTUATORS OUTSIDE CONTAINMENT WITH     CHECKED B DATE 8/22/84  
 CLASS B MOTORS

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the test report and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if No, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>NA</u>	<u>NA</u>	<u>NA</u>
External Process Connections	<u>NA</u>	<u>NA</u>	<u>NA</u>
Electrical Connections	<u>NA</u>	<u>(See NA Comment)</u>	<u>NA</u>
Conduit Seals	<u>None</u>	<u>No</u>	<u>B0058 Sect 3.2.3 and 4.1.2 See Tab B, Sect P B0058 Sect 3.2.3 &amp; 4.1.2</u>
Connector Seals	<u>None</u>	<u>No</u>	<u>See Tab G, Sect A1</u>
Orientation	<u>Motor horizontal with limit switch compartment up</u>	<u>No</u>	<u>See Tab G, Sect A1</u>
Physical Configuration	<u>NA</u>	<u>NA</u>	<u>NA</u>
Other	<u>NA</u>	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS Report B0003 makes no mention of any specific installation interface requirements; however, B0058 Sections 3.2.3 and 4.1.2 concludes that sealing of the actuators (i.e. conduit seals, seals and gaskets) are of no importance for the qualification of the actuators. See Tab C, Section 3.0. See Tab C, Section 7, concerning orientation of the actuator. See Tab C, Section 8.2, concerning electrical connection of the actuator. For electrical connections, a qualified cable should be used.



BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 7 OF 28  
 BINDER TITLE LIMITORQUE COMPUTED [Signature] DATE 9/9/86 R     R      
ACTUATORS OUTSIDE CONTAINMENT WITH CHECKED [Signature] DATE 9/12/86  
CLASS B MOTORS

G. TEST SEQUENCE

(1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>No</u>	<u>See Comments B0003, Fig. 2A and 2B</u>
(b) Baseline performance measurements taken	<u>Yes</u>	
(c) Equipment aged:		
Thermal	<u>Yes</u>	<u>B0003, Sect. 4.1</u>
Radiation	<u>Yes</u>	<u>B0003, Sect. 4.3</u>
Wear	<u>Yes</u>	<u>B0003, Sect. 4.2</u>
(d) Vibration/seismic testing conducted	<u>Yes-Seismic</u>	<u>B0003, Sect. 4.4</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	<u>B0003, Sect. 4.5.1</u>
(f) Post-DBE exposure	<u>Yes</u>	<u>B0003, Sect. 4.5.1</u>
(g) Final inspection and disassembly	<u>Yes</u>	<u>B0003, Sect. 4.5.3</u>

- (2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes
- (3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes (Reference B0003, Appendix I \_).

JUSTIFICATION/COMMENTS (a) There is no evidence in the report that the equipment was inspected prior to start of the test. However, pre-inspection is not a requirement of IEEE 323 (1974). (b) Baseline performance measurements were taken at time 0. They are within nominal and are acceptable. (d) Low level vibration is addressed in Tab C, Section 2.0

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 8 OF 28  
 BINDER TITLE LIMITORQUE COMPUTED JW DATE 8/22/86 R     R      
 ACTUATORS OUTSIDE CONTAINMENT WITH CLASS B MOTORS CHECKED B DATE 8/22/86

H. AGING

- (1) Was aging considered in the qualification program (Yes/no/NA)? Yes (Reference B0058, Sect. 3.0).

JUSTIFICATION/COMMENTS None

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>B0003, Sect. 4.1.4</u> <u>B0058, Sect. 3.2</u>
Radiation exposure	<u>Yes</u>	<u>B0058, Sect. 3.4</u> <u>B0003, Sect. 4.3</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>B0058, Sect. 2.1</u> <u>B0058, Sect. 3.3</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	<u>B0003, Sect. 4.2</u>

JUSTIFICATION/COMMENTS None

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? NA (Reference NA).

JUSTIFICATION/COMMENTS No known synergistic effects.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program (yes/no/NA)? Yes (Reference B0003, Sect. 4.1), B0058, Sect. 3.2).

JUSTIFICATION/COMMENTS See Tab C, Section 8.

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 9 OF 28  
 BINDER TITLE LIMITORQUE COMPUTED July DATE 9/12/86 R    R     
ACTUATORS OUTSIDE CONTAINMENT WITH CHECKED 13 DATE 9/12/86  
CLASS B MOTORS

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes (Reference: B0058, Sect. 3.2 ).

JUSTIFICATION/COMMENTS See Tab C, Section 8.

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference B0058, Sect. 3.2 ).

JUSTIFICATION/COMMENTS See Tab C, Section 8.

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference B0003, Sect.4.1 B0058, Sect.3.2.1.1 ).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
<u>Temperature</u>	<u>110°F</u>	<u>See Comments</u>	<u>See Comments</u>
<u>Time</u>	<u>40 years</u>	<u>See Comments</u>	<u>See Comments</u>

JUSTIFICATION/COMMENTS See Tab C, Section 8. All materials which are potentially susceptible to aging have qualified or expected life of greater than 40 years.

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference B0058, Sect. 3.2 ).

JUSTIFICATION/COMMENTS See Tab C, Section 8.

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? NA (Reference NA ).

JUSTIFICATION/COMMENTS See Tab C, Section 8.

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 10 OF 28  
BINDER TITLE LIMITORQUE COMPUTED Just DATE 8/22/86  
ACTUATORS OUTSIDE CONTAINMENT WITH CLASS B MOTORS CHECKED B DATE 8/22/86

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? Yes (Reference B0058, Sect. 3.2.1.3 ).

JUSTIFICATION/COMMENTS See Tab C, Section 8. Regression analysis provided for Class "B" insulated motor.

- (h) Was the equipment operated during the thermal aging (yes/no/NA)? Yes (Reference B0003, Sect. 4.1 ).

JUSTIFICATION/COMMENTS None

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (yes/no/NA)? Yes (Reference B0003, Sect. 2.3 ), App. II, and B0058, Sect. 3.4 ).

JUSTIFICATION/COMMENTS None

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (yes/no/NA)? NA (Reference B0058, Sect. 3.4 ).

JUSTIFICATION/COMMENTS Limitorque concluded after several tests that "there was no noticeable detrimental effect of radiation on any component in any of the test sequence or radiation level employed".

- (c) Was the basis for radiation aging exposure identified in the qualification program (yes/no/NA)? Yes (Reference B0058, Sect. 3.4 ).

JUSTIFICATION/COMMENTS None

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 11 OF 28  
 BINDER TITLE LIMITORQUE COMPUTED JS DATE 8/22/86 R     R      
 ACTUATORS OUTSIDE CONTAINMENT WITH CLASS B MOTORS CHECKED B DATE 8/22/86

H. AGING (Continued)

- (d) Is the radiation test exposure dose and dose rate acceptable (yes/no/NA)? Yes (Reference B0003, Sect. 2.3, 4.3 ) and App. II

Plant normal ambient radiation dose (rd) 1.8 x 10<sup>7</sup>  
 Test exposure dose (rd) 2.04 x 10<sup>8</sup> - Motor Only  
2 x 10<sup>7</sup> - Other-See Comments  
 Test exposure dose rate (rd/hr) 1.0 x 10<sup>6</sup>  
 Test exposure source type (e.g., Co-60 gamma) Co-60 gamma

JUSTIFICATION/COMMENTS See Tab C, Section 9.0

(6) Vibration (non-seismic) Aging:

- (a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference B0058, Sect. 2.1 ).

JUSTIFICATION/COMMENTS Non-seismic (low level) vibration was considered but determined to be of no consequence based on experience. See Tab C, Section 2.0.

- (b) Was the basis for vibration aging identified and justified in the qualification program (yes/no/NA)? NA (Reference B0058, Sect. 2.1 ).

JUSTIFICATION/COMMENTS See Tab C, Section 2.0 for justification of omission of non-seismic vibration aging.

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference B0003, Sect. 4.1.5 and 4.2 ).

JUSTIFICATION/COMMENTS The actuator was cycled (mech. aging) 1993 times.

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 12 OF 28  
 BINDER TITLE LIMITORQUE COMPUTED July DATE 9/9/86 R     R      
ACTUATORS OUTSIDE CONTAINMENT WITH CHECKED 12 DATE 9/12/86  
CLASS B MOTORS

H. AGING (Continued)

(b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference B0003, Sect.4.2 ).

B0058, Sect.3.3

JUSTIFICATION/COMMENTS The actuator was required to provide its full output rating at the torque seated position during cycling.

(8) Was the qualified life of the equipment and its basis defined in the qualification program (yes/no/NA)? Yes (Reference B0058, Sect. 3.2 and 7.0 ).

Qualified life (Document in QMDS) greater than 40 years

JUSTIFICATION/COMMENTS None

(9) Were replacement intervals for the equipment or its components defined in the qualification program (yes/no/NA)? Yes (Reference B0058, Sect. 7.0. ).

Replacement Intervals (Document in QMDS) Seals and gaskets are to be replaced during routine maintenance when wear or damage is observed. Also, the actuator lubricants must be inspected for separation after each fuel cycle. If lubricant has separated it must be remixed or replaced (see Tab G, Sections A3, 8 and 9).

JUSTIFICATION/COMMENTS None

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 13 OF 28  
 BINDER TITLE LIMITORQUE COMPUTED Juzi DATE 9/9/86 R     R      
ACTUATORS OUTSIDE CONTAINMENT WITH CHECKED 10 DATE 9/12/86  
CLASS B MOTORS

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Tab C of Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>Durez (Red)</u>	<u>2 x 10<sup>7</sup></u>	<u>B0003(4.3)</u>	<u>1.02</u>	<u>TAB E, item 18</u> <u>See Comments</u>
(b) <u>G.P. Phenolic (Black)</u>	<u>2.09 x 10<sup>8</sup></u>	<u>B0212(6.7)</u> <u>B0003(2.3)</u>	<u>1.63</u>	<u>See Comments</u>
(c) <u>Motor Insulation-CL-"B"</u>	<u>2.04 x 10<sup>8</sup></u>	<u>and App. II</u>	<u>0.93</u>	<u>See Comments</u>
(d) <u>Wiring Insulation</u>	<u>2.0 x 10<sup>8</sup></u>	<u>WBNEQ-CABL</u> <u>-044</u>	<u>NA</u>	<u>See Tab C,</u> <u>Sect. 4.0</u>
(e) _____	_____	_____	_____	_____

JUSTIFICATION/COMMENTS Radiation threshold does not apply. Limitorque  
has performed radiation exposure per the referenced Limitorque test re-  
ports. The values listed in the threshold column represent the testing  
parameters. (a) See Tab C, Section 9.0

Activation energies are documented in Tab E as follows:  
a. Durez - Limitorque telex September 25, 1985 (B70850926001)  
b. G. P. Phenolic - Limitorque letter September 15, 1985 (B70850910004)  
c. Motor insulation - Limitorque letter September 25, 1985 (B70850926001)

See Tab C, Section 8.0 for material analysis.  
Limitorque's telex dated November 6, 1985 (B70 851107 021), shows the  
correlation between the material color, material name, and the test  
report.

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 14 OF 28  
 BINDER TITLE LIMITORQUE COMPUTED Jys DATE 8/22/86 R     R      
 ACTUATORS OUTSIDE CONTAINMENT WITH CLASS B MOTORS CHECKED B DATE 8/25/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference B0058, Sect. 4.1.8 ).

Identify Acceptance Criteria: The actuator must be capable of opening or closing a valve on demand. TVA Quality Assurance procedures and pre-operational test results provide assurance that the actuator will perform its intended function.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference B0003, Sect.4.0, Fig.1, 2A, and 2B )

Identify baseline and functional testing: See Tab C, Section 11.

JUSTIFICATION/COMMENTS None

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? No (Reference NA ).

JUSTIFICATION/COMMENTS B0003 does not describe mechanical loads during DBE testing. Electrical characteristics and stroke time during DBE cycling are shown in Figure 2B of B0003.



BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 15 OF 28  
 BINDER TITLE LIMITORQUE COMPUTED JWS DATE 8/22/86 R     R      
 ACTUATORS OUTSIDE CONTAINMENT WITH CLASS B MOTORS CHECKED B DATE 8/22/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

(4) Do the applied loads during baseline testing reflect normal operating conditions (yes/no/NA)? Yes (Reference B0003, Sect.4.1,4.2, and 4.5, & Fig. 2A and 2B).

JUSTIFICATION/COMMENTS None

(5)(a) <u>Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference</u>
Voltage	<u>See Comment</u>	<u>See Comment</u>
Load	<u>See Comment</u>	<u>NA</u>
Frequency	<u>60 Hz <math>\pm</math> 3.2%</u>	<u>WBN FSAR p 8.3 - 17</u>
Accuracy	<u>NA</u>	<u>NA</u>
<u>Other(s)</u>		

JUSTIFICATION/COMMENTS Justification for lack of reduced voltage starting tests under accident conditions is presented in Tab C, Section 5.0. Actuators are sized to produce the required torque for each valve under specified applications and conditions.

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 15A OF 28  
 BINDER TITLE LIMITORQUE COMPUTED July 15 DATE 9/9/86 R    R     
ACTUATORS OUTSIDE CONTAINMENT WITH CHECKED    DATE 9/12/86  
CLASS B MOTORS

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

(5)(b) <u>Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>
Voltage	<u>490 - 500 VAC</u>	<u>B0003, Fig. 2B</u>
Load	<u>Thrust 20,000 lbs</u>	<u>B0003, Sect. 4.1</u>
Frequency	<u><del>NA</del> SEE COMMENTS <sup>July 9/9/86</sup> 9/12</u>	<u>B0003, App. III, page 3A</u>
Accuracy	<u>NA</u>	<u>NA</u>
<u>Other(s)</u>		

JUSTIFICATION/COMMENTS Although the test report does not address demonstrated frequency, we have no reason to believe that the operator was tested at other than 60 Hz. Also, per Limitorque letter dated 6/18/86 (B71 860623 004, Tab E, item 19) the actuator motor is purchased to NEMA standards that require the motor to operate at plus or minus 5 percent of nominal frequency.

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16 OF 28  
 BINDER TITLE LIMITORQUE COMPUTED JWH DATE 8/22/86 R     R      
 ACTUATORS OUTSIDE CONTAINMENT WITH CLASS B MOTORS CHECKED B DATE 8/22/86

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. Worst case listed below - See pp 16A through 16M for all operating environments

(1) Normal Max	(2) Abnormal Max
(a) Temperature (°F) <u>110</u>	(a) Temperature (°F) <u>120</u>
(b) Pressure (psig) <u>0</u>	(b) Pressure (psig) <u>0</u>
(c) Humidity (%) <u>80</u>	(c) Humidity (%) <u>90</u>
(d) Radiation (rd) <u>1.8 x 10<sup>7</sup></u>	(d) Radiation (rd) <u>NA</u>

(3) Process Interfaces: Valve body and stem connection configuration isolates the degradable actuator parts from significant additional heating due to the high temperature of process fluids.

(4) State anticipated occurrence frequency and duration of abnormal conditions: Abnormal temperatures could occur as a result of outside temp. excursions, temporarily greater than design heat loads, or degraded environment control systems. This could exist for up to eight hours per excursion and will occur less than 1% of the plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

* (a) Temperature (°F) <u>162.00</u>	Accident type <u>LOCA(See Tab A)</u>
(b) Pressure (psig) <u>0</u>	Accident type <u>HELB(See Tab A)</u>
(c) Humidity (%) <u>100</u>	Accident type <u>HELB(See Tab A)</u>
(d) Radiation (rd) <u>1.2 x 10<sup>7</sup></u>	Accident type <u>LOCA(See Tab A)</u>
(e) Spray Type <u>NA</u>	Accident type <u>NA</u>

\*This is the most severe temperature because the duration of the temperature does not drop off as rapidly as the peak temperatures listed on sheet 16G, 16H, 16I (209°F) and sheet 16K (190°F).

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16A OF 28  
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED [Signature] DATE 8/22/86  
OUTSIDE CONTAINMENT WITH CHECKED [Signature] DATE 8/22/86  
CLASS B MOTORS

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-44 RQ (Annulus) *R1 July 9/9/86 Bg/1-2*

- |  |                                 |
|--|---------------------------------|
| (1) Normal Max   | (2) Abnormal Max                |
| (a) Temperature (°F) <u>110</u>                            | (a) Temperature (°F) <u>120</u> |
| (b) Pressure (psig) <u>0</u>                               | (b) Pressure (psig) <u>0</u>    |
| (c) Humidity (%) <u>80</u>                                 | (c) Humidity (%) <u>90</u>      |
| <i>Bg/1-2</i> (d) Radiation (rd) <u>1 x 10<sup>6</sup></u> | (d) Radiation (rd) <u>NA</u>    |
- (3) Process Interfaces: See page 16.
- 
- 

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

---

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- |  |                           |
|--|---------------------------|
| (a) Temperature (°F) <u><del>150</del> 133.7</u> <i>July 9/9/86 Bg/1-2</i> | Accident type <u>LOCA</u> |
| (b) Pressure (psig) <u>0</u>   | Accident type <u>HELB</u> |
| (c) Humidity (%) <u><del>100</del> 61</u> <i>July 9/9/86 Bg/1-2</i>        | Accident type <u>HELB</u> |
| <i>Bg/1-2</i> (d) Radiation (rd) <u>1.2 x 10<sup>7</sup></u>               | Accident type <u>LOCA</u> |
| (e) Spray Type <u>NA</u>   | Accident type <u>NA</u>   |

~~\*See CENNAL3-001 (B45-851117-235) for normal radiation dose.~~ *July 9/9/86 Bg/1-2*  
~~\*\*See WBNNAL3-004 (B45-860205-235) for accident radiation dose.~~

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16B OF 28  
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 R     R      
OUTSIDE CONTAINMENT WITH CHECKED B DATE 8/22/86  
CLASS B MOTORS

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-46 ~~70~~ (737 A1) R1 JWH 9/19/86 9/12

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) 104 (a) Temperature (°F) 110

(b) Pressure (psig) 0 (b) Pressure (psig) 0

(c) Humidity (%) 80 (c) Humidity (%) 90

*Bg 9/12/86* (d) Radiation (rd) 2.1 x 10<sup>5</sup> (d) Radiation (rd) NA

(3) Process Interfaces: See page 16.

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 128 Accident type HELB

(b) Pressure (psig) 0 Accident type LOCA

(c) Humidity (%) 100 Accident type HELB

*Bg 9/12/86* (d) Radiation (rd) <1 x 10<sup>4</sup> Accident type LOCA

(e) Spray Type NA Accident type NA

~~\*See WBNNAL3-025 (B45 860328 236) for normal radiation dose.~~ *JWH 9/12/86*  
~~\*\*See WBNNAL3-026 (B45 860328 237) for accident radiation dose.~~ *Bg 9/12*

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-48 ~~R3~~ <sup>9/11/86</sup> (737 A5, A9)

(1) Normal Max		(2) Abnormal Max	
(a) Temperature (°F)	<u>104</u>	(a) Temperature (°F)	<u>110</u>
(b) Pressure (psig)	<u>0</u>	(b) Pressure (psig)	<u>0</u>
(c) Humidity (%)	<u>80</u>	(c) Humidity (%)	<u>90</u>
<sup>9/11/86</sup> (d) Radiation (rd)	<u>8.8 x 10<sup>5</sup></u>	(d) Radiation (rd)	<u>NA</u>

(3) Process Interfaces: See page 16.

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

\_\_\_\_\_

\_\_\_\_\_

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F)	<u>110</u>	Accident type	<u>LOCA</u>
(b) Pressure (psig)	<u>0</u>	Accident type	<u>LOCA</u>
(c) Humidity (%)	<u>NA</u>	Accident type	<u>LOCA</u>
** (d) Radiation (rd)	<u>1.8 x 10<sup>6</sup></u> <del>1.0 x 10<sup>6</sup></del>	Accident type	<u>LOCA</u>
(e) Spray Type	<u>NA</u>	Accident type	<u>NA</u>

\*See ~~WBNNAL3-025 (B45 860328 236)~~ for normal radiation dose. <sup>9/11/86</sup>

\*\*See ~~WBNNAL3-026 (B45 860328 237)~~ for accident radiation dose. <sup>9/11/86</sup>

<sup>9/11/86</sup> QIR NEB 86092 (B46 860721252)

<sup>9/11/86</sup>

BINDER NO. WBNEQ-MOV-004 PLANT WBN UNIT(S) 1 SHEET 16D OF 28  
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 R     R      
OUTSIDE CONTAINMENT WITH CHECKED B DATE 8/12/86  
CLASS B MOTORS

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-50 <sup>R1</sup> (713 A11, A12, A15, A16) *JWH 8/12/86*

- |  |                                 |
|--|---------------------------------|
| (1) Normal Max   | (2) Abnormal Max                |
| (a) Temperature (°F) <u>104</u>                                  | (a) Temperature (°F) <u>110</u> |
| (b) Pressure (psig) <u>0</u>                                     | (b) Pressure (psig) <u>0</u>    |
| (c) Humidity (%) <u>80</u>                                       | (c) Humidity (%) <u>90</u>      |
| <i>B 9/1/86</i> * (d) Radiation (rd) <u>4.3 x 10<sup>5</sup></u> | (d) Radiation (rd) <u>NA</u>    |
| (3) Process Interfaces: <u>See page 16.</u>                      |                                 |

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

- |  |                           |
|--|---------------------------|
| (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile): |                           |
| (a) Temperature (°F) <u>110</u>  | Accident type <u>LOCA</u> |
| (b) Pressure (psig) <u>0</u>   | Accident type <u>LOCA</u> |
| (c) Humidity (%) <u>NA</u>   | Accident type <u>LOCA</u> |
| <i>B 9/1/86</i> * (d) Radiation (rd) <u>1.0 x 10<sup>7</sup></u>   | Accident type <u>LOCA</u> |
| (e) Spray Type <u>NA</u>   | Accident type <u>NA</u>   |

\*See ~~WBNNAL3-025 (B45 860328 236)~~ for normal radiation dose. *JWH 8/12/86*  
 \*\*See ~~WBNNAL3-026 (B45 860328 237)~~ for accident radiation dose.

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16E OF 28  
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 R     R      
OUTSIDE CONTAINMENT WITH  
CLASS B MOTORS CHECKED B DATE 8/22/86

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-52 ~~88~~ (713 A1, A13, A14)  
 RI 9/19/86 9/12

- |   |                                 |
|---|---------------------------------|
| (1) Normal Max  | (2) Abnormal Max                |
| (a) Temperature (°F) <u>104</u>                                 | (a) Temperature (°F) <u>110</u> |
| (b) Pressure (psig) <u>0</u>                                    | (b) Pressure (psig) <u>0</u>    |
| (c) Humidity (%) <u>80</u>                                      | (c) Humidity (%) <u>90</u>      |
| <i>9/11/86</i> * (d) Radiation (rd) <u>1.8 x 10<sup>7</sup></u> | (d) Radiation (rd) <u>NA</u>    |
| (3) Process Interfaces: <u>See page 16.</u>                     |                                 |

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

- |  |                           |
|--|---------------------------|
| (5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile): |                           |
| (a) Temperature (°F) <u>128</u>  | Accident type <u>HELB</u> |
| (b) Pressure (psig) <u>0</u>   | Accident type <u>HELB</u> |
| (c) Humidity (%) <u>100</u>  | Accident type <u>HELB</u> |
| <i>9/11/86</i> * (d) Radiation (rd) <u>&lt;1.0 x 10<sup>4</sup></u>  | Accident type <u>LOCA</u> |
| (e) Spray Type <u>NA</u>   | Accident type <u>NA</u>   |

\*See WBNNAL3-025 (B45 860328 236) for normal radiation dose. *JWH 9/12*  
 \*\*See WBNNAL3-026 (B45 860328 237) for accident radiation dose. *9/19/86*



BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16F OF 28  
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 R     R      
OUTSIDE CONTAINMENT WITH  
CLASS B MOTORS CHECKED BZ DATE 8/22/86

K. REQUIRED OPERATING ENVIRONMENT

*R1 9/19/86 BZ/12*

Reference Environmental Drawing No. 47E235-56 B8 (713 A6, A19)

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) 104 (a) Temperature (°F) 110

(b) Pressure (psig) 0 (b) Pressure (psig) 0

(c) Humidity (%) 80 (c) Humidity (%) 90

*BZ/12 JWH 9/19/86*

(d) Radiation (rd) 2.2 x 10<sup>6</sup> (d) Radiation (rd) NA

(3) Process Interfaces: See page 16.

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 110 Accident type LOCA

(b) Pressure (psig) 0 Accident type LOCA

(c) Humidity (%) NA Accident type LOCA

*BZ/12 JWH 9/19/86*

(d) Radiation (rd) 2.0 x 10<sup>6</sup> ~~1.0 x 10<sup>6</sup>~~ Accident type LOCA

(e) Spray Type NA Accident type NA

\*See WBNNALS-025 (B45 860328 236) for normal radiation dose. *JWH BZ/12 9/19/86*  
 \*\*See WBNNALS-026 (B45 860328 237) for accident radiation dose.

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16G OF 28  
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JW DATE 8/22/86  
OUTSIDE CONTAINMENT WITH CHECKED B DATE 8/22/86  
CLASS B MOTORS

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 747E235-58 ~~RS~~, ~~59~~ ~~R1~~ (676 A16, A17) <sup>R2</sup>

(1) Normal Max		(2) Abnormal Max	
(a) Temperature (°F)	<u>104</u>	(a) Temperature (°F)	<u>110</u>
(b) Pressure (psig)	<u>0</u>	(b) Pressure (psig)	<u>0</u>
(c) Humidity (%)	<u>80</u>	(c) Humidity (%)	<u>90</u>
(d) Radiation (rd)	<u>7.5 x 10<sup>6</sup></u>	(d) Radiation (rd)	<u>NA</u>

*Draft JW 9/1/86*

(3) Process Interfaces: See page 16.

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F)	<u>209</u>	Accident type	<u>HELB</u>
(b) Pressure (psig)	<u>0</u>	Accident type	<u>HELB</u>
(c) Humidity (%)	<u>100</u>	Accident type	<u>HELB</u>
(d) Radiation (rd)	<u>5.0 x 10<sup>6</sup></u>	Accident type	<u>LOCA</u>
(e) Spray Type	<u>NA</u>	Accident type	<u>NA</u>

\*See ~~WBNNAL3-025 (B45 860328 236)~~ for normal radiation dose. <sup>JW 9/1/86</sup>  
 \*\*See ~~WBNNAL3-026 (B45 860328 237)~~ for accident radiation dose. <sup>Bg/12</sup>

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16H OF 28

BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWC DATE 8/22/86 R     R      
OUTSIDE CONTAINMENT WITH  
CLASS B MOTORS CHECKED B DATE 8/23/86

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-60 R1, -59 R2 (692 A8, A24)

(1) Normal Max

(a) Temperature (°F) 104

(b) Pressure (psig) 0

(c) Humidity (%) 80

*B 9/12* *9/12* *9/12* (d) Radiation (rd) 7.5 x 10<sup>6</sup>

(2) Abnormal Max

(a) Temperature (°F) 110

(b) Pressure (psig) 0

(c) Humidity (%) 90

(d) Radiation (rd) NA

(3) Process Interfaces: See page 16.

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 209 Accident type HELB

(b) Pressure (psig) 0 Accident type HELB

(c) Humidity (%) 100 Accident type HELB

*B 9/12* *9/12* *9/12* (d) Radiation (rd) 5.0 x 10<sup>6</sup> Accident type LOCA

(e) Spray Type NA Accident type NA

~~\*See WBNNAL3 025 (B45 860328 236) for normal radiation dose.~~

~~\*\*See WBNNAL3 026 (B45 860328 237) for accident radiation dose.~~

PAGE B-28

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16I OF 28  
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWI DATE 8/22/86  
OUTSIDE CONTAINMENT WITH CHECKED B DATE 8/23/86  
CLASS B MOTORS

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-61 R1, 59 R2 (713 A28, A29) *R1 9/11/86 R2 9/12*

(1) Normal Max	(2) Abnormal Max
(a) Temperature (°F) <u>104</u>	(a) Temperature (°F) <u>110</u>
(b) Pressure (psig) <u>0</u>	(b) Pressure (psig) <u>0</u>
(c) Humidity (%) <u>80</u>	(c) Humidity (%) <u>90</u>
<i>Baliv JWI 9/11/86</i> (d) Radiation (rd) <u>7.5 x 10<sup>6</sup></u>	(d) Radiation (rd) <u>NA</u>

(3) Process Interfaces: See page 16.

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) <u>209</u>	Accident type <u>HELB</u>
(b) Pressure (psig) <u>0</u>	Accident type <u>HELB</u>
(c) Humidity (%) <u>100</u>	Accident type <u>HELB</u>
<i>Baliv JWI 9/11/86</i> (d) Radiation (rd) <u>5.0 x 10<sup>6</sup></u>	Accident type <u>LOCA</u>
(e) Spray Type <u>NA</u>	Accident type <u>NA</u>

\*See ~~WBNNAL3-025 (B45-860328-236)~~ for normal radiation dose. *JWI 9/11/86*  
 \*\*See ~~WBNNAL3-026 (B45-860328-237)~~ for accident radiation dose. *Baliv 9/11/86*

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16J OF 28  
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED Jwt DATE 8/22/86 R     R      
OUTSIDE CONTAINMENT WITH  
CLASS B MOTORS CHECKED B DATE 8/23/86

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-62<sup>R1</sup>, 63<sup>R2</sup>, 64<sup>R2</sup>, 65<sup>R2</sup>  
 (692 A1)

(1) Normal Max	(2) Abnormal Max
(a) Temperature (°F) <u>104</u>	(a) Temperature (°F) <u>110</u>
(b) Pressure (psig) <u>0</u>	(b) Pressure (psig) <u>0</u>
(c) Humidity (%) <u>80</u>	(c) Humidity (%) <u>90</u>
(d) Radiation (rd) <u>5.6 x 10<sup>5</sup></u>	(d) Radiation (rd) <u>NA</u>

(3) Process Interfaces: See page 16.

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) <u>141</u>	Accident type <u>HELB</u>
(b) Pressure (psig) <u>0</u>	Accident type <u>HELB</u>
(c) Humidity (%) <u>100</u>	Accident type <u>HELB</u>
(d) Radiation (rd) <u>&lt;1.0 x 10<sup>4</sup></u>	Accident type <u>LOCA</u>
(e) Spray Type <u>NA</u>	Accident type <u>NA</u>

\*See ~~WBNNAL3-025 (B45-860328-236)~~ for normal radiation dose. *Jwt 9/9/86 B 9/11*  
 \*\*See ~~QIR-NEB-86052 (#4) (B45-860328-237)~~ for accident radiation dose.

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16K OF 28

BINDER TITLE LIMITORQUE ACTUATORS COMPUTED Jug DATE 8/22/86  
OUTSIDE CONTAINMENT WITH  
CLASS B MOTORS CHECKED B DATE 8/23/86

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-77 ~~86~~ (RSVR) (685 A7, A25')

(1) Normal Max		(2) Abnormal Max	
(a) Temperature (°F)	<u>104</u>	(a) Temperature (°F)	<u>110</u>
(b) Pressure (psig)	<u>0</u>	(b) Pressure (psig)	<u>0</u>
(c) Humidity (%)	<u>80</u>	(c) Humidity (%)	<u>90</u>
<i>Bg/12 Jul 9/9/86</i> *(d) Radiation (rd)	<u>1.8 x 10<sup>6</sup></u>	(d) Radiation (rd)	<u>NA</u>

(3) Process Interfaces: See page 16.

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F)	<u>190</u>	Accident type	<u>LOCA</u>
(b) Pressure (psig)	<u>0</u>	Accident type	<u>LOCA</u>
(c) Humidity (%)	<u>90</u>	Accident type	<u>LOCA</u>
<i>Bg/12 Jul 9/9/86</i> *(d) Radiation (rd)	<u>1.0 x 10<sup>7</sup></u> <u>3.0 x 10<sup>8</sup></u>	Accident type	<u>LOCA</u>
(e) Spray Type	<u>NA</u>	Accident type	<u>NA</u>

\*See WBNNAL3-025 (B45 860328 236) for normal radiation dose.  
 \*\*See QIR NEB86052 (#4) (B45 860527 265) for accident radiation dose.

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-79 ~~80~~ <sup>R1 JUL 26 9/5/86 B4/12</sup> (692 A9, A10, A11, A12, A13, A19, A20, A21, A22, A23)

(1) Normal Max	(2) Abnormal Max
(a) Temperature (°F) <u>104</u>	(a) Temperature (°F) <u>110</u>
(b) Pressure (psig) <u>0</u>	(b) Pressure (psig) <u>0</u>
(c) Humidity (%) <u>80</u>	(c) Humidity (%) <u>90</u>
<sup>B4/12 JUL 26 9/5/86</sup> * (d) Radiation (rd) <u>3.5 x 10<sup>4</sup></u>	(d) Radiation (rd) <u>NA</u>

(3) Process Interfaces: See page 16.  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.  
 \_\_\_\_\_  
 \_\_\_\_\_

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) <u>110</u>	Accident type <u>LOCA</u>
(b) Pressure (psig) <u>0</u>	Accident type <u>LOCA</u>
(c) Humidity (%) <u>NA</u>	Accident type <u>LOCA</u>
<sup>B4/12 JUL 26 9/5/86</sup> * (d) Radiation (rd) <u>1.0 x 10<sup>7</sup></u>	Accident type <u>LOCA</u>
(e) Spray Type <u>NA</u>	Accident type <u>NA</u>

\*See ~~WBNNAL3-025 (B45 860328 236)~~ for normal radiation dose. <sup>JUL 26 9/5/86 B4/12</sup>  
 \*\*See ~~WBNNAL3-026 (B45 860328 237)~~ for accident radiation dose.

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 16M OF 28  
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED [Signature] DATE 8/22/86  
OUTSIDE CONTAINMENT WITH CHECKED [Signature] DATE 8/22/86  
CLASS B MOTORS

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-56 (713 A7')  
See Open Items R1, -57, R2  
(SQN) 47E235-59

(1) Normal Max

(a) Temperature (°F) 104  
 (b) Pressure (psig) ATM (-)  
 (c) Humidity (%) 80

(2) Abnormal Max

(a) Temperature (°F) 110  
 (b) Pressure (psig) ATM (-)  
 (c) Humidity (%) 90  
 (d) Radiation (rd) NA

(3) Process Interfaces: See page 16.

(4) State anticipated occurrence frequency and duration of abnormal conditions: See page 16.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F)	<u>190</u>	Accident type	<u>HELB</u>
(b) Pressure (psig)	<u>0</u>	Accident type	<u>HELB</u>
(c) Humidity (%)	<u>100</u>	Accident type	<u>HELB</u>
(d) Radiation (rd)	<u>5.0 x 10<sup>6</sup></u>	Accident type	<u>LOCA</u>
(e) Spray Type	<u>NA</u>	Accident type	<u>NA</u>

~~\*See WBNNAL3-025 (B45 860328 236) for normal radiation dose.~~

~~\*\*See WBNNAL3-026 (B45 860328 237) for accident radiation dose.~~

Note: ~~Temperature, pressure and humidity data were taken from the referenced SQN Environmental Drawing, since the WBN drawing does not exist at this time (see open items).~~



BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 17 OF 28  
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWB DATE 8/22/86  
OUTSIDE CONTAINMENT WITH CHECKED B DATE 8/23/86  
CLASS B MOTORS

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.):

None

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (yes/no/NA)? No (Reference Tab B, Sect. p Tab C, Sect. 7.0 ).
- (7) Subject to submergence (yes/no/NA)? No (Reference Tab C, Section 12.0 ).

Identify initiation time and duration of submergence: See Tab C, Section 12.0.

- (8) Special environmental calculations (temp. rad. etc.).

Type	RIMS No.
<del>Radiation WBNNAL3-025</del> <u>JWB 9/9/86 B 9/12</u>	<del>B45 860328 236</del> <u>JWB 9/9/86 B 9/12</u>
<del>Radiation WBNNAL3-026</del> <u>JWB 9/9/86 B 9/12</u>	<del>B45 860328 237</del> <u>JWB 9/9/86 B 9/12</u>
<del>Radiation QIR NEB86052 (#4)</del> <u>JWB 9/9/86 B 9/12</u>	<del>B45 860527 265</del> <u>JWB 9/9/86 B 9/12</u>
<del>Radiation GENNAL3-001</del> <u>JWB 9/9/86 B 9/12</u>	<del>B45 851117 235</del> <u>JWB 9/9/86 B 9/12</u>
<del>Radiation WBNNAL3-004</del> <u>JWB 9/9/86 B 9/12</u>	<del>B45 860205 235</del> <u>JWB 9/9/86 B 9/12</u>
<u>RADIATION QIR NEB 86092</u> <u>JWB 9/9/86 B 9/12</u>	<u>B46 860721 252</u> <u>JWB 9/9/86 B 9/12</u>

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 18 OF 28  
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JLB DATE 8/22/86  
OUTSIDE CONTAINMENT WITH CHECKED B DATE 8/22/86  
CLASS B MOTORS

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100 days</u>	<u>16 days</u>	<u>B0003, Sect. 4.5 &amp; Fig. 1</u>
Temperature (°F)	<u>209</u>	<u>250</u>	<u>B0003, Fig. 1</u>
Pressure (psig)	<u>0</u>	<u>25</u>	<u>B0003, Fig. 1</u>
Relative Humidity (%)	<u>100</u>	<u>100</u>	<u>B0003, Sect. 2.5.2 &amp; Fig. 1</u>
*Chemical Spray	<u>NA</u>	<u>NA</u>	<u>NA</u>
**Radiation (rd)	<u>1.8 x 10<sup>7</sup></u>	<u>2x10<sup>7</sup> - Other 2.04x10<sup>8</sup> - Motor Only</u>	<u>B0003, Sect. 2.3 &amp; App. II See Comments</u>
Submergence	<u>NA</u>	<u>NA</u>	<u>NA</u>

\*Includes spray concentration, flowrate, density, duration, and pH.  
 \*\*Enter 40-year integrated normal dose plus integrated accident dose and specify type.

JUSTIFICATION/COMMENTS Please note that the radiation levels in K(1) and K(5) on page 16 are not additive and the worst case is based on sheet 16E. See Tab C, Section 9.0 for discussion of radiation testing for switches. See Tab C, Section 6.0 for post-accident operability time justification.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>B0003, Fig. 1</u>
Pressure	<u>Yes</u>	<u>B0003, Fig. 1</u>
Relative Humidity	<u>Yes</u>	<u>B0003 Sect. 4.1.4</u>
Chemical Spray	<u>NA</u>	<u>NA</u>
Submergence	<u>NA</u>	<u>NA</u>

JUSTIFICATION/COMMENTS \_\_\_\_\_

BINDER NO. WBNEQ-MOV-003 PLANT WRN UNIT(S) 1 SHEET 19 OF 28  
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWH DATE 8/22/86 R     R      
OUTSIDE CONTAINMENT WITH CHECKED     DATE 8/23/86  
CLASS B MOTORS

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

- (3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, yes/no/NA)

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	15°F	Yes-B0003 Fig. 1
Pressure: +10% but no more than 10 psig	10%	Yes-B0003, Fig. 1
Radiation: +10% of accident dose	10%	Yes-B0003, Sect. 4.3
Time: +10% (or 1 hour + operating time per NUREG-0588)	--	No-See Comment
Voltage: + 10% of rated value	+8.7%	No-See Comments Tab C, Sect. 5
Frequency: + 5% of rated value		See Comments
Environmental Transient: the initial transient and the peak temperature applied twice	2 Dwells	Yes-B0003, Fig. 1
Vibration: +10% added to acceleration	NA	NA-Tab C, Sect. 2

JUSTIFICATION/COMMENTS: See above references for all items  
except time margin. See Tab C, Section 6.0. See comments on  
frequency in TAB B section J(5). Although the test margin is  
only +8.7%. Limitorque letter dated 6-19-86 (B71 860623 004,  
Tab E, Item 20) states that Limitorque purchase actuator motors  
to Nema standards requiring the motors to be capable of operating  
at plus or minus 10% voltage or plus or minus 5% of nominal  
frequency.

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 20 OF 28

BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWC DATE 8/22/86 R     R      
OUTSIDE CONTAINMENT WITH  
CLASS B MOTORS CHECKED B DATE 8/25/86

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:  
(Reference B0058, Sect. 2.4 ).

JUSTIFICATION/COMMENTS The actuator must be capable of providing  
the required torque and/or thrust to open or close the valve as  
required.

- (2) Did the equipment perform its intended function during the simulated  
design basis accident exposure (yes/no/NA)? Yes  
(Reference B0003, Sect. 5.0 ).

JUSTIFICATION/COMMENTS None

- (3) Did the equipment perform its intended function during the simulated  
post-design basis accident exposure (yes/no/NA)? Yes  
(Reference B0003, Sect. 5 ).

JUSTIFICATION/COMMENTS None

- (4) Did the test demonstrate the operability requirements for the required  
time interval for which the equipment is required to operate  
(yes/no/NA)? No (Reference B0003, Fig 1, 2A and 2B ).

JUSTIFICATION/COMMENTS See Tab C, Section 6.0 for justification  
of post-accident actuator operability.

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly  
addressed and resolved (yes/no/NA)? Yes  
(Reference B0003, Sect. 4.5.2 ).

JUSTIFICATION/COMMENTS Minor problems were experienced during the  
LOCA test. These problems had no effect on overall actuator per-  
formance. See the referenced section of report B0003.



BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 22 OF 88  
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED Jwi DATE 8/22/86  
OUTSIDE CONTAINMENT WITH CHECKED B DATE 8/22/86  
CLASS B MOTORS

0. SUMMARY OF REVIEW

- |  | <u>Yes/No/NA</u> |
|--|------------------|
| (1) Documented evidence of qualification adequate<br>(Have all assumptions, mathematical models, and<br>all extrapolations of test data used in an<br>analysis been justified and documented)? | <u>Yes</u>       |
| (2) Any exceptions (i.e., sound reasons to the contrary)<br>taken to the specified qualification level<br>adequately justified?  | <u>NA</u>        |
| (3) Choice of qualification methodology adequately<br>justified?   | <u>Yes</u>       |
| (4) If analysis was performed, complete the following:   |                  |
| (a) Were equipment performance requirements<br>identified?   | <u>NA</u>        |
| (b) Were specific features and failure modes and<br>effects analyzed?  | <u>NA</u>        |
| (c) Were assumptions and mathematical models used<br>together with appropriate justification for<br>their use?   | <u>NA</u>        |
| (d) Were environmental parameters which affect<br>equipment performance identified?  | <u>NA</u>        |
| (5) Adequate similarity between equipment and test<br>specimen established?  | <u>Yes</u>       |
| (6) Aging degradation evaluated adequately?  | <u>Yes</u>       |
| (a) Mechanical and/or cycle aging addressed?   | <u>Yes</u>       |
| (b) Equipment aged to end of life condition prior to<br>application of DBE conditions?   | <u>Yes</u>       |
| (c) Absence of preaging in test/analysis justified?  | <u>Yes</u>       |
| (d) Materials susceptible to thermal/radiation<br>aging identified?  | <u>Yes</u>       |

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 23 OF 28  
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JW DATE 8/22/86 R     R      
OUTSIDE CONTAINMENT WITH CHECKED B DATE 8/25/86  
CLASS B MOTORS

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>NA</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>NA</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>NA</u>
(11) Criteria regarding submergence satisfied?	<u>NA</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

PAGE B-40

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 24 OF 28  
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED *Plots* DATE 8/22/81  
OUTSIDE CONTAINMENT WITH CHECKED *B* DATE 8/25/81  
CLASS B MOTORS

0. SUMMARY OF REVIEW (Continued)

- |  | <u>Yes/No/NA</u> |
|--|------------------|
| (15) Criteria regarding functional testing satisfied?  | <u>Yes</u>       |
| (a) Does the test plan/report specify an acceptance criteria for equipment performed?  | <u>Yes</u>       |
| (b) Was an initial base line test done to establish required performance characteristics?  | <u>Yes</u>       |
| (c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? | <u>Yes</u>       |
| (16) Criteria regarding instrument accuracy satisfied?   | <u>NA</u>        |
| (17) Test duration margin (1 hour + function time) satisfied?  | <u>Yes</u>       |
| (a) Is the minimum specified operating time at least 1 hour?   | <u>Yes</u>       |
| (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided?  | <u>NA</u>        |
| (18) Criteria regarding synergistic effects satisfied?   | <u>Yes</u>       |
| (19) Criteria regarding margins satisfied?   | <u>Yes</u>       |
| (20) Maintenance and surveillance requirements adequately identified?  | <u>Yes</u>       |



BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 25 OF 8  
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED [Signature] DATE 8/22/86 R     R      
OUTSIDE CONTAINMENT WITH  
CLASS B MOTORS CHECKED [Signature] DATE 8/23/86 R     R    

P. DISCUSSION

JUSTIFICATION FOR NOT USING LIMIT SWITCH COMPARTMENT DRAINS IN LIMITORQUE VALVE ACTUATORS.

Concerning the potential problem of steam entering the conduit during a HELB, condensing, and subsequently running down a long vertical conduit run and into the actuator, we present the following assumptions and calculations:

1. Assume the conduit is 1 1/2 inch rigid steel conduit conforming to the dimensions listed in TVA Electrical Design Standard DS-El3.1.3, Revision 0.

Weight is 2.51 lbs/ft  
 OD = 1.90  
 ID = 1.61  
 Wall Thickness = 0.29

2. Conduit is 0.5% carbon steel with a specific heat of  $0.111 \frac{\text{BTU}}{\text{lb}_m \text{ } ^\circ\text{F}}$ .
3. Peak pressure to be evaluated is 26.8 psia. This is the maximum pressure to be expected in containment following a HELB or LOCA. PEAK PRESSURE, NOT TEMPERATURE is used because steam will condense only as long as the object on which it is condensing remains below the saturation temperature for that particular pressure. Therefore, a conduit will support the condensing of steam during a HELB until the elevated room temperature and the energy liberated by the change in phase from saturated steam to saturated liquid during condensation cause the temperature of the conduit to increase to the saturated steam temperature.
4. Assume the initial conduit temperature is 50 °F, which is the minimum abnormal temperature for containment as taken from drawing 45M 47E235-45. It should be noted that the heat loads generated by plant operation will keep the lower containment temperature higher than 50 °F. Examination of the time/temperature curve on the environmental drawing shows that the containment temperature will be in excess of 200 °F when the ambient pressure reaches 26.7 psia. However, since 50 °F is very easily defendable as a minimum temperature it will be used instead of a temperature more relevant to actual operating conditions.

PAGE B-42

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 26 OF 28  
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JWB DATE 8/22/86  
OUTSIDE CONTAINMENT WITH CHECKED B DATE 8/23/86  
CLASS B MOTORS

Appendix B of NUREG-0588 - "Model for Environmental Qualification for loss of coolant accident and main steam line break inside PWR and BWR dry type containment" bases condensate heat transfer to components upon the following equation:

$$q/A = h_{\text{cond}}(T_s - T_w)$$

Where:

$q/A$  = Component Surface Heat Flux

$h_{\text{cond}}$  = Condensing Heat Transfer Coefficient

$T_s$  = Saturation Temperature

$T_w$  = Component Surface Temperature

If the component surface temperature ( $T_w$ ) is equal to the saturation temperature ( $T_s$ ), the right hand side of the equation will equal zero. Therefore, if no heat is being transferred from the steam, and heat transfer is required for the phase change from steam to condensate, we can conclude that no more condensate will be formed (as stated in assumption No. 3).

The amount of heat required to raise a component from some initial temperature to a higher temperature, in this case the saturation temperature, is:

$$q = M C_p (T_s - T_i)$$

Where:

$M$  = Mass of the Component

$C_p$  = Specific Heat at Constant Pressure

$T_s$  = Saturation Temperature

$T_i$  = Initial Temperature of the Component

For the Conduit:

$$q = 2.51 \frac{\text{lb}_m}{\text{ft}} * 0.111 \frac{\text{BTU}}{\text{lb}_m \text{ } ^\circ\text{F}} * (244-50) ^\circ\text{F}$$

$$= 54.05 \frac{\text{BTU}}{\text{ft}}$$

PAGE B-43

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 27 OF 28  
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED Jy2 DATE 8/22/86 R     R      
OUTSIDE CONTAINMENT WITH  
CLASS B MOTORS CHECKED B DATE 8/23/86

244°F is the saturation temperature for a relative humidity of 100% and a pressure of 26.8 psia (slightly higher than the 26.7 psia containment pressure). This should yield the theoretical maximum amount of condensate heat transfer.

Assuming none of the condensate vaporizes, the mass of the condensate can now be calculated:

$$M_{\text{condensed}} = \frac{q \text{ transferred}}{h_{fg}}$$

$$\text{Where } h_{fg} = \text{latent heat of vaporization } \frac{\text{BTU}}{\text{lb}_m}$$

$$\text{At } 244^\circ\text{F, } h_{fg} = 949.5 \frac{\text{BTU}}{\text{lb}_m}$$

Note that  $h_{fg}$  increases as temperature decreases. Therefore, the lower temperature in the auxiliary building would yield smaller amounts of condensate.

$$\text{Therefore, } M_{\text{cond}} = \frac{54.05 \frac{\text{BTU}}{\text{ft}}}{949.5 \frac{\text{BTU}}{\text{lb}_m}} = 0.0569 \text{ lb}_m/\text{ft of conduit}$$

This is the amount of condensate that will be formed both inside and outside the conduit. If we consider the conduit to be nonporous, which implies that the condensate on the outside of the conduit will not enter the conduit and increase the mass of the condensate on the inside of the conduit, we can determine the amount of condensate that will be formed inside the conduit. By necessity the external surface area of the conduit is larger than the internal surface area of the conduit, which implies that more than half of condensate formed will be on the outside of the conduit. Comparing the inside and outside surface areas per lineal foot:

$$\frac{D_o}{D_i} = \frac{1.90}{1.61} = 1.18$$

We find that there is 18 percent more surface area outside the conduit on which to form condensate. The mass of condensate inside the conduit ( $m_i$ ) can be determined as follows (mass of condensate is a function of available surface area for formation):

PAGE B-44

BINDER NO. WBNEQ-MOV-003 PLANT WBN UNIT(S) 1 SHEET 28 OF 28  
 R     R      
 BINDER TITLE LIMITORQUE ACTUATORS COMPUTED JW DATE 8/9/86  
 OUTSIDE CONTAINMENT WITH  
CLASS B MOTORS CHECKED BJ DATE 9/12/86

$$\frac{M_o}{M_i} = 1.18 \quad M_o = 1.18 M_i$$

$$M_i$$

$$M_o + M_i = 0.0569 \text{ lb}_m/\text{ft}$$

$$1.18 M_i + M_i = 0.0569 \text{ lb}_m/\text{ft}$$

$$2.18 M_i = 0.0569 \text{ lb}_m/\text{ft}$$

$$M_i = 0.0261 \text{ lb}_m/\text{ft}$$

At 244°F water has a density of approximately 59.7 lb/ft<sup>3</sup>.

If we use the limit switch compartment for the SMB-000 actuator (11.75 x 9.5 in) we can determine the greatest theoretical depth of accumulated condensate.

$$(11.75 \text{ in}) (9.5 \text{ in}) = 111.625 \text{ in}^2 = 0.7752 \text{ ft}^2$$

NOTE: This would be the smallest limit switch compartment for any of the Limitorque operators in the 10CFR50.49 program at WBNP.

If we consider the longest vertical run of unobstructed conduit to be 30 ft in length we get the following depth of condensate in the limit switch compartment.

$$\frac{0.0261 \text{ lb}/\text{ft} \times 30 \text{ ft} \times 1 \text{ ft}^3/59.7 \text{ lb}}{0.7752 \text{ ft}^2} = 0.0169 \text{ ft} = 0.20 \text{ in}$$

Assuming all conditions to be worst case, that is the largest amount of condensate in the smallest space, we calculate less than 13/64" of condensate in the limit switch compartment, which is not deep enough to submerge any of the electrical contacts on the limit switch. Therefore the conduit configuration at WBP is deemed to result in no condensate problems for Limitorque MOVs.

PAGE B-45

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WBNED-NOT-001  
 MANUFACTURER: WESTINGHOUSE  
 PAGE: 1 OF 2

EDIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV#						
WBN-1-NTR-062-0104	-B 1-NTR-062-0104	-B CVCS PMP NTR	HSDP	UA4		692'	A10	54114-1	L RH/A CV/A AF AB	A A A A A	1000 1MO 1MO 1MO 1MO	THE CCP'S NTRS ARE ESSENTIAL FOR PROPER OPERATION OF THE PMP'S WHICH ARE REQUIRED FOR THE MITIGATION OF THESE EVENTS
WBN-1-NTR-062-0108	-A 1-NTR-062-0108	-A CVCS PMP NTR	HSDP	UA4		692'	A09	LATER	L RH/A CV/A AF AB	A A A A A	1000 1MO 1MO 1MO 1MO	THE CCP'S NTRS ARE ESSENTIAL FOR PROPER OPERATION OF THE PMP'S WHICH ARE REQUIRED FOR THE MITIGATION OF THESE EVENTS
WBN-1-NTR-063-0010	-A 1-NTR-063-0010	-A SIS PMP NTR	HSDP	VA6		692'	A13	54114-1	L RH/A CV/A AF AB	A C C C C	1000	THE SIS PMP'S MUST FUNCTION FOR THE DURATION OF THE LOCA TO ASSURE ADEQUATE CORE COOLING, THEY ARE NOT REQUIRED TO MITIGATE ANY EVENTS IN THE AUX BUILDING.
WBN-1-NTR-063-0015	-B 1-NTR-063-0015	-B SIS PMP NTR	HSDP	UA6		692'	A12	54114-1	L RH/A CV/A AF AB	A C C C C	1000	THE SIS PMP'S MUST FUNCTION FOR THE DURATION OF THE LOCA TO ASSURE ADEQUATE CORE COOLING, THEY ARE NOT REQUIRED TO MITIGATE ANY EVENTS IN THE AUX BUILDING.
WBN-1-NTR-072-0010	-B 1-NTR-072-0010	-B CS PMP NTR	HSW2	TA6		676'	A08	54114-1	L RH/A CV/A AF AB	A C C C C	300	THE CS PMP'S ARE REQUIRED FOR THE MITIGATION OF A LOCA THESE NTRS MUST OPERATE DURING THE MITIGATION OF THE EVENT. THE CS IS NOT REQUIRED TO MITIGATE ANY EVENTS IN THE AUX BUILDING.

PAGE A-1

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

PREPARER/DATE

CHECKER/DATE

*Randy West 7/23/86*  
*W.B. [Signature] 7/23/86*

R \_ \_ R \_ \_ R \_ \_

TAB A - EQUIPMENT IDENTIFICATION MATRIX

BINDER NO. WBNED-MDT -001  
 MANUFACTURER: WESTINGHOUSE  
 PAGE: 2 OF 2

EQUIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL	LOCATION			CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION	
				COLUMN	AZ	ELEV*						
WBN-1-NTR -072-0027	-A 1-NTR -072-0027	-A CS PMP NTR	NSW2	UAG		676'	A09	54114-1	L RH/A CV/A AB AF	A C C C C	300	THE CSS PMPs ARE REQUIRED FOR THE MITIGATION OF A LOCA. THESE NTRS MUST OPERATE DURING THE MITIGATION OF THE EVENT. THE CSS IS NOT REQUIRED TO MITIGATE ANY EVENTS IN THE AUX BUILDING.
WBN-1-NTR -074-0010	-A 1-NTR -074-0010	-A RHR PUMP NTR	VSW1	VAS		676'	A11	160412	L RH/A CV/A AF AB	A C C C C	1000	THESE PMPs FUNCTION AS PART OF THE ECCS TO ENSURE ADEQUATE CORE COOLING DURING A LOCA. ACTUATION OF THE ECCS IS NOT REQD FOR RH/A, CV/A, AF, OR AB.
WBN-1-NTR -074-0020	-B 1-NTR -074-0020	-B RHR PUMP NTR	VSW1	VAS		676'	A10	54114-1	L RH/A CV/A AF AB	A C C C C	1000	THESE PMPs FUNCTION AS PART OF THE ECCS TO ENSURE ADEQUATE CORE COOLING DURING A LOCA. ACTUATION OF THE ECCS IS NOT REQD FOR RH/A, CV/A, AF, OR AB.

PAGE A-2

\* FLOOR/ACTUAL ELEVATION - ACTUAL ELEVATIONS ARE DOCUMENTED ON FIELD VERIFICATION SHEETS AND FOUND IN TAB F.

PREPARER/DATE *[Signature]* \_\_\_\_\_ R \_\_\_\_\_ R \_\_\_\_\_ R \_\_\_\_\_  
 CHECKER/DATE *[Signature]* 7/30/86 \_\_\_\_\_

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 1 OF 27  
BINDER TITLE WESTINGHOUSE MOTORS COMPUTED RF DATE 7/10/86 R     R      
ON RHR, CVCS, CS, and SIS CHECKED WJK DATE 7/21/86

A. DOCUMENTATION

Equipment Description CS, RHR, SIS, and CVCS pump motors  
Vendor/Manufacturer Westinghouse  
Equipment Model No.(s) See TAB A for a complete listing of  
the equipment covered by this report.

QUALIFICATION REPORTS

- WCAP-8687
- \* (1) Title/Number/Revision EQTR-A02A, Rev. 2 RIMS B43 850401 304  
"Equipment Qualification Test Report  
Westinghouse LMD Motor Ins." DATE March 1983  
NEB
- (2) Title/Number/Revision WCAP-8754, RIMS 801215300  
"Environmental Qualification of Class 1E Motor  
for Nuclear Out-of-Containment Use." DATE June 1976  
WCAP-8587
- (3) Title/Number/Revision EODP AE-2, Rev. 5 RIMS B43 850401 303  
"Environmental Qualification Data Package  
Large Pump Motors (outside containment)." DATE March 1983

OTHER (ANALYSIS, VENDOR DATA, ETC.) Application Data 3170;  
EPRI Report NP-1447, Project 893-1, dated July 1980, pgs. 3-14  
through 3-20; EPRI Report NP-4172SP dated August 1985  
(See "Lubricants" - TAB C);  
EPRI Report NP-3887 dated February 1985 (TAB G), Environmental  
drawings - 47E235-74, 79, and 81; WBN Equipment List; Westinghouse  
Report EQ&T-EQT-3592 Rev. 0. WBN Cat. and Op times for system; 62  
(WBNOSG4-13-R7 B45 860320 223), 63 (WBNOSG4-14-R9 B45 860314 219), 72  
(WBNOSG4-19-R3 B45 860121 225), and 74 (WBNOSG4-020-R6 B45 860307 218).

\*WCAP-8687 is the only test report used for qualification purposes. However, WCAP-8754 and -8587 were included because they contain useful information on Westinghouse motors.

PAGE B-1

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 2 OF 27  
BINDER TITLE WESTINGHOUSE MOTORS COMPUTED RF DATE 9/18/86 R     R      
ON RHR, CVCS, CS, and SIS CHECKED WBK/AWT DATE 9/19/86

B. CONCLUSION OF REVIEW (Check only one block)

- Equipment Qualified Pending Resolution of All Open Items.  
 Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule  
 Equipment Qualification Not Established by Documentation  
 Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES See Open Items in front of binder.

- 1 - SCR EEB8618 must be resolved (see Open Item No. 6).  
2 - Watts Bar must supply termination data (see Open Item No. 1).  
3 - Watts Bar must supply documentation on installed motors  
S.O. No. 78F35296 and 79F55979 (see Open Item No. 5).

COMMENTS/RECOMMENDATIONS \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 3 OF 27

BINDER TITLE WESTINGHOUSE MOTORS COMPUTED [Signature] DATE 7/10/86 R     R    

ON RHR, CVCS, CS, and SIS CHECKED [Signature] DATE 7/21/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

       Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)

  X   Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of IE Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET  
NEMA Standard MG1-1972, IEEE 275-1966, IEEE 112A-1964, IEEE 344-1975,

Reg. Guide 1.89.  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 4 OF 27

BINDER TITLE WESTINGHOUSE MOTORS COMPUTED RCF DATE 7/30/86 R      R     

ON RHR, CVCS, CS, and SIS CHECKED AKK DATE 7/30/86

D. QUALIFICATION METHODOLOGY (Check only one block)

     Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis

     Test of Similar Items with Supporting Analysis

  X   Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions

     Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS The qualification of these motors is based on a Westinghouse test in which only a stator was subjected to environmental testing. Westinghouse denotes that only the thermalastic epoxy insulation system is the limiting material in these motors. The effects of accident conditions on lubricants, bearings, and interfaces are discussed in TAB C and are qualified by analysis. Westinghouse has provided a materials comparison on the tested stator versus the TVA motors. This comparison is discussed in TAB C, "Similarity."

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 5 OF 27

BINDER TITLE WESTINGHOUSE MOTORS COMPUTED RF DATE 7/30/86 R     R    

ON RHR, CVCS, CS, and SIS CHECKED WNR DATE 7/30/86

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? No  
See Section A and C.

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Motor(s)</u>	<u>Stator</u>	<u>WCAP-8687</u> <u>page 2</u>
(2) Manufacturer	<u>Westinghouse</u>	<u>Same</u>	<u>WCAP-8687</u> <u>page 2</u>
(3) Model Number(s)	<u>See TAB C</u>	<u>S.O.# 76F60185</u>	<u>WCAP-8687</u> <u>page 2</u>
	<u>                    </u>	<u>                    </u>	<u>                    </u>
	<u>                    </u>	<u>                    </u>	<u>                    </u>
	<u>                    </u>	<u>                    </u>	<u>                    </u>
(4) Serial Number(s)	<u>See TAB C</u>	<u>1S-78</u>	<u>                    </u>
	<u>                    </u>	<u>                    </u>	<u>                    </u>
	<u>                    </u>	<u>                    </u>	<u>                    </u>
	<u>                    </u>	<u>                    </u>	<u>                    </u>
(5) Identify Component- Unique checksheet attached:	<u>Supplement 1, pages 26 and 27 of this tab.</u>		

JUSTIFICATION/COMMENTS TAB C provides a comparison between  
the W test stator and the TVA motors. A discussion is provided  
for all items which are not the same.

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 6 OF 27  
 BINDER TITLE WESTINGHOUSE MOTORS COMPUTED [Signature] DATE 7/10/86 R     R      
ON RHR, CVCS, CS, and SIS CHECKED [Signature] DATE 7/21/86

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the test report and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if No, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	<u>*None</u>	<u>Yes</u>	<u>   </u>
External Process Connections	<u>*None</u>	<u>N/A</u>	<u>   </u>
Electrical Connections	<u>*None</u>	<u>Yes</u>	<u>   </u>
Conduit Seals	<u>None</u>	<u>No</u>	<u>   </u>
Connector Seals	<u>None</u>	<u>N/A</u>	<u>   </u>
Orientation	<u>*Vertical or Horizontal</u>	<u>Yes</u>	<u>   </u>
Physical Configuration	<u>None</u>	<u>N/A</u>	<u>   </u>
Other	<u>None</u>	<u>   </u>	<u>   </u>

JUSTIFICATION/COMMENTS \*The W test was performed only on a stator not the motor assembly as a whole. The interfaces listed above have been analyzed and are noted in TAB C.

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 7 OF 27  
 BINDER TITLE WESTINGHOUSE MOTORS COMPUTED REF DATE 7/18/86 R     R      
 ON RHR, CVCS, CS, and SIS CHECKED WJK DATE 7/21/86

G. TEST SEQUENCE

(1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>Yes</u>	<u>Pg. 7 of WCAP-8687</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>Table 4 of WCAP-8687</u>
(c) Equipment aged:		
Thermal	<u>Yes</u>	<u>Pg. 7 of WCAP-8687</u>
Radiation	<u>Yes</u>	<u>Pg. 8 of WCAP-8687</u>
Wear	<u>No</u>	<u>                    </u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>Pg. 6&amp;8 of WCAP-8687</u>
(e) Design basis event (DBE) exposure (radiation and humidity)	<u>Yes</u>	<u>Pg. 8&amp;9 of WCAP-8687</u>
(f) Post-DBE exposure	<u>N/A</u>	<u>                    </u>
(g) Final inspection and disassembly	<u>No</u>	<u>                    </u>

(2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes

(3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? No  
 (Reference Table 1 and 2 of WCAP-8687 ).

JUSTIFICATION/COMMENTS (1)Wear arings was not defined as a pretest requirement. Following completion of the test, the stator was subjected to a series of electrical tests which proved the reliability of the insulation system. (2)Complete calibration data was not included within the text of the qualification report. However, this information is on file at Westinghouse and is available for audit.

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 8 OF 27  
 BINDER TITLE WESTINGHOUSE MOTORS COMPUTED RCF DATE 7/30/86 R     R      
 ON RHR, CVCS, CS, and SIS CHECKED WOMK DATE 7/30/86

H. AGING

- (1) Was aging considered in the qualification program (Yes/no/NA)? Yes (Reference Pg. 7&8 of WCAP-8687 ).

JUSTIFICATION/COMMENTS The test stator was subjected to thermal, radiation, and vibration aging.

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>Pg. 7 of WCAP-8687</u>
Radiation exposure	<u>Yes</u>	<u>Pg. 8 of WCAP-8687</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>Pg. 6 &amp; 8 of WCAP-8687</u>
Operational (electrical/mechanical/process) stress aging	<u>No</u>	<u>                    </u>

JUSTIFICATION/COMMENTS Only a stator was tested.

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? N/A (Reference                      ).

JUSTIFICATION/COMMENTS Based on available information, no known synergistic effects exist in these motors.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program (yes/no/NA)? Yes (Reference Pg. 7 of WCAP-8687 ).

JUSTIFICATION/COMMENTS Only two materials were identified as being significantly affected by thermal aging; they are the thermalastic epoxy insulation and motor lubricant. Since the motor lubricant is sampled and replaced periodically, only the insulation was subjected to thermal aging.

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 9 OF 27  
 BINDER TITLE WESTINGHOUSE MOTORS COMPUTED [Signature] DATE 2/10/86 R     R      
 ON RHR, CVCS, CS, and SIS CHECKED [Signature] DATE 2/21/86

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes (Reference: Pg. 7 of WCAP-8687 & TAB C ).

JUSTIFICATION/COMMENTS Thermalastic Epoxy insulation, see "Similarity" in TAB C.

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference Pg. 2&3 of WCAP-8687 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference Pg. 7 of WCAP-8687 ).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	<u>104°F or 40°C</u>	<u>210°C</u>	<u>See TAB C</u>
Time	<u>40 Years Normal</u>	<u>168hrs</u>	<u>See TAB C</u>

JUSTIFICATION/COMMENTS See TAB C

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference Pg. 7 of WCAP-8687 ).

JUSTIFICATION/COMMENTS See TAB C

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? Yes (Reference Pg. 7 of WCAP-8687 ).

JUSTIFICATION/COMMENTS Activation energy of 1.11 ev was derived from tests performed as required by IEEE-275-1966.









BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 13 OF 27  
 BINDER TITLE WESTINGHOUSE MOTORS COMPUTED [Signature] DATE 7/2/86 R     R      
ON RHR, CVCS, CS, and SIS CHECKED [Signature] DATE 7/2/86

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of EQC Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>See TAB C</u>	<u>(Similarity)</u>	<u>   </u>	<u>   </u>	<u>   </u>
(b) <u>   </u>	<u>   </u>	<u>   </u>	<u>   </u>	<u>   </u>
(c) <u>   </u>	<u>   </u>	<u>   </u>	<u>   </u>	<u>   </u>
(d) <u>   </u>	<u>   </u>	<u>   </u>	<u>   </u>	<u>   </u>
(e) <u>   </u>	<u>   </u>	<u>   </u>	<u>   </u>	<u>   </u>

JUSTIFICATION/COMMENTS Provided in TAB C.

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 14 OF 27

BINDER TITLE WESTINGHOUSE MOTORS COMPUTED RF DATE 7/18/86 R     R    

ON RHR, CVCS, CS, and SIS CHECKED [Signature] DATE 7/2/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

(1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference WCAP-8687, pgs. 3 and 12 ).

Identify Acceptance Criteria: The tested stator must measure greater than 5 megohms when subjected to a 2500 VDC megger and must pass a 6000 VAC hipot for one minute.

(2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference Sect. 5.1, pg. 7 of WCAP-8687 ).

Identify baseline and functional testing: Before and after each major test sequence, the resistance of the stator insulation was measured and the ambient temperature recorded. Resistance was measured using a 2500 VDC megger where the stator leads were tied together. The voltage was applied for 10 minutes and measurements taken at 15, 30, 45, 60, 90, and 120 seconds and at 1 minute intervals thereafter until test completion. Also see above.

JUSTIFICATION/COMMENTS \_\_\_\_\_

(3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? No (Reference \_\_\_\_\_ ).

JUSTIFICATION/COMMENTS Only a stator was tested; therefore, operational loading conditions could not be addressed. However, the stator passage of the electrical test described in WCAP-8687 demonstrates that the insulation system had shown no signs of significant wear and verified its integrity.

PAGE B-14



BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 16 OF 27

BINDER TITLE WESTINGHOUSE MOTORS COMPUTED [Signature] DATE 7/10/86 R     R    

ON RHR, CVCS, CS, and SIS CHECKED [Signature] DATE 7/21/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

<u>(5)(b) Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>
Voltage	_____	_____
Load	_____	_____
Frequency	_____	_____
Accuracy	N/A	_____
<u>Other(s)</u>	_____	_____
_____	_____	_____
_____	_____	_____

JUSTIFICATION/COMMENTS A discussion on these parameters is included  
in TAB C.

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 17 OF 27  
 BINDER TITLE WESTINGHOUSE MOTORS COMPUTED WJF DATE 7/12/86  
 ON RHR, CVCS, CS, and SIS CHECKED WJK DATE 7/21/86

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-74R1, -79R1, and -81R1.

(1) Normal Max	(2) Abnormal Max
(a) Temperature (°F) <u>104</u>	(a) Temperature (°F) <u>110</u>
(b) Pressure (psig) <u>ATM(-)</u>	(b) Pressure (psig) <u>N/A</u>
(c) Humidity (%) <u>80</u>	(c) Humidity (%) <u>90</u>
*(d) Radiation (rd) <u>3.6x10<sup>6</sup></u>	(d) Radiation (rd) <u>3.6x10<sup>6</sup></u>

\*Greatest value for any of the motors qualified in this binder.  
 (See TVA Calculation WBNNAL3-025, B45 860328 236)

(3) Process Interfaces: None

(4) State anticipated occurrence frequency and duration of abnormal conditions: Temperature and humidity - Up to 8 hours per excursion and less than 1 percent of plant life (excluding accident conditions).

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) <u>110 for 30 days</u> <u>104 for 70 days</u>	Accident type <u>LOCA</u>
(b) Pressure (psig) <u>N/A</u>	Accident type <u>LOCA</u>
(c) Humidity (%) <u>90</u>	Accident type <u>LOCA</u>
(d) Radiation (rd) <u>1x10<sup>7</sup></u>	Accident type <u>LOCA</u>
(e) Spray Type <u>None</u>	Accident type <u>LOCA</u>

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 18 OF 27  
 BINDER TITLE WESTINGHOUSE MOTORS COMPUTED RF DATE 9/7/86 R     R      
 ON RHR, CVCS, CS, and SIS CHECKED WBK/AWT DATE 9/17/86

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH. margin, etc.):

Under worse conditions of post-LOCA, the CVCS, RHR, and SIS motors are required to operate 100 days. The CS motors are required for 30 days.

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (yes/no/NA)? No (Reference See TAB C ).

(7) Subject to submergence (yes/no/NA)? No  
 (Reference See "Submergence" in TAB C ).

Identify initiation time and duration of submergence: \_\_\_\_\_  
 \_\_\_\_\_

(8) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
<u>WBN Flooding Calculation O/S</u>	
<u>Cntmt. WBN-OSG4-44</u>	<u>B45 860110 218</u>
<u>Areas with High Potential</u>	
<u>for Condensate Formation</u>	
<u>GENNAL6-002</u>	<u>B45 851017 235</u>
<u>Degraded Voltage Code</u>	
<u>WBP-EVAR-86-02001</u>	<u>B43 860227 901</u>
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____



BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 19 OF 27  
 BINDER TITLE WESTINGHOUSE MOTORS COMPUTED [Signature] DATE 7/18/86 R     R      
 ON RHR, CVCS, CS, and SIS CHECKED [Signature] DATE 7/21/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>100 Days</u>	<u>***48 Hours</u>	See L(3) this tab and Sec. 5.6 of <u>WCAP 8687.</u> See L(3) this tab and Sec. 5.6 of <u>WCAP 8687</u>
Temperature (°F)	<u>110</u>	<u>95</u>	See <u>TAB C</u> See TAB C and Sec. 5.6 of <u>WCAP 8687</u>
Pressure (psig)	<u>-0-</u>	<u>-0- ..</u>	See <u>TAB C</u> See TAB C and Sec. 5.6 of <u>WCAP 8687</u>
Relative Humidity (%)	<u>90</u>	<u>100</u>	See L(3) this tab and Sec. 5.6 of <u>WCAP 8687</u>
*Chemical Spray	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
**Radiation (rd)	<u>1.36x10<sup>7</sup></u> <u>gamma</u>	<u>5x10<sup>7</sup></u> <u>gamma</u>	See TAB C and Sec. 5.3 of <u>WCAP 8687</u>
Submergence	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

\*Includes spray concentration, flowrate, density, duration, and pH.

\*\*Enter 40-year integrated normal dose plus integrated accident dose and specify type.

\*\*\*Westinghouse subjected the test stator to a 100% relative humidity/environment for 48 hours. However, the TVA motors are not subject to this condition. The TVA motors are only subject to DBA radiation exposure with no appreciable increase in temperature, pressure, or humidity (see TAB C).

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	See <u>TAB C</u>
Pressure	<u>Yes</u>	See <u>TAB C</u>
Relative Humidity	<u>Yes</u>	See <u>TAB C</u>
Chemical Spray	<u>N/A</u>	<u>N/A</u>

PAGE B-19

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 20 OF 27  
 BINDER TITLE WESTINGHOUSE MOTORS COMPUTED [Signature] DATE 7/18/85 R     R      
 ON RHR, CVCS, CS, and SIS CHECKED [Signature] DATE 7/21/85

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

(3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, yes/no/NA)

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u> (Hot Spot Margin)
* Temperature: +15 degrees F	<u>40°F</u>	<u>Yes</u>
Pressure: +10% but no more than 10 psig	<u>N/A</u>	<u>N/A</u>
Radiation: +10% of accident dose	<u>267%</u>	<u>Yes</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>See TAB C</u>	
Voltage: ± 10% of rated value	<u>See TAB C</u>	
Frequency: ± 5% of rated value	<u>See TAB C</u>	
Environmental Transient: the initial transient and the peak temperature applied twice	<u>See TAB C and Below</u>	
Vibration: +10% added to acceleration	<u>See TAB C</u>	

JUSTIFICATION/COMMENTS: The accident parameters are not significantly different from the max. normal with the exception of radiation. TAB C provides a discussion on each of the parameters listed above. Only a stator was tested by Westinghouse. In addition, 0588-Category I requires the application of the environmental transient twice. 0588-Category II does not.

\* A 15°C (40°F) hot spot margin was added to the stator temperature as calculated in TAB C. This margin provides conservatism for the Arrhenius aging analysis.

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 21 OF 27

BINDER TITLE WESTINGHOUSE MOTORS COMPUTED [Signature] DATE 7/21/86 R     R    

ON RHR, CVCS, CS, and SIS CHECKED [Signature] DATE 7/21/86

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:  
(Reference See TAB A ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? N/A  
(Reference \_\_\_\_\_ ).

JUSTIFICATION/COMMENTS Only a stator was tested.  
\_\_\_\_\_  
\_\_\_\_\_

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? N/A  
(Reference \_\_\_\_\_ ).

JUSTIFICATION/COMMENTS Only a stator was tested.  
\_\_\_\_\_  
\_\_\_\_\_

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? No (Reference \_\_\_\_\_ ).

JUSTIFICATION/COMMENTS Only a stator was tested.  
\_\_\_\_\_  
\_\_\_\_\_

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? N/A  
(Reference \_\_\_\_\_ ).

JUSTIFICATION/COMMENTS No abnormal conditions or anomalies were identified.  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 23 OF 27  
 BINDER TITLE WESTINGHOUSE MOTORS COMPUTED [Signature] DATE 7/10/86 R     R      
ON RHR, CVCS, CS, and SIS CHECKED [Signature] DATE 7/21/86

0. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
(1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
(2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>N/A</u>
(3) Choice of qualification methodology adequately justified?	<u>Yes</u>
(4) If analysis was performed, complete the following:	
(a) Were equipment performance requirements identified?	<u>Yes</u>
(b) Were specific features and failure modes and effects analyzed?	<u>Yes</u>
(c) Were assumptions and mathematical models used together with appropriate justification for their use?	<u>Yes</u>
(d) Were environmental parameters which affect equipment performance identified?	<u>Yes</u>
(5) Adequate similarity between equipment and test specimen established?	<u>Yes</u>
(6) Aging degradation evaluated adequately?	<u>Yes</u>
(a) Mechanical and/or cycle aging addressed?	<u>Yes</u>
(b) Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes</u>
(c) Absence of preaging in test/analysis justified?	<u>N/A</u>
(d) Materials susceptible to thermal/radiation aging identified?	<u>Yes</u>

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 24 OF 27  
 BINDER TITLE WESTINGHOUSE MOTORS COMPUTED WPK DATE 7/2/86 R     R      
ON RHR, CVCS, CS, and SIS CHECKED WPK DATE 7/2/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>N/A</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>N/A</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>N/A</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>N/A</u>
(11) Criteria regarding submergence satisfied?	<u>N/A</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>N/A</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>N/A</u>

PAGE B-24

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 25 OF 27  
 BINDER TITLE WESTINGHOUSE MOTORS COMPUTED WJK DATE 7/21/86 R     R      
ON RHR, CVCS, CS, and SIS CHECKED WJK DATE 7/21/86

O. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(15) Criteria regarding functional testing satisfied?	<u>Yes</u>
(a) Does the test plan/report specify an acceptance criteria for equipment performed?	<u>Yes</u>
(b) Was an initial base line test done to establish required performance characteristics?	<u>Yes</u>
(c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured?	<u>Yes</u>
(16) Criteria regarding instrument accuracy satisfied?	<u>N/A</u>
(17) Test duration margin (1 hour + function time) satisfied?	<u>*No</u>
(a) Is the minimum specified operating time at least 1 hour?	<u>N/A</u>
(b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided?	<u>Yes</u>
(18) Criteria regarding synergistic effects satisfied?	<u>Yes</u>
(19) Criteria regarding margins satisfied?	<u>Yes</u>
(20) Maintenance and surveillance requirements adequately identified?	<u>Yes</u>

P. DISCUSSION

\*See TABS C and G. The accident conditions are not significantly different from the max. normal with the exception of radiation; therefore, the major concern is radiation and aging. TAB C provides a detailed discussion on each. Based on the analysis provided in TAB C along with this section, it is concluded that the motors covered by this report are qualified for 40 years plus 100 days post-accident.

PAGE B-25-

BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 26 OF 27  
 BINDER TITLE WESTINGHOUSE MOTORS COMPUTED RCF DATE 7/30/86 R     R      
 ON RHR, CVCS, CS, and SIS CHECKED WWR DATE 7/30/86

SUPPLEMENT 1  
 COMPONENT-UNIQUE CHECKLIST  
 MOTORS

Page 1 of 2

EQUIPMENT IDENTIFICATION

(1) Is the motor identified in the qualification report identical to the plant motors which require qualification (yes/no/NA)? No (Similar)

<u>Item</u>	<u>Plant</u>	<u>Report</u>	<u>Acceptable (Yes/No/NA)</u>	<u>Report Section</u>
(a) Insulation system materials	Thermalastic <u>Epoxy</u>	<u>Same</u>	<u>Yes</u>	See <u>TAB C</u>
(b) Coil construction (form or random wound, cast)	<u>Form</u>	<u>Form</u>	<u>Yes</u>	Form 3170 (See Section E7) See
(c) Insulation class (B, F, H)	<u>B</u>	<u>B</u>	<u>Yes</u>	TAB C and <u>WCAP-8687</u>
(d) Lubricant				
Manufacturer	<u>Var.</u>	<u>Var.</u>	<u>Yes</u>	See TAB <u>C and E</u>
Type	<u>*STO-2</u>	<u>Var.</u>	<u>Yes</u>	See <u>TAB C</u>
(e) Bearing				
Manufacturer	Westing- <u>house</u>	Westing- <u>house</u>	<u>Yes</u>	See <u>TAB C&amp;E</u>
Type	Split Sleeve & <u>Ball</u>	<u>N/A</u>	<u>Yes</u>	See <u>TAB C&amp;E</u>
Bearing life	See <u>Sec C</u>	<u>N/A</u>	<u>Yes</u>	See <u>TAB C&amp;E</u>
(f) Seals				
Manufacturer	<u>Unknown</u>	<u>Unknown</u>	<u>Yes</u>	<u>Seals are metallic</u>
Type	<u>Metal</u>	<u>Metal</u>	<u>Yes</u>	<u>See (5) on next pg</u>
Material	<u>Brass</u>	<u>Brass</u>	<u>Yes</u>	<u>See (5) on next pg</u>

\*STO-2 is a generic designator for Turbine Oils procured by TVA. See procurement specification 18.009 and TAB C.

PAGE B-26



BINDER NO. WBNEQ-MOT-001 PLANT WBN UNIT(S) 1 SHEET 27 OF 27  
 BINDER TITLE WESTINGHOUSE MOTORS COMPUTED RF DATE 7/30/86 R     R      
 ON RHR, CVCS, CS, and SIS CHECKED WMA DATE 7/30/86

EQUIPMENT IDENTIFICATION (Continued)

Page 2 of 2

<u>Item</u>	<u>Plant</u>	<u>Report</u>	<u>Acceptable (Yes/No/NA)</u>	<u>Report Section</u>
(g) Motor lead insulation	<u>Same</u>	Treated Glass <u>Sleeving</u>	<u>Yes</u>	See <u>TAB C</u>

Comments: \_\_\_\_\_  
 \_\_\_\_\_

- (2) Does the qualification report indicate that the motorette insulation system is the same as that used on the motors (yes/no/NA)? N/A  
 (Reference See TAB C "Similarity" & Sections E11, E12, and E13 ).

Comments: Qualification testing was not performed on a motorette,  
but a full size stator.

- (3) Has the vendor provided the bearing rating (yes/no/NA)? Yes  
 (Reference TAB E ).

Comments: Motor Data Sheets

- (4) Was the lubricant included in the test program (yes/no/NA)? No  
 (Reference Pg. 2 of WCAP-8687 ).

Comments: Motor lubricant is qualified separately in TAB C.

- (5) Were the seals included in the test program (yes/no/NA)? No  
 (Reference See WCAP-8754, pg. 8-4, paragraph 6, TAB D ).

Comments: Only a stator was tested. The seals are brass construc-  
tion and are not age sensitive or susceptible to radiation  
degradation.

TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL NO.	LOCATION			CONTRACT	EVENT	CAT	OPER TIME	SAFETY FUNCTION
				COL/AZ	ELEV	RM/RAD					
WEN-1-MIR-030-0038	-A 1-MIR-30-38-A	Containment Air Return Fan Motors	42.25-26.5-1770	250°	733'1"	RB	77K35-83165	L	A	100D	Motors start on a phase B containment isolation signal and must operate for duration of the event. Fans enhance ice condenser and containment spray heat removal and limit hydrogen build-up in stagnant regions.
								MS/C	A	100D	
								FW/C	A	100D	
								RU/C	A	1MO	
								CV/C	A	1MO	
WEN-1-MIR-030-0039	-B 1-MIR-30-39-B	Containment Air Return Fan Motors	42.25-26.5-1770	297°	740'11"	RB	77K35-83165	L	A	100D	Motors start on a phase B containment isolation signal and must operate for duration of the event. Fans enhance ice condenser and containment spray heat removal and limit hydrogen build-up in stagnant regions.
								MS/C	A	100D	
								FW/C	A	100D	
								RU/C	A	1MO	
								CV/C	A	1MO	

PAGE A-1

Preparer/Date L. d. Leonard 6-9-86  
 Checked/Date W. B. King 7/1/86

BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 1 OF 29  
BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED H. Hayward DATE 6-9-86 R     R      
INSULATION-INSIDE CONTAINMENT CHECKED WBE/PA DATE 7/1/86

A. DOCUMENTATION

Equipment Description Squirrel-Cage Induction Motor  
Vendor/Manufacturer Joy Fan/Reliance Electric  
Equipment Model No.(s) 100hp, 460 VAC, 3ph, 60 Hz, 1800rpm  
Type RN Insulation  
Inside Containment

\* QUALIFICATION REPORTS

- (1) Title/Number/Revision Qualification Testing of RIMS NEB 831213 426  
Joy Axivane Fan & Reliance Electric Motor  
Report X-604, Rev. 2 (TAB D, Section D-1) DATE 3-20-80
- (2) Title/Number/Revision Type Test Support Analy- RIMS EEB 820602 304  
sis Random Wound Motors, Report NUC-9 + Supplement,  
Rev. 2 (TAB D, Section D-2) DATE 7-1-78/7-15-81
- (3) Title/Number/Revision End of Life Type Test- RIMS B43 850919 500  
Random Wound Motors, Report NUC 22, Rev. 2 DATE 2-10-84  
(TAB D, Section D-3)

OTHER (ANALYSIS, VENDOR DATA, ETC.) Material Aging Calculation WAC-50  
(TAB C, Att. 1), Material Aging Calculation WAC-56 (TAB C, Att. 2),  
Certificate of Similarity (TAB E, Div. 1), Letter from D. L. Kitchel to  
Joy Mfg. dated May 9, 1986; B71 860509 002 (TAB E, Div. 2), Joy L-10  
Bearing Life Calculation (TAB E, Div. 1), Joy Report S-1 (TAB E, Div. 1),  
Joy Proposal Correspondence (TAB E, Div. 3).

- \* Qualification Report 1 is the base document for qualification of the motors  
listed in TAB A to Class 1E service. Report 2 is a summary report of type  
test support analysis for 1E motors in normal service, excluding in-contain-  
ment type transients. Report 3 is included to support radiation withstand  
capability claims for the insulation systems provided with the motors  
listed in TAB A.

PAGE B-1



BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 3 OF 29  
BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L.L. Loggins DATE 6-2-86 R     R      
INSULATION-INSIDE CONTAINMENT CHECKED W.D. New DATE 6/14/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate All Documents Which are Applicable):

  X   Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)

       Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE 334-1974, Type Test of Continuous Duty Class 1E Motors

NEMA MG1-1967, Motors and Generators

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_





BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 6 OF 29  
 BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L. L. Hayward DATE 6-9-86  
 INSULATION-INSIDE CONTAINMENT CHECKED W. B. For DATE 7/1/86

F. INSTALLATION INTERFACES

Does the qualification program address all relevant interfaces of the equipment so that the installed design and configuration is similar or identical to the test configuration (yes/no/NA)? (note below)

<u>Interface</u>	<u>Identify Interface Requirement</u>	<u>Acceptable? (Yes/No/NA)</u>	<u>Reference Test Report</u>
Mounting Bolts	Plant-Bolted C face mtr w/4 add. threaded stud bolts test-std mtg	Yes	TAB E, Div 1, Joy Rpt S-1, pg. 32, 42, 45 TAB I, Dwg FF14650, Dwg. FF14598.
External Process Connections	N/A	N/A	
Electrical Connections	Refer to Note 1 Below	Yes	Qual Rpt 1, pg. 2
Conduit Seals	Plant - N/A/Test - None	N/A	Refer to Note 2
Connector Seals	None	N/A	
Orientation	Plant - Vertical/Test- Horizontal	Yes	Qual Rpt 1, App. E, pg. 2
Physical Configuration	Test - Typ outer casing, vanes dnstr of fan, w/ mtr mtd in ctr of casing/Plant - Identical	Yes	Qual Rpt 1, pg. 2
Other	Breather drains installed at motor lowpoint	Yes	TAB H, B-3620-8, pg. 5

PAGE B-6



BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 7 OF 29

BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L.H. Leonard DATE 6-9-86 R     R    

INSULATION-INSIDE CONTAINMENT CHECKED M. B. King DATE 7/1/86

F. INSTALLATION INTERFACES (Continued)

JUSTIFICATION/COMMENTS \_\_\_\_\_

Note 1: During the LOCA simulation, leads were connected inside the pres-  
sure chamber to terminal studs protruding through insulating and sealing  
plate. Plant terminations are made inside a terminal box using materials  
analyzed in 600 volts and below, Type NMCK Motor Connection Kit.

Note 2: During LOCA simulation, no attempt was made to prevent chemical  
spray and moisture from entering the motor lead conduit (reference TAB E,  
Div. 2, Joy/TVA Telecon Confirmation Letter).

BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 8 OF 29  
 BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L.S. Raymond DATE 6-9-86 R     R      
 INSULATION-INSIDE CONTAINMENT CHECKED W.B. [Signature] DATE 6/12/86

G. TEST SEQUENCE

(1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>No</u>	<u>TAB C, Sec 4.1</u> <u>Qual Rpt 1,</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>Appendix E, p 2</u>
(c) Equipment aged:		
Thermal	<u>Yes</u>	<u>Qual Rpt 1,</u> <u>page 5</u>
Radiation	<u>No</u>	<u>Qual Rpt 1,</u> <u>page 4</u>
Wear	<u>No</u>	<u>TAB C, Sec</u> <u>4.2.4</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>Qual Rpt 1,</u> <u>pages 7-11</u>
(e) Design basis event (DBE) exposure	<u>Yes</u>	<u>Qual Rpt 1,</u> <u>pages 12-16</u>
(f) Post-DBE exposure	<u>Yes</u>	<u>Qual Rpt 1,</u> <u>page 17</u>
(g) Final inspection and disassembly	<u>Yes</u>	<u>Qual Rpt 1,</u> <u>page 18</u>

- (2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes
- (3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes  
 (Reference Qual Rpt 1, App A, p 11 ).

JUSTIFICATION/COMMENTS Test equipment accuracies and calibration data  
are not significant in establishing continued operability of the motor.

BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 9 OF 29  
 BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L.L. Reynolds DATE 6-9-86 R     R      
 INSULATION-INSIDE CONTAINMENT CHECKED W.H. Vero DATE 7/1/86

H. AGING

- (1) Was aging considered in the qualification program (Yes/no/NA)? Yes (Reference Qual Rpt 1, page 5 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	<u>Qual Rpt 1, page 5</u>
Radiation exposure	<u>Yes</u>	<u>Qual Rpt 1, page 4</u>
Vibration (non-seismic) aging	<u>Yes</u>	<u>Refer to TAB C, Sec 4.2.4</u>
Operational (electrical/mechanical/process) stress aging	<u>No</u>	<u>Refer to TAB C, Sec 4.2.4</u>

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? NA (Reference \_\_\_\_\_ ).

JUSTIFICATION/COMMENTS There are no known synergistic effects based on review of the materials of construction for this motor.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program (yes/no/NA)? Yes (Reference Qual Rpt 1, page 5 ).

JUSTIFICATION/COMMENTS Motor aged in vertical non-rotating position. Accelerated aging involved aging motor at a temperature of 415°F (213°C) for 108 hours.

BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 10 OF 29

BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED R. H. Hayward DATE 6-7-86 R     R    

INSULATION-INSIDE CONTAINMENT CHECKED W. B. [unclear] DATE 6/10/86

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes  
(Reference: Qual Rpt 2, pages 3-7, 19, 20 ).

JUSTIFICATION/COMMENTS For a listing of materials in RN insulation system, see Qual Rpt 1, App F.

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference Qual Rpt 1, page 5 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference Qual Rpt 1, pages 5 and 6 ).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	<u>TAB C, Sec 4.2.1</u>	<u>213°C</u>	<u>105°C</u>
Time	<u>TAB C, Sec 4.2.1</u>	<u>100 hrs</u>	<u>350,000 hrs</u>

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference \_\_\_\_\_ ).

JUSTIFICATION/COMMENTS Refer to TAB C, Section 4.2.1

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? NA  
(Reference \_\_\_\_\_ ).

JUSTIFICATION/COMMENTS Activation energies were used to establish qualified life and are referenced in TAB C, Sec 5.0.

BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 11 OF 29  
BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L.L. Raymond DATE 6-9-86 R     R      
INSULATION-INSIDE CONTAINMENT CHECKED WJH/PLM DATE 6/12/86

H. AGING (Continued)

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? Yes (Reference Qual Rpt 1, page 6 Qual Rpt 2, "Supplement" Pg 3 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (h) Was the equipment operated during the thermal aging (yes/no/NA)? No (Reference \_\_\_\_\_ ).

JUSTIFICATION/COMMENTS The effects of temperature rise during motor operation were accounted for in the establishment of qualified life for these motors. Refer to TAB C, Section 5.0 and WAC-50.

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (yes/no/NA)? Yes (Reference Qual Rpt 1, Pg 4 ).

JUSTIFICATION/COMMENTS Irradiation was considered unnecessary because tests conducted on the motor components show that direct damage to materials is negligible at levels considered. Refer to TAB C, Section 4.2.2 for additional information.

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (yes/no/NA)? Yes (Reference Qual Rpt 1, Appendix F ).

JUSTIFICATION/COMMENTS Refer to TAB C, Section 4.2.2 for additional justification.

- (c) Was the basis for radiation aging exposure identified in the qualification program (yes/no/NA)? NA (Reference \_\_\_\_\_ ).

JUSTIFICATION/COMMENTS Refer to TAB C, Section 4.2.2 for additional justification.

PAGE B-11





BINDER NO WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 14 OF 29  
 BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L.S. Kay DATE 6-8-86 R     R      
 INSULATION-INSIDE CONTAINMENT CHECKED W.B. Kay DATE 6/1/86

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of EQC Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>Type RN insulation system</u>	<u>-</u>	<u>Note 1</u>	<u>1.17</u>	<u>TAB C, Att. 1</u>
(b) <u>Bearing lubricant (Chevron SRI-2 grease)</u>	<u>2 x 10<sup>8</sup></u>	<u>Qual Rpt 1, App. F, P 7</u>	<u>NA</u>	<u>-</u>
(c) _____	_____	_____	_____	_____
(d) _____	_____	_____	_____	_____
(e) _____	_____	_____	_____	_____

JUSTIFICATION/COMMENTS

Note 1: Analysis of test data on insulation components show that direct damage to materials is negligible at greater radiation doses than experienced by TVA motors. Type RH insulation, which is similar to type RN, has withstood a total radiation dose of 2.2 x 10<sup>8</sup> RADS and maintained its ability to perform its required function. Refer to TAB C, Section 4.2.2 for additional information.



BINDER NO. WBNEQ-MOT-002 PLANT WBN UNIT(S) 1 SHEET 15 OF 29  
BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED Lab Raymond DATE 6-9-86 R     R      
INSULATION-INSIDE CONTAINMENT CHECKED WB Khan DATE 7/2/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference Qual Rpt 1, pages 5-19).

Identify Acceptance Criteria: Motor/fan assembly must operate during and after a simulated DBE described on page 16, following accelerated thermal aging and seismic testing.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference Qual Rpt 1, App. A).

Identify baseline and functional testing: During DBE testing, several conditions were monitored and periodically recorded as indicated in the referenced document. Continued motor operability or a lack thereof was the sole failure criteria.

JUSTIFICATION/COMMENTS Refer to Tab C, Sections 4.1, 4.3.1, and 10.0, Qualification Report X-604, Appendix A (TAB D).

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes (Reference Qual Rpt 1, pages 13-15).

JUSTIFICATION/COMMENTS In a telecon between Bob Raymond of TVA and Tom Bissett of Joy on 5-8-86, (TAB E, Div. 2), it was confirmed that the motor/vaneaxial fan assembly was operated under low speed conditions, 75 hp, 590 rpm, during the DBE simulation. A bypass loop was provided to allow for recirculation of fan air flow.

BINDER NO WBNEQ-MOT-002 PLANT WBN UNIT(S) 1 SHEET 16 OF 29

BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L.H. Berglund DATE 6-9-86 R     R    

INSULATION-INSIDE CONTAINMENT CHECKED W.B. King DATE 4/2/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

(4) Do the applied loads during baseline testing reflect normal operating conditions (yes/no/NA)? Yes (Reference Qual. Rpt. 1,

Appendix E, page 2 )

JUSTIFICATION/COMMENTS Baseline testing conditions were equal to or more severe than normal operating conditions.

(5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

<u>(a) Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference</u>
Voltage	<u>(1)453.13 VAC (2)458.38 VAC</u>	<u>WBP EVAR 86 02001, Sheets D165 &amp; D225</u>
Load	<u>Refer to Note 1, Sheet 17</u>	<u>TAB C,</u>
Frequency	<u>60 Hz</u>	<u>Sect. 7.0</u>
Accuracy	<u>N/A</u>	<u>   </u>
<u>Other(s)</u>	<u>   </u>	<u>   </u>
<u>   </u>	<u>   </u>	<u>   </u>
<u>   </u>	<u>   </u>	<u>   </u>

JUSTIFICATION/COMMENTS Minimum accident voltages for motors 1-MTR-30-38-A and -39-B (453.13 VAC and 458.38 VAC, respectively) are terminal voltages at T=15 secs. after a phase B containment isolation signal.

BINDER NO. WBNEQ-MOT-002 PLANT WBN UNIT(S) 1 SHEET 17 OF 29

BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L.S. Hayward DATE 6-9-86 R     R    

INSULATION-INSIDE CONTAINMENT \_\_\_\_\_ CHECKED W.B. Hoover DATE 7/2/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

<u>(5)(b) Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>
Voltage	<u>460 VAC</u>	<u>Qual. Rpt. 1, App. E, p3</u>
Load	<u>Refer to Note 1 below</u>	
Frequency	<u>60 Hz</u>	<u>Qual. Rpt. 1, App. E, p3</u>
Accuracy	<u>N/A</u>	
<u>Other(s)</u>		
_____	_____	_____
_____	_____	_____

JUSTIFICATION/COMMENTS Note 1 - Load consists of vaneaxial fans of similar design but of different size. Motors are sized by the fan manufacturer to ensure proper fan performance. TVA motors are rated 100 hp, 1800 rpm. The tested motor was a 2-speed motor rated 150/75 hp, 1200/600 rpm.

BINDER NO. WBNEQ-MOT-002 PLANT WBN UNIT(S) 1 SHEET 18 OF 29  
 BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L.L. Ayers DATE 9-5-86 R     R      
INSULATION-INSIDE CONTAINMENT CHECKED WBK/AWT DATE 9-5-86

**K. REQUIRED OPERATING ENVIRONMENT**

Reference Environmental Drawing No. 47E235-42, Rev. 2

(1) Normal Max

(a) Temperature (°F) 120°F  
 (0.3 psig)  
 (b) Pressure (psig) 14.7 psia  
 (c) Humidity (%) 80%  
 $2 \times 10^7$   
 (d) Radiation (rd) RADS MAX

(2) Abnormal Max

(a) Temperature (°F) 130°F  
 (0.3 psig)  
 (b) Pressure (psig) 14.7 psia  
 (c) Humidity (%) 100%  
 (d) Radiation (rd) --

(3) Process Interfaces: Fan mounted on motor shaft using a 3/4" x 3/4" key.

Motor is mounted to fan casing through 4 threaded stud bolts in the front section of the motor.

(4) State anticipated occurrence frequency and duration of abnormal conditions: 8 Hours per excursion and will occur less than 1% of the plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F)	<u>327°F</u> (11.2 psig)	Accident type <u>HELB (MSLB)</u>
(b) Pressure (psig)	<u>25.6 psia</u>	Accident type <u>LOCA</u>
(c) Humidity (%)	<u>100%</u> $4.7 \times 10^6$ Beta (refer to Sect. P)	Accident type <u>LOCA/HELB</u>
(d) Radiation (rd)	<u><math>4 \times 10^7</math> Gamma</u> Refer to	Accident type <u>LOCA</u>
(e) Spray Type	<u>Comments</u>	Accident type <u>LOCA/HELB</u>

BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 19 OF 29

BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L.L. Raymond DATE 6-9-86 R     R    

INSULATION-INSIDE CONTAINMENT CHECKED [Signature] DATE 6/12/86

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.):

Actual accident environment is a composite of several profiles. Refer to TAB C, Section 2.0, for additional details. Chemical spray is addressed in TAB C, Section 4.3.2.

(6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (yes/no/NA)? Yes (Reference TAB C, Sections 4.2.3 and 4.3.3 ).

(7) Subject to submergence (yes/no/NA)? No (Reference TAB C, Section 9.0 ).

Identify initiation time and duration of submergence: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

(8) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
<u>Inside Containment Flooding</u>	<u>NEB 840120 220</u>
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____

BINDER NO. WBNEQ-MOT-002 PLANT WBN UNIT(S) 1 SHEET 20 OF 29

BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L.L. Hayward DATE 9-5-86 R     R    

INSULATION-INSIDE CONTAINMENT \_\_\_\_\_ CHECKED WBK/AWT DATE 9-5-86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO REQUIRED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Required</u>	<u>Demonstrated</u>	<u>Reference</u>
Post-DBE Operating Time	<u>2400 hrs.</u>	<u>10,145 hrs.</u>	<u>Qual Rpt 1, page 17</u>
Temperature (°F)	<u>327°F</u>	<u>350°F peak. 330°F for 4 hours</u>	<u>Qual Rpt 1, pages 14 &amp; 15</u>
Pressure (psig)	<u>11.2</u>	<u>78</u>	<u>Qual Rpt 1, pg. 14, item 5a</u>
Relative Humidity (%)	<u>100%</u>	<u>100%</u>	<u>Qual Rpt 1, App. A., page 8</u>
*Chemical Spray	<u>Refer to TAB C, Section 4.3.2</u>		
**Radiation (rd)	<u>7 6x10 Gamma</u>	<u>Refer to TAB C, Sec 4.2.2</u>	
Submergence	<u>No</u>	<u>No</u>	<u>Refer to TAB C, Section 9.0</u>

\*Includes spray concentration, flowrate, density, duration, and pH.  
 \*\*Enter 40-year integrated normal dose plus integrated accident dose and specify type.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>L.(1) above</u>
Pressure	<u>Yes</u>	<u>L.(1) above</u>
Relative Humidity	<u>Yes</u>	<u>L.(1) above</u>
Chemical Spray	<u>Refer to TAB C, Section 4.3.2</u>	
Submergence	<u>NA</u>	

JUSTIFICATION/COMMENTS Additional discussion in TAB C, Section 5.0

BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 21 OF 29  
 BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L.S. Leonard DATE 6-9-86  
 INSULATION-INSIDE CONTAINMENT CHECKED W.S. [Signature] DATE 6/12/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

(3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, yes/no/NA)

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	<u>23°F</u>	<u>Yes</u>
Pressure: +10% but no more than 10 psig	<u>550% (AP=66psig)</u>	<u>Yes</u>
Radiation: +10% of accident dose	<u>Refer to WAC-50, pg. 5 (TAB C)</u>	<u>No</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>Refer to WAC-50, pg. 5 (TAB C)</u>	<u>Yes</u>
Voltage: +10% of rated value	<u>_____</u>	<u>No</u>
Frequency: +5% of rated value	<u>_____</u>	<u>No</u>
Environmental Transient: the initial transient and the peak temperature applied twice	<u>Refer to Qual Rpt 1, pgs 13-16</u>	<u>Yes</u>
Vibration: +10% added to acceleration	<u>+33%</u>	<u>Yes</u>

JUSTIFICATION/COMMENTS: For elaboration, refer to following sections of TAB C:

- Temperature Section 4.3.1
- Pressure Section 4.3.1
- Radiation Section 4.2.2
- Time Section 5.0
- \* Voltage Section 7.0 \* Also, See TAB E, Div. 2, Degraded Voltage Correspondence
- Frequency Section 7.0
- Vibration Section 4.2.4

BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 22 OF 29  
BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L.A. Hayward DATE 6-9-86 R      R       
INSULATION-INSIDE CONTAINMENT CHECKED W.H. / DATE 6/12/86

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:  
(Reference                      ).

JUSTIFICATION/COMMENTS Refer to TAB A  
\_\_\_\_\_  
\_\_\_\_\_

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes  
(Reference Qual Rpt 1, pgs. 13-16 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? Yes  
(Reference Qual Rpt 1, page 17 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? Yes (Reference Qual Rpt 1, p 17 ).

JUSTIFICATION/COMMENTS Per TAB A, TVA equipment required to operate for a period of 100 days. The equipment tested performed in post-DBE environment for 10,145 hours.  
\_\_\_\_\_

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? Yes  
(Reference                      ).

JUSTIFICATION/COMMENTS Refer to TAB C, Section 4.3.3  
\_\_\_\_\_





BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 24 OF 29  
 BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L.L. Long DATE 6-9-86  
 INSULATION-INSIDE CONTAINMENT CHECKED W. J. H. H. DATE 6/17/86

0. SUMMARY OF REVIEW

- |   | <u>Yes/No/NA</u> |
|---|------------------|
| (1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)? | <u>Yes</u>       |
| (2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?   | <u>Yes</u>       |
| (3) Choice of qualification methodology adequately justified?   | <u>Yes</u>       |
| (4) If analysis was performed, complete the following:  |                  |
| (a) Were equipment performance requirements identified?   | <u>Yes</u>       |
| (b) Were specific features and failure modes and effects analyzed?  | <u>Yes</u>       |
| (c) Were assumptions and mathematical models used together with appropriate justification for their use?  | <u>Yes</u>       |
| (d) Were environmental parameters which affect equipment performance identified?  | <u>Yes</u>       |
| (5) Adequate similarity between equipment and test specimen established?  | <u>Yes</u>       |
| (6) Aging degradation evaluated adequately?   | <u>Yes</u>       |
| (a) Mechanical and/or cycle aging addressed?  | <u>Yes</u>       |
| (b) Equipment aged to end of life condition prior to application of DBE conditions?   | <u>Yes</u>       |
| (c) Absence of preaging in test/analysis justified?   | <u>Yes</u>       |
| (d) Materials susceptible to thermal/radiation aging identified?  | <u>Yes</u>       |

BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 25 OF 29  
 BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L.L. Raymond DATE 6-9-86  
 INSULATION-INSIDE CONTAINMENT CHECKED W.H. Kiser DATE 6/12/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>Yes</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>Yes</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>Yes</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>No</u>
(11) Criteria regarding submergence satisfied?	<u>NA</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Yes</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

BINDER NO. WBNEQ-MOT-002 PLANT WBN UNIT(S) 1 SHEET 26 OF 29  
 BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED A. H. Reynolds DATE 9-5-86  
INSULATION-INSIDE CONTAINMENT CHECKED WBR/AWT DATE 9-5-86

O. SUMMARY OF REVIEW (Continued)

- (15) Criteria regarding functional testing satisfied? Yes
- (a) Does the test plan/report specify an acceptance criteria for equipment performed? Yes
- (b) Was an initial base line test done to establish required performance characteristics? No
- (c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? Yes
- (16) Criteria regarding instrument accuracy satisfied? NA
- (17) Test duration margin (1 hour + function time) satisfied? Yes
- (a) Is the minimum specified operating time at least 1 hour? Yes
- (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided? NA
- (18) Criteria regarding synergistic effects satisfied? NA
- (19) Criteria regarding margins satisfied? Yes
- (20) Maintenance and surveillance requirements adequately identified? Yes

P. DISCUSSION

The accident radiation doses shown in section K, part (5) are  $4.7 \times 10^8$  rads Beta and  $4 \times 10^7$  rads Gamma. The radiation susceptible components of these fans (motor insulation, wiring, etc.) are shielded from Beta radiation by the steel fan housing, motor casing, and terminal box (field wiring is terminated at lugs inside the steel terminal box mounted on the fan housing). Therefore, these components effectively see only the  $4 \times 10^7$  rads Gamma accident radiation dose. For section O(10)(b) and O(15)(b) justifications, see TAB C, 4.3.2 and TAB B, J(2) respectively.

PAGE B-26

BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 27 OF 29

BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L. S. Raymond DATE 6-9-86 R      R     

INSULATION-INSIDE CONTAINMENT CHECKED W. S. Raymond DATE 7/7/86

SUPPLEMENT 1  
COMPONENT-UNIQUE CHECKLIST  
MOTORS

EQUIPMENT IDENTIFICATION

- (1) Is the motor identified in the qualification report identical to the plant motors which require qualification (yes/no/NA)? No

<u>Item</u>	<u>Plant</u>	<u>Report</u>	<u>Acceptable (Yes/No/NA)</u>	<u>Report Section</u>
(a) Insulation system materials	<u>Type RN</u>	<u>Type RN</u>	<u>Yes</u>	<u>Refer to TAB C, Section 3.1</u>
(b) Coil construction (form or random wound, cast)	<u>Random</u>	<u>Random</u>	<u>Yes</u>	<u>Qual Rpt 2, page 5</u>
(c) Insulation class (B, F, H)	<u>H</u>	<u>H</u>	<u>Yes</u>	<u>Qual Rpt 1, page 1</u>
(d) Lubricant				
Manufacturer	<u>Chevron</u>	<u>Chevron</u>	<u>Yes</u>	<u>Refer to TAB C, Section 6.0</u>
Type	<u>SRI-2</u>	<u>SRI-2</u>	<u>Yes</u>	<u>    </u>
(e) Bearing				
Manufacturer	<u>    </u>	<u>New Departure Hyatt</u>	<u>Yes</u>	<u>Refer to (3)</u>
Type	<u>Anti- friction</u>	<u>Anti- friction</u>	<u>Yes</u>	<u>    </u>
Bearing life	<u>156 yr</u>	<u>--</u>	<u>Yes</u>	<u>Refer to TAB E, Div. 1</u>
(f) Seals				
Manufacturer	<u>    </u>	<u>    </u>	<u>    </u>	<u>    </u>
Type	<u>Laby- rinth</u>	<u>Laby- rinth</u>	<u>Yes</u>	<u>Refer to TAB C, Section 6.0</u>
Material	<u>Brass</u>	<u>Brass</u>	<u>Yes</u>	<u>    </u>



BINDER NO. WBNEQ-MOT -002 PLANT WBN UNIT(S) 1 SHEET 29 OF 29  
BINDER TITLE INDUCTION MOTOR-TYPE RN COMPUTED L.L. Kayman DATE 6-9-86  
INSULATION-INSIDE CONTAINMENT CHECKED W.B. King DATE 6/12/86

EQUIPMENT IDENTIFICATION (Continued)

(5) Were the seals included in the test program (yes/no/NA)? Yes  
(Reference Qual Rpt 2, Pg 18 ).

Comments: \_\_\_\_\_  
\_\_\_\_\_

TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL NO.	LOCATION			PURCHASE CONTRACT NO./RD	CAT	OPERATING TIME	MITIGATING ACCIDENT	SAFETY FUNCTION
				COL/AZ	ELEV*	ROOM					
WBN-1-MIR-030-0146	-A 1-MIR-30-146-A**	ABGIS Fan Mtr	50hp, 1800 rev/min 460 Vac 1YF-882365	VAS	737	A5	76K35-83246-1	A	100d	L	Motor is required to drive cooler to ensure adequate cooling and continued operation of the ABGIS.
WBN-2-MIR-030-0157	-B 2-MIR-30-157-B**	ABGIS Fan Mtr	50hp, 1800 rev/min 460 Vac B45524 1YF-882365	VA11	737	A9	76K35-83246-1	A	100d	L	Motor is required to drive cooler to ensure adequate cooling and continued operation of the ABGIS.
WBN-1-MIR-030-0175	-A 1-MIR-30-175-A	RHR Pump Room Cooler Motor	5hp, 1800 rev/min 460 Vac 1YF-883397	WAS	676	A11	84K-834550-1	A	100d	L	Motor is required to drive cooler that cools the safety-related, RHR pump motors.
WBN-1-MIR-030-0176	-B 1-MIR-30-176-B	RHR Pump Room Cooler Motor	5hp, 1800 rev/min 460 Vac 1YF-883397	VAS	676	A10	84K5-834550-1	A	100d	L	Motor is required to drive cooler that cools the safety-related, RHR pump motors.
WBN-1-MIR-030-0177	-A 1-MIR-30-177-A	CIN SPR Pmp Rm Cooler Motor	7-1/2hp, 1800 rev/min 460 Vac 2YF-883397	UA6	676	A9	84K5-834550-1	A	100d	L	Motor is required to drive cooler that cools the safety-related, containment spray pump motors.
WBN-1-MIR-030-0178	-B 1-MIR-30-178-B	CIN SPR Pmp Rm Cooler Motor	7-1/2hp, 1800 rev/min 460 Vac 2YF-883397	UA6	676	A8	84K5-834550-1	A	100d	L	Motor is required to drive cooler that cools the safety-related, containment spray pump motors.

\*Floor/Actual Elevation - Actual elevations are documented on Field Verification Sheets found in Tab F.

\*\*Shown as Common (0) on 50.49 List; Installed as Unit 1-2.

Preparer/Date W. P. Schulte 9/20/86 R R R  
 Checked/Date W. M. Swanton 9/29/86



TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL NO.	LOCATION		ROOM	PURCHASE CONTRACT NO./RD	CAT	OPERATING TIME	MITIGATING ACCIDENT	SAFETY FUNCTION
				COL/AZ	ELEV*						
WBN-1-MIR-030-0179	-B 1-MIR-30-179-B	SIS Pump Rm Cooler Motor	5hp, 1800 rev/min 460 Vac 1YF-883397	VA7	692	A12	84K5-834550-1	A	100d	L	Motor is required to drive cooler that cools the safety-related, SIS pump motors.
WBN-1-MIR-030-0180	-A 1-MIR-30-180-A	SIS Pump Rm Cooler Motor	5hp, 1800 rev/min 460 Vac 1YF-883397	UA7	692	A13	84K5-834550-1	A	100d	L	Motor is required to drive cooler that cools the safety-related, SIS pump motors.
WBN-1-MIR-030-0182	-B 1-MIR-30-182-B	Cent Chg Pump Rm Cooler Motor	5hp, 1800 rev/min 460 Vac 3YF-883397	UA4	692	A10	84K5-834550-1	A	100d 1 mo 1 mo 1 mo 1 mo	L AF/A CV/A RH/A AB	Motor is required to drive cooler that cools the safety-related, Cent. Chg Pump Motors.
WBN-1-MIR-030-0183	-A 1-MIR-30-183-A	Cent Chg Pump Rm Cooler Motor	5hp, 1800 rev/min 460 Vac 3YF-883397	UA4	692	A9	84K5-834550-1	A	100d 1 mo 1 mo 1 mo 1 mo	L AF/A CV/A RH/A AB	Motor is required to drive cooler that cools the safety-related, Cent. Chg Pump Motors.
WBN-0-MIR-065-0023	-A 0-MIR-65-23-A	EGIS Fan Motor	20hp, 1800 rev/min 460 Vac 1YF-882366	UA11	757	A16	76K35-83246-1	A	100d	L	Motors drive fans which must run for the EGIS to perform its safety-related function.
WBN-0-MIR-065-0042	-B 0-MIR-65-42-B	EGIS Fan Motor	20hp, 1800 rev/min 460 Vac 1YF-882366	VA11	757	A16	76K35-83246-1	A	100d	L	Motors drive fans which must run for the EGIS to perform its safety-related function.

\*Floor/Actual Elevation - Actual elevations are documented on Field Verification Sheets found in Tab F.

Preparer/Date Don P. Decker 9/2/86 R R R  
 Checked/Date N. J. Swinton 9/2/86

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 1 OF 28  
BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED DATE 9/20/86  
MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/19/86

A. DOCUMENTATION

Equipment Description Continuous Duty 460 volt motors  
Vendor/Manufacturer Reliance Electric Company  
Equipment Model No.(s) Totally enclosed fan-cooled random wound motors  
on shop orders 1YF-, 2YF-, and 3YF-883397,  
1YF-882365, and 1YF-882366.

QUALIFICATION REPORTS

- (1) Title/Number/Revision Summary Report Nuclear RIMS EEB 820602304  
Power Motor Systems/NUC-9/July 1, 1978 DATE July 15, 1981  
including Supplement R2 dated July 15, 1981  
(TAB D-1)
- (2) Title/Number/Revision Qualification Report/ RIMS B43 850919 500  
End of Life Tests/NUC-22 Rev. 2 (TAB D-2) DATE Feb 10, 1984
- (3) Title/Number/Revision Limitorque PWR Valve RIMS MED 830510 219  
Operator Test Report No. 600456 (excerpt DATE Dec 9, 1975  
TAB D-3)

OTHER (ANALYSIS, VENDOR DATA, ETC.)

- (4) TVA Radiation Calculation WBNNAL3-025, RO (B45 860401 235)
- (5) TVA Radiation Calculation WBNNAL3-031, RO (B45 860529 237)
- (6) System 30 Cat. & Op. Times WBNOSG4-008, R10 (B45 860320 224)
- (7) System 65 Cat. & Op. Times WBNOSG4-015, R7 (B45 860326 222)
- (8) TVA Degraded Voltage Calc WBP-EVAR 8602001, RO (B43 860227 901)
- (9) TVA Flooding Calc WBNOSG4-44, RO (B45 860110 218)
- (10) WBN Environmental Dwgs (a) 85M47E235-48, R3, (b) 85M47E235-74, R1,  
(c) 85M47E235-78, R3, (d) 85M47E235-79, R1, (e) 85M47E235-81, R1
- (11) TVA Condensation Calc GENNAL6-002, R1 (B45 851017 235)

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 2 OF 28

BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED 13 DATE 9/20/86 R     R    

    MOTORS-OUTSIDE CONTAINMENT     CHECKED 13 DATE 9/24/86        

B. CONCLUSION OF REVIEW (Check only one block)

- Equipment Qualified
- Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule
- Equipment Qualification Not Established by Documentation
- Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES: Refer to open items listed in the front of this binder.

1. Technical information from Reliance is outstanding
2. "T" drains must be repositioned
3. Installation of larger terminal boxes

COMMENTS/RECOMMENDATIONS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 3 OF 28  
R     R    

BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Q. Kelly DATE 9/20/86

MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/25/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

X Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)

       Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS \_\_\_\_\_

\_\_\_\_\_

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE 323-1974 Qualifying Class 1E Equipment for Nuclear Power

Generating Stations

IEEE 334-1974 Type Test of Continuous Duty 1E Motors

NEMA MG-1 Motors and Generators

IEEE 117-1974 Evaluation of Insulating Materials for Random-Wound

AC Electrical Machinery.

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 4 OF 28

BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Actualy DATE 9/20/86 R     R    

MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/24/86

D. QUALIFICATION METHODOLOGY (Check only one block)

    Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis

X Test of Similar Items with Supporting Analysis

    Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions

    Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS Refer to TAB C, Section 3.1 for additional details.

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 5 OF 28  
 BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Actually DATE 9/20/86 R     R      
MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/24/86

**E. EQUIPMENT DESCRIPTION**

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? No

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Induction Motors</u>	<u>Induction Motors</u>	<u>NUC-22, Section IV, TAB D-2</u>
(2) Manufacturer	<u>Reliance</u>	<u>Reliance</u>	<u>NUC-22 I, TAB D-2</u>
(3) Model Number(s)	<u>RH Insulation System</u>	<u>3hp</u>	<u>NUC-22, Section III, TAB D-2</u>
	<u>Other data</u>	<u>575 Vac,</u>	
	<u>in TAB A</u>	<u>3ph, 60 Hz</u>	
		<u>1800 rpm-</u>	
		<u>no load</u>	
		<u>RH Insulation System</u>	
(4) Serial Number(s)	<u>Note 1</u>	<u>1YF-882616-A1</u>	<u>TAB D-2, NUC-22, Section III</u>
(5) Identify Component-Unique checksheet attached:	<u>Motors - Supplement 1</u>		

JUSTIFICATION/COMMENTS Refer to TAB C, Section 2.0, Similarity.

NOTE 1 - Motor serial numbers may be referred to as either model or serial numbers on the field verification data sheets in TAB F.



BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 7 OF 28  
 BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Rehley DATE 9/20/86 R     R      
MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/24/86

G. TEST SEQUENCE

(1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>No</u>	<u>See comments</u> <u>NUC-22, IV. A</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>(p 3) TAB D-2</u>
(c) Equipment aged:		<u>NUC-22, IV. B.1</u>
Thermal	<u>Yes</u>	<u>(p 3) TAB D-2</u>
Radiation	<u>Yes</u>	<u>NUC-22, IV. E</u> <u>(p 5) TAB D-2</u>
Wear	<u>Yes</u>	<u>NUC-22, IV. B.3</u> <u>(p 3) TAB D-2</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>NUC-22, IV. C&amp;F</u> <u>(pp 4&amp;6)</u> <u>TAB D-2</u>
(e) Design basis event (DBE) exposure	<u>NA</u>	<u>See comments</u>
(f) Post-DBE exposure	<u>NA</u>	<u>See comments</u>
(g) Final inspection and disassembly	<u>Yes</u>	<u>NUC-22, IV. H</u> <u>(p 6) TAB D-2</u>

(2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes

(3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? Yes\*  
 (Reference TAB D-2, NUC-22, Section IV.C & E).

JUSTIFICATION/COMMENTS G.1.a-Though not documented, inspection for damage is inherent in baseline performance tests. G.1.e&f-In the locations indicated in TAB A, significant transients do not occur, and the effects of the DBE result in only moderate increases in the temperature, humidity, and in some cases, a marked increase in radiation. This represents an extension of conditions existing during normal and abnormal operating conditions which are addressed by the thermal/radiation aging phase of the test series. (See TAB C, Section 3.3).

\*Although some of the test equipment used in the series of seismic tests may have been out of calibration, this has no bearing on the fact that the motor satisfactorily performed at rated conditions following testing intended to simulate the effects of all service conditions.



H. AGING

- (1) Was aging considered in the qualification program (Yes/no/NA)? Yes (Reference TAB D-2, NUC-22, Section IV.B).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

- (2) Were the following effects considered in the aging program:

<u>Aging Effect</u>	<u>Yes/No/NA</u>	<u>Reference</u>
Thermal aging	<u>Yes</u>	Refer to <u>H.4.a</u>
Radiation exposure	<u>Yes</u>	Refer to <u>H.5.a</u>
Vibration (non-seismic) aging	<u>Yes</u>	Refer to <u>H.6.a</u>
Operational (electrical/mechanical/process) stress aging	<u>Yes</u>	Refer to <u>H.7.a</u>

JUSTIFICATION/COMMENTS \_\_\_\_\_  
 \_\_\_\_\_

- (3) Were all known synergistic effects which are believed to have a significant effect on equipment performance considered in the aging program (yes/no/NA)? NA (Reference \_\_\_\_\_).

JUSTIFICATION/COMMENTS A review of the materials used in these motors indicates that there are no known synergistic effects.

- (4) Thermal Aging:

- (a) Was thermal aging considered in the qualification program (yes/no/NA)? Yes (Reference TAB D-2, NUC-22, p 3, Section IV.B, p 3 and Appendix 3.)

JUSTIFICATION/COMMENTS Stator winding and leads were aged 88 days at 255°C (491°F).

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 9 OF 28  
 BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Adelberg DATE 9/20/86 R     R      
MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/20/86

H. AGING (Continued)

- (b) Were the materials susceptible to thermal aging degradation identified in the qualification program (yes/no/NA)? Yes  
 (Reference TAB D-1, NUC-9, p 19, Section VI).

JUSTIFICATION/COMMENTS Components susceptible to thermal degradation are the insulation and lubricants. Lubricant is routinely replaced, in accordance with the QMDS (TAB G) and, therefore, not subject to long-term thermal degradation.

- (c) Was the basis for thermal aging identified in the qualification program (yes/no/NA)? Yes (Reference TAB D-2, NUC-22, Section IV.B.1, & App 3, p 2).

JUSTIFICATION/COMMENTS In accordance with IEEE 334-1974, Section 9.0, a regression line developed in NUC-9 was used to obtain equivalent aging time and temperature.

- (d) Was the aging acceleration rate justified and the parameters of time and temperature identified in the qualification program (yes/no/NA)? Yes (Reference TAB D-2, NUC-22, Section IV.B and App 3).

<u>Parameter</u>	<u>Plant Maximum Normal</u>	<u>Test</u>	<u>Equivalent</u>
Temperature	<u>Refer to TAB C, Section 8.1</u>	<u>255°C</u>	<u>155°C</u>
Time	<u>40 years</u>	<u>88 days</u>	<u>44 years</u>

JUSTIFICATION/COMMENTS Refer to TAB C, Section 8.1.

H. AGING (Continued)

- (e) Was the Arrhenius methodology used for accelerated aging (yes/no/NA)? Yes (Reference TAB D-2, NUC-22, Section IV.B and App. 3 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (f) If activation energies were used for determining accelerated aging parameters, are they properly referenced to the source of the technical data (yes/no/NA)? NA (Reference \_\_\_\_\_ ).

JUSTIFICATION/COMMENTS Accelerated aging parameters developed in accordance with Section 9 of IEEE 334-1974 using a system regression line.

- (g) If a regression line was used for determining accelerated aging parameters, are test points or failure modes identified on the line (yes/no/NA)? Yes (Reference TAB D-1, NUC-9, Supp. p 2 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_

- (h) Was the equipment operated during the thermal aging (yes/no/NA)? Yes (Reference TAB D-2 NUC-22, p 6 Section IV, F&G. ).

JUSTIFICATION/COMMENTS The accelerated thermal aging process of the complete stator assembly and the motor leads accounts for the thermal stresses which would occur from prolonged normal operation. Following this process, the assembled motor, complete with the aged stator assembly and leads, was operated in a series of performance tests.

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 11 OF 28  
 BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Aduly DATE 9/20/86 R     R      
MOTORS-OUTSIDE CONTAINMENT CHECKED     DATE 9/20/86

H. AGING (Continued)

(5) Radiation Aging Exposure:

- (a) Was radiation aging exposure considered in the qualification program (yes/no/NA)? Yes (Reference TAB D-2, NUC-22, p 5 Section IV.E.).

JUSTIFICATION/COMMENTS Complete motor assembly, including bearings and lubricant, was exposed to a total integrated dose of  $2.2 \times 10^8$  rads, gamma.

- (b) Were the materials susceptible to radiation degradation identified in the qualification program (yes/no/NA)? Yes (Reference TAB D-1, NUC-9, p 8, Section III, and TAB D-2, NUC-22, Appendix I, p 1).

JUSTIFICATION/COMMENTS Organic materials of the Reliance RH system, Spec. 4824-GZ, and bearing lubricants are identified by Reliance specification number in Section III of the NUC-9 report.

- (c) Was the basis for radiation aging exposure identified in the qualification program (yes/no/NA)? Yes (Reference TAB D-1, NUC-9, Section I.B (pp 1 & 2)).

JUSTIFICATION/COMMENTS Radiation test dose was selected to envelop applications occurring throughout a significant radiation range.

- (d) Is the radiation test exposure dose and dose rate acceptable (yes/no/NA)? Yes (Reference TAB D-2, NUC-22, App. 5).

Plant normal ambient radiation dose (rd)	<u>6</u>	<u>8</u>
	<u><math>3.6 \times 10^6</math> rd normal,</u>	<u><math>1.00 \times 10^8</math> rd</u>
	<u>accident</u>	
Test exposure dose (rd)	<u><math>2.2 \times 10^8</math></u>	<u>rads</u>

H. AGING (Continued)

220 hrs at .55 MRad/hr  
20 hrs at .05 MRad/hr  
Test exposure dose rate (rd/hr) 85.7 hrs at 1.14 MRad/hr

Test exposure source type  
(e.g., Co-60 gamma) Co-60, gamma.

JUSTIFICATION/COMMENTS Co-60 gamma source confirmed in  
telecon on August 29, 1986, between Don Ackerly of TVA and  
Gary Wheeler of Reliance Electric.

(6) Vibration (non-seismic) Aging:

(a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference TAB D-2, NUC-22, p 3, Section IV.B.3).

JUSTIFICATION/COMMENTS Mechanically aged per Section 9 of  
IEEE 334-1975 for one hour at 60 cycle per second vibration,  
with a deflection of 8 mils pk-pk.

(b) Was the basis for vibration aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference TAB D-2, NUC-22, p 3, Section IV.B.3 ).

JUSTIFICATION/COMMENTS \_\_\_\_\_  
\_\_\_\_\_

(7) Operational Stress Aging:

(a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference TAB D-2, NUC-22, p 3, Section IV.B.3; p 4, Section IV.C.4; and p 6, Section IV.F ).

JUSTIFICATION/COMMENTS Motor operated under load during  
multiple frequency seismic tests which followed thermal,  
radiation, and vibration aging. Motor also operated under  
no-load conditions during vibration aging addressed in TAB B,  
Section H, Item 6.

BINDER NO. WBNEQ-MOT-Q03 PLANT WBN UNIT(S) 1 SHEET 13 OF 28  
R    R     
BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Qckly DATE 9/20/86  
MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/20/86

H. AGING (Continued)

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference Refer to references in 7a ).

JUSTIFICATION/COMMENTS Motor operated under rated conditions during both series of seismic tests. This results in stresses much greater than those encountered through normal operation.

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (yes/no/NA)? Yes (Reference TAB D-2, NUC-22, p 7, Section V ).

Qualified life (Document in QMDS) 40+ years

JUSTIFICATION/COMMENTS NUC-22 documents a qualified life of 40 years plus 10% margin, i.e., 44 years at a total temperature of 155°C.

- (9) Were replacement intervals for the equipment or its components defined in the qualification program (yes/no/NA)? Yes (Reference TAB D-1, NUC-9, p 17, Section V.2&3 ).

Replacement Intervals (Document in QMDS) Refer to TAB G.

JUSTIFICATION/COMMENTS No replaceable items were identified in the insulation system. The bearings and lubricants are routine maintenance items, the replacement of which is addressed in the Qualification Maintenance Data Sheets in TAB G. Basically, lubrication schedules, bearing replacement intervals and electrical and mechanical surveillance recommendations are detailed.

**I. MATERIALS ANALYSIS**

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of EQC Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>DuPont 10/Electrical/Insulation</u>	<u>8</u> <u>2.2x10</u>	<u>Note 1</u>	<u>1.02 eV</u>	<u>Note 3</u>
(b) <u>Chevron/Mechanical/Lubricant SRI No. 2</u>	<u>8</u> <u>2x10 rad</u>	<u>Note 2</u>	<u>Note 4</u>	<u>   </u>
(c) <u>   </u>	<u>   </u>	<u>   </u>	<u>   </u>	<u>   </u>
(d) <u>   </u>	<u>   </u>	<u>   </u>	<u>   </u>	<u>   </u>
(e) <u>   </u>	<u>   </u>	<u>   </u>	<u>   </u>	<u>   </u>

JUSTIFICATION/COMMENTS

Note 1 - The Reliance RH/DuPont 10 insulation system withstood a total dose of 2.2x 10<sup>8</sup> RADS and maintained its ability to perform its required function as documented in Reliance Report NUC-22, TAB D-2.

Note 2 - Refer to Digital Material Aging and Radiation Effects Library Code No. 157-83A.

Note 3 - Refer to Material Aging Calculation WAD-34. Refer to TAB D-4.

Note 4 - Consideration of long-term thermal degradation of the grease is not required because it is not considered to be a substance with an infinite life. A surveillance and maintenance program is established in the QMDS in TAB G to ensure proper operation.

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 15 OF 28  
R     R    

BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Acting DATE 9/20/86

MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/20/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference TAB D-2, NUC-22, p 6, Section IV.G).

Identify Acceptance Criteria: Following accelerated aging and seismic testing, intended to simulate the effects of all service conditions, the motor must continue to operate at its rated load.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference TAB D-2, NUC-22, App. 2).

Identify baseline and functional testing: No load, locked rotor, and dielectric tests done to baseline motor performance parameters. After all environmental aging and testing, baseline tests were repeated and full load tests were also performed.

JUSTIFICATION/COMMENTS Motor test results were essentially identical with no indication of diminished capability.

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? Yes (Reference TAB D-2, Nuc-22, pg 6, Sect. IV.G).

JUSTIFICATION/COMMENTS The motor functioned under rated electrical and mechanical conditions during and B 9/20 in 9/20 following a simulation of the service conditions. The effects of the DBE result in only moderate increases in the temperature, humidity, and, in some cases, a marked increase in radiation. This can be represented as an extension of conditions existing during normal and abnormal operating conditions which is addressed by the thermal/radiation aging phase of the test series.



J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

(4) Do the applied loads during baseline testing reflect normal operating conditions (yes/no/NA)? Yes (Reference TAB D-1, NUC-22, Section I).

JUSTIFICATION/COMMENTS Baseline tests performed are industry-standard tests used to determine performance characteristics during normal operating conditions.

(5) Identify electrical characteristics necessary to ensure the equipment performance specifications can be satisfied.

<u>(a) Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference</u>
Voltage	<u>Refer to Justification below</u>	<u>                    </u>
Load	<u>"</u>	<u>                    </u>
Frequency	<u>"</u>	<u>                    </u>
Accuracy	<u>NA</u>	<u>                    </u>
Other(s)	<u>                    </u>	<u>                    </u>

JUSTIFICATION/COMMENTS Refer to TAB C, Section 5.0 for discussion of voltage and frequency requirements.

<u>(b) Parameter</u>	<u>Specific Accident Conditions</u>	<u>Reference</u>
Voltage	<u>Refer to Justification below</u>	<u>                    </u>
Load	<u>"</u>	<u>                    </u>
Frequency	<u>"</u>	<u>                    </u>
Accuracy	<u>NA</u>	<u>                    </u>
Other(s)	<u>                    </u>	<u>                    </u>

JUSTIFICATION/COMMENTS Refer to TAB C, Section 5.0 for discussion of voltage and frequency requirements.

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 17 OF 28  
 BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Actualy DATE 9/20/86 R     R      
MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/20/86

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. Worst Case Summary of the next 5 sheets

(1) Normal Max

(a) Temperature (°F) 104  
 (b) Pressure (psig) ATM-  
 (c) Humidity (%) 80  
 (d) Radiation (rd) 3.6 X 10<sup>6</sup>

(2) Abnormal Max

(a) Temperature (°F) 110  
 (b) Pressure (psig) ATM-  
 (c) Humidity (%) 90  
 (d) Radiation (rd) NA

(3) Process Interfaces: None.

(4) State anticipated occurrence frequency and duration of abnormal conditions: 8 hours per excursion totaling less than 1% of plant

life and a total of 1600 hours during life of plant.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F)	<u>110 for 100 days</u>	Accident type <u>LOCA</u>
(b) Pressure (psig)	<u>ATM</u>	Accident type <u>HELB</u>
(c) Humidity (%)	<u>100%</u>	Accident type <u>HELB</u>
(d) Radiation (rd)	<u>1.00 x 10<sup>8</sup></u>	Accident type <u>LOCA</u>
(e) Spray Type	<u>NA</u>	Accident type <u>NA</u>

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 17A OF 28  
 BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Agley DATE 9/20/86  
MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/20/86

**K. REQUIRED OPERATING ENVIRONMENT**

Reference Environmental Drawing No. 85M47E235-48 R3 Node 14

- |  |                                 |
|--|---------------------------------|
| (1) Normal Max                               | (2) Abnormal Max                |
| (a) Temperature (°F) <u>104</u>              | (a) Temperature (°F) <u>110</u> |
| (b) Pressure (psig) <u>ATM-</u>              | (b) Pressure (psig) <u>ATM-</u> |
| (c) Humidity (%) <u>80%</u>                  | (c) Humidity (%) <u>90%</u>     |
| (d) Radiation (rd) <u>8.8x10<sup>5</sup></u> | (d) Radiation (rd) <u>NA</u>    |

(3) Process Interfaces: None

(4) State anticipated occurrence frequency and duration of abnormal conditions: 8 hrs. per excursion totaling less than 1% of plant life and a total of 1600 hours during life of plant.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- |  |                           |
|--|---------------------------|
| (a) Temperature (°F) <u>110°F for 100 days</u> | Accident type <u>LOCA</u> |
| (b) Pressure (psig) <u>ATM- NA</u>             | Accident type <u>NA</u>   |
| (c) Humidity (%) <u>NA</u>                     | Accident type <u>LOCA</u> |
| (d) Radiation (rd) <u>1x10<sup>8</sup></u>     | Accident type <u>LOCA</u> |
| (e) Spray Type <u>NA</u>                       | Accident type <u>NA</u>   |

\*\*Affected Motors: 0-MTR-30-146-A, RM A5  
 0-MTR-30-157-B, RM A9

\*\* Motors listed are required to operate only during conditions resulting from a LOCA.

**K. REQUIRED OPERATING ENVIRONMENT**

Reference Environmental Drawing No. 85M47E235-74 RI Node 2

(1) Normal Max	(2) Abnormal Max
(a) Temperature (°F) <u>104</u>	(a) Temperature (°F) <u>110</u>
(b) Pressure (psig) <u>ATM-</u>	(b) Pressure (psig) <u>ATM-</u>
(c) Humidity (%) <u>80%</u>	(c) Humidity (%) <u>90%</u>
(d) Radiation (rd) <u>4.3x10<sup>5</sup></u>	(d) Radiation (rd) <u>NA</u>

(3) Process Interfaces: None

(4) State anticipated occurrence frequency and duration of abnormal conditions: 8 hrs. per excursion totaling less than 1% of plant life and a total of 1600 hours during life of plant.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) <u>110°F for 100 days</u>	Accident type <u>LOCA</u>
(b) Pressure (psig) <u>ATM-</u>	Accident type <u>LOCA</u>
(c) Humidity (%) <u>NA</u>	Accident type <u>LOCA</u>
(d) Radiation (rd) <u>1 x 10<sup>7</sup></u>	Accident type <u>LOCA</u>
(e) Spray Type <u>NA</u>	Accident type <u>NA</u>

\*\*Affected Motors: 1-MTR-30-175-A, Rm A11  
1-MTR-30-176-B, Rm A10

\*\*Motors listed are required to operate only during conditions resulting from a LOCA.

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 17C OF 28

BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Actualy DATE 9/20/86 R    R   

MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/20/86

**K. REQUIRED OPERATING ENVIRONMENT**

Reference Environmental Drawing No. 85M47E235-78 R3

(1) Normal Max

(a) Temperature (°F) 104

(b) Pressure (psig) ATM

(c) Humidity (%) 80

(d) Radiation (rd) 1.8x10<sup>3</sup>

(2) Abnormal Max

(a) Temperature (°F) 110

(b) Pressure (psig) ATM

(c) Humidity (%) 90

(d) Radiation (rd) NA

(3) Process Interfaces: None.

(4) State anticipated occurrence frequency and duration of abnormal conditions: 8 hrs. per excursion totaling less than 1% of plant life and a total of 1600 hours during life of plant.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F) 110°F FOR 100 days ±10 Accident type LOCA

(b) Pressure (psig) NA Accident type   

(c) Humidity (%) NA Accident type   

(d) Radiation (rd) 1.4x10<sup>6\*\*</sup> Accident type LOCA

(e) Spray Type NA Accident type   

Affected Motors: 0-MTR-65-23-A, Rm A16  
0-MTR-65-42-B, Rm A16

\*\*WBNNAL3-031 RO (B45 860529 237)

*Sp 9/20/86  
B 9/20*

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 17D OF 28  
 BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED October DATE 9/20/86 R     R      
MOTORS-OUTSIDE CONTAINMENT CHECKED 15 DATE 9/20/86

**K. REQUIRED OPERATING ENVIRONMENT**

Reference Environmental Drawing No. 85M47E235-79 R1

- |  |                                 |
|--|---------------------------------|
| (1) Normal Max                               | (2) Abnormal Max                |
| (a) Temperature (°F) <u>104</u>              | (a) Temperature (°F) <u>110</u> |
| (b) Pressure (psig) <u>ATM-</u>              | (b) Pressure (psig) <u>ATM-</u> |
| (c) Humidity (%) <u>80%</u>                  | (c) Humidity (%) <u>90%</u>     |
| (d) Radiation (rd) <u>3.6x10<sup>6</sup></u> | (d) Radiation (rd) <u>NA</u>    |

(3) Process Interfaces: None.

(4) State anticipated occurrence frequency and duration of abnormal conditions: 8 hrs. per excursion totaling less than 1% of plant life and a total of 1600 hours during life of plant.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

- |  |                                 |
|--|---------------------------------|
| (a) Temperature (°F) <u>110°F for 100 days</u> | Accident type <u>LOCA</u>       |
| (b) Pressure (psig) <u>NA</u>                  | Accident type <u>          </u> |
| (c) Humidity (%) <u>NA</u>                     | Accident type <u>          </u> |
| (d) Radiation (rd) <u>1 x 10<sup>7</sup></u>   | Accident type <u>LOCA</u>       |
| (e) Spray Type <u>NA</u>                       | Accident type <u>          </u> |

Affected Motors: 1-MTR-30-179-B, Rm A12 (40 yr. 3.5 x 10<sup>4</sup>)  
 1-MTR-30-180-A, Rm A13 (40 yr. 3.5 x 10<sup>4</sup>)  
 1-MTR-30-182-B, Rm A10  
 1-MTR-30-183-A, Rm A9

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 17 OF 28  
 BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Checked DATE 9/20/86 R    R     
MOTORS-OUTSIDE CONTAINMENT CHECKED 15 DATE 9/20/86

**K. REQUIRED OPERATING ENVIRONMENT**

Reference Environmental Drawing No. 85M47E235-81 R1

(1) Normal Max

(a) Temperature (°F) 104  
 (b) Pressure (psig) ATM-  
 (c) Humidity (%) 80%  
 (d) Radiation (rd) 3.5x10<sup>4</sup>

(2) Abnormal Max

(a) Temperature (°F) 110  
 (b) Pressure (psig) ATM-  
 (c) Humidity (%) 90%  
 (d) Radiation (rd) NA

(3) Process Interfaces: None.

(4) State anticipated occurrence frequency and duration of abnormal conditions: 8 hrs. per excursion totaling less than 1% of plant life and a total of 1600 hours during life of plant.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F)	<u>110°F for 100 days</u>	Accident type <u>LOCA</u>
(b) Pressure (psig)	<u>NA</u>	Accident type <u>          </u>
(c) Humidity (%)	<u>NA</u>	Accident type <u>          </u>
(d) Radiation (rd)	<u>1 x 10<sup>7</sup></u>	Accident type <u>LOCA</u>
(e) Spray Type	<u>NA</u>	Accident type <u>          </u>

Affected Motors: 1-MTR-30-177-A, Rm A9  
 1-MTR-30-178-B, Rm A8





BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 19 OF 28  
 BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Agueby DATE 9/20/86 R     R      
MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/20/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Required</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	40 years + <u>100 days</u>	<u>44 years</u>	NUC-22, <u>Section V, TAB D-2</u>
Temperature (°F)	<u>135°C</u>	<u>155°C</u>	See TAB C, <u>Section 8.1</u>
Pressure (psig)	<u>ATM</u>	<u>ATM</u>	See TAB C, <u>Section 9.0</u>
Relative Humidity (%)	<u>100%</u>	<u>100%</u>	<u>TAB C, Section 8.3</u>
*Chemical Spray	<u>NA</u>	<u>NA</u>	<u>NA</u>
**Radiation (rd)	<u>1.04x10<sup>8</sup></u>	<u>2.2x10<sup>8</sup></u>	NUC-22, Section V, p 7, TAB D-2 and TAB C, <u>Section 8.2</u>
Submergence	<u>NA</u>	<u>NA</u>	Refer to TAB C, <u>Section 7.0</u>

\*Includes spray concentration, flowrate, density, duration, and pH.

\*\*Enter 40-year integrated normal dose plus integrated accident dose and specify type.

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 20 OF 28

BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Actualy DATE 9/20/86 R     R    

MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/20/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>TAB C, Sect. 8.1</u>
Pressure	<u>Yes</u>	<u>TAB C, Sect. 3.5</u>
Relative Humidity	<u>Yes</u>	<u>TAB C, Sect. 8.3</u>
Chemical Spray	<u>NA</u>	<u>TAB C, Sect. 3.4</u>
Submergence	<u>NA</u>	<u>TAB C, Sect. 7.0</u>

JUSTIFICATION/COMMENTS \_\_\_\_\_

(3) Were margins applied to the test parameters or otherwise addressed in the test program to assure that normal variation and uncertainties are accounted for? (Note margin applied, yes/no/NA)

<u>Suggested Margins per IEEE-323(74)</u>	<u>Margin Applied</u>	<u>Yes/No/NA</u>
Temperature: +15 degrees F	<u>Note 1</u>	<u>Yes</u>
Pressure: +10% but no more than 10 psig	<u>          </u>	<u>NA(Note 2)</u>

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 21 OF 28  
 BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Agley DATE 9/20/86 R      R       
MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/20/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS (Continued)

Radiation: +10% of accident dose	<u>10%</u>	<u>Yes (Note 3)</u>
Time: +10% (or 1 hour + operating time per NUREG-0588)	<u>10%</u>	<u>Yes (Note 1)</u>
Voltage: $\pm$ 10% of rated value	<u>    </u>	<u>NA (Note 4)</u>
Frequency: $\pm$ 5% of rated value	<u>    </u>	<u>NA (Note 4)</u>
Environmental Transient: the initial transient and the peak temperature applied twice	<u>    </u>	<u>NA (Note 5)</u>
Vibration: +10% added to acceleration	<u>    </u>	<u>NA (Note 6)</u>

JUSTIFICATION/COMMENTS     

Note 1 - Refer to TAB C, Section 8.1.

Note 2 - Refer to TAB C, Section 3.5.

Note 3 - Refer to TAB C, Section 8.2.

Note 4 - Refer to TAB C, Section 5.0.

Note 5 - Refer to TAB C, Section 3.3.

Note 6 - These motors do not experience significant process-  
related vibration and as such, the vibration margin  
has been accounted for during the seismic/vibration  
tests documented in the Nuc-22 report. ~~Item 5 is not~~  
~~required~~

*Agley 9/20/86*  
*B 9/30*

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:  
(Reference            ).

JUSTIFICATION/COMMENTS Refer to TAB A and J(1).

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? Yes  
(Reference            ).

JUSTIFICATION/COMMENTS TAB C, Section 3.3.

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? Yes  
(Reference            ).

JUSTIFICATION/COMMENTS TAB C, Section 3.3.

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? Yes (Reference NUC-22, p 7, Section V ).

JUSTIFICATION/COMMENTS Motor operated under full-load conditions following accelerated thermal aging, irradiation, and mechanical aging.

- (5) Abnormal Conditions: Were abnormal conditions or anomalies properly addressed and resolved (yes/no/NA)? NA  
(Reference            ).

JUSTIFICATION/COMMENTS No test anomalies were reported.

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 23 OF 28  
BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Regularly DATE 9/20/86 R     R      
MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/20/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the EQC Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS No replaceable items were identified in the  
insulation system qualification program described in NUC-9 and NUC-22.  
The bearings and lubricants are routine maintenance items, the replace-  
ment of which is addressed in the Qualification Maintenance Data Sheets  
(QMDS) in this binder. Basically, lubrication schedules, bearing  
replacement intervals and electrical and mechanical surveillance  
recommendations are detailed in the QMDS located in TAB G.

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 24 OF 28  
 BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Reckling DATE 9/20/86 R     R      
MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/20/86

0. SUMMARY OF REVIEW

	<u>Yes/No/NA</u>
(1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)?	<u>Yes</u>
(2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?	<u>Yes</u>
(3) Choice of qualification methodology adequately justified?	<u>Yes</u>
(4) If analysis was performed, complete the following:	
(a) Were equipment performance requirements identified?	<u>Yes</u>
(b) Were specific features and failure modes and effects analyzed?	<u>Yes</u>
(c) Were assumptions and mathematical models used together with appropriate justification for their use?	<u>Yes</u>
(d) Were environmental parameters which affect equipment performance identified?	<u>Yes</u>
(5) Adequate similarity between equipment and test specimen established?	<u>Yes</u>
(6) Aging degradation evaluated adequately?	<u>Yes</u>
(a) Mechanical and/or cycle aging addressed?	<u>Yes</u>
(b) Equipment aged to end of life condition prior to application of DBE conditions?	<u>Yes</u>
(c) Absence of preaging in test/analysis justified?	<u>NA</u>
(d) Materials susceptible to thermal/radiation aging identified?	<u>Yes</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 25 OF 28  
 BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Actualy DATE 9/20/86  
MOTORS-OUTSIDE CONTAINMENT CHECKED By DATE 9/20/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>NA</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>NA</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>NA</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>NA</u>
(11) Criteria regarding submergence satisfied?	<u>Yes</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>Yes</u>
(b) Was beta radiation considered?	<u>Section P Note 1</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

O. SUMMARY OF REVIEW (Continued)

- |  | <u>Yes/No/NA</u> |
|--|------------------|
| (15) Criteria regarding functional testing satisfied?  | <u>Yes</u>       |
| (a) Does the test plan/report specify an acceptance criteria for equipment performed?  | <u>Yes</u>       |
| (b) Was an initial base line test done to establish required performance characteristics?  | <u>Yes</u>       |
| (c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? | <u>Yes</u>       |
| (16) Criteria regarding instrument accuracy satisfied?   | <u>Yes</u>       |
| (17) Test duration margin (1 hour + function time) satisfied?  | <u>Yes</u>       |
| (a) Is the minimum specified operating time at least 1 hour?   | <u>Yes</u>       |
| (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided?  | <u>NA</u>        |
| (18) Criteria regarding synergistic effects satisfied?   | <u>Yes</u>       |
| (19) Criteria regarding margins satisfied?   | <u>Yes</u>       |
| (20) Maintenance and surveillance requirements adequately identified?  | <u>Yes</u>       |

P. Discussion

Note 1: Motors are located in areas throughout the auxiliary building.  
Beta-radiation is confined to the reactor building by plant  
design; therefore, these motors are not required to be eval-  
uated for the effects of beta radiation.



BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 27 OF 28  
 BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Dehaly DATE 9/20/86  
MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/20/86

SUPPLEMENT 1  
 COMPONENT-UNIQUE CHECKLIST  
 MOTORS

Page 1 of 2

EQUIPMENT IDENTIFICATION

- (1) Is the motor identified in the qualification report identical to the plant motors which require qualification (yes/no/NA)? No (Refer Note 1)

<u>Item</u>	<u>Plant</u>	<u>Report</u>	<u>Acceptable (Yes/No/NA)</u>	<u>Report Section</u>
(a) Insulation system materials	<u>RH</u>	<u>RH</u>	<u>Yes</u>	<u>TAB C, Sect. 2.1</u>
(b) Coil construction (form or random wound, cast)	<u>Random</u>	<u>Random</u>	<u>Yes</u>	<u>TAB D-1, NUC-9, Sect. I.D</u>
(c) Insulation class (B, F, H)	<u>H</u>	<u>H</u>	<u>Yes</u>	<u>TAB D-2, NUC-22, Sect. III</u>
(d) Lubricant				
Manufacturer	<u>Chevron</u>	<u>Chevron</u>	<u>Yes</u>	<u>TAB D-2, NUC-22, App 1, Sect. I</u>
Type	<u>SRI-2</u>	<u>SRI-2</u>	<u>Yes</u>	<u>TAB D-2, NUC-22, App 1, Sect. I</u>
(e) Bearing				
Manufacturer	<u>Note 2</u>	<u>Note 2</u>	<u>Yes</u>	<u>_____</u>
Type	<u>Anti Friction</u>	<u>Anti Friction</u>	<u>Yes</u>	<u>Refer to item (5) this supplement</u>
Bearing life	<u>*</u>	<u>*</u>	<u>Yes</u>	<u>*Refer to TAB C, Section 4.1</u>

*Dehaly*  
 9/20/86

BINDER NO. WBNEQ-MOT-003 PLANT WBN UNIT(S) 1 SHEET 28 OF 28  
 BINDER TITLE RELIANCE-RANDOM WOUND COMPUTED Achudy DATE 9/20/86 R     R      
MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 9/20/86

EQUIPMENT IDENTIFICATION (Continued)

Page 2 of 2

<u>Item</u>	<u>Plant</u>	<u>Report</u>	<u>Acceptable (Yes/No/NA)</u>	<u>Report Section</u>
(f) Seals				
Manufacturer	<u>Note 2</u>	<u>Note 2</u>	<u>Yes</u>	<u>                    </u>
Type	<u>400654</u>	<u>400654</u>	<u>Yes</u>	<u>NUC-9, Sect.V.C, TAB D</u>
Material	<u>Steel</u>	<u>Steel</u>	<u>Yes</u>	<u>NUC-9, Sect.V.C, TAB D</u>
(g) Motor lead insulation	<u>Nomex tape and braided glass</u>	<u>Nomex tape and braided glass</u>	<u>Yes</u>	<u>NUC-9, Sect. III. 8, p 12, TAB D</u>

Comments: Note 1: Tested motors are the same as installed except for the actual physical size and rating. Differences are achieved through the use of long-time, industry standard design and construction principles.

Note 2: Tested equipment utilized components determined to be acceptable by Reliance. Bearings and seals for equipment in Tab A were also provided by Reliance.

*Handwritten:*  
 Du  
 9/20/86  
 B  
 9/20

- (2) Does the qualification report indicate that the motorette insulation system is the same as that used on the motors (yes/no/NA)? Yes (Reference                     ). Refer to TAB C, Section 2.1.
- (3) Has the vendor provided the bearing rating (yes/no/NA)? Yes (Reference           ). Refer to TAB C, Section 4.1.
- (4) Was the lubricant included in the test program (yes/no/NA)? Yes (Reference           ). Refer to TAB C, Section 4.2.
- (5) Were the seals included in the test program (yes/no/NA)? Yes (Reference           ). Refer to TAB C, Section 4.3.

TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL NO.	LOCATION			PURCHASE CONTRACT NO./RD	CAT	OPERATING TIME	MITIGATING ACCIDENT	SAFETY FUNCTION
				COL/AZ	ELE*	ROOM					
WBN-1-MIR-030-0194	-A 1-MIR-30-194-A	EL 737 Penetration Rn Cooler Motor	3hp, 460Vac NH7. ins. sys. M.O. 4-147740	A4V	737	A5	84K5-834550-2	a	100D	L	MOTOR IS REQUIRED TO DRIVE COOLER THAT COOLS SAFETY RELATED EQUIPMENT IN THE PENETRATION ROOM.
								a	1MD	AF/A	
								a	1MD	CV/A	
								a	1MD	RH/A	
a	1MD	AB									
WBN-1-MIR-030-0195	-B 1-MIR-30-195-B	EL 737 Penetration Rn Cooler Motor	3hp, 460Vac NH7. ins. sys. M.O. 4-147740	A4V	737	A5	84K5-834550-2	a	100D	L	MOTOR IS REQUIRED TO DRIVE COOLER THAT COOLS SAFETY RELATED EQUIPMENT IN THE PENETRATION ROOM.
								a	1MD	AF/A	
								a	1MD	CV/A	
								a	1MD	RH/A	
a	1MD	AB									
WBN-2-MIR-030-0194	-A 2-MIR-30-194-A	EL 737 Penetration Rn Cooler Motor	3hp, 460Vac NH7. ins. sys. M.O. 4-147745	A12V	737	A9	84K5-834550-2	a	100D	L	MOTOR IS REQUIRED TO DRIVE COOLER THAT COOLS SAFETY RELATED EQUIPMENT IN THE PENETRATION ROOM.
								a	1MD	AF/A	
								a	1MD	CV/A	
								a	1MD	RH/A	
a	1MD	AB									

PAGE A-1

R R R

\*Floor/Actual Elevation - Actual elevations are documented on Field Verification Sheets found in Tab F.

Preparer/Date Don F. Cichelski 9/2/86  
 Checked/Date W. M. Gauster 9/2/86

TAB A - EQUIPMENT IDENTIFICATION MATRIX

EQIS NO.	UNIT DEVICE ID NO.	DESCRIPTION	MODEL NO.	LOCATION		ROOM	PURCHASE CONTRACT NO./RD	CAT	OPERATING TIME	MITIGATING ACCIDENT	SAFETY FUNCTION
				CUL/AZ	ELE*						
WBN-2-MIR-030-0195	-B 2-MIR-30-195-B	EL 737 Penetration Rm Cooler Motor	3hp, 460Vac NH7, ins. sys. M.O. 4-147745	A12V	737	A9	84K5-834550-2	a	100D	L	MOTOR IS REQUIRED TO DRIVE COOLER THAT COOLS SAFETY RELATED EQUIPMENT IN THE PENETRATION ROOM.
								a	1MD	AF/A	
								a	1MD	CV/A	
								a	1MD	RH/A	
WBN-1-MIR-030-0196	-A 1-MIR-30-196-A	EL 713 Penetration Rm Cooler Motor	3hp, 460Vac NH5, ins. sys. M.O. 4-147739	A2U	713	A6	84K5-834550-2	a	100D	L	MOTOR IS REQUIRED TO DRIVE COOLER THAT COOLS SAFETY RELATED EQUIPMENT IN THE PENETRATION ROOM.
								a	1MD	AF/A	
								a	1MD	CV/A	
								a	1MD	RH/A	
WBN-1-MIR-030-0197	-B 1-MIR-30-197-B	EL 713 Penetration Rm Cooler Motor	3hp, 460Vac NH5, ins. sys. M.O. 4-147739	A2U	713	A6	84K5-834550-2	a	100D	L	MOTOR IS REQUIRED TO DRIVE COOLER THAT COOLS SAFETY RELATED EQUIPMENT IN THE PENETRATION ROOM.
								a	1MD	AF/A	
								a	1MD	CV/A	
								a	1MD	RH/A	
WBN-2-MIR-030-0200	-A 2-MIR-30-200-A	EGTS Cooler Fan Motor	3hp, 460Vac NH9, ins. sys. M.O. 4-147746	A11W	757	A16	84K5-834550-2	a	100D	L	EVENT L: THE EGTS MUST WORK TO PREVENT RELEASE OF RADIO-ACTIVE GASES. THESE MOTORS DRIVE COOLERS REQUIRED TO FUNCTION TO PREVENT OVERHEATING EGTS. EVENTS AB, AF, CVA, RH/A: THE COOLERS ARE NOT NEEDED, EGTS IS NOT REQUIRED TO MITIGATE THESE EVENTS.
								c		RH/A	
								c		CV/A	
								c		AF	
WBN-2-MIR-030-0207	-B 2-MIR-30-207-B	EGTS Cooler Fan Motor	3hp, 460Vac NH9, ins. sys. M.O. 4-147746	A11W	757	A16	84K5-834550-2	a	100D	L	EVENT L: THE EGTS MUST WORK TO PREVENT RELEASE OF RADIO-ACTIVE GASES. THESE MOTORS DRIVE COOLERS REQUIRED TO FUNCTION TO PREVENT OVERHEATING EGTS. EVENTS AB, AF, CVA, RH/A: THE COOLERS ARE NOT NEEDED, EGTS IS NOT REQUIRED TO MITIGATE THESE EVENTS.
								c		RH/A	
								c		CV/A	
								c		AF	
								c		AB	

PAGE A-2

\*Floor/Actual Elevation - Actual elevations are documented on Field Verification Sheets found in Tab F.

Preparer/Date Don P. Quinlan 9/2/86 R R R  
 Checked/Date N. J. Zonster 9/2/86

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 1 OF 1  
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Adydy DATE 8/23/86 R     R      
MOTORS-OUTSIDE CONTAINMENT CHECKED B DATE 8/23/86

TAB B

TABLE OF CONTENTS

- TAB B-1 Louis Allis NH5 Insulation System  
(For service to  $1 \times 10^5$  rads total)
- TAB B-2 Louis Allis NH7 Insulation System  
(For service to  $1 \times 10^7$  rads total)
- TAB B-3 Louis Allis NH9 Insulation System  
(For service to  $1 \times 10^9$  rads total)

PAGE B-1

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) I SHEET 1 OF 30  
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Ockley Inf DATE 9/15/86 R     R      
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 9/15/86

A. DOCUMENTATION

Equipment Description Squirrel-Cage Induction Motor  
Vendor/Manufacturer Louis Allis  
Equipment Model No.(s) 3hp, 460 Vac, NH5 insulation system  
M.O. No. 4-147739

QUALIFICATION REPORTS

- (1) Title/Number/Revision Insulation System Study RIMS B71 860512 103  
Class H - Safety Class 1E-600 Volt AC Stator  
(for SVC to  $1 \times 10^5$  rads); M&M Report 272 DATE January 28, 1977
- (2) Title/Number/Revision \_\_\_\_\_ RIMS \_\_\_\_\_  
\_\_\_\_\_ DATE \_\_\_\_\_
- (3) Title/Number/Revision \_\_\_\_\_ RIMS \_\_\_\_\_  
\_\_\_\_\_ DATE \_\_\_\_\_

OTHER (ANALYSIS, VENDOR DATA, ETC.) \_\_\_\_\_

- (4) Louis Allis letter to D. F. Ackerly dated March 26, 1986  
B71 860512 105). TAB E-5.
- (5) Nuclear Qualification Report 4-147739-NQR, Rev. A (TAB E-1).
- (6) WBN Environmental Dwg. 47E235-56, RI.
- (7) TVA Radiation Calculation WBNNAL3-029 RO (B45 860506 236).
- (8) TVA Condensation Calculation GENNAL6-002 RI (B45 851017 235).
- (9) Material Aging Calculation WAC-081 (TAB D-7).
- (10) TVA Degraded Voltage Calculation WBP-EVAR 8602001 RO (B43 860227 901).
- (11) TVA Flooding Calculation WBNOSG4-44 RO (B45 860110 218).
- (12) Memo to CEB files (CEB 841022 252) (TAB E-5).
- (13) System 30 Category and Operating Times WBNOSG4-008 R10 (B45 860320 224).

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 2 OF 30  
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Adyuly DATE 9/15/86 R     R      
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 9/15/86

B. CONCLUSION OF REVIEW (Check only one block)

- Equipment Qualified  
 Equipment Satisfies All Requirements Except Qualified Life or Justification of Replacement Schedule  
 Equipment Qualification Not Established by Documentation  
 Equipment Not Qualified Based on Test Failures

OPEN ITEMS AND QUALIFICATION DEFICIENCIES Refer to open items  
listed in the front of this binder.

1. Weephole to be drilled in terminal box (Open Item 6)

COMMENTS/RECOMMENDATIONS \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 3 OF 30  
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Aggely DATE 8/28/86 R     R      
MOTORS - OUTSIDE CONTAINMENT CHECKED 12 DATE 8/28/86

C. QUALIFICATION CRITERIA

Criteria Used to Demonstrate Qualification is in Accordance with the Following (Indicate Which Criteria is Applicable):

  X   Components are Qualified to the Criteria of 10CFR50.49 and/or NUREG-0588 Category I (IEEE323-1974)

       Components are Qualified to the Criteria of NUREG-0588 Category II or the DOR Guidelines of 1E Bulletin No. 79-01B (IEEE323-1971) (DOR Guidelines Applicable to only BFN)

JUSTIFICATION/COMMENTS \_\_\_\_\_

INDICATE OTHER REGULATORY DOCUMENTS AND/OR INDUSTRY STANDARDS MET

IEEE 334-1974 Type Test of Continuous Duty Class 1E Motors

NEMA MG1-1982 Motors and Generators

IEEE 117-1974 Evaluation of Insulating Materials for Random-Wound

AC Electric Machinery

PAGE B-5



BINDER NO. WBNEQ-MOT-004 PLANT \_\_\_\_\_ WBN \_\_\_\_\_ UNIT(S) 1 SHEET 4 OF 30  
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Adjudy DATE 8/28/86 R \_\_\_\_\_ R \_\_\_\_\_  
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/28/86

D. QUALIFICATION METHODOLOGY (Check only one block)

- Test of Identical Item Under Identical Conditions or Under Similar Conditions with Supporting Analysis
- Test of Similar Items with Supporting Analysis
- Analysis in Combination with Partial Type Test Data that Supports the Analytical Assumptions and Conclusions
- Experience with Identical or Similar Equipment Under Similar Conditions with Supporting Analysis

JUSTIFICATION/COMMENTS Refer to TAB C, Section 3.0, for additional details.

---

---

---

---

---

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 5 OF 30  
 BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Adkins DATE 8/28/86  
 MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/28/86

E. EQUIPMENT DESCRIPTION

Is the equipment identified in the qualification report identical to the plant equipment which requires qualification (yes/no/NA)? No

	<u>Plant Device</u>	<u>Qualification Document</u>	<u>Reference</u>
(1) Equipment Type	<u>Induction Motor</u>	<u>Motorettes</u>	<u>TAB C</u> <u>Sect 3.1</u> <u>Qual Rpt 1</u>
(2) Manufacturer	<u>Louis Allis</u>	<u>Louis Allis</u>	<u>Title pg</u>
(3) Model Number(s)	<u>3hp, 460 Vac</u> <u>NH5 Ins. Sys.</u> <u>M.O. 4-147739</u>	<u>NH5 Ins. Sys.</u>	
(4) Serial Number(s)	<u>4-147739-001</u> <u>4-147739-002</u>	<u>NA</u>	<u>TAB E-2</u> <u>Rpt</u> <u>4-147739-NOR,</u> <u>Rev A, Sect B</u>
(5) Identify Component-Unique checksheet attached:	<u>Supp 1, Component Unique Checklist, Motors.</u>		

JUSTIFICATION/COMMENTS The equipment provided for the plant consists of complete motor assemblies which included a random-wound stator with the NH5 insulation system. The qualification report documents the motorette testing performed on the NH5 insulation system in accordance with IEEE 117-1974. Applicability of the data from the qualification report is dependent solely upon the use of the NH5 system (L.A. System P4-9060) in the stator assembly and is independent of the motor horsepower rating.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 6 OF 30  
 BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Deckerly DATE 8/28/86 R     R      
 MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/28/86

F. INSTALLATION INTERFACES

List all interfaces pertinent to EQ identified in the test report and/or evaluation and reference the source. Is the interface a requirement for our application (Yes/No)? (Note below.) If yes, enter requirement in QMDS, if No, provide justification.

<u>Interface</u>	<u>Identify Interface</u>	<u>Plant Requirement? (Yes/No)</u>	<u>Reference Test Report</u>
Mounting Bolts	_____	<u>NA</u>	_____
External Process Connections	_____	<u>NA</u>	_____
Electrical Connections	_____	<u>NA</u>	_____
Conduit Seals	_____	<u>NA</u>	_____
Connector Seals	_____	<u>NA</u>	_____
Orientation	_____	<u>NA</u>	_____
Physical Configuration	<u>horizontal shaft</u>	<u>Yes</u>	_____
Other	_____	_____	_____

JUSTIFICATION/COMMENTS Refer to TAB C, Section 6.0, Interfaces.  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 7 OF 30  
 BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Rehedy DATE 8/28/86 R     R      
 MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/28/86

G. TEST SEQUENCE

(1) Test Sequence: Was the test sequence established to simulate the accident environment in accordance with IEEE-323 (74), paragraph 6.3.2 (yes/no/NA)? (note below)

	<u>Yes/No/NA</u>	<u>Reference</u>
(a) Equipment inspected for damage	<u>No</u>	<u>TAB C, Sect 3.2</u> <u>Note 1, Also TAB C</u>
(b) Baseline performance measurements taken	<u>Yes</u>	<u>Att 1, Sect B.2</u>
(c) Equipment aged:		<u>Qual. Rpt 1, App 1,</u> <u>pg 1, Subsect C.1,</u> <u>also TAB C,</u>
Thermal	<u>Yes</u>	<u>Att 1, Sect B.4</u>
Radiation	<u>NA</u>	<u>TAB C,</u> <u>Att 1, Sect C.2</u>
Wear	<u>NA</u>	<u>TAB C, Sect 3.1</u>
(d) Vibration/seismic testing conducted	<u>Yes</u>	<u>TAB C, Sect 3.2</u>
(e) Design basis event (DBE) exposure	<u>NA</u>	<u>TAB C, Sect 3.3</u>
(f) Post-DBE exposure	<u>NA</u>	<u>TAB C, Sect 3.3</u>
(g) Final inspection and disassembly	<u>NA</u>	<u>Note 2</u>

(2) Was the same piece of equipment used throughout the test sequence described in item (1) above (yes/no/NA)? Yes

(3) Have the test equipment, test equipment accuracies and calibration data been appropriately documented (yes/no/NA)? NA  
 (Reference Note 2)

JUSTIFICATION/COMMENTS Note 1 - Refer to Qual. Rpt 1, App I,  
Att 2, LTP-110, pg 1, Method of Test, Sect 2.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 8 OF 30  
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Okley DATE 8/28/86 R     R      
MOTORS - OUTSIDE CONTAINMENT CHECKED 13 DATE 8/28/86

G. TEST SEQUENCE (continued)

Note 2 - The continued ability of the motorette and the insulation  
system to function is predicated upon its ability to  
withstand dielectric proof tests as shown in TAB C, Att.1,  
Sect B.7. Failure of a dielectric proof test is a con-  
clusive failure and does not require accurate and calibrat-  
ed test equipment.









BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 12 OF 30  
 BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Agjuly DATE 8/28/86  
 MOTORS - OUTSIDE CONTAINMENT CHECKED Bj DATE 9/29/86

H. AGING (Continued)

(d) Is the radiation test exposure dose and dose rate acceptable (yes/no/NA)? NA (Reference \_\_\_\_\_).  
 \_\_\_\_\_).

Plant normal ambient radiation dose (rd) 9.3 x 10<sup>3</sup> rads

Test exposure dose (rd) \_\_\_\_\_

Test exposure dose rate (rd/hr) \_\_\_\_\_

Test exposure source type (e.g., Co-60 gamma) \_\_\_\_\_

JUSTIFICATION/COMMENTS Refer to TAB C, Att 1, Sect C.2.

(6) Vibration (non-seismic) Aging:

(a) Were the effects of non-seismic vibration induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes (Reference \_\_\_\_\_).  
 \_\_\_\_\_).

JUSTIFICATION/COMMENTS Refer to TAB C, Att 1, Sect B.5.

(b) Was the basis for vibration aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference Qual Rpt 1, App 1, Att 2, LTP-110, pg 2, Method of Test, Sect 3.b).

JUSTIFICATION/COMMENTS Mechanical stress testing performed in accordance with sect 2.2.3 of IEEE 117-1974 to simulate forces on the winding that occur in an actual motor.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 13 OF 30  
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Ackerly DATE 8/28/86 R     R      
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/28/86

H. AGING (Continued)

(7) Operational Stress Aging:

- (a) Were the effects of electrical, mechanical, and process operational stresses induced during normal and abnormal operation addressed in the qualification program (yes/no/NA)? Yes  
(Reference \_\_\_\_\_).

JUSTIFICATION/COMMENTS Refer to TAB C, Sect 3.1

- (b) Was the basis for stresses induced during operational aging identified and justified in the qualification program (yes/no/NA)? Yes (Reference \_\_\_\_\_).

JUSTIFICATION/COMMENTS Refer to TAB C, Sect 3.1

- (8) Was the qualified life of the equipment and its basis defined in the qualification program (yes/no/NA)? Yes  
(Reference \_\_\_\_\_).

Qualified life (Document in QMDS) Expected qualified life is 40+ years.

JUSTIFICATION/COMMENTS Refer to TAB C, Att 1, Sect D.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 14 OF 30  
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Agley DATE 8/28/86 R     R      
MOTORS - OUTSIDE CONTAINMENT CHECKED     DATE 8/29/86

H. AGING (Continued)

(9) Were replacement intervals for the equipment or its components defined in the qualification program (yes/no/NA)? Yes  
(Reference \_\_\_\_\_)

Replacement Intervals (Document in QMDS) Refer to TAB G.

JUSTIFICATION/COMMENTS No replaceable items were identified in the insulation system qualification program described in M&M Rpt 272  
The bearings and lubricants are routine maintenance items, the replacement of which are addressed in individual Qualification Maintenance Data Sheets in this binder. Basically, lubrication schedules, bearing replacement intervals and electrical and mechanical surveillance recommendations, particularly regarding the neoprene slingers and gaskets, are detailed.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 15 OF 30  
 BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Actualy DATE 9/2/86 R     R      
 MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 9/2/86

I. MATERIALS ANALYSIS

Identification of Materials Susceptible to Significant Thermal and/or Radiation Degradation and Aging (Use Section C of Binder for Detailed Materials Analysis)

<u>Material/Property/Function</u>	<u>Radiation Threshold</u>	<u>Reference</u>	<u>Activation Energy</u>	<u>Reference</u>
(a) <u>Type NH5 insulation system</u> <u>Bearing lubricant</u>	<u>1 x 10<sup>5</sup></u>	<u>Note 1</u>	<u>1.24</u>	<u>TAB D-7; WAC-081; Calc No. 1</u>
(b) <u>(Chevron SRI-2 Grease)</u>	<u>2 x 10<sup>8</sup></u>	<u>Note 2</u>	<u>Note 4</u>	<u>   </u>
(c) <u>Neoprene/mechanical/ slinger &amp; gasket</u>	<u>2 x 10<sup>6</sup></u>	<u>Note 3</u>	<u>Note 4</u>	<u>   </u>
(d) <u>   </u>	<u>   </u>	<u>   </u>	<u>   </u>	<u>   </u>

JUSTIFICATION/COMMENTS

Note 1: Radiation threshold is actual rating of system. Refer to TAB C,  
Att 1, Sect C.

Note 2: Refer to Digital Material Aging and Radiation Effects Library,  
Library Code No. 157-83A.

Note 3: Refer to Digital Material Aging and Radiation Effects Library,  
Library Code No. 202-83, Radiation Library Code 094-83.

Note 4: Consideration of long-term thermal degradation is not required  
because lubricant and slingers are not considered to be substances  
and devices with infinite lives. A surveillance and maintenance  
program is established in the QMDS in TAB G to ensure proper  
operation.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 16 OF 30  
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Adelady DATE 8/28/86  
MOTORS - OUTSIDE CONTAINMENT CHECKED BZ DATE 8/28/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS

- (1) Acceptance Criteria: Does the report/analysis identify the limiting values of performance characteristics which would constitute failure if not met (yes/no/NA)? Yes (Reference Qual Rpt 1, App 1, Att 2,

LTP-110, pg 2, Method of Test, Sect 3.d).

Identify Acceptance Criteria: Failure to withstand 10 minute applied potential tests at the following levels: turn to turn - 120 Vac; coil to coil - 600 Vac; coil to ground - 600 Vac.

- (2) Performance Characteristics: Does the report/analysis provide the performance characteristics for the equipment which should be verified before, after, and periodically during the test to judge equipment performance (yes/no/NA)? Yes (Reference Qual Rpt 1, App 1,

Att 2, LTP-110, pg 1, Method of Test, Sect 2).

Identify baseline and functional testing: Functional tests listed in section J.1 above. Each motorette was subjected to the following baseline tests: turn to turn - 400 Vac; coil to coil - 2000 Vac; coil to ground - 2000 Vac.

JUSTIFICATION/COMMENTS Also refer to TAB C, Att 1, Sects B.2. & B.7.

- (3) Does the qualification report/analysis describe loads (or load combinations) applied during DBE test (yes/no/NA)? NA  
(Reference \_\_\_\_\_)

JUSTIFICATION/COMMENTS Refer to TAB C, Sect 3.3.



BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 18 OF 30  
 BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Adjudy DATE 8/28/86 R     R      
 MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/28/86

J. EQUIPMENT ELECTRICAL CHARACTERISTICS NECESSARY TO ENSURE THE PERFORMANCE SPECIFICATIONS CAN BE SATISFIED UNDER ACCIDENT CONDITIONS (Continued)

(5)(b) <u>Parameter</u>	<u>Demonstrated Conditions</u>	<u>Reference</u>
Voltage	<u>NA</u>	<u>   </u>
Load	<u>NA</u>	<u>   </u>
Frequency	<u>NA</u>	<u>   </u>
Accuracy	<u>NA</u>	<u>   </u>
<u>Other(s)</u>	<u>   </u>	<u>   </u>
<u>   </u>	<u>   </u>	<u>   </u>
<u>   </u>	<u>   </u>	<u>   </u>

JUSTIFICATION/COMMENTS Refer to TAB C, Sect 5.0 for discussion of  
Voltage and Frequency requirements.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 19 OF 30

BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Ockerly DATE 9/15/86 R     R    

MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 9/15/86

K. REQUIRED OPERATING ENVIRONMENT

Reference Environmental Drawing No. 47E235-56 R1 Node 15

(1) Normal Max

(2) Abnormal Max

(a) Temperature (°F) 104

(a) Temperature (°F) 110

(b) Pressure (psig) ATM-

(b) Pressure (psig) ATM-

(c) Humidity (%) 80

(c) Humidity (%) 90

(d) Radiation (rd) 9.3 x 10<sup>3</sup>\*

(d) Radiation (rd) -

per WBNNAL3-025

(3) Process Interfaces: None.

(4) State anticipated occurrence frequency and duration of abnormal conditions: 8 hours per excursion and will occur less than 1% of the plant life.

(5) Accident (worst case for any combination of specified accident parameter including peak, duration, and profile):

(a) Temperature (°F)	(1) <u>196°F/15 min decaying to 110°F in 24 hrs. continuing for 30 days.</u>	Accident type	<u>RH/A LOCA</u>
(b) Pressure (psig)	(2) <u>110 for 100 days ATM</u>	Accident type	<u>HELB</u>
(c) Humidity (%)	<u>100</u>	Accident type	<u>HELB</u>
(d) Radiation (rd)	<u>1.1 x 10<sup>4</sup>*</u>	Accident type	<u>LOCA</u>
(e) Spray Type	<u>NA</u>	Accident type	<u>   </u>

\* Radiation site specific dose per TVA Calculation WBNNAL3-029 RO (B45 860506 236).

\*\* For additional details, refer to TAB C, Att 1, Section C.1.



BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 20 OF 30  
 BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Adyely DATE 8/28/86 R     R      
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/18/86

K. REQUIRED OPERATING ENVIRONMENT (Continued)

Comments (duration/peak/profile/spray composition and pH, margin, etc.):

Motors are located outside containment and are not subject to chemical spray.

- (6) Is the equipment subject to moisture or liquid intrusion which can affect the performance of the equipment under design basis accident conditions (yes/no/NA)? Yes (Reference TVA Calculation

GENNAL6-002 (B45 851017 235) Potential for Condensate Formation, also refer to TAB C, Sect 7.0).

- (7) Subject to submergence (yes/no/NA)? No  
 (Reference TAB C, Sect 7.0).

Identify initiation time and duration of submergence: \_\_\_\_\_

- (8) Special environmental calculations (temp., rad., etc.)

<u>Type</u>	<u>RIMS No.</u>
<u>Radiation WBNNAL3-029 RO</u>	<u>B45 860506 236</u>
<u>Condensate GENNAL6-002</u>	<u>B45 851017 235</u>
_____	_____
_____	_____

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 21 OF 30  
 BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED October DATE 8/28/86 R     R      
 MOTORS - OUTSIDE CONTAINMENT CHECKED fg DATE 8/28/86

L. SUMMARY COMPARISON OF TEST CONDITIONS TO SPECIFIED CONDITIONS

(1) Comparison of worst-case maximum parameters:

<u>Parameter</u>	<u>Specified</u>	<u>Demonstrated</u>	<u>Reference</u>
Operating Time	<u>Note 1</u>	<u>                    </u>	<u>                    </u>
Temperature (°F)	<u>Note 1</u>	<u>                    </u>	<u>                    </u>
Pressure (psig)	<u>ATM</u>	<u>Att 1, Sect 3.5</u>	<u>                    </u>
Relative Humidity (%)	<u>100</u>	<u>TAB C,</u> <u>Att 1 Sect B.6</u>	<u>                    </u>
*Chemical Spray	<u>NA</u>	<u>TAB C, Sect 3.4</u>	<u>                    </u>
**Radiation (rd)	<u>2.03x10<sup>4</sup></u>	<u>TAB C,</u> <u>Att 1, Sect C.2</u>	<u>                    </u>
Submergence	<u>NA</u>	<u>TAB C, Sect 7.0</u>	<u>                    </u>

\*Includes spray concentration, flowrate, density, duration, and pH.

\*\*Enter 40-year integrated normal dose plus integrated accident dose and specify type.

(2) Comparison of worst-case profiles and margin assessment:

<u>Parameter</u>	<u>Test Profile Envelopes Specified (Yes/No/NA)</u>	<u>Reference</u>
Temperature	<u>Yes</u>	<u>TAB C,</u> <u>Att 1, Sect C.1</u>
Pressure	<u>Yes</u>	<u>TAB C, Sect 3.5</u>
Relative Humidity	<u>Yes</u>	<u>TAB C,</u> <u>Att 1, Sect B.6</u>
Chemical Spray	<u>NA</u>	<u>TAB C, Sect 3.4</u>
Submergence	<u>NA</u>	<u>TAB C, Sect 7.0</u>

JUSTIFICATION/COMMENTS Note 1: Worst case temperature is the result of a HELB and is 196°F (91°C) for 15 minutes, decaying to 110°F (43.3°C) in 24 hrs. and continuing for 30 days.

Worst case life is based upon conditions resulting from a LOCA which is 110°F for a duration of 100 days. See TAB C, Att 1, Sect C.1.



BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 23 OF 30  
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Actually DATE 8/28/86 R    R     
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/28/86

M. OPERABILITY TEST RESULTS

- (1) Identify the safety function(s) of this equipment:  
(Reference \_\_\_\_\_)

JUSTIFICATION/COMMENTS Motors utilizing the stator insulation system tested, must be capable of starting and maintaining operation.

Refer to TAB A.

- (2) Did the equipment perform its intended function during the simulated design basis accident exposure (yes/no/NA)? NA  
(Reference \_\_\_\_\_)

JUSTIFICATION/COMMENTS Refer to TAB C, Sect 3.3.

- (3) Did the equipment perform its intended function during the simulated post-design basis accident exposure (yes/no/NA)? NA  
(Reference \_\_\_\_\_)

JUSTIFICATION/COMMENTS Refer to TAB C, Sect 3.3.

- (4) Did the test demonstrate the operability requirements for the required time interval for which the equipment is required to operate (yes/no/NA)? NA (Reference \_\_\_\_\_)

JUSTIFICATION/COMMENTS TAB C, Att 1, Sect D.

PAGE B-25



BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 25 OF 30  
BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Accurly DATE 8/28/86 R     R      
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/28/86

N. MAINTENANCE AND SURVEILLANCE

Has the qualification program identified those surveillance, maintenance, and inspection parameters which are essential to maintain qualification and which aid in detecting degrading materials or equipment performance (yes/no/NA)? Yes (Enter all requirements in Section G of the Binder - Qualification Maintenance Data Sheets).

JUSTIFICATION/COMMENTS No replaceable items were identified in the insulation system qualification program described in M&M Report 272 relative the insulation system. The bearings and lubricants are routine maintenance items, the replacement of which are addressed in individual Qualification Maintenance Data Sheets in this binder. Basically, lubrication schedules, bearing replacement intervals and electrical and mechanical surveillance recommendations, particularly regarding the neoprene slingers and gaskets, are detailed in the QMDS located in TAB G.

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 26 OF 30  
 BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED October DATE 8/28/86 R     R      
 MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 9/28/86

0. SUMMARY OF REVIEW

- |   | <u>Yes/No/NA</u> |
|---|------------------|
| (1) Documented evidence of qualification adequate (Have all assumptions, mathematical models, and all extrapolations of test data used in an analysis been justified and documented)? | <u>Yes</u>       |
| (2) Any exceptions (i.e., sound reasons to the contrary) taken to the specified qualification level adequately justified?   | <u>Yes</u>       |
| (3) Choice of qualification methodology adequately justified?   | <u>Yes</u>       |
| (4) If analysis was performed, complete the following:  |                  |
| (a) Were equipment performance requirements identified?   | <u>Yes</u>       |
| (b) Were specific features and failure modes and effects analyzed?  | <u>Yes</u>       |
| (c) Were assumptions and mathematical models used together with appropriate justification for their use?  | <u>Yes</u>       |
| (d) Were environmental parameters which affect equipment performance identified?  | <u>Yes</u>       |
| (5) Adequate similarity between equipment and test specimen established?  | <u>Yes</u>       |
| (6) Aging degradation evaluated adequately?   | <u>Yes</u>       |
| (a) Mechanical and/or cycle aging addressed?  | <u>Yes</u>       |
| (b) Equipment aged to end of life condition prior to application of DBE conditions?   | <u>Yes</u>       |
| (c) Absence of preaging in test/analysis justified?   | <u>NA</u>        |
| (d) Materials susceptible to thermal/radiation aging identified?  | <u>Yes</u>       |

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 27 OF 30  
 BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Checked DATE 8/28/86 R     R      
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 8/28/86

0. SUMMARY OF REVIEW (Continued)

	<u>Yes/No/NA</u>
(e) Normally operating state of device (e.g., normally energized) considered?	<u>Yes</u>
(7) Qualified life or replacement schedule established?	<u>Yes</u>
(8) Criteria regarding temperature/pressure exposure satisfied?	<u>Yes</u>
(a) Peak temperature adequate	<u>Yes</u>
(b) Peak pressure adequate	<u>Yes</u>
(c) Duration adequate	<u>Yes</u>
(d) Required profile enveloped adequately	<u>Yes</u>
(e) Steam exposure adequate	<u>NA</u>
(9) Criteria regarding test sequence satisfied?	<u>Yes</u>
(10) Criteria regarding spray satisfied?	<u>NA</u>
(a) Was the spray testing done while under the extremes of pressure and temperature?	<u>NA</u>
(b) Does the spray concentration, flow rate, density, duration, and pH used in tests meet or exceed those to be used for the plant?	<u>NA</u>
(11) Criteria regarding submergence satisfied?	<u>Yes</u>
(12) Criteria regarding radiation satisfied?	<u>Yes</u>
(a) Was dose rate considered?	<u>NA</u>
(b) Was beta radiation considered?	<u>Section P - Note 1</u>
(13) Criteria regarding operability status/mode satisfied?	<u>Yes</u>
(14) Criteria regarding test failures or anomalies satisfied?	<u>Yes</u>

PAGE B-29



BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 28 OF 30  
 BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Adjudy DATE 8/28/86 R     R      
 MOTORS - OUTSIDE CONTAINMENT CHECKED 17 DATE 8/28/86

O. SUMMARY OF REVIEW (Continued)

- |  | <u>Yes/No/NA</u> |
|--|------------------|
| (15) Criteria regarding functional testing satisfied?  | <u>Yes</u>       |
| (a) Does the test plan/report specify an acceptance criteria for equipment performed?  | <u>Yes</u>       |
| (b) Was an initial base line test done to establish required performance characteristics?  | <u>Yes</u>       |
| (c) Has the test/analysis demonstrated that performance performance specifications and characteristics (e.g., voltage, load frequency, and other electrical characteristics) can be ensured? | <u>Yes</u>       |
| (16) Criteria regarding instrument accuracy satisfied?   | <u>NA</u>        |
| (17) Test duration margin (1 hour + function time) satisfied?  | <u>Yes</u>       |
| (a) Is the minimum specified operating time at least 1 hour?   | <u>Yes</u>       |
| (b) If exception to the 1-hour minimum operating time was taken, was adequate justification provided?  | <u>NA</u>        |
| (18) Criteria regarding synergistic effects satisfied?   | <u>NA</u>        |
| (19) Criteria regarding margins satisfied?   | <u>Yes</u>       |
| (20) Maintenance and surveillance requirements adequately identified?  | <u>Yes</u>       |

P. DISCUSSION

NOTE: Motors are located in areas throughout the Auxiliary Building.  
Beta-radiation is confined to the Reactor Bldg. by plant  
design; therefore, these motors are not required to be  
evaluated for the effects of beta radiation.

PAGE B-30

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 29 OF 30  
 BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Accepted DATE 8/28/86 R     R      
 MOTORS - OUTSIDE CONTAINMENT CHECKED     DATE 8/28/86

SUPPLEMENT 1 Page 1 of 2  
 COMPONENT-UNIQUE CHECKLIST  
 MOTORS

EQUIPMENT IDENTIFICATION

(1) Is the motor identified in the qualification report identical to the plant motors which require qualification (yes/no/NA)? No

<u>Item</u>	<u>Plant</u>	<u>Report</u>	<u>Acceptable (Yes/No/NA)</u>	<u>Report Section</u>
(a) Insulation system materials	<u>NH5</u> (P4-9060)	<u>NH5</u> (P4-9060)	<u>Yes</u>	refer to (2) <u>supplement</u>
(b) Coil construction (form or random wound, cast)	<u>Random</u>	<u>Random</u>	<u>Yes</u>	Qual Rpt 1, <u>App 1, Intro</u>
(c) Insulation class (B, F, H)	<u>H</u>	<u>H</u>	<u>Yes</u>	Qual Rt 1, <u>pg 1, Scope</u>
(d) Lubricant				
Manufacturer	<u>Chevron</u>	<u>NA</u>	<u>Yes</u>	<u>refer to</u> <u>TAB C,</u> <u>Sect 4.2</u>
Type	<u>SRI-2</u>	<u>NA</u>	<u>Yes</u>	
(e) Bearing				
Manufacturer	<u>MRC</u>	<u>NA</u>	<u>Yes</u>	refer to (3) <u>this supplement</u>
Type	<u>Anti-friction</u>	<u>NA</u>	<u>Yes</u>	
Bearing life	<u>   </u>	<u>   </u>	<u>   </u>	<u>   </u>
(f) Seals				
Manufacturer	<u>-</u>	<u>NA</u>	<u>   </u>	<u>   </u>
Type	<u>Slinger</u>	<u>NA</u>	<u>Yes</u>	refer to (5) <u>this supplement</u>
Material	<u>Neoprene</u>	<u>   </u>	<u>Yes</u>	<u>   </u>

PAGE B-31

BINDER NO. WBNEQ-MOT-004 PLANT WBN UNIT(S) 1 SHEET 30 OF 30  
 BINDER TITLE LOUIS ALLIS-INDUCTION COMPUTED Checked DATE 8/28/86 R      R       
MOTORS - OUTSIDE CONTAINMENT CHECKED B DATE 9/28/86

EQUIPMENT IDENTIFICATION (Continued)

<u>Item</u>	<u>Plant</u>	<u>Report</u>	<u>Acceptable (Yes/No/NA)</u>	<u>Report Section</u>
(g) Motor lead insulation	<u>Si Rubber</u>	<u>Si Rubber</u>	<u>Yes</u>	<u>TAB C, Att 1, Sect C.3</u>

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

(2) Does the qualification report indicate that the motorette insulation system is the same as that used on the motors (yes/no/NA)? Yes  
 (Reference \_\_\_\_\_).  
 \_\_\_\_\_).

Comments: TAB E-2, document 4-147739-NQR, Rev A, Sheet 1, item B.2.  
 \_\_\_\_\_

(3) Has the vendor provided the bearing rating (yes/no/NA)? Yes  
 (Reference \_\_\_\_\_).  
 \_\_\_\_\_).

Comments: Refer to TAB C, Sect 4.1.  
 \_\_\_\_\_

(4) Was the lubricant included in the test program (yes/no/NA)? No  
 (Reference \_\_\_\_\_).  
 \_\_\_\_\_).

Comments: Refer to TAB C, Sect 4.2.  
 \_\_\_\_\_

(5) Were the seals included in the test program (yes/no/NA)? No  
 (Reference \_\_\_\_\_).  
 \_\_\_\_\_).

Comments: Refer to TAB C, Sect 4.3.  
 \_\_\_\_\_

PAGE B-32