

ENCLOSURE 4  
WATTS BAR NUCLEAR PLANT (WBN)  
CALCULATION WBN-EEB-MS-TI15-0011  
480V NON-CLASS 1E POWER CABLE ASSOCIATED CIRCUITS

9206260077 920615  
PDR ADOCK 05000390  
A PDR

TITLE 480V Non-Class 1E Power Cable Associated Circuits			PLANT/UNIT WBN 1&2		
PREPARING ORGANIZATION NE, EE		KEY NOUNS (Consult RIMS DESCRIPTORS LIST) Cable, Associated, Circuit Anal, Non-Safety Rel, Power			
BRANCH/PROJECT IDENTIFIERS WBN EEB-MS-TI15-0011		Each time these calculations are issued, preparers must ensure that the original (RO) RIMS accession number is filled in.			
		Rev (for RIMS' use)		RIMS accession number	
		RO	900315E0015	B26900220409	
APPLICABLE DESIGN DOCUMENT(S) WB-DC-30-4 R5 EEB TI-15 RO FSAR 8.3.1.4.3		R 13 911030D0022 (36)		B26 '91 1002 401	
		R 14 920117B0015 (31)		B26 '92 0102 400	
SAR SECTION(S) 8.3		UNID SYSTEM(S) NA		R 15 APR 28 1992 (438) B18 '92 0427 253	
Revision 0		R 13	R 14	R 15	Safety-related? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
ECN No. (or indicate Not Applicable) NA		DCN M-13300B	DCN M-15092-A	DCNs M-08614-A M-12212-A	Statement of Problem FSAR Section 8.3 identifies acceptable protection of Non-1E circuits located in category 1 structures as two breakers in series, one breaker and one fuse in series, or one single fuse. In addition to meeting this protection requirement for reliability, it is necessary to identify the ratings of protective devices that will protect the class 1E circuits from thermal damage caused by associated non-1E circuits.
Prepared G.S. Bates *		<i>R. Bates</i>	<i>J. Mangel</i>	<i>Mac Roopman</i> 04-25-92	
Checked T.B. Thorsell*		<i>J. Mangel</i>	<i>D. Caldwell</i>	<i>Porter</i> 04-25-92	
Reviewed T.B. Thorsell*		<i>J. Mangel</i>	<i>D. Caldwell</i>	<i>Porter</i>	
Approved P. Schaffer/M.C. Brickey *		<i>P. Schaffer</i>	<i>M.C. Brickey</i>	<i>Porter</i>	
Date 10-20-90		10-2-91	12/31/91	4/25/92	
List all pages added by this revision.		See Rev. Log	SEE REV. LOG	See Rev Log	
List all pages deleted by this revision.		↓	↓	↓	
List all pages changed by this revision.		↓	↓	↓	

Abstract \*For original signatures see RIMS No. B26900220409

These calculations contain an unverified assumption(s) that must be verified later. Yes  No

This calculation reviews all 480V non-1E power cables that have an end point in a category 1 building for proper protection to assure that associated class 1E circuits are protected against thermal damage. Included in this population of non-1E cables are appendix R 480V associated circuits. Sections 8.0 and 9.0 provide the summary of results and conclusions.

See rev. log for total pages and FSAR compliance.

## ORIGINAL

Microfilm and store calculations in RIMS Service Center. Microfilm and destroy.  *EEB*

Microfilm and return calculations to: Calculation Control Center Address: QAC-IC-WBN

TITLE <b>480V NON-CLASS IE POWER CABLE ASSOCIATED CIRCUITS</b>		PLANT/UNIT <b>WBN 1&amp;2</b>	
PREPARING ORGANIZATION <b>NE, EE</b>		KEY NOUNS (Consult RIMS DESCRIPTORS LIST) <b>CABLE, ASSOCIATED, CIRCUIT ANAL, NON SAFETY REL, POWER</b>	
BRANCH/PROJECT IDENTIFIERS <b>WBN EEB-MS-TI15-0011</b>		Each time these calculations are issued, preparers must ensure that the original (RO) RIMS accession number is filled in. Rev (for RIMS' use) RIMS accession number	
APPLICABLE DESIGN DOCUMENT(S) <b>WB-DC-30-4 R5 EEB TI-15 RO FSAR 8.3.1.4.3</b>		R10 <b>900315E0015</b>	<b>B26900220409</b>
SAR SECTION(S) <b>8.3</b>		R10 <b>910219D0005</b>	<b>B26 '91 0102 403</b>
L'NID SYSTEM(S) <b>NA 4-16-91</b>		R11 <b>10514B0005</b>	<b>B26 '91 0419 401</b>
Revision 0		R12 <b>910826E0001</b>	<b>B26 '91 0802 405</b>
ECN No. (for indicate Not Applicable) <b>NA 4-16-91</b>		Safety-related? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
Prepared <b>C. S. BATES *</b>		Statement of Problem <b>FSAR SECTION 8.3 IDENTIFIES ACCEPTABLE PROTECTION OF NON-IE CIRCUITS LOCATED IN CATEGORY I STRUCTURES AS TWO BREAKERS IN SERIES, ONE BREAKER AND ONE FUSE IN SERIES, OR ONE SINGLE FUSE. IN ADDITION TO MEETING THIS PROTECTION REQUIREMENT FOR RELIABILITY, IT IS NECESSARY TO IDENTIFY THE RATINGS OF PROTECTIVE DEVICES THAT WILL PROTECT THE CLASS IE CIRCUITS FROM THERMAL DAMAGE CAUSED BY ASSOCIATED NON-IE CIRCUITS.</b>	
Checked <b>T. B. THORSELL *</b>		Date <b>2-20-90</b>	
Revised <b>T. B. THORSELL *</b>		Use form TV 10534 if more space required	
Approved <b>P. SCHAFFER / M. C. BRICKEY *</b>		SEE REV LOG	
Date <b>2-20-90</b>		List all pages added by this revision.	
		List all pages deleted by this revision.	
		List all pages changed by this revision.	
Abstract <b>* FOR ORIGINAL SIGNATURES SEE RIMS NO. B26900220409</b>			
These calculations contain an unverified assumption(s) that must be verified later. <del>Yes</del> <input checked="" type="checkbox"/> No <input checked="" type="checkbox"/>			
THIS CALCULATION REVIEWS ALL 480V NON-IE POWER CABLES THAT HAVE AN END POINT IN A CATEGORY I BUILDING FOR PROPER PROTECTION TO ASSURE THAT ASSOCIATED CLASS IE CIRCUITS ARE PROTECTED AGAINST THERMAL DAMAGE. INCLUDED IN THIS POPULATION OF NON-IE CABLES ARE APPENDIX R 480V ASSOCIATED CIRCUITS. Sections 8.0 and 9.0 provide the summary of results and conclusions. SEE REV LOG FOR TOTAL PAGES AND FSAR COMPLIANCE.			
<input type="checkbox"/> Microfilm and store calculations in RIMS Service Center.		Microfilm and destroy. <input type="checkbox"/> QAC-IC -WBN	
<input checked="" type="checkbox"/> Microfilm and return calculations to: <b>BECKY YOUNG</b>		Address: <b>7508, WBN</b>	

100B5

QA Record

TITLE <b>480V NON-CLASS IE POWER CABLE ASSOCIATED CIRCUITS</b>		PLANT/UNIT <b>WBN 1&amp;2</b>	
PREPARING ORGANIZATION <b>NE, EE</b>		KEY NOUNS (Consult RIMS DESCRIPTORS LIST)	
BRANCH/PROJECT IDENTIFIERS <b>WBN EEB-MS-TI15-0011</b>		Each time these calculations are issued, preparers must ensure that the original (RO) RIMS accession number is filled in. Rev (for RIMS' use) RIMS accession number	
APPLICABLE DESIGN DOCUMENT(S) <b>WB-DC-30-4 R5 EEB TI-15 RO FSAR 8.3.1.4.3</b>		R 7 <b>900315E0015</b>	<b>B26 '90 0828 405</b>
SAR SECTION(S) <b>8.3</b>		R 8 <b>901027E0007</b>	<b>B26 '90 1005 417</b>
UNID SYSTEM(S)		R 9 <b>910104E0034</b>	<b>B18 901216 502</b>
Revision 0	R 7	R 8	R 9
ECN No. (or indicate Not Applicable)	DCN <b>M-10541-B</b>	DCN <b>F-13654-A</b>	DCNs <b>M-09494-A C-03205-A</b>
Prepared <b>G. S. BATES *</b>	<b>8-25-90</b> <i>T.M. Barber</i>	<b>10-5-90</b> <i>T.M. Barber</i>	<b>2-11-90</b> <i>T.M. Barber</i>
Checked <b>T. B. THORSELL *</b>	<b>8-27-90</b> <i>T.A. Adams</i>	<b>10-5-90</b> <i>C.W. Smith</i>	<b>12-14-90</b> <i>GCP</i>
Reviewed <b>T. B. THORSELL *</b>	<b>9-27-90</b> <i>T.M. Barber</i>	<b>10-18-90</b> <i>T.M. Barber</i>	<b>12-14-90</b> <i>T.M. Barber</i>
Approved <b>P. SCHAFFER / M.C. BRICKEY *</b>	<b>C.C. Lyke</b> <i>SM MCB</i>	<b>C.C. Lyke</b> <i>SM MCB</i>	<i>M. Brickey</i>
Date <b>2-20-90</b>	<b>8/27/90</b>	<b>10/5/90</b>	<b>12-14-90</b>
Use form T-10534 if more space required.	List all pages added by this revision.		
	List all pages deleted by this revision.		
	List all pages changed by this revision.		
Statement of Problem <b>FSAR SECTION 8.3 IDENTIFIES ACCEPTABLE PROTECTION OF NON-IE CIRCUITS LOCATED IN CATEGORY I STRUCTURES AS TWO BREAKERS IN SERIES, ONE BREAKER AND ONE FUSE IN SERIES, OR ONE SINGLE FUSE. IN ADDITION TO MEETING THIS PROTECTION REQUIREMENT FOR RELIABILITY, IT IS NECESSARY TO IDENTIFY THE RATINGS OF PROTECTIVE DEVICES THAT WILL PROTECT THE CLASS IE CIRCUITS FROM THERMAL DAMAGE CAUSED BY ASSOCIATED NON-IE CIRCUITS.</b>			
Abstract <b>* FOR ORIGINAL SIGNATURES SEE RIMS NO. B26906220409</b> These calculations contain an unverified assumption(s) that must be verified later. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> <b>THIS CALCULATION REVIEWS ALL 480V NON-IE POWER CABLES THAT HAVE AN END POINT IN A CATEGORY I BUILDING FOR PROPER PROTECTION TO ASSURE THAT ASSOCIATED CLASS IE CIRCUITS ARE PROTECTED AGAINST THERMAL DAMAGE. INCLUDED IN THIS POPULATION OF NON-IE CABLES ARE APPENDIX R 480V ASSOCIATED CIRCUITS.</b> <b>SEE REV LOG FOR TOTAL PAGES AND FSAR COMPLIANCE.</b>			

Microfilm and store calculations in RIMS Service Center. *Calculation Control Center*

Microfilm and return calculations to: **BECKY YOUNG** Address: **TSOB, WBN**

*QAC-IE-WBN*

TITLE <b>480V NON-CLASSIE POWER CABLE ASSOCIATED CIRCUITS</b>				PLANT/UNIT <b>WBUP 1 &amp; 2</b>	
REPAIRING ORGANIZATION <b>NE, EE</b>		KEY NOUNS (Consult RIMS DESCRIPTORS LIST)			
BRANCH/PROJECT IDENTIFIERS <b>WBN EEB-M9-TI15-0011</b>		Each time these calculations are issued, preparers must ensure that the original (RO) RIMS accession number is filled in. Rev (for RIMS' use) RIMS accession number			
APPLICABLE DESIGN DOCUMENT(S) <b>WB-DC-90-4 R5 EEB TI-15 RO FSAR B.3.1.4.3</b>		R4	<b>900706D0008</b>	<b>B26 '90 0615 413</b>	
SAR SECTION(S) UNID SYSTEM(S) <b>B.3</b>		R5	<b>900710D0008</b>	<b>B26 '90 0618 413</b>	
Revision 0		R6	<b>900730A0005</b>	<b>B26 '90 0706 404</b>	
ECN No. (or indicate Not Applicable)		R74	DCN <b>M10448A</b>	R75	DCN <b>M08613A</b>
Prepared <b>G. S. BATES *</b>		R76	DCN <b>K-03129-A</b>	Safety-related? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
Checked <b>T. B. THORBELL *</b>		Statement of Problem <b>FSAR SECTION B.3 IDENTIFIES ACCEPTABLE PROTECTION OF NON-IE CIRCUITS LOCATED IN CATEGORY I STRUCTURES AS TWO BREAKER IN SERIES, ONE BREAKER AND ONE FUSE IN SERIES, OR ONE SINGLE FUSE.</b>			
Reviewed <b>T. B. THORBELL *</b>		IN ADDITION TO MEETING THIS PROTECTION REQUIREMENT FOR RELIABILITY, IT IS NECESSARY TO IDENTIFY THE RATINGS OF PROTECTIVE DEVICES THAT WILL PROTECT THE CLASS IE CIRCUITS FROM THERMAL DAMAGE CAUSED BY ASSOCIATED NON-IE CIRCUITS.			
Approved <b>P. J. SCHAFFER * M. C. BRICKEY *</b>					
Date <b>2-20-90</b>					
Use form TV 10534 if more space required.	List all pages added by this revision.	SEE REV. LOG	SEE REV. LOG	SEE REV. LOG	
	List all pages deleted by this revision.	SEE REV. LOG	SEE REV. LOG	SEE REV. LOG	
	List all pages changed by this revision.	SEE REV. LOG	SEE REV. LOG	SEE REV. LOG	

**ORIGINAL**

**Abstract**

These calculations contain an unverified assumption(s) that must be verified later. Yes  No

THIS CALCULATION REVIEWS ALL 480V NON-IE POWER CABLES THAT HAVE AN END POINT IN A CATEGORY I BUILDING FOR PROPER PROTECTION TO ASSURE THAT ASSOCIATED CLASS IE CIRCUITS ARE PROTECTED AGAINST THERMAL DAMAGE. INCLUDED IN THIS POPULATION OF NON-IE CABLES ARE APPENDIX R 480V ASSOCIATED CIRCUITS.

R4 | FSAR COMPLIANCE REVIEW M. C. Brickey DATE 6-15-90  
(ABC/LE)

R5 | FSAR COMPLIANCE REVIEW M. C. Brickey DATE 6-18-90

\* FOR ORIGINAL SIGNATURES, SEE RIMS NO. B26900220409.

<input type="checkbox"/> Microfilm and store calculations in RIMS Service Center.	Microfilm and destroy. <input type="checkbox"/>
<input checked="" type="checkbox"/> Microfilm and return calculations to: <b>BECKY YOUNG</b>	Address: <b>TSOB, WBN</b>

TITLE 480 V Non-Class 1E Power Cable Associated Circuits				PLANT/UNIT WBNP 1&2	
PREPARING ORGANIZATION TVA, EE		KEY NOUNS (Consult RIMS DESCRIPTORS LIST) CABLE, ASSOCIATED, CIRCUIT ANAL, NON SAFETY REL, POWER			
BRANCH/PROJECT IDENTIFIERS WBN EEB-MS-TI15-0011		Each time these calculations are issued, preparers must ensure that the original (RO) RIMS accession number is filled in.			
Rev		(for RIMS' use)		RIMS accession number	
RO	900315E0015	B26 '90	0220	409	
APPLICABLE DESIGN DOCUMENT(S) WB-DC-30-4 R5 EEB TI-15 RO FSAR 3.3.1.4.3	R 1	900524D0005	B26 '90	0413	410
	R 2	900716B0001	B26 '90	0427	405
SAR SECTION(S) 8.3	UNID SYSTEM(S)	R 3	900730A0001	B26 '90	0511 409
Revision 0	R1	R2	R3	Safety-related? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
ECN No. (or indicate Not Applicable) N/A			DCN P-5297-A	Statement of Problem	
Prepared W. Bates	4-12-90 T.M. Barber	4-27-90 T.M. Barber	5-3-90 T.M. Barber	FSAR Section 3.3 identifies acceptable protection of non-1E circuits located in Category I structures as two breakers in series, one breaker and one fuse in series, or one single fuse.	
Checked T.B. Small	4/12/90 WJH	4-27-90 WJH	5/1/90 CP	In addition to meeting this protection requirement for reliability, it is necessary to identify the ratings of protective devices that will protect the Class 1E circuits from thermal damage caused by associated non-1E circuits.	
Reviewed T.B. Small	4/12/90 WJH	4-27-90 WJH	5/1/90 CP		
Approved Date 2-20-90	C.C. Lyke for MCB 4/13/90	W. Bates 4-27-90	C.C. Lyke for MCB 5/10/90		
Use form T-10534 if more space required.	List all pages added by this revision. See TVA				
	List all pages deleted by this revision. Form 10534				
	List all pages changed by this revision. Rev. Log				

**Abstract**

These calculations contain an unverified assumption(s) that must be verified later. Yes  No

This calculation reviews all 480 V non-1E power cables that have an end point in a Category I building for proper protection to assure that associated Class 1E circuits are protected against thermal damage. Included in this population of non-1E cables are Appendix R 480 V associated circuits.

RO: FSAR Compliance Review W. Bates Date 2-20-90

R1: FSAR COMPLIANCE REVIEW C.C. Lyke for MCB DATE 4/13/90

R2: FSAR COMPLIANCE REVIEW W. Bates DATE 4-27-90

R3: FSAR COMPLIANCE REVIEW C.C. Lyke for MCB DATE 5/10/90

SEE REV LOG FOR TOTAL PAGES

~~205~~  
THIS CALCULATION CONTAINS ~~204~~ PAGES INCLUDING PAGES 163A, 163B, 181A AND 181B, 3A, ATTACHMENT M08663A (3A.1-26), p. 3B

Microfilm and store calculations in RIMS Service Center. Microfilm and destroy.

Microfilm and return calculations to: Becky Young Address: 113-TSOB-WBN



CHECKED WSTH DATE 4/16/90 CHECKED TAD DATE 4-27-90

WBN EEB-MS-TI15-0011 Title: 480 V Non Class 1E Power Cable Associated Circuits		REVISION LOG
Revision No.	DESCRIPTION OF REVISION	Date Approved
0	Initial Issue	
1	REVISED PAGE 5 & 1, & PAGE 4 ADDED PAGE 3A AND ATTACHMENT M08663A (SH.1→6)	
2	ADD UNVERIFIED ASSUMPTION (P. 8); ADDED PAGE 3B; REVISED P.1,2,&5	
3	ADD PAGE 3C & ATTACHMENT P5297A (SH1→3); REVISE PAGES 1,2,4,&5 TOTAL PAGES REV.3= 8 . FOR COMPLETE CALCULATION ADD REV.1,2,& 3 TO REV. 0	YMB 5-3-90 CP 5/7/90
4	<sup>EJ 6/13/90</sup> <del>ADDED ATTACHMENT NOS. M08663A, PAGES 1-7 AND M10448A, PAGES 1-7.</del> ADDED PAGES 1A AND 2D. REVISED PAGES 1 & 2. TOTAL PAGES FOR REVISION 4: <sup>18</sup> / <del>13</del> PAGES. FOR COMPLETE CALCULATION COMBINE REVISIONS 0, 1, 2, 3, AND 4. <del>TO</del>	YMB 6-13-90 EJ 6/13/90
5	ADDED ATTACHMENT NO. M08663A, PAGES 1-8 AND PAGE 3E REVISED PAGES 1A, 2, 4, AND 5. TOTAL PAGES FOR REVISION 5: 14 FOR COMPLETE CALCULATION COMBINE REVISION 0, 1, 2, 3, 4 AND 5.	EJ CP 6/13/90
6	ISSUED CALC. TO SUPPORT DCN K-03123-A WHICH DELETES PAX MULTIPLEXER XFMR O-DXF-253-1 FROM 480V AUX BLDG COM MCC B, COMPT SFI. THE DELETION IS CONSERVATIVE AND WILL BE INCORPORATED IN THE NEXT ATTACHMENT TO THE CALCULATION. REVISED PAGES 1 AND 2. TOTAL PAGES FOR REVISION 6: <sup>3</sup> / <del>2</del> <sup>CP 7/6/90</sup> . FOR COMPLETE RE CALCULATION COMBINE REVISIONS 0, 1, 2, 3, 4, 5 AND 6. ADDED PAGE 3F	EJ 7/6/90 CP 7/6/90
7	O-MTR-31-203/204 (C&A BLDG VENT BD 1A2-A, COMPT 4B) DELETED PER DCN M-10541-B. THIS DELETION IS CONSERVATIVE AND WILL BE DELETED FOR THE CALCULATION ON A LATER REVISION. REVISED: PAGE 2 TOTAL PAGES REV. 7: 2 ADDED: PAGE 1B, FOR COMPLETE CALCULATION COMBINE REV. 0→7	YMB 8-25-90 TAD 8-27-90
8	ADD: ATTACHMENT F13654A FOR DCN F-13654-A PAGE 3G REVISED: PAGE 1B, 2, 4, 5 FSAR COMPLIANCE REVIEW <u>C.C. Lyke for MCB</u> DATE <u>10/5/90</u> TOTAL PAGES REV. 8: 18 FOR COMPLETE CALCULATION COMBINE REV 0→8	



WBN EEB-MS-7115-0011

REVISION LOG

Title: 480V NON-CLASS IE POWER CABLE ASSOCIATED CIRCUITS

Revision No.	DESCRIPTION OF REVISION	Date Approved
9	<p>ADDED: ATTACHMENT <del>603205A</del> (FOR DCN C-03205-A) <sup>TMB</sup> 12-13-90                      PAGE: 2A, 3H                      ATTACHMENT NO. C03205A/M09494A (FOR DCN C-03205-A &amp; M-09494A)</p> <p>REVISED: PAGE 1B, 4, 5</p> <p>TOTAL PAGES REV. 9: <del>14</del> <sup>16</sup> <sup>TMB</sup> 12-13-90</p> <p>FOR COMPLETE CALCULATION COMBINE REV Ø THRU 9</p> <p>FSAR COMPLIANCE REVIEW <u>[Signature]</u> DATE <u>12-14-90</u></p>	
10	<p>ADDED: ATTACHMENT NO. UVA2.1/2.4 TO RESOLVE UNVERIFIED ASSUMPTIONS 2.1 AND 2.4                      PAGE 3I, 1C</p> <p>REVISED: PAGE 2A, 4, 5, 8, 13, 14                      (REMOVED UNVERIFIED ASSUMPTION 2.6)                      THIS IS A COMPLETE CALCULATION</p> <p>TOTAL PAGES REV. 10: <u>344</u> INCLUDING PAGES 1A, 1B, 1C, 2A, 3A, 3B, 3C, 3D, 3E, 3F, 3G, 3H, 3I, 163A, 163B, 181A, 181B, AND ATTACHMENTS ADDED ON R1 THRU R10.</p> <p>FSAR COMPLIANCE REVIEW <u>C.C. Lyke for MCB</u> DATE <u>12/28/90</u></p>	<p><u>CP 12/20/90</u></p>
11	<p>REVISED CALCULATION TO RESOLVE ENGINEERING SELF-ASSESSMENT COMMENTS 2, 3, 4, 5, 6, 7, 8, 9, 11, AND 12 (ACTION ITEM NO. WBNA-88, REV. Ø). <sup>TMB</sup> 4-15-91</p> <p>REVISED: PAGES 1C, 2A, 4, 5, and <del>8</del> <sup>TMB</sup> 12, 15                      PAGES 1 of 24 and 4 of 24 (ATTACHMENT 1)                      PAGES A1, A2, A3, A4, and A5 of APPENDIX A                      PAGES C1, C5 thru C20, and C23 thru C27 of APPENDIX C                      MINOR ADMINISTRATIVE CORRECTION WAS MADE TO DELETE THE TOTAL CALCULATION PAGE COUNT WHICH WAS SHOWN ON SEVERAL PAGES.</p> <p>ADDED: PAGE 3J                      PAGES 80 thru 93 of ATTACHMENT UVA2.1/2.4</p> <p>DELETED: PAGES B0 thru B17 of APPENDIX B</p> <p>TOTAL PAGES REV. 11: 341 INCLUDING PAGES 1A, 1B, 1C, 2A, 3A, 3B, 3C, 3D, 3E, 3F, 3G, 3H, 3I, 3J, 163A, 163B, 181A, 181B, AND ALL ATTACHMENTS ADDED ON SUBSEQUENT REVISIONS</p> <p>FSAR COMPLIANCE <u>[Signature]</u> DATE <u>4-19-91</u></p>	<p><sup>TMB</sup> 3-8-91                      EJS 4/16/91                      EJS 4/18/91</p>



TVA

Title: 480V Non-Class IE Power Cable Associated Circuits		REVISION LOG WEN EEB-M5-TI15-0011
Revision No.	DESCRIPTION OF REVISION	Date Approved
12	<p>Added Attachments ECN 6670, P00972B, P03437A.</p> <p>Added page 2B, 3K; revised page 1C, 4. Total pages R12 = 360</p> <p>No FSAR sections are deemed relevant to this revision.</p> <p>R12 FSAR Compliance <u>[Signature]</u> / 8-2-91 APPROVE Date</p>	See cover sheet for approval and date.
13	<p>Revised calculation to support DCN M-13300-B which reclassifies voltage level from V3 to V4 for cable PL3390.</p> <p>Added attachment M13300B.</p> <p>Added page : 1D, 3L, and attachment M13300B (4 pages)</p> <p>Revised pages: 2B, 4 &amp; 5</p> <p><b>Total number of pages for Revision 13 = 366</b></p> <p>No FSAR sections are impacted by this revision.</p> <p>FSAR Compliance: <u>[Signature]</u> Date: <u>10-2-91</u></p>	SEE COVER SHEET FOR APPROVAL AND DATE.
14	<p>Revised Calculation to support DCN M-15092-A which change the size of cable 1PL3017 from a #10 to a #6.</p> <p>Added Attachment M15092A ( 4 pgs) and Page 3M, revised pgs 1D, 2B, 4 &amp; 5.</p> <p>Total Number of Pages R14 = 371</p> <p>No FSAR Sections are impacted by this Revision.</p> <p>FSAR Compliance <u>C.C. Lyke for MCB</u> Date <u>12/31/91</u></p>	See cover sheet for approval and date

REVISION NUMBER	DESCRIPTION OF REVISION	DATE APPROVED
15	<p>ADDED ATTACHMENT M08614A TO SUPPORT DCN<sub>s</sub> M-08614-A<del>4</del>                      THIS ATTACHMENT REEVALUATES AND REVISES APPENDIX F, G AND H OF THIS CALCULATION BASED UPON THE LATEST CONFIGURATION CONTROL DRAWINGS, THE CCRS, CALCULATION WBN EEB-MS-TI08-0008 ATTACHMENT M12212A, AND ATTACHMENT M08613A OF THIS BASELINE CALCULATION.</p> <p>FOR BASELINE: PAGES REVISED: 1D, 4                      PAGES DELETED: NONE                      PAGES ADDED: 2C, 3N</p> <p>FOR ATTACHMENT: PAGES REVISED: NONE                      PAGES DELETED: NONE                      PAGES ADDED: 1 THRU. 9, APP. 1 (5 PAGES)                      APP. 2 (1 PAGE)                      APP. 3 (46 PAGES)                      APP. 4 (2 PAGES)                      APP. 5 (2 PAGES)</p> <p>TOTAL PAGES INCLUDING REV 15 = 438</p> <p>FSAR SECTION 8.3.1.4.3 WAS REVIEWED. NO DISCREPANCIES EXIST BETWEEN THIS REVISION AND THE FSAR. <i>m.x. 4/24/92</i></p> <p>FSAR COMPLIANCE REVIEW <i>Don Farrell</i> for <i>ABC/LDE</i> DATE <i>4/25/92</i>  <i>MCB</i></p> <p>PREPARED BY <i>Mac Roopani</i> DATE <i>4/24/92</i></p> <p>CHECKED BY <i>Don Farrell</i> DATE <i>04-24-92</i></p>	<p><i>M-12212-A.</i>                      SEE COVER SHEET FOR APPROVAL &amp; DATE</p>

THIS SHEET ADDED BY REVISION 15

CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM

WBN EEB-MS-TI15-0011                      0  
Calculation No.                              Revision

Method of design verification (independent review) used (check method used):

- 1. Design Review                                X
- 2. Alternate Calculation
- 3. Qualification Test

Justification (explain below):

Method 1: In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc.).

Method 2: In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

Method 3: In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

Independently reviewed Calculation WBN EEB-MS-TI15-0011, R0 for technical adequacy as addressed in 10CFR50, Appendix B (NEP 3.1 Attachment 10). The design input data and assumptions were reviewed and found appropriate and reasonable. The calculation methods were based on Branch Technical Instruction EEB-TI08, Rev.0. The results and conclusions are adequate.

EEB-TI15

TBI 2-5-90

TB Small                                      2-5-90  
Design Verifier                              Date  
(Independent Reviewer)

## CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM

WBN-EEB-MS-TI.15-0011

Calculation.No.

1

Revision

Method of design verification (independent review) used (check method used):

1. Design Review
2. Alternate Calculation
3. Qualification Test

Justification (explain below):

Method 1: In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc.).

Method 2: In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

Method 3: In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

Reviewed R1 for technical adequacy as addressed in NEP 3.1  
Attachment 10. R1 updates the protective settings of Group 1 loads.  
These settings were determined and documented in WBN-EEB-MS-TI08  
-0008 R1. The results/conclusions are adequate.

William J. Holbert 4/11/90  
 Design Verifier Date  
 (Independent Reviewer)

CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM

WBM EEB-MS-T215-0011  
Calculation No.

2  
Revision

Method of design verification (independent review) used (check method used):

- 1. Design Review
- 2. Alternate Calculation
- 3. Qualification Test

Justification (explain below):

Method 1: In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc.).

Method 2: In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

Method 3: In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

*Reviewed R2 for technical adequacy as addressed in NEP 3.1 Attachment 10. R2 <sup>9-27-90</sup> updated the protective added an unverified assumption. The results and conclusions are unchanged*

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

*Thomas A. Bennett* 9-27-90  
 Design Verifier Date  
 (Independent Reviewer)



CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM

WBL EEB-M5-TI15-0011  
Calculation No.

R4  
Revision

Method of design verification (independent review) used (check method used):

- 1. Design Review
- 2. Alternate Calculation
- 3. Qualification Test

Justification (explain below):

Method 1: In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc.).

Method 2: In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

Method 3: In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

Independently reviewed calculation WBL EEB-M5-TI15-0011 in accordance with NEP 3.1 for technical adequacy.

Verified that the design inputs and outputs are reasonable and consistent based on experience and engineering judgement. Reviewed the purpose, assumptions, methodology and conclusions to verify adequacy of the calculation.

E. J. Iglesias  
Design Verifier  
(Independent Reviewer)

6/13/90  
Date

CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM

WBN EEB-MG-TI15-0011  
Calculation No.

R5  
Revision

Method of design verification (independent review) used (check method used):

- 1. Design Review
- 2. Alternate Calculation
- 3. Qualification Test

Justification (explain below):

Method 1: In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc.).

Method 2: In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

Method 3: In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

Reviewed to verify technical adequacy. Inputs and outputs are appropriate and reasonable. Reviewed purpose, assumptions, methodology and conclusions to verify adequacy.

S. Friedman 6/18/90  
Design Verifier Date  
(Independent Reviewer)



CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM

WBNEEBMSTI50011  
Calculation No.

R6  
Revision

Method of design verification (independent review) used (check method used):

- 1. Design Review
- 2. Alternate Calculation
- 3. Qualification Test

Justification (explain below):

Method 1: In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc.).

Method 2: In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

Method 3: In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

Reviewed to verify that this revision is conservative  
in nature and appropriate.  

---

---

---

---

---

---

---

---

---

---

*[Signature]*  
Design Verifier  
(Independent Reviewer)

7/6/90  
Date

CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM

WBN EEB-MS-TIIS-0011                      8  
Calculation No.                                      Revision

Method of design verification (independent review) used (check method used):

- 1. Design Review
- 2. Alternate Calculation
- 3. Qualification Test

Justification (explain below):

Method 1: In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc.).

Method 2: In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

Method 3: In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

*Reviewed RB for technical adequacy as addressed in*  
*NEP 3.1 Attachment 10. The design inputs are from calc*  
*WBN-EEB-MS-TIOB-0008 R 10. The results and conclusions*  
*are reasonable.*

*William S. Holbert*                      *10/5/90*  
 Design Verifier                                      Date  
 (Independent Reviewer)



CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM

WBN EEB-MS-TIIS-0011                      10  
Calculation No.                                      Revision

Method of design verification (independent review) used (check method used):

- 1. Design Review
- 2. Alternate Calculation
- 3. Qualification Test

Justification (explain below):

Method 1: In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc.).

Method 2: In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

Method 3: In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

*Reviewed for technical adequacy in accordance with NEP 3.1. Verified design inputs and methodology were appropriate and the results and conclusion were reasonable based on experience and engineering judgement.*

J. Peterson                      12/20/90  
Design Verifier                      Date  
(Independent Reviewer)

CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM

WBN EEB-MS-TI15-0011  
Calculation No.

11  
Revision

Method of design verification (independent review) used (check method used):

1. Design Review
2. Alternate Calculation
3. Qualification Test

Justification (explain below):

Method 1: In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc.).

Method 2: In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

Method 3: In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

Independently reviewed revision 11 of calculation WBN EEB-MS-TI15-0011 in accordance with NEP 3.1 for technical adequacy.

Inputs and outputs were reviewed and were found appropriate and reasonable. The purpose, assumptions, methodology and conclusions are adequate.

E. J. Iglesias  
Design Verifier  
(Independent Reviewer)

4/16/91  
Date

CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM

WBN EEP-MK-TLIS-0011  
Calculation No.

R12  
Revision

Method of design verification (independent review) used (check method used):

- 1. Design Review
- 2. Alternate Calculation
- 3. Qualification Test

Justification (explain below):

Method 1: In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc.).

Method 2: In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

Method 3: In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

Independently reviewed revision 11 of calculation WBN EEP-MK-TLIS-0011 for technical adequacy as addressed in NEP 3.1, ATTACHMENT 10.

Reviewed that the design inputs are appropriate and reasonable. Verified that the purpose, assumptions, methodology, results, and conclusions are technically adequate.

E. J. Ighawas  
Design Verifier  
(Independent Reviewer)

8/2/91  
Date

CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM

WBN EEB-MS-TIIS-0011

Calculation No.

13

Revision

Method of design verification (independent review) used (check method used):

1. Design Review
2. Alternate Calculation
3. Qualification Test


Justification (explain below):

Method 1: In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc.).

Method 2: In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

Method 3: In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

INDEPENDENTLY REVIEWED CALCULATION WBN EEB-MS-TIIS-0011  
FOR TECHNICAL ADEQUACY AS ADDRESSED IN 10CFR50, APPENDIX B  
(NEP 3.1, ATTACHMENT 10) THE DESIGN INPUT DATA AND ASSUMPTIONS  
WERE REVIEWED AND WERE FOUND APPROPRIATE AND REASONABLE.  
THE CALCULATION METHODS WERE BASED ON BRANCH TECHNICAL  
INSTRUCTION EEB-TI-09, REVISION 2. THE RESULTS AND CONCLUSIONS  
ARE ADEQUATE.

  
Design Verifier  
(Independent Reviewer)

9-20-91  
Date

CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM

WBN-EEB-MS-TIIS-0011  
Calculation No.

R14  
Revision

Method of design verification (independent review) used (check method used):

- 1. Design Review
- 2. Alternate Calculation
- 3. Qualification Test

Justification (explain below):

Method 1: In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc.).

Method 2: In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

Method 3: In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

INDEPENDENTLY REVIEWED CALCULATION WBN-EEB-MS-TIIS-0011 R14  
FOR TECHNICAL ADEQUACY AS ADDRESSED IN 10CFR60, APPENDIX E  
(NEP 3.1, ATTACHMENT 10) THE DESIGN INPUT DATA AND ASSUMPTIONS  
WERE REVIEWED AND WERE FOUND APPROPRIATE AND REASONABLE.

D. J. Cebulka  
 Design Verifier  
 (Independent Reviewer)

12/11/01  
 Date



CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM

WBN EEB-MS-TI15-0011

Calculation No.

15

Revision

Method of design verification (independent review) used (check method used):

- |    |                       |                    |
|----|-----------------------|--------------------|
| 1. | Design Review         | <u>        *</u>   |
| 2. | Alternate Calculation | <u>        N/R</u> |
| 3. | Qualification Test    | <u>        N/R</u> |

Justification (explain below):

Method 1: In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc.).

Method 2: In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

Method 3: In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

\* Independently reviewed calculation WBN EEB-MS-TI15-0011 R15 for technical adequacy as addressed in 10CFR50, Appendix B (NEP 3.1, Attachment 10). The design input data and assumptions were reviewed and were found appropriate and reasonable.

*Jonathan*

\_\_\_\_\_  
Design Verifier  
(Independent Reviewer)

04-21-92

Date

THIS PAGE REDONE R11  
 PREP YMB DATE 3-8-91  
 CHK EA DATE 4/16/91

WBN EEB-MS-TI15-0011

PAGE 4

TABLE OF CONTENTS

	PAGE NO.	
COVER SHEET.....	1 THRU	1 <del>D</del>
REVISION LOG.....	2, 2	2 <del>A</del> B
CALCULATION DESIGN VERIFICATION FORM.....	3 THRU	3 <del>Z</del> M
TABLE OF CONTENTS.....	4	
FSAR COMPLIANCE.....	5	
1. PURPOSE.....	7	
2. ASSUMPTIONS.....	8	
3. SOURCES OF DESIGN INPUT INFORMATION.....	9	
4. DESIGN INPUT DATA.....	13	
5. DOCUMENTATION OF INPUT/ASSUMPTIONS.....	13	
6. COMPUTATION/ANALYSIS.....	14	
7. SUPPORTING GRAPHICS.....	14	
8. SUMMARY OF RESULTS.....	15	
9. CONCLUSION.....	15	
 ATTACHMENTS/APPENDICES		
	NO. OF PAGES	
ATTACHMENT 1- ACCEPTANCE CRITERIA FOR PROTECTIVE DEVICES FOR CABLES.....	24	
APPENDIX A - MAXIMUM RATING OF CABLE PROTECTIVE DEVICES.....	6	
APPENDIX C - CABLE PROTECTION.....	28	
APPENDIX D - PROTECTIVE DEVICES TIME-CURRENT CURVES.....	17	
APPENDIX E - DIT INFORMATION.....	2	
APPENDIX F - LISTING OF INADEQUATE PROTECTIVE DEVICES.....	5	
APPENDIX G - LISTING OF PROTECTIVE DEVICES WHICH POTENTIALLY VIOLATE THE CRITERIA.....	13	
APPENDIX H - TABULATION OF NON-1E POWER CIRCUITS LOCATED IN CATEGORY 1 STRUCTURES.....	76	
ATTACHMENT UVA2.1/2.4 - RESOLUTION OF UNVERIFIED ASSUMPTIONS 2.1 & 2.4.....	93	
ATTACHMENT M08663A - EVALUATION OF DCN MODS.....	6	
ATTACHMENT P5297A - EVALUATION OF DCN MODS.....	3	
ATTACHMENT M10448A - EVALUATION OF DCN MODS.....	7	
ATTACHMENT M08613A - EVALUATION OF DCN MODS.....	8	
ATTACHMENT F13654A - EVALUATION OF DCN MODS.....	13	
ATTACHMENT C03205A/M09494A - EVALUATION OF DCN MODS.....	11	
Attachment ECN 6670 - Evaluation of ECN Mods .....	4	
Attachment P00972B - Evaluation of DCN Mods .....	4	
Attachment P03437A - Evaluation of DCN Mods .....	9	
ATTACHMENT <del>M13300B</del> - EVALUATION OF DCN MODS .....	54	4/10/91
M13300B		
Rg 29AUG91		
ATTACHMENT M15092A - EVALUATION OF DCN MODS .....	4	
ATTACHMENT M08614A/M12212A - EVALUATION OF DCN MODS .....	65	4/14/91 J.H. 0424-92

R13  
R14

R12

R13

R14

Prepared M. Bates Date 2/5/90 Checked TBT Date 2-5-90

FSAR COMPLIANCE

FSAR Compliance for R0: This FSAR Compliance Review is performed in accordance with PM 87-31 (EEB).

- a. No discrepancies exist between this calculation and the FSAR
- b. Applicable FSAR Sections:  
8.3.1.4.3

FSAR COMPLIANCE FOR <sup>R1</sup>~~R0~~: SECTION 8.3.1.4.3 WAS REVIEWED. NO DISCREPANCIES | R1  
<sub>TMB 4-11-90</sub> WERE NOTED.

FSAR COMPLIANCE FOR R2: SECTION 8.3.1.4.3 WAS REVIEWED. NO DISCREPANCIES NOTED | R2

FSAR COMPLIANCE FOR R3: SECTION 8.3.1.4.3 WAS REVIEWED. NO DISCREPANCIES NOTED | R3

FSAR COMPLIANCE FOR R4: SECTION 8.3.1.4.3 WAS REVIEWED. NO DISCREPANCIES NOTED. | R4

R4: COMPUTED TMB DATE 6-13-90  
CHECKED EGJ DATE 6-13-90

FSAR COMPLIANCE FOR R5: SECTION 8.3.1.4.3 WAS REVIEWED. NO DISCREPANCIES NOTED | R5

COMPUTED EJT DATE 6/12/90  
CHECKED GP DATE 6/13/90

SECTION 8.3.1.4.3 WAS REVIEWED. NO DISCREPANCIES NOTED. | R8

SECTION 8.3.1.4.3 WAS REVIEWED. NO DISCREPANCIES NOTED | R9

SECTION 8.3.1.4.3 WAS REVIEWED. NO DISCREPANCIES NOTED | R10

SECTION 8.3.1.4.3 WAS REVIEWED. NO DISCREPANCIES NOTED | R11

COMPUTED TMB DATE 3-2-91  
CHECKED EGJ DATE 4/16/91

SECTION 8.3.1.4.3 WAS REVIEWED. NO DISCREPANCIES NOTED | R13  
PREP. BY: Rudy Dodge 30 SEP 91

SECTION 8.3.1.4.3 WAS REVIEWED. NO DISCREPANCIES NOTED | R14  
PREP BY Jeffrey J. Sprange 12-9-91

WBN-FEB-MS - 7115-0011

COMPUTED JAD DATE 2/20/90  
CHECKED JMB DATE 2-20-90

*This page left blank intentionally.*

Prepared J. Bates Date 2/5/90 Checked TBT Date 2-5-90

1. Purpose

To analyze 480-V non-Class 1E power cables to demonstrate that associated Class 1E power cables are not degraded below an acceptable level.

NRC Regulatory Guide 1.75 and IEEE Standard 384-1981 require that non-Class 1E cables must be separated from Class 1E cables by a minimum distance. If the requirement cannot be met the non-Class 1E circuits must be analyzed to demonstrate that the Class 1E circuits are not degraded below an acceptable level.

1.1 Scope

The scope of this calculation is limited to analysis of 480-V non-Class 1E power cables in seismic Category I structures. These cables and their protective devices were identified. Adequacy and proper number of the protective devices to prevent thermal damage to the non-Class 1E cables due to faults are evaluated. Protection of the cables is evaluated only for the first 10 seconds from the time of initiation of fault.

If a non-Class 1E cable is protected adequately by any of the three following means, the protective devices are not required to be inspected periodically to protect the Class 1E cables it associates with:

two breakers in series,  
a breaker and a fuse in series, or  
a single fuse.

If a non-Class 1E cable is protected by a single breaker, the breaker must be tested periodically to assure its reliability and to assure that the Class 1E cables it associates with are not degraded below an acceptable level.

This criteria has been evaluated and justified by TVA and is documented in the Watts Bar FSAR, Section 8.3

Output cables from lighting cabinets are generally not within the scope of this calculation. An exception is O-LAC-233-160 which has been included at the request of TVA.

WBN EEB-MS-T115-0011 R0  
480 V Non-Class 1E Power Cable Associated Circuits

Prepared *M. Bates* Date 2/5/90 Checked *ASZ* Date 2-5-90

Feed cables to 480-V boards are not evaluated in this calculation because they are protected by 6.9-kV breakers and those evaluations are addressed in a separate calculation.

Coordination of the protection system for 480-V 1E loads has been evaluated in a calculation, WBN EEB-MS-T108-008, which includes breakers supplying power to non-1E loads.

Power cables from 480-V Ice Condenser MCC, 0-MCC-61-1 could not be evaluated because of incomplete and/or inconsistent information found in References 3.1, 3.64, and 3.66, and the TELAS database.

2. Assumptions

2.1 WBNP cable routing system non-QA report of Equipment Loading Report for NV4 non-1E cables, dated January 5, 1990, provides a complete and accurate list for the purpose of this calculation. ~~This is an unverified assumption.~~

| R10

2.2 In the above report, location designations with prefixes A, C, K, R and D are in Category I structures. The remaining designations are in non-Category I structures.

2.3 Several power outlets are connected in series by cables. Power to them is supplied through one breaker. Therefore, protection of all these cables are assured by considering only those cables that come out of the MCCs.

2.4 Non-Class 1E power cables that have an end point location in a Category 1 structure, comprise all non-1E cables that are potentially associated circuits. ~~This is an unverified assumption.~~

| R10

2.5 For the purpose of this calculation, all 480 V non-Class 1E power cables in Category I structures are assumed to be associated cables.

2.6 ~~PROTECTIVE DEVICES ARE QUALIFIED FOR THE ENVIRONMENT THEY ARE LOCATED IN. THIS IS AN UNVERIFIED ASSUMPTION.~~

| R2  
R10

3. References

3.1 Watts Bar Nuclear Plant Cable Routing System Equipment Loading Report for NV4 Non-1E cables dated January 5, 1990, a non-QA Report

3.2 WBNP FSAR, Chapter 8, Amendment 62

3.3 480-V Penetration Protection Calculation, EEB-MS-T108-0015, R0

3.4 Non-1E Power Circuits located in Category I Structures, DS1284E2, R2.

3.5 Associated Cables Analysis, 26DS211RP, December 15, 1983

Prepared JL Bates Date 2/5/90 Checked TBT Date 2-5-90

- 3.6 480-V Intake Pumping Station Bd. Single Line, 35N713-1, R10, Wiring Diagram
- 3.7 480-V Intake Pumping Station MCC, Single Line, 35N713-2, R10, Wiring Diagram
- 3.8 480V Aux. Bldg. Com Bd, Single Line, 45N731, R9 (O-BD-206-1), Wiring Diagram
- 3.9 480-V Diesel Aux. Bd 1A1-A, Single Line, 45W732-1, R20 (1-MCC-215-A1), Wiring Diagram
- 3.10 480-V Diesel Aux. Bd 1A2-A, Single Line, 45W732-2, R15 (1-MCC-215-A2), Wiring Diagram
- 3.11 480-V Diesel Aux. Bd 1B1-B, Single Line, 45W732-3, R19 (1-MCC-215-B1), Wiring Diagram
- 3.12 480-V Diesel Aux. Bd 1B2-B, Single Line, 45W732-4, R14 (1-MCC-215-B2), Wiring Diagram
- 3.13 480-V Diesel Aux. Bd C2-5, Single Line, 45W733-5, R5 (O-MCC-215-C2-S), Wiring Diagram
- 3.14 480-V Diesel Aux. Bd C2-5, Single Line, 45W733-6, R4 (O-MSS-215-C2-S), Wiring Diagram
- 3.15 480-V Turb. Bldg. Common MCC A, Single Line, 45W740-1, R11 (O-MCC-207-A), Wiring Diagram
- 3.16 480-V Fuel and Waste Hd1 Bd A, Single Line 45W743-1, 3, R19 (O-MCC-216-A), Wiring Diagram
- 3.17 480-V Fuel and Waste Hd1 Bd B, Single Line 45W743-2, R18 (O-MCC-216-B) Wiring Diagram
- 3.18 480-V Auxiliary Bldg Com MCC A, Single Line, Sh. 1, 45W744-1, R4 (O-MCC-208-A) Wiring Diagram
- 3.19 480-V Auxiliary Bldg Com MCC A, Single Line, Sh. 1, 45W744-2, R2 (O-MCC-208-A) Wiring Diagram
- 3.20 480-V Auxiliary Bldg Com MCC B, Single Line, Sh. 1, 45W744-3, R13 (O-MCC-208-B) Wiring Diagram
- 3.21 480-V Auxiliary Bldg Com MCC B, Single Line, Sh. 2, 45W744-4, R11 (O-MCC-208-A) Wiring Diagram

Prepared JBates Date 2/5/90 Checked TBT Date 2-5-90

- 3.22 480-V Auxiliary Bldg Com MCC C, Single Line, Sh. 1, 45W744-5, R11 (O-MCC-208-A) Wiring Diagram
- 3.23 480-V Lube Oil Board, Single Line 45W745, R12 (O-MCC-218-1) Wiring Diagram
- 3.24 480-V Chem & Vol Cont Bd A, Single Line, 45W746-1, R11 (O-MCC-217-A) Wiring Diagram
- 3.25 480-V Chem & Vol Cont Bd B, Single Line, 45W746-2, R11 (O-MCC-217-B) Wiring Diagram
- 3.26 480-V Unit Bd 1A, Single Line, 45N747-1, R12 (O-BD-203-A) Wiring Diagram
- 3.27 480-V Unit Bd 1B, Single Line, 45N747-2, R12 (O-BD-203-A) Wiring Diagram
- 3.28 480-V Cord Denin Wast MCC, Single Line, 45W748, R2 (O-MCC-249-1) Wiring Diagram
- 3.29 480-V Shutdown Bd 1A1-A, Single Line, 45W749-1, R23 (1-BD-212-A1) Wiring Diagram
- 3.30 480-V Shutdown Bd 1A2-A, Single Line, 45W749-2, R22 (1-BD-212-A2) Wiring Diagram
- 3.31 480-V Shutdown Bd 1B1-B, Single Line, 45W749-3, R22 (1-BD-212-B1) Wiring Diagram
- 3.32 480-V Shutdown Bd 1B2-B, Single Line, 45W749-4, R23, (1-BD-212-B2) Wiring Diagram
- 3.33 480-V Reactor MOV Bd 1A1, Single Line, Sh. 1 45W751-1, R25 (1-MCC-213-A1) Wiring Diagram
- 3.34 480-V Reactor MOV Bd 1A1, Single Line, Sh. 2 45W751-2, R18 (1-MCC-213-A1) Wiring Diagram
- 3.35 480-V Reactor MOV Bd 1A1, Single Line Sh. 3 45W751-3, R21 (1-MCC-213-A1) Wiring Diagram
- 3.36 480-V Reactor MOV Bd 1A2, Single Line Sh. 4 45W751-4, R26 (1-MCC-213-A2) Wiring Diagram
- 3.37 480-V Reactor MOV Bd 1A2, Single Line Sh. 5 45W751-5, R22 (1-MCC-213-A2) Wiring Diagram



Prepared ElBates Date 2/5/90 Checked TBT Date 2-5-90

- 3.38 480-V Reactor MOV Bd 1A2, Single Line Sh. 6 45W751-6, R16 (1-MCC-213-A2) Wiring Diagram
- 3.39 480-V Reactor MOV Bd 1B1, Single Line Sh. 7 45W751-7, R27 (1-MCC-213-B1) Wiring Diagram
- 3.40 480-V Reactor MOV Bd 1B1, Single Line Sh. 8 45W751-8, R16 (1-MCC-213-B1) Wiring Diagrams
- 3.41 480-V Reactor MOV Bd 1B1, Single Line Sh. 9 45W751-9, R25 (1-MCC-213-B1) Wiring Diagram
- 3.42 480-V Reactor MOV Bd 1B2, Single Line Sh. 10 45W751-10, R24 (1-MCC-213-B2) Wiring Diagram
- 3.43 480-V Reactor MOV Bd 1B2, Single Line Sh. 11 45W751-11, R19 (1-MCC-213-B2) Wiring Diagram
- 3.44 480-V Reactor MOV Bd 1B2, Single Line Sh. 12 45W751-12, R14 (1-MCC-213-B2) Wiring Diagram
- 3.45 480-V Turbine MOV Bd 1A, Single Line Sh. 2 45W753-2, R12 (1-MCC-209-A) Wiring Diagram
- 3.46 480-V Turbine MOV Bd 1A, Single Line Sh. 3 45W753-3, R8 (1-MCC-209-A) Wiring Diagram
- 3.47 480-V Turbine MOV Bd 1C, Single Line Sh. 6 45W753-6, R10 (1-MCC-209-C) Wiring Diagram
- 3.48 480-V Reactor Building Vent. Board 1A-A, Single-Line Sh. 1, 45W755-1, R13 (1-MCC-232-A-A)
- 3.49 480-V Reactor Building Vent. Board 1A-A, Single-Line Sh. 2, 45W755-2, R16 (1-MCC-232-A-A)
- 3.50 480-V Reactor Building Vent. Board 1A-A, Single-Line Sh. 1, 45W755-3, R14 (1-MCC-232-B-B)
- 3.51 480-V Reactor Building Vent. Board 1A-A, Single-Line Sh. 2, 45W755-4, R13 (1-MCC-232-B-B)
- 3.52 480-V Control and Auxiliary Building Vent. Board 1A1-A, Single-Line Sh. 1, 45W756-1, R25 (1-MCC-214-A1-A)
- 3.53 480-V Control and Auxiliary Building Vent. Board 1A1-A, Single-Line Sh. 2, 45W756-2, R31 (1-MCC-214-A1-A)

Prepared YBate Date 2/5/90 Checked TBT Date 2-5-90

- 3.54 480-V Control and Auxiliary Building Vent. Board 1A2-A, Single-Line Sh. 1, 45W756-3, R23 (1-MCC-214-A2-A)
- 3.55 480-V Control and Auxiliary Building Vent. Board 1A2-A, Single-Line Sh. 2, 45W756-4, R11 (1-MCC-214-A2-A)
- 3.56 480-V Control and Auxiliary Building Vent. Board 1B1-B, Single-Line Sh. 1, 45W756-5, R8 (1-MCC-214-B1-B)
- 3.57 480-V Control and Auxiliary Building Vent. Board 1B1-B, Single-Line Sh. 2, 45W756-6, R31 (1-MCC-214-B1-B)
- 3.58 480-V Control and Auxiliary Building Vent. Board 1B2-B, Single-Line Sh. 1, 45W756-7, R17 (1-MCC-214-B2-B)
- 3.59 480-V Control and Auxiliary Building Vent. Board 1B2-B, Single-Line Sh. 2, 45W756-8, R15 (1-MCC-214-B2-B)
- 3.60 480-V Turbine Building Vent. Board 1A, Single-Line, Sh. 1, 45W757-1, R16 (1-MCC-210-A)
- 3.61 480-V Turbine Building Vent. Board 1A, Single-Line, Sh. 2, 45W757-2, R10 (1-MCC-210-A)
- 3.62 480-V Turbine Building Vent. Board 1B, Single-Line, Sh. 1, 45W757-3, R10 (1-MCC-210-B)
- 3.63 480-V Turbine Building Vent. Board 1B, Single-Line, Sh. 2, 45W757-4, R11 (1-MCC-210-B)
- 3.64 480-V Ice Condensing System MCC, Westinghouse Drawing 1458F09, (O-MCC-61-1), Contract No. 73C62-54114-1
- 3.65 TVA Design Standard ~~DS-E12-63~~ <sup>DSE12.6.3 TMB 3-8-91</sup>, R1, November 5, 1986
- 3.66 WBNP walkdown data for ~~non-1E boards and breakers in Category I structures, January 1990.~~ <sup>NON-CLASS 1E EQUIPMENT (B26900201400) TMB 3-8-91</sup>
- 3.67 TVA Detailed Design Criteria, No. WB-DC-30-13, Title: 10 CFR 50, Appendix R, Type I, II, and III, Circuits Issue Date: ~~August 13, 1985~~ <sup>REV. 2 (B26900213076) TMB 3-8-91</sup>
- 3.68 Calculation WBN EEB-MS-TI08-0008, RO for 480-V 1E Coordination and Protection Review, prepared concurrently with this calculation.
- 3.69 WBN Calculation No. WBN-EEB-MS-TI05-0001, RO: TVA Auxiliary Power System (TELAS 1.0)
- 3.70 WBN Calculation No. WBN-EEB-MS-TI08-0015, RO: Watts Bar NP Containment Penetration Protection Study, Voltage Level V4, V5, Appendix A
- 3.71 WATTS BAR DESIGN CRITERIA, WB-DC-30-4, R5 (7-27-88), SEPARATION/ISOLATION

R11  
R11  
R11

Prepared J. S. Bate Date 2/5/90 Checked TBT Date 2-5-90

4. Design Input Data

- 4.1 The cables considered in this calculation were selected from Reference 3.1.
- 4.2 Protective devices for each cable were identified from WBNP Single-Line Diagrams of the MCCs and Boards, Reference 3.6 to 3.64.
- 4.3 Data for the protective devices were obtained from Reference 3.4 and 3.66 and are listed in Appendix H.
- 4.4 Cable type for each cable was obtained from Reference 3.1. It was compared with Reference 3.65 to determine the temperature rating of the insulation. All the cables in this calculation have insulation temperature rating of 90 degrees Celsius.
- 4.5 Manufacturer, model number, and rating of primary protective devices in this calculation were verified with walkdown data, Reference 3.66.
- 4.6 Acceptance criteria developed in Attachment 1 were used to determine adequacy of the protective devices in preventing damage to insulation of each cable.

5. Documentation of Assumptions

- 5.1 The assumption (2.1) that the non-QA report provides a complete and accurate list of NV4 non-1E cables is ~~unverified.~~ <sup>verified</sup> DOCUMENTED IN <sup>6/2/90</sup> ATTACHMENT NO. UVA2.1/2.4. | RIO
- 5.2 The assumption (2.2) that only the prefixes A, C, K, R, and D are used for location designations of Category I structures has been verified by FSAR Table 3.2-1 with the list of prefixes used.
- 5.3 The assumption (2.3) that where several power outlets are connected in series, all cables in that circuit are protected by virtue of the fact that the first one has been protected was verified by reviewing the cables to assure that all cables in the series are of the same size as the feed cable.
- 5.4 The assumption (2.4) that identifies all potentially associated circuits, is ~~unverified.~~ <sup>verified</sup> DOCUMENTED IN ATTACHMENT NO. UVA2.1/2.4 <sup>6/2/90</sup> | RIO
- 5.5 The assumption (2.5) that all non-Class 1E power cables in Category I structures are assumed to be associated cables is a conservative assumption. By reviewing all cables that could potentially be associated, and assuming that they all are, we have covered the worst case.
- 5.6 THIS UNVERIFIED ASSUMPTION MAY BE REMOVED FROM THIS CALCULATION SINCE THE ENVIRONMENTAL QUALIFICATION OF CIRCUIT BREAKERS IS BEING TRACKED (AND WILL BE RESOLVED) UNDER OPEN ITEM NO. 1 IN EQ BINDER NO. WBN EQ BKRA-002. | RIO

Prepared J. Bates Date 2/5/90 Checked TBT Date 2-5-90

6. Computation and Analyses

6.1 Associated cables were selected from WBNP cable routing system non-QA report of Equipment Loading Report for NV-4, non-1E cables, dated January 5, 1990, (Reference 3.1). This report is a computer sort with the following fields: Cable ID, Cable Type, NC1/NC2, MCM/AWG, From and To Equipment IDs, From and To Locations, and For. ~~Even though the report is non-QA, it is assumed that the sort is complete and accurate.~~ All cables from 480-V boards and MCCs in non-Category I structures, running to Category I structures or located totally within Category I structures are the only group of cables considered in this calculation. RIO

6.2 NV-4 cables are defined as non-safety-related low voltage power cables (480-V power cables and all ac and dc power cables of 250 V or less that carry 30 A or more). This criteria is defined in the TVA FSAR, Chapter 8.

6.3 Data for the protective devices for the cables are obtained from the following sources:

1. Associated Cables Analysis, 2GDS211RP, 12/15/83 (Ref. 3.5)
2. Non-1E Power Cables Located in Category I Structures, DS1284E2, R2 (Ref. 3.4)
3. Walkdown Data (Ref. 3.66)

Walkdown data are considered to be the most reliable and are relied upon. Drawings were used only for informational purposes. Data for the cables and their protective devices are tabulated in Appendix H.

6.4 Adequacy of the protective devices to protect associated 1E cables is evaluated using the acceptance criteria attached with this calculation as Attachment 1. Time-current characteristic curves of each cable and its protective devices are compared. The protective devices which are evaluated to be inadequate are listed in Appendix F.

6.5 Circuits were also reviewed to determine if they contained the proper protective devices; i.e., two breakers in series, one fuse and one breaker in series, or one fuse. Circuits not meeting this criteria are listed in Appendix G.

7. Supporting Graphics

Time-current curves for protective devices, which were used in developing the acceptance criteria for the protection of 480-V non-Class 1E cables are attached in Appendices C and D.

480 V Non-Class 1E Power Cable Associated CircuitsPrepared J. Bates Date 2/5/90 Checked TBT Date 2-5-90

## 8. Summary of Results

8.1 Appendix F lists 480-V power cables' associated circuits whose protective devices were evaluated to be inadequate for acceptance criteria developed in Attachment 1.

8.2 Appendix G lists 480-V power cables' associated circuits whose protective devices do not fall in any of the three categories stated below:

1. Two breakers in series.
2. One breaker and a fuse in series.
3. One fuse.

8.3 SEE "RESULTS/CONCLUSIONS" IN ATTACHMENT UVA2.1/2.4 FOR ADDITIONAL CIRCUITS | RII

## 9. Conclusions

9.1 Protection meeting the acceptance criteria of Attachment 1 needs to be provided for the circuits listed in Appendix F. The circuits listed in Appendix G require periodic testing of their breakers or design modification to assure reliability of their protection in accordance with FSAR, Chapter 8.

9.2 SEE "RESULTS/CONCLUSIONS" IN ATTACHMENT UVA2.1/2.4 FOR ADDITIONAL CIRCUITS | RII

# I REVIEW SUMMARY

REVISION 0 - ALL PAGES

TEXT PAGES 1-24

APPENDIX A PAGES A0-A5

~~APPENDIX B PAGES B0-B17~~

APPENDIX C PAGES C0-C27

APPENDIX D PAGES D0-D16

APPENDIX E PAGES E0-E1

| R11

WBN EEB-MS- TI15-0011R0  
180 V Power Cable Associated Circuits

Prepared HA Date 2/2/90 Checked Jan Z Date 2/2/90

HA

QA CALCULATION REVIEW CHECKLIST  
TYPE OF CALCULATION

- Hand-Prepared Design Calculation Only
- Computer-Aided Design Calculation Only
- Both Hand-Prepared and Computer-Aided Design Calculation

FOR HAND-PREPARED DESIGN CALC  
(check the appropriate items)

- Detailed review of the original calculation.
- Review by an alternate, simplified or approximate method of calculation.
- Review of a representative sample of repetitive calculations.
- Review of the calculation against a similar calculation previously performed.

FOR COMPUTER-AIDED DESIGN CALC  
(check the appropriate items)

- A review to determine if the computer output is identified by the computer program number, calculation number and run date. (MUST BE PERFORMED)
- A review to determine if the engineering design and analysis computer program(s) used have been validated and documented and that the calculation, regardless of the program used, contains all the necessary documentation for reconstruction at a later date. (MUST BE PERFORMED)
- A review to verify that the computer program is suitable to the problem being analyzed. (MUST BE PERFORMED)
- A review to determine if the input data as specified for program execution is consistent with the design input, correctly defines the problem for the computer program algorithm and is sufficiently accurate to produce results within any numerical limitation of the program. (MUST BE PERFORMED)
- A review to verify that the results obtained from the program are correct and within stated assumptions and limitations of the program and are consistent with the input. (MUST BE PERFORMED)
- Validation documentation for temporary changes to listed programs or developmental programs or unique single application programs shall be reviewed to assure that methods used adequately validate the program for the intended application. (WHERE APPLICABLE)

Form GO-3.08.1 Rev. 2 SL-F647 10-85 KPS

REVIEWER: A. J. M. Smith Date: 1/27/90

WBN EEB-MS- TI15-0011R0

30 V Power Cable Associated Circuits

Prepared Ht Date 2/2/90 Checked Jmt Date 2/2/90

### III. Table of Contents

1. INTRODUCTION
2. PURPOSE
3. ASSUMPTION
4. DOCUMENTATION OF ASSUMPTIONS
5. Sources of Design Input Information (Reference)
6. Methodology
7. Input Data
8. Computation and Analysis
9. Supporting Graphics
10. Summary of Results
11. Conclusion

Cont'd



WBN EEB-MS- TI15-0011R0  
480 V Power Cable Associated Circuits

Prepared HA Date 2/2/90 Checked Jmz Date 7/2/90

Table of Content (Cont'd)

12. APPENDIX

A - MAXIMUM RATINGS OF CABLE  
PROTECTION DEVICES

~~B - TYPICAL CABLE PROTECTION DEVICES  
USED AT WATTS BAR STATION~~

R11

C - CABLE PROTECTION  
TIME - CURRENT CURVES

D - PROTECTIVE DEVICES  
TIME - CURRENT CURVES

E - DIT INFORMATION

WBN EEB-MS- T115-0011 R0  
480 V Power Cable Associated CircuitsPrepared HA Date 2/2/90 Checked fmL Date 2/2/90

## 1. Introduction

NRC Regulatory guide 1.75 and IEEE Standard 384-1981 require that the non-class IE cables must be separated from class IE and associated circuits by minimum separation distance. If the minimum separation distance is not maintained, the non IE circuits must be analyzed to demonstrate that the class IE circuits are not degraded below an accepted level.

The cable installation practices for the non class IE cables at the Wall, Bar Nuclear Station (WBNS) do not lend themselves in meeting the minimum separation criteria for the non-IE cables and therefore analyses need to be performed to demonstrate that class IE circuits are not degraded below an accepted level.

WBN EEB-MS- TI15-0011R0

480 V Power Cable Associated Circuits

Prepared

HA

Date

2/4/90

Checked

JmJ

Date

2/2/90

## 2. Purpose

Non class 1E cables when faulted or overloaded could initiate a fire or cause nearby class 1E cables to fail due to their proximity. The protective device for the non class 1E cables should clear the faults or overload conditions before any damage to the nearby class 1E cables or a fire could take place.

The purpose of this calculation is to identify the maximum rating of the protective devices for non class 1E cables at 480V level which will prevent thermal damage to the non-1E cables through 10 seconds time limit. The identification of the protective devices based on the prevention of thermal damage beyond 10 seconds region is outside the scope of this calculation.

WBN EEB-MS- T115-0011R3  
480 V Power Cable Associated Circuits

Prepared HA Date 2/2/90 Checked gmt Date 2/2/90

3. ASSUMPTIONS

None

4. Documentation of Assumptions.

None

WBN EEB-MS- T115-0011 R0  
80 V Power Cable Associated CircuitsPrepared HA Date 2/2/90 Checked Jmt Date 2/2/905. SOURCES OF DESIGN INPUT INFORMATION (Reference)

5.1. TVA Calculation 2 GDS 211 RP, Revision 0  
"Associated Cable Analysis" prepared 12/15/83

5.2. Gould Shawmut Form 600 Amp-Trip  
Current Limiting Fuse - Bulletin AT 615

5.3. DIT No. WB-EPEE-0010-00  
Nbr IE Cables Covered in this calculation are  
rated for 90°C continuous temperature  
operation

5.4 Sargent & Lundy Standard ESC-193  
REVISED 11-28-89

5.5 UL 489 Standard for Safety,  
"Molded-Case Circuit Breakers and  
Circuit-Breaker Enclosures",  
September 15, 1986, 7th Edition

WBN EEB-MS- T115-0011R0

80 V Power Cable Associated Circuits

Prepared HA Date 2/2/90 Checked JMA Date 2/2/90

## 6. METHODOLOGY

6.1. Identify different sizes of Non-class IE cables that are not appropriately separated from class IE circuits. Identify different types of protective devices used on those non-IE cables.

This will be done by using table 2 of Appendix E of TVA calculation 2GDS211RP revision 0. (Reference 5.1). This table will be used to generate a table of non-IE cable sizes listing different types of protective devices used on their circuits.

6.2. Establish the following temperature ratings of the non-class IE cables that are mixed together with IE cables in cable trays.

- Normal operating Temperature
- Emergency over load temperature
- Short circuit Temperature
- Auto Ignition Temperature

4m/3  
3-7-91WBN EEB-MS- TI15-0011R0  
480 V Power Cable Associated Circuits

Prepared

AA

Date

2/2/90

Checked

JML

Date

2/2/90

- 6.3. Establish the maximum short circuit current-time capability of non-IE cables for duration upto 10 seconds
- 6.4. Use the Time-Current curves included in the TVA calculation 2GDS 211RP revision 0 (reference 5.1) to determine the maximum rating of the protective devices which will protect the non-IE cables through 10 seconds. The time-current characteristics shown in those curves for duration beyond 10 seconds will be ignored since thermal damage consideration beyond 10 seconds duration is outside the scope of this calculation.

WBN EEB-MS- T115-0011R0  
130 V Power Cable Associated Circuits

Page 11 of 24

Prepared HA Date 2/2/90 Checked JM Date 2/2/90

6.5. Analyze that nearby class 1E cables will not be exposed to degradation even if the conductor temperature in non class 1E cable is raised above 580°C during the high magnitude fault clearing time



RN EEB-MS- T115-0011R0  
30 V Power Cable Associated CircuitsPrepared HA Date 2/2/90 Checked JMT Date 2/2/90

## 7. Input Data

7.1. According to reference 5.3 the reviews of the non-IE cables covered in this calculation are rated for 90°C continuous temperature operation.

According to reference 1 the other temperature ratings of the 90°C cables are:

Short Time Overload Temperature — 130°C  
Short Circuit Temperature — 250°C  
Auto Ignition Temperature — 500°C

Prepared Hh Date 2/2/90 Checked Jmd Date 2/2/90

## 8. Computation and Analysis

8. 1. Using Table 2 of Appendix E in Reference 5.1 a table was prepared which listed ~~the~~ different types of protective devices used on non IE cables. This table is included in Appendix B of this calculation.

8. 2. The non class IE cables are rated for continuous operation at 90°C (Ref. 5.3) Time Current Curves in Appendix C of Reference 1 show the thermal damage curve of cables rated for 250°C short circuit current. Using these curves and comparing the tripping characteristics of the protective devices (included in appendix D of Reference 5.1) a table was generated which shows the maximum rating and/or the setting of the

WBN EEB-MS- T115-0011R0  
480 V Power Cable Associated CircuitsPrepared HA Date 2/2/90 Checked Jmd Date 2/2/90

protective devices which will protect the non IE Cable against thermal damage through the duration upto 10 seconds. This table is included in Appendix A of this calculation.

8.3. Appendix C of this calculation includes those Time Current Curves of Reference 5.1 which have been used to prepare the table in item 2 above. The curve marked as "TD" on these time current curves indicate the thermal Damage characteristic of the 90°C rated cable when the conductor temperature reaches 250°C. The curve labeled as "AI" indicates the characteristic of the 90°C rated cable when the conductor temperature reaches 500°C. These curves are based on Under Donk equation of Reference 5.1

8.4. Appendix D of this calculation includes those time-current characteristic of the protective devices which have been used to prepare the table in item 2 above

WBN EEB-MS- TI15-0011R0  
80 V Power Cable Associated CircuitsPrepared HA Date 2/2/90 Checked JMT Date 2/2/90

8.5 A review of the time current curves in Appendix C indicates that the molded case circuit breakers will interrupt the fault current in about 0.012 seconds. And, depending on the trip device setting, the fault clearing time by the DC breakers could be as high as 0.5 seconds - assuming the maximum available DC breaker time delay setting. The MCC feeder breakers are the only circuit breakers requiring time delay based on coordination considerations. The actual time delay used on the MCC feeders can and should be less than 0.5 seconds (0.18 seconds expected) to allow for coordination with the switchgear main feed circuit breakers.

It is the purpose of this analysis

WBN EEB-MS- TI15-0011 R0  
480 V Power Cable Associated CircuitsPrepared HA Date 2/2/90 Checked JM Date 2/2/90

to demonstrate that high magnitude fault currents on the non-IE cables, when cleared as discussed above, will not cause a failure of the nearby IE cables. This conclusion is reached based on the following considerations for the instantaneous and time delayed fault clearing.

#### A. Instantaneous fault clearing.

-UL Standard No 489 entitled "Molded Case Circuit breakers and circuit breaker enclosures" ref (5.5) requires in section 21.1 that cables used during the short circuit breaker testing shall not suffer damage.

WBN EEB-MS- TI15-0011 R0  
180 V Power Cable Associated CircuitsPrepared H/A Date 2/2/90 Checked Jmf Date 2/2/90

Depending on the circuit breaker sizes, cables as small as #14 AWG are used during the UL 489 Tests.

The short circuit current magnitudes used for the testing are, depending on the breaker size, between 10KA and 70KA.

- The cables used in the UL 489 tests are of a lower quality than the cables utilized at WREN (Section 21.8 of the UL 489 Standard identifies the cables as TW or THW rated at 60°C)

- We are familiar with several proprietary tests, conducted by independent

WBN EEB-MS- T115-0011R0

480 V Power Cable Associated Circuits

Prepared HA Date 2/2/90 Checked JMD Date 2/2/90

testing organizations for different utilities, which confirm that the requirement of the UL 489 standard about no cable damage during a high magnitude fault are indeed met. These tests show that not only faulted cables are not damaged but their insulation remains intact

B Time delay tripping on MCC feeder cables.

The smallest expected cable sizes one feeds to the MCC's are 4/0.

Utilizing the Under Donk formula from Ref 5.1, we will conservatively calculate the temperature that a

WBN EEB-MS- TI15-0011 R0

80 V Power Cable Associated Circuits

Prepared HA Date 2/2/90 Checked JMJ Date 2/2/90

4/0 cable copper conductor can reach with 50kA flowing through it for 0.18 sec. The 50kA short circuit current was conservatively chosen since it is equal to the interrupting rating of some 480V switchgear circuit breakers.

$$\left[ \frac{I}{cm} \right]^2 t = 0.0297 \log_{10} \frac{T_2 + 234}{T_1 + 234}$$

$$T_1 = 90^\circ C$$

$$I = 50000$$

$$cm = 211600$$

$$t = 0.18 \text{ seconds}$$

$$\left[ \frac{50000}{211600} \right]^2 (0.18) = 0.0297 \log_{10} \frac{T_2 + 234}{90 + 234}$$

$$0.3384 = \log_{10} \frac{T_2 + 234}{90 + 234}$$



TMD  
3-7-91

Prepared Ht Date 2/2/90 Checked Jmj Date 2/2/90

$$2.18 (90 + 234) = T_2 + 234$$

$$T_2 = 472^{\circ}\text{C}$$

The resulting copper temperature is  $472^{\circ}\text{C}$  which is below the  $500^{\circ}\text{C}$  cable autoignition temperature.

Furthermore, it should be noted that with the copper at  $472^{\circ}\text{C}$  the outside of the cable insulation would be at a much lower temperature. Industry tests referred to in section A earlier indicate that the cable outside insulation will be at about  $250^{\circ}\text{C}$

BN EEB-MS- T115-0011R0  
80 V Power Cable Associated Circuits

Prepared HA Date 2/2/90 Checked fmf Date 2/2/90

The above illustrates that the MCC feeder cables when faulted will not cause damage to the surrounding cables.

It is therefore concluded from the above discussion that the surrounding cables are not damaged during heavy short circuits even if the conductor temperature of the faulted cable exceeds  $250^{\circ}\text{C}$ .

Prepared HJA Date 2/2/90 Checked Jmy Date 2/2/90

### 9. Supportings Graphics

The time - current characteristic curves of the Non IE cables and the protective devices are included in Appendix C and D of this calculation.

### 10. Summary of Results

This calculation has determined the maximum rating and/or the settings of the protective devices which will prevent the thermal damage to the non-class IE cables through 10 seconds period. The results are applicable for 250°C short circuit temperature rated copper cables. The results are tabulated and included in Appendix A of this

WBN EEB-MS- TI15-0011R0  
80 V Power Cable Associated Circuits

Prepared HA Date 2/2/90 Checked JMY Date 2/2/90

The Calculator has determined that the surrounding cables will not be damaged, even if the conductor temperature on the faulted cable may exceed its 250°C short circuit temperature rating as the fault will be quickly cleared by its protective device. The faulted cable, however, should be replaced.

WBN EEB-MS- TI15-0011R0

480 V Power Cable Associated Circuits

Prepared HADate 2/2/90Checked JMDate 2/2/90

## II. Conclusion

The protective devices on Non-IE Cable, whose rating and/or setting does not exceed the maximum rating/setting listed in Appendix A, will protect the nearby Class IE Cables against thermal damage, provided the fault on the non-IE cable is cleared within 10 seconds.

The conductor temperature of non-IE cable may rise beyond its 250°C short-circuit-temperature rating during the fault clearing delay. The faulted non-IE cable, in such event, should be replaced.

WBN EEB-MS-T115-0011R0  
480 V Power Cable Associated Circuits

Prepared AA Date 2/2/90 Checked JM Date 2/2/90

APPENDIX A

MAXIMUM RATING OF  
PROTECTIVE DEVICES  
FOR  
90°C RATED CABLES  
0- 10 SECOND REGION

COMPUTED: TMB DATE: 3-7-91

CHECKED: Egg DATE: 4/16/91

ATTACHMENT 1 Page 41 of 200  
Page A1 of A5  
TMB-91  
3-7-91

WBN EEB-MS-T115-0011R0  
480 V Power Cable Associated Circuits

Prepared HA Date 2/2/90 Checked gmj Date 2/2/90

90°C RATED CABLE PROTECTION (0-10 SEC REGION ONLY)

CABLE SIZE	MAXIMUM PROTECTIVE DEVICE RATING	REFERENCE	
#14 AWG	- SQ.D - QOB-25A	TC-109 } Appendix C	
	- BUSSMAN - <sup>FRN 15A</sup> <del>FRS-15A</del>		TC-118 }
	- MAG ONLY BKR SETG. PLUS TOLERANCE LOWER THAN 80A		
	- BUSSMAN - KWN 25A		
	- SHMT - ALJ - 30A		
#12 AWG	- SHMT - TRS-20A	TC-64 Appendix C	
	- SQ.D - QOB140	TC-112 } App. C	
	- ITE - EF3 B030		TC-77 }
	- MAG. ONLY BKR SETG. PLUS TOLERANCE LOWER THAN 140A		
#10 AWG	- SHMT - TRS30A	TC-38 } App. C	
	- ITE - EF3B040		TC-39 }
	- SQ.D - QOB150	TC-117 }	
	- MAG. ONLY BKR, SETG. PLUS TOLERANCE LOWER THAN 225A		
	- HFCP - 15A		

RII

WBN EEB-MST115-0011R0  
 480 V Power Cable Associated Circuits

Prepared HA Date 2/4/90 Checked JML Date 2/2/90

90°C RATED CABLE PROTECTION (0-10 SEC. REGION ONLY)

CABLE SIZE	MAXIMUM PROTECTIVE DEVICE RATING	REFERENCE
# 8 AWG	- SHAWMUT AGY - 100A	MFR BULLETIN AT 615 (APP. D) TC-123 } TC-70 } APP. C TC-67 }
	- ITE-EF3 B070	
	- SHMT-TRS 60A	
	- MAG ONLY BKR SETG. PLUS TOL. BELOW 350A	
	- SHMT - HFCP 30A	
	- SHMT - AJJ - 100A	
	# 6 AWG	- MAG ONLY BKR SETTING PLUS TOLERANCE SHOULD BE BELOW 550A
- ITE - EF3 B100		TC-17 (APP. C)
- ITE - FJ BREAKERS CAN'T BE USED		SHEET <del>D6</del> (APP. D)
- SHMT - TRS 70A		TC-56 (APP. C)
- SHMT - HFCP 50A		
# 4	- W JA-70A	TC-84 } TC-30 } APP. C
	- GOULD RFS-100A (THE USE OF HIGHER RATED FUSE SHOULD BE INVESTIGATED)	
	- THE USE OF ITE-FJ BKR NEED INVESTIGATION	SHEET <del>D6</del> (APP. D)
	- MAG. ONLY BKR SETTING PLUS TOLERANCE BELOW 900A	TC-84 (APP. C)

| RII

| RII



WBN EEB-MS-T115-0011R0  
 480 V Power Cable Associated Circuits

Prepared HA Date 2/2/90 Checked gmd Date 2/2/90  
 \* JBT 2-5-90 \* YUB 2-5-90

90°C RATE CABLE PROTECTION (0-10 SEC. REGION ONLY)

CABLE SIZE	MAXIMUM PROTECTIVE DEVICE RATING	REFERENCE
# 2	<ul style="list-style-type: none"> <li>- W JA 125A</li> <li>- W DS BKR 150A SENSOR LTDELAY @ 12 SEC. ST OR INSTANT PICK UP &lt; 600% (THE USE OF OTHER SETTINGS SHOULD BE INVESTIGATED)</li> <li>- SHMT - CP6 - 4%</li> <li>- SHMT - CP6A - 2/0</li> <li>- MAG ONLY BKR SETTING PLUS TOLER. LOWER THAN 1200A</li> <li>- SHMT - HFcp - 100A</li> <li>- BUSSMANN JJS 225</li> </ul>	TC-83 } APP. C TC-6 } <del>D-15</del> D2 (APP. D)
* # 1/0	<ul style="list-style-type: none"> <li>- FP FUSEMATIC 100A</li> <li>- ITE - FJ-B125 (THE USE OF HIGHER RATED BKR SHOULD BE INVESTIGATED)</li> <li>- SHMT - CP6A - 4%</li> <li>- SHMT - CP6 - 350MM</li> <li>- MAG ONLY BKR SETG. PLUS TOLERANCE LOWER THAN 2000A</li> <li>- BUSSMANN JJS 400</li> </ul>	TC-6 (APP. C)  TC-4 (APP. C) TC-80 (APP. C)

R11

WBN EEB-MST115-0011 R0  
 480 V Power Cable Associated Circuits

Prepared HA Date 2/2/90 Checked Jmz Date 2/2/90

90°C RATED CABLE PROTECTION (0-10 SEC. REGION ONLY)

CABLE SIZE	MAXIMUM PROTECTIVE DEVICE RATING	REFERENCE	R11
# 2/0 AWG	W DS BKR SENSOR 150A LT DELAY @ 36 SEC. INST OR SHRT TIME PU UPTO 12 TIMES SENSOR RATING (THE USE OF OTHER SETTINGS SHOULD BE INVESTIGATED)	TC-91 & <del>D16</del> D2 (APP.C) (APP.D)	R11
# 4/0 AWG	- ITE - FJ3 B 225 W DS BKR SENSOR 300A LT DELAY @ 36 SEC INST OR SHOR TTIME PU UPTO 12 TIMES SENSOR RATING (THE USE OF OTHER SETTINGS SHOULD BE INVESTIGATED)	TC-27 & <del>D21</del> <sup>D6</sup> (APP.C & D) TC-7 & <del>D16</del> <sup>D2</sup> (APP.C & D)	R11
	- SHMT - CP6A - 350 MCM - SHMT - CP6 - 750 MCM - SHMT - CP - 750 MCM		

CHECKED EJ DATE 4/16/91

WBN EEB-MS-T115-0011R0  
 480 V Power Cable Associated Circuits

Prepared HA Date 2/2/90 Checked Jmf Date 2/2/90

90°C RATED CABLE PROTECTION (0-10 SEC. REGION ONLY)

CABLE SIZE	MAXIMUM PROTECTIVE DEVICE RATING	REFERENCE
300 MCM	- W JA 225A	TC-86 & <del>D1</del>
	- W LA 400A	TC-33 & <del>D3</del>
	- W DS BKR SENSOR 600A LT Delay @ 20 Sec. INSTANT OR SHORT TIME PU 4 TO 12 TIMES SENSOR RATING (THE USE OF OTHER SETTINGS SHOULD BE INVESTIGATED) - SHMT CPG-1000MCM - SHMT-CPGA-500MCM	TC-89 & <del>D2</del>
400 MCM	SHMT CPGA UPTO 1000 MCM	TC-13 & <del>D4</del> (APP. C&D)

APP. C&D

R11

R11

NOTES

- 1) THE MAXIMUM PROTECTIVE DEVICES LISTED AGAINST A 90° CABLE WILL PROTECT THAT CABLE THROUGH 0-10 SECONDS.
- 2) THE MAXIMUM PROTECTIVE DEVICES LISTED AGAINST A CABLE SIZE WILL ALSO PROTECT LARGER DIAMETER CABLES OF 90°C RATING THROUGH 10 SEC.
- 3) THE DIAMETER OF A CABLE INCREASES AS THE AWG NUMBER DECREASES FROM #14 TO #1

WATTS BAR NUCLEAR PLANT CONDUIT REPORT										PAGE 33	DATE 12/16/90			
QA REPORT CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VER STAT
B 1223	4	3.0 P	C	25	0.000	2.290	2.712	7.390	0.000	5.254	2		291	V

CABLES ROUTED IN CONDUIT:

B	84	1*1	WDQ	NC1:	2	CAB CSA:	1.356	CAB WT:	2.627	TOTAL CSA:	2.712	TOTAL WT:	5.254
											2.712	5.254	

TOTALS

PAGE 46  
 ATTACHMENT NO. UVA2.1/2.4  
 WBN EEB-MS-TIIS-0011, REV.10

WATTS BAR NUCLEAR PLANT CONDUIT REPORT										PAGE 34	DATE 12/16/90		SYSTEM	VER
QA REPORT CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP		STAT
B 1224	4	3.0 P	C	25	0.600	2.290	2.712	7.390	0.000	5.254	2		291	U

CABLES ROUTED IN CONDUIT:

B	83	1*1	WDQ	NC1: 2	CAB CSA: 1.356	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 47  
 ATTACHMENT NO. UVA2.1/2.4  
 WBN EEB-MS-TIIS-0011, REV. 10

WATTS BAR NUCLEAR PLANT CONDUIT REPORT										PAGE 35	DATE 12/16/90			
QA REPORT CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VER BTAT
B 1225	4	3.0 P	C	25	0.000	2.290	2.712	7.390	0.000	5.254	2		291	V

CABLES ROUTED IN CONDUIT:

B	88	1*1	WDQ	NC1:	2	CAB CSA:	1.356	CAB WT:	2.627	TOTAL CSA:	2.712	TOTAL WT:	5.254
TOTALS											2.712	5.254	

PAGE 48  
 ATTACHMENT NO. UVA2.1/2.4  
 WBN EEB-MS-TIIS-0011, REV.10

QA REPORT		WATTS BAR NUCLEAR PLANT CONDUIT REPORT										PAGE 36	DATE 12/16/90		
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VER STAT	
B 1226	4	3.0 P	C	25	0.000	2.290	2.712	7.390	0.000	5.254	2		291	U	

CABLES ROUTED IN CONDUIT:

B	89	1*1	WDQ	NC1:	2	CAB CSA:	1.356	CAB WT:	2.627	TOTAL CSA:	2.712	TOTAL WT:	5.254
TOTALS											2.712	5.254	

PAGE 49  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TI/5-0011, REV. 10

QA REPORT	WATTS BAR NUCLEAR PLANT CONDUIT REPORT												PAGE 37	DATE 12/16/90	
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VER STAT	
B 1227	4	3.0 P	C	25	0.000	2.290	2.712	7.390	0.000	5.254	2		291	U	

CABLES ROUTED IN CONDUIT:

B	94	1*1	WDQ	NC1: 2	CAB CSA: 1.356	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 50  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TIIS-0011, REV. 10



QA REPORT		WATTS BAR NUCLEAR PLANT CONDUIT REPORT							PAGE 38	DATE 12/16/90			SYSTEM	VER
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP		STAT
B 1228	4	3.0 P	C	25	0.000	2.290	2.712	7.390	0.000	5.254	2		291	V

CABLES ROUTED IN CONDUIT:

B	93	1x1	WDQ	NC1:	2	CAB CSA:	1.356	CAB WT:	2.627	TOTAL CSA:	2.712	TOTAL WT:	5.254
TOTALS											2.712	5.254	

PAGE 51  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TI15-0011, REV. 10

QA REPORT		WATTS BAR NUCLEAR PLANT CONDUIT REPORT							PAGE 99		DATE 12/16/90					
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VER STAT		
B 1229	4	3.0 P	C	25	0.000	2.290	2.712	7.390	0.000	5.254	2		291	V		

CABLES ROUTED IN CONDUIT:

B	98	1*1	WDQ	NC1: 2	CAB CSA: 1.354	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 52  
 ATTACHMENT NO. UVA2.1/2.4  
 WBN EEB-MS-TIIS-0011, REV.10

1 90

PAGE 40    DATE 12/16/90

QA REPORT CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CON LIMIT	CON CSA MAX	CON CSA ACCUM	CON CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VER STAT
----------------------------	----	-----------------	------------	-------------	--------------	-------------------	---------------------	-------------------	-----------------	-----------------	------------	-------------	--------	-------------

B	1230	4	3.0 F	C	25	0.000	2.290	2.712	7.390	0.000	5.254	2	291	V
---	------	---	-------	---	----	-------	-------	-------	-------	-------	-------	---	-----	---

CABLES ROUTED IN CONDUIT:

B	99	1*1	WDQ	NC1:	2	CAB CSA:	1.356	CAB WT:	2.627	TOTAL CSA:	2.712	TOTAL WT:	5.254
TOTALS											2.712	5.254	

PAGE 53  
ATTACHMENT NO. UVA.2.1/2.4  
W8NEEB-MS-TIIS-0011, REV.10

QA REPORT CONDUIT ID NV CONDUIT SIZE CON TYP CON LENG CSA LIMIT CSA MAX CSA ACCUM CONDUIT CSA INS WT/FT. LIMIT WT/FT. ACCUM NO. CAB AMB TEMP SYSTEM VER STAT

B 1253 4 3.0 P C 5 0.000 2.290 2.712 7.390 0.000 5.254 2 292 U

CABLES ROUTED IN CONDUIT:

B	64	1*1	WDQ	NC1:	2	CAB CSA:	1.956	CAB WT:	2.627	TOTAL CSA:	2.712	TOTAL WT:	5.254
											-----	-----	
TOTALS											2.712	5.254	

PAGE 54  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TIIS-0011, REV. 10

QA REPORT	WATTS BAR NUCLEAR PLANT CONDUIT REPORT										PAGE 42		DATE 12/16/90		SYSTEM	VER
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP				STAT
B 1252	4	3.0 P	C	5	0.000	2.290	2.712	7.390	0.000	5.254	2				292	U

CABLES ROUTED IN CONDUIT:

B	B3	1*1	WDQ	NC1:	2	CAB CSA:	1.356	CAB WT:	2.627	TOTAL CSA:	2.712	TOTAL WT:	5.254
TOTALS											2.712	5.254	

PAGE 55  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TI/5-0011, REV. 10

QA REPORT	WATTS BAR NUCLEAR PLANT CONDUIT REPORT												PAGE 43	DATE 12/16/90
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VER STAT
B 1254	4	3.0 P	C	5	0.000	2.290	2.712	7.390	0.000	5.254	2		292	V

CABLES ROUTED IN CONDUIT:

B	88	1x1	WDQ	NC1: 2	CAB CSA: 1.356	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 56  
 ATTACHMENT NO. UVA2.1/2.4  
 WBN EEB-MS-TIIS-0011, REV. 10

WATTS BAR NUCLEAR PLANT CONDUIT REPORT										PAGE 44		DATE 12/16/90		SYSTEM		VER
QA REPORT CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VER STAT		
B 1255	4	3.0 P	C	5	0.000	2.290	2.712	7.390	0.000	5.254	2		292	U		

CABLES ROUTED IN CONDUIT:

B	89	1*1	WDQ	NC1:	2	CAB CSA:	1.356	CAB WT:	2.627	TOTAL CSA:	2.712	TOTAL WT:	5.254
TOTALS											2.712	5.254	

PAGE 57

ATTACHMENT NO. UVA 2.1/2.4  
W8NEEB-MS-TI/5-0011, REV 10

QA REPORT CONDUIT ID	NU	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VER STAT
B 1285	4	3.0 P	C	20	0.000	2.290	2.712	7.390	0.000	5.254	2		292	V

CABLES ROUTED IN CONDUIT:

B	93	1*1	WDQ	NC1:	2	CAB CSA:	1.356	CAB WT:	2.627	TOTAL CSA:	2.712	TOTAL WT:	5.254
TOTALS											2.712	5.254	

PAGE 58  
 ATTACHMENT NO. UVA.2.1/2.4  
 W&NEEB-MS-TI/5-0011, REV.10



QA REPORT	WATTS BAR NUCLEAR PLANT CONDUIT RE												PAGE 46	DATE 12/16/90	
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VER STAT	
B 1286	4	3.0 P	C	20	0.000	2.290	2.712	7.390	0.000	5.254	2		292	V	

CABLES ROUTED IN CONDUIT:

B	94	1*1	WDQ		NC1: 2	CAB CSA: 1.356	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS								2.712	5.254

PAGE 59  
 ATTACHMENT NO. UVA 2.1/2.4  
 W&N EEB-MS-TI/5-0011, REV. 10

QA REPORT		WATTS BAR NUCLEAR PLANT CONDUIT REPORT										PAGE 47		DATE 12/14/90			
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VER STAT			
B 1280	4	3.0 P	C	20	0.000	2.290	2.712	7.390	0.000	5.254	2		292	V			

CABLES ROUTED IN CONDUIT:

B	98	1*1	WDQ	NC1: 2	CAB CSA: 1.356	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 60

ATTACHMENT NO. UVA 2.1/2.4  
WBN EEB-MS-TI15-0011, REV. 10

WATTS BAR NUCLEAR PLANT CONDUIT REPORT										PAGE 48		DATE 12/16/90		
QA REPORT CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VER STAT
B 1281	4	3.0 P	C	20	0.000	2.290	2.712	7.990	0.000	5.254	2		292	U

CABLES ROUTED IN CONDUIT:

B	99	1*1	WDQ	NC1:	2	CAB CSA:	1.356	CAB WT:	2.627	TOTAL CSA:	2.712	TOTAL WT:	5.254
TOTALS											2.712	5.254	

PAGE 61

ATTACHMENT NO. UVA 2.1/2.4  
WBN EEB-MS-TI15-0011, REV. 10

QA REPORT CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CON LIMIT	CON MAX	CON ACCUM	CON INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VER STAT
PLC 2472	4	1.5 I	C	70	0.000	1.081	0.213	2.040	0.000	0.246	1		290	U

CABLES ROUTED IN CONDUIT:

PL 4407	1x1	WFC-1	NC1: 1	CAB CSA:	.213	CAB WT:	0.246	TOTAL CSA:	.213	TOTAL WT:	.246
TOTALS									.213	.246	

PAGE 62  
 ATTACHMENT NO. UVA2.1/2.4  
 WBN EEB-MS-TIIS-0011, REV. 10

CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CON CSA LIMIT	CON CSA MAX	CON CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VER STAT
------------	----	--------------	---------	----------	---------------	-------------	---------------	-----------------	--------------	--------------	---------	----------	--------	----------

PLC 3140	4	1.5 I	C	60	0.000	.632	1.017	2.040	0.000	1.265	2		290	U
----------	---	-------	---	----	-------	------	-------	-------	-------	-------	---	--	-----	---

CABLES ROUTED IN CONDUIT:

ABN 755	1*1	WFA-4	NC1: 1	CAB CSA: 0.377	CAB WT: 0.430	TOTAL CSA: .377	TOTAL WT: .430
PL 6280	1*1	WFA-2	NC1: 1	CAB CSA: .640	CAB WT: 0.835	TOTAL CSA: .640	TOTAL WT: .835
TOTALS						1.017	1.265

PAGE 63  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TIIS-0011, REV. 10

9MB 91  
3-2-91


WBN EEB-MS-TIIS-0011R0

Page C0 of C27

Prepared HA Date 2/2/90 Checked Jm J Date 2/2/90

APPENDIX C

CABLE PROTECTION  
TIME - CURRENT CURVES




R11  
 COMPUTED TMB DATE 3-7-91  
 BY EJJ DATE 4/16/91  
 BASIS FOR DATA Standards  
 Tests at 100V  
 Curves are plotted to

CURRENT IN AMPERES 10  
 TIME IN SECONDS  
 480V BASE  
 TIME CURRENT CHARACTERISTICS CURVES  
 Fuse Links in  
 (Start)  
 (T starting at 250 with no initial load)

\* PREPARED TRT 2-5-90  
 \* VERIFIED JLB 2-5-90

COMPUTED JH DATE 11-14-85 Prepared JA Date 2/2/90  
 Verified Om Z Date 2/2/90




WATTS BAK  
 BASIS FOR DATA  
 Tests made at  
 Conditions are as follows:

TIME CURRENT CHARACTERISTIC CURVES  
 Fuses in 920V BASE  
 (Start at 25% with no initial load)

COMPUTED DATE

Prepared HA Date 2/2/90  
 Verified AMZ Date 2/2/90





WASTINGHOUSE TYPE DT 414  
 800, 100A TRIP L.R. = 67%,  
 INST. = 700%, L.D. TIME = 12 SEC.


MIX. CONT. AND REFRIG. COMPRESSOR A D-MTR-22-25

WALKS LANE ASSOCIATED CIRCUITS ANALYSIS  
 TIME CURRENT CHARACTERISTIC CURVES  
 Fuses listed in 250V BASE  
 Date: 2/2/90  
 (If starting at 25C with no inductance)

Prepared JA Date 2/2/90  
 Verified JML Date 2/2/90

Time 3-1-91  
1 CONT.

WALIS BAK  
2GDS211RP



20 GDS 211 RP

TIME CURRENT CHARACTERISTIC CURVES  
Fuse Links In 900 A. 3.15  
Date

TC-13

COMPUTED DATE  
CHECKED DATE 12-1-85


Prepared JH Date 2/2/90  
Verified JM Date 2/2/90

Page 69 of 200

3-7-91 W. J. ...  
2GDS211R

SHEET ~~68~~ 2/2/90

CURRENT IN AMPERES



CURRENT IN AMPERES 12 480V BASE

TIME CURRENT CHARACTERISTIC CURVES

Fuse time in  
Date  
p.f. starting at 25C with no initial load

No. TC-17  
Date

COMPUTED YMB DATE 3-7-91

CHECKED EJH DATE 4/16/91

IS PER DATA Standards  
Tests made at  
Curves are plotted by

Units are at  
Test points 60 variations should be

COMPUTED JH DATE 11-14-83  
CHECKED JHC DATE 11-22-83


Prepared HA Date 2/2/90  
Verified JMZ Date 2/2/90

Page 70 of 200  
4/16/91

WATTS BAR  
2GDS211RP

STEEL

~~CS~~ ~~HTS~~  
~~2/13/2/90~~



COMPUTED YMB DATE 3-7-91  
 CHECKED EJ DATE 4/16/91

TIME-CURRENT CHARACTERISTIC CURVES 480V BASE  
 Fuse Links in \_\_\_\_\_  
 Dated \_\_\_\_\_  
 p.f. starting at 75C with no initial load

No. TC-21  
 Date \_\_\_\_\_

COMPUTED LH DATE 11-14-83  
 CHECKED WJC DATE 11-14-83


Prepared HA Date 2/2/90  
 Verified WJC Date 2/2/90

RII

Page 71 of 200  
TMB  
3-7-91

WATTS LAM  
RGDS211RP

2/16  
2/12/90



480V BASE

TIME-CURRENT CHARACTERISTIC CURVES

Fuse Links in  
Date: 1/1 starting at 25C with no initial load

Volts a.c. at  
Test points on varistor should be

No. TC-30  
Date


Prepared HA Date 2/4/90  
Verified Jim S Date 2/2/90

COMPUTED INH DATE 11-14-83

COMPUTED TMB DATE 3-7-91  
CHECKED EBJ DATE 4/16/91

- 1 Tests made at
- 2 Fuse is a printed in

RII



COMPUTED YMB DATE 3-7-91

CHECKED EST DATE 4/16/91

TESTED AT \_\_\_\_\_ Volts a.c. at \_\_\_\_\_


TIME-CURRENT CHARACTERISTIC CURVES  
Fuse links in \_\_\_\_\_  
Date \_\_\_\_\_  
p.f. starting at 25C with no initial load  
Test points or variations should be \_\_\_\_\_

480V BASE

No TC-33  
Date \_\_\_\_\_

COMPUTED WH DATE 11-14-83  
CHECKED WH DATE 11-15-83

PREPARED HA DATE 2/2/90  
VERIFIED Jan DATE 2/2/90



311  
 TESTED T.M. DATE 3-7-91  
 BY EJS DATE 4/16/91  
 TESTS MADE AT  
 2. Curves are plotted on...

TIME-CURRENT CHARACTERISTIC CURVES  
 Fuse Links in  
 Dated  
 p.f. starting at 25C with no initial load


No. TC-38  
 Date

COMPUTED LW DATE 11-14-83  
 CHECKED T.C. DATE 11-25-83

Prepared JHA Date 2/2/90  
 Verified Jmz Date 2/2/90

Page 74 of 200  
3-26-91  
260-211RP

Sheet ~~CH~~  
EB 2/2/90



R11  
 Date 3-7-91  
 Date 4/16/91


TIME CURRENT CHARACTERISTIC CURVES 480V BASE

no TC-39

COMPUTED DATE 11-14-83  
 CHECKED DATE 11-15-83

Prepared HA Date 2/4/90  
 Verified Jm L Date 2/2/90






RII  
 CONT. DATE 3-7-91  
 CHECKED ESJ DATE 4/16/91  
 MAIN TEST DATA Standards  
 Tests made at  
 Curves are plotted by

TIME-CURRENT CHARACTERISTIC CURVES  
 Fuse Links in  
 Dated  
 at starting at 25C with no initial load  
 Test points are variations allowed by

480V BASE  
 1 RII  
 No TC-56  
 Date  
 Prepared HA Date 2/2/90  
 Verified SM Date 2/2/90



R11  
DATE 3-7-91  
EJ DATE 4/16/91


TIME-CURRENT CHARACTERISTIC CURVES 480V BASE  
Use Lines in  
Dated  
p.f. starting at 25C with no initial load  
No TC-64  
Date

- INSTRUCTIONS FOR DATA Standard
1. Tests made at
  2. Curves are plotted to

COMPUTED LW DATE 11-14-83  
CHECKED LW DATE 11/16/83

Prepared HA Date 2/2/90  
Verified Jmz Date 2/2/90

R11



R11  
COMPUTED TWB DATE 3-7-91  
ED EJA DATE 4/16/91  
TESTED AT  
TESTED BY


TIME-CURRENT CHARACTERISTIC CURVES  
Fuses listed in  
Dated  
p.f. starting at 25C with no initial load  
480V BASE  
R11

No. TC-67  
Date  
Prepared [Signature] Date 2-3-90  
Verified [Signature] Date 2-3-90

COMPUTED LH DATE 11-14-83  
CHECKED [Signature] DATE [Signature]

WATTS BAR  
3-7-91 (26 US 211 KF)

SHEET ~~88~~ OF ~~245~~  
BAR 2/2/90




R11  
 TESTED TMB DATE 3-7-91  
 BY EJF DATE 4/16/91  
 TO FULL DATA Standards  
 Tests made at  
 Test point to be specified on drawing

TIME CURRENT CHARACTERISTIC CURVES  
 Fuse Links In  
 Dates  
 p.t. starting at 25C with no initial load  
 No TC-68  
 Date  
 480V BASE  
 R11

Prepared HA Date 2/2/90  
 Verified Jim Z Date 2/2/90

COMPUTED LM DATE 11-28-83  
 CHECKED DSC DATE 11-28-83

YMB 3-7-91 WATT'S BAR  
260021111



COMPUTED YMB DATE 3-7-91  
 CHECKED ESJ DATE 4/16/91

- SIS FOR DATA Standards
1. Tests made at
  2. Curves are plotted to

Volts a.c. at \_\_\_\_\_  
 Test points or conditions should be \_\_\_\_\_


TIME-CURRENT CHARACTERISTIC CURVES  
 Fuse Links in \_\_\_\_\_  
 Date \_\_\_\_\_  
 p.f. starting at 25C with no initial load

480V BASE

TC-70

RII

Prepared HA Date 2/2/90  
 Verified Jim Z Date 2/2/90




RII  
 COMPUTED Tom DATE 3-7-91  
 CHECKED EB DATE 4/16/91  
 Tests made at  
 Units & C at

CURRENT IN AMPERES  
 TIME CURRENT CHARACTERISTIC CURVES  
 Fuse Links in  
 Date  
 P.F. starting at 75C with no initial load  
 480V BASE  
 No TC-77

9ms 3-2-91

WATTS LAN  
2GDS211NF



COMPUTED YML DATE 3-7-91  
 CHECKED EJF DATE 4/16/91

TIME-CURRENT CHARACTERISTIC CURVES  
 Fuse links in  
 Dated \_\_\_\_\_  
 p.f. starting at 25C with no initial load


480V BASE  
 R11

No TC-80  
 Date \_\_\_\_\_

K-E

COMPUTED LWH DATE 11-14-83  
 CHECKED M.C. DATE 11-17-83

Prepared HA Date 2/2/90  
 Verified JML Date 2/2/90



480V BASE

R11

R11  
 4MB DATE 3-7-91  
 ESB DATE 4/16/91  
 CHECKED  
 SIS FOR DATA Standards  
 Tests made at  
 Equipment are per IIR


TIME CURRENT CHARACTERISTIC CURVES  
 Fuse Links in  
 Dates  
 p.f. starting at 25C with no initial load  
 Test points as per table on circuit list

No TC-83  
 Date

COMPUTED LNH DATE 11-24-83  
 CHECKED DATE 11-26-83

Prepared HA Date 2/2/90  
 Verified JMF Date 2/2/90





R11  
 TESTED TIME DATE 3-7-91  
 CHECKED EJ DATE 4/10/91  
 NIS FOR DATA Standards  
 Tests made at  
 Location and printed by

TIME-CURRENT CHARACTERISTIC CURVES 480V BASE  
 Fuse Links in  
 Dated  
 p.f. starting at 25C with no initial load  
 Test points on secondary strand fro

No TC-84  
 Date


K-E

COMPUTED LWH DATE 11-24-83  
 CHECKED D.L.C. DATE 11-26-83

Prepared HA Date 2/2/90  
 Verified gms Date 2/2/90

Page 84 of 200  
gmb  
3-7-91

WALLEN  
2GDS211KP



gmb DATE 3-7-91  
EJH DATE 4/16/91

480V BASE

TIME CURRENT CHARACTERISTIC CURVES


Fuse links in  
Date  
p1 starting at 25C with no initial load

No. TC-86  
Date

Prepared HA Date 2/2/90  
Verified Jim S Date 2/2/90

COMPUTED WMI DATE 11-24-83  
CHECKED MLC DATE 11-26-83

SIS FOR DATA Standards  
Tests made at  
Curves are plotted for  
K-E



WASHINGTONE TYPE DS 200  
BKA, FKA, TKA, L.D. = 25.7%  
S.D. = 140%  
S.D. TIME = 0.18 SEC.

FORMER T.D. (B)  
300 MCM A.S.


750V COND. DEMIN. WASTE  
EVAP MCC 0-111-309-1

TIME-CURRENT CHARACTERISTIC CURVES  
Fuse Links in 750V BASE  
Dated: \_\_\_\_\_  
p.f. starting at 70°C with no initial load

COMPUTED DATE \_\_\_\_\_  
CHECKED MLC DATE 12-1-83

Prepared HA Date 2/2/90  
Verified Jm Date 2/2/90

No. TC-89  
Date: \_\_\_\_\_



2GDS211RP

WATTS BAR ASSOCIATED CIRCUITS ANALYSIS  
FROM DATA STANDARDS

TIME CURRENT CHARACTERISTIC CURVES  
FOR LINKS IN 480V 9.116


TC-91

COMPUTED DATE  
CHECKED m.c. LEE 12-1-83

Prepared HA Date 2/2/90  
Verified Jm L Date 2/2/90

Page 87 of 200 WATTS BAR  
YMB 3-7-91  
2600211F

Page C22 of C27  
23  
JULY 21 1990



YMB DATE 3-7-91  
EJS DATE 4/16/91

TIME-CURRENT CHARACTERISTIC CURVES  
Fuse Links in  
Dated  
p.f. starting at 25C with no initial load  
480V BASE  
TC-109


ASIS FROM DATA Standards  
1 Tests made at  
2

Units as of  
Test points on variations should be

Prepared HA Date 2/2/90  
Verified Jm Z Date 2/2/90

COMPUTED BY LM DATE 11-14-83  
CHECKED BY C DATE 11-26-83

R11



RU


R11

COMPUTED 4MB DATE 3-7-91  
CHECKED E19 DATE 4/16/91

TIME-CURRENT CHARACTERISTIC CURVES 480V BASE  
Fuse links in  
Date TC-112  
p.f. starting at 25C with no initial load

1 Tests made at \_\_\_\_\_  
 2 Tests are as per \_\_\_\_\_

Checked by LNH 11-14-83 Prepared HA Date 2/2/90  
 Checked by MLC DATE 11-19-83 Verified JmY Date 2/2/90



REVISIONS  
 1. DATE 3-7-91  
 2. DATE 4/16/91

TIME-CURRENT CHARACTERISTIC CURVES 480V BASE


Fuse Links In  
 Dated  
 p.f. starting at 25C with no initial load

No. TC-117  
 Date

Prepared HA Date 2/2/90  
 Verified Jim Z Date 2/2/90

COMPUTED BY LM DATE 11-14-83  
 CHECKED BY J.C DATE 11-19-83

R11




RII COMPUTED YMB DATE 3-7-91  
 CHECKED EJ DATE 4/16/91  
 1. Tests made at \_\_\_\_\_  
 2. Test points are plotted by \_\_\_\_\_

TIME-CURRENT CHARACTERISTIC CURVES 480V BASE  
 Fuse Links in \_\_\_\_\_  
 Dated \_\_\_\_\_  
 p 1 Starting at 25C with no initial load  
 No TC-118  
 Date \_\_\_\_\_

COMPUTED YMB DATE 11-14-83 Prepared JHA Date 2/2/90  
 CHECKED JHA DATE 11-26-83 Verified JMZ Date 2/2/90





SHAWMUT AMPTRAP 16Y30 TYPE 2 (ATM-30) (80A)

8 AWG TD

8 AWG AL

REPUTED WMB DATE 3-7-91  
 CHECKED EJ DATE 4/10/91  
 Tests made at \_\_\_\_\_  
 Fuse tags are placed in \_\_\_\_\_

TIME-CURRENT CHARACTERISTIC CURVES  
 Fuse Links in \_\_\_\_\_  
 Dated \_\_\_\_\_  
 p.T. starting at 25C with no initial load  
 480V BASE  
 No TC-123  
 IRII

K-E \_\_\_\_\_  
 PREPARED HA DATE 4/4/90  
 VERIFIED JM DATE 2/2/90  
 11-14-83

50-390

WATTS BAR 1

TVA

Fire Protection/Appendix R Program Calculations

Books 1, 2, 3, 4, and 5

Rec'd w/ltr dtd 6/15/92...9206260059

3

rmg  
3-2-91

WBN EEB-MS-TIIS-0011R0

Prepared Hd Date 2/2/90 Checked Jm L Date 2/2/90

APPENDIX D


PROTECTIVE DEVICES  
TIME-CURRENT CURVES



# AR DE-ION® CIRCUIT BREAKERS Types JA and KA MARK 75® Type HKA

70-225 Amperes, 2 and 3 Poles, 600 Volts Ac Max.  
250 Volts Dc

CURRENT IN PERCENT OF BREAKER TRIP UNIT RATING



WATTS BAR  
26DS2111F

SHEET D12 OF D26

Prepared AA 2/2/90  
 Verified AM 2/2/90  
 Date


Maximum and Minimum Characteristic Curves  
40°C Ambient, Cold Start - Thermal Magnetic

Interrupting Capacity (Symmetrical Amperes)	240 Volts	480 Volts	600 Volts
JA, KA	25,000	17,500	12,000

Curve No. SC-363-70  
January, 1971

Westinghouse Electric Corporation  
Low Voltage Breaker Division, Beaver, Pa.

Application Data 33 760 8



Type DE Air Circuit Breakers  
Application up to 800 Volts AC  
Time-Current Characteristics

Curve No. 1  
Reference No. 678450 8  
September 1988

Westinghouse Electric Corporation  
Baltimore Division, Baltimore, Md.  
Product 1128

Current  
= 100

Prepared HA Date 2/2/90  
Verified JM Date 2/2/90


Page 95 of 200 <sup>YMP 3-7-91</sup>

INITIAL TYPE LA

70-400 Amperes, 2 and 3 Poles, 600 Volts Ac Max.  
250 Volts Dc

SHEET ~~116~~ 2/2/92  
2GDS211RP  
of 110

Prepared HA Date 1/12/80  
Verified JMB Date 1/12/80



Average Unlatching Times  
Breaker Tripping Magnetically

Current Rms Ampe	Time Seconds
1,000	.0122
5,000	.0045
10,000	.0029
15,000	.0024
20,000	.0020
25,000	.0017


# SHAWMUT CABLE PROTECTOR

CHARACTERISTIC CURVES  
600 V.A.C. or less  
(For Copper Cables)

SHEET 022 OF 026  
2605211KP


CP6

CURRENT IN AMPERES



CP6A

CURRENT IN AMPERES




Prepared AA Date 2/2/90  
 Verified Jim J Date 2/2/90

TIME - CURRENT CURVES  
ET® CIRCUIT BREAKER  
E, EH AND EF FRAMES  
15 TO 100 AMPERES  
40° C  
TWO AND THREE POLE  
LIT-E IMPERIAL CORPORATION

INSTANTANEOUS TRIP

RATING IN AMPERES	FIXED INSTANTANEOUS TRIP, AMPERES
15 TO 40	480 TO 560
50 TO 100	1000 TO 1200



FOR APPLICATION AND COORDINATION PURPOSES ONLY. BASED ON 40°C AMBIENT COLD START.  
E F FRAME: 240 VOLTS, 60 HZ., 125/250 VOLTS DC.  
EH FRAME: 480 VOLTS, 60 HZ., 250 VOLTS DC.  
EF FRAME: 600 VOLTS, 60 HZ., 250 VOLTS DC.


Prepared HH Date 2/2/90  
Verified Jm J Date 2/2/90  
(E), (EH), (EF)-1A



TIME - CURRENT CURVES  
ET<sup>®</sup> CIRCUIT BREAKER  
FJ FRAME  
70 TO 225 AMPERES  
40° C  
TWO AND THREE POLE  
I-T-E IMPERIAL CORPORATION

INSTANTANEOUS TRIP

RATING IN AMPERES	ADJ. INSTANTANEOUS TRIP SETTING, AMPERES
70 TO 175	750 TO 1600
200 TO 225	800 TO 2000



FOR APPLICATION AND COORDINATION PURPOSES ONLY. BASED ON 40°C AMBIENT COLD START. 600 VOLTS, 60 HZ, 750 VOLTS DC.

Prepared HA Date 2/2/90  
Verified Jm Date 2/2/90 FJ-1A

**Gould Shawmut  
Form 600 Amp-trap  
Current Limiting Fuse**

~~250~~  
7/20/91  
3-2-91

200,000  
Amperes RMS  
Interrupting  
Capacity  
250 Volts &  
600 Volts





Prepared HA Date 4/2/90  
Verified Jim Z Date 2/2/90


Prepared HA Date 2/2/80  
 Verified JMD Date 2/2/80

FORM 600 AMP-TRAP FUSE  
 MELTING TIME-CURRENT CURVES  
 ATMI-30,  
 (600 VOLTS)

FORM 600 AMP-TRAP FUSE  
 MELTING TIME-CURRENT CURVES  
 A2Y OR A6Y1-600 TYPES 1, 3, 4 OR 5 (250 OR 600 VOLTS)  
 A6Y650-2000 TYPES 4 OR 5 (600 VOLTS)




MBN EER-MS-TIIS-0011 R0 Page 100 of 200  
 JMD 2/2/80 Page D8 of D16



ITE CAT NO.	Fuse Rating
D15AB03	3 Amp
D15A005	5 Amp
D15A010	10 Amp
D15A030	30 Amp
D15A050	50 Amp
D15AB100	100 Amp
D15AB150	150 Amp

Prepared HA Date 2/2/90  
 Verified Jim L Date 2/2/90




Shawmut Fuse Type HFCEP

ITE CAT NO.	Fuse Rating
D15A003	3 Amp
D15A005	5 Amp
D15A010	10 Amp
D15A030	30 Amp
D15A050	50 Amp
D15AB100	100 Amp
D15AB150	150 Amp

Prepared HA Date 2/2/90  
 Verified Jmz Date 2/2/90

Page D11 of D16



THIS DRAWING IS CURRENT AS OF DATE BELOW

JAN 18 1990

<b>KLC, TOTAL CLEARING TIME-CURRENT CHARACTERISTIC CURVES</b> For <b>KTN, KTS, KWN &amp; KWS LIMITRON FAST-ACTING FUSES</b>		Bussmann Division Cooper Industries St. Louis, MO 63178
BASIS FOR DATA Standards ..... Dated .....		No. <b>50549</b> Date <b>8-22-74</b>
1. Tests made at ..... Volts a.c at ..... p.f., Starting at 25C with no initial load ..... 2. Curves are plotted to ..... Test points so variations should be .....		


Prepared HA Date 2/2/90  
 Verified JmZ Date 2/2/90



# Tri-onic® - Class RK5 Time Delay Fuses

TRS

## Melting Time—Current Data 0.1-12 Amperes, 600 Volts AC



Prepared HA Date 2/2/90  
 Verified Jim Z Date 2/2/13

GOULD SHAWMUT


# Tri-onic® -Class RK5

## Time Delay Fuses

### TRS


### Melting Time—Current Data

#### 15-600 Amperes, 600 Volts AC




Prepared HA Date 2/2/90  
 Verified JmZ Date 2/2/90






Prepared HA Date 2/2/90  
 Verified Jm 2 Date 2/2/90



Prepared HA Date 2/2/90  
 Verified Jm L Date 2/2/90

**STANDARD CP CABLE PROTECTOR  
 FOR COPPER AND ALUMINUM CABLE  
 4/0, 250MCM, 350MCM, 500MCM, 750MCM  
 800 VOLTS  
 DB011C**

Page D16 of Final  
 19



Prepared HA Date 2/2/90  
 Verified Jm Date 2/2/90

WBN EEB-MS-TIIS-0011 R0

Page EO of E1

Prepared HH Date 2/2/90 Checked JMY Date 2/2/90

APPENDIX E

DIT INFORMATION

SAFETY-RELATED

NON-SAFETY-RELATED

DIT No. WB-EPED-0010-00

CLIENT TENNESSEE VALLEY AUTHORITY

Page 1 of     

STATION WATTS BAR NUCLEAR PLANT UNIT(S) 1 & 2

To S. R. H. ASHRAFI

PROJECT NO(S). B573-27

EAD

SUBJECT OPERATING TEMPERATURE FOR 480V NON IE CABLES ROUTED IN CATEGORY I STRUCTURES. SARGENT & LUNDY EAD

MODIFICATION OR DESIGN CHANGE NUMBERS(S) N/A

JAN 24 1990

K. MAJUMDAR

EPED

Kiran. J. Majumdar

RECEIVED

Preparer (Please print name)

Division

Preparer's signature

Issue date

**STATUS OF INFORMATION** (This information is approved for use. Design information, approved for use, that contains assumptions or is preliminary or requires further verification (review) shall be so identified.)

THE DESIGN INFORMATION TRANSMITTED VIA THIS DIT IS OBTAINED FROM APPROVED DOCUMENTS AND IS READY TO USE. THIS DIT DOES NOT CONTAIN ANY PRELIMINARY INFORMATION.

**IDENTIFICATION OF THE SPECIFIC DESIGN INFORMATION TRANSMITTED AND PURPOSE OF ISSUE**

(List any supporting documents attached to DIT by its title, revision and/or issue date, and total number of pages for each supporting document.)

PURPOSE OF ISSUE

TO TRANSMIT THE DESIGN INFORMATION AS REQUESTED BY EAD TO DEVELOPE AN ACCEPTANCE CRITERION FOR THE PROTECTION OF NON IE 480V CABLES ROUTED IN CATEGORY I STRUCTURES.

IDENTIFICATION OF SPECIFIC DESIGN INFORMATION

AS DERIVED FROM TVA DESIGN STANDARD DS-E12.6.3, REV. 1, THAT ATTACHMENT I, TABLE 2; THE NON IE 480V CABLES, WHICH ARE ROUTED IN CATEGORY I STRUCTURES OF THE PLANT ARE RATED FOR 90°C CONTINUOUSLY OPERATING TEMPERATURE. FURTHER, THESE NON IE CABLES ARE HAVING SIZES FROM #14 AWG TO 400 MCM.

**SOURCE OF INFORMATION**

Calc. no. N/A Report no. N/A

Rev. and/or date

Rev. and/or date

Other DS-E12.6.3, REV. 1 dated 11/5/86.

**DISTRIBUTION**

G. BATES, EPED.

WBN EEB-MS-TI15-0011 RD

Prepared HA Date 2/2/90

Verified JMZ Date 2/2/90

Form GO-3.17.1 Rev. 2 (01-08-87)

Prepared Kmajumdar Date 2/2/90 Checked TBT FOR RAB Date 2-5-90  
ELBates 2/5/90 R. Supkar 2-5-90

APPENDIX F

480V Power Cables Associated Circuits where protective devices were evaluated to be inadequate per acceptance criteria developed in Attachment 1. The protective devices are coded as "B" for a breaker and "F" for a secondary protection fuse.

480 V Bus	Compt. No.	Inadequate Protective Device
2-BD-212-A1	2C	B
	8A	F
2-MCC-214-A2	2D1	F
	6D1	F
	2E1	F
	6F1	F
	7D1	F
	3D1	F
	3E1	F
	3F1	F
	3F2	F
	4E1	F
	4F1	F
	5F1	F
	5F2	F
	6F2	F
7E1	F	
2-MCC-214-B1	3F2	F
	2F1	F
	9F1	F
	12F1	F
	12F2	F
1-MCC-232-B	2A, 9B, 10B, 13B	F
	3B	F
	3C	F
	6C	B
	6F1	F
	7B	F
	8B	F
	11F	F
	12F	F
	13B	F
	14B	F
15A	F	
16A	F	

*JTB* 2/12/90  
*RAB* 2/12/90

*JTB* 2/12/90  
*RAB* 2/12/90

WBN EEB-MS-TI15-0011 RO  
 480 V Non-Class 1E Power Cable Associated Circuits

Prepared Amgmd/cw Date 2/2/90 Checked TST FOR RMB Date 2-5-90  
J.Bates 2/5/90 R. Supkar 2-5-90

480 V Bus	Compt. No.	Inadequate Protective Device	
1-MCC-232-A	3A, 2A, 9B, 10B	F	
	3B	F	
	3C	F	
	4D	B	
	7B	F	
	8B	F	
	10F	F	
	11F	F	
	13D	F, B	
	14B	F	
	<del>14D</del>	<del>F</del>	
	15A	F	
	16A	F	
	2-MCC-214-A1	2F1	F
		2F2	F
		3F1	F
4F2		F	
10F1		F	
12E1		F	
2-MCC-214-B2	2E1	F	
	2F1	F	
	3E1	F	
	3F1	F	
	4E1	F	
	4F1	F	
	4F2	F	
	5E1	F	
	5F1	F	
	6E1	F	
	6F1	F	
	5F2	F	
7E1	F		
8E2	F		
0-MCC-208-A	<del>2C</del>	<del>F</del>	
	6A	F	
	6B	F	
	7A	B	
	7C	B	
	8B	B	
	8C	B	
	8D	B	

*J.Bates* 2/14/90  
*REB* 2/15/90

*J.Bates* 2/14/90  
*REB* 2/15/90

*J.Bates* 2/12/90  
*REB* 2/12/90

Prepared Amginder Date 2/2/90 Checked TBT FOR RHB Date 2-5-90  
ElBates 2/15/90 R. Supkar 2-5-90

<u>480 V Bus</u>	<u>Compt. No.</u>	<u>Inadequate Protective Device</u>
2-MCC-232-A	3B, 2A, 9B, 10B, 10F	F
	3C	F
	4D	B
	7B	F
	8B	F
	11D	F
	11F	F
	<del>13D</del>	<del>F</del>
	14B	F
	<del>14D</del>	<del>F</del>
	15A	F
	16A	F
2-MCC-232-B	2A, 9B, 10B, 13B	F
	3A	F
	3B	F
	3C	F
	6C	B
	6F1	F
	7B	F
	8B	F
	10F	F
	11F	F
	12F	F
	14B	F
	15A	F
	16A	F
1-MCC-214-A2	2D1	F
	2E1	F
	3D1	F
	3E1	F
	3F1	F
	3F2	F
	4E1	F
	4F1	F
	5F1	F
	5F2	F
	6F2	F
	7E1	F
	2E2	B, F
1-MCC-214-B2	2E1, 8F1	F
	2F1	F
	3E1	F
	3F1	F
	4E1	F



WBN EEB-MS-TI15-0011 RO  
 480 V Non-Class 1E Power Cable Associated Circuits

Prepared for ymuckew Date 2/2/90 Checked TBT FOR RHB Date 2-5-90  
ELBats 2/5/90 R. Supkar 2-5-90

480 V Bus	Compt. No.	Inadequate Protective Device
1-MCC-214-B2 (Cont.)	4F1	F
	4F2	F
	5E1	F
	5F1	F
	6E1	F
	6F1	F
0-MCC-208-B	6F2	F
	8B	B
	8D	B
0-MCC-216-B	4F	F
0-MCC-217-A	3E	B
	4E	B
1-MCC-210-A	3F2	B
2-MCC-209-A	7D	B
0-MCC-218-1	6D	B
0-MCC-208-C	9A	B
	7C1	F
1-MCC-214-A1	2F2	F
	3F1	F
	3F2	F
	5F1	F
	10F1	F
	12E1	F
1-MCC-214-B1	2F2	F
	9F1	F
	12E1	F
	12F1	F
	13F1	F
1-MCC-213-B1	<del>16E, 16A</del>	<del>F</del>
	<del>17E</del>	<del>F</del>
	17A	B
1-MCC-213-A1	<del>17E, 16A, 16B</del>	<del>F</del>
<del>1-BD-212-B2</del>	<del>3B</del>	<del>F</del>

*Handwritten notes:*  
 2/15/90  
 AEB  
 2/15/90

WBN EEB-MS-TI15-0011 RO  
 480 V Non-Class 1E Power Cable Associated Circuits

Prepared Ameymudar Date 2/2/90 Checked TBT FOR RNB Date 2-5-90  
YS Bates 2/5/90 RSupkar 2-5-90

480 V Bus	Compt. No.	Inadequate Protective Device
<del>2-BB-212-B2</del>	3B	F
2-MCC-213-A1	<i>JTB</i> <u>2/15/90</u> <del>17E, 16A, 16B</del>	F
2-MCC-213-B1	<i>R40</i> <u>2/15/90</u> <del>16E, 16A</del> <del>17E</del> 17A	F F B

*JTB* 2/15/90  
*R40* 2/15/90

Prepared S. Kelly by YLB Date 2/2/90 Checked TBT FOR RHB Date 2-5-90

APPENDIX G

Protective devices which potentially violate the criteria listed below:

1. Two breakers in series
2. A breaker and a fuse in series
3. A single fuse

<u>480 V Bus</u>	<u>Compt. No.</u>
0-BD-206-1	1A
	1C
	2B
	2C
	2D
	3A
	3B
	3C
	3D
	6A
	6B
	6C
	6D
0-BD-225-1	7C
	8B
	8C
	11A
	11B
	11C
	12B
	12C
	13A
	13B
13C	
2D	
4B	
4C	
4D	
6B	
6C	
6D	
7C	

Prepared Scott Kelley Date 2-2-90 Checked R.H. Buchart Date 2/2/90

<u>480 V Bus</u>	<u>Compt. No.</u>
1-BD-203-A	4D 6B
1-BD-203-B	3B
1-BD-212-A1	2C
1-BD-212-A2	3D
1-BD-212-B1	2B 3B 3D
1-BD-212-B2	3D
2-BD-203-A	6B
2-BD-203-B	3B
2-BD-212-A1	2C
2-BD-212-B1	2B 3B
2-BD-212-B2	3D
0-MCC-61-1	2FF 2KF 1DF 2BF 5HR 4DR 4MR 3DR 3HR 5BF 6BF
0-MCC-207-A	4F1
0-MCC-218-1	2F2 6D

Prepared Jerry Kelley Date 2-2-90 Checked R. A. Buchart Date 2/2/90

<u>480 V Bus</u>	<u>Compt. No.</u>
O-MCC-257-A	4F1
	4A
	4C1
O-MCC-208-A	2A
	2B
	2E2
	2F1
	2F2
	3A
	3B
	3C1
	3E1
	3E2
	3F1
	3F2
	4A
	4B
	4D2
	4E1
	4E2
	4F1
	4F2
	5C
	5E1
	5E2
	5F2
	6C
	6D
	6E1
	6E2
	6F1
	6F2
	7A
	7C
7D	
7E1	
7E2	
7F1	
7F2	
8A	
8B	
8C	
8D	
8E	

Prepared Scott Kelley Date 2-2-90 Checked R.H. Buckart Date 2/2/90

<u>480 V Bus</u>	<u>Compt. No.</u>
0-MCC-208-A (Cont.)	8F1 8F2 9D1 9D2 9E1 9E2 9F1
0-MCC-208-B	2A 2C 2E1 2F2 3A 3E1 3F2 4A 4B 4F1 5A 5E2 5F2 6A 6E1 6F2 7B 7E1 7E2 7F1 7F2 8B 8D 8F1 8F2 9B 9F2 10A 10D 11A 5F1 6D

Prepared Scott Kelley Date 2-2-90 Checked R.H. Buchert Date 2/2/90

480 V Bus

Compt. No.

0-MCC-208-C

- 2A
- 2C
- 2E2
- 2F1
- 3A
- 3E1
- 3E2
- 3F2
- 4A
- 4B
- 4E2
- 4F1
- 5A
- 5F2
- 6E1
- 6F1
- 7A
- 7C1
- 7E1
- 7E2
- 7F1
- 7F2
- 8A
- 8B
- 8D
- 8F1
- 8F2
- 9B
- 9F2
- 10A
- 10B
- 10C
- 10E
- 11C
- 6F2
- 9A

0-MCC-216-A

- 2A
- 2B
- 2C
- 2D
- 3A
- 3B
- 3C
- 3D
- 3F2
- 4A
- 4B

Prepared Scott Kelley Date 2-2-90 Checked R.H. Buchheit Date 2/2/90

<u>480 V Bus</u>	<u>Compt. No.</u>
0-MCC-216-A (cont.)	4E
	5A
	5E
	5F1
	6A
	6B
	6C
	6D
	6E
	8A
	8B
	8C
	8D
	6F1
	6F2
0-MCC-216-B	2A
	2B
	2C
	2D
	3A
	3B
	3C
	3E
	3F1
	3F2
	4A
	4B
	4E
	5A
	5B
	5E
	5F1
	6A
	6B
	6C
	6D
	6E



Prepared Scott Kelley Date 2-2-90 Checked R.H. Buchert Date 2/2/90

<u>480 V Bus</u>	<u>Compt. No.</u>
O-MCC-217-A	2A
	2B
	2D
	2E2
	2F1
	2F2
	3A
	3B
	3D
	3E
	3F1
	4D
	4E
	4F1
	5A
5E2	
5F1	
O-MCC-217-B	2B
	2C
	2D
	2E1
	2E2
	2F1
	2F2
	3B
	3C
	3D
	3E
	3F1
	3F2
	4D
	4F1
5E1	
5E2	
5F1	
O-MCC-226-1	2B
	2C
	2D
	2F1
	2F2
	3A
	3B
	3D
	3E1
	3E2

Prepared Scott Kelley Date 2-2-90 Checked R.H. Buchert Date 2/2/90

<u>480 V Bus</u>	<u>Compt. No.</u>
O-MCC-266-1 (cont.)	3F1
	3F2
	4B
	4C
	4F1
	4F2
	5A
	5B
	5C
	5F2
	6A
	6B
	6C
	6E1
	6F1
	6F2
	7A
	7F1
7F2	
5F1	
O-MCC-249-1	2A
	2B
	2D
	2F1
	2F2
	3A
	3B
	3F2
	4A
	4B
	4F2
	5D1
	5D2
	5E2
	5F1
5F2	
6A	
6C	
6E1	
6F1	
8A1	
8B1	
8C	
8E	

Prepared Deon Kelley Date 2-2-90 Checked R.H. Buchert Date 2/2/90

<u>480 V Bus</u>	<u>Compt. No.</u>
1-MCC-209-A	6F1 7D 10C 13E
1-MCC-209-C	3F2
1-MCC-210-A	2D 2F2 3F2
1-MCC-213-A1	16F1 16F2 17A 17F1 18C 18D 18F1 18F2
1-MCC-213-A2	4A 4B
1-MCC-213-B1	3F1 16F1 17A 17F1 17F2 18C 18D
1-MCC-213-B2	4A 4B 12A
1-MCC-214-A1	2D 13A 13B 13C
1-MCC-214-A2	2A 3A 4A 4B 5A 8A 8B

Prepared Scott Neeley Date 2-2-90 Checked R.H. Buchert Date 2/2/90

<u>480 V Bus</u>	<u>Compt. No.</u>
1-MCC-214-B1	2D 12A 13A 13B 13C
1-MCC-214-B2	2B 3B 3C 4B 6B 7D 9A
1-MCC-215-A1	5A 5F1 5F2 6A 6F1
1-MCC-215-A2	2E2 3E1 3F1 3F2 5A 5E1 5F1 6A 6D
1-MCC-215-B1	5A 5F1 6A
1-MCC-215-B2	3E1 3F1 3F2 5A 5F2 6D
1-MCC-232-A	4D 4E 5A 6A 6C 15D 16D

Prepared Scott Kelley Date 2-2-90 Checked R. H. Buchert Date 2/2/90

<u>480 V Bus</u>	<u>Compt. No.</u>
1-MCC-232-B	5E 6A 6C 6D 6E 15D 16D
2-MCC-209-A	7D 10C 13E
2-MCC-209-C	3F2
2-MCC-210-A	2D 2F2
2-MCC-213-A1	16F1 16F2 17A 18C 18F1 18F2
2-MCC-213-A2	4A 4B 13B
2-MCC-213-B1	3F1 17A 17F1 17F2 18C
2-MCC-213-B2	4A 4B 5A 5B
2-MCC-214-A1	2D 7D 13A 13C

Prepared Scott Kelley Date 2-2-90 Checked R.H. Buchat Date 2/2/90

<u>480 V Bus</u>	<u>Compt. No.</u>
2-MCC-214-B1	2D 12A 7D 13A 13C
2-MCC-214-A2	3A 4A 5A 8A 8B
2-MCC-214-B2	2B 3B 4B 6B 9A
2-MCC-215-A1	5A 5F1 5F2 6A
2-MCC-215-B1	5A 5F1 6A 5F2
2-MCC-215-A2	3E1 3F1 3F2 5A 6D
2-MCC-215-B2	3E1 3F1 3F2 5A 6D 4B

Prepared Scott Welley Date 2-2-90 Checked R.H. Buehler Date 2/2/90

<u>480 V Bus</u>	<u>Compt. No.</u>
2-MCC-232-A	15D
	16D
	4D
	4E
2-MCC-232-B	6C
	5E
	6C
	6D
	6E
	15D
	16D

EEB-MS-TI15-0011 R0  
 Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared Al Bates Date 2/1/90 Checked R.H. Buchert Date 2/1/90  
Al Bates 2/1/90 R.H. Buchert 2/1/90

O-LAC-233-160

COMPT No	SERVICE	BKR MODEL NO	SENSOR RATING	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
						NA				8	L660
	O-JB-299-5225	B-20	Y20			NA				8	L661
	O-JB-299-5225	B020	Y20			NA				8	L662
	O-JB-292-5205	B020	Y20			NA				8	L663
	O-JB-297-5226	B020	Y20			NA				8	L664
	O-JB-299-5226	B020	Y20			NA				8	L664



Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared by R. A. Buchheit Date 1/22/90 Checked K. J. Chouhary Date 1/26/90  
R. S. W. K. O. W. 1-4-90 1/20/90

O-BD-206-1

COMPT NO	SERVICE	BKR MODEL NO.	SENSOR RATING	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
1A	0-MCC-208-B	206	600 <sup>y</sup>	58	3.75	400	0.18	-	N/A	400	PL316
1C	0-MCC-217-A	206	300 <sup>y</sup>	83	4	400	0.33	-	N/A	300x2	PL333
	0-MCC-217-B										
2B	0-MCC-249-1	206	600 <sup>y</sup>	75	4	400	0.18	-	N/A	300	PL305
										300	PL306
2C	0-MCC-216-A	206	300 <sup>y</sup>	66	4	400	0.33	-	N/A	4/0	PL328
	0-MCC-216-B										
2D	0-SW-270-TB	206	150 <sup>y</sup>	80	8	-	-	1000	N/A	2/0	PL344
	0-SW-271-AB									2/0	PL346
3A	0-SW-257-1	206	100 <sup>y</sup>	66	20	-	-	600	N/A	210x2	PL335
3B	0-XSW-239-1	206	300 <sup>y</sup>	67	4	-	-	600	N/A	4/0	PL338
3C	0-MCC-208-A	206	300 <sup>y</sup>	100	3.9	400	0.33	-	N/A	400	PL326
3D	0-MCC-208-C	206	600 <sup>y</sup>	57	4	400	0.18	-	N/A	400	PL323
6A	0-MTR-61-2D	206	300 <sup>y</sup>	76	8	-	-	800	N/A	300	PL300
	0-MTR-61-12D										
6B	0-MTR-61-42D	206	300 <sup>y</sup>	76	8	-	-	800	N/A	300	PL361
	0-MTR-61-52D										
6C	0-CRN-271-A1	206	300 <sup>y</sup>	80	8	400	0.33	N/A	N/A	300	PL384
6D	0-MTR-32-27	206	300 <sup>y</sup>	76	8	-	-	1000	N/A	4/0	PL370
7C	0-MTR-61-22D	206	300 <sup>y</sup>	75	8	-	-	800	N/A	300	PL310
	0-MTR-61-32D										
8B	0-MCC-61-1	206	400 <sup>y</sup>	75	8	400	0.33	N/A	N/A	300	PL350
8C	0-MTR-61-62D	206	300 <sup>y</sup>	75	8	-	-	800	N/A	300	PL365
	0-MTR-61-72D										

BN EEB-MS-TI15-0011 R0

Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R. H. Buchert Date 1-22-90 Checked K. J. Mular Date 1/26/90  
R. Supkow 1-4-90 N. T. Chowdhury 1/20/90

O-BD-206-1

COMPT NO	SERVICE	BKR MODEL NO	SENSOR RATING	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
11A	0-MCC-208-B	206	600	60	3.75	400	0.18	N/A	N/A	400x2	PL318
11B	0-MCC-208-C	206	600	57.5	3.75	400	0.18	N/A	N/A	400x2	PL321
11C	0-MCC-217-A	206	300	82	3.75	400	0.33	N/A	N/A	400	PL335
	0-MCC-217-B										
12B	0-XSW-239-2	206	300	67	4	N/A	N/A	400	N/A	4/0	PL340
	2-INV										
12C	0-MCC-216-B	206	300	67	4	400	0.33	N/A	N/A	4/0x2	PL330
	0-MCC-216-A			68	3.8						
13A	0-MTR-32-136	206	300	70	8	NA	N/A	950	N/A	4/0	PL410
13B	0-XSW-239-AC	206	300	70	12	800	0.33	N/A	N/A	4/0	PL342
13C	0-MCC-208-A	206	300	100	4	400	0.33	N/A	N/A	400	PL325

EEB-MS-TI15-0011 R0  
 Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R. H. Bucher Date 1/22/90 Checked K. J. Mueler Date 1/26/90  
R. Supkar 1-9-90 N. T. Choudy 1/20/90

O-BD-226-1

COMPT NO	SERVICE	BKR MODEL NO	SENSOR RATING	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE MCM	CABLE NO
2D	0-MCC-226-1	DSA16	400 y	95	20	NIA	NIA	600	Name	400	PLW357 PLW358
								1000		300	PLW325
4B	0-MTR-24-20		600 y	100	4						
4C	0-MTR-24-141		600 y	100	4			1000		300	PLW345
4D	0-MTR-24-144		600 y	100	4			1000		300	PLW350
6B	0-MTR-24-7		600 y	100	4			1000		300	PLW320
6C	0-MTR-24-10		600 y	100	4			1000		300	PLW330
6D	0-MTR-24-13		600 y	100	4			1000		300	PLW335
7C	0-MTR-24-17		600 y	100	4			1000		300	PLW340

3EN713-1.210

Form GO-3.08.1 Rev. 2  
 SL-F647 04/84

ASN EEB-MS-TI15-0011 R0

Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchert Date 1/22/90 Checked Amymudar Date 1/26/90  
R.H. Buchert 1/17/90 Amymudar 1/21/90

1-BD-203-A

COMPT No	SERVICE	BKR MODEL NO	SENSOR RATING	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
4D	1-MTR-85-A	DS-206	300	75	12	N/A	N/A	1000	N/A	400	IPL160
6B	1-INV-264-1	DS-206	300 <sup>y</sup>	50	20	0.10	4	N/A	N/A	410	IPL6661

45N747-1.R12

EEB-MS-TI15-0011 R0  
 Population of Non-IE Power Circuits Located in Category 1 Structures

Prepared by R.H. Buchart Date 1/22/90 Checked by Kingmeclaw Date 1/26/90  
R.H. Buchart 1/17/90 Kingmeclaw 1/21/90

1-BD-203-B

COMPT No	SERVICE	BKR MODEL NO	SENSOR RATING	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
3B	1-MTR-85-B	DS-206	300 A Y	75	12	N/A	N/A	1000	N/A	300	1PL167

45N747-2,  
R12

W EEB-MS- TI15-0011 R0

Insulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buckert Date 1/22/90 Checked kmjmdar Date 1/26/90  
R.H. Buckert 1/12/90 kmjmdar 1/21/90

1-BD-212-A1

COMPT NO	SERVICE	BKR MODEL NO	SENSOR RATING (A)	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
2C	1-MTR-30-103	DS-416	300	50	8	N/A	N/A	Y 700	N/A	4/0	IPL5140
8A	0-XSW-239-1	DS-206	300	75	20	N/A	N/A	Y 600	COULD/SIGNALING CP350CS Y	300	IPL4931

BN EEB-MS- TI15-0011 R0

Page H8 of H72

Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Burchett Date 1/22/90 Checked Jim G. M... .. Date 1/26/90  
R.H. Burchett 1/10/90 Brian Kelley 1/25/90

-BD-212-A2

COMPT NO	SERVICE	BKR MODEL NO	SENSOR RATING	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
3D	0-MTR32-25	DS-416	300A	75	12	N/A	N/A	1000	N/A	4/0	1PL5033
7B	1-MTR30-159	DS-206	300A	66	12	N/A	N/A	900	CP 4/0CS COULD SUPPORT	4/0	1PL5085 1PL5150

EEB-MS-TI15-0011 R0

Location of Non-IE Power Circuits Located in Category 1 Structures

Prepared Kinghudas Date 1/22/90 Checked R.H. Buchart Date 1/20/90  
R.H. Buchart 1/10/90 Swannley 1/25/90

1-BD-212-B1

COMPT NO	SERVICE	BKR MODEL NO	SENSOR RATING	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
2B	1-MTR-30-102	DS-416	300A	50	7.5	N/A	N/A	700	N/A	4/0	IPL5160
3B	1-MTR-62-101	DS-416	400A	75	20	N/A	N/A	1000	N/A	400	IPL5025
3D	0-MTR-32-26	DS-416	300A	75	12	N/A	N/A	980	N/A	400	IPL5080



EEB-MS-TI15-0011 R0  
 Calculation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchert Date 1/22/90 Checked Kingma Date 1/26/90  
R.H. Buchert 1/17/90 Scott Kelley 1/25/90  
YBats 2/5/90 R. Supkar 2/5/90

1-BD-212-B2

COMPT No	SERVICE	BKR MODEL NO DS-	SENSOR RATING (A)	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
3B	1-PENT-293-11	416	300	100	20	N/A	N/A	600	CPGA-87 350	400 300	IPL4610 IPL4611
3D	0-BD-296-1	416	300	100	20	400	0.33	N/A	N/A	400	IPL4948
7A	1-MTR-30-162	206	300	65	12	N/A	N/A	900	CP 4/0CS	410	IPL5170
8A	0-XSW-239-AC	206	300	75	20	N/A	N/A	600	CP 250CS	300	IPL4932

ON EEB-MS-TI15-0011 RO  
 Tabulation of Non-IE Power Circuits Located in Category I Structures

Prepared R.H. Burkart Date 1/22/90 Checked Kmajmudar Date 1/26/90  
Kmajmudar 1/16/90 Robert Kelly 1/25/90

2-BD-203-A

COMPT NO	SERVICE	BKR MODEL NO	SENSOR RATING (A)	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
6 B	2-INV-264-1	DS-206	300 <sup>Y</sup>	50	20	400	0.15	N/A	N/A	4/0	2PL6661

45N747-1R12

WBN EEB-MS-TI15-0011 R0

Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared Kingman Date 1/22/90 Checked R.H. Buchert Date 1/26/90  
R.H. Buchert 1/17/90 Scott Melley 1/25/90

2-BD-203-B

COMPT No	SERVICE	BKR MODEL NO	SENSOR RATING	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
3B	2-MTR-85-B	DS-206	300 <sup>y</sup>	75	12 <sup>y</sup>	-	-	1/1000	N/A	300	2PL167

45N747-2, R13

EEB-MS-TI15-0011 R0  
 Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared Kingman Date 1/22/90 Checked R.H. Buchart Date 1/26/90  
R.H. Buchart 1/10/90 Scott Kelley 1/25/90

2-BD-212-A1

COMPT NO	SERVICE	BKR MODEL NO	SENSOR RATING	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
2C	2-MTR-30-104	DS-416	N 600A	50	8	N/A	N/A	700	N/A	4/0	2PL5140
8A	CHKR 0-XSW-239-2	DS-206	Y 300A	75	20	N/A	N/A	600	TX Y CP6 CP350CS	2/12/90 2/12/90 300	2PL4931, PL341

IN EEB-MS-TI15-0011 R0  
 Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchart Date 1/22/90 Checked Kmajmudar Date 1/26/90  
Kmajmudar 1/16/90 R.H. Buchart 1/21/90

2-BD-212-A2

COMPT NO	SERVICE	BKR MODEL NO	SENSOR RATING (A)	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
7B	2-MTR-30-274	DS-206	300	67	12	N/A	N/A	910	SHAWMUT CP410 Y C5	4/0	2PL5150
7C	0-MTR-30-136	DS-200	200	75	12	N/A	N/A	1100	SHAWMUT CP410 C5 Y	4/0	2PL5111

PN EEB-MS-TI15-0011 R0  
 Population of Non-IE Power Circuits Located in Category 1 Structures

Prepared kmj/ndw Date 1/22/90 Checked R.H. Buckert Date 1/26/90  
kmj/ndw 1/16/90 R.H. Buckert 1/21/90

2-BD-212-B1

COMPT No	SERVICE	BKR MODEL NO	SENSOR RATING (A)	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
2B	2-MTR-30-105	DS-416	1300	50	8	N/A	N/A	700	N/A	410	2PL5160
3B	2-MTR-62-101	DS-416	1400	75	20	N/A	N/A	1000	N/A	400	2PL5025

N EEB-MS-TI15-0011 RO  
 Tabulation of Non-IE Power Circuits Located in Category I Structures

Prepared km g/m/cw Date 1/22/90 Checked R.H. Buchert Date 1/26/90  
km g/m/cw 1/16/90 R.H. Buchert 1/21/90  
DLBals 2/5/90 R. Supkan 2/5/90

2-BD-212-B2

COMPT NO	SERVICE	BKR MODEL NO	SENSOR RATING (A)	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
3B	2-PENT-293-11	DS-416	300	100	20	N/A	N/A	600	Shawmut CP6A-87 350	400 300	2PL4610 2PL4611
3D	0-BD-206-1/90	"	300	100	20	400	0.33	N/A	N/A	400	2PL4968
7A	2-MTR-30-278	DS-206	300	65	12	N/A	N/A	1900	Y Gould CP 4/0 CS	4/0	2PL5170
7C	0-MTR-30-133	"	200	77.5	12	N/A	N/A	1100	Y Gould CP 4/0 CS	4/0	2PL5100

ON EEB-MS-TI15-0011 R0  
 Population of Non-IE Power Circuits Located in Category I Structures  
 Prepared R. Sudkar Date 1-29-90 Checked Y. Bates Date 1/29/90

O-MCC-61-1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		MCP		(A)		FH	MFR	MODEL	RATING		
	0-MTR-61-126 / CD									12	PL2841
2CF	0-MTR-61-126 / 23480RC GP			480?		47				8	PL2842
	0-MTR-61-136 / CD									12	PL2844
2KF	0-MTR-61-136 / 23480RC GP			480		48				8	PL2845
IDF	0-MTR-61-116 / 0358RC CD			40		29				12	PL2846
	0-MTR-61-A									10	PL4145
	0-MTR-61-B									10	PL4160
	0-MTR-61-C									10	PL4190
	0-MTR-61-D									6	PL4123
	0-MTR-61-E									6	PL4235
2BF	0-MTR-61-116 / 23480RC GP			480		47				8	PL2847
5HR	0-MTR-61-DPB 43180RC			1800		87				1/0	PL4100
4DR	0-JB-292-4141 0358RC			28		27				12	PL4111
4MR	0-JB-292-4141 0358RC			28		28				12	PL4120
3DR	0-JB-292-4141 0358RC			18		24				12	PL4127
3HR	0-JB-61-B 03150RC			150		33				10	PL4131

Incomplete Data  
 Not Evaluated



ORN EEB-MS-TI15-0011 R0  
 Evaluation of Non-IE Power Circuits Located in Category 1 Structures  
 Prepared R. Supkar Date 1-29-90 Checked J. Bates Date 1/29/90

O - MCC - 61-1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		MCP		(A)		FH	MFR	MODEL	RATING		
5BF	0-TB-61-C	0322RC		22		29				12	PL4157
6BF	0-TB-61-C	0322RC		22		29				12	PL4158
<p>Incomplete Data - Not Evaluated</p>											
<p>Sources</p> <ol style="list-style-type: none"> <li>W 1458F09 Contract # 73062-54114-1</li> <li>TELAS (Node 263)</li> <li>Walkdown data Jan 1990</li> <li>CCRS</li> </ol>											

EEB-MS-TI15-0011 R0

Enumeration of Non-IE Power Circuits Located in Category 1 Structures

Prepared R. H. Buchert Date 1/22/90 Checked Amajmudar Date 1/26/90  
Amajmudar 1/16/90 R. H. Buchert 1/21/90

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
0-MCC-207-A /4F1	0-SW-31-API	B020	N/A	Y 20	WP # N62 97-2	N/A	← N/A →			8	PL6140
0-MCC-218-1 /2F2	0-SW-39-5	B040	N/A	Y 40		N/A	← N/A →			10	PL1360
0-MCC-218-1 /6D	0-MTR-2-236	LO50	4	N 330		T50	← N/A →			8	PL1370
0-MCC-257-A /AF1	0-XSW-250-2	B060	N/A	Y 60			No SECONDARY PROTECTION INFO. AVAILABLE.			4	PL6281
0-MCC-257-A /4A	0-LAC-233-160	B050	N/A	Y 50						4	L681
0-MCC-257-A /4C1	0-SW-257-SAS	B020	N/A	Y 20						10	PL4407
	45W740-1, R11										
	45W745, R12										
	00, 00										

Form GO-3.08.1 Rev. 2 SL-F647 04/84

IBN EEB-MS-TI15-0011 R0  
 Installation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.A. Buchert Date 1/22/90 Checked Krajmuder Date 1/26/90  
Z.H. Buchert 1/17/90 Krajmuder 1/25/90

O-MCC-208-A

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
2A	1-MTR-44-90	A025	2	105	1	T38		N/A		10	PL841
2B	1-MTR-44-45	A025	2	105	1	T38		N/A		10	PL845
2C	1-MTR-77-410	A025	LO	75	1	T38	1	TRS-30	30A	10X3	1PL1480
2EZ	0-PNL-271-STD	B030	N/A	30				N/A		8	PL975
2FI	0-HST-271-AB7	B040	N/A	40				N/A		6X2	PL903
2FZ	0-PO-208-STD	B100	N/A	100				N/A		2	PL965
3A	2-MTR-44-90	A025	2	105	1	T38		N/A		10	PL843
3B	2-MTR-44-45	A025	2	105	1	T38		N/A		10	PL847
3C1	0-PMP-44-005	B020	N/A	20				N/A		6	PL3060
3E1	0-HTR-29-CB1	B020	N/A	20				N/A		10	PL960
3E2	0-HST-271-AB3	B030	N/A	30				N/A		8	PL900
3F1	0-XSW-253-1	B020	N/A	20				N/A		10	PL887
3F2	0-MTR-30-STD	B040	N/A	40				N/A		6	PL970
4A	0-MTR-30-244J	A010	4	58	1	T34		N/A		10	PL854
4B	0-MTR-30-246J	A010	4	58	1	T34		N/A		10	PL859
4D2	0-DXF-31-A/B	B030	N/A	30				N/A		8	PL807
4E1	0-HST-271-AB6	B020	N/A	20				N/A		10	PL849
4E2	0-LAC-233-33	B050	N/A	50				N/A		2/0	PL801
4F1	0-XSW-253-2	B020	N/A	20				N/A		10	PL893
4F2	0-HST-271-AB9	B040	N/A	40				N/A		6	PL904
5A	1-MTR-77-411	A025	LO	75	1	T38	1	TRS-30	30A	10	1PL4190
5C	0-LS-31-369 } 0-FSV-31-366 }	B015	N/A	15				N/A		12	PL957
5E1	0-HST-271-AB8	B020	N/A	20				N/A		10	PL914
5E2	0-LAC-233-61	B100	N/A	100				N/A		1/0	PL867
5F2	0-HST-271-AB10	B040	N/A	40				N/A		6	PL912
6A	2-MTR-77-410	A025	LO	75	1	T38	1	TRS-30	30A	12	2PL6481
6B	2-MTR-77-411	A025	LO	75	1	T38	1	TRS-30	30A	12X2	2PL6491
6C	1-MTR-318-A1	A010	4	58	1	T34		N/A		12	1PL6780
6D	1-MTR-31-437-C/1	A003	HI	21	1	T22		N/A		12	1PL6800
6E1	0-XSW-250-1	B020	N/A	20				N/A		10	PL870
6E2	0-HST-271-AB11	B030	N/A	30				N/A		8	PL905

Form GO-3.08.1 Rev. 2 SL-F647 04/84

ORN EEB-MS-T115-0011 R0  
 Calculation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R. H. Buchert Date 1/22/90 Checked R. H. Buchert Date 1/26/90  
R. H. Buchert 1/17/90 R. H. Buchert 1/25/90  
Libate 2/5/90 R. S. Upkove 2-5-90

O-MCC-208-A

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO.
							MFR	MODEL	RATING		
		EF3-		(A)		G30					
6F2	0-HST-271-AB12	B040	N/A	Y40		N/A	←	N/A	→	6	PL917
7A	1 HTR-31-397	L050	HIGH	N470	2	T47	←	N/A	→	10	PL921
7C	0-MTR-31-452	H050	4	N565	2	T52	←	N/A	→	6	PL943
7D	0-MTR-31-455	H050	LO	Y320	2	T52	←	N/A	→	6	PL20
7E1	0-CHGR-240-1	B020	N/A	Y20		N/A	←	N/A	→	10	PL875
7E2	0-HST-271-AB13	B030	N/A	Y30		N/A	←	N/A	→	8	PL907
7F1	0-HST-271-AB14	B030	N/A	Y30		N/A	←	N/A	→	8x2	PL906
7F2	0-LAC-233-80	B050	N/A	Y50		N/A	←	N/A	→	6	PL803
8A	0-MTR-31-APA	A005	HIGH	Y41		N/A	←	N/A	→	12	PL812
8B	2-MTR-31-397	A025	HIGH	210 <sup>N</sup>	1	T47	←	N/A	→	12	PL2080
8C	2-MTR-31-396	A025	HIGH	N210	1	T47	←	N/A	→	10	PL925
8D	1-MTR-31-396	A025	HIGH	N210	1	T47	←	N/A	→	10	PL934
8E	0-MTR-31-BPB	A005	4	29 <sup>Y</sup>		N/A	←	N/A	→	12	PL816
8F1	0-MTR-31-APOC	B020	N/A	20 <sup>Y</sup>		N/A	←	N/A	→	12	PL2082
8F2	0-MTR-31-BPOC	B020	N/A	20 <sup>Y</sup>		N/A	←	N/A	→	10	PL822
9D1	0-LAC-233-90	B040	N/A	40 <sup>Y</sup>		N/A	←	N/A	→	10	PL820
9D2	0-LAC-233-91	B040	N/A	40 <sup>Y</sup>		N/A	←	N/A	→	8	PL3105
9E1	0-LAC-233-92	B040	N/A	40 <sup>Y</sup>		N/A	←	N/A	→	4	PL3106
9E2	0-LAC-233-93	B040	N/A	40 <sup>Y</sup>		N/A	←	N/A	→	2	PL3107
9F1	0-LAC-233-94	B040	N/A	40 <sup>Y</sup>		N/A	←	N/A	→	2	PL3108
6F1	0-HTR-271-STD	B050	N/A	50 <sup>Y</sup>		N/A	←	N/A	→	4	PL3109
										6	PL980

EEB-MS-TI15-0011 R0

Location of Non-IE Power Circuits Located in Category 1 Structures

Prepared by R. H. Buchat Date 1/22/90 Checked by knayndar Date 1/26/90  
R. H. Buchat 1/17/90 knayndar 1/25/90  
Y. Bats 215190 R. Sullivan 2-5-90

O-MCC-208-B

COMP. NO	SERVICE	BKR TYPE	SET POS	TRIP RATING (A)	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
2A	0-HST-271-HA	A025	3	125	1	T40	←	N/A	→	10	PL1100 PL1101 PL1110 PL1111
2C	0-HST-271-HB	A025	3	125	1	T47 T40	←	N/A	→	10	PL1117
2E1	0-HTR-271-ABUD	B030	N/A	30		N/A	←	N/A	→	8	PL1172
2F2	0-HST-271-AB15	B050	N/A	50		N/A	←	N/A	→	6	PL3840
3A	0-HST-271-HC	A025	3	125	1	T47 T40	←	N/A	→	10	PL1150 PL1151
3E1	0-HTR-271-ABUC	B030	N/A	30		N/A	←	N/A	→	8	PL1176
3F2	0-PO-208-B4	B070	N/A	70		N/A	←	N/A	→	2	PL3760
4A	0-MTR-61-120A	A010	HI	84	1	T28	←	N/A	→	10	PL1120
4B	0-MTR-61-112F	A003	HI	21	1	T18	←	N/A	→	12	PL1124
4F1	0-PKG-59-B	B040	N/A	40		N/A	←	N/A	→	6	PL3789
5A	1-MTR-87-26	A025	3	125	1	T39	←	N/A	→	10	PL3844
5E2	1-ACU-31-B	B050	N/A	50		N/A	←	N/A	→	6	PL3844
5F2	1-ACU-31-C	B100	N/A	100		N/A	←	N/A	→	2	PL3749
6A	2-MTR-77-262A	A025	LO	75	1	T38	←	N/A	→	10	PL3920
6E1	1-HTR-31-PASF	E020	N/A	20		N/A	←	N/A	→	6	IPL6813
6F2	1-ACU-31-IRS	B030	↓	30		↓	FUSE INFO. NOT AVAILABLE.		30A	8	IPL6794
7B	1-MTR-77-262A	A025	LO	75	1	T30	←	N/A	→	10	PL3947
7E1	1-HTR-271-AEE,AEN	B020	N/A	20		N/A	←	N/A	→	10	PL1189
7E2	0-HTR-271-ABUT	B040	↓	40		↓	←	N/A	→	6	PL1204
7F1	2-HTR-271-AEB,AED	B030	↓	30		↓	←	N/A	→	8	PL1209 PL1210,11 PL3789 PL3789,369
7F2	0-PO-208-B1,B2,B3	B100	↓	100		↓	←	N/A	→	6	PL1129
8B	0-MTR-61-86	H050	HI	670	3	T50	←	N/A	→	6	PL1132
8D	0-MTR-61-87	H050	HI	670	3	T50	←	N/A	→	6	PL1184
8F1	0-HTR-271-AECAED	B030	N/A	30		N/A	←	N/A	→	8	PL1160
8F2	0-HTR-271-AB/RRI	B030	N/A	30		N/A	←	N/A	→	8	PL1160
9B	0-MTR-61-88	H050	3	475	3	T50	←	N/A	→	6	PL1135
9F2	1-MTR-271-AEJ	B030	N/A	30		N/A	←	N/A	→	8	PL1189
10A	2-MTR-31-318-B2	L050	3	260	2	T48	←	N/A	→	8	2PL6795

SL-F647 04/84  
 Form GO-308.1 Rev. 2

IBN EEB-MS-TI15-0011 R0  
 Installation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R. H. Embert Date 1/20/90 Checked Kmagnuder Date 1/26/90  
R. H. Embert 1/17/90 Kmagnuder 1/25/90

O-MCC-208-B

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO.
							MFR	MODEL	RATING		
		EF3-		(A)		G30					
10D	Spare Glycol Chiller	FJB-B200	HL	Y 2000 (45WTH-1) (R11-S-L)		N/A	N/A	N/A	N/A	4/0	PL2890
11A	O-MD-271-A112	EF3-A025Z	2	Y 105		T38	←	N/A	→	10	PL1220
5F1	O-SW-253-1	B040	N/A	Y 40		N/A	N/A	N/A	N/A	8	PL6284
6D	O-CRN-271-RR6A	B040	N/A	Y 40		N/A	←	N/A	→	6	PL1142

See p. 449, 450 & 451  
 of study # DS1284E2  
 450744-4

ON EEB-MS- T115-0011 R0

Location of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchart Date 1/22/90 Checked James M. Clark Date 1/27/90  
R.H. Buchart 1/17/90 Strom Kelley 1/15/90  
ElBates 2/5/90 R Supnar 2-5-90

O-MCC-208-C

COMP NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
2A	0-HST-271-HD	A0252	3	Y125	1	T47	N/A	N/A	N/A	10	PL2920
						T40				10	PL2921
2C	0-HST-271-HE	A0252	3	Y125	1	T47	N/A	N/A	N/A	10	PL2930
						T40				10	PL2931
2E2	1-ACU-31-A	B040	N/A	Y40		N/A	N/A	N/A	N/A	6	PL3937
2F1	2-ACU-31-A	B040	N/A	Y40		N/A	N/A	N/A	N/A	6	PL2857
3A	0-HST-271-HF	A0252	3	Y125	1	T47	N/A	N/A	N/A	10	PL2940
						T40				10	PL2941
3E1	0-HTR-271-AB/RR2	B020	N/A	Y20		N/A	N/A	N/A	N/A	10	PL2860
3E2	0-HTR-271-ABUI	B040	N/A	Y40		N/A	N/A	N/A	N/A	6	PL2900
3F2	0-IAC-220-259	B100	N/A	Y100		N/A	N/A	N/A	N/A	4	PL2855
4A	0-MTR-61-120B	A010	L0	Y27	1	T28	←	N/A	→	10	PL2820
4B	0-MTR-61-112G	A003	3	Y12	1	T18	←	N/A	→	12	PL2824
4E2	0-CRN-77-1A	B050	N/A	Y50		N/A	←	N/A	→	6	PL3960
4F1	0-HTR-271-AEA	B040	N/A	Y40		N/A	←	N/A	→	8	PL2904
										8	PL2905,06
5A	2-MTR-77-262B	A0252	L0	Y75	1	T38	←	N/A	→	10	PL2930
5F2	0-PO-208-C1→C4	B100	N/A	Y100		N/A	←	N/A	→	2	PL3971
6E1	0-PO-77-AHVC	B020	N/A	Y20		N/A	←	N/A	→	10	PL2909
6F1	0-CHL-61-120	B020	N/A	Y20		N/A	←	N/A	→	10	PL3305
7A	1-MTR-77-262B	A0252	L0	Y75	1	T38	←	N/A	→	10	PL3955
7C1	2-ALL-31-IRS	B030	N/A	Y30		N/A	←	N/A	→	8	PL2880
7E1	1-HTR-271-AEF, AEG	B020		Y20						8	PL2888
7E2	1-HTR-271-AEK, AEL	B030		Y30						8	PL2888
7F1	2-HTR-31-PASF	B020		Y20						14	2PL6813
7F2	0-PO-208-C5, C8	B100		Y100						2	PL3940
8A	0-MTR-61-80	A0252	L0	Y75	1	T38	←	N/A	→	10	PL2850
8B	0-MTR-61-83	H050	2	Y400	3	TE0	←	N/A	→	6	PL2828
8D	0-MTR-61-84	H050	2	Y400	3	TE0	←	N/A	→	6	PL2831
8F1	0-HTR-271-ABUA	B030	N/A	Y30		N/A	←	N/A	→	8	PL2875
8F2	0-HTR-271-ABUB	B030	N/A	Y30		N/A	←	N/A	→	8	PL2870
9B	0-MTR-61-85	H050	2	Y400	3	T50	←	N/A	→	6	PL2834
9E2	1-HTR-271-AED AEA	B030	N/A	Y30		N/A	←	N/A	→	8	PL2896

Form GO-3.0B.1 Rev. 2 SL-F647 04/84

FUSE INFO. NOT AVAILABLE 30A

WBN EEB-MS-TI15-0011 R0

Installation of Non-IE Power Circuits Located in Category I Structures

Prepared R.H. Buchart Date 1/22/90 Checked Jim Gardner Date 1/27/90

R.H. Buchart 1/17/90 Scott Willey 1/15/90

O-MCC-208-C

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
		EF3-	(A)		G30						
10A	2-MTR-31-318/ B2	L050	3	Y 260		T48	←	N/A	→	8	2PL6795
10B	2-MTR-31-318/ A2	A010	4	Y 58		T34	←	N/A	→	12	2PL6780
10C	0-MTR-257-1	A003	3	Y 12		T19	←	N/A	→	12	PL3925
10E	2-MTR-31-437/ C2	A003Z	HI	Y 21		T22	←	N/A	→	12	2PL6800
11C	0-HTR-31-479	B050	N/A	Y 50		N/A	←	N/A	→	6	PL6001
6F2	0-CHGR-236-5	B100	N/A	Y 100	N/A	N/A	N/A	N/A	N/A	2	PL3900
9A	2-MTR-87-26	A025Z	HI	N 210		T40	←	N/A	→	10	ABN2023
							450744-6				

Form GO-3.08.1 Rev. 2 SL-F647 04/84



EEB-MS-TI15-0011 R0  
 Population of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchert Date 1/22/90 Checked km y m r d w Date 1/27/90  
A.H. Buchert 1/10/90 Scott Welley 1/25/90

O-MCC-215-C2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO.
							MFR	MODEL	RATING		
		GE TED		(A)		G30					
BN-	O-HTR-30-32	136YT 150	N/A	150	N/A	N/A	1	A4J15	Y 15A	12	PL3274
BR-	O-HTR-30-315	136YT 150	N/A	150	N/A	N/A	1	A4J15	Y 15A	12	PL3272
CA-	O-MTR-30-329	136YT 150	N/A	150	1	CO.97A	1	TRS1R	Y 1A	12X2	PL3308
CN-	O-HTR-30-317	136YT 150	N/A	150	N/A	N/A	1	A4J30	Y 30A	8	PL3270
CR	O-HTR-30-322	136YT 150	N/A	150	N/A	N/A	1	A4J30	Y 30A	8	PL3275
CU	O-HTR-30-325	136YT 150	N/A	150	N/A	N/A	1	A4J15	Y 15A	12	PL3278
CX	O-HTR-30-324	136YT 150	N/A	150	N/A	N/A	1	A4J15	Y 15A	12	PL3277
DR	O-MTR-82-320	N/A	N/A	N/A	1	CB.67A	1	TRS 9R PRIM. PROT.	Y 9A	12	PL3269
DU	O-MTR-82-321	N/A	N/A	N/A	1	CB.67A	1	TRS 9R PRIM. PROT.	Y 9A	12	PL3268
EA	O-SW-30-327	N/A	N/A	N/A	1	C148A	1	TRS-6/10 PRIM. PROT.	Y 1.6A	12	PL3316
EE	O-TB-82-C1-S	N/A	N/A	N/A	1	C695A	1	TRS 10R PRIM. PROT.	Y 10A	12	PL3267
FS	O-PO-215-12	136YT 150	N/A	150	N/A	N/A	1	A4J40	Y 40A	4	PL3286
FW	O-PO-215-13	136YT 150	N/A	150	N/A	N/A	1	A4J60	Y 60A	4	PL3287
GA	O-HTR-30-318	136YT 150	N/A	150	N/A	N/A	1	A4J15	Y 15A	12	PL3271
GD	O-HTR 30-320	136YT 150	N/A	150	N/A	N/A	1	A4J15	Y 15A	12	PL3273
GG	O-HTR-30-323	136YT 150	N/A	150	N/A	N/A	1	A4J15	Y 15A	12	PL3276

Form GO-3.08.1 Rev. 2 SL-F647 04/84

IBN EEB-MS-TI15-0011 R0  
 Installation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchart Date 1/22/90 Checked Amaymudar Date 1/27/90  
R.H. Buchart 1/10/90 Dwan Kelley 1/25/90  
Albato 215190 RSnpkan 2-5-90

O-MCC-215-C2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
GK	O-JB-287-4784	136Y T150	N/A	150	N/A	N/A	1	A4J90	90A	2	PL3280
GR	O-HTR-30-326	136Y T150	N/A	150	N/A	N/A	1	A4J20	20A	2	PL3281 Zhou PL3285 PL3279

EEB-MS-TI15-0011 RO

Page H28 of H72

Location of Non-IE Power Circuits Located in Category 1 Structures

Prepared kmayndaw Date 1/22/90 Checked R.H. Burchart Date 1/24/90  
R.H. Burchart 1/17/90 kmayndaw 1/21/90

O-MCC-216-A

COMP-NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
2A	0-MTR-77-38	A010	HI	Y 84	1	T33	N/A	N/A	N/A	10	PLR1
2B	0-MTR-40-64A	A010	HI	Y 84	1	T34	N/A	N/A	N/A	10x2	PLR540
2C	1-MTR-40-354	A025Z	2	Y105	1	T37	N/A	N/A	N/A	8	IPL6840
2D	0-DXF-216-A	B020	NA	Y 20		N/A	N/A	N/A	N/A	10	PLR560
3A	0-MTR-77-11A	A010	4	Y 58	1	T32	N/A	N/A	N/A	10	PLR440
3B	0-MTR-77-179	A010	HI	Y 84	1	T32	N/A	N/A	N/A	10	PLR175
3C	2-MTR-40-14A	A025Z	LO	Y 75	1	T38	N/A	N/A	N/A	10	PLR470
3D	0-MTR-77-307	L050	2	Y210	2	T47	N/A	N/A	N/A	8	PLR180
3FZ	1-HTR-271-PT1	B030	N/A	Y 30		N/A	N/A	N/A	N/A	8	PLR500
4A	0-MTR-77-133A	A010	4	Y 58	1	T34	N/A	N/A	N/A	10	PLR84
4B	0-MTR-77-32	A010	HI	Y 84	1	T32	N/A	N/A	N/A	10	PLR90
4E	1-MTR-41-9	A025Z	2	Y105	1	T37	N/A	N/A	N/A	8	IPL5380
4F	1-HST-78-W12	B020	N/A	Y20		N/A	SHAW-MUT	TRS-30	Y 30	10	PLR200
5A	0-MTR-70-79	A010	HI	Y 84	1	T28	N/A	N/A	N/A	12	PLR158
5E	1-MTR-41-12	A025Z	2	Y105	1	T37	N/A	N/A	N/A	8	IPL5381
5F1	1-HST-78-W1	B020	N/A	Y20		N/A	N/A	N/A	N/A	10	PLR125
6A	0-MTR-77-141	A010	4	Y 58	1	T38	N/A	N/A	N/A	10	PLR106
6E	0-MTR-78-1	A010	HI	Y 84	1	T38	N/A	N/A	N/A	10	PLR52
6C	1-MTR-40-14A	A025Z	LO	Y 75	1	T19	N/A	N/A	N/A	10	PLR460
6D	1-MTR-41-15	A025Z	2	Y105	1	T37	N/A	N/A	N/A	8	IPL5382
6E	1-MTR-41-18	A025Z	2	Y105	1	T37	N/A	N/A	N/A	8	IPL5383
8A	0-MTR-30-FREF/1	A010	3	Y45	1	T33	N/A	N/A	N/A	10	PLR485
8B	0-MTR-30-FREF/2	A010	3	Y45	1	T33	N/A	N/A	N/A	10	PLR486
8C	0-MTR-30-FREF/3	A010	3	Y45	1	T33	N/A	N/A	N/A	10	PLR487
8D	0-MTR-30-FREF/4	A010	3	Y45	1	T33	N/A	N/A	N/A	10	PLR488
6F1	O-LAC-233-2Z	B030	N/A	Y30		N/A	N/A	N/A	N/A	8x2	PLR 555
6F2		B030	N/A	Y30		N/A	N/A	N/A	N/A		

SL-F647 04/84  
 Form GO-3.08.1 Rev. 2

EEB-MS-TI15-0011 R0

Page H29 of H72

Installation of Non-IE Power Circuits Located in Category 1 Structures

Prepared for gmdar Date 1/26/90 Checked R.H. Buchert Date 1/27/90  
R.H. Buchert 1/17/90 for gmdar 1/25/90

O-MCC-216-B

COMP-NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
2A	0-MTR-77-40	A010	4	Y58	1	T32	←	N/A	→	10	PLR9
2B	0-MTR-40-64B	A010	HI	Y84	1	T34	←	N/A	→	12x2	PLR548
2C	1-MTR-40-14B	A025Z	LO	Y75	1	T38	←	N/A	→	10	PLR465
2D	0-DXF-216-B	B020	N/A	Y20		N/A	←	N/A	→	10	PLR565
3A	0-MTR-77-11B	A010	4	Y58	1	T32	←	N/A	→	10	PLR448
3B	0-MTR-77-180	A010	HI	Y84	1	T32	←	N/A	→	10	PLR167
3C	2-MTR-40-14B	A025Z	LO	Y75	1	T38	←	N/A	→	10	PLR475
3E	2-MTR-43-354	A005	HI	Y41		N/A	←	N/A	→	8	2PL6840
3F1	0-ELEV-78-1	B020	N/A	Y20		N/A	←	N/A	→	10	PLR290
3F2	2-HTR-271-PT2	B030	N/A	Y30		N/A	←	N/A	→	8	PLR525
4A	0-MTR-77-133E	A010	4	Y58	1	T34	←	N/A	→	10	PLR75
4B	0-MTR-77-143	A010	HI	Y84	1	T32	←	N/A	→	10	PLR100
4E	2-MTR-41-9	A025Z	2	Y105	1	T37	←	N/A	→	8	2PL5380
4F	2-HST-78-W2	B020	N/A	Y20		N/A	SHW	TRS-50	N 50	10	PLR260
5A	0-MTR-70-77	A010	HI	Y84	1	T28	←	N/A	→	12	PLR157
5B	2-MTR-41-12	A025Z	2	Y105	1	T37	←	N/A	→	8	2PL5381
5E	0-CRN-78-1	B020	N/A	Y20		N/A	←	N/A	→	10	PLR195
5F1	2-HST-78-W1	B020	N/A	Y20		N/A	←	N/A	→	10	PLR230
6A	0-MTR-77-142	A010	4	Y58	1	T38	←	N/A	→	10	PLR113
6B	0-MTR-77-25	A010	3	Y45	1	T32	←	N/A	→	10	PLR20
6C	0-MTR-77-29	A010	HI	Y84	1	T32	←	N/A	→	10	PLR30
6D	2-MTR-41-15	A025	2	Y105	1	T37	←	N/A	→	8	2PL5382
6E	2-MTR-41-18	A025Z	2	Y105	1	T37	←	N/A	→	8	2PL5383

Form GO-308.1 Rev. 2 SL-F647 04/84

EEB-MS-T115-0011 R0

Location of Non-IE Power Circuits Located in Category 1 Structures

Prepared penygmuctur Date 1/22/90 Checked R.H. Buchert Date 1/26/90  
R.H. Buchert 1/17/90 penygmuctur 1/25/90

O-MCC-217-A

COMP. NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
2A	0-MTR-62-250	A003	3	Y12	1	T12	←	N/A	→	12	PL1780
2B	2-HTR-63-131A,131B	B040	N/A	Y40		N/A	←	N/A	→	6	PL1660
2D	0-MTR-31-451	H050	L0	Y320	2	T52	←	N/A	→	6	PL950
2E2	0-PNL-62-LIA	B070	N/A	Y70		N/A	←	N/A	→	4x2	PL1840
2F1	0-CHGR-217-A1, 0-PO-217-A1	B020	N/A	Y20		N/A	←	N/A	→	10	PL1793
2F2	0-HST-271-AB16	B040	N/A	Y40		N/A	←	N/A	→	6	PL1810
3A	0-MTR-62-251	A005	3	Y22	1	T24	←	N/A	→	12	PL1785
3B	1-HTR-63-132A,132B	B040	N/A	Y40		N/A	←	N/A	→	6	PL1672
3D	0-MTR-12-63	L050	3	Y260	2	T49	←	N/A	→	8	PL1700
3E	1-MTR-62-153	L050	4	N330	2	T51	←	N/A	→	8	PL1732
3F1	0-HTR-271-ABUM	B020	N/A	Y20		N/A	←	N/A	→	10	PL1926
4D	0-MTR-62-211	L050	3	Y260	2	T50	←	N/A	→	8x2	PL1760
4E	0-MTR-62-155	L050	4	N330	2	T51	←	N/A	→	8	PL1746 CONDUIT
4F1	1-CHL-43-161	B020	N/A	Y20		N/A	←	N/A	→	10	PL1800
5A	0-MTR-31-454	H050	2	Y400	2	T52	←	N/A	→	6	PL30
5E2	0-DXF-234-1/WDS	B030	N/A	Y30		N/A	←	N/A	→	8	PL1778
5F1	1-CHL-43-156	B020	N/A	Y20		N/A	←	N/A	→	10	PL1735

Form GO-308.1 Rev. 2  
 SL-F647 04/84

IBN EEB-MS- T115-0011 R0  
 Installation of Non-IE Power Circuits Located in Category 1 Structures

Prepared Kingpin dlar Date 1/22/90 Checked R.H. Buchart Date 1/26/90  
R.H. Buchart 1/17/90 Kingpin dlar 1/25/90

O-MCC-217-B

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
		EF3-		(A)		G30					
2B	2-HTR-63-131A,131B	B040	N/A	Y40	2(?)	N/A	←	N/A	→	6	PL1680
2C	2-MTR-31-398	A010	4	Y58	1	T32	←	N/A	→	10	PL1817
2D	0-MTR-62-148	H050	2	Y400	2	T52	←	N/A	→	6	PL1725
2E1	0-HST-271-AB18	B040	N/A	Y40		N/A	←	N/A	→	6	PL1830
2E2	0-PNL-62-L1B	B070	N/A	Y70		N/A	←	N/A	→	4	PL1880
2F1	0-HTR-271-ABUK	B020	N/A	Y20		N/A	←	N/A	→	10	PL1920
2F2	0-HST-271-AB19	B040	N/A	Y40		N/A	←	N/A	→	6	PL1820
3B	2-HTR-63-132A,B	B040	N/A	Y40		N/A	←	N/A	→	6	PL1692
3C	1-MTR-31-398	A010	4	Y58	1	T38	←	N/A	→	10	PL1812
3D	0-MTR-12-68	L050	3	Y260	2	T48	←	N/A	→	8	PL1711 CONDUIT
3E	2-MTR-62-153	L050	3	Y260	2	T51	←	N/A	→	8	PL1739
3F1	0-HTR-271-ABUL	B020	N/A	Y20		N/A	←	N/A	→	10	PL1923 CONDUIT
3F2	0-HST-271-AB20	B040	N/A	Y40		N/A	←	N/A	→	6	PL1825
4D	0-MTR-62-213	L050	3	Y260	2	T50	←	N/A	→	8	PL1768
4F1	2-CHL-43-161	B120	N/A	Y20		N/A	←	N/A	→	10	PL1822
5E1	0-HST-271-AB21	B040	↓	Y40		↓	←	N/A	→	6	PL1835 CONDUIT
5E2	0-DXF-234-2/WDS	B020	↓	Y20		↓	←	N/A	→	10	PL1755
5F1	2-CHL-43-156	B020	↓	Y20		↓	←	N/A	→	10	PL1792

Form GO-3.08.1 Rev. 2 SL-F647 04/84

EEB-MS-TI15-0011 R0  
 Population of Non-IE Power Circuits Located in Category 1 Structures

Prepared Kingman Date 1/22/90 Checked R.H. Buchart Date 1/26/90  
R.H. Buchart 1/17/90 Kingman 1/25/90

O-MCC-226-1

COMP NO	SERVICE	BKR TYPE	SET POS	TRIP RATING (A)	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO.
							MFR	MODEL	RATING		
2B	0-MTR-30-709B	A010	2	Y36	1	T29/T30	←	None	→	10	PLW365
2C	0-FCV-27-101	A005	3	Y22	1	T24		↓		10	PLW515
2D	0-MTR-30-714B	A010	3	Y45	1	N/A		↓		10	PLW360
2F1	0-HTR-30-710	B020	N/A	Y20		N/A	in	conduit		4	PLW393
2F2	0-PO-226-1,2,3	B100	N/A	Y100		N/A	←	None	→	2	PLW431
3A	0-FCV-27-97	A005	3	Y22	1	N/A		↓		6	PLW432
3B	0-MTR-40-10A	A010	4	Y58	1	T30	in	conduit		12	PLW500
3D	0-MTR-40-10B	A010	4	Y58	1	N/A		↓		12	PLW420
3E1	0-HTR-30-712	B020	N/A	Y20		N/A		↓		4	PLW425
3E2	0-DPL-226-1	B050	N/A	Y50		N/A	←	None	→	4	PLW400
3F1	0-HTR-30-711	B020	N/A	Y20		N/A		↓		4	PLW465
3F2	0-PO-226-4,5,6	B100	N/A	Y100		N/A		↓		10	PLW466
4B	0-MTR-30-709A	A010	2	Y36	1	N/A		↓		2	PLW376
4C	0-HTR-30-714	FJ3-B200	LO	Y960		N/A		↓		10	PLW377
4F1	0-LAC-233-34	B050	N/A	Y50		N/A		↓		2	PLW437
4F2	0-PO-226-7,8,9	B100	N/A	Y100		N/A		↓		2+2	PLW438
5A	0-MTR-30-714A	A010	3	Y45	1	N/A		↓		10	PLW375
5B	0-FCV-27-100	A005	3	Y22	1	N/A		↓		10	PLW508
5C	0-HTR-30-708	FJ3-B100	LO	Y750		N/A		↓		2	PLW415
5F2	0-HTR-30-713	B020	N/A	Y20		N/A		↓		10	PLW384
6A	0-MTR-30-708B	A010	2	Y36	1	T29/T30		↓		10	PLW370
6B	0-MTR-30-708A	A010	2	Y36	1	N/A		↓		10	PLW381
6C	0-HTR-30-709	FJ3-B100	LO	Y750		N/A		↓		2	PLW409
6E1	0-MTR-40-5	B020	N/A	Y20		N/A		↓		10	PLW480
6F1	0-HTR-30-7165	B020	N/A	Y20		N/A	in	conduit		10	PLW387
6F2	0-HTR-30-71	B020	N/A	Y20		N/A		↓		10	PLW390
7A	0-CRN-270-11	FJ3-B200	LO	Y960		N/A		↓		4/0	PLW470
7F1	0-MTR-40-68	B020	N/A	Y20		N/A	←	None	→	10	PLW490
7F2	0-LAC-226-32	B070	N/A	Y70		N/A	←	None	→	4	PLW425
5F1	LC 36	B020	N/A	Y20		N/A		↓		6	L29
										10	RM700

Form GO-3.0B.1 Rev. 2 SL-F647 04/84

WBN EEB-MS- TI15-0011 R0  
 Installation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchat Date 1/22/90 Checked kmymur Date 1/26/90  
R.H. Buchat 1/17/90 kmymur 1/25/90

O-MCC-249-1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING (A)	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
2A	O-MTR-249-HS54	A010	4	58		T34		N/A		10	PLR965
2B	O-MTR-249-HS55	A010	4	58		T34		N/A		10	PLR970
2D	O-MTR-249-HS33	FJ3-A225	2	1200		T60		N/A		1/0	PLR790
2F1	O-HST-249-1	B030	N/A	30	N/A	N/A		N/A		8	PLR952
2F2	O-ACU-249-B	B050	N/A	50	N/A	N/A		N/A		6	PLR920
3A	O-MTR-249-HS12	A010	H1	84		T29		N/A		10	PLR785
3B	O-MTR-249-HS11	A010	H1	84		T29		N/A		10	PLR780
3F2	O-HTR-249-WH	B050	N/A	50	N/A	N/A		N/A		6	PLR946
4A	O-MTR-249-HS20	A030	4	170 (45W748) (R2 S-L)		T41		N/A		10	PLR800
4B	O-MTR-249-HS22	A030	4	170 (45W748) (R2 S-L)		T41		N/A		10	PLR805
4F2	O-HST-249-2	B040	N/A	40	N/A	N/A		N/A		6	PLR950
5D1	O-MTR-249-CDWE /SF	B040	N/A	40	N/A	N/A		N/A		10	PLR948
5D2	O-MTR-249-CDWE /EF	B040	N/A	40	N/A	N/A		N/A		10	PLR944
5E2	O-ACU-249-A	B070	N/A	70	N/A	N/A		N/A		4	PLR936
5F1	O-HTR-249-A	B030	N/A	30	N/A	N/A		N/A		8	PLR933
5F2	O-HTR-249-B	B030	N/A	30	N/A	N/A		N/A		8	PLR928

Form GO-3.08.1 Rev. 2 SL-F647 04/84



IN EEB-MS-TI15-0011 R3

Population of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchert Date 1/22/90 Checked km ajm dhw Date 1/26/90  
R.H. Buchert 1/17/90 km ajm dhw 1/25/90

O-MCC-249-1

COMPT NO	SERVICE	BKR	SET	TRIP	STR	DL	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		TYPE	POS	RATING	SIZE	HTR CAT#	MFR	MODEL	RATING		
		EF3-		(A)		G30					
6A	O-MTR-249-HS60	A003	L0	Y7		T23	←	N/A	→	10	PLR43
6C	O-MTR-249-HS34	A010	4	Y5B		T32	←	N/A	→	10	PLR795
6E1	O-HTR-249-C	B020	N/A	Y20	N/A	N/A	←	N/A	→	10	PLR925
6F1	O-PO-249-1	B100	N/A	Y100	N/A	N/A	←	N/A	→	2	PLR910
8A1	O-HST-249-3	B040	N/A	Y40	N/A	N/A	←	N/A	→	6	PLR942
8B1	O-HST-249-4	B030	N/A	Y30	N/A	N/A	←	N/A	→	8	PLR940
8C	O-MTR-249-HS57	FJ3 -A225	Z	Y1200*		T60	←	N/A	→	1/0	PLR960
8E	O-MTR 249-HS56	FJ3 -A225	Z	Y1200*		T60	←	N/A	→	1/0	PLR955

\* ITC CIRCUIT BKR DATA FROM VENDOR MANUAL.

Form GO-3.08.1 Rev. 2 SL-F647 04/84

EEB-MS-TI15-0011 R0  
 Population of Non-IE Power Circuits Located in Category 1 Structures

Prepared Krajmuder Date 1/22/90 Checked R.A. Buchart Date 1/26/90  
Krajmuder 1/16/90 R.A. Buchart 1/25/90

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
1-MCC-209-A	0-XSW-250-2	B060	N/A	Y60		N/A	←	N/A	→	4	PL6280
/6F1											
/7D	1-FCV-3-253	A025	3	Y125		T42	←	N/A	→	10	IV4649
/10C	1-FCV-3-250	A025	3	Y125		T42	←	N/A	→	10	IV4640
/13E	1-FCV-3-251	A025	3	Y125		T42	←	N/A	→	10	IV4643
1-MCC-209-C	1-DXF-264-1	B100	N/A	Y100		N/A	←	N/A	→	2	IPL6660
/3F2											
1-MCC-210-A	1-FCV-3-252	A025	3	Y125	1	T42	←	N/A	→	10	IV4646
/2D											
/2F2	1-P0-210-A4	B030	N/A	Y30	N/A	N/A	←	N/A	→	8	IPL1195
/3F2	1-SW-210-A/3F2	A100	HI	N1125	-	N/A	←	N/A	→	2	PL6143
	45W753-2,3 R12,8										
	45W753 6,R10										
	45W757-1,2 R16,10										

Form GO-3.08.1 Rev. 2 SL-F647 04/84

WBN EEB-MS-TI15-0011 R0

Page H35A of H.72

Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared: J. Bates Date 2/5/90 Checked: R. Sunkar Date 2-5-90

1-DPL-68-341 H

COMPT NO	SERVICE	BKR MODEL NO	SENSOR RATING (A)	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
	Pressurizer Htr Group C	XJL100	100						JJS225	1/0	1PL6430 1PL6431 1PL6432 1PL6433 1PL6434 1PL6435  1PL4702 1PL4703 1PL4704 1PL4705 1PL4706 1PL4707  2 1PL4710 1PL4711 1PL4712 1PL4713 1PL4714 1PL4715

WBN EEB-MS-TI15-0011 R0

Page H35B of H72

Enumeration of Non-IE Power Circuits Located in Category 1 Structures

Prepared: M. Bate Date 2/5/90 Checked R. Supkar Date 2-5-90

1-DPL-68-341F

COMPT No	SERVICE	BKR MODEL NO	SENSOR RATING (A)	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
	Pressurizer Htr Group D	XJLY100	100						JJS225Y	1/0	1PL6410 1PL6411 1PL6412 1PL6413 1PL6414 1PL6415  1PL4655 1PL4656 1PL4657 1PL4658 1PL4659 1PL4660  1PL4661 1PL4662 1PL4663 1PL4664 1PL4665 1PL4666

EEB-MS-TI15-0011 R0  
 Location of Non-IE Power Circuits Located in Category 1 Structures

Prepared R. H. Buchat Date 1/22/90 Checked R. H. Buchat Date 1/26/90  
W. Bates 1/16/90 2/5/90 R. Slupka 1/25/90 2/5/90

1-MCC-213-A1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
16A	1-PENT-293-32	A010	3	Y 45 Y	1	T32	SHAW-MUT	TRS-30	Y 30A N	10 12	1PL6300 1PL6301
16B	1-PENT-293-24	A010	LO	Y 27 Y	1	T27	SHAW-MUT	TRS-30	Y 30A N	10 12	1PL6268 1PL6269
16F1	0-XSW-252-1	B020	N/A	Y 20	N/A	N/A	N/A	N/A	N/A	10	1PL6040
16F2	1-TB-31-303/2	B020	N/A	Y 20	N/A	N/A	N/A	N/A	N/A	10x2	1PL6289
17A	0-JB-292-2051	B030	N/A	Y 30	2	N/A	N/A	N/A	N/A	8 12 12	1PL6208 1PL6209 1PL6210
17E	1-PENT-293-32	B100	N/A	Y 100	N/A	N/A	SHAW-MUT	CPGA-197 #2	N/A	2 2	1PL6100 1PL6094
17F1	0-XSW-240-5	B020	N/A	Y 20	N/A	N/A	N/A	N/A	N/A	10	1PL6060
18C	1-MTR-31-303	A010	3	Y 45	1	T32	← N/A →			12	1PL6281
18D	0-MTR-62-226	A005	3	Y 22	1	T26	← N/A →			12	1PL6265
18F1	0-XSW-250-1	B020	N/A	Y 20	←	N/A			→	10	PL871
18F2	1-JB-293-2859	A100	LO	Y 475	←	N/A			→	2x2 2 2 2 2	1PL6093 1PL6101 1PL6102 1PL6103 1PL6104 1PL6106

SN EEB-MS- T115-0011 R0  
 Installation of Non-IE Power Circuits Located in Category 1 Structures

Prepared K. Srinivasan Date 1/22/90 Checked R.H. Buckert Date 1/24/90  
K. Srinivasan 1/16/90 R.H. Buckert 1/25/90

1-MCC-213-A2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		EF3-		(A)		G30	MFR	MODEL	RATING		
4A	1-FCV-3-191	A010	3	745	1	T32	←	N/A	→	12	1V3260
4B	1-FCV-3-192	A010	3	745	1	T32	←	N/A	→	12	1V3280

IN EEB-MS-TI15-0011 R0  
 Tabulation of Non-IE Power Circuits Located in Category 1 Structures  
 Prepared R.H. Buchart Date 1/22/90 Checked Jim Gardner Date 1/26/90  
R.H. Buchart 1/10/90 Scott Kelley 1/25/90

1-MCC-213-B1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
3F1	0-XSW-252-2	B020	N/A	Y 20			N/A			10	IPL6045
16A	1-PENT-293-35	A010	3	Y 45	1	T32	1	TR5 30	Y 30A N	10 12	IPL6310 IPL6311
16E	1-PENT-293-47	B100	N/A	Y 100	N/A	N/A	1	CP6A-197 #2	N Y 2/15/90 REC 2/15/90	2 2	IPL6085 IPL6082
16F1	0-XSW-240-5	B020	N/A	Y 20		N/A				10	IPL6061
17A	0-JB-292-2048	B040	N/A	Y 40 N N	2		N/A			8 12 12	IPL6214 IPL6215 IPL6216
17E	1-PENT-293-35	B100	N/A	Y 100	N/A	N/A	1	CP6A-197 #2	N Y 2/15/90 REC 2/15/90	2x2 2	IPL6075 IPL6076
17F1	0-XSW-240-1	B020	N/A	Y 20			N/A			10	PL876
17F2	1-TB-31-324/2	B020	N/A	Y 20			N/A			10	IPL6291
18C	1-MTR-31-324/1	A010	3	Y 45	1	T32		N/A		10	IPL6285
18D	0-MTR-84-2	A005	3	Y 22	1	T26		N/A		12	IPL6273

MBN EEB-MS-TI15-0011 R0

Population of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buehler Date 1/22/90 Checked kmajumdar Date 1/26/90  
R.H. Buehler 1/10/90 kmajumdar 1/21/90

1-MCC-213-B2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		EF3-		(A)		G30	MFR	MODEL	RATING		
4A	1-FCV-3-193	A0102	3	745	1	T32	←	N/A	→	12	1V3290
4B	1-FCV-3-194	A0102	3	745	1	T32	←	N/A	→	12x2	1V3270
12A	0-FCV-67-362	B010	L0	727	1	T28	←	N/A	→	12	1V3230



UBN EEB-MS-TI15-0011 R0  
Circulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared Krajmudar Date 1/22/90 Checked R.H. Buchert Date 1/26/90  
R.H. Buchert 1/10/90 Scott Kelley 1/25/90

1-MCC-214-A1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		EF3-		(A)		G30	MFR	MODEL	RATING		
2D	1-MTR-81-3	H050	2	400	3	T52	N/A	N/A	N/A	6	IPL3221
2F1	0-DXF-234-A/SIS	B020	N/A	20	N/A	N/A	GOULD/SHAWMUT	DISA030	Y 30A	8	IPL3590
2F2	1-DXF-242-1	B070	N/A	70	N/A	N/A	GOULD/SHAWMUT	DISA8100	*N 100A	4	IPL3596
3F1	1-RE-90-119	B020	N/A	20	N/A	N/A	GOULD/SHAWMUT	DISA030	*N 30A	10	IPL3589
3F2	0-TB-40-3	B020	N/A	20	N/A	N/A	GOULD/SHAWMUT	DISA030	*N 30A	10	IPL3720 <del>IPL3716</del> 2-5790
5F1	0-RE-90-132	B020	N/A	20	N/A	N/A	GOULD/SHAWMUT	DISA030	*N 30A	10	IPL3599
10F1	0-RE-90-101	B020	N/A	20	N/A	N/A	GOULD/SHAWMUT	DISA030	*N 30A	10	IPL3598
12E1	1-PNL-90-L398	B020	N/A	20	N/A	N/A	GOULD/SHAWMUT	DISA030	*N 30A	10	IPL3610
13A	1-MTR-84-16	A005	3	22	1	T25	← N/A →			12	IPL2940
13B	0-MTR-84-6	A005	3	22	1	T25	← N/A →			12	IPL3460
13C	1-MTR-65-77	A0252	L0	75	1	T37	← N/A →			12	IPL3645

Shamut DISA & HFCP are the same fuse.

SL-F647 04/84  
Form GO-308.1 Rev. 2

EEB-MS-TI15-0011 R0

Installation of Non-IE Power Circuits Located in Category 1 Structures

Prepared Ameyhuder Date 1/22/90 Checked R.H. Buchert Date 1/24/90  
Ameyhuder 1/16/90 R.H. Buchert 1/25/90  
AlBates 2/5/90 R. Supkar 2-5-90

1-MCC-214-A2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
2A	0-MTR-31-339	A003	3	Y12	1	T20		N/A		12	IPL2830
2D1	1-HTR-30-A1A	B020	N/A	Y20	N/A	N/A	1	DISA030	N 30A	10	IPL3280
2D2	0-PO-214-1	B100	N/A	Y100	N/A	N/A	1	DISA100	Y 100A	2	IPL2780
2E1	1-HTR-30-B1A	B020	N/A	Y20	N/A	N/A	1	DISA030	N 30A	10	IPL3284
2E2	0-TB-31-493/1	B0502	N/A	Y50 N	N/A	N/A	1	DISA050	Y 50A N	6 10	IPL6460 IPL6463,64
2F2	0-PO-214-7	B100	N/A	Y100	N/A	N/A	1	DISA100	Y 100A	2	IPL2777
3A	1-MTR-30-25	A010	3	Y45	1	T32		N/A		12x2	IPL2906
3D1	1-HTR-30-ACRD	B020	N/A	Y20	N/A	N/A	1	DISA030	N 30A	10	IPL3266
3D2	0-PO-214-5	B100	N/A	Y100	N/A	N/A	1	DISA100	Y 100A	2	IPL2775
3E1	1-HTR-30-C1A	B020	N/A	Y20	N/A	N/A	1	DISA030	N 30A	10	IPL3288
3E2	1-HTR-30-D1A	B0502	N/A	Y50	N/A	N/A	1	DISA050	Y 50A	6	IPL3510
3F1	0-HTR-31-97	B020	N/A	Y20	N/A	N/A	1	DISA030	N 30A	10	IPL2800
3F2	1-HTR-30-1A1	B020	N/A	Y20	N/A	N/A	1	DISA030	N 30A	10	IPL3365
4A	1-MTR-30-283	A005	2	Y18	1	T24		N/A		12	IPL3621
4B	0-MTR-31-203 /204	A025	3	Y125	1	T44		N/A		10	V1920
4E1	1-HTR-30-BCRD	B020	N/A	Y20	N/A	N/A	1	DISA030	N 30A	10	IPL3264

EEB-MS-TI15-0011 R0

Location of Non-IE Power Circuits Located in Category 1 Structures

Prepared Ameybudar Date 1/22/90 Checked R.H. Burchat Date 1/26/90  
Ameybudar 1/16/90 R.H. Burchat 1/25/90

1-MCC-214-A2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		EF3-		(A)		G30	MFR	MODEL	RATING		
4F1	1-HTR-30-CCRD	B020	N/A	Y20	N/A	N/A	1	DISA030	N30A	10	IPL3268
5A	1-MTR-30-301	A010	3	Y45	1	T34	← N/A →			12	IPL3435
5E1	0-HTR-31-83	B030	N/A	Y30	N/A	N/A	1	DISA030	Y30A	8	IPL3707
5F1	1-HTR-30-XMIA	B020	N/A	Y20	N/A	N/A	1	DISA030	N30A	10	IPL3370
5F2	1-HTR-30-ABI	B020	N/A	Y20	N/A	N/A	1	DISA030	N30A	10	IPL3314
6E1	1-HTR-30-SMS	B030	N/A	Y30	N/A	N/A	1	DISA030	Y30A	8	IPL2811
6E2	1-HTR-30-NMI	B050	N/A	Y50	N/A	N/A	1	DISA050	Y50A	6	IPL2806
6F2	0-HTR-30-RMI	B020	N/A	Y20	N/A	N/A	1	DISA030	N30A	10	IPL3320
7D2	0-HTR-30-AFH	B040	N/A	Y40	N/A	N/A	1	DISA050	Y50A	6	IPL3335
7E1	1-HTR-30-UIA	B020	N/A	Y20	N/A	N/A	1	DISA030	N30A	10	IPL2813
7E2	0-HTR-30-BFH	B040	N/A	Y40	N/A	N/A	1	DISA050	Y50A	6	IPL3330
7F2	0-HTR-30-CFH	B040	N/A	Y40	N/A	N/A	1	DISA050	Y50A	6	IPL3340
8A	1-MTR-30-CRD	FJ3 B125	H1	Y1600	N/A	N/A	← N/A →			2/0	IPL3692
8B	1-HTR-1-CBS	FJ3 B125	L1	Y1500	N/A	N/A	← N/A →			4/0	IPL3680

SL-F647 04/84

Form GO-3.08.1 Rev. 2

EEB-MS-TI15-0011 R0

Enumeration of Non-IE Power Circuits Located in Category 1 Structures

Prepared K. H. Buchart Date 1/22/90 Checked R. H. Buchart Date 1/24/90  
R. H. Buchart 1/10/90 Don Welley 1/25/90

1-MCC-214-B1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
2D	1-MTR-81-7	H050	2	400	3	T52	← N/A →			6	IPL3228
2F1	0-DXF-234-B1	B020	N/A	20	N/A	N/A	1	DISA030	Y 30A	8	IPL3740
2F2	0-TB-40-66	B020	N/A	20	N/A	N/A	1	DISA030	N 30A	10	IPL3730
9F1	1-PNL-55-L236	B020	N/A	20	N/A	N/A	1	DISA030	N 30A	10	IPL2972
12A	1-MTR-30-181	A010	3	45	1	T33	← N/A →			10	IPL3021
12E1	0-PNL-90-L397	B020	N/A	20	N/A	N/A	1	DISA030	N 30A	10	IPL3609
12F1	1-RE-90-99	B020	N/A	20	N/A	N/A	1	DISA030	N 30A	10	IPL3790
13A	1-MTR-84-21	A005	3	22	1	T23	← N/A →			12	IPL2948
13B	0-MTR-84-11	A005	3	22	1	T24	← N/A →			12	IPL3465
13C	1-MTR-65-74	A025	LO	75	1	T37	← N/A →			12	IPL3660
13F1	0-DXF-234-B4	B020	N/A	20	N/A	N/A	1	DISA030	N 30A	10	IPL3017

SL-F647 04/84

Form GO-3.08.1 Rev. 2

3-7-91

NON EEB-MS-TI15-0011 RO

Location of Non-IE Power Circuits Located in Category 1 Structures

Prepared knajhndar Date 1/22/90 Checked R.H. Buchart Date 1/20/90  
R.H. Buchart 1/10/90 Deora Welley 1/25/90

1-MCC-214-B2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
2B	0-MTR-31-418	A005	4	Y29	1	T28	←	N/A	→	12	IPL3654
2E1	1-HTR-30-A1B	B020	N/A	Y20	N/A	N/A	1	N DISA030	30A	10	IPL3676
2E2	0-HTR-30-GFA	B040	N/A	Y40	N/A	N/A	1	Y DISA050	50A	6	IPL3400
2F1	1-HTR-30-B1B	B020	N/A	Y20	N/A	N/A	1	N DISA030	30A	10	IPL3898
2F2	1-HTR-31-BRB	B050	N/A	Y50	N/A	N/A	1	Y DISA050	50A	6	IPL3890
3B	1-MTR-30-284	A005	2	Y18	1	T24	←	N/A	→	12	IPL3626
3C	1-MTR-30-66	A005	2	Y18	1	T24	←	N/A	→	12	IPL3631
3E1	1-HTR-30-C1B	B020	N/A	Y20	N/A	N/A	1	N DISA030	30A	10	IPL3895
3E2	0-HTR-30-HFA	B040	N/A	Y40	N/A	N/A	1	Y DISA050	50A	6	IPL3405
3F1	1-HTR-30-PRX	B020	N/A	Y20	N/A	N/A	1	N DISA030	30A	10	IPL3395
4B	1-MTR-30-302	A010	3	Y45	1	T32	←	N/A	→	12	IPL3438
4E1	0-HTR-31-95	B020	N/A	Y20	N/A	N/A	1	N DISA030	30A	10	IPL2809
4E2	0-HTR-30-NFA	B040	N/A	Y40	N/A	N/A	1	Y DISA050	50A	6	IPL3415
4F1	1-HTR-30-SBU	B020	N/A	Y20	N/A	N/A	1	N DISA030	30A	10	IPL3425
4F2	1-HTR-30-U113	B020	N/A	Y20	N/A	N/A	1	N DISA030	30A	10	IPL2975
5E1	1-HTR-31-87	B020	N/A	Y20	N/A	N/A	1	N DISA030	30A	10	IPL2825

Form GO-3.08.1 Rev. 2 SL-F647 04/84

EEB-MS-TI15-0011 RO  
 Location of Non-IE Power Circuits Located in Category 1 Structures

Page H45 of H72

Prepared Amjadur Date 1/22/90 Checked R.H. Buchert Date 1/26/90  
R.H. Buchert 1/12/90 Zsuzsanna Kelly 1/25/90  
ElBates 2/5/90 RSupkar 2-5-90

1-MCC-214-B2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		EF3-		(A)		G30	MFR	MODEL	RATING		
5F1	0-HTR-30-RM2	B020	N/A	Y 20	N/A	N/A	1	DISA030	N 30A	10	IPL3385
6B	1-MTR-30-26	A010	3	Y 45	1	T32	← N/A →			12	IPL2913
6E1	1-HTR-30-AB7	B020	N/A	Y 20	N/A	N/A	1	DISA030	N 30A	10	IPL3381
6F1	1-HTR-30-T1B	B020	N/A	Y 20	N/A	N/A	1	DISA030	N 30A	10	IPL3430
7D	0-HTR-31-421	FJ3- B225	HI	Y 2000	N/A	N/A	← N/A →			300	IPL3440
7E2	0-HTR-31-72	EF3- B030	N/A	Y 30	N/A	N/A	1	DISA030	Y 30A	8	IPL2977
7F1	1-HTR-30-NM2	B050Z	N/A	Y 50	N/A	N/A	1	DISA050	Y 50A	6	IPL3421
8F1	0-TB-31-494	B040	N/A	Y 40	N/A	N/A	1	DISA050	Y 50A N	6 10	IPL6470 IPL6473 IPL6474
8F2	1-PO-214-10	B100	N/A	Y 100	N/A	N/A	1	DISA0100	Y 100A	2	IPL2785
9A	1-MTR-30-CRB	FJ3- B125	LO	Y 750	N/A	N/A	← N/A →			4/0	IPL3671

W EEB-MS- T115-0011 R0

Page H46 of H72

Location of Non-IE Power Circuits Located in Category 1 Structures

Prepared kmj/mclaw Date 1/22/90 Checked R.H. Buchat Date 1/26/90  
kmj/mclaw 1/16/90 R.H. Buchat 1/25/90

1-MCC-215-A1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
5A	1-MTR-82-181	A025	LO	75	1	T38	← N/A →			12	PL2195
5F1	0-HTR-30-479	B020	N/A	20			← N/A →			10	PL2322
5F2	1-JB-296-256	B100	N/A	100			← N/A →			2	PL2539
6A	1-SW-30-463	A005	2	18	1	T25	← N/A →			12	PL2235
6F1	0-HTR-30-483	B020	N/A	20			← N/A →			10	PL2310

WBN EEB-MS-TI15-0011 R0

Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared Krajmudar Date 1/22/90 Checked R.H. Buchat Date 1/26/90  
Krajmudar 1/15/90 R.H. Buchat 1/25/90

1-MCC-215-A2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							EF3-	(A)	G30		
2E2	0-HTR-30-484	B040	N/A	Y 40			N/A			6	PL2304
3E1	1-HTR-30-487	B020	N/A	Y 20	N/A	N/A	N/A	N/A	N/A	10	PL2411
3F1	1-HTR-30-471	B030	N/A	Y 30	N/A	N/A	N/A	N/A	N/A	8	PL2262
3F2	1-HTR-30-472	B030	N/A	Y 30	N/A	N/A	N/A	N/A	N/A	8	PL2268
5A	1-MTR-82-180	A025Z	LO	Y 75	1	T38	N/A	N/A	N/A	12	PL2200
5E1	0-HTR-30-485	B030	N/A	Y 30	N/A	N/A	N/A	N/A	N/A	8	PL2316
5F1	0-SW-39-37	B020	N/A	Y 20	N/A	N/A	N/A	N/A	N/A	10	PL2765
6A	0-MTR-30-470	A005	4	Y 29	1	T28	N/A	N/A	N/A	12	PL2572
6D	1-TB-82-A1-A	B020	N/A	Y 20	1	N/A	N/A	N/A	N/A	12	PL2700
2E2	0-HTR-30-484	B040	N/A	Y 40	N/A	N/A	N/A	N/A	N/A	6	PL2304



MBN EEB-MS-TI15-0011 R0  
 Abulation of Non-IE Power Circuits Located in Category 1 Structures  
 Prepared Junyandar Date 1/22/90 Checked R.H. Buchart Date 1/24/90  
R.H. Buchart 1/17/90 Junyandar 1/25/90

1-MCC-215-B1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							EF3-	(A)	G30		
5A	1-MTR-82-211	A0252	LO	75	1	N/A	N/A	N/A	N/A	12	PL2215
5F1	0-HTR-30-481	3020	N/A	20	N/A	N/A	N/A	N/A	N/A	10	PL2340
6A	1-SW-30-465	A005	2	1/18	1	T26	N/A	N/A	N/A	12	PL2249

EEB-MS-TI15-0011 R0  
 Calculation of Non-IE Power Circuits Located in Category 1 Structures  
 Prepared Krajendar Date 1/22/90 Checked R.H. Buchart Date 1/26/90  
R.H. Buchart 1/17/90 Krajendar 1/25/90

1-MCC-215-B2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		EF3-		(A)		G30	MFR	MODEL	RATING		
3E1	1-HTR-30-489	3020	N/A	1/20	N/A	N/A	N/A	N/A	N/A	10	PL2412
3F1	1-HTR-30-473	3030	N/A	1/30	N/A	N/A	N/A	N/A	N/A	8	PL2274
3F2	1-HTR-30-474	3030	N/A	1/30	N/A	N/A	N/A	N/A	N/A	8	PL2280
5A	1-MTR-82-210	A0252	L0	1/75	1	T38	N/A	N/A	N/A	12	PL2220
5F2	1-JB-296-258	B100	N/A	1/100	N/A	N/A	N/A	N/A	N/A	2	PL2552
6D	1-TB-82-B/1-B	B020	N/A	1/20	1	N/A	N/A	N/A	N/A	12	PL2706

3-7-91

WBN EEB-MS-TI15-0011 R0

Page H50 of H72

Tabulation of Non-IE Power Circuits Located in Category I Structures

Prepared KM by JLB Date 1/22/90 Checked TBT FOR RAB Date 1-26-90  
KM by JLB 1/16/90 TBT FOR RAB 1-25-90  
JLBates 2/5/90 R. Supkar 2-5-90

1-MCC-232-A

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							EF3-	(A)	G30		
2A	1-PENT-293-24	A010	3	Y45 Y	1	T35	SHAW-MUT	TRS-30	Y30 N	10X2 12	IPL653 IPL654
3A	1-PENT-293-32 FLUX D	B020	N/A	Y20	N/A	N/A	"	DISA030	N30	10X2 10	IPL295 IPL296
3B	1-PENT-293-32 FLUX E	B020	N/A	Y20	N/A	N/A	"	DISA030	N30	10X2 10	IPL300 IPL301
3C	1-PENT-293-32 FLUX F	B020	N/A	Y20	N/A	N/A	"	"	N30	10X2 10	IPL305 IPL306
4D	1-MTR-61-51	L050	4	N 330	2	T51	N/A	N/A	N/A	8	IPL4320
4E	1-HTR-61-92	B050	N/A	Y50	-2	T51	N/A	N/A	N/A	6	IPL4300
5A	0-MTR-31-406	A005	4	Y29	1	T28	N/A	N/A	N/A	12	IPL644
6A	0-MTR-31-25	A010	4	Y58	1	T34	N/A	N/A	N/A	12	IPL735
6C	0-MTR-77-91	H050	L0	Y320	2	T52	N/A	N/A	N/A	6x2	IPL5460
6F1	0-SW-234-A/ IPS	B030	N/A	Y30	N/A	N/A	SHAW-MUT	DISA030	Y30	1/0	IPL1108
7B	1-PENT-293-32 RCP 1 HTR	A010	2	Y36	1	T36	"	TRS-30	N30	12 12	IPL370 IPL371
7D	1-PENT-293-32 RCP 1 LIFT	B040	N/A	Y40	1	T44	"	"	Y30	10 10	IPL396 IPL397
7F2	1-JB-292-994	B100	N/A	Y100	N/A	N/A	SHAW-MUT	DISA B100	Y100	2	IPL258
8B	1-PENT-293-24 RCP 3 HTR	A010	2	Y36	1	T36	"	TRS-30	N30	12X2 12	IPL382 IPL383
8D	1-PENT-293-24 RCP 3 LIFT	A025	3	Y125	1	T45	"	"	Y30	10X2 10	IPL408 IPL409
8F2	1-JB-292-993	B100	N/A	Y100	N/A	N/A	SHAW-MUT	DISA B100	Y100	2	IPL240 241,243

WBN EEB-MS-TI15-0011 R0

Page H51 of H72

Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchert Date 1/22/90 Checked Krajmuder Date 1/26/90  
Krajmuder 1/16/90 R.H. Buchert 1/25/90  
ZLBats 2/15/90 R. Svrpkar 2/15/90

1-MCC-232-A

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		EF3-		(A)		G30	MFR	MODEL	RATING		
9B	1-PENT-293-32 FAN A	A025	LO	Y 75 Y	1	T40	SHAW-MUT	TRS-30	Y 30 N	10x2 12	IPL520 IPL521
9F2	1-JB-292-1869	B100	N/A	Y 100	N/A	N/A	SHAW-MUT	DISAB100	Y 100	2	IPL250, 251-253
10B	1-PENT-293-24 FAN C	A025	2	Y 105 Y	1	T40	"	TRS-30	Y 30 N	10x2 12	IPL550 IPL551
10F	1-PENT-293-32 STUD	B020	N/A	Y 20 Y	N/A	N/A	"	DISA030	N 30 N	10 12	IPL270 IPL271
11D	1-PENT-293-24 RCDT A	B030	N/A	Y 30	2	T45	"	TRS-60	Y 60	8 8	IPL485 IPL486
11F	1-PENT-293-32 HTR A	B020	N/A	Y 20	N/A	N/A	"	DISA030	N 30	10 10	IPL336 IPL337
12F	1-PENT-293-32 HTRA	B020	N/A	Y 20	N/A	N/A	"	"	Y 30	10 10	IPL5440 IPL5441
13A	1-PENT-293-5	B040	N/A	Y 40	N/A	N/A	"	DISA050	Y 50	6 6	IPL621 IPL622
13D	1-PENT-293-5	FJ3-B175	HI	Y 1600 N	N/A	N/A	SHAW-MUT	CPGA-14 4/0	Y 2/15/60 Y 2/1/40	4/0x2 2/0	IPL820 IPL821
14B	1-PENT-293-5	EF3-A010	2	Y 36	1	T29	"	TRS-30	N 30	12	IPL587 IPL588
14D	1-PENT-293-5	FJ3-B150	HI	Y 1600 Y	N/A	N/A	SHAW-MUT	CPGA-14 4/0	Y 2/15/60 Y 2/1/40	4/0 2/0	IPL861 IPL862
15A	1-PENT-293-32 (1-HTR-30-35H)	EF3-B070	N/A	Y 70	N/A	N/A	"	DISAB100	N 100	4 4	IPL425 IPL426
15D	1-MTR-30-1	B100	N/A	Y 100	3	T56	N/A	N/A	N/A	2x2	IPL777
16A	1-PENT-293-5	B070	N/A	Y 70	N/A	N/A	SHAW-MUT	DISAB100	N 100	4 4	IPL440 IPL441
16D	1-MTR-30-1E	A100	3	Y 760	3	T56	N/A	N/A	N/A	2	IPL764

Form GO.3.08.1 Rev. 2 SL-F647 04/84

WBN EEB-MS-TI15-0011 R0

Page H52 of H72

Installation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchart Date 1/22/90 Checked knajmudar Date 1/26/90  
knajmudar 1/16/90 R.H. Buchart 1/25/90  
AlBates 2/5/90 R. Supkar 2-5-90

1-MCC-232-B

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
2A	1-PENT-293-47 (1-MTR-77-125B)	A010	3	Y45	1	T33	SHAW-MUT	TRS-30	N30	12 10	IPL672 IPL673
3A	1-PENT-293-35	B020	N/A	Y20	N/A	N/A	"	"	Y30	10 10	IPL280 IPL281
3B	1-PENT-293-35	B020	N/A	Y20	N/A	N/A	"	DISA030	N30	10 10	IPL285 IPL286
3C	1-PENT-293-35	B020	N/A	Y20	N/A	N/A	"	DISA030	N30	10 10	IPL290 IPL291
5E	1-MTR-30-11	A003	2	Y10	1	T16	N/A	N/A	N/A	12	IPL794
6A	0-MTR-31-26	A010	4	Y58	1	T34	N/A	N/A	N/A	12	IPL752
6C	1-MTR-61-61	L050	4	N330	2	T51	N/A	N/A	N/A	8	IPL4325
6D	1-HTR-61-93	B050Z	N/A	Y50		T51	N/A	N/A	N/A	6	IPL4310
6E	1-MTR-30-11E	A003	2	Y10	1	T16	N/A	N/A	N/A	12	IPL760
6F1	1-STR-40-2	B020	N/A	Y20	N/A	N/A	SHAW-MUT	DISA030	N30	10	IPL695
7B	1-PENT-293-35	A010	4	Y58	1	T36	"	TRS-30	N30	12 12	IPL376 IPL377
7D	1-PENT-293-35	B040	N/A	Y40	1	T44	"	"	Y30	10 10	IPL402 IPL403
8B	1-PENT-293-47	A010	2	Y36	1	T36	"	"	N30	12 12	IPL388 IPL389
8D	1-PENT-293-47	B040	N/A	Y40	1	T44	"	"	Y30	10 10	IPL414 IPL415
8F1	0-SW-234-B/ IPS	B030	N/A	Y30	N/A	N/A	SHAW-MUT	DISA030	Y30	10x2	IPL1115
9B	1-PENT-293-35	A025	L0	Y75 Y	1	T40	"	TRS-30	Y30 N	10 12	IPL531 IPL532

SL-F647 04/84

Form GO-3.08.1 Rev. 2

URN EEB-MS-TI15-0011 R0

Calculation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchert Date 1/22/90 Checked Kingmucker Date 1/26/90

Kingmucker  
LLBates

1/16/90  
2/5/90

R.H. Buchert 1/25/90  
R. Supkar 2-5-90

1- MCC-232-B

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							EF3-	(A)	G30		
10B	1-PENT-293-47	A025	2	Y 105	1	T40	SHAW-MNT	TRS-30	Y 30 N	10 12	IPL561 IPL562
10F	1-PENT-293-11	B020	N/A	Y 20	N/A	N/A	"	"	Y 30	10 10	IPL707 IPL708
11D	1-PENT-293-11	B100	N/A	Y 100	2	T49	"	TRS-60	Y 60	4 4	IPL496 IPL497
11F	1-PENT-293-35	B020	N/A	Y 20	N/A	N/A	"	DISA030	N 30	10 10	IPL345 IPL346
12F	1-PENT-293-35	B020	N/A	Y 20	N/A	N/A	"	"	N 30	10 10	IPL545D IPL545I
13B	1-PENT-293-11	A010	2	Y 36	1	T29	"	TRS-30	Y 30 N	10 12	IPL598 IPL599
13D	1-PENT-293-11	FJ3-B175	HI	Y 1600	N/A	N/A	"	CP6A-14 4/0	Y 30 N 4/0 2/0 2/0	4/0 2/0 2/0	IPL897 IPL975 IPL902
13F	1-PENT-293-11	EF3-B050	N/A	Y 50	N/A	N/A	"	DISA050	Y 50	6 6	IPL712 IPL713
14B	1-PENT-293-11	A003	L0	Y 7	1	T12	"	TRS-30	N 30	12 12	IPL1100 IPL1101
14D	1-PENT-293-11 (AHU)	FJ3-3150	HI	Y 1600	N/A	N/A	"	CP4/0 -CS	Y 30 N	4/0 2/0 2/0	IPL937 IPL938 IPL943
14F	1-PENT-293-11	EF3-B040	N/A	Y 40	N/A	N/A	"	DISA050	Y 50	6 6	IPL704 IPL705
15A	1-PENT-293-35	B070	N/A	Y 70	N/A	N/A	"	DISAB100	N 100	4 4	IPL454 IPL455
15D	1-MTR-30-4	A100	3	Y 760	3	T57	N/A	N/A	N/A	2	IPL785
16A	1-PENT-293-47	B070	N/A	Y 70	N/A	N/A	SHAW-MNT	DISAB100	N 100	4 4	IPL468 IPL469
16D	1-MTR-30-4E	A100	3	Y 760	3	T57	N/A	N/A	N/A	2	IPL768

\* IPL 902 → IPL 907 (2/0) → IPL 912 (2/0) → IPL 917 (2/0) → IPL 922 (2/0) → IPL 927 (2/0) → IPL 932 (2/0)  
 \*\* IPL 943 → IPL 948 (2/0) → IPL 953 (2/0) → IPL 958 (2/0) → IPL 963 (2/0) → IPL 968 (2/0)

SL-F647 04/84  
 Form 00-3.08.1 Rev. 2

WBN EEB-MS-T115-0011 R0

Page H53A of H72

Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared: ML Bates Date 2/5/90 Checked R Supkar Date 2-5-90

2-DPL-68-341F

COMPT No	SERVICE	BKR MODEL NO	SENSOR RATING (A)	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
	Pressurizer Htr Group D	SL100	100						JJS-225	1/0	2PL6410 2PL6411 2PL6412 2PL6413 2PL6414 2PL6415
									Y	1/0	2PL4655 2PL4656 2PL4657 2PL4658 2PL4659 2PL4660
									Y	2	2PL4661 2PL4662 2PL4663 2PL4664 2PL4665 2PL4666

WBN EEB-MS-TI15-0011 R0

Page 454 of 472

Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared: R Supkar Date 2-5-90 Checked JL Bates Date 2/5/90

2-DPL-68-341H

COMPT No	SERVICE	BKR MODEL NO	SENSOR RATING (A)	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO	
	Pressurizer Heater Backup Group C	KJL100	100						JJS225	1/0	2PL6430	
										↓	2PL6431	
										↓	2PL6432	
										↓	2PL6433	
										↓	2PL6434	
										↓	2PL6435	
										Y	1/0	2PL4702
										↓	2PL4703	
										↓	2PL4704	
										↓	2PL4705	
										↓	2PL4706	
										↓	2PL4707	
										Y	2	2PL4710
										↓	2PL4711	
										↓	2PL4712	
	↓	2PL4713										
	↓	2PL4714										
	↓	2PL4715										



182 of 200  
183 of 201  
184 of 202  
185 of 203  
186 of 204  
187 of 205  
188 of 206  
189 of 207  
190 of 208  
191 of 209  
192 of 210

UBN EEB-MS-TI15-0011 R0

Population of Non-IE Power Circuits Located in Category 1 Structures

Prepared knajmuder Date 1/22/90 Checked R.H. Buchart Date 1/26/90  
R.H. Buchart 1/10/90 knajmuder 1/25/90

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
2-MCC-209-A											
17D	2-FCV-3-253	LO50	2	N 210		T49	←	N/A	→	10	2V4649
110C	2-FCV-3-250	A025Z	3	Y125		T42	←	N/A	→	10	2V4640
113E	2-FCV-3-251	A025	3	Y125		T42	←	N/A	→	10	2V4643
2-MCC-209-C											
13F2	2-DXF-264-1	B100	N/A	Y100	N/A	N/A	←	N/A	→	2	2PL6660
2-MCC-210-A											
12D	2-FCV-3-252	A025	3	Y125	1	T42	←	N/A	→	10	2V4646
12F2	2-PO-210-A4	B050	N/A	Y50	N/A	N/A	←	N/A	→	8	2PL1195
	45W753-213 R12,8										
	45W753-6,R10										
	45W757-2 R16-10										

SL-F647 04/84

Form GO-3.08.1 Rev. 2

IBN EEB-MS-TI15-0011 R0  
Circulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchart Date 1/22/90 Checked Krajmudar Date 1/26/90  
Krajmudar 1/16/90 Deon Kelley 1/25/90  
Bates 2/5/90 R. Supkar 2-5-90

2-MCC-213-A1

COMPT NO	SERVICE	BKR	SET	TRIP	STR	DL	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		TYPE	POS	RATING	SIZE	CAT#	MFR	MODEL	RATING		
		EF3-		(A)		G30					
16A	2-PENT-293-32 (2-MTR-31-265)	A010	3	Y45	1	T34	SHAW-MUT	TRS-30	Y30 N	10 12	2PL6300 2PL6301
16B	2-PENT-293-24 (2-MTR-77-129)	A010	L0	Y27	1	T27	"	"	Y30 N	10 12	2PL6268 2PL6269
16F1	0-XSW-252-1	B020	N/A	Y20	N/A	N/A	N/A	N/A	N/A	10	2PL6040
16F2	2-TB-31-303/2	B020	N/A	Y20	N/A	N/A	N/A	N/A	N/A	10	2PL6289
17A	0-JB-292-2051 (2-HTR-62-228/A)	B030	N/A	Y30 Y	N/A	N/A	N/A	N/A	N/A	8 12 12	2PL6208 2PL6209 2PL6210
17E	2-PENT-293-32 (2-P0-213-A1/4) (2-P0-213-A1/5)	B100	N/A	Y100	N/A	N/A	SHAW-MUT	CPGA197 #2	N/A	2 2	2PL6100 2PL6094
18C	2-MTR-31-303/1	A010	3	Y45	1	T32	N/A	N/A	N/A	12	2PL6281
18F1	0-XSW-253-1	B020	N/A	Y20	N/A	N/A	N/A	N/A	N/A	10	PL888
18F2	2-JB-293-2860 (2-P0-213-A1/6-10)	B100	N/A	Y100	N/A	N/A	N/A	N/A	N/A	2	2PL6093

SL-F647 04/84

Form GO-3.08.1 Rev. 2

BN EEB-MS-TI15-0011 RO  
 Distribution of Non-IE Power Circuits Located in Category 1 Structures  
 Prepared Kinghunder Date 1/22/90 Checked R.H. Buchert Date 1/26/90  
Kinghunder 1/16/90 Scott Kelley 1/25/90

2-MCC-213-A2

COMPT NO	SERVICE	BKR	SET	TRIP	STR	OL HTR	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		TYPE	POS	RATING	SIZE	CAT#	MFR	MODEL	RATING		
		EF3-		(A)		G30					
4A	2-FCV-3-191	A010	3	Y45	1	T31	N/A	N/A	N/A	12	2V3260
4B	2-FCV-3-192	A010	3	Y45	1	T31	N/A	N/A	N/A	12x2	2V3280
13B	0-FCV-67-360	A010	L0	Y27	1	T28	N/A	N/A	N/A	12	2V3230

UBN EEB-MS-TI15-0011 R0

Page 157 of H72

Population of Non-IE Power Circuits Located in Category 1 Structures

Prepared R. H. Buchant Date 1/22/90 Checked Kinghudas Date 1/26/90  
Kinghudas 1/16/90 Scott Kelley 1/25/90  
LLBates 2/5/90 R. Supkar 2-5-90

2-MCC-213-B1

COMPT NO	SERVICE	BKR	SET	TRIP	STR	OL HTR	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		TYPE	POS	RATING	SIZE	CAT#	MFR	MODEL	RATING		
3F1	0-XSW-252-2	3020	N/A	Y 20	N/A	N/A	N/A	N/A	N/A	10	2PL6045
16A	2-PENT-293-35 (2-MTR-31-266)	A010	3	Y 45 Y	1	T34	SHAW- MUT	TAS-30	Y 30 N	10 12	2PL6310 2PL6311
16E	2-PENT-293-47 (2-PO-213-31/1-5)	B100	N/A	Y 100	N/A	N/A	"	CP6A-51 #2 -197	N/A 2/15/90 R68 2/15/90	2X2 2	2PL6085 2PL6086
17A	0-JB-292-2048 (2-MTR-62-226)	3040	N/A	Y 40 N	2	N/A	N/A	N/A	N/A	8x2 12 12	2PL6214 2PL6215 2PL6216
17E	2-PENT-293-35 (2-PO-213-31/6-10)	B100	N/A	Y 100	N/A	N/A	SHAW- MUT	CP6A-97 #2	N/A 2/15/90 R68 2/15/90	2 2	2PL6075 2PL6076
17F1	0-XSW-253-2	3020	N/A	Y 20	N/A	N/A	N/A	N/A	N/A	10	PL894
17F2	2-TB-31-324/2	3020	N/A	Y 20	N/A	N/A	N/A	N/A	N/A	10	2PL6291
18C	2-MTR-31-324/1	A010	3	Y 45	1	T32	N/A	N/A	N/A	10	2PL6285

ORN EEB-MS-TI15-0011 RO  
 Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared King Nuclear Date 1/22/90 Checked R.A. Buckart Date 1/26/90  
King Nuclear 1/16/90 Scott Welley 1/25/90

2-MCC-213-B2

COMPT NO	SERVICE	BKR	SET	TRIP	STR	DL HTR	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		TYPE	POS	RATING	SIZE	CAT#	MFR	MODEL	RATING		
		EF3-		(A)		G30					
4A	2-FCV-3-193	A010	3	45	1	T31	N/A	N/A	N/A	12x2	2V3290
4B	2-FCV-3-194	A010	3	45	1	T31	N/A	N/A	N/A	12	2V3270
5A	0-FCV-26-15	A003	LO	7	1	T6	N/A	N/A	N/A	12	2V3360
5B	0-FCV-26-16	A003	LO	7	1	T6	N/A	N/A	N/A	12	2V3370

WBN EEB-MS-TI15-0011 R0

Population of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchart Date 1/22/90 Checked knayh uclaw Date 1/26/90  
knayh uclaw 1/16/90 Scott Kelley 1/25/90

2-MCC-214-A1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
2D	2-MTR-81-3	H050	2	Y 400	3	T51	N/A	N/A	N/A	6	2PL3221
2F1	0-DXF-234-A2 SIS	B020	N/A	Y 20	N/A	N/A	SHAW-MUT	HFCP	N 30	10	2PL3590
2F2	2-DXF-242-1	B070	N/A	Y 70	N/A	N/A	"	"	N 100	4	2PL3596
3F1	2-RE-90-119	B020	N/A	Y 20	N/A	N/A	"	"	N 30	10	2PL3589
10F1	0-TB-40-3	B020	N/A	Y 20	N/A	N/A	"	"	N 30	10	2PL3720
12F2	0-DXF-227-1	B050	N/A	Y 50	N/A	N/A	"	"	Y 50	6	2PL3713
7D	0-DXF-234-A1 CVC5	FJB- B125	N/A	Y 125	N/A	N/A	N/A	N/A	N/A	1/0	2PL3580
4F2	0-DXF-234-A4	EF3- B020	N/A	Y 20	N/A	N/A	SHAW-MUT	HFCP	N 20	10	2PL3017
12E1	2-PNL-90-L398	B020Z	N/A	Y 20	N/A	N/A	"	"	N 30	10	2PL3610
13A	2-MTR-84-16	A005	3	Y 22	1	T25	N/A	N/A	N/A	12	2PL2940
13C	2-MTR-65-77	A005	HI	Y 41	1	T31	N/A	N/A	N/A	12	2PL3645

SUB 2/5/90  
 189 of 201  
 188 of 200  
 3-7-90

MBN EEB-MS-TI15-0011 R0  
 Installation of Non-IE Power Circuits Located in Category 1 Structures  
 Prepared Kojimudat Date 1/22/90 Checked R.H. Buchart Date 1/26/90  
Z.H. Buchart 1/10/90 Scott Kelley 1/25/90

2-MCC-214-B1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
2D	2-MTR-81-7	NO50	2	Y400	3	T51	N/A	N/A	N/A	6	2PL3228
3F2	0-DXF-234-B2 SIS	B020	N/A	Y20	N/A	N/A	SHAW-MUT	DISA	*N30	10	2PL3375
2F1	0-TB-40-66	B020	N/A	Y20	N/A	N/A	"	"	N30	10	2PL3730
9F1	2-PNL-55-L237	B020	N/A	Y20	N/A	N/A	SHAW-MUT	DISA	*N30	10	2PL2972
12A	2-MTR-30-181	A010	3	Y45	1	T32	N/A	N/A	N/A	10	2PL3021
7D	0-DXF-234-B1 CVCS	FJ3-B125	HI	Y1600	N/A	N/A	N/A	N/A	N/A	2/0	2PL3744
12F1	2-RE-90-99	EF3-B020	N/A	Y20	N/A	N/A	SHAW-MUT	DISA	*N30	10	2PL3790
13A	2-MTR-84-21	A005	3	Y22	1	T25	N/A	N/A	N/A	12	2PL2948
12F2	0-DXF-227-3	B070	N/A	Y70	N/A	N/A	SHAW-MUT	DISA	*N100	4	2PL3719
13C	2-MTR-65-74	A005	HI	Y41	1	T31	N/A	N/A	N/A	12	2PL3660

Shawmut DISA and HECP are the same fuse.

WBN EEB-MS-TI15-0011 R0

Page H61 of H72

Abulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared King nuclear Date 1/22/90 Checked R.H. Buchert Date 1/26/90  
King nuclear 1/16/96 Drew Kelley 1/25/90

2-MCC-214-A2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
		EF3-		(A)		G30					
2DI	2-HTR-30-A1A	B020	N/A	Y 20	N/A	N/A	SHAW-MUT	DISA030	N 30	10	2PL3280
6DI	0-HTR-30-AB1	B020	N/A	Y 20	N/A	N/A	"	"	N 30	10	2PL2815
2E1	2-HTR-30-B1A	B020	N/A	Y 20	N/A	N/A	"	"	N 30	10	2PL3284
6F1	0-HTR-31-339	B020	N/A	Y 20	N/A	N/A	"	"	N 30	10	2PL3833
7DI	0-HTR-30-AB2	B020	N/A	Y 20	N/A	N/A	"	"	N 30	10	2PL2819
3A	2-MTR-30-25	A10	3	Y 45	1	T31	N/A	N/A	N/A	12x2	2PL2906
3DI	2-HTR-30-ACRD	B020	N/A	Y 20	N/A	N/A	SHAW-MUT	DISA030	N 30	10	2PL3266
3E1	2-HTR-30-C1A	B020	N/A	Y 20	N/A	N/A	"	"	N 30	10	2PL3288
3E2	2-HTR-31-D1A	B050	N/A	Y 50	N/A	N/A	"	DISA050	Y 50	6x2	2PL3510
3F1	0-HTR-31-91	B020	N/A	Y 20	N/A	N/A	SHAW-MUT	DISA030	N 30	10	2PL2800
3F2	2-HTR-30-1A1	B020	N/A	Y 20	N/A	N/A	"	"	N 30	10	2PL3365
4A	2-MTR-30-67	A005	4	Y 29	1	T29	N/A	N/A	N/A	12	2PL3621
4E1	2-HTR-30-BCRD	B020	N/A	Y 20	N/A	N/A	SHAW-MUT	DISA030	N 30	10x2	2PL3264

Form GO-3.08.1 Rev. 2 SL-F647 04/84



WBN EEB-MS-TI15-0011 R0

Tabulation of Non-IE Power Circuits Located in Category I Structures

Prepared Kingman Date 1/22/90 Checked Roy H. Gubert Date 1/26/90  
Kingman 1/16/90 Dora Helley 1/25/90

2-MCC-214-A2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
4F1	2-HTR-30-CCRD	B020	N/A	Y20	N/A	N/A	SHAW-MUT	DISA030	N30	10X2	2PL3268
5A	2-MTR-30-301	A010	3	Y45	1	T34	N/A	N/A	N/A	12	2PL3435
5E1	0-HTR-31-71	B030	N/A	Y30	N/A	N/A	SHAW-MUT	DISA030	Y30	8	2PL3691
5F1	2-HTR-30-XMIA	B020	N/A	Y20	N/A	N/A	"	"	N30	10	2PL3370
5F2	2-HTR-30-ABI	B020	N/A	Y20	N/A	N/A	"	"	N30	10	2PL3314
6E1	2-HTR-30-SMS	B030	N/A	Y30	N/A	N/A	"	"	Y30	8	2PL2811
6E2	2-HTR-30-NMI	B050	N/A	Y50	N/A	N/A	"	DISA050	Y50	6	2PL2806
6F2	0-HTR-30-KM3	B020	N/A	Y20	N/A	N/A	"	DISA030	N30	10	2PL3320
7D2	0-HTR-30-DFH	B040	N/A	Y40	N/A	N/A	"	DISA050	Y50	6	2PL3335
7E1	2-HTR-30-UIA	B020	N/A	Y20	N/A	N/A	"	DISA030	N30	10	2PL2813
7E2	0-HTR-30-EFH	B040	N/A	Y40	N/A	N/A	"	DISA050	Y50	6	2PL3330
7F2	0-HTR-30-FFH	B040	N/A	Y40	N/A	N/A	"	"	Y50	6	2PL3340
8A	2-MTR-30-CRD	FJ3-B12SL	HI	Y1600	N/A	N/A	N/A	N/A	N/A	2/0	2PL3692
8B	2-HTR-1-CBS	FJ3-B12S	HI	Y1600	N/A	N/A	N/A	N/A	N/A	4/0	2PL3680

MBN EEB-MS-TI15-0011 R0

Installation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchert Date 1/22/90 Checked R.H. Buchert Date 1/27/90  
R.H. Buchert 1/16/90 R.H. Buchert 1/25/90

2-MCC-214-B2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		EF3-		(A)		G30	MFR	MODEL	RATING		
2B	0-MTR-30-27	A005	4	Y 29	1	T27	N/A	N/A	N/A	12	2PL3812
2E1	2-HTR-30-AIB	B020	N/A	Y 20	N/A	N/A	SHAW-MUT	DISA030	N 30	10	2PL3676
2E2	0-HTR-30-KFA	B040	N/A	Y 40	N/A	N/A	"	DISA050	Y 50	6	2PL3400
2F1	2-HTR-30-BIB	B020	N/A	Y 20	N/A	N/A	"	DISA030	N 30	10	2PL3898
2F2	2-HTR-31-BRB	B050	N/A	Y 50	N/A	N/A	"	DISA050	Y 50	6	2PL3890
3B	2-MTR-30-285	A005	4	Y 29	1	T29	N/A	N/A	N/A	12	2PL3626
3F2	0-HTR-31-93	B040	N/A	Y 40	N/A	N/A	SHAW-MUT	DISA050	Y 50	6	2PL3851
3E1	2-HTR-30-CIB	B020	N/A	Y 20	N/A	N/A	"	DISA030	N 30	10	2PL3895
3E2	0-HTR-30-LFA	B040	N/A	Y 40	N/A	N/A	"	DISA050	Y 50	6	2PL3405
3F1	2-HTR-30-PRX	B020	N/A	Y 20	N/A	N/A	"	DISA030	N 30	10	2PL3395
4B	2-MTR-30-302	A010	3	Y 45	1	T32	N/A	N/A	N/A	12	2PL3438
4E1	0-HTR-31-85	B020	N/A	Y 20	N/A	N/A	SHAW-MUT	DISA030	N 30	10	2PL2809
4E2	0-HTR-30-PFA	B040	N/A	Y 40	N/A	N/A	"	DISA050	Y 50	6	2PL3415
4F1	2-HTR-30-SBU	B020	N/A	Y 20	N/A	N/A	"	DISA030	N 30	10	2PL3425
4F2	2-HTR-30-U113	B020	N/A	Y 20	N/A	N/A	"	"	N 30	10	2PL2975
5E1	2-HTR-31-89	B020	N/A	Y 20	N/A	N/A	SHAW-MUT	DISA030	N 30	10	2PL2825

WBN EEB-MS-TI15-0011 R0

Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R. H. Buchert Date 1/22/90 Checked R. H. Buchert Date 1/27/90  
kmj/haclar 1/16/90 R. H. Buchert 1/20/90

2-MCC-214-B2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		EF3-		(A)		G30	MFR	MODEL	RATING		
5F1	0-HTR-30-RM4	B020	N/A	Y 20	N/A	N/A	SHAW-MUT	DISA030	N 30	10	2PL3385
6B	2-MTR-30-26	A010	3	Y 45	1	T33	N/A	N/A	N/A	12	2PL2913
6E1	2-HTR-30-AB7	B020	N/A	Y 20	N/A	N/A	SHAW-MUT	DISA030	N 30	10	2PL3381
6F1	2-HTR-30-T1B	B020	N/A	Y 20	N/A	N/A	"	"	N 30	10	2PL3430
5F2	0-HTR-30-U1	B020	N/A	Y 20	N/A	N/A	SHAW-MUT	DISA030	N 30	10	2PL2817
7F1	2-HTR-30-NM2	B050	N/A	Y 50	N/A	N/A	"	DISA050	Y 50	6	2PL3421
7E1	0-HTR-31-99	B020	N/A	Y 20	N/A	N/A	"	DISA030	N 30	10	2PL3840
8F2	2-JB-292-19	B100	N/A	Y 100	N/A	N/A	"	DISAB100	Y 100	2	2PL2785
9A	2-MTR-30-CRB	B125	L0	Y 750	N/A	N/A	N/A	N/A	N/A	2/0	2PL3671
8E2	0-HTR-30-A1A	B020	N/A	Y 20	N/A	N/A	SHAW-MUT	DISA030	N 30	10	2PL3390

SL-F647 04/84  
Form GO-3.08.1 Rev. 2

7-7-91

WRN EEB-MS-TI15-0011 R0

Page H65 of H72

Installation of Non-IE Power Circuits Located in Category 1 Structures

Prepared kmj/hudw Date 1/22/90 Checked R.H. Buchert Date 1/26/90  
R.H. Buchert 1/17/90 kmj/hudw 1/25/90

2-MCC - 215 - A1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		EF3-		(A)		G30	MFR	MODEL	RATING		
5A	2-MTR-82-241	A0252	L0	175	1	T38	N/A	N/A	N/A	12	PL2205
5F1	0-HTR-30-480	B020	N/A	120	N/A	N/A	N/A	N/A	N/A	10	PL2334
5F2	2-JB-296-257 (P.O.'S)	B100	N/A	100	N/A	N/A	N/A	N/A	N/A	2	PL2543
6A	2-SW-30-464	A005	2	18	1	T26	N/A	N/A	N/A	12	PL2242

ON EEB-MS-TI15-0011 R3

Page H66 of H72

Compilation of Non-IE Power Circuits Located in Category 1 Structures

Prepared Krajmudaw Date 1/22/90 Checked R.H. Buchart Date 1/26/90  
R.H. Buchart 1/17/90 Krajmudaw 1/25/90

2-MCC-215-B1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							EF3-	(A)	G30		
5A	2-MTR-82-271	A025Z	LO	Y75	1	T38	N/A	N/A	N/A	12	PL2225
5F1	0-HTR-30-482	B020	N/A	Y20	N/A	N/A	N/A	N/A	N/A	10	PL2328
6A	2-SW-30-466	A005	2	Y18	1	T26	N/A	N/A	N/A	12	PL2255
5F2	2-JB-296-259 (P.O.'s)	B100	N/A	Y100	N/A	N/A	N/A	N/A	N/A	2	PL2556

21511-  
195 of 200  
Tom B  
3-2-91

WBN EEB-MS-T115-0011 R0

Population of Non-IE Power Circuits Located in Category 1 Structures

Prepared kmj/ndw Date 1/24/90 Checked R.H. Buchert Date 1/24/90  
R.H. Buchert 1/17/90 kmj/ndw 1/25/90

2-MCC-215-A2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
3E1	2-HTR-30-488	B020	N/A	Y 20	N/A	N/A	N/A	N/A	N/A	10	PL2413
3F1	2-HTR-30-475	B030	N/A	Y 30	N/A	N/A	N/A	N/A	N/A	8	PL2286
3F2	2-HTR-30-476	B030	N/A	Y 30	N/A	N/A	N/A	N/A	N/A	8	PL2292
5A	2-MTR-82-240	A025E	L0	Y 75	1	T38	N/A	N/A	N/A	12	PL2210
6D	2-TB-82-A/1-A	B020	N/A	Y 20	1	N/A	N/A	N/A	N/A	12	PL2703

BN EEB-MS-TI15-0011 R0

Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared Kingmular Date 1/22/90 Checked R.A. Buckert Date 1/26/90  
R.A. Buckert 1/17/90 Kingmular 1/25/90

2-MCC-215-B2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
		EF3-		(A)		G30					
3E1	2-HTR-30-490	B020	N/A	Y20	N/A	N/A	N/A	N/A	N/A	10	PL2414
3F1	2-HTR-30-477	B030	N/A	Y30	N/A	N/A	N/A	N/A	N/A	8	PL2298
3F2	2-HTR-30-478	B030	N/A	Y30	N/A	N/A	N/A	N/A	N/A	8	PL2775
5A	2-MTR-82-270	A025	L0	Y75	1	T38	N/A	N/A	N/A	12	PL2230
6D	2-TB-82-B1-B	B020	N/A	Y20	1	N/A	N/A	N/A	N/A	12	PL2709
4B	0-MTR-18-913	A025	3	Y25	1	T24	N/A	N/A	N/A	10	PL2460

WBN EEB-MS-TI15-0011 R0

Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Page H69 of H72

Prepared R. H. Buckhart Date 1/22/90 Checked for [signature] Date 1/26/96  
[signature] 1-25-90  
[signature] 2-5-90

2-MCC-232-A  
1/16/90  
2/15/90

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
2A	2-PENT-293-24	A010	3	Y 45	1	T33	SHAW-MUT	TRS-30	Y 30	10 12	2PL653 2PL654
3A	2-PENT-293-35 FLUX D	B020	N/A	Y 20	N/A	N/A	"	"	Y 30	10x2 10	2PL295 2PL296
3B	2-PENT-293-35 FLUX E	B020	N/A	Y 20	N/A	N/A	"	DISA030	N 30	10x2 10	2PL300 2PL301
3C	2-PENT-293-35 FLUX F	B020	N/A	Y 20	N/A	N/A	"	DISA030	N 30	10x2 10	2PL305 2PL306
4D	2-MTR-61-51	L050	4	N 330	2	T51	N/A	N/A	N/A	8	2PL4320
4E	2-HTR-61-92	B050	N/A	Y 50	2	T51	N/A	N/A	N/A	6x2	2PL4300
6C	0-MTR-77-105	H050	L0	Y 320	2	T52	N/A	N/A	N/A	6x2	2PL5460
7B	2-PENT-293-32 RCP 1 HTR	A010	2	Y 36	1	T36	"	TRS-30	N 30	12 12	2PL370 2PL371
7D	2-PENT-293-32 RCP 1 LIFT	A025	4	Y 170	1	T44	"	"	Y 30	10 10	2PL396 2PL397
7F2	2-JB-292-981 (1450V REC PT'S)	B100	N/A	Y 100	N/A	N/A	SHAW-MUT	DISAB100	Y 100	2	2PL258
8B	2-PENT-293-24 RCP 3 HTR	A010	2	Y 36	1	T36	"	TRS-30	N 30	12 12	2PL382 2PL383
8D	2-PENT-293-24 RCP 3 LIFT	A025	3	Y 125	1	T44	"	"	Y 30	10 10	2PL408 2PL409
8F2	2-PO-232-9	B100	N/A	Y 100	N/A	N/A	SHAW-MUT	DISAB100	Y 100	2	2PL240

Form GO-3.08.1 Rev. 2 SL-F647 04/84



EEB-MS-TI15-0011 R3  
 Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchart Date 1/22/90 Checked Ken of the Star Date 1/26/90  
Jim of the Star 2/15/90 Dean Kelley 1-25-90  
Ed Bates 2-5-90 R. S. Walker

2-MCC-232-A

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
9B	2-PENT-293-32 FAN A	A025	L0	Y 75 Y	1	T40	SHAW-MUT	TRS-30	Y 30 N	10 12	2PL520 2PL521
10B	2-PENT-293-24 FAN C	A025	2	Y 105 Y	1	T44	"	"	Y 30 N	10 12	2PL550 2PL551
10F	2-PENT-293-32 STUD	B020	N/A	Y 20 Y	N/A	N/A	"	"	Y 30 N	10 12	2PL270 2PL271
11D	2-PENT-293-24 RCDT A	B030	N/A	Y 30	2	T47	"	TRS-60	N 60	10 10	2PL485 2PL486
11F	2-PENT-293-32 HTR A	B020	N/A	Y 20	N/A	N/A	"	DIS A030	N 30	10 10	2PL336 2PL337
12F	2-PENT-293-32 HTR A	B020	N/A	Y 20	N/A	N/A	"	TRS-30	Y 30	10 10	2PL5440 2PL5441
13A	2-PENT-293-5	B040	N/A	Y 40	N/A	N/A	"	TRS-40	Y 40	6 6	2PL621 2PL622
13D	2-PENT-293-5 (AHU)	FJ3-B175	HI	Y 1600 Y	N/A	N/A	"	CPGA-14 4/0	Y 4/0 Y 4/0	4/0 2/15/90 2/10	2PL820 2PL821 *
14B	2-PENT-293-5	A010	2	Y 36	1	T29	"	TRS-30	N 30	12 12	2PL587 2PL588
14D	2-PENT-293-5 (AHU)	FJ3-B150	HI	Y 1600 Y	N/A	N/A	"	CPGA-14 4/0	Y 4/0 Y 4/0	4/0 2/15/90 2/10	2PL861 2PL862 2PL867 *
15A	2-PENT-293-32	B070	N/A	Y 70	N/A	N/A	"	DISAB100	N 100	4 4	2PL425 2PL426
15D	2-MTR-30-1	A100	3	Y 760	3	T56	N/A	N/A	N/A	2	2PL777
16A	2-PENT-293-5	B070	N/A	Y 70	N/A	N/A	SHAW-MUT	DISAB100	N 100	4 4	2PL440 2PL441
16D	2-MTR-30-1E	A100	3	Y 760	3	T56	N/A	N/A	N/A	2	2PL764

\* 2PL821 → 2PL826(2/0) → 2PL831(2/0) → 2PL836(2/0) → 2PL841(2/0) → 2PL846(2/0)  
 → 2PL851(2/0) → 2PL856(2/0) → 2PL861(2/0) → 2PL866(2/0)  
 \*\* 2PL867 → 2PL872(2/0) → 2PL877(2/0) → 2PL882(2/0) → 2PL887(2/0) → 2PL892(2/0)  
 2/15/90

Form GO-3.08.1 Rev. 2 SL-F647 04/84

NBN EEB-MS-TI15-0011 R0  
 Installation of Non-IE Power Circuits Located in Category 1 Structures

Page H71 of H72

Prepared Kingman Date 1/22/90 Checked R.H. Guchert Date 1/26/90  
Kingman 1/16/90 Scott Kelley 1/25/90  
ELBate 2/5/90 R. Supkar 2-5-90

2-MCC-232-B

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING (A)	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
2A	2-PENT-293-47	A010	3	Y45	1	T33	SHAW-MUT	TRS-30	N30	12 10	2PL672 2PL673
3A	2-PENT-293-32	B020	N/A	Y20	N/A	N/A	"	DISA030	N30	10x2 10	2PL280 2PL281
3B	2-PENT-293-32	B020	N/A	Y20	N/A	N/A	"	"	N30	10x2 10	2PL285 2PL286
3C	2-PENT-293-32	B020	N/A	Y20	N/A	N/A	"	"	N30	10x2 10	2PL290 2PL291
5E	2-MTR-30-11	A003	4	Y16	1	T16	N/A	N/A	N/A	12	2PL794
6F2	2-JB-292-1868	B100	N/A	Y100	N/A	N/A	SHAW-MUT	DISAB100	Y100	2	2PL233
6C	2-MTR-61-61	L050	4	N330	2	T51	N/A	N/A	N/A	8	2PL4325
6D	2-HTR-61-93	B050	N/A	Y50	2	T51	N/A	N/A	N/A	6x2	2PL4310
6E	2-MTR-30-11E	A003	2	Y10	1	T16	N/A	N/A	N/A	12	2PL760
6F1	2-STR-40-2	B020	N/A	Y20	N/A	N/A	SHAW-MUT	DISA030	N30	10	2PL695
7B	2-PENT-293-35	A010	2	Y36	1	T36	"	TRS-30	N30	12 12	2PL376 2PL377
7D	2-PENT-293-35	A025	4	Y170 Y	1	T44	"	"	Y30 Y	8 10	2PL402 2PL403
8B	2-PENT-293-47	A010	2	Y36	1	T36	"	"	N30	12 12	2PL388 2PL389
8D	2-PENT-293-47	A025	4	Y170	1	T44	SHAW-MUT	TRS-30	Y30	10 10	2PL414 2PL415
8F2	2-JB-292-1866	B100	N/A	Y100	N/A	N/A	SHAW-MUT	DISAB100	Y100	2	2PL242
9B	2-PENT-293-35	A025	1	Y75 Y	1	T40	"	TRS-30	Y30 N	10 12	2PL531 2PL532

SL-F647 04/84

Form GO-3.08.1 Rev. 2

BN EEB-MS-TI15-0011 R0  
 Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared knagmudaw Date 1/22/90 Checked R.H. Gubert Date 1/26/90

knagmudaw 1/16/90  
ElBato 2/5/90  
Z-MCC-232-B  
Scott Kelley 1/25/90  
R. Supkar 2-5-90

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							EF3-	(A)	G30		
10B	2-PENT-293-47	A025	2	Y105 Y	1	T40	SHAQ-MUT	TRS-30	Y30 N	10 12	2PL561 2PL562
10F	2-PENT-293-11	B020	N/A	Y20	N/A	N/A	"	DISA030	N30	10 10	2PL707 2PL708
11D	2-PENT-293-11	B050	N/A	Y50 Y	2	T47	"	TRS-60	Y60 Y	4 8	2PL496 2PL497
11F	2-PENT-293-35	B020	N/A	Y20	N/A	N/A	"	DISA030	N30	10 10	2PL345 2PL346
12F	2-PENT-293-35	B020	N/A	Y20	N/A	N/A	"	DISA030	N30	10 10	2PL545D 2PL545I
13B	2-PENT-293-11	A010	2	Y36 Y	1	T29	"	TRS-30	Y30 N	10 12	2PL598 2PL599
13D	2-PENT-293-11 (AHU)	FJ3- B175	HI	Y1600 Y	N/A	N/A	"	CP6-C5 4/0	Y Y	4/0 2/0 2/0	2PL897 2PL975 2PL902 2PL902
13F	2-PENT-293-9	EF3- 3050	N/A	Y50	N/A	N/A	"	DISA050	Y50	6	2PL712
14B	2-PENT-293-11	A003	L0	Y7	1	N/A	"	TRS-30	N30	12	2PL1100
14D	2-PENT-293-11 (AHU)	FJ3- B150	HI	Y1600 Y	N/A	N/A	"	CP6-C5 4/0	Y Y	4/0X2 2/0 2/0	2PL937 2PL938 2PL943
14F	2-PENT-293-11	EF3- B040	N/A	Y40	N/A	N/A	"	DISA050	Y50	6 6	2PL704 2PL705
15A	2-PENT-293-35	B070	N/A	Y70	N/A	N/A	"	DISAB100	N100	4 4	2PL454 2PL455
15D	2-MTR-30-4	A100	3	Y760	3	T56	N/A	N/A	N/A	2	2PL785
16A	2-PENT-293-47	B070	N/A	Y70	N/A	N/A	SHAQ-MUT	DISAB100	N100	4 4	2PL468 2PL469
16D	2-MTR-30-4E	A100	3	Y760	3	T56	N/A	N/A	N/A	2x2	2PL768
<p>* * 2PL902 → 2PL907(2/0) → 2PL912(2/0) → 2PL917(2/0) → 2PL922(2/0) → 2PL927(2/0) → 2PL932(2/0)</p> <p>* 2PL943 → 2PL948(2/0) → 2PL953(2/0) → 2PL958(2/0) → 2PL963(2/0) → 2PL968(2/0)</p>											

Form GO-3.08.1 Rev. 2 SL-F647 04/84

ATTACHMENT NO. UVA2.1/2.4  
RESOLUTION OF UNVERIFIED ASSUMPTIONS 2.1 AND 2.4

DOCUMENTATION OF UNVERIFIED ASSUMPTION 2.1

The Computerized Cable Routing System (CCRS) capabilities generating this report have been subjected to (and successfully satisfied) verification and validation testing in accordance with NEP 3.8. The routines utilized to generate this report were identical to those in the verified CCRS Version 7 (See attached test results report).

**TENNESSEE VALLEY AUTHORITY**  
**WATTS BAR NUCLEAR PLANT CABLE ROUTING SYSTEM**  
**SOFTWARE VERIFICATION AND VALIDATION REPORT**

ID Y9894

REVISION 1

October 01, 1990

	Signature	Date
Sponsor Approval	<u><i>R. M. Shuman Jr.</i></u>	<u>10/15/90</u>
WBDP Supervisor Approval	<u><i>Alta F. Leryard</i></u>	<u>9/28/90</u>
Independent Review	<u><i>C. J. Dennis</i></u>	<u>9-28-90</u>
Prepared By	<u><i>D. J. Malin</i></u>	<u>9-28-90</u>

COMPUTER SOFTWARE REVISION/SIGNATURE LOG  
SOFTWARE VERIFICATION AND VALIDATION REPORT

---

Revision	Description of Revision
0	Initial Issue
1	Deleted all SVVR sections except SVVP Test Plan Results and index. Executed tests for Version 7 changes.

---

**WATTS BAR NUCLEAR PLANT CABLE ROUTING SYSTEM  
SOFTWARE VERIFICATION AND VALIDATION PLAN**

**Table of Contents**

Section	Page
1.0 SVVP TEST PLAN RESULTS. . . . .	1-1

# WATTS BAR NUCLEAR PLANT CABLE ROUTING SYSTEM

## SOFTWARE VERIFICATION AND VALIDATION REPORT

### 1.0 SVVP TEST PLAN RESULTS.

Version 7 of the *Watts Bar Cable Routing System* was tested in accordance with Revision 3 of the Software Verification and Validation Plan. See page 1-2 for an index of the required tests.

The results of test plan execution conform to the expected results described in the Software Verification and Validation Plan. The original test plan documents are in the Computer Systems Library.



WATTS BAR CABLE ROUTING SYSTEM  
TEST INDEX FOR VERSION 7

JOB NAME	SVVP SECTION	JOB NAME	SVVP SECTION
FILPRT1I	CLSTR1 INITIAL	WBHSTR01	10.14.2.3
ROUTER01	9.5.3.1	WBHSTR02	10.14.2.4
FILPRT1F	ROUTER01 FINAL	WBPULL01	10.15.2.3
FILPRT2I	CLSTR2 INITIAL	WBCONI01	10.16.2.3
ROUTER02	9.5.3.2	WBEQPT01	10.17.2.3
FILPRT2F	ROUTER02 FINAL	WBEQPT02	10.17.2.4
FILPRT3I	CLSTR3 INITIAL	WBEQPT03	10.17.2.5
ROUTER03	9.5.3.3	WBEQPT04	10.17.2.6
FILPRT3F	ROUTER03 FINAL	WBEQPT05	10.17.2.7
FILPRT4I	CLSTR4 INITIAL	WBEQPT06	10.17.2.8
ROUTER04	9.5.3.4	WBEQPT07	10.17.2.9
FILPRT4F	ROUTER04 FINAL	WBEQPT08	10.17.2.10
ROUTER05	9.5.3.5	WBEQPT09	10.17.2.11
FILPRT5I	CLSTR5 INITIAL	WBEQPT10	10.17.2.12
WBCABL01	10.1.2.3	WBEQPT11	10.17.2.13
WBCABL27	10.1.2.29	WBEQPT12	10.17.2.14
WBCABL28	10.1.2.30	WBEQPT13	10.17.2.15
WBNTWK01	10.2.2.3	WBEQLD01	10.18.2.3
WBCTYP01	10.3.2.3	WBEQLD02	10.18.2.4
WBCOND01	10.4.2.3	WBTOGE01	10.19.2.3
WBCOND29	10.4.2.31	WBTOGE02	10.19.2.4
WBCOND30	10.4.2.32	WBTOGE03	10.19.2.5
WBLOAD01	10.5.2.3	FILPRT5F	BATCH TEST FINAL
WBLOAD02	10.5.2.4	FILPRT6I	CLSTR6 INITIAL
WBCOLD01	10.6.2.3	FILPRT6F	ONLINE TEST FINAL
WBCOLD02	10.6.2.4	WBSAVE01	11.2.2.3
WBR Siz01	10.7.2.3	WBRSTR01	11.3.2.3
WBTOGM01	10.8.2.3	RLODPRTI	14.1.2.2
WBCTOG01	10.9.2.3	TESTCNCB	14.1.2.3
WBTOGN01	10.10.2.3	TESTSGCB	14.1.2.3
WBTOGN02	10.10.2.4	TESTEQPC	14.1.2.3
WBTOGC01	10.11.2.3	TESTEQCN	14.1.2.3
WBTOGR01	10.12.2.3	HICOND	14.1.2.3
WBRLES01	10.13.2.3	HINTWK	14.1.2.3
		RLODCONC	14.1.2.4
		RLODCOND	14.1.2.5
		RLODSEGC	14.1.2.6
		RLODNTWK	14.1.2.7
		RLODCTYP	14.1.2.8
		RLODEQPC	14.1.2.9
		RLODEQCN	14.1.2.10
		RLODEQPT	14.1.2.11
		RLODPRTF	14.1.2.2

ATTACHMENT UVA2.1/2.4  
CALCULATION WBN-EEB-MS-T115-0011, REV. 10

Prepared: M.W. Riehan Date: 12-19-90 Checked: W.D. Meyer Date: 12-19-90

I. Objective: Resolution of unverified assumption 2.4.

Identify all voltage level 4 or 5 cables (routed in conduit) which pass from the Turbine Building into a seismic Category I structure and then back into the Turbine Building. Once a cable is identified as entering a Category I structure, its entire route (including cable trays) must be evaluated to determine if it reenters the Turbine Building. For the review of cables routed in trays only, see pages 9 thru 13 of this attachment.

II. Methodology:

The conduit drawings for the Turbine and Control Buildings were reviewed to identify all conduits which pass from the Turbine Building to either the Control or Auxiliary Buildings. The conduit drawings which pertain to the areas of interest are identified in Section IV.

DCDTS was reviewed for outstanding changes to the conduit drawings which could impact this effort. Eighty-three DCNS and three ECN modification packages were reviewed which had outstanding changes posted against the above identified conduit drawings. As a result of this review, voltage level 4 conduits 1PLC3881, 2PLC3880, 1PLC3882, 2PLC3879, and MC694 were identified and added to the list for analysis.

The conduits identified by the above steps were then sorted by voltage level and all voltage level 4 and 5 (power) conduits were listed (see attached). Load reports were then obtained from the Computer Cable Routing System (CCRS) to identify the cables impacted. Each cables route (including cable tray) was identified in the CCRS and traced to determine if the cable passed back into the Turbine Building. Spare and Abandoned cables were excluded from this analysis since they are not energized cables.

III. Results:

No cables were found which were routed across this boundary more than one time.

Attached are the conduit load reports for the voltage level 4 conduits identified. No voltage level 5 (6900V) conduits were identified. These load reports contain the list of cables whose individual routings were evaluated to determine applicability to the above condition.

ATTACHMENT UVA2.1/2.4  
CALCULATION WBN-EEB-MS-T115-0011, REV. 10

Prepared: M. W. Riehan Date: 12-19-90 Checked: W. O. Myers Date: 12-19-90

IV. References:

Following is the list of drawings that contain plans and details which pertain to the areas of interest of this analysis. Both the as-designed and as-constructed revision levels indicated were reviewed.

45W802- 3, RC & R16	45W810- 1, RE & R22
45W802- 6, RF & R32	45W810- 2, RD & R25
45W802- 9, RB & R10	45W810- 3, RC & R27
45W802-12, RD & R29	45W810- 4, RE & R38
45W802-19, RC & R02	45W810- 5, RB & R10
45W802-20, RE & R04	45W810- 6, RD & R08
	45W810- 7, RE & R09
45W804- 3, RC & R22	45W812- 1, RE & R31
45W804- 6, RG & R31	45W812- 2, RF & R34
45W804- 9, RD & R31	45W812- 3, RC & R15
45W804-12, RE & R30	45W812- 4, RB & R26
45W804-22, RB & R05	45W812- 6, RC & R27
45W806- 3, RB & R13	45W812- 7, RB & R16
45W806- 6, RC & R18	45W812- 8, RD & R17
45W806- 7, RC & R08	45W812- 9, RG & R07
45W806- 8, RC & R12	
45W808- 1, RB & R16	45W814- 1, RC & R30
	45W814- 2, RE & R32
	45W814- 3, RE & R24
	45W814- 5, RB & R17
	45W814- 6, RC & R24
	45W814- 7, RD & R20
	45W814- 8, RA & R17
	45W814- 9, RC & R18
	45W814-10, RD & R28
	45W814-11, RF & R27
	45W814-12, RB & R29
	45W814-13, RC & R30
	45W814-15, RE & R07
	45W814-16, RE & R04
	45W816- 1, RF & R36
	45W816- 2, RD & R40
	45W816- 5, RC & R22
	45W816- 7, RF & R13
	45W816- 8, RF & R10
	45W816-10, RG & R09
	45W816-12, RD & R08
	45W817, RC & R08
	45W818- 1, RC & R06
	45W818- 2, RB & R06

Page 1

INPUT DATA FOR RESOLUTION OF UNVERIFIED ASSUMPTION  
2.4 IN CALCULATION WBN-EEB-MS-TI15-0011 REV. 5-10

The 45N884 series of drawings were reviewed to identify non-safety related 480 V cable trays passing from the turbine building into adjacent seismic category I structures. Four tray sections were found on drawing 45N884-24. The cables contained in those tray sections appear on the attached loading reports.

The attached loading reports indicate one cable passes through the boundary walls in two locations 2PL3720. This cable does have one termination in the auxiliary building (at 2-MCC-214-A1) and has been addressed in calculation WBN EEB-MS-TI15-0011.

Prepared By: Wesley L. Lattin

Date: 10-30-90

Reviewed By: John Curtis

Date: 10-31-90

WATTS BAR NUCLEAR PLANT CABLE ROUTING SYSTEM  
TRAY SEGMENT LOADING SCREEN

ACTION CODE: Q (Q-QUERY, X-CANCEL)

CABLES ROUTED IN SEGMENT: 4 1392 2124

NO. CABLES: 23

ABN 752 1*	PL 4460 1*
L 534 1*	SP 153 1*
L 535 1*	2PL 3719 1*
L 542 1*	<u>2PL 3720 1*</u>
PL 1240 1*	2V 4640 1*
PL 1250 1*	2V 4643 1*
PL 1260 1*	2V 4646 1*
PL 1280 1*	2V 4649 1*
PL 1295 1*	
PL 1324 1*	
PL 1335 1*	
PL 2450 1*	
PL 2455 1*	
PL 2480 1*	
PL 4402 1*	

SEGMENT RETRIEVED -- TYPE NEW SEGMENT ID OR PRESS ENTER FOR NEXT  
ENTER TO PAGE, PF3 TO TOGGLE, ACTION CODE 'X' PLUS PF3 TO EXIT

IN 2

PAGE: 1

Walter D. Whittall  
PREPARED  
Rich Curtis  
REVIEWER

10-30-90  
DATE  
10/31/90  
DATE

WBN EES-MS-TTIS-0011, REV 1  
PAGE 10

WANNEN-MS-TIS-0011, REV.10  
PAGE 11

WATTS BAR NUCLEAR PLANT CABLE ROUTING SYSTEM  
TRAY SEGMENT LOADING SCREEN

ACTION CODE: Q (Q-QUERY, X-CANCEL)  
                  NV FNOD TNOD  
CABLES ROUTED IN SEGMENT: 4 1353 2070      NO. CABLES: 11

- PL 248 1\* ✓
- PL 370 1\* ✓
- PL 378 1\* ✓
- PL 3080 1\* ✓
- 1A 4665 1\* ✓
- 1PL 167 1\* ✓
- 1PL 3589 1\* ✓
- 1PL 3599 1\* ✓
- 1PL 5033 1\* ✓
- 1PL 5085 1\* ✓
- 1PL 5089 1\* ✓

SEGMENT RETRIEVED -- TYPE NEW SEGMENT ID OR PRESS ENTER FOR NEXT  
ENTER TO PAGE, PF3 TO TOGGLE, ACTION CODE 'X' PLUS PF3 TO EXIT

SC 2  
W. H. Walker  
PREPARED  
Rich Curtis  
PAGE: 1  
REVIEWER

10-30-90  
DATE  
10/31/90  
DATE

WATTS BAR NUCLEAR PLANT CABLE ROUTING SYSTEM  
TRAY SEGMENT LOADING SCREEN

SCN 2

Wesley A. Whallon  
PREPARED  
Rich Curtis  
REVIEWER

10-30-90  
DATE  
10/31/90  
DATE

ACTION CODE: Q (Q-QUERY, X-CANCEL)  
NV FNOD TNOD  
CABLES ROUTED IN SEGMENT: 4 1358 2119 NO. CABLES: 11

PAGE: 1

- B 90 1\*
- L 210 1\*
- PL 346 1\*
- PL 4401 1\*
- SP 155 1\*
- SP 577 1\*
- SP 578 1\*
- 1V 4640 1\*
- 1V 4643 1\*
- 1V 4646 1\*
- 1V 4649 1\*

SEGMENT RETRIEVED -- TYPE NEW SEGMENT ID OR PRESS ENTER FOR NEXT  
ENTER TO PAGE, PF3 TO TOGGLE, ACTION CODE 'X' PLUS PF3 TO EXIT

WABN EEB-M5-TI/5-0011, REV.10 PAGE 12

WATTS BAR NUCLEAR PLANT CABLE ROUTING SYSTEM  
TRAY SEGMENT LOADING SCREEN

SCREEN 2

ACTION CODE: Q (Q-QUERY, X-CANCEL)

NO. FNOD TR01

CABLES ROUTED IN SEGMENT: 4 1397 2121 NO. CABLES: 13

PAGE: 1

- L 681 1\* |
- PL 410 1\* |
- 1ABN 67 1\* |
- 1PL 160 1\* |
- 1PL 3790 1\* |
- 1PL 3900 1\* |
- 2PL 160 1\* |
- 2PL 167 1\* |
- 2PL 3589 1\* |
- 2PL 3713 1\* |
- 2PL 3720 1\*** |
- 2PL 3790 1\* |
- 2PL 3901 1\* |

SEGMENT RETRIEVED -- TYPE NEW SEGMENT ID OR PRESS ENTER FOR NEXT  
ENTER TO PAGE, PF3 TO TOGGLE, ACTION CODE 'X' PLUS PF3 TO EXIT

Wolfgang W. Walle  
PREPARED

Rich Curtis  
REVIEWER

10/31/90  
DATE

ATTACHMENT DYN 2-1/2.7  
WABN EEBB-MS-TI15-001, REV.  
PAGE 13



QA REPT CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	STA
B 1066	4	3.0 I	C	3	0.000	2.290	1.880	7.390	0.000	3.562	2		290	V

CABLES ROUTED IN CONDUIT:

2B	288	1*1	WDP	NC1:	2	CAB CSA:	.940	CAB WT:	1.781	TOTAL CSA:	1.880	TOTAL WT:	3.562
TOTALS											1.880	3.562	

PAGE 14  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TIIS-0011, REV. 10

QA REPO CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	WATTS BAR NUCLEAR PLANT CONDUIT R CSA LIMIT	CSA MAX	CS ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	PAGE 2	DATE 12/16/90 WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	U S
B 1067	4	3.0 I	C	3	0.000	2.290	1.880	7.390	0.000		3.562	2		290	V

CABLES ROUTED IN CONDUIT:

18	288	1*1	WDP	NC1: 2	CAB CSA:	.940	CAB WT: 1.781	TOTAL CSA:	1.880	TOTAL WT:	3.562
TOTALS									1.880	3.562	

PAGE 15  
ATTACHMENT NO. UVA 2.1/2.4  
WBN EEB-MS-TIIS-0011, REV. 10

QA REPT CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	PAGE WT/FT. LIMIT	3 WT/FT. ACCUM	DATE 12/16/90 NO. CAB	AMB TEMP	SYSTEM	STAT
B 1068	4	3.0 I	C	3	0.000	2.956	2.596	7.390	0.000	4.588	4		290	V

CABLES ROUTED IN CONDUIT:

B	120	1*1	WDN	NC1:	2	CAB CSA:	.649	CAB WT:	1.147	TOTAL CSA:	1.298	TOTAL WT:	2.294
2B	276	1*1	WDN	NC1:	2	CAB CSA:	.649	CAB WT:	1.147	TOTAL CSA:	1.298	TOTAL WT:	2.294
TOTALS										2.596		4.588	

PAGE 16  
 ATTACHMENT NO. UVA2.1/2.4  
 W8NEB-MS-TI/5-0011, REV.10

QA REP	WATTS BAR NUCLEAR PLANT CONDUIT R							PAGE	DATE 12/16/90					
CONDUIT	NV	CONDUIT	CON	CON	CSA	CSA	CSA	CONDUIT	WT/FT.	WT/FT.	NO.	AMB	SYSTEM	STAT
ID		SIZE	TYP	LENG	LIMIT	MAX	ACCUM	CSA INS	LIMIT	ACCUM	CAB	TEMP		
B 1069	4	3.0 I	C	3	0.000	2.956	2.596	7.390	0.000	4.588	4		290	V

CABLES ROUTED IN CONDUIT:

B	116	1*1	WDN	NC1: 2	CAB CSA: .649	CAB WT: 1.147	TOTAL CSA: 1.298	TOTAL WT: 2.294
1B	276	1*1	WDN	NC1: 2	CAB CSA: .649	CAB WT: 1.147	TOTAL CSA: 1.298	TOTAL WT: 2.294
TOTALS							2.596	4.588

PAGE 17  
ATTACHMENT NO. UVA 2.1/2.4  
WBN EEB-MS-TI/5-0011, REV. 10

WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE	5	DATE 12/16/90			
QA REPO CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CS ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	V ST	
B	1070	4	3.0 I	C	3	0.000	2.956	0.980	7.390	0.000	1.230	10	290	V	

CABLES ROUTED IN CONDUIT:

B	146	1*2	WDE	NC1: 2	CAB CSA: .098	CAB WT: 0.123	TOTAL CSA: .196	TOTAL WT: .246
1B	256	1*1	WDE	NC1: 2	CAB CSA: .098	CAB WT: 0.123	TOTAL CSA: .196	TOTAL WT: .246
1B	258	1*1	WDE	NC1: 2	CAB CSA: .098	CAB WT: 0.123	TOTAL CSA: .196	TOTAL WT: .246
2B	256	1*1	WDE	NC1: 2	CAB CSA: .098	CAB WT: 0.123	TOTAL CSA: .196	TOTAL WT: .246
2B	258	1*1	WDE	NC1: 2	CAB CSA: .098	CAB WT: 0.123	TOTAL CSA: .196	TOTAL WT: .246
TOTALS							.980	1.230

PAGE 18  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TIIS-0011, REV. 10

QA REP	WATTS BAR NUCLEAR PLANT CONDUIT R														PAGE	6	DATE 12/16/90
CONDUIT	NV	CONDUIT	CON	CON	CSA	CSA	CSA	CONDUIT	WT/FT.	WT/FT.	NO.	AMB	SYSTEM	VE			
ID		SIZE	TYP	LENG	LIMIT	MAX	ACCUM	CSA INS	LIMIT	ACCUM	CAB	TEMP		STAT			
B 1071	4	3.0 I	C	3	0.000	2.290	0.146	7.390	0.000	0.158	2		290	V			

CABLES ROUTED IN CONDUIT:

B	144	1*2	WDD	NC1: 2	CAB CSA:	.073	CAB WT: 0.079	TOTAL CSA:	.146	TOTAL WT:	.158	
TOTALS									-----	.146	-----	.158

PAGE 19  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TIIS-0011, REV 10

QA REP	CONDUIT	NV	CONDUIT	CON	CON	CSA	CSA	CSA	CONDUIT	WT/FT.	WT/FT.	NO.	AMB	SYSTEM	V
ID			SIZE	TYP	LENG	LIMIT	MAX	ACCUM	CSA INS	LIMIT	ACCUM	CAB	TEMP		STAT
B	1072	4	3.0 I	C	3	0.000	2.956	0.700	7.390	0.000	1.072	4		290	V

CABLES ROUTED IN CONDUIT:

2B	307	1*1	WDG	NC1:	2	CAB CSA:	.175	CAB WT:	0.268	TOTAL CSA:	.350	TOTAL WT:	.536
2B	318	1*1	WDG	NC1:	2	CAB CSA:	.175	CAB WT:	0.268	TOTAL CSA:	.350	TOTAL WT:	.536
TOTALS											.700	1.072	

PAGE 10  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TI/5-0011, REV. 10

QA REPT CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	U STAT
B 1073	4	3.0 I	C	3	0.000	3.916	0.000	7.390	0.000	0.000	0		290	U

CABLES ROUTED IN CONDUIT:

TOTALS

-----  
 .000  
 -----  
 .000

PAGE 21  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TIIS-0011, REV. 10



QA REPT CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	U STAT
B 1074	4	2.0 I	C	3	0.000	1.780	0.000	3.360	0.000	0.000	0		290	V

PAGE 9 DATE 12/16/90

CABLES ROUTED IN CONDUIT:

TOTALS

-----  
 .000  
 -----  
 .000

PAGE 22  
 ATTACHMENT NO. UVA 2.1/2.4  
 W8NEEB-MS-TIIS-0011, REV.10



QA REPORT	WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 11	DATE 12/16/90		
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	V STA
B 1076	4	2.0 I	C	3	0.000	1.780	0.000	3.360	0.000	0.000	0		290	V

CABLES ROUTED IN CONDUIT:

TOTALS

-----  
.000

-----  
.000

PAGE 24  
ATTACHMENT NO. UVA 2.1/2.4  
WBN EEB-MS-TIIS-0011, REV. 10

QA REF	WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 12		DATE 12/16/90			
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	U STA		
B 1077	3	2.0 I	C	3	0.000	1.041	0.150	3.360	0.000	0.186	2		290	V		

CABLES ROUTED IN CONDUIT:

B	149	1*2	WDD-1	NC1: 2	CAB CSA: .075	CAB WT: 0.093	TOTAL CSA: .150	TOTAL WT: .186
TOTALS							.150	.186

PAGE 25  
 ATTACHMENT NO. UVA2.1/2.4  
 WBN EEB-MS-TI/5-0011, REV. 10

WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 13		DATE 12/16/90		
QA REP CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	ST
B 1200	4	3.0 I	C	3	0.000	2.956	2.596	7.390	0.000	4.588	4		290	V

CABLES ROUTED IN CONDUIT:

B	119	1*1	WDN	NC1: 2	CAB CSA: .649	CAB WT: 1.147	TOTAL CSA: 1.298	TOTAL WT: 2.294
2B	275	1*1	WDN	NC1: 2	CAB CSA: .649	CAB WT: 1.147	TOTAL CSA: 1.298	TOTAL WT: 2.294
TOTALS							2.596	4.588

PAGE 26  
 ATTACHMENT NO. UVA2.1/2.4  
 WBN EEB-MS-TI/5-0011, REV.10

WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 14	DATE 12/16/90				
QA REPT CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CS ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	STAT	
B 1201	4	3.0 I	C	3	0.000	2.956	2.596	7.390	0.000	4.588	4		290	V	

CABLES ROUTED IN CONDUIT:

B	115	1*1	WDN	NC1: 2	CAB CSA: .649	CAB WT: 1.147	TOTAL CSA: 1.298	TOTAL WT: 2.294
1B	275	1*1	WDN	NC1: 2	CAB CSA: .649	CAB WT: 1.147	TOTAL CSA: 1.298	TOTAL WT: 2.294
TOTALS							2.596	4.588

PAGE 27  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TIIS-0011, REV. 10

QA REP CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	STAT
B 1202	4	3.0 I	C	3	0.000	2.290	1.880	7.390	0.000	3.562	2		290	V

CABLES ROUTED IN CONDUIT:

2B	287	1*1	WDP	NC1: 2	CAB CSA: .940	CAB WT: 1.781	TOTAL CSA: 1.880	TOTAL WT: 3.562
TOTALS							1.880	3.562

PAGE 28  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TI/5-0011, REV. 10

QA REPO CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE STAT
B 1203	4	3.0 I	C	3	0.000	2.290	1.880	7.390	0.000	3.562	2		290	V

PAGE 16 DATE 12/16/90

CABLES ROUTED IN CONDUIT:

1B	287	1*1	WDP	NC1: 2	CAB CSA: .940	CAB WT: 1.781	TOTAL CSA: 1.880	TOTAL WT: 3.562
TOTALS							1.880	3.562

PAGE 29  
 ATTACHMENT NO. UVA 2.1/2.4  
 W8NEB-MS-TI/5-0011, REV. 10



QA REPO	WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 17	DATE 12/16/90		
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE STAT
B	1204	4	3.0 I	C	3	0.000	2.290	0.896	7.390	0.000	1.600	2	290	V

CABLES ROUTED IN CONDUIT:

B	140	1*2	WDK	NC1:	2	CAB CSA:	.448	CAB WT:	0.800	TOTAL CSA:	.896	TOTAL WT:	1.600
TOTALS											.896	1.600	

PAGE 30  
 ATTACHMENT NO. UVA.2.1/2.4  
 WBN EEB-MS-TI/5-0011, REV.10

QA REPORT	WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 18	DATE 12/16/90			
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	V STA	
B 1205	4	3.0 I	C	3	0.000	2.956	0.700	7.390	0.000	1.072	4		290	U	

CABLES ROUTED IN CONDUIT:

1B	307	1*1	WDG	NC1:	2	CAB CSA:	.175	CAB WT:	0.268	TOTAL CSA:	.350	TOTAL WT:	.536
1B	318	1*1	WDG	NC1:	2	CAB CSA:	.175	CAB WT:	0.268	TOTAL CSA:	.350	TOTAL WT:	.536
TOTALS											.700	1.072	

PAGE 3 /  
 ATTACHMENT NO. UVA2.1/2.4  
 WBN EEB-MS-TI/5-0011, REV.10

B	1206	4	3.0 I	C	3	0.000	2.290	0.146	7.390	0.000	0.158	2	290	V
---	------	---	-------	---	---	-------	-------	-------	-------	-------	-------	---	-----	---

CABLES ROUTED IN CONDUIT:

B	143	1*2	WDD	NC1:	2	CAB CSA:	.073	CAB WT:	0.079	TOTAL CSA:	.146	TOTAL WT:	.158
TOTALS											.146	.158	

PAGE 3 2  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TI5-0011, REV. 10

QA REPT	WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 20	DATE 12/16/90			
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	V. STAT	
B 1207	4	3.0 I	C	3	0.000	2.956	0.980	7.390	0.000	1.230	10		290	V	

CABLES ROUTED IN CONDUIT:

B	147	1*2	WDE	NC1: 2	CAB CSA: .098	CAB WT: 0.123	TOTAL CSA: .196	TOTAL WT: .246
1B	255	1*1	WDE	NC1: 2	CAB CSA: .098	CAB WT: 0.123	TOTAL CSA: .196	TOTAL WT: .246
1B	257	1*1	WDE	NC1: 2	CAB CSA: .098	CAB WT: 0.123	TOTAL CSA: .196	TOTAL WT: .246
2B	255	1*1	WDE	NC1: 2	CAB CSA: .098	CAB WT: 0.123	TOTAL CSA: .196	TOTAL WT: .246
2B	257	1*1	WDE	NC1: 2	CAB CSA: .098	CAB WT: 0.123	TOTAL CSA: .196	TOTAL WT: .246
TOTALS							.980	1.230

PAGE 3  
 ATTACHMENT NO. UVA.2.1/2.4  
 WBN EEB-MS-TI/5-0011, REV.10

QA REPO CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE STAT
B 1208	4	2.0 I	C	3	0.000	1.780	0.000	3.360	0.000	0.000	0		290	V

CABLES ROUTED IN CONDUIT:

TOTALS

-----  
 .000  
 -----  
 .000

PAGE 34  
 ATTACHMENT NO. UVA.2.1/2.4  
 WBN EEB-MS-TI/5-0011, REV.10

QA REPO CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE STAT
B 1209	4	2.0 I	C	3	0.000	1.780	0.000	3.360	0.000	0.000	0		290	V

CABLES ROUTED IN CONDUIT:

TOTALS

-----  
.000

-----  
.000

PAGE 35  
ATTACHMENT NO. UVA 2.1/2.4  
WBN EEB-MS-TIJS-0011, REV. 10

QA REP CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	U STAT
B 1210	4	2.0 I	C	3	0.000	1.780	0.000	3.360	0.000	0.000	0		290	V

CABLES ROUTED IN CONDUIT:

TOTALS

-----  
 .000  
 -----  
 .000

PAGE 36  
 ATTACHMENT NO. UVA.2.1/2.4  
 WBN EEB-MS-TIJS-0011, REV.10

QA REPO	WATTS BAR NUCLEAR PLANT CONDUIT R								PAGE 24	DATE 12/16/90					
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE STAT	
B 1211	3	2.0 I	C	3	0.000	1.041	0.150	3.360	0.000	0.186	2		290	V	

CABLES ROUTED IN CONDUIT:

B	148	1*2	WDB-1	NC1: 2	CAB CSA: .075	CAB WT: 0.093	TOTAL CSA: .150	TOTAL WT: .186
TOTALS							.150	.186

PAGE 37  
 ATTACHMENT NO. UVA2.1/2.4  
 WBN EEB-MS-TI5-0011, REV.10



WATTS BAR NUCLEAR PLANT CONDUIT RE										PAGE 25		DATE 12/16/90		
QA REPORT CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VER STAT
B 1231	4	3.0 P	C	55	0.000	2.290	2.712	7.390	0.000	5.254	2		290	V

CABLES ROUTED IN CONDUIT:

B	84	1*1	WDQ	NC1: 2	CAB CSA: 1.356	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 38  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TI/5-0011, REV. 10

WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 26		DATE 12/16/90		
QA REPT CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	V STA
B 1232	4	3.0 P	C	55	0.000	2.290	2.712	7.390	0.000	5.254	2		290	V

CABLES ROUTED IN CONDUIT:

B	83	1+1	WDQ	NC1: 2	CAB CSA: 1.356	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 39

ATTACHMENT NO. UVA 2.1/2.4  
WBNEEB-MS-TIIS-0011, REV. 10

WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 27	DATE 12/16/90			
QA REPT CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE STAT
B 1233	4	3.0 P	C	55	0.000	2.290	2.712	7.390	0.000	5.254	2		290	V

CABLES ROUTED IN CONDUIT:

B	88	1*1	WDQ	NC1: 2	CAB CSA: 1.356	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 40  
 ATTACHMENT NO. UVA2.1/2.4  
 WBN EEB-MS-TI/5-0011, REV.10

QA REPO WATTS BAR NUCLEAR PLANT CONDUIT RE PAGE 28 DATE 12/16/90  
 CONDUIT NV CONDUIT CON CON CSA CSA CSA CONDUIT WT/FT. WT/FT. NO. AMB SYSTEM VE  
 ID SIZE TYP LENG LIMIT MAX ACCUM CSA INS LIMIT ACCUM CAB TEMP STAT

B 1234 4 3.0 P C 55 0.000 2.290 2.712 7.390 0.000 5.254 2 290 V

CABLES ROUTED IN CONDUIT:

B 89 1\*1 WDQ NC1: 2 CAB CSA: 1.356 CAB WT: 2.627 TOTAL CSA: 2.712 TOTAL WT: 5.254  
 TOTALS 2.712 5.254

PAGE 4/  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TIIS-0011, REV. 10

WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 29	DATE 12/16/90			
QA REPO CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE STAT
B 1235	4	3.0 P	C	55	0.000	2.290	2.712	7.390	0.000	5.254	2		290	V

CABLES ROUTED IN CONDUIT:

B	93	1*1	WDQ	NC1: 2	-CAB CSA: 1.356	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 42  
ATTACHMENT NO. UVA 2.1/2.4  
WBN EEB-MS-TI/5-0011, REV. 10

CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	V STA
B 1236	4	3.0 P	C	55	0.000	2.290	2.712	7.390	0.000	5.254	2		290	V

CABLES ROUTED IN CONDUIT:

B	94	1*1	WDQ	NC1: 2	CAB CSA: 1.356	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 43  
 ATTACHMENT NO. UVA.2.1/2.4  
 WBN EEB-MS-TIIS-0011, REV.10

QA REPORT	WATTS BAR NUCLEAR PLANT CONDUIT RE										PAGE 31	DATE 12/16/90			
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CON CSA LIMIT	CON CSA MAX	CON CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VER STAT	
B 1237	4	3 0 F	C	55	0.000	2.290	2.712	7.390	0.000	5.254	2		290	V	

CABLES ROUTED IN CONDUIT:

B	98	1*1	WDQ	NC1: 2	CAB CSA: 1.356	CAB W.I: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 44

ATTACHMENT NO. UVA2.1/2.4  
WBNEB-MS-TIIS-0011, REV.10

QA REPO	WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 32		DATE 12/16/90			
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE	STAT	
B 1238	4	3.0 P	C	55	0.000	2.290	2.712	7.390	0.000	5.254	2		290	V		

CABLES ROUTED IN CONDUIT:

B	99	1*1	WDQ	NC1: 2	CAB CSA: 1.356	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 45  
 ATTACHMENT NO. UVA2.1/2.4  
 WBN EEB-MS-TI5-0011, REV.10



QA REP	WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 33	DATE 12/16/90		
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	U STAT
B 1223	4	3.0 P	C	25	0.000	2.290	2.712	7.390	0.000	5.254	2		291	V

CABLES ROUTED IN CONDUIT:

B	B4	1+1	WDQ	NC1:	2	CAB CSA:	1.356	CAB WT:	2.627	TOTAL CSA:	2.712	TOTAL WT:	5.254
TOTALS											2.712	5.254	

PAGE 46  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TI/5-0011, REV. 10

QA REPC	WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 34	DATE 12/16/90			
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE STAT	
B 1224	4	3.0 P	C	25	0.000	2.290	2.712	7.390	0.000	5.254	2		291	V	

CABLES ROUTED IN CONDUIT:

B	83	1*1	WDQ	NC1: 2	CAB CSA: 1.356	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 47  
 ATTACHMENT NO. UVA2.1/2.4  
 WBN EEB-MS-TI15-0011, REV. 10

WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 35	DATE 12/16/90				
QA REPO CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE STAT	
B 1225	4	3.0 P	C	25	0.000	2.290	2.712	7.390	0.000	5.254	2		291	V	

CABLES ROUTED IN CONDUIT:

B	88	1*1	WDQ	NC1: 2	CAB CSA: 1.356	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 4 8  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TI/5-0011, REV. 10

QA REPO	WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 36	DATE 12/16/90			
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE STAT	
B 1226	4	3.0 P	C	25	0.000	2.290	2.712	7.390	0.000	5.254	2		291	V	

CABLES ROUTED IN CONDUIT:

B	89	1*1	WDQ	NC1: 2	CAB CSA: 1.356	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 49  
ATTACHMENT NO. UVA 2.1/2.4  
WBNEEB-MS-TI/5-0011, REV. 10

QA REPORT	WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 37	DATE 12/16/90			
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE STAT	
B 1227	4	3.0 P	C	25	0.000	2.290	2.712	7.390	0.000	5.254	2		291	V	

CABLES ROUTED IN CONDUIT:

B	94	1*1	WDQ	NC1: 2	CAB CSA: 1.356	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 50  
 ATTACHMENT NO. UVA2.1/2.4  
 WBN EEB-MS-TIIS-0011, REV.10

QA REPORT	WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 38	DATE 12/16/90			
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE STAT	
B 1228	4	3.0 P	C	25	0.000	2.290	2.712	7.390	0.000	5.254	2		291	V	

CABLES ROUTED IN CONDUIT:

B	93	1*1	WDQ	NC1: 2	CAB CSA: 1.356	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 51  
 ATTACHMENT NO. UVA2.1/2.4  
 WBN EEB-MS-TI/5-0011, REV.10

QA REPT CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CS ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	STAT
B 1229	4	3.0 P	C	25	0.000	2.290	2.712	7.390	0.000	5.254	2		291	V

CABLES ROUTED IN CONDUIT:

B	98	1*1	WDQ	NC1: 2	CAB CSA: 1.356	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 52  
 ATTACHMENT NO. UVA.2.1/2.4  
 WBN EEB-MS-TIIS-0011, REV. 10

QA REP	WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 40	DATE 12/16/90			
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	STAT	
B 1230	4	3.0 F	C	25	0.000	2.290	2.712	7.390	0.000	5.254	2		291	V	

CABLES ROUTED IN CONDUIT:

B	99	1*1	WDQ	NC1:	2	CAB CSA:	1.356	CAB WT:	2.627	TOTAL CSA:	2.712	TOTAL WT:	5.254
TOTALS											2.712	5.254	

PAGE 53  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TI/5-0011, REV. 10



WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 41		DATE 12/16/90			
QA REPC CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE STAT	
B 1253	4	3.0 P	C	5	0.000	2.290	2.712	7.390	0.000	5.254	2		292	V	

CABLES ROUTED IN CONDUIT:

B	84	1*1	WDQ	NC1: 2	CAB CSA: 1.356	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 54  
 ATTACHMENT NO. UVA 2.1/2.4  
 W8N EEB-MS-TIIS-0011, REV 10

QA REP CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	STAT
B 1252	4	3.0 P	C	5	0.000	2.290	2.712	7.390	0.000	5.254	2		292	V

WATTS BAR NUCLEAR PLANT CONDUIT R

CABLES ROUTED IN CONDUIT:

B	83	1*1	WQ	NC1: 2	CAB CSA: 1.356	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 55  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TI/5-0011, REV. 10

QA REP	WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 43	DATE 12/16/90			
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	STAT	
B 1254	4	3.0 P	C	5	0.000	2.290	2.712	7.390	0.000	5.254	2		292	V	

CABLES ROUTED IN CONDUIT:

B	88	1*1	WDQ	NC1: 2	CAB CSA: 1.356	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 56

ATTACHMENT NO. UVA 2.1/2.4  
WBN EEB-MS-TIIS-0011, REV. 10

QA REP	WATTS BAR NUCLEAR PLANT CONDUIT							PAGE 44	DATE 12/16/90					
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	STAT
B 1255	4	3.0 P	C	5	0.000	2.290	2.712	7.390	0.000	5.254	2		292	U

CABLES ROUTED IN CONDUIT:

B	B9	1*1	WDQ	NC1:	2	CAB CSA:	1.356	CAB WT:	2.627	TOTAL CSA:	2.712	TOTAL WT:	5.254
TOTALS											2.712	5.254	

PAGE 57  
ATTACHMENT NO. UVA 2.1/2.4  
WBN EEB-MS-TIIS-0011, REV. 10

QA REP	CONDUIT ID	NU	CONDUIT SIZE	CON TYP	CON LENG	CON CSA LIMIT	CON CSA MAX	CON CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	STAT
	B 1285	4	3.0 P	C	20	0.000	2.290	2.712	7.390	0.000	5.254	2		292	V

CABLES ROUTED IN CONDUIT:

B	93	1*1	WBQ	NC1:	2	CAB CSA:	1.356	CAB WT:	2.627	TOTAL CSA:	2.712	TOTAL WT:	5.254
TOTALS											2.712	5.254	

PAGE 58  
ATTACHMENT NO. UVA 2.1/2.4  
WBNEB-MS-TI/5-0011, REV. 10

QA REF CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	STAT
B 1286	4	3.0 P	C	20	0.000	2.290	2.712	7.390	0.000	5.254	2		292	V

CABLES ROUTED IN CONDUIT:

B	94	1*1	WDQ	NC1: 2	CAB CSA: 1.356	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 59  
ATTACHMENT NO. UVA 2.1/2.4  
WBN EEB-MS-TI/5-0011, REV. 10

QA REP CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	STAT
B 1280	4	3.0 P	C	20	0.000	2.290	2.712	7.390	0.000	5.254	2		292	V

WATTS BAR NUCLEAR PLANT CONDUIT

CABLES ROUTED IN CONDUIT:

B	98	1*1	WDQ	NC1: 2	CAB CSA: 1.356	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 60  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TI5-0011, REV. 10

QA REPORT	WATTS BAR NUCLEAR PLANT CONDUIT R														PAGE 48	DATE 12/16/90
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE STAT		
B 1281	4	3.0 P	C	20	0.000	2.290	2.712	7.390	0.000	5.254	2		292	V		

CABLES ROUTED IN CONDUIT:

B	99	1*1	WDQ	NC1: 2	CAB CSA: 1.356	CAB WT: 2.627	TOTAL CSA: 2.712	TOTAL WT: 5.254
TOTALS							2.712	5.254

PAGE 6 /  
 ATTACHMENT NO. UVA2.1/2.4  
 WBN EEB-MS-TI/5-0011, REV.10



QA REP CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	STAT
PLC 2472	4	1.5 I	C	70	0.000	1.081	0.213	2.040	0.000	0.246	1		290	U

CABLES ROUTED IN CONDUIT:

PL 4407	1*1	WFC-1	NC1: 1	CAB CSA:	.213	CAB WT: 0.246	TOTAL CSA:	.213	TOTAL WT:	.246
TOTALS								.213	.246	

PAGE 62  
 ATTACHMENT NO. UVA.2.1/2.4  
 WBN EEB-MS-TI/5-0011, REV.10

CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	STAT
PLC 3140	4	1.5 I	C	60	0.000	.632	1.017	2.040	0.000	1.265	2		290	V

CABLES ROUTED IN CONDUIT:

ABN	755	1*1	WFA-4	NC1:	1	CAB CSA:	0.377	CAB WT:	0.430	TOTAL CSA:	.377	TOTAL WT:	.430
PL	6280	1*1	WFA-2	NC1:	1	CAB CSA:	.640	CAB WT:	0.835	TOTAL CSA:	.640	TOTAL WT:	.835
TOTALS										1.017		1.265	

PAGE 63  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TI/5-0011, REV. 10

WATTS BAR NUCLEAR PLANT CONDUIT R													PAGE 51	DATE 12/16/90
QA REPO CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE STAT
PLC 3141	4	1.5 I	C	60	0.000	.632	1.017	2.040	0.000	1.265	2		290	V

CABLES ROUTED IN CONDUIT:

PL 6041	1*1	WFA-4	NC1: 1	CAB CSA: 0.377	CAB WT: 0.430	TOTAL CSA: 000.377	TOTAL WT: 000.430
PL 6281	1*1	WFA-2	NC1: 1	CAB CSA: .640	CAB WT: 0.835	TOTAL CSA: .640	TOTAL WT: .835
TOTALS						1.017	1.265

PAGE 64  
ATTACHMENT NO. UVA 2.1/2.4  
WBNEEB-MS-TIIS-0011, REV. 10

QA REPT CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE STAT
PLC 3781	4	2.0 I	C	56	0.000	1.041	.754	3.360	0.000	.860	2		290	V

CABLES ROUTED IN CONDUIT:

PL 6340	1*1	WFA-4	NC1: 1	CAB CSA: 0.377	CAB WT: 0.430	TOTAL CSA: .377	TOTAL WT: .430
PL 6341	1*1	WFA-4	NC1: 1	CAB CSA: 0.377	CAB WT: 0.430	TOTAL CSA: .377	TOTAL WT: .430
TOTALS						.754	.860

PAGE 65  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-T115-0011, REV. 10

CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CON CSA LIMIT	CON CSA MAX	CON CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VER STAT
------------	----	--------------	---------	----------	---------------	-------------	---------------	-----------------	--------------	--------------	---------	----------	--------	----------

PLC 3137	4	1.5 I	C	35	0.000	.632	1.017	2.040	0.000	1.265	2		291	V
----------	---	-------	---	----	-------	------	-------	-------	-------	-------	---	--	-----	---

CABLES ROUTED IN CONDUIT:

ABN 755	1*1	WFA-4	NC1: 1	CAB CSA: 0.377	CAB WT: 0.430	TOTAL CSA: .377	TOTAL WT: .430
PL 6280	1*1	WFA-2	NC1: 1	CAB CSA: .640	CAB WT: 0.835	TOTAL CSA: .640	TOTAL WT: .835

TOTALS

1.017

1.265

PAGE 66  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TIIS-0011, REV. 10

QA REP CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	STAT
PLC 3138	4	1.5 I	C	35	0.000	.632	1.017	2.040	0.000	1.265	2		291	V

CABLES ROUTED IN CONDUIT:

PL 6041	1*1	WFA-4	NC1: 1	CAB CSA: 0.377	CAB WT: 0.430	TOTAL CSA: 000.377	TOTAL WT: 000.430
PL 6281	1*1	WFA-2	NC1: 1	CAB CSA: .640	CAB WT: 0.835	TOTAL CSA: .640	TOTAL WT: .835
TOTALS						1.017	1.265

PAGE 67  
 ATTACHMENT NO. UVA 2.1/2.4  
 W8NEEB-MS-TIIS-0011, REV.10

QA REF CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	STAT
PLC 3780	4	2.0 I	C	19	0.000	1.041	.754	3.360	0.000	.860	2		291	V

CABLES ROUTED IN CONDUIT:

PL 6340	1*1	WFA-4	NC1: 1	CAB CSA: 0.377	CAB WT: 0.430	TOTAL CSA: .377	TOTAL WT: .430
PL 6341	1*1	WFA-4	NC1: 1	CAB CSA: 0.377	CAB WT: 0.430	TOTAL CSA: .377	TOTAL WT: .430
TOTALS						.754	.860

ATTACHMENT NO. UVA 2.1/2.4  
 WBNEEB-MS-TIIS-0011, REV. 10  
 PAGE 68

QA REPORT WATTS BAR NUCLEAR PLANT CONDUIT REPORT PAGE 56 DATE 12/16/90

CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VEHICLE STAT
------------	----	--------------	---------	----------	-----------	---------	-----------	-----------------	--------------	--------------	---------	----------	--------	--------------

1PLC3656	4	3.0 I	C	50	0.000	2.956	1.642	7.390	0.000	3.012	5		290	V
----------	---	-------	---	----	-------	-------	-------	-------	-------	-------	---	--	-----	---

CABLES ROUTED IN CONDUIT:

1PL 6660	1*1	WDG-1	NC1: 2	CAB CSA: .173	CAB WT: 0.291	TOTAL CSA: .346	TOTAL WT: .582
1PL 6661	1*1	WDK-1	NC1: 3	CAB CSA: .432	CAB WT: 0.810	TOTAL CSA: 1.296	TOTAL WT: 2.430
TOTALS						1.642	3.012

PAGE 69  
 ATTACHMENT NO. UVA2.1/2.4  
 WBN EEB-MS-TI/5-0011, REV.10



QA REPO	WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 57	DATE 12/16/90			
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CON CSA LIMIT	CON CSA MAX	CON CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE. STAT	
2PLC3636	4	3.0 I	C	70	0.000	2.956	1.642	7.390	0.000	3.012	5		290	V	

CABLES ROUTED IN CONDUIT:

2PL 6660	1*1	WDG-1	NC1: 2	CAB CSA: .173	CAB WT: 0.291	TOTAL CSA: .346	TOTAL WT: .582
2PL 6661	1*1	WDK-1	NC1: 3	CAB CSA: .432	CAB WT: 0.810	TOTAL CSA: 1.296	TOTAL WT: 2.430
TOTALS						1.642	3.012

PAGE 70  
ATTACHMENT NO. UVA2.1/2.4  
W8NEB-MS-TI/5-0011, REV.10

QA REPC	WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 58	DATE 12/16/90			
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE STAT	
VC 1598	4A	3.0 I	C	0	0.000	3.916	.000	7.390	0.000	.000			292	V	

CABLES ROUTED IN CONDUIT:

TOTALS

-----  
.000

-----  
.000

PAGE 71  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TI/5-0011, REV. 10

QA REPO	WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 59	DATE 12/16/90			
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE STAT	
VC 1743	4B	3.0 I	C	12	0.000	3.916	.339	7.390	0.000	.343	1		290	V	

CABLES ROUTED IN CONDUIT:

ABN 2515 B 1*1	WHH-1	NC1: 1	CAB CSA: 0.339	CAB WT: 0.343	TOTAL CSA: .339	TOTAL WT: .343
TOTALS					.339	.343

PAGE 72  
 ATTACHMENT NO. UVA2.1/2.4  
 W8N E8B-MS-TIIS-0011, REV.10

QA REPO	WATTS BAR NUCLEAR PLANT CONDUIT RE										PAGE 60	DATE 12/16/90			
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VEN STAT	
VC 1740	4A	3.0 I	C	6	0.000	3.916	.163	7.390	0.000	.158	1		290	V	

CABLES ROUTED IN CONDUIT:

ABN 2511 A 1*1	WGC-1	NC1: 1	CAB CSA: 0.163	CAB WT: 0.158	TOTAL CSA: .163	TOTAL WT: .158
TOTALS					.163	.158

PAGE 75  
 ATTACHMENT NO. UVA 2.1/2.4  
 WBN EEB-MS-TIIS-0011, REV. 10

GA REPO	WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 61	DATE 12/16/90			
CONDUIT	NV	CONDUIT	CON	CON	CSA	CSA	CSA	CONDUIT	WT/FT.	WT/FT.	NO.	AMB	SYSTEM	VE	
ID		SIZE	TYP	LENG	LIMIT	MAX	ACCUM	CSA INS	LIMIT	ACCUM	CAB	TEMP		STAT	
VC 1599	4B	3.0 I	C	0	0.000	2.290	.502	7.390	0.000	.501	2		292	V	

CABLES ROUTED IN CONDUIT:

ABN 2511 A 1*1	UGC-1	NC1: 1	CAB CSA: 0.163	CAB WT: 0.158	TOTAL CSA: .163	TOTAL WT: .158
ABN 2515 B 1*1	WHH-1	NC1: 1	CAB CSA: 0.339	CAB WT: 0.343	TOTAL CSA: .339	TOTAL WT: .343
TOTALS					.502	.501

PAGE 74  
 ATTACHMENT NO. UVA2.1/2.4  
 WBN EEB-MS-TIIS-0011, REV.10

WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE 1		DATE 12/16/90			
QA REPO CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE STAT	
1PLC3881	4	1.5 I	C	15	0.000	.816	.495	2.040	0.000	.625	1	40	290	V	

CABLES ROUTED IN CONDUIT:

1PL	3900	1*1	WFA-15	NC1: 1	CAB CSA:	0.495	CAB WT:	0.625	TOTAL CSA:	000.495	TOTAL WT:	000.625
TOTALS										.495		.625

PAGE 75  
ATTACHMENT NO. UVA.2.1/2.4  
WBN EEB-MS-TIIS-0011, REV.10

QA REPO	WATTS BAR NUCLEAR PLANT CONDUIT R										PAGE	DATE 12/16/90			
CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE STAT	
2PLC3880	4	1.5 I	C	15	0.000	.816	.495	2.040	0.000	.625	1	40	291	V	

CABLES ROUTED IN CONDUIT:

2PL	3901	1*1	WFA-15	NC1: 1	CAB CSA: 0.495	CAB WT: 0.625	TOTAL CSA: 000.495	TOTAL WT: 000.625
TOTALS							.495	.625

PAGE 76  
ATTACHMENT NO. UVA.2.1/2.4  
W8N E8B-MS-TI/5-0011, REV.10

QA REP CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	PAGE 3	DATE 12/16/90	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE STAT
1PLC3882	4	1.5 I	C	15	0.000	.816	.495	2.040	0.000			.625	1	40	292	V

CABLES ROUTED IN CONDUIT:

1PL	3900	1*1	WFA-15	NC1: 1	CAB CSA:	0.495	CAB WT:	0.625	TOTAL CSA:	000.495	TOTAL WT:	000.625
TOTALS										.495	.625	

PAGE 77

ATTACHMENT NO. UVA2.1/2.4  
WBN EEB-MS-TIIS-0011, REV.10



QA REP CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	CSA LIMIT	CSA MAX	CSA ACCUM	CONDUIT CSA INS	WT/FT. LIMIT	WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	STAT
2PLC3879	4	1.5 I	C	15	0.000	.816	.495	2.040	0.000	.625	1	40	290	V

CABLES ROUTED IN CONDUIT:

2PL 3901	1*1	WFA-15	NC1:	1	CAB CSA:	0.495	CAB WT:	0.625	TOTAL CSA:	000.495	TOTAL WT:	000.625
TOTALS										.495		.625

PAGE 78  
 ATTACHMENT NO. UVA 2.1/2.4  
 W8NEEB-MS-TIIS-0011, REV.10

QA REPT CONDUIT ID	NV	CONDUIT SIZE	CON TYP	CON LENG	WATTS BAR NUCLEAR CSA LIMIT	PLANT CONDUIT R CSA MAX	CONDUIT CSA ACCUM	CONDUIT CSA INS	PAGE WT/FT. LIMIT	7 DATE 12/16/90 WT/FT. ACCUM	NO. CAB	AMB TEMP	SYSTEM	VE STAT
MC 694	4	3.0 I	C	120	0.000	2.290	.630	7.390	0.000	1.070	2	43	290	V

CABLES ROUTED IN CONDUIT:

1A	4665	1*1	WDJ-1	NC1: 2	CAB CSA: 0.315	CAB WT: 0.535	TOTAL CSA: 000.630	TOTAL WT: 001.070
TOTALS							.630	1.070

PAGE 29  
ATTACHMENT NO. UVA2.1/2.4  
WBN EEB-MS-TI/5-0011, REV. 10

The purpose of this section of Attachment UVA2.1/2.4 is to identify Non-1E V4 cables which could possibly become associated with Class 1E cables by entering the Category 1 duct banks between the Auxiliary Building and (1) the Intake Pumping Station, or (2) the Diesel Generator Building, and evaluating their cable protection.

#### REFERENCES

References for this section consist of the drawings identified in Table 1 and 2 and:

- Computerized Cable Reporting System (CCRS)
- CCRS Conduit Report (B26910227412)
- Ref. 3.65 of this calculation (Design Standard DS E12.6.3)
- Ref. 3.66 of this calculation (Walkdown data)
- Design Guide DG E12.6.2 (R0)
- Westinghouse Circuit Breaker Type EHB Curve (Attached)
- Cutler-Hammer Circuit Breaker Type FC Curve (Attached)
- Field Verified Protective Device Data (Attached)

#### METHODOLOGY

The task was accomplished by completion of the following steps:

- (1) Identifying V4 raceways which interface with the duct banks
- (2) Identifying the cables within the raceways and their power sources
- (3) Determining if the cables are presently addressed by the calculation and
- (4) If not, identifying the cables protective device(s) and
- (5) Analysis to determine the adequacy of cable protection

The details of steps 1 thru 5 are as follows:

- (1) Refer to Table 2 of this Attachment.  
The drawings noted in Table 2 and the referenced CCRS Conduit Report were reviewed to determine the manholes (MH) and associated V4 raceways listed (\* denotes that the raceway is empty).
- (2) Cables routed in the raceways were identified from the referenced CCRS Conduit Report. Cable data and power sources were extracted from CCRS and tabulated. Cable insulation temperature ratings were obtained from DS E12.6.3. See Table 1 for results of this step.
- (3) The tabulation was compared with Appendix H of the calculation to determine if the cables were presently addressed and noted as such in Table 1.
- (4) For cables not presently addressed in the calculation the protective device data was obtained from walkdown data (Ref. 3.66 of this calculation) or by field verification (attached) and tabulated in Table 1.
- (5) Time-current plots were developed for the protective devices and cables using the referenced manufacturer's data and the cable thermal damage characteristics from Figure 1 of DG E12.6.2. Adjustment for 75C Degree cable insulation was accomplished by extracting a multiplier ( $K_t = 0.533$ ) from Figure 2 of the standard (75 to 150C Degrees). The adequacy of cable protection is noted in the PASS/FAIL column of Table 1 (See RESULTS/CONCLUSIONS) which was determined based on these curves and/or Appendix A.

RESULTS/CONCLUSIONS (Refer to Table 1)

Circuits identified as PASS(1) require that the circuit breakers be periodically tested since they do not meet the criteria outlined in the calculation. Circuits identified as PASS require no further action.

DCN S-15905-A has been initiated to revise the following drawings and to correct discrepancies noted while verifying the protective devices (Refer to Table 1 for the correct field verified settings) and to update the Periodic Breaker Test Drawings.

- 45W745 (Compt 6A & 6B)
- 45B797-6B
- 45W743-1 (Compt 2B)
- 45B786-2B
- 45W743-2 (Compt 2B)
- 45B787-2B
- 45B710-series Periodic breaker test drawings for the boards/compartments identified in Table 1 as PASS(1)

ATTACHED SUPPORTING DOCUMENTATION

	PAGE
Table 1.....	82-83
Table 2.....	84
Westinghouse Circuit Breaker Type EHB Curve.....	85
Cuttler-Hammer Circuit Breaker Type FC Curve.....	86
Time-Current Plot, Westinghouse Type EHB Breaker.....	87
Time-Current Plot, Cuttler-Hammer Type FC Breaker.....	88
Field Verified Protective Device Data.....	89-93


TABLE 1

CABLE	INSULATION			BOARD	TRIP			REV	PASS/ FAIL	NOTES
	MK NO.	SIZE	TEMP RTG		PROT DEVICE	MFR RTG	DWG REF			
.29				0-MCC-226-1/5F1						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX
.34				0-MCC-226-1/4F1						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX
306	WDH-1	#1/0	90C	0-LAC-233-25	EHB3020	W 20A	45W399-4	RJ,R12	PASS(1)	FIELD VERIFIED PROT DEVICE DATA ATTACHED
525	WBS *	#4	75C	0-LAC-233-90	FC3020	C-H 20A	45W399-4	RJ,R12	PASS(1)	*SPLICED WITH WDF-1 (3-1C #4,90C) IN MH FIELD VERIFIED PROT DEV DATA ATTACHED
526	WBQ	#8	75C	0-LAC-233-27	EHB3020	W 20A	45W399-4	RJ,R12	PASS(1)	FIELD VERIFIED PROT DEVICE DATA ATTACHED
527	WBQ	#8	75C	0-LAC-233-27	EHB3020	W 20A	45W399-4	RJ,R12	PASS(1)	FIELD VERIFIED PROT DEVICE DATA ATTACHED
528	WBQ	#8	75C	0-LAC-233-27	EHB3020	W 20A	45W399-4	RJ,R12	PASS(1)	FIELD VERIFIED PROT DEVICE DATA ATTACHED
529	WBQ	#8	75C	0-LAC-233-23	EHB3030	W 30A	45W399-4	RJ,R12	PASS(1)	FIELD VERIFIED PROT DEVICE DATA ATTACHED
534	WBS	#4	75C	0-LAC-233-25	EHB3020	W 20A	45W399-4	RJ,R12	PASS(1)	FIELD VERIFIED PROT DEVICE DATA ATTACHED
535	WBS	#4	75C	0-LAC-233-25	EHB3020	W 20A	45W399-4	RJ,R12	PASS(1)	FIELD VERIFIED PROT DEVICE DATA ATTACHED
542	WBS	#4	75C	0-LAC-233-25	EHB3020	W 20A	45W399-4	RJ,R12	PASS(1)	FIELD VERIFIED PROT DEVICE DATA ATTACHED
561	WDD-1	#8	90C	0-LAC-233-25	EHB3020	W 20A	45W399-4	RJ,R12	PASS(1)	FIELD VERIFIED PROT DEVICE DATA ATTACHED
568	WDD-1	#8	90C	0-LAC-233-27	EHB3020	W 20A	45W399-4	RJ,R12	PASS(1)	FIELD VERIFIED PROT DEVICE DATA ATTACHED
569	WDD-1	#8	90C	0-LAC-233-23	EHB3020	W 20A	45W399-4	RJ,R12	PASS(1)	FIELD VERIFIED PROT DEVICE DATA ATTACHED
570	WBS	#4	75C	0-LAC-233-23	EHB3020	W 20A	45W399-4	RJ,R12	PASS(1)	FIELD VERIFIED PROT DEVICE DATA ATTACHED
PL395				0-BD-206-1/3A						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX (TO BE SPARE PER DCN M-15245-A)
PL801				0-MCC-208-A/4E2						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX
PL802				0-MCC-208-A/7F2						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX
PL803				0-MCC-208-A/5E2						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX (TO BE SPARE PER DCN M-15245-A)
PL1240	WLO	#10	90C	0-MCC-218-1/2A	EF3-B030	ITE 30A	45B797-2A	RB,R1	PASS(1)	PROT DEV DATA FROM REF 3.66
							45W797-1	RC,R2		
PL1250	WLO	#10	90C	0-MCC-218-1/2B	EF3-B030	ITE 30A	45B797-2B	RB,R1	PASS(1)	PROT DEV DATA FROM REF 3.66
							45W797-1	RC,R2		
PL1260	WMJ	#6	90C	0-MCC-218-1/3A	EF3-B050	ITE 50A	45B797-3A	RB,R1	PASS(1)	PROT DEV DATA FROM REF 3.66
							45W797-1	RC,R2		
PL1280	WMJ	#6	90C	0-MCC-218-1/3B	EF3-B050	ITE 50A	45B797-3B	RB,R1	PASS(1)	PROT DEV DATA FROM REF 3.66
							45W797-1	RC,R2		
PL1295	WLO	#10	90C	0-MCC-218-1/4D	EF3-A025 @4	ITE 170A	45B797-4D	RC,R2	PASS(1)	PROT DEV DATA FROM REF 3.66
							45W797-1	RC,R2		
PL1324	WLO	#10	90C	0-MCC-218-1/5F1	EF3-B020	ITE 20A	45B797-5F	RG,R4	PASS(1)	PROT DEV DATA FROM REF 3.66
							45W797-1	RC,R2		
PL1335	WLO	#10	90C	0-MCC-218-1/3F1	EF3-B020	ITE 20A	45B797-3F	RB,R0	PASS(1)	PROT DEV DATA FROM REF 3.66
							45N1699-5	RE,R8		
PL2450	WLO	#10	90C	0-MCC-218-1/6A	EF3-A025 @3	ITE 125A	45B797-6A	RC,R2	PASS(1)	PROT DEV DATA FROM REF 3.66
							45W797-1	RC,R2		
PL2455	WLO	#10	90C	0-MCC-218-1/6B	EF3-A025 @HI	ITE 210A	45B797-6B	RB,R2	PASS(1)	PROT DEV DATA FROM REF 3.66
							45W797-1	RC,R2		
PL2480	WMB	#8	90C	0-MCC-218-1/6C	EF3-L050 @3	ITE 260A	45B797-6C	RC,R2	PASS(1)	PROT DEV DATA FROM REF 3.66
							45W797-1	RC,R2		
PL3060				0-MCC-208-A/3C1						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX
PL3080	WDE-1	#6	90C	0-MCC-222-1/8C1	EF3-B020	ITE 20A	45B790-8C	RD,R2	PASS(1)	FIELD VERIFIED PROT DEVICE DATA ATTACHED
							45W399-5	RE,R5		
PL3105				0-MCC-208-A/9D2						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX
PL3115				0-MCC-208-A/9E1						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX
PL3125				0-MCC-208-A/9E2						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX

TABLE 1

CABLE	MK NO.	INSULATION		BOARD	PROT DEVICE	TRIP		REV	PASS/ FAIL	NOTES
		SIZE	TEMP RTG			MFR RTG	DWG REF			
PL3109				0-MCC-208-A/9F1						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX
PL4401	WFA-2	#4	90C	0-MCC-257-1/2E	EF3-B070	ITE 70A	45B772-2E RD,R2		PASS(1)	PROT DEV DATA FROM REF 3.66
							45W399-4 RJ,R12			
PL4402	WDH-1	#1/0	90C	0-MCC-257-1/3C	EF3-B070	ITE 70A	45B772-3C RD,R2		PASS(1)	PROT DEV DATA FROM REF 3.66
							45W399-4 RJ,R12			
PL4460	WFC-1	#10	90C	0-MCC-257-1/5A	EF3-B020	ITE 20A	45B772-5A RD,R2		PASS(1)	PROT DEV DATA FROM REF 3.66
							45W399-4 RJ,R12			
PLR540				0-MCC-216-A/2B						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX
PLR548				0-MCC-216-B/2B						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX
PLW500				0-MCC-226-1/3A						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX
PLW508				0-MCC-226-1/5B						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX
PLW515				0-MCC-226-1/2C						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX
RM700				0-MCC-226-1/5F1						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX
1V3230				1-MCC-213-B2/12A-B						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX
2V3230				2-MCC-213-A2/13B-A						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX
PLR555				0-MCC-216-A/6F1						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX
1PL1108				1-MCC-232-A/6F1-A						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX
1PL3720				1-MCC-214-A1/3F2-A						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX
2PL3720				2-MCC-214-A1/10F1-A						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX
1PL1108				1-MCC-232-B/8F1-B						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX
1PL3720				1-MCC-214-B1/2F2-B						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX
2PL3730				2-MCC-214-B1/2F1-B						CIRCUIT PRESENTLY ADDRESSED IN APPENDIX





**Circuit Breaker Time/Current Curves**  
 Types EB, EHB, FB, HFB Breakers. Two and Three Poles  
 Westinghouse Electric Corporation

For application and coordination purposes only.  
 Based on 40°C ambient, cold start. Connected with four  
 (4) feet of rated wire (60°C) per terminal. Tested in open  
 air with current in all poles.

**Maximum Volts**

Breaker Type	Ac Volts, 60 Hz	Dc Volts
EB	240	125/250
EHB	480	250
FB	600	250
HFB	600	250

**Breaker Ratings**

Breaker	Continuous Amperes	Instantaneous Trip Amperes
15 - 40	See Curve	See Curve

**Interrupting Ratings (UL Listed)**


Breaker Type	Symmetrical RMS Amperes			Dc Amps
	240 Volts	480 Volts	600 Volts	250 Volts
EB	10,000	-----	-----	5,000 (125/250)
EHB	18,000	14,000	-----	10,000
FB	18,000	14,000	14,000	10,000
HFB	65,000	25,000	18,000	10,000

Ⓢ Single pole test data at 25°C based on NEMA  
 Procedures for verifying performance on Molded  
 Case Circuit Breakers.



ATTACHMENT UVA2.1/2.4  
W3N EEB-MS-TI15-0011, R11

CURRENT IN PERCENT OF BREAKER TRIP RATING



**Circuit Breaker Time/Current Curves.**  
Types EC, EMC, FC Breakers, Two and Three Poles  
Cutler-Hammer, Inc.

For application and coordination purposes only.  
Based on 25°C ambient, cold start. Connected with  
four (4) feet of rated wire (80°C) per terminal.  
Tested in open air with current in all poles.

**Maximum Volts**


Breaker Type	Ac Volts	Dc Volts
EC	240	250
EMC	480	250
FC	600	250

**Breaker Ratings**

Breaker	Continuous Amperes	Instantaneous Trip Amperes
EC	30 - 40	See Curve

**Interrupting Ratings (UL Listed - File Number E11713)**


Breaker Type	Symmetrical RMS Amperes	Dc Amps
EC	10,000	10,000
EMC	18,000	14,000
FC	18,000	14,000



TIME-CURRENT CHARACTERISTIC CURVES  
 For \_\_\_\_\_ Fuse Links In \_\_\_\_\_  
 BASIS FOR DATA Standards \_\_\_\_\_ Dated \_\_\_\_\_  
 1. Tests made at \_\_\_\_\_ Volts ac at \_\_\_\_\_ p-f., starting at 25°C with no initial load  
 2. Curves are plotted to \_\_\_\_\_ Test points so variations should be \_\_\_\_\_  
 No. \_\_\_\_\_  
 Date \_\_\_\_\_

PREP'D BY DATE 3-8-91  
 CHK EJS DATE 4/16/91

KEUFFEL & ESSER CO.  
 1000 UNIVERSITY AVENUE  
 PITTSBURGH, PA. 15206



TIME-CURRENT CHARACTERISTIC CURVES

For \_\_\_\_\_ Fuse Links In \_\_\_\_\_ Dated \_\_\_\_\_

1. Tests made at \_\_\_\_\_ Volts a-c at \_\_\_\_\_ p-f., starting at 150 with no initial load.

2. Curves are plotted to \_\_\_\_\_ Test points so variations should be \_\_\_\_\_

No. \_\_\_\_\_ Date \_\_\_\_\_

PREP *ym* 13 DATE 3-8-91  
CHK *ESJ* DATE 4/16/91

FIELD VERIFIED DATA

BOARD/PANEL 0-LAC-233-90

BKR/FUSE	MFR.	TYPE/MODEL	RTG	ADDITIONAL DATA
NA 4/11/91 3-5-91	CUTTLER- HAMMER	FC3020	20A	BREAKER TO BE TAKEN FROM 0-DPL-251-1

PREP T M B... DATE 3-5-91  
 CHK ... DATE 3/5/91

FIELD VERIFIED DATA

BOARD/PANEL O-LAC-233-25

BKR/FUSE	MFR.	TYPE/MODEL	RTG	ADDITIONAL DATA
#   thru   0	W	EHB3020	20A	NA YMB 3-5-91

PREP YMB DATE 3-5-91CHK Robert M. Z. [unclear] DATE 3/5/91

FIELD VERIFIED DATA

BOARD/PANEL 0-LAC-233-23

BKR/FUSE	MFR.	TYPE/MODEL	RTG	ADDITIONAL DATA
#2	W	EH83020	20A	NA 4MB 3-5-91 ↓
#1	W	EH83030	30A	

PREP T M Barber DATE 3-5-91  
CHK Robert M. Zimney DATE 3/5/91

FIELD VERIFIED DATA

BOARD/PANEL 0-LAC-233-27

BKR/FUSE	MFR.	TYPE/MODEL	RTG	ADDITIONAL DATA
#1, 2, 3, 4	<u>W</u>	EHB3020	20A	NA fmb 3-5-91

PREP T M Barber DATE 3-5-91  
CHK Robert M. J. Smith DATE 3/5/91

FIELD VERIFIED DATA

BOARD/PANEL 0-MCC-222-1/8C1

BKR/FUSE	MFR.	TYPE/MODEL	RTG	ADDITIONAL DATA
COMPT 8C1	ITE	EF3-B020	20A	NA <sup>9/28</sup> 3-5-91

PREP T M Bunker DATE 3-5-91  
 CHK Robert m n metz DATE 3/5/91



PREPARED: JM B DATE: 4-11-90  
VERIFIED: WST DATE: 4/11/90

PURPOSE

The purpose of this Attachment is to evaluate and support modifications to be implemented under DCN's M-08663-A and P-03065-B.

The modifications involve breaker and/or breaker setting changes and overload heater changes.

The following baseline calculations evaluate the DCN modifications for their impact. These evaluations are identified by the Attachment No. M08663A and are included in the calculation noted.

BASELINE CALCULATION	CALCULATION NO.
480VAC 1E COORDINATION/PROTECTION.....	WBN EEB-MS-TI08-0008
AUXILIARY POWER SYSTEM ANALYSIS.....	WBN-EEB-MS-TI06-0002
CONTAINMENT PENETRATION PROTECTION STUDY, VOLTAGE LEVEL V4 AND V5.....	EEB-MS-TI08-0015
480V NON-CLASS 1E POWER CABLE ASSOCIATED CIRCUITS.....	WBN EEB-MS-TI15-0011

ATTACHMENT MOB663A  
CALC NO. WBN EEB-MS-TI15-0011

PAGE 2

PREPARED: YMB DATE: 4-9-90  
VERIFIED: WJH DATE: 4/11/90

REFERENCE:

480VAC 1E COORDINATION/PROTECTION CALCULATION  
WBN EEB-MS-TI08-0008, Rev. 1

SCOPE:

Attached are copies of the sheets H8, H9, H39, and H56 from Appendix H which have been marked to depict the changes to the protective devices identified in the referenced calculation for the following Systems Group 1 loads :

0-MTR-32-25  
0-MTR-32-26

0-FCV-67-360  
0-FCV-67-362

SUMMARY OF RESULTS / CONCLUSIONS

The protective device changes do not adversely impact this calculation based on the following:

0-MTR-32-25 & 0-MTR-32-26

The new settings are acceptable since they do not exceed the criteria for the maximum protective device rating for a 4/0 cable (established in Rev. 0 of the base calc, Appendix A, Page 4)

0-FCV-67-360 & 0-FCV-67-362

The new settings are acceptable since they do not exceed the criteria for the maximum protective device rating for a #12 cable (established in Rev. 0 of the base calc, Appendix A, Page A1).

EX 1:  
 COMPUTED YMB DATE 4-9-90  
 CHECKED WPH DATE 4/11/90

WBN EEB-MS- TI15-0011 R0  
 Installation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Burchart Date 1/22/90 Checked Imy medel Date 1/26/90  
R.H. Burchart 1/10/90 Brian Kelley 1/25/90

1-BD-212-A2

COMPT NO	SERVICE	BKR MODEL NO	SENSOR RATING	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
3D	0-MTR-32-25	DS-416	300A	<del>75</del> 76	<del>112</del> 4	N/A	N/A	<del>1000</del> 600	N/A	4/0	1PL5083
7E	1-MTR-30-159	DS-206	300A	66	112	N/A	N/A	900	CP 4/0CS COULD SHARPEN	4/0	1PL5085 1PL5150

CHECKED WPH DATE 4/11/90

Page H9 of -H72

WBN EEB-MS-TI15-0011 R0

Termination of Non-IE Power Circuits Located in Category 1 Structures

Prepared Kingmudger Date 1/22/90 Checked R.H. Buchat Date 1/26/90  
R.H. Buchat 1/10/90 Swannley 1/25/90

1-BD-212-B1

COMPT NO	SERVICE	BKR MODEL NO	SENSOR RATING	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
2B	1-MTR-30-102	DS-416	300A	50	7.5	N/A	N/A	700	N/A	4/0	IPL5160
3E	1-MTR-62-101	DS-416	400A	75	20	N/A	N/A	1000	N/A	400	IPL5025
3D	0-MTR-32-26	DS-416	300A	<del>75</del> 76	<del>12</del> 4	N/A	N/A	<del>980</del> 600	N/A	400	IPL5080

RI

WBN EEB-MS-TI15-0011 R0

Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Bushart Date 1/22/90 Checked Kingman Date 1/26/90  
R.H. Bushart 1/10/90 Kingman 1/21/90

1-MCC-213-B2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
4A	1-FCV-3-193	A0102	3	45	1	T32	← N/A →			12	IV3290
4B	1-FCV-3-194	A0102	3	45	1	T32	← N/A →			12x2	IV3270
12A	0-FCV-67-362	<del>B010</del> A010	<del>10</del> 2	<del>27</del> 36	1	<del>T28</del> T29	← N/A →			12	IV3230

RI

COMPUTED TMB DATE 4-9-90

CHECKED WJH DATE 4/9/90

Page H56 of H72

WBN EEB-MS-TI15-0011 RO  
Installation of Non-IE Power Circuits Located in Category 1 Structures

Prepared knigh under Date 1/22/90 Checked R.H. Buchert Date 1/26/90  
knigh under 1/16/90 Scott Kelley 1/25/90

2-MCC-213-A2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
4A	2-FCV-3-191	A010	3	Y45	1	T31	N/A	N/A	N/A	12	2V3260
4B	2-FCV-3-192	A010	3	Y45	1	T31	N/A	N/A	N/A	12x2	2V3280
13B	0-FCV-67-360	A010	<del>10</del> 2	<del>27</del> 36	1	<del>T28</del> T29	N/A	N/A	N/A	12	2V3230

RI

PREPARED: T.M. Barber DATE: 5-3-90  
VERIFIED: S.P. Peterson DATE: 5/2/90

PURPOSE

The purpose of this Attachment is to evaluate and support modifications to be implemented under DCN P-5297-A.

The modifications involve the addition of two Air Handling Units for the Computer Room HVAC.

The following baseline calculations evaluate the DCN modifications for their impact. Since different aspects of a design modification are evaluated or determined in the calculation controlling that particular feature, interfaces or references between the calculations are necessary. The evaluations for this modification are identified by "ATTACHMENT NO. P5297A" and are included in the following calculations.

BASELINE CALCULATION	CALCULATION NO.
480VAC 1E COORDINATION/PROTECTION.....	WBN EEB-MS-TI08-0008
AUXILIARY POWER SYSTEM ANALYSES.....	WBN-EEB-MS-TI06-0002
480V NON-CLASS 1E POWER CABLE ASSOCIATED CIRCUITS.....	WBN EEB-MS-TI15-0011
REG GUIDE 1.75 ASSOCIATED CIRCUIT and APPENDIX R ANALYSIS for NON-CLASS 1E 120V AC and 250VDC CIRCUITS.....	WBPEVAR9001006
CONTROL POWER TRANSFORMERS.....	WBN EEB-MS-TI02-0019
120V PROTECTION/COORDINATION.....	WBN EEB-MS-TI07-0018
TELAS.....	WBN EEB-MS-TI05-0001
CABLE AMPACITY - NV4 and NV5 CABLES in CLASS 1E RACEWAYS.....	WBPEVAR8909010

PREPARED: Tom Barker DATE: 5-3-90  
VERIFIED: S. J. Peterson DATE: 5/2/90

## 1.0 SCOPE

This attachment evaluates and verifies that the proposed design is adequate and meets the guidelines applicable to the baseline calculation.

The loads are proposed as additions to 480V Reactor Vent Boards 1A-A and 2B-B (compartment 11B on both boards).

## 2.0 ASSUMPTIONS

See "Assumptions" identified in the base calculation (Section 2.0).

## 3.0 SOURCES OF DESIGN INPUT / REFERENCES

3.1 TELAS, WBN EEB-MS-TI06-0001

3.2 Cable Ampacity - NV4 and NV5 Cables in Class 1E Raceways, WBPEVAR8909010

3.3 480VAC 1E Coordination/Protection, WBN EEB-MS-TI08-0008

## 4.0 DESIGN INPUT DATA

The proposed cable sizes are documented in Ref. 3.2.

Protective device data is documented in Ref 3.1 with the breaker settings documented in Ref 3.3.

## 5.0 JUSTIFICATION OF ASSUMPTIONS

See "Justification of Assumptions" in base calculation (Section 5.0).

## 6.0 METHODOLOGY

The protective devices are ITE circuit breakers Model No. EF3-A025 with an instantaneous setting of 3 (125 Amps) and Shawmut TRS30 (30 Amp) fuses.



PREPARED: T. M. Barber DATE: 5-8-90  
VERIFIED: \_\_\_\_\_ DATE: \_\_\_\_\_

The minimum required cable size:

For a tray route: #6, WFA-3 or WFA-15

OR

For a conduit route: #10, WFC-1 or WFC-2

To provide adequate cable protection (per Appendix A of the base calculation) for these conductor sizes:

The magnetic circuit breaker trip rating (including tolerance) must be below the following settings.

#6: 550 Amps

#10: 225 Amps

The maximum fuse ratings are:

#6: TRS70

#10: TRS30

7.0 GRAPHICS

Not applicable.

8.0 SUMMARY OF RESULTS

The result of this analysis is that for the cable sizes selected, the proposed protective devices are at or below the maximum devices identified in Appendix A.

9.0 CONCLUSION

The cables are adequately protected by the protective devices (both the circuit breaker and fuse) identified in Section 6.0.

10.0 ATTACHMENTS

Not applicable.

PREPARED: T. M. B. DATE: 6-7-90  
VERIFIED: E. J. J. DATE: 6-8-90

PURPOSE

The purpose of this Attachment is to evaluate and support modifications to be implemented under DCN's M-10448-A (Group 2A) and M-10522-A (Groups 2B and 2C).

The modifications involve breaker and/or breaker setting and overload heater changes and incorporate data for cables to be replaced on DCN's M-10473-A (Train A) and M-10511-A (Train B).

The following baseline calculations evaluate the DCN modifications for their impact. These evaluations are identified by the Attachment No. M10448A and are included in the calculation noted.

BASELINE CALCULATION	CALCULATION NO.
480VAC 1E COORDINATION/PROTECTION.....	WBN EEB-MS-TI08-0008
AUXILIARY POWER SYSTEM ANALYSIS.....	WBN-EEB-MS-TI06-0002
CONTAINMENT PENETRATION PROTECTION STUDY, VOLTAGE LEVEL V4 AND V5.....	EEB-MS-TI08-0015
480V NON-CLASS 1E POWER CABLE ASSOCIATED CIRCUITS.....	WBN EEB-MS-TI15-0011
CABLE AMPACITY - NV4 and NV5 CABLES in CLASS 1E RACEWAYS.....	WBPEVAR8909010

PREPARED: YMB DATE: 6-7-90  
VERIFIED: EJS DATE: 6-8-90

1.0 SCOPE

This attachment addresses 480V Non-Class 1E protective device cable protection for System Group 2A, 2B, and 2C that receive power from the Class 1E boards listed within the base calculation.

2.0 ASSUMPTIONS

See Unverified Assumptions identified in the base calculation (Section 2.0, Page 8).

3.0 SOURCES OF DESIGN INPUT / REFERENCES

3.1 480VAC 1E Coordination/Protection, WBN EEB-MS-TI08-0008

4.0 DESIGN INPUT DATA

The Design input data consists of the following.

Protective device data was taken from Ref. 3.1

5.0 JUSTIFICATION OF ASSUMPTIONS

See Justification of Assumptions in base calculation (Section 5.0).

6.0 METHODOLOGY

The breaker types and settings (from Reference 3.1) were tabulated along with the cable sizes (See Section A).

The new breakers and/or settings were then evaluated to determine if the cable protection was adequate in accordance with the criteria established in the baseline calculation.

PREPARED: TMB DATE: 6-7-90  
VERIFIED: ESJ DATE: 6-8-90

7.0 GRAPHICS

Graphics for cable protection consists of the time-current plots contained in the baseline calculation.

8.0 SUMMARY OF RESULTS

The result of this analysis is that the protection for the 480V Non-Class 1E cables within the scope previously outlined have been determined to pass or fail as indicated in Section A.

9.0 CONCLUSION

All cables within the scope of this attachment are adequately protected.

The new breakers and/or settings supersede that contained in the baseline calculation.

10.0 SECTION REFERENCES

SECTION A - Tabulation of cables and circuit breaker modifications and/or settings

ATTACHMENT NO. M10448A - SECTION A  
WBN EEB-MS-TI15-0011  
480V SHUTDOWN BOARDS  
NON-CLASS 1E CIRCUITS

CMPT	LOAD	BKR TYPE	SENSOR	LDPV	LDTD	SDPU	SOTD	INST	CABLE NO	CABLE SZ	CABLE PROT	NOTES
* 480V SHDN BD 1A1-A 2C	1-MTR-30-103	200	0.90	4				7	1PL5140	4/0	PASS	
* 480V SHDN BD 1A2-A 7B	1-MTR-30-159	300	0.70	6				7	1PL5150	4/0	PASS	
* 480V SHDN BD 1B1-B 2B	1-MTR-30-102	200	0.90	4				7	1PL5160	4/0	PASS	
3B	1-MTR-62-101	400	0.80	4				9	1PL5025	400	PASS	
* 480V SHDN BD 1B2-B 7A	1-MTR-30-162	300	0.65	4				7	1PL5170	4/0	PASS	
* 480V SHDN BD 2A1-A 2C	2-MTR-30-104	200	0.90	4				7	2PL5140	4/0	PASS	
* 480V SHDN BD 2A2-A 7B	1-MTR-30-274	300	0.65	4				7	2PL5150	4/0	PASS	
7C	1-MTR-30-136	200	0.90	4				7	2PL5111	4/0	PASS	
* 480V SHDN BD 2B1-B 2B	2-MTR-30-105	200	0.90	4				7	2PL5160	4/0	PASS	
* 480V SHDN BD 2B2-B 7A	2-MTR-30-278	300	0.65	4				7	2PL5170	4/0	PASS	
7C	0-MTR-30-139	200	0.90	4				7	2PL5100	4/0	PASS	

ATTACHMENT NO. M10448A - SECTION A  
WBN EEB-MS-TI15-0011  
480V CLASS 1E MOTOR CONTROL CENTERS  
NON-CLASS 1E CIRCUITS

CMPT	LOAD	BKR TYPE	BREAKER SETTING	CABLE NO	CABLE SZ	CABLE PROT	NOTES
* C&A VENT BD 1A1-A							
13C	1-MTR-65-77	EF3-A025Z	2	1PL3645	#12	PASS	
* C&A VENT BD 1A2-A							
2A	0-MTR-31-339	EF3-A005	4	1PL2830	#12	PASS	
3A	1-MTR-30-25	EF3-A010	4	1PL2906	#12	PASS	
4A	1-MTR-30-283	EF3-A005	4	1PL3621	#12	PASS	
4B	0MTR-31-203/204	EF3-A025Z	3	V1920	#10	PASS	
5A	1-MTR-30-301	EF3-A010	4	1PL3435	#12	PASS	
8A	1-MTR-30-CRD	FJ3-B125	LO	1PL3692	2/0	PASS	
* C&A VENT BD 1B1-B							
12A	1-MTR-30-181	EF3-A010	4	1PL3021	#10	PASS	
13C	1-MTR-65-74	EF3-A025Z	2	1PL3660	#12	PASS	
* C&A VENT BD 1B2-B							
2B	0-MTR-31-418	EF3-A005	3	1PL3654	#12	PASS	
3B	1-MTR-30-284	EF3-A005	4	1PL3626	#12	PASS	
3C	1-MTR-30-66	EF3-A005	4	1PL3631	#12	PASS	
4B	1-MTR-30-302	EF3-A010	4	1PL3438	#12	PASS	
6B	1-MTR-30-26	EF3-A010	4	1PL2913	#12	PASS	
9A	1-MTR-30-CRB	FJ3-B125	LO	1PL3671	2/0	PASS	
* C&A VENT BD 2A2-A							
4A	2-MTR-30-67	EF3-A005	HI	2PL3621	#12	PASS	
* DSL AUX BD 1A1-A							
6A	1-MTR-30-463	EF3-A005	HI	PL2235	#12	PASS	
* DSL AUX BD 1A2-A							
6A	0-MTR-30-470	EF3-A005	4	PL2572	#12	PASS	
* DSL AUX BD 1B1-B							
6A	1-MTR-30-465	EF3-A005	HI	PL2249	#12	PASS	
* DSL AUX BD 2A1-A							
6A	2-MTR-30-464	EF3-A005	HI	PL2242	#12	PASS	
* DSL AUX BD 2B1-B							
6A	2-MTR-30-466	EF3-A005	HI	PL2255	#12	PASS	
* DSL AUX BD C2-S							
CA	0-MTR-30-329			PL3300	#12	PASS	SHAWMUT TRS1.5R 1.5A FUSES
EA	0-MTR-30-327			PL3316	#12	PASS	SHAWMUT TRS3R 3A FUSES

ATTACHMENT NO. M10448A - SECTION A  
WBN EEB-MS-TI15-0011  
480V CLASS 1E MOTOR CONTROL CENTERS  
NON-CLASS 1E CIRCUITS

COMPUTED YMB DATE 6-13-90  
CHECKED EH DATE 6/19/90

CMPT	LOAD	BKR TYPE	BREAKER SETTING	CABLE NO	CABLE SZ	CABLE PROT	NOTES
* RMOV BD 1A1-A							
16A	1-MTR-31-265	EF3-A010	4	1PL6300	#10	PASS	
16F2	1-MTR-31-303/2	EF3-B020		1PL6289	#10	PASS	
18C	1-MTR-31-303/1	EF3-A010	4	1PL6281	#12	PASS	
* RMOV BD 1B1-B							
16A	1-MTR-31-266	EF3-A010	4	1PL6310	#10	PASS	
17F2	1-MTR-31-324/2	EF3-B020		1PL6291	#10	PASS	
18C	1-MTR-31-324/1	EF3-A010	4	1PL6285	#10	PASS	
* RX VENT BD 1A-A							
5A	0-MTR-31-406	EF3-A005	3	1PL644	#12	PASS	
6A	0-MTR-31-25	EF3-A010	4	1PL735	#12	PASS	
9B	1-MTR-30-95	EF3-A025	LO	1PL520	#10	PASS	
				1PL521	#12		
10B	1-MTR-30-99	EF3-A025	LO	1PL550	#10	PASS	
				1PL551	#12		
11B	0-MTR-31-497	EF3-A025	3	1PL3900	#6	PASS	
15D	0-MTR-30-1	EF3-A100	3	1PL777	#6	PASS	
16D	1-MTR-30-1E	EF3-A100	2	1PL764	#2	PASS	
* RX VENT BD 1B-B							
5E	1-MTR-30-11	EF3-A003	HI	1PL794	#12	PASS	
6A	0-MTR-31-26	EF3-A010	4	1PL752	#12	PASS	
6E	1-MTR-30-11E	EF3-A003	HI	1PL760	#12	PASS	
9B	1-MTR-30-97	EF3-A025	LO	1PL531	#10	PASS	
				1PL532	#12		
10B	1-MTR-30-100	EF3-A025	LO	1PL561	#10	PASS	
				1PL562	#12		
15D	1-MTR-30-4	EF3-A100	3	1PL785	#2	PASS	
16D	1-MTR-30-4E	EF3-A100	2	1PL768	#2	PASS	
* RX VENT BD 2B-B							
11B	0-MTR-31-498	EF3-A025	3	2PL3901	#6	PASS	
* RMOV BD 1A1-A							
17A	1-HTR-62-228/2	EF3-B040		1PL6208	#8	PASS	
				6209 #10	#12		
* RMOV BD 1B1-B							
17A	1-HTR-62-228/1	EF3-B040		1PL6214	#8	PASS	
				6215 #16	#12		
* RMOV BD 2A1-A							
17	1-HTR-62-228/4	EF3-B040		2PL6208	#8	PASS	
				6209 #10	#12		

ATTACHMENT NO. M10448A - SECTION A  
 WBN EEB-MS-TI15-0011  
 480V CLASS 1E MOTOR CONTROL CENTERS  
 NON-CLASS 1E CIRCUITS

COMPUTED Temp DATE 6-13-90  
 CHECKED EJS DATE 6/13/90

CMPT	LOAD	BKR TYPE	BREAKER SETTING	CABLE NO	CABLE SZ	CABLE PROT	NOTES
**	RMOV BD 2B1-B						
17A	2-HTR-62-228/3	EF3-B040		2PL6214	#8	PASS	
				6215 & 16	#12		
**	RMOV BD 1A1-A						
18D	0-MTR-62-226	EF3-A005	4	1PL6265	#12	PASS	
**	RMOV BD 1A2-A						
4A	1-FCV-3-191	EF3-A010	4	1V3260	#12	PASS	
4B	1-FCV-3-192	EF3-A010	4	1V3280	#12	PASS	
**	RMOV BD 1B2-B						
4A	1-FCV-3-193	EF3-A010	4	1V3290	#12	PASS	
4B	1-FCV-3-194	EF3-A010	4	1V3270	#12	PASS	



ATTACHMENT NO. M08613A  
CALC NO. WBN EEB-MS-TI15-0011

Page 1  
Prpd ESH Date 6/12/90  
Chkd GP Date 6/18/90

### PURPOSE

The purpose of this Attachment is to evaluate and support modifications to be implemented under the following DCN's: M-08613-A

This Attachment evaluates the adequacy of unit 1 system group 2 protective devices for 480V power cables associated circuits as identified in Appendix F of WBN EEB-MS-TI15-0011.

This Attachment affects the following calculations:

<u>BASELINE CALCULATION</u>	<u>CALCULATION NO.</u>
480V Non-Class 1E Power Cable Associated Circuits	WBN EEB-MS-TI15-0011

### ANALYSIS

Appendix F identified that the protective devices are inadequate for the 480V power cables. The protection scheme consists of: two breakers in series or one breaker and one fuse in series or a single fuse. If this scheme protects the 480V non-Class 1E power cables associated circuits, periodic testing is not required.

To resolve the inadequacies, Appendix F was reviewed to ensure that the breakers protect the cables. If the cables are protected, the breakers are deleted from Appendix F and added to the design output document, 45B710-series for inclusion to the periodic testing program.

Prepared Amajinder Date 2/2/90 Checked TBT FOR RAB Date 2-5-90  
ELBates 2/5/90 R. Supkar 2-5-90

ATTACHMENT M08619A PAGE 2 APPENDIX F

PREP EH DATE 6/12/90  
 CHKD GP DATE 6/18/90

480V Power Cables Associated Circuits where protective devices were evaluated to be inadequate per acceptance criteria developed in Attachment 1. The protective devices are coded as "B" for a breaker and "F" for a secondary protection fuse.

480 V Bus	Compt. No.	Inadequate Protective Device	
2-BB-212-A1	2C	B	MO8619A JTB 2/12/90 REC 2/12/90
	8A	F	
2-MCC-214-A2	2D1	F	MO8619A
	6D1	F	
	2E1	F	
	6F1	F	
	7D1	F	
	3D1	F	
	3E1	F	
	3F1	F	
	3F2	F	
	4E1	F	
	4F1	F	
	5F1	F	
	5F2	F	
	6F2	F	
	7E1	F	
2-MCC-214-B1	3F2	F	
	2F1	F	
	9F1	F	
	12F1	F	
	12F2	F	
1-MCC-232-B	2A, 9B, 10B, 13B	F	MO8619A
	3B	F	
	3C	F	
	6C	B	
	6F1	F	
	7B	F	
	8B	F	
	11F	F	MO8619A JTB 2/12/90 REC 2/12/90
	12F	F	
	13B	F	
	14B	F	
15A	F		
16A	F	MO8619A	

Prepared Amgen/da Date 2/2/90 Checked TBT FOR RMB Date 2-5-90  
ElBates 2/5/90 R. Supkar 2-5-90

ATTACHMENT MO8613A PAGE 7

PREP BY DATE 6/12/90

480 V Bus Compt. No. Inadequate Protective Device CHKD BY DATE 6/18/90

1-MCC-232-A 3A, 2A, 9B, 10B F | MO8613A

- 3B F
- 3C F
- 4D B
- 7B F
- 8B F
- 10F F
- 11F F
- 13D F
- 14B F
- 14D F
- 15A F
- 16A F

JTB 2/14/90  
 REB 2/15/90

MO8613A

JTB 2/14/90  
 REB 2/15/90

2-MCC-214-A1

- 2F1 F
- 2F2 F
- 3F1 F
- 4F2 F
- 10F1 F
- 12E1 F

MO8613A

2-MCC-214-B2

- 2E1 F
- 2F1 F
- 3E1 F
- 3F1 F
- 4E1 F
- 4F1 F
- 4F2 F
- 5E1 F
- 5F1 F
- 6E1 F
- 6F1 F
- 5F2 F
- 7E1 F
- 8E2 F

MO8613A

0-MCC-208-A

- 2C F
- 6A F
- 6B F
- 7A B
- 7C B
- 8B B
- 8C B
- 8D B

JTB 2/12/90  
 REB 2/12/90

MO8613A

Prepared Amey M. Kar. Date 2/2/90 Checked TBT FOR RHR Date 2-5-90  
RLBates 2/15/90 R. Supkar 2-5-90

ATTACHMENT M08619A PAGE 4 PREP ESJ DATE 6/2/90 CHKD GP DATE 6/18/90

480 V Bus Compt. No. Inadequate Protective Device

2-MCC-232-A 3B, 2A, ~~9B, 10B~~, 10F F | M08619A  
 3C F  
 4D B  
 7B F  
 8B F  
 11D F  
 11F F  
 13B F  
 14B F  
 14D F  
 15A F  
 16A F

2/15/90  
AEO  
2/15/90

2-MCC-232-B 2A, ~~9B, 10B, 13B~~ F | M08619A  
 3A F  
 3B F  
 3C F  
 6C B  
 6F1 F  
 7B F  
 8B F  
 10F F  
 11F F  
 12F F | M08619A  
 14B F  
 15A F | M08619A  
 16A F

1-MCC-214-A2 2D1 F  
 2E1 F  
 3D1 F  
 3E1 F  
 3F1 F  
 3F2 F  
 4E1 F  
 4F1 F  
 5F1 F  
 5F2 F  
 6F2 F  
 7E1 F  
 2E2 F

M08619A

1-MCC-214-B2 2E1, 8F1 F  
 2F1 F  
 3E1 F  
 3F1 F  
 4E1 F

WBN EEB-MS-TI15-0011 R0  
 480 V Non-Class 1E Power Cable Associated Circuits

Prepared for ymuckler Date 2/2/90 Checked TBT FOR RHB Date 2-5-90  
ZLBats 2/5/90 R. Supkar 2-5-90

ATTACHMENT MO8613A PAGE 5

PRDD EJH DATE 6/12/90  
 CHKD GP DATE 6/18/90

480 V Bus Compt. No. Inadequate Protective Device

1-MCC-214-B2 (Cont.)	4F1	F	MO8613A
	4F2	F	
	5E1	F	
	5F1	F	
	6E1	F	
	6F1	F	
0-MCC-208-B	6F2	F	
	8B	B	
	8D	B	
0-MCC-216-B	4F	F	
0-MCC-217-A	3E	B	MO8613A
	4E	B	
1-MCC-210-A	3F2	B	
2-MCC-209-A	7D	B	MO8613A
0-MCC-218-1	6D	B	
0-MCC-208-C	9A	B	MO8613A
	7C1	F	
1-MCC-214-A1	2F2	F	
	3F1	F	
	3F2	F	
	5F1	F	
	10F1	F	
	12E1	F	
1-MCC-214-B1	2F2	F	
	9F1	F	
	12E1	F	
	12F1	F	
	13F1	F	
1-MCC-213-B1	16E, 16A	F	MO8613A
	17E	F	
	17A	B	
1-MCC-213-A1	17E, 16A, 16B	F	MO8613A
<del>1-BB-212-B2</del>	<del>3B</del>	<del>F</del>	

*Handwritten notes:*  
 2/15/90  
 AEB  
 2/15/90

ATTACHMENT M08613A

WBN EEB-MS-TI15-0011 RO

480 V Non-Class 1E Power Cable Associated Circuits

PAGE 6  
PRPD EJS DATE 6/12/90  
CHKD GP DATE 6/10/90

Page 195 of 200  
Page F5 of Final

Prepared Amginder Date 2/2/90 Checked TST FOR RMB Date 2-5-90  
YS Bates 2/5/90 RSUPKAR 2-5-90

480 V Bus	Compt. No.	Inadequate Protective Device
<del>2-BD-212-B2</del>	3B	F
2-MCC-213-A1	17E, 16A, 16B	F
2-MCC-213-B1	16E, 16A	F
	17E	F
	17A	B

*Handwritten notes:*  
 JTB 2/15/90  
 RCB 2/15/90  
 JTB 2/15/90  
 RCB 2/15/90  
 M08613A

WBN EEB-MS-TI15-0011 R0

Page H21 of H72

Tabulation of Non-IE Power Circuits Located in Category I Structures

Prepared by R. H. Buchert Date 1/22/90 Checked by R. S. Upkare Date 1/26/90  
R. H. Buchert 1/17/90 R. S. Upkare 1/25/90  
Libate 2/5/90 R. S. Upkare 2-5-90

O-MCC-208-A

CMT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO.
							MFR	MODEL	RATING		
6F2	0-HST-271-AB12	B040	N/A	Y40		N/A	←	N/A	→	6	PL917
7A	1 HTR-31-397	<del>A025</del> A025	HIGH	N <del>210</del> 470	2	T47	←	N/A	→	10	PL921
7C	0-MTR-31-452	H050	4	N565	2	T52	←	N/A	→	6	PL943
7D	0-MTR-31-455	H050	LD	Y320	2	T52	←	N/A	→	6	PL20
7E1	0-CHGR-240-1	B020	N/A	Y20		N/A	←	N/A	→	10	PL875
7E2	0-HST-271-AB13	B030	N/A	Y30		N/A	←	N/A	→	8	PL907
7F1	0-HST-271-AB14	B030	N/A	Y30		N/A	←	N/A	→	8 X 2	PL906
7F2	0-LAC-233-80	B050	N/A	Y50		N/A	←	N/A	→	6	PL803
8A	0-MTR-31-APA	A005	HIGH	Y41		N/A	←	N/A	→	12	PL812
8B	2-MTR-31-397	A025	HIGH	210 <sup>N</sup>	1	T47	←	N/A	→	12 10	PL2080 PL925
	2-MTR-31-396	A025	HIGH	N210	1	T47	←	N/A	→	10	PL930
	1-MTR-31-396	A025	HIGH	N210	1	T47	←	N/A	→	10	PL934
8E	0-MTR-31-BPB	A005	4	29 <sup>Y</sup>		N/A	←	N/A	→	12 12	PL816 PL2082
8F1	0-MTR-31-APOC	B020	N/A	20 <sup>Y</sup>		N/A	←	N/A	→	10	PL822
8F2	0-MTR-31-BPBC	B020	N/A	20 <sup>Y</sup>		N/A	←	N/A	→	10	PL820
9D1	0-LAC-233-90	B040	N/A	40 <sup>Y</sup>		N/A	←	N/A	→	8	PL3105
9D2	0-LAC-233-91	B040	N/A	40 <sup>Y</sup>		N/A	←	N/A	→	4	PL3106
9E1	0-LAC-233-92	B040	N/A	40 <sup>Y</sup>		N/A	←	N/A	→	2	PL3107
9E2	0-LAC-233-93	B040	N/A	40 <sup>Y</sup>		N/A	←	N/A	→	2	PL3108
9F1	0-LAC-233-94	B040	N/A	40 <sup>Y</sup>		N/A	←	N/A	→	4	PL3109
6F1	0-HTR-271-STD	B050	N/A	50 <sup>Y</sup>		N/A	←	N/A	→	6	PL980

ATTACHMENT M08613A  
CALC NO. EEB-MS-TI15-0011

Page 0  
Prpd EH Date 6/12/90  
Chkd GP Date 6/18/90

The following protective devices are to be added to the output document 45B710-series for periodic breaker testing and to be implemented on DCN M-08614-A:

<u>480V Bus</u>	<u>Board Name</u>	<u>Compt</u>
0-MCC-208-A	Aux Bldg Com MCC A	7C 8D
0-MCC-208-B	Aux Bldg Com MCC B	6F2
0-MCC-208-C	Aux Bldg Com MCC C	7C1
0-MCC-217-A	CVC Board A	3E 4E

The following are circuit breaker changes required to protect the 480V non-Class 1E power cable associated circuits:

<u>480V Bus</u>	<u>Board Name</u>	<u>Compt</u>	<u>Bkr Type</u>
0-MCC-208-A	Aux Bldg Com MCC A	7A	EF3-A025

#### CONCLUSION

This Attachment No. M08613A confirms that the protection scheme for 480V non-Class 1E power cables for associated circuits is adequate and the protective devices are periodically tested to ensure unacceptable influences to the Class 1E circuits.



PURPOSE

The purpose of this Attachment is to evaluate and support the modifications to be implemented under DCN's F-13654-A.

The modifications involve breaker replacement and/or breaker setting changes.

The following baseline calculations evaluate the DCN modifications for their impact. These evaluations are identified by the Attachment No. F13654A or the DCN is otherwise identified in the calculation.

BASELINE CALCULATION	CALCULATION NO.
480VAC 1E COORDINATION/PROTECTION.....	WBN EEB-MS-TI08-0000
480V NON-CLASS 1E POWER CABLE ASSOCIATED CIRCUITS.....	WBN EEB-MS-TI15-0011

1.0 SCOPE

This attachment evaluates new circuit breakers and settings for the following loads to ensure that the cables are adequately protected within the guidelines of the base calculation.

EQUIPMENT ID	BOARD (COMPT)	WIRE SIZE	PROT DEVICE	SETTING (RTG)
1-MTR-30-CRD	1-MCC-214-A2-A (8A)	2/0	FXD63B125	LO (800A)
0-HTR-31-421	1-MCC-214-B2-B (7D)	300	FXD63B225	3 (1500A)
1-MTR-30-CRB	1-MCC-214-A2-A (9A)	4/0	FXD63B125	LO (800A)
1-MTR-31-303/2	1-MCC-213-A1-A (16F2)	10	ED63B020	NA (20A)
1-MTR-31-324/2	1-MCC-213-B1-B (17F2)	10	ED63B020	NA (20A)

2.0 ASSUMPTIONS

See Section 2.0 of the base calculation.

3.0 REFERENCES

3.1 Calculation, 480VAC 1E Coordination/Protection,  
WBN EEB-MS-TI08-0008

4.0 DESIGN INPUT

The new circuit breakers/settings were taken from Ref. 3.1.

5.0 JUSTIFICATION OF ASSUMPTIONS

See Section 5.0 of the base calculation.

6.0 METHODOLOGY

Sheets from the base calculation pertaining to the proposed modifications were marked to show the new protective devices.

Time current plots are included to verify that the cables are adequately protected.

(See Section 10.0)

7.0 GRAPHICS

Graphics for this attachment consist of the time-current plots for the new protective devices (See Section 10.0).

8.0 SUMMARY OF RESULTS

The results of this attachment are depicted on the associated time-current plots and the marked sheets from Appendix A (See Section 10.0).

9.0 CONCLUSIONS

The new protective devices and settings adequately protect the cables.

10.0 ATTACHMENTS

Sheets from the base calculation showing proposed modifications:

SHEET	PAGE
A1	4
A3	5
A4	6
H36 (1-MCC-213-A1-A, 16F2)	7
H38 (1-MCC-213-B1-B, 17F2)	8
H42 (1-MCC-214-A2-A, 8A)	9
H45 (1-MCC-214-B2-B, 7D & 9A)	10

Time-current plots for protective devices:

DEVICE	PAGE
FXD63B125	11
FXD63B225	12
ED63B050	13

WBN EEB-MS-T115-0011R0  
480 V Power Cable Associated Circuits

Page A1 of A5

3-7-91

Prepared HA Date 2/2/90 Checked Jmz Date 2/2/90

90°C RATED CABLE PROTECTION (0-10 SEC REGION ONLY)

CABLE SIZE	MAXIMUM PROTECTIVE DEVICE RATING	REFERENCE
#14 AWG	- SQ.D - QOB-25A	TC-109 } Appendix C
	- BUSSMAN - FR515A	
	- MAG ONLY BKR SETG. PLUS TOLERANCE LOWER THAN 80A	
	- BUSSMAN - KWV 25A	
	- SHMT - A4J - 30A	
#12 AWG	- SHMT - TR5-20A	TC-64 Appendix C
	- SQD - QOB140	TC-112 } App. C
	- ITE - EF3 B030	
	- MAG. ONLY BKR SETG. PLUS TOLERANCE LOWER THAN 140A	
#10 AWG	- SHMT - TR530A	TC-38 } App. C
	- ITE - EF3B040	
	- SQ.D - QOB150	TC-117
	- MAG. ONLY BKR, SETG. PLUS TOLERANCE LOWER THAN 225A	
	- HFCP - 15A	

ED63B050

CURVE ED63B050

200  
3-7-91

WBN EEB-MS-T115-0011R0  
480 V Power Cable Associated Circuits

Prepared HA Date 2/2/90 Checked GMD Date 2/2/90  
\* TBT 2-5-90 \* JLB 2-5-90

90°C RATE CABLE PROTECTION (0-10 SEC. REGION ONLY)

CABLE SIZE	MAXIMUM PROTECTIVE DEVICE RATING	REFERENCE
# 2	- W JA 125A - W DS BKR 150A SENSOR LTDELAY @ 12 SEC. ST OR INSTANT PICK UP < 600% (THE USE OF OTHER SETTINGS SHOULD BE INVESTIGATED) - SHMT - CP6 - 4/0 - SHMT - CP6A - 2/0 - MAG ONLY BKR SETTING PLUS TOLER. LOWER THAN 1200A - SHMT - HFCP - 100A - BUSSMANN JJS 225	TC-83 } TC-6 } APP. C D-16 (APP. D)  TC-6 (APP. C)
# 1/0	- FP FUSEMATIC 100A - ITE - FJ-B125 (THE USE OF HIGHER RATED BKR SHOULD BE INVESTIGATED) - SHMT - CP6A - 4/0 - SHMT - CP6 - 350MM - MAG ONLY BKR SETG PLUS TOLERANCE LOWER THAN 2000A - BUSSMANN JJS 400	TC-4 (APP. C) TC-80 (APP. C)
	FXD63B25 @ 3	CURVE FXD63B225

WBN EEB-MST115-0011 RO  
480 V Power Cable Associated CircuitsPrepared HHA Date 2/2/90 Checked Jmz Date 2/2/90

## 90°C RATED CABLE PROTECTION (0-10 SEC. REGION ONLY)

CABLE SIZE	MAXIMUM PROTECTIVE DEVICE RATING	REFERENCE
# 2/0 AWG	<p>W DS BKR SENSOR 150A LT DELAY @ 36 SEC. INST OR SHRT TIME PU UP TO 12 TIMES SENSOR RATING (THE USE OF OTHER SETTINGS SHOULD BE INVESTIGATED)</p> <p>FXD63B125 @ HI</p>	<p>TC-91 &amp; D16 (APP.C) (APP.D)</p> <p>CURVE FXD63B125</p>
# 4/0 AWG	<p>- ITE-FJ3B225</p> <p>- W DS BKR SENSOR 300A LT DELAY @ 36 SEC INST OR SHORRTIME PU UPTO 12 TIMES SENSOR RATING (THE USE OF OTHER SETTINGS SHOULD BE INVESTIGATED)</p> <p>- SHMT-CP6A-350MCM - SHMT-CP6-750MCM - SHMT-CP-750MCM</p>	<p>TC-27 &amp; D21 (APP.C &amp; D)</p> <p>TC-7 &amp; D16 (APP.C &amp; D)</p>

WRN EEB-MS-TI15-0011 R0

Installation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R. H. Buchat Date 1/22/90 Checked R. H. Buchat Date 1/26/90  
longman 1/16/90 R. H. Buchat 1/25/90  
ElBate 2/5/90 R. Supkar 2/5/90

1-MCC-213-A1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO	
							MFR	MODEL	RATING			
		DEF3-		(A)		G30						
16A	1-PENT-293-32	A010	3	Y45 Y	1	T32	SHAW-MUT	TRS-30	Y30A N	10 12	1PL6300 1PL6301	
16B	1-PENT-293-24	A010	LO	Y27 Y	1	T27	SHAW-MUT	TRS-30	Y30A N	10 12	1PL6268 1PL6269	
16F1	0-XSW-252-1	B020	N/A	Y20	N/A	N/A	N/A	N/A	N/A	10	1PL6040	
16F2	1-TB-31-303/2	ED63 B020	N/A	Y20	N/A	N/A	N/A	N/A	N/A	10x2	1PL6289	
17A	0-JB-292-2051	B030	N/A	Y30	2	N/A	N/A	N/A	N/A	8 12 12	1PL6208 1PL6209 1PL6210	
17E	1-PENT-293-32	B100	N/A	Y100	N/A	N/A	SHAW-MUT	CPGA-197 #2	2/15/90 2/15/90 R60 N/A	2 2	1PL6100 1PL6094	
17F1	0-XSW-240-5	B020	N/A	Y20	N/A	N/A	N/A	N/A	N/A	10	1PL6060	
18C	1-MTR-31-303	A010	3	Y45	1	T32	← N/A →			12	1PL6281	
18D	0-MTR-62-226	A005	3	Y22	1	T26	← N/A →			12	1PL6265	
18F1	0-XSW-250-1	B020	N/A	Y20	←			N/A			10	PL871
18F2	1-JB-293-2859	A100	LO	Y475	←			N/A			2x2 2 2 2 2	1PL6093 1PL6101 1PL6102 1PL6103 1PL6104 1PL6106

# EXCEPT AS NOTED

Form GO-3.08.1 Rev. 2 SL-F647 04/84

PN EEB-MS-TI15-0011 R0

Installation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchart Date 1/22/90 Checked Jim J. ... Date 1/26/90  
R.H. Buchart 1/10/90 Scott Kelley 1/25/90

1-MCC-213-B1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
3F1	0-XSW-252-2	3020	N/A	Y 20			N/A			10	IPL6045
16A	1-PENT-293-35	A010	3	Y 45	1	T32	1	TR330	Y 30A N	10 12	IPL6310 IPL6311
16E	1-PENT-293-47	B100	N/A	Y 100	N/A	N/A	1	CP6A-197 #2	NY 2/15/90 REC 2/15/90	2 2	IPL6085 IPL6082
16F1	0-XSW-240-S	3020	N/A	Y 20			N/A			10	IPL6061
17A	0-JB-292-2048	3040	N/A	Y 40 N N	2		N/A			8 12 12	IPL6214 IPL6215 IPL6216
17E	1-PENT-293-35	B100	N/A	Y 100	N/A	N/A	1	CP6A-197 #2	NY 2/15/90 REC 2/15/90	2x2 2	IPL6075 IPL6076
17F1	0-XSW-240-1	3020	N/A	Y 20			N/A			10	PL876
17F2	1-TB-31-324/2	EDG3 3020	N/A	Y 20			N/A			10	IPL6291
18C	1-MTR-31-324/1	A010	3	Y 45	1	T32		N/A		10	IPL6285
18D	0-MTR-84-2	A005	3	Y 22	1	T26		N/A		12	IPL6273

\* EXCEPT AS NOTED

Form GO-308.1 Rev. 2 SL-F647 04/84



UBN EEB-MS-TI15-0011 R0

Page H42 of H72

Location of Non-IE Power Circuits Located in Category 1 Structures

Prepared Amynudar Date 1/22/90 Checked R.H. Buchart Date 1/26/90  
Amynudar 1/16/90 R.H. Buchart 1/25/90

1-MCC-214-AZ

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
4F1	1-HTR-30-CCRD	B020	N/A	20	N/A	N/A	1	DISA030	N 30A	10	IPL3268
5A	1-MTR-30-301	A010	3	45	1	T34	← N/A →			12	IPL3435
5E1	0-HTR-31-83	B030	N/A	30	N/A	N/A	1	DISA030	Y 30A	8	IPL3707
5F1	1-HTR-30-XMIA	B020	N/A	20	N/A	N/A	1	DISA030	N 30A	10	IPL3370
5F2	1-HTR-30-AB1	B020	N/A	20	N/A	N/A	1	DISA030	N 30A	10	IPL3314
6E1	1-HTR-30-SMS	B030	N/A	30	N/A	N/A	1	DISA030	Y 30A	8	IPL2811
6E2	1-HTR-30-NM1	B050	N/A	50	N/A	N/A	1	DISA050	Y 50A	6	IPL2806
6F2	0-HTR-30-RM1	B020	N/A	20	N/A	N/A	1	DISA030	N 30A	10	IPL3320
7D2	0-HTR-30-AFH	B040	N/A	40	N/A	N/A	1	DISA050	Y 50A	6	IPL3335
7E1	1-HTR-30-UIA	B020	N/A	20	N/A	N/A	1	DISA030	N 30A	10	IPL2813
7E2	0-HTR-30-BFH	B040	N/A	40	N/A	N/A	1	DISA050	Y 50A	6	IPL3330
7F2	0-HTR-30-CFH	B040	N/A	40	N/A	N/A	1	DISA050	Y 50A	6	IPL3340
8A	1-MTR-30-CRD	<del>F33</del> B125		LO 1800 1600	N/A	N/A	← N/A →			2/0	IPL3692
8B	1-HTR-1-CBS	FJ3 B125	LI	1500	N/A	N/A	← N/A →			4/0	IPL3680

\* EXCEPT AS NOTED

Form GO-3.08.1 Rev. 2 SL-F647 04/84

WBN EEB-MS-TI15-0011 R0

Page H45 of H72

Compilation of Non-IE Power Circuits Located in Category 1 Structures


Prepared Amjadur Date 1/22/90 Checked R.H. Bucher Date 1/20/90  
R.H. Bucher 1/17/90 Zsuzsanna Kelley 1/25/90  
YlBate 2/5/90 RSupkarc 2-5-90


1-MCC-214-B2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		*EF3-		(A)		G30	MFR	MODEL	RATING		
5F1	0-HTR-30-RM2	B020	N/A	Y 20	N/A	N/A	1	DISA030	N 30A	10	IPL3385
6B	1-MTR-30-26	A010	3	Y 45	1	T32	← N/A →			12	IPL2913
6E1	1-HTR-30-AB7	B020	N/A	Y 20	N/A	N/A	1	DISA030	N 30A	10	IPL3381
6F1	1-HTR-30-T1B	B020	N/A	Y 20	N/A	N/A	1	DISA030	N 30A	10	IPL3430
7D	0-HTR-31-421	FXD63 F33 B225	3 HE	Y 1500 2000	N/A	N/A	← N/A →			300	IPL3440
7E2	0-HTR-31-72	EF3- B030	N/A	Y 30	N/A	N/A	1	DISA030	Y 30A	8	IPL2977
7F1	1-HTR-30-NM2	B050Z	N/A	Y 50	N/A	N/A	1	DISA050	Y 50A	6	IPL3421
8F1	0-TB-31-494	B040	N/A	Y 40 Y	N/A	N/A	1	DISA050	Y 50A N	6 10 10	IPL6470 IPL6473 IPL6474
8F2	1-PO-214-10	B100	N/A	Y 100	N/A	N/A	1	DISA3100	Y 100A	2	IPL2785
9A	1-MTR-30-CRB	FXD63 F3 B125	LO	Y 800 750	N/A	N/A	← N/A →			4/0	IPL3671

\*EXCEPT AS NOTED

Form GO-3.08.1 Rev. 2 SL-F647 04/84






DRAWING FWD63B225

PLOT ELL: 480

SCALE: 10^1



PURPOSE

The purpose of this Attachment is to evaluate and support modifications to be implemented under DCN's C-03205-A and M-09494-A.

Modifications involve splicing of cables with a different cable mark number/size (DCN C-03205-A) and redesignating 480V Control & Auxiliary Building Vent Board 1B2-B compartment 7D to 7C (DCN M-09494-A).

Since different aspects of a design modification are evaluated or determined in various calculations other calculations may have also been issued to evaluate/support a particular feature. For identification of all calculations and revisions issued to support the modification(s), see the applicable DCN package.

1.0 SCOPE

This attachment documents data for cables 1PL486 and 1PL497 which are being spliced with a different mark number and conductor size per DCN C-03205-A and documents the compartment number change (7D to 7C) on 480V Control and Auxiliary Building Vent Board 1B2-B.

2.0 ASSUMPTIONS

See "Assumptions" in the base calculation (Section 2.0).

3.0 SOURCES OF DESIGN INPUT / REFERENCES

3.1 DCN C-03205-A Cable design review sheets

3.1 DCN M-09494-A Cover sheet

4.0 DESIGN INPUT DATA

Input data consists of the cable data taken from Ref. 3.1 (See Section 10.0) which shows the conductor sizes as a #4 (WFA-16) spliced to #8 (WDD-2) for the subject cables and Ref. 3.2.

5.0 JUSTIFICATION OF ASSUMPTIONS

See "Justification of Assumptions" in base calculation (Section 5.0).

6.0 METHODOLOGY

6.1 DCN C-03205-A

The methodology for this attachment is similar to that used in the Revision 0 of the base calculation. The cable sizes were shown on the applicable sheets of Appendix H along with their protective devices. The cable sizes and protective devices were compared to the acceptance criteria of Appendix A which notes the maximum protective device(s) for a given conductor size. Acceptable/unacceptable cable protection was noted in Appendix H by either a "Y" or "N" (See Section 10.0)

6.2 DCN M-09494-A

The methodology involved documenting the revised compartment number.

7.0 GRAPHICS

Graphics consists of the applicable time-current plots in the base calculation (Appendix C).

8.0 SUMMARY OF RESULTS

Cable 1PL486 is adequately protected by both the fuse (TRS-60) and the circuit breaker (EF3-B030).

Cable 1PL497 is adequately protected by the fuse (TRS-60) but not by the circuit breaker (EF3-B100).

9.0 CONCLUSIONS

Cable protection is adequate since the cables are not required to be protected by both of the protective devices in the circuits.

10.0 ATTACHMENTS/ADDITIONAL DATA

	PAGE
Cable Design Review Sheet - 1PL486.....	4
Cable Design Review Sheet - 1PL497.....	6
Baseline calculation Appendix H Sheet H51.....	8
Baseline calculation Appendix H Sheet H53.....	9
DCN M-09494-A.....	10
Baseline calculation Appendix H Sheet H45.....	11



WATTS BAR NUCLEAR PLANT CABLE ROUTING SYSTEM

WBN EEB-MS-TI/5-0011  
ATTACHMENT C03205A  
/M04494A  
PAGE 4

CABLE DESIGN REVIEW SHEET

CABLE ID: L 486 SEP SET 1\*2 REV R08 NV 4 SYS 77 FNODE 0 TNODE 0 APX-R N 50.49 N

CABLETYP WFA-16 NC1 1 NC2 3C MCM/AWG 4 DIA 0.942 CSA 0.697 WT/FT 0.835

TEMP PULL RAD 0.000 TRAIN RAD CONTRACT 745568 BIND/TEMP

FROM ID: 1-PENT-293-24 TO ID: 1-MTR-77-4 LOC/ELEV: R2238 / 730RM: R2270 / 703RM:

FROM DWG: 10002-02-1-24 TO DWG: 45W1755-1

FOR: RC DR TK PMP A SUPPLY ECN: DCN: C03205

AUTO-SIZING DATA

AC/DC: AC AMP: 9. MAX-VD: MIN NC1: LOAD: M VDROP:

ROUTING INFORMATION

CN LENGTH 72 N/R LENGTH 7 TRAY LENGTH COND LENGTH 65 INST LENGTH

CONDUITS: 1PLC1032

TRAY NODES:

RECORD STATUS INFORMATION

VERIF STATUS : V VERIFIED BY : DAH VERIF DATE : 901119  
ROUTING STATUS: H ROUTING PRITY: 2 UPDATE DATE: 901119

REVIEW SIGNATURES

DESIGNER: Compton DATE: 11-20-90 CHECKER: \_\_\_\_\_ DATE: \_\_\_\_\_

CABLE DESIGN REVIEW SHEET

CABLE ID    SEP    SET    REV    NV    SYS    FNODE    TNODE    AFX-R    50.49  
L    486    2\*2    R08    4    77    0    0    N    N

CABLETYP    NC1    NC2    MCM/AWG    DIA    CSA    WT/FT  
WDD-2    3    1C    8    0.291    0.067    0.093

TEMP    PULL RAD    TRAIN RAD    CONTRACT    BIND/TEMP  
          0.000                      74556B

FROM ID: 1-PENT-293-24                      LOC/ELEV: RZ239 /                      730RM:  
TO    ID: 1-MTR-77-4                          LOC/ELEV: RZ270 /                      703RM:

FROM DWG: 10002-02-1-24                      TO DWG: 45W1755-1

FOR: SPLICE AT JB 6400                          ECN:                                      DCN: C03205

AUTO-SIZING DATA

AC/DC: AC    AMP: 9.    MAX-VD:                      MIN NC1:                      LOAD: M    VDROP:

ROUTING INFORMATION

CABLE LENGTH    N/R LENGTH    TRAY LENGTH    COND LENGTH    INST LENGTH  
11                      7                                      4

CONDUITS: 1PLC3953

TRAY NODES:

RECORD STATUS INFORMATION

VERIF STATUS : V                              VERIFIED BY : DAH                              VERIF DATE : 901119  
ROUTING STATUS: H                              ROUTING PRIRTY: 2                              UPDATE DATE: 901119

REVIEW SIGNATURES

DESIGNER: *Omig mioson*    DATE: 11-20-90    CHECKER : \_\_\_\_\_    DATE: \_\_\_\_\_

CABLE DESIGN REVIEW SHEET

BLE ID SEP SET REV NV SYS FNODE TNODE AOX-D 50.49  
L 497 1\*2 R05 4 77 0 0 N N

CABLETYP NC1 NC2 MCM/AWG DIA CSA WT/FT  
WFA-16 1 3C 4 0.942 0.697 0.835

TEMP PULL RAD TRAIN RAD CONTRACT BIND/TEMP  
0.000 74556B

FROM ID: 1-PENT-293-11 LOC/ELEV: RZ248 / 716RM:  
TO ID: 1-MTR-77-6 LOC/ELEV: RZ277 / 703RM:

FROM DWG: 10001-01-1-11 TO DWG: 45W1756-1

FOR: RC DR TK PMP B SUPPLY ECN: DCN: C03205

AUTO-SIZING DATA

AC/DC: AC AMP: 18. MAX-VD: MIN NC1: LOAD: M VDROP:

ROUTING INFORMATION

GN LENGTH N/R LENGTH TRAY LENGTH COND LENGTH INST LENGTH  
122 7 115

CONDUITS: 1PLC1036

TRAY NODES:

RECORD STATUS INFORMATION

VERIF STATUS : V VERIFIED BY : DAH VERIF DATE : 901119  
ROUTING STATUS: H ROUTING PRIRTY: 2 UPDATE DATE: 901119

REVIEW SIGNATURES

DESIGNER: Olmg DATE: 11-20-90 CHECKER: \_\_\_\_\_ DATE: \_\_\_\_\_

WATTS BAR NUCLEAR PLANT CABLE ROUTING SYSTEM

WBN ECR-MS-TI15-0011  
ATTACHMENT C03205A  
PAGE 7 1M09444

CABLE DESIGN REVIEW SHEET

CABLE ID    SEP    SET    REV    NV    SYS    FNODE    TNODE    APX-R    50.49  
1PL    497    2\*2    R05    4    77    0    0    N    N

CABLETYP    NC1    NC2    MCM/AWG    DIA    CSA    WT/FT  
WOD-2    3    1C    8    0.291    C.057    0.093

TEMP    PULL RAD    TRAIN RAD    CONTRACT    BIND/TEMP  
    0.000       745568   

FROM ID: 1-PENT-293-11    LOC/ELEV: RZ248 /    716RM:  
TO ID: 1-MTR-77-6    LOC/ELEV: RZ277 /    703RM:

FROM DWG: 10001-01-1-11    TO DWG: 45W1756-1

FOR: SPLICE AT JB 6400    ECN:    OCN: C03205

AUTO-SIZING DATA

AC/DC: AC    AMP: 18.    MAX-VD:    MIN NC1:    LOAD: M    VDROP:

ROUTING INFORMATION

GN LENGTH    N/R LGTH    TRAY LENGTH    COND LENGTH    INST LENGTH  
11    7       4

CONDUITS: 1PLC3954

TRAY NODES:

RECORD STATUS INFORMATION

VERIF STATUS : V    VERIFIED BY : DAH    VERIF DATE : 901119  
ROUTING STATUS: H    ROUTING PRITY: 2    UPDATE DATE: 901119

REVIEW SIGNATURES

DESIGNER: *Quinn*    DATE: 11-20-90    CHECKER:    DATE:

Page 179 of 200  
Page 180 of 201  
Page 179 of 200  
3-7-91

WBN EEB-MS-TI15-0011 R0

Page H51 of H72

Location of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buckert Date 1/22/90 Checked knymuder Date 1/26/90  
knymuder 1/16/90 R.H. Buckert 1/25/90  
ZUBats 2/5/90 R. Supkar 2/5/90

1-MCC-232-A

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		EF3-		(A)		G30	MFR	MODEL	RATING		
9B	1-PENT-293-32 FAN A	A025	LO	Y 75 Y	1	T40	SHAW-MNT	TRS-30	Y 30 N	10x2 12	IPL520 IPL521
9F2	1-JB-292-1869	B100	N/A	Y 100	N/A	N/A	SHAW-MNT	DISAB100	Y 100	2	IPL250, 251-253
10B	1-PENT-293-24 FAN C	A025	2	Y 105 Y	1	T40	"	TRS-30	Y 30 N	10x2 12	IPL550 IPL551
10F	1-PENT-293-32 STUD	B020	N/A	Y 20 Y	N/A	N/A	"	DISA030	N 30 N	10 12	IPL270 IPL271
11D	1-PENT-293-24 RCDT A	B030	N/A	Y 30 Y	2	T45	"	TRS-60	Y 60 Y	8 8,4	IPL485 IPL486
11F	1-PENT-293-32 HTR A	B020	N/A	Y 20	N/A	N/A	"	DISA030	N 30	10	IPL336
12F	1-PENT-293-32 HTRA	B020	N/A	Y 20	N/A	N/A	"	"	Y 30	10	IPL337
13A	1-PENT-293-5	B040	N/A	Y 40	N/A	N/A	"	DISA050	Y 50	10	IPL5440 IPL5441
13D	1-PENT-293-5	FJ3-B175	HI	Y 1600 N	N/A	N/A	SHAW-MNT	CPGA-14 4/0	Y 215/60 Y 215/100	6 6 4/0x2 2/0	IPL621 IPL622 IPL820 IPL821
14B	1-PENT-293-5	EF3-A010	2	Y 36	1	T29	"	TRS-30	N 30	12	IPL587 IPL588
14D	1-PENT-293-5	FJ3-B150	HI	Y 1600 Y	N/A	N/A	SHAW-MNT	CPGA-14 4/0	Y 215/60 Y 215/100	12 12 4/0 2/0	IPL861 IPL862
15A	1-PENT-293-32 (1-HTR-30-35H)	EF3-B070	N/A	Y 70	N/A	N/A	"	DISAB100	N 100	4 4	IPL425 IPL426
15D	1-MTR-30-1	B100	N/A	Y 100	3	T56	N/A	N/A	N/A	2x2	IPL777
16A	1-PENT-293-5	B070	N/A	Y 70	N/A	N/A	SHAW-MNT	DISAB100	N 100	4 4	IPL440 IPL441
16D	1-MTR-30-IE	A100	3	Y 760	3	T56	N/A	N/A	N/A	2	IPL764

Form GO-3.08.1 Rev. 2 SL-F647 04/84

R9

WRN EEB-MS-TI15-0011 R0

Page H53 of H72

Location of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchert Date 1/22/90 Checked Kingmucker Date 1/26/90

Kingmucker  
LLBates

1/16/90  
2/5/90

R.H. Buchert 1/25/90  
R. Supkar 2-5-90

1 - MCC-232-B

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
10B	1-PENT-293-47	A025	2	Y 105	1	T40	SHAQ-MNT	TRS-30	Y 30 N	10 12	IPL561 IPL562
10F	1-PENT-293-11	B020	N/A	Y 20	N/A	N/A	"	"	Y 30	10 10	IPL707 IPL708
11D	1-PENT-293-11	B100	N/A	Y 100	2	T49	"	TRS-60	Y 60 Y N	4 4, #8	IPL496 IPL497
11F	1-PENT-293-35	B020	N/A	Y 20	N/A	N/A	"	DISA030	N 30	10 10	IPL345 IPL346
12F	1-PENT-293-35	B020	N/A	Y 20	N/A	N/A	"	"	N 30	10 10	IPL5450 IPL5451
13B	1-PENT-293-11	A010	2	Y 36	1	T29	"	TRS-30	Y 30 N	10 12	IPL598 IPL599
13D	1-PENT-293-11	F33-B175	HI	Y 1600	N/A	N/A	"	CP6A-14 4/0	Y 4/0 N Y REE 4/0 2/0 2/0	4/0	IPL897 IPL975 IPL902
13F	1-PENT-293-11	EF3-B050	N/A	Y 50	N/A	N/A	"	DISA050	Y 50	6 6	IPL712 IPL713
14B	1-PENT-293-11	A003	LO	Y 7	1	T12	"	TRS-30	N 30	12 12	IPL1100 IPL1101
14D	1-PENT-293-11 (AHU)	F33-B150	HI	Y 1600	N/A	N/A	"	CP4/0 -CS	Y 4/0	4/0 2/0 2/0	IPL937 IPL938 IPL943
14F	1-PENT-293-11	EF3-B040	N/A	Y 40	N/A	N/A	"	DISA050	Y 50	6 6	IPL704 IPL705
15A	1-PENT-293-35	B070	N/A	Y 70	N/A	N/A	"	DISA100	N 100	4 4	IPL454 IPL455
15D	1-MTR-30-4	A100	3	Y 760	3	T57	N/A	N/A	N/A	2	IPL785
16A	1-PENT-293-47	B070	N/A	Y 70	N/A	N/A	SHAQ-MNT	DISA100	N 100	4 4	IPL468 IPL469
16D	1-MTR-30-4E	A100	3	Y 760	3	T57	N/A	N/A	N/A	2	IPL768

\* IPL 902 → IPL 907 (2/0) → IPL 912 (3/4) → IPL 917 (2/6) → IPL 922 (2/6) → IPL 927 (2/6) → IPL 932 (2/6)  
\*\* IPL 943 → IPL 948 (2/0) → IPL 953 (3/6) → IPL 958 (2/6) → IPL 963 (2/6) → IPL 968 (2/6)

Form GO-3.08.1 Rev. 2 SL-F647 04/84

ISSUE RIMS

CLOSURE RIMS

DESIGN CHANGE NOTICE  
DIVISION OF NUCLEAR ENGINEERING

DCN NO. **MS-09494A**  
PAGE 1 OF 11  
REASON CODE **NA**  
*NA 4/17/90*

PLANT/PROJECT AND UNIT **WATTS BAR NUCLEAR PLANT UNIT-0**

C.O NO **NA** AREA/BLDG LOC **6 AUX BLDG A3R, EL757** EQUIP. I.D NO (S)/SYS CODE(S) **7 1-MCC-214-B2-B / 214, 31**

REFERENCE DOCUMENTS **45W756-8 RL, 45W1773-2RG, 43B1773-7D RC, 45B1773-0RB, 45NP756-43R4** SUPPLIER (OR SUBSUPPLIER) NAME **NA**

DESCRIPTION SUMMARY **10 DRAWING DISCREPANCY WITH BKR LOCATION** REMARKS **11 NA**

DESCRIPTION OF PROBLEM/REQUESTED CHANGE  
**NUCLEAR ENGINEERING (NE) DRAWINGS SHOW 1-MCC-214-B2-B COMPT 7C AS A FUTURE AND 1-MCC-214-B2-B, COMPT 7D CONTAINING 225A CIRCUIT BREAKER. THE AS FOUND CONDITION SHOWS NO FUTURE COMPT AND THE 225A CIRCUIT BREAKER ENCOMPASSING BOTH COMPT 7C & 7D AS ONE COMPT AND SHALL BE MARKED COMPT 7C. NEED TO CHANGE NE DRAWINGS, CABLE SCHEDULE AND CALCULATIONS TO SHOW CORRECT COMPT NO.**

JUSTIFICATION/REASON FOR CHANGE **12 TO CORRECT BREAKER COMPARTMENT LOCATION ON DRAWINGS IN ORDER TO COMPLETE MR A-658562** CCB APPROVAL **15A** DATE **4/25/90**  
*John*  
**PWL BP**

REQUESTED BY **13** ORGANIZATION **14 ROBERT M. NIMETZ** EXT. **1062** DATE **4/14/90** NEED DATE **7/2/90** REVIEWED BY **C.C. Lyke** DATE **4/17/90**

PROBLEM SOLUTION/APPROVED CHANGE (INCLUDE BASIS FOR APPROVAL)  
**(SEE ATTACHED PAGE 2 FOR CONTINUATION OF BLOCK 16)**

RIMS NO. B26901121308

AFFECTED DOCUMENT NOS. <b>17 (SEE PAGE 3)</b>	TYPE	STATUS	CIVIL ISSUES? <b>18</b> <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	ENVIRONMENTAL? <b>19</b> <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	APPENDIX R IMPACT? <b>20</b> <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
			SAFETY RELATED? <b>21</b> <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	SAR CHANGE? <b>22</b> <input type="checkbox"/> YES <input type="checkbox"/> NO	ALARA IMPACT? <b>23</b> <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
			ANSWERED BY (RESP. ENGR.)	DATE	<b>30</b>
			RESP. LEAD ENGR.	DATE	<b>31</b>
			OTHER	DATE	DESIGN VERIFICATION
			OTHER	DATE	WORK COMPLETION <input type="checkbox"/> NWR
			OTHER	DATE	<b>33</b>
			QA	DATE	INSP. REPORT NO & SIG
			OTHER	DATE	<b>34</b>
			PROJ. ENGR.	DATE	FINAL WORK TRACKING CLOSURE
			OTHER	DATE	<b>35</b>

STATUS  
 CI-CHANGE TO BE INCORPORATED  
 CH-CHANGE NOT TO BE INCORPORATED  
 IC-NO CHANGE-INFO ONLY  
 RL-RELATED DOCUMENT-FOR REFERENCE

BN EEB-MS- T115-0011 R0

Page H45 of H72

Installation of Non-IE Power Circuits Located in Category 1 Structures

Prepared Amjadur Date 1/22/90 Checked R.H. Buchert Date 1/20/90  
R.H. Buchert 1/17/90 Eric H. Kelley 1/25/90  
Albates 2/5/90 RSupkani 2-5-90

1-MCC-214-B2

COMPT NO	SERVICE	BKR	SET	TRIP	STR	DL	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		TYPE	POS	RATING	SIZE	HTR	CAT#	MFR	MODEL		
5F1	0-HTR-30-RM2	B020	N/A	Y 20	N/A	N/A	1	DISA030	N 30A	10	IPL3385
6B	1-MTR-30-26	A010	3	Y 45	1	T32	← N/A →			12	IPL2913
6E1	1-HTR-30-AB7	B020	N/A	Y 20	N/A	N/A	1	DISA030	N 30A	10	IPL3381
6F1	1-HTR-30-T1B	B020	N/A	Y 20	N/A	N/A	1	DISA030	N 30A	10	IPL3430
7C	0-HTR-31-421	FJ3- B225	HI	Y 2000	N/A	N/A	← N/A →			300	IPL3440
7E2	0-HTR-31-72	EF3- B030	N/A	Y 30	N/A	N/A	1	DISA030	Y 30A	8	IPL2977
7F1	1-HTR-30-NM2	B050Z	N/A	Y 50	N/A	N/A	1	DISA050	Y 50A	6	IPL3421
8F1	0-TB-31-494	B040	N/A	Y 40	N/A	N/A	1	DISA050	Y 50A N	6 10 10	IPL6470 IPL6473 IPL6474
8F2	1-PO-214-10	B100	N/A	Y 100	N/A	N/A	1	DISA3100	Y 100A	2	IPL2785
9A	1-MTR-30-CRB	FJ3- B125	LO	Y 750	N/A	N/A	← N/A →			4/0	IPL3671

10-308.1 Rev. 2 SL-F647 04/84



TABLE OF CONTENTS

	<u>Page No.</u>	<u>Number of Pages</u>
-- Table of Contents	1	1
1.0 Purpose & Scope	2,3	2
2.0 Criteria	3	-
3.0 Assumptions	3	-
4.0 References	3	-
5.0 Design Input Data	3	-
6.0 Computation/Analysis	3	-
7.0 Summary of Calculation Results	3	-
8.0 Conclusions	3	-
0 Appendix - Tabulation of Non-1E Power Circuits Located in Category 1 Structures		1

This Attachment Package contains 4 total pages.

1.0 PURPOSE AND SCOPE

1.1 Purpose

The purpose of this attachment is to evaluate and support the modifications to be implemented under ECN 6670.

This attachment documents the roll-up of mini calculation no. WBPE0318808039, which affects all the baseline calculations shown below. The attachment is tailored to the specific baseline calculation shown in the heading above.

Baseline Calculations

Calculation No.

480V NON 1E (RG 1.75)

WBN EEB-MS-TI15-0011

TELAS

WBN EEB-MS-TI05-0001

1.2 Scope

The scope of this attachment is to analyze short circuit current, for the 480V Non-Class 1E power cables PL6340 and PL6341.

2.0 CRITERIA

See Baseline Calculation

3.0 ASSUMPTIONS

See Baseline Calculation

4.0 SOURCE OF DESIGN INPUT REFERENCES

4.1 480V AC 1E Coordination/Protection calculation WBN-EEB-MS-TI08-0008

4.2 Departmental Guidelines for Electrical Mini Calculation Roll-up, ELEC-004. dated 4-30-91 WPH 7-31-91 BF 7-31-91

4.3 ECN 6670 (RIMS # B26 900920 816)

4.4 Calc. #WBPE0318808040 RO.

5.0 DESIGN INPUT DATA

The design input data consists of the following: Protective device data was taken from Reference 4.4.

6.0 COMPUTATION/ANALYSIS

See Appendix

7.0 SUMMARY OF CALCULATION RESULT

See Appendix

8.0 CONCLUSION

The settings are acceptable since they do not exceed the criteria for the maximum protective device rating for a #8 AWG cable. (Established in Rev. 0 of the baseline calculation Appendix A Page A2)

9.0 APPENDIX

Tabulation of Non-1E Power Circuits located in Category 1 Structures.

Appendix

Tabulation of Non-1E Power Circuits Located in Category 1 Structures

COMPT. NO.	SERVICE	BKR	Set	TRIP	STR	OL HTR	SECONDARY PROTECTION			CABLE SIZE	CABLE NO.
		TYPE	POS	RATING	SIZE	CAT #	MFG	MODEL	RATING		
		EF3		(A)		G30					
1-MCC-209-C/5F1	0-ACU-31-5301	B015	N/A	15	N/A	N/A	N/A	N/A	N/A	8	PL6340
2-MCC-209-C/5F1	0-ACU-31-5302	B020	N/A	20	N/A	N/A	N/A	N/A	N/A	8	PL6341

Prepared by B Fitzgerald Date 7-31-91

Checked by WPH Date 7-31-91

Sheet 1

TABLE OF CONTENTS

		<u>Page No.</u>	<u>Number of Pages</u>
--	Table of Contents	1	1
1.0	Purpose & Scope	2,3	2
2.0	Criteria	3	-
3.0	Assumptions	3	-
4.0	References	3	-
5.0	Design Input Data	3	-
6.0	Computation/Analysis	3	-
7.0	Summary of Calculation Results	3	-
8.0	Conclusions	3	-
9.0	Appendix - Tabulation of Non-1E Power Circuits Located in Category 1 Structures	4	1

This Attachment contains 4 total pages.

Prepared by B. Fitzgerald Date 7-31-91  
Checked by WJH Date 7-31-91

Sheet 2

1.0 PURPOSE AND SCOPE

1.1 Purpose

The purpose of this attachment is to evaluate and support the modifications to be implemented under DCN P-00972-B.

This attachment documents the roll-up of mini calculation no. WBPE0448805054, which affects all the baseline calculations shown below. The attachment is tailored to the specific baseline calculation shown in the heading above.

Baseline Calculations

Calculation No.

480V NON 1E (RG 1.75)

WBN EEB-MS-TI15-0011

TELAS

WBN EEB-MS-TI05-0001

1.2 Scope

The scope of this attachment is to analyze protective devices for the 480V Non-Class 1E power cables 1PL1365, 1PL1375, 1PL1370 and 1PL1380.

2.0 CRITERIA

See Baseline Calculation

3.0 ASSUMPTIONS

See Baseline Calculation

4.0 SOURCE OF DESIGN INPUT/REFERENCES

4.1 Calc. #WBPE0448806001 R0.

4.2 Departmental Guidelines for Electrical Mini Calculation Roll-up, ELEC-004. (Dated April 30, 1991)

4.3 DCN P-00972-B

5.0 DESIGN INPUT DATA

The design input data consists of the following: Protective device data was taken from Reference 4.3.

6.0 COMPUTATION/ANALYSIS

See Appendix

7.0 SUMMARY OF CALCULATION RESULT

See Appendix

8.0 CONCLUSION

The settings are acceptable since they do not exceed the criteria for the maximum protective device ratings for #4 & #8 AWG cable. (Established in Rev. 0 of the baseline calculation Appendix A Page A2)

9.0 APPENDIX

Tabulation of Non-1E Power Circuits located in Category 1 Structures.

Prepared by B. Fitzgerald Date 7-31-91  
 Checked by WJH Date 7-31-91

Sheet 4

Appendix

Tabulation of Non-1E Power Circuits Located in Category 1 Structures

COMPT. NO.	SERVICE	BKR	Set	TRIP	STR	OL HTR	SECONDARY			CABLE SIZE	CABLE NO.
		TYPE	POS	RATING	SIZE	CAT #	PROTECTION				
		EF3		(A)		G30	MFG	MODEL	RATING		
1-MCC-210-A/7A	1-MTR-44-61	L050	2	210	2	T48	N/A	N/A	N/A	4	1PL1365
1-MCC-210-A/7B	1-MTR-44-68	A025	3	125	1	T41	N/A	N/A	N/A	8	1PL1375
1-MCC-210-B/7A	1-MTR-44-87	L050	2	210	2	T48	N/A	N/A	N/A	4	1PL1370
1-MCC-210-B/7B	1-MTR-44-81	A025	3	125	1	T41	N/A	N/A	N/A	8	1PL1380



Prepared by J. J. J. J. Date 06-17-91

Checked by B. Fitzgerald Date 6-17-91

Page 1

TABLE OF CONTENTS

<u>Section</u>	<u>Description</u>	<u>Page No.</u>	<u>Number of Pages</u>
--	Table of Contents	1	1
1.0	Purpose & Scope	2,3	2
2.0	Assumptions	3	-
3.0	Source of Design Input Information (References)	3	-
4.0	Design Input Data	3	-
5.0	Documentation of Input/Assumptions	4	1
6.0	Computation/Analysis	4	-
7.0	Supporting Graphics	5	-
8.0	Summary of Results	5	1
9.0	Conclusion	5	-
10.0	Appendices	-	-
	Appendix A - Field Verification Data Sheet	6-8	3
	Appendix B - Page 170 of 200 (Appendix H, Page H42 of H72) of Baseline Calculation	9	1

This attachment contains 9 pages.

Prepared by Jonathan Date 06-17-91

Checked by Brian Fitzgerald Date 6-17-91

1.0 PURPOSE AND SCOPE

1.1 Purpose

The purpose of this attachment is to evaluate and support the modifications to be implemented under DCN P-03437-A. Drawings 45B1773-7D R0, 45B1773-9A R1, 45B1771-8B R1, 45W756-8 R12, 45W756-7 R17 and 45W756-4 R11 need to be revised to specify breaker trip settings.

This attachment (protection trip setting calculation is documented in mini calculation No. WBPE0018906004) affects the baseline calculations shown below. This attachment is tailored to the specific baseline calculation shown in the heading above.

Baseline Calculation

Calculation No.

~~480V AC 1E COORDINATION/PROTECTION~~

~~WBN-EEB-MS-TI08-0008~~

J.H.H. 06-20-91

480V NON-CLASS 1E POWER CABLE  
ASSOCIATE CIRCUITS (RG1.75)

WBN-EEB-MS-TI15-0011

BF 6-20-91

Prepared by Jonathan Date 06-17-91

Checked by Brian Fitzgerald Date 6-17-91

Page 3

## 1.2 Scope

The scope of this attachment is to modify page 170 of 200 (Appendix H, Page H42 of H72) of the Baseline Calculation to reflect implementation of DCN No. P-03437-A.

## 2.0 ASSUMPTIONS

See Baseline Calculation.

## 3.0 SOURCES OF DESIGN INPUT INFORMATION (REFERENCES)

3.1 DCN No. P-03437-A

3.2 Baseline Calculation

3.3 Departmental Guidelines for Electrical Mini Calculation Roll-up, Elec-004 dated 04/30/91.

## 4.0 DESIGN INPUT DATA

### Description of Data

### Source of Data

a. Load Description 1-HTR-1-CBS

Field Verification Data Sheet

Cont Bldg Steam Gen Htr

Field Verification Data Sheet

b. Rating 75 KW

Field Verification Data Sheet

c. Full load current 91 A

Field Verification Data Sheet

d. Existing Breaker Type/Frame ET/FJ

Field Verification Data Sheet

e. Existing Breaker Catalog No. FJ3-B125

Field Verification Data Sheet

f. Existing Breaker

Field Verification Data Sheet

Cont. Rating 125 amp

g. Existing Breaker Trip Setting  
Position 4

Field Verification Data Sheet

h. Existing Breaker Trip

Field Verification Data Sheet

Current 1500 amp

5.0 DOCUMENTATION OF INPUT/ASSUMPTIONS

See Baseline Calculation

6.0 COMPUTATION/ANALYSIS

Instantaneous Trip Current Rating and Trip-Setting Position for the Control Building Steam Generator Circuit Breaker

This tripping function is to provide the short circuit protection for the load and its incoming feeder cable and as such shall be selected to provide the most sensitive protection while allowing reliable operation. The trip setting shall also be coordinated with the trip setting of the upstream protective device so that an acceptable tripping selectivity can be achieved in the event of a short circuit fault.

1. The control Building Steam Generator Heater (1-HTR-1-CBS) is essentially a resistive load with no apparent inrush current involved.
2. The breaker instantaneous trip setting selected is based on common industry acceptable practice, which is 8 to 10 times the circuit FLA.
  - a.  $8 \times \text{Circuit FLA} = 8 \times 91 = 728$  amps
  - b. Trip setting selected: 750 amps
  - c. Trip position selected: Lo
3. Is the existing breaker trip position (4) acceptable?

Yes \_\_\_\_\_ No X

Prepared by Jonathan Date 06-17-91

Checked by Brian Fitzgerald Date 6-17-91

7.0 SUPPORTING GRAPHICS

Not applicable

8.0 SUMMARY OF RESULTS

Circuit Protection	Required	Existing	Acceptable	Change
1-MCC-214-A2/8B-A Breaker Ratings	125	125	Yes <u>X</u> No <u>  </u>	No
Breaker Set Point/Amp	LO/750	4/1500	Yes <u>  </u> No <u>X</u>	Yes

9.0 CONCLUSION

Change Control Bldg Steam Generator Heater (1-HTR-1-CBS) breaker instantaneous trip setting from position 4 (1500 amps) to position Lo (750 amps) at 1-MCC-214-A2-A compartment 8B.

10.0 APPENDICES

Appendix A Field Verification Data Sheet

Appendix B Page 170 of 200 (Appendix H, H42 of H72) of Baseline Calculation

Prepared by Jonathan Date 06-17-91

Checked by Brian Fitzgerald Date 6-17-91

Page 6

Appendix A  
Sheet 1 of 3

BOARD UNIT NO. 1-MCC-214-A2-A BOARD NAME 480V CONT & AUX BLDG WT RD

COMPARTMENT NO. 88 LOAD UNIT NO. 1-HTR-1-CBS

DESCRIPTION CONTROL BLDG STEAM GENERATOR

SINGLE LINE DRAWING REFERENCE 45W756-4

- A. PRIMARY CIRCUIT BREAKER
1. Manufacturer ITE
  2. Model/Catalog No. FT3-B125
  3. Type ADJUSTABLE
  4. Continuous Current Rating 125A
  5. Instantaneous Setting (For Adjustable Breakers) 4
  6. Serial No. N/A 6/6/88

- B. CONTROL TRANSFORMER
1. Manufacturer \_\_\_\_\_
  2. Model/Catalog No. \_\_\_\_\_
  3. Size \_\_\_\_\_
  4. UNID \_\_\_\_\_

- F. STARTER/CONTACTOR
1. Manufacturer \_\_\_\_\_
  2. Model/Catalog No. \_\_\_\_\_
  3. Size \_\_\_\_\_

- B. SECONDARY PROTECTIVE DEVICE
1. Location \_\_\_\_\_
  2. Manufacturer \_\_\_\_\_
  3. Type \_\_\_\_\_
  4. Continuous Current Rating (Adjustable Breakers) \_\_\_\_\_
  5. Instantaneous Setting (For Adjustable Breakers) \_\_\_\_\_
  6. Serial No. \_\_\_\_\_

- G. PRIMARY CONTROL CIRCUIT FUSE
1. Manufacturer \_\_\_\_\_
  2. Model/Catalog No. N/A 6/6/88
  3. Size \_\_\_\_\_
  4. Type MCB-6-88
  5. UNID \_\_\_\_\_

- C. TRIP ELEMENT
1. Manufacturer N/A 6/6/88
  2. Model/Catalog No. N/A 6-6-88
  3. Frame Size \_\_\_\_\_
  4. Trip Size \_\_\_\_\_

- H. SECONDARY CONTROL CIRCUIT FUSE (IF Applicable)
1. Manufacturer \_\_\_\_\_
  2. Model/Catalog No. \_\_\_\_\_
  3. Size \_\_\_\_\_
  4. Type \_\_\_\_\_
  5. UNID \_\_\_\_\_

- D. OVERLOAD HEATER
1. Manufacturer \_\_\_\_\_
  2. Catalog No. \_\_\_\_\_
  3. Size \_\_\_\_\_

I. SERVICE LOADS NAMEPLATE ON MCC MATCH SINGLE LINE  
YES  NO

LEGIBILITY EVALUATED and ACCEPTED for issue.

CABLE NUMBER(S) 1-4 PL-1-3680  
(For power cables entering and/or leaving compartment)

Signature Date 7/14/89

Prepared By Ray Tai Date 6/12/88

Verified By James D. Higgins Date 6-16-88

Prepared by Jonathan Date 06-17-91

Checked by B. Fitzgerald Date 6-18-91

Page 7  
Appendix A  
Sheet 2 of 3

ACCEPTABLE LEGIBILITY

Audysmith 7/13/89  
SIGNATURE DATE



BOARD 1-MCC-24 -A2 - A COMP 88

LOAD DESCRIPTION CONTROL BLOC STEAM GENERATOR

LOAD LOCATION CIQ/7.55

POWER RATING 75 KW

NAMEPLATE DATA BELOW:

	PRECISION parts corporation NASHVILLE, TENNESSEE	ASME  NAT'L. BD
MODEL <u>J1</u>		
SERIAL <u>6967</u>		
K.W. <u>75</u>	MAX. W.P. <u>150 P.S.I. STM</u>	
<u>      </u> B.T.U. / HR		M.S.V.R CAP.
VOLTAGE <u>480</u> PHASE <u>3</u>		<u>      </u> B.T.U / HR
AMPERES <u>91</u>		<u>263</u> LB / HR
<u>5</u> STEPS OF <u>15</u> K.W.		DATE
<u>      </u> STEPS OF <u>      </u> K.W.		<u>APR '75</u>

CONTINUED ON NEXT PAGE

Prepared By Jeffrey R. Datta  
Date 4-26-88

Verified By William C. Cielo  
Date 4-26-88

Attachment P-03437-A  
480V Non-Class 1E Power Cable  
Associated Circuits

NE Calculation No. WBN-EEB-MS-TI15-0011

Prepared by J. J. J. J. Date 06-17-91


Checked by P. Fitzgerald Date 6-18-91

Page 8  
Appendix A  
Sheet 3 of 3

BOARD 1-MCC-214-A2-A COMET 8B

BREAKER DATA BELOW:

NOMINAL INSTANTANEOUS TRIP SETTINGS - AMPERES AC					DC ADD 15% TO NOMINAL. TOLERANCES ON ALL SETTINGS ± 10%
LO	2	3	4	HI	
750	960	1300	1500	1600	

CURRENT INTERRUPTING RATING		UND. LAB. INC. LISTED CIRCUIT BREAKER 3-POLE UNIT ISSUE LAB31 600 VAC 125/250 V.D.C. CAT. NO. FJ3-B125  ITE IMPERIAL CORPORATION PHILADELPHIA, PENNSYLVANIA, USA	400 CU/AL
MAX. RMS.	SYM. AMPERES		
240 VOLTS	22,000 AMPERES		
480 VOLTS	18,000 AMPERES		
600 VOLTS	14,000 AMPERES		

ACCEPTABLE LEGIBILITY

Signature 7/13/89  
SIGNATURE DATE

Prepared By Ray J. J.  
Date 6/6/88

Verified By James D. Higgins  
Date 6-6-88



Prepared by J. Fitzgerald Date 06-17-91

Checked by B. Fitzgerald Date 6-18-91

Page 9  
 Appendix B

1-MCC-214-A2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING (A)	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
4F1	1-HTR-30-CCRD	B020	N/A	Y20	N/A	N/A	1	DISA030	N30A	10	IPL3268
5A	1-MTR-30-301	A010	3	Y45	1	T34	← N/A →			12	IPL3435
5E1	0-HTR-31-83	B030	N/A	Y30	N/A	N/A	1	DISA030	Y30A	8	IPL3707
5F1	1-HTR-30-XMIA	B020	N/A	Y20	N/A	N/A	1	DISA030	N30A	10	IPL3370
5F2	1-HTR-30-AB1	B020	N/A	Y20	N/A	N/A	1	DISA030	N30A	10	IPL3314
6E1	1-HTR-30-SMS	B030	N/A	Y30	N/A	N/A	1	DISA030	Y30A	8	IPL2811
6E2	1-HTR-30-NM1	B050	N/A	Y50	N/A	N/A	1	DISA050	Y50A	6	IPL2806
6F2	0-HTR-30-RM1	B020	N/A	Y20	N/A	N/A	1	DISA030	N30A	10	IPL3320
7D2	0-HTR-30-AFH	B040	N/A	Y40	N/A	N/A	1	DISA050	Y50A	6	IPL3335
7E1	1-HTR-30-UIA	B020	N/A	Y20	N/A	N/A	1	DISA030	N30A	10	IPL2813
7E2	0-HTR-30-BFH	B040	N/A	Y40	N/A	N/A	1	DISA050	Y50A	6	IPL3330
7F2	0-HTR-30-CFH	B040	N/A	Y40	N/A	N/A	1	DISA050	Y50A	6	IPL3340
8A	1-MTR-30-CRD	<del>FXD63</del> B125	LO H	Y800 <del>1600</del>	N/A	N/A	← N/A →			2/0	IPL3692
8B	1-HTR-1-CBS	FJ3 B125	LO H	Y750 <del>1500</del>	N/A	N/A	← N/A →			4/0	IPL3680

\* EXCEPT AS NOTED

DCN P-03437-A  
 J.I.H. 06-17-91

1.0 PURPOSE & SCOPE

1.1 PURPOSE

The purpose of this attachment is to evaluate and support modifications to be implemented under DCN M-13300-B.

Modifications involve the reclassification and re-route of cable no. PL3390.

Cable PL3390 was originally designed as a voltage class 3. Upon further review, it was determined that this cable, which feeds a 10HP motor, should be re-classified as voltage class 4. DCN M13300 was generated to re-classify this cable.

The following baseline calculations evaluate the DCN modifications for their impact. These evaluations are identified by the attachment No M13300B and are included in the calculation noted.

<u>BASELINE CALCULATION</u>	<u>CALCULATION NO.</u>
AUXILIARY POWER SYSTEM ANALYSIS	.....WBN EEB-MS-TI06-0002
480V NON-CLASS 1E POWER CABLE ASSOCIATED CIRCUITS	.....WBN EEB-MS-TI15-0011
CABLE AMPACITY - NV4 AND NV5 CABLES IN CLASS 1E RACEWAYS	.....WBPEVAR8909010

1.2 SCOPE

This attachment documents data for cable PL3390 which is being reclassified from voltage level V3 to V4 per DCN M-13300-B. It determines if cable protection is adequate so not to degrade possible associated class 1E cables below an acceptable limit.

## 2.0 ASSUMPTIONS

See "Assumptions" in base calculation (section 2.0).

## 3.0 SOURCES OF DESIGN INPUT/REFERENCES

- 3.1 Drawing #1-45W733-5 R0
- 3.2 Calculation, 480VAC 1E Coordination and Protection, WBN EEB-MS-TI08-0008
- 3.3 Calculation, Cable ampacity - NV4 And NV5 Cables In Class 1E Raceways, WBPEVAR8909010 R18
- 3.4 See base calc.

## 4.0 DESIGN INPUT DATA

- 4.1 Protective device size documented in Ref. 3.1 and 3.2.
- 4.2 Proposed adequate cable size in Ref. 3.3.
- 4.3 Input data consist of cable and protective device time current curves and associated data from 3.4.

## 5.0 JUSTIFICATION OF ASSUMPTIONS

- 5.1 See "Justification of Assumptions" in base calculation (section 5.0).

## 6.0 METHODOLOGY

- 6.1 The protected device listed on the calculation (Ref. 3.2) is a Gould-Shawmut fuse #TRS-20R (20A dual element/time delay). The protective device shown on the drawing (Ref. 3.1) is a 15 AMP fuse, this fuse will be replaced by a 20 AMP per DCN M-12212-A.

6.2 Calculation (Ref. 3.3) identifies the minimum required cable size as a #8.

6.3 The methodology is similar to that used in previous revisions of the base calculation.

Appendix H (page H27) was revised to document the applicable cable and protection device data.

The cable size was compared to the protective device data and time current curves (Appendix C & D of the base calculation), to determine if the proposed cable size was adequately protected by a TRS-20R (20 AMP fuse).

**7.0 GRAPHICS**

Graphics consist of the applicable time-current plots in the base calculation (Appendix C & D).

**8.0 SUMMARY OF RESULTS**

8.1 A TRS-20R fuse will adequately protect a #8 cable.

**9.0 CONCLUSIONS**

Cable PL3390 is adequately protected by the fuse (TRS-20R).

Cable protection is adequate since cable is required to be protected by at least one acceptable fuse.

It should be noted that currently a 15 Amp fuse is installed as required by drawing 1-45W733-5 and that DCN M-12212-A is replacing that required 15 Amp fuse with a 20 Amp fuse (TRS-20R).

**10.0 ATTACHMENTS / ADDITIONAL DATA**

PAGE

Baseline calculation appendix H - sheet H27 . . . . . 4

WBN EEB-MS-TI15-0011 R0

Page H27 of H72

Re 05AUG91

Calculation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchert Date 1/22/90 Checked Amay ... Date 1/27/90  
R.H. Buchert 1/10/90 Dwan ... 1/25/90  
UBats 215190 RSupkar 2-5-90

O-MCC-215-C2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING (A)	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
GK	O-JB-287-4784	136Y T150	N/A	150	N/A	N/A	1	A4J90	90A	2	PL3280
GR	O-HTR-30-326	136Y T150	N/A	150	N/A	N/A	1	A4J20	20A	2	PL3281 Thru PL3285
DN	O-MTR-18-110	N/A	N/A	N/A	N/A	C163B	GOULD SHAW MUT	TRS-20R	20A	8	PL3390

13

ATTACHMENT NO. M-15092-A  
CALC. NO. WBN EEB-MS-TI15-0011

PREPARED BY: JSM DATE: 12-10-91  
REVIEWED BY: DR DATE: 12-11-91  
PAGE 1

### PURPOSE

The purpose of this Attachment is to evaluate and support modifications to be implemented under the following DCN: M-15092-A

This Attachment evaluates the adequacy of Unit 1 System group protective devices for 480V power cables associated circuits.

This Attachment affects the following calculations:

<u>BASELINE CALCULATION</u>	<u>CALCULATION NO.</u>
480V Non-Class 1E Power Cable Associated Circuits	WBN EEB-MS-TI15-0011

1.0 SCOPE

This Attachment documents data for cable 1PL3017 which is being replaced for ampacity failure with a #6 cable. This Attachment will also document protection adequacy for this cable.

2.0 ASSUMPTIONS

See "Assumptions" in the base Calculation (Section 2.0).

3.0 SOURCES OF DESIGN INPUT/REFERENCES

3.1 Calculation WBPEVAR8909010 - Ampacity (Appendix I).

3.2 Appendix A of the base Calculation.

4.0 DESIGN INPUT DATA

4.1 Calculation WBPEVAR8909010 provides the data for the new cable size.

4.2 Provides the protection criteria for cable size.

5.0 JUSTIFICATION OF ASSUMPTIONS

See "Justification of Assumptions" in base Calculation (Section 5.0).

6.0 METHODOLOGY

The methodology for this Attachment is similar to that used in the base Calculation. The cable size is shown on the applicable sheet of Appendix H. Appendix A was reviewed to determine if adequate cable protection exists.

7.0 SUPPORTING GRAPHICS

None.

ATTACHMENT NO. M-15092-A  
CALCULATION WBN EEB-MS-TI15-0011  
PREPARED BY: JJM DATE: 12-10-91  
REVIEWED BY: DJC DATE: 12-11-91  
PAGE 3

8.0 SUMMARY OF RESULTS

Appendix A, page A2, shows a SHMT-HFLP 30A (D15A030) will protect a #8 @ 90° C for 10 seconds. Therefore, cable 1PL3017, which is being changed to a #6 @ 90° C, will also be protected by this fuse.

9.0 CONCLUSIONS

Cable 1PL3017, which is fed from 1-MCC-214-B1-B Comp. 13F1, is adequately protected in regards to the proposed increase in cable size to be implemented by DCN M-15092-A.



PN EEB-MS-TI15-0011 R0

Installation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R. H. Buchart Date 1/22/90 Checked R. H. Buchart Date 1/24/90  
R. H. Buchart 1/10/90 Dean Kelley 1/25/90

1-MCC-214-B1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
2D	1-MTR-81-7	H050	2	Y400	3	T52	← N/A →			6	IPL3228
2F1	0-DXF-234-B1	B020	N/A	Y20	N/A	N/A	1	DISA030	Y30A	8	IPL3740
2F2	0-TB-40-66	B020	N/A	Y20	N/A	N/A	1	DISA030	N30A	10	IPL3730
9F1	1-PNL-55-L236	B020	N/A	Y20	N/A	N/A	1	DISA030	N30A	10	IPL2972
12A	1-MTR-30-181	A010	3	Y45	1	T33	← N/A →			10	IPL3021
12E1	0-PNL-90-L397	B020	N/A	Y20	N/A	N/A	1	DISA030	N30A	10	IPL3609
12F1	1-RE-90-99	B020	N/A	Y20	N/A	N/A	1	DISA030	N30A	10	IPL3790
13A	1-MTR-84-21	A005	3	Y22	1	T23	← N/A →			12	IPL2948
13B	0-MTR-84-11	A005	3	Y22	1	T24	← N/A →			12	IPL3465
13C	1-MTR-65-74	A025	L0	Y75	1	T37	← N/A →			12	IPL3660
13F1	0-DXF-234-B4	B020	N/A	Y20	N/A	N/A	1	DISA030	N30A	6 + 10	IPL3017

IPEN  
M-15092  
JSM

Form GO-3.08.1 Rev. 2  
SL-F647 04/84

TABLE OF CONTENTS

<u>Section</u>	<u>Description</u>	<u>Page No.</u>	<u>Number of Pages</u>
--	Table of Contents	1	1
1.0	Purpose and Scope	2	1
2.0	Assumptions	3	1
3.0	Sources of Design Input Information (References)	3,4	1
4.0	Design Input Data	5	1
5.0	Justification of Assumptions	5	-
6.0	Criteria	5	-
7.0	Methodology	6	1
8.0	Supporting Graphics	7	1
9.0	Summary of Results	7,8	1
10.0	Conclusions	9	1
11.0	Appendices and Attachments	9	-

This Attachment contains 9 total pages.

1.0 PURPOSE AND SCOPE

1.1 Purpose

The purpose of this attachment is to evaluate and support the modifications to be implemented under DCN M-08614-A.

This attachment evaluates the adequacy of the protective devices for 480V power cables associated circuits originally identified in Appendix F of this baseline calculation.

This attachment affects the following calculation:

<u>Baseline Calculation</u>	<u>Calculation No.</u>
480V Non-Class 1E Power Cable Associated Circuits	WBN EEB-MS-TI15-0011

1.2 Scope

This attachment evaluates the adequacy of the remaining seventy (70) 480V power cables associated circuits protective devices that were originally identified in Appendix F of this baseline calculation (WBN EEB-MS-TI15-0011) and were not evaluated as part of DCN M-08613-A. In addition this attachment revises Appendix G of this baseline calculation.

This attachment also updates ~~and reevaluates~~ protective devices to resolve discrepancies between baseline calculation

WBN EEB-MS-TI15-0011 Appendix H and baseline calculation

WBN EEB-MS-TI08-0008 Attachment M12212A. *The protective devices that did not meet the cable protection criteria of the baseline calculation WBN EEB-MS-TI15-0011 are listed below and will be reevaluated via future revisions of baseline calculations WBN EEB-MS-TI15-0011 and WBN EEB-MS-TI08-0008 in support of DCN M-8614-A issue:*

- 0-MCC-208-A Compt NO. 7C, 8B, 8C, 8D.
- 0-MCC-217-A Compt NO. 3E, 4E.
- 0-MCC-218-1 Compt No. 6D.
- 1-MCC-210-A Compt NO. 3F2
- 1-MCC-214-A1 Compt NO. 2F2
- 1-MCC-232-A Compt No. 4D
- 1-MCC-232-B Compt NO. 6C
- 2-MCC-214-A1 Compt NO. 2F2
- 2-MCC-209-A Compt No. 7D
- 2-MCC-232-A Compt NO. 4D
- 2-MCC-232-B Compt NO. 6C

*m.r. 4/24/92  
J.L.H. 04-24-92*

2.0 ASSUMPTIONS

See "Assumptions" in baseline calculation (Section 2.0).

3.0 SOURCES OF DESIGN INPUT INFORMATION (REFERENCES)

- 3.1 Calculation WBN EEB-MS-TI08-0008 R17, "480V 1E Coordination/Protection".
- 3.2 WBN Computer Cable Routing System (CCRS) - July 7, 1989.
- 3.3 Wiring Diagrams, Periodic Breaker Test 85E-45B710-Series drawings.
- 3.4 Drawing 1-15E500-1 R0, "Key Diagram - Station Aux Power System".
- 3.5 Drawing 1-15E500-2 R0, "Key Diagram - Station Aux Power System".
- 3.6 Drawing 1-45W756-5 R2, "Wiring Diagrams - 480V Cont & Aux Bldg VT BD 1B1-B & 2B1-B Single Line Sh-1".
- 3.7 Drawing 1-45W756-6 R1, "Wiring Diagrams - 480V Cont & Aux Bldg VT BD 1B1-B & 2B1-B Single Line Sh-2".
- 3.8 Drawing 1-45W755-3 R0, "Wiring Diagrams - 480V Reactor Vent BD 1B-B & 2B-B Single Line Sh-1".
- 3.9 Drawing 1-45W755-4 R0, "Wiring Diagrams - 480V Reactor Vent BD 1B-B & 2B-B Single Line Sh-2".
- 3.10 Drawing 1-45W755-1 R0, "Wiring Diagrams - 480V Reactor Vent BD 1A-A & 2A-A Single Line Sh-1".
- 3.11 Drawing 1-45W755-2 R0, "Wiring Diagrams - 480V Reactor Vent BD 1A-A & 2A-A Single Line Sh-2".
- 3.12 Drawing 1-45W755-3 R0, "Wiring Diagrams - 480V Reactor Vent BD 1B-B & 2B-B Single Line Sh-1".
- 3.13 Drawing 1-45W755-4 R0, "Wiring Diagrams - 480V Reactor Vent BD 1B-B & 2B-B Single Line Sh-2".
- 3.14 Drawing 1-45W756-1 R2, "Wiring Diagrams - 480V Cont & Aux Bldg Vt BD 1A1-A & 2A1-A - Single Line Sh-1".
- 3.15 Drawing 1-45W756-2 R1, "Wiring Diagrams - 480V Cont & Aux Bldg Vt BD 1A1-A & 2A1-A - Single Line Sh-2".
- 3.16 Drawing 1-45W744-1 R0, "Wiring Diagrams - 480V Auxiliary Bldg Com MCC A Single Line Sh-1".
- 3.17 Drawing 1-45W744-2 R1, "Wiring Diagrams - 480V Auxiliary Bldg Com MCC A Single Line Sh-2".

- 3.18 Drawing 1-45W744-3 R1, "Wiring Diagrams - 480V Auxiliary Bldg Com MCC B Single Line Sh-1".
- 3.19 Drawing 1-45W744-4 R3, "Wiring Diagrams - 480V Auxiliary Bldg Com MCC B Single Line Sh-2".
- 3.20 Drawing 1-45W743-2 R0, "Wiring Diagrams - 480V Fuel & Waste Handling BD".
- 3.21 Drawing 1-45W757-1 R0, "Wiring Diagrams - 480V Turbine Bldg Vent BD 1A & 2A Single Line".
- 3.22 Drawing 1-45W757-2 R0, "Wiring Diagrams - 480V Turbine Bldg Vent BD 1A & 2A Single Line".
- 3.23 Drawing 1-45W745 R0, "Wiring Diagrams - 480V Lube Oil Board Single Line".
- 3.24 Drawing 1-45W744-5 R0, "Wiring Diagrams - 480V Aux Bldg Com MCC C Single Line Sh-1".
- 3.25 Drawing 1-45W744-6 R1, "Wiring Diagrams - 480V Aux Bldg Com MCC C Single Line Sh-2".
- 3.26 Drawing 1-45W751-1 R1, "Wiring Diagrams - 480V Reac MOV BDS 1A1-A & 2A1 Single Line Sh-1".
- 3.27 Drawing 1-45W751-2 R1, "Wiring Diagrams - 480V Reac MOV BDS 1A1-A & 2A1 Single Line Sh-2".
- 3.28 Drawing 1-45W751-3 R1, "Wiring Diagrams - 480V Reac MOV BDS 1A1-A & 2A1 Single Line Sh-3".
- 3.29 DCN M-08614-A
- 3.30 DCN M-07633-A

4.0 DESIGN INPUT DATA

- 4.1 Calculation WBN EEB-MS-TI15-0011, Attachment M08613A lists the remaining (70) inadequate protective devices for 480V power cables associated circuits that will be evaluated in this Attachment (M08614A). These remaining inadequate protective devices are identified in Appendix F as "NOT CROSSED OUT".
- 4.2 Calculation WBN EEB-MS-TI08-0008, Attachment M12212A (Ref. 3.1) provides updated settings for coordination of Class 1E protective devices used to update Appendix H of this baseline calculation.
- 4.3 WBN Computer Cable Routing System (Reference 3.2) provides the latest cable sizes utilized in Appendix H of this baseline calculation.
- 4.4 Drawings 1-15E500-1 & 2 (References 3.4 & 3.5) correlates the names and numbers of MCCs and boards with corresponding wiring diagrams.
- 4.5 Design Change Notice DCN M-07633-A provides the replacement secondary protective device for 1-BD-212-B2 compartment 3B.

5.0 JUSTIFICATION OF ASSUMPTIONS

See "Documentation of Assumptions" in Baseline Calculation (Section 5).

6.0 CRITERIA

Calculation WBN EEB-MS-TI15-0011, Attachment 1, Appendix A provides the acceptance criteria for the adequate protective devices with respect to the cable sizes. Section 1.1 (Scope) of this baseline calculation provides protective devices periodic testing requirements.

7.0 METHODOLOGY

7.1 Evaluate the adequacy of the remaining (70) protective devices listed in Attachment M08613A of this baseline calculation and reevaluate the adequacy of the protective devices affected by calculation WBN EEB-MS-TI08-0008 Attachment M12212A. The protective devices were compared against the acceptance criteria of Appendix A (Attachment 1) of this baseline calculation.

Breakers that are adequately protecting cables will be included in the periodic testing program (Ref. 3.3) via DCN M-08614-A.

7.2 Protective devices listed in Appendix H of this calculation were updated based upon the information provided in calculation WBN EEB-MS-TI08-0008 Attachment M12212A. The protective devices were then compared to the acceptance criteria of Appendix A to reevaluate the acceptability of the protective device.

7.3 Appendix F was then modified based on the following:

- \*\* Protective device was evaluated to be included in the periodic test program per attachment M08613A.
- \*\*\* Protective device was evaluated to be included in the periodic test program per attachment M08614A. Cable is protected, per Appendix A requirements, by a single breaker only.
- \*\*\* Protective device was evaluated to be acceptable per attachment M08614A. Cable is protected by at least one fuse, one fuse and one breaker or two breakers in series which meets Appendix A requirements.
- \*\*\*\* Protective device to be <sup>reevaluated via future revisions of baseline calculations</sup> replaced or reset per attachment M08614A. Resulting protection (Sec. 9.2 Remarks) is acceptable per Appendix A requirements. WBN EEB-MS-TI15-0011 and WBN EEB-MS-TI08-0008 in support of DCN M-8614-A issue.
- \*\*\*\*\* Protective device to be replaced or reset per attachment M08613A. Resulting protection is acceptable per Appendix A requirements.
- \*\*\*\*\* The circuit containing the protective device has been spared.

7.4 Appendix 1 (originally Appendix F of this baseline calculation) includes the list of all the inadequate protective devices evaluated in this attachment.

7.5 Appendix 2 (originally Appendix G of this baseline calculation) includes only the protective device that is revised for typo by this attachment.

7.6 Appendix 3 (originally Appendix H of this baseline calculation) includes only the protective devices that are revised per calculation WBN EEB-MS-TI08-0008 Attachment M12212A, the appropriate configuration control drawings (Reference 3.4 thru 3.28) and evaluated in this attachment.

8.0 SUPPORTING GRAPHICS

Time-current curves for ITE breakers FXD63B125 and FXD63B225 extracted from Attachment F13654A of this calculation (See Appendix 5).

9.0 SUMMARY OF RESULTS

9.1 The following protective devices are to be added to the output document 45B710-Series for periodic breaker testing and to be implemented on DCN M-08614-A.

9.1.1 All protective devices listed in Appendix F of this attachment with two asterisks "\*\*".

9.1.2 All protective devices listed in Appendix F of this attachment with four asterisks "\*\*\*\*".

9.2 The following are circuit breaker changes required to protect the 480V Non-Class 1E power cable associated circuits. Reset of these breakers will affect calculation WBN EEB-MS-TI08-0008 Attachment M12212A.

*The protective devices will be reevaluated via future revisions of baseline calculations WBN EEB-MS-TI15-0011 and WBN EEB-MS-TI08-0008 in support of DCN M-8614-A issue.*

480V Bus	Board Name	Compt No.	Bkr Type	Remarks
0-MCC-208-A	Aux Bld Com MCC-A	7C	EF3-H050	Reset adjustable Mag. Overcurrent Trip to less than 495A.
0-MCC-208-A	Aux Bld Com MCC-A	8B	EF3-A025Z	Reset adjustable Mag. Overcurrent Trip to less than 202.5A.
0-MCC-208-A	Aux Bld Com MCC-A	8C	EF3-A025Z	Reset adjustable Mag. Overcurrent Trip to less than 202.5A.
0-MCC-208-A	Aux Bld Com MCC-A	8D	EF3-A025Z	Reset adjustable Mag. Overcurrent Trip to less than 202.5A.
0-MCC-217-A	Chem & Vol BD-A	3E	EF3-L050	Reset adjustable Mag. Overcurrent Trip to less than 315A.
0-MCC-217-A	Chem & Vol BD-A	4E	EF3-L050	Reset adjustable Mag. Overcurrent Trip to less than 315A.

J.L.H.  
04-24-92  
m.r.  
4/24/92



9.2 (Continued)

<u>480V Bus</u>	<u>Board Name</u>	<u>Compt No.</u>	<u>Bkr Type</u>	<u>Remarks</u>
0-MCC-218-1	Lube Oil BD	6D	EF3-L050	Reset adjustable Mag. Overcurrent Trip to less than 315A.
1-MCC-210-A	Turb Bld Vent BD-1A	3F2	EF3-A100	Reset adjustable Mag. Overcurrent Trip to less than 1080A.
1-MCC-214-A1	Cont & Aux Bld BD 1A1-A	2F2	FXD63-B125	Reset adjustable Mag. Overcurrent Trip to less than 810A.
1-MCC-232-A	Reactor Vent BD 1A-A	4D	EF3-L050	Reset adjustable Mag. Overcurrent Trip to less than 315A.
1-MCC-232-B	Reactor Vent BD 1B-B	6C	EF3-L050	Reset adjustable Mag. Overcurrent Trip to less than 315A.
2-MCC-214-A1	Cont & Aux Bld BD 2A1-A	2F2	FXD63-B125	Reset adjustable Mag. Overcurrent Trip to less than 810A.
2-MCC-209-A	Turb MOV BD-2A	7D	EF3-L050	Reset adjustable Mag. Overcurrent Trip to less than 202.5A.
2-MCC-232-A	Reactor Vent BD 2A-A	4D	EF3-L050	Reset adjustable Mag. Overcurrent Trip to less than 315A.
2-MCC-232-B	Reactor Vent BD 2B-B	6C	EF3-L050	Reset adjustable Mag. Overcurrent Trip to less than 315A.

J.I.H. 04-24-92  
 m.p.  
 4/24/92

EEB-MS-TI15-0011-09  
 Location of Non-IE Power Circuits Located in Category 1 Structures

Page 117 of 1172

Prepared R.H. Buchert Date 1/22/90 Checked Kingmular Date 1/26/90  
R.H. Buchert 1/12/90 Kingmular 1/21/90

1-BD-212-A1 (

COMPT No	SERVICE	BKR MODEL NO	SENSOR RATING (A)	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
2C	1-MTR-30-103	DS-416	<del>200</del> 300	50	84	N/A	N/A	700	N/A	4/0	IPL5140
8A	CHGR D- <del>XSW</del> -239-1	DS-206	300	70 75	20	N/A	N/A	600	COULD/SWAMP CP350CS Y	300	IPL4931

R15  
 m.a. 4/13/92  
 J.H.H.  
 04-21-92

Form GO-3.08.1 Rev. 2 SL-F647 04/84

WBN EEB-MS-TI15-0011  
 ATTACHMENT M08614A/M12212A  
 Appendix 3 Page 2

APPENDIX H

R15  
 M.A. 4/13/92

WBN EEB-MS-TI15-0011 R0  
 Regulation of Non-IE Power Circuits Located in Category 1 Structures

Page 118 of 1172

Prepared R.H. Buchart Date 1/22/90 Checked Imagined Date 1/26/90  
R.H. Buchart 1/10/90 Swan Helley 1/25/90

1-BD-212-A2

COMPT NO	SERVICE	BKR MODEL NO	SENSOR RATING	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
3D	0-MTR32-25	DS-416	300A	<del>76</del> 75	<del>4</del> 12	N/A	N/A	<del>600</del> +000	N/A	4/0	IPL5033
7B	1-MTR30-159	DS-206	300A	<del>70</del> 66	<del>6</del> 12	N/A	N/A	<del>700</del> 900	CP 4/0CS COULD SHARPEN	4/0	IPL5085 IPL5150

R15  
 M.A. 4/13/92

J.I.H.  
 04-21-92

Form GO-3.0B.1 Rev. 2 SL-F647 04/84

WBN EEB-MS-TI15-0011 R0  
 Installation of Non-IE Power Circuits Located in Category 1 Structures

Prepared Kinghudas Date 1/22/90 Checked R.H. Buchat Date 1/26/90  
R.H. Buchat 1/10/90 Brown Kelley 1/25/90

1-BD-212-B1

COMPT No	SERVICE	BKR MODEL NO	SENSOR RATING	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
2B	1-MTR-30-102	DS-416	200 300A	90 50	4.0 7.5	N/A	N/A	700	N/A	4/0	IPL5160
3B	1-MTR-62-101	DS-416	400A	80 75	4.0 20	N/A	N/A	900 1000	N/A	400	IPL5025
3D	0-MTR-32-26	DS-416	300A	76 75	4 12	N/A	N/A	600 980	N/A	400	IPL5089

R15  
 4/13/92  
 J.H.  
 04-21-92

Form GO-3.08.1 Rev. 2 SL-F647 04/84

WBN EEB-MS-TI15-0011 RO

Appendix 3 Page 4

Page 110 of 172

Installation of Non-IE Power Circuits Located in Category 1 Structures

Prepared by R.H. Buchert Date 1/22/90 Checked by King Nuclear Date 1/26/90  
R.H. Buchert 1/17/90 Steve Kelley 1/25/90  
VBato 2/5/90 R. Supkar 2/5/90

1-BD-212-82

COMPT NO	SERVICE	BKR MODEL NO	SENSOR RATING (A)	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
3B	<del>1-CRM-271-R1</del> <del>1-PENT 273-11</del>	416	300	100	<del>20</del> 4	N/A	N/A	600	<del>CP6A-BT</del> 2100 2/15/90 5/15/90	400 300	IPL4610 IPL4611
3D	0-BD-276-XA	416	300	100	20	600	0.18	N/A	N/A	400	IPL4948
7A	1-MTR-30-162	206	300	65	<del>12</del> 4	N/A	N/A	<del>900</del> 700	CP4/OC5	410	IPL5170
8A	0-CHGR-239-S <del>0-XS-239-AG</del>	206	300	<del>75</del> 70	20	N/A	N/A	600	CP250C5	300	IPL4932

(REF.)  
(3.30)  
R15  
4/13/92  
J.L.H.  
04-21-92

Form GO-3.08.1 Rev. 2 SL-F647 04/84

R15  
 m.n. 9/13/92

~~WBN EEB-MS-TI15-0011~~ ~~RO~~  
 Distribution of Non-IE Power Circuits Located in Category 1 Structures

Prepared kyg Date 1/22/90 Checked R.H. Buchart Date 1/26/90  
R.H. Buchart 1/10/90 Joan Kelley 1/25/90

2-BD-212-A1

COMPT No	SERVICE	BKR MODEL NO	SENSOR RATING	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
2C	2-MTR-30-104	DS-416	200 <del>200A</del>	90 <del>50</del>	4 <del>8</del>	N/A	N/A	700	N/A	4/0	2PL5140
8A	<sup>CHSR</sup> 0-XSW-239-2	DS-206	300A	70 <del>75</del>	20	N/A	N/A	600	TX Y CP6 CP350CS	4/0 2/2 300	2PL4931 PL341

R15  
 m.n. 4/13/92  
 J.I.H.  
 04-21-92

Form GO-3.08.1 Rev. 2 SL-F647 04/84

WBN EEB-MS-TI15-0011 R9  
 Population of Non-IE Power Circuits Located in Category 1 Structures  
 Page ~~114~~ of ~~1172~~

Prepared R.H. Buchart Date 1/22/90 Checked Kmajmudar Date 1/26/90  
Kmajmudar 1/16/90 R.H. Buchart 1/21/90

2-BD-212-A2

COMPT No	SERVICE	BKR MODEL NO	SENSOR RATING (A)	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
7B	2-MTR-30-274	DS-206	300	<del>65</del> 67	4 +2	N/A	N/A	700 910	SHAWMIT CP410 Y C5	4/0	2PL5150
7C	0-MTR-30-136	DS-200	200 <sup>Y</sup>	90 75	4 +2	N/A	N/A	700 1100	S-AWMST CP410 C5 Y	4/0	2PL5111

R15  
 4/13/92  
 J.L.H.  
 04-21-92

Form GO-3.08 1 Rev. 2 SL-F647 04/84

WBN EEB-MS-TI15-0011 R9

Page H15 of H72

Population of Non-IE Power Circuits Located in Category 1 Structures

Prepared Amaynadar Date 1/22/90 Checked R.H. Buckert Date 1/26/90  
Amaynadar 1/16/90 R.H. Buckert 1/21/90

2-BD-212-B1

COMPT NO	SERVICE	BKR MODEL NO	SENSOR RATING (A)	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
2B	2-MTR-30-105	DS-416	200 300	90 50	84	N/A	N/A	700	N/A	410	2PL5160
3B	2-MTR-62-101	DS-416	400	80 75	4 20	N/A	N/A	900 1000	N/A	400	2PL5025

R15  
 4/13/92  
 J.L.H.  
 04-21-92

Form GO-3.08.1 Rev. 2 SL-F647 04/84



WBN EEB-MS-TI15-0011-R9  
 Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Page 116 of 172

Prepared for g/mud/cr Date 1/22/90 Checked R.H. Buchert Date 1/26/90  
for g/mud/cr 1/16/90 R.H. Buchert 1/21/90  
2/15/90 R. Supkan 2/5/90

2-BD-212-B2

COMPT No	SERVICE	BKR MODEL NO	SENSOR RATING (A)	LONG DELAY % OF PICKUP	LONG TIME (SEC)	SHORT DELAY % OF PICKUP	SHORT DELAY TIME (SEC)	INST % OF PICKUP	SECONDARY PROTECTIVE DEVICE	CABLE SIZE	CABLE NO
	2-CRN-271-R1										
3B	2-PENT-293-4	DS-416	300	100	4	N/A	N/A	600	Shannon CP6A-87 350	400 300	2PL4610 2PL4611
3D	0-BD-206-1/40	"	300	100	20	600 400	0.18 0.33	N/A	N/A	400	2PL4948
7A	2-MTR-30-278	DS-206	300	65	4 12	N/A	N/A	700 900	Y Gould CP 4/0 CS	4/0	2PL5170
7C	0-MTR-30-133	"	200	90 77.5	4 12	N/A	N/A	700 400	Y Gould CP 4/0 CS	4/0	2PL5100

R15  
 4/17/92  
 J.H.  
 04-21-92

Form GO-3.08.1 Rev. 2 SL-F647 04/84

Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared by R.H. Buchart Date 1/22/90 Checked by R. Supkar Date 1/26/90  
R.H. Buchart 1/17/90 R. Supkar 1/25/90  
M. Bates 2/5/90

O-MCC-208-B

COMP NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
2A	0-HST-271-HA	A0252	3	125	1	T40	←	N/A	→	10	PL1100 PL1101 PL1110 PL1111
2C	0-HST-271-HB	A0252	3	125	1	T40	←	N/A	→	10	
2E1	0-HTR-271-ABUD	B030	N/A	30		N/A	←	N/A	→	8	PL1172
2F2	0-HST-271-AB15	B050	N/A	50		N/A	←	N/A	→	6	PL3840
3A	0-HST-271-HC	A0252	3	125	1	T47	←	N/A	→	10	PL1150 PL1151
3E1	0-HTR-271-ABUC	B030	N/A	30		N/A	←	N/A	→	8	PL1176
3F2	0-PO-208-B4	B070	N/A	70		N/A	←	N/A	→	2	PL3760
4A	0-MTR-61-120A	A010	HI	84	1	T28	←	N/A	→	10	PL1120
4B	0-MTR-61-112F	A003	HI	21	1	T18	←	N/A	→	12	PL1124
4F1	0-PKG-59-B	B040	N/A	40		N/A	←	N/A	→	6	PL3789
5A	1-MTR-87-26	A0252	3	125	1	T39	←	N/A	→	10	
5E2	1-ACU-31-B	B050	N/A	50		N/A	←	N/A	→	6	PL3844
5F2	1-ACU-31-C	B100	N/A	100		N/A	←	N/A	→	2	PL3749
6A	2-MTR-77-262A	A0252	LO	75	1	T38	←	N/A	→	2	PL3320
6E1	1-HTR-31-PASF	B020	N/A	20		N/A	←	N/A	→	10	IPL6813
6F2	1-ACU-31-IRS	B030	↓	30		↓	FUSE INFO. NOT AVAILABLE.		30A	8	IPL6794
7B	1-MTR-77-262A	A0252	LO	75	1	T30	←	N/A	→	10	PL3047
7E1	1-HTR-271-AEE,AEN	B020	N/A	20		N/A	←	N/A	→	10	PL1183
7E2	0-HTR-271-ABUJ	B040	↓	40		↓	←	N/A	→	6	PL1204
7F1	2-HTR-271-AEB,AED	B030	↓	30		↓	←	N/A	→	8	PL1209 PL1210,11 PL3780 PL3783,349
7F2	0-PO-208-B1,B2,B3	B100	2 HE	100		↓	←	N/A	→	2	PL1129
8B	0-MTR-61-86	H050	2 HE	400	3	T50	←	N/A	→	6	PL1132
8D	0-MTR-61-87	H050	2 HE	400	3	T50	←	N/A	→	6	PL1184
8F1	0-HTR-271-AECAF	B030	N/A	30		N/A	←	N/A	→	8	PL1160
8F2	0-HTR-271-AB/RRI	B030	N/A	30		N/A	←	N/A	→	8	PL1160
9B	0-MTR-61-88	H050	3	475	3	T50	←	N/A	→	6	PL1135
9F2	1-MTR-271-AEJ	B030	N/A	30		N/A	←	N/A	→	8	PL1180
10A	2-MTR-31-318-B2	L050	3	260	2	T48	←	N/A	→	8	2PL6795

Form GO-3.08.1 Rev. 2  
 SL-F647 04/84

R15  
 n.a. 4/13/92  
 J.L.H.  
 04-21-92

WBN EEB-MS-TI15-0011-R0

Calculation of Non-IE Power Circuits Located in Category I Structures

Prepared R.H. Buchat Date 1/22/90 Checked Kingma Date 1/27/90  
R.H. Buchat 1/17/90 Scott Weller 1/25/90

O-MCC-208-C

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
10A	2-MTR-31-318/B2	L050	3	Y 250		T48	←	N/A	→	8	2PL6795
10B	2-MTR-31-318/A2	A010	4	Y 50		T34	←	N/A	→	12	2PL6780
10C	0-MTR-257-1	A003	3	Y 12		T19	←	N/A	→	12	PL3925
10E	2-MTR-31-437/C2	A003Z	HI	Y 21		T22	←	N/A	→	12	2PL6800
11C	0-HTR-31-479	B050	N/A	Y 50		N/A	←	N/A	→	6	PL6001
6F2	0-CHGR-236-5	B100	N/A	Y 100	N/A	N/A	N/A	N/A	N/A	2	PL3900
9A	SPARE <del>2-MTR-87-26</del>	A025Z	HI	N 210		T40	←	N/A	→	10	ABN2023

R15 (REF: 3-25)  
 m.a. 4/13/92  
 J.L.H.  
 04-21-92

ASCW744-6

Form GO-3.08.1 Rev. 2 SL-F647 04/84

WBN EEB-MS-TI15-0011 RO  
 Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Page 1126 of 1172

Prepared R.H. Buckert Date 1/22/90 Checked Amymrdr Date 1/27/90  
A.H. Buckert 1/10/90 Scott Welley 1/25/90

O-MCC-215-C2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							G30	MFR	MODEL		
BN	O-HTR-30-32 <sup>321</sup>	136YT 150	N/A	150	N/A	N/A	1	A4J15	Y15A	12	PL3274
BR	O-HTR-30-31 <sup>319</sup>	136YT 150	N/A	150	N/A	N/A	1	A4J15	Y15A	12	PL3272
CA	O-MTR-30-32 <sup>329</sup>	136YT 150	N/A	150	1	CB.97A	1	1.6R TR5TR	Y1.6A 1.6A	12X2	PL3308
CN	O-HTR-30-317	136YT 150	N/A	150	N/A	N/A	1	A4J30	Y30A	8	PL3270
CR	O-HTR-30-322	136YT 150	N/A	150	N/A	N/A	1	A4J30	Y30A	8	PL3275
CU	O-HTR-30-325	136YT 150	N/A	150	N/A	N/A	1	A4J15	Y15A	12	PL3278
CX	O-HTR-30-324	136YT 150	N/A	150	N/A	N/A	1	A4J15	Y15A	12	PL3277
DR	O-MTR-82-320	N/A	N/A	N/A	1	CB.67A	1	12R TR5TR PRIM. PROT.	Y12A 9A	12	PL3269
DU	O-MTR-82-321	N/A	N/A	N/A	1	CB.67A	1	12R TR5TR PRIM. PROT.	Y12A 9A	12	PL3268
EA	O-SW-30-327	N/A	N/A	N/A	1	C148A	1	3R TR5TR PRIM. PROT.	Y3A 1.6A	12	PL3316
EE	O-HTR-82-C-S <del>O-TB-82-C-S</del>	N/A	N/A	N/A	1	C695A	1	TR5 10R PRIM. PROT.	Y10A	12	PL3267
FS	O-PO-215-12	136YT 150	N/A	150	N/A	N/A	1	60 A4J40	Y60A 40A	4	PL3286
FW	O-PO-215-13	136YT 150	N/A	150	N/A	N/A	1	A4J60	Y60A	4	PL3287
GA	O-HTR-30-318	136YT 150	N/A	150	N/A	N/A	1	A4J15	Y15A	12	PL3271
GD	O-HTR 30-320	136YT 150	N/A	150	N/A	N/A	1	A4J15	Y15A	12	PL3273
GG	O-HTR-30-323	136YT 150	N/A	150	N/A	N/A	1	A4J15	Y15A	12	PL3276

R15  
 4/2/92  
 J.H.  
 04-21-92

R15  
 4/1/92  
 J.H.  
 04-21-92

Form GO-3.08.1 Rev. 2 SL-F647 04/84

WBN EEB-MS-TI15-0011-R0

Page 127 of 172

Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchert Date 1/22/90 Checked fraymeyer Date 1/27/90  
R.H. Buchert 1/10/90 Dwan Kelley 1/25/90  
W. Sato 215/90 R. Smpkan 2-5-90

O-MCC-215-C2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
	O-PO-215-8-11	GE TED		(A)		G30					
GK	<del>O-JB-287-4784</del>	136Y T150	N/A	150	N/A	N/A	1	A4J90	90A	2	PL3280
GR	O-HTR-30-326	136Y T150	N/A	150	N/A	N/A	1	A4J20	15A 20A	2	PL3279

R15  
 m.a. 4/13/92  
 J.I.H.  
 04-21-92

Form GO-3.08.1 Rev. 2 SL-F647 04/84

R15  
 3-2-91  
 4/14/90

~~WBN EEB MS TI15 0011 R0~~

Page 136 of 1172

Tabulation of Non-IE Power Circuits Located in Category I Structures

Prepared R. H. Buchat Date 1/22/90 Checked Km Jm Date 1/26/90  
W. Bates 1/16/90 R. H. Buchat 1/25/90  
2/5/90 R. Siplan 2/5/90

1-MCC-213-A1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
	1-MTR-31-265	EF3-		(A)		G30					
16A	<del>1-PENT-293-32</del>	A010	4 3	Y 58 45	1	T33 T32	SHAW-MUT	TRS-30	Y30A N	10 12	1PL6300 1PL6301
16B	1-MTR-77-129 <del>1-PENT-293-24</del>	A010	2 LO	Y 36 27	1	T27	SHAW-MUT	TRS-30	Y30A N	10 12	1PL6268 1PL6269
16F1	0-CHGR-252-1 <del>0-XSW-252-1</del>	B030 B020	N/A	Y 30 20	N/A	N/A	N/A	N/A	N/A	10	1PL6040
16F2	1-MTR-31-303/2 <del>1-TB-31-303/2</del>	B020	N/A	Y 20	N/A	N/A	N/A	N/A	N/A	10x2	1PL6289
17A	1-MTR-62-228/2 <del>0-JB-292-205-1</del>	B040 B030	N/A	Y 30	2	N/A	N/A	N/A	N/A	8 12 12	1PL6208 1PL6209 1PL6210
17E	1-PO-213-A1/1-5 <del>1-PENT-293-32</del>	B100	N/A	Y 100	N/A	N/A	SHAW-MUT	CPGA-197 #2	Y N/A	2 2	1PL6100 1PL6094
17F1	CHGR <del>0-XSW-240-5</del>	B020	N/A	Y 20	N/A	N/A	N/A	N/A	N/A	10	1PL6060
18C	1-MTR-31-303/1	A010	4 3	Y 58 45	1	T33 T32		N/A		12	1PL6281
18D	0-MTR-62-226	A005	4 3	Y 29 22	1	T26		N/A		12	1PL6265
18F1	CHGR <del>0-XSW-250-1</del>	B020	N/A	Y 20			N/A			10	PL871
18F2	1-PO-213-A1/6-10 <del>1-TB-293-2859</del>	B100 A100	LO	Y 475			N/A			2x2 2 2 2 2	1PL6093 1PL6101 1PL6102 1PL6103 1PL6104 1PL6106

R15  
 4/14/90  
 J.L.H.  
 04-21-92

Form GO-3.08.1 Rev. 2 SL-F647 04/84

WBN EEB-MS-TI15-0011 R9  
 Calculation of Non-IE Power Circuits Located in Category 1 Structures

Prepared K. Singh Date 1/22/90 Checked R.H. Buchert Date 1/24/90  
K. Singh 1/16/90 R.H. Buchert 1/25/90

1-MCC-213-A2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
4A	1-FCV-3-191	A010	4 3	58 45	1	630 T28 T32	←	N/A	→	12	1V3260
4B	1-FCV-3-192	A010	4 3	58 45	1	T28 T32	←	N/A	→	12	1V3280

R15  
 m.n. 4/13/92  
 J.H.  
 04-21-92

Form GO-3.08.1 Rev. 2 SL-F647 04/84

WBN EEB MS T115 0011 R0  
 Tabulation of Non-IE Power Circuits Located in Category 1 Structures  
 Prepared R.H. Buchart Date 1/22/90 Checked Amg/br/da Date 1/26/90  
R.H. Buchart 1/10/90 Scott Kelley 1/25/90

1-MCC-213-B1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
3F1	<del>0-CHGR-252-2</del> <del>0-XSW-252-2</del>	EDG3- <del>3020</del> 30	N/A	Y 30 20	←		N/A			10	IPL6045
16A	1-MTR-31-266 <del>1-PENT-293-35</del>	A010	4 3	Y 58 45	1	T33 T32	1	TR330	Y 30A N	10 12	IPL6310 IPL6311
16E	1-PO-213-B1/1-5 <del>1-PENT-293-47</del>	B100	N/A	Y 100	N/A	N/A	1	CPLA-197 #2	N.Y. 2/15/90 R10 2/15/90	2 2	IPL6085 IPL6082
16F1	CHGR <del>0-XSW-240-5</del>	B020	N/A	Y 20	←	N/A				10	IPL6061
17A	1-HTR-62-228/1 <del>0-JB-292-2048</del>	B040	N/A	Y 40 N.Y. N.Y.	2	←	N/A			8 12 12	IPL6214 IPL6215 IPL6216
17E	1-PO-213-B1/6-10 <del>1-PENT-293-35</del>	B100	N/A	Y 100	N/A	N/A	1	CPLA-197 #2	N.Y. 2/15/90 R10 2/15/90	2x2 2	IPL6075 IPL6076
17F1	CHGR <del>0-XSW-240-1</del>	EDG3- B020	N/A	Y 20	←		N/A			10	PL876
17F2	MTR <del>1-FB-31-324/2</del>	EDG3- B020	N/A	Y 20	←		N/A			10	IPL6291
18C	1-MTR-31-32A/1	A010	4 3	Y 58 45	1	T33 T32		N/A		10	IPL6285
18D	0-MTR-8A-2	A005	4 3	Y 29 22	1	T26		N/A		12	IPL6273

R15  
 4/14/92  
 04-21-92  
 J.L.H.

Form GO-3.08.1 Rev. 2 SL-F647 04/84



YMB  
 3-7-90  
 R15  
 4/13/92

WBN EEB-MS-TI15-0011R0

Enumeration of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchart Date 1/22/90 Checked knaymader Date 1/26/90  
R.H. Buchart 1/10/90 knaymader 1/21/90

1-MCC-213-B2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
4A	1-FCV-3-193	A010 A0102	4 3	58 45	1	T28 I32	←	N/A	→	12	1V3290
4B	1-FCV-3-194	A010 A0102	4 3	58 45	1	T28 I32	←	N/A	→	12x2	1V3270
12A	0-FCV-67-362	A B010	2 10	36 27	1	T29 T28	←	N/A	→	12	1V3230

R15  
 4/13/92  
 J.L.H.  
 04-21-92

Form GO-3.08.1 Rev. 2 SL-F647 04/84

WBN EEB-MS-T115-0011 RO  
 Installation of Non-IE Power Circuits Located in Category 1 Structures

Prepared by R.H. Buckert Date 1/22/90 Checked by R.H. Buckert Date 1/26/90  
R.H. Buckert 1/10/90 Scott W. Kelley 1/25/90

1-MCC-214-A1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
2D	1-MTR-81-3	H050	3	475 400	3	T52	N/A	N/A	N/A	6	IPL3221
2F1	0-DXF-234-A1 SIS	B020 FXD69- B125	N/A	Y 20	N/A	N/A	GOULD/ SHAWMUT	DISA030	Y 30A	8	IPL3590
2F2	1-DXF-242-1	B020 3070	N/A	N 1200 70	N/A	N/A	GOULD/ SHAWMUT	DISA100	N 100A	4	IPL3596
3F1	1-RE-90-119	B020	N/A	Y 20	N/A	N/A	GOULD/ SHAWMUT	DISA030	N 30A	10	IPL3589
3F2	SPARE 1-MTR-40-3A <del>0-TB-40-3</del>	B020	N/A	Y 20	N/A	N/A	GOULD/ SHAWMUT	DISA030	N 30A	10	IPL3720 IPL3716 2-5790
5F1	0-RE-90-132	B020	N/A	Y 20	N/A	N/A	GOULD/ SHAWMUT	DISA030	N 30A	10	IPL3599
10F1	0-RE-90-101	B020	N/A	Y 20	N/A	N/A	GOULD/ SHAWMUT	DISA030	N 30A	10	IPL3598
12E1	1-PNL-90-L398	B020	N/A	Y 20	N/A	N/A	GOULD/ SHAWMUT	DISA030	N 30A	10	IPL3610
13A	1-MTR-84-16	A005	4	Y 29 22	1	T25	← N/A →			12	IPL2940
13B	0-MTR-84-6	A005	3	Y 22	1	T25	← N/A →			12	IPL3460
13C	1-MTR-65-77	A0252	2	Y 105 75	1	T38 T37	← N/A →			12	IPL3645

R15  
 4/13/92  
 J.I.H.  
 04-21-92

R15  
 4/13/92  
 J.I.H.  
 04-21-92

(REF 3.14)  
 R15  
 4/13/92  
 J.I.H.  
 04-21-92

R15  
 4/13/92  
 J.I.H.  
 04-21-92

R15  
 4/13/92  
 J.I.H.  
 04-21-92

Shamut DISA & HFCP are the same fuse.

Form GO-3.08.1 Rev. 2 SL-F647 04/84

WBN EEB-MS-TI15-0011-R0

Location of Non-IE Power Circuits Located in Category 1 Structures

Prepared Krajncider Date 1/22/90 Checked R.H. Buchert Date 1/26/90  
Albats 1/16/90 R.H. Buchert 1/25/90  
2/15/90 R. Supkar 2-5-90

1-MCC-214-A2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
2A	0-MTR-31-339	A003 <sup>5</sup>	4	Y <sup>29</sup> <sub>25</sub>	1	T20		N/A		12	IPL2830
2D1	1-HTR-30-A1A	B020	N/A	Y <sub>20</sub>	N/A	N/A	1	DISA030	N 30A	10	IPL3280
2D2	0-PO-214-1-4	B100	N/A	Y <sub>100</sub>	N/A	N/A	1	DISAB100	Y 100A	2	IPL2780
2E1	1-HTR-30-B1A	B020	N/A	Y <sub>20</sub>	N/A	N/A	1	DISA030	N 30A	10	IPL3284
2E2	0-HTR-31-493 <del>0-F3-31-493</del>	B0502	N/A	Y <sub>50</sub> N	N/A	N/A	1	DISA050	Y <sub>50A</sub> N	6 10	IPL6460 IPL6463,64
2F2	0-PO-214-7,8	B100	N/A	Y <sub>100</sub>	N/A	N/A	1	DISAB100	Y 100A	2	IPL2777
3A	1-MTR-30-25	A010	4	Y <sup>58</sup> <sub>45</sub>	1	T34 T33		N/A		12x2	IPL2906
3D1	1-HTR-30-ACRD	B020	N/A	Y <sub>20</sub>	N/A	N/A	1	DISA030	N 30A	10	IPL3266
3D2	0-PO-214-5,6	B100	N/A	Y <sub>100</sub>	N/A	N/A	1	DISAB100	Y 100A	2	IPL2775
3E1	1-HTR-30-C1A	B020	N/A	Y <sub>20</sub>	N/A	N/A	1	DISA030	N 30A	10	IPL3288
3E2	1-HTR-30-D1A	B0502	N/A	Y <sub>50</sub>	N/A	N/A	1	DISA050	Y 50A	6	IPL3510
3F1	0-HTR-31-97	B020	N/A	Y <sub>20</sub>	N/A	N/A	1	DISA030	N 30A	10	IPL2800
3F2	1-HTR-30-1A1	B020	N/A	Y <sub>20</sub>	N/A	N/A	1	DISA030	N 30A	10	IPL3365
4A	1-MTR-30-283	A005	4	Y <sup>29</sup> <sub>18</sub>	1	T24		N/A		12	IPL3621
4B	0-MTR-31-203 1204	A025	3	Y <sub>125</sub>	1	T41 T44		N/A		10	V1920
4E1	1-HTR-30-BCRD	B020	N/A	Y <sub>20</sub>	N/A	N/A	1	DISA030	N 30A	10	IPL3264

R15  
 m.a. 4/13/92

R15  
 m.a. 4/13/92

R15  
 m.a. 4/13/92

R15  
 m.a. 4/13/92

R15  
 m.a. 4/13/92

R15  
 m.a. 4/13/92

R15  
 J.L.H. 04-21-92

Form 00-308.1 Rev. 2 SL-F647 04/84

R15  
 no. 4/13/92

WBN EEB-MS-TI15-0011-R9

Page 142 of 172

Location of Non-IE Power Circuits Located in Category 1 Structures

Prepared Amey Indar Date 1/22/90 Checked R.H. Burchart Date 1/26/90  
Amey Indar 1/16/90 R.H. Burchart 1/25/90

1-MCC-214-A2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
4F1	1-HTR-30-CCRD	B020	N/A	20	N/A	N/A	1	DISA030	N 30A	10	IPL3268
5A	1-MTR-30-301	A010	4 3	58 45	1	T34	← N/A →			12	IPL3435
5E1	0-HTR-31-83	B030	N/A	30	N/A	N/A	1	DISA030	Y 30A	8	IPL3707
5F1	1-HTR-30-XMIA	B020	N/A	20	N/A	N/A	1	DISA030	N 30A	10	IPL3370
5F2	1-HTR-30-ABI	B020	N/A	20	N/A	N/A	1	DISA030	N 30A	10	IPL3314
6E1	1-HTR-30-SMS	B030	N/A	30	N/A	N/A	1	DISA030	Y 30A	8	IPL2811
6E2	1-HTR-30-NMI	B050	N/A	50	N/A	N/A	1	DISA050	Y 50A	6	IPL2806
6F2	0-HTR-30-RMI	B020	N/A	20	N/A	N/A	1	DISA030	N 30A	10	IPL3320
7D2	0-HTR-30-AFH	B040	N/A	40	N/A	N/A	1	DISA050	Y 50A	6	IPL3335
7E1	1-HTR-30-UIA	B020	N/A	20	N/A	N/A	1	DISA030	N 30A	10	IPL2813
7E2	0-HTR-30-BFH	B040	N/A	40	N/A	N/A	1	DISA050	Y 50A	6	IPL3330
7F2	0-HTR-30-CFH	B040	N/A	40	N/A	N/A	1	DISA050	Y 50A	6	IPL3340
8A	1-MTR-30-CRD	<del>FXD63</del> <del>F33</del> B125	LO HI	800 1600	N/A	N/A	← N/A →			2/0	IPL3692
8B	1-HTR-1-CBS	<del>FXD63</del> <del>F33</del> B125	LO HI	800 1500	N/A	N/A	← N/A →			4/0	IPL3680

R15  
 no. 4/13/92  
 J.L.H.  
 04-21-92

R15  
 no. 4/13/92  
 J.L.H.  
 04-21-92

Form 00-3.08.1 Rev. 2 SL-F647 04/84

R15  
 m.n. 4/13/92  
 3-2-91

Population of Non-IE Power Circuits Located in Category 1 Structures

Prepared R. H. Buchart Date 1/22/90 Checked R. H. Buchart Date 1/24/90  
R. H. Buchart 1/10/90 Deon Kelley 1/25/90

1-MCC-214-B1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
		EF3-		(A)		630					
2D	1-MTR-81-7	H050	3	Y 475 400	3	T52		N/A		6	IPL3228
2F1	0-DXF-234-B1	B020	N/A	Y 20	N/A	N/A	1	DISA030	Y 30A	8	IPL3740
2F2	<del>1-MTR-40-66A</del> <del>0-TB-40-66</del>	B020	N/A	Y 20	N/A	N/A	1	DISA030	N 30A	10	IPL3730
9F1	<del>1-XFMR-290-236</del> <del>1-PNL-55-L236</del>	B020	N/A	Y 20	N/A	N/A	1	DISA030	N 30A	10	IPL2972
12A	1-MTR-30-181	A010	4 3	Y 58 45	1	T33		N/A		10	IPL3021
12E1	0-PNL-90-L397	B020	N/A	Y 20	N/A	N/A	1	DISA030	N 30A	10	IPL3609
12F1	1-RE-90-99	B020	N/A	Y 20	N/A	N/A	1	DISA030	N 30A	10	IPL3790
13A	1-MTR-84-21	A005	4 3	Y 29 22	1	T25 T23		N/A		12	IPL2948
13B	0-MTR-84-11	A005	3	Y 22	1	T25 T21		N/A		12	IPL3465
13C	1-MTR-65-74	A025	2 CO	Y 105 45	1	T38 T37		N/A		12	IPL3660
13F1	<del>0-DXF-234-B4</del>	B020	N/A	Y 20	N/A	N/A	1	DISA030	N 30A	10	IPL3017

(REF 3.6)  
 R15  
 m.n. 4/13/92  
 J.I.H.  
 04-21-92

R15  
 m.n. 4/13/92  
 (REF 3.6)  
 J.I.H.  
 04-21-92

Form 00-3.08.1 Rev. 2 SL-F647 04/84

R15  
 4/17/92

WBN EEB-MS-TI15-0011 RO  
 Location of Non-IE Power Circuits Located in Category 1 Structures  
 Prepared knajhuder Date 1/22/90 Checked R.H. Buchart Date 1/20/90  
R.H. Buchart 1/10/90 Scott Kelley 1/25/90

1-MCC-214-B2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
2B	0-MTR-31-418	A005	34	Y <sup>22</sup> <sub>29</sub>	1	T18 T28	←	N/A	→	12	IPL3654
2E1	1-HTR-30-AIB	B020	N/A	Y <sup>20</sup>	N/A	N/A	1	N DISA030	30A.	10	IPL3676
2E2	0-HTR-30-GFA	B040	N/A	Y <sup>40</sup>	N/A	N/A	1	Y DISA050	50A.	6	IPL3400
2F1	1-HTR-30-BIB	B020	N/A	Y <sup>20</sup>	N/A	N/A	1	N DISA030	30A	10	IPL3898
2F2	1-HTR-31-BRB	B050	N/A	Y <sup>50</sup>	N/A	N/A	1	Y DISA050	50A	6	IPL3890
3B	1-MTR-30-284	A005	4 Z	Y <sup>29</sup> <sub>28</sub>	1	T24	←	N/A	→	12	IPL3626
3C	1-MTR-30-66	A005	4 Z	Y <sup>29</sup> <sub>28</sub>	1	T24	←	N/A	→	12	IPL3631
3E1	1-HTR-30-CIB	B020	N/A	Y <sup>20</sup>	N/A	N/A	1	N DISA030	30A.	10	IPL3895
3E2	0-HTR-30-HFA	B040	N/A	Y <sup>40</sup>	N/A	N/A	1	Y DISA050	50A	6	IPL3405
3F1	1-HTR-30-PRX	B020	N/A	Y <sup>20</sup>	N/A	N/A	1	N DISA030	30A.	10	IPL3395
4B	1-MTR-30-302	A010	4 Z	Y <sup>58</sup> <sub>45</sub>	1	T33 T32	←	N/A	→	12	IPL3438
4E1	0-HTR-31-95	B020	N/A	Y <sup>20</sup>	N/A	N/A	1	N DISA030	30A	10	IPL2809
4E2	0-HTR-30-NFA	B040	N/A	Y <sup>40</sup>	N/A	N/A	1	Y DISA050	50A	6	IPL3415
4F1	1-HTR-30-SBU	B020	N/A	Y <sup>20</sup>	N/A	N/A	1	N DISA030	30A	10	IPL3425
4F2	1-HTR-30-U113	B020	N/A	Y <sup>20</sup>	N/A	N/A	1	N DISA030	30A	10	IPL2975
5E1	1-HTR-31-87	B020	N/A	Y <sup>20</sup>	N/A	N/A	1	N DISA030	30A.	10	IPL2825

R15  
 4/17/92

R15  
 4/17/92

R15  
 4/17/92

SL-F647 04/84  
 Form GO-3.08.1 Rev. 2

R15  
 J.I.H. 04-21-92

WBN EEB MS TI15 0011 R0

Page 145 of 172

Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared Amgundar Date 1/22/90 Checked R.H. Buchert Date 1/26/90  
R.H. Buchert 1/17/90 Bruce Kelley 1/25/90  
ElBate 2/5/90 RSupkarc 2-5-90

1-MCC-214-B2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
5F1	0-HTR-30-RM2	3020	N/A	Y 20	N/A	N/A	1	DISA030	N 30A	10	IPL3385
6B	1-MTR-30-26	A010	4 3	Y 58 45	1	T33 T32	← N/A →			12	IPL2913
6E1	1-HTR-30-AB7	3020	N/A	Y 20	N/A	N/A	1	DISA030	N 30A	10	IPL3381
6F1	1-HTR-30-T1B	3020	N/A	Y 20	N/A	N/A	1	DISA030	N 30A	10	IPL3430
7D	0-HTR-31-421	FXD63 F33 3225	3 HE	Y 1500 2000	N/A	N/A	← N/A →			300	IPL3440
7E2	0-HTR-31-72	EF3- 3030	N/A	Y 30	N/A	N/A	1	DISA030	Y 30A	8	IPL2977
7F1	1-HTR-30-NM2	3050Z	N/A	Y 50	N/A	N/A	1	DISA050	Y 50A	6	IPL3421
8F1	HTR 0-31-494	50 3042	N/A	Y 150 42	N/A	N/A	1	DISA050	Y 50A N	6 10 10	IPL6470 IPL6473 IPL6474
8F2	1-PO-214-10-12	3100	N/A	Y 100	N/A	N/A	1	DISA3100	Y 100A	2	IPL2785
9A	1-MTR-30-CRB	FXD63 F3 3125	LO	Y 800 750	N/A	N/A	← N/A →			4/0	IPL3671

R15  
 4/21/92  
 J.I.H.  
 04-21-92  
 R15  
 4/21/92  
 J.I.H.  
 04-21-92  
 R15  
 4/21/92  
 J.I.H.  
 04-21-92

Form GO-3.08.1 Rev. 2 SL-F647 04/84

WBN EEB-MS-TI15-0011 R9  
 Enumeration of Non-IE Power Circuits Located in Category 1 Structures

Page 1146 of H72

Prepared Krajmiller Date 1/22/90 Checked R.H. Buchart Date 1/26/90  
Krajmiller 1/16/90 R.H. Buchart 1/25/90

1-MCC-215-A1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING (A)	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
5A	1-MTR-82-181	A025	2 <del>LO</del>	Y <sup>103</sup> <del>75</del>	1	T34 <del>T38</del>	←	N/A	→	12	PL2195
5F1	0-HTR-30-479	B020	N/A	Y20	←	N/A	→			10	PL2322
5F2	1-PO-215-1,2,3 <del>1-JB-296-256</del>	B100	N/A	Y100	←	N/A	→			2	PL2539
6A	MTR 1-SW-30-463	A005	HI <del>Z</del>	Y41 <del>Y48</del>	1	T28 <del>T25</del>	←	N/A	→	12	PL2235
6F1	0-HTR-30-483	B020	N/A	Y20	←	N/A	→			10	PL2310

R15  
 4/13/92  
 J.L.H.  
 04-21-92

R15  
 4/13/92  
 J.L.H.  
 04-21-92



R15  
 m.r. 4/13/92

WBN EEB-MS-TI15-0011 R0

Page 117 of 1172

Installation of Non-IE Power Circuits Located in Category 1 Structures

Prepared Krajmucker Date 1/22/90 Checked R.H. Buchat Date 1/26/90  
Krajmucker 1/16/90 R.H. Buchat 1/25/90

1-MCC-215-A2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
2E2	0-HTR-30-484	B040	N/A	Y 40			N/A			6	PL2304
3E1	1-HTR-30-487	B020	N/A	Y 20	N/A	N/A	N/A	N/A	N/A	10	PL2411
3F1	1-HTR-30-471	B030	N/A	Y 30	N/A	N/A	N/A	N/A	N/A	8	PL2262
3F2	1-HTR-30-472	B030	N/A	Y 30	N/A	N/A	N/A	N/A	N/A	8	PL2268
5A	1-MTR-82-180	A025Z	2	Y 105 <del>75</del>	1	T39 <del>T38</del>	N/A	N/A	N/A	12	PL2200
5E1	0-HTR-30-485	B030	N/A	Y 30	N/A	N/A	N/A	N/A	N/A	8	PL2316
5F1	PKG 0-SW-39-37	B020	N/A	Y 20	N/A	N/A	N/A	N/A	N/A	10	PL2765
6A	0-MTR-30-470	A005	4	Y 29	1	T22 <del>T28</del>	N/A	N/A	N/A	12	PL2572
6D	1-HTR-82-100 <del>1-B-82-A1-A</del>	B020	N/A	Y 20	N/A	N/A	N/A	N/A	N/A	12	PL2700
<del>2E2</del>	<del>0-HTR-30-484</del>	<del>B040</del>	<del>N/A</del>	<del>Y 40</del>	<del>N/A</del>	<del>N/A</del>	<del>N/A</del>	<del>N/A</del>	<del>N/A</del>	<del>6</del>	<del>PL2304</del>

R15  
 m.r. 4/13/92  
 J.H.  
 04-21-92

R15  
 m.r. 4/13/92  
 J.H.  
 04-21-92

Form GO-3.08.1 Rev. 2 SL-F647 04/84

WBN EEB-MS-TI15-0011 R0  
 Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Page 148 of 172

Prepared Junyandur Date 1/22/90 Checked R.H. Buchert Date 1/24/90  
R.H. Buchert 1/17/90 Junyandur 1/25/90

1-MCC-215-B1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		EF3-		(A)		630	MFR	MODEL	RATING		
5A	1-MTR-82-211	A0252	2 LO	105 75	1	T39 N/A	N/A	N/A	N/A	12	PL2215
5F1	0-HTR-30-481	8020	N/A	20	N/A	N/A	N/A	N/A	N/A	10	PL2340
6A	MTR 1-SW-30-465	A005	HI 2	41 1+8	1	T28 T26	N/A	N/A	N/A	12	PL2249

R15  
 m.a. 4/13/92  
 J.L.H.  
 04-21-92

R15  
 m.a. 4/13/92  
 J.L.H.  
 04-21-92

Form 00-308.1 Rev. 2 SL-F647 04/84

WBN EEB-MS-TI15-0011 R9  
 Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared Knajmuder Date 1/22/90 Checked R.H. Buchart Date 1/26/90  
R.H. Buchart 1/12/90 Knajmuder 1/25/90

1-MCC-215-B2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
3E1	1-HTR-30-489	B020	N/A	Y 20	N/A	N/A	N/A	N/A	N/A	10	PL2412
3F1	1-HTR-30-473	B030	N/A	Y 30	N/A	N/A	N/A	N/A	N/A	8	PL2274
3F2	1-HTR-30-474	B030	N/A	Y 30	N/A	N/A	N/A	N/A	N/A	8	PL2280
5A	1-MTR-82-210	A025Z	2	Y 105 75	1	T39 T38	N/A	N/A	N/A	12	PL2220
5F2	1-PO-215-4,5,6 <del>1-B-296-258</del>	B100	N/A	Y 100	N/A	N/A	N/A	N/A	N/A	2	PL2552
6D	1-HTR-82-200 <del>1-B-82-211</del>	B020	N/A	Y 20	N/A X	N/A	N/A	N/A	N/A	12	PL2706

R15  
 4/21/92  
 J.L.H.  
 04-21-92

Form GO-3.08.1 Rev. 2 SL-F647 04/84

R15  
 4/13/92

WBN EEB-MS-TI15-0011 R0  
 Tabulation of Non-IE Power Circuits Located in Category I Structures

Prepared KM by JLB Date 1/22/90 Checked TBT FOR RAB Date 1-26-90  
KM by JLB 1/16/90 TBT FOR RAB 1-25-90  
JLBates 2/5/90 R. SUPKAR 2-5-90

1-MCC-232-A

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
2A	<del>1-MTR-77-125A</del> <del>PENT 293-24</del>	A010	4 <del>3</del>	<del>Y 45</del> Y 58 Y	1	T35	SHAW-MUT	TRS-30	Y 30 N	10X2 12	IPL653 IPL654
3A	<del>1-MTR-94-1D</del> <del>PENT 293-32</del> FLUX D	B020	N/A	Y 20	N/A	N/A	"	DISA030	N 30	10X2 10	IPL295 IPL296
3B	<del>1-MTR-94-1E</del> <del>PENT 293-32</del> FLUX E	B020	N/A	Y 20	N/A	N/A	"	DISA030	N 30	10X2 10	IPL300 IPL301
3C	<del>1-MTR-94-1F</del> <del>PENT 293-32</del> FLUX F	B020	N/A	Y 20	N/A	N/A	"	"	N 30	10X2 10	IPL305 IPL306
4D	1-MTR-61-51	L050	HI 4	N 470 330	2	T51	N/A	N/A	N/A	8	IPL4320
4E	1-HTR-61-92	B050	N/A	Y 50	-2	T54 F51	N/A	N/A	N/A	6	IPL4300
5A	0-MTR-31-406	A005	3 4	Y 22 29	1	T18 F28	N/A	N/A	N/A	12	IPL644
6A	0-MTR-31-25	A010	4	Y 58	1	T34	N/A	N/A	N/A	12	IPL735
6C	0-MTR-77-91	H050	2 LO	Y 400 320	2	T53 F52	N/A	N/A	N/A	6X2	IPL5460
6F1	DXF 0-SW-234-A/ IPS	B040 B030	N/A	Y 40 30	N/A	N/A	SHAW-MUT	DISA030	Y 30	1/0	IPL1108
7B	<del>1-HTR-68-8AA</del> <del>PENT 293-32</del> RCP HTR	A010	L0 2	Y 27 36	1	T31 F36	"	TRS-30	N 30	12 12	IPL370 IPL371
7D	<del>1-MTR-68-84</del> <del>PENT 293-32</del> RCP LIFT	B040	N/A	Y 40	1	T45 F44	"	"	Y 30	10 10	IPL396 IPL397
7F2	<del>1-PO-232-9-11</del> <del>JB 292-994</del>	B100	N/A	Y 100	N/A	N/A	SHAW-MUT	DISA B100	Y 100	2	IPL258
8B	<del>1-HTR-68-50AA</del> <del>PENT 293-24</del> RCP HTR	A010	L0 2	Y 27 36	1	T31 F36	"	TRS-30	N 30	12X2 12	IPL382 IPL383
8D	<del>1-MTR-68-86</del> <del>PENT 293-24</del> RCP LIFT	B040 A025	3	Y 125	1	T45	"	"	Y 30	10X2 10	IPL408 IPL409
8F2	<del>1-PO-232-1,2,3</del> <del>JB 292-993</del>	B100	N/A	Y 100	N/A	N/A	SHAW-MUT	DISA B100	Y 100	2	IPL240 241,243

R15  
 4/13/92  
 J.L.H.  
 04-21-92

R15  
 4/13/92  
 J.L.H.  
 04/21/92

Form GO-3.08.1 Rev. 2 SL-F647 04/84

428 2/5/98  
 Page 180 of 201  
 179 of 200  
 9-7-98

R15  
 4/13/92

WBN EEB-MS-TI15-0011 R9  
 Population of Non-IE Power Circuits Located in Category I Structures  
 Page H51 of H72

Prepared R.H. Buchert Date 1/22/90 Checked Kryzander Date 1/26/90  
Kryzander 1/16/90 R.H. Buchert 1/25/90  
ZLBats 2/5/90 R. Supkari 2/5/90

1-MCC-232-A

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING (A)	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
9B	<del>1-MTR-30-95</del> <del>1-PENT 293-32</del> FAN A	A025	LO	Y 75 Y	1	T40	SHAW-MUT	TRS-30	Y 30 N	10x2 12	IPL520 IPL521
9FZ	<del>1-PO-232-5-B</del> <del>1-JB-292-186A</del>	B100	N/A	Y 100	N/A	N/A	SHAW-MUT	DISAB100	Y 100	2	IPL250, 251-253
10B	<del>1-MTR-30-99</del> <del>1-PENT 293-24</del> FAN G	A025	LO	Y 75 Y 405	1	T40	"	TRS-30	Y 30 N N	10x2 12	IPL550 IPL551
10F	<del>1-HST-78-ST12B</del> <del>1-PENT 293-32</del> STUD	B020	N/A	Y 20 Y	N/A	N/A	"	DISA030	N 30 N	10 12	IPL270 IPL271
11D	<del>1-PENT-293-24</del> RCDT A	B030	N/A	Y 30	2	T45	"	TRS-60	Y 60	8 8	IPL485 IPL486
11F	<del>1-HTR-30-74H</del> <del>1-PENT 293-32</del> HTR A	B020	N/A	Y 20	N/A	N/A	"	DISA030	N 30	10 10	IPL336 IPL337
12F	<del>1-HTR-30-11H</del> <del>1-PENT 293-32</del> HTR A	B020	N/A	Y 20	N/A	N/A	"	"	Y 30	10 10	IPL5440 IPL5441
13A	<del>1-CAN-78-1M</del> <del>1-PENT 293-5</del>	B040	N/A	Y 40	N/A	N/A	"	DISA050	Y 50	6	IPL621
13D	<del>1-AHU-61-1T028</del> <del>1-PENT 293-5</del>	FJ3- B175	LO HE	Y 750 Y 1400	N/A	N/A	SHAW-MUT	CPGA-14 4/0	Y 215/50 Y 215/100	6 4/0x2 2/0	IPL820 IPL821
14B	<del>1-MTR-61-280A</del> <del>1-PENT 293-5</del>	EF3- A010	LO HE	Y 58 Y 36	1	T30 T29	"	TRS-30	N 30 N	12	IPL587 IPL588
14D	<del>1-AHU-61-3T027</del> <del>1-PENT 293-5</del>	FT3- B150	LO HE	Y 750 Y 1600	N/A	N/A	SHAW-MUT	CPGA-14 4/0	Y 215/50 Y 215/100	4/0 2/0	IPL861 IPL862
15A	<del>1-HTR-30-35H</del> <del>1-PENT 293-32</del> A HTR 30-35H	EF3- B070	N/A	Y 70	N/A	N/A	"	DISAB100	N 100	4 4	IPL425 IPL426
15D	1-MTR-30-1	A100 B100	3 N/A	Y 750 Y 400	3	T56	N/A	N/A	N/A	2x2	IPL777
16A	<del>1-HTR-30-33H</del> <del>1-PENT 293-5</del>	B070	N/A	Y 70	N/A	N/A	SHAW-MUT	DISAB100	N 100	4 4	IPL440 IPL441
16D	1-MTR-30-IE	A100	3	Y 760	3	T56	N/A	N/A	N/A	2	IPL764

R15  
 4/11/92  
 J.L.H.  
 04-21-92

R15  
 4/11/92  
 J.L.H.  
 04-21-92

SL-F647 04/84  
 Form GO.3.08.1 Rev. 2

R15  
 4/14/92

WBN EEB-MS-TI15-0011-RO

Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchart Date 1/22/90 Checked Krajmych Date 1/26/90  
Krajmych 1/16/90 R.H. Buchart 1/25/90  
ElBates 2/5/90 R. Supkon 2-5-90

1-MCC-232-B

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							EF3-	(A)	G30		
2A	<del>1-MTR-77-135B</del> <del>PENT-293-47</del> <del>1-MTR-77-135B</del>	A010	43	Y 45	1	T33	SHAW-MUT	TRS-30	N 30	12 10	IPL672 IPL673
3A	<del>1-MTR-94-1A</del> <del>PENT-293-35</del>	B020	N/A	Y 20	N/A	N/A	"	"	Y 30	10 10	IPL280 IPL281
3B	<del>1-MTR-94-1B</del> <del>PENT-293-35</del>	B020	N/A	Y 20	N/A	N/A	"	DISA030	N 30	10 10	IPL285 IPL286
3C	<del>1-MTR-94-1C</del> <del>PENT-293-35</del>	B020	N/A	Y 20	N/A	N/A	"	DISA030	N 30	10 10	IPL290 IPL291
5E	1-MTR-30-11	A003	HI 2	Y 40	1	T18 T16	N/A	N/A	N/A	12	IPL794
6A	0-MTR-31-26	A010	4	Y 58	1	T34	N/A	N/A	N/A	12	IPL752
6C	1-MTR-61-61	L050	4	N 330	2	T51	N/A	N/A	N/A	8	IPL4325
6D	1-HTR-61-93	B050Z	N/A	Y 50		T54 T51	N/A	N/A	N/A	6	IPL4310
6E	1-MTR-30-11E	A003	HI 2	Y 40	1	T18 T16	N/A	N/A	N/A	12	IPL760
6F1	<del>1-MTR-40-2</del> <del>STR-40-2</del>	B020	N/A	Y 20	N/A	N/A	SHAW-MUT	DISA030	N 30	10	IPL695
7B	<del>1-HTR-68-31AA</del> <del>PENT-293-35</del>	A010	L0 4	Y 58	1	T31 T36	"	TRS-30	N 30	12 12	IPL376 IPL377
7D	<del>1-MTR-68-85</del> <del>PENT-293-35</del>	B040	N/A	Y 40	1	T45 T44	"	"	Y 30	10 10	IPL402 IPL403
8B	<del>1-HTR-68-73AA</del> <del>PENT-293-47</del>	A010	L0 2	Y 38	1	T31 T36	"	"	N 30	12 12	IPL388 IPL389
8D	<del>1-MTR-68-87</del> <del>PENT-293-47</del>	B040	N/A	Y 40	1	T45 T44	"	"	Y 30	10 10	IPL414 IPL415
8F1	DXF 0-SW-234-B/ IPS	40 3030	N/A	Y 40 30	N/A	N/A	SHAW-MUT	DISA030	Y 30	1/0x2	IPL1115
9B	<del>1-MTR-30-97</del> <del>PENT-293-35</del>	A025	L0	Y 75 Y	1	T40	"	TRS-30	Y 30 N	10 12	IPL531 IPL532

R15  
 4/14/92  
 J.H.  
 04-21-92

R15  
 4/14/92  
 J.H.  
 04-21-92

Form GO-3.08.1 Rev. 2 SL-F647 04/84

Page 182 of 200  
 Page 181 of 200  
 418 2/5/90  
 102 of 201  
 181 of 200  
 R15  
 11492  
 3-28

WBN EEB-MS-TI15-0011 R0

Page 153 of 172

Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchert Date 1/22/90 Checked Kingmucker Date 1/26/90  
Kingmucker 1/16/90 R.H. Buchert 1/25/90  
H.Bates 2/5/90 R. Supkan 2-5-90

1 - MCC-232-B

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
10B	1-MTR-30-100 +PENT 293-47	A025	LO	Y 75 Y 105	1	T40	SHAW-MNT	TRS-30	Y 30 N	10 12	IPL561 IPL562
10F	1-CRN-78-15 +PENT 293-11	B020	N/A	Y 20	N/A	N/A	"	"	Y 30	10 10	IPL707 IPL708
11D	1-MTR-77-6 +PENT 293-11	B070 B100	N/A	Y 70 Y 100	2	T4B F49	"	TRS-60	Y 60	4 4	IPL496 IPL497
11F	1-HTR-30-75H +PENT 293-35	B020	N/A	Y 20	N/A	N/A	"	DISA030	N 30	10 10	IPL345 IPL346
12F	1-HTR-30-12H +PENT 293-35	B020	N/A	Y 20	N/A	N/A	"	"	N 30	10 10	IPL545D IPL545I
13B	1-MTR-61-280B +PENT 293-11	A010	4 2	Y 58 Y 36	1	T30 F29	"	TRS-30	Y 30 N	10 12	IPL598 IPL599
13D	1-AHV-61-2T030 +PENT 293-11	FJ3- B175	LO HI	Y 750 4600	N/A	N/A	"	CP6A-14 4/0	XY 21/2/490 XY 21/2/2/0	4/0 2/0	IPL897 IPL975 IPL902
13F	1-CRN-61-1BC +PENT 293-11	B030 B050	N/A	Y 30 Y 50	N/A	N/A	"	DISA050	Y 50	6 6	IPL712 IPL713
14B	1-CRN-78-1RCC +PENT 293-11	A003	HI LO	Y 21 Y 7	1	T1B F12	"	TRS-30	N 30	12 12	IPL1100 IPL1101
14D	1-AHV-61-5T029 +PENT 293-11 (FAHU)	FJ3- B150	LO HI	Y 750 Y 1600	N/A	N/A	"	CP4/0 -CS	Y	4/0 2/0 2/0	IPL937 IPL938 IPL933
14F	1-CRN-78-1EH +PENT 293-11	B030 EF3 B040	N/A	Y 30 Y 40	N/A	N/A	"	DISA050	Y 50	6 6	IPL704 IPL705
15A	1-HTR-30-37H +PENT 293-35	B070	N/A	Y 70	N/A	N/A	"	DISA100	N 100	4 4	IPL454 IPL455
15D	1-MTR-30-4	A100	3	Y 750 Y 760	3	T56 F57	N/A	N/A	N/A	2	IPL785
16A	1-HTR-30-100M +PENT 293-47	B070	N/A	Y 70	N/A	N/A	SHAW-MNT	DISA8100	N 100	4 4	IPL468 IPL469
16D	1-MTR-30-4E * IPL 902 → IPL 907(2/0) → IPL 912(3/6) → IPL 917(3/6) → IPL 922(2/6) → IPL 927(2/6) → IPL 932(2/6) ** IPL 943 → IPL 948(2/0) → IPL 953(3/6) → IPL 958(2/6) → IPL 963(2/6) → IPL 968(2/6)	A100	2 2	Y 630 Y 760	3	T56 F57	N/A	N/A	N/A	2	IPL768

Form GO-3.08.1 Rev. 2 SL-F647 04/84

R15  
 11492  
 J.I.A.  
 04-21-92

418 2/15/90  
 184 of 204  
 183 of 200  
 R15  
 4/1/92  
 7-7-91

~~WBN EEB-MS-TI15-0011 R9~~

Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchart Date 1/22/90 Checked Kaymeda Date 1/26/90  
Kaymeda 1/16/90 Deon Kelley 1/25/90  
B. Bates 2/5/90 R. Supkar 2-5-90

2-MCC-213-A1

COMPT NO	SERVICE	BKR	SET	TRIP	STR	DL	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		TYPE	POS	RATING	SIZE	CAT#	MFR	MODEL	RATING		
16A	2-PENT-293-32 (2-MTR-31-265)	A010	3	Y45	1	T34	SHAW-MUT	TRS-30	Y30 N	10 12	2PL6300 2PL6301
16B	2-PENT-293-24 (2-MTR-77-129)	A010	LO	Y27	1	T27	"	"	Y30 N	10 12	2PL6268 2PL6269
16F1	CHGR 0-XSW-252-1	ED63- B030 B020	N/A	Y30	N/A	N/A	N/A	N/A	N/A	10	2PL6040
16F2	MTR 2-TB-31-303/2	B020	N/A	Y20	N/A	N/A	N/A	N/A	N/A	10	2PL6289
17A	2-HTR-62-228/4 0-JB-292-205 (2-HTR-62-228/4)	B040 B030	N/A	Y40 30 Y	N/A	N/A	N/A	N/A	N/A	8 12 12	2PL6208 2PL6209 2PL6210
17E	2-PO-213-A1/5 2-PENT-293-32 (2-PO-213-A1/5) (2-PO-213-A1/5)	ED63- B100	N/A	Y100	N/A	N/A	SHAW-MUT	CP6A-197 #2	N/A	2 2	2PL6100 2PL6094
18C	2-MTR-31-303/1	A010	3	Y45	1	T32	N/A	N/A	N/A	12	2PL6281
18F1	CHGR 0-XSW-253-1	ED63- B020	N/A	Y20	N/A	N/A	N/A	N/A	N/A	10	PL888
18F2	2-PO-213-A1/6-10 2-JB-293-2860 (2-PO-213-A1/6-10)	ED63- B100	N/A	Y100	N/A	N/A	N/A	N/A	N/A	2	2PL6093

R15  
 4/1/92  
 J.I.H.  
 04-21-92

R15  
 4/1/92  
 J.I.H.  
 04-21-92

Form GG-308.1 Rev. 2 SL-F647 04/84



2182/5/90  
 185 of 201  
 184 of 200  
 3-7-91

R15  
 m.n. 4/13/90

WBN EEB-MS-TI15-0011 R0  
 Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Page 1156 of H72

Prepared Kingman Date 1/22/90 Checked R.H. Buchheit Date 1/26/90  
Kingman 1/16/90 Scott Kelley 1/25/90

2-MCC-213-A2

COMPT NO	SERVICE	BKR	SET	TRIP	STR	DL	SECONDARY			CABLE SIZE	CABLE NO
		TYPE	POS	RATING	SIZE	CAT#	PROTECTION				
		EF3-		(A)		G30	MFR	MODEL	RATING		
4A	2-FCV-3-191	A010	3	Y45	1	T31	N/A	N/A	N/A	12	2V3260
4B	2-FCV-3-192	A010	3	Y45	1	T31	N/A	N/A	N/A	12x2	2V3280
13B	0-FCV-67-360	A010	2	Y36 =7	1	T29 T28	N/A	N/A	N/A	12	2V3230

R15  
 m.n. 4/13/90  
 J.H.  
 04-21-92

R15  
 4/13/92

WBN EEB-MS-TI15-0011  
 Installation of Non-IE Power Circuits Located in Category 1 Structures

Page 157 of 172

Prepared R.H. Buchart Date 1/22/90 Checked Knapphuder Date 1/26/90  
Knapphuder 1/16/90 Scott Kelley 1/25/90  
JLBate 2/15/90 R. Supkan 2-5-90

2-MCC-213-B1

COMPT NO	SERVICE	BKR	SET	TRIP	STR	OL HTR	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		TYPE	POS	RATING	SIZE	CAT#	MFR	MODEL	RATING		
3F1	CHGR 0-XSW-252-2	30 ED63-	N/A	Y 20	N/A	N/A	N/A	N/A	N/A	10	2PL6045
16A	2-PENT-293-35 (2-MTR-31-266)	A010	3	Y 45	1	T34	SHAQ-MUT	TAS-30	Y 3.0 N	10 12	2PL6310 2PL6311
16E	2-PO-213-B1/4-5 2-PENT-293-47 (2-PO-213-31/1-5)	B100	N/A	Y 100	N/A	N/A	"	CP6A-51 #2-197	N.Y. JLB 2/15/90 RFB 2/15/90	2X2 2	2PL6085 2PL6086
17A	2-MTR-62-228/3 0-JB-292-2048 (2-MTR-62-228/3)	3040	N/A	Y 40 N.Y. N.Y.	2	N/A	N/A	N/A	N/A	8x2 12 12	2PL6214 2PL6215 2PL6216
17E	2-PO-213-B1/6-10 2-PENT-293-35 (2-PO-213-31/6-10)	B100	N/A	Y 100	N/A	N/A	SHAQ-MUT	CP6A-197 #2-197	N.Y. JLB 2/15/90 RFB 2/15/90	2 2	2PL6075 2PL6076
17F1	CHGR 0-XSW-253-2	3020	N/A	Y 20	N/A	N/A	N/A	N/A	N/A	10	PL894
17F2	MTR 2-TB-31-324/2	B020	N/A	Y 20	N/A	N/A	N/A	N/A	N/A	10	2PL6291
18C	2-MTR-31-324/1	A010	3	Y 45	1	T32	N/A	N/A	N/A	10	2PL6285

R15  
 4/13/92  
 J.L.H.

04-21-92

R15  
 4/13/92  
 J.L.H.

04-21-92

R15  
 4/13/92  
 J.L.H.

04-21-92

SL-F647 04/84  
 Form GO-3.08.1 Rev. 2

Calculation of Non-IE Power Circuits Located in Category 1 Structures

Prepared Ameyhndar Date 1/21/90 Checked R.A. Buckart Date 1/26/90  
Ameyhndar 1/16/90 Scott Welley 1/25/90

2-MCC-213-B2

COMPT NO	SERVICE	BKR	SET	TRIP	STR	DL MTR	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		TYPE	POS	RATING	SIZE	CAT#	MFR	MODEL	RATING		
		EF3-		(A)		G30					
4A	2-FCV-3-193	A010	3	45	1	T31	N/A	N/A	N/A	12x2	2V3290
4B	2-FCV-3-194	A010	3	45	1	T31	N/A	N/A	N/A	12	2V3270
5A	0-FCV-26-15	A003	LO	7	1	T9 T6	N/A	N/A	N/A	12	2V3360
5B	0-FCV-26-16	A003	LO	7	1	T9 T6	N/A	N/A	N/A	12	2V3370

R15  
 4/13/92  
 J.I.H.  
 04-21-92

WBN EEB-MS-TI15-0011 R0

Page 459 of 472

Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Brubaker Date 1/22/90 Checked Jim Brubaker Date 1/26/90  
Knighthead 1/16/90 Scott Kelley 1/25/90

2-MCC-214-A1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		EF3-		(A)		G30	MFR	MODEL	RATING		
2D	2-MTR-81-3	H050	2	Y 400	3	T51	N/A	N/A	N/A	6	2PL3221
2F1	0-DXF-234-A2/SIS	B020	N/A	Y 20	N/A	N/A	SHAU-MVT	HFCP	N 30	10	2PL3590
2F2	2-DXF-242-1	<del>FXD 63 B125 3070</del>	5	<del>Y 1200 70</del>	N/A	N/A	"	"	N 100	4	2PL3596
3F1	2-RE-90-119	B020	N/A	Y 20	N/A	N/A	"	"	N 30	10	2PL3589
0F1	0-TB-40-3	B020	N/A	Y 20	N/A	N/A	"	"	N 30	10	2PL3720
12F2	0-DXF-227-1	B050	N/A	Y 50	N/A	N/A	"	"	Y 50	6	2PL3713
7D	0-DXF-234-AV/CVCS	FJB-B125	N/A	Y 125	N/A	N/A	N/A	N/A	N/A	1/0	2PL3580
4F2	0-DXF-234-AA/CVCS	<del>EF3 B020</del>	N/A	Y 20	N/A	N/A	SHAU-MVT	HFCP	N 30	10	2PL3017
12E1	2-PNL-90-L398	B020Z	N/A	Y 20	N/A	N/A	"	"	N 30	10	2PL3610
13A	2-MTR-84-16	A005	3	Y 22	1	T25	N/A	N/A	N/A	12	2PL2940
13C	2-MTR-65-77	A005	HI	Y 41	1	T31	N/A	N/A	N/A	12	2PL3645

R15  
 4/24/92  
 J.L.H.  
 04-24-92

R15  
 4/24/92  
 J.L.H.  
 04-24-92

Page 188 of 200  
 2/15/90  
 1/26/90  
 3-7-91

R15  
 4/13/92

EEB-MS-TI15-0011 R9  
 Tabulation of Non-IE Power Circuits Located in Category 1 Structures  
 Prepared Kojmudal Date 1/22/90 Checked R.H. Buchart Date 1/26/90  
R.H. Buchart 1/10/90 Scott Kelley 1/25/90

2-MCC-214-B1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		EF3-		(A)	G30	MFR	MODEL	RATING			
2D	2-MTR-81-7	A050	2	Y400	3	T51	N/A	N/A	N/A	6	2PL3228
3F2	0-DXF-234-B2 SIS	B020	N/A	Y20	N/A	N/A	SHAW-MUT	DISA030	N30	10	2PL3375
2F1	0-TB-40-66	B020	N/A	Y20	N/A	N/A	"	"	N30	10	2PL3730
9F1	2-XFMR-290-236 <del>2-PNL-55-1237</del>	B020	N/A	Y20	N/A	N/A	SHAW-MUT	DISA030	N30	10	2PL2972
12A	2-MTR-30-181	A010	3	Y45	1	T32	N/A	N/A	N/A	10	2PL3021
TD	0-DXF-234-B1 CVCS	EF3- B125	HI	Y1600	N/A	N/A	N/A	N/A	N/A	2/0	2PL3744
12F1	2-RE-90-99	EF3- B020	N/A	Y20	N/A	N/A	SHAW-MUT	DISA030	N30	10	2PL3790
13A	2-MTR-24-21	A005	3	Y22	1	T25	N/A	N/A	N/A	12	2PL2948
12F2	0-DXF-227-3	B070	N/A	Y70	N/A	N/A	SHAW-MUT	DISA B100	N100	4	2PL3719
13C	2-MTR-65-74	A005	HI	Y41	1	T31	N/A	N/A	N/A	12	2PL3660

R15  
 4/11/92  
 J.L.H.  
 04-21-92

Shawmut DISA and HECP are the same fuse.

Form GO-3.08.1 Rev. 2 SL-F647 04/84

WBN EEB-MS-TI15-0011 R0  
 Tabulation of Non-IE Power Circuits Located in Category 1 Structures  
 Prepared Amjad Nadeem Date 1/22/90 Checked R.H. Buckner Date 1/24/90  
Amjad Nadeem 1/16/96 Drew Kelley 1/25/90

2-MCC-214-A2

COMPT NO	SERVICE	BKR	SET	TRIP	STR	DL	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		TYPE	POS	RATING	SIZE	CAT#	MFR	MODEL	RATING		
		EF3-		(A)		G30					
2DI	2-HTR-30-A1A	B020	N/A	Y 20	N/A	N/A	SHAW-MUT	DISA030	N 30	10	2PL3280
6DI	0-HTR-30-AB1	B020	N/A	Y 20	N/A	N/A	"	"	N 30	10	2PL2815
2E1	2-HTR-30-B1A	B020	N/A	Y 20	N/A	N/A	"	"	N 30	10	2PL3284
6F1	0-HTR-31-339	B020	N/A	Y 20	N/A	N/A	"	"	N 30	10	2PL3833
7DI	0-HTR-30-AB2	B020	N/A	Y 20	N/A	N/A	"	"	N 30	10	2PL2819
3A	2-MTR-30-25	A10	3	Y 45	1	T31	N/A	N/A	N/A	12x2	2PL2906
3DI	2-HTR-30-ACRD	B020	N/A	Y 20	N/A	N/A	SHAW-MUT	DISA030	N 30	10	2PL3266
3E1	2-HTR-30-C1A	B020	N/A	Y 20	N/A	N/A	"	"	N 30	10	2PL3288
3E2	2-HTR-31-D1A	B050	N/A	Y 50	N/A	N/A	"	DISA050	Y 50	6x2	2PL3510
3F1	0-HTR-31-91	B020	N/A	Y 20	N/A	N/A	SHAW-MUT	DISA030	N 30	10	2PL2800
3F2	2-HTR-30-1A1	B020	N/A	Y 20	N/A	N/A	"	"	N 30	10	2PL3365
4A	2-MTR-30-67	A005	HI 4	Y 41 29	1	T29	N/A	N/A	N/A	12	2PL3621
4E1	2-HTR-30-BCRD	B020	N/A	Y 20	N/A	N/A	SHAW-MUT	DISA030	N 30	10x2	2PL3264

R15  
 04-21-92

Form GO-3.08.1 Rev. 2 SL-F647 04/84

WBN EEB-MS-TI15-0011  
 Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared Kanghuda Date 1/22/90 Checked Don Helly Date 1/24/90  
Kanghuda 1/16/90

2-MCC-214-A2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		EF3-		(A)		G30	MFR	MODEL	RATING		
4F1	2-HTR-30-CCRD	B020	N/A	Y20	N/A	N/A	SHAW-MUT	DISA030	N30	10X2	2PL3268
5A	2-MTR-30-301	A010	3	Y45	1	T34	N/A	N/A	N/A	12	2PL3435
5E1	0-HTR-31-71	B030	N/A	Y30	N/A	N/A	SHAW-MUT	DISA030	Y30	8	2PL3691
5F1	2-HTR-30-XM1A	B020	N/A	Y20	N/A	N/A	"	"	N30	10	2PL3370
5F2	2-HTR-30-AB1	B020	N/A	Y20	N/A	N/A	"	"	N30	10	2PL3314
6E1	2-HTR-30-SMS	B030	N/A	Y30	N/A	N/A	"	"	Y30	8	2PL2811
6E2	2-HTR-30-NM1	B050	N/A	Y50	N/A	N/A	"	DISA050	Y50	6	2PL2806
6F2	0-HTR-30-KM3	B020	N/A	Y20	N/A	N/A	"	DISA030	N30	10	2PL3320
7D2	0-HTR-30-DFH	B040	N/A	Y40	N/A	N/A	"	DISA050	Y50	6	2PL3335
7E1	2-HTR-30-VIA	B020	N/A	Y20	N/A	N/A	"	DISA030	N30	10	2PL2813
7E2	0-HTR-30-EFH	B040	N/A	Y40	N/A	N/A	"	DISA050	Y50	6	2PL3330
7F2	0-HTR-30-FFH	B040	N/A	Y40	N/A	N/A	"	"	Y50	6	2PL3340
8A	2-MTR-30-CRD	FXD63 B125 F33 B125	LO HE	Y800 Y4600	N/A	N/A	N/A	N/A	N/A	2/0	2PL3692
8B	2-HTR-1-CBS	FXD63 F33 B125	LO HE	Y800 Y4600	N/A	N/A	N/A	N/A	N/A	4/0	2PL3680

SL-F647 04/84  
 Form GO-3.08.1 Rev. 2

R15  
 4/13/92  
 J.L.H.  
 04-21-92

WBN EEB-MS-TI15-0011 R0  
 Population of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.H. Buchert Date 1/22/90 Checked R.H. Buchert Date 1/27/90  
R.H. Buchert 1/16/90 R.H. Buchert 1/25/90

2-MCC-214-B2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		EF3-		(A)		G30	MFR	MODEL	RATING		
2B	0-MTR-30-27	A005	HE	Y <sup>41</sup> <sub>29</sub>	1	T28 F27	N/A	N/A	N/A	12	2PL3812
2E1	2-HTR-30-AIB	B020	N/A	Y <sub>20</sub>	N/A	N/A	SHAW-MUT	DISA030	N <sub>30</sub>	10	2PL3676
2E2	0-HTR-30-KFA	B040	N/A	Y <sub>40</sub>	N/A	N/A	"	DISA050	Y <sub>50</sub>	6	2PL3400
2F1	2-HTR-30-BIB	B020	N/A	Y <sub>20</sub>	N/A	N/A	"	DISA030	N <sub>30</sub>	10	2PL3898
2F2	2-HTR-31-BRB	B050	N/A	Y <sub>50</sub>	N/A	N/A	"	DISA050	Y <sub>50</sub>	6	2PL3890
3B	2-MTR-30-285	A005	HI	Y <sup>41</sup> <sub>29</sub>	1	T30 F29	N/A	N/A	N/A	12	2PL3626
3F2	0-HTR-31-93	B040	N/A	Y <sub>40</sub>	N/A	N/A	SHAW-MUT	DISA050	Y <sub>50</sub>	6	2PL3851
3E1	2-HTR-30-CIB	B020	N/A	Y <sub>20</sub>	N/A	N/A	"	DISA030	N <sub>30</sub>	10	2PL3895
3E2	0-HTR-30-LFA	B040	N/A	Y <sub>40</sub>	N/A	N/A	"	DISA050	Y <sub>50</sub>	6	2PL3405
3F1	2-HTR-30-PRX	B020	N/A	Y <sub>20</sub>	N/A	N/A	"	DISA030	N <sub>30</sub>	10	2PL3395
4B	2-MTR-30-302	A010	4	Y <sup>58</sup> <sub>45</sub>	1	T33 F32	N/A	N/A	N/A	12	2PL3438
4E1	0-HTR-31-85	B020	N/A	Y <sub>20</sub>	N/A	N/A	SHAW-MUT	DISA030	N <sub>30</sub>	10	2PL2809
4E2	0-HTR-30-PFA	B040	N/A	Y <sub>40</sub>	N/A	N/A	"	DISA050	Y <sub>50</sub>	6	2PL3415
4F1	2-HTR-30-SBU	B020	N/A	Y <sub>20</sub>	N/A	N/A	"	DISA030	N <sub>30</sub>	10	2PL3425
4F2	2-HTR-30-U113	B020	N/A	Y <sub>20</sub>	N/A	N/A	"	"	N <sub>30</sub>	10	2PL2975
5E1	2-HTR-31-89	B020	N/A	Y <sub>20</sub>	N/A	N/A	SHAW-MUT	DISA030	N <sub>30</sub>	10	2PL2825

R15  
 4/13/92  
 J.L.H.  
 2-4-21-92

R15  
 4/13/92  
 J.L.H.  
 04-21-92

R15  
 4/13/92  
 J.L.H.  
 04-21-92

Form GO-308.1 Rev. 2 SL-F647 04/84



218 2/5/90  
 3-7-91

WBN EEB-MS-TI15-0011 R0  
 Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared R.A. Buchert Date 1/20/90 Checked Kinghuder Date 1/27/90  
Kinghuder 1/16/90 R.A. Buchert 1/20/90

2-MCC-214-82

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		EF3-		(A)		G30	MFR	MODEL	RATING		
5F1	0-HTR-30-RMA	B020	N/A	Y 20	N/A	N/A	SHAW-MUT	DISA030	N 30	10	2PL3385
6B	2-MTR-30-26	A010	4 2	Y 58 45	1	T33	N/A	N/A	N/A	12	2PL2913
6E1	2-HTR-30-AB7	B020	N/A	Y 20	N/A	N/A	SHAW-MUT	DISA030	N 30	10	2PL3381
6F1	2-HTR-30-T1B	B020	N/A	Y 20	N/A	N/A	"	"	N 30	10	2PL3430
5F2	0-HTR-30-U1	B020	N/A	Y 20	N/A	N/A	SHAW-MUT	DISA030	N 30	10	2PL2817
7F1	2-HTR-30-NM2	B050	N/A	Y 50	N/A	N/A	"	DISA050	Y 50	6	2PL3421
7E1	0-HTR-31-99	B020	N/A	Y 20	N/A	N/A	"	DISA030	N 30	10	2PL3840
8F2	2-PO-214-10-12 <del>2-JB-292-19</del>	B100	N/A	Y 100	N/A	N/A	"	DISA100	Y 100	2	2PL2785
9A	2-MTR-30-CRB	FXD63 B125	LO	Y 800 750	N/A	N/A	N/A	N/A	N/A	2/0	2PL3671
8E2	0-HTR-30-A1A	B020	N/A	Y 20	N/A	N/A	SHAW-MUT	DISA030	N 30	10	2PL3390

R15  
 4/13/92  
 J.C.H.  
 04-21-92

R15  
 4/13/92  
 J.C.H.  
 04-21-92

Form GO-3.08.1 Rev. 2 SL-F647 04/84

WBN EEB-MS-TI15-0011 RO  
 Installation of Non-IE Power Circuits Located in Category 1 Structures

Prepared kingman Date 1/22/90 Checked R.H. Buchert Date 1/26/90  
R.H. Buchert 1/17/90 kingman 1/25/90

2-MCC - 215 - A1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO.
		EF3-		(A)		G30	MFR	MODEL	RATING		
5A	2-MTR-82-241	A025E	2 L0	105 75	1	T39 F38	N/A	N/A	N/A	12	PL2205
5F1	0-HTR-30-480	B020	N/A	120	N/A	N/A	N/A	N/A	N/A	10	PL2334
5F2	2-PO-215-1-5 2JB-296-257 (P.O'S)	B100	N/A	100	N/A	N/A	N/A	N/A	N/A	2	PL2543
6A	MTR 2SW-30-464	A005	HI 2	41 18	1	T28 F26	N/A	N/A	N/A	12	PL2242

R15  
 4/13/92  
 04-21-92  
 J.H.H.

R15  
 4/13/92  
 J.H.H.  
 04-21-92

Form GO-3.08.1 Rev. 2 SL-F647 04/84

Page 1950 of 201  
 1946 of 200  
 3-7-91

R15  
 m.a. 4/13/92

Population of Non-IE Power Circuits Located in Category 1 Structures  
 Prepared Krajmuder Date 1/22/90 Checked R.H. Buchat Date 1/26/90  
R.H. Buchat 1/17/90 Krajmuder 1/25/90

2-MCC-215-B1

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
5A	2-MTR-82-271	A025Z	2 <del>LO</del>	Y 105 <del>75</del>	1	T39 <del>F38</del>	N/A	N/A	N/A	12	PL2225
5F1	0-HTR-30-482	B020	N/A	Y 20	N/A	N/A	N/A	N/A	N/A	10	PL2328
6A	MTR 2-SW-30-466	A005	HI <del>Z</del>	Y 41 <del>18</del>	1	T29 <del>F26</del>	N/A	N/A	N/A	12	PL2255
5F2	2-PO-215-5,6,7 <del>2-JB-296-259</del> (P.O.'s)	B100	N/A	Y 100	N/A	N/A	N/A	N/A	N/A	2	PL2556

R15  
 m.a. 4/13/92  
 J.L.H.  
 04-21-92

R15  
 m.a. 4/17/92  
 J.L.H.  
 04-21-92

Form GO-3.08.1 Rev. 2 SL-F647 04/84

Page 196 of 204  
 195 of 200  
 2/15/90  
 3-7-91

R15  
 4/17/92

EEB-MS-TI15-0011  
 Location of Non-IE Power Circuits Located in Category 1 Structures

Prepared by R.H. Buchert Date 1/22/90 Checked by R.H. Buchert Date 1/24/90  
R.H. Buchert 1/17/90 R.H. Buchert 1/25/90

2-MCC-215-A2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
		EF3-		(A)		G30	MFR	MODEL	RATING		
3E1	2-HTR-30-488	B020	N/A	Y20	N/A	N/A	N/A	N/A	N/A	10	PL2413
3F1	2-HTR-30-475	B030	N/A	Y30	N/A	N/A	N/A	N/A	N/A	8	PL2286
3F2	2-HTR-30-476	B030	N/A	Y30	N/A	N/A	N/A	N/A	N/A	8	PL2292
5A	2-MTR-82-240	A025Z	2	Y105	1	T38	N/A	N/A	N/A	12	PL2210
6D	2-HTR-82-100 <del>2-TB-82-A/A</del>	B020	N/A	Y20	1	N/A	N/A	N/A	N/A	12	PL2703

R15  
 4/17/92  
 J.L.H.  
 04-21-92

Form GO-3.08.1 Rev. 2 SL-F647 04/84

EEB-MS-TI15-0011 R0

Page 1168 of 1172

Enumeration of Non-IE Power Circuits Located in Category 1 Structures

Prepared by Kingma Date 1/22/90 Checked by R.A. Buchert Date 1/26/90  
R.A. Buchert 1/17/90 Kingma 1/25/90

2-MCC-215-B2

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
3E1	2-HTR-30-490	B020	N/A	Y20	N/A	N/A	N/A	N/A	N/A	10	PL2414
3F1	2-HTR-30-477	B030	N/A	Y30	N/A	N/A	N/A	N/A	N/A	8	PL2298
3F2	2-HTR-30-478	B030	N/A	Y30	N/A	N/A	N/A	N/A	N/A	8	PL2775
5A	2-MTR-82-270	A025	2 L0	Y105 75	1	T39 T38	N/A	N/A	N/A	12	PL2230
6D	2-HTR-82-200 <del>2-HTR-82-81-8</del>	B020	N/A	Y20	1	N/A	N/A	N/A	N/A	12	PL2709
4B	0-MTR-18-913	A025	3	Y25	1	T24	N/A	N/A	N/A	10	PL2460

R15  
 rev. 4/13/92  
 J.L.H.  
 04-21-92  
 rev. 4/13/92  
 R15

Form GO-3.08.1 Rev. 2 SL-F647 04/84

WBN EEB-MS-T115-0011 R0

Tabulation of Non-IE Power Circuits Located in Category I Structures

Prepared R. A. Buckart Date 1/22/90 Checked James Law Date 1/26/90  
W. Bates 1/16/90 2/5/90 2-MCC-232-A  
Sweet Melley 1-15-90  
R. Supkan 2-5-90

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	DL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							EF3-	(A)	G30		
ZA	2-PENT-293-24	A010	3	Y 45	1	T33	SHAW-MUT	TRS-30	Y 30 N	10 12	2PL653 2PL654
3A	2-PENT-293-35 FLUX D	B020	N/A	Y 20	N/A	N/A	"	"	Y 30	10x2 10	2PL295 2PL296
3B	2-PENT-293-35 FLUX E	B020	N/A	Y 20	N/A	N/A	"	DISA030	N 30	10x2 10	2PL300 2PL301
3C	2-PENT-293-35 FLUX F	B020	N/A	Y 20	N/A	N/A	"	DISA030	N 30	10x2 10	2PL305 2PL306
4D	2-MTR-61-51	L050	4	N 330	2	T51	N/A	N/A	N/A	8	2PL4320
4E	2-HTR-61-92	B050	N/A	Y 50	2	T51	N/A	N/A	N/A	6x2	2PL4309
6C	0-MTR-77-105	H050	2	Y 400 320	2	T53 T52	N/A	N/A	N/A	6x2	2PL5460
7B	2-PENT-293-32 RCP 1 HTR	A010	2	Y 36	1	T36	"	TRS-30	N 30	12 12	2PL370 2PL371
7D	2-PENT-293-32 RCP 1 LIFT	A025	4	Y 170	1	T44	"	"	Y 30	10 10	2PL396 2PL397
7F2	2-PO-232-1-4 <del>2-JB-292-981</del> <del>(4-PO-232-1-4)</del>	B100	N/A	Y 100	N/A	N/A	SHAW-MUT	DISAB100	Y 100	2	2PL258
8B	2-PENT-293-24 RCP 3 HTR	A010	2	Y 36	1	T36	"	TRS-30	N 30	12 12	2PL382 2PL383
8D	2-PENT-293-24 RCP 3 LIFT	A025	3	Y 125	1	T44	"	"	Y 30	10 10	2PL408 2PL409
8FZ	2-PO-232-9,10	B100	N/A	Y 100	N/A	N/A	SHAW-MUT	DISAB100	Y 100	2	2PL240

Form 00-3.08.1 Rev. 2 SL-F647 04/84

R15  
 4/1/92  
 J.L.H.  
 04-21-92  
 R15  
 4/1/92  
 J.L.H.  
 04-21-92  
 R15  
 4/1/92  
 J.L.H.  
 04-21-92

WBN EEB-MS-TI15-0011 R9

Page ~~171~~ of ~~172~~ <sup>172</sup>

Tabulation of Non-IE Power Circuits Located in Category 1 Structures

Prepared Kingmaker Date 1/22/90 Checked R.H. Buckner Date 1/26/90  
Kingmaker 1/16/90 Steve Kelley 1/25/90  
GLBats 2/5/90 R. Supkar 2-5-90

2-MCC-232-B

COMPT NO	SERVICE	BKR TYPE	SET POS	TRIP RATING	STR SIZE	OL HTR CAT#	SECONDARY PROTECTION			CABLE SIZE	CABLE NO
							MFR	MODEL	RATING		
		EF3-		(A)		G30					
2A	2-PENT-293-47	A010	3	Y45	1	T33	SHAW-MUT	TRS-30	N30	12 10	2PL672 2PL673
3A	2-PENT-293-32	B020	N/A	Y20	N/A	N/A	"	DISA030	N30	10x2 10	2PL280 2PL281
3B	2-PENT-293-32	B020	N/A	Y20	N/A	N/A	"	"	N30	10x2 10	2PL285 2PL286
3C	2-PENT-293-32	B020	N/A	Y20	N/A	N/A	"	"	N30	10x2 10	2PL290 2PL291
5E	2-MTR-30-11	A003	4	Y16	1	T16	N/A	N/A	N/A	12	2PL794
6F2	2-JB-292-1868	B100	N/A	Y100	N/A	N/A	SHAW-MUT	DISAB100	Y100	2	2PL233
6C	2-MTR-61-61	L050	4	N330	2	T51	N/A	N/A	N/A	8	2PL4325
6D	2-HTR-61-93	B050	N/A	Y50	2	T51	N/A	N/A	N/A	6x2	2PL4310
6E	2-MTR-30-11E	A003	2	Y10	1	T16	N/A	N/A	N/A	12	2PL760
6F1	MTR 2-STR-40-2	B020	N/A	Y20	N/A	N/A	SHAW-MUT	DISA030	N30	10	2PL695
7B	2-PENT-293-35	A010	2	Y36	1	T36	"	TRS-30	N30	12 12	2PL376 2PL377
7D	2-PENT-293-35	A025	4	Y170 Y	1	T44	"	"	Y30 Y	8 10	2PL402 2PL403
8B	2-PENT-293-47	A010	2	Y36	1	T36	"	"	N30	12 12	2PL388 2PL389
8D	2-PENT-293-47	A025	4	Y170	1	T44	SHAW-MUT	TRS-30	Y30	10 10	2PL414 2PL415
8F2	2-PO-232-16-19 2-JB-292-1866	B100	N/A	Y100	N/A	N/A	SHAW-MUT	DISAB100	Y100	2	2PL242
9B	2-PENT-293-35	A025	1	Y75 Y	1	T40	"	TRS-30	Y30 N	10 12	2PL531 2PL532

Form 00-308.1 Rev. 2 SL-F647 04/84

R15  
4/14/92  
J.L.H.  
04/21/92

R15  
4/14/92  
J.L.H.  
04/21/92

R:\COMPUTER\... DATE 3-2-91

CHECKED: EH DATE 4/16/91

WBN EEB-MS-TI15-0011 RO

480 V Power Cable Associated Circuits

ATTACHMENT Page 144

APPENDIX A

Page A4 of A5

300  
 3-2-91

R15  
 m.a.  
 4/24/92

Prepared Hut Date 2/2/90 Checked Jim Z Date 2/2/90

90°C RATED CABLE PROTECTION (0-10 SEC. REGION ONLY)

CABLE SIZE	MAXIMUM PROTECTIVE DEVICE RATING	REFERENCE
# 2/0 AWG	W DS BKR SENSOR 150A LT DELAY @ 36 SEC. INST or START TIME PU upto 12 TIMES SENSOR RATING (THE USE OF OTHER SETTINGS SHOULD BE INVESTIGATED ITE - FXD63B125	TC-91 & <del>D16</del> D2 (APP.C) (APP.D)  CURVE FXD63B125 (ATT. M08614A)
# 4/0 AWG	ITE - FJ3 B 225 W DS BKR SENSOR 300A LT DELAY @ 36 SEC INST or START TIME PU UPTO 12 TIMES SENSOR RATING (THE USE OF OTHER SETTINGS SHOULD BE INVESTIGATED - SHMT - CP6A - 350 MCM - SHMT - CP6 - 750 MCM - SHMT - CP - 750 MCM ITE - FXD63B125	TC-27 & <del>D21</del> <sup>D6</sup> (APP.C & D) TC-7 & <del>D16</del> <sup>D2</sup> (APP.C & D)

R11

R11

R15  
 m.a.  
 4/24/92  
 J.H. 04-24-92



R15  
 rev. 4/24/92

R11 COMPUTED TIB DATE 3-7-91

CHECKED EBJ DATE 4/16/91

WBN EEB-MS-TI15-0011  
480 V Power Cable Associated Circuits

~~ATTACHMENT ID~~ Page 45 of 200

~~APPENDIX A~~

Page 15 of Final

3-7-91

Prepared HA Date 2/2/90 Checked Jmk Date 2/2/90

90°C RATED CABLE PROTECTION (0-10 SEC. REGION ONLY)

CABLE SIZE	MAXIMUM PROTECTIVE DEVICE RATING	REFERENCE
300 MCM	<u>W</u> JA 225A	TC-86 & <del>D1</del>
	<u>W</u> LA 400A	TC-33 & <del>D3</del>
	<u>W</u> DS BKR SENSOR 600A LT Delay @ 20 Sec. INSTANT OR SHORT TIME PU UP TO 12 TIMES SENSOR RATING (THE USE OF OTHER SETTINGS SHOULD BE INVESTIGATED) - SHMT CPG - 1000 MCM - SHMT - CPA - 500 MCM ITE - FXD63 B225	TC-89 & <del>D2</del>
400 MCM	SHMT CPA UP TO 1000 MCM	TC-13 & <del>D4</del>

APP. C&D

R11

CURVE FXD63 B225 (ATT. M08614A)

R15 rev. 4/24/92  
 J.L.H.  
 04-24-92

(APP. C&D)

R11

NOTES


- 1) THE MAXIMUM PROTECTIVE DEVICES LISTED AGAINST A 90° CABLE WILL PROTECT THAT CABLE THROUGH 0-10 SECONDS.
- 2) THE MAXIMUM PROTECTIVE DEVICES LISTED AGAINST A CABLE SIZE WILL ALSO PROTECT LARGER DIAMETER CABLES OF 90°C RATING THROUGH 10 SEC.
- 3) THE DIAMETER OF A CABLE INCREASES AS THE AWG NUMBER DECREASES FROM #14 TO #1.

WBN EEB-MS-TI15-0011

PREPARED BY: m.a. DATE: 4/24/92

ATTACHMENT M08614A/M12212A CHECKED BY: J.L.H. DATE: 04-24-92

Appendix 5 Page 1



WBN EEB-MS-TI15-0011  
ATTACHMENT M08614A/M12212A  
Appendix 5 Page 2

PREPARED BY M.A. DATE 4/24/92  
CHECKED BY J.H. DATE 02-24-92

