



Tennessee Valley Authority, Post Office Box 2000, Decatur, Alabama 35609-2000

July 29, 2008

10 CFR 50.55a

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Stop: OWFN P1-35
Washington, D.C. 20555-0001

Gentlemen:

In the Matter of)
Tennessee Valley Authority)

Docket No. 50-260

BROWNS FERRY NUCLEAR PLANT (BFN) - UNIT 2 - AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME) SECTION XI, INSERVICE INSPECTION (ISI) PROGRAM, THIRD TEN-YEAR INSPECTION INTERVAL - REQUEST FOR RELIEF 2-ISI-18, REVISION 1

In accordance with 10 CFR 50.55a(g)(5)(iii), TVA is requesting relief from certain inservice inspection (ISI) requirements in Section XI of the ASME Boiler and Pressure Vessel Code. The need for this request for relief was identified during ISI examinations completed during the BFN Unit 2, Cycles 13 and 14 refueling outages.

TVA determined that certain BFN Unit 2 welds had nondestructive examination (NDE) coverage limitations (less than 90 percent coverage completed) which exceed that specified in ASME Code Case N-460, "Alternative Examination Coverage for Class 1 and Class 2 Welds, Section XI, Division 1."

TVA has determined that 10 welds had nondestructive examination (NDE) coverage limitations (less than 90 percent coverage completed) which exceed that specified in ASME Code Case N-460, "Alternative Examination Coverage for Class 1 and Class 2 Welds, Section XI, Division 1." The welds are Category R-A (Westinghouse Owners

A047
NCR

U.S. Nuclear Regulatory Commission
Page 2
July 29, 2008


Group (WOG) WCAP-14572, Revision 1-NP-A) Class 1 piping welds. These weld examinations had calculated NDE examination coverage ranging between 50 and 87 percent. The limitations encountered during the performance of the ultrasonic (UT) examination were caused by component configuration. Three of the welds received greater than 90 percent examination coverage per the requirements of ASME Section XI. However, 10 CFR 50.55a(b)(2)(xv)(A)(2) restricts taking credit for "one-side" examinations without completing a single-sided ASME Section XI, Appendix VIII demonstration, using flaws on the opposite side of the weld. At the time of the examinations, no Performance Demonstration Initiative (PDI) Program existed for single-side austenitic welds. Consequently, the percent examination coverage achieved for the three welds was 50, 50, and 75 percent respectively. The enclosure to this letter provides BFN Unit 2 request for relief, 2-ISI-18, Revision 1, which addresses the examination coverage limitations for the 10 welds described above.

This request for relief is consistent with 2-ISI-18, Revision 0 (Unit 2 Cycle 12 weld examinations) submitted by TVA letters dated June 2, 2003 and December 16, 2003. TVA's request was approved by NRC letter dated April 12, 2004.

TVA seeks review of this request for relief by February 2, 2009, to support resource planning for the Unit 2, Cycle 15 (Spring 2009) refueling outage.

There are no new regulatory commitments in this letter. If you have any questions, please contact me at (256) 729-2636.

Sincerely,



D. T. Langley
Manager of Licensing
and Industry Affairs

Enclosure
cc (Enclosure): see page 3

U.S. Nuclear Regulatory Commission
Page 3
July 29, 2008

cc (Enclosure):

(Via NRC Electronic Distribution)

Mr. Eugene F. Guthrie, Branch Chief
U.S. Nuclear Regulatory Commission
Region II
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, Georgia 30303-8931

NRC Resident Inspector
Browns Ferry Nuclear Plant
10833 Shaw Road
Athens, Alabama 35611-6970

Ms. Eva A. Brown, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
(MS 08G9)
11555 Rockville Pike
Rockville, Maryland 20852-2739

ENCLOSURE

**TENNESSEE VALLEY AUTHORITY
BROWNS FERRY NUCLEAR PLANT (BFN)
UNIT 2
AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME) SECTION XI,
INSERVICE INSPECTION (ISI) PROGRAM
(THIRD TEN-YEAR INSPECTION INTERVAL)
REQUEST FOR RELIEF 2-ISI-18, REVISION 1**

(SEE ATTACHED)

**TENNESSEE VALLEY AUTHORITY
BROWNS FERRY NUCLEAR PLANT (BFN)
UNIT 2
AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME) SECTION XI,
INSERVICE INSPECTION (ISI) PROGRAM
(THIRD TEN-YEAR INSPECTION INTERVAL)

REQUEST FOR RELIEF 2-ISI-18, REVISION 1**

EXECUTIVE SUMMARY:

This request for relief addresses four Reactor Recirculation (RECIRC) System full penetration piping Welds, one Reactor RECIRC weld overlay, four Reactor Water Cleanup (RWCU) System and one Residual Heat Removal (RHR) System full penetration piping welds examined during Cycles 13 and 14 in the second period of the Third Ten-Year ISI interval.

The subject welds were examined with the latest ultrasonic techniques, procedures, equipment, and personnel qualified to the requirements of the Performance Demonstration Initiative (PDI) Program, as mandated by 10 CFR 50.55a(g)(4).

Credit for the single side access ultrasonic examination of RECIRC Welds GR-2-38, GR-2-41 provided 50 percent coverage, weld KR-2-03 provided 62.5 percent coverage, and GR-2-48 provided 75 percent coverage because of the requirement mandated in 10 CFR 50.55a(b)(2)(xv)(A)(2), which states in part, "Where examination from both sides is not possible on austenitic welds, full coverage credit from a single side may be claimed only after completing a successful single sided Appendix VIII demonstration using flaw on the opposite side of the weld." At the time of the examination, there was no Appendix VIII Program for single sided austenitic welds. Under the original ASME Section XI Code requirements, UT coverage attained was essentially 100 percent.

An ultrasonic examination was performed on RHR weld DRHR-2-03 and provided 87.6 percent coverage due to component configuration (Valve to Flued Head).

An ultrasonic examination was performed on RECIRC weld GR-2-15 (OL) and provided 76 percent coverage due to design of the Structural Weld Overlay (SWOL) configuration (Pipe to Saddle).

An ultrasonic examination was performed on RWCU Weld RCRD-2-50 and provided 62.7 percent coverage due to joint configuration (Elbow to Pipe).

An ultrasonic examination was performed on RWCU Weld RCRD-2-52 and provided 87 percent coverage due to joint configuration (Pipe to Valve).

An ultrasonic examination was performed on RWCU Weld, RWCU-2-004-083 and provided 81.5 percent coverage due to joint configuration (Elbow to Valve).

An ultrasonic examination was performed on RWCU Weld CRD-2-005-003 and provided 64.8 percent coverage due to joint configuration (Pipe to Valve).

The ultrasonic examinations were performed on all accessible areas to the maximum extent practical.

The performance of the ultrasonic examination of the subject areas to the maximum extent practical provides an acceptable level of quality and safety because the information and data obtained from the volume examined provides sufficient information to judge the overall integrity of the piping welds. Therefore, pursuant to 10 CFR 50.55a(g)(5)(iii), it is requested that relief be granted for the third inspection interval.

This request for relief is consistent with 2-ISI-18, Revision 0 (Unit 2 Cycle 12 weld examinations) submitted by TVA letters dated June 2, 2003, and December 16, 2003. TVA's request was approved by NRC letter dated April 12, 2004.

Unit: Two (2)

ISI Interval: ASME Section XI, Third Ten-Year ISI Inspection Interval (May 25, 2001 to May 24, 2011)

Systems: Reactor Recirculation (RECIRC) System, Residual Heat Removal (RHR) System, and Reactor Water Cleanup (RWCU) System

Components: 9 Full Penetration Piping Welds, 1 Structural Weld Overlay (SWOL) listed in Table 1.

ASME Code Class: ASME Code Class 1

ASME Section XI Code Edition: 1995 Edition, 1996 Addenda

Code Table: Code Case N-577, N-577-2500 Table I

Examination Category: R-A, Risk-Informed Piping Examinations

Examination Item Number: R1.16, Elements Subject to Intergranular Stress Corrosion Cracking (IGSCC)

Code Requirement: Code Case N-577, N-577-2500 Table I, Examination Category R1.16, Requires Volumetric Examination of 100 percent of the Weld and Adjacent base Material as depicted in Figure IWB-2500-8 (c).

Code Requirement From Which Relief Is Requested: Relief is requested from the Risk-Informed Inservice Inspection Program, Code Case N-577 requirement (Table I, N-577-2500), Examination Category R-A, Item No. R1.16), to perform essentially 100 percent volumetric examination of the weld and adjacent base material.

LIST OF ITEMS ASSOCIATED WITH THE REQUEST FOR RELIEF:

Weld DRHR-2-03 - Valve (A351, CF8M, F316, S.S.) to Flued Head (A403, WP304, S.S.)

Weld KR-2-03 - Pipe (A358, TP304, S.S.) to Tee (A403, WP304, S.S.)

Weld GR-2-38 - Pipe (A358, TP304, S.S.) to Saddle (A403, WP304, S.S.)

Weld GR-2-41 - Pipe (A358, TP304, S.S.) to Reducer (A403, WP304, S.S.)

Weld GR-2-48 - Pipe (A358, TP304, S.S.) to Saddle (A403, WP304, S.S.)

Weld GR-2-15(OL) - Pipe (A358, TP304, S.S.) to Reducer (A403, WP304, S.S.) Overlaid Weld

RCRD-2-50 - Elbow (SA420, GR. WPL6, C.S.) to Valve (A182, F316, S.S.)

RCRD-2-52 - Pipe (A333, GR. 1, C.S.) to Valve (A182, F316, S.S.)
(Note: Weld removed, and replaced with CRD-2-005-003)

RWCU-2-004-083 - Pipe (A106, C.S.) to Valve (A351, CF8M, F316, S.S.)

CRD-2-005-003 - Pipe (A106, C.S.) to Valve (A182, F316, S.S.)
(Note: This weld replaced weld RCRD-2-52)

BASIS FOR REQUEST FOR RELIEF: It is not possible to achieve the required volumetric examination due to the configuration of these components or due to single side access. Because of the requirement mandated in 10 CFR 50.55a(b)(2)(xv)(A)(2), which in part states, "Where examination from both sides is not possible on austenitic welds, full coverage credit from a single side may be claimed only after completing a successful single sided Appendix VIII demonstration using flaw on the opposite side of the weld." Only 50 percent coverage for welds GR-2-38 and GR-2-41, 62.5 percent for weld KR-2-03, and only 75 percent coverage for weld GR-2-48 can be claimed. At the time of the examinations, there was no Appendix VIII Program for single-sided austenitic welds.

Weld DRHR-2-03 limitations were due to the configuration of the component, Valve to Flued Head

Weld GR-2-15(OL) limitations were due to the design configuration of the structural weld overlay (SWOL) on the pipe to saddle weld.

RCRD-2-50 limitations were due to joint configuration consisting of piping elbow to valve.

RCRD-2-52 limitations were due to joint configuration consisting of pipe to valve.

RWCU-2-004-083 limitations were due to joint configuration consisting of piping elbow to valve.

CRD-2-005-003 limitations were due to joint configuration consisting of pipe to valve.

Under the ASME Section XI Code requirements, UT coverage attained was essentially 100 percent. The performance of the ultrasonic examination of the subject areas to the maximum extent practical provides an acceptable level of quality and safety because the information and data obtained from the volume examined provides sufficient information to judge the overall integrity of the piping welds. Attached is a detailed description of the limitations in Table 1.

ALTERNATIVE EXAMINATION: None. In lieu of the Code required essentially 100 percent volume ultrasonic examination, TVA proposes an ultrasonic examination of the accessible areas to the maximum extent practical given the component design and configuration of the aforementioned piping welds.

JUSTIFICATION FOR THE GRANTING OF RELIEF: The welds were examined with the latest ultrasonic techniques, procedures, equipment, and personnel qualified to the requirements of the Performance Demonstration Initiative (PDI) Program, as mandated by 10 CFR 50.55a(g)(4).

An ultrasonic examination was performed on the piping welds and structural weld overlay accessible areas to the maximum extent practical due to the configuration. Credit for the one-sided examination of GR-2-38 and GR-2-41 provided 50 percent coverage because of the requirement mandated in 10 CFR 50.55a(b)(2)(xv)(A)(2), which states in part, "Where examination from both sides is not possible on austenitic welds, full coverage credit from a single side may be claimed only after completing a successful single sided Appendix VIII demonstration using flaw on the opposite side of the weld." At time of the examination, there was no Appendix VIII Program for single sided austenitic welds. Under the original ASME Section XI Code requirements, UT coverage attained was essentially 100 percent.

Credit for the one-sided examinations of KR-2-03 and GR-2-48 provided 62.5 and 75 percent coverage respectively since the requirement mandated in 10 CFR 50.55a(b)(2)(xv)(A)(2), which states in part, "Where examination from both sides is not possible on austenitic welds, full coverage credit from a single side may be claimed only after completing a successful single sided Appendix VIII demonstration using flaw on the opposite side of the weld." At the time of the examination, there was no Appendix VIII Program for single sided austenitic welds. Under the original ASME Section XI Code requirements, UT coverage attained was essentially 100 percent for both welds.

Coverage for the Ultrasonic examination of Weld DRHR-2-03 was limited to the configuration of the components, valved to flued head. Coverage obtained was 87.6 percent.

Coverage for the Ultrasonic examination of Weld GR-2-15(OL) was limited due the configuration of the structural weld overlay covering the pipe to saddle weld. Coverage obtained was 76 percent.

Coverage for the Ultrasonic examination of Weld RCRD-2-50 was limited due the elbow to valve configuration of the weld. Coverage obtained was 62.7 percent.

Coverage for the Ultrasonic examination of Weld RCRD-2-52 was limited due the pipe to valve configuration of the weld. Coverage obtained was 87 percent.

Coverage for the Ultrasonic examination of Weld RWCU-2-004-083 was limited due the elbow to valve configuration of the weld. Coverage obtained was 81.5 percent.
Coverage for the Ultrasonic examination of Weld CRD-2-005-003 was limited due the pipe to valve configuration of the weld. Coverage obtained was 64.8 percent.

The performance of the ultrasonic examination of the subject areas to the maximum extent practical provides an acceptable level of quality and safety because the information and data obtained from the volume examined provides sufficient information to judge the overall integrity of the piping welds.

Reference RFR 2-ISI-18, Revision 0, (Unit 2 Cycle 12 weld examinations) submitted by TVA letters dated June 2, 2003 and December 16, 2003. NRC approved TVA's request by letter dated April 12, 2004, (TAC NOS. MB9749 and MB9750.)

Welds associated with Request for Relief 2-ISI-18, Revision 1:

<u>WELD</u>	<u>REPORT</u>	<u>CYCLE</u>
DRHR-2-03	R-022	13
KR-2-03	R-043	13
GR-2-38	R-109	14
GR-2-41	R-112	14
GR-2-48	R-114	14
GR-2-15(OL)	R-115	14
RCRD-2-50	R-118	14
RCRD-2-52	R-074	14
RWCU-2-004-083	R-123	14
CRD-2-005-003	R-171	14

Therefore, pursuant to 10 CFR 50.55a(g)(5)(iii), TVA requests that relief be granted for the third Ten-Year ISI inspection interval for the above listed welds.

IMPLEMENTATION SCHEDULE: This request for relief is applicable to the BFN Unit 2 Third Ten-Year ISI inspection interval (May 25, 2001 to May 24, 2011). The Reactor Recirculation (RECIRC) System welds, Residual Heat Removal (RHR) System welds, and Reactor Water Cleanup System (RWCUS) welds listed in Table 1 were examined during the second period (Cycles 13 and 14) of the Third Ten-Year ISI inspection interval.

REFERENCE:

TVA Nuclear power Group, Nondestructive Examination procedure, N-GP-31, "Calculation of ASME Code Coverage for Section XI, Appendix VIII Ultrasonic Examinations"

ATTACHMENTS:

Attachment A - 4 ISI Sketches:

2-ISI-0221-C, Sheet 1

2-ISI-0270-C, Sheets 1 and 2

2-ISI-0272-C, Sheet 1

Attachment B:

Ten Nondestructive Examination Reports:

R-022
R-043
R-109
R-112
R-114
R-115
R-118
R-074
R-123
R-171

TABLE 1

WELD NUMBER	NPS	ISI DRAWING	PERCENT EXAMINED	REMARKS
DRHR-2-03	24"	2-ISI-0221-C	87.6%	Limitation due to component configuration. The configuration is a Flued Head to Valve that prevents a complete examination of the required exam volume. This weld was examined using PDI qualified personnel, procedures, and equipment.
KR-2-03	28"	2-ISI-0270-C	62.5%	Limitation due to saddle to pipe component configuration and the requirement in 10 CFR 50.55a(b)(2)(xv)(A)(2), which requires UT of one side of austenitic welds to be qualified to Appendix VIII Program to claim full Code coverage. At the time of the examination, there was no Appendix VIII Program for single sided austenitic welds.
GR-2-38	12"	2-ISI-0270-C	50%	Limitation due to saddle to pipe component configuration and the requirement in 10 CFR 50.55a(b)(2)(xv)(A)(2), which requires UT of one side of austenitic welds to be qualified to Appendix VIII Program to claim full Code coverage. At the time of the examination, there was no Appendix VIII Program for single sided austenitic welds.

WELD NUMBER	NPS	ISI DRAWING	PERCENT EXAMINED	REMARKS
GR-2-41	12"	2-ISI-0270-C	50%	Limitation due to saddle to pipe component configuration and the requirement in 10 CFR 50.55a(b)(2)(xv)(A)(2), which requires UT of one side of austenitic welds to be qualified to Appendix VIII Program to claim full Code coverage. At the time of the examination, there was no Appendix VIII Program for single sided austenitic welds.
GR-2-48	12"	2-ISI-0270-C	75%	Limitation due to saddle to pipe component configuration and the requirement in 10 CFR 50.55a(b)(2)(xv)(A)(2), which requires UT of one side of austenitic welds to be qualified to Appendix VIII Program to claim full Code coverage. At the time of the examination, there was no Appendix VIII Program for single sided austenitic welds.
GR-2-15(OL)	12"	2-ISI-0270-C	76%	Limitation due the design configuration of the structural weld overlay covering the pipe to saddle weld. This weld was examined using PDI qualified personnel, procedures and equipment.
RCRD-2-50	4"	2-ISI-0272-C	62.7%	Limitation due to the elbow to valve joint configuration. Elbow intrados and the required transducer focusing values prevented interrogation of the required examination volume. This weld was examined using PDI qualified personnel, procedures and equipment.

WELD NUMBER	NPS	ISI DRAWING	PERCENT EXAMINED	REMARKS
RCRD-2-52	4"	2-ISI-0272-C	87%	Limitation due to the pipe to valve joint configuration. Weld contour prevented scanning on the weld surface in the axial direction to achieve full interrogation of the required examination volume. This weld was examined using PDI qualified personnel, procedures and equipment.
RWCU-2-004-083	4"	2-ISI-0272-C	81.5%	Limitation due to the elbow to valve joint configuration. Weld contour prevented scanning on the weld surface in the axial direction to achieve full interrogation of the required examination volume. This weld was examined using PDI qualified personnel, procedures and equipment.
CRD-2-005-003	4"	2-ISI-0272-C	64.8%	Limitation due to the pipe to valve joint configuration. Weld contour prevented scanning on this surface in the axial direction to achieve full interrogation of the required examination volume. This weld was examined using PDI qualified personnel, procedures and equipment.

ATTACHMENT A


ISI SKETCHES

2-ISI-0221-C, Sheet 1


2-ISI-0270-C, Sheet 1

2-ISI-0270-C, Sheet 2

2-ISI-0272-C, Sheet 1




GR-2-15(OL)



REFERENCE DRAWINGS:
 2-47W2403-8,9 (S.E. REPLACEMENT)
 GE 769E963 (S.E. REPLACEMENT)
 TVA 47K:544-2
 GE 2-153F754
 KELLOGG, BF 2-180
 NOTE: THIS DRAWING SUPERSEDES
 CHM-2668-C ALL SHEETS

MATERIAL SPECIFICATIONS:
 A358, TP 304
 4" X 0.337" NOM. WALL THK. (SS)
 12" X 0.588" NOM. WALL THK. (SS)
 22" X 1.030" NOM. WALL THK. (SS)
 28" X 1.138" NOM. WALL THK. (SS) SUCTION
 28" X 1.377" NOM. WALL THK. (SS) DISCHARGE
 2" SCH. 80 A-376, TP304
 2" FITTINGS A-182, F304
 SAFE END REPLACEMENT
 12" X 0.588" NOM. WALL THK. (SS)
 SA 403 WP 315 N.C.



- NOTES:**
1. WELDS 2RX1 ARE THE NOZZLE TO SAFE-END WELDS
 2. ALL 2" WELDS ARE SOCKET WELDED EXCEPT WHERE NOTED.
 3. PIPE SEGMENTS CONTAINING TWO LONGITUDINAL SEAMS WILL BE IDENTIFIED AS:
 (BASE WELD NO.)-LS-1D (DOWNSTREAM)
 (BASE WELD NO.)-LS-2D (DOWNSTREAM)
 (BASE WELD NO.)-LS-1U (UPSTREAM)
 (BASE WELD NO.)-LS-2U (UPSTREAM)
 THE -LS-1 SEAM WILL BE NUMERICALLY CLOSEST TO 0° ON THE PIPE, AND THE -LS-2 SEAM WILL BE NUMERICALLY FARTHEST FROM 0° ON THE PIPE. (e.g. -LS-1 AT 130°, AND -LS-2 AT 310°)
 4. PIPE SEGMENTS CONTAINING ONLY ONE LONGITUDINAL SEAM WILL BE IDENTIFIED AS
 (BASE WELD NO.)-LS-D (DOWNSTREAM)
 (BASE WELD NO.)-LS-U (UPSTREAM)

— RISK INFORMED WELDS

003	ADMIN	RD 105187R	WCH	RLD	12-11-02
REVISED PER RISMS MEMO R14 021202 102					
REV	CHANGE REF	PREPARER	CHECKER	APPROVED	DATE
TENNESSEE VALLEY AUTHORITY					
BROWNS FERRY NUCLEAR PLANT					
UNIT 2					
RECIRCULATION SYSTEM					
WELD LOCATIONS					
DRAWN: mgd	SUBMITTED	APPROVED	SCALE: 1/8"	SHEET 1 OF 2 SHEET(S)	
DATE: 9-10-97	DATE: 11-88	DATE: 11-88	DATE: 11-88	DRAWING NO.	REV.
DATE: 9-12-98	FOC	CLB	2-151-0270-C003		

E-13

ALL A/D HISTORY RESEARCHED AT R000

CAD MAINTAINED DRAWING CCD

ATTACHMENT B

Examination Reports

R-022

R-043

R-109

R-112

R-114

R-115

R-118

R-074

R-123

R-171

Examination Report No. R-022


Weld No. DRHR-2-03

TENNESSEE VALLEY AUTHORITY		EXAMINATION SUMMARY AND		REPORT NUMBER: <i>R-022</i>	
PROJECT: <i>BFM</i> UNIT: <i>2</i> CYCLE <i>13</i>			COMPONENT ID: <i>DRHR-2-03</i>		
EXAMINATION METHOD			SYSTEM: <i>RIIRS</i> ISI DWG NO: <i>2-ISI-0221-C-01</i>		
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CONFIGURATION	CATEGORY
PROCEDURE <i>N-UT-64</i>		REV <i>7</i>	TC <i>N/A</i>	VERT LS TO <i>P</i>	<i>D</i>
EXAMINER: <i>JASON POLISENSKY</i>		EXAMINER: <i>N/A</i>		EXAMINER: <i>N/A</i>	EXAMINER: <i>N/A</i>
LEVEL: <i>II</i>		LEVEL:		LEVEL:	LEVEL:
<p>Total coverage calculated to be approximately <i>87.58</i> %</p> <p>THE ABOVE MENTIONED WELD WAS EXAMINED WITH A <i>45° 60° SHEAR AND A 60° RL. A HALF V CALIBRATION WAS UTILIZED AND SCANNED AT 5% TO 20% ID ROLL.</i></p> <p>ROOT GEOMETRY WAS RECORDED WITH THE <i>60RL ON SCAN 4 360°. NO REJECTABLE INDICATIONS WERE OBSERVED.</i></p> <p>CODE COVERAGE WAS LESS THAN <i>90%</i> DUE TO COMPONENT CONFIGURATION.</p> <p><i>This exam satisfies the requirements of NUREG 0313(145CC) and Section XI, R-A, R.116A. Man Welded 3/21/05</i></p>					
RESOLUTION BY <i>Jason Polisenky</i>		REVIEWED BY <i>Walter Welch</i>		ANII: <i>W. Welch</i>	
LEVEL <i>II</i> DATE <i>3/26/05</i>		LEVEL: <i>III</i> DATE <i>3/21/05</i>		DATE <i>4/8/05</i>	
				Page: <i>1</i> OF <i>7</i>	

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER <u>R-022</u>
---------------------------------------	--	--------------------------------------

PROJECT BFN UNIT/CYCLE 2/13
 PROCEDURE: N-UT-64 REV: 7 TC: N/A
 TRANSDUCER
 MANUFACTURER KBA
 MODEL: Comp G S/N 00YNCO1
 SIZE: .375 / FREQ: 1.5 MH
 SHAPE: RND # ELEMENTS: 2 # CONS: 0
 CABLE TYPE RG174 LENGTH: 6'
 MODE: SHEAR LONG RL

CALIBRATION DATE: 3/25/05
 CALIBRATION BLOCK NO. WB85 TEMP: 72 °F
 SIMULATOR BLOCK: 790398 RompAS
 THERMOMETER S/N 558271 DUE DATE 6-9-05
 COUPLANT: ULTRAGEL BATCH: 03125
 ANGLE VERIFICATION
 BLOCK TYPE: RompAS S/N: 790398
 NOMINAL ANGLE: 45 ACTUAL ANGLE 45 °
 INSTRUMENT
 MANUFACTURER KBA DUE DATE 6-4-05
 MODEL NO.: USN 52L S/N: 00F575



INSTRUMENT SETTINGS E30218

REFLECTOR			REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC	SDH		
AXIAL	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>18.5</u> dB	<u>10</u>
CIRC.	<input type="checkbox"/>	<input type="checkbox"/>	<u>N/A</u> dB	<u>N/A</u>
FREQ: <u>2-8</u>	MH		REJECT: = <u>0</u> %	
ANGLE: <u>45</u>	deg		DAMPING: <u>1000</u> ohms	
DELAY <u>0.000</u>	msec		PULSER: <u>SINGLE</u> *	
ZERO: <u>5.910</u>	msec			
VELOCITY <u>.1244</u>	msec		PRR/PFR: <u>HIGH</u>	
RANGE: <u>4.0</u>	inches		TOF: <u>PEAK</u>	
DISP. MODE: <u>FULL WAVE</u>			POWER: <u>BAT</u>	

REF. REFLECTOR: FAR SDH GAIN: 30.5 dB
 AMPLITUDE: 75 % METAL PATH: 1.035
 VERIFICATION TIMES 1) 1345 2) 1440 3) N/A 4) N/A 5) N/A 6) N/A 7) N/A 8) N/A 9) N/A

CALIBRATION TIMES

INITIAL TIME: 1235 FINAL TIME 1500

*PDI QUALIFIED INSTRUMENT SETTINGS:
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2
 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL									
	SIGNAL 1	100	90	80	70	60	50	40	30	20
	SIGNAL 2	50	45	40	35	30	25	20	15	10
ATTENUATOR	GAIN	SET	-6 dB	-12dB	SET	+12	SET	+6		
	AMP	80%	32 TO 48	16 TO 24	20%	64 TO 96	40%	64 TO 96		
			40	20		80		80		

COMMENTS	WELD / ITEMS EXAMINED
	<u>DRHR-2-03</u>

EXAMINER: <u>Jason Polianog</u>	LVL.: <u>II</u>	ANII: <u>W. Usel</u>
EXAMINER:	LVL.:	DATE <u>4/8/05</u>
REVIEWER: <u>W. Usel</u>	LVL.: <u>III</u> DATE <u>3/27/05</u>	PAGE <u>2</u> OF <u>7</u>

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER <u>R-022</u>
---------------------------------------	--	--------------------------------------

PROJECT: BFN UNIT/CYCLE: 2/13
 PROCEDURE: N-UT-64 REV: 7 ✓ TC: N/A

TRANSDUCER

MANUFACTURER: KBA
 MODEL: COMP G S/N: 00XD3R
 SIZE: .375 FREQ: 1.5 MH
 SHAPE: RND # ELEMENTS: 2 # CONS: 0
 CABLE TYPE: RG-174 LENGTH: 6"

MODE: SHEAR LONG RL

DAC

CALIBRATION DATE: 3/25/05
 CALIBRATION BLOCK NO. WB85 ✓ TEMP: 72 °F
 SIMULATOR BLOCK: 790398 ✓ RomPAS
 THERMOMETER S/N 558271 ✓ DUE DATE 6-9-05
 COUPLANT: ULTRAGEL BATCH: 03125


ANGLE VERIFICATION

BLOCK TYPE: RomPAS S/N: 790398 ✓
 NOMINAL ANGLE: 60 ACTUAL ANGLE 60°

INSTRUMENT

MANUFACTURER: KBA DUE DATE 6-4-05
 MODEL NO.: USN52L S/N: DDF575

INSTRUMENT SETTINGS E30218



REFLECTOR			REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC	SDH		
AXIAL	<input checked="" type="checkbox"/>	<input type="checkbox"/>	38 dB	11
CIRC.	<input type="checkbox"/>	<input type="checkbox"/>	N/A dB	N/A
FREQ: <u>2-8</u> ✓	MH		REJECT: = <u>0</u> % ✓	
ANGLE: <u>60</u>	deg		DAMPING: <u>1000</u> ohms ✓	
DELAY <u>0.000</u>	msec		PULSER: <u>SINGLE</u> ✓ *	
ZERO: <u>10.191</u>	msec			
VELOCITY <u>.1266</u>	msec		PRR/PRF: <u>HIGH</u> ✓	
RANGE: <u>5.0</u>	inches		TOF: <u>PEAK</u>	
DISP. MODE: <u>FULL WAV</u> ✓			POWER: <u>BAT</u>	

REF. REFLECTOR: NEAR SDH GAIN: 32 dB
 AMPLITUDE: 60 % METAL PATH: .624
 VERIFICATION TIMES 1) 1410 2) 1430 3) N/A 4) N/A 5) N/A 6) N/A 7) N/A 8) N/A 9) N/A

CALIBRATION TIMES

INITIAL TIME: 1245 FINAL TIME 1501

*PDI QUALIFIED INSTRUMENT SETTINGS:
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2
 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20	
	SIGNAL 2	50	45	40	35	30	25	20	15	10	
ATTENUATOR	GAIN	SET	-6 dB	-12dB	SET	+12	SET	+6			
	AMP	80%	32 TO 48	16 TO 24	20%	64 TO 96	40%	64 TO 96			
			40	20		80		80			


COMMENTS	WELD / ITEMS EXAMINED
	<u>DRHR-2-03</u>

EXAMINER: <u>Jason Polansky</u>	LVL.: <u>II</u>	ANII: <u>Weld</u>
EXAMINER:	LVL.:	DATE <u>4/8/05</u>
REVIEWER: <u>Weld</u>	LVL.: <u>III</u> DATE <u>3/27/05</u>	PAGE <u>3</u> OF <u>7</u>

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER <u>R-022</u>
---------------------------------------	--	--------------------------------------

PROJECT BFN UNIT/CYCLE 2/13
 PROCEDURE: N-UT-64 REV: 7 TC: NIA
 TRANSDUCER
 MANUFACTURER RTD
 MODEL: TRLA S/N 85-630
 SIZE: 2 (10x18) FREQ: 2 MH
 SHAPE: RECT # ELEMENTS: 2 # CONS: 0
 CABLE TYPE RG-174 LENGTH: 6
 MODE: SHEAR LONG RL

CALIBRATION DATE: 3/25/05
 CALIBRATION BLOCK NO. WB85 TEMP: 72 °F
 SIMULATOR BLOCK: 790398 RomPAS
 THERMOMETER S/N 558271 DUE DATE 6-9-05
 COUPLANT: ULTRAGEL BATCH: 03125
 ANGLE VERIFICATION
 BLOCK TYPE: RompAS S/N: 290398
 NOMINAL ANGLE: 60 ACTUAL ANGLE 60 °
 INSTRUMENT
 MANUFACTURER KBA DUE DATE 6-4-05
 MODEL NO.: USN 52L S/N: 00F575



INSTRUMENT SETTINGS E30218

REFLECTOR			REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC	SDH		
AXIAL	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>64</u> dB	<u>12</u>
CIRC.	<input type="checkbox"/>	<input type="checkbox"/>	<u>NIA</u> dB	<u>NIA</u>
FREQ: <u>2-8</u> ✓	MH	REJECT: = <u>0</u> %		
ANGLE: <u>60</u>	deg	DAMPING: <u>1000</u> ohms		
DELAY <u>0.000</u>	msec	PULSER: <u>DUAL</u> *		
ZERO: <u>9.472</u>	msec	PRR/PRF: <u>HIGH</u> ✓		
VELOCITY <u>2278</u>	msec	TOF: <u>PEAK</u>		
RANGE: <u>5.0</u>	inches	POWER: <u>BAT</u>		
DISP. MODE: <u>FULL WAY</u> ✓				

REF. REFLECTOR: FAR SDH GAIN: 58 dB
 AMPLITUDE: 55 % METAL PATH: 1.491
 VERIFICATION TIMES 1) 420 2) N/A 3) N/A 4) N/A 5) N/A 6) N/A 7) N/A 8) N/A 9) N/A

CALIBRATION TIMES

INITIAL TIME: 1250 FINAL TIME 1503

*PDI QUALIFIED INSTRUMENT SETTINGS:
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2
 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL									
	SIGNAL 1	100	90	80	70	60	50	40	30	20
	SIGNAL 2	50	45	40	35	30	25	20	15	10
ATTENUATOR	GAIN	SET	-6 dB	-12dB	SET	+12	SET	+6		
	AMP	80%	32 TO 48	16 TO 24	20%	64 TO 96	40%	64 TO 96		
			40	20		80		80		

COMMENTS	WELD / ITEMS EXAMINED
	<u>DRHR-2-03</u>

EXAMINER: <u>Jason Polisenaly</u> LVL: <u>II</u>	ANII: <u>Walter</u>
EXAMINER: _____ LVL: _____	DATE: <u>4/8/05</u>
REVIEWER: <u>Walter</u> LVL: <u>III</u> DATE: <u>3/27/05</u>	PAGE: <u>4</u> OF <u>7</u>

TENNESSEE VALLEY AUTHORITY	MANUAL ULTRASONIC PIPING EXAMINATION DATA SHEET	REPORT NUMBER <u>R-022</u>
---------------------------------------	--	--------------------------------------

PROJECT: <u>BFN</u> UNIT/CYCLE <u>2/13</u> SYSTEM <u>RHRS</u> WELD I.D.: <u>DRHR-2-03</u> CONFIG.: <u>VERT LS</u> TO <u>P</u> <div style="text-align: center;"> FLOW </div> PROCEDURE: <u>N-UT-64</u> REV: <u>7</u> TC: <u>NIA</u> W ₀ REFERENCE: <u>WELD E</u> L ₀ REFERENCE: <u>TDC</u>	EXAMINATION DATE <u>3/25/05</u> START TIME: <u>1345</u> END TIME: <u>1500</u> EXAM SURFACE <input type="checkbox"/> ID <input checked="" type="checkbox"/> OD MATERIAL TYPE: <input type="checkbox"/> CS <input checked="" type="checkbox"/> SS <input type="checkbox"/> CSCL <input type="checkbox"/> CCSS SURFACE TEMP. <u>82</u> PYRO NO. <u>558271</u> EXAMINATION ANGLE <u>45/60_{short}</u> DEG. <u>60_{long}</u> DEG. AXIAL SCAN SENSITIVITY <u>30.5 / 44</u> dB <u>64</u> dB CIRC. SCAN SENSITIVITY <u>30.5 / NIA</u> dB <u>NIA</u> dB
---	---

IND NO.	L (in) FROM REF.			AT MAX AMP			MAX AMP % DAC	EXAM NO. 3-14	NOM. ANG.	NRI	INDICATION INFORMATION: TYPE, DAMPING, ETC.
	L1	L Max	L2	W MAX	MP MAX	D MAX					
								3	45	<input checked="" type="checkbox"/>	
								4	45	<input checked="" type="checkbox"/>	
								5	45	<input checked="" type="checkbox"/>	
								6	45	<input checked="" type="checkbox"/>	
								3	60	<input checked="" type="checkbox"/>	
								4	60	<input checked="" type="checkbox"/>	
								3	60L	<input checked="" type="checkbox"/>	
1	0"		1.4"	2.0"	N/A		100%	4	60L	<input type="checkbox"/>	ROOT GEO 360°
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	

REMARKS/LIMITATIONS

MAINTAINED 5% TO 20% ID ROLL, 60°L SCANNED AT REFERENCE JB

87.50% COVERAGE DUE TO CONFIGURATION

NO REJECTABLE INDICATIONS

EXAMINER: <u>Jason P. Brandy</u> LEVEL: <u>II</u> EXAMINER: <u>NIA</u> LEVEL: _____	ANII: <u>[Signature]</u> DATE: <u>4/8/05</u> PAGE <u>5</u> OF <u>7</u>
REVIEWED BY: <u>Mark Welch</u> LEVEL: <u>III</u> DATE <u>3/27/05</u>	

TVA


Office of Nuclear Power

PROJECT: BFN SYSTEM: RHR

Unit: 2 WELD NO.: DRHR-2-03

REPORT NO.:

R-022



BY: *Josiah Robinson*

LEVEL: II

DATE: 3/25/05

PAGE 6 OF 7


00062

TVA	WALL THICKNESS PROFILE SHEET	REPORT NO: R-022
------------	---	----------------------------


PROJECT: <u>BFN</u>	WELD NO: <u>DRHR-2-03</u>
UNIT: <u>2</u>	SYSTEM: <u>RHR</u>

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	N/A			
2	1.25		N	
3	1.3			A
4	1.2			
5	N/A			



CROWN HEIGHT: <u>FLUSH</u>	DIAMETER: <u>24"</u>
CROWN WIDTH: <u>1.4"</u>	WELD LENGTH: <u>75"</u>



SCAN 3 AREA
 $A = ab$
 $.38 = .4 \times .95$
 MISSING AREA
 $Y = ab$
 $.06 = .4 \times .2$
 $Z = bh$
 $.0053 = \frac{.33 \times .4}{2}$

TOTAL EXAM VOLUME
 $.38 + .38 = .76 \text{''}^2$
 TOTAL MISSED VOLUME
 $.06 + .0053 + .0091 = .0944 \text{''}^2$
 12.42% MISSING COVERAGE

SCAN 4 AREA
 $A = ab$
 $.38 = .4 \times .95$
 MISSING AREA
 $X = bh$
 $.0091 = \frac{.13 \times .14}{2}$

**87.58 % TOTAL CODE COVERAGE
ACHIEVED**

EXAMINER: <u>Jason Palisano</u>	REVIEWED BY: <u>Walter Welch</u>	ANII: <u>DR/M Hall</u>
LEVEL: <u>II</u>	LEVEL: <u>III</u>	DATE: <u>4/8/05</u>
DATE: <u>3/25/05</u>	DATE: <u>3/27/05</u>	PAGE: <u>7</u> OF <u>7</u>

Examination Report No. R-043


Weld No. KR-2-03

TENNESSEE VALLEY AUTHORITY		EXAMINATION SUMMARY AND		REPORT NUMBER: R-043	
PROJECT: <i>BFN</i> UNIT: <i>2</i> CYCLE <i>13</i>		COMPONENT ID: <i>KR-2-03</i>			
EXAMINATION METHOD				SYSTEM: RECIR ISI DWG NO: <i>2-ISI-0270-C-01</i>	
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CONFIGURATION	CATEGORY
PROCEDURE <i>N-UT-64</i>		REV <i>7</i>	TC <i>N/A</i>	<i>P TO TEE</i>	<i>C</i>
EXAMINER: <i>JASON POLISENSKY</i>		EXAMINER: <i>N/A</i>		EXAMINER: <i>N/A</i>	EXAMINER: <i>N/A</i>
LEVEL: <i>II</i>		LEVEL:		LEVEL:	LEVEL:
<p>Total coverage calculated to be approximately 62.50 % ⊗</p> <p>THE ABOVE MENTIONED WELD WAS EXAMINED WITH A 45° SHEAR 375° 1.5MHZ AND A 60° RL 10X18mm 2MHZ. BOTH TRANSDUCERS UTILIZED A 1/2 V CALIBRATION</p> <p>THE EXAMINATION WAS LIMITED TO A SINGLE SIDED EXAM DUE TO TEE CONFIGURATION.</p> <p><i>NO RECORDABLE INDICATIONS</i></p> <p><i>MAINTAINED 10% TO 20% ID ROLL</i></p> <p><i>Dual credit exam - satisfies ASME Section XI, category R-A, item RI-16 and NUREG 0343 requirements. Man Welch 4/1/04</i></p> <p>⊗ 100% Code coverage achieved, 62.5% qualified credit coverage for single sided exam. Man Welch 4/1/04</p>					
RESOLUTION BY <i>Jason Poloski</i>		REVIEWED BY <i>Man Welch</i>		ANII: <i>Man Welch</i>	
LEVEL <i>II</i> DATE <i>4/1/05</i>		LEVEL: <i>III</i> DATE <i>4/1/05</i>		DATE <i>4/1/05</i>	
				Page: <i>1</i> OF <i>5</i>	

00141

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER <u>R-043</u>
---------------------------------------	--	--------------------------------------

PROJECT <u>BFN</u> UNIT/CYCLE <u>2113</u> PROCEDURE: <u>N-UT-64</u> REV: <u>7</u> TC: <u>N/A</u>	CALIBRATION DATE: <u>4/01/05</u> CALIBRATION BLOCK NO. <u>WB 85</u> TEMP: <u>75</u> "F" SIMULATOR BLOCK: <u>RompAS 790393</u> THERMOMETER S/N <u>558271</u> DUE DATE <u>6-9-05</u> COUPLANT: <u>ULTRAGEL</u> BATCH: <u>03125</u>
MANUFACTURER <u>KBA</u> MODEL: <u>COMP G</u> S/N <u>00YNCO</u> SIZE: <u>.375</u> FREQ: <u>1.5</u> MH SHAPE: <u>RND</u> # ELEMENTS: <u>1</u> # CONS: <u>0</u> CABLE TYPE <u>RG 174</u> LENGTH: <u>6'</u>	ANGLE VERIFICATION BLOCK TYPE: <u>RompAS</u> S/N: <u>790393</u> NOMINAL ANGLE: <u>45</u> ACTUAL ANGLE <u>45</u> "
MODE: <input checked="" type="checkbox"/> SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RL DAC	INSTRUMENT MANUFACTURER <u>KBA</u> DUE DATE <u>07/28/05</u> MODEL NO.: <u>USN 60</u> S/N: <u>E36311</u>



REFLECTOR			REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC	SDH		
AXIAL	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>26.5</u> dB	<u>45° 1-ST. SS</u>
CIRC.	<input type="checkbox"/>	<input type="checkbox"/>	<u>N/A</u> dB	<u>N/A</u>
FREQ: <u>2</u>	MH	REJECT: <u>0</u>	%	
ANGLE: <u>45</u>	deg	DAMPING: <u>1000</u>	ohms	
DELAY: <u>0.000</u>	msec	PULSER: <u>SINGLE</u>	*	
ZERO: <u>5.3409</u>	msec	ENERGY: <u>HIGH</u>		
VELOCITY: <u>1233</u>	msec	PRR/PRF: <u>AUTO HIGH</u>		
RANGE: <u>3.0</u>	inches	TOF: <u>PEAK</u>		
DISP. MODE: <u>FULL WAV</u>		POWER: <u>BAT</u>		

REF. REFLECTOR: <u>FAR SDH</u> GAIN: <u>38.5</u> dB AMPLITUDE: <u>70</u> % METAL PATH: <u>1.045</u>	CALIBRATION TIMES INITIAL TIME: <u>0920</u> FINAL TIME <u>1050</u>
VERIFICATION TIMES <u>1) 0940</u> <u>2) N/A</u> <u>3) N/A</u>	<u>4) N/A</u> <u>5) N/A</u> <u>6) N/A</u> <u>7) N/A</u> <u>8) N/A</u> <u>9) N/A</u>

*PDI QUALIFIED INSTRUMENT SETTINGS:
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2
 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK												
VERTICAL	SIGNAL 1		100	90	80	70	60	50	40	30	20	
	SIGNAL 2		50	45	40	35	30	25	20	15	10	
ATTENUATOR	GAIN	SET	-6 dB		-12dB		SET		+12		SET	+6
	AMP	80%	32 TO 48		16 TO 24		20%		64 TO 96		40%	64 TO 96
			40		20				80			80

COMMENTS	WELD/ITEMS EXAMINED <u>KR-2-03</u>
----------	---------------------------------------


EXAMINER: <u>Jason Polinsky</u>	LVL.: <u>II</u>	ANII: <u>John Flood</u>
EXAMINER: <u>N/A</u>	LVL.:	DATE: <u>4/16/05</u>
REVIEWER: <u>Walter Welch</u>	LVL.: <u>III</u> DATE: <u>4/1/05</u>	PAGE: <u>2</u> OF <u>5</u>

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER <u>R-043</u>
---------------------------------------	--	--------------------------------------

PROJECT BFN UNIT/CYCLE 2/13
 PROCEDURE: N-UT-64 REV: 7 TC: NIA
 TRANSDUCER
 MANUFACTURER RTD
 MODEL: TRLA S/N 85-735
 SIZE: 2 (10X10)mm FREQ: 2 MH
 SHAPE: RECT # ELEMENTS: 2 # CONS: 0
 CABLE TYPE RG 174 LENGTH: 6'
 MODE: SHEAR LONG RL

CALIBRATION DATE: 4/01/05
 CALIBRATION BLOCK NO. WB 85 TEMP: 75 °F
 SIMULATOR BLOCK: RompAS 790393
 THERMOMETER S/N 558271 DUE DATE 6-9-05
 COUPLANT: ULTRAGEL BATCH: 03125

DAC



ANGLE VERIFICATION
 BLOCK TYPE: RompAS S/N: 790393
 NOMINAL ANGLE: 60 ACTUAL ANGLE 60°
 INSTRUMENT
 MANUFACTURER KBA DUE DATE 7/28/05
 MODEL NO.: USN-60 S/N: E36311

REFLECTOR			REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC	SDH		
AXIAL	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>83</u> dB	<u>60 RL 1-5T 5S</u>
CIRC.	<input type="checkbox"/>	<input type="checkbox"/>	<u>NIA</u> dB	
FREQ: <u>2</u> MH	REJECT: <u>0</u> %			
ANGLE: <u>60</u> deg	DAMPING: <u>1000</u> ohms			
DELAY <u>0.000</u> msec	PULSER: <u>DUAL</u> *			
ZERO: <u>8.3916</u> msec	ENERGY <u>HIGH</u>			
VELOCITY <u>2167</u> msec	PRR/PRF: <u>AUTO HIGH</u>			
RANGE: <u>4.5</u> inches	TOF: <u>PEAK</u>			
DISP. MODE: <u>FULL WAVE</u>	POWER: <u>BAT</u>			

REF. REFLECTOR: FAR SDH GAIN: 75 dB
 AMPLITUDE: 60 % METAL PATH: 1.390
 VERIFICATION TIMES 1) 1005 2) N/A 3) N/A 4) N/A 5) N/A 6) N/A 7) N/A 8) N/A 9) N/A

CALIBRATION TIMES
 INITIAL TIME: 0925 FINAL TIME 1052

*PDI QUALIFIED INSTRUMENT SETTINGS:
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2
 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK										
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20
		SIGNAL 2	50	45	40	35	30	25	20	15
ATTENUATOR	GAIN	SET	-6 dB	-12dB	SET	+12	SET	+6		
	AMP	80%	32 TO 48	16 TO 24	20%	64 TO 96	40%	64 TO 96		
			40	20		80		80		

COMMENTS	WELD / ITEMS EXAMINED
	<u>KR-2-03</u>

EXAMINER: <u>Josiah Polysand</u> LVL: <u>II</u>	ANH: <u>[Signature]</u>
EXAMINER: <u>N/A</u> LVL: <u> </u>	DATE <u>4/16/05</u>
REVIEWER: <u>Walter Welch</u> LVL: <u>III</u> DATE <u>4/1/05</u>	PAGE <u>3</u> OF <u>5</u>

TENNESSEE VALLEY AUTHORITY	MANUAL ULTRASONIC PIPING EXAMINATION DATA SHEET	REPORT NUMBER <u>R-043</u>
---------------------------------------	--	--------------------------------------

PROJECT: BFN UNIT/CYCLE 2113
 SYSTEM RECIR
 WELD I.D.: KR-2-03
 CONFIG.: P TO TEE
 FLOW
 PROCEDURE: N-UT-64 REV: 7 TC: N/A
 W₀ REFERENCE: WELD E
 L₀ REFERENCE: 180° FROM RX VESSEL

EXAMINATION DATE 4/01/05
 START TIME: 0940 END TIME: 1030
 EXAM SURFACE ID OD
 MATERIAL TYPE: CS SS CSCL CCSS
 SURFACE TEMP. 82°F PYRO NO. 558271

EXAMINATION ANGLE	<u>45</u> DEG.	<u>60L</u> DEG.
AXIAL SCAN SENSITIVITY	<u>38.5</u> dB	<u>83</u> dB
CIRC. SCAN SENSITIVITY	<u>38.5</u> dB	<u>N/A</u> dB

IND NO.	L (in) FROM REF.			AT MAX AMP			MAX AMP % DAC	EXAM NO. 3-14	NOM. ANG.	NRI	INDICATION INFORMATION: TYPE, DAMPING, ETC.
	L1	L Max	L2	W MAX	MP MAX	D MAX					
								3	45	<input checked="" type="checkbox"/>	
								5	45	<input checked="" type="checkbox"/>	LIMITED TO PIPE SIDE ONLY
								6	45	<input checked="" type="checkbox"/>	LIMITED TO PIPE SIDE ONLY
								3	60L	<input checked="" type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	

REMARKS/LIMITATIONS

NO SCAN 4 ON 45° SHEAR & 60RL DUE TO TEE CONFIGURATION.

60° RL SCANNED AT REFERENCE. BOTH 45 & 60 MAINTAINED 10% TO 20% TD ROLL

NO RECORDABLE INDICATIONS

EXAMINER: <u>Jean Robinson</u> LEVEL: <u>II</u>	ANII: <u>John Flork</u>
EXAMINER: <u>N/A</u> LEVEL: <u></u>	DATE: <u>4/1/05</u>
REVIEWED BY: <u>Mark Welch</u> LEVEL: <u>III</u> DATE: <u>4/1/05</u>	PAGE: <u>4</u> OF <u>5</u>

00144

TVA

**WALL THICKNESS
PROFILE SHEET**

REPORT NO:


R-043

PROJECT: BFN
UNIT: 2


WELD NO: KR-2-03
SYSTEM: RECIRC

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	1.34			
2	1.39		N	
3	1.45			A
4	N/A			
5	N/A			



CROWN HEIGHT: FLUSH DIAMETER: 28"
CROWN WIDTH: 1.3" WELD LENGTH: 90"



EXAMINER: Joseph Polanski
LEVEL: II
DATE: 4/1/05

REVIEWED BY: Walter Welch
LEVEL: III DATE: 4/1/05

ANII: [Signature]
DATE: 4/1/05
PAGE 5 OF 5

Examination Report No. R-109

Weld No. GR-2-38

000287

TENNESSEE VALLEY AUTHORITY		EXAMINATION SUMMARY AND RESOLUTION DATA SHEET		REPORT NUMBER: <i>R109</i>	
PROJECT: BFN		UNIT: 2 <i>3/13/07</i>	CYCLE: 14	COMPONENT ID: GR-2-38	
EXAMINATION METHOD				SYSTEM: Recirc	ISI DWG. NO. 2-ISI-270-C-02
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CODE CLASS: 1	CATEGORY: R-A
PROCEDURE: N-UT <i>3/13/07</i>		REV: <i>4/9</i>	TC: N/A	CONFIG.: Saddle	TO Pipe
EXAMINER: Patrick Mahoney <i>3/13/07</i>		EXAMINER: <i>3/14/07</i> N/A		EXAMINER: N/A	EXAMINER: N/A
LEVEL: II		LEVEL:		LEVEL:	LEVEL:

This report contains data associated with the Manual Ultrasonic Examination of Weld GR-2-38.
 The examination satisfies the requirements of ASME Section XI (Risk Informed) R1.16E & NUREG 0313.
(BWRVIP-76A)

Root Geometry was recorded at below recordable levels.

There were no recordable indications detected during the examination.

A 45° Shear Wave, a 60° Shear Wave, and a 60°RL transducer were used during the exam

50% coverage was achieved, using ASME Section XI, Appendix VIII qualified techniques.
 100% ASME Section XI Code Coverage achieved. *Walter Welch 3/15/07*

This exam was performed with equipment, procedures, and personnel qualified I.A.W. ASME Section XI, Appendix VIII as amended by the final rule.


RESOLUTION BY: <i>Patrick Mahoney</i>	REVIEWED BY: <i>Walter Welch</i>	ANI: <i>Paul Flood</i>
LEVEL: II DATE: 3/13/07	LEVEL: III DATE: 3/14/07	DATE: 4/13/07
		PG. 1 OF 7

000288

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER: <i>R109</i>									
PROJECT: <i>BFN UNIT 2</i> CYCLE: <i>14</i>	CALIBRATION DATE: <i>3/13/07</i>										
PROC.: <i>N-UT-64</i> REV: <i>9</i> TC: <i>N/A</i>	CALIBRATION BLOCK NO.: <i>WB 85</i> TEMP: <i>72 °F</i>										
INSTR. MFG: <i>KRAUTKRAMER</i> DUE DATE: <i>8/21/07</i>	SIMULATOR BLOCK NO.: <i>ALT CAL BLOCK</i>										
MODEL/TYPE: <i>USN 60</i> M & TE NO.: <i>E36303</i>	THERMOMETER S/N: <i>562774</i> DUE DATE: <i>12/12/07</i>										
TRANSDUCER MFG: <i>KBA</i>	COUPLANT <i>UTRAGEL II</i> BATCH: <i>05325</i>										
S/N <i>00YNCO</i> SIZE: <i>.375</i> FREQ: <i>1.5</i> MHz	EXAM TYPE: SHEAR <input checked="" type="checkbox"/> LONG <input type="checkbox"/> RL <input type="checkbox"/>										
CABLE TYPE: <i>RG-174</i> LENGTH: <i>72"</i> inches	ANGLE VERIFICATION										
DAC	BLOCK TYPE: <i>Rompas</i>	S/N: <i>6026-83</i>									
	NOMINAL ANGLE: <i>45°</i>	ACTUAL ANGLE: <i>45°</i>									
<div style="display: flex; align-items: center;"> <div style="margin-right: 10px;">100 80 60 40 20 0</div> <div style="flex-grow: 1;"> </div> <div style="margin-left: 10px; writing-mode: vertical-rl; transform: rotate(180deg);"> A M P L I T U D E </div> </div>	INSTRUMENT SETTINGS										
	REFLECTOR		REFERENCE								
	SCAN DIRECT:	NTCH <input type="checkbox"/> SDH <input type="checkbox"/>	SENSITIVITY								
	AXIAL	<input checked="" type="checkbox"/> <input type="checkbox"/>	<i>33.5</i> dB <i>45° S/S</i>								
	CIRC	<input checked="" type="checkbox"/> <input type="checkbox"/>	<i>33.5</i> dB <i>45° S/S</i>								
	RANGE:	<i>2.375</i>	*INST. FREQ.: <i>2</i> Mhz								
	PROBE DELAY:	<i>8.5400</i>	*RECTIFY: <i>FULL WAVE</i>								
	VELOCITY:	<i>1230</i>	DUAL <input type="checkbox"/> ON <input checked="" type="checkbox"/> OFF								
	DISPLAY DELAY:	<i>0</i>	*REJECT: <i>0</i> %								
	*ENERGY: <i>HIGH</i>	*DISPLAY START: <i>1P</i>									
*DAMPING: <i>1K</i>	DET: <input type="checkbox"/> PEAK <input checked="" type="checkbox"/> FLANK										
*PRF MODE: <i>AUTO HIGH</i>	TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>										
REF. REFLECTOR: <i>SDH</i> GAIN: dB <i>42</i>	CALIBRATION TIMES										
AMPLITUDE: <i>80%</i> METAL PATH: <i>1.040</i>	INITIAL TIME: <i>1030</i>	FINAL TIME: <i>1330</i>									
VERIFICATION TIMES	1) <i>1200</i> 2) <i>1225</i> 3) <i>1245</i>	4) <i>1300</i> 5) <i>N/A</i> 6) <i>N/A</i> 7) <i>N/A</i> 8) <i>N/A</i> 9) <i>N/A</i>									
* PDI QUALIFIED INSTRUMENT SETTINGS: VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!											
LINEARITY CHECK											
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20	10
	SIGNAL 2	50	45	40	35	30	25	20	15	10	05
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6			
	AMP	80	32-48	16-24	20	64-96	40	64-96			
			40	20		80		80			
COMMENTS: <i>SEE ATTACHED</i>						WELDS/ITEMS EXAMINED: <i>GR-2-38</i>					
EXAMINER: <i>[Signature]</i>	EXAMINER: <i>N/A</i>	REVIEWER: <i>[Signature]</i>	ANII: <i>[Signature]</i>								
LEVEL: <i>II</i>	LEVEL:	LEVEL: <i>III</i>	DATE: <i>3/14/07</i>	DATE: <i>4/13/07</i>							
			PG. <i>2</i> OF <i>7</i>								

000289

TENNESSEE VALLEY AUTHORITY		DIGITAL ULTRASONIC CALIBRATION DATA SHEET			REPORT NUMBER: <i>R109</i>							
PROJECT: <i>BFN UNIT 2</i>		CYCLE: <i>14</i>		CALIBRATION DATE: <i>3/13/07</i>								
PROC.: <i>N-UT-64</i>		REV: <i>9</i>		TC: <i>N/A</i>		CALIBRATION BLOCK NO.: <i>WB85</i> TEMP: <i>72 °F</i>						
INSTR. MFG: <i>KRAUTKRAMER</i>		DUE DATE: <i>8/21/07</i>		SIMULATOR BLOCK NO: <i>ALT CAL BLOCK</i>								
MODEL/TYPER: <i>USN 60</i>		M & TE NO.: <i>E36303</i>		THERMOMETER S/N: <i>562774</i> DUE DATE: <i>12/12/07</i>								
TRANSDUCER MFG: <i>KBA</i>		COUPLANT <i>ULTRAGEL II</i> BATCH: <i>05325</i>										
S/N <i>DDYNCO</i> SIZE: <i>.375</i>		FREQ: <i>1.5</i> MHz		EXAM TYPE: SHEAR <input checked="" type="checkbox"/> LONG <input type="checkbox"/> RL <input type="checkbox"/>								
CABLE TYPE: <i>RG-174</i>		LENGTH: <i>72"</i> inches		ANGLE VERIFICATION								
DAC		BLOCK TYPE: <i>Rompas</i>		S/N: <i>602L-83</i>								
		NOMINAL ANGLE: <i>60°</i>		ACTUAL ANGLE: <i>58°</i>								
INSTRUMENT SETTINGS												
REFLECTOR			REFERENCE		MEMORY							
SCAN DIRECT.	NTCH	SDII	SENSITIVITY		NUMBER							
AXIAL	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>44</i> dB		<i>60°</i>							
CIRC	<input type="checkbox"/>	<input type="checkbox"/>	<i>N/A</i> dB		<i>N/A</i>							
RANGE: <i>3.350</i>			*INST. FREQ.: <i>2</i> Mhz									
PROBE DELAY: <i>6.2638</i>			*RECTIFY: <i>FULL WAVE</i>									
VELOCITY: <i>1236</i>			DUAL <input type="checkbox"/> ON <input checked="" type="checkbox"/> OFF									
DISPLAY DELAY: <i>0</i>			*REJECT: <i>0</i> %									
*ENERGY: <i>HIGH</i>			*DISPLAY START: <i>1P</i>									
*DAMPING: <i>1K</i>			DET: <input type="checkbox"/> PEAK <input checked="" type="checkbox"/> FLANK									
*PRF MODE: <i>AUTO HIGH</i>			TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>									
CALIBRATION TIMES												
REF. REFLECTOR: <i>SDH</i>		GAIN: dB <i>44</i>		INITIAL TIME: <i>1030</i>								
AMPLITUDE: <i>60%</i>		METAL PATH: <i>1.59</i>		FINAL TIME: <i>1330</i>								
VERIFICATION TIMES		1) <i>1200</i>		2) <i>1225</i>		3) <i>1245</i>						
		4) <i>1300</i>		5) <i>N/A</i>		6) <i>N/A</i>						
		7) <i>N/A</i>		8) <i>N/A</i>		9) <i>N/A</i>						
* PDI QUALIFIED INSTRUMENT SETTINGS:												
VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE !												
LINEARITY CHECK												
VERTICAL	SIGNAL 1		100	90	80	70	60	50	40	30	20	10
	SIGNAL 2		50	45	40	35	30	25	20	15	10	05
ATTENUATOR	GAIN	SET	-6 dB		-12 dB		SET		+12		SET	
	AMP	80	32-48		16-24		20		64-96		40	
			<i>40</i>		<i>20</i>		<i>80</i>		<i>80</i>			
COMMENTS: <i>SEE ATTACHED</i>						WELDS/ITEMS EXAMINED:						
						<i>GR-2-38</i>						
EXAMINER: <i>[Signature]</i>		EXAMINER: <i>N/A</i>		REVIEWER: <i>[Signature]</i>		ANII: <i>[Signature]</i>		DATE: <i>4/13/07</i>				
LEVEL: <i>II</i>		LEVEL:		LEVEL: <i>III</i>		DATE: <i>3/14/07</i>		PG. <i>3</i> OF <i>7</i>				



DISPLAY WIDTH: inches *3.350*

000290

TENNESSEE VALLEY AUTHORITY		DIGITAL ULTRASONIC CALIBRATION DATA SHEET			REPORT NUMBER: <i>R109</i>						
PROJECT: <i>BFN UNIT Z</i>		CYCLE: <i>14</i>		CALIBRATION DATE: <i>3/13/07</i>							
PROC.: <i>N-UT-64</i>		REV: <i>9</i>		TC: <i>N/A</i>		CALIBRATION BLOCK NO.: <i>WB 85</i> TEMP: <i>72 F</i>					
INSTR. MFG: <i>KRAUTKRAMER</i>		DUE DATE: <i>8/21/07</i>		SIMULATOR BLOCK NO.: <i>ALT CAL BLOCK</i>							
MODEL/TYPE: <i>USN 60</i>		M & TE NO.: <i>E36303</i>		THERMOMETER S/N: <i>562774</i> DUE DATE: <i>12/12/07</i>							
TRANSDUCER MFG: <i>RTD</i>		COUPLANT <i>ULTRAGEL II</i> BATCH: <i>DS325</i>									
S/N <i>92-816</i>		SIZE: <i>2(8x14)</i>		FREQ: <i>2.0</i> MHz		EXAM TYPE: SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RL <input checked="" type="checkbox"/>					
CABLE TYPE: <i>RG-174</i>		LENGTH: <i>72"</i>		inches							
DAC				ANGLE VERIFICATION							
				BLOCK TYPE: <i>Rompas</i>		S/N: <i>602L-83</i>					
				NOMINAL ANGLE: <i>60°L</i>		ACTUAL ANGLE: <i>60°L</i>					
INSTRUMENT SETTINGS											
REFLECTOR			REFERENCE		MEMORY						
SCAN DIRECT.	NTCH	SDH	SENSITIVITY		NUMBER						
AXIAL	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>76</i> dB		<i>60-RL</i>						
CIRC	<input type="checkbox"/>	<input type="checkbox"/>	<i>N/A</i> dB		<i>N/A</i>						
RANGE: <i>4.0</i>			*INST. FREQ.: <i>2</i> Mhz								
PROBE DELAY: <i>8.7716</i>			*RECTIFY: <i>FULL WAVE</i>								
VELOCITY: <i>2330</i>			DUAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF								
DISPLAY DELAY: <i>0</i>			*REJECT: <i>0</i> %								
*ENERGY: <i>HIGH</i>			*DISPLAY START: <i>1P</i>								
*DAMPING: <i>1K</i>			DET: <input type="checkbox"/> PEAK <input checked="" type="checkbox"/> FLANK								
*PRF MODE: <i>AUTO HIGH</i>			TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>								
REF. REFLECTOR: <i>SDH</i>				GAIN: dB <i>76</i>							
AMPLITUDE: <i>60%</i>				METAL PATH: <i>1.52</i>							
VERIFICATION TIMES				INITIAL TIME: <i>1030</i> FINAL TIME: <i>1330</i>							
1) <i>1200</i> 2) <i>1225</i> 3) <i>1245</i>				4) <i>1300</i> 5) <i>N/A</i> 6) <i>N/A</i> 7) <i>N/A</i> 8) <i>N/A</i> 9) <i>N/A</i>							
* PDI QUALIFIED INSTRUMENT SETTINGS: VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!											
LINEARITY CHECK											
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20	10
	SIGNAL 2	50	<i>45</i>	<i>40</i>	<i>35</i>	<i>30</i>	<i>25</i>	<i>20</i>	<i>15</i>	<i>10</i>	<i>05</i>
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6			
	AMP	80	32-48	16-24	20	64-96	40	64-96			
			<i>40</i>	<i>20</i>	<i>80</i>		<i>80</i>				
COMMENTS: <i>SEE ATTACHED</i>				WELDS/ITEMS EXAMINED:							
				<i>GR-2-38</i>							
EXAMINER: <i>[Signature]</i>		EXAMINER: <i>N/A</i>		REVIEWER: <i>[Signature]</i>		ANTI: <i>[Signature]</i>					
LEVEL: <i>II</i>		LEVEL:		LEVEL: <i>III</i> DATE: <i>3/14/07</i>		DATE: <i>4/14/07</i>					
						PG. <i>4</i> OF <i>7</i>					

000291

TENNESSEE VALLEY
AUTHORITY

MANUAL ULTRASONIC
PIPING EXAMINATION
DATA SHEET

REPORT NUMBER

R109

PROJECT: BFN UNIT/CYCLE 2114

S TM RECIR

WELD ID.: GR-2-38

CONFIG.: SDL TO P
FLOW 

EXAMINATION DATE 3/13/07

START TIME: 1030 END TIME: 1330

EXAM SURFACE ID OD

MATERIAL TYPE: CS SS CSCI CCSS

SURFACE TEMP. 72 PYRO NO. 562774

PROCEDURE: N-UT-64 REV: 9 TC: N/A

W_o REFERENCE: WELD E

L_o REFERENCE: REACTOR SIDE OF PIPE

EXAMINATION ANGLE 45 DEG. 60/60 DEG.

AXIAL SCAN SENSITIVITY 48 dB 46/76 dB

CIRC. SCAN SENSITIVITY 48 dB N/A dB

IND NO.	L (in) FROM REF.			AT MAX AMP			MAX AMP % DAC	EXAM NO. 3-14	NOM. ANG.	NRI	INDICATION INFORMATION: TYPE, DAMPING, ETC.
	L1	L Max	L2	W MAX	MP MAX	D MAX					
								3	45	<input checked="" type="checkbox"/>	SCAN 3, 45° shear, not performed 3/13/07 DUE TO CONFIG
								4	45	<input checked="" type="checkbox"/>	
								5	45	<input checked="" type="checkbox"/>	
								6	45	<input checked="" type="checkbox"/>	
								3	60	<input checked="" type="checkbox"/>	SCAN 3, 60° shear NOT PERFORMED 3/13/07 DUE TO CONFIGURATION
								4	60	<input checked="" type="checkbox"/>	
								3	60RL	<input checked="" type="checkbox"/>	
								4	60RL	<input checked="" type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	

REMARKS/LIMITATIONS ID GEOMETRY WAS NOTED AT BELOW RECORDABLE LEVELS 360° INTERMITTANTLY

EXAMINER: [Signature] LEVEL: II
 EXAMINER: N/A LEVEL: _____
 REVIEWED BY: [Signature] LEVEL: III DATE 3/14/07

ANII: [Signature]
 DATE 4/13/07
 PAGE 5 OF 7


000292

TVA	WALL THICKNESS PROFILE SHEET	REPORT NO: <i>R109</i>
------------	---	---------------------------


PROJECT: <u>BFN</u>	WELD NO: <u>GR-Z-38</u>
UNIT: <u>2 CYCLE 14</u>	SYSTEM: <u>RECIRCULATION</u>

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	.96	N/A		
2	.60			
3	.65			
4	.60			
5	.61			



CROWN HEIGHT: <u>FLUSH</u>	DIAMETER: <u>12"</u>
CROWN WIDTH: <u>1.5"</u>	WELD LENGTH: <u>39.5"</u>



CONTOURS

EXAMINER: <i>[Signature]</i>	REVIEWED BY: <i>[Signature]</i>	ANII: <i>[Signature]</i>
LEVEL: <u>#</u>	LEVEL: <u>III</u>	DATE: <u>4/13/07</u>
DATE: <u>3/13/07</u>	DATE: <u>3/14/07</u>	PAGE <u>6</u> OF <u>7</u>


TVA	WALL THICKNESS PROFILE SHEET	REPORT NO: R109
------------	---	---------------------------

PROJECT: <u>BFN</u>	WELD NO: <u>GR-2-38</u>
UNIT: <u>2 CYCLE 14</u>	SYSTEM: <u>RECIRCULATION</u>

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°


SEE CONTOUR SHEET

Position	0°	90°	180°	270°
1				
2			A	
3		N		
4				
5				



CROWN HEIGHT: <u>FLUSH</u>	DIAMETER: <u>12"</u>
CROWN WIDTH: <u>1.5"</u>	WELD LENGTH: <u>39.5"</u>

Required exam volume = (.2x2.0) 39.5 = 15.8 cubic inches



ASME Section II Code coverage = 100%

ASME Section XI, Appendix VIII qualified coverage = 50%

axial scans = (1.0x.2) x 39.5 = 7.9 cubic inches ÷ 15.8 = .5 x 100 = 50%

Circ scans = (1.0x.2) x 39.5 = 7.9 cubic inches ÷ 15.8 = .5 x 100 = 50%

(50+50) ÷ 2 = 50

COVERAGE

EXAMINER: <u>[Signature]</u>	REVIEWED BY: <u>[Signature]</u>	ANII: <u>[Signature]</u>
LEVEL: <u>II</u>	LEVEL: <u>III</u>	DATE: <u>4/13/07</u>
DATE: <u>3/13/07</u>	DATE: <u>3/14/07</u>	PAGE <u>2</u> OF <u>7</u>

Examination Report No. R-112

Weld No. GR-2-41

000296

TENNESSEE VALLEY AUTHORITY		EXAMINATION SUMMARY AND RESOLUTION DATA SHEET		REPORT NUMBER: <i>R112</i>	
PROJECT: BFN UNIT: 2		CYCLE: 14		COMPONENT ID: GR-2-41	
EXAMINATION METHOD				SYSTEM: Recirc ISI DWG. NO. 2-ISI-0270-C-02	
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CODE CLASS: 1 CATEGORY: R-A	
PROCEDURE: N-UT-64		REV: 9	TC: NA	CONFIG.: RED	TO Pipe
EXAMINER: <i>Wade Holberg</i>		EXAMINER: <i>N/A</i>		EXAMINER: <i>N/A</i>	
LEVEL: <i>II</i>		LEVEL:		LEVEL:	

This report contains the data associated with the manual ultrasonic examination of GR-2-41 to met the requirements of ASME Section XI, category R-A (see assignment sheet), item number R1.16C and BWRVIP 75A, NU0313.

This exam was performed using equipment, procedures and personnel qualified in accordance with ASME Section XI, Appendix VIII as amended by 10CFR50.55a final rule.

The component examined was a SS 22" to 12" reducer to pipe weld, having single sided access.

A 45° and 60° shear was used for scan directions 4, 5 and 6. A 60° RL wave was used for scan 4. Joint configuration prevented using the scan 3 direction.


Root geometry was seen intermittently 360° at varying amplitudes.

There were no reportable indications.

10CFR50.55a qualified coverage obtained was 50% due to single sided access.
ASME Section XI Code coverage was 100%

RESOLUTION BY: <i>Wade Holberg</i>	REVIEWED BY: <i>Wade Holberg</i>	ANII: <i>David Hunt</i>
LEVEL: <i>II</i> DATE: <i>3/13/07</i>	LEVEL: <i>III</i> DATE: <i>3/15/07</i>	DATE: <i>4/17/07</i>
		PG. <i>1</i> OF <i>8</i>

TENNESSEE VALLEY AUTHORITY	MANUAL ULTRASONIC PIPING EXAMINATION DATA SHEET	REPORT NUMBER <u>R112</u>
---------------------------------------	--	-------------------------------------


PROJECT: <u>BFN</u> UNIT/CYCLE: <u>2114</u> S ^{TE} TEM RECIR _____ WELD I.D.: <u>GR-241</u> CONFIG.: <u>TEE REDUCER TO PIPE</u> <div style="text-align: center;">  <p>FLOW</p> </div> PROCEDURE: <u>N-UT-64</u> REV: <u>9</u> TC: _____ W ₀ REFERENCE: <u>WELD CENTERLINE</u> L ₀ REFERENCE: <u>SIDE OPPOSITE R₀</u>	EXAMINATION DATE: <u>3/13/07</u> START TIME: <u>1245</u> END TIME: <u>1303</u> EXAM SURFACE <input type="checkbox"/> ID <input checked="" type="checkbox"/> OD MATERIAL TYPE: <input type="checkbox"/> CS <input checked="" type="checkbox"/> SS <input type="checkbox"/> CSCL <input type="checkbox"/> CCSS SURFACE TEMP. <u>88</u> PYRO NO. <u>562274</u> <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>EXAMINATION ANGLE</td> <td><u>45°</u> DEG.</td> <td>DEG.</td> </tr> <tr> <td>AXIAL SCAN SENSITIVITY</td> <td><u>38.0</u> dB</td> <td>dB</td> </tr> <tr> <td>CIRC. SCAN SENSITIVITY</td> <td><u>42.0</u> dB</td> <td>dB</td> </tr> </table>	EXAMINATION ANGLE	<u>45°</u> DEG.	DEG.	AXIAL SCAN SENSITIVITY	<u>38.0</u> dB	dB	CIRC. SCAN SENSITIVITY	<u>42.0</u> dB	dB
EXAMINATION ANGLE	<u>45°</u> DEG.	DEG.								
AXIAL SCAN SENSITIVITY	<u>38.0</u> dB	dB								
CIRC. SCAN SENSITIVITY	<u>42.0</u> dB	dB								

IND NO.	L (in) FROM REF.			AT MAX AMP			MAX AMP % DAC	EXAM NO. 3-14	NOM. ANG.	NRI	INDICATION INFORMATION: TYPE, DAMPING, ETC.
	L1	L Max	L2	W MAX	MP MAX	D MAX					
								3	45°	<input type="checkbox"/>	NO SCAN DUE TO CONFIGURATION OF TEE
								4	"	<input checked="" type="checkbox"/>	NO RECORDABLE INDICATIONS
								5	"	<input checked="" type="checkbox"/>	" " "
								6	"	<input checked="" type="checkbox"/>	" " "
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	

REMARKS/LIMITATIONS NO SCAN #3 DUE TO CONFIGURATION

EXAMINER: <u>Wade Welch</u>	LEVEL: <u>II</u>	ANI: <u>Paul Ford</u>
EXAMINER: <u>N/A</u>	LEVEL: _____	DATE: <u>4/17/07</u>
REVIEWED BY: <u>Wade Welch</u>	LEVEL: <u>III</u>	DATE: <u>3/15/07</u>
		PAGE: <u>2</u> OF <u>8</u>

TENNESSEE VALLEY AUTHORITY	MANUAL ULTRASONIC PIPING EXAMINATION DATA SHEET	REPORT NUMBER <u> R112 </u>
---------------------------------------	--	---

PROJECT: <u>BFN</u> UNIT/CYCLE <u>2114</u> SYSTEM: <u>RECIR</u> WELD I.D.: <u>GR-241</u> CONFIG.: <u>TEE REDUCER TO PIPE</u> <div style="text-align: center;">  FLOW </div> PROCEDURE: <u>N-UT-64</u> REV: <u>9</u> TC: _____ W ₀ REFERENCE: <u>WELD CENTERLINE</u> L ₀ REFERENCE: <u>SIDE OPPOSITE RPV</u>	EXAMINATION DATE <u>3/13/07</u> START TIME: <u>1222</u> END TIME: <u>1244</u> EXAM SURFACE <input type="checkbox"/> ID <input checked="" type="checkbox"/> OD MATERIAL TYPE: <input type="checkbox"/> CS <input checked="" type="checkbox"/> SS <input type="checkbox"/> CSCL <input type="checkbox"/> CCSS SURFACE TEMP. <u>88</u> PYRO NO. <u>5E2724</u> EXAMINATION ANGLE <u>60°S</u> DEG. <u>60°RL</u> DEG. AXIAL SCAN SENSITIVITY _____ dB _____ dB CIRC. SCAN SENSITIVITY _____ dB _____ dB
--	--

IND NO.	L (in) FROM REF.			AT MAX AMP			MAX AMP %DAC	EXAM NO. 3-14	NOM. ANG.	NRI	INDICATION INFORMATION: TYPE, DAMPING, ETC.	
	L1	LMax	L2	W MAX	MP MAX	O MAX						
									4	60°S	<input type="checkbox"/>	ROOT GEOMETRY INT. 360°
									4	60°RL	<input type="checkbox"/>	" " " "
											<input type="checkbox"/>	
											<input type="checkbox"/>	
											<input type="checkbox"/>	
											<input type="checkbox"/>	
											<input type="checkbox"/>	
											<input type="checkbox"/>	
											<input type="checkbox"/>	
											<input type="checkbox"/>	
											<input type="checkbox"/>	
											<input type="checkbox"/>	
											<input type="checkbox"/>	
											<input type="checkbox"/>	
											<input type="checkbox"/>	
											<input type="checkbox"/>	
											<input type="checkbox"/>	
											<input type="checkbox"/>	
											<input type="checkbox"/>	
											<input type="checkbox"/>	

REMARKS/LIMITATIONS ROOT GEOMETRY SEEN INT 360° AT VARYING AMPLITUDES.
NO OTHER RELEVANT INDICATIONS NOTED. NO SCAN #3 DUE TO CONFIGURATION.

EXAMINER: <u>Shel Holtz</u>	LEVEL: <u>II</u>	ANI: <u>Shel Holtz</u>	
EXAMINER: <u>N/A</u>	LEVEL: _____	DATE: <u>4/17/07</u>	
REVIEWED BY: <u>Walt Welch</u>	LEVEL: <u>III</u>	DATE: <u>3/13/07</u>	PAGE <u>3</u> OF <u>8</u>


000299

TENNESSEE VALLEY AUTHORITY		DIGITAL ULTRASONIC CALIBRATION DATA SHEET				REPORT NUMBER: <i>R112</i>						
PROJECT: <i>BFN UNIT 2</i>		CYCLE: <i>14</i>		CALIBRATION DATE: <i>3/13/07</i>								
PROC.: <i>N-UT-82</i>		REV: <i>2</i>		TC: <i>N/A</i>		CALIBRATION BLOCK NO.: <i>5Q-123</i> TEMP: <i>72 °F</i>						
INSTR. MFG: <i>KRAUTKRAMER</i>		DUE DATE: <i>12/11/07</i>		SIMULATOR BLOCK NO.: <i>92-7616</i>								
MODEL/TYPE: <i>USN-60</i>		M & TE NO.: <i>E34054</i>		THERMOMETER S/N: <i>562774</i> DUE DATE: <i>12/12/07</i>								
TRANSDUCER MFG: <i>KBA</i>		COUPLANT		BATCH:								
ELEMENTS: <i>1</i> SHAPE: <i>ROUND</i>		<i>ULTRAGEL II</i>		<i>05325</i>								
S/N <i>00XD3R</i> SIZE: <i>0.375</i>		FREQ: <i>1.5</i> MHz		EXAM TYPE: SHEAR <input checked="" type="checkbox"/>		LONG <input type="checkbox"/> RL <input type="checkbox"/>						
CONTOUR: <i>FLAT</i>		FOCUS: <i>N/A</i>		ANGLE VERIFICATION								
CABLE TYPE: <i>RG-174</i> LENGTH: <i>72"</i>		#CNT: <i>0</i>		BLOCK TYPE: <i>ROMPAS</i>		S/N: <i>6026-83</i>						
DAC		NOMINAL ANGLE: <i>45°</i>		ACTUAL ANGLE: <i>46°</i>								
INSTRUMENT SETTINGS												
REFLECTOR				REFERENCE		MEMORY						
SCAN DIRECT:		NTCH		SDH		SENSITIVITY						
AXIAL		<input checked="" type="checkbox"/>		<input type="checkbox"/>		30.0 dB						
CIRC		<input type="checkbox"/>		<input type="checkbox"/>		45° P375						
RANGE: <i>3.0</i>				*INST. FREQ.: <i>2.0</i> MHz								
PROBE DELAY: <i>4.1400</i>				*RECTIFY: <i>FULLWAVE</i>								
VELOCITY: <i>0.1270</i>				DUAL <input type="checkbox"/> ON <input checked="" type="checkbox"/> OFF								
DISPLAY DELAY: <i>0.0</i>				*REJECT: <i>0</i> %								
*ENERGY: <i>HIGH</i>				*DISPLAY START: <i>IP</i>								
*DAMPING: <i>1K</i>				DET: <input type="checkbox"/> PEAK <input checked="" type="checkbox"/> FLANK								
*PRF MODE: <i>AUTOHIGH</i>				TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>								
		A M P L I T U D E		CALIBRATION TIMES								
				INITIAL TIME: <i>0845</i>		FINAL TIME: <i>1340</i>						
REF. REFLECTOR: <i>1.0" NOTCH</i>		GAIN: dB <i>26.5</i>		VERIFICATION TIMES		1) <i>1245</i> 2) <i>N/A</i> 3) _____ 4) _____ 5) _____ 6) _____ 7) _____ 8) _____ 9) _____						
AMPLITUDE: <i>80%</i>		METAL PATH: <i>1.439</i>		* PDI QUALIFIED INSTRUMENT SETTINGS:								
VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!												
LINEARITY CHECK												
VERTICAL	SIGNAL 1		100	90	80	70	60	50	40	30	20	10
	SIGNAL 2		50	45	40	35	30	25	20	15	10	5
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6				
	AMP	80	32-48	16-24	20	64-96	40	64-96				
			40	20		80		80				
COMMENTS:					WELDS/ITEMS EXAMINED:							
					<i>GR-2-41</i>							
EXAMINER: <i>[Signature]</i>		EXAMINER: <i>N/A</i>		REVIEWER: <i>[Signature]</i>		ANII: <i>[Signature]</i>		DATE: <i>4/17/07</i>				
LEVEL: <i>II</i>		LEVEL:		LEVEL: <i>III</i>		DATE: <i>3/13/07</i>		PG. <i>4</i> OF <i>8</i>				

000300

TENNESSEE VALLEY AUTHORITY		DIGITAL ULTRASONIC CALIBRATION DATA SHEET			REPORT NUMBER: <i>R112</i>																																																																										
PROJECT: <i>BFU UNIT 2</i>		CYCLE: <i>14</i>		CALIBRATION DATE: <i>3/13/07</i>																																																																											
PROC.: <i>N-UT-64</i>		REV: <i>9</i>		CALIBRATION BLOCK NO.: <i>SQ-123</i> TEMP: <i>77 F</i>																																																																											
INSTR. MFG: <i>KRAUTKRAMER</i>		DUE DATE: <i>12/11/07</i>		SIMULATOR BLOCK NO: <i>6026-83</i>																																																																											
MODEL TYPE: <i>USN-60</i>		M & TE NO.: <i>E34054</i>		THERMOMETER S/N: <i>562774</i> DUE DATE: <i>12/12/07</i>																																																																											
TRANSDUCER MFG: <i>KBA</i>		COUPLANT <i>ULTRAGEL II</i>			BATCH: <i>05325</i>																																																																										
ELEMENTS: <i>1</i> SHAPE: <i>ROUND</i>		EXAM TYPE: SHEAR <input checked="" type="checkbox"/> LONG <input type="checkbox"/> RL <input type="checkbox"/>																																																																													
S/N <i>00XD3R</i> SIZE: <i>0.375"</i> FREQ: <i>1.5</i> MHz		ANGLE VERIFICATION																																																																													
CONTOUR: <i>FLAT</i> FOCUS: <i>N/A</i>		BLOCK TYPE: <i>Rompas</i>		S/N: <i>6026-83</i>																																																																											
CABLE TYPE: <i>RG-174</i> LENGTH: <i>72"</i> #CNT: <i>0</i>		NOMINAL ANGLE: <i>60°</i>		ACTUAL ANGLE: <i>58°</i>																																																																											
DAC		INSTRUMENT SETTINGS																																																																													
<div style="display: flex; align-items: center;"> <table border="1" style="border-collapse: collapse; text-align: center;"> <tr><td>100</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>80</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>60</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>40</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>20</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>0</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </table> <div style="margin-left: 10px;"> <p>A M P L I T U D E</p> </div> </div> <p style="margin-top: 10px;">* <i>1.0" NOTCH</i></p> <p style="margin-top: 10px;">* <i>5m</i></p> <p style="margin-top: 10px;">DISPLAY WIDTH: inches <i>4.0"</i></p>		100												80												60												40												20												0												REFLECTOR		REFERENCE		MEMORY	
		100																																																																													
		80																																																																													
		60																																																																													
		40																																																																													
		20																																																																													
		0																																																																													
		SCAN DIRECT		NTCH		SDH		SENSITIVITY		NUMBER																																																																					
		AXIAL		<input checked="" type="checkbox"/>		<input type="checkbox"/>		<i>48.0</i> dB		<i>60-375 RECUR</i>																																																																					
		CIRC		<input type="checkbox"/>		<input type="checkbox"/>		<i>N/A</i> dB		<i>N/A</i>																																																																					
RANGE: <i>4.0</i>		*INST. FREQ.: <i>2.0</i> MHz																																																																													
PROBE DELAY: <i>9.5900</i>		*RECTIFY: <i>FULLWAVE</i>																																																																													
VELOCITY: <i>0.1236</i>		DUAL <input type="checkbox"/> ON <input checked="" type="checkbox"/> OFF																																																																													
DISPLAY DELAY: <i>0.0</i>		*REJECT: <i>0</i> %																																																																													
*ENERGY: <i>HIGH</i>		*DISPLAY START: <i>TP</i>																																																																													
*DAMPING: <i>1K</i>		DET: <input type="checkbox"/> PEAK <input checked="" type="checkbox"/> FLANK																																																																													
*PRF MODE: <i>AUTO HIGH</i>		TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>																																																																													
REF. REFLECTOR: <i>1.0" NOTCH</i>		GAIN: dB <i>48.0</i>		CALIBRATION TIMES																																																																											
AMPLITUDE: <i>80%</i>		METAL PATH: <i>1.83</i>		INITIAL TIME: <i>0905</i>		FINAL TIME: <i>1342</i>																																																																									
VERIFICATION TIMES		<i>1) 233</i>		<i>2) N/A</i>		<i>3) ---</i>		<i>4) ---</i>		<i>5) ---</i>		<i>6) ---</i>		<i>7) ---</i>		<i>8) ---</i>		<i>9) ---</i>																																																													
* PDI QUALIFIED INSTRUMENT SETTINGS: VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!																																																																															
LINEARITY CHECK																																																																															
VERTICAL		SIGNAL 1		100		90		80		70		60		50		40		30		20		10																																																									
		SIGNAL 2		50		45		40		35		30		25		20		15		10		5																																																									
ATTENUATOR		GAIN		SET		-6 dB		-12 dB		SET		+12		SET		+6																																																															
		AMP		80		32-48		16-24		20		64-96		40		64-96																																																															
				<i>40</i>		<i>20</i>				<i>80</i>		<i>80</i>																																																																			
COMMENTS:										WELDS/ITEMS EXAMINED: <i>GR-2-41</i>																																																																					
EXAMINER: <i>[Signature]</i>					EXAMINER: <i>N/A</i>					REVIEWER: <i>[Signature]</i>					ANII: <i>[Signature]</i>																																																																
LEVEL: <i>I</i>					LEVEL:					LEVEL: <i>III</i> DATE: <i>3/15/07</i>					DATE: <i>4/17/07</i>																																																																
										PG. <i>5</i> OF <i>8</i>																																																																					

000301

TENNESSEE VALLEY AUTHORITY		DIGITAL ULTRASONIC CALIBRATION DATA SHEET			REPORT NUMBER: <i>R112</i>						
PROJECT: <i>BFU UNIT 2</i>		CYCLE: <i>14</i>		CALIBRATION DATE: <i>3/13/07</i>							
PROC.: <i>N-UT-64</i>		REV: <i>9</i>		CALIBRATION BLOCK NO.: <i>SQ-123</i> TEMP: <i>72°F</i>							
INSTR. MFG: <i>KRAUTKRAMER</i>		DUE DATE: <i>12/11/07</i>		SIMULATOR BLOCK NO.: <i>6026-83</i>							
MODEL TYPE: <i>USN-60</i>		M & TE NO.: <i>E34054</i>		THERMOMETER S/N: <i>562774</i> DUE DATE: <i>12/12/07</i>							
TRANSDUCER MFG: <i>RTD</i>		COUPLANT <i>ULTRAGEL II</i>			BATCH: <i>05325</i>						
ELEMENTS: <i>2</i> SHAPE: <i>RECT.</i>		EXAM TYPE: SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RL <input checked="" type="checkbox"/>									
S/N <i>92-816</i> SIZE: <i>2(8x14)</i>		FREQ: <i>2.0</i> MHz									
CONTOUR: <i>FLAT</i>		FOCUS: <i>FS-20</i>									
CABLE TYPE: <i>2(RG-174)</i>		LENGTH: <i>72"</i>		#CNT: <i>0</i>		BLOCK TYPE: <i>ROMPAS</i> S/N: <i>6026-83</i>					
DAC		NOMINAL ANGLE: <i>60°L</i>		ACTUAL ANGLE: <i>60°L</i>							
<div style="display: flex; align-items: center;"> <div style="margin-right: 10px;">100 80 60 40 20 0</div>  <div style="margin-left: 10px; text-align: center;">A M P L I T U D E</div> </div> <p style="margin-top: 10px;">DISPLAY WIDTH: inches <i>4.0</i></p>		INSTRUMENT SETTINGS									
		REFLECTOR			REFERENCE		MEMORY				
		SCAN DIRECT:	NTCH	SDII	SENSITIVITY		NUMBER				
		AXIAL	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>72.0</i> dB		<i>92-816</i>				
		CIRC	<input type="checkbox"/>	<input type="checkbox"/>	dB						
		RANGE: <i>4.0"</i>			*INST. FREQ: <i>2.0</i> MHz						
		PROBE DELAY: <i>8.7716</i>			*RECTIFY: <i>FULLWAVE</i>						
		VELOCITY: <i>0.2330</i>			DUAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF						
		DISPLAY DELAY: <i>0.0</i>			*REJECT: <i>0</i> %						
		*ENERGY: <i>HIGH</i>			*DISPLAY START: <i>IP</i>						
*DAMPING: <i>1K</i>			DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK								
*PRF MODE: <i>AUTO HIGH</i>			TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>								
REF. REFLECTOR: <i>1.0" NOTCH</i>		GAIN: dB <i>72.0</i>		CALIBRATION TIMES							
AMPLITUDE: <i>80%</i>		METAL PATH: <i>2.00</i>		INITIAL TIME: <i>0834</i>		FINAL TIME: <i>1345</i>					
VERIFICATION TIMES		1) <i>222</i>	2) <i>N/A</i>	3) <i>---</i>	4) <i>---</i>	5) <i>---</i>					
		6) <i>---</i>	7) <i>---</i>	8) <i>---</i>	9) <i>---</i>						
* PDI QUALIFIED INSTRUMENT SETTINGS:											
VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!											
LINEARITY CHECK											
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20	10
	SIGNAL 2	50	45	40	35	30	25	20	15	10	5
ATTENUATOR	GAIN	SET	-6 dB		-12 dB		SET	+12		SET	+6
	AMP	80	32-48		16-24		20	64-96		40	64-96
				40	20			80			80
COMMENTS:				WELDS/ITEMS EXAMINED:							
				<i>GR-2-41</i>							
EXAMINER: <i>[Signature]</i>		EXAMINER: <i>N/A</i>		REVIEWER: <i>[Signature]</i>		ANII: <i>[Signature]</i>		DATE: <i>4/17/07</i>		PG. <i>6</i> OF <i>8</i>	
LEVEL: <i>I</i>		LEVEL:		LEVEL: <i>III</i>		DATE: <i>3/13/07</i>					

TVA

WALL THICKNESS
PROFILE SHEET

000302

REPORT NO:

R112

PROJECT: BFNP


WELD NO: GR-2-41

UNIT: 2

SYSTEM: RECIRC

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	N/A			
2	N/A			
3	.72			
4	.57			
5	.62			



CROWN HEIGHT: ISI PREP


DIAMETER: 12"

CROWN WIDTH: 1.25"

WELD LENGTH: 41

Required grain volume = $(.25 \times 1.75) 40 = 17.5$ cubic inches.

RING HENDER
TEE



ASME Code Coverage Section XI = 100%

ASME Section II, Appendix VII qualified coverage = 50%

$\cdot 17.5 \div 2 = 8.75 \div 17.5 = .5 \times 100 = 50\%$ axial & circum. flaws.

Walter Welch 3/15/07

EXAMINER: [Signature]
LEVEL: II
DATE: 3/13/07

REVIEWED BY: Walter Welch
LEVEL: III DATE: 3/15/07


ANII: [Signature]
DATE: 4/17/07
PAGE 7 OF 8

<h1>TVA</h1>	<h2>WALL THICKNESS PROFILE SHEET</h2>	REPORT NO: <i>R112</i>
--------------	---------------------------------------	---------------------------


PROJECT: <u>BFN</u>	WELD NO: <u>GR-2-41</u>
UNIT: <u>2</u>	SYSTEM: <u>RECIRC</u>

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	NA			
2	NA			
3	.72			
4	.67			
5	.62			



CROWN HEIGHT: <u>TGT 4511</u>	DIAMETER: <u>12"</u>
CROWN WIDTH: <u>1.25</u>	WELD LENGTH: <u>41</u>



ROOT GEOMETRY SEEN INT. 360°

EXAMINER: <u>[Signature]</u>	REVIEWED BY: <u>[Signature]</u>	ANII: <u>[Signature]</u>
LEVEL: <u>II</u>	LEVEL: <u>III</u>	DATE: <u>4/17/07</u>
DATE: <u>3/13/07</u>	DATE: <u>3/15/07</u>	PAGE <u>8</u> OF <u>8</u>

Examination Report No. R-114

Weld No. GR-2-48

000309

TENNESSEE VALLEY AUTHORITY		EXAMINATION SUMMARY AND RESOLUTION DATA SHEET		REPORT NUMBER: <i>R114</i>	
PROJECT: BFN UNIT: 2		CYCLE: 14		COMPONENT ID: GR-2-48	
EXAMINATION METHOD				SYSTEM: Recirc ISI DWG. NO. 2-ISI-0270-C-02	
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CODE CLASS: I CATEGORY: R-A	
PROCEDURE: N-UT-64		REV:9	TC:NA	CONFIG.:	SDL TO Pipe
EXAMINER: <i>Dick Helms</i>		EXAMINER:		EXAMINER:	
LEVEL: <u>II</u>		LEVEL:		LEVEL:	

This report contains the data associated with the manual ultrasonic examination of GR-2-48 to meet the requirements of ASME Section XI, category R-A (see assignment sheet), item number RL16C and BWRVIP 75A, NU0313.

This exam was performed using equipment, procedures and personnel qualified in accordance with ASME Section XI, Appendix VIII as amended by 10CFR50.55a final rule.

The component examined was a SS pipe to saddle weld, 12" diameter, having single side access.

A 45° and 60° shear was used for scan directions 4, 5 and 6. A 60° RL wave was used for scan 4. Joint configuration prevented using the scan 3 direction.


There were no reportable indications.

10CFR50.55a qualified coverage obtained was 50% due to single sided access.
ASME Section XI Code coverage was 100%

RESOLUTION BY: <i>Dick Helms</i>		REVIEWED BY: <i>Walter Welch</i>		ANI: <i>Pat Hood</i>	
LEVEL: <u>II</u> DATE: <i>3/16/07</i>		LEVEL: <u>III</u> DATE: <i>3/16/07</i>		DATE: <i>4/18/07</i>	
				PG. <i>1</i> OF <i>7</i>	

000311

TENNESSEE VALLEY AUTHORITY	MANUAL ULTRASONIC PIPING EXAMINATION DATA SHEET	REPORT NUMBER <u>R114</u>
---------------------------------------	--	-------------------------------------

PROJECT: <u>BFN</u> UNIT/CYCLE <u>2114</u> S' TEM RECIR _____ WELD I.D.: <u>GR-2.48</u> CONFIG.: <u>SDL</u> TO <u>P</u> <div style="text-align: center;">  </div>	EXAMINATION DATE <u>3/10/07</u> START TIME: <u>1142</u> END TIME: <u>1152</u> EXAM SURFACE <input type="checkbox"/> ID <input checked="" type="checkbox"/> OD MATERIAL TYPE: <input type="checkbox"/> CS <input checked="" type="checkbox"/> SS <input type="checkbox"/> CSCL <input type="checkbox"/> CCSS SURFACE TEMP. <u>89</u> PYRO NO. <u>562774</u>
PROCEDURE: <u>N-UT-64</u> REV: <u>9</u> TC: <u>N/A</u> W _o REFERENCE: <u>WELD CENTERLINE</u> L _o REFERENCE: <u>TOP DEAD CENTER</u>	EXAMINATION ANGLE <u>60° RL</u> DEG. <u>N/A</u> DEG. AXIAL SCAN SENSITIVITY <u>78.0</u> dB <u>N/A</u> dB CIRC. SCAN SENSITIVITY <u>N/A</u> dB _____ dB

IND NO.	L (in) FROM REF.			AT MAX AMP			MAX AMP % DAC	EXAM NO. 3-14	NOM. ANG.	NRI	INDICATION INFORMATION: TYPE, DAMPING, ETC.
	L1	L Max	L2	W MAX	MP MAX	D MAX					
								4	60° RL	<input checked="" type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	


REMARKS/LIMITATIONS 60° RL USED FOR DETECTION OF FLAWS ON OPPOSITE SIDE OF WELD.
NO IND. NOTED.

EXAMINER: <u>Walter Hurling</u> LEVEL: <u>II</u>	ANI: <u>Paul J. Ford</u>
EXAMINER: <u>N/A</u> LEVEL: _____	DATE: <u>4/13/07</u>
REVIEWED BY: <u>Walter Welch</u> LEVEL: <u>III</u> DATE: <u>3/16/07</u>	PAGE: <u>3</u> OF <u>7</u>

000312

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER: <i>R114</i>
-------------------------------	---	-------------------------------

PROJECT: <i>BFN UNIT 2</i>	CYCLE: <i>14</i>	CALIBRATION DATE: <i>3/10/07</i>
PROC.: <i>N-UT-64</i>	REV: <i>9</i>	TC: <i>N/A</i>
INSTR. MFG: <i>KRAUTKRAMER</i>	DUE DATE: <i>12/11/07</i>	CALIBRATION BLOCK NO.: <i>5Q-123</i>
MODELTYPE: <i>USN-60</i>	M&TE NO.: <i>E34054</i>	TEMP: <i>77 F</i>
TRANSDUCER MFG: <i>KBA</i>	COUPLANT	SIMULATOR BLOCK NO.: <i>6026-83</i>
ELEMENTS: <i>1</i>	SHAPE: <i>ROUND</i>	BATCH: <i>ULTRAGEL II 05325</i>
S/N <i>00XD3R</i>	SIZE: <i>0.375"</i>	FREQ: <i>1.5</i> MHz
CONTOUR: <i>FLAT</i>	FOCUS: <i>N/A</i>	EXAM TYPE: SHEAR <input checked="" type="checkbox"/> LONG <input type="checkbox"/> RL <input type="checkbox"/>
CABLE TYPE: <i>RG-174</i>	LENGTH: <i>72"</i>	#CNT: <i>Ø</i>
DAC	BLOCK TYPE: <i>Rompas</i>	S/N: <i>6026-83</i>
	NOMINAL ANGLE: <i>45°</i>	ACTUAL ANGLE: <i>46°</i>



INSTRUMENT SETTINGS				
REFLECTOR			REFERENCE	MEMORY
SCAN DIRECT	NTCH	SDH	SENSITIVITY	NUMBER
AXIAL	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>30.0</i> dB	<i>45° RECIPL</i>
CIRC	<input type="checkbox"/>	<input type="checkbox"/>	dB	
RANGE: <i>3.0</i>	*INST. FREQ: <i>2.0</i> MHz			
PROBE DELAY: <i>7.4509</i>	*RECTIFY: <i>FULLWAVE</i>			
VELOCITY: <i>0.1236</i>	DUAL <input type="checkbox"/> ON <input checked="" type="checkbox"/> OFF			
DISPLAY DELAY: <i>0.0</i>	*REJECT: <i>0</i> %			
*ENERGY: <i>HIGH</i>	*DISPLAY START: <i>IP</i>			
*DAMPING: <i>1K</i>	DET: <input type="checkbox"/> PEAK <input checked="" type="checkbox"/> FLANK			
*PRF MODE: <i>AUTO HIGH</i>	TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>			

REF. REFLECTOR: <i>1.0" NOTCH</i>	GAIN: dB <i>30.0</i>	CALIBRATION TIMES								
AMPLITUDE: <i>80%</i>	METAL PATH: <i>1.429</i>	INITIAL TIME: <i>1000</i>	FINAL TIME: <i>1554</i>							
VERIFICATION TIMES	1) <i>1/20</i>	2)	3)	4)	5)	6)	7)	8)	9)	

* PDI QUALIFIED INSTRUMENT SETTINGS:
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2
 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK											
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20	10
	SIGNAL 2	50	45	40	35	30	25	20	15	10	5
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6			
	AMP	80	32-48	16-24	20	64-96	40	64-96			
			40	20		80		80			


COMMENTS: <i>sim 4.5 @ 45° REF.</i>	WELDS/ITEMS EXAMINED:

EXAMINER: <i>[Signature]</i>	EXAMINER: <i>N/A</i>	REVIEWER: <i>[Signature]</i>	ANI: <i>[Signature]</i>
LEVEL: <i>T</i>	LEVEL:	DATE: <i>3/16/07</i>	DATE: <i>4/18/07</i>
		PG. <i>4</i> OF <i>7</i>	

000813

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER: <i>R114</i>
-------------------------------	---	-------------------------------

PROJECT: <i>BFN UNIT 2</i>	CYCLE: <i>14</i>	CALIBRATION DATE: <i>3/10/07</i>
PROC.: <i>N-UT-64</i>	REV: <i>9</i> TC: <i>N/A</i>	CALIBRATION BLOCK NO.: <i>5Q-123</i> TEMP: <i>78°F</i>
INSTR. MFG: <i>KRAUTKRAMER</i>	DUE DATE: <i>12/11/07</i>	SIMULATOR BLOCK NO.: <i>6026-83</i>
MODEL TYPE: <i>USN-60</i>	M & TE NO.: <i>E34054</i>	THERMOMETER S/N: <i>562774</i> DUE DATE: <i>12/12/07</i>
TRANSDUCER MFG: <i>RTD</i>	COUPLANT	BATCH:
ELEMENTS: <i>2</i> SHAPE: <i>RECT.</i>	<i>ULTRAGEL II</i> <i>05325</i>	
S/N <i>92-816</i> SIZE: <i>2(8x14)</i> FREQ: <i>2.0</i> MHZ	EXAM TYPE: SHEAR <input type="checkbox"/>	LONG <input type="checkbox"/> RL <input checked="" type="checkbox"/>
CONTOUR: <i>FLAT</i> FOCUS: <i>FS-20</i>	ANGLE VERIFICATION	
CABLE TYPE: <i>2(RG-174)</i> LENGTH: <i>72"</i> #CNT: <i>0</i>	BLOCK TYPE: <i>ROMPAS</i>	S/N: <i>6026-83</i>
DAC	NOMINAL ANGLE: <i>60°</i>	ACTUAL ANGLE: <i>60°</i>



DISPLAY WIDTH: inches *4.0*

INSTRUMENT SETTINGS				
REFLECTOR			REFERENCE	MEMORY
SCAN DIRECT.	NTCH	SDH	SENSITIVITY	NUMBER
AXIAL	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>76.0</i> dB	<i>92-816</i>
CIRC	<input type="checkbox"/>	<input type="checkbox"/>	dB	
RANGE:	<i>4.0</i>		*INST. FREQ.: <i>2.0</i> Mhz	
PROBE DELAY:	<i>8.7716</i>		*RECTIFY: <i>FULLWAVE</i>	
VELOCITY:	<i>0.2330</i>		DUAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF	
DISPLAY DELAY:	<i>0.0</i>		*REJECT: <i>0</i> %	
*ENERGY:	<i>HIGH</i>		*DISPLAY START: <i>IP</i>	
*DAMPING:	<i>1K</i>		DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK	
*PRF MODE:	<i>AUTO HIGH</i>		TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>	

REF. REFLECTOR: <i>1.0" NOTCH</i>	GAIN: dB <i>76.0</i>	CALIBRATION TIMES			
AMPLITUDE: <i>80%</i>	METAL PATH: <i>1.995</i>	INITIAL TIME: <i>0956</i>	FINAL TIME: <i>1550</i>		
VERIFICATION TIMES	1) <i>1142</i>	2) <i>1152</i>	3) _____	4) _____	5) _____
	6) _____	7) _____	8) _____	9) _____	

* PDI QUALIFIED INSTRUMENT SETTINGS:
VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2
OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK											
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20	10
	SIGNAL 2	50	45	40	35	30	25	20	15	10	5
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6			
	AMP	80	32-48	16-24	20	64-96	40	64-96			
			40	20		80		80			

COMMENTS: <i>sim 3.2 @ 60% 60.0 dB</i>	WELDS/ITEMS EXAMINED:
	<i>GR-2-48</i>

EXAMINER: <i>Wick Holling</i>	EXAMINER: <i>N/A</i>	REVIEWER: <i>Wick Wick</i>	ANI: <i>Earl Flood</i>
LEVEL: <i>II</i>	LEVEL: <i>TRN</i>	DATE: <i>3/16/07</i>	DATE: <i>4/18/07</i>
		PG. <i>5</i> OF <i>7</i>	

000314

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER: <i>R114</i>										
PROJECT: <i>BFU UNIT 2</i>	CYCLE: <i>14</i>	CALIBRATION DATE: <i>3/10/07</i>										
PROC.: <i>N-UT-64</i>	REV: <i>TC: N/A</i>	CALIBRATION BLOCK NO.: <i>SQ-123</i> TEMP: <i>77 °F</i>										
INSTR. MFG: <i>KRAUTKRAMER</i>	DUE DATE: <i>12/11/07</i>	SIMULATOR BLOCK NO.: <i>6026-83</i>										
MODEL TYPE: <i>USN-60</i>	M & TE NO.: <i>E34054</i>	THERMOMETER S/N: <i>562774</i> DUE DATE: <i>12/12/07</i>										
TRANSDUCER MFG: <i>KBA</i>	COUPLANT	BATCH:										
ELEMENTS: <i>1</i> SHAPE: <i>ROUND</i>	<i>ULTRAGEL II 05325</i>											
S/N <i>00XD3A</i> SIZE: <i>0.375"</i> FREQ: <i>1.5</i> MHz	EXAM TYPE: <input checked="" type="checkbox"/> SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RL <input type="checkbox"/>											
CONTOUR: <i>FLAT</i> FOCUS: <i>N/A</i>	ANGLE VERIFICATION											
CABLE TYPE: <i>RG-174</i> LENGTH: <i>72"</i> #CNT: <i>Ø</i>	BLOCK TYPE: <i>ROMPAS</i>	S/N: <i>6026-83</i>										
DAC	NOMINAL ANGLE: <i>60°</i>	ACTUAL ANGLE: <i>58°</i>										
<div style="display: flex; align-items: center;"> <div style="margin-right: 10px;">100 80 60 40 20 0</div> <div style="margin-left: 10px; text-align: center;">A M P L I T U D E</div> </div>	INSTRUMENT SETTINGS											
	REFLECTOR		REFERENCE									
	SCANDIRECT	NTCH	SDH	SENSITIVITY	MEMORY NUMBER							
	AXIAL	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>47.0</i> dB	<i>60° RECIRC</i>							
	CIRC	<input type="checkbox"/>	<input type="checkbox"/>	dB								
	RANGE: <i>4.0</i>	*INST. FREQ.: <i>2.0</i> MHz										
	PROBE DELAY: <i>9.5900</i>	*RECTIFY: <i>FULLWAVE</i>										
	VELOCITY: <i>0.1236</i>	DUAL <input type="checkbox"/> ON <input checked="" type="checkbox"/> OFF										
	DISPLAY DELAY: <i>0.0</i>	*REJECT: <i>0</i> %										
	*ENERGY: <i>HIGH</i>	*DISPLAY START: <i>IP</i>										
*DAMPING: <i>1K</i>	DET: <input type="checkbox"/> PEAK <input checked="" type="checkbox"/> FLANK											
*PRF MODE: <i>AUTO HIGH</i>	TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>											
REF. REFLECTOR: <i>NOTCH</i> GAIN: dB <i>47.0</i>	CALIBRATION TIMES											
AMPLITUDE: <i>80%</i> METAL PATH: <i>1.82"</i>	INITIAL TIME: <i>1015</i>	FINAL TIME: <i>1556</i>										
VERIFICATION TIMES	1) <i>1135</i> 2) <i>N/A</i> 3) <i>---</i>	4) <i>---</i> 5) <i>---</i> 6) <i>---</i> 7) <i>---</i> 8) <i>---</i> 9) <i>---</i>										
* PDI QUALIFIED INSTRUMENT SETTINGS: VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!												
LINEARITY CHECK												
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20	10	
	SIGNAL 2	50	45	40	35	30	25	20	15	10	5	
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6				
	AMP	80	32-48	16-24	20	64-96	40	64-96				
			<i>40</i>	<i>20</i>		<i>80</i>		<i>80</i>				
COMMENTS:	WELDS/ITEMS EXAMINED:											
EXAMINER: <i>[Signature]</i>	EXAMINER: <i>N/A</i>	REVIEWER: <i>[Signature]</i>	ANI: <i>[Signature]</i>									
LEVEL: <i>II</i>	LEVEL:	DATE: <i>3/16/07</i>	DATE: <i>3/16/07</i>	PG. <i>6</i> OF <i>7</i>								


000315

TVA	WALL THICKNESS PROFILE SHEET	REPORT NO: R114
------------	---	---------------------------

PROJECT: <u>BEN</u>	WELD NO: <u>GR-2-48</u>
UNIT: <u>2</u>	SYSTEM: <u>RECIRC</u>


Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	N/A			
2	.69			
3	.77	.67	SPLIT	
4	.75			
5	.60			



CROWN HEIGHT: <u>ISI PREF</u>	DIAMETER: <u>12.0"</u>
CROWN WIDTH: <u>10"</u>	WELD LENGTH: <u>40.0"</u>

Required exam volume = (.25 x 1.55) 40.0 = 15.5 cubic inches



WELD WAS SCANNED WITH 45°, 60° SHEAR AND 60° RL.
 Single sided access coverage = 75%
 Axial scans = $15.5 / 2 = 7.75 \div 15.5 = .5 \times 100 = 50\%$
 Circ scan = 15.5 obtained coverage = 100%
 $100 + 50 = 150 \div 2 = 75\%$ Appendix VII qualified coverage.
 ASME code coverage = no limitations = 100% *Walter Welch 3/13/07*

EXAMINER: <u>[Signature]</u>	REVIEWED BY: <u>Walter Welch</u>	ANII: <u>[Signature]</u>
LEVEL: <u>II</u>	LEVEL: <u>III</u> DATE: <u>3/16/07</u>	DATE: <u>3/18/07</u>
DATE: <u>3/16/07</u>		PAGE <u>7</u> OF <u>7</u>

Examination Report No. R-115

Weld No. GR-2-15(OL)

000316

TENNESSEE VALLEY AUTHORITY		EXAMINATION SUMMARY AND RESOLUTION DATA SHEET		REPORT NUMBER: <i>R115</i>	
PROJECT: BFN UNIT: 2		CYCLE: 14		COMPONENT ID: GR-2-15(OI.)	
EXAMINATION METHOD				SYSTEM: RWCUS ISI DWG. NO. 2-ISI-0272-C-01	
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CODE CLASS: 1 CATEGORY: R-A	
PROCEDURE: N-UT-66		REV: 5	TC: NA	CONFIG.:	SWOL TO NA
EXAMINER: <i>MATT WELCH</i>		EXAMINER: <i>N/A</i>		EXAMINER: <i>N/A</i>	
LEVEL: <i>III</i>		LEVEL:		LEVEL:	
<p>This report contains the data associated with the manual ultrasonic examination of GR-2-15(OI.) to meet the requirements of ASME Section XI, category R-A, item number R1.16E and BWRVIP-75A, NU0313.</p> <p>This exam was performed using equipment, procedures and personnel qualified in accordance with ASME Section XI, Appendix VIII as amended by 10CFR50.55a final rule.</p> <p>The component examined was a SS Structural Weld Overlay (SWOL) of a 12" diameter SS pipe branch connection to a 22" piping header.</p> <p>There were scan limitations associated with the SWOL geometry (the SWOL has a non-standard profile).</p> <p>There were no signals associated with flaw growth into the upper 25% of the exam volume.</p> <p>A 60° RI was used for scan directions 3 and 4 (axial directions). A 45° RI was used for scan directions 3, 4, 5 and 6 (circumferential directions).</p> <p>10CFR50.55a qualified coverage obtained was 76%. ASME Section XI Code coverage was 76%</p>					
RESOLUTION BY: <i>Matt Welch</i>		REVIEWED BY: <i>Peter [unclear]</i>		ANI: <i>Carl Flood</i>	
LEVEL: <i>III</i> DATE: <i>3/15/07</i>		LEVEL: <i>II</i> DATE: <i>3/15/07</i>		DATE: <i>4/18/07</i>	
				PG. <i>1</i> OF <i>9</i>	

TENNESSEE VALLEY AUTHORITY

MANUAL ULTRASONIC PIPING EXAMINATION DATA SHEET

REPORT NO. R- R115 000817

PROJECT: BFN UNIT: UZC14
SYSTEM: RECIRC
WELD I.D.: GR-2-15(DL)
CONFIG: SWOL TO: PIPE

EXAMINATION DATE: 3/16/07 3/15/07 3/11/07
START TIME: 2245 END TIME: 0300
EXAM SURFACE: ID OD
MATERIAL TYPE: CS SS CSCL CCSS
SURFACE TEMP: 76°F F PYRO NO: 558272

PROCEDURE: N-UT- 66 REV.: 5 TC: N/A
W6 REFERENCE: 3.6" U/S FROM SWOL WELD TOE
L0 REFERENCE: 0/S RADIUS OF RECIRC HEADER

Table with calibration data: CALIBRATION SHEET NO. C- C- EXAMINATION ANGLE 45 DEG 60 DEG CIRC. SCAN SENSITIVITY 54.2 dB 71.2 dB AXIAL SCAN SENSITIVITY 54.2 dB 71.2 dB

Main data table with columns: IND. NO., L (In) FROM REF., AT MAX AMP, MAX AMP %DAC, EXAM NO. 3-14, NOM. ANG., NRI, INDICATION INFORMATION: TYPE, DAMPING, ETC.

REMARKS/LIMITATIONS: NONE

EXAMINER: [Signature] LEVEL: III
EXAMINER: [Signature] LEVEL: N/A
REVIEWED BY: [Signature] LEVEL: II DATE: 3/15/07
ANIR [Signature] DATE: 4/18/07 PAGE 2 OF 9

000218

TENNESSEE VALLEY AUTHORITY		DIGITAL ULTRASONIC CALIBRATION DATA SHEET				REPORT NUMBER: R115																	
PROJECT: BFN UNIT 2		CYCLE: 14		CALIBRATION DATE: 3/11/07																			
PROC.: N-UT-66		REV: 5 TC: N/A		CALIBRATION BLOCK NO.: BF133 TEMP: 70 °F																			
INSTR. MFG: Krautkrumm		DUE DATE: 8/21/07		SIMULATOR BLOCK NO.: 79-7620																			
MODEL/TYPE: USN 60		M & TE NO.: E36307		THERMOMETER S/N: 558272 DUE DATE: 6/7/07																			
TRANSDUCER MFG: MEGASONICS		COUPLANT		BATCH: 05325																			
ELEMENTS: 2 SHAPE: RET		S/N: U0104		EXAM TYPE: SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RL <input checked="" type="checkbox"/>																			
SIZE: 2(10x10) FREQ: 2 MHz		CONTOUR: FLAT		ANGLE VERIFICATION																			
FOCUS: 30mm		CABLE TYPE: RG174		LENGTH: 72 #CNT: 0		BLOCK TYPE: Rompus		S/N: 83-3236															
DAC		NOMINAL ANGLE: 45		ACTUAL ANGLE: 45																			
<p>100 80 60 40 20 0</p> <p>1.0</p> <p>REF *</p> <p>DISPLAY WIDTH: inches 2.0" DEPTH</p>		INSTRUMENT SETTINGS		REFLECTOR		REFERENCE		MEMORY															
		SCAN DIRECT.		NTCH		SDH		SENSITIVITY		NUMBER													
		AXIAL		<input type="checkbox"/>		<input checked="" type="checkbox"/>		46.2 dB		104AXCR													
		CIRC		<input type="checkbox"/>		<input checked="" type="checkbox"/>		46.2 dB		104AXCR													
		RANGE: 2.84		*INST. FREQ.: 2 Mhz		PROBE DELAY: 6.6703		*RECTIFY: FULL WAVE		VELOCITY: .2369													
		*ENERGY: HIGH		*DISPLAY START: IP		*DAMPING: 1K ohm		DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK		*RECTIFY: ON <input type="checkbox"/> OFF													
		*PRI MODE: AUTOHIGH		TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>		INITIAL TIME: 2150		FINAL TIME: 0305		VERIFICATION TIMES													
		CALIBRATION TIMES		1) N/A		2)		3)		4)													
		AMPLITUDE: 8590		METAL PATH: 1.11		5)		6)		7)													
		GAIN: dB 46.2		8)		9) N/A		10)		11)													
<p>* PDI QUALIFIED INSTRUMENT SETTINGS: VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!</p>																							
LINEARITY CHECK																							
VERTICAL		SIGNAL 1		100		90		80		70		60		50		40		30		20		10	
		SIGNAL 2		50		45		40		35		30		25		20		15		10		5	
ATTENUATOR		GAIN		SET		-6 dB		-12 dB		SET		+12		SET		+6							
		AMP		80		32-48		16-24		20		64-96		40		64-96							
				42		42				78				80									
COMMENTS:					WELDS/ITEMS EXAMINED:					GR-2-15(OL)													
EXAMINER: <i>Walter Wilch</i>					EXAMINER: N/A					REVIEWER: <i>Robert Adams</i>					ANIL: <i>Paul Hand</i>								
LEVEL: <i>III</i>					LEVEL:					DATE: 3/15/07					DATE: 4/18/07								
										LEVEL: <i>II</i>					PG. 3 OF 9								

000319

TENNESSEE VALLEY AUTHORITY		DIGITAL ULTRASONIC CALIBRATION DATA SHEET		REPORT NUMBER: R115							
PROJECT: <i>BFN</i> UNIT <i>2</i> CYCLE: <i>14</i>		CALIBRATION DATE: <i>3/11/07</i>		CALIBRATION BLOCK NO.: <i>BE133</i> TEMP <i>70</i> °F							
PROC.: <i>N-UT-66</i> REV: <i>5</i> TC: <i>N/A</i>		SIMULATOR BLOCK NO.: <i>79-7620</i>		THERMOMETER S/N: <i>558272</i> DUE DATE: <i>6/7/07</i>							
INSTR. MFG: <i>Kraut Kraus</i> DUE DATE: <i>8/21/07</i>		COUPLANT: <i>Ultracou II</i> BATCH: <i>05325</i>		EXAM TYPE: SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RL <input checked="" type="checkbox"/>							
MODEL/TYPE: <i>USN 60</i> M & TE NO.: <i>E36307</i>		ANGLE VERIFICATION		BLOCK TYPE: <i>Rompus</i> S/N: <i>83-3236</i>							
TRANSducer MFG: <i>MEGASONICS</i>		NOMINAL ANGLE: <i>60</i>		ACTUAL ANGLE: <i>60</i>							
ELEMENTS: <i>2</i> SHAPE: <i>RET</i>		INSTRUMENT SETTINGS		REFLECTOR							
S/N <i>U0105</i> SIZE: <i>2(10x18)</i> FREQ: <i>2</i> MHz		SCAN DIRECT		REFERENCE SENSITIVITY							
CONTOUR: <i>FLAT</i> FOCUS: <i>40mm</i>		NTCH <input type="checkbox"/>		MEMORY NUMBER							
CABLE TYPE: <i>R4174</i> LENGTH: <i>72</i> #CNT: <i>Ø</i>		SDH <input checked="" type="checkbox"/>		<i>63.2</i> dB							
DAC		CIRC <input type="checkbox"/>		<i>10SAX</i>							
		RANGE: <i>4006</i>		*INST. FREQ.: <i>2</i> Mhz							
DISPLAY WIDTH: inches <i>2.0</i> DEPTH		PROBE DELAY: <i>7.2103</i>		*RECTIFY: <i>FULLWAVE</i>							
		VELOCITY: <i>.2369</i>		DUAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF							
		DISPLAY DELAY: <i>0.0</i>		*REJECT: <i>0</i> %							
		*ENERGY: <i>HIGH</i>		*DISPLAY START: <i>IP</i>							
		*DAMPING: <i>1K ohm</i>		DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK							
		*PRF MODE: <i>AUTOHIGH</i>		TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>							
REF. REFLECTOR: <i>SDH</i> GAIN: dB <i>52.2</i>		CALIBRATION TIMES		INITIAL TIME: <i>2200</i> FINAL TIME: <i>0310</i>							
AMPLITUDE: <i>80%</i> METAL PATH: <i>1.5</i>		VERIFICATION TIMES		1) <i>N/A</i> 2) <i>---</i> 3) <i>---</i> 4) <i>---</i> 5) <i>---</i> 6) <i>---</i> 7) <i>---</i> 8) <i>---</i> 9) <i>N/A</i>							
* PDI QUALIFIED INSTRUMENT SETTINGS:		VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!		<i>u-3/11/07</i>							
LINEARITY CHECK											
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20	10
	SIGNAL 2	50	<i>45</i>	<i>40</i>	<i>35</i>	<i>30</i>	<i>25</i>	<i>20</i>	<i>15</i>	<i>10</i>	<i>5</i>
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6			
	AMP	80	32-48	16-24	20	64-96	40	64-96			
			<i>42</i>	<i>42</i>	<i>78</i>		<i>80</i>				
COMMENTS:				WELDS/ITEMS EXAMINED:				<i>GR-2-15(OL)</i>			
EXAMINER: <i>Walter Welch</i>		EXAMINER: <i>N/A</i>		REVIEWER: <i>[Signature]</i>		ANH: <i>[Signature]</i>		DATE: <i>4/18/07</i>		PG. <i>4</i> OF <i>9</i>	
LEVEL: <i>III</i>		LEVEL:		LEVEL: <i>II</i>		DATE: <i>3/15/07</i>					

000320

TENNESSEE VALLEY AUTHORITY		DIGITAL ULTRASONIC CALIBRATION DATA SHEET				REPORT NUMBER: R115																																																										
PROJECT: BFN UNIT 2		CYCLE: 14		CALIBRATION DATE: 3/11/07																																																												
PROC.: N-UT-66		REV: 5 TC: N/A		CALIBRATION BLOCK NO.: BE133 TEMP: 70 °F																																																												
INSTR. MFG: Krautkramer		DUE DATE: 8/21/07		SIMULATOR BLOCK NO: 79-7620																																																												
MODEL/TYPE: USN 60		M & T# NO.: E36307		THERMOMETER S/N: 558272 DUE DATE: 6/7/07																																																												
TRANSDUCER MFG: MEGASONICS		COUPLANT: Ultracell II		BATCH: 05325																																																												
ELEMENTS: 2 SHAPE: RET		S/N: U0106		SIZE: 2(10x18)		FREQ: 2 MHz		EXAM TYPE: SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RI <input checked="" type="checkbox"/>																																																								
CONTOUR: FLAT		FOCUS: F520mm		ANGLE VERIFICATION																																																												
CABLE TYPE: R4174		LENGTH: 72		#CNT: 0		BLOCK TYPE: Rompus		S/N: 83-3236																																																								
DAC		NOMINAL ANGLE: 60		ACTUAL ANGLE: 60																																																												
		INSTRUMENT SETTINGS		<table border="1"> <tr> <th colspan="3">REFLECTOR</th> <th>REFERENCE SENSITIVITY</th> <th>MEMORY NUMBER</th> </tr> <tr> <td>SCAN DIRECT</td> <td>NTCH</td> <td>SDH</td> <td>53.2 dB</td> <td>106 AX</td> </tr> <tr> <td>AXIAL</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td>N/A dB</td> <td>N/A</td> </tr> <tr> <td>CIRC</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> <td></td> </tr> <tr> <td colspan="3">RANGE: 3.456</td> <td colspan="2">*INST. FREQ: 2 Mhz</td> </tr> <tr> <td colspan="3">PROBE DELAY: 5.2806</td> <td colspan="2">*RECTIFY: FULLWAVE</td> </tr> <tr> <td colspan="3">VELOCITY: 2369</td> <td colspan="2">DUAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF</td> </tr> <tr> <td colspan="3">DISPLAY DELAY: 1.505</td> <td colspan="2">*REJECT: 0 %</td> </tr> <tr> <td colspan="3">*ENERGY: HIGH</td> <td colspan="2">*DISPLAY START: IP</td> </tr> <tr> <td colspan="3">*DAMPING: 1K ohm</td> <td colspan="2">DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK</td> </tr> <tr> <td colspan="3">*PRF MODE: AUTOHIGH</td> <td colspan="2">TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/></td> </tr> </table>						REFLECTOR			REFERENCE SENSITIVITY	MEMORY NUMBER	SCAN DIRECT	NTCH	SDH	53.2 dB	106 AX	AXIAL	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A dB	N/A	CIRC	<input type="checkbox"/>	<input type="checkbox"/>			RANGE: 3.456			*INST. FREQ: 2 Mhz		PROBE DELAY: 5.2806			*RECTIFY: FULLWAVE		VELOCITY: 2369			DUAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF		DISPLAY DELAY: 1.505			*REJECT: 0 %		*ENERGY: HIGH			*DISPLAY START: IP		*DAMPING: 1K ohm			DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK		*PRF MODE: AUTOHIGH			TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>	
REFLECTOR			REFERENCE SENSITIVITY	MEMORY NUMBER																																																												
SCAN DIRECT	NTCH	SDH	53.2 dB	106 AX																																																												
AXIAL	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A dB	N/A																																																												
CIRC	<input type="checkbox"/>	<input type="checkbox"/>																																																														
RANGE: 3.456			*INST. FREQ: 2 Mhz																																																													
PROBE DELAY: 5.2806			*RECTIFY: FULLWAVE																																																													
VELOCITY: 2369			DUAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF																																																													
DISPLAY DELAY: 1.505			*REJECT: 0 %																																																													
*ENERGY: HIGH			*DISPLAY START: IP																																																													
*DAMPING: 1K ohm			DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK																																																													
*PRF MODE: AUTOHIGH			TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>																																																													
REF. REFLECTOR: SD4		GAIN: dB 53.2		CALIBRATION TIMES																																																												
AMPLITUDE: 45%		METAL PATH: 1.5		INITIAL TIME: 2220		FINAL TIME: 0315																																																										
VERIFICATION TIMES		1) N/A		2) N/A		3) N/A		4) N/A																																																								
<p>* PDI QUALIFIED INSTRUMENT SETTINGS: VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!</p>																																																																
LINEARITY CHECK																																																																
VERTICAL	SIGNAL 1		100	90	80	70	60	50	40	30	20	10																																																				
	SIGNAL 2		50	45	40	35	30	25	20	15	10	5																																																				
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6																																																								
	AMP	80	32-48	16-24	20	64-96	40	64-96																																																								
			42	42		78		80																																																								
COMMENTS:					WELDS/ITEMS EXAMINED:																																																											
					GR-2-15 (OL)																																																											
EXAMINER: <i>Mark Welch</i>		EXAMINER: N/A		REVIEWER: <i>Patricia...</i>		ANII: <i>Lul...</i>		DATE: 4/18/07																																																								
LEVEL: III		LEVEL:		LEVEL: IV		DATE: 3/15/07		PG. 5 OF 9																																																								

GR-2-15 (OL)

ISI exam, RL Transducers:

Angle	Size	Freq	Focus	Scan Dir	Cntr.	T1	Mfg	Notes
45	2(10 X 18)	2	FS-30mm	Ax/Circ	FLAT	Y	MGS	U0104, DS side ax scan, US and DS circ scans
60	2(10 X 18)	2	FS-40mm	Ax	FLAT	Y	MGS	U0105, US side ax scan
60	2(10 X 18)	2	FS-20mm	Ax	FLAT	Y	MGS	U0106, DS side ax scan

PS 6/9

C00321

R115

TVA

Office of Nuclear Power

PROJECT: BEN

SYSTEM: RECIRC

REPORT NO.:

Unit: U2C14

WELD NO.: GR-2-15(02)

R115


REQUIRED EXAM VOLUME = 74.1 cubic inches

$$[(.82 \times 2.1) - (.5 \times .24)] \times 44.6 = \text{REV}$$

$$[1.722 - .06] \times 44.6 = \text{REV}$$

$$1.662 \times 44.6 = \text{REV}$$

$$74.1 \text{ cu.in} = \text{REV}$$



$$\text{ACHIEVED EXAM VOLUME} = (81.52 + 70.44) \div 2 = 75.98 = 76\%$$

AXIAL SCANS = 81.52%

CIRC SCANS = 70.44%

CIRCUMFERENCE = 44.6"

000322

BY: Walter Welch

LEVEL: III

DATE: 3/15/07

PAGE 7 OF 9

TVA

Office of Nuclear Power

PROJECT: BEN

SYSTEM: RECIRC

REPORT NO.:

Unit: U2C14

WELD NO.: GR-2-15(02)

R115


REQUIRED EXAM VOLUME = 74.1 cubic inches

$$[(.82 \times 2.1) - (.5 \times .24)] \times 44.6 = \text{REV}$$

$$[1.722 - .06] \times 44.6 = \text{REV}$$

$$1.662 \times 44.6 = \text{REV}$$

$$74.1 \text{ cu.in} = \text{REV.}$$



CIRCUMFERENCE = 44.6"

000323

BY: Walter Welch

LEVEL: III

DATE: 3/15/07

PAGE 8 OF 9

TVA

Office of Nuclear Power

PROJECT: BFN

SYSTEM: RECIRC

REPORT NO.:

Unit: U2C14

WELD NO.: GR-2-15(02)

R115


REQUIRED EXAM VOLUME = 74.1 cubic inches

$$[(.82 \times 2.1) - (.5 \times .24)] \times 44.6 = \text{REV}$$

$$[1.722 - .06] \times 44.6 = \text{REV}$$

$$1.662 \times 44.6 = \text{REV}$$

$$74.1 \text{ cu.in} = \text{REV}$$



CIRCUMFERENCE = 44.6"

000324

BY: Walt Welch

LEVEL: 115

DATE: 3/15/07

PAGE 9 OF 9

Examination Report No. R-118

Weld No. RCRD-2-50

000333

TENNESSEE VALLEY AUTHORITY		EXAMINATION SUMMARY AND RESOLUTION DATA SHEET		REPORT NUMBER: <i>R118</i>	
PROJECT: BFN UNIT: 2		CYCLE: 14		COMPONENT ID: RCRD-2-50	
EXAMINATION METHOD				SYSTEM: RWGUS ISI DWG. NO. 2-ISI-0272-C-01	
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CODE CLASS: NA CATEGORY: R-A	
PROCEDURE: N-UT-82		REV: 2	TC: NA	CONFIG.:	C/S Pipe TO S/S Valve
EXAMINER: <i>Wade Hollaway</i>		EXAMINER: <i>N/A</i>		EXAMINER: <i>N/A</i>	
LEVEL: <i>II</i>		LEVEL:		LEVEL:	

This report contains the data associated with the manual ultrasonic examination of RCRD-2-50 to meet the requirements of ASME Section XI, category R-A, item number R1.16D, exreq A14-03 and BWRVIP-75A, NU0313, exreq B12-02 for expanded scope examinations.

This exam was performed using equipment, procedures and personnel qualified in accordance with ASME Section XI, Appendix VIII as amended by 10CFR50.55a final rule.

The component examined was a CS pipe to a forged SS valve piping weld, 4.0" nominal diameter, having single sided access.

A 45° shear was used for scan directions 3, 5, and 6.
 A 60° shear was used for scan direction 3.
 A 45° RL was used for scan direction 3.
 A 60° RL was used for scan direction 3.
 A 70° RL was used for scan direction 3.
 A 41° RL was used for scan directions 5 and 6.
42° mode 5-15-07

Scan direction 4 was not performed due to weld joint configuration (could not scan on the valve body).
 Scan direction 3 was limited for the 45° RL scan due the elbow intradose from 4.1" to 10.1".
 Scan directions 5 and 6 for the 41° RL could not be performed from the valve body due to taper.

Axial scan coverage achieved for the 45° and 60° RL wave modes was 57.5%.
 Circumferential scan coverage achieved for the 41° RL wave modes was 67.9%.
 Combined shear wave 45° and 60° axial and 45° circumferential coverage was 35%.

The reported achieved qualified coverage is 62.7%.

No recordable indications. Wade Welch 4/18/06

RESOLUTION BY: <i>Wade Hollaway</i>	REVIEWED BY: <i>Wade Welch</i>	ANII: <i>Sub Staff</i>
LEVEL: <i>II</i> DATE: <i>3/1/07</i>	LEVEL: <i>II</i> DATE: <i>3/16/07</i>	DATE: <i>5/16/07</i>
		PG. <i>1</i> OF <i>16</i>


000334

TVA	WALL THICKNESS PROFILE SHEET	REPORT NO: <i>R118</i>
------------	---	---------------------------


PROJECT: <u>BFN</u>	WELD NO: <u>RCRD-2-50</u>
UNIT: <u>2</u>	SYSTEM: <u>CRD 085</u>

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	.58			
2	.46			
3	.48			
4	N/A			
5	N/A			



CROWN HEIGHT: <u>ISI PREP</u>	DIAMETER: <u>4.0"</u>
CROWN WIDTH: <u>0.4"</u>	WELD LENGTH: <u>14.15"</u>



COULD NOT SCAN 6.0" OF WELD IN THE ELBOW INNER RADIUS WITH THE RL TRANSDUCERS DUE TO BRIDGING. THE SHEAR WAVE TRANSDUCERS WERE USED FOR THE ENTIRE CIRCUMFERENCE OF THE WELD.

EXAMINER: <u>[Signature]</u>	REVIEWED BY: <u>[Signature]</u>	ANII: <u>[Signature]</u>
LEVEL: <u>II</u>	LEVEL: <u>III</u>	DATE: <u>3/16/07</u>
DATE: <u>4/16/07</u>		DATE: <u>5/16/07</u>
		PAGE <u>2</u> OF <u>16</u>

000395

TVA
Office of Nuclear Power

PROJECT: BFN SYSTEM: RWCUS
Unit: U2C14 WELD NO.: RCRD-2-50



REPORT NO.:
R118

REQUIRED EXAM VOLUME = $(.15 \times 1.0) \times 14.15 = \underline{2.12}$ cubic inches

REQUIRED EXAM VOLUME (RL) = 2.12 cubic inches

REQUIRED EXAM VOLUME (SHEAR) = $[(.2 \times 1.0) \div 2] \times 14.15 = .015 \times 14.15 = .212$ cubic inches

* $2.12 - .212 = \underline{1.91}$ cubic inches




SCAN LIMITATION
DUE TO ELBOW (ASTRADOSE)
R/L TRANSDUCERS ONLY
4.075" - 10.075"

BY: Walt Welch LEVEL: III DATE: 3/16/07 PAGE 3 OF 16

TENNESSEE VALLEY
AUTHORITY

MANUAL ULTRASONIC
PIPING EXAMINATION
DATA SHEET

REPORT NUMBER
R118

PROJECT: BFN UNIT/CYCLE 2114
SYSTEM RWCUS
WELD I.D.: RCRD-2-50
CONFIG.: EL TO VLV
FLOW 

EXAMINATION DATE 3/11/07
START TIME: 1610 END TIME: 1625
EXAM SURFACE ID OD
MATERIAL TYPE: CS SS CSCL CCSS
SURFACE TEMP. 85° F PYRO NO. 562774

PROCEDURE: N-UT-82 REV: 2 TC: N/A
W₆ REFERENCE: WELD CENTERLINE
L₀ REFERENCE: TOP DEAD CENTER

EXAMINATION ANGLE 70°_{SN} DEG. 60°_{SN} DEG.
AXIAL SCAN SENSITIVITY 64.5 dB 51.0 dB
CIRC. SCAN SENSITIVITY N/A dB N/A dB

IND NO.	L (in) FROM REF.			AT MAX AMP			MAX AMP % DAC	EXAM NO. 3-14	NOM. ANG.	NRI	INDICATION INFORMATION: TYPE, DAMPING, ETC.
	L1	L Max	L2	W MAX	MP MAX	D MAX					
								3	70°	<input checked="" type="checkbox"/>	NO RELEVANT IND. NOTED
								3	60°	<input checked="" type="checkbox"/>	NO RELEVANT IND. NOTED
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	

REMARKS/LIMITATIONS THIS IS A BEST EFFORT EXAMINATION OF BI-METALIC WELD CONSISTING OF A CARBON STEEL ELBOW TO STAINLESS STEEL VALVE.
ROOT GEOMETRY WAS SEEN AT VARYING AMP. 360°


EXAMINER: [Signature] LEVEL: II ANI: [Signature]
EXAMINER: N/A LEVEL: _____ DATE 5/10/07
REVIEWED BY: [Signature] LEVEL: III DATE 3/16/07 PAGE 4 OF 16

TENNESSEE VALLEY
AUTHORITY

MANUAL ULTRASONIC
PIPING EXAMINATION
DATA SHEET

REPORT NUMBER

R118

PROJECT: BFN UNIT/CYCLE 2114
 SYSTEM RWCUS
 WELD ID.: RCRD-2-50
 CONFIG.: EL TO VLV
 FLOW 

EXAMINATION DATE 3/11/07
 START TIME: 1638 END TIME: 1642
 EXAM SURFACE ID OD
 MATERIAL TYPE: CS SS CSCL CCSS
 SURFACE TEMP. 85°F PYRO NO. 562774

PROCEDURE: N-UT-82 REV: 2 TC: N/A
 W_o REFERENCE: WELD CENTERLINE
 L_o REFERENCE: TOP DEAD CENTER

EXAMINATION ANGLE 60°RL DEG. 70°RL DEG.
 AXIAL SCAN SENSITIVITY 56.0 dB 65.5 dB
 CIRC. SCAN SENSITIVITY N/A dB N/A dB

IND NO.	L (in) FROM REF.			AT MAX AMP			MAX AMP % DAC	EXAM NO. 3-14	NOM. ANG.	NRI	INDICATION INFORMATION: TYPE, DAMPING, ETC.
	L1	L Max	L2	W MAX	MP MAX	D MAX					
								3	60°RL	<input checked="" type="checkbox"/>	
								3	70°RL	<input checked="" type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	

REMARKS/LIMITATIONS SCANNED AT REF LEVEL DUE TO SIGNAL TO NOISE RATIO

EXAMINER: Chad Kelley LEVEL: II
 EXAMINER: N/A LEVEL: _____
 REVIEWED BY: Mark Walsh LEVEL: III DATE 3/16/07

ANI: San O'Neal
 DATE 5/16/07
 PAGE 5 OF 16


000339

DIGITAL ULTRASONIC CALIBRATION DATA SHEET

TENNESSEE VALLEY AUTHORITY

REPORT NUMBER: R118

PROJECT: BFN UNIT 2	CYCLE: 14	CALIBRATION DATE: 3/11/07
PROC.: N-UT-82	REV: 2 TC: N/A	CALIBRATION BLOCK NO.: BF-131 TEMP: 72. °F
INSTR. MFG: KRAUTKRAMER	DUE DATE: 12/11/07	SIMULATOR BLOCK NO.: N/A
MODEL TYPE: USN-60	M & TE NO.: E34054	THERMOMETER S/N: 562774 DUE DATE: 12/12/07
TRANSDUCER MFG: MEGASONICS	COUPLANT: ULTRAGEL II	BATCH: 05325
ELEMENTS: 2 SHAPE: RECT.	S/N: U0109	SIZE: 2(10x18) FREQ: 2.0 MHz
CONTOUR: 6.0" OD AXIAL	FOCUS: FS=17mm	EXAM TYPE: SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RL <input checked="" type="checkbox"/>
CABLE TYPE: 2(RG-174) LENGTH: 72" #CNT: 0	BLOCK TYPE: DAC	S/N: BF-131
	NOMINAL ANGLE: 60°	ACTUAL ANGLE: 57°



DISPLAY WIDTH inches 2.0"

INSTRUMENT SETTINGS:			
REFLECTOR			REFERENCE
S/N DIRECT	NTCH	SIDE	SENSITIVITY
AXIAL	<input type="checkbox"/>	<input checked="" type="checkbox"/>	56.0 dB
CIRC	<input type="checkbox"/>	<input type="checkbox"/>	N/A dB
RANGE: 2.0"	*INST. FREQ: 2.0 MHz		
PROBE DELAY: 7.1650	*RECTIFY: FULLWAVE		
VELOCITY: .2367	DUAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF		
DISPLAY DELAY: 0.0	*REJECT: 0		
*ENERGY: HIGH	*DISPLAY START:		
*DAMPING: 1K	DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK		
*PRF MODE: AUTOHIGH	TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>		

REF. REFLECTOR: .4" SDH	GAIN: dB 56.0	CALIBRATION TIMES			
AMPLITUDE: 80%	METAL PATH: 0.636	INITIAL TIME: 1438	FINAL TIME: 1640		
VERIFICATION TIMES	1) 1638	2) N/A	3)	4)	5)

* PDI QUALIFIED INSTRUMENT SETTINGS:
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!


LINEARITY CHECK											
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20	10
	SIGNAL 2	50	45	40	35	30	25	20	15	10	5
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6			
	AMP	80	32-48	16-24	20	64-96	40	64-96			
			40	20		80		80			

COMMENTS:	WELDS/ITEMS EXAMINED: RCRD-2-50
-----------	---------------------------------

EXAMINER: <i>Whit Walker</i>	EXAMINER: N/A	REVIEWER: <i>Walter Welch</i>	DATE: 3/16/07
LEVEL: II	LEVEL:	LEVEL: III	DATE: 3/16/07
			PG. 7 OF 10

000340

TENNESSEE VALLEY AUTHORITY		DIGITAL ULTRASONIC CALIBRATION DATA SHEET			REPORT NUMBER: <i>R118</i>							
PROJECT: <i>BFN UNIT 2</i>		CYCLE: <i>14</i>		CALIBRATION DATE: <i>3/11/07</i>								
PROC.: <i>N-UT-82</i>		REV: <i>2</i> TC: <i>N/A</i>		CALIBRATION BLOCK NO.: <i>BF-131</i> TEMP: <i>72.°F</i>								
INSTR. MFG: <i>KRAUTKRAMER</i>		DUE DATE: <i>12/11/07</i>		SIMULATOR BLOCK NO.: <i>N/A</i>								
MODEL/TYPE: <i>USN-60</i>		M & TE NO.: <i>E34054</i>		THERMOMETER S/N: <i>562774</i> DUE DATE: <i>12/12/07</i>								
TRANSducer MFG: <i>MEGASONICS</i>		COUPLANT			BATCH:							
ELEMENTS: <i>2</i> SHAPE: <i>RECT.</i>		<i>ULTRAGEL II</i>			<i>05325</i>							
S/N <i>U0110</i> SIZE: <i>2(10x18)</i>		FREQ: <i>2.0</i> MHz		EXAM TYPE: SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RL <input checked="" type="checkbox"/>								
CONTOUR <i>6" OD AXIAL</i>		FOCUS: <i>F5=28mm</i>		ANGLE VERIFICATION								
CABLE TYPE: <i>2(RG-174)</i>		LENGTH: <i>72"</i>		BLOCK TYPE:		S/N: <i>BF-131</i>						
DAC				NOMINAL ANGLE: <i>70°</i>		ACTUAL ANGLE: <i>67°</i>						
INSTRUMENT SETTINGS												
REFLECTOR			REFERENCE		MEMORY							
SOUND DIRECT			SENSITIVITY		NUMBER							
AXIAL			<i>65.5</i> dB		<i>U0110</i>							
CIRC			<i>N/A</i> dB		<i>N/A</i>							
RANGE:			*INST. FREQ: <i>2.0</i> MHz									
PROBE DELAY:			*RECTIFY: <i>FULLWAVE</i>									
VELOCITY: <i>.2367</i>			DUAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF									
DISPLAY DELAY: <i>0.0</i>			*REJECT: <i>0</i>									
*ENERGY: <i>HIGH</i>			*DISPLAY START: <i>0.0</i>									
*DAMPING: <i>1K</i>			DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK									
*PRF MODE: <i>AUTOHIGH</i>			TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>									
CALIBRATION TIMES												
REF. REFLECTOR: <i>.4" SDH</i>			GAIN: dB <i>65.5</i>		INITIAL TIME: <i>1440</i>							
AMPLITUDE: <i>80%</i>			METAL PATH: <i>.945</i>		FINAL TIME: <i>1642</i>							
VERIFICATION TIMES		<i>1) 1640</i>		<i>2) N/A</i>		<i>3) -</i>						
		<i>4) -</i>		<i>5) -</i>		<i>6) -</i>						
		<i>7) -</i>		<i>8) -</i>		<i>9) -</i>						
* PDI QUALIFIED INSTRUMENT SETTINGS: VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!												
LINEARITY CHECK												
VERTICAL	SIGNAL 1		100	90	80	70	60	50	40	30	20	10
	SIGNAL 2		50	45	40	35	30	25	20	15	10	5
ATTENUATOR	GAIN	SET	-6 dB		-12 dB		SET		+12		SET	
	AMP	<i>80</i>	<i>32-48</i>		<i>16-24</i>		<i>20</i>		<i>64-96</i>		<i>40</i>	
			<i>40</i>		<i>20</i>		<i>80</i>		<i>80</i>			
COMMENTS:				WELDS/ITEMS EXAMINED: <i>RCRD-2-50</i>								
EXAMINER: <i>Wick Holby</i>			EXAMINER: <i>N/A</i>			REVIEWER: <i>Walter Welch</i>			ANI: <i>Jim Flood</i>			
LEVEL: <i>II</i>			LEVEL:			LEVEL: <i>III</i>			DATE: <i>5/16/07</i>			
						DATE: <i>3/16/07</i>			PG. <i>4</i> OF <i>16</i>			



DISPLAY WIDTH inches *2.0*

000341

TENNESSEE VALLEY AUTHORITY		DIGITAL ULTRASONIC CALIBRATION DATA SHEET			REPORT NUMBER: <i>R118</i>						
PROJECT: <i>BFN</i> UNIT <i>2</i> CYCLE: <i>14</i>		CALIBRATION DATE: <i>3/11/07</i>									
PROC.: <i>N-UT-82</i> REV: <i>2</i> TC: <i>N/A</i>		CALIBRATION BLOCK NO.: <i>50-115</i> TEMP: <i>72 F</i>									
INSTR. MFG: <i>KRAUTKRAMER</i> DUE DATE: <i>12/11/07</i>		SIMULATOR BLOCK NO.: <i>92-7616</i>									
MODEL TYPE: <i>USN-60</i> M & TE NO.: <i>E34054</i>		THERMOMETER S/N: <i>562774</i> DUE DATE: <i>12/12/07</i>									
TRANSDUCER MFG: <i>KBA</i>		COUPLANT BATCH:									
ELEMENTS: <i>1</i> SHAPE: <i>ROUND</i>		<i>ULTRAGEL II</i> <i>05325</i>									
S/N <i>0156YP</i> SIZE: <i>0.25</i> FREQ: <i>5.0</i> MHZ		EXAM TYPE: <input checked="" type="checkbox"/> SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RL <input type="checkbox"/>									
CONTOUR: <i>FLAT</i> FOCUS: <i>N/A</i>		ANGLE VERIFICATION									
CABLE TYPE: <i>RG-174</i> LENGTH: <i>72"</i> #CNT: <i>0</i>		BLOCK TYPE: <i>ROMPAS</i> S/N: <i>92-7616</i>									
DAC		NOMINAL ANGLE: <i>45°</i> ACTUAL ANGLE: <i>44°</i>									
<div style="display: flex; align-items: center;"> <div style="margin-right: 10px;">100 80 60 40 20 0</div> <div style="border: 1px solid black; width: 280px; height: 170px; position: relative;"> <div style="position: absolute; top: 10%; left: 60%; transform: translate(-50%, -50%);">.5" NOTCH</div> <div style="position: absolute; top: 45%; left: 15%;">SIM</div> </div> <div style="margin-left: 10px; text-align: center;">A M P L I T U D E</div> </div> <p>DISPLAY WIDTH: inches <i>1.0</i></p>		INSTRUMENT SETTINGS									
		REFLECTOR		REFERENCE	MEMORY						
		SCAN DIRECT:	NTCH	SDH	SENSITIVITY	NUMBER					
		AXIAL	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>28.0</i> dB	<i>RWCU 45</i>					
		CIRC	<input type="checkbox"/>	<input type="checkbox"/>	<i>N/A</i> dB	<i>N/A</i>					
		RANGE: <i>1.0"</i>		*INST. FREQ: <i>5.0</i> MHz							
		PROBE DELAY: <i>3.5750</i>		*RECTIFY: <i>FULL WAVE</i>							
		VELOCITY: <i>0.1270</i>		DUAL <input type="checkbox"/> ON <input checked="" type="checkbox"/> OFF							
		DISPLAY DELAY: <i>0.0</i>		*REJECT: <i>0</i> %							
		*ENERGY: <i>HIGH</i>		*DISPLAY START: <i>IP</i>							
*DAMPING: <i>1K</i>		DET: <input type="checkbox"/> PEAK <input checked="" type="checkbox"/> FLANK									
*PRF MODE: <i>AUTO HIGH</i>		TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>									
REF. REFLECTOR: <i>.5" NOTCH</i> GAIN: dB <i>28.0</i>		CALIBRATION TIMES									
AMPLITUDE: <i>80%</i> METAL PATH: <i>0.692</i>		INITIAL TIME: <i>1425</i>		FINAL TIME: <i>1705</i>							
VERIFICATION TIMES		1) <i>1630</i>	2) <i>N/A</i>	3) _____	4) _____	5) _____					
		6) _____	7) _____	8) _____	9) _____	10) _____					
* PDI QUALIFIED INSTRUMENT SETTINGS: VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!											
LINEARITY CHECK											
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20	10
	SIGNAL 2	50	45	40	35	30	25	20	15	10	5
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6			
	AMP	80	32-48	16-24	20	64-96	40	64-96			
			<i>40</i>	<i>20</i>		<i>80</i>		<i>80</i>			
COMMENTS:				WELDS/ITEMS EXAMINED:							
				<i>RCRD-2-50</i>							
EXAMINER: <i>Wade Holley</i>		EXAMINER: <i>N/A</i>		REVIEWER: <i>Wade Holley</i>		ANI: <i>Wade Holley</i>					
LEVEL: <i>II</i>		LEVEL: _____		LEVEL: <i>III</i> DATE: <i>3/16/07</i>		DATE: <i>3/16/07</i>					
						PG. <i>9</i> OF <i>10</i>					

000342

TENNESSEE VALLEY AUTHORITY		DIGITAL ULTRASONIC CALIBRATION DATA SHEET			REPORT NUMBER: <i>R118</i>																																																																									
PROJECT: <i>BFN UNIT 2</i>		CYCLE: <i>14</i>		CALIBRATION DATE: <i>3/11/07</i>																																																																										
PROC.: <i>N-UT-82</i>		REV: <i>2</i> TC: <i>N/A</i>		CALIBRATION BLOCK NO.: <i>SQ-123</i> TEMP: <i>72 F</i>																																																																										
INSTR. MFG: <i>KRAUTKRAMER</i>		DUE DATE: <i>12/11/07</i>		SIMULATOR BLOCK NO.: <i>92-7616</i>																																																																										
MODEL/TYPE: <i>USN-60</i>		M&TE NO.: <i>E34054</i>		THERMOMETER S/N: <i>562774</i> DUE DATE: <i>12/12/07</i>																																																																										
TRANSDUCER MFG: <i>KBA</i>		COUPLANT			BATCH:																																																																									
ELEMENTS: <i>1</i> SHAPE: <i>ROUND</i>		<i>ULTRAGEL II</i>			<i>05325</i>																																																																									
S/N <i>00X03R</i> SIZE <i>0.375</i> FREQ: <i>1.5</i> MHz		EXAM TYPE: <input checked="" type="checkbox"/> SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> R: <input type="checkbox"/>		ANGLE VERIFICATION																																																																										
CONTOUR: <i>FLAT</i> FOCUS: <i>N/A</i>		BLOCK TYPE: <i>ROMPAS</i> S/N: <i>6026-83</i>																																																																												
CABLE TYPE: <i>RG-174</i> LENGTH: <i>72"</i> #CNT: <i>0</i>		NOMINAL ANGLE: <i>45°</i>		ACTUAL ANGLE: <i>46°</i>																																																																										
DAC		INSTRUMENT SETTINGS																																																																												
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width: 20px;">100</td> <td style="width: 20px;"></td> <td style="width: 20px;"></td> <td style="width: 20px;"></td> <td style="width: 20px;"></td> <td style="width: 20px;"></td> <td style="width: 20px;"></td> <td style="width: 20px;"></td> <td style="width: 20px;"></td> <td style="width: 20px;"></td> <td style="width: 20px;"></td> <td style="width: 20px;"></td> </tr> <tr> <td style="width: 20px;">80</td> <td></td> <td></td> <td></td> <td style="text-align: center;"><i>1.0</i></td> <td style="text-align: center;"><i>*</i></td> <td style="text-align: center;"><i>NOTCH</i></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td style="width: 20px;">60</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td style="width: 20px;">40</td> <td></td> <td></td> <td style="text-align: center;"><i>*</i></td> <td style="text-align: center;"><i>sim</i></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td style="width: 20px;">20</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td style="width: 20px;">0</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>		100												80				<i>1.0</i>	<i>*</i>	<i>NOTCH</i>						60												40			<i>*</i>	<i>sim</i>								20												0												REFLECTOR		REFERENCE		MEMORY
		100																																																																												
		80				<i>1.0</i>	<i>*</i>	<i>NOTCH</i>																																																																						
		60																																																																												
		40			<i>*</i>	<i>sim</i>																																																																								
		20																																																																												
		0																																																																												
		SCAN DIRECT		NTCH	SDH	SENSITIVITY		NUMBER																																																																						
		AXIAL		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>30.0</i> dB		<i>45° P375</i>																																																																						
		CIRC		<input type="checkbox"/>	<input type="checkbox"/>	<i>N/A</i> dB		<i>N/A</i>																																																																						
RANGE: <i>2.0</i>		*INST. FREQ: <i>2.0</i> MHz																																																																												
PROBE DELAY: <i>4.1400</i>		*RECTIFY: <i>FULLWAVE</i>																																																																												
VELOCITY: <i>0.1270</i>		DUAL <input type="checkbox"/> ON <input checked="" type="checkbox"/> OFF																																																																												
DISPLAY DELAY: <i>0.0</i>		*REJECT: <i>0</i> %																																																																												
*ENERGY: <i>HIGH</i>		*DISPLAY START: <i>IP</i>																																																																												
*DAMPING: <i>1K</i>		DET: <input type="checkbox"/> PEAK <input checked="" type="checkbox"/> FLANK																																																																												
*PRF MODE: <i>AUTOHIGH</i>		TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>																																																																												
DISPLAY WIDTH: inches <i>2.0</i>		CALIBRATION TIMES																																																																												
REF. REFLECTOR: <i>1.0" NOTCH</i>		GAIN: dB <i>30.0</i>		INITIAL TIME: <i>1435</i> FINAL TIME: <i>1707</i>																																																																										
AMPLITUDE: <i>80%</i>		METAL PATH: <i>1.42"</i>		VERIFICATION TIMES																																																																										
		1) <i>1635</i>	2) <i>N/A</i>	3) _____	4) _____	5) _____																																																																								
		6) _____	7) _____	8) _____	9) _____	10) _____																																																																								
* PDI QUALIFIED INSTRUMENT SETTINGS:																																																																														
VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!																																																																														
LINEARITY CHECK																																																																														
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20	10																																																																			
	SIGNAL 2	50	45	40	35	30	25	20	15	10	5																																																																			
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6																																																																						
	AMP	80	32-48	16-24	20	64-96	40	64-96																																																																						
			40	20		80		80																																																																						
COMMENTS:				WELDS/ITEMS EXAMINED:																																																																										
				<i>RCRD-2-50</i>																																																																										
EXAMINER: <i>Wanda Holberg</i>		EXAMINER: <i>N/A</i>		REVIEWER: <i>Wanda Holberg</i>		ANI: <i>Sam Flank</i>		DATE: <i>5/16/07</i>																																																																						
LEVEL: <i>II</i>		LEVEL:		LEVEL: <i>III</i> DATE: <i>3/16/07</i>		PG. <i>10</i> OF <i>10</i>																																																																								

000343

TENNESSEE VALLEY AUTHORITY		DIGITAL ULTRASONIC CALIBRATION DATA SHEET				REPORT NUMBER: <i>R118</i>																																																																					
PROJECT: <i>BEN UNIT 2</i>		CYCLE: <i>14</i>		CALIBRATION DATE: <i>3/11/07</i>																																																																							
PROC.: <i>N-UT-82</i>		REV: <i>2</i>		TC: <i>N/A</i>		CALIBRATION BLOCK NO.: <i>SQ-123</i> TEMP: <i>72 °F</i>																																																																					
INSTR. MFG: <i>KRAUTKRAMER</i>				DUE DATE: <i>12/11/07</i>		SIMULATOR BLOCK NO.: <i>92-7616</i>																																																																					
MODEL TYPE: <i>USN-60</i>				M&TE NO.: <i>E34054</i>		THERMOMETER S/N: <i>562774</i> DUE DATE: <i>12/12/07</i>																																																																					
TRANSDUCER MFG: <i>KBA</i>				COUPLANT		BATCH:																																																																					
ELEMENTS: <i>1</i> SHAPE: <i>ROUND</i>				<i>ULTRAGEL II</i>		<i>05325</i>																																																																					
S/N <i>00Y8DV</i> SIZE: <i>0.25</i>				FREQ: <i>2.25</i> MHz		EXAM TYPE: SHEAR <input checked="" type="checkbox"/>		LONG <input type="checkbox"/> RL <input type="checkbox"/>																																																																			
CONTOUR: <i>FLAT</i>				FOCUS: <i>N/A</i>		ANGLE VERIFICATION																																																																					
CABLE TYPE: <i>RG-174</i> LENGTH: <i>72</i>				#CNT: <i>0</i>		BLOCK TYPE: <i>ROMPAS</i>		S/N: <i>92-7616</i>																																																																			
DAC				NOMINAL ANGLE: <i>70°</i>		ACTUAL ANGLE: <i>67.5°</i>																																																																					
<div style="display: flex; align-items: center;"> <table border="1" style="border-collapse: collapse; text-align: center;"> <tr><td>100</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>80</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>60</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>40</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>20</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>0</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </table> <div style="margin-left: 10px;"> <p>A M P L I T U D E</p> </div> </div> <p style="margin-top: 10px;">* <i>5" NOTCH</i></p> <p style="margin-top: 10px;">* <i>SIM @ 52.5</i></p> <p style="margin-top: 10px;">DISPLAY WIDTH: inches <i>2.0</i></p>				100											80											60											40											20											0											INSTRUMENT SETTINGS					
				100																																																																							
				80																																																																							
				60																																																																							
				40																																																																							
				20																																																																							
				0																																																																							
				REFLECTOR		REFERENCE		MEMORY																																																																			
				SCAN DIRECT	NTCH	SDH	SENSITIVITY		NUMBER																																																																		
				AXIAL	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>58.5</i> dB		<i>70°-2P25</i>																																																																		
CIRC	<input type="checkbox"/>	<input type="checkbox"/>	<i>N/A</i> dB		<i>N/A</i>																																																																						
RANGE: <i>2.0</i>		*INST. FREQ: <i>2.0</i> MHz																																																																									
PROBE DELAY: <i>6.4403</i>		*RECTIFY: <i>FULLWAVE</i>																																																																									
VELOCITY: <i>0.1270</i>		DUAL <input type="checkbox"/> ON <input checked="" type="checkbox"/> OFF																																																																									
DISPLAY DELAY: <i>0.0</i>		*REJECT: <i>0</i> %																																																																									
*ENERGY: <i>HIGH</i>		*DISPLAY START: <i>IP</i>																																																																									
*DAMPING: <i>1K</i>		DET: <input type="checkbox"/> PEAK <input checked="" type="checkbox"/> FLANK																																																																									
*PRF MODE: <i>AUTO HIGH</i>		TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>																																																																									
REF. REFLECTOR: <i>0.5" NOTCH</i>		GAIN: dB <i>58.5</i>		CALIBRATION TIMES																																																																							
AMPLITUDE: <i>80%</i>		METAL PATH: <i>1.250</i>		INITIAL TIME: <i>1415</i>		FINAL TIME: <i>1710</i>																																																																					
VERIFICATION TIMES		<i>1) 1610</i>	<i>2) —</i>	<i>3) —</i>	<i>4) —</i>	<i>5) —</i>	<i>6) —</i>	<i>7) —</i>	<i>8) —</i>	<i>9) —</i>																																																																	
* PDI QUALIFIED INSTRUMENT SETTINGS: VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!																																																																											
LINEARITY CHECK																																																																											
VERTICAL	SIGNAL 1		100	90	80	70	60	50	40	30	20	10																																																															
	SIGNAL 2		50	45	40	35	30	25	20	15	10	5																																																															
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6																																																																			
	AMP	80	32-48	16-24	20	64-96	40	64-96																																																																			
			40	20	80			80																																																																			
COMMENTS:					WELDS/ITEMS EXAMINED:																																																																						
					<i>RCRD-2-50</i>																																																																						
EXAMINER: <i>Wade Helling</i>			EXAMINER: <i>N/A</i>			REVIEWER: <i>Wade Helling</i>			ANI: <i>La Stue</i>																																																																		
LEVEL: <i>II</i>			LEVEL:			LEVEL: <i>III</i> DATE: <i>3/16/07</i>			DATE: <i>3/16/07</i>																																																																		
									PG. <i>11</i> OF <i>10</i>																																																																		

TENNESSEE VALLEY AUTHORITY	MANUAL ULTRASONIC PIPING EXAMINATION DATA SHEET	REPORT NUMBER <u>R118</u>
---------------------------------------	--	-------------------------------------

PROJECT: BFN UNIT/CYCLE 2114
 SYSTEM RWCUS
 WELD I.D.: RCRD-2-50
 CONFIG.: EL TO VLV
 FLOW
 PROCEDURE: N-UT-S2 REV: 2 TC: N/A
 W_o REFERENCE: WELD CENTERLINE
 L_o REFERENCE: TOP DEAD CENTER

EXAMINATION DATE 3/11/07
 START TIME: 1642 END TIME: 1648
 EXAM SURFACE ID OD
 MATERIAL TYPE: CS SS CSCL CCSS
 SURFACE TEMP. 85° PYRO NO. 562774
 EXAMINATION ANGLE 45° RL DEG. 42° CCW DEG.
 AXIAL SCAN SENSITIVITY 59.5 dB
 CIRC. SCAN SENSITIVITY dB 57.0 dB

IND NO.	L (in) FROM REF.			AT MAX AMP			MAX AMP % DAC	EXAM NO. 3-14	NOM. ANG.	NRI	INDICATION INFORMATION: TYPE, DAMPING, ETC.
	L1	L Max	L2	W MAX	MP MAX	D MAX					
								3	45° RL	<input checked="" type="checkbox"/>	
								5	42° RL ^{CCW}	<input checked="" type="checkbox"/>	
								6	42° RL ^{CCW}	<input checked="" type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	

N/A

REMARKS/LIMITATIONS 42° RL CIRC SCANS PERFORMED WITH TRANSDUCER ON TOP OF WELD CROWN.

EXAMINER: <u>Jack Kelley</u> LEVEL: <u>II</u>	ANII: <u>Lee Ford</u>
EXAMINER: <u>N/A</u> LEVEL: <u></u>	DATE: <u>3/16/07</u>
REVIEWED BY: <u>Mark Welch</u> LEVEL: <u>III</u> DATE: <u>3/16/07</u>	PAGE: <u>13</u> OF <u>16</u>


000346

TENNESSEE VALLEY
AUTHORITY

DIGITAL ULTRASONIC
CALIBRATION
DATA SHEET

REPORT NUMBER:
R118

PROJECT: <i>BFN UNIT 2</i>	CYCLE: <i>14</i>	CALIBRATION DATE: <i>3/11/07</i>
PROC.: <i>N-UT-82</i>	REV: <i>2</i> TC:	CALIBRATION BLOCK NO.: <i>BF-131</i> TEMP: <i>72.1° F</i>
INSTR. MFG: <i>KRAUTKRAMER</i>	DUE DATE: <i>12/11/07</i>	SIMULATOR BLOCK NO.: <i>N/A</i>
MODEL TYPE: <i>USN-60</i>	M & TE NO.: <i>E34054</i>	THERMOMETER S/N: <i>562774</i> DUE DATE: <i>12/12/07</i>
TRANSDUCER MFG: <i>MEGASONICS</i>		COUPLANT BATCH:
ELEMENTS: <i>2</i> SHAPE: <i>RECT</i>		<i>ULTRAGEL II</i> <i>05325</i>
S/N <i>U0111</i> SIZE: <i>2(10x18)</i>	FREQ: <i>2.0</i> MHz	EXAM TYPE: SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RL <input checked="" type="checkbox"/>
CONTOUR: <i>6" OD AXIAL</i>	FOCUS: <i>FS=20mm</i>	ANGLE VERIFICATION
CABLE TYPE: <i>2(RG-174)</i>	LENGTH: <i>72"</i> #CNT: <i>0</i>	BLOCK TYPE: S/N: <i>BF-131</i>
DAC		NOMINAL ANGLE: <i>45°</i> ACTUAL ANGLE: <i>44.5°</i>



DISPLAY WIDTH: inches *1.0"*

INSTRUMENT SETTINGS				
REFLECTOR			REFERENCE	MEMORY
SCAN DIRECT	NTCH	SDH	SENSITIVITY	NUMBER
AXIAL	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<i>59.5</i> dB	<i>U0111</i>
CIRC	<input type="checkbox"/>	<input type="checkbox"/>	<i>N/A</i> dB	<i>N/A</i>
RANGE	<i>1.0</i>		*INST. FREQ: <i>2.0</i> MHz	
PROBE DELAY:	<i>6.4384</i>		*RECTIFY: <i>FULLWAVE</i>	
VELOCITY:	<i>.2367</i>		DUAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF	
DISPLAY DELAY:	<i>0.0</i>		*REJECT: <i>0</i>	
*ENERGY:	<i>HIGH</i>		*DISPLAY START: <i>0.0</i>	
*DAMPING:	<i>1K</i>		DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK	
*PRF MODE: <i>AUTOHIGH</i>	TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>			

REF. REFLECTOR: <i>.4" SDH</i>	GAIN: dB <i>59.5</i>	CALIBRATION TIMES							
AMPLITUDE: <i>80%</i>	METAL PATH: <i>0.522</i>	INITIAL TIME: <i>1442</i>	FINAL TIME: <i>1644</i>						
VERIFICATION TIMES	1) <i>1642</i>	2) <i>N/A</i>	3) <i></i>	4) <i></i>	5) <i></i>	6) <i></i>	7) <i></i>	8) <i></i>	9) <i></i>

* PDI QUALIFIED INSTRUMENT SETTINGS:
VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2
OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL 1		100	90	80	70	60	50	40	30	20	10
	SIGNAL 2		50	<i>45</i>	<i>40</i>	<i>35</i>	<i>30</i>	<i>25</i>	<i>20</i>	<i>15</i>	<i>10</i>	<i>5</i>
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6				
	AMP	80	32-48	16-24	20	64-96	40	64-96				
			<i>40</i>	<i>20</i>		<i>80</i>		<i>80</i>				


COMMENTS:	WELDS/ITEMS EXAMINED:
	<i>RCRD-2-50</i>

EXAMINER: <i>Wade Holcomb</i>	EXAMINER: <i>N/A</i>	REVIEWER: <i>Wade Holcomb</i>	ANII: <i>Wade Holcomb</i>
LEVEL: <i>II</i>	LEVEL:	DATE: <i>3/16/07</i>	DATE: <i>3/16/07</i>
			PG. <i>14</i> OF <i>16</i>

600347

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER: R118
-------------------------------	---	-------------------------------

PROJECT: BFN UNIT 2	CYCLE: 14	CALIBRATION DATE: 3/11/07
PROC.: N-UT-82	REV: 2 TC:	CALIBRATION BLOCK NO.: BF-132 TEMP. 72.1 F
INSTR. MFG: KRAUTKRAMER	DUE DATE: 12/11/07	SIMULATOR BLOCK NO.: N/A
MODEL/TYPE: USN-60	M & TE NO.: E34054	THERMOMETER S/N: 562774 DUE DATE: 12/12/07
TRANSDUCER MFG: MEGASONICS	COUPLANT BATCH:	
ELEMENTS: 2 SHAPE: RECT.	ULTRAGEL II	
S/N U0271 SIZE: 2(4x12mm) FREQ: 2.0 MHz	EXAM TYPE: <input type="checkbox"/> SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RI <input checked="" type="checkbox"/>	
CONTOUR: 6.0" OD CIRC FOCUS: FS=14mm	ANGLE VERIFICATION	
CABLE TYPE: 2(RG-174) LENGTH: 72" #CNT: 0	BLOCK TYPE:	S/N: BF-132
DAC	NOMINAL ANGLE: 42	ACTUAL ANGLE: 42



DISPLAY WIDTH inches **2.0**

INSTRUMENT SETTINGS				
REFLECTOR			REFERENCE	MEMORY
STAN DIRECT	NTCH	SDI	SENSITIVITY	NUMBER
AXIAL	<input type="checkbox"/>	<input type="checkbox"/>	N/A dB	N/A
CIRC	<input type="checkbox"/>	<input checked="" type="checkbox"/>	57.0 dB	U0271
RANGE: 2.0			*INST. FREQ.: 2.0 MHz	
PROBE DELAY: 5.1888			*RECTIFY: FULLWAVE	
VELOCITY: 2367			DUAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF	
DISPLAY DELAY: 0.0			*REJECT: 0	
*ENERGY: HIGH			*DISPLAY START: 0.0	
*DAMPING: 1K			DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK	
*PRF MODE: AUTOHIGH			TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>	

REF. REFLECTOR: .4" SDH	GAIN: dB 57.0	CALIBRATION TIMES							
AMPLITUDE: 80%	METAL PATH: .662	INITIAL TIME: 14 46	FINAL TIME: 16 46						
VERIFICATION TIMES	1) 16 44	2)	3)	4)	5)	6)	7)	8)	9)

* PDI QUALIFIED INSTRUMENT SETTINGS:
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2
 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK											
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20	10
	SIGNAL 2	50	45	40	35	30	25	20	15	10	5
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6			
	AMP	80	32-43	16-24	20	64-96	40	64-96			
			40	20		80		80			

COMMENTS: **THIS TRANSDUCER HAS A 6" CCLW TAPER** WELDS/ITEMS EXAMINED:
RCRD-2 -50

EXAMINER: <i>Wick Holley</i>	EXAMINER: N/A	REVIEWER: <i>Walter Weller</i>	ANI: <i>Sam Ford</i>
LEVEL: II	LEVEL:	LEVEL: III DATE: 3/16/07	DATE: 5/16/07
		PG. 15 OF 16	

000348

TENNESSEE VALLEY AUTHORITY		DIGITAL ULTRASONIC CALIBRATION DATA SHEET			REPORT NUMBER: <i>R118</i>							
PROJECT: <i>BFN UNIT 2</i>		CYCLE: <i>14</i>		CALIBRATION DATE: <i>3/11/07</i>								
PROC.: <i>N-UT-82</i>		REV: <i>2</i> TC:		CALIBRATION BLOCK NO.: <i>BF-132</i> TEMP: <i>72. F</i>								
INSTR. MFG: <i>KRAUTKRAMER</i>		DUE DATE: <i>12/11/07</i>		SIMULATOR BLOCK NO.: <i>N/A</i>								
MODEL TYPE: <i>USN-60</i>		M & T E NO.: <i>E34054</i>		THERMOMETER S/N: <i>562774</i> DUE DATE: <i>12/12/07</i>								
TRANSDUCER MFG: <i>MEGASONICS</i>		COUPLANT		BATCH:								
ELEMENTS: <i>2</i> SHAPE: <i>RECT</i>		<i>5-15-07</i>		<i>ULTRAGEL II</i>								
S/N <i>U0270</i>		SIZE: <i>2 (4x14mm)</i>		REQ. <i>2.0</i> MHZ								
CONTOUR: <i>6.0" OD CIRC</i>		FOCUS: <i>F3=14mm</i>		ANGLE VERIFICATION								
CABLE TYPE: <i>2 (RG-174)</i>		LENGTH: <i>72"</i>		#CNT: <i>0</i>								
		A M P L I T U D E		BLOCK TYPE:								
				S/N: <i>BF-132</i>								
DAC		NOMINAL ANGLE: <i>42</i>		ACTUAL ANGLE: <i>42</i>								
INSTRUMENT SETTINGS												
REFLECTOR				REFERENCE		MEMORY						
STAN DIRECT		NTCH	SDH	SENSITIVITY		NUMBER						
ANAL.		<input type="checkbox"/>	<input type="checkbox"/>	<i>N/A</i> dB		<i>N/A</i>						
COR.		<input type="checkbox"/>	<input checked="" type="checkbox"/>	<i>57.0</i> dB		<i>U0270</i>						
RANGE: <i>2.0"</i>				*INST. FREQ: <i>2.0</i> MHz								
PROBE DELAY: <i>4.2459</i>				*RECTIFY: <i>FULLWAVE</i>								
VELOCITY: <i>.2367</i>				DUAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF								
DISPLAY DELAY: <i>0.0</i>				*REJECT: <i>0</i>								
*ENERGY: <i>HIGH</i>				*DISPLAY START: <i>0.0</i>								
*DAMPING: <i>1K</i>				DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK								
*PRF MODE: <i>AUTOHIGH</i>				TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>								
DISPLAY WIDTH: inches <i>2.0</i>												
REF. REFLECTOR: <i>.4" SDH</i>		GAIN: dB <i>57.0</i>		CALIBRATION TIMES								
AMPLITUDE: <i>80%</i>		METAL PATH: <i>.662</i>		INITIAL TIME: <i>1448</i>		FINAL TIME: <i>1648</i>						
VERIFICATION TIMES		1) <i>1646</i>	2) <i>---</i>	3) <i>---</i>	4) <i>---</i>	5) <i>---</i>						
		6) <i>---</i>	7) <i>---</i>	8) <i>---</i>	9) <i>---</i>							
* PDI QUALIFIED INSTRUMENT SETTINGS: VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!												
LINEARITY CHECK												
VERTICAL	SIGNAL 1		100	90	80	70	60	50	40	30	20	10
	SIGNAL 2		50	45	40	35	30	25	20	15	10	5
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6				
	AMP	80	32-48	16-24	20	64-96	40	64-96				
			<i>40</i>	<i>20</i>		<i>80</i>		<i>80</i>				
COMMENTS: <i>THIS TRANSDUCER HAS A 6° CW TAPER</i>				WELDS/ITEMS EXAMINED:								
				<i>RCRD-2-50</i>								
EXAMINER: <i>Shelby Holton</i>		EXAMINER: <i>N/A</i>		REVIEWER: <i>Walter Welch</i>		ANI: <i>Sam Stoy</i>		DATE: <i>5/16/07</i>				
LEVEL: <i>II</i>		LEVEL:		LEVEL: <i>III</i>		DATE: <i>3/14/07</i>		PG. <i>16</i> OF <i>10</i>				

Examination Report No. R-074

Weld No. RCRD-2-52

000188

TENNESSEE VALLEY AUTHORITY		EXAMINATION SUMMARY AND RESOLUTION DATA SHEET		REPORT NUMBER: R074	
PROJECT: BFN UNIT: 2		CYCLE: 14		COMPONENT ID: RCRD-2-52	
EXAMINATION METHOD				SYSTEM: RWCUS ISI DWG. NO. 2-ISI-0272-C-01	
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CODE CLASS: NA CATEGORY: R-A	
PROCEDURE: N-UT-82		REV: 2	TC: NA	CONFIG.:	Valve TO Elbow
EXAMINER: <i>W. H. Hill</i>		EXAMINER:		EXAMINER:	
LEVEL: II		LEVEL:		LEVEL:	

This report contains the data associated with the manual ultrasonic examination of RCRD-2-52 to meet the requirements of ASME Section XI, Category R-A, Item Number R1.16D, and BWRVIP-75.

This exam was performed using equipment, procedures and personnel qualified in accordance with ASME Section XI, Appendix VIII as amended by 10CFR50.55a final rule.

The component configuration is a 4" diameter, Sch 80 carbon steel pipe, welded to a forged stainless steel valve.

Both refracted longitudinal (RL) and shear wave search units were used as defined in procedure PDI-UT-10. The ultrasonic examination is limited due to the taper configuration of the dissimilar metal weld.

During the examination, a planar indication was detected that was oriented in the circumferential direction with a recorded length of 1.10 inches. The indication was detected using a 60° shear wave and a 60° RL wave search units. The indication was confirmed using a 70° shear wave and a 70° RL wave search units.

Notice of Indication (NOI) report number U2C14-017 generated.

Due to the inherent component geometry, it is not possible to obtain depth measurements of this indication using PDI ultrasonic qualified techniques. However, a best effort through wall sizing technique was applied and indicated an estimated remaining ligament of 0.20" in depth.

ASME Section XI Coverage:

Circumferential scan coverage was 100%. Axial scan coverage was 74%
Combined ASME Section XI Code coverage was 87%.

RESOLUTION BY: <i>W. H. Hill</i>	REVIEWED BY: <i>Walter Meteb</i> 2/3/19/07	ANII: <i>Jan Kneel</i>
LEVEL: II DATE: 3/3/07	LEVEL: III DATE: 3/3/07	DATE: 5/15/07 PG. 1 OF 20

ISI report no. R-017

000189

NOI no. U2C14-017

Component I.D. RCRD-2-52

Additional resolution details:

Weld configuration:

4" Carbon Steel, sch. 80 pipe to a forged stainless steel check valve. The joint configuration exhibits a dissimilar metal weld with a pipe wall thickness at the weld joint of .36" connected to a SS check valve body. The weld crown is tapered from the pipe to the valve at an angle of 18°. This configuration limits the ability to scan across the weld crown in the axial direction.

Examination technique:

The examination was performed in accordance with ASME Section XI, Appendix VIII qualified techniques for examination of dissimilar metal welds. The procedure utilized was TVA/ISO NDE Procedure N-UT-82 that implements the PDI Generic procedure PDI-UT-10.

Indication discrimination:

The joint configuration limited the ultrasonic examination angles to 60 and 70 degrees. The weld taper and width prevented the use of a 45° inspection angle.

The indication presented signal characteristics indicative of a planer reflector located in the weld. The reflector continued to return energy until the transducer contacted the weld taper. The higher examination angle returned more reflected energy than the lower examination angle. The reflector maintained echo dynamic motion during the axial raster scan and during skewing of the search unit.

The PDI dissimilar metal examination does not contain qualified through wall sizing techniques. However, a best effort through wall sizing technique was applied and indicated an estimated remaining ligament of 0.20" in depth.

Conclusion:

The weld configuration does not allow for all of the indication discrimination tools defined in the PDI generic procedure. The discrimination tools utilized indicate the presence of a planer flaw located in the weld metal. The available data indicates the presence of a planer reflector that would not meet the ASME Section XI, Table IWB-3514-2, for allowable planer flaws.

Steve Wilder III 3/3/07

10 2/20 W-3/19/07

TENNESSEE VALLEY
AUTHORITY

MANUAL ULTRASONIC
PIPING EXAMINATION
DATA SHEET

REPORT NUMBER

2074

PROJECT: BFW UNIT/CYCLE 2114
 SYSTEM RWCU5
 WELD ID.: RCRD-2-52
 CONFIG: VALVE TO PIPE
 FLOW \rightarrow

EXAMINATION DATE: 2/28/07
 START TIME: 1805 END TIME: 1846
 EXAM SURFACE ID OD
 MATERIAL TYPE: CS SS CSCL CCSS
 SURFACE TEMP. 82 PYRO NO. 562774

PROCEDURE: NUT-92 REV: 2 TC: N/A
 W₀ REFERENCE: WELD CENTERLINE
 L₀ REFERENCE: TOP DEAD CENTER

EXAMINATION ANGLE 45° SH DEG. 60° SH DEG.
 AXIAL SCAN SENSITIVITY 38.0 dB 54.0 dB
 CIRC. SCAN SENSITIVITY 42.0 dB N/A dB

IND NO.	L (in) FROM REF.			AT MAX AMP			MAX AMP %DAC	EXAM NO. 3-14	NOM. ANG.	NRI	INDICATION INFORMATION: TYPE, DAMPING, ETC.
	L1	L Max	L2	W MAX	MP MAX	D MAX					
								4	45° SH	<input checked="" type="checkbox"/>	
								5		<input checked="" type="checkbox"/>	
								6		<input checked="" type="checkbox"/>	
1	3.0	3.5	4.1	.68	*0.65"		130%	4	60° SH	<input type="checkbox"/>	* CAN NOT MAX OUT AMP, DUE TO OD GEOMETRY.
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	

REMARKS/LIMITATIONS IND. #1 SHOWS SIGNAL CHARACTERISTICS OF CRACKING FURTHER EVAL. REQUIRED.

EXAMINER: [Signature] LEVEL: II ANII: [Signature]
 EXAMINER: N/A LEVEL: _____ DATE: 5/15/07
 REVIEWED BY: Walt Welch LEVEL: III DATE: 3/3/07 PAGE: 3 OF 70
LEN 3/14/07

TENNESSEE VALLEY AUTHORITY	MANUAL ULTRASONIC PIPING EXAMINATION DATA SHEET	REPORT NUMBER <u> R074 </u>
---------------------------------------	--	---

PROJECT: <u>BFN</u> UNIT/CYCLE <u>2114</u> SYSTEM <u>RWCUS</u> WELD ID: <u>RCRD-2-52</u> CONFIG: <u>VLV</u> TO <u>P</u> <div style="text-align: center;"> FLOW </div> PROCEDURE: <u>N-UT-82</u> REV: <u>2</u> TC: <u>N/A</u> Wo REFERENCE: <u>WELD CENTER LINE</u> Lo REFERENCE: <u>TOP DEAD CENTER</u>	EXAMINATION DATE <u>2/28/07</u> START TIME: <u>1846</u> END TIME: <u>1910</u> EXAM SURFACE <input type="checkbox"/> ID <input checked="" type="checkbox"/> OD MATERIAL TYPE: <input type="checkbox"/> CS <input type="checkbox"/> SS <input type="checkbox"/> CSCI <input checked="" type="checkbox"/> CCSS SURFACE TEMP. <u>82</u> PYRO NO. <u>562774</u> <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>EXAMINATION ANGLE</td> <td>60° RL DEG.</td> <td>70° RL DEG.</td> </tr> <tr> <td>AXIAL SCAN SENSITIVITY</td> <td>56.0 dB</td> <td>65.5 dB</td> </tr> <tr> <td>CIRC. SCAN SENSITIVITY</td> <td></td> <td></td> </tr> </table>	EXAMINATION ANGLE	60° RL DEG.	70° RL DEG.	AXIAL SCAN SENSITIVITY	56.0 dB	65.5 dB	CIRC. SCAN SENSITIVITY		
EXAMINATION ANGLE	60° RL DEG.	70° RL DEG.								
AXIAL SCAN SENSITIVITY	56.0 dB	65.5 dB								
CIRC. SCAN SENSITIVITY										

IND NO.	L (in) FROM REF.			AT MAX AMP			MAX AMP % DAC	EXAM NO. 3-14	NOM. ANG.	NRI	INDICATION INFORMATION: TYPE, DAMPING, ETC.
	L1	LMax	L2	W MAX	MP MAX	D MAX					
								4	60° RL	<input checked="" type="checkbox"/>	
1	3.0"	3.5"	4.1"	.8"	.73"		120%	4	70° RL	<input type="checkbox"/>	LINEAR IJD. FURTHER EVAL. REQUIRED.
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	

REMARKS/LIMITATIONS IND. #1 CAN NOT BE MAXIMIZED DUE TO PROBE HITTING WELD TAPER. SIGNAL CHARACTERISTICS ARE INDICATIVE OF CRACKING AND NOT ID OR ROOT GEOMETRY. SCANNING WAS PERFORMED AT REF. LEVEL DUE TO SIGNAL TO NOISE RATIO.


EXAMINER: <u>[Signature]</u>	LEVEL: <u>II</u>	ANN: <u>[Signature]</u>
EXAMINER: <u>N/A</u>	LEVEL: _____	DATE: <u>5/15/07</u>
REVIEWED BY: <u>[Signature]</u>	LEVEL: <u>III</u> DATE: <u>3/3/07</u>	PAGE: <u>4</u> OF <u>20</u>

TENNESSEE VALLEY
AUTHORITY

MANUAL ULTRASONIC
PIPING EXAMINATION
DATA SHEET

REPORT NUMBER

2074

PROJECT: BFN UNIT/CYCLE 2114
 SYSTEM RWCUS
 WELD ID.: RCRD-2-52
 CONFIG.: VLV TO P
 FLOW 

EXAMINATION DATE 2/28/07
 START TIME: 1832 END TIME: 1915
 EXAM SURFACE ID OD
 MATERIAL TYPE: CS SS CSCL CCSS
 SURFACE TEMP. 82 PYRO NO. 562774

PROCEDURE: N-UT-82 REV: 2 TC: N/A
 W₀ REFERENCE: WELD CENTER LINE
 L₀ REFERENCE: TOP DEAD CENTER

EXAMINATION ANGLE	<u>45° SH</u> DEG.	<u>45° RL</u> DEG.
AXIAL SCAN SENSITIVITY	<u>38.0</u> dB	<u>59.5</u> dB
CIRC. SCAN SENSITIVITY	<u>42.0</u> dB	

IND NO.	L (in) FROM REF.			AT MAX AMP			MAX AMP % DAC	EXAM NO. 3-14	NOM. ANG.	NRI	INDICATION INFORMATION: TYPE, DAMPING, ETC.
	L1	LMax	L2	W MAX	MP MAX	D MAX					
								3	45° SH	<input checked="" type="checkbox"/>	
								4	"	<input checked="" type="checkbox"/>	
								5	"	<input checked="" type="checkbox"/>	
								6	"	<input checked="" type="checkbox"/>	
								4	45° RL	<input checked="" type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	

REMARKS/LIMITATIONS SCAN #3 AND 4 COVERAGE IS LIMITED DUE TO WELD TAPER AT VALVE.

EXAMINER: [Signature] LEVEL: I
 EXAMINER: N/A LEVEL: _____
 REVIEWED BY: [Signature] LEVEL: III DATE 3/3/07
Rev 3/19/07

ANI: [Signature]
 DATE 2/28/07
 PAGE 6 OF 20

TVA


Office of Nuclear Power

PROJECT: 255A SYSTEM: R-100

Unit: 1 WELD NO.: 255A-100

REPORT NO.:

R074



- The weld was inspected and found to be satisfactory.
- The effort to inspect the weld was completed.

BY: Michael V. Velez ^{mm 3/19/07} LEVEL: III DATE: 3/5/07 PAGE 7 OF 20


000195

TVA	WALL THICKNESS PROFILE SHEET	REPORT NO: R074
------------	---	---------------------------

PROJECT: <u>BFN</u> <u>RF-14</u>	WELD NO: <u>RCRD-2-52</u>
UNIT: <u>2</u>	SYSTEM: <u>RWCU</u>

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	—	—	—	—
2	—	—	—	—
3	—	—	—	—
4	.36	.36	.36	.36
5	.53	.53	.53	.53



CROWN HEIGHT: _____	DIAMETER: _____
CROWN WIDTH: _____	WELD LENGTH: _____

* O READING ON TAPER IS APPROXIMATE

.62 .56* .42 .48 .55 .55

END FROM OD OR APPROX LOCATION IND #2

70° SHEAR

70° RC REPTD NOT SHORT OF 20° SHEAR DUE TO RESTRICTION

OD CREEPER DETECTED AN IND. IN SAME AREA THAT PRODUCED A RESPONSE GREATER THAN THAT OF THE SDH OR NOTCH AT A DEPTH OF APPROX .175 TO .25" FROM OD. COULD NOT PEAK OUT IND. DUE TO TAPER.

EXAMINER: <u>[Signature]</u>	REVIEWED BY: <u>[Signature]</u>	ANII: <u>[Signature]</u>
LEVEL: <u>I</u>	LEVEL: <u>III</u>	DATE: <u>8/15/07</u>
DATE: <u>2/28/07</u>	DATE: <u>3/3/07</u>	PAGE <u>8</u> OF <u>70</u>

TVA

Office of Nuclear Power

PROJECT: BFN


SYSTEM: RWCU

REPORT NO.:

Unit: 2

WELD NO.: RCRD-2-52

R074



NOT TO SCALE

BY: Wade Hollings

LEVEL: IV

DATE: 3/3/07

PAGE 9 OF 20


000197

TENNESSEE VALLEY AUTHORITY		DIGITAL ULTRASONIC CALIBRATION DATA SHEET				REPORT NUMBER: <i>R074</i>																	
PROJECT: <i>BFN UNIT 2</i>		CYCLE: <i>14</i>		CALIBRATION DATE: <i>2/28/07</i>																			
PROC.: <i>N-UT-82</i>		REV: <i>2</i>		TC: <i>N/A</i>		CALIBRATION BLOCK NO.: <i>SQ115</i>		TEMP: <i>72 °F</i>															
INSTR. MFG: <i>KRAUTKRAMER</i>				DUE DATE: <i>12/11/07</i>		SIMULATOR BLOCK NO:																	
MODEL TYPE: <i>USN-60</i>				M & TE NO.: <i>E34054</i>		THERMOMETER S/N: <i>562774</i>				DUE DATE: <i>12/12/07</i>													
TRANSDUCER MFG: <i>KBA</i>				COUPLANT: <i>ULTRAGEL II</i>				BATCH: <i>04125</i>															
ELEMENTS: <i>1</i>		SHAPE: <i>ROUND</i>		EXAM TYPE: <input checked="" type="checkbox"/> SHEAR		<input type="checkbox"/> LONG		<input type="checkbox"/> RI															
S/N <i>00YCH3</i>		SIZE: <i>0.375"</i>		FREQ: <i>5.0</i> MHz		ANGLE VERIFICATION																	
CONTOUR: <i>FLAT</i>		FOCUS: <i>N/A</i>		BLOCK TYPE: <i>CS ROMPAS</i>				S/N: <i>790918</i>															
CABLE TYPE: <i>RG-174</i>		LENGTH: <i>72"</i>		#CNT: <i>0</i>		NOMINAL ANGLE: <i>60°</i>		ACTUAL ANGLE: <i>58°</i>															
DAC						INSTRUMENT SETTINGS																	
REFLECTOR						SCAN DIRECT		STCH		SDH		REFERENCE SENSITIVITY		MEMORY NUMBER									
						ANAL		<input checked="" type="checkbox"/>		<input type="checkbox"/>		<i>440.0</i> dB		<i>60° .375 50</i>									
RANGE: <i>1.5"</i>						CIRC		<input type="checkbox"/>		<input type="checkbox"/>		*INST. FREQ: <i>5.0</i> MHz											
						PROBE DELAY: <i>6.5444</i>		*RECTIFY: <i>FULLWAVE</i>		VELOCITY: <i>0.1270</i>		DUAL: <input type="checkbox"/> ON <input checked="" type="checkbox"/> OFF											
DISPLAY DELAY: <i>0.0</i>						*ENERGY: <i>HIGH</i>		*DISPLAY START: <i>IP</i>		*DAMPING: <i>1K</i>		DET: <input type="checkbox"/> PEAK <input checked="" type="checkbox"/> FLANK											
*PRF MODE: <i>AUTO HIGH</i>						TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>																	
REF. REFLECTOR: <i>.5 NOTCH</i>						GAIN: <i>440</i>		CALIBRATION TIMES															
AMPLITUDE: <i>80%</i>						METAL PATH: <i>901</i>		INITIAL TIME: <i>1338</i>		FINAL TIME: <i>1805</i>													
VERIFICATION TIMES						<i>1) 1730</i>		<i>2) —</i>		<i>3) —</i>		<i>4) —</i>		<i>5) —</i>									
		<i>6) —</i>		<i>7) —</i>		<i>8) —</i>		<i>9) —</i>															
* PDI QUALIFIED INSTRUMENT SETTINGS: VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!																							
LINEARITY CHECK																							
VERTICAL		SIGNAL 1		100		90		80		70		60		50		40		30		20		10	
		SIGNAL 2		50		45		40		35		30		25		20		15		10		5	
ATTENUATOR		GAIN		SET		-6 dB		-12 dB		SET		+12		SET		+6							
		AMP		80		32-48		16-24		20		64-96		40		64-96							
				<i>40</i>		<i>20</i>				<i>80</i>				<i>80</i>									
COMMENTS:						WELDS/ITEMS EXAMINED:																	
						<i>RCRD-2-49 ; RCRD-2-52</i>																	
						<i>RWCU-2-004-083</i>																	
EXAMINER: <i>[Signature]</i>				EXAMINER: <i>N/A</i>				REVIEWER: <i>[Signature]</i>				ANIE: <i>[Signature]</i>											
LEVEL: <i>I</i>				LEVEL:				LEVEL: <i>III</i>				DATE: <i>3/19/07</i>											
								DATE: <i>3/19/07</i>				PG. <i>10</i> OF <i>20</i>											

000198

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER: <i>R074</i>
-------------------------------	---	-------------------------------

PROJECT: <i>BFN UNIT 2</i>	CYCLE: <i>14</i>	CALIBRATION DATE: <i>2/28/07</i>
PROC.: <i>N-UT-82</i>	REV: <i>2</i> TC:	CALIBRATION BLOCK NO.: <i>SQ115</i> TEMP: <i>72</i> °F
INSTR. MFG: <i>KRAUTKRAMER</i>	DUE DATE: <i>12/11/07</i>	SIMULATOR BLOCK NO.: <i>N/A</i>
MODEL TYPE: <i>USN-60</i>	M & TE NO.: <i>E34054</i>	THERMOMETER S/N: <i>562774</i> DUE DATE: <i>12/12/07</i>
TRANSDUCER MFG: <i>KBA</i>	COUPLANT	BATCH:
ELEMENTS: <i>1</i> SHAPE: <i>ROUND</i>	<i>ULTRAGEL II</i> <i>04125</i>	
S/N <i>0156XP</i> SIZE: <i>0.25"</i> FREQ: <i>5.0</i> MHz	EXAM TYPE: <input checked="" type="checkbox"/> SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RL <input type="checkbox"/>	
CONTOUR: <i>FLAT</i> FOCUS: <i>N/A</i>	ANGLE VERIFICATION	
CABLE TYPE: <i>AG-174</i> LENGTH: <i>72"</i> #CNT <i>0</i>	BLOCK TYPE: <i>CS ROMPAS</i>	S/N: <i>790918</i>
DAC	NOMINAL ANGLE: <i>60°</i>	ACTUAL ANGLE: <i>57°</i>



DISPLAY WIDTH: inches *1.5"*

INSTRUMENT SETTINGS				
REFLECTOR			REFERENCE	MEMORY
STANDARD	DIRECT	NTCH	SENSITIVITY	NUMBER
AXIAL	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>45.0</i> dB	<i>60.25</i>
CIRC	<input type="checkbox"/>	<input type="checkbox"/>	dB	
RANGE: <i>1.5"</i>			*INST. FREQ: <i>5.0</i> MHz	
PROBE DELAY: <i>5.0478</i>			*RECTIFY: <i>FULL WAVE</i>	
VELOCITY: <i>0.1270</i>			DUAL <input type="checkbox"/> ON <input checked="" type="checkbox"/> OFF	
DISPLAY DELAY: <i>0.0</i>			*REJECT: <i>0</i> %	
*ENERGY: <i>HIGH</i>			*DISPLAY START: <i>IF</i>	
*DAMPING: <i>1K</i>			DET: <input type="checkbox"/> PEAK <input checked="" type="checkbox"/> FLANK	
*PRF MODE: <i>AUTO HIGH</i>			TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>	

REF. REFLECTOR: <i>.5" NOTCH</i>	GAIN: dB <i>45.0</i>	CALIBRATION TIMES							
AMPLITUDE: <i>80%</i>	METAL PATH: <i>.905</i>	INITIAL TIME: <i>1345</i>	FINAL TIME: <i>1820</i>						
VERIFICATION TIMES	1) <i>1805</i>	2) _____	3) _____	4) _____	5) _____	6) _____	7) _____	8) _____	9) _____

* PDI QUALIFIED INSTRUMENT SETTINGS:
VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2
OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL 1		100	90	80	70	60	50	40	30	20	10
	SIGNAL 2		50	45	40	35	30	25	20	15	10	5
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6				
	AMP	80	32-48	16-24	20	64-96	40	64-96				
			40	20			80	80				


COMMENTS:	WELDS/ITEMS EXAMINED:
	<i>RCRD-2-49 ; RCRD-2-52</i>
	<i>RWCU-2-004-083</i>

EXAMINER: <i>Wade Holler</i>	EXAMINER: <i>N/A</i>	REVIEWER: <i>Wade Holler</i>	ANI: <i>Low Flaw</i>
LEVEL: <i>II</i>	LEVEL:	DATE: <i>3/19/07</i>	DATE: <i>3/15/07</i>
		PG. <i>11</i>	OF <i>20</i>

000199

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER: <i>R074</i>
-------------------------------	---	-------------------------------

PROJECT: <i>BFN UNIT 2</i>	CYCLE: <i>14</i>	CALIBRATION DATE: <i>2/28/07</i>
PROC.: <i>N-UT-82</i>	REV: <i>2</i>	TC:
INSTR. MFG: <i>KRAUTKRAMER</i> DUE DATE: <i>12/11/07</i>		CALIBRATION BLOCK NO.: <i>SQ115(ACT)</i> TEMP: <i>72 F</i>
MODEL/TYPE: <i>USN-60</i> M & TE NO.: <i>E34054</i>		SIMULATOR BLOCK NO.: <i>N/A</i>
TRANSDUCER MFG: <i>KBA</i>		THERMOMETER S/N: <i>562774</i> DUE DATE: <i>12/12/07</i>
ELEMENTS: <i>1</i> SHAPE: <i>ROUND</i>		COUPLANT: <i>ULTRAGEL II</i> BATCH: <i>04125</i>
S/N <i>0156YP</i> SIZE: <i>0.25"</i> FREQ: <i>5.0</i> MHz		EXAM TYPE: <input checked="" type="checkbox"/> SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> REL <input type="checkbox"/>
CONTOUR: <i>FLAT</i> FOCUS: <i>N/A</i>		ANGLE VERIFICATION
CABLE TYPE: <i>RG-174</i> LENGTH: <i>72"</i> #CNT: <i>0</i>		BLOCK TYPE: <i>CS ROMPMS</i> S/N: <i>790918</i>
DAC		NOMINAL ANGLE: <i>45°</i> ACTUAL ANGLE: <i>44°</i>



DISPLAY WIDTH: inches: *1.0"*

INSTRUMENT SETTINGS				
REFLECTOR			REFERENCE	MEMORY
SCAN DIRECT	STCH	SDH	SENSITIVITY	NUMBER
AXIAL	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>28.0</i> dB	<i>45° 25.5</i>
CIRC	<input type="checkbox"/>	<input type="checkbox"/>	dB	
RANGE: <i>1.0"</i>		*INST. FREQ: <i>5.0</i> MHz		
PROBE DELAY: <i>3.7184</i>		*RECTIFY: <i>FULLWAVE</i>		
VELOCITY: <i>0.1270</i>		DUAL <input type="checkbox"/> ON <input checked="" type="checkbox"/> OFF		
DISPLAY DELAY: <i>0.0</i>		*REJECT: <i>0</i> %		
*ENERGY: <i>HIGH</i>		*DISPLAY START: <i>IP</i>		
*DAMPING: <i>1K</i>		DET: <input type="checkbox"/> PEAK <input checked="" type="checkbox"/> FLANK		
*PRF MODE: <i>AUTO HIGH</i>		TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>		

REF. REFLECTOR: <i>.5" NOTCH</i>	GAIN: dB <i>28.0</i>	CALIBRATION TIMES	
AMPLITUDE: <i>80%</i>	METAL PATH: <i>0.692</i>	INITIAL TIME: <i>1342</i>	FINAL TIME: <i>1846</i>
VERIFICATION TIMES	1) <i>1840</i>	2) <i>N/A</i>	3) <i>17</i>

* PDI QUALIFIED INSTRUMENT SETTINGS:
VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2
OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK											
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20	10
	SIGNAL 2	50	<i>45</i>	<i>40</i>	<i>35</i>	<i>30</i>	<i>25</i>	<i>20</i>	<i>15</i>	<i>10</i>	<i>5</i>
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6			
	AMP	80	32-48	16-24	20	64-96	40	64-96			
			<i>40</i>	<i>20</i>			<i>80</i>	<i>80</i>			


COMMENTS:	WELDS/ITEMS EXAMINED:
	<i>RCRD-2-49, RCRD-2-52</i>
	<i>RWCU-2-004-083</i>

EXAMINER: <i>Wade Wilcox</i>	EXAMINER: <i>N/A</i>	REVIEWER: <i>Wade Wild</i>	ANH: <i>Jan Hank</i>
LEVEL: <i>II</i>	LEVEL:	DATE: <i>3/19/07</i>	DATE: <i>2/15/07</i>
		PG. <i>12</i> OF <i>20</i>	

000201

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER: <i>R074</i>
-------------------------------	---	-------------------------------

PROJECT: <i>BFN UNIT 2</i>	CYCLE: <i>14</i>	CALIBRATION DATE: <i>2/28/07</i>
PROC.: <i>N-UT-82</i>	REV: <i>2</i>	TC:
INSTR. MFG: <i>KRAUTKRAMER</i>	DUE DATE: <i>12/11/07</i>	CALIBRATION BLOCK NO.: <i>5Q123</i>
MODEL TYPE: <i>USN-60</i>	M & TE NO.: <i>E34054</i>	TEMP: <i>72 F</i>
TRANSDUCER MFG: <i>KBA</i>	COUPLANT	SIMULATOR BLOCK NO.: <i>N/A</i>
ELEMENTS: <i>1</i>	SHAPE: <i>ROUND</i>	THERMOMETER S/N: <i>562774</i>
S/N: <i>00X03R</i>	SIZE: <i>.375"</i>	DUE DATE: <i>12/12/07</i>
CONTOUR: <i>FLAT</i>	FOCUS: <i>N/A</i>	BATCH:
CABLE TYPE: <i>RG-174</i>	LENGTH: <i>72"</i>	ANGLE VERIFICATION
DAC	BLOCK TYPE: <i>SS ROMPAS</i>	S/N: <i>6026-83</i>
	NOMINAL ANGLE: <i>45°</i>	ACTUAL ANGLE: <i>46°</i>



DISPLAY WIDTH inches *2.0"*

INSTRUMENT SETTINGS				
REFLECTOR			REFERENCE	MEMORY
S (AN DIRECT)	STCH	SDH	SENSITIVITY	NUMBER
ANAL	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>30.0</i> dB	<i>45° 37515</i>
CIRC	<input type="checkbox"/>	<input type="checkbox"/>	dB	
RANGE: <i>2.0"</i>			INST. FREQ: <i>2.0</i> MHz	
PROBE DELAY: <i>7.7631</i>			RECTIFY: <i>FULL WAVE</i>	
VELOCITY: <i>0.1270</i>			DUAL <input type="checkbox"/> ON <input checked="" type="checkbox"/> OFF	
DISPLAY DELAY: <i>0.0</i>			REJECT: <i>0</i>	
ENERGY: <i>HIGH</i>			DISPLAY START: <i>IP</i>	
DAMPING: <i>1K</i>			DET: <input type="checkbox"/> PEAK <input checked="" type="checkbox"/> FLANK	
PRF MODE: <i>AUTO HIGH</i>			TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>	

REF. REFLECTOR: <i>1.0" WDEH</i>	GAIN: <i>30.0</i> dB	CALIBRATION TIMES							
AMPLITUDE: <i>80%</i>	METAL PATH: <i>1.42</i>	INITIAL TIME: <i>1330</i>	FINAL TIME: <i>1840</i>						
VERIFICATION TIMES	1) <i>1832</i>	2) <i>N/A</i>	3) <i></i>	4) <i></i>	5) <i></i>	6) <i></i>	7) <i></i>	8) <i></i>	9) <i></i>

* PDI QUALIFIED INSTRUMENT SETTINGS:
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2
 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK											
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20	10
	SIGNAL 2	50	45	40	35	30	25	20	15	10	5
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6			
	AMP	80	32.48	16.24	20	64.96	40	64.96			
			40	20		80		80			


COMMENTS:	WELDS/ITEMS EXAMINED:
	<i>RCRD-2-49; RCRD-2-52</i>

EXAMINER: <i>Wade Holcomb</i>	EXAMINER: <i>N/A</i>	REVIEWER: <i>Wade Holcomb</i>	ASST: <i>Wade Holcomb</i>
LEVEL: <i>II</i>	LEVEL:	DATE: <i>3/19/07</i>	DATE: <i>5/15/07</i>
		PG. <i>14</i> OF <i>20</i>	

000202

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER: R074
-------------------------------	---	------------------------

PROJECT: BFN UNIT 2	CYCLE: 14	CALIBRATION DATE: 2/28/07
PROC.: N-UT-82	REV: 2 TC:	CALIBRATION BLOCK NO.: BF-131 TEMP: 72.°F
INSTR. MFG: KRAUTKRAMER	DUE DATE: 12/11/07	SIMULATOR BLOCK NO.: N/A
MODEL TYPE: USN-60	M & TE NO.: E34054	THERMOMETER S/N: 562774 DUE DATE: 12/12/07
TRANSDUCER MFG: MEGASONICS		COUPLANT BATCH:
ELEMENTS: 2 SHAPE: RECT.		ULTRAGEL II 04125
S/N U0110	SIZE: 2(10x18) FREQ: 2.0 MHz	EXAM TYPE: SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RL <input checked="" type="checkbox"/>
CONTOUR: 6.0" OD AXIAL	FOCUS: FS-28	ANGLE VERIFICATION
CABLE TYPE: 2(RG-174)	LENGTH: 72" #CNT: 0	BLOCK TYPE: S/N: BF-131
DAC	NOMINAL ANGLE: 70°	ACTUAL ANGLE: 67°



INSTRUMENT SETTINGS			
REFLECTOR			REFERENCE
SCAN DIRECT	NTCH	SDH	SENSITIVITY
AXIAL	<input type="checkbox"/>	<input checked="" type="checkbox"/>	65.5 dB
CIRC	<input type="checkbox"/>	<input type="checkbox"/>	dB
RANGE:	2.0	*INST. FREQ: 2.0 Mhz	
PROBE DELAY:	7.9159	*RECTIFY: FULLWAVE	
VELOCITY:	.2367	DUAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF	
DISPLAY DELAY:	0.0	*REJECT: 0 %	
*ENERGY:	HIGH	*DISPLAY START: I P	
*DAMPING:	1K	DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK	
*PRF MODE:	AUTOHIGH	TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>	

REF. REFLECTOR: .4" SDH	GAIN: dB 65.5	CALIBRATION TIMES	
AMPLITUDE: 80%	METAL PATH: .945	INITIAL TIME: 1355	FINAL TIME: 1910
VERIFICATION TIMES	1) 1857	2) N/A	3) _____

* PDI QUALIFIED INSTRUMENT SETTINGS:
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2
 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK												
VERTICAL	SIGNAL 1		100	90	80	70	60	50	40	30	20	10
	SIGNAL 2		50	45	40	35	30	25	20	15	10	5
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6				
	AMP	80	32-48	16-24	20	64-96	40	64-96				
			40	20	80		80					


COMMENTS:	WELDS/ITEMS EXAMINED:
	RCRD-2-49; RCRD-2-52
	RWCU-2-004-083

EXAMINER: <i>[Signature]</i>	EXAMINER: N/A	REVIEWER: <i>[Signature]</i>	ANI: <i>[Signature]</i>
LEVEL: II	LEVEL:	LEVEL: III	DATE: 5/15/07
		DATE: 3/19/07	PG. 15 OF 20

000203

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER: <i>R074</i>
-------------------------------	---	-------------------------------

PROJECT: <i>BFN UNIT 2</i>	CYCLE: <i>14</i>	CALIBRATION DATE: <i>2/28/07</i>
PROC.: <i>N-UT-82</i>	REV: <i>2</i> TC:	CALIBRATION BLOCK NO.: <i>BF-131</i> TEMP: <i>72.1 F</i>
INSTR. MFG: <i>KRAUTKRAMER</i>	DUE DATE: <i>12/11/07</i>	SIMULATOR BLOCK NO: <i>N/A</i>
MODEL/TYPE: <i>USN-60</i>	M & TE NO.: <i>E34054</i>	THERMOMETER S/N: <i>562774</i> DUE DATE: <i>12/12/07</i>
TRANSDUCER MFG: <i>MEGASONICS</i>	COUPLANT	BATCH:
ELEMENTS: <i>2</i> SHAPE: <i>RECT</i>	<i>ULTRAGEL II</i>	<i>04125</i>
S/N <i>U0109</i> SIZE: <i>2(10x18)</i>	FREQ: <i>2.0</i> MHz	EXAM TYPE: SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RL <input checked="" type="checkbox"/>
CONTOUR: <i>6.0" OD AXIAL</i>	FOCUS: <i>FS = 17 mm</i>	ANGLE VERIFICATION
CABLE TYPE: <i>2(RG-174)</i>	LENGTH: <i>72"</i> #CNT: <i>0</i>	BLOCK TYPE: S/N: <i>BF-131</i>
DAC	NOMINAL ANGLE: <i>60°</i>	ACTUAL ANGLE: <i>57.0</i>



DISPLAY WIDTH: inches *1.5"*

INSTRUMENT SETTINGS				
REFLECTOR			REFERENCE	MEMORY
SCAN DIRECT.	NTCH	SDH	SENSITIVITY	NUMBER
AXIAL	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<i>56.0</i> dB	<i>U0109</i>
CIRC	<input type="checkbox"/>	<input type="checkbox"/>	dB	
RANGE:	<i>1.5"</i>		*INST. FREQ: <i>2.0</i> MHz	
PROBE DELAY:	<i>2.1650</i>		*RECTIFY: <i>FULLWAVE</i>	
VELOCITY:	<i>.2367</i>		DUAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF	
DISPLAY DELAY:	<i>0.0</i>		*REJECT: <i>0</i> %	
*ENERGY:	<i>HIGH</i>		*DISPLAY START: <i>IP</i>	
*DAMPING:	<i>1K</i>		DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK	
*PRF MODE:	<i>AUTO HIGH</i>		TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>	

REF. REFLECTOR: <i>.4" SDH</i>	GAIN: dB <i>56.0</i>	CALIBRATION TIMES							
AMPLITUDE: <i>80%</i>	METAL PATH: <i>.636</i>	INITIAL TIME: <i>1350</i>	FINAL TIME: <i>1857</i>						
VERIFICATION TIMES	1) <i>1846</i>	2) <i>N/A</i>	3)	4)	5)	6)	7)	8)	9)

* PDI QUALIFIED INSTRUMENT SETTINGS:
VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2
OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK											
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20	10
	SIGNAL 2	50	<i>45</i>	<i>40</i>	<i>35</i>	<i>30</i>	<i>25</i>	<i>20</i>	<i>15</i>	<i>10</i>	<i>5</i>
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6			
	AMP	<i>80</i>	<i>32-48</i>	<i>16-24</i>	<i>20</i>	<i>64-96</i>	<i>40</i>	<i>64-96</i>			
			<i>40</i>	<i>20</i>		<i>80</i>		<i>80</i>			

COMMENTS:	WELDS/ITEMS EXAMINED:
	<i>RCRD-2-49; RCRD-2-52</i>
	<i>RWCU-2-004-083</i>

EXAMINER: <i>John Holland</i>	EXAMINER: <i>N/A</i>	REVIEWER: <i>Walter Wilder</i>	ANI: <i>John Holland</i>
LEVEL: <i>II</i>	LEVEL:	DATE: <i>3/19/07</i>	DATE: <i>5/15/07</i>
		LEVEL: <i>III</i>	PG. <i>16</i> OF <i>20</i>


000204

TENNESSEE VALLEY AUTHORITY		DIGITAL ULTRASONIC CALIBRATION DATA SHEET				REPORT NUMBER: <i>R074</i>						
PROJECT: <i>BFN UNIT 2</i>		CYCLE: <i>14</i>		CALIBRATION DATE: <i>2-28-07</i>								
PROC.: <i>N-UT-82</i>		REV: <i>2</i> TC:		CALIBRATION BLOCK NO.: <i>BF-132</i> TEMP: <i>72.°F</i>								
INSTR. MFG: <i>KRAUTKRAMER</i> DUE DATE: <i>12/11/07</i>				SIMULATOR BLOCK NO:								
MODEL TYPE: <i>USN-60</i>		M & TE NO.: <i>E34054</i>		THERMOMETER S/N: <i>562774</i> DUE DATE: <i>12/12/07</i>								
TRANSDUCER MFG: <i>MEGASONICS</i>				COUPLANT		BATCH:						
ELEMENTS: <i>2</i> SHAPE: <i>RECT</i>				<i>ULTRAGEL II</i>		<i>04125</i>						
S/N <i>U0114</i> SIZE: <i>2(7x12)</i> FREQ: <i>2.0</i> MHz				EXAM TYPE: SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RL <input checked="" type="checkbox"/>		ANGLE VERIFICATION						
CONTOUR: <i>60° OD 18ccw TAPER</i> FOCUS: <i>FS=17mm</i>				BLOCK TYPE:								
CABLE TYPE: <i>2(RG-174)</i> LENGTH: <i>72"</i> #CNT: <i>0</i>				S/N: <i>BF-132</i>		NOMINAL ANGLE: <i>41°</i> ACTUAL ANGLE: <i>41°</i>						
DAC				INSTRUMENT SETTINGS								
				REFLECTOR		REFERENCE	MEMORY					
				SCAN DIRECT	NTCH	SDH	SENSITIVITY	NUMBER				
				AXIAL	<input type="checkbox"/>	<input type="checkbox"/>	dB					
				CIRC	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<i>60°</i> dB					
				RANGE: <i>1.5"</i>		*INST. FREQ: <i>2.0</i> MHz						
PROBE DELAY: <i>5.1888</i>		*RECTIFY: <i>FULLWAVE</i>										
VELOCITY: <i>.2367</i>		DUAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF										
DISPLAY DELAY: <i>0.0</i>		*REJECT: <i>0</i> %										
*ENERGY: <i>HIGH</i>		*DISPLAY START: <i>IP</i>										
*DAMPING: <i>1K</i>		DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK										
*PRF MODE: <i>AUTO HIGH</i>		TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>										
REF. REFLECTOR: <i>.4" 50H</i> GAIN: dB <i>60</i>				CALIBRATION TIMES								
AMPLITUDE: METAL PATH:				INITIAL TIME: <i>1420</i>		FINAL TIME: <i>1922</i>						
VERIFICATION TIMES		1) <i>1918</i>	2) _____	3) _____	4) _____	5) _____	6) _____	7) _____	8) _____	9) _____		
* PDI QUALIFIED INSTRUMENT SETTINGS: VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!												
LINEARITY CHECK												
VERTICAL	SIGNAL 1		100	90	80	70	60	50	40	30	20	10
	SIGNAL 2		50	45	40	35	30	25	20	15	10	5
ATTENUATOR	GAIN	SET	-6 dB		-12 dB		SET	+12		SET	+6	
	AMP	80	32-48		16-24		20	64-96		40	64-96	
			<i>40</i>		<i>20</i>			<i>80</i>			<i>80</i>	
COMMENTS:					WELDS/ITEMS EXAMINED:							
					<i>RCRD-2-52</i>							
EXAMINER: <i>[Signature]</i>			EXAMINER: <i>N/A</i>			REVIEWER: <i>[Signature]</i>			ANII: <i>[Signature]</i>			
LEVEL: <i>11</i>			LEVEL:			LEVEL: <i>11</i> DATE: <i>3/19/07</i>			DATE: <i>3/15/07</i>			
									PG. <i>17</i> OF <i>20</i>			

000205

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER: <i>R074</i>
-------------------------------	---	-------------------------------

PROJECT: <i>BFN UNIT 2</i>	CYCLE: <i>14</i>	CALIBRATION DATE: <i>2/28/07</i>
PROC.: <i>N-UT-82</i>	REV: <i>2</i> TC:	CALIBRATION BLOCK NO.: <i>BF-132</i> TEMP: <i>72. F</i>
INSTR. MFG: <i>KRAUTKRAMER</i>	DUE DATE: <i>12/11/07</i>	SIMULATOR BLOCK NO:
MODEL TYPE: <i>USN-60</i>	M & TE NO.: <i>E34054</i>	THERMONITER S/N: <i>562774</i> DUE DATE: <i>12/12/07</i>
TRANSDUCER MFG: <i>MEGASONICS</i>	ELEMENTS: <i>2</i> SHAPE: <i>RECT.</i>	COUPLANT: <i>ULTRAGEL II</i> BATCH: <i>04125</i>
S/N: <i>U0272</i> SIZE: <i>2(7x12)</i> FREQ: <i>2.0</i> MHz	EXAM TYPE: SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RL <input checked="" type="checkbox"/>	ANGLE VERIFICATION
CONTOUR: <i>6.0 00 TAPER 2518°</i> FOCUS: <i>FS: 17mm</i>	BLOCK TYPE:	S/N: <i>BF-132</i>
CABLE TYPE: <i>2(RG-174)</i> LENGTH: <i>72"</i> #CNT: <i>0</i>	NOMINAL ANGLE: <i>41°</i>	ACTUAL ANGLE: <i>42°</i>



INSTRUMENT SETTINGS				
REFLECTOR			REFERENCE	MEMORY
SCAN DIRECT:	NTCH	SDH	SENSITIVITY	NUMBER
AXIAL	<input type="checkbox"/>	<input type="checkbox"/>	dB	<i>U0272</i>
CIRC	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<i>57.0</i> dB	
RANGE: <i>1.5"</i>	*INST. FREQ: <i>2.0</i> MHz			
PROBE DELAY: <i>5.1888</i>	*RECTIFY: <i>FULLWAVE</i>			
VELOCITY: <i>.2367</i>	DUAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF			
DISPLAY DELAY: <i>0.0</i>	*REJECT: <i>0 %</i>			
*ENERGY: <i>HIGH</i>	*DISPLAY START: <i>1.2</i>			
*DAMPING: <i>1K</i>	DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK			
*PRF MODE: <i>AUTO HIGH</i>	TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>			

REF. REFLECTOR: <i>.4" SDH</i>	GAIN: <i>JB 57.0</i>	CALIBRATION TIMES		
AMPLITUDE: <i>80%</i>	METAL PATH: <i>0.567</i>	INITIAL TIME: <i>1415</i>	FINAL TIME: <i>1935</i>	
VERIFICATION TIMES	1) <i>1930</i>	2) <i>---</i>	3) <i>---</i>	4) <i>---</i>

* PDI QUALIFIED INSTRUMENT SETTINGS:
VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2
OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK											
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20	10
	SIGNAL 2	50	45	40	35	30	25	20	15	10	5
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6			
	AMP	80	32-48	16-24	20	64-96	40	64-96			
			<i>40</i>	<i>20</i>		<i>80</i>		<i>80</i>			

COMMENTS:	WELDS/ITEMS EXAMINED: <i>RCRD-2-52</i>
-----------	---


EXAMINER: <i>Clark Holcomb</i>	EXAMINER: <i>N/A</i>	REVIEWER: <i>Walter Welch</i>	ANTI: <i>Sanford</i>
LEVEL: <i>II</i>	LEVEL:	LEVEL: <i>III</i> DATE: <i>3/19/07</i>	DATE: <i>5/15/07</i>
		PG. <i>8</i> OF <i>20</i>	

<h1>TVA</h1>	<h2>WALL THICKNESS 000206 PROFILE SHEET</h2>	REPORT NO: R074
--------------	--	---------------------------


PROJECT: <u>BFIN</u>	WELD NO: <u>RCRD-2-52</u>
UNIT: <u>2</u>	SYSTEM: <u>RWCU</u>

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	N/A			
2	.62			
3	.50		N/A	
4	.36			
5	.53			



CROWN HEIGHT: <u>ISI PREP</u>	DIAMETER: <u>4.0</u>
CROWN WIDTH: <u>0.6</u>	WELD LENGTH: <u>14.5</u>



#1 45°
#2 70°
#3 60°

EXAMINER: <u>[Signature]</u>	REVIEWED BY: <u>[Signature]</u>	ANII: <u>[Signature]</u>
LEVEL: <u>II</u>	LEVEL: <u>III</u>	DATE: <u>5/15/07</u>
DATE: <u>2/28/07</u>	DATE: <u>3/19/07</u>	PAGE <u>19</u> OF <u>20</u>

RERD-2-5Z

000207

ID/OD RATIO = .835

R074

DWG - 2-IST-0272-C-01

Max ϕ for ID imp. = 56.62"

1" 5/80 C/S, .337 NOM WALL, 4.3" OD

Req'd Transducers

RL: 60°/70° axial scans, 45° circum scans,

FREQ = WT < .50; 2.0 TO 5.0 mm (DS SIDE) / WT > .50; 1.0 - 2.25 mm (US SIDE)

SIZES = AS REQUIRED

SHR: 45°/60° axial scans, 45° circum scans

FREQ = WT < .5"; 2.0 - 2.25 mm (DS SIDE) / WT > .5"; 1.0 - 2.25 mm (US SIDE)

Metal Paths US .362" / DS .582"

60° DS SIDE = .724" (18.4 mm)

70° DS = 1.1" (28 mm)

45° DS = .52" (13 mm)

60° US SIDE = 1.0" (25.4 mm)

70° US = 1.7" (43.2 mm)

45° US = .82" (21 mm)

US 50% - 110% = DS (11-20 mm) US (18-32) [15]

DS (17-31) US (26-48) [25]

DS (14-17) US (15-26) } = 75% - 125%

45° DS = .59" (15 mm)

circ scans

FREQ = 75% - 125%

US (15-26)

US = .82" (21 mm)


Exam Volume = 1.25 x 2 = .21 cu in

Est % obtained = $.21 \text{ cu in} - [(.75 \times 2) + (\frac{1.05 \times 2}{2})] = .135 \div .21 \times 100 = 73.8\%$ - axial scans R/L & SHR

Est % obtained circum scans:

100% (combined R/L & SHR)

Est coverage = 86.9%



ps20/20

NOTIFICATION OF INDICATION FORM

NOI No. 42014-47 Plant/Unit BFN 2 PART I - FINDINGS ISI Dwg./Sh. No. 2-ISI-0272C, SHT. 1 of 3
Examination Report No. R-074 Component ID RCRD-2-52

Description of Indication (Sketch/Photograph if Required for Clarification): ULTRASONIC EXAMINATION OF 4" CS/SS WELD RCRD-2-52 DETECTED A PLANAR INDICATION. REFERENCE ATTACHED UT REPORT.

Signature of Examiner/Certification Level: [Signature] /Date: 3/3/07
Signature of ISO Coordinator (Field Supervisor): [Signature] /Date: 03/03/07
Signature of ISI Program Owner: [Signature] /Date: 04/10/07

PART II - DISPOSITION

See attached.

Corrective Action Program or Administrative Control document number (PER, WO) if applicable: 121003

ASME XI Subsection IWE Yes No If Yes, complete the supplemental information Parts II and III of Page 2 of this form in addition to Parts II, III, and IV, of Page 1. If No, completion of Parts II and III of Page 2 of this form is not required and attachment of Page 2 with Page 1 is not required.

Disposition Prepared/Recorded By: Victor D. Williams Org. SE-M/N Date: 05-10-2007

PART III - ADDITIONAL EXAMINATIONS

Additional Sample Required [IW(X)-2430]: Yes No scw 5/11/07 Page 2 of 2 additional samples attached? Yes No scw 5/11/07

(Attach list of items in additional sample, if yes.) [Signature] 5/11/07
ISI or CISI Program Owner Date

Successive Examination Required: Yes No [Signature] 5/11/07
ISI or CISI Program Owner Date

PART IV - VERIFICATION OF CLOSURE

Reexamination Report number, if Applicable: N/A
Signature of ISO Coordinator: _____ Date: _____

Finding resulted from performance of the General visual Examination Yes No If Yes, concurrence of the Registered Professional Engineer (RPE) or Individual Responsible for performance is required (N/A otherwise):

N/A
RPE/Responsible Engineer Date

Comments: _____

Verification of Complete Corrective Action Required by Disposition (Including Page 2, if applicable)
Signature of ISI or CISI Program Owner: [Signature] Date: 5/11/07

04 5/15/07

000209

Page 2 of 4

NOTIFICATION OF INDICATION FORM
ATTACHMENTNOI No. U2C14-017 Plant/Unit BFN Unit 2Examination Report No. R-074 Component ID RCRD-2-52**Part II - Disposition**

This NOI documents a planar indication that was observed during manual ultrasonic examination of dissimilar metal weld RCRD-2-52 (4-inch Carbon Steel, Schedule 80 pipe to stainless steel check valve 2-CKV-085-0576) during the Unit 2 Cycle 14 Refueling Outage. This examination was performed in accordance with ASME Section XI, Appendix VIII qualified techniques for examination of dissimilar metal welds (Report Number R-074). The procedure utilized was TVA/ISO NDE Procedure N-UT-82 that implements the PDI Generic Procedure PDI-UT-10. The indication presented signal characteristics indicative of a planar reflector located in the weld. The available data indicated that the planar reflector would not meet the ASME Section XI, Table IWB-3514-2, criteria for allowable planar flaws.

The planar indication was removed when check valve 2-CKV-085-0576 was cut out and replaced under Work Order Number 07-713160-000. The indication was removed in such a manner to allow subsequent metallurgical evaluation. Westinghouse, LLC has been contracted to determine the cause of the planar indication, and is expected to have preliminary results of their evaluation by June 2007.

Prepared By: Victor D. Schiavone Org. SE-M/N Date 05-10-2007

000210

Page 3 of 4

NOI U2C14-017
List of Items in Additional Sample

Weld ID	ISI Exam	Report Number	Exam Results
RCRD-2-33	manual UT	R-116	No Recordable Indications
RCRD-2-50	manual UT	R-118	No Recordable Indications
DRHR-2-11	manual UT	R-119	No Recordable Indications
DRHR-2-03	manual UT	R-121	No Recordable Indications

NOTIFICATION OF INDICATION FORM
SUBSECTION IWE

Complete this page in addition to Page 1 for findings affecting Class MC/Subsection IWE.

NOI No. 42C14-017

Plant/Unit BFN/2

Examination Report No. R-074

Component ID RCRD-252

PART II - DISPOSITION (Supplemental Information)

Evaluation of inaccessible areas as required by 10CFR50.55a(b)(2)(ix)(A)
(Include (1) A description of the type and estimated extent of degradation, and the conditions that led to the degradation; (2) An evaluation of each area, and the result of the evaluation; and (3) A description of necessary corrective actions) [additional separate continuation sheets may be attached, as necessary].

Corrective Action Program or Administrative Control document number (PER, WO) if applicable: _____

Disposition Prepared By: _____

N Org. 8/26/07

Date _____

PART III - ADDITIONAL EXAMINATIONS (Supplemental Information)

Additional examinations required per 10CFR50.55a(b)(2)(ix)(D) Yes No
If Yes, provide (1) A description of each flaw or area, including the extent of degradation, and the conditions that led to the degradation; (2) The acceptability of each flaw or area, and the need for additional examinations to verify that similar degradation does not exist in similar components; (3) A description of the necessary corrective actions; and (4) The number and type of additional examinations to ensure detection of similar degradation in similar components [additional separate continuation sheets may be attached, as necessary].

Specified By: _____

Org. _____

Date: _____

Examination Report No. R-123

Weld No. RWCU-2-004-083

TENNESSEE VALLEY AUTHORITY		EXAMINATION SUMMARY AND RESOLUTION DATA SHEET		REPORT NUMBER: <i>R123</i>	
PROJECT: BFN UNIT: 2		CYCLE: 14		COMPONENT ID: RWCU-2-004-083	
EXAMINATION METHOD				SYSTEM: RWCUS ISI DWG. NO. 2-ISI-0272-C-01	
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CODE CLASS: NA CATEGORY: R-A	
PROCEDURE: N-UT-82		REV: 2	TC: NA	CONFIG:	C/S Pipe TO S/S Valve
EXAMINER: <i>W. K. Helms</i>		EXAMINER: <i>N/A</i>		EXAMINER: <i>N/A</i>	
LEVEL: <i>I</i>		LEVEL:		LEVEL:	
<p>This report contains the data associated with the manual ultrasonic examination of RCRD-2-50 ^{see 4/18/07} to meet the requirements of ASME Section XI, category R-A, item number RI.16A. <i>RWCu 2-004-083</i></p> <p>This exam was performed using equipment, procedures and personnel qualified in accordance with ASME Section XI, Appendix VIII as amended by 10CFR50.55a final rule.</p> <p>The component examined was a CS pipe to a cast SS valve piping weld, 4.0" nominal diameter, having single sided access.</p> <p> A 45° shear was used for scan directions 4, 5, and 6. A 60° shear was used for scan direction 4. A 60° RL was used for scan direction 4. A 70° RL was used for scan direction 4. A 42° RL was used for scan directions 5 and 6. </p> <p>Scan direction 3 was not performed due to weld joint configuration (could not scan on the valve body). Scan directions 5 and 6 for the 42° RL could not be performed from the valve body due to cast SS material.</p> <p><u>Obtained exam volumes:</u></p> <p> Lower 1/3T axial scan coverage achieved was 100%. Lower 1/3T circumferential scan coverage was 63%. Full volume axial scan direction coverage was 69.1%. Full volume circumferential scan direction coverage was 65.8%. </p> <p>The reported achieved coverage is 81.5%.</p> <p><i>No recordable indications. Main weld 4/18/07</i></p>					
RESOLUTION BY: <i>W. K. Helms</i>		REVIEWED BY: <i>Mark Walch</i>		ANI: <i>Paul Ford</i>	
LEVEL: <i>I</i> DATE: <i>2/28/07</i>		LEVEL: <i>III</i> DATE: <i>3/19/07</i>		DATE: <i>4/18/07</i>	
				PG. <i>1</i> OF <i>13</i>	

000377

TENNESSEE VALLEY AUTHORITY	MANUAL ULTRASONIC PIPING EXAMINATION DATA SHEET	REPORT NUMBER <u>2123</u>
---------------------------------------	--	-------------------------------------

PROJECT: <u>BFN</u> UNIT/CYCLE <u>2114</u> SYSTEM <u>RWCUS</u> WELD I.D.: <u>RWCU-2-004-083</u> CONFIG.: <u>VLV</u> TO <u>P</u> <div style="text-align: center;"> FLOW </div>	EXAMINATION DATE <u>2/28/07</u> START TIME: <u>1730</u> END TIME: <u>1820</u> EXAM SURFACE <input type="checkbox"/> ID <input checked="" type="checkbox"/> OD MATERIAL TYPE: <input type="checkbox"/> CS <input type="checkbox"/> SS <input type="checkbox"/> CSCL <input checked="" type="checkbox"/> CCSS SURFACE TEMP. <u>82°F</u> PYRO NO. <u>562774</u>
--	--

PROCEDURE: <u>N-UT-82</u> REV: <u>2</u> TC: <u>N/A</u> W ₀ REFERENCE: <u>WELD CENTER LINE</u> L ₀ REFERENCE: <u>TOP DEAD CENTER</u>	EXAMINATION ANGLE <u>45°_{SH}</u> DEG. <u>60°_{SH}</u> DEG. AXIAL SCAN SENSITIVITY <u>38.0</u> dB <u>52.0</u> dB CIRC. SCAN SENSITIVITY <u>42.0</u> dB <u></u> dB
---	---

IND NO.	L (in) FROM REF.			AT MAX AMP			MAX AMP %DAC	EXAM NO. 3-14	NOM. ANG.	NRI	INDICATION INFORMATION: TYPE, DAMPING, ETC.
	L1	L Max	L2	W MAX	MP MAX	O MAX					
								4	45° _{SH}	<input checked="" type="checkbox"/>	
								5	"	<input checked="" type="checkbox"/>	
								6	"	<input checked="" type="checkbox"/>	
1		INT 360		0.65	0.812		100%	4	60° _{SH}	<input type="checkbox"/>	ROOT GEOMETRY INT. 360°
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	

REMARKS/LIMITATIONS NO SCAN #3 DUE TO CONFIGURATION. ROOT GEOMETRY SEEN INT. 360° WITH 60°. NO SERVICE INDUCED INDICATIONS NOTED.

EXAMINER: <u>Walt Helling</u>	LEVEL: <u>II</u>	ANH: <u>Paul Hank</u>
EXAMINER: <u>N/A</u>	LEVEL: <u></u>	DATE: <u>4/18/07</u>
REVIEWED BY: <u>Mark Miller</u>	LEVEL: <u>III</u>	DATE: <u>3/19/07</u>
		PAGE: <u>2</u> OF <u>13</u>

TENNESSEE VALLEY AUTHORITY	MANUAL ULTRASONIC PIPING EXAMINATION DATA SHEET	REPORT NUMBER <u> R123 </u>
---------------------------------------	--	---

SUBJECT: <u>BFN</u> UNIT/CYCLE <u>2114</u> SYSTEM <u>RWCUS</u> WELD I.D.: <u>RWCU-2-004.083</u> CONFIG.: <u>VLV</u> TO <u>P</u> <div style="text-align: center;"> FLOW </div>	EXAMINATION DATE: <u>2/28/07</u> START TIME: <u>1922</u> END TIME: <u>1930</u> EXAM SURFACE <input type="checkbox"/> ID <input checked="" type="checkbox"/> OD MATERIAL TYPE: <input type="checkbox"/> CS <input type="checkbox"/> SS <input type="checkbox"/> CSCL <input checked="" type="checkbox"/> CCSS SURFACE TEMP. <u>82°F</u> PYRO NO. <u>562774</u>
---	---

PROCEDURE: <u>N-UT-82</u> REV: <u>2</u> TC: <u>N/A</u> Wo REFERENCE: <u>WELD CENTERLINE</u> Lo REFERENCE: <u>TOP DEAD CENTER</u>	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:33%;">EXAMINATION ANGLE</td> <td style="width:33%;">42° DEG.</td> <td style="width:33%;">42° DEG.</td> </tr> <tr> <td>AXIAL SCAN SENSITIVITY</td> <td>N/A dB</td> <td>N/A dB</td> </tr> <tr> <td>CIRC. SCAN SENSITIVITY</td> <td>63.0 dB</td> <td>63.0 dB</td> </tr> </table>	EXAMINATION ANGLE	42° DEG.	42° DEG.	AXIAL SCAN SENSITIVITY	N/A dB	N/A dB	CIRC. SCAN SENSITIVITY	63.0 dB	63.0 dB
EXAMINATION ANGLE	42° DEG.	42° DEG.								
AXIAL SCAN SENSITIVITY	N/A dB	N/A dB								
CIRC. SCAN SENSITIVITY	63.0 dB	63.0 dB								

IND NO.	L (in) FROM REF.			AT MAX AMP			MAX AMP %DAC	EXAM NO. 3-14	NOM. ANG.	NRI	INDICATION INFORMATION: TYPE, DAMPING, ETC.
	L1	L Max	L2	W MAX	MP MAX	D MAX					
								5	42° CW	<input checked="" type="checkbox"/>	
								6	42° CCW	<input checked="" type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	

REMARKS/LIMITATIONS SCANS 5 AND 6 WERE PERFORMED USING 42° RL CONTOURED PROBE WITH A 6° ROOF ANGLE NO INDICATIONS NOTED.

EXAMINER: <u>[Signature]</u> LEVEL: <u>II</u> MINER: <u>N/A</u> LEVEL: _____ REVIEWED BY: <u>[Signature]</u> LEVEL: <u>III</u> DATE <u>3/19/07</u>	ANII: <u>[Signature]</u> DATE: <u>4/18/07</u>	PAGE <u>3</u> OF <u>13</u>
--	--	----------------------------

TENNESSEE VALLEY AUTHORITY	MANUAL ULTRASONIC PIPING EXAMINATION DATA SHEET	REPORT NUMBER <u>R123</u>
---------------------------------------	--	-------------------------------------

PROJECT: <u>BFN</u> UNIT/CYCLE <u>2/14</u> SYSTEM <u>RWCUS</u> WELD I.D.: <u>RWCU-2-004-083</u> CONFIG.: <u>VLV</u> TO <u>P</u> <div style="text-align: center;"> FLOW </div>	EXAMINATION DATE <u>2/23/07</u> START TIME: <u>1846</u> END TIME: <u>1910</u> EXAM SURFACE <input type="checkbox"/> ID <input checked="" type="checkbox"/> OD MATERIAL TYPE: <input type="checkbox"/> CS <input type="checkbox"/> SS <input type="checkbox"/> CSCL <input checked="" type="checkbox"/> CCSS SURFACE TEMP. <u>82°F</u> PYRO NO. <u>562774</u>									
PROCEDURE: <u>N-UT-82</u> REV: <u>2</u> TC: <u>N/A</u> W ₀ REFERENCE: <u>WELD CENTERLINE</u> L ₀ REFERENCE: <u>TOP DEAD CENTER</u>	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>EXAMINATION ANGLE</td> <td><u>60°RL</u> DEG.</td> <td><u>70°RL</u> DEG.</td> </tr> <tr> <td>AXIAL SCAN SENSITIVITY</td> <td><u>56.0</u> dB</td> <td><u>65.5</u> dB</td> </tr> <tr> <td>CIRC. SCAN SENSITIVITY</td> <td></td> <td></td> </tr> </table>	EXAMINATION ANGLE	<u>60°RL</u> DEG.	<u>70°RL</u> DEG.	AXIAL SCAN SENSITIVITY	<u>56.0</u> dB	<u>65.5</u> dB	CIRC. SCAN SENSITIVITY		
EXAMINATION ANGLE	<u>60°RL</u> DEG.	<u>70°RL</u> DEG.								
AXIAL SCAN SENSITIVITY	<u>56.0</u> dB	<u>65.5</u> dB								
CIRC. SCAN SENSITIVITY										

IND NO.	L (in) FROM REF.			AT MAX AMP			MAX AMP % DAC	EXAM NO. 3-14	NOM. ANG.	NRI	INDICATION INFORMATION: TYPE, DAMPING, ETC.
	L1	L Max	L2	W MAX	MP MAX	D MAX					
1		<u>INT 360</u>		<u>.675"</u>	<u>0.82</u>		<u>100%</u>	<u>4</u>	<u>60</u>	<input type="checkbox"/>	<u>ROOT GEOMETRY</u>
								<u>4</u>	<u>70</u>	<input checked="" type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	

REMARKS/LIMITATIONS ROOT GEOMETRY SEEN INT. 360° PREVIOUSLY RECORDED
NO OTHER RELEVANT IND. NOTED.

EXAMINER: <u>John H. [Signature]</u> LEVEL: <u>II</u> MINER: <u>N/A</u> LEVEL: <u></u> REVIEWED BY: <u>Alan Wilder</u> LEVEL: <u>III</u> DATE <u>3/19/07</u>	ANI: <u>Paul Flord</u> DATE: <u>4/18/07</u>	PAGE <u>4</u> OF <u>13</u>
--	--	----------------------------


C00980

<h1>TVA</h1>	<h2>WALL THICKNESS PROFILE SHEET</h2>	REPORT NO: R123
--------------	---------------------------------------	---------------------------


PROJECT: <u>BFN</u>	WELD NO: <u>RWCU-2-004-083</u>
UNIT: <u>2</u>	SYSTEM: <u>RWCU</u>

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	N/A	/		
2	N/A	/		
3	.5		N/A	
4	.36			/
5	.36			/



CROWN HEIGHT: <u>ISI PREP</u>	DIAMETER: <u>4.5"</u>
CROWN WIDTH: <u>.5</u>	WELD LENGTH: <u>14.1"</u>




EXAMINER: <u>[Signature]</u>	REVIEWED BY: <u>[Signature]</u>	ANII: <u>[Signature]</u>
LEVEL: <u>II</u>	LEVEL: <u>III</u>	DATE: <u>4/18/07</u>
DATE: <u>2/27/07</u>	DATE: <u>3/19/07</u>	PAGE <u>3</u> OF <u>13</u>

TVA	WALL THICKNESS PROFILE SHEET	REPORT NO: R123
------------	---	---------------------------


PROJECT: <u>BFJ</u>	WELD NO: <u>RWCU-2-004-083</u>
UNIT: <u>2</u>	SYSTEM: <u>RWCU</u>

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	N/A			
2	N/A			
3	.5		N/A	
4	.36			
5	.36			



CROWN HEIGHT: <u>ISI PREP</u>	DIAMETER: <u>4.5"</u>
CROWN WIDTH: <u>.5</u>	WELD LENGTH: <u>14.1"</u>



ROOT GEOMETRY SEEN INT. 360°

FEEDING WELD MET = $(.4 \times 14.1) + (.36 \times 14.1) = 2.9$ cable inches

PROFILING WELD MET = $(.4 \times 14.1) + (.36 \times 14.1) = 7.13$ cable inches
Walter Wedel 3/19/07

EXAMINER: <u>Walter Wedel</u>	REVIEWED BY: <u>Walter Wedel</u>	ANII: <u>Carl Flood</u>
LEVEL: <u>II</u>	LEVEL: <u>III</u>	DATE: <u>2/18/07</u>
DATE: <u>2/19/07</u>	DATE: <u>3/19/07</u>	PAGE <u>6</u> OF <u>13</u>

TVA



Office of Nuclear Power

PROJECT: BFN SYSTEM: RWCUS

Unit: U2C14 WELD NO.: RWCU-2-004-083

REPORT NO.:

R123



OBTAINED EXAM NUMBERS:

LOWER 1/2 T AXIAL SIGNATURE = NO LOWER 1/2 T SIGNATURE

LOWER 1/2 T AXIAL SIGNATURE = NO LOWER 1/2 T SIGNATURE

LOWER 1/2 T AXIAL SIGNATURE = NO LOWER 1/2 T SIGNATURE

LOWER 1/2 T AXIAL SIGNATURE = NO LOWER 1/2 T SIGNATURE

Walter Welch III
3/19/07

BY: Walter Welch

LEVEL: III


DATE: 3/19/07

PAGE 7 OF 13

000383

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER: <i>R123</i>
-------------------------------	---	-------------------------------

PROJECT: <i>BFN UNIT 2</i>	CYCLE: <i>14</i>	CALIBRATION DATE: <i>2/28/07</i>
PROC.: <i>N-UT-82</i>	REV: <i>2</i>	TC: <i>N/A</i>
INSTR. MFG: <i>KRAUTKRAMER</i>	DUE DATE: <i>12/11/07</i>	SIMULATOR BLOCK NO: <i>N/A</i>
MODEL TYPE: <i>USN-60</i>	M & TE NO: <i>E34054</i>	THERMOMETER S/N: <i>562774</i>
TRANSducer MFG: <i>KBA</i>	COUPLANT	BATCH:
ELEMENTS: <i>1</i>	SHAPE: <i>ROUND</i>	<i>ULTRAGEL II</i> <i>04125</i>
S/N <i>0156YP</i>	SIZE: <i>0.25"</i>	FREQ: <i>5.0</i> MHz
CONTOUR: <i>FLAT</i>	FOCUS: <i>N/A</i>	EXAM TYPE: <input checked="" type="checkbox"/> SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RL <input type="checkbox"/>
CABLE TYPE: <i>RG-174</i>	LENGTH: <i>72"</i>	ANGLE VERIFICATION
	DAC	BLOCK TYPE: <i>CS RUMPLS</i>
		S/N: <i>790918</i>
		NOMINAL ANGLE: <i>45°</i>
		ACTUAL ANGLE: <i>44°</i>



INSTRUMENT SETTINGS			
REFLECTOR			REFERENCE
SCAN DIRECT	NTCH	SDH	SENSITIVITY
ANAL	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>28.0</i> dB
CIRC	<input type="checkbox"/>	<input type="checkbox"/>	<i>45.25</i> .5
RANGE	<i>1.0"</i>		INST. FREQ <i>5.0</i> MHz
PROBE DELAY:	<i>3.7184</i>		*RECTIFY: <i>FULLWAVE</i>
VELOCITY:	<i>0.1270</i>		DUAL <input type="checkbox"/> ON <input checked="" type="checkbox"/> OFF
DISPLAY DELAY:	<i>0.0</i>		*REJECT: <i>0</i> %
*ENERGY:	<i>HIGH</i>		*DISPLAY START <i>IP</i>
*DAMPING:	<i>1K</i>		DET: <input type="checkbox"/> PEAK <input checked="" type="checkbox"/> FLANK
*PRF MODE:	<i>AUTO HIGH</i>		TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>

REF. REFLECTOR: <i>.5" NOTCH</i>	GAIN dB: <i>28.0</i>	CALIBRATION TIMES	
AMPLITUDE: <i>80%</i>	METAL PATH: <i>0.692</i>	INITIAL TIME: <i>1342</i>	FINAL TIME: <i>1846</i>
VERIFICATION TIMES	1) <i>1840</i>	2) <i>N/A</i>	3) <i>→</i>

* PDI QUALIFIED INSTRUMENT SETTINGS:
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2
 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK											
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20	10
	SIGNAL 2	50	45	40	35	30	25	20	15	10	5
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6			
	AMP	80	32-43	16-24	20	64-96	40	64-96			
			<i>40</i>	<i>20</i>		<i>80</i>		<i>80</i>			


COMMENTS:	WELDS/ITEMS EXAMINED:
	<i>RCRD-2-49, RCRD-2-52</i>
	<i>RWCU-2-004-083</i>

EXAMINER: <i>Whit Hollum</i>	EXAMINER: <i>N/A</i>	REVIEWER: <i>Mark Wulfe</i>	ANI: <i>Paul Shank</i>
LEVEL: <i>II</i>	LEVEL:	DATE: <i>3/19/07</i>	DATE: <i>4/18/07</i>
		PG. <i>8</i> OF <i>13</i>	

000384

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER: <i>R123</i>
-------------------------------	---	-------------------------------

PROJECT: <i>BFN UNIT 2</i>	CYCLE: <i>14</i>	CALIBRATION DATE: <i>2/28/07</i>
PROC.: <i>N-UT-82</i>	REV: <i>2</i>	TC: <i>N/A</i>
INSTR. MFG: <i>KRAUTKRAMER</i>	DUE DATE: <i>12/11/07</i>	SIMULATOR BLOCK NO: <i>N/A</i>
MODEL/TYPE: <i>USN-60</i>	M&TE NO: <i>E34054</i>	THERMOMETER S/N: <i>562774</i>
DUE DATE: <i>12/12/07</i>		
TRANSDUCER MFG: <i>KBA</i>	COUPLANT	BATCH
ELEMENTS <i>1</i>	SHAPE <i>ROUND</i>	<i>ULTRAGEL II</i>
		<i>04125</i>
S/N <i>0156YP</i>	SIZE: <i>0.25"</i>	FREQ: <i>5.0</i> MHz
CONTOUR: <i>FLAT</i>	FOCUS: <i>N/A</i>	EXAM TYPE: <input checked="" type="checkbox"/> SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RI <input type="checkbox"/>
CABLE TYPE: <i>RG-174</i>	LENGTH: <i>72"</i>	ANGLE VERIFICATION
DAC		BLOCK TYPE: <i>CS ROMPAS</i>
		S/N: <i>790918</i>
		NOMINAL ANGLE: <i>60°</i>
		ACTUAL ANGLE: <i>57°</i>



INSTRUMENT SETTINGS				
REFLECTOR			REFERENCE	MEASUREMENT
STANDARD	NTCH	SDI	SENSITIVITY	NUMBER
ANG	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>45.0</i> dB	<i>60° 25</i>
CIRC	<input type="checkbox"/>	<input type="checkbox"/>	dB	
RANGE	<i>1.5"</i>		INST. FREQ	<i>5.0</i> MHz
PROBE DELAY:	<i>5.0478</i>		RECTIFY:	<i>FULL WAVE</i>
VELOCITY:	<i>0.1270</i>		DUAL	<input type="checkbox"/> ON <input checked="" type="checkbox"/> OFF
DISPLAY DELAY:	<i>0.0</i>		REJECT:	<i>0 %</i>
ENERGY:	<i>HIGH</i>		DISPLAY START	<i>IP</i>
DAMPING:	<i>1K</i>		DET:	<input type="checkbox"/> PEAK <input checked="" type="checkbox"/> FLANK
PRF MODE:	<i>AUTO HIGH</i>		TCG:	<input type="checkbox"/> ON <input checked="" type="checkbox"/> OFF

DISPLAY WIDTH: inches *1.5"*

REF. REFLECTOR: <i>5" NOTCH</i>	GAIN: <i>45.0</i> dB	CALIBRATION TIMES	
AMPLITUDE: <i>80%</i>	METAL PATH: <i>.905</i>	INITIAL TIME: <i>1345</i>	FINAL TIME: <i>1820</i>
VERIFICATION TIMES	<i>1 1805</i>	<i>2</i>	<i>3</i>
	<i>4</i>	<i>5</i>	<i>6</i>
	<i>7</i>	<i>8</i>	<i>9</i>

* PDI QUALIFIED INSTRUMENT SETTINGS:
VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL 1		100	90	80	70	60	50	40	30	20	10
	SIGNAL 2		50	45	40	35	30	25	20	15	10	5
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6				
	AMP	80	32-43	16-24	20	64-96	40	64-96				
			40	20		80		80				


COMMENTS:	WELDS/ITEMS EXAMINED:
	<i>RCRD-2-49; RCRD-2-52</i>
	<i>RWCU-2-004-083</i>

EXAMINER: <i>Walter Wilch</i>	EXAMINER: <i>N/A</i>	REVIEWER: <i>Walter Wilch</i>	ANI: <i>Paul Hund</i>
LEVEL: <i>II</i>	LEVEL:	DATE: <i>2/19/07</i>	DATE: <i>4/18/07</i>
		PG. <i>9</i> OF <i>13</i>	

000385

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER: <i>R123</i>
-------------------------------	---	-------------------------------

PROJECT: <i>BFN UNIT 2</i>	CYCLE: <i>14</i>	CALIBRATION DATE: <i>2/28/07</i>
PROC.: <i>N-UT-82</i>	REV: <i>2</i> TC: <i>N/A</i>	CALIBRATION BLOCK NO.: <i>BF-132</i> TEMP: <i>72. F</i>
INSTR. MFG: <i>KRAUTKRAMER</i>	DUE DATE: <i>12/11/07</i>	SIMULATOR BLOCK NO.: <i>N/A</i>
MODEL TYPE: <i>USN-60</i>	M & TE NO.: <i>E34054</i>	THERMOMETER S/N: <i>562774</i> DUE DATE: <i>12/12/07</i>
TRANSDUCER MFG: <i>MEGASONICS</i>	COUPLANT BATCH:	
ELEMENTS: <i>2</i> SHAPE: <i>RECT</i>	<i>ULTRAGEL II</i> <i>04125</i>	
S/N <i>U0270</i> SIZE: <i>2(4x12)</i> FREQ: <i>2.0</i> MHz	EXAM TYPE: SHEAR <input type="checkbox"/>	LONG <input type="checkbox"/> RI <input checked="" type="checkbox"/>
CONTOUR: <i>60" 6° CW TAPER</i> FOCUS: <i>FS-14 mm</i>	ANGLE VERIFICATION	
CABLE TYPE: <i>2(RG-174)</i> LENGTH: <i>72"</i> #CNT: <i>0</i>	BLOCK TYPE:	S/N: <i>BF-132</i>
DAC	NOMINAL ANGLE: <i>42°</i>	ACTUAL ANGLE: <i>42°</i>



INSTRUMENT SETTINGS			
REFLECTOR			REFERENCE
SCAN DIRECT.	NTCH	SDH	SENSITIVITY
AXIAL	<input type="checkbox"/>	<input type="checkbox"/>	dB
CIRC	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<i>57.0</i> dB
RANGE: <i>1.5"</i>			*INST. FREQ.: <i>2.0</i> MHz
PROBE DELAY: <i>4.2459</i>			*RECTIFY: <i>FULLWAVE</i>
VELOCITY: <i>.2367</i>			DUAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF
DISPLAY DELAY: <i>0.0</i>			*REJECT: <i>0</i> %
*ENERGY: <i>HIGH</i>			*DISPLAY START: <i>IP</i>
*DAMPING: <i>1K</i>			DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK
*PRF MODE: <i>AUTOHIGH</i>			TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>

REF. REFLECTOR: <i>.4" 50H</i>	GAIN: dB <i>57</i>	CALIBRATION TIMES			
AMPLITUDE: <i>80%</i>	METAL PATH: <i>.662</i>	INITIAL TIME: <i>1405</i>	FINAL TIME: <i>1926</i>		
VERIFICATION TIMES	1) <i>1922</i>	2) _____	3) _____	4) _____	5) _____

* PDI QUALIFIED INSTRUMENT SETTINGS:
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2
 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!


LINEARITY CHECK											
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20	10
	SIGNAL 2	50	45	40	35	30	25	20	15	10	5
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6			
	AMP	80	32-48	16-24	20	64-96	40	64-96			
			40	20	80		80				

COMMENTS: <i>① CIRC SCAN CONTOUR</i>	WELDS/ITEMS EXAMINED: <i>RWCU-2-004-083</i>
--------------------------------------	--

EXAMINER: <i>[Signature]</i>	EXAMINER: <i>N/A</i>	REVIEWER: <i>[Signature]</i>	ANI: <i>[Signature]</i>
LEVEL: <i>II</i>	LEVEL:	DATE: <i>3/19/07</i>	DATE: <i>4/16/07</i>
		PG. <i>10</i>	OF <i>13</i>

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER: <i>R123</i>
-------------------------------	---	-------------------------------

PROJECT: <i>BFN UNIT 2</i>	CYCLE: <i>14</i>	CALIBRATION DATE: <i>2/28/07</i>
PROC.: <i>N-UT-82</i>	REV: <i>2</i> TC: <i>N/A</i>	CALIBRATION BLOCK NO.: <i>BF-132</i> TEMP: <i>72.°F</i>
INSTR. MFG: <i>KRAUTKRAMER</i>	DUE DATE: <i>12/11/07</i>	SIMULATOR BLOCK NO.: <i>N/A</i>
MODEL TYPE: <i>USN-60</i>	M & TE NO.: <i>E34054</i>	THERMOMETER S/N: <i>562774</i> DUE DATE: <i>12/12/07</i>
TRANSDUCER MFG: <i>MEGASONICS</i>	COUPLANT BATCH:	
ELEMENTS: <i>2</i> SHAPE: <i>RECT.</i>	<i>ULTRAGEL II</i> <i>04125</i>	
S/N <i>U0271</i> SIZE: <i>2(4x12)</i>	FREQ: <i>2.0</i> MHz	EXAM TYPE: SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RL <input checked="" type="checkbox"/>
CONTOUR: <i>60°00</i> <i>6°CCU TARE</i>	FOCUS: <i>FS=14 mm</i>	ANGLE VERIFICATION
CABLE TYPE: <i>2(RG-174)</i>	LENGTH: <i>72"</i> #CNT: <i>0</i>	BLOCK TYPE: S/N: <i>BF-132</i>
DAC	NOMINAL ANGLE: <i>42°</i>	ACTUAL ANGLE: <i>42°</i>



DISPLAY WIDTH: inches 1.5"

INSTRUMENT SETTINGS				
REFLECTOR			REFERENCE	MEMORY
SCAN DIRECT.	NTCH	SDH	SENSITIVITY	NUMBER
AXIAL	<input type="checkbox"/>	<input type="checkbox"/>	dB	
CIRC	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<i>570</i> dB	<i>U0271</i>
RANGE:	<i>1.5"</i>		*INST. FREQ.: <i>2.0</i> Mhz	
PROBE DELAY:			*RECTIFY: <i>FULLWAVE</i>	
VELOCITY:	<i>.2367</i>		DUAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF	
DISPLAY DELAY:	<i>0.0</i>		*REJECT: <i>0</i> %	
*ENERGY:	<i>HIGH</i>		*DISPLAY START: <i>IP</i>	
*DAMPING:	<i>1K</i>		DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK	
*PRF MODE:	<i>AUTO HIGH</i>		TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>	

REF. REFLECTOR: <i>4" SDH</i>	GAIN: dB <i>57.0</i>	CALIBRATION TIMES	
AMPLITUDE: <i>802</i>	METAL PATH: <i>0.630</i>	INITIAL TIME: <i>1407</i>	FINAL TIME: <i>1930</i>
VERIFICATION TIMES	1) <i>1920</i>	2) _____	3) _____
	4) _____	5) _____	6) _____
	7) _____	8) _____	9) _____

* PDI QUALIFIED INSTRUMENT SETTINGS:
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2
 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK											
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20	10
	SIGNAL 2	50	45	40	35	30	25	20	15	10	5
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6			
	AMP	80	32-48	16-24	20	64-96	40	64-96			
			<i>40</i>	<i>20</i>		<i>80</i>		<i>80</i>			


COMMENTS: <i>① CIRC SCAN CONTOUR</i>	WELDS/ITEMS EXAMINED: <i>RWCU-2-004-083</i>
--------------------------------------	--

EXAMINER: <i>Steve Hildner</i>	EXAMINER: <i>N/A</i>	REVIEWER: <i>Walter Welch</i>	ANI: <i>Paul Howard</i>
LEVEL: <i>II</i>	LEVEL:	DATE: <i>3/19/07</i>	DATE: <i>4/18/07</i>
		PG. <i>11</i> OF <i>13</i>	

000387

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER: <i>R123</i>
-------------------------------	---	-------------------------------

PROJECT: <i>BFN UNIT 2</i>	CYCLE: <i>14</i>	CALIBRATION DATE: <i>2/28/07</i>
PROC.: <i>N-UT-82</i>	REV: <i>2</i>	TC: <i>N/A</i>
INSTR. MFG: <i>KRAUTKRAMER</i>	DUE DATE: <i>12/11/07</i>	SIMULATOR BLOCK NO: <i>N/A</i>
MODELTYPE: <i>USN-60</i>	M & TE NO.: <i>E34054</i>	THERMOMETER S/N: <i>562774</i>
TRANSducer MFG: <i>MEGASONICS</i>	COUPLANT	BATCH:
ELEMENTS: <i>2</i>	SHAPE: <i>RECT.</i>	<i>ULTRAGEL II</i>
S/N <i>U0109</i>	SIZE: <i>2(10x18)</i>	FREQ: <i>2.0</i> MHz
CONTOUR: <i>6.0" OD AXIAL</i>	FOCUS: <i>FS = 17 mm</i>	EXAM TYPE: SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RL <input checked="" type="checkbox"/>
CABLE TYPE: <i>2 (RG-174)</i>	LENGTH: <i>72"</i>	#CNT: <i>0</i>
DAC	BLOCK TYPE:	S/N: <i>BF-131</i>
	NOMINAL ANGLE: <i>60°</i>	ACTUAL ANGLE: <i>57.0</i>



DISPLAY WIDTH: inches *1.5"*

INSTRUMENT SETTINGS				
REFLECTOR			REFERENCE	MEMORY
SCAN DIRECT.	NTCH	SDH	SENSITIVITY	NUMBER
AXIAL	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<i>56.0</i> dB	<i>U0109</i>
CIRC	<input type="checkbox"/>	<input type="checkbox"/>	<i>N/A</i> dB	<i>N/A</i>
RANGE:	<i>1.5"</i>		*INST. FREQ: <i>2.0</i> MHz	
PROBE DELAY:	<i>7.1650</i>		*RECTIFY: <i>FULLWAVE</i>	
VELOCITY:	<i>.2367</i>		DUAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF	
DISPLAY DELAY:	<i>0.0</i>		*REJECT: <i>0 %</i>	
*ENERGY:	<i>HIGH</i>		*DISPLAY START: <i>IP</i>	
*DAMPING:	<i>1K</i>		DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK	
*PRF MODE:	<i>AUTOHIGH</i>		TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>	

REF. REFLECTOR: <i>.4" SDH</i>	GAIN: dB <i>56.0</i>	CALIBRATION TIMES			
AMPLITUDE: <i>80%</i>	METAL PATH: <i>0.690</i>	INITIAL TIME: <i>1350</i>	FINAL TIME: <i>1857</i>		
VERIFICATION TIMES	1) <i>1846</i>	2) <i>N/A</i>	3)	4)	5)

* PDI QUALIFIED INSTRUMENT SETTINGS:
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2
 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK												
VERTICAL	SIGNAL 1		100	90	80	70	60	50	40	30	20	10
	SIGNAL 2		50	45	40	35	30	25	20	15	10	5
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6				
	AMP	80	32-48	16-24	20	64-96	40	64-96				
			40	20		80		80				

COMMENTS:	WELDS/ITEMS EXAMINED:
	<i>RCRD-2-49; RCRD-2-52</i>
	<i>RWCU-2-004-083</i>

EXAMINER: <i>Jack Hill</i>	EXAMINER: <i>N/A</i>	REVIEWER: <i>Walter Welch</i>	ANII: <i>Paul J. Hill</i>
LEVEL: <i>II</i>	LEVEL:	DATE: <i>3/19/07</i>	DATE: <i>4/18/07</i>
		LEVEL: <i>III</i>	PG. <i>12</i> OF <i>13</i>

000388

TENNESSEE VALLEY AUTHORITY		DIGITAL ULTRASONIC CALIBRATION DATA SHEET			REPORT NUMBER: <i>R123</i>								
PROJECT: <i>BFN UNIT 2</i>		CYCLE: <i>14</i>		CALIBRATION DATE: <i>2/28/07</i>									
PROC.: <i>N-UT-82</i>		REV: <i>2</i>		TC: <i>N/A</i>		CALIBRATION BLOCK NO.: <i>BF-131</i> TEMP: <i>72. F</i>							
INSTR. MFG: <i>KRAUTKRAMER</i> DUE DATE: <i>12/11/07</i>				SIMULATOR BLOCK NO.: <i>N/A</i>									
MODEL TYPE: <i>USN-60</i> M & TE NO.: <i>E34054</i>				THERMOMETER S/N: <i>562774</i> DUE DATE: <i>12/12/07</i>									
TRANSducer MFG: <i>MEGASONICS</i>				COUPLANT		BATCH:							
ELEMENTS: <i>2</i> SHAPE: <i>RECT.</i>				<i>ULTRAGEL II</i>		<i>04125</i>							
S/N <i>U0110</i>		SIZE: <i>2(10x18)</i>		FREQ: <i>2.0</i> MHz		EXAM TYPE: SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RI <input checked="" type="checkbox"/>							
CONTOUR: <i>6.0" OD AXIAL</i> FOCUS: <i>FS-28</i>				ANGLE VERIFICATION									
CABLE TYPE: <i>2(RG-174)</i> LENGTH: <i>72"</i> #CNT: <i>0</i>				BLOCK TYPE:		S/N: <i>BF-131</i>							
DAC				NOMINAL ANGLE: <i>70°</i>		ACTUAL ANGLE: <i>67°</i>							
				INSTRUMENT SETTINGS									
				REFLECTOR			REFERENCE		MEMORY				
				SCAN DIRECT. NTCH SDH			SENSITIVITY		NUMBER				
				AXIAL <input type="checkbox"/> <input checked="" type="checkbox"/>			<i>65.5</i> dB		<i>U0110</i>				
				CIRC <input type="checkbox"/> <input type="checkbox"/>			<i>N/A</i> dB		<i>N/A</i>				
				RANGE: <i>2.0</i>			*INST. FREQ: <i>2.0</i> MHz						
				PROBE DELAY: <i>7.9159</i>			*RECTIFY: <i>FULLWAVE</i>						
				VELOCITY: <i>.2367</i>			DUAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF						
				DISPLAY DELAY: <i>0.0</i>			*REJECT: <i>0</i> %						
				*ENERGY: <i>HIGH</i>			*DISPLAY START: <i>IP</i>						
*DAMPING: <i>1K</i>			DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK										
*PRF MODE: <i>AUTOHIGH</i>			TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>										
REF. REFLECTOR: <i>.4" 50H</i> GAIN: dB <i>65.5</i>				CALIBRATION TIMES									
AMPLITUDE: <i>80%</i>		METAL PATH: <i>945</i>		INITIAL TIME: <i>1355</i>		FINAL TIME: <i>1910</i>							
VERIFICATION TIMES		1) <i>1857</i>	2) <i>N/A</i>	3)	4)	5)	6)						
* PDI QUALIFIED INSTRUMENT SETTINGS: VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!													
LINEARITY CHECK													
VERTICAL		SIGNAL 1	100	90	80	70	60	50	40	30	20	10	
		SIGNAL 2	50	45	40	35	30	25	20	15	10	5	
ATTENUATOR		GAIN	SET	-6 dB		-12 dB		SET		+12		SET	+6
		AMP	80	32-48	16-24	20	64-96	40	64-96	80	80		
COMMENTS:				WELDS/ITEMS EXAMINED:									
				<i>RCRD-2-49; RCRD-2-52</i>									
				<i>RWCU-2-004-083</i>									
EXAMINER: <i>Shane H. [Signature]</i>		EXAMINER: <i>N/A</i>		REVIEWER: <i>Walter Weber</i>		ANI: <i>[Signature]</i>							
LEVEL: <i>II</i>		LEVEL:		LEVEL: <i>III</i> DATE: <i>3/19/07</i>		DATE: <i>4/18/07</i>							
						PG. OF <i>13</i> OF <i>13</i>							

Examination Report No. R-171

Weld No. CRD-2-005-003

000376

TENNESSEE VALLEY AUTHORITY		EXAMINATION SUMMARY AND RESOLUTION DATA SHEET		REPORT NUMBER: <i>R171</i>	
PROJECT: BFN UNIT: 2		CYCLE: 14	COMPONENT ID: CRD-2-005-003		
EXAMINATION METHOD			SYSTEM: RWCUS	ISI DWG. NO. 2-ISI-0272-C-01	
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CODE CLASS: NA	CATEGORY: R-A
PROCEDURE: N-UT-82		REV:2	TC:NA	CONFIG.:	C/S Pipe TO S/S Valve
EXAMINER: Patrick Mahoney		EXAMINER: NA		EXAMINER: NA	
LEVEL: II		LEVEL:		LEVEL:	

This report contains the data associated with the manual ultrasonic examination of CRD-2-003-005 to meet the requirements of BERVIP-75-A, category D and ASME Section XI, category R-A, item number R1.16D, exreq P95-96 for pre-service examinations. *4/10/07*

This exam was performed using equipment, procedures and personnel qualified in accordance with ASME Section XI, Appendix VIII as amended by 10CFR50.55a final rule.

The component examined was a CS pipe to a forged SS valve piping weld, 4.0" nominal diameter, having single side access.

A 45° shear was used for scan directions 4, 5, and 6.

A 60° shear was used for scan direction 4.

A 45° RL was used for scan direction 4, 5 and 6.

A 60° RL was used for scan direction 4.

A 70° RL was used for scan direction 4.

Scan direction 3 was not performed from the valve body due to surface condition.

Scan directions 5 and 6 for the 45° RL could not be performed from the valve body due surface condition.

Axial scan coverage achieved for the 45° and 60° RL wave modes was 52.6%.

Circumferential scan coverage achieved for the 45° RL wave modes was 77%.

Combined axial and circumferential coverage was 64.8%.

Ref: W/O# 07-713160-000.

RESOLUTION BY: <i>Patrick Mahoney</i> PATRICK MAHONEY	REVIEWED BY: <i>Patrick Mahoney</i>	ANII: <i>John H. H. H.</i>
LEVEL: II DATE: <i>4/10/07</i>	LEVEL: III DATE: <i>4/10/07</i>	DATE: <i>5/2/07</i>
		PG. <i>1</i> OF <i>10</i>

000378

TENNESSEE VALLEY AUTHORITY		DIGITAL ULTRASONIC CALIBRATION DATA SHEET				REPORT NUMBER: <i>R171</i>							
PROJECT: BFN UNIT 2		CYCLE: 14		CALIBRATION DATE: 04/01/2007									
PROC.: N-UT-82		REV: 2		TC: N/A		CALIBRATION BLOCK NO.: SQ-116		TEMP: 75°F					
INSTR. MFG: KRAUTKRAMER		DUE DATE: 08/21/07		SIMULATOR BLOCK NO: 790662									
MODEL/TYPE: USN-60		M & TE NO.: E36302		THERMOMETER S/N: 562774		DUE DATE: 12/12/07							
TRANSDUCER MFG: KBA		COUPLANT ULTRAGEL II BATCH: 05325											
S/N 00W40F		SIZE: .375		FREQ: 2.25 MHz		EXAM TYPE: SHEAR <input checked="" type="checkbox"/>		LONG <input type="checkbox"/>		RI <input type="checkbox"/>			
CABLE TYPE: RG-174		LENGTH: 72 inches		ANGLE VERIFICATION									
DAC				BLOCK TYPE: ROMPAS		S/N: 790662							
				NOMINAL ANGLE: 60		ACTUAL ANGLE: 57							
INSTRUMENT SETTINGS													
REFLECTOR						REFERENCE		MEMORY					
SCAN DIRECT.		NTCH	SDH		SENSITIVITY		NUMBER						
AXIAL		<input checked="" type="checkbox"/>	<input type="checkbox"/>		43.5 dB		PAC-60SS						
CIRC		<input type="checkbox"/>	<input type="checkbox"/>		N/A dB								
RANGE: 1.62						*INST. FREQ.: 2.25 Mhz							
PROBE DELAY: 6.4938						*RECTIFY: F.W.							
VELOCITY: .1297						DUAL <input type="checkbox"/> ON <input checked="" type="checkbox"/> OFF							
DISPLAY DELAY: 0.0						*REJECT: 0 % % %							
*ENERGY: HIGH						*DISPLAY START: I.P.							
*DAMPING: 1000 Ohms						DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK							
*PRF MODE: AUTO HIGH						TCG: ON <input type="checkbox"/>		OFF <input checked="" type="checkbox"/>					
CALIBRATION TIMES													
REF. REFLECTOR: SDH						GAIN: dB 40							
AMPLITUDE: 80						METAL PATH: .588							
INITIAL TIME: 1400		FINAL TIME: 1645											
VERIFICATION TIMES		1)1430	2)1515	3)1540	4)1555	5)1610	6)N/A	7)N/A	8)N/A	9)N/A			
* PDI QUALIFIED INSTRUMENT SETTINGS: VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE !													
LINEARITY CHECK													
VERTICAL	SIGNAL 1		100	90	80	70	60	50	40	30	20	10	
	SIGNAL 2		50	45	40	35	30	25	20	15	10	05	
ATTENUATOR	GAIN	SET	-6 dB		-12 dB		SET		+12		SET		+6
	AMP	80	32-48		16-24		20		64-96		40		64-96
			40		20				80				80
COMMENTS: SEE ATTACHED						WELDS/ITEMS EXAMINED:							
						CRD-2-005-003							
EXAMINER: <i>Robert W. [Signature]</i>			EXAMINER: <i>N/A</i>			REVIEWER: <i>Mark [Signature]</i>			ANI: <i>[Signature]</i>				
LEVEL: <i>I</i>			LEVEL:			LEVEL: <i>III</i>			DATE: <i>5/2/07</i>				
						DATE: <i>4/10/07</i>			PG. <i>3</i> OF <i>10</i>				

000379

TENNESSEE VALLEY AUTHORITY			DIGITAL ULTRASONIC CALIBRATION DATA SHEET				REPORT NUMBER: <i>R171</i>							
PROJECT: BFN UNIT 2			CYCLE: 14		CALIBRATION DATE: 04/01/2007									
PROC.: N-UT-82			REV: 2		TC: N/A		CALIBRATION BLOCK NO.: SQ-116		TEMP: 75°F					
INSTR. MFG: KRAUTKRAMER			DUE DATE: 08/21/07			SIMULATOR BLOCK NO.: 790662								
MODEL/TYPER: USN-60			M & TE NO.: E36302			THERMOMETER S/N: 562774		DUE DATE: 12/12/07						
TRANSDUCER MFG: KBA						COUPLANT ULTRAGEL II BATCH: 05325								
S/N 00W40F			SIZE: .375		FREQ: 2.25 MHz		EXAM TYPE: SHEAR <input checked="" type="checkbox"/>		LONG <input type="checkbox"/> RL <input type="checkbox"/>					
CABLE TYPE: RG-174			LENGTH: 72 inches			ANGLE VERIFICATION								
DAC						BLOCK TYPE: ROMPAS		S/N: 790662						
						NOMINAL ANGLE: 70		ACTUAL ANGLE: 67						
<p>DISPLAY WIDTH: inches <u>2.2</u></p>						INSTRUMENT SETTINGS								
						REFLECTOR			REFERENCE		MEMORY			
						SCAN DIRECT		NTCH	SDH		SENSITIVITY		NUMBER	
						AXIAL		<input checked="" type="checkbox"/>	<input type="checkbox"/>		50.0	dB	PAC-70SS	
						CIRC		<input type="checkbox"/>	<input type="checkbox"/>		N/A	dB		
						RANGE: 2.2			*INST. FREQ.: 2.25 Mhz					
						PROBE DELAY: 6.1662			*RECTIFY: F.W.					
						VELOCITY: 1270			DUAL <input type="checkbox"/> ON <input checked="" type="checkbox"/> OFF					
						DISPLAY DELAY: 0.0			*REJECT: 0 % % %					
						*ENERGY: HIGH			*DISPLAY START: I.P.					
*DAMPING: 1000 Ohms			DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK											
*PRF MODE: AUTO HIGH			TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>											
REF. REFLECTOR: SDH						GAIN: dB 42		CALIBRATION TIMES						
AMPLITUDE: 80			METAL PATH: .88			INITIAL TIME: 1400		FINAL TIME: 1645						
VERIFICATION TIMES		1)1430	2)1515	3)1540	4)1555	5)1610	6)N/A	7)N/A	8)N/A	9)N/A				
* PDI QUALIFIED INSTRUMENT SETTINGS: VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE !														
LINEARITY CHECK														
VERTICAL	SIGNAL 1		100	90	80	70	60	50	40	30	20	10		
	SIGNAL 2		50	45	40	35	30	25	20	15	10	05		
ATTENUATOR	GAIN	SET	-6 dB		-12 dB		SET		+12		SET		+6	
	AMP	80	32-48		16-24		20		64-96		40		64-96	
			40	20			80			80				
COMMENTS: SEE ATTACHED						WELDS/ITEMS EXAMINED:								
						CRD-2-005-003								
EXAMINER: <i>John W. Jones</i>			EXAMINER: <i>W. J. A.</i>			REVIEWER: <i>Walter Welch</i>			ANI: <i>John Flunk</i>					
LEVEL: <i>II</i>			LEVEL:			LEVEL: <i>III</i>			DATE: <i>5/2/07</i>					
						DATE: <i>4/10/07</i>			PG. <i>4</i> OF <i>10</i>					

000381


TENNESSEE VALLEY AUTHORITY		DIGITAL ULTRASONIC CALIBRATION DATA SHEET				REPORT NUMBER: <i>R171</i>					
PROJECT: BFN UNIT 2		CYCLE: 14		CALIBRATION DATE: 04/01/2007							
PROC.: N-UT-82		REV:2		TC:N/A		CALIBRATION BLOCK NO.: BF-131		TEMP: 75°F			
INSTR. MFG: KRAUTKRAMER		DUE DATE: 08/21/07		SIMULATOR BLOCK NO.: BF-131							
MODEL/TYPER: USN-60		M & TE NO.: E36302		THERMOMETER S/N: 562774		DUE DATE: 12/12/07					
TRANSDUCER MFG: MEGASONIC		COUPLANT ULTRAGEL II BATCH: 05325									
S/N: SN-0109 <i>228307</i>		SIZE: 10X18		FREQ: 2.0 MHz		EXAM TYPE: SHEAR <input type="checkbox"/>		LONG <input type="checkbox"/>		RI <input checked="" type="checkbox"/>	
CABLE TYPE: RG-174		LENGTH: 72 inches		ANGLE VERIFICATION							
DAC				BLOCK TYPE: CAL / REF		S/N: BF-131					
				NOMINAL ANGLE: 60		ACTUAL ANGLE: 57					
INSTRUMENT SETTINGS											
REFLECTOR					REFERENCE		MEMORY				
SCAN DIRECT:		NTCH	SDH		SENSITIVITY		NUMBER				
AXIAL:		<input checked="" type="checkbox"/>	<input type="checkbox"/>		49.5 dB		PAC-U0109				
CIRC:		<input type="checkbox"/>	<input type="checkbox"/>		N/A dB						
RANGE: 1.62					*INST. FREQ.: 2.0 Mhz						
PROBE DELAY: 5.8200					*RECTIFY: F.W.						
VELOCITY: 2384					DUAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF						
DISPLAY DELAY: 0.0					*REJECT: 0 % % %						
*ENERGY: HIGH					*DISPLAY START: I.P.						
*DAMPING: 1000 Ohms					DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK						
*PRF MODE: AUTO HIGH					TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>						
CALIBRATION TIMES											
REF. REFLECTOR: SDH		GAIN: dB 49.5									
AMPLITUDE: 80		METAL PATH: .808									
VERIFICATION TIMES		1)1430	2)1515	3)1540	4)1555	5)1610	6)N/A	7)N/A	8)N/A	9)N/A	
* PDI QUALIFIED INSTRUMENT SETTINGS: VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE !											
LINEARITY CHECK											
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20	10
	SIGNAL 2	50	45	40	35	30	25	20	15	10	05
ATTENUATOR	GAIN	SET	-6 dB		-12 dB		SET	+12		SET	+6
	AMP	80	32-48		16-24		20	64-96		40	64-96
			40		20			80			80
COMMENTS: SEE ATTACHED					WELDS/ITEMS EXAMINED:						
<i>@ Connection - 3/16 50109 Main Weld 5/2/07</i>					CRD-2-005-003						
EXAMINER:	<i>[Signature]</i>	EXAMINER:	<i>N/A</i>	REVIEWER:	<i>[Signature]</i>	ANII:	<i>[Signature]</i>	DATE:	<i>5/2/07</i>	PG. <i>6</i> OF <i>10</i>	
LEVEL:	<i>II</i>	LEVEL:	<i>N/A</i>	LEVEL:	<i>III</i>	DATE:	<i>4/10/07</i>				

000382

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER: <i>R171</i>
-------------------------------	---	-------------------------------

PROJECT: BFN UNIT 2	CYCLE: 14	CALIBRATION DATE: 04/01/2007
PROC.: N-UT-82	REV:2 TC:N/A	CALIBRATION BLOCK NO.: BF-131 TEMP: 75°F
INSTR. MFG: KRAUTKRAMER	DUE DATE: 08/21/07	SIMULATOR BLOCK NO: BF-131
MODEL/TYPE: USN-60	M & TE NO.: E36302	THERMOMETER S/N: 562774 DUE DATE: 12/12/07
TRANSDUCER MFG: MEGASONIC	COUPLANT ULTRAGEL II BATCH: 05325	
S/N <i>SN-0110</i> SIZE: 10X18	FREQ: 2.0 MHz	EXAM TYPE: SHEAR <input type="checkbox"/> LONG <input type="checkbox"/> RL <input checked="" type="checkbox"/>
CABLE TYPE: RG-174	LENGTH: 72 inches	

DAC		BLOCK TYPE: CAL / REF	S/N: BF-131
		NOMINAL ANGLE: 70	ACTUAL ANGLE: 67



DISPLAY WIDTH: inches 2.465

INSTRUMENT SETTINGS			
REFLECTOR		REFERENCE	MEMORY
SCAN DIRECT.	NTCH	SDH	SENSITIVITY
AXIAL	<input checked="" type="checkbox"/>	<input type="checkbox"/>	64 dB PAC-U0110
CIRC	<input type="checkbox"/>	<input type="checkbox"/>	N/A dB
RANGE: 2.465		*INST. FREQ.: 2.0 Mhz	
PROBE DELAY: 5.000		*RECTIFY: F.W.	
VELOCITY: .2384		DUAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF	
DISPLAY DELAY: 0.0		*REJECT: 0 % % %	
*ENERGY: HIGH		*DISPLAY START: I.P.	
*DAMPING: 1000 Ohms		DET: <input checked="" type="checkbox"/> PEAK <input type="checkbox"/> FLANK	
*PRF MODE: AUTO HIGH		TCG: ON <input type="checkbox"/> OFF <input checked="" type="checkbox"/>	

REF. REFLECTOR: SDH	GAIN: dB 64.5 <i>1.73"</i>	CALIBRATION TIMES							
AMPLITUDE: 80	METAL PATH: .600(depth)	INITIAL TIME: 1400	FINAL TIME: 1645						
VERIFICATION TIMES	1)1430	2)1515	3)1540	4)1555	5)1610	6)N/A	7)N/A	8)N/A	9)N/A

* PDI QUALIFIED INSTRUMENT SETTINGS:
**VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2
 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE !**

LINEARITY CHECK											
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20	10
	SIGNAL 2	50	45	40	35	30	25	20	15	10	05
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6			
	AMP	80	32-48	16-24	20	64-96	40	64-96			
			40	20		80		80			

COMMENTS: SEE ATTACHED	WELDS/ITEMS EXAMINED:
<i>Correction - 3/4 CEHC Metal Welds - 3/4/07</i>	CRD-2-005-003

EXAMINER: <i>[Signature]</i>	EXAMINER: <i>N/A</i>	REVIEWER: <i>[Signature]</i>	ANI: <i>[Signature]</i>
LEVEL: <i>II</i>	LEVEL:	DATE: <i>4/10/07</i>	DATE: <i>5/2/07</i>
		PG. <i>7</i> OF <i>10</i>	

000383

TENNESSEE VALLEY AUTHORITY	ULTRASONIC PIPING EXAMINATION DATA SHEET	REPORT NUMBER: <i>R171</i>
-------------------------------	--	-------------------------------

PROJECT: BFN UNIT: 2 CYCLE: 14	EXAMINATION DATE: 04/01/2007	
PROCEDURE: N-UT-82 REV:2 TC:N/A	START TIME: 1430	END TIME: 1600
SYSTEM: CRD ISI DWG. NO:	EXAM SURFACE <input type="checkbox"/> ID <input checked="" type="checkbox"/> OD	
COMPONENT ID: CRD-2-005-003	MATL. TYPE: <input type="checkbox"/> CS <input checked="" type="checkbox"/> SS <input type="checkbox"/> CSCL <input type="checkbox"/> CCSS	
CONFIGURATION VALVE TO PIPE FLOW \longrightarrow	SURFACE TEMP.: 83 °F PYRO. NO.: 562774	
	CAL DUE DATE: 12/12/07	
	EXAM ANGLE	45/60/70 shear 45/60/70 RL
W ₀ REFERENCE: C/L OF WELD	CIRC. SCAN SENSITIVITY (DB)	40/NA/NA 53.5/NA/NA
L ₀ REFERENCE: TDC	AXIAL SCAN SENSITIVITY (DB)	40/45/50 NA/50/64

IND. NO.	L (in) FROM REF.			AT MAX AMP			MAX AMP %DAC	EXAM NO. 3-14	NOM. ANG.	N R I	IND. INFO: TYPE, DAMPING, ETC.
	L1	L MAX	L2	W MAX	MP MAX	D MAX					
							%	4	45	X	
							%	5	45	X	
							%	6	45	X	
							%	4	60	X	
							%	4	70	X	
							%	5	45RL	X	CIRC CONTOUR
							%	6	45RL	X	CIRC CONTOUR
							%	4	60RL	X	AXIAL CONTOUR
							%	4	70RL	X	AXIAL CONTOUR
							%				
							%				
							%				
							%				
							%				

REMARKS / LIMITATIONS: ID / Root Geometry were noted during the exam below recordable levels.

EXAMINER: <i>[Signature]</i>	LEVEL: <i>II</i>	ANII: <i>[Signature]</i>
EXAMINER: <i>N/A</i>	LEVEL:	DATE: <i>5/2/07</i>
REVIEWER: <i>[Signature]</i>	LEVEL: <i>III</i>	DATE: <i>4/16/07</i>
		PAGE <i>8</i> OF <i>10</i>


000384

TVA **WALL THICKNESS PROFILE SHEET** **REPORT NO: R171**

PROJECT: BFN WELD NO: CRD-2-005-003
 UNIT: 2 CYCLE 14 SYSTEM: CRD


Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	1.15	.79	.78	.76
2	.80	.69	.65	.60
3	.60	.51	.51	.51
4	.399	.399	.395	.395
5	.51	.51	.51	.51




CROWN HEIGHT: 1.15 DIAMETER: 4"
 CROWN WIDTH: .85 WELD LENGTH: 14.9"

AREA ① $.133 + .233 \div 2 = .183 \times 1.35 = .247 \times 14.9 = 3.681$
 ② $.233 + .183 \div 2 = .208 \times .4 = .083$
 ③ $.183 \times .35 \div 2 = .032$ } $.115 \times 14.9 = 1.713 = 46.5\% \text{ NOT COVERED @ } 90/180/270$
53.5% COVERAGE @ 90/180/270



AREA ① $.133 + .266 \div 2 = .200 \times 1.35 = .27 \times 14.9 = 4.023$
 ② $.266 + .208 \div 2 = .237 \times .4 = .094$
 ③ $.208 \times .4 \div 2 = .041$ } $.135 \times 14.9 = 2.011 = 50\% \text{ NOT COVERED @ } 0°$
50% COVERAGE @ 0°



COMBINED COVERAGE AXIALLY $53.5 + 53.5 + 53.5 + 50 \div 4 =$ **52.6%**


EXAMINER: [Signature] REVIEWED BY: [Signature] ANII: [Signature]
 LEVEL: II LEVEL: III DATE: 4/10/07 DATE: 5/2/07
 DATE: 6/4/07 PAGE: 9 OF 10

TVA	WALL THICKNESS PROFILE SHEET	REPORT NO: R171
------------	---	---------------------------

PROJECT: BFN	WELD NO: CRD-2-005-003
UNIT: 2 CYCLE 14	SYSTEM: CRD


Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	1.15	.79	.78	.76
2	.80	.69	.65	.60
3	.60	.51	.51	.51
4	.399	.399	.395	.395
5	.51	.51	.51	.51




CROWN HEIGHT: $\frac{K}{.15}$ DIAMETER: **4"**
 CROWN WIDTH: **.85** WELD LENGTH: **14.9"**

AREA ① $.133 + .233 \div 2 = .183 \times 1.35 = .247 \times 14.9 = 3.681$
 ② $.206 + .233 \div 2 = .220 \times 0.175 = .038$
 ③ $.133 + .141 \div 2 = .137 \times .145 = \frac{.020}{.058 \times 14.9} = .864''^3 = 22.4\% \text{ Not Covered @ } 90/180/270$
77.6% COVERAGE @ 90/180/270



AREA ① $.133 + .266 \div 2 = .200 \times 1.35 = .27 \times 14.9 = 4.023''^3$
 ② $.266 + .233 \div 2 = .250 \times .185 = .046$
 ③ $.15 + .133 \div 2 = .142 \times .145 = .021$ } $.067 \times 14.9 = .998 = 24.8\% \text{ Not covered @ } 0°$
75.2% Coverage at 0°



COMBINED COVERAGE CIRC. **77%** $77.6 + 77.6 + 77.6 + 75.2 \div 4 = 77\%$

EXAMINER: <i>[Signature]</i>	REVIEWED BY: <i>[Signature]</i>	ANII: <i>[Signature]</i>
LEVEL: <i>[Signature]</i>	LEVEL: <i>[Signature]</i> DATE: 4/10/07	DATE: 5/2/07
DATE: 04/01/07		PAGE 10 OF 10