



**INDIANA
MICHIGAN
POWER®**

A unit of American Electric Power

Indiana Michigan Power
One Cook Place
Bridgman, MI 49106
IndianaMichiganPower.com

April 8, 2011

AEP-NRC-2011-23
10 CFR 50.55a

Docket No.: 50-315
50-316

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Donald C. Cook Nuclear Plant Units 1 and 2
Relief Requests for Limited Coverage Examinations Performed In
The Third 10-Year Inspection Interval

The third 10-year interval for the inservice inspection program for Donald C. Cook Nuclear Plant (CNP) Units 1 and 2 concluded on April 9, 2010. During this interval, the components identified in Attachments 1 through 10 received less than the required examination coverage. Accordingly, pursuant to 10 CFR 50.55a(g)(5)(iii), Indiana Michigan Power Company (I&M) requests relief on the basis that the required examination coverage is impractical due to physical obstructions and limitations imposed by design, geometry, and materials of construction of the subject components.

Attachments 1 through 10 contain the relief requests and the basis for these requests.

There are no new or revised commitments in this letter. Should you have any questions, please contact Mr. Michael K. Scarpello, Regulatory Affairs Manager at (269) 466-2649.

Sincerely,

Joel P. Gebbie
Site Vice President

MCS/jen

c: J. T. King – MPSC, w/o attachment
S. M. Krawec - AEP Ft. Wayne, w/o attachment
MDNRE – WHMD/RPS, w/o attachment
NRC Resident Inspector
M. A. Satorius – NRC Region III
P. S. Tam – NRC Washington DC
W. Vallance - DLEG/BCCFS/BD

A047
NRC

Attachments:

1. Relief Request ISIR-33 - Examination Category B-A, Pressure Retaining Welds in Reactor Vessels, and Examination Category B-D, Full Penetration Welds of Nozzles in Vessels – Inspection Program B (Reactor Vessel only)
2. Relief Request ISIR-34 - Examination Category B-B, Pressure Retaining Welds in Vessels Other Than Reactor Vessels
3. Relief Request ISIR-35 - Examination Category B-D, Full Penetration Welds of Nozzles in Vessels - Inspection Program B
4. Relief Request ISIR-36 - Examination Category B-F, Pressure Retaining Dissimilar Metal Welds
5. Relief Request ISIR-37 - Examination Category B-J Pressure Retaining Welds in Piping
6. Relief Request ISIR-38, Examination Category C-A, Pressure Retaining Welds in Pressure Vessels
7. Relief Request ISIR-39, Examination Category C-B, Pressure Retaining Nozzle Welds in Vessels
8. Relief Request ISIR-40, Examination Category C-C, Integral Attachments for Vessels, Piping, Pumps, and Valves
9. Relief Request ISIR-41, Examination Category C-F-1, Pressure Retaining Welds in Austenitic Stainless Steel or High Alloy Piping
10. Relief Request ISIR-42, Examination Category R-A, Risk Informed Piping Examinations

ATTACHMENT 1 to AEP-NRC-2011-23

RELIEF REQUEST ISIR-33

EXAMINATION CATEGORY B-A
PRESSURE RETAINING WELDS IN REACTOR VESSEL

And

EXAMINATION CATEGORY B-D
FULL PENETRATION WELDS OF NOZZLES IN VESSELS – INSPECTION PROGRAM B
(Reactor Vessel only)

RELIEF REQUEST ISIR-33Relief Request In Accordance with 10 CFR 50.55a(g)(5)(iii)
Inservice Inspection Impracticality1. ASME Code Components Affected

ASME Code Class: Code Class 1

Examination Category: B-A, Pressure Retaining Welds in Reactor Vessel
B-D, Full Penetration Welds of Nozzles in Vessels – Inspection
Program B (Reactor Vessel only)Item Numbers: B1.11, Shell Welds - Circumferential
B1.12, Shell Welds - Longitudinal
B1.21, Head Welds - Circumferential
B1.22, Head Welds – Meridional
B1.30, Shell to Flange Weld
B3.90, Reactor Vessel – Nozzle to Vessel Welds

Component Identification: Listed in Table 1

2. Applicable Code Edition and Addenda

ASME Section XI, 1989 Edition, No addenda

3. Applicable Code Requirement

ASME Section XI, 1989 Edition, Examination Categories B-A and B-D require volumetric examination of 100 percent of the weld volume as defined in ASME Section XI Table IWB-2500-1 and shown in Figures IWB-2500-1, IWB-2500-2, IWB- 2500-3, and IWB-2500-7. The alternative requirements of ASME Section XI, Code Case N-460, approved for use in Regulatory Guide 1.147, Revision 15, allows credit for essentially 100 percent coverage of the weld provided greater than 90 percent of the required volume has been examined.

4. Impracticality of Compliance

Pursuant to 10 CFR 50.55a(g)(5)(iii), relief is requested from the essentially 100 percent volumetric examination coverage requirement for the subject welds. Due to the design of the reactor vessel, geometric configuration and permanent obstructions limit the volumetric examination coverage of the subject welds.

During the second 10-year reactor pressure vessel examination, the best available technology was utilized in performing the automated ultrasonic examination. The examinations were performed with equipment, procedures, and personnel qualified in accordance with the requirements of ASME Section XI, Appendix VIII, 1995 Edition thru 1996 Addenda as modified by the Performance Demonstration Initiative (PDI) program.

Several interferences and vessel geometries prevent full volumetric examination coverage, including the 58 permanent incore instrument nozzles penetrating the bottom head and six core support lugs permanently attached to the vessel interior limiting the access to the lower head welds. The close proximity of the inlet nozzle and outlet nozzle boss limits the ultrasonic scanning of the upper shell longitudinal seam welds. The flange to vessel configuration, specimen slots, and keyways also hinder access. These noted obstructions prevent achieving the essentially 100 percent volumetric examination coverage required by code. Also, Nozzle to Vessel geometry, vessel saddle effect, and adjacent outlet nozzle protrusion limited access for achieving 100 percent volumetric examination coverage for the Nozzle to Vessel welds.

The limitations and the actual examination coverage attained for each weld for which relief is requested are noted in Table 1.

5. Burden Caused by Compliance

To increase examination coverage on the subject welds requires a significant design modification or replacement of components with a different design to eliminate the noted obstructions. This is impractical due to the cost, additional radiation exposure, and impact to plant equipment.

6. Proposed Alternative and Basis for Use

The subject welds received a volumetric examination on the accessible portions of the subject welds to the maximum extent practical given the limitations caused by the geometric configuration and permanent obstructions. Additionally, a visual examination (VT-2) is performed at the end of each refueling outage during the system leakage tests as required by Section XI, IWB-2500-1, Category B-P.

Based upon the examination volumes that were obtained with acceptable results, along with the visual (VT-2) examination performed each refueling outage, it is reasonable to conclude that service induced degradation would be detected. Therefore, these proposed alternatives provide an acceptable level of quality and safety by providing reasonable assurance of structural integrity of the subject welds.

7. Period for Which Relief is Requested

The relief is requested for the Third 10-year inspection interval for CNP Units 1 and 2, which began on July 1, 1996, and ended April 9, 2010, at the conclusion of the Unit 1 Cycle 23 Refueling Outage. Significant long-term outages (greater than six months) occurred multiple times during the interval and the interval was extended as allowed by IWA-2430(e) and by IWA-2430(d) to accommodate interval planning and scheduling.

Table 1

Component ID	Weld Description	Item Number	Ultrasonic Examination Coverage Attained (%)	Remarks
1-RPV-A	Shell to Flange	B1.30	84.44	The completed examination was limited to 84.4% coverage due to the configuration. The limitations are due to flange configuration, specimen slots, and keyways at 0, 90, 180, and 270 degrees. No recordable indications detected.
1-RPV-D	Lower Shell to Bottom Head	B1.11	82.60	The completed examination was limited to 82.60% coverage due to the configuration. The limitations are due to six core support lugs. No recordable indications detected.
1-RPV-E	Dollar Plate	B1.21	38.4	The completed examination was limited to 38.4% coverage due to the configuration. The limitation is due to the bottom mounted instrument penetrations. No recordable indications detected.
1-RPV-VC1	Lower Shell Longitudinal at 60 Degrees	B1.12	78.29	The completed examination was limited to 78.29% coverage due to the configuration. The limitation is due to the core support lug. No recordable indications detected.
1-RPV-VC2	Lower Shell Longitudinal at 180 Degrees	B1.12	78.29	The completed examination was limited to 78.29% coverage due to the configuration. The limitation is due to the core support lug. No recordable indications detected.
1-RPV-VC3	Lower Shell Longitudinal at 300 Degrees	B1.12	78.29	The completed examination was limited to 78.29% coverage due to the configuration. The limitation is due to the core support lug. No recordable indications detected.
1-LHM-01	Lower Head Meridional at 30 Degrees	B1.22	79.0	The completed examination was limited to 79.0% coverage due to the configuration. The limitation is due to bottom mounted instrumentation penetrations. No recordable indications detected.

Table 1 (continued)

Component ID	Weld Description	Item Number	Ultrasonic Examination Coverage Attained (%)	Remarks
1-LHM-02	Lower Head Meridional at 90 Degrees	B1.22	73.26	The completed examination was limited to 73.26% coverage due to the configuration. The limitation is due to bottom mounted instrumentation penetrations. No recordable indications detected.
1-LHM-05	Lower Head Meridional at 270 Degrees	B1.22	88.1	The completed examination was limited to 88.1% coverage due to the configuration. The limitation is due to bottom mounted instrumentation penetrations. No recordable indications detected.
1-LHM-06	Lower Head Meridional at 330 Degrees	B1.22	74.5	The completed examination was limited to 74.5% coverage due to the configuration. The limitation is due to bottom mounted instrumentation penetrations. No recordable indications detected.
1-N3B	Outlet Nozzle to Shell at 22 Degrees	B3.90	71.08	The completed examination was limited to 71.08% coverage due to the configuration. The limitation is due to nozzle geometry, vessel saddle effect, and adjacent outlet nozzle protrusion. Two subsurface indications were detected and evaluated as acceptable to IWB-3512-1.
1-N4B	Outlet Nozzle to Shell at 158 Degrees	B3.90	71.08	The completed examination was limited to 71.08% coverage due to the configuration. The limitation is due to nozzle geometry, vessel saddle effect, and adjacent outlet nozzle protrusion. One subsurface indication was detected and evaluated as acceptable to IWB-3512-1.

Table 1 (continued)

Component ID	Weld Description	Item Number	Ultrasonic Examination Coverage Attained (%)	Remarks
1-N1B	Outlet Nozzle to Shell at 202 Degrees	B3.90	71.08	The completed examination was limited to 71.08% coverage due to the configuration. The limitation is due to nozzle geometry, vessel saddle effect and adjacent outlet nozzle protrusion. Six subsurface indications were detected and evaluated as acceptable to IWB-3512-1.
1-N2B	Outlet Nozzle to Shell at 338 Degrees	B3.90	71.08	The completed examination was limited to 71.08% coverage due to the configuration. The limitation is due to nozzle geometry, vessel saddle effect and adjacent outlet nozzle protrusion. Eight subsurface indications were detected and evaluated as acceptable to IWB-3512-1.

RELIEF REQUEST ISIR-33


EXAMINATION CATEGORY B-A
PRESSURE RETAINING WELDS IN REACTOR VESSEL

And

EXAMINATION CATEGORY B-D
FULL PENETRATION WELDS OF NOZZLES IN VESSELS – INSPECTION PROGRAM B
(Reactor Vessel only)

SUPPORTING DOCUMENTATION

19 of 39



D.C. COOK UNIT 1 2010

WesDyne International


VESSEL ROLLOUT


EXAMINATION PROGRAM PLAN

ALL DIMENSIONS IN INCHES
UNLESS OTHERWISE NOTED

SHEET 1 OF 21


20 of 39






D.C. COOK UNIT 1 2010	
WesDyne International	
Nozzle Orientation	
EXAMINATION PROGRAM PLAN	
ALL DIMENSIONS IN INCHES UNLESS OTHERWISE NOTED	SHEET 3 OF 21


① Scan Boundaries Between Keyways & Irradiation Specimen Slots



② Scan Boundaries Below Keyways



③ Scan Boundaries Below Irradiation Specimen Slots



Perp. Scan Areas (Vessel @)		Scan Limit Configuration
Start	Stop	
363	7	3
7	37	1
37	43	3
43	87.25	1
87.25	92.75	2
92.75	137	1
137	143	3
143	173	1
173	187	3
187	217	1
217	223	3
223	267.25	1
267.25	272.5	2
272.5	317	1
317	323	3
323	353	1

Parallel Scan Areas (Vessel @)		Scan Limit Configuration
Start	Stop	
351.25	8.75	3
8.75	35.25	1
35.25	44.75	3
44.75	85.5	1
85.5	94.5	2
94.5	135.25	1
135.25	144.75	3
144.75	171.25	1
171.25	188.75	3
188.75	215.25	1
215.25	224.75	3
224.75	265.5	1
265.5	274.5	2
274.5	315.25	1
315.25	324.75	3
324.75	351.25	1

Scan Increment = 0.5" for Parallel Scans
= 0.3" (0.335") for Perp. Scans

WELD 1-RPV-A (1)

D.C. COOK UNIT 1

WesDyne International

SHEET TITLE FLANGE TO UPPER SHELL

2010 EXAMINATION PROGRAM PLAN

ALL DIMENSIONS IN INCHES
UNLESS OTHERWISE NOTED SHEET 4 OF 21

REACTOR VESSEL WELD RESULTS SUMMARY

PLANT NAME DC Cook Unit 1

WELD NO. 1-RPV-A COMPONENT Shell to Flange Weld

LIMITATIONS: NO YES 84.44 % Complete
See Coverage Breakdown Sheet

RESULTS NO. OF INDICATIONS 0

NI X STATUS _____

RI _____

EXAM DOCUMENTATION

INDICATION DOCUMENTATION

PARAGON ANALYSIS LOG

ASSESSMENT SHEET

PARAGON ACQUISITION LOG

PARAGON HARD COPY

SCAN PRINT OUT

OTHER (Specify)

COVERAGE BREAKDOWN

Comments:

Limited due to Flange Configuration, Specimen Slots, and Keyways at 0, 90, 180 and 270 degrees.

Analyst *JMT* Date: 3/25/12

R.V. COVERAGE ESTIMATE BREAKDOWNS

PLANT NAME DC Cook

WesDyne

WELD NO. 1-RPV-A

International

COMPONENT Shell to Flange Weld

BEAM ANGLE BREAK DOWN

BEAM DIRECTION	45 Shear		45 L Single		45 L Dual			
	VOLUME		VOLUME		VOLUME			
Perpendicular	UP	DN	UP	DN	UP	DN		
		99.87	45.74	94.61	72.78	90.73	87.14	
Parallel	CW	CCW	CW	CCW	CW	CCW		
	89.01	89.03	89.03	85.11	85.11	85.11		
AVERAGE	80.91		85.38		87.02			

Comments: Limited due to Flange Configuration, Specimen Slots, and Keyways at 0, 90, 180 and 270 degrees.


Combined Perp. 81.81 Combined Para. 87.07 Combined Average 84.44

Analyst 


Date 3/25/10

27 of 39

SCANS BETWEEN LUGS




SCANS BELOW LUGS



SCAN LIMITS AROUND LUGS
 Perp Scans +/- 10.5° from Lug ξ
 Parallel Scans +/- 11.5° from Lug ξ

Note: Perform scans between Lugs first then expand scans below Lugs to maximize coverage.

For Perp. Below Lug scans perform both -90° (Standard) and +90° (Reverse) axis 6 rotation scans
 For Parallel Below scans perform both 0° (Standard) and 180° (Reverse) axis 6 rotation scans



Calculation of Angular Positions

SUPREEM SCAN INCREMENT
 Perp Scans & Parallel Scans = 0.5° Surface Index

PARAGON SCAN INCREMENTS
 Perp and Parallel Scans Below Lugs = 0.325° (using Head Radius of 88.16")
 Perp Scans Between Lugs = 0.33° (using Vessel Radius of 85.5")
 Parallel Scans Between Lugs = 0.5°

WELD 1-RPV-D (4)

D.C. COOK UNIT 1	
WesDyne International	
SHEET TITLE	LOWER SHELL TO LOWER HEAD
2010 EXAMINATION PROGRAM PLAN	
ALL DIMENSIONS IN INCHES UNLESS OTHERWISE NOTED	SHEET 9 OF 21

REACTOR VESSEL WELD RESULTS SUMMARY

PLANT NAME DC Cook Unit 1
WELD NO. 1-RPV-D COMPONENT Lower Shell to Bottom Head

LIMITATIONS: NO YES 82.60 % Complete
See Coverage Breakdown Sheet

RESULTS NO. OF INDICATIONS 0
NI X STATUS _____
RI _____

EXAM DOCUMENTATION

INDICATION DOCUMENTATION

PARAGON ANALYSIS LOG

ASSESSMENT SHEET

PARAGON ACQUISITION LOG

PARAGON HARD COPY

SCAN PRINT OUT

OTHER (Specify)

COVERAGE BREAKDOWN

Comments: Limited due to 6 core support lugs

Analyst [Signature]

Date: 3/25/10

R.V. COVERAGE ESTIMATE BREAKDOWNS

PLANT NAME DC Cook

WesDyne

WELD NO. 1-RPV-D

International

COMPONENT Lower Shell to Bottom Head

BEAM ANGLE BREAK DOWN

BEAM DIRECTION	45 Shear		45 L Single		45 L Dual			
	VOLUME		VOLUME		VOLUME			
Perpendicular	UP	DN	UP	DN	UP	DN		
	99.86	65.71	81.20	64.99	89.48	68.03		
Parallel	CW	CCW	CW	CCW	CW	CCW		
	86.98	86.98	86.98	86.98	86.98	86.98		
AVERAGE	84.88		80.04		82.87			


Comments: Limited due to 6 core support lugs

Combined Perp. 78.21 Combined Para. 86.98 Combined Average 82.60


Analyst *[Signature]*

Date 3/25/10

31 of 39




30 of 39



USE "STANDARD" SLED ROTATIONS FOR BOTH PERP AND PARALLEL SCANS

WELD 1-RPV-E (5)



Calculation of Angular Positions

SUPREEM SCAN INCREMENT
Perp Scans & Parallel Scans = 0.5° Surface Index

PARAGON SCAN INCREMENT
Perp Scans = 0.86° (using Weld ϕ Radius of 49.3")
Parallel Scans = 0.325° (using Head Radius of 88.16")

D.C. COOK UNIT 1

WesDyne International

SHEET TITLE BOTTOM HEAD TO DOLLAR PLATE

2010 EXAMINATION PROGRAM PLAN

ALL DIMENSIONS IN INCHES UNLESS OTHERWISE NOTED

SHEET 12 OF 21

REACTOR VESSEL WELD RESULTS SUMMARY

PLANT NAME DC Cook Unit 1

WELD NO. 1-RPV-E COMPONENT Bottom Head Dollar Weld

LIMITATIONS: NO YES 38.40 % Complete
See Coverage Breakdown Sheet

RESULTS NO. OF INDICATIONS 0

NI X

STATUS _____

RI _____

EXAM DOCUMENTATION

INDICATION DOCUMENTATION

PARAGON ANALYSIS LOG

ASSESSMENT SHEET

PARAGON ACQUISITION LOG

PARAGON HARD COPY

SCAN PRINT OUT

OTHER (Specify)

COVERAGE BREAKDOWN

Comments: Limited due to bottom head instrumentation tubing

Analyst [Signature]

Date: 3/25/10

R.V. COVERAGE ESTIMATE BREAKDOWNS

PLANT NAME DC Cook

WesDyne

WELD NO. 1-RPV-E

International

COMPONENT Bottom Head Dollar Weld

BEAM ANGLE BREAK DOWN



BEAM DIRECTION	45 Shear		45 L Single		45 L Dual			
	VOLUME		VOLUME		VOLUME			
Perpendicular	UP	DN	UP	DN	UP	DN		
	39.50	39.50	39.50	39.50	39.50	39.50		
Parallel	CW	CCW	CW	CCW	CW	CCW		
	37.30	37.30	37.30	37.30	37.30	37.30		
AVERAGE	38.40		38.40		38.40			

Comments: Limited due to bottom head instrumentation tubing

Combined Perp. 39.50 Combined Para. 37.30 Combined Average 38.40

Analyst *[Signature]*

Date 3/25/12



SECTION C-C

- 1-RPV-VC1 @ 60° (12)
- 1-RPV-VC2 @ 180° (13)
- 1-RPV-VC3 @ 300° (14)

SCAN INCREMENTS
 PARALLEL SCANS = 0.5" (0.331°)
 PERP. SCANS = 0.5"

D.C. COOK UNIT 1	
WesDyne International	
SHEET TITLE	LOWER SHELL LONG SEAMS
2010 EXAMINATION PROGRAM PLAN	
ALL DIMENSIONS IN INCHES UNLESS OTHERWISE NOTED	SHEET 10 OF 21

REACTOR VESSEL WELD RESULTS SUMMARY

PLANT NAME DC Cook Unit 1
WELD NO. 1-RPV-VC1 COMPONENT Lower Shell Long Seams

LIMITATIONS: NO YES 78.29 % Complete
See Coverage Breakdown Sheet

RESULTS	NO. OF INDICATIONS
NI <u>X</u>	STATUS
RI _____	

EXAM DOCUMENTATION

INDICATION DOCUMENTATION

- PARAGON ANALYSIS LOG
- PARAGON ACQUISITION LOG
- SCAN PRINT OUT
- COVERAGE BREAKDOWN

- ASSESSMENT SHEET
- PARAGON HARD COPY
- OTHER (Specify)

Comments: Limited due to core support lug

Analyst [Signature] Date: 3/23/16

R.V. COVERAGE ESTIMATE BREAKDOWNS

PLANT NAME DC Cook

WesDyne

WELD NO. 1-RPV-VC1

International

COMPONENT Lower Shell Long Seams

BEAM ANGLE BREAK DOWN

BEAM DIRECTION	45 Shear		45 L Single		45 L Dual			
	VOLUME		VOLUME		VOLUME			
Perpendicular	UP	DN	UP	DN	UP	DN		
	79.18	79.18	79.18	79.18	79.18	79.18		
Parallel	CW	CCW	CW	CCW	CW	CCW		
	77.39	77.39	77.39	77.39	77.39	77.39		
AVERAGE	78.29		78.29		78.29			

Comments: Limited due to core support lug

Combined Perp. 79.18 Combined Para. 77.39 Combined Average 78.29

Analyst 

Date 3/25/10

REACTOR VESSEL WELD RESULTS SUMMARY

PLANT NAME DC Cook Unit 1
WELD NO. 1-RPV-VC2 COMPONENT Lower Shell Long Seams

LIMITATIONS: NO YES 78.29 % Complete
See Coverage Breakdown Sheet

RESULTS	NO. OF INDICATIONS
NI <u>X</u>	STATUS
RI _____	

EXAM DOCUMENTATION

INDICATION DOCUMENTATION

PARAGON ANALYSIS LOG

ASSESSMENT SHEET

PARAGON ACQUISITION LOG

PARAGON HARD COPY

SCAN PRINT OUT

OTHER (Specify)

COVERAGE BREAKDOWN

Comments: Limited due to core support lug

Analyst D. J. [Signature] Date: 3/25/10

R.V. COVERAGE ESTIMATE BREAKDOWNS

PLANT NAME DC Cook

WesDyne

WELD NO. 1-RPV-VC2

International

COMPONENT Lower Shell Long Seams


BEAM ANGLE BREAK DOWN

BEAM DIRECTION	45 Shear		45 L Single		45 L Dual			
	VOLUME		VOLUME		VOLUME			
Perpendicular	UP	DN	UP	DN	UP	DN		
	79.18	79.18	79.18	79.18	79.18	79.18		
Parallel	CW	CCW	CW	CCW	CW	CCW		
	77.39	77.39	77.39	77.39	77.39	77.39		
AVERAGE	78.29		78.29		78.29			

Comments: Limited due to core support lug

Combined Perp. 79.18 Combined Para. 77.39 Combined Average 78.29

Analyst



Date

3/25/10

REACTOR VESSEL WELD RESULTS SUMMARY

PLANT NAME DC Cook Unit 1
WELD NO. 1-RPV-VC3 COMPONENT Lower Shell Long Seams

LIMITATIONS: NO YES 78.29 % Complete
See Coverage Breakdown Sheet

RESULTS	NO. OF INDICATIONS
NI <u>X</u>	STATUS
RI _____	

EXAM DOCUMENTATION

INDICATION DOCUMENTATION

PARAGON ANALYSIS LOG

ASSESSMENT SHEET

PARAGON ACQUISITION LOG

PARAGON HARD COPY

SCAN PRINT OUT

OTHER (Specify)

COVERAGE BREAKDOWN

Comments: Limited due to core support lug

Analyst [Signature]

Date: 3/25/12

R.V. COVERAGE ESTIMATE BREAKDOWNS

PLANT NAME DC Cook

WesDyne

WELD NO. 1-RPV-VC3

International

COMPONENT Lower Shell Long Seams

BEAM ANGLE BREAK DOWN


BEAM DIRECTION	45 Shear		45 L Single		45 L Dual			
	VOLUME		VOLUME		VOLUME			
Perpendicular	UP	DN	UP	DN	UP	DN		
	79.18	79.18	79.18	79.18	79.18	79.18		
Parallel	CW	CCW	CW	CCW	CW	CCW		
	77.39	77.39	77.39	77.39	77.39	77.39		
AVERAGE	78.29		78.29		78.29			

Comments: Limited due to core support lug


Combined Perp. 79.18 Combined Para. 77.39 Combined Average 78.29

Analyst 

Date 3/25/10



USE "REVERSE" SLED ROTATIONS FOR BOTH PERP AND PARALLEL SCANS



Calculation of Angular Positions

SUPREEM SCAN INCREMENT
 Perp Scans & Parallel Scans = 0.5° Surface Index

PARAGON SCAN INCREMENTS
 Perp and Parallel Scans = 0.325° (using Head Radius of 88.16")

- WELD 1-LHM-01 @ 30' (15)
- WELD 1-LHM-02 @ 90' (16)
- WELD 1-LHM-03 @ 150' (17)
- WELD 1-LHM-04 @ 210' (18)
- WELD 1-LHM-05 @ 270' (19)
- WELD 1-LHM-06 @ 330' (20)

D.C. COOK UNIT 1	
WesDyne International	
SHEET	Meridional Welds
2010 EXAMINATION PROGRAM PLAN	
ALL DIMENSIONS IN INCHES UNLESS OTHERWISE NOTED	SHEET 11 OF 21

REACTOR VESSEL WELD RESULTS SUMMARY

PLANT NAME DC Cook Unit 1

WELD NO. 1-LHM-01 COMPONENT Bottom Head Meridionals

LIMITATIONS: NO YES 79.00 % Complete
See Coverage Breakdown Sheet

RESULTS NO. OF INDICATIONS 0

NI X STATUS _____

RI _____

EXAM DOCUMENTATION

INDICATION DOCUMENTATION

PARAGON ANALYSIS LOG

ASSESSMENT SHEET

PARAGON ACQUISITION LOG

PARAGON HARD COPY

SCAN PRINT OUT

OTHER (Specify)

COVERAGE BREAKDOWN

Comments: Limited due to bottom head instrumentation tubing

Analyst [Signature] Date: 7/25/10

R.V. COVERAGE ESTIMATE BREAKDOWNS

PLANT NAME DC Cook

WesDyne

WELD NO. 1-LHM-01

International

COMPONENT Bottom Head Meridionals

BEAM ANGLE BREAK DOWN

BEAM DIRECTION	45 Shear		45 L Single		45 L Dual			
	VOLUME		VOLUME		VOLUME			
Perpendicular	UP	DN	UP	DN	UP	DN		
	84.00	84.00	84.00	84.00	84.00	84.00		
Parallel	CW	CCW	CW	CCW	CW	CCW		
	74.00	74.00	74.00	74.00	74.00	74.00		
AVERAGE	79.00		79.00		79.00			

Comments: Limited due to bottom head instrumentation tubing

Combined Perp. 84.00 Combined Para. 74.00 Combined Average 79.00

Analyst *Jm2*

Date *3/23/10*

REACTOR VESSEL WELD RESULTS SUMMARY

PLANT NAME DC Cook Unit 1

WELD NO. 1-LHM-02 COMPONENT Bottom Head Meridionals

LIMITATIONS: NO YES 73.26 % Complete
See Coverage Breakdown Sheet

RESULTS NO. OF INDICATIONS 0

NI X STATUS _____

RI _____

EXAM DOCUMENTATION

INDICATION DOCUMENTATION

PARAGON ANALYSIS LOG

ASSESSMENT SHEET

PARAGON ACQUISITION LOG

PARAGON HARD COPY

SCAN PRINT OUT

OTHER (Specify)

COVERAGE BREAKDOWN

Comments: Limited due to bottom head instrumentation tubing

Analyst [Signature] Date: 3/25/11

R.V. COVERAGE ESTIMATE BREAKDOWNS

PLANT NAME DC Cook

**WesDyne
International**

WELD NO. 1-LHM-02

COMPONENT Bottom Head Meridionals

BEAM ANGLE BREAK DOWN

BEAM DIRECTION	45 Shear		45 L Single		45 L Dual			
	VOLUME		VOLUME		VOLUME			
Perpendicular	UP	DN	UP	DN	UP	DN		
	74.30	74.30	74.30	74.30	74.30	74.30		
Parallel	CW	CCW	CW	CCW	CW	CCW		
	72.20	72.20	72.20	72.20	72.27	72.20		
AVERAGE	73.25		73.25		73.27			

Comments: Limited due to bottom head instrumentation tubing

Combined Perp. 74.30 Combined Para. 72.21 Combined Average 73.26

Analyst  Date 3/23/10

REACTOR VESSEL WELD RESULTS SUMMARY

PLANT NAME DC Cook Unit 1
WELD NO. 1-LHM-05 COMPONENT Bottom Head Meridionals

LIMITATIONS: NO YES 88.10 % Complete
See Coverage Breakdown Sheet

RESULTS NO. OF INDICATIONS 0
NI X STATUS _____
RI _____

EXAM DOCUMENTATION

INDICATION DOCUMENTATION

PARAGON ANALYSIS LOG

ASSESSMENT SHEET

PARAGON ACQUISITION LOG

PARAGON HARD COPY

SCAN PRINT OUT

OTHER (Specify)

COVERAGE BREAKDOWN

Comments: Limited due to bottom head instrumentation tubing

Analyst *[Signature]*

Date: 3/25/16

R.V. COVERAGE ESTIMATE BREAKDOWNS

PLANT NAME DC Cook

WesDyne

WELD NO. 1-LHM-05

International

COMPONENT Bottom Head Meridionals

BEAM ANGLE BREAK DOWN

BEAM DIRECTION	45 Shear		45 L Single		45 L Dual			
	VOLUME		VOLUME		VOLUME			
Perpendicular	UP	DN	UP	DN	UP	DN		
	87.70	87.70	87.70	87.70	87.70	87.70		
Parallel	CW	CCW	CW	CCW	CW	CCW		
	88.50	88.50	88.50	88.50	88.50	88.50		
AVERAGE	88.10		88.10		88.10			

Comments: Limited due to bottom head instrumentation tubing

Combined Perp. 87.70 Combined Para. 88.50 Combined Average 88.10

Analyst *[Signature]*

Date 3/25/10

REACTOR VESSEL WELD RESULTS SUMMARY

PLANT NAME DC Cook Unit 1

WELD NO. 1-LHM-06 COMPONENT Bottom Head Meridionals

LIMITATIONS: NO YES 74.50 % Complete
See Coverage Breakdown Sheet

RESULTS NO. OF INDICATIONS 0

NI X STATUS _____

RI _____

EXAM DOCUMENTATION

INDICATION DOCUMENTATION

PARAGON ANALYSIS LOG

ASSESSMENT SHEET

PARAGON ACQUISITION LOG

PARAGON HARD COPY

SCAN PRINT OUT

OTHER (Specify)

COVERAGE BREAKDOWN

Comments: Limited due to bottom head instrumentation tubing

Analyst *[Signature]*

Date: 3/05/12

R.V. COVERAGE ESTIMATE BREAKDOWNS

PLANT NAME DC Cook

WesDyne

WELD NO. 1-LHM-06

International

COMPONENT Bottom Head Meridionals


BEAM ANGLE BREAK DOWN

BEAM DIRECTION	45 Shear		45 L Single		45 L Dual			
	VOLUME		VOLUME		VOLUME			
Perpendicular	UP	DN	UP	DN	UP	DN		
	74.00	74.00	74.00	74.00	74.00	74.00		
Parallel	CW	CCW	CW	CCW	CW	CCW		
	75.00	75.00	75.00	75.00	75.00	75.00		
AVERAGE	74.50		74.50		74.50			


Comments: Limited due to bottom head instrumentation tubing

Combined Perp. 74.00 Combined Para. 75.00 Combined Average 74.50

Analyst *DJM* Date 3/25/10



D.C. COOK UNIT 1	
WesDyne International	
SHEET	Outlet Nozzle Configuration
TITLE	
2010 EXAMINATION PROGRAM PLAN	
ALL DIMENSIONS IN INCHES UNLESS OTHERWISE NOTED	SHEET 140F 21



SCANNING INCREMENT
 STAR - 0.5° or 1.08°
 TAN - 0.5°

* Note: The Star Scan MAX dimension shall be reduced to 35.50" as follows:
 Nozzle @ 22° - 239° to 301°
 Nozzle @ 158° - 59° to 122°
 Nozzle @ 202° - 239° to 301°
 Nozzle @ 338° - 59° to 122°

D.C. COOK UNIT 1	
WesDyne International	
SHEET TITLE	Outlet Star, Tan, IR Exams
2010 EXAMINATION PROGRAM PLAN	
ALL DIMENSIONS IN INCHES UNLESS OTHERWISE NOTED	SHEET 16 OF 21

REACTOR VESSEL WELD RESULTS SUMMARY			
PLANT NAME	DC Cook	Unit	1
WELD NO.	1-N3B	COMPONENT	Outlet Nozzle To Shell Weld @ 22 Deg.
LIMITATIONS:	NO <input type="checkbox"/>	YES <input checked="" type="checkbox"/>	71.08 % Complete See Coverage Breakdown Sheet
RESULTS		NO. OF INDICATIONS	2
NI		STATUS	Code Allowable
RI	X		
<u>EXAM DOCUMENTATION</u>		<u>INDICATION DOCUMENTATION</u>	
<input checked="" type="checkbox"/> PARAGON ANALYSIS LOG		<input checked="" type="checkbox"/> ASSESSMENT SHEET	
<input checked="" type="checkbox"/> PARAGON ACQUISITION LOG		<input checked="" type="checkbox"/> PARAGON HARD COPY	
<input checked="" type="checkbox"/> SCAN PRINT OUT		<input type="checkbox"/> OTHER (Specify)	
<input checked="" type="checkbox"/> COVERAGE BREAKDOWN			
Comments:			
Limitation is due to nozzle geometry, vessel saddle effect, and adjacent outlet nozzle protrusion			
Analyst <u>E.P. Zoller</u> Date: <u>3/25/10</u>			

04-20-10:02:23PM

R.V. COVERAGE ESTIMATE BREAKDOWNS

PLANT NAME DO Cook

WesDyne

WELD NO. 1-N3B

International

COMPONENT Outlet Nozzle To Shell Weld @ 22 Deg.

BEAM ANGLE BREAKDOWN

BEAM DIRECTION	Tan Scan	Star Scan	Bore Scan	
	45° L Dual, 45° L Single, 45° Shear	45° L Dual, 45° L Single, 45° Shear	15° 30', 45°, 60°	
CW	42.54			
CCW	42.54			
Out (away from bore)			100.00	
In (toward bore)		89.23		

Comments: Limitation is due to nozzle geometry, vessel saddle effect, and adjacent outlet nozzle protrusion

Combined Avg. 71.08

Analyst E-L Zolner Date 3/25/10

REACTOR VESSEL WELD RESULTS SUMMARY

PLANT NAME DC Cook Unit 1

WELD NO. 1-N4B COMPONENT Outlet Nozzle To Shell Weld @ 158 Deg.

LIMITATIONS: NO YES 71.08 % Complete
See Coverage Breakdown Sheet

RESULTS NO. OF INDICATIONS 1
NI _____ STATUS Code Allowable
RI X

EXAM DOCUMENTATION

INDICATION DOCUMENTATION

PARAGON ANALYSIS LOG

ASSESSMENT SHEET

PARAGON ACQUISITION LOG

PARAGON HARD COPY

SCAN PRINT OUT

OTHER (Specify)

COVERAGE BREAKDOWN

Comments: _____

Limitation is due to nozzle geometry, vessel saddle effect, and adjacent outlet nozzle protrusion

Analyst *[Signature]*

Date: 3/25/10

R.V. COVERAGE ESTIMATE BREAKDOWNS

PLANT NAME DC Cook

WesDyne

WELD NO. 1-N4B

International

COMPONENT Outlet Nozzle To Shell Weld @ 158 Deg.

BEAM ANGLE BREAK DOWN

BEAM DIRECTION	Tan Scan	Star Scan	Bore Scan	
	45° L Dual, 45° L Single, 45° Shear	45° L Dual, 45° L Single, 45° Shear	15° 30°, 45°, 60°	
CW	42.54			
CCW	42.54			
Out (away from bore)			100.00	
In (toward bore)		99.23		

Comments: Limitation is due to nozzle geometry, vessel saddle effect, and adjacent outlet nozzle protrusion

Combined Avg. 71.08

Analyst *[Signature]*

Date *3/6/06*

REACTOR VESSEL WELD RESULTS SUMMARY

PLANT NAME DC Cook Unit 1
WELD NO. 1-N1B COMPONENT Outlet Nozzle To Shell Weld @ 202 Deg.

LIMITATIONS: NO YES 71.08 % Complete
See Coverage Breakdown Sheet

RESULTS NO. OF INDICATIONS 6
NI STATUS Code Allowable
RI X

EXAM DOCUMENTATION

INDICATION DOCUMENTATION

- | | |
|---|---|
| <input checked="" type="checkbox"/> PARAGON ANALYSIS LOG | <input checked="" type="checkbox"/> ASSESSMENT SHEET |
| <input checked="" type="checkbox"/> PARAGON ACQUISITION LOG | <input checked="" type="checkbox"/> PARAGON HARD COPY |
| <input checked="" type="checkbox"/> SCAN PRINT OUT | <input type="checkbox"/> OTHER (Specify) |
| <input checked="" type="checkbox"/> COVERAGE BREAKDOWN | |

Comments: Limitation is due to nozzle geometry, vessel saddle effect, and adjacent outlet nozzle protrusion

Analyst [Signature] Date: 3/25/10

R.V. COVERAGE ESTIMATE BREAKDOWNS

PLANT NAME DC Cook

WesDyne

WELD NO. 1-N1B

International

COMPONENT Outlet Nozzle To Shell Weld @ 202 Deg.


BEAM ANGLE BREAK DOWN

BEAM DIRECTION	Tan Scan	Star Scan	Bore Scan	
	45° L Dual, 45° L Single, 45° Shear	45° L Dual, 45° L Single, 45° Shear	15° 30°, 45°, 60°	
CW	42.54			
CCW	42.54			
Out (away from bore)			100.00	
In (toward bore)		99.23		

Comments: Limitation is due to nozzle geometry, vessel saddle effect, and adjacent outlet nozzle protrusion

Combined Avg. 71.08

Analyst



Date

3/23/10

REACTOR VESSEL WELD RESULTS SUMMARY			
PLANT NAME	<u>DC Cook</u>	Unit	<u>1</u>
WELD NO.	<u>1-N2B</u>	COMPONENT	<u>Outlet Nozzle To Shell Weld @ 338 Deg.</u>
LIMITATIONS:	NO <input type="checkbox"/>	YES <input checked="" type="checkbox"/>	<u>71.08 % Complete</u> <u>See Coverage Breakdown Sheet</u>
RESULTS	NO. OF INDICATIONS <u>8</u>		
NI	<u> </u>	STATUS	<u>Code Allowable</u>
RI	<u> X </u>		
<u>EXAM DOCUMENTATION</u>		<u>INDICATION DOCUMENTATION</u>	
<input checked="" type="checkbox"/> PARAGON ANALYSIS LOG		<input checked="" type="checkbox"/> ASSESSMENT SHEET	
<input checked="" type="checkbox"/> PARAGON ACQUISITION LOG		<input checked="" type="checkbox"/> PARAGON HARD COPY	
<input checked="" type="checkbox"/> SCAN PRINT OUT		<input type="checkbox"/> OTHER (Specify)	
<input checked="" type="checkbox"/> COVERAGE BREAKDOWN			
Comments:			
<u>Limitation is due to nozzle geometry, vessel saddle effect, and adjacent outlet nozzle protrusion</u>			
Analyst <u>EA John</u> Date: <u>3/24/10</u>			

R.V. COVERAGE ESTIMATE BREAKDOWNS

PLANT NAME DC Cook

WesDyne

WELD NO. 1-N2B

International

COMPONENT Outlet Nozzle To Shell Weld @ 338 Deg.

BEAM ANGLE BREAK DOWN

BEAM DIRECTION	Ten Scan	Star Scan	Bore Scan	
	45° L Dual, 45° L Single, 45° Shear	45° L Dual, 45° L Single, 45° Shear	15° 30°, 45°, 60°	
CW	42.54			
CCW	42.54			
Out (away from bore)			100.00	
In (toward bore)		99.23		

Comments: Limitation is due to nozzle geometry, vessel saddle effect, and adjacent outlet nozzle protrusion

Combined Avg. 71.08

Analyst *E.R. Zoller*

Date 3/24/10

04-20-10:02:23PM

ATTACHMENT 2 to AEP-NRC-2011-23

RELIEF REQUEST ISIR-34

EXAMINATION CATEGORY B-B
PRESSURE RETAINING WELDS IN VESSELS OTHER THAN REACTOR VESSELS

RELIEF REQUEST ISIR-34

Relief Request In Accordance with 10 CFR 50.55a(g)(5)(iii)
Inservice Inspection Impracticality

1. ASME Code Components Affected

ASME Code Class: Code Class 1

Examination Category: B-B, Pressure Retaining Welds in Vessels Other Than Reactor Vessels

Item Numbers: B2.40, Steam Generators (Primary Side) – Tubesheet to Head

Component Identification: Listed in Table 1

2. Applicable Code Edition and Addenda

ASME Section XI, 1989 Edition, No addenda

3. Applicable Code Requirement

ASME Section XI, 1989 Edition, Examination Category B-B requires volumetric examination of 100 percent of the weld volume as defined in Table IWB-2500-1 and shown in Figures IWB-2500-1 and IWB-2500-6. The alternative requirements of ASME Section XI, Code Case N-460, approved for use in Regulatory Guide 1.147, Revision 15, allows credit for essentially 100 percent coverage of the welds provided greater than 90 percent of the required volume has been examined.

4. Impracticality of Compliance

Pursuant to 10 CFR 50.55a(g)(5)(iii), relief is requested from the essentially 100 percent volumetric examination coverage requirement for the subject welds due to the geometric configuration and permanent obstructions which limit the volumetric examination coverage of the subject welds.

The Steam Generator Tubesheet to Head Weld (2-24-01) was limited to 72% coverage due to the configuration. Examination coverage was limited due to the proximity of welded pads, nozzles, adjacent piping, hand-hole openings, permanent support brackets, and permanent electrical conduits.

These noted obstructions prevent achieving the essentially 100 percent volume examination coverage required by code.

The limitations and the actual examination coverage attained for each weld for which relief is requested are noted in Table 1.

5. Burden Caused by Compliance

To increase the examination coverage for STM-24-01 requires removal and reinstallation of insulation support ring mounting pads by cutting the mounting pad welds and then reinstalling the mounting pads by welding following completion of the examination. Additionally, to increase examination coverage on the subject weld would require a significant design modification or replacement of components with a different design to eliminate the noted obstructions. This is impractical due to the cost, additional radiation exposure, and impact to plant equipment.

6. Proposed Alternative and Basis for Use

The subject welds received a volumetric examination on the accessible portions of the subject welds to the maximum extent practical given the limitations caused by the geometric configuration and permanent obstructions. Additionally, a visual examination (VT-2) is performed at the end of each refueling outage during the system leakage tests as required by Section XI, IWB-2500-1, Category B-P.

Based upon the examination volumes that were obtained with acceptable results, along with the visual (VT-2) examination performed each refueling outage, it is reasonable to conclude that service induced degradation would be detected. Therefore, these proposed alternatives provide an acceptable level of quality and safety by providing reasonable assurance of structural integrity of the subject welds.

7. Period for Which Relief is Requested

The relief is requested for the Third 10-year inspection interval for Donald C. Cook Nuclear Plant Units 1 and 2, which began on July 1, 1996, and ended April 9, 2010, at the conclusion of the Unit 1 Cycle 23 Refueling Outage. Significant long-term outages (greater than six months) occurred multiple times during the interval and the interval was extended as allowed by IWA-2430(e) and by IWA-2430(d) to accommodate interval planning and scheduling.

Table 1

Component ID	Weld Description	Item Number	Ultrasonic Examination Coverage Attained (%)	Remarks
STM-24-01	Lower Shell to Tubesheet	B2.40	72.0	The completed examination was limited to 72% coverage due to the configuration. Examination coverage was limited due to the proximity of welded pads, nozzles, adjacent piping, hand-hole openings, permanent support brackets, and permanent electrical conduits. One subsurface indication was detected and evaluated as acceptable to IWB-3512-1.

RELIEF REQUEST ISIR-34

EXAMINATION CATEGORY B-B
PRESSURE RETAINING WELDS IN VESSELS OTHER THAN REACTOR VESSELS

SUPPORTING DOCUMENTATION

**D. C. COOK UNIT2
CYCLE 14
COVERAGE REPORT**

Weld No.	Exam Type	Exam No.	X"		Y"		Square Inches Scanned Per Exam	Total Square Inches Scanned	Square Inches Required	Percent	Total Coverage	Remarks
			Start	Stop	Start	Stop						
STM-24-01 Lower shell -to- Tube Sheet	Parallel (Axial scan)	3A1-UP	404.00	414.64	441.70	451.66	106		11500	15767	73%	Limited exams due to proximity of welded pads and adjacent piping.
			414.64	421.81	438.36	451.66	95					
			421.81	427.00	442.50	451.66	48					
			0.00	2.09	442.50	451.66	19					
		3A2-UP	6.00	16.26	442.70	451.66	92					
			16.26	24.24	441.70	451.66	79					
			24.24	37.16	438.98	451.66	164					
		3A3-UP	37.40	41.96	141.98	451.66	1412					
		3A-DN	405.00	427.00	443.25	461.00	391					
			0.00	37.66	443.25	461.00	668					
		3B1-UP	65.00	69.94	441.46	451.66	50					
			69.94	84.38	433.10	451.66	268					
			84.38	94.26	411.18	451.66	400					
		3B2-UP	94.26	102.24	433.10	451.66	148					
			102.20	113.22	442.35	451.66	103					
			113.22	115.50	443.10	451.66	20					
		3B1-DN	115.50	118.92	442.10	451.66	33					
			65.00	84.38	443.25	461.33	350					
			84.38	98.44	458.69	461.29	37					
		3B2-DN	98.44	120.94	443.25	461.33	407					
			138.00	143.70	433.10	451.66	106					
			143.70	153.20	441.98	451.66	92					
		3C-UP	153.20	168.40	433.10	451.66	282					
			168.40	177.52	441.98	451.66	88					
			177.52	193.10	433.10	451.66	289					
		3C-DN	193.10	198.42	441.98	451.66	51					
			138.00	198.42	443.25	461.41	1097					
			198.42	248.56	440.80	451.68	546					
		3D1-UP	204.00	210.84	433.10	440.80	53					
		3D2-UP	241.55	249.15	433.10	440.80	59					
		3D3-UP	198.40	249.32	443.25	461.09	908					
		3D1-DN	249.32	258.42	446.60	461.44	135					
		3D2-DN	279.75	340.17	443.15	451.75	520					
		3E1-UP	286.10	300.16	433.10	443.15	141					
		3E2-UP	310.70	319.01	433.10	443.15	84					
3E3-UP	279.75	339.41	443.25	461.41	1083							
3E-DN	340.00	375.72	443.10	451.74	309							
3F1-UP	347.85	360.39	433.10	443.10	125							
3F2-UP	340.00	375.72	443.25	461.24	643							
3F-DN												
								11500	15767	73%		
	Transverse (Circ scan)	4A-CW	405.00	427.30	443.75	452.49	97		2777	3897	71%	Limited exam due to welded pads, permanent support braces, and electrical conduit.
			0.00	36.66	443.75	452.49	160					
		4A-CCW	405.00	427.30	443.75	452.49	97					
			0.00	36.66	443.75	452.49	160					
		4B-CW	85.00	120.64	443.75	452.87	163					
		4B-CCW	85.00	120.64	443.75	452.87	163					
		4C-CW	138.00	197.72	443.75	452.87	272					
		4C-CCW	138.00	197.72	443.75	452.87	272					
		4D1-CW	249.30	258.70	446.60	452.68	29					
		4D2-CW	198.40	249.30	443.75	452.87	232					
		4D1-CCW	249.30	258.70	446.60	452.68	29					
		4D2-CCW	198.40	249.30	443.75	452.87	232					
		4E-CW	279.75	339.43	443.75	452.87	272					
		4E-CCW	279.75	339.43	443.75	452.87	272					
		4F-CW	340.00	375.84	443.75	452.87	163					
		4F-CCW	340.00	375.84	443.75	452.87	163					

X is the dimension in the circumferential direction measured in inches from vessel 0 degrees.
Y is the dimension in elevation measured in inches from vessel 0°.

Feedwater
Nozzle



Weld 05



Manufacturers
Rating plate



Weld 04



Manufacturers
Rating plate



Weld 01



Areas of
limitations

D.C.Cook Unit 2 - Generator 24

Weld 2-GEN-24-01, 04, & 05

May 2003

coverage gen24.dwg

ATTACHMENT 3

RELIEF REQUEST ISIR-35

EXAMINATION CATEGORY B-D
FULL PENETRATION WELDS OF NOZZLES IN VESSELS – INSPECTION PROGRAM B

RELIEF REQUEST ISIR-35

Relief Request In Accordance with 10 CFR 50.55a(g)(5)(iii)
Inservice Inspection Impracticality

1. ASME Code Components Affected

ASME Code Class: Code Class 1

Examination Category: B-D, Full Penetration Welds of Nozzles in Vessels – Inspection Program B

Item Numbers: B3.110, Pressurizer, Nozzle to Vessel Welds
B3.140, Steam Generators (Primary Side) – Nozzle Inside Radius Section (IRS)

Component Identification: Listed in Table 1

2. Applicable Code Edition and Addenda

ASME Section XI, 1989 Edition, No addenda

3. Applicable Code Requirement

ASME Section XI, 1989 Edition, Examination Category B-D requires volumetric examination of 100 percent of the weld volume as defined in Table IWB-2500-1 and shown in Figures IWB-2500-7(a) thru (d) as applicable. The alternative requirements of ASME Section XI, Code Case N-460, approved for use in Regulatory Guide 1.147, Revision 15, allows credit for essentially 100 percent coverage of the welds provided greater than 90 percent of the required volume has been examined.

4. Impracticality of Compliance

Pursuant to 10 CFR 50.55a(g)(5)(iii), relief is requested from the essentially 100 percent volumetric examination coverage requirement for the subject welds due to the geometric configuration and permanent obstructions which limit the volumetric examination coverage of the subject welds.

The Steam Generator Inner Radius examinations (STM-12-I-IRS, STM-12-O-IRS, STM-14-I-IRS and STM-14-O-IRS) were limited to 34.9%, 36.8%, 40.9% and 25% coverage, respectively. Due to the component geometry, no coverage of the inner radius region can be effectively obtained by scanning from the shell side. No contact could be maintained in the blend radius area.

Additionally, the pressurizer Nozzle to Vessel welds (2-RC-26 and 2-RC-27) were each limited to 75% coverage. Examination limitations were due to the contour of the weld on the nozzle side, where 50% coverage was achieved for both the 45 and 60 degree axial scans.

These noted obstructions prevent achieving the essentially 100 percent volumetric examination coverage required by code.

The limitations and the actual examination coverage attained for each weld for which relief is requested are noted in Table 1.

5. Burden Caused by Compliance

To increase examination coverage on the subject weld would require a significant design modification or replacement of components with a different design to eliminate the noted obstructions. This is impractical due to the cost, additional radiation exposure, and impact to plant equipment.

6. Proposed Alternative and Basis for Use

The subject welds received a volumetric examination on the accessible portions of the subject welds to the maximum extent practical. Additionally, a visual examination (VT-2) is performed at the end of each refueling outage during the system leakage tests as required by Section XI, IWB-2500-1, Category B-P.

Based upon the examination volumes that were obtained with acceptable results, along with the visual (VT-2) examination performed each refueling outage, it is reasonable to conclude that service induced degradation would be detected. Therefore, these proposed alternatives provide an acceptable level of quality and safety by providing reasonable assurance of structural integrity of the subject welds.

7. Period for Which Relief is Requested

The relief is requested for the Third 10-year inspection interval for Donald C. Cook Nuclear Plant Units 1 and 2, which began on July 1, 1996, and ended April 9, 2010, at the conclusion of the Unit 1 Cycle 23 Refueling Outage. Significant long-term outages (greater than six months) occurred multiple times during the interval and the interval was extended as allowed by IWA-2430(e) and by IWA-2430(d) to accommodate interval planning and scheduling.

Table 1

Component ID	Weld Description	Item Number	Ultrasonic Examination Coverage Attained (%)	Remarks
STM-14-I-IRS	Inlet Nozzle Inside Radius Section	B3.140	40.9	The completed examination was limited to 40.9% coverage due to the configuration. Due to the component geometry, no coverage of the inner radius region can be effectively obtained by scanning from the shell side. No contact could be maintained in the blend radius area. No recordable indications detected.
STM-14-O-IRS	Outlet Nozzle Inside Radius Section	B3.140	25.0	The completed examination was limited to 25% coverage due to the configuration. Due to the component geometry, no coverage of the inner radius region can be effectively obtained by scanning from the shell side. No contact could be maintained in the blend radius area. No recordable indications detected.
STM-12-I-IRS	Inlet Nozzle Inside Radius Section	B3.140	34.9	The completed examination was limited to 34.9% coverage due to the configuration. Due to the component geometry, no coverage of the inner radius region can be effectively obtained by scanning from the shell side. No contact could be maintained in the blend radius area. No recordable indications detected.
STM-12-O-IRS	Outlet Nozzle Inside Radius Section	B3.140	36.8	The completed examination was limited to 36.8% coverage due to the configuration. Due to the component geometry, no coverage of the inner radius region can be effectively obtained by scanning from the shell side. No contact could be maintained in the blend radius area. No recordable indications detected.

Table 1 (continued)

Component ID	Weld Description	Item Number	Ultrasonic Examination Coverage Attained (%)	Remarks
2-RC-26	Upper Head to Relief Nozzle	B3.110	75.0	The completed examination was limited to 75% coverage due to the configuration. Exam limitations were due to the contour of the weld on the nozzle side, where 50% coverage was achieved for both the 45 and 60 degree axial scans. No recordable indications detected.
2-RC-27	Upper Head to Relief Nozzle	B3.110	75.0	The completed examination was limited to 75% coverage due to the configuration. Exam limitations were due to the contour of the weld on the nozzle side, where 50% coverage was achieved for both the 45 and 60 degree axial scans. No recordable indications detected.

RELIEF REQUEST ISIR-35

EXAMINATION CATEGORY B-D
FULL PENETRATION WELDS OF NOZZLES IN VESSELS – INSPECTION PROGRAM B

SUPPORTING DOCUMENTATION



UT Calibration/Examination

Site/Unit: DC Cook / 1
 Summary No.: 015000
 Workscope: ISI

Procedure: 54-151-132
 Procedure Rev.: 01
 Work Order No.: 04145023-03

Outage No.: U-C20
 Report No.: UT-05-010
 Page: 1 of 8

Code: ASME XI 1989 Cat./Item: B-D/B3.140 Location: CONT. L4
 Drawing No.: A-6 Description: INLET NOZZLE INSIDE RADIUS SECTION
 System ID: 14
 Component ID: STM-14-I-RS Size/Length: 167" circ Thickness/Diameter: 6 1/8" / 53 9/32"
 Limitations: INSULATION SUPPORT RING & COMPONENT CONFIGURATION Start Time: 1300 Finish Time: 1430

Instrument Settings
 Serial No.: VH-9075
 Manufacturer: KRAUTKRAMER
 Model: USN-58L
 Delay: 16.5822 uS Range: 20.0"
 M/TI Cal/Vel: 0.1273 in/uS Pulser: N/A
 Damping: 1 KHZ Reject: 0
 Rep. Rate: AUTO HIGH Freq.: 2.25 MHZ
 Filter: N/A Mode: SINGLE
 Voltage: HIGH
 Ax. Gain (dB): N/A Circ. Gain (dB): 64.6
1.0 Screen Div. = 2.0 in. of Sound Path
 Linearity Report No.: L-05-002

Search Unit
 Serial No.: 0111PK DB# 35684
 Manufacturer: KBA
 Size: 0.60" X 1.0" Shape: RECTANGLE
 Freq.: 2.25 Mhz Style: Benchmark
 Exam Angle: 35 # of Elements: 1
 Mode: SHEAR
 Measured Angle: 38 DEGREES
 Wedge Style: FLAT
 Search Unit Cable
 Type: RG174
 Length: 12' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	1030	4/1/2005
Inter. Cal.		
Inter. Cal.		
Inter. Cal.		
Final Cal.	1600	4/1/2005

Couplant
 Cal. Batch: 04325
 Type: Ultragel II
 Mfg.: Sonotech
 Exam Batch: 04325
 Type: Ultragel II
 Mfg.: Sonotech

Reference Block
 Serial No.: 037405
 Type: Rompus Steel

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
NOTCH 7	85%	5.3	10.59"
NOTCH 8	65%	6.4	12.73"

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
24.3	2"	80%	1.0	2.005"
52.2	14"	80%	5.5	13.95"
65.3	20"	80%	8.5	20.00"

Calibration Block
 Cal. Block No.: IR-CSCL-24-DCC
 Thickness: N/A Dia.: FLAT
 Cal. Blk. Temp.: 89 F Temp. Tool: VH-8048
 Comp. Temp.: 86 F Temp. Tool: VH-8048
 Exam Surface: NOZZLE & SHELL OD
 Surface Condition: MACHINED

Scan Coverage
 Upstream Downstream Scan dB: 74
 CW CCW Scan dB: 74

Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: No

Comments: SDCN #30-5062334 REV. 00
SEE ATTACHED SHEET FOR NOTES.

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Flesner, Bret T.	II	<i>Bret Flesner</i>	4/1/2005	NA		
N/A	N/A			Site Review	<i>RENE</i>	4/26/05
Key, Michael W.	III	<i>Michael W. Key</i>	4/21/2005	ANII Review	<i>[Signature]</i>	4/27/05



Supplemental Report

Report No.: UT-05-010

Page: 2 of 8

Summary No.: 015000

Examiner:	<u>Flesner, Bret T. <i>Bret Flesner</i></u>	Level:	<u>II</u>	Reviewer:	<u>N/A</u>	Date:	<u></u>
Examiner:	<u>N/A</u>	Level:	<u>N/A</u>	Site Review:	<u>RE N/A</u>	Date:	<u>4/26/05</u>
Other:	<u>Key, Michael W. <i>Key</i></u>	Level:	<u>III</u>	ANII Review:	<u><i>[Signature]</i></u>	Date:	<u>4/27/05</u>

Comments:

Limitations from nozzle configuration:

Due to the component geometry no coverage of the inner radius region can be effectively obtained by scanning from the shell side. Scanning from the nozzle side was performed and 40.9% of the coverage of the inner radius region can be effectively obtained. The limitations are documented below and pictures are attached.

NOTE: With the component configuration detailed in the drawing provided by the utility, the technique in procedure 54-ISI-132-1 would result in skew angles of $\pm 80^\circ$ to cover the examination volume. It is the examiner's opinion that this high degree of skew angle results in misorientation angles too high for probable flaw detection. Scans from the shell side with skew angles from 0° - $\pm 45^\circ$ were performed to meet requirements of 7.2 of the procedure. Scanning was also performed from the nozzle side since lower skew angles are needed to cover the inner radius region. Without scanning from the blend, effective coverage of the entire inner-radius region can not be achieved with skew angles low enough for probable flaw detection. Scans from the nozzle boss with skew angles of $\pm 0^\circ$ to $\pm 45^\circ$ were performed, although coverage was calculated for only skew angles ranging from 0° to $\pm 10^\circ$.

It should be noted that the ASME Section XI examination requirement figures IWB-2500-7(a) - (d) do not represent the ID geometry of the inner radius detailed in the provided drawing. The drawing provided indicates a "Keyway" type feature located in the inner radius examination volume. For coverage calculation the examiner "best fit" the requirements of Figure -2500-7(a) to this examination.

Scan limitations:

1. 154" to 8" due to the insulation support ring. (Total limitation 21")
2. 23" to 32" due to support attachment. (Total limitation 9")

No contact could be maintained in the blend radius area. This liftoff was in an 4" area centered 2" on each side of the blend radius centerline.

Coverage Calculations:

Inner Radius exam volume = 4.88182 square inches
 2.44382 square inches of this area could not be achieved due to component configuration.
 2.44382 square inches + 4.88182 square inches = 49.9% cross-sectional exam volume achieved.
 30" of limited scan circumference ÷ 167" total circumference = 82% of total inner radius circumference scanned.
 49.9% X 82.0% = 40.9% total coverage obtained by scanning from the nozzle side.
 0% coverage obtained by scanning from the shell side.

Examiner: Flesner, Bret T

Date: 04/01/2005



Supplemental Report

Report No.: UT-05-010

Page: 4 of 8

Primary No.: 015000

Examiner: Flesner, Bret T. *Bret T. Flesner* Level: II

Reviewer: N/A

Date: _____

Examiner: _____ Level: _____

Site Review: RENA

Date: 4/26/05


Other: Monkey *Monkey* Level: III

ANII Review: _____

Date: 4/27/05

Comments:

Sketch or Photo: X:\U1C20-Framatome Info\STM-14-I-IRS-G1.jpg





UT Calibration Examination

Site/Unit: DC Cook / 1
 Summary No.: 015100
 Workscope: ISI

Procedure: 54-ISI-132
 Procedure Rev.: 01
 Work Order No.: 04145023-04

Outage No.: C20
 Report No.: UT-05-019
 Page: 1 of 10

Code: ASME XI 1989 Cat./Item: B-D/B3.140 Location: CONT. L4
 Drawing No.: A-6 Description: OUTLET NOZZLE INSIDE RADIUS SECTION
 System ID: 14
 Component ID: STM-14-O-IRS Size/Length: 187.39" CIRC Thickness/Diameter: 6 1/8" / 53 9/32"
 Limitations: INSULATION SUPPORT RING & COMPONENT CONFIGURATION. Start Time: 1430 Finish Time: 1600

Instrument Settings
 Serial No.: VH-9075
 Manufacturer: KRAUTKRAMER
 Model: USN-58L
 Delay: 16.6822 uS Range: 20.0"
 M'll Cal/Vel: 0.1273 In/uS Pulsar: N/A
 Damping: 1 KHZ Reject: 0
 Rep. Rate: AUTO HIGH Freq.: 2.25 MHZ
 Filter: N/A Mode: SINGLE
 Voltage: HIGH
 Ax. Gain (dB): N/A Circ. Gain (dB): 64.6
1.0 Screen Div. = 2 In. of Sound Path
 Linearity Report No.: L-05-002

Search Unit
 Serial No.: 0111PK DB# 36694
 Manufacturer: KBA
 Size: 0.50" X 1.0" Shape: RECTANGLE
 Freq.: 2.25 Mhz Style: Benchmark
 Exam Angle: 35 # of Elements: 1
 Mode: SHEAR
 Measured Angle: 38 DEGREES
 Wedge Style: FLAT

Search Unit Cable
 Type: RG174
 Length: 12' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	1050	4/1/2005
Inter. Cal.		
Inter. Cal.		
Inter. Cal.		
Final Cal.	1600	4/1/2005

Couplant
 Cal. Batch: 04325
 Type: Ultragel II
 Mfg.: Sonotech
 Exam Batch: 04325
 Type: Ultragel II
 Mfg.: Sonotech

Reference Block
 Serial No.: 037405
 Type: Rompus Steel

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
NOTCH 7	85%	5.3	10.59"
NOTCH 8	65%	6.4	12.73"

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
24.3	2"	80%	1.0	2.005"
52.2	14"	80%	5.5	13.95"
65.3	20"	80%	8.5	20.00"

Calibration Block
 Cal. Block No.: IR-CSCL-24-DCC
 Thickness: N/A Dia.: FLAT CW CCW Scan dB: 74
 Cal. Blk. Temp.: 89 Temp. Tool: VH-8048 Exam Surface: NOZZLE & SHELL OD
 Comp. Temp.: 86 Temp. Tool: VH-8048 Surface Condition: MACHINED

Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: No

Comments: SDCN#30-5062334 REV. 00
SEE ATTACHED SHEET FOR NOTES.

Examiner	Level	Signature	Date	Review	Signature	Date
Flesner, Bret T.	II	<i>Bret Flesner</i>	4/1/2005	N/A		
N/A	N/A			Site Review	<i>RENOON</i>	4/27/05
Key, Michael W.	III	<i>Michael W. Key</i>	4/21/2005	ANII Review	<i>[Signature]</i>	<i>[Signature]</i>



Supplemental Report

Report No.: UT-05-019

Page: 2 of 10

Summary No.: 015100

Examiner:	<u>Flesner, Bret T. <i>Bret Flesner</i></u>	Level:	<u>II</u>	Reviewer:	<u>N/A</u>	Date:	<u></u>
Examiner:	<u>N/A</u>	Level:	<u>N/A</u>	Site Review:	<u>RE N/A</u>	Date:	<u>4/27/05</u>
Other:	<u>Key, Michael W. <i>Key</i></u>	Level:	<u>III</u>	ANII Review:	<u><i>[Signature]</i></u>	Date:	<u>4/27/05</u>

Comments:

Limitations from nozzle configuration:

Due to the component geometry no coverage of the inner radius region can be effectively obtained by scanning from the shell side. Scanning from the nozzle side was performed using the techniques in procedure S4-ISI-132-1 and 25.0% of the coverage of the inner radius region can be effectively obtained. The limitations are documented below and pictures are attached.

NOTE:

With the component configuration detailed in the drawing provided by the utility, the technique in procedure 54-ISI-132-1 would result in skew angles of $\pm 80^\circ$ to cover the examination volume. It is the examiner's opinion that this high degree of skew angle results in misorientation angles too high for probable flaw detection. Scans from the shell side with skew angles from 0° - $\pm 45^\circ$ were performed to meet requirements of 7.2 of the procedure. Scanning was also performed from the nozzle side since lower skew angles are needed to cover the inner radius region. Without scanning from the blend, effective coverage of the entire inner-radius region can not be achieved with skew angles low enough for probable flaw detection. Scans from the nozzle boss with skew angles of $\pm 0^\circ$ to $\pm 45^\circ$ were performed, although coverage was calculated for only skew angles ranging from 0° to $\pm 10^\circ$.

It should be noted that the ASME Section XI examination requirement figures IWB-2500-7(a) - (d) do not represent the ID geometry of the inner radius detailed in the provided drawing. The drawing provided indicates a "Keyway" type feature in the inner radius examination volume. For coverage calculation the examiner "best fit" the requirements of Figure IWB-2500-7(a) to this examination.

Scan limitations:

1. 115" to 30" due to the insulation and its support ring. (Total limitation 82")

No contact could be maintained in the blend radius area. This liftoff was in an 4" area centered 2" on each side of the blend radius centerline.

Coverage Calculations:

Inner Radius exam volume= 4.88182 sq in

2.44382 sq in of this area could not be achieved due to component configuration.

2.44382 sq in ÷ 4.88182 sq in = 49.9% cross-sectional exam volume achieved.

82" of limited scan circumference ÷ 167" total circumference = 50.1% of total inner radius circumference scanned.

49.9% X 50.1% = 25.0% total coverage obtained by scanning from the nozzle side.

0% coverage obtained by scanning from the shell side.

Examiner: Bret T Flesner, Level II

Date: 4/1/05




Supplemental Report

Report No.: UT-05-019

Page: 5 of 10

Primary No.: 015100

Sketch or Photo: X:\U1C20-Framatome Info\STM-14-O-IRS-G1.jpg





UT Calibration/ Examination

Site/Unit: DC Cook / 1
 Summary No.: 012900
 Workscope: ISI

Procedure: 54-ISI-132
 Procedure Rev.: 01
 Work Order No.: 04145016-04

Outage No.: U1-C20
 Report No.: UT-05-021
 Page: 1 of 8

Code: ASME XI 1989 Cat./Item: B-D/B3.140 Location: CONT. L2
 Drawing No.: A-6 Description: INLET NOZZLE INSIDE RADIUS SECTION
 System ID: 12
 Component ID: STM-12-I-IRS Size/Length: 167.39" circ Thickness/Diameter: 6 1/8" / 53 9/32"
 Limitations: INSULATION SUPPORT RINGS & COMPONENT CONFIGURATION Start Time: 0830 Finish Time: 1030

Instrument Settings
 Serial No.: VH-9075
 Manufacturer: KRAUTKRAMER
 Model: USN-58L
 Delay: 16.5822 uS Range: 20.0"
 M'tl Cal/Vel: 0.1273 in/uS Pulsar: N/A
 Damping: 1 KHZ Reject: 0
 Rep. Rate: AUTO HIGH Freq.: 2.25 MHZ
 Filter: N/A Mode: SINGLE
 Voltage: HIGH
 Ax. Gain (dB): N/A Circ. Gain (dB): 69.3
1.0 Screen Div. = 2.0 in. of Sound Path
 Linearity Report No.: L-05-002

Search Unit
 Serial No.: 0111PK DB# 35694
 Manufacturer: KBA
 Size: 0.50" X 1.0" Shape: RECTANGLE
 Freq.: 2.25 Mhz Style: Benchmark
 Exam Angle: 35 # of Elements: 1
 Mode: SHEAR
 Measured Angle: 38 DEGREES
 Wedge Style: FLAT

Search Unit Cable
 Type: RG174
 Length: 12' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	0715	3/31/2005
Inter. Cal.		
Inter. Cal.		
Inter. Cal.		
Final Cal.	1220	3/31/2005

Couplant
 Cal. Batch: 98225
 Type: Ultrigel II
 Mfg.: Sonotech
 Exam Batch: 98225
 Type: Ultrigel II
 Mfg.: Sonotech

Reference Block
 Serial No.: 037405
 Type: Rompus Steel

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
NOTCH 7	85%	5.3	10.59"
NOTCH 8	55%	6.5	12.83"

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
28.6	2"	80%	1.0	2.005"
55.5	14"	80%	5.5	13.95"
67.9	20"	80%	8.5	20.00"

Calibration Block
 Cal. Block No.: IR-CACL-24-DCC
 Thickness: N/A Dia.: FLAT
 Cal. Blk. Temp.: 86 Temp. Tool: VH-8048
 Comp. Temp.: 86 Temp. Tool: VH-8048
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info

Scan Coverage
 Upstream Downstream Scan dB: 79.5
 CW CCW Scan dB: 79.5
 Exam Surface: NOZZLE & SHELL OD
 Surface Condition: MACHINED

Percent Of Coverage Obtained > 90%: NO Reviewed Previous Data: No

Comments: SDCN #30-5062334 REV. 00
SEE ATTACHED SHEETS FOR COMMENTS.

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Flesner, Bret T.	II	<i>Bret Flesner</i>	3/31/2005	N/A		
N/A	N/A			Site Review	<i>RE Hall</i>	4/26/05
Key, Michael W.	III	<i>Michael W. Key</i>	4/21/2005	ANII Review	<i>[Signature]</i>	4/26/05



Supplemental Report

Report No.: UT-05-021

Page: 2 of 8

Summary No.: 012900

Examiner: Flesner, Bret T.

Level: II

Reviewer: N/A

Date: _____

Examiner: N/A

Level: N/A

Site Review: [Signature]

Date: 4/26/05

Other: Key, Michael W. [Signature]

Level: III

ANII Review: [Signature]

Date: 4/26/05

Comments:

Limitations from nozzle configuration:

Due to the component geometry no coverage of the inner radius region can be effectively obtained by scanning from the shell side. Scanning from the nozzle side was performed and 34.9% of the coverage of the inner radius region can be effectively obtained. The limitations are documented below and pictures are attached.

NOTE: With the component configuration detailed in the drawing provided by the utility, the technique in procedure 54-ISI-132-1 would result in skew angles of $\pm 80^\circ$ to cover the examination volume. It is the examiner's opinion that this high degree of skew angle results in misorientation angles too high for probable flaw detection. Scans from the shell side with skew angles from 0° - $\pm 45^\circ$ were performed to meet requirements of 7.2 of the procedure. Scanning was also performed from the nozzle side since lower skew angles are needed to cover the inner radius region. Without scanning from the blend, effective coverage of the entire inner-radius region can not be achieved with skew angles low enough for probable flaw detection. Scans from the nozzle boss with skew angles of $\pm 0^\circ$ to $\pm 45^\circ$ were performed, although coverage was calculated for only skew angles ranging from 0° to $\pm 10^\circ$.

It should be noted that the ASME Section XI examination requirement figures IWB-2500-7(a) - (d) do not represent the ID geometry of the inner radius detailed in the provided drawing. The drawing provided indicates a "Keyway" type feature mated in the inner radius examination volume. For coverage calculation the examiner "best fit" the requirements of Figure IWB-2500-7(a) to this examination.

Scan limitations:

1. 143" to 14" due to the insulation support ring. (total limitation 38")
2. 25" to 37" due to support attachment. (total limitation 12")

No contact could be maintained in the blend radius area. This liftoff was in an ~4" area centered ~2" on each side of the blend radius centerline.

Coverage Calculations:

Inner Radius exam volume = 4.88182 sq in

2.44382 sq in of this area could not be achieved due to component configuration.

2.44382 sq in ÷ 4.88182 sq in = 49.9% cross-sectional exam volume achieved.

50" of limited scan circumference ÷ 167" total circumference = 70.0% of total inner radius circumference scanned.

49.9% X 70.0% = 34.9% total coverage obtained by scanning from the nozzle side.

0% coverage obtained by scanning from the shell side.

Examiner: Bret T. Flesner, Level II

Date: March 31, 2005



Supplemental Report


Report No.: UT-05-021

Page: 8 of 8

Primary No.: 012900

Sketch or Photo: X:\U1C20-Framatome Info\STM-12-I-IRS-G1.jpg

A
REVA





UT Calibration/ Examination

Site/Unit: DC Cook / 1
 Summary No.: 013000
 Workscope: ISI

Procedure: 54-ISI-132
 Procedure Rev.: 01
 Work Order No.: 04145016-05

Outage No.: U1-C20
 Report No.: UT-05-020
 Page: 1 of 8

Code: ASME XI 1989 Cat./Item: B-D/B3.140 Location: CONT. L2
 Drawing No.: A-6 Description: OUTLET NOZZLE INSIDE RADIUS SECTION
 System ID: 12
 Component ID: STM-12-O-IRS Size/Length: 167.39" circ Thickness/Diameter: 6 1/8" / 53 9/32"
 Limitations: INSULATION SUPPORT RING & COMPONENT CONFIGURATION Start Time: 1030 Finish Time: 1210

Instrument Settings
 Serial No.: VH-9075
 Manufacturer: KRAUTKRAMER
 Model: USN-58L
 Delay: 16.5822 uS Range: 20.0"
 M/I Cal/Vel: 0.1273 in/uS Pulsar: N/A
 Damping: 1 KHZ Reject: 0
 Rep. Rate: AUTO HIGH Freq.: 2.25 MHZ
 Filter: N/A Mode: SINGLE
 Voltage: HIGH
 Ax. Gain (dB): N/A Circ. Gain (dB): 69.3
1.0 Screen Div. = 2.0 in. of Sound Path
 Linearity Report No.: L-05-002

Search Unit
 Serial No.: 0111PK DB# 35694
 Manufacturer: KBA
 Size: 0.50" X 1.0" Shape: RECTANGLE
 Freq.: 2.25 Mhz Style: Benchmark
 Exam Angle: 35 # of Elements: 1
 Mode: SHEAR
 Measured Angle: 38 DEGREES
 Wedge Style: FLAT
Search Unit Cable
 Type: RG174
 Length: 12' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	0715	3/31/2005
Inter. Cal.		
Inter. Cal.		
Inter. Cal.		
Final Cal.	1220	3/31/2005

Couplant
 Cal. Batch: 98225
 Type: Ultragel II
 Mfg.: Sonotech
 Exam Batch: 98225
 Type: Ultragel II
 Mfg.: Sonotech

Calibration Block
 Cal. Block No.: IR-CSCL-24-DCC
 Thickness: N/A Dia.: FLAT
 Cal. Blk. Temp.: 85 Temp. Tool: VH-8048
 Comp. Temp.: 86 Temp. Tool: VH-8048
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info

Scan Coverage
 Upstream Downstream Scan dB: 79.5
 CW CCW Scan dB: 79.5
 Exam Surface: NOZZLE & SHELL OD
 Surface Condition: MACHINED

Reference Block
 Serial No.: 037405
 Type: Rompus Steel

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
NOTCH 7	85%	5.3	10.59"
NOTCH 8	55%	6.5	12.83"

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
28.6	2"	80%	1.0	2.005"
55.5	14"	80%	5.5	13.95"
67.9	20"	80%	8.5	20.00"

Comments: SDCN #30-5062334 REV. 00
SEE ATTACHED SHEETS FOR COMMENTS.

Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: No

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Flesner, Bret T.	II	<i>Bret Flesner</i>	3/31/2005	N/A		
Examiner	Level	Signature	Date	Site Review	Signature	Date
N/A	N/A			<i>RE Hall</i>		4/27/05
Other	Level	Signature	Date	ANII Review	Signature	Date
Key, Michael W.	III	<i>Michael Key</i>	4/21/2005		<i>[Signature]</i>	4/27/05



Supplemental Report

Report No.: UT-05-020

Page: 2 of 8

Summary No.: 013000

Examiner:	<u>Flesner, Bret T. <i>Bret Flesner</i></u>	Level:	<u>II</u>	Reviewer:	<u>N/A</u>	Date:	<u> </u>
Examiner:	<u>N/A</u>	Level:	<u>N/A</u>	Site Review:	<u>RE N/A</u>	Date:	<u>4/27/05</u>
Other:	<u>Key, Michael W. <i>Key</i></u>	Level:	<u>III</u>	ANII Review:	<u> </u>	Date:	<u>4/27/05</u>

Comments:

Limitations from nozzle configuration:

Due to the component geometry no coverage of the inner radius region can be effectively obtained by scanning from the shell side. Scanning from the nozzle side was performed and 36.8% of the coverage of the inner radius region can be effectively obtained. The limitations are documented below and pictures are attached.

NOTE: With the component configuration detailed in the drawing provided by the utility, the technique in procedure 54-ISI-132-1 would result in skew angles of $\pm 80^\circ$ to cover the examination volume. It is the examiner's opinion that this high degree of skew angle results in misorientation angles too high for probable flaw detection. Scans from the shell side with skew angles from 0° - $\pm 45^\circ$ were performed to meet requirements of 7.2 of the procedure. Scanning was also performed from the nozzle side since lower skew angles are needed to cover the inner radius region. Without scanning from the blend, effective coverage of the entire inner-radius region can not be achieved with skew angles low enough for probable flaw detection. Scans from the nozzle boss with skew angles of $\pm 0^\circ$ to $\pm 45^\circ$ were performed, although coverage was calculated for only skew angles ranging from 0° to $\pm 10^\circ$.

It should be noted that the ASME Section XI examination requirement figures IWB-2500-7(a) - (d) do not represent the ID geometry of the inner radius detailed in the provided drawing. The drawing provided indicates a "Keyway" type feature located in the inner radius examination volume. For coverage calculation the examiner "best fit" the requirements of Figure I-2500-7(a) to this examination.

Scan limitations:

1. 149" to 8" due to the insulation and its support ring. (total limitation 26")
2. 24" to 36" due to support attachment. (total limitation 12")
3. 52" to 58" due to ID plate. (total limitation 6")

No contact could be maintained in the blend radius area. This liftoff was in an 4" area centered 2" on each side of the blend radius centerline.

Coverage Calculations:

Inner Radius exam volume = 4.88182 square inches
 2.44382 square inches of this area could not be achieved due to component configuration.
 2.44382 square inches \div 4.88182 square inches = 49.9% cross-sectional exam volume achieved.
 44" of limited scan circumference \div 167" total circumference = 73.7% of total inner radius circumference scanned.
 49.9% X 73.7% = 36.8% total coverage obtained by scanning from the nozzle side.
 0% coverage obtained by scanning from the shell side.

Examiner: Flesner, Bret T. Level II

Date: March 31, 2005



ULTRASONIC EXAMINATION SCAN LIMITATION REPORT

AMATOME ANP

Customer: DC Cook Unit 2

Component: Branch Connection Weld

Summary No.: 006950

Weld No.: 6"-2-RC-26

Reference Point: See below

1) Interfering Condition

Distance From Centerline To

Distance From Ref. Point To

2) Interfering Condition

Distance From Centerline To

Distance From Ref. Point To

3) Interfering Condition

Distance From Centerline To

Distance From Ref. Point To

(For All Measurements Indicate: US, DS, CW, CCW)


Percent Of Exam Completed
(Calculations Or Comments Below)

45 degree Axial scan - 50% Coverage
45 degree circumferential scan - 100% Coverage
60 degree axial scan - 50% Coverage
60 degree circumferential scan - 100% Coverage

Total Coverage - 75%

Sketch Of Limitation(s):

Examination was limited due to component configuration.



NO AXIAL SCAN FROM
NOZZLE SIDE OF WELD
DUE TO CONFIGURATION.

(INCLUDED THE EXTENT OF % COMPLETED OF EXAM AND REASON FOR LIMITED REPORT, AND SKETCH SHOWING AREA OF LIMITATION.)

Level III: RA Kellerhall

Date: 10/23/04

Examiner: Julien Stanford

Date: 10-15-04

ver: NA

Date:

Customer: Roy E. Hall

Date: 10/25/04

416/490 6/6



ULTRASONIC EXAMINATION SCAN LIMITATION REPORT

AMATOME ANP

Customer: DC Cook Unit 2

Component: Branch Connection Weld

Summary No.: 006960

Weld No.: 6"-2-RC-27

Reference Point: See below

1) Interfering Condition

Distance From Centerline To

Distance From Ref. Point To

2) Interfering Condition

Distance From Centerline To

Distance From Ref. Point To

3) Interfering Condition

Distance From Centerline To

Distance From Ref. Point To

(For All Measurements Indicate: US, DS, CW, CCW)

Percent Of Exam Completed
(Calculations Or Comments Below)

45 degree Axial scan – 50% Coverage

45 degree circumferential scan – 100% Coverage

60 degree axial scan – 50% Coverage

60 degree circumferential scan – 100% Coverage

Total Coverage – 75%

Sketch Of Limitation(s):

Examination was limited due to component configuration.

NOZZLE

HEAD

No Scan From
NOZZLE SIDE OF
WELD (AXIAL) DUE
TO CONFIGURATION.

(INCLUDED THE EXTENT OF % COMPLETED OF EXAM AND REASON FOR LIMITED REPORT, AND SKETCH SHOWING AREA OF LIMITATION.)

Level III: RA Källerhall

R. Källerhall

Date:

10/23/04

Examiner: Julien Stanford

Julien Stanford

Date: 10-15-04

ver: NA

Date:

Customer:

R. E. Hall

Date:

10/25/04

422/490

6/6

ATTACHMENT 4

RELIEF REQUEST ISIR-36

EXAMINATION CATEGORY B-F
PRESSURE RETAINING DISSIMILAR METAL WELDS

RELIEF REQUEST ISIR-36**Relief Request In Accordance with 10 CFR 50.55a(g)(5)(iii)
Inservice Inspection Impracticality****1. ASME Code Components Affected**

ASME Code Class: Code Class 1

Examination Category: B-F, Pressure Retaining Dissimilar Metal Welds

Item Numbers: B5.70, Steam Generator, Nozzle to Safe End Butt Welds

Component Identification: Listed in Table 1

2. Applicable Code Edition and Addenda

ASME Section XI, 1989 Edition, No addenda

3. Applicable Code Requirement

ASME Section XI, 1989 Edition, Examination Category B-F requires volumetric examination of 100 percent of the weld volume as defined in Table IWB-2500-1 and shown in Figure IWB-2500-8. The alternative requirements of ASME Section XI, Code Case N-460, approved for use in Regulatory Guide 1.147, Revision 15, allows credit for essentially 100 percent coverage of the welds provided greater than 90 percent of the required volume has been examined.

4. Impracticality of Compliance

Pursuant to 10 CFR 50.55a(g)(5)(iii), relief is requested from the essentially 100 percent volumetric examination coverage requirement for the subject welds due to the geometric configuration and permanent obstructions which limit the volumetric examination coverage of the subject welds.

The Steam Generator Nozzle to Safe End examinations (STM-12-02R, STM-12-03R, STM-14-02R, and STM-14-03R) were limited to 25.72%, 23.92%, 25.72%, and 23.9% coverage respectively due to the component geometry. Coverage was limited due to tapers, weld contours, and depressions on some of the nozzles.

The Safe End to Elbow examinations (STM-22-02, STM-22-03, STM-23-02, and STM-23-03) were limited to 19.5%, 19.5%, 19.5% and 19.5% coverage respectively due to limitations encountered with the contour of the weld along with depressions on the nozzle side of the weld and the CASS Elbow material.

These noted obstructions prevent achieving the essentially 100 percent volume examination coverage required by code.

The limitations and the actual examination coverage attained for each weld for which relief is requested are noted in Table 1.

5. Burden Caused by Compliance

Class 1 piping and components are often designed with welded joints such as nozzle-to-pipe, pipe-to valve, and pipe-to-pump which can physically obstruct a large portion of the required examination volume. For the welds listed in Table 1, the examinations were performed after the 10 CFR 50.55a mandatory implementation date (November 22, 2002) for Appendix VIII of Section XI. The provided code coverage percentages reflect what is currently allowed by qualified Appendix VIII techniques. Appendix VIII qualified (PDI) procedures have demonstrated that sound beams may potentially be attenuated and distorted when required to pass through austenitic weld metal. However, the PDI qualified methods employ the best available technology for maximizing examination coverage of these types of welds. For the components listed in this relief request, examination was extended to the far side of the weld to the extent permitted by geometry as qualified through PDI. Indiana Michigan Power Company (I&M) has used the best available techniques to examine the subject piping welds. To improve upon these examination coverage percentages, modification and/or replacement of the component would be required. No alternative testing is proposed at this time. I&M has examined the subject welds to the extent practical and will continue to perform pressure testing on the subject welds as required by the Code. I&M also performed surface examinations of 100% of the required area without limitations.

Additionally, for the welds consisting of CASS Elbow material (STM-22-02, STM-22-03, STM-23-02 and STM-23-03), there are currently no Appendix VIII PDI qualified procedures to inspect Cast Austenitic Stainless Steel (CASS) materials. The Steam Generator Inlet and Outlet nozzle configuration includes an austenitic stainless steel safe-end welded to a cast austenitic stainless steel elbow. The Appendix VIII procedure qualified for the examination of austenitic stainless steel welds from the Outside Diameter surface was used to perform a best effort examination of the CASS elbow material.

To increase examination coverage on the subject weld would require a significant design modification or replacement of components with a different design or material to eliminate the noted obstructions or material limitations. This is impractical due to the cost, additional radiation exposure, and impact to plant equipment.

6. Proposed Alternative and Basis for Use

The subject welds received a volumetric examination on the accessible portions of the subject welds to the maximum extent practical. Each weld also received a surface examination without limitations. Additionally, a visual examination (VT-2) is performed at the end of each refueling outage during the system leakage tests as required by Section XI, IWB-2500-1, Category B-P.

Based upon the examination volumes that were obtained with acceptable results along with the completed surface examination and the visual (VT-2) examination performed each refueling outage, it is reasonable to conclude that service induced degradation would be

detected. Therefore, these proposed alternatives provide an acceptable level of quality and safety by providing reasonable assurance of structural integrity of the subject welds. .

7. Period for Which Relief is Requested

The relief is requested for the Third 10-year inspection interval for Donald C. Cook Nuclear Plant Units 1 and 2, which began on July 1, 1996, and ended April 9, 2010, at the conclusion of the Unit 1 Cycle 23 Refueling Outage. Significant long-term outages (greater than six months) occurred multiple times during the interval and the interval was extended as allowed by IWA-2430(e) and by IWA-2430(d) to accommodate interval planning and scheduling.

Table 1

Component ID	Weld Description	Item Number	Ultrasonic Examination Coverage Attained (%)	Remarks
STM-12-02R	Safe End to Inlet Nozzle	B5.70	25.72	The completed examination was limited to 25.72% coverage due to the configuration. The limited coverage of this weld is due to the configuration of the taper transition of the safe end. No recordable indications detected.
STM-12-03R	Safe End to Inlet Nozzle	B5.70	23.92	The completed examination was limited to 23.92% coverage due to the configuration. The limited coverage of this weld is due to the configuration of the taper transition of the safe end. No recordable indications detected.
STM-14-02R	Safe End to Inlet Nozzle	B5.70	25.72	The completed examination was limited to 25.72% coverage due to the configuration. The limited coverage of this weld is due to the configuration of the taper transition of the safe end. No recordable indications detected.
STM-14-03R	Safe End to Inlet Nozzle	B5.70	23.9	The completed examination was limited to 23.9% coverage due to the configuration. The limited coverage of this weld is due to the configuration of the taper transition of the safe end. No recordable indications detected.
STM-22-02	Elbow to Inlet Nozzle	B5.70	19.5	The completed examination was limited to 19.5% coverage due to the configuration. Limitations were encountered due the contour of the weld along with depressions on the nozzle side of the weld and the CASS Elbow material. No relevant indications detected.

Table 1 (continued)

Component ID	Weld Description	Item Number	Ultrasonic Examination Coverage Attained (%)	Remarks
STM-22-03	Elbow to Inlet Nozzle	B5.70	19.5	The completed examination was limited to 19.5% coverage due to the configuration. Limitations were encountered due the contour of the weld along with depressions on the nozzle side of the weld and the CASS Elbow material. No relevant indications detected.
STM-23-02	Elbow to Inlet Nozzle	B5.70	19.5	The completed examination was limited to 19.5% coverage due to the configuration. Limitations were encountered due the contour of the weld along with depressions on the nozzle side of the weld and the CASS Elbow material. No relevant indications detected.
STM-23-03	Outlet Nozzle to Elbow	B5.70	19.5	The completed examination was limited to 19.5% coverage due to the configuration. Limitations were encountered due the contour of the weld along with depressions on the nozzle side of the weld and the CASS Elbow material. No relevant indications detected.

RELIEF REQUEST ISIR-36

EXAMINATION CATEGORY B-F
PRESSURE RETAINING DISSIMILAR METAL WELDS

SUPPORTING DOCUMENTATION



Supplemental Report

STM-12-02R
RET 4/5/2011

Report No.: UT-05-008

Page: 2 of 5

Summary No.: 013100

Examiner: Anderson, Paul S. *[Signature]*

Level: II

Reviewer: N/A

Date:

Examiner: N/A

Level: N/A

Site Review: REVIEW *[Signature]*

Date: 4/25/05

Other: Key, Michael W. *[Signature]*

Level: III

ANII Review: [Signature]

Date: 4/26/01

Comments:

Procedure 54-ISI-829-02 was used as guidance to perform a best effort examination.

Component configuration and contour prevented completing the examination in accordance with 54-ISI-829-02.

45 Shear:

- Gain adjusted to maintain a 5-20% ID Roll throughout exam
- Exam limited to safe end side only due to nozzle configuration
- Axial scan limited on safe end due to taper transition (see coverage) and / or safe end to elbow weld

35 Shear:

- Gain adjusted to maintain a 5-20% ID Roll throughout exam
- Axial scan performed only to help intergate near side
- Scan limited on safe end side due to taper transition and / or safe end to elbow weld.

45RL:

- Gain adjusted to maintain a 5-20% noise level throughout exam
- Exam limited to safe end side only due to nozzle configuration
- Axial scan limited on safe end due to taper transition and / or safe end to elbow weld.

60 RL:

- Gain adjusted to maintain a 5-20% noise level throughout exam
- Exam limited to safe end side only due to nozzle configuration
- Scan limited on safe end due to taper transition
- Procedure 54-ISI-829-02 was used for guidance to perform a best effort examination.
- Component configuration and contour prevented completing the examination in accordance to 54-ISI-829-02

Axial Examination Coverage (CODE)

Total Area	1.5" (width) x 1.25" (height)	= 1.8 SQ IN	
45 Degree S area examined	0.6175" SQ IN	% exam complete = 34.3%	
35 Degree S area examined	1.3 SQ IN	% exam complete = 72.2%	
45 RL area examined	0.097 SQ IN	% exam complete = 5.4%	
60 RL area examined	0	% exam complete = 0.0%	

TOTAL COVERAGE

	AX DN	CIRC DN	CIRC UP	AX UP	
45 S =	0%	+	0%	+	100% + 34.7% = 134.3% / 4 = 33.5%
35 S =	0%	+	0%	+	0% + 72.2% = 72.2% / 4 = 18.05%
45RL =	0%	+	0%	+	100% + 5.4% = 105.4% / 4 = 26.35%
60RL =	0%	+	0%	+	100% + 0% = 100% / 4 = 25.0%

102.9 / 4 = 25.725% RET 4/5/2011

Examiner: Paul S. Anderson

Date: 3/31/05



Supplemental Report


Report No.: UT-05-006

Page: 3 of 5

Summary No.: 013100

Sketch or Photo: X:\U1C20-Framatome Info\STM-12-02.jpg

WELD: STM-12-02
SUMMARY: 013100
REPORT: UT-05-006
PAGE:





Supplemental Report

Report No.: UT-05-022

Page: 2 of 5

Summary No.: 013200

STM-12-03R Ret 4/5/2011

Examiner: <u>Anderson, Paul S.</u>	Level: <u>II</u>	Reviewer: <u>N/A</u>	Date: _____
Examiner: <u>N/A</u>	Level: <u>N/A</u>	Site Review: <u>RE WALK</u>	Date: <u>4/25/05</u>
Other: <u>Key, Michael W.</u>	Level: <u>III</u>	ANII Review: _____	Date: <u>4/26/05</u>

Comments:

Procedure 54ISI-829-02 was used for guidance to perform a best effort examination.

Component configuration and contour prevented completing the examination in accordance to 54-ISI-829-02.

45 Degree S:

- Gain adjusted to maintain a 5-20% ID Roll throughout exam
- Exam limited to safe end side only due to nozzle configuration
- Axial scan limited on safe end due to taper transition (see coverage) and / or safe end to elbow weld

35 Degree S

- Gain adjusted to maintain a 5-20% ID Roll throughout exam
- Axial scan performed only to help interigate near side
- Scan limited on safe end side due to taper transition and / or safe end to elbow weld.

45 RL

- Gain adjusted to maintain a 5-20% noise level throughout exam
- Exam limited to safe end side only due tonozzle configuration
- Axial scan limited on safe end due to taper transition and / or safe end to elbow weld.

60 RL

- Gain adjusted to maintain a 5-20% noise level throughout exam
- Exam limited to safe end side only due to nozzle configuration
- Scan limited on safe end due to taper transition

Axial Examination Coverage (CODE)

Total Area 1.3" x 1.5" = 1.95 sq in.

45 Degree Shear - Area Examined	0.325 sq in	% Exam Complete = 16.6%
35 Degree Shear - Area Examined	1.3 sq in	% Exam Complete = 66.6%
45 Degree RL - Area Examined	0	% Exam Complete = 0%
60 Degree RL - Area Examined	0	% Exam Complete = 0%

TOTAL COVERAGE

	AX UP	CIRC UP	AX DN	CIRC DN	
45 S	= 0%	0%	16.6%	100%	= 29.1%
35 S	= 0%	0%	66.6%	0%	= 16.6%
45 RL	= 0%	0%	0%	100%	= 25%
60 RL	= 0%	0%	0%	100%	= 25%

Examiner: Paul S. Anderson, Level II

95.7/4 = 23.925%
 Date: March 31, 2005
Ret 4/7/2011



Supplemental Report

Report No.: UT-05-022

Page: 4 of 5

Summary No.: 013200

Sketch or Photo:

X:\U1C20-Framatome Info\STM-12-03-G1.jpg

AREVA						WELD PROFILE AND THICKNESS	
Exam Date: 03/31/2005			Summary No.: 013200				
Site: DC Cook Unit 1, C20				Examination Method: UT			
System: STM 12				Identification / Weld ID: STM-12-03			
POSITION	0	90	180	270			
1	0				CROWN HEIGHT: FLUSH		
2	3.8				CROWN WIDTH: 1.2		
3	3.8				NOM. DIAMETER: 30		
4	3.8				WELD LENGTH: 122.75		
5	3.8						
<p>0.97MM "0" @ TDC AND 2 STEEL TO 5 STEEL INTER-FACE</p>							
Prepared By: Paul S Anderson		Date: 3/21/05		Reviewed By: _____		Date: _____	
				Utility Review By: <i>RENOL</i>		Date: <i>4/25/05</i>	



Supplemental Report

Report No.: UT-05-015

Page: 2 of 5

Summary No.: 015200 STM-14-02R Ret# 4/5/2011

Examiner: Anderson, Paul S. Level: II Reviewer: N/A Date: _____

Examiner: N/A Level: N/A Site Review: RE [Signature] Date: 4/25/05

Other: Key, Michael W. Level: III ANII Review: [Signature] Date: 4/26/05

Comments:

Due to the procedures limitation with scans conducted from tapers, procedure 54-ISI-829-02 was used for guidance to perform a best effort examination. In addition, component configuration and contour prevented completing the examination in accordance to 54-ISI-829-02. Axial cal used in circ scan.

45 Degree S:

- Gain adjusted to maintain a 5-20% ID Roll throughout exam
- Exam limited to safe end side only due to nozzle configuration
- Axial scan limited on safe end due to taper transition (see coverage) and / or safe end to elbow weld.

35 Degree S:

- Gain adjusted to maintain a 5-20% ID Roll throughout exam.
- Axial scan performed only to help interigate near side
- Scan limited on safe end side due to taper transition and / or safe end to elbow weld.

45 RL:

- Gain adjusted to maintain a 5-20% noise level throughout exam
- Exam limited to safe end side only due to nozzle configuration
- Axial scan limited on safe end due to taper transition and / or safe end to elbow weld.

60 RL:

- Gain adjusted to maintain a 5-20% noise level throughout exam
- Exam limited to safe end side only due to nozzle configuration
- Scan limited on safe end due to taper transition

Axial Examination Coverage (CODE)

Total Area	1.5" (width) x 1.25" (Height) = 1.8 SQ IN	
45 Degrees S Area Examined	0.6175 SQ IN	% Exam Complete = 34.3%
35 Degrees S Area Examined	1.3 SQ IN	% Exam Complete = 72.2%
45 RL Area Examined	0.097 SQ IN	% Exam Complete = 5.4%
60 RL Area Examined	0	% Exam Complete = 0.0%

TOTAL COVERAGE

	AX UP		CIRC UP		CIRC DN		AX DN			
45S	=	0%	+	0%	+	100%	+	34.7%	=	134.3% / 4 = 33.5%
35S	=	0%	+	0%	+	0%	+	72.2%	=	72.2% / 4 = 18.05%
45RL	=	0%	+	0%	+	100%	+	5.4%	=	105.4% / 4 = 26.35%
60RL	=	0%	+	0%	+	100%	+	0%	=	100% / 4 = 25.0%

102.9/4 = 25.725%
Ret# 4/7/2011

Examiner: Paul Anderson

Date: 4/1/2005



Supplemental Report


Report No.: UT-05-015

Page: 4 of 5

Summary No.: 015200

Sketch or Photo: X:\U1C20-Framatome Info\STM-14-02.jpg

WELD: STM-14-02
SUMMARY: 015200
REPORT: UT-05-015
PAGE:





Supplemental Report

Report No.: UT-05-011

Page: 2 of 5

Summary No.: **015300**

Examiner: <u>Anderson, Paul S.</u>	Level: <u>II</u>	Reviewer: <u>N/A</u>	Date: _____
Examiner: <u>N/A</u>	Level: <u>N/A</u>	Site Review: <u>REVIEW</u>	Date: <u>4/25/05</u>
Other: <u>Key, Michael W.</u>	Level: <u>III</u>	ANII Review: <u>[Signature]</u>	Date: <u>4/26/05</u>

Comments:

Procedure 54-ISI-829-02 was used for guidance to perform a best effort examination. The following issues prevented performing a complete examination in accordance with 54-ISI-829-02.

- Component configuration
- Transitional of OD taper at safe end to elbow weld

45 Degree S:

- Gain adjusted to maintain a 5-20% ID Roll throughout exam
- Exam limited to safe end side only due to nozzle configuration
- Axial scan limited on safe end due to taper transition (see coverage) and / or safe end to elbow weld

35 Degree S: (Supplemental)

- Gain adjusted to maintain a 5-20% ID Roll throughout exam
- Axial scan performed only to help interigate near side
- Scan limited on safe end side due to taper transition and / or safe end to elbow weld.

45 RL:

- Gain adjusted to maintain a 5-20% noise level throughout exam.
- Exam limited to safe end side only due to nozzle configuration
- Axial scan limited on safe end due to taper transition and / or safe end to elbow weld.
- Transducer does not meet freq. requirements for circ scans
- Focal depth = 2.7", squint angle = 3 degrees

60 RL

- Gain adjusted to maintain a 5-20% noise level throughout exam
- Exam limited to safe end side only due to nozzle configuration
- Scan limited on safe end due to taper transition
- Focal depth = 2.1", squint angle = 3 degrees

Axial Examination Coverage (CODE)

TOTAL AREA 1.3" x 1.5" = 1.95 SQ IN

45 Degree SHEAR - AREA Examined	0.325 SQ IN	% Exam Complete = 16.6%
35 Degree SHEAR - AREA Examined	1.3 SQ IN	% Exam Complete = 66.6%
45 Degree RL - AREA Examined	0	% Exam Complete = 0%
60 Degree RL - AREA Examined	0	% Exam Complete = 0%

TOTAL COVERAGE

	AX UP	CIRC UP	AX DN	CIRC DN		
45S	= 0%	0%	16.6%	100%	=	29.1%
35S	= 0%	0%	66.6%	0%	=	16.6%
45RL	= 0%	0%	0%	100%	=	25%
60RL	= 0%	0%	0%	100%	=	25%
			TOTAL		=	23.9% (Code Coverage NOT PDI)

Examiner: Paul Anderson Level II

Date: 4/1/05



Supplemental Report


Report No.: UT-05-011

Page: 4 of 5

Summary No.: 016300

Sketch or Photo: X:\U1C20-Framatome Info\STM-14-03-G4.jpg

12-13





EXAMINATION SUMMARY

EXAMINATION SUMMARY

Examination No.: 009800

Data Package: N/A

Exam Date: 10/13/2004

Customer: DC Cook 2

Examination Methods: UT and PT

System / Component ID: Steam Generator / STM-22-02

Examination Procedures: 54-ISI-829-02 and 54-ISI-240-40

Component Description: ELBOW TO INLET NOZZLE

Calibration Sheets No(s): U2C15-Cal-011, U2C15-Cal-012, U2C15-Cal-013, U2C15-Cal-014

Examination Category: B-F

Examination Results: No Reportable Indications

Reportable Indications

ISO / Drawing: A-6

Geometric

Summary:

A PT and UT exam was performed on weld STM-22-02.

The PT examination was performed with no recordable indications and no limitations.

The UT examination revealed recordable geometric indications and scan limitations. Geometric indications were noted in the root area intermittently 360 degrees. See the attached indication data sheets.

Scan limitations were encountered due to cast stainless elbow, weld contour, and depressions on the nozzle side of the weld. For the 45 degree shear wave, 37.5% of the base material in the area of interest was scanned. For the 45 degree refracted longitudinal wave (RL), 10.2% of the required examination volume was covered. For the 60 degree RL, 10.8% of the required examination was covered. See attached Ultrasonic Examination Scan Limitation Report for areas and percentages of coverage.

The above procedure was used to provide guidance to perform a best effort examination. Weld crown configurations and the cast stainless material prevented performing a complete examination in accordance with the above procedure.

Thickness and profiles were taken and are included in the data package. .

Prepared By: John Langdon

Date: 10/18/2004

Reviewed By: RA Kellerhall

Date:

10/20/04

Customer:

Sign:

Date:

10/21/04

Page 1 of 12

223/490



ULTRASONIC EXAMINATION SCAN LIMITATION REPORT

FRAMATOME ANP

Order: DC Cook Unit 2

Component: STM-22-02

Summary No.: 009800

Weld No.: STM-22-02

Reference Point

1) Interfering Condition Weld Ground area (depression in weld)

Distance From Centerline 1.25" DS To 1.75" DS

Distance From Ref. Point 100.5" CW To 104.8" CW

2) Interfering Condition

Distance From Centerline To

Distance From Ref. Point To

3) Interfering Condition

Distance From Centerline To

Distance From Ref. Point To

(For All Measurements Indicate: US, DS, CW, CCW)

Percent Of Exam Completed

(Calculations Or Comments Below)

Scanning of the weld could not be performed due to the irregular contour of the weld.

Scanning of the elbow side of the weld was not performed due to the material being cast stainless steel.

Coverage was achieved as follows.

Nozzle side scans

- 45 degree shear wave- 37.5%

- 45 degree RL 10.2%

- 60 degree RL 10.8%

$$\frac{58.5}{3} = 19.5\%$$

REH 4/7/2011

Sketch Of Limitation(s):

See attached coverage plot for limitations.

(INCLUDED THE EXTENT OF % COMPLETED OF EXAM AND REASON FOR LIMITED REPORT, AND SKETCH SHOWING AREA OF LIMITATION.)

Level: RA Kellerhall

RA Kellerhall

Date:

10/20/04

Examiner: Edward P. Mazyck

Edward P. Mazyck

Date:

10/13/2004

Order:

N/A

Date:

N/A

Order:

Ray E. Wade 10/21/04

Date:


10/12
232/490

COVERAGE PLOT
STM-22-02
INLET NOZZLE
(TOWARD RPV)

NOZZLE
VESSEL

← FLOW

ELBOW



Edward P. Magyok
LEVEL II 10/13/2004

RAK 12/12
234/490



FRAMATOME ANP

EXAMINATION SUMMARY

ary No.:009900	Data Package: N/A	Exam Date: 10/13/2004
Customer: DC Cook 2	Examination Methods: UT and PT	
System / Component ID: Steam Generator / STM-22-03	Examination Procedures: 54-ISI-829-02 and 54-ISI-240-40	
Component Description: Outlet Nozzle to Elbow	Calibration Sheets No(s): U2C15-Cal-011, U2C15-Cal-012, U2C15-Cal-013, U2C15-Cal-014	
Examination Category: B-F	Examination Results: <input type="checkbox"/> No Reportable Indications	
ISO / Drawing:A-6	<input type="checkbox"/> Reportable Indications	
	<input checked="" type="checkbox"/> Geometric	

Summary:

A PT and UT exam was performed on weld STM-22-03.

The PT examination was performed with no recordable indications and no limitations.

The UT examination revealed recordable geometric indications and scan limitations. Geometric indications were noted in the root area intermittently 360 degrees. See the attached indication data sheets.

Scan limitations were encountered due to cast stainless elbow, weld contour, and depressions on the nozzle side of the weld. For the 45 degree shear wave, 37.5% of the base material in the area of interest was scanned. For the 45 degree refracted longitudinal wave (RL), 10.2% of the required examination volume was covered. For the 60 degree RL, 10.8% of the required examination was covered. See attached Ultrasonic Examination Scan Limitation Report for areas and percentages of coverage.

above procedure was used to provide guidance to perform a best effort examination. Weld crown configurations and the cast stainless material prevented performing a complete examination in accordance with the above procedure.

Thickness and profiles were taken and are included in the data package. .

Prepared By: JW Langdon <i>JW Langdon</i>	Date: 10/18/2004	Reviewed By: RA Kellerhall <i>RA Kellerhall</i>	Date: 10/19/04
Signer: <i>Perry E. Hall</i>	Date: 10/25/04	Page 6 of 11	

258/490



ULTRASONIC EXAMINATION SCAN LIMITATION REPORT

FRAMATOME ANP

Number: DC Cook Unit 2

Component: STM-22-03

Summary No.: 009900

Weld No.: STM-22-03

Reference Point

1) Interfering Condition Weld Ground area (depression in weld)

Distance From Centerline 0.5" US To 1.4" US

Distance From Ref. Point 47.25" CW To 51" CW

2) Interfering Condition Weld Ground area (depression in weld)

Distance From Centerline 0.4" US To 1.4" US

Distance From Ref. Point 52.25" CW To 55" CW

3) Interfering Condition

Distance From Centerline To

Distance From Ref. Point To

(For All Measurements Indicate: US, DS, CW, CCW)

Percent Of Exam Completed

(Calculations Or Comments Below)

Scanning of the weld could not be performed due to the irregular contour of the weld.

Scanning of the elbow side of the weld was not performed due to the material being cast stainless steel.

Coverage was achieved as follows.

Nozzle side scans

- 45 degree shear wave- 37.5%
- 45 degree RL 10.2%
- 60 degree RL 10.8%

Sketch Of Limitation(s):

See attached coverage plot for limitations.

(INCLUDED THE EXTENT OF % COMPLETED OF EXAM AND REASON FOR LIMITED REPORT, AND SKETCH SHOWING AREA OF LIMITATION)

Level III: RA Kellerhall

Date:

Examiner: Edward P. Mazyck

Date:

RA Kellerhall III

10/19/04

Edward P. Mazyck

10/13/2004

Number:

N/A

Date:

N/A

Number:

Prof E Hall

Date:

10/25/04


264/490 7/11

COVERAGE Plot
STM-22-03
OUTLET NOZZLE
(TOWARD PUMP)

NOZZLE
VESSEL

Flow →

Elbow



R. E. Nall
10/25/04

Edward P. Maggach
LEVEL II 10/13/2004
PAC 10/14/04
267/490 10/11

A**EXAMINATION SUMMARY****RAMATOME ANP**

Primary No.: 010700

Data Package: N/A

Exam Date: 10/12/2004

Customer: DC Cook 2

Examination Methods: UT and PT

System / Component ID: Steam Generator / STM-23-02

Examination Procedures: 54-ISI-829-02 and 54-ISI-240-40

Component Description: ELBOW TO INLET NOZZLE

Calibration Sheets No(s): U2C15-Cal-011, U2C15-Cal-012, U2C15-Cal-013, U2C15-Cal-014

Examination Category: B-F

Examination Results: No Reportable Indications Reportable Indications

ISO / Drawing: A-6

 Geometric**Summary:**

A PT and UT exam was performed on weld STM-23-02.

The PT examination was performed with no recordable indications and no limitations.

The UT examination revealed recordable geometric indications and scan limitations. Geometric indications were noted in the root area intermittently 360 degrees. See the attached indication data sheets.

Scan limitations were encountered due to cast stainless elbow, weld contour, and depressions on the nozzle side of the weld. For the 45 degree shear wave, 37.5% of the base material in the area of interest was scanned. For the 45 degree refracted longitudinal wave (RL), 10.2% of the required examination volume was covered. For the 60 degree RL, 10.8% of the required examination was covered. See attached Ultrasonic Examination Scan Limitation Report for areas and percentages of coverage.

The above procedure was used to provide guidance to perform a best effort examination. Weld crown configurations and the cast stainless material prevented performing a complete examination in accordance with the above procedure.

Thickness and profiles were taken and are included in the data package.

Prepared By: John Langdon

Date: 10-18-2004

Reviewed By: RA Kellerhall

Date:

Sign:

10/21/04

Customer:

Date:

Sign:

10/24/04

Page 1 of 12

235/490



ULTRASONIC EXAMINATION SCAN LIMITATION REPORT

RAMATOME ANP

Customer: DC Cook Unit 2		Component: STM-23-02		Summary No.: 010700	
Weld No.: STM-23-02			Percent Of Exam Completed		
Reference Point			(Calculations Or Comments Below)		
1) Interfering Condition Weld Ground area (depression in weld)			Scanning of the weld could not be performed due to the irregular contour of the weld.		
Distance From Centerline		1.0" DS	To	1.5" DS	
Distance From Ref. Point		97" CW	To	115" CW	
2) Interfering Condition			Scanning of the elbow side of the weld was not performed due to the material being cast stainless steel.		
Distance From Centerline			To		
Distance From Ref. Point			To		
3) Interfering Condition			Coverage was achieved as follows.		
Distance From Centerline			To		
Distance From Ref. Point			To		
(For All Measurements Indicate: US, DS, CW, CCW)			Nozzle side scans		
			- 45 degree shear wave- 37.5%		
			- 45 degree RL 10.2%		
			- 60 degree RL 10.8%		

Sketch Of Limitation(s):

See attached coverage plot for limitations.

(INCLUDED THE EXTENT OF % COMPLETED OF EXAM AND REASON FOR LIMITED REPORT, AND SKETCH SHOWING AREA OF LIMITATION.)

Level III: RA Kellerhall	Date: 10/21/04	Examiner: Edward P. Mazyck	Date: 10/13/2004
Signature: <i>RA Kellerhall</i>		Signature: <i>Edward P. Mazyck</i>	
Signature: <i>Roger Wall</i>	Date: 10/24/04	Date: N/A	
Customer: <i>Roger Wall</i>			


244/490 10/12

COVERAGE PLOT
STM-23-02
INLET NOZZLE
(TOWARD RPV)

NOZZLE
VESSEL

← Flow

ELBOW



RECALL 10/24/04
Edward P. Mapp
LEVEL II 10/13/2004
RAK 12/12
346/490



FRAMATOME ANP

EXAMINATION SUMMARY

Weld No.: 010800

Data Package: N/A

Exam Date: 10/12/2004

Customer: DC Cook 2

Examination Methods: UT and PT

System / Component ID: Steam Generator / STM-23-03

Examination Procedures: 54-ISI-829-02 and 54-ISI-240-40

Component Description: OUTLET NOZZLE TO ELBOW

Calibration Sheets No(s): U2C15-Cal-011, U2C15-Cal-012, U2C15-Cal-013, U2C15-Cal-014

Examination Category: B-F

Examination Results: No Reportable Indications

Reportable Indications

ISO / Drawing: A-6

Geometric

Summary:

A PT and UT exam was performed on weld STM-23-03.

The PT examination was performed with no recordable indications and no limitations.

The UT examination revealed recordable geometric indications and scan limitations. Geometric indications were noted in the root area intermittently 360 degrees. See the attached indication data sheets.

Scan limitations were encountered due to cast stainless elbow, weld contour, and depressions on the nozzle side of the weld. For the 45 degree shear wave, 37.5% of the base material in the area of interest was scanned. For the 45 degree refracted longitudinal wave (RL), 10.2% of the required examination volume was covered. For the 60 degree RL, 10.8% of the required examination was covered. See attached Ultrasonic Examination Scan Limitation Report for areas and percentages of coverage.

The above procedure was used to provide guidance to perform a best effort examination. Weld crown configurations and the cast stainless material prevented performing a complete examination in accordance with the above procedure.

Thickness and profiles were taken and are included in the data package. .

Prepared By: John Langdon

Date: 10/18/2004

Reviewed By: RA Kellerhall

Date:

John Langdon

RA Kellerhall

10/21/04

Number:

Date:

Sign:

Roy E. Hall

10/25/04

Page 1 of 12

269/490



ULTRASONIC EXAMINATION SCAN LIMITATION REPORT

FRAMATOME ANP

mer: DC Cook Unit 2

Component: STM-23-03

Summary No.: 010800

Weld No.: STM-23-03

Reference Point

1) Interfering Condition Weld Ground area (depression in weld)

Distance From Centerline 0.5" US To 1.8" US

Distance From Ref. Point 114" CW To 117" CW

2) Interfering Condition Weld Ground area (depression in weld)

Distance From Centerline 0.5" US To 1.8" US

Distance From Ref. Point 118" CW To 10.5" CW

3) Interfering Condition

Distance From Centerline To

Distance From Ref. Point To

(For All Measurements Indicate: US, DS, CW, CCW)

Percent Of Exam Completed

(Calculations Or Comments Below)

Nozzle side of weld was limited from 114" to 117" and 118" to 10.5", with a W of 0.5" to 1.80", due to grind out areas.

Scanning of the weld could not be performed due to the irregular contour of the weld.

Scanning of the elbow side of the weld was not performed due to the material being cast stainless steel.

Coverage was achieved as follows.

Nozzle side scans

- 45 degree shear wave- 37.5%
- 45 degree RL 10.2%
- 60 degree RL 10.8%

Sketch Of Limitation(s):

See attached Coverage Plot for contours causing scan limitations

(INCLUDED THE EXTENT OF % COMPLETED OF EXAM AND REASON FOR LIMITED REPORT, AND SKETCH SHOWING AREA OF LIMITATION.)

Level III: RA Kellerhall

RA Kellerhall

Date:

10/21/04

Examiner: Edward P. Mazyck

Edward P. Mazyck

Date:

10/12/2004

ver:

N/A

Date:

N/A

mer:

Perry E. Noll

10/25/04


Date:

278/490

10/12

NOZZLE
VESSEL

COVERAGE PHOTO
STM-23-03
OUT NOZZLE
(TOWARD PUMP)



Page 2
10/25/04

Edward P. Maynard
LEVEL II 10/13/2004
280/490 Date 12/12

ATTACHMENT 5

RELIEF REQUEST ISIR-37

EXAMINATION CATEGORY B-J
PRESSURE RETAINING WELDS IN PIPING

RELIEF REQUEST ISIR-37

Relief Request In Accordance with 10 CFR 50.55a(g)(5)(iii)
Inservice Inspection Impracticality

1. ASME Code Components Affected

ASME Code Class: Code Class 1

Examination Category: B-J, Pressure Retaining Welds in Piping

Item Numbers: B9.11, NPS 4 and Larger, Circumferential Welds
B9.31, Branch Pipe Connection Welds, NPS 4 or Larger

Component Identification: Listed in Table 1

2. Applicable Code Edition and Addenda

ASME Section XI, 1989 Edition, No addenda

3. Applicable Code Requirement

ASME Section XI, 1989 Edition, Examination Category B-J requires volumetric examination of 100 percent of the weld volume as defined in Table IWB-2500-1 and shown in Figures IWB-2500-8, or IWB-2500-9, -10 or -11. The alternative requirements of ASME Section XI, Code Case N-460, approved for use in Regulatory Guide 1.147, Revision 15, allows credit for essentially 100 percent coverage of the welds provided greater than 90 percent of the required volume has been examined.

4. Impracticality of Compliance

Pursuant to 10 CFR 50.55a(g)(5)(iii), relief is requested from the essentially 100 percent volumetric examination coverage requirement for the subject welds due to the geometric configuration and permanent obstructions which limit the volumetric examination coverage of the subject welds.

Due to the component geometry coverage was limited due to tapers, bevels, weld contours, and joint configurations.

These noted obstructions prevent achieving the essentially 100 percent volume examination coverage required by code.

The limitations and the actual examination coverage attained for each weld for which relief is requested are noted in Table 1.

5. Burden Caused by Compliance

During ultrasonic examination of the piping welds listed in Table 1 of this relief request, 100 percent coverage of the required examination volume could not be obtained. Class 1 piping and components are often designed with welded joints such as nozzle-to-pipe, pipe-to-valve, and pipe-to-pump which can physically obstruct a large portion of the required examination volume. For the welds listed in Table 1, the examinations were performed using Appendix VIII of Section XI as modified by the PDI program. The provided code coverage percentages reflect what is allowed by qualified Appendix VIII techniques. Appendix VIII qualified PDI procedures have demonstrated that sound beams may potentially be attenuated and distorted when required to pass through austenitic weld metal. However, the PDI qualified methods employ the best available technology for maximizing examination coverage of these types of welds. For all the components listed in this relief request, examination was extended to the far side of the weld to the extent permitted by geometry, but this portion of the examination is not included in the reported coverage for welds examined under PDI and Appendix VIII rules. Indiana Michigan Power Company (I&M) has used the best available techniques to examine the subject piping welds. To improve upon these examination coverage percentages, modification and/or replacement of the component would be required. No alternative testing is proposed at this time. I&M has examined the subject welds to the extent practical and will continue to perform pressure testing on the subject welds as required by the Code.

To increase examination coverage on the subject weld would require a significant design modification or replacement of components with a different design or material to eliminate the noted obstructions or material limitations. This is impractical due to the cost, additional radiation exposure and impact to plant equipment.

6. Proposed Alternative and Basis for Use

The subject welds received a volumetric examination on the accessible portions of the subject welds to the maximum extent practical. Each weld also received a surface examination without limitations. Additionally, a visual examination (VT-2) is performed at the end of each refueling outage during the system leakage tests as required by Section XI, IWB-2500-1, Category B-P.

Based upon the examination volumes that were obtained with acceptable results along with the completed surface examination and the visual (VT-2) examination performed each refueling outage, it is reasonable to conclude that service induced degradation would be detected if present. Therefore, these proposed alternatives provide an acceptable level of quality and safety by providing reasonable assurance of structural integrity of the subject welds.

7. Period for Which Relief is Requested

The relief is requested for the Third 10-year inspection interval for Donald C. Cook Nuclear Plant Units 1 and 2, which began on July 1, 1996, and ended April 9, 2010, at the conclusion of the Unit 1 Cycle 23 Refueling Outage. Significant long-term outages (greater than six months) occurred multiple times during the interval and the interval was extended as allowed by IWA-2430(e) and by IWA-2430(d) to accommodate interval planning and scheduling.

Table 1

Component ID	Weld Description	Item Number	Ultrasonic Examination Coverage Attained (%)	Remarks
1-RH-28-05F	Pipe to Pipe	B9.11	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration prevents examination on the penetration side due to the bevel and the contour of the ID and OD. No relevant indications detected.
1-SI-22-18F	Pipe to Valve	B9.11	50.0	The completed examination was limited to 50% coverage due to the configuration. The coverage limitation was due to the OD bevel configuration on the valve side of the weld. No relevant indications detected.
1-SI-23-17F	Pipe to Valve	B9.11	50.0	The completed examination was limited to 50% coverage due to the configuration. The coverage limitation was due to the OD bevel configuration on the valve side of the weld. No relevant indications detected.
1-RC-5-01F	Branch to Pipe	B9.11	50.0	The completed examination was limited to 50% coverage due to the configuration. The exam limitation was due to the proximity of the branch connection to the branch side weld. No relevant indications detected.
1-SI-33-23S	Tee to Pipe	B9.11	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration prevents examination on the tee side due to the sharp bevel adjacent to the tee side weld toe. No relevant indications detected.
2-RC-22-01	Safe End to Elbow	B9.11	65.0	The completed examination was limited to 65% coverage due to the configuration. The configuration prevents examination due to the geometry of the safe end. No relevant indications detected.

Table 1 (continued)

Component ID	Weld Description	Item Number	Ultrasonic Examination Coverage Attained (%)	Remarks
2-RC-28-23	Tee to Pipe	B9.11	66.7	The completed examination was limited to 66.7% coverage due to the configuration. The configuration prevents examination on the tee side due to the sharp bevel adjacent to the tee side weld toe. No relevant indications detected.
2-SI-56-19	Tee to Pipe	B9.11	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration prevents examination on the tee side due to the sharp bevel adjacent to the tee side weld toe. No relevant indications detected.
2-RH-33-01	Branch to Pipe	B9.11	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration prevents examination on the tee side due to the sharp bevel adjacent to the tee side weld toe. No relevant indications detected.
2-RC-17-08N	Branch to Pipe	B9.31	34.0	The completed examination was limited to 34% coverage due to the configuration. Limitations were based on the joint configuration. No axial scans were performed on the downstream side of the weld along with no circumferential scans on the branch connection weld due to the contour of the weld. In addition, circumferential scans could only be performed on the branch connection base material. No relevant indications detected.

RELIEF REQUEST ISIR-37

EXAMINATION CATEGORY B-J
PRESSURE RETAINING WELDS IN PIPING

SUPPORTING DOCUMENTATION

INCOMPLETE EXAMINATION REPORT

REPORT NO: UC18-UT-015
PAGE 4 OF 4
DATA PKG: N/A
PROCEDURE: 83A6228 REV2

PLANT/UNIT: D.C. COOK / UNIT 1 WELD NO: 1-RH-28-05F SYSTEM: RH

CONFIGURATION: PIPE TO PENETRATION

ASME CODE CLASS: C-F-1

CODE EXAMINATION REQUIREMENTS: IN ACCORDANCE TO 1989 SECTION XI, FIGURE IWC-2500-7(a)

INTERFERING CONDITION: SINGLE-SIDED ACCESS DUE TO CONFIGURATION. SINGLE SIDED ACCESS EXAMINATION PERFORMED IN ACCORDANCE WITH PROCEDURE PARAGRAPH 2.3. PENETRATION SIDE LIMITED BY BEVEL WD ID/OD CONTOUR.

ESTIMATE OF TOTAL % CODE COMPLETE: 50% SKETCH ATTACHED: YES NO X

PARTIAL EXAMINATION PERFORMED: YES X NO NO

EXAMINATION ANGLE AFFECTED:

0 DEGREE WRV YES 0 DEGREE BASE MATERIAL N/A

45 DEGREE AXIAL YES 45 DEGREE CIRCUMFERENTIAL YES

OTHER: * 70° AXIAL

ALTERNATE METHOD RECOMMENDED: YES NO X

EXPLANATION: * EXAMINATION PERFORMED IN ACCORDANCE TO 83A6228, REV 2

PREPARED BY: Dennis P. Strickland

DATE: 5-15-02

REVIEWED: Shirley

DATE: 5-17-02

WELDED STRIP




Visual Component Database



Component Number: 1-CPN-47

Image Title: 1-CPN-47

Image Date: 04/15/1985



Date Printed: 05/30/2002 11:38 AM

INCOMPLETE EXAMINATION REPORT

REPORT NO: UIC18-UT-019
PAGE 8 OF 8
DATA PKG: N/A
PROCEDURE: B3A6ZZ0 R/2

PLANT/UNIT: D.C. Cook #1 WELD NO: 1-SI-22-18F SYSTEM: SI

CONFIGURATION: PIPE TO VALVE

ASME CODE CLASS: B-J, B9.11

CODE EXAMINATION REQUIREMENTS: EXAMINED IN ACCORDANCE WITH ASME SEC. XI, 1989 ED., IWB-2500 REQUIREMENTS.

INTERFERING CONDITION: A SINGLE SIDED ACCESS EXAMINATION WAS PERFORMED IN ACCORDANCE WITH PROCEDURE PARAGRAPH 2.3. ACCESS WAS LIMITED DUE TO THE OD BEVEL CONFIGURATION ON THE VALVE SIDE OF THE WELD.

ESTIMATE OF TOTAL % CODE COMPLETE: 50% SKETCH ATTACHED: YES NO

PARTIAL EXAMINATION PERFORMED: YES NO

EXAMINATION ANGLE AFFECTED:
0 DEGREE WRV 0 DEGREE BASE MATERIAL N/A
45 DEGREE AXIAL 45 DEGREE CIRCUMFERENTIAL

OTHER: * 70° R.L.



ALTERNATE METHOD RECOMMENDED: YES NO

EXPLANATION: * EXAMINATION PERFORMED IN ACCORDANCE WITH PROCEDURE PARAGRAPH 5.1.8.2.

PREPARED BY: [Signature] DATE: 5.11.02
REVIEWED: [Signature] DATE: 5.20.02
[Signature] 5/28/02

1-SI-22-18F

Lower Containment, just off 29" I.D. 1-RC-2 Hot Leg (Steam Generator #12). Scaffold required. Insulated. High contact dose rate (≈ 200 to 300 mr). Done from Steam Generator manway scaffold.



INCOMPLETE EXAMINATION REPORT

REPORT NO: UIC18-UT-020
PAGE 4 OF 4
DATA PKG: N/A
PROCEDURE: B3A622B R/2

PLANT/UNIT: D.C. Cook #1 WELD NO: I-SI-23-17F SYSTEM: SI

CONFIGURATION: PIPE TO VALVE

ASME CODE CLASS: B-J, B9.11

CODE EXAMINATION REQUIREMENTS: EXAMINED IN ACCORDANCE WITH
ASME SEC. XI, 1989 ED., IWB-2500 REQUIREMENTS.

INTERFERING CONDITION: A SINGLE SIDED ACCESS EXAMINATION WAS
PERFORMED IN ACCORDANCE WITH PROCEDURE PARAGRAPH 2.3.
ACCESS WAS LIMITED DUE TO THE OD BEVEL CONFIGURATION
ON THE VALVE SIDE OF THE WELD.

ESTIMATE OF TOTAL % CODE COMPLETE: 50% SKETCH ATTACHED: YES NO

PARTIAL EXAMINATION PERFORMED: YES NO

EXAMINATION ANGLE AFFECTED:

0 DEGREE WRV 0 DEGREE BASE MATERIAL N/A

45 DEGREE AXIAL 45 DEGREE CIRCUMFERENTIAL

OTHER: * 70° R.L.

ALTERNATE METHOD RECOMMENDED: YES NO



EXPLANATION: * EXAMINATION PERFORMED IN ACCORDANCE
WITH PROCEDURE PARAGRAPH 5.1.B.2.

PREPARED BY: [Signature]
REVIEWED: [Signature]

DATE: 5.11.02
DATE: 5.20.02

1-SI-23-17F

Lower Containment, just off 29" I.D. 11-RC-3 Hot Leg (Steam Generator #13). Scaffold required. Insulated. High contact dose rate (≈ 200 to 300 mr). Done from Steam Generator manway scaffold.





UT Calibration/Examination

Site/Unit: AEP / 1
 Summary No.: 030900
 Workscope: ISI

Procedure: ISI-PDI-UT-2
 Procedure Rev.: 4
 Work Order No.: 65247776-01

Outage No.: 1
 Report No.: UT-00-046
 Page: 1 of 3

Code: ASME XI 1989 Cat./Item: B-J/B9.11 Location: CONT. L3
 Drawing No.: A-19 Description: BRANCH CONNECTION TO PIPE
 System ID: RC
 Component ID: 1-RC-5-01F Size/Length: Size: 14" Thickness/Diameter Thickness: 1.406
 Limitations: No exam upstream due to component configuration Start Time: 1304 Finish Time: 1323

Instrument Settings
 Serial No.: 105205
 Manufacturer: GEIT
 Model: USN-60 SW
 Delay: 5.8588 µsec Range: 4.0"
 M'tl Cal/Vel: 0.1220 "/µsec Pulsar: Square
 Damping: 500 Ω Reject: 0%
 Rep. Rate: Auto High Freq.: 2.0 MHz
 Filter: N/A Mode: Fullwave
 Voltage: 450v
 Ax. Gain (dB): 18.5 Circ. Gain (dB): N/A
1 Screen Div. = .40 In. of Sound Path
 Linearity Report No.: L-06-011

Search Unit
 Serial No.: 01D6NM
 Manufacturer: KBA
 Size: 0.375" Shape: ROUND
 Freq.: 1.5 MHz Style: Comp-G
 Exam Angle: 45° # of Elements: 1
 Mode: Shear
 Measured Angle: 45°
 Wedge Style: MSWQC
Search Unit Cable
 Type: RG174
 Length: 12' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	1016	10/17/2006
Inter. Cal.	1303	10/17/2006
Inter. Cal.	N/A	
Inter. Cal.	N/A	
Final Cal.	1455	10/17/2006

Couplant
 Cal. Batch: 06225
 Type: Ultragel II
 Mfg.: Sonotech
 Exam Batch: 06225
 Type: Ultragel II
 Mfg.: Sonotech

Reference Block
 Serial No.: A20250
 Type: Rompus SS

Axial Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
1.5" Notch	80%	05.4	2.16"
N/A	N/A	N/A	N/A

Circumferential Orientated Search Unit

Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A	N/A	N/A	N/A

Reference/Simulator Block

Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
18.5	FSDH	46%	4.5	1.8"

Calibration Block
 Cal. Block No.: CB-02-184
 Thickness: 0.5" - 2.0" Dia.: Flat
 Cal. Blk. Temp.: 89° Temp. Tool: 0506533
 Comp. Temp.: 82° Temp. Tool: 0506533

Scan Coverage
 Upstream Downstream Scan dB: 28.5
 CW CCW Scan dB: 28.5
 Exam Surface: OD
 Surface Condition: AS WELDED

Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: 50%* Reviewed Previous Data: Yes

Comments: *=Best effort exam per procedure due to branch connection to pipe configuration. Pulse Width (330). See report UT-06-70 for 60" report.

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Snyder, Steven C.	II	<i>[Signature]</i>	10/17/2006	Feige, Edward	<i>[Signature]</i>	10/21/06
Examiner	Level	Signature	Date	Site Review	Signature	Date
N/A	N/A			Donavin, Paul	<i>[Signature]</i>	10/21/06
Other	Level	Signature	Date	ANII Review	Signature	Date
Orihuela, Miguel	III	<i>[Signature]</i>	10/20/06	Longenberger, James A.	<i>[Signature]</i>	10-22-06





Supplement Report

Report No.: UT-06

Page: 3 of 3

Summary No.: 030900

Examiner: Snyder, Steven C.

Level: II

Reviewer: Feige, Edward J. Date: _____

Examiner: N/A

Level: N/A

Site Review: Donavin, Paul Date: _____

Other: Orihuela, Miguel MO


Level: III

ANII Review: Longenberger, James A. Date: _____

Comments: 1-RC-5-01F COVERAGE PLOT

Sketch or Photo: X:\DDEAL\U1-C21 Inspection Documentation and Photos\WesDyne Examinations\CompID 1-RC-5-01F
CompID 1RC-5-01F TC A.jpg

WO 55247776-01 SN 030900 Rpt UT-06-046\Coverage Plot



T.E.C. TRANSIT FROM 1990 DATA

INFORMATION ONLY



UT Calibration/Examination

Site/Unit: AEP / 1
 Summary No.: 030900
 Workscope: ISI

Procedure: ISI-PDI-UT-2
 Procedure Rev.: 4
 Work Order No.: 55247776-01

Outage No.: U
 Report No.: UT-06-070
 Page: 1 of 1

Code: ASME XI 1989 Cat./Item: B-J/B9.11 Location: CONT. L3

Drawing No.: A-19 Description: BRANCH CONNECTION TO PIPE

System ID: RC

Component ID: 1-RC-5-01F Size/Length: Size: 14" Thickness/Diameter: Thickness: 1.406

Limitations: No exam upstream due to component configuration Start Time: 1243 Finish Time: 1301

Instrument Settings
 Serial No.: 105206
 Manufacturer: GEIT
 Model: USN-60 SW
 Delay: 9.0141 μ sec Range: 4.0"
 M'tl Cal/Vel: 0.2293 "/μsec Pulsar: Square
 Damping: 500 Ω Reject: 0%
 Rep. Rate: Auto High Freq.: 2.0 MHz
 Filter: N/A Mode: Full Wave
 Voltage: 480v
 Ax. Gain (dB): 68.5 Circ. Gain (dB): N/A
 1 Screen Div. = .40 In. of Sound Path
 Linearity Report No.: L-06-011

Search Unit
 Serial No.: 06-483
 Manufacturer: RTD
 Size: 2(8 X 14)mm Shape: Rectangular
 Freq.: 2 Mhz Style: TRL2-Aust
 Exam Angle: 80° # of Elements: 2
 Mode: Longitudinal
 Measured Angle: 60°
 Wedge Style: Integral

Search Unit Cable
 Type: RG174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	1020	10/17/2006
Inter. Cal.	N/A	
Inter. Cal.	N/A	
Inter. Cal.	N/A	
Final Cal.	1452	10/17/2006

Couplant
 Cal. Batch: 06226
 Type: Ultragel II
 Mfg.: Sonotech
 Exam Batch: 06226
 Type: Ultragel II
 Mfg.: Sonotech

Reference Block
 Serial No.: A20260
 Type: Rompus SS

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
1.6" Notch	80%	06.3	2.5"
N/A	N/A	N/A	N/A

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A	N/A	N/A	N/A

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A	N/A	N/A	N/A	N/A

Calibration Block
 Cal. Block No.: CB-02-184
 Thickness: 0.5" - 2.0" Dia.: Flat
 Cal. Blk. Temp.: 89° Temp. Tool: 0606533
 Comp. Temp.: 82° Temp. Tool: 0606533
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: 60%* Reviewed Previous Data: Yes

Scan Coverage
 Upstream Downstream Scan dB: 65.5
 CW CCW Scan dB: N/A
 Exam Surface: OD
 Surface Condition: AS WELDED

Comments: Pulse Width (250) *=Best effort exam per procedure due to branch connection to pipe configuration. Reference 45° report UT-06-046 for photo and coverage plot.

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Snyder, Steven C.	II	<i>Steven Snyder</i>	10/17/2006	Felge, Edward J.	<i>Edward Felge</i>	10/21/06
N/A	N/A			Donavin, Paul	<i>Paul Donavin</i>	10/21/06
Orihuela, Miguel	III	<i>M.O.</i>	10/20/06	Longenberger, James A.	<i>James Longenberger</i>	10-22-06





UT Calibration/Examination

Site/Unit: AEP / 1 Procedure: ISI-PDI-UT-2 Outage No.: L
 Summary No.: 108500 Procedure Rev.: 4 Report No.: UT-06-049
 Workscope: ISI Work Order No.: 66247782-03 Page: 1 of 1

Code: ASME XI 1989 Cat./Item: B-J/B9.11 Location: CONT. L3
 Drawing No.: A-56 Description: TEE TO PIPE
 System ID: SI
 Component ID: I-SI-33-23S Size/Length: Size: 10" Thickness/Diameter: Thickness: 1.312"
 Limitations: No exam upstream due to component configuration Start Time: 1119 Finish Time: 1131

Instrument Settings
 Serial No.: 108206
 Manufacturer: GEIT
 Model: USN-80 SW
 Delay: 9.0141 μ sec Range: 4.0"
 M'fl Cal/Vel: 0.2283 "/μsec Pulsar: Square
 Damping: 800 Ω Reject: 0%
 Rep. Rate: Auto High Freq.: 2.0 MHz
 Filter: N/A Mode: Full Wave
 Voltage: 480v
 Ax. Gain (dB): 88.5 Circ. Gain (dB): N/A
 Screen Div. = .40 In. of Sound Path
 Linearity Report No.: L-06-011

Search Unit
 Serial No.: 06-483
 Manufacturer: RTD
 Size: 2(8 X 14)mm Shape: Rectangular
 Freq.: 2 Mhz Style: TRL2-Aust
 Exam Angle: 90° # of Elements: 2
 Mode: Longitudinal
 Measured Angle: 60°
 Wedge Style: Integral
 Search Unit Cable
 Type: RG174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	1047	10/14/2006
Inter. Cal.	1119	10/14/2006
Inter. Cal.	N/A	
Inter. Cal.	N/A	
Final Cal.	1869	10/14/2006

Couplant
 Cal. Batch: 06225
 Type: Ultragel II
 Mfg.: Sonotech
 Exam Batch: 06225
 Type: Ultragel II
 Mfg.: Sonotech

Reference Block
 Serial No.: A20260
 Type: Rompus SS

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
1.6" Notch	80%	08.0	2.3"
N/A	N/A	N/A	N/A

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
N/A	N/A	N/A	N/A

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
45	FSDH	80%	3.0	1.2"
N/A	N/A	N/A	N/A	N/A

Calibration Block
 Cal. Block No.: CB-02-184
 Thickness: 0.5" - 2.0" Dia.: Flat
 Cal. Blk. Temp.: 80° Temp. Tool: 0608533
 Comp. Temp.: 78° Temp. Tool: 0606633
 Upstream Downstream Scan dB: 58.6
 CW CCW Scan dB: N/A
 Exam Surface: OD
 Surface Condition: AS WELDED
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: 50% Reviewed Previous Data: Yes

INFORMATION ONLY

Comments: Pulse Width (260). ID Geometry observed below recordable levels. Scanned at reference due to excessive noise level. Ref 45° rpt UT-06-055 for Coverage Plot/Photo.

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Snyder, Steven C.	II	<i>[Signature]</i>	10/11/2006	Feige, Edward J.	<i>[Signature]</i>	10/21/06
Frana, Jeremy R.	I	<i>[Signature]</i>	10/11/2006	Donavin, Paul	<i>[Signature]</i>	10/21/06
Orihuela, Miguel	III	<i>[Signature]</i>	10/21/06	Longenberger, James A.	<i>[Signature]</i>	10-21-06





UT Calibration/Examination

Site/Unit: AEP / 1 Procedure: ISI-PDI-UT-2 Outage No.: U
 Summary No.: 108500 Procedure Rev.: 4 Report No.: UT-06-055
 Workscope: ISI Work Order No.: 55247782-03 Page: 1 of 3

Code: ASME XI 1999 Cat./Item: B-J/B9.11 Location: CONT. L3
 Drawing No.: A-58 Description: TEE TO PIPE
 System ID: SI
 Component ID: 1-SI-33-23S Size/Length: Size:10" Thickness/Diameter: Thickness:1.312
 Limitations: No exam upstream due to component configuration. Start Time: 1103 Finish Time: 1117

Instrument Settings		Search Unit		Cal. Checks	Time	Date	Axial Orientated Search Unit			
Serial No.:	<u>108205</u>	Serial No.:	<u>01D6NM</u>	Initial Cal.	<u>1043</u>	<u>10/14/2006</u>	Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
Manufacturer:	<u>GEIY</u>	Manufacturer:	<u>KBA</u>	Inter. Cal.	<u>1100</u>	<u>10/14/2006</u>	<u>1.6" Notch</u>	<u>80%</u>	<u>05.4</u>	<u>2.16"</u>
Model:	<u>USN-60 SW</u>	Size:	<u>0.375"</u> Shape: <u>ROUND</u>	Inter. Cal.	<u>N/A</u>		<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Delay:	<u>0.8688 μsec</u> Range: <u>4.0"</u>	Freq.:	<u>1.5 MHz</u> Style: <u>Comp-G</u>	Inter. Cal.	<u>N/A</u>					
M'll Cal/Vel:	<u>0.1220 "/μsec</u> Pulsar: <u>Square</u>	Exam Angle:	<u>45°</u> # of Elements: <u>1</u>	Final Cal.	<u>1655</u>	<u>10/14/2006</u>				
Damping:	<u>600 Ω</u> Reject: <u>0%</u>	Mode:	<u>Shear</u>	Couplant						
Rep. Rate:	<u>Auto High</u> Freq.:	Measured Angle:	<u>45°</u>	Cal. Batch:	<u>06225</u>					
Filter:	<u>N/A</u> Mode: <u>Fullwave</u>	Wedge Style:	<u>MSWQC</u>	Type:	<u>Ultragel II</u>					
Voltage:	<u>450v</u>			Mfg.:	<u>Sonotech</u>					
Ax. Gain (dB):	<u>18.5</u> Circ. Gain (dB): <u>N/A</u>	Search Unit Cable		Exam Batch:	<u>06225</u>					
<u>1</u> Screen Div. = <u>.4</u> In. of <u>Sound Path</u>	Type:	<u>RG174</u>		Type:	<u>Ultragel II</u>					
Linearity Report No.: <u>L-06-011</u>	Length:	<u>8'</u> No. Conn.: <u>0</u>		Mfg.:	<u>Sonotech</u>					
Calibration Block		Scan Coverage		Reference Block						
Cal. Block No.:	<u>CB-02-184</u>	Upstream <input type="checkbox"/> Downstream <input checked="" type="checkbox"/>	Scan dB: <u>28.5</u>	Serial No.:	<u>A20250</u>					
Thickness:	<u>0.5" - 2.0"</u> Dia.: <u>Flat</u>	CW <input checked="" type="checkbox"/> CCW <input checked="" type="checkbox"/>	Scan dB: <u>28.5</u>	Type:	<u>Rompus SS</u>					
Cal. Blk. Temp.:	<u>80°</u> Temp. Tool: <u>0606533</u>	Exam Surface:	<u>OD</u>	Reference/Simulator Block						
Comp. Temp.:	<u>80°</u> Temp. Tool: <u>0606533</u>	Surface Condition:	<u>AS WELDED</u>	Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path		
Recordable Indication(s):	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> (If Yes, Ref. Attached Ultrasonic Indication Report.)			<u>18.5</u>	<u>FSDH</u>	<u>45%</u>	<u>04.5</u>	<u>1.8"</u>		
Results:	Accept <input checked="" type="checkbox"/> Reject <input type="checkbox"/> Info <input type="checkbox"/>									
Percent Of Coverage Obtained > 90%:	<u>50%</u>	Reviewed Previous Data:	<u>Yes</u>	Comments: <u>Pulse Width (330). ID Geometry observed below recordable levels. 60° exam on report UT-06-049.</u>						

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Snyder, Steven C.	II	<i>[Signature]</i>	10/14/2006	Feige, Edward J.	<i>[Signature]</i>	10/21/06
Frana, Jeremy R.	I	<i>[Signature]</i>	10/14/2006	Donavin, Paul	<i>[Signature]</i>	10/21/06
Orihuela, Miguel	III	<i>[Signature]</i>	10/21/06	James A. Longue...	<i>[Signature]</i>	10-21-06

UT Calibration/Examination

ABS
11/06



Supplemental Report

Report No.: UT-06

Page: 2 of 3

Summary No.: 108500

Examiner: Snyder, Steven C. *SES*

Level: II

Reviewer: Felge, Edward J.

Date: _____

Examiner: Frana, Jeremy R.

Level: I

Site Review: Donavin, Paul

Date: _____

Other: Orihuela, Miguel *MO*

Level: III


ANII Review: Longenberger, James A.

Date: _____

Comments: 1-SI-33-23S Coverage Plot

Sketch or Photo: X:\DDEALU1-C21 Inspection Documentation and Photos\WesDyne Examinations\CompID 1-SI-33-23S
33-23S with TC D.jpg

WO 55247782-03 SN 108500 Rpt UT-06-049\Coverage plot 1-



INFORMATION ONLY

A**EXAMINATION SUMMARY****EXAMATOME ANP**

Primary No.: 025700

Data Package: NA

Exam Date: 10/16/2004

Customer: DC Cook 2

Examination Methods: PT and UT

System / Component ID: Reactor Coolant / 2-RC-22-01

Examination Procedures: 54-ISI-240-40 and 54-ISI-836-08

Component Description: Safe End to Elbow Weld

Calibration Sheets No(s): U2C15-Cal-049, U2C15-Cal-051

Examination Category: B-~~R~~^J / B5.130Examination Results: No Reportable Indications Reportable Indications

ISO / Drawing: A-18 20

 Geometric**Summary:**

A PT examination was performed on 100% of weld 2-RC-22-01 with no indications noted.

A UT examination was performed from one side of weld 2-RC-22-01 with no indications noted. See attached Scan Limitations Report for areas coverage could not be obtained.

Prepared By: JW Langdon

Date: 10-25-04

Reviewed By: RA Kellerhall

Date: 10-25-04

Customer:

Sign:

Date:

Sign:

Page 1 of 7

453/490




ULTRASONIC EXAMINATION SCAN LIMITATION REPORT

PARAMATOME ANP

Customer: DC Cook Unit 2		Component: Reactor Coolant		Summary No.: 025700	
Weld No.: 2-RC-22-01				Percent Of Exam Completed 65.0%	
Reference Point 0"				(Calculations Or Comments Below)	
1) Interfering Condition		Surface Geometry		45 degree circumferential coverage	
Distance From Centerline	0.25" US	To	0.55 US	Total area:	
Distance From Ref. Point	0"	To	20.4"	1.5" width	
2) Interfering Condition				0.25 height	
Distance From Centerline				20.4" length	
Distance From Ref. Point				1.5W x 0.25H x 20.4L = 7.65	
3) Interfering Condition				Obstructed area	
Distance From Centerline				0.3" obstructed width	
Distance From Ref. Point				0.25" obstructed height	
4) Interfering Condition				20.4" obstructed length	
Distance From Centerline				0.3W x 0.25H x 20.4L = 1.53	
Distance From Ref. Point				45 degree circumferential coverage = 80.0%	
(For All Measurements Indicate: US, DS, CW, CCW)				45 degree axial coverage = 100%	

Area of Limitation(s):



(INCLUDED THE EXTENT OF % COMPLETED OF EXAM AND REASON FOR LIMITED REPORT, AND SKETCH SHOWING AREA OF LIMITATION.)


Level III: Robert Kellerhall	Date: 10-25-04	Examiner: George Chapman	Date: 10-16-04
Answer: N/A		Date: N/A	
Customer: [Signature]		Date: 10/26/04	

457/490

A

FRAMATOME ANP

UT COVERAGE PLOT



458/490

COMPONENT: 2-RC-22-01

Ray K. C.
RE Hall 10/26/04

PAK PAGE 6 OF 7



EXAMINATION SUMMARY

AMATOME ANP

Summary No.: 034300	Data Package: NA	Exam Date: 10/20/2004
Customer: DC Cook 2	Examination Methods: PT and UT	
System / Component ID: Reactor Coolant / 2-RC-28-23	Examination Procedures: 54-ISI-240-40 and 54-ISI-836-08	
Component Description: Tee to Pipe Weld	Calibration Sheets No(s): U2C15-Cal-056, U2C15-Cal-057	
Examination Category: B-J / B9.11	Examination Results: <input checked="" type="checkbox"/> No Reportable Indications	
ISO / Drawing: A-257 <i>SPJ 12-10-04</i>	<input type="checkbox"/> Reportable Indications	
	<input type="checkbox"/> Geometric	

Summary:
 A PT and UT examination was performed on weld 2-RC-28-23 with no indications noted.

The PT exam covered 100% of the weld.

The UT exam was limited to the pipe side. See attached Scan Limitation Report for areas and percentages of coverage.

Prepared By: JW Langdon <i>JW Langdon</i>	Date: 10-25-04	Reviewed By: RA Kellerhall <i>RA Kellerhall</i>	Date: 10-25-04
Customer: <i>Roy E Hall</i>	Date: <i>10/26/04</i>	Page 1 of 7	

479/490



ULTRASONIC EXAMINATION SCAN LIMITATION REPORT

AMATOME ANP

Customer: DC Cook Unit 2

Component: Reactor Coolant

Summary No.: 034300

Weld No.: 2-RC-28-23

Reference Point 0" Weld CL

1) Interfering Condition Surface Geometry

Distance From Centerline 0.2" US To 0.6" US

Distance From Ref. Point 0.0" CW To 14.5" CW

2) Interfering Condition

Distance From Centerline To

Distance From Ref. Point To

3) Interfering Condition

Distance From Centerline To

Distance From Ref. Point To

4) Interfering Condition

Distance From Centerline To

Distance From Ref. Point To

(For All Measurements Indicate: US, DS, CW, CCW)

Percent Of Exam Completed
(Calculations Or Comments Below)

45S Circumferential coverage

Weld length 14.3"

Coverage Height = 0.15" Obstructed

Coverage Width = 0.4" Obstructed

Coverage Length = 14.5" Obstructed

$0.15H \times 0.4W \times 14.5L = 0.87$

Coverage Height = 0.15"

Coverage Width = 1.2"


Coverage Length = 14.5"

$0.15H \times 1.2W \times 14.5L = 2.61$ for Complete Coverage

$4.8/108.6 =$ percent obstructed area

66.7% Coverage Achieved

Reason Of Limitation(s):



(INCLUDED THE EXTENT OF % COMPLETED OF EXAM AND REASON FOR LIMITED REPORT, AND SKETCH SHOWING AREA OF LIMITATION.)

Level III: Robert Kellerhall

Date: 10-25-04

Examiner: George Chapman

Date: 10-20-04

Operator:

N/A

Date:

N/A

Customer:

Roger E. Neill

Date:

10/26/04


483/490

5/7

A

FRAMATOME ANP

UT COVERAGE PLOT



484/490
abh/hst

COMPONENT: 2-RC-28-23

Map A Chyn 10-20-04

Re Weld
10/26/04

Rev PAGE 6 OF 7



UT Calibration/Examination

Site/Unit: AEP / 2
 Summary No.: 089750
 Workscope: ISI

Procedure: 54-ISI-836
 Procedure Rev.: 09
 Work Order No.: 05144018

Outage No.: 6
 Report No.: UT-06-018
 Page: 1 of 5

Code: ASME XI 1989 Cat./Item: B-J/B9.11 Location: CONT. L1
 Drawing No.: A-47 Description: TEE TO PIPE
 System ID: SI
 Component ID: 2-SI-56-19 Size/Length: N/A / 34.375 Thickness/Diameter: 1.1" / 10.0"
 Limitations: Tee configuration Start Time: 2245 Finish Time: 2345

Instrument Settings
 Serial No.: 01040X
 Manufacturer: KBA
 Model: USN-68L
 Delay: 6.79 Range: 2.828
 M'tl Cal/Vel: 0.124 Pulsar: High
 Damping: 1K Reject: Off
 Rep. Rate: AutoHigh Freq.: 2.25
 Filter: Full Wave Mode: N/A
 Voltage: Fixed
 Ax. Gain (dB): 24.8 Circ. Gain (dB): N/A
1 Screen Div. = 0.20 in. of Depth
 Linearity Report No.: L-06-002

Search Unit
 Serial No.: 00HRX9
 Manufacturer: KBA
 Size: 0.375" Shape: ROUND
 Freq.: 2.25 MHZ Style: COMP-G
 Exam Angle: 45 # of Elements: 1
 Mode: Shear
 Measured Angle: 45
 Wedge Style: MSWQC
Search Unit Cable
 Type: RG174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	2200	4/12/2006
Inter. Cal.	2300	4/12/2006
Inter. Cal.	N/A	
Inter. Cal.	N/A	
Final Cal.	0030	4/13/2006

Couplant
 Cal. Batch: 04325
 Type: Ultragel II
 Mfg.: Sonotech
 Exam Batch: 04325
 Type: Ultragel II
 Mfg.: Sonotech

Reference Block
 Serial No.: N/A
 Type: N/A

Axial Orientated Search Unit				
Calibration Reflector	Signal Amplitude %	Sweep Division	Depth	
1.5"	80%	7.5	1.5"	
ID ROLL	10%	5.0	1.0"	
N/A				
			N/A	
Circumferential Orientated Search Unit				
Calibration Reflector	Signal Amplitude %	Sweep Division	Depth	
N/A				
			N/A	
Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Depth
N/A				
				N/A

Calibration Block
 Cal. Block No.: CB-02-44
 Thickness: 0.5" - 2.0" Dia.: Flat
 Cal. Blk. Temp.: 85 Temp. Tool: JC24395 / VH-9567
 Comp. Temp.: 81 Temp. Tool: JC24395 / VH-9567

Scan Coverage
 Upstream Downstream Scan dB: 41
 CW CCW Scan dB: 46
 Exam Surface: OD
 Surface Condition: GROUND

Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Comments: NGD

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Chapman, George G.	II-PDI	<i>GC</i>	4/13/2006	Nicholas Shearer, Level III	<i>NS</i>	4/14/2006
Bauman, Nathan M.	II	<i>NMB</i>	4/13/2006	Roy E. Hall	<i>REH</i>	4/18/2006
Blum, William E.	III	<i>WLB</i>	4/14/2006	ANII Review	<i>WLB</i>	4/19/06




Limitation Record

Site/Unit: AEP / 2 Procedure: 54-ISI-836 Outage No.: U2-C16
 Summary No.: 089750 Procedure Rev.: 09 Report No.: UT-06-018
 Workscope: ISI Work Order No.: 05144018 Page: 2 of 5

Description of Limitation:

One sided exam due to configuration of T to pipe. 50% coverage achieved. See supplemental report for limitation description.

Sketch of Limitation: X:\VDEAL\U2-C16 Inspection Documentation and photos\U2-C16 Framatome Pictures\2-SI-56-19a.jpg



Limitations removal requirements:

Radiation field:

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Chapman, George G	Level II-PDI	<i>GC</i>	4/13/2006	Nicholas Shearer, Level III	<i>Nicholas Shearer</i>	4/14/2006
Chuman, Nathan M.	Level II	<i>NMB</i>	4/13/2006	Site Review Roy E. Hall	<i>Roy E. Hall</i>	4/18/2006
Blum, William E.	Level III	<i>WEB</i>	4/14/2006	ANII Review	<i>William E. Blum</i>	4/14/06

Additional - Limitation <edit from Setup>



Supplemental Report

Report No.: UT-06


Page: 4 of 5

Summary No.: 089750

Sketch or Photo: X:\IDDEAL\U2-C16 Inspection Documentation and photos\U2-C16 Framatome Pictures\coveragePlots\summary# 089750.jpg


	<h2 style="margin: 0;">UT COVERAGE PLOT</h2>
---	--

TEE



PIPE

Coverage plot shows 45°, 60° shear and 60° RL angles.
Coverage Plot for Safety Injection System weld# 2-SI-56-19

Nm3


COMPONENT: Summary# 089750

PAGE ____ OF ____



Supplemental Report

Report No.: UT-06-018

Page: 5 of 5

Summary No.: 089750

Examiner:	<u>Chapman, George G</u> <i>h/k</i>	Level:	<u>II-PDI</u>	Reviewer:	<u>Nicholas Shearer, Level III</u>	Date:	<u>4/14/2006</u>
Examiner:	<u>Bauman, Nathan M.</u> <i>NMB</i>	Level:	<u>II</u>	Site Review:	<u>Roy E. Hall</u> <i>REH</i>	Date:	<u>4/18/2006</u>
Other:	<u>Blum, William E.</u> <i>WEB</i>	Level:	<u>III</u>	ANII Review:	<i>[Signature]</i>	Date:	<u>4/19/06</u>

Comments: None

Sketch or Photo: X:\DDEAL\U2-C16 Inspection Documentation and photos\U2-C16 Framatome Pictures\2-SI-56-19a.jpg





UT Calibration Examination

Site/Unit: AEP / 2
 Summary No.: 148800
 Workscope: ISI

Procedure: ISI-PDI-UT-2
 Procedure Rev.: 4
 Work Order No.: 55289182

Outage No.: 02-C17
 Report No.: UT-07-133
 Page: 1 of 3

Code: ASME XI 1989 Cat./Item: B-J/B9.11 Location: CONT. L2
 Drawing No.: A-77 Description: BRANCH CONNECTION TO PIPE
 System ID: RH
 Component ID: 2-RH-33-01 Size/Length: 1.5"/44.5" Thickness/Diameter: 1.41"/14"Sch160
 Limitations: 50% coverage due to configuration. Start Time: 1006 Finish Time: 1030

Instrument Settings
 Serial No.: 102344
 Manufacturer: KBA
 Model: USN-60
 Delay: 6.609 µsec Range: 3.00"
 MFI Cal/Vel: .1237/µsec Pulser: High
 Damping: Fixed Reject: 0%
 Rep. Rate: Fixed Freq.: Fixed
 Filter: N/A Mode: Fullwave
 Voltage: Fixed Other: N/A
 Ax. Gain (dB): 17.5 Circ. Gain (dB): 17.5
10 Screen Div. = 3.0 in. of Sound Path
 Linearity Report No.: L-07-002

Search Unit
 Serial No.: 008J9H
 Manufacturer: KBA
 Size: 0.60" Shape: ROUND
 Freq.: 1.5 MHZ Style: COMP-G
 Exam Angle: 46° # of Elements: 1
 Mode: Shear
 Measured Angle: 45°
 Wedge Style: Non-Integral
Search Unit Cable
 Type: RG174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	0905	9/28/2007
Inter. Cal.	1005	9/28/2007
Inter. Cal.		
Inter. Cal.		
Final Cal.	1130	9/28/2007

Couplant
 Cal. Batch: 07125
 Type: Ultrage II
 Mfg.: Sonotech
 Exam Batch: 07125
 Type: Ultrage II
 Mfg.: Sonotech

Reference Block
 Serial No.: 103434
 Type: Rompas

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
1.5" Notch	80%	7.1	2.13"

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
1.5" Notch	80%	7.1	2.13"

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path
17.5	FSDH	20%	3.5	1.06"

Calibration Block
 Cal. Block No.: 105255
 Thickness: 0.5" - 2.0" Dia.: 0
 Cal. Blk. Temp.: 82° Temp. Tool: 105379
 Comp. Temp.: 69° Temp. Tool: 105379
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Scan Coverage
 Upstream Downstream Scan dB: 37.5
 CW CCW Scan dB: 37.5
 Exam Surface: OD
 Surface Condition: FLAT TOPPED

Results: Accept Reject Info

Comments: Previously recorded indications observed at below recordable levels. 50% coverage due to configuration.

Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: N/A

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Cox, Stephen R.	II-PDI		9/28/2007	Feige, Edward J.		9/30/07
N/A	N/A			Donavin, Paul		10/1/07
Siever, Theodore J.	III-PDI		9-29-07	Jackson, Charles		10/1/07



Supplemental Report

Report No.: UT-07-133


Page: 2 of 3

Primary No.: 148800

Examiner: <u>Cox, Stephen R.</u> <i>src</i>	Level: <u>II-PDI</u>	Reviewer: <u>Feige, Edward J.</u> <i>EF</i>	Date: <u>9/30/07</u>
Examiner: <u>N/A</u>	Level: <u>N/A</u>	Site Review: <u>Donavin, Paul</u> <i>PRD</i>	Date: <u>10/1/07</u>
Other: <u>Siever, Theodore J.</u> <i>TS</i>	Level: <u>III-PDI</u>	ANII Review: <u>Jackson, Charles</u> <i>CJ</i>	Date: <u>10/1/07</u>

Comments: **Component # 2-RH-33-01**

Sketch or Photo: C:\Documents and Settings\S206165\My Documents\My Scans\2007-09 (Sep)\2-RH-33-01 Dwg..jpg





Supplemental Report

Report No.: UT-07-133

Page: 3 of 3

Summary No.: 148800

Examiner: <u>Cox, Stephen R. <i>SR</i></u>	Level: <u>II-PDI</u>	Reviewer: <u>Feige, Edward J. <i>EF</i></u>	Date: <u>9/30/07</u>
Examiner: <u>N/A</u>	Level: <u>N/A</u>	Site Review: <u>Donavin, Paul <i>PRD</i></u>	Date: <u>10/1/07</u>
Other: <u>Siever, Theodore J. <i>TS</i></u>	Level: <u>III-PDI</u>	ANII Review: <u>Jackson, Charles <i>CM</i></u>	Date: <u>10/1/07</u>

Comments: **Component # 2-RH-33-01**

Sketch or Photo: C:\Documents and Settings\S206165\My Documents\My Scans\2007-09 (Sep)\2-RH-33-01 Photo.jpg



2-RH-33-01

A**EXAMINATION SUMMARY****AMATOME ANP**

Exam No.: 015800

Data Package: NA

Exam Date: 10/21/2004

Customer: DC Cook 2

Examination Methods: UT and PT

System / Component ID: Reactor Coolant / 2-RC-17-08N

Examination Procedures: 54-ISI-836-08, 54-ISI-240-40

Component Description: Branch Connection to Pipe

Calibration Sheets No(s): U2C15-Cal-029

Examination Category: B-J

Examination Results: No Reportable Indications Reportable Indications

ISO / Drawing: A-9

 Geometric**Summary:**

A UT and PT examination was performed on weld 2-RC-17-08N with no indications noted. Component geometry prevented scanning on the downstream side in the axial direction. The weld geometry prevented performing circumferential scanning on the weld.

Prepared By: JW Langdon

Date: 10-22-04

Reviewed By: RA Kellerhall

Date: 10/24/04

*JW Langdon*Sign: *RA Kellerhall*Customer: *Rig E Hole*Date: *10/25/04*Sign: *Rig E Hole*

Page 1 of 7

423/490



ULTRASONIC EXAMINATION SCAN LIMITATION REPORT

AMATOME ANP

Customer: DC Cook Unit 2		Component: Branch Connection Weld	Summary No.: 015800
Weld No.: 2-RC-17-08N		Percent Of Exam Completed (Calculations Or Comments Below) Axial, Upstream – 100% Axial, Downstream – 0% Circumferential, Clockwise – 18% Circumferential, Counter Clockwise – 18% Total Coverage – 34%	
Reference Point: Weld Toe @ Main Loop			
1) Interfering Condition			
Distance From Centerline	To		
Distance From Ref. Point	To		
2) Interfering Condition			
Distance From Centerline	To		
Distance From Ref. Point	To		
3) Interfering Condition			
Distance From Centerline	To		
Distance From Ref. Point	To		
(For All Measurements Indicate: US, DS, CW, CCW)			

Sketch Of Limitation(s):

See attached Coverage Plot. Circumferential scans were limited to the 1/4" of base material on the branch connection side of the weld. Weld configuration prevented scanning on or across the weld.

(INCLUDED THE EXTENT OF % COMPLETED OF EXAM AND REASON FOR LIMITED REPORT, AND SKETCH SHOWING AREA OF LIMITATION.)

Level III: NA	Date:	Examiner: RA Kellerhall	Date: 10-21-04
Inspector: Edward P. Mazyck	Date: 10-23-04	Signature: <i>RA Kellerhall</i>	Date:
Customer: <i>Rog E No. 10</i>	Date:	Date: 10/25/04	


4/E

2-RC-17-08N

BRANCH
CONNECTION

DC COOKS UNIT 2
SUMMARY # 015800
Rechecked 10/21/84

Revised
10/25/84



ATTACHMENT 6

RELIEF REQUEST ISIR-38

EXAMINATION CATEGORY C-A
PRESSURE RETAINING WELDS IN PRESSURE VESSELS

RELIEF REQUEST ISIR-38

Relief Requested
In Accordance with 10 CFR 50.55a(g)(5)(iii) -
Inservice Inspection Impracticality

1. ASME Code Components Affected

ASME Code Class: Code Class 2
Examination Category: C-A, Pressure Retaining Welds in Pressure Vessels
Item Numbers: C1.10, Shell Circumferential Welds
C1.20, Head Circumferential Welds
C1.30, Tubesheet to Shell Weld

Component Identification: Listed in Table 1

2. Applicable Code Edition and Addenda

ASME Section XI, 1989 Edition, No addenda

3. Applicable Code Requirement

ASME Section XI, 1989 Edition, Examination Category C-A requires volumetric examination of 100 percent of the weld volume as defined in Table IWC-2500-1 and shown in Figures IWC-2500-1 or IWC-2500-2 as applicable. The alternative requirements of ASME Section XI, Code Case N-460, approved for use in Regulatory Guide 1.147, Revision 15, allows credit for essentially 100 percent coverage of the welds provided greater than 90 percent of the required volume has been examined.

4. Impracticality of Compliance

Pursuant to 10 CFR 50.55a(g)(5)(iii), relief is requested from the essentially 100 percent volumetric examination coverage requirement for the subject weld due to the geometric configuration and permanent obstructions which limit the volumetric examination coverage of the subject welds.

These noted obstructions prevent achieving the essentially 100 percent volume examination coverage required by code.

The limitations and the actual examination coverage attained for each weld for which relief is requested are noted in Table 1.

5. Burden Caused by Compliance

To increase examination coverage on the subject welds requires removal of the permanently welded pads, supports, electrical supports, adjacent piping and nozzles or replacement of the heat exchanger with a design that would allow for complete examination coverage of the subject weld. This option to meet the 100 percent code examination requirement is considered impractical due to the cost, increased radiation exposure and impact to plant equipment.

6. Proposed Alternative and Basis for Use

The subject welds received a volumetric examination utilizing the best available techniques on the accessible portions of welds to the extent practical. Additionally, a visual (VT-2) examination is performed during each inspection period during the system leakage tests as required by Section XI, Table IWC-2500-1, Category C-H.

Based upon the examination volumes that were attained with acceptable results along with the visual (VT-2) examination performed each inspection period, it is reasonable to conclude that service induced degradation would be detected. Therefore, these proposed alternatives provide an acceptable level of quality and safety by providing reasonable assurance of structural integrity of the subject welds.

7. Period for Which Relief is Requested

The relief is requested for the Third 10-year inspection interval for Donald C. Cook Nuclear Plant Units 1 and 2, which began on July 1, 1996, and ended April 9, 2010, at the conclusion of the Unit 1 Cycle 23 Refueling Outage. Significant long-term outages (greater than six months) occurred multiple times during the interval and the interval was extended as allowed by IWA-2430(e) and by IWA-2430(d) to accommodate interval planning and scheduling.

Table 1

Component ID	Weld Description	Item Number	Ultrasonic Examination Coverage Attained (%)	Remarks
W-CTSHEX-2	Shell to Flange	C1.10	48.1	The completed examination was limited to 48.1% coverage due to the configuration. The examination was single sided due to the proximity of the flange and its associated bolting. Exam limitation on the accessible side was due to the inlet and outlet nozzles restricting access for an 11" area of the weld. No relevant indications detected.
2-BIT-A	Shell to Lower Head	C1.20	80.5	The completed examination was limited to 80.5% coverage due to the configuration. The examination limitation was due to four leg supports located along the weld from 0 degrees at 18"-26", 62"-70", 99"-107", and 142"-150". No relevant indications detected.
STM-24-04	Tube Sheet to Stub Barrel	C1.30	85.0	The completed examination was limited to 85% coverage due to the configuration. Examination coverage was limited due to the proximity of welded pads, nozzles, adjacent piping, hand hole openings, permanent support brackets and permanent electrical conduits. No relevant indications detected.

RELIEF REQUEST ISIR-38

EXAMINATION CATEGORY C-A
PRESSURE RETAINING WELDS IN PRESSURE VESSELS

SUPPORTING DOCUMENTATION



UT Calibration/Examination

Site/Unit: AEP / 2
 Summary No.: 300680
 Workscope: ISI

Procedure: ISI-PDI-UT-2
 Procedure Rev.: 4
 Work Order No.: 55289193

Outage No.: 00017
 Report No.: UT-07-036
 Page: 1 of 1

Code: ASME XI 1989 Cat./Item: C-A/C1.10 Location: W CTS HXRM
 Drawing No.: B-8 Description: SHELL TO FLANGE

System ID: CTSHEX
 Component ID: W-CTSHEX-2 Size/Length: 2.0"/192.6" Thickness/Diameter: 0.5"/61"
 Limitations: Single sided exam due to flange and bolting configuration. Start Time: 1215 Finish Time: 1245

Instrument Settings
 Serial No.: 101304
 Manufacturer: Staveley
 Model: SONIC 136
 Delay: 1.09 µsec Range: 1.50"
 MUI Cal/Vel: 0.223/µsec Pulsar: 126ns
 Damping: 500 Ω Reject: Off
 Rep. Rate: 4 KHz Freq.: 5 Mhz
 Filter: 1 Mode: Dual
 Voltage: Fixed Other: N/A
 Ax. Gain (dB): 51.4 Clrc. Gain (dB): N/A
10 Screen Div. = 1.50 in. of Depth
 Linearity Report No.: L-07-001

Search Unit
 Serial No.: 574629679
 Manufacturer: KBA
 Size: 3.5 X 10mm Shape: ROUND
 Freq.: 4.0 Mhz Style: MSEB4E
 Exam Angle: 0° # of Elements: 2
 Mode: LONGITUDINAL
 Measured Angle: 0°
 Wedge Style: Integral
 Search Unit Cable
 Type: RG174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	1130	8/28/2007
Inter. Cal.	1216	8/28/2007
Inter. Cal.		
Inter. Cal.		
Final Cal.	1615	8/28/2007

Couplant
 Cal. Batch: 05226
 Type: Ultrage II
 Mfg.: Sonotech
 Exam Batch: 05226
 Type: Ultrage II
 Mfg.: Sonotech

Reference Block
 Serial No.: 106266
 Type: Alt. Block

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Depth
ALT .50"	80%	3.3	0.5"
ALT 1.0"	60%	6.6	1.0"
ALT 1.5"	40%	9.9	1.5"

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Depth
N/A	N/A	N/A	N/A

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Depth
51.4	0.50"	80%	3.3	0.5"

Calibration Block
 Cal. Block No.: 105266
 Thickness: 0.5" - 2.0" Dia.: 0
 Cal. Blk. Temp.: 75 Temp. Tool: 105379
 Comp. Temp.: 88 Temp. Tool: 105379
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: N/A Reviewed Previous Data: Yes

Scan Coverage
 Upstream Downstream Scan dB: 57.4
 CW CCW Scan dB: N/A
 Exam Surface: OD (BM & Weld)
 Surface Condition: AS WELDED

Comments: NRI. Single sided, limited exam due to flange and bolting configuration. Limited exam referenced on UT-07-036. ISI-UT-350 used to obtain T&C's and perform lamination scan.

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Cox, Stephen R.	II-PDI		8/28/2007	Feige, Edward J.		9/26/07
Examiner	Level	Signature	Date	Site Review	Signature	Date
N/A	N/A			Donavin, Paul		9/26/07
Other	Level	Signature	Date	ANII Review	Signature	Date
Siever, Theodore J.	III-PDI		9-23-07	Jackson, Charles		9/28/07



Supplemental Report

Report No.: UT-07-036

Page: 4 of 5

Summary No.: 300680

Examiner: Cox, Stephen R. *SKC* Level: II-PDI Reviewer: Feige, Edward J. *EF* Date: 9/26/07
 Examiner: N/A Level: N/A Site Review: Donavin, Paul *PD* Date: 9/26/07
 Other: Siever, Theodore J. *TS* Level: III-PDI ANII Review: Charles Jackson *CJ* Date: 9/28/07

Comments: Inlet and outlet nozzles restricted access for 11" and one sided exam.

Sketch or Photo: C:\Documents and Settings\S206165\My Documents\My Scans\2007-09 (Sep)\W-CTSHEX-2 Coverage 1.jpg

Determination of Percent Coverage for UT Examinations

Component ID: W-CTSHEX-2

0 deg Planar

	<u>Examine Length</u> (Inches)	<u>Weld Length</u> (Inches)			
LKUP Scan 1	<u>0</u>	<u>192.5</u>	X 100 =	<u>0</u>	% total for Scan 1
LKDN Scan 2	<u>181.5</u>	<u>192.5</u>	X 100 =	<u>94.3</u>	% total for Scan 2

Add totals of percentages and divide by # scans = $\frac{47.15}{2} = 23.575$ % total for 0 deg

45 deg

LKUP Scan 1	<u>0</u>	<u>192.5</u>	X 100 =	<u>0</u>	% total for Scan 1
LKDN Scan 2	<u>181.5</u>	<u>192.5</u>	X 100 =	<u>94.3</u>	% total for Scan 2
CW Scan 3	<u>96.25</u>	<u>192.5</u>	X 100 =	<u>50.0</u>	% total for Scan 3
CCW Scan 4	<u>96.25</u>	<u>192.5</u>	X 100 =	<u>50.0</u>	% total for Scan 4

Add totals of percentages and divide by # scans = $\frac{194.3}{4} = 48.575$ % total for 45 deg

Other deg 60RL

LKUP Scan 1	<u>0</u>	<u>192.5</u>	X 100 =	<u>0</u>	% total for Scan 1
LKDN Scan 2	<u>181.5</u>	<u>192.5</u>	X 100 =	<u>94.3</u>	% total for Scan 2
CW Scan 3	<u>96.25</u>	<u>192.5</u>	X 100 =	<u>50.0</u>	% total for Scan 3
CCW Scan 4	<u>96.25</u>	<u>192.5</u>	X 100 =	<u>50.0</u>	% total for Scan 4

Add totals of percentages and divide by # scans = $\frac{194.3}{4} = 48.575$ % total for 60RL deg

Percent complete coverage

Add totals for each angle and divide by # of angles to determine:

48.10 % Total for complete exam



Supplemental Report

Report No.: UT-07-036

Page: 3 of 5

Primary No.: 300680


Examiner: Cox, Stephen R. *SRL* Level: II-PDI Reviewer: Feige, Edward J. *EJF* Date: 9/26/07

Examiner: N/A Level: N/A Site Review: Donavin, Paul *PRD* Date: 9/26/07

Other: Siever, Theodore J. *TJS* Level: III-PDI ANII Review: Jackson, Charles *CJK* Date: 9/29/07

Comments: W-CTSHEx-2

Sketch or Photo: C:\Documents and Settings\IS206165\My Documents\My Scans\2007-09 (Sep)\W-CTSHEx-2 Dwg 1.jpg





UT Calibration Examination

Site/Unit: AEP / 2
 Summary No.: 300680
 Workscope: ISI

Procedure: ISI-PDI-UT-2
 Procedure Rev.: 4
 Work Order No.: 55289193

Outage No.: 02-C17
 Report No.: UT-07-037
 Page: 1 of 1

Code: ASME XI 1989 Cat./Item: C-A/C1.10 Location: W CTS HXRM
 Drawing No.: B-8 Description: SHELL TO FLANGE
 System ID: CTSHEX
 Component ID: W-CTSHEX-2 Size/Length: 2.0"/192.6" Thickness/Diameter: 0.5"/61"
 Limitations: Single sided exam due to flange and bolting configuration. Start Time: 1330 Finish Time: 1415

Instrument Settings
 Serial No.: 101304
 Manufacturer: Staveley
 Model: SONIC 138
 Delay: 1.02 µsec Range: 2.5"
 MII Cal/Vel: 0.225/µsec Pulser: 250ns
 Damping: 500 Ω Reject: Off
 Rep. Rate: 4 KHz Freq.: 2.25 Mhz
 Filter: 1 Mode: Dual
 Voltage: Fixed Other: N/A
 Ax. Gain (dB): 53.0 Circ. Gain (dB): 53.0
10 Screen Div. = 2.5 in. of Sound Path
 Linearity Report No.: L-07-001

Search Unit
 Serial No.: F1013
 Manufacturer: Megasonics
 Size: 0.38"x0.76" Shape: Rectangular
 Freq.: 2.0 Mhz Style: CGD-60L
 Exam Angle: 60° # of Elements: Dual
 Mode: Longitudinal
 Measured Angle: 60°
 Wedge Style: Integral
Search Unit Cable
 Type: RG174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	1145	8/28/2007
Inter. Cal.	1330	8/28/2007
Inter. Cal.		
Inter. Cal.		
Final Cal.	1620	8/28/2007

Couplant
 Cal. Batch: 05225
 Type: Ultragel II
 Mfg.: Sonotech
 Exam Batch: 05225
 Type: Ultragel II
 Mfg.: Sonotech

Reference Block
 Serial No.: 103772
 Type: Rompas

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
ALT 1.0"	80%	8.0	2.00"
Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
ALT 1.0"	80%	8.0	2.00"
Reference/Simulator Block			
Gain dB	Reflector	Signal Amplitude %	Sweep Division
53.0	FSDH	60%	6.0

Calibration Block
 Cal. Block No.: 105266
 Thickness: 0.5" - 2.0" Dia.: 0
 Cal. Blk. Temp.: 76° Temp. Tool: 106379
 Comp. Temp.: 88° Temp. Tool: 106379
 Exam Surface: OD
 Surface Condition: AS WELDED

Scan Coverage
 Upstream Downstream Scan dB: 59
 CW CCW Scan dB: 59
 Exam Surface: OD
 Surface Condition: AS WELDED

Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Comments: Single sided, limited exam due to flange and bolting configuration. Limited exam referenced on UT-07-036. No recordable indications.

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Cox, Stephen R.	II-PDI		8/29/2007	Feige, Edward J.		9/26/07
Examiner	Level	Signature	Date	Site Review	Signature	Date
N/A	N/A			Donavin, Paul		9/26/07
Other	Level	Signature	Date	ANII Review	Signature	Date
Siever, Theodore J.	III-PDI		9-23-07	Charles Jackson		9/29/07



UT Calibration Examination

Site/Unit: AEP / 2
 Summary No.: 300840
 Workscope: ISI

Procedure: ISI-UT-208
 Procedure Rev.: 0
 Work Order No.: 55289186

Outage No.: U2-C17
 Report No.: UT-07-003
 Page: 1 of 3

Code: ASME XI 1989 Cat./Item: G-A/C1.20 Location: BIT RM
 Drawing No.: B-11 Description: SHELL TO LOWER HEAD
 System ID: BIT
 Component ID: 2-BIT-A Size/Length: 2"/184" Thickness/Diameter: 2.5"/52"
 Limitations: Obstruction due to 4 support legs equally spaced. Start Time: 1150 Finish Time: 1215

Instrument Settings
 Serial No.: 102344
 Manufacturer: KBA
 Model: USN-50
 Delay: 11.04 μsec Range: 5.3"
 M/TI Cal/Vel: .1320/μsec Pulsar: High
 Damping: Fixed Reject: 0%
 Rep. Rate: Fixed Freq.: Fixed
 Filter: N/A Mode: Full Wave
 Voltage: Fixed N/A Other: N/A
 Ax. Gain (dB): 33 Circ. Gain (dB): 33
10 Screen Div. = 3.76" in. of Depth
 Linearity Report No.: L-07-002

Search Unit
 Serial No.: 40003
 Manufacturer: PANAMETRICS
 Size: 0.5" Shape: ROUND
 Freq.: 2.25 MHZ Style: Gamma
 Exam Angle: 45° # of Elements: 1
 Mode: Shear
 Measured Angle: 45°
 Wedge Style: Non-Integral

Search Unit Cable
 Type: RG174
 Length: 12' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	1050	8/29/2007
Inter. Cal.	1150	8/29/2007
Inter. Cal.		
Inter. Cal.		
Final Cal.	1615	8/29/2007

Couplant
 Cal. Batch: 05225
 Type: Ultrage II
 Mfg.: Sonotech
 Exam Batch: 05225
 Type: Ultrage II
 Mfg.: Sonotech

Reference Block
 Serial No.: 103768
 Type: Rompus

Axial Orientated Search Unit				
Calibration Reflector	Signal Amplitude %	Sweep Division	Depth	
1/4 SDH	80%	2.0	0.75"	
2/4 SDH	80%	4.0	1.50"	
3/4 SDH	40%	6.0	2.25"	
5/4 Hole	4%	10.0	3.75"	
ID Notch	10%	8.0	3.00"	
Circumferential Orientated Search Unit				
Calibration Reflector	Signal Amplitude %	Sweep Division	Depth	
1/4 SDH	80%	2.0	0.75"	
2/4 SDH	80%	4.0	1.50"	
3/4 SDH	40%	6.0	2.25"	
ID Notch	10%	8.0	3.00"	
Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Depth
N/A	N/A	N/A	N/A	N/A

Calibration Block
 Cal. Block No.: PL-3.0-CSCL-4-DCC
 Thickness: 3" Dia.: 0
 Cal. Blk. Temp.: 88° Temp. Tool: 105379
 Comp. Temp.: 103° Temp. Tool: 105379
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Comments: Limited exam. No recordable indications. Zero: 6.542

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Cox, Stephen R.	II-PDI		8/29/2007	Feige, Edward J.		9/24/07
Wright, Gary D.	I		8/29/2007	Donavin, Paul		9/24/07
Siever, Theodore J.	III-PDI		9-23-07	Charles Jackson		9/25/07



Supplemental Report

Report No.: UT-07-003


Page: 2 of 3

Summary No.: 300840

Examiner: <u>Cox, Stephen R.</u> <i>SCR</i>	Level: <u>II-PDI</u>	Reviewer: <u>Feige, Edward J.</u> <i>EFJ</i>	Date: <u>9/25/07</u>
Examiner: <u>Wright, Gary D.</u> <i>GDW</i>	Level: <u>I</u>	Site Review: <u>Donavin, Paul</u> <i>PD</i>	Date: <u>9/25/07</u>
Other: <u>Siever, Theodore J.</u> <i>TJS</i>	Level: <u>III-PDI</u>	ANII Review: <u>Charles Jackson</u> <i>CJ</i>	Date: <u>9/25/07</u>

Comments:

Sketch or Photo: C:\Documents and Settings\S206165\My Documents\My Scans\2007-09 (Sep)\2-BIT-A.jpg





Supplemental Report

Report No.: UT-07-003

Page: 3 of 3

Summary No.: 300840

Examiner: Cox, Stephen R. *SKC* Level: II-PDI Reviewer: Feige, Edward J. *EJF* Date: 9/25/07
 Examiner: Wright, Gary D. *GDW* Level: I Site Review: Donavin, Paul *PLD* Date: 9/25/07
 Other: Siever, Theodore J. *TS* Level: III-PDI ANII Review: Charles Jackson *CJ* Date: 9/16/07

Comments: 4 Leg Supports located from 0 degree @ 18"-26", 62"-70", 99"-107", 142"-150"
 8" X 4 legs = 32", 164" - 32" = 132"
 No scan looking down from Shell. No Circ scan on Shell side.
 Weld Length 164", Weld Width 2", Weld Thickness 2.5"

Sketch or Photo: C:\Documents and Settings\S206165\My Documents\My Scans\2007-09 (Sep)\2-BIT-A Coverage.jpg

Determination of Percent Coverage for UT Examinations

Component ID: 2-BIT-A

0 deg Planar

	<u>Examine Length</u> (Inches)	<u>Weld Length</u> (Inches)				
Scan 1	<u>132</u>	<u>164</u>	X	<u>100</u>	=	<u>80.5</u> % total for Scan 1
Scan 2	<u>132</u>	<u>164</u>	X	<u>100</u>	=	<u>80.5</u> % total for Scan 2

Add totals of percentages and divide by # scans = 80.5 % total for 0 deg

45 deg

Scan 1	<u>132</u>	<u>164</u>	X	<u>100</u>	=	<u>80.5</u> % total for Scan 1
Scan 2	<u>132</u>	<u>164</u>	X	<u>100</u>	=	<u>80.5</u> % total for Scan 2
Scan 3	<u>132</u>	<u>164</u>	X	<u>100</u>	=	<u>80.5</u> % total for Scan 3
Scan 4	<u>132</u>	<u>164</u>	X	<u>100</u>	=	<u>80.5</u> % total for Scan 4

Add totals of percentages and divide by # scans = 80.5 % total for 45 deg

Other deg 60

Scan 1	<u>132</u>	<u>164</u>	X	<u>100</u>	=	<u>80.5</u> % total for Scan 1
Scan 2	<u>132</u>	<u>164</u>	X	<u>100</u>	=	<u>80.5</u> % total for Scan 2
Scan 3	<u>132</u>	<u>164</u>	X	<u>100</u>	=	<u>80.5</u> % total for Scan 3
Scan 4	<u>132</u>	<u>164</u>	X	<u>100</u>	=	<u>80.5</u> % total for Scan 4

Add totals of percentages and divide by # scans = 80.5 % total for 60 deg

Percent complete coverage

Add totals for each angle and divide by # of angles to determine:

80.5 % Total for complete exam

**D. C. COOK UNIT2
CYCLE 14
COVERAGE REPORT**

Weld No.	Exam Type	Exam No.	X"		Y"		Square Inches Scanned Per Exam	Total Square Inches Scanned	Square Inches Required	Percent	Total Coverage	Remarks									
			Start	Stop	Start	Stop															
STM-24-04 Tube Sheet -to- Stub Barrel	Parallel (Axial scan)	5A-UP	405.00	427.30	464.05	477.65	303						Limited exam due to proximity of manway nozzle, welded pads and adjacent piping.								
			0.00	18.70	464.05	477.65	254														
		5A-DN	405.00	464.66	472.70	486.34	814														
			0.00	18.70	472.70	486.34	255														
		5B-UP	65.00	120.86	466.78	477.66	608														
			5B-DN	65.00	67.28	472.70	479.98							17							
				67.28	120.86	472.70	483.58							583							
		5C1-UP	139.48	147.08	466.28	477.66	86														
		5C2-UP	147.08	155.26	466.78	475.18	69														
		5C3-UP	155.26	172.45	466.78	474.62	135														
		5C4-UP	174.45	198.28	466.78	477.66	259														
		5C-DN	139.48	148.98	472.70	483.58	103														
			148.98	164.18	472.70	474.78	32														
			164.18	173.30	472.70	477.62	45														
			173.30	198.38	472.70	483.58	273														
		5D1-UP	198.38	224.98	466.78	477.46	284														
		5D2-UP	229.52	261.44	466.78	477.66	347														
		5D1-DN	198.38	227.70	472.70	483.58	319														
		5D2-DN	232.88	259.86	473.30	483.38	272														
		5E-UP	279.50	339.92	466.78	477.70	660														
		5E1-DN	279.00	319.02	319.02	472.70	484														
		5E2-DN	319.02	340.20	472.70	483.58	484														
		5F-UP	339.92	365.46	466.78	477.66	278														
		5F-DN	339.92	365.16	472.70	483.50	273														
														7235	9341	77%					
			Transverse (Circ scan)	6A-CW	405.00	427.30	472.60							477.92	59						
					0.00	45.00	472.60							477.92	120						
				6A-CCW	405.00	427.30	472.60							477.92	59						
0.00	45.00				472.60	477.92	120														
6B-CW	65.00			120.08	472.60	478.29	157														
6B-CCW	65.00			120.08	472.60	478.29	157														
6C-CW	139.48			198.04	472.60	478.29	167														
6C-CCW	139.48			198.04	472.60	478.29	167														
6D1-CW	198.04			224.90	472.60	478.29	76														
6D2-CW	231.56			266.84	472.60	478.29	100														
6D1-CCW	198.04			224.90	472.60	478.29	76														
6D2-CCW	231.56			278.30	472.60	478.29	702														
6E-CW	279.75			340.15	472.60	478.29	172														
6E-CCW	279.75			340.15	472.60	478.29	172														
6F-CW	340.15			369.16	472.60	478.29	83														
6F-CCW	340.15			368.84	472.60	478.29	82														
								2468	2692	92%											

X is the dimension in the circumferential direction measured in inches from vessel 0 degrees.
Y is the dimension in elevation measured in inches from vessel 0°.

Feedwater
Nozzle

Weld 05

Manufacturers
adding plate

Weld 04

Manufacturers
adding plate

Weld 01

Areas of
limitations

D.C.Cook Unit 2 - Generator 24

Weld 2-GEN-24-01, 04, & 05

May 2003

coverage gen24.dwg

ATTACHMENT 7

RELIEF REQUEST ISIR-39

EXAMINATION CATEGORY C-B
PRESSURE RETAINING NOZZLE WELDS IN VESSELS

RELIEF REQUEST ISIR-39Relief Request In Accordance with 10 CFR 50.55a(g)(5)(iii)
Inservice Inspection Impracticality1. ASME Code Components Affected

ASME Code Class: Code Class 2

Examination Category: C-B, Pressure Retaining Nozzle Welds in Vessels

Item Numbers: C2.21, Nozzles Without Reinforcing Plate in Vessels > ½ inch
Nominal Thickness, Nozzle to Shell (or Head) Weld

Component Identification: Listed in Table 1

2. Applicable Code Edition and Addenda

ASME Section XI, 1989 Edition, No addenda

3. Applicable Code Requirement

ASME Section XI, 1989 Edition, Examination Category C-B requires volumetric examination of 100 percent of the weld volume as defined in Table IWC-2500-1 and shown in Figures IWC-2500-4(a) or IWC-2500-4(b) as applicable. The alternative requirements of ASME Section XI, Code Case N-460, approved for use in Regulatory Guide 1.147, Revision 15, allows credit for essentially 100 percent coverage of the welds provided greater than 90 percent of the required volume has been examined.

4. Impracticality of Compliance

Pursuant to 10 CFR 50.55a(g)(5)(iii), relief is requested from the essentially 100 percent volumetric examination coverage requirement for the subject welds due to the geometric configuration and permanent obstructions which limits the volumetric examination coverage of the subject welds.

Due to the component geometry, coverage was limited due to tapers, bevels, weld contours, and joint configurations.

These noted obstructions prevent achieving the essentially 100 percent volume examination coverage required by code.

The limitations and the actual examination coverage attained for each weld for which relief is requested are noted in Table 1.

5. Burden Caused by Compliance

To increase examination coverage on the subject welds requires removal of significant portions of insulation and its supporting elements and redesign of the blend radius of the nozzle to shell weld with a design that would allow for complete examination coverage of the subject weld. This option to meet the 100 percent code examination requirement is considered impractical due to the cost, increased radiation exposure and impact to plant equipment.

6. Proposed Alternative and Basis for Use

The subject welds received a volumetric examination utilizing the best available techniques on the accessible portions of welds to the extent practical. Additionally, a surface examination without any limitations was performed along with a visual (VT-2) examination that is performed during each inspection period during the system leakage tests as required by Section XI, Table IWC-2500-1, Category C-H.

Based upon the examination volumes that were attained along with acceptable results and the acceptable surface examination that was performed and the visual (VT-2) examination performed each inspection period, it is reasonable to conclude that service induced degradation would be detected. Therefore, these proposed alternatives provide an acceptable level of quality and safety by providing reasonable assurance of structural integrity of the subject welds.

7. Period for Which Relief is Requested

The relief is requested for the Third 10-year inspection interval for Donald C. Cook Nuclear Plant Units 1 and 2, which began on July 1, 1996, and ended April 9, 2010, at the conclusion of the Unit 1 Cycle 23 Refueling Outage. Significant long-term outages (greater than six months) occurred multiple times during the interval and the interval was extended as allowed by IWA-2430(e) and by IWA-2430(d) to accommodate interval planning and scheduling.

Table 1

Component ID	Weld Description	Item Number	Ultrasonic Examination Coverage Attained (%)	Remarks
STM-14-FWN	Nozzle to Shell	C2.21	46.5	The completed examination was limited to 46.5% coverage due to the configuration. The coverage limitation was due to the proximity of insulation and a metal strap at top-dead-center and at bottom-dead-center due to the shell weld. No relevant indications detected.

RELIEF REQUEST ISIR-39

EXAMINATION CATEGORY C-B
PRESSURE RETAINING NOZZLE WELDS IN VESSELS

SUPPORTING DOCUMENTATION



UT Calibration Examination

Site/Unit: DC Cook / 1
 Summary No.: 300400
 Workscope: ISI

Procedure: 54-ISI-130
 Procedure Rev.: 38
 Work Order No.: 04145023-12

Outage No.: U1-C20
 Report No.: UT-05-049
 Page: 1 of 7

Code: ASME XI 1989 Cat./Item: C-B/C2.21 Location: CONT. L4
 Drawing No.: B-4 Description: NOZZLE TO SHELL
 System ID: 14
 Component ID: STM-14-FWN Size/Length: 106.0" Thickness/Diameter: 3.7"
 Limitations: INSULATION, METAL STRAPS, & SHELL CONFIGURATION Start Time: 10:00 Finish Time: 10:40

Instrument Settings
 Serial No.: VH-9075
 Manufacturer: KRAUTKRAMER
 Model: USN-58L
 Delay: 1.1181" Range: 5.0"
 M'tf Cal/Vel: 0.2310 in/uS Pulsar: N/A
 Damping: 1 KHZ Reject: 0
 Rep. Rate: AUTO HIGH Freq.: 2.25 MHZ
 Filter: N/A Mode: SINGLE
 Voltage: HIGH
 Ax. Gain (dB): 24.5 Circ. Gain (dB): N/A
1 Screen Div. = 0.4 in. of Sound Path
 Linearity Report No.: L-05-006

Search Unit
 Serial No.: 014LWR/ DB#38029
 Manufacturer: KBA
 Size: 1.0" Shape: ROUND
 Freq.: 2.25 Mhz Style: Gamma
 Exam Angle: 0 # of Elements: 1
 Mode: LONGITUDINAL
 Measured Angle: N/A
 Wedge Style: N/A
Search Unit Cable
 Type: RG174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	08:45	4/13/2005
Inter. Cal.		
Inter. Cal.		
Inter. Cal.		
Final Cal.	13:40	4/13/2005

Couplant
 Cal. Batch: 04325
 Type: Ultrage II
 Mfg.: Sonotech
 Exam Batch: 04325
 Type: Ultrage II
 Mfg.: Sonotech

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path
1/4 T	59%	1.4	0.690"
1/2 T	85%	2.9	1.435"
3/4 T	73%	4.4	2.18"

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Sound Path

Calibration Block
 Cal. Block No.: PL-3.0-CS-22-DCC
 Thickness: 3.0" Dia.: FLAT
 Cal. Blk. Temp.: 86 F Temp. Tool: VH-8556
 Comp. Temp.: 87 F Temp. Tool: VH-8556
 Upstream Downstream Scan dB: 38.5
 CW CCW Scan dB: N/A
 Exam Surface: OD SHELL
 Surface Condition: GROUND

Reference Block
 Serial No.: N/A
 Type: N/A

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Sound Path

Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: NO Reviewed Previous Data: No

Comments: SDCN: 5050201-00
SEE ATTACHED SHEET FOR COMMENTS

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Flesner, Bret T.	II	<i>Bret Flesner</i>	4/13/2005	N/A		
N/A	N/A			RE Hall		4/26/05
Key, Michael W.	III	<i>Michael Key</i>	4/20/2005	ANII Review	<i>Michael Key</i>	4/27/05



Supplemental Report

Report No.: UT-05-049

Page: 2 of 7

Summary No.: 300400

Examiner:	<u>Flesner, Bret T. <i>Bret Flesner</i></u>	Level:	<u>II</u>	Reviewer:	<u>N/A</u>	Date:	
Examiner:	<u>N/A</u>	Level:	<u>N/A</u>	Site Review:	<u><i>60° N/A</i></u>	Date:	<u>4/26/05</u>
Other:	<u>Key, Michael W. <i>self</i></u>	Level:	<u>III</u>	ANII Review:	<u><i>[Signature]</i></u>	Date:	<u>4/27/05</u>

Comments:

Notes for Lamination Scan:

Gain adjusted while scanning to maintain ~80% FSH backwall response.

No Laminations were noted in the area scanned.

The lamination and weld examination scans were limited at TDC from -17" to +17" due to insulation and a metal strap.

Notes for weld volume inspection:

Total weld length is 106".

Scan limitation at TDC from -17" to +17" due to insulation and metal strap.

Scan limitation at BDC from 43" to 63" due to shell weld.

Both of the above limitations affected the 60° transducer, but only the limitation at TDC affected the 0° and 45° transducers.

60° coverage:

54" of scan area limited or 52" of area covered

$52" \div 106" = 49\%$ coverage obtained in axial down, CW, and CCW directions.

45° coverage:

of scan area limited or 72" of area covered

$72" \div 106" = 67.9\%$ coverage obtained in the axial down, CW and CCW directions.

0° coverage:

34" of scan area limited or 72" of area covered

$72" \div 106" = 67.9\%$ coverage obtained.

Total coverage obtained:

$[(60^\circ \text{ axup} + 60^\circ \text{ axdown} + 60^\circ \text{ ccw} + 60^\circ \text{ cw}) + (45^\circ \text{ axup} + 45^\circ \text{ axdown} + 45^\circ \text{ ccw} + 45^\circ \text{ cw}) + (0^\circ)] \div 9 \text{ scan directions} = \text{total coverage obtained.}$

$[(0\% + 49\% + 49\% + 49\%) + (0\% + 67.9\% + 67.9\% + 67.9\%) + 67.9\%] \div 9 = 46.5\%$ coverage obtained.

Maintained 5% ID roll with 45° which resulted in a scan gain exceeding +14 dB.

Maintained 5% to 10% weld noise with 60° which resulted in a scan gain exceeding + 14 dB.

One indication at ~180° and one at ~270° were noted within the weld material at scan gain. These two indications are far below recordable levels and noted for future information only.

Intermittent responses from internal attachments were also noted with all three transducers. These attachments are outside the examination volume.



Supplemental Report


Report No.: UT-05-049

Page: 3 of 7

Summary No.: 300400

Sketch or Photo: X:\U1C20-Framatome Info\STM-14-FWN-G1.jpg

PROFILE AND THICKNESS				
A AREVA	Component ID: STM-14-FWN	Summary No.: 300400		Report No.:
	Crown Height: Flush to 1/16"	Crown Width: 2.85"	Diameter: ~25" Boss	Weld Length: 106" circ.



Profile taken at BDC (180°)

Prepared By: <i>[Signature]</i>	Reviewed By: <i>[Signature]</i>
---------------------------------	---------------------------------

ATTACHMENT 8

RELIEF REQUEST ISIR-40

EXAMINATION CATEGORY C-C
INTEGRAL ATTACHMENTS FOR VESSELS, PIPING, PUMPS AND VALVES

RELIEF REQUEST ISIR-40

Relief Request In Accordance with 10 CFR 50.55a(g)(5)(iii)
Inservice Inspection Impracticality

1. ASME Code Components Affected

ASME Code Class: Code Class 2

Examination Category: C-C, Integral Attachments for Vessels, Piping, Pumps and Valves

Item Numbers: C3.20, Pumps, Integrally Welded Attachments
C3.40, Valves, Integrally Welded Attachments

Component Identification: Listed in Table 1

2. Applicable Code Edition and Addenda

ASME Section XI, 1989 Edition, No addenda

3. Applicable Code Requirement

ASME Section XI, 1989 Edition, Examination Category C-C requires volumetric examination of 100 percent of the weld volume as defined in Table IWC-2500-1 and shown in Figure IWC-2500-5. The alternative requirements of ASME Section XI, Code Case N-460, approved for use in Regulatory Guide 1.147, Revision 15, allows credit for essentially 100 percent coverage of the welds provided greater than 90 percent of the required volume has been examined.

4. Impracticality of Compliance

Pursuant to 10 CFR 50.55a(g)(5)(iii), relief is requested from the essentially 100 percent surface examination coverage requirement for the subject weld due to the permanently attached support orientation and permanently embedded bolting obstructions which limits the surface examination coverage of the subject weld.

These noted obstructions prevent achieving the essentially 100 percent volume examination coverage required by code.

The limitations and the actual examination coverage attained for each weld for which relief is requested are noted in Table 1.

5. Burden Caused by Compliance

To increase the examination coverage on the subject weld requires removal of the permanent structural steel support member by physically cutting the support members apart and replacing the support members by re-welding following the completion of the surface

examination. Removal of the permanently welded support members is considered to be impractical based due to increased cost, potential for increased radiation exposure, and impact to plant equipment.

6. Proposed Alternative and Basis for Use

The subject welds received a surface examination utilizing the best available techniques on the accessible portions of welds to the extent practical. Additionally, a visual (VT-2) examination is performed during each inspection period during the system leakage tests as required by Section XI, Table IWC-2500-1, Category C-H.

Based upon the examination volumes that were attained along with acceptable results and the acceptable visual (VT-2) examination performed each inspection period, it is reasonable to conclude that service induced degradation would be detected. Therefore, these proposed alternatives provide an acceptable level of quality and safety by providing reasonable assurance of structural integrity of the subject welds.

7. Period for Which Relief is Requested

The relief is requested for the Third 10-year inspection interval for Donald C. Cook Nuclear Plant Units 1 and 2, which began on July 1, 1996, and ended April 9, 2010, at the conclusion of the Unit 1 Cycle 23 Refueling Outage. Significant long-term outages (greater than six months) occurred multiple times during the interval and the interval was extended as allowed by IWA-2430(e) and by IWA-2430(d) to accommodate interval planning and scheduling.

Table 1

Component ID	Weld Description	Item Number	Ultrasonic Examination Coverage Attained (%)	Remarks
1-MS-6-11S-PS	Integrally Welded Pipe Attachment	C3.20	64	The completed examination was limited to 64% due to configuration. Base metal examinations were limited due to inner and outer cooler interference. No relevant indications detected.
MSIV-MRV-230-S2	Integrally Welded Support	C3.40	83.3	The completed examination was limited to 83.3% coverage due to the configuration. The limitation on the extent of the coverage for the bottom horizontal attachment weld was based on the orientation of the attached support in relation to the weld. No relevant indications detected.

RELIEF REQUEST ISIR-40

EXAMINATION CATEGORY C-C
INTEGRAL ATTACHMENTS FOR VESSELS, PIPING, PUMPS AND VALVES

SUPPORTING DOCUMENTATION



Liquid Penetrant Examination

Site/Unit: AEP / 1 Procedure: 12-QHP-5050-NDE-001 Outage No.: U1-C23
 Summary No.: 313800 Procedure Rev.: 6 Report No.: PT-10-001
 Workscope: ISI Work Order No.: 55321209-02 Page: 1 of 4

Code: ASME XI 1989 Cat./Item: C-C/C3.20 Location: ANNULUS

Drawing No.: B-63 Description: PENETRATION SUPPORT WELD

System ID: MS

Component ID: 1-MS-6-11S-PS Mat./Thickness: SA350 / 1.688

Limitations: Base Material on both sides of weld inaccessible due to attached coolers

Light Meter Mfg.: Sylvania Serial No.: CQC-275 Illumination: 473 fc
 Temp. Tool Mfg.: Fluke Corp Serial No.: CQC-357 Surface Temp.: 69 °F
 Comparator Block Temp.: Side A: N/A °F Side B: N/A °F Resolution: Not Used
 Lo/Wo Location: _____ Surface Condition: As Found

	Cleaner	Penetrant	Remover	Developer
Brand	Magnaflux	Magnaflux	Magnaflux	Magnaflux
Type	SKC-S	SKL-SP1	SKC-S	SKD-S2
Batch No.	09E01K	05M068	09E01K	06J05K
Time	Evap.	Dwell	Evap.	Develop
Time Exam Started: <u>02:30</u>		Time Exam Completed: <u>03:30</u>		

Indication No.	Loc L	Loc W	Diameter	Length	Type R/L	Remarks

Comments:

**No Reportable Indications Noted. Extent of Coverage per IWC-2500-5.
 Reference attached Limitation record for more information.**

Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: Yes

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Blamer, Eric J.	III		3/19/2010	N/A		
Examiner	Level	Signature	Date	Site Review	Signature	Date
A	N/A			Roy E. Hall		3/21/2010
Other	Level	Signature	Date	ANII Review	Signature	Date
Vargo, Stephen R.	III		3/21/2010	Reuel K. Schenck		3/22/2010



Limitation Record

Site/Unit:	<u>AEP / 1</u>	Procedure:	<u>12-QHP-5050-NDE-001</u>	Outage No.:	<u>U1-C23</u>
Summary No.:	<u>313800</u>	Procedure Rev.:	<u>6</u>	Report No.:	<u>PT-10-001</u>
Workscope:	<u>ISI</u>	Work Order No.:	<u>55321209-02</u>	Page:	<u>4</u> of <u>4</u>

Description of Limitation:

Inner and outer coolers are within the area of interest, circumference = 164.148". Total sq/in of required coverage = 451.407" (1.75 x 164.148 + 82.074 + 82.074). Total sq/in of exam surface NOT examined = 164.148" (1.0 x 164.148). Total sq/in of exam surface examined = 287.259" (1.75 x 164.148). Calculated percentage of required coverage = 64% (287.259 + 451.407)



Limitations removal requirements:

Radiation field:

Examiner	Level	III	Signature	Date	3/19/2010	Reviewer	Signature	Date
Blamer, Eric J.						N/A		
Examiner	Level	N/A	Signature	Date		Site Review	Signature	Date
						Roy E. Hall		3/21/2010
Examiner	Level	III	Signature	Date	3/21/2010	ANII Review	Signature	Date
Vargo, Stephen R.						Reuel K. Schenck		3/22/2010

Additional - Limitation <edit from Setup>



Magnetic Particle Examination

Site/Unit: AEP / 1 Procedure: 12-QHP-5050-NDE-002 Outage No.: U1-C21
 Summary No.: 317180 Procedure Rev.: 3 Report No.: MT-06-004
 Workscope: ISI Work Order No.: 55247775-02 Page: 1 of 3

Code: ASME XI 1989 Cat./Item: C-C/C3.40 Location: W MS ENC

Drawing No.: B-76 Description: Integrally Welded Support

System ID: MRV

Component ID: MSIV-MRV-230-S2 Size/Length: Ref.Limitation Rec.

Limitations: Bottom horizontal attachment weld inaccessible due to support geometry.

Light Meter Mfg.: N/A Serial No.: N/A Illumination: Yoke Light
 Temp. Tool Mfg.: N/A Serial No.: _____ Surface Temp.: Ambient °F
 Resolution: N/A
 Lift Block Serial No.: WT-2 Surface Condition: As Welded
 Lo/Wo Location: N/A Field Orientation: N/A

Magnetic Particle Material

Brand: Magnaflux Wet Mixed: Yes Applied By: Dusting
 Type: Red #8A Dry No Spraying
 Batch No.: 01K085 Fluorescent With: N/A Flooding

Equipment: Parker - B300 Serial No.: 4675
 Head Shot N/A Amperes Fixed Spacing AC DC
 Adj. Spacing 3"-6" inches Encircling Coils N/A Turns
 Prods. Spacing N/A inches Current (machine setting) N/A Amperes

Indication No.	Loc L	Loc W	Diameter	Length	Type R/L	Remarks

Comments:

No Relevant Indications Noted.
 Reference "Limitation Record" for examination limitations.

Results: Accept Reject Info

Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: _____ Exam Time: _____

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Vargo, Stephen R.	III		9/21/2006	Feige, Edward J.		10/16/2006
Examiner	Level	Signature	Date	Site Review	Signature	Date
JA	N/A			Donavin, Paul		10/19/2006
Other	Level	Signature	Date	ANII Review	Signature	Date
Ouellette, John	II		9/25/2006	Longenberger, James A.		10/19/2006




Limitation Record

Site/Unit: <u>AEP / 1</u>	Procedure: <u>12-QHP-5050-NDE-002</u>	Outage No.: <u>U1-C21</u>
Summary No.: <u>317180</u>	Procedure Rev.: <u>3</u>	Report No.: <u>MT-06-004</u>
Workscope: <u>ISI</u>	Work Order No.: <u>55247775-02</u>	Page: <u>3</u> of <u>3</u>

Description of Limitation:

Limitation on the extent of coverage due to orientation of installed support steel. Calculated that 83.3% of the required exam area was examined.

MSIV-MRV-230-S2
SUMMARY NO. 317180
55247775-02



Total Sq/in. of required coverage = 204.375
Total Sq/in. of Exam Surface NOT Examined = 34.125
Total Sq/in. Examined = 170.25
Total coverage attained = 83.30%

Limitations removal requirements:

Radiation field:

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Vargo, Stephen R.	III		9/21/2006	Felge, Edward J.		10/16/2006
	N/A			Donavin, Paul		10/19/2006
Ouellette, John	II		9/25/2006	Longenberger, James A.		10/19/2006

Additional - Limitation <edit from Setup>

ATTACHMENT 9

RELIEF REQUEST ISIR-41

EXAMINATION CATEGORY C-F-1
PRESSURE RETAINING WELDS IN AUSTENITIC STAINLESS STEEL OR HIGH ALLOY
PIPING

RELIEF REQUEST ISIR-41

Relief Request In Accordance with 10 CFR 50.55a(g)(5)(iii)
Inservice Inspection Impracticality

1. ASME Code Components Affected

ASME Code Class: Code Class 2

Examination Category: C-F-1,

Item Numbers: C5.11, Piping Welds \geq 3/8 inch Nominal Wall Thickness for Piping
> NPS 4, Circumferential Weld
C5.21, Piping Welds \geq 1/5 inch Nominal Wall Thickness for Piping
 \geq NPS 2 and \leq NPS 4, Circumferential Weld

Component Identification: Listed in Table 1

2. Applicable Code Edition and Addenda

ASME Section XI, 1989 Edition, No addenda

Austenitic piping welds with single side access subject to ultrasonic examination with Supplement 2 of Appendix VIII to the 1995 Edition with 1996 Addenda of ASME Section XI.

3. Applicable Code Requirement

ASME Section XI, 1989 Edition, Examination Category C-F-1 requires volumetric examination of 100 percent of the weld volume as defined in Table IWC-2500-1 and shown in Figure IWC-2500-7. The alternative requirements of ASME Section XI, Code Case N-460, approved for use in Regulatory Guide 1.147, Revision 15, allows credit for essentially 100 percent coverage of the welds provided greater than 90 percent of the required volume has been examined.

10 CFR 50.55a(b)(2)(xv)(A), requires the following examination coverage criteria when applying Supplement 2 to Appendix VIII:

(1) Piping must be examined in two axial directions and when examination in the circumferential direction is required, the circumferential examination must be performed in two directions, provided access is available.

(2) Where examination from both sides is not possible, full coverage credit may be claimed from a single side for ferritic welds. Where examination from both sides is not possible on austenitic welds, full coverage credit from a single side may be claimed only after completing a successful single sided Appendix VIII demonstration using flaws on the opposite side of the weld.

10 CFR 50.55a(b)(2)(xvi)(B), requires that examinations performed from one side of a ferritic or stainless steel pipe weld must be conducted with equipment, procedures, and personnel that have demonstrated proficiency with single side examinations. To demonstrate equivalency to the two sided examinations, the demonstration must be performed to the requirements of Appendix VIII as modified by this paragraph and 10 CFR 50.55a(b)(2)(xv)(A).

4. Impracticality of Compliance

Pursuant to 10 CFR 50.55a(g)(5)(iii), relief is requested from the essentially 100 percent volumetric examination coverage requirement for austenitic piping welds with single side access.

There are currently no Performance Demonstration Initiative (PDI) qualified single side examination procedures that demonstrate equivalency to two-sided examination procedures on austenitic piping welds. Current technology, is not capable of reliably detecting or sizing flaws on the far side of an austenitic weld for configurations common to United States nuclear applications.

PDI Performance Demonstration Qualification Summary (PDQS) certificates for austenitic piping list the limitation that single side examination is performed on a best effort basis. The best effort qualification is provided in place of a complete single side qualification to demonstrate that the examiners qualification and the subsequent weld examination is based on application of the best available technology.

When the examination area is limited to one side of an austenitic weld, examination coverage does not comply with 10 CFR 50.55a(b)(2)(xv)(A) and proficiency demonstrations do not comply with 10 CFR 50.55a(b)(2)(xvi)(B) and full coverage credit may not be claimed.

Based on the configuration limited to single side access, relief is requested from the essentially 100 percent surface examination coverage requirements for the subject piping welds listed in Table 1. Note that examination coverage listed is that attained during examination with no credit taken for the far side of each weld in which examination from that side could not be performed.

Pursuant to 10 CFR 50.55a(g)(5)(iii), relief is requested from the essentially 100 percent volumetric examination coverage requirement for the subject welds due to the geometric configuration and permanent obstructions which limit the volumetric examination coverage of the subject welds.

The limitations and the actual examination coverage attained for each weld for which relief is requested are noted in Table 1.

5. Burden Caused by Compliance

Compliance with code requirements requires extensive modification or replacement of components with a design that allows examination from both sides of the weld. This option to meet the required 100 percent volume examination coverage is considered impractical based on the cost, additional radiation exposure and impact to plant equipment.

6. Proposed Alternative and Basis for Use

The subject welds received a volumetric examination to the maximum extent practical utilizing the best available techniques, as qualified through the Performance Demonstration Initiative (PDI) for Supplement 2 with demonstrated best effort for single sided examination, from the accessible side of the weld. Additionally, a surface examination without limitations was performed on each weld. Further, a visual (VT-2) examination is performed each inspection period during the system leakage tests as required by Section XI, Table IWC-2500-1, Category C-H.

Based upon the examination volumes that were obtained with acceptable results along with the completed surface examination and the visual (VT-2) examination performed each inspection period, it is reasonable to conclude that service induced degradation would be detected if present. Therefore, these proposed alternatives provide an acceptable level of quality and safety by providing reasonable assurance of structural integrity of the subject welds.

7. Period for Which Relief is Requested

The relief is requested for the Third 10-year inspection interval for Donald C. Cook Nuclear Plant Units 1 and 2, which began on July 1, 1996, and ended April 9, 2010, at the conclusion of the Unit 1 Cycle 23 Refueling Outage. Significant long-term outages (greater than six months) occurred multiple times during the interval and the interval was extended as allowed by IWA-2430(e) and by IWA-2430(d) to accommodate interval planning and scheduling.

Table 1

Component ID	Weld Description	Item Number	Ultrasonic Examination Coverage Attained (%)	Remarks
1-CTS-2-18F	Pipe to Flange	C5.11	50.0	The completed examination was limited to 50% coverage due to the configuration. The flange side is limited by the O.D. contour and flange bolting. No relevant indications detected.
1-SI-2-42S	Pipe to Pump Casing	C5.11	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration prevents examination from the pump side due to its severe taper and the proximity of the pump casing to the weld. No relevant indications detected.
1-RH-27-05S	Pipe to Elbow	C5.11	78.0	The completed examination was limited to 78% coverage due to the configuration. The configuration prevents examination due to the welds location inside of the box restraint surrounding the pipe. No relevant indications detected.
1-SI-24-06F	Pipe to Tee	C5.11	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration prevents examination on the tee side due to the sharp bevel adjacent to the tee side weld toe. No relevant indications detected.
1-SI-30-08F	Valve to Pipe	C5.11	50.0	The completed examination was limited to 50% coverage due to the configuration. The examination limitation is caused by the OD bevel on the valve, which is in proximity to the weld toe on the valve side. No relevant indications detected.
1-SI-34-11F	Elbow to Valve	C5.11	50.0	The completed examination was limited to 50% coverage due to the configuration. Full coverage was not obtainable due to the bevel at the weld toe on the valve side of the weld. No relevant indications detected.

Table 1 (continued)

Component ID	Weld Description	Item Number	Ultrasonic Examination Coverage Attained (%)	Remarks
2-CTS-13-04F	Pipe to Valve	C5.11	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration prevents examination from the valve side due to its severe taper and close proximity of the valve to the weld. No relevant indications detected.
1-SI-11A-01S	Flange to Elbow	C5.21	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration of the reducing elbow to flange leads to a limited examination based on the taper of the flange face and its proximity to the weld. No relevant indications detected.
1-SI-11-01S	Flange to Elbow	C5.21	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration of the elbow to flange leads to a limited examination based on the taper of the flange face and its proximity to the weld. No relevant indications detected.
1-SI-11-05F	Pipe to Valve	C5.21	49.0	The completed examination was limited to 49% coverage due to the configuration. The configuration prevents examination from the valve side due to its severe taper and the close proximity of the valve. A portion of the pipe side is obstructed due to the proximity of the integrally welded pipe support. No relevant indications detected.
1-SI-74-01F	Penetration to Elbow	C5.21	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration prevents examination from the penetration side due to the OD surface contour and the proximity of the penetration. No relevant indications detected.

Table 1 (continued)

Component ID	Weld Description	Item Number	Ultrasonic Examination Coverage Attained (%)	Remarks
2-SI-42-01S	Flange to Elbow	C5.21	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration prevents examination from the flange side due to its severe taper and close proximity of the flange taper to the weld. No relevant indications detected.
2-SI-42-03F	Pipe to Valve	C5.21	46.5	The completed examination was limited to 46.5% coverage due to the configuration. The configuration prevents examination from the valve side due to its severe taper and close proximity of the valve to the weld. Additionally, a portion of the examination area was obstructed due to a branch connection in the piping. No relevant indications detected.
2-SI-73-02S	Elbow to Pipe	C5.21	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration prevents examination from the elbow side due to its severe taper and close proximity of the elbow to the weld. No relevant indications detected.
2-SI-81-01F	Valve to Elbow	C5.21	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration prevents examination from the valve side due to its severe taper and close proximity of the valve to the weld. No relevant indications detected.

RELIEF REQUEST ISIR-41

EXAMINATION CATEGORY C-F-1
PRESSURE RETAINING WELDS IN AUSTENITIC STAINLESS STEEL OR HIGH ALLOY
PIPING

SUPPORTING DOCUMENTATION

INCOMPLETE EXAMINATION REPORT

REPORT NO: UIC18-WT-008

PAGE 4 OF 4

DATA PKG: N/A

PROCEDURE: 83A6228 Rev.2

PLANT/UNIT: D.C. Cook/Unit 1 WELD NO: 1-CTS-2-18F SYSTEM: CTS

CONFIGURATION: FLANGE to Elbow

ASME CODE CLASS: C-F-1, C5.11

CODE EXAMINATION REQUIREMENTS: In Accordance to 1989 Section III, Figure IWC-2500-7(k)

INTERFERING CONDITION: Single - Sided Access Due to Configuration. PIPE TO FLANGE, FLANGE SIDE IS LIMITED BY O.D. CONTOUR & FLANGE BOLTING, SINGLE SIDED ACCESS CLAIMED IN ACCORDANCE WITH PROCEDURE PARAGRAPH 2.3.

ESTIMATE OF TOTAL % CODE COMPLETE: 50% SKETCH ATTACHED: YES NO X

PARTIAL EXAMINATION PERFORMED: YES X NO NO

EXAMINATION ANGLE AFFECTED:

0 DEGREE WRV Yes 0 DEGREE BASE MATERIAL N/A

45 DEGREE AXIAL Yes 45 DEGREE CIRCUMFERENTIAL Yes

OTHER: 70° Axial Scan*

ALTERNATE METHOD RECOMMENDED: YES NO X

EXPLANATION: * EXAMINATION PERFORMED IN ACCORDANCE TO 83A6228 REV 2

PREPARED BY: Dennis P. Strick

DATE: 4.30.02



REVIEWED: [Signature]

DATE: 5-4-02

RE Hall 5/17/02

1-CTS-2-18F

Elevation 609', rear of CTS Heat Exchanger Room. Approximately 6' of scaffold. Non-insulated.



INCOMPLETE EXAMINATION REPORT

REPORT NO: U1619-UT-011
PAGE 4 OF 4
DATA PKG: N/A
PROCEDURE: 83A6228 Rev. 2

PLANT/UNIT: D.C. Cook / Unit 1 WELD NO: 1-SI-2-42S SYSTEM: SI

CONFIGURATION: PIPE TO PUMP

ASME CODE CLASS: C-F-1, C 5.11

CODE EXAMINATION REQUIREMENTS: IN ACCORDANCE WITH 1989 SECTION XI, FIGURE IWC-2500-7(a)

INTERFERING CONDITION: SINGLE-SIDE ACCESS DUE TO CONFIGURATION.
Pump side configuration is limited by a sharp bevel at the
weld edge. Procedure 83A6228 is qualified for detection
on the near side of single sided access welds only (para. 2.3)

ESTIMATE OF TOTAL % CODE COMPLETE: 50% SKETCH ATTACHED: YES NO X

PARTIAL EXAMINATION PERFORMED: YES X NO NO

EXAMINATION ANGLE AFFECTED:
0 DEGREE WRV YES 0 DEGREE BASE MATERIAL N/A
45 DEGREE AXIAL YES 45 DEGREE CIRCUMFERENTIAL YES

OTHER: * 70° Axial

ALTERNATE METHOD RECOMMENDED: YES NO X

EXPLANATION: * EXAMINATION PERFORMED IN ACCORDANCE TO 83A6228 REV 2



PREPARED BY: Dennis P. Stuck DATE: 5.3.02

REVIEWED: Shirley DATE: 5.6.02

Re Hall 5/17/02

1-SI-2-42S (F on Fig. B-12)

Auxiliary building, 577' elevation. West CTS pump room. No scaffold required. Non-insulated.



Ultrasonic Examination Limitation Report

DATA SHEET # UIC18-UT-021

Weld location is within the area of the box restraint surrounding the pipe.


0" location = top dead center of upstream horizontal run of pipe.

Total circumferential length of weld = 40.0

Of the total 40 inches of circumferential weld length, the following was not examined with the 45° scan.

- Lug @ 0° - 0.0"
- Lug @ 90° - 6.5"
- Lug @ 180° - 0.0"
- Lug @ 270° - 2.5"
- Total Length 9.0"

40.0" - 9.0" = 31.0" examined
 31.0" / 40.0" = 78% of weld inspected



Examiners:

- 1. _____ Level: _____ Date: _____
- 2. _____ Level: _____ Date: _____

Reviewers:

- 1. [Signature] Level: III Date: 5-21-02
- 2. _____ Level: _____ Date: _____
- 3. _____ Level: _____ Date: _____

INCOMPLETE EXAMINATION REPORT

REPORT NO: WC18-UT-021
PAGE 4 OF 4
DATA PKG: N/A
PROCEDURE: 83AG228 Rev 2

PLANT/UNIT: D.C. COOK / UNIT 1 WELD NO: 1-RH-27-05S SYSTEM: RH

CONFIGURATION: PIPE TO ELBOW

ASME CODE CLASS: C-F-1

CODE EXAMINATION REQUIREMENTS: IN ACCORDANCE TO 1989 SECTION XI, FIGURE IWC-2500-7(a)

INTERFERING CONDITION: WELD LOCATED INSIDE OF BOX RESTRAINT

ESTIMATE OF TOTAL % CODE COMPLETE: _____ SKETCH ATTACHED: YES X NO _____

PARTIAL EXAMINATION PERFORMED: YES X NO _____

EXAMINATION ANGLE AFFECTED:

0 DEGREE WRV YES 0 DEGREE BASE MATERIAL N/A

45 DEGREE AXIAL YES 45 DEGREE CIRCUMFERENTIAL YES

OTHER: N/A

ALTERNATE METHOD RECOMMENDED: YES _____ NO X


EXPLANATION: EXAMINATION PERFORMED IN ACCORDANCE TO 83AG228, REV 2.
ALTERNATE METHODS WILL NOT INCREASE COVERAGE DUE TO THE PHYSICAL LOCATION OF THE WELD IN RELATION TO THE BOX RESTRAINT.

PREPARED BY: [Signature] DATE: 5-15-02

REVIEWED: [Signature] DATE: 5-21-02
REMO 5/28/02

1-RH-27-05S

Annulus Area, elevation 608'. No scaffold required. Insulated. Limited UT examinations due to box restraint. Need ladder to access steel - sit on steel for exam.



INCOMPLETE EXAMINATION REPORT

REPORT NO: W118-UT-014
PAGE 3 OF 3
DATA PKG: N/A
PROCEDURE: 83A6228 REV2

PLANT/UNIT: D.C. Cook WELD NO: 1-SI-24-06F SYSTEM: SI

CONFIGURATION: PIPE TO TEE

ASME CODE CLASS: C-F-1

CODE EXAMINATION REQUIREMENTS: IN ACCORDANCE TO 1989 SECTION XI, FIGURE IWC-250-7(a)

INTERFERING CONDITION: SINGLE-SIDED ACCESS DUE TO CONFIGURATION. SINGLE SIDED ACCESS EXAMINATION PERFORMED IN ACCORDANCE WITH PROCEDURE PARAGRAPH 2-3. O.D. CONFIGURATION OF TEE SIDE LIMITS EXAM DUE TO SHARP BEVEL ADJACENT TO TEE SIDE WELD TOE.

ESTIMATE OF TOTAL % CODE COMPLETE: 50% SKETCH ATTACHED: YES NO X

PARTIAL EXAMINATION PERFORMED: YES X NO

EXAMINATION ANGLE AFFECTED:

0 DEGREE WRV N/A 0 DEGREE BASE MATERIAL N/A

45 DEGREE AXIAL YES 45 DEGREE CIRCUMFERENTIAL YES

OTHER: * 70° RL Axial Scan

ALTERNATE METHOD RECOMMENDED: YES NO X

EXPLANATION: * EXAMINATION PERFORMED IN ACCORDANCE TO 83A6228, REV2.

PREPARED BY: Dennis P. Strickland DATE: 5-16-02

REVIEWED: [Signature] DATE: 5-17-02

Rehall 5/17/02



visual Component Database



Component Number: 1-SI-152N

Image Title: 1-SI-152N

Image Date: 12/30/1899



Date Printed: 05/30/2002 09:37 AM




visual Component Database



Component Number: 1-SI-152N

Image Title: 1-SI-152N

Image Date: 04/14/1997



Date Printed: 05/30/2002 09:37 AM

INCOMPLETE EXAMINATION REPORT

REPORT NO: UIC10-UT-012
PAGE 4 OF 4
DATA PKG: _____
PROCEDURE: 83A6228 Rev.2

PLANT/UNIT: D.C. Cook / Unit 1 WELD NO: 1-SI-30-08F SYSTEM: SI
CONFIGURATION: VALVE TO PIPE
ASME CODE CLASS: C-F-1
CODE EXAMINATION REQUIREMENTS: IN ACCORDANCE TO 1989 SECTION XI
FIGURE IWC-2500-7(a)

INTERFERING CONDITION: SINGLE-SIDED ACCESS DUE TO CONFIGURATION. PIPE TO VALVE CONFIGURATION LIMITED TO PIPE SIDE ACCESS AND SINGLE SIDED EAM IN ACCORDANCE WITH PARAGRAPH 2.3 OF PROCEDURE. THE LIMITATION CAUSED BY THE O.D. BEVEL ON THE VALVE ADJACENT TO THE WELD TOE, VALVE SIDE.

ESTIMATE OF TOTAL % CODE COMPLETE: 50% SKETCH ATTACHED: YES _____ NO X
PARTIAL EXAMINATION PERFORMED: YES X NO _____

EXAMINATION ANGLE AFFECTED:
0 DEGREE WRV X 0 DEGREE BASE MATERIAL N/A
45 DEGREE AXIAL X 45 DEGREE CIRCUMFERENTIAL X

OTHER: 70° RL AXIAL

ALTERNATE METHOD RECOMMENDED: YES _____ NO X

EXPLANATION: EXAMINATION PERFORMED IN ACCORDANCE TO 83A6228 REV 2.



PREPARED BY: [Signature] DATE: 5-11-02

REVIEWED: [Signature] DATE: 5-11-02

[Signature] Re Hall 5/11/02

1-SI-30-08F

Annulus Area, elevation 599'. No scaffold required. Not Insulated. Right above floor.



Weld located approximately 1" downstream from the top of the lugs.

0° location = inside radius of the upstream elbow.

Total circumferential length of weld = 33.75


Of the total 33.75 inches of circumferential weld length, the following was not examined with the 45° scan on the upstream side of the weld.

- Lug @ 0° - 0.0"
- Lug @ 90° - 5.0"
- Lug @ 180° - 3.5"
- Lug @ 270° - 5.5"
- Total Length 14.0"

33.75" - 14.0" = 19.75" examined
 19.75" / 40.0" = 58.5% of weld inspected

A 70° RL examination was conducted in the areas that the 45° transducer could not scan. Because of this, 100% of the upstream side of the weld was examined resulting in 50% of the total required being completed.

The downstream side of the weld could not be examined because of the valve. See Incomplete Examination Report for total coverage achieved on this exam.



Examiners:

1. *Dennis P. [Signature]* Level: II Date: 5-11-02
2. _____ Level: _____ Date: _____

Reviewers:

1. *[Signature]* Level: III Date: 5-11-02
2. *[Signature]* Level: - Date: 5/28/02
3. *[Signature]* Level: _____ Date: 5/29/02

INCOMPLETE EXAMINATION REPORT

REPORT NO: UICB-UT-022
PAGE 5 OF 5
DATA PKG: N/A
PROCEDURE: 83A6228 REV2

PLANT/UNIT: D.C. Cook / UNIT 1 WELD NO: 1-SI-34-11F SYSTEM: SI

CONFIGURATION: ELBOW TO VALVE

ASME CODE CLASS: C-F-1

CODE EXAMINATION REQUIREMENTS: IN ACCORDANCE TO 1989 SECTION XI, FIGURE IWC-2500.7(a)

INTERFERING CONDITION: SINGLE-SIDED ACCESS DUE TO CONFIGURATION.
SINGLE SIDED EXAMINATION PERFORMED IN ACCORDANCE WITH PROCEDURE PARAGRAPH 2.3. VALVE SIDE SCANNING IS NOT POSSIBLE DUE TO BEVEL AT THE WELD TOE ON THE VALVE SIDE.

ESTIMATE OF TOTAL % CODE COMPLETE: 50% SKETCH ATTACHED: YES X NO

PARTIAL EXAMINATION PERFORMED: YES X NO

EXAMINATION ANGLE AFFECTED:
0 DEGREE WRV X 0 DEGREE BASE MATERIAL N/A
45 DEGREE AXIAL X 45 DEGREE CIRCUMFERENTIAL X

OTHER: *70° RL AXIAL

ALTERNATE METHOD RECOMMENDED: YES NO X

EXPLANATION: *EXAMINATION PERFORMED IN ACCORDANCE TO 83A6228, REV. 2.

PREPARED BY: Dennis P. Strickland DATE: 5.11.02
REVIEWED: RENO DATE: 5.21.02
5/28/02

EXAMINATION SUMMARY

AMATOME ANF

Summary No.: 317310	Data Package: U2C14-0007	Exam Date: 5/9/2003
Customer: DC COOK U2C14	Examination Methods: UT, PT	
System / Component ID: CONTAINMENT SPRAY / 2-CTS-13-04F	Examination Procedures: 54-ISI-836-04, 54-ISI-240-40	
Component Description: PIPE TO VALVE	Calibration Sheets No(s): 00018, 00019, 00020	
Examination Category: C-F-1	Examination Results: <input checked="" type="checkbox"/> No Reportable Indications <input type="checkbox"/> Reportable Indications <input checked="" type="checkbox"/> Geometric	
ISO / Drawing: B-49		

Summary:
 COMPONENT NUMBER 2-CTS-13-04F, PIPE TO VALVE WAS EXAMINED USING THE PT AND UT METHODS.
 ID GEOMETRY WAS RECORDED WITH THE 60 & 70 DEGREE TRANSDUCERS.
 THE UT WAS LIMITED TO SINGLE SIDED ACCESS, DUE TO PIPE TO VALVE CONFIGURATION, RESULTING IN 50% EXAM COVERAGE.
 CA# DC-03-001 REVISION 00 APPLIES TO PROCEDURE 54-ISI-836-04

Prepared By: Simon Crothers	Date: 5-9-03	Reviewed By: Jerry Newgard	Date:
Sign: <i>Simon Crothers</i>		Sign: <i>Jerry Newgard</i>	5-17-03
Customer:	Date:	Page 1 of 9	
Sign: <i>Reggie NWC</i>	5/20/03		



PROFILE AND THICKNESS

Exam Date: 5-9-03

Summary No.: 317310



Site: DC COOK U2C14

Examination Method: UT

System: CONTAINMENT SPRAY

Identification: 2-CTS-13-04F

POSITION	0	90	180	270	
1	0.38"	N/A	N/A	N/A	CROWN HEIGHT: <u>0.05"</u>
2	0.35"	N/A	N/A	N/A	CROWN WIDTH: <u>0.5"</u>
3	0.45"	N/A	N/A	N/A	NOM DIAMETER: <u>4"</u>
4	N/A	N/A	N/A	N/A	WELD LENGTH: <u>34"</u>
5	N/A	N/A	N/A	N/A	



Simon Crothers 5-9-03

Prepared By Simon Crothers Date

Reviewed By Jerry [Signature] Date

5-17-03

Utility Review By Ray E. Hall Date

5/20/03

INCOMPLETE EXAMINATION REPORT

REPORT NO: UCLB-WT-004
PAGE 4 OF 4
DATA PKG: N/A
PROCEDURE: 83AG228 Rev. 2

PLANT/UNIT: D.C. Cook / Unit 1 WELD NO: 1-SI-11A-015 SYSTEM: SI

CONFIGURATION: Flange to Elbow

ASME CODE CLASS: C-F-1

CODE EXAMINATION REQUIREMENTS: In Accordance with 1989 Section XI, Figure IWC-2500-7(a)

INTERFERING CONDITION: Single-Sided Access Due to Configuration. Reducing Elbow to Flange Configuration is limited to single sided examination from the elbow side in accordance with procedure paragraph 2.3. The limitation is the OD contour (bevel) of the flange face.

ESTIMATE OF TOTAL % CODE COMPLETE: 50% SKETCH ATTACHED: YES NO X

PARTIAL EXAMINATION PERFORMED: YES X NO

EXAMINATION ANGLE AFFECTED:
0 DEGREE WRV Yes 0 DEGREE BASE MATERIAL N/A
45 DEGREE AXIAL N/A 45 DEGREE CIRCUMFERENTIAL Yes

OTHER: 70° Axial

ALTERNATE METHOD RECOMMENDED: YES NO X

EXPLANATION: Examination Performed in Accordance 83AG228 Rev 2 70° Axial Scan Performed Due to Pipe Wall Dimension (.203), Weld Crown Condition (As welded) And Elbow to Flange Configuration.

PREPARED BY: Daniel P. Shuck

DATE: 4.30.02



REVIEWED: Shup Singh

DATE: 5.4.02

PH
PH 5/17/02

1-SI-11A-01S

Auxiliary building 587' elevation. North Safety Injection Pump Room. No scaffold required. Non-insulated.



INCOMPLETE EXAMINATION REPORT

REPORT NO: UIC18-UT-005
PAGE 4 OF 4
DATA PKG: N/A
PROCEDURE: 83A6228 Rev 2

PLANT/UNIT: D.C. Cook / Unit 1 WELD NO: 1-SI-11A-015 SYSTEM: SI

CONFIGURATION: Flange to Elbow

ASME CODE CLASS: C-F-1

CODE EXAMINATION REQUIREMENTS: In Accordance to 1989 Section XI,
Figure IWC-2500-7(a)

INTERFERING CONDITION: Single-sided Access Due to Configuration. Reducing
Elbow to FLANGE Configuration is Limited to SINGLE SIDED ACCESS
From the Elbow side in accordance with Procedure Paragraph 2.3.
The Limitation is the O.D. Contour (Bevel) of the Flange Face.

ESTIMATE OF TOTAL % CODE COMPLETE: 50% SKETCH ATTACHED: YES NO X

PARTIAL EXAMINATION PERFORMED: YES X NO

EXAMINATION ANGLE AFFECTED:

0 DEGREE WRV Yes 0 DEGREE BASE MATERIAL N/A

45 DEGREE AXIAL N/A 45 DEGREE CIRCUMFERENTIAL Yes

OTHER: 70° Axial

ALTERNATE METHOD RECOMMENDED: YES NO X

EXPLANATION: Examination Performed in Accordance with 83A6228 Rev. 2
70° Axial Scan Performed Due to Pipe Wall Dimension (.203), weld crown
condition (as welded) and Elbow to Flange Configuration.

PREPARED BY: Dennis Shields

DATE: 4-30-02

REVIEWED: Shubany

DATE: 5-4-02

MM Reid 5/17/02

INCOMPLETE EXAMINATION REPORT

REPORT NO: UICIB-UT-005
PAGE 4 OF 4
DATA PKG: N/A
PROCEDURE: 83A6228 Rev 2

PLANT/UNIT: D.C. Cook / Unit 1 WELD NO: 1-SI-11A-015 ^{Ref # 4/16/01} SYSTEM: SI

CONFIGURATION: Flange to Elbow

ASME CODE CLASS: C-F-1

CODE EXAMINATION REQUIREMENTS: In Accordance to 1989 Section XI, Figure INC-2500-7(a)

INTERFERING CONDITION: Single-sided Access Due to Configuration. Reducing Elbow to Flange Configuration is Limited to Single Sided Access from the Elbow Side in Accordance with Procedure Paragraph 2.3. The Limitation is the O.D. Contour (Bevel) of the Flange Face.

ESTIMATE OF TOTAL % CODE COMPLETE: 50% SKETCH ATTACHED: YES NO

PARTIAL EXAMINATION PERFORMED: YES NO

EXAMINATION ANGLE AFFECTED:

0 DEGREE WRV Yes 0 DEGREE BASE MATERIAL N/A

45 DEGREE AXIAL N/A 45 DEGREE CIRCUMFERENTIAL Yes

OTHER: 70° Axial

ALTERNATE METHOD RECOMMENDED: YES NO

EXPLANATION: Examination Performed in Accordance with 83A6228 Rev. 2 70° Axial Scan Performed Due to Pipe Wall Dimension (.203), weld crown condition (as welded) and Elbow to Flange Configuration.

PREPARED BY: Dennis P. Smith

DATE: 4-30-02



REVIEWED: [Signature]

DATE: 5.4.02

[Signature] 5/1/02

1-SI-11-01S

Auxiliary building 587' elevation. South Safety Injection Pump Room. No scaffold required. Non-insulated.



INCOMPLETE EXAMINATION REPORT

REPORT NO: WCI0-UT-006
PAGE 4 OF 6
DATA PKG: N/A
PROCEDURE: 03A622B R/2

PLANT/UNIT: D.C. Cook Unit 1 WELD NO: I-SI-11-05F SYSTEM: SI

CONFIGURATION: FLANGE TO ELBOW

ASME CODE CLASS: C-F-1, CS.21

CODE EXAMINATION REQUIREMENTS: 1989 Ed., ASME Section XI
FIGURE IXC-2500-7(a)

INTERFERING CONDITION: SINGLE SIDE ACCESS DUE TO CONFIGURATION
AND PIPE Support I-GSI-R-2. PIPE TO VALVE, VALVE SIDE
IS LIMITED DUE TO O.D. BEVEL ADJACENT TO WELD AND ON
PIPE SIDE BY Support INTEGRAL ATTACHMENT. (SEE SKETCH)

ESTIMATE OF TOTAL % CODE COMPLETE: 49% SKETCH ATTACHED: YES NO

PARTIAL EXAMINATION PERFORMED: YES NO


EXAMINATION ANGLE AFFECTED:
0 DEGREE WRV YES 0 DEGREE BASE MATERIAL N/A
45 DEGREE AXIAL YES 45 DEGREE CIRCUMFERENTIAL YES

OTHER: * 70 DEGREE AXIAL

ALTERNATE METHOD RECOMMENDED: YES NO

EXPLANATION: * EXAMINATION PERFORMED IN ACCORDANCE WITH 03A622B R/2.

PREPARED BY: Dennis L. Hurd DATE: 4.30.02
REVIEWED: Shelby DATE: 5.6.02
Rehll 5/17/02



* OBSTRUCTION, .30" FROM WELDTOE, .20" LONG CIRCUMFERENTIALLY, 2 PLACES, SUPPORT # 1-GSI-R2. SEE ATTACHED SKETCH.

REQUIRED VOLUME = $.95" \times .102" \times 14.25" (\text{CIRCUMFERENCE}) = 1.38"^3$

VOLUME NOT EXAMINED = 50% NOT EXAMINED ON VALVE SIDE DUE TO SINGLE SIDED ACCESS.

PLUS


$.475" \times .102" \times .20" \times 2 (\text{PLACES}) = .00969"^3$

PERCENTAGE NOT EXAMINED = $.00969"^3 \div 1.38"^3 =$

$.70\% + 50\% = 50.7\% = 51\%$

EXAMINERS 1	<i>Daniel J. Hill</i>	LEVEL	<u>II</u>	DATE	<u>4/9/02</u>
2	<u>N/A</u>	LEVEL	<u>N/A</u>	DATE	<u>N/A</u>
REVIEWERS 1	<i>[Signature]</i>	LEVEL	<u>III</u>	DATE	<u>5/6/02</u>
2	<i>[Signature]</i>	LEVEL	<u>-</u>	DATE	<u>5/17/02</u>
3	<i>[Signature]</i>	LEVEL	<u>-</u>	DATE	<u>5/17/02</u>

SUPPORT # 1 - GSI-R-2 OBSTRUCTION



EXAMINERS	1 <i>Dennis Stubb</i>	LEVEL	III	DATE	4/30/02
	2 <i>N/A</i>	LEVEL	N/A	DATE	N/A
REVIEWERS	1 <i>Steph...</i>	LEVEL	III	DATE	5/6/02
	2 <i>...</i>	LEVEL	-	DATE	5/17/02
	3 <i>...</i>	LEVEL	-	DATE	5/17/02

INCOMPLETE EXAMINATION REPORT

REPORT NO: UIC18-UT-013
PAGE 4 OF 4
DATA PKG: N/A
PROCEDURE: 83A6228 R/2

PLANT/UNIT: D.C. Cook Unit #1 WELD NO: 1-SI-74-01F SYSTEM: SI

CONFIGURATION: PENETRATION TO ELBOW

ASME CODE CLASS: C-F-1, CS.21

CODE EXAMINATION REQUIREMENTS: IN ACCORDANCE WITH 1989 ASME
Section XI, IWC-2500-7(a)

INTERFERING CONDITION: SINGLE SIDED ACCESS DUE TO CONFIGURATION.
PENETRATION TO ELBOW ALLOWS EXAMINATION FROM ELBOW SIDE ONLY
DUE TO O.D. SURFACE CONTOUR AND PENETRATION PROXIMITY
ON PENETRATION SIDE.

ESTIMATE OF TOTAL % CODE COMPLETE: 50% SKETCH ATTACHED: YES NO

PARTIAL EXAMINATION PERFORMED: YES NO

EXAMINATION ANGLE AFFECTED:

0 DEGREE WRV 0 DEGREE BASE MATERIAL N/A

45 DEGREE AXIAL 45 DEGREE CIRCUMFERENTIAL

OTHER: 70° AXIAL*

ALTERNATE METHOD RECOMMENDED: YES NO

EXPLANATION: * EXAMINATION PERFORMED IN ACCORDANCE WITH
83A6228 R/2.


PREPARED BY: Dennis P. Smith

DATE: 5-11-02

REVIEWED: Shirley

DATE: 5-11-02

REHOC 5/17/02



EXAMINERS 1	<u>McH</u>	LEVEL	<u>II</u>	DATE	<u>5-11-02</u>
2	<u>N/A</u>	LEVEL	<u>N/A</u>	DATE	<u>N/A</u>
REVIEWERS 1	<u>ShoDean</u>	LEVEL	<u>III</u>	DATE	<u>5-11-02</u>
2	<u>Ken</u>	LEVEL	<u>-</u>	DATE	<u>5/17/02</u>
3		LEVEL		DATE	

A

EXAMINATION SUMMARY

FRAMATOME ANP

Summary No.: 325500

Data Package: U2C14-0004

Exam Date: 5/8/2003

Customer: DC COOK U2C14

Examination Methods: UT , PT

System / Component ID: ECCS (SI) / 2-SI-42-01S

Examination Procedures: 54-ISI-836-04 , 54-ISI-240-40

Component Description: FLANGE TO ELBOW

Calibration Sheets No(s): 00010, 00011

Examination Category: C-F-1

Examination Results: No Reportable Indications

Reportable Indications

ISO / Drawing: B-83

Geometric

Summary:

COMPONENT NUMBER 2-SI-42-01S , VALVE TO ELBOW WAS EXAMINED USING THE PT, AND UT METHODS.

COUNTERBORE WAS OBSERVED WITH THE 70 DEGREE TRANSDUCER , SEE THE ATTACHED UT INDICATION DATA SHEET.

CA NO: DC-03-001 REVISION 00 APPLIES TO 54-ISI-836-04

THE UT EXAM WAS LIMITED TO SINGLE SIDED ACCESS , DUE TO FLANGE TO ELBOW CONFIGURATION, RESULTING IN 50% COVERAGE.

Prepared By: Simon Crothers

Date: 5-8-03

Reviewed By: Jerry Newgard

Date: 5-12-03

Sign: *Simon Crothers*

Sign: *Jerry Newgard*

Customer:


Date:

Sign: *Ray E. Hall* 5/13/03

A

FRAMATOME ANP

UT INDICATION PLOT



① 67° COUNTERBORE SEEN THROUGHOUT ELBOW INTRADOS.

Simon Crothers 5-8-03

FIGURE NO.: IWC-2500-7
COMPONENT ID: 2-SI-42-01S
COMPONENT: FLANGE TO ELBOW

A**EXAMINATION SUMMARY****RAMATOME ANP**

Summary No.:325520	Data Package: U2C14-0005	Exam Date: 5/9/2003
Customer: DC COOK U2C14	Examination Methods: UT , PT	
System / Component ID: ECCS (SI) / 2-SI-42-03F	Examination Procedures: 54-ISI-836-04 , 54-ISI-240-40	
Component Description: PIPE TO VALVE	Calibration Sheets No(s): 00012, 00013, 00014	
Examination Category: C-F-1	Examination Results: <input checked="" type="checkbox"/> No Reportable Indications	
ISO / Drawing: B-83	<input type="checkbox"/> Reportable Indications	
	<input checked="" type="checkbox"/> Geometric	

Summary:
 COMPONENT NUMBER 2-SI-42-03F PIPE TO VALVE WAS EXAMINED USING THE UT, AND PT METHODS.

ID ROOT GEOMETRY WAS OBSERVED WITH THE 60 DEGREE TRANSDUCER INTERMITTENT 360 DEGREES.

THE UT EXAM WAS LIMITED TO SINGLE SIDED ACCESS , DUE TO PIPE TO VALVE CONFIGURATION. THE AXIAL UT EXAM WAS OBSTRUCTED BY BRANCH CONNECTION FOR 2" @ 180 DEGREES.
 EXAM COVERAGE =46.5%


CA NO: DC-03-001 REVISION 00 APPLIES TO 54-ISI-836-04

Prepared By: Simon Crothers	Date: 5-9-03	Reviewed By: Jerry Newgard	Date:
Sign: <i>Simon Crothers</i>		Sign: <i>Jerry Newgard</i>	5-12-03
Customer:	Date:		
Sign: <i>Ray E. Noll</i>	5/16/03		Page 1 of 8

A

FRAMATOME ANP

UT INDICATION PLOT



① 58° ROOT GEOMETRY SEEN INTERMITTENT 360°

Simon Crothers 5-9-03

FIGURE NO.: IWC-2500-7
COMPONENT ID: 2-SI-42-03F
COMPONENT: PIPE TO VALVE

A

EXAMINATION SUMMARY

RAMATOME ANP

Summary No.:330010	Data Package: U2C14-0013	Exam Date: 5/16/2003
Customer: DC COOK U2C14	Examination Methods: UT , PT	
System / Component ID: ECCS (SI) / 2-SI-73-02S	Examination Procedures: 54-ISI-836-04 , 54-ISI-240-40	
Component Description: ELBOW TO PIPE	Calibration Sheets No(s): 00032,00033,00034	
Examination Category: C-F-1	Examination Results: <input checked="" type="checkbox"/> No Reportable Indications	
ISO / Drawing:B-89	<input type="checkbox"/> Reportable Indications	
	<input checked="" type="checkbox"/> Geometric	

Summary:

COMPONENT NUMBER 2-SI-73-02S, ELBOW TO PIPE WAS EXAMINED USING THE PT, AND UT METHODS.

ID ROOT GEOMETRY WAS RECORDED WITH THE 70 DEGREE TRANSDUCER.

THE EXAM WAS LIMITED TO SINGLE-SIDED ACCESS, DUE TO ELBOW TO PIPE CONFIGURATION, RESULTING IN 50 % EXAM COVERAGE,

CA NO: DC-03-001 REVISION 00 APPLIES TO 54-ISI-836-04

Prepared By: Simon Crothers	Date: 5-16-03	Reviewed By: Jerry Newgard	Date:
Sign: <i>Simon Crothers</i>		Sign: <i>Jerry Newgard</i>	5-19-03
Customer: <i>Roy E. Hall</i>	Date: 5/20/03	Page 1 of 8	

FRAMATOME ANP

PROFILE AND THICKNESS

Exam Date: 5-16-03

Summary No.: 330010



Site: DC COOK U2C14

Examination Method: UT

System: ECCS(SI)

Identification: 2-SI-73-02S

POSITION	0	90	180	270	
1	N/A	N/A	N/A	N/A	CROWN HEIGHT: <u>0.05"</u>
2	N/A	N/A	N/A	N/A	CROWN WIDTH: <u>0.6"</u>
3	0.57"	N/A	N/A	N/A	NOM DIAMETER: <u>4.0"</u>
4	0.42"	N/A	N/A <td N/A	WELD LENGTH: <u>14.25"</u>	
5	0.42"	N/A	N/A	N/A	



Simon Crothers 5-16-03

Simon Crothers
Prepared By Date

Jerry [Signature] 5-19-03
Reviewed By Date

Ray E. Hall 5/20/03
Utility Review By Date

A**EXAMINATION SUMMARY****RAMATOME ANP**

Summary No.:331000	Data Package: U2C14-0002	Exam Date: 5/6/2003
Customer: DC COOK U2C14	Examination Methods: UT , PT	
System / Component ID: ECCS (SI) / 2-SI-81-01F	Examination Procedures: 54-ISI-836-04 , 54-ISI-240-40	
Component Description: VALVE TO ELBOW	Calibration Sheets No(s): 00005, 00006, 00007	
Examination Category: C-F-1	Examination Results: <input checked="" type="checkbox"/> No Reportable Indications	
ISO / Drawing:B-92	<input type="checkbox"/> Reportable Indications	
	<input checked="" type="checkbox"/> Geometric	

Summary:
 COMPONENT NUMBER 2-SI-81-01F , VALVE TO ELBOW WAS EXAMINED USING THE PT, AND UT METHODS
 ID ROOT GEOMETRY WAS RECORDED WITH THE 60 & 70 DEGREE TRANSDUCERS,
 THE UT EXAM WAS LIMITED TO SINGLE SIDED ACCESS, DUE TO VALVE TO ELBOW CONFIGURATION, RESULTING IN 50% EXAM COVERAGE.
 CA NO: DC-03-001 REVISION OO APPLIES TO 54-ISI-836-04

Prepared By: George G Chapman	Date: 5-6-03	Reviewed By: Jerry Newgard	Date: 5-7-03
Sign: <i>George G Chapman</i>		Sign: <i>Jerry Newgard</i>	
Customer: <i>Ray E. Hall</i>	Date: 5/10/03		



PROFILE AND THICKNESS

Exam Date: 5-6-03

Summary No.: 331000


Site: DC COOK U2C14

Examination Method: UT


System: SAFETY INJECTION

Identification: 2-SI-81-01F

POSITION	0	90	180	270	
1	N/A	N/A	N/A	N/A	CROWN HEIGHT: <u>0.10"</u>
2	N/A	N/A	N/A	N/A	CROWN WIDTH: <u>0.8"</u>
3	N/A	N/A <td N/A	N/A	NOM DIAMETER: <u>4.0"</u>	
4	0.49"	N/A	N/A	N/A	WELD LENGTH: <u>14.5"</u>
5	0.55"	N/A	N/A	N/A	



FLOW →



Simon Crothers 5-6-03
Prepared By Date

Jerry [Signature] L-III 5-7-03
Reviewed By Date

[Signature] E. Hall 5/10/03
Utility Review By Date

ATTACHMENT 10

RELIEF REQUEST ISIR-42

EXAMINATION CATEGORY R-A
RISK INFORMED PIPING EXAMINATIONS

RELIEF REQUEST ISIR-42Relief Request In Accordance with 10 CFR 50.55a(g)(5)(iii)
Inservice Inspection Impracticality1. ASME Code Components Affected

ASME Code Class: Code Class 1 and 2

Examination Category: R-A, Risk Informed Piping Examinations

Item Numbers: R1.11, Elements Subject to Thermal Fatigue
R1.16, Elements Subject to Intergranular or Transgranular Stress Corrosion Cracking (IGSCC or TGSCC)
R1.20, Elements Not Subject to a Degradation Mechanism

Component Identification: Listed in Table 1

2. Applicable Code Edition and Addenda

ASME Section XI, 1989 Edition, No addenda

Austenitic piping welds with single side access subject to ultrasonic examination with Supplement 2 of Appendix VIII to the 1995 Edition with 1996 Addenda of ASME Section XI.

3. Applicable Code Requirement

The examination requirements for Class 1 and 2 piping welds are governed by the Risk Informed Inservice Inspection program that was approved by the NRC in a Safety Evaluation Report dated September 28, 2007 (ADAMS Accession No. ML072620553). This program was developed in accordance with ASME Section XI Code Case N-716, Alternative Piping Classification and Examination Requirements. Table 1, Examination Category R-A, of Code Case N-716 requires 100 percent of the examination location to be examined. The alternative requirements of ASME Section XI, Code Case N-460, approved for use in Regulatory Guide 1.147, Revision 15, allow credit for essentially 100 percent coverage of the weld provided greater than 90 percent of the required volume has been examined. 10 CFR 50.55a(b)(2)(xv)(A), requires the following examination coverage when applying Supplement 2 to Appendix VIII:

(1) Piping must be examined in two axial directions and when examination in the circumferential direction is required, the circumferential examination must be performed in two directions, provided access is available.

(2) Where examination from both sides is not possible, full coverage credit may be claimed from a single side for ferritic welds. Where examination from both sides is not possible on austenitic welds, full coverage credit from a single side may be claimed only

after completing a successful single side Appendix VIII demonstration using flaws on the opposite side of the weld.

10 CFR 50.55a(b)(2)(xvi)(B), requires that examinations performed from one side of a stainless steel pipe weld must be conducted with equipment, procedures, and personnel that have demonstrated proficiency with single side examinations. To demonstrate equivalency to the two sided examinations, the demonstration must be performed to the requirements of Appendix VIII as modified by this paragraph and 10 CFR 50.55a(b)(2)(xv)(A).

4. Impracticality of Compliance

Pursuant to 10 CFR 50.55a(g)(5)(iii), relief is requested from the 100 percent volumetric examination coverage requirement for austenitic piping welds with single side access.

There are currently no Performance Demonstration Initiative (PDI) qualified single side examination procedures that demonstrate equivalency to two-sided examination procedures on austenitic piping welds. Current technology is not capable of reliably detecting or sizing flaws on the far side of an austenitic weld for configurations common to United States nuclear applications.

PDI Performance Demonstration Qualification Summary (PDQS) certificates for austenitic piping list the limitation that single side examination is performed on a best effort basis. The best effort qualification is provided in place of a complete single side qualification to demonstrate that the examiners qualification and the subsequent weld examination is based on application of the best available technology.

When the examination area is limited to one side of an austenitic weld, examination coverage does not comply with 10 CFR 50.55a(b)(2)(xv)(A) and proficiency demonstrations do not comply with 10 CFR 50.55a(b)(2)(xvi)(B) and full coverage credit may not be claimed.

Based on the configuration limited to single side access, relief is requested on complying with the 100 percent required examination coverage for the piping welds listed in Table 1. Note that examination coverage listed is that which was obtained during examination with no credit taken for the far side of each weld when only single-sided access was attainable.

Other welds in Table 1 have physical limitations that prevented full access from both sides of the weld. These limitations include pipe support members, transition areas on elbows, tapers and other geometric interferences. Compliance with code requirements would require extensive modification or replacement of components with a design that allows examination from both sides of the weld.

5. Burden Caused by Compliance

Compliance with code requirements requires extensive modification or replacement of components with a design that allows examination from both sides of the weld.

This option to meet the required 100 percent volume examination coverage is considered impractical based on the cost, additional radiation exposure and impact to plant equipment

6. Proposed Alternative and Basis for Use

The subject welds received a volumetric examination to the maximum extent practical utilizing the best available techniques, as qualified through the Performance Demonstration Initiative (PDI) for Supplement 2 with demonstrated best effort for single sided examination, from the accessible side of the weld. Additionally, a surface examination without limitations was performed on each weld. Further, a visual (VT-2) examination is performed each inspection period during the system leakage tests as required by Section XI, Table IWC-2500-1, Category C-H.

Based upon the examination volumes that were obtained with acceptable results along with the completed surface examination and the visual (VT-2) examination performed each inspection period, it is reasonable to conclude that service induced degradation would be detected if present. Therefore, these proposed alternatives provide an acceptable level of quality and safety by providing reasonable assurance of structural integrity of the subject welds.

7. Period for Which Relief is Requested

The relief is requested for the Third 10-year inspection interval for Donald C. Cook Nuclear Plant Units 1 and 2, which began on July 1, 1996, and ended April 9, 2010, at the conclusion of the Unit 1 Cycle 23 Refueling Outage. Significant long-term outages (greater than six months) occurred multiple times during the interval and the interval was extended as allowed by IWA-2430(e) and by IWA-2430(d) to accommodate interval planning and scheduling.

Table 1

Component ID	Weld Description	Item Number	Ultrasonic Examination Coverage Attained (%)	Remarks
1-CS-96-60F (Class 1)	Elbow to Branch	R1.11	50.0	The completed examination was limited to 50% coverage due to the configuration. The exam limitation was due to the geometry of the branch limiting access from the downstream side. No relevant indications detected.
1-SI-29-19S (Class 1)	Pipe to Tee	R1.16	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration prevents examination on the tee side, downstream, due to the sharp bevel adjacent to the tee side weld toe. No relevant indications detected.
1-SI-29-20S (Class 1)	Elbow to Tee	R1.16	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration prevents examination on the tee side due to the sharp bevel adjacent to the tee side weld toe. No relevant indications detected.
1-SI-29-23S (Class 1)	Tee to Pipe	R1.16	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration prevents examination on the tee side due to the sharp bevel adjacent to the tee side weld toe. No relevant indications detected.
1-SI-31-21S (Class 1)	Elbow to Tee	R1.16	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration prevents examination on the tee side due to the sharp bevel adjacent to the tee side weld toe. No relevant indications detected.
2-SI-57-19 (Class 1)	Pipe to Tee	R1.16	36.8	The completed examination was limited to 36.8% coverage due to the configuration. The configuration prevents examination on the tee side due to the sharp bevel adjacent to the tee side weld toe (single side exam = 50.0%). Additional coverage was missed due to the weld contour (13.2%). No relevant indications detected.

Table 1 (continued)

Component ID	Weld Description	Item Number	Ultrasonic Examination Coverage Attained (%)	Remarks
2-SI-57-21 (Class 1)	Elbow to Tee	R1.16	50.0	The completed examination was limited to 50.0% coverage due to the configuration. The configuration prevents examination on the tee side due to the sharp bevel adjacent to the tee side weld toe (single side exam = 50.0%). No relevant indications detected.
2-SI-56-18 (Class 1)	Elbow to Tee	R1.16	50.0	The completed examination was limited to 50.0% coverage due to the configuration. The configuration prevents examination on the tee side due to the sharp bevel adjacent to the tee side weld toe (single side exam = 50.0%). No relevant indications detected.
1-SI-548-45S (Class 1)	Valve to Pipe	R1.20	50.0	The completed examination was limited to 50% coverage due to the configuration. Full coverage was not obtainable due to the bevel at the weld toe on the valve side of the weld. No relevant indications detected.
1-RH-30-06F (Class 2)	Elbow to Valve	R1.20	50.0	The completed examination was limited to 50% coverage due to the configuration. Full coverage was not obtainable due to the bevel at the weld toe on the valve side of the weld. No relevant indications detected.
1-RC-8-02S (Class 1)	Elbow to Pipe	R1.20	89.7	The completed examination was limited to 89.7% coverage due to the configuration. Full coverage was not obtainable due to the bevel at the weld toe on the valve side of the weld. No relevant indications detected.
1-SI-29-26F (Class 1)	Elbow to Pipe	R1.20	50.0	The completed examination was limited to 50% coverage due to the configuration. Full coverage was not obtainable due to the bevel at the weld toe on the valve side of the weld. No relevant indications detected.

Table 1 (continued)

Component ID	Weld Description	Item Number	Ultrasonic Examination Coverage Attained (%)	Remarks
1-SI-33-26F (Class 1)	Nozzle to Elbow	R1.20	50.0	The completed examination was limited to 50% coverage due to the configuration. Full coverage was not obtainable due to the Nozzle taper at the weld toe. No relevant indications detected.
2-RC-22-24 (Class 1)	Elbow to Valve	R1.20	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration prevents examination from the valve side due to the close proximity of the valve body to the weld. No relevant indications detected.
2-RC-23-12 (Class 1)	Elbow to Valve	R1.20	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration prevents examination from the valve side due to the close proximity of the valve body to the weld. No relevant indications detected.
2-RC-24-09 (Class 1)	Elbow to Valve	R1.20	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration prevents examination from the valve side due to the close proximity of the valve body to the weld. No relevant indications detected.
2-SI-569-49S (Class 1)	Tee to Pipe	R1.20	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration prevents examination from the Socket Welded fitting side. No relevant indications detected.
2-SI-569-53S (Class 1)	Elbow to Pipe	R1.20	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration prevents examination from the Socket Welded fitting side. No relevant indications detected.

Table 1 (continued)

Component ID	Weld Description	Item Number	Ultrasonic Examination Coverage Attained (%)	Remarks
2-SI-569-54S (Class 1)	Elbow to Pipe	R1.20	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration prevents examination from the Socket Welded fitting side. No relevant indications detected.
2-SI-57-22 (Class 1)	Tee to Pipe	R1.16	48.4	The completed examination was limited to 48.4% coverage due to the configuration. The configuration prevents examination on the tee side due to the sharp bevel adjacent to the tee side weld toe (single side exam = 50.0%). Additional coverage was missed due to the weld contour (1.6%). No relevant indications detected.
2-SI-56-10 (Class 1)	Pipe to Elbow	R1.20	66.2	The completed examination was limited to 66.2% coverage due to the configuration. The configuration prevents examination of 100% of the required area due to the presence of a permanent support which limited access. No relevant indications detected.
2-SI-78-01 (Class 1)	Valve to Elbow	R1.20	50.0	The completed examination was limited to 50% coverage due to the configuration. The configuration prevents examination from the valve side due to its severe taper and close proximity of the valve to the weld. No relevant indications detected.
2-SI-56-22 (Class 1)	Elbow to Branch	R1.20	50.0	The completed examination was limited to 50% coverage due to the configuration. The exam limitation was due to the geometry of the branch limiting access from the upstream side. No relevant indications detected.

RELIEF REQUEST ISIR-42

EXAMINATION CATEGORY R-A
RISK INFORMED PIPING EXAMINATIONS

SUPPORTING DOCUMENTATION

Plant: D.C. Cook Unit: 1
 Comp/System: 1-CS-96-60F / CVCS
 ISO #: AEP 1-CS-96
 Summary No.: 129300
 Thermometer S/N or SAP#: 105231

UT No. U1C22-UT-08-025
 Procedure No. WDI-STD-1026, Rev. 0
 Cal Block No. 3378027
 Scan Surface: ID OD
 Block/Comp Temp 84° / 75° F

SEARCH UNIT

Scan Angle: 45° Mode: Shear
 Serial No.: 010XT9 Mfg. KBA
 Fixturing: Non-Integral Model: Comp-G
 Size: 0.25" Shape: Round
 Frequency: 5.0 MHz
 Measured Angle: 45°
 Cable Type: RG-174 Length: 6'
 Couplant Brand: Ultrage II
 Couplant Batch: 07125


Rompas 102268

SCAN AREA	
0° WRV	
0° BM	
⊥ To Weld	X
To Weld	

IDENT	0° or ⊥ TO WELD			TO WELD		
	Sweep Pos	AMPL %	ATTEN dB	Sweep Pos	AMPL %	ATTE N dB
ID Notch	6.0	80	40.3	N/A	N/A	N/A

INSTRUMENT SETTINGS
 Mfg/Model No.: Krautkramer USN 60
 Serial/SAP No.: 102176
 Damping: 1000 Display St: IP
 Mode Select: Dual Off Reject: 0%
 Frequency: 5.0 MHz Rep. Rate: AUTO HIGH
 Energy: High Rectify: Full Wave
 Filter: Fixed Volt: Fixed Jack: "T"
 Range: 1.0" Vel: 0.122
 Swp Delay: 3.648 Zero: 0.000

CAL		
CHECKS	TIME	
Initial Cal.	9:21	
Intermediate	N/A	
Intermediate	N/A	
Intermediate	N/A	
Final Cal.	12:26	



Screen Divisions, 10 = 1.0"

Gain 0° or ⊥	dB	40.3
Gain	dB	N/A

Scan Sensitivity Axial = 61.3
 Circ = N/A

INSTR. LINEARITY CAL.					
	High	Low	High	Low	
1	N/A	N/A	6	N/A	N/A
2			7		
3			8		
4			9		
5			10		

AMPL. CONTROL LINEARITY		
Initial	Δ dB	Result
80	-6	N/A
80	-12	
40	+6	
20	+12	

Horizontal Linearity Performed
 N/A Acceptable

EXAMINATION WELD/AREA	Recordable Indications		Scan Limitation		COMMENTS
	Yes	No	Yes	No	
1-CS-96-60F		X		X	No exam DNST due to component configuration. Examined from weld to weld. <i>50% Coverage Results 4/6/08</i>

Examiner Steve Snyder Level II Date 4/6/2008
 Examiner N/A Level N/A Date N/A

Reviewer Phil Lancaster Level III Date 4/7/2008

Utility Review Edward J. Long Date 4/8/08


Authorized Inspection Agency TRC Date 4-8-2008
Reverend K. Schenck

ADDITIONAL SHEETS? (Check Box)		
Continuation	X	Beam Plot
Supplements		Other

WALL THICKNESS PROFILE SHEET

WELD NO. : 1-CS-96-60F


Position	0°	90°	180°	270°
1	0.44			
2	0.44			
3	0.44			
TOE* CL TOE*	0.50			
5	0.52			
6	0.45			
7	0.44			
8	0.43			
9	0.43			



Crown Height: Flush
 Crown Width: 0.6"
 Longseam: N/A

Diameter: 3.0"
 Weld Length: 11.25"
 Iso Drawing: AEP 1-CS-96

PROFILE AREA



Examiner: *Steven Snyder* Level: II Date: 4/6/2008
 Examiner: N/A Level: N/A Date: N/A
 Reviewer: *Phil Lancaster* Level: III Date: 4/7/2008
 Utility Review: *Edward J. J...* Level: III Date: 4/8/08
 Authorized Inspection Agency: *TRC* Date: 4-8-2008
 "A powerful part of your team" *Rewel K. Schenck*

**ULTRASONIC CALIBRATION
DATA SHEET**

A Westinghouse NDE Company

Int: D.C. Cook Unit: 1 UT No. U1C22-UT-08-021
 Comp/System: 1-SI-29-19S / Safety Injection System Procedure No. ISI-PDI-UT-2, Rev. 4
 ISO #: AEP 1-SI-29 Cal Block No. 102915
 Summary No.: 102400 Scan Surface: ID OD

Thermometer S/N or SAP#: 105231 Block/Comp Temp 82° / 86° F

SEARCH UNIT

Scan Angle: 60° Mode: RL
 Serial No.: 01-049 Mfg. RTD
 Fixturing: Integral Model: TRL2
 Size: 2(8x14) Shape: Rect
 Frequency: 2.0 MHz
 Measured Angle: 60°
 Cable Type: RG-174 Length: 6'
 Couplant Brand: Ultrage II
 Couplant Batch: 07125

Rompas 103774


SCAN AREA	
0° WRV	
0° BM	
⊥ To Weld	X
To Weld	

IDENT	Sweep Pos	AMPL %	ATTEN dB	TO WELD		
				Sweep Pos	AMPL %	ATTE N dB
2.0" Notch	5.0	80	49	N/A	N/A	N/A

INSTRUMENT SETTINGS
 Mfg/Model No.: Krautkramer USN 58 Lsw
 Serial/SAP No.: 104391
 Damping: 500 Puls Wth: 250
 Mode Select: Dual On Reject: 0%
 Frequency: 2.0 MHz Rep. Rate: Auto High
 Pulsar Type: Square Voltage: 450

Connectors 0
 Exit Pnt Dim: = 0.4"
 N/A Contoured

CAL CHECKS	TIME
Initial Cal.	8:45
Intermediate	11:45
Intermediate	12:36
Intermediate	N/A
Final Cal.	16:33



Rectify: Full Wave
 ar: Fixed Jack: "T & R"

Range 8" Vel. 0.224
 Swp Delay 0 Zero 7.153
 Gain 0° or ⊥ 49 dB
 Gain || N/A dB

Scan Sensitivity Axial = 54
 Circ = N/A

INSTR. LINEARITY CAL.					
	High	Low	High	Low	
1	N/A	N/A	6	N/A	N/A
2			7		
3			8		
4			9		
5			10		

AMPL. CONTROL LINEARITY		
Initial	Δ dB	Result
80	-6	N/A
80	-12	
40	+6	
20	+12	

EXAMINATION WELD/AREA	Recordable Indications		Scan Limitation		COMMENTS
	Yes	No	Yes	No	
	1-SI-29-19S		X	X	

Examiner [Signature] Level II Date 4/3/2008
 Print Matt Schmalz

Examiner N/A Level N/A Date N/A
 Print

Reviewer [Signature] Level III Date 4/6/2008
 Phil Lancaster

Utility Review [Signature] Date 4/7/08

Authorized Inspection Agency [Signature] Date 4-8-2008
 Rene K. Schmalz

ADDITIONAL SHEETS? (Check Box)		
Continuation	X	Beam Plot
Supplements		Other


Horizontal Linearity Performed
 N/A Acceptable
 "A powerful part of your team"

WALL THICKNESS PROFILE SHEET

WELD NO. : 1-SI-29-19S

Position	0°	90°	180°	270°
1	N/A			
2	N/A			
3	1.087			
4	1.083			
5	1.000			
6	N/A			
7	N/A			
8	N/A			
9	N/A			


TOE+
CL
TOE*



Crown Height: 0.15"
Crown Width: 0.95"
Longseam: N/A

Pipe Component Diameter: 10.0"
Weld Length: 31.4"
Iso Drawing: AEP 1-SI-29

PROFILE AREA



Examiner: [Signature] Level: II Date: 4/3/2008
 Examiner: N/A Level: N/A Date: N/A
 Reviewer: [Signature] Level: III Date: 4/6/08
 Reviewer: Phil Lancaster Level: III Date: 4/6/2008
 Utility Review: [Signature] Level: III Date: 4/7/08
 Authorized Inspection Agency: [Signature] Date: 4-8-2008
 "A powerful part of your team" Renet K. Schenck

**ULTRASONIC CALIBRATION
DATA SHEET**

A Westinghouse NDE Company

Part: D.C. Cook Unit: 1 UT No. U1C22-UT-08-022
 Comp/System: 1-SI-29-20S / Safety Injection System Procedure No. ISI-PDI-UT-2, Rev. 4
 ISO #: AEP 1-SI-29 Cal Block No. 102915
 Summary No.: 102500 Scan Surface: ID OD
 Thermometer S/N or SAP#: 105231 Block/Comp Temp 82° / 86° F
0° or ⊥ TO WELD **|| TO WELD**

SEARCH UNIT

Scan Angle: 60° Mode: RL
 Serial No.: 01-049 Mfg. RTD
 Fixturing: Integral Model: TRL2
 Size: 2(8x14) Shape: Rect.
 Frequency: 2.0 MHz
 Measured Angle: 60°
 Cable Type: RG-174 Length: 6'
 Couplant Brand: Ultragel II
 Couplant Batch: 07125

Rompas 103774

SCAN AREA	
0° WRV	
0° BM	
⊥ To Weld	<u>X</u>
To Weld	


IDENT	Sweep Pos	AMPL %	ATTEN dB	TO WELD	
				Sweep Pos	AMPL %
2.0° Notch	<u>5.0</u>	<u>80</u>	<u>49</u>	<u>N/A</u>	<u>N/A</u>

Connectors 0
 Exit Pnt Dim: = 0.4"
 N/A Contoured

INSTRUMENT SETTINGS

Mfg/Model No.: Krautkramer USN 58 Lsw
 Serial/SAP No.: 104391
 Damping: 500 Puls Wth: 250
 Mode Select: Dual On Reject: 0%
 Frequency: 2.0 MHz Rep. Rate: Auto High

CAL. CHECKS		TIME
Initial Cal.		<u>8:45</u>
Intermediate		<u>11:45</u>
Intermediate		<u>12:36</u>
Intermediate		<u>N/A</u>
Final Cal.		<u>16:33</u>



0 1 2 3 4 5 6 7 8 9 10
Screen Divisions, 10 = 8.0"

Puls Type: Square Voltage: 450
 Off: Full Wave
 Ref: Fixed Jack: "T & R"
 Range 8" Vel. 0.224
 Swp Delay 0 Zero 7.153
 Gain 0° or ⊥ 49 dB
 Gain || N/A dB
 Scan Sensitivity Axial = 54
 Circ = N/A

EXAMINATION WELD/AREA	Recordable Indications		Scan Limitation		COMMENTS
	Yes	No	Yes	No	
	1-SI-29-20S		<u>X</u>	<u>X</u>	

INSTR. LINEARITY CAL.					
	High	Low	High	Low	
1	<u>N/A</u>	<u>N/A</u>	<u>6</u>	<u>N/A</u>	<u>N/A</u>
2			<u>7</u>		
3			<u>8</u>		
4			<u>9</u>		
5			<u>10</u>		

Examiner [Signature] Level II Date 4/3/2008
 Print Matt Schmalz

Examiner N/A Level N/A Date N/A
 Print

Reviewer [Signature] Level III Date 4/6/2008
 Phil Lancaster

Utility Review [Signature] Date 4/7/08

Authorized Inspection Agency [Signature] Date 4-8-2008
 Renee K. Schencka

AMPL CONTROL LINEARITY		
Initial	Δ dB	Result
<u>80</u>	<u>-6</u>	<u>N/A</u>
<u>80</u>	<u>-12</u>	
<u>40</u>	<u>+6</u>	
<u>20</u>	<u>+12</u>	


ADDITIONAL SHEETS? (Check Box)			
Continuation	<u>X</u>	Beam Plot	
Supplements		Other	

Horizontal Linearity Performed
 N/A Acceptable
 "A powerful part of your team"

WALL THICKNESS PROFILE SHEET

WELD NO. : 1-SI-29-20S


Position	0°	90°	180°	270°
1	N/A			
2	N/A			
3	1.319			
TOE*	4	1.326		
CL	5	1.125		
TOE*	6	N/A		
	7	N/A		
	8	N/A		
	9	N/A		



Crown Height: 0.05"
Crown Width: 1.15"
Longseam: N/A

Diameter: 10.0"
Weld Length: 31.4"
Iso Drawing: AEP 1-SI-29

PROFILE AREA



Examiner: [Signature] Level: II Date: 4/3/2008

Examiner: Matt Schmalz Level: N/A Date: N/A

Reviewer: [Signature] Level: III Date: 4/7/08
Phil Lancaster Level: III Date: 4/6/2008

Utility Review: [Signature] Level: II Date: 4/7/08

Authorized Inspection Agency: [Signature] Date: 4-8-2008
"A powerful part of your team" Renel K. Schenck

**ULTRASONIC CALIBRATION
DATA SHEET**

A Westinghouse NDE Company

Plant: D.C. Cook Unit: 1 UT No. U1C22-UT-08-023
 Comp/System: 1-SI-29-23S / Safety Injection System Procedure No. ISI-PDI-UT-2, Rev. 4
 ISO #: AEP 1-SI-29 Cal Block No. 102915
 Summary No.: 102700 Scan Surface: ID OD

Thermometer S/N or SAP#: 105231

Block/Comp Temp 82° / 86° F

SEARCH UNIT

0° or ⊥ TO WELD

|| TO WELD


Scan Angle: 60° Mode: RL
 Serial No.: 01-049 Mfg. RTD
 Fixturing: Integral Model: TRL2
 Size: 2(8x14) Shape: Rect.
 Frequency: 2.0 MHz
 Measured Angle: 60°
 Cable Type: RG-174 Length: 6'
 Couplant Brand: Ultragel II
 Couplant Batch: 07125

Rompas 103774

SCAN AREA	
0° WRV	
0° BM	
⊥ To Weld	X
To Weld	

IDENT	Sweep Pos	AMPL %	ATTEN dB	Sweep Pos	AMPL %	ATTE N dB
2.0" Notch	5.0	80	49	N/A	N/A	N/A

Connectors 0
 Exit Pnt Dim: = 0.4"
 N/A Contoured



INSTRUMENT SETTINGS
 Mfg/Model No.: Krautkramer USN 58 Lsw
 Serial/SAP No.: 104391
 Damping: 500 Puls With: 250
 Mode Select: Dual On Reject: 0%
 Frequency: 2.0 MHz Rep. Rate: Auto High
 Pulser Type: Square Voltage: 450

CAL CHECKS	TIME
Initial Cal.	8:45
Intermediate	11:45
Intermediate	12:36
Intermediate	N/A
Final Cal.	16:33

Rectify: Full Wave
 Filter: Fixed Jack: "T & R"

Range 8" Vel. 0.224
 Swp Delay 0 Zero 7.153

Gain 0° or ⊥ 49 dB
 Gain || N/A dB

Scan Sensitivity Axial = 54
 Circ = N/A

INSTR. LINEARITY CAL.

	High	Low	High	Low
1	N/A	N/A	6	N/A
2			7	
3			8	
4			9	
5			10	

AMPL. CONTROL LINEARITY

Initial	Δ dB	Result
80	-6	N/A
80	-12	
40	+6	
20	+12	

EXAMINATION WELD/AREA	Recordable Indications		Scan Limitation		COMMENTS
	Yes	No	Yes	No	
	1-SI-29-23S		X	X	

Examiner [Signature] Level II Date 4/3/2008
 Print Matt Schmalz

Examiner N/A Level N/A Date N/A
 Print

Reviewer [Signature] Level III Date 4/6/2008
 Print Phil Lancaster

Utility Review [Signature] Date 4/7/08

Authorized Inspection Agency [Signature] Date 4-8-2008
Reuel K. Schenck

Horizontal Linearity Performed
 N/A **Acceptable**
 "A powerful part of your team"


ADDITIONAL SHEETS? (Check Box)

Continuation	X	Beam Plot	
Supplements		Other	

WALL THICKNESS PROFILE SHEET

WELD NO. : 1-SI-29-23S

Position	0°	90°	180°	270°
1	N/A			
2	N/A			
3	1.080			
TOE*	4	1.078		
C _L	5	1.016		
TOE*	6	N/A		
	7	N/A		
	8	N/A		
	9	N/A		



Crown Height: 0.05"

Diameter: 10.0"


Crown Width: 1.2"

Weld Length: 31.4"

Longseam: N/A

Iso Drawing: AEP 1-SI-29

PROFILE AREA



Examiner: [Signature]

Level: II

Date: 4/3/2008

Examiner: Matt Schmalz

Level: N/A

Date: N/A

Reviewer: [Signature]
Phil Lancaster

Level: III

Date: 4/6/08
4/6/2008

Utility Review: [Signature]

Level: III

Date: 4/7/08

Authorized Inspection Agency: [Signature]

Date: 4-8-2008

"A powerful part of your team"

Reuel K. Schenck

A Westinghouse NDE Company

Part: D.C. Cook Unit: 1 UT No: U1C22-UT-08-028
 Comp/System: 1-SI-31-21S / Safety Injection System Procedure No. ISI-PDI-UT-2, Rev. 4
 ISO #: AEP 1-SI-31 Cal Block No. 102915
 Summary No.: 105300 Scan Surface: ID OD

Thermometer S/N or SAP#: 105231 Block/Comp Temp 82° / 86° F

SEARCH UNIT

Scan Angle: 60° Mode: RL
 Serial No.: 01-049 Mfg. RTD
 Fixturing: Integral Model: TRL2
 Size: 2(8x14) Shape: Rect.
 Frequency: 2.0 MHz
 Measured Angle: 60°
 Cable Type: RG-174 Length: 6'
 Couplant Brand: Ultragel II
 Couplant Batch: 07125

Rompas 103774

SCAN AREA	
0° WRV	
0° BM	
⊥ To Weld	X
To Weld	


IDENT	0° or ⊥ TO WELD			TO WELD		
	Sweep Pos	AMPL %	ATTEN dB	Sweep Pos	AMPL %	ATTE N dB
2.0" Notch	5.0	80	49	N/A	N/A	N/A

Connectors 0
 Exit Pnt Dim: = 0.4"
 N/A Contoured

INSTRUMENT SETTINGS

Mfg/Model No.: Krautkramer USN 58 Lsw
 Serial/SAP No.: 104391
 Damping: 500 Puls Wth: 250
 Mode Select: Dual On Reject: 0%
 Frequency: 2.0 MHz Rep. Rate: Auto High
 Puls Type: Square Voltage: 450
 Filter: Full Wave
 Preset: Fixed Jack: "T & R"
 Range: 8" Vel: 0.224
 Swp Delay: 0 Zero: 7.153
 Gain 0° or ⊥: 49 dB
 Gain ||: N/A dB

CAL CHECKS		TIME
Initial Cal.		8:45
Intermediate		11:45
Intermediate		12:36
Intermediate		N/A
Final Cal.		16:33



0 1 2 3 4 5 6 7 8 9 10
Screen Divisions, 10 = 8.0"

Scan Sensitivity: Axial = 54
 Circ = N/A

INSTR. LINEARITY CAL

	High	Low	High	Low
1	N/A	N/A	6	N/A
2			7	
3			8	
4			9	
5			10	

AMPL. CONTROL LINEARITY

Initial	Δ dB	Result
80	-6	N/A
80	-12	
40	+6	
20	+12	

EXAMINATION WELD/AREA	Recordable Indications		Scan Limitation		COMMENTS
	Yes	No	Yes	No	
	1-SI-31-21S		X	X	

Examiner [Signature] Level II Date 4/3/2008
 Print Matt Schmalz

Examiner N/A Level N/A Date N/A
 Print

Reviewer [Signature] Level III Date 4/7/2008
 Phil Lancaster

Utility Review [Signature] Date 4/7/08

Authorized Inspection Agency [Signature] Date 4-8-2008
 Rexell Schenue

ADDITIONAL SHEETS? (Check Box)		
Continuation	X	Beam Plot
Supplements		Other


Horizontal Linearity Performed
 N/A **Acceptable**
 "A powerful part of your team"

WALL THICKNESS PROFILE SHEET

WELD NO.: 1-SI-31-21S

Position	0°	90°	180°	270°
1	N/A			
2	N/A			
3	N/A			
4	N/A			
5	1.152			
6	1.312			
7	1.308			
8	N/A			
9	N/A			


TOE*
CL
TOE*



Crown Height: 0.05"
Crown Width: 1.10"
Longseam: N/A

Tee Component Elbow Component
Diameter: 10.0"
Weld Length: 31.4"
Iso Drawing: AEP 1-SI-31

PROFILE AREA



Examiner: [Signature] Level: II Date: 4/3/2008
 Examiner: Matt Schmalz Level: N/A Date: N/A
 Reviewer: [Signature] Level: III Date: 4/7/08
 Reviewer: Phil Lancaster Level: III Date: 4/7/2008
 Utility Review: [Signature] Level: III Date: 4/7/08
 Authorized Inspection Agency: [Signature] Date: 4-8-2008
 "A powerful part of your team" Reuel K. Schenck

A Westinghouse NDE Company

Int: D.C. Cook Unit: 2
Comp/System: 2-SI-57-19
ISO #: A-48
Summary No.: 092900

UT No.: U2C18-UT-09-037
Procedure No.: ISI-PDI-UT-2 Rev 4
Cal Block No.: 102917

Thermometer S/N or SAP#: 105547

Scan Surface: ID OD
Block/Comp Temp: 88° F / 68° F

SEARCH UNIT

Scan Angle: 60° RL Mode: Long
Serial No.: 05-483 Mfg. RTD
Fixturing: Integral Model: TRL-2
Size: 2(Bx14) Shape: Rect
Frequency: 2 MHz
Measured Angle: 60°
Cable Type: RG-174 Length: 6'
Couplant Brand: Ultragel II
Couplant Batch: 07125


I/W / Rompas
S/N - Step Wedge: 102268

SCAN AREA
0° WRV
0° BM
⊥ To Weld X
|| To Weld
Connectors 0

IDENT	0° or ⊥ TO WELD			TO WELD		
	Sweep Pos	AMPL %	ATTEN dB	Sweep Pos	AMPL %	ATTE N dB
1.0" notch	4.2	80	47.2			
1.5" notch	6.0	80	47.2			
	N			N	A	
	A					

INSTRUMENT SETTINGS
Mfg/Model No.: GEIT USN 60 SW
Serial/SAP No.: 105420 Display Start = IP
Damping: 500 Pulse Width 250
Pulser Type: Dual Reject: 0%
Frequency: 2 MHz PRF Mode: Auto High
Display Mode (RECTIF): Full Wave

Exit Pnt Dim: = N/A
N/A Contoured
CAL CHECKS TIME
Initial Cal.: 11:00
Intermediate
Intermediate
Final Cal.: 13:30



Filter: Fixed Voltage: 450 Jack: T&R
Range: 5.0 Vel.: .2279
Swp Delay: 7.6509 Zero: 0.00

Gain 0° or ⊥	dB	47.2
Gain	dB	N/A

Scan Sensitivity Axial = 59.0
Circ = N/A

INSTR. LINEARITY CAL.

	High	Low		High	Low
1			6		
2	N		7	N	
3		A	8		A
4			9		
5			10		

AMPL. CONTROL LINEARITY

Initial	Δ dB	Result
80	-6	
80	-12	N
40	+6	A
20	+12	

Horizontal Linearity Performed
N/A Acceptable

"A powerful part of your team"

Screen Divisions, 10 = 5"

EXAMINATION WELD/AREA	Recordable Indications		Scan Limitation		COMMENTS
	Yes	No	Yes	No	
	2-SI-57-19		X	X	

Examiner: Matthew Schmalz Level: II Date: 04/02/2009

Examiner: _____ Level: _____ Date: _____

Reviewer: M. O. Level: III Date: 4/3/09

Utility Review: _____ Date: 4/3/09

Authorized Inspection Agency: Renel K. Scherer Date: 4-4-2009

ADDITIONAL SHEETS? (Check Box)


Continuation		Beam Plot	X
Supplements	X	Other	

Plant/Unit: DC. COOK / UNIT 2

Comp/System: 2-51-57 -

Weld / Component ID Number: 2-51-57-19

Crown Height:	<u>.1</u>
Crown Width:	<u>1.1</u>
Diameter:	<u>10</u>
Weld Length:	<u>31.4</u>



$$\text{No coverage} = \frac{1}{2} (0.4") (0.5") = 0.1 \text{ in}^2$$

$$\text{TOTAL} = (1.9") (0.4") = 0.76 \text{ in}^2$$

$$\text{MISSED COVERAGE (\%)} = \frac{0.1}{0.76} * 100\% = 13.2\%$$

$$\text{SINGLE SIDED EXAM COVERAGE} = 50\%$$

$$\text{TOTAL COVERAGE} = 50 - 13.2 = \underline{\underline{36.8\%}}$$

Comments: SINGLE SIDED EXAM DUE TO Component CONFIGURATION

Examiner: Matt Schmalz Level: II Date: 4-2-09 Examiner: _____ Level: _____ Date: _____
 Reviewer: M.O. Level: III Date: 4/3/09 Utility Reviewer: [Signature] Level: _____ Date: 4/3/09
 Authorized Inspection Agency: TWUS / Revel K. Schenck Date: 4-4-2009

"A powerful part of your team"

A Westinghouse NDE Company

Ant: D.C. Cook Unit: 2
Comp/System: 2-SI-57-21
ISO #: A-48
Summary No.: 093100

UT No. U2C18-UT-09-038
Procedure No. ISI-PDI-UT-2 Rev. 4
Cal Block No. 102917
Scan Surface: ID OD

Thermometer S/N or SAP#: 105547

Block/Comp Temp 88° F / 68° F

SEARCH UNIT

Scan Angle: 60° RL Mode: Long
Serial No.: 05-483 Mfg: RTD
Fixturing: Integral Model: TRL-2
Size: 2(8x14) Shape: Rect
Frequency: 2 MHz
Measured Angle: 60°
Cable Type: RG-174 Length: 6'
Couplant Brand: Ultragel II
Couplant Batch: 07125

I/W / Rompas
S/N - Step Wedge 102268


SCAN AREA
0° WRV
0° BM
⊥ To Weld X
|| To Weld

IDENT	0° or ⊥ TO WELD			TO WELD		
	Sweep Pos	AMPL %	ATTEN dB	Sweep Pos	AMPL %	ATTE N dB
1.0" notch	4.2	80	47.2			
1.5" notch	6.0	80	47.2			
	N			N	A	
	A					

INSTRUMENT SETTINGS

Mfg/Model No.: GEIT USN 60 SW
Serial/SAP No.: 105420 Display Start = IP
Damping: 500 Pulse Width 250
Pulsar Type: Dual Reject: 0%
Frequency: 2 MHz PRF Mode: Auto High
Display Mode (RECTIF): Full Wave

Connectors 0
Exit Pnt Dim: = N/A
CAL. N/A Contoured
CHECKS TIME
Initial Cal. 11:00
Intermediate
Intermediate
Final Cal. 13:30



Screen Divisions; 10 = 5"

Filter: Fixed Voltage: 450 Jack: T&R
ange 5.0 Vel. .2279
Swp Delay 7.6509 Zero 0.00

EXAMINATION WELD/AREA	Recordable Indications		Scan Limitation		COMMENTS
	Yes	No	Yes	No	
2-SI-57-21		X	X		Single sided exam due to configuration of component. Maintained 20% ID roll.

Gain 0° or ⊥	dB	47.2
Gain	dB	N/A

Scan Sensitivity Axial = 59.0
Circ = N/A

INSTR. LINEARITY CAL.

	High	Low		High	Low
1			6		
2	N		7	N	
3		A	8		A
4			9		
5			10		

AMPL. CONTROL LINEARITY

Initial	Δ dB	Result
80	-6	
80	-12	N
40	+6	A
20	+12	

Examiner Matthew Schmalz Level II Date 04/02/2009

Examiner _____ Level _____ Date _____

Reviewer M. O. [Signature] Level III Date 4/3/09

Utility Review [Signature] Date 4/3/09

Authorized Inspection Agency [Signature] Date 4-4-2009

Benet K. Scherck

Horizontal Linearity Performed
N/A Acceptable

ADDITIONAL SHEETS? (Check Box)			
Continuation		Beam Plot	X
Supplements	X	Other	

"A powerful part of your team"



A Westinghouse NDE Company

ULTRASONIC EXAMINATION SUPPLEMENT SHEET

Page 6 of 6


UT No. U2C18-UT-09-038

Plant/Unit: DC COOK / UNIT 2

Comp/System: 2-51-57

Weld / Component ID Number: 2-51-57-21

Crown Height:	.1
Crown Width:	1.1
Diameter:	10"
Weld Length:	31.4



SINGLE SIDED EXAM COVERAGE = 50%.

Comments: SINGLE SIDED EXAM DUE TO COMPONENT CONFIGURATION.

Examiner: MATT SCHMALZ Level: II Date: 4-2-09 Examiner: _____ Level: _____ Date: _____

Reviewer: M.O. Level: III Date: 4/3/09 Utility Reviewer: Paul D. ... Level: _____ Date: 4/3/09

Authorized Inspection Agency: RDCS / Renewal Services Date: 4-4-2009

"A powerful part of your team"



ULTRASONIC CALIBRATION DATA SHEET

A Westinghouse NDE Company

Plant: D.C. Cook Unit: 2
Comp/System: 2-SI-56-18
ISO #: A-47
Summary No.: 089700

UT No.: U2C18-UT-09-062
Procedure No.: ISI-PDI-UT-2 Rev 4
Cal Block No.: 102917
Scan Surface: [] ID [x] OD

Thermometer S/N or SAP#: 105547

Block/Comp Temp: 80 F / 79 F

SEARCH UNIT

Scan Angle: 60 degrees Mode: Long
Serial No.: 05-483 Mfg. RTD
Fixturing: Integral Model: TRL-2
Size: 2(8x14) Shape: Rect
Frequency: 2.0 MHz
Measured Angle: 60 degrees
Cable Type: RG-174 Length: 6'
Couplant Brand: Ultra Gel II
Couplant Batch: 07125


IIV / Rompas S/N - Step Wedge 102268

SCAN AREA table with rows for 0 degree WRV, 0 degree BM, and +/- To Weld.

Table with columns: IDENT, Sweep Pos, AMPL %, ATTE dB, Sweep Pos, AMPL %, ATTE N dB. Includes a diagonal line across the table.

INSTRUMENT SETTINGS
Mfg/Model No.: GEIT USN 60 SW
Serial/SAP No.: 105420 Display Start: IP
Damping: 500 Pulser Width: 250
Mode Select Square Reject Off
Frequency: 2.0 PRF Mode: Auto High
Display Mode (RECTIF): Full Wave

CAL. CHECKS TIME table with rows for Initial Cal, Intermediate, and Final Cal.



Filter: Fixed Voltage: 450 Jack: T&R
Range: 5.9116 Vel: 2245
Swp Delay: 7.5034 Zero: N/A

Gain table with rows for 0 degrees or +/- and Gain II.

Scan Sensitivity Axial = 55 Circ = 59

INSTR. LINEARITY CAL table with columns for High and Low at 1, 2, 3, 4, 5 divisions.

AMPL. CONTROL LINEARITY table with columns for Initial, delta dB, and Result.

Horizontal Linearity Performed N/A Acceptable

"A powerful part of your team"

Screen Divisions, 10 = 5.9116"

EXAMINATION WELD/AREA table with columns for Recordable Indications and Scan Limitation.

Examiner: James Galica Level II Date: 04/03/2009

Examiner: Patrick Langreck Level I Date: 04/03/2009

Reviewer: M.O. Level III Date: 4/7/09

Utility Review: Paul Dominici Date: 4/7/09


Authorized Inspection Agency: Relics Date: 4-7-2009
Renel K. Scherck

ADDITIONAL SHEETS? (Check Box) table with rows for Continuation, Supplements, Beam Plot, and Other.

WALL THICKNESS PROFILE SHEET

WELD NO.: 2-SI-56-18

	Position	0°	90°	180°	270°
	1	1.194			
	2	1.167			
	3	1.138			
TOE*	4	1.150			
CL	5	2.179	N A	N A	N A
TOE*	6	2.268			
	7	2.562			
	8	X			
	9	X			



Crown Height: .02"

Diameter: 2.0"


Crown Width: 1.05"

Weld Length: 34"

Longseam: N/A

Iso Drawing: A-47

PROFILE AREA



SINGLE SIDED COVERAGE 50% Coverage
RL 4/30/09

FLOW →

Examiner: [Signature] Level: II Date: 4/3/09

Examiner: [Signature] Level: I Date: 4/3/09

Reviewer: [Signature] Level: III Date: 4/7/09

Utility Review: [Signature] Level: --- Date: 4/7/09

Authorized Inspection Agency: TRIS D / Renew K Schenck Date: 4-7-2009

"A powerful part of your team"

**ULTRASONIC EXAMINATION
SCAN LIMITATION REPORT**


Weld Number: 2-S1-56-18 Interfering Condition: TEE CONFIGURATION

Size of Interfering Condition: 12"

Distance from Weld Centerline: 2" Distance from Datum Point 0.0: 0"

Reference Drawing Number: _____

Comments and Sketches: (include extent of exam coverage not completed)



50% Coverage Obtained
Pl. 4/30/09

Examiner: [Signature] Level: II Date: 4/3/09

Examiner: [Signature] Level: I Date: 4/3/09

Reviewer: [Signature] Level: III Date: 4/7/09

Utility Review: [Signature] Level: _____ Date: 4/7/09

Authorized Inspection Agency: Revel K.S. D / Revel K. Schenck Date: 4-7-2009
"powerful part of your team"

Plant: D.C. Cook Unit: 1
 Comp/System: 1-SI-548-45S / Safety Injection
 ISO #: AEP 1-SI-548
 Summary No.: 172200
 Thermometer S/N or SAP#: 105231

UT No. U1C22-UT-08-031
 Procedure No. WDI-STD-1026, Rev. 0
 Cal Block No. 1.5-SS-16D-281-1-DCC
 Scan Surface: ID OD
 Block/Comp Temp 80° / 76° F

SEARCH UNIT

Scan Angle: 60° Mode: Shear
 Serial No.: 010XT9 Mfg. KBA
 Fixturing: Non-Integral Model: Comp-G
 Size: 0.25" Shape: Round
 Frequency: 5.0 MHz
 Measured Angle: 60°
 Cable Type: RG-174 Length: 6'
 Couplant Brand: Ultragel II
 Couplant Batch: 07125

Rompas 102268


SCAN AREA	
0° WRV	
0° BM	
⊥ To Weld	X
To Weld	

IDENT	0° or ⊥ TO WELD			TO WELD		
	Sweep Pos	AMPL %	ATTEN dB	Sweep Pos	AMPL %	ATTE N dB
ID Notch	5.6	80	47.2	N/A	N/A	N/A

INSTRUMENT SETTINGS

Mfg/Model No.: Krautkramer USN 60
 Serial/SAP No.: 102176
 Damping: 1000 Display St: IP
 Mode Select: Dual Off Reject: 0%
 Frequency: 5.0 MHz Rep. Rate: AUTO HIGH
 Energy: High Rectify: Full Wave
 Filter: Fixed Volt: Fixed Jack: "I"
 Range: 1.0" Vel: 0.122
 Swp Delay: 4.76 Zero: 0.000

CAL. CHECKS		TIME
Initial Cal.		14:52
Intermediate		N/A
Intermediate		N/A
Intermediate		N/A
Final Cal.		15:59



Screen Divisions, 10 = 1.0"

Gain 0° or ⊥	dB	61.6
Gain	dB	N/A

Scan Sensitivity Axial = 67.6
 Chro = N/A

INSTR. LINEARITY CAL.					
	High	Low	High	Low	
1	N/A	N/A	6	N/A	N/A
2			7		
3			8		
4			9		
5			10		

AMPL. CONTROL LINEARITY		
Initial	Δ dB	Result
80	-6	N/A
80	-12	
40	+6	
20	+12	

Horizontal Linearity Performed
 Acceptable

EXAMINATION WELD/AREA	Recordable Indications		Scan Limitation		COMMENTS
	Yes	No	Yes	No	
1-SI-548-45S		X	X		Single sided exam due to check valve. NRI
					50% COVERAGE RET 4/6/2011

Examiner Steven Snyder Level II Date 4/6/2008

Examiner N/A Level N/A Date N/A

Reviewer Phil Lancaster Level III Date 4/8/2008

Utility Review Edward Jones Date 4/8/08


Authorized Inspection Agency RELIC Date 4-8-2008
Reuel K. Schenck

ADDITIONAL SHEETS? (Check Box)		
Continuation	X	Beam Plot
Supplements		Other

WALL THICKNESS PROFILE SHEET

WELD NO. : 1-SI-548-45S


Position	0°	90°	180°	270°
1	N/A			
2	N/A			
3	N/A			
TOE*	4	N/A		
C _L	5	N/A		
TOE*	6	0.28		
	7	0.28		
	8	0.28		
	9	0.28		



Crown Height: Flush
 Crown Width: 0.6"
 Longseam: N/A

Valve Component Diameter: 1.5"
 Weld Length: 6.5"
 Iso Drawing: AEP 1-SI-548

PROFILE AREA



Examiner: Steven Snyder Level: II Date: 4/6/2008

Examiner: N/A Level: N/A Date: N/A

Reviewer: Phil Lancaster Level: III Date: 4/8/2008

Utility Review: Edward J. Jones Level: III Date: 4/8/08

Authorized Inspection Agency: TRICS Date: 4-8-2008
 "A powerful part of your team" Reuel K. Schenck

Plant: Cook Nuclear Plant Unit: 1 Procedure No.: ISI-PDI-UT-2 Rev.: 4
 FCN # N/A
 Comp/ System: Emergency Core Cooling Cal. Blk. # SAP 105255 Ref. Blk. # SAP 102272 "T" Nom. 0.812" Nom. Pipe Ø 8.0"
 Isometric Dwg # 1-RH-30, Rev. 13 Thermometer S/N: SAP 105378 Block / Comp Temp: 69 °F / 81 °F

SEARCH UNIT
 Scan Angle: 60° RL Mode: Long.
 Serial No.: 08-376 Mfr. RTD
 Fixturing: Non-Integral Model: TRLA
 Size: 2(7x10) Shape: Rect.
 Frequency: 2.0 MHz # Elem: 2
 Measured Angle: 60° Exit Pnt. 0.3
 Couplant Type/Batch #: UltraGel II / 07125
 Cable / Length / # Conn: RG-174 / 16' / 10

Examination Surface OD ID
 Material Type CS SS Other

INSTRUMENT SETTINGS
 Mfr/Model No. GE / KrautKramer USN 60 SW
 Serial No.: SAP 104389
 Pulsar: Square Dual On Dual Off Puls Wth: 250
 Damping: 500 Reject: 0%
 Freq: 2.0 MHz Rectify: Full Wave
 PRF: Auto High Volt: 450 Jack: T&R
 Range: 2.5000 Velocity: 0.2340
 Probe Delay: 8.2400 Dsp Delay: 0.0000

Contoured Wedge N/A Ax Circ

0 1 2 3 4 5 6 7 8 9 10
 Screen Divisions, 10 = 2.5"

SCAN AREA

0° WRV	<input type="checkbox"/>
0° BM	<input type="checkbox"/>
⊥ To Weld	<input checked="" type="checkbox"/>
∥ To Weld	<input type="checkbox"/>

CAL CHECKS	TIME
Initial Cal.	0720
Intermediate	1250
Intermediate	N/A
Intermediate	N/A
Final Cal.	1625

DAC			
Reflector ID	% FSH	Swp Pos	dB
1.0" Notch Tip	80	7.6	64.0
Rompas FSDH	80	6.0	55.0

	Cal	Scan	
Gain 0° or ⊥	64.0	68.0	dB
Gain ∥	N/A	N/A	dB

EXAMINATION WELD/AREA

1-RH-30-06F

Recordable Indications YES NO
 Scan Limitations YES NO

Remarks: Scanned elbow side (UPST) only, due to valve configuration.

Examiner: Wade Holasek Lv. III Date: 3/5/2010
 Print: Wade Holasek
 Examiner: Jordan Taylor Lv. IT Date: 3/5/2010
 Print: Jordan Taylor

Code Coverage Achieved 50 %

Risk Informed YES NO C'Bore Y N
 Exam is Acceptable YES NO

Reviewer: Michael McKie Lv. III Date: 3/6/10

Reviewer: Renell K. Schenck Date: 3/8/10

Authorized Inspection Agency

Renell K. Schenck 3-9-2010



ESDYNE
NATIONAL

ULTRASONIC EXAMINATION SKETCH SHEET

Data Pkg. #: UIC23-UT-10-L

A Westinghouse NDE Company

Page 4 of 4


Plant/Unit : Cook Nuclear Plant / 1 Comp / System : Emergency Core Cooling
Iso. Drwg: 1-RH-30, Rev. 13

ATTACHED TO: N/A
UT Sheet No. N/A


Weld / Component ID Number: 1-RH-30-06F

Crown Height: Ground Smooth
Crown Width: 1.500"
Diameter: 8.625"
Weld Length: 27.600"

Position	0	90	180	270
1	0.914"			
2	0.918"			
3	0.930"			
4	0.937"			
5	0.801"			
6	0.810"			
7	N/A			
8	N/A			
9	N/A			



Not to scale



COMMENTS:

EXAMINER: Wade Holasek Lv. III DATE: 3/5/2010
Print Wade Holasek

EXAMINER: Jordan Taylor Lv. IT DATE: 3/5/2010
Print Jordan Taylor

REVIEWER: Michael McKie Lv. III DATE: 3/6/10

REVIEWER: Ruff E. Neel Lv. N/A DATE: 3/8/10

Authorized Inspection Agency: TRISA Renewl K. Schenck DATE: 3-10-2010

"A powerful part of your team"

Plant: Cook Nuclear Plant Unit: 1 Procedure No.: ISI-PDI-UT-2 Rev.: 4

Comp/ System: Reactor Coolant Cal. Blk. # SAP 105256 Ref. Blk.# SAP 102268 FCN # N/A "T" Nom. 0.718" Nom. Pipe Ø 6.0"

Isometric Dwg # I-RC-8 Thermometer S/N: SAP 105547 Block / Comp Temp: 98 °F / 103 °F


SEARCH UNIT

Scan Angle: 60° Mode: Shear
Serial No.: 00X1R9 Mfr. KBA
Fixturing: Non-Integral Model: Comp-G
Size: 0.25" Shape: Round
Frequency: 2.25 MHz # Elem: 1
Measured Angle: 58° Exit Pnt. 0.25
Couplant Type/Batch #: UltraGel II / 07125

Examination Surface OD ID
Material Type CS SS Other

INSTRUMENT SETTINGS

Mfr/Model No. GE / KrautKramer USN 58 L
Serial No.: SAP 104765
Pulser: Square Dual On Dual Off Puls Wth: 220
Damping: 500 Reject: 0%
Freq: 2.25 MHz Rectify: Full Wave
PRF: Auto High Volt: 450 Jack: T



Range: 3.0000 Velocity: 0.1220
Swp Delay: 2.5000 Zero: 0.0000

Cable / Length / # Conn: RG-174 / 6' / 10

Contoured Wedge N/A Ax Circ

Screen Divisions, 10 = 3.0"

	Cal	Scan	
Gain 0° or ⊥	54.0	60.0	dB
Gain	N/A	N/A	dB

SCAN AREA

0° WRV	<input type="checkbox"/>
0° BM	<input type="checkbox"/>
⊥ To Weld	<input checked="" type="checkbox"/>
To Weld	<input type="checkbox"/>

CAL CHECKS	TIME
Initial Cal.	1030
Intermediate	N/A
Intermediate	1250
Intermediate	N/A
Final Cal.	1500

DAC

Reflector ID	% FSH	Swp Pos	dB
1.0" Notch Tip	80	6.0	54.0
FSDH Rompas	80	4.8	59.0

EXAMINATION WELD/AREA

1-RC-8-02S

Recordable Indications YES NO
Scan Limitations YES NO

Remarks: Limited scan on pipe side due to proximity of weld I-RC-8-03S.

Examiner: Patrick Mahoney Lv. II Date: 3/7/2010
Print: Patrick Mahoney
Examiner: Jordan Taylor Lv. IT Date: 3/7/2010
Print: Jordan Taylor

Code Coverage Achieved 89.7 %

Risk Informed YES NO C'Bore Y N
Exam is Acceptable YES NO

Reviewer: Michael M. King Lv. III Date: 3/10/10 Reviewer: Renel K. Schenk Date: 3/11/10

Authorized Inspection Agency RTISO Renel K. Schenk 3-11-2010

**ESDYNE**
NATIONAL**ULTRASONIC EXAMINATION SKETCH SHEET**

Data Pkg. #: U1C23-UT-10

A Westinghouse NDE Company


Page 3 of 3

Plant/Unit: Cook Nuclear Plant / 1
Iso. Drwg: 1-RC-8
Comp./System: Reactor CoolantATTACHED TO: N/A
UT Sheet No. N/A

Weld / Component ID Number: 1-RC-8-02S

Crown Height: $\leq 0.100''$
Crown Width: $1.100''$
Diameter: $6.625''$
Weld Length: $21.250''$

Position	0	90	180	290
1	0.75"			
2	0.75"			
3	0.75"			
4	0.75"			
5	0.86"			
6	0.82"			
7	0.82"			
8	N/A			
9	N/A			



Not to Scale


Pipe Side Limitation
 $(.27 \times 1.05) = 0.28''$ (Total Exam Volume)
 $.27 \times .30 = .081''$
 $+ (.27 \times .25) \div 2 = .034''$
 $= 0.115''$ (Missed Volume)
 $.115'' / .28'' = .41''$ or 41%

US Ax - 100%

DS Ax - 59%

US Circ - 100%

DS Circ - 100%

 $359 / 4 = 89.7\%$ Coverage

COMMENTS: N/A

EXAMINER: Patrick Mahoney Lv. II DATE 3/7/2010

EXAMINER: Jordan Taylor Lv. IT DATE: 3/7/2010

REVIEWER: Michael McKeig Lv. III DATE 3/10/10


REVIEWER: Re Hall Lv. N/A DATE: 3/11/10

Authorized Inspection Agency RPKS Renee K. Schrock DATE 3-11-2010

"A powerful part of your team"

Plant: Cook Nuclear Plant Unit: 1 Procedure No.: ISI-PDI-UT-2 Rev.: 4
 FCN # N/A
 Comp/ System: Safety Injection Cal. Blk. # SAP 105256 Ref. Blk.# SAP 102268 "T" Nom. 1.312" Nom. Pipe Ø 10.0"
 Isometric Dwg # 1-SI-29 Thermometer S/N: SAP 105547 Block / Comp Temp: 72 °F / 85 °F

SEARCH UNIT
 Scan Angle: 60° RL Mode: Long.
 Serial No.: 08-374 Mfr. RTD
 Fixturing: Integral Model: TRL-2
 Size: 2(7x10) Shape: Rect.
 Frequency: 2.0 MHz # Elem: 2
 Measured Angle: 60° Exit Pnt. 0.3
 Couplant Type/Batch #: UltraGel II / 07125
 Cable / Length / # Conn: RG-174 / 6' / 10



INSTRUMENT SETTINGS
 Mfr/Model No. GE / KrautKramer USN 60 SW
 Serial No.: SAP 105420
 Pulsers: Square Dual On Dual Off Puls Wth: 250
 Damping: 500 Reject: 0%
 Freq: 2.0 MHz Rectify: Full Wave
 PRF: Auto High Volt: 450 Jack: T & R
 Range: 5.0000 Velocity: 2.8800
 Swp Delay: 7.2438 Zero: 0.0000

Contoured Wedge N/A Ax Circ

0 1 2 3 4 5 6 7 8 9 10
 Screen Divisions, 10 = 5.0"

	Cal	Scan	
Gain 0° or ⊥	60.0	62.6	dB
Gain	N/A	N/A	dB

SCAN AREA

0° WRV	<input type="checkbox"/>
0° BM	<input type="checkbox"/>
⊥ To Weld	<input checked="" type="checkbox"/>
To Weld	<input type="checkbox"/>

CAL CHECKS	TIME
Initial Cal.	0825
Intermediate	N/A
Intermediate	1115
Intermediate	N/A
Final Cal.	1228

DAC

Reflector ID	% FSH	Swp Pos	dB
1.5" Notch	80	5.2	60.0
FSDH Rompas	40	3.0	49.0

EXAMINATION WELD/AREA
1-SI-29-26F
 Recordable Indications YES NO
 Scan Limitations YES NO

Remarks: Scanned elbow (UPST) side only due to nozzle.
Scanned 0.5" beyond counterbore.
Observed counterbore below recordable levels.

Examiner: [Signature] Lv. II Date: 3/9/2010
 Print: Matt Schmalz
 Examiner: [Signature] Lv. IT Date: 3/9/2010
 Print: David Frye

Code Coverage Achieved 50 %
 Risk Informed YES NO C'Bore Y N
 Exam is Acceptable YES NO

Reviewer: [Signature] Lv. III Date: 3/11/10 Reviewer: [Signature] Date: 3/12/10
 Authorized Inspection Agency TUHSI Reuel K. Schenck 3-12-2010



ESDYNE
NATIONAL

ULTRASONIC EXAMINATION SKETCH SHEET

Data Pkg. #: U1C23-UT-10-C

A Westinghouse NDE Company

Page 4 of 4


Plant/Unit: Cook Nuclear Plant / 1
Iso. Drwg: 1-SI-29
Comp / System: Safety Injection

ATTACHED TO: N/A
UT Sheet No. N/A


Weld / Component ID Number: 1-SI-29-26F

Crown Height:	0.100"
Crown Width:	1.250"
Diameter:	10.750"
Weld Length:	31.400"

Position	0	90	180	290
1	N/A			
2	1.480"			
3	1.155"			
4	1.156"			
5	1.006"			
6	N/A			
7	N/A			
8	N/A			
9	N/A			



Not to Scale



COMMENTS: N/A

EXAMINER: Matt Schmalz Lv. II DATE 3/9/2010

EXAMINER: David Frye Lv. IT DATE: 3/9/2010

REVIEWER: Michael McKeig Lv. III DATE 3/11/10

REVIEWER: RE Hall Lv. N/A DATE: 3/12/10

Authorized Inspection Agency RPK S&P Renewal Services DATE 3-12-2010

"A powerful part of your team"

Plant: Cook Nuclear Plant Unit: 1 Procedure No.: ISI-PDI-UT-2 Rev.: 4
 Comp/ System: Safety Injection Cal. Blk. # SAP 105255 Ref. Blk.# SAP 102268 "T" Nom. 1.312" Nom. Pipe Ø 10.0"
 Isometric Dwg # 1-SI-33 Thermometer S/N: SAP 105547 Block / Comp Temp: 72 °F / 86 °F

SEARCH UNIT
 Scan Angle: 60° RL Mode: Long.
 Serial No.: 08-374 Mfr. RTD
 Fixturing: Integral Model: TRL2
 Size: 2(7x10) Shape: Rect.
 Frequency: 2.0 MHz # Elem: 1
 Measured Angle: 60° Exit Pnt. 0.3
 Couplant Type/Batch #: UltraGel II / 07125
 Cable / Length / # Conn: RG-174 / 6' / 10

Examination Surface OD ID
 Material Type CS SS Other

100%										
90										
80		Rompas	*		*	Notch				
70										
60										
50										
40										
30										
20										
10										
0										

INSTRUMENT SETTINGS
 Mfr/Model No. GE / KrautKramer USN 58 L
 Serial No.: SAP 104766
 Pulsar: Square Dual On Dual Off Puls Wth: 250
 Damping: 500 Reject: 0%
 Freq: 2.0 MHz Rectify: Full Wave
 PRF: Auto High Volt: 450 Jack: T&R
 Range: 5.0000 Velocity: 0.2230
 Swp Delay: 6.0000 Zero: 0.0000

Contoured Wedge N/A Ax Circ

0 1 2 3 4 5 6 7 8 9 10
 Screen Divisions, 10 = 5.0"

		Cal	Scan	
Gain 0° or ⊥		59.0	65.0	dB
Gain		N/A	N/A	dB

SCAN AREA

0° WRV	<input type="checkbox"/>
0° BM	<input type="checkbox"/>
⊥ To Weld	<input checked="" type="checkbox"/>
To Weld	<input type="checkbox"/>

CAL CHECKS	TIME
Initial Cal.	0745
Intermediate	N/A
Intermediate	1010
Intermediate	N/A
Final Cal.	1100

DAC

Reflector ID	% FSH	Swp Pos	dB
1.5" Notch Tip	80	5.5	59.0
FSDH Rompas	80	3.2	53.0

EXAMINATION WELD/AREA

1-SI-33-26F

Recordable Indications YES NO
 Scan Limitations YES NO

Remarks: Single sided exam due to nozzle to elbow configuration.

Scanned elbow (DNST) side only.

Code Coverage Achieved 50 %

Risk Informed YES NO C'Bore Y N

Exam is Acceptable YES NO

Examiner Patrick Mahoney Lv. II Date: 3/12/2010
 Examiner Jordan Taylor Lv. IT Date: 3/12/2010

Reviewer: Michael McKeig LV III Date: 3/13/10

Reviewer: Renel K. Schenck Date: 3/17/10

Authorized Inspection Agency

TRPUS
Renel K. Schenck
3-17-2010



ESDYNE
NATIONAL

ULTRASONIC EXAMINATION SKETCH SHEET

Data Pkg. #: UIC23-UT-10-6

A Westinghouse NDE Company

Page 4 of 4


Plant/Unit : Cook Nuclear Plant / 1 Comp / System Safety Injection
Iso. Drwg: 1-SI-33

ATTACHED TO: N/A
UT Sheet No. N/A


Weld / Component ID Number: 1-SI-33-26F

Crown Height:	<u>≤0.100"</u>
Crown Width:	<u>1.250"</u>
Diameter:	<u>10.750"</u>
Weld Length:	<u>34.500"</u>

Position	0	90	180	290
1	N/A			
2	N/A			
3	N/A			
4	N/A			
5	1.08"			
6	1.03"			
7	1.11"			
8	1.15"			
9	1.17"			



Not to Scale



COMMENTS: Exam was a single sided exam with 50% coverage achieved. A 45° shear and 60° shear as well as a 60°RL were used for this exam.

EXAMINER: Patrick Mahoney Lv. II DATE 3/12/2010

EXAMINER: Jordan Taylor Lv. IT DATE: 3/12/2010

REVIEWER: Michael M. King Lv. III DATE 3/13/10

REVIEWER: Renel K. Schenck Lv. N/A DATE: 3/17/10

Authorized Inspection Agency IRPS DATE 3-17-2010

"A powerful part of your team" Renel K. Schenck



UT Calibration Examination

Site/Unit: AEP / 2
 Summary No.: 027420
 Workscope: ISI

Procedure: ISI-PDI-UT-2
 Procedure Rev.: 4
 Work Order No.: 55246120

Outage No.: U2-C17
 Report No.: UT-07-052
 Page: 1 of 3

Code: ASME XI 1989 Cat./Item: R-AR1.20 Location: PRESS. DH
 Drawing No.: A-20 Description: ELBOW TO VALVE
 System ID: PRZ
 Component ID: 2-RC-22-24 Size/Length: 3"/11" Thickness/Diameter: 0.45"/3"
 Limitations: None TS 92307 50% coverage due to component configuration Start Time: 1115 Finish Time: 1330

Instrument Settings
 Serial No.: 102342
 Manufacturer: KBA
 Model: USN-50
 Delay: 4.125 µsec Range: 1.4"
 MTI Cal/Vel: .123/µsec Pulsar: High
 Damping: Fixed Reject: 0%
 Rep. Rate: Fixed Freq.: Fixed
 Filter: Fixed Mode: Fullwave
 Voltage: Fixed Other: Jack: R
 Ax. Gain (dB): 22.5 Circ. Gain (dB): 22.5
10 Screen Div. = 1.25 In. of Depth
 Linearity Report No.: L-07-003

Search Unit
 Serial No.: 00X1R9
 Manufacturer: KBA
 Size: 0.25" Shape: ROUND
 Freq.: 2.25 Mhz Style: COMP-G
 Exam Angle: 45° # of Elements: 1
 Mode: Shear
 Measured Angle: 44°
 Wedge Style: Non-Integral
Search Unit Cable
 Type: RG174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	1115	8/28/2007
Inter. Cal.		
Inter. Cal.		
Inter. Cal.		
Final Cal.	1330	8/28/2007

Couplant
 Cal. Batch: 05225
 Type: Ultragel II
 Mfg.: Sonotech
 Exam Batch: 05226
 Type: Ultragel II
 Mfg.: Sonotech

Reference Block
 Serial No.: N/A
 Type: N/A

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Depth
0.5" Notch	80%	4.0	0.5"
1.0" Notch	80%	8.0	1.0"

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Depth
N/A	N/A	N/A	N/A

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Depth
N/A	N/A	N/A	N/A	N/A

Calibration Block
 Cal. Block No.: 105256
 Thickness: 0.5" - 2.0" Dia.: 0
 Cal. Blk. Temp.: 76° Temp. Tool: 105543
 Comp. Temp.: 78° Temp. Tool: 105543

Scan Coverage
 Upstream Downstream Scan dB: 34.5
 CW CCW Scan dB: 34.5
 Exam Surface: OD
 Surface Condition: FLUSH

Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: N/A

Comments: No recordable indications, ID Geometry observed at less than recordable levels and verified visually i.e. root. See USN-52L Table for transducer selection.

Examiner	Level	III-PDI	Signature	Date	8/28/2007	Reviewer	Signature	Date	9/24/07
Lancaster, Phillip L.			<i>Phillip Lancaster</i>			Feige, Edward J.	<i>Edward J. Feige</i>		
Examiner	Level	N/A	Signature	Date		Site Review	Signature	Date	9/24/07
N/A						Donavin, Paul	<i>Paul Donavin</i>		
Other	Level	III-PDI	Signature	Date	9/25/07	ANII Review	Signature	Date	9/25/07
Siever, Theodore J.			<i>Theodore J. Siever</i>			Charles Jackson	<i>Charles Jackson</i>		



Supplemental Report

Report No.: UT-07-052

Page: 2 of 3

Summary No.: 027420


Examiner: Lancaster, Phillip L. PL Level: III-PDI Reviewer: Feige, Edward J. EJS Date: 9/25/07

Examiner: N/A Level: N/A Site Review: Donavin, Paul PDD Date: 9/25/07

Other: Siever, Theodore J. TS Level: III-PDI ANII Review: Charles Jackson CM Date: 9/25/07

Comments: T&C for Component 2-RC-22-24
50% coverage obtained due to geometric configuration (elbow to valve).

Sketch or Photo: C:\Documents and Settings\S208165\My Documents\My Scans\2007-09 (Sep)\2-RC T&C 3.jpg





UT Calibration Examination

Site/Unit: AEP / 2
 Summary No.: 027420
 Workscope: ISI

Procedure: ISI-PDI-UT-2
 Procedure Rev.: 4
 Work Order No.: 65248120

Outage No.: U2-C17
 Report No.: UT-07-085
 Page: 1 of 1

Code: ASME XI 1989 Cat./Item: R-A/R1.20 Location: PRESS. DH
 Drawing No.: A-20 Description: ELBOW TO VALVE
 System ID: PRZ
 Component ID: 2-RC-22-24 Size/Length: 3"/11" Thickness/Diameter: 0.45"/3"
 Limitations: One sided examination due to geometric configuration elbow to valve. Start Time: 1400 Finish Time: 1630

Instrument Settings
 Serial No.: 102342
 Manufacturer: KBA
 Model: USN-50
 Delay: 18.3 µsec Range: 1.62"
 M'tl Cal/Vel: 0.123/µsec Pulsar: High
 Damping: Fixed Reject: 0%
 Rep. Rate: Fixed Freq.: Fixed
 Filter: Fixed Mode: Fullwave
 Voltage: Fixed Other: N/A
 Ax. Gain (dB): 46.5 Circ. Gain (dB): N/A
10 Screen Div. = 1 in. of Depth
 Linearity Report No.: L-07-003

Search Unit
 Serial No.: 010R01
 Manufacturer: KBA
 Size: 0.25" Shape: ROUND
 Freq.: 2.26 Mhz Style: Comp-G
 Exam Angle: 70° # of Elements: 1
 Mode: Shear
 Measured Angle: 68°
 Wedge Style: Non-Integral
Search Unit Cable
 Type: RG174
 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	1400	8/28/2007
Inter. Cal.		
Inter. Cal.		
Inter. Cal.		
Final Cal.	1630	8/28/2007

Couplant
 Cal. Batch: 05225
 Type: Ultrage II
 Mfg.: Sonotech
 Exam Batch: 05225
 Type: Ultrage II
 Mfg.: Sonotech

Reference Block
 Serial No.: N/A
 Type: N/A

Axial Orientated Search Unit				
Calibration Reflector	Signal Amplitude %	Sweep Division	Depth	
0.5" Notch	80%	5.0	0.5"	
1.0" Notch	60%	10.0	1.0"	
Circumferential Orientated Search Unit				
Calibration Reflector	Signal Amplitude %	Sweep Division	Depth	
N/A	N/A	N/A	N/A	
Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Depth
N/A	N/A	N/A	N/A	N/A

Calibration Block
 Cal. Block No.: 106258
 Thickness: 0.5" - 2.0" Dia.: 0
 Cal. Blk. Temp.: 76° Temp. Tool: 105543
 Comp. Temp.: 78° Temp. Tool: 105543
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Scan Coverage
 Upstream Downstream Scan dB: 52.5
 CW CCW Scan dB: N/A
 Exam Surface: OD
 Surface Condition: FLUSH

Results: Accept Reject Info

Comments: One-sided exam. No recordable indications. See USN-52L Table for transducer selection.

Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: N/A

Examiner Level III-PDI <u>Lancaster, Philip L.</u>	Signature <i>Philip Lancaster</i>	Date <u>8/28/2007</u>	Reviewer <u>Federico J. J...</u>	Signature <i>Federico J. J...</i>	Date <u>9/24/07</u>
Examiner Level N/A <u>N/A</u>	Signature	Date	Site Review <u>Paul D...</u>	Signature <i>Paul D...</i>	Date <u>9/24/07</u>
Other Level III-PDI <u>Siever, Theodore J.</u>	Signature <i>Ed Siever</i>	Date <u>9-29-07</u>	ANII Review <u>Charles Jackson</u>	Signature <i>Charles Jackson</i>	Date <u>9/28/07</u>



Supplemental Report

Report No.: UT-07-052


Page: 3 of 3

Summary No.: 027420

Examiner: <u>Lancaster, Philip L. <i>PL</i></u>	Level: <u>III-PDI</u>	Reviewer: <u>Feige, Edward J. <i>EJF</i></u>	Date: <u>9/25/07</u>
Examiner: <u>N/A</u>	Level: <u>N/A</u>	Site Review: <u>Donavin, Paul <i>PD</i></u>	Date: <u>9/25/07</u>
Other: <u>Siever, Theodore J. <i>TJ</i></u>	Level: <u>III-PDI</u>	ANII Review: <u>Charles Jackson <i>CJ</i></u>	Date: <u>9/25/07</u>

Comments: **Typical spool piece.
Component ID 2-RC-22-24**

Sketch or Photo: C:\Documents and Settings\S206165\My Documents\DSCN0162.JPG





UT Calibration/Examination

Site/Unit: AEP / 2
 Summary No.: 028220
 Workscope: ISI

Procedure: ISI-PDI-UT-2
 Procedure Rev.: 4
 Work Order No.: 55246120

Outage No.: CC-17
 Report No.: UT-07-059
 Page: 1 of 3

Code: ASME XI 1989 Cat./Item: R-AR1.20 Location: PRESS DH
 Drawing No.: A-21 Description: ELBOW TO VALVE
 System ID: RC
 Component ID: 2-RC-23-12 Size/Length: 3"/11" Thickness/Diameter: 0.46"/3"
 Limitations: One sided examination due to geometric configuration elbow to valve. 50% coverage per 9/6/07 Start Time: 1115 Finish Time: 1330

Instrument Settings
 Serial No.: 102342 Manufacturer: KBA Model: USN-50
 Delay: 4.125 μsec Range: 1.4" MTI Cal/Vel: .123/μsec Pulser: High
 Damping: Fixed Reject: 0% Rep. Rate: Fixed Freq.: Fixed
 Filter: Fixed Mode: Fullwave Voltage: Fixed Other: Jack: R
 Ax. Gain (dB): 22.5 Circ. Gain (dB): 22.5
10 Screen Div. = 1.25 in. of Depth
 Linearity Report No.: L-07-003

Search Unit
 Serial No.: 00X1R9 Manufacturer: KBA Size: 0.25" Shape: ROUND
 Freq.: 2.25 Mhz Style: COMP-G Exam Angle: 45° # of Elements: 1
 Mode: Shear Measured Angle: 44° Wedge Style: Non-Integral
 Search Unit Cable Type: RG174 Length: 6' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	1115	8/28/2007
Inter. Cal.		
Inter. Cal.		
Inter. Cal.		
Final Cal.	1330	8/28/2007

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Depth
0.5" Notch	80%	4.0	0.5"
1.0" Notch	80%	8.0	1.0"

Couplant
 Cal. Batch: 06226
 Type: Ultrage II
 Mfg.: Sonotech
 Exam Batch: 06226
 Type: Ultrage II
 Mfg.: Sonotech

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Depth
N/A	N/A	N/A	N/A

Calibration Block
 Cal. Block No.: 105256 Thickness: 0.5" - 2.0" Dia.: 0
 Cal. Blk. Temp.: 76° Temp. Tool: 105543 Comp. Temp.: 78° Temp. Tool: 105543
 Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)

Scan Coverage
 Upstream Downstream Scan dB: 34.5
 CW CCW Scan dB: 34.5
 Exam Surface: OD Surface Condition: FLUSH

Reference Block
 Serial No.: N/A
 Type: N/A

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Depth
N/A	N/A	N/A	N/A	N/A

Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: N/A

Comments: One-sided exam. No recordable indications. ID Geometry observed at less than recordable levels and verified visually i.e. root. See USN-52L Table for transducer

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Lancaster, Philip L.	III-PDI	<i>Philip Lancaster</i>	8/28/2007	Feige, Edward J.	<i>Edward J. Feige</i>	9/27/07
N/A	N/A			Site Review	<i>Paul Donavin</i>	9/27/07
Other	III-PDI	<i>Theodore J. Siever</i>	9/26/2007	ANII Review	<i>Charles Jackson</i>	9/19/07



Supplemental Report

Report No.: UT-07-059


Page: 3 of 3

Summary No.: 028220

Examiner: <u>Lancaster, Philip L. <i>PL</i></u>	Level: <u>III-PDI</u>	Reviewer: <u>Feige, Edward J. <i>EJ</i></u>	Date: <u>9/27/07</u>
Examiner: <u>N/A</u>	Level: <u>N/A</u>	Site Review: <u>Donavin, Paul <i>PD</i></u>	Date: <u>9/27/07</u>
Other: <u>Siever, Theodore J. <i>TJ</i></u>	Level: <u>III-PDI</u>	ANII Review: <u>Jackson, Charles <i>C</i></u>	Date: <u>9/27/07</u>

Comments: Typical spool piece.
Component ID 2-RC-23-12

Sketch or Photo: C:\Documents and Settings\S206165\My Documents\My Scans\2007-09 (Sep)\DSCN0162.JPG





UT Calibration/Examination

Site/Unit: AEP / 2
 Summary No.: 028620
 Workscope: ISI

Procedure: ISI-PDI-UT-2
 Procedure Rev.: 4
 Work Order No.: 55246120

Outage No.: Uz-C17
 Report No.: UT-07-088
 Page: 1 of 3

Code: ASME XI 1989 Cat./Item: R-AR1.20 Location: PRESS. DH

Drawing No.: A-22 Description: ELBOW TO VALVE

System ID: RC

Component ID: 2-RC-24-09 Size/Length: 3"11" Thickness/Diameter: 0.46"13"

Limitations: One sided examination due to geometric configuration elbow to valve. 50% COVERAGE PER 4/6/2011 Start Time: 1115 Finish Time: 1330

Instrument Settings
 Serial No.: 102342
 Manufacturer: KBA
 Model: USN-50
 Delay: 4.125 psec Range: 1.4"
 M/TI Cal/Vel: .123/psec Pulsar: High
 Damping: Fixed Reject: 0%
 Rep. Rate: Fixed Freq.: Fixed
 Filler: Fixed Mode: Fullwave
 Voltage: Fixed Other: Jack: R
 Ax. Gain (dB): 22.5 Circ. Gain (dB): 22.5
10 Screen Div. = 1.28 in. of Depth
 Linearity Report No.: L-07-003

Search Unit
 Serial No.: 00X1R9
 Manufacturer: KBA
 Size: 0.25" Shape: ROUND
 Freq.: 2.25 Mhz Style: COMP-G
 Exam Angle: 45° # of Elements: 1
 Mode: Shear
 Measured Angle: 44°
 Wedge Style: Non-Integral
 Search Unit Cable
 Type: RG174
 Length: 8' No. Conn.: 0

Cal. Checks	Time	Date
Initial Cal.	1115	8/28/2007
Inter. Cal.		
Inter. Cal.		
Inter. Cal.		
Final Cal.	1330	8/28/2007

Couplant
 Cal. Batch: 06225
 Type: Ultragel II
 Mfg.: Sonotech
 Exam Batch: 06225
 Type: Ultragel II
 Mfg.: Sonotech

Reference Block
 Serial No.: N/A
 Type: N/A

Axial Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Depth
0.5" Notch	80%	4.0	0.5"
1.0" Notch	80%	8.0	1.0"

Circumferential Orientated Search Unit			
Calibration Reflector	Signal Amplitude %	Sweep Division	Depth
N/A	N/A	N/A	N/A

Reference/Simulator Block				
Gain dB	Reflector	Signal Amplitude %	Sweep Division	Depth
N/A	N/A	N/A	N/A	N/A

Calibration Block
 Cal. Block No.: 106256
 Thickness: 0.5" - 2.0" Dia.: 0
 Cal. Blk. Temp.: 76° Temp. Tool: 105543
 Comp. Temp.: 78° Temp. Tool: 106543
 Exam Surface: OD
 Surface Condition: FLUSH

Scan Coverage
 Upstream Downstream Scan dB: 34.5
 CW CCW Scan dB: 34.5

Recordable Indication(s): Yes No (If Yes, Ref. Attached Ultrasonic Indication Report.)
 Results: Accept Reject Info
 Percent Of Coverage Obtained > 90%: No Reviewed Previous Data: N/A

Comments: One-sided exam. No recordable indications. ID Geometry observed at less than recordable levels and verified visually i.e. root. See USN-52L Table for transducer

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Lancaster, Phillip L.	III-PDI	<i>Phillip Lancaster</i>	8/28/2007	Felge, Edward J.	<i>Edward J. Felge</i>	9/27/07
N/A	N/A			Site Review Donavin, Paul	<i>Paul Donavin</i>	9/27/07
Siever, Theodore J.	III-PDI	<i>Theodore Siever</i>	9-26-07	ANII Review Jackson, Charles	<i>Charles Jackson</i>	9/29/07



Supplemental Report

Report No.: UT-07-066

Page: 3 of 3

Summary No.: 028620

Examiner: Lancaster, Philip L. *PL* Level: III-PDI

Reviewer: Feige, Edward J. *EF*

Date: 9/27/07

Examiner: N/A Level: N/A

Site Review: Donavin, Paul *PD*

Date: 9/27/07


Other: Siever, Theodore J. *TJ* Level: III-PDI

ANII Review: Jackson, Charles *CJ*

Date: 9/27/07

Comments: **Typical spool piece.**
Component ID 2-RC-24-09

Sketch or Photo: C:\Documents and Settings\S206165\My Documents\My Scans\2007-09 (Sep)\DSCN0162.JPG



A Westinghouse NDE Company

Ant: D.C. Cook Unit: 2
Comp/System: 2-SI-569-49S
ISO #: A-68
Summary No.: 122665

UT No. U2C18-UT-09-021
Procedure No. WDI-STD-1026 REV 0
Cal Block No. 1.5-SS-160-281-1-DCC
Scan Surface: ID OD
Block/Comp Temp 74.5° F / 74° F

SEARCH UNIT

Scan Angle: 45° Mode: Shear
Serial No.: 00YHTP Mfg: KBA
Fixturing: Non-Integral Model: Comp-G
Size: .25" Shape: Rnd
Frequency: 2.25 MHz
Measured Angle: Ax 45° Circ 40°
Cable Type: RG-174 Length: 6'
Couplant Brand: Ultra Gel II
Couplant Batch: 04225


IIV / Rompas
S/N - Step Wedge N/A

SCAN AREA
0° WRV
0° BM
⊥ To Weld X
|| To Weld X
Connectors 0

IDENT	0° or ⊥ TO WELD			TO WELD		
	Sweep Pos	AMPL %	ATTEN dB	Sweep Pos	AMPL %	ATTE N dB
ID notch	4.2	80	30	4.9	80	4.0
	N			N		
	A			A		

INSTRUMENT SETTINGS
Mfg/Model No.: Krautkramer USN 50
Serial/SAP No.: 102342
Damping: Fixed Puls.Wth: Fixed
Pulser: High Reject: 0%
Frequency: Fixed Rep. Rate: Fixed
Display Mode (RECTIF): Full Wave

CAL CHECKS		TIME
Initial Cal.		08:30
Intermediate		10:00
Intermediate		
Intermediate		
Final Cal.		11:25



Filter: Fixed Voltage: Fixed Jack: T
Range 1.0" Vel. 1220
Swp Delay 3.039 Zero 6.30

Gain 0° or ⊥	dB	30
Gain	dB	40

Scan Sensitivity Axial = 42.5dB
Circ = 55 dB

INSTR. LINEARITY CAL.					
	High	Low		High	Low
1			6		
2	N		7	N	
3		A	8		A
4			9		
5			10		

AMPL. CONTROL LINEARITY			
Initial	Δ dB	Result	
80	-6	A	
80	-12		
40	+6		
20	+12		

Horizontal Linearity Performed
N/A Acceptable

"A powerful part of your team"

Screen Divisions 10 = 1.0"

EXAMINATION WELD/AREA	Recordable Indications		Scan Limitation		COMMENTS
	Yes	No	Yes	No	
2-SI-569-49S		X	X		Scan limitation due to support. Scanned 3"
					DS to support.
					Maintained 20% ID roll.
					50% Coverage Obtained fl. 4/30/09

Examiner Matthew Schmalz Level II Date 03/31/09

Examiner _____ Level _____ Date _____

Reviewer M.O. Level III Date 4/1/09

Utility Review Paul Donavari Date 4/1/09

Authorized Inspection Agency TRU Date 4-1-2009

René K. Schenck

ADDITIONAL SHEETS? (Check Box)			
Continuation		Beam Plot	
Supplements	X	Other	

**ULTRASONIC EXAMINATION
SCAN LIMITATION REPORT**

Weld Number: 2-S1-58-495 ^{569 REPAIR ball} Interfering Condition: I BEAM SUPPORT


Size of Interfering Condition: 4"

Distance from Weld Centerline: N/A Distance from Datum Point 0.0: N/A

Reference Drawing Number: A-68

Comments and Sketches: (include extent of exam coverage not completed)

50% Coverage Obtained
Pl. 4/30/09



SUPPORT

Examiner: ~~_____~~ Level: I Date: 03-31-09
MATT SCHWALZ

Examiner: _____ Level: _____ Date: _____

Reviewer: M.O. Level: III Date: 4/1/09

Utility Review: Paul Bonanni Level: _____ Date: 4/1/09

Authorized Inspection Agency: TRACIS / Reuel K. Schenck Date: 4-1-2009
"A successful part of your team"

A Westinghouse NDE Company

Plant: D.C. Cook Unit: 2
Comp/System: 2-SI-569-53S
ISO #: A-68
Summary No.: 122685

UT No. U2C18-UT-09-025
Procedure No. WDI-STD-1026 REV 0
Cal Block No. 1.5-SS-160-281-1-DCC
Scan Surface: ID OD

Thermometer S/N or SAP#: 105547

Block/Comp Temp 74.5° F / 74° F

SEARCH UNIT

Scan Angle: 45° Mode: Shear
Serial No.: 00YHTP Mfg. KBA
Fixturing: Non-integral Model: Comp-G
Size: .25" Shape: Rnd
Frequency: 2.25 MHz
Measured Angle: Ax 45° Circ 40°
Cable Type: RG-174 Length: 6'
Couplant Brand: Ultra Gel II
Couplant Batch: 04225

IIV / Rompas
S/N - Step Wedge N/A

SCAN AREA
0° WRV
0° BM
⊥ To Weld X
|| To Weld X
Connectors 0


IDENT	0° or ⊥ TO WELD			TO WELD		
	Sweep Pos	AMPL %	ATTEN dB	Sweep Pos	AMPL %	ATTE N dB
ID notch	4.2	80	30	4.9	80	4.0
	N			N		
	A			A		

INSTRUMENT SETTINGS

Mfg/Model No.: Krautkramer USN 50
Serial/SAP No.: 102342
Damping: Fixed Puls Wth: Fixed
Pulser: High Reject: 0%
Frequency: Fixed Rep. Rate: Fixed
Display Mode (RECTIF): Full Wave

Exit Pnt Dim: = N/A
 Contoured

CAL. CHECKS	TIME
Initial Cal.	08:30
Intermediate	10:00
Intermediate	
Intermediate	
Final Cal.	11:25



Screen Divisions 10 = 1.0"

Filter: Fixed Voltage: Fixed Jack: T
Range 1.0" Vel. 1220
Swp Delay 3.039 Zero 6.30

Gain 0° or ⊥	dB 30
Gain	dB 40

Scan Sensitivity Axial = 42.5dB
Circ = 55 dB

INSTR. LINEARITY CAL.

	High	Low	High	Low
1			6	
2	N		7	N
3		A	8	A
4			9	
5			10	

AMPL. CONTROL LINEARITY

Initial	Δ dB	Result
80	-6	
80	-12	N
40	+6	A
20	+12	

Horizontal Linearity Performed
N/A Acceptable

EXAMINATION WELD/AREA	Recordable Indications		Scan Limitation		COMMENTS
	Yes	No	Yes	No	
	2-SI-569-53S		X	X	

50% Coverage Obtained
A.L. 4/30/09

Examiner Matthew Schmalz Level II Date 03/31/09

Examiner _____ Level _____ Date _____

Reviewer M.O. Level III Date 4/1/09

Utility Review Paul D... Date 4/1/09

Authorized Inspection Agency Travel & Schenck Date 4-1-09

ADDITIONAL SHEETS? (Check Box)

Continuation		Beam Plot	X
Supplements	X	Other	

"A powerful part of your team"

**ULTRASONIC EXAMINATION
SCAN LIMITATION REPORT**


Weld Number: 2-S1-58-53S Interfering Condition: WELD FROM ADJACENT JOINT

Size of Interfering Condition: 1" - 360°

Distance from Weld Centerline: N/A Distance from Datum Point 0.0: N/A

Reference Drawing Number: A-68

Comments and Sketches: (include extent of exam coverage not completed)



50% Coverage Obtained
Pl. 4/20/09

Examiner: *[Signature]* Level: II Date: 03-31-09
MATT SCHMALZ

Examiner: _____ Level: _____ Date: _____

Reviewer: *[Signature]* Level: III Date: 4/1/09
M.O.

Utility Review: *[Signature]* Level: _____ Date: 4/1/09
Paul Donovin

Authorized Inspection Agency: *[Signature]* Date: 4-1-2009
Renel K. Schell
"A powerful part of your team"

A Westinghouse NDE Company

Ant: D.C. Cook Unit: 2
Comp/System: 2-SI-569-54S
ISO #: A-88
Summary No.: 122887

UT No. U2C18-UT-09-026
Procedure No.: WDI-STD-1026 REV 0
Cal Block No.: 1.5-SS-160-281-1-DCC
Scan Surface: ID OD

Thermometer S/N or SAP#: 105547

Block/Comp Temp 74.5° F / 74° F

SEARCH UNIT


Scan Angle: 45° Mode: Shear
Serial No.: 00YHTP Mfg: KBA
Fixturing: Non-Integral Model: Comp-G
Size: .25" Shape: Rnd
Frequency: 2.25 MHz
Measured Angle: Ax 45° Circ 40°
Cable Type: RG-174 Length: 6'
Couplant Brand: Ultra Gel II
Couplant Batch: 04225

IWV / Rompas
S/N - Step Wedge N/A
SCAN AREA
0° WRV
⊥ To Weld
|| To Weld
Connectors 0
Exit Pnt Dim: N/A
 Contoured

IDENT	0° or ± TO WELD			TO WELD		
	Sweep Pos	AMPL %	ATTEN dB	Sweep Pos	AMPL %	ATTE N dB
ID notch	4.2	80	30	4.9	80	4.0
	N			N		
	A			A		

INSTRUMENT SETTINGS
Mfg/Model No.: Krautkramer USN 50
Serial/SAP No.: 102342
Damping: Fixed Puls Wth: Fixed
Pulser: High Reject: 0%
Frequency: Fixed Rep. Rate: Fixed
Display Mode (RECTIF): Full Wave
Filter: Fixed Voltage: Fixed Jack: T
Range: 1.0" Vel: .1220
Swp Delay: 3.039 Zero: 6.30

CAL CHECKS	TIME
Initial Cal.	08:30
Intermediate	10:00
Intermediate	
Intermediate	
Final Cal.	11:25



Screen Divisions 10 = 1.0"

Gain 0° or ⊥ dB 30
Gain || dB 40
Scan Sensitivity Axial = 42.5dB
Circ = 55 dB

INSTR. LINEARITY CAL.

	High	Low		High	Low
1	/		6	/	
2	N		7	N	
3		A	8		A
4	/		9	/	
5	/		10	/	

AMPL. CONTROL LINEARITY

Initial	Δ dB	Result
80	-6	/
80	-12	N
40	+6	A
20	+12	/

EXAMINATION WELD/AREA	Recordable Indications		Scan Limitation		COMMENTS
	Yes	No	Yes	No	
	2-SI-569-54S		X	X	

Examiner [Signature] Level II Date 03/31/09
Print Matthew Schmalz

Examiner _____ Level _____ Date _____
Print _____

Reviewer [Signature] Level III Date 4/1/09

Utility Review [Signature] Date 4/1/09

Authorized Inspection Agency [Signature] Date 4-1-2009
Renek K. Schenck

Horizontal Linearity Performed
N/A Acceptable

ADDITIONAL SHEETS? (Check Box)

Continuation		Beam Plot	
Supplements	X	Other	

"A powerful part of your team"



Manufacturing Skills Company

UT Sheet No. U2018-UT-09-026

Page 2 of 2

**ULTRASONIC EXAMINATION
SCAN LIMITATION REPORT**

REX
59-4172011

Weld Number: L-SI-58-545 Interfering Condition: WELD FROM ADJACENT JOINT


Size of Interfering Condition: 1" - 360°

Distance from Weld Centerline: N/A Distance from Datum Point 0.0: N/A

Reference Drawing Number: A-68

Comments and Sketches: (include extent of exam coverage not completed)

56% Coverage Obtained
PL. 4/20/09



Examiner: [Signature] Level: II Date: 03-31-09
MATT SCHMALZ

Examiner: _____ Level: _____ Date: _____

Reviewer: M.O. Level: III Date: 4/1/09

Utility Review: Paul Dominici Level: _____ Date: 4/1/09

Authorized Inspection Agency: R.H.S. D. / Reuel K. Schreck Date: 4-1-2009

"Part of your team"

A Westinghouse NDE Company

Int: D.C. Cook Unit: 2
Comp/System: 2-SI-57-22
ISO #: A-48
Summary No.: 093200

UT No. U2C18-UT-09-039
Procedure No. ISI-PDI-UT-2 Rev 4
Cal Block No. 102917
Scan Surface: ID OD
Block/Comp Temp 88° F / 68° F

Thermometer S/N or SAP#: 105547

SEARCH UNIT

Scan Angle: 60° RL Mode: Long
Serial No.: D5-483 Mfg: RTD
Fixturing: Integral Model: TRL-2
Size: 2(8x14) Shape: Rect
Frequency: 2 MHz
Measured Angle: 60°
Cable Type: RG-174 Length: 6'
Couplant Brand: Ultragel II
Couplant Batch: 07125


I/W / Rompas
S/N - Step Wedge 102268

SCAN AREA	
0° WRV	
0° BM	
⊥ To Weld	X
To Weld	

IDENT	0° or ⊥ TO WELD			TO WELD		
	Sweep Pos	AMPL %	ATTEN dB	Sweep Pos	AMPL %	ATTE N dB
1.0" notch	4.2	80	47.2			
1.5" notch	6.0	80	47.2			
	N			N	A	
	A					

INSTRUMENT SETTINGS
Mfg/Model No.: GEIT USN 60 SW
Serial/SAP No.: 105420 Display Start = IP
Damping: 500 Pulse Width 250
Pulser Type: Dual Reject: 0%
Frequency: 2 MHz PRF Mode: Auto High
Display Mode (RECTIFY): Full Wave

CAL. CHECKS		TIME
Initial Cal.		11:00
Intermediate		
Intermediate		
Final Cal.		13:30



Filter: Fixed Voltage: 450 Jack: T&R
Range: 5.0 Vel.: 2279
Swp Delay: 7.6509 Zero: 0.00

Gain 0° or ⊥	dB	47.2
Gain	dB	N/A

Scan Sensitivity Axial = 59.0
Circ = N/A

INSTR. LINEARITY CAL.

	High	Low	High	Low
1			6	
2	N		7	N
3		A	8	A
4			9	
5			10	

AMPL. CONTROL LINEARITY

Initial	Δ dB	Result
80	-6	
80	-12	N
40	+6	A
20	+12	

Horizontal Linearity Performed
N/A Acceptable

"A powerful part of your team"

Screen Divisions, 10 = 5"

EXAMINATION WELD/AREA	Recordable Indications		Scan Limitation		COMMENTS
	Yes	No	Yes	No	
2-SI-57-22		X	X		Single sided exam due to configuration of component. Maintained 20% ID roll.

Examiner [Signature] Level II Date 04/02/2009
Print Matthew Schmalz

Examiner _____ Level _____ Date _____
Print _____

Reviewer M.O. [Signature] Level III Date 4/3/09

Utility Review [Signature] Date 4/3/09

Authorized Inspection Agency [Signature] Date 4-4-2009

Renel H. Schmalz

ADDITIONAL SHEETS? (Check Box)


Continuation		Beam Plot	X
Supplements	X	Other	

Plant/Unit: DC COOK / Unit 2

Comp/System: 2-SI-57

Weld / Component ID Number: 2-SI-57-22

Crown Height:	.1"
Crown Width:	1.1"
Diameter:	10"
Weld Length:	31.4"



No COVERAGE = $\frac{1}{2}(0.22)(0.13) = 0.014 \text{ in}^2$

TOTAL = 0.876 in^2

MISSED COVERAGE = $\frac{0.014}{0.876} \times 100\% = 1.6\%$

SINGLE SIDED EXAMS COVERAGE = 50%

TOTAL COVERAGE = $50 - 1.6 = \underline{48.4\%}$

Comments: SINGLE SIDED EXAM DUE TO Component CONFIGURATION

Examiner: MATT SCHMAZ Level: II Date: 4-2-09 Examiner: _____ Level: _____ Date: _____

Reviewer: M.O. Level: III Date: 4/3/09 Utility Reviewer: [Signature] Level: _____ Date: 4/3/09

Authorized Inspection Agency: TRUS O / Revelle Schenck Date: 4-4-2009

"A powerful part of your team"



A Westinghouse NDE Company

ULTRASONIC EXAMINATION SUPPLEMENT SHEET

Page 7 of 7

UT No. U2C18-UT-09-639

Plant/Unit: DC COOK / UNIT 2

Comp/System: 2-SI-57

Weld / Component ID Number: 2-SI-57-22

Crown Height:

Crown Width:

Diameter:

Weld Length:

/
N/A
/
/

$$\text{AREA 1} = \left(\frac{0.15 + 0.14}{2} \right) \times 0.42 = 0.189 \text{ in}^2$$

$$\text{AREA 2} = (0.67)(0.38) = 0.254 \text{ in}^2$$

$$\text{AREA 3} = (1.03)(0.42) = 0.433 \text{ in}^2$$

$$\text{TOTAL} = 0.876 \text{ in}^2$$

Comments:

Examiner: N/A Level: N/A Date: N/A Examiner: N/A Level: N/A Date: N/A

Reviewer: M. Q. Level: III Date: 4/3/09 Utility Reviewer: Paul Dora Level: --- Date: 4/3/09

Authorized Inspection Agency: R. P. S. D. / Renee K. Scherell Date: 4-4-2009

"erful part of your team"

A Westinghouse NDE Company

Int: D.C. Cook Unit: 2
 Comp/System: 2-SI-56-10
 ISO #: A-47
 Summary No.: 088900

UT No. U2C18-UT-09-044
 Procedure No. ISI-PDI-UT-2 Rev 4
 Cal Block No. 102917
 Scan Surface: ID OD
 Block/Comp Temp: 80° F / 79° F

SEARCH UNIT


Scan Angle: 60° Mode: Long
 Serial No.: 05-483 Mfg.: RTD
 Fixturing: Integral Model: TRL-2
 Size: 2(8x14) Shape: Rect
 Frequency: 2.0 MHz
 Measured Angle: 60°
 Cable Type: RG-174 Length: 6'
 Couplant Brand: Ultra Gel II
 Couplant Batch: 07125

Thermometer S/N or SAP#: 105547
 IIV / Rompas.
 S/N - Step Wedge 102268
SCAN AREA
 0° WRV
 0° BM
 ⊥ To Weld: X
 || To Weld
 Connectors 0
 Exit Pnt Dim: = N/A
 N/A Contoured

IDENT	0° or ⊥ TO WELD			TO WELD		
	Sweep Pos	AMPL %	ATTEN dB	Sweep Pos	AMPL %	ATTE N dB
1.5" notch	5	80	45			
					N	
				N		A
				A		

INSTRUMENT SETTINGS
 Mfg/Model No.: GEIT USN 60 SW
 Serial/SAP No.: 105420 Display Start: IP
 Damping: 500 Pulsar Width: 250
 Mode Select: Square Reject: Off
 Frequency: 2.0 PRF Mode: Auto High
 Display Mode (RECTIF): Full Wave

CAL. CHECKS	TIME
Initial Cal.	12:50
Intermediate	
Intermediate	
Intermediate	
Final Cal.	15:37



Filter: Fixed Voltage: 450 Jack: T&R
 ange 5.9116 Vel. .2245
 Swp Delay 7.5034 Zero N/A

Gain 0° or ⊥	dB	45
Gain	dB	N/A

Scan Sensitivity Axial = 55
 Circ = 59

INSTR. LINEARITY CAL.

	High	Low		High	Low
1			6		
2	N		7	N	
3		A	8		A
4			9		
5			10		

AMPL. CONTROL LINEARITY

Initial	Δ dB	Result
80	-6	
80	-12	N
40	+6	A
20	+12	

Horizontal Linearity Performed
 N/A Acceptable

"A powerful part of your team"

Screen Divisions, 10 = 5.9116"

EXAMINATION WELD/AREA	Recordable Indications		Scan Limitation		COMMENTS
	Yes	No	Yes	No	
	2-SI-56-10		X	X	

Examiner [Signature] Level II Date 04/04/2009
 Print James Gatica

Examiner [Signature] Level I Date 04/04/2009
 Print Patrick Langrock

Reviewer [Signature] Level III Date 4/6/09

Utility Review [Signature] Date 4/6/09

Authorized Inspection Agency [Signature] Date 4-6-2009
Revel K. Schach

ADDITIONAL SHEETS? (Check Box)

Continuation		Beam Plot	X
Supplements	X	Other	

Attachment to :
UT Sheet No. 42018-UT-09-044

Page 6 of 7

ULTRASONIC EXAMINATION
SCAN LIMITATION REPORT

Weld Number: 2-S1-56-10 Interfering Condition: BOX RESTRAINT / SUPPORT


Size of Interfering Condition: 23" TOTAL

Distance from Weld Centerline: -.6" Distance from Datum Point 0.0: 0"

Reference Drawing Number: A-47

Comments and Sketches: (include extent of exam coverage not completed)

Able to ACHIEVE COVERAGE ON
UPSTREAM SIDE 2"-6.5" 12"-13"
21"-22"; 27.5-32" in "L"



EXAMINER <u>[Signature]</u>	LEVEL <u>II</u>	DATE <u>4/4/09</u>
EXAMINER <u>[Signature]</u>	LEVEL <u>I</u>	DATE <u>4/4/09</u>
REVIEWER <u>M.O.</u>	LEVEL <u>III</u>	DATE <u>4/6/09</u>
Client REVIEW: <u>[Signature]</u>	LEVEL <u>---</u>	DATE <u>4/6/09</u>
Authorized Inspection Agency <u>Re. DCS. D / Reuel K. Schenk</u>		DATE <u>4-6-2009</u>



A Westinghouse NDE Company

ULTRASONIC EXAMINATION SUPPLEMENT SHEET

Page 7 of 7

UT No. UZC18-UT-09-044

Plant/Unit: DC COOK UNIT 2

Comp/System: 2-SI-56

Weld / Component ID Number: 10

Crown Height:	<u>0.07"</u>
Crown Width:	<u>1.1"</u>
Diameter:	<u>10" nom</u>
Weld Length:	<u>34"</u>

TOTAL WELD LENGTH = $34" \times 2 \text{ SIDES} = 68"$.

TOTAL UNSCANNED LENGTH = $23"$ ON ONE SIDE.

TOTAL COVERAGE % = $\frac{68-23}{68} \times 100\% = 66.2\%$

Comments:

Examiner: N/A Level: N/A Date: N/A Examiner: N/A Level: N/A Date: N/A

Reviewer: M.O. Level: III Date: 4/6/09 Utility Reviewer: Rae M. Azami Level: --- Date: 4/6/09

Authorized Inspection Agency: RLS P / Renee K. Schall Date: 4-6-2009

"vertical part of your team"

A Westinghouse NDE Company

Plant: D.C. Cook Unit: 2
Comp/System: 2-SI-78-01
ISO #: A-47
Summary No.: 090100

UT No. U2C18-UT-09-048
Procedure No. ISI-PDI-UT-2 Rev 4
Cal Block No. 102917
Scan Surface: ID OD

Thermometer S/N or SAP#: 105547

Block/Comp Temp 80 ° F / 79 ° F

SEARCH UNIT


Scan Angle: 60 ° Mode: Long
Serial No.: 05-483 Mfg: RTD
Fixturing: Integral Model: TRL-2
Size: 2(8x14) Shape: Rect
Frequency: 2.0 MHz
Measured Angle: 60 °
Cable Type: RG-174 Length: 6' Connectors: 0
Couplant Brand: Ultra Gel II Exit Pnt Dim: = N/A
Couplant Batch: 07125 N/A Contoured

IIV / Rompas
S/N - Step Wedge 102268
SCAN AREA
0° WRV
0° BM
⊥ To Weld X
|| To Weld

IDENT	Sweep Pos	AMPL %	ATTEN dB	TO WELD		
				Sweep Pos	AMPL %	ATTE N dB
1.0" notch	5	80	50			
					N	A
				N		
				A		

INSTRUMENT SETTINGS
Mfg/Model No.: GEIT USN 60 SW
Serial/SAP No.: 105420 Display Start: IP
Damping: 500 Pulser Width: 250
Mode Select Square Reject: Off
Frequency: 2.0 PRF Mode: Auto High
Display Mode (RECTIF): Full Wave

CAL CHECKS	TIME
Initial Cal.	11:55
Intermediate	
Intermediate	
Intermediate	
Final Cal.	15:45



Filter: Fixed Voltage: 450 Jack: T&R
Range 3.9610 Vel. .2245
Swp Delay 7.5034 Zero N/A

Gain 0° or ⊥	dB	50
Gain	dB	N/A

Scan Sensitivity Axial = 56
Circ = N/A

INSTR. LINEARITY CAL.

	High	Low		High	Low
1			6		
2	N		7	N	
3		A	8		A
4			9		
5			10		

AMPL CONTROL LINEARITY

Initial	Δ dB	Result
80	-8	
80	-12	N
40	+8	A
20	+12	

Horizontal Linearity Performed
N/A Acceptable

"A powerful part of your team"

Screen Divisions, 10 = 3.9610"

EXAMINATION WELD/AREA	Recordable Indications		Scan Limitation		COMMENTS
	Yes	No	Yes	No	
2-SI-78-01		X	X		Single sided access downstream due to valve configuration. Maintained 10 to 20% ID roll for exam.
					50% Coverage Obtained Pd. 4/6/09

Examiner *[Signature]* Level II Date 04/04/2009
Print James Gatica

Examiner *[Signature]* Level I Date 04/04/2009
Print Patrick Langrock

Reviewer *[Signature]* Level III Date 4/6/09

Utility Review *[Signature]* Date 4/6/09

Authorized Inspection Agency *[Signature]* Date 4-6-2009

Rene K. Schenck

ADDITIONAL SHEETS? (Check Box)

Continuation	Beam Plot	X
Supplements	X	Other

Plant/Unit: DC COOK UNIT 2


Comp/System: 2-SI-78

Weld / Component ID Number: 01

Crown Height:	N/A
Crown Width:	0.75"
Diameter:	6" Nom
Weld Length:	21.4"

VALVE

ELBOW



PROFILE TAKEN FROM PREVIOUS EXAM REPORT. (SEE ATTACHED.)
SINGLE SIDE COVERAGE, 50% Coverage Obtained
Rd. 4/20/09

Comments:

Examiner: N/A Level: N/A Date: N/A Examiner: N/A Level: N/A Date: N/A
Reviewer: M.O. Level: III Date: 4/6/09 Utility Reviewer: R. D. ... Level: --- Date: 4/6/09
Authorized Inspection Agency: TRC/US O/Treuelic Science Date: 4-6-2009

verful part of your team"

A Westinghouse NDE Company

Plant: D.C. Cook Unit: 2
 Comp/System: 2-SI-56-22
 ISO #: A-47
 Summary No.: 090000

UT No.: U2C18-UT-09-063
 Procedure No.: ISI-PDI-UT-2 Rev 4
 Cal Block No.: 102917
 Scan Surface: ID OD

Thermometer S/N or SAP#: 105547

Block/Comp Temp: 80° F / 79° F
 0° or ⊥ TO WELD || TO WELD

SEARCH UNIT

Scan Angle: 60° Mode: Long
 Serial No.: 05-483 Mfg: RTD
 Fixturing: Integral Model: TRL-2
 Size: 2(8x14) Shape: Rect
 Frequency: 2.0 MHz
 Measured Angle: 60°

IIV / Rompas
 S/N - Step Wedge 102268
SCAN AREA
 0° WRV
 0° BM
 ⊥ To Weld
 || To Weld

IDENT	Sweep Pos	AMPL %	ATTEN dB	TO WELD		
				Sweep Pos	AMPL %	ATTE N dB
1.5" notch	5	80	45			
					N	
						A
				N		
				A		

Cable Type: RG-174 Length: 6'
 Couplant Brand: Ultra Gel II
 Couplant Batch: 07125


Connectors: 0
 Exit Pnt Dim: = N/A
 N/A Contoured

INSTRUMENT SETTINGS

Mfg/Model No.: GEIT USN 60 SW
 Serial/SAP No.: 105420 Display Start: IP
 Damping: 500 Pulsar Width: 250
 Mode Select: Square Reject: Off
 Frequency: 2.0 PRF Mode: Auto High
 Display Mode (RECTIF): Full Wave

CAL. CHECKS

CHECKS	TIME
Initial Cal.	08:15
Intermediate	
Intermediate	
Intermediate	
Final Cal.	11:45



Filter: Fixed Voltage: 450 Jack: T&R
 Range: 5.9116 Vel.: .2245
 Swp Delay: 7.5034 Zero: N/A

Gain 0° or ⊥	dB	45
Gain	dB	N/A

Scan Sensitivity: Axial = 55
 Circ = 59

INSTR. LINEARITY CAL.

	High	Low		High	Low
1			6		
2	N		7	N	
3		A	8		A
4			9		
5			10		

AMPL. CONTROL LINEARITY

Initial	Δ dB	Result
80	-6	
80	-12	N
40	+6	A
20	+12	

Horizontal Linearity Performed
 N/A Acceptable

"A powerful part of your team"

Screen Divisions, 10 = 5.9116"

EXAMINATION WELD/AREA	Recordable Indications		Scan Limitation		COMMENTS
	Yes	No	Yes	No	
2-SI-56-22		X	X		Maintained 10 to 20% ID roll. Single sided access due to branch connection configuration.
					50% Coverage Obtained PC 4/2/09

Examiner: James Gatica Level II Date 04/03/2009

Examiner: Patrick Langreck Level I Date 04/03/2009

Reviewer: M.O. Level III Date 4/7/09

Utility Review: Paul Donavin Date 4/7/09

Authorized Inspection Agency: Relias Date 4-7-2009


ADDITIONAL SHEETS? (Check Box)

Continuation		Beam Plot	X
Supplements	X	Other	

WALL THICKNESS PROFILE SHEET

WELD NO. : 2-SI-56-22

Position	0°	90°	180°	270°
1	1.123			
2	1.108			
3	1"			
TOE*	4	1.023		
C _L	5	1"	N/A	N/A
TOE*	6	1"		
	7	X		
	8	X		
	9	X		



Crown Height: .09"

Diameter: 10"


Crown Width: 1.07"

Weld Length: 34.5"

Longseam: N/A

Iso Drawing: A-47

PROFILE AREA



SINGLE SIDED COVERAGE, 50% Coverage
Pl. 4/30/09

FLOW →

Examiner: [Signature] Level: II Date: 4/3/09
 Examiner: [Signature] Level: I Date: 4/3/09
 Reviewer: M.O. Level: III Date: 4/3/09
 Utility Review: [Signature] Level: _____ Date: 4/7/09
 Authorized Inspection Agency: [Signature] / Reud K. Schenck Date: 4-7-2009
 "A powerful part of your team"