


United States Nuclear Regulatory Commission Official Hearing Exhibit	
In the Matter of:	Entergy Nuclear Operations, Inc. (Indian Point Nuclear Generating Units 2 and 3)
	ASLBP #: 07-858-03-LR-BD01
	Docket #: 05000247   05000286
	Exhibit #: RIV00052C-00-BD01
	Admitted: 10/15/2012
	Rejected:
Other:	Identified: 10/15/2012
	Withdrawn:
	Stricken:

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION FATIGUE EVALUATION OF HEAD FLANGE  
VESSEL FLANGE AND CLOSURE STUDS


NUMBER S-151-P | A-65  
SHEET 14 OF 51  
DATE 5-12-66 BY COCKBELL  
CHECK DATE 5-12-66 BY ALEXANDER

5. DETAILED ANALYSIS:

d. DEVELOPMENT OF CONTINUITY EQUATIONS:

2. MOVEMENTS DUE TO LOADS:

BODY-3:



$$I = 20945 \text{ in}^4$$

$$A = 378.957 \text{ in}^2$$

$$\frac{R^2}{I} = 0.41409$$

$$\frac{R^2}{A} = 22.9367$$

$$\bar{H} = 1.0290 H_2 + 0.9764 H_3 + 23.7340 P$$

$$\bar{M} = -45.4751 M_2 - 1.0290 M_3 - 1.0136 M_{7a} + 12.5351 H_2$$

$$+ 0.9765 (M_2 + M_{7a}) + 7.1370 (T+V)$$

$$+ 7.8499 (W+S) - 79.8729 P$$



DISPLACEMENTS DUE TO REDUNDANT FORCES:

$$E \Delta_{22} = \frac{R^2}{A} \bar{H} - h; \frac{R^2}{I} \bar{M} = 1919.8093 H_2 + 69.7697 M_2 - 207.4870 H_3 - 17.9066 M_3 - 120.8925 V$$

$$E \Delta_{32}^* = \frac{R^2}{I} \bar{M} = -69.7697 H_2 - 3.6815 M_2 + 5.2019 H_3 + 0.4052 M_3 + 2.9619 V$$

$$E \Delta_{23} = \frac{R^2}{A} \bar{H} - h; \frac{R^2}{I} \bar{M} = -218.6730 H_2 - 5.4818 M_2 + 89.1774 H_3 + 5.2020 M_3 + 38.0249 V$$

$$E \Delta_{33}^* = \frac{R^2}{I} \bar{M} = -18.8717 H_2 - 0.4270 M_2 + 5.2019 H_3 + 0.4052 M_3 + 2.9619 V$$

$$E V_{33} = 6.936 \frac{R^2}{I} \bar{M} = -130.8941 H_2 - 2.9617 M_2 + 36.0804 H_3 + 2.8105 M_3 + 30.1982 V$$

COMBUSTION ENGINEERING, INC.  
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.  
 CHARGE NO. \_\_\_\_\_  
 DESCRIPTION FATIGUE EVALUATION OF HEAD FLANGE  
VESSEL FLANGE AND CLOSURE STUDS

NUMBER S-151-P | A 66  
 SHEET 15 OF 51  
 DATE 5-12-66 BY COXWELL  
 CHECK DATE 5-12-66 BY ALEXANDER

5. DETAILED ANALYSIS:

1- DEVELOPMENT OF CONTINUITY EQUATIONS:

2. MOVEMENTS DUE TO FORCES:

DISPLACEMENTS DUE TO APPLIED FORCES:

$$E\delta_{32} = \frac{R^2}{A} \bar{H} - h_j; \frac{R^2}{I} \bar{M} = -130.8923T - 143.9612(W+S) + 2009.1897P$$

$$E\delta_{32}^* = \frac{R^2}{I} \bar{M} = 2.9619T + 3.2576(W+S) - 33.1465P$$

$$E\delta_{33} = \frac{R^2}{A} \bar{H} - h_j; \frac{R^2}{I} \bar{M} = 38.0249T + 41.8215(W+S) + 118.8449P$$

$$E\delta_{33}^* = \frac{R^2}{I} \bar{M} = 2.9619T + 3.2576(W+S) - 33.1465P$$

$$E\nu_{32} = 6.936 \frac{R^2}{I} \bar{M} = -229.9041P$$

DISPLACEMENTS DUE TO THERMAL EFFECTS:

$$E\delta_{32T} = R_3 E_d (T_m - 70) - R_3 h_j E_d \left(\frac{\Delta T}{\Delta X}\right)_{eq} - h_j \frac{R^2}{I} \bar{M} =$$

$$= 93.231 E_d (T_m - 70) - 4120.064 E_d \left(\frac{\Delta T}{\Delta X}\right)_{eq} - 17.9066 M_{T3} + 18.5485 M_{T2}$$

$$E\delta_{32}^* = R_3 E_d \left(\frac{\Delta T}{\Delta X}\right)_{eq} + \frac{R^2}{I} \bar{M} = 93.231 E_d \left(\frac{\Delta T}{\Delta X}\right)_{eq} + 0.4052 M_{T3} - 0.41972 M_{T2}$$

$$E\delta_{33T} = R_4 E_d (T_{top} - 70) + h_j \frac{R^2}{I} \bar{M} = 91.031 E_d (T_{top} - 70) + 5.2020 M_{T3} - 5.3884 M_{T2}$$

$$E\delta_{33}^* = R_3 E_d \left(\frac{\Delta T}{\Delta X}\right)_{eq} + \frac{R^2}{I} \bar{M} = 93.231 E_d \left(\frac{\Delta T}{\Delta X}\right)_{eq} + 0.4052 M_{T3} - 0.41972 M_{T2}$$

$$E\nu_{32T} = R_8 E_d (T_8 - 70) \frac{E_{d8}}{E_{d193}} + 6.936 \frac{R^2}{I} \bar{M} =$$

$$= 30.5221 E_d (T_8 - 70) + 646.6502 E_d \left(\frac{\Delta T}{\Delta X}\right)_{eq} + 2.8105 M_{T3} - 2.9112 M_{T2}$$

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION FATIGUE EVALUATION OF HEAD FLANGE  
VESSEL FLANGE AND CLOSURE STUDSNUMBER S-151-P| A67SHEET 16 OF 51DATE 5-12-66 BY COCKRELLCHECK DATE 5-12-66 BY ALEXANDER5. DETAILED ANALYSIS:d. DEVELOPMENT OF CONTINUITY EQUATIONS:2. MOVEMENTS DUE TO FORCES:

$T_{ax}$ ,  $T_{bx}$ , AND  $\left(\frac{\Delta T}{\Delta x}\right)_{eq}$  FOR THE VESSEL FLANGE ARE OBTAINED BY THE METHOD AS ILLUSTRATED ON SHEETS -11 & 12 AND ARE LISTED BELOW.

TRANSIENT	$T_m$	$(E\epsilon)_i$	$M_T$	$\left(\frac{\Delta T}{\Delta x}\right)_{eq}$	$T_a$	$T_b$	$T_B$ (ROST)	
HEATUP	4.00 HRS	296	196	-2482806	6.539	211.0	331.0	172
	4.25	315	198	-2838430	6.848	226.0	404.0	183
	4.35	323	198	-2896055	6.987	232.2	413.8	187
	4.47	334	199	-2986356	7.169	240.8	427.2	194
	5.00	368	202	-3007646	7.113	275.5	460.5	220
STEADY STATE	533	212	-471993	1.064	519.2	546.8	532	
COOLDOWN	4.00 HRS	336	199	2325354	-5.582	408.6	263.4	459
	4.25	317	198	2424287	-5.849	393.0	241.0	449
	4.35	309	197	2469749	-5.989	386.9	231.1	444
	4.47	299	196	2523836	-6.151	379.0	219.0	437
	5.00	263	193	2448075	-6.059	341.8	184.2	411

SUBSTITUTING VALUES INTO EQUATIONS AS GIVEN ON SHEET - 15, WE GET THE FOLLOWING VALUES FOR DISPLACEMENTS AND ROTATIONS OF BODY-3 AT CUTS-2 & 3.

**COMBUSTION ENGINEERING, INC.**  
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-151-P | A 68

SHEET 17 OF 51

CHARGE NO. \_\_\_\_\_

DATE 5-12-66 BY COCKRELL

DESCRIPTION FATIGUE EVALUATION OF HEAD FLANGE,  
VESSEL FLANGE AND CLOSURE STUDS

CHECK DATE 5-12-66 BY ALEXANDER

5. DETAILED ANALYSIS:

- 1. DEVELOPMENT OF CONTINUITY MATRIX:
- 2. MOVEMENTS DUE TO LOADS:

TRANSIENT	$(\frac{10}{E})_{in}$	$(\frac{10}{E})_{out}$	$(\frac{10}{E})_{in}$	$(\frac{\Delta T}{\Delta X})_{log}$	$M_{T3}$	$M_{T2}$	$E_{327}$	$E_{317}$	$E_{327}$	$E_{317}$	$E_{327}$	$E_{317}$			
4.00 hrs	226	183	311	184	102	180	6.539	45.9071	1023.212	9702.229	-132.289	2078.537	-132.289	-338.472	-338.472
4.25	215	174	334	185	113	170	6.848	46.1449	1049.229	1058.1097	-144.324	2263.799	-144.324	-356.069	-356.069
4.35	253	184	343.8	185	117	180	6.987	46.2890	1101.081	1117.955	-154.725	2264.701	-154.725	-405.380	-405.380
4.47	264	184	357.3	186	124	180	7.169	46.4736	1134.218	1181.0278	-164.762	2353.930	-164.762	-435.043	-435.043
5.00	298	184	390.5	186	150	181	7.113	36.1170	1176.806	1508.0433	-225.563	214.9524	-225.563	-703.712	-703.712
STEADY STATE	463	186	472.8	186	462	186	1.064	17.291	361.003	1359.949	-126.063	621.7775	-126.063	18.33059	18.33059
4.00 hrs	266	184	192.4	182	389	186	-5.582	-402.539	-726.730	2823.090	46.158	5026.108	46.158	2949.787	2949.787
4.25	247	184	171	182	379	186	-5.849	-406.478	-774.763	1579.158	60.142	4893.324	60.142	2638.176	2638.176
4.35	239	183	161	181	374	186	-5.989	-408.144	-796.483	1128.053	66.740	4823.010	66.740	2654.639	2654.639
4.47	229	183	149	181	367	185	-6.151	-410.452	-821.931	648.890	73.722	4748.762	73.722	2662.044	2662.044
5.00	193	182	114.2	180	341	185	-6.059	-304.752	-942.210	-2346.516	12.7197	4824.103	12.7197	2880.580	2880.580

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-151-P | A 69

SHEET 18 OF 51

DATE 5-12-66 BY COCKRELL


DESCRIPTION FATIGUE EVALUATION OF HEAD FLANGE, VESSEL FLANGE AND CLOSURE STUDS, CHECK DATE 5-12-66 BY ALEXANDER

5. DETAILED ANALYSIS:

1. DEVELOPMENT OF CONTINUITY EQUATIONS:

2. MOVEMENTS DUE TO FORCES:

BODY-4:



$$R_4 = 91.031''$$

$$b_4 = 85.437''$$

$$t_4 = 10.75''$$

$$\beta^4 = \frac{3(1-\nu^2)}{R_4^2 t_4^3}$$

$$\beta = 0.04108$$

$$D = \frac{E t_4^3}{12(1-\nu^2)} = 113.76345E$$

DISPLACEMENTS DUE TO REDUNDANT FORCES:

$$E \Delta_{43} = \frac{E}{2\beta^4 D} \left[ -\frac{1}{\beta} H_3 + M_3 \right] = -63.2918 H_3 + 2.6006 M_3$$

$$E \Delta_{43}^* = -\frac{E}{2\beta^4 D} \left[ -H_3 + 2\beta M_3 \right] = 2.6006 H_3 - 0.2137 M_3$$

DISPLACEMENTS DUE TO APPLIED LOADS:

$$E \delta_{43} = \frac{b_4^2}{t_4} \left( \frac{R_4}{b_4} - \frac{r}{z} \right) P = 621.6238 P$$

$$E \delta_{43}^* = 0$$

DISPLACEMENTS DUE TO THERMAL EFFECTS:

$$E \delta_{43T} = R_4 E \alpha (T_{43} - 70) + \frac{E}{2\beta^4 D} M_{73} = 91.031 E \alpha (T_{43} - 70) + 2.6006 M_{73}$$

$$E \delta_{43T}^* = R_4 E \alpha \left( \frac{\Delta T}{\Delta X} \right)_{43} - \frac{E}{\beta D} M_{73} = 91.031 E \alpha \left( \frac{\Delta T}{\Delta X} \right)_{43} - 0.2137 M_{73}$$

COMBUSTION ENGINEERING, INC. NUMBER 5-151-P | A 70  
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN. SHEET 19 OF 51  
 CHARGE NO. \_\_\_\_\_ DATE 5-12-66 BY CORRELL  
 DESCRIPTION FATIGUE EVALUATION OF HEAD FLANGE, CHECK DATE 5-12-66 BY ALEXANDER  
VESSEL FLANGE AND CLOSURE STRIPS

5. DETAILED ANALYSIS:

d. DEVELOPMENT OF CONTINUITY EQUATIONS:

2- MOVEMENTS DUE TO FORCES:

SUBSTITUTING VALUES INTO DISPLACEMENTS AS GIVEN ON SHEET-18,  
 WE GET THE FOLLOWING VALUES FOR DISPLACEMENTS AND ROTATIONS  
 OF BODY-4 AT CUT-3.

TRANSIENT		$T_{43}$	$(E\delta)_m$	$(\Delta T / \Delta X)_{43}$	$M_{T3}$	$E\delta_{43T}$	$E\delta_{43T}^*$
HEATUP	4.00 HRS	391	185	2.800	458071	6597135	-50736
	4.25	413	185	2.800	461449	6976416	-51458
	4.35	423	186	2.800	462890	7180705	-51511
	4.47	435	186	3.200	464736	7388687	-45132
	5.00	466	186	3.00	361170	7644238	-26387
STEADY STATE		544	186	0.200	17291	8070624	-309
COOLDOWN	4.00 HRS	253	182	-2.600	-402539	1985035	42947
	4.25	230	181	-2.600	-406478	1579171	43788
	4.35	221	181	-2.700	-408144	1426549	42733
	4.47	209	180	-2.500	-410452	1210175	46750
	5.00	177	180	-2.900	-304752	960719	25801

3. CONTINUITY MATRIX AND LOADING VECTORS:

THE MATRIX FOR THE SOLUTION FOR THE THERMAL LOADINGS WILL  
 BE ARRANGED AS SHOWN BELOW

$$\begin{aligned} E\Delta_{11} - E\Delta_{21} &= E\delta_{21T} - E\delta_{11T} \\ E\Delta_{11}^* - E\Delta_{21}^* &= E\delta_{21T}^* - E\delta_{11T}^* \\ E\Delta_{22} - E\Delta_{32} &= E\delta_{32T} - E\delta_{22T} \\ E\Delta_{22}^* - E\Delta_{32}^* &= E\delta_{32T}^* - E\delta_{22T}^* \\ E\Delta_{33} - E\Delta_{43} &= E\delta_{43T} - E\delta_{33T} \\ E\Delta_{33}^* - E\Delta_{43}^* &= E\delta_{43T}^* - E\delta_{33T}^* \\ EV_{22} - EV_{32} &= EV_{32T} - EV_{22T} \end{aligned}$$

THE SOLUTION FOR THE APPLIED  
 LOADS WERE DETERMINED IN THE  
 MECHANICAL ANALYSIS (5-150-P).

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-151-D | 1471

SHEET 20 OF 51

DATE 5-12-66 BY CRABELL

DESCRIPTION ENTIRE EVALUATION OF HEAT EXCHANGER, VESSEL FLANGE AND GASQUE STUDS

CHECK DATE 5-12-66 BY ALEXANDER

CHARGE NO. \_\_\_\_\_

5. DETAILED ANALYSIS

d. DEVELOPMENT OF CONTINUITY EQUATIONS:

3. CONTINUITY MATRIX AND LOADING VECTORS:

SUBSTITUTING THE DEFLECTIONS AND ROTATIONS IN THE COMPATIBILITY EQUATIONS AS GIVEN ON SHEET -19 AND WRITING IN MATRIX FORM YIELDS THE FOLLOWING MATRIX AND LOADING VECTORS:

162.1377	2.2709	82.6039	3.9830	0	0	-27.6228	H <sub>1</sub>
2.2709	0.9094	-5.0262	-0.3190	0	0	2.2123	M <sub>1</sub>
-72.3659	4.4028	-2018.0589	-74.7959	207.4870	17.9066	165.7537	H <sub>2</sub>
3.4890	-0.2794	74.7959	4.0005	-5.2019	-0.4052	-5.1742	M <sub>2</sub>
0	0	-218.6730	-5.4818	152.4692	2.6013	30.0249	H <sub>3</sub>
0	0	-18.8717	-0.4270	2.6013	0.6189	2.9619	M <sub>3</sub>
24.1997	-1.9379	165.7558	5.1743	-36.0804	-2.8105	-48.1249	V

HEAT UP					STEADY STATE
T=4.00 HRS	T=4.25	T=4.35	T=4.57	T=5.00	
-2212,270	-2296,590	-2331,160	-2367,380	-2105,180	-12,000
-236,050	-234,790	-234,080	-233,770	-165,500	-4,810
3933,219	4326,047	4835,205	5267,348	8313,263	5097,179
-44,929	-56,284	-66,435	-76,072	-158,163	-121,723
4518,598	4712,617	4916,004	5034,757	5494,714	1852,849
31,550	92,860	103,220	119,630	199,170	125,750
-1182,842	-1304,099	-1391,680	-1481,383	-2079,022	-366,841

COOL DOWN				
T=4.00 HRS	T=4.25	T=4.35	T=4.47	T=5.00
2096,790	2137,860	2167,270	2181,990	1950,810
195,740	197,030	196,920	196,960	134,550
-709,320	-1292,952	-1599,907	-1849,120	-4630,996
-26,902	-13,648	-7,340	-808	72,437
-3041,073	-3314,153	-3396,461	-3538,587	-3863,384
-3,210	-16,350	-24,010	-26,970	-101,400
671,377	820,286	880,239	953,544	1478,570

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-151-P | A72  
SHEET 21 OF 51

CHARGE NO. \_\_\_\_\_

DATE 5-12-66 BY COCKRELL

DESCRIPTION FATIGUE EVALUATION OF HEAD FLANGE,  
VESSEL FLANGE AND CLOSURE STUDS

CHECK DATE 5-12-66 BY ALEXANDER

5- DETAILED ANALYSIS:

4- DEVELOPMENT OF CONTINUITY EQUATIONS:

4. REDUNDANT LOAD VALUES:

SOLVING THE MATRIX ON SHEET - 20 WITH THE GIVEN LOADING-VECTORS FOR THE HEATUP, STEADYSTATE AND COOLDOWN CONDITIONS, WE GET THE FOLLOWING REDUNDANT FORCES. THE VALUES OF THE REDUNDANT FORCES FOR BOLT-UP, CORE SUPPORT WEIGHT, CORE HOLDDOWN SPRING FORCE AND INTERNAL PRESSURE ARE TAKEN FROM CALCULATION NO. 5-150-P. THE VALUES OF THE REDUNDANT FORCES FOR INTERNAL PRESSURE ARE LEFT IN TERMS OF PRESSURE SINCE THE ACTUAL PRESSURE DURING THE TRANSIENT WILL BE USED.

TRANSIENT	H <sub>1</sub>	M <sub>1</sub>	H <sub>2</sub>	M <sub>2</sub>	H <sub>3</sub>	M <sub>3</sub>	V	
BOLT-UP ONLY	28.2120	-329.4526	3.3876	-19.1672	-18.2221	-391.0394	—	
CORE SUPPORT WEIGHT	-0.0112	0.0771	0.0550	-0.7267	-0.2172	-4.5965	—	
CORE HOLDDOWN SPRING	0.2130	-3.0406	0.0426	-0.3261	-0.2134	-4.5652	—	
INTERNAL PRESSURE	-0.04139P	-8.38228P	-1.09028P	19.09019P	1.22229P	9.64912P	3.90667P	
HEATUP	4.00 HRS	-7.6782	-275.2274	2.6804	-13.3455	28.4550	-3.7709	18.4845
	4.25	-7.9770	-275.9300	2.5753	-10.9385	29.2191	3.6531	19.8155
	4.35	-8.1679	-275.0594	2.5149	-8.9711	30.2851	13.9666	20.0634
	4.47	-8.4331	-273.9405	2.6621	-10.3082	30.7298	41.7267	20.1573
	5.00	-6.8833	-213.1766	2.2308	-4.5564	30.5946	141.8189	24.2974
STEADY STATE	0.8837	-17.3723	-0.1853	-1.7866	8.5167	144.3207	3.8965	
COOLDOWN	4.00 HRS	8.0529	224.1142	-2.3640	7.7285	-20.5951	92.0124	-16.1701
	4.25	7.7977	231.9945	-2.4440	7.8418	-21.7476	85.5139	-18.7298
	4.35	7.8772	232.8309	-2.3687	6.2381	-21.9726	77.8335	-19.2652
	4.47	7.5940	237.8749	-2.3461	5.6215	-22.5571	84.3951	-21.0675
	5.00	6.4418	179.6201	-1.8011	-2.0546	-21.7719	-13.7274	-24.0173

UNITS ON FORCES:

FOR H'S	KIPS PER INCH OF CIRCUMFERENCE	} APPLIED AT THEIR RESPECTIVE RADII.
M'S	IN-KIP PER INCH OF CIRCUMFERENCE	
V'S	KIPS PER INCH OF CIRCUMFERENCE	



COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-151-P | A 73  
SHEET 22 OF 51

CHARGE NO. \_\_\_\_\_

DATE 5-12-66 BY COCKERELL

DESCRIPTION FATIGUE EVALUATION OF HEAD FLANGE  
VESSEL FLANGE AND CLOSURE STUDS


CHECK DATE 5-12-66 BY ALEXANDER

5. DETAILED ANALYSIS:

B. STRESSES:

1. UNCONFINED:

CONSIDER THE BEARING STRESS BETWEEN THE STUD WASHER AND CLOSURE HEAD. AT THE END OF THE HEATUP TRANSIENT, THE AXIAL LOAD ON THE CLOSURE STUD WILL BE THE GREATEST; HENCE, THE BEARING STRESS BETWEEN THE STUD WASHER AND CLOSURE HEAD WILL BE THE GREATEST. NOTE THAT THE CHANGE IN BOLT LOAD, OVER THE INITIAL COLD BOLT-UP LOAD, IS APPROXIMATELY 28% TOTAL FOR BOTH PRESSURE AND THERMAL EFFECTS.



LOAD PER STUD =  $\frac{27 R_B (T+V)}{54}$  SEE SHEET 23 FOR VALUE OF T+V

=  $\left[ \frac{116.532 + 3.9067P + 24.297}{54} \right] 27 R_B$

= 1670.2 KIPS.

MINIMUM O.D. OF WASHER:  
 $10.5625 - 0.0313 = 10.5312$

MAXIMUM DIA. OF STUD HOLE:  
 $7.500 + 0.0625 = 7.5625$

BEARING AREA PER STUD =  $\frac{\pi}{4} [10.5312^2 - 7.5625^2] = 42.19 \text{ in}^2$

$\sigma_B = \frac{T+V}{A_B} = \frac{1670.2}{42.19} = \underline{\underline{39.6 \text{ ksi}}}$

ALLOWABLES	FLANGE: $1.5 S_m = 40 \text{ ksi}$
SEE CRITERION	WASHER: $1.5 S_m = 59.2 \text{ ksi}$
5-C-1	BOTH AT $550^\circ \text{F}$ (ACTUAL TEMP.)

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-151-P A 74

SHEET 23 OF 51

CHARGE NO. \_\_\_\_\_

DATE 5-12-66 BY COCKRELL

DESCRIPTION FATIGUE EVALUATION OF HEAD FLANGE,  
VESSEL FLANGE AND CLOSURE HEAD


CHECK DATE 5-12-66 BY ALEXANDER

5. DETAILED ANALYSIS:

a. STRESSES:

1. UNCONCENTRATED:

STRESSES WILL BE CALCULATED AT THE LOCATIONS AS SHOWN BELOW.



POINTS 1 & 2:

$$\sigma_x = \pm \frac{b}{t^2} (M_1 + M_{T1}) + \frac{H \cos \theta}{t} + \frac{a^2 P}{2R_1 t} + \frac{E \Delta}{(1-\nu)} (T_m - 70)$$

$$= \pm 0.06783 (M_1 + M_{T1}) + 0.03654 H + 4.3709 P$$

$$+ 1.42857 E \Delta (T_m - 70)$$

$$\sigma_\theta = \pm \frac{t b}{t^2} (M_1 + M_{T1}) + \frac{t H \cos \theta}{t} + \frac{E \Delta_{11} + E \Delta_{1T}}{R_1 \sin \theta} + \frac{t \cos \theta (E \Delta_{11}^* + E \Delta_{1T}^*)}{2 P \sin \theta}$$

$$+ \frac{a^2 P}{2 R_1 t} + \frac{E \Delta (T_m - 70)}{(1-\nu)} - E \Delta (T_m - 70) = \pm 0.02035 (M_1 + M_{T1})$$

$$+ 0.01096 H + 0.01189 (E \Delta_{11} + E \Delta_{1T}) \pm 0.01922 (E \Delta_{11}^* + E \Delta_{1T}^*)$$

$$+ 4.3709 P + 1.42857 E \Delta (T_m - 70) - E \Delta (T_m - 70)$$

POINTS 3 & 4:

$$\sigma_x = \pm \frac{b}{t^2} (M_3 + M_{T3}) + \frac{b^2 P}{2 R_4 t^2} + \frac{E \Delta}{(1-\nu)} (T_m - 70)$$

$$= \pm 0.05191 (M_3 + M_{T3}) + 3.7296 P + 1.42857 E \Delta (T_m - 70)$$

$$\sigma_\theta = \pm \frac{t b}{t^2} (M_3 + M_{T3}) + \frac{E M_{T3}}{2 R_4 b^2 t} + \frac{E \Delta_{43}}{R_4} + \frac{b t P}{t a}$$

$$+ \frac{E \Delta}{(1-\nu)} (T_m - 70) = \pm 0.01557 (M_3 + M_{T3}) + 0.02860 M_{T3}$$

$$+ 0.01098 E \Delta_{43} + 7.94762 P + 1.42857 E \Delta (T_m - 70)$$

POINTS 5 & 6:

$$\sigma_y = \frac{T+V}{A} \pm \frac{M C}{I} = 0.31631 (T+V) \pm 0.36236 M_2$$

POINTS 7 & 8:

$$\sigma_x = \frac{T+V}{A} \pm \frac{(M + H R_0) C}{I} = 0.31631 (T+V) \pm 0.36236 M_2 \pm 11.33489 H_2$$

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-151-P | A 75

SHEET 24 OF 51

DATE 5-12-66 BY COCKRELL

CHARGE NO. \_\_\_\_\_  
DESCRIPTION FATIGUE EVALUATION OF HEAD FLANGE,  
VESSEL FLANGE AND CLOSURE STUDS

CHECK DATE 5-12-66 BY ALEXANDER

5. DETAILED ANALYSIS:

a. STRESSES:

1. UNCONCENTRATED:

THE FOLLOWING TABLES GIVE THE MECHANICAL AND THERMAL STRESSES, THE TOTAL STRESS, AND STRESS INTENSITIES AT THE LOCATIONS AS SHOWN ON SHEET-23. STRESSES FOR THE MECHANICAL LOADS AND FOR THE HEATUP AND COOLDOWN CYCLES WERE CALCULATED BY USING THE STRESS EXPRESSIONS AS GIVEN ON SHEET-23 AND THE VALUES OF THE REDUNDANT FORCES LISTED ON SHEET-21. THERMAL STRESSES FOR ALL OTHER TRANSIENT CONDITIONS WERE CONSERVATIVELY CALCULATED BY TREATING THE CHANGE IN REACTOR COOLANT TEMPERATURE AS A SKIN EFFECT ON THE INSIDE SURFACE OF THE VESSEL. THIS METHOD WAS USED SINCE THE MEAN TEMPERATURE OF THE VESSEL WALL WILL NOT DEVIATE APPRECIABLY FROM THE MEAN TEMPERATURE EXISTING AT STEADY STATE AND BECAUSE THE TRANSIENTS ARE OF SHORT DURATION. THE STRESS AT THE INSIDE SURFACE WILL BE CALCULATED ASSUMING THAT THE SURFACE WILL BE AT A TEMPERATURE EQUAL TO THE REACTOR COOLANT TEMPERATURE AND IS CALCULATED FROM THE EXPRESSION:

$$\sigma_x = \sigma_y = \frac{E\alpha}{1-\nu} (T_m - T)$$

WHERE,

T = REACTOR COOLANT TEMPERATURE

T<sub>m</sub> = MEAN TEMP. OF VESSEL AT THE LOCATION OF INTEREST

Eα = YOUNG'S MODULUS TIMES COEFFICIENT OF THERMAL EXPANSION

ν = POISSON'S RATIO

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER 5-157-D | A 76  
SHEET 25 OF 51

DESCRIPTION Failure Examination of Head Flange  
Lower Flange And Closure Studs

DATE 5-12-66 BY BYG/STC  
CHECK DATE 5-12-66 BY ALC/STC

5-DETAILED ANALYSIS:  
σ-STRESSES:  
1-UNBARRIQUETED:

LOCATION 1

TRANSIENT	INTERNAL PRESSURE KSIa	(T <sub>m</sub> -T) °F	THERMAL STRESS		PRESSURE STRESS			TOTAL STRESS			STRESS INTENSITY			
			σ <sub>x</sub>	σ <sub>θ</sub>	σ <sub>x</sub>	σ <sub>θ</sub>	σ <sub>r</sub>	σ <sub>x</sub>	σ <sub>θ</sub>	σ <sub>r</sub>	σ <sub>x</sub> -σ <sub>θ</sub>	σ <sub>x</sub> -σ <sub>r</sub>	σ <sub>θ</sub> -σ <sub>r</sub>	
Cold Bolt Up	0	0	0	0	-21.50	-2.51	0	-21.50	-2.51	0	-18.99	-21.50	-2.51	
Bolt Up + 2500 psia	2.5	0	0	0	-11.99	6.17	-2.50	-11.99	6.17	-2.50	-18.16	-9.49	8.67	
a Heating	4.00 hrs.	1.882	[Graph showing temperature vs. time]	-17.50	-26.63	-14.35	4.02	-1.88	-31.85	-22.61	-1.88	-9.24	-29.97	-20.73
	4.25	2.078		-18.34	-27.98	-13.60	4.70	-2.08	-31.96	-23.28	-2.08	-8.70	-29.90	-21.20
	4.35	2.156		-18.37	-28.19	-13.31	4.97	-2.16	-31.68	-23.22	-2.16	-8.76	-29.52	-21.06
	4.47	2.250		-18.61	-28.73	-12.95	5.30	-2.25	-31.56	-23.43	-2.25	-8.13	-29.31	-21.18
	5.00	2.250		-13.80	-22.43	-12.95	5.30	-2.25	-26.75	-17.13	-2.25	-9.62	-24.50	-14.88
Steady State	2.250			-1.23	-0.59	-12.95	5.30	-2.25	-14.18	4.71	-2.25	-18.89	-11.93	6.96
b Cooling	4.00 hrs.	0.315	[Graph showing temperature vs. time]	14.96	24.85	-20.30	-1.42	-0.32	-5.34	23.43	-0.32	-28.77	-5.02	23.75
	4.25			16.29	25.49				-4.01	24.07	-0.32	-28.08	-3.69	24.39
	4.35			16.63	25.74				-3.87	24.32	-0.32	-28.19	-3.55	24.64
	4.47			16.80	25.89				-3.50	24.47	-0.32	-27.97	-3.18	24.79
	5.00			11.69	19.66				-8.61	18.24	-0.32	-26.85	-8.29	18.56
c	20 min	2.250	-7.8	-3.63	-2.99	-12.95	5.30	-2.25	-16.58	2.31	-2.25	-18.89	-14.33	4.56
d	20 min	2.250	7.8	1.17	1.81	-12.95	5.30	-2.25	-11.78	7.11	-2.25	-18.89	-9.53	9.36
e	100 sec.	2.110	11.2	2.21	2.95	-13.37	4.92	-2.14	-11.16	7.77	-2.14	-18.93	-9.02	9.91
	225 sec.	2.275	1.7	-0.71	-0.07	-12.85	5.38	-2.28	-13.56	5.31	-2.28	-18.87	-11.28	7.59

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_  
DESCRIPTION Failure Evaluation Of Head Flange  
Vessel Flange And Gasket Straps  
CHECK DATE 5-12-66 BY Alexander

5. DETAILED ANALYSIS:  
σ-STRESSES:

1. UNKNOWN STRESS:

LOCATION - 1

TRANSIENT	WIRE MESH PRESSURE PSIA	(T <sub>m</sub> -T) °F	THERMAL STRESS		PRESSURE STRESS			TOTAL STRESS			STRESS INTENSITY			
			F <sub>x</sub>	F <sub>θ</sub>	F <sub>x</sub>	F <sub>θ</sub>	F <sub>r</sub>	F <sub>x</sub>	F <sub>θ</sub>	F <sub>r</sub>	F <sub>x-θ</sub>	F <sub>x-r</sub>	F <sub>θ-r</sub>	
f	40sec	2.320	-9.3	-4.09	-3.45	-12.68	5.54	-2.32	-16.77	2.09	-2.32	-18.86	-14.45	4.41
	100sec	2.260	-13.3	-5.31	-4.67	-12.91	6.33	-2.26	-18.22	0.66	-2.26	-18.88	-15.96	2.92
	260sec	2.140	-1.3	-1.63	-0.99	-13.37	4.92	-2.14	-15.00	3.93	-2.14	-18.93	-12.86	6.07
g	2 min	2.370	-12.0	-4.92	-4.28	-12.49	5.71	-2.37	-17.41	1.43	-2.37	-18.84	-15.04	3.80
	3.2 min	2.350	-15.0	-5.84	-5.20	-12.57	5.64	-2.35	-18.41	0.44	-2.35	-18.85	-16.06	2.79
	10.9 min	2.150	0	-1.23	-0.59	-13.33	4.95	-2.15	-14.56	4.36	-2.15	-18.92	-12.41	6.51
h	10 sec	2.220	-9.5	-4.15	-3.51	-13.06	5.19	-2.22	-17.21	1.68	-2.22	-18.89	-14.99	3.90
	65 sec	1.910	8.5	1.38	2.02	-14.28	4.12	-1.91	-12.86	6.14	-1.91	-19.00	-10.95	8.05
i	220 min	3.125	0	0	0	-9.62	8.33	-3.13	-9.62	8.33	-3.13	-17.95	-6.49	11.46
j	HEATUP 3.5 hrs	1.250	X	-18.61	-28.73	-16.75	1.93	-1.25	-35.36	-26.90	-1.25	-8.46	-34.11	-25.65
	S.S.	2.500		-1.23	-0.59	-11.99	6.17	-2.50	-13.22	5.58	-2.50	-18.80	-10.72	8.08
	COOLDOWN 3.5 hrs	0.315		16.80	25.89	-20.30	-1.42	-0.32	-3.50	24.47	-0.32	-27.97	-3.18	24.79
k	~	2.350	6.0	0.61	1.25	-12.57	5.64	-2.35	-11.96	6.89	-2.35	-18.85	-9.16	9.24
	~	2.150	-6.0	-3.07	-2.43	-13.33	4.95	-2.15	-16.40	2.52	-2.15	-18.92	-14.25	4.64
l	12 sec	2.250	33.3	9.00	9.64	-12.95	5.30	-2.25	-3.95	14.94	-2.25	-18.89	-1.70	17.19
m	10 sec	2.760	-30.2	-10.51	-9.87	-11.01	7.07	-2.76	-21.52	-2.90	-2.76	-18.72	-18.76	-0.04
	28 sec	2.170	-41.2	-13.88	-13.24	-13.44	4.85	-2.12	-27.32	-8.39	-2.12	-18.93	-25.20	-6.27
	160 sec	1.440	4.8	0.24	0.88	-16.03	2.49	-1.44	-15.79	3.37	-1.44	-19.16	-14.35	4.81
n	33 sec	0.300	117	34.71	35.35	-20.36	-1.47	-0.30	14.35	33.88	-0.30	-19.53	14.65	34.18
	54 sec	0.700	197	59.28	59.92	-18.84	-0.08	-0.70	40.44	59.84	-0.70	-19.40	41.14	60.54

SI<sub>MAX RANGE</sub> = (F<sub>θ</sub>-F<sub>r</sub>) = 50.40 ksi < 3S<sub>m</sub> = 80.1 ksi (CRITERION 5-C-2)

NUMBER 5-151-P OF 51  
SHEET 26  
DATE 5-12-66 BY Alexander

A 77

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-151-P | 1 A 78

SHEET 27 OF 51

DATE 5-12-66 BY CKEEL

DESCRIPTION Fatigue Evaluation of Head Flange CHECK DATE 5-12-66 BY ALEXANDER

Washer Flange And Closure Studs

5. Detailed Analysis:

C-Stresses:

1. Unaccounted:

LOCATION 2

TRANSIENT	INTERNAL PRESSURE KPSIA	(T <sub>int</sub> - T) °F	THERMAL STRESS		PRESSURE STRESS			TOTAL STRESS			STRESS INTENSITY			
			$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$\sigma_r$	$\sigma_x$	$\sigma_y$	$\sigma_r$	$\sigma_x - \sigma_y$	$\sigma_x - \sigma_r$	$\sigma_y - \sigma_r$	
Cold Bolt Up	0	0	0	0	23.20	13.74	0	23.20	13.74	0	9.46	23.20	13.74	
Bolt Up + 2500 psia	2.5	0	0	0	35.54	23.80		35.54	23.80		11.74	35.54	23.80	
a Heating	4.00 hrs	1.882	12.25	8.53	32.49	21.31		44.74	29.84		14.90	44.74	29.84	
	4.25	2.078	13.09	9.06	33.46	22.10		46.55	31.16		15.39	46.55	31.16	
	4.35	2.156	13.84	9.00	33.85	22.41		46.89	31.41		15.48	46.89	31.41	
	4.47	2.250	13.54	7.20	34.31	22.79		47.85	29.99		17.86	47.85	29.99	
	5.00	2.250	10.91	6.72	34.31	22.79		45.22	29.51		15.71	45.22	29.51	
Steady State	2.250		0.99	0.29	34.31	22.79		35.30	23.08		12.22	35.30	23.08	
b Cooling	4.20 hrs	0.315	-9.74	-6.60	24.76	15.01		15.02	8.41		6.61	15.02	8.41	
	4.25		-10.83	-7.35				13.93	7.66		6.27	13.93	7.66	
	4.35		-10.45	-6.89				14.31	8.12		6.19	14.31	8.12	
	4.47		-10.87	-7.23				13.89	7.78		6.11	13.89	7.78	
	5.00		-9.36	-5.71				15.40	9.30		6.10	15.40	9.30	
c	20 min	2.250	0	0.99	0.29	34.31	22.79		35.30	23.08		12.22	35.30	23.08
d	20 min	2.250				34.31	22.79		35.30	23.08		12.22	35.30	23.08
e	100 sec	2.110				33.77	22.35		34.76	22.64		12.12	34.76	22.64
	225 sec	2.275				34.43	22.89		35.42	23.18		12.24	35.42	23.18

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO.

NUMBER 5-151-P 1 A-79

SHEET 28 OF 51

DESCRIPTION: Failure Evaluation of Head Flanges and Gasket Stubs  
VESSEL: Failure  
CHECK DATE: 5-12-66 BY: AK/AM/DR

5-DETACHED ANALYSIS:  
E-STRESSES:

1- UNIFORM TENSILE

LOCATION - 2

TRANSIENT	INTERNAL PRESSURE LBS/IN <sup>2</sup>	(T <sub>in</sub> -T) OF	THERMAL STRESS		PRESSURE STRESS			TOTAL STRESS			STRESS INTENSITY			
			F <sub>x</sub>	F <sub>y</sub>	F <sub>x</sub>	F <sub>y</sub>	F <sub>r</sub>	F <sub>x</sub>	F <sub>y</sub>	F <sub>r</sub>	σ <sub>x-σ<sub>y</sub></sub>	σ <sub>x-σ<sub>r</sub></sub>	σ <sub>y-σ<sub>r</sub></sub>	
f	40 sec	2.320	0	0.99	0.29	34.66	23.07	0	35.65	23.36	0	12.29	35.65	23.36
	100 sec	2.260				34.36	22.83		35.35	23.12		12.23	35.35	23.12
	260 sec	2.140				33.77	22.35		34.76	22.64		12.12	34.76	22.64
g	2 min	2.370				34.90	23.28		35.89	23.57		12.32	35.89	23.57
	3.2 min	2.350				34.80	23.19		35.79	23.48		12.31	35.79	23.48
	10.4 min	2.150				33.82	22.39		34.81	22.68		12.13	34.81	22.68
h	10 sec	2.220				34.16	22.67		35.15	22.96		12.19	35.15	22.96
	6.5 sec	1.910				32.63	21.42		33.62	21.71		11.91	33.62	21.71
i	2.20 min	3.125	↓	0	0	38.63	26.31		38.63	26.31		12.32	38.63	26.31
j	HEATING 3.5 hrs	1.250	X	13.54	7.20	29.37	18.77		42.91	25.97		16.94	42.91	25.97
	S.S.	2.500		0.99	0.29	35.54	23.80		36.53	24.09		12.44	36.53	24.09
	COOLING 3.5 hrs	0.315		-10.87	-7.23	24.76	15.01		13.89	7.78		6.11	13.89	7.78
k	~	2.350	0	0.99	0.29	34.80	23.19		35.79	23.48		12.31	35.79	23.48
	~	2.150				33.82	22.39		34.81	22.68		12.13	34.81	22.68
l	12 sec	2.250				34.31	22.79		35.30	23.08		12.22	35.30	23.08
m	10 sec	2.760				36.83	24.84		37.82	25.13		12.69	37.82	25.13
	28 sec	2.120				33.67	22.27		34.66	22.56		12.10	34.66	22.56
	180 sec	1.440				30.31	19.53		31.30	19.82		11.48	31.30	19.82
n	33 sec	0.300				24.68	14.45		25.67	15.24		10.43	25.67	15.24
	64 sec	0.700				26.66	16.56		27.65	16.85		10.80	27.65	16.85

S.I. <sub>RANGE</sub> max = (σ<sub>x</sub>-σ<sub>r</sub>) = 47.85 ksi < 35m = 80.1 ksi (CRITERIA 5-C-2)

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-151-D OF 1 100

SHEET 29 OF 51

DATE 5-12-66 BY LOCKE

DESCRIPTION Exhaust Exhaust Manifold Head Flange CHECK DATE 5-12-66 BY ALEXANDER

CHARGE NO. \_\_\_\_\_

Vessel Flange And Closure Studs

5. DETAILED ANALYSIS:

a. STRESSES:

1. UNCOMPENSATED:

LOCATION 3

TRANSIENT	INTERNAL PRESSURE KSIH	(Tm-T) OF	THERMAL STRESS		PRESSURE STRESS			TOTAL STRESS			STRESS INTENSITY			
			$\sigma_x$	$\sigma_\theta$	$\sigma_x$	$\sigma_\theta$	$\sigma_r$	$\sigma_x$	$\sigma_\theta$	$\sigma_r$	$\sigma_x - \sigma_\theta$	$\sigma_x - \sigma_r$	$\sigma_\theta - \sigma_r$	
LOAD BOLT UP	0	0	0	0	-20.30	-4.59	0	-20.30	-4.59	0	-15.71	-20.30	-4.59	
BOLT UP + 2500 PSIH	2.5	0	0	0	-9.72	16.22	-2.50	-9.72	14.22	-2.50	-23.94	-7.22	16.72	
a Neutral	4.00 hrs.	1.882	-3.10	-26.39	-12.34	9.57	-1.19	-15.44	-16.82	-1.19	1.38	-14.25	-15.63	
	4.25	2.078	-3.09	-27.00	-11.51	11.04	-2.08	-14.60	-15.96	-2.08	1.36	-12.52	-13.88	
	4.35	2.156	-2.61	-27.35	-11.18	11.63	-2.16	-13.79	-15.72	-2.16	1.93	-11.63	-13.56	
	4.47	2.250	-1.67	-26.94	-10.78	12.34	-2.25	-12.45	-14.60	-2.25	2.15	-10.20	-12.35	
	5.00	2.250	5.31	-19.95	-10.78	12.34	-2.25	-5.47	-7.51	-2.25	2.04	-3.22	-5.26	
Steady STATE	2.250		7.48	6.30	-10.78	12.34	-2.25	-3.30	12.64	-2.25	-15.94	-1.05	14.89	
b Compression	4.00 hrs.	0.315	8.42	25.13	-18.97	-2.22	-0.32	-10.55	22.91	-0.32	-33.46	-10.23	23.23	
	4.25		7.90	25.49				-11.07	23.27	-0.32	-34.34	-10.75	23.59	
	4.35		7.55	25.38				-11.42	23.16	-0.32	-34.58	-11.10	23.48	
	4.47		8.18	26.38				-10.79	24.16	-0.32	-34.95	-10.47	24.48	
	5.00		1.27	18.87				-17.70	16.65	-0.32	-34.35	-17.38	16.97	
c	20 min	2.250	-7.8	5.08	-2.10	-10.78	12.34	-2.25	-5.70	10.24	-2.25	-15.94	-3.45	12.49
d	20 min	2.250	7.8	9.88	2.70	-10.78	12.34	-2.25	-0.90	15.04	-2.25	-15.94	1.35	17.29
e	100 sec	2.110	11.2	10.92	3.74	-11.25	11.51	-2.14	-0.33	15.25	-2.14	-15.58	1.91	17.39
	225 sec	2.275	1.7	8.00	9.82	-10.68	12.53	-2.28	-2.63	13.35	-2.28	-16.03	-0.40	15.63



COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER 5-151-P | A 81  
SHEET 30 OF 51

DESCRIPTION Failure Evaluation Of Heat Exchanger

DATE 5-12-66 BY W. J. ...

Vessel Flange And Gaslet Studs

CHECK DATE 5-12-66 BY W. J. ...

5. DETAILED ANALYSIS:  
2. STRESSES:  
1. UNCOMPENSATED:

LOCATION - 3

TRANSIENT	INTERNAL PRESSURE LBS/IN <sup>2</sup>	(T <sub>m</sub> -T) °F	THERMAL STRESS		PRESSURE STRESS			TOTAL STRESS			STRESS INTENSITY			
			F <sub>x</sub>	F <sub>θ</sub>	F <sub>x</sub>	F <sub>θ</sub>	F <sub>r</sub>	F <sub>x</sub>	F <sub>θ</sub>	F <sub>r</sub>	σ <sub>x-θ</sub>	σ <sub>x-r</sub>	σ <sub>θ-r</sub>	
f	40sec	2.320	-9.3	4.62	-2.56	-10.49	12.87	-2.32	-5.87	10.31	-2.32	-16.18	-3.55	12.63
	100sec	2.260	-13.3	3.40	-3.78	-10.74	12.41	-2.26	-7.34	8.63	-2.26	-15.97	-5.08	10.89
	260sec	2.140	-1.3	7.08	-0.10	-11.25	11.51	-2.14	-4.17	11.41	-2.14	-15.58	-2.03	13.55
g	.2 min	2.370	-12.0	3.79	-3.39	-10.27	13.24	-2.37	-6.48	9.85	-2.37	-16.33	-4.11	12.22
	3.2 min	2.350	-15.0	2.97	-4.31	-10.36	13.09	-2.35	-7.49	8.78	-2.35	-16.27	-5.14	11.13
	10.4 min	2.150	0	7.48	0.30	-11.20	11.59	-2.15	-3.72	11.89	-2.15	-15.61	-1.57	14.04
h	10sec	2.220	-9.5	4.56	-2.62	-10.91	12.11	-2.22	-6.35	9.49	-2.22	-15.84	-4.13	11.71
	65sec	1.910	8.5	10.09	2.91	-12.22	9.78	-1.91	-2.13	12.69	-1.91	-14.82	-0.22	14.60
i	220 min	3.125	0	0	0	-7.08	18.92	-3.13	-7.08	18.92	-3.13	-26.00	-3.95	22.05
j	HEATUP 3.5 hrs	1.250	X	-1.67	-26.94	-15.01	4.82	-1.25	-16.68	-22.12	-1.25	5.44	-15.43	-20.87
	S.S. 3.5 hrs	2.500		7.98	0.30	-9.72	14.22	-2.50	-2.24	14.52	-2.50	-16.56	0.26	17.02
	COOLDOWN 3.5 hrs	0.315		8.18	26.38	-18.97	-2.22	-0.32	-10.79	24.16	-0.32	-34.95	-10.47	24.48
k	~	2.350	6.0	9.32	2.14	-10.36	13.09	-2.35	-1.04	15.23	-2.35	-16.27	1.31	17.58
	~	2.150	-6.0	5.64	-1.54	-11.20	11.59	-2.15	-5.56	10.05	-2.15	-15.61	-3.41	12.20
l	18sec	2.250	33.3	17.71	10.53	-10.78	12.34	-2.25	6.93	22.87	-2.25	-15.94	9.18	25.12
m	10sec	2.760	-30.2	-1.80	-9.98	-8.62	16.18	-2.76	-10.42	7.20	-2.76	-17.62	-7.66	9.96
	26sec	2.120	-4.2	-5.17	-12.35	-11.33	11.36	-2.12	-16.50	-0.99	-2.12	-15.51	-14.38	1.13
	160sec	1.440	4.8	8.95	1.77	-14.21	6.24	-1.44	-5.26	8.01	-1.44	-13.27	-3.92	9.45
n	33sec	0.300	117	43.42	36.24	-19.03	-2.33	-0.30	24.39	33.91	-0.30	-9.52	24.69	34.21
	64sec	0.700	197	67.99	60.81	-17.34	0.68	-0.70	50.65	61.49	-0.70	-10.84	51.35	62.19

$S.I._{\text{max RANGE}} = (\sigma_{\theta} - \sigma_r) = 45.35 \text{ ksi} < 80.1 \text{ ksi} \quad \text{CONFORM S-C-2}$

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-151-P | A 82

SHEET 31 OF 51

DATE 5-12-66 BY W. K. KREUZER

DESCRIPTION Exhaust Evaluation of Head Flanges CHECK DATE 5-17-66 BY W. K. KREUZER

Wessel Flange And Closure Stubs

5. DETAILED ANALYSIS:

a. STRESSES:

1. UNLOADING/TREATER:

LOCATION 4

TRANSIENT	INTERNAL PRESSURE KSI/A	(T <sub>in</sub> -T) °F	THERMAL STRESS		PRESSURE STRESS			TOTAL STRESS			STRESS INTENSITY			
			$\sigma_x$	$\sigma_\theta$	$\sigma_x$	$\sigma_\theta$	$\sigma_r$	$\sigma_x$	$\sigma_\theta$	$\sigma_r$	$\sigma_x - \sigma_\theta$	$\sigma_x - \sigma_r$	$\sigma_\theta - \sigma_r$	
Cold Bolt Up	0	0	0	0	20.30	7.59	0	20.30	7.59	0	12.71	20.30	7.59	
Bolt Up + 2500 psia	2.5	0	0	0	28.37	25.65		28.37	25.65		2.72	28.37	25.65	
a Neutron	4.00 hrs.	1.882			-7.92	1.81	26.38	21.18				-4.53	18.46	22.99
	4.25	2.078			-8.04	1.86	27.01	22.60				-5.49	18.97	24.46
	4.35	2.156			-8.27	1.65	27.26	23.16				-5.82	18.99	24.81
	4.47	2.250			-9.52	2.02	27.56	23.84				-7.92	18.04	25.96
	5.00	2.250			-13.04	-1.64	27.56	23.84				-7.69	14.52	22.20
Steady State	2.250				-7.78	-3.21	27.56	23.84				-0.85	19.78	20.63
b Cooling	4.00 hrs.	0.315			1.78	-4.08	21.32	9.87				17.31	23.10	5.79
	4.25				1.93	-3.81						17.19	23.25	6.06
	4.35				2.99	-3.70						17.64	23.81	6.17
	4.47				2.62	-2.89						16.96	23.94	6.98
	5.00				5.37	-0.18						17.00	26.69	9.69
c	20 min	2.250	0		-7.78	-3.21	27.56	23.84				-0.85	19.78	20.63
d	20 min	2.250					27.56	23.84				-0.85	19.78	20.63
e	100 sec	2.110					27.21	23.05				-0.41	19.43	19.84
	225 sec	2.275					27.65	24.02				-0.94	19.87	20.81

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER 5-151-P A 83

SHEET 32 OF 51

DATE 5-12-66 BY CDW/ML

DESCRIPTION ENGINE Evaluation Of Head Flanges CHECK DATE 5-12-66 BY AK/ML/WR

VESSEL FLANGE AND COVER STRESS

5. DETAILED ANALYSIS:  
a. STRESSES:  
1. UNCONCENTRATED:

LOCATION - 4

TRANSIENT	OUTSIDE PRESSURE PSIA	(Tm-T) °F	THERMAL STRESS		PRESSURE STRESS			TOTAL STRESS			STRESS INTENSITY			
			Fr	Ft	Fr	Ft	Fr	Fr-fo	Ft-fr	fo-ft				
f	40sec	2.320	0	-7.78	-3.21	27.79	24.35	0	20.01	21.14	0	-1.13	20.01	21.14
	100sec	2.260				27.60	23.92		19.82	20.71		-0.89	19.82	20.71
	260sec	2.140				27.21	23.05		19.43	19.84		-0.41	19.43	19.84
g	2 min	2.370				27.95	24.71		20.17	21.50		-1.33	20.17	21.50
	3.2 min	2.350				27.89	24.57		20.11	21.36		-1.25	20.11	21.36
	10.4 min	2.150				27.24	23.12		19.46	19.91		-0.45	19.46	19.91
h	10 sec	2.220				27.47	23.63		19.69	20.42		-0.73	19.69	20.42
	65 sec	1.910				26.47	21.39		18.69	18.18		0.51	18.69	18.18
i	220 min	3.125		0	0	30.39	30.16		30.39	30.16		0.23	30.39	30.16
j	HEATUP 3.5 hrs	1.250	X	-9.52	2.02	24.34	16.62		14.82	18.64		-3.92	14.82	18.64
	5.5. COOLDOWN	2.500		-7.78	-3.21	28.37	25.65		20.59	22.44		-1.85	20.59	22.44
	3.5 hrs	0.315		2.62	-2.89	21.32	9.97		23.94	6.98		16.96	23.94	6.98
k	~	2.350	0	-7.78	-3.21	27.89	24.57		20.11	21.36		-1.25	20.11	21.36
	~	2.150				27.24	23.12		19.46	19.91		-0.45	19.46	19.91
l	12 sec	2.250				27.56	23.84		19.78	20.63		-0.85	19.78	20.63
m	10 sec	2.760				29.21	27.53		21.43	24.32		-2.89	21.43	24.32
	26 sec	2.120				27.14	22.90		19.36	19.69		-0.33	19.36	19.69
	160 sec	1.440				24.95	19.99		17.17	16.78		0.39	17.17	16.78
n	33 sec	0.300				21.27	9.76		13.49	6.55		6.94	13.49	6.55
	54 sec	0.700				22.56	12.65		14.78	9.44		5.34	14.78	9.44

SI<sub>MAX</sub> =  $\sqrt{F_x \cdot F_r} = 30.59 \text{ ksi} < 90.1 \text{ ksi}$  CRITERIA 5-C-2  
RAISE

**COMBUSTION ENGINEERING, INC.**  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-151-P A 84

SHEET 33 OF 51

DATE 5-12-66 BY W.C. REEL

CHECK DATE 5-12-66 BY ALEXANDER

DESCRIPTION Fatigue Evaluation Of Head Flange  
Vessel Flange And Closure Stubs

5. DETAILED ANALYSIS:

a. STRESSES

1. UNCONDENSED:

TRANSIENT	INTERNAL PRESSURE KPSIA	LOCATION - 5			LOCATION - 6			LOCATION - 7			LOCATION - 8		
		MECHANICAL STRESS $\sigma_x$	THERMAL STRESS $\sigma_x$	TOTAL STRESS $\sigma_x$	MECHANICAL STRESS $\sigma_x$	THERMAL STRESS $\sigma_x$	TOTAL STRESS $\sigma_x$	MECHANICAL STRESS $\sigma_x$	THERMAL STRESS $\sigma_x$	TOTAL STRESS $\sigma_x$	MECHANICAL STRESS $\sigma_x$	THERMAL STRESS $\sigma_x$	TOTAL STRESS $\sigma_x$
Load Bolt Up	0	29.91	0	29.91	43.81	0	43.81	43.31	0	43.31	5.41	0	5.41
Bolt Up + 2500 PSI	2500	50.29	0	50.29	29.61	0	29.61	57.80	0	57.80	22.10	0	22.10
a 4.00 hrs 4.25 4.35 4.47 5.00	1.882	45.25	1.01	46.26	34.12	10.68	44.80	60.40	31.39	91.79	17.97	-19.70	-1.73
	2.078	46.95	2.45	49.30	32.00	10.09	42.09	59.57	31.64	91.21	19.28	-19.10	0.18
	2.156	47.49	3.10	50.59	31.56	9.60	41.16	59.24	31.61	90.85	19.80	-18.91	0.89
	2.250	48.25	2.64	50.89	31.03	10.11	41.14	58.85	32.81	91.66	20.43	-20.06	0.37
	2.250	49.25	6.03	54.28	31.03	9.34	40.37	58.05	31.32	90.17	20.43	-15.95	4.48
STEADY STATE	2.250	49.25	0.59	49.84	31.03	1.88	32.91	58.05	-1.51	57.34	20.43	3.98	24.41
b 4.00 hrs 4.25 4.35 4.47 5.00	0.315	32.43	-2.31	30.17	42.02	-7.91	34.11	66.99	-29.11	37.88	7.54	18.89	26.43
			-3.08	29.40		-8.77	33.25		-30.78	36.21		18.93	26.47
			-3.83	28.65		-9.35	33.67		-30.68	36.31		18.50	26.04
			-4.63	27.85		-8.70	33.32		-31.22	35.77		17.89	25.43
			-8.34	24.14		-6.25	35.17		-29.76	38.23		13.57	21.11
c 20 min	2.250	49.25	0.59	49.84	31.03	1.88	32.91	58.05	-1.51	57.34	20.43	3.98	24.41
d 20 min	2.250	49.25		49.84	31.03		32.91	58.05		57.34	20.43		24.41
e 100 sec 225 sec	2.140	47.36		47.95	31.65		33.53	59.31		57.80	19.70		23.68
	2.275	48.46		49.05	30.88		32.76	59.74		57.23	20.60		24.58

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-151-1 | A85

SHEET 34 OF 51

DATE 5-12-66 BY LOCKER

DESCRIPTION FATIGUE EVALUATION OF HEAD FLANGE CHECK DATE 5-12-66 BY ALLEN  
VESSEL FAILURE AND CRACK STUDY

5. DETAILED ANALYSIS:  
Q. STRESS:  
1. LINEAR ELASTIC:

TRANSIENT	W/THERMAL PROPERTIES KSI/A	LOCATION-5			LOCATION-6			LOCATION-7			LOCATION-8			
		MECHANICAL STRESS $\sigma_x$	THERMAL STRESS $\sigma_x$	TOTAL STRESS $\sigma_x$	MECHANICAL STRESS $\sigma_x$	THERMAL STRESS $\sigma_x$	TOTAL STRESS $\sigma_x$	MECHANICAL STRESS $\sigma_x$	THERMAL STRESS $\sigma_x$	TOTAL STRESS $\sigma_x$	MECHANICAL STRESS $\sigma_x$	THERMAL STRESS $\sigma_x$	TOTAL STRESS $\sigma_x$	
f	40sec	2.320	48.83	0.59	49.62	38.63	1.88	32.51	58.55	-1.51	57.04	20.90	3.98	24.88
	100sec	2.260	48.34		48.93	30.97		32.85	58.91		57.30	20.50		24.48
	240sec	2.140	47.36		47.95	31.65		33.53	59.31		57.80	19.70		23.68
g	2 min	2.370	49.23		49.82	30.34		32.22	59.34		56.83	21.23		25.21
	3.2 min	2.350	49.07		49.66	30.46		32.34	58.43		56.92	21.10		25.08
	10.4 min	2.150	47.44		48.03	31.59		33.47	59.27		57.76	19.76		23.74
h	10 sec	2.220	49.01		48.60	31.20		33.08	58.97		57.46	20.23		24.21
	65 sec	1.910	45.48		46.07	32.96		34.84	60.28		58.77	18.16		22.14
i	280 min	3.125	55.39	0	55.39	26.05	0	26.05	55.17	0	55.17	26.27	0	26.27
j	HEAT UP 3.5 hrs	1.250	40.10	2.64	42.74	36.70	10.11	46.81	63.06	32.81	95.87	13.76	-20.26	-6.50
	S.S.	2.500	50.29	0.59	50.88	29.61	1.88	31.49	57.90	-1.51	56.29	22.10	3.98	26.08
	Cool Down 3.5 hrs	0.315	32.48	-4.63	27.85	42.02	-8.70	33.32	66.99	-31.22	35.77	7.54	17.89	25.43
k	~	2.350	49.07	0.59	49.66	30.46	1.88	32.34	58.43	-1.51	56.92	21.10	3.98	25.08
	~	2.150	47.44		48.03	31.59		33.47	59.27		57.76	19.76		23.74
l	12 sec	2.350	48.25		48.84	31.03		32.91	58.95		57.34	20.43		24.41
m	10 sec	2.760	52.41		53.00	29.13		30.01	56.70		55.19	23.84		27.82
	28 sec	2.120	47.19		47.78	31.76		33.64	59.40		57.89	19.56		23.54
	160 sec	1.440	41.65		42.24	35.63		37.51	62.25		60.74	15.02		19.00
n	33 sec	0.300	32.32		32.91	42.10		43.98	67.05		65.54	7.41		11.39
	54 sec	0.700	35.62		36.21	39.82		41.70	65.37		63.86	10.08		14.06

$S_{I,MAX} = 95.87 \text{ ks} < 110.2 \text{ ks}$  CRITERIA S-C-2

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION FATIGUE EVALUATION OF HEAD FLANGE,  
VESSEL FLANGE AND CLOSURE STUDSNUMBER 5-151-PA 86SHEET 35 OF 51DATE 5-12-66 BY COCKRELLCHECK DATE 5-12-66 BY ALEXANDER5. DETAILED ANALYSIS:c. STRESSES:2. CONCENTRATED:

FOR THE PURPOSE OF THE FATIGUE ANALYSIS, THE FOLLOWING STRESS EXPRESSIONS WILL BE USED TO CALCULATE PEAK STRESSES AT THE EIGHT LOCATIONS AS SHOWN ON SHEET-23.

POINTS 1 & 2:

$$\sigma_x = \pm \frac{6}{E_1} (M_1 + M_{T1}) K_B + \frac{H \cos \theta}{E_1} K_T + \frac{a^2 P}{2R_1 E_1} K_T + \frac{Ed}{(1-\nu)} (T_{m1} - 70) K_T$$

$$= \pm 0.06783 (M_1 + M_{T1}) K_B + 0.03654 H_1 K_T + 4.3709 P K_T + 1.42857 (T_{m1} - 70) K_T$$

$$\sigma_D = \pm \frac{\sqrt{6}}{E_1} (M_1 + M_{T1}) K_B + \frac{H \cos \theta}{E_1} + \frac{Ed_{11} + Ed_{1T}}{R_1 \sin \theta} \pm \frac{t \cos \theta (Ed_{11}^* + Ed_{1T}^*)}{2R_1 \sin \theta} + \frac{a^2 P}{2R_1 E_1} + \frac{Ed}{(1-\nu)} (T_{m1} - 70) - Ed (T_{m1} - 70)$$

$$= \pm 0.02035 (M_1 + M_{T1}) K_B + 0.01096 H_1 + 0.01189 (Ed_{11} + Ed_{1T}) \pm 2.01922 (Ed_{11}^* + Ed_{1T}^*) + 4.3709 P$$

$$+ 1.42857 (T_{m1} - 70) - Ed (T_{m1} - 70)$$

POINTS 3 & 4:

$$\sigma_x = \pm \frac{6}{E_2} (M_3 + M_{T3}) K_B + \frac{b^2 P}{2R_2 E_2} K_T + \frac{Ed}{(1-\nu)} (T_{m4} - 70) K_T$$

$$= \pm 0.05191 (M_3 + M_{T3}) K_B + 3.7296 P K_T + 1.42857 (T_{m4} - 70) K_T$$

$$\sigma_D = \pm \frac{\sqrt{6}}{E_2} (M_3 + M_{T3}) K_B + \frac{EM_{T3}}{2R_2 E_2 D_2} + \frac{Ed_{43}}{R_2} + \frac{b^2 P}{E_2} + \frac{Ed}{(1-\nu)} (T_{m4} - 70)$$

$$= \pm 0.01557 (M_3 + M_{T3}) K_B + 0.02860 M_{T3} + 0.01098 Ed_{43} + 7.94762 P + 1.42857 Ed (T_{m4} - 70)$$

POINTS 5 & 6:

$$\sigma_x = \left( \frac{T+V}{A} \right) K_T \pm \frac{\bar{M} E}{I} K_B = 0.31631 (T+V) K_T \pm 0.36236 M_2 K_B$$

POINTS 7 & 8:

$$\sigma_x = \left( \frac{T+V}{A} \right) K_T + \frac{(\bar{M} + H \cos \theta) E}{I} K_B = 0.31631 (T+V) K_T \pm 0.36236 M_2 K_B \pm 11.33489 H_2 K_B$$


## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION FATIGUE EVALUATION OF HEAD FLANGE  
VESSEL FLANGE AND CLOSURE STUDSNUMBER 5-151-P | A 87SHEET 36 OF 51DATE 5-12-66 BY COCKRELLCHECK DATE 5-12-66 BY ALEXANDER5. DETAILED ANALYSIS:e. STRESSES:2. CONCENTRATED:DETERMINATION OF STRESS CONCENTRATION FACTORS:POINT-1

$$K_T = K_D = 1$$

POINT-2

$$h = 2.181'' \quad R = 1.875''$$

$$D = 11.586''$$

$$d = 9.405''$$

$$\Delta = \frac{d}{D} = 1.232$$

FROM REFERENCE - 4, WE HAVE  
FOR TENSION

$$K_0 = 1 + \left[ \frac{1}{2.8\Delta - 2} \left( \frac{h}{R} \right)^{0.65} \right] = 1 + \left[ \frac{1}{2.8(1.232) - 2} \left( \frac{2.181}{1.875} \right)^{0.65} \right]$$

$$= 1.866$$

$$K_T = 1 + (K_0 - 1) \left[ 1 - \left( \frac{\beta}{90} \right)^{1 + 2.4\sqrt{R/h}} \right]$$

$$= 1 + (1.866 - 1) \left[ 1 - \left( \frac{33}{90} \right)^{1 + 2.4\sqrt{\frac{1.875}{2.181}}} \right]$$


$$= \underline{1.833} \quad \leftarrow$$

FOR BENDING:

$$K_0 = 1 + \left[ \frac{1}{5.37\Delta - 4.8} \left( \frac{h}{R} \right)^{0.85} \right] = 1 + \left[ \frac{1}{5.37(1.232) - 4.8} \left( \frac{2.181}{1.875} \right)^{0.85} \right] = 1.685$$

$$K_B = 1 + (K_0 - 1) \left[ 1 - \left( \frac{\beta}{90} \right)^{1 + 2.4\sqrt{R/h}} \right] = 1 + (1.685 - 1) \left[ 1 - \left( \frac{33}{90} \right)^{1 + 2.4\sqrt{\frac{1.875}{2.181}}} \right] = \underline{1.659} \quad \leftarrow$$

COMBUSTION ENGINEERING, INC. NUMBER 5-151-P A 88  
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN. SHEET 37 OF 51  
 CHARGE NO. \_\_\_\_\_ DATE 5-12-66 BY COCKRILL  
 DESCRIPTION FATIGUE EVALUATION OF HEAD FLANGE, CHECK DATE 5-12-66 BY ALEXANDER  
VESSEL FLANGE AND CLOSURE STUDS

5. DETAILED ANALYSIS:C. STRESSES:2. CONCENTRATED:POINT-3:

$$\begin{aligned} h_3 &= 1.906" & h_4 &= 6.094" \\ D_3 &= 7.281" & D_4 &= 11.469" \\ d_3 &= 5.375" & d_4 &= 5.375" \\ \Delta_3 &= \frac{D_3}{d_3} = 1.355 & \Delta_4 &= \frac{D_4}{d_4} = 2.134 \end{aligned}$$

FROM REF. 4, WE HAVE

FOR TENSION

$$K_0 = 1 + \left[ \frac{1}{2.8\Delta_3 - 2} \left( \frac{h_3}{R_3} \right) \right]^{0.65} = 1 + \left[ \frac{1}{2.8(1.355) - 2} \left( \frac{1.906}{2} \right) \right]^{0.65} = 1.663$$

$$K_T = 1 + (K_0 - 1) \left[ 1 - \left( \frac{\beta_3}{90} \right)^{1+2.4\sqrt{\frac{R}{h}}} \right] = 1 + (1.663 - 1) \left[ 1 - (0.795)^{1+2.4\sqrt{\frac{2}{1.906}}} \right] = 1.363 \leftarrow$$

FOR BENDING:

$$K_0 = 1 + \left[ \frac{1}{5.37\Delta_3 - 4.8} \left( \frac{h_3}{R_3} \right) \right]^{0.85} = 1 + \left[ \frac{1}{5.37(1.355) - 4.8} \left( \frac{1.906}{2} \right) \right]^{0.85} = 1.444$$

$$K_B = 1 + (K_0 - 1) \left[ 1 - \left( \frac{\beta_3}{90} \right)^{1+2.4\sqrt{\frac{R}{h}}} \right] = 1 + (1.444 - 1) \left[ 1 - (0.795)^{1+2.4\sqrt{\frac{2}{1.906}}} \right] = 1.243 \leftarrow$$

POINT-4:FOR TENSION:

$$K_0 = 1 + \left[ \frac{1}{2.8\Delta_4 - 2} \left( \frac{h_4}{R_4} \right) \right]^{0.65} = 1 + \left[ \frac{1}{2.8(2.134) - 2} \left( \frac{6.094}{2} \right) \right]^{0.65} = 1.841$$

$$K_T = 1 + (K_0 - 1) \left[ 1 - \left( \frac{\beta_4}{90} \right)^{1+2.4\sqrt{\frac{R}{h}}} \right] = 1 + (1.841 - 1) \left[ 1 - (0.643)^{1+2.4\sqrt{\frac{2}{6.094}}} \right] = 1.547 \leftarrow$$

FOR BENDING:

$$K_0 = 1 + \left[ \frac{1}{5.37\Delta_4 - 4.8} \left( \frac{h_4}{R_4} \right) \right]^{0.85} = 1 + \left[ \frac{1}{5.37(2.134) - 4.8} \left( \frac{6.094}{2} \right) \right]^{0.85} = 1.515$$

$$K_B = 1 + (K_0 - 1) \left[ 1 - \left( \frac{\beta_4}{90} \right)^{1+2.4\sqrt{\frac{R}{h}}} \right] = 1 + (1.515 - 1) \left[ 1 - (0.643)^{1+2.4\sqrt{\frac{2}{6.094}}} \right] = 1.335 \leftarrow$$

POINTS 5, 6, 7, 5'B:

$$K_T = K_B = 4 \leftarrow \text{(FROM PAR. N. 416.4, SECTION III NUCLEAR CODE)}$$



COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-151-P | 1 A 89

SHEET 38 OF 51

DATE 5-12-66 BY WALKER

CHECK DATE 5-12-66 BY ALEXANDER

DESCRIPTION Failure Evaluation of Head Flanges  
Vessel Flange And Pressure Stubs

- 5. Detailed Analysis:
- 8. Stresses:
- 2. Generalized:

LOCATION - 1

TRANSIENT	INTERNAL PRESSURE KSI/A	(T <sub>m</sub> -T) °F	THERMAL STRESS		PRESSURE STRESS			PEAK STRESS			STRESS INTENSITY			
			σ <sub>x</sub>	σ <sub>θ</sub>	σ <sub>x</sub>	σ <sub>θ</sub>	σ <sub>r</sub>	σ <sub>x</sub>	σ <sub>θ</sub>	σ <sub>r</sub>	σ <sub>x</sub> -σ <sub>θ</sub>	σ <sub>x</sub> -σ <sub>r</sub>	σ <sub>θ</sub> -σ <sub>r</sub>	
Cold Bolt Up	0	0	0	0	-2.150	-2.51	0	-2.150	-2.51	0	-18.99	-2.150	-2.51	
Bolt Up + 2500 PSIA	2.5	0	0	0	-11.99	6.17	-2.50	-11.99	6.17	-2.50	-19.16	-9.49	8.67	
a Heating	4.00 hrs	1.882	/	-17.50	-26.63	-14.35	4.02	-1.88	-31.85	-22.61	-1.88	-9.24	-29.97	-20.73
	4.25	2.078		-19.38	-27.99	-13.60	4.70	-2.08	-31.98	-23.28	-2.08	-8.70	-29.90	-21.20
	4.35	2.156		-18.37	-28.19	-13.31	4.97	-2.16	-31.68	-23.22	-2.16	-8.76	-29.52	-21.06
	4.47	2.250		-18.61	-28.73	-12.95	5.30	-2.25	-31.56	-23.43	-2.25	-8.13	-29.31	-21.19
	5.00	2.250		-13.80	-22.43	-12.95	5.30	-2.25	-26.75	-17.13	-2.25	-9.62	-24.50	-14.88
Steady State	2.250			-1.23	-0.59	-12.95	5.30	-2.25	-14.18	4.71	-2.25	-13.99	-11.93	6.96
b Cooling	4.00 hrs	0.315	\	14.96	24.85	-20.30	-1.42	-0.32	-5.34	23.43	-0.32	-28.77	-5.02	23.75
	4.25			16.29	25.49				-4.01	24.07	-0.32	-28.08	-3.69	24.39
	4.35			16.43	25.74				-3.87	24.32	-0.32	-28.19	-3.55	24.64
	4.47			16.80	25.89				-3.50	24.47	-0.32	-27.97	-3.18	24.79
	5.00			11.69	19.66				-8.61	18.24	-0.32	-26.85	-8.29	18.56
c	20 min	2.250	-7.8	-3.63	-2.99	-12.95	5.30	-2.25	-16.58	2.31	-2.25	-18.89	-14.33	4.56
d	20 min	2.250	7.8	1.17	1.81	-12.95	5.30	-2.25	-11.78	7.11	-2.25	-18.89	-9.53	9.36
e	100 sec	2.110	11.2	2.21	2.85	-13.37	4.92	-2.14	-11.16	7.77	-2.14	-18.93	-9.02	9.91
	225 sec	2.275	1.7	-0.71	-0.07	-12.85	5.38	-2.28	-13.56	5.31	-2.28	-14.97	-11.28	7.59

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-151-P | A 90

SHEET 39 OF 51

CHARGE NO. \_\_\_\_\_

DATE 5-12-66 BY COCKELL

DESCRIPTION FATIGUE EVALUATION OF HEAD FLANGE  
VESSEL FLANGE AND CLOSURE STUDS

CHECK DATE 5-12-66 BY ALEXANDER

5- DETAILED ANALYSIS:

e. STRESSES

2. CONCENTRATED

LOCATION - 1

TRANSIENT	INTEGRAL PRESSURE (PSIA)	TEMP (°F)	THERMAL STRESS		PRESSURE STRESS		PEAK STRESS		STRESS INTENSITY				
			F <sub>x</sub>	F <sub>y</sub>	F <sub>x</sub>	F <sub>y</sub>	F <sub>x</sub>	F <sub>y</sub>	F <sub>x</sub> -60	F <sub>y</sub> -60	F <sub>x</sub> -67	F <sub>y</sub> -67	
f	40sec	2320	-4.09	-3.45	-12.08	5.54	-2.32	-16.77	2.09	-2.32	-18.86	-14.45	4.41
	100sec	2260	-5.31	-4.67	-12.91	5.33	-2.26	-18.22	0.66	-2.26	-18.86	-15.96	2.92
	260sec	2140	-1.63	-0.99	-13.37	4.92	-2.14	-15.00	3.93	-2.14	-18.93	-12.86	6.07
g	2 min	2370	-4.92	-4.28	-12.49	5.71	-2.37	-17.41	1.43	-2.37	-18.84	-15.04	3.80
	3.2 min	2350	-5.84	-5.20	-12.57	5.64	-2.35	-18.41	0.44	-2.35	-18.85	-16.06	2.79
	10.4 min	2150	-1.23	-0.59	-13.33	4.95	-2.15	-14.56	4.36	-2.15	-19.92	-12.47	6.51
h	10 sec	2220	-4.15	-3.51	-13.06	5.19	-2.22	-17.21	1.68	-2.22	-18.89	-14.99	3.90
	65 sec	1910	1.38	2.02	-14.24	4.12	-1.91	-12.86	6.14	-1.91	-19.80	-10.95	8.05
	220 min	3125	0	0	-9.62	8.33	-3.13	-9.62	8.33	-3.13	-17.95	-6.99	11.46
j	HEATING	1250	-18.61	-28.73	-16.75	1.83	-1.25	-35.36	-24.90	-1.25	-8.46	-34.11	-25.65
	3.5 hrs	2500	-1.23	-0.59	-11.99	6.17	-2.50	-13.22	5.58	-2.50	-18.80	-10.72	8.08
	COOLING	0.315	16.80	25.89	-20.30	-1.42	-0.32	3.50	24.47	-0.32	-27.97	-3.18	24.79
k	~	2350	0.61	1.25	-12.57	5.64	-2.35	-11.96	6.89	-2.35	-18.85	-9.16	9.24
	~	2150	-3.07	-2.43	-13.33	4.95	-2.15	-16.40	2.52	-2.15	-18.92	-14.25	4.67
	125 sec	2250	9.00	9.64	-12.95	5.30	-2.25	-3.95	14.94	-2.25	-19.89	-1.70	17.19
m	10 sec	2760	-10.51	-9.87	-11.01	7.07	-2.76	-21.52	-2.90	-2.76	-19.72	-9.76	-0.04
	20 sec	2170	-13.88	-13.24	-13.44	4.85	-2.12	-27.32	-9.39	-2.12	-19.93	-25.20	-6.27
	160 sec	1490	2.24	0.88	-16.03	2.49	-1.44	-15.79	3.37	-1.44	-19.16	-14.35	4.81
n	33 sec	0.300	34.71	35.35	-20.36	-1.47	-0.30	14.35	33.88	-0.30	-19.53	-14.65	34.18
	64 sec	0.700	59.28	59.92	-18.84	-0.08	-0.70	40.44	59.84	-0.70	-19.40	-14.14	60.54

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER 5-151-P | A 91  
SHEET 40 OF 51  
DATE 5-12-66 BY ALEXANDER

DESCRIPTION FAILURE EVALUATION OF HEAD FLANGE  
LESSER FLANGE AND CASQUET STOPS

CHECK DATE 5-12-66 BY ALEXANDER

5. DETAILED ANALYSIS:  
STRESSES:  
2. COMMENTARIES:

LOCATION - 2

TRANSIENT	INTERNAL PRESSURE KSI/A	(Tm-T) OF	THERMAL STRESS		PRESSURE STRESS			PEAK STRESS			STRESS INTENSITY			
			$\sigma_x$	$\sigma_\theta$	$\sigma_x$	$\sigma_\theta$	$\sigma_r$	$\sigma_x$	$\sigma_\theta$	$\sigma_r$	$\sigma_x - \sigma_\theta$	$\sigma_x - \sigma_r$	$\sigma_\theta - \sigma_r$	
LOAD Bolt UP	0	0	0	0	38.63	18.16	0	38.63	18.16	0	20.47	38.63	18.16	
Bolt UP + 2800 PSIA	2.5	0	0	0	61.01	28.50		61.01	28.50		32.51	61.01	28.50	
a Normal	4.00 hrs.	1.802	23.13	7.76	55.40	25.94		78.61	33.70		44.91	78.61	33.70	
	4.25	2.078	24.68	8.27	57.23	26.75		81.91	35.02		46.89	81.91	35.02	
	4.35	2.156	24.62	8.17	57.93	27.08		82.55	35.27		47.28	82.55	35.27	
	4.47	2.250	25.57	6.36	58.77	27.47		84.34	33.83		50.51	84.34	33.83	
	5.00	2.250	20.54	6.07	58.77	27.47		79.31	33.56		45.75	79.31	33.56	
STEADY STATE	2.250		1.65	0.48	58.77	27.47		60.42	27.95		32.47	60.42	27.95	
b Compression	4.00 hrs.	0.315	-18.62	-5.72	41.45	19.46		22.83	13.74		9.09	22.83	13.74	
	4.25		-20.56	-6.54				20.89	12.92		7.97	20.89	12.92	
	4.35		-19.87	-6.08				21.58	13.38		8.20	21.58	13.38	
	4.47		-20.61	-6.46				20.84	13.00		7.84	20.84	13.00	
	5.00		-17.70	-5.10				23.75	14.36		9.39	23.75	14.36	
c	20 min	2.250	0	1.65	0.48	58.77	27.47		60.42	27.95		32.47	60.42	27.95
d	20 min	2.250				58.77	27.47		60.42	27.95		32.47	60.42	27.95
e	100 sec	2.110				57.79	27.01		59.44	27.49		31.95	59.44	27.49
	225 sec	2.275				59.00	27.57		60.65	28.05		32.60	60.65	28.05

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION FLATHEAD EVALUATION OF HEAD FLANGES  
VESSEL FLANGE AND CLOSURE STUDS

NUMBER 5151P | A 92

SHEET 41 OF 51

DATE 5-12-66 BY ALLENHURD

CHECK DATE 5-12-66 BY ALLENHURD

5. DETAILED ANALYSIS:

a. STRESSES:

2. CONCENTRATIONS:

LOCATION - 2

TRANSIENT	INTERNAL PRESSURE KSI/A	$(T_m - T)$ °F	THERMAL STRESS		PRESSURE STRESS			PEAK STRESS			STRESS INTENSITY			
			$F_x$	$F_y$	$F_x$	$F_y$	$F_r$	$F_x$	$F_y$	$F_r$	$F_x - F_y$	$F_x - F_r$	$F_y - F_r$	
f	40 sec	2.320	0	1.65	0.48	59.40	27.75	0	61.05	28.23	0	32.82	61.05	28.23
	100 sec	2.260				58.86	27.50		60.51	27.98		32.53	60.51	27.98
	260 sec	2.140				57.79	27.01		59.44	27.49		31.95	59.44	27.49
g	2 min	2.370				59.85	27.96		61.50	28.44		33.06	61.50	28.44
	3.2 min	2.350				59.67	27.88		61.32	28.36		32.96	61.32	28.84
	10.4 min	2.150				57.88	27.05		59.33	27.53		32.00	59.53	27.53
h	10 sec	2.220				58.50	27.34		60.15	27.82		32.33	60.15	27.82
	65 sec	1.910				55.73	26.06		57.38	26.54		30.84	57.38	26.54
i	220 min	3.125	↓	0	0	66.61	31.08		66.61	31.08		35.53	66.61	31.08
j	HEATING 3.5 hrs	1.250	X	25.57	6.36	49.02	23.33		75.39	29.69		45.70	75.39	29.69
	S.S. COOL DOWN 3.5 hrs	2.500		1.65	0.48	61.01	28.50		62.66	28.98		33.68	62.66	28.98
		0.315		-20.61	-6.46	41.45	19.46		20.84	13.00		7.84	20.84	13.00
k	~	2.350	0	1.65	0.48	59.67	27.88		61.32	28.36		32.96	61.32	28.36
	~	2.150				57.88	27.05		59.53	27.53		32.00	59.53	27.53
l	12 sec	2.250				58.77	27.47		60.42	27.95		32.47	60.42	27.95
m	10 sec	2.760				63.34	29.57		64.99	30.05		34.94	64.99	30.05
	28 sec	2.120				57.61	26.93		59.26	27.41		31.85	59.26	27.41
	160 sec	1.490				51.52	24.12		53.17	24.60		29.57	53.17	24.60
n	33 sec	0.300				41.32	19.40		42.97	19.88		23.09	42.97	19.88
	54 sec	0.700				44.90	21.06		46.55	21.54		25.01	46.55	21.54

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER 5-157-1 | A 93

SHEET 42 OF 51

DATE 5-12-66 BY WATTELL

DESCRIPTION Engine Evaluation of Lean Engine CHECK DATE 5-12-66 BY Alexander

Vessel Furnace And Exhaust Stubs

5. DETAILED ANALYSIS:

a. STRESSES:

2. COMMENTED:

LOCATION - 3

TRANSIENT	INTERVAL PRESSURE KSI/A	(Tm-T) °F	THERMAL STRESS		PRESSURE STRESS			PEAK STRESS			STRESS INTENSITY			
			$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$\sigma_r$	$\sigma_x$	$\sigma_y$	$\sigma_r$	$\sigma_x - \sigma_y$	$\sigma_y - \sigma_r$	$\sigma_x - \sigma_r$	
Cold Bolt Up	0	0	0	0	-25.23	-6.07	0	-25.23	-6.07	0	-19.16	-25.23	-6.07	
Bolt Up + 2500 PSIA	2.5	0	0	0	-10.93	12.83	-2.50	-10.96	12.83	-2.50	-23.79	-9.46	15.33	
a Normal	4.00 hrs	1.832	-7.05	-24.67	-14.49	8.16	-1.88	-21.54	-16.51	-1.88	-5.03	-19.66	-14.63	
	4.25	2.078	-7.12	-25.24	-13.37	9.64	-2.08	-20.49	-15.60	-2.08	-4.89	-19.41	-13.52	
	4.35	2.156	-6.54	-25.55	-12.93	10.23	-2.16	-19.47	-15.32	-2.16	-4.15	-17.31	-13.16	
	4.47	2.250	-5.43	-25.02	-12.39	10.94	-2.25	-17.82	-14.08	-2.25	-3.74	-15.57	-11.83	
	5.00	2.250	4.10	-17.95	-12.39	10.94	-2.25	-8.29	-7.01	-2.25	-1.28	-6.04	-4.76	
Steady State	2.250		9.18	0.41	-12.39	10.94	-2.25	-3.21	11.85	-2.25	-15.00	-0.96	14.10	
b Compression	4.00 hrs	0.315	13.41	23.95	-23.43	-3.69	-0.32	-10.02	20.26	-0.32	-30.28	-9.70	20.58	
	4.25		12.76	24.28				-10.67	20.59	-0.32	-31.26	-10.35	20.91	
	4.35		12.35	24.13				-11.08	20.44	-0.32	-31.52	-10.76	20.76	
	4.47		13.19	25.15				-10.24	21.46	-0.32	-31.70	-9.92	21.78	
	5.00		3.72	17.67				-19.71	13.98	-0.32	-33.69	-19.39	14.30	
c	20 min	2.250	-7.8	4.79	-3.48	-12.39	10.94	-2.25	-7.60	7.46	-2.25	-15.06	-5.35	9.71
d	20 min	2.250	7.8	13.57	5.30	-12.39	10.94	-2.25	-1.18	16.24	-2.25	-15.06	3.43	18.49
e	100 sec	2.110	11.2	15.49	7.22	-13.02	10.11	-2.14	2.47	17.33	-2.14	-14.86	4.61	19.47
	225 sec	2.275	1.7	10.14	1.87	-12.25	11.13	-2.28	-2.11	13.00	-2.28	-15.11	0.17	15.28

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-151-1 | A 94

SHEET 43 OF 51

CHARGE NO. \_\_\_\_\_

DATE 5-12-66 BY CG

DESCRIPTION ENTIRE EXAMINATION OF HEAD FLANGE  
VESSEL FLANGE AND CLOSURE STUDS

CHECK DATE 5-17-66 BY MS

5. DETAILED ANALYSIS:

e. STRESSES:

2. CONCENTRATED:

LOCATION - 3

Transient	Inservice Pressure (lb/ft <sup>2</sup> )	Temperature (°F)	Thermal Stress		Pressure Stress			Peak Stress			Stress Intensity		
			F <sub>x</sub>	F <sub>y</sub>	F <sub>x</sub>	F <sub>y</sub>	F <sub>z</sub>	F <sub>x</sub>	F <sub>y</sub>	F <sub>z</sub>	F <sub>x</sub> -F <sub>y</sub>	F <sub>x</sub> -F <sub>z</sub>	F <sub>y</sub> -F <sub>z</sub>
f	40sec 2,320	-9.3	3.94	-4.33	-11.94	11.47	-2.32	7.14	-8.05	-2.32	-15.19	-5.73	9.46
	10sec 2,260	-13.3	1.69	-6.58	-12.33	11.02	-2.26	4.44	-10.68	-2.26	-15.05	-9.33	6.70
	260sec 2,140	-1.3	8.45	0.18	-13.02	10.11	-2.14	10.29	-4.57	-2.14	-14.90	-2.43	12.43
g	2 min 2,370	-12.0	2.42	-5.85	-11.71	11.95	-2.37	6.00	-9.29	-2.37	-15.29	-6.92	9.37
	3.2 min 2,350	-15.0	0.74	-7.53	-11.82	11.70	-2.35	4.17	-11.08	-2.35	-15.25	-9.73	6.52
	10.4 min 2,150	0	9.18	0.91	-12.96	10.19	-2.15	11.10	-3.78	-2.15	-14.82	-1.63	13.25
h	10sec 2,220	-9.5	3.93	-4.44	-12.56	10.71	-2.22	6.27	-8.73	-2.22	-15.00	-6.51	9.49
	6.5sec 1,910	3.5	12.97	5.70	-14.33	9.37	-1.91	14.07	-0.36	-1.91	-14.43	1.55	15.93
i	230 min 3,125	0	0	0	-7.40	17.56	-3.13	17.40	-7.40	-3.13	-24.96	-4.27	20.69
	1-250 2.5 hrs		-5.43	-25.02	-19.10	3.38	-1.25	-23.53	-21.64	-1.25	-1.89	-22.29	-20.39
j	5.5 2,500 600 min 0.315		9.18	0.91	-10.93	12.83	-2.50	13.74	-1.75	-2.50	-15.49	0.15	16.24
	2.5 sec		13.19	25.12	-23.43	-3.69	-0.32	-10.24	21.46	-0.32	-31.70	-9.92	21.78
k	~ 2,350	6.0	12.56	4.29	-11.82	11.70	-2.35	0.74	15.99	-2.35	-15.25	3.09	19.34
	~ 3,500	-6.0	5.90	-2.47	-12.96	10.19	-2.15	7.72	-7.16	-2.15	-14.82	-5.01	9.87
l	12.5 sec 2,250	33.3	27.93	19.46	-12.39	10.94	-2.25	15.54	30.60	-2.25	-15.06	17.79	32.55
	10 sec 2,760	-30.2	-7.82	-16.09	-9.45	14.80	-2.76	-17.30	-1.29	-2.76	-16.01	-14.54	1.47
m	26.5 sec 2,120	-41.2	-14.02	-22.29	-13.13	9.96	-2.72	-27.15	-12.33	-2.72	-14.82	-25.33	-10.21
	16.5 sec 1,440	4.8	11.22	5.61	-17.01	4.82	-1.40	-5.13	3.43	-1.40	-13.56	-3.69	9.87
n	33.5 sec 0,300	117	75.05	66.78	-23.52	-3.80	-0.30	51.53	62.98	-0.30	-11.45	51.93	63.28
	54 sec 0,760	197	122.09	111.82	-21.24	-0.78	-0.70	90.85	111.04	-0.70	-12.19	99.55	111.74

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER 5-151-P / 1 A 95

SHEET 44 OF 51

DATE 5-12-66 BY WARRICK

CHECK DATE 5-12-66 BY ALEXANDER

DESCRIPTION Exhaust Expansion of Heavy Engines  
Washer Flange And Closure Studs

5. Detailed Analysis:  
9. Stresses:  
2. Commentated:

LOCATION - 4

TRANSIENT	INTERNAL PRESSURE KSI/A	(T <sub>int</sub> -T) °F	THERMAL STRESS		PRESSURE STRESS			PEAK STRESS			STRESS INTENSITY			
			σ <sub>x</sub>	σ <sub>θ</sub>	σ <sub>x</sub>	σ <sub>θ</sub>	σ <sub>r</sub>	σ <sub>x</sub>	σ <sub>θ</sub>	σ <sub>r</sub>	σ <sub>x</sub> -σ <sub>θ</sub>	σ <sub>x</sub> -σ <sub>r</sub>	σ <sub>θ</sub> -σ <sub>r</sub>	
Cold Bolt Up	0	0	0	0	27.10	9.63	0	27.10	9.63	0	17.47	27.10	9.63	
Bolt Up + 2500 PSIA	2.5	0	0	0	39.55	27.56		39.55	27.56		11.99	39.55	27.56	
a Heating	4.00 hrs	1.882	-7.25	-0.56	36.48	23.13		29.23	22.57		6.66	29.23	22.57	
	4.25	2.078	-7.31	-0.57	37.45	24.54		30.14	23.97		6.17	30.14	23.97	
	4.35	2.156	-7.55	-0.84	37.84	15.47		30.29	24.25		6.04	30.29	24.25	
	4.47	2.250	-9.14	-0.62	38.31	25.77		29.17	25.15		4.02	29.17	25.15	
	5.00	2.250	-14.63	-4.26	38.31	25.77		23.68	21.51		2.17	23.68	21.51	
STEADY STATE	2.250		-10.26	-4.05	38.31	25.77		28.05	21.72		6.33	28.05	21.72	
b Cooling	4.00 hrs	0.315	-0.66	-2.46	28.67	11.89		28.01	9.43		18.58	28.01	9.43	
	4.25		-0.55	-2.14				28.12	9.75		18.37	28.12	9.75	
	4.35		0.21	-1.96				28.88	9.91		18.97	28.88	9.91	
	4.47		0.45	-1.19				29.12	10.70		18.42	29.12	10.70	
	5.00		4.90	1.48				33.47	13.37		20.10	33.47	13.37	
c	20 min	2.250	0	-10.26	-4.05	38.31	25.77		28.05	21.72		6.33	28.05	21.72
d	20 min	2.250				38.31	25.77		28.05	21.72		6.33	28.05	21.72
e	100 sec	2.110				37.76	24.98		27.50	20.93		6.57	27.50	20.93
	225 sec	2.275				38.43	25.95		28.17	21.90		6.27	28.17	21.90

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER 5-151P | A-96  
SHEET 45 OF 51

DESCRIPTION Engine Evaluation Of Head Features  
Vessel Flange And Closure Studs

DATE 5-12-66 BY W. J. L.  
CHECK DATE 5-12-66 BY ALEXANDER

5. DETAILED ANALYSIS  
a. STRESSES;  
1. CONCENTRATED:

LOCATION - 4

TRANSIENT	UNIFORM PRESSURE PSIA	$(T_m - T)$ °F	THERMAL STRESS		RESIDUAL STRESS			PEAK STRESS			STRESS INTENSITY			
			$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\sigma_x - \sigma_y$	$\sigma_x - \sigma_z$	$\sigma_y - \sigma_z$	
f	40sec	2.320	0	-10.26	-4.05	38.66	26.27	0	28.40	22.22	0	6.18	28.40	22.22
	100sec	2.260				38.36	25.94		28.10	21.79		6.31	29.10	21.79
	260sec	2.140				37.76	24.98		27.50	20.93		6.57	27.50	20.93
g	2 min	2.370				38.91	26.63		28.65	22.58		6.07	28.65	22.58
	3.2 min	2.350				38.91	26.49		28.55	22.44		6.11	28.55	22.44
	10.9 min	2.150				37.81	26.05		27.55	21.00		6.55	27.55	21.00
h	10 sec	2.220				38.16	25.55		27.90	21.50		6.40	27.90	21.50
	65 sec	1.910				36.16	23.33		26.35	19.28		7.07	26.35	19.28
c	220 min	3.125	↓	0	0	42.67	32.05		42.67	32.05		10.62	42.67	32.05
j	HEATUP 3.5 hrs	1.250	X	-9.14	-0.62	33.33	18.59		24.19	17.97		6.22	24.19	17.97
	S.S. Cool Down 3.5 hrs	2.500		-10.26	-4.05	39.55	27.56		29.29	23.51		5.78	29.29	23.51
		0.315		0.45	-1.19	29.67	11.89		29.12	10.70		18.42	29.12	10.70
k	~	2.350	0	-10.26	-4.05	38.91	26.49		28.55	22.44		6.11	28.55	22.44
	~	2.150				37.81	25.05		27.55	21.00		6.55	27.55	21.00
l	12 sec	2.250				38.31	25.77		29.05	21.72		6.33	28.05	21.72
m	10 sec	2.760				40.85	29.43		30.59	25.38		6.21	30.59	25.38
	28 sec	2.170				37.66	24.84		27.40	20.79		6.61	27.40	20.79
	160 sec	1.490				34.27	19.96		24.01	15.91		8.10	24.01	15.91
n	33 sec	0.300				28.59	11.78		18.33	7.73		10.60	18.33	7.73
	54 sec	0.700				30.59	14.65		20.33	10.60		9.73	20.33	10.60



COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-151-P | A 97

SHEET 46 OF 51

DATE 5-12-66 BY LOCKE

CHECK DATE 5-12-66 BY ALEXANDER

CHARGE NO.

DESCRIPTION FATIGUE EVALUATION OF HEAD FLANGES  
LESSER FLANGES AND GASCKET STUDS

5. DETAILED ANALYSIS:

a. STRESSES:

2. CONDENSED:

TRANSIENT	LOCATION-5	LOCATION-6	LOCATION-7	LOCATION-8	
	$\bar{\sigma}_x$	$\bar{\sigma}_x$	$\bar{\sigma}_z$	$\bar{\sigma}_z$	
f	40 sec	197.68	130.04	228.16	99.52
	100 sec	195.72	131.40	229.20	97.92
	260 sec	191.80	134.12	231.20	94.72
g	2 min	199.28	128.88	227.32	100.84
	3.2 min	198.64	129.36	227.68	100.32
	8.4 min	192.12	133.88	231.04	94.96
h	10 sec	192.80	132.32	229.84	96.84
	65 sec	184.28	139.36	235.08	88.56
i	220 min	221.56	104.20	220.68	105.08
j	HEATUP 3.5 hrs	170.96	137.24	383.48	-26.00
	S.S.	203.52	125.96	225.16	104.32
	COOLDOWN 3.5 hrs	111.40	133.28	143.08	101.72
k	~	198.64	129.36	227.68	100.32
	~	192.12	133.88	231.04	94.96
l	12 sec	195.36	131.64	229.36	97.64
m	10 sec	212.00	120.04	220.76	111.28
	28 sec	191.12	134.56	231.56	94.16
	160 sec	168.96	150.04	242.96	76.00
n	33 sec	131.64	175.92	262.16	45.56
	54 sec	144.84	166.80	255.44	56.24

TRANSIENT	LOCATION-5	LOCATION-6	LOCATION-7	LOCATION-8	
	$\bar{\sigma}_x$	$\bar{\sigma}_x$	$\bar{\sigma}_z$	$\bar{\sigma}_z$	
COOL BOLT-UP	119.64	175.24	273.24	21.64	
BOLT-UP + 2500 PSI	201.16	118.44	231.20	88.40	
a HEATING	4.00 hrs	185.04	179.20	367.16	-6.92
	4.25 hrs	197.20	168.36	364.84	0.72
	4.35	202.36	164.64	363.40	3.56
	4.47	203.56	164.56	366.64	1.48
	5.00	217.12	161.48	360.68	17.92
STEADY STATE	195.36	131.64	229.36	97.64	
b COOLING	4.00 hrs	120.68	136.44	151.52	105.72
	4.25	117.60	133.00	144.84	105.88
	4.35	114.60	134.68	145.24	104.16
	4.47	111.40	133.28	143.08	101.72
	5.00	96.56	140.68	152.92	84.44
c	20 min	195.36	131.64	229.36	97.64
d	20 min	195.36	131.64	229.36	97.64
e	100 sec	191.80	134.12	231.20	94.72
	225 sec	196.20	131.04	228.92	98.32

COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-151-P | A98

SHEET 47 OF 51

CHARGE NO. \_\_\_\_\_

DATE 5-12-66 BY COXPELL



DESCRIPTION FATIGUE EVALUATION OF HEAD FLANGE  
VESSEL FLANGE AND CLOSURE STUDS

CHECK DATE 5-12-66 BY ALEXANDER

5. DETAILED ANALYSIS:

f. FATIGUE EVALUATION:

( $\sigma_o - \sigma_r$ ) At LOADING - 1



S <sub>MAX</sub>	S <sub>MIN</sub>	NUMBER OF OCCURRENCES	S <sub>AFT</sub>	N <sup>*</sup>	U
60.54	-25.65	5	43.1	6600	0.00075
24.79	-21.20	195	23.0	56000	0.00348
17.19	-6.27	80	11.7	∞	0

\* FROM FIG. N-15(A)  
REFERENCE 1

U<sub>TOTAL</sub> = 0.00423

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-151-P | A 99  
SHEET 48 OF 51

CHARGE NO. \_\_\_\_\_



DATE 5-12-66 BY COCKERELL

DESCRIPTION FATIGUE EVALUATION OF HEAD FLANGE  
VESSEL FLANGE AND CLOSURE STUDS

CHECK DATE 5-12-66 BY ALEXANDER

5. DETAILED ANALYSIS:

f. FATIGUE EVALUATION:



S <sub>MAX</sub>	S <sub>MIN</sub>	NUMBER OF OCCURRENCES	S <sub>Avg</sub>	N*	U
84.34	0	40	42.2	7000	0.00571
84.34	20.84	160	31.8	18000	0.00888
75.38	20.84	5	27.3	30000	0.00016
66.61	38.63	5	14.0	60000	0.00001
64.99	42.97	5	11.0	∞	0

\* FROM FIG. N-415(A)  
REFERENCE 1

Overall = 0.01476

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-151-P | A100

SHEET 49 OF 51

CHARGE NO. \_\_\_\_\_



DATE 5-12-66 BY COCKRELL

DESCRIPTION FATIGUE EVALUATION OF HEAD FLANGE  
VESSEL FLANGE AND CLOSURE STUDS

CHECK DATE 5-12-66 BY ALEXANDER

5- DETAILED ANALYSIS:

f- FATIGUE EVALUATION:



S <sub>MAX</sub>	S <sub>MIN</sub>	NUMBER OF OCCURRENCES	S <sub>AUT</sub>	N <sup>#</sup>	U
111.74	-20.39	5	66.1	2000	0.00250
32.35	-14.63	80	23.7	51000	0.00156
21.78	-14.63	115	18.2	140000	0.00082
19.47	-10.21	80	14.8	400000	0.00020
20.69	-6.07	5	13.4	800000	0.00001
19.47	6.52	200	6.5	∞	0

\* FROM FIG. N-415 (A)  
REFERENCE 1

U<sub>OVERALL</sub> = 0.00508

**COMBUSTION ENGINEERING, INC.**  
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-151-P | A 101

SHEET 50 OF 51

CHARGE NO. \_\_\_\_\_

DATE 5-12-66 BY COCKRELL



DESCRIPTION FATIGUE EVALUATION OF HEAD FLANGE  
VESSEL FLANGE AND CLOSURE STUDS

CHECK DATE 5-12-66 BY ALEXANDER

5. DETAILED ANALYSIS:

f. FATIGUE EVALUATION:

( $\sigma_o - \sigma_f$ ) AT LOCATION -4



$S_{max}$	$S_{min}$	NUMBER OF OCCURRENCES	SALT	$N^*$	$U$
32.05	0	5	16.1	260000	0.00002
25.38	0	80	12.7	∞	0

\* FROM FIG. N-415(A)  
 REFERENCE 1

$U_{OVERALL} = 0.00002$

COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-151-P

A 102

SHEET 51 OF 51

CHARGE NO. \_\_\_\_\_


DATE 5-12-66 BY CRIBELL

DESCRIPTION FATIGUE EVALUATION OF HEAD FLANGE  
VESSEL FLANGE AND CLOSURE STUDS

CHECK DATE 5-12-66 BY ALEXANDER

5. DETAILED ANALYSIS:

F. FATIGUE EVALUATION:



S <sub>MAX</sub>	S <sub>MIN</sub>	S <sub>AUT</sub>	Seq	Number Of Occurrences	N	U	* N = 5.7 [ 10 <sup>4</sup> / (2S <sub>seq</sub> - 10 <sup>4</sup> ) ] <sup>2</sup>
383.48	0	191.74	191.74	5	218	0.02794	For Seq. > 78 KSI
367.16	0	183.58	183.58	35	246	0.14228	
367.16	143.08	112.04	112.04	165	1140	0.14473	N = [ 10 <sup>4</sup> / (3S <sub>seq</sub> - 10 <sup>4</sup> ) ] <sup>2</sup>
273.24	220.68	26.28	92.31	5	2450	0.00204	For Seq. ≤ 78 KSI
262.16	220.76	20.70	62.61	5	12960	0.00038	SEE N-4.16.2 OF REF. 1
242.96	220.76	11.10	42.86	75	122436	0.00061	
235.08	227.32	7.76	33.16	200	∞	0	U <sub>OVERALL</sub> = 0.31298

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-210-P | A 103

SHEET 4 OF 14

CHARGE NO. \_\_\_\_\_

DATE 10-15-65 BY COCKRELL

DESCRIPTION NOZZLE CODE CALCULATION


CHECK DATE 10-20-65 BY FERRISON

5- DETAILED ANALYSIS:

a. REINFORCEMENT CALCULATIONS:

1- INLET NOZZLE:

A CROSS-SECTION OF THE INLET NOZZLE IS SHOWN BELOW.  
CERTAIN DIMENSIONS ARE GIVEN TO FACILITATE THE ANALYSIS



THE GENERAL PROCEDURE FOR INSURING ADEQUATE REINFORCEMENT IS OUTLINED IN PARAGRAPHS N-451 THRU N-456 OF THE SECTION III NUCLEAR CODE

THE MINIMUM REQUIRED SHELL THICKNESS IS:

$$t_{REQ} = \frac{PR}{S_m - 0.5P} = \frac{2.5(85.98)}{26.7 - 1.25} = \underline{8.393"}$$

THE REQUIRED NOZZLE THICKNESS IS:

$$R = \frac{17.766 - 10.25 \tan 6^\circ}{\cos 6^\circ} = \frac{17.766 - 10.25(0.1051)}{0.99452} = \underline{16.728"}$$

$$t_{REQ} = \frac{PR}{S_m - 0.5P} = \frac{2.5(16.728)}{26.7 - 1.25} = \underline{1.643"}$$

SEE ARTICLE I-110  
OF APPENDIX I  
OF SECTION III

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-210-P | A 104

SHEET 5 OF 14

CHARGE NO. \_\_\_\_\_

DATE 10-15-65 BY COMBELL

DESCRIPTION NOZZLE CODE CALCULATION

CHECK DATE 10-20-65 BY FERRISON

5. DETAILED ANALYSIS:

a. - REINFORCEMENT CALCULATION:

1. INLET NOZZLE:

FROM PARAGRAPH N-452, THE AREA REMOVED IS GIVEN BY:

$$A_0 = d t_r F = 2(17.544)(8.393)(1) + [(1.75)^2(1 - \frac{2}{3})]2 = 295.81 \text{ in}^2$$

WHERE:

$d$  = AVERAGE DIA. OF HOLE THRU CODE THICKNESS OF SHELL

$t_r$  = CODE THICKNESS OF SHELL

$F$  = SEE FIGURE 452 OF SECTION III

CONSIDER THE LIMITS OF COMPENSATION AS OUTLINED IN N-454:

THE LIMIT OF REINFORCEMENT ALONG THE VESSEL WALL IS THE LARGER OF:

1- THE DIAMETER OF THE OPENING IN THE CORRODED CONDITION  
= 35.088"

2- THE SUM OF THE FINISHED CORRODED RADIUS, THE ACTUAL BASE METAL VESSEL SHELL THICKNESS, AND THE THICKNESS OF THE NOZZLE WALL =  $17.544 + 10.75 + 10.686 = 38.980$ " ← USE

THE LIMIT OF REINFORCEMENT MEASURED NORMAL TO THE VESSEL SHALL BE EQUAL TO,

$$\bar{H} = 0.5 \sqrt{r_m t} + 0.5 R_2 = 0.5 \sqrt{(21.657)(10.686)} + 0.5(5.375) \\ = 10.294"$$

$$r_m = \text{MEAN NOZZLE RADIUS} = \frac{16.314 + 27}{2} = 21.657"$$

$$t = \text{NOMINAL NOZZLE WALL THICKNESS} = 10.686"$$

$$R_2 = \text{TRANSITION RADIUS BETWEEN NOZZLE \& VESSEL WALL} = 5.375"$$



COMBUSTION ENGINEERING, INC.  
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-210-A | A 105  
 SHEET 6 OF 14  
 CHARGE NO. \_\_\_\_\_ DATE 10-16-65 BY COCKPELL  
 DESCRIPTION NOZZLE CODE CALCULATIONS CHECK DATE 10-20-65 BY FERRISON

5. DETAILED ANALYSIS:a. REINFORCEMENT CALCULATIONS:1. INLET NOZZLE:

THE TOTAL AREA OF REINFORCEMENT CONSISTS OF THE THREE AREAS DESIGNATED  $a_1$ ,  $a_2$ , AND  $a_3$  ON SHEET-4.

$$\begin{aligned} a_1 &= 2(38.980 - 16.979)(2.357) - (2.23)(0.853) = 101.81 \text{ in}^2 \\ a_2 &= 2(27 - 17.966)(10.294) = 185.99 \text{ in}^2 \\ a_3 &= 2(5.375)(1 - \frac{\pi}{4}) = 12.90 \text{ in}^2 \\ a_{\text{TOTAL}} &= 300.20 \text{ in}^2 \end{aligned}$$

$$a_{\text{TOTAL}} = 300.2 > 295.8 \quad \therefore \text{ADEQUATE REINFORCEMENT IS PROVIDED}$$

NOTE THAT  $\frac{2}{3}$  OF THE REQUIRED REINFORCEMENT MUST BE WITHIN THE LIMIT,

$$r + 0.5\sqrt{Rt}$$

WHERE:

$R$  = THE MEAN SHELL RADIUS = 91.032"

$t$  = THE NOMINAL VESSEL THICKNESS = 10.75"

$r$  = THE INSIDE NOZZLE RADIUS = 16.314"

$$r + 0.5\sqrt{Rt} = 16.314 + 0.5\sqrt{(91.032)(10.75)} = 31.955"$$

$$\begin{aligned} \text{AREA OUTSIDE LIMIT} &= 2(38.980 - 31.955)(2.357) - (2.23)(0.853) \\ &= 31.21 \text{ in}^2 \end{aligned}$$

$$\frac{31.21}{300.20} = 0.10$$

$\therefore$  LESS THAN  $\frac{1}{3}$  OF REINFORCEMENT IS OUTSIDE OF THE LIMIT - REQUIREMENT SATISFIED.



COMBUSTION ENGINEERING, INC.  
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.  
 CHARGE NO. \_\_\_\_\_  
 DESCRIPTION NOZZLE CODE CALCULATION

NUMBER 5-210-7 | A 107  
 SHEET 8 OF 14  
 DATE 10-15-65 BY CARROLL  
 CHECK DATE 10-20-65 BY FERGUSON

5. DETAILED ANALYSIS:a. REINFORCEMENT CALCULATIONS:2. OUTLET NOZZLE:AREA REMOVED:

$$A_0 = d t_r F = 2(16.783)(8.373)(1) = 281.72 \text{ in}^2$$

LIMIT OF REINFORCEMENT:1. ALONG VESSEL WALL (LARGER DIA):

a. DIAMETER OF OPENING IN THE CORRODED CONDITION  
 = 33.566 "

b. FINISHED CORRODED RADIUS + VESSEL THICKNESS +  
 NOZZLE WALL THICKNESS = 16.783 + 10.75 + 10.092  
 = 37.575" ← USE

2. NORMAL TO VESSEL WALL:

$$\bar{H} = 0.5\sqrt{r_m t} + 0.5R_2 = 0.5\sqrt{(19.979)(10.092)} + 0.5(5.375)$$

$$= 9.770 "$$

AREA OF REINFORCEMENT:

$$a_1 = 2[2438(5.297) - (1.094)^2(1 - \frac{7}{8})] = 25.31$$

$$a_2 = 2(37.575 - 15.835)(2.357) - (1.825)(.315) = 102.48$$

$$a_3 = 2(4.937)(25 - 16.749) + 2(4.823)(25 - 16.143) = 167.08$$

$$a_4 = 2(5.375)^2(1 - \frac{7}{8}) = 12.40$$

$$307.27 \text{ in}^2$$

$$A_{TOTAL} = 307.27 \text{ in}^2 > 281.72 \text{ in}^2 \therefore \text{ADEQUATE REINFORCEMENT}$$

2/3 AREA REQUIREMENT

$$\text{LIMIT} = r + 0.5\sqrt{r t} = 30.599 \text{ in}$$

$$\text{AREA OUTSIDE LIMIT} = 32.625$$

$$\frac{32.625}{307.27} = 0.11 \therefore \text{REQUIREMENT SATISFIED}$$

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-210-P | A 108

SHEET 9 OF 14

DATE 10-15-65 BY COOKRELL

CHARGE NO. \_\_\_\_\_  
DESCRIPTION NOZZLE CODE CALCULATION

CHECK DATE 10-20-65 BY FEEGUSON

5- DETAILED ANALYSIS:


b- NOZZLE SPACING:

INLET, OUTLET, & VENT NOZZLES:

IN ORDER TO USE THE STRESS INDEX METHOD OF STRESS EVALUATION, THE REQUIREMENTS OF ARTICLE I-6, I-613 MUST BE SATISFIED. THE APPLICABLE PORTIONS OF SECTION I-613 ARE CONSIDERED BELOW.


I-613-b: STATES THAT THE ARC DISTANCE MEASURED BETWEEN THE CENTER LINES OF ADJACENT NOZZLES MEASURED ALONG THE INSIDE SURFACE OF THE SHELL SHALL NOT BE LESS THAN

- 1- THREE TIMES THE SUM OF THEIR INSIDE RADII FOR OPENINGS IN A HEAD,
- 2- TWO TIMES THE SUM OF THEIR INSIDE RADII FOR OPENINGS ALONG THE CIRCUMFERENCE OF A CYLINDRICAL SHELL.



INLET & OUTLET NOZZLES

$R = 85.656''$   
 $r_{OUTLET} = 16.575''$   
 $r_{INLET} = 17.420''$



VENT NOZZLE

$R = 86''$   
 $r_{VENT HOUSING} = 2''$   
 $r_{VENT NOZ.} = 0.781''$

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION NOZZLE CODE CALCULATION

NUMBER 5-210-P | A 109

SHEET 10 OF 14

DATE 10-15-65 BY COCKRELL

CHECK DATE 10-20-65 BY FERGUSON

5. DETAILED ANALYSIS:

b. NOZZLE SPACING

INLET, OUTLET & VENT NOZZLES:

I-613-b (cont'd):

	$\alpha$ (ACTUAL)	$\alpha^*$ (REQUIRED)
2 INLET NOZZLES	46°	46.609°
2 OUTLET NOZZLES	44°	44.348°
1 INLET 1 OUTLET	45°	45.479°
VENT NOZ. (C.R. HOUSING)	5.622°	5.059°

$$\alpha^* \geq \frac{2(r_1 + r_2)(100)}{R} \left(\frac{\%}{\text{IN}}\right) \quad (\text{FOR INLET \& OUTLET NOZZLES})$$

$$\alpha^* \geq \frac{3(r_1 + r_2)(100)}{R} \left(\frac{\%}{\text{IN}}\right) \quad (\text{FOR VENT NOZZLE})$$

WE SEE FROM THIS TABLE THAT ALL NOZZLES MEET THE SPACING REQUIREMENT EXCEPT BY A NEGLIGIBLE AMOUNT (LESS THAN 1%).

I-613-c: STATES THAT,

- 1- THE RATIO OF THE INSIDE SHELL DIAMETER TO THE SHELL THICKNESS SHALL NOT EXCEED <sup>(a)</sup> 100 FOR CYLINDRICAL SHELLS AND <sup>(b)</sup> 100 FOR SPHERICAL SHELLS
- 2- THE RATIO OF THE INSIDE NOZZLE DIAMETER TO THE INSIDE SHELL DIAMETER SHALL NOT EXCEED 0.5

	CONDITION 1	CONDITION 2
INLET NOZZLE	15.9 < 100	0.203 < 0.5
OUTLET NOZZLE	15.9 < 100	0.194 < 0.5
VENT NOZZLE	24.6 < 100	0.006 < 0.5

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-210-P | A 110  
SHEET 11 OF 14  
DATE 10-15-65 BY COCKRILL  
CHECK DATE 10-20-65 BY FERGUSON


CHARGE NO. \_\_\_\_\_  
DESCRIPTION NOZZLE COOE CALCULATIONS

5. DETAILED ANALYSIS:

b. NOZZLE SPACING:

INLET, OUTLET & VENT NOZZLE:

SHOWN BELOW ARE CERTAIN DIMENSIONS FOR THE INLET, OUTLET AND VENT NOZZLES WHICH MUST MEET CERTAIN VALUES IN I-613-d → f.



I-613-d STATES THAT  $r_1$  MUST BE BETWEEN 0.1 AND 0.5 TIMES THE SHELL THICKNESS

NOZZLE	$r_1$ (ACTUAL)	$r_1$ (REQ)
INLET	1.75	$1.08 \leq r_1 \leq 5.38$
OUTLET	1.094	$1.08 \leq r_1 \leq 5.38$
VENT	0.75	$0.7 \leq r_1 \leq 3.5$

$0.1t \leq r_1 \leq 0.5t$

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION NOZZLE CORE CALCULATIONNUMBER S-210-P | A-111SHEET 12 OF 14DATE 10-15-65 BY COCKRELLCHECK DATE 10-20-65 BY FERGUSON5- DETAILED ANALYSIS:6- NOZZLE SPACING:INLET, OUTLET & VENT NOZZLE:

I-613-c STATES THAT  $r_2$  SHOULD BE LARGE ENOUGH TO PROVIDE A SMOOTH TRANSITION BETWEEN NOZZLE AND SHELL. IN ADDITION, IF THE OPENING DIAMETER IS GREATER THAN  $1\frac{1}{2}$  TIMES THE SHELL THICKNESS FOR CYLINDRICAL SHELLS AND 3 TIMES THE SHELL THICKNESS FOR SPHERICAL SHELLS, THEN  $r_2$  SHALL BE EQUAL TO OR GREATER THAN THE LARGER OF THE NOZZLE OR SHELL THICKNESS.

NOZZLE	$r_2$ (ACTUAL)	$r_2$ (REQ'D)
INLET	5.375	5.375
OUTLET	5.375	5.375

$$r_{2REQ'D} = 0.5 t_n \text{ OR } 0.5 t_s$$

NOTE THAT THE DIAMETER OF THE VENT NOZZLE IS LESS THAN  $3 t_{SHELL}$ ; HENCE  $r_2$  IS NOT LIMITED TO  $0.5 t_n$  OR  $0.5 t_s$ .

I-613-f STATES THAT  $r_3$  MUST BE EQUAL TO OR GREATER THAN THE LARGER OF  $0.002 D_o$  OR  $2 (\sin \theta)^3$  (OFFSET), WHERE  $D_o$  = OUTSIDE DIA OF NOZ.

NOZZLE	$r_3$ (ACTUAL)	$r_3$ (REQ'D)
INLET	3.219	3.203
OUTLET	5.408	5.381

$$r_3(REQ'D) \geq 0.002 D_o \text{ OR } \geq 2 (\sin \theta)^3 (\text{OFFSET})$$

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-210-P | A-112  
SHEET 13 OF 14  
DATE 5-15-65 BY CARROLL  
CHECK DATE 5-20-65 BY FERGUSON

CHARGE NO. \_\_\_\_\_  
DESCRIPTION NOZZLE COOL CALCULATIONS

5. DETAILED ANALYSIS:


b. NOZZLE SPACING:

INLET, OUTLET & VENT NOZZLE:

FROM THE RESULTS AS GIVEN ON SHEETS 9-12, WE SEE THAT THE INLET AND OUTLET NOZZLES DO NOT MEET ALL THE REQUIREMENTS OF I-6, I-613; HENCE, THE STRESS INDEX METHOD OF STRESS EVALUATION CANNOT BE USED. SINCE THIS IS THE CASE, AN INTERACTION ANALYSIS OF THE NOZZLE TO VESSEL JUNCTURE WILL HAVE TO BE PERFORMED. WE SEE, HOWEVER, THAT THE VENT NOZZLE DOES MEET ALL THE REQUIREMENTS OF I-6, I-613, THEREFORE, THE STRESS INDEX METHOD CAN BE USED FOR THE VENT NOZZLE.

c. NOZZLE AND SAFE END COOL SIZING:

1. INLET NOZZLE:



NOZZLE:

SA-336  $S_m = 26.7 \text{ ksi @ } 650^\circ\text{F}$

SAFE END:

SA-182-F-316  $S_m = 16.7 \text{ ksi @ } 650^\circ\text{F}$

FOR THE NOZZLE END FROM I-110 OF SECTION III:

$$t_{\text{MIN. REQ}} = \frac{PR}{S_m - 0.5P} = \frac{25(13.750)}{26.7 - 1.25}$$

$$= \underline{1.351"} \quad (\text{USE } 2.281" \text{ MIN})$$



COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-210-P | A113  
SHEET 14 OF 14  
DATE 5-15-65 BY LOCKRELL  
CHECK DATE 5-20-65 BY FERGUSON

CHARGE NO. \_\_\_\_\_  
DESCRIPTION NOZZLE CODE CALCULATIONS

5- DETAILED ANALYSIS:

C- NOZZLE AND SAFE END CODE SIZING:

1- INLET NOZZLE:

THE NOZZLE SAFE END IS CLASSIFIED AS PIPING IN PARAGRAPH N-150 OF SECTION III. IT THEREFORE MUST BE SIZED BY THE CODE FOR PRESSURE PIPING, SEE REFERENCE 8, WHICH DEFINES THE THICKNESS BY


$$t_{\min} = \frac{PD}{2S + 2yP} + C$$

$$= \frac{(2.5)(32.5)}{2(16.7) + 2(0.4)(2.5)}$$

$$= \underline{2.295"} \text{ (USE } 2.395")$$

WHERE: P IS THE DESIGN PRESS OF 2.5 KSI  
D IS THE OD. OF PIPE = 32.5"  
S IS THE ALLOWABLE OF MATERIAL - TAKEN AS  $S_m$  FOR SA-132-F-316 FROM SECTION III @ 650°F,  $S_m = 16.7 \text{ KSI}$   
 $y = 0.4$   
 $C = 0$  } FROM REF 8

2- OUTLET NOZZLE:



FOR NOZZLE END:

$$t_{\min \text{ REQ'D}} = \frac{PR}{S_m - 0.5P} = \frac{2.5(14.5)}{26.7 - 1.25} = \underline{1.424"} \text{ USE } 2.312"$$

FOR SAFE END:

$$t_{\min \text{ REQ'D}} = \frac{PD}{2S + 2yP} + C = \frac{2.5(34.062)}{2(16.7) + 2(0.4)(2.5)} = \underline{2.406"} \text{ USE } 2.426"$$

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

NUMBER 5-211-P | A114


SHEET 6 OF 69

DATE 4-22-68 BY COCKRELL

CHECK DATE 4-22-68 BY HEILKER

5. DETAILED ANALYSIS:

a - SYSTEM GEOMETRY:



COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-211-P | A 115  
SHEET 7 OF 69  
DATE 4-22-68 BY COCKRELL  
CHECK DATE 4-22-68 BY HEILKER

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORT

5. DETAILED ANALYSIS:

6. SYSTEM ALLOWABLES:

- 1- THE STRESS INTENSITY IN THE REINFORCEMENT PORTION OF THE NOZZLE RESULTING FROM DESIGN PRESSURE AND FROM EXTERNAL LOAD OR MOMENT SHALL NOT EXCEED  $S_m$  AT DESIGN TEMP.
- 2- THE STRESS INTENSITY DERIVED FROM THE AVERAGE PRIMARY PLUS THE LOCAL PRIMARY STRESS SHALL NOT EXCEED  $1.5S_m$  AT DESIGN TEMP.
- 3- THE STRESS INTENSITY AROUND THE NOZZLE TO SHELL JUNCTURE RESULTING FROM INTERNAL PRESSURE, PIPE LOADS, WEIGHT OF VESSEL AND REACTIONS FROM EXTERNAL LOADS SHALL NOT EXCEED  $1.5S_m$  AT DESIGN TEMP.
- 4- THE STRESS INTENSITY IN THE NOZZLE OUTSIDE OF THE REINFORCEMENT PORTION OF THE NOZZLE AND THE SAFE END RESULTING FROM DESIGN PRESSURE AND FROM DESIGN SEISMIC LOAD OR MOMENT SHALL NOT EXCEED  $1.5S_m$  AT DESIGN TEMP.
- 5- THE RANGE OF PRIMARY PLUS SECONDARY STRESS INTENSITY RESULTING FROM MECHANICAL OR THERMAL LOADS SHALL NOT EXCEED  $3S_m$  AT OPERATING PRESSURE AND TEMP.
- 6- SHOW THAT EACH POINT MEETS THE REQUIREMENTS FOR PEAK STRESS INTENSITY GIVEN IN N-414.5 OF THE ASME CODE, THE PROCEDURE WILL BE AS OUTLINED IN N-415.2 OF SECT. III.

NOTE THAT FOR THE CONSIDERATION OF "NO LOSS OF FUNCTION" SEISMIC NOZZLE LOADS, THE ABOVE ALLOWABLES (WHERE APPLICABLE) WILL BE INCREASED BY A FACTOR OF 1.2.

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A 116  
SHEET 8 OF 69  
DATE 4-22-68 BY COZZELL  
CHECK DATE 4-22-68 BY HEIKER

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORT

5. DETAILED ANALYSIS:

1. SYSTEM LOADING:

1. INTERNAL PRESSURE:

THE INLET NOZZLE AND THE VESSEL WALL IN THE VICINITY OF THE NOZZLE WILL BE INVESTIGATED FOR THE DESIGN PRESSURE WHERE APPLICABLE AND THE OPERATING PRESSURES DURING THE TRANSIENTS LISTED IN 5.C.2. THE STRESSES RESULTING FROM INTERNAL PRESSURE ARE DETERMINED FROM AN INTERACTION ANALYSIS AND ARE PRESENTED IN 5.C. THE PEAK STRESSES DUE TO INTERNAL PRESSURE AT THE JUNCTURE OF THE NOZZLE TO VESSEL SHELL WILL BE TAKEN AS GIVEN IN I-610 OF THE ASME CODE SECT. III.

2. THERMAL TRANSIENTS:

THE INLET NOZZLE AND THE VESSEL WALL WILL BE ANALYZED FOR THE FOLLOWING TRANSIENT CONDITIONS.

<u>TRANSIENT</u>	<u>NUMBER OF OCCURRENCES</u>
a. PLANT HEATUP AT 100°F PER HOUR	200
b. PLANT COOLDOWN AT 100°F PER HOUR	200
c. PLANT LOADING AT 5% OF FULL POWER PER MIN.	14500
d. PLANT UNLOADING AT 5% OF FULL POWER PER MIN.	14500
e. STEP LOAD INCREASE OF 10% OF FULL POWER BUT NOT TO EXCEED FULL POWER	2000
f. STEP LOAD DECREASE OF 10% OF FULL POWER FROM 100% POWER	2000
g. STEP LOAD REDUCTION FROM 100% TO 50% FULL POWER	200
h. REACTOR TRIP FROM FULL POWER	400
i. PLANT HYDROSTATIC TEST OF 3125 PSIA AT ROOM TEMP.	5
j. PLANT HYDROSTATIC TEST OF 2500 PSIA UP TO 400°F.	5
k. STEADYSTATE FLUCTUATIONS OF ±6°F AND ±100 PSI PER MIN.	∞
l. LOSS OF FLOW, ONE PUMP	80
m. LOSS OF LOAD	80
n. STEAM BREAK	5

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-211-D | A117

SHEET 9 OF 69

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS


CHECK DATE 4-22-68 BY HEILKER

5. DETAILED ANALYSIS:

a. SYSTEM LOADING:

3- THERMAL INDUCED PIPE REACTIONS:

THE FOLLOWING FIGURE SHOWS THE INLET NOZZLE WITH THE POSITIVE DIRECTIONS. THE PIPE REACTIONS ARE APPLIED AT THE SMALL END OF THE NOZZLE.



$$\begin{aligned} F_x &= 14.8 \text{ KIPS} \\ F_y &= -92.0 \text{ KIPS} \\ F_z &= 27.5 \text{ KIPS} \\ M_x &= -3783 \text{ IN-KIPS} \\ M_y &= 4499 \text{ IN-KIPS} \\ M_z &= 7441 \text{ IN-KIPS} \end{aligned}$$

4. SEISMIC PIPE REACTIONS:

THE FOLLOWING PIPE REACTIONS DUE TO SEISMIC CONDITIONS WILL BE COMBINED WITH THE THERMAL PIPE REACTIONS IN THE WORST POSSIBLE COMBINATION WHEN ANALYZING THE NOZZLE AND SUPPORTS. TO DETERMINE THE MAXIMUM EFFECT OF THE SEISMIC PIPE REACTIONS ON THE NOZZLE TO VESSEL JUNCTION AND THE SUPPORT PAD, IT IS NECESSARY TO DETERMINE THE WORSE COMBINATION OF FORCES. THIS HAS BEEN DONE AND THE FORCES RESULTING ARE LABELED H AND V. NOTE THAT THE EFFECT OF TWO OF THE INLET AND OUTLET NOZZLE SEISMIC REACTIONS MUST BE TAKEN BY THE INLET AND OUTLET NOZZLES WHICH SUPPORT THE VESSEL. THE FOLLOWING ARE THE PIPE REACTIONS.

DESIGN SEISMIC LOADING

$$\begin{aligned} F_x &= \pm 57.9 \text{ KIPS} \\ F_y &= \pm 67.0 \text{ KIPS} \\ F_z &= \pm 132.9 \text{ KIPS} \\ M_x &= \pm 982 \text{ IN-KIPS} \\ M_y &= \pm 12972 \text{ IN-KIPS} \\ M_z &= \pm 9910 \text{ IN-KIPS} \end{aligned}$$

NO LOSS OF FUNCTION SEISMIC LOADING

$$\begin{aligned} F_x &= \pm 81.9 \text{ KIPS} \\ F_y &= \pm 111.0 \text{ KIPS} \\ F_z &= \pm 202.0 \text{ KIPS} \\ M_x &= \pm 2800 \text{ IN-KIPS} \\ M_y &= \pm 23655 \text{ IN-KIPS} \\ M_z &= \pm 10005 \text{ IN-KIPS} \end{aligned}$$

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A118

SHEET 10 OF 69

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORT


CHECK DATE 4-22-68 BY HEIKER

5. DETAILED ANALYSIS:

C. SYSTEM LOADING:

4. SEISMIC PIPE REACTIONS:

AS CAN BE SEEN FROM THE TABLE ON SHEET 9, THERE ARE MANY COMBINATIONS OF FORCES. SINCE THE SEISMIC FORCES CAN ALTERNATE, IT WILL BE NECESSARY TO DETERMINE THE COMBINATION OF FORCES WHICH PRODUCE THE MAXIMUM AND MINIMUM STRESSES AT CUT-A. THIS WILL OCCUR WHEN THE VALUES FOR  $\bar{F}_x, \bar{F}_y, \bar{F}_z, \bar{M}_x, \bar{M}_y, \bar{M}_z$  AS GIVEN ON SHEETS 41 & 46 ARE SOLVED TO GIVE MAXIMUM AND MINIMUM VALUES. THE METHOD USED TO DETERMINE THIS IS AS FOLLOWS: (1) THE LOADS ON THE INDIVIDUAL NOZZLES ARE TRANSFERRED TO THE C.G. OF THE REACTOR VESSEL, (2) THE FORCES H AND V ARE DETERMINE IN RELATION TO THE LOADS AT THE  $\bar{C}$  OF THE VESSEL, AND (3) TAKING THE COMBINATION OF SEISMIC LOADS GIVEN ON SHEET 9 TO GIVE THE MAXIMUM AND MINIMUM VALUES OF H & V.



## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLES - VESSEL SUPPORTSNUMBER 5-211-D

A119

SHEET 11 OF 69DATE 4-22-68 BY COCKRELLCHECK DATE 4-22-68 BY HEILKER5. DETAILED ANALYSIS:C. SYSTEM LOADING:4. SEISMIC PIPE REACTIONS:(1) FORCES AT E OF VESSEL:

$$\bar{F}_x = (F_{x_{IN\#1}} - F_{x_{IN\#3}}) + (-F_{x_{IN\#2}} + F_{x_{IN\#4}}) \cos 46^\circ + (F_{z_{IN\#2}} - F_{z_{IN\#4}}) \sin 46^\circ + (F_{x_{OUT\#1}} - F_{x_{OUT\#3}}) \cos 46^\circ \\ + (F_{z_{OUT\#1}} - F_{z_{OUT\#3}}) \sin 46^\circ + (F_{z_{OUT\#2}} - F_{z_{OUT\#4}})$$

$$\bar{F}_y = (F_{y_{IN\#1}} + F_{y_{IN\#2}} + F_{y_{IN\#3}} + F_{y_{IN\#4}}) + (F_{y_{OUT\#1}} + F_{y_{OUT\#2}} + F_{y_{OUT\#3}} + F_{y_{OUT\#4}})$$

$$\bar{F}_z = (-F_{x_{IN\#2}} + F_{x_{IN\#4}}) \sin 46^\circ + (F_{z_{IN\#1}} - F_{z_{IN\#3}}) + (-F_{z_{IN\#2}} + F_{z_{IN\#4}}) \cos 46^\circ + (-F_{x_{OUT\#1}} + F_{x_{OUT\#3}}) \sin 46^\circ \\ + (-F_{x_{OUT\#2}} + F_{x_{OUT\#4}}) + (F_{z_{OUT\#1}} - F_{z_{OUT\#3}}) \cos 46^\circ$$

$$\bar{M}_x = (-F_{y_{IN\#2}} + F_{y_{IN\#4}}) 126.72 \sin 46^\circ + (M_{x_{IN\#1}} - M_{x_{IN\#3}}) + (-M_{x_{IN\#2}} + M_{x_{IN\#4}}) \cos 46^\circ + (M_{z_{IN\#2}} - M_{z_{IN\#4}}) \sin 46^\circ \\ + (-F_{y_{OUT\#1}} + F_{y_{OUT\#3}}) 118.563 \sin 46^\circ + (-F_{y_{OUT\#2}} + F_{y_{OUT\#4}}) 118.563 + (M_{x_{OUT\#1}} - M_{x_{OUT\#3}}) \cos 46^\circ \\ + (M_{z_{OUT\#1}} - M_{z_{OUT\#3}}) \sin 46^\circ + (M_{z_{OUT\#2}} - M_{z_{OUT\#4}})$$

$$\bar{M}_y = (F_{z_{IN\#1}} + F_{z_{IN\#2}} + F_{z_{IN\#3}} + F_{z_{IN\#4}}) 126.72 + (M_{y_{IN\#1}} + M_{y_{IN\#2}} + M_{y_{IN\#3}} + M_{y_{IN\#4}}) \\ + (F_{z_{OUT\#1}} + F_{z_{OUT\#2}} + F_{z_{OUT\#3}} + F_{z_{OUT\#4}}) 118.563 + (M_{y_{OUT\#1}} + M_{y_{OUT\#2}} + M_{y_{OUT\#3}} + M_{y_{OUT\#4}})$$

$$\bar{M}_z = (-F_{y_{IN\#1}} + F_{y_{IN\#3}}) 126.72 + (F_{y_{IN\#2}} - F_{y_{IN\#4}}) 126.72 \cos 46^\circ + (-M_{x_{IN\#2}} + M_{x_{IN\#4}}) \sin 46^\circ \\ + (M_{z_{IN\#1}} - M_{z_{IN\#3}}) + (-M_{z_{IN\#2}} + M_{z_{IN\#4}}) \cos 46^\circ + (-F_{y_{OUT\#1}} + F_{y_{OUT\#3}}) 118.563 \cos 46^\circ \\ + (-M_{x_{OUT\#1}} + M_{x_{OUT\#3}}) \sin 46^\circ + (-M_{x_{OUT\#2}} + M_{x_{OUT\#4}}) + (M_{z_{OUT\#1}} - M_{z_{OUT\#3}}) \cos 46^\circ$$

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A 120SHEET 12 OF 69DATE 4-22-69 BY COCKRELLCHECK DATE 4-22-69 BY HEILKER

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS5- DETAILED ANALYSIS:4- SYSTEM LOADING:4. SEISMIC PIPE REACTIONS:(2) FORCES ON SUPPORTS:

$$H = \frac{\bar{F}_z}{2} - \frac{\bar{M}_y}{4(109.406)}$$

$$V = -\frac{\bar{F}_y}{4} \pm \frac{\bar{M}_z}{2(109.406)}$$

NOTE HERE THAT THE TOP SIGN IS FOR INLET NOZZLE #1 AND THE BOTTOM SIGN IS FOR INLET NOZZLE #3. HOWEVER, WITH SUBSTITUTION OF FORMULAS ON SHEET 11 & SOLVING WILL YIELD THE SAME RESULTS.

(3) VALUES OF FORCES ON SUPPORTS:

WITH THE ABOVE EXPRESSIONS FOR H & V AND THE EXPRESSIONS FOR  $\bar{F}_y$ ,  $\bar{F}_z$ ,  $\bar{M}_y$ , AND  $\bar{M}_z$  GIVEN ON SHEET 11, WE GET THE FOLLOWING.

$$H = 0.35967(F_{x, IN\#2} - F_{x, IN\#4}) - 0.78956 F_{z, IN\#1} + 0.05777 F_{z, IN\#2} + 0.21044 F_{z, IN\#3} - 0.63689 F_{z, IN\#4}$$

$$- 0.002285(M_{y, IN\#1} + M_{y, IN\#2} + M_{y, IN\#3} + M_{y, IN\#4}) + 0.35967(F_{x, OUT\#1} - F_{x, OUT\#3}) + 0.5(F_{x, OUT\#2} - F_{x, OUT\#4})$$

$$- 0.61825 F_{z, OUT\#1} - 0.27092(F_{z, OUT\#2} + F_{z, OUT\#4}) + 0.07641 F_{z, OUT\#3} - 0.002295(M_{y, IN\#1} + M_{y, IN\#2} + M_{y, IN\#3} + M_{y, IN\#4})$$

$$V = -0.0291 F_{y, IN\#1} + 0.15229 F_{y, IN\#2} + 0.32912 F_{y, IN\#3} - 0.65229 F_{y, IN\#4} + 0.00329(-M_{x, IN\#2} + M_{x, IN\#4})$$

$$+ 0.00457(M_{z, IN\#1} - M_{z, IN\#3}) + 0.00317(-M_{z, IN\#2} + M_{z, IN\#4}) - 0.6264 F_{y, OUT\#1}$$

$$+ 0.25(-F_{y, OUT\#2} - F_{y, OUT\#4}) + 0.12640 F_{y, OUT\#3} + 0.00329(-M_{x, OUT\#1} + M_{x, OUT\#3})$$

$$+ 0.00457(-M_{x, OUT\#2} + M_{x, OUT\#4}) + 0.00317(M_{z, OUT\#1} - M_{z, OUT\#3})$$



**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

NUMBER 5-211-P | A 121

SHEET 13 OF 69

DATE 4-22-68 BY COCKRELL

CHECK DATE 4-22-68 BY HEILKER

5- DETAILED ANALYSIS:

C- SYSTEM LOADING:

4- SEISMIC PIPE REACTIONS:

WITH THE ABOVE EQUATIONS AND THE FOLLOWING VALUES FOR THE SEISMIC PIPE REACTIONS, THE VALUES FOR H & V ARE DETERMINED THAT WILL GIVE THE MAXIMUM AND MINIMUM STRESSES AT CUT-4.

FOR DESIGN SEISMIC:

NOZZLE	PIPE REACTION					
	F <sub>x</sub>	F <sub>y</sub>	F <sub>z</sub>	M <sub>x</sub>	M <sub>y</sub>	M <sub>z</sub>
INLET #1	-57.9	-67	132.9	-982	12972	9910
2	57.9	-67	132.9	982	-12972	9910
3		-67	132.9		-12972	9910
4	-57.9	67	-132.9	-982	-12972	-9910
OUTLET #1	122	90	-71	1572	-11248	-7282
2	122	90	-71	1572	-11248	
3	-122	-90	71	-1572	-11248	7282
4	-122	90	-71	-1572	-11248	

H = 516.5 KIPS  
V = -273.2 KIPS

REVERSING SIGNS  
GIVES

H = -516.5 KIPS  
V = 273.2 KIPS

FOR NO LOSS OF FUNCTION SEISMIC:

NOZZLE	PIPE REACTION					
	F <sub>x</sub>	F <sub>y</sub>	F <sub>z</sub>	M <sub>x</sub>	M <sub>y</sub>	M <sub>z</sub>
INLET #1	-81.9	-111	262	-2800	23655	10005
2	81.9	-111	262	2800	-23655	10005
3		-111	262		-23655	10005
4	-81.9	111	-262	-2800	-23655	-10005
OUTLET #1	122	162	-124	2830	-19569	-13200
2	122	162	-124	2830	-19569	
3	-122	-162	124	-2830	-19569	13200
4	-122	162	-124	-2830	-19569	

H = 738.9 KIPS  
V = -446.5 KIPS

REVERSING SIGNS  
GIVES,

H = -738.9 KIPS  
V = 446.5 KIPS

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTNUMBER 5-211-P | A122SHEET 14 OF 69DATE 4-22-69 BY CORRELLCHECK DATE 4-22-69 BY HELMER5- DETAILED ANALYSIS:a. SYSTEM LOADING:5- STATIC LOADING THROUGH SUPPORTS:

THE FOLLOWING IS THE OVERALL WEIGHT AND C.G. FOR THE VESSEL AND CONTENTS. THE DYNAMIC LOAD OF THE SCRAMMED CONTROL RODS WILL BE ADDED WHERE IT GIVES HIGHER STRESSES.

ITEM	DESCRIPTION	WEIGHT (KIPS)	DISTANCE TO C.G. FROM $\phi$ OF NOZZLES
a	WEIGHT OF CORE AND CORE SUPPORT STRUCTURE	675	100.8 BELOW
b	DYNAMIC LOAD OF TRIPPED CONTROL RODS	112.8	~
c	WEIGHT OF WATER CONTAINED WITHIN THE REACTOR VESSEL AND HEAD	375	79.6 BELOW
d	WEIGHT OF REACTOR VESSEL & CLOSURE HEAD	866	41.2 BELOW
e	WEIGHT OF INSULATION ON VESSEL & CLOSURE HEAD	12	80 BELOW
f	WEIGHT OF VESSEL HEAD LIFTING RIG AND VENTILATING SHROUD	60	330.0 ABOVE
g	WEIGHT OF CONTROL ROD DRIVE MECHANISMS	161.5	260.3 ABOVE
h	PARTIAL WEIGHT OF REACTOR COOLANT PIPING	95	@ $\phi$ OF NOZZLES

$$\text{TOTAL STATIC LOAD} = \Sigma W = 2244.5 \text{ KIPS}$$

$$\text{C.G. OF SYSTEM} = \frac{\Sigma Wd}{\Sigma W} = 32.6" \text{ BELOW } \phi \text{ OF NOZZLES}$$

$$\text{STATIC LOAD PER SUPPORT} = 561.1 \text{ KIPS}$$

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-211-P | A123

SHEET 15 OF 69

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS


CHECK DATE 4-22-68 BY HEIKER

5- DETAILED ANALYSIS:

C. SYSTEM LOADING:

6- EARTHQUAKE LOADING THROUGH SUPPORTS:

DURING AN EARTHQUAKE, THE SUPPORTS MUST RESIST THE VERTICAL AND HORIZONTAL FORCES APPLIED THROUGH THE C.G. OF THE VESSEL DUE TO THE EARTHQUAKE SHOCK FORCES. SINCE THE BOTTOM OF THE VESSEL SUPPORTS IS AT A DIFFERENT ELEVATION THAN THE C.G. OF THE VESSEL, AN OVERTURNING MOMENT DUE TO THE HORIZONTAL SHOCK FORCE RESULTS AND MUST BE RESISTED BY THE SUPPORTS. THE FOLLOWING FIGURE ILLUSTRATES THE METHOD FOR DETERMINING THE FORCES ON THE PADS.



$$V = \pm \frac{\bar{V}}{4} \pm \frac{\bar{H}}{2(109.406)}$$

$$H = \pm \frac{\bar{H}}{2}$$

DIRECTION	EARTHQUAKE FACTORS	
	DESIGN	NO LOSS OF FUNCTION
HORIZONTAL	0.3g	0.4g
VERTICAL	0.2g	0.4g

FORCE	DESIGN EARTHQUAKE	NO LOSS OF FUNCTION EARTHQUAKE
H	± 336.7	± 673.4
V	± 126.4	± 252.8

a = 28"  
b = 4.6"  
c = 32.6"

NOTE HERE THAT THE ABOVE SEISMIC SHOCK FACTORS ARE LARGER THAN THOSE LISTED IN REF. 9. THE ABOVE FACTORS WILL BE USED WHEN CALCULATING STRESSES; HOWEVER, THE SPECIFIED SEISMIC SHOCK FACTORS GIVEN IN REF. 9 WILL BE USED WHEN DETERMINING THE MAXIMUM FORCES ON THE PAD, SEE SHEET 57.



## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTNUMBER S-211-P | A124SHEET 16 OF 69DATE 4-22-68 BY COCKRELLCHECK DATE 4-22-68 BY HEILKER5. DETAILED ANALYSIS:C. SYSTEM LOADINGS:7. DUE TO THERMAL EXPANSION & CONTRACTION:

DURING THE HEATUP AND COOLODOWN TRANSIENT THE VESSEL WILL EXPAND OR CONTRACT RADIALLY, THUS CREATING RADIAL FORCES IN THE HORIZONTAL PLANE DUE TO FRICTION BETWEEN THE SUPPORT PADS ON THE NOZZLES AND THE BEARING PLATES ON THE SUPPORT LEDGE OF THE CONCRETE ENCLOSURE. IN CALCULATING THESE FRICTIONAL FORCES, A COEFFICIENT OF STATIC FRICTION OF  $\mu = 0.3$  IS ASSUMED.

FORCES DUE TO  
HEATUPFORCES DUE TO  
COOLODOWN

THE MAXIMUM RADIAL FORCE ON ONE LUG DUE TO FRICTION IS,

$$F = \frac{\mu W}{4} = \frac{0.3(2244.5)}{4} = 168.3 \text{ KIPS}$$

IN DETERMINING THE ABOVE FRICTIONAL FORCE, ONLY THE STATIC WEIGHT OF THE VESSEL AND COMPONENTS IS CONSIDERED BECAUSE THE FRICTIONAL FORCE WOULD BE DESTROYED DURING AN EARTHQUAKE SHOCK. THIS FRICTIONAL FORCE WILL BE CONSIDERED WHERE APPLICABLE.

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-211-P | A125

SHEET 17 OF 69

DATE 4-22-68 BY COCKRELL

CHECK DATE 4-22-68 BY HEILKER

CHARGE NO. \_\_\_\_\_


DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORT

5. DETAILED ANALYSIS:

d. PRESSURE AND THERMAL INTERACTION:

1. ANALYTICAL MODEL:

THE ACTUAL STRUCTURE AS SHOWN ON SHEET 10 IS DIVIDED INTO THE FOLLOWING ANALYTICAL MODEL TO FACILITATE THE ANALYSIS. THE ASSUMED DIRECTION OF THE REDUNDANT FORCES IS ILLUSTRATED.



**COMBUSTION ENGINEERING, INC.**  
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.  
 CHARGE NO. \_\_\_\_\_  
 DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORT


NUMBER S-211-P | A 126  
 SHEET 18 OF 69  
 DATE 4-22-69 BY COCKRELL  
 CHECK DATE 4-27-69 BY HEIKER

5. DETAILED ANALYSIS:

d. PRESSURE AND THERMAL INTERACTION:

1. DEFLECTIONS:

BODY-1



$R_1 = 15.000''$   
 $b_i = 13.750''$   
 $L_1 = 2.500''$   
 $R_2 = 15.110''$   
 $e = 0.110$

$\beta^* = \frac{3(1-\nu^2)}{R_1^2 t^3}$   
 $\beta = 0.20991$

$D = \frac{Et^3}{12(1-\nu^2)} = 1.43086 E_{316}$   
 $\frac{E_{316}}{E_{36}} = 1$

DISPLACEMENTS DUE TO REDUNDANT FORCES:

$ED_{11} = -\frac{E}{2\beta^2 D} \left[ \frac{1}{\beta} H_1 - M_1 \right] \frac{R_1}{R_1} \frac{E_{321P}}{E_{316}} = -38.0602 H_1 + 7.9891 M_1$

$ED_{11}^* = -\frac{E}{2\beta^2 D} \left[ H_1 - 2\beta M_1 \right] \frac{R_1}{R_1} \frac{E_{321P}}{E_{316}} = -7.9891 H_1 + 3.3539 M_1$

DISPLACEMENTS DUE TO APPLIED FORCES:

$ES_{11} = \frac{b_i^2 (R_1 - \frac{t}{2}) P}{2} \frac{E_{316}}{E_{316}} - \frac{E}{2\beta^2 D} (V_1 e) \frac{R_1}{R_1} \frac{E_{316}}{E_{316}} = 65.6583 P$

$EO_{11}^* = -\frac{E}{\beta D} (V_1 e) \frac{R_1}{R_1} \frac{E_{316}}{E_{316}} = -2.3081 P$

DISPLACEMENTS DUE TO THERMAL EFFECTS:

FOR RANGE OF STRESS

FOR PEAK STRESS

$ED_{11T} = R_2 E d_m (T_1 - 100) \frac{E_{316}}{E_{316}}$

$= R_2 E d_m (T_1 - 100) \frac{E_{316}}{E_{316}} + \frac{E}{2\beta^2 D} \frac{R_1}{R_1} \frac{E_{321P}}{E_{316}} M_{1T}$

$= 15.110 E d_m (T_1 - 100)$

$= 15.110 E d_m (T_1 - 100) + 7.9891 M_{1T}$

$EO_{11T}^* = R_1 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{11} \frac{E_{321P}}{E_{316}}$

$= R_1 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{11} \frac{E_{321P}}{E_{316}} + \frac{E}{\beta D} \frac{R_1}{R_1} \frac{E_{321P}}{E_{316}} M_{1T}$

$= 15.000 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{11}$

$= 15.000 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{11} + 3.3539 M_{1T}$

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | 1A127

SHEET 19 OF 69

DATE 4-22-68 BY COOPER

CHARGE NO. \_\_\_\_\_

CHECK DATE 4-22-68 BY HEILKER


DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

d. PRESSURE AND THERMAL INTERACTION:

2. DEFLECTIONS:

BODY-2



$R_2 = 15.110''$   
 $b_2 = 13.750''$   
 $t_2 = 2.281''$   
 $r_2 = 2.923''$

$$\beta^* = \frac{3(1-\nu^2)}{R_2^3 t_2^2}$$

$$\beta = 0.21895$$

$$D = \frac{E t_2^3}{12(1-\nu^2)} = 1.0868E$$

For  $\beta R = 0.64$

$B_{11} = 3.1300$	$G_{11} = -1.5588$
$B_{12} = 7.3671$	$G_{12} = -7.2989$
$B_{22} = 23.3633$	$G_{22} = -22.7239$

DISPLACEMENTS DUE TO REDUNDANT FORCES

$$EA_{21} = \frac{E}{38^3 D} \left[ \frac{1}{\beta} B_{11} H_1 + B_{12} M_1 - \frac{1}{\beta} G_{11} H_2 + G_{12} M_2 \right]$$

$$= 137.1918 H_1 + 70.7010 M_1 + 68.3242 H_2 - 70.0465 M_2$$

$$EA_{21}^* = \frac{E}{38^3 D} \left[ -B_{12} H_1 - \beta B_{22} M_1 + G_{12} H_2 - \beta G_{22} M_2 \right]$$

$$= -70.7010 H_1 - 49.0918 M_1 - 70.0465 H_2 + 47.7482 M_2$$

$$EA_{22} = \frac{E}{38^3 D} \left[ \frac{1}{\beta} G_{11} H_1 + G_{12} M_1 - \frac{1}{\beta} B_{11} H_2 + B_{12} M_2 \right]$$

$$= -68.3242 H_1 - 70.0465 M_1 - 137.1918 H_2 + 70.7010 M_2$$

$$EA_{22}^* = \frac{E}{38^3 D} \left[ G_{12} H_1 + \beta G_{22} M_1 - B_{12} H_2 + \beta B_{22} M_2 \right]$$

$$= -70.0465 H_1 - 47.7482 M_1 - 70.7010 H_2 + 49.0918 M_2$$

COMBUSTION ENGINEERING, IIIIC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A128

SHEET 20 OF 69

DATE 4-22-68 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEILKER

5. DETAILED ANALYSIS:

d. PRESSURE AND THERMAL INTERACTION:

2. DEFLECTIONS:

DISPLACEMENTS DUE TO APPLIED FORCES

$$E\delta_{21} = E\delta_{22} = \frac{b_1}{b_2} \left( \frac{R_1}{b_2} - \frac{r}{2} \right) P = \underline{78.6511 P}$$

$$E\delta_{21}^* = E\delta_{22}^* = 0$$

DISPLACEMENTS DUE TO THERMAL EFFECTS:

<u>FOR RANGE OF STRESS</u>	<u>FOR PEAK STRESS</u>
$E\delta_{21T} = R_2 E d_m (T_{21} - 100)$ $= \underline{15.110 E d_m (T_{21} - 100)}$	$= R_2 E d_m (T_{21} - 100) + \frac{E}{2\beta^2 D} [B_{12} M_{1T} + G_{12} M_{2T}]$ $= \underline{15.110 E d_m (T_{21} - 100) + 70.7010 M_{1T} - 70.0465 M_{2T}}$
$E\delta_{21}^* = R_2 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{21}$ $= \underline{15.110 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{21}}$	$= R_2 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{21} + \frac{E}{2\beta^2 D} [-\beta B_{22} M_{1T} - \beta G_{22} M_{2T}]$ $= \underline{15.110 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{21} - 49.0918 M_{1T} + 47.7482 M_{2T}}$
$E\delta_{22T} = R_2 E d_m (T_{22} - 100)$ $= \underline{15.110 E d_m (T_{22} - 100)}$	$= R_2 E d_m (T_{22} - 100) + \frac{E}{2\beta^2 D} [G_{12} M_{1T} + B_{12} M_{2T}]$ $= \underline{15.110 E d_m (T_{22} - 100) - 70.0465 M_{1T} + 70.7010 M_{2T}}$
$E\delta_{22}^* = R_2 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{22}$ $= \underline{15.110 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{22}}$	$= R_2 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{22} + \frac{E}{2\beta^2 D} [\beta G_{22} M_{1T} + \beta B_{22} M_{2T}]$ $= \underline{15.110 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{22} - 47.7482 M_{1T} + 49.0918 M_{2T}}$



COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-211-P | A129

SHEET 21 OF 69

CHARGE NO. \_\_\_\_\_

DATE 4-22-69 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS


CHECK DATE 4-22-69 BY HETLER

5. DETAILED ANALYSIS:

1. PRESSURE & THERMAL INTERACTION:

2. DEFLECTIONS:

BODY-3:



- $R_2 = 15.110"$
- $R_3 = 18.383"$
- $R_4 = 21.657"$
- $\alpha_3 = 14.922$
- $t_0 = 2.281"$
- $t_L = 10.686"$
- $L_3 = 17.077"$
- $e_1 = 5.273"$
- $e_2 = 5.274"$

$$\lambda = \frac{1}{L_3} (t_L - t_0) = 0.49218$$

THE INFLUENCE COEFFICIENTS FOR A SHORT TAPERED CYLINDER ARE CALCULATED BY THE METHOD OUTLINED ON PAGES 488 - 492 OF REF 12 AND ARE PRINTED OUT ON C.E.'S COMPUTER PROGRAM AS FOLLOWS.

DISPLACEMENTS DUE TO REDUNDANT FORCES:

$$E\Delta_{32} = \phi_{11} H_2 \frac{R_1}{R_3} + \phi_{12} M_2 \frac{R_1}{R_3} + \phi_{13} H_3 \frac{R_1}{R_3} + \phi_{14} M_3 \frac{R_1}{R_3}$$

$$= 20.9248 H_2 + 3.3409 M_2 + 6.5006 H_3 - 1.2909 M_3$$

$$E\Delta_{33}^* = \phi_{21} H_2 \frac{R_1}{R_3} + \phi_{22} M_2 \frac{R_1}{R_3} + \phi_{23} H_3 \frac{R_1}{R_3} + \phi_{24} M_3 \frac{R_1}{R_3}$$

$$= -3.3342 H_2 - 1.4814 M_2 - 0.7004 H_3 + 0.0605 M_3$$

$$E\Delta_{33} = \phi_{31} H_2 \frac{R_1}{R_3} + \phi_{32} M_2 \frac{R_1}{R_3} + \phi_{33} H_3 \frac{R_1}{R_3} + \phi_{34} M_3 \frac{R_1}{R_3}$$

$$= -4.5532 H_2 - 0.4916 M_2 - 12.0860 H_3 + 1.4232 M_3$$

$$E\Delta_{33}^* = \phi_{41} H_2 \frac{R_2}{R_3} + \phi_{42} M_2 \frac{R_2}{R_3} + \phi_{43} H_3 \frac{R_2}{R_3} + \phi_{44} M_3 \frac{R_2}{R_3}$$

$$= -0.9061 H_2 - 0.0425 M_2 - 1.4262 H_3 + 0.2817 M_3$$

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-211-P | A130

SHEET 22 OF 69

CHARGE NO. \_\_\_\_\_

DATE 4-22-69 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-69 BY HEILKER

5. DETAILED ANALYSIS:

d. PRESSURE AND THERMAL INTERACTION:

1. DEFLECTIONS:

DISPLACEMENTS DUE TO APPLIED FORCES:

$$E\delta_{32} = P_{a3}^2 \left( \frac{R_3}{a_3} - \frac{v}{2} \right) \left[ \frac{(\phi_{12} + \phi_{11}) - \frac{\lambda^2}{2(1-\nu^2)}}{E_0} + \frac{1}{E_0} \right] + \phi_{12} V_1 e_1 \frac{R_2}{R_3} - \phi_{14} V_3 e_2 \frac{R_4}{R_3} = \underline{176.1759 P}$$

$$E\delta_{32}^* = P_{a3}^2 \left( \frac{R_3}{a_3} - \frac{v}{2} \right) \left[ \frac{(\phi_{22} + \phi_{21}) - \frac{\lambda^2}{2(1-\nu^2)}}{E_0} - \frac{\lambda}{E_0} \right] + \phi_{22} V_1 e_1 \frac{R_2}{R_3} - \phi_{24} V_3 e_2 \frac{R_4}{R_3} = \underline{-40.8173 P}$$

$$E\delta_{31} = P_{a3}^2 \left( \frac{R_3}{a_3} - \frac{v}{2} \right) \left[ \frac{(\phi_{32} + \phi_{31}) - \frac{\lambda^2}{2(1-\nu^2)}}{E_0} + \frac{1}{E_0} \right] + \phi_{32} V_1 e_1 \frac{R_2}{R_3} - \phi_{34} V_3 e_2 \frac{R_4}{R_3} = \underline{-19.7843 P}$$

$$E\delta_{31}^* = P_{a3}^2 \left( \frac{R_3}{a_3} - \frac{v}{2} \right) \left[ \frac{(\phi_{42} + \phi_{41}) - \frac{\lambda^2}{2(1-\nu^2)}}{E_0} - \frac{\lambda}{E_0} \right] + \phi_{42} V_1 e_1 \frac{R_2}{R_3} - \phi_{44} V_3 e_2 \frac{R_4}{R_3} = \underline{-8.8063 P}$$

DISPLACEMENTS DUE TO THERMAL EFFECTS:

<u>FOR RANGE OF STRESS</u>	<u>FOR PEAK STRESS</u>
$E\delta_{32T} = R_2 E d_m (T_{32} - 100)$ $= 15.110 E d_m (T_{32} - 100)$	$R_2 E d_m (T_{32} - 100) + \phi_{12} M_{2T} \frac{R_2}{R_3} + \phi_{14} M_{3T} \frac{R_4}{R_3}$ $= 15.110 E d_m (T_{32} - 100) + 3.3409 M_{2T} - 1.2909 M_{3T}$
$E\delta_{32T}^* = R_3 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{32}$ $= 18.383 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{32}$	$R_3 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{32} + \phi_{22} M_{2T} \frac{R_2}{R_3} + \phi_{24} M_{3T} \frac{R_4}{R_3}$ $= 18.383 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{32} - 1.4814 M_{2T} + 0.0605 M_{3T}$
$E\delta_{33T} = R_4 E d_m (T_{33} - 100)$ $= 21.657 E d_m (T_{33} - 100)$	$R_4 E d_m (T_{33} - 100) + \phi_{32} M_{2T} \frac{R_2}{R_3} + \phi_{34} M_{3T} \frac{R_4}{R_3}$ $= 21.657 E d_m (T_{33} - 100) - 0.4916 M_{2T} + 1.4232 M_{3T}$
$E\delta_{33T}^* = R_3 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{33}$ $= 18.383 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{33}$	$R_3 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{33} + \phi_{42} M_{2T} \frac{R_2}{R_3} + \phi_{44} M_{3T} \frac{R_4}{R_3}$ $= 18.383 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{33} - 0.0425 M_{2T} + 0.2817 M_{3T}$

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-211-P | A 131

SHEET 23 OF 69

DATE 4-22-68 BY COCHRAN

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS


CHECK DATE 4-22-68 BY HEILKER

5- DETAILED ANALYSIS:

d. PRESSURE AND THERMAL INTERACTIONS:

2- DEFLECTIONS:

BODY-4:



$$R_4 = 21.657'' \quad \beta^* = \frac{3(1-\nu^2)}{R_4^2 t_4^3}$$

$$b_4 = 16.094'' \quad \beta = 0.09450$$

$$t_4 = 10.686'' \quad D = \frac{E t_4^3}{12(1-\nu^2)} = 111.74365 E$$

$$L_4 = 15.688''$$

For  $\beta L = 1.32557$

$$B_{11} = 1.5523 \quad G_{11} = -0.7220$$

$$B_{12} = 1.8882 \quad G_{12} = -1.6017$$

$$B_{22} = 3.5493 \quad G_{22} = -2.2458$$

DISPLACEMENTS DUE TO REDUNDANT FORCES:

$$E \Delta_{43} = \frac{E}{2\beta^2 D} \left[ \frac{1}{\beta} B_{11} H_3 + B_{12} M_3 - \frac{1}{\beta} G_{11} H_4 + G_{12} M_4 \right]$$

$$= 11.5139 H_3 + 1.1834 M_3 + 5.3553 H_4 - 1.0038 M_4$$

$$E \Delta_{43}^* = \frac{E}{2\beta^2 D} \left[ -B_{12} H_3 - \beta B_{22} M_3 + G_{12} H_4 - \beta G_{22} M_4 \right]$$

$$= -1.1834 H_3 - 0.1880 M_3 - 1.0038 H_4 + 0.1189 M_4$$

$$E \Delta_{44} = \frac{E}{2\beta^2 D} \left[ \frac{1}{\beta} G_{11} H_3 + G_{12} M_3 - \frac{1}{\beta} B_{11} H_4 + B_{12} M_4 \right]$$

$$= -5.3553 H_3 - 1.0038 M_3 - 11.5139 H_4 + 1.1834 M_4$$

$$E \Delta_{44}^* = \frac{E}{2\beta^2 D} \left[ G_{12} H_3 + \beta G_{22} M_3 - B_{12} H_4 + \beta B_{22} M_4 \right]$$

$$= -1.0038 H_3 - 0.1189 M_3 - 1.1834 H_4 + 0.1880 M_4$$

COMBUSTION ENGINEERING, INC.  
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.  
 CHARGE NO. \_\_\_\_\_  
 DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

NUMBER 5-211-P | A 132  
 SHEET 24 OF 69  
 DATE 4-22-68 BY COCKRELL  
 CHECK DATE 4-22-68 BY HEILKER

5. DETAILED ANALYSIS:

d. PRESSURE AND THERMAL INTERACTION:

2. DEFLECTIONS:

DISPLACEMENTS DUE TO APPLIED FORCES:

$$E\delta_{43} = E\delta_{44} = \frac{b_2^2}{L_2} \left( \frac{R_2}{b_2} - \frac{\nu}{2} \right) P = \underline{28.9814P}$$

$$E\delta_{43}^* = E\delta_{44}^* = 0$$

DISPLACEMENTS DUE TO THERMAL EFFECTS:

FOR RANGE OF STRESS	FOR PEAK STRESS
$E\delta_{43T} = R_2 E d_m (T_{43} - 100)$ $= 21.657 E d_m (T_{43} - 100)$	$= R_2 E d_m (T_{43} - 100) + \frac{E}{2\beta^2 D} [B_{12} M_{3T} + G_{12} M_{4T}]$ $= 21.657 E d_m (T_{43} - 100) + 1.1834 M_{3T} - 1.0038 M_{4T}$
$E\delta_{43T}^* = R_2 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{43}$ $= 21.657 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{43}$	$= R_2 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{43} + \frac{E}{2\beta^2 D} [-\beta B_{22} M_{3T} - \beta G_{22} M_{4T}]$ $= 21.657 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{43} - 0.1880 M_{3T} + 0.1189 M_{4T}$
$E\delta_{44T} = R_2 E d_m (T_{44} - 100)$ $= 21.657 E d_m (T_{44} - 100)$	$= R_2 E d_m (T_{44} - 100) + \frac{E}{2\beta^2 D} [G_{12} M_{3T} + B_{12} M_{4T}]$ $= 21.657 E d_m (T_{44} - 100) - 1.0038 M_{3T} + 1.1834 M_{4T}$
$E\delta_{44T}^* = R_2 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{44}$ $= 21.657 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{44}$	$= R_2 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{44} + \frac{E}{2\beta^2 D} [\beta G_{22} M_{3T} + \beta B_{22} M_{4T}]$ $= 21.657 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{44} - 0.1189 M_{3T} + 0.1880 M_{4T}$

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A133  
SHEET 25 OF 69  
DATE 4-22-68 BY COCKRELL  
CHECK DATE 4-22-68 BY HEILKER


CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

1. PRESSURE AND THERMAL INTERACTIONS:

2. DEFLECTIONS:

Body-S:



$R_s = 136.546"$   
 $a_s = 130.952"$   
 $t_s = 10.75"$   
 $\phi_s = 9^{\circ}7.5'$

FOR  $\phi = \sqrt{\frac{R}{t}} = 32.53119$   
 $P_{11} = 0.6718$   
 $P_{12} = 0.6084$   
 $P_{21} = 3.1457$

NOTE THAT THE VESSEL SHELL IS IDEALIZED AS A SPHERICAL SEGMENT OF THE SAME THICKNESS AS THE VESSEL AND WITH A MID-RADIUS 1.5 TIMES THAT OF THE VESSEL. THIS YIELDS A MODEL WITH MEMBRANE STRESS EQUAL TO THE AVERAGE OF THAT IN THE LONG. & CIRC. DIRECTIONS OF THE VESSEL

DISPLACEMENTS DUE TO REDUNDANT FORCES:

$E\Delta_{S4} = \frac{180}{\pi t_s^3 \phi_s} [t_s^2 P_{11} H_a + t_s P_{12} M_a] = 4.2123 H_a + 0.3553 M_a$   
 $E\Delta_{S4}^* = -\frac{180}{\pi t_s^3 \phi_s} [t_s P_{21} H_a + P_{22} M_a] = -0.3553 H_a - 0.1708 M_a$

DISPLACEMENTS DUE TO APPLIED FORCES:

$E\delta_{S4} = \frac{a_s^2}{2} \left[ \frac{180 \cos \phi}{\pi R_s \phi} P_{11} + \frac{\sin \phi}{t_s} (1-\nu) \right] = 349.9944 P$   
 $E\delta_{S4}^* = -\frac{90 a_s^2 \cos \phi}{\pi R_s t_s \phi} P_{12} P = -22.0252 P$

DISPLACEMENTS DUE TO THERMAL EFFECTS:

FOR RANGE OF STRESS	FOR PEAK STRESS
$E\Delta_{S4} = R_s \sin \phi E d_m (T_{S4} - 100)$ $= 21.657 E d_m (T_{S4} - 100)$	$= R_s \sin \phi E d_m (T_{S4} - 100) + \frac{180}{\pi t_s^3 \phi_s} P_{12} M_{S7}$ $= 21.657 E d_m (T_{S4} - 100) + 0.3553 M_{S7}$
$E\Delta_{S4}^* = R_s \sin \phi E d_m \left( \frac{\Delta T}{\Delta X}_{S4} \right)$ $= 21.657 E d_m \left( \frac{\Delta T}{\Delta X}_{S4} \right)$	$= R_s \sin \phi E d_m \left( \frac{\Delta T}{\Delta X}_{S4} \right) - \frac{180}{\pi t_s^3 \phi_s} P_{22} M_{S7}$ $= 21.657 E d_m \left( \frac{\Delta T}{\Delta X}_{S4} \right) - 0.1708 M_{S7}$

COMBUSTION ENGINEERING, INC.  
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.  
 CHARGE NO. \_\_\_\_\_  
 DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

NUMBER S-211-P | A134  
 SHEET 26 OF 69  
 DATE 4-22-68 BY COCKRELL  
 CHECK DATE 4-22-69 BY HEILNER

5- DETAILED ANALYSIS:

- d- PRESSURE AND THERMAL INTERACTION:
- 2- DEFLECTIONS:

THE FOLLOWING TABLES GIVE THE MEAN TEMPERATURE, SLOPE OF THE AXIAL GRADIENT, AND THE THERMAL MOMENT DUE TO THE RADIAL GRADIENT AT EACH CUT. THESE VALUES ARE USED TO CALCULATE THE DEFLECTIONS AND ROTATIONS OF EACH CUT DUE TO THERMAL EFFECTS.

TRANSIENT	T <sub>1</sub> & T <sub>2</sub>	T <sub>22</sub> & T <sub>22</sub>	T <sub>33</sub> & T <sub>43</sub>	T <sub>44</sub>	T <sub>54</sub>	(ΔT) (ΔX) <sub>11</sub>	(ΔT) & (ΔT) (ΔX) <sub>21</sub> (ΔY) <sub>22</sub>	(ΔT) & (ΔT) (ΔX) <sub>32</sub> (ΔY) <sub>33</sub>	
a - HEAT TIP	4.00 HRS	492	490	423	426	435	1.000	-0.684	-3.923
	4.25	517	515	448	451	460	↓	↓	↓
	4.35	527	525	458	461	470	↓	↓	↓
	4.47	539	537	470	473	482	↓	↓	↓
	5.00	547	546	508	510	515	0	-0.342	-2.225
STEADY STATE	547	547	547	547	547	0	0	0	
b - COOL DOWN	4.00 HRS	155	157	224	221	212	-1.000	0.684	3.923
	4.25	130	132	199	196	187	↓	↓	↓
	4.35	120	122	189	186	177	↓	↓	↓
	4.47	108	110	177	174	165	↓	↓	↓
	5.00	100	101	139	137	132		0.342	2.225
c	547	547	547	547	547	0	0	0	
d → f	554.8	554.8	554.8	554.8	554.8				
g	555	555	555	555	555				
h	554.5	554.5	554.5	554.5	554.5				
i	100	100	100	100	100	↓	↓	↓	
j	N.D. 3.00 HRS	392	390	323	326	335	1.000	-0.684	-3.923
	S.S. C.D.	400	400	400	400	400	0	0	0
	3.00 HRS	100	110	177	174	165	-1.000	0.684	3.923
k → m	554.8	554.8	554.8	554.8	554.8	0	0	0	
n	547	547	547	547	547	0	0	0	

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A135  
SHEET 27 OF 69  
DATE 4-22-68 BY COCKBELL  
CHECK DATE 4-22-69 BY HEINER

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

d. PRESSURE AND THERMAL INTERACTION:

2. DEFLECTIONS:

TRANSIENT	$\frac{(\Delta T)}{(\Delta X)}_{23}$	$\frac{(\Delta T)}{(\Delta X)}_{54}$	M <sub>1T</sub> IN-KIP/IN	M <sub>2T</sub> IN-KIP/IN	M <sub>3T</sub> IN-KIP/IN	M <sub>4T</sub> IN-KIP/IN	M <sub>5T</sub> IN-KIP/IN	
a - HEATUP	4.00HRS	0.333	0.666	1.432	1.884	296.455	308.138	336.543
	4.25		0.500	1.439	1.893	297.894	311.129	338.168
	4.35		0.500	1.446	1.903	299.333	312.625	339.794
	4.47		0.250	1.453	1.910	300.772	314.121	341.420
	5.00	0.222	0	0	0.398	171.974	169.914	184.075
STEADY STATE	0	0	0	0	0	0	0	
b - COOLDOWN	4.00HRS	-0.333	-0.666	-1.432	-1.884	-296.455	-308.138	-336.543
	4.25		-0.500	-1.439	-1.893	-297.894	-311.129	-338.168
	4.35		-0.500	-1.446	-1.902	-299.333	-312.625	-339.794
	4.47		-0.250	-1.453	-1.910	-300.772	-314.121	-341.420
	5.00	-0.222	0	0	-0.398	-171.974	-169.914	-184.075
c	0			0	0	0	0	
d → f								
g								
h								
i								
j	11.0 3.00HRS	0.333	0.666	1.453	1.910	300.772	314.121	341.420
	5.5	0	0	0	0	0	0	0
	6.0 3.00HRS	-0.333	-0.666	-1.453	-1.910	-300.772	-314.121	-341.420
k → m	0	0	0	0	0	0	0	
n	0	0	0	0	0	0	0	

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-211A7 | A136  
SHEET 28 OF 69  
DATE 4-22-68 BY POCKRELL  
CHECK DATE 4-22-68 BY HEIKER

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORT

5. DETAILED ANALYSIS:

d. PRESSURE AND THERMAL INTERACTION:

2. DEFLECTIONS:

WITH THE EXPRESSIONS FOR THE DISPLACEMENTS AS PRESENTED ON SHEETS 18-25 AND THE VALUES GIVEN IN THE TABLES ON SHEETS 26-27, THE FOLLOWING VALUES OF DISPLACEMENT WERE OBTAINED FOR RANGE OF STRESS

TRANSIENT	$E\delta_{117}$	$E\delta_{117}^*$	$E\delta_{217}$	$E\delta_{217}^*$	$E\delta_{227}$	$E\delta_{227}^*$	$E\delta_{327}$	$E\delta_{327}$	
a - HEATUP	4.00 HRS	1475.4	3.736	1102.6	-1.924	1096.9	-1.924	1096.9	-13.424
	4.25	1568.9	3.735	1172.8	-1.924	1167.2	-1.924	1167.2	-13.424
	4.35	1606.1	3.734	1200.7	-1.923	1195.1	-1.923	1195.1	-13.421
	4.47	1650.7	3.733	1233.9	-1.923	1228.4	-1.923	1228.4	-13.416
	5.00	1680.2	0	1256.0	-0.961	1253.3	-0.961	1253.3	-7.607
STEADY STATE	1680.2	0	1256.0	0	1256.0	0	1256.0	0	
b - COOLDOWN	4.00 HRS	203.0	-3.663	149.4	1.858	154.9	1.858	154.9	12.967
	4.25	110.4	-3.655	81.2	1.851	86.6	1.951	86.6	12.919
	4.35	73.6	-3.651	54.0	1.847	59.4	1.848	59.4	12.895
	4.47	29.4	-3.647	21.5	1.842	26.9	1.843	26.9	12.861
	5.00	0	0	0	0.919	2.7	0.919	2.7	7.278
c	1680.2	0	1256.0	0	1256.0	0	1256.0	0	
d → f	1709.0		1277.5		1277.5		1277.5		
g	1709.7		1278.1		1278.1		1278.1		
h	1707.9		1276.7		1276.7		1276.7		
i	0		0		0		0		
j	3 HRS	1127.3	3.730	838.9	-1.913	838.9	-1.913	838.9	-13.346
	5.5	1127.3	0	838.9	0	838.9	0	838.9	0
	8 HRS	44.1	-3.648	32.4	1.844	32.4	1.844	32.4	12.867
k → m	1709.0	0	1277.5	0	1277.5	0	1277.5	0	
n	1680.2	0	1256.0	0	1256.0	0	1256.0	0	



**COMBUSTION ENGINEERING, INC.**  
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-211-P | A137

SHEET 29 OF 69

DATE 4-22-69 BY LOCKWELL

CHECK DATE 4-22-69 BY HEIKER

CHARGE NO. \_\_\_\_\_  
 DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

d. PRESSURE AND THERMAL INTERACTION:

2. DEFLECTIONS:

FOR RANGE OF STRESS

TRANSIENT		$E_{D37}$	$E_{D37}^*$	$E_{D47}$	$E_{D47}^*$	$E_{D47}$	$E_{D47}^*$	$E_{D47}$	$E_{D47}^*$
a. HEATUP	1.00 HRS	1291.5	-13.376	1291.5	1.338	1309.9	1.338	1347.0	2.678
	1.25	1400.6	-13.402	1400.6	1.340	1412.9	1.340	1449.9	2.014
	1.35	1441.7	-13.410	1441.7	1.341	1454.0	1.341	1490.8	2.015
	1.47	1490.8	-13.417	1490.8	1.342	1503.0	1.342	1539.7	1.008
	5.00	1644.8	-7.614	1644.8	0.895	1652.9	0.895	1672.9	0
STEADYSTATE		1800.3	0	1800.3	0	1800.3	0	1800.3	0
b. COOLDOWN	1.00 HRS	486.4	13.062	486.4	-1.306	474.5	-1.306	438.8	-2.609
	1.25	387.3	13.029	387.3	-1.303	375.5	-1.302	340.0	-1.954
	1.35	347.9	13.015	347.9	-1.302	336.0	-1.301	300.6	-1.952
	1.47	300.6	12.998	300.6	-1.300	288.8	-1.299	253.4	-0.975
	5.00	151.5	7.336	151.5	-0.862	143.7	-0.862	124.1	0
c		1800.3	0	1800.3	0	1800.3	0	1800.3	0
d → f		1831.1		1831.1		1831.1		1831.1	
g		1831.8		1831.8		1831.8		1831.8	
h		1829.9		1829.9		1829.9		1829.9	
i		0		0		0		0	
j	3.0 HRS	1202.3	-13.346	1202.3	1.335	1202.3	1.335	1202.3	1.002
	5.5	1202.3	0	1202.3	0	1202.3	0	1202.3	0
	3.0 HRS	46.4	12.867	46.4	-1.287	46.4	-1.287	46.4	-0.097
k → m		1831.1	0	1831.1	0	1831.1	0	1831.1	0
n		1800.3	0	1800.3	0	1800.3	0	1800.3	0

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A138

SHEET 30 OF 69

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY DOUBELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEILKER

5- DETAILED ANALYSIS:

1- PRESSURE AND THERMAL INTERACTION:

2- DEFLECTIONS:

FOR PEAK STRESS

TRANSIENT	$E_{\delta_{IT}}$	$E_{\delta_{IT}}^*$	$E_{\delta_{2T}}$	$E_{\delta_{2T}}^*$	$E_{\delta_{2T}}$	$E_{\delta_{2T}}^*$	$E_{\delta_{32T}}$	$E_{\delta_{32T}}^*$
a - Heating 400NPS 425 435 447 5.00	1486.8	8.539	1071.8	17.734	1129.8	22.190	720.5	1.721
	1580.4	8.561	1141.9	17.821	1200.2	22.297	789.0	1.795
	1617.7	8.584	1169.6	17.955	1228.4	22.454	815.0	1.870
	1662.3	8.606	1202.9	17.946	1261.7	22.464	846.5	1.951
	1680.2	0.0	1228.2	18.043	1281.4	18.578	1032.6	2.208
STEADY STATE	1680.2	0.0	1256.0	0.0	1256.0	0.0	1256.0	0.0
b - Cooling 400NPS 425 435 447 5.00	191.5	-9.466	180.1	-17.800	122.0	-22.255	531.3	-2.177
	98.9	-8.481	112.0	-17.893	53.6	-22.370	464.8	-2.299
	62.0	-8.501	85.0	-17.983	26.3	-22.481	439.5	-2.397
	17.8	-8.520	52.6	-18.026	-6.3	-22.544	408.8	-2.506
	0.0	0.0	27.9	-18.085	-25.5	-18.619	223.4	-2.537
c	1680.2		1256.0	0.0	1256.0	0.0	1256.0	0.0
d → f	1709.0		1277.5		1277.5		1277.5	
g	1709.7		1278.1		1278.1		1278.1	
h	1707.9		1276.7		1276.7		1276.7	
i	0.0	↓	0.0	↓	0.0	↓	0.0	↓
j 4.0 3.0 HRS 5.5 0.0 3.0 HRS	1138.9	8.604	807.8	17.956	872.1	22.475	457.0	2.021
	1127.3	0.0	838.9	0.0	838.9	0.0	838.9	0.0
	32.5	-8.522	63.4	-18.025	-0.9	-22.543	414.2	-2.500
k → m	1709.0	0.0	1277.5	0.0	1277.5	0.0	1277.5	0.0
n	1680.2	0.0	1256.0	0.0	1256.0	0.0	1256.0	0.0

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-211-P | A139

SHEET 31 OF 69

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COXPELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEUER

5. DETAILED ANALYSIS:

1. PRESSURE AND THERMAL INTERACTION:

2. DEFLECTIONS:

FOR PEAK STRESS

TRANSIENT		$E\delta_{33T}$	$E\delta_{33T}^*$	$E\delta_{43T}$	$E\delta_{43T}^*$	$E\delta_{44T}$	$E\delta_{44T}^*$	$E\delta_{54T}$	$E\delta_{54T}^*$
a - HEATUP	4.00 HRS	1718.5	70.055	1339.0	-17.758	1377.0	24.019	1466.6	-54.804
	4.25	1823.6	70.434	1440.8	-17.671	1482.1	24.413	1570.0	-55.745
	4.35	1866.7	70.832	1482.1	-17.763	1523.5	24.524	1611.5	-56.022
	4.47	1917.9	71.229	1531.4	-17.854	1572.9	24.635	1661.0	-57.307
	5.00	1889.4	40.814	1677.8	-11.233	1621.3	12.391	1738.3	-31.440
STEADY STATE		1800.3	0.0	1800.3	0.0	1800.3	0.0	1800.3	0.0
b - COOL DOWN	4.00 HRS	65.4	-70.369	444.9	17.790	407.4	-23.987	319.2	54.872
	4.25	-35.7	-70.808	347.1	17.708	306.3	-24.375	219.8	55.805
	4.35	-77.2	-71.226	307.4	17.802	266.5	-24.484	179.8	56.085
	4.47	-126.6	-71.648	259.9	17.896	218.9	-24.592	132.1	57.340
	5.00	-93.1	-41.092	118.5	11.266	115.2	-12.358	58.7	31.440
c		1800.3	0.0	1800.3	0.0	1800.3	0.0	1800.3	0.0
d → f		1831.1		1831.1		1831.1		1831.1	
g		1831.8		1831.8		1831.8		1831.8	
h		1829.9		1829.9		1829.9		1829.9	
i		0.0	↓	0.0	↓	0.0	↓	0.0	↓
j	4.0 HRS	1629.5	71.300	1243.0	-17.862	1272.2	24.628	1323.7	-57.313
	5.5	1202.3	0.0	1202.3	0.0	1202.3	0.0	1202.3	0.0
	8.0 HRS	-380.8	-71.779	5.8	17.909	-23.4	-24.580	-74.9	58.218
k → m		1831.1	0.0	1831.1	0.0	1831.1	0.0	1831.1	0.0
n		1800.3	0.0	1800.3	0.0	1800.3	0.0	1800.3	0.0

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A 140

SHEET 32 OF 69

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COURELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEINER

5. DETAILED ANALYSIS:

d. PRESSURE AND THERMAL INTERACTION:

3. CONTINUITY MATRIX AND LOADING VECTORS:

WRITING THE COMPATIBILITY EQUATIONS IN MATRIX FORM,

-175.2520	-62.7120	-68.3242	70.0465	0	0	0	0	14 <sub>1</sub>
62.7120	52.4457	70.0465	-47.7482	0	0	0	0	M <sub>1</sub>
-68.3242	-70.0465	-158.1166	67.3601	-6.5006	1.2909	0	0	H <sub>2</sub>
-70.0465	-47.7482	-67.3668	50.5752	0.7004	-0.0605	0	0	M <sub>2</sub>
0	0	-4.5332	-0.4916	-23.5999	0.2398	-5.3553	1.0038	H <sub>3</sub>
0	0	-0.9061	-0.0425	-0.2428	0.4696	1.0038	-0.1189	M <sub>3</sub>
0	0	0	0	-5.3553	-1.0038	-15.7262	0.8281	H <sub>4</sub>
0	0	0	0	-1.0038	-0.1189	-0.8281	0.3588	M <sub>4</sub>

FOR RANGE OF STRESS

PRESSURE	HEATUP					STEADY STATE	COOLDOWN	
	T=4.00MS	T=4.25	T=4.85	T=4.97	T=5.00		T=4.00MS	T=4.25
12.9919P	-372.8	-396.1	-405.5	-416.7	-424.2	-424.2	-53.6	-29.3
3.3091P	-5.660	-5.659	-5.657	-5.655	-0.961	0	5.521	5.505
97.5249P	0	0	0	0	0	0	0	0
-40.8173P	-11.500	-11.500	-11.498	-11.494	-6.646	0	11.109	11.067
48.7657P	0	0	0	0	0	0	0	0
8.8063P	14.714	14.742	14.751	14.759	8.509	0	-14.368	-14.332
321.0130P	37.2	36.9	36.8	36.7	20.1	0	-35.7	-35.5
-22.0252P	1.340	0.673	0.673	-0.334	-0.895	0	-1.308	-0.651

FOR RANGE OF STRESS

	COOLDOWN			c	d-f	g	h	i	j
	T=0.35	T=4.47	T=5.00						
-19.5	-7.8	0	-424.2	-431.5	-431.6	-431.2	0	-288.4	
5.499	5.489	0.919	0	0	0	0	0	-5.643	
0	0	0	0	0	0	0	0	0	
11.047	11.018	6.358	0	0	0	0	0	-11.433	
0	0	0	0	0	0	0	0	0	
-14.317	-14.298	-8.198	0	0	0	0	0	14.680	
-35.5	-35.4	-19.5	0	0	0	0	0	0	
-0.651	0.325	0.862	0	0	0	0	0	-0.333	

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A141  
SHEET 33 OF 69  
DATE 4-22-68 BY OSKRELL  
CHECK DATE 4-22-68 BY HEILKER

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

- d. PRESSURE AND THERMAL INTERACTION:
- 3. CONTINUITY MATRIX AND LOADING VECTORS:

FOR RANGE OF STRESS				FOR PEAK STRESS					
j	C.D. 3.00MPS	k → m	n	HEATUP					
				T=4.00MPS	T=4.25	T=4.35	T=4.47	T=5.00	
S.S									
-288.4	-11.8	-431.5	-424.2	-415.0	-438.5	-449.1	-459.4	-452.1	
0	5.493	0	0	9.195	9.259	9.371	9.340	13.043	
0	0	0	0	-409.3	-411.3	-413.3	-415.1	-248.8	
0	11.023	0	0	20.469	-20.503	-20.585	-20.513	-16.369	
0	0	0	0	-379.5	-382.8	-384.7	-386.5	-211.6	
0	-14.154	0	0	-87.813	-88.105	-89.594	-89.024	-52.047	
0	0	0	0	89.7	87.9	89.1	89.2	57.0	
0	1.190	0	0	-78.823	-80.159	-80.546	-81.942	-43.831	

FOR PEAK STRESS								
STRAIN RATE	COOLDOWN					c	d → f	g
	T=4.00MPS	T=4.25	T=4.35	T=4.47	T=5.00			
-424.2	-11.4	13.1	23.0	34.8	27.9	-424.2	-431.5	-431.6
0	-9.334	-9.412	-9.482	-9.506	-18.085	0	0	0
0	409.3	411.3	413.2	415.1	248.8	0	0	0
0	20.078	20.070	20.084	20.038	16.082	0	0	0
0	379.5	382.8	384.7	386.5	211.6	0	0	0
0	88.159	88.516	89.028	89.544	52.358	0	0	0
0	-88.2	-86.5	-86.7	-86.9	-56.5	0	0	0
0	78.860	80.180	80.569	81.932	43.798	0	0	0

FOR PEAK STRESS						
h	l	j		k → m	n	
		A.S. T=3.00MPS	C.D. T=3.00MPS			
-431.1	0	-331.1	-288.4	30.9	-431.5	-424.2
0	0	9.353	0	-9.503	0	0
0	0	-415.1	0	415.1	0	0
0	0	-20.453	0	20.043	0	0
0	0	-386.5	0	386.5	0	0
0	0	-89.162	0	89.688	0	0
0	0	51.5	0	-51.5	0	0
0	0	-81.940	0	82.798	0	0

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A142

SHEET 34 OF 69

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEILKER

5- DETAILED ANALYSIS:

d. PRESSURE AND THERMAL INTERACTION:

4. REDUNDANT FORCES:

THE ABOVE MATRIX WITH THE GIVEN LOADING VECTORS FOR PRESSURE AND THE TRANSIENT CONDITIONS FOR BOTH RANGE OF STRESS AND PEAK STRESS GIVE THE FOLLOWING VALUES FOR THE REDUNDANT FORCES.

— FOR RANGE OF STRESS —

TRANSIENT	H <sub>1</sub> KIP/IN	M <sub>1</sub> IN-KIP/IN	H <sub>2</sub> KIP/IN	M <sub>2</sub> IN-KIP/IN	H <sub>3</sub> KIP/IN	M <sub>3</sub> IN-KIP/IN	H <sub>4</sub> KIP/IN	M <sub>4</sub> IN-KIP/IN	
PRESSURE ONLY	-1.4820P	-4.0236P	-1.4297P	-8.5635P	0.9949P	51.5276P	-29.8560P	-110.4336P	
a - HEATUP	4.00 HRS	5.4218	-1.9397	2.8411	9.2769	1.6582	53.9849	-5.6804	13.1555
	4.25	5.7652	-1.8840	2.9779	9.9809	1.5267	53.8035	-5.7380	10.7364
	4.35	5.9028	-1.8632	3.0245	10.2617	1.5114	53.9330	-5.7330	10.7487
	4.47	6.0690	-1.8299	3.0865	10.6073	1.3483	53.2669	-5.8186	7.0657
	5.00	6.2067	-0.3086	2.7739	11.9022	0.3808	32.3727	-3.3944	1.4660
STEADY STATE	6.2340	0.9222	2.3724	12.6809	-0.6379	5.6658	-0.1588	-0.2734	
b - COOL DOWN	4.00 HRS	0.8400	2.7851	-0.4398	3.4015	-2.2358	-47.0402	5.3413	-13.1506
	4.25	0.4919	2.7183	-0.5732	2.6625	-2.0994	-46.7069	5.3900	-10.7289
	4.35	0.3387	2.6930	-0.6270	2.3680	-2.0822	-46.7841	5.3859	-10.7136
	4.47	0.1653	2.6543	-0.6907	2.0043	-1.9219	-46.0909	5.4718	-7.1183
	5.00	0.0249	1.1797	-0.3880	0.7399	-0.9844	-25.7664	3.1338	-1.6585
c	6.2340	0.9222	2.3724	12.6809	-0.6379	5.6658	-0.1588	-0.2734	
d → f	6.3407	0.9380	2.4131	12.8981	-0.6488	5.7628	-0.1616	-0.2781	
g	6.3435	0.9384	2.4141	12.9037	-0.6491	5.7653	-0.1616	-0.2782	
h	6.3366	0.9374	2.4115	12.8898	-0.6484	5.7591	-0.1614	-0.2779	
i	0	0	0	0	0	0	0	0	
j	HU 3.0 HRS	4.1645	-2.0371	2.2937	6.7150	0.9230	45.0705	-2.6381	10.5043
	SS CO	4.2388	0.6271	1.6131	8.6224	-0.4337	3.8525	-0.1080	-0.1859
	CO 3.00 HRS	0.2437	2.5950	-0.5902	2.1894	-1.2013	-38.8840	2.5159	-7.1246
k → m	6.3407	0.9380	2.4131	12.8981	-0.6488	5.7628	-0.1616	-0.2781	
n	6.2340	0.9222	2.3724	12.6809	-0.6379	5.6658	-0.1588	-0.2734	

**COMBUSTION ENGINEERING, INC.**  
**ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.**

NUMBER 5-211-P 1A143

SHEET 35 OF 69

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEILKER

5- DETAILED ANALYSIS:

d- PRESSURE AND THERMAL INTERACTION:

4- REDUNDANT FORCES:

- FOR PEAK STRESS -

TRANSIENT		H <sub>1</sub> KIP/IN	M <sub>1</sub> IN-KIP/IN	H <sub>2</sub> KIP/IN	M <sub>2</sub> IN-KIP/IN	H <sub>3</sub> KIP/IN	M <sub>3</sub> IN-KIP/IN	H <sub>4</sub> KIP/IN	M <sub>4</sub> IN-KIP/IN
a - HEATUP	4.00 HRS	5.4314	-3.3474	2.8545	7.4518	1.1275	-244.7520	-6.9856	-313.7740
	4.25	5.7743	-3.2997	2.9846	8.1440	1.0213	-246.2679	-6.9801	-318.2831
	4.35	5.9120	-3.2858	3.0372	8.4150	1.0037	-247.5879	-6.9811	-319.8529
	4.47	6.0782	-3.2595	3.0993	8.7540	0.8381	-249.7035	-7.0727	-325.1178
	5.00	6.2115	-0.2963	2.7805	11.5336	0.1159	-140.7465	-4.0447	-177.8202
STEADY STATE		6.2340	0.9222	2.3724	12.6809	-0.6379	5.6658	-0.1588	-0.2734
b - COOLDOWN	4.00 HRS	0.8304	4.1928	-0.4532	5.2265	-1.7052	251.6967	6.6465	313.7789
	4.25	0.4728	4.1341	-0.5859	4.4994	-1.5941	253.3645	6.6322	318.2906
	4.35	0.3295	4.1157	-0.6397	4.2136	-1.5744	254.7368	6.6341	319.8880
	4.47	0.1561	4.0838	-0.7035	3.8577	-1.4117	256.8794	6.7259	325.0652
	5.00	0.0201	1.1673	-0.3946	1.1085	-0.7195	147.3528	3.7840	177.6277
c		6.2340	0.9222	2.3724	12.6809	-0.6379	5.6658	-0.1588	-0.2734
d → f		6.3407	0.9380	2.4131	12.6981	-0.6488	5.7628	-0.1616	-0.2781
g		6.3435	0.9384	2.4141	12.9037	-0.6491	5.7653	-0.1616	-0.2782
h		6.3366	0.9374	2.4115	12.8998	-0.6484	5.7591	-0.1614	-0.2779
i		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
j	H.U. 30 HRS	4.1737	-3.4666	2.3064	4.8617	0.4128	-257.8999	-3.8922	-321.6793
	SS.	4.2398	0.6271	1.6131	8.6224	-0.4337	3.8525	-0.1080	-0.1859
	C.O. 30 HRS	0.2344	4.0246	-0.6030	4.0428	-0.6911	264.0863	3.7700	325.0589
k → m		6.3407	0.9380	2.4131	12.8981	-0.6488	5.7628	-0.1616	-0.2781
n		6.2340	0.9222	2.3724	12.6809	-0.6379	5.6658	-0.1588	-0.2734

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

NUMBER 5-211-P | A144

SHEET 30 OF 69

DATE 4-22-68 BY COCKRELL

CHECK DATE 4-22-68 BY HEILKER

5- DETAILED ANALYSIS:

a. STRESSES:

1- COMBINED STRESSES - UNCONCENTRATED:

FOR THIS SECTION OF THE ANALYSIS, STRESSES WILL BE CALCULATED AT THE TEN LOCATIONS AS SHOWN ON SHEET 17.


LOCATION 1 & 2:

PRESSURE STRESS:

$$\sigma_x = \pm \frac{6M_x R_1}{2t^2 R_1} + \frac{b^2 P}{2R_1 t} = \pm 0.9670 M_x + 2.5208 P$$

$$\sigma_\theta = \pm \frac{\sqrt{6} M_x R_1}{2t^2 R_1} + \frac{E W_{II}}{R_1} + \frac{b^2 P}{t} = \pm 0.2901 M_x + 0.06667 E W_{II} + 5.5000 P$$

$$\sigma_r = -P$$



$$I = \frac{\pi}{4} (R_1^4 - R_2^4) = 26691 \text{ IN}^4$$

$$A = \pi (R_1^2 - R_2^2) = 235.6 \text{ IN}^2$$

THERMAL STRESS:

$$\sigma_x = \pm \frac{6M_x R_1}{2t^2 R_1} = \pm 0.9670 M_x$$

$$\sigma_\theta = \pm \frac{\sqrt{6} M_x R_1}{2t^2 R_1} + \frac{E W_{II}}{R_1} = \pm 0.2901 M_x + 0.06667 E W_{II}$$

THERMAL INDUCED PIPE REACTIONS:

	LOCATION - 1	LOCATION - 2
$\sigma_x = -\frac{F_x}{A} \pm \frac{M_x}{I}$	$= -0.00424 F_x + 0.00052 M_x$ POINT A $= -0.00424 F_x - 0.00052 M_x$ B $= -0.00424 F_x + 0.00052 M_x$ C $= -0.00424 F_x - 0.00052 M_x$ D	$= -0.00424 F_x + 0.00061 M_x$ POINT A $= -0.00424 F_x - 0.00061 M_x$ B $= -0.00424 F_x + 0.00061 M_x$ C $= -0.00424 F_x - 0.00061 M_x$ D
$\tau_{\theta\phi} = \frac{F_\theta}{I b'} + \frac{M_\theta}{2I}$	$= 0.00845 F_x + 0.00026 M_x$ POINT A $= 0.00845 F_x - 0.00026 M_x$ B $= 0.00845 F_y + 0.00026 M_x$ C $= 0.00845 F_y - 0.00026 M_x$ D	$= 0.00845 F_x + 0.00031 M_x$ POINT A $= 0.00845 F_x - 0.00031 M_x$ B $= 0.00845 F_y + 0.00031 M_x$ C $= 0.00845 F_y - 0.00031 M_x$ D



COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A145  
SHEET 37 OF 69  
DATE 4-22-68 BY LOCKRELL  
CHECK DATE 4-22-68 BY HEIKER

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

C - STRESSES:

1. COMBINED STRESSES - UNCONCENTRATED:

SEISMIC PIPE REACTIONS:

THE FORMULAS FOR CALCULATING THE STRESSES DUE TO THE SEISMIC PIPE REACTIONS ARE THE SAME AS FOR THE THERMALLY INDUCED PIPE REACTIONS.

NOTE:

THERE WILL BE NO STRESS PRODUCED AT LOCATIONS 1-6 DUE TO THE STATIC LOADING THROUGH SUPPORTS, EARTHQUAKE LOADING THROUGH SUPPORTS, OR DUE TO THERMAL EXPANSION OR CONTRACTION.


LOCATION 3 & 4:

PRESSURE STRESS:

$$\sigma_x = \pm \frac{6M_1}{t^2} + \frac{b^2 P}{2R_2 t_2} = \pm 1.1532 M_1 + 2.7428 P$$

$$\sigma_\theta = \pm \frac{\sqrt{6} M_1}{t^2} + \frac{E W_2}{R_2} + \frac{b P}{t_2} = \pm 0.3460 M_1 + 0.0662 E W_2 + 6.0281 P$$

$$\sigma_r = -P$$



$$I = \frac{\pi}{4} (r_o^4 - r_i^4) = 24861 \text{ in}^4$$

$$A = \pi (r_o^2 - r_i^2) = 216.6 \text{ in}^2$$

THERMAL STRESS

$$\sigma_x = \pm \frac{6M_1}{t^2} = \pm 1.1532 M_1$$

$$\sigma_\theta = \pm \frac{\sqrt{6} M_1}{t^2} + \frac{E W_2}{R_2} = \pm 0.3460 M_1 + 0.0662 E W_2$$

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A146

SHEET 39 OF 69

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COCKRILL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-69 BY HEUSER

5- DETAILED ANALYSIS:

C. STRESSES:

1- COMBINED STRESSES - UNCONCENTRATED:

THERMAL INDUCED PIPE REACTIONS:

	LOCATION - 3		LOCATION - 4	
$\sigma_x = -\frac{E\epsilon}{A} \pm \frac{Mx}{I}$	$-0.00462F_x + 0.00056M_z$ POINT A		$-0.00462F_x + 0.00065M_z$ POINT A	
	$-0.00462F_x - 0.00056M_z$	B	$-0.00462F_x - 0.00065M_z$	B
	$-0.00462F_y + 0.00056M_y$	C	$-0.00462F_x + 0.00065M_y$	C
	$-0.00462F_x - 0.00056M_y$	D	$-0.00462F_x - 0.00065M_y$	D
$\tau_{xz} = \frac{FQ}{Ib} \pm \frac{Mc}{2I}$	$0.00926F_z + 0.00028M_x$ POINT A		$0.00926F_z + 0.00033M_x$ POINT A	
	$0.00926F_z - 0.00028M_x$	B	$0.00926F_z - 0.00033M_x$	B
	$0.00926F_y + 0.00028M_x$	C	$0.00926F_y + 0.00033M_x$	C
$b = 2t_z$	$0.00926F_y - 0.00028M_x$	D	$0.00926F_y - 0.00033M_x$	D

SEISMIC PIPE REACTIONS:

THE FORMULAS FOR CALCULATING THE STRESSES ARE THE SAME AS FOR THE THERMAL INDUCED PIPE REACTIONS.

LOCATION 5-6:

PRESSURE STRESS:

$$\sigma_x = \pm \frac{6M_x}{t_{20}^2} + \frac{bP}{2R_2 t_{20}} = \pm 1.0637M_x + 2.6342P$$


$$\sigma_\theta = \pm \frac{\sqrt{6}M_x}{t_{20}^2} + \frac{E\nu b}{R_2} + \frac{bP}{t_{20}} = \pm 0.3191M_x + 0.0662E\nu b + 5.7895P$$

$$\sigma_r = -P$$

THERMAL STRESS:

$$\sigma_x = \pm \frac{6M_x}{t_{20}^2} = \pm 1.0637M_x$$

$$\sigma_\theta = \pm \frac{\sqrt{6}M_x}{t_{20}^2} + \frac{E\nu b}{R_2} = \pm 0.3191M_x + 0.0662E\nu b$$



$$I = \frac{\pi}{4}(r_o^4 - r_i^4) = 26138 \text{ in}^4$$

$$A = \pi(r_o^2 - r_i^2) = 226.2 \text{ in}^2$$

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A147

SHEET 39 OF 69

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEKKER

5. DETAILED ANALYSIS:

E - STRESSES:

1- COMBINED STRESSES - UNCONCENTRATED:

THERMAL INDUCED PIPE REACTIONS:

SINCE THE PIPE REACTIONS ARE APPLIED AT THE SMALL END OF THE NOZZLE, THE PIPE REACTIONS MUST BE RESOLVED TO THE CROSS SECTION OF INTEREST. THIS IS DONE AS FOLLOWS.

$$\begin{aligned} \bar{F}_x &= F_x = 14.8 & \bar{M}_x &= M_x & & = -3783 \\ \bar{F}_y &= F_y = -92 & \bar{M}_y &= M_y + 2.923 F_z & = & 4579.4 \\ \bar{F}_z &= F_z = 27.5 & \bar{M}_z &= M_z - 2.923 F_y & = & 7710.0 \end{aligned}$$

	LOCATION - 5		LOCATION - 6
$\sigma_x = -\frac{\bar{F}_x}{A} + \frac{\bar{M}_z}{I}$	$= -0.00442 \bar{F}_x + 0.00053 \bar{M}_z$	POINT A	$= -0.00442 \bar{F}_x + 0.00062 \bar{M}_z$ POINT A
	$= -0.00442 \bar{F}_x - 0.00053 \bar{M}_z$	B	$= -0.00442 \bar{F}_x - 0.00062 \bar{M}_z$ B
	$= -0.00442 \bar{F}_x + 0.00053 \bar{M}_y$	C	$= -0.00442 \bar{F}_x + 0.00062 \bar{M}_y$ C
	$= -0.00442 \bar{F}_x - 0.00053 \bar{M}_y$	D	$= -0.00442 \bar{F}_x - 0.00062 \bar{M}_y$ D
$T_{x0} = \frac{FQ}{Ib'} + \frac{Mc}{2I}$	$= 0.00881 \bar{F}_z + 0.00026 \bar{M}_x$	POINT A	$= 0.00881 \bar{F}_z + 0.00031 \bar{M}_x$ POINT A
	$= 0.00881 \bar{F}_z - 0.00026 \bar{M}_x$	B	$= 0.00881 \bar{F}_z - 0.00031 \bar{M}_x$ B
	$= 0.00881 \bar{F}_y + 0.00026 \bar{M}_x$	C	$= 0.00881 \bar{F}_y + 0.00031 \bar{M}_x$ C
	$= 0.00881 \bar{F}_y - 0.00026 \bar{M}_x$	D	$= 0.00881 \bar{F}_y - 0.00031 \bar{M}_x$ D

SEISMIC PIPE REACTIONS:

THE FORMULAS FOR CALCULATING THE STRESSES DUE TO THE SEISMIC PIPE REACTIONS ARE THE SAME AS FOR THE THERMAL INDUCED PIPE REACTIONS.

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A148  
SHEET 40 OF 69  
DATE 4-22-63 BY COCKERELL  
CHECK DATE 4-22-63 BY HEILKER

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

e - STRESSES:

1. COMBINED STRESSES - UNCONCENTRATED:


LOCATION 7 & B:

PRESSURE STRESS:

$$\sigma_x = \pm \frac{6M_x R_o}{E I} \frac{R_o}{R_{in}} + \frac{b^2 P}{2R_o t_{in}} = \pm 0.0574 M_x + 0.6197 P$$

$$\sigma_{\theta} = \pm \frac{16M_{\theta} R_o}{E I} \frac{R_o}{R_{in}} + \frac{E W_{\theta}}{R_{in}} + \frac{bP}{t_{in}} = \pm 0.0172 M_{\theta} + 0.0456 E W_{\theta} + 1.6349 P$$

$$\sigma_r = -P$$



$$I = \frac{\pi}{4} (r_o^4 - r_i^4) = 35429016$$

$$A = \pi (r_o^2 - r_i^2) = 140010$$

THERMAL STRESS:

$$\sigma_x = \pm \frac{6M_x R_o}{E I} \frac{R_o}{R_{in}} = \pm 0.0574 M_x$$

$$\sigma_{\theta} = \pm \frac{16M_{\theta} R_o}{E I} \frac{R_o}{R_{in}} + \frac{E W_{\theta}}{R_{in}} = \pm 0.0172 M_{\theta} + 0.0456 E W_{\theta}$$

THERMAL INDUCED PIPE REACTIONS:

SINCE THE PIPE REACTIONS ARE APPLIED AT THE SMALL END OF THE NOZZLE, THE PIPE REACTIONS MUST BE RESOLVED TO THE CROSS SECTION OF INTEREST. THIS IS DONE AS FOLLOWS.

$$\bar{F}_x = F_x = 14.8 \quad \bar{M}_x = M_x = -3783$$

$$\bar{F}_y = F_y = -92 \quad \bar{M}_y = M_y + 30.313 F_z = 5332.6$$

$$\bar{F}_z = F_z = 27.5 \quad \bar{M}_z = M_z - 30.313 F_y = 10229.8$$

	LOCATION - 7		LOCATION - B
$\sigma_x = -\frac{\bar{F}_x}{A} \pm \frac{\bar{M}_x}{I}$	$= -0.00071 \bar{F}_x + 0.00005 \bar{M}_z$	POINT A	$= -0.00071 \bar{F}_x + 0.00008 \bar{M}_z$ POINT A
	$= -0.00071 \bar{F}_x - 0.00005 \bar{M}_z$	B	$= -0.00071 \bar{F}_x - 0.00008 \bar{M}_z$ B
	$= -0.00071 \bar{F}_x + 0.00005 \bar{M}_y$	C	$= -0.00071 \bar{F}_x + 0.00008 \bar{M}_y$ C
	$= -0.00071 \bar{F}_x - 0.00005 \bar{M}_y$	D	$= -0.00071 \bar{F}_x - 0.00008 \bar{M}_y$ D

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A 149  
SHEET 41 OF 69  
DATE 4-22-68 BY COCKPOLL  
CHECK DATE 4-22-68 BY HEILKER

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

a. STRESSES:

1. COMBINED STRESSES - UNCONCENTRATED:

	LOCATION - 7	LOCATION - 8
$T_{x0} = \frac{FQ}{Ib} \pm \frac{Mc}{2I}$	$0.00138 \bar{F}_z + 0.000024 \bar{M}_x$	$0.00138 \bar{F}_z + 0.000038 \bar{M}_x$
	$0.00138 \bar{F}_z - 0.000024 \bar{M}_x$	$0.00138 \bar{F}_z - 0.000038 \bar{M}_x$
$b' = 2t_{an}$	$0.00138 \bar{F}_y + 0.000024 \bar{M}_x$	$0.00138 \bar{F}_y + 0.000038 \bar{M}_x$
	$0.00138 \bar{F}_y - 0.000024 \bar{M}_x$	$0.00138 \bar{F}_y - 0.000038 \bar{M}_x$
	POINT A	POINT A
	B	B
	C	C
	D	D

SEISMIC PIPE REACTIONS:

IN SETTING UP EQUATIONS TO ACCOUNT FOR THE SEISMIC PIPE REACTIONS, THE FORCES EXERTED ON THE NOZZLE WHICH ARE APPLIED THRU THE SUPPORT PAD MUST BE RESOLVED TO THE CROSS SECTION OF INTEREST. THESE FORCES ARE LABELED H AND V AS SHOWN ON SHEET 9. THE VALUES FOR THE DESIGN EARTHQUAKE AND THE NO LOSS OF FUNCTION CONDITION WHICH WILL BE CONSIDERED ARE PRESENTED IN THE TABLE ON SHEET 9. THE EQUATIONS FOR STRESS WILL BE THE SAME FOR THE SEISMIC CONDITIONS AS FOR THE THERMAL INDUCED PIPE REACTIONS EXCEPT THE VALUES FOR  $\bar{F}_x$ ,  $\bar{F}_y$ ,  $\bar{F}_z$ ,  $\bar{M}_x$ ,  $\bar{M}_y$ , AND  $\bar{M}_z$  WILL BE AS FOLLOWS.

$$\begin{aligned} \bar{F}_x &= F_x = -57.9 & \bar{M}_x &= M_x - 27H = -1492.7 \\ \bar{F}_y &= F_y + V = -340.2 & \bar{M}_y &= M_y + 30.313 F_z + 13.0 H = 23715.1 \\ \bar{F}_z &= F_z + H = 649.4 & \bar{M}_z &= M_z - 30.313 F_y - 13.0 V = 15492.6 \end{aligned}$$

STATIC LOADING THROUGH SUPPORTS:

THE EQUATIONS FOR STRESS ARE THE SAME AS FOR THE THERMALLY INDUCED PIPE REACTIONS WITH THE FOLLOWING VALUES FOR  $\bar{F}_y$  &  $\bar{M}_z$ .

$$\begin{aligned} \bar{F}_y &= V = 561.1 \text{ SEE SHEET 14 FOR VALUES OF } V \text{ WITH OR WITHOUT} \\ \bar{M}_z &= -13.0 V = -7294.3 \text{ THE DYNAMIC LOAD OF TRIPPED CONTROL RODS.} \end{aligned}$$

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-211-P | A150

SHEET 42 OF 69

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEILKER

5. DETAILED ANALYSIS:

e. STRESSES:

1- COMBINED STRESSES - UNCONCENTRATED:

EARTHQUAKE LOADING THRU SUPPORTS:

THE EQUATIONS FOR STRESS DUE TO THE EARTHQUAKE LOADING THROUGH THE SUPPORTS WILL BE THE SAME AS FOR THE THERMAL INDUCED PIPE REACTIONS WITH THE FOLLOWING VALUES FOR  $\bar{F}_y$ ,  $\bar{F}_z$ ,  $\bar{M}_x$ ,  $\bar{M}_y$ , AND  $\bar{M}_z$

$$\begin{aligned} \bar{F}_y = V &= -126.4 & \bar{M}_x &= -27H = -9090.9 \\ \bar{F}_z = H &= 336.7 & \bar{M}_y &= 13H = 4377.1 \\ & & \bar{M}_z &= -13V = 1643.2 \end{aligned}$$

THERMAL EXPANSION AND CONTRACTION:

THE EQUATIONS FOR STRESS DUE TO EXPANSION AND CONTRACTION ARE AS FOLLOWS WITH THE VALUES FOR  $\bar{F}_x$  AND  $\bar{M}_z$  EQUAL TO.

$$\left. \begin{aligned} \bar{F}_x = F &= 168.3 \\ \bar{M}_z = 28F &= 4712.4 \end{aligned} \right\} \text{SEE SHEET 16 FOR VALUES OF F.}$$

	LOCATION - 7		LOCATION - 8	
$\sigma_x = -\frac{\bar{F}_x}{A} \pm \frac{\bar{M}_z}{I}$	$= -0.00071 \bar{F}_x + 0.00005 \bar{M}_z$	POINT A	$= -0.00071 \bar{F}_x + 0.00008 \bar{M}_z$	POINT A
	$= -0.00071 \bar{F}_x - 0.00005 \bar{M}_z$	B	$= -0.00071 \bar{F}_x - 0.00008 \bar{M}_z$	B
	$= -0.00071 \bar{F}_x$	C	$= -0.00071 \bar{F}_x$	C
	$= -0.00071 \bar{F}_x$	D	$= -0.00071 \bar{F}_x$	D

	LOCATION - 7	LOCATION - 8	
$\sigma_x = 0.00069 F$	$= 0.00153 F$		POINT A
$= -0.00211 F$	$= -0.00295 F$		B
$= -0.00071 F$	$= -0.00071 F$		C
$= -0.00071 F$	$= -0.00071 F$		D

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A151  
SHEET 43 OF 69  
DATE 4-22-68 BY COCKRELL  
CHECK DATE 4-22-68 BY HEILKER

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

5- DETAILED ANALYSIS:

a- STRESSES:

1- COMBINED STRESSES - UNCONCENTRATED:

LOCATION 9&10:

PRESSURE STRESS:


NOTE HERE THAT IT WILL BE NECESSARY TO CALCULATE STRESSES IN BOTH THE LONGITUDINAL AND CIRCUMFERENTIAL DIRECTIONS FOR PRESSURE

POINTS A & B (LONGITUDINAL PLANE):

$$\sigma_x = \pm \frac{6M_x}{t_s^2} - \frac{H_x}{t_s} + \frac{V_x \sin \phi}{t_s} = \pm 0.05192 M_x - 0.09302 H_x + 0.0882 P$$

$$\sigma_\theta = \pm \frac{\sqrt{6} M_\theta}{t_s} + \frac{E W_\theta}{R_s \sin \phi} + \frac{D_x P}{t_s} = \pm 0.01558 M_\theta + 0.0462 E W_\theta + 7.9477 P$$

$$\sigma_r = -P$$



POINTS C & D (CIRCUMFERENTIAL PLANE):

$$\sigma_x = \pm \frac{\sqrt{6} M_x}{t_s} + \frac{E W_x}{R_s \sin \phi} + \frac{D_x P}{2R_s t_s} = \pm 0.01558 M_x + 0.0462 E W_x + 3.7297 P$$

$$\sigma_\theta = \pm \frac{6M_\theta}{t_s^2} - \frac{H_\theta}{t_s} + \frac{V_\theta \sin \phi}{t_s} = \pm 0.05192 M_\theta - 0.0918 H_\theta + 0.0882 P$$

$$\sigma_r = -P$$

THERMAL STRESS:

POINTS A & B (LONGITUDINAL PLANE):

$$\sigma_x = \pm \frac{6M_x}{t_s^2} - \frac{H_x}{t_s} = \pm 0.05192 M_x - 0.0930 H_x$$

$$\sigma_\theta = \pm \frac{\sqrt{6} M_\theta}{t_s} + \frac{E W_\theta}{R_s \sin \phi} = \pm 0.01558 M_\theta + 0.0462 E W_\theta$$

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A 152

SHEET 44 OF 69

CHARGE NO. 6866

DATE 4-22-68 BY LOCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORT

CHECK DATE 4-22-68 BY HEILKER

5. DETAILED ANALYSIS:

e. STRESSES:

1. COMBINED STRESSES - UNCONCENTRATED:

POINTS C & D (CIRCUMFERENTIAL PLANE):


$$\sigma_x = \pm \frac{r M_x}{I_x} + \frac{E M_x}{R_s S M P} = \pm 0.01558 M_x + 0.0462 E W_x$$

$$\sigma_\theta = \pm \frac{6 M_x}{t^3} - \frac{H_{\text{CORD}}}{t_s} = \pm 0.05192 M_x - 0.0918 H_x$$

THERMAL INDUCED PIPE REACTIONS:

THE STRESSES IN THE VESSEL WALL DUE TO THE THERMALLY INDUCED PIPE REACTIONS WILL BE CALCULATED BY THE METHOD OUTLINED IN REF. 21 FOR A CYLINDRICAL ATTACHMENT TO A CYLINDRICAL SHELL. SINCE THE PIPE REACTIONS ARE APPLIED AT THE SMALL END OF THE NOZZLE, THEY MUST BE RESOLVED TO THE MID-RADIUS OF THE VESSEL WALL. THIS IS DONE BY THE FOLLOWING RELATIONSHIP OF FORCES.

$F_x = F_x = 14.8$	$\bar{M}_x = M_x = -3783$
$F_y = F_y = -92$	$\bar{M}_y = M_y + 35.688 F_z = 5480.4$
$F_z = F_z = 27.5$	$\bar{M}_z = M_z - 35.688 F_y = 10724.3$



WITH THE GEOMETRIC PARAMETERS OF  $\gamma = \frac{R_m}{T} = 8.5$  AND  $\beta = 0.875 \frac{r_0}{R_m} = 0.260$  AND THE CURVES IN REF. 21 WE GET THE FOLLOWING EXPRESSIONS FOR STRESS.



COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO.

DESCRIPTION: STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

NUMBER 5-211-P 1 A153

SHEET 45 OF 109

DATE 4-22-68 BY BARRELL

CHECK DATE 4-22-68 BY LEWIS

5. DETAILED ANALYSIS:  
A. STRESSES:

1. COMBINED STRESSES - UNRAIL RATED:

$$\sigma_x = \left( \frac{N_x}{F_x/R_m} \right) \frac{\bar{F}_x}{R_m T} \pm \left( \frac{M_x}{F_x} \right) \frac{6\bar{F}_x}{T^2} \pm \left( \frac{N_y}{M_y/R_m\beta} \right) \frac{\bar{M}_y}{R_m\beta T} \pm \left( \frac{M_y}{M_y/R_m\beta} \right) \frac{6\bar{M}_y}{R_m\beta T^2} \pm \left( \frac{N_z}{M_z/R_m\beta} \right) \frac{\bar{M}_z}{R_m\beta T} \pm \left( \frac{M_z}{M_z/R_m\beta} \right) \frac{6\bar{M}_z}{R_m\beta T^2}$$

$$= -(1.45) \frac{\bar{F}_x}{978.58} \pm (0.072) \frac{6\bar{F}_x}{115.56} \pm (0.50) \frac{\bar{M}_y}{23162} \pm (0.055) \frac{6\bar{M}_y}{2735.2} \pm (0.28) \frac{\bar{M}_z}{23162} \pm (0.067) \frac{6\bar{M}_z}{2735.2}$$

LOCATION - 9		LOCATION - 10	
-0.00148 $\bar{F}_x$ + 0.00374 $\bar{F}_y$ + 0.000012 $\bar{M}_z$ - 0.00015 $\bar{M}_2$ POINT A		-0.00148 $\bar{F}_x$ - 0.00374 $\bar{F}_y$ + 0.000012 $\bar{M}_z$ + 0.00015 $\bar{M}_2$ POINT H	
-0.00148 $\bar{F}_x$ + 0.00374 $\bar{F}_y$ - 0.000012 $\bar{M}_z$ + 0.00015 $\bar{M}_2$ B		-0.00148 $\bar{F}_x$ - 0.00374 $\bar{F}_y$ - 0.000012 $\bar{M}_z$ - 0.00015 $\bar{M}_2$ B	
-0.00148 $\bar{F}_x$ + 0.00374 $\bar{F}_y$ + 0.000022 $\bar{M}_y$ - 0.00012 $\bar{M}_4$ C		-0.00148 $\bar{F}_x$ - 0.00374 $\bar{F}_y$ + 0.000022 $\bar{M}_y$ + 0.00012 $\bar{M}_4$ C	
-0.00148 $\bar{F}_x$ + 0.00374 $\bar{F}_y$ - 0.000022 $\bar{M}_y$ + 0.00012 $\bar{M}_4$ D		-0.00148 $\bar{F}_x$ - 0.00374 $\bar{F}_y$ - 0.000022 $\bar{M}_y$ - 0.00012 $\bar{M}_4$ D	

$$\sigma_D = \left( \frac{N_D}{F_x/R_m} \right) \frac{\bar{F}_x}{R_m T} \pm \left( \frac{M_D}{F_x} \right) \frac{6\bar{F}_x}{T^2} \pm \left( \frac{N_y}{M_y/R_m\beta} \right) \frac{\bar{M}_y}{R_m\beta T} \pm \left( \frac{M_y}{M_y/R_m\beta} \right) \frac{6\bar{M}_y}{R_m\beta T^2} \pm \left( \frac{N_z}{M_z/R_m\beta} \right) \frac{\bar{M}_z}{R_m\beta T} \pm \left( \frac{M_z}{M_z/R_m\beta} \right) \frac{6\bar{M}_z}{R_m\beta T^2}$$

$$= -(1.25) \frac{\bar{F}_x}{978.58} \pm (0.094) \frac{6\bar{F}_x}{115.56} \pm (0.27) \frac{\bar{M}_y}{23162} \pm (0.097) \frac{6\bar{M}_y}{2735.2} \pm (1.00) \frac{\bar{M}_z}{23162} \pm (0.042) \frac{6\bar{M}_z}{2735.2}$$

LOCATION - 9		LOCATION - 10	
-0.00128 $\bar{F}_x$ + 0.00488 $\bar{F}_y$ + 0.000043 $\bar{M}_z$ - 0.000092 $\bar{M}_2$ POINT A		-0.00128 $\bar{F}_x$ - 0.00488 $\bar{F}_y$ + 0.000043 $\bar{M}_z$ + 0.000092 $\bar{M}_2$ POINT A	
-0.00128 $\bar{F}_x$ + 0.00488 $\bar{F}_y$ - 0.000043 $\bar{M}_z$ + 0.000092 $\bar{M}_2$ B		-0.00128 $\bar{F}_x$ - 0.00488 $\bar{F}_y$ - 0.000043 $\bar{M}_z$ - 0.000092 $\bar{M}_2$ B	
-0.00128 $\bar{F}_x$ + 0.00488 $\bar{F}_y$ + 0.000012 $\bar{M}_y$ - 0.00021 $\bar{M}_4$ C		-0.00128 $\bar{F}_x$ - 0.00488 $\bar{F}_y$ + 0.000012 $\bar{M}_y$ + 0.00021 $\bar{M}_4$ C	
-0.00128 $\bar{F}_x$ + 0.00488 $\bar{F}_y$ - 0.000012 $\bar{M}_y$ + 0.00021 $\bar{M}_4$ D		-0.00128 $\bar{F}_x$ - 0.00488 $\bar{F}_y$ - 0.000012 $\bar{M}_y$ - 0.00021 $\bar{M}_4$ D	

LOCATION 9 & 10

$$\tau_{xy} \pm \frac{\bar{F}_x}{\pi r_0 T} \pm \frac{\bar{F}_y}{\pi r_0 T} + \frac{\bar{M}_x}{2\pi r_0 T} = 0.00110 \bar{F}_y + 0.00002 \bar{M}_x \text{ POINT A}$$

$$= -0.00110 \bar{F}_y + 0.00002 \bar{M}_x \text{ B}$$

$$= 0.00110 \bar{F}_y + 0.00002 \bar{M}_x \text{ C}$$

$$= -0.00110 \bar{F}_y + 0.00002 \bar{M}_x \text{ D}$$

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTNUMBER 5-211-P | A154SHEET 46 OF 69DATE 4-22-68 BY COCKRELLCHECK DATE 4-22-68 BY HEUKER5. DETAILED ANALYSIS:C. STRESSES:1. COMBINED STRESSES - UNCONCENTRATED:SEISMIC PIPE REACTIONS

THE EQUATIONS FOR STRESS FOR THE SEISMIC PIPE REACTIONS WILL BE THE SAME AS FOR THE THERMALLY INDUCED PIPE REACTIONS. THE VALUES FOR  $\bar{F}_x$ ,  $\bar{F}_y$ ,  $\bar{F}_z$ ,  $\bar{M}_x$ ,  $\bar{M}_y$ , AND  $\bar{M}_z$  WILL BE AS FOLLOWS. SEE SHEET 13 FOR VALUES OF H AND V.

$$\begin{aligned} \bar{F}_x &= F_x = -57.9 & \bar{M}_x &= M_x - 27H = -14927.5 \\ \bar{F}_y &= F_y + V = -340.2 & \bar{M}_y &= M_y + 35.688F_z + 18.375H = 27205.6 \\ \bar{F}_z &= F_z + H = 649.4 & \bar{M}_z &= M_z - 35.688F_y - 18.375V = 17321.1 \end{aligned}$$

STATIC LOADING THROUGH SUPPORTS:

THE EQUATIONS FOR STRESS ARE THE SAME AS FOR THE THERMALLY INDUCED PIPE REACTIONS WITH THE FOLLOWING VALUES FOR  $\bar{F}_y$  AND  $\bar{M}_z$

$$\begin{aligned} \bar{F}_y &= V = 561.1 & \text{SEE SHEET 14 FOR VALUES OF V WITH OR} \\ \bar{M}_z &= -18.375V & \text{WITHOUT THE DYNAMIC LOAD OF TRIPPED CONTROL RODS.} \\ &= -10310.2 \end{aligned}$$

EARTHQUAKE LOADING THROUGH SUPPORTS:

THE EQUATIONS FOR STRESS ARE THE SAME AS FOR THE THERMALLY INDUCED PIPE REACTIONS WITH THE FOLLOWING VALUES FOR  $\bar{F}_y$ ,  $\bar{F}_z$ ,  $\bar{M}_x$ ,  $\bar{M}_y$ , AND  $\bar{M}_z$ .

$$\begin{aligned} \bar{F}_y &= V = -126.4 & \bar{M}_x &= -27H = -9090.9 \\ \bar{F}_z &= H = 336.7 & \bar{M}_y &= 18.375H = 6186.9 \\ & & \bar{M}_z &= -18.375V = 2322.6 \end{aligned}$$

COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

NUMBER S-211-P | 1A155

SHEET 47 OF 69

DATE 4-22-68 BY COCKBELL

CHECK DATE 4-22-68 BY HEUER

5- DETAILED ANALYSIS:

c- STRESSES:

1- COMBINED STRESSES - UNCONCENTRATED:

THERMAL EXPANSION AND CONTRACTION:

THE EQUATIONS FOR STRESS ARE THE SAME AS FOR THE THERMALLY INDUCED PIPE REACTIONS WITH THE FOLLOWING VALUES FOR  $\bar{F}_x$  &  $\bar{M}_z$

$\bar{F}_x = F = \pm 168.3 \text{ KIPS}$   
 $\bar{M}_z = 28F = \pm 4712.4 \text{ IN-KIPS}$

CONSIDER CRITERION S.B.I.:

THE CROSS SECTION OF INTEREST IS THE SECTION SHOWN ON SHEET AD FOR LOCATIONS 7 & 8. SINCE THERE IS BENDING IN TWO DIRECTIONS, THE FOLLOWING RELATIONSHIPS WILL BE USED TO DETERMINE THE MAXIMUM EFFECT OF BENDING BY THE THERMAL AND DESIGN SEISMIC PIPE LOADS, WEIGHT, ETC.

$$\sigma_x = -\frac{\bar{F}_x}{A} \pm \frac{c}{I} \sqrt{\bar{M}_y^2 + \bar{M}_z^2} = -0.00071 \bar{F}_x \pm 0.00005 \sqrt{\bar{M}_y^2 + \bar{M}_z^2} \text{ INSIDE}$$
  
$$= -0.00071 \bar{F}_x \pm 0.00008 \sqrt{\bar{M}_y^2 + \bar{M}_z^2} \text{ OUTSIDE}$$

$$T_{x\theta} = \frac{\theta}{I_b} [\bar{F}_y \sin\theta + \bar{F}_z \cos\theta] + \frac{\bar{M}_x c}{2I} = 0.00138 [\bar{F}_y \sin\theta + \bar{F}_z \cos\theta] \pm 0.000024 \bar{M}_x \text{ INSIDE}$$
  
$$= 0.00138 [\bar{F}_y \sin\theta + \bar{F}_z \cos\theta] \pm 0.000038 \bar{M}_x \text{ OUTSIDE}$$

$$\theta = \tan^{-1} \frac{\bar{M}_y}{\bar{M}_z}$$

LOCATION	PRESSURE STRESS			DUE TO EXT. LOADS, WEIGHT, ETC.		PRINCIPAL STRESS			STRESS INTENSITY		
	$\sigma_x$	$\sigma_\theta$	$\sigma_r$	$\sigma_x$	$T_{x\theta}$	$\sigma_1$	$\sigma_2$	$\sigma_3$	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$
7	1.55	4.09	-2.5	1.99	0.17	4.14	3.49	-2.5	0.65	6.64	5.99
	↓	↓	-2.5	-2.17	1.50	4.53	-1.06	-2.5	5.59	7.03	1.44
8	↓	↓	0	3.24	-0.21	4.85	4.03	0	0.82	4.85	4.03
	↓	↓	0	-3.42	1.90	4.64	-2.42	0	7.06	4.64	-2.42

$SI_{MAX} = \sigma_1 - \sigma_2 = 7.06 \text{ KSI} < S_m = 26.7 \text{ KSI}$  LOCATION 8

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A156  
SHEET 48 OF 69  
DATE 4-22-69 BY COCKRELL  
CHECK DATE 4-22-69 BY HEIKER

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

e. STRESSES:

1. COMBINED STRESSES - UNCONCENTRATED:

CONSIDER CRITERION 5.b.2:

CUT	BODY	b <sup>2</sup> P 2Rt	bP t	FW R	σ <sub>x</sub>	σ <sub>θ</sub>	σ <sub>r</sub>	STRESS INTENSITY		
								σ <sub>x</sub> -σ <sub>θ</sub>	σ <sub>r</sub> -σ <sub>r</sub>	σ <sub>θ</sub> -σ <sub>r</sub>
1	1	6.30	13.75	3.16	6.30	16.91	-1.25	-10.61	7.55	18.16
1	2	6.86	15.07	1.90	6.86	16.97	↓	-10.11	8.11	18.22
2	2	6.59	14.47	-3.59	6.59	10.88	↓	-4.29	7.84	12.13
4	4	1.55	4.09	17.79	1.55	21.88	↓	-20.33	2.80	23.13
4	5 LONG AXIS	7.16	19.87	11.15	7.16	31.02	↓	-23.86	8.41	32.27
4	5 CIRC S AXIS	9.32	7.07	11.15	20.47	7.07	↓	13.40	21.72	8.32

$S.I._{MAX} = \sigma_{\theta} - \sigma_r = 32.27 \text{ KSI} < 1.5 S_m = 40 \text{ KSI}$  CUT 4 BODY 5  
LONGITUDINAL AXIS  
SEE SHEET  
POINTS 9 & 10

CONSIDER CRITERION 5.b.3:

LOCATION	PRESSURE STRESS			STRESS DUE TO PIPE LOADS, WEIGHT, ETC			PRINCIPAL STRESS			STRESS INTENSITY		
	σ <sub>x</sub>	σ <sub>θ</sub>	σ <sub>r</sub>	σ <sub>x</sub>	σ <sub>θ</sub>	T <sub>xy</sub>	σ <sub>1</sub>	σ <sub>2</sub>	σ <sub>3</sub>	σ <sub>1</sub> -σ <sub>2</sub>	σ <sub>1</sub> -σ <sub>3</sub>	σ <sub>2</sub> -σ <sub>3</sub>
9A	7.16	31.02	-2.5	4.53	1.30	1.20	32.34	11.67	-2.5	20.67	34.84	14.17
B	7.16	31.02	↓	4.01	2.11	1.56	33.24	11.06	↓	22.18	35.74	13.56
C	20.47	7.07	↓	3.85	7.42	1.61	24.58	14.22	↓	10.36	27.08	16.72
D	20.47	7.07	↓	4.29	8.64	-1.25	24.79	15.55	↓	9.24	27.29	18.05
10A	7.16	31.02	0	3.36	2.57	1.20	33.60	10.51	0	23.09	33.60	10.51
B	7.16	31.02	↓	6.73	6.24	1.56	37.37	13.79	↓	23.58	37.37	13.79
C	20.47	7.07	↓	6.62	9.93	1.61	27.12	16.97	↓	10.15	27.12	16.97
D	20.47	7.07	↓	5.86	8.74	-1.25	26.48	15.66	↓	10.82	26.48	15.66

$S.I._{MAX} = \sigma_1 - \sigma_3 = 37.4 \text{ KSI} < 1.5 S_m = 40 \text{ KSI}$  LOCATION 10B

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A157

SHEET 49 OF 69

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEIKER

5- DETAILED ANALYSIS:

a. - STRESSES:

1- COMBINED STRESSES - UNCONCENTRATED:

CONSIDER CRITERION 5.6.4:

SAFE END

$$\sigma_x = -\frac{F_x}{A} \pm \frac{C}{I} \sqrt{M_y^2 + M_z^2} = -0.00424 F_x \pm 0.00052 \sqrt{M_y^2 + M_z^2} \quad \text{POINT 1}$$

$$= -0.00424 F_x \pm 0.00061 \sqrt{M_y^2 + M_z^2} \quad \text{POINT 2}$$

$$T_{xy} = \frac{Q}{Ib} [F_y \sin \theta + F_z \cos \theta] \pm \frac{M_x Q}{2I} = 0.00945 [F_y \sin \theta + F_z \cos \theta] \pm 0.00026 M_x \quad \text{POINT 1}$$

$$\theta = \tan^{-1} \frac{M_y}{M_z} = 0.00845 [F_y \sin \theta + F_z \cos \theta] \pm 0.00031 M_x \quad \text{POINT 2}$$

LOCATION	PRESSURE STRESS			STRESS DUE TO SHOCK LOADS		PRINCIPAL STRESS			STRESS INTENSITY		
	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\sigma_x$	$T_{xy}$	$\sigma_1$	$\sigma_2$	$\sigma_3$	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$
1	6.30	16.91	-2.5	8.74	1.39	17.50	14.25	-2.5	3.25	20.00	16.75
			-2.5	-8.24	0.87	16.95	-1.99	-2.5	18.93	19.45	0.52
2			0	10.21	1.43	19.16	16.28	0	2.88	19.16	16.28
			0	-9.71	0.83	16.94	-3.44	0	20.38	16.94	-3.44

$S.I._{max} = \sigma_1 - \sigma_2 = 20.38 \text{ KSI} < 1.5 S_m = 25.05 \text{ KSI} \quad \text{LOCATION -}$

SMALL END OF NOZZLE

$$\sigma_0 = -\frac{F_x}{A} \pm \frac{C}{I} \sqrt{M_y^2 + M_z^2} = -0.00462 F_x \pm 0.00056 \sqrt{M_y^2 + M_z^2} \quad \text{POINT 3}$$

$$= -0.00462 F_x \pm 0.00065 \sqrt{M_y^2 + M_z^2} \quad \text{POINT 4}$$

$$T_{xy} = \frac{Q}{Ib} [F_y \sin \theta + F_z \cos \theta] \pm \frac{M_x Q}{2I} = 0.00926 [F_y \sin \theta + F_z \cos \theta] \pm 0.00029 M_x \quad \text{POINT 3}$$

$$\theta = \tan^{-1} \frac{M_y}{M_z} = [F_y \sin \theta + F_z \cos \theta] \pm 0.00033 M_x \quad \text{POINT 4}$$

LOCATION	PRESSURE STRESS			STRESS DUE TO SHOCK LOADS		PRINCIPAL STRESS			STRESS INTENSITY		
	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\sigma_x$	$T_{xy}$	$\sigma_1$	$\sigma_2$	$\sigma_3$	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$
3	6.96	16.97	-2.5	9.41	1.51	18.17	15.07	-2.5	3.10	20.67	17.57
			-2.5	-8.87	0.97	17.02	-2.06	-2.5	19.08	19.52	0.44
4			0	10.88	1.56	18.96	15.75	0	3.21	18.96	15.75
			0	-10.34	0.92	17.01	-3.52	0	20.53	17.01	-3.52

$S.I._{max} = \sigma_1 - \sigma_3 = 20.67 \text{ KSI} < 1.5 S_m = 40.05 \text{ KSI} \quad \text{LOCATION 3}$

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTNUMBER 5-211-P | A158SHEET 50 OF 69DATE 4-22-68 BY COCKRELLCHECK DATE 4-22-68 BY HEKKER5. DETAILED ANALYSIS:B. STRESSES:1. COMBINED STRESSES - UNCONCENTRATED:CONSIDER CRITERION S.D.S.?

NOTE HERE THAT THE RANGE OF STRESS INTENSITY WAS CALCULATED AT THE TEN LOCATIONS AS SHOWN ON SHEET 17 FOR THE FOUR ORIENTATIONS A, B, C AND D. THE FOLLOWING TABLE GIVES THE RANGE OF STRESS INTENSITY FOR EACH LOCATION AND ORIENTATION. STRESSES AND STRESS INTENSITIES PRODUCING THESE RANGE OF STRESS INTENSITIES WILL NOT BE PRESENTED FOR ALL LOCATIONS AND ORIENTATIONS. ONLY STRESSES AND STRESS INTENSITIES AT THE LOCATION AND ORIENTATION WHICH PRODUCED THE HIGHEST RANGE OF STRESS WILL BE PRESENTED. THIS WAS LOCATION-10B.

LOCATION AND ORIENTATION	S.I. RANGE
1A	24.31
B	26.93
C	27.26
D	28.17
2A	33.31
B	33.46
C	33.48
D	32.27
3A	31.14
B	39.14
C	34.36
D	39.80
4A	37.68
B	35.45
C	36.74
D	35.35

LOCATION AND ORIENTATION	S.I. RANGE
5A	28.12
B	25.30
C	26.89
D	26.43
6A	36.70
B	37.07
C	36.70
D	36.70
7A	18.29
B	18.28
C	18.44
D	18.44
8A	33.28
B	33.28
C	33.33
D	33.33

LOCATION AND ORIENTATION	S.I. RANGE
9A	41.44
B	43.28
C	29.32
D	29.32
10A	42.75
B	45.54
C	32.20
D	31.05

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A159

SHEET 51 OF 69

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COPPELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEILNER

5. DETAILED ANALYSIS:

e- STRESSES:

1. COMBINED STRESSES - UNCOMBUTRATED:

LOCATION 10B

TRANSIENT	PRESSURE STRESS		THERMAL STRESS		THERMAL INDUCED PIPE BEND STRESS		SEISMIC PIPE BEND STRESS		STATIC WEIGHT STRESS			
	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$		
4.04HS	10.16	16.70	-0.15	-1.09	-1.62	-1.38	-0.09	-2.50	-1.98	1.67	1.39	0
4.25	17.87	29.35	-0.02	-1.11	-1.73	-1.46	-0.10					
4.35	18.54	30.46	-0.02	-1.11	-1.77	-1.50	-0.10					
4.47	19.35	31.78	0.17	-1.13	-1.81	-1.54	-0.11					
5.00	19.35	31.78	0.24	-0.66	-1.81	-1.54	-0.11					
4.00	10.16	16.70	-0.15	-1.09	-1.62	-1.38	-0.09	2.50	1.98			
4.25	17.87	29.35	-0.02	-1.11	-1.73	-1.46	-0.10					
4.35	18.54	30.46	-0.02	-1.11	-1.77	-1.50	-0.10					
4.47	19.35	31.78	0.17	-1.13	-1.81	-1.54	-0.11					
5.00	19.35	31.78	0.24	-0.66	-1.81	-1.54	-0.11					
STEADY-STATE			0.03	0.03	-1.81	-1.54	-0.11	-2.50	-1.98			
			0.03	0.03	-1.81	-1.54	-0.11	2.50	1.98			
			0.03	0.03	-1.81	-1.54	-0.11	0	0			
4.04HS	2.71	4.45	0.19	1.03	-0.19	-0.16	-0.01	-2.50	-1.98			
4.25			0.06	1.04	-0.09	-0.08	-0.01					
4.35			0.06	1.04	-0.05	-0.04	0					
4.47			-0.14	1.06	0	0	0					
5.00			-0.21	0.61	0	0	0					
4.00			0.19	1.03	-0.19	-0.16	-0.01	2.50	1.98			
4.25			0.06	1.04	-0.09	-0.08	-0.01					
4.35			0.06	1.04	-0.05	-0.04	0					
4.47			-0.14	1.06	0	0	0					
5.00			-0.21	0.61	0	0	0					

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-D 1 ALB

SHEET 52 OF 69

DATE 4-22-68 BY COOPER

CHECK DATE 4-22-68 BY HEILER

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION OF INLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:  
E. STRESSES:

1. COMBINED STRESSES - UNCORRECTED

LOCATION 10B

TRANSIENT		PRESSURE STRESS			THERMAL STRESS		THERMAL INDUCED PIPE REACTION STRESS			SEISMIC PIPE REACTION STRESS			STATIC WEIGHT STRESS		
		$\sigma_x$	$\sigma_y$	$\sigma_z$	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$T_{ho}$	$\sigma_x$	$\sigma_y$	$T_{ho}$	$\sigma_x$	$\sigma_y$	$T_{ho}$
c	20 min	19.35	31.78	0	0.03	-0.03	-1.81	-1.54	-0.11	0	0	0	1.67	1.39	0
d	20 min	19.35	31.78												
e	160 sec	18.40	30.23												
	225 sec	19.56	32.14												
f	40 sec	19.95	32.77												
	100 sec	19.43	31.93												
	260 sec	18.40	30.23												
g	2 min	20.38	33.48												
	3.2 min	20.21	33.20												
	10.9 min	18.49	30.37												
h	10 sec	19.09	31.36												
	65 sec	16.42	26.98												
i	220 min	26.87	44.14		0	0	0	0	0						
j	A.D. 3.0 HRS	10.75	17.66		-0.30	-0.50	-1.22	-1.04	-0.08						
	S.S. 2.0	21.50	35.32		0.02	-0.02	-1.22	-1.04	-0.08						
	3.0 HRS	2.71	4.45		0.14	0.48	0	0	0						
k	~	20.21	33.20		0.03	-0.03	-1.81	-1.54	-0.11						
	~	18.49	30.37												
l	12 sec	19.35	31.78												
m	10 sec	23.73	38.99												
	28 sec	18.23	29.95												
	160 sec	12.39	20.34												
n	33 sec	2.58	4.24												
	54 sec	6.02	9.89												



COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | 1  
SHEET 53 OF 69 ALB

DATE 4-22-65 BY CKE/EL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION OF INLET NOZZLE - VESSEL SUPPORTS CHECK DATE 4-22-65 BY WEL/EL

5. DETAILED ANALYSIS:

a. STRESSES:

1. (OBTAINED STRESSES - UNSTABILIZED):

TRANSIENT	EARTHQUAKE LOADING THROUGH SUPPORTS STRESS			EXPANSION AND CONTRACTION STRESS		TOTAL STRESS			PRINCIPAL STRESS			STRESS INTENSITY				
	$\sigma_x$	$\sigma_y$	$\tau_{xy}$	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$\sigma_r$	$\tau_{xy}$	$\sigma_1$	$\sigma_2$	$\sigma_3$	$\sigma_1-\sigma_2$	$\sigma_1-\sigma_3$	$\sigma_2-\sigma_3$	
2 - HEATING	4.00 HRS	-0.38	-0.31	-0.55	-1.64	-1.67	5.53	11.65	0	-1.66	12.07	5.11	0	6.96	12.07	5.11
	4.25						13.27	24.21		-1.67	24.46	13.02		11.44	24.46	13.02
	4.35						13.90	25.28		-1.67	25.52	13.66		11.86	25.52	13.66
	4.47						14.86	26.54		-1.67	26.78	14.62		12.16	26.78	14.62
	5.00						14.92	27.01		-1.67	27.24	14.69		12.54	27.24	14.69
	4.00	0.38	0.31	0.55			11.29	16.24		1.47	16.64	10.89		5.75	16.64	10.89
	4.25						19.03	28.80		1.46	29.01	18.81		10.20	29.01	18.81
	4.35						19.67	29.89		1.46	30.10	19.47		10.63	30.10	19.47
	4.47						20.62	31.13		1.46	31.33	20.42		10.91	31.33	20.42
	5.00						20.68	31.60		1.46	31.79	20.49		11.30	31.79	20.49
STEADY-STATE		-0.38	-0.31	-0.55	0	0	16.35	29.31		-1.67	29.52	16.14		13.38	29.52	16.14
		0.38	0.31	0.55			22.11	33.90		1.46	34.08	21.93		12.14	34.08	21.93
		0	0	0			19.23	31.61		-0.11	31.61	19.23		12.38	31.61	19.23
6 - COOLDOWN	4.00 HRS	-0.38	-0.31	-0.55	1.64	1.67	3.14	6.09		-1.58	6.77	2.45		4.32	6.77	2.45
	4.25						3.11	6.18		-1.57	6.84	2.45		4.40	6.84	2.45
	4.35						3.15	6.22		-1.57	6.97	2.49		4.39	6.97	2.49
	4.47						3.00	6.28		-1.57	6.90	2.57		4.53	6.90	2.37
	5.00						2.93	5.93		-1.57	6.51	2.25		4.26	6.51	2.25
	4.00	0.38	0.31	0.55			9.39	12.67		1.55	11.58	7.99		3.58	11.58	7.99
	4.25						9.97	10.77		1.56	11.65	7.99		3.66	11.65	7.99
	4.35						9.91	10.81		1.56	11.63	8.03		3.66	11.63	8.03
	4.47						9.76	10.97		1.57	11.70	7.93		3.77	11.70	7.93
	5.00						9.69	10.42		1.57	11.34	7.77		3.57	11.34	7.77

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER 5-211-P OF 69  
SHEET 54  
DATE 4-22-69 BY ARKRELL

DESCRIPTION: Structural And Fatigue Evaluation Of Water Nozzle - Vessel Supports  
CHECK DATE 4-22-69 BY HECKER

5. Detailed Analysis:  
C. Stresses:  
1. Computed Stresses - Unstressed:

LOCATION 10B

TRANSIENT	EARTHQUAKE LOADING THROUGH SUPPORTS STRESS			EXPANSION AND CONTRACTION STRESS		TOTAL STRESS				PRINCIPAL STRESS			STRESS INTENSITY		
	$\sigma_x$	$\sigma_y$	$T_{xy}$	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$\sigma_z$	$T_{xy}$	$\sigma_1$	$\sigma_2$	$\sigma_3$	$\sigma_1-\sigma_2$	$\sigma_1-\sigma_3$	$\sigma_2-\sigma_3$
c 20 min	0	0	0	0	0	19.23	31.61	0	-0.11	31.61	19.23	0	12.38	31.61	19.23
d 20 min						19.23	31.61			31.61	19.23		12.37	31.61	19.23
e 100 SEC 275 SEC						18.29	30.05			30.05	18.29		11.77	30.05	18.29
						19.45	31.96			31.96	19.45		12.51	31.96	19.45
f 40 SEC 100 SEC 260 SEC						19.04	32.59			32.60	19.83		12.76	32.60	19.83
						19.32	31.75			31.75	19.32		12.43	31.75	19.32
g 2 min 3.2 min 10.4 min						18.29	30.05			30.05	18.29		11.77	30.05	18.29
						20.27	33.30			33.30	20.26		13.04	33.30	20.26
h 10 SEC 65 SEC						20.09	33.02			33.02	20.09		12.93	33.02	20.09
						18.37	30.19			30.19	18.37		11.82	30.19	18.37
i 220 min H.D. 3.0 HRS S.S. C.D. 3.0 HRS						18.98	31.18			31.18	18.97		12.21	31.18	18.97
						16.31	26.80		↓	26.80	16.31		10.50	26.80	16.31
j						28.54	45.54		0	45.54	28.54		16.99	45.54	28.54
						10.90	17.51		-0.08	17.51	10.90		6.61	17.51	10.90
k ~ ~						21.97	35.65		-0.08	35.65	21.96		13.68	35.65	21.96
						4.51	6.33		0	6.33	4.51		1.81	6.33	4.51
l 12 SEC						20.09	33.02		-0.11	33.02	20.09		12.93	33.02	20.09
						18.37	30.19			30.19	18.37		11.82	30.19	18.37
m 10 SEC 28 SEC 160 SEC						19.23	31.61			31.61	19.23		12.37	31.61	19.23
						23.62	39.81			39.81	23.62		15.19	39.81	23.62
n 33 SEC 54 SEC						19.12	29.77			29.77	18.11		11.66	29.77	18.11
						12.27	20.16			20.16	12.27		7.90	20.16	12.27
						2.46	4.06			4.07	2.46		1.61	4.07	2.46
						5.90	9.71			9.71	5.90		3.81	9.71	5.90

**COMBUSTION ENGINEERING, INC.**  
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A163

SHEET 55 OF 69

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY CORRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEILKER

5. DETAILED ANALYSIS:

c. STRESSES:

1. COMBINED STRESSES - UNCONCENTRATED:

CONSIDER STRESSES DURING NO. LOSS OF FUNCTION SEISMIC LOADING:

IN THIS SECTION THE ALLOWABLE STRESSES LISTED ON SHEET 7 FOR CRITERION 5.6.1, 5.6.3, AND 5.6.4 WILL BE INCREASED BY A FACTOR OF 1.2, SEE REF 10.

CONSIDER CRITERION 5.6.1:

LOCATION	PRESSURE STRESS			STRESS DUE TO EXTERNAL LOADS			PRINCIPAL STRESS			STRESS INTENSITY		
	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\sigma_x$	$\tau_{xy}$	$\tau_{yz}$	$\sigma_1$	$\sigma_2$	$\sigma_3$	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$
7	1.55	4.09	-2.5	3.08	-0.36		4.81	3.91	-2.5	0.90	7.31	6.41
			-2.5	-3.22	1.78		4.60	-2.18	-2.5	6.78	7.10	0.32
8			0	4.97	-0.99		6.87	3.34	0	3.13	6.87	3.34
			0	-5.11	2.41		4.79	-4.26	0	9.05	4.79	-4.26

$S.I._{MAX} = \sigma_1 - \sigma_2 = \underline{9.05 \text{ KSI}} < 1.2 S_m = 32.04 \text{ KSI}$  LOCATION 8

CONSIDER CRITERION 5.6.3:

LOCATION	PRESSURE STRESS			STRESSES DUE TO EXTERNAL LOADS			PRINCIPAL STRESS			STRESS INTENSITY		
	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\sigma_x$	$\sigma_y$	$\tau_{xy}$	$\sigma_1$	$\sigma_2$	$\sigma_3$	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$
9A	7.16	31.02	-2.5	5.24	1.63	1.02	32.67	12.26	-2.5	20.41	35.17	14.76
B	7.16	31.02		5.49	2.70	2.66	34.06	12.32		21.74	36.56	14.82
C	20.47	7.07		5.70	11.48	2.32	26.82	17.90		8.92	29.32	20.40
D	20.47	7.07		7.04	13.84	-0.52	27.55	20.87		6.68	30.05	23.37
10A	7.16	31.02	0	5.06	4.27	0.98	35.34	12.18	0	23.16	35.34	12.18
B	7.16	31.02		7.52	6.98	2.61	38.29	14.39		23.90	38.29	14.39
C	20.47	7.07		8.49	13.56	2.31	29.56	20.04		9.52	29.56	20.04
D	20.47	7.07		9.56	14.51	-0.51	30.06	21.56		8.50	30.06	21.56

$S.I._{MAX} = \sigma_1 - \sigma_3 = \underline{38.3 \text{ KSI}} < 1.2(1.5 S_m) = 48.1 \text{ KSI}$  LOCATION 10B

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-211-P | A164

SHEET 56 OF 69

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORT

CHECK DATE 4-22-68 BY HEILKER

5- DETAILED ANALYSIS:

C. STRESSES

1- COMBINED STRESSES - UNCONCENTRATED:

CONSIDER CRITERION S.I.4:

SAFE END

LOCATION	PRESSURE STRESS			STRESS DUE TO SEISMIC LOADS		PRINCIPAL STRESSES			STRESS INTENSITY		
	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\sigma_x$	$\tau_{xy}$	$\sigma_1$	$\sigma_2$	$\sigma_3$	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$
1	6.30	16.91	-2.5	13.71	2.46	21.37	15.55	-2.5	5.82	23.87	18.05
	↓	↓	-2.5	-13.01	1.00	16.95	-6.75	-2.5	23.70	19.45	-4.25
2			0	16.02	2.60	23.37	15.86	0	7.50	23.37	15.86
	↓	↓	0	-15.32	0.86	16.94	-9.05	0	25.99	16.94	-9.05

$S.I_{MAX} = \sigma_1 - \sigma_2 = \underline{25.99 \text{ KSI}} < 1.2(1.55m) = 30.06 \text{ KSI}$  LOCATION 2

SMALL END OF NOZZLE

LOCATION	PRESSURE STRESS			STRESS DUE TO SEISMIC LOADS		PRINCIPAL STRESSES			STRESS INTENSITY		
	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\sigma_x$	$\tau_{xy}$	$\sigma_1$	$\sigma_2$	$\sigma_3$	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$
3	6.86	16.97	-2.5	14.76	2.67	22.04	15.75	-2.5	7.09	25.34	18.25
	↓	↓	-2.5	-14.00	1.11	17.02	-7.19	-2.5	24.21	19.52	-4.69
4			0	17.07	2.81	24.92	15.98	0	8.94	24.92	15.98
	↓	↓	0	-16.31	0.97	17.01	-9.49	0	26.50	17.01	-9.49

$S.I_{MAX} = \sigma_1 - \sigma_3 = \underline{25.07 \text{ KSI}} < 1.2(1.55m) = 48.06 \text{ KSI}$  LOCATION 3

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A 165  
SHEET 57 OF 69  
DATE 4-22-68 BY COCKRELL  
CHECK DATE 4-22-68 BY HEUKER

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORT

5- DETAILED ANALYSIS:

e- STRESSES:

1. COMBINED STRESSES - UNCONCENTRATED:

CONSIDER THE COMBINED FORCES ON THE PAD:

THE MAXIMUM AND MINIMUM VERTICAL FORCE ON THE INLET NOZZLE PADS WAS FOUND TO BE,

$$\left. \begin{array}{l} \bar{V}_{MAX} = \underline{1172.1 \text{ KIPS}} \\ \bar{V}_{MIN} = \underline{42.1 \text{ KIPS}} \end{array} \right\} \text{NOTE HERE THAT THESE FORCES WERE DETERMINED USING THE DESIGN SEISMIC PIPE LOADS, THERMAL INDUCED PIPE LOADS AND THE SEISMIC SHOCK FACTORS GIVEN IN REF 9 \& 10.}$$

NOTE THAT SINCE THE MINIMUM VALUE OF  $\bar{V}$  IS POSITIVE, THE VESSEL WILL NOT LIFT OFF THE SUPPORT STRUCTURE UNDER THE DESIGN CONDITIONS.

THE MAXIMUM HORIZONTAL FORCE ON THE INLET NOZZLE PADS WAS FOUND TO BE,

$$\bar{H}_{MAX} = \underline{925.5 \text{ KIPS}} \quad \text{SEE NOTE ABOVE FOR } \bar{V}_{MAX} \& \bar{V}_{MIN}.$$

THE ABOVE MAXIMUM FORCES PRODUCE BEARING STRESSES ON THE PAD EQUAL TO,

$$\left. \begin{array}{l} \sigma_{BBB} = \frac{\bar{V}_{MAX}}{A} = \frac{1172.1}{10 \times 22} = 5.3 \text{ KSI} \\ \sigma_{BBB} = \frac{\bar{H}_{MAX}}{A} = \frac{925.5}{25 \times 10} = 37.0 \text{ KSI} \end{array} \right\} < S_y = 44.5 \text{ KSI @ 400}^\circ\text{F}$$

NOTE THAT THE BEARING STRESS ON THE BOTTOM OF THE PAD IS 3.0 KSI WHEN CONSIDERING DEAD WEIGHT AND THERMAL PIPE REACTIONS ONLY. THIS COMPARES WITH A DESIRED BEARING STRESS OF 5.0 KSI. THIS STRESS BELOWS 4.0 KSI WHEN CONSIDERING THREE SUPPORT ONLY.

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A166

SHEET 58 OF 69

DATE 4-22-68 BY COCKRELL

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEILER


5. DETAILED ANALYSIS:

c. STRESSES:

2. PEAK STRESSES:

THE FOLLOWING VALUES OF STRESS CONCENTRATION FACTORS WILL BE USED TO CALCULATE PEAK STRESSES AT LOCATIONS 6, 8 AND 10. THE STRESS CONCENTRATION FACTORS AT ALL OTHER LOCATIONS WILL BE ONE; HENCE, THE EXPRESSIONS FOR PEAK STRESS WILL BE THE SAME AS THOSE GIVEN ON SHEETS 36-47 WITH THE FOLLOWING EXCEPTIONS (1) THE TERM  $\frac{E\alpha}{z^2}(T_m - T)$  IS ADDED TO REFLECT THE STRESS DUE TO THE RADIAL GRADIENT (2) THE  $\frac{GM}{z^2}$  AND  $\frac{VM}{z^2}$  TERMS FOR STRESSES DUE TO THERMAL EFFECTS WILL INCLUDE THE THERMAL MOMENT DUE TO THE RADIAL GRADIENT, AND (3) FOR LOCATION 10, THE PRESSURE STRESS WILL BE CALCULATED USING THE STRESS INDICES GIVEN IN I-612 OF SECTION III.

LOCATION 6:



$D = 26.062''$      $h = 10.75$      $\beta = 58^\circ$      $\Delta = \frac{D}{d} = 5.713$   
 $d = 4.562$      $R = 3.219$      $\frac{R}{d} = 0.699$      $\frac{h}{R} = 3.34$


FROM EQUATIONS 6.20 AND 6.24 OF REF. 13:

$K_{TO} = 1.42$   
 $K_{BO} = 1.22$

FROM EQUATION 6.22 OF REF. 13:

$K_T = 1.27$   
 $K_B = 1.14$

LOCATION 8 & 10



$t = 10.686''$      $r = 5.375$   
 $D = 21.372''$      $\frac{r}{t} = 0.503$

FOR  $\frac{r}{t} = 0.503$

$K_T = \frac{1.80}{}$   
 $K_B = \frac{1.50}{}$  } FROM FIG. A.7-1 REF. 6

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P A167  
SHEET 59 OF 69  
DATE 4-22-69 BY Cochell  
CHECK DATE 4-22-69 BY HEIKER

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

a. STRESSES:

2. PEAK STRESS:

THE FOLLOWING EXPRESSIONS FOR STRESS WILL BE USED TO CALCULATE PEAK STRESSES AT LOCATIONS 6, 8 AND 10.

LOCATION 6:

PRESSURE STRESS:

$$\sigma_x = -\frac{6M_z}{L_{2A}^2} K_B + \frac{b^2 P}{2R_2 L_{2A}} K_T = -1.2126 M_z + 3.3454 P$$

$$\sigma_\theta = -\frac{\sqrt{6}M_z}{L_{2A}^2} K_B + \frac{EW_z}{R_2} + \frac{bP}{t_{2A}} = -0.3638 M_z + 0.0662 EW_z + 5.7895 P$$

$$\sigma_r = 0$$

THERMAL STRESS:

$$\sigma_x = -\frac{6(M_z + M_{2T})}{L_{2A}^2} K_B + \frac{E d_i}{(1-\nu)} (T_m - T) K_T = -1.2126 M_z + 1.8143 E d_i (T_m - T)$$

$$\sigma_\theta = -\frac{\sqrt{6}(M_z + M_{2T})}{L_{2A}^2} K_B + \frac{EW_z}{R_2} + \frac{E d_i}{(1-\nu)} (T_m - T) = -0.3638(M_z + M_{2T}) + 0.0662 EW_z + 1.4286 E d_i (T_m - T)$$

THERMAL INDUCED PIPE REACTIONS:

$$\begin{aligned} \sigma_x = -\frac{\bar{F}_x}{A} K_1 + \frac{\bar{M}_z}{I} K_B &= -0.00561 \bar{F}_x + 0.00071 \bar{M}_z & \text{POINT A} \\ &= -0.00561 \bar{F}_x - 0.00071 \bar{M}_z & \text{B} \\ &= -0.00561 \bar{F}_x + 0.00071 \bar{M}_y & \text{C} \\ &= -0.00561 \bar{F}_x - 0.00071 \bar{M}_y & \text{D} \end{aligned}$$

$$\begin{aligned} T_{10} = \frac{EQ}{IB} K_B \pm \frac{M_z}{ZI} K_B &= 0.01004 \bar{F}_z + 0.00035 \bar{M}_x & \text{POINT A} \\ &= 0.01004 \bar{F}_z - 0.00035 \bar{M}_x & \text{B} \\ &= 0.01004 \bar{F}_y + 0.00035 \bar{M}_x & \text{C} \\ &= 0.01004 \bar{F}_y - 0.00035 \bar{M}_x & \text{D} \end{aligned}$$

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTNUMBER 5-211-P | A168SHEET 60 OF 69DATE 4-22-68 BY COCKRELLCHECK DATE 4-22-68 BY HEILKER5- DETAILED ANALYSIS:e. STRESSES:2. PEAK STRESSES:SEISMIC PIPE REACTIONS:

THE FORMULAS FOR CALCULATING THE STRESSES DUE TO THE SEISMIC PIPE REACTIONS ARE THE SAME AS FOR THE THERMAL INDUCED PIPE REACTIONS.

LOCATION B:PRESSURE STRESS

$$\sigma_x = -\frac{6M_z R_c}{E I_{xx}^2} K_B + \frac{\delta P}{2R_{ext}} K_T = -0.0861 M_z + 1.1155 P$$

$$\sigma_{\theta} = -\frac{\sqrt{6} M_z R_c}{E I_{xx}^2} K_B + \frac{E M_z}{R_{in}} + \frac{\delta P}{E A} = -0.0258 M_z + 0.0456 E M_z + 1.6399 P$$

$$\sigma_T = 0$$

THERMAL STRESS

$$\sigma_x = -\frac{6(M_z + M_{dT}) R_c}{E I_{xx}^2} K_B + \frac{E \Delta T}{(1-\nu)} K_T = -0.0861(M_z + M_{dT}) + 2.5714 E \Delta T$$

$$\sigma_{\theta} = -\frac{\sqrt{6}(M_z + M_{dT}) R_c}{E I_{xx}^2} K_B + \frac{E M_z}{R_{in}} + \frac{E \Delta T}{(1-\nu)} = -0.0258(M_z + M_{dT}) + 0.0456 E M_z + 1.4286 E \Delta T$$

THERMAL INDUCED PIPE REACTIONS:

$$\begin{aligned} \sigma_x &= -\frac{F_x K_T + M_z}{I} K_B = -0.00128 \bar{F}_x + 0.00012 \bar{M}_z \\ &= -0.00128 \bar{F}_x - 0.00012 \bar{M}_z \\ &= -0.00128 \bar{F}_x + 0.00012 \bar{M}_y \\ &= -0.00128 \bar{F}_x - 0.00012 M_y \end{aligned}$$

$$\begin{aligned} T_{10} &= \frac{F_y K_T + M_z}{I} K_B = 0.00207 \bar{F}_z + 0.000057 \bar{M}_x \\ &= 0.00207 \bar{F}_z - 0.000057 \bar{M}_x \\ &= 0.00207 \bar{F}_y + 0.000057 \bar{M}_x \\ &= 0.00207 \bar{F}_y - 0.000057 \bar{M}_x \end{aligned}$$



COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A169  
SHEET 61 OF 69  
DATE 4-22-69 BY COCKRELL  
CHECK DATE 4-22-69 BY HEIKER

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

5- DETAILED ANALYSIS:

e. STRESSES:

2. PEAK STRESSES:

THE EQUATIONS FOR STRESS DUE TO SEISMIC PIPE REACTIONS, STATIC LOADING THROUGH SUPPORTS, EARTHQUAKE LOADING THROUGH SUPPORTS, AND THERMAL EXPANSION & CONTRACTION ARE THE SAME AS FOR THE THERMAL INDUCED PIPE REACTIONS. THE VALUES OF  $\bar{F}_x$ ,  $\bar{F}_y$ ,  $\bar{F}_z$ ,  $\bar{M}_x$ ,  $\bar{M}_y$ , AND  $\bar{M}_z$  ARE THE SAME AS THOSE LISTED ON SHEETS 40-42.

LOCATION 10:

PRESSURE STRESS:

POINTS A+B LONGITUDINAL PLANE	POINTS C&D CIRCUMFERENTIAL PLANE
$\sigma_x = i_x \left( \frac{6P}{t} + \frac{P}{2} \right) = 8.4477P$	$= 17.7402P$
$\sigma_\theta = i_\theta \left( \frac{6P}{t} + \frac{P}{2} \right) = 10.1373P$	$= 21.9641P$
$\sigma_r = 0$	

THERMAL STRESS:

POINTS A&B (LONGITUDINAL PLANE):

$$\sigma_x = -\frac{6}{t^3} (M_A + M_{ST}) K_B - \frac{H_e}{E_s} K_T + \frac{E_c i_x}{(1-\nu)} (T_m - T) K_T = -0.0779 (M_A + M_{ST}) - 0.1674 H_e + 2.5714 E_c i_x (T_m - T)$$

$$\sigma_\theta = -\frac{\nu b}{t^3} (M_A + M_{ST}) K_B + \frac{E_w s_A}{R_s \sin \phi} + \frac{E_c i_x}{(1-\nu)} (T_m - T) = -0.0234 (M_A + M_{ST}) + 0.0462 E_w s_A + 1.4286 (T_m - T)$$

POINTS C&D (CIRCUMFERENTIAL PLANE):

$$\sigma_x = -\frac{\nu b}{t^3} (M_A + M_{ST}) K_B + \frac{E_w s_A}{R_s \sin \phi} + \frac{E_c i_x}{(1-\nu)} (T_m - T) = -0.0234 (M_A + M_{ST}) + 0.0462 E_w s_A + 1.4286 (T_m - T)$$

$$\sigma_\theta = -\frac{6}{t^3} (M_A + M_{ST}) K_B - \frac{H_e \cos \phi}{E_s} K_T + \frac{E_c i_x}{(1-\nu)} (T_m - T) K_T = -0.0779 (M_A + M_{ST}) - 0.1652 H_e + 2.5714 E_c i_x (T_m - T)$$

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A170

SHEET 62 OF 69

CHARGE NO. \_\_\_\_\_

DATE 4-22-69 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-69 BY HEILKER

5- DETAILED ANALYSIS:

C. STRESSES:

2 PEAK STRESSES:

THERMAL INDUCED PIPE REACTIONS:

$$\sigma_x = -\left(\frac{N_x}{F_x/R_m}\right) \frac{F_x}{R_m} K_T \pm \left(\frac{M_x}{F_x}\right) \frac{6F_x}{T^2} K_B \pm \left(\frac{N_x}{A(R^2 m/\beta)}\right) \frac{F_x}{R_m \beta T} K_T \pm \left(\frac{M_x}{A(R^2 m/\beta)}\right) \frac{6F_x}{R_m \beta T^2} K_B$$

$$= -0.00827 \bar{F}_x + 0.00025 \bar{M}_z \quad \text{POINT A}$$

$$= -0.00827 \bar{F}_x - 0.00025 \bar{M}_z \quad \text{B}$$

$$= -0.00827 \bar{F}_x + 0.00022 \bar{M}_y \quad \text{C}$$

$$= -0.00827 \bar{F}_x - 0.00022 \bar{M}_y \quad \text{D}$$

$$\sigma_y = -\left(\frac{N_y}{F_x/R_m}\right) \frac{F_x}{R_m} K_T \pm \left(\frac{M_y}{F_x}\right) \frac{6F_x}{T^2} K_B \pm \left(\frac{N_y}{A(R^2 m/\beta)}\right) \frac{F_x}{R_m \beta T} K_T \pm \left(\frac{M_y}{A(R^2 m/\beta)}\right) \frac{6F_x}{R_m \beta T^2} K_B$$

$$= -0.00962 \bar{F}_x + 0.00022 \bar{M}_z \quad \text{POINT A}$$

$$= -0.00962 \bar{F}_x - 0.00022 \bar{M}_z \quad \text{B}$$

$$= -0.00962 \bar{F}_x + 0.00034 \bar{M}_y \quad \text{C}$$

$$= -0.00962 \bar{F}_x - 0.00034 \bar{M}_y \quad \text{D}$$

$$T_{1/4} = \pm \frac{F_x}{\pi R_m T} K_B + \frac{M_x}{2\pi R_m T} K_B = 0.00165 \bar{F}_z + 0.00003 \bar{M}_x \quad \text{POINT A}$$

$$= -0.00165 \bar{F}_z + 0.00003 \bar{M}_x \quad \text{B}$$

$$= 0.00165 \bar{F}_y + 0.00003 \bar{M}_x \quad \text{C}$$

$$= -0.00165 \bar{F}_y + 0.00003 \bar{M}_x \quad \text{D}$$

THE EQUATIONS FOR STRESS DUE TO SEISMIC PIPE REACTIONS, STATIC LOADING THROUGH SUPPORTS, EARTHQUAKE LOADING THROUGH SUPPORTS, AND THERMAL EXPANSION AND CONTRACTION ARE THE SAME AS FOR THE THERMAL INDUCED PIPE REACTIONS. THE VALUES OF  $F_x$ ,  $F_y$ ,  $F_z$ ,  $M_x$ ,  $M_y$ , AND  $M_z$  ARE THE SAME AS THOSE GIVEN ON SHEETS 44 THRU 47.

**COMBUSTION ENGINEERING, INC.**  
**ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.**

NUMBER S-211-P | A171

SHEET 63 OF 69

DATE 4-22-68 BY COCKRELL

CHARGE NO. \_\_\_\_\_  
 DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEILKER

5. DETAILED ANALYSIS:

e. STRESSES:

2. PEAK STRESSES

THE FOLLOWING VALUES OF  $(T_{INNER} - T_{SURFACE})$  FOR THE INSIDE AND OUTSIDE SURFACES ARE TO BE USED TO CALCULATE PEAK STRESSES FOR THE FATIGUE EVALUATION.

TRANSIENT	CUT-1 BODY-1		CUT-1 BODY-2		CUT-2 BODY-2		CUT-4 BODY-4 & BODY-5		TRANSIENT	FOR ALL BODIES		
	$\Delta T_{INSIDE}$	$\Delta T_{SURFACE}$	$\Delta T_{INSIDE}$	$\Delta T_{SURFACE}$	$\Delta T_{INSIDE}$	$\Delta T_{SURFACE}$	$\Delta T_{INSIDE}$	$\Delta T_{SURFACE}$		$\Delta T_{INSIDE}$	$\Delta T_{SURFACE}$	
A - HEATUP	4.00 hrs	-8	3	-4	3	-6	4	-55	30	STEADY STATE	0	0
	4.25	↓	↓	↓	↓	↓	↓	↓	↓	c 20 MIN	-7.8	
	4.35	↓	↓	↓	↓	↓	↓	↓	↓	d 20 MIN	7.8	
	4.47	↓	↓	↓	↓	↓	↓	↓	↓	e 100 SEC	11.2	
	5.00	0	0	0	0	-1	1	-28	17	225 SEC	1.7	
COOL-DOWN	4.00 hrs	8	-3	4	-3	6	-4	55	-30	f 40 SEC	-9.3	
	4.25	↓	↓	↓	↓	↓	↓	↓	↓	100 SEC	-13.3	
	4.35	↓	↓	↓	↓	↓	↓	↓	↓	260 SEC	-1.3	
	4.47	↓	↓	↓	↓	↓	↓	↓	↓	2 MIN	12	
	5.00	0	0	0	0	1	1	28	-17	g 32 MIN	15	
									10.4 MIN	0		
									h 105 SEC	-9.5		
									65 SEC	8.5		
									i 220 MIN	0	9	
									11.0			
									3 HRS	-8	3	
									5.5	0	0	
									C.D			
									3 HRS	8	-3	
									k ~	6	0	
									~	-6		
									l 12 SEC	33.3		
									10 SEC	-30.2		
									m 28 SEC	-4.2		
									160 SEC	-4.8		
									n 33 SEC	117		
									54 SEC	197	↓	

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-211-P | A172

SHEET 64 OF 69

CHARGE NO. \_\_\_\_\_

DATE 4-22-69 BY COCKBELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-69 BY HEIKER

5. DETAILED ANALYSIS:

e. STRESSES

2. PEAK STRESSES

NOTE HERE THAT PEAK STRESSES WERE CALCULATED AT THE TEN LOCATIONS AS SHOWN ON SHEET 11 FOR THE FOUR ORIENTATIONS A, B, C AND D. THE FOLLOWING TABLE GIVES THE OVERALL USAGE FACTORS FOR EACH LOCATION AND EACH ORIENTATION. STRESSES AND STRESS INTENSITIES PRODUCING THESE USAGE FACTORS WILL NOT BE PRESENTED FOR ALL LOCATIONS AND ORIENTATIONS. ONLY STRESSES AND STRESS INTENSITIES AT THE LOCATION AND ORIENTATION WHICH PRODUCED THE HIGHEST OVERALL USAGE FACTOR WILL BE PRESENTED. THIS WAS LOCATION 10C.

LOCATION AND ORIENTATION	$U_{\text{OVERALL}}$
1 A	0.00015
B	0.00013
C	0.00014
D	0.00014
2 A	0
B	0
C	0
D	0
3 A	0.0011
B	0.0015
C	0.0011
D	0.0013
4 A	0.0018
B	0.00053
C	0.0016
D	0.00096

LOCATION AND ORIENTATION	$U_{\text{OVERALL}}$
5 A	0.00092
B	0.00083
C	0.00089
D	0.00088
6 A	0.0098
B	0.0038
C	0.0098
D	0.0058
7 B	0.0034
B	0.0038
C	0.0037
D	0.0039
8 A	0.0060
B	0.0046
C	0.0059
D	0.0054

LOCATION AND ORIENTATION	$U_{\text{OVERALL}}$
9 A	0.013
B	0.015
C	0.0032
D	0.0030
10 A	0.0061
B	0.0024
C	0.042
D	0.037

**COMBUSTION ENGINEERING, INC.**  
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | AM3  
 SHEET 65 OF 69

CHARGE NO. \_\_\_\_\_

DATE 4-22-69 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-69 BY HEILKER

5. DETAILED ANALYSIS:

a. STRESSES:

2. PEAK STRESSES:

TRANSIENT	PRESSURE STRESS		THERMAL STRESS		THERMAL INWARD P/W REACTION STRESS		SEISMIC P/W REACTION STRESS		SHAFT MOMENT STRESS	
	OX	OY	OX	OY	OX	OY	OX	OY	OX	OY
4.00 MS	33.39	41.34	7.35	15.34	0.95	1.54	6.54	9.81	0	0
4.25	36.86	45.64	7.44	15.69	1.01	1.64	-0.25	-0.25	0	0
4.35	38.25	47.35	7.47	15.74	1.03	1.67	-0.26	-0.26	0	0
4.47	39.92	49.42	7.51	16.10	1.06	1.72	-0.27	-0.27	0	0
5.00	39.92	49.42	4.32	9.44	1.06	1.72	-0.27	-0.27	0	0
4.00	33.39	41.34	7.35	15.34	0.95	1.54	6.54	9.81	0	0
4.25	36.86	45.64	7.44	15.69	1.01	1.64	-0.25	-0.25	0	0
4.35	38.25	47.35	7.47	15.74	1.03	1.67	-0.26	-0.26	0	0
4.47	39.92	49.42	7.51	16.10	1.06	1.72	-0.27	-0.27	0	0
5.00	39.92	49.42	4.32	9.44	1.06	1.72	-0.27	-0.27	0	0
STEADY-STATE			-0.03	0.05			6.54	9.81	-1.01	-1.01
			-0.03	0.05			-6.54	-9.81	1.01	1.01
			-0.03	0.05			0	0	0	0
4.00 MS	5.59	6.92	-6.65	-13.91	0.11	0.18	6.54	9.81	-1.01	-1.01
4.25			-6.59	-13.98	0.05	0.08				
4.35			-6.56	-13.92	0.03	0.05				
4.47			-6.53	-14.14	0	0				
5.00			-3.66	-9.11	0	0				
4.00			-6.65	-13.91	0.11	0.18	-6.54	-9.81	1.01	1.01
4.25			-6.59	-13.98	0.05	0.08				
4.35			-6.56	-13.92	0.03	0.05				
4.47			-6.53	-14.14	0	0				
5.00			-3.66	-9.11	0	0				

LOCATION 10C

a - HEATUP

b - COOLDOWN

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTAHOOGA, TENN.

NUMBER 5. 211-P | AT14

SHEET 06 OF 69

DATE 4-22-68 BY ROBERT BELL

CHECK DATE 4-22-69 BY HEIKER

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION OF INLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:  
E. STRESSES;  
2. PEAK STRESSES;

LOCATION 10C

TRANSIENT		PRESSURE STRESS			THERMAL STRESS		THERMAL INDUCED PIPE REACTION STRESS			SEISMIC PIPE REACTION STRESS			STATIC WEIGHT STRESS		
		$\sigma_x$	$\sigma_y$	$\sigma_r$	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$T_{10}$	$\sigma_x$	$\sigma_y$	$T_{10}$	$\sigma_x$	$\sigma_y$	$T_{10}$
c	20 min	39.92	49.42	0	-0.03	0.05	1.06	1.72	-0.27	0	0	0	0	0	0.93
d	28 min	39.92	49.42												
e	100 sec	37.96	47.00												
	275 sec	40.36	49.97												
f	40 sec	41.16	50.96												
	100 sec	40.09	49.64												
	260 sec	37.96	47.00												
g	2 min	42.04	52.05												
	3.2 min	41.69	51.62												
	10.4 min	38.14	47.22												
h	10 sec	39.38	48.76		↓	↓	↓	↓	↓						
	65 sec	33.88	41.95												
i	220 min N.D.	55.44	68.64		0	0	0	0	0						
j	3.0 HRS	22.18	27.46		-0.02	0.68	0.71	1.15	-0.18						
	5.5	44.35	54.91		-0.02	0.03	0.71	1.15	-0.18						
	20. 3.0 HRS	5.59	6.92		0.07	-0.74	0	0	0						
k	~	41.69	51.62		-0.03	0.05	1.06	1.72	-0.27						
	~	38.14	47.22												
l	12 sec	39.92	49.42												
m	10 sec	48.96	60.62												
	28 sec	37.61	46.56												
	160 sec	25.55	31.63												
n	38 sec	5.32	6.59												
	54 sec	12.42	15.37												

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHANGE NO. \_\_\_\_\_

NUMBER 5-211-P A175  
SHEET 67 OF 69  
DATE 4-22-69 BY BARRELL  
CHECK DATE 4-22-69 BY HICKER

DESCRIPTION STRUCTURAL ANAL FATIGUE EVALUATION OF INLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:  
a. STRESSES:  
2. PEAK STRESSES:

LOCATION 10C

TRANSIENT	EARTHQUAKE LOADING THROUGH SUPPORTS STRESS			EXPANSION AND CONTRACTION STRESS		TOTAL STRESS				PRINCIPAL STRESS			STRESS INTENSITY			
	$\sigma_x$	$\sigma_y$	$\tau_{xy}$	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\tau_{xy}$	$\sigma_1$	$\sigma_2$	$\sigma_3$	$\sigma_1-\sigma_2$	$\sigma_1-\sigma_3$	$\sigma_2-\sigma_3$	
a - HEATING	4.00 HRS	1.36	2.10	-0.48	-1.39	-1.62	47.97	68.73	0	-0.80	68.77	47.94	0	20.83	68.77	47.94
	4.25						51.60	73.49		-0.82	73.52	51.57		21.95	73.52	51.57
	4.35						53.04	75.29		-0.82	75.32	53.00		22.32	75.32	53.00
	4.47						54.77	77.76		-0.83	77.79	54.74		23.05	77.79	54.74
	5.00						51.53	71.11		-0.83	71.14	51.54		19.60	71.14	51.54
	4.00	-1.36	-2.10	0.48			32.16	44.91		2.18	45.28	31.79		13.49	45.28	31.79
	4.25						35.79	49.67		2.16	50.01	35.46		14.55	50.01	35.46
	4.35						37.26	51.51		2.16	51.84	36.94		14.90	51.84	36.94
	4.47						38.96	53.94		2.15	54.24	38.66		15.59	54.24	38.66
	5.00						35.77	47.29		2.15	47.68	35.38		12.31	47.68	35.38
STEADY-STATE		1.36	2.10	-0.48	0	0	48.85	63.10		-0.83	63.15	48.80		14.34	63.15	48.80
		-1.36	-2.10	0.48			33.05	39.28		2.15	39.95	32.38		7.57	39.95	32.38
		0	0	0			40.95	51.19		0.66	51.23	40.91		10.32	51.23	40.91
b - COOLDOWN	4.00 HRS	1.36	2.10	-0.48	1.39	1.62	8.57	6.49		-0.59	6.55	8.52		-1.97	6.55	8.52
	4.25						8.57	6.32		-0.58	6.39	8.49		-2.10	6.39	8.49
	4.35						8.58	6.34		-0.57	6.42	8.50		-2.08	6.42	8.50
	4.47						8.58	6.07		-0.56	6.17	8.48		-2.32	6.17	8.48
	5.00						11.45	12.10		-0.56	11.17	12.38		-1.20	11.17	12.38
	4.00	-1.36	-2.10	0.48			-7.24	-17.33		1.97	-17.48	-7.09		-10.39	-17.48	-7.09
	4.25						-7.24	-17.50		1.99	-17.65	-7.09		-10.56	-17.65	-7.09
	4.35						-7.23	-17.48		1.99	-17.63	-7.08		-10.56	-17.63	-7.08
	4.47						-7.22	-17.75		2.00	-17.89	-7.08		-10.81	-17.89	-7.08
	5.00						-4.36	-11.72		2.00	-12.01	-4.06		-7.95	-12.01	-4.06

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHANGE NO. \_\_\_\_\_

NUMBER S-211-P | 176

SHEET 68 OF 69

DATE 4-22-69 BY DEWRELL

DESCRIPTION: STRUCTURAL AND FATIGUE EVALUATION CHECK DATE 4-22-69 BY HEUSER

DE WELT HAZZLE - LESSER SUPPORTS

5. Detailed Analysis:

1. STRESSES:  
2. PEAK STRESSES:

LOCATION 10C

TRANSIENT	EARTHQUAKE LOADING THROUGH SUPPORTS STRESSES			EXPANDED AND CONTRACTION STRESSES		TOTAL STRESSES				PRINCIPAL STRESSES			STRESS INTENSITY		
	$\sigma_x$	$\sigma_y$	$\tau_{xy}$	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\tau_{xy}$	$\sigma_1$	$\sigma_2$	$\sigma_3$	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$
c 20 min	0	0	0	0	0	40.95	51.19	0	0.66	51.23	40.91	0	10.32	51.23	40.91
d 20 min						40.95	51.19			51.23	40.91		10.32	51.23	40.91
e 100 SEC						39.00	48.77			48.82	38.95		9.86	48.82	38.95
	225 SEC					41.39	51.74			51.78	41.35		10.43	51.78	41.35
f 40 sec						42.19	52.73			52.77	42.15		10.62	52.77	42.15
	100 sec					41.13	51.41			51.45	41.08		10.37	51.45	41.08
g 260 SEC						39.00	48.77			48.82	38.95		9.86	48.82	38.95
	2 min					43.08	53.82			53.86	43.04		10.83	53.86	43.04
h 3.2 min						42.72	53.38			53.43	42.68		10.74	53.43	42.68
	10.4 min					39.18	48.99			49.04	39.13		9.91	49.04	39.13
i 10 sec						40.42	50.53			50.57	40.37		10.20	50.57	40.37
	65 sec					34.92	43.72		0.93	43.77	34.87		8.90	43.77	34.87
j 220 min						55.44	68.64			68.70	55.37		13.33	68.70	55.37
	N.D. 3.0 HRS					22.86	29.28		0.74	29.37	22.78		6.59	29.37	22.78
k S.S. C.D. 3.0 HRS						45.04	56.09		0.74	56.14	44.99		11.15	56.14	44.99
						5.66	6.17		0.93	6.88	4.96		1.92	6.88	4.96
l ~ ~						42.72	53.38		0.66	53.43	42.68		10.74	53.43	42.68
						39.18	48.99			49.04	39.13		9.91	49.04	39.13
m 12 sec						40.95	51.19			51.23	40.91		10.32	51.23	40.91
n 10 sec						50.00	62.39			62.43	49.96		12.46	62.43	49.96
	28 sec					38.64	48.33			48.38	38.60		9.78	48.38	38.60
o 160 SEC						26.58	33.40			33.46	26.52		6.94	33.46	26.52
	33 sec					6.36	9.36			9.56	6.16		2.40	9.56	6.16
p 54 sec						13.45	17.14			17.26	13.34		3.92	17.26	13.34



COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-211-P | A177

SHEET 69 OF 69

CHARGE NO. \_\_\_\_\_


DATE 4-22-68 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF INLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEILKER

5. DETAILED ANALYSIS:

f. FATIGUE EVALUATION:



\* FROM FIG. N-115(A)  
REFERENCE 1

$D_{OVERALL} = 0.042$

Stress	Swain	SALT	Number of Occurrences	N <sup>*</sup>	U
77.79	-17.89	47.84	200	4900	0.0408
68.70	0	34.35	5	14000	0.0004
62.43	8.56	26.94	5	34000	0.0002
62.43	33.46	14.49	75	460000	0.0002
56.14	0	28.07	5	20000	0.0002
53.86	43.77	5.05	200	∞	0

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-D | A178

SHEET 6 OF 80

CHARGE NO. \_\_\_\_\_


DATE 4-22-68 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HELLER

5 - DETAILED ANALYSIS:

a. SYSTEM GEOMETRY:



## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-212-P

A179

SHEET 7 OF 80DATE 4-22-68BY COCKRELL

CHARGE NO. \_\_\_\_\_

CHECK DATE 4-22-68BY HEYLKERDESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS5- DETAILED ANALYSIS:6- SYSTEM ALLOWABLES:

- 1- THE STRESS INTENSITY IN THE REINFORCEMENT PORTION OF THE NOZZLE RESULTING FROM DESIGN PRESSURE AND FROM EXTERNAL LOAD OR MOMENT SHALL NOT EXCEED  $S_m$  AT DESIGN TEMP.
- 2- THE STRESS INTENSITY DERIVED FROM THE AVERAGE PRIMARY PLUS THE LOCAL PRIMARY STRESS SHALL NOT EXCEED  $1.5S_m$  AT DESIGN TEMP.
- 3- THE STRESS INTENSITY AROUND THE NOZZLE TO SHELL JUNCTURE RESULTING FROM INTERNAL PRESSURE, PIPE LOADS, WEIGHT OF VESSEL AND REACTIONS FROM EXTERNAL LOADS SHALL NOT EXCEED  $1.5S_m$  AT DESIGN TEMP.
- 4- THE STRESS INTENSITY IN THE NOZZLE OUTSIDE OF THE REINFORCEMENT PORTION OF THE NOZZLE AND THE SAFE END RESULTING FROM DESIGN PRESSURE AND FROM DESIGN SEISMIC LOAD OR MOMENT SHALL NOT EXCEED  $1.5S_m$  AT DESIGN TEMP.
- 5- THE RANGE OF PRIMARY PLUS SECONDARY STRESS INTENSITY RESULTING FROM MECHANICAL OR THERMAL LOADS SHALL NOT EXCEED  $3S_m$  AT OPERATING PRESSURE AND TEMP.
- 6- SHOW THAT EACH POINT MEETS THE REQUIREMENTS FOR PEAK STRESS INTENSITY GIVEN IN N-414.5 OF THE ASME CODE. THE PROCEDURE WILL BE AS OUTLINED IN N-415.2 OF SECT. III.

NOTE THAT FOR THE CONSIDERATION OF "NO LOSS OF FUNCTION" SEISMIC NOZZLE LOADS, THE ABOVE ALLOWABLES (WHERE APPLICABLE) WILL BE INCREASED BY A FACTOR OF 1.2.

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A180

SHEET 8 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY CORRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEUKER

5- DETAILED ANALYSIS:

C. SYSTEM LOADING:

1. INTERNAL PRESSURE:

THE OUTLET NOZZLE AND THE VESSEL WALL IN THE VICINITY OF THE NOZZLE WILL BE INVESTIGATED FOR THE DESIGN PRESSURE WHERE APPLICABLE AND THE OPERATING PRESSURES DURING THE TRANSIENTS LISTED IN 5.C.2. THE STRESSES RESULTING FROM INTERNAL PRESSURE ARE DETERMINED FROM AN INTERACTION ANALYSIS AND ARE PRESENTED IN 5.C. THE PEAK STRESSES DUE TO INTERNAL PRESSURE AT THE JUNCTURE OF THE NOZZLE TO VESSEL SHELL WILL BE TAKEN AS GIVEN IN I-610 OF THE ASME CODE SECT. III.

2. THERMAL TRANSIENTS:

THE OUTLET NOZZLE AND THE VESSEL WALL WILL BE ANALYZED FOR THE FOLLOWING TRANSIENT CONDITIONS.

<u>TRANSIENT</u>	<u>NUMBER OF OCCURRENCES</u>
a. PLANT HEATUP AT 100°F PER HOUR	200
b. PLANT COOLDOWN AT 100°F PER HOUR	200
c. PLANT LOADING AT 5% OF FULL POWER PER MIN.	14500
d. PLANT UNLOADING AT 5% OF FULL POWER PER MIN.	14500
e. STEP LOAD INCREASE OF 10% OF FULL POWER BUT NOT TO EXCEED FULL POWER	2000
f. STEP LOAD DECREASE OF 10% OF FULL POWER FROM 100% POWER	2000
g. STEP LOAD REDUCTION FROM 100% TO 50% FULL POWER	200
h. REACTOR TRIP FROM FULL POWER	400
i. PLANT HYDROSTATIC TEST OF 3125 PSIA AT ROOM TEMP.	5
j. PLANT HYDROSTATIC TEST OF 2500 PSIA UP TO 400°F.	5
k. STEADYSTATE FLUCTUATIONS OF ±6°F AND ±100 PSI PER MIN.	00
l. LOSS OF FLOW, ONE PUMP	80
m. LOSS OF LOAD	80
n. STEAM BREAK	5


## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTSNUMBER 5-212-P | A181SHEET 9 OF 80DATE 4-22-68 BY COCKRELLCHECK DATE 4-22-68 BY HEILKER5. DETAILED ANALYSIS:C. SYSTEM LOADING:3. THERMAL INDUCED PIPE REACTIONS:

THE FOLLOWING FIGURE SHOWS THE OUTLET NOZZLE WITH THE POSITIVE DIRECTIONS. THE PIPE REACTIONS ARE APPLIED AT THE SMALL END OF THE NOZZLES:



$$\begin{aligned}
 F_x &= 26.2 \text{ KIPS} \\
 F_y &= -230 \text{ KIPS} \\
 F_z &= -10 \text{ KIPS} \\
 M_x &= -2010 \text{ IN-KIPS} \\
 M_y &= -1830 \text{ IN-KIPS} \\
 M_z &= 27084 \text{ IN-KIPS}
 \end{aligned}$$

4. SEISMIC PIPE REACTIONS:

THE FOLLOWING PIPE REACTIONS DUE TO SEISMIC CONDITIONS WILL BE COMBINED WITH THE THERMAL PIPE REACTIONS IN THE WORST POSSIBLE COMBINATION WHEN ANALYZING THE NOZZLE AND SUPPORTS. TO DETERMINE THE MAXIMUM EFFECT OF THE SEISMIC PIPE REACTIONS ON THE NOZZLE TO VESSEL JUNCTURE AND THE SUPPORT PAD, IT IS NECESSARY TO DETERMINE THE WORSE COMBINATION OF FORCES. THIS HAS BEEN DONE AND THE FORCES RESULTING ARE LABELED H AND V. NOTE THAT THE EFFECT OF TWO OF THE INLET AND OUTLET NOZZLE SEISMIC REACTIONS MUST BE TAKEN BY THE INLET AND OUTLET NOZZLES WHICH SUPPORT THE VESSEL. THE FOLLOWING ARE THE PIPE REACTIONS

DESIGN SEISMIC LOADING

$$\begin{aligned}
 F_x &= \pm 122 \text{ KIPS} \\
 F_y &= \pm 90 \text{ KIPS} \\
 F_z &= \pm 71 \text{ KIPS} \\
 M_x &= \pm 1572 \text{ IN-KIPS} \\
 M_y &= \pm 11248 \text{ IN-KIPS} \\
 M_z &= \pm 7282 \text{ IN-KIPS}
 \end{aligned}$$

NO LOSS OF FUNCTION SEISMIC LOADING

$$\begin{aligned}
 F_x &= \pm 122 \text{ KIPS} \\
 F_y &= \pm 162 \text{ KIPS} \\
 F_z &= \pm 124 \text{ KIPS} \\
 M_x &= \pm 2830 \text{ IN-KIPS} \\
 M_y &= \pm 19569 \text{ IN-KIPS} \\
 M_z &= \pm 13200 \text{ IN-KIPS}
 \end{aligned}$$

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-211-P | A182

SHEET 10 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY CUSHKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORT

CHECK DATE 4-22-68 BY HEILKER


5. DETAILED ANALYSIS:

C. SYSTEM LOADING:

4. SEISMIC PIPE REACTIONS:

AS CAN BE SEEN FROM THE TABLE ON SHEET 9, THERE ARE MANY COMBINATIONS OF FORCES. SINCE THE SEISMIC FORCES CAN ALTERNATE, IT WILL BE NECESSARY TO DETERMINE THE COMBINATION OF FORCES WHICH PRODUCE THE MAXIMUM AND MINIMUM STRESSES AT CUT-4. THIS WILL OCCUR WHEN THE VALUES FOR  $\bar{F}_x$ ,  $\bar{F}_y$ ,  $\bar{F}_z$ ,  $\bar{M}_x$ ,  $\bar{M}_y$ , AND  $\bar{M}_z$  AS GIVEN ON SHEETS 47 + 52 ARE SOLVED TO GIVE MAXIMUM AND MINIMUM VALUES. THE METHOD USED TO DETERMINE THIS IS AS FOLLOWS:

- (1) THE LOADS ON THE INDIVIDUAL NOZZLES ARE TRANSFERRED TO THE C.G. OF THE REACTOR VESSEL,
- (2) THE FORCES H AND V ARE DETERMINED IN RELATION TO THE LOADS AT THE  $\bar{c}$  OF THE VESSEL, AND
- (3) TAKING THE COMBINATION OF SEISMIC LOADS GIVEN ON SHEET 9 TO GIVE THE MAXIMUM AND MINIMUM VALUES OF H & V.



## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLES - VESSEL SUPPORTSNUMBER S-212-P| A183SHEET 11 OF 80DATE 4-22-68 BY COCKRELLCHECK DATE 4-22-68 BY HEIKER5- DETAILED ANALYSIS:C. SYSTEM LOADING:4. SEISMIC PIPE REACTIONS:(1) FORCES AT & OF VESSEL:SEE SHEET 11 OF S-211-P(2) FORCES ON SUPPORTS:

$$H = \mp \frac{\bar{F}_x}{2} - \frac{\bar{M}_y}{4(109.406)}$$

$$V = -\frac{\bar{F}_y}{4} \pm \frac{\bar{M}_x}{2(109.406)}$$

NOTE HERE THAT THE TOP SIGN IS FOR OUTLET NOZZLE #2 AND THE BOTTOM SIGN IS FOR OUTLET NOZZLE #4. HOWEVER, WITH SUBSTITUTION OF FORMULAS FOR  $\bar{F}_x$ ,  $\bar{F}_y$ ,  $\bar{M}_x$ , AND  $\bar{M}_y$  AND SOLVING WILL YIELD THE SAME RESULTS.

(3) VALUES OF FORCES ON SUPPORTS:

WITH THE ABOVE EXPRESSIONS FOR  $H$  &  $V$  AND THE EXPRESSIONS FOR  $\bar{F}_x$ ,  $\bar{F}_y$ ,  $\bar{M}_x$ , AND  $\bar{M}_y$  GIVEN ON SHEET-11 OF S-211-P, WE GET THE FOLLOWING.

$$H = -0.5 \left( \frac{F_{x, IN\#1}}{IN\#1} - \frac{F_{x, IN\#3}}{IN\#3} \right) + 0.34733 \left( \frac{F_{x, IN\#2}}{IN\#2} - \frac{F_{x, IN\#4}}{IN\#4} \right) - 0.28956 \left( \frac{F_{z, IN\#1}}{IN\#1} + \frac{F_{z, IN\#3}}{IN\#3} \right) - 0.64923 \frac{F_{z, IN\#2}}{IN\#2}$$

$$+ 0.07011 \frac{F_{z, IN\#4}}{IN\#4} - 0.34733 \left( \frac{F_{y, OUT\#1}}{OUT\#1} - \frac{F_{y, OUT\#3}}{OUT\#3} \right) - 0.63059 \frac{F_{y, OUT\#1}}{OUT\#1} - 0.77092 \frac{F_{y, OUT\#2}}{OUT\#2}$$

$$+ 0.08875 \frac{F_{y, OUT\#3}}{OUT\#3} + 0.22849 \frac{F_{y, OUT\#4}}{OUT\#4} - 0.002285 \left( \frac{M_{y, IN\#1}}{IN\#1} + \frac{M_{y, IN\#2}}{IN\#2} + \frac{M_{y, IN\#3}}{IN\#3} + \frac{M_{y, IN\#4}}{IN\#4} \right)$$

$$- 0.002285 \left( \frac{M_{y, OUT\#1}}{OUT\#1} + \frac{M_{y, OUT\#2}}{OUT\#2} + \frac{M_{y, OUT\#3}}{OUT\#3} + \frac{M_{y, OUT\#4}}{OUT\#4} \right)$$

$$V = -0.25 \left( \frac{F_{y, IN\#1}}{IN\#1} + \frac{F_{y, IN\#3}}{IN\#3} \right) - 0.66659 \frac{F_{y, IN\#2}}{IN\#2} + 0.16659 \frac{F_{y, IN\#4}}{IN\#4} - 0.63977 \frac{F_{y, OUT\#1}}{OUT\#1} - 0.79184 \frac{F_{y, OUT\#2}}{OUT\#2} + 0.13977 \frac{F_{y, OUT\#3}}{OUT\#3}$$

$$+ 0.29184 \frac{F_{y, OUT\#4}}{OUT\#4} + 0.00457 \left( \frac{M_{x, IN\#1}}{IN\#1} - \frac{M_{x, IN\#3}}{IN\#3} \right) - 0.00317 \left( \frac{M_{x, IN\#2}}{IN\#2} - \frac{M_{x, IN\#4}}{IN\#4} \right) + 0.00329 \left( \frac{M_{z, IN\#1}}{IN\#1} - \frac{M_{z, IN\#3}}{IN\#3} \right)$$

$$+ 0.00317 \left( \frac{M_{z, OUT\#1}}{OUT\#1} - \frac{M_{z, OUT\#3}}{OUT\#3} \right) + 0.00329 \left( \frac{M_{z, OUT\#2}}{OUT\#2} - \frac{M_{z, OUT\#4}}{OUT\#4} \right) + 0.00457 \left( \frac{M_{z, OUT\#1}}{OUT\#1} - \frac{M_{z, OUT\#3}}{OUT\#3} \right)$$

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A184

SHEET 12 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY LOCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLES - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEIKER

5- DETAILED ANALYSIS:

C. SYSTEM LOADING:

4. SEISMIC PIPE REACTIONS:

WITH THE ABOVE EQUATIONS AND THE FOLLOWING VALUES FOR THE SEISMIC PIPE REACTIONS, THE VALUES FOR H & V ARE DETERMINED THAT WILL GIVE THE MAXIMUM AND MINIMUM STRESSES AT CUT-4.

FOR DESIGN SEISMIC:

NOZZLE	PIPE REACTION					
	F <sub>x</sub>	F <sub>y</sub>	F <sub>z</sub>	M <sub>x</sub>	M <sub>y</sub>	M <sub>z</sub>
INLET #1	57.9	67	132.9	-982	12972	
2	-57.9	67	132.9	982	12972	-9910
3	-57.9	67	132.9	982	12972	
4	57.9	-67	-132.9	-982	12972	9910
OUTLET #1	122	90	-71	-1572	11248	-7282
2	-122	-90	-71	-1572	-11248	7282
3	-122	-90	71	1572	11248	7282
4		-90	71		11248	7282

H = -538.5 KIPS  
V = -252.8 KIPS  
REVERSING SIGNS  
GIVES,  
H = 538.5 KIPS  
V = 252.8 KIPS

FOR NO LOSS OF FUNCTION SEISMIC:

NOZZLE	PIPE REACTION					
	F <sub>x</sub>	F <sub>y</sub>	F <sub>z</sub>	M <sub>x</sub>	M <sub>y</sub>	M <sub>z</sub>
INLET #1	91.9	81.9	262	-2800	23655	
2	-91.9	81.9	262	2800	23655	-10005
3	-91.9	81.9	262	2800	23655	
4	91.9	-81.9	-262	-2800	23655	10005
OUTLET #1	122	162	-124	-2830	19569	-13200
2	-122	-162	-124	-2830	-19569	13200
3	-122	-162	124	2830	19569	13200
4		-162	124		19569	13200

H = -892.2 K  
V = -407.2 K  
REVERSING SIGNS  
GIVES,  
H = 892.2 K  
V = 407.2 K



**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLES - VESSEL SUPPORTS

NUMBER 5-212-P

A185

SHEET 13 OF 80

DATE 4-22-68

BY LOCKRELL

CHECK DATE 4-22-68

BY HEILKER

5- DETAILED ANALYSIS:


C. SYSTEM LOADINGS:

5- STATIC LOADING THROUGH SUPPORTS:

THE STATIC LOAD PER SUPPORT WAS FOUND TO BE 561.1 KIPS, SEE SHEET 14 OF 5-211-P.

6- EARTHQUAKE LOADING THROUGH SUPPORTS:

DURING AN EARTHQUAKE, THE SUPPORTS MUST RESIST THE VERTICAL AND HORIZONTAL FORCES APPLIED THROUGH THE C.G. OF THE VESSEL DUE TO THE EARTHQUAKE SHOCK FORCES. SINCE THE BOTTOM OF THE VESSEL SUPPORTS IS AT A DIFFERENT ELEVATION THAN THE C.G. OF THE VESSEL, AN OVERTURNING MOMENT DUE TO THE HORIZONTAL SHOCK FORCE RESULTS AND MUST BE RESISTED BY THE SUPPORTS. THE FOLLOWING FIGURE ILLUSTRATES THE METHOD FOR DETERMINING THE FORCES ON THE PADS.



$$V = \pm \frac{V}{4} \pm \frac{H}{2(109.406)}$$

$$H = \pm \frac{H}{2}$$

DIRECTION	EARTHQUAKE FACTORS	
	DESIGN	NO LOSS OF FUNCTION
HORIZONTAL	0.39	0.69
VERTICAL	0.29	0.49

FORCE	DESIGN	NO LOSS OF FUNCTION
H	± 336.7	± 673.4
V	± 132.5	± 265.1

NOTE THAT THE ABOVE SEISMIC SHOCK FACTORS ARE LARGER THAN THOSE LISTED IN REF 10. THE ABOVE FACTORS WILL BE USED WHEN CALCULATING STRESSES; HOWEVER, THE SPECIFIED SEISMIC SHOCK FACTORS GIVEN IN REF 10, WILL BE USED WHEN DETERMINING THE MAX. FORCES ON THE PAD, SEE SHEET 65.

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A186

SHEET 14 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY POWELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEUER

5. DETAILED ANALYSIS:


c. SYSTEM LOADING:

7. DUE TO THERMAL EXPANSION & CONTRACTION

THE FRICTIONAL FORCE DUE TO EXPANSION AND CONTRACTION WAS FOUND TO BE 168.3 KIIPS, SEE SHEET 16 OF S-211-P.

d. PRESSURE AND THERMAL INTERACTION:

1- ANALYTICAL MODEL:



THE ACTUAL STRUCTURE AS SHOWN ON SHEET 6 IS DIVIDED INTO THE ANALYTICAL MODEL AS SHOWN TO FACILITATE THE ANALYSIS. THE ASSUMED DIRECTIONS OF THE REDUNDANT FORCES ARE ILLUSTRATED.

- ① LONG CYLINDER
- ② SHORT CYLINDER
- ③ SHORT TAPERED CYLINDER
- ④ SHORT CYLINDER
- ⑤ LONG SPHERE

**COMBUSTION ENGINEERING, INC.**  
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A187  
 SHEET 15 OF 80  
 DATE 4-22-69 BY COCKRELL  
 CHECK DATE 4-27-69 BY HEILKER


CHARGE NO. \_\_\_\_\_  
 DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

d. PRESSURE & THERMAL INTERACTION:

1- DEFLECTIONS:

BODY-1:



$R_1 = 15.766''$   
 $b_1 = 14.5''$   
 $t_1 = 2.531''$   
 $R_2 = 15.875''$   
 $e = 0.109''$

$$\beta^* = \frac{3(1-\nu^2)}{R_1^2 t_1^3}$$

$$\beta = 0.20349$$

$$D = \frac{E t_1^3}{12(1-\nu^2)} = 1.48475E$$

$$\frac{E_{316}}{E_{304}} = 1$$

DISPLACEMENTS DUE TO REDUNDANT FORCES:

$$E\delta_{11} = -\frac{E}{2\beta^2 D} \left[ \frac{1}{\beta} H_1 - M_1 \right] \frac{R_2}{R_1} \frac{E_{316}}{E_{304}} = -40.2444 H_1 + 8.1892 M_1$$

$$E\delta_{11}^* = -\frac{E}{2\beta^2 D} [H_1 - 2\beta M_1] \frac{R_2}{R_1} \frac{E_{316}}{E_{304}} = -8.1892 H_1 + 3.3328 M_1$$

DISPLACEMENTS DUE TO APPLIED FORCES:

$$E\delta_{11} = \frac{b_1^2}{t_1} \left( \frac{R_1}{b_1} - \frac{\nu}{2} \right) P \frac{E_{316}}{E_{304}} - \frac{E}{2\beta^2 D} (\nu e) \frac{R_2}{R_1} \frac{E_{316}}{E_{304}} = 71.9513P$$

$$E\delta_{11}^* = -\frac{E}{\beta D} (\nu e) \frac{R_2}{R_1} \frac{E_{316}}{E_{304}} = -2.4056P$$

DISPLACEMENTS DUE TO THERMAL EFFECTS:

FOR RANGE OF STRESS	FOR PEAK STRESS
$E\delta_{11T} = R_2 E d_m (T_{11} - 100) \frac{E_{316}}{E_{304}}$ $= 15.875 E d_m (T_{11} - 100)$	$= R_2 E d_m (T_{11} - 100) \frac{E_{316}}{E_{304}} + \frac{E}{2\beta^2 D} \frac{R_2}{R_1} \frac{E_{316}}{E_{304}} M_{1T}$ $= 15.875 E d_m (T_{11} - 100) + 8.1892 M_{1T}$
$E\delta_{11T}^* = R_1 E d_m \left( \frac{\Delta T}{\Delta X} \right) \frac{E_{316}}{E_{304}}$ $= 15.766 E d_m \left( \frac{\Delta T}{\Delta X} \right)$	$= R_1 E d_m \left( \frac{\Delta T}{\Delta X} \right) \frac{E_{316}}{E_{304}} + \frac{E}{\beta D} \frac{R_2}{R_1} \frac{E_{316}}{E_{304}} M_{1T}$ $= 15.766 E d_m \left( \frac{\Delta T}{\Delta X} \right) + 3.3328 M_{1T}$

**COMBUSTION ENGINEERING, INC.**  
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.  
 CHARGE NO. \_\_\_\_\_  
 DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS


NUMBER 5-212-P | A188  
 SHEET 16 OF 80  
 DATE 4-22-68 BY COLLRELL  
 CHECK DATE 4-22-68 BY HEILKER

5. DETAILED ANALYSIS:

1. PRESSURE AND THERMAL INTERACTION:

2. DEFLECTIONS:

BODY-2:



$R_2 = 15.875"$   
 $b_2 = 14.500"$   
 $t_2 = 2.312"$   
 $L_2 = 4.0025"$

$$\beta^4 = \frac{3(1-\nu^2)}{R_2^2 L_2^2}$$

$$\beta = 0.21217$$

$$D = \frac{E t^3}{12(1-\nu^2)} = 1.13172E$$

For  $\beta L = 0.862$

$B_{11} = 2.3326$	$G_{11} = -1.1511$
$B_{12} = 4.1158$	$G_{12} = -3.9924$
$B_{21} = 10.0093$	$G_{21} = -9.1500$

DISPLACEMENTS DUE TO REDUNDANT FORCES:

$$E \Delta_{21} = \frac{E}{2\beta^2 D} \left[ \frac{1}{\beta} B_{11} H_1 + B_{12} M_1 - \frac{1}{\beta} G_{11} H_2 + G_{12} M_2 \right]$$

$$= 107.8952 H_1 + 40.3930 M_1 + 53.2445 H_2 - 39.1819 M_2$$

$$E \Delta_{21}^* = \frac{E}{2\beta^2 D} \left[ -B_{12} H_1 - \beta B_{22} M_1 + G_{12} H_2 - \beta G_{22} M_2 \right]$$

$$= -40.3930 H_1 - 20.8423 M_1 - 39.1819 H_2 + 19.0519 M_2$$

$$E \Delta_{22} = \frac{E}{2\beta^2 D} \left[ \frac{1}{\beta} G_{11} H_1 + G_{12} M_1 - \frac{1}{\beta} B_{11} H_2 + B_{12} M_2 \right]$$

$$= -53.2445 H_1 - 39.1819 M_1 - 107.8952 H_2 + 40.3930 M_2$$

$$E \Delta_{22}^* = \frac{E}{2\beta^2 D} \left[ G_{12} H_1 + \beta G_{22} M_1 - B_{12} H_2 + \beta B_{22} M_2 \right]$$

$$= -39.1819 H_1 - 19.0519 M_1 - 40.3930 H_2 + 20.8423 M_2$$

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER 5-212-D | A189

SHEET 17 OF 80

DATE 4-22-68 BY CORRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEILKER

5- DETAILED ANALYSIS:

d- PRESSURE AND THERMAL INTERACTION:

2- DEFLECTIONS:

DISPLACEMENTS DUE TO APPLIED FORCES

$$E\delta_{21} = E\delta_{22} = \frac{b_2^2}{r_2} \left( \frac{R_2}{b_2} - \frac{v}{2} \right) P = \underline{85.9213P}$$

$$E\delta_{21}^* = E\delta_{22}^* = 0$$

DISPLACEMENTS DUE TO THERMAL EFFECTS:

FOR RANGE OF STRESS	FOR PEAK STRESS
$E\delta_{21T} = R_2 E d_m (T_{21} - 100)$ $= \underline{15.875 E d_m (T_{21} - 100)}$	$= R_2 E d_m (T_{21} - 100) + \frac{E}{2.8^2 D} [B_{12} M_{1T} + G_{12} M_{2T}]$ $= 15.875 E d_m (T_{21} - 100) + 40.3930 M_{1T} - 39.1819 M_{2T}$
$E\delta_{21T}^* = R_2 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{21}$ $= \underline{15.875 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{21}}$	$= R_2 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{21} + \frac{E}{2.8^2 D} [-\beta B_{22} M_{1T} - \beta G_{22} M_{2T}]$ $= 15.875 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{21} - 20.8423 M_{1T} + 19.0519 M_{2T}$
$E\delta_{22T} = R_2 E d_m (T_{22} - 100)$ $= \underline{15.875 E d_m (T_{22} - 100)}$	$= R_2 E d_m (T_{22} - 100) + \frac{E}{2.8^2 D} [G_{12} M_{1T} + B_{12} M_{2T}]$ $= 15.875 E d_m (T_{22} - 100) - 39.1819 M_{1T} + 40.3930 M_{2T}$
$E\delta_{22T}^* = R_2 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{22}$ $= \underline{15.875 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{22}}$	$= R_2 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{22} + \frac{E}{2.8^2 D} [\beta G_{22} M_{1T} + \beta B_{22} M_{2T}]$ $= 15.875 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{22} - 19.0519 M_{1T} + 20.8423 M_{2T}$


## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTSNUMBER 5-212-P

A190

SHEET 18 OF 80DATE 4-22-68 BY COCKRELLCHECK DATE 4-22-68 BY HEILKER5. DETAILED ANALYSIS:d. PRESSURE AND THERMAL INTERACTION:2. DEFLECTIONS:BODY-3:

$$R_2 = 15.875$$

$$t_0 = 2.312$$

$$R_3 = 17.928$$

$$t_L = 10.281$$

$$R_4 = 19.980$$

$$L_3 = 8.219$$

$$a_3 = 14.500$$

$$e_1 = 2.053$$

$$e_2 = 2.052$$

$$\lambda = \frac{1}{L_3}(t_L - t_0)$$

$$\frac{R_4 - R_2}{4.8} = 0.96958$$

THE INFLUENCE COEFFICIENTS FOR A SHORT TAPERED CYLINDER ARE CALCULATED BY THE METHOD OUTLINED ON PAGES 488-492 OF REF. 12 AND ARE PRINTED OUT ON C.E.'S COMPUTER PROGRAM AS FOLLOWS.

DISPLACEMENTS DUE TO REDUNDANT FORCES:

$$E\Delta_{22} = \phi_{11} H_2 \frac{R_2}{R_3} + \phi_{12} M_2 \frac{R_2}{R_3} + \phi_{13} H_3 \frac{R_4}{R_3} + \phi_{14} M_3 \frac{R_4}{R_3}$$

$$= 34.1884 H_2 + 6.1893 M_2 + 15.7480 H_3 + 6.9346 M_3$$

$$E\Delta_{32}^* = \phi_{21} H_2 \frac{R_2}{R_3} + \phi_{22} M_2 \frac{R_2}{R_3} + \phi_{23} H_3 \frac{R_4}{R_3} + \phi_{24} M_3 \frac{R_4}{R_3}$$

$$= -6.1847 H_2 - 1.8617 M_2 - 4.4781 H_3 + 1.3550 M_3$$

$$E\Delta_{33} = \phi_{31} H_2 \frac{R_2}{R_3} + \phi_{32} M_2 \frac{R_2}{R_3} + \phi_{33} H_3 \frac{R_4}{R_3} + \phi_{34} M_3 \frac{R_4}{R_3}$$

$$= -12.5173 H_2 - 3.5624 M_2 - 21.9623 H_3 + 4.6783 M_3$$

$$E\Delta_{23}^* = \phi_{41} H_2 \frac{R_2}{R_3} + \phi_{42} M_2 \frac{R_2}{R_3} + \phi_{43} H_3 \frac{R_4}{R_3} + \phi_{44} M_3 \frac{R_4}{R_3}$$

$$= -5.5112 H_2 - 1.0776 M_2 - 4.6773 H_3 + 1.4794 M_3$$

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTSNUMBER S-212-P

A191

SHEET 19 OF 80DATE 4-22-68 BY COCKRELLCHECK DATE 4-22-68 BY HEILKER5. DETAILED ANALYSIS:1. PRESSURE AND THERMAL INTERACTION:2. DEFLECTIONS:DISPLACEMENTS DUE TO APPLIED FORCES:

$$E\delta_{32} = Pa_3^2 \left( \frac{R_3}{a_3} - \frac{v}{2} \right) \left[ (\phi_{12} + \phi_{14}) \frac{-\lambda^2}{a(1-v^2)} + \frac{1}{L_0} \right] + \phi_{12} V_2 e_1 \frac{R_2}{R_3} - \phi_{14} V_3 e_2 \frac{R_4}{R_3} = \underline{227.6294P}$$

$$E\delta_{32}^* = Pa_3^2 \left( \frac{R_3}{a_3} - \frac{v}{2} \right) \left[ (\phi_{22} + \phi_{24}) \frac{-\lambda^2}{a(1-v^2)} - \frac{\lambda}{L_0} \right] + \phi_{22} V_2 e_1 \frac{R_2}{R_3} - \phi_{24} V_3 e_2 \frac{R_4}{R_3} = \underline{-46.4974P}$$

$$E\delta_{33} = Pa_3^2 \left( \frac{R_3}{a_3} - \frac{v}{2} \right) \left[ (\phi_{32} + \phi_{34}) \frac{-\lambda^2}{a(1-v^2)} + \frac{1}{L_1} \right] + \phi_{32} V_2 e_1 \frac{R_2}{R_3} - \phi_{34} V_3 e_2 \frac{R_4}{R_3} = \underline{-83.5960P}$$

$$E\delta_{33}^* = Pa_3^2 \left( \frac{R_3}{a_3} - \frac{v}{2} \right) \left[ (\phi_{42} + \phi_{44}) \frac{-\lambda^2}{a(1-v^2)} - \frac{\lambda}{L_1} \right] + \phi_{42} V_2 e_1 \frac{R_2}{R_3} - \phi_{44} V_3 e_2 \frac{R_4}{R_3} = \underline{-37.0640P}$$


DISPLACEMENTS DUE TO THERMAL EFFECTS:

<u>FOR RANGE OF STRESS</u>	<u>FOR PEAK STRESS</u>
$E\delta_{32T} = R_2 Ed_m (T_{32} - 100)$ $= 15.875 Ed_m (T_{32} - 100)$	$= R_2 Ed_m (T_{32} - 100) + \phi_{12} M_{2T} \frac{R_2}{R_3} + \phi_{14} M_{3T} \frac{R_4}{R_3}$ $= 15.875 Ed_m (T_{32} - 100) + 6.1893 M_{2T} - 6.9346 M_{3T}$
$E\delta_{32T}^* = R_3 Ed_m \left( \frac{\Delta T}{\Delta X} \right)_{32}$ $= 17.928 Ed_m \left( \frac{\Delta T}{\Delta X} \right)_{32}$	$= R_3 Ed_m \left( \frac{\Delta T}{\Delta X} \right)_{32} + \phi_{22} M_{2T} \frac{R_2}{R_3} + \phi_{24} M_{3T} \frac{R_4}{R_3}$ $= 17.928 Ed_m \left( \frac{\Delta T}{\Delta X} \right)_{32} - 1.8617 M_{2T} + 1.3550 M_{3T}$
$E\delta_{33T} = R_4 Ed_m (T_{33} - 100)$ $= 19.980 Ed_m (T_{33} - 100)$	$= R_4 Ed_m (T_{33} - 100) + \phi_{32} M_{2T} \frac{R_2}{R_3} + \phi_{34} M_{3T} \frac{R_4}{R_3}$ $= 19.980 Ed_m (T_{33} - 100) - 3.5624 M_{2T} + 4.6783 M_{3T}$
$E\delta_{33T}^* = R_3 Ed_m \left( \frac{\Delta T}{\Delta X} \right)_{33}$ $= 17.928 Ed_m \left( \frac{\Delta T}{\Delta X} \right)_{33}$	$= R_3 Ed_m \left( \frac{\Delta T}{\Delta X} \right)_{33} + \phi_{42} M_{2T} \frac{R_2}{R_3} + \phi_{44} M_{3T} \frac{R_4}{R_3}$ $= 17.928 Ed_m \left( \frac{\Delta T}{\Delta X} \right)_{33} - 1.0776 M_{2T} + 1.4794 M_{3T}$

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A192  
SHEET 20 OF 80  
DATE 4-22-68 BY COOPER  
CHECK DATE 4-22-68 BY HEILKER

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

5- DETAILED ANALYSIS:d. PRESSURE AND THERMAL INTERACTION:2. DEFLECTIONS:BODY-4:

$$R_4 = 19.980''$$

$$b_4 = 14.739''$$

$$t_2 = 10.042''$$

$$L_4 = 15.25''$$

$$\beta = \frac{3(1-\nu^2)}{R_4^3 E_2}$$

$$\beta = 0.09075$$

$$D = \frac{E t^3}{12(1-\nu^2)} = 92.7338 E$$

$$\text{FOR } \beta L = 1.384$$

$$B_{11} = 1.4944 \quad G_{11} = -0.6859$$

$$B_{12} = 1.7630 \quad G_{12} = -1.4519$$

$$B_{21} = 3.2777 \quad G_{21} = -1.9212$$

DISPLACEMENTS DUE TO REDUNDANT FORCES:

$$E \Delta_{13}^* = \frac{E}{2\beta^2 D} \left[ \frac{1}{\beta} B_{11} H_3 + B_{12} M_3 - \frac{1}{\beta} G_{11} H_4 + G_{12} M_4 \right]$$

$$= 10.7821 H_3 + 1.1543 M_3 + 4.9488 H_4 - 0.9506 M_4$$

$$E \Delta_{13}^* = \frac{E}{2\beta^2 D} \left[ -B_{12} H_3 - \beta B_{22} M_3 + G_{12} H_4 - \beta G_{22} M_4 \right]$$

$$= -1.1543 H_3 - 0.1948 M_3 - 0.9506 H_4 + 0.1142 M_4$$

$$E \Delta_{23} = \frac{E}{2\beta^2 D} \left[ \frac{1}{\beta} G_{11} H_3 + G_{12} M_3 - \frac{1}{\beta} B_{11} H_4 + B_{12} M_4 \right]$$

$$= -4.9488 H_3 - 0.9506 M_3 - 10.7821 H_4 + 1.1543 M_4$$

$$E \Delta_{24}^* = \frac{E}{2\beta^2 D} \left[ G_{12} H_3 + \beta G_{22} M_3 - B_{12} H_4 + \beta B_{22} M_4 \right]$$

$$= -0.9506 H_3 - 0.1142 M_3 - 1.1543 H_4 + 0.1948 M_4$$



COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-212-P A193

SHEET 21 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEILNER

5- DETAILED ANALYSIS

1. PRESSURE AND THERMAL INTERACTION:

2. DEFLECTIONS:

DISPLACEMENTS DUE TO APPLIED FORCES:

$$E\delta_{43} = E\delta_{44} = \frac{b_4}{L_4} \left( \frac{R_4}{b_4} - \frac{r}{2} \right) P = \underline{26.0803P}$$

$$E\delta_{43}^* = E\delta_{44}^* = 0$$

DISPLACEMENTS DUE TO THERMAL EFFECTS:

<u>FOR RANGE OF STRESS</u>	<u>FOR PEAK STRESS</u>
$E\delta_{43T} = R_4 E d_m (T_{43} - 100)$ $= \underline{19.980 E d_m (T_{43} - 100)}$	$= R_4 E d_m (T_{43} - 100) + \frac{E}{2\beta^2 D} [B_{12} M_{3T} + G_{12} M_{4T}]$ $= \underline{19.980 E d_m (T_{43} - 100) + 1.1543 M_{3T} - 0.9506 M_{4T}}$
$E\delta_{43T}^* = R_4 E d_m \frac{(\Delta T)}{(\Delta X)_{43}}$ $= \underline{19.980 E d_m \frac{(\Delta T)}{(\Delta X)_{43}}}$	$= R_4 E d_m \frac{(\Delta T)}{(\Delta X)_{43}} + \frac{E}{2\beta^2 D} [-\beta B_{22} M_{3T} - \beta G_{22} M_{4T}]$ $= \underline{19.980 E d_m \frac{(\Delta T)}{(\Delta X)_{43}} - 0.1948 M_{3T} + 0.1142 M_{4T}}$
$E\delta_{44T} = R_4 E d_m (T_{44} - 100)$ $= \underline{19.980 E d_m (T_{44} - 100)}$	$= R_4 E d_m (T_{44} - 100) + \frac{E}{2\beta^2 D} [G_{12} M_{3T} + B_{12} M_{4T}]$ $= \underline{19.980 E d_m (T_{44} - 100) - 0.9506 M_{3T} + 1.1543 M_{4T}}$
$E\delta_{44T}^* = R_4 E d_m \frac{(\Delta T)}{(\Delta X)_{44}}$ $= \underline{19.980 E d_m \frac{(\Delta T)}{(\Delta X)_{44}}}$	$= R_4 E d_m \frac{(\Delta T)}{(\Delta X)_{44}} + \frac{E}{2\beta^2 D} [\beta G_{22} M_{3T} + \beta B_{22} M_{4T}]$ $= \underline{19.980 E d_m \frac{(\Delta T)}{(\Delta X)_{44}} - 0.1142 M_{3T} + 0.1948 M_{4T}}$

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-212-P | A194

SHEET 22 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-69 BY COVERELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS


CHECK DATE 4-22-69 BY HEILKER

5. DETAILED ANALYSIS:

1. PRESSURE AND THERMAL INTERACTION:

2. DEFLECTIONS:

BODY-5:



$R_3 = 136.546"$  For  $\phi \sqrt{\frac{R}{t}} = 29.987$   
 $a_3 = 130.952"$   $P_{11} = 0.5387$   
 $t_3 = 10.750"$   $P_{12} = 0.4851$   
 $\phi_5 = 8.4138"$   $P_{22} = 2.7734$

NOTE THAT THE VESSEL SHELL IS IDEALIZED AS A SPHERICAL SEGMENT OF THE SAME THICKNESS AS THE VESSEL AND WITH A MID-RADIUS 1.5 TIMES THAT OF THE VESSEL. THIS YIELDS A MODEL WITH MEMBRANE STRESS EQUAL TO THE AVERAGE OF THAT IN THE LONGITUDINAL AND CIRCUMFERENTIAL DIRECTIONS OF THE VESSEL.

DISPLACEMENTS DUE TO REDUNDANT FORCES:

$$E\Delta_{54} = \frac{180}{\pi t_3 \phi_5} [t_3^2 P_{11} H_4 + t_3 P_{12} M_4] = 3.6684 H_4 + 0.3073 M_4$$

$$E\Delta_{54}^* = -\frac{180}{\pi t_3 \phi_5} [t_3 P_{12} H_4 + P_{22} M_4] = -0.3073 H_4 - 0.1634 M_4$$

DISPLACEMENTS DUE TO APPLIED FORCES:

$$E\delta_{54}^* = \frac{a_3^2}{2} \left[ \frac{180 \cos \phi}{\pi R_3 \phi} P_{11} + \frac{\sin \phi}{t_3} (1-\nu) \right] P = 309.5291 P$$

$$E\delta_{54}^* = -\frac{90 a_3^2 \cos \phi}{\pi R_3 t_3 \phi} P_{12} P = -19.0884 P$$

DISPLACEMENTS DUE TO THERMAL EFFECTS:

FOR RANGE OF STRESS	FOR PEAK STRESS
$E\Delta_{54} = R_3 \sin \phi E_{th} (\Delta T)_{54} = 19.980 E_{th} (\Delta T)_{54}$	$= R_3 \sin \phi E_{th} (\Delta T)_{54} + \frac{180}{\pi t_3 \phi_5} P_{12} M_{5T}$ $= 19.980 E_{th} (\Delta T)_{54} + 0.3073 M_{5T}$
$E\Delta_{54}^* = R_3 \sin \phi E_{th} \left( \frac{\Delta T}{54} \right)_{54} = 19.980 E_{th} \left( \frac{\Delta T}{54} \right)_{54}$	$= R_3 \sin \phi E_{th} \left( \frac{\Delta T}{54} \right)_{54} - \frac{180}{\pi t_3 \phi_5} P_{22} M_{5T}$ $= 19.980 E_{th} \left( \frac{\Delta T}{54} \right)_{54} - 0.1634 M_{5T}$

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION

OF OUTLET NOZZLE - VESSEL SUPPORTS

NUMBER 5-212-P | A195

SHEET 23 OF 80

DATE 4-22-68 BY COCKRELL

CHECK DATE 4-22-68 BY HEILNER

5- DETAILED ANALYSIS:

1- PRESSURE AND THERMAL INTERACTION:

2- DEFLECTIONS:

THE FOLLOWING TABLES GIVE THE MEAN TEMPERATURE, SLOPE OF THE AXIAL GRADIENT, AND THE THERMAL MOMENT DUE TO THE RADIAL GRADIENT FOR EACH CUT. THESE VALUES ARE USED TO CALCULATE THE DEFLECTIONS OF EACH CUT DUE TO THE THERMAL EFFECTS AS PRESENTED ON SHEETS 15-22.

TRANSIENT		$T_{11} \text{ \& } T_{21}$	$T_{22} \text{ \& } T_{32}$	$T_{33} \text{ \& } T_{43}$	$T_{44}$	$T_{64}$	$(\frac{\Delta T}{\Delta X})_{11}$	$(\frac{\Delta T}{\Delta X})_{21} \text{ \& } (\frac{\Delta T}{\Delta X})_{22}$	$(\frac{\Delta T}{\Delta X})_{32} \text{ \& } (\frac{\Delta T}{\Delta X})_{33}$
Heatup	4.00 hrs	492	488	440	433	435	1.000	-0.985	-4.668
	4.25	517	513	465	458	460	↓	↓	↓
	4.35	527	523	475	468	470	↓	↓	↓
	4.47	539	535	487	480	481	↓	↓	↓
	5.00	547	544	521	516	516	0	-0.738	-2.237
No Load Steady State		547	547	547	547	547	0	0	0
Cool down	4.00 hrs	155	159	207	214	212	-1.000	0.985	4.668
	4.25	130	134	182	189	187	↓	↓	↓
	4.35	120	124	172	179	177	↓	↓	↓
	4.47	108	112	160	167	166	↓	↓	↓
	5.00	100	103	126	131	131	0	0.738	2.237
Plant Loadings	10 min	568	568	553	552	548	0.666	0	-1.459
	15	583	582	558	556	549	1.333	-0.246	-2.334
	20	599	597	565	562	550	1.444	-0.492	-3.112
	25	608	605	571	567	552	1.000	-0.738	-3.307
	30	610	608	576	571	555	0.666	-0.492	-3.112
Full Load Steady State		613	613	607	598	574	0	0	-0.584
Plant Unloadings	10 min	592	592	602	593	573	-1.000	0	0.973
	15	577	577	596	589	572	-1.333	0	1.848
	20	561	562	590	583	570	-1.666	0.246	2.723
	25	552	554	584	578	568	-1.333	0.492	2.918
	30	549	552	578	574	566	-0.666	0.738	2.529

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A196  
SHEET 24 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORT

CHECK DATE 4-22-68 BY HEWLER

5. DETAILED ANALYSIS:

1. PRESSURE AND THERMAL INTERACTIONS:

2. DEFLECTIONS:

TRANSIENT	T <sub>11</sub> & T <sub>12</sub>	T <sub>22</sub> & T <sub>23</sub>	T <sub>33</sub> & T <sub>43</sub>	T <sub>44</sub>	T <sub>54</sub>	(ΔT) (ΔX) <sub>11</sub>	(ΔT) (ΔX) <sub>22</sub> & (ΔT) (ΔX) <sub>23</sub>	(ΔT) (ΔX) <sub>33</sub> & (ΔT) (ΔX) <sub>43</sub>	
e → f	584	584	584	584	584	0	0	-0.584	
g	3.5 MIN	620	620	609	575	575	↓	↓	
	11 MIN	604	604	606	575	575			
	15.5 MIN	591	591	602	574	574			
h	10 SEC	612	612	607	574	574	↓	↓	
	90 SEC	593	593	603	573	573			
i	100	100	100	100	100	0	0	0	
j	H.D 3.0 HRS	392	388	340	333	334	1.0	-0.985	-4.668
	S.S.	400	400	400	400	400	0	0	0
	C.O 3.0 HRS	108	112	160	167	166	-1.0	0.985	4.668
k	613	613	613	574	574	0	0	-0.584	
l	12 SEC	613	613	607	573	573	↓	↓	
	18.5 SEC	609	609	606	573	573			
m	12 SEC	616	616	608	574	574	↓	↓	
	26 SEC	618	618	608	575	575			
	144 SEC	595	595	603	575	575			
n	547	547	547	547	547	↓	↓	↓	

**COMBUSTION ENGINEERING, INC.**  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A197  
SHEET 75 OF 80

CHARGE NO. \_\_\_\_\_  
DATE 4-22-69 BY COCKRELL  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS  
CHECK DATE 4-22-68 BY HEILY

5. DETAILED ANALYSIS:

- 1. PRESSURE & THERMAL INTERACTION:
- 2. DEFLECTIONS:

TRANSIENT		$\frac{\Delta T}{\Delta X}_{93}$	$\frac{\Delta T}{\Delta X}_{44}$	$\frac{\Delta T}{\Delta X}_{54}$	M <sub>1T</sub>	M <sub>2T</sub>	M <sub>3T</sub>	M <sub>4T</sub>	M <sub>5T</sub>
Heating	4.00 HRS	-0.933	0.250	1.432	2.296	201.261	259.971	320.808	
	4.25	-0.933	-0.250	1.439	2.307	202.228	262.483	322.358	
	4.35	-0.933	-0.250	1.446	2.318	203.196	263.739	323.908	
	4.47	-0.933	0	1.453	2.328	204.164	264.995	325.458	
	5.00	-0.667	0	0	0.677	98.958	136.549	174.296	
No Load Steady State		0	0	0	0	0	0	0	
Cooling	4.00 HRS	0.933	-0.250	-1.432	-2.296	-201.261	-259.971	-320.808	
	4.25	0.933	-0.250	-1.439	-2.307	-202.228	-262.483	-322.358	
	4.35	0.933	-0.250	-1.446	-2.318	-203.196	-263.739	-323.908	
	4.47	0.933	0	-1.453	-2.328	-204.164	-264.995	-325.458	
	5.00	0.667	0	0	-0.677	-98.958	-136.549	-174.296	
Plant Loading	10 MIN	-0.133	0	2.219	2.199	67.384	78.067	11.625	
	15	-0.267	-0.100	2.511	2.571	107.043	123.200	16.178	
	20	-0.400	-0.400	2.825	2.946	142.450	169.119	22.245	
	25	-0.533	-0.700	1.070	1.655	145.947	180.557	18.706	
	30	-0.667	-1.050	0.646	1.090	134.611	178.923	15.167	
FULL LOAD Steady State		-1.200	-4.500	0	0	23.488	95.758	-108.694	
Plant Unloading	10 MIN	-1.200	-2.750	-2.300	-2.129	-42.350	7.834	-120.431	
	15	-0.933	-2.750	-2.531	-2.601	-82.208	-40.630	-125.024	
	20	-0.933	-2.500	-2.619	-2.739	-118.670	-82.080	-130.637	
	25	-0.800	-2.000	-1.020	-1.460	-120.442	-100.958	-128.000	
	30	-0.533	-1.750	-0.420	-1.040	-111.940	-94.772	-121.397	

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A198

SHEET 26 OF 90

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORT

CHECK DATE 4-22-68 BY HELVICK

5- DETAILED ANALYSIS:

1- PRESSURE AND THERMAL INTERACTION:

2- DEFLECTIONS:

TRANSIENT	$\frac{(\Delta T)_4}{\Delta T_{43}} \frac{(\Delta T)}{\Delta T_{45}}$	$\frac{(\Delta T)}{\Delta T_{54}}$	$M_{1T}$	$M_{2T}$	$M_{3T}$	$M_{4T}$	$M_{5T}$	
e-f	-1.200	-4.500	0	0	23.488	85.758	-108.694	
g	3.5 min							
	11 min							
	15.5 min							
h	10 sec							
	90 sec							
i	0	0	0	0	0	0	0	
j	4.0							
	3.0 HRS	-0.933	0	1.453	2.328	204.164	264.995	325.458
	5.5	0	0	0	0	0	0	0
k	2.0							
	3.0 HRS	0.933	0	-1.453	-2.328	-204.164	-264.995	-325.458
l	-1.200	-4.500	0	0	23.488	85.758	-108.694	
m	12 SEC							
	18.5 SEC							
n	12 SEC							
	26 SEC							
	144 SEC							

WITH THE EXPRESSIONS FOR DISPLACEMENTS AS PRESENTED ON SHEETS 15 THRU 22 AND THE VALUES GIVEN ON SHEETS 23 - 25, THE FOLLOWING VALUES FOR DISPLACEMENT WERE OBTAINED.

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-212-F

A199

SHEET 27 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-69 BY COOPER

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION OF OUTLET NOZZLE - VESSEL SUMMETS

CHECK DATE 4-22-69 BY HEUKER

5. DETAILED ANALYSIS:

1. PRESSURE & THERMAL INTERACTION:

2. DEFLECTIONS:

FOR RANGE OF STRESS

TRANSIENT		$E\sigma_{11T}$	$E\sigma_{11T}^*$	$E\sigma_{21T}$	$E\sigma_{21T}^*$	$E\sigma_{32T}$	$E\sigma_{32T}^*$	$E\sigma_{21T}$	$E\sigma_{32T}^*$
HEATUP	4.00 HRS	1550.1	3.927	1158.4	-2.911	1146.5	-2.911	1146.5	-15.577
	4.25	1648.4	3.926	1232.2	-2.911	1220.4	-2.911	1220.4	-15.578
	4.35	1687.5	3.925	1261.5	-2.910	1249.8	-2.910	1249.8	-15.575
	4.47	1734.2	3.923	1296.4	-2.909	1284.8	-2.909	1284.8	-15.570
	5.00	1765.3	0.0	1319.6	-2.779	1310.9	-2.779	1310.9	-7.459
NO LOAD STEADY STATE		1765.3	0.0	1319.6	0.0	1319.6	0.0	1319.6	0.0
COOL DOWN	4.00 HRS	213.2	-3.850	157.0	2.811	168.5	2.812	168.5	15.052
	4.25	116.0	-3.841	85.3	2.800	96.7	2.802	96.7	14.997
	4.35	77.3	-3.838	56.7	2.795	68.2	2.797	68.2	14.970
	4.47	30.9	-3.838	22.6	2.787	34.0	2.790	34.0	14.932
	5.00	0.0	0.0	0.0	0.0	8.5	0.0	8.5	7.140
PLANT LOADING	10 MIN	1846.4	2.610	1380.3	0.0	1380.3	0.0	1380.3	-4.860
	15	1903.9	5.218	1423.5	-0.725	1420.6	-0.725	1420.6	-7.769
	20	1964.8	5.647	1469.6	-1.449	1463.8	-1.449	1463.8	-10.351
	25	1998.9	3.908	1495.6	-2.173	1486.9	-2.173	1486.9	-10.996
	30	2006.4	2.602	1501.4	-1.448	1495.6	-1.449	1495.6	-10.347
	FULL LOAD STEADY STATE		2017.7	0.0	1510.1	0.0	1510.1	0.0	1510.1
PLANT UNLOADING	10 MIN	1938.2	-3.912	1449.4	0.0	1449.4	0.0	1449.4	3.237
	15	1880.9	-5.220	1406.2	0.725	1406.2	0.725	1406.2	6.152
	20	1819.4	-0.530	1360.1	1.452	1363.0	1.451	1363.0	9.072
	25	1784.7	-5.227	1334.1	2.178	1339.9	2.178	1339.9	9.726
	30	1773.0	-2.612	1325.4	0.0	1334.1	0.0	1334.1	8.426

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-212-P | A200

SHEET 28 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COX/KRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEUSER

5. DETAILED ANALYSIS:

d - PRESSURE & THERMAL INTERACTION:

2 - DEFLECTIONS:

FOR RANGE OF STRESS

TRANSIENT	$E_{01T}$	$E_{01T}^*$	$E_{02T}$	$E_{02T}^*$	$E_{022T}$	$E_{022T}^*$	$E_{032T}$	$E_{032T}^*$	
e → f	1907.7	0	1426.3	0	1426.3	0	1426.3	-1.944	
g	3.5 min	2044.1		1530.6		1530.6	1530.6	-1.941	
	11 min	1983.8		1484.0		1484.0	1484.0	-1.942	
	15.5 min	1934.4		1446.5		1446.5	1446.5	-1.943	
h	10 sec	2014.0		1507.2		1507.2	1507.2	-1.942	
	90 sec	1942.0		1452.3		1452.3	1452.3	-1.943	
i	0	↓	0	↓	0	↓	0	0	
j	N.O.	1152.4	3.919	857.1	-2.891	844.9	-2.890	844.9	-15.466
	3.0 HRS	1184.4	0	881.3	0	881.3	0	881.3	0
	8.0 3.0 HRS	30.9	-3.833	22.6	2.787	34.0	2.790	34.0	14.996
k	2017.7	0	1510.1	0	1510.1	0	1510.1	-1.941	
l	12 sec	2017.7		1510.1		1510.1	1510.1	-1.941	
	18.5 sec	2002.7		1498.5		1498.5	1498.5	-1.942	
m	12 sec	2029.0		1518.9		1518.9	1518.9	-1.941	
	26 sec	2036.5		1524.7		1524.7	1524.7	-1.941	
	144 sec	1949.6		1458.0		1458.0	1458.0	-1.943	
n	1765.3	↓	1319.6	↓	1319.6	↓	1319.6	-1.947	



**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5 212-P A201

SHEET 29 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-27-68 BY COCKBELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-27-68 BY HEILKER

5-DETAILED ANALYSIS:

d. PRESSURE & THERMAL INTERACTION:

2- DEFLECTIONS:

FOR RANGE OF STRESS

TRANSIENT	ED <sub>357</sub>	ED <sub>337</sub> *	ED <sub>37</sub>	ED <sub>37</sub> *	ED <sub>37</sub>	ED <sub>37</sub> *	ED <sub>37</sub>	ED <sub>37</sub> *	
HEATUP	4.00 HRS	1261.7	-15.544	1261.7	-3.462	1235.1	-3.461	1242.7	0.927
	4.25	1356.5	-15.567	1356.5	-3.467	1330.0	-3.466	1337.6	0.929
	4.35	1394.2	-15.572	1394.2	-3.469	1367.8	-3.468	1375.4	0.929
	4.47	1439.2	-15.577	1439.2	-3.470	1413.0	-3.469	1416.7	0
	5.00	1565.5	-7.464	1565.5	-2.480	1547.1	-2.481	1547.1	0
No Load STEADY STATE	1660.9	0	1660.9	0	1660.9	0	1660.9	0	
COOLDOWN	4.00 HRS	386.5	15.131	386.5	3.371	412.1	3.373	404.8	-0.904
	4.25	295.5	15.092	295.5	3.362	320.9	3.364	313.6	-0.901
	4.35	259.1	15.076	259.1	3.358	284.6	3.361	277.3	-0.900
	4.47	215.6	15.054	215.6	3.353	241.0	3.356	237.4	0
	5.00	93.0	7.177	93.0	2.385	110.9	2.387	110.9	0
PLANT LOADING	10 MIN	1682.7	-4.863	1682.7	-0.494	1679.1	-0.494	1664.5	0
	15	1700.9	-7.778	1700.9	-0.992	1693.6	-0.992	1668.2	-0.372
	20	1726.3	-10.367	1726.3	-1.485	1715.4	-1.485	1671.8	-1.486
	25	1748.1	-11.013	1748.1	-1.978	1733.6	-1.979	1679.1	-2.600
	30	1766.2	-10.361	1766.2	-2.475	1748.1	-2.476	1690.0	-3.900
Full Load STEADY STATE	1878.7	-1.942	1878.7	-4.447	1845.9	-4.448	1758.9	-16.699	
PLANT UNLOADING	10 MIN	1860.5	3.236	1860.5	-4.447	1827.8	-4.449	1755.3	-10.205
	15	1838.7	6.147	1838.7	-3.459	1813.3	-3.460	1751.7	-10.206
	20	1816.9	9.060	1816.9	-3.460	1791.5	-3.461	1744.4	-9.279
	25	1795.2	9.711	1795.2	-2.967	1773.4	-2.968	1737.2	-7.424
	30	1773.4	8.416	1773.4	-1.977	1758.9	-1.978	1722.9	-6.497

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A 202

SHEET 30 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEILER

5- DETAILED ANALYSIS:  
1- PRESSURE & THERMAL INTERACTION:  
2- DEFLECTIONS:

FOR RANGE OF STRESS

TRANSIENT	$E_{33T}$	$E_{33T}^*$	$E_{43T}$	$E_{43T}^*$	$E_{54T}$	$E_{54T}^*$	$E_{54T}$	$E_{54T}^*$	
e → f	1795.2	-1.944	1795.2	-4.451	1795.2	-4.451	1795.2	-16.691	
g	3.5 min	1886.0	-1.942	1886.0	-4.446	1762.6	-4.453	1762.6	-16.698
	11 min	1875.1	↓	1875.1	-4.447	1762.6	↓	1762.6	-16.698
	15.5 min	1860.5	↓	1860.5	↓	1758.9	↓	1758.9	-16.699
h	10 sec	1878.7	↓	1878.7	↓	1758.9	↓	1758.9	-16.699
	90 sec	1864.1	↓	1864.1	↓	1755.3	↓	1755.3	-16.700
i	0	0	0	0	0	0	0	0	
j	H.O 3.0 HRS	880.8	-15.372	880.8	-3.424	854.3	-3.421	858.1	0
	S.S. 2.0	1109.2	0	1109.2	0	1109.2	0	1109.2	0
	3.0 HRS	215.6	15.118	215.6	3.353	241.0	3.356	237.4	0
k	1900.6	-1.941	1900.6	-4.446	1758.9	-4.453	1758.9	-16.699	
l	12 sec	1878.7	-1.942	1878.7	-4.447	1755.3	↓	1755.3	-16.700
	185 sec	1875.1	↓	1875.1	↓	1755.3	↓	1755.3	-16.700
m	12 sec	1882.4	↓	1882.4	↓	1758.9	↓	1758.9	-16.699
	26 sec	1882.4	↓	1882.4	↓	1762.6	↓	1762.6	-16.698
	144 sec	1864.1	↓	1864.1	↓	1762.6	↓	1762.6	-16.698
n	1660.9	-1.947	1660.9	-4.459	1660.9	-4.459	1660.9	-16.720	

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

NUMBER S-212-P | A 203

SHEET 31 OF 80

DATE 4-22-69 BY COCKRELL

CHECK DATE 4-22-69 BY HEILKER

5. DETAILED ANALYSIS:

1. PRESSURE AND THERMAL INTERACTIONS:

2. DEFLECTIONS:

FOR PEAK STRESS

TRANSIENT		$E_{01T}$	$E_{01T}^*$	$E_{02T}$	$E_{02T}^*$	$E_{032T}$	$E_{032T}^*$	$E_{032T}$	$E_{032T}^*$
HEATUP	4.00HRS	1561.0	8.700	1126.3	10.986	1183.1	17.661	-235.0	252.957
	4.25	1660.1	8.722	1199.9	11.050	1257.2	17.757	-167.7	254.146
	4.35	1699.3	8.744	1229.0	11.114	1286.7	17.853	-145.0	255.443
	4.47	1746.1	8.766	1263.9	11.160	1321.9	17.929	-116.6	256.738
	5.00	1765.3	0.0	1293.1	10.719	1338.3	11.931	629.6	125.233
NO LOAD STEADYSTATE		1765.3	0.0	1319.6	0.0	1319.6	0.0	1319.6	0.0
COOLDOWN	4.00HRS	201.5	-8.623	189.1	-11.086	131.8	-17.159	1549.3	-253.382
	4.25	104.3	-8.637	117.6	-11.160	59.9	-17.865	1494.9	-254.727
	4.35	65.4	-8.657	99.2	-11.229	31.2	-17.966	1467.9	-256.045
	4.47	19.0	-8.676	55.2	-11.282	-3.1	-18.048	1435.4	-257.376
	5.00	0.0	0.0	26.5	-12.898	-18.9	-14.110	689.3	-125.552
ABOVE LOADING	10 MIN	1864.6	10.005	1393.8	-4.354	1392.2	3.556	926.6	82.352
	15	1924.5	13.587	1424.2	-4.078	1426.0	5.021	694.2	132.488
	20	1987.9	15.062	1469.3	-4.202	1472.1	6.131	494.2	177.184
	25	2007.6	7.474	1474.0	7.057	1511.9	11.936	485.1	183.681
	30	2011.8	4.788	1485.2	5.646	1513.9	9.772	568.9	170.022
FULL LOAD STEADYSTATE		2017.7	0.0	1510.1	0.0	1510.1	0.0	1347.3	29.885
ABOVE UNLOADING	10 MIN	1919.4	-11.578	1439.9	7.376	1453.5	-0.554	1729.9	-50.184
	15	1860.2	-13.656	1405.9	3.923	1400.3	-5.265	1960.2	-100.397
	20	1798.0	-15.259	1361.6	3.854	1355.0	-5.739	2169.0	-146.626
	25	1776.3	-8.626	1350.1	-4.378	1320.9	-8.919	2166.1	-150.755
	30	1769.6	-4.012	1349.2	-11.060	1308.6	-13.674	2103.9	-141.316

COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-212-P | A 204

SHEET 32 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY CONYRELL

DESCRIPTION: STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEILKER

5- DETAILED ANALYSIS:

1- PRESSURE AND THERMAL INTERACTION:

2- DEFLECTIONS:

FOR PEAK STRESS

TRANSIENT	$E_{DIT}$	$E_{DIT}^*$	$E_{DIT}$	$E_{DIT}^*$	$E_{DIT}$	$E_{DIT}^*$	$E_{DIT}$	$E_{DIT}^*$
e → f	1907.7	0.0	1426.3	0.0	1426.3	0.0	1263.5	29.883
g	3.5 min	2044.1	1530.6	1530.6	1530.6		1367.7	29.985
	11 min	1983.8	1484.0	1484.0	1484.0		1321.1	29.984
	15.5 min	1934.4	1446.5	1446.5	1446.5		1283.6	29.983
h	10 sec	2014.0	1507.2	1507.2	1507.2		1344.4	29.985
	90 sec	1942.0	1452.3	1452.3	1452.3		1289.4	29.983
i	0.0	↓	0.0	↓	0.0	↓	0.0	0.0
j	H.O. 3.0 HRS	1164.1	823.3	823.3	883.2	18.520	-556.4	256.842
	S.S. C.D.	1194.4	0.0	991.3	0	891.3	0.0	991.3
	3.0 HRS	19.2	-8.576	56.4	-17.482	-4.3	-24.200	1435.4
k	2017.7	0.0	1510.1	0.0	1510.1	0.0	1347.3	29.895
l	12 sec	2017.7	1510.1	1510.1	1510.1		1347.3	
	18.5 sec	2002.7	1498.5	1498.5	1498.5		1335.6	
m	12 sec	2029.7	1518.9	1518.9	1518.9		1356.0	
	26 sec	2036.5	1524.7	1524.7	1524.7		1361.8	
	144 sec	1949.6	1458.0	1458.0	1458.0		1295.2	29.994
n	1765.3	↓	1319.6	↓	1319.6	↓	1156.7	29.879

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

NUMBER S-112-P

A 205

SHEET 33 OF 80

DATE 4-22-69 BY COCKRELL

CHECK DATE 4-22-69 BY HEILKER

5-DETAILED ANALYSIS:

1. PRESSURE AND THERMAL INTERACTIONS:

2. DEFLECTIONS:

FOR PEAK STRESS

TRANSIENT	EO <sub>33T</sub>	EO <sub>33T</sub> *	EO <sub>43T</sub>	EO <sub>43T</sub> *	EO <sub>44T</sub>	EO <sub>44T</sub> *	EO <sub>54T</sub>	EO <sub>54T</sub> *	
HEATUP	4.00 HRS	2195.1	279.727	1246.9	-12.979	1343.9	24.235	1341.3	-51.493
	4.25	2294.4	281.124	1340.4	-12.886	1440.8	24.608	1436.7	-51.744
	4.35	2336.5	282.541	1378.0	-12.933	1479.1	24.740	1474.9	-51.997
	4.47	2386.1	283.955	1423.0	-12.978	1524.8	24.873	1516.7	-53.180
	5.00	2025.6	138.057	1549.9	-6.144	1610.7	12.830	1600.7	-29.480
	NO LOAD STEADY STATE	1660.9	0.0	1660.9	0.0	1660.9	0.0	1660.9	0.0
COOLDOWN	4.00 HRS	-546.8	-280.140	401.4	12.887	303.4	-24.285	306.2	51.516
	4.25	-642.4	-291.598	311.5	12.780	210.2	-24.673	214.6	51.772
	4.35	-683.2	-283.035	275.3	12.822	173.3	-24.811	177.8	52.026
	4.47	-731.2	-284.478	231.9	12.862	129.2	-24.949	137.4	53.180
	5.00	-367.1	-138.344	108.7	6.048	47.3	-12.923	57.4	29.480
	PLANT LOADING	10 MIN	1990.1	92.455	1686.3	-4.705	1705.1	7.018	1668.1
15		2192.5	147.811	1707.3	-7.774	1734.1	10.783	1673.1	-3.015
20		2392.2	197.199	1730.0	-9.921	1775.2	15.191	1678.6	-5.121
25		2425.0	203.117	1744.9	-9.789	1803.2	16.527	1684.8	-5.657
30		2392.1	187.608	1750.5	-8.150	1827.8	17.201	1694.7	-6.378
FULL LOAD STEADY STATE		1989.6	32.806	1824.3	0.771	1922.6	9.575	1725.5	1.062
PLANT UNLOADING	4.00 HRS	1670.0	-57.123	1804.2	4.697	1877.1	1.913	1718.3	9.473
	4.25	1463.4	-112.669	1782.4	7.916	1844.5	-1.986	1713.3	10.223
	4.35	1271.5	-163.549	1758.0	10.284	1809.6	-5.898	1704.3	12.067
	4.47	1236.9	-166.897	1752.1	8.965	1771.4	-3.880	1697.9	13.491
	5.00	1253.4	-156.067	1734.3	9.005	1756.0	-7.656	1692.6	13.340

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A 206

SHEET 34 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COOPER

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEILKER

5. DETAILED ANALYSIS:

1. PRESSURE AND THERMAL INTERACTION:

2. DEFLECTIONS:

FOR PEAK STRESS

TRANSIENT	ESST	ESST*	ESST	ESST*	ESST	ESST*	ESST	ESST*
e → f	1905.1	32.805	1740.8	0.767	1871.8	9.572	1761.8	1.070
g	3.5 min	1995.9	32.806	1831.6	0.772	1839.2	9.571	1729.2
	11 min	1984.9		1820.7	0.771	1839.2	9.571	1729.2
	16.5 min	1970.4		1806.1		1835.6	9.571	1725.5
h	10 sec	1988.6		1824.3		1835.6	9.570	1725.5
	90 sec	1974.0		1809.7		1832.0	9.570	1721.9
i	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
j	AV. 30 HRS	1827.7	284.159	864.6	-12.933	966.1	24.884	958.1
	SS. CD	1109.2	0.0	1109.2	0.0	1109.2	0.0	1109.2
	3.0 HRS	-731.2	-314.650	231.9	12.862	129.2	-24.949	137.4
k	2010.5	32.806	1846.2	0.772	1835.6	9.570	1725.5	1.062
l	12 sec	1988.6		1824.3	0.771	1832.0		1721.9
	18.5 sec	1984.9		1813.4	0.771	1832.0		1721.9
m	12 sec	1992.2		1828.0	0.772	1835.6		1725.5
	26 sec	1992.2		1828.0	0.772	1839.2	9.571	1729.2
	144 sec	1974.0		1809.7	0.771	1839.2	9.571	1729.2
n	1770.7	32.805	1606.5	0.759	1737.5	9.565	1627.2	1.041

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-12-P | A207

SHEET 35 OF 86

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEWLER

5. DETAILED ANALYSIS:

d. PRESSURE AND THERMAL INTERACTION:

3. CONTINUITY MATRIX AND LOADING VECTORS

Writing The Compatibility Equations In Matrix Form

-148.1396	-32.2032	-53.2445	39.1819	0	0	0	0	0	H <sub>1</sub>
32.2038	24.1750	39.1819	-19.0519	0	0	0	0	0	M <sub>1</sub>
-53.2445	-39.1819	-142.0836	34.2037	-15.7480	6.9346	0	0	0	H <sub>2</sub>
-39.1819	-19.0519	-34.2083	22.7039	4.4781	-1.3550	0	0	0	M <sub>2</sub>
0	0	-12.5773	-3.5624	-32.7443	3.5240	-4.9488	0.9506	0	H <sub>3</sub>
0	0	-5.5112	-1.0776	-3.5230	1.6742	0.9506	-0.1142	0	M <sub>3</sub>
0	0	0	0	-4.9488	-0.9506	-14.4505	0.8470	0	H <sub>4</sub>
0	0	0	0	-0.9506	-0.1142	-0.8470	0.3582	0	M <sub>4</sub>

RANGE OF STRESS

PRESSURE	HEATUP					No Load Steady State	COOLDOWN	
	T=4.00 MS	T=4.25	T=4.35	T=4.47	T=5.00		T=4.00 MS	T=4.25
13.96990	-391.7	-416.2	-426.0	-437.8	-445.7	-445.7	-56.3	-30.8
24.0539	-6.838	-6.836	-6.835	-6.832	-2.179	0	6.661	6.642
141.49742	0	0	0	0	0	0	0	0
46.49742	-12.667	-12.667	-12.665	-12.661	-5.280	0	12.240	12.195
109.67643	0	0	0	0	0	0	0	0
37.06395	12.082	12.099	12.104	12.107	4.984	0	-11.761	-11.730
283.44889	7.6	7.6	7.5	3.8	0	0	-7.3	-7.3
-19.08840	4.388	4.395	4.397	3.469	2.481	0	-4.277	-4.266

RANGE OF STRESS

COOL DOWN			PLANT LOADING					Full Load Steady State
T=4.35	T=4.47	T=5.00	T=10 MIN	T=15	T=20	T=25	T=30	
-20.5	-8.2	0	-466.1	-480.4	-495.2	-503.2	-505.0	-507.6
6.633	6.621	0	-2.610	-5.943	-7.096	-6.081	-4.051	0
0	0	0	0	0	0	0	0	0
12.173	12.142	7.140	-4.860	-7.044	-9.902	-8.923	-9.898	-1.941
0	0	0	0	0	0	0	0	0
-11.717	-11.701	-4.792	4.369	6.786	8.882	9.035	7.886	-2.505
-7.3	-3.6	0	-14.6	-25.3	-43.6	-54.5	-58.1	-87.0
-4.261	-3.356	-2.387	0.499	0.620	-0.001	-0.622	-1.424	-12.251

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-212-P | A 208

SHEET 36 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY ROCKWELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HELMER

5. DETAILED ANALYSIS:

1. PRESSURE AND THERMAL INTERACTIONS:

3. CONTINUITY MATRIX AND LOADING VECTORS:

← RANGE OF STRESS →

PLANT UNLOADING										
T=10min	T=15	T=20	T=25	T=30	e	f	g	T=35min	T=11	T=15.5
-488.8	-474.7	-459.3	-450.6	-447.6	-481.4	-513.5	-499.7	-497.9		
3.912	5.945	7.982	7.405	2.612	0	0	0	0		
0	0	0	0	0	0	0	0	0		
3.237	5.427	7.621	7.548	8.426	-1.944	-1.941	-1.942	-1.943		
0	0	0	0	0	0	0	0	0		
-7.683	-9.606	-12.519	-12.679	-10.393	-2.507	-2.505	-2.505	2.505		
-72.5	-61.6	-47.1	-36.2	-29.0	0	0	0	0		
-5.756	-6.746	-5.818	-4.456	-4.519	-12.240	-12.245	-12.245	-12.246		

← RANGE OF STRESS →

RANGE OF STRESS											
h	T=10sec	T=90	l	T=3 HRS	j	S.S.	T=3.0MS	k	q	T=12500	T=18.5
-506.7	-489.8	0	-295.3	-303.0	-8.2	-507.6	-507.6	-504.1			
0	0	0	-6.811	0	6.620	0	0	0			
0	0	0	0	0	0	0	0	0			
-1.942	-1.943	0	-12.576	0	12.206	-1.941	-1.941	-1.942			
0	0	0	0	0	0	0	0	0			
-2.505	-2.505	0	11.948	0	-11.765	-2.504	-2.505	-2.505			
0	0	0	0	0	0	0	0	0			
-12.246	-12.246	0	3.421	0	-3.356	-12.246	-12.246	-12.246			

← RANGE OF STRESS →      ← PEAK STRESS HEATUP →

RANGE OF STRESS				PEAK STRESS HEATUP					
m	T=12500	T=26	T=144	n	T=4.00MS	T=4.25	T=4.35	T=4.47	T=5.00
-510.1	-511.8	-491.6	-445.7	-435.6	-460.2	-470.3	-482.2	-472.2	
0	0	0	0	2.287	2.328	2.370	2.394	10.719	
0	0	0	0	-14.18.1	-14.24.9	-14.31.7	-14.38.5	-708.7	
-1.941	-1.941	-1.943	-1.947	235.196	236.389	227.589	238.809	113.302	
0	0	0	0	-948.2	-953.9	-958.5	-963.1	-475.8	
-2.505	-2.505	-2.505	-2.512	-292.707	-294.009	-295.474	-296.933	-144.201	
0	0	0	0	-2.6	-4.1	-4.2	-8.0	-10.1	
-12.246	-12.245	-12.245	-12.261	-75.728	-76.353	-76.738	-78.053	-41.310	



COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5 212-P | A209

SHEET 37 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COCKBELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORT

CHECK DATE 4-22-68 BY HEIKER

5- DETAILED ANALYSIS:

4- PRESSURE AND THERMAL INTERACTION:

3- CONTINUITY MATRIX AND LOADING VECTORS:

PEAK STRESS

NO LOAD STEADY STATE	COOLDOWN					PLANT LOADING		
	T=4.0HRS	T=4.25	T=4.35	T=4.47	T=5.00	T=10MIN	T=15	T=20
-445.7	-12.4	13.3	23.7	36.2	26.5	-480.8	-500.3	-519.7
0.0	-2.463	-2.523	-2.573	-2.606	-2.698	-14.359	-17.665	-19.263
	1418.1	1424.9	1431.7	1438.5	708.7	-455.6	-731.9	-977.9
	-235.623	-236.862	-238.079	-239.328	-111.442	78.796	127.467	171.053
	948.2	953.9	958.5	963.1	475.8	-303.8	-485.2	-652.3
	293.027	294.378	295.856	297.340	144.393	-97.160	-155.585	-207.120
	2.9	4.4	4.5	8.2	10.1	-37.1	-61.0	-76.6
	75.802	76.445	76.837	78.129	41.403	-8.918	-13.798	-20.312

PEAK STRESS

PLANT LOADING			FULL LOAD STEADY STATE		PLANT UNLOADING				e	f
T=25	T=30	T=30	T=10MIN	T=15	T=20	T=25	T=30			
-533.6	-526.6	-507.6	-479.5	-454.3	-436.4	-426.2	-420.4	-491.4		
-0.417	0.857	0.0	18.954	17.579	19.113	4.248	-7.049	0.0		
-1026.8	-945.1	-162.9	276.4	559.9	814.0	845.2	795.4	-162.9		
171.745	161.250	29.885	-49.630	-95.132	-140.888	-141.936	-127.642	29.883		
-680.1	-641.5	-164.3	134.2	319.1	486.5	515.2	480.9	-164.3		
-212.907	-195.758	-32.035	61.820	120.584	173.833	175.863	165.073	-32.037		
-118.4	-133.1	-197.1	-158.8	-131.3	-105.3	-73.5	-63.3	-110.1		
-22.184	-23.579	-8.513	7.560	12.209	17.965	22.372	20.996	-8.503		

PEAK STRESS

T=35MIN	g				h	i	j		T=30HRS
	T=11	T=15.5	T=10.5C	T=90			T=3.0HRS	5.5	
-513.5	-499.7	-487.9	-506.7	-499.8	0.0	-340.7	-303.0	37.1	
0.0	0.0	0.0	0.0	0.0		3.141	0.0	-8.906	
-162.9	-162.9	-162.9	-162.9	-162.9		-1439.7		1439.7	
29.885	29.884	29.883	29.885	29.883		238.322		-263.109	
-164.3	-164.3	-164.3	-164.3	-164.3		-963.1		963.1	
-32.035	-32.035	-32.035	-32.035	-32.035		-297.092		327.512	
-110.1	-110.1	-110.1	-110.1	-110.1		-8.0		8.2	
-8.508	-9.508	-9.509	-8.509	-8.509		-78.064		78.129	

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212P | A210

SHEET 30 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY SCARFELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEIKER

5- DETAILED ANALYSIS:

J. PRESSURE AND THERMAL INTERACTION:

3- CONTINUITY MATRIX AND LOADING VECTORS:

PEAK STRESS

K	L		M		N	
	T=12sec	T=18.5	T=12sec	T=26	T=144	
-507.6	-507.6	-504.1	-510.1	-511.8	-491.6	-445.7
0	0	0	0	0	0	0
-162.9	-162.9	-162.9	-162.9	-169.2	-162.9	-162.9
29.885	29.885	29.885	29.885	29.885	29.884	29.879
-164.3	-164.3	-164.3	-164.3	-164.3	-164.3	-164.3
-32.035	-32.035	-32.035	-32.035	-32.035	-32.042	-32.042
-110.1	-110.1	-110.1	-110.1	-110.1	-110.1	-110.1
-8.509	-8.509	-8.509	-8.509	-8.508	-8.508	-8.524

4. REDUNDANT FORCES

THE ABOVE MATRIX WITH THE GIVEN LOADING VECTORS FOR PRESSURE AND THE TRANSIENT CONDITIONS FOR BOTH RANGE OF STRESS AND PEAK STRESS GIVE THE FOLLOWING VALUES FOR THE REDUNDANT FORCES

FOR RANGE OF STRESS

TRANSIENT	H <sub>1</sub>	M <sub>1</sub>	H <sub>2</sub>	M <sub>2</sub>	H <sub>3</sub>	M <sub>3</sub>	H <sub>4</sub>	M <sub>4</sub>	
PRESSURE ONLY	-0.0876P	-1.45312P	1.36218P	0.68414P	1.69431P	39.9392P	-28.9497P	-104.526P	
G. HEATING	4.00 HRS	5.6039	-2.0100	3.2354	13.9348	1.7995	33.3171	-1.9903	22.9379
	4.25	5.9455	-1.9919	3.3521	14.7748	1.7711	34.2241	-2.0207	23.0809
	4.35	6.0826	-1.9843	3.3986	15.1119	1.7591	34.5837	-2.0432	23.1348
	4.47	6.2343	-1.9571	3.4044	15.4146	1.5562	34.0666	-1.8431	20.3141
	5.00	6.2633	-0.5405	2.6465	15.4582	0.4170	23.9627	-0.9296	13.4707
NO LOAD STEADY STATE	6.2065	0.3245	2.0862	15.1932	-0.5580	16.0273	-0.7554	1.3407	
D. COOLDOWN	4.00 HRS	0.16360	2.2667	-1.1040	1.3310	-2.2977	-16.7133	1.1875	-20.5559
	4.25	0.2805	2.2406	-1.2203	0.4591	-2.2596	-17.5845	1.2262	-20.6104
	4.35	0.1382	2.2296	-1.2669	0.1092	-2.2442	-17.9330	1.2417	-20.6310
	4.47	-0.0209	2.2186	-1.2747	-0.2146	-2.0435	-17.4380	1.0506	-17.8663
	5.00	0.0143	0.7376	-0.4249	0.0759	-0.9460	-7.0540	0.1375	-11.0977

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

NUMBER 5-212-P

A-211

SHEET 39 OF 80

DATE 4-22-68 BY COCKRELL

CHECK DATE 4-27-68 BY HEIKER

5. DETAILED ANALYSIS

d. PRESSURE AND THERMAL INTERACTION:

4. REDUNDANT FORCES:

FOR RANGE OF STRESS

TRANSIENT		H <sub>1</sub>	H <sub>1</sub>	H <sub>2</sub>	M <sub>2</sub>	H <sub>2</sub>	M <sub>3</sub>	H <sub>4</sub>	M <sub>4</sub>
c. <u>Flow</u> <u>Loads</u>	10 min	6.4929	-0.5009	2.5287	15.6769	-0.1994	21.0567	0.1563	7.9302
	15	6.7822	-1.1715	2.8107	15.9349	-0.0687	23.6785	0.8849	11.1877
	20	6.8971	-1.4753	2.9610	16.2481	-0.2166	24.6551	2.2040	12.4923
	25	6.9927	-1.2919	2.9131	16.4907	-0.4869	23.6338	3.0728	11.7705
	30	6.9521	-0.9933	2.6891	16.2339	-0.8029	20.9701	3.4227	8.6691
Full Load Stress 57978		6.6404	0.4482	1.0413	13.9346	-4.0488	-3.0711	6.7086	-32.4274
d. <u>Flow</u> <u>Characteristics</u>	10 min	6.3890	1.3950	0.6621	13.7260	-3.5952	-5.3616	5.8021	-13.6008
	15	6.2001	1.8924	0.4456	13.4856	-3.7752	-7.6626	4.9047	-19.6976
	20	5.9656	2.3548	0.1637	12.9895	-3.7545	-10.1310	4.0471	-19.8667
	25	5.8635	2.2243	0.2191	12.7955	-3.3887	-9.7301	3.2773	-16.4659
	30	5.9676	1.6185	0.6659	13.3731	-2.9803	-4.1214	2.3434	-16.2973
e → f		6.4606	0.3163	1.5463	14.5021	-2.4906	5.8903	-2.1070	-43.8878
g	3.5 min	6.9080	0.3400	1.6969	15.5981	-2.5313	7.0469	-2.1625	-43.7784
	11	6.7163	0.3300	1.6324	15.1287	-2.5140	6.5514	-2.1391	-43.8303
	15.5	6.5517	0.3213	1.5770	14.7255	-2.4994	6.1253	-2.1191	-43.8816
h	10 sec	6.8139	0.3351	1.6653	15.3677	-2.5229	6.8033	-2.1511	-43.8036
	90	6.5775	0.3226	1.5857	14.7885	-2.5018	6.1916	-2.1224	-43.8761
i		0	0	0	0	0	0	0	0
j	H.U. 3.0 MPa	4.2455	-2.0491	2.7181	10.5235	1.7090	29.6858	-1.5933	19.4611
	S.S	4.2201	0.2206	1.4185	10.3306	-0.3794	10.8978	-0.5136	1.2516
	C.O 3.0 MPa	-0.0217	2.2049	-1.2809	-0.2207	-2.0517	-17.5242	1.0571	-17.9001
k		6.8259	0.3357	1.6693	15.3971	-2.5239	6.8348	-2.1526	-43.7998
l	12 sec	6.8259	0.3357	1.6693	15.3969	-2.5241	6.8338	-2.1526	-43.8022
	18.5 sec	6.7777	0.3332	1.6531	15.2789	-2.5197	6.7092	-2.1468	-43.8166
m	12 sec	6.8614	0.3376	1.6812	15.4841	-2.5272	6.9261	-2.1569	-43.7894
	26	6.8849	0.3388	1.6891	15.5414	-2.5292	6.9869	-2.1597	-43.7803
	144	6.6031	0.3240	1.5943	14.8513	-2.5039	6.2584	-2.1253	-43.8641
n		5.9628	0.2903	1.3779	13.2811	-2.4492	4.5857	-2.0488	-44.1163

**COMBUSTION ENGINEERING, INC.**  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A 212

SHEET 40 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEILKER

5- DETAILED ANALYSIS:

d. PRESSURE AND THERMAL INTERACTION:

4- REDUNDANT FORCES:

FOR PEAK STRESS

TRANSIENT	H <sub>1</sub>	M <sub>1</sub>	H <sub>2</sub>	M <sub>2</sub>	H <sub>3</sub>	M <sub>3</sub>	H <sub>4</sub>	M <sub>4</sub>	
HEATUP	4.00 HRS	5.5923	-3.3263	3.1279	11.5458	0.8151	-171.355	-4.9870	-275.663
	4.25	5.9345	-3.3170	3.2464	12.3765	0.8022	-171.361	-4.9780	-277.423
	4.35	6.0716	-3.3159	3.2924	12.7021	0.7855	-171.988	-5.0070	-278.811
	4.47	6.2232	-3.2951	3.2976	12.9943	0.5778	-173.487	-4.8213	-283.074
	5.00	6.2564	-0.4691	2.5802	14.7238	-0.1910	-77.001	-2.7858	-146.967
	No Load STEADY STATE	6.2065	0.3245	2.0862	15.1932	-0.5580	16.027	-0.7554	1.841
COOLDOWN	4.00 HRS	0.6469	3.5335	-0.9975	3.7184	-1.3182	187.938	4.1793	277.910
	4.25	0.2913	3.5662	-1.1155	2.9560	-1.2956	187.980	4.1706	279.758
	4.35	0.1490	3.5617	-1.1615	2.5175	-1.2755	188.615	4.2007	281.180
	4.47	-0.0101	3.5371	-1.1689	2.2041	-1.0701	190.095	4.0240	285.387
	5.00	0.0211	0.6662	-0.3636	0.8104	-0.3381	93.910	1.9938	149.340
PLANT LOADING	10 MIN	6.5060	-2.8445	2.6479	13.5972	0.8731	-42.592	3.4223	-28.062
	15	6.7234	-3.8831	3.0027	13.5399	1.6589	-77.347	6.1459	-44.237
	20	6.9261	-4.5757	3.2245	13.5437	2.1543	-109.537	9.4241	-63.615
	25	7.0247	-2.6654	3.2034	15.1018	2.1257	-113.213	11.0291	-66.292
	30	6.9847	-1.9584	2.9846	15.4146	1.8565	-104.378	11.5217	-66.922
FULL LOAD STEADY STATE	6.6783	0.0829	1.3890	14.2503	-0.9113	-15.640	15.2675	4.933	
PLANT UNLOADING	10 MIN	6.4139	3.4538	0.8911	16.0618	-1.5261	44.186	12.1073	59.769
	15	6.2162	4.2645	0.5958	16.2213	-2.4143	79.277	9.0533	74.354
	20	5.9747	4.8921	0.2496	15.8043	-2.9721	111.255	6.4340	92.940
	25	5.8683	3.1930	0.2665	14.2961	-2.9535	113.219	4.6068	101.597
	30	5.9723	1.9880	0.7126	14.4531	-2.5517	109.303	3.6523	95.316

**COMBUSTION ENGINEERING, INC.**  
**ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.**

NUMBER 5-212-P | A 213  
 SHEET 41 OF 80  
 DATE 4-22-68 BY COCKRILL  
 CHECK DATE 4-22-68 BY HEILKER

CHARGE NO. \_\_\_\_\_  
 DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORT

5- DETAILED ANALYSIS:

- d- PRESSURE AND THERMAL INTERACTION:
- 4- REDUNDANT FORCES:

FOR PEAK STRESS

TEMPERATURE	H <sub>1</sub>	M <sub>1</sub>	H <sub>2</sub>	M <sub>2</sub>	H <sub>3</sub>	M <sub>3</sub>	H <sub>4</sub>	M <sub>4</sub>
e → f	6.4986	-0.0489	1.8940	14.8178	0.6469	-6.6784	7.4513	-6.5275
g 3.5 MIN 11 15.5	6.9460	-0.0252	2.0446	15.9139	0.6062	-5.5210	7.3964	-6.4131
	6.7543	-0.0353	1.9801	15.4444	0.6255	-6.0173	7.4198	-6.4700
	6.5897	-0.0440	1.9247	15.0412	0.6381	-6.4434	7.4398	-6.5213
h 10 SEC 90	6.8519	-0.0302	2.0130	15.6834	0.6146	-5.7654	7.4078	-6.4433
	6.6154	-0.0426	1.9334	15.1042	0.6358	-6.3771	7.4365	-6.5158
i	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
j H.V. 3.0 HRS S.S C.D. 3.0 HRS	4.2346	-3.3576	2.6122	8.1047	0.7356	-178.8470	-4.5667	-283.7917
	4.2201	0.2206	1.4185	10.3306	-0.3794	10.8978	-0.5136	1.2516
	0.5206	0.3475	2.0263	5.9557	2.7407	231.9337	0.9093	301.4685
k	6.8638	-0.0295	2.0170	15.7128	0.6136	-5.7348	7.4062	-6.4419
Q 12 SEC 18.5 SEC	6.8638	-0.0295	2.0170	15.7127	0.6135	-5.7348	7.4062	-6.4419
	6.8042	-0.0817	1.9981	15.5069	0.9902	-5.0031	7.2845	-5.4967
m 12 SEC 26 144	6.8994	-0.0277	2.0289	15.7998	0.6103	-5.6426	7.4020	-6.4291
	6.9228	-0.0264	2.0368	15.8571	0.6083	-5.5817	7.3992	-6.4200
	6.6410	-0.0443	1.9420	15.1670	0.6336	-6.3103	7.4336	-6.5038
n	6.0008	-0.0750	1.7256	13.5968	0.6883	-7.9830	7.5101	-6.7560

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A214  
SHEET 42 OF 80  
DATE 4-22-68 BY COCKRELL  
CHECK DATE 4-22-68 BY HELLER

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

C-STRESSES:

1. COMBINED STRESSES - UNCONCENTRATED:

FOR THIS SECTION OF THE ANALYSIS, STRESSES WILL BE CALCULATED AT THE TEN LOCATIONS AS SHOWN ON SHEET 14.


LOCATION 1 & 2:

PRESSURE STRESS:

$$\sigma_x = \pm \frac{6M_1 R_2}{t^2 R_1} + \frac{b^2 P}{2R_1 t} = \pm 0.9431 M_1 + 2.6345 P$$

$$\sigma_\theta = \pm \frac{\sqrt{6} M_1 R_2}{t^2 R_1} + \frac{EW_1}{R_1} + \frac{bP}{t} = \pm 0.2829 M_1 + 0.0634 EW_1 + 5.7290 P$$

$$\sigma_r = -P$$



$$I = \frac{\pi}{4} (r_o^4 - r_i^4) = 31358 \text{ in}^4$$

$$A = \pi (r_o^2 - r_i^2) = 251 \text{ in}^2$$

THERMAL STRESS:

$$\sigma_x = \pm \frac{6M_1 R_2}{t^2 R_1} = \pm 0.9431 M_1$$

$$\sigma_\theta = \pm \frac{\sqrt{6} M_1 R_2}{t^2 R_1} + \frac{EW_1}{R_1} = \pm 0.2829 M_1 + 0.0634 EW_1$$

THERMAL INDUCED PIPE REACTIONS:

	LOCATION-1	LOCATION-2
$\sigma_x = -\frac{F_x}{A} \pm \frac{Mc}{I}$	$= -0.00398 F_x + 0.00046 M_z$ POINT A	$= -0.00398 F_x + 0.00054 M_z$ POINT A
	$= -0.00398 F_x - 0.00046 M_z$ B	$= -0.00398 F_x - 0.00054 M_z$ B
	$= -0.00398 F_x + 0.00046 M_y$ C	$= -0.00398 F_x + 0.00054 M_y$ C
	$= -0.00398 F_x - 0.00046 M_y$ D	$= -0.00398 F_x - 0.00054 M_y$ D
$T_{x0} = \frac{Fy}{Ib'} + \frac{Mc}{I}$	$= 0.00794 F_z + 0.00023 M_x$ POINT A	$= 0.00794 F_z + 0.00027 M_x$ POINT A
	$= 0.00794 F_z - 0.00023 M_x$ B	$= 0.00794 F_z - 0.00027 M_x$ B
$b' = 2t$	$= 0.00794 F_y + 0.00023 M_x$ C	$= 0.00794 F_y + 0.00027 M_x$ C
	$= 0.00794 F_y - 0.00023 M_x$ D	$= 0.00794 F_y - 0.00027 M_x$ D

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A215  
SHEET 43 OF 80  
DATE 4-22-68 BY COCKRELL  
CHECK DATE 4-22-68 BY HEILER

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

a. STRESSES:

1. COMBINED STRESSES - UNCONCENTRATED:

SEISMIC PIPE REACTIONS:

THE FORMULAS FOR CALCULATING THE STRESSES DUE TO THE SEISMIC PIPE REACTIONS ARE THE SAME AS FOR THE THERMALLY INDUCED PIPE REACTIONS.

NOTE:

THERE WILL BE NO STRESS PRODUCED AT LOCATIONS 1 → 6 DUE TO THE STATIC LOADING THROUGH SUPPORTS, EARTHQUAKE LOADING THROUGH SUPPORTS, OR DUE TO THERMAL EXPANSION OR CONTRACTION.


LOCATION 344:

PRESSURE STRESS:

$$\sigma_x = \pm \frac{6M_1}{t_1^2} + \frac{b^2 P}{2R_2 t_2} = \pm 1.1225 M_1 + 2.8642 P$$

$$\sigma_\theta = \pm \frac{\sqrt{6} M_1}{t_1^2} + \frac{E W_{21}}{R_2} + \frac{6P}{t_2} = \pm 0.3367 M_1 + 0.0630 E W_{21} + 6.2716 P$$

$$\sigma_r = -P$$



$$I = \frac{\pi}{4} (r_o^4 - r_i^4) = 29215 \text{ IN}^4$$

$$A = \pi (r_o^2 - r_i^2) = 231 \text{ IN}^2$$

THERMAL STRESS:

$$\sigma_x = \pm \frac{6M_1}{t_1^2} = \pm 1.1225 M_1$$

$$\sigma_\theta = \pm \frac{\sqrt{6} M_1}{t_1^2} + \frac{E W_{21}}{R_2} = \pm 0.3367 M_1 + 0.0630 E W_{21}$$

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S 212-P | A 216

SHEET 44 OF 80

DATE 4-27-68 BY JOCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-27-68 BY HEWNER

5- DETAILED ANALYSIS:

C. STRESSES:

1- COMBINED STRESSES - UNCONCENTRATED:

THERMAL INDUCED PIPE REACTIONS:

	LOCATION-3		LOCATION-4
$\sigma_x = -\frac{F_x}{A} \pm \frac{M_x}{I}$	$= -0.00434 F_x + 0.00050 M_x$ POINT A		$= -0.00434 F_x + 0.00058 M_x$ POINT A
	$= -0.00434 F_x - 0.00050 M_x$ B		$= -0.00434 F_x - 0.00058 M_x$ B
	$= -0.00434 F_x + 0.00050 M_y$ C		$= -0.00434 F_x + 0.00058 M_y$ C
	$= -0.00434 F_x - 0.00050 M_y$ D		$= -0.00434 F_x - 0.00058 M_y$ D
$T_{ho} = \frac{F_y}{I_b} \pm \frac{M_y}{I}$	$= 0.00864 F_y + 0.00025 M_x$ POINT A		$= 0.00864 F_y + 0.00029 M_x$ POINT A
	$= 0.00864 F_y - 0.00025 M_x$ B		$= 0.00864 F_y - 0.00029 M_x$ B
	$= 0.00864 F_y + 0.00025 M_x$ C		$= 0.00864 F_y + 0.00029 M_x$ C
	$= 0.00864 F_y - 0.00025 M_x$ D		$= 0.00864 F_y - 0.00029 M_x$ D

SEISMIC PIPE REACTIONS:

THE FORMULAS FOR CALCULATING THE STRESSES ARE THE SAME AS FOR THE THERMAL INDUCED PIPE REACTIONS.

LOCATION 5-6:

PRESSURE STRESS:

$$\sigma_x = \pm \frac{6M_x}{L_{2A}^2} + \frac{6P}{K_2 L_{2A}} = \pm 0.7582 M_x + 2.3541 P$$


$$\sigma_y = \pm \frac{\sqrt{6}M_y}{L_{2A}^2} + \frac{EW_{22}}{K_2} + \frac{6P}{L_{2A}} = \pm 0.2275 M_y + 0.0630 EW_{22} + 2.1546 P$$

$$\sigma_r = -P$$

THERMAL STRESS:

$$\sigma_x = \pm \frac{6M_x}{L_{2A}^2} = \pm 0.7582 M_x$$

$$\sigma_y = \pm \frac{\sqrt{6}M_y}{L_{2A}^2} + \frac{EW_{22}}{K_2} = \pm 0.2275 M_y + 0.0630 E W_{22}$$



$$I = \frac{\pi}{4}(r_o^4 - r_i^4) = 37338 \text{ in}^4$$

$$A = \pi(r_o^2 - r_i^2) = 285 \text{ in}^2$$



**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

NUMBER S 212-P A 217

SHEET 45 OF 80

DATE 4-22-68 BY COCKRELL

CHECK DATE 4-22-68 BY HEIKER

5- DETAILED ANALYSIS:

e. STRESSES:

1. COMBINED STRESSES - UNDOCENTRATED:

THERMAL INDUCED PIPE REACTIONS:

SINCE THE PIPE REACTIONS ARE APPLIED AT THE SMALL END OF THE NOZZLE, THE PIPE REACTIONS MUST BE RESOLVED TO THE CROSS SECTION OF INTEREST. THIS IS DONE AS FOLLOWS.

$$\begin{aligned} \bar{F}_x = F_x &= 26.2 & \bar{M}_x &= M_x & & = -2010 \\ \bar{F}_y = F_y &= -230 & \bar{M}_y &= M_y + 4.0625 F_z & = & -1870.6 \\ \bar{F}_z = F_z &= -10 & \bar{M}_z &= M_z - 4.0625 F_y & = & 28018.4 \end{aligned}$$

	LOCATION-5	LOCATION-6
$\sigma_x = -\frac{\bar{F}_x}{A} \pm \frac{\bar{M}_x}{I}$	$= -0.00351 \bar{F}_x + 0.00039 \bar{M}_z$ POINT A	$= -0.00351 \bar{F}_x + 0.00047 \bar{M}_z$ POINT A
	$= -0.00351 \bar{F}_x - 0.00039 \bar{M}_z$ B	$= -0.00351 \bar{F}_x - 0.00047 \bar{M}_z$ B
	$= -0.00351 \bar{F}_y + 0.00039 \bar{M}_y$ C	$= -0.00351 \bar{F}_y + 0.00047 \bar{M}_y$ C
	$= -0.00351 \bar{F}_y - 0.00039 \bar{M}_y$ D	$= -0.00351 \bar{F}_y - 0.00047 \bar{M}_y$ D
$\tau_{xy} = \frac{F_y}{I b'} \pm \frac{M_y}{Z I}$	$= 0.00698 \bar{F}_z + 0.00020 \bar{M}_x$ POINT A	$= 0.00698 \bar{F}_z + 0.00024 \bar{M}_x$ POINT A
	$= 0.00698 \bar{F}_z - 0.00020 \bar{M}_x$ B	$= 0.00698 \bar{F}_z - 0.00024 \bar{M}_x$ B
$b' = 2t_{20}$	$= 0.00698 \bar{F}_y + 0.00020 \bar{M}_x$ C	$= 0.00698 \bar{F}_y + 0.00024 \bar{M}_x$ C
	$= 0.00698 \bar{F}_y - 0.00020 \bar{M}_x$ D	$= 0.00698 \bar{F}_y - 0.00024 \bar{M}_x$ D

SEISMIC PIPE REACTIONS:

THE FORMULAS FOR CALCULATING THE STRESSES DUE TO THE SEISMIC PIPE REACTIONS ARE THE SAME AS FOR THE THERMAL INDUCED PIPE REACTIONS.

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-312-P | A 21B  
SHEET 110 OF 80  
DATE 4-22-68 BY COCKRELL  
CHECK DATE 4-22-68 BY HELMER

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

E - STRESSES:

1. COMBINED STRESSES - UNCONCENTRATED:


LOCATION 7 & 8:

PRESSURE STRESS:

$$\sigma_x = \pm \frac{6M_x R_o}{t_{in}^2 R_{in}} + \frac{b^2 P}{2R_o t_{in}} = \pm 0.0637 M_x + 0.6044 P$$

$$\sigma_\theta = \pm \frac{\sqrt{6} M_x R_o}{t_{in} R_{in}} + \frac{E W_{xx}}{R_{in}} + \frac{b P}{t_{in}} = \pm 0.0191 M_x + 0.0493 E W_{xx} + 1.5961 P$$

$$\sigma_r = -P$$



$$I = \frac{\pi}{4} (r_o^4 - r_i^4) = 260413 \text{ IN}^4$$

$$A = \pi (r_o^2 - r_i^2) = 12001 \text{ IN}^2$$

THERMAL STRESS:

$$\sigma_x = \pm \frac{6M_x R_o}{t_{in}^2 R_{in}} = \pm 0.0637 M_x$$

$$\sigma_\theta = \pm \frac{6M_x R_o}{t_{in}^2 R_{in}} + \frac{E W_{xx}}{R_{in}} = \pm 0.0191 M_x + 0.0493 E W_{xx}$$

THERMAL INDUCED PIPE REACTIONS:

SINCE THE PIPE REACTIONS ARE APPLIED AT THE SMALL END OF THE NOZZLE, THE PIPE REACTIONS MUST BE RESOLVED TO THE CROSS SECTION OF INTEREST. THIS IS DONE AS FOLLOWS.

$$\bar{F}_x = F_x = 26.2 \quad \bar{M}_x = M_x = -2010$$

$$\bar{F}_y = F_y = -230 \quad \bar{M}_y = M_y + 22.156 F_z = -2051.6$$

$$\bar{F}_z = F_z = -10 \quad \bar{M}_z = M_z - 22.156 F_y = 32179.9$$

LOCATION - 7		LOCATION - 8	
$\sigma_x = -\frac{\bar{F}_x}{A} \pm \frac{\bar{M}_x}{I}$	$= -0.00082 \bar{F}_x + 0.00006 \bar{M}_z$	POINT A	$= -0.00082 \bar{F}_x + 0.00010 \bar{M}_z$ POINT A
	$= -0.00082 \bar{F}_x - 0.00006 \bar{M}_z$	B	$= -0.00082 \bar{F}_x - 0.00010 \bar{M}_z$ B
	$= -0.00082 \bar{F}_x + 0.00006 \bar{M}_y$	C	$= -0.00082 \bar{F}_x + 0.00010 \bar{M}_y$ C
	$= -0.00082 \bar{F}_x - 0.00006 \bar{M}_y$	D	$= -0.00082 \bar{F}_x - 0.00010 \bar{M}_y$ D

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-D A219  
SHEET 47 OF 80  
DATE 4-22-68 BY COCKBELL  
CHECK DATE 4-22-68 BY HEUKER

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

e. STRESSES:

1. COMBINED STRESSES - UNCONCENTRATED:

	LOCATION - 7	LOCATION - 8
$T_{30} = \frac{FQ}{I_B} + \frac{M_C}{Z_I}$	$= 0.00156 \bar{F}_z + 0.00003 \bar{M}_x$ POINT A	$= 0.00156 \bar{F}_z + 0.000048 \bar{M}_x$ POINT A
	$= 0.00156 \bar{F}_z - 0.00003 \bar{M}_x$ B	$= 0.00156 \bar{F}_z - 0.000048 \bar{M}_x$ B
	$= 0.00156 \bar{F}_y + 0.00003 \bar{M}_x$ C	$= 0.00156 \bar{F}_y + 0.000048 \bar{M}_x$ C
	$= 0.00156 \bar{F}_y - 0.00003 \bar{M}_x$ D	$= 0.00156 \bar{F}_y - 0.000048 \bar{M}_x$ D

SEISMIC PIPE REACTIONS:

IN SETTING UP EQUATIONS TO ACCOUNT FOR SEISMIC PIPE REACTIONS, THE FORCES EXERTED ON THE NOZZLE WHICH ARE APPLIED THRU THE SUPPORT PAD MUST BE RESOLVED TO THE CROSS SECTION OF INTEREST. THESE FORCES ARE LABELED H AND V AS SHOWN ON SHEET 9. THE VALUES FOR THE DESIGN EARTHQUAKE AND THE NO LOSS OF FUNCTION CONDITION WHICH WILL BE CONSIDERED ARE PRESENTED IN THE TABLE ON SHEET 12. THE EQUATIONS FOR STRESS WILL BE THE SAME FOR THE SEISMIC CONDITIONS AS FOR THE THERMAL INDUCED PIPE REACTIONS EXCEPT THE VALUES FOR  $\bar{F}_x$ ,  $\bar{F}_y$ ,  $\bar{F}_z$ ,  $\bar{M}_x$ ,  $\bar{M}_y$ , AND  $\bar{M}_z$  WILL BE AS FOLLOWS.

$$\begin{aligned} \bar{F}_x &= F_x = -122 & \bar{M}_x &= M_x - 25H & &= 11890.5 \\ \bar{F}_y &= F_y + V = -342.8 & \bar{M}_y &= M_y + 22.156 F_z + 13.0H & &= -19051.6 \\ \bar{F}_z &= F_z + H = -609.5 & \bar{M}_z &= M_z - 22.156 F_y - 13.0V & &= 12562.4 \end{aligned}$$

STATIC LOADING THROUGH SUPPORTS:

THE EQUATIONS FOR STRESS ARE THE SAME AS FOR THE THERMALLY INDUCED PIPE REACTIONS WITH THE FOLLOWING VALUES FOR  $\bar{F}_y$  AND  $\bar{M}_z$ .

$$\begin{aligned} \bar{F}_y &= V = 561.1 & \text{SEE SHEET 13 FOR VALUES OF V WITH OR WITHOUT} \\ \bar{M}_z &= -13V = & \text{THE DYNAMIC LOAD OF TRIPPED CONTROL RODS.} \\ & & = -7294.3 \end{aligned}$$

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-212-P | A220

SHEET 48 OF 80

DATE 4-22-68 BY COCKPELL

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEILKER

5- DETAILED ANALYSIS:

e. STRESSES:

1- COMBINED STRESSES - UNCONCENTRATED:

EARTHQUAKE LOADING THRU SUPPORTS:

THE EQUATIONS FOR STRESS DUE TO THE EARTHQUAKE LOADING THROUGH THE SUPPORTS WILL BE THE SAME AS FOR THE THERMAL INDUCED PIPE REACTIONS WITH THE FOLLOWING VALUES FOR  $F_y$ ,  $F_z$ ,  $M_x$ ,  $M_y$  AND  $M_z$ .

$$\left. \begin{aligned} F_y &= V = -132.5 & M_x &= -25H = 8412.5 \\ F_z &= H = -336.5 & M_y &= 13H = -4374.5 \\ & & M_z &= -13V = 1722.5 \end{aligned} \right\} \text{SEE SHEET 13 FOR VALUES OF H AND V.}$$

THERMAL EXPANSION AND CONTRACTION:

THE EQUATIONS FOR STRESS DUE TO EXPANSION AND CONTRACTION ARE AS FOLLOWS WITH THE VALUES FOR  $F_x$  AND  $M_z$  EQUAL TO.

$$\left. \begin{aligned} F_x &= F = 168.3 \\ M_z &= 26F \\ &= 4375.8 \end{aligned} \right\} \text{SEE SHEET 14 FOR VALUES OF F.}$$

	LOCATION-7		LOCATION-8
$\sigma_x = -\frac{F_x}{A} \pm \frac{M_z}{I}$	$= -0.00082 F_x + 0.00006 M_z$	POINT A	$= -0.00082 F_x + 0.00010 M_z$ POINT A
	$= -0.00082 F_x - 0.00006 M_z$	B	$= -0.00082 F_x - 0.00010 M_z$ B
	$= -0.00082 F_x$	C	$= -0.00082 F_x$ C
	$= -0.00082 F_x$	D	$= -0.00082 F_x$ D

	LOCATION-7	LOCATION-8	
$\sigma_x$	$= 0.00074 F$	$0.00178 F$	POINT A
	$= -0.00238 F$	$-0.00342 F$	B
	$= -0.00082 F$	$-0.00082 F$	C
	$= -0.00082 F$	$-0.00082 F$	D

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A 221

SHEET 49 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEIKER

5. DETAILED ANALYSIS:

e. STRESSES:

1- COMBINED STRESSES - UNCONCENTRATED:

LOCATION 9#10:

PRESSURE STRESS:


NOTE HERE THAT IT WILL BE NECESSARY TO CALCULATE STRESSES IN BOTH THE LONGITUDINAL AND CIRCUMFERENTIAL DIRECTIONS FOR PRESSURE

POINTS A & B (LONGITUDINAL PLANE):

$$\sigma_x = \pm \frac{6M_x}{t_s^2} - \frac{H_x}{t_s} + \frac{V_x \sin \phi}{t_s} = \pm 0.05192 M_x - 0.09302 H_x + 0.0740 P$$

$$\sigma_\theta = \pm \frac{r_0 M_x}{t_s^2} + \frac{E W_{\theta x}}{R_s \sin \phi} + \frac{b_v P}{t_s} = \pm 0.01558 M_x + 0.0501 E W_{\theta x} + 7.9477 P$$

$$\sigma_r = -P$$



POINTS C & D (CIRCUMFERENTIAL PLANE):

$$\sigma_x = \pm \frac{r_0 M_x}{t_s^2} + \frac{E W_{\theta x}}{R_s \sin \phi} + \frac{b_v P}{2R_s t_s} = \pm 0.01558 M_x + 0.0501 E W_{\theta x} + 3.7297 P$$

$$\sigma_\theta = \pm \frac{6M_x}{t_s^2} - \frac{H_x \cos \phi}{t_s} + \frac{V_x \sin \phi}{t_s} = \pm 0.05192 M_x - 0.09202 H_x + 0.0740 P$$

$$\sigma_r = -P$$

THERMAL STRESS

POINTS A & B (LONGITUDINAL PLANE):

$$\sigma_x = \pm \frac{6M_x}{t_s^2} - \frac{H_x}{t_s} = \pm 0.05192 M_x - 0.09302 H_x$$

$$\sigma_\theta = \pm \frac{r_0 M_x}{t_s^2} + \frac{E W_{\theta x}}{R_s \sin \phi} = \pm 0.01558 M_x + 0.0501 E W_{\theta x}$$

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A222  
SHEET 50 OF 80  
DATE 4-22-69 BY COCKRELL  
CHECK DATE 7-22-69 BY HECKER

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

C - STRESSES:

1. COMBINED STRESSES - UNCONCENTRATED:

POINTS C & D (CIRCUMFERENTIAL PLANE):


$$\sigma_x = \pm \frac{2W_2M_x}{t^3} + \frac{EW_2a}{R_0 \sin \phi} = \pm 0.01558 M_x + 0.0501 EW_2a$$

$$\sigma_\theta = \pm \frac{WM_x}{t^3} - \frac{H_2 \cos \phi}{t^3} = \pm 0.05192 M_x - 0.09202 H_2$$

THERMAL INDUCED PIPE REACTIONS:

THE STRESSES IN THE VESSEL WALL DUE TO THE THERMALLY INDUCED PIPE REACTIONS WILL BE CALCULATED BY THE METHOD OUTLINED IN REF. 21 FOR A CYLINDRICAL ATTACHMENT TO A CYLINDRICAL SHELL. SINCE THE PIPE REACTIONS ARE APPLIED AT THE SMALL END OF THE NOZZLE, THEY MUST BE RESOLVED TO THE MID-RADIUS OF THE VESSEL. THIS IS DONE BY THE FOLLOWING RELATIONSHIP OF FORCES.

$$\begin{aligned} \bar{F}_x = F_x &= 26.2 & \bar{M}_x = M_x &= -2010 \\ \bar{F}_y = F_y &= -230 & \bar{M}_y = M_y + 27.531 F_z &= -2105.3 \\ \bar{F}_z = F_z &= -10 & \bar{M}_z = M_z - 27.531 F_y &= 33416.1 \end{aligned}$$



WITH THE GEOMETRIC PARAMETERS OF  $\gamma = \frac{R_0}{T} = 0.5$  AND  $\beta = 0.975 \frac{L_0}{R_m} = 0.24$  AND THE CURVES IN REF. 2 WE GET THE FOLLOWING EXPRESSIONS FOR STRESS.

**COMBUSTION ENGINEERING, INC.**  
**ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.**

NUMBER 212-P | A223  
 SHEET 51 OF 80  
 DATE 4-22-63 BY COCKRELL  
 CHECK DATE 4-27-63 BY HEIKER

CHARGE NO. \_\_\_\_\_  
 DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

5- DETAILED ANALYSIS:

e. STRESSES:

1- COMBINED STRESSES - UNCONCENTRATED:

$$\sigma_x = -\left(\frac{M_x}{F_x R_{m, \beta}}\right) \frac{F_x}{r} \pm \left(\frac{M_x}{M_y R_{m, \beta}}\right) \frac{M_y}{R_{m, \beta} T} \pm \left(\frac{M_x}{M_z R_{m, \beta}}\right) \frac{M_z}{R_{m, \beta} T} \pm \left(\frac{M_x}{M_y R_{m, \beta}}\right) \frac{M_y}{R_{m, \beta} T} \pm \left(\frac{M_x}{M_z R_{m, \beta}}\right) \frac{M_z}{R_{m, \beta} T} \pm \left(\frac{M_x}{M_y R_{m, \beta}}\right) \frac{M_y}{R_{m, \beta} T} \pm \left(\frac{M_x}{M_z R_{m, \beta}}\right) \frac{M_z}{R_{m, \beta} T}$$

$$= -(142/978.58) \pm (0.075) \frac{M_y}{115.50} \pm (0.056) \frac{M_z}{21390} \pm (0.20) \frac{M_y}{21390} \pm (0.070) \frac{M_z}{25248}$$

LOCATION - 9	LOCATION - 10
Point A $-0.00145 \bar{F}_x + 0.00339 \bar{F}_y + 0.00013 \bar{M}_z - 0.00017 \bar{M}_2$	Point A $-0.00145 \bar{F}_x - 0.00339 \bar{F}_y + 0.00013 \bar{M}_z + 0.00017 \bar{M}_2$
Point B $-0.00145 \bar{F}_x + 0.00339 \bar{F}_y - 0.00013 \bar{M}_z + 0.00017 \bar{M}_2$	Point B $-0.00145 \bar{F}_x - 0.00339 \bar{F}_y - 0.00013 \bar{M}_z - 0.00017 \bar{M}_2$
Point C $-0.00145 \bar{F}_x + 0.00339 \bar{F}_y + 0.00022 \bar{M}_y - 0.00013 \bar{M}_y$	Point C $-0.00145 \bar{F}_x - 0.00339 \bar{F}_y + 0.00022 \bar{M}_y + 0.00013 \bar{M}_y$
Point D $-0.00145 \bar{F}_x + 0.00339 \bar{F}_y - 0.00022 \bar{M}_y + 0.00013 \bar{M}_y$	Point D $-0.00145 \bar{F}_x - 0.00339 \bar{F}_y - 0.00022 \bar{M}_y - 0.00013 \bar{M}_y$

$$\sigma_y = -\left(\frac{M_y}{F_y R_{m, \beta}}\right) \frac{F_y}{r} \pm \left(\frac{M_y}{M_x R_{m, \beta}}\right) \frac{M_x}{R_{m, \beta} T} \pm \left(\frac{M_y}{M_z R_{m, \beta}}\right) \frac{M_z}{R_{m, \beta} T} \pm \left(\frac{M_y}{M_x R_{m, \beta}}\right) \frac{M_x}{R_{m, \beta} T} \pm \left(\frac{M_y}{M_z R_{m, \beta}}\right) \frac{M_z}{R_{m, \beta} T}$$

$$= -(115/978.58) \pm (0.11) \frac{M_x}{115.50} \pm (0.26) \frac{M_z}{21390} \pm (0.097) \frac{M_x}{25248} \pm (1.00) \frac{M_z}{21390} \pm (0.044) \frac{M_x}{25248}$$

LOCATION - 9	LOCATION - 10
Point A $-0.00118 \bar{F}_x + 0.00571 \bar{F}_y + 0.00047 \bar{M}_z - 0.00010 \bar{M}_2$	Point A $-0.00118 \bar{F}_x - 0.00571 \bar{F}_y + 0.00047 \bar{M}_z + 0.00010 \bar{M}_2$
Point B $-0.00118 \bar{F}_x + 0.00571 \bar{F}_y - 0.00047 \bar{M}_z + 0.00010 \bar{M}_2$	Point B $-0.00118 \bar{F}_x - 0.00571 \bar{F}_y - 0.00047 \bar{M}_z - 0.00010 \bar{M}_2$
Point C $-0.00118 \bar{F}_x + 0.00571 \bar{F}_y + 0.00012 \bar{M}_y - 0.00023 \bar{M}_y$	Point C $-0.00118 \bar{F}_x - 0.00571 \bar{F}_y + 0.00012 \bar{M}_y + 0.00023 \bar{M}_y$
Point D $-0.00118 \bar{F}_x + 0.00571 \bar{F}_y - 0.00012 \bar{M}_y + 0.00023 \bar{M}_y$	Point D $-0.00118 \bar{F}_x - 0.00571 \bar{F}_y - 0.00012 \bar{M}_y - 0.00023 \bar{M}_y$

$$\tau_{xy} = \pm \frac{F_y}{T R_{m, \beta}} \pm \frac{F_x}{T R_{m, \beta}} + \frac{M_x}{T R_{m, \beta}} = 0.00010 \bar{F}_y + 0.00002 \bar{M}_x$$

$$= -0.00110 \bar{F}_y + 0.00002 \bar{M}_x$$

$$= 0.00110 \bar{F}_y + 0.00002 \bar{M}_x$$

$$= -0.00110 \bar{F}_y + 0.00002 \bar{M}_x$$

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTSNUMBER 5-212-P

AZZA

SHEET 52 OF 80DATE 4-22-69 BY COCKRELLCHECK DATE 4-22-69 BY HEILNER5. DETAILED ANALYSIS:C. STRESSES:1. COMBINED STRESSES - UNCONCENTRATED:SEISMIC PIPE REACTIONS:

THE EQUATIONS FOR STRESS FOR THE SEISMIC PIPE REACTIONS WILL BE THE SAME AS FOR THE THERMALLY INDUCED PIPE REACTIONS. THE VALUES FOR  $\bar{F}_x$ ,  $\bar{F}_y$ ,  $\bar{F}_z$ ,  $\bar{M}_x$ ,  $\bar{M}_y$ , AND  $\bar{M}_z$  WILL BE AS FOLLOWS. SEE SHEET 12 FOR VALUES OF H AND V.

$$\begin{aligned} \bar{F}_x = F_x &= -122 & \bar{M}_x = M_x - 25H &= 11890.5 \\ \bar{F}_y = F_y + V &= -342.8 & \bar{M}_y = M_y + 27.531F_z + 13.375H &= -23127.6 \\ \bar{F}_z = F_z + H &= -609.5 & \bar{M}_z = M_z - 27.531F_y - 18.375V &= 14405.0 \end{aligned}$$

STATIC LOAD THROUGH SUPPORTS:

THE EQUATIONS FOR STRESS ARE THE SAME AS FOR THE THERMALLY INDUCED PIPE REACTIONS WITH THE FOLLOWING VALUES FOR  $\bar{F}_y$  AND  $\bar{F}_z$ .

$$\begin{aligned} \bar{F}_y = V & \quad \text{SEE SHEET 13 FOR VALUES OF V WITH OR WITHOUT} \\ \bar{F}_z = -18.375V & \quad \text{THE DYNAMIC LOAD OF TRIPPED CONTROL RODS.} \end{aligned}$$

EARTHQUAKE LOADING THROUGH SUPPORTS:

THE EQUATIONS FOR STRESS ARE THE SAME AS FOR THE THERMALLY INDUCED PIPE REACTIONS WITH THE FOLLOWING VALUES FOR  $\bar{F}_y$ ,  $\bar{F}_z$ ,  $\bar{M}_x$ ,  $\bar{M}_y$ , AND  $\bar{M}_z$

$$\begin{aligned} \bar{F}_y = V &= -132.5 & \bar{M}_x &= -25H &= 8412.5 \\ \bar{F}_z = H &= -336.5 & \bar{M}_y &= 18.375H &= -6193.2 \\ & & \bar{M}_z &= -18.375V &= 2434.7 \end{aligned}$$



COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A225  
SHEET 53 OF 80  
DATE 4-22-68 BY COOPER  
CHECK DATE 4-22-68 BY HEILKER

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORT

5- DETAILED ANALYSIS:

e- STRESSES:

1- COMBINED STRESSES - UNCONCENTRATED:

THERMAL EXPANSION AND CONTRACTION:

THE EQUATIONS FOR STRESS ARE THE SAME AS FOR THE THERMALLY INDUCED PIPE REACTIONS WITH THE FOLLOWING VALUES FOR  $F_x$  &  $M_z$ .

$F_x = F = \pm 168.3$  KIPS  
 $M_z = 26F = \pm 4375.8$  IN-KIPS

CONSIDER CRITERION 5.6.1:

THE CROSS SECTION OF INTEREST IS THE SECTION SHOWN ON SHEET 46 FOR LOCATIONS 7 & B. SINCE THERE IS BENDING IN TWO DIRECTIONS, THE FOLLOWING RELATIONSHIPS WILL BE USED TO DETERMINE THE MAXIMUM EFFECT OF BENDING BY THE THERMAL AND DESIGN SEISMIC PIPE LOADS, WEIGHT, ETC.

$$\sigma_x = -\frac{F_x}{A} \pm \frac{c}{I} \sqrt{M_y^2 + M_z^2} = -0.00082 F_x \pm 0.00006 \sqrt{M_y^2 + M_z^2}$$
  
INSIDE  
$$= -0.00082 F_x \pm 0.00010 \sqrt{M_y^2 + M_z^2}$$
  
OUTSIDE

$$\tau_{xy} = \frac{Q}{Ib} [F_y \sin \theta + F_z \cos \theta] \pm \frac{M_{xc}}{I} = 0.00156 [F_y \sin \theta + F_z \cos \theta] \pm 0.000023 M_x$$
  
INSIDE  
$$= 0.00156 [F_y \sin \theta + F_z \cos \theta] \pm 0.000023 M_x$$
  
OUTSIDE

$$\theta = \tan^{-1} \frac{M_y}{M_z}$$

LOCATION	PRESSURE STRESS			DUE TO EXTERNAL LOADS, WEIGHT, ETC.		PRINCIPAL STRESS			STRESS INTENSITY		
	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\sigma_x$	$\tau_{xy}$	$\sigma_1$	$\sigma_2$	$\sigma_3$	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$
7	1.51	3.99	-2.5	2.99	-0.61	4.91	3.58	-2.5	1.33	7.41	6.09
	↓	↓	-2.5	-3.11	-1.71	4.47	-2.08	-2.5	6.55	6.97	0.42
B			0	5.03	-0.28	6.57	3.96	0	2.61	6.57	3.96
	↓	↓	0	-5.15	-2.04	4.50	-4.15	0	8.65	4.50	4.15

$S_{I_{max}} = \sigma_1 - \sigma_2 = 8.65 \text{ KSI} < S_m = 26.7 \text{ KSI}$  LOCATION B

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A276

SHEET 54 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COCKBELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORT

CHECK DATE 4-22-68 BY HEILNER

5. DETAILED ANALYSIS:

e. STRESSES:

1. COMBINED STRESSES - UNCONCENTRATED:

CONSIDER CRITERION 5.b.2:

CUT	BODY	B <sup>2</sup> P 2RE	δP t	EW R	σ <sub>x</sub>	σ <sub>θ</sub>	σ <sub>r</sub>	STRESS INTENSITY		
								σ <sub>x</sub> -σ <sub>θ</sub>	σ <sub>x</sub> -σ <sub>r</sub>	σ <sub>θ</sub> -σ <sub>r</sub>
1	1	6.59	14.32	-2.52	6.59	11.80	-1.25	-5.21	7.84	13.05
1	2	7.16	15.68	-3.52	7.16	12.16		-5.00	8.41	13.41
2	2	5.89	12.89	-9.10	5.89	3.79		2.10	7.14	5.04
4	4	1.51	3.99	17.89	1.51	21.88		-20.37	2.76	23.13
4	5 LONG. AXIS	6.92	19.87	11.21	6.92	31.08		-24.16	8.17	32.33
4	5 CIRC. AXIS	9.32	6.84	11.21	20.53	6.84	↓	13.69	21.73	5.09

$S.I._{MAX} = \sigma_{\theta} - \sigma_r = 32.33 \text{ KSI} < 1.5 S_m = 40.0 \text{ KSI}$  CUT 4 BODY 5  
LONGITUDINAL AXIS  
SEE SHEET 1A.  
POINTS 9 & 10

CONSIDER CRITERION 5.b.3:

LOCATION	PRESSURE STRESS			STRESS DUE TO PIPE LOADS, WEIGHT, ETC			PRIMARY STRESS			STRESS INTENSITY		
	σ <sub>x</sub>	σ <sub>θ</sub>	σ <sub>r</sub>	σ <sub>x</sub>	σ <sub>θ</sub>	τ <sub>θr</sub>	σ <sub>1</sub>	σ <sub>2</sub>	σ <sub>3</sub>	σ <sub>1</sub> -σ <sub>2</sub>	σ <sub>1</sub> -σ <sub>3</sub>	σ <sub>2</sub> -σ <sub>3</sub>
9A	6.92	31.08	-2.5	4.84	1.46	0.63	32.55	11.74	-2.5	20.81	35.05	14.24
B	6.92	31.08	↓	7.14	2.68	1.42	33.86	13.96	↓	19.90	36.36	16.46
C	20.53	6.84	↓	3.57	7.18	0.21	24.10	14.02	↓	10.08	26.60	16.52
D	20.53	6.84	↓	3.88	7.71	-1.55	24.65	14.31	↓	10.34	27.15	16.81
10A	6.92	31.08	0	7.72	7.02	-0.63	38.11	14.62	0	23.49	38.11	14.62
B	6.92	31.08	↓	6.02	4.31	-1.45	35.48	12.85	↓	22.63	35.48	12.85
C	20.53	6.84	↓	4.71	7.41	0.73	26.29	15.21	↓	11.08	26.29	15.21
D	20.53	6.84	↓	6.19	9.42	0.53	26.75	16.23	↓	10.52	26.75	16.23

$S.I._{MAX} = \sigma_1 - \sigma_3 = 38.11 \text{ KSI} < 1.5 S_m = 40.05 \text{ KSI}$  LOCATION 10A

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P A-277

SHEET 55 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COCKRILL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEIKER

5- DETAILED ANALYSIS:

e- STRESSES:

1- COMBINED STRESS - UNCONCENTRATED:

CONSIDER CRITERION 5.0.4:

SAFE END

$$\sigma_x = -\frac{\bar{F}_x}{A} \pm \frac{C}{I} \sqrt{\bar{M}_y^2 + \bar{M}_z^2} = -0.00398 \bar{F}_x \pm 0.00046 \sqrt{\bar{M}_y + \bar{M}_z} \quad \text{POINT 1}$$

$$= -0.00398 \bar{F}_x \pm 0.00054 \sqrt{\bar{M}_y + \bar{M}_z} \quad \text{POINT 2}$$

$$T_{xy} = \frac{Q}{Ib} [\bar{F}_y \sin \theta + \bar{F}_z \cos \theta] \pm \frac{\bar{M}_x C}{2I} = 0.00794 [\bar{F}_y \sin \theta + \bar{F}_z \cos \theta] \pm 0.00023 \bar{M}_x \quad \text{POINT 1}$$

$$\theta = \tan^{-1} \frac{\bar{M}_y}{\bar{M}_z} = 0.00794 [\bar{F}_y \sin \theta + \bar{F}_z \cos \theta] \pm 0.00027 \bar{M}_x \quad \text{POINT 2}$$

LOCATION	PRESSURE STRESS			STRESS DUE TO SEISMIC LOADS		PRINCIPAL STRESS			STRESS INTENSITY		
	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\sigma_x$	$T_{xy}$	$\sigma_1$	$\sigma_2$	$\sigma_3$	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$
1	6.59	11.00	-2.5	6.67	1.27	13.99	11.07	-2.5	2.92	16.49	13.57
			-2.5	-5.69	0.55	11.03	0.97	-2.5	10.96	14.33	3.37
2			0	6.76	1.33	14.11	11.04	0	2.07	14.11	11.04
			0	-5.78	0.49	11.82	0.79	0	11.03	11.82	0.79

S.I.<sub>max</sub> =  $\sigma_1 - \sigma_3 = 16.49 \text{ KSI} < 1.5 S_m = 25.05 \text{ KSI}$  LOCATION 1

SMALL END OF NOZZLE

$$\sigma_x = -\frac{\bar{F}_x}{A} \pm \frac{C}{I} \sqrt{\bar{M}_y^2 + \bar{M}_z^2} = -0.00434 \bar{F}_x \pm 0.00050 \sqrt{\bar{M}_y^2 + \bar{M}_z^2} \quad \text{POINT 3}$$

$$= -0.00434 \bar{F}_x \pm 0.00058 \sqrt{\bar{M}_y^2 + \bar{M}_z^2} \quad \text{POINT 4}$$

$$T_{xy} = \frac{Q}{Ib} [\bar{F}_y \sin \theta + \bar{F}_z \cos \theta] \pm \frac{\bar{M}_x C}{2I} = 0.00864 [\bar{F}_y \sin \theta + \bar{F}_z \cos \theta] \pm 0.00025 \bar{M}_x \quad \text{POINT 3}$$

$$\theta = \tan^{-1} \frac{\bar{M}_y}{\bar{M}_z} = 0.00864 [\bar{F}_y \sin \theta + \bar{F}_z \cos \theta] \pm 0.00029 \bar{M}_x \quad \text{POINT 4}$$

LOCATION	PRESSURE STRESS			STRESS DUE TO SEISMIC LOADS		PRINCIPAL STRESS			STRESS INTENSITY		
	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\sigma_x$	$T_{xy}$	$\sigma_1$	$\sigma_2$	$\sigma_3$	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$
3	7.16	12.16	-2.5	7.24	1.38	15.06	11.50	-2.5	3.56	17.56	14.00
			-2.5	-6.18	0.60	12.19	0.95	-2.5	11.24	14.69	3.45
4			0	8.32	1.45	16.02	11.62	0	4.40	16.02	11.62
			0	-7.26	0.53	12.18	-0.12	0	12.30	12.18	-0.12

S.I.<sub>max</sub> =  $\sigma_1 - \sigma_3 = 17.56 \text{ KSI} < 1.5 S_m = 40.05 \text{ KSI}$  LOCATION 3

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-212-P | A22B

SHEET 56 OF 80

DATE 4-22-69 BY COCKBELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-69 BY HEILKER

5- DETAILED ANALYSIS:

C- STRESSES

1- COMBINED STRESSES - UNCONCENTRATED:

CONSIDER CRITERION 5.6.5:

NOTE HERE THAT THE RANGE OF STRESS INTENSITY WAS CALCULATED AT THE TEN LOCATIONS AS SHOWN ON SHEET 1A FOR THE FOUR ORIENTATIONS A, B, C AND D. THE FOLLOWING TABLE GIVES THE RANGE OF STRESS INTENSITY FOR EACH LOCATION AND ORIENTATION. STRESSES AND STRESS INTENSITIES PRODUCING THESE RANGE OF STRESS INTENSITIES WILL NOT BE PRESENTED FOR ALL LOCATIONS AND ORIENTATIONS. ONLY STRESSES AND STRESS INTENSITIES AT THE LOCATION AND ORIENTATION WHICH PRODUCE THE HIGHEST RANGE OF STRESS WILL BE PRESENTED. THIS WAS LOCATION 10B.

LOCATION AND ORIENTATION	S.I. RANGE
1A	26.72
B	28.13
C	20.84
D	20.59
2A	34.76
B	29.27
C	26.53
D	26.23
3A	29.84
B	36.95
C	30.06
D	29.91
4A	33.31
B	34.64
C	29.97
D	29.64

LOCATION AND ORIENTATION	S.I. RANGE
5A	34.75
B	15.10
C	23.77
D	26.15
6A	11.85
B	28.27
C	18.47
D	16.96
7A	40.36
B	39.48
C	39.96
D	39.96
8A	33.48
B	33.48
C	33.55
D	33.55

LOCATION AND ORIENTATION	S.I. RANGE
9A	41.00
B	43.15
C	29.10
D	29.01
10A	42.42
B	45.46
C	30.83
D	31.39

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A229

SHEET 57 OF 80

DATE 4-22-68 BY Bozzelli

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION OF OUTLET NOZZLE - VESSEL SUPPORT CHECK DATE 4-22-68 BY HELLER

**5. DETAILED ANALYSIS:**  
**a. STRESSES:**

1. CALCULATED STRESSES - UNWELDMENT AREA:

LOCATION 10B

TRANSIENT	PRESSURE STRESS			THERMAL STRESS		THERMAL INDUCED PIPE REACTION STRESS			SEISMIC PIPE REACTION STRESS			STATIC WEIGHT STRESS			
	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$T_{10}$	$\sigma_x$	$\sigma_y$	$T_{10}$	$\sigma_x$	$\sigma_y$	$T_{10}$	
a. Heatup	4.00 HRS	15.42	26.46	0	-1.51	-0.37	-5.60	-4.56	-0.03	-1.97	-1.28	0.91	1.89	1.52	0
	4.25	17.03	29.22		-1.51	-0.38	-5.95	-4.84							
	4.35	17.68	30.34		-1.01	-0.38	-6.09	-4.96							
	4.47	18.44	31.64		-0.98	-0.34	-6.26	-5.09							
	5.00	18.44	31.64		-0.61	-0.17	-6.26	-5.09							
	4.00	15.42	26.46		-1.01	-0.37	-5.60	-4.56		1.97	1.28	-0.91			
	4.25	17.03	29.22		-1.01	-0.38	-5.95	-4.84							
	4.35	17.67	30.31		-1.01	-0.38	-6.09	-4.96							
	4.47	18.44	31.64		-0.98	-0.34	-6.26	-5.09							
	5.00	18.44	31.64		-0.61	-0.17	-6.26	-5.09							
No Load Steady State	18.44	31.64		-0.03	-0.14	-6.26	-5.09		0	0	0				
b. Cool down	4.00 HRS	2.58	4.43		0.96	0.22	-0.66	-0.54	0	-1.97	-1.28	0.91			
	4.25				0.56	0.23	-0.51	-0.25							
	4.35				0.96	0.23	-0.17	-0.14							
	4.47				0.55	0.20	0	0							
	5.00				0.53	0.03	0	0							
	4.00				0.96	0.22	-0.66	-0.54		1.97	1.28	-0.91			
	4.25				0.96	0.23	-0.51	-0.25							
	4.35				0.96	0.23	-0.17	-0.14							
	4.47				0.55	0.20	0	0							
	5.00				0.56	0.03	0	0							

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A230

SHEET 58 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-63 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-63 BY HELVICK

5. DETAILED ANALYSIS:

E. STRESSES:

1. COMBINED STRESSES - UNCONCENTRATED:

LOCATION 10B

TRANSIENT	PRESSURE STRESS		THERMAL STRESS		THERMAL INDUCED PIPE REACTION STRESS		SEISMIC PIPE REACTION STRESS		STATIC WEIGHT STRESS				
	σ <sub>x</sub>	σ <sub>y</sub>	σ <sub>x</sub>	σ <sub>y</sub>	σ <sub>x</sub>	σ <sub>y</sub>	σ <sub>x</sub>	σ <sub>y</sub>	σ <sub>x</sub>	σ <sub>y</sub>			
PLANT LOADS d	10 min	18.44	31.64	0	-0.43	0.03	-6.26	-5.01	-0.03	0	1.99	1.52	0
	15				-0.66	0.16							
	20				-0.95	0.40							
	25				-0.90	0.56							
	30				-0.77	0.63							
FULL LOAD STEADY STATE PLANT LOADS d	10 min				1.15	1.06							
	15				0.17	1.07							
	20				0.57	0.91							
	25				0.66	0.75							
	30				0.55	0.61							
e	100 sec	17.54	30.09		2.47	-0.38							
	225	18.64	31.99										
	40 sec	19.01	32.62										
	100	19.52	31.79										
	200	17.54	30.09										
g	3.5 min	19.26	33.04										
	11	17.62	30.23										
	15.5	18.44	31.64		2.48	-0.38							